

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 201 / 11 KV AJARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.6859	.6859	.7468	.6979	.7545	.7167
2	.695	.6344	.6859	.7468	.6722	.7356	.6979
3	.6767	.6173	.6687	.7095	.6535	.7356	.7095
4	.6584	.6173	.6516	.7282	.6602	.6908	.7095
5	.6653	.6344	.6687	.7282	.6908	.7095	.7468
6	.7023	.6687	.7202	.724	.6653	.7095	.7922
7	.6401	.6516	.7545	.7373	.6722	.6979	.8029
8	.6838	.6516	.703	.7682	.7282	.7095	.7655
9	.695	.7947	.7865	.8316		.7602	.8145
10	.7023	.9055	.8596	.9145	.9877	.8779	.8869
11	.7316	.9425	.9328	.9425	1.0608	.9877	.9511
12	.6653	.924	.9231	.8596	1.0974		.9145
13	.6979	.823	.8779	.9145	1.0269		.8048
14	.6219	.8413	.9694	.8596	.9619	1.2489	.8413
15	.7316	.905	.8962	.905	1.0642	1.1222	.8686
16	.7133	.8688				1.0059	.8962
17	.7316	.8688	.9511			.9412	.4938
18	.6687	.8507	.8596			.8688	.9425
19	.9088	.9145	1.0242	.8145		1.1403	1.0425
20	.9945	1.0745	1.1041	.9145		1.0498	1.1888
21	.9259	.9431	1.0642	.9231	.9808	.9774	1.0791
22	.8916	.9259	.9694	.8962	.9431	.9431	1.0059
23	.8059	.8059	.8775	.7842	.8676	.8775	.8413
24	.7316	.703	.703	.7733	.6908	.7922	.7922
Max	.9945	1.0745	1.1041	.9425	1.0974	1.2489	1.1888
Min	.6219	.6173	.6516	.7095	.6535	.6908	.4938
Avg	.7348	.8022	.8407	.8201	.8401	.8789	.8460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 202 / 11 KV Bhadvan Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.2561	.2401	.2054	.2987		.2195
2	.3511	.2534	.2572	.1829	.2772		.2218
3	.3734	.2427	.2401	.2012	.2987		.2378
4	.3734	.2561	.2401	.181	.2772		.2241
5	.3734	.2801	.2401	.181	.2801		.2587
6	.3841	.2926	.2229	.2054	.1663		.2957
7	.3109	.2896	.2229	.1991	.2195		.3174
8	.2987	.2427	.2229	.3077	.2218		.2743
9	2.7618	2.6425	1.086	.2054	.2195		.1267
10	2.9683	2.5882	.3982	.1867	.1829		.1267
11	2.8778	2.7149	.7602	.567	.1848		.0914
12	2.7984	2.5701	.4207	.7421	.1478		.0914
13	2.7149		.7865	.4024	.0943		.0914
14	2.3529		.6767	.4024	.0377		.0924
15	2.6787		.6984	.3439	.056	.0181	.1097
16	2.4874	.3475				.0183	.0924
17	.2229	.3475				.1646	.1478
18	.3429	.5853				.1829	.1294
19	.2915	.2743	.1646			.128	.1663
20	.3086	.3045	.1629	.1448		.1267	.1848
21	.2743	.2915	.168	.1829		.1267	.1848
22	.2743	.2915	.2218	.2801		.1307	.1646
23	.2915	.2743	.2054	.2987		.1307	.1097
24	.3696	.2229	.2572	.2054	.2987		
Max	2.9683	2.7149	1.086	.7421	.2987	.1829	.3174
Min	.2229	.2229	.1629	.1448	.0377	.0181	.0914
Avg	1.1181	.7413	.3759	.2813	.2038	.1141	.1721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 203 / 11 KV Gavase Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3575	1.6244		1.9044			.0187
2	1.3394	1.419		1.8298			.0189
3	1.3352	1.386	1.3032	1.7924			.0187
4	1.3169	1.4003	1.3203	1.6827			.0189
5	1.2851	1.4083		1.701			.0189
6	1.3937	1.4449		1.7924			.0187
7	1.4998	1.4998	1.3889	1.7013			.0189
8	.0747	.0924	.0857	.0934			.0187
9	.056	.0934	.0739	.0739			
10	.056	.0747	.0732	.0747			.1629
11	.056	.0747	.0554	.056			.1646
12	.0183	.0747	.0732	.0566			.1829
13	.0362	.0732		.0549			.1646
14	.0366	.0732	.0549	.0549			.1646
15	.0366	.0732	.0549	.0543	.2058	.1829	.4024
16	.0362	.0724				.1646	.5121
17	.0724	.0732	.0732			.1646	.0732
18	.0857	.0914	.0724			.0183	.0366
19	.1029	.1086	.0724			.0366	.0554
20	.1029	.1075	.1086			.0183	.0739
21	.1029	.1029	.1109			.0183	.0924
22	1.9547	1.7318	1.9805	.0187		.0185	.0914
23	1.989	1.6632	2.0633			.0185	.0549
24	1.4449	1.869		1.9753			.0189
Max	1.989	1.869	2.0633	1.9753	.2058	.1829	.5121
Min	.0183	.0724	.0549	.0187	.2058	.0183	.0187
Avg	.6579	.6930	.5273	.8775	.2058	.0712	.1044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 204 / 11 KV Watangi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6651	1.701		1.7375	.0373	.0747	
2	1.6644	1.6301		1.7924	.0373	.0566	
3	1.6461	1.6301	1.6461	1.7375	.0373	.0566	
4	1.6461	1.6655	1.6651	1.7741	.0377	.056	
5	1.6644	1.7194		1.8298	.0377	.0754	
6	1.7193	1.8107		1.7924	.0377	.0747	
7	1.701	1.829	1.828	1.6804	.0187	.0747	
8	.3174	.2561	.298	.2614		.056	
9	.2033	.2587	.2743	.2427	1.3032	.1097	.5792
10	.2402	.2402	.2561	.2427	1.2308	.2378	
11	.2378	.2378	.2378	.2427	1.5384	.4024	1.1523
12	.2012	.2218	.2378	.2402	1.6651		1.1157
13	.2241	.2172	.2378	.2378	1.5684		1.0059
14	.1991	.1991	.2195	.2195	1.475	.5611	1.0608
15	.2353	.2743	.2172	.2172	1.3817	1.2254	1.262
16	.2378	.2743				.2195	1.2071
17	.2534	.2561	.2353			.0732	.2926
18	.2572	.2561	.2561			.1829	.2957
19	.2572	.2926	.2896			.0732	.3292
20	.3086	.3109	.3224	.0724			.4024
21	.3086	.2915	.3174	.0366		.1132	.439
22	1.6804	1.6975	1.9418	.0373	.0747	.112	.4024
23	1.749	1.8004	1.9231	.0366	.0754	.112	
24	1.7013	1.6289		1.7924	.0373	.0754	.1509
Max	1.749	1.829	1.9418	1.8298	1.6651	1.2254	1.262
Min	.1991	.1991	.2172	.0366	.0187	.056	.1509
Avg	.8466	.8625	.6891	.8112	.6232	.1915	.6925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 205 / 11 KV WATANGI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4733	.5068	.5487	.3547	.0747	.3018
2	.4572	.4572	.4938	.5415	.3361	.0754	.2987
3	.4481	.439	.5121	.5304	.3395	.0747	.3018
4	.439	.4344	.4854	.5487	.3547	.0754	.3174
5	.4481	.462	.4854	.5601	.3395	.0747	.3395
6	.5228	.4854	.5415	.567	.3547	.0754	.3584
7	.5544	.5788	.5316	.6722	.3921	.0934	.4338
8	.5175	.5914	.5121	.6161	.4481	.0754	.2987
9	.5601	.6767	.5304	.6535	.439	.0732	.6878
10	.5544	.6468	.6401	.567	.5175	.0549	.7059
11	.462	.5304	.5853	.3841	.4854	.1463	.5304
12	.4024	.5729	.6401	.5121	.5788		.5121
13	.3658	.5487	.4706	.4755	.6161		.4251
14	.3439	.5304	.5249	.567	.5601	.1463	.4024
15	.3801	.4887	.5487	.543	.3921	.4706	
16	.4024	.5121				.4706	.0549
17	.4525	.4755	.6219			.5792	.0549
18	.4973	.6154	.6767			.6697	.0732
19	.7888	.8869	.8507			.724	.1646
20	.9945	1.0029	.9511	.362			.6838
21	.8916	.823	.9431	.5041			.8316
22	.7716	.7373	.811	.4668	.0934	.168	.8048
23	.6173	.583	.6161	.3921	.0754	.3584	.5304
24	.5359	.5144	.4973	.5658	.3584	.0747	.3174
Max	.9945	1.0029	.9511	.6722	.6161	.724	.8316
Min	.3439	.4344	.4706	.362	.0754	.0549	.0549
Avg	.5372	.5861	.6077	.5289	.3909	.2278	.4100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 206 / 11 KV MIDC feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1233	.1425	.1385	.161
2	.1222	.1431	.1381	.1568
3	.1223	.1427	.1389	.157
4	.1227	.1238	.1397	.1576
5	.1222	.1424	.1399	.1568
6	.1212	.145	.1294	.1817
7	.121	.1448	.0937	.1606
8	.3774	.1427	.1267	.1541
9	.1223	.1429	.1748	.1928
10	.1231	.1313	.2541	.2231
11	.1234	.1507	.2282	.2029
12	.121	.1608	.2246	.2354
13	.1177	.1496	.2231	.2292
14	.1397	.1857	.2133	.2088
15	.1212	.1846	.2358	.1932
16	.1206	.1737		
17	.1385	.1509	.1177	
18	.1167	.146	.2354	
19	.1162	.1294	.2274	
20	.1156	.146	.2141	
21	.1118	.1389	.1589	
22	.1124	.1164	.1562	
23	.1227	.1185	.1236	
24	.1252	.1393	.148	.0747
Max	.3774	.1857	.2541	.2354
Min	.1118	.1164	.0937	.0747
Avg	.1325	.1455	.1730	.1779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 207 / 11 KV Bhadvan Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3921	.3258	.3921	.3772	.1132	.3772
2	.3475	.3881	.3086	.4108	.3734	.1132	.3961
3	.3511	.3734	.3086	.3881	.3547	.1132	.3921
4	.3316	.3772	.3258	.3734	.3734	.112	.3734
5	.3361	.3547	.3086	.3921	.3734	.1307	.4338
6	.3921	.3511	.3772	.4294	.4668	.1509	.4668
7	.3292	.439	.4287	.4854	.4527	.1494	.5281
8	.4207	.3921	.4458	.5041	.4481	.1698	.5658
9	.4207	.4066	.4572	.5041	.4435	.1646	.543
10	.4108	.4854	.4572	.462	.4805	.128	.4572
11	.3696	.439	.4938	.439	.4481		.3439
12	.2743	.3881	.4207	.3841	.4294		.439
13	.3841	.3658	.4207	.3658	.3961		.4207
14	.3658	.3841	.4207	.3658	.415	.5304	.3696
15	.3292	.4207	.4163	.362	.3772	.3109	.3841
16	.3292	.4572				.5304	.4207
17	.3475	.4207	.2561			.567	.4938
18	.3601	.4755	.3982			.5611	.4251
19	.5658	.6401	.4525			.7133	.5853
20	.7545	.7499	.6219	.2896		.6878	.8316
21	.6516	.6001	.6348	.5415	.1698	.6878	.7023
22	.5658	.5487	.5658	.499	.168	.6161	.5853
23	.463	.4115	.4668	.4108	.1509	.5281	.5304
24	.3658	.3772	.3258	.3841	.3734	.112	.4108
Max	.7545	.7499	.6348	.5415	.4805	.7133	.8316
Min	.2743	.3511	.2561	.2896	.1509	.112	.3439
Avg	.4092	.4433	.4190	.4192	.3722	.3424	.4782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 405 / 33 KV Amboli

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4266	1.1523	.5201	1.3169	.2829	.2263	.7922
2	1.3717	1.1763	.5487	1.4003	.2801	.2263	.7282
3	1.3169	1.2323	1.262	1.3443	.2263	.2263	.679
4	1.262	1.1763	1.1694	1.3169	.2241	.2263	.6722
5	1.2197	1.2323	.5316	1.3443	.2241	.3395	.7842
6	1.4815	1.4003	.6516	1.4003	.2829	.5658	.9054
7	1.4815	1.5123	1.4969	1.2883	.2801	.679	1.1317
8	.8779	1.5524	.8596	.823	.4481	.679	1.3014
9	2.8532	3.2922	3.0178	.8779	1.4266	1.262	1.2489
10	3.0727	3.2922	2.8532	.8779	1.8107	1.701	1.1946
11	3.1824	3.1824	1.8107	.7682	1.5364	1.5364	.8779
12	3.0178	2.9081	2.7435	2.0302	1.5203		.7133
13	2.963	.7682	2.6337	2.2805	1.6975		.7682
14	2.9081	.7133	2.2805	2.3594	2.037	1.0425	.7133
15	3.4019	.7682	2.2565	2.3891	2.0165	1.0425	.6584
16	2.6063	2.5789		.2743		.9328	.6584
17	.8688	.823	.823			.7682	.5487
18	.7202	.823	1.0317			.8688	.7133
19	.8745	1.0317	1.1946			.9231	.7682
20	1.1317	1.2071	1.3169	.543		.5658	.9328
21	.9774	1.0288	1.2883	.0566	.2241	.3361	.823
22	1.9033	1.749	1.9605	.056	.2829	.5041	.7682
23	1.4918	1.4918	1.6244	.3395	.2829	.5093	.6036
24	.6173	1.1831	.5658	1.4003	.3361	.2263	.4481
Max	3.4019	3.2922	3.0178	2.3891	2.037	1.701	1.3014
Min	.6173	.7133	.5201	.056	.2241	.2263	.4481
Avg	1.7928	1.5531	1.4974	1.1661	.8116	.6994	.8097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 201 / 11KV UtturVg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5112	1.6476	1.5196	1.6008	1.5333	1.3317	1.6445
2	1.4441	1.6019	1.4342	1.5354	1.5188	1.3089	1.5855
3	1.363	1.5352	1.454	1.4575	1.5158	1.3083	1.5411
4	1.3413	1.4472	1.4658	1.4723	1.4906	1.3279	1.5566
5	1.3408	1.4493	1.4693	1.526	1.5287	1.3695	1.5093
6	1.464	1.6114	1.6895	1.6552	1.6008	1.5074	1.5634
7	1.6932	1.8103	1.7699	1.7795	1.7143	1.6282	1.6925
8	1.6089	1.8023	1.8161	1.8054	1.6674	1.8621	1.6826
9	1.563	1.8762	1.7535	1.9079	1.821	1.9159	1.8389
10	1.659	1.7947	1.7349	1.9505	1.8397	1.9387	1.9509
11	1.4163	1.7955	1.7555	1.9776	1.7456	1.8622	1.9913
12	1.4316	1.6739	1.784	1.8652	.8352	2.0549	1.8462
13	1.4815	1.6651	1.7295	1.8537	1.7044	2.117	1.7037
14	1.5436	1.8354	1.8381	1.6217	1.7311	2.005	1.6872
15	1.5043	1.7311	1.7612	1.4414	1.7174	2.0744	.6348
16	1.486	1.7273	1.1816	1.6217	1.76	2.0576	1.688
17	1.5097	1.6423	1.555	1.744	1.4799	1.8481	1.691
18	1.4876	1.6641	1.8206	2.0465	1.7516	1.8728	1.9353
19	2.2066	2.1841	2.0564	2.244	.8871	2.0386	2.1414
20	2.7755	2.8228	2.6684	2.4432	2.114	2.1372	2.6833
21	2.6582	2.6856	2.3895	2.3091	2.0633	2.2097	2.6864
22	2.4752	2.0599	2.0813	1.8967	2.0701	1.8698	1.2727
23	2.1609	2.0324	1.9586	1.8362	1.8381	1.8157	2.1403
24	1.7574	1.72	1.6388	1.6095	1.6259	1.6541	1.6579
Max	2.7755	2.8228	2.6684	2.4432	2.114	2.2097	2.6864
Min	1.3408	1.4472	1.1816	1.4414	.8352	1.3083	.6348
Avg	1.7035	1.8257	1.7636	1.8000	1.6481	1.7965	1.7635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 202 / 11KV Bahirewadi Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8608	1.2014		1.816	.0324	.032	.032
2	.8692	1.1329		1.6571	.0324	.032	.032
3	.8306	1.0802	.8965	1.5703	.0324	.032	.032
4	.8646	1.0982	.8994	1.5439	.0324	.032	.032
5	.9487	1.1942	.4748	1.47	.0486	.032	.032
6	1.0155	1.4655	.1562	1.6356	.0524	.032	.048
7	1.4784	1.8603	1.7473	1.7455	.1271	.077	.1059
8	.1629	.2772	.2511	.237	.1326	.0991	.1189
9	.1271	.1439	.1172	.133	1.2373	1.0667	1.0391
10	.088	.1233	.1646	.154	2.3967	2.2504	2.1908
11	.1112	.0282	.1662	.1341	1.88	2.2793	2.0045
12	.0785	.032	.1408	.1326	.7026	2.2348	2.0588
13	.0396	.0343	.1307	.0655	2.1106	2.1308	1.9965
14	.0876	.0724	.0975	.048	1.9677	2.0542	1.9521
15	.1509	.0358	.0623	.0686	2.0342	2.0786	1.044
16	.1394	.061	.1225	.1301	1.9161	1.7735	2.1654
17	.14	.0974	.1035	.1492	1.0378	.9928	1.2674
18	.1469	.1471	.0867	.1431	.1547	.1469	.1578
19	.1662	.1532	.0722	.1393	.0846	.1646	.1616
20	.1662	.1452	.1164	.1393	.0486	.1157	.1578
21	.157	.1332	.1172	.14	.0324	.0324	.1378
22	1.3223	1.6255	1.5882	.0821	.0671	.032	.0808
23	1.3313	1.608	1.5718	.0524	.0335	.032	.1547
24	1.1088	1.2894	.7171	1.2323	.0324	.032	.0998
Max	1.4784	1.8603	1.7473	1.816	2.3967	2.2793	2.1908
Min	.0396	.0282	.0623	.048	.0324	.032	.032
Avg	.5163	.6267	.4455	.6091	.6761	.7410	.7126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 203 / MAHAGOND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1025	.1223	.1147	.0354	1.1339	.0354	.0354
2	.1017	.1238	.1147	.0537	1.086	.0354	.9053
3	.122	.12	.1154	.0354	1.0784	.0354	.9107
4	.1246	.1238	.1154	.0354	1.0578	.0354	.9358
5	.0735	.1401	.1147	.0351	1.0955	.0354	1.0013
6	.117	.1435	.137	.0351	.28	.0709	1.1005
7	.1101	.1462	.1355	.0354	.0537	.2153	1.3085
8	.12	.1553	.1139	.0354	.0354	.1646	1.2696
9	2.1635	2.4406	2.1262	.075	.0354	.2029	.6632
10	2.4714	2.4985	2.4833	.0948	.0362	.0181	.0181
11	2.1331	2.2794	2.2265	.0377	.0606	.0181	.0181
12	1.7056	2.1003	2.1876	1.249		.0183	.0181
13	1.6064	1.0479	2.1086	1.4289	.1075	.0183	.0181
14	1.768		2.0439	1.6133	.1351	.0181	.0181
15	1.8412		2.1302	1.3672	.0385	.0181	
16	2.0043	1.4586	.6897	1.1306	.0362	.0181	.0181
17	.3433	1.7343	.0471	1.0974	.0407	.0573	.0177
18	.0753	1.6031	.0362	1.0852	.0369	.0177	.0177
19	.1169	.2824	.0514	.1759	.0305	.0177	.0177
20	.1446	.125	.0385	.0499	.4556	.0177	.0177
21	.153	.1435	.0499	.1147	.3245	.0177	.0177
22	.1546	.1177	.0674	1.0978	.3378	.0177	
23	.1261	.1177	.0354	1.1324	.0177	.0177	.0177
24	.1223	.1162	.0354	.6428	.5609	.0177	.0177
Max	2.4714	2.4985	2.4833	1.6133	1.1339	.2153	1.3085
Min	.0735	.1162	.0354	.0351	.0177	.0177	.0177
Avg	.7417	.7791	.7216	.5289	.3511	.0475	.3801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 201 / 11 KV Kanoli Vg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.4973	.4508	.4681	.181	.4115	.4801
2	.5041	.4973	.4458	.4115	.1867	.3772	.4801
3	.4854	.4973	.4382	.4252	.181	.3467	.4973
4	.5041	.4801	.4458	.4252	.1867	.3467	.4973
5	.5041	.4801	.4801	.4458	.1991	.4161	.5144
6	.499	.4973	.5258	.5316	.1943	.4557	.5316
7	.5175	.5144	.5144	.5434	.2534	.5144	.583
8	.5975	.583	.5487	.5847	.3439	.5548	.6173
9	.5359		.6001	.591		.5548	.5658
10	.5359	.4973	.5144	.4973		.583	.4458
11	.5041	.4508	.5258		.4854	.583	.5258
12	.4458	.4908	.4961	.4706	.4854		.3391
13	.4115	.4854	.5138	.4294	.5201		.3856
14	.3772	.4801		.4706	.5258		.407
15	.4115	.4207	.4344		.5487		.3391
16	.4115	.4854		.3856	.5548	.4287	.5373
17	.4115	.4854	.4961		.5487	.6859	.5316
18	.463	.5548	.5373		.5548	.703	.583
19	.6516	.6661	.6154		.5201	.6859	.7522
20	.7373	.8413	.7455		.3814		.9328
21	.703	.7011	.7265		.5487	.7373	.7343
22	.6859	.6516	.6878		.5609	.6859	.6836
23	.5316	.5548	.5609		.5144	.5658	.6335
24	.5041	.5144	.4854	.5258	.197	.4557	.5144
Max	.7373	.8413	.7455	.591	.5609	.7373	.9328
Min	.3772	.4207	.4344	.3856	.181	.3467	.3391
Avg	.5165	.5359	.5359	.4804	.3942	.5312	.5463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 202 / 11KV Sarambalwadi Ag.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0686	.0693	.0678	.4001	.3429	.3429
2	.0747	.0686	.0701	.0663	.4161	.3506	
3	.0747	.0686	.0693	.0678		.2572	
4	.0625	.0686	.0686	.0648		.2572	
5	.0747	.0686	.0686	.0678		.3506	
6	.0747	.0343	.0347	.0678		.5548	
7	.056	.0343	.052	.0324		.5548	.4287
8	.0747	.0343	.0343	.0332		.5548	.4115
9	.6249	.7545	.7628	.0328	.4161	.0175	
10	.6249	.7545	.6859	.0164		.0175	.0171
11	.6859	.7545	.7796		.0173	.0171	.017
12	.7545	.7712	.7011	.5944	.0173		.0164
13	.7545	.7545	.6935		.0343		.0164
14	.7545	.7545		.602	.0173	.0171	.0162
15	.7545	.7545	.6935	.5868	.0173	.0171	.016
16	.7545	.6859		.6241	.0173	.0171	.0164
17	.0171	.7011	.0164		.0175		.032
18	.0171	.6935	.0162				.0164
19	.0686	.0343	.0324		.0175	.0343	.0312
20	.0686	.0693	.0663		.0701	.0343	.0316
21	.0686	.0343	.0663		.0351	.0343	.0328
22	.0686	.0686	.0663		.0343	.0343	.0332
23	.0686	.0701	.0655		.0347	.0514	.0312
24	.0747	.0686	.0686	.0655	.4534	.0686	.0514
Max	.7545	.7712	.7796	.6241	.4534	.5548	.4287
Min	.0171	.0343	.0162	.0164	.0173	.0171	.016
Avg	.2803	.3404	.2355	.1993	.1260	.1792	.0866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 203 / 11 kv Kolindre Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2029	1.406	1.387	1.3176	.1307	.1029	.0857
2	1.1873	1.406	1.387	1.3321	.1307	.1052	.0857
3	1.1584	1.4403	1.2136	1.3112		.1052	.0857
4	1.1883	1.4403	1.2136	1.283		.1052	.0857
5	1.2037	1.4403	1.2971	1.4266		.1029	.0857
6	1.2811	1.4403	1.283	1.3672		.1052	.1029
7	1.3123	1.4403	1.3032	1.3672		.104	.1029
8	.2054	.1886	.1734	.213		.104	.0857
9	.2054	.1715	.1734	.1492	1.1523	.5144	.8916
10	.1867	.1715	.1715	.1357		.7362	.8916
11	.1867	.1734	.1526		1.3176	.7202	.9214
12	.1715	.1734	.1187	.1494	1.3672		
13	.1715	.1734	.0983	.112	1.0517		.7865
14	.1715	.1753		.0701	1.3321	1.0974	.4588
15	.1715	.1734	.1094		.9259	1.0974	.9015
16	.1543	.1734		.112	.9465	.823	.9114
17	.1715	.1753	.1017		.5548	.0857	.0983
18	.1886	.1402	.1147			.1029	.1017
19	.1886	.208	.1638		.1029	.0857	.1134
20	.1886	.1734	.1311		.1029	.1543	.1147
21	.1715	.1715	.1357		.1052	.1029	.0995
22	1.4403	1.387	1.382		.104	.1029	.1187
23	1.4746	1.387	1.3969		.1052	.0857	.096
24	1.1584	1.406	1.387	1.4118	.1307	.1029	.0857
Max	1.4746	1.4403	1.3969	1.4266	1.3672	1.0974	.9214
Min	.1543	.1402	.0983	.0701	.1029	.0857	.0857
Avg	.6309	.6932	.6770	.7839	.5975	.3021	.3179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 201 / 11 KV Devarde Vg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.2075	.1715	.2263	.1463	.2033	
2	.1494	.1905	.2012	.1848	.1463	.2241	.1463
3	.1494	.1886	.1848	.1848	.1463	.1867	.1478
4	.1478	.1886	.1829	.1867	.1463	.1509	.1494
5	.1848	.2054	.2058	.2263	.1478	.1509	.1886
6	.2561	.2587	.2374	.2614	.1905	.1715	.1886
7	.3258	.3944	.2263	.3353	.2507	.3403	.2012
8	.3315	.3467	.2774	.1417	.2195	.3012	.3467
9	.2743	.3772	.3189	.3121	.2172	.3174	.2926
10	.298	.3898	.3353	.2743	.3506	.2785	.2601
11	.2241	.3189	.3018	.2683	.2713	.3189	.2601
12	.1646	.3258	.3018		.3467		.2279
13	.2378	.3239	.3189	.2683	.2721		.2629
14	.2601	.2984		.2926	.2328	.3544	.2835
15	.3403	.3052	.3506	.2507	.1867	.3315	.1227
16	.3841	.2835				.3521	.2279
17	.4031	.2915	.1966			.3429	.2984
18	.3077	.2683	.373	.1075		.3429	.4334
19	.4251	.4252	.3856			.394	.3982
20	.5041	.439	.5121				.499
21	.3772	.3982	.5014		.2263	.2835	.3921
22	.381	.3361	.415		.1886	.3018	.3395
23	.3018	.2614	.3018	.181	.1886	.1867	.2829
24	.1886	.2263	.208	.2641	.1463	.1524	.1867
Max	.5041	.439	.5121	.3353	.3506	.394	.499
Min	.1478	.1886	.1715	.1075	.1463	.1509	.1227
Avg	.2827	.3020	.2958	.2333	.2116	.2708	.2668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 202 / 11 KV Velvatti Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.852	.6464		.6401	.1524	.132	.1509
2	.7811	.5992		.6226	.1524	.1509	.1478
3	.7362	.5468	.4641	.6226	.1334	.1509	.1494
4	.6562	.5601	.4915	.6093	.1334	.1509	.1509
5	.6249	.6154	.4938	.6173	.1334	.1509	.1494
6	.8619	.7045		.6019	.1867	.1698	.132
7	.788	.6097	.6882	.4214	.1905	.1509	.132
8	.132	.1509	.1143	.1509	.1886	.1509	.1132
9	.0953	.1267	.1143	.1478	.9282	.8817	.6478
10	.0566	.1132	.112	.1109	.9448	.852	.5121
11	.0377	.132	.1294	.0914	.8122	.5921	.3281
12	.0754	.0972	.0924	.0924	.6722		.2743
13	.0754	.1097	.0924	.0914	.5117		.208
14	.0754	.1307		.1109	.4725	.4938	.1882
15	.0943	.1307	.1075	.1097	.4843	.4755	.2258
16	.1132	.1294				.4172	.2494
17	.132	.1294	.1307	.1075		.132	.0686
18	.132	.1402	.1867	.1509		.1307	.1307
19	.1698	.2075	.1905			.1509	.1307
20	.1905	.1905	.1715				.132
21	.1905	.1905	.1715		.1698	.1698	.1509
22	1.0576	.964	.8288		.1698	.1509	
23	.9945	.8149	.788	.1524	.1509	.1509	.1307
24	.9069	.7293		.6167	.1524	.1509	.1509
Max	1.0576	.964	.8288	.6401	.9448	.8817	.6478
Min	.0377	.0972	.0924	.0914	.1334	.1307	.0686
Avg	.4096	.3654	.2982	.3194	.3547	.2836	.2023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 203 / 11 KV Kittawade Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1132		.1334	.116	.2462	
2	.1307	.1132	.168	.1132	.1147	.2462	.3048
3	.1307	.1132	.1509	.132	.1134	.2286	.3311
4	.132	.1132	.1509	.1307	.0972	.2286	.3395
5	.1307	.1143	.1509	.112	.0983	.2347	.3963
6	.1132	.1143	.1307	.1334	.0377	.2408	.4666
7	.1143	.1109	.132	.132	.0187	.2378	.5247
8	.132	.0943	.168	.132	.0179	.208	.5624
9	1.8378	1.9765	1.8004	.1307	.0171	.0347	.0754
10	1.9591	1.9765	1.6956	.1132	.0177	.052	.0543
11	1.9418	1.8551	.759	.1132	.0177	.0532	.0168
12	1.7318	1.6632	1.543	1.1603	.0554		.0914
13	1.6804		1.5089	1.3426	.0354		.0732
14	1.7147			1.4251	.0509	.0446	.0709
15	1.6975		1.2944	1.4754	.0469	.0772	.0716
16	1.7337	1.3748				.1097	.0709
17	.1132	1.3426	.0739			.1132	.0693
18	.1307	1.2955	.1307	.1406		.0747	.052
19	.1132	.1524	.1509			.0943	.0732
20	.132	.1715	.1509			.0895	.112
21	.1334	.1905	.1698		.0526	.0895	.0934
22	.1524	.1715	.1524		.0724	.1132	
23	.132	.1524	.1524	.1341	.0514	.0943	.1086
24	.132	.1132	.168	.1334	.1492	.0503	.0934
Max	1.9591	1.9765	1.8004	1.4754	.1492	.2462	.5624
Min	.1132	.0943	.0739	.112	.0171	.0347	.0168
Avg	.6814	.6344	.5144	.3993	.0621	.1346	.1842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 146006 / 220KV Gadhinglaj(Mumewadi)

Feeder No / Name : 408 / 33 KV Soot Girni

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	.8745
Max	.8745
Min	.8745
Avg	.8745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 201 / 11 KV KOWAD VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3315	.0754	.3647	.415	.4854	.3429
2			.4481	.3391	.3772		.3353
3			1.1401	.2743	.3772		.2984
4			1.1271	.2683	.415		.3052
5			1.1271	.2683	.4481		.3391
6			.4854	.5365	.5228		.4359
7		.5765	1.1934	.583	.5544		.5144
8		.5487	.5601	.583			.6443
9		.5765	.5228			.6516	.6348
10		.6722	.6348	.7011			.695
11	.4409	.6722		.7011			.5853
12	.4115	.6219	.6661	.631			.6219
13	.373	.5487	.631	.5258			.5853
14	.3772	.5228	.5068	.5014			.4481
15	.4115	.5601	.567	.5014			.5601
16	.407	.5487	.6516				.5975
17	.4207	.5975	.6024			.6173	.6173
18		.5853	.5609				.6859
19		.8215		.1698			.823
20	.8048	.9335		.9054			
21	.5487	.8962		.8299	.8048		.7578
22	.6036	.7468		.6413	.6584		
23		.6722		.5658	.5853		
24	.4481	.3772	.5975	.4748	.4904	.5601	.4748
Max	.8048	.9335	1.1934	.9054	.8048	.6516	.823
Min	.373	.3315	.0754	.1698	.3772	.4854	.2984
Avg	.4718	.6216	.6721	.5183	.5135	.5786	.5382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 202 / 11 KV Kagani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0277		1.4937		.0381	
2		.9922		1.4883			
3		.9602		1.4723			
4		.9709		1.4373			
5		1.0166		1.4022			
6		.9835		1.4563			
7		.9465					
8			.0381				
9	.4915		.0381			.3688	.2321
10			.0381	.016			.2321
11				.0191			.2321
12		.0381	.0171	.0183			
13			.0175				.3315
14		.0381	.016	.0191			.3315
15		.0381	.016	.0191			.3353
16		.0381	.0171				.3353
17		.0381					
18		.0381	.0171				
19		.0381					
20		.0381					
21		.0381			.0381		
22	.9602	1.1271			.0381		
23	.9835				.0381		
24	.4458	.9835		1.4175		.0381	
Max	.9835	1.1271	.0381	1.4937	.0381	.3688	.3353
Min	.4458	.0381	.016	.016	.0381	.0381	.2321
Avg	.7203	.5195	.0239	.8549	.0381	.1483	.2900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 203 / 11 KV Kudnoor Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3353	.3734	.3052	.3429	.4572	.3429
2		.2984	.3734	.2713	.3048		.3391
3		.2713	.3696	.2743	.3048		.2743
4		.2683	.3696	.3052	.3048		.2713
5		.2713	.3361	.373	.3429		.2984
6		.2984	.3734	.4641	.415		.3391
7		.503	.4108	.4572	.5658		.4409
8		.6104	.6348	.5426			
9		.6104	.7468	.5967			.7095
10		.7842	.7095	.7164			.695
11		.7842		.6805			.7095
12		.7842	.7316	.5792			.6722
13		.5975	.7682	.6089			.6722
14		.5975	.7682	.6447			.5228
15		.5975	.6219	.6089			.5975
16		.6348	.5601				.6348
17		.5228	.5853				.6173
18		.4854	.6219	.3429			.6104
19		.5228		.6097			.5426
20	.5765	.7095		.5716			
21	.6036	.5601		.5335	.5228		.5487
22	.5426	.5601		.5335	.439		
23	.4359	.4108		.5335	.3361		
24	.4954	.373	.3734	.3391	.4191	.4481	.3688
Max	.6036	.7842	.7682	.7164	.5658	.4572	.7095
Min	.4359	.2683	.3361	.2713	.3048	.4481	.2713
Avg	.5308	.5163	.5404	.4951	.3907	.4527	.5104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 204 / 11 KV KUDNOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0381		.3052	.0381	.2012
2			.0381		.3086		.2374
3			.0381		.3086		.2401
4			.0381		.3052		.2401
5			.0381		.3391		.2427
6			.0381		.0259		.2743
7			.0381		.0259		.2713
8	.0008	.4839	.5731				
9	1.1683	2.8738	3.0815	.0008			.0381
10	1.2437	3.0331	3.1188	.0236			.0381
11	.7659	3.0308	1.6331	.0244			.0381
12		3.1519	2.2756	2.5301			.0381
13		.6043	2.9222	2.7969			.0381
14			2.8913	2.9127			.0381
15			2.8242	2.8963			.0381
16		2.9238	.3609	1.4274			.0381
17		2.841	2.2771				
18		2.6967	2.2504	.0256			
19		.0381		.0263			
20		.0381		.0263			
21		.0381		.1101	.0381		
22		.0381			.0381		
23		.0381		.6885	.0381		
24	.0377		.0381	.3597	.3052	.0381	
Max	1.2437	3.1519	3.1188	2.9127	.3391	.0381	.2743
Min	.0008	.0381	.0381	.0008	.0259	.0381	.0381
Avg	.6433	1.5593	1.2902	.9892	.1853	.0381	.1341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 205 / 11 KV KAGANI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0846	.1578	.1837	.1585	.0754	.0762	.0663
2	.08	.1516	.1608	.1585	.0754		.0686
3	.0793	.1517	.16	.1585	.0754		.0671
4	.0732	.1486	.157	.1554	.0747		.0671
5	.0312	.1486	.1562	.1547	.0747		.0671
6	.0861	.2008	.2229	.2092	.0747		.1017
7	.1143	.301	.2934	.2317	.112		.1341
8	.1158	.3437	.3178	.2729			
9	.1517	.3887	.3132	.3255			.1494
10	.1692	.3224	.3582	.3026			.1494
11	.2329	.3216	.1837	.253			.1494
12	.1707	.3467	.2713	.2179			.1494
13	.1624	.1799	.2682	.1139			.1494
14	.1608	.1814	.2629	.1059			.0762
15	.197	.1791	.2309	.1699			.0747
16	.2065	.1806	.224	.0914			.0762
17	.1075	.2286	.2408	.0533			.1029
18	.1227	.1257	.2088	.2306			.1372
19	.144	.3087	.1661	.3102			.1715
20	.4481	.4672	.367	.3753			
21	.455	.4321	.2469	.3677	.1494		
22	.4481	.3818	.208	.2778	.1494		
23	.2827	.327	.1692	.1829	.0747		
24	.2088	.1943	.2324	.1818	.0754	.0747	.0671
Max	.455	.4672	.367	.3753	.1494	.0762	.1715
Min	.0312	.1257	.1562	.0533	.0747	.0747	.0663
Avg	.1805	.2571	.2335	.2108	.0919	.0755	.1066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 206 / 11 KV Hemrus

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.2263	.2438	.2306		.112	.0678
2	.1311	.2313	.2423	.2335			
3	.1311	.2332	.2377	.2347			
4	.1311	.2324	.2385	.2328			.0678
5	.1311	.2347	.2428	.2306			.0671
6	.1303	.2294	.2443	.2328			
7	.128	.2161	.2393	.2244			.0678
8	.1296	.2153	.24	.1288			
9	.1265	.2191	.2393	.128			.0747
10	.1265	.1943	.2339	.1685			.0762
11	.226	.2339	.1097	.1566			.0762
12	.2259	.2362	.1691	.1559			.0747
13	.2244	.24	.1219	.1227			.0747
14	.2279	.2446	.2316	.1524			.0747
15	.2225	.2446	.269	.1555			.0747
16	.229	.2446	.269	.1296			.0747
17	.1265	.2431	.282	.016			.0686
18	.1235	.2461	.2568				.0686
19	.1235	.2438	.2221				.0686
20	.1303	.253	.1494				
21	.1311	.2438	.1501		.112		
22	.1318	.2484	.1463		.112		
23	.1303	.2347	.1303		.112		
24	.2122	.2302	.2423	.1017		.1143	.0671
Max	.229	.253	.282	.2347	.112	.1143	.0762
Min	.1235	.1943	.1097	.016	.112	.112	.0671
Avg	.1567	.2341	.2146	.1686	.112	.1132	.0715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 207 / Nrusinghwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5261		1.4243		.0381	
2		1.4723		1.4922			
3		1.4403	1.0608	1.5089			
4		1.3565	1.0277	1.4243			
5		1.387	1.0277	1.406			
6		1.3375		1.5432			
7		1.1576	1.326				
8			.0381				
9			.0381				
10		.0381	.0381	.0122			
11		.0381					.8619
12		.0381	.0114	.016			.9054
13		.0381	.0122	.016			.7042
14		.0381	.0122	.0122			.7712
15		.0381	.0122	.0114			.8288
16		.0381					.8288
17			.0145				
18		.0381	.0145				
19		.0381		.016			
20		.0381		.0171			
21		.0381			.0381		
22	1.406	1.7295			.0381		
23	1.5947	1.5912			.0381		
24	.4111	1.5432		1.3375		.0381	
Max	1.5947	1.7295	1.326	1.5432	.0381	.0381	.9054
Min	.4111	.0381	.0114	.0114	.0381	.0381	.7042
Avg	1.1373	.7124	.3564	.7312	.0381	.0381	.8167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 208 / RAJGOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0076	.1158	.0381		.9945	.6036	
2	.0099	.1166	.0381		.9945		
3		.1174	.0381		.9945		
4		.1174	.0381		.9724		
5	.0008	.1158	.0381		.9724		
6	.0175	.1151	.0427		.0343		
7		.1105	.0419	.0114	.0339		
8	.3018	.4595	.2416				
9	1.8961	3.986	4.1145	.1372			.0381
10	2.0843	3.932	4.1655	.1463			.0381
11	3.9167	4.2531	2.1315	.2214			.0381
12	4.1057	3.6831		3.3482			.0381
13	4.0413	.7758		3.935			.0381
14	3.8965		3.7235	4.0832			.0381
15	3.815		3.93	4.2471			.0381
16	3.6038	3.9419	.7354	2.146			.0381
17		3.9449	3.8287				
18		3.7212	3.8402				
19		.048	.0244	.0259			
20		.0602		.0305			
21		.0564	.0091	.2584	.0381		
22	.1158	.0754	.0084	2.1582	.0381		
23	.1158	.0655		2.1464	.0381		
24	.1646	.0236	.0381	1.0905	.9835	.0381	
Max	4.1057	4.2531	4.1655	4.2471	.9945	.6036	.0381
Min	.0008	.0236	.0084	.0114	.0339	.0381	.0381
Avg	1.7558	1.3561	1.3533	1.5990	.5540	.3209	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV Shinoli Ex.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.1063	.0343	.1132	.1063	.1147
2		.0377	.1052	.0328	.0377	.0343	.0655
3		.0377	.0343	.0328	.0377	.0343	.0328
4		.0377	.0343	.0343	.0377	.0343	.0328
5		.0377	.0343	.0343	.0377	.0171	.0328
6		.0377	.0343	.0343	.0377	.0171	.017
7		.0377	.0343	.0343	.0377	.0171	.0164
8		.1132	.1417	.12	.1509	.1417	.1147
9		.1509	.1372	.1372	.1509	.1417	.1357
10		.1509	.1372	.1372	.1509	.1417	.1311
11		.1433	.1372	.1698	.1417	.1372	.1509
12		.1433	.12	.1509	.1417	.12	.1132
13		.1417	.0343	.0377	.1417	.12	.1132
14		.1433		.1132	.1402	.12	.1132
15		.0343		.1132	.0343	.0343	
16		.0343	.12	.1132	.1063		.0377
17		.0343	.1372	.0377	.0171		.0377
18		.0343	.0343	.0377	.0171		.0377
19		.0343	.0343	.0377	.0171	.12	.0377
20	.0377	.104	.0343	.1509	.0171	.12	.0377
21	.1509	.1417	.1372	.1509	.1417	.1311	
22	.1509	.1612	.1372	.1509	.1417	.1311	
23	.1509	.1612	.1372	.1509	.1433	.1311	.1509
24	.4287	.1132	.1612	.12	.1132	.1417	.12
Max	.4287	.1612	.1612	.1698	.1509	.1417	.1509
Min	.0377	.0343	.0343	.0328	.0171	.0171	.0164
Avg	.1838	.0908	.0920	.0903	.0878	.0949	.0783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV Gaulwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.046	.945		.9774	.0305	.0335	.0328
2	1.0288	.9145		.9602	.0305	.0335	.0328
3	.0343	.884	1.1736	.9259	.0305	.0503	.0339
4	.0343	.8535	1.0898	.8916	.0305	.0503	.0339
5	.0343	.9145	1.0395	.9259	.0305	.0503	.0343
6	.0343	.9755		.9259	.0305	.0335	.0324
7	.0343	.945	1.073	.9774	.0305	.0335	.0328
8	.0343	.0305	.0335	.0343	.0305	.0335	.0328
9		.0305	.0343	.0343	1.4022	1.4922	.583
10	.0343	.0305		.0343	1.5242	1.8107	.6344
11	.0343			.0305	1.8652	1.5947	.8535
12	.0305	.0335		.0305	1.8107	.7202	.8535
13	.0305	.0335		.0305	1.6766	1.5432	.8535
14	.0305	.0339		.0305	1.6766	1.6118	.823
15	.0305	.0339		.0305	1.5089	1.6289	.7926
16	.0305	.0335	.0343	.0305	.503		.7926
17	.0305	.0335	.0343		.0335		.0305
18		.0335	.0343	.0305	.0335		.0305
19		.0509	.0343	.0305	.0503	.0305	.0305
20	.0305	.0671	.0343	.0305	.0503	.0305	.0305
21	.0305	.0509	.0343	.0305	.0503	.0328	
22	1.2193	1.4413	1.3032	.0305	.0503	.0328	
23	1.1584	1.3226	1.1317	.0305	.0335	.0343	.0305
24	1.1317	.945		1.0117	.0305	.0335	.0343
Max	1.2193	1.4413	1.3032	1.0117	1.8652	1.8107	.8535
Min	.0305	.0305	.0335	.0305	.0305	.0305	.0305
Avg	.2906	.4625	.5060	.3506	.5227	.5197	.3018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 204 / 11 KV Shivanage Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.4973
Max	.4973
Min	.4973
Avg	.4973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 205 / 11 KV BELEBHAT Mix

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2427			.2401	.2481	.2572
2		.1981			.2229	.2481	.2294
3	.2572	.2254		.2915	.2058	.2103	.2374
4	.2229	.2427		.2743	.2229	.2126	.2572
5	.2743	.2743		.3258	.2401	.2658	.3086
6	.3086	.3086	.3898	.463	.3429	.3366	.3605
7	.4115	.4161	.5493	.6001	.5144	.4961	.5079
8	.463	.5144	.5493	.583	.5144	.5316	.4915
9		.4508	.5144	.5144	.5487		.4287
10	.4115	.5201	.3429	.463	.5144		.6344
11	.3944	.4298			.3772		.3086
12	.3467						.2774
13	.3121						.2427
14	.2774	.394				.4973	.208
15	.2427				.4252	.4801	.2774
16	.3121						.2743
17	.3814	.3582	.5144	.4854	.443		.3814
18		.4607	.6687	.5548	.5847	.4801	.4161
19		.5609	.703	.6588	.6379	.6687	.4854
20	.7282	.5316	.823	.6241	.5493	.6687	.6935
21	.6588	.6089	.6687	.583	.5316	.6344	.583
22	.5201	.567	.6001	.4508	.5258	.4973	
23	.3467	.3898	.3429	.3467	.3544	.3601	.4161
24	.2229	.2774	.3012	.3258	.2774	.2658	.2572
Max	.7282	.6089	.823	.6588	.6379	.6687	.6935
Min	.2229	.1981	.3012	.2743	.2058	.2103	.208
Avg	.3733	.3986	.5360	.4715	.4137	.4177	.3710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Gaulwadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2254		.2058	.1734	.2303	.1966
2	.1715	.208		.1829	.156	.2126	.1802
3	.1715	.1734		.1886	.156	.2126	.1638
4	.1886	.1734		.1715	.1734	.2126	.1865
5	.2058	.208		.2401	.208	.2303	.2294
6		.2774	.2481	.2572	.2401	.2835	.2622
7	.2743	.2254	.3012	.3086	.2743	.3366	.2785
8	.2743	.2401	.2865	.2915	.3086	.3012	.2785
9		.2947	.3086	.2915	.3086	.2286	.3601
10		.3467		.3601	.3086	.2286	.3601
11	.2915				.3544	.2134	.3121
12	.1907						.2947
13	.208					.1829	.2601
14	.208	.2715				.2915	.2601
15	.1907				.2126	.3086	.2774
16	.2254		.463				.2774
17	.2427	.2835	.4287	.2947	.3189		.2774
18		.3189	.3772	.3121	.3012		.2601
19		.3898	.3944	.3467	.3544	.4096	.3121
20	.5201	.443	.463	.3429	.3544	.463	.3814
21	.3814	.394	.3944	.3258	.298	.3605	
22	.3121	.3189	.3601	.2947	.2629	.2785	
23	***	.2303	.2915	.2427	.2481	.2294	.2774
24	.2058	.2427	.2303	.2572	.208	.2126	.2229
Max	10.4424	.443	.463	.3601	.3544	.463	.3814
Min	.1715	.1734	.2303	.1715	.156	.1829	.1638
Avg	.7830	.2771	.3498	.2730	.2610	.2713	.2686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 207 / 11 KV Turkewadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1605	2.1338		2.5549	.061	.0838	.0819
2	2.1434	1.8595		2.572	.061	.0671	.0655
3	2.572	1.3565	2.3569	2.5892	.061	.0671	.0678
4	2.5377	1.4327	2.3137	2.6063	.061	.0671	.0625
5	2.5549	1.4632	2.2634	2.6235	.061	.0838	.0686
6	2.7092	1.5242		2.692	.061	.0838	.0819
7	2.5377	1.4632	2.4926	2.5206	.0762	.0838	.0819
8	.0857	.0762	.0848	.0857	.0914	.0838	
9		.0762	.0857	.0857	3.1703		
10	.1029	.0762	.0857	.0857	3.1703		2.2462
11	.0857	.0838	.0857	.0762	3.3532	.7373	2.2558
12	.0762	.0848	.1029	.0762	3.3532	.6173	2.5149
13	.061	.0503	.1029	.0762		.7545	2.4082
14	.061	.0503		.0762	3.3196	.7545	2.332
15	.061	.0678		.0762	2.8837	2.8464	2.652
16	.0762		.1029				2.6673
17	.061	.0838	.0857	.061			.0457
18		.1006	.0857	.061	.1006		.0762
19		.0848	.1029	.0762	.0838		.061
20	.0762	.1006	.0857	.0762	.0838	.1067	.061
21	.0762	.0848	.0857	.0762		.0857	
22	2.1948	2.9835	2.6406	.0762	.0838	.1029	
23	2.4539	3.0352	2.8978	.061	.0838	.0819	.061
24	.1029	2.2558		2.7092	.061	.0838	.0857
Max	2.7092	3.0352	2.8978	2.7092	3.3532	2.8464	2.6673
Min	.061	.0503	.0848	.061	.061	.0671	.0457
Avg	1.0852	.8925	.8923	.9562	1.0140	.3773	.8989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 208 / 11 KV Shivanage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0152		.0343	.7621	.7545	.2785
2	.0171	.0152		.0343	.7621	.7545	.2949
3	.0171	.0152		.0328	.7468	.7545	.2785
4	.0171	.0152		.0343	.7468	.7545	.2883
5	.0171	.0152		.0343	.7468	.763	.2949
6	.0171	.0152	.0171	.0343	.0152	.9156	.3052
7	.0171	.0173	.0168	.0343	.0152	.8886	.3277
8	.0171	.0152	.0168	.0343	.0152	.9389	.3113
9		1.5546	1.7833	.0343	.0152	.0152	.0171
10	1.6461	1.4632	1.749	.0343	.0152	.0152	.0339
11	1.5261		1.869		.0335	.0305	.0152
12	1.3717		1.8861			.0305	.0152
13	1.3717		1.869			.0305	.0152
14	1.3717					.0343	.0152
15	.2743				.0168	.0343	.0152
16	.7621		.0343				.0152
17	.0152	1.576	1.4232	1.1126	.0168		.0152
18		1.5261	1.5604	1.0212	.0168		.0152
19		.0168	.0343	.0152	.0171	.0305	.0152
20	.0152	.0335	.0343	.0152	.0168	.0305	.0152
21	.0152	.0168	.0343	.0152	.0168	.0328	
22	.0152	.0168	.0343	.8383	.0168	.0328	
23	.0152	.0168	.0343	.7926	.017	.0328	.0152
24	.0171	.0152	.0168	.0343	.7468	.0168	.0339
Max	1.6461	1.576	1.8861	1.1126	.7621	.9389	.3277
Min	.0152	.0152	.0168	.0152	.0152	.0152	.0152
Avg	.4073	.3533	.7302	.2326	.2378	.3281	.1196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 209 / 11 KV BELEBHAT Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.9259
Max	.9259
Min	.9259
Avg	.9259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 201 / 11 KV Adkur Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0381	.0373	.0377	.0373	.0187	.0373
2	.0377	.0381	.0373	.0381	.0373	.0187	.0377
3	.0377	.0377	.0187	.0381	.0366	.0191	.0377
4	.037	.0377	.0189	.0377	.0366	.0187	.0381
5	.037	.0373	.0373	.0377	.0362	.0189	.0381
6	.0366	.0549	.0377	.0373	.0373	.0377	.0377
7	.0549	.0701			.0549	.0732	.0716
8	.0543	.0543	.0914	.0693	.0732	.1097	.0716
9	.0366	.0566	.0747	.0554	.0373	.0709	.037
10	.0549	.0377		.0549	.0373	.0732	.037
11	.0366	.0566	.0377		.0351	.0732	.037
12	.0362	.0566	.037			.0377	.0187
13					.0347		.0183
14	.0366						.0377
15	.0362						.0187
16	.0358	.0554	.0509		.0354	.0543	.0185
17	.0358	.0554	.0701		.0671	.0373	.0358
18	.0532	.0701	.0857		.112	.0366	.0351
19	.0914	.1109	.0934		.1097	.0914	.0554
20	.112		.112	.0914		.1109	.0943
21	.0943	.0934	.0943	.0732		.0754	.0943
22	.0754	.0943	.0762	.0732		.0732	.0754
23	.0572		.0572	.0549	.056	.0566	.0566
24	.0377	.0377	.056	.0566	.0373	.0373	.0377
Max	.112	.1109	.112	.0914	.112	.1109	.0943
Min	.0358	.0373	.0187	.0373	.0347	.0187	.0183
Avg	.0506	.0575	.0591	.0540	.0506	.0544	.0449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 202 / 11 KV Kurtanwadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1915	.2305	.2351	.2489	.1684	.2711	.1699
2	.1668	.2033	.2252	.2297	.1578	.265	.163
3	.1661	.1883	.1821	.205	.1525	.2267	.1616
4	.1581	.1864	.1921	.2195	.1528	.2225	.1612
5	.1554	.1888	.2453	.2248	.1566	.2237	.1661
6	.2226	.2545	.2701	.2736	.2126	.2893	.2067
7	.3014	.3343	.3284	.3355	.2427	.3536	.2443
8	.2987	.3618	.3677	.3612	.2462	.4244	.2926
9	.2412	.389	.3799	.3607	.2416	.5545	.32
10	.3026	.4528	.192	.343	.1924	.4611	.3093
11	.3437	.4416	.4123	.3593	.1014	.3963	.3582
12	.2755	.4068	.4405	.3639		.3269	.317
13	.2189	.4365	.4694	.2758		.3117	.2974
14	.3117	.3875	.4607	.2877	.1374	.29	.3107
15	.33	.3724	.4173	.426	.2014	.3205	.2787
16	.3166	.5022	.4513	.3589	.217	.4018	.2953
17	.3894	.4946	.487		.2882	.2932	.2739
18	.4462	.5441	.4734		.5067	.3513	.362
19	.458	.6306	.5716	.2366	.5945	.4287	.4873
20	.6352	.6238	.6621	.419	.6199	.535	.5464
21	.6233	.6261	.5685	.3932	.5785	.4855	.5088
22	.5483	.514	.5074	.3345	.4946	.3782	.4538
23	.3973	.39	.4153	.2575	.4104	.2805	.4069
24	.2479	.2713	.3115	.241	.2492	.2713	.2771
Max	.6352	.6306	.6621	.426	.6199	.5545	.5464
Min	.1554	.1864	.1821	.205	.1014	.2225	.1612
Avg	.3228	.3930	.3861	.3071	.2874	.3485	.3070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 203 / 11 KV Here Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0452	.0394	.061	.061	.0434	.0678	.0457
2	.0457	.0394	.061	.0617	.0372	.0678	.0457
3	.0463	.0267		.0617	.0248	.061	.0457
4	.0469	.0267		.061	.0248	.061	.04
5	.0457	.04		.061	.0248	.061	.0533
6	.0377	.0734		.0617	.0533	.0753	.0762
7	.0972	.1372	.1357	.0743	.08	.0937	.0914
8	.1341	.1423	.112	.1696	.1094	.1094	.0914
9	.1696	.1235	.0995		.0914	.0937	.061
10	.1067	.0926		.1174	.061	.0937	.0914
11	.0949	.0892	.0781		.0587		.064
12	.0926	.0781	.0972				.0648
13	.0838	.0781	.112				.0655
14	.08	.104	.1326		.0949	.0762	.0663
15	.0838	.1187	.0671		.116	.0762	.0791
16	.1029	.1107	.1433		.1311	.061	.064
17	.1357	.1107	.1341		.1006	.0293	.0857
18	.1696	.112	.1526		.1052	.08	.0819
19	.1829	.1448	.1269	.0947	.1052	.1027	.1128
20	.153	.1448	.1334	.1067		.1006	.1149
21	.1334	.1174	.12	.0934		.0743	.096
22	.088	.0686	.0991	.08		.0834	.08
23	.0503		.0638	.0495	.0753	.0762	.0667
24	.044	.0495	.0594	.0572	.04	.061	.061
Max	.1829	.1448	.1526	.1696	.1311	.1094	.1149
Min	.0377	.0267	.0594	.0495	.0248	.0293	.04
Avg	.0946	.0899	.1047	.0807	.0725	.0764	.0727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 204 / 11 KV Hambire Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2206	.2057	.2206	.221	1.0341	.5007	.413
2	.2156	.2049	.2176	.2145	.9991	.7985	.7491
3	.2088	.1962	.2153	.2168	1.0014	.7975	.7476
4	.2077	.1654	.2145	.2168	.9968	.8341	.775
5	.2054	.1669	.2236	.2156	.996	.7137	.8116
6	.186	.1978	.2244	.2164	.6054	1.009	.8093
7	.2035	.1973	.2015	.2134	.1055	1.1347	.8802
8	.2248	.2206	.2016	.2198	.097	1.1217	.8581
9	2.9127	2.4573	2.4364	.2096	.0223	.6234	.4686
10	3.4735	3.5333	1.6949	.2084	.0164	.3467	.2503
11	3.6757	3.5665	2.2127	.1135	.0661	.1471	.0111
12	3.7984	3.642	1.5832	1.06	.0745	.0564	.0128
13	3.7152	1.8061	3.118	2.4013	.0334	.0328	.0124
14	3.6062		3.1592	1.3131	.0448	.1196	.0118
15	2.4668		2.7496	3.099	.0276	.157	
16	2.8829	1.656	1.3435	1.6126	.0466	.1017	.0625
17	1.3773	2.9797	1.1957		.0707	.1022	.1395
18	.2334	3.0564	1.5806		.0579	.0365	.1615
19	.2362	1.7147	.9191	.017	.0594	.1006	.1642
20	.2126	.2338	.2309	.2488	.0907	.1898	.1802
21	.242	.243	.1303	.1814	.1052	.2141	.185
22	.226	.266	.1288	.9404	.1044	.2152	.1867
23	.2229	.1395	.1303	1.089	.1806	.1813	.1662
24	.2138	.2252	.2347	.6592	.5769	.1806	.1684
Max	3.7984	3.642	3.1592	3.099	1.0341	1.1347	.8802
Min	.186	.1395	.1288	.017	.0164	.0328	.0111
Avg	1.2987	1.2307	1.0236	.6767	.3089	.4048	.3576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 205 / 11 KV Kuratnwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5967	.8383		.9339	.017	.0187	.0088
2	.5735	.8288		.9221	.017	.0187	.0086
3	.5571	.7956	.8139	.8951	.017	.0179	.0095
4	.5506	.7773	.8478	.8951	.017	.0179	.0095
5	.57	.852	.8478	.8848	.0168	.0179	.0095
6	.6613	.9175		.9614	.0168	.0173	.0095
7	.5693	.8745	.8848	1.0322	.0168	.0173	.0095
8	.0328	.0848	.104	.1478	.0168	.0175	.0095
9	.0857	.0678	.0655	.1494	.4111	.583	.5533
10	.0886	.0324		.1463	.5121	.5506	.57
11	.0876	.0648	.0332	.1463		.9496	.5365
12	.0876	.0655	.0671	.1463		.9496	.1524
13	.0332	.0316	.0876	.1174		1.0059	.426
14	.0316	.0328	.1063	.1494	.2778	.8951	.4807
15	.0312	.0335	.0693	.1494	.3391	.8951	.5304
16	.0709	.0686	.1086		.3361	.5243	.5571
17	.1075	.0686	.0876		.132	.0093	.0739
18	.168	.0633	.1063		.0189	.0093	.0347
19	.2263	.1433	.1478		.0179	.0088	.0362
20	.1494	.0671	.1075	.017	.0381	.0088	.0362
21	.128	.0671	.0867	.0168	.0358	.0095	.0754
22	.9221	1.1065	1.1401	.0164	.0183	.0095	.0373
23	.9054	1.153	1.17	.0168	.0179	.0095	.0373
24	.6464	.8619		1.0277	.017	.0183	.0095
Max	.9221	1.153	1.17	1.0322	.5121	1.0059	.57
Min	.0312	.0316	.0332	.0164	.0168	.0088	.0086
Avg	.3284	.4124	.3622	.4386	.1099	.2741	.1759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 206 / 11 KV Adkur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.1577	.0175	.0354	1.2279	.5757	.0838
2	.0351	.0362	.0191	.0354	1.1431	1.02	.6889
3	.0351	.0362	.0175	.0351	1.1004	1.028	.7194
4	.0351	.0358	.017	.0354	1.0867	1.0547	.6698
5	.0351	.0724	.0732	.0351	1.1233	1.115	.7324
6	.0823	.0716	.0732	.0801	.6999	1.4826	.8292
7	.1699	.1139	.1425	.1924	.1509	1.6697	1.1454
8	.1838	.1806	.144	.2488	.1577	1.5028	1.0525
9	3.5467	3.9036	3.2228	.2707	.1692	.8449	.5668
10	3.9743	4.0505	2.0652	.1973	.1288	.1638	.016
11	3.9026	3.9186	3.158	.0655	.1281	.1677	.0229
12	3.6992	3.7472	3.6342	1.8153	.0983	.1242	.0181
13	1.9098	1.6918	3.5551	3.0766	.048	.1174	.0183
14	.9077		3.7396	3.37	.0189	.2031	.0183
15	2.2123		3.2338	3.5444	.0177	.1898	.0187
16	2.6631	3.5079	1.2612	1.8435	.0177	.1951	.0319
17	.9175	3.7464	2.46		.0846	.1059	.1615
18	.1925	3.6107	2.7686		.0587	.0808	.2199
19	.192	.5571	.8142	.0701	.0179	.1601	.1501
20	.1753	.088	.0551	.0894	.0008	.1859	.1577
21	.1284	.0354	.1174	.0543	.0046	.1874	.1562
22	.0351	.1078	.1319	1.2795	.0008	.1671	.1653
23	.1356	.032	.0446	1.327	.0212	.1532	.1261
24	.1205	.0716	.0175	.721	.6089	.0557	.1128
Max	3.9743	4.0505	3.7396	3.5444	1.2279	1.6697	1.1454
Min	.0351	.032	.017	.0351	.0008	.0557	.016
Avg	1.0552	1.3533	1.2826	.8374	.3381	.5229	.3284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 208 / 11 KV Chandgad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4338	.056	.4527	.3734	.4481	.3475
2	.3921	.4108	.4481	.4481	.3658	.4481	.3696
3	.3921	.4108	.4854	.0377		.4481	.3696
4	.3921	.4108	.4481	.4338		.4481	.3658
5	.3921	.415	.4115	.4527		.4481	.3658
6	.4527	.4527	.4115	.4715	.4161	.4481	.4066
7	.4805	.4481	.5544	.4805	.1097	.4706	.4435
8	.4835	.4668	.5601	.499	.4435	.543	.4435
9	.6516	.4961	.7602	.5304	.499	.6268	.4887
10	.6154	.567		.5487	.499	.5914	.5316
11	.5792	.695	.6878	.5487		.5853	.5068
12	.6154	.6516	.7316	.5487		.631	.5121
13	.5611	.6154	.6584	.5544	.7442	.6733	.5138
14	.5373	.567	.6878	.5487	.5792	.5853	.5068
15	.543	.6415	.6154	.5601	.5552	.5853	.5487
16	.5544	.567	.631		.543	.6447	.5249
17	.5729	.5487	.6335		.543	.4938	.5144
18	.543	.543	.5194		.6447	.4938	.5258
19	.7316	.7682	.7059	.7947	.7164	.6219	.6516
20	.7392		.7577	.7133		.7207	.7207
21	.7095		.7095	.6401		.5914	.6653
22	.6348	.679	.679	.543		.5487	.6099
23	.5658	.1509	.5847	.4887	.5544	.4938	.5415
24	.4481	.4715	.5975	.4904	.3898	.4435	.3696
Max	.7392	.7682	.7602	.7947	.7442	.7207	.7207
Min	.3921	.1509	.056	.0377	.1097	.4435	.3475
Avg	.5416	.5187	.5798	.5136	.4985	.5430	.4935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 201 / 11 KV VAIJANATH

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.1829	.1715	.6001	.1829	.4287
2	.3429	.3429	.1829	.1715	.6859	.1829	.4287
3	.2572	.2572	.2743	.1715	.7716	.1829	.4287
4	.2572	.2572	.2743	.1715	.8573	.1829	.5144
5	.2572	.3429	.2743	.1715	1.3717	.1829	.6859
6	.4287	.4287			1.7147	.1829	.8573
7	.9431	.8573			2.3148	.1829	1.5432
8	.8573	.7716	.3658	1.1145	2.3148	.3658	1.6289
9	.5144	.6001	1.0974		2.0576		1.5432
10	.4287	.5487			.9145		1.286
11	.3429	.4572			1.0974		1.0288
12	.3429						.9431
13	.2572						.9431
14	.0857	.0914			.1829		.9431
15	.1715	.4287	.6859		1.0974	.6001	.9431
16	.3429	.4572	.6859		1.4632		1.2003
17	.4287	.5487	.6859	.6001	1.829	.3429	
18	.6001	.7316	.6859	.6859	2.0119	1.3717	
19	.5144	.5487	.5144	1.1145	1.4632	1.6289	
20	.5144		.5144	1.3717	1.0974	1.0288	
21	.4287	.4572	.4287	1.286		.9431	
22	.4287		.3429	1.286		.8573	
23	.3429		.2572	1.1145	.0914	.6859	
24		.3429	.0914		.5144	.1829	.5144
Max	.9431	.8573	1.0974	1.3717	2.3148	1.6289	1.6289
Min	.0857	.0914	.0914	.1715	.0914	.1829	.4287
Avg	.4100	.4638	.4438	.7254	1.2226	.5463	.9330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 202 / 11 KV HITECH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.5144	.6001	.6859	.6001	.6859	.6859
2	.7716	.4287	.5144	.7716	.6859	.6859	.5144
3	.6859	.4287	.5144	.6859	.6001	.6001	.5144
4	.6001	.4287	.5144	.6859	.5144	.6001	.5144
5	.5144	.4287	.5144	.6859	.5144	.5144	.5144
6	.5144	.4287	.5144	.6001	.6001	.5144	.5144
7	.5144	.5144	.5144	.5144	.6001	.6001	.6001
8	.3429	.5144	.6001	.5144	.6859	.6001	.6001
9	.4287	.5144	.6859	.6859	.6001	.5144	.5144
10	.4287	.6859	1.286	.6859	.6859	.6859	1.0288
11	.4287	.7716	1.0288	1.1145	.8573	1.0288	1.0288
12	.4287	.8573	1.0288	1.0288	1.1145		.9431
13	.4287	.7716	1.3717	.7716	1.2003	.6001	1.2003
14	.4287	.6859	1.3717	1.0288	1.3717	.8573	1.2003
15	.4287	.6859	1.4575	1.2003	1.3717	1.0288	1.1145
16	.4287	.6859	1.0288	1.1145	1.3717		1.0288
17	.4287	.6859	1.0288	1.0288	1.0288	.5144	1.0288
18	.5144	.7716	1.0288	.5144	.5144	.5144	.6859
19	.5144	.6859	.6859	.6859	.6859	.5144	.6001
20	.5144	.6859	.7716	.5144	.6859	.6001	.7716
21	.5144	.6859	.7716	.6001	.5144	.6001	.8573
22	.5144	.6401	.6859	.6001	.5144	.5144	.6859
23	.5144	.6001	.6859	.6859	.6001	.5144	.7716
24	.9431	.5144	.6001	.6859	.6859	.6859	.6859
Max	.9431	.8573	1.4575	1.2003	1.3717	1.0288	1.2003
Min	.3429	.4287	.5144	.5144	.5144	.5144	.5144
Avg	.5287	.6090	.8252	.7537	.7752	.6352	.7752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 203 / 11 KV Angolkar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3429	.2572	.2572	.2572	.2572	.2572
2	.2572	.3429	.2572	.2572	.2572	.2572	.2572
3	.2572	.3429	.2572	.2572	.2572	.2572	.2572
4	.2572	.3429	.2572	.2572	.2572	.2572	.2572
5	.2572	.3429	.2572	.2572	.2572	.2572	
6	.2572	.3429	.2572	.2572	.2572	.2572	.2572
7	.2572	.3429	.2572	.2572	.2572	.2572	.2572
8	.2572	.3429	.2572	.2572	.2572	.2572	.2572
9	.2572	.2572	.2572	.2572	.2572	.2572	.2572
10	.2572	.4287	.3429	.3429	.3429	.3429	.2572
11	.2572	.3429	.4287	.3429	.3429	.3429	.2572
12	.2572	.3429	.3429	.4287	.4287		.3429
13	.2572	.3429	.3429	.4287	.4287	.3429	.2572
14	.2058	.3429	.3429	.3429	.4287	.5144	.2572
15	.2572	.3429	.4287	.2572	.4287	.6859	.3429
16	.2572	.4287	.3429	.2572	.3429		.6001
17	.2572	.3429	.3429	.3429	.3429	.3429	.3429
18	.2572	.2572	.5144	.3429	.3429	.3429	.3429
19	.2572	.2572	.2572	.2572	.3429	.3429	.2572
20	.2572	.2572	.2572	.2572	.2572	.2572	.2572
21	.2572	.2572	.2572	.2572	.2572	.2572	.2572
22	.3429	.2572	.2572	.2572	.2572	.2572	.2572
23	.3429	.2572	.2572	.2572	.2572	.2572	.2572
24	.2572	.3429	.2572	.2572	.2572	.2572	.2572
Max	.3429	.4287	.5144	.4287	.4287	.6859	.6001
Min	.2058	.2572	.2572	.2572	.2572	.2572	.2572
Avg	.2622	.3251	.3036	.2893	.3072	.3118	.2870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 204 / 11 KV Aqua

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.724	.6859	.8573	.724	.6859
2	.6859	.0857	.6335	.6859	.9431	.724	.6001
3	.6001	.6001	.6335	.6859	.6859	.6335	.6001
4	.6001	.5144	.543	.6859	.7716	.6335	.6859
5	.5144	.5144	.543	.6001	.8573	.543	.6859
6	.5144	.5144	.543	.6001	.9431	.543	.7716
7	.5144	.5144	.543	.6001	.6859	.543	.6859
8	.5144		.543	.6859	.6001	.724	.6859
9	.2572		.905	.6859	.8573	1.086	
10	.2572	.8145	.6859	.8573	.0905	1.0288	
11	.4287	.724	.6859	.6001	.543	.8573	
12	.1715	.724	.6859	.6859	.8145		
13	.0857	.724	.6859	.7716	.905	.6859	
14	.0857	.6335	.6859	.7716	.905	1.0288	
15	.0857	.905	.6859	.9431	.905	.9431	
16	.0857	.905	.6859	.8573	.905		
17		.8145	.6859	.9431	.905	.8573	
18	.0857	.724	.6859	.7716	.724	.6859	
19	.5144	.724	.7716	.8573	.8145	.9431	
20	.5144	.724	.6859	.7716	.905	.8573	
21	.5144	.724	.6859	.6859	.905	.8573	
22	.5144	.724		.6859	.905	.7716	
23	.6859	.724	.6859	.6859	.724	.6859	
24	.6859	.6859	.0905	.7716	.9431	.724	.6859
Max	.6859	.905	.905	.9431	.9431	1.086	.7716
Min	.0857	.0857	.0905	.6001	.0905	.543	.6001
Avg	.4175	.6684	.6393	.7323	.7956	.7764	.6764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 201 / 11 KV AMROLI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1494	.1753	.1494	.156	.1267	.188
2	.1402	.112	.1791	.112	.1402	.1267	.1879
3	.1448	.112	.1791	.112	.1387	.128	
4	.1433	.1494	.181	.1494	.1387	.1463	.1503
5	.1629	.1867	.181	.1867	.1715	.1448	.1503
6	.2328	.1879	.2507	.2241	.2103	.1753	.1879
7	.2804	.2247	.2534	.2241	.2427	.2561	.1879
8	.2534	.3003	.2686	.2614	.2774	.2629	.3006
9	.218	.3009	.2279	.2818	.2254	.2715	.2241
10	.2865	.2012	.2534	.2987	.2279	.2427	.2254
11	.2071	.2103	.2241	.2427	.2229	.2241	.1867
12	.2241	.213	.2254	.1928			.1879
13	.1867		.1879	.208			
14	.1867	.1791		.1715			
15	.1867	.1753		.1715	.208	.2241	
16	.1867	.2149	.1879			.1867	
17	.1867	.1791	.1867			.2241	
18		.2804	.2254		.3429	.2241	
19		.3506	.4854		.4334	.3006	
20	.5544	.5194	.5228	.3944	.4382	.5601	
21	.4508	.4477	.4481	.3429	.3467	.4508	
22	.3734	.3982	.3757	.2572	.2774	.3757	.3361
23	.3006	.2507	.2254	.1734	.1578	.2638	.2614
24	.1612	.1867	.2172	.1867	.1543	.1612	.1867
Max	.5544	.5194	.5228	.3944	.4382	.5601	.3361
Min	.1402	.112	.1753	.112	.1387	.1267	.1503
Avg	.2369	.2404	.2573	.2170	.2374	.2417	.2115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 202 / 11 KV BONJURDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8845	3.5909	.4626	3.2975	.1031	.0778	.0678
2	2.8311	2.9789		3.1718	.1037	.0755	.0624
3	2.8014	2.934	1.4022	3.0673	.1031	.0747	.0419
4	2.7747	3.0269	2.8662	2.9641	.1037	.0747	.08
5	2.7046	2.9271	2.8129	2.8517	.1197	.0751	.0852
6	2.7382	2.8929	1.48	2.8905	.1204	.0751	.0792
7	2.8753	2.9614	1.4159	2.8326	.1211	.0781	.0799
8	1.5973	1.7175	1.4495	1.1925	.1059	.0785	.0899
9	.1718	.2224	.147	.1546	1.3329	.9763	.6748
10	.1813	.2162	.1726	.1881	2.9329	1.9764	1.3702
11	.1996	.1844	.1987	.1761	3.1697	2.1419	1.4083
12	.2011	.1319	.2048	.2153	3.3574	2.1518	1.5021
13	.2027	.1193	.1721	.201	3.1905	2.0728	1.4034
14	.1882	.1122	.0724	.2264	3.0207	1.9128	1.3691
15	.1714	.1221	.0854	.1985	3.3677	1.1515	1.3725
16	.1683	.1684	.057	.1273	1.7985	1.9633	1.3824
17	.1667	.144	.1439	.1852	.6958	.5913	.8579
18	.1311	.1768	.1789	.1547	.1143	.0814	.7253
19	.141	.2145	.1705	.1349	.1477	.085	.1089
20	.1759	.2136	.2231	.1288	.1265	.1188	.1188
21	.1972	.2267	.166	.1107	.1101	.1355	.1256
22	2.4509	2.5975	2.4417	.1114	.1061	.1348	.048
23	3.5407	3.435	3.3928	.1067	.1021	.1149	.0875
24	3.2217	3.4843	1.8496	1.5943	.0831	.0907	.1067
Max	3.5407	3.5909	3.3928	3.2975	3.3677	2.1518	1.5021
Min	.1311	.1122	.057	.1067	.0831	.0747	.0419
Avg	1.3632	1.4500	.9376	1.0951	1.0224	.6795	.5520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 204 / Adkur Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.112	.1402	.1126	.1214	.0724	.112
2	.1086	.0751	.1433	.0751	.1227	.0724	.0747
3	.0876	.0751	.1254	.0751	.1227	.0724	
4	.1052	.112	.1267	.1127	.1402	.0905	.1494
5	.1227	.1879	.1254	.1879	.1753	.1267	.1494
6	.1791	.1879	.1991	.1879	.1907	.181	.1867
7	.2149	.2254	.2353	.2254	.208	.2012	.1867
8	.2328	.2254	.2195	.2254	.1753	.2033	.1494
9	.2103	.1879	.2126	.2241	.1753	.2012	.1867
10	.181	.1658	.2149	.1867	.1734	.1879	.1867
11	.1494	.1753	.1503	.1734	.1753	.1867	.1867
12	.1879	.1658	.1879	.1578	.1715		.1879
13	.1879	.1677	.1879	.1387	.1907	.1879	
14	.1879	.181		.1402	.1372	.2254	
15	.1867	.1791		.1387	.1578	.2254	
16	.1867	.181	.1867			.1879	
17	.1867	.1928	.1867	.1578	.1578	.1867	
18	.1867	.16	.1867	.208	.208	.2261	
19		.2507	.263	.208	.2601	.263	
20	.3361	.3258	.3006	.2254	.2058	.3381	
21	.2987	.2507	.2987	.2254	.1734	.2254	
22	.2241	.1829	.2254	.1715	.1578	.1879	.2614
23	.1867	.1646	.1879	.1402	.12	.184	.2614
24	.1214	.1504	.1463	.1503	.1387	.1097	.1494
Max	.3361	.3258	.3006	.2254	.2601	.3381	.2614
Min	.0876	.0751	.1254	.0751	.12	.0724	.0747
Avg	.1816	.1784	.1932	.1673	.1678	.1801	.1735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 205 / Satavane Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2401	.7421	.3277
2					.2035	.8589	.3391
3					.2058	.8326	
4					.208	.8059	.4096
5					.1907	.8413	.4096
6						.8954	.4588
7						.8939	.4915
8						.7865	.4915
9	2.2466	2.2672	2.2131				
10	2.4013	2.0805	2.0222				
11	2.2672	2.0454	1.9433				
12	2.13	2.079	2.0481	1.7976			
13	1.9662		1.9662	1.8564			
14	1.9662			2.1879			
15	1.8023			2.0885			
16	1.8023	2.226					
17		1.8442	1.6385				
18		1.6095	1.7204				
22				.2572			.2614
23				.2401			.2614
24					.2401		
Max	2.4013	2.2672	2.2131	2.1879	.2401	.8954	.4915
Min	1.8023	1.6095	1.6385	.2401	.1907	.7421	.2614
Avg	2.0728	2.0217	1.9360	1.4046	.2147	.8321	.3834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 201 / 11 KV Kurani Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2056	.201	.2014	.2199	.1286	.1469	.1829
2	.1867	.1827	.2014	.2016	.1102	.1469	.1829
3	.1869	.1833	.1831	.1833	.1102	.1469	.1829
4	.1867	.1833	.1831	.1833	.1102	.1469	.1829
5	.1865	.1833	.1648	.1835	.1102	.1469	.1829
6	.2245	.2569	.2563	.2385	.1655		.2561
7	.2987	.2752	.2929	.3302	.1837	.2385	.2561
8	.2789	.2936	.3479	.3669	.202	.2569	.3292
9	.3272	.3666	.2932	.2743	.1469	.2569	.2926
10	.3873			.2385	.2571	.2534	.2561
11	.2571	.2905	.2378	.2385	.2755		.1829
12	.3309	.2905	.3662	.2569	.3122	.2534	.1646
13	.1646	.2179	.3296	.2202	.2755	.2743	.1829
14	.2926	.1997	.2566	.2018	.2755	.2743	.1829
15	.146	.1997		.2018	.2571	.2926	.1646
16	.31	.1997	.0915		.1286	.2012	.1991
17	.3624	.2197	.1465		.1469	.1829	
18	.2899	.3113	.3654		.202	.2561	.3109
19	.3251	.4572	.475	.2195	.3666	.4024	.3841
20	.5798	.5487	.5127	.2926	.4032	.5487	.4938
21	.4887	.4938	.4938	.2926	.4765		
22	.3982	.4024	.3802	.2388	.2383	.2926	.362
23	.2899	.2926	.3296	.202	.1835	.2534	.2715
24	.2181	.2172	.2197	.238	.1469	.1835	.2195
Max	.5798	.5487	.5127	.3669	.4765	.5487	.4938
Min	.146	.1827	.0915	.1833	.1102	.1469	.1646
Avg	.2884	.2812	.2877	.2392	.2172	.2455	.2465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 202 / Bijur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0864	.0864	.0864	.0691		
2	.0864	.0864	.0864	.0691		
3	.0864	.0864	.0864	.0691		
4	.0864	.0864	.0864	.0691		
5	.0864	.0864	.0864	.0864		
6	.0864	.0864	.121	.0864		
7	.0691	.0864	.0864	.0691		
8	.0691	.0864	.0691	.0691		
9	2.1773	2.4192	1.6416	.0691		
10	2.16			.0691		
11	2.1427	2.2119	1.4688	.0691		
12	2.0909	2.1773	1.417	1.3479		
13	1.9527		1.296	1.4861		
14	1.7453		1.2615	1.6935		
15	.6221			1.6935		
16	1.6416	1.9354			.0686	
17	.0518	1.8663	.3802		.4801	
18	.0518	1.4688	.8122		.583	.0686
19	.0691	.0864	.1037		.0514	.0686
20	.1037	.0864	.0864		.0514	.0686
21	.0864	.0864	.1037			
22	.0864	.1037	.0864		.0171	.0686
23	.1037	.1037	.1037		.0171	.0686
24	.121	.1037	.1037	.0864		.0171
Max	2.1773	2.4192	1.6416	1.6935	.583	.0686
Min	.0518	.0864	.0691	.0691	.0171	.0171
Avg	.6610	.6670	.4559	.4439	.1812	.0600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 203 / Pundra AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4409	.5596		.373		.0339	
2	.407	.4748		.3456		.0339	.017
3	.407	.4748	.3561	.3456		.0339	.017
4	.407	.4748	.373	.3456		.0339	.017
5	.4239	.5087	.4239	.3391		.0339	.017
6	.4578	.5087		.373			.017
7	.4917	.5426	.3391	.017		.017	.017
8	.0339	.017	.017	.017		.017	.017
9	.0339	.017	.0339	.017	.2204	.373	.1357
10	.017			.017	.3561	.5765	.1187
11	.0339	.017	.0339	.017	.39	.5596	.1187
12	.017	.017	.0339	.017		.6274	.1187
13	.017	.017	.017	.017	.407	.5935	.1017
14	.0339	.017	.017	.017	.407	.5935	.1017
15	.017	.017		.017	.373	.5256	.1187
16	.0339	.017	.017		.2374	.373	.2374
17	.0339	.017	.017		.017	.017	
18	.017	.017	.017		.017	.017	.017
19	.017	.017	.017		.017	.017	.017
20	.017	.017	.017		.017	.017	.017
21	.017	.017	.017		.0339		
22	.6104	.5087	.39		.017	.017	.017
23	.6274	.5426	.407		.017	.017	.017
24	.4409	.5765		.407		.0339	.017
Max	.6274	.5765	.4239	.407	.407	.6274	.2374
Min	.017	.017	.017	.017	.017	.017	.017
Avg	.2106	.2345	.1413	.1676	.1805	.2073	.0606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 201 / RAVIKIRAN PAPERMILL EXP NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5497	1.7909	1.8995	.0187	.0185	.0187	.0187
2	1.4445	1.7212	2.0112	.0187	.0183	.0187	.0185
3	1.5915	1.9208	2.0359		.0373		
4	1.542	1.6431	1.8975		.0185		
5	1.544	1.9586	1.912		.0185		.0185
6	1.8015	1.5721	1.9422		.0183		
7	1.6514	1.906	1.4818				
8	1.9326	1.8654	1.8419	.0187			
9	1.8846	1.7368	1.8706	.101			
10	1.3779	1.787	1.829	.0373			.0373
11	1.3054	1.6895	1.4525	.0193	.0187	.056	.0373
12	1.9417	1.7596	1.9071	.0187	.0187	.0185	.037
13	1.6084	1.4361	1.4625	.0366	.0187		.0366
14	1.9755	1.8473	1.8347		.0187	.0373	.0185
15	.9419	1.5021	1.7833				.037
16		2.061	1.797	.0185			.0187
17	.237	1.6793	1.5429	.0183	.0187		.0185
18	.9678	1.9383	1.2906	.0187	.0187	.0187	.0183
19	.8749	1.6183	1.0917	.0183	.0187	.0185	.0187
20	1.853	1.9345	.2298	.0185	.0187		.0185
21	1.6918	1.6049	.0217	.0187	.0187	.0185	
22	1.9471	1.6968			.0187	.0366	
23	1.595	1.9589		.0187	.0187	.037	
24	1.7242	1.9509	.7095	.0187	.0183	.0187	.0373
Max	1.9755	2.061	2.0359	.101	.0373	.056	.0373
Min	.237	1.4361	.0217	.0183	.0183	.0185	.0183
Avg	1.5210	1.7741	1.5384	.0261	.0196	.0270	.0260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 202 / 11 KV Turkewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895		.2218	.2427	.0914		.1478
2	.0709	.2012	.2033	.2427	.112		.0895
3	.0701	.2054	.2218	.2614	.1097		
4	.0876	.2033	.1848	.2614	.0934		
5	.1075	.2195	.2218	.2614	.0924		.1417
6	.1075	.2241	.2402	.2801	.0924		.124
7	.1052	.2587	.2218	.2987	.1307		.124
8	.1949	.1478	.1663	.2054	.1307	.1307	.2149
9	.2835	.2054	.2218	.2801	.5853	.168	.2614
10	.2103	.2218	.2801	.3174	.5788	.2054	.4207
11	.168	.3881	.3361		.5228	.2865	.3696
12	.1829		.2987				.3475
13	.1294		.2987				.2987
14	.112		.3361				.1829
15		.4435	.3361		.3174	.5373	.1829
16		.3881	.3361		.4668		.1463
17		.3881	.3174	.2427	.5228		.3547
18		.2402	.1867	.2195	.2054	.2149	.2241
19		.2587	.168	.2054	.2427	.2686	.2218
20		.2592	.2054		.2427	.2534	
21		.2033	.168			.1949	
22	.3142	.3142	.2801	.168	.0093	.1417	
23	.2614	.2587	.2427	.1109		.1227	
24	.0876	.2218	.2218	.2427	.1109		.0895
Max	.3142	.4435	.3361	.3174	.5853	.5373	.4207
Min	.0701	.1478	.1663	.1109	.0093	.1227	.0895
Avg	.1519	.2626	.2465	.2400	.2451	.2295	.219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 201 / Parle Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2112	.2247	.2115	.2601	.1907	.2112	
2	.1766	.1867	.1879	.2427	.2254	.2087	
3	.1732	.148	.1739	.208	.2254	.2206	
4	.1732	.1471		.208	.208	.2156	
5	.2425	.2199		.208	.208	.2555	
6	.2768	.2942		.2947	.2427	.3158	
7	.3114	.3265		.2947	.3121	.3124	
8	.2683	.4175		.3865	.3467	.3573	.1677
9	.3672	.3827	.1717	.3513	.3536	.4449	.5365
10	.3361	.3176	.3422		.2298	.4374	.4748
11	.2805	.2832	.4503		.3403	.4604	
12	.3588	.2462	.2473				.3353
13		.2747	.3609				.3052
14	.2023	.2478					.243
15	.1686	.2747			.3151	.4359	.3467
16	.3093	.3483	.3844		.3159	.3795	.2427
17	.2398	.3467	.4717		.2957		.3467
18		.4255	.4717	.3294	.3668	.3795	.3429
19		.5218	.5028	.3988	.4503	.6241	.4166
20	.7346	.6251	.5075	.4558	.5761	.6219	.5548
21	.6244	.555	.5201	.4681	.4636		.4854
22	.4775	.3677	.4193	.2774	.4506	.394	.4334
23	.3371	.3012	.3145	.2774	.4362		.3814
24	.2457	.2622	.2569	.3294		.3206	
Max	.7346	.6251	.5201	.4681	.5761	.6241	.5548
Min	.1686	.1471	.1717	.208	.1907	.2087	.1677
Avg	.3102	.3227	.3526	.3119	.3277	.3664	.3742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 202 / Here Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0169	.0167	.0168	.0337	.1688	.2535	
2	.0169	.0167	.0168	.0169	.169		
3	.0169	.0167	.0168	.0169	.169		
4	.0169	.0169	.0168	.0169	.169		
5	.0169	.0338	.0336	.0169	.1688		
6	.0169	.0337	.0168	.0337	.0169		
7	.0169	.0337	.0168	.0337	.0169		
8	.0169	.0169	.0337	.0338	.0169		.2515
9	.9464	.845	1.096	.0338	.0169		.2683
10	.9126	.9295	1.6524	.0338	.0169	.0169	.0168
11	.8364	.8112	.9768	.0338	.0169	.0169	.0168
12	.736	.7739	.9768	.709	.0169	.0168	.0168
13			1.1453	.8946	.0169	.0168	.0168
14	.676			1.0128	.0169	.0168	.0168
15	.2366			1.1816	.0169	.0168	.0168
16	.2997	.6393	.0168		.0169	.0168	.0168
17	.0169	.6729	.8421		.0169		.0168
18		.6364	.8758	.0169	.0169	.285	.0168
19		.0168	.0337	.0169	.0169	.0168	.0169
20	.0167	.0168	.0337	.0169	.0169	.0168	.0169
21	.0167	.0168	.0337	.0169	.0169		.0338
22	.0169	.0168	.0337	.2194	.0169		.0338
23	.0169	.0168	.0337	.1688	.0169		.0338
24	.0169	.0169	.0168	.0337	.1688	.0169	
Max	.9464	.9295	1.6524	1.1816	.169	.285	.2683
Min	.0167	.0167	.0168	.0169	.0169	.0168	.0168
Avg	.2324	.2664	.3607	.2087	.0549	.0589	.0504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 203 / Patane ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.5862		.6999	.0171	.0176	.0166
2	.4689	.5517		.6821	.0171		.0166
3	.4354	.5178	.5064	.6576	.0171		.0164
4	.4315	.5127	.5377	.6991	.0171		.0164
5	.3891	.4785	.5298	.6991	.0171		.0164
6	.4215	.4438		.6139	.0171		.0164
7	.4215	.4428	.6284	.5115	.0171		.0164
8	.0189	.0186	.0181	.034	.0171		.0164
9	.0182	.0188	.0187	.034	.9228	.4175	.4915
10	.0163	.0181	.0184	.034	.9912	.96	.4858
11	.0171	.0186	.0182	.034	1.1216	.9198	.5243
12	.0117	.0165	.0183	.034	1.1187	1.1233	.5735
13	.0117	.0184	.0171	.034	1.0528	1.1603	.5735
14	.0117	.019		.0341	.7584	1.1603	.6091
15	.0119	.019		.0341	.4755	1.2071	.5414
16	.0109	.0189	.0171		.6601	.9054	.5752
17	.0109	.0168	.0171		.5218		.0169
18		.018	.0171	.0171	.0174	.0168	.0169
19		.0182	.0341	.0171	.0177	.0187	.0169
20	.019	.0186	.0341	.0171	.0188	.017	
21	.0189	.0187		.0171	.0191		.0338
22	.5869	.8946	.8535	.0171	.0189	.0179	.0338
23	.5856	.8897	.8535	.0171	.0191	.0175	.0338
24	.4354	.62		.8176	.0171	.0188	.0166
Max	.5869	.8946	.8535	.8176	1.1216	1.2071	.6091
Min	.0109	.0165	.0171	.0171	.0171	.0168	.0164
Avg	.2192	.2581	.2434	.2616	.3287	.5319	.2032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 401 / Aqua

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	1.2346
Max	1.2346
Min	1.2346
Avg	1.2346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 407 / 33 KV KEMPLAST

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 805 / Hemrus

Feeder KV- 220 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 201 / 11 KV GADHINGLAJ

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.1888	1.0974	1.1888	1.0974	1.0974	1.0974
2	1.0974	1.134	1.0608	1.0608	1.0608	1.0608	1.0608
3	1.0608	1.134	1.0608	1.0608	1.0242	1.0425	1.0608
4	1.0608	1.1888	1.0608	1.0608	1.0242	1.0608	1.0608
5	1.0608	1.2071	1.0974	1.0974	1.0608	1.0974	1.0608
6	1.0974	1.2437	1.1888	1.1888	1.1888	1.0974	1.086
7	1.134	1.2437	1.2803	1.2803	1.2437	1.134	1.1888
8	1.134	1.2803	1.2254	1.2803	1.2803	1.1888	1.2071
9	1.1946	1.2437	1.2803	1.3169	1.39	1.1706	1.2071
10	1.2071	1.3169	1.4266	1.4632	1.4266	1.4266	1.39
11	1.1946	1.4266	1.5364	1.6461	1.5729	1.5729	1.4266
12	1.1946	1.4632	1.6095	1.6461	1.6461	.695	1.4266
13	1.1765	1.4632	1.6095	1.5364	1.6461	1.6461	1.4266
14	1.1888	1.4998	1.5364	1.5364	1.6461	1.6461	1.4266
15	1.2071	1.4632	1.5364	1.4632	1.6461	1.6461	1.4998
16	1.2437	1.4998	1.3032	1.5729	1.6827	1.5546	1.5729
17	1.262	1.4998	1.5364	1.5729	1.6461	1.5546	1.4632
18	1.2803	1.5364	1.6461	1.7558	1.4998	1.4632	1.3717
19	1.6095	1.7558	1.4632	1.9387			1.6461
20	1.829	1.9753	1.9753	1.9387	1.829	1.6461	1.829
21	1.6461	1.8656	1.9022	1.7558	1.7741	1.6461	
22	1.6461	1.6095	1.6461	1.5729	1.4632	1.4632	1.6461
23	1.5364	1.3717	1.4266	1.3169	1.3717	1.2437	1.5364
24	1.2803	1.2803	1.2254	1.2437	1.1888	1.2071	1.134
Max	1.829	1.9753	1.9753	1.9387	1.829	1.6461	1.829
Min	1.0608	1.134	1.0608	1.0608	1.0242	.695	1.0608
Avg	1.2729	1.4121	1.4055	1.4373	1.4091	1.3200	1.3402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 204 / 11 KV Uttur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6066	3.5056	.4344	3.4598	2.8197	.4527	.6066
2	.5689	3.4294	.4344	3.2427	2.8521	.4527	.5689
3	.4927	3.3532	2.1148	3.2427	2.6788	.4527	.5689
4	.5304	3.5452	2.3739	3.213	2.6788	.4527	.4927
5	.5304	3.6092	2.1262	3.3074	2.7283	.4527	.4927
6	.6254	3.8698	.6287	4.0543	.7315	.5212	.6066
7	.7952	4.7874	3.1207	2.7053	.7277	.6035	.6443
8	.6066	.5689	.5822	.5822	.6554	.6035	.6443
9	.4927	.5689	.5492	.6066	2.2177	2.1125	2.2649
10	.4927	.55	.4927	.6443	3.8866	3.9582	4.2234
11	.4738	.4738	.4738	.5311	4.0542	4.0771	4.1762
12	.4549	.3795	.4361	.4549	4.0771	2.8654	3.9658
13	.4549	.3222	.3599	.4549	4.0542	3.8256	3.789
14	.2452	.4738	.3599	.4738	2.5164	3.5894	3.6702
15	.2263	.4549	.3787	.4927	2.8975	4.058	3.9018
16	.2641	.5115	.3222	.4549	1.7528	4.5512	4.0542
17	.2401	.4927	.4153	.5289	.9862	2.5125	2.588
18	.2427	.602	.5273	.6706	.5115	.4549	.5681
19	.3467	.6706	.6782	.7918	.2286	.2286	.6443
20	.4115	.8962	.7468	.8962	.6443	.5182	.7651
21	.4161	.8291	.7468	.82	.6443	.7009	.381
22	1.8138	3.8477	3.6275	3.0087	.5791	.796	.7582
23	1.8244	3.959	3.7448	3.1276	.5822	.7205	.6254
24	.3018	3.6458	2.2557	3.2198	1.5889	.5128	.6066
Max	1.8244	4.7874	3.7448	4.0543	4.0771	4.5512	4.2234
Min	.2263	.3222	.3222	.4549	.2286	.2286	.381
Avg	.5607	1.8894	1.1638	1.7077	1.9622	1.6447	1.7336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 205 / 11 KV Nool Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.5769	.0171	.5548	.282	.0187	
2	.0185	.4968	.0171	.5639	.2789	.0187	
3	.0185	.4206	.282	.5639	.2789	.0187	
4	.0185	.4991	.6935	.4968	.2804	.0187	
5	.0185	.5289	.5639	.4991	.2804	.0187	
6	.0185	.5315	.141	.6249	.0171	.0373	
7	.0189	.5477	.7049	.3219	.0173	.0187	
8	.0185	.0185	.0173	.0173	.0173	.0187	
9	.0189	.0189	.0189	.0189	.2073	.1174	.1128
10	.0189	.0189	.0377	.0189	.3353	.4542	.3216
11	.0189	.0189	.0189	.0189	.4024	.5365	.4001
12	.0189	.0189	.0189	.0185	.474	.5075	.3978
13	.0189	.0189	.0189	.0377	.4968	.426	.2652
14	.2452	.0189	.0189	.0377	.4572	.4024	.2652
15	.0189	.0189	.0189	.0189	.4176	.4024	.2652
16	.0189	.0189	.0189		.3978	.4046	.2682
17	.0171	.0187	.0187		.1844	.1709	.1894
18	.0173	.0187	.0373		.0185	.0185	.037
19	.0347	.0183	.0373	.0187			.0185
20	.0171	.0366	.0373	.0187	.037	.0554	.0185
21	.0347	.0373	.0373	.0183	.0185		
22	.6401	.7651	.6096	.2934	.0347		.0189
23	.7651	.8459	.7125	.2789	.0173		.0189
24	.3233	.7293	.3219	.4115	.128	.0173	
Max	.7651	.8459	.7125	.6249	.4968	.5365	.4001
Min	.0171	.0183	.0171	.0173	.0171	.0173	.0185
Avg	.0990	.2600	.1841	.2310	.2208	.1841	.1855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 207 / 11 KV WATERWORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3204	.5281	.3033	.3383	.5281	.5974	.6066
2	.3018	.49	.3002	.3002	.4146	.4908	.493
3	.3018	.3391	.3018	.3002	.3391	.2987	.4172
4	.3772	.3772	.3383	.3399	.3772	.3399	.3791
5	.3772	.3734	.3383	.3772	.3414	.3399	.3791
6	.4146	.3772	.3753	.4168	.3391	.4146	.3791
7	.4713	.3772	.4504	.4527	.4527	.4481	.4549
8	.4713	.49	.4873	.4927	.4927	.4527	.4927
9	.7125	.6797	.7579	.7201	.6721	.7849	.6706
10	.7394	.6828	.743	.7394	.7171	.7544	.7468
11	.7394	.6258	.7205	.6073	.6043	.679	.7171
12	.55	.5877	.6066	.5308	.5662	.5281	.6035
13	.5119	.5496	.5685	.5382	.5654	.5974	.5662
14	.4172	.5308	.5308	.5496	.4862	.5243	.5228
15	.3222	.4742	.4742	.5496	.5281	.4862	.6035
16	.3222	.398	.398	.493	.4527	.3959	.4153
17	.3791	.41	.4146	.41	.3018	.3772	.3959
18	.3772	.2987	.3772	.3734	.3018	.3391	.3772
19	.3791	.3353	.3734	.3551	.1905	.1905	.3204
20	.3399	.3734	.3734	.3368	.3585	.2621	.3204
21	.3772	.6721	.41	.3399	.3959	.3938	.1905
22	.5273	.679	.3772	.4831	.4546	.5496	.6062
23	.7171	.6755	.3414	.5654	.679	.682	.6066
24	.4728	.5654	.3018	.4526	.6043	.6447	.6062
Max	.7394	.6828	.7579	.7394	.7171	.7849	.7468
Min	.3018	.2987	.3002	.3002	.1905	.1905	.1905
Avg	.4550	.4954	.4443	.4609	.4651	.4821	.4946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 210 / 11 KV Uttur VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4024	.439	.439	.3658	.439	.4344
2	.3658	.3658	.439	.3658	.362	.439	.4024
3	.3658	.3658	.3658	.3658	.3658	.3658	.4024
4	.4207	.3658	.439	.3658	.3658	.3658	.4024
5	.4207	.3841	.439	.3658	.3658	.4024	.439
6	.4207	.3841	.439	.439	.3658	.439	.4706
7	.4207	.3658	.439	.439	.439	.439	.4525
8	.4207	.3841	.439	.439	.3658	.439	.5068
9	.4477	.4656	.4344	.5014	.439	.4755	.5121
10	.4477	.4024	.4477	.4656	.5121	.5121	.4755
11	.4477	.4755	.4656	.4938	.439	.5121	.439
12	.4298	.4938	.4298	.5611	.439	.5121	.439
13	.4298	.439	.439	.543	.2926	.5121	.439
14	.394	.4706	.4706	.5121	.439	.5487	.5121
15	.3801	.4706	.4835		.5121	.5121	.5121
16	.3761	.4572	.4755	.439	.5121	.2561	.439
17	.3658	.439	.4755	.439	.5121	.5121	.439
18	.3658	.4755	.5121	.6584	.2926	.4572	.4572
19	.439	.5853	.5853	.7316			.5121
20	.6584	.7316	.7316	.6584	.6219	.2926	.6401
21	.6584	.6584	.695	.6584	.6401	.6219	
22	.5853	.6584	.6584	.5487	.5853	.5611	.6335
23	.4938	.5121	.5121	.439	.439	.4835	.5487
24	.439	.4024	.439	.439	.3658	.439	.4344
Max	.6584	.7316	.7316	.7316	.6401	.6219	.6401
Min	.3658	.3658	.3658	.3658	.2926	.2561	.4024
Avg	.4415	.4648	.4872	.4916	.4364	.4581	.4758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 211 / 11KV Belbag

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.9145	.8779	.8048	.7316	.7316	.8048
2	.8048	.7316	.8048	.8048	.7316	.7316	.7682
3	.8048	.7316	.8048	.8048	.7316	.6584	.7682
4	.823	.7682	.8048	.8048	.7316	.6584	.7682
5	.823	.8048	.8048	.8048	.7316	.7316	.7682
6	.823	.8048	.8048	.8048	.8048	.7316	.8048
7	.8048	.7865	.8779	.8048	.8048	.6584	.7316
8	.8596	.7499	.8048	.8048	.8048	.7316	.8048
9	.8048	.8048	.8048	.8688	.8779	.8779	.8779
10	.8048	.8779	.9511	.8779	.8779	.8413	.8779
11	.8048	.9511	.9511	1.0242	1.0608	1.0974	1.0242
12	.8688	1.0242	1.0242	1.0974	1.0974	1.0974	1.0242
13	.8779	1.0974	1.0242	1.1706	1.0974	1.0242	.8779
14	.8779	1.0242	1.0242	1.1317	1.0242	1.0974	.9511
15	.8779	.9877	1.0974	.9511	1.0242	1.1706	1.0242
16	.9412	1.0242	.4344	1.0974	1.1706	1.1706	1.0242
17	.9511	1.0242	1.0974	1.0974		1.134	1.0974
18	.8779	1.1706	1.2437	1.2437	1.1706	1.0242	1.0242
19	1.1706	1.0974	1.1706	1.1706			1.2437
20	1.3169	1.2437	1.3169	1.2437	1.2254	1.2437	1.4266
21	1.2437	1.0242	1.1706	1.0974	.0183	1.134	
22	1.0974	1.0974	1.0974	1.0242	.9511	1.0242	1.0974
23	1.0608	.9511	.9511	.9511	.8779	.8688	.9511
24	.9145	.9328	.8779	.8779	.8779	.7316	.8048
Max	1.3169	1.2437	1.3169	1.2437	1.2254	1.2437	1.4266
Min	.8048	.7316	.4344	.8048	.0183	.6584	.7316
Avg	.9198	.9427	.9509	.9735	.8829	.9205	.9368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 201 / 11 Kv Karambali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	1.1336	.2458	1.0526	1.2146	.213	.1943
2	.2267	1.1336	.2458	1.004	1.1984	.1966	.1943
3	.2267	1.1336	.7537	.9878	1.1984	.1966	.1943
4	.2267	1.2308	.852	.9878	1.2289	.1966	.2105
5	.2429	1.2955	.2949	1.1012	1.2308	.213	.2105
6	.2591	1.3279	.213	1.2146	.2105	.2294	.2267
7	.2429	1.3117	1.2452	.2105		.2294	.2267
8	.2429	.3077	.2458	.2591	.2267	.3113	.2591
9	.2267	.3239	.2622	.2105	1.7004	1.5893	1.6194
10	.2591	.2622		.2267	2.0153	1.9826	1.8785
11	.2429	.2622	.2267	.1943	1.917	1.9433	1.749
12	.2429	.2294	.2105	.1943	1.7695	1.8138	1.6518
13	.2429	.213	.2267		1.8187	1.8138	1.5546
14	.2267	.213	.2267		1.7695	1.6194	1.5546
15	.2105	.2949	.2429	.0972	1.8023	1.5384	1.5708
16	.2267	.2785	.1943	.1943	1.6385	1.6518	1.6518
17	.2267	.2622	.2105	.1943	.2622	.2429	.2591
18	.3239	.2785	.2267	.2591	.2458	.2105	.2429
19	.3239	.2458		.1943			.2429
20	.3239	.2622	.2267	.2267	.2294	.1943	.2591
21	.3239		.2429	.2267	.2622	.1943	.2753
22	1.2793	1.2125	1.2146	1.3603	.2622	.1943	.2915
23	1.1984	1.1797	1.1822	1.3279	.2294	.1943	.2591
24	.2429	1.166	.2622	1.1336	1.2631	.2294	.1943
Max	1.2793	1.3279	1.2452	1.3603	2.0153	1.9826	1.8785
Min	.2105	.213	.1943	.0972	.2105	.1943	.1943
Avg	.3340	.6765	.4205	.5844	1.0770	.7478	.7071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 202 / 11 KV Kaulage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6905		.2157	.2378		
2		.6775	.2683	.1593	.2263		
3		.6706	.5235	.1563	.2263	.1341	
4		.6623	.7041	.1585	.2317		
5		.7118	.4588	.2081	.186		
6		.7339	.3559	.2622			
7		.4534	.4603				
8					.0061		.0259
9					.3681	.2027	.3239
10					.4657	.2408	.3593
11					.4138	.2979	.2866
12					.4054	.3025	.2614
13					.3452	.3033	.2428
14					.3605	.2926	.2103
15					.3262	.2287	.2344
16					.288	.1798	.1943
21	.3147	.3696	.1684	.1372			
22	.8215	.7465	.3216	.2698			
23	.8268	.6585	.2517	.2934			
24	.4313	.3688	.1318	.2631	.1174		
Max	.8268	.7465	.7041	.2934	.4657	.3033	.3593
Min	.3147	.3688	.1318	.1372	.0061	.1341	.0259
Avg	.5986	.6130	.3644	.2124	.2803	.2425	.2377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 203 / 11 KV Ainapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6915					1.0124	1.1561
2	3.6131					1.0281	1.1622
3	3.5971					1.0661	1.1721
4	3.6244					1.0928	1.254
5	3.7612					1.1919	1.3059
6	4.0017					1.496	1.6011
7	2.002					1.5496	1.7527
8	2.0462	1.6187	1.3192			1.5009	1.5885
9	3.9552	3.1443	2.4585				
10	4.06	3.4888	1.3375	.5441			
11	3.059	3.3311	2.4261	1.8824			
12	2.9877	.9537	2.2767	2.1502			
13	2.6025		2.0225	2.2096			
14	2.7157		1.9989	2.0709			
15	2.8216	1.009	2.0153	.9173			
16	1.3965	2.0881	1.1862	.7845			
17		2.0599		.2747			
18		.8852		.4752			
24	1.4746				.2987	.2713	.2446
Max	4.06	3.4888	2.4585	2.2096	.2987	1.5496	1.7527
Min	1.3965	.8852	1.1862	.2747	.2987	.2713	.2446
Avg	3.0241	2.0643	1.8934	1.2565	.2987	1.1343	1.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 204 / 11 KV Hiralge(karmbali) Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4534	.4049	.426	.4372	.3725	.3277	.3725
2	.421	.4049	.426	.4049	.3725	.2949	.3563
3	.4049	.4049	.4096	.4049	.3725	.2785	.3563
4	.4049	.421	.4096	.3887	.3932	.3277	.3563
5	.4049	.421	.4096	.421	.421	.3932	.3725
6	.421	.4372	.4752	.4534	.4534	.426	.3887
7	.4534	.4534	.426	.4534	.3887	.4588	.4372
8	.4534	.4858	.4752	.4049		.4752	.4534
9	.421	.4858	.032	.3887	.502	.4752	.4696
10	.3725	.4752		.3401	.4915	.4096	.4534
11	.3563	.4752	.3887	.2591	.5079	.4534	.421
12	.3887	.4588	.4696		.4752	.4858	.421
13	.3563	.4752	.4534	.1457	.3441	.421	.4049
14	.3239	.4752	.421	.4696		.4534	.3887
15	.3401	.4096	.4372	.421	.4096	.4534	.421
16	.3239	.4588	.421	.4534	.4588	.3401	.4049
17	.4049	.4588	.4534	.421	.4424	.3887	.421
18	.4534	.4915	.3887	.5506	.3932	.5182	.5182
19	.4858	.6062		.5668			.5506
20	.6316	.6554	.6154	.583		.5506	.6964
21	.5668	.5898	.583	.5344	.3277	.5182	.6478
22	.5506	.5571	.5506	.5182	.4915	.502	.5992
23	.4696	.4915	.4858	.421	.4096	.4534	.5344
24	.4534	.421	.4424	.4534	.4049	.3768	.4049
Max	.6316	.6554	.6154	.583	.5079	.5506	.6964
Min	.3239	.4049	.032	.1457	.3277	.2785	.3563
Avg	.4298	.4758	.4363	.4302	.4216	.4253	.4521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 205 / KCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0368	.0364	.0368	.0366	.0365	.0366
2	.0368	.0365	.0369	.0365	.0364	.0366
3	.0369	.0365	.0368	.0366	.0364	.0365
4	.0369	.0366	.0368	.0364	.0365	.0366
5	.0368	.0365	.0368	.0365	.0365	.0365
6	.0369	.0364	.037	.0366	.0367	.0373
7	.0369	.0372	.0366	.037	.0374	.0374
8	.0378	.037	.0373	.0364	.0375	.0375
9	.0376	.0366	.0374	.0371	.0367	.0357
10	.0374	.0376	.0183	.0375	.0368	.0372
11	.0372	.0373	.0366	.0376	.0366	.0366
12	.0373	.0375	.037	.0372	.0369	.0367
13	.0376	.0382	.0373	.0374	.0374	
14	.0376	.0382	.0374	.0372	.0374	
15	.0376	.0381	.0374	.0374	.037	
16	.0378	.0378	.0375	.0377	.0373	
17	.0378	.0378	.0374	.0376	.0376	
18	.0376	.0378	.0375	.0375	.0378	
19	.0375	.0376	.0186	.0373	.0377	
20	.0368	.0372	.0371	.0369	.0368	
21	.037	.0372	.0371	.037	.0369	
22	.0364	.0369	.0366	.0366	.0368	
23	.0363	.0368	.0363	.0364	.0368	
24	.0365	.0366	.0366	.0363	.0367	.0191
Max	.0378	.0382	.0375	.0377	.0378	.0375
Min	.0363	.0364	.0183	.0363	.0364	.0191
Avg	.0372	.0372	.0355	.0370	.0370	.0354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 201 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0183	.0343	.0373	.0343	.0187	.0171
2	.0187	.0183	.0343	.0373	.0751	.0187	.0171
3	.0187	.0183	.0343	.0373	.0751	.0187	.0171
4	.0187	.0183	.0343	.0373	.0343	.0187	.0552
5	.0187	.0183	.0343	.0373	.0751	.0187	.0552
6	.0187	.0183	.0724	.0754	.0751	.0187	.0552
7	.0187	.0183	.0724	.0754	.4496	.0187	.0724
8	.0187	.0366	.0724	.0373	.7544	.0568	.0724
9	.0187	.2622	.0514	.0373	.7731	.0941	.0724
10	.0187	.735	.7156	.6394	.4549	.602	.703
11	.0185	.381	.8299	.7544	.1512	.7918	.7792
12		.8135	.8299	.7357	.1696	.7277	.8112
13	.0185	.7449	.7544	.3983	.1696	.7792	.4364
14	.0185	.5525	.7544	.0751	.1322	.4324	.0751
15	.0185	.7411	.381	.0381	.0924	.1448	.0751
16	.0185	.7792	.2271	.0751	.0754	.1448	.0935
17	.037	.4667	.1509	.0935	.0754	.1238	.0935
18		.0895	.0941	.0751	.0743	.0762	.0751
19		.0895	.0941	.0747	.0381	.0381	.0751
20	.0185	.0895	.0754	.0366	.0362		.0751
21	.037	.0724	.0187	.0564	.0754	.0343	.0751
22	.0185	.0724	.0373	.0183	.0362	.0171	
23	.0185	.0381	.0373	.0185	.0373	.0171	.0185
24	.0187	.0185	.0343	.0373	.0185	.0373	.0171
Max	.037	.8135	.8299	.7544	.7731	.7918	.8112
Min	.0185	.0183	.0187	.0183	.0185	.0171	.0171
Avg	.0204	.2546	.2281	.1474	.1660	.1847	.1668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 202 / Shendri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5344	.0686	.0686	.0328	.0343	.5668	.3601
2	.6161	.0514	.0686	.0328	.0343	.5506	.3601
3	.5344	.0514	.0686	.0328	.0343	.5658	.3601
4	.5344	.0514	.0514	.0328	.0343	.5344	.3772
5	.583	.0514	.0686	.0655	.0343	.5155	.3944
6	.6154	.0686	.0686	.0655	.0514	.6154	.4973
7	.6478	.0686	.0857	.0819	.0857	.583	.463
8	.1134	.0857	.0686	.0819	.0857	.583	
9	.9069	.9955	1.0631	.0819	.0693	.0324	
10	.8436	.9328	.8684	.0819	.0693	.0972	
11	.905	.8745	.7537	.8688	.0814	.0373	
12	.7865	.6687	.6718	.9774	.0648	.0514	.1227
13	.7316		.6554	.9412	.0747		.0876
14	.6767		.6062	.905	.056	.0857	.0876
15	.6584		.6718		.0324	.0857	.0701
16	.6401	.5658		.543	.0324	.0686	.0876
17	.0857	.5658	.3277	.5249	.0312	.0686	.0876
18	.0857	.5316	.3605	.4706	.0486	.0514	.0701
19	.0857	.0686	.0983	.0857			.0701
20	.1029	.1029	.0819	.0857	.0469		.0876
21	.1029	.1029	.0819	.0686	.0469	.0171	.0876
22	.0857	.12	.0655	.0514	.0324	.0514	
23	.0686		.0655	.0514	.0324	.0514	.0701
24	.6348	.0686	.0686	.0328	.0514	.0324	.0514
Max	.9069	.9955	1.0631	.9774	.0857	.6154	.4973
Min	.0686	.0514	.0514	.0328	.0312	.0171	.0514
Avg	.4825	.3047	.3039	.2694	.0506	.2498	.1996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025] BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 201 / Nool Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 202 / Bhadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	.0509		.0492	.0554		.5426
2	.9831	.0497		.0486	.0554		.6554
3	.9503	.0497		.0492	.0554		.7537
4	.9503	.0497		.0492	.0554		.8259
5	.9667	.0497			.0554		.8802
6	1.0978	.0482		.0486	.0739		.9922
7	1.1469	.0829		.0819	.132		1.1043
8	.0943	.116		.0648	.0943		1.094
9	1.2308	1.4413	1.3765	.081	.0762	.0943	.0509
10	1.3117	1.3927	1.4251	.0655	.0754	.1132	.0328
11	.9717	1.3272	1.3927	1.0364	.0754	.0747	
12	1.3279	1.2163	1.247	.2267	.0754	.056	.0497
13	.8907		1.2452	1.1961	.0754	.056	.0497
14	.8097		1.1469	1.247	.0566	.0747	.0492
15	.8907		1.1174	.9831	.056	.0566	.0492
16	.7611	1.0322		1.0364			.0497
17	.0747	1.0486	.7125	1.0364			.0747
18	.0924	.7209	.6964	.9231			.0549
19	.112	.0678	.056	.0747			.0943
20	.112	.0848	.0943	.0934			.1307
21	.0914	.0895	.0943	.0747	.0747	.0716	.1307
22	.0934		.0754	.0934	.0701	.0709	
23	.0716		.0514	.0554	.052	.052	.132
24	1.0442	.0532		.0497	.0554	.052	.0514
Max	1.3279	1.4413	1.4251	1.247	.132	.1132	1.1043
Min	.0716	.0482	.0514	.0486	.052	.052	.0328
Avg	.7117	.4722	.7665	.3767	.0695	.0702	.3567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 203 / Chennikuppi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.6516		.8951	.8002		.0686
2	.1334	.5967		.852	.8002		.0732
3	.132	.5967		.8619	.7907		.0739
4	.132	.5967		.852	.6401		.0754
5	.132	.6554		.9393	.8002		.0934
6	.132	.9835		1.0364	.1109		
7	.1132	.9835		.0972	.1132		.132
8	.0943	.0995		.0829	.1132		.1311
9	.112	.0848	.0953	.0995	.9602	.9602	.9945
10	.112	.096	.1143	.0983	1.2334	1.1683	1.1469
11	.112	.0995	.0943	.0983	1.2163	1.1843	1.1271
12	.0754	.0972	.0943	.0648	1.1203	1.1523	1.0486
13	.1132	.0876	.0943	.0819	1.0883		1.0277
14	.1132	.081	.1132	.1132	1.0608	1.0242	.9831
15	.0754	.081	.0943	.0754	1.004	1.0364	.9831
16	.0905	.1147	.0943	.0754			1.065
17	.0905	.0983	.132	.1132			.1132
18	.1052	.0995	.0943	.132			.1132
19	.1109	.1174	.1109	.1494			.2096
20	.1509	.1696	.1509	.168			.2286
21	.1478	.1753	.1698	.168	.1696	.1509	.1886
22	.961		.852	.8097	.1227	.1509	
23	.7537		.8642	.8322	.1109	.0934	.1107
24	.132	.6401		.8951	.8322	.0924	.0924
Max	.961	.9835	.8642	1.0364	1.2334	1.1843	1.1469
Min	.0754	.081	.0943	.0648	.1109	.0924	.0686
Avg	.1774	.3275	.2112	.3996	.6888	.7013	.4582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 201 / 11 KV Nilaji Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6401	.6413	.6348	.6097	.5716	.0572
2	.6401	.6401	.5975	.6348	.5716	.5658	.0572
3	.6401	.6401	.5544	.5975	.5335	.5716	.0572
4	.6401	.6401	.5544	.5975	.5716	.5716	.0566
5	.6584	.6401	.5975	.5544	.6097	.5658	.0754
6	.6584	.6584	.6283	.6283	.6348	.6413	.0943
7	.5487	.6584	.6584	.5914	.7392	.6413	.0943
8	.5487	.6584	.5914	.5853	.6878	.6722	.056
9	.5792	.6219	.5853	.6447	.6805	.695	
10	.6154	.6447	.7164	.7442	.7164	.7442	.2534
11		.6805		.7442	.7362	.7522	.724
12		.6447	.7682	.6219	.7087	.6089	.788
13		.6805	.6805	.6447	.7011	.6154	.724
14		.5853		.543	.6661	.6283	.7316
15		.5792	.4481		.6584	.6348	.7023
16		.6722	.4908		.5853		.6653
17		.6413			.6283		.924
18		.567	.6733				1.0829
19		.7762	.8501				1.1203
20		1.1203	1.0562				1.1576
21	1.0974	1.0562	1.0456	.961	.8962		1.105
22	.9511	1.0082	.9709	.7842	.8676		1.0082
23	.823	.8299	.8131	.7545	.7167		.7922
24	.6401	.6401	.6722	.7095	.6478	.6036	
Max	1.0974	1.1203	1.0562	.961	.8962	.7522	1.1576
Min	.5487	.567	.4481	.543	.5335	.5658	.056
Avg	.6915	.7052	.6949	.6653	.6746	.6302	.5603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 202 / HITANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.823		.7499	.6443	.1267	.08
2	.1829	.823		.7186	.6516	.1307	.0838
3	.1829	.823	.583	.6642	.6344	.132	.081
4	.1829	.823	.6802	.6249	.6516	.132	.08
5	.2195	.8779	.7362	.8322	.6687	.1494	.1017
6	.2378	.9511		.9717	.2804	.2614	.181
7	.3658	1.0059	.9221	.6828	.3189	.3174	.2353
8	.2926	.3077	.362	.3439	.3045	.3361	.2481
9	.2658	.2801		.362	.7202	.6325	
10	.2103		.2534	.2865	.7773	.8642	
11	.1829		.2481	.2103	.8539	.8223	.6874
12			.1595	.1734	.6706	.6173	.7362
13			.1372	.1227	.6249	.5247	.5864
14			.1715	.1254	.5693	.4458	.6249
15			.1357		.5312	.4725	.5937
16			.1696		.5693		.6478
17					.2195		.181
18			.1629				.1848
19			.2033				.1848
20		.3292	.2075		.2033		.2241
21	.2743	.3361	.2054	.181	.1886		.1867
22	.8059	.7045	.8907	.78	.1886		.1663
23	.8596	.6081	.8223	.7545	.1463		.128
24	.1829	.823		.7499	.6783	.1307	
Max	.8596	1.0059	.9221	.9717	.8539	.8642	.7362
Min	.1829	.2801	.1357	.1227	.1463	.1267	.08
Avg	.3086	.6797	.3917	.5186	.5044	.3810	.2963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 203 / HASURCHAMPU AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.1829	.1698	.1698	.1334	.4744	.132
2	.8779	.1829	.1698	.1509	.1334	.4999	.1132
3	.8779	.1886	.1698	.1509	.1334	.5376	.1132
4	.9145	.1829	.132	.132	.1334	.5312	
5	.9511	.1829	.1886	.132	.1509	.6483	
6	1.0059	.2012	.1867	.1698	.1524	.8802	
7	1.0425	.2012	.1698	.1867	.1715	.9374	.2263
8	.2012	.1886	.2054	.1886	.1867	.7274	.1698
9	.7432	.8436	.8855		.1307	.1698	
10	.6718	.8025	.8436		.112	.132	.3086
11	.5937	.5937		.7186	.0747	.112	.3163
12	.578		.5247	.7907	.1663	.112	.3086
13	.4938		.4666	.7545	.1494	.0934	.2972
14	.4938		.4214	.6478	.1494	.1174	.0934
15	.4115		.4161		.1478	.1132	.1132
16		.4938			.1494		.1334
17		.4572	.2462		.1509		.1886
18		.4167	.2787				.1886
19		.2075	.1886				.1886
20		.2096	.2096				.2286
21	.1829	.2096	.2286	.1867	.2263		.2096
22	.2012	.2075	.2075	.1509	.0189		.1905
23	.1886	.1886	.1886	.1334	.1886		.1905
24	.8779	.1829	.1886	.1698	.1334	.1886	
Max	1.0425	.8436	.8855	.7907	.2263	.9374	.3163
Min	.1829	.1829	.132	.132	.0189	.0934	.0934
Avg	.6413	.3162	.3039	.3021	.1425	.3922	.1953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 201 / 11 KV Halkarni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1454	1.3662		1.3202	.3105	.3463	.3327
2	1.1417	1.3113	.0038	1.2827	.2912	.3422	.313
3	1.1694	1.2247	1.0463	1.2671	.2934	.3216	.314
4	1.1819	1.227	1.1067	1.3119	.3102	.3256	.333
5	1.1839	1.3753	1.107	1.4106	.3578	.3908	.3704
6	1.3053	1.7418	.2942	1.6522	.4125	.4451	.4298
7	1.5612	1.6548	1.7805	1.3456	.474	.4916	.4766
8	.3685	.4378	.3981	.4649	.48	.4317	.4718
9	.436	.502	.4355	.4371	2.0081	1.7876	1.7462
10	.4501	.4384	.4979	.415	2.1997	2.2976	2.2502
11	.3906	.3532	.401	.3455	2.0518	2.1694	2.3239
12	.3163	.3324	.3816	.352	1.9126	2.0206	2.2672
13	.314	.3547	.3167	.3498	1.6112	1.8857	2.0159
14	.0335	.3486	.3086	.3171	1.5362	1.8174	1.8711
15	.343	.3824	.2919	.3024	1.0872	1.7855	1.8774
16	.3696	.4302	.3697	.2595	1.4093	1.5534	1.8692
17	.4638	.4873	.2294	.3244	1.2684	.6332	.6924
18	.6015	.4356	.4669	.4668	.4489	.4337	.6188
19	.5628	.4592	.5254	.4801	.4333	.2416	.6403
20	.5304	.5573	.5807	.4793	.4976	.3997	.6619
21	.9297	.9018	.9656	.4744	.4708	.3715	.6589
22	1.3831	1.4662	1.4289	.4687	.4424	.357	.5883
23	1.4311	1.403	1.4068	.3803	.4007	.3894	.0457
24	1.2925	.6142	.7552	.794	.3795	.3566	.3258
Max	1.5612	1.7418	1.7805	1.6522	2.1997	2.2976	2.3239
Min	.0335	.3324	.0038	.2595	.2912	.2416	.0457
Avg	.7877	.8252	.6565	.6959	.8786	.8998	.9789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV Hiduggi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4064	.4052	.5107	.4738	2.8235	2.0607	1.4655
2	.387	.3887	.4938	.4611	3.021	2.5157	1.9526
3	.3712	.351	.4814	.4645	2.7563	2.5696	.6409
4	.3512	.349	.4799	.4693	2.8454	2.5735	
5	.3621	7.8356	.5024	.442	2.8545	2.7136	
6	.3827	.453	.4836	.463	.6182	2.9647	2.6971
7	.386	.402	.4724	.5171	.5029	3.6593	3.2241
8	.5094	.7295	.5882	.5165	.4256	3.2333	2.8274
9	3.8155	4.6164	3.9208	.6847	.3848	1.9662	1.8045
10	3.7961	4.8503	4.2014	.6508	.398	.3542	.3745
11	3.0471	4.1109	3.9209	.6246	.3925	.3475	.4127
12	2.5725	3.9658	3.6801	2.8926	.307	.3614	.3525
13	2.5258	1.7596	3.653	3.0949	.3469	.3493	.2619
14	2.7266		3.519	3.4467	.3781	.3563	.2353
15	2.6099		3.3548	3.5427	.3786	.3432	.3007
16	2.9226	2.8644	.5998	3.6789	.3566	.2995	.2889
17	.3652	.7417	.176	3.5121	.4186	.3443	.3624
18	.321	.9288	.4727	3.3054	.5835	.4501	.4325
19	.563	.4352	.4931	.4572	.5001	.2827	.4656
20	.6089	.4967	.5273	.4798	.4686	.4213	.4205
21	.5892	.4905	.5906	.6366	.4878	.4352	.4367
22	.4731	.5028	.4886	2.758	.5002	.4457	.4909
23	.458	.4951	.4355	2.8779	.4661	.4971	.2423
24	.4251	.4792	.482	1.8149	1.5514	.4634	.4303
Max	3.8155	7.8356	4.2014	3.6789	3.021	3.6593	3.2241
Min	.321	.349	.176	.442	.307	.2827	.2353
Avg	1.2907	1.7114	1.4387	1.5944	.9903	1.2503	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV nagnoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2466	.5728	.3315	.2682			
2	.2201	.5636	.3315	.2672			
3	.2134	.5422	.5499	.5357			
4	.2815	.5785	.571	.5324			
5	.286	.6482	.6181	.5868			
6	.3768	.796	.49	.3985			
7	.423	.6196	.6895	.7565			
8	.2187						
9	.4687				.8404	.7682	.8551
10	.5197				1.0113	.953	1.0125
11	.4245				.8794	.7887	.8936
12	.3688				.7651	.774	.7293
13	.3429				.7381	.6201	.7174
14	.3506				.6933	.6498	.6783
15	.3224				.7454	.2545	.6858
16	.3102				.7863	.2783	.7689
17					.298	.2294	.3452
21	.1776	.2439	.1951	.1776			
22	.6626	.7103	.6838	.3757			
23	.5818	.6501	.6587	.3826			
24	.5792	.6072	.0953	.6319			
Max	.6626	.796	.6895	.7565	1.0113	.953	1.0125
Min	.1776	.2439	.0953	.1776	.298	.2294	.3452
Avg	.3688	.5939	.4740	.4466	.7508	.5907	.7429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 204 / 11 KV HALKARNI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5562	.6007	.7161	.66	.7156	.7123	.6697
2	.5089	.5788	.6635	.6302	.6822	.6631	.6247
3	.511	.5292	.6696	.6279	.6483	.6493	.6469
4	.5293	.5421	.6686	.6455	.6663	.6372	.6257
5	.5609	.5416	.7043	.6831	.6808	.6249	.6447
6	.6306	.6436	.7556	.6923	.7705	.6814	.7203
7	.6148	.6476	.7346	.6558	.7029	.6979	.7495
8	.6901	.5939	.735	.6012	.6385	.6481	.688
9	.5586	.5076	.6525	.557	.7134	.6801	.6604
10	.5942	.4694	.6509	.5138	.6999	.6004	.6429
11	.5529	.611	.6781	.7422	.7032	.6542	.6564
12	.3549	.6038	.6776	.7171	.6464	.6782	.6287
13	.4229	.6083	.6902	.6891	.6571	.6577	.6736
14	.4109	.5949	.672	.7078	.6671	.6579	.6157
15	.5926	.5912	.6933	.6928	.6613	.631	.6386
16	.5932	.5567	.7174	.7415	.7537	.6054	.6388
17	.5582	.5807	.3452	.8509	.7834	.5287	.6756
18	.6728	.621	.7074	.9084	.8051	.6158	.6932
19	.1638	.9389	.9138	1.0131	.8799	.4176	.8761
20	1.051	1.0473	1.1458	1.0487	.9324	.9627	.9894
21	.9847	.9954	1.0996	.9959	.9479	.9047	.9914
22	.9258	.9372	.7789	.9238	.9406	.8418	.9139
23	.8139	.8544	.8663	.8989	.8712	.8059	.0655
24	.6726	.6844	.7513	.738	.8358	.7126	.7141
Max	1.051	1.0473	1.1458	1.0487	.9479	.9627	.9914
Min	.1638	.4694	.3452	.5138	.6385	.4176	.0655
Avg	.6052	.6617	.7370	.7473	.7501	.6779	.6852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 205 / 11 KV Hidduggi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2573	1.3614	1.6225	1.6534	1.6497	1.518	1.2167
2	1.5102	1.3159	1.7021	1.5608	1.5386	1.472	1.4076
3	1.4205	1.2826	1.6384	1.5594	1.5026	1.4283	1.4454
4	1.4312	1.239	1.5433	1.6336	1.4896	1.4306	1.4927
5	1.3634	1.2702	1.6373	1.7006	1.5588	1.5033	1.5485
6	1.7072	1.493	1.8453	1.9996	1.2226	2.0113	1.6978
7	1.7665	.5449	1.6468	2.1122	1.861	1.9553	1.8111
8	1.4807	1.0386	2.0503	2.0836	1.9604	1.7919	2.062
9	.9446	1.8877	1.8846	2.0134	1.3919	1.702	1.6542
10	1.4623	1.686	2.0008	1.2807	1.7451	1.5649	2.077
11	.5925	1.1659	1.8797	1.2506	1.1445	1.7284	1.827
12	.8215	.9874	1.9235	1.1173	1.0333	1.1306	1.2488
13	.573	.978	1.8342	1.0145	.8581	1.053	1.0432
14	.587	1.0385	1.0613	1.0944	.7418	.9775	.9957
15	.5474	.9431	.99	1.0105	.9127	.3521	1.0286
16	.5413	.9886	1.0414	1.1244	.8797	.2858	1.0351
17	.5952	.9366	.5601	1.0698	.909	.1969	.9577
18	.6182	1.1633	1.2007	1.3414	.9599	.5966	1.1022
19	1.3729	1.6816	1.373	2.4548	1.2469	.6074	1.0368
20	2.1757	1.9373	2.5304	2.5663	2.1415	1.6053	2.3785
21	2.2522	2.1928	2.591	2.3302	2.2693	2.1191	1.246
22	1.9514	2.1011	2.0107	2.2012	2.1922	1.9875	2.2504
23	1.6702	1.5199	2.0935	1.9444	1.8048	1.8086	.6882
24	1.6825	1.5822	1.8883	1.7569	1.6827	1.5142	1.4741
Max	2.2522	2.1928	2.591	2.5663	2.2693	2.1191	2.3785
Min	.5413	.5449	.5601	1.0105	.7418	.1969	.6882
Avg	1.2635	1.3473	1.6896	1.6614	1.4457	1.3475	1.4469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Nagnoor Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.2479	.2717	.2631	.2719	.265	.2648
2	.2403	.2485	.2498	.2606	.2677	.2586	.2611
3	.2411	.2613	.2637	.2759	.2493	.2452	.24
4	.2223	.2207	.2439	.2698	.2727	.2539	.2569
5	.2433	.2461	.2446	.2736	.2791	.2792	.2691
6	.2719	.245	.3013	.2995	.3134	.3254	.3056
7	.2751	.1934	.2727	.272	.3224	.3348	.3052
8	.261	.2356	.2449	.2885	.2958	.3251	.2995
9	.1934	.2183	.2454	.2551	.281	.3186	.2737
10	.2503	.2286	.2266	.2796	.317	.3174	.3635
11	.2129	.224	.204		.2999	.3362	.3262
12	.2402	.2074	.232	.3087	.2436	.157	.2946
13	.2364	.2249		.2423	.2713	.3065	.2981
14	.2375	.2343	.2482	.0808	.2521	.2907	.3103
15	.238	.2635	.248	.3658	.3212	.0274	.3112
16	.2416	.2601	.077	.3828	.3526	.1578	.3694
17	.2817	.3132	.1692	.4827	.3566	.3772	.3832
18	.3536	.253	.3315	.5105	.3691	.3344	.4168
19	.4325	.5528	.391	.5799	.4775	.2164	.5816
20	.5008	.4872	.4945	.5948	.6079	.5327	.6945
21	.4678	.4599	.4684	.5297	.5302	.4623	.3429
22	.4436	.4035	.4335	.4089	.4166	.3948	.537
23	.3197	.3175	.3509	.3165	.3323	.3178	
24	.2625	.2684	.2859	.2806	.3143	.2731	.3227
Max	.5008	.5528	.4945	.5948	.6079	.5327	.6945
Min	.1934	.1934	.077	.0808	.2436	.0274	.24
Avg	.2875	.2840	.2826	.3401	.3340	.2961	.3490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 201 / 11 KV Kowad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1155	.1111	.1412	2.139	.9025	.7265
2	.1294	.1156	.1109	.1408	2.1308	1.2953	1.2112
3	.1296	.1158	.1081	.1408	2.0742	1.319	1.223
4	.1284	.1156	.1102	.1416	2.033	1.2866	.7754
5	.1331	.1212	.1111	.1419	2.0317	1.2875	.6964
6	.1314	.1217	.1139	.1452	.1294	1.2578	.6893
7	.1186	.1151	.1025	.1284	.1212	1.2882	1.1708
8	.3104	.281	.2746	.1179	.1292	1.3169	1.3685
9	3.0066	3.075	3.0264	.125	.1158	.7606	.6817
10	3.1149	3.2048	1.6129	.1313	.1151	.0975	.081
11	2.898	3.1991	2.9822	.1265	.1111	.0957	.0815
12	3.0486	3.0432	2.9062	2.7293	.1025	.0945	.081
13	2.9927	1.3234	2.8347	2.892	.0974	.0929	.0737
14	2.952		2.8592	2.785	.0966	.0876	.0764
15	2.9518		2.8363	2.9743	.0966	.0815	.0817
16	3.0021	2.7444	2.7387	2.7926	.1017	.0848	.0831
17	.0812	2.8309	.2288	2.3803	.1031	.0789	.0867
18	.0825	2.7876	.0996	2.3605	.0547	.0783	.0507
19	.1166	.1174	.1078	.1349	.1185	.0851	.0777
20	.1248	.1263	.1265	.1396	.1231	.0945	.088
21	.1297	.1398	.1454	.2157	.1233	.1069	.0861
22	.1254	.1349	.1505	2.0932	.1212	.1073	.0884
23	.1248	.1257	.145	2.1104	.1198	.1057	.0867
24	.1035	.1246	.1438	1.1084	1.1465	.0919	.0798
Max	3.1149	3.2048	3.0264	2.9743	2.139	1.319	1.3685
Min	.0812	.1151	.0996	.1179	.0547	.0783	.0507
Avg	1.0860	1.0945	.9994	1.0915	.5640	.5041	.4061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 202 / 11 KV Talewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1409	.1661	.1474	.1692	3.1726	2.3815	2.3449
2	.1409	.1661	.1467	.1699	3.1512	2.3716	2.335
3	.1409	.1654	.1444	.1654	3.1192	2.3746	2.338
4	.1425	.1684	.1437	.1654	3.2	2.3739	2.3373
5	.1455	.1738	.1582	.176	3.1733	2.4211	2.3845
6	.1455	.1798	.1627	.1753	.1349	2.6398	2.6032
7	.144	.176	.1467	.1494	.1257	1.2673	2.6436
8	2.6848	3.0948	2.7583	.1684	.1014	1.3085	2.7617
9	6.7544	6.8245	5.7804	.1524	.0541	.0415	.423
10	6.5363	6.9594	3.2198	.1463	.0061	.0316	.0572
11	6.6026	6.8504	6.3588	1.1096			.0381
12	6.1385	6.5592	6.0745	5.7217			.0381
13	6.1843		6.0151	5.9054			.0381
14	6.1682		5.9663	6.3108			
15	6.1683	.3894	5.5098	6.2109			.0381
16	6.0174	6.1423	4.7348	4.0756			.0381
17	.1395	6.1241	.1482	3.9925	.125	.0869	.0381
18	.1402	5.4329	.1421	3.5299	.0907	.0907	
19	.1776	.1669	.1558	.144	.1555	.1174	.1516
20	.1837	.1684	.1634	.1463	.1356	.123	.1456
21	.1768	.1654	.173	1.6651	.0869	.125	.144
22	.1783	.1707	.1753	3.4157	.1212	.1212	.1372
23	.1707	.1684	.1745	3.4294	.1158	.1158	.1364
24	.1558	.1608	.1707	1.6888	1.7178	.1041	.1334
Max	6.7544	6.9594	6.3588	6.3108	3.2	2.6398	2.7617
Min	.1395	.1608	.1421	.144	.0061	.0316	.0381
Avg	2.3157	2.2988	2.0321	2.0410	1.0437	1.0053	.9684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 203 / 11 KV Batakanangle Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.7826	6.4677	.5151	6.1644	.6462	.5236	.49
2	5.7361	6.3283	.5083	6.1065	.6454	.5198	.4732
3	5.6447	6.2254	5.6226	6.0257	.6447	.5167	.4709
4	5.6736	6.2475	5.6973	6.0204	.6432	.516	.4717
5	5.8367	6.2886	5.8017	6.0334	.6432	.5289	.4725
6	6.3748	6.547	1.5642	6.2582	.6546	.5335	.4847
7	6.4525	6.5241	5.8825	6.3519	.6424	.5274	.4862
8	.5997	1.012	.4474	1.3687	.6287	.3513	.5715
9	.5411	.5631	.4599	.6424	2.7016	3.9399	2.0523
10	.5068	.567	.2507	.5708	2.889	5.5761	2.899
11	.4702	.346	.3856	.5449	7.2565	5.6927	2.8059
12	.4603	.2606	.3879	.5235	7.2855	5.9099	2.9691
13	.4328	.2286	.3879	.4725	7.0424	6.0928	4.8514
14	.4427	.2271	.3681	.4626	6.6819	5.7194	5.0717
15	.3147	.2263	.357	.4732	6.7018	3.1314	5.2576
16	.4267	.2423	.3849	.3848	6.3534		5.1639
17	.4481	.2347	.4462	.4786	2.9325	1.3507	2.8433
18	.4405	.2347	.4607	.6173		.3395	.2736
19	.4862	.5418	.453	.65	.506	.4576	.4275
20	.5289	.6561	.5136	.6744	.6234	.4637	.5037
21	.5144	1.1157	.5921	.6851	.6211	.586	.5083
22	6.5874	6.2795	6.028	.6767	.6249	.541	.4999
23	6.608	6.4738	6.4982	.6615	.6295	.4969	.551
24	6.0989	5.7613	3.5322	3.392	.6797	.4169	.5365
Max	6.608	6.547	6.4982	6.3519	7.2855	6.0928	5.2576
Min	.3147	.2263	.2507	.3848	.506	.3395	.2736
Avg	2.8087	2.9000	1.9810	2.3433	2.5512	1.9449	1.7140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 204 / 11 KV Talewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.4287	.4717	.3094	.4584	.4043	.4728
2	.3849	.4332	.4633	.4949	.4241	.383	.4488
3	.3826	.4306	.45	.5007	.4176	.3849	.4435
4	.3677	.4267	.4477	.498	.4115	.3803	.4374
5	.3746	.4325	.4473	.4869	.4104	.3776	.4309
6	.4599	.5007	.5117	.5327	.4881	.4359	.4904
7	.4656	.5353	.5601	.5628	.5445	.447	.5544
8	.5323	.6024	.5072	.5929	.5456	.5335	.5731
9	.5532	.5936	.5875	.5959	.5475	.5346	.591
10	.5517	.5776	.3052	.6264	.5285	.6074	.5811
11	.4607	.5201	.5449	.5586	.5471	.5628	.5487
12	.4401	.5491	.5228	.4214	.5163	.298	.4934
13	.4241	.5193	.5102	.3524	.4599	.5518	.4206
14	.4568	.5129	.5247	.3589	.4645	.5327	.402
15	.4709	.5132	.4603	.3711	.4808	.487	.3982
16	.4496	.4957	.2618	.1745	.2313	.245	.4058
17	.5662	.5452	.5289	.3403	.2534	.4698	.5441
18	.6893	.559	.5537	.4508	.2953	.4603	.3121
19	.836	.8748	.7933	.7251	.7205	.7781	.788
20	.9941	1.0292	.9545	.847	.7373	.9667	1.022
21	.8653	.9457	.8413	.8291	.7479	.8783	1.0037
22	.7041	.7479	.7003	.6721	.6283	.7278	.8916
23	.5742	.6123	.6047	.5445	.5148	.5677	.7639
24	.4805	.4591	.5129	.4633	.4664	.4375	.546
Max	.9941	1.0292	.9545	.847	.7479	.9667	1.022
Min	.3677	.4267	.2618	.1745	.2313	.245	.3121
Avg	.5365	.5769	.5444	.5129	.4933	.5188	.5651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 205 / 11 KV Kowad Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.243	1.5242	1.4175	1.5051	1.3908	1.3222	1.3718
2	1.153	1.4861	1.3794	1.4861	1.3337	1.3032	1.3146
3	1.134	1.467	1.3794	1.4861	1.3146	1.2841	1.2956
4	1.1149	1.448	1.3413	1.448	1.3146	1.2651	1.2956
5	1.121	1.448	1.3413	1.467	1.2956	.6287	1.3146
6	1.2566	1.5051	1.3984	1.5242	1.3908	1.3413	1.3908
7	1.3656	1.6385	1.5729	1.6004	1.5432	1.4365	1.6385
8	1.6004	1.6194	1.5455	1.6194	1.6194	1.611	1.7147
9	1.4861	1.6004	1.5592	1.7528	1.7147	1.5646	1.7909
10	1.4861	1.6194	.8383	1.7528	1.3526	1.7291	1.7909
11	1.448	1.7337	1.6735	1.7337	1.7147	1.701	1.6385
12	1.3908	1.448	1.6079	1.6385	1.5242	.9145	1.4099
13	1.3718	1.3908	1.5242	1.5432	1.467	1.6579	1.3718
14	1.3908	1.3908	1.4556	1.4861	1.4861	1.7814	1.5432
15	1.3718	1.3718	1.1226	1.5051	1.5623	1.2517	1.5813
16	1.3527	1.3146	1.4365	1.467	1.2193	.6759	1.5432
17	1.3527	1.4099	1.5401	1.5813	.7811	1.1946	1.5432
18	1.4099	1.6956	1.5401	1.829	.4382	1.6156	.8573
19	1.8861	2.0767	1.6956	1.9242	.9717	1.8271	2.1147
20	2.2481	2.6291	2.1781	2.21	.0381	2.2352	2.6291
21	2.3434	2.4005	2.2672	2.1148	1.3146	2.2291	2.591
22	2.1338	2.1529	2.0957	1.9624	1.6385	2.0767	2.3624
23	1.9433	1.829	1.829	1.6956	1.5432	1.6956	2.2481
24	1.4281	1.6385	1.6194	1.5242	1.4289	1.4365	1.6194
Max	2.3434	2.6291	2.2672	2.21	1.7147	2.2352	2.6291
Min	1.1149	1.3146	.8383	1.448	.0381	.6287	.8573
Avg	1.5013	1.6599	1.5566	1.6607	1.3082	1.4908	1.6655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 201 / 11 KV MAHAGAON VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5487	.4908	.6283	.5914	.5249	.5487
2	.4805	.4938	.5121	.5853	.5729	.5068	.5415
3	.4481	.4344	.5068	.543	.5487	.4887	.5359
4	.4854	.5093	.5121	.5175	.5487	.5249	.5487
5	.5304	.5373	.5249	.543	.5792	.5487	.5373
6	.6036	.5914	.5373	.6653	.543	.5731	.5373
7	.6602	.6161	.6219	.6219	.567	.6516	.5973
8	.6224	.6161	.5792	.5487	.547	.6584	.5914
9	.5304	.5792	.6036	.6283	.6036	.6516	.5601
10	.5914	.6036		.5853	.6535	.6335	.679
11	.5121	.6335	.6535	.6219	.6535	.5959	.6036
12	.4887	.6161	.6224	.4938	.6413	.6154	.5658
13	.5249	.6224	.5788	.6099	.5853	.6878	.5729
14	.5258	.6036	.5658	.5914	.6468	.6516	.5611
15	.5304	.5228	.5415	.5175	.5853	.5434	.5544
16	.543	.5601	.6036	.5544	.5359		.5847
17	.543	.5847	.5601	.5914	.5121	.5249	.5847
18	.5304	.5975		.7023	.5853	.5434	.6348
19	.6984	.6979	.7655	.7392	.6661	.6661	.7356
20	.8962	.9619	.8962	.7577	.7602	.6135	.9522
21	.8029	.8501	.8413	.7682	.7059	.6154	.8402
22	.7655	.7577	.7762	.7682	.6516	.591	.7783
23	.679	.6653	.7316	.695	.6268	.5784	.679
24	.5788	.5792	.5359	.695	.6219	.5973	.567
Max	.8962	.9619	.8962	.7682	.7602	.6878	.9522
Min	.4481	.4344	.4908	.4938	.5121	.4887	.5359
Avg	.5867	.6159	.6164	.6239	.6055	.5907	.6205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 203 / 11 KV Mahagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5927	1.6278	.1494	1.286	.1595	.0358	.1646
2	1.5729	1.5684	.1509	1.3146	.1578	.181	.168
3	1.5339	1.4815	1.0974	1.3466	.1402	.1629	.1509
4	1.5893	1.5203	1.1088	1.3321	.1402	.1629	.1646
5	1.6617	1.5746	1.134	1.3496	.1595	.1753	.168
6	1.7551	1.7164	.1848	1.3466	.1578	.1991	.1848
7	1.8111	1.7558	1.363	1.0631	.1578	.2103	.2054
8	.1448	.1848	.2218	.1753	.1848	.1991	
9	.1753	.1991	.1848	.1753	1.6834	1.6108	
10	.1753	.1791		.1753	1.9791	1.5927	1.5927
11	.1402	.181	.2033	.1928	2.0513	1.5074	1.5524
12	.1629	.1829	.1829	.1715	1.7558	1.4723	1.5402
13	.1791	.128	.1307	.1372	1.6126	1.4022	1.5912
14	.1791	.1463	.1509	.0312	1.5424	1.4118	1.4632
15	.1991	.1294	.128	.12	1.4373	1.4022	1.4175
16	.181	.1478	.1463	.1543	1.4022	1.0136	1.5364
17	.1991	.1478	.1463	.1543	.124	.1267	.1829
18	.1991	.1646		.1543	.1402	.1629	.1886
19	.2353	.1848	.1791	.1886	.1578	.1578	.1949
20	.2402	.2195	.2126	.2058	.1629	.2172	.2452
21	.2614	.1886	.2103	.2103	.181	.1991	.2149
22	1.7002	1.1831	1.262	.1753	.181	.1753	.2452
23	1.7551	1.2689	1.3321	.1753	.1612	.181	.2195
24	1.6617	1.6827	.1372	1.3496	.1578	.1629	.1829
Max	1.8111	1.7558	1.363	1.3496	2.0513	1.6108	1.5927
Min	.1402	.128	.128	.0312	.124	.0358	.1509
Avg	.8044	.7401	.4553	.5410	.6662	.5884	.617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 205 / 11 KV Nadighat Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0838	.0328	.0671	.0328	.0339	.0328
2	.0686	.0686	.0335	.0655	.0335	.0362	.0332
3	.0693	.0701	.0655	.0655	.0328	.0351	.0354
4	.0671	.0686	.0678	.0671	.0328	.0343	.0335
5	.0848	.0867	.0686	.0671	.0328	.0343	.0343
6	.0857	.1029	.0328	.0655	.0335	.0335	.0335
7	.0819	.1147	.0655	.0671	.0328	.0339	.0343
8	.0328	.0343	.0335	.0335	.0351	.0339	
9	.0335	.0335	.032	.0328	.0671	.0339	.0693
10	.0335	.0339		.0335	.0819	.0335	.0709
11	.0335	.0339	.0335	.0328	.0829	.0678	.0701
12	.0335	.0343	.0335	.0312	.0838	.0724	.0701
13	.0335	.0343	.0332	.0312	.0838	.0678	.0709
14	.0332	.0335	.0335	.0312	.0655	.0671	.0701
15	.0332	.0343	.032	.0312	.0671	.0671	.0671
16	.0332	.0335		.0312	.0655	.0686	.0701
17	.0335	.0328	.0328	.0312	.0335	.0335	.0351
18	.0335	.0328	.0328		.0335	.0335	.0343
19	.0335	.0335	.0332	.0312	.0332	.0339	.0335
20	.0343	.0328	.0335	.0312	.0335	.0343	.0335
21	.0335	.0312	.0335	.0335	.0335	.0339	.0339
22	.0857	.0469	.0671	.0335	.0335	.0339	.0343
23	.0686	.0469	.0671	.0335	.0332	.0343	.0347
24	.0671	.0819	.0312	.0671	.0335	.0335	.0343
Max	.0857	.1147	.0686	.0671	.0838	.0724	.0709
Min	.0328	.0312	.0312	.0312	.0328	.0335	.0328
Avg	.0506	.0517	.0422	.0441	.0471	.0427	.0465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144112 / 33/11 Kv Nangnur

Feeder No / Name : 203 / Khandal Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.0869		.1337	.032	.0301	.0328
2	.0934	.0892		.1219	.032	.0297	.0332
3	.0934	.0914	.1303	.1235	.032	.029	.0339
4	.1097	.0914	.1286	.1355	.032	.0293	.0343
5	.1235	.0892	.1429	.1524	.032	.0278	.0343
6	.141	.132		.1932	.032	.0301	.0351
7	.1692	.2286	.3102	.2027	.032	.0274	.0351
8	.0301	.0312	.0328	.0301	.032	.0267	.0328
9	.032	.0305	.0179	.0271	.3201	.2256	
10	.0149	.0156	.0335	.0309	.3384	.2317	
11	.0152	.0162	.017	.0328	.2364	.2027	.2429
12		.0149	.0168	.0305	.2	.1623	.2397
13		.04	.0168	.0293	.1278	.1082	.1858
14		.0274	.0335	.0332	.1115	.0934	.1551
15		.0263	.0316		.1183	.0834	.1391
16		.0154	.0267		.088		.1269
17		.0147	.0282		.0255	.024	
18	.0305	.0412	.0274		.0236	.0251	
19	.0328	.0324	.029				
20	.0343	.0328	.032		.0412		
21	.0343	.0335	.0309	.0514	.0429		
22	.1448	.1829	.2675	.0335	.0423	.0316	
23	.1337	.1372	.1957	.0324	.0412	.0282	.0305
24	.0777	.1189		.1286	.0324	.029	.0271
Max	.1692	.2286	.3102	.2027	.3384	.2317	.2429
Min	.0149	.0147	.0168	.0271	.0236	.024	.0271
Avg	.0773	.0675	.0775	.0846	.0889	.0738	.0887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 201 / YADRAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6222	3.0483	3.4675	3.4294	3.0483		3.4294
2		3.0483	3.4294	3.4294	3.0483		3.4294
3		2.6673	3.4294	3.4294	2.8578		3.0483
4		2.6673		3.4294	2.8578		3.0483
5	3.4728	2.6673		3.4294	3.0483		3.0483
6	3.4705	3.0483		3.4294	3.0483		3.4294
7	3.3608	3.0483	3.5056	3.4294			3.4294
8	2.6139	3.0483	3.5437	3.4294	3.0483		3.4294
9	2.6673	3.8104	4.1152	4.1914		3.3981	3.8104
10	2.6673	3.8866	4.1495	3.7342		3.3608	3.6199
11		4.1152	1.4937	3.9209		3.7342	4.1914
12		3.4294					3.8866
13		2.934	2.6406	2.6139			3.8104
14	2.5911	3.4294	3.3608	3.3608			3.4675
15	2.5149	4.0009	3.8104	3.7342		3.8089	3.8104
16	2.5149	4.039	3.9628	2.9874		3.8477	3.8866
17	2.4768	4.0009	3.8104	3.7342		3.9628	3.8104
18	2.2862	1.9433	3.8104			3.8104	3.8104
19	2.2862	3.8104	3.9628				3.9628
20	2.6673	3.4294	3.4294				
21	3.0483	3.2388	3.8104			3.0483	
22	3.0483	3.8104	3.8104			3.4294	3.8104
23	3.0483		3.8104			3.4294	3.8104
24	3.8104	3.0483	3.8104	3.8104	3.0483	2.6139	3.4294
Max	3.8104	4.1152	4.1495	4.1914	3.0483	3.9628	4.1914
Min	2.2862	1.9433	1.4937	2.6139	2.8578	2.6139	3.0483
Avg	2.8982	3.3117	3.5582	3.5013	3.0007	3.4949	3.6095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 203 / ARUNDATHI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	.9145	1.448	1.3336	1.1431		1.5242
2		.7621	1.3717	1.1431	1.1431		1.5242
3		.5716	1.3336	1.1431	.9526		1.5242
4		.5716		1.1431	.9526		1.3336
5	1.1949	.5716		1.1431	.9526		1.3336
6	.9335	.7621		1.1431	.9526		1.1431
7	.9335	.7621	1.2955	1.1431			1.1431
8	.6348	.8764	1.2574	1.1431	.9526		1.1431
9	.6097	1.2193	1.5623	1.3336		1.1949	1.3336
10	.5716	1.6004	1.5844	1.4937		1.3817	1.3717
11	.5716	1.6385	1.4937	1.4937		1.5089	
12	.6478	1.3336					
13	.5716	1.105	1.1317			1.1694	
14	.5716	1.3336	1.307	1.307			
15	.6097	1.6004	1.5242	1.307		1.3957	
16	.6097	1.5623	1.3717	.9808		1.3203	
17	.6478	1.5242	1.4098	1.3817			
18	.7621	1.448	1.3336				
19	.7621	1.4861	1.5242				
20	.7621	1.3336	1.3336			.7621	
21	.7621	1.2193	1.3336			.7621	1.5242
22	.7621	1.4098	1.5242			1.3336	1.5242
23	.7621		1.5242			1.3336	1.5242
24	1.5242	.9145	1.5242		1.1431	1.307	1.5242
Max	1.5242	1.6385	1.5844	1.4937	1.1431	1.5089	1.5242
Min	.5716	.5716	1.1317	.9808	.9526	.7621	1.1431
Avg	.7934	1.1531	1.4094	1.2422	1.0240	1.2245	1.3908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 204 / SPM

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.1431	1.5242	1.3336	1.5242		1.7147
2		1.1431	1.5623	1.3336	1.5242		1.7147
3		1.1431	1.5242	1.3336	1.5242		1.7147
4		1.1431		1.3336	1.3336		1.5242
5	1.358	1.3336		1.3336	1.3336		1.5242
6	1.307	1.3336		1.448	1.5242		1.5242
7	1.307	1.3336	1.448	1.5242			1.5242
8	.7842	1.3336	1.448	1.5242	1.5242		1.7147
9	.8383	1.5242	1.5242	1.7147		1.6598	1.7147
10	.9526	1.6004	1.4937	1.4937		1.6598	
11		1.7528	1.5089	1.4937		1.6804	
12		1.5242				1.5089	
13		1.448	1.6385	1.531		1.5089	
14	.8383	1.6766	1.6057	1.6804		1.5466	
15	.8764	1.7147	1.5242			1.6804	
16	.8383	1.7147	1.4098	1.3203		1.5089	
17	.8383	1.6004	1.4098	1.5684		1.6004	
18	.7621	1.5242	1.5242			1.7147	
19	.9526	1.6385	1.5242				
20	.9526	1.5242	1.5242			1.1431	
21	1.1431	1.5623	1.5242			1.1431	
22	1.1431	1.6004	1.5242			1.7147	1.7147
23	1.1431		1.5242			1.7147	1.7147
24	1.5623	1.1431	1.5623	1.5242	1.5242	1.6057	1.7147
Max	1.5623	1.7528	1.6385	1.7147	1.5242	1.7147	1.7147
Min	.7621	1.1431	1.4098	1.3203	1.3336	1.1431	1.5242
Avg	1.0606	1.4546	1.5165	1.4682	1.4766	1.5593	1.6512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 205 / PADMAJA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.773	.8383	1.7909	1.7528	1.2955		1.5242
2		.8002	1.7909	1.6004	1.2574		1.5242
3		.724	1.7528	1.6004	1.2574		1.5623
4		.724		1.6385	1.3336		1.5623
5	1.5684	.8002		1.6385	1.4098		1.6004
6	1.531	.8764		1.6004	1.5242		1.6385
7	1.358	.9145	1.6004	1.6766	1.5242		1.6385
8	.8048	1.0669	1.6385	1.6766	1.3717		1.6385
9	.7621	1.6385	1.9814	1.9052		1.8671	1.9052
10	.8383	1.7909	1.9616	1.8671		1.9418	
11	.6668	1.9052	1.9993	2.1658		1.8861	
12	.8383	1.8671					
13	.7621	1.829	1.8484	1.9044		1.9044	
14	.7621	1.9052	1.9052	2.2032			
15	.7621	2.0957	1.9433			1.8298	
16	.8002	2.0957	1.9052	2.1285		1.8671	
17	.8002	2.0576	1.7909			1.9433	
18	.6859	1.9814	1.6004			2.0957	
19	.6859	1.6766	1.6004				
20	.724	1.5242	1.6766			1.2955	
21	.8764	1.5242	1.7528			1.2574	
22	.8383	1.6004	1.829			1.5242	1.6766
23	.8383		1.9052			1.5242	1.6385
24	1.829	.8383	1.829	1.9052	1.2955		1.5242
Max	1.829	2.0957	1.9993	2.2032	1.5242	2.0957	1.9052
Min	.6668	.724	1.6004	1.6004	1.2574	1.2574	1.5242
Avg	.9764	1.4380	1.8051	1.8176	1.3633	1.7447	1.6195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 206 / 11 kV YADRAV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.421			
5	.5182			
6	.6478			
7	.6554			.0762
9		.9374	.8913	.7499
10		.8848		.7125
11		.7865		.583
12		.6882		
13				.4534
14			.679	.3887
15			.6874	
16		.5505	.6249	.3887
17		.5276	.5624	
18		.4915	.4374	
19		.1143		
20		.1257		
24	.4374			
Max	.6554	.9374	.8913	.7499
Min	.421	.1143	.4374	.0762
Avg	.5360	.5674	.6471	.4789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 207 / TARDAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182				
5	.8192				
7	.8421				
9		1.1142	1.0683	1.0814	
10		1.1797		1.0364	
11		1.0093		.9069	
12		1.0159			
13				.6478	
14			.852		
15			.852		
16		.7865	.7865	.6554	
17		.7603	.7209		
18		.6554	.6882		
24	.4744				.1134
Max	.8421	1.1797	1.0683	1.0814	.1134
Min	.4744	.6554	.6882	.6478	.1134
Avg	.6635	.9316	.8280	.8656	.1134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 402 / SUNIL INDUSTRIES
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.4572	.5716	.4572	.4572		.4572
2		.4572	.5716	.4572	.4572		.4572
3		.4572	.5716	.4572	.4572		.4572
4		.4572		.4572	.5716		.4572
5	.6161	.4572		.5716	.5716		.4572
6	.6161	.4572		.5716	.5716		.4572
7	.5093	.5144	.5716	.5716			.4572
8	1.2323	.5716	.5716	.5716	.5716		.5144
9	.3429	.5716	.5716	.5716		.5601	.5144
10	.3429	.5716	.6161	.5041		.5041	.5144
11	.3429	.5716	.6161	.5041		.4481	.5144
12	.4001	.5716					.4572
13	.3429	.5716	.5093	.3921		.5093	.4572
14	.4001	.5716	.5601	.4481			.4001
15	.4001	.5716	.3429	.3921		.6161	.5144
16	.4001	.5716	.4001	.3361		2.6886	.6287
17	.4001	.5716	.6287			.5144	.5716
18		.5716	.5716			.4572	.5144
19	.4572	.5716	.5716			.4572	.5716
20	.4572	.6287	.5716			.5144	
21	.4572	.5716	.5716			.4572	
22	.5716	.5716	.4572			.4572	.5144
23	.4572		.4572			.4572	.5716
24	.6859	.4572	.5716	.4572	.5144	.3921	.4572
Max	1.2323	.6287	.6287	.5716	.5716	2.6886	.6287
Min	.3429	.4572	.3429	.3361	.4572	.3921	.4001
Avg	.5024	.5368	.5438	.4825	.5216	.6452	.4962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 703 / 33 KV Main VCB

SHEDDABLE RURAL

Feeder KV- 33 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3951	1.4861	2.7435	2.4006			2.0576
2		1.4861	2.6292	2.2862			2.0576
3		1.3717	2.6292	2.2862			2.0576
4		1.3717		2.2862			2.0576
5	3.6969	1.3717		2.2862			2.1719
6	3.8089	1.4861		2.2862			2.1719
7	3.6969	1.7147	2.4006	2.4006			2.0576
8		1.829	2.5149	2.5149			2.1719
9	2.0576	4.6868	4.9154	4.6868		2.4897	2.4006
10	1.3717	4.8011	3.4728	4.5931		2.6886	2.6292
11	1.1431	4.5725	2.6886	4.481		2.6886	2.7435
12	1.4861	4.4582					2.6292
13	1.3717	2.4006	2.8006	3.3608		2.3525	2.1719
14	1.4861	2.5149	4.4582	3.9209			2.4006
15	1.4861	2.7435	4.4582	3.8089		2.8292	2.9721
16	1.4861	4.2295	4.2295	3.9209		2.7161	2.8578
17	1.4861	4.2295	3.8866			2.2862	2.4006
18	1.2574	3.8866	3.5437			2.5149	2.2862
19	1.3717	2.6292	2.4006				2.2862
20	1.4861	2.6292	2.6292			1.829	
21	1.7147	2.5149	2.6292			1.7147	
22	1.7147	2.6292				1.9433	2.4006
23	1.6004		2.6292			2.0576	2.5149
24	3.658	1.4861	2.7435	2.6292	1.829	2.1502	2.0576
Max	3.8089	4.8011	4.9154	4.6868	1.829	2.8292	2.9721
Min	1.1431	1.3717	2.4006	2.2862	1.829	1.7147	2.0576
Avg	2.0388	2.7186	3.1791	3.1343	1.829	2.3277	2.3434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 201 / LAXMI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 202 / MANIK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17
HR	Load (MW)
24	2.7625
Max	2.7625
Min	2.7625
Avg	2.7625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 402 / 33 KV LIE

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17
HR	Load (MW)
24	3.1436
Max	3.1436
Min	3.1436
Avg	3.1436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 201 / SAJANI FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.415	.4854	.6413	.4854		.3361
2	.5658	.3772	.4854	.6413	.4481		.3361
3	.5601	.3772	.5041	.6036	.4527		.3395
4	.5658	.3584	.5041	.6036	.4481	.3584	.3361
5	.5658	.3772	.5093	.6036	.5093		.3395
6	.5281	.4338		.5847	.5041	.3961	.3584
7	.5228	.4715	.5415	.6413	.5281	.4108	.3772
8	.3174	.3772	.4904	.5847	.5281	.4108	.3361
9	.2801	.5228	.5847	.6224	.5658	.4108	.3361
10	.2452	.4854	.6979		.5847	.4294	
11	.2263	.5041	.6224	.5975	.6036	.4854	
12	.2263	.4108	.6036	.5415	.415	.415	
13	.2263	.4108	.5658	.4108			
14	.2641	.5601	.5281	.5228		.4715	
15	.2829	.4854	.547	.5228		.5415	
16	.3206	.4481	.5658			.5975	
17	.3395	.4854	.6036	.4854			
18	.3206	.4854	.5847	.547			
19	.4904	.6224	.6413				
20	.5658	.5658	.679	.5093			
21	.5281	.6535		.4904		.4108	
22	.5281	.5601	.679	.5228		.3772	
23	.4527	.5788		.5281		.3361	.5847
24	.5415	.415	.4668	.6413	.5041	.415	.3361
Max	.5658	.6535	.6979	.6413	.6036	.5975	.5847
Min	.2263	.3584	.4668	.4108	.415	.3361	.3361
Avg	.4177	.4742	.5662	.5641	.5059	.4311	.3651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 203 / PANCHAGANGA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.5281	.5228	.7167	.5544	.415	.168
2	.5975	.5281	.5041	.6979	.5228	.3584	.168
3	.5975	.5281	.5041	.7167	.5228	.3772	.168
4	.5975	.5281	.5041	.7167	.5228		.168
5	.5975	.5853	.5658	.7922	.5228		.168
6	.5601	.8865	.8029	.8865	.8589		.1867
7	.5788	.9054	.7095		.6908		.1867
8		.9431	.5847	1.0185	.7468		.1494
9		.9709	.7545	1.0374	.7655		.2614
10		1.0456	.8299	.9979	.7545		
11		.8589	.8299	.9522	.8299		
12	.3395	.9896	.7922	.8962	.6036		
13	.3206	.8215	.7922	.8589			
14	.4527	.9896	.679	.9795			
15	.4527	.9709	.8299	1.0164		.6161	
16	.5093	.9522	.811	.9522		.5975	
17	.5281	.8962	.8299	.8215			
18	.5281	.8962	.7922				
19	.6979	1.0642	.9431				
20	.7356	1.0829	.9431	.5975			
21	.7545	.8589	.9431	.6283			
22	.7356	.8215	.8299	.6348			
23	.6413	.5975		.5975		.1494	.8299
24	.7655	.6036	.5788	.6602	.5975	.4527	.168
Max	.7655	1.0829	.9431	1.0374	.8589	.6161	.8299
Min	.3206	.5281	.5041	.5975	.5228	.1494	.1494
Avg	.5813	.8272	.7338	.8179	.6533	.4238	.2384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 204 / RUI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.57	.8288	.1006	.7293			
2	.57	.7377	.0838	.6299			
3	.57	.7377	.5365	.5967			
4	.57	.7377	.57	.5967		.1132	
5	.6133	.7956	.1174	.663		.116	
6	.8215	.9054	.116	.8453		.0995	
7	.7712	.8619	.8288	.8453		.0838	
8	.116	.0995	.0829	.6299		.0503	
9	.1174	.1006	.0995	.5967	.5868	.2515	
10	.1326	.1006	.0995	.5365	.7127	.3018	
11	.116	.116	.116	.1174	.7625	.3353	
12	.116	.1006	.1326	.1006	.6464	.3521	
13	.1174	.1006	.1326	.0995			
14	.1174	.1174	.1326	.0838		.3647	
15	.1174	.1006	.1326	.0983		.3441	
16	.1174	.1006	.1326	.0972		.4024	
17	.1174	.0838	.1326	.0838			
18	.1174	.1006	.0995	.1174			
19	.1174	.1006	.1326				
20	.1174	.1174					
21	.1341	.0671	.1326				
22	.9614	.9389	.8951				
23	.9614	.8785					.2818
24	.5868	.8288	.1006	.779			
Max	.9614	.9389	.8951	.8453	.7625	.4024	.2818
Min	.116	.0671	.0829	.0838	.5868	.0503	.2818
Avg	.3611	.4024	.2230	.4340	.6771	.2346	.2818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 205 / MANGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2801	.2614	.2427	.2801	.2054	.1867
2	.2614	.2241	.2614	.2427	.2614	.2054	.1867
3	.2614	.2241	.2614	.2427	.2614	.2054	.1867
4	.2614	.2241	.2614	.2427	.2614	.2054	.1867
5	.2987	.2241	.2801	.2427	.2987	.2054	.2054
6	.2614	.2801	.2801	.2427	.2801	.2054	.2241
7	.2054	.2614	.2614	.2427	.2801	.2054	.2241
8	.2241	.2241	.2427	.2427	.2614	.168	.1867
9	.2054	.2427	.2427	.2614	.2614	.1494	.168
10	.2241	.2427	.2427	.2614	.1867	.1867	
11	.2054	.2614	.2427	.2614	.2241	.168	
12	.2241	.2614	.2614	.2614	.2614	.2054	
13	.2614	.2614	.2614	.2987			
14	.2801	.2801	.2614	.2801		.2427	
15	.2801	.2987	.2427	.2614		.2241	
16	.2427	.2987	.2427	.2614		.2054	
17	.2427	.2987	.2614	.2801			
18	.2241	.2987	.2801	.3361			
19	.3921	.3734	.3174				
20		.4294	.3361	.4108			
21	.3734	.4108	.3361	.3921		.3361	
22	.3734	.3547	.3174	.3547		.2801	
23	.3174	.3174		.3174		.2427	.2801
24	.2614	.2801	.2801	.2427	.2987	.2054	.2054
Max	.3921	.4294	.3361	.4108	.2987	.3361	.2801
Min	.2054	.2241	.2427	.2427	.1867	.1494	.168
Avg	.2671	.2855	.2711	.2792	.2628	.2133	.2037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 206 / 11 KV MANGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9605	1.8442	.0514	1.7436	.0343		
2	1.7147	1.8442	.0343	1.7101	.0343		
3	1.6804	1.8442	1.9418	1.7101	.0343		
4	1.6804	1.8442	1.9418	1.7101	.0343		
5	1.6804	1.8442	.052	1.7101	.0339		
6	1.7318	1.8945	.052	1.7101	.0343		
7	1.7661	1.8945	1.8298	1.7101	.0343		
8	.0343	.0335	.0335	1.6933	.0343		
9	.0343	.0343	.0335	1.7939	1.8347		
10	.0335	.0343	.0335	1.9071	2.0287		
11		.0343	.0335		2.079	1.3375	
12	.0335	.0343	.0335		1.8442		
13	.0335	.0343	.0335			1.4746	
14	.0335	.0343	.0335	.0343		1.4746	
15	.0335		.0335	.0339		1.4575	
16	.0335	.0343	.0335	.0343		1.4575	
17	.0335	.0343	.0335	.0343			
18	.0335		.0335	.0343			
19	.0335	.0343	.0335				
20	.0335	.0343	.0335	.0343			
21	.0335	.0343	.0335	.0343			
22	1.9951	2.1091	1.7939	.0339			
23	1.9448	2.1434		.0373			1.1401
24	1.8004	1.9448	.0514	1.7604	.0343	.0168	
Max	1.9951	2.1434	1.9418	1.9071	2.079	1.4746	1.1401
Min	.0335	.0335	.0335	.0339	.0339	.0168	1.1401
Avg	.7996	.8917	.3573	.9735	.6227	1.2031	1.1401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 207 / 11 KV Laxmi AG. (Sajani) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5937	.8192	.0625	.7865	.0781		
2	.5937	.7956	.0625	.6554	.0791		
3	.5937	.7956	.6562	.639	.0781		
4	.6249	.7956	.6874	.6554	.0937		
5	.6706	.8619	.0625	.7209	.1094		
6	.9374	1.094	.0937	1.1305	.1094		
7	.9374	1.1437	1.1561	1.1469	.0937		
8	.0937	.0995	.1147	.852	.0937		
9	.0781	.0937	.1326	.8122	.953	.6874	
10	.0995	.0781	.1311	.7186	1.1633	.7499	
11	.0995	.0781	.1326		1.1797	.7186	
12	.0995	.0781	.1311		1.2125	.7968	
13	.0995	.0781	.1147			.6718	
14	.0995	.0625	.1147	.0486			
15	.0995	.0781	.1147	.1296			
16	.0995	.0625	.1147	.1094			
17	.0995	.0625	.116	.0937			
18	.0995	.0937	.0995	.0937			
19	.0663	.0781	.1326				
20	.0663	.0781	.1326	.0937			
21	.0671	.0781	.1326	.1094			
22	.9831	1.078	1.1469	.1107			
23	.9282	.9998		.0937			.3978
24	.6249	.8619	.0469	.8951	.0937		
Max	.9831	1.1437	1.1561	1.1469	1.2125	.7968	.3978
Min	.0663	.0625	.0469	.0486	.0781	.6718	.3978
Avg	.3648	.4310	.2473	.4948	.4106	.7249	.3978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 208 / 11 KV Gomtesh Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1886	.1867	.2075	.1867		.112
2	.1867	.1886	.1867		.1867		.112
3	.1867	.1886	.1867		.1867		.112
4	.1867	.1886	.1867	.132	.1886		.112
5	.1867	.1886	.1867	.132	.1867		.112
6	.1867	.1886	.2054	.132	.1867		.112
7	.2054	.1886	.2054	.132	.1867		.1307
8	.1867	.1886	.2075	.1509	.1867		.1307
9	.2054	.2801	.2075		.2614		.1494
10	.3018	.4108	.2641	.4458	.4715		
11	.3018	.4854	.4527	.4481	.4527		
12	.3018	.4294	.3772	.4481	.3772		
13	.2829	.4108	.3772	.3326			
14	.2075	.3921	.3206	.2614			
15	.2263	.3361	.2641	.0747			
16	.2075	.2427	.2641	.2614			
17	.2075	.2054	.2641	.2614			
18	.2075	.2054	.2263	.2957			
19	.2263	.2241	.2641				
20	.2452	.2054	.2829	.2054			
21	.2075	.1867	.2829	.1867		.1307	
22	.2075	.1867	.2263	.1867		.1307	
23	.2075	.1867		.1848		.112	.1698
24	.1867	.1886	.1867	.2075	.1867		.112
Max	.3018	.4854	.4527	.4481	.4715	.1307	.1698
Min	.1867	.1867	.1867	.0747	.1867	.112	.112
Avg	.2185	.2536	.2527	.2343	.2496	.1245	.1241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 401 / 33 KV Mangaon Outgoing
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8477	2.2634	4.1872	4.5833	4.0741	4.4702	3.9609
2	3.7346	2.2634	4.1307	4.0175	3.9609	3.7346	4.0741
3	3.7346	2.2634	4.357	3.5082	4.0741	3.7346	4.0741
4	3.6214	2.1502	4.3004	3.9043	3.9609	3.7346	3.9609
5	3.5648	2.1502	4.2438	3.9609	3.9609	3.7912	3.9609
6	3.9609	2.1502	3.5082	3.9043	4.0175	4.1307	4.1872
7	3.6214	2.1502	3.678	4.2438	4.0741	3.678	4.4136
8	2.2634	2.9424	3.7912	4.3004	3.9609	4.3004	4.0741
9	2.2068	3.5082	3.6214	3.8477	4.2438	3.7346	3.9609
10	2.1502	4.4702	4.357	4.5268	4.0741	4.357	
11	2.3765	4.1872	4.4136	3.8866	4.1872	4.4136	
12	2.2634	3.6214	4.1872	4.357	4.4136	4.4702	
13	2.2068	4.1872	3.9043	4.357		3.7346	
14	2.2634	4.4136	3.8477	3.7346		3.678	
15	2.2634	4.6399	3.678	3.7346			
16	2.2634	4.8097	3.8477	3.8477		4.4136	
17	2.1502	4.3004	4.2438	3.7912			
18	2.037	4.5268	4.1872	4.2438			
19	2.037	4.0175	4.4702				
20	2.0936	4.2438	4.357	3.6214			
21	2.2068	4.357	4.357	4.3004		4.0175	
22	2.2068	4.2438	4.2438	4.3004		3.9609	
23	2.2634	3.9609		4.5268		3.9609	4.2438
24	3.7346	2.2634	4.4702	4.5268	4.357	4.5268	3.678
Max	3.9609	4.8097	4.4702	4.5833	4.4136	4.5268	4.4136
Min	2.037	2.1502	3.5082	3.5082	3.9609	3.678	3.678
Avg	2.7113	3.5035	4.1036	4.0881	4.1045	4.0443	4.0535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 201 / PUJARI MALA AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7072	1.6484	.064	.08	.08	.08	1.5813
2	1.7661	1.6518	.0648	.08	.08	.08	1.5203
3	1.7661	1.6518	.064	.08	.08	.08	1.5844
4	1.7661	1.668	.064	.08	.08	.08	1.6194
5	1.8004	1.704	.08	.08	.08	.08	1.6194
6	1.8519	1.7004		.0791	.08	.08	1.6804
7	1.8347	1.7124	.08	.0762	.08	.08	1.8107
8	.0857		.08	.0762	.08	.08	1.7194
9	.0867	.0667	2.0083	2.2119	1.8785	1.8404	.08
10	.104	.0857		2.0576	2.0005	1.8244	.08
11	.1052				2.0485	1.7318	.08
12	.1052	.0857		2.0748	2.0005	1.8176	.08
13	.1052		2.0485	1.8861	1.9757	1.8861	.08
14	.104		2.0805	1.7147	1.8976	1.8861	.08
15	.1029		1.9524	1.7661	1.8027	1.8861	.08
16	.1029	.0762	2.0243	1.7147	1.8435		.0762
17	.104	.08	1.5729		.08	.0857	.0857
18	.104	.08	1.6518	.0857		.0857	.0762
19	.1214	.081	.104				.0762
20	.1029	.08	.096	.0857		.0953	.0762
21	.104	.08	.096	.0667	.08	.0857	.0857
22	1.6644	.08		.0762	.08	.0953	.0762
23	1.7328	.08	.08	.0762	.08	.0857	.0762
24	1.6842	1.668	.081	.08	.08	.08	.0857
Max	1.8519	1.7124	2.0805	2.2119	2.0485	1.8861	1.8107
Min	.0857	.0667	.064	.0667	.08	.08	.0762
Avg	.7922	.7516	.7522	.6918	.7851	.6421	.6004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 202 / 11Kv Ganpati Mandir AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1012	.9175	
2				1.1012	.9069	
3				.9667	.9175	
4				.9503	.9175	
5				.9717	.9175	
6				1.0631		
7				1.046		
9		1.3717	1.3599			1.0159
10	1.3592	1.3717	1.3599			.8421
11	1.3757	1.4403	1.3763			.9503
12	1.326	1.3717	1.3441			.9831
13	1.3413					1.0322
14	1.3435		1.3927			1.004
15	1.326	1.3032	1.3592			1.0526
16	1.326	1.3032	1.2597			1.1145
17		1.326	1.1271			
18		1.2929				
22			1.1271	.9175		
23			1.1797	.9175		
24				1.1469	.9282	
Max	1.3757	1.4403	1.3927	1.1469	.9282	1.1145
Min	1.326	1.2929	1.1271	.9175	.9069	.8421
Avg	1.3425	1.3476	1.2886	1.0182	.9175	.9993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 203 / SHIRADWAD FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.6483	.583	.5376	.5121	.2229	.543
2	.5487	.6167	.5441	.5312	.5182	.2229	.5658
3	.5487	.578	.5121	.5441	.5121	.2401	.5658
4	.6173	.5693	.5182	.5281	.5243	.2401	.6097
5	.583	.5535	.5344	.5281	.5182	.2572	.6036
6	.4877	.5624	.5601	.5668	.5121	.2915	.6287
7	.583	.6241	.5851	.5487	.5761	.3048	.6413
8	.6859	.6516	.6562	.5944	.6401	.3353	.695
9	.6882	.823	.7099	.6706	.6401	.4877	.7362
10	.7125	.6859	.7499	.7545	.6478	***	.7116
11	.7537	.7545	.7716		.6241	.6097	.7362
12	.3681	.7545	.7499	.6859	.5506		.6562
13	.6274	.4801		.6859	.4049	.6859	.4481
14	.6062	.4801	.68	.6859	.4012	.6859	.5281
15	.6882	.7545	.7499	.7545	.5182	.6859	.6562
16	.6718	.6401	.7655	.823	.4938		.7202
17	.6718	.7682	.6874	.6859	.4001	.823	.823
18	.7209	.7611	.6944	.7545		.8383	.823
19	.5851	.7611	.7274				.7545
20	.6093	.6882	.6722	.4115		.381	.6859
21	.68	.7202	.6722	.5487	.2401	.6516	.6173
22	.7042	.6316	.6562	.5487	.2241	.724	.6859
23	.6642	.6325	.6241	.6173	.2347	.6859	
24	.6299	.6882	.6241	.6009	.5761	.2058	.631
Max	.7537	.823	.7716	.823	.6478	12.239	.823
Min	.3681	.4801	.5121	.4115	.2241	.2058	.4481
Avg	.6261	.6595	.6534	.6185	.489	1.0390	.6551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 204 / ABDUL LAT AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.2629	.2103	1.8244	1.6518	1.406	.12
2		.2454	.1949		1.6518	1.406	.1227
3		.2279	.1781	.7611	1.6518	1.4403	.1267
4		.2279	.2172	.7449	1.6324	1.4746	.1227
5		.2279	.2279	.7682	1.6518	1.5432	.124
6		.2454		.8482	.1619	1.7833	.1227
7		.2481	.2279	1.0288	.2012	2.0062	.1214
8		.2058	.2353	.1219	.2058	1.7661	.12
9	3.0639	3.3779	3.0769	.12	.1715	.1715	.1619
10	3.1786	3.1207	3.0887	.1372	.2103	.1829	.1147
11	2.8018	2.9321	2.8487	1.6461	.1753	.1829	.1311
12	2.6686	2.9492	2.6558	.1829	.1772		2.2186
13	2.5857		2.4939	.1677	.1772	.1829	2.1765
14	2.556		2.4806	.1886	.1753	.2229	1.7497
15	2.5888	2.9492	2.3045	.2058	.2103	.1981	1.8591
16	2.5396	2.5425	2.2939	.2229	.1753		2.0576
17	.1928	2.4577	.2401	.1886	.1928	.3429	1.8861
18	.1886	2.5377	.2629	.1886		.3086	1.9204
19	.2229	.2454	.2774				.2743
20	.2601	.2629	.298	4.6296		.1372	.2743
21	.2743	.2865	.298	1.6975	.1543	.1715	.2572
22	.3012	.2715	1.9685	1.8519			.2572
23	.2743	.2561	1.866	1.9376		.1214	.2286
24	.2374	.2658	.2279	1.8404	1.749		.124
Max	3.1786	3.3779	3.0887	4.6296	1.749	2.0062	2.2186
Min	.1886	.2058	.1781	.12	.1543	.1214	.1147
Avg	1.4209	1.1976	1.2249	.9683	.6514	.7920	.6946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 205 / 11 KV LATWAD GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2269	.0189	.0191	.0183	.0191	.0114	1.0479
2		.0189	.0191	.0183	.0191	.0114	1.0185
3		.0189	.0191	.0185	.0191	.0152	.9774
4		.0189	.0191	.0183	.0191	.0152	1.0374
5		.0189	.0191	.0185	.0191	.0152	.9877
6		.0189	.0191	.0185	.0191	.0152	
7		.0189	.0191	.0171	.0381	.0171	1.1765
8		.0152	.0187	.0171	.0381	.0171	1.3937
9	1.4746	.0152	.0187	.0171	.0191	.0152	1.3603
10	1.4074	.0152	.0189	.0191	.0183	.0152	1.3603
11	1.5083	.0171	.0187	.0191	.0189	.0152	1.4083
12		.0152	.0189	.0191	.0189	.0171	
13	.0187	.0152	.0189	.0191	.0191	.0171	.9878
14	.0187	.0171	.0189	.0191	.0189	.0152	1.1012
15	.0187	.0171	.0189	.0191	.0189	.0171	1.4083
16	.0187	.0343	.0189	.0191	.0189		1.4232
17	.0187	.0191	.0189	.0191	.0191	.0343	1.4403
18	.0187	.0191	.0189	.0191			1.4918
19	.0187	.0191	.0189				1.5089
20	.0187	.0191	.0189	.0191	.0191	.0191	1.3375
21	.0373	.0191	.0191	.0381	.0191	.0191	1.3889
22	.0373	.0191	.0191	.0381	.0191	.0191	1.286
23	.0189	.0191	.0183	.0191	.0191	1.086	
24	1.3146	.0189	.0191	.0183	.0191	.0114	1.1431
Max	1.5083	.0343	.0191	.0381	.0381	1.086	1.5089
Min	.0187	.0152	.0183	.0171	.0183	.0114	.9774
Avg	.4484	.0186	.0189	.0203	.0207	.0676	1.2517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 206 / 11 Kv Society Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1829	.2033	.197	.1829	.0857	.1753
2		.1848	.1829	.1991	.1829	.0857	.181
3		.2012	.1646	.1991	.1829	.0686	.1829
4		.2195	.1494	.181	.1867	.0686	.1867
5		.2033	.1463	.181	.1867	.0857	.1791
6		.2033		.1791	.1829	.0857	.2172
7		.1848	.2172	.1715	.1829	.0857	.2075
8		.1886	.1991	.1715	.1829	.0857	.2172
9	.2534	.2401	.2743	.2743	.1646	.1372	.2561
10	.2743	.2439	.3292	.2743	.1629	.2058	.2926
11	.2507	.2229	.3258	.2572	.1448	.1886	.2926
12	.2054	.2401	.2743	.2743	.1267		.2012
13	.1991	.1715	.2195	.2743	.1448		.1646
14	.2012	.1715	.2378	.2439	.1463	.1886	.176
15	.1829	.2058	.2218	.2401	.128	.1886	.3109
16	.1829	.2401	.2926	.2439	.1463		.2743
17	.181	.2534	.2561	.2134	.1578	.2858	.2229
18	.2195	.2195	.2353	.1981		.2477	.2572
19	.2172	.2012	.2378				.2229
20	.2012	.2012	.2195	.1886		.1715	.2058
21	.2012	.2195	.2195	.1981	.0886	.1753	.1543
22	.2172	.2172	.2195	.2401	.0886	.1905	.1543
23	.2012	.2561	.2195	.2134	.0914	.1715	
24	.2926	.2033	.2378	.2172	.2286	.0762	.1629
Max	.2926	.2561	.3292	.2743	.2286	.2858	.3109
Min	.181	.1715	.1463	.1715	.0886	.0686	.1543
Avg	.2178	.2115	.2297	.2187	.1567	.1439	.2128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 402 / I-CO SPIN FEEDER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3439	1.6575	3.9438	3.2819	3.4865	3.4865	3.7151
2	4.3439	1.6004	3.8866	3.6008	3.4865	3.4294	3.678
3	4.3439	1.6004	3.8295	3.658	3.4865	3.315	3.6969
4	4.2295	1.6575	3.8295	3.5437	3.4865	3.315	3.6214
5	4.1152	1.6575	3.8866	3.4517	3.4865	3.4294	3.8295
6	4.1152	1.6004	3.7723	3.4865	3.4865	3.4294	3.6008
7	4.5725	2.0005	3.8866	3.5437	3.5437	3.4865	3.8295
8	3.5437	2.2291	3.9438	3.5437	3.658	3.8866	4.1872
9	2.0576	7.8875	3.8866	3.8295	3.658	3.7723	4.1872
10	1.7147	4.401	3.6008	3.3722	3.5437	3.5437	3.315
11	1.8861	4.4582	3.3722	3.658	3.6008	3.5437	3.678
12	1.3717	4.0009	3.8866	4.0009	3.8866	3.7151	4.0175
13	1.4861	3.4294	3.8295	3.7723	3.658	3.5437	3.678
14	1.6575	3.4294	3.8866	3.6008	3.4294	3.5437	3.6008
15	1.829	4.0009	3.8866	4.0581	3.7723	3.7151	3.8295
16	1.4861	4.3439	4.0581	3.8295	3.8295		4.1152
17	1.7718	3.9438	3.5437	3.5437	3.4294	3.7151	3.7151
18		3.9438	3.8866	3.315		3.7723	3.7151
19	1.6004	3.5437	3.9438				3.4865
20	1.7147	3.5437	3.4294	2.3434		2.552	3.3722
21	1.7147	3.6008	3.7723	3.1436	3.0293	3.6008	3.5437
22	1.829	3.8295	3.7151	3.4294	3.2007	3.4865	3.658
23	1.829	3.7723	3.8866	3.6008	3.4294	3.7151	3.8866
24	4.2867	1.7147	4.0009	4.0009	3.6008	3.315	3.7151
Max	4.5725	7.8875	4.0581	4.0581	3.8866	3.8866	4.1872
Min	1.3717	1.6004	3.3722	2.3434	3.0293	2.552	3.315
Avg	2.6888	3.2436	3.8152	3.5482	3.5328	3.5142	3.7363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 201 / 11 KV SAHARANAGAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6062	.583	.5571	.583	.5784	.1677	
2	.5243	.5658	.5407	.5506	.5434	.1677	
3	.4915	.5658	.4973	.5344	.5258	.1677	
4	.4588	.5487	.4973	.4915	.5258	.1696	
5	.4588	.5144	.4973	.4588	.5258	.1696	
6	.4915	.5144	.4973	.4752	.5258	.1677	
7	.5571	.6516	.5138	.5182	.5258	.1696	
8	.5243	.6173	.5407	.5571	.5083	.4527	
9	.5792	.7202	.5898	.6722	.4908	.5668	
10	.5792	.7202		.6401	.4557	.6478	
11	.5792	.5468		.6706		.7209	
12	.4287	.5937				.6718	
13	.3429	.3887	.4049	.381		.4144	
14	.5487	.4161	.4481	.4572	.16	.4858	
15	.6001		.6249	.6097	.2715		
16	.6173	.5937	.6562	.6554	.2772	.6964	
17	.6344	.5376	.6718	.6706	.2075	.6802	
18	.6001	.6562	.6405	.6401		.6081	
19	.5658	.6478	.6405				
20	.5487	.583	.5693				.1578
21	.5487	.6062	.6081				.3506
22	.583	.6316	.5992	.1806	.1619		.4557
23	.6173	.583	.6478	.5418	.1677		.4908
24	.5801	.6001	.5735	.6154	.5487	.1677	
Max	.6344	.7202	.6718	.6722	.5784	.7209	.4908
Min	.3429	.3887	.4049	.1806	.16	.1677	.1578
Avg	.5444	.5820	.5627	.5452	.4118	.4051	.3637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 202 / 11 KV BIRDEV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1385	1.3077	1.1469	1.2334	1.0212	.7011	
2	1.1385	1.2071	1.1469	1.2323	.9907	.6935	
3	1.1544	1.1401	1.1603	1.2452		.7202	
4	1.1523	1.1401	1.2431	1.2266	.1524	.7202	
5	1.1523	1.1736	1.2431	1.2431	.1829	.7282	
6	1.2003	1.2407	1.2289	1.2431	.2439	.7802	
7	1.3443	1.3413	1.2289	1.3923	.2743	.7888	
8	1.2963	1.3413	1.2651	1.3108	.5182	.8916	
9	1.3748	1.5089	1.4403	1.3916	1.3108	1.3279	
10	1.3565	1.5424		1.5043	1.2803	1.4419	
11	1.2955	1.5043		1.3565		1.6004	
12	.8583	1.1561		.9145		1.2803	
13	.8259	.8482	1.1203	.8535		.8764	
14	1.166	1.3279	1.3441	1.1888	.7522	1.4083	
15	1.2955		1.3599	1.2955	.7716	1.4723	
16	1.2955	1.3904	1.3916	1.3565	.6859	1.5684	
17	1.3117	1.406		1.3717	.7373	1.5043	
18	1.2631	1.4586	1.3717	1.3413		1.4563	
19	1.1984	1.3765	1.3435				
20	1.2308	1.2308	1.2186				.4191
21	1.2793	1.2631	1.3283				1.1233
22	1.3279	1.2289	1.2308	.3048			1.2742
23	1.2955	1.2631	1.3443	1.2193	.4858		1.291
24	1.1248	1.3413	1.2289	1.2955	1.1126	.5735	
Max	1.3748	1.5424	1.4403	1.5043	1.3108	1.6004	1.291
Min	.8259	.8482	1.1203	.3048	.1524	.5735	.4191
Avg	1.2115	1.2930	1.2693	1.2153	.7013	1.0807	1.0269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 203 / 11 KV Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8502	1.9281	2.7664	2.8502	.9389		
2	2.6825	1.8778	2.6825	2.8502	1.8442	1.7528	
3	2.713	1.8778	2.5987	2.6825	1.9281	1.7528	
4	2.5987	1.8778	2.5987	2.6825	1.9281	1.7528	
5	2.6155	1.9281	2.5987	2.7664	2.0454	1.7528	
6	2.6825	2.0957	2.5987	2.8502	2.1795	1.9938	
7	2.6825	2.0119	2.6825	2.6825	2.3472	1.9938	
8	2.1491	2.2801	2.8502	2.8502	2.5484	2.4863	
9	1.2894	3.1184	2.9959	3.2322	3.1855	3.0178	
10	1.3032	3.152		3.1493	3.152	2.8502	
11	1.3032	3.1493		3.1623		3.2322	
12	.7331	2.9835		2.7035		3.0664	
13	.5921	2.5149	2.6216	2.4249		2.7435	
14	.5921	2.7349	2.753	2.8837	2.3482	2.9007	
15	.5921		2.915	3.1459	2.834	3.1493	
16	.5716	3.2322	2.9959	3.1459	2.915	3.315	
17	.5716	3.2693	3.0312	3.2922	2.8502	3.0664	
18	.5921	3.1459	3.1493	3.2579		3.315	
19	.6203	3.1017	3.0664				
20	.743	2.8826	3.1017				1.0029
21	1.6004	2.7854	3.1017				2.332
22	1.8842	2.7846	3.0178	.5609			2.6406
23	1.8435	2.9172	2.934				2.8807
24	3.0178	1.9281	2.8826	2.8502	.9831		
Max	3.0178	3.2693	3.1493	3.2922	3.1855	3.315	2.8807
Min	.5716	1.8778	2.5987	.5609	.9389	1.7528	1.0029
Avg	1.6177	2.5903	2.8544	2.8012	2.2685	2.5966	2.2141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 205 / Chandur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1401	1.2323					
2	1.1271	1.2323					
3	1.094	1.1949					
4	1.094	1.1949					
5	1.1065	1.1949					
6	1.1401	1.2136					
7	1.1603	1.2136					
9			1.4419	1.3592	1.3213		
10				1.4089	1.4352	.8145	
11				1.3592		.9831	
12				1.3592			
13			1.2651	1.2574		.9282	
14			1.3592	1.2431	1.4089	.9614	
15			1.4089	1.2574	1.4746	.9614	
16			1.3923	1.2239	1.4746	.9614	
17			1.3916		1.3108	.9282	
18			1.358			.9116	
22	1.2803						.7865
23	1.2803						.7499
24	1.1469	1.2696					
Max	1.2803	1.2696	1.4419	1.4089	1.4746	.9831	.7865
Min	1.094	1.1949	1.2651	1.2239	1.3108	.8145	.7499
Avg	1.1570	1.2183	1.3739	1.3085	1.4042	.9312	.7682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 206 / 11 Kv Abhar Phata
Industrial Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8669	2.8292	2.8292	2.9424	2.8292	2.6783	
2	2.8292	2.8292	2.8292	2.9047	2.9047	2.7349	
3	2.8104	2.8292	2.8292	2.8292	2.9047	2.7349	
4	2.7915	2.8292	2.8292	2.7915	2.9047	2.7349	
5	2.7915	2.7915	2.8292	2.7915	2.9047	2.7349	
6	2.8104	2.7915	2.8669	2.7915	2.9424	2.7915	
7	2.6406	2.7538	2.8669	2.8858	2.9801	2.8292	
8	2.4897	2.8669	3.1687	2.9424	3.0178	2.8292	
9	2.0195	2.9424	3.2065	3.131	2.9235	2.9235	
10	1.9433	2.9801		3.131	2.9235	3.0178	
11	1.8861	2.9047		2.9874		3.0556	
12	1.8861	2.8481				2.7915	
13	1.773	2.6406	2.7435	2.7633		2.6406	
14	1.8484	2.8292	3.0178	2.9874	2.8669	3.0178	
15	1.8861		3.0178	3.062	2.9235	3.0178	
16	1.8861	2.9424	3.0178	3.0994	2.9235	3.1121	
17	1.8861	2.8669	2.9613	3.131	2.8292	3.0933	
18	1.8861	2.9047	2.9047	3.0556		3.1499	
19	1.9239	2.9235	2.9047				
20	2.8292	2.9613	2.8858				.9054
21	3.131	3.0178	3.0178				2.3765
22	3.0933	3.0178	3.0556	1.358	2.5463		2.5652
23	3.0933	3.0933	3.0178	2.8006	2.6406		2.7538
24	2.9047	2.8669	3.0178	2.9801	2.7349	2.6783	
Max	3.131	3.0933	3.2065	3.131	3.0178	3.1499	2.7538
Min	1.773	2.6406	2.7435	1.358	2.5463	2.6406	.9054
Avg	2.4128	2.8809	2.9437	2.8683	2.8647	2.8719	2.1502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 207 / 11 KV Sonar Mali AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083	1.4754		1.3565			
2	1.3748	1.4251		1.3565			
3	1.2498	1.3916	1.1736	1.3413			
4	1.3748	1.3916	1.3413	1.3565			
5	1.3748	1.4083	1.3413	1.3565			
6	1.3748	1.4419		1.3904			
7	1.326	1.3077	1.3413	1.3565			
9					1.8107		
10					1.6095		
14					1.8842		
16					1.9662		
17					1.9281	1.2574	
18						1.3077	
22	1.6095	1.4754	1.5089				.6036
23	1.6263	1.5089	1.4922				.5868
24	1.4251	1.5089		1.4251			
Max	1.6263	1.5089	1.5089	1.4251	1.9662	1.3077	.6036
Min	1.2498	1.3077	1.1736	1.3413	1.6095	1.2574	.5868
Avg	1.4144	1.4335	1.3664	1.3674	1.8397	1.2826	.5952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 208 / 11 KV MAULI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1544	.6249	1.186	1.2955	1.0595	.9488	
2	1.1385	.5937	1.186	1.2955	1.0753	1.0402	
3	1.1227	.578	1.186	1.2163	1.1069	1.0526	
4	1.1069	.6249	1.186	1.166	1.1069	1.0526	
5	1.1069	.7186	1.186	1.1822	1.1069	1.0526	
6	1.1385	.8592	1.2018	1.1683	1.1385	1.1012	
7	1.0753	.9374	1.1717	1.2163	1.2018	1.0936	
8	1.0911	1.0467	1.2498	1.2955	1.2809	1.1405	
9	.8065	1.4217	1.406	1.3441	1.3599	1.3279	
10	.8223	1.3904		1.4563	1.2967	1.4373	
11	.6009	1.406		1.5203		1.4864	
12	.4687	1.3904		1.3923		1.3923	
13	.3125	1.0155	1.0936	1.0562		1.0722	
14	.4062	1.078	1.2498	1.2483	.7499	1.2483	
15	.4374		1.3435	1.2963	1.3279	1.4403	
16	.4374	1.3435	1.3748	1.3283	1.3279	1.439	
17	.4531	1.4232	1.3748	1.3279	1.3279	1.3916	
18	.3906	1.3435	1.3735	1.3279		1.439	
19	.3437	1.3279	1.3435				
20	.4999	1.3279	1.2186				.3353
21	.6249	1.2967	1.3765				.9755
22	.6562	1.2654	1.247	.3125			1.1279
23	.6249	1.3279	1.3283	1.2186	.7907		1.0822
24	1.2018	.6562	1.2651	1.2803	1.2186	.9014	
Max	1.2018	1.4232	1.406	1.5203	1.3599	1.4864	1.1279
Min	.3125	.578	1.0936	.3125	.7499	.9014	.3353
Avg	.7509	1.0869	1.2642	1.2355	1.1548	1.2136	.8802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 209 / 11 KV Jaihind Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.6805	.7167	.7922	.7167	.6401	
2	.7922	.6805	.7167	.7922	.7545	.6602	
3	.7922	.6805	.7356	.7922	.7545	.6602	
4	.7545	.6805	.7356	.7545	.7545	.6602	
5	.7545	.6805	.7356	.7545	.7545	.6602	
6	.7545	.7164	.7356	.7922	.7545	.679	
7	.7545	.6805	.7356	.7922	.7167	.679	
8	.6413	.7164	.7733	.7545	.6413	.6602	
9	.679	.788	.8299	.8299	.679	.7545	
10	.679	.788		.7922	.679	.8488	
11	.679	.7922		.7468		.7922	
12	.3395	.7167		.6722		.7545	
13	.3018	.6602	.7167	.7095		.7167	
14	.3395	.7545	.7922	.7842	.7545	.7545	
15	.3772		.7922	.8215	.7733	.7922	
16		.7922	.7922	.8215	.7545	.8299	
17	.3772	.7922	.7922	.8215	.6602	.8299	
18	.3772	.7922	.811	.8215		.7545	
19	.3772	.7733	.7922				
20	.4715	.7545	.7922				.6036
21	.8299	.7733	.8299				.7545
22	1.2936	.7922	.7922	.2241	.7167		.7167
23	.7545	.811	.7922	.8215	.6224		.7545
24	.7922	.6805	.7733	.7922	.6722	.6224	
Max	1.2936	.811	.8299	.8299	.7733	.8488	.7545
Min	.3018	.6602	.7167	.2241	.6224	.6224	.6036
Avg	.6393	.7381	.7706	.7563	.7152	.7236	.7073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 201 / 11KV TELEPHONE EXCHANGE

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 11 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2481	1.4998	2.21	2.0165	1.7147		2.1148
2	2.1879	1.5203	2.1719	1.9791	1.7528		2.0767
3	2.2291	1.5384	2.1338	1.9418	1.7909		2.0386
4	2.0748	1.4266	2.191	1.9044	1.6975		2.0195
5	2.1338	1.39	2.2291	1.9791	1.6766		2.0005
6	2.1529		2.2481	2.0165	1.6787		1.9814
7	2.0957		2.2672	2.0911	1.7353		2.4387
8	1.5813		2.3053	2.0165	1.773		1.9052
9	1.643		2.3243		2.21		1.9814
10		2.4768	2.3712	2.4768	2.1502		2.3899
11			2.4459	2.6673			
12		2.4196	2.3525	2.2862			
13		2.0182	2.0165	2.21			
14		2.4196	2.1472	2.2257		1.9052	
15		2.4768	2.4459	2.2862		2.21	
16		2.3815	2.3712	1.9052		2.2862	
17		2.3624	2.3339			1.7528	
18	1.4784	2.3434	2.2405				
19	1.4998	2.3815					
20	1.5384	2.3243					
21	1.5844	2.2862				1.9814	
22	1.5524	2.2481				2.21	
23	1.4998	2.21				2.1719	
24	2.1719	1.4415	2.2291	2.0538	1.6956		2.1529
Max	2.2481	2.4768	2.4459	2.6673	2.21	2.2862	2.4387
Min	1.4784	1.39	2.0165	1.9044	1.6766	1.7528	1.9052
Avg	1.8545	2.0613	2.2650	2.1285	1.8068	2.0739	2.1000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 202 / 11 KV KHOTWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029		1.0082	.9877		.9149
2	.8215		.9709	.9511		.8775
3	.8962		.9335	.9145		.8402
4	.9149		.9709	.8413		.8775
5	.9335		1.0082	.8779		.8589
6	.8589		1.0456	.9145		.8962
7	.8962		.9709	.9511		.9709
8	.6722		1.0185	.9145		.9709
9	.6878		1.0456			1.0456
10	.6584	1.0185	1.0608			
11	.6268		.9511			
12	.6154	.924	.9145			
13	.5853	.9335	.8779			
14	.6089	.9054	.9511		1.0829	
15	.6584	1.094	1.0242		1.1203	
16	.6335	1.094	1.0608		1.1088	
17	.6036	1.1203	1.0791		1.1203	
18	.5975	1.0829	1.0974			
19		1.0562				
20		1.0185				
21		1.0456			.9709	
22		1.0829			.9709	
23		1.0642			.9335	
24	1.1765	.8962	1.0456	1.0242		.9522
Max	1.1765	1.1203	1.0974	1.0242	1.1203	1.0456
Min	.5853	.8962	.8779	.8413	.9335	.8402
Avg	.7499	1.0240	1.0018	.9308	1.0439	.9205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 203 / 11 KV SARITA POLYMER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8197		3.0864	3.2007		2.8959
2	2.726		3.0483	3.1626		2.8578
3	2.8197		3.0102	3.1245		2.8959
4	2.8578		2.9721	3.0864		2.934
5	2.7054		3.0102	3.0483		2.9912
6	2.7816		3.0483	3.0102		3.0483
7	2.6139		3.1055	3.0864		3.0483
8	1.8484		3.2007	3.0102		3.1626
9	1.6804		3.0769	3.2007		3.296
10	1.8111	3.0483	3.1436	3.3008		
11	1.9239		3.2388	3.2579		
12	1.9791	3.0483	3.1436	3.131		
13	1.8877	2.8769	2.8578	3.0102		
14	1.8484	3.2007	3.2007	2.8959	3.0483	
15	1.9258	3.2198	3.1626	3.4294	3.1436	
16	1.9404	2.9721	3.2388	3.2819	3.2579	
17	1.905	3.296	3.3341		3.3532	
18	1.9418	3.3532	3.3913			
19		3.4294				
20		3.3341				
21		3.1245			3.0864	
22					3.0102	
23		3.0864			2.9721	
24	2.9531	2.8959	2.8959	1.3336		2.934
Max	2.9531	3.4294	3.3913	3.4294	3.3532	3.296
Min	1.6804	2.8769	2.8578	1.3336	2.9721	2.8578
Avg	2.2615	3.1450	3.1140	3.0336	3.1245	3.0064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 204 / RENUKANAGAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3529		2.4615	2.524	2.3655		.3768
2	2.3411		2.4253	2.4874	2.0911		.3932
3	2.3045		2.3891	2.4508	2.1582		.3605
4	2.2916		2.3529	2.4143	2.1658		.3768
5	2.2779		2.3167	2.3777	2.2032		.426
6	2.3899		2.3529	2.3411	2.1472		.4588
7	2.3152		2.3891	2.268	2.0911		.3932
8	2.1658		2.6292	2.1948	2.1068		.3277
9	2.1582		2.7435	2.6337	2.1658		.5281
10	2.2443	2.6505	2.6063	2.7801	2.3525		
11	2.2314		2.6063	2.6787			
12	2.1216	2.5692	2.5339	2.6139			
13	1.949	1.9845	2.1719	2.4646			
14	1.9547	2.3891	2.3167	2.5133			
15	2.0058	2.7069	2.6244	2.7351			
16	1.9387	2.6787	2.6063	1.4415			
17	1.9185	2.5606	2.7149				
18	1.7375	2.5701	2.8235				
19		2.6337					
20		2.5701					
21		2.5789				.3932	
22		2.5606				.3932	
23		2.4977				.3932	
24	2.3891	2.3167	2.4796	2.5606	2.4025		.4096
Max	2.3899	2.7069	2.8235	2.7801	2.4025	.3932	.5281
Min	1.7375	1.9845	2.1719	1.4415	2.0911	.3932	.3277
Avg	2.1625	2.5191	2.5023	2.4400	2.2045	.3932	.4051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 205 / 11 KV Sanmati Vg Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7558		1.8823	1.9022		1.8296
2	1.7551		1.8461	1.8656		1.7926
3	1.7737		1.8099	1.829		1.7556
4	1.7364		1.7737	1.7924		1.7187
5	1.7551		1.7375	1.7558		1.7002
6	1.7558		1.7013	1.7193		1.6632
7	1.8298		1.7375	1.7558		1.8665
8	.9808		1.8642	1.7193		1.7187
9	.9193		1.9366	2.0698		1.9959
10	.8505	1.9591	2.1582	2.1807		
11	.8505		2.1582	2.0633		
12	.8048	1.8724	2.0119	2.0911		
13	.8238	1.4043	1.7924	2.0165		
14	.8505	1.828	2.1033	1.8983	1.8446	
15	.9145	1.9909	2.1582	2.0538	2.0774	
16	.8779	1.9753	2.0119	2.1082	2.167	
17	.8238	1.9936	1.9753		2.0416	
18	.7865	1.9366	2.0119			
19		1.9185				
20		1.9004				
21		1.8823			1.9936	
22		1.9387			1.8839	
23		1.8823			1.8656	
24	1.7375	1.4899	1.9185	1.9387		1.8473
Max	1.8298	1.9936	2.1582	2.1807	2.167	1.9959
Min	.7865	1.4043	1.7013	1.7193	1.8446	1.6632
Avg	1.2412	1.8552	1.9257	1.9270	1.9820	1.7888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 148015 / 220 KV TILAWANI

Feeder No / Name : 402 / ARVIND

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	14.289
Max	14.289
Min	14.289
Avg	14.289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 148015 / 220 KV TILAWANI

Feeder No / Name : 406 / 33 KV F.I.E. SPHEROTECH
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 148015 / 220 KV TILAWANI

Feeder No / Name : 408 / PRIDE INDIA

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17
HR	Load (MW)
24	4.2867
Max	4.2867
Min	4.2867
Avg	4.2867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 201 / 11KV TAKWADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5441		.5761	.6562	.6722	.2753	.4001
2	.5121	.5761	.5761	.6401	.6401	.3077	.5344
3	.5121	.5441	.5441	.6401	.6401	.2915	.5344
4	.4961	.5281	.5121		.6081	.2753	.4858
5	.4961	.4961	.5121	.4801	.5761	.3077	.4534
6	.4801	.5121	.5601	.5281	.6081	.2753	.4534
7	.5601	.5601	.5921	.5761	.6081	.3239	.5344
8	.5921	.5601	.5921	.5601	.5441	.3401	.583
9	.6562	.7522	.7362	.7522	.5121	.7287	.7287
10	.7202	.8002	.8802	.8322	.5601	.7935	.7449
11	.7522	.8322	.7682	.8802	.5441	.7935	.7935
12	.7042	.7522	.8162	.8962	.4801	.7449	.8097
13	.6081	.6081	.6401	.5921	.3841	.5921	.6316
14	.6722	.7362	.6401	.6882	.4161	.7682	.6154
15	.7842	.8162	.8802	.8802	.4641	.8802	.7773
16	.8002	.8322	.8322	.8482	.3841	.8962	.8259
17	.7842	.8322	.8162	.8482	.3201	.6882	.7773
18	.7842	.8162	.8482	.8162		.7682	.6964
19	.7682	.8482	.8482				.8097
20	.7522	.8002	.8962		.3361	.6081	.8745
21	.8309	.7362	.8002	.8002	.421	.6562	.7522
22	.7042	.6882	.7362	.8002	.421	.6722	.7202
23	.6562	.7202	.7362	.8065	.3401	.6081	.7202
24	.6081	.6241	.6241	.6562	.759	.3077	.5761
Max	.8309	.8482	.8962	.8962	.759	.8962	.8745
Min	.4801	.4961	.5121	.4801	.3201	.2753	.4001
Avg	.6574	.6944	.7068	.7228	.5109	.5610	.6597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 202 / 11 KV PATIL MALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1069	1.2018	1.1523	1.0402	1.2651	.506	.9717
2	1.012	1.1385	1.0883	1.1523	1.2003	.4902	1.0688
3	.9804	1.1069	1.0562	1.1523	1.1069	.4902	1.085
4	.9804	1.0279	1.0242	1.0562	1.0753	.4902	1.0202
5	.9922	.9646	1.0242	1.0082	1.0437	.506	.9069
6	.9488	1.0279	1.0402	1.0402	.9488	.506	.9878
7	1.0911	1.1069	1.1203	1.1203	1.0279	.5693	1.0202
8		1.1069	1.0883	1.1203	.8223	.7274	1.1336
9	1.2651	1.4091	1.3763	1.4403	.759	1.2967	1.3117
10	1.3283	1.3916	1.4083	1.3443	.6642	1.2967	1.4089
11	1.4232	1.3599	1.4403	1.4083	.6325	1.3916	1.3599
12	1.3283	1.2018	1.4232	1.2967	.6325	1.3599	1.2967
13	.9282	.8642	1.0082	.9646	.5441	.9488	.9488
14	1.0562	1.0242	1.0437	1.1385	.5281	1.1069	1.0279
15	1.3123	1.2643	1.3283	1.2809	.6081	1.2334	1.3283
16	1.4403	1.3923	1.3916	1.3916	.6081	1.2334	1.3927
17	1.4083	1.3763	1.4232	1.3283	.6081	1.3283	1.166
18	1.4083	1.3283	1.3283	1.3599		1.3599	1.3279
19	1.3763	1.4403	1.3283		.5761		1.4251
20	1.2631	1.3283	1.2334	.8855	.6241	.9122	1.3279
21	1.3283	1.3443	1.3923	1.3441	.6009	1.2483	1.3599
22	1.2967	1.2803	1.2643	1.2967	.6009	1.2643	1.2811
23	1.2651	1.2803	1.3443	1.3599	.5851	1.2483	1.2967
24	1.2018	1.2176	1.2483	1.2963	1.3441	.5376	1.1984
Max	1.4403	1.4403	1.4403	1.4403	1.3441	1.3916	1.4251
Min	.9282	.8642	1.0082	.8855	.5281	.4902	.9069
Avg	1.2062	1.2160	1.2323	1.2098	.8003	.9588	1.1938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 203 / 11 KV PARIJAAT FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6226	.5735	.6962	.6952	.6554	.3768	1.6956
2	.6299	.5735	.6962	.6783	.663	.3932	1.8204
3	.6062	.5898	.6299	.6401	.6299	.3768	1.8378
4	.6062	.5898	.6299		.6226	.3768	1.8204
5	.6226	.6062	.6299	.6274	.6226	.3768	1.7684
6	.6554	.5898	.6796	.3222	.6554	.3932	1.7857
7	.6554	.5735	.7293	.3315	.6226	.3441	1.8204
8	.6554	.6554	.663		.4915	.3932	1.8204
9	.8192	.8029	.8619	.8288	.4915	.7045	2.0978
10	.8192	.8029	.9116	.8619	.4915	.8029	1.8378
11	.8192	.852	.9614	.9614	.5243	1.8023	2.1628
12	.7373	.852	.9339	.8356	.5304	1.9334	2.2939
13	.5138	.6274	.6226	.6062	.4917	1.8842	1.9989
14	.6299	.7969	.7865	.8356	.4748	2.0481	2.1628
15	.7459	.9156	.9116	.852	.5426	2.3758	2.3594
16	.7956	.9156	.9012	.7865	.4748	2.3758	2.2805
17	.7625	.8817	.9831	.9175	.4917	2.4034	2.4188
18	.7956	.9156	.9503	.8029		2.4577	2.4006
19	.8122	.8648	.8192	.8029	.3561		2.2634
20	.7716	.8139	.7373	.6554	.373	2.0348	2.2977
21	.7865	.7625	.8139	.7459	.4096	2.1195	2.3739
22	.7209	.7956	.8309	.8192	.426	1.9161	2.0805
23	.6554	.7956	.763	.7373	.426	1.8482	2.0805
24	.763	.5898	.7459	.7291	.6882	.3768	1.8313
Max	.8192	.9156	.9831	.9614	.6882	2.4577	2.4188
Min	.5138	.5735	.6226	.3222	.3561	.3441	1.6956
Avg	.7084	.7390	.7870	.7306	.5285	1.3093	2.0546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 204 / 11 KV DRAINAJE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.1163	.9431	.8842	.9389	.631	.9362
2	1.9204	1.0277	.8916	.8842	.8478	.5784	.8764
3	1.8442	.9214	.823	.8322	.8139	.5784	.8413
4	1.8107	.8505	.7716	.7802	.8139	.5609	.7888
5	1.7859	.815	.7716	.7108	.7888	.5609	.7186
6	1.8275	.8505	.7888	.7628	.7461	.5609	.7537
7	2.0008	.8682	.7716	.7888	.8478	.5784	.8764
8	2.1125	.8682	.8059	.7545	.7042	.6135	.8764
9	2.3739	1.2048	1.2003	1.166	.8309	1.1568	1.262
10	2.4143	1.2048	1.0631	1.166	.8139	1.1393	1.3146
11	2.452	1.2048	1.2346	1.3032		1.3146	1.3321
12	2.3061	1.1871	1.2209	1.258		1.3321	1.1919
13	1.989	.2774	.9389	.7973		.9724	.9465
14	2.0233	.3294	1.0059	1.0277		.9282	1.0867
15		.9189	1.1869	1.2934		1.1603	1.2445
16	.5144	1.3176	1.2742	1.2934	.8322	1.2071	1.3321
17	1.286	1.335	1.2239	1.258	.8495	1.2209	1.4198
18	1.3032	1.2309	1.2071	1.2574		1.2071	1.3496
19	1.2346	1.2309	1.1869		.7282		1.3321
20	1.1443	1.0749	1.073	.9156	.7802	.9536	1.1568
21	1.258	1.2003	1.1269	1.1736	.8413	1.0402	1.2689
22	1.2048	1.1317	1.0923	1.1065	.8063	.9602	1.1869
23	1.2226	1.1317	1.1443	1.1065	.7712	1.0576	1.0753
24	2.1948	1.134	.9945	1.0402	1.0513	.7011	1.0056
Max	2.452	1.335	1.2742	1.3032	1.0513	1.3321	1.4198
Min	.5144	.2774	.7716	.7108	.7042	.5609	.7186
Avg	1.7513	1.018	1.0309	1.0244	.8226	.9136	1.0906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 205 / BALIRAJA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7625	.9116					
2	.7373	.8785				.3315	.431
3	.7459	.8619				.3978	.431
4	.7625	.8785				.4144	.4144
5	.8048	.8619				.4144	.3812
6	.8785	.8785				.4144	.4475
7	.8718	.9282				.4641	.4973
8						.431	
9		1.0442	1.0608	.9282		.431	
10		1.0442		.9945			
11		1.1271		.8619			
12		1.0608		1.0111			
13			.8619	.9779			
14			1.0898	.8288			
15			1.1568	1.0111			
16		.9614	1.153	.9614			
17		.8785	.9724				
18		.8951	.9724				
20					.1658		
21					.1658		
22	.8785				.1326		
23	.8785						
24	.8383	.9116					
Max	.8785	1.1271	1.1568	1.0111	.1658	.4641	.4973
Min	.7373	.8619	.8619	.8288	.1326	.3315	.3812
Avg	.8159	.9415	1.0382	.9469	.1547	.4123	.4337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 201 / TAMBE MAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3163	1.1873	1.3916	1.5432	1.3123	.5487	
2	.3163	1.1561	1.3283	1.5432	1.2498	.5144	
3	.3479	1.0311	1.2651	1.3717	1.2498	.5144	
4	.3479	.9374	1.2651	1.3717	1.2498	.5144	
5	.3479	.9998	1.2651	1.3717	1.2498	.5487	
6	.3795	1.0623	1.2651	1.3717	1.2498	.5487	
7	.3795		1.3916	1.3717	1.2498	.583	
8	.3479	1.3123	1.4548	1.3375	1.3123	.9602	
9	.3795	1.5623	1.7147	1.5051	1.2498	1.7147	1.5242
10	.3795	1.3748	1.6461	1.5051	1.2498		1.5546
11	.4111	1.3748		1.5051	1.1248		1.4937
12	.4111	1.4373		1.5051	.9061		1.3108
13	.9488	.9998	1.0288	.9031	.7811		1.2193
14	1.0753	1.5623	1.0288	1.3245	.9686		1.3717
15	1.4548	1.5623	1.5432	1.3245	1.0623		1.4327
16	1.4232	1.5623	1.7147	1.3245	1.1248		1.5089
17	1.3916		1.7147	1.3998	1.0623		1.4937
18	1.4232	1.5623	1.6461	1.5051			1.4327
19	1.3916	1.5623	1.6461				1.3717
20	1.3599	1.4998	1.6118	.6622	.4321		1.3717
21	1.3916	1.4998	1.6118	1.3847	.4938		1.4022
22	1.4232	1.4998	1.5432	1.3847	.5247		1.3717
23	1.4548	1.4998	1.5432	1.3245	.5556	1.3717	1.3717
24	.3163	1.2186	1.4548	1.5432	1.3603	.583	
Max	1.4548	1.5623	1.7147	1.5432	1.3603	1.7147	1.5546
Min	.3163	.9374	1.0288	.6622	.4321	.5144	1.2193
Avg	.8091	1.3393	1.4579	1.3645	1.0463	.7638	1.4154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 202 / UTTAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	1.382	1.5043	1.406	1.448	1.2003	
2	.7522	1.3466	1.4784	1.406	1.3611	1.166	
3	.7522	1.2048	1.4327	1.406	1.3756	1.0974	
4	.7522	1.134	1.4327	1.3717	1.3032	.9602	
5	.7522	1.2757	1.4327	1.3717	1.3032	1.0288	
6	.788	1.3466	1.4327	1.3717	1.3032	1.0631	
7	.8238	1.4175	1.4327	1.3375	1.448	1.0974	
8	.8238	1.4883	1.4327	1.4403	1.448	1.166	
9	1.0029	1.5592	1.5775	1.6461	1.448	1.4403	1.3466
10	1.0029	1.6301	1.6461	1.6461	1.448		1.4175
11	1.0029	1.6301		1.6461	1.4118		1.6301
12	1.0029	1.5592		1.6461	1.4118		1.5592
13	.8954	1.2757		1.3169	1.2308		1.2403
14	1.2178	1.6301	1.5775	1.6095	1.267		1.5592
15	1.6078	1.6301	1.5775	1.6095	1.267		1.5947
16	1.576	1.6301	1.5775	1.6827	1.3032		1.6124
17	1.6118	1.6301	1.5432	1.7558	1.267		1.6124
18	1.6476	1.6301	1.4746	1.6827			1.5947
19	1.6834	1.701	1.4746				1.6301
20	1.7551	1.6301	1.4746	1.4632			1.4883
21	1.7551	1.6301	1.4746	1.7558			1.5592
22	1.7193	1.5592	1.4746	1.7558			1.5769
23	1.7551	1.5592	1.4403	1.6095	1.3756	1.2346	1.5947
24	.788	1.4175	1.5043	1.406	1.5203	1.2346	
Max	1.7551	1.701	1.6461	1.7558	1.5203	1.4403	1.6301
Min	.7522	1.134	1.4327	1.3169	1.2308	.9602	1.2403
Avg	1.1759	1.4957	1.4950	1.5366	1.3653	1.1535	1.5344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 203 / 11 KV CHANDUR ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.506	1.8747	2.1506	2.2634	2.2024	.6173	
2	.506	1.8122	2.0241	2.2634	2.0729	.583	
3	.4744	1.7497	2.0241	2.2805	2.0729	.583	
4	.4744	1.6872	2.0241	2.2977	2.0729	.5487	
5	.4744	1.906	2.0241	2.2977	2.0729	.6173	
6	.4744	1.9997	2.0241	2.332	2.0729	.7202	
7	.4744	1.9997	2.2771	2.332	1.9433	.8573	
8	.4744	2.2497	2.2771	2.4006	1.9433	1.3375	
9	.5693	2.4996	2.7435	2.713	1.2803	2.572	2.4996
10	.5693	2.4996	2.7435	2.713	1.2803		2.4996
11	.5693	2.4996	2.7435	2.713	1.1523		2.5309
12	.5693	2.2497	2.0576	2.713	.9282		2.1715
13	1.5813	1.4998	1.4746	1.3565	.8002		1.8747
14	1.8976	2.3746	2.6749	2.5774	.8642		2.1872
15	2.1822	2.3746	2.6749	2.5774	.9602		2.4371
16	2.1506	2.3746	2.6749	2.5774	1.0562		2.4996
17	2.2138	2.3746	2.5034	2.5774	1.0242		2.4996
18	2.2138	2.3746	2.4691	2.5774			2.4996
19	2.1247	2.3746	2.4348				
20	2.1822	2.2497	2.4348	.9496	.4801		2.1872
21	2.2455	2.2497	2.4348	2.5774	.6241		2.234
22	2.2455	2.2497	2.4006	2.5774	.6401		2.2497
23	2.2771	2.2497	2.2291	2.4417	.6722	2.0576	2.3045
24	.5376	1.9997	2.1506	2.2634	2.332	.6516	
Max	2.2771	2.4996	2.7435	2.713	2.332	2.572	2.5309
Min	.4744	1.4998	1.4746	.9496	.4801	.5487	1.8747
Avg	1.2495	2.1572	2.3196	2.3640	1.3886	1.0132	2.3339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 204 / WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8421	2.0972	2.332	2.4006	2.3205		
2	.8421	1.9662	2.332	2.332	2.2542	.6173	
3	.8097	1.9334	2.2672	2.332	2.2542	.6516	
4	.8097	1.8023	2.2672	2.332	2.2542	.6516	
5	.8097	2.0317	2.2672	2.332	2.2542	.6859	
6	.8097	2.13	2.2672	2.2634	2.2542	.6859	
7	.8745	2.2611	2.332	2.2977	1.989	.8573	
8	.8421	2.3922	2.332	2.2634	1.989	1.2003	
9	1.1012	2.6216	2.7435	2.6292	1.1934	2.7435	2.6216
10	1.1012	2.6871	2.7435	2.6642	1.1934		2.556
11	1.0688	2.6871	2.7435	2.6642	1.0608		2.7362
12		2.2939	2.0576	2.6642	.8619		2.2447
13		1.7695	1.8861	1.4022	.8288		2.13
14		2.556	2.6063	2.6642	.8951		2.2939
15	1.3927	2.556	2.6063	2.6642	.8951		2.5888
16	1.5223	2.556	2.6406	2.6642	.9282		2.7199
17	1.749	2.4905	2.572	2.8045	.8951		2.6543
18	1.9433	2.4905	2.5034	2.6642			2.6216
19	2.0081	2.4249	2.4006				2.556
20	2.1538	2.4905	2.4006				2.4577
21	2.2024	2.4905	2.4006	2.6642			2.4249
22	2.2672	2.4905	2.4348	2.6642			2.3594
23	2.332	2.4905	2.4006	2.524		1.2003	2.3102
24	.8745	2.1628	2.3967	2.4006	2.3205		
Max	2.332	2.6871	2.7435	2.8045	2.3205	2.7435	2.7362
Min	.8097	1.7695	1.8861	1.4022	.8288	.6173	2.13
Avg	1.3503	2.328	2.4139	2.4678	1.5912	1.0326	2.4850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 205 / DKTE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0349	1.1827	1.1317	1.0288	.8573	
2		.9979	1.1827	1.166	1.0029	.823	
3		.961	1.1088	1.1317	.9602	.7545	
4		.8871	1.1088	1.0974	.9602	.6859	
5		.961	1.1088	1.0974	1.0288	.7202	
6		1.0719	1.1088	1.0288	1.0288	.7202	
7		1.1088	1.1827	1.0288	1.0974	.823	
8		1.2567	1.1088	1.0288	1.0974	1.0631	
9		1.3306	1.0288	1.4327	1.3611	1.2003	1.1946
10		1.4045		1.4327	1.3611		1.267
11		1.4045		1.4327	1.3611		1.2851
12		1.4045	1.0288	1.4327	1.3611		1.267
13		1.2567	.9602	1.2178	1.0387		1.086
14		1.3306	1.0288	1.3611	1.1104		1.1222
15	.7392	1.3306	1.3717	1.3611	1.182		1.1584
16	.8871	1.4045	1.3717	1.2894	1.2178		1.1946
17	.9979	1.4045	1.3032	1.2894			1.4118
18	1.1203	1.4045	1.2689	1.4327			1.448
19	1.2567	1.7002	1.2689				1.5023
20	1.4045	1.5524	1.2689	1.3611	1.1462		1.5203
21	1.3676	1.5524	1.2689	1.2894	1.0387		1.5203
22	1.3306	1.4045	1.2689	1.2894	1.0387		1.448
23	1.2936	1.3306	1.2346	1.2178	1.0029	1.0288	1.267
24		1.0719	1.2567	1.166	1.1462	.8916	
Max	1.4045	1.7002	1.3717	1.4327	1.3611	1.2003	1.5203
Min	.7392	.8871	.9602	1.0288	.9602	.6859	1.086
Avg	1.1553	1.2736	1.1828	1.2485	1.1224	.8698	1.3128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 206 / GAON BHAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3978	.9145	1.0608	1.2003	.9717	.5316	
2	.4525	.8535	.9945	1.2003	.8421	.5144	
3	.3978	.7926	.9282	.9602	.8916	.4973	
4	.4458	.7316	.9282	.9602	.8718	.4801	
5	.4287	.7926	.8619	.9602	.8421	.5487	
6	.5258	.8535	.8619	.9602	.9069	.583	
7	.5087	.9755	1.0608	.9602	.9069	.6344	
8	.5316	1.0669	1.0608	.9945	.9069	.8573	
9	.5967	1.1584	1.2346	1.0269	.9717	1.3717	1.2193
10	.5967	1.0974		1.0562	.9717		1.2193
11	.6299	1.1584		1.0562	.9717		1.1584
12	.663	.8535	1.2003	1.0562	.9602		1.0669
13	.5967	1.0623		.8802	.7773		.9145
14	.7956	.9755	1.2003	1.0562	.8097		.9145
15	.9945	.9145	1.2003	1.0562	.8097		1.0364
16	1.0277	.9145	1.2346	1.0562	.8421		1.0822
17	1.0608	.9145	1.2346	.8802	.7773		1.1279
18	1.1271	.9145	1.2346	1.1736			1.1888
19	1.1603	.945	1.3717				1.2193
20	1.2266	1.2193	1.3032	.7628	.6802		1.1888
21	1.1934	1.2193	1.3032	1.0562	.6802		1.1888
22	1.1934	1.0974	1.2689	1.0562	.6478		1.0974
23	1.1603	1.0974	1.2003	.9976	.583	1.0631	1.0517
24	.3647	.9755	1.1271	1.2003	1.0364	.5658	
Max	1.2266	1.2193	1.3717	1.2003	1.0364	1.3717	1.2193
Min	.3647	.7316	.8619	.7628	.583	.4801	.9145
Avg	.7532	.9791	1.1367	1.0247	.8481	.6952	1.1116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 207 / 11 KV Ramnagar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	2.5873	2.8959	2.7435	2.8654	2.0576	
2	.6219	2.5133	2.8959	2.6749	2.8959	1.989	
3	.6219	2.4394	2.8959	2.6749	2.8654	1.8519	
4	.5731	2.3655	2.8959	2.6749	2.8654	1.8176	
5	.5792	2.6612	2.8959	2.6749	2.8959	2.0576	
6	.5853	2.809	2.8959	2.7435	2.8654	2.1262	
7		2.7721	3.2526		3.0087	2.2291	
8	.5792	2.9938	3.1855	2.5034	3.0087	2.572	
9	.5792	3.4004	3.2922	3.658	3.2952	3.0521	3.155
10	.5792	3.5482	3.4294	3.658	3.3303		3.1207
11	.5792	3.5482	3.4294	3.658	3.0407		3.1207
12		3.2526	3.2579	3.658	2.6863		2.6353
13		3.4004	2.7435	2.3411	2.364		2.6006
14		3.4004	2.6749	3.219	2.5789		2.6699
15	.9593	3.4004	3.4294	3.219	2.9012		2.9473
16	1.2308	3.4004	3.4294	3.219	3.3669		3.0514
17	1.4842	3.4004	3.2579	3.0727	3.0445		3.0167
18	1.7013	3.4004	3.0864	3.0727			2.9473
19	1.9547	3.5482	3.1207				2.878
20	2.0633	3.4004	3.1207	1.4632	1.0208		2.774
21	2.3891	3.4004	3.0864	3.219	2.2923		2.7913
22	2.6063	3.1047	2.7435	3.219	2.364		2.774
23	2.8959	3.1047	2.7435	3.0727	2.4356	2.7435	2.722
24	.6516	2.6612	2.8959	2.7435	3.0087	2.1262	
Max	2.8959	3.5482	3.4294	3.658	3.3669	3.0521	3.155
Min	.5731	2.3655	2.6749	1.4632	1.0208	1.8176	2.6006
Avg	1.1943	3.1047	3.0648	2.9629	2.7727	2.2384	2.8803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 208 / 11 KV KRISHI GANGA SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3841			.3086
2		.3841			.3429
3		.4161			.3601
4		.4481			.3601
5		.4481			.3772
6		.4801			.3772
7		.5121			.3772
8		.5281			.3772
9		.5335	.5487	.4161	
10		.6036	.5487	.4801	
11		.6036	.5487	.5761	
12		.5121	.583	.5761	
13			.583	.5761	
14			.6173	.5761	
15			.6173	.5761	
16		.5121	.6173	.5761	
17		.5121	.4458	.5761	
18		.5121	.4458		
23	.3201				
24		.4024			
Max	.3201	.6036	.6173	.5761	.3772
Min	.3201	.3841	.4458	.4161	.3086
Avg	.3201	.4870	.5556	.5477	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 209 / JACKWELL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1886	.1715	.1867	.1715	
2		.1867	.1886	.1715	.1867		
3		.1867	.1886	.1715	.1867	.1715	
4		.1867	.1886	.1715	.1867	.1715	
5		.1867	.1886	.1715	.1867	.1715	
6		.1867	.1886	.1715	.1867	.1715	
7		.1867	.1886	.1715	.1867	.1715	
8		.1867	.1886	.1715	.1867	.1715	
9		.2054	.1715	.1867	.1886	.1715	.1886
10		.1867	.1715	.1867	.1886		.1886
11		.1867	.1715	.1867	.1886		.1886
12		.1867	.1715	.1867	.1886		.1886
13		.1867	.1715	.1867	.1886		.1886
14		.1867	.1715	.1867	.1886		.1886
15	.2452	.1867	.1715	.1867	.1886		.1886
16	.2452	.1867	.1715	.1867	.1886		.1886
17	.2427	.1867	.1715	.1867	.1886		.1886
18	.2328	.1867	.1715	.1867			.1886
19	.2328	.1867	.1715				.1886
20	.2328	.1867	.1715	.0934	.1867		.1886
21	.2328	.1867	.1715	.0934	.1867		.1886
22	.2328		.1715	.0934	.1867		.1886
23	.2507	.1867	.1715	.1867	.1867	.1715	.1886
24		.1867	.1886	.1715	.1867	.1715	
Max	.2507	.2054	.1886	.1867	.1886	.1715	.1886
Min	.2328	.1867	.1715	.0934	.1867	.1715	.1886
Avg	.2386	.1875	.1779	.1686	.1875	.1715	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 210 / AVENUE SUPER MARKET

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0747	.0343	.056	.0343	
2	.0373	.0373	.0373	.0343	.0373	.0343	
3	.0373	.0373	.0373	.0343	.0373	.0343	
4	.056	.0373	.0373	.0343	.0373	.0343	
5	.056	.0373	.0373	.0343	.0373	.0343	
6	.056	.0373	.0373	.0343	.0373	.0514	
7	.0373	.0373	.0747	.0514	.0373	.0686	
8	.056	.0373	.0747	.0514	.0373	.0686	
9	.056	.0747	.0686	.056	.0747	.0686	.0566
10	.056	.1307	.0686	.056	.0747		.0566
11	.0373	.1307	.0686	.112	.0934		.1132
12	.056	.0934	.12	.112	.0934		.1509
13	.0187	.0747	.0686	.112	.0934		.132
14	.0187	.0934	.0857	.1307	.096		.132
15	.0187	.0934	.1029	.1307	.096		.132
16	.0934	.0934	.1372	.1307	.096		.1132
17	.112	.168	.12	.1307			.1509
18	.1494	.168	.1029	.1494			.1509
19	.168	.1867	.12				.1698
20	.1867	.2033	.1543	.2054	.112		.1886
21	.168	.2054	.12	.1867	.112		.1886
22	.112	.1867	.1372	.1867	.0934		.1509
23	.0747	.1867	.0514	.1494	.0934	.0343	.1132
24	.0373	.0373	.1494	.0514	.112	.0686	
Max	.1867	.2054	.1543	.2054	.112	.0686	.1886
Min	.0187	.0373	.0373	.0343	.0373	.0343	.0566
Avg	.0723	.1010	.0869	.0960	.0742	.0483	.1333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 211 / naikmala

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	1.8778	2.2634	2.4006	2.1262	1.0631	
2	.3353	2.0165	2.2634	2.2291	2.1262	1.0288	
3	.3688	1.7436	2.5019	2.2291	2.0919	.9945	
4	.3688	1.6766	2.2466	2.1605	2.0919	.9259	
5	.3688	1.7772	2.2466	2.1605	2.1091	1.0288	
6		1.7772	2.2801	2.1605	2.1091	1.0631	
7	.4024	2.0119	2.2801	2.332	2.1091	1.3375	
8	.4024	2.3807	2.3304	2.4006	2.0919	1.3375	
9	.4359	2.5316	2.6063	2.4478	1.9204	2.4177	2.1795
10	.4359	2.5819	2.6063	2.5484	1.8404		2.3472
11	.4359	2.6155	2.6063	2.5484	1.7604		2.3137
12	.4024	2.3807	2.6063	2.5484	1.2146		1.5257
13	1.3413	2.0287	1.6461	1.6095	1.2955		1.643
14	1.8107	2.4143	1.6289	2.4143	1.6194		2.3472
15	2.0287	2.4478	1.7147	2.4143	1.749		2.3807
16	2.079	2.4646	2.572	2.4478	1.7652		2.3975
17	2.0119	2.5484	2.4691	2.4143	1.6194		2.3975
18	1.9784	2.838	2.4348	2.4981			2.4143
19	1.9448	2.6513	2.4348				2.4143
20	1.8945	2.6139	2.4348	1.3413	1.2308		2.1795
21	2.1125	2.3137	2.4348	2.1125	1.1984		2.1125
22	2.268	2.2801	2.4006	2.146	1.1336		2.1125
23	2.0119	2.2801	2.4006	2.1125	1.085	2.0576	2.0957
24	.3353	1.9448	2.2801	2.4006	2.1365	1.0974	
Max	2.268	2.838	2.6063	2.5484	2.1365	2.4177	2.4143
Min	.3353	1.6766	1.6289	1.3413	1.085	.9259	1.5257
Avg	1.1352	2.2582	2.3204	2.2642	1.7465	1.3047	2.1907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 212 / MAHADEV NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.3353	.3688	.3086	.3772	.1543	
2	.1341	.3353	.3688	.3086	.3772	.1543	
3	.1341	.3353	.3688	.3086	.3601	.1543	
4	.1341	.3018	.3521	.2743	.3601	.1372	
5	.1341	.3353	.3521	.2743	.3429	.1543	
6	.1341	.3688	.3521	.2743	.3429	.1715	
7	.1341	.3856	.3856	.3429	.3429	.1886	
8	.1341	.4191	.3856	.3772	.3429	.2401	
9	.1509	.4359	.463	.4024	.2949	.3772	.3239
10	.1677	.4359	.463	.4359	.2915		.3239
11	.1677	.4359	.4801	.4359	.2622		.3563
12	.1677	.4359	.3772	.4359	.2458		.3563
13	.3353	.3353	.3086	.218	.2458		.3239
14	.3856	.4359	.3429	.4191	.2622		.3563
15	.3856	.4359	.3429	.4191	.2622		.3725
16	.4024	.4191	.3429	.4191	.2622		.3887
17	.4191	.4115	.3601	.4191	.253		.3887
18	.4191	.4024	.3601	.3856			.4049
19	.4024	.4024	.3772				.4049
20	.4024	.4191	.3429	.2347	.2294		.3725
21	.4024		.3429	.4191	.1966		.3725
22	.3856	.4191	.3772	.4191	.1638		.3563
23	.3688	.4191	.3429	.4024	.1475	.3772	.3563
24	.1006	.3353	.4024	.3429	.3944	.1543	
Max	.4191	.4359	.4801	.4359	.3944	.3772	.4049
Min	.1006	.3018	.3086	.218	.1475	.1372	.3239
Avg	.2543	.3911	.3733	.3599	.2890	.2058	.3639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 202 / IND EST FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0059	1.448	1.2193	1.448	1.3817	1.0974
2		1.0059	1.448	1.3226	1.5074	1.3817	1.1222
3	.2347	1.0608	1.4118	1.1439	1.4746	1.307	1.153
4	.3932	1.0608	1.3611	1.3032	1.4746	1.307	1.3672
5	.4409	1.0608	1.3611	1.3717	1.5089	1.307	1.3283
6	1.0242	1.086	1.3756		1.5927	1.3443	1.2955
7	.3094	1.086	1.5203	1.5424	1.5927	1.419	1.3413
8		1.448	1.5927	1.5592	1.5089	1.419	1.6598
9			2.0119	2.3167	2.0576	2.2443	2.1948
10		2.3034	2.146	2.4874	2.1434	2.3167	2.3899
11		2.332	2.3579	2.4034	2.332	2.5393	2.332
12	.9221	1.9631	2.3167	2.2291			2.1033
13	.8316	1.3717	1.8823	2.0119	1.5775	1.7737	1.5775
14	.8316	2.0058	2.0698	2.2634	1.9631	2.0576	1.9631
15	.8962	2.2436	2.1849		2.1033	2.4874	1.9982
16	.9335	2.2786	2.1704	2.431	2.1033	2.4874	2.2436
17	.8402			2.431	1.989	2.4615	2.1262
18	.8402	2.1948	2.2177	2.3472		2.3411	2.0576
19	.7468	2.0576	2.2634				1.9631
20	.9145	1.5775	1.9418				1.5775
21	1.0974	1.5775	1.7375		1.4022		
22	1.0136	1.5089	1.6644	.9288	1.4022		
23	1.0242	1.5424	1.6644		1.4022		1.6476
24	1.5257	.985	1.4022	1.448	1.5927	1.3321	.9069
Max	1.5257	2.332	2.3579	2.4874	2.332	2.5393	2.3899
Min	.2347	.985	1.3611	.9288	1.4022	1.307	.9069
Avg	.8233	1.5798	1.8065	1.8200	1.7088	1.8282	1.7021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 204 / YASHWANT FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9418	1.267	1.9993	2.0698	1.9605	1.7177	1.8671
2	1.8861	1.1765	1.9616	2.0165	1.8671	1.6804	1.8484
3	1.7924	1.1765	1.9616	1.9022	1.8671	1.6804	1.5546
4	1.6975	1.1765	1.8861	1.7337	1.8671	1.6804	1.3375
5	1.6827	1.1765	1.8861	1.9044	1.8671	1.6804	1.7353
6	1.8298	1.2308	1.8861	1.7375	1.8671	1.7177	1.6827
7	1.4937	1.267	2.037	1.9616	1.8671	1.7924	1.8671
8	1.3565	1.3575	1.9239	1.9616	1.8671		1.829
9			2.2405	2.21	2.2405	2.2405	2.2634
10	.9945	2.0376	2.5393	2.5393	2.5206	2.4646	2.3152
11		2.3152		2.5873	2.6139	2.6063	2.6886
12	.9431	2.2405		2.3339	2.4272	2.5606	2.5133
13	.5658	2.0538	2.3411	2.2405	2.2405	2.1719	2.3152
14	.5658	2.2405	2.268	2.5206	2.3899	2.2443	2.4394
15	.5944	2.4272	2.524	2.6139	2.4646		2.4272
16	.6043	2.4272	2.5606	2.6139	2.4646	2.5339	2.2916
17	.5811			2.6139	2.4646	2.7161	2.6139
18	.6001	2.3152	2.3411	2.5206			2.3899
19	.6602	2.3152	2.4143				2.3152
20	.7621	2.2405	2.1948				1.9418
21	1.0526	2.1658	1.9448				
22	1.1336	2.0911	2.1216	1.587			
23	1.267	2.1658		1.7737	1.7924		2.0911
24	2.037	1.2803	1.9791	2.0058	1.9605	1.7177	1.8861
Max	2.037	2.4272	2.5606	2.6139	2.6139	2.7161	2.6886
Min	.5658	1.1765	1.8861	1.587	1.7924	1.6804	1.3375
Avg	1.1837	1.8247	2.1505	2.1642	2.1373	2.0753	2.1006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 205 / IGM FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5364	1.4575	1.4575	1.5203	1.3889	.6413	1.0456
2	1.4175	1.4251	1.4575	1.3717	1.3117	.6097	.8848
3	1.4118	1.3765	1.3927	1.382	1.2346	.5658	.8916
4	1.3176	1.3765	1.3927	1.3413	1.1574	.5658	.9145
5	1.448	1.3765	1.3603	1.2498	1.1574	.5658	1.0277
6	1.448	1.3765	1.3603	1.2041	1.1574	.6097	1.1949
7	1.3108	1.3765	1.3603	1.3077	1.1574	.679	1.3169
8	1.6461	1.3765	1.3603	1.3748	1.1574	1.0562	1.4632
9			1.7497	1.9204	1.2289	1.9418	2.0485
10	2.0911	.2372	1.7924	1.8778	1.1469	2.0911	2.0698
11				1.7284	.9114	2.0485	1.7497
12	1.6975	1.3108	1.8031	1.6204			1.5364
13	1.3603	1.7528	1.4175	1.2346	.6379	1.7635	1.094
14	1.4403	1.7528	1.6263	1.6667	.9114	1.7375	1.4899
15	1.6604	1.6385	2.0485	1.6975	.9816	2.0485	1.6004
16	1.7695	1.7695	2.1719	1.6975	.9816	2.0911	1.7924
17	1.7284			1.7284	.8413	2.0485	1.6872
18	1.7394		1.6827	1.7284			1.749
19	1.7394		1.922				1.7284
20	1.5023	1.3108	1.9022				1.6842
21	1.5813	1.8107	1.9616				
22	1.5181	1.7436	1.7375		.7011		
23	1.5023	1.6766	2.2405	1.5242	.7011	.5521	1.6004
24	1.4083	1.4232	1.5424	1.6095	1.3717	.631	1.1584
Max	2.0911	1.8107	2.2405	1.9204	1.3889	2.0911	2.0698
Min	1.3108	.2372	1.3603	1.2041	.6379	.5521	.8848
Avg	1.5579	1.4510	1.6700	1.5393	1.0598	1.2359	1.4422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 206 / 11 K.V BHAJI MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1827	1.0288	.9991	.9335	.3372
2			1.0974	1.0166	.9391	.9054	.9877
3			1.0974	.9054	.8859	.8589	.9412
4			1.0242	.8322	.8669	.8589	.9145
5			1.0242	.9724	.9214	.8299	.9015
6			1.0349	1.0174	.9214	.8299	.9877
7			1.0608	.945	.9214	.8589	.9492
8	1.0974		1.2803	1.2178	.9328	1.0456	1.0498
9			1.4118	1.3756	.7712	1.3756	1.1904
10	1.251		1.4327	1.46	.8859	1.2971	1.262
11		1.262	1.4266	1.3146	.8676	1.1105	1.3611
12		1.1919		1.1393			1.182
13		1.0166	1.1641	1.0867	.7468	1.1643	1.0029
14		1.1568	1.267	1.2048	.7842	1.1568	1.2178
15		1.2971	1.3112	1.2403	.8413	1.39	1.2536
16		1.2269	1.4266	1.262	.8048	1.3676	1.3253
17				1.3289	.7682	1.2689	1.267
18		1.3321	1.4266	1.3466			1.2536
19		1.3969	1.358				1.2269
20		1.1568	1.5249				1.2178
21		1.2178	1.2308		.1791	1.2696	
22		1.2536	1.2136	.884	.9877	1.2127	
23		1.182	1.2894	1.2346	.9511	1.1096	1.182
24	1.086		1.182	1.1827	1.0117	.9145	.9282
Max	1.251	1.3969	1.5249	1.46	1.0117	1.39	1.3611
Min	1.086	1.0166	1.0242	.8322	.1791	.8299	.3372
Avg	1.1448	1.2242	1.2485	1.1427	.8494	1.0879	1.0882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 207 / 11 KV JIVESHWAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.57	.5304	.4218	.1867	.5487
2		.5636	.503	.3906	.1886	.4001
3		.5636	.4161	.3858	.1886	.3447
4		.5365	.4973	.3858	.1886	.3864
5		.5365	.4666	.381	.1886	.4534
6		.5365	.591	.381	.1886	.5083
7		.503	.503	.381	.2641	.5087
8		.6371	.583	.3506	.5228	.6878
9		.7209		.4862	.8589	.8328
10		.7449	.7282	.4694	.8326	.8962
11	.7811	.7545	.7621	.5144		.7811
12	.5937		.5792		.7712	.5441
13	.5624	.5182	.3963	.2401	.4755	.4374
14	.6874	.4864	.5401	.2743	.4995	.5937
15	.7186	.5792	.7407	.2743	.631	.6562
16	.7499	.815	.8025	.2804	.8939	.8002
17			.7811	.1753	.6287	.6874
18	.7186	.6241	.7811			.7773
19	.7186	.7682				.7537
20	.7499	.7602				.6722
21	.5761	.4733		.16	.4207	
22	.5441	.5268	.1734	.1638	.3597	.57
23	.5761	.5201	.4877	.1715	.6036	.5506
24		.5441	.6161	.4115	.1715	.3426
Max	.7811	.815	.8025	.5144	.8939	.8962
Min	.5441	.4733	.1734	.16	.1715	.3426
Avg	.6647	.6038	.5739	.3349	.4532	.5971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 201 / 11 KV JANTA TEX.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.0178	3.2065	3.0769	
2		2.9874	3.2065	2.8959	
3		2.8006	3.2065	2.8959	
4		2.8006	3.2065	2.8959	
5		2.8292	3.2065	2.8959	
6		3.0178	3.1121	2.8959	
7		3.0178	3.3951	2.8959	
8		3.1121	3.3951	2.8959	
9		3.1121	3.2065		
10			3.3951		
11			3.2065		
12	2.3777	3.1121	3.0769	3.3008	3.3951
13	2.1719	3.0178	2.8959	2.9874	3.0807
14	2.2624	3.2065	2.8959	3.0178	3.1741
15	2.3529	3.3951	2.8959	3.1121	3.3951
16	2.2624	3.3951	2.8959	2.9874	3.3608
17	2.1262	3.2065	3.0769	2.9569	3.1741
18	2.1719	3.1121	3.0769		3.1741
19	2.1948	3.2065	3.0769		3.3608
20	2.5339	3.2065	3.0769		
21	2.9264	3.2065	3.1674		
22	2.9264	3.2065	3.1674		
23	2.9874	3.2065	3.1674		
24	3.0769	3.0178	3.2065	3.1674	
Max	3.0769	3.3951	3.3951	3.3008	3.3951
Min	2.1262	2.8006	2.8959	2.8959	3.0807
Avg	2.4901	3.0996	3.1425	2.9919	3.2644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 202 / 11 KV DECCAN PROCESS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.9569	3.2674	3.2579	
2		2.9569	3.1741	3.1674	
3		2.7721	3.1741	3.2579	
4		2.8006	3.0807	3.1674	
5		2.7721	2.9569	3.1674	
6			2.9569	3.2579	
7		2.9874	3.2674	3.2579	
8		3.1741	3.1741	3.3484	
9		3.3608	3.3608		
10		2.9874	3.4541		
11			3.4541		
12		3.1741	3.2579	3.3608	3.4541
13	***	3.0807	3.0769	3.1417	2.9264
14	1.4937	3.1417	3.2579	3.3608	3.1741
15	1.4175	3.3265	3.4389	3.5113	3.3608
16	1.4327	3.3608	3.3484	3.5475	3.3608
17	1.448	3.4189	3.4389	3.5475	3.3265
18	1.4842	3.2674	3.4389		3.3608
19	1.587	3.2674	3.3484		3.3608
20	2.3529	3.1741	3.0769		
21	2.9874	3.1417	3.1674		
22	2.9569	3.2341	3.2579		3.1741
23	2.9874	3.1417	3.3484		3.1417
24	3.3484	2.9874	3.2674	3.2579	
Max	14.6062	3.4189	3.4541	3.5475	3.4541
Min	1.4175	2.7721	2.9569	3.1417	2.9264
Avg	3.1752	3.1129	3.2519	3.3073	3.2640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 203 / 11 KV ICH METALLOY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8861	2.0748	1.9004	
2		1.8861	2.0748	1.9004	
3		1.7918	2.0748	1.9909	
4		1.7737	2.0748	1.9909	
5		1.7918	1.8861	1.9004	
6		1.8861	1.8861	1.9909	
7		1.8671	1.8861	1.9909	
8		2.0748	1.8861	1.9909	
9		2.2405	2.2405		
10			2.0748		
11			2.452		
12	1.2136	2.2634	1.9909	2.0538	2.2405
13	1.1203	2.2634	1.9004	1.7918	1.9805
14	1.2012	2.2634	1.9909	2.1472	2.0538
15	1.2136	2.2634	2.1719	2.2405	2.2405
16	1.086	2.2634	2.1719	2.2405	2.2405
17	1.0631	2.2634	1.9909	2.1691	2.2177
18	1.0745	2.2634	2.1719		2.2405
19	1.086	2.1691	2.1719		2.2405
20	1.3717	2.2634	1.9909		
21	1.7918	2.1691	1.9909		
22	1.7737	2.1691	1.9909		2.0538
23	1.8861	2.0748	1.9909		2.1691
24	1.9909	1.8671	2.191	1.9909	
Max	1.9909	2.2634	2.452	2.2405	2.2405
Min	1.0631	1.7737	1.8861	1.7918	1.9805
Avg	1.3748	2.0797	2.0553	2.0193	2.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 204 / 11 SHAHPUR IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.848	2.0748	1.9004	
2		1.848	2.0957	1.8099	
3		1.848	1.8861	1.9004	
4		1.8671	1.9805	1.9004	
5		1.8671	1.8861	1.8099	
6		1.9605	1.8861	1.8099	
7		1.9605	2.0748	1.8099	
8		2.0538	2.0748	1.9004	
9		2.2405	2.1691		
10			2.1691		
11			2.2634		
12	1.2803	2.2634	1.9909	2.0538	2.2405
13	1.1888	2.2634	1.5384	1.7737	1.9605
14	1.2136	2.0748	1.8099	2.0538	2.1472
15	1.226	2.2634	1.9909	2.1691	2.2634
16	.9288	2.2634	1.9909	2.1472	2.2405
17	.904	2.2634	1.9004	2.1472	2.2634
18	.9846	2.0748	1.9909		2.2405
19	1.0002	2.0748	1.9909		2.1472
20	1.5384	1.8861	1.8099		
21	1.8671	2.0748	1.8099		
22	1.8671	2.0957	1.9004		2.0538
23	1.848	2.0748	1.9004		2.0538
24	1.9004	1.8671	2.0748	1.9004	
Max	1.9004	2.2634	2.2634	2.1691	2.2634
Min	.904	1.848	1.5384	1.7737	1.9605
Avg	1.3652	2.0470	1.9691	1.9391	2.1611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 205 / 11 KV RADHA KANHAIYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4434	2.5606	2.4434	
2		2.3529	2.5606	2.3529	
3		2.3529	2.4434	2.4434	
4		2.2386	2.4691	2.4434	
5		2.4025	2.5606	2.3529	
6		2.4949	2.652	2.3529	
7		2.5072	2.7435	2.4434	
8		2.7149	2.7435	2.5339	
9		2.8959	3.1093		
10			2.8959		
11			3.0769		
12	2.3529	2.7435	3.0769	2.652	2.8959
13	1.7375	2.3529	2.2624	2.1719	2.3777
14	1.829	2.7435	2.8959	2.6863	2.7435
15	1.9404	3.0769	2.8959	2.8959	2.9264
16	2.0538	3.1093	2.9864	2.9264	2.8654
17	2.0538	3.0178	2.8959	2.8959	2.8959
18	1.9909	3.0178	2.8959		2.8654
19	1.9204	2.9264	3.5294		
20	2.1719	2.7435	2.6244		
21	2.5072	2.7435	2.6244		
22	2.5339	2.7149	2.6244		2.7435
23	2.5606	2.7149	2.6244		2.5072
24	2.6244	2.5606	2.652	2.4434	
Max	2.6244	3.1093	3.5294	2.9264	2.9264
Min	1.7375	2.2386	2.2624	2.1719	2.3777
Avg	2.1751	2.6759	2.7668	2.5359	2.7579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 206 / 11 KV TARDAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6804	1.6804	1.8099	
2		1.6617	1.6804	1.7194	
3		1.6598	1.6975	1.7194	
4		1.6409	1.6032	1.7013	
5		1.587	1.6032	1.7194	
6		1.587	1.6975	1.6832	
7		1.6409	1.7918	1.6651	
8		1.7737	1.7918	1.6289	
9		1.9231	1.8861		
10			1.9605		
11			1.9605		
12	1.2696	1.6598	1.8099	.9896	1.7364
13	1.086	1.5089	1.5023	1.6032	1.587
14	1.226	1.8861		1.7737	1.7918
15	1.2136	1.8671	1.828	1.8671	1.9044
16	1.307	1.9605	1.7918	1.9605	1.9418
17	1.358	1.8861	1.9366	2.0182	1.9605
18	1.307	1.8861	1.9004		1.8671
19	1.226	1.8671	1.8461		1.7364
20	1.4003	1.8861	1.8099		
21	1.587	1.8671	1.7918		
22	1.6975	1.8861	1.8099		1.8484
23	1.7541	1.8671	1.8099		1.8861
24	1.6651	1.7164	1.7918	1.8099	
Max	1.7541	1.9605	1.9605	2.0182	1.9605
Min	1.086	1.5089	1.5023	.9896	1.587
Avg	1.3921	1.7681	1.7818	1.7113	1.8260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 207 / 11 K.V AMIT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2405	2.2634	2.1719	
2		2.1472	2.2634	2.0814	
3		2.1691	2.0748	2.1719	
4		2.0748	2.0748	2.0814	
5		2.1691	2.0748	2.1719	
6		2.1691	2.0748	2.0814	
7		2.2405	2.2634	2.0814	
8		2.2634	2.2634	1.9909	
9		2.2634	2.2634		
10			2.2634		
11			2.2634		
12	2.0538	2.2634	2.1719	2.2405	2.452
13	2.0165	2.2634	1.9909	2.1691	2.2405
14	1.8099	2.2634	2.0814	2.2634	2.2405
15	1.7375	2.2634	2.1719	2.4272	2.2634
16	1.7918	2.452	1.9909	2.3101	2.2405
17	1.7737	2.2634	1.9909	2.2405	2.2634
18	1.7364	2.2634	1.9909		2.2177
19	1.6975	2.2634	2.0814		2.2177
20	1.8861	2.2634	1.9909		
21	2.0538	2.2634	1.9909		
22	2.1253	2.2405	2.1719		2.2634
23	2.2634	2.2405	2.1719		2.2405
24	2.1719	2.2634	2.2634	2.1719	
Max	2.2634	2.452	2.2634	2.4272	2.452
Min	1.6975	2.0748	1.9909	1.9909	2.2177
Avg	1.9321	2.2411	2.1334	2.1770	2.2640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 208 / 11 K.V. TULJABHAVANI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.9874	3.0178	3.2579	
2		2.8292	3.0178	3.0769	
3		2.8292	3.0483	3.0769	
4		2.8006	3.0483	3.0769	
5		2.8292	3.0178	2.8959	
6		2.9874	3.0178	2.8959	
7		3.0178	3.0178	2.9864	
8		3.2065	3.0178	3.1674	
9		3.2065	3.5837		
10			3.7723		
11		3.1741	3.7723		
12	1.3279	3.2065	3.4389	3.5475	3.678
13	1.1203	1.6032	3.0769	3.2065	3.5837
14	1.2498	3.2065	3.1674	3.3951	3.7723
15	1.2193	3.5837	3.1674	3.3608	3.7342
16	1.2041	3.5837	3.2579	3.5475	3.5475
17	1.0269	3.5837	3.3484	3.5837	3.3608
18		3.3951	3.4389		3.3608
19	1.0669	3.3951	3.4389		3.3951
20	2.1719	3.3951	3.2579		
21	2.8292	3.3951	3.2579		
22	2.9874	3.4294	3.2579		3.3951
23	3.0178	3.3951	3.2579		3.3608
24	3.155	3.0178	3.0178	3.2579	
Max	3.155	3.5837	3.7723	3.5837	3.7723
Min	1.0269	1.6032	3.0178	2.8959	3.3608
Avg	1.8647	3.1330	3.2382	3.2222	3.5188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 209 / 11 K.V YOGASHRAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1736	1.2955	1.6289	
2		1.1603	1.1469	1.267	
3		1.0174	1.1469	1.267	
4		1.0288	.9831	1.267	
5		1.0402	1.1336	1.267	
6		1.2136	1.3565	1.267	
7		1.1469	1.2955	1.267	
8		1.4575	1.2955	1.267	
9		1.6766	1.4403		
10			1.4403		
11			1.6575		
12	1.2955	1.3413	1.6289	1.6385	.8097
13	.6783	.8573	.905		1.2955
14	1.2955	.9831	1.6289	1.2955	1.4746
15	1.406	1.4918	1.6289	1.4746	1.4918
16	1.4575	1.6194	1.8099	1.4918	1.4918
17	1.406	1.5089	1.8099	1.4746	1.4575
18	1.4403	1.5089	1.7194		1.4575
19	1.406	1.2955	1.6289		1.2955
20	1.4746	1.1869	1.6289		1.2955
21	1.4575	1.3717	1.6289		1.3413
22	1.2803	1.5775	1.6289		1.3108
23	1.2955	1.3717	1.6289		1.2955
24	1.267	1.3108	1.2955	1.6289	
Max	1.4746	1.6766	1.8099	1.6385	1.4918
Min	.6783	.8573	.905	1.267	.8097
Avg	1.32	1.2882	1.4484	1.3930	1.3348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 210 / 11 KV New Supereme Feeder SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8111	2.452	2.3529	
2		1.7737	2.2634	2.4434	
3		1.9052	2.2862	2.3529	
4		1.8107	2.3815	2.3529	
5		1.8484	2.4768	2.4434	
6		1.8861	2.452	2.4434	
7		1.9239	2.452	2.4434	
8		2.0936	2.452	2.8959	
9		2.1879	2.9874		
10			3.1121		
11			2.9235		
12	1.267	2.3577	2.7149	3.0178	3.2065
13	1.0936	2.3577	2.2081	2.4646	2.9874
14		2.8292	2.5339	2.7435	2.32
15	1.0402	2.2405	2.6063	3.0556	2.5206
16	.9859	2.572	2.3529	2.3954	2.6595
17	.9457	3.1121	1.828	1.9052	2.9874
18	1.1288	2.452	2.4072		2.5206
19	1.25	2.6406	2.4434		2.3577
20	1.5947	2.9235	1.9909		
21	1.7193	2.0748	1.8099		
22	1.7737	1.8861	2.3529		2.32
23	1.8296	1.8861	2.3891		2.4646
24	1.7556	1.8099	2.452	2.3529	
Max	1.8296	3.1121	3.1121	3.0556	3.2065
Min	.9457	1.7737	1.8099	1.9052	2.32
Avg	1.3653	2.1992	2.4304	2.5109	2.6344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 402 / 33 KV JAY GANGATARA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
23	3.6008
24	3.6008
Max	3.6008
Min	3.6008
Avg	3.6008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 201 / 11 KV KABNOOR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.7147	1.7147	1.6004	1.7147	1.4003	1.448
2	1.6766	1.7147	3.2579	1.6004	1.7147	1.4003	1.448
3	1.6766	1.6289	1.7147	1.6004	1.7147	1.3203	1.448
4	1.6766	1.6289	1.7147	1.6004	1.7147	1.307	1.448
5	1.6766	1.6289	1.7147	1.6004	1.7147	1.307	1.448
6	1.6766	1.6289	1.8861	1.6004	1.7147	1.4146	1.448
7	1.6766	1.7147	1.8861	1.6004	1.7147	1.587	1.448
8	1.6766	1.8861	2.0576	1.6004	1.5432	1.7556	1.448
9	2.0957	1.9719	2.0576	1.829	1.5432	1.8804	.7621
10	2.0957	2.2291	2.1948	2.0576		1.8861	1.448
11	2.1033	2.2291	1.9052	2.0576		1.7528	1.7194
12	1.8604	1.7147	1.829	1.8861		1.5242	1.8804
13	1.5947	1.7147	1.3717	1.7147		1.0669	1.4685
14	1.97	2.0576	1.829	2.0576		1.6461	2.1491
15	2.1262	2.0576	1.9052	2.1948		1.829	2.1491
16	2.1033	2.1948	1.9052	2.1948		1.9814	2.1262
17	2.1033	2.1948		2.0576		1.9814	
18	2.1033	2.0576	1.9814	2.0576		1.9814	
19	2.1262	2.0576	1.9052		.8488		
20	2.0595	1.8861	1.829	1.7147	1.6032		
21	2.0595	2.0576	1.829	2.0576	1.6032	1.6004	
22	2.0814	2.0576	1.829	2.0576	1.6032	1.6004	
23	2.0119	2.0576	1.829	1.8861	1.587	1.6004	
24	1.7604	1.9404	1.7147	1.829	1.7147	1.5089	1.6004
Max	2.1262	2.2291	3.2579	2.1948	1.7147	1.9814	2.1491
Min	1.5947	1.6289	1.3717	1.6004	.8488	1.0669	.7621
Avg	1.9028	1.9177	1.9070	1.8459	1.6033	1.6060	1.5816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 202 / CHANDUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1855	3.2579	3.2579	2.8959	2.7435	2.1472	2.5911
2	3.1855	3.2579	3.2579	2.8959	2.7435	2.1472	2.5911
3	3.1855	3.2579	3.2579	2.8959	2.7435	2.1472	2.5911
4	3.1855	3.2579	3.2579	2.8959	2.7435	2.1472	2.5911
5	3.1855	3.2579	3.2579	2.8959	2.7435	2.1472	2.5911
6	3.1855	3.2579	3.4294	2.8959	2.915	2.2405	2.5911
7	3.1855	3.2579	3.4294	2.8959	3.0178	2.5873	2.5911
8	3.1855	3.6008	3.6008	2.8959	2.572	2.9264	2.5911
9	4.0238	4.1152	4.1152	3.8104	2.0576	4.1152	.9907
10	4.0238	4.2867	4.2524	4.2867		4.1076	4.2067
11	4.0695	4.2867	3.8866	4.3724		3.8104	4.2524
12	3.6008	3.0864	3.658	3.8409		3.2007	3.2236
13	2.652	2.7435	2.7435	2.572			3.0769
14	3.9819	3.6008	3.3532	2.452		3.2769	3.5437
15	3.9847	4.1152	3.658	4.1152		3.4294	3.9866
16	3.94	4.1152	3.658	4.1152		3.5056	3.9438
17	3.8152	4.1152	3.5056	3.9438		3.5056	
18	3.6885	4.1152		3.9781		3.2769	
19	3.898	3.7723	3.4294		1.1203		
20	3.3303	3.4294	3.4294		1.4937		
21	3.7723	3.6008	3.2769	1.3717	2.1253	2.7435	
22	3.7723	3.4008		3.4294	2.1472	2.8197	
23	3.4675	3.6008	3.2769	3.6008	2.1253	2.8197	
24	2.6578	3.5437	3.2579		3.4294	2.1691	2.8197
Max	4.0695	4.2867	4.2524	4.3724	3.4294	4.1152	4.2524
Min	2.652	2.7435	2.7435	1.3717	1.1203	2.1472	.9907
Avg	3.5068	3.5973	3.4659	3.2884	2.4481	2.9176	2.9866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 203 / 11 KV COLLAGE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9221	.9717	.9717	.8383	.9069	.6602	.7621
2	.9221	.8907	.9717	.8383	.9069	.6413	.7621
3	.9221	.8907	.9717	.8383	.9069	.6036	.7621
4	.9221	.8907	.9717	.8383	.9069	.6036	.7621
5	.9221	.8907	.9717	.8383	.9069	.6036	.7621
6	.9221	.8907	.9717	.8383	.8097	.6036	.7621
7	.9221	.9717	.9717	.8383	.8097	.7468	.7621
8	.9221	.9717	1.0364	.8383	.7125	.8764	.7621
9	1.2574	1.2146	1.2308	1.0669	.7125	1.1603	1.2193
10	1.2574	1.2308	1.2308	1.1336		1.2146	1.3717
11	1.186	1.2308	1.1888	1.166		1.2929	1.4022
12	1.1336	1.166	1.1431	1.0364		1.0669	1.1269
13	.8573	.7773	.8383	.7773			1.0898
14	.9221	.9717	.9145	1.1012		.9145	1.0774
15	.9717	1.166	1.1888	1.2308		1.2193	1.2574
16	1.065	1.3032	1.1888	1.2308		1.2193	1.2289
17	1.0802	1.166	1.1431	1.2308		1.2193	
18	1.0669	1.166	1.1431	1.166		1.2193	
19	1.1203	1.1012			.7316		
20	1.1336	1.0364	1.1431	.8421	.7316		
21	1.2003	1.166	1.0669	1.166	.7392	.9907	
22	1.2003	1.166	1.0669	1.166	.7392	.9145	
23	1.2003	1.1336	1.0669	1.1336	.7164	.9145	
24	1.0898	1.1269	.9717	1.0669	.9717	.6535	.9145
Max	1.2574	1.3032	1.2308	1.2308	.9717	1.2929	1.4022
Min	.8573	.7773	.8383	.7773	.7125	.6036	.7621
Avg	1.0466	1.0621	1.0593	1.0096	.8139	.9209	.9873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 205 / DATTA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4251	1.3765	1.3603	1.2193	1.2955	.8402	1.1431
2	1.4413	1.2955	1.3603	1.2193	1.2955	.7468	1.1431
3	1.4251	1.2955	1.3603	1.2193	1.2955	.7392	1.1431
4	1.3765	1.2955	1.3603	1.2193	1.2955	.7316	1.1431
5	1.4251	1.2955	1.3603	1.2193	1.2955	.7392	1.1431
6	1.4413	1.2955	1.4575	1.2193	1.3603	.7392	1.1431
7	1.4251	1.3765	1.4575	1.2193	1.3603	1.0059	1.1431
8	1.4251	1.4575	1.4575	1.2193	1.2308	1.2431	1.1431
9	1.8442	1.7004	1.9433	1.829	1.1012	1.7966	1.7528
10	1.8442	1.8138	1.9433	1.9433		1.829	1.8404
11	1.8519	1.8138	1.829	1.9433		1.9052	.7202
12	1.7404	1.7814	1.7528	1.6194		1.6766	
13	1.2146		1.2193	1.166			1.3441
14	1.5623		1.5242	1.6194		1.6766	1.7394
15	1.7185	1.9204	1.7528	1.8785		1.829	1.7604
16	1.7747	1.9433	1.7528	1.9433		1.829	1.7604
17	1.7966	1.9433	1.7528	1.9433		1.829	
18		1.9433	1.7528	1.8138		1.829	
19	1.7604	1.7814	.1677		.823		
20	1.7814	1.6194	1.6766	1.1012	1.0059		
21	1.7004	1.749	1.6004	1.749	.9955	1.5242	1.5203
22	1.7004	1.749	1.6004	1.6842	.9955	1.3717	1.5203
23	1.6385	1.6194	1.6004	1.6194	.9431	1.3717	1.5565
24	1.5927	1.4918	1.3603	1.6004	1.4575	.9335	1.3717
Max	1.8519	1.9433	1.9433	1.9433	1.4575	1.9052	1.8404
Min	1.2146	1.2955	.1677	1.1012	.823	.7316	.7202
Avg	1.6046	1.6163	1.5168	1.5308	1.1834	1.3422	1.3701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 207 / Chandur Kabnur Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0152	.0152	.4572	.3963	.4214	.0152
2	.0168	.0152	.0152	.4572	.3963	.4515	.0152
3	.017	.0152	.0152	.4572	.3963	.4458	.0152
4	.0168	.0152	.0152	.4572	.3963	.4515	.0152
5	.0168	.0152	.0152	.4572	.3963	.4515	.0152
6	.0168	.0152	.0152	.4572	.0152	.4816	.0152
7	.0168	.0152	.0152	.6097	.0152	.5201	.0152
8	.0168	.0152	.0152	.0152	.0152	.5201	.0152
9	.6706	.7621	.7316	.0152	.0152	.0149	.2286
10	.6706			.0152		.0152	.2315
11	.679	.7316		.0152		.0152	.2469
12	.5401	.7316		.0152		.0152	.2469
13	.5575			.0152		.0152	.2743
14	.6097		.7621	.0171		.0152	.3048
15	.6097		.7621	.0152		.0152	.3048
16	.6173	.6478	.7621	.0152		.0152	.3048
17	.0154	.6097	.5335	.0152		.0152	.0156
18	.0151	.6097	.5335	.0152		.0152	.0156
19	.0151	.0152	.0152		.017		.0156
20	.0151	.0152	.0152	.0152	.0168		.0154
21	.0152	.0152	.0152	.0152	.0168	.0152	.0154
22	.0154	.0152	.4572	.4877	.0166	.0152	.0154
23	.0156	.0152	.4572	.4877	.0168	.0152	.0156
24	.0168	.0156	.0152	.4572	.4572	.0162	.0152
Max	.679	.7621	.7621	.6097	.4572	.5201	.3048
Min	.0151	.0152	.0152	.0152	.0152	.0149	.0152
Avg	.2172	.2153	.2591	.2167	.1722	.1799	.0995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 208 / 11 KV Dhuleshwar Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.5668	.5487	.4572	.5182	.4668	.4572
2	.5868	.5668	.5487	.4572	.5182	.4668	.4572
3	.5868	.5668	.5487	.4572	.5182	.4668	.4572
4	.5868	.5668	.5487	.4572	.5182	.462	.4572
5	.5868	.5668	.5487	.4572	.5182	.462	.4572
6	.5868	.5668	.5182	.4572	.5182	.4668	.4572
7	.5868	.5668	.5182	.4572	.5182	.5487	.4572
8	.5868	.6478	.583	.4572	.4858	.6401	.4572
9	.6706	.7287	.7125	.6859	.4858	.7716	.6859
10	.6706	.7773	.823	.7287		.763	.763
11	.663	.7773	.6859	.7773		.7316	.763
12	.5935	.7545	.6097	.6478			.6001
13	.5935	.5487	.4572	.5487			.5144
14	.6706	.7125	.6859	.7125		.7621	.7716
15	.7545	.7773	.7316	.7773		.7621	.7716
16	.7545	.7773	.7316			.7621	.763
17	.763	.6478	.6859	.7125		.7621	.763
18	.763	.6478	.6859	.7125		.7621	.763
19	.763	.7125	.6859		.4715		.763
20	.6859	.6859	.6859	.583	.4715		.6859
21	.6859	.6859	.6097	.6478	.4668	.4572	.6859
22	.7011	.6859	.6097	.7125	.4668	.5335	.6859
23	.7087	.6478	.6097	.7125	.4382	.5335	.6935
24	.6706	.7087	.5487	.6097	.6478	.4668	.5335
Max	.763	.7773	.823	.7773	.6478	.7716	.7716
Min	.5868	.5487	.4572	.4572	.4382	.4572	.4572
Avg	.6586	.6621	.6217	.6012	.5041	.6024	.6193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 201 / 11 KV HANUMANNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0852	1.2717	1.3077	1.0669	1.2742	.4572	1.0852
2	1.0174	1.2378	1.2742	1.0669	1.2574	.4572	1.0513
3	.9665	1.2378	.5243	1.0669	1.2407	.4572	1.0852
4	.9835	1.153	1.2071	1.0669	1.2407	.4572	1.1361
5	1.0513	1.153	1.1736	1.1431	1.2071	.4572	1.1869
6	1.1191	1.1869	1.2071	1.1736	1.2574	.5182	1.2209
7	1.2717	1.2209	1.2742	1.2193	1.2407	.5487	1.3226
8	1.3904	1.3226	1.3077	1.3717	1.1065	.6859	1.4413
9	1.5769	1.4413	1.5592	1.3717	1.0517	1.3717	1.56
10	1.5939	1.5261	1.448	1.4937		1.448	1.6787
11	1.543	1.4746	1.448	1.749		1.448	1.6617
12	1.2548	1.4232	1.3717	1.6804		1.3717	1.56
13	1.0513	1.1317	1.2193	1.3203		1.1431	1.2717
14	1.3395	1.286	1.448	1.6461		1.326	1.4752
15	1.5261	1.4918	1.448	1.6975		1.3717	1.6108
16	1.543	1.5089	1.448	1.7661		1.3717	1.6617
17	1.5091	1.4586	1.448	1.6598		1.3717	1.6448
18	1.5091	1.5089	1.3717	1.6975		1.448	1.6278
19	1.4243	1.4083	1.2955				1.6278
20	1.4074	1.3748	1.0364	.7373		1.0513	1.5261
21	1.4582	1.4083	1.0974	1.5604	.583	1.4074	1.5089
22	1.4413	1.358	1.2193	1.4746	.5487	1.3565	1.4251
23	1.3565	1.4746	1.2193	1.5261	.5487	1.3056	1.3916
24	1.2378	1.3226	1.3413	1.0669	1.3077	.4572	1.153
Max	1.5939	1.5261	1.5592	1.7661	1.3077	1.448	1.6787
Min	.9665	1.1317	.5243	.7373	.5487	.4572	1.0513
Avg	1.3191	1.3492	1.2790	1.3749	1.0665	1.0125	1.4131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 203 / 11 KV SWAMI APPARTMENT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.78	.8048	.6097	.7545	.381	.7122
2	.6274	.7461	.7712	.6097	.7209	.381	.6783
3	.5935	.7122	.5197	.6097	.7042	.381	.6274
4	.6443	.6783	.7545	.6097	.7042	.381	.6104
5	.6783	.6783	.7545	.6097	.6874	.381	.6443
6	.7461	.6952	.7712	.6706	.6874	.381	.6783
7	.8139	.7122	.7377	.7621	.6874	.4268	.7461
8	.9156	.9156	.7712	.9145	.7377	.6097	.7122
9	.9665	1.0004	.9724	.9755	.6554	.9145	.8817
10	1.0174	1.0174	.9145	.9907		.9907	.9835
11	.9156	.9945	.9907	1.0631		.9907	.9496
12	.8648	.9774	.9907	.9945		.9145	.8817
13	.5596	.6344	.7621	.7373		.6097	.6104
14	.8309	.8916	.9145	.9945		.7926	.9835
15	1.0174	1.0631	.9145	1.0288		.9145	.9835
16	.9835	1.0562		1.0631		.9907	1.0174
17	.9496	1.0631	.945	1.0562		.9907	1.0174
18	.9665	1.0631	.9145	1.0631		.9907	1.0174
19	.9496	.9945	.9145				1.0174
20	.9156	.9088	.8383	.7202	.5487	.017	.9665
21	.9496	.9088	.9145	.9088	.5487	.8139	.8886
22	.9156	1.046	.9145	.9259	.5144	.8817	.9724
23	.8817	.8916	.7621	.9088	.5144	.8478	.9556
24	.7122	.8139	.8383	.6097	.788	.381	.7461
Max	1.0174	1.0631	.9907	1.0631	.788	.9907	1.0174
Min	.5596	.6344	.5197	.6097	.5144	.017	.6104
Avg	.8372	.8851	.8429	.8450	.6610	.6680	.8451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 202 / 11KV SOOT GIRNI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	3.3532
Max	3.3532
Min	3.3532
Avg	3.3532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 203 / 11KV URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	3.0121
Max	3.0121
Min	3.0121
Avg	3.0121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 205 / 11KV JAWHARNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	2.7854
Max	2.7854
Min	2.7854
Avg	2.7854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 209 / 1-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6401
Max	.6401
Min	.6401
Avg	.6401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 210 / 11 KV GANGA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	4.3343
Max	4.3343
Min	4.3343
Avg	4.3343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 211 / 11 KV INDUSTRIAL EXPRESS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 401 / 33 KV KABNOOR (METE&KSL)
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	1.1317
Max	1.1317
Min	1.1317
Avg	1.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 404 / 33 KV KURUNDWAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	5.407
Max	5.407
Min	5.407
Avg	5.407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 405 / 33 kV Shiradwad

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	13.7174
Max	13.7174
Min	13.7174
Avg	13.7174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 407 / 33KV Shahapur Estate
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	11.9427
Max	11.9427
Min	11.9427
Avg	11.9427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 201 / 11 kv Chokak Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5967	.7625		.663	.0663		.0663
2	.5967	.663		.5967	.0663		.0663
3	.5967	.663	.663	.5636	.064		.0663
4	.663	.663	.663	.3315	.0663		.0663
5	.7956	.7625		.3315	.064		.064
6	.8453	1.0277		.663	.0663		.0663
7	.8453	.9945	.7956	.663	.0829		
8	.0829	.0663	.0829	.0663	.0663		.0663
9	.0663	.0663	.0663	.0829	.4144		.2984
10	.0663				1.0277	.149	
11	.0663				1.0927	.2815	.1989
12					1.0762	.3311	.2321
13	.0663				.8278	.4636	.2984
14		.0663			.9106	.3808	.2984
15	.0663		.0829	.0829	.8775	.5132	.431
16	.0663	.0663	.0829	.0663	.7616	.5464	.3978
17	.0663	.0829	.0663	.0663		.0829	
18	.0663	.0663		.0663		.0995	.1326
19	.0663	.0829	.0829				.1326
20	.0995	.0829	.0829				.1326
21	.0995	.0829	.0995				.1326
22	.8951	.8619	.9945	.0829		.0663	
23	.8951	.7625	.9282	.0663		.0663	.116
24	.5138	.8288		.7956	.0663		.0663
Max	.8951	1.0277	.9945	.7956	1.0927	.5464	.431
Min	.0663	.0663	.0663	.0663	.064	.0663	.064
Avg	.3692	.4554	.3608	.3243	.4469	.2710	.1665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 202 / 11KV Mudshingi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5135	1.4335	1.4712	1.4146	1.3203	.8299	1.1317
2	1.4757	1.3957	1.3957	1.358	1.2826	.8299	1.094
3	1.4757	1.358	1.358	1.3203	1.2826	.8299	1.094
4	1.4378	1.358	1.358	1.2826	1.2826	.8299	1.094
5	1.4757	1.358	1.358	1.3203	1.358	.9054	1.094
6	1.4757	1.4146	1.5089	1.358	1.5089	.9808	1.1317
7	1.4	1.358	1.4146	1.3203	1.4712	1.094	1.2449
8	1.2865	1.5466	1.3203	1.4712	1.4712	1.0185	1.4335
9	1.094	1.5844	1.2449	1.5135	1.3621	1.0216	1.4335
10	1.2826	1.6221	1.4335	1.5513	1.7027	1.1351	1.3957
11	1.1883	1.6975	1.4712	1.7027	1.627	.9934	1.4712
12	1.2826	1.6975	1.6221	1.7027	1.7027	1.8162	1.5089
13	1.2826	1.7353	1.5466	1.5513	1.5892	1.7405	1.5089
14	1.358	1.8861	1.5844	1.7405	1.4946	1.7027	1.5466
15	1.358	1.9616	1.6032	1.7405	1.5513	1.8919	1.4712
16	1.3014	1.9239	1.6975	1.6648	1.8162	1.627	1.4335
17	1.3243	1.5844	1.6598	1.7027	1.8107	1.0374	
18	1.3243	1.5892		1.3243		1.0374	1.6975
19	1.7027	1.8162	1.8484				1.9239
20	1.8919	2.1378	1.9239				2.0748
21	1.9675	2.081	1.8861			1.7353	1.8107
22	1.8484	1.9616	1.6975	1.7353	.3206	1.4712	
23	1.6221	1.6975	1.5466	1.6221	.9431	1.3203	1.5844
24	1.5135	1.5089	1.5089	1.4712	1.3957	.8676	1.2071
Max	1.9675	2.1378	1.9239	1.7405	1.8162	1.8919	2.0748
Min	1.094	1.358	1.2449	1.2826	.3206	.8299	1.094
Avg	1.4535	1.6545	1.5417	1.5175	1.4147	1.2144	1.4266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 203 / 11 KV HERLE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2383	1.2773	1.3492	1.4289	1.4891	1.1088	1.2313
2	1.1865	1.193	1.2651	1.3855	1.35	1.0708	1.1188
3	1.1758	1.1763	1.2582	1.334	1.3111	1.0578	1.1035
4	1.1667	1.1702	1.2376	1.2544	1.2936	1.0371	1.0906
5	1.1948	1.2247	1.2022	1.3645	1.3476	1.0624	1.1252
6	1.0408	1.342	1.3489	1.4898	1.4332	1.1269	1.2986
7	.6341	1.2765	1.3241	1.4994	1.3799	1.0498	1.2773
8	1.1205	1.1915	1.2151	1.323	1.2544	.519	1.1683
9	1.0662	1.1442	1.1742	1.2527	1.1858		1.0699
10	1.0147	1.1191	1.2479	1.2693	1.248		1.1244
11	1.094	1.1765	1.2874	1.3833	1.3446		1.2064
12	.9534	1.2755	1.3634	1.4853	1.3211	.8586	1.3024
13	.8124	1.2729	1.3367	1.3896	1.4054	1.4653	1.3245
14	1.041	1.1991	1.3593	1.3447	1.4565	1.6294	1.3481
15	1.1468	1.2037	1.3251	1.3797	1.3896	1.7409	1.3527
16	1.1342	1.1966	1.3372	1.4291	1.4868	1.6632	1.3694
17	1.299	.9951	1.3996	1.4246	1.5081	1.5368	.7446
18	1.2906	.9632	.7423	1.4617	.7468	1.4472	1.4274
19	1.3422	.4931	1.3934	.2629		.7156	.7964
20	1.5527	1.7259	1.9376	.5876			1.7402
21	1.5638	1.9913	1.9376	.2004		1.502	1.8073
22	1.544	1.8446	1.8202	1.8021		1.6145	.8932
23	1.5109	1.6545	1.6461	1.8499	.0488	1.4617	1.6909
24	1.3693	1.4883	1.5364	1.6336	1.0519	1.2822	1.4681
Max	1.5638	1.9913	1.9376	1.8499	1.5081	1.7409	1.8073
Min	.6341	.4931	.7423	.2004	.0488	.519	.7446
Avg	1.1872	1.2748	1.3769	1.3015	1.2526	1.2475	1.2533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 204 / 11Kv Halondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1688	.1677	.1677	.1677	.6613	.6104	.4748
2	.1688	.1677	.1677	.1677	.6613	.6783	.4748
3		.1677			1.2826	.6783	.4748
4	.1688	.1677		.1677	.6443	.6783	.4748
5	.1688	.1677		.1677	.6613	.7461	.4748
6		.1677			.0848	.8139	.5087
7	.1688	.1677			.0848	.8817	.5426
8	.1857	.1509	.1677	.1677	.0848	.9496	.5426
9	3.103			2.8021	.1013	.1182	.0514
10	3.1708			1.4517	.135	.135	.0514
11	3.1708	2.9165	3.1878	1.9412	.135	.1182	.1357
12	3.103	2.9673	3.086	1.8568	.1182	.1182	.1372
13	2.8487		2.7639	1.8062	.1182	.1182	.1372
14	2.8487		2.5265	2.0762	.135	.1182	.12
15	2.696	.1526	2.6113	1.9412	.135	.1182	.1372
16	2.6282	2.8487	2.5434	1.9412	.135	.1182	.1372
17	.1738	2.8696	1.2346	.1519	.1372	.6371	
18	.1519	2.6164		.1519		.1174	.1174
19	.1857	.1519	.1677				.1174
20	.2026	.1857					.1174
21	.1857	.1857	.1677			.0671	.1174
22	.2012	.1677	.1677	.6783		.0678	
23	.1677	.1677	.1677	.6783		.0678	.1187
24	.1857	.1677	.1677	.1677	.6783	.1696	.0678
Max	3.1708	2.9673	3.1878	2.8021	1.2826	.9496	.5426
Min	.1519	.1509	.1677	.1519	.0848	.0671	.0514
Avg	1.1842	.8361	1.2863	1.0268	.3330	.3694	.2514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 205 / 11Kv Rukadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1546	2.5377		2.2291	.0347		.052
2	2.1198	2.4348		2.1262	.0347		.052
3	2.1893	2.3663	2.0919	2.0576	.0347		.052
4	2.2588	2.3663	2.0919		.0347		.052
5	2.3631	2.4006			.0347		.052
6	2.4326	2.4348			.0347		.052
7	2.2936	2.2977	2.2634		.0347		.052
8	.5213	.0686	.0514	.0686	.0347		.0343
9	.052	.0693	.052		2.3457		1.7337
10	.0693	.052		.0695	2.4673	1.946	1.387
11	.0693	.052		.0695	2.5542	1.8765	1.4563
12	.0693	.0347		.0869	2.5021	1.3553	2.0111
13	.0693			.0521	2.4847	1.4595	2.0111
14	.0693	.0693		.0521	2.7627	1.7723	2.0458
15	.0693	.0693	.0867		2.7279	1.9634	2.0111
16	.0693	.0693	.052	.0695	2.3631	1.9113	1.9765
17	.0695	.0695	.0686	.0695	.0678	.0686	
18	.0869	.0695		.0695		.0514	.0514
19	.0695	.0521	.0686				.0514
20	.0695	.0695	.0686				.0514
21	.0695	.0695	.0686			.0686	.0514
22	2.572	2.4006	2.4691	.0347		.0867	
23	2.6063	2.2291	2.4348	.0347		.0867	.052
24	2.1719	2.6063		2.332	.0347		.052
Max	2.6063	2.6063	2.4691	2.332	2.7627	1.9634	2.0458
Min	.052	.0347	.0514	.0347	.0347	.0514	.0343
Avg	1.0244	1.0821	.9129	.6281	1.1438	1.0539	.6973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 201 / 11 KV Nimshirgaon AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.4267	.061	.5791	.0305	.1372	.0305
2	.1524	.4115	.061	.5791	.0305	.1372	.0305
3	.1524	.4115	.3658	.5791	.0305	.1372	.0305
4	.2286	.4115	.442	.6096	.0305	.1372	.0305
5	.2286	.442	.3658	.6401	.0305	.1372	.0305
6	.6249	.7925	.061	.884	.0305	.1676	.0305
7	.884	1.0822	1.0212	1.2041	.0305	.1676	.0305
8	.4572	.0457	.1372	.2134	.0457	.1676	.0305
9	.1372	.061		.1372	.3658	.4267	.1524
10	.0457	.061	.061	.1219	.5487	.5944	.3201
11	.061	.0457	.061	.0457	.5487	.4725	.2896
12	.061	.061	.0457	.0457	.3048	.5182	.3048
13	.0457	.0457	.0457	.0305	.5182	.4877	.3048
14	.061	.0457	.0457	.061	.6858	.5334	.3048
15	.061	.061	.0457	.0914	.6858	.4572	.3201
16	.0457	.061	.061	.1219	.7316	.5487	.3353
17	.0457	.061	.0762	.061	.442	.5791	.2896
18	.1524	.061	.0457	.061		.3048	.1705
19	.061	.061	.061	.0762	.0762		.1524
20	.1372	.1372	.1372		.1981		.1676
21	.1372	.1372	.1372		.1676		.0762
22	.7011	.7163	.5182		.1676		.0762
23	.6401	.6553	.6553		.1676		.1524
24	.4725	.442	.3658	.2743	.1067	.061	.1067
Max	.884	1.0822	1.0212	1.2041	.7316	.5944	.3353
Min	.0457	.0457	.0457	.0305	.0305	.061	.0305
Avg	.2394	.2807	.2121	.3208	.2598	.3249	.1570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 202 / 11 KV Alate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3906	.5624	.25	.5937	.1094	.0914	
2	.3906	.5624	.1875	.5468	.1094	.0914	
3	.3906	.5468	.3749	.4687	.1094	.0914	
4	.4374	.6874	.4999	.4999	.1094	.0914	
5	.5937	.6874	.1875	.6405	.1406	.0914	
6	.7811	1.1248	.2439	.7811	.1406	.1219	
7	.9374	1.3748	1.0974	1.1717	.1406	.1219	
8	1.0155	.1718	.1829	.1875	.1562	.0937	
9	.1875	.1829		.2031			
10	.2031	.1829	.1875	.2187		.2187	.1875
11	.1562	.1524	.1562	.2031		.25	.4687
12	.1406	.1219	.1562	.1677		.4374	.4062
13	.1562	.1524	.1981	.1562		.3125	.4062
14	.1562	.1372	.1829	.1718		.4374	.4374
15	.1875			.1677		.4687	.6249
16		.1715		.1677	.6859	.4687	.6093
17				.1718	.2439	.3048	.1219
18	.25	.2439	.2343	.2187			.1524
19	.2343	.2439	.25				.1406
20	.25	.2439	.25		.1219		.2343
21	.2656	.2439	.25	.0625	.061		.2343
22	.8535	.7316	.7968	.0625			.1875
23	.6874	.6249	.6249	.125	.1219		.1562
24	.3906	.5937	.1875	.6249	.1094	.0914	
Max	1.0155	1.3748	1.0974	1.1717	.6859	.4687	.6249
Min	.1406	.1219	.1562	.0625	.061	.0914	.1219
Avg	.4116	.4429	.3249	.3460	.1685	.2226	.3120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 203 / 11 Kv Atigre Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	.3772	.415	.4338	.3772	.3395
2		.4527	.3772	.3961	.415	.3395	.3395
3		.4338	.3772	.3961	.415	.3395	.3395
4		.4338	.3772	.3772	.415	.3772	.3395
5		.4338	.4115	.415	.4338	.3772	.3584
6	.4338	.4338	.4115	.4527	.4338	.415	.3772
7	.4527	.4338	.3772	.3961	.3772	.3772	.3772
8	.2829	.3772	.3429	.3772	.3772	.3772	.3395
9	.2452	.3772		.3961	.3772	.415	.3395
10	.2829	.3772	.3584	.3721	.415	.3772	.3395
11	.2263	.415	.4338	.4338	.3772	.3772	.3772
12	.3018	.415	.3961	.3772		.3772	.3395
13	.2896	.3584	.3018	.3584	.3584	.3584	.3395
14	.3018	.3584	.3772	.3584	.4338	.3772	
15	.3206	.415	.3772	.3961	.4527	.415	
16	.3206		.3772	.3961	.4527	.3961	
17	.3018		.3961	.3395	.4527	.3961	
18	.3018		.4338	.5093			
19	.3961		.4904				
20	.547		.4904		.5281		.4904
21	.5281		.4715		.4904		
22	.5093		.4715	.4715	.4527		.415
23	.5093		.4527	.415	.4527		.415
24	.4527	.4715	.3658	.415	.4338	.3772	.3772
Max	.547	.4715	.4904	.5093	.5281	.415	.4904
Min	.2263	.3584	.3018	.3395	.3584	.3395	.3395
Avg	.3729	.4150	.4020	.4030	.4275	.3804	.3672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANANGALE

Feeder No / Name : 206 / Jathar Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.5623	1.6385	1.5242	1.6766	1.6766	1.6194
2	1.6194	1.5242	1.6766	1.5242	1.6385	1.6385	1.6194
3	1.6194	1.5242	1.6004	1.6194	1.6004	1.6004	1.6004
4	1.6385	1.5242	1.6385	1.6004	1.6004	1.6004	1.7147
5	1.6385	1.6004	1.5623	1.6194	1.6004	1.6385	1.5242
6	1.7147	1.7147	1.5623	1.6194	1.6385	1.6004	1.5242
7	1.6194	1.5623	1.5623	1.7147	1.6004	1.6766	1.6194
8	1.3336	1.5623	1.5242	1.5242	1.5623	1.4098	1.6194
9	1.1431	1.6004		1.5242	1.6004	1.6766	1.5242
10	1.105	1.5623	1.5242	1.6766	1.6385	1.7147	1.6766
11	1.1431	1.5623	1.5242	1.7147	1.5623	1.5242	1.6766
12	1.1431	1.7147	1.5242	1.5242		1.6194	1.5623
13	1.1431	1.5242	1.5242	1.6194	1.5242	1.5242	1.2193
14	1.2003	1.5623	1.5242	1.6575	1.7147	1.5242	1.5623
15	1.3336	1.5242	1.5242	1.7147	1.6766	1.6194	1.5623
16	1.2955	1.2193	1.5242	1.6004	1.7147	1.7147	1.5623
17	1.2955	1.2803	1.6194	1.6194	1.2803	1.7147	1.5623
18	1.2955	1.3108	1.5242	1.6385			1.5623
19	1.3336	1.2803	1.6194				1.5623
20	1.5242	1.3108	1.7147	1.6766	.9145		1.5242
21	1.5242	1.2498	1.7147	1.6766	1.2803		
22	1.5623	1.3413	1.6194	1.6766	1.2803		
23	1.6004	1.7147	1.6194	1.6385	1.2803		1.6766
24	1.5242	1.6004	1.6004	1.5242	1.5623	1.3108	1.5242
Max	1.7147	1.7147	1.7147	1.7147	1.7147	1.7147	1.7147
Min	1.105	1.2193	1.5242	1.5242	.9145	1.3108	1.2193
Avg	1.4194	1.4972	1.5855	1.6186	1.5213	1.5991	1.5727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 207 / 11KV ALATE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.4715	.5144	.5658	.5281	.4904	.3772
2	.6036	.4527	.4268	.9054	.5093	.4904	.3772
3	.5658	.4338	.5144	.5658	.4904	.4904	.3772
4	.5658	.4338	.4458	.5658	.5093	.5281	.3772
5	.5658	.4527	.4801	.5847	.5281	.5281	.3961
6	.5658	.4527	.5487	.6036	.5847	.5658	.415
7	.5281	.4715	.5487	.6036	.547	.6036	.4338
8	.415	.4715	.5487	.6036	.4904	.5281	.4527
9	.3961	.6036		.7545	.679	.6413	.6602
10	.3961	.7356	.811	3.0178	.7545		.8488
11	.3772	.8488	.7922	.8865	.8676	.6602	.8676
12	.3772	.8299	.8299	.811		.9054	.8299
13	.3584	.679	.6602	.7545	.811	.8488	.6036
14	.3772	.7922	.7922	.8299	.8676	.8299	.811
15	.415	.8676	.7922	.8676	1.0185	.9431	.8299
16	.3961	.6687	.8488	.811	.7888		.7733
17	.3961			.7356	.8573	.9997	.7545
18	.4338		.811	.8299			.6979
19	.5093		.679				
20	.5847		.6602		.5658		.7356
21	.6036		.6413		.4904		
22	.547		.6602	.4904	.5658		.679
23	.5281		.6224	.5658	.5658		.6602
24	.6036	.4904	.5487	.5658	.5281	.5281	.3772
Max	.679	.8676	.8488	3.0178	1.0185	.9997	.8676
Min	.3584	.4338	.4268	.4904	.4904	.4904	.3772
Avg	.4912	.5974	.6444	.8056	.6451	.6613	.6061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 208 / Laxminagar Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0724	.0724	.0724	.0724	.0724	.0724
2	.0905	.0724	.0724	.0724	.0724	.0724	.0724
3	.0905	.0724	.0724	.0724	.0724	.0362	.0724
4	.0905	.0762	.0362	.0905	.0724	.0362	.0905
5	.0905	.0724	.0762	.1086	.0724	.0724	.1086
6	.1086	.0724	.0724	.1086	.0905	.0724	.1086
7	.1086	.0724	.0724	.1086	.0724	.0724	.1086
8	.1086	.0905	.1086	.1086	.0724	.1086	.1086
9	.1086	.0724		.1086	.0724	.0724	.1086
10	.0724	.0724	.1086	.0905	.0724	.1086	.0724
11	.0724	.0724	.1086	.0724	.0724	.1086	.1086
12	.0724	.0724	.0724	.0724		.0724	.0543
13	.0724	.0724	.0724	.0724		.0724	.0543
14	.0724	.0724	.1086	.0724		.1086	.0532
15	.0724	.0724	.1086	.0724		.1086	.0724
16	.0724	.0686	.1086	.0724	.0686	.1086	.0724
17	.0724	.0686	.0724	.0724	.0686	.0724	.0724
18	.1086	.0686	.1086	.0724			.0724
19	.1086	.0686	.1086				.0905
20	.1086	.1029	.1086	.0905			.1086
21		.1029	.1086	.1086	.0686		.1086
22	.0905	.0686	.1086	.1086	.0686		.1086
23	.0905	.1086	.0905	.0754	.0686		.0724
24	.1086	.0724	.1086	.0724	.0724	.0686	.0905
Max	.1086	.1086	.1086	.1086	.0905	.1086	.1086
Min	.0724	.0686	.0362	.0724	.0686	.0362	.0532
Avg	.0905	.0766	.0907	.0859	.0723	.0802	.0859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 201 / 11 KV Hingangaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.0381	.0339		1.1401	1.0029	.9979
2		.0381	.0339		1.1401	1.0631	
3	.0354	.0381	.0339		1.1401	1.0517	.8871
4	.0354	.0381	.0339		1.1401	1.1104	
5	.0354	.0381	.0339		1.1401	1.1946	.961
6	.0354	.0381	.0339		.0381	1.267	.9979
7	.0354	.0381	.0339		.0381	1.4998	1.1458
8	.0354	.0381	.0339		.0381	1.3611	
9	1.2548		2.2131	2.2382	.0343	.0366	
10	1.3904		2.2382	2.0348	.0377	.0358	
11	1.7635		2.0348	1.6956	.0377		
12			1.95	1.8313	.0377	.0354	
13	1.8313		1.6766	1.7635			
14	1.8652		1.8313	1.7295	.0373		
15	1.8991		1.8442	1.7295	.0373		
16	1.8991	1.8604	1.7604	1.6956	.0373		.0343
17	.0381	.0339	.0354	.0381	.0377		.037
18	.0381	.0339	.0354	.0381			
19	.0381	.0339	.0354		.0373		.037
20	.0381	.0339	.0354	.0381			.0366
21	.0381	.0339	.0354	.0381	.0377		.0366
22	.0381	.0339	.0354	1.1736	.0373	.0354	
23	.0381	.0339	.0354	1.1869	.0373	.0354	.0366
24		.0381	.0339	.0354	1.1736	.0358	.037
Max	1.8991	1.8604	2.2382	2.2382	1.1736	1.4998	1.1458
Min	.0354	.0339	.0339	.0354	.0343	.0354	.0343
Avg	.5913	.1436	.6709	1.1511	.3540	.6975	.4371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 202 / 11 KV Warana Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5646	2.8323		1.275	.2107	.2092	.2237
2	1.3138	2.7374		1.2689	.2107	.2214	.1105
3	2.4874	2.6863	2.5036	1.2666	.2092	.2202	.2214
4	2.5143	2.6658	2.6346	1.2681	.2088	.2206	.112
5	2.5534	2.7191	2.6318	1.2689	.2111	.2214	.2222
6	2.7877	2.8517	1.4175	1.3138	.2134	.2248	.2305
7	2.8098	2.8475	1.8881	1.3405	.1928	.224	.1976
8	.2221	.1877	.2313	.1113	.2126	.2179	.1006
9	.2108	.0907	.2157	.1884	2.7526	2.2817	.6744
10	.2054	.08	.2111	.19	3.6797	3.007	.9465
11	.2092	.0815	.1989	.216	3.9796	2.9636	.9145
12	.2755	.0831	.2172	.1915	3.7601	1.5905	.8954
13	.1893	.154	.2259	.1862	3.4463	2.9902	.8558
14	.1893	.1892	.2267	.1892	3.3132	1.4304	.8505
15	.1269	.1991	.2137	.2022	3.3979	1.4335	.8337
16	.1892	.177	.2122	.193	3.2392	1.4068	.8604
17	.1816	.1577	.2191	.1874	1.6998	1.4068	.6579
18	.154	.1509	.2198	.1844		.0899	.1907
19	.1962	.197	.2305	.0899	.17	.0038	.193
20	.2069	.2015	.2298	.1867	.1174	.0983	.224
21	.5182	.4056	.5216	.2164	.1945	.1174	.2202
22	3.04	2.9441	2.5785	.2175	.2053	.2267	.112
23	3.0245	2.8727	2.6427	.2168	.2	.2229	.1996
24	2.7814	2.2365	1.2971	1.3161	.2137	.2118	.2138
Max	3.04	2.9441	2.6427	1.3405	3.9796	3.007	.9465
Min	.1269	.08	.1989	.0899	.1174	.0038	.1006
Avg	1.2063	1.2395	.9531	.5535	1.3930	.8850	.4275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 203 / 11KV Kumbhoj Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6024	.6535	.5373		.6283	.5121	.5544
2		.6535	.5373		.6283	.4755	
3	.5316	.6535	.5014		.6348	.4706	.5544
4	.6024	.6535	.5014		.6348	.4706	
5	.6733	.6535	.5373		.6722	.543	.5544
6	.6733	.7023	.6805		.7095	.6584	.5914
7	.6733	.5975	.5731		.5975	.6089	.5544
8	.567	.5228	.5373		.5601	.439	
9	.4252		.4805	.5014	.5258	.4755	
10	.4298		.5228	.5731	.543	.4252	
11	.4656		.5175	.5373	.6154	.4961	
12	.5014		.5601	.5765	.543	.567	
13	.5731		.6154	.6089			
14	.5373	.6024	.5853	.6089	.6219		
15	.5731	.567	.5914	.6089	.6154		
16	.5731	.6379	.5975		.6219		
17	.5914	.6447	.5316	.6348	.6219		.5914
18	.5975	.6089	.7087	.7392			.5914
19	.7468	.7522	.7442		.6516		.7392
20	.8871	.8954	.7442	.7842			.8048
21	.8145	.8238	.7442	.7842	.8413		.8048
22	.8402	.788	.6733	.7468	.6878	.6733	
23	.7392	.7164	.6733	.7468	.695	.567	.5853
24	.6024	.7095	.6089	.6379	.6283	.5792	.5544
Max	.8871	.8954	.7442	.7842	.8413	.6733	.8048
Min	.4252	.5228	.4805	.5014	.5258	.4252	.5544
Avg	.6183	.6756	.5960	.6492	.6323	.5308	.6234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 204 / 11 KV Bahubali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.5087			.0335	.0339	
2		.4694			.0335	.0343	
3	.3366	.4748	.4144		.0335	.0343	
4	.3544	.4694	.3978		.0509	.0339	
5	.4252	.503	.431		.0509	.0678	
6	.5138	.5426			.0503	.0857	
7	.5847	.5596	.4144		.0503	.1029	
8	.0532	.0503	.0663		.0335	.0848	
9	.0497		.0503	.0497	.3353	.2883	
10	.0497		.0335	.0332	.5801		
11	.0332		.0335	.0332	.6203	.4607	
12	.0497		.0503	.0332	.5967	.4607	
13	.0332	.0354	.0335	.0332	.5415		
14	.0332	.0354	.0335	.0332	.4694		
15	.0332	.0354	.0335	.0332	.4359		
16	.0332	.0354	.0335	.0332	.4239		
17	.0339	.0332		.0335	.0686		.037
18	.0503	.0332	.0532	.0339			.037
19	.0503	.0497	.0532		.1029		.037
20	.0671	.0497	.0709				.0366
21	.0678	.0497	.0709	.0671	.052		.0366
22	.5765	.6464	.6379	.0678	.0351		
23	.5426	.6464	.691	.0509	.0343		.0366
24		.503		.5316	.0503	.0335	
Max	.5847	.6464	.691	.5316	.6203	.4607	.037
Min	.0332	.0332	.0335	.0332	.0335	.0335	.0366
Avg	.1966	.2865	.1896	.0762	.2129	.1434	.0368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 205 / 11 KV Narande Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1871	1.3032			.1715	.156	
2		1.3375			.1715	.156	
3	1.1517	1.3375	1.0402		.1715	.156	
4	1.1517	1.3717	1.0402		.1715	.1578	
5	1.2226	1.3717	1.0749		.1886	.1578	
6	1.3466	1.5089			.1886	.1578	
7	1.3998	1.406	1.0056		.1715	.1578	
8	.1772	.1715	.156		.1543	.156	
9	.1734		.1715	.156	1.2574	1.0802	
10	.1734		.1543	.1734	1.6126		
11	.1734				1.7164	1.5769	
12	.1734						
13	.1734	.1772			1.4575	1.4529	
14	.1696	.1949	.1715		1.4737		
15	.1734		.1715	.1734	1.4575		
16	.1734	.1772	.1715	.1734	1.4232		
17	.1715	.1734		.1715	.1772		.1848
18	.1886	.1734	.1772	.1715			.1848
19	.1886	.1907	.1949				.1848
20	.1886	.1907	.1949				.1829
21	.1886	.1907	.1949	.1886	.1578		.1829
22	1.2517	1.335		.1886	.1578		
23	1.2003	1.283	.9391	.1715	.1578		.1829
24		1.3032		1.1694	.1715	.1543	
Max	1.3998	1.5089	1.0749	1.1694	1.7164	1.5769	.1848
Min	.1696	.1715	.1543	.156	.1543	.1543	.1829
Avg	.5635	.7999	.4572	.2737	.6305	.4600	.1839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 206 / 11 KV Kumbhoj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.0381	.0339		.3052	.2507	.037
2		.0381	.0339		.2683	.2507	
3	.0354	.0381	.0339		.2713	.2481	
4	.0354	.0381	.0339		.3018	.2481	
5	.0354	.0381	.0339		.3018	.2865	.037
6	.0354	.0381	.0339		.0381	.2835	.037
7	.0354	.0381	.0339		.0381	.2835	.037
8	.0354	.0381	.0339		.0381	.2804	
9	1.56		1.7772	1.8313		.0362	
10	1.5939		1.8652	1.8313	.0373		
11	1.6956		1.7804	1.7295	.0377	.0354	
12	1.56		1.6617	1.7295	.0377	.0354	
13	1.5939		.3353	1.6617			
14	1.56		1.5424	1.56	.0377		
15	1.5939		1.6095	1.5939	.0377		
16	1.5939	1.6301	1.6095	1.6278	.0377		
17	.0381	.0339	.0354	.0381	.0373		.037
18	.0381	.0339	.0354	.0381			.037
19	.0381	.0339	.0354		.0373		.037
20	.0381	.0339	.0354	.0381	.0377		.0366
21	.0381	.0339	.0354	.0381	.0377		
22	.0381	.0339	.0354	.3052	.0377		
23	.0381	.0339	.0354	.3052	.0377		.0366
24	.0354	.0381	.0339	.0354	.3018	.0358	
Max	1.6956	1.6301	1.8652	1.8313	.3052	.2865	.037
Min	.0354	.0339	.0339	.0354	.0373	.0354	.0366
Avg	.5783	.1300	.5306	.9575	.1103	.1895	.0369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 207 / 11KV Bahubali-Nej Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1663	.1478		.1494	.1478	.1294
2		.1663	.1478		.1494	.1478	
3	.1595	.1663	.1478		.1494	.1463	.1294
4	.1417	.1646	.1478		.1478	.1478	
5	.1417	.1663	.1478		.1478	.1478	.1294
6	.1417	.1646	.1848		.1494	.1646	.1478
7	.1417	.1294	.1663		.1307	.1478	.1294
8	.1417	.1494	.1109		.0934	.1646	
9	.1254		.168	.1663	.1612	.1478	
10			.168	.2218	.1848		
11	.1478		.1307	.2033	.2218	.1949	
12	.1848		.1478	.2033	.2378	.2303	
13	.1478	.1595	.168	.2218	.2218		
14	.1663	.1772	.168	.2218	.2561		
15	.1478	.2481	.1663	.1848	.2561		
16	.1478	.2481		.1663	.2957		
17	.1867	.2033	.1772	.168	.2218		.2402
18	.1494	.2402	.1772	.1478			.2218
19	.2054	.2587	.2126		.1294		.1848
20	.2054	.2587	.1949				.2378
21	.2033	.2218	.1949	.1494	.1463		
22	.168	.2033	.1417	.1478	.1848	.1772	
23	.1867	.1663	.1417	.1663	.168	.1595	.1463
24	.1417	.1867	.1478	.1595	.168	.1663	.1478
Max	.2054	.2587	.2126	.2218	.2957	.2303	.2402
Min	.1254	.1294	.1109	.1478	.0934	.1463	.1294
Avg	.1610	.1923	.1611	.1806	.1805	.1636	.1676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 203 / 11 KV Korochi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2164	.3022	
2	.1932	.2492	
3	.1943	.2153	.1082
4	.1821	.2138	.1128
5	.1856	.2294	.125
6	.298	.3582	.0446
7	.4713	.5331	.1932
8	.1879	.3765	.1669
9	.032	.04	
10	.0267	.0431	.0412
11	.0385	.0183	.04
12		.0412	.0446
13		.0373	.04
14		.0126	.0297
15			.0389
16	.0027	.0011	.0412
17	.0011	.0065	.0286
18	.0187	.0244	
19		.024	
20		.04	
21		.0389	
22	.3235	.0145	
23	.3174	.173	
24	.2964	.1779	
Max	.4713	.5331	.1932
Min	.0011	.0011	.0286
Avg	.1756	.1378	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 201 / 11KV Udagaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2845	4.3507		3.7585	.0179	.0953	.0762
2	3.2304	4.2707		3.6054	.0179	.0953	.0762
3	3.1802	4.1724	3.0659	3.4835	.017	.0953	.0762
4	3.197	4.1388	3.6839	3.4964	.0181	.0953	.0762
5	3.3113	2.9943	3.5742	3.5963	.0181	.1608	.0762
6	3.5368	4.3499	1.8656	3.9338	.0183	.1776	.0762
7	3.7365	4.5298	2.3488	3.7136	.0183	.1852	.1189
8	1.5074	1.8839	1.5866	1.2887	.0191	.1563	.0189
9	.0762	.0846	.0762	.0762	1.6004	.9198	1.5454
10	.0762	.0762	.0762	.0762	3.8957	.6302	3.6153
11	.0762	.0762	.0777	.0762	4.6929	1.829	3.7204
12	.0762	.0762	.0953	.0762	4.8422	1.9578	3.6066
13	.0762	.0762	.1067	.0762	4.9741	3.1139	3.4743
14	.0762	.0762	.0953	.0762	5.173	2.7473	3.347
15	.0762	.0762	.0953	.0762	5.0206	2.2565	3.3072
16	.0762	.0762	.1403	.0762	4.8155	2.37	3.2777
17	.0762	.0762	.1158	.0189	2.4676	1.4685	1.784
18	.0762	.0762	.0762	.0181	.2698	.4146	.4771
19	.0762	.0762	.0762	.0076			.0762
20	.9717	.0762	.0762		.0792	.0762	.0762
21	.0762	.0762		.0168	.1257	.0762	
22	4.1854	4.1777	1.8854	.0183	.1784	.0762	.0023
23	4.4779	4.529	4.1922	.0189	.0122	.0762	.0762
24	3.8699	4.4528	2.0005	1.9243	.0187	.0953	.0762
Max	4.4779	4.5298	4.1922	3.9338	5.173	3.1139	3.7204
Min	.0762	.0762	.0762	.0076	.0122	.0762	.0023
Avg	1.6418	1.8687	1.2053	1.2830	1.6657	.8334	1.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 202 / 11KV Estate

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2274	1.8991	2.8646	1.4464	2.7633	3.4538	2.9729
2	3.1474	1.8602	2.7328	2.7069	2.7247	3.2358	2.7854
3	3.0552	1.8625	2.7008	2.6474	2.7217	3.0034	2.7892
4	2.9051	2.0073	2.5567	2.5438	2.8605	3.0743	2.6131
5	2.934	2.0751	2.6375	2.6459	2.7472	2.8304	2.7267
6	2.3213	2.1536	2.4859	2.697	2.9636	2.841	2.8876
7	2.2055	2.5172	2.7549	2.6314	2.86	3.0026	2.7008
8	1.8709	2.5332	2.828	3.0414	2.9965	3.4972	3.3776
9	1.9105	2.835	3.501	3.9575	3.6542	3.9491	4.1798
10	1.8892	3.1055	3.8782	4.0062	3.7091	4.0505	4.1811
11	1.8823	3.2107	4.1198	4.6281	4.3385	4.5061	4.1343
12	1.8831	3.0407	3.9765	4.2486	3.5864	4.1533	3.533
13	1.8031	3.3379	3.7411	3.9941	3.5612	3.7113	4.0125
14	1.877	3.642	4.148	4.3583	3.6542	4.2463	4.2646
15	1.8877	4.02	4.1381	4.1708	3.7479	4.5824	4.4247
16	1.7886	3.5688	4.1167	4.3103	3.7814	4.2943	4.5631
17	1.7078	3.4073	3.8927	3.8729	3.8013	4.321	4.4978
18	1.7139	2.8623	3.5909	3.8066	1.1325	3.3517	3.8783
19	1.8633	3.2335	3.5201	.0503	3.5658	1.4449	3.7425
20	1.7818	3.2153	3.1147	2.106	3.8378	3.8775	3.7921
21	1.8701	3.0407	1.6789	3.2873	3.7113	3.533	2.0027
22	1.9326	3.2823	1.8016	3.6081	3.3417	3.7174	1.9448
23	1.9456	2.9219	3.4773	3.1832	3.4049	3.2877	3.6046
24	2.5599	2.4006	2.9889	3.0414	3.2201	3.405	3.3578
Max	3.2274	4.02	4.148	4.6281	4.3385	4.5824	4.5631
Min	1.7078	1.8602	1.6789	.0503	1.1325	1.4449	1.9448
Avg	2.1651	2.8347	3.2186	3.2079	3.2786	3.5571	3.4570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 204 / 11KV Mayur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1474	3.4218	3.2267	1.6438	2.78	3.1124	2.9645
2	3.1504	3.4149	3.2427	3.2915	2.5926	2.9866	2.8616
3	3.1375	3.3966	3.2389	3.309	2.4539	2.966	2.841
4	3.1505	3.424	3.245	3.2655	2.4132	2.9843	2.8936
5	3.1665	3.3684	3.3318	3.2267	2.3678	3.1116	3.0148
6	3.1954	3.3379	3.3189	3.2975	2.62	3.1886	3.232
7	3.4294	3.4378	3.4256	3.4911	2.95	3.133	3.424
8	3.456	3.3951	3.7167	3.4157	3.1409	3.1009	3.4217
9	3.4202	3.4126	4.228	3.7929	3.8828	1.8046	4.0261
10	3.4195	3.642	4.8027	4.0101	4.1998	2.2138	4.6395
11	3.4507	4.2249	5.2461	4.59	4.6998	2.428	5.1356
12	3.3799	4.3378	4.859	4.3027	4.9322	2.2588	4.3523
13	3.2678	3.9751	4.1099	3.7906	3.9392	2.1186	4.0363
14	3.3882	4.2821	5.1722	4.0071	4.497	2.2009	4.4161
15	3.482	4.6136	5.2751	4.2608	4.4383	2.4074	4.6365
16	3.4218	4.5748	5.3642	4.4803	4.5381	2.3617	4.5613
17	3.4187	4.5968	4.4215	4.3884	4.3812	2.3221	4.2158
18	3.4774	4.2333	4.2654	3.9529	.0511	2.1353	4.1228
19	3.3707	4.0344	4.007	2.0759	2.6932	.6333	3.8409
20	3.4233	3.7175	3.5924	3.1295	3.2731	1.643	3.8653
21	3.4683	3.754	1.9029	2.947	3.1824	1.6126	1.8198
22	3.3395	3.5155	1.8214	2.991	3.3219	1.6042	1.7162
23	3.3463	3.3143	3.3897	3.1219	3.2678	3.2846	3.4568
24	3.2526	3.4408	3.3044	3.3036	2.838	3.3555	3.184
Max	3.482	4.6136	5.3642	4.59	4.9322	3.3555	5.1356
Min	3.1375	3.3143	1.8214	1.6438	.0511	.6333	1.7162
Avg	3.34	3.7861	3.8545	3.5036	3.3106	2.4570	3.6116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 205 / 11 KV Buvaphan AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.7528			.0191		.0191
2	1.448	1.5242		1.3717	.0191		.0191
3	1.467	1.5242	1.5242	1.3336	.0191		
4	1.467	1.5623	1.6385	1.3336	.0191		
5	1.6575	1.6385	1.6385	1.4289	.0191		
6	1.7528	1.829	.0191	1.6956	.0191		
7	1.7909	1.8671	1.7528	1.7147	.0191		
8	.0191	.0191	.0191	.0191	.0191		
9	.0191	.0191	.0191	.0191			.8124
10	.0191	.0191	.0191	.0191	2.553		.8951
11	.0191	.0191	.0191	.0191	2.6673		.9568
12	.0191	.0191	.0191	.0191	2.4006		.8855
13	.0191	.0191	.0191	.0191	2.3624		.7775
14	.0191	.0191	.0191	.0191	2.4006		.7926
15	.0191	.0191	.0191	.0191	2.3243		1.0494
16	.0191	.0191	.0191	.0191	2.1719		1.2498
17	.0191	.0191	.0191	.0191			.0191
18	.0191	.0191	.0191	.0191			.0191
19	.0191	.0191	.0191				.0191
20	.0191	.0191	.0191				.0191
21	.0191	.0191		.0191			
22		1.829					
23	2.0005	1.9052	2.1338	.0191		.0191	.0191
24	1.448	1.9052		.0191	.0191		.0191
Max	2.0005	1.9052	2.1338	1.7147	2.6673	.0191	1.2498
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.6403	.7335	.4713	.4573	1.0658	.0191	.4732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 206 / Jogeswari gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4945	1.4358	1.3497	1.358	1.4487	.6805	1.3055
2	1.3725	1.3664	1.2887	1.2833	1.3545	1.2109	1.1889
3	1.3511	1.3139	1.2636	1.2307	1.2869	1.1865	1.1493
4	1.2857	1.2628	1.259	1.2224	1.261	1.166	1.1188
5	1.3214	1.2659	1.288	1.339	1.3331	1.2323	1.1493
6	1.2673	1.3337	1.3352	1.4045	1.3653	1.2864	1.2803
7	1.1927	1.3169	1.3017	1.2231	1.2631	1.2567	1.1592
8	1.0882	1.2361	1.1119	1.179	1.177	1.1462	.5952
9	1.262	1.4975	1.4007	1.3954	1.5691	.7346	1.5013
10	1.4061	1.5874	1.6179	1.5745	1.6065	.8109	1.5501
11	1.3748	1.5676	1.656	1.5547	1.7627	.7926	1.6195
12		1.7817	1.7459	1.7756	1.9845	.8993	1.518
13		1.6042	1.701	1.4304	1.6271	.8192	1.392
14	.8687	1.3527	1.5409	1.4442	1.672	.6973	1.2064
15	1.2026	1.3367	1.4175	1.3862	1.4388	.7339	1.3565
16	1.2018	1.3176	1.2377	1.3771	1.4068	.6546	1.3032
17	1.2735	1.5204	1.2956	1.2658	.4153	.6607	1.2956
18	1.2788	1.2704	1.5166	1.5358		.6424	.2652
19	1.9143	2.0157	2.1536		.0808	.6386	2.1552
20	2.3441	2.2291	2.2992	1.7756	2.2024	1.1858	2.3929
21	2.1102	2.4158	1.1645	2.2302	2.1155	1.1744	1.2315
22	2.2359	2.2504	1.0319	2.2062	2.024	1.1134	1.169
23	2.0454	1.9479	1.9349	1.9757	1.9189	1.7749	1.8541
24	1.7795	1.7376	1.5905	1.5935	1.6405	1.5684	1.6316
Max	2.3441	2.4158	2.2992	2.2302	2.2024	1.7749	2.3929
Min	.8687	1.2361	1.0319	1.179	.0808	.6386	.2652
Avg	1.4851	1.5818	1.4793	1.5113	1.4763	1.0028	1.3495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 208 / 11 KV Krushna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2028	.2256	.2283	.1814	.2012	.0191
4	.2035	.2473	.2679	.1989	.2016	.0191
5	.2035	.2469	.2679	.1993	.2012	.0191
6	.2028	.2465	.2691	.2172	.2001	.0191
7	.1997	.2473	.2706	.221	.1982	.0191
8	.2599	.2694	.2679	.2014	.2012	.0191
9	.3147	.3879	.3555	.2202	.1254	.1997
10	.354	.3875	.3932	.2225	.1387	.2122
11	.3829	.3848	.3913	.2991	.1395	.2111
12	.3837	.3829	.3886	.3014	.1357	.2115
13	.3848	.3822	.386	.3162	.1292	.2103
14	.3871	.3829	.3822	.3128	.1078	.21
15	.3883	.386	.3848	.2946	.1078	.2111
16	.3944	.402	.3829	.2881	.1078	.1756
17	.3875	.3109	.3452	.2645	.1078	.1101
18	.3082	.3113	.2747	.1265	.0934	.224
19	.1448	.1254	.1109			.0819
24						.1143
Max	.3944	.402	.3932	.3162	.2016	.224
Min	.1448	.1254	.1109	.1265	.0934	.0191
Avg	.3002	.3133	.3157	.2416	.1498	.1270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 209 / KULKARNI POWER TOOLS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4432	1.9585	2.1475	2.3647	2.3201	2.4577	2.4859
2	2.4043	1.9616	2.1217	2.2687	2.3318	2.2413	2.5034
3	2.3617	1.9585	1.9845	2.287	2.1407	2.1979	2.3388
4	2.3594	1.9867	2.0027	2.2656	1.9764	2.1689	2.274
5	2.2542	1.9646	1.9685	2.1697	2.1857	2.1834	2.1727
6	2.0187	1.9418	1.9898	2.258	1.9856	2.1948	2.1163
7	1.9654	1.8961	2.0706	2.2359	1.876	2.1879	2.0241
8	1.9738	1.8564	2.1301	2.2314	2.2977	2.1651	1.867
9	1.9761	2.5453	3.123	3.1055	3.0689	2.979	3.2297
10	1.9814	2.7076	3.3577	3.7235	3.4614	3.3311	3.4073
11	1.8686	2.9584	3.5589	3.5795	3.4751	3.706	3.4816
12	1.8015	3.2358	3.5627	3.7251	3.7952	4.0208	3.5671
13	1.8137	2.4699	3.0354	3.027	1.7093	3.2038	2.9389
14	1.8442	3.1619	3.1763	3.6892	3.735	4.02	3.2449
15	1.9037	2.9058	3.4241	3.6374	3.7212	4.0939	3.4171
16	1.9044	3.0042	3.7776	3.7418	3.6861	3.6702	3.5246
17	1.954	2.9012	3.7044	3.737	3.5749	3.7205	3.2793
18	2.0111	2.5248	3.1657	2.3312		3.3356	2.9279
19	2.0142	2.5164	3.0605	1.6728	2.4996	.3102	2.6071
20	2.0104	2.2703	2.6932	2.2306	2.5949	2.5309	2.524
21	1.9486	2.2893	1.2696	2.1643	2.4554	2.4424	1.2612
22	1.9403	2.1574	1.3016	2.5628	2.572	2.5568	1.31
23	1.8404	2.3396	2.5248	2.5827	2.5186	2.3647	2.3731
24	2.1879	2.1285	2.3716	2.6604	2.4154	2.6459	2.3632
Max	2.4432	3.2358	3.7776	3.7418	3.7952	4.0939	3.5671
Min	1.8015	1.8564	1.2696	1.6728	1.7093	.3102	1.2612
Avg	2.0326	2.4017	2.6468	2.7605	2.7129	2.7804	2.6350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 201 / 11KV LIS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2007			3.2007		.0572
2	3.1245			2.6863		.0572
3	3.1055		2.8959	2.7625		.0572
4	3.1055		3.0483	2.8006		.0572
5	3.2388		3.0674	2.934		.0762
6	3.4675		.1905	3.296		.0762
7	2.5911		2.4387	2.553		.0381
8	.0953		.0953	.0762		.0381
9	.0953	.0953	.0953			.4191
10	.1143	.0953	.0953			.4572
11	.1143	.0953	.0953		.2096	.4572
12	.1143	.0953	.0953		.2477	.4572
13	.1143	.0953	.0953		.2667	.4572
14	.1143	.1143	.0953		.2858	.4572
15	.1334	.0953	.0953		.362	.5335
16		.0953	.0953		.4001	.4001
17	.0762	.0953	.0953		.0572	.0381
18		.0953	.1143		.0572	.0381
19		.1143	.1524		.0762	.0762
20		.1524	.1524		.0762	
21		.1524	.1524		.0762	
22		3.2579	3.658		.0572	
23		2.553	3.4294		.0572	.0762
24	3.2388			3.2388		.0572
Max	3.4675	3.2579	3.658	3.296	.4001	.5335
Min	.0762	.0953	.0953	.0762	.0572	.0381
Avg	1.5320	.4801	.9644	2.6165	.1715	.2087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 202 / 11KV Kothali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0762	.0762			.0191
2	.0572		.0762	.0762			.0191
3	.0572		.0762	.0572			.0191
4	.0572		.0762	.0762			.0191
5	.0762		.0762	.0572			.0191
6	.0762		.0762	.0762			.0381
7	.0572		.0572	.0572			.0381
8	.0572		.0572	.0572			.0381
9	2.5911	2.8959	3.0102			.0191	.0191
10	2.6673	3.0864	3.0674			.0191	.0191
11	2.8006	3.0483	3.0483			.0191	.0191
12	2.7054	3.0864	3.0674		.0381	.0191	.0191
13	2.572		3.0483		.0191	.0191	.0191
14	2.572		2.9721		.0191	.0191	.0191
15	2.553		2.7435		.0191	.0191	.0191
16	2.553	2.3624	.0572		.0191	.0191	.0191
17	.0572	2.5911	.0572			.0191	.0381
18	.0572	2.7054	.0762			.0191	.0381
19	.0762	.0572	.0762			.0191	.0381
20	.0762	.0953	.0762			.0191	
21	.0762	.0953	.0762			.0191	
22		.0953	.0762			.0191	.0572
23		.0953	.0762			.0191	.0572
24	.0953		.0762	.0762		.0191	.0191
Max	2.8006	3.0864	3.0674	.0762	.0381	.0191	.0572
Min	.0572	.0572	.0572	.0572	.0191	.0191	.0191
Avg	.9985	1.6845	.9240	.0678	.0229	.0191	.0277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 203 / 11KV Umalwad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0697	1.4891	.3208	2.7023		.0191
2	2.9722	1.4807		2.3434		.0191
3	2.9417	1.4495	1.3488	2.2093		.0191
4	2.8914	1.4167	2.7213	2.409		.0191
5	2.883	1.39	2.7458	2.4241		.0191
6	2.9805	1.3756	1.4053	2.5339		.0191
7	3.0925	1.4419	1.1058	2.6185		.0191
8	1.5715	1.4693	.8505	1.3398		.0191
9	.0191	.0191	.0191		.0191	.3825
10	.0191	.0191	.0191		.0229	.9123
11	.0191	.0191	.0191		.0366	1.041
12	.0191	.0191	.0191		.1326	1.2125
13	.0191	.0191	.0191		.2271	1.3039
14	.0191	.0191	.0191	.0747	.6775	1.3466
15	.0191	.0191	.0191	.0785	.8665	1.3962
16	.0191	.0191	.0191	.0793	.852	1.4213
17	.0191	.0191	.0191	.0785	.4337	.737
18		.0191	.0191	.045	.3537	.58
19		.0191	.0191	.0404	.0191	.0191
20		.0191	.0191		.0191	
21		.0191	.0191		.0191	
22	.6485	2.1895	2.2924		.0191	.0191
23	1.5737	2.9699	2.8936		.0191	.0762
24	3.1109	1.5143	1.454	1.3527		.0191
Max	3.1109	2.9699	2.8936	2.7023	.8665	1.4213
Min	.0191	.0191	.0191	.0404	.0191	.0191
Avg	1.3954	.7681	.7559	1.3553	.2478	.4827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 204 / 11KV Danoli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1715	.1715		.1334
2	.1524		.1715	.1715		.1334
3	.1524		.1715	.1524		.1334
4	.1524		.1715	.1524		.1334
5	.1905		.1905	.1524		.1334
6	.1905		.1905	.1905		.1905
7	.1715		.1905	.1715		.2286
8	.1524		.1905	.1715		.2286
9	4.382	4.8583	4.4963			.0191
10	4.4201	4.5725	4.2867			.1715
11	4.4582	4.2867	3.8676			
12	4.382	4.1724	3.9057		.0191	.1143
13	4.02		3.6389			.1334
14	4.0009		3.7723			.1143
15	4.0009		3.677			.1143
16	3.9819	3.8104	.1524			.1143
17	.1715	3.9057	.1524			.1334
18	.1715	2.4006	.1715			2.0767
19		.1715	.1715		.0572	.1715
20		.2286	.2096		.0572	
21		.2286	.2286		.0572	
22		.2096	.1905		.0572	.1905
23		.1905	.1715		.0572	.1905
24	.1905	.1905	.1905	.1715		.0381
Max	4.4582	4.8583	4.4963	.1905	.0572	2.0767
Min	.1524	.1715	.1524	.1524	.0191	.0191
Avg	1.8691	2.2481	1.2805	.1672	.0509	.2332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 205 / 11KV Waranamai

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0572	.0572		
2	.0762		.0572	.0572		
3	.0762		.0381	.0381		
4	.0572		.0381			
5	.0572		.0381			
6	.0572		.0381	.0381		
7	.0572		.0381	.0381		
8	.2096		.3429	.1905		
9	6.1538	7.4875	7.3922	3.8104		
10	6.6301	7.2779	7.4303	3.8104		
11	7.5065	6.8206	.4572	3.8104		
12	7.2779	6.7254	6.8969	3.658		
13	7.1826	3.3532	7.2969	3.3532		.0762
14	6.8778		7.2398	3.3532		.0191
15	6.8588		6.9731	3.3532	.0191	.0191
16	6.9921	5.9252	3.3913	3.2007		.0191
17	.0191	5.9823	.0381			.0191
18		6.0776	.0381			.0953
19		.0381	.0381			
20		.0572	.0381			
21		.0572	.0572			
22		.0572	.0572			.0762
23		.0572	.0572			.0381
24	.0762		.0572	.0572		
Max	7.5065	7.4875	7.4303	3.8104	.0191	.0953
Min	.0191	.0381	.0381	.0381	.0191	.0191
Avg	3.1246	3.8397	2.0044	1.9217	.0191	.0453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 206 / 11KV Danoli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.5335	.5716			.5335
2	.4191		.5335				.5335
3	.4191		.5525				.5335
4	.4191		.5716				.5335
5	.4572		.6668				.5335
6	.4572		.6668	.6478			.5525
7	.4001		.5716	.5335			.4954
8	.3429		.5335	.5144			.4382
9	.3239	.5335	.5716				.4954
10	.3239	.5335	.5525				.4572
11	.3239	.5525	.5716		.6859	.6668	
12	.3429	.5716	.6097			.5716	
13	.3429	.5335	.6097		.6287	.6097	
14	.3429	.5906	.5906		.5716	.6287	
15	.362	.5716	.5906		.6287	.6097	.5335
16	.362	.5716	.5716		.6097	.6287	.5335
17	.2667	.5716	.6097			.6097	.6097
18		.5525	.7049			.6668	.6478
19		.6668	.6668			.6287	
20		.7621	.724			.6097	
21		.743	.7621			.6287	
22		.7049	.6859			.5906	.724
23		.6097	.6478			.5525	.6478
24	.4763		.5335	.5906			.5335
Max	.4763	.7621	.7621	.6478	.6859	.6668	.724
Min	.2667	.5335	.5335	.5144	.5716	.5525	.4382
Avg	.3800	.6046	.6097	.5716	.6249	.6155	.5492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 207 / 11KV Umalwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.6234	1.1431	1.2086		.0968	.7803
2	.5525	.5929	.5525	1.2079		.1059	.7674
3	.5525	.5784	1.0654	1.1363		.0533	.7582
4	.5716	.5655	1.0868	1.0936		.0373	.7575
5	.6097	.6371	1.1691	1.1873			.7796
6	.6478	.6386	1.2971	1.339			.8063
7	.5335	.6401	1.2544	1.3138			.7971
8	.5144	.5822	1.1775	1.0836			.8482
9	.5335	1.0006	1.1271	.4771		.0191	.8101
10	.5144	1.0029	1.0715	.4344		.0191	.8901
11	.4382	1.0029	1.0966	.4641		.1311	1.0913
12	.4572	1.0158	1.0608	.4626		.0465	.9739
13	.4763	1.073	1.0814	.4847		.1151	.7567
14	.4763	1.0936	1.0883	.567	.0762	.3079	.929
15	.4763	1.1126	1.1865	.5632	.1684	.5525	1.1043
16	.4763	1.0532	1.1157	.5693	.2545	.9724	1.0624
17	.4382	1.054	1.1042	.5677	.1029	.9495	1.0944
18		1.1493	1.2514	.5792	.0655	1.2666	1.1995
19		1.2254	1.3916	.5677		1.2711	1.2993
20		1.5348	1.4502			1.1401	.7552
21		1.5569	1.4365		.0633	1.089	.8063
22		1.5234	1.4121		.1097	1.0136	1.5173
23		1.3741	1.3588		.1585	.9336	1.4449
24	.5906	.6897	1.2415	.6097	.1677	.4374	1.0432
Max	.6478	1.5569	1.4502	1.339	.2545	1.2711	1.5173
Min	.4382	.5655	.5525	.4344	.0633	.0191	.7552
Avg	.5229	.9717	1.1758	.7958	.1296	.5279	.9614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 201 / 11KV RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.8501	.8865	.8413	.8316	.7762	.7545
2	.7316	.8131	.7922	.7316	.8029	.7392	.7167
3	.724	.7762	.7733	.695	.7842	.7023	.7167
4	.6878	.7577	.7545	.6878	.7095	.6653	.6413
5	.6878	.7392	.7733	.724	.7282	.7023	.679
6	.7059	.7207	.811	.7602	.7392	.7023	.7356
7	.7421	.7577	.8029	.7701	.7577	.7577	.7095
8	.724	.7947	.8131	.7964	.7947	.7577	.7392
9	.7468	.8145	.8501	.8326	.8131	.6878	.7577
10	.8589	.9774	1.0719	1.0317	.9979	.8688	.8871
11	.8686	1.0208	1.1273	1.0679	.9979	.9955	.9055
12	.9425	.9955	1.1827	1.1403	1.0903		.9425
13	.9979	1.1458	1.2071	1.1222	1.0534	1.0679	.8871
14	.4066	1.0608	1.134	1.1222	1.1016	1.0317	.9055
15	.3881	1.0608	1.2071	1.086	1.1016	1.0136	.924
16	.3696	1.0679	1.0974	1.1041	1.1016	1.0317	.9425
17	1.0534	1.0903	1.0679	1.1222	1.0719	1.0349	.9412
18	1.0534	1.0679	1.1946	1.1765		.9877	.9412
19	1.2382	1.2803	1.2308		1.3306	1.1403	1.1041
20	1.2752	1.3676	1.2437	1.1584	1.2567	1.1643	1.2308
21	1.1643	1.251	1.1157	1.1157	1.1458	1.1016	
22	1.0903	1.1506	1.0425	1.0164	.961	.9896	1.0974
23	1.0164	1.0562	.9877	.9896	.924	.8865	1.0425
24	.8962	.924	.9242	.9145	.8686	.8686	.7922
Max	1.2752	1.3676	1.2437	1.1765	1.3306	1.1643	1.2308
Min	.3696	.7207	.7545	.6878	.7095	.6653	.6413
Avg	.8421	.9809	1.0038	.9568	.9550	.8988	.8693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 202 / 11KV PINGARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5166	1.5276	1.4788	1.592	1.4644	1.3581	1.3083
2	1.4026	1.4903	1.46	1.4788	1.3512	1.302	1.2194
3	1.4026	.6859	1.3649	1.3581	1.3581	1.2445	1.2003
4	1.3954	1.3767	1.3649	1.3581	1.3394	1.2445	1.0993
5	1.3565	1.3954	1.4026	1.3581	1.3394	1.2445	1.1755
6	1.4327	1.4141	1.5354	1.5463	1.4828	1.4327	1.2321
7	1.7532	1.565	1.5089	1.6699	1.633	1.5089	1.3954
8	1.6038	1.5276	1.5013	1.6598	1.5623	1.4903	1.3512
9	1.5089	1.5276	1.5463	1.5585	1.5198	1.5836	1.4903
10	1.4327	1.5463	1.6598	1.6166	1.633	1.5752	1.4141
11	1.3327	1.5752	1.6785	1.5985	1.6145	1.596	1.1885
12	.6097	1.5276	1.6412	1.5042	1.596	.7621	1.1885
13	.6097	1.4903	1.596	1.4499	1.4828	1.5013	1.2445
14	.6097	1.3626	1.4754	1.4861	1.5089	1.4327	1.2632
15	1.238	1.3809	1.512	1.5261	1.6785	1.5276	1.2632
16	1.3512	1.5276	.1524	1.689	1.6412	1.5463	1.2632
17	1.3394	1.4828	1.4327	1.5585	1.6038	1.4828	1.2832
18	1.3954	1.468	1.8667	1.4499		1.3626	1.1527
19	1.7158	1.7162	1.8755	.0762		.9888	1.5223
20	1.8854	1.8962	1.9429	1.6747	1.6785	1.7276	1.7833
21	1.9429	1.8962	1.9429	1.7071	1.9989	1.6225	.9145
22	1.9989	1.9149	1.8667	1.7646	1.792	1.6038	1.7741
23	1.9429	1.8395	1.8576	1.7646	1.736	1.555	1.7558
24	1.7255	1.6412	1.5928	1.7059	1.4903	1.4141	1.4796
Max	1.9989	1.9149	1.9429	1.7646	1.9989	1.7276	1.7833
Min	.6097	.6859	.1524	.0762	1.3394	.7621	.9145
Avg	1.4376	1.5323	1.5523	1.5063	1.5684	1.4211	1.3318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 203 / 11KV SHAHUNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3882	1.3697	1.4026	.7023	.7023	.6283	1.2133
2	1.275	1.3512	1.3649	.6653	.6722	.6099	1.1182
3	1.2681	1.2565	1.3272	.6283	.6535	.5914	1.0993
4	1.2316	1.238	1.251	.6219	.6535	.5544	1.0993
5	1.2316	1.275	.6602	.6584	.6348	.5729	1.0993
6	1.2316	1.275	.7167	.6767		.6099	1.1182
7	1.2316	1.2565	.6535	.6584	.6283	.6283	1.0936
8	1.1767	1.238	.5914	.6036	.6036	.5729	1.0879
9	1.0563	1.1005	.5729	.6219	.5914	.5304	1.051
10	.9987	1.0639	.5544	.5487	.5729	.4572	1.0694
11	.9377	1.0222	.6099	.5611	.5729	.5304	1.0879
12	.9747	1.0822	.6099	.5611	.5914		1.0879
13	1.051	1.0403	.6099	.5792	.499	.439	1.1064
14	1.1434	1.1005	.6219	.6335	.5975	.5853	1.1064
15	1.2196	1.195	.6219	.5973	.6348	.567	1.1434
16	1.1826	1.195	.5853	.6154	.6348	.6036	1.0879
17	1.1064	1.2196	.567	.5973	.6283	.6653	1.1005
18	1.0694	1.2794	.695	.7059		.6584	1.3556
19	1.4436	1.5638	.8048			.8145	1.5404
20	1.7069	1.82	.8779	.7964	.9425	.8316	1.8195
21	1.7069	1.82	.8596	.7964	.8871	.8215	.9145
22	1.7254	1.8387	.8596	.8871	.8501	.8215	1.6979
23	1.6884	1.7821	.8316	.7947	.7577	.7356	1.6796
24	1.5406	1.5775	.7356	.7392	.7392	.6653	1.4034
Max	1.7254	1.8387	1.4026	.8871	.9425	.8316	1.8195
Min	.9377	1.0222	.5544	.5487	.499	.439	.9145
Avg	1.2744	1.3317	.7910	.6630	.6689	.6302	1.2159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 201 / Jambhali gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	1.1584
Max	1.1584
Min	1.1584
Avg	1.1584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 205 / 11KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17
HR	Load (MW)
24	.3601
Max	.3601
Min	.3601
Avg	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 206 / 11KV SIDHESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	1.0822	1.0928	1.121	1.1652	1.1652	1.0761
2	1.0044	1.0128	1.0532	1.0707	1.0761	1.0761	.9922
3	.9656	.977	1.0014		1.041	1.041	.9617
4	.9381	.9503	.9777		1.0098	1.0098	.9343
5	.913	.9214	.9671	.7042	.9732	.9732	.9503
6	.9069	.9229	.9998	.7217	.9907	.9907	.9526
7	.8893	.9015	.9534	.6783	1.009	1.009	.9595
8	.8429	.8985	.9396	.6714	.9069	.9069	.9419
9	.8253	.9137	.9412	.676	.9396	.9396	.9549
10	.8977	1.0776	1.1347	.7583	1.1789	1.1789	1.1164
11	.9114	1.1866	1.2323	1.3344	1.2582	1.2582	1.214
12	.9282	1.2338	1.2521	1.3336	1.2803	1.2803	1.2056
13	.9457	1.2734	1.2468	1.3695	1.3283	1.3283	1.2704
14	.9823	1.2117	1.182	1.2551	1.2346	1.2346	1.2003
15	.9915	1.2833	1.2993	1.3527	1.31	1.31	1.2765
16	1.0067	1.2917	1.3115	1.3451	1.2925	1.2925	1.2696
17	1.0128	1.278	1.2925	1.3397	1.3687	1.3687	1.1927
18	1.0082	1.2483	1.3397	1.4403			1.2407
19	1.2422	1.2955	1.3916		1.2452	1.2452	1.2399
20	1.3794	1.4464	1.4228	1.496	1.5234	1.5234	1.2849
21	1.3222	1.4098	1.3832	1.467	1.512	1.512	1.2346
22	1.2742	1.3298	1.3222	1.4098	1.3634	1.3634	1.2079
23	1.2696	1.3161	1.3237	1.3656	1.2765	1.2765	1.1782
24	1.1995	1.2254	1.2422	1.2795	1.1675	1.1675	1.0799
Max	1.3794	1.4464	1.4228	1.496	1.5234	1.5234	1.2849
Min	.8253	.8985	.9396	.6714	.9069	.9069	.9343
Avg	1.0299	1.1537	1.1793	1.1519	1.1935	1.1935	1.1223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 209 / Kondigre Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
14	.8535
23	1.0288
24	1.0288
Max	1.0288
Min	.8535
Avg	.9704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 210 / Chipri (Hanuman)AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	1.4632
Max	1.4632
Min	1.4632
Avg	1.4632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 211 / Venkateshwara Express ind
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0076				.0324		
2	.0076				.021		
3					.0019		
4			.0019				
5					.0019		
6					.0095		
7	.0267		.021		.0114		
8	.0514		.0781		.0324		
9	.0076		.1696		.0229		
10	.0438	.0762	.2077	.0229	.2096	.1257	.0857
11		.2458	.2515	.2553	.1962	.2362	.1296
12		.3144	.2686	.2877	.242	.0514	.2172
13	.0038	.2953	.2724	.2934	.2362	.2496	.2705
14		.2896	.2515	.2458	.2439	.2515	.2553
15		.2553	.2134	.2515	.221	.1962	.2229
16		.2743	.261	.2763	.2515	.2058	.181
17		.2629	.2343	.2705	.2382	.2343	.1677
18		.2763	.2172	.2591	.1943	.1943	.1124
19		.0914	.0495	.0895	.0019	.0476	.0495
20		.0057		.0076		.0514	.0705
21				.04		.0286	.0991
22		.021		.0762	.0057		.0533
23				.0591			.0038
24				.0267			
Max	.0514	.3144	.2724	.2934	.2515	.2515	.2705
Min	.0038	.0057	.0019	.0076	.0019	.0286	.0038
Avg	.0212	.2007	.1784	.1641	.1144	.1561	.1370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 407 / 33KV SUPERCRAFT

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8875	2.6578	6.286	8.0247	7.6715	7.9561
2	2.9047	2.6886	6.2106	6.7456	5.8128	5.6859
3	2.9081	2.6646	6.9856	7.0508	6.9033	7.0885
4	2.9252	2.6646	8.3128	7.963	7.5892	7.0062
5	2.9184	2.644	8.083	7.7641	6.7147	6.6735
6	2.8395	2.8429	6.8759	6.1214	6.6084	6.2277
7	2.7812	2.8567	7.4314	6.7524	6.5329	6.2963
8	2.8807	2.8704	6.7113	7.0576	6.2003	6.5741
9	2.7709	2.7023	6.6358	8.0761	5.4767	7.0268
10	2.5686	2.4623	8.1584	4.7634	6.749	5.9911
11	2.5274	2.5206	6.7627	5.8642	7.6886	6.5021
12	2.5446	2.476	4.6468	6.5707	6.8141	7.5412
13	2.5034	2.4863	6.7627	6.3923	7.9218	6.4232
14	2.7195	2.5652	7.8395	6.7798	5.559	7.0542
15	2.5206	2.548	6.7215	6.3855	5.2812	8.011
16	2.5412	2.524	7.3183	6.6118	7.3251	7.4383
17	2.7401	.7819	4.6399	6.5089	6.8484	8.2373
18	2.6303	.5075	3.6386	2.452	4.8731	5.3772
19	2.6166	.487	1.6152	2.5069	6.9856	7.3834
20	2.596	.4561		4.321	7.62	6.262
21	2.5857	2.6166	3.0727	7.4589	7.0508	6.6221
22	2.7538	2.5412	6.1214	6.5089	6.9719	7.7915
23	2.7846	5.0617	6.4746	5.3189	6.8073	6.8793
24	2.7949	6.4952	7.2428	6.869	6.6049	7.0233
Max	2.9252	6.4952	8.3128	8.0761	7.9218	8.2373
Min	2.5034	.4561	1.6152	2.452	4.8731	5.3772
Avg	2.7185	2.5467	6.2847	6.2862	6.6921	6.8780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 408 / Sidhivinayak

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	1.2346
Max	1.2346
Min	1.2346
Avg	1.2346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 409 / 33Kv Industrial
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 603 / USDPCL 110 KV

Feeder KV- 100 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	1.5588
Max	1.5588
Min	1.5588
Avg	1.5588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 201 / 11KV Takawade Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.0335		.9762	.1341
2	.0377	.0377	.0335		.9762	.1341
3	.0377	.0377	.0335		1.0242	.1341
4	.0377	.0377	.0335		1.0242	.1341
5	.0377	.0373	.0335		1.0562	.1341
6	.0377	.0377	.0335		.032	.1341
7	.0377	.0377	.0335		.032	
8	.0377	.0373	.0335		.0335	
9	1.8564	1.9364			.032	
10	1.9364		2.2634		.032	
11	1.7284		2.0325		.032	
12	1.8084		1.9044	2.0119	.032	
13	1.8724		1.8404	1.9113	.032	
14	1.7444		1.9113	1.6766		
15	1.8404		1.8778	1.6766		
16				1.4754		
17	.0366		.032	.032		
18	.0373		.032	.0335		
19	.0366		.032			
20			.032	.032		
21	.0377		.032	.032		
22	.0377		.032	1.1401		
23	.0377		.032	1.073		
24	.0377	.0377	.0335		.9922	.0335
Max	1.9364	1.9364	2.2634	2.0119	1.0562	.1341
Min	.0366	.0373	.032	.032	.032	.0335
Avg	.6068	.2275	.5616	1.0086	.4505	.1197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 202 / Shirdhon, Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9233	2.5389		1.4617	.032	.0335	.1052
2	2.9093	2.519		1.4579	.032	.0335	.1036
3	2.8994	2.492	1.7268	1.4426	.032	.0335	.1021
4	2.9009	2.4828	2.495	1.3428		.0335	.0991
5	2.8796	2.4722	2.4882	1.3115	.032	.0335	.096
6	2.8628	2.4512	1.2551	1.3054	.032		.0953
7	2.9237	2.4718	1.3634	1.2475	.032		.1082
8	1.7159	1.3542	1.4518	.0015	.0335		.1189
9	.3616	.0328	.1014		1.3771		.1044
10	.402	.0008	.0343		3.2465		
11	.4489			.0008	3.4743		
12	.4923	.0023		.0335	3.7623		
13	.506	.0015	.0373	.115	3.8606		
14	.4862		.032	.0719	3.8546	.2332	
15	.49		.0335	.1182	3.8622	.2766	
16	.2728		.0343	.1791	2.1171	.2911	
17	.3616		.0328	.0373	2.0896	.2919	
18	.4367		.0343	.032	1.0883	.1433	
19			.0328			1.4319	.0069
20	.0328	.016	.0328	.032		.0145	.003
21	.0404	.0793	.0328	.032			
22	2.2633	1.0822	2.3495	.0335		.0023	
23	2.5587	1.3154	2.6954	.0343		.1052	.0008
24	2.7335	2.5111	1.5287		.032	.1394	.0061
Max	2.9237	2.5389	2.6954	1.4617	3.8622	1.4319	.1189
Min	.0328	.0008	.032	.0008	.032	.0023	.0008
Avg	1.4740	1.4014	.8896	.5145	1.6106	.2065	.0730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 204 / 11KV Shiradhon Takawade

GAOTHAN FEEDER

Vlg Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3241	1.371	1.3344	.7537	1.5516	1.1294	.6958
2	1.2178	1.3104	1.2879	.727	1.4968	1.0958	.6462
3	1.2315	1.2984	1.2894	.7171	1.5006	1.0814	.6203
4	1.1673	1.2475	1.2429	.6516	1.4792	1.076	.6112
5	1.1536	1.2574	1.2857	.6516	1.496	1.0707	.6089
6	1.243	1.2723	1.3329	.6691	1.5326	1.0935	.6455
7	1.1834	1.2018	1.275	.7004	1.3931	.6226	.6836
8	1.1042	1.1067	1.0753	.6554	.7034	.5754	.6645
9	1.1184	1.0739	.5838	.6066	1.2087	.554	.6295
10	1.1088	.5746	1.169	.6622	1.2422		
11	1.1338	.5708	1.2818	.6661	1.5615		
12	1.1603	.599	1.291	1.2803	1.5867		
13	1.1048	.6302	1.179	1.2056	1.5234	.4016	
14	1.048	.6066	1.134	1.2201	1.48	.7202	
15	1.1922	.647	1.2028	1.4121	1.5158	.8063	
16	.6622	.647	1.3771	1.5081	.8147	.7545	
17	1.2003	.6318	1.3869	1.6111	.7301	.9069	
18	1.1755	.6295	1.5303	1.5463	.7156	.9252	
19	1.3443	.6363	1.1012	.8794		.977	.7362
20	1.6464	.8467	1.6141	1.4739	.128	.4641	.9884
21	1.6872	.9099	1.7619	1.72	.6851	.2751	1.0418
22	1.6538	.9061	1.704	1.7772	.8131	.3986	1.0319
23	1.5833	.8627	1.6316	1.669	.7964	.2713	.9945
24	1.4703	1.4863	1.5066	.8787	1.5265	1.2567	.9496
Max	1.6872	1.4863	1.7619	1.7772	1.5867	1.2567	1.0418
Min	.6622	.5708	.5838	.6066	.128	.2713	.6089
Avg	1.2464	.9302	1.3158	1.0684	1.1948	.7836	.7699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 205 / JAMBHALI-TAKWADE LIS

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0244		.0381			.0091
3	.8734	.8025	.471	.0076	.4557	.458
4	.9069	.8604	.4694	.0076	.4618	.4641
5	.9236	.8566	.471	.0107	.4633	.4603
6	.9442	.865	.4725	.0107	.4733	.4664
7	.9388	.8757	.4672	.6779	.4588	.4641
8	.9274	.4649	.4641	.9053	.4611	.4572
9	.9297	.8871	.4786	.8954		.4565
10	.4771	.953	.4679	.8908		
11	.413	.9404	.4725	.9054		
12	.4687	.9297	.8741	.8993		
13	.4512	.8954	.8703	.8962	.8566	
14	.4702	.8459	.8764	.8894	.8909	
15	.3749	.8924	.8795	.8955	.4588	
16	.3262	.8954	.8802	.4595	.4588	
17	.4748	.887	.9107	.4664	.4626	
18	.4489	.5898	.5884	.4557	.4451	
Max	.9442	.953	.9107	.9054	.8909	.4664
Min	.0244	.4649	.0381	.0076	.4451	.0091
Avg	.6102	.8401	.5972	.5796	.5289	.4045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 206 / JAYHIND-JAWAHAR LIS

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2743	.3353		.3353	
4	.2743	.3353		.3201	
5	.2743	.3353		.3201	
6	.2743	.3353		.3201	
7	.2743	.3353		.3353	
8	.2743	.3353		.3521	
9	.2743			.3361	
10		.3125		.3081	
11		.3315		.3081	
12		.3201	.3353	.3081	
13		.3041	.3353	.3081	.3361
14		.3041	.3353	.3081	.3201
15		.3041	.3353	.3081	.3361
16		.2561	.3353		.3201
17		.2347	.2561		
18		.2347	.2561		
Max	.2743	.3353	.3353	.3521	.3361
Min	.2743	.2347	.2561	.3081	.3201
Avg	.2743	.3076	.3127	.3206	.3281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 201 / 11 Kv Shridatt Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0687	1.9938		1.9765	.0492	.0655	.0655
2	2.0348	1.9806			.0492	.0655	.0655
3	1.917	2.0022	1.6385		.0492	.0655	.0655
4	1.8679	2.0416	1.6385		.0492	.0655	.0655
5	1.8896	2.0814	1.6385		.0492	.0655	.0655
6	1.9006	2.1399			.0492	.0819	.0655
7	1.8351	2.1992	1.704		.0492	.0819	.0655
8	.0663	.056	.0983		.0492	.0819	.1311
9	.0678	.0754	.0983		2.2939	1.5893	2.6406
10	.0671	.0655	.1311		2.6063	1.7166	2.4348
11	.0693		.156	.0655	2.8433	1.6842	2.9127
12	.0701			.0983	2.8395	1.6842	2.9271
13	.0709	.0972	.1595	.0655	2.9412	1.6842	2.9412
14	.0716	.0983	.1433	.0655	3.0266	1.9433	2.9012
15	.0724	.0655	.1267	.0655	3.0407	1.8785	2.8597
16	.0732	.0648	.1463	.0655	3.0178	1.8138	2.7801
17	.0739	.0648	.0924	.0983	.0554	.0324	.1848
18	.0747	.0648	.0934	.0655			.112
19	.0754	.0648	.0943	.0655			.1698
20	.0686	.0648	.0857	.0655	.0686	.0492	.1543
21	.0867	.096	.0867	.0655	.0693	.0655	.1214
22	2.1033	1.8351	1.9982	.0492	.0732	.0655	.1578
23	2.0908	1.8351	2.073	.0492	.0709	.0655	.1417
24	2.1628	2.0233		1.989	.0492	.0655	.0655
Max	2.1628	2.1992	2.073	1.989	3.0407	1.9433	2.9412
Min	.0663	.056	.0857	.0492	.0492	.0324	.0655
Avg	.8699	.9550	.6422	.3233	1.0632	.6778	1.0039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 202 / 11 kv Bastwad feeder AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2283	2.5139		2.3926	.0324	.0492	.0492
2	2.2211	2.524			.0324	.0492	.0492
3	2.1795	2.516	2.2348	2.2148	.0324	.0492	.0492
4	2.13	2.5431	2.2348	2.1849	.0324	.0492	.0492
5	2.1628	2.6063	2.4272	2.19	.0324	.0492	.0492
6	2.1956	2.6703		2.3045	.0324	.0492	.0492
7	2.1628	2.5503	2.3644	2.347	.0324	.0492	.0492
8	.0503	.0373	.0328	.0324	.0324	.0492	.0492
9	.0503	.0377	.0324	.0324	2.2996	2.6707	3.2442
10	.0509	.0328		.0486	3.035	3.0148	3.2236
11	.052	.0328	.0347	.0328		3.1459	3.4155
12	.0701	.0655	.0351	.0492	3.1725	2.982	3.2427
13	.0709	.0486	.0354	.0492	3.2779	2.9492	3.5082
14	.0716	.0486	.0358	.0324	3.4027	3.1459	3.2594
15	.0543	.0324	.0362	.0324	3.3665	2.982	3.3665
16	.0549	.0324	.0549	.0324	3.658	2.982	3.3471
17	.0554	.032	.0554	.0324	.0554	.0328	.1109
18	.056	.0324	.056	.0324		.0655	.056
19	.0566	.032	.0566	.0324			.0566
20	.0514	.048	.0514	.0486	.0514	.0655	.0686
21	.0693	.048	.052	.0324	.0693	.0655	.0693
22	2.4364	2.4006	2.5766	.0324	.0876	.0655	.0701
23	2.6223	2.3365	2.6578	.0324	.0709	.0655	.0709
24	2.2085	2.5034		2.3663	.0332	.0492	.0655
Max	2.6223	2.6703	2.6578	2.3926	3.658	3.1459	3.5082
Min	.0503	.032	.0324	.0324	.0324	.0328	.0492
Avg	.9734	1.0719	.7929	.7211	1.0876	1.0729	1.1487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 203 / HERWAD VILLETTE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.4161		.4854	.5729	.3326	.4108
2	.3856	.4557	.462		.5175	.3326	.4481
3	.3582	.4252	.462	.4961	.5175	.3326	.4481
4	.3544	.5014	.4435	.5014	.4805	.3696	.4108
5	.4119	.5792	.462	.543	.4805	.4066	.4108
6	.4298	.6036	.499	.5853	.499	.4435	.4251
7	.4031	.6099	.4251	.5359	.4435	.4066	.4435
8	.4298	.5601	.4251	.6099	.499	.3881	.4251
9	.4163	.6224	.5914	.5487	.5914	.4435	.5658
10	.5487	.5853	.5914	.567	.5487	.462	.4973
11	.5201	.4805	.5375	.5487		.3881	.5028
12	.5083	.4049	.4733	.6036	.6135		.5083
13	.4961	.439	.4607	.4755	.5138	.5544	.4961
14	.4477	.4755	.5014	.439	.5731	.5914	.4656
15	.4887	.5544	.5792	.4755	.6154	.6099	.543
16	.5121	.5175	.6036	.4938	.6219	.6099	.6036
17	.462	.5175	.5359	.3658	.462	.5544	.3881
18	5.3399	.4755	.5975	.4938		.3921	.5601
19		.695	.6413	.439			.7167
20	.5487	.7316	.6173	.6219		.6722	.6859
21	.4854	.5914	.5028	.4938	.3814	.6161	.6588
22	.5434	.5544	.298	.499	.4207	.5601	.6135
23	.4961	.5175	.567	.5729	.4075	.5601	.5493
24	.5304	.4458	.4435	.5144	.5544	.3658	.5415
Max	5.3399	.7316	.6413	.6219	.6219	.6722	.7167
Min	.3544	.4049	.298	.3658	.3814	.3326	.3881
Avg	.6755	.5316	.5096	.5178	.5157	.4724	.5133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 204 / 11 kv water works feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0867	.0693	.0895	.0693	.0693	.0693
2	.0686	.0701	.0693	.0876	.0693	.0693	.0693
3	.0686	.0709	.0693	.0886	.0693	.0693	.0693
4	.0716	.0716	.0867	.0895	.104	.0693	.0693
5	.0914	.0905	.104	.0905	.104	.0867	.0867
6	.0876	.0914	.104	.0914	.104	.104	.0867
7	.1052	.0924	.104	.0924	.104	.104	.0867
8	.1052	.0934	.104	.1214	.104	.104	.104
9	.1029	.1132	.0867	.104	.104	.0867	.0943
10	.0857	.104	.104	.1214	.1029	.0867	.0343
11	.0693	.0701	.104	.104	.0693	.104	.0867
12	.0526	.1029	.1029	.104	.1052	.104	.1052
13	.0709	.1029	.1063	.104	.1063	.104	.1063
14	.0716	.104	.1075	.104	.1075	.104	.1075
15	.0905	.104	.1086	.104	.1086	.104	.1086
16	.0732	.104	.1097	.104	.1097	.104	.1097
17	.0924	.104	.0924	.104	.0924	.104	.1109
18	.0747	.0867	.0934	.0867		.104	.112
19	.0566	.0693	.0943	.0867			.0943
20	.0686	.0693	.0514	.0693	.0857	.0693	.0514
21	.0867	.0693	.0693	.0693	.0693	.0693	.052
22	.0876	.0693	.0532	.0693	.0701	.0693	.0526
23	.0886	.0693	.0532	.0693	.0709	.0693	.0709
24	.0876	.0857	.0693	.0857	.0693	.0693	.0693
Max	.1052	.1132	.1097	.1214	.1097	.104	.112
Min	.0526	.0693	.0514	.0693	.0693	.0693	.0343
Avg	.0803	.0873	.0882	.0934	.0909	.0882	.0836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 205 / 11 Kv Herwad Fdr

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0972	2.3405		2.1152	.0312	.0474	.08
2	2.0809	2.3487			.0312	.0474	.08
3	2.0481	2.3034	1.8747	1.781	.0312	.0474	.08
4	2.0481	2.2923	1.8747	1.781	.0312	.0633	.08
5	2.0325	2.2986	1.9372	1.8122	.0312	.0633	.0791
6	2.1548	2.4508		1.8435	.0312	.0791	.0791
7	2.1956	2.5318	2.1247	1.9216	.0312	.0791	.0949
8	.0509	.0747	.0625	.0312	.0312		.0633
9	.0509	.0754	.0625	.0312		.9488	2.452
10	.0497	.0949	.0633	.0469	1.5089	1.0936	2.332
11	.0693	.096	.0867	.0469		1.2498	2.4099
12	.0701	.0937	.0701	.0469			2.5766
13	.0709	.0791	.0709	.0625	2.6578	2.1247	2.6932
14	.0716	.0791	.0716	.0469	2.7401	2.0622	2.7759
15	.0724	.0633	.0905	.0312	2.7692	2.0934	2.7511
16	.0732	.0633	.0914	.0312	2.9264	2.1247	2.7252
17	.0739	.0781	.0739	.0312	2.7905	.0469	
18	.056	.0633	.0747	.0312		.0625	
19	.0754	.0625	.0754	.0312			.0754
20	.0686	.0633	.0709	.0469	.0686	.0937	.0686
21	.0867	.0625	2.9473	.0469	.0693	.0937	.0693
22	2.4013	2.1506	2.3059	.0312	.0701	.0949	.0876
23	2.4451	2.119	2.3565	.0354	.0709	.0949	.0709
24	2.13	2.3491		2.1434	.0316	.0625	.0791
Max	2.4451	2.5318	2.9473	2.1434	2.9264	2.1247	2.7759
Min	.0497	.0625	.0625	.0312	.0312	.0469	.0633
Avg	.9406	1.0098	.8193	.6099	.8396	.6035	.9911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 206 / 11KV Kurundwad Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2715	1.2483		1.3003	.8848	1.065	1.0486
2	1.1744	1.4198	1.166		.852	.9831	.9831
3	1.1517	1.1517	1.1012	.7442	.852	.9175	.9831
4	1.1462	1.0745	1.0688	.7164	.8192	.9175	.9831
5	1.1584	1.1765	1.0814	.724	.852	.9831	1.0486
6	1.1568	1.2437	1.1469	.7682	.8848	1.0159	1.0814
7	1.1568	1.3306	1.166	.8131	1.0159	1.2125	1.1469
8	1.2894	1.4003	1.1469		1.0814	1.1961	1.1142
9	1.379	1.5466	1.3435	1.3272	1.3763	1.2616	1.5466
10	1.3169	1.2955	1.3763	1.5565	1.5432	1.3435	1.4575
11	1.387	1.1142		1.5402	1.5257	1.5402	1.5604
12	1.3847	1.4091	1.6476	1.5074	1.5424	1.3763	1.5249
13	1.2934	1.2125	1.3289	1.2955	1.2757	1.2452	1.382
14	1.3253	1.1336	1.4685	1.166	1.3611	1.278	1.3969
15	1.4661	1.3279	1.5927	1.3279	1.5203	1.4746	1.6289
16	1.6278	1.3279	1.3957	1.3603	1.5912	1.5074	1.6278
17	1.4784	1.2955	1.7187	1.1336	1.7372	1.4746	1.6263
18	1.6804	1.4575	6.394	1.1012		1.6712	1.8484
19	1.8296	1.587	1.9805	1.0364			1.8673
20	1.7661	1.587	1.6804	1.1984		1.4746	1.7318
21	1.5777	1.4899	1.5257	1.1469	1.3176	1.3927	1.6991
22	1.56	1.4251	1.5424	1.1142	1.4198	1.3435	1.5775
23	1.4529	1.3279	1.4883	1.0486	1.2934	1.278	1.4529
24	1.3575	1.3032	1.2308	1.3375	.9175	1.1142	1.1797
Max	1.8296	1.587	6.394	1.5565	1.7372	1.6712	1.8673
Min	1.1462	1.0745	1.0688	.7164	.8192	.9175	.9831
Avg	1.3912	1.3286	1.6178	1.1484	1.2221	1.2638	1.3957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 207 / BASTWAD VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.298	.2774		.2774	.3258	.2378	.2772
2	.2804	.2629	.3475		.3292	.2195	.2587
3	.2686	.2481	.3109	.2481	.3109	.2195	.2614
4	.2658	.2507	.3292	.2865	.3292	.2378	.2987
5	.3155	.362	.4024	.3258	.3658	.2743	.3361
6	.3544	.4024	.4024	.3658	.3658	.3292	.3734
7	.3224	.3326	.3475	.3696	.3109	.2926	.2957
8	.3077	.3174	.3109	.2801	.2743	.2715	.2926
9	.2743	.3018	.3326	.2987	.2926	.2896	.3395
10	.2629	.3155	.3475	.2835	.2915		.2401
11	.2427	.3403	.3294	.3189	.2947	.3077	.2774
12	.2804	.3544	.333	.3582	.333	.3801	.3155
13	.2481	.333	.3366	.3582	.3544	.3801	.3189
14	.2686	.3258	.3224	.3224	.3224	.3582	.3045
15	.2715	.3439	.362	.3189	.3258	.3403	.3077
16	.2926	.3155	.3292	.3258	.3292	.3403	.2926
17	.3142	.2835	.3142	.2896	.3142	.3077	.2772
18	.2801	.2774	.3734	.2715		.3258	.2987
19	.3961	.3721	.4338	.4207			.3772
20	.4115	.4252	.3944	.4207	.2743	.3801	.3429
21	.4161	.3898	.4161	.4207	.3121	.3658	.3121
22	.4207	.4572	.4031	.4251	.3681	.3881	.3856
23	.3721	.4163	.3366	.4066	.3189	.3734	.3544
24	.3224	.3086	.3721	.3086	.3547	.2715	.3174
Max	.4207	.4572	.4338	.4251	.3681	.3881	.3856
Min	.2427	.2481	.3109	.2481	.2743	.2195	.2401
Avg	.3120	.3339	.3560	.3348	.3226	.3132	.3106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 208 / KURUNDWAD AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2774		.2254	.0305	.0154	.0309
2		.2629			.0305	.0154	.0309
3		.2481	.1829	.2126	.0305	.0154	.0309
4		.2507	.1829	.2149	.0305	.0154	.0309
5		.2715	.1981	.2353	.0305	.0154	.0309
6		.2926		.2378	.0305	.0154	.0309
7		.2772	.2439	.2957	.0305	.0154	.0309
8	.0332	.0373		.0301	.0305	.0154	.0309
9	.0328	.0377	.0301	.0305	.2896	.0154	.2452
10	.0339	.0297	.0301	.0305	.3429	.2315	.2229
11	.0347	.0305	.0347	.0305	.3641	.2134	.2601
12	.0351	.0305	.0351	.0305	.3155	.2778	.298
13	.0354	.0305	.0354	.0305	.3366	.2439	.3012
14	.0358	.0297	.0358	.0305	.3224	.2439	.3224
15	.0362	.0297	.0362	.0305	.3258	.2286	.3258
16	.0366	.0297	.0366	.0305	.3109	.2286	.3475
17	.037	.0297	.037	.0305	.037	.0305	.037
18	.0373	.0297	.0373	.0305		.0305	.0373
19	.0377	.0297	.0377	.0305			.0377
20	.0343	.0297	.0343	.0305	.0343	.0305	.0343
21	.0347	.0297	.0347	.0305	.0173	.0309	.0347
22	.298	.2107		.0305	.0175	.0309	.0351
23	.3012	.2107	.2835	.0354	.0177	.0309	.0354
24	.2686	.2915		.2401	.0305	.0154	.0309
Max	.3012	.2926	.2835	.2957	.3641	.2778	.3475
Min	.0328	.0297	.0301	.0301	.0173	.0154	.0309
Avg	.0801	.1261	.0859	.0937	.1366	.0872	.1189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 201 / 11KV Takali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1143	.1143	.1143	.0953
2	.0953	.1143	.1143	.1143	.1143	.1143	.0953
3	.0953	.1143	.1143	.1143	.1143	.1143	.0953
4	.0953	.1143	.1143	.1143	.1143	.1143	.0953
5	.1143	.1143	.1143	.1143	.1143	.1143	.0953
6	.0953	.1143	.1334	.1143	.1143	.1334	.1143
7	.1143	.1143	.1334	.1334	.1334	.1334	.1143
8	.1143	.1334	.1334	.1524	.1334	.1143	.1143
9	.1143	.1524	.1334	.1143	.1334	.1143	.1334
10	.0953	.1143	.1334	.1334	.1334	.1143	.1143
11	.1143	.1143	.1334	.1334	.1524	.1143	.0953
12	.1143	.1334	.1524	.1524	.1524	.1143	
13	.1143	.1334	.1334	.1524	.1524	.1334	.1143
14	.1143	.1334	.1524	.1524	.1524	.1524	.1334
15	.1143	.1334	.1524	.1524	.1524	.1524	.1334
16	.1334	.1143	.1524	.1334	.1524	.1524	.1524
17	.1524	.1143	.1524	.1524	.1334	.1524	.1334
18	.1334	.1334	.1905	.1905		.1524	.1143
19	.1715	.1334	.1905	.2096	.1334		.1715
20	.1715	.1524	.1905	.2096		.1334	
21	.1715	.1524	.1715	.1905	.1715	.1334	
22	.1524	.1715	.1524	.1715	.1334	.1143	
23	.1334	.1524	.1524	.1334	.1334	.0953	
24	.1334	.1334	.1334	.1334	.1143	.1334	.0953
Max	.1715	.1715	.1905	.2096	.1715	.1524	.1715
Min	.0953	.1143	.1143	.1143	.1143	.0953	.0953
Avg	.1239	.1294	.1437	.1453	.1342	.1267	.1163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 202 / 11KV Takaliwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0297	.0572	1.0402		1.0254
2	.0381	.0572	.0429	.0572	1.0402		1.0254
3	.0381	.0572	.0446	.0572	1.0402		1.0254
4	.0381	.0572	.0446	.0572	1.0105		1.0254
5	.0381	.0572	.0446	.0572	.9511		1.0254
6	.0381	.0572	.0446	.0572	.0297		1.0402
7	.0381	.0572	.0429	.0762	.0297		1.1145
8			.0446	.0572	.0297		1.1888
9		1.9052	1.5752	1.8671	.0297	.0297	.0297
10		1.4861	1.9814	1.5158	.0381	.0297	.0381
11	1.7528	1.4563	1.7909	1.4861	.0381		.0381
12	1.7528	1.7528	1.829	1.382	.0381		.0381
13	1.6385		1.6766	1.3672	.0381		.0381
14	1.6766		1.4861	1.3375	.0381	.0297	.0381
15	1.6766		1.6004	1.3375	.0381	.0297	.0381
16	1.6766	1.3077		1.3077	.0381	.0297	.0381
17	.0381	1.278	.0381	.0297	.0572	.0297	.0381
18	.0381	1.2037	.0381	.0297		.0297	.0381
19	.0381	.0297	.0572	.0446	.0381		.0381
20	.0572	.0297	.0572	.0446		.0297	.0381
21	.0572	.0446	.0572	.0446		.0297	.0381
22	.0572	.0446	.0572	1.1294		.0297	.0381
23	.0572	.0446	.0572	1.0848		.0297	
24	.0381	.0572	.0446	.0572	1.0402		.0297
Max	1.7528	1.9052	1.9814	1.8671	1.0402	.0297	1.1888
Min	.0381	.0297	.0297	.0297	.0297	.0297	.0297
Avg	.5153	.5520	.5515	.6059	.3475	.0297	.3924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 203 / 11KV Danwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3336		1.6385	.0332	.0332	.0332
2	1.3336	1.3336		1.6385	.0332	.0297	.0332
3	1.2955	1.3336	1.2929	1.6385	.0332	.0332	.0332
4	1.2955	1.3336	1.2597	1.6385	.0332	.0332	.0332
5	1.2574	1.2955	1.1603	1.6385	.0332	.0332	.0332
6	1.2955	1.2193		1.6004	.0332	.0332	.0332
7	1.2574	1.2193	1.3426		.0332	.0332	.0332
8	.0381	.0381	.0332	.0381	.0332	.0332	.0332
9	.0381	.0381	.0332	.0381	1.7404	1.5912	1.442
10	.0381	.0332	.0381	.0332	2.1719	1.6575	1.9243
11	.0381	.0332	.0381	.0332	1.9433	1.8399	2.0005
12		.0332	.0381	.0332	2.0957	1.8233	1.8861
13	.0381	.0332	.0381	.0332	1.9814	1.8067	1.9052
14	.0381	.0332	.0381	.0332	1.9814	1.757	1.7909
15	.0381	.0332	.0381	.0332	2.0957	1.6907	1.829
16	.0381	.0332	.0381	.0332	1.9052	1.6409	1.7909
17	.0381	.0332	.0381	.0332	.0381	.0332	.0381
18	.0381	.0332	.0381	.0332		.0332	.0381
19	.0381	.0332	.0572	.0332	.0381		.0381
20	.0381	.0332	.0572	.0332		.0332	.0381
21	.0381	.0332	.0572	.0332	.0381	.0332	.0381
22	1.4098	1.326	1.6385	.0332	.0381	.0332	.0381
23	1.4098	1.326	1.7147	.0332	.0381	.0332	.0381
24	1.4289	1.3717		1.6575	.0332	.0381	.0332
Max	1.4289	1.3717	1.7147	1.6575	2.1719	1.8399	2.0005
Min	.0381	.0332	.0332	.0332	.0332	.0297	.0332
Avg	.6022	.5653	.4495	.5214	.7457	.6220	.6306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 204 / 11KV Rajapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0332	.0572	1.989	1.2929	1.8861
2	.0381	.0381	.0332	.0572	1.989	1.2929	1.8861
3	.0381	.0381	.0332	.0572	1.989	1.2929	1.8861
4	.0381	.0381	.0332	.0572	1.989	1.2929	1.8861
5	.0381	.0381	.0332	.0572	1.9725	1.2929	1.8861
6	.0381	.0381	.0332	.0572	.0332	1.326	1.8861
7	.0381	.0381	.0332	.0572	.0332	1.6244	2.0957
8	.0381	.0381	.0332	.0381	.0332	1.7238	2.4006
9	2.4958	2.8578	2.7681	2.9721	.0332	.0497	.0381
10	2.7435	2.6023	3.2769	2.652	.0381	.0332	.0381
11	2.8959	2.5692	3.1626	2.652	.0381	.0332	.0381
12	2.8959	2.4034	3.1626	2.6852	.0381	.0332	.0381
13	2.934		2.9721	2.6852	.0381	.0332	.0381
14	2.8578		3.0102	2.652	.0381	.0332	.0381
15	2.6673			2.6189	.0381	.0332	.0381
16	2.6673	2.2211		2.5194	.0381	.0332	.0381
17	.0381	2.3205	.0381	.0332	.0381	.0332	.0381
18	.0381	2.4697	.0381	.0332		.0332	.0381
19	.0381		.0572	.0332	.0381		.0381
20	.0381	.0332	.0572	.0332		.0332	.0381
21	.0381	.0332	.0572	.0332	.0381	.0332	.0381
22	.0381	.0332	.0572	2.0388	.0572	.0332	.0381
23	.0381	.0332	.0572	2.0056	.0381	.0332	
24	.0381	.0381	.0332	.0572	1.989	.0381	.0381
Max	2.934	2.8578	3.2769	2.9721	1.989	1.7238	2.4006
Min	.0381	.0332	.0332	.0332	.0332	.0332	.0381
Avg	.9486	.8960	.8643	1.0893	.5694	.5069	.7124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 205 / Rajapur Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2286	.2477	.2667	.2286	.2286	.2477
2	.2286	.2286	.2477	.2667	.2286	.2286	.2477
3	.2286	.2286	.2477	.2667	.2286	.2286	.2477
4	.2286	.2286	.2477	.2667	.2286	.2286	.2477
5	.2286	.2286	.2477	.2667	.2667	.2286	.2477
6	.2858	.2286	.2667	.2667	.2286	.2286	.2477
7	.2286	.2286	.2477	.2286	.2286	.2286	.2667
8	.2096	.1905	.2477	.1905	.2286	.2286	.2667
9	.1905	.1905	.2096	.1905	.2096	.1905	.2286
10	.1905	.1905	.2096	.2096	.2096	.1658	.1905
11	.1524	.1905	.2096	.2096	.2096		.1905
12	.1905	.1905	.2286	.2286	.2286		.2286
13	.2286	.2286	.2286	.2286	.2286	.2286	.2477
14	.2286	.2286	.2477	.2477	.2477	.2858	.2477
15	.1905	.2286	.2286	.2477	.2667	.2286	.2477
16	.1905	.2477	.1905	.2286	.2477	.1905	.2096
17	.1905	.1905	.2477	.2286	.2286	.1905	.2286
18	.2286	.1715	.2477	.3239		.2667	.1905
19	.2667	.2667	.3048	.362			.2667
20	.3048	.3429	.3429	.3429		.3239	.4001
21	.3048	.3429	.3239	.3239	.3429	.3239	.381
22	.3048	.3239	.3048	.3048	.3239	.3048	.362
23	.2667	.3048	.2667	.2667	.2667	.2286	
24	.2477	.2286	.2667	.2667	.2286	.2667	.2286
Max	.3048	.3429	.3429	.362	.3429	.3239	.4001
Min	.1524	.1715	.1905	.1905	.2096	.1658	.1905
Avg	.2318	.2358	.2524	.2596	.2431	.2392	.2551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 206 / Takaliwadi Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.0762	.0572	.0762	.0572
2	.0572	.0762	.0762	.0762	.0572	.0572	.0572
3	.0572	.0762	.0762	.0762	.0572	.0572	.0572
4	.0572	.0762	.0762	.0762	.0572	.0572	.0572
5	.0572	.0762	.0762	.0762	.0572	.0572	.0572
6	.0572	.0572	.0762	.0762	.0762	.0572	.0572
7	.0572	.0572	.0953	.0762	.0762	.0762	.0762
8	.0572	.0572	.0762	.0762	.0572	.0953	.0762
9	.0572	.0762	.0572	.0762	.0762	.0572	.0572
10	.0762	.0953	.0572	.0762	.0953	.0762	.0762
11	.0762	.1143	.0572	.0762	.0953	.0953	.0953
12	.0953	.1143	.0762	.0953	.0953	.1143	.0953
13	.1143	.1143	.0953	.0953	.1143	.0953	.0953
14	.1143	.1143	.0953	.0953	.1143	.0762	.1143
15	.1143	.1143	.0953	.0953	.1143	.0953	.1143
16	.1143	.0762	.1143	.0762	.0762	.1334	.0953
17	.1143	.0762	.0953	.0762	.0762	.1334	.0953
18	.0953	.0762	.0953	.0953		.0953	.0953
19	.0953	.1143	.1143	.1143	.0762		.0953
20	.1334	.1334	.1334	.1143		.1143	
21	.1334	.1334	.1334	.1334	.1334	.1143	
22	.1143	.1143	.1334	.1143	.1143	.0953	
23	.1143	.0953	.1143	.0762	.0953	.0762	
24	.0572	.0953	.0762	.0953	.0572	.0762	.0572
Max	.1334	.1334	.1334	.1334	.1334	.1334	.1143
Min	.0572	.0572	.0572	.0762	.0572	.0572	.0572
Avg	.0866	.0921	.0905	.0881	.0832	.0862	.0791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 207 / 11 KV TAKALI (AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	1.9052		1.9814			
2	1.9433	1.9052		1.9814			
3	1.9243	1.9052	1.6766	1.9814			
4	1.9243	1.9052	1.643	1.9814			
5	1.9433	1.7147	1.576	1.9433			
6	2.0005	1.7147		1.9052			
7	2.0195	1.7147	1.4083				
9					1.6095		1.6598
10					2.0957	1.6766	2.3243
11					1.9814	1.8107	2.4577
12					2.1719	1.9113	2.4577
13					2.2862	1.8778	2.3815
14					2.2862	1.8275	2.191
15					2.4006	1.8778	2.2481
16					2.3243	1.9951	2.3243
22	1.9814	1.6933	1.9624				
23	1.9814	1.7269	1.9814				
24	2.0195	1.9433		1.9814			
Max	2.0195	1.9433	1.9814	1.9814	2.4006	1.9951	2.4577
Min	1.9243	1.6933	1.4083	1.9052	1.6095	1.6766	1.6598
Avg	1.9719	1.8128	1.7080	1.9651	2.1445	1.8538	2.2556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 208 / 11 KV SANGAM AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.724		1.3717	.0332	.0332	.0332
2	.8002	.724		1.3717	.0332	.0332	.0332
3	.8192	.724	.6299	1.3717	.0332	.0332	.0332
4	.7621	.6097	.6299	1.3717	.0332	.0332	.0332
5	.724	.6097	.6133	1.3717	.0332	.0332	.0332
6	.6478	.6097		1.3336	.0332	.0332	.0332
7	.6859	.6478	.6299		.0332	.0332	.0332
8	.0381	.0381	.0332	.0381	.0332	.0332	.0332
9	.0381	.0381	.0332	.0381	1.4255	1.5249	1.5581
10	.0381	.0332	.0381	.0332	1.7909	1.5912	1.9243
11	.0381	.0332	.0381	.0332	1.8671	1.6907	2.0005
12	.0381	.0332	.0381	.0332	1.7909	1.829	2.0005
13	.0381		.0381	.0332	1.8671	1.5746	1.9243
14	.0381	.0332	.0381	.0332	1.8671	1.5581	1.8861
15	.0381	.0332	.0381	.0332	1.7909	1.5912	1.9052
16	.0381	.0332	.0381	.0332	1.7147	1.6078	1.7528
17	.0381	.0332	.0381	.0332	.0381	.0332	.0381
18	.0381	.0332	.0381	.0332		.0332	
19	.0381	.0332	.0381	.0332	.0381	.0332	
20	.0381	.0332	.0381	.0332		.0332	
21	.0381	.0332	.0381	.0332	.0381		
22	.7621	.6299	1.3717	.0332			.0381
23	.7621	.6464	1.3717	.0332	.0381		.0381
24	1.0479	.724		1.3717	.0332	.0381	.0332
Max	1.0479	.724	1.3717	1.3717	1.8671	1.829	2.0005
Min	.0381	.0332	.0332	.0332	.0332	.0332	.0332
Avg	.3541	.3083	.2885	.4393	.6936	.6383	.7682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 209 / 11 KV Danwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1334	.1334	.1143	.1143	.1143
2		.1524	.1334	.1334	.1143	.1143	.1143
3		.1524	.1334	.1334	.1143	.0953	.1143
4	.1143	.1524	.1334	.1334	.1143	.1143	.1143
5	.1143	.1524	.1334	.1334	.1334	.1143	.1143
6	.1524	.1524	.1524	.1524	.1334	.1334	.1143
7	.1334	.1524	.1334	.1524	.1334	.1334	.1143
8	.1143	.1143	.1334	.1143	.1143	.1334	.0995
9	.1334	.1334	.0953	.0572	.1334	.1143	.0953
10	.1143	.1143	.1143	.0953	.1143	.1143	.0953
11	.1143	.1334	.1143	.0953	.1334	.1143	.1143
12	.1143	.1334	.1143	.0953	.1524		.0762
13	.1143	.1524	.1143	.0953	.1143	.1334	.0953
14	.1334	.1524	.1143	.1143	.0953	.1334	.1143
15	.1334	.1524	.1334	.1143	.1143	.1334	.1143
16	.1334	.1334	.1143	.1334	.1334	.1143	.1143
17	.1334	.1334	.0953	.1334	.1334	.1334	.1143
18	.1524	.1143	.1143	.1905		.1524	.1334
19	.1715	.1905	.1715	.2096			.1334
20	.1905	.2096	.1905	.2096		.1524	.2096
21	.1905	.2096	.1715	.1715		.1524	.1905
22	.1905	.1715	.1715	.1524	.1143	.1334	.1715
23	.1524	.1524	.1524	.1334	.1334	.1143	
24	.1334	.1524	.1334	.1334	.1143	.1334	.1143
Max	.1905	.2096	.1905	.2096	.1524	.1524	.2096
Min	.1143	.1143	.0953	.0572	.0953	.0953	.0762
Avg	.1397	.1508	.1334	.1342	.1229	.1264	.1211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 201 / 11 KV Santubai AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6404	1.6842		1.9433	.0486		.0324
2	1.6842	1.6842		1.9109	.0486		.0324
3	1.6404	1.6842	1.7394	1.8785	.0486		.0324
4	1.6404	1.6842	1.7711	1.8623	.0486	.0305	.0324
5	1.6872	1.8138	1.7869	1.8299	.0486	.0305	.0324
6	1.7652	1.8138		1.8461	.048		.0324
7	1.7444	1.8138	2.0083		.0324		.0324
8	.0492	.0305	.0474	.0486	.0492	.0305	.0324
9	.0324	.0305	.0316	.0486	2.1247	.0648	2.0243
10	.0328	.0305	.0316	.0324	2.3434	.0648	2.2024
11	.0305	.0305	.0324	.0324	2.3903	2.0729	2.1052
12	.0305	.048	.0486	.0328	2.2672	2.2565	2.1052
13	.0457	.032	.0486	.0474	2.2672	2.2565	2.0405
14	.0305	.032	.0324	.0324	2.2672	2.2085	2.0729
15		.032	.0486	.0324	2.2672	2.1445	2.0243
16	.0457	.032	.0486	.032	2.2672	2.0805	2.0081
17	.0305	.032	.0324	.0486	.003	.032	.0486
18	.0305	.032	.0486	.0486		.0048	.0486
19		.064	.0486	.0486		.048	.0486
20	.0457	.064	.0648	.0655		.048	.0648
21	.0305	.064	.0648	.0648		.0474	.0648
22	1.9757	2.0165	2.0243	.0648	.0305	.0312	.0648
23	1.9757	1.9608	1.9757	.0486	.0305	.032	.0648
24	1.7004	1.7166		1.9757	.0305	.0305	.0316
Max	1.9757	2.0165	2.0243	1.9757	2.3903	2.2565	2.2024
Min	.0305	.0305	.0316	.032	.003	.0048	.0316
Avg	.8131	.7678	.5967	.6076	.9331	.7113	.7199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 202 / 11 kv Ghosarawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.048	.0305	.0316	.048	1.4998	1.2308	1.2643
2	.0324	.0305	.0312	.048	1.2967		1.2643
3	.0328	.0305	.0316	.048	1.2811	1.2308	1.2803
4	.0328	.0305	.0316	.048	1.3117	1.2308	1.2963
5	.0324	.0305	.0316	.048	1.2654	1.2308	1.2963
6	.0324		.0474	.048	.0316	1.4251	1.3123
7	.0328		.0156	.016	.0324	1.4251	1.3123
8	.0328	.0305	.0158	.032	.0324	1.4251	1.3443
9	1.4217	1.4575	1.6446	1.5684	.0324	.0305	.016
10	1.6057	1.587	1.7711	1.6484	.0324	.0305	.016
11	1.5546	1.587	1.7924	1.6324	.0324	.0305	.016
12	1.4899	1.4083	1.7284	1.531	.0305	.016	
13	1.4899		1.6644	1.5708		.048	.016
14	1.4899		1.6964	1.4529		.032	.016
15	1.4251		1.6324	1.587	.0305	.016	.048
16		1.3763		1.5023	.0305	.016	.048
17			.032	.0324	.0305	.016	.048
18	.0305	1.4243	.048	.0324		.016	.048
19		.048	.048	.0324		.016	.176
20	.0305	.064	.048	.0324	.0305	.016	.032
21	.0305	.064	.048	.0324		.016	.032
22	.0305	.032	.032	1.2498	.0305	.016	.048
23	.0305	.032	.048	1.2967	.0305	.0158	.032
24	.0648	.0305	.0312	.048	1.3279	.0305	.0158
Max	1.6057	1.587	1.7924	1.6484	1.4998	1.4251	1.3443
Min	.0305	.0305	.0156	.016	.0305	.0158	.0158
Avg	.5224	.5163	.5435	.6494	.4416	.4157	.4773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 203 / 11 KV Ghosarawad VG

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1448	.181	.1663	.1629	.1448	.1478
2	.1448	.1448	.1829	.1478	.1629		.1478
3	.1294	.1448	.1829	.1663	.1448		.1663
4	.1463	.1448	.1829	.1848	.1646	.181	.1663
5	.1646	.181	.2012	.2033	.181	.181	.2033
6	.181	.181	.2561	.2957	.2353		.2218
7	.2012	.2534	.2743	.2587	.181		.2587
8	.1646	.2534	.2561	.2218	.2534	.2172	.2587
9	.1646	.2172	.2378	.2033	.2353	.181	.2402
10	.1646	.2172	.2378	.2033	.2378	.1448	.2218
11		.0217	.2402	.1848	.2353	.1448	.2402
12	.1448	.2195	.2587	.2172	.2172	.1829	
13	.181	.2353	.2218	.2195	.2172	.2012	.2402
14		.2353	.2402	.2353	.2172	.2195	.2587
15	.2172	.2378	.2402	.2378	.2172	.2561	.2587
16		.1991	.1478	.1629	.2172	.2743	.2772
17		.1991	.1663	.1448	.1086	.2195	.2402
18		.128	.1848	.1629		.1829	.1848
19	.2172	.1991	.2033	.2172		.2033	.2033
20	.2534	.2534	.2402	.2172	.181	.2561	.2587
21	.1829	.2534	.2402	.2195		.2012	.2507
22	.2172	.2378	.2218	.1991	.0181	.1829	.2402
23	.2172	.1991	.2033	.1781	.1448	.1663	.2218
24	.1629	.181	.1791	.1848	.181	.1448	.1463
Max	.2534	.2534	.2743	.2957	.2534	.2743	.2772
Min	.1294	.0217	.1478	.1448	.0181	.1448	.1463
Avg	.1789	.1951	.2159	.2014	.1864	.1943	.2197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 204 / 11 kv Balumama AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.587		1.656	.0486		.0312
2	1.587	1.587		1.6248	.0486		.0312
3	1.587	1.587	1.5971	1.6091	.048		.0312
4	1.5466	1.587	1.6288	1.5935	.0486	.0305	.0312
5	1.6385	1.587	1.6604	1.5779	.0486		.0312
6	1.5497	1.6194		1.5779	.0324		.0312
7	1.5074	1.6194	1.7185		.0324		.0312
8	.0328	.0305	.0474	.0312	.0324	.0305	.0312
9	.0486	.0305	.0474	.0312	1.9216	1.5546	1.8122
10	.0492	.0305	.0474	.0469	2.1091	2.0081	1.9052
11		.0305	.0312	.0469	1.9528	2.1052	1.9372
12	.0305	.0474	.0312	.0486	1.9433	1.9925	1.7341
13	.0305	.0474	.0469	.0486	1.9433	1.9292	1.781
14	.0305	.0474	.0469	.0486	1.9433	1.8976	1.7654
15		.0474	.0469	.0324	1.9433	1.8027	1.7966
16	.0305	.0474	.0312	.048	1.9433	1.7869	1.8122
17	.0457	.0474	.0469	.0486	.0305	.0316	
18	.0305	.0474	.0312	.0474		.0316	
19		.0474	.0469	.0486		.0316	
20	.0305	.048	.0469	.0486	.0305	.0312	.0312
21	.0305	.0474	.0469	.0486		.0312	.0469
22	1.8461	1.7711	1.7497	.0486	.0305	.0312	.0625
23	1.8138	1.7185	1.7497	.0486	.0305	.0312	.0625
24	1.6194	1.6194		1.7029	.0486	.0305	.0312
Max	1.8461	1.7711	1.7497	1.7029	2.1091	2.1052	1.9372
Min	.0305	.0305	.0312	.0312	.0305	.0305	.0312
Avg	.7955	.7033	.5350	.5245	.7719	.8549	.7156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 205 / 11 KV Dattawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.003	.032	.0328	1.3927	.9717	1.0159
2	.0328	.0305	.0312	.0312	1.3279	.9717	1.0159
3	.0328	.0305	.0316	.0328	1.3763	.9717	1.0159
4	.0324	.0305	.0316	.0328	1.3283	.9717	1.0159
5	.0324	.0305	.0316	.0328	1.2967	.9717	1.0159
6	.0328	.0305	.0316	.0328	.0324	1.1336	1.0486
7	.0492		.032	.0328	.0324	1.1336	1.0486
8	.0486		.032	.0492	.032	1.1336	1.0978
9	1.5466	1.8785	1.8185	1.7859	.0324	.0305	.0328
10	1.6712	1.8461	1.8724	1.8187	.0328	.0305	.0492
11	1.668	1.8461	1.9334	1.8351	.0324	.0305	.0492
12	1.6518	1.7924	1.8515	1.4842	.0305	.048	.0328
13	1.6518		1.7532			.048	.0328
14	1.6518		1.6876	1.4373		.048	.0312
15	1.7166			1.5813	.0305	.048	.0328
16	1.6194	1.6324		1.6091	.0305	.048	.0328
17		1.6324	.0328	.0324		.032	
18	.0305	1.6164	.0328	.0648		.032	.0328
19		.032	.0328	.0328		.032	.0328
20	.0305	.032	.0328	.0324	.0305	.032	.0328
21	.0305	.032	.0328	.0324		.032	.0328
22	.0305	.032	.0328	1.4089	.0305	.0316	.0328
23	.0305	.0316	.0328	1.4089	.0305	.032	.0328
24	.0324	.0305		.0328	1.3435	.0305	.0316
Max	1.7166	1.8785	1.9334	1.8351	1.3927	1.1336	1.0978
Min	.0305	.003	.0312	.0312	.0305	.0305	.0312
Avg	.6207	.6626	.5428	.6467	.4690	.3685	.3825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 206 / 11 KV Dattawad VG

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2534	.2896	.3077	.2896	.2534	.2534
2	.2534	.2534	.2926	.2896	.2715		.2534
3	.2561	.2534	.2926	.2896	.2715		.2353
4	.2378	.2534	.2926	.2896	.2715	.2534	.2353
5	.2561	.0253	.2926	.2896	.2896	.2896	.2353
6	.2743	.2534	.3258	.3258	.3258		.2534
7	.2896		.3109	.3077	.2896		.2896
8	.2172	.2896	.2378	.2715	.2534	.2172	.2534
9	.1966	.2534	.2926	.2715	.2896	.2172	.2534
10	.2195	.2896	.2926	.3258	.3258	.2534	.0543
11		.2896	.3258	.3258	.3258	.2534	.2896
12	.2172	.2896	.3258	.362	.3258	.2561	.3077
13	.2534	.2896	.362	.3258	.3258	.2926	.3077
14		.2896	.3439	.362	.3258	.2926	.2896
15	.2534	.2896	.3258	.3224	.3258	.2926	.3077
16		.3258	.3258	.3258	.3258	.2561	.3077
17		.3258	.2896	.2896	.2896	.2926	.2896
18		.3258	.3258	.3258		.3292	.2896
19	.3258	.3258	.362	.4344		.3881	.362
20	.3982	.4344	.3982	.3982	.362	.3658	.4298
21	.3982	.3801	.362	.362		.3292	.3801
22	.362	.362	.362	.362	.2896	.3109	.3439
23	.3258	.3258	.3258	.3077	.2534	.2957	.2896
24	.2534	.3292	.2896	.3258	.3077	.2534	.2561
Max	.3982	.4344	.3982	.4344	.362	.3881	.4298
Min	.1966	.0253	.2378	.2715	.2534	.2172	.0543
Avg	.2768	.2916	.3185	.3249	.3017	.2846	.2820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 207 / 11 KV Hanuman AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0152	.0147	.0152	.8535	.7449	
2	.0152	.0152	.0145	.0152	.823	.7449	
3	.0152	.0152	.0145	.0152	.823	.9717	
4	.0152	.0152	.0147	.0152	.7926	.7449	
5	.0152	.0152	.0145	.0152	.7926	.7449	
6	.0152	.0152	.0145	.0152	.0152	.7449	
7	.0152		.0143	.0152	.0152	.9069	
8	.0152	.0305	.0149	.0152	.0152	.9069	
9	.9145	1.1012	1.1145	1.1431	.0152	.0152	
10	.9297	1.0688	1.07	1.1584	.0152	.0152	
11	1.0364	1.0688	1.0517	1.1126	.0152	.0152	
12	1.004	1.0059	.9755	1.0822	.0152	.0151	.8993
13	.9717		.9907	1.0669		.0151	.8993
14	.9717		.9602	.9907		.0151	.0152
15	.9717			1.0059	.0152	.0151	.0152
16	.9717	.9031		.9755	.0152	.0152	.0152
17	.0152	.873	.0152	.0152	.0152	.0152	.0152
18	.0152	.9482	.0152	.0152		.0151	.0152
19		.0151	.0152	.0152		.0151	.0152
20	.0152	.0152	.0152	.0152	.0152	.0151	.0152
21	.0152	.016	.0152	.0152		.0151	.0152
22	.0152	.0152	.0152	.9145	.0152	.0151	.0152
23	.0152	.0147	.0152	.8535	.0152	.0151	.0152
24	.0152	.0152	.0147	.0152	.8535	.0152	.0149
Max	1.0364	1.1012	1.1145	1.1584	.8535	.9717	.8993
Min	.0152	.0147	.0143	.0152	.0152	.0151	.0149
Avg	.3478	.3591	.2909	.4382	.2703	.2813	.1512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 201 / 11KV Shirati Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1867	.1823	.2054	.2096	.1494	.1829
2	.1494	.1867	.1658	.1867	.2096	.1307	.1829
3	.1494	.1905	.1989	.1867	.2096	.1307	.1867
4	.1867	.1867	.1823	.1867	.2096	.1307	.2054
5	.2241	.2096	.2155	.2054	.2858	.1307	.2427
6	.2614	.2427	.2486	.2614	.2667	.1867	.2987
7	.2801	.2096	.1989	.1867	.2667	.168	.2614
8	.2241	.1715	.1823	.2054	.2241	.1494	.2155
9	.2096	.1494	.1492	.2241	.2427	.1494	.1989
10	.2096	.1494	.1823	.2054	.2427	.1029	.1989
11	.1524	.2241	.1823	.2054	.2054	.112	.1823
12	.1524	.1494	.1658	.1867	.2614		.1658
13	.2286	.2075	.1867	.1867	.2427	.1097	.1989
14	.1905	.1867	.1867	.2241	.2241		.1658
15	.2096	.2241	.1867	.168	.2427		
16	.1715	.1867	.1867	.1905	.2427		
17	.2286	.181	.1867	.1334			
18	.2096	.2012	.2427	.1905			
19	.2286	.2012	.2427	.2667		.2378	
20	.2858	.2561	.2614	.2667		.2614	
21	.2477	.2896	.2614	.2667		.2987	
22	.2477	.2427	.2241	.2667	.168	.2561	
23	.2286	.2054	.2054	.2477		.2378	
24	.2054	.1905	.2054	.2054	.2096	.1494	.2241
Max	.2858	.2896	.2614	.2667	.2858	.2987	.2987
Min	.1494	.1494	.1492	.1334	.168	.1029	.1658
Avg	.2096	.2012	.2013	.2108	.2313	.1718	.2074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 202 / KUTWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7551	1.6004	.0366	1.2266	.0381		.0343
2	1.7177	1.5432	.0373		.0381		.0343
3	1.6991	1.5242	1.307	1.1576	.0381		.0343
4	1.6804	1.5242	1.2803	1.2696	.0381		.0343
5	1.6991	1.5051	1.2803	1.1389	.0381		.0343
6	1.7177	1.5051	.0366	1.1576	.0191		.0343
7	1.6991	1.5242	1.3169	.0373	.0191		.0343
8	.0373	.0381	.0366	.0373	1.8111		
9	.0191	.0343	.0332	.0373	1.531		.8453
10	.0191	.0343	.0332	.0187	1.8111		.9779
11	.0191	.0343	.0332	.0373	1.9418		1.0277
12	.0191	.0171	.0332	.0187	1.6617	.2743	1.0277
13	.0191	.0373	.0332	.0187	1.9044	.5975	.9945
14		.0343	.0332	.0187	1.9605	.5853	.9945
15	.0191	.0343	.0332	.0187	1.9418	.567	1.0111
16	.0191		.0332	.0381	1.8484	.5487	.9779
17	.0191		.0332	.0381			.0332
18	.0381	.0362	.0332	.0381			.0332
19	.0381	.0343	.0332	.0381		.0343	.0332
20	.0381	.0343	.0332	.0381		.0343	.0332
21	.0381	.0343	.0332	.0381		.0343	.0332
22	1.6194	1.448	1.1768	.0191		.0343	.0497
23	1.6385	1.4563	1.3817	.0381		.0343	.0497
24	1.8111	1.6004		1.3443	.0381		.0343
Max	1.8111	1.6004	1.3817	1.3443	1.9605	.5975	1.0277
Min	.0191	.0171	.0332	.0187	.0191	.0343	.0332
Avg	.7556	.7106	.3618	.3401	.9811	.2744	.3651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 203 / SHIROL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1845	2.3624	.0343	1.9227	.0572		.0497
2	2.1845	2.2672	.0343	1.5581	.0572		.0497
3	2.1845	2.2481	2.1765	1.5083	.0572		.0497
4	2.2032	2.2481	2.1582	1.6907	.0572		.0497
5	2.2032	2.2481	2.1582	1.6741	.0572		.0343
6	2.4272	2.3624	.0343	1.7736	.0572		.0343
7		2.3624	2.3339	.0332	.0572		.0351
8		.0381	.0366	.0332	.056		.0497
9		.0343	.0332	.0373			1.989
10		.0343	.0332	.056		2.3228	2.1216
11	.0191	.0343	.0332	.056	2.3525	2.3339	2.0553
12	.0191	.0343	.0332	.056	2.5953	2.3339	2.1051
13	.0191	.0343	.0332	.056	2.5206	2.1719	2.0222
14	.0191	.0343	.0332	.0373	2.5766	2.1658	1.9725
15	.0191	.0343	.0332	.056	2.726	2.1098	1.9725
16	.0381		.0332	.0381	2.6326	1.9204	1.989
17	.0381	.0343	.0332	.0381		.0514	.0663
18	.0381	.0343	.0332	.0381		.0514	.0663
19	.0572	.0362	.0332			.0343	.0332
20	.0572	.0362	.0332	.0381		.0343	.0663
21	.0572	.0362	.0332	.0381		.0343	.0663
22	2.572	2.4326	2.2045	.0381		.0343	.0829
23	2.5911	2.0919	2.1051	.0572		.0686	.0829
24	2.2405	2.4768		2.0222	.0572		.0686
Max	2.5911	2.4768	2.3339	2.0222	2.726	2.3339	2.1216
Min	.0191	.0343	.0332	.0332	.056	.0343	.0332
Avg	1.0586	1.0241	.5960	.5590	1.0611	1.1191	.7130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 204 / GHALWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0381	.0343	.0829	1.9624		
2	.0373	.0381	.0343	.0829	1.9624		
3	.0373	.0381	.0343	.0829	1.9624		
4	.0373	.0381	.0343	.0829	1.9624		
5	.0373	.0381	.0343	.0829	2.0005		
6	1.7737	.0381	.0343	.0829	.0381		
7	.0373	.0381	.0343	.0829	.0381		
8	.0373	.0381	.0343	.0829	.0373		
9	2.0195	2.4459	2.0388	.0934	.0934		
10	2.3053	2.2634	2.0885	2.2965	.0934		
11	2.3624	2.5206	2.1548	2.4459	.0934		
12	2.3815	2.5206	2.1879	2.2592	.0934		
13	2.3815	.0373	2.2211	2.3525	.0934		
14	2.2672	.0343	2.2211	2.4272	.0934	.5975	
15	2.2672	.0344		2.3339	.0934	.591	
16	2.2291	2.2592		2.2481	.0934	.5973	.4973
17	.0381	2.1538	.0995	.0381			.5967
18	.0381	1.8642	.0995	.0381			.5967
19	.0381	.0343	.0995	.0381			.0829
20	.0381	.0362		.0381			.0829
21	.0381	.0343		.0381			.0829
22	.0381	.0343		2.0005			.3978
23	.0381	.0343		1.9624			.4973
24	.0373	.0381	.0343	.0829	1.9624		
Max	2.3815	2.5206	2.2211	2.4459	2.0005	.5975	.5967
Min	.0373	.0343	.0343	.0381	.0373	.591	.0829
Avg	.8564	.6938	.7511	.8898	.7455	.5953	.3543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 205 / 11KV Shirti Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0191	.0343	.0332	1.5623	
2	.0373	.0191	.0373	.0332	1.5623	
3		.0191	.0373	.0332	1.5623	
4		.0191	.0373	.0332	1.5623	
5		.0191	.0373	.0332	1.5813	
6		.0191	.0373	.0332	.0381	
7	.0373	.0191	.0373	.0332	.0381	
8	.0373	.0191	.0373	.0332	.0747	
9	2.5149	2.6139	2.1382	.0373	.0747	
10	2.5911	2.6139	2.0222	2.2779	.0747	
11	2.7244	2.6699	2.2211	2.4272	.0747	
12	2.7054	2.5393	2.2874	2.3525	.0747	
13	2.5339	.0373	2.2211	2.3152	.0747	
14	2.5149	.0343	2.1382	2.3525	.0747	
15	2.3243	.0373	2.1051	2.2032	.0747	
16	2.4006	2.1098		2.2291	.0747	
17	.0191	1.9204	.0332	.0381		
18	.0191	1.9728	.0332	.0381		.0663
19	.0191	.0343	.0332	.0381		.0663
20	.0191	.0373	.0332	.0381		.0332
21	.0191	.0343	.0332	.0381		.0663
22	.0191	.0343	.0332	1.6766		.4807
23	.0191	.0343	.0332	1.5623		.5138
24	.0373	.0191	.0343	.0332	1.5623	
Max	2.7244	2.6699	2.2874	2.4272	1.5813	.5138
Min	.0191	.0191	.0332	.0332	.0381	.0332
Avg	1.0315	.7040	.6824	.8301	.5965	.2044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 206 / Kutwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1524	.168	.1326	.1524	.056	.1307
2	.112	.1524	.1494	.1326	.1524	.056	.1307
3	.112	.1524	.168	.1326	.1524	.056	.1307
4	.1307	.1524	.168	.1326	.1524	.056	.1494
5	.1494	.1524	.168	.1326	.1715	.056	.168
6	.1494	.1715	.1867	.1492	.1715	.0747	.1867
7	.1494	.1715	.1867	.1492	.1715	.0934	.1543
8	.112	.1524	.1867	.116	.1307	.0934	.116
9	.0953	.1494	.116	.1326	.1307	.1029	.0995
10	.0953	.1494	.0829	.116	.1494		.116
11	.0953	.1307	.0829	.1494	.1494	.0934	.116
12	.0953	.168	.116	.168	.1494	.1029	.0995
13	.1143	.168	.1326	.1494	.168	.1307	.116
14	.0953	.1494	.1492	.1494	.168	.112	.116
15	.1143	.1494	.1492	.1494	.168	.1494	
16	.1143	.1307	.116	.1143	.1494		.116
17	.1143	.112		.1334			.0829
18	.1334	.1267	.1326	.1524			.0995
19	.1715	.1448	.0995	.1905		.1463	.1492
20	.2096	.1991	.1658	.2096		.1646	.1658
21	.2096	.2012	.1658	.1905		.2172	.1658
22	.2096	.1867	.1658	.1905	.0747	.1829	.1492
23	.1715	.168	.1492	.1715	.0747		.1326
24	.1494	.1524	.168	.1326	.1524	.056	.1494
Max	.2096	.2012	.1867	.2096	.1715	.2172	.1867
Min	.0953	.112	.0829	.1143	.0747	.056	.0829
Avg	.1340	.1560	.1467	.1490	.1468	.1053	.1322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 207 / Ghalwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2477	.2743	.1989	.2477	.2614	.2353
2	.2427	.2477	.2561	.2321	.2477	.2614	.2172
3	.2427	.2477	.2743	.2652	.2477	.2614	.2229
4	.2427	.2477	.2743		.2477	.2801	.2195
5	.3361	.2858	.2926	.3149		.3174	.2987
6	.3395	.3239	.3475	.2984		.3361	.3361
7	.2987	.2477	.2926	.2321		.2801	.2743
8	.2614		.2743	.1989	.2427	.2614	.2321
9	.2667	.2427	.2321	.2241	.2801	.2801	.2321
10	.2477	.2427	.2155		.2427	.2601	.2321
11	.1905	.2427	.2486	.2801	.2987	.2801	.2321
12	.1905	.2241	.1989	.2241	.2801	.2172	.1989
13	.2286	.2427	.1823	.2054	.2614	.2534	.1989
14	.2477	.2241	.1989	.2614	.2987	.2378	.1823
15	.2477	.2987	.1989	.2427	.2614	.2378	.1823
16		.2054	.1658	.3048	.2987	.1867	.1823
17	.2477	.2172	.1658	.2096	.2987	.2058	.1989
18	.2096	.2715	.2486	.2477		.2229	.1823
19	.2858	.2614	.2652	.2667		.2987	.2321
20	.3048	.3258	.2652	.3239		.2614	.2984
21	.3048	.2896	.2652	.3429	.1867	.2896	.2818
22	.3048	.2926	.2486	.3048	.2614	.2926	.2652
23	.2858	.2896	.2486	.2667	.2614	.2534	.2321
24	.2614	.2667	.2534	.1823	.2667	.2614	.2378
Max	.3395	.3258	.3475	.3429	.2987	.3361	.3361
Min	.1905	.2054	.1658	.1823	.1867	.1867	.1823
Avg	.2622	.2602	.2453	.2558	.2628	.2624	.2336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 201 / 11KV K'Guland

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	1.5912	.0152	1.4251	.0166	
2	1.3413	1.5912	.0152		.0166	
3	1.3413	1.5912	1.326	1.1233	.0166	
4	1.3413	1.5746	1.3592	1.1401	.0166	
5	1.3413	1.5746	1.3923	1.1568	.0166	
6	1.3717	1.6409	.0152	.0168	.0166	
7	1.4575	1.442	1.4918	.0152	.0166	
8	.0152	.0152	.0152		.0171	
9	.0152	.0152	.0152	.0152	1.4089	
10	.0152	.0152	.0152	.0166	1.749	.4862
11	.0152	.0152	.0152	.0166	1.7814	
12	.0152	.0152	.0152	.0166	1.7814	.5197
13	.0152	.0152	.0152	.0166	1.7814	1.1233
14	.0152	.0152	.0152	.0166	1.749	
15	.0152	.0152	.0152	.0166	1.6194	1.2071
16	.0152	.0152	.0171	.0166	1.6004	1.2574
17	.0152	.0152	.0152	.0166		
18	.0152	.0152	.0152	.0166		
19	.0152	.0152	.0152	.0166		
20	.0152	.0152	.0152	.0166		
21	.0152	.0152	.0152	.0166		
22	1.5746	1.5746	1.4419	.0166		.0166
23	1.5912	1.5415	1.4922	.0171		.0166
24	1.4251	1.5912	.0152	1.4922	.0166	
Max	1.5912	1.6409	1.4922	1.4922	1.7814	1.2574
Min	.0152	.0152	.0152	.0152	.0166	.0166
Avg	.5975	.6636	.3658	.3008	.8012	.6610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 202 / 11KV Ganeshwadi

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0162	.0162	.0171	2.0576	
2	.0152	.0162	.0162	.0171	2.0576	
3	.0152	.0162	.0162	.0171	2.0576	
4	.0152	.0162	.0162	.0171	2.0576	
5	.0152	.0162	.0162	.0171	.0171	
6	.0152	.0162	.0162	.0171	.0171	
7	.0152	.0162	.0162	.0171	.0171	
8	.0152	.0162	.0162	.0171	.0171	
9	2.4291	2.6052	2.5396	.0171	.0171	
10	2.556	2.4577	2.8881	2.3148	.0152	
11	2.6216	2.6543	2.8704	2.6578	.0152	
12	2.5888	2.5888	2.7818	2.7435	.0152	
13	2.5232		2.7641	2.6578	.0152	
14	2.2283		2.6223	2.6578	.0152	
15	2.2283	.0162	.0171	2.6063	.0152	
16	2.2283	2.1792	.0171	2.572	.0152	
17	.0162	2.0972	.0171	.0171	.0152	
18	.0162	2.1628	.0171	.0171		
19	.0162	.0162	.0171	.0171		
20	.0162	.0162	.0171	.0171		
21	.0162	.0162	.0171	.0171		
22	.0162	.0162	.0171	2.2291		.6687
23	.0162	.0162	.0171	2.2291		.6104
24	.0166	.0162	.0162	.0171	2.2291	
Max	2.6216	2.6543	2.8881	2.7435	2.2291	.6687
Min	.0152	.0162	.0162	.0171	.0152	.6104
Avg	.8190	.7722	.6986	.9552	.5926	.6396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 203 / 11KV Alas Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0152	.0152	.0143	1.0608		.7122
2	.0152	.0152	.0152	.0143	1.0608		.6539
3	.0152	.0152	.0152	.0143	1.0608		.6706
4	.0152	.0152	.0152	.0143	1.0608		.7042
5	.0152	.0152	.0152	.0143	1.0608		.7377
6	.0152	.0152	.0152	.0143	.0166		.7625
7	.0166	.0152	.0152	.0143	.0166		.8684
8	.0152	.0152	.0152	.0143	.0166		.8619
9	1.1336	1.2407	1.3916	.0143	.0168		.0143
10	1.3077	1.2483	1.4083	1.073	.0162		.0143
11	1.291	1.2308	1.3413	1.2071	.0152		.0143
12	1.2742	1.3592	1.3077	1.3077	.0152		.0143
13	1.2407		1.3245	1.3413	.0152		.0143
14	1.2407		1.291	1.3413	.0152		.0143
15	1.2574	.0152	1.2742	1.3077	.0152		.0143
16	1.2742	1.1568	.0143	1.3077	.0152		.0143
17	.0152	1.1437	.0143	.0166	.0152		.0166
18	.0152	1.2239	.0143	.0166			.0166
19	.0152	.0152	.0143	.0166			.0166
20	.0152	.0152	.0143	.016			.0166
21	.0152	.0152	.0143	.0166			.0166
22	.0152	.0152	.0143	1.0898		.0152	.0166
23	.0152	.0152	.0143	1.0898		.0152	.0166
24	.016	.0152	.0152	.0143	1.0898		.0152
Max	1.3077	1.3592	1.4083	1.3413	1.0898	.0152	.8684
Min	.0152	.0152	.0143	.0143	.0152	.0152	.0143
Avg	.4277	.4014	.3996	.4705	.3657	.0152	.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 204 / 11KV Alas Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.5083	.5258	.5316	.5258		.5959
2	.4115	.4908	.5258	.5138	.5258		.5959
3	.0171	.4733	.4908	.4784	.5258		.5784
4	.3772	.4733	.4908	.4784	.5258		.5609
5	.3772	.4908	.5258	.5138	.5258		.5784
6	.4115	.5083	.5434	.5434	.4908		.6135
7	.3772	.5083	.4908	.4961	.4557		.5959
8	.3429	.5083	.4382	.4961	.4207		.5258
9	.3429	.4382	.4382	.4607	.4252		.5138
10	.3506	.5258	.5316	.4908	.4115		.5316
11	.2454	.4908	.4607	.3506	.4115		.5316
12	.4031	.5258	.443	.4557	.3772		.5138
13	.4557	.5609	.5493	.567	.3772		.5493
14	.4382	.5258	.567	.5609	.3772		.567
15	.4382	.5258	.567	.5609			.567
16	.4207	.5258	.5316	.5784	.5144		.6024
17	.4031	.4733	.4607	.5609	.4458		.5316
18	.4382	.4908	.6379	.5258			.5316
19	.5784	.5959	.7087	.6485			.5959
20	.7011	.7011	.7087	.6661		.8238	.7537
21	.6661	.631	.6556	.6485			.7362
22	.631	.6135	.6201	.631		.7712	.7011
23	.5609	.5784	.5847	.5784		.7362	.6485
24	.4161	.5258	.5609	.5316	.5609		.631
Max	.7011	.7011	.7087	.6661	.5609	.8238	.7537
Min	.0171	.4382	.4382	.3506	.3772	.7362	.5138
Avg	.4257	.5288	.5440	.5361	.4645	.7771	.5896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 205 / 11KV Ganeshwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4938	.4572	.443	.4525		.3841
2	.3429	.4938	.4938		.4572		.3841
3	.3429	.4755	.4755	.4252	.4572		.3658
4	.3429	.4572	.4755	.4252	.4755		.3658
5	.3772	.4572	.4938	.4252	.4938		.4024
6	.4115	.4755	.4938	.4784	.4525		.439
7	.3772	.4024	.4207	.4607	.4163		.4024
8	.3429	.3841	.3841	.4075	.3841		.4024
9	.3429	.3475	.4024	.3366	.3681		.4075
10	.3475	.3475	.3544	.3841	.3772		.3898
11	.3292	.3841	.3898	.3475	.3772		.3898
12	.3475	.3658	.3898	.439	.3772		
13	.3292	.3658	.4252	.3841	.4287		
14	.3841	.439	.4252	.3982	.4115		
15	.3841	.4024	.4252	.4344	.4115		.4961
16	.4024	.3841	.4252	.4163	.3772		.4607
17	.3841	.3658	.443	.4344	.362		.4525
18	.4572	.3292	.4961	.4938			.4706
19	.5121	.4572	.4961	.567			.4887
20	.6401	.5304	.567	.5611		.567	.6697
21	.5853	.5487	.567	.5611		.6219	.6036
22	.5853	.5487	.5493	.5304		.5487	.567
23	.5487	.5304	.4961	.4887		.439	.4207
24	.4115	.5121	.5121	.4784	.4706		.4024
Max	.6401	.5487	.567	.567	.4938	.6219	.6697
Min	.3292	.3292	.3544	.3366	.362	.439	.3658
Avg	.4127	.4374	.4608	.4487	.4195	.5442	.4460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 206 / 11KV Krishna Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3772	.3734	.3734	.3395	.0343
4	.3772	.3734	.3734	.3772	.2743
5	.3772	.3734	.3921	.3772	.3658
6	.3772	.3921	.3921	.3772	.3658
7	.3772	.3734	.3921	.3772	.3696
8	.3772	.3734	.3921	.3429	.3696
9	.3772	.3734	.3921	.3772	.3734
10	.362	.3921	.3772	.3391	.3734
11	.362	.3921	.3772	.3391	.3734
12	.3696	.3921	.3772	.3391	.3734
13	.3696	.3921	.3772	.3391	.3734
14	.3696	.3921	.3961	.3429	.3734
15	.3696	.3921	.3961	.3429	.3734
16	.3734	.3921	.3772	.3429	.3734
17	.3696	.3921	.3961	.3429	.3772
18	.3734	.3921	.3772		.3772
Max	.3772	.3921	.3961	.3772	.3772
Min	.362	.3734	.3734	.3391	.0343
Avg	.3725	.3851	.3849	.3531	.3451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 207 / 11KV Vijay-Ganesh

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1086	.1494	.124	.1715	
4	.1086	.2587	.2303	.2229	
5	.1448	.2561	.2303	.2401	
6	.1448	.2641	.2303	.2229	
7	.1448	.2641	.2303	.2229	
8	.1448	.2829	.2303	.2229	
9	.2743	.2772	.2303	.2743	
10	.2561	.2481	.2279	.3391	.1417
11	.2561	.2481	.2534	.3391	.2658
12	.2801	.2481	.2454	.3391	.2658
13	.2561	.2481	.2454	.3391	.3366
14	.2561	.2481	.2401	.3391	.3366
15	.2561	.2481	.2401	.3429	.3544
16	.2561	.2481	.2279	.3258	.2835
17	.2561	.2481	.2058	.3086	
18	.1646	.2481	.1543		
Max	.2801	.2829	.2534	.3429	.3544
Min	.1086	.1494	.124	.1715	.1417
Avg	.2068	.2491	.2216	.2834	.2835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 208 / 11 KV Bubnal Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.181	.0373	.0886	.1372	.1109
4	.1991	.0924	.1417	.1715	.1109
5	.1991	.0924	.1417	.1715	.1109
6	.1991	.0924	.1417	.1715	.1294
7	.1991	.0934	.124	.1715	.1294
8	.2012	.0934	.124	.1715	.2614
9	.2561	.0934	.124	.1715	.1949
10	.2012	.0924	.2454	.2915	.1949
11	.2587	.2126	.2454	.2915	.2481
12	.2587	.2481	.1402	.2915	.1949
13	.2587	.2481	.1227	.2572	.1417
14	.2587	.2481	.2279	.2572	.1595
15	.2587	.2481	.2279	.2401	.1595
16	.2587	.2481	.2279	.2229	.1595
17	.2587	.2481	.2279	.2229	.2743
18	.1848	.1949	.2279		.2229
Max	.2587	.2481	.2454	.2915	.2743
Min	.181	.0373	.0886	.1372	.1109
Avg	.2270	.1615	.1737	.2161	.1752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 201 / 11 KV Nandani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0181	.0187	.5601	.0175	.6653
2	.0187	.0181	.0181	.0187	.5601	.0177	.6653
3	.0187	.0187	.0179	.0187	.5601	.0179	.7392
4	.0187	.0181	.0177	.0187	.5601	.0179	.7392
5	.0187	.0181	.0177	.0187	.5601	.0179	.8131
6	.0187	.0181	.0175	.0187	.0181	.0179	.8501
7	.0185	.0181	.0191	.0187	.0181	.0187	1.0456
8	.0183	.0187	.0191	.0181	.0181	.0191	1.0082
9		1.4861		1.419	.0191	.0191	.0181
10	1.4937	1.4289	1.4937	1.3443	.0191	.0191	.0181
11	1.307	1.448	1.531	1.2696	.0191		.0181
12	1.3443	1.4289	1.4335	1.2323	.0191	.6478	.0181
13	1.307		1.2449	1.1576	.0191	.6859	
14	1.307		1.2071	1.1576	.0191	.7621	
15	1.307		1.2071	1.1203	.0191	.7621	.0181
16	1.307	1.3336	.0187	1.1203	.0191	.724	.0181
17	.0181	1.1431	.0187	.0187		.0191	.0181
18	.0181	1.1431	.0185	.0187		.0191	.0187
19	.0181	.0191	.0185			.0191	.0181
20	.0181	.0191	.0187		.0173	.0191	.0181
21	.0181	.0191	.0187	.0187	.0179	.0191	.0181
22	.0181	.0179	.0189	.6348	.0183	.0191	.0181
23	.0181	.0181	.0189	.5975	.0179	.0187	.0181
24	.0187	.0181	.0179	.0189	.5601	.0175	.0187
Max	1.4937	1.4861	1.531	1.419	.5601	.7621	1.0456
Min	.0181	.0179	.0175	.0181	.0173	.0175	.0181
Avg	.4203	.4605	.3665	.5126	.1733	.1702	.3082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 202 / 11 KV Nandani Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3801	.3982	.4108	.362	.3506	.3696
2	.3734	.3801	.3801	.4108	.362	.3544	.3696
3	.3734	.362	.3582	.3734	.362	.3582	.3696
4	.3734	.362	.3544	.4108	.362	.394	.4066
5	.4481	.3982	.4252	.4668	.3801	.4298	.4435
6	.4854	.4344	.5083	.5041	.4344	.4656	.4805
7	.4435	.4525	.4763	.4481	.4706	.4108	.4481
8	.439	.4163	.4191	.4294	.4706	.4191	.4668
9	.3921	.4763	.4805	.4108	.4763	.4191	.4525
10	.3734	.4954	.4854	.4481	.4763	.4191	.3982
11	.4294	.5144	.5041	.4854	.4763	.4572	.4163
12	.4668	.4001	.5281	.5228	.4763	.4954	.362
13	.3734	.4001	.4338	.4854	.4763	.4572	.3982
14	.3734	.3734	.4904	.4854	.4763	.4191	.362
15	.3734	.3881	.5281	.5041	.4763	.4191	.3801
16	.4668	.5144	.4854	.4854	.4954	.4763	.4344
17	.4706	.4954	.4668	.4854	.5144	.4572	.4163
18	.4887	.4954	.4066	.5041		.4572	.4344
19	.4887	.5716	.5175			.4954	.4706
20	.5792	.5906	.5601		.4334	.5335	.5973
21	.5792	.5906	.547	.5415	.4656	.4954	.543
22	.543	.4835	.5281	.4854	.4755	.4763	.543
23	.4887	.4525	.4904	.4481	.394	.4108	.4887
24	.4294	.4344	.4298	.4527	.4294	.3681	.3881
Max	.5792	.5906	.5601	.5415	.5144	.5335	.5973
Min	.3734	.362	.3544	.3734	.362	.3506	.362
Avg	.4443	.4526	.4667	.4636	.4430	.4350	.4350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 203 / Ganesh Bakery

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1086	.0905	.112	.1086	.0876	.1109
2	.112	.1086	.0905	.112	.1086	.0886	.1109
3	.0934	.1086	.0895	.112	.1086	.0895	.1109
4	.0934	.1086	.0886	.112	.1086	.0895	.1109
5	.0747	.1267	.0886	.1307	.1086	.0895	.1294
6	.0747	.1267	.1052	.1494	.1448	.0895	.1478
7	.0924	.1629	.2286	.2427	.1991	.2054	.1867
8	.0732	.2353	.3239	.3361	.2353	.3048	.2427
9	.0934	.2667	.3326	.3361	.2858	.3429	.2353
10	.0934	.2858	.3174	.3361	.3048	.381	.3258
11	.0934	.3048	.3361	.2987	.3048		.3258
12	.0934	.2858	.3395	.3361	.2858		.2896
13	.0747	.2286	.3206	.2801	.2858	.2667	.2896
14	.0747	.2427	.3018	.2987	.3048	.2667	.2353
15	.0934	.2587	.3018	.3174	.3239	.2858	.2534
16	.0934	.2858	.2801	.2987	.3048	.2667	.2534
17	.0905	.2858	.2614	.2987	.3048	.2667	.2715
18	.0724	.2477	.2587	.2801	.2241	.2667	.2715
19	.0905	.2477	.2402		.1524	.2286	.2715
20	.0905	.2286	.2054		.1734	.1715	.1991
21	.0724	.2286	.1509	.1867	.1791	.1334	.1991
22	.0724	.1791	.132	.1307	.1463	.1143	.181
23	.0724	.1086	.132	.1307	.1075	.112	.181
24	.1307	.0905	.0895	.1132	.1307	.1052	.112
Max	.1307	.3048	.3395	.3361	.3239	.381	.3258
Min	.0724	.0905	.0886	.112	.1075	.0876	.1109
Avg	.0894	.2026	.2127	.2250	.2059	.1933	.2102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 204 / 11 KV Agar Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2172	.2172	.2241	.2172	.2454	
2	.1867	.2172	.2172	.1867	.2172	.2303	
3	.1867	.2172	.2149	.1867	.2172	.2328	
4	.2054	.2172	.2149	.2241	.2353	.2507	
5	.2241	.2172	.2303	.2427	.2534	.2507	
6	.2427	.2172	.2454	.2614	.2614	.2686	.2587
7	.2402	.2353	.2858	.2241	.2614	.2241	.2987
8	.2378	.2614	.2858	.2987	.2715	.2286	.2241
9	.2241	.2667	.2957	.2801	.2858	.2477	.2534
10	.2241	.2858	.3361	.3174	.2858	.381	.3077
11	.2614	.2858	.3547	.3361	.2667	.4191	.3258
12	.2801	.2858	.2772	.2801	.2667	.381	.2896
13	.2801	.2858	.3018	.2987	.2667	.381	.2534
14	.2801	.2427	.3018	.2801	.3048	.381	.2534
15	.2801	.2218	.3395	.2801	.3429	.381	.2715
16	.2801	.2667	.2987	.3174	.3048	.3048	.2715
17	.2715	.2667	.2801	.2987	.2667	.3429	.2715
18	.2715	.2858	.2587	.2801		.3429	.2896
19	.2896	.3048	.3511			.3429	.2715
20	.3077	.3048	.3174		.2774	.381	.3439
21	.3077	.2858	.3018	.3361	.3045	.362	.3077
22	.3258	.2534	.3018	.2987	.3109	.3429	.3077
23	.2896	.2534	.2641	.2427	.2507	.2987	
24	.2427	.2534	.2507	.2263	.2427	.2279	.2614
Max	.3258	.3048	.3547	.3361	.3429	.4191	.3439
Min	.1867	.2172	.2149	.1867	.2172	.2241	.2241
Avg	.2568	.2562	.2809	.2691	.2687	.3104	.2812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 201 / MINCHE AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6493	.5772	.5399	.6028	1.2347	.8551	.0328
2	.6195	.5681	.5274	.6074	1.1958	.961	.1425
3	.6123	.5665	.5293	.5967	1.1737	.9945	.1433
4	.6173	.5673	.5106	.5898	1.1669	.9804	.2042
5	.6066	.5643	.6142	.5906	1.215	1.0593	.2827
6	.6299	.578	.5826	.6379	.9577	1.2361	.2953
7	.6882	.6714	.5719	.6561	.7171	1.675	.4103
8	.3879	.6577	1.3885	.615	.3955	1.8419	.4831
9	2.1837	2.186	1.227	1.7387	.6107	.9358	.6451
10	2.5926	2.688	2.2877	2.0664	.3239	.7099	.6927
11	2.4866	2.4753	2.4028	1.8701	.2103	.5792	.5913
12	2.2245	2.1079	2.2619	1.7091	.3079	.534	.5677
13	1.9098	1.0128	1.8679	1.6525	.2583	.5252	.5715
14	1.778		1.6187	1.5336	.269	.4876	.5624
15	1.632		1.6948	1.5032	2.0683	.4738	.5448
16	1.7703	1.1046	1.9052	1.5638	2.1166	.5193	.573
17	1.0654	1.7307	1.2011	1.1619	.3551	.5543	.6172
18	.4939	1.5227	.6173	.5397	.3277	.349	.5815
19	.6478	.932	.6965	.6048		.3452	.6462
20	.7453	.6577	.6455	.6262	.1654	.1966	.7781
21	.7491	.668	.6866	.6521	.3963	.2385	.7568
22	.7339	.6584	.6821	1.1896	.4024	.2111	.7385
23	.675	.5807	.6393	1.2911	.4062	.1974	.6471
24	.6344	.5734	.5609	.9388	.6439	.1943	.3834
Max	2.5926	2.688	2.4028	2.0664	2.1166	1.8419	.7781
Min	.3879	.5643	.5106	.5397	.1654	.1943	.0328
Avg	1.1306	1.0749	1.0942	1.0641	.7356	.6939	.4955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 202 / NARANDE Ag FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.804	.0663	.6104	.0637	.0663	.0655
2	.6478	.804	.0655	.6104	.0637	.0655	.0655
3	.6478	.804	.6226	.6036	.0637	.0663	.0655
4	.6554	.804	.6226	.6104	.0643	.0648	.0648
5	.6722	.804	.9175	.6104	.0637	.0655	.0655
6	1.0364	1.0934	.0663	.7888	.0637	.0655	.0655
7	.9175	.9648	1.0242	.8817	.0637	.0648	.0648
8	.0671	.0637	.0655	.1052	.0637	.0655	.0648
9	.0655	.0637	.0648	.1052	.9648	.5243	.4359
10	.0648	.0637	.0701	.1052		.6363	.6251
11	.0655	.0701	.0701	.064		.7636	.57
12	.0655	.0701	.0693	.0637		.7008	.5144
13	.0655	.0701	.0701	.066		.6371	.407
14	.1147	.0701	.0701	.0643		.5734	.407
15	.0648	.0701	.0701	.0643	.9069	.5734	.4359
16	.0655	.0701	.0701	.0636	.9069	.3216	.4748
17	.0655	.0701	.0701	.0634	.0648	.0637	.064
18	.064	.0701	.0701	.0639			.064
19	.0643	.0972	.0701	.0965		.0648	.064
20	.0988	.0983	.1052	.0639	.0648	.0655	.064
21	.0956	.0983	.1052	.0951	.0648	.0655	
22	1.0194		.7712	.0637	.0648		.064
23	.9648		.78	.0637	.064	.0655	.064
24	.6554	.9005	.0663	.6104	.0657	.0655	.0655
Max	1.0364	1.0934	1.0242	.8817	.9648	.7636	.6251
Min	.064	.0637	.0648	.0634	.0637	.0637	.064
Avg	.3702	.3647	.2518	.2724	.2163	.2566	.2105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 203 / KHOCHI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8618	3.5963	.1113	2.6284	.066	.0655	.0655
2	3.3532	3.5544	.9549	2.6003	.066	.0655	.0655
3	3.341	3.5185	2.8867	2.5995	.0658	.0655	.0655
4	3.3479	3.5292	2.937	2.582	.0658	.0648	.0655
5	3.4454	3.671	2.9752	2.6182	.0661	.0655	.0648
6	3.5856	4.0292	.711	2.9424	.0657	.0648	.0648
7	1.4967	3.4736	3.0796	2.4958	.0661	.0648	.0648
8	.0648	.0661	.1463	.0678	.0894	1.6749	.0648
9	.0655	.0661	.0663	.0701	4.6958	4.6144	2.2016
10	.0648	.0658	.0701	.0701	5.5349	5.2077	2.2969
11	.064	.0701	.0701	.064	5.4721	5.352	2.3099
12	.0655	.0914	.0701	.0657	3.083	5.1566	2.2718
13	.0655	.0701	.0701	.066	5.1276	4.8273	2.2337
14	.0655	.0701	.0701	.0658	4.7867	4.7269	2.2093
15	.0655	.0701	.0724	.0657	2.5103	4.5376	2.1758
16	.0678	.0701	.0709	.0668	2.4912	4.3409	2.1323
17	.0724	.0709	.0701	.066	.4641	.3674	.2728
18	.1006	.0762	.0701	.0661		.0053	.0655
19	.1502	.0655	.0701	.0658		.0823	.0655
20	.1529	.0785	.0709	.0657		.0685	.0677
21	2.0291	2.037	1.4815	.0684		.0648	.0724
22	3.8781	2.1597	2.873	.0658		.0655	.0754
23	3.8825	2.1399	2.7945	.0658		.0656	.0701
24	3.5163	1.8511	1.4159	1.2548	.066	.0777	.0663
Max	3.8825	4.0292	3.0796	2.9424	5.5349	5.352	2.3099
Min	.064	.0655	.0663	.064	.0657	.0053	.0648
Avg	1.4501	1.4371	.9670	.8661	1.9324	1.7372	.7962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 204 / BENDA VADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0678		.0701	1.6804	1.4083	.5571
2	.0671	.0678		.0701	1.6804	1.4419	.5571
3	.0671	.0678	.0655	.0701	1.6804	1.4419	.5506
4	.0671	.0678	.0655	.0701	1.6804	1.4251	.5506
5	.0671	.0678	.0648	.0701	1.6842	1.4419	.5898
6	.0671	.0678	.0655	.0701	.0672	1.4419	.6478
7	.0671	.0678	.0655	.0701	.0672	1.4419	.6478
8	.0655	.0672	.0648	.0701	.0672	1.4746	.6478
9	2.5232	2.4198	1.9204	2.1795	.0672	.0655	.0701
10	2.4939	2.5542	2.5774	2.1795	.0648	.0675	.0724
11	2.4615	2.4756	2.4813	1.9433	.0655	.0675	.0701
12	2.4577	2.3739	2.4143	1.882	.0648	.0675	.0701
13	2.3967		2.3807	1.7476	.0648	.0675	.0724
14	2.2939		2.5503	1.882	.0648	.0675	.0701
15	2.2024		2.2786	1.9034		.0675	.0701
16	2.1052	2.1704	1.262	1.8863		.0675	.0701
17	.0655	2.1026	.0701	.7394		.0675	.0671
18	.0648	2.0348	.0701	.0672			.0671
19	.0672	.0655	.0701	.0672			.0671
20	.0672	.0655	.0701	.0672			.0655
21	.0672	.0655	.0693	.0672			
22	.0672		.0701	1.8863		.0655	.0655
23	.0672		.0701	1.7476		.0655	.0655
24	.0671	.0678		.0701	1.6804	.0655	.0655
Max	2.5232	2.5542	2.5774	2.1795	1.6842	1.4746	.6478
Min	.0648	.0655	.0648	.0672	.0648	.0655	.0655
Avg	.8335	.8914	.8927	.8699	.7120	.6160	.2512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 205 / BENDA VADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4031	.3799	.2412	.3086	.4399	.3117	.3578
2	.3856	.3704	.2248	.3041	.4349	.306	.3593
3	.389	.37	.4096	.3063	.4322	.3086	.3578
4	.3849	.3662	.405	.3037	.4301	.3041	.3578
5	.3711	.3658	.3864	.301	.3791	.3021	.3429
6	.3734	.3704	.397	.3521	.4301	.3467	.3517
7	.389	.3344	.4573	.3738	.4441	.3574	.4234
8	.3948	.3348	.4146	.3986	.4566	.3414	.4153
9	.4028	.3523	1.7876	.3803	.4084	.3266	.4215
10	.3502	.3081	.3753	.3696	.365	.378	.426
11	.3002	.3837	.4134	.3765	.3658	.4054	.3638
12	.2915	.3997	.4565	.3872	.3605	.2244	.3658
13	.3144	.4039	.4237	.4017	.3708	.3708	.3814
14	.3162	.4169	.426	.4494	.3749	.4595	.3902
15	.327	.4153	.3963	.4494	.3746	.4519	.4119
16	.325	.4104	.4523	.4119	.3776	.4546	.4191
17	.3334	.4588	.3365	.4185	.3673	.4325	.4363
18	.3509	.463	.3982	.4824	.2279	.2484	.4146
19	.4124	.4733	.4657	.5041	.2195	.1437	.4702
20	.462	.4706	.5266	.5085	.4405		.5819
21	.47	.5057	.5171	.5144	.4535	.037	.3151
22	.462	.2717	.4698	.5205	.4066	.2298	.554
23	.4192	.2644	.4111	.4819	.389	.2469	.4614
24	.402	.4299	.3654	.3879	.4048	.3464	.4096
Max	.47	.5057	1.7876	.5205	.4566	.4595	.5819
Min	.2915	.2644	.2248	.301	.2195	.037	.3151
Avg	.3763	.3883	.4649	.4039	.3897	.3189	.4079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 206 / Khochi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.7057	.7263	.5155	.5766	.5076	.5624
2	.679	.695	.7164	.5167	.5689	.5015	.522
3	.6721	.6928	.7118	.4832	.5642	.5045	.5167
4	.663	.6882	.7087	.4748	.5552	.4946	.5076
5	.7118	.6859	.7034	.4901	.5915	.5361	.5076
6	.727	.7483	.6371	.5144	.6022	.5605	.538
7	.5861	.6478	.6119	.4824	.5391	.5197	.5411
8	.5015	.5482	.4996	.4664	.2812	.4954	.4832
9	.4763	.4952	.458	.4485	.5276	.4634	.3559
10	.458	.5342	.4588	.4789	.5266	.2317	.3703
11	.4534	.5323	.5117	.4717	.6043	.4938	.4111
12	.4664	.5346	.533	.4799	.5982	.538	.3974
13	.4847	.5391	.5376	.511	.6035	.5136	.439
14	.4915	.5489	.583	.5339	.3079	.6172	.452
15	.5129	.5612	.559	.5385	.6051	.6279	.4824
16	.5137	.5407	.5689	.5553	.6073	.3231	.4938
17	.4794	.5391	.551	.5433	.5959	.4001	.5213
18	.5167	.4888	.5899	.66	.2873	.317	.5891
19	.6083	.647	.6702	.769	.2926	.5083	.663
20	.7278	.7156	.6908	.7576	.7095	.2534	.7583
21	.724	.7407	.7167	.7857	.7705	.6349	.4245
22	.7469	.3833	.6181	.7514	.679	.6047	.7446
23	.7911	.3551	.5761	.661	.628	.5944	.7027
24	.7431	.6851	.6508	.5967	.5888	.6166	.6333
Max	.7911	.7483	.7263	.7857	.7705	.6349	.7583
Min	.4534	.3551	.458	.4485	.2812	.2317	.3559
Avg	.6012	.5939	.6079	.5619	.5505	.4941	.5257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 207 / Narand Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2454	.2908	.2953	.2377	.3129	.266	.1139
2	.2504	.2901	.2922	.2434	.3017	.2648	.1547
3	.2503	.2935	.3041	.2514	.2937	.2606	.2031
4	.2462	.2905	.2968	.2431	.2865	.2595	.1981
5	.2797	.295	.3323	.2797	.2867	.2595	.1928
6	.3547	.3072	.3536	.2976	.2994	.2679	.2027
7	.2873	.3229	.4153	.3242	.3417	.3368	.2183
8	.2614	.2838	.3227	.2835	.336	.2877	.2229
9	.2793	.2806	.3006	.2561	.2928	.2683	.2069
10	.2717	.317	.3189	.2492	.2587	.3044	.2164
11	.2861	.33	.3052	.2412	.2945	.23	.2149
12	.2961	.3582	.3437	.3033	.2732	.2895	.2191
13	.3106	.426	.3818	.3057	.3094	.3101	.2728
14	.3125	.3593	.3238	.2791	.1799	.3075	.2659
15	.3018	.3049	.3238	.2892	.3029	.2521	.2412
16	.306	.3734	.3147	.2924	.306	.2862	.2846
17	.3201	.3967	.3082	.3083	.3208	.3219	.3201
18	.256	.41	.3688	.3505	.1627	.1684	.3315
19	.322	.41	.37	.3707		.2465	.3505
20	.4394	.4489	.3814	.3871	.003	.1448	.3894
21	.4069	.4447	.3787	.3863	.3304	.3124	.2164
22	.4058	.2153	.3288	.3799	.3204	.3082	.3559
23	.3454	.1939	.3059	.386	.2877	.2842	.3369
24	.2644	.3114	.2827	.3017	.2831	.2709	.1555
Max	.4394	.4489	.4153	.3871	.3417	.3368	.3894
Min	.2454	.1939	.2827	.2377	.003	.1448	.1139
Avg	.3041	.3314	.3312	.3020	.2776	.2712	.2452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 208 / Minche Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.3727	.3658	.3326	.3354	.2561	.2926
2	.362	.3711	.3658	.3326	.3354	.2534	.2926
3	.362	.3727	.3658	.3326	.3354	.2534	.2896
4	.3658	.3727	.3658	.3326	.3354	.2561	.2926
5	.362	.3354	.439	.3696	.3727	.2926	.3292
6	.3658	.3727	.439	.3696	.3704	.2926	.4344
7	.2865	.3354	.4344	.2957		.2926	.362
8	.2195	.2981	.3292	.3326	.1491	.2534	.2896
9	.2172	.2975	.2561	.2926	.1488	.2587	.2957
10	.2195	.2963	.2587	.2926		.2582	.2957
11	.2195	.2957	.2957	.2865	.3658	.2951	.2957
12	.2172	.2957	.3696	.2969	.439	.2951	.2957
13	.2149	.3292	.3326	.2969	.439	.3688	.2957
14	.2195	.3326	.2957	.2963	.439	.2951	.2926
15	.2195	.3326	.2957	.2969	.3658	.3688	.3292
16	.2195	.3696	.2957	.2981		.3688	.3658
17	.2926	.3696	.2957	.3354	.3658	.3688	.3734
18	.2896	.3696	.3326	.3727			.3734
19	.3719	.5121	.4066	.4472	.439	.439	.4805
20	.4099	.5121	.4435	.4845	.439	.439	.5228
21	.4463	.5068	.439	.4845	.3658	.4344	
22	.4463		.4024	.4472	.3292	.3658	.4481
23	.3711		.3772	.4124	.2896	.3292	.3734
24	.3658	.3704	.3696	.3326		.2926	.3292
Max	.4463	.5121	.4435	.4845	.439	.439	.5228
Min	.2149	.2957	.2561	.2865	.1488	.2534	.2896
Avg	.3093	.3646	.3571	.3488	.3505	.3186	.3456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 209 / 11KV Buwache Wathar AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4899	1.6278	.0655	.1402	.0672	.0655	.0655
2	1.5074	1.6278	.0655	.1402	.0658	.0663	.0663
3	1.5074	1.6278	1.4746	.1387	.0657	.0663	.0655
4	1.4899	1.6278	1.4746	.1402	.0684	.0655	.0655
5	1.5074	1.6278	1.4746	.1402	.068	.0663	.0655
6	1.5364	1.6617	.0655	.1734	.0658	.0663	.0648
7	1.5223	1.6278	1.2955	.208	.066	.0655	.0648
8	.0324	.0678	.0648	.0347	.066	.0655	.0648
9	.0328	.0678	.0655	.0351	1.7674	1.4251	
10	.0648	.0701	.0686	.0351	1.8679	1.8861	
11	.0655	.0701	.0686	.0328	1.7814	1.9247	.8383
12	.0648	.0701	.0686	.0334	1.7695	1.7872	.8916
13	.0655	.0701	.0686	.0329	1.6385	1.6804	.8817
14	.0655	.0701	.0686	.0336	1.6194	1.7147	.8916
15	.0648	.0701	.0701	.033		1.6804	.8817
16	.0655	.0701	.0701	.0319		1.406	.8573
17	.0655	.0701	.0701	.0319		.0686	.0351
18	.0648	.0701		.034			.0351
19	.0701	.0655	.0351	.034		.0655	.0351
20	.07	.0655	.0351	.0747		.0648	.0343
21	.0738	.0655	.0351	.071		.0655	
22	1.8229		.1715	.0748			.0747
23	1.7953		.1753	.0701		.0655	.0701
24	1.4899	1.6956	.0655	.1372	.0658	.0655	.0655
Max	1.8229	1.6956	1.4746	.208	1.8679	1.9247	.8916
Min	.0324	.0655	.0351	.0319	.0657	.0648	.0343
Avg	.6889	.6403	.3094	.0796	.7362	.6558	.2912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 210 / Khandoba AG (Bhendwade) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.033	.0332	.0351	.7008	.6882	.2949
2	.032	.033	.0328	.0351	.7008	.7122	.2949
3	.0328	.033	.0351	.0351	.7276	.6802	.2984
4	.032	.033	.0351	.0351	.7008	.6882	.2949
5	.0328	.033	.0351	.0351	.7938	.6802	.3277
6	.0328	.033	.0351	.0351	.0328	.8421	.421
7	.0324	.033	.0351	.0351	.0328	.8421	.421
8	.0324	.0319	.0351	.0351	.034	.852	.421
9	1.065	1.0584	1.1869	.0351	.033	.0332	.0351
10	1.1012	.9946	1.1736	1.0059	.0328	.0312	.0351
11	1.0486	.9945	1.073	.9282	.0324	.0312	.0362
12	1.0242	.9602	1.0631	.8868	.0328	.0312	.0351
13	.9831		.9496	.8599	.032	.0312	.0351
14	.9831		.9054	.7964	.0328	.0312	.0351
15	.9717		.9259	.8021	.0328	.0312	.0351
16	.9831	1.0174	.8573	.7645	.0328	.0316	.0351
17	.0328	1.0288	.0351	.0319	.0328	.0312	.0328
18	.0328	.9835	.0347	.0323	.0328		.0328
19	.0319	.0328	.0351	.0319	.0328	.0328	.0316
20	.0319	.0328	.0351	.034	.0328	.0328	.0319
21	.0319	.0339	.0351	.0318	.0324	.0328	
22	.0319		.0351	.7327	.0328	.0324	.032
23	.0319		.0351	.7025	.0332	.0324	.0328
24	.0328	.033	.0328	.0351	.7075	.6882	.0324
Max	1.1012	1.0584	1.1869	1.0059	.7938	.852	.421
Min	.0319	.0319	.0328	.0318	.032	.0312	.0316
Avg	.3616	.3912	.3621	.3330	.2051	.3096	.1427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 201 / 11KV Bhokari (Bhadole) AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.4403	.0305	1.2029		.0324	
2	1.2955	1.4083	.0305	1.2186		.0324	
3	1.278	1.3603	1.3441	1.2186		.0328	
4	1.2631	1.3603	1.3117	1.2186		.0324	
5	1.2955	1.3927	1.3108	1.2342		.0324	
6	1.2955	1.4091	.0457	1.2498		.0324	
7	1.2955	1.4419	1.2955	1.2498		.0324	
8	.0324	.0305	.0305			.0324	
9	.0324	.0305	.0305		1.5364	1.6518	
10	.0324	.0305			1.7284	1.7976	
11					1.8138	1.7532	
12					1.7328	1.7695	1.4737
13					1.7368	1.749	1.6057
14					1.8023	1.704	1.5546
15					1.749	1.6712	1.5238
16					1.7166	1.6032	1.4899
17					.0305	.0305	1.3603
18							1.0562
19	.0305	.0305			.0324		.0324
20	.0305	.0305			.0324		.0324
21	.0305	.0305			.0324		.0324
22	1.5384	1.4413	1.2811		.0324		.0324
23	1.5223	1.3765	1.2498		.0324		.0324
24	1.3279	1.4723	.0305	1.2186		.0324	
Max	1.5384	1.4723	1.3441	1.2498	1.8138	1.7976	1.6057
Min	.0305	.0305	.0305	1.2029	.0305	.0305	.0324
Avg	.8497	.8929	.6659	1.2264	1.0006	.779	.8522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 202 / 11KV Latwade AG Fdr

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.061	.061		1.6385	.6316	.6554
2	.0486	.061	.061		1.6057	.664	.7209
3	.0486	.061	.061		1.7737	.6802	.3605
4	.0648	.061	.061		1.8099	.7125	.3277
5	.0648	.061	.061		1.704	.7287	.3277
6	.0486	.061	.0457			.7611	.3441
7	.0486	.061	.061			.8421	
8	.0648	.061	.061			.8421	.7045
9	2.3266	2.1538	2.3102	1.8679		.0486	
10	2.2611	2.2996	2.3594	1.9006		.0488	
11	2.2775	2.2119	2.1628	1.8187	.061	.061	.061
12	2.2119	2.1628	2.1136	1.7695	.061	.061	.061
13	2.2447		2.0809	1.7532	.061	.061	.061
14	2.1956		2.0809	1.7695	.061	.061	.061
15	2.2447		2.0809	1.8023	.061	.061	.061
16	2.2447	1.6385	1.8679	1.8023	.061	.061	.061
17		1.6244			.061	.061	.061
18		1.5729					.061
19	.061	.061			.0648		.0648
20	.061	.061			.0486		.0648
21	.061	.061			.0648		.0648
22	.061	.061		1.7368			.0324
23	.061	.061		1.6876			.0648
24	.0655	.061	.061		1.6549	.0486	
Max	2.3266	2.2996	2.3594	1.9006	1.8099	.8421	.7209
Min	.0486	.061	.0457	1.6876	.0486	.0486	.0324
Avg	.8560	.6913	1.0347	1.7908	.6745	.3575	.2110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 203 / 11KV Latwade Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4382	.4382	.4024	.5068	.4706	.4572
2	.3982	.4207	.4161	.3841	.4706	.4525	.439
3	.3982	.4075	.4031	.4024	.5068	.4525	.4572
4	.4525	.4031	.4031	.4572	.543	.5068	.4755
5	.5249	.4733	.5493	.4572	.6154	.5611	.5121
6	.5853	.6201	.6135	.5487	.6516	.6697	.6219
7	.5121	.5552	.5493	.5487	.5973	.5792	.5853
8	.4706	.4835	.4961	.5304	.5249	.3963	.5487
9	.4525	.5121	.567	.5304	.543	.5611	.5304
10	.4706	.4733	.567	.5487	.6154	.543	.5304
11	.4755	.543	.6584	.5552	.6135	.5847	.4961
12	.128	.5552	.5853	.5552	.6024		.4961
13	.128	.5373	.4938	.5194	.6089	.5552	.4835
14	.1463	.5552	.5121	.5373	.5731	.5493	.5316
15	.4572	.5373	.5304	.5552	.5784	.5493	.5847
16	.4938	.5552	.5853	.5552	.5847	.567	.6089
17	.4938	.4656	.5487	.5552	.567	.5731	.6024
18	.5121	.5373	.3841	.591			.5083
19	.5847	.6697	.5853	.6878	.6335		.6878
20	.6268	.7701	.6401	.6984	.6878	.2012	.7783
21	.6268	.7522	.6036	.6626	.0297	.6219	.7421
22	.6268	.6201	.6036	.7059	.6154	.6584	.6584
23	.5258	.5258	.4572	.5792	.5068	.5304	.543
24	.4706	.4733	.4382		.5249	.4706	.4755
Max	.6268	.7701	.6584	.7059	.6878	.6697	.7783
Min	.128	.4031	.3841	.3841	.0297	.2012	.439
Avg	.4581	.5368	.5262	.5464	.5522	.5264	.5564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 201 / SUT GIRNI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17
HR	Load (MW)
14	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 202 / GHUNKI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 203 / BHADOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 204 / VADGAON Vg FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 206 / Top Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 207 / 11KV AMBAP AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9473	1.1264	.2271	.9846	.2309	.2103	.2103
2	.8886	1.0006	.2195	.9168	.2286	.2058	.205
3	.881	.9275	.5769	.8284	.2157	.1997	.2149
4	.8711	.9595	.7072	.8109	.2134	.2004	.218
5	1.0219	1.0479	.98	.8436	.2073	.1997	.2218
6	1.5455	1.5066	1.0692	.9419	.2408	.2202	.2599
7	1.8877	2.0248	.6295	1.7063	.2721	.2713	.2797
8	.3201	.3368	.4031	.3871	.2644	.2477	.2652
9	.1966	.2347	.2241	.2042	2.3403	.8901	.7933
10	.1699	.2164	.1905	.205	2.4981	2.0782	1.9182
11	.1486	.2157		.192	2.3274	2.0416	1.9578
12	.1265	.2157		.2012	2.1651	1.7284	1.454
13	.1585	.2233	.2484	.1875	1.8191	1.358	1.2986
14	.1517	.2271	.2454	.1631	1.5394	1.3725	1.2224
15	.1494	.2088	.2355	.0975	1.419	1.3611	1.275
16	.1623	.2187	.2568	.1997	1.499	1.5165	1.2369
17	.2073	.2119	.269	.2126	.2484	1.2132	1.1286
18	.2172	.2439	.1296	.234	.1867	.2225	.2149
19	.3064	.2515		.2683	.1898		.2454
20	.3406	.3361	.2408	.2652	.2492		.3117
21	.3033	.333	.2446	.2804	.2561	.2469	.2995
22	1.5646	1.7086	1.4327	.2743	.2683	.2865	.314
23	1.5859	1.7147	1.3817	.2492	.2393	.2515	.3163
24	2.0935	1.5333	1.1728	.2256	.2126	.2241	.2675
Max	2.0935	2.0248	1.4327	1.7063	2.4981	2.0782	1.9578
Min	.1265	.2088	.1296	.0975	.1867	.1997	.205
Avg	.6769	.7093	.5278	.4533	.8055	.7521	.6720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 208 / BHADOLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 209 / GHUNKI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 210 / VADGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1859	.2157		.237			
2	.16	.1875		.2149			
3	.1524	.176	.0267	.2058			
4	.1494	.1768	.0602	.1936			
5	.1539	.1753	.1738	.1585			
6	.1768	.205	.1875	.1738			
7	.2736	.3003		.2629			
8	.2599	.2995	.0633	.2728			.0008
9					.2401		
10			.0206		.3658		.2644
11			.0419		.381		.2782
12				.0046	.3765	.0777	.2629
13					.3399	.282	.2713
14					.2599	.3437	.2759
15					.285	.3338	.2698
16					.2926	.2964	.2934
17					.2759	.2858	.2439
18						.1364	.0793
20						.0876	
22	.144	.173	.1905				
23	.2439	.2385	.2652				
24	.3902	.2401	.2561				.0038
Max	.3902	.3003	.2652	.2728	.381	.3437	.2934
Min	.144	.173	.0206	.0046	.2401	.0777	.0008
Avg	.2082	.2171	.1286	.1915	.3130	.2304	.2040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 211 / Ambap Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 402 / 33 kv Warana LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 405 / 33 KV R.M Mohite NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	3.0864
Max	3.0864
Min	3.0864
Avg	3.0864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 406 / 33 KV Sawarde

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	7.7161
Max	7.7161
Min	7.7161
Avg	7.7161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 604 / 110 kV Warana Co-Gen NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 100 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-MAY-17
HR	Load (MW)
24	1.5588
Max	1.5588
Min	1.5588
Avg	1.5588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 201 / 11 KV Katali

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.3326
Max	.3326
Min	.3326
Avg	.3326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 202 / 11 KV Gagan Bawada

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.037
Max	.037
Min	.037
Avg	.037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 203 / 11 KV Andur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.0366
Max	.0366
Min	.0366
Avg	.0366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 204 / 11 KV KATALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.0181
Max	.0181
Min	.0181
Avg	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 205 / 11 KV ANDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.0181
Max	.0181
Min	.0181
Avg	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 201 / 11 KV Shiye Ag Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9843	2.8178		1.4746	.0497	.0819	.0819
2	3.0178	2.7349		.0819	.0497	.0819	.0819
3	3.0178	2.652	2.6216	.0819	.0497	.0819	.0819
4	3.0514	2.652	2.7854	.0819	.0497	.0819	.0819
5	3.0849	3.0664	2.7854	.0819	.0497	.0819	.0819
6	3.152	3.315		.0819	.0497	.0819	.0819
7	3.0803	2.9835	2.8673	.0819	.0497	.0819	.0819
8	.0848	.0829	.0819	.0819	.0829	.0819	.0819
9	.0819	.0829	.0829	1.7436	1.5746	2.0481	
10	.0819	.0838	.0829	1.704	1.9662	2.6155	.4973
11	.0819	.0838	.0166	1.9662	2.13	2.6216	2.5692
12			.0166	1.9662	2.0481	2.4577	2.5692
13			.0164	1.8023	2.0481	2.3266	2.3434
14			.0166	1.8023	2.0481	2.3594	
15			.0829	2.13	1.9662	2.3594	2.3205
16			.0829	1.9662	2.0481	2.556	2.652
17		.0838		.0819	.0819	.0838	2.4863
18	.0829	.0819		.0829	.0819	.0819	.0838
19	.0829	.0819	.0671	.0829	.0819		.0838
20	.0829	.0819	.0838		.0819	.0819	.0838
21	.0829	.0819	.0838	.0497	.0819	.0819	
22	3.1493	2.9492	.0838	.0497	.0819	.0819	.0838
23	3.315	2.9492	1.4754	.0497	.0819	.0819	.0838
24	2.4371	2.9007		1.4746	.0497	.0819	.0819
Max	3.315	3.315	2.8673	2.13	2.13	2.6216	2.652
Min	.0819	.0819	.0164	.0497	.0497	.0819	.0819
Avg	1.7196	1.5666	.7407	.8261	.7035	.8946	.7902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 202 / 11KV Water Supply -Shiye

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7167	.5535	.6335	.7468	.6325	.5937
2	.6379	.7167	.5535	.6335	.7468	.6325	.5937
3	.6516	.7167	.5535	.6154	.7468	.6325	.5937
4	1.4529	.7167	.2372		.7468	.6325	.5937
5	.6516	.7545	.5535		.7468	.6325	.6249
6	.578	.7545	.6325		.7468	.6325	.6249
7	.5937	.724	.6325		.7468	.7116	.6718
8	.5312	.8907	.9374	.8145	.9374		.7811
9	.5155	1.0155	1.2498	1.1393	1.1717	1.2651	1.3592
10	.5468	1.1393	1.2498	1.2651	1.2498	1.4899	1.5623
11	.5468		1.2936	.6325	1.3279	1.5415	1.4842
12	.5468	1.3496	1.0155	.6325	1.2029	1.1568	1.4842
13	.5468	.8939	.8478	1.2651	.4218	1.1871	1.0155
14	.5937	1.0517	.8592	1.0279	.4687	1.4022	.9374
15	.578	1.1568	1.0936		1.2967	1.5775	1.4842
16	.578	1.0437	1.1717	.9488	1.1405	1.5769	1.2498
17	.578	1.012		1.0279	.9686	1.5947	1.2498
18	.6535	1.0279		.8802	.7907	.8749	1.2226
19	.6535	.7907	.6767	.7811	.5535		.8859
20	.7545	.6325	.6556	.7468	.6325	.6562	.7442
21	.7545	.6325	.6626	.7468	.6325	.6718	
22	.7468	.6325	.6697	.7468	.6325	.6718	.7087
23	.7468	.5535	.6516	.7468	.6325	.6562	.7059
24	.6379	.7167	.5535	.6379	.7468	.6325	.6249
Max	1.4529	1.3496	1.2936	1.2651	1.3279	1.5947	1.5623
Min	.5155	.5535	.2372	.6154	.4218	.6325	.5937
Avg	.6553	.8539	.7866	.8380	.8348	.9755	.9477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 204 / HANUMAN GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2241	.2427	.2195	.2241	.2427	.2427
2	.2587	.2241	.2241	.2195	.2241	.2241	.2427
3	.2195	.2241	.2241	.2195	.2241	.2241	.2241
4	.2218	.2241	.2241	.2195	.2241	.2241	.2241
5	.2172	.2241	.2427	.2172	.2241	.2427	.2427
6	.2561	.2801	.2801	.2012	.2801	.2801	.2427
7	.2614	.2801	.2614	.2012	.2801	.2614	.2614
8	.2241	.2241	.2427	.2012	.2801	.2427	.2614
9	.2241	.2801	.2241	.2241	.2801	.2427	.2614
10	.1867	.2534	.2241	.2241	.2801	.1991	.2241
11	.1867	.2172	.2241	.2241	.2801	.2218	.2801
12		.2715	.1867	.2801	.2801	.2172	.2801
13			.1867	.2241	.2241	.2195	.2241
14		.2534	.2241	.2241	.2801	.2507	.2241
15		.2172	.2241	.2241	.2801		.2801
16	.2241	.2241	.2241	.2614	.2427		.2801
17	.2614	.2241		.2614	.2801	.2172	.2801
18	.2241	.2427		.2801		.2987	.2772
19	.2801	.2987		.3174	.3174		.3258
20	.3734	.3734	.0924	.3734	.3734		.3658
21	.3734	.3361	.2772	.3734	.3174	.3361	
22	.3734	.3361	.2775	.3361	.3361	.3174	.3511
23	.3174		.2218	.2801	.2987	.2801	.3142
24	.2829	.2801	.2614	.2195	.2801	.2427	.2614
Max	.3734	.3734	.2801	.3734	.3734	.3361	.3658
Min	.1867	.2172	.0924	.2012	.2241	.1991	.2241
Avg	.2611	.2597	.2281	.2511	.2744	.2493	.2683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 202 / 11 KV NIGAWA GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905		.1715	.1905	.1715	.1646
2	.1905	.1905	.1905	.1715	.1886	.1715	.1715
3	.1905	.1905	.1905	.1715	.1905	.1509	.1715
4	.1905	.1905	.1715	.1715		.1715	.1886
5	.1905	.1905	.1715	.1715	.1646	.1886	.1886
6	.2075	.2075	.2263	.2263	.2075	.1905	.2241
7	.1867	.2054		.2452	.1886	.2378	.1867
8	.168	.2427	.2263	.2241	.2263	.2241	.1886
9	.197	.2353	.3086	.2957	.2614	.3155	.168
10	.181	.2507		.2835	.2641	.168	.1494
11	.1829	.2896		.2835	.1886	.2054	.2241
12	.1791	.2149		.0191	.2033	.2054	.3012
13	.2012	.2378		.2658	.2241	.1848	.2172
14	.2195	.2454	.2658	.2561	.2263	.168	.2012
15	.2054	.2534	.3326	.2218	.2195	.2614	.2218
16	.2218	.2195	.2715	.2427	.2241	.168	.2614
17	.1448	.2926			.1905	.197	.2987
18	.2012	.2614	.2402	.2686	.2218	.2172	.2987
19	.2587	.0377	.2987	.2957	.3361		.2587
20	.2987	.3326	.2926		.3361	.3696	
21	.2614	.2896	.2614	.2987	.3206	.3734	
22	.2378	.2561	.2263	.2641	.2858	.2667	.2614
23	.2195	.2218	.2012	.2286	.2286	.2286	.1867
24	.2286	.1867	.1867	.1715	.1905	.1646	.1715
Max	.2987	.3326	.3326	.2987	.3361	.3734	.3012
Min	.1448	.0377	.1715	.0191	.1646	.1509	.1494
Avg	.2064	.2264	.2390	.2249	.2295	.2174	.2138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 204 / 11KV AMBEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3279	.0572		.0366	.0476	.6009	.3932
2	1.2803	.0457	.0457	.0358	.0457	.6722	.3887
3	1.2163	.0457	.0526	.0358	.0476	.7209	.3479
4	1.2163	.0467	.0526	.0351	.0495	.7209	.3563
5	1.2483	.0549	.0549	.0351	.0514	.759	.3795
6	1.3123	.0572	.0549	.0366	.0476	.9831	.4534
7	1.3279	.0572		.0457	.0514	1.1469	.5571
8	.0581	.0549	.0549	.0457		1.0688	.5121
9	2.0885	2.2211	2.3594	.9804	.0314	.0263	.0404
10	2.1879	2.1548		1.1069		.0257	.0404
11	2.1445	2.2211		1.1385	.0396	.0263	.0514
12	2.1956	2.2211		1.1069	.0314	.0263	
13	2.0081			1.6712	.0309	.028	.0457
14	2.0553		2.3922	1.5912	.0297	.0438	.0469
15	1.9989		2.4291	1.6575	.0286	.0457	.0469
16	1.8351	2.1879	1.8461	1.5912	.0343	.0274	.0469
17	.081	1.989		1.5074	.0572	.0572	.0503
18	.0819	1.8351		.0953	.0762	.0572	.0514
19	.1006	.0486		.0953			.0686
20	.0983	.064			.0762	.0762	
21	.1006	.0594	.1097	.0953	.0762	.0762	
22	.0972	.0572	.1307	.1143	.0762	.0762	.0514
23	.0995	.0572	.1075	.0953	.0762	.0762	.0514
24	1.4251	.0686	.0467	.0366	.0486	.0579	.0394
Max	2.1956	2.2211	2.4291	1.6712	.0762	1.1469	.5571
Min	.0581	.0457	.0457	.0351	.0286	.0257	.0394
Avg	1.1494	.7431	.6955	.5735	.0502	.3217	.1914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 205 / 11 KV Kerli Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1238	3.2602		.9389	.9012		.1052
2	.1219	2.9843		.9389	.8802		.1036
3	.1219	2.7206	1.3916	.9282	.8642		.1036
4	.1219	2.7206		.9282	.8745		.0991
5	.1219	2.7206	.4481	.9282	.9175		.1021
6	.1219	3.0849		1.2071	.1113	.1311	.1115
7	.144	2.8166		1.166	.1219	.128	.1021
8	.1524	.1115	.9709	.1829	.1174	.144	.1149
9	.1905	.1524		.1524	.426	1.9433	2.4691
10	.1905	.1524		.1524		2.6216	2.1704
11	.1905	.1524		.1524	.5243	2.6886	2.7831
12	.1715	.1524		.1524	1.5729	2.5606	2.7199
13	.1715	.1524	.1524	.1524	2.9835	2.4996	2.5911
14	.1524	.1524	.1524	.1524	3.0148	2.5301	2.4326
15	.1905	.1524	.1524	.1524	3.408	2.5911	2.4326
16	.1905	.1006	.1905	.1524	3.315	2.3594	2.3045
17	.1326	.1448		.1524		.1524	
18	.1509	.1848		.1524	.9175	.1524	
19	.1311	.16					.1372
20	.1638	.1677			.1524	.1524	
21	.1581	.1638		.1524	.1524	.1524	
22	3.4476	3.3589	1.0486	.8749	.1524	.1524	.1372
23	3.4294		1.065	.8855	.1524	.1524	.1372
24	.1238	3.2769		.9389	.9012		.1067
Max	3.4476	3.3589	1.3916	1.2071	3.408	2.6886	2.7831
Min	.1219	.1006	.1524	.1524	.1113	.128	.0991
Avg	.4256	1.2628	.6191	.5270	1.0696	1.2419	1.0632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 206 / 11 KV VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6722		.679	.6413	.6413	.6036
2	.5716	.6722	.6478	.679	.6036	.6097	.6036
3	.6036	.6348	.6097	.679	.5601	.5716	.5716
4	.6097	.679	.6097	.679	.5544	.6097	.5716
5	.6478	.679	.679	.7167	.6036	.679	.6413
6	.7545	.9054	.8215	.8299	.7842	.8299	.8488
7	.724	.8048		.8048	.8316	.8501	.924
8	.7316	.8048	.8215	.8779	.8326	.8871	.924
9	.724	.8688	.7964	.8596	.8871	.8326	.9412
10	.724	.8688		.8505	.8871		.9412
11	.7964	.8596		.8596	.5975	.8048	.9412
12	.7316	.8505		.7964	.8131		.8596
13	.7316	.7964		.8048	.8779	.788	.8413
14	.7164	.8048	1.0029	.8131	.8871	.8688	.8131
15	.7392	.8048	1.0136	.8131	.8871	.8688	.8779
16	.7087	.7964		.8048	.8688		.8048
17	.7023	.8676		.788	.7087	1.0242	.9709
18	.6805	.7392		.9313	.7164	.9511	.8215
19	.8131	.7392		1.0349	.8871		.8962
20	.8413	.8589			1.0456		
21	.8501	.8589	1.0349	.9054	.8962	.9709	
22	.7545	.7922	.9709	.9054	.8299	.8299	.8215
23	.7545	.7922	.7922	.7545	.7621	.6859	.8215
24	.7621	.6653	.679	.679	.7167	.6722	.679
Max	.8501	.9054	1.0349	1.0349	1.0456	1.0242	.9709
Min	.5716	.6348	.6097	.679	.5544	.5716	.5716
Avg	.7201	.7840	.8061	.8063	.7783	.7882	.8054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 207 / 11 KV Nigave Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5364	.1307		.112	.1753	1.012	.8145
2	1.5364	.1307	.1307	.112	.1753	1.0242	1.0364
3	1.5546	.1307	.112	.112	.1433	1.0814	1.0364
4	1.6194	.1307	.1494	.112	.1433	1.0814	1.0562
5	1.704	.1307	.1494	.1294	.1267	1.166	1.0562
6	1.8138	.1663	.168	.1494	.1646	1.6324	1.5074
7	1.8138	.1463		.1307	.1494	1.7901	1.6964
8	.128	.1829	.1867	.112	.1086	1.6766	1.6518
9	1.8564	2.5194	2.4143	1.7711	.1109	.0943	.1109
10	2.0119	2.6825		1.8343	.1097	.1109	.112
11	1.9433	2.5873		1.7078	.0181	.1109	.112
12	1.9662	2.0119			.0732	.1109	.1097
13	1.8351			1.5912	.0934	.112	.1109
14	1.7901		2.3868	1.6575	.1086	.1132	.1109
15	1.9227		2.3472	1.8778	.1063	.112	.1478
16	1.6842	2.3472	2.1376	1.8778	.0905	.1109	.1478
17	.1543			1.1385	.1905	.1143	.1478
18	.1886	1.6385	.9175	.1905	.1334	.1334	.1372
19	.1372		.1109	.1905	.1334		.1372
20	.1448	.1886	.1097		.3429	.1524	
21	.1848	.181	.1267		.1524	.1524	
22	.1478	.1478	.1463	.1905	.1524	.1524	.1372
23	.1448	.1478	.112	.1524	.1334	.1334	.1372
24	1.7284	.1307	.1478	.112	.1753	.1109	.1109
Max	2.0119	2.6825	2.4143	1.8778	.3429	1.7901	1.6964
Min	.128	.1307	.1097	.112	.0181	.0943	.1097
Avg	1.2311	.8280	.6972	.7267	.1380	.5343	.5284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 208 / 11 KV Panhala Feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5281		.4572	.4954	.4715	.415
2		.4904	.4904	.4572	.4572	.4572	.415
3		.4904	.4527	.4572	.4527	.4572	.4572
4		.5281	.4954	.4572	.4904	.415	.4572
5		.5281	.4904	.4954	.4904	.4763	.4904
6		.5658	.5658	.6036	.6036	.5658	.5914
7		.5658		.5601	.5975	.6036	.5544
8		.5601	.5601	.5601	.5914	.5525	.5975
9		.5914	.6089	.5731	.6024	.5175	.5853
10		.5914		.543	.6722	.5792	.5487
11		.6516		.5068	.6878	.5544	.5487
12		.5487		.543	.724	.7164	
13		.5544		.5973	.6283	.5853	.5914
14		.6219	.695	.5228	.6161	.5914	.5544
15		.4481	.8048	.5914	.5093		.5175
16		.6584	.7316	.6154	.6154		.5853
17		.6036		.6089		.7164	.5487
18		.5228		.6653		.724	.4755
19		.6283	.6036	.6722	.2587		.6859
20		.7545	.7545		.415	.679	
21		.7922	.6722	.7545	.7842	.679	
22		.6535	.6584	.7167	.6413	.6036	.6722
23		.5658	.5601	.5716	.5716	.381	.5975
24	.5658	.5228		.4572	.4954	.4961	.4191
Max	.5658	.7922	.8048	.7545	.7842	.724	.6859
Min	.5658	.4481	.4527	.4572	.2587	.381	.415
Avg	.5658	.5819	.6096	.5647	.5637	.5630	.5385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 201 / 11 kv Yavaluj Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0175	.0189			.3086	.6878	.2172
2	.0175	.0189			.3429	.695	.2218
3	.0175	.0189			.3772	.7207	.2402
4	.0175	.0189			.4801	.7468	.2402
5	.0175	.0189			.6687	.7468	.2427
6	.0173	.0189			.6687	.8029	.2772
7	.0175	.0189			.6687	.8775	.3881
8	.0175	.0189	.0185		.0189	.9335	.4572
9	2.3655	2.0317	2.1548		.0171	.0175	.0189
10	2.079	2.0399		.9326	.0175	.0175	.0189
11	1.8778	1.8385	1.8099	.9835	.0175	.0175	
12	1.643		1.8214	1.1736	.0175	.0175	.0189
13	1.291	1.7485	1.8616	1.1736	.0175	.0175	.0189
14	1.5089		1.6718	1.1904	.0175	.0175	.0189
15	1.6095			1.4586	.0175	.0175	.0189
16	1.5927	1.9044	1.587	1.4922	.0171	.0175	.0189
17	.0189	1.7177		1.1869		.0175	.0189
18	.0189	1.6461				.0175	.0189
19	.0189	.0183		.0189	.0175	.0175	.0189
20	.0189			.0189	.0175		.0189
21	.0189	.018		.0189	.0175	.0175	.0189
22	.0189	.0182		.5144	.0175	.0175	.0189
23	.0189				.0175	.0175	.0189
24	.0171	.0189	.0182		.2743	.0173	.0175
Max	2.3655	2.0399	2.1548	1.4922	.6687	.9335	.4572
Min	.0171	.018	.0182	.0189	.0171	.0173	.0175
Avg	.5940	.6922	1.3679	.8469	.1834	.2814	.1116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 202 / 11 KV YEVALUJ VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.132			.1132	.1109	.0739
2	.1307	.1132			.1132	.0924	.0747
3	.1307	.1132			.1132	.0934	.0747
4	.1307	.132			.132	.0934	.0747
5	.1494	.1509			.132	.112	.0934
6	.168	.1698			.132	.1307	.1307
7	.168	.1698			.1132	.1494	.1307
8	.1867	.1886	.2075	.2263	.1509	.168	.1307
9	.168	.1698	.2075	.1132	.1307	.168	.1509
10	.168	.1509		.1509	.1307	.1867	.132
11	.168	.1886	.132	.1307	.1307	.1867	
12	.168	.1886	.1509	.1509	.1294	.2241	.168
13	.168	.1886	.1886	.1509	.1294	.2241	.1698
14	.168	.2075	.2263	.132	.1494	.2054	.1698
15	.168	.2075	.2452	.132	.1867	.1867	.168
16	.1867	.2075	.2641	.1698	.2241	.1867	.168
17	.168	.1886		.1698		.1867	.1698
18	.1867	.2075				.1867	.1886
19	.1867	.2263	.1698		.1867	.1867	.2263
20	.2241		.1886	.1886	.2427		.2452
21	.2263	.2263	.2075	.1886	.2614	.1867	.2452
22	.1886	.2075	.2075	.1698	.1867	.1494	.0189
23	.1698		.1713	.132	.168	.112	.1886
24	.1307	.1509	.1886	.1132	.132	.1494	.0934
Max	.2263	.2263	.2641	.2263	.2614	.2241	.2452
Min	.1294	.1132	.132	.1132	.1132	.0924	.0189
Avg	.1682	.1766	.1968	.1546	.1540	.1598	.1429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 203 / 11Kv Satarde sheti
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	2.0576			.0189	.0175	.0175
2	2.2218	2.0233			.0189	.0175	.0175
3	2.2032	1.989			.0189	.0175	.0175
4	2.2032	1.989	1.9856		.0189	.0175	.0175
5	2.2032	2.0233	1.9978		.0189	.0173	.0173
6	2.2257	1.9784			.0189	.0175	.0175
7	2.0165	1.7939	2.2588		.0189	.0175	.0181
8	.0175	.0189			.0189	.0175	.0177
9	.0175	.0189	.0188		2.0538	2.4025	1.406
10	.0189	.0189			2.0911	2.5766	1.6289
11	.0189	.0189	.0185		2.0538	2.6886	1.5089
12	.0189	.0189			2.2965	2.7633	1.2742
13	.0189	.0184			2.1658	2.6886	1.3916
14	.0189	.0186	.0185		2.0538		1.358
15		.0181			2.0165	2.5766	1.3077
16		.0181	.0183		1.9605	2.4764	1.2574
17	.0189	.0183		1.5257	.0175	.0175	.0189
18	.0189	.0184			.0175	.0173	.0189
19	.0189	.0187		.0189	.0175	.0175	.0189
20	.0189			.0189	.0175		.0189
21	.0189	.0185		.0189	.0175	.0175	.0189
22	2.3472	2.4406		.0189	.0175	.0175	.0189
23	2.2131			.0189	.0175	.0175	.0189
24	2.2177	2.146			.0189	.0175	.0175
Max	2.3472	2.4406	2.2588	1.5257	2.2965	2.7633	1.6289
Min	.0175	.0181	.0183	.0189	.0175	.0173	.0173
Avg	1.0144	.8492	.9023	.2700	.7077	.8379	.4760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 204 / Majgaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2916	2.2043			.0189	.0175	.0175
2	2.2177	2.1534			.0189	.0175	.0175
3	2.2177	2.1026			.0189	.0181	.0181
4	2.1807	2.0348	2.4406		.0189	.0175	.0175
5	2.1285	2.1262	2.4771		.0189	.0175	.0175
6	2.0911	2.0748			.0189	.0175	.0175
7	1.9231	1.9719	2.5082		.0189	.0175	.0175
8	1.9231	.0189			.0189	.0175	.0175
9	.0175		.0184		2.4272	1.8099	
10	.0189	.0183	.0186		2.6513	1.7924	1.2346
11		.0184	.0181		2.8753	1.8111	1.2003
12					2.8567	1.8111	1.0562
13					2.726	1.8111	1.0395
14			.0185	.9221	2.6139	1.7924	.9602
15	.0189			1.4419	2.4646	1.531	1.0288
16	.0189		.0189	1.6766	2.4272	1.307	1.1317
17	.0189			1.7772		.0175	.0189
18	.0189	.0184				.0175	.0189
19	.0189	.0184		.0189	.0175	.0175	.0189
20	.0189			.0189	.0175		.0189
21	.0189	.0181		.0189	.0173	.0175	.0189
22	2.4478	3.1255		.0189	.0175	.0175	.0189
23	2.364			.0189	.0175	.0175	
24	2.3152	2.1795			.0189	.0175	.0175
Max	2.4478	3.1255	2.5082	1.7772	2.8753	1.8111	1.2346
Min	.0175	.0181	.0181	.0189	.0173	.0175	.0175
Avg	1.2135	1.3389	.9398	.6569	.9682	.6056	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 205 / Majgaon Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
1	.1867
2	.1867
3	.1494
4	.1494
5	.1886
6	.2263
7	.2054
8	.2241
9	.2241
10	.2286
14	.2286
15	.2286
16	.2858
17	.2667
18	.2667
24	.1867
Max	.2858
Min	.1494
Avg	.2145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 206 / 11 KV Satarde Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2263			.1886	.1867	.1478
2	.1867	.1886			.1509	.1494	.1494
3	.1867	.1886	.2452		.1509	.1494	.1494
4	.1867	.1886			.1886	.1478	.1494
5	.2241	.2641	.2641		.2641	.2241	.1867
6	.2987	.3584			.3584	.2987	.208
7	.2987	.3772	.3395		.3395	.3361	.2801
8	.3174	.3395	.3584	.3045	.3395	.3547	.3361
9	.3547	.3961	.415	.3206	.3361	.3361	.3584
10	.2987	.3772		.3361	.3361	.3361	.3361
11	.2801	.3772	.3584	.3361	.3174	.3361	.3361
12	.2801	.2829	.3584	.3734	.3174	.3174	.3361
13	.2801	.3206	.3584	.3584	.3174	.3174	.3361
14		.3961	.3206	.3395	.3361	.3361	.3174
15	.2801	.3772		.2987	.3361	.3361	.3361
16		.3772	.3772	.2987	.3734		.3547
17	.2801	.3395		.3395	.3547	.3881	.3584
18	.2829	.3584			.3734	.3547	.3734
19	.3772	.3772	.3772	.3772	.4108	.4108	.415
20	.4338		.3584	.415	.4108		.4527
21	.4338	.3961	.415	.3772	.3361	.3921	.4527
22	.3772	.3772	.3018	.3206	.2987	.3547	.3772
23	.2829		.2263	.2641	.2614	.2241	.3395
24	.2241	.2263	.2855	.2263	.2263	.2218	.2241
Max	.4338	.3961	.415	.415	.4108	.4108	.4527
Min	.1867	.1886	.2263	.2263	.1509	.1478	.1478
Avg	.2904	.3232	.3350	.3304	.3051	.2958	.3046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 201 / 11KV BORGOAN VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0354	.0175		.0177	.0305	.0351
2	.0305	.0354	.0168	.0354	.017	.0305	.0351
3	.0305	.0354	.0171	.0354	.017	.0305	.0351
4	.0305	.0354	.0171	.0354	.0354	.0305	.0351
5	.0305	.0354	.0347	.0532	.0358	.0305	.052
6	.0486	.0532	.052	.0532	.0354	.0486	.052
7	.0486	.0532	.0514	.0532	.0532	.0486	.0526
8	.0486	.0532	.0543	.0532	.0532	.0486	.052
9	.0486	.0503	.0503	.0549	.0532	.0486	.0532
10	.0532	.0509	.0503	.0532	.0532	.0486	
11	.0532	.0509	.0532	.0532	.0486	.052	.0532
12	.0532	.0469	.0532		.0486		.0532
13	.0532	.0509	.0532	.0532		.0526	.0509
14	.0532	.0503	.0532	.0532	.0503	.0526	.0509
15	.0532	.0509	.0532	.0509	.0486	.0509	.0532
16	.0532	.0503	.0532	.0509	.0486	.0503	.0532
17	.0532	.048		.0509	.0486	.0509	.0532
18	.0532	.0509	.0532		.0497	.0509	.0532
19	.0709	.0514	.0709	.0532	.0686	.052	.0532
20	.0709	.0678	.0709		.0663		.0709
21	.0532	.0492	.0532		.0497	.0526	.0509
22	.0532	.0339	.0532		.0486	.0332	.0354
23	.0354	.017	.0532		.0305	.0351	.0339
24	.0305	.0354	.017		.0177	.0305	
Max	.0709	.0678	.0709	.0549	.0686	.0526	.0709
Min	.0305	.017	.0168	.0354	.017	.0305	.0339
Avg	.0475	.0455	.0458	.0495	.0433	.0436	.0485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 202 / 11KV KARANJFEN AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	2.6749
Max	2.6749
Min	2.6749
Avg	2.6749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 203 / 11KV PADASALI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	.0354	.0351	.0177		1.3375
2	1.5947	.0354	.0351	.0177		1.4723
3	1.5061	.0354	.0354			1.4723
4	1.5061	.0354	.0351			1.4723
5	1.5061	.0354	.0351			1.5775
6	1.5061		.0358			1.893
7	1.5432		.0514	.0177		2.1033
8	.0305	.0354	.0351	.0177		2.0576
9	2.3034	2.1862		2.1262		.0305
10	2.4806	3.103	1.8842	2.3034	.0354	.0305
11	2.0376	2.9007	2.1262	2.6578	.0305	.0339
12	1.9667	2.8166	3.0121	2.713	.0305	
13	2.0376	.0335	3.0653			
14	2.0553	.0335	2.8349	2.6932		
15		.0339		2.5095		
16	2.1971	2.8607	2.4806	2.9235		
17	2.3211	2.7349		2.8349	.0305	
18	.0354	2.7362	.0177		.0305	.0509
19		.0509	.0177	.0358	.0305	.0526
20	.0354	.0492	.0177		.0305	
21	.0354	.0503	.0177		.0305	.0526
22	.0354	.0339	.0177		.0305	.0351
23	.0354	.0335	.0177		.0305	.0347
24	1.9719	.0354	.0339	.0177		.0305
Max	2.4806	3.103	3.0653	2.9235	.0354	2.1033
Min	.0305	.0335	.0177	.0177	.0305	.0305
Avg	1.3789	.9048	.7544	1.4918	.0310	.8081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 204 / 11 Kv Boragaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945				.2818	.2658
2	.9431				.2818	.2629
3	.9431				.2818	.2629
4	.9431				.2915	.2572
5	.9945				.3601	.2572
6	1.046				.463	.2629
7	1.1145				.463	.333
8					.463	.3294
9	1.3889	1.4582	1.5746	1.0682		.333
10	1.4232	1.4737	1.5565	1.0808		
11	1.2757	1.4232	1.5592	1.0174		
12	1.3998	1.4074	1.5061	1.0745		
13	1.382		1.5415	1.0631		
14	1.3289		1.4706	1.1163		
15	1.2934			1.0631		
16	1.258	1.4074		1.0454		
17		1.3735				
18		1.2742				
24	1.0288					
Max	1.4232	1.4737	1.5746	1.1163	.463	.333
Min	.9431	1.2742	1.4706	1.0174	.2818	.2572
Avg	1.1723	1.4025	1.5348	1.0661	.3608	.2849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 205 / 11 KV PADASALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0886	1.6297	.0709		.0648
2	.0648	.0709	1.6301	.0709		.0648
3	.0648	.0709	1.5947	.0709		.0648
4	.0648	.0709	1.6476	.0709		.0648
5	.081	.0886	1.647	.0886		.081
6	.116			.1595		.0995
7	.116		1.6461	.1772		.1174
8	.1326	.1063	.1387	.1595		.1174
9	.1326	.0995		.124		1.4918
10	.116	.1017	.1134	.1187	.9922	1.7661
11	.1063	.12	.1063	.1017	1.046	1.7804
12	.1063	.1187	.1063	.1063	1.2689	1.7804
13	.1063	.1147	.124		1.5432	1.7974
14		.1147	.124		1.8004	1.7772
15		.1326		.1063	1.7147	1.7878
16	.124	.1341	.124	.1063	1.6289	1.6651
17	.1417	.1187		.1063	1.5432	.1357
18	.1772	.1326			1.286	.1543
19	.2126	.2035	.1949	.124	.1715	.2254
20	.2126	.2713	.1595		.2229	
21	.2126	.2012	.1595		.1715	.1543
22	.9745	1.6549	.1417		.1326	.1017
23	.1772	1.6194	.0886		.081	.0867
24	.0648	.1063	1.5746	.0886		.0648
Max	.9745	1.6549	1.6476	.1772	1.8004	1.7974
Min	.0648	.0709	.0886	.0709	.081	.0648
Avg	.1623	.2609	.6816	.1089	.9716	.6715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 206 / 11 KV KARANJFEN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1326	.124	.1017	.1063	.124	.1326	.0671
2	.1326	.1063	.104	.1063	.124	.1326	.0678
3	.1326	.1063	.1029	.1063	.124	.1326	.0678
4	.1326	.1063	.104	.1063	.124	.1326	.0701
5	.1658	.124	.1402	.124		.1492	.0876
6	.2058	.2126	.208	.2303	.1417	.2204	.1052
7	.2401	.2481	.2401		.2303	.2401	.1402
8	.2572	.2835	.2601	.2835	.2543	.2401	.1402
9	.2572	.2347	.2458	.2481	.2543	.2572	.1402
10	.2572	.2347	.2429	.2481	.2658	.2572	.2543
11	.2481	.2572	.2658	.2481	.2572	.2543	.2658
12	.2481	.2374	.2658	.2481	.2572	.2543	
13	.2481	.2601	.2481	.2374	.2572	.2374	.2658
14	.2481	.2429	.2481	.2507	.2572	.2515	.2658
15	.2481	.2515	.2481	.2507	.2572	.2543	.2658
16		.2515	.2481	.2374	.2572	.2486	.2658
17	.2658	.2713		.2658	.2572	.2515	.2658
18	.2658	.2652			.2743	.2774	.2543
19	.3366	.373	.2303	.3189	.3506	.3814	.3189
20	.3721	.4024	.2835		.4207		.4252
21	.3544	.3856	.2658		.3506	.4207	.3544
22	.2658	.2374	.2126		.2572	.2481	.3189
23	.2126	.1492	.1772		.1658	.1402	.1949
24	.1326	.1417	.1006	.124	.1187	.1326	
Max	.3721	.4024	.2835	.3189	.4207	.4207	.4252
Min	.1326	.1063	.1006	.1063	.1187	.1326	.0671
Avg	.2330	.2295	.2065	.2078	.2339	.2281	.2092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 201 / 11 KV Salawan Sheti

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 202 / 11 KV SAVARDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 203 / 11 KV VETAVDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 204 / 11 KV Salawan Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 205 / 11 KV WALOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 206 / Punal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.4801
Max	.4801
Min	.4801
Avg	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 207 / Punal Sawarde Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 208 / 11 KV Waloli Sheti

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 402 / 33 KV NAGRIKA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	8.5734
Max	8.5734
Min	8.5734
Avg	8.5734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 201 / 11 KV KAKHE AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	2.0934		1.1279	.1372	.1543	.0914
2	.1029	1.9528		1.0974	.1372	.1372	.0914
3	.1029	1.9528	1.6156	1.0669	.1372	.1372	.0914
4	.1067	1.9685	1.6766	1.0669	.1372	.1372	.0914
5	.1372	2.0309	1.7833	1.1279	.1372	.1372	.0914
6	.1372	2.2184		1.1888	.1543	.1543	.1067
7	.1372	2.0622	2.0881	1.3413	.1543	.1715	.1219
8	.1372	.1372	.0914	.1219	.1715	.1886	.1219
9	.1029	.1372	.1029	1.829	1.9814	2.1643	1.9841
10	.0686	.1219	.1029	2.1605	2.4082	2.8197	2.4215
11	.0686	.1219	.0857	1.9204	2.4082		2.4996
12	.1029	.1219	.0686	1.9509	2.4691	2.5911	2.1795
13	.0914	.0857	.0686	1.9814	2.4082	2.4691	2.1643
14	.0914		.1372	1.9052	2.3777	2.5911	2.1186
15	.0914		.1372	1.9204	2.4234	2.5911	2.3015
16	.1219		.1715	1.829	2.3777	2.4082	2.3167
17	.061			.1219	.1219	2.3777	.061
18	.1372		.0686	.12	.1715	.1219	.1372
19	.1715	.1524	.1372	.12	.1715		.1715
20	.1715	.1715	.1372	.1543	.1543	.1067	.1372
21	.1715	.1524	.1372	.1372	.1715	.0914	.1715
22	2.4691	2.1033	1.406	.1543	.1715	.0914	.1372
23	2.5309	2.0729	1.3717	.1372	.1715	.0914	.1372
24	.1372	2.2653		1.1736	.1372	.1715	.0914
Max	2.5309	2.2653	2.0881	2.1605	2.4691	2.8197	2.4996
Min	.061	.0857	.0686	.12	.1219	.0914	.061
Avg	.3154	1.1538	.5993	1.0731	.8871	.9956	.8266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 202 / 11KV KODOLI URBAN VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8573		.7011	.823	.8573	
2	.7545	.823	.8059	.6706	.8573	.823	.7716
3	.7545	.823	.7888	.6706	.8573	.823	.7716
4	.7888	.823	.8059	.7011	.8573	.823	.7716
5	.823	.823	.8059	.7316	.8573	.8573	.7716
6	.8573	.9259	.8745	.7621	.8916	.8916	.8573
7	.9259	.8745	.9088	.7926	.9431	.8573	1.3546
8	.8573	.8745	.8573	.7316	.8745	.7888	.8402
9	.7011	.8916	.9259	.7926	.8745	.8916	.8059
10	.7716	.7621	.9431	.8916	.9431	.7621	
11	.7888	.7926	.9259	.9259	.9431	.7926	
12	.6687	.7926	.9774	.8916	.8916	.823	.9297
13	.7373	.9259	.9774	.8916	1.0117	.823	.8383
14	.7716	.8402	.9431	.8059	.9431	.8535	.8535
15	.7545	.8573	.9431	.8573	.9259	.7926	
16	.7545	.8916	.9774	.8573	.9088	.7621	.884
17	.7888	.9602		.945	1.0288	.7926	.9145
18	.8916	1.0117	.1715	1.1317	1.0288	.9774	1.0631
19	1.0974	1.1831	1.2346	1.166	1.0974		1.2346
20	1.2346	1.3546	1.2346	1.3717	1.286	1.2517	1.2955
21	1.2003	1.2003	1.1317	1.2346	1.2346	1.0802	1.2346
22	1.1317	1.1145	1.0631	1.1488	1.1317	1.1145	1.2003
23	1.0288	.9945	.9259	1.0117	1.0288	1.0288	1.0631
24	.8573	.8916	.8573	.7316	.8745	.8916	.8573
Max	1.2346	1.3546	1.2346	1.3717	1.286	1.2517	1.3546
Min	.6687	.7621	.1715	.6706	.823	.7621	.7716
Avg	.8651	.9287	.9127	.8923	.9631	.8852	.9656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 203 / 11 KV FACTORY VILLAGE

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0029		.7621	.8596	.823	.7202
2	.823	1.0566	.9431	.7316	.8417	.7888	.703
3	.7888	1.0029	.9602	.7011	.8417	.7888	.6859
4	.7888	.985	.9945	.7316	.8596	.7888	.6859
5	.823	.985	1.046	.7926	.9313	.8916	.6859
6	.8573	1.1641	1.2517	.945	1.0745	.9945	.9945
7	1.0631	1.3073	1.286	1.0669	1.0745	1.1488	.9945
8	1.2003	1.2178	1.2346	1.0059	1.0208	1.0288	1.0631
9	1.0974	1.2715	1.2536	1.0059	1.0745	.9945	1.1283
10	1.0631	1.0364	1.3969	1.1317	1.0631	1.0517	1.2178
11	.7202	1.0669	1.3253	1.0288	1.1317	.9755	.985
12	.703	.9755	1.182	.9259	1.3203	.884	.7621
13	.9259	1.166	1.182	.9602	1.3375	.9145	.8688
14	.9774	1.2689	1.2178	1.0974	1.2689	1.0059	.9602
15	.9602	1.286	1.3432	1.1317	1.286	1.1888	1.1126
16	.9945	1.3032	1.3432	1.1145	1.3032	1.0974	1.3375
17	1.0631	1.2689		1.0822	1.2517	1.1279	1.1736
18	.9671	1.1145		1.1283	.9602	1.2003	1.0631
19	1.182	1.2689		1.1462	1.0974		1.2003
20	1.2178	1.2689	.7202	1.3253	1.2174	.9774	1.2003
21	1.2489	1.2003	1.166	1.2357	1.1317	1.046	1.1317
22	1.2894	1.2346	1.0288	1.1462	1.2003	.9431	1.0631
23	1.086	.9945	.9602	1.0029	.9259	.8573	.9259
24	.8573	.9412	.8573	.7926	.8954	.8573	.7202
Max	1.2894	1.3073	1.3969	1.3253	1.3375	1.2003	1.3375
Min	.703	.9412	.7202	.7011	.8417	.7888	.6859
Avg	.9815	1.1412	1.1346	.9997	1.0820	.9728	.9743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 204 / 11 KV POKHALE Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.9374		.2743	.3086	.3429	.2591
2	.3086	.8124		.2439	.2743	.3086	.2591
3	.3086	.8124	1.6156	.2439	.2743	.3086	.2591
4	.3429	.828	.9755	.2439	.2915	.3086	.2591
5	.3772	.9374	.9755	.2743	.3086	.3772	.3048
6	.4115	1.5779		.3048	.3601	.3944	.3353
7	.4115	1.3123	1.3717	.3353	.3772	.4115	.3658
8	.4115	.3772	.3658	.1524	.3944	.4115	.3201
9	.4115	.3258	.3944	.4877	1.4403	.9145	1.2498
10	.3429	.3048		.9259	1.6613	1.7375	1.4373
11	.3429	.3048		.9145	1.5394	1.7375	1.406
12	.3258	.3048		.9145	1.448	1.5699	1.4746
13	.3048	.3944	.4115	.823	1.2955	1.3717	1.2651
14	.3048	.3601	.3944	.9907	1.1584	1.1888	1.1584
15	.3201	.3772	.4115	.9755	1.1584	1.2193	1.2498
16	.3353	.3772	.4287	.884		1.0059	1.1279
17	.3658	.2915				.2134	.2896
18	.3944	.3201			.4458	.3201	.3048
19	.4458	.4268	.1372	.3086	.4115		.4115
20	.463	.3963	.1372	.3429	.3944	.2439	.4287
21	.4458	.381	.1715	.3601	.3944	.2439	.4115
22	1.6004	1.5394	.3086	.3429	.3944	.2591	.4115
23	1.4842	1.3717	.3086	.3086	.3601	.2439	.3429
24	.3601	1.1717		.2896	.2743	.3429	.2591
Max	1.6004	1.5779	1.6156	.9907	1.6613	1.7375	1.4746
Min	.3048	.2915	.1372	.1524	.2743	.2134	.2591
Avg	.4651	.6768	.5605	.4973	.6802	.6729	.6496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 205 / 11 KV AMRUT AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	1.7185		.6706	.1543	.1372	.1372
2	.1372	1.531		.6401	.1543	.1372	.1543
3	.1029	1.4685	1.3717	.6401	.1543	.1372	.1372
4	.1372	1.4685	1.4022	.6401	.1543	.1372	.1372
5	.1715	1.4685	1.4327	.6706	.1543	.1543	.1524
6	.1715	1.7497		.7011	.1886	.1715	.1677
7	.2058	1.7654	1.6004	.7011	.1886	.1886	.1524
8	.2058	.1715	.2286	.1067	.2058	.1715	.1677
9	.2401	.1715	.2401	1.0059	1.5935	.061	1.4373
10	.2229	.1524		1.2003	1.8747	1.6004	1.656
11	.1715	.1829			1.7528	1.9509	1.7497
12	.1715	.1829		1.3717	1.7071	2.0119	
13	.1372	.2058	.2572	1.4937	1.5089	1.8595	
14	.1219	.1715	.2572	1.4327	1.4632	1.7528	
15	.1219	.1715	.1886	1.4022	1.4327	1.768	
16		.1715	.1715	1.2803	1.4327	1.6461	1.829
17	.2134	.1886		.1524	.1372	1.4632	1.7985
18	.2058	.1829		.1715	.1372	.1981	1.3413
19	.1886	.1829		.1886	.1715		.2058
20	.2058	.1829	.1029	.1886	.1886	.1677	.1715
21	.2058	.1829	.1029	.1886	.1715	.1524	.2058
22	2.1491	2.0119	.7716	.1715	.1715	.1715	.1886
23	2.1559	1.7833	.7716	.1715	.1372	.1372	.1715
24	.1715	1.8747		.6706	.1543	.1543	.1372
Max	2.1559	2.0119	1.6004	1.4937	1.8747	2.0119	1.829
Min	.1029	.1524	.1029	.1067	.1372	.061	.1372
Avg	.3457	.8059	.6357	.6896	.6412	.7100	.6049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 206 / 11 KV KAKHE VILLAGE FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4908		.381	.5784	.4458	.6001
2	.5144	.5609	.5658	.3658	.5258	.4287	.6001
3	.4801	.5434	.583	.3353	.4557	.4287	.5658
4	.4458	.5609	.583	.3353	.4031	.4287	.5658
5	.4115	.5784	.463	.3048	.4031	.4458	.5144
6	.4458	.5959	.463	.3353	.4382	.3429	.4801
7	.2915	.4733	.463	.381	.4382	.3086	.4458
8	.3601	.4733	.463	.4268	.4733	.3086	.4973
9	.4115	.4908	.5784	.381	.4382	.3086	.4733
10		.4115	.5609	.4287	.463	.3048	.0596
11	.5487	.4115	.631	.6173	.4115	.4115	.5784
12	.6001	.4268	.6661	.6173	.3944	.3506	.4725
13	.6173	.2915	.6485	.6344	.463	.3658	.4725
14	.6173	.3086	.6485	.6173	.6687	.3658	.4877
15	.6001	.5144	.6661	.6001	.6516	.381	.5182
16	.6001	.6001	.6661	.5144	.7202	.381	.5487
17	.5658	.6001		.4572	.6516	.5182	.4572
18	.631	.6859	.3429	.631	.6173	.6001	.6001
19	.6661	.6687	.3944	.6485	.5658	.6001	.7545
20	.5959	.7373	.3429	.7362	.6344	.6344	.7373
21	.6984	.6859	.583	.6836	.6859	.7202	.7373
22	.5083	.6516	.5316	.6485	.5487	.703	.6859
23	.4835	.4801	.5144	.5434	.4458	.6859	.6516
24	.583	.4656	.4458	.3963	.5784	.463	.6001
Max	.6984	.7373	.6661	.7362	.7202	.7202	.7545
Min	.2915	.2915	.3429	.3048	.3944	.3048	.0596
Avg	.5315	.5295	.5366	.5009	.5273	.4555	.5460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 207 / 11 KV Jakhoba LIS

PURELY LIS FEEDERS

Feeder KV- 11 / INCOMING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0514	.0686		.0514	.0514	.0686
4	.0514	.0686		.0514	.0686	.0686
5	.0514	.0686		.0514	.0686	.0686
6	.0514	.0686	.0305	.0514	.0686	.0686
7	.0514	.0686	.0305	.0514	.0686	.0686
8	.0514	.0686	.0457	.0514	.0686	.0686
9	.0686	.0686	.0305	.0514	.0686	.0686
10	.061	.0686	.0514	.0514	.061	.0701
11	.0457	.0343	.0514	.0514	.061	.0686
12	.0457	.0514	.0343	.0686	.0457	.061
13	.0686	.0514	.0343	.0686	.0305	.061
14	.0686	.0514	.0514	.0686	.061	.061
15	.0686	.0514	.0514	.0686	.061	.061
16	.0686	.0514	.0514	.0686	.061	.061
17	.0686		.0457	.0686	.061	.061
18	.0686	.0343	.0514	.0343	.0514	.0686
Max	.0686	.0686	.0514	.0686	.0686	.0701
Min	.0457	.0343	.0305	.0343	.0305	.061
Avg	.0588	.0583	.0431	.0568	.0598	.0658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 401 / 33 KV Biltube Express
Feeder Feeder KV- 33 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.3663		2.2862	2.1605	2.1605	2.0576
2	2.4691	2.3663	2.1605	2.1948	2.1091	2.2634	2.0062
3	2.3663	2.3148	2.4691	2.1033	2.1605	2.2634	2.0576
4	2.0576	2.3663	2.572	2.0119	2.0576	2.2634	1.9547
5	2.2634	2.4177	2.6235	2.1948	1.8004	2.3663	1.8519
6	2.6749	2.1605	2.1091	2.2862	2.0576	2.4691	1.8004
7	2.572	2.1605	2.8292	2.4691	2.0062	2.8292	2.0576
8	2.4691	2.4691	2.6749	1.6004	.7202	2.4691	1.8519
9	2.3148	2.4691	2.4691	1.9204	.6173	2.0576	2.2634
10	2.3148	2.1948	2.4691	2.6235	.6687	2.1948	2.2634
11	2.3148	2.0576	2.3148	2.4691	.6687	2.0119	2.3663
12	2.1605	1.9547	2.6749	2.4691	.5658	1.829	1.7833
13	2.0576	1.9547	2.4691	2.3148	.5658	1.6461	2.4177
14	1.9547	2.4691	2.8807	2.4691	.5658	1.6461	2.4234
15	2.1605	1.829	2.2634	2.8807	.5658	2.0119	2.1091
16	2.3663	2.1091	2.3148	2.9835	.5658	1.9662	2.2405
17	2.2634	2.3148		2.2634	.6173	2.1033	1.8747
18	2.0576	2.3663	.823	2.2119	.5144	2.6235	2.0576
19	2.572	2.3663	.8745	2.6749	.6173	2.3663	2.2119
20	2.1605	2.1091	1.0802	2.1091	.6173	1.9547	2.0576
21	2.0062	2.1605	2.2119	1.9547	.6173	2.9835	2.2119
22	2.3663	2.5206	2.4177	2.4691	1.0288	2.2119	2.0576
23	2.2119	2.9321	2.4691	2.572	2.3148	2.0576	2.3148
24	2.6749	2.3663	2.1605	2.2862	2.2119	2.2634	2.0576
Max	2.6749	2.9321	2.8807	2.9835	2.3148	2.9835	2.4234
Min	1.9547	1.829	.823	1.6004	.5144	1.6461	1.7833
Avg	2.3084	2.2832	2.2423	2.3258	1.1831	2.2088	2.0979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 201 / Single Phasing Stave- SINGLE PHASING
 Sawarde Feeder KV- 11 /
 OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.1143		.0934	.7459	.6274	.4801
2	1.1431	.1143	.1132	.0934	.7127	.8048	.5144
3	1.1431	.0953	.0934	.0934	.6874	.7712	.5144
4	1.1431	.0953	.0953	.0934	.6874	.7042	.5144
5	1.1812	.1143	.0953	.0934	.6874	.7712	.5365
6	1.1812	.1143	.1132	.0914	.132	.8048	.5967
7	1.2193	.0953	.1029	.1086	.1109	.8951	.6802
8	.0914	.0905	.0739	.112	.1097	.8288	
9	1.2193	.1294	1.5089	.0905	.0838	.0829	.0686
10	1.419	1.4003	1.5339	.0655	.0671	.0655	.0503
11	1.358	1.4003	1.5708	.0663	.0829	.0953	.0762
12	1.3817	1.4003	1.3306	.0829	.0492		.0762
13	1.3957	.0747	1.307	.0829	.0953		.0953
14	1.1317	.0747	1.3256	.0848	.0953	.0953	.0953
15	1.1949	.0747	1.3256	.0838	.0953	.0953	.0762
16	1.0374	1.4415	1.1203	.0838	.0953	.0953	.0762
17	.0914	1.0269	.0886	.1052	.0716	.0905	.0886
18	.0914	1.1506		.1086		.0732	.1075
19	.1307	.1307	.1254	.1307	.0943	.1097	.128
20	.1698	.1509	.1254	.1698	.1494		
21	.1698	.1509	.1433	.1698	.132		
22	.1715	.1524	.1307	.8551	.1307	.0754	.1307
23	.1524	.1334	.112	.8288	.132	.0754	.112
24	1.1812	.1334	.1132	.0934	.7956	.1017	.0566
Max	1.419	1.4415	1.5708	.8551	.7956	.8951	.6802
Min	.0914	.0747	.0739	.0655	.0492	.0655	.0503
Avg	.8559	.4108	.5704	.1617	.2627	.3632	.2416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 202 / Single Phasing Stave- SINGLE PHASING
 Mohare Feeder KV- 11 /
 OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0957		.6722			
2		2.0005		.6722			
3		1.9433	2.0911	.5975			
4		1.9433	2.1338	.5975			
5		1.9433	2.2862	.6348			
6		1.9433		.6584			
7		1.9052	1.4403	.7602			
9				1.3213	1.4754	1.326	1.6289
10				1.0322	1.8275	1.7368	.503
11				1.3426	1.3592	2.0957	2.4006
12				1.3426	1.7368	2.0195	2.4768
13				1.2266	1.9814	2.0005	1.9433
14				1.2209	2.0195	1.9052	2.1719
15				1.1401	1.9433	1.8671	2.1719
16				1.0898	1.8671	1.8099	2.2862
22	2.1338	2.2481	.7842				
23	2.3243	2.5339	.7468				
24		2.1338		.7468			
Max	2.3243	2.5339	2.2862	1.3426	2.0195	2.0957	2.4768
Min	2.1338	1.9052	.7468	.5975	1.3592	1.326	.503
Avg	2.2291	2.0690	1.5804	.9410	1.7763	1.8451	1.9478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 203 / Single Phasing Stave- SINGLE PHASING
 Satave Feeder KV- 11 /
 OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	.1143		.0934	.4641	.5596	.3772
2	1.105	.1143	.1132	.0934	.4144	.57	.2743
3	1.105	.1143	.0934	.0934	.4191	.6036	.2743
4	1.1431	.1143	.0953	.0934	.4191	.6036	.2743
5	1.1431	.1143	.0953	.0934	.4191	.6371	.3018
6	1.2193	.1143	.1132	.0914	.132	.6539	.3647
7	1.2574	.0953	.1029	.1086	.1109	.6796	.4049
8	.0914	.0905	.0739	.112	.0914	.6299	.3688
9	1.5623	1.423	1.4712	.0905	.0838	.0829	.0857
10	1.4003	1.4377	1.4415	.0655	.0838	.0819	.0503
11	1.2071	1.4003	1.5524	.0663	.0995	.0953	.0953
12	1.4937	1.3817	1.4969	.0829	.0492		
13	1.5089	.0747	1.4377	.0829	.1143		.0953
14	1.4712	.0747	1.419	.0848	.1143	.1334	.0953
15	1.4937	.0747	1.3817	.1006	.1143	.1334	.0953
16	1.226	1.0164	1.2883	.0838	.0953	.1143	.0953
17	.0914	1.1203	.0886	.1052	.0895	.1086	
18	.0914	.679		.1086	.0716	.0914	
19	.1307	.1307	.1254	.1307	.0943		
20	.1698	.1509	.1075	.1698	.1494	.1494	
21	.1698	.1509	.1478	.1698	.1509	.1509	
22	.1715	.1524	.1307	.6203	.1494	.1509	.1307
23	.1524	.1334	.112	.5304	.132	.132	.112
24	1.105	.1334	.1132	.0934	.4973	.1132	.1132
Max	1.5623	1.4377	1.5524	.6203	.4973	.6796	.4049
Min	.0914	.0747	.0739	.0655	.0492	.0819	.0503
Avg	.9006	.4336	.5910	.1402	.1900	.3083	.2005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 201 / Shahuwadi-Maan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1132	.1663	.0754	.1109	.1132	.1132
2	.112	.1132	.1448	.0754	.0924	.1132	.0943
3	.112	.1132	.1448	.0754	.0914	.1132	.0943
4	.1307	.1307	.1463	.0943	.0732	.1494	.0943
5	.1646	.1463	.1646	.112	.0924	.1663	.1307
6	.181	.181	.1886	.112	.0924	.181	.1463
7	.1928	.2126	.2149	.1294	.1097	.1791	.1595
8	.2204	.2303	.2303	.1448	.1463	.1612	.1402
9	.2058	.2229	.197	.1227			.1267
10	.1844	.2035	.1791	.1254	.2012	.1886	.1063
11	.1715	.1526	.1753		.1543	.1886	.1086
12	.1677				.1492	.1734	.1448
13	.1715				.1311	.1227	.1595
14	.1372	.218			.1844	.1214	.1753
15	.1543	.1715	.1865		.1357	.1187	.1448
16	.1492	.1844	.1844		.1341	.12	.1417
17	.156	.1865	.1696	.1715	.1677	.104	.1526
18	.1753	.1865			.1715	.1402	.1475
19	.2561	.2103		.1372	.2149	.181	.181
20	.2772	.2957	.1698	.1402	.2402	.2241	.2772
21	.2587	.2561	.2075	.1629	.2241	.1867	.2587
22	.2427	.2241	.1698	.1646	.1867	.1698	.2218
23	.1867	.1867	.132	.1463	.168	.132	.1867
24	.1463	.1509	.1698	.0943	.1109	.1307	.1132
Max	.2772	.2957	.2303	.1715	.2402	.2241	.2772
Min	.112	.1132	.132	.0754	.0732	.104	.0943
Avg	.1778	.1859	.1759	.1226	.1471	.1512	.1508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 202 / Shahuwadi- Amba

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1886	.2263	.132	.1463	.1509	.1509
2	.1509	.1698	.2218	.1132	.1448	.1509	.1509
3	.1509	.1698	.2218	.1132	.1463	.1509	.1509
4	.168	.1867	.2195	.1132	.1478	.1867	.1509
5	.2033	.2218	.2353	.1509	.1478	.1867	.168
6	.2218	.2402	.2353	.1698	.1463	.2054	.1867
7	.2561	.2561	.2353	.1886	.1463	.2054	.2054
8	.2896	.2686	.3109	.2033	.1848	.2402	.2195
9	.3189	.3292	.3439	.2507	.2172	.2378	.2715
10	.3012	.333	.3224	.2572	.2195	.3012	.2865
11	.3012	.3856	.3045	.2103	.2507	.2715	.2686
12	.3189	.3641	.3155	.1791	.2804	.2686	.3012
13	.298	.3155	.3155	.2481	.2481	.2561	.2715
14	.3012	.3189	.3155	.2195	.2481	.2378	.2561
15	.3045	.3403	.3366	.2172	.2658	.2715	.2896
16	.2601	.3721	.333	.2012	.2454	.2561	.2896
17	.2328	.3366	.3403	.2149	.1928	.2481	.2865
18	.2534	.2774		.2103	.2149	.2507	.2835
19	.2926	.3258		.1753	.2561	.2743	.2804
20	.2957	.3439	.1829	.2149	.2801	.2987	.3012
21	.2801	.2957	.2427	.2172	.2614	.2801	.2987
22	.2614	.2614	.2263	.181	.2263	.2614	.2614
23	.2263	.2587	.2075	.1646	.2263	.2263	.2241
24	.1886	.1886	.2427	.1509	.1629	.1886	.1886
Max	.3189	.3856	.3439	.2572	.2804	.3012	.3012
Min	.1509	.1698	.1829	.1132	.1448	.1509	.1509
Avg	.2511	.2812	.2698	.1874	.2086	.2336	.2393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 203 / Shahuwadi-sawe

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2641	.2987	.1132	.3361	.3018	.3018
2	.2641	.2641	.2987	.1132	.2987	.3018	.2641
3	.2641	.2641	.2772	.1132	.2987	.3018	.2641
4	.2641	.2641	.2772	.1509	.2987	.3018	.2641
5	.3018	.2987	.4854	.1886	.3326	.3361	.3018
6	.3734	.3361	.439	.2263	.3475	.3734	.3361
7	.3921	.3734	.4251	.2452	.3511	.3734	.3921
8	.3292	.3292	.3511	.1886	.4108	.4108	.4251
9	.3658	.4207	.3658	.2614	.4207	.4163	.4525
10	.3658	.3982	.362	.3174	.4066	.3658	.4207
11	.3658	.4024	.362	.2957	.3921	.1928	.3881
12	.3511	.3841	.3326	.2829	.3881	.3841	.3361
13	.3326	.3326	.3361		.3658	.2561	.3361
14	.2829	.2926	.2987	.2075	.2957	.3142	.2801
15	.2772	.2614	.2926	.2241	.3109	.2926	.2614
16	.3224	.3142	.3511	.2263	.3326	.3292	.2829
17	.3439	.3475	.3696	.2772		.4119	.3475
18	.4024	.3841		.3292		.4706	.4024
19	.5121	.4938		.4294	.5544	.5175	.4805
20	.5544	.5792	.2987	.5175	.6348	.5601	.5788
21	.5228	.567	.2829	.5228	.5975	.2987	.4854
22	.4527	.439	.2452	.4854	.4904	.2241	.4527
23	.3772	.4066	.2075	.4108	.415	.3961	.4108
24	.3206	.3018	.3395	.1509	.3395	.3395	.3395
Max	.5544	.5792	.4854	.5228	.6348	.5601	.5788
Min	.2641	.2614	.2075	.1132	.2957	.1928	.2614
Avg	.3600	.3633	.3317	.2729	.3917	.3529	.3669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 204 / Shahuwadi-Kotoli Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391				.1341
2	.3391				.1341
3	.3429				.1357
4	.3688				.1677
5	.4024				.1677
6	.426				.1989
7	.4588				.2155
8					.1638
9	.57	.5765	.6706	.2155	
10	.6443	.57	.6299	.1943	
11	.6104	.5533	.6203	.1943	
12	.6104	.5868	.5801	.1781	
13	.5533		.57	.1619	
14	.57		.5365	.1492	
15	.5596		.5868	.1696	
16	.5182	.5138	.4752	.1677	
17		.5197			
18		.5304			
24	.3688				
Max	.6443	.5868	.6706	.2155	.2155
Min	.3391	.5138	.4752	.1492	.1341
Avg	.4801	.5501	.5837	.1788	.1647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 205 / Shahuwadi - Malkapur
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3018	.3961	.3018	.3772	.3395	.3395
2	.3018	.3018	.3772	.2641	.3395	.3018	.3018
3	.3018	.3018	.3734	.2641	.3395	.3018	.3018
4	.3018	.3361	.3734	.2641	.2987	.3395	.3018
5	.3395	.3361	.3881	.3018	.3395	.3734	.3361
6	.3734	.3734	.4066	.3734	.3696	.3772	.3734
7	.4066	.4108	.4066	.4108	.3696	.415	.4294
8	.4024	.4207	.4108	.4435	.4024	.4108	.4435
9	.439	.4805	.4668	.4066	.439	.462	.4668
10	.439	.4755	.4755	.439	.5601	.4755	.5175
11	.4435	.4938	.5487		.6219	.567	.5487
12	.4251	.543	.543	.6219	.6036	.5487	.5487
13	.4435	.5611	.543	.567	.5853	.5853	.5121
14	.4251	.5611	.5487	.6036	.6036	.5853	.5121
15	.4805	.6036	.5611	.5792	.6036		.5487
16	.4706	.567	.543	.567	.5729		.567
17	.4525	.567		.5249		.6089	.4938
18	.5487	.4835		.4572	.5544	.6154	.4656
19	.6283	.5544		.724	.5975	.6584	.5853
20	.6722	.6283		.695	.6722	.7095	.6653
21	.6348	.6224	.5601	.6401	.6348	.6224	.6413
22	.5658	.5228	.4904	.5853	.1715	.547	.5601
23	.4527	.4108	.4338	.4854	.4715	.4904	.4854
24	.3772	.3772	.3961	.3395	.415	.415	.415
Max	.6722	.6283	.5611	.724	.6722	.7095	.6653
Min	.3018	.3018	.3734	.2641	.1715	.3018	.3018
Avg	.4444	.4681	.4621	.4721	.4758	.4886	.4734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 206 / Shahuwadi-Parale Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.6935			.1867	.0191	.021
2	.0191	.7011			.181	.0191	.0229
3	.021	.7011	.5304		.1829	.021	.0229
4	.021	.6935	.5304		.1829	.021	.0248
5	.0257	.6661	.57		.1829	.0229	.0248
6	.0305	.6588				.0238	.0267
7	.0372	.6415	.5533			.0248	.0267
8	.0362	.0381	.0244			.0267	.0267
9	.0305	.0362	.0267		.4252	.5959	.6733
10	.0305	.0343	.0248		.5258	.6935	.6588
11	.0267	.0352	.0286		.4917	.7011	.691
12	.0238	.0229	.0267		.4862	.6935	.7186
13	.0248	.0229	.0267		.4588	.7108	.7186
14	.0238	.0133	.0248		.4694	.6485	.7186
15	.0295	.0133	.0305	.0305	.407	.5895	.6661
16	.0343	.0295	.0238	.0286	.3353	.6379	.6379
17	.0257	.0248	.0362	.0286	.0229	.0238	.0152
18	.0267	.0267		.0267	.0248	.0248	.0324
19	.0286	.0305		.0229	.0191	.1852	.0257
20	.0286	.0333		.0305	.0171	.0267	.0276
21	.0295	.0333		.0305	.0171	.0191	.0248
22	.7888	.788		.2218	.0152	.0133	.0267
23	.7628	.7537		.1848	.0143	.0171	.0333
24	.0133	.7362			.1867	.0171	.0191
Max	.7888	.788	.57	.2218	.5258	.7108	.7186
Min	.0133	.0133	.0238	.0229	.0143	.0133	.0152
Avg	.0890	.3095	.1755	.0672	.2301	.2407	.2452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 207 / Shahuwadi-Bajagewadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.407				.1696
2	.407				.1696
3	.407				.1677
4	.4287				.1696
5	.4359				.2058
6	.4694				.2401
7	.4862				.2601
8					.3561
9	.5967	.5935	.6036	.4359	
10	.5801	.6371	.5636	.2883	
11	.5256	.6036	.5197	.285	
12	.5533	.57	.5197	.2883	
13	.5533		.503	.2713	
14	.5197		.4694	.2572	
15	.5304		.4588	.2572	
16	.4858	.5426	.4424	.2572	
17		.5256			
18		.5197			
24	.4458				
Max	.5967	.6371	.6036	.4359	.3561
Min	.407	.5197	.4424	.2572	.1677
Avg	.4895	.5703	.5100	.2926	.2173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 208 / Shahuwadi-Perid Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.57					
2		.5765					
3		.5765	.3647				
4		.57	.3647				
5		.5636	.4024				
6		.5636	.431				
7		.5571	.4641				
9						.4588	.426
10					.4359	.5761	.663
11					.3932	.5571	.6443
12				.2656	.3887	.5344	.6104
13				.2408	.3437	.4744	.5407
14				.2812	.3321	.502	.5079
15				.2812	.3201	.5121	.4973
16				.3005	.2688	.4696	.4973
22	.6036	.5365					
23	.57	.4973					
24		.57					
Max	.6036	.5765	.4641	.3005	.4359	.5761	.663
Min	.57	.4973	.3647	.2408	.2688	.4588	.426
Avg	.5868	.5581	.4054	.2739	.3546	.5106	.5484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 209 / Shahuwadi-Ameni vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0381		.0373	.0377	.0373
2	.0377	.0373	.0362		.0373	.0373	.0373
3	.0377	.0373	.0362		.0377	.0373	.0373
4	.0377	.0373	.037		.0381	.0373	.0373
5	.0377	.0373	.037		.0381	.037	.0366
6	.0373	.037	.037		.0381	.037	.0366
7	.0373	.037			.0381	.037	.0366
8	.0366	.0362	.0362			.0362	.0362
9	.0362	.0358	.0351		.0381	.0358	.0358
10	.0358	.0354	.0351		.0381	.0354	.0354
11	.0351	.0351	.0351		.0351	.0351	.0351
12	.0351						.0351
13	.0351						.0351
14	.0351						.0351
15	.0351	.0351	.0351	.0175	.0351	.0351	.0351
16	.0351	.0351	.0351	.0175	.0351	.0351	.0351
17	.0362	.0351	.0351	.0351	.0351	.0351	.0351
18	.0362	.0351		.0351	.0351	.0351	.0351
19	.0366	.0362		.0351	.0354	.0351	.0351
20	.0366	.0362		.0362	.0532	.0354	.0373
21	.037	.0373	.037	.0362	.0362	.0362	.0373
22	.037	.0373		.0362	.0366	.0366	.0373
23	.0373	.0362		.0362	.0373	.037	.0373
24	.0373	.0373	.0381		.0362	.0377	.037
Max	.0377	.0373	.0381	.0362	.0532	.0377	.0373
Min	.0351	.0351	.0351	.0175	.0351	.0351	.0351
Avg	.0365	.0364	.0362	.0317	.0376	.0363	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 201 / Sarud-Bambawade Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335		.8962	.9335	.9997	.8962	.9145
2	.8402	.8383	.8871	.8402	.9431	.8962	.8383
3	.8402	.8383	.8686	.8402	.9431	.8686	.8383
4	.8402	.8383	.8686	.8962	.9431	.9149	.8764
5	.9335	.9145	.8686	.8962	.9997	.9335	.9145
6	1.1203	1.1431	1.0903	.9896	1.0751	.9522	.9907
7	1.0456	1.1431	1.1458	1.0456	1.2071	1.0829	1.0669
8	1.0456	1.1431	1.0719	1.0456	1.1317	1.0082	1.0669
9	.9896	1.0669	1.0082	1.0456	1.1317	.8589	1.1431
10	.9709	1.0642	1.2637		1.0534	1.2136	
11	.8962	.9795			1.0829	1.2136	1.1694
12	.8962	.9979	1.2637		1.2197		1.2826
13	.8962	1.1203	1.2449		1.0269	1.251	1.1317
14	.8962	1.0456	1.2071		1.2197	1.2696	1.2449
15	.8962	1.1088	1.226		1.2323	1.363	1.2071
16	.8962	1.1203	1.226		1.134	1.363	1.2637
17	1.0456	1.1949	1.1763		1.2323	1.1949	1.1128
18	1.1431	1.0829		1.226	1.2323	1.2193	1.226
19	1.3717	1.2696		1.3769	1.419	.1524	1.4901
20	1.6004	1.643		1.7353	1.643	1.3717	1.6221
21	1.5242	1.4937		1.5466	1.4937	1.2955	1.5278
22	1.2955	1.4784		1.4901		1.2955	1.3769
23	.9907	1.1949	.9335	1.2449	1.1203	1.0669	1.1694
24	.9907	.9907	1.0456	.9896	1.0562	.9709	.9907
Max	1.6004	1.643	1.2637	1.7353	1.643	1.3717	1.6221
Min	.8402	.8383	.8686	.8402	.9431	.1524	.8383
Avg	1.0374	1.1178	1.0718	1.1339	1.1539	1.0718	1.1506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 202 / Sarud-Bhedasgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.381	.3734	.1494	.3772	.3734	.381
2	.3361	.3429	.3734	.1494	.3206	.3734	.3429
3	.3361	.3429	.3326	.1494	.3206	.3547	.3429
4	.3361	.3429	.3696	.1494	.3206	.3734	.3429
5	.3361	.381	.3734	.1867	.3772	.4108	.381
6	.4481	.4572	.4108	.1867	.4338	.4481	.4191
7	.4668	.5335	.4481	.1867	.4715	.4481	.4572
8	.4854	.5716	.4481	.4481	.4338	.4805	.5335
9	.4854	.5335	.4108	.4294	.4527	.4854	.5335
10	.4435	.5175	.415		.4435	.4481	.4904
11	.4481	.4108			.4481	.4481	.4904
12	.4108	.4481	.4338		.4481	.4481	.4715
13	.3734	.4481	.4338		.4481	.4481	
14	.1867	.4481	.4904		.4481	.4481	
15	.1867	.4435	.4904		.4108	.4481	.4715
16	.1867	.4668	.4904		.4435	.4481	.4338
17	.1867	.4668	.4338		.3658	.4481	.4338
18	.4572	.4481		.679		.4572	.4715
19	.5716	.5601		.6224	.5228	.5716	.547
20	.7621	.6722		.7733	.7095	.7621	.7167
21	.6097	.5975		.6979	.5975	.6097	.679
22	.5335	.5544		.6036		.6097	.547
23	.4572	.4435	.1867	.4904	.4481	.4572	.4715
24	.3361	.381	.3881	.1494	.3772	.3734	.381
Max	.7621	.6722	.4904	.7733	.7095	.7621	.7167
Min	.1867	.3429	.1867	.1494	.3206	.3547	.3429
Avg	.4048	.4664	.4057	.3782	.4372	.4656	.4700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 203 / Sarud-Sarud Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1905	.2241		.2263	.2241	.1715
2	.2241	.1905	.2241		.1886	.2241	.1715
3	.2241	.1905	.2241		.1886	.2241	.1715
4	.2241	.1905	.2614		.1886	.2614	.1715
5	.2241	.1905	.2614		.1886	.2614	.1905
6	.2241	.2286	.2987		.2075	.2987	.2286
7	.2427	.2286	.2587		.2263	.2241	.2286
8	.2427	.2286	.1848		.1886	.2614	.2286
9	.2427	.2286	.2614		.2829	.2614	
10	.2241	.2241	.2641		.3326	.2241	.2452
11	.2241	.2241			.2987	.2241	.2829
12	.1867	.2241	.2452				.2641
13	.2241	.2241	.2452		.2987	.2241	.2641
14	.2241	.2241	.2641		.2587	.2241	.2641
15	.2241	.2218	.2452		.2957	.2987	.2641
16	.2241	.2241	.2452		.2987	.2241	.3018
17	.2587	.2241	.3206		.3361	.2241	.3018
18	.2667	.2957		.3018	.2987	.3048	.2829
19	.3048	.3361		.415	.3361	.3048	.3961
20	.3429	.3734		.415	.3734	.3048	.4904
21	.381	.3361		.3961	.3361	.3048	.3961
22	.3429	.3361		.3395		.2286	.3584
23	.2667	.2957	.2241	.2641	.2614	.1905	.3206
24	.2241	.1905	.2614		.2452	.2241	.1905
Max	.381	.3734	.3206	.415	.3734	.3048	.4904
Min	.1867	.1905	.1848	.2641	.1886	.1905	.1715
Avg	.2497	.2425	.2508	.3553	.2662	.2498	.2689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 204 / Sarud-Gogawe Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0187		.6036	.6653	.4572
2	.0191	.0191	.0187		.6036	.7392	.4572
3	.0191	.0191	.0187		.6036	.7468	.4572
4	.0191	.0191	.0187		.6413	.7468	.4572
5	.0191	.0191	.0187		.679	.8131	.5335
6	.0191	.0191	.0187		.0189	.8962	.6097
7	.0187	.0191	.0185		.0189	1.1203	.7621
8	.0187	.0191	.0187		.0189	1.0456	.8383
9	2.4646	2.1338	2.6139		.0189	.0187	.0191
10	2.5873		2.6406		.0187	.0187	.0189
11	2.6139	2.4025				.0187	.0189
12	2.4272	2.4272	2.6029			.0191	.0189
13	2.2405		2.3765			.0191	.0189
14	.2241		2.4331		.0185	.0191	.0189
15	2.4025		2.4143		.0185	.0191	.0189
16	2.2177	2.4272	2.3577		.0187	.0191	.0189
17	.0185	2.2405			.0187	.0187	.0189
18	.0191	2.2405				.0191	.0189
19	.0191	.0187		.0189		.0191	.0189
20	.0191	.0187		.0189	.0187	.0191	
21	.0191	.0187		.0189	.0187	.0191	
22	.0191	.0187		.7167		.0191	.0189
23	.0191	.0187	.0381	.679	.0187	.0191	.0189
24	.0187	.0191	.0187		.6413	.0187	.0191
Max	2.6139	2.4272	2.6406	.7167	.679	1.1203	.8383
Min	.0185	.0187	.0185	.0189	.0185	.0187	.0189
Avg	.7284	.7069	1.0380	.2905	.2221	.2949	.2199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 205 / Sarud-Shirgaon Village
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.112		.1698	.1307	.1524
2	.1334	.1143	.112		.1698	.1307	.1524
3	.1334	.1143	.112		.1698	.112	.1334
4	.1143	.1143	.1307		.1698	.1307	.1334
5	.1143	.1334	.1494		.1509	.1494	.1524
6	.1663	.1715	.168		.1509	.168	.1715
7	.1867	.1905	.1848		.1509	.168	.1905
8	.1867	.2286	.1848		.1886	.168	.1715
9	.1867	.2286			.1509	.2801	.1905
10	.1867	.2218	.1886		.1307	.1494	.1698
11	.168	.1867			.1307	.112	.1132
12	.1867	.1848	.1886		.1867	.1307	.1698
13	.1494	.1867	.2075		.1307	.1307	.1886
14	.1478	.1494	.1886		.168	.1307	.1698
15	.168	.1494	.1886		.1478	.1494	.1698
16	.1307	.168	.1886			.1494	.1698
17	.1294	.1867	.1886				.1698
18	.1524	.168		.2452		.2096	.1886
19	.2096	.2054		.2452	.2614	.2477	.2263
20	.3048	.2614		.3395	.2801	.3048	
21	.2477	.2402		.3395	.2427		
22	.2096	.2033		.2641		.2286	.2641
23	.1715	.1494		.2075	.168	.1905	.1886
24	.1494	.1334	.1307		.1886	.1307	.1715
Max	.3048	.2614	.2075	.3395	.2801	.3048	.2641
Min	.1143	.1143	.112	.2075	.1307	.112	.1132
Avg	.1695	.1752	.1640	.2735	.1753	.1683	.1731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 206 / Sarud-Salashi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2477	.1848		.7733	.9335	.6859
2	.2477	.2477	.2054		.7545	.9896	.6478
3	.2477	.2477	.2054		.7733	.9795	.6478
4	.2858	.2477	.2033		.811	1.0719	.724
5	.2801	.2667	.2218		.8299	1.1949	.8383
6	.2801	.2858	.2427		.2263	1.6078	.9145
7	.2801	.2858	.2987		.2263	1.5123	.9907
8	.2801	.2477	.2587		.2263	1.2323	.9145
9	3.1927	3.0483			.1886	.1867	.1143
10	2.8753	2.6242	3.0178		.2054	.2054	
11	2.6513	2.4272			.2054	.2096	.2263
12	2.4086	2.4025	2.6595		.1494		.2263
13	2.4272		2.5652				.1886
14	2.3339		2.3577			.2241	.3018
15	2.3899		2.3011			.2241	.2452
16	2.0883	2.4272	2.2068		.1494	.2241	.2829
17	.2587	2.1845	.2641		.2054	.2241	1.1317
18	.2858	1.9418		.2263	.2033	.2477	.2263
19	.2667	.2427		.2263		.2667	.2829
20	.2858	.2427		.2641	.2241	.2667	
21	.2667	.2427		.2641	.2241		
22	.2858	.2427		.9619		.1143	.2829
23	.2667	.2218		.9054	.2054	.1143	.2641
24	.2229	.2477	.168		.7922	.2054	.1143
Max	3.1927	3.0483	3.0178	.9619	.8299	1.6078	1.1317
Min	.2229	.2218	.168	.2263	.1494	.1143	.1143
Avg	1.0273	.9797	1.0851	.4747	.3881	.5826	.4881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 207 / Sarud-Thergaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.0669			.0377	.0373	.0191
2	1.1203	1.0288			.0377	.0373	.0191
3	1.1203	1.0288	.9335		.0377	.0373	.0191
4	1.0269	1.0288	1.0269		.0377	.0373	.0191
5	1.1271	1.105	1.1203		.0377	.0373	.0191
6	1.251	1.2574			.0377	.0373	.0191
7	1.1088	1.1431	1.2012		.0377	.0373	.0191
8	.056	.0572	.056		.0377	.056	.0191
9	.056	.0572			1.358	1.6057	
10	.056	.056	.0754		1.6057	1.8671	.7545
11	.0373	.056			1.6632	1.9044	.7167
12	.0373	.056	.0566			1.7737	.6602
13	.0373	.0554	.0566		1.6804	1.7737	1.358
14	.0373	.056	.0566		1.6244	1.7364	1.4712
15	.037	.056	.0566		1.587	1.6804	1.5089
16	.0373	.056	.0566		1.5123	1.6244	1.4712
17	.037	.056	.0566		.037	.0373	.0566
18	.0572	.0554		.0566	.037	.0953	.0566
19	.0572	.0554		.0566	.0373	.0572	.0566
20	.0572	.056		.0566	.0373		
21	.0572	.0739		.0566	.0373		
22	1.2193	1.2012		.0566		.0191	.0566
23	1.1431	1.1763		.0377	.0373	.0191	.0566
24	1.1203	1.105			.0377	.0373	.0191
Max	1.251	1.2574	1.2012	.0566	1.6804	1.9044	1.5089
Min	.037	.0554	.056	.0377	.037	.0191	.0191
Avg	.5006	.4977	.3961	.0535	.5270	.6613	.3998

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 208 / 11 KV Bhadale LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.0187	.0373	.0189	.0187	
4		.0187	.0373	.0189	.0187	
5		.0185		.0189	.0187	
6		.0187		.0189	.0187	
7		.2587		.2401	.2614	
8		.2614		.2641	.2614	
9		.2614		.2641	.2614	
10		.2641		.2772	.2614	.0754
11	.2801			.2587	.2614	.0189
12	.2801	.2641		.2587	.2614	.2641
13	.2801	.2641		.2427	.2614	.2641
14	.2801	.2641		.2614	.2614	.2641
15	.2801	.2641		.2587	.2614	.2641
16	.2772	.2641		.2587	.2614	.2641
17	.2801	.2641		.2587	.2614	.2641
18	.2587		.0189	.2587	.2858	.2641
Max	.2801	.2641	.0373	.2772	.2858	.2641
Min	.2587	.0185	.0189	.0189	.0187	.0189
Avg	.2771	.1932	.0312	.1986	.2023	.2159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 209 / Sarud-Nerle Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4003	1.2193			.0377	.0373	.0381
2	1.307	1.1431			.0377	.0373	.0381
3	1.2136	1.1431	1.1203		.0377	.0373	.0381
4	1.1203	1.1431	1.1949		.0377	.0373	.0381
5	1.2136	1.1431	1.2696		.0377	.0373	.0381
6	1.4003	1.4098			.0377	.0373	.0381
7	1.4003	1.3717	1.1643		.0377	.0373	.0381
8	.0373	.0381	.0373		.0377	.0373	.0381
9	.0373	.0381	.0373		1.8107	2.0725	
10		.037	.0377		1.9231	2.5766	2.0182
11	.0373	.0373			2.0538	2.5579	2.1313
12	.0373	.0373			2.1285	2.4832	1.9993
13	.0373	.0373	.0377		2.1098	2.4272	1.9805
14	.0373	.0373	.0377		2.0883	2.3339	1.8296
15	.037	.0373	.0377		2.0165	2.0538	1.8484
16	.037	.0373	.0377		1.9791	2.0538	1.8107
17	.037	.0373	.0377		.037	.0373	.0377
18	.0381	.037			.0373	.0381	.0377
19	.0381	.0373		.0377		.0381	.0377
20	.0381	.0373		.0377	.0373	.0381	
21	.0381	.0373		.0377	.037	.0381	
22	1.448			.0377		.0381	.0377
23	1.3717	1.3817		.0377	.0373	.0381	.0377
24	1.4003	1.3336			.0377	.0373	.0381
Max	1.448	1.4098	1.2696	.0377	2.1285	2.5766	2.1313
Min	.037	.037	.0373	.0377	.037	.0373	.0377
Avg	.5984	.5136	.4208	.0377	.7561	.7984	.6738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144077 / 33/11 Kv Manjare

Feeder No / Name : 202 / Manjare-Vishalgad
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17
HR	Load (MW)
24	.2263
Max	.2263
Min	.2263
Avg	.2263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144077 / 33/11 Kv Manjare

Feeder No / Name : 203 / Manjare- Anuskura Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144077 / 33/11 Kv Manjare

Feeder No / Name : 401 / 33 Kv Gelawade Generation NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	.7842
Max	.7842
Min	.7842
Avg	.7842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 201 / 11 Kv Warul-Amba

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.6099			.5788	.5601	.6036
2	.4031	.4854			.4481	.4854	.567
3	.3898	.3734			.3921	.4527	.5609
4		.3734			.3696	.4572	.5853
5	.4031	.4251			.5601	.4954	.6154
6	.4334	.5359			.5914	.5041	.6201
7	.5316	.6283			.695	.5544	.6379
8	.6661	.7762			.7392	.5914	.6767
9		.7207	.8413		.7865	.6805	.8413
10	.6584	.7023	.7964		.8413	.6935	.7316
11	.6219	.7362	.724		.8402	.2195	.7316
12	.4572	.6415	.7059		.8413		.7682
13	.3658	.463	.5853	.6161	.4908	.6154	.7682
14	.4207	.5721	.6653	.6653	.5959	.6935	.6556
15	.4207		.7392	.7964	.5487	.3856	.6379
16	.4668	.7373	.8048	.5731			
17	.4435	.8779		.4854	.5731	.8048	.6154
18	.8779	.8413		.5544	.6036	.815	.6584
19	.9425	.8779		.3547	.7762		.6661
20	1.0425			.8871	1.0082		.9145
21	.924			1.0425	.9758		.8413
22	.9335	.8048		.961	.8962	.9328	.7164
23	.7392	.6401		.985	.7095		.6135
24	.4904	.7207			.8589	.5975	.6584
Max	1.0425	.8779	.8413	1.0425	1.0082	.9328	.9145
Min	.3658	.3734	.5853	.3547	.3696	.2195	.5609
Avg	.5929	.6449	.7328	.7201	.6835	.5855	.6820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 202 / 11 Kv Warul -Yelur
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5959	.6325	.7042
2					.5784	.6325	.7122
3					.631	.6325	.7202
4					.6661	.6241	.7377
5					.0187	.6642	.823
6						.7362	.8718
7						.7499	.9389
8		.0187			.0187	.7499	1.0174
9	1.8991	1.8778	1.8884		.0187	.0183	.0335
10	1.8778	2.2211	1.9393			.0183	
11		2.0687	1.9559			.0183	
12	1.95	2.0856	1.8275			.0183	
13	1.7436		1.757			.0183	
14			1.7269			.0183	
15	1.7101		1.56			.0183	
16	1.4251	1.6787	1.4586	.4801	.0358		
17		1.6956		.3814	.0179		
18	.0187	1.6617		.3814	.0183		
19					.0185		
20	.0187			.0187	.0183		
21	.0187			.0187	.0183		
22				.6516	.0187		
23				.6099	.0183		
24	.0166	.0189			.5721	.0183	
Max	1.95	2.2211	1.9559	.6516	.6661	.7499	1.0174
Min	.0166	.0187	1.4586	.0187	.0179	.0183	.0335
Avg	1.0678	1.4808	1.7642	.3631	.2040	.3480	.7288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 203 / 11Kv Warul- Bhendavade
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8309	.5426				
2	.7537	.463				
3	.763	.4334				
4	.7223	.4681				
5	.8215	.4973				
6	.8309	.5316				
7	.8309	.5658				
9					.9835	
10					1.1736	1.0852
11				1.1488	1.1603	1.0898
12				1.153	1.0682	1.2378
13					1.1401	.9054
14					1.1568	.9556
15			.4024	.9054	1.0059	.8987
16				.9221		
22	.5596					
23	.503					
24	1.0227	.4917				
Max	1.0227	.5658	.4024	1.153	1.1736	1.2378
Min	.503	.4334	.4024	.9054	.9835	.8987
Avg	.7639	.4992	.4024	1.0323	1.0983	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 401 / 33 Kv Kadavi Generation NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.631	
5			.6379	.7282
6			.691	.7133
7			.6836	.691
8			.7442	
9		.7522	.7362	
10		.7362		
11		.7362	.691	
12		.7842	.6762	
13		.7842	.6836	
14		.7442	.6762	
15		.7442	.6836	
16		.7442		
17		.631	.6379	
18		.631		
19		.691	.7059	
20		.6836		
21		.691		
22			.7133	
23			2.2965	
24	.1052			
Max	.1052	.7842	2.2965	.7282
Min	.1052	.631	.631	.691
Avg	.1052	.7195	.7925	.7108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 201 / Turukwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0576				.4706	.4298
2	1.0402				.5068	.4344
3	1.0402				.5014	.4163
4	1.0402				.5014	.4163
5	1.0692				.5014	.4656
6	1.0867				.5249	.6089
7	1.3256				.5784	.7522
8					.5375	.8505
9	1.7718	2.0195	2.3243			
10	1.7337	1.829	2.4577	.5201		
11	1.7528	1.7718	2.5911	.6661		
12	1.6766		2.5149	.7282		
13	1.5623		2.4387	.7802		
14	1.3908		2.3815	.7282		
15	1.5242		2.4387	.6935		
16		1.0456	2.21	.6588		
17		1.0829				
18		1.2574				
24	1.1694					
Max	1.7718	2.0195	2.5911	.7802	.5784	.8505
Min	1.0402	1.0456	2.21	.5201	.4706	.4163
Avg	1.3494	1.5010	2.4196	.6822	.5153	.5468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 202 / 11 KV Thawade - Udagiri Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774	.2896	.3077	.1063	.1402	.1629	.1612
2	.2774	.2896	.2896	.0886	.1402	.1448	.1448
3	.2774	.2896	.2896	.0886	.1402	.1433	.1448
4	.2774	.2715	.2926	.0876	.1402	.1433	.1448
5	.3155	.2715	.3109	.1052	.1433	.1433	.1612
6	.3506	.3326	.3292	.1227	.1494	.1629	.197
7	.4294	.4344			.1478	.1753	.2328
8	.4207	.4706	.443	.1227	.1753	.1907	.3012
9	.4382	.5144	.4954	.1372	.2454	.2103	.3544
10	.4763	.5335	.5335	.1387		.2401	.3366
11	.4572	.4763	.4382		.208	.2254	.3294
12	.4572	.3768	.4572		.1886	.2254	.2743
13	.4382						.2743
14	.4001						.3121
15	.4382						.3294
16		.4668	.4954		.2515		.2743
17		.4481				.2883	.3052
18		.5144		.2134	.218	.2883	.3391
19		.4207		.4161	.2774	.3506	.3898
20			.1991	.4481	.3658	.3734	.439
21	.4435	.4805	.2534	.3734	.3174	.3206	
22	.4435	.4527	.1848	.2427	.2452	.2829	
23	.4066	.3881	.1448	.1867	.2033	.2241	.3292
24	.3012	.3077	.3258	.1075	.1463	.1478	.1646
Max	.4763	.5335	.5335	.4481	.3658	.3734	.439
Min	.2774	.2715	.1448	.0876	.1402	.1433	.1448
Avg	.3856	.4015	.3406	.1866	.2023	.2222	.2700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 203 / 11 KV Kandavan Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1734	.2172	.2353	.124	.1753	.2172	.2328
2	.1734	.2172	.2172	.124	.1753	.1991	.2172
3	.1734	.2172	.2172	.1063	.1753	.197	.2172
4	.1734	.1991	.2195	.1052	.1753	.197	.2172
5	.2103	.1991	.2378	.1052	.1791	.197	.2149
6	.2629	.2957	.2926	.1402	.2987	.3077	.2865
7	.3174	.3439	.3292	.1715	.3142	.298	.3224
8	.298	.362	.3366	.1928	.333	.3121	.3189
9	.3429	.2858	.381	.2058	.333	.298	.3189
10	.3048	.362	.3239		.3086		.3012
11	.3239	.381	.3239	.2629	.3121	.2601	
12	.3048	.2949	.3239	.3467	.2743		
13	.2667	.2984	.2477	.3814	.3149	.3185	
14	.2858	.2984	.2286	.3294	.2713	.3086	
15	.2858		.2286	.0693	.3185	.3258	
16		.4108		.0693	.3353		
17		.4108			.3239	.3391	
18		.4382			.3353	.373	
19		.4733		.4334	.3814	.3856	.4961
20		.5853		.5601	.5304	.5415	
21	.4435	.4435		.4668	.4854	.4338	
22	.4435	.3961	.0739	.4294	.415	.3961	
23	.3326	.2772	.1448	.3174	.3142	.3174	.3658
24	.1772	.2353	.2534	.1254	.2378	.2587	.2561
Max	.4435	.5853	.381	.5601	.5304	.5415	.4961
Min	.1734	.1991	.0739	.0693	.1753	.197	.2149
Avg	.2786	.3323	.2564	.2413	.3049	.3086	.2896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 201 / Sh-R- Panhala Hill Station

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1334	.1524	.1524	.1334	.1334	.1334
2	.1715	.1334	.1524	.1524	.1334	.1334	.1334
3	.1715	.1334	.1524	.1524	.1334	.1334	.1334
4	.1715	.1334	.1524	.1524	.1524	.1334	.1334
5	.1715	.1334	.1524	.1524	.1524	.1334	.1524
6	.2286	.1715	.1905	.1905	.1524	.1334	.1905
7	.2286		.1905	.1905	.1524	.1905	.2096
8	.2096	.2096	.1905	.1905	.1905	.1715	.1905
9	.1905	.1905	.1905	.1905	.1905	.1905	.1905
10	.1905	.1715	.1905	.1905	.1905	.1905	.1524
11	.1715	.1905	.1905	.1905	.1905	.1715	.1524
12	.1905	.1905	.1905	.1905	.1905	.1524	.1524
13	.2096	.1905	.2096	.1905	.2096	.1715	.1524
14	.2096	.2286	.2096		.1905	.1905	.1905
15	.2096	.2286	.2096	.1905	.2096	.1905	.1905
16	.2286	.2096	.1905	.1905	.1905	.1905	.1905
17	.1905	.1905	.1905	.1905	.1905	.1905	.2286
18	.1905	.1905		.1905	.1334	.1905	.2286
19	.2096	.2286	.2477	.1905	.1715	.2096	.2667
20	.2667	.2667	.2667	.2667	.2096		.2667
21	.2477	.2667	.2477	.2667	.2286	.2477	.2667
22	.2477	.2477	.2286	.2667	.2286	.2286	
23	.1905	.2286	.1905	.1905	.2096	.2096	.1905
24	.2096	.1524	.1905	.1524	.1524	.1715	.1715
Max	.2667	.2667	.2667	.2667	.2286	.2477	.2667
Min	.1715	.1334	.1524	.1524	.1334	.1334	.1334
Avg	.2032	.1922	.1947	.1905	.1786	.1764	.1855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 202 / SH-R- 11 KV WAGHAWE
GAVTHAN Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1524	.1715	.1905	.1524	.1524
2	.1334	.1334	.1524	.1715	.1905	.1524	.1524
3	.1334	.1334	.1524	.1715	.1905	.1524	.1524
4	.1334	.1334	.1524	.1715	.1905	.1524	.1524
5	.1524	.1334	.1905	.1905	.2286	.1524	.1524
6	.1905	.2286	.2286	.2858	.2667	.1524	.2096
7	.2286		.2667	.2477	.2286	.2477	.2286
8	.2096	.2477	.2858	.2477	.2667	.2477	.2286
9	.2096	.1905	.3048	.1905	.2286	.2477	.2477
10	.2477	.2286	.2858	.2286	.2667	.2096	.3048
11	.2477	.2286	.3048	.2286	.2477	.3048	.3048
12	.2477	.2286	.2858	.2286	.2286	.3048	.1905
13	.2477	.1905	.2667	.2286	.3048	.3048	.1905
14	.2286	.1524	.2667		.2858	.3239	.2477
15	.2286	.1905	.2858	.2667	.3048	.3239	.2286
16	.2477	.2286	.2667	.3429	.2286	.2477	.2286
17	.2286	.2477	.2858	.2667	.2286	.3048	.2286
18	.2286	.2477		.2286	.1334	.3048	.1905
19	.2286	.3048	.2858	.2667	.2096	.2667	.381
20	.2858	.3429	.3048	.3048	.3239		.3429
21	.2667	.2667	.2858	.3048	.381	.3048	.3048
22	.3048	.3048	.2477	.2667	.362	.2477	
23	.2286	.2667	.2286	.2667	.3239	.2096	.2286
24	.1524	.1334	.2286	.1905	.2286	.2096	.1715
Max	.3048	.3429	.3048	.3429	.381	.3239	.381
Min	.1334	.1334	.1524	.1715	.1334	.1524	.1524
Avg	.2143	.2129	.2485	.2377	.2516	.2402	.2270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 203 / 11 KV NAVALI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4191	.4572	.3429	.4572	.0381	.4191
2	.4572	.4191	.4572	.3429	.4572	.0381	.4191
3	.4572	.4191	.4572	.3429	.4572	.0381	.4191
4	.4572	.4191	.4572	.3429	.4572	.0381	.4191
5	.4572	.4191	.4954	.381	.4572	.0381	.4572
6	.5335	.5525	.5716	.4572	.6097	.0381	.5335
7	.5335		.5335	.4572	.6097	.0572	.5716
8	.5335	.6287	.4954	.4572	.6478	.0381	.6097
9	.4954	.5716	.5716	.4572	.6097	.0191	.6097
10	.6097	.6478	.6287	.5716	.6668	.0381	.6859
11	.6287	.6478	.6859	.6097	.6668	.0191	.6859
12	.5144	.6478	.5716	.6478	.6478	.0381	.6859
13	.5525	.5716	.4954	.6097	.6478	.5335	.5716
14	.5906	.5716	.5335		.6859	.6097	.6097
15	.6668	.5716	.6097	.6478	.6287	.6859	.6859
16	.724	.6859	.6097	.724	.724	.7621	.6859
17	.724	.4954	.5716	.6478	.6287	.7621	.724
18	.8002	.4572		.5716		.6859	.4572
19	.8764	.8764		.5716		.6478	.7621
20	.9335	.9907	.8383				.9145
21	.8383	.8383	.6478	.9145		.7621	.8764
22	.724	.8002	.5335	.7621	.0572	.6859	
23	.5716	.6097	.4191	.6478	.0572	.5335	.6097
24	.4954	.4763	.5335	.381	.5335	.0381	.4572
Max	.9335	.9907	.8383	.9145	.724	.7621	.9145
Min	.4572	.4191	.4191	.3429	.0572	.0191	.4191
Avg	.6097	.5972	.5534	.5404	.5354	.3106	.6030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 204 / 11 KV MITHARWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1143	.1143	.1524	.5335	.1143
2	.1524	.1524	.1524	.1143	.1524	.5335	.1143
3	.1524	.1524	.1524	.1143	.1524	.5335	.1143
4	.1524	.1524	.1524	.1143	.1524	.5335	.1143
5	.1524	.1524	.1524	.1334	.1524	.5335	.1334
6	.2096	.1905	.1905	.1715	.1905	.5335	.2096
7	.2286		.1905	.1905	.1905	.7621	.2286
8	.2096	.2858	.1905	.2096	.2286	.7621	.2477
9	.1524	.1524	.1905	.1715	.1905	.7621	.2096
10	.1524	.2286	.1524	.1524	.1334	.9526	.1905
11	.1524	.1905	.1524	.1524	.1143	.9145	.1905
12	.1905	.1905	.1334	.1524	.1334	.8764	.1905
13	.1715	.1905	.1334	.1524	.1715	.1524	.2286
14	.1715	.1905	.1524		.1715	.1524	.2477
15	.2096	.2477	.1715	.1905	.1715	.1524	.2667
16	.1905	.2477	.1715	.1905	.2096	.1715	.2667
17	.2286	.2477	.1715	.1905	.2096	.1905	.1524
18	.2286	.2286		.2096		.2667	.2286
19	.2667	.2667		.2286	.1905	.2667	.3048
20	.3048	.3048	.2286	.2667	.2286		.381
21	.2286	.2286	.2286	.2667	.1524	.1334	.2667
22	.2477	.1905	.2096	.2286	1.0479	.1334	
23	.1905	.1524	.1334	.1905	.9526	.1715	.1905
24	.1715	.1715	.1143	.1143	.1524	.6668	.1334
Max	.3048	.3048	.2286	.2667	1.0479	.9526	.381
Min	.1524	.1524	.1143	.1143	.1143	.1334	.1143
Avg	.1945	.2029	.1654	.1748	.2435	.4647	.2054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 205 / 11 KV INJOLE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.1524	.1334	.1143	.1334	.1143
2	.1524	.1334	.1524	.1334	.1143	.1334	.1143
3	.1524	.1334	.1524	.1334	.1143	.1334	.1143
4	.1524	.1334	.1524	.1334	.1143	.1334	.1143
5	.1715	.1334	.1524	.1334	.1524	.1334	.1143
6	.2477	.2096	.2286	.1715	.1905	.1334	.1524
7	.2286		.2286	.1905	.2096	.2096	.2096
8	.2286	.2286	.2286	.1715	.1905	.2096	.1905
9	.2096	.2286	.2096	.1524	.2286	.1905	.1905
10	.2477	.2286	.2286	.1905	.2477	.1905	.1524
11	.2286	.2286	.1905	.1905	.2286	.2096	.1524
12	.1905	.2286	.2096	.1524	.2286	.2096	.1524
13	.1715	.1905	.1905	.1524	.2286	.2286	.1524
14	.1905	.1905	.2096		.2096	.2667	.1524
15	.2096	.2286	.2096	.1905	.1905	.2477	.1524
16	.2096	.2286	.1905	.2286	.2477	.2096	.1524
17	.2286	.1524	.2096	.2286	.2667	.2096	.1524
18	.2477	.1905		.1905		.2096	.1524
19	.2858	.2858		.2286	.2286	.2667	.2286
20	.3239	.3239	.2096	.2286	.3048		.2667
21	.3048	.3048	.1905	.1905	.3239	.2286	.2286
22	.2667	.2667	.1905	.1905	.2286	.1905	
23	.1905	.2286	.1524	.1524	.2286	.1524	.1905
24	.1715	.1524	.1905	.1334	.1524	.1715	.1334
Max	.3239	.3239	.2286	.2286	.3239	.2667	.2667
Min	.1524	.1334	.1524	.1334	.1143	.1334	.1143
Avg	.2151	.2071	.1922	.1740	.2062	.1914	.1623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 206 / 11kv Broadcast Express NON SHEDDABLE EXPRESS HV FEEDERS
 feeder Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0381	.0572	.0572
2	.0572	.0572	.0572	.0572	.0381	.0572	.0572
3	.0572	.0572	.0572	.0572	.0381	.0572	.0572
4	.0572	.0572	.0572	.0572	.0381	.0572	.0572
5	.0572	.0572	.0572	.0572	.0572	.0572	.0572
6	.0572	.0572	.0572	.0572	.0572	.0572	.0572
7	.0572		.0572	.0572	.0572	.0572	.0191
8	.0572	.0572	.0572	.0572	.0572	.0572	.0191
9	.0572	.0572	.0572	.0572	.0572	.0762	.0191
10	.0572	.0572	.0572	.0572	.0572	.0572	.0572
11	.0572	.0572	.0572	.0572	.0762	.0762	.0572
12	.0762	.0572	.0572	.0572	.0762	.0762	.0572
13	.0762	.0572	.0572	.0572	.0572	.0762	.0572
14	.0762	.0572	.0572		.0572	.0762	.0572
15	.0762	.0572	.0572	.0572	.0572	.0572	.0572
16	.0572	.0572	.0572	.0572	.0572	.0572	.0572
17	.0572	.0572	.0572	.0572	.0572	.0572	.0572
18	.0572	.0572		.0572	.0572	.0572	.0572
19	.0572	.0572	.0572	.0572	.0572	.0572	.0762
20	.0191	.0572	.0572	.0572	.0572		.0762
21	.0572	.0572	.0572	.0572	.0572	.0572	.0572
22	.0572	.0572	.0572	.0572	.0572	.0572	
23	.0572	.0572	.0572	.0572	.0572	.0572	.0572
24	.0572	.0572	.0572	.4191	.0572	.0572	.0572
Max	.0762	.0572	.0572	.4191	.0762	.0762	.0762
Min	.0191	.0572	.0572	.0572	.0381	.0572	.0191
Avg	.0588	.0572	.0572	.0729	.0556	.0613	.0539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 207 / 11Kv Mitharwadi Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.5792	.1524	.1524	.1524	.1334	.1334
2	.1524	.5792	.1524	.1524	.1524	.1334	.1334
3	.1524	.5792	.7621	.1524	.1524	.1334	.1334
4	.1524	.5792	.7621	.1524	.1524	.1334	.1334
5	.1524	.5792	.7621	.1524	.1524	.1334	.1524
6	.2096	.6706	.2286	.1524	.1524	.1334	.2286
7	.2667		.7621	.0381	.1524	.2286	.2286
8	.2286	.4268	.2286	.0381	.2286	.2286	.2477
9	.2286	.2286	.1905	.3048	.4268	.7621	.7621
10	.2286	.1905	.2286	.381	.6097	.7545	.9145
11	.2286		.1524	.381	.6097	.6173	.9145
12	.1905		.1524	.381	.6097	.6859	.9145
13	.1905		.1905	.4572	.5487	.6859	.7621
14	.1905		.1905		.5487	.6173	.7621
15	.1905	.0191	.2286	.5335	.5944	.5144	.7621
16	.1524	.2286	.2286	.5335	.6097	.583	.7621
17	.2286	.2286	.1905	.2286	.1905	.1905	.2286
18	.2286	.2286		.2286	.1524	.2286	.1524
19	.2286	.2096	.1905	.2286	.1715	.2286	.1715
20	.2286	.2096	.1524	.2286	.1715		.2286
21	.2286	.2286	.1905	.2286	.1905	.1905	.1905
22	.6097	1.0669		.2286	.1905	.1905	
23	.6097	.9907	.1753	.2286	.1905	.1524	.1905
24	.1524	.7621	.1524	.1905	.1524	.1334	.1524
Max	.6097	1.0669	.7621	.5335	.6097	.7621	.9145
Min	.1524	.0191	.1524	.0381	.1524	.1334	.1334
Avg	.2326	.4518	.2920	.2501	.3026	.3388	.4026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 208 / Waghawe Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	1.3717	.0191	.1524	.381	.0191	.0191
2	.0191	1.3717	.0191	.1524	.381	.0191	.0191
3	.0191	1.3717	1.6004	.1524	.381	.0191	.0191
4	.0191	1.3717	1.6004	.1524	.381	.0191	.0191
5	.0191	1.3717	1.6004	.1524	.4572	.0191	.0191
6	.0191	1.3717	.0191	.1524	.0191	.0191	.0191
7	.0191		1.7147	.0191	.0191	.0191	.0191
8	.0191	1.1888	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	1.0059	.503	.4572
10	.0191	.0191	.0191	.0191	1.1888	.5316	.4572
11	.0191	.0191	.0191	.0191	1.0974	.5487	.4572
12	.0191	.0191	.0191	.0191	1.0974	.4115	.4572
13	.0191	.0191	.0191	.0191	.9145	.4115	.3429
14	.0191	.0191	.0191		.9145	.3429	.3429
15	.0191	.0191	.0191		.9145	.3429	.4572
16	.0191	.0191	.0191	.0191	.884	.3601	.4572
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191		.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191		.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	1.7528	2.1719	.2172	.5716	.0191	.0191	
23	1.5242	2.1338	.1448	.4572	.0191	.0191	.0191
24	.0191	1.3717	.0191	.1524	.4572	.0191	.0191
Max	1.7528	2.1719	1.7147	.5716	1.1888	.5487	.4572
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1541	.6672	.3132	.1065	.4436	.1626	.1615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 209 / 11KV INJOLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429				.3048	
2	.3429				.3048	
3	.3429				.3048	
4	.3429				.3048	
5	.3429				.3048	
6	.3429				.3048	.0381
7	.3429				.381	.0572
8					.2932	.0572
9	.3963	.5716	.6516	.4572		
10	.4572	.6097	.6001	.4954		
11	.4877	.5716	.583	.4954		.3048
12	.503	.5716	.583	.4191		
13	.503		.583	.4572		
14	.503		.583			
15	.503		.583	.4191		
16	.5335	.5716		.4954		
17		.5716				
18		.5716				
24	.3429					
Max	.5335	.6097	.6516	.4954	.381	.3048
Min	.3429	.5716	.583	.4191	.2932	.0381
Avg	.4144	.5770	.5952	.4627	.3129	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 201 / 11 KV DIGAWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.132	.0857	.0686	.1698	.1029	.1132
2	.1029	.132	.0857	.0686	.1509	.1029	.0943
3	.1029	.132	.0857	.0686	.1509	.1029	.0943
4	.1029	.132	.1372	.1029	.1494	.1029	.1132
5	.12	.1509	.1715	.1715	.168	.1029	.1494
6	.124	.1663	.1715	.1886	.1478	.12	.1478
7	.1372	.1848	.1715	.1715	.1433	.1543	.1612
8	.1372	.1646	.1715	.1543	.1433	.1543	.1417
9	.1029	.124	.1715	.1543	.12	.12	.1417
10	.12	.12	.1387	.1543	.1372	.1341	.12
11	.12	.1372	.1174	.1543	.1372	.1174	.12
12	.12	.1372	.1311	.1372	.1372	.1006	.1029
13	.12	.1372	.1326	.1543	.1372	.1017	.1029
14	.12	.1372	.0995	.1543	.12	.1017	.1029
15	.12	.12	.116	.1372	.1372	.1372	.1029
16	.1543	.1372	.1326	.1715	.1715	.1543	.1029
17	.1543	.1372		.1543	.1715	.1543	.12
18	.1715	.1715			.2229	.1578	.1715
19	.2126	.1715		.2058	.2229	.1791	.1715
20	.2149	.1715	.2058	.2149	.2058		.1715
21	.2149	.1715	.2058	.2033	.1886	.2033	.1715
22	.1867	.1829	.1715	.1829	.1715	.1848	
23	.1494	.12	.1372	.1663	.1543	.1494	.1372
24	.1132	.132	.12	.0857	.168	.1372	.1132
Max	.2149	.1848	.2058	.2149	.2229	.2033	.1715
Min	.1029	.12	.0857	.0686	.12	.1006	.0943
Avg	.1385	.1459	.1410	.1489	.1594	.1337	.1290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 202 / 11 KV ALAWE-KOTOLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0514	.0343	.2058	.1562	.0343	.0343
2	.0686	.0514	.0076	.1715	.1562	.0457	.0171
3	.0686	.0514	1.8861	.1372	.125	.0457	.0171
4	.0686	.0686	2.0576	.1029		.0457	.0171
5	.0686	.0686	2.0851	.0686		.0457	.0343
6	.0686	.1372	.0076	.0343		.0305	
7	.0686	.1372	1.3717	.0171		.0305	
8	.0343	.2058	.0343	.0171		.0305	
9	3.2407	.1886	.0343	.0171	.583	.503	.4534
10	2.8045	.2058	.0514	.0171	.7202		.5243
11	2.7435	.1543	.0503			.7773	.4287
12	2.6825	.1372	.0503		1.0117	.8097	.5487
13	2.3015		.0497	.0457	.1715	.9069	.5487
14	2.3167		.0671	.061	.1715	.8322	.5487
15	2.3167	.1372	.0663	.061		.7042	.5487
16	1.6309	.2058	.0663	.0762	1.1317	.8322	.5487
17	.1402	.2058		.0686	.7468		.0343
18	.1417	.2058			.0152	.0514	.0343
19	.1417	.2058			.0152		.0343
20	.1372	.2058			.0152		.0343
21	.1417	.2058		.0857	.0152	.0514	.0343
22	.1372	2.915	.3772	.2187	.0457	.0514	
23	.1372	2.9835	.3429	.2031	.0305	.0514	.0343
24	.1433	.0686	.0343	.2572	.1875	.0343	.0343
Max	3.2407	2.9835	2.0851	.2572	1.1317	.9069	.5487
Min	.0343	.0514	.0076	.0171	.0152	.0305	.0171
Avg	.9030	.3998	.4565	.0982	.3117	.2957	.2255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 203 / 11 KV GHOTWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1524	.1372	.0686	.132	.12	.0943
2	.1029	.1334	.1372	.0686	.1132	.1029	.0943
3	.1029	.1334	.1372	.0686	.1132	.1029	.0943
4	.1029	.1509	.1372	.1029	.1132	.1029	.0943
5	.1029	.1698	.1372	.12	.132	.12	.112
6	.1372	.1867	.1372	.1715	.168	.1543	.1663
7	.2058	.2241	.1372	.2058	.197	.1886	.1991
8	.2229	.2378	.2058	.2572	.197	.2229	.2686
9	.2058	.1791	.2401	.2572	.2401	.2401	.2507
10	.1372	.2279	.2103	.1886	.2401	.2321	.1886
11	.12	.1543	.1802	.1886	.2401	.208	.1715
12	.12	.1543	.1638	.1886	.2572	.1907	.1715
13	.0857	.1372	.1311	.2058	.1715	.1753	.0171
14	.0857		.1658	.2058	.1715	.1753	.2229
15	.0857	.1029	.1677	.1715	.1372	.1715	.0686
16	.0686	.12	.1658	.1715	.1372	.1886	.1372
17	.208	.1543		.1753	.1715	.2454	.2058
18	.2743	.2401			.2229	.2835	.2572
19	.3898	.2572		.2743	.3429	.3511	.3086
20	.3801	.3086	.2229	.3403	.2915		.3086
21	.3584	.2915	.2743	.3174	.2743	.2614	.3429
22	.2667	.2572	.2058	.2241	.2229	.2054	
23	.2096	.1715	.1372	.1494	.1886	.1509	.2058
24	.132	.1524	.1372	.1029	.132	.12	.0943
Max	.3898	.3086	.2743	.3403	.3429	.3511	.3429
Min	.0686	.1029	.1311	.0686	.1132	.1029	.0171
Avg	.1753	.1868	.1699	.1837	.1920	.1876	.1772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 204 / 11 kv Digavade Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0189	.0343	.1029	.0937	.0305	.0171
2	.0343	.0189	.0343	.0857	.0937	.0305	.0171
3	.0343	.0189	.8573	.0857	.0781	.0343	.0171
4	.0343	.0189	1.0288	.0686	.0781	.0343	.0171
5	.0343	.0377	.9717	.0686	.0781	.0305	.0171
6	.0343	.0377	.0343	.0171	.0343	.0305	
7	.0514	.0554	.9431	.0171	.0316	.0305	
8	.0343	.037	.0343	.0171	.032	.0457	
9	2.3663	.0537	.0343	.0171	.3601	.4877	.2241
10	2.0881	.0343	.0351	.0171	.463	.6316	.3429
11	2.1434	.0343	.037	.0171	.463	.6081	.3429
12	1.7985	.0514	.0366	.0171	.4801	.5441	.2401
13	1.768	.0686	.0358	.0305	.4287	.5601	.2229
14	1.7375	.0686	.0351	.0305	.463	.5441	.2058
15	1.6766	.0343	.0339	.0305	.4458	.5441	.1715
16	1.3413	.0343	.0339	.0457	.463	.5441	.1715
17	.0358	.0343		.0532	.0305	.0343	.0343
18	.0362	.0343			.0305	.0343	.0514
19	.0358	.0343		.0351	.0305	.0343	.0514
20	.0362	.0343	.0343	.0358	.0305		.0514
21	.0373	.0343	.0343	.0362	.0305	.0343	.0343
22	.0366	1.3032	.1886	.128	.0305	.0343	.0343
23	.0366	1.3375	.1715	.0937	.0305	.0343	.0343
24	.0358	.037	.0343	.1372	.0937	.0343	.0343
Max	2.3663	1.3375	1.0288	.1372	.4801	.6316	.3429
Min	.0343	.0189	.0339	.0171	.0305	.0305	.0171
Avg	.6459	.1447	.2230	.0516	.1831	.2161	.1111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 205 / 11 KV ALAVE-KOTOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2829	.2915	.1715	.2641	.2572	.2452
2	.2743	.2829	.2572	.1372	.2641	.2572	.2263
3	.2743	.2641	.2401	.1372	.2641	.2401	.2263
4	.2401	.2829	.2915	.1543	.2614	.2401	.2241
5	.2572	.3018	.3258	.1886	.2801	.2401	.2241
6	.2915	.3584	.3429	.2572	.3511	.2401	.2987
7	.3258	.3547	.3086	.2572	.3109	.2401	.3142
8	.3258	.3658	.3429	.2401	.3224	.2743	.3224
9	.3258	.3761	.3429	.2572	.3601	.3258	.3366
10	.3429	.3258	.3506	.3258	.3772	.3155	.3429
11	.3429	.3944	.3506		.3601	.3856	.3429
12	.3258	.3601	.3467		.3772	.3856	.2915
13	.3258	.3772	.3601	.4801	.4287	.3856	.3086
14	.3258	.3601	.333	.4801	.3086	.3681	.3258
15	.3429	.3772	.3506	.5316	.3086	.3155	.3429
16	.3601	.3944	.4031	.5316	.3601	.3856	
17	.3856	.4115		.4733	.4973	.4908	
18	.4252	.4458			.2401	.5194	
19	.4835	.4458		.4557	.3086	.5487	.5144
20	.5249	.4458		.5373	.3258		.5144
21	.499	.463	.3772	.499	.3772	.4805	.463
22	.4527	.3772	.3086	.3547	.4115	.3696	.3429
23	.3772	.3772	.2572	.2957	.3601	.2987	.3258
24	.3584	.3018	.3086	.2058	.2801	.2915	.2614
Max	.5249	.463	.4031	.5373	.4973	.5487	.5144
Min	.2401	.2641	.2401	.1372	.2401	.2401	.2241
Avg	.3540	.3636	.3245	.3320	.3333	.3416	.3235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 206 / 11 KV GHOTWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.7528			.5487	.4854
2	1.5432	1.6827			.5487	.4481
3	1.4575	1.5424			.5487	.4108
4	1.3717	1.5074			.5639	.3734
5	1.3889	1.5074			.5792	.3734
6	1.3717	1.7528			.7164	.4435
7	1.286	1.9806			.9945	.6036
8		2.6116			.7926	.591
9		2.6642	2.9835	.2572		
10		2.6063	2.8921	1.0802		
11		2.4348	2.489	.945		
12		2.4348	2.0508	1.2803		
13			2.0858	1.4022		
14			2.0332			
15			1.9982	1.3565		
16		2.3663	1.893	1.3108		
17		2.1262				
18		2.0576				
23	1.3321					
24	1.8427	1.8054				
Max	1.8427	2.6642	2.9835	1.4022	.9945	.6036
Min	1.286	1.5074	1.893	.2572	.5487	.3734
Avg	1.4749	2.0521	2.3032	1.0903	.6616	.4662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 201 / 11 kv M.Shiroli sheti fdr SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
23	.9145
24	1.2193
Max	1.2193
Min	.9145
Avg	1.0669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 202 / 11 kv Chande Sheti Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6673	2.915		1.7528	.0381	.0572	.0381
2	2.572	2.8578		1.7147	.0381	.0572	.0381
3	2.572	2.7244		1.7147	.0381	.0572	.0381
4	2.572	2.6673		1.6575	.0381	.0572	.0381
5	2.572	2.6673		1.5623	.0381	.0572	.0381
6	2.8578	3.1055		1.6956	.0381	.0572	
7	2.572	2.934		1.6766	.0572	.0572	.0572
8	.0572	.0572	1.6461	.0572	.0572	.0572	.0572
9	.0572	.0572		.0572	2.4768	3.0102	2.722
10	.0572	.0381		.0572	2.8197	2.9835	3.1626
11	.0572	.0381			2.7435		3.0483
12	.0572	.0381		.0572		3.0178	3.2579
13	.0572	.0381		.0381	2.7816	2.8635	3.1817
14	.0572	.0381		.0381	2.9912	2.9492	3.1436
15	.0572	.0381		.0572	2.934	2.8292	3.1245
16	.0572	.0381		.0572	2.8959	2.7435	3.1626
17	.0572	.0381		.0381	.0572	.0572	.0572
18	.0572	.0381		.0572	.0572	.0572	.0762
19	.0572	.0381		.0381		.0572	.0762
20	.0572	.0572		.0381	.0572		.0381
21	.0572	.0381	.0572	.0381	.0572	.0572	
22	3.2007		2.1338	.0381	.0572	.0572	
23	3.2579			.0381		.0572	
24	3.2769	3.0483		2.0005	.0381	.0572	.0572
Max	3.2769	3.1055	2.1338	2.0005	2.9912	3.0178	3.2579
Min	.0572	.0381	.0572	.0381	.0381	.0572	.0381
Avg	1.2051	1.0687	1.2790	.6296	.9671	.9661	1.2707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 203 / 11 Kv Kanchanwadi Sheti SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0381		.9526	.7049
2		.0381	.0381		.9526	.7621
3		.0381	.0381		.9526	.8383
4		.0381	.0381		.9526	.9145
5		.0381	.0381		1.0288	1.0288
6		.0381	.0381		.0381	1.3527
7	.0381	.0381	.0381		.0381	
8	.0381	.0381	.0381		.0572	1.467
9	2.572	2.934			.0572	.0381
10		2.4691			.0381	.0381
11	2.934	2.5892			.0381	.0381
12	3.0674	2.452				.0381
13	3.1055		2.9531		.0381	
14	2.8578			.8383	.0381	
15	2.7054		2.934		.0381	
16	2.5339	2.572	1.8671	1.9433	.0381	
17	.0381	2.1605		1.9433	.0381	
18	.0381	2.1605		1.0098	.0381	
19	.0381	.0381		.0572		
20	.0381	.0381		.0572	.0381	
21	.0381			.0572	.0381	
22	.0381	.0381		1.0669	.0381	
23	.0381	.0381		1.0098		
24	.7621	.0381	.0381		.9526	.0381
Max	3.1055	2.934	2.9531	1.9433	1.0288	1.467
Min	.0381	.0381	.0381	.0572	.0381	.0381
Avg	1.2283	.8916	.6748	.887	.3048	.6049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 204 / 11 KV Arale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.9717				
2	.8383	.8764				
3	.8383	.8192	.4287			
4	.8383	.7621	.4334			
5	.8954	.7811				
6	.9907	.9717				
7	.9145	.9145	.583			
9				1.0288	.8954	.8573
10				1.4098	1.2003	1.1431
11				1.2193	.9602	1.1431
12					1.0974	1.2193
13				1.0669	1.0288	1.1812
14				1.1431	1.0288	1.0669
15				1.0669	.9945	1.0669
16				1.0098	.9259	1.0098
22	1.1622	.7202				
23	1.1431	.7373				
24	.7621	1.0479				
Max	1.1622	1.0479	.583	1.4098	1.2003	1.2193
Min	.7621	.7202	.4287	1.0098	.8954	.8573
Avg	.9221	.8602	.4817	1.1349	1.0164	1.0860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 205 / 11 kv M. Shirolgi Gaothan
fdr Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2667		.2667	.2477	.2477	.2103
2	.2286	.2667	.2804	.2667	.2477	.2477	.2103
3	.2286	.2667	.2774	.2667	.2477	.2477	.2103
4	.2286	.2667	.2804	.3048	.2667	.2477	.2103
5	.2286	.3048	.3121	.3239	.3429	.2858	.2629
6	.381	.381	.3467	.4191	.381	.4191	
7	.381	.381	.3467	.381	.381	.4001	.3155
8	.381	.381	.2774	.381	.3429	.362	.2804
9	.2286	.3048		.3239	.3429	.3239	.3155
10	.2286	.2427		.3048	.3048	.2804	.3048
11	.2286	.2774		.3048	.3048	.2804	.3048
12	.2286	.2774		.3048	.3048	.2774	.3048
13		.2804	.3239	.3048	.3048	.2804	.3048
14	.2858	.2774		.3048	.3048	.2804	.3048
15	.2667	.2804	.362	.3048	.3048	.2947	.3429
16	.2667	.2774	.3048		.2667	.298	.3429
17	.3048	.2804			.2286	.298	.3429
18	.3048	.2774		.381	.4001	.3506	.3429
19	.381	.3467		.4572			.381
20	.4572	.4508		.4572	.4001		.4954
21	.4572	.4161	.5144	.4191	.381	.3856	
22	.4572	.3856	.381	.381	.362	.298	
23	.3239	.3506		.2858		.2454	
24	.7621	.2667	.2804	.2667	.2477	.2667	.2454
Max	.7621	.4508	.5144	.4572	.4001	.4191	.4954
Min	.2286	.2427	.2774	.2667	.2286	.2454	.2103
Avg	.3247	.3128	.3298	.3368	.3143	.3008	.3016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 206 / 11 Kv Chande Gavthan
Feeder Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334		.1524	.1143	.1524	.1052
2	.1524	.1334	.1402	.1524	.1143	.1334	.1052
3	.1524	.1334	.1402	.1524	.1143	.1334	.1052
4	.1524	.1334	.1402	.1524	.1143	.1334	.1052
5	.1524	.1334	.1928	.1524	.1524	.1334	.1227
6	.2096	.2477	.2427	.2858	.2286	.2286	
7	.2286	.2477	.2427	.2667	.2286	.2286	.2279
8	.2096	.1905	.1907	.2286	.2286	.1524	.2103
9	.2096	.1905		.2477	.2096		.208
10	.1715	.156			.1905	.1753	.1715
11	.1715	.1734			.1715		.1524
12	.1715					.2279	.1905
13			.1905		.1524	.1928	.2096
14	.1715	.2254			.1334	.208	.1905
15	.1715	.2103	.2096		.1334	.2427	.1905
16	.1524	.1734	.1715		.1715	.2103	.1905
17	.1524	.1928		.2477	.1715	.2254	.2096
18	.1715	.2254		.2286	.2096	.2629	.1905
19	.2096	.2254		.3048		.2454	.2286
20	.2477	.3294		.3048	.2858		.3048
21	.2667	.2774	.362	.2858	.2667	.2454	
22	.2096	.1928		.2477	.1905	.2279	
23	.1715	.156		.1334		.1402	
24	.7621	.1334	.1578	.1905	.1143	.1524	.1227
Max	.7621	.3294	.362	.3048	.2858	.2629	.3048
Min	.1524	.1334	.1402	.1334	.1143	.1334	.1052
Avg	.2096	.1916	.1984	.2197	.1760	.1930	.1771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 207 / 11 Kv Kanchanwadi Gavthan

GAOTHAN FEEDER

Feed Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667		.2858	.2858	.2667	.2279
2	.2477	.2667	.2629	.2858	.2858	.2667	.2279
3	.2477	.2667	.2629	.2858	.2858	.2667	.2279
4	.3048	.3048	.2629	.3429	.3048	.3048	.2279
5	.381	.381	.3467	.4382	.3429	.362	.3155
6	.5144	.5525	.5548	.5525	.4572	.5906	
7	.5144	.4572	.4508	.4572	.5144		.4508
8	.4191	.4382	.3814	.5144	.4572	.5144	.3856
9	.3429	.381		.4763	.381	.4382	.3467
10	.3429	.3641		.4572	.4191		.4382
11	.3429	.3641			.4001	.3681	.3429
12	.3048	.4161		.4382		.4681	.3429
13		.3681	.4572	.4382	.4382	.4382	.3429
14	.3429	.2947		.4382	.4001	.4207	.3429
15	.2858	.298	.4572	.3239	.4382	.3856	.3429
16	.3429						.362
17	.3429				.4191	.4207	.362
18	.362			.5144	.4572	.4733	.4572
19	.4572	.4334		.5906		.5083	.5335
20	.1905	.5895		.5716	.5335		.5906
21	.4572	.5028	.5716	.5525	.4572	.5083	
22	.4001	.4334	.4763	.4382	.4191	.3856	
23	.3239	.3121		.3239		.2804	
24	.3048	.2667	.298	.3239	.2858	.2858	.2279
Max	.5144	.5895	.5716	.5906	.5335	.5906	.5906
Min	.1905	.2667	.2629	.2858	.2858	.2667	.2279
Avg	.3487	.3789	.3986	.4309	.3991	.3977	.3548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 208 / 11 kv ARALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762		.0953	.0762	.0762	.0701
2	.0762	.0762	.0876	.0762	.0762	.0762	.0701
3	.0762	.0762	.0876	.0762	.0762	.0762	.0701
4	.0762	.0762	.0876	.0762	.0762	.0762	.0701
5	.0762	.0953	.0867	.1143	.0762	.0762	.0876
6	.1143	.1334	.104	.1524	.1143	.1143	
7	.1524	.1334	.1387		.1143	.1334	.1387
8	.1143	.1334	.104	.1524	.1143	.1143	.1227
9	.0762	.0953			.0953	.1143	.104
10	.0762	.0867			.0953	.1052	.1143
11	.0953	.0867			.1334	.0876	.1143
12	.0953	.0867					.1143
13		.1052	.1143				.0953
14	.0953	.104			.1334		.0953
15	.0762	.1052	.1143		.1334	.0867	.0953
16	.0762	.1052	.0953		.1524	.0867	.0953
17	.0953	.0867			.1143	.1052	.1143
18	.1334	.0876		.0953	.1334	.1052	.1143
19	.1715	.0867		.1524		.1227	.1334
20		.1387		.1524	.1524		.1715
21	.1524	.1387	.1715	.1334	.1524	.1402	.1524
22	.1334	.1227	.1334	.1143	.1143	.1052	.1143
23	.0953	.104		.0953		.0876	
24	.0762	.0762	.0876	.0953	.0762	.0762	.0701
Max	.1715	.1387	.1715	.1524	.1524	.1402	.1715
Min	.0762	.0762	.0867	.0762	.0762	.0762	.0701
Avg	.1005	.1007	.1087	.1130	.1105	.0983	.1058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 201 / 11 Kv Bachani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	04-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4527
2				.6036
3				.6036
4				.6036
5				.6036
6				.6036
7				.6036
8				.5853
9				.0191
10				.0191
11				.0191
13			.0171	.0191
14			.0171	.0191
15			.0171	.0191
16			.0171	.0191
17			.0189	.0187
18			.0189	.0183
19				.0366
20		.1372		.0366
21			.0189	.0362
22			.0189	.0362
23			.0189	.0362
24	.3963			.0189
Max	.3963	.1372	.0189	.6036
Min	.3963	.1372	.0171	.0183
Avg	.3963	.1372	.0181	.2187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 202 / 11 Kv Nandgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8351	2.3663		2.0243	.1372		.132
2	1.8896	2.332		1.9757	.1372		.112
3	1.8896	2.332	2.452	2.0388	.12		.1132
4	1.9334	2.2462	2.1026	2.0481	.12		.1132
5	1.989	2.1776	2.2634	2.0405	.12		.132
6	1.9662	2.1605		2.0972	.1372		
7	1.9662	2.2291	2.1125	2.1548	.1372		.1097
8	.1677	.1715	.1886	.1715	.2058		.1886
9	.1147	.1823		.1715	2.9447		
10	.1326	.1638		.1715	3.3008		
11	.1463				3.2301		
12	.1509		.1524	.1029	3.2442		
13	.1509		.1524	.1372	3.0933		
14	.1463			.1372	3.0178		
15	.1494		.1524	.1372	2.6749		1.7318
16	.1509	.0972		.1543	2.8669		1.6461
17	.1715	.1463		.1886	.1905		.0995
18	.2096	.1509		.1543	.1524	.7545	.1174
19	.1905	.1886	.1134	.1372			.1296
20	.1905	.2263	.1147	.1372			.1619
21	.1715	.2263	.1147	.1543		.1509	.1457
22	2.4691	2.6406	2.2611	.1543		.132	.1638
23	2.572	2.4897	2.2348	.1372		.1509	.1619
24	1.8945	2.3834		2.0972	.1372		.132
Max	2.572	2.6406	2.452	2.1548	3.3008	.7545	1.7318
Min	.1147	.0972	.1134	.1029	.12	.132	.0995
Avg	.9437	1.3111	1.1088	.8140	1.3667	.2971	.3171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 203 / 11 kv Ispurli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5893	1.9204		1.8656	.6859	.2477	.4527
2	1.5729	1.9204		1.8099	.6859	.1905	.3772
3	1.6632	1.869	2.2634	1.8665	.6859	.1715	.3772
4	1.7375	1.8004	2.2068	1.8656	.6859	.1715	.3772
5	1.829	1.7318	1.905	1.8642	.7202	.2096	.3961
6	2.0328	1.7833		1.8839	.7202	.2096	.415
7	2.0165	1.9033	2.2443	1.9418	.6859	.2667	.547
8	.8048	.6478	.7655	.4973	.6859	.3429	.6036
9	.7023	.8215		.583	3.1876		1.9204
10	.7499	.8413		.6859	3.3951	1.4575	2.0233
11	.7167	.7282		.583		1.9204	1.8347
12	.1509	.695	.6859	.583	2.1125	1.9547	1.7833
13	.6979	.6401	.6859	.583		1.749	1.6804
14	.6413	.6348		.5487	2.6406	1.7147	1.5604
15	.6584	.7133	.724	.5487	2.6406	1.6975	1.5775
16	.6516	.6878		.6516	2.6406	1.7147	1.6632
17	.724	.4108		.6344	1.989	.547	.2172
18	.743	.8048	.6036	.6859	.5716	.6219	.5068
19	.8764	.8962	.5792	.6516			.567
20	.7621	.8589	.6584	.6173			.5373
21	.8002	.8299	.6219	.6859	.381	.4527	.5973
22	2.1948	2.2634	2.1582	.7373	.3239	.4572	.6036
23	2.2634	2.0559	1.9753	.7202	.2667	.4854	.5792
24	1.5893	2.0405		1.9004	.6859	.2667	.4914
Max	2.2634	2.2634	2.2634	1.9418	3.3951	1.9547	2.0233
Min	.1509	.4108	.5792	.4973	.2667	.1715	.2172
Avg	1.1737	1.2291	1.2912	1.0414	1.3195	.8024	.9037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 204 / 11 Kv Bachani Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.5144	.4715	.4572	.4287		.4904
2	.4572	.4763	.4527	.4954	.4115	.2858	.4668
3	.4954	.4763	.4527	.4954	.4458	.2667	.4527
4	.5335	.4191	.4715	.5335	.463	.3239	.4904
5	.5335	.5335	.5093	.5716	.463	.362	.5281
6	.5906	.6287	.5658	.6097	.5316	.4001	.6602
7	.5716	.5906	.5729	.5335	.5144	.362	.567
8	.5335	.5716	.5304	.5335	.4801	.381	.5601
9	.4572	.4763		.4115	.4668	.6478	.4954
10	.4572	.4572		.4287	.4904		.4954
11	.4207			.4458	.4904	.3601	.4763
12	.4715	.4572	.5525	.463	.4904		
13	.4527	.4572	.5525	.463	.4904	.4115	.4763
14	.4527	.4954		.4458	.5093	.4458	.4572
15	.4715	.4572	.5335	.4458	.5093	.4287	.4954
16	.4854	.6478		.4801	.5281	.463	.5906
17	.5525	.547		.5144	.5716	.4904	.5906
18	.6287	.567	.6097	.5487	.6097	.4904	.6097
19	.6859	.6036	.5335	.6344			.6097
20	.7621	.7545	.7621	.6344			.7621
21	.6859	.6979	.6859	.6001		.6602	.724
22	.6668	.6036	.6097	.5144		.5601	.6859
23	.5906	.5093	.5335	.4801		.5121	.5716
24	.4763	.5144	.4904	.4763	.4458		.4904
Max	.7621	.7545	.7621	.6344	.6097	.6602	.7621
Min	.4207	.4191	.4527	.4115	.4115	.2667	.4527
Avg	.5363	.5416	.5495	.5090	.4916	.4362	.5542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 205 / 11 kv ispurli Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4191	.5281	.5335	.5144	.4954	.5281
2	.5144	.4001	.4904	.5525	.5144	.5144	.5281
3	.5335	.362	.5093	.5525	.5144	.5144	.4904
4	.5525	.381	.5658	.5716	.5144	.5716	.5281
5	.6097	.5906	.679	.6097	.5316	.6478	.6413
6	.743	.8192	.7167	.8764	.703	.8002	.7733
7	.6859	.6478	.7167	.8002	.6344	.6859	.6219
8	.5335	.6287	.6219	.6478	.5487	.6097	.5121
9	.4954	.6668		.6001	.5853	.5716	.5906
10	.5716	.5716		.6173	.5658	.5144	.5716
11	.4904			.5487	.7095	.5658	.5716
12	.4572	.4954	.8002	.4115	.5316	.5487	.5335
13	.4572	.5144	.8002	.4458		.5658	.5906
14	.4715	.5525		.5144	.679	.5487	.5525
15	.4904	.5525	.8002	.5144	.6979	.583	.6478
16	.5093	.6478		.583	.6516		.6668
17	.6097	.6602		.6344	.6859	.7545	.6859
18		.5658		.7373		.7545	.6668
19	.8383	.8962	.9526	.7716			.743
20	.9145	.9997	.9717	.7716			.9145
21	.8383	.8299	.8383	.7545	.6668	.7356	.8383
22	.8002	.7733	.8002	.7202	.6478	.6413	.8192
23	.6287	.7167	.6478	.6173	.6097	.5658	.6859
24	.5335	.4191	.6036	.5716	.5144	.5716	.5281
Max	.9145	.9997	.9717	.8764	.7095	.8002	.9145
Min	.4572	.362	.4904	.4115	.5144	.4954	.4904
Avg	.5997	.6135	.7084	.6232	.6010	.6077	.6346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 206 / 11 KV Renuka & Hanuman

PURELY LIS FEEDERS

Express Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.5335	.5281	.5335	.4801	.2286	.2263
4	.5335	.5281	.5335	.4801	.2477	.2263
5	.5335	.5281	.5525	.4801	.2477	.2263
6	.5335		.5525	.4458	.2477	.2452
7	.5525	.1494	.4954	.4801	.2477	.2427
8	.5335	.6224	.5335	.4801	.5335	.4801
9	.5335		.4801	.5281	.5144	.5144
10	.5335		.4801	.5281		.5144
11			.4801	.5281	.4801	.5144
12	.5335	.5906	.4801	.4338	.5144	
13		.5906	.4801	.415	.5316	.4382
14			.4801	.415	.5316	.5144
15		.5525	.4801	.4527	.463	.5335
16	.5906		.4801	.4294	.463	.5144
17	.5658		.4801	.4382	.5093	.2858
18	.6224		.4801	.5335	.5281	.2858
Max	.6224	.6224	.5525	.5335	.5335	.5335
Min	.5335	.1494	.4801	.415	.2286	.2263
Avg	.5499	.5112	.5001	.4718	.4192	.3841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 207 / 11 KV Kawane Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.5432	.0191	.0189
2					.8916	.0191	.0189
3					.8916	.0191	.0189
4					.8916	.0191	.0189
5					.9259	.0381	.1132
6						.0381	.132
7						.0191	.1886
8						.0191	.168
9	1.643	1.7193		1.2174			
10	1.6289	1.8111		1.2003			
11	1.3203	1.7375					
12	1.5089		1.7318	1.4575			
13	1.6032		1.7318	1.406			
14	1.5089			1.406			
15	1.4712		1.6632	1.3717			
16	1.4146	1.4969		1.3375			
17		.9335					.0191
18		1.3491					
22				.9602			
23				.9945			
24					.9602		.0189
Max	1.643	1.8111	1.7318	1.4575	1.5432	.0381	.1886
Min	1.3203	.9335	1.6632	.9602	.8916	.0191	.0189
Avg	1.5124	1.5079	1.7089	1.2612	1.0174	.0239	.0715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 201 / 11 KV BHOGAWATI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4108	.3772	.4338	.4108	.4108	.3961
2	.3772	.4108	.3772	.4338	.4108	.3961	.3772
3	.3772	.4108	.3658	.4338	.4024	.3881	.3772
4	.3772	.4108	.3961	.4338	.4024	.3921	.3772
5	.4527	.4435	.415	.4904	.4481	.4481	.415
6	.547	.5228	.5093	.5281	.5121	.5281	.4527
7	.4854	.4668	.415	.6036	.4755	.4854	.4904
8	.4668	.4854	.4163	.5175	.4854	.4481	.5121
9	.4668	.5415			.5853	.4938	.5138
10	.443	.5138			.5175	.4572	.5552
11	.439	.5068			.5175	.5487	
12	.4252	.439					.5249
13	.4024	.4572	.5959				.4835
14	.4024	.4572					.5014
15	.3658	.439	.5258		.6283	.5973	.5611
16	.4252	.3658			.6219	.5853	.5249
17	.4572	.439	.567	.7316	.6584		.6036
18	.4161	.4161	.3174	.695	.6024	.543	.5304
19	.5083	.567		.7023		.5973	.5729
20	.5316	.567	.6535	.6283			.5914
21	.567	.5544	.6224	.6099	.5493		.5788
22	.5175	.5281	.5847	.5487	.5068	.5792	
23	.439	.4481	.5281	.462	.4527		.4715
24	.415	.4024	.3772	.4338	.4481	.415	.439
Max	.567	.567	.6535	.7316	.6584	.5973	.6036
Min	.3658	.3658	.3174	.4338	.4024	.3881	.3772
Avg	.4451	.4668	.4732	.5429	.5071	.4890	.4932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 202 / 11 KV RASHIWADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0324	.1715	.0343	1.4575	.1543	.2658
2	.0381	.0362	.1715	.0343	1.4575	.1715	.2543
3	.0381	.0362	.1715	.0343	1.4575	.1772	.2658
4	.0381	.0324	.1715	.0343	1.4251	.1753	.3898
5	.0381	.0381	.1715	.0343	1.5424	.2572	.4755
6	.0381	.0381	.1905	.0343	.1715	.4908	.3898
7	.0381	.0381	.1905	.0343	.1715	.5144	.5316
8	.0419	.0343	.1905	.0343	.1715	.463	.7265
9	2.8292	3.2579			.1715	.1372	.1524
10	.6661	3.1352		2.6749	.0263	.0191	.0467
11	3.1207	3.0178		2.572	.0263	.0189	
12	3.2768	3.0864		2.4417	.0219	.0189	.0467
13	2.9473		2.7778	2.489	.0263	.0187	.04
14	2.9797			2.5065	.0263	.0171	.0467
15	2.9096		2.9664	2.3579	.0263	.0191	.0467
16	2.8121	2.5316	1.749	2.1795	.0438	.0171	.0427
17	.1905	2.8635			.0438		.0467
18	.0324	2.7778		.1715	.0324	.1334	.0307
19	.0343	.1715		.1715		.1334	.0307
20	.0324	.1905	.0343	.1715			.0307
21	.0362	.1905	.0343	.1715	.0324		.0307
22	.0762	.1905	.0343	1.6095	.0324	.1524	
23	.0381	.1715	.0343	1.6461	.0655		.0307
24	.1524	.0324	.1715	.0343	1.5947	.0655	.1524
Max	3.2768	3.2579	2.9664	2.6749	1.5947	.5144	.7265
Min	.0324	.0324	.0343	.0343	.0219	.0171	.0307
Avg	.9351	1.0430	.5769	.9760	.4557	.1577	.1852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 203 / 11 KV KOULAV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9376	1.9547		.124	.0343	.0373	.0381
2	1.9376	1.8519		.124	.0343	.0377	.0381
3	1.9547	1.7661	1.4373	.124	.0343	.0328	.0381
4	1.9547	1.7974	1.5061	.124	.0343	.0324	.0381
5	1.9719	1.9376	1.5775	.124	.0343	.0324	.0381
6	2.0919	2.0062		.1417	.0343	.0316	.0381
7	1.989	1.8176	1.4074	.1417	.0343	.0324	.0572
8	.0377	.0381	.0381	.0189	.0343	.0316	.0762
9	.0373	.0381			1.3413	1.0898	1.4083
10	.0381	.0343		.0381	1.7661	1.7101	1.6712
11	.0381	.0343		.0572	1.8004	1.7604	
12		.0191		.0572	1.5947	1.7436	1.6461
13	.0381	.0191	.0191	.0572	1.7833	1.5927	1.9376
14	.0381	.0191		.0572	1.6975	1.6933	1.869
15	.0572	.0191	.0381	.0572	1.6804	1.6095	1.9204
16	.0572	.0183		.0381	1.5432	1.4754	1.9719
17	.0381	.0191		.0572	.0566		1.9376
18	.0381	.0572	.0377	.0343	.0532	.0572	.0373
19	.0377	.0381	.0377	.0343		.0191	.0373
20	.0381	.0381	.0377	.0343			.0373
21	.0377	.0381	.0377	.0343	.0377		.0373
22	2.1605	1.8652	.1595	.0343	.0381	.0381	
23	2.1091	1.6956	.1417	.0343	.0377		.0377
24	1.989	2.0576		.124	.0343	.0377	.0381
Max	2.1605	2.0576	1.5775	.1417	1.8004	1.7604	1.9719
Min	.0373	.0183	.0191	.0189	.0343	.0191	.0373
Avg	.8968	.7992	.4981	.0727	.6245	.6548	.6795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 201 / 11 KV SHAHUNAGAR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
20	.5792
Max	.5792
Min	.5792
Avg	.5792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 202 / 11 KV COLLAGE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.4268
Max	.4268
Min	.4268
Avg	.4268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 204 / 11 Kv Washi Sheti
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 205 / 11 kv Dewale

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 206 / 11 Kv Tulashi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 207 / 11 KV HIRAWADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
23	.3048
24	.4572
Max	.4572
Min	.3048
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 208 / 11KV KOTHALI SPPM

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 209 / 11 KV HANUMAN SPPM

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 401 / 33 Kv Puikhadi

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 402 / 33 KV Kanchanwadi Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 403 / Awali

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
22	6.8587
24	2.7435
Max	6.8587
Min	2.7435
Avg	4.8011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 404 / 33 KV Wadakshiwale Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146013 / 111/33 kv Puikhadi

Feeder No / Name : 406 / Rajiwaji Sut Girani

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 201 / 11 Kv Wakare Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0342	.0362		.0342			
2	.0342	.0346		.0342			
3	.0342	.0331	.0436	.0342			
4	.0357	.0331	.0436	.0342			
5	.0357	.0346		.0342			
6	.0372	.0391		.0342			
7	.0372	.0376	.0436	.0297			
9					.0368	.0403	
10					.0473	.0486	.0208
11					.0496	.0486	.0372
12					.0496	.0514	
13					.0461	.0537	.0372
14					.0448	.0537	.0372
15					.0478	.0436	.0381
16					.0478	.0436	.0372
22	.0421	.0441	.0337				
23	.0452	.0436	.0342				
24	.0342	.0406		.0342			
Max	.0452	.0441	.0436	.0342	.0496	.0537	.0381
Min	.0342	.0331	.0337	.0297	.0368	.0403	.0208
Avg	.0370	.0377	.0397	.0336	.0462	.0479	.0346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 202 / 11 Kv Mahe Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0089	.009	.0086	.0089	.0053	.0088	.0069
2	.0089	.009	.0086	.0089	.0053	.0088	.0069
3	.0089	.0072	.0086	.0089	.0053	.0089	.0069
4	.009	.0072	.0103	.0089	.0053	.0089	.0069
5	.009	.009	.0103	.0106	.0071	.0088	.0086
6	.0129	.0107	.0103	.0125	.0089	.0123	.0086
7	.011	.0107	.0103	.0106		.0104	.0103
8		.0107	.0103	.0106	.0089	.0105	.0086
9		.0106	.0107	.0105	.0088	.0106	.0089
10	.0089	.0124		.0105		.0117	.0088
11		.0124			.0123	.0101	.0105
12		.0143	.0142	.0124	.0123	.0102	
13		.0125	.0142	.0123	.0111	.0103	.0123
14		.0125	.0124	.0123	.0088	.0103	.0105
15		.0125	.0106	.014	.0123	.0103	.0123
16		.0106	.0106	.0123	.0124	.0103	.0106
17	.0089	.0086		.0089	.0105	.0103	.0105
18	.0106	.0105		.0106	.0105	.0103	.0106
19	.0128	.012			.0123		.0124
20	.0142	.0137	.0142	.0106	.0142	.012	.0142
21	.0142	.012	.0124	.0089	.014	.012	.0142
22	.0125	.0103	.0106	.0089	.0124	.0086	.0124
23	.0107	.0103		.0071	.0105	.0069	.0089
24	.0514	.009	.0086	.0089	.0071	.007	.0069
Max	.0514	.0143	.0142	.014	.0142	.0123	.0142
Min	.0089	.0072	.0086	.0071	.0053	.0069	.0069
Avg	.0133	.0107	.0109	.0104	.0098	.0099	.0099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 203 / 11 Kv Bahireshwar Vg
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0037	.0037	.0034	.0037	.0037	.0037	.0037
2	.0037	.0037	.0034	.0037	.0019	.0036	.0037
3	.0038	.0037	.0034	.0037	.0019	.0037	.0037
4	.0037	.0037	.0034	.0037	.0037	.0034	.0037
5	.0038	.0036	.0034	.0056	.0037	.0035	.0037
6	.0037	.0035	.0034	.0075	.0037	.0056	.0037
7	.0037	.0034	.0034	.0053	.0035	.0056	.0037
8		.0034		.0054	.0035	.0053	.0037
9	.0017	.0036	.0034	.0053	.0051	.0053	.0034
10	.0035	.0051		.0053	.0053	.0037	.0035
11	.0017	.0051		.0053	.0053	.0055	.0034
12	.0017	.0051	.0051	.0053	.0053	.0055	
13	.0018	.0051	.0053	.0051	.0051		.0049
14	.0017	.0053	.0053	.0053	.0053	.0055	.0051
15	.0034	.0053	.0053	.0054	.0051	.0055	.0052
16	.0034		.0053	.0054	.0051	.0055	.0051
17	.0036	.0035		.0034	.0053	.0037	.0051
18	.0036	.0035		.0051	.0034	.0037	.0053
19	.0035	.0055		.0053	.0053		.0053
20	.0055	.0055	.0073	.0053	.0053	.0055	.0054
21	.0051	.0055	.0055	.0053	.0051	.0055	.0055
22	.0056	.0037	.0056	.0035	.0056	.0037	.0056
23	.0037	.0037	.0038	.0035	.0034	.0037	.0037
24	.0038	.0037	.0034	.0038	.0037	.0037	.0034
Max	.0056	.0055	.0073	.0075	.0056	.0056	.0056
Min	.0017	.0034	.0034	.0034	.0019	.0034	.0034
Avg	.0035	.0043	.0044	.0048	.0043	.0046	.0043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 204 / 11 Kv Sangrul Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0033	.0033	
2					.0033	.0033	.0033
3					.0033	.0033	.0033
4					.0033	.0033	.0033
5					.0032	.005	.0033
6						.005	.0033
7						.0067	.0033
8						.0066	.0033
9	.0215	.0227	.0262	.0166			
10	.0229	.0211		.0166			
11		.0213		.0166			
12	.0229	.0178	.0246	.0149			
13	.0229		.0246	.0133			
14	.0229		.0229	.0147			
15	.0213		.0213	.0133			
16	.018	.0162	.018	.014			
17		.0166					
18		.0149					
22				.0049			
23				.0049			
24					.0033		
Max	.0229	.0227	.0262	.0166	.0033	.0067	.0033
Min	.018	.0149	.018	.0049	.0032	.0033	.0033
Avg	.0218	.0187	.0229	.0130	.0033	.0046	.0033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 205 / 11 Kv Mahe Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0405	.0369		.0046			
2	.0405	.0352		.0047			
3	.0405	.0344	.0398	.0048			
4	.041	.0352	.0402	.0047			
5	.0426	.0365		.0043			
6	.0421	.0419		.0046			
7	.0368	.0369	.0431	.0043			
9					.0356	.0459	.0448
10						.0537	.0481
11					.0393	.0537	.0481
12					.0448		
13					.0464	.057	.041
14					.0448	.0587	.0393
15					.0426	.057	.0381
16					.0441	.052	.0381
17					.0377		
22	.0503	.0486					
23	.0453	.0436					
24	.061	.0402		.0048			
Max	.061	.0486	.0431	.0048	.0464	.0587	.0481
Min	.0368	.0344	.0398	.0043	.0356	.0459	.0381
Avg	.0441	.0389	.0410	.0046	.0419	.054	.0425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 206 / 11 Kv bahireshwar Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0276	.0303		.0188			
2	.0286	.0265		.018			
3	.0286	.0261	.0453	.0183			
4	.0281	.0265	.0303	.0171			
5	.0281	.0276		.0169			
6	.0287	.0293		.0169			
7	.0292	.0287	.0247	.016			
9					.0281	.0034	.0303
10						.036	.032
11					.0337	.036	.0169
12					.0371	.0382	
13					.0354	.0348	.0157
14					.0354	.0348	.0276
15					.0343	.0326	.0281
16					.0354	.0326	.0292
17					.032		
22	.032	.0337	.0199				
23	.0315	.0337	.0199				
24	.0276	.0309		.0188			
Max	.032	.0337	.0453	.0188	.0371	.0382	.032
Min	.0276	.0261	.0199	.016	.0281	.0034	.0157
Avg	.029	.0293	.0280	.0176	.0339	.0311	.0257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 201 / 11 kv Nagdevwadi Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3375		.8573	
2				1.3032			
3				1.3032			
4				1.3375			
5				1.3717			
6				1.3203			
8		.0857	.0171			1.2193	
9	1.989	1.9376	1.4403				
10	2.3663	2.0233					
11	2.4691	1.9204					
12	2.4006	1.7147	2.0062				
13	2.332		2.2119				
14	2.332		2.2291				
15	2.2634						
16	2.2634	2.1948					
17	.0343	2.1948					
18	.0171	2.1262					
19	.0171						
20	.0171						
22			1.406				
23			1.406	.3429			
24				1.3546	.3429	.7621	.0343
Max	2.4691	2.1948	2.2291	1.3717	.3429	1.2193	.0343
Min	.0171	.0857	.0171	.3429	.3429	.7621	.0343
Avg	1.5418	1.7747	1.5309	1.2089	.3429	.9462	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 202 / 11 kv Padali Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.6516	.6516	.6344		.6001
2	.5658	.6516	.6516	.6344		
3	.5658	.6173	.6516	.6344		
4	.5658	.6516	.6859	.6516		
5	.6173		.7545	.6687		
6	.7888	.823	.823	.8916		
7	.7716	.7545	.8059	.8745		
8	.7545	.7202	.6859	.8745		.7621
9	.703	.823	.823	.8916		.7621
10	.6344	.7888		.8916		.7621
11	.5487	.7545		.8383		
12	.5487	.7545	.9088			
13	.6173	.6859	.8402	.6859		
14	.6173	.6859	.8059			
15	.5658	.6859	.7716			
16	.5658	.6173		.7621		
17	.6173	.6859				
18	.6516	.6859		.8916		
19	.823	.823				
20	.9774	.8916				
21	.8916	.8573			.7926	
22	.823	.823	.9259	.7545	.6859	
23	.7373	.7545	.8059	.6859	.6097	
24	.6344	.6859	.6859	.6687	.6516	.5335
Max	.9774	.8916	.9259	.8916	.7926	.7621
Min	.5487	.6173	.6516	.6344	.6097	.5335
Avg	.6737	.7336	.7673	.7608	.6850	.6840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 203 / 11 kv khupire Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2572	.2229	.3258			
2		.2572	.2229	.3086			
3	.2229	.2229	.2229	.3086			
4	.2229	.2229	.2229	.3086			
5	.2229	.2229	.2229	.3258			
6	.2915	.2915	.2572	.4115			
7	.2572	.2401	.3086	.4115			
8	.2743	.2915	.2915	.4115		.3048	
9	.2743	.2743	.3086	.3944		.2743	
10	.2743	.2572		.4287		.3048	
11	.2401	.2572		.381		.3601	
12	.2572	.2401	.0429			.4458	
13	.2743	.3772	.4458	.381		.4458	
14	.2743	.3772	.4801			.4115	
15	.2743	.3601	.4801			.5144	
16	.2915	.4287		.381			
17	.3086	.4458					
18	.3086	.3258		.4801			
19	.3086	.3258					.3658
20	.3944	.3429					
21	.3429	.3258			.4115		
22	.3258	.3258	.463	.3258	.381		.381
23	.2743	.2743	.3772	.3429	.3353		
24	.2229	.2572	.2401	.3258	.2572	.2286	.1886
Max	.3944	.4458	.4801	.4801	.4115	.5144	.381
Min	.2229	.2229	.0429	.3086	.2572	.2286	.1886
Avg	.2766	.3001	.3006	.3678	.3463	.3656	.3118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 204 / 11 Kv Fulewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9945	.9259	.8745		.9431	
2	.8916	.9602	.8916	.8573			
3	.8745	.9259	.8916	.8573			
4	.8745	.9602	.9259	.8573			
5	.9088	.9602	.9602	.8745			
6	.9945	.9602	1.0288	.9431			
7	.9945	1.0117	1.0288	1.0802			
8	1.0117	1.0631	1.0288	1.0802		1.0288	
9	.8916	.9774	1.3375	.9774		.9602	
10	.8573	.9259		.9259		.9602	
11	.823	.9602		.9602		.9945	
12	.6516	.9602	1.1831			1.0288	
13	.6859	.9602	1.0974	.8916		1.0974	
14	.6859	.9602	1.046			1.046	
15	.9602	.9602	1.046			.9945	
16	.9602	.9259		.9431			
17	.9259	.9602					
18		.9602		1.1145			
19	1.0802	1.166					1.2346
20	1.3889	1.3032					
21	1.3203	1.3717			1.3717		
22	1.3546	1.2517	1.2003	1.166	1.3032		1.3032
23	1.2517	1.0974	1.0631	.9945	1.2003		
24	.9602	1.0631	.9945	.9431	.8916	1.0288	.823
Max	1.3889	1.3717	1.3375	1.166	1.3717	1.0974	1.3032
Min	.6516	.9259	.8916	.8573	.8916	.9431	.823
Avg	.9684	1.0267	1.0406	.9612	1.1917	1.0082	1.1203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 205 / Balinga Water Works NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9602	.9259	.9602		.9602	
2		.9602	.9259	.9602			
3	1.0562	.9602	.9259	.9602			
4	1.0562	.9431	.9259	.9259			
5	1.0562	.9431	.9602	.9259			
6	1.0562	.9945	.9602	.9431			
7	1.0374	.9774	.9602	.9259			
8	.9997	.9602	.9602	.9259		.8916	
9	1.0562	.9945	.0977	.9602		.9602	
10	.9774	.9774	.9602	.9602		.9602	
11	.9602	.9602	.9945	.9602		.9945	
12	.9602	.9602	.9945			.9602	
13	.9602	.9259	.9945	.9602		.9602	
14	.9602	.9259	.9945			.9774	
15	.9602	.9259	.9945			.9602	
16	.9945	.9602		.9431		.9602	
17	.9259	.9602					
18	.9259	.9602		.9602			
19	.9431	.9259					.9602
20	.9259	.9259		.9259			
21	.9259	.9259		.9259	.9602		
22	.9602	.9602	.9602	.9259	.9602		.9602
23	.9774	.9602	.9602	.9259	.9602		
24	1.0562	.9431	.9602	.9431	.9259	.9602	1.0185
Max	1.0562	.9945	.9945	.9602	.9602	.9945	1.0185
Min	.9259	.9259	.0977	.9259	.9259	.8916	.9602
Avg	.9878	.9538	.9142	.9431	.9516	.9586	.9796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 206 / 11 KV KUDITRE AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0233	2.1948					
2	1.9376	2.0576					
3	1.9204	1.5432	1.9376				
4	1.9033	1.6804	1.9204				
5	1.6461	2.0062					
6	2.1948	2.3834					
7	2.0748	2.3148	2.1948	.0171			
8	.0229			.0171			
9				2.7435		1.3717	
10				2.8978		2.0576	
11				2.7435		2.1262	
12						1.7223	
13				2.3148		2.0062	
14						1.9547	
15						1.6632	
16				.1715			
18				.0343			
19		.0171					.0343
20		.0171					
21	.0171	.0171			.0343		
22	2.5034	2.572			.0343		
23	2.6063	2.332			.0343		
24	1.9204	2.2977				.0343	
Max	2.6063	2.572	2.1948	2.8978	.0343	2.1262	.0343
Min	.0171	.0171	1.9204	.0171	.0343	.0343	.0343
Avg	1.7309	1.6487	2.0176	1.3675	.0343	1.6170	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 207 / 11 KV FULEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.7621			
2		.7316			
3	.703	.7316	.7164		
4	.703	.8535	.7164		
5	.7202	.7011			
6	.7888	.7621			
7	.7888	.7468	.6859		
8			.6859		
9				.9297	.7621
10				1.0059	.7621
11				.9907	.7621
12					.7621
13				.9145	.7621
14					.7468
15					.7468
16				.7926	
22	.9297	.8688			
23	.8535	.7926			
24	.7373	.7621			
Max	.9297	.8688	.7164	1.0059	.7621
Min	.703	.7011	.6859	.7926	.7468
Avg	.7716	.7712	.7012	.9267	.7577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 208 / 11KV Padali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0114	.0152	.0152	.6097			
2			.0152	.5792			
3	.0114	.0152	.0152	.5792			
4	.0114	.0152	.0152	.5792			
5	.0114	.0152	.0152	.6097			
6	.0114	.0152	.0152	.6249			
7	.0114	.0152	.0152	.0171			
8	.0114	.0152	.0152	.0152		1.0669	
9	2.0405	2.0424	1.9052	.0152		.0152	
10	1.7833	1.9204		.0152		.0305	
11	1.8442	1.9052		.0152			
12	1.7375	1.89	1.9204			.0152	
13	1.6766		1.9052	.0152			
14	1.6766		1.829				
15	1.5851		1.7833			.945	
16	1.5699	1.6918		.0152			
17	.0152	1.6156					
18	.0152	1.5699		.0305			
19	.0152	.0152					.6097
20	.0152	.0152					
21	.0152	.0152			.0305		
22	.0152	.0152	.7545		.0305		.8535
23	.0152	.0152	.6401	.4877	.0305		
24	.0114	.0152	.0152	.6097	.503	.0305	.5658
Max	2.0405	2.0424	1.9204	.6249	.503	1.0669	.8535
Min	.0114	.0152	.0152	.0152	.0305	.0152	.5658
Avg	.6135	.6416	.6797	.3011	.1486	.3506	.6763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 209 / 11KV Khupire Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0114	.0152	.0152	.3963		.3772	
2	.0114	.0152	.0152	.3963			
3	.0114	.0152	.0152	.4115			
4	.0114	.0152	.0152	.3658			
5	.0114	.0171	.0152	.3658			
6	.0114		.0152	.4572			
7	.0114	.0171	.0152	.0152			
8	.0114	.061	.0152	.0152		.6859	
9	2.1262	1.768	.945			.0305	
10	1.8595	1.7071		.0152		.0305	
11	1.7071	1.3413		.0305			
12	1.4022	1.1584	1.4632			.0343	
13	1.2193		1.4632	.0305		.0152	
14	1.2193		1.2498			.0152	
15	1.0974		1.0974			.0152	
16	.9145	.9755		.0305			
17	.0305	.9145					
18	.0152	.823		.0305			
19	.0152	.0152					.0305
20	.0152	.0152					
21	.0152	.0152			.0305		
22	.0152	.0152	.4115		.0305		
23		.0152	.4268	.0305	.0343		
24	.0114	.0152	.0152	.3963		.0305	.0114
Max	2.1262	1.768	1.4632	.4572	.0343	.6859	.0305
Min	.0114	.0152	.0152	.0152	.0305	.0152	.0114
Avg	.5111	.4468	.4496	.1992	.0318	.1372	.0210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 210 / 11 Kv kuditre Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)
11		.9431
24	.0514	
Max	.0514	.9431
Min	.0514	.9431
Avg	.0514	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 201 / 11 KV SANGRUL VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4066	.4527	.3881	.3734	.3961	.4338
2	.3361	.3881	.415	.3841	.3772	.3961	.4338
3	.3395	.3696	.4108	.3696	.3772	.3584	.415
4	.3547	.3475	.4108	.3658	.3734	.3584	.3921
5	.415	.4481	.4854	.5041	.3881	.415	.4294
6	.5415	.5544	.6161	.5788	.5487	.6161	.6348
7	.5853	.5729	.5487	.5359	.543	.5729	.6036
8	.567	.5083	.5316	.4298	.6335	.5552	.567
9	.5138	.5609	.5375	.4298	.6089		.4382
10	.5028	.5375	.5201	.5375	.6001		.443
11	.4508	.5201	.4908	.5201	.6001	.4784	.5373
12		.463	.5316	.5144	.6241		.4656
13	.3982	.5028	.4961	.5434	.5721	.6104	.4477
14	.4119	.5258	.4656	.5373	.5434	.5731	.4784
15	.4119	.5375	.5138	.5068	.4784	.5959	.4784
16	.4298	.5609		.5256	.6068		.5552
17	.4733	.6173		.5552	.6203	.7377	.5426
18	.5144	.5935			.6104	.6299	
19	.631	.691	.7522		.6984	.7802	.7802
20	.7762	.7865	.823	.4207	.7947		.9145
21	.7282	.7655	.7421	.7095	.7655	.7762	.8402
22	.6535	.6602	.6413	.5975	.5847	.5788	.6722
23	.5601	.5093	.4481	.415	.4904	.4854	
24	.4338		.4904	.4481	.415	.4338	.4904
Max	.7762	.7865	.823	.7095	.7947	.7802	.9145
Min	.3361	.3475	.4108	.3658	.3734	.3584	.3921
Avg	.4959	.5403	.5392	.4917	.5512	.5446	.5452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 202 / 11 KV KHATANGLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1448	.2641	.1429
2					.1448	.2709	.1448
3					.1486	.2896	.1509
4					.1718	.3353	.1355
5					.2012	.3658	.2743
6						.6009	.5468
7						.7116	.7116
8						.5535	.5268
9	2.6578	2.4417	2.2466	1.5257			
10	2.4247	2.1874	2.1365	1.2929			
11	2.2043	2.0687	1.7772	1.4419			
12		1.7238	1.6766	1.3272			
13	1.95		1.6244	1.2944			
14	1.8275		1.7126	1.2717			
15	1.8275		1.6766	1.2717			
16	1.6787	1.2887	1.5912	1.153			
17		1.5261					
18		1.4586					
22				.1429			
23				.1486			
24					.1572		
Max	2.6578	2.4417	2.2466	1.5257	.2012	.7116	.7116
Min	1.6787	1.2887	1.5912	.1429	.1448	.2641	.1355
Avg	2.0815	1.8136	1.8052	1.087	.1614	.4240	.3292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 203 / 11 KV UPWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2279			.0191			
2	.2229	.0191		.0191			
3	.2229	.0191	.0191	.0191			
4	.2427	.0191	.0191				
5	.2374	.0191	.0191	.0191			
6	.2713	.0191		.0191			
7	.3688	.0191	.0191	.0191			
9					.0191	.285	.3041
10					.2561		.3277
11					.5535	.2785	.2652
12					.6154		.1638
13					.4858	.1718	.1619
14					.426	.1296	.1677
15					.3768	.1296	.16
16					.2753	.096	.16
22		.0324	.0191				
23		.0312	.0191				
24	.2401			.0191			
Max	.3688	.0324	.0191	.0191	.6154	.285	.3277
Min	.2229	.0191	.0191	.0191	.0191	.096	.16
Avg	.2543	.0223	.0191	.0191	.376	.1818	.2138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 202 / 11 KV SHENAGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	.1143	.1143	.1143	.8383	.2477	.5716
2	1.9052	.1143	.1143	.1143	.8383	.2477	.5716
3	1.9052	.1143	.1143	.1143	.8383	.2477	.5906
4	1.9052	.1143	.1143	.1143	.8764	.2477	.5906
5	1.9052	.1143	.1143	.1143	.9907	.2477	.6097
6	1.9243	.1143	.1143	.1143	1.1431	.3429	.6859
7	.1143	.1143	.1143	.1143	.1143	.3429	.724
8	.1334	.1143	.1143	.1143	.0953	.362	.6478
9	3.6199	3.658	3.5437	3.2388	.0953	.0191	
10	3.4865	3.658	3.4294	3.0483	.0953	.0191	.0191
11	3.5246	3.5818	3.6199	2.8197	.0953	.0191	.0191
12	3.658	3.6199	3.315	2.7435	.0953	.0191	.0191
13	3.5056	3.5818	3.2388	3.0483	.1143	.0191	.0191
14	3.5056	3.4675	3.2007	3.0483	.1143	.0191	
15	3.2388	3.4294			.1143	.0191	
16	3.4294	3.3532			.0191	.0191	
17	.1143	.1143	.0191	.1143	.0191	.0191	
18	.1143	.1143	.0953	.1143	.0191	.0191	
19	.1143	.1143	.0953	.0762	.0191	.0191	
20	.1143		.0953	.0762			
21	.1143	.1143	.0953	.0191	.0191		.0191
22	.1143	.1143	.0953	.0762	.0191		.0191
23	.4163	.1143	.1143	.9145	.0191	.0191	.0191
24	2.0005	.1143	.1143	.1143	.8383	.0191	.0191
Max	3.658	3.658	3.6199	3.2388	1.1431	.362	.724
Min	.1143	.1143	.0191	.0191	.0191	.0191	.0191
Avg	1.7820	1.3071	.9994	.9257	.3231	.1207	.3215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPALGAON VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7049	.6859	.724	.6668	.6478	.6097
2	.7049	.7049	.6859	.724	.6668	.6097	.6097
3	.7049	.7049	.6859	.6859	.6668	.6097	.6097
4	.7049	.7049	.6859	.6859	.6668	.6097	.6287
5	.7049	.7049	.6859	.7049	.6859	.6097	.6287
6	.7049	.7049	.6859	.724	.7049	.6478	.6478
7	.6287	.6478	.6097	.6287	.6668	.6097	.5906
8	.6287	.6668	.6478	.5906	.6478	.6478	.6097
9	.6668	.6287	.6478	.6668	.6668	.6859	.6097
10	.6859	.7621	.6859	.724	.6859	.6668	.7621
11	.724	.7621	.8573	.7621	.8192	.7621	.7621
12		.7621	.8573	.8383	.8383	.7621	.7621
13			.9145	.7621	.9145	.9145	.724
14		.7621	.9335	.8383	.8573	.8383	
15	.8383	.7621	.8383	.8192	.7811	.7621	
16	.8383	.8764			.9145	.7621	
17	.7621	.8002	.8383	.7621	1.0098	.7049	
18	.7621	.7621	.8002	.8573	.7811	.724	
19	.9145	.8002	.9907	.9907	.9717	.8383	
20	1.1431	.9145	1.1622	.9907			
21	1.0098	.8764	1.0479	.9145	1.0098		
22	.9907	.8002	.9907	.8383	.8764	.8383	
23	.8383		.8573	.7621	.7811	.7621	.7621
24	.381	.7621	.6859	.743	.6859	.6668	.6859
Max	1.1431	.9145	1.1622	.9907	1.0098	.9145	.7621
Min	.381	.6287	.6097	.5906	.6478	.6097	.5906
Avg	.7648	.7534	.8035	.7712	.7811	.7127	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 204 / 11 KV MADILAGE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.362	.4191	.4001	.3239	.381	.3048
2	.381	.362	.4191	.4001	.3239	.362	.3048
3	.381	.362	.4191	.4001	.3239	.362	
4	.381	.362	.4191	.4001	.3429	.362	
5	.381	.4001	.4191	.4001	.362	.362	
6	.4191	.4382	.4382	.4191	.381	.4382	
7	.362	.381	.4001	.381	.362	.4001	
8	.362	.362	.3429	.362	.3239	.362	.0762
9	.3429	.3239	.3239	.362	.3048	.3239	
10	.3429	.3429	.3429	.3429	.3429	.4001	.4001
11	.1715	.3429	.3239	.362	.3429	.4191	.4572
12	.1715	.3429	.3429	.3429	.381	.4382	.4382
13		.3429	.381	.3048	.3239	.4191	.4191
14	.2858	.3429	.381	.3429	.4001	.4191	
15	.3429	.381	.381		.4382	.4382	
16	.362	.381		.2477	.381	.4572	
17	.381	.381	.4382	.3048	.4954	.5144	
18	.362	.4001	.4572	.4001	.4191	.4572	
19	.4763	.5335	.5716	.4954	.4763	.4954	
20	.5335	.5716	.6097	.5144			
21	.4954	.5335	.5716	.4763	.5335		.6097
22	.4954	.4954	.5525	.4191	.4763	.4382	.5716
23	.4572	.4763	.4382	.362	.4001	.3429	.4763
24	.4001	.4001	.4382	.4191	.3429	.381	.3429
Max	.5335	.5716	.6097	.5144	.5335	.5144	.6097
Min	.1715	.3239	.3239	.2477	.3048	.3239	.0762
Avg	.3769	.4009	.4274	.3852	.3827	.4079	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 205 / 11 KV GARGOTI PWV EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	.0572
4	.0572	.0572	.0572	.0572	.0572	.0572	.0572
5	.0572	.0572	.0572	.0572	.0572	.0572	.0572
6	.0572	.0572	.0572	.0572	.0572	.0572	.0572
7	.0572	.0572	.0572	.0572	.0572	.0572	.0572
8	.0572	.0572	.0572	.0572	.0572	.0572	.0572
9	.0572	.0572	.0572	.0572	.0572	.0572	.0572
10	.0572	.0572	.0572	.0572	.0572	.0572	.0572
11	.0572	.0572	.0572	.0572	.0572	.0572	.0572
12	.0572	.0572	.0572	.0572	.0572	.0572	.0572
13	.0572	.0572	.0191	.0572	.0572	.0572	.0572
14	.0572	.0572	.0572	.0572	.0572	.0572	
15	.0572	.0572	.0572	.0572	.0572	.0572	
16	.0572	.0572		.0572	.0572	.0572	
17	.0572	.0572	.0572	.0191	.0572	.0191	
18	.0572	.0572	.0572	.0191	.0191	.0191	
19	.0572	.0572	.0572	.0191	.0191	.0572	
20	.0572	.0572	.0572	.0191			
21	.0572	.0572	.0572	.0572	.0572		.0572
22	.0572	.0572	.0572	.0572	.0572	.0572	.0572
23	.0572	.0572	.0572	.0572	.0572	.0572	.0572
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0191	.0191	.0191	.0191	.0572
Avg	.0572	.0572	.0555	.0509	.0539	.0537	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 206 / 11 KV PIMPALGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.0572	.0381	.0381	.1905	.0572	.0762
2	.1715	.0572	.0381	.0381	.1905	.0572	.0762
3	.1715	.0572	.0381	.0381	.1905	.0572	.0762
4	.1715	.0572	.0381	.0381	.1905	.0572	.0762
5	.1715	.0572	.0381	.0381	.2096	.0572	.0762
6	.1524	.0572	.0381	.0381	.2667	.0953	.1905
7	.0381	.0381	.0381	.0381	.0381	.0953	.1905
8	.0381	.0572	.0381	.0191	.0381	.0953	.1715
9	.2667	.381	.3239	.2858	.0381	.0191	.0191
10	.3048	.3429	.3239	.2667	.0381	.0191	.0191
11	.3239	.2858	.3239	.2858	.0381	.0381	.0191
12	.2858	.2667	.3048	.2667		.0381	.0191
13	.2667	.2667	.2667	.2667		.0381	.0191
14	.2477	.2667	.2477	.2477		.0381	
15	.2667	.2858	.2477	.2096	.0191	.0381	
16	.2858	.2858		.1715	.0191	.0381	
17	.0381	.0381	.0191	.0381	.0191	.0381	
18	.0381	.0381	.0381	.0381	.0191	.0381	
19	.0381	.0381	.0381	.0381	.0191	.0572	
20	.0381	.0381	.0381	.0381			
21	.0381	.0381	.0381	.0381	.0191		.0381
22	.0572	.0381	.0381	.1715	.0191		.0381
23	.0572	.0381	.0381	.1715	.0191	.0381	.0381
24	.2096	.0572	.0381	.0381	.1715	.0191	.0381
Max	.3239	.381	.3239	.2858	.2667	.0953	.1905
Min	.0381	.0381	.0191	.0191	.0191	.0191	.0191
Avg	.1612	.1310	.1143	.1191	.0877	.0490	.0695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 207 / 11 KV GANGAPUR AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.9052		1.0098	.0762	.0572	.1334
2	1.8099	1.9052		1.0098	.0762	.0572	.1334
3	1.7909	1.9052	2.1338	.9526	.0762	.0572	.1334
4	1.7909	2.0576	2.0957	.9907	.0762	.0572	.1334
5	1.7909	2.1719	2.0005	1.086	.0762	.0572	.1334
6	2.2481	2.2291		1.4289	.0762	.0572	.1334
7	2.1338	2.3815	2.5339	1.6004		.0572	.0953
8	1.9433	2.1719	2.4768	1.4861	.0762	.0572	.0953
9	.2096	.2096	.2096	.1905	.6478	.5335	
10	.1905	.2096	.2096	.1905	1.0669	.8192	.724
11	.2096	.2096	.2096	.1905	1.467	.9145	.8764
12	.2096	.2096	.1715	.1715	1.6194	.8573	.8002
13		.2096	.1905	.1715	1.6575	.9145	.7621
14	.2096	.2096	.1905	.1715	1.6956	.9335	
15	.2096	.2096	.1905	.1715	1.5813	.8002	
16	.2096	.2096			1.5813	1.1622	
17	.2096	.1905	.0191		.1715	.1334	
18	.2096	.1905	.1905	.0191	.1715	.1143	
19	.2096	.1905	.1905		.1715	.1143	
20	.2096	.1905	.1905	.0762		.1143	
21	.2096	.2096	.1905	.0762	.1715		.0762
22	.2096	.2096	.1905	.0762	.1715	.1334	.0762
23	2.0767	2.1338	1.3908	.0762	.1524	.1334	.0762
24	2.0386	1.9243		1.0479	.0762	.0572	.1334
Max	2.2481	2.3815	2.5339	1.6004	1.6956	1.1622	.8764
Min	.1905	.1905	.0191	.0191	.0762	.0572	.0762
Avg	.9667	.9852	.7882	.5806	.5880	.3562	.2822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 208 / 11 KV DARWAD AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3429		.0191	.0381	.0381	.0191
2	.362	.362		.0381	.0381	.0381	.0191
3	.362	.362	.3429	.0191	.0381	.0381	.0191
4	.362	.362	.3239	.0191	.0381	.0381	.0191
5	.362	.362	.2477	.0191	.0381	.0381	.0191
6	.381	.4191		.0191	.0381	.0381	.0191
7	.4001	.4001	.3239	.0381		.0381	.0191
8	.381	.3429	.3239	.0381	.0572	.0381	.0381
9	.0191	.0381	.0381	.6287	.5335	.0191	
10	.0191	.0381	.0381	.6859	.5716	.2858	.1524
11	.0191	.0381	.0191	.7621	.5906	.3429	.2286
12	.0191	.0381	.0191	.724	.5716	.3239	.2286
13	.0191	.0381	.0191	.7621	.6097	.381	.2667
14	.0191	.0381	.0191	.724	.5335	.3429	
15	.0191	.0381	.0191	.6287	.5335	.3048	
16	.0191	.0381		.2477	.4763	.3239	
17	.0191	.0381	.0191	.0191	.0381	.0191	
18	.0191	.0381	.0191	.0381	.0381	.0191	
19	.0381	.0381	.0191	.0381	.0191	.0191	
20	.0381	.0381	.0191	.0381			
21	.0381	.0381	.0381	.0381	.0381		.0191
22	.0381	.0381	.0381	.0381	.0381		.0191
23	.381	.3429	.0381	.0381	.0381	.0191	.0191
24	.4001	.3429		.0191	.0381	.0381	.0191
Max	.4001	.4191	.3429	.7621	.6097	.381	.2667
Min	.0191	.0381	.0191	.0191	.0191	.0191	.0191
Avg	.1715	.1738	.1013	.2350	.2252	.1306	.0703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 209 / 11KV MADUR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3048	.381	.381	.2667	.3239	.2667
2	.381	.3048	.381	.381	.2667	.3239	.2667
3	.381	.3048	.381	.381	.2667	.3239	.2667
4	.381	.3048	.381	.381	.2667	.3239	.2858
5	.4001	.3429	.381	.4001	.2858	.3239	.3048
6	.4191	.4382	.4572	.4572	.3239	.4001	.381
7	.4382	.4001	.4572	.4572	.3429	.362	.362
8	.4001	.4191	.4572	.4572	.381	.4001	.381
9	.4001	.4191	.4191	.4191	.381	.362	
10	.381	.4001	.381	.4191	.4001	.3429	.2667
11	.2858	.381	.3048	.4191	.4572	.381	.3048
12	.2858	.381	.3239	.4001	.2858	.4191	.3048
13	.1715	.381	.4191	.362	.2477	.3239	.3429
14	.1905	.381	.4382	.381	.3048	.3429	
15	.1524	.381	.4001		.2667	.381	
16	.2858	.3429			.362		
17	.3239	.381	.4191	.381	.381	.4572	
18	.3429	.4191	.4382	.381	.4001	.4191	
19	.4763	.4954	.5525	.4572	.4763	.4191	
20	.5716	.5335	.6097	.4572			
21	.5335	.4954	.5525	.4572	.4763		.4954
22	.5144	.4572	.5144	.4001	.4001	.2858	.4572
23	.4191	.4191	.4382	.3239	.3429	.3239	.362
24	.4001	.3429	.381	.4001	.2858	.3239	.2858
Max	.5716	.5335	.6097	.4572	.4763	.4572	.4954
Min	.1524	.3048	.3048	.3239	.2477	.2858	.2667
Avg	.3715	.3929	.4291	.4070	.3421	.3602	.3334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 201 / 11 KV MANGNOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1389	1.3443		.9896	.0019	.0074	
2	1.1203	1.2883		.9335	.0019	.0073	
3	1.1203	1.2752	.7316	.9335	.0019	.0073	
4	1.0829	1.3817	1.0164	.8962		.0074	
5	1.1203	1.4563	1.1694	.9335	.0019	.0074	
6	1.5123	1.531		1.1203	.0019	.0073	
7		1.6632	1.5181	1.3443	.0018	.0073	
8	1.307	1.3676	1.3535	1.1576	.0019	.0073	
9		.0018	.0073			1.0317	
10		.0073	.0073		1.3676	1.4299	1.4083
11	.0019	.0074		.0019	1.2254	1.4563	1.419
12	.0018	.0073		.0019	1.4266	1.2323	1.419
13	.0018	.0074		.0018	1.262	1.4003	1.3443
14	.0019	.0074		.0019		1.3817	1.2936
15	.0018	.0073		.0019		1.4563	1.3817
16	.0018	.0073		.0018	1.2986	1.4563	1.4563
17	.0018	.0073	.8215	.0019	.0074		.0019
18	.0019	.0073	.8215	.0019	.0074		.0019
19	.0019	.0074		.0019	.0073	.0073	.0019
20	.0019	.0073		.0018	.0074		.0019
21	.0019	.0074		.0019	.0073		.0019
22	.0019	.0073		.0018	.0073		
23	1.4784	1.3432	1.0269	.0018	.0074		.0019
24	1.1576	1.3676		1.0269	.0018	.0073	
Max	1.5123	1.6632	1.5181	1.3443	1.4266	1.4563	1.4563
Min	.0018	.0018	.0073	.0018	.0018	.0073	.0019
Avg	.5267	.5882	.8474	.4254	.3323	.6066	.7487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 202 / 11 KV ARALGUNDI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0019	.0073		.5914	.543	.6036
2		.0019	.0074		.5975	.5853	.6219
3		.0019	.0073		.5544	.5853	.5792
4		.0019	.0074		.6099	.6219	.5487
5		.0019	.0073		.6653	.7023	.5121
6		.0019	.0073		.7468	.7682	.5853
7		.0018	.0073		.0018	.7133	.6154
8		.0018	.0073		.0019	.6767	.5487
9	1.8484	1.4937	.9955	1.0269		.0073	.0073
10	1.7737	1.4118	.9955	.9335	.0019	.0074	.0073
11	1.6078	1.3169	.9335	.8779	.0073		.0019
12		1.3169			.0073		.0018
13	1.6095	1.3717	.8962	.3696	.0073		.0019
14	1.5684	1.2803	.9335	.462			.0018
15	1.4784	1.2254	.8962	.7392	.0073		.0019
16	1.4632	1.2803	.5601	.6653	.0073		.0019
17	.0018			.0018	.0073		.0019
18	.0019			.0018	.0073		.0019
19	.0019	.0073		.0019		.0073	.0018
20	.0019	.0073		.0019		.0073	.0019
21	.0019	.0072		.0019		.0074	.0019
22	.0019	.0073		.0019	.0073	.0074	
23	.0019	.0073		.6653	.0074	.0074	.0019
24	.4287	.0018	.0073		.6099	.0073	.0074
Max	1.8484	1.4937	.9955	1.0269	.7468	.7682	.6219
Min	.0018	.0018	.0073	.0018	.0018	.0073	.0018
Avg	.7861	.4886	.3923	.4108	.2340	.3284	.2026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 203 / 11 KV ARALGUNDI VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0943	.0934	.132	.1132	.1307	.1494
2	.1132	.0754	.0739	.132	.0943	.1109	.112
3	.1132	.0754	.0747	.1132	.0943	.1132	.1132
4	.1132	.0754	.0754	.1132	.0943	.0739	.0739
5	.1132	.0943	.0747	.1132	.1132	.112	.112
6	.1132	.132	.1109	.132	.132	.1494	.1494
7	.132	.132	.1109	.1509	.132	.1294	.168
8	.132	.132	.1307	.1509	.1509	.1663	.1867
9	.132	.1509	.112	.1509		.1663	.168
10	.1509	.1478	.112	.1509	.132	.1494	.1478
11	.132	.1307	.132	.1509	.1433	.132	.1509
12		.128		.132	.128	.1132	.1509
13	.1132	.1307	.1698	.1132	.128	.1132	.132
14	.1132	.112	.132	.1132	.1294	.132	.132
15	.0943	.1294	.132	.1132	.1109	.132	.1509
16	.1132	.1307	.0377	.132	.1109	.132	.1509
17	.1132	.128	.0943	.1509	.1075	.1509	.132
18	.1132	.1294	.1698	.1698	.1478	.1509	.1509
19	.1886	.1867	.2075	.1886	.1663	.2033	.1886
20	.2452	.2195	.2641	.2263	.2241	.2033	.2263
21	.2075	.168	.2263	.1886	.1867	.2195	.2263
22	.1886	.1478	.1886	.1509	.1867	.2033	
23	.132	.1478	.1698	.1509	.1663	.1867	.1886
24	.132	.1132	.112	.1509	.1132	.1494	.1478
Max	.2452	.2195	.2641	.2263	.2241	.2195	.2263
Min	.0943	.0754	.0377	.1132	.0943	.0739	.0739
Avg	.1353	.1296	.1306	.1446	.1350	.1468	.1525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 205 / 11 KV BARVE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.1663	.1698	.1509	.1646	.1478
2	.1698	.1509	.168	.1698	.132	.1478	.1494
3	.1509	.1509	.1463	.1509	.132	.1307	.1478
4	.1509	.1509	.1463	.1509	.132	.1294	.1307
5	.1698	.1509	.1478	.1509	.1509	.1478	.1478
6	.1698	.1698	.1663	.1698	.1698	.168	.1663
7	.1886	.1886	.2033	.1698	.1886	.1848	.1663
8	.2263	.1886	.1663	.1886	.2452	.2033	.2218
9	.2641	.1698	.2054	.1886		.3109	.2402
10	.1886	.2033	.2054	.1509	.2075	.2378	.2241
11	.1886	.1867	.1509	.2452	.2195	.2263	.2075
12		.1848		.1509	.2054	.2263	.1886
13	.1886	.1848	.1509	.132	.2033	.1132	.1698
14	.1509	.1294	.132	.1509	.1494	.1132	.1698
15	.1886	.1494	.1509	.1509	.168	.2263	.1886
16	.1698	.1294	.132	.132	.1663	.1698	.2263
17	.1886	.1097	.1886	.2075	.2033	.2075	.1886
18	.1886	.1646	.1886	.2641	.168	.1886	.2075
19	.2452	.2587	.2452	.3018		.2587	.2452
20	.3395	.2957	.3395	.3206	.2587		.3018
21	.3018	.2587	.3018	.2641	.2587	.2587	.3018
22	.2641	.2402	.2641	.2452	.2402	.2241	
23	.2263	.2012	.2075	.1509	.2427	.2033	.2263
24	.1698	.1886	.2054	.1886	.1509	.1663	.1663
Max	.3395	.2957	.3395	.3206	.2587	.3109	.3018
Min	.1509	.1097	.132	.132	.132	.1132	.1307
Avg	.2026	.1823	.1904	.1902	.1883	.1916	.1970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 202 / 11 KV MHASARANG AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8006	2.7333		2.552			
2	2.7915	2.9194		2.3891			
3	2.7161	2.6578		2.2986			
4	2.6783	2.7873	2.6337	1.9547			
5	2.6595	2.6235	2.652	2.2624			
6	2.6406	2.7692		2.2119			
7	2.6406	2.4714	2.8292	2.2634			
8	2.452	2.3148	2.8349	2.1434			
9	.0754	.0943	.0934	.0905			2.2177
10	.0747	.0943		.0857	1.8347		1.9404
11	.0732	.0943	.0724		2.0576		2.1807
12	.0724	.0943	.0724	.0739	2.4177	3.0123	2.0062
13	.0732	.0566	.0701	.0739	2.4006	3.0862	2.0995
14	.0724	.0934	.0876	.0739		3.0123	1.9376
15	.0857	.0943	.0857		2.2291	2.6981	1.8519
16	.0895	.0754				2.6427	1.7318
17	.0857	.0732	.0724			.0739	.0724
18	.0895	.0943	.0905			.0716	.0514
19	.0905	.0914	.0857			.0924	.0724
20	.1086	.0943	.0905				.0724
21	.1086	.0914	.0857				.0724
22	.1052	.0943	.0905				
23	3.1131	3.0178	2.8054				.0686
24	2.9502	2.7092					
Max	3.1131	3.0178	2.8349	2.552	2.4177	3.0862	2.2177
Min	.0724	.0566	.0701	.0739	1.8347	.0716	.0514
Avg	1.1936	1.1766	.8678	1.4210	2.1879	1.8362	1.1697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 204 / 11 KV DONAWADE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3825	.3658	.1029			
2	.3395	.3429	.4715	.1086			
3	.3206	.3825	.4755	.1075			
4	.3206	.3801		.1086			
5	.3206	.3772	.4755	.1029			
6	.3206	.3814	.439	.12			
7	.3206	.3601	.415	.12			
8		.3601	.4024	.1086			
9	4.6776	5.036	4.6965	1.4918			
10	4.8544	5.0926		1.4918	.2058		
11	4.4324	4.6965		1.4969	.2058		.2772
12		4.6399		1.7556	.2743	.3511	.2401
13		4.4063		3.9582	.3086	.3361	.2353
14		4.4324	4.742	3.9548	.2401	.3142	.2534
15	4.4525	4.2798			.2401	.3142	.2715
16	4.1667	4.6776			.0857	.3547	.2572
17	.4525	.2641				.3696	2.1719
18	.4031	.3772	.1448			.3696	2.3529
19	.3509	.4904	.1448			.4066	.3258
20	.3772	.4527	.1448				.3086
21	.3856	.3772	.1991				.3403
22	.4572	.3584	.1629				
23	.3467	.4338	.1448				.2715
24	2.9235	.3813	.4338				
Max	4.8544	5.0926	4.742	3.9582	.3086	.4066	2.3529
Min	.3206	.2641	.1448	.1029	.0857	.3142	.2353
Avg	1.5281	1.8068	.8661	1.0734	.2229	.3520	.6088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 205 / 11 KV SHELOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.3825	.3658	.2566			
2	.1886	.3781	.3658	.2172			
3	.1886	.3719	2.652	.2151			
4	.1886	.3443	.1463	.1991			
5	.1886	.3443	.1463	.2172			
6	.1886	.3258	.1494	.2715			
7	.1886	.345	.1886	.3265			
8	.2263	.3624	.2195	.362			
9	.2263	.4527	.2263	.3624			.112
10	.2241	.5093		.3801	.12		.2218
11	.1886	.5281	.181	.3881	.1543		.462
12	.2172	.5281	.3258	.462	.1029	.3881	.4525
13	.2629	.5281	.362	.3881	.12	.4481	.362
14	.2353	.4527	.4525	.439	.2058	.3881	.4525
15	.3258	.439	.2534		.2743	.4435	.4887
16	.362	.4527					.4525
17	.3765	.4527	.2686			.462	.4525
18	.2537	.4527	.3582			.4435	
19	.4298	.5281	.4887			.499	.5068
20	.5447	.6413	.4344				.5979
21	.5014	.439	.5068				.5249
22	.4711	.415	.4163				
23	.4371	.4481	.3467				.3624
24	.2263	.3825	.4024		.2033		.0924
Max	.5447	.6413	2.652	.462	.2743	.499	.5979
Min	.1886	.3258	.1463	.1991	.1029	.3881	.0924
Avg	.2846	.4377	.4208	.3204	.1687	.4389	.3958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 206 / 11 KV KARADWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1991	.1886	.1448			
2	.1829	.1827	.1829	.1448			
3	.1886	.1802	.1886	.1449			
4	.1886	.1995	.1829	.1629			
5	.1886	.2177	.1829	.181			
6	.2075	.2172	.2263	.1991			
7	.2263	.1995	.2195	.2174			
8	.1886	.1629	.2263	.2151			
9	.1886	.1698	.2263	.1991			.2218
10	.2263	.1698		.181	.12		.1867
11	.132	.1886	.1991	.0934	.12		.1848
12	.1448	.1509	.2218	.2033	.2743	.2772	.1454
13	.1629	.1509	.2172	.1478	.2058	.2402	.1267
14	.1578	.1509	.1448	.1478	.2058	.2427	.1402
15	.1791	.1494	.1227		.2058	.2957	.181
16	.1402	.1463					.1993
17	.1653	.2263	.1821			.2218	.2353
18	.1636	.2263	.1991			.2402	.2353
19	.2715	.2263	.181			.3326	.2686
20	.3439	.3292	.3258				.2896
21	.3292	.3395	.2808				.2896
22	.2868	.3018	.2279				
23	.2174	.1886	.1991				.1991
24	.2263	.2181	.1886				.1294
Max	.3439	.3395	.3258	.2174	.2743	.3326	.2896
Min	.132	.1463	.1227	.0934	.12	.2218	.1267
Avg	.2040	.2038	.2052	.1702	.1886	.2643	.2022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044] BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 207 / 11 KV NANDOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 201 / 11 KV MINCHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3803		.4001	.362	.3429	.3077	.3416
2	.3803	.362	.381	.3239	.3429	.3077	.3232
3	.3795	.3439	.381	.3048	.3429	.2896	.3226
4	.3791	.3982	.381	.3429	.3429	.3439	.3232
5	.3993	.4163	.381	.381	.362	.362	.3423
6	.4183	.4344	.4191	.4001	.362	.3681	.3985
7	.4373	.4706	.5144	.381	.4001	.3982	.436
8	.436	.4525	.4763	.381	.3048	.362	.4563
9	.436	.4572	.4382	.362	.3429	.3982	.4753
10	.4373	.4382	.2667	.3048	.3658	.4344	.4344
11	.2561	.4572	.5144	.3429	.3658	.362	.4344
12		.4191	.4763	.3429	.3475	.3993	.362
13	.2926	.3048	.4001	.3429	.3841	.3803	.3439
14	.362	.381	.3429	.381	.3982	.4373	.3258
15	.3982	.4382	.3239	.381	.4525	.3993	.3439
16	.4344	.4191			.462	.3803	.3077
17	.4163	.4382			.6036	.4373	.3292
18	.3982	.4001	.3239	.5335	.4163	.4944	.3841
19	.6516	.6097	.6287	.743		.7606	.4344
20	.724	.7049	.7049	.6668			.543
21	.6154	.5716	.5906	.5525	.543		.5249
22	.5487	.5335	.5335	.4763	.4344	.4944	.2715
23			.4382	.4001	.362	.3993	.3258
24	.3993	.362	.4191		.362	.3077	.3423
Max	.724	.7049	.7049	.743	.6036	.7606	.543
Min	.2561	.3048	.2667	.3048	.3048	.2896	.2715
Avg	.4355	.4460	.4425	.4146	.3928	.4011	.3803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 202 / 11 KV HEDEWADE AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4934	.9593	.2096	.4001	.1715	.1629	
2	.4744	.9412	.1905	.3239	.1715	.1578	
3	.4744	.9231	.724	.3429	.1715	.1629	
4	.5308	.905	.724	.4191	.1715	.1629	
5	.6072	.8326	.8002	.4763	.1715	.1448	
6	.7415	.7964	.1715	.5716	.1715	.1448	
7		.7421	1.1622	.6097	.1715	.1448	
8	.4183	.543	.9907	.4001	.1905	.1448	
9	.1898	.1715	.2096	.1334	1.3336	.8326	
10	.181	.1715	.2096	.1334	1.0317	.6516	
11	.181		.1905	.1334	.7602	.5792	.4706
12	.181	.1905	.2096	.1524	.724	.5313	.4706
13	.1991	.1905	.2096	.1524	.6878	.3985	.3982
14	.2012	.1905	.2096	.1905	.5792	.3795	.3801
15	.1991	.1905	.1905	.1905	.6154	.4175	.3801
16	.1991	.1905			.4887	.3416	.2896
17	.1991	.1905			.4525	.1328	.0905
18	.1991	.2096		.0953		.1331	.0905
19	.1991	.2096	.1715	.0953		.1331	.1086
20	.1991	.2096	.1524	.1905			.1086
21	.1991	.1905	.1524	.1715	.1448		.1086
22	.1991	.1905	.1524	.1715	.1448		.1086
23	1.1584	1.0669	.5716	.1715	.1629		.1086
24	.5308	.8688	.1524		.1715	.1629	
Max	1.1584	1.0669	1.1622	.6097	1.3336	.8326	.4706
Min	.181	.1715	.1524	.0953	.1448	.1328	.0905
Avg	.3546	.4815	.3693	.2631	.4137	.2960	.2395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 203 / 11 KV NILPAN AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1711	.181	.1905	.0381		.0181	
2	.1711	.181	.1905	.0381		.0181	
3	.1711	.181	.1905	.0381		.0181	
4	.1711	.181	.1905	.0381		.0181	
5	.1896	.181	.1905	.0381		.0181	
6	.1901	.1629	.1905	.0381		.0181	
7	.6084	.1629	.2096	.0381		.0181	
8	.2092	.181	.2096	.0381		.0181	
9	2.2938	3.1055	3.1436	.5144		.0181	
10	2.5339	3.0293	3.1245	.1334	.0181		
11	2.7873	3.2007	3.0483	1.2193	.0181	.0362	.0362
12	2.6244	3.1245	2.9531		.0181	.038	.0724
13	2.4253	3.0102	2.915	1.3908	.0181	.038	.0724
14		2.8387	2.6482	1.848	.0181	.038	.0543
15	2.6606	2.7054	2.2672		.0181	.0761	
16	2.6425	2.5149			.0181	.0758	.0362
17	.1991	.1905			.0181	.0761	.0362
18	.1991	.2477	.0381		.0181	.0951	.0362
19	.181	.2667	.0381			.0761	.0362
20	.181	.2477	.0381				.0362
21	.181	.2286	.0381		.0181		.0362
22	.181	.2286	.0381		.0181		.0362
23	.1629	.1905	.0381		.0181		.0362
24	.1711	.181	.1905			.0181	
Max	2.7873	3.2007	3.1436	1.848	.0181	.0951	.0724
Min	.1629	.1629	.0381	.0381	.0181	.0181	.0362
Avg	.9263	1.1134	1.0037	.4162	.0181	.0384	.0437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 201 / 11 KV DASEWADI AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	2.2611		1.9805			
2	2.2068	2.2436		1.7918	.1595		
3	2.0725	2.191	1.6632	1.6975			
4	1.9805	2.0805	1.6804	1.6975	.1578		
5	1.9791	2.0458	1.8484				
6	2.0165	2.0111			.1578		
7	2.0748	1.9161	1.9616	1.8861			
8	1.9993	1.8625	2.1691	1.8861	.1612		.1646
9	.2075	.1791	.2218	.1867	1.6124		1.7353
10	.1905	.1753			1.9631	2.2068	1.9427
11		1.848	.2033	.1886	2.0936	2.2068	2.0351
12	.2096	.2075	.197	.1848		2.1691	1.8298
13	.2096	.2286	.1867	.181	1.9616	2.0748	1.7177
14	.2096	.2263	.1698	.181	1.7164	2.0748	1.7187
15	.2075	.2286	.1886	.2054	1.6632	1.9805	
16	.2054	.2477			1.7353	1.9427	
17	.2033	.2452	.181		.1715	.1417	
18	.1949	.2452	.1848	.1829	.1753	.1433	
19	.2075	.2452	.1886			.1509	
20	.2286	.2477	.1886				
21	.2263	.2452	.1886				
22	.2477	.2452	.1886			.1698	
23	2.3167	2.1691		.1578		.1663	
24	2.2592	2.3529		2.0748	.1578		
Max	2.3167	2.3529	2.1691	2.0748	2.0936	2.2068	2.0351
Min	.1905	.1753	.1698	.1578	.1578	.1417	.1646
Avg	1.0389	1.0812	.6829	.9655	.9919	1.2856	1.5920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBAL SUBSTATION

Feeder No / Name : 202 / 11 KV PATGAON VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1052	.1433	.1509		.1646	.1463
2	.1698	.1052	.1254	.1307	.1402	.1433	.1463
3	.168	.1052	.132	.132		.1433	.1294
4	.1886	.1387	.132	.132	.1595	.1791	.1829
5	.2241	.1734	.1509	.1848		.2172	.1829
6	.2614	.208	.1848	.2587	.2103	.2427	.2587
7	.2829	.2204	.2452	.2641		.2427	.2743
8	.3206	.3582	.2829	.2641	.3224	.3121	.2743
9	.3018	.3224	.2641	.3018	.3121	.3142	.2829
10	.3239	.3155			.2629	.3395	.3395
11		.3239	.2587	.2641	.2452	.2829	.2427
12	.2667	.2263		.2218	.2263		.2427
13	.2286	.2452	.2402	.181		.2829	.2241
14	.2286	.2452	.2452	.1991	.1509	.2641	.2033
15	.2263	.2286	.2402	.2241	.1663	.2452	.2195
16	.2427	.2075			.2263	.2452	.2054
17	.2218	.2427	.2402		.2401	1.5238	.2715
18	.2303	.2587	.2378	.2561	.1928	.3475	.2686
19		.3772	.3772			.415	.3475
20	.4382	.4191	.4382				.4382
21	.4338	.415	.4338		.381		
22	.381	.381	.3772		.3239	.3018	
23	.2172	.2987		.2279	.2614		.3174
24	.1867	.1448	.2149	.1886	.1753	.1629	.1463
Max	.4382	.4191	.4382	.3018	.381	1.5238	.4382
Min	.168	.1052	.1254	.1307	.1402	.1433	.1294
Avg	.2596	.2528	.2482	.2107	.2351	.3185	.2429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 203 / 11 KV SHIVDAV AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1227	.1254	.132		1.2254	
2	.1132	.1214	.1254	.132	1.0166	1.2437	
3	.1307	.1227	.1294	.132		1.2178	
4	.132	.1227	.132	.132	1.0454	1.2894	
5	.1307	.1214	.132			1.3032	
6	.1307	.1214	.132		1.0517	1.3817	
7	.132	.1187	.132			1.3523	
8	.132	.1254	.132		.1254	1.2483	
9	1.9993		1.773	1.9427	.1214	.1294	.128
10	2.0767	1.6126			.1227	.1132	.132
11	2.0957	1.848		1.9427	.132	.132	.0747
12	1.9624	1.8861		1.5524		.1307	.0747
13	2.0005	1.9052		1.7013	.1132		.0934
14	1.9624	1.8861	1.905	1.6651	.1132	.1132	.0924
15	1.9616	1.8861	1.8665	1.6617	.1109	.1132	.0732
16	1.7364	1.7528			.0943	.1132	.0747
17		1.7177	.1294		.1029	.1075	.0724
18	.1417		.1294	.1097	.1052	.128	.0716
19	.1509		.1334			.1509	.1097
20	.1524	.1509	.132				.1334
21	.1509	.1715	.1509		.1334		
22	.1524		.1509		.1334	.1509	
23	.1267			1.0867	.1307		
24	.112	.1267	.1254	.132	1.0166	.1267	
Max	2.0957	1.9052	1.905	1.9427	1.0517	1.3817	.1334
Min	.112	.1187	.1254	.1097	.0943	.1075	.0716
Avg	.7737	.8379	.4187	.9479	.3335	.5885	.0942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBAL SUBSTATION

Feeder No / Name : 402 / 33 KV PATGAON SHP

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.6836	.6447	.679
2	.6224	.6836	.6447	.679
3	.6161	.6836	.679	.679
4	.679	.6762	.679	.679
5	.6161	.6762	.679	.679
6	.6161	.6762	.679	.5601
7	.679	.6104	.679	.6224
8	.679	.6447	.7356	.5658
9	.679	.6984	.679	.6224
10	.743	.6836		.6224
11	.743	.743		.679
12	.6859	.7356	.5544	
13	.6859	.679	.7762	
14	.6287	.679	.679	
15	.6859	.6287	.6584	
16	.6722			
17	.5544	.5601		
18	.5316	.6099	.5544	
19	.5658	.6224	.5658	
20	.5716	.6287	.5716	
21	.5658	.6287	.5658	
22	.6287	.6859	.5658	
23	.6516	.679		
24	.6722	.6516	.6447	.6224
Max	.743	.743	.7762	.679
Min	.5316	.5601	.5544	.5601
Avg	.6412	.6630	.6440	.6408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 201 / SILVER ZONE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0381	.0366	.0373	.0381	.0366	.0366
2	.0183	.0381	.0366		.0381	.0366	.0366
3	.0187	.0381	.0366	.0373	.0381	.0183	.0183
4	.0187	.0381	.0366	.0373	.0381	.0183	.0185
5	.0187	.0191	.0366	.0373		.0183	.0185
6	.0187	.0191	.0366	.0373	.0381	.0183	.0185
7	.0187	.0191	.0358	.0187	.0381	.0362	.0185
8	.0187	.0191	.0181	.0187	.0191	.0362	.0183
9	.0189	.0179		.0191	.0181		.0181
10	.0191	.0181	.0187	.0189	.0362	.0187	.0358
11	.0191	.0358	.0187	.0377	.0362	.0187	.0358
12	.0191	.0358	.0187	.0377	.0362	.0373	.0362
13	.0191	.0362		.0377	.0362	.0373	.0177
14	.0191	.0362	.0187	.0377	.0362	.0187	.0362
15	.0191	.0362	.0187	.0381	.0362	.0179	.0362
16	.0191	.0366		.0191	.0362	.0181	.0362
17	.0191	.0183	.0187	.0191	.0185	.0181	.0362
18	.0191	.0185	.0187	.0191		.0181	.0181
19	.0381	.037	.0187	.0381			.0366
20	.0381	.037	.0187	.0381	.0366		.037
21	.0381	.0373	.0187	.0381	.0366		.0366
22	.0381	.0373	.0373	.0381	.0366	.0181	.037
23	.0381	.0366	.0328	.0381	.0366	.0362	.0366
24	.0187	.0381	.0366		.0381	.0366	.0366
Max	.0381	.0381	.0373	.0381	.0381	.0373	.037
Min	.0183	.0179	.0181	.0187	.0181	.0179	.0177
Avg	.0229	.0309	.0270	.0318	.0344	.0256	.0296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 202 / HUPARI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0985	1.134	1.2803	1.0985	1.0679	1.086
2	1.0974	1.0631	1.1157	1.2803	1.0631	.9774	1.086
3	1.0974	1.0208	1.0791		.9922	.9694	.9145
4	1.0974	.9492	1.0242		1.0099	.9145	.9145
5	1.0974	.9492	1.0349	.7682	1.0099	.9328	.9145
6	1.0974	.9922	1.0791	.7682	1.0277	.9231	.9328
7	.9328	.9745	.9391	1.0608	.9745	.905	.9511
8	.9694	.9568	.9671	1.0242	.9568	.4887	.9412
9	1.0099	.9955		1.0277	.9955		1.0029
10	1.0454	1.2536		1.1871	1.2536	1.2071	1.1517
11	1.1163	1.4506	1.2803	1.4198	1.4864	1.2071	1.2894
12	1.1694	1.4842	1.4632	1.4373	1.6108		1.379
13	1.134	1.379	1.4998	1.3847	1.4299		1.2934
14	1.0808	1.1641	1.4998	1.3146	1.3253		1.2357
15	1.1694	1.3611	1.5466	1.4022	1.4661	1.267	1.2403
16	1.1869	1.4148		1.4373	1.5729	1.267	1.4685
17	1.1871	1.4118	1.5729	1.4352	1.5043	1.379	1.5043
18	1.1694	1.3969	1.5729	1.4352			1.4083
19	1.5775	1.5223	1.5729	1.5769			1.5023
20	1.5249	1.4506	1.5364	1.4706		1.0745	
21	1.4548	1.4118	1.4632	1.4175	.6335	1.3575	
22	1.4175	1.3756	1.4632	1.2757	1.267	1.267	
23	1.2757	1.3253	1.3535	1.2403	1.1706	1.1041	1.3394
24	1.0974	1.1517	1.2437	1.2803	1.1694	1.1403	1.086
Max	1.5775	1.5223	1.5729	1.5769	1.6108	1.379	1.5043
Min	.9328	.9492	.9391	.7682	.6335	.4887	.9145
Avg	1.1710	1.2314	1.3067	1.2693	1.1913	1.0805	1.1734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 203 / YALGUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.0164	.0177	.0162	.5992	.5144	.0514
2	.0162	.0164	.0175	.0162	.5668	.4917	.052
3	.0162	.0164	.0175	.0162	.5735	.4917	.0526
4	.0324	.0164	.0175	.0162	.5668	.5087	.0526
5	.0324	.0164	.0175	.0162	.5992	.503	.0526
6	.0324	.0164	.0347	.0162	.6802	.5426	.0526
7	.0486	.0164	.0171	.0162	.0324	.6133	.0526
8	.0486	.0164	.0175	.0162	.0324	.547	.0514
9	.9393	1.0562		.9602	.0173		.0175
10	.9878	1.0774	1.004	.9282	.0347	.0162	.0177
11	.9717	1.073	1.004	.9442	.0168	.0162	.0171
12	.7773	.8535	.9717	.8002	.0173	.0162	.0168
13	.7449		.9069	.8162	.0171	.0162	.017
14	.7449		.9069	.8642	.0171	.0162	
15	.8097		.8097	.8482	.0171	.0171	
16	.7935	.9326	.7449	.8162	.0171	.0171	
17	.0486	.8987	.0324	.0328	.0171	.0171	
18	.0486	.8383	.0324	.0328		.0173	.4973
19	.0324	.0343	.0162	.0328			.0175
20	.0164	.0343	.0162	.0328			.0175
21	.0164	.0351	.0164	.0328			.0177
22	.0164	.0351	.0162	.0328	.0351	.0171	.0354
23	.0164	.0173	.0162	.6316	.0351	.0171	.0351
24	.0164	.0164	.0177	.0162	.6556	.0351	.0171
Max	.9878	1.0774	1.004	.9602	.6802	.6133	.4973
Min	.0162	.0164	.0162	.0162	.0168	.0162	.0168
Avg	.3010	.3349	.2899	.3313	.2274	.2216	.0571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 204 / RENDAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.8861	1.8099	1.4746	1.5242	1.4022	1.0402
2	1.3108	1.6975	1.6289	1.4746	1.5242	1.4022	1.0517
3	1.3108	1.3336	1.448		1.5242	1.2403	1.0631
4	1.3108	1.3336	1.448	1.4746	1.5242	1.448	1.0631
5	1.5729	1.3336	1.4327	1.4746	1.5242	1.448	1.086
6	1.4746	1.5242	1.6461	1.4746	1.5242	1.4327	1.086
7	1.6385	1.6975	1.7909	1.4746	1.5242	1.6118	1.4327
8	1.9662	1.6975	1.949	1.4746	1.5089	1.949	1.7909
9	2.572	2.572		1.5089	2.2043		2.6292
10	2.3137	2.915	2.4577	1.5089	2.5434	2.6216	2.572
11	2.713	2.7435	2.2939	1.5089	2.6825	2.6216	2.7435
12	2.572	2.7435	2.2939	1.3203	2.4006	2.2939	2.2291
13	2.0328	1.5947	1.4746	1.3203	1.7147	1.6385	1.5947
14	1.5089	1.4022	1.9662	1.3203	1.3565	1.4746	1.7909
15	2.5149	2.572	2.2939	1.3336	2.572	2.0576	2.572
16	2.6825	2.915	2.6216	1.3336	2.7435	2.7435	2.8502
17	2.5434	2.774	2.6216	1.3336	2.7435	2.8502	2.7435
18	2.5149	2.8045	2.2939	1.3336		2.4006	
19	2.5606	2.4539	2.2939	1.5242			2.1033
20	2.0748	2.1033	1.8023	1.5242	1.2269		2.1262
21	2.0748	2.1719	1.8023	1.5242	1.7528	1.0402	1.949
22	2.0748	2.1491	1.8023	1.5242	1.7718	1.0517	1.949
23	2.0748	2.1491	1.8023	1.5242	1.7528	1.2403	1.97
24	1.6385	1.8861	1.97	1.6385	1.5242	1.6118	1.0288
Max	2.713	2.915	2.6216	1.6385	2.7435	2.8502	2.8502
Min	1.3108	1.3336	1.4327	1.3203	1.2269	1.0402	1.0288
Avg	2.0151	2.1022	1.9541	1.4523	1.8713	1.7895	1.8463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 207 / HUPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	1.6832		.0532	.037	.0177	.0177
2	1.4175	1.6651		.0532	.037	.0179	.0175
3	1.4175	1.6289	1.749	.0532	.037	.0179	.0177
4	1.4175	1.6289	1.7703	.0532	.037	.0181	.0177
5	1.4175	1.6832	1.7703	.0532	.037	.0181	.0179
6	1.7364	1.828		.0532	.037	.0181	.0179
7	1.6301	1.7556	1.8519	.0532	.037	.0179	.0177
8		1.7737	1.7833	.0532	.037	.0354	.0177
9	.037	.0532		1.8642	1.5604		.0177
10	.037	.0526	.0532	1.8099	1.6975		.0177
11	.037	.0526	.0532	1.9004	1.6956	1.4706	.7545
12	.037	.0532	.0532	1.7556	1.166	1.4175	1.046
13	.037	.052	.0532	1.7918	1.6975	1.3998	1.0117
14	.0354	.052	.0532	1.9547	1.7147	1.3289	1.0117
15	.0554	.0514	.0532	1.8461	1.7833	1.2003	.9945
16	.0554	.0526	.0532	1.7194	1.858	1.3203	.9602
17	.0554	.4508	.0532	.037	.0358	.0175	.0347
18	.0554	.0526	.0532			.0177	.0175
19	.0549	.0514	.0532	.1663			.052
20	.0732	.052	.0532	.1663		.0177	.0526
21	.0739	.0709	.0549	.037		.0177	.0532
22	.0739	.0701	.0532	.037	.0171	.0177	.0537
23	1.7737	1.8519	.0532	.037	.0179	.0179	
24	1.6478	1.7194		.0532	.037	.0177	.0175
Max	1.7737	1.8519	1.8519	1.9547	1.858	1.4706	1.046
Min	.0354	.0514	.0532	.037	.0171	.0175	.0175
Avg	.6422	.7661	.5090	.6783	.6788	.4011	.2712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 208 / BIRDEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.8421		.0328	.0328		.0171
2	.6882	.8097		.0328	.0328		.0171
3	.6882	.7611	.8383	.0328	.0328		.0171
4	.7537	.7611	.823	.0328	.0328		.0171
5	.7537	.7773	.823	.0328	.0328		.0171
6	.6554	.8097		.0328	.0381		.0171
7	.7865	.8421	.8718	.0164	.0328		.0171
8	.7865	.8097	.9054	.0328	.0328		.0171
9	.0328	.0171		.9762	1.0562		.6516
10	.0328	.0171	.0164	1.0402	1.1105		.7377
11	.0328	.0171	.0164	1.0562	1.1437	.8192	.7291
12	.0328	.0343	.0164	1.0402	1.073	.9831	.6718
13	.0164	.0514	.0164	.9922	1.1233	.9339	.7209
14	.0164	.0514	.0328	.9442	1.1271	.9012	.663
15	.0164	.0171	.0328	.8962	1.1105	.9116	.547
16	.0164	.0343	.0492	.8642	1.1105	.8951	.5407
17	.0328	.0343	.0492	.0324		.8356	.0171
18	.0328	.052	.0164	.0328		.6796	.0171
19	.0328	.0347	.0164	.0328			.0347
20	.0328	.0347	.0164	.0328		.0166	.0343
21	.0328	.0526	.0164	.0328		.0171	.0343
22	.0492	.0526	.0328	.0328		.0171	.0343
23	.8745	.9665	.0328	.0328		.0173	.052
24	.6554	.8421		.0328	.0328		.0171
Max	.8745	.9665	.9054	1.0562	1.1437	.9831	.7377
Min	.0164	.0171	.0164	.0164	.0328	.0166	.0171
Avg	.3211	.3634	.2433	.3466	.5385	.5856	.2350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 201 / PATTANKODOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8298		.0747	.0747	
2		1.8298		.0747	.0747	
3		1.8484	1.7556	.0747	.0747	
4		1.8671	1.7364	.0747	.0716	
5		1.9044	1.7556	.0747	.0934	
6		1.9418		.0747	.0747	
7		1.9418	2.2177	.0747	.0747	
8		1.8298	2.1658	.0747	.0747	
9		.1307	.0739	2.0513	2.9687	
10		.056		2.3152	3.2674	
11	.0343	.0514		2.7446	2.7263	.9431
12	.0343	.0514		3.0434	2.8807	1.3375
13	.0343	.0343	.0343	3.062	2.7092	1.3375
14	.0343	.0343	.0343	3.0247	2.7092	1.3375
15	.0343	.0343	.0343	2.9874	2.572	1.1317
16	.0343	.0343	.0343	2.8193	2.5034	1.1317
17	.0343	.0343		.0716	.0343	1.1317
18	.0686	.0343	.0343	.0716		1.0117
19	.0686	.0934	.0747	.0716		.056
20	.0905	.0934	.0747	.0716		.056
21	.0724	.0934	.0747	.0716		.0554
22	.0724	.0934	.0747	.0716		.0554
23	1.905	2.2177	.0747	.0747		.0554
24		1.8484		.0747	.0747	
Max	1.905	2.2177	2.2177	3.062	3.2674	1.3375
Min	.0343	.0343	.0343	.0716	.0343	.0554
Avg	.1937	.8303	.6406	.9677	1.2811	.7416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 202 / 11 kV INGALI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0373	1.4003	1.307		.0362
2		.0377	.037	1.3443	1.2696		.0362
3		.0373	.037	1.307	1.2696		.0362
4		.0373	.0373	1.307	1.2696		.0362
5		.0373	.0373	1.363	1.2696		.0362
6		.0373	.0373	1.4377	1.307		.0362
7		.0373	.056	1.4563	.0373		.0362
8		.0377	.056	1.3817	.0373		.0543
9		1.8858	1.922	.0554	.0377		.5373
10		2.0911		.056	.0373		.543
11	1.8176	1.8861		.0373	.0343		.4287
12	1.8176	1.8004		.0377	.0343		.4115
13	1.7833		1.8861	.0373	.0343		.4115
14	1.6461		1.9547	.0373	.0343		.4115
15	1.6118		1.8519	.0373	.0343		.3429
16		1.7147		.0373	.0343		.2572
17	.0171	.8402		.0373	.0343		.1715
18	.0171	1.7147	1.2003			.0362	
19	.0343	.0373	.056				.0373
20	.0362	.056	.056	.0358			
21	.0362	.056	.056	.0358		.0358	.037
22	.0343	.056	.056	.037		.0358	.037
23	.0377	.0373	1.363	1.3073		.0362	.037
24		.0377	.0373	1.3817	1.307		.0362
Max	1.8176	2.0911	1.9547	1.4563	1.307	.0362	.543
Min	.0171	.0373	.037	.0358	.0343	.0358	.0362
Avg	.7408	.5959	.5671	.6440	.5216	.036	.1822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 203 / 11 kV SANGWADE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.132	.1307	.1307	1.4937		
2		.1307	.1294	.1307	1.4937		
3		.1307	.1307	.1307	1.4937		
4		.1307	.1307	.1307	1.4937		
5		.1494	.1294	.1307	1.7924		
6		.1494	.1478	.1494	2.0351		
7		.1494	.1663	.168	.168	2.0233	
8	.0857	.1494	.168	.1867	.1494		
9	2.8635	2.8567	3.0123	2.6612	.1494		
10	2.7092	2.6699		2.8193	.1494		
11	2.6578	2.1948		2.7446	.1372		
12		2.452		2.5579	.1372		
13	2.4006		2.692	2.2592	.1372		
14	2.2291		2.692	2.0911	.1372		
15	2.2634		2.4006	2.0538	.1372		
16	2.0576	2.6235	2.3834	2.0351	.1372		
17	.1372	1.5089		.1433	.1372		
18	.1372	1.5947	.12	.1433			1.2689
19	.1372	.1494	.1494	.1433			.1494
20	.1629	.1494	.168	.1254			.168
21	.1448	.1494	.1494	.1254	.1267		.1478
22	.1448	.1494	.1494	.1433	.1267		.1478
23	.132	.1494	.1307	1.587	.1267		.1294
24		.132	.1307	.1307	1.531	.1267	
Max	2.8635	2.8567	3.0123	2.8193	2.0351	2.0233	1.2689
Min	.0857	.1307	.12	.1254	.1267	.1267	.1294
Avg	1.1511	.8524	.7655	.9551	.6329	1.075	.3352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 204 / 11 KV INGALI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1494	.1294	.1494	.1494		.1086
2		.1509	.1307	.1494	.1494		.1086
3		.1494	.1307	.1494	.1494		.1086
4		.1494	.1307	.1494	.1494		.1086
5		.168	.1478	.1867	.168		.1267
6		.168	.1663	.2054	.1867		.1448
7		.1494	.168	.1494	.1494		.1448
8		.1494	.1494	.168	.1494		.1267
9		.1307	.1294	.1663	.1494		.1433
10		.1494		.1494	.1494		.1433
11	.1372	.1372		.168	.1372	.1029	.1543
12		.1372		.1307	.1372	.1029	.1543
13		.1715	.1886	.168	.1543	.1029	.1543
14		.1543	.1715	.1494	.1543		.1543
15		.1543	.1886	.1494	.1543	.2058	.1715
16		.1715	.1886	.1494	.1543	.1886	.1715
17	.1372	.12		.1254	.0343	.1715	.1715
18	.0895	.1029	.1715	.1433		.1448	.2058
19	.1372	.1867	.2054				.2054
20	.1448	.2241	.2241	.2149			.2402
21	.181	.2054	.2241	.1791		.181	.2033
22	.181	.2054	.2054	.1791		.1629	.2033
23	.1698	.1848	.1867	.1791		.1448	.1848
24		.1698	.1494	.1494	.168		.2427
Max	.181	.2241	.2241	.2149	.1867	.2058	.2427
Min	.0895	.1029	.1294	.1254	.0343	.1029	.1086
Avg	.1472	.1600	.1693	.1612	.1469	.1508	.1617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 205 / 11 KV SANGAWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4481	.4668	.4668	.4854		.4344
2		.4481	.4066	.4668	.4668		.4344
3		.4294	.462	.4668	.4668		.4344
4		.4481	.4668	.4668	.4668		.4344
5		.4854	.4668	.4668	.4854		.4706
6		.5041	.5788	.5601	.5228		.5068
7		.4854	.4854	.5228	.5041		.4344
8		.3921	.4668	.4481	.4481		.4344
9		.4108	.4435	.4294	.4668		.4298
10		.4294		.3921	.4108		.4477
11	.3772	.3772		.3921	.4115	.4287	.4115
12	.3772	.3772		.4294	.4115	.4115	.4115
13	.3429	.3944	.3429	.4294	.4458	.4115	.4115
14	.3772	.4115	.3429	.4668	.4458		.4115
15	.3772	.4115	.3772	.4854	2.2805	.4458	.4115
16	.4115	.4458	.3772	.4854	.4458	.4458	.4115
17	.4458	.4458		.4298	.4458	.4458	.4458
18	.3429	.4801	.4801	.5014		.5249	.4458
19	.4287	.5975	.6348	.5373			.5975
20	.5973	.6722	.5975	.7164			.6838
21	.5973	.6722	.6348	.6805		.6697	.6283
22	.543	.6283	.6161	.5731	.6401	.5611	.5914
23	.4904	.5601	.5601	.5041	.5249	.4706	.5914
24		.4715	.4668	.5041	.5041		.6908
Max	.5973	.6722	.6348	.7164	2.2805	.6697	.6908
Min	.3429	.3772	.3429	.3921	.4108	.4115	.4115
Avg	.4391	.4761	.4837	.4926	.5640	.4815	.4835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 206 / 11 KV PATTANKODOLI VLG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7842	.7842	.7842	.7468		.6516
2		.7842	.7468	.7468	.7842		.6154
3		.7842	.7468	.7468	.7842		.6154
4		.8029	.7468	.7468	.7842		.6516
5		.8402	.7842	.7468	.8402		.7059
6		.8775	.8215	.8402	.8962		.7682
7		.8402	.7842	.8402	.9149		.724
8		.7282	.7095	.7468	.8029		.6697
9		.8029	.7392	.6653	.7842		.6626
10		.8402		.8029	.8029		.7522
11	.6516	.7202		.9335	.7545		.6859
12	.6173	.6859		.8589	.7545		.6859
13	.6173	.7202	.9602	.8402	.823		
14	.6516	.7202	.583	.8589	.823	.6173	.6859
15	.6516	.7202	.6173	.8962	.823		.6859
16	.6516	.7545	.6173	.8775	.7888		.6859
17	.6859	.7888		.9492	.823	1.0288	.7202
18	.8402	.823	.823	.9492		1.0679	.823
19	.9602	1.1016	.7282	1.0745			1.0642
20	1.1584	1.0829	1.2323	1.1999			1.1643
21	1.1222	1.1576	1.1763	1.0387		1.0317	1.0534
22	.9774	1.0456	1.0269	.8954		.905	1.0059
23	.9431	.8316	.924	.8589	.5487	.724	.924
24		.8299	.8402	.8402	.7655	.5068	1.1763
Max	1.1584	1.1576	1.2323	1.1999	.9149	1.0679	1.1763
Min	.6173	.6859	.583	.6653	.5487	.5068	.6154
Avg	.8099	.8361	.8196	.8641	.7918	.8402	.7903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 201 / 11 KV BRAMHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.12	.1132	1.7918		1.2125
2	.132	.132	.1227	.1132	1.8107		1.1961
3	.132	.1132	.132	.112	1.8107		1.166
4	.132	.1132	.132	.112	1.8296		1.1498
5	.1509	.1132	.132	.1307	1.8107		1.1822
6	.1509	.1132	.12	.1307	1.8107		1.247
7	.1307	.132	.132	.0754	.0716		1.2163
8	.1494	.1509	.0943	.1132	.0724		1.2492
9	2.2592	2.4025	2.2218	2.1472	.0754		.0314
10		2.4209	2.2592	2.1658	.0754		.0497
11	2.2218	2.2916	2.2218	2.2032	.0754	.0716	.0503
12	2.1472	2.2361	2.1845	2.1285			.056
13	2.1098		2.1285	2.0559		.0754	.0554
14	2.0725		2.0725	1.9993	.0566	.0754	.0554
15	2.0725		2.0538	1.9993	.0566	.0754	.0554
16	2.0725	2.0165	1.6255	1.9605	.0566	.0747	.0554
17	.0892	1.8861	.0678	.1075	.0503	1.9616	.0497
18	.104	1.9044	.0655	.1086		1.6004	.0503
19	.1147	.0829	.1006	.1075			.0995
20	.1417	.0886	.1075	.1075	.0739		.0995
21	.1433	.1227	.1075	.0739	.1097	.1294	
22	.1433	.124	.1075	.0739	.0934	.1294	
23	.1509	.1509	.1132	1.8107	.0924	.1307	.0838
24	.132	.132	.1387	.1132	1.8296	.0924	.1307
Max	2.2592	2.4209	2.2592	2.2032	1.8296	1.9616	1.2492
Min	.0892	.0829	.0655	.0739	.0503	.0716	.0314
Avg	.7428	.8028	.7734	.8360	.6827	.4015	.4792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 202 / 11 KV PANCHGANGA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8673	1.8673		1.773			
2	1.8673	1.8484		1.7353			
3	1.8296	1.8296	1.7918	1.6804			
4	1.8296	1.8107	1.8107	1.6244			
5	1.8484	1.8107	1.8296	1.643			
6	1.8484	1.8296		1.6804			
7	1.8671	1.7918	1.773	1.7353			
8	1.9605	1.7918	1.7353	1.7353			
9					1.8673	1.6108	1.358
10					1.9239	1.5384	1.326
11					2.0182	1.4327	1.291
12					2.0182	1.8296	1.4377
13					2.0748	1.7353	1.3817
14					2.0748	1.7541	1.3491
15					1.9805	1.773	1.3676
16					1.8111	1.7551	1.423
23	1.8861	1.8107	1.8107				
24	1.8673	1.905		1.8107			
Max	1.9605	1.905	1.8296	1.8107	2.0748	1.8296	1.4377
Min	1.8296	1.7918	1.7353	1.6244	1.8111	1.4327	1.291
Avg	1.8672	1.8296	1.7919	1.7131	1.9711	1.6786	1.3668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 203 / 11 KV RANGOLI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2829	.3772	.3772	.3206	.2957	.2622
2	.3206	.2829	.3506	.3584	.3018	.2772	.2458
3	.3206	.2641	.3206	.3547	.3018	.2587	.2267
4	.3206	.2641	.3206	.3547	.3395	.2587	.2105
5	.3395	.2829	.3584	.3734	.3206	.2772	.208
6	.3547	.3395	.3772	.4108	.3109	.3361	.2105
7	.3361	.4338	.3961	.3961	.3395	.3224	.2401
8	.3174	.3961	.3961	.3584	.2896	.2865	.2688
9	.3547	.4066	.4108	.3361	.2452	.3077	.3353
10		.4435	.4481	.3547	.3018		.3481
11	.3734	.462	.4854	.3734	.3395	.3403	.3018
12	.3361	.4435	.4294	.3547	.3584	.3772	.3361
13	.2054	.3563	.3921	.2829	.3206	.3772	.2241
14	.2241	.3688	.4108	.3018	.3395	.3772	.2957
15	.2801	.407	.4854	.3772	.3772	.415	.3326
16	.3547	.4481		.3547	.3734		.3881
17	.2824	.4715	.4409	.3582	.2347	.3961	.3315
18	.2675	.4668	.5243	.3801		.2881	.3315
19	.3113	.3978	.5197	.3921			.3521
20	.3366	.443	.4298	.3292	.2587		
21	.3403	.4557	.4477	.3326	.3658	.3696	
22	.3403	.4607	.4298	.3511	.3547	.3511	
23	.3395	.4904	.415	.3584	.3326	.3174	.3018
24	.3772	.3018	.3988	.3772	.3395	.3142	.3174
Max	.3772	.4904	.5243	.4108	.3772	.415	.3881
Min	.2054	.2641	.3206	.2829	.2347	.2587	.208
Avg	.3205	.3904	.4159	.3583	.3212	.3272	.2890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 201 / 11 KV YELGUD VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2353	.2987	.2241	.2614		.1905
2	.2667	.2195	.2801	.2054	.2353		.1905
3	.2667	.1991	.2801	.1867	.2149		.1886
4	.2477	.1991	.2829	.1867	.197		.1886
5	.2241	.1991	.2957	.2241	.2103		.181
6	.2126	.2172	.2172	.2641	.2481		.1753
7		.2012	.2279	.2614	.2172	.2427	.1844
8	.2378	.2058	.2401	.2572	.2172	.2454	.1677
9	.2801	.2279	.2155	.2241	.2279	.1886	.1578
10	.3429	.3185	.2818	.3315	.3681	.3155	
11	.3506	.3887	.3018	.3479	.3353	.3239	
12	.3467	.3563	.2743	.3637	.3521	.3052	
13	.2683	.362	.3601	.1265	.3521	.2572	
14	.2683	.3511	.3258	.3149	.3856		.3506
15		.3696	.3772	.3315	.3353	.2572	.3856
16	.2774	.2753	.2804	.3052	.3641	.2804	.333
17	.2427	.2591	.2915			.3239	.2641
18	.2229	.2561	.2915	.362		.3429	
19	.2947	.3239	.3395	.381			.2641
20	.2915	.4191	.3086	.362	.2915		.3239
21	.3086	.381	.3395	.362	.3048	.1905	.3018
22	.3206	.362	.3206	.3239	.3018	.1905	
23	.2804	.3429	.2427	.2534		.2096	
24	.2858	.2686	.0373		.2534		.2096
Max	.3506	.4191	.3772	.381	.3856	.3429	.3856
Min	.2126	.1991	.0373	.1265	.197	.1886	.1578
Avg	.2783	.2891	.2796	.2818	.2837	.2624	.2387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 202 / LAXMI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.3801		.0373	.0181		.0191
2	.2477	.362		.0373	.0181		.0191
3	.2286	.362	.3361	.0373	.0179		.0189
4	.2286	.362	.3395	.0187	.0177		.0189
5	.2427	.3982	.3511	.0187	.0177		.0181
6	.3898	.3982		.0187	.0179		.0175
7		.4359	.4908	.0187	.0181	.0175	.0168
8		.3429	.4287	.0171	.0181	.0175	.0168
9	.0187	.0175	.0166	.3841	.4733	.3429	.2804
10	.0343	.0168	.0166	.4641	.5258	.4207	.3239
11	.0347	.0324	.0168	.506	.503	.3887	.3277
12	.0173	.0324	.0171	.4744	.503	.373	.3481
13	.0168	.0181	.0343	.4902	.4862	.3601	.3125
14	.0168	.0185	.0171	.4973	.4527		.333
15	.0171	.0185	.0171	.4144	.4191	.3429	.3155
16	.0173	.0162	.0701	.4239	.4287	.333	.298
17	.0173	.0162	.0171			.0191	.0191
18	.0173	.0366	.0171	.0381		.0191	.0189
19	.0173	.0381	.0168	.0381			.0189
20	.0343	.0381	.0189	.0381	.0343		.0381
21	.0343	.0381	.0377	.0381	.0191	.0191	.0189
22	.3856	.0381	.0377	.0381	.0019	.0191	
23	.3856	.3429	.0373	.0181		.0191	
24	.2667	.394	.0373		.0181		.0191
Max	.3898	.4359	.4908	.506	.5258	.4207	.3481
Min	.0168	.0162	.0166	.0171	.0019	.0175	.0168
Avg	.1326	.1731	.1129	.1849	.2004	.1923	.1281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 203 / bajrang ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0351	.0373	.0373	.4252		.5335
2	.0381	.0362	.0373	.0373	.4161		.5335
3	.0381	.0181	.0373	.0373			.5281
4	.0572	.0362	.0377	.0373	.4207		.5093
5	.056	.0362	.037	.0373	.4784		.5068
6	.0532	.0362	.0362	.0373	.2328		.5434
7		.0335	.0351	.0373	.0181		.6203
8	.0366	.0343	.0343	.0343	.0181		.6706
9		1.0867	.9779	.9762	.0351		.0351
10	.8916	.9054	.7459	.9282	.0351	.5609	
11	1.1043	.8745	.8383	.8065	.0168	.5506	
12	1.0923	.8421	.7888	.6642	.0335	.0339	
13	.9556		.703	.6167	.0168	.0343	
14	.9389		.6859	.6464	.0335		.0351
15	.823		.7373	.6133	.0335	.0343	.0351
16	.8322	.7773	.7011	.6443	.0173	.0351	.0175
17		.6478	.0343			.0381	.0189
18	.0347	.7316	.0343	.0191		.0381	
19	.0347	.0381	.0377	.0381			.0377
20	.0343	.0572	.0377	.0381	.0343		.0381
21	.0343	.0572	.0377	.0381	.0381	.0381	.0377
22	.0377	.0572	.0377	.0381	.0377	.0381	
23	.0351	.0572	.0373	.0362		.0381	
24	.0381	.0358	.0373		.0362		.0381
Max	1.1043	1.0867	.9779	.9762	.4784	.5609	.6706
Min	.0343	.0181	.0343	.0191	.0168	.0339	.0175
Avg	.3431	.3064	.2819	.2909	.1251	.1309	.2788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 201 / GADMUDSHINGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1715	.1646	.1905	1.6766	1.8623	1.7147
2	.168	.1715	.2218	.1905	1.643	1.8299	1.7177
3	.1715	.1715	.2033	.2096	1.643	1.8299	1.6817
4	.1905	.1905	.2195	.2286	1.5089		1.6804
5	.1905	.1905	.2402	.2286	1.5089		1.7833
6	.1905	.1905	.2218	.2477		2.1445	2.0332
7	.1905	.1715	.2218	.2477	.1524	2.2245	2.1209
8	.2096	.1905	.2218	.2477	.1715	2.2405	1.9376
9	2.8121	2.5149	2.5316	2.3045	.1478	1.9113	
10	2.5316	2.4813	2.3975	2.1285	.2033	1.8275	
11	2.332	2.2466	2.364	2.2085	.2033	.1715	.1524
12	2.2969	2.1628	2.2634	2.2085	.2218		.1334
13	2.3663		2.0622	2.0485	.2033		.1524
14	2.1776		1.8945	1.9524	.2033		.1334
15	2.2462		1.9784	1.9524	.1848		.1334
16	2.0748	2.0622	1.9784	1.8351	.1848		.1524
17	.1334	2.0062		.1524	.2075		.1524
18	.1905	1.9204	.2286	.1524		.1663	.1524
19	.1715	.1829	.2096				.1715
20	.2096	.2402	.2096	.1905	.2263	.2772	.2096
21	.2096	.2402	.2477	.1715	.3174	.2957	.2286
22	.1905	.2218	.2286	.1524	.3206	.2587	
23	.1715	.2218	.2286	1.8107	.2829	.2957	.1905
24	.1524	.1715	.2033	.2286	1.7604	.2641	.2772
Max	2.8121	2.5149	2.5316	2.3045	1.7604	2.2405	2.1209
Min	.1334	.1715	.1646	.1524	.1478	.1663	.1334
Avg	.9054	.8629	.9018	.9256	.6177	1.1733	.8052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 202 / KALAMWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1029	.1109	.0934	.0995	.0754	.1109
2	.0934	.1029	.1109	.0934	.0995	.0754	.0924
3	.112	.1029	.0924	.112	.0995	.0754	.0924
4	.112	.1029	.0924	.112	.0995	.0754	.0924
5	.1132	.1029	.1097	.112	.0995	.0754	.1109
6	.1132	.1086	.1109	.1307	.1075	.0943	.1109
7	.0953	.0934	.1294	.112	.112	.0943	.1109
8	.0943	.0934	.1109	.1307	.112	.0754	.0924
9	.1097	.0934	.112	.1132	.1463	.056	.112
10	.1097	.1494	.1132	.1132	.1478	.0747	.5228
11	.0914	.1494	.132	.1886	.1294	.0934	.1494
12	.0924	.112	.132	.1886	.1478	.2427	.1494
13	.0914	.112	.1509	.168	.1478	.1494	.112
14	.0857	.112	.1509	.1494	.1294	.2614	.112
15	.0914	.1307	.132	.1886	.1294		.1307
16	.0857	.112	.1509	.132	.1294		.112
17	.0934	.1294		.1494	.1509	.1663	.0934
18	.0953	.1109	.1307	.1698		.0924	.112
19	.112	.1478	.1494	.1307	.132		.1307
20	.1307	.1294	.168	.1307	.0754	.1109	.1509
21	.132	.1294	.1494	.1509	.0943	.1294	.1494
22	.1334	.1109	.1307	.1147	.0943	.1109	
23	.1052	.1109	.1307	.116	.0943	.1109	.1307
24	.112	.1052	.0924	.112	.0995	.0754	.1109
Max	.1334	.1494	.168	.1886	.1509	.2614	.5228
Min	.0857	.0934	.0924	.0934	.0754	.056	.0924
Avg	.1041	.1148	.1258	.1338	.1164	.1102	.1344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 203 / GADMUDSHINGI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3921	.4108	.4294	.5658	.5415	.3734
2	.3734	.3734	.6161	.4294	.5228	.5228	.3921
3	.3734	.3696	.5975	.4527	.5228	.5041	.4481
4	.4108	.3696	.5788	.4904	.5601	.5228	.4294
5	.4854	.4294	.5975	.5228	.6161	.5228	.4854
6	.5041	.4668	.5228	.5975	.6979	.5975	.5228
7	.4854	.3921	.4854	.5788	.4904	.5228	.5601
8	.4527	.3734	.4108	.4481	.4294	.4481	.5228
9	.4294	.4294	.4294	.4294	.4854	.4294	.5228
10	.4108	.4294	.4338	.3734	.5975	.6161	.4481
11	.4108	.4481	.6036	.2641	.6348	.6348	.4527
12	.4294	.4108	.3772	.2641	.6161	.6161	.4338
13	.4294	.3361	.5093	.2614	.5975	.5975	.5847
14	.4481	.6161	.5847	.4108	.5975	.6224	.6036
15	.4668	.6348	.5847	.7282	.5228	.6535	.6224
16	.4108	.4338	.4338	.4668	.4294	.4854	.4904
17	.3734	.4481		.7167	.4715	.4668	.5041
18	.3921	.6161	.5975	.6979		.3361	.5601
19	.5041	.7842	.7095	.8029	.7655		.8029
20	.5847	.8215	.7655	.8676	.6908	.4668	.8029
21	.6224	.7282	.5788	.811	.6908	.7392	.7842
22	.5658	.6908	.7282	.7621	.7095	.5975	
23	.5041	.6722	.6722	.6859	.6161	.4066	.6722
24	.4854	.4108	.4481	.4854	.5365	.4854	.3921
Max	.6224	.8215	.7655	.8676	.7655	.7392	.8029
Min	.3734	.3361	.3772	.2614	.4294	.3361	.3734
Avg	.4568	.5032	.5511	.5407	.5812	.5363	.5396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 204 / sarnobatwadi ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3898	.4287		.0953	.0953	.1143	.0914
2	.4252	.4287		.0953	.0953	.0953	.0739
3	.4252	.4115	.4527	.0953	.0953	.0953	.0739
4	.4252	.4287	.4801	.0953	.0953		.0739
5	.4961	.4801	.4191	.1143	.1143	.1143	.0924
6	.5847	.5197		.1524	.1524	.1334	.0924
7	.567	.5197	.5197	.1334	.1524	.1334	.1109
8	.2835	.2743	.5868	.1524	.1905	.1524	.1109
9	.1663	.0953	.1524	.6642	.6401	.7265	.5658
10	.1294	.0953	.0953	.3113	.703	.7442	.6173
11	.1463		.1334	.6009	.6706	.7442	.6001
12	.1463	.0953		.5281	.6036	.691	.6173
13	.1097	.0953	.1143	.4801	.5383	.5847	.463
14	.0914	.1143	.0953	.4641	.4807	.5138	.3944
15	.128	.0953	.0953	.4801	.4694	.567	.4458
16	.1097	.1143	.1715	.4588	.4409	.5316	.5144
17	.0953	.0924			.2865	.1646	.0953
18	.0953	.0924	.1143			.1318	.0953
19	.0953	.1109	.1334	.1334	.0953		.1143
20	.1334	.1294	.1334	.1334	.0953	.0924	.0953
21	.1334	.1109	.1143	.1143	.0953	.1109	.0953
22	.1334	.1109	.1143	.1143	.1143	.0924	
23	.5316	.503	.1143	.1334	.1143	.0924	.1143
24	.3721	.4287		.1143	.1143	.1143	.0924
Max	.5847	.5197	.5868	.6642	.703	.7442	.6173
Min	.0914	.0924	.0953	.0953	.0953	.0924	.0739
Avg	.2589	.2511	.2244	.2575	.2806	.3064	.2452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 201 / EKONDI Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4863	.2236	.124	.2058	.1715
2	2.4863	.2227	.1417	.2058	.1387
3	2.4863	.2227	.1063	.2058	.1387
4	2.5377	.2236		.2058	
5	2.5377	.2236		.2058	
6	2.5377	.2241		.1715	
7	2.6063	.2598		.1715	
8	3.357	.2606	.1402	.2058	.1372
9	2.4863	3.8561		3.6866	.1402
10	2.652	3.5728		3.7723	.1407
11	2.7349	3.096	3.2579	3.6008	.2108
12		2.8706	3.1722		.2106
13	2.4291		2.9492		.2112
14	2.5101		2.915	2.5692	.2115
15			2.572	2.4939	
16	2.5606	2.9843	2.0576	2.6578	
17	.0732	2.8804	1.6461		
18	.1503		1.7147		
19	.2254	.1402	.2058		
20	.2627	.1417	.2058		
21	.2437		.1715	.1147	
22	.2236	.1433	.1715	.1357	
23	.2229				
24	2.4863	.2236	.1063	.1829	.1696
Max	3.357	3.8561	3.2579	3.7723	.2115
Min	.0732	.1402	.1063	.1147	.1372
Avg	1.8317	1.2094	1.2740	1.2230	.1710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 202 / Siddhanerli- Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	.0951	.1402	.1372	.1402
2	1.5432	.0949	.1417	.1372	
3	1.5432	.095		.1372	
4	1.5432	.0759		.1372	
5	1.5432	.0747		.1372	
6	1.5432	.0759		.1372	
7	1.7147	.0758		.1372	
8	1.5432	.0756	.1417	.1372	.1402
9		3.5608	.1433		
19			.1715		
20	.0948		.1715		
21	.0947		.1715	.1372	
22	.0951		.1715	.1402	
23	.0932				
24	1.5432	.0951	.1417	.1372	.1402
Max	1.7147	3.5608	.1715	.1402	.1402
Min	.0932	.0747	.1402	.1372	.1402
Avg	1.1106	.4319	.1550	.1375	.1402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 203 / 11KV Shendur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	2.1143		1.3717	.9054
2		2.1165		1.2003	.9054
3	.4458	2.0328	1.3565	1.2003	.9116
4		1.9364	1.3203	1.2003	.9282
5		1.9204		1.2003	.9724
6		1.8328		1.2003	1.0341
7	.4458	1.9284	2.0119	1.3717	
8	.4458	1.6512	1.7974	1.5432	.0701
9	.4458	.4658			1.9559
10	.431	.4656			2.4451
11		.4676			2.7788
12		.4671			2.7641
13		.4656			2.672
14		.4646		.3018	2.4118
15		.4656	.4458	.4207	
16	.3601	.4656	.4458		
17	.3544	.4656	.4954		
18	.394				
19	.4298	.4458	.4458		
20	.4656	.4458	.4458		
21	.4656		.4458	.3814	
22	.4656	.4115	.4458		
23	2.0348				
24	.4458	2.1216		1.3717	.9326
Max	2.0348	2.1216	2.0119	1.5432	2.7788
Min	.3544	.4115	.4458	.3018	.0701
Avg	.5384	1.1024	.8778	1.0636	1.5491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 204 / Sidhnerli Ekondi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5041	.4887	.5601	.5373
2	.4458	.5057	.4835	.5601	.543
3	.4458	.4894	.4706	.5144	.543
4	.4458	.5041	.4706	.5487	.4938
5	.4801	.5271	.5373	.5658	.5121
6	.5144	.5888	.5731	.6036	.5316
7	.4801	.5788		.5658	.5487
8	.4481	.5509	.5068	.6413	.5121
9		.6426		.6348	.5014
10	.543	.6218		.6001	.563
11				.6036	.6749
12			.7468		.7529
13			.7468		.6562
14			.5601	.5068	.5613
15			.4801	.5068	
16	.4706		.5228	.5175	
17	.4755		.5281	.4887	
18	.5704		.6413	.5487	
19	.716	.6089	.7468	.6154	
20	.8366	.788	.8299	.724	
21	.7606		.8299	.7164	
22	.7583	.7164	.7468	.724	
23	.606				
24	.4458	.5217	.5487	.6348	.5792
Max	.8366	.788	.8299	.724	.7529
Min	.4458	.4894	.4706	.4887	.4938
Avg	.5494	.5820	.6031	.5896	.5674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 205 / 11 kv Shendur Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3977	.394	.3429	
2	.3429	.4166	.362	.3429	
3	.3429	.3965	.3258	.3429	
4	.3429	.3973		.3429	
5	.3429	.4158		.3429	
6		.4347	.3224	.4115	
7	.3772	.4154		.4115	
8	.3772	.3206	.3258	.4115	
9		.2646		.3772	.3258
10	.3582			.3772	.3176
11			.3429	.3772	.389
12			.3429		.4252
13			.3772		.4425
14			.3772		.443
15			.3772	.3258	
16	.3045		.3429	.3258	
17	.3403		.3429	.3077	
18	.3746		.3429	.3582	
19	.5624	.5014	.4115	.4755	
20	.5818	.567	.567	.5487	
21	.5818		.5487	.5014	
22	.5303	.5068	.5144	.4344	
23	.4536				
24	.3429	.3977	.4298	.4115	
Max	.5818	.567	.567	.5487	.443
Min	.3045	.2646	.3224	.3077	.3176
Avg	.4058	.4179	.3915	.3885	.3905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 206 / Octega Green

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0286	.0347		
2	.0305	.0305	.0343		
3	.0305	.0286			
4	.0305	.0305			
5	.0305	.0309	.0335		
6	.0343	.0293			
7	.0343	.032		.0312	
8	.0305	.032	.0343	.0312	
9	.0305	.0309		.0312	.0335
10	.0343	.0305		.0312	.0267
11			.0305		.0286
12			.0305		.0276
13			.0305		.0285
14			.0305		.0283
15			.0305		
16	.0343		.0343		
17			.0343		
18	.0267		.0312	.0335	
19	.0297		.0316	.0354	
20	.0282	.0335	.0335	.0335	
21	.0271		.0312	.0339	
22	.0297	.0351	.0312	.0335	
23	.0289				
24	.0305	.0286	.0343		.0335
Max	.0343	.0351	.0347	.0354	.0335
Min	.0267	.0286	.0305	.0312	.0267
Avg	.0306	.0308	.0324	.0327	.0295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 207 / 11KV Vitthal Shivaji LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.3353	.1372	.2035
4		.373	.1372	.2058
5	.5115	.373	.1372	.2374
6	.5262	.4115	.1715	.2374
7	.5274		.1715	.2572
8	.5463		.1715	.2743
9	.5444		.1715	.2713
10	.4753		.1372	.2646
11	.5438	.4458	.1372	.3149
12	.545	.4458		.298
13	.5463	.4801		.3346
14	.5469	.4801		.3655
15	.5438	.4801	.0671	
16	.5426	.3429	.1017	
17	.4991	.3429	.1357	
18		.3429	.1326	
Max	.5469	.4801	.1715	.3655
Min	.4753	.3353	.0671	.2035
Avg	.5307	.4045	.1392	.2720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 402 / 33 KV Shahu LIS -SDH-

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 33 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2425			
2	3.8683			
3	3.7929		1.749	3.2956
4	3.8329		3.3436	4.2067
5	5.0497		3.3436	4.421
6	5.3441		3.3436	4.4765
7	4.9218		3.2922	4.6811
8	4.8903		4.5268	4.6296
9	4.7942		4.321	4.3759
10	4.784		4.6273	4.6525
11	4.7788		4.5268	4.7325
12	4.8903			4.5959
13	4.9858			4.532
14	4.8903			4.5222
15	4.9858	4.8354	2.8669	
16	5.0073	4.7325	3.0498	
17	5.002	4.9383	4.4256	
18		1.3375	1.6301	
Max	5.3441	4.9383	4.6273	4.7325
Min	3.2425	1.3375	1.6301	3.2956
Avg	4.6506	3.9609	3.4651	4.4268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 201 / Kagal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1334	.1334	1.6244
2	.1524	.1524	.1334	.1334	1.6078
3	.1334	.1524	.1334	.1334	1.6078
4	.1524	.1524	.1334	.1143	1.5912
5	.1715	.1715	.1524	.1143	1.4255
6	.1143	.1334	.1524	.1143	1.6244
7	.1334	.1143	.1143	.1143	.1715
8	.0953	.1143	.1524	.1524	.1334
9	3.0864	3.1055	2.7515	3.0483	.0953
10	2.9912	3.2579	2.7846	3.1436	.0762
11	2.9721	3.0864	2.5194	2.8006	.0762
12	2.7816	2.9721	2.536	2.7816	.0953
13	2.8578		2.3703	2.7244	
14	2.8769		2.1216	2.572	.0572
15	2.8197		2.1548	2.6292	.0762
16	2.6482	2.8197	1.989	2.3815	.0953
17	.0381	2.7244		.0572	.0953
18	.1334	2.572	.0953	.0381	
19	.1524	.1334	.1524	.1524	
20	.1905	.1715	.1524	.1715	
21	.1715	.1905	.1715	.1715	
22	.1715	.1715	.1524	.1524	
23	.1715	.1524	.1334	1.7238	
24		.1524	.1334		1.6741
Max	3.0864	3.2579	2.7846	3.1436	1.6741
Min	.0381	.1143	.0953	.0381	.0572
Avg	1.0943	1.0787	.9271	1.1112	.7134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 202 / Kagal-Sugar Factory Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.381	.381	.3326	.0953
2	.3429	.3429	.3429	.362	.3361	.0953
3	.3239	.3429	.3429	.381	.3361	.0953
4	.3048	.3429	.3429	.362	.3361	.0953
5	.3429	.3429	.3429	.362	.3841	
6	.4572	.3961		.4572	.439	
7	.4382	.4805	.4191	.5716	.5014	
8	.4191	.6154	.4954	.6859	.5792	
9	.3239	.5525	.567	.5335	.4954	
10	.2667	.5525		.6097	.5525	
11	.2667	.5335		.4763	.6859	
12	.3429	.4954	.7282	.4954	.5716	
13	.3048	.6097	.6379	.4763		
14	.3429	.4763	.7087	.6668	.6478	
15	.3429	.6097	.5175	.5716	.7049	
16	.3239	.5525		.6478	.5525	
17	.2947	.4572	.381	.5544	.5335	
18	.3121	.381	.5335	.499	.5716	
19	.3814	.4572	.4954	.4435		
20	.5175	.5525	.5144	.4805		
21	.4805	.4954	.5144	.4435		
22	.4805	.5144	.4954	.4251		
23	.4001	.3429	.4572	.3734		
24		.3429	.381		.3511	.0762
Max	.5175	.6154	.7282	.6859	.7049	.0953
Min	.2667	.3429	.3429	.362	.3326	.0762
Avg	.3632	.4638	.4799	.4895	.4951	.0915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 203 / Non Sh MIDC Kagal-Anant SHEDDABLE FEEDER HAVING WEEKLY
 Roto Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2012		1.4289	1.4784
2	1.3527	.2012	1.1812	1.4289	1.4969
3	1.3717	.1951	1.2574	1.4289	1.4969
4	1.105	.2743	1.3146	1.4098	1.5154
5	1.3336	.3048	1.5051	1.6004	1.5524
6	1.5051	.3458	1.4289	1.5051	1.6078
7	1.3908	.4146	1.5242	1.7147	
8	1.105	.4723	1.5813	1.6575	1.6078
9	.6478	.6668	1.4003	1.6385	.9526
10	.6097	.9145	1.587	1.7337	1.5623
11	.6097	1.0479	1.5123	1.7147	1.7147
12	.6287	1.1241	1.6617	1.8099	1.9052
13	.6287	1.105	1.6991	1.5813	1.7718
14		.9335	1.2883	1.5051	1.6194
15		1.2765	1.6991	1.9243	1.6956
16		1.4098	1.5684	1.7337	1.8861
17	.2561	1.6575	1.6956	1.8296	1.6194
18	.2401	1.6194	1.5051	1.6263	1.5051
19	.2481	1.5813	1.5432	1.6448	
20	.2439	1.6194	1.4861	1.6078	
21	.2515	1.1812	1.2955	1.2567	
22	.2515	1.2193	1.4289	1.2012	
23	.2012	1.3908	1.5242	1.2936	.6478
24		.2012	1.3527		1.4937
Max	1.5051	1.6575	1.6991	1.9243	1.9052
Min	.2012	.1951	1.1812	1.2012	.6478
Avg	.7358	.8899	1.4800	1.5772	1.5331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 204 / Laxmi Ind

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.096	.1524	.2096	.1905
2	.1143	.096	.4001	.1143	.1905
3	.1143	.096	.1905	.1143	.1905
4	.1524	.096	.1143	.1143	.1905
5	.1524	.0975	.1143	.1905	.1905
6	.1524	.0991	.1334	.1143	.1524
7	.1524	.1021	.2667	.1905	.1524
8	.1143	.0766	.1334	.2286	.1524
9	.1143	.2667	.2103	.1143	.2286
10	.1334	.3048	.2629	.1905	.362
11		.2667	.2279	.3429	.3048
12		.1905	.2804	.3429	.362
13		.2286	.2328	.3429	.2667
14	.1143	.1715	.1905		.3429
15	.1143	.2858	.1905	.2667	.2286
16	.1143	.3239	.2096	.2477	.381
17	.0492	.2096	.2667	.2667	.2286
18	.0572	.2858	.1905	.2096	.1905
19	.0572	.2858	.2477	.2858	
20	.0812	.2667	.1143	.1905	.1905
21	.1082	.2096	.1905	.2286	.1905
22	.1082	.2286	.1905	.2286	.1524
23	.096		.2096	.2096	.1334
24		.096	.2858		.2096
Max	.1524	.3239	.4001	.3429	.381
Min	.0492	.0766	.1143	.1143	.1334
Avg	.1107	.1904	.2086	.2156	.2253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 205 / K.Sangaon SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4191		.4191	.4066
2	.4001	.2521	.4001	.4001	.3921
3	.381	.4001	.4382	.381	.3921
4	.381	.4001	.4763	.4763	.3921
5	.4001	.547	.5144	.5716	.5175
6	.4001	.5788	.5716	.5906	.5487
7	.362	.5611	.5716	.5906	.5487
8	.381	.5068	.5716	.5906	.5373
9	.381	.5716	.567	.6097	.5716
10	.362	.5716	.5493	.5335	.6097
11	.4001	.5525	.5973	.5906	.5716
12	.4001	.5335	.5249	.6097	.6097
13	.4001	.5906	.5249	.5716	.6287
14	.4001	.5906	.5792	.5716	.6097
15	.381	.5716	.5973	.6097	.5906
16	.4001	.5906		.6097	.5525
17	.3582	.6287	.5335	.567	.5906
18	.4477	.6478	.5906	.5493	
19	.5552	.6287	.6668	.6379	
20	.6805	.7049	.743	.6024	
21	.6805	.6287	.6668	.6024	
22	.591	.5144	.5716	.567	
23	.5144		.4763	.4525	.4572
24		.4572	.4382		.4066
Max	.6805	.7049	.743	.6379	.6287
Min	.3582	.2521	.4001	.381	.3921
Avg	.4373	.5412	.5532	.5524	.5228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 206 / Laxmi-Ag Feeder-

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381		.0381	.663
2	.0381	.0381	.0381	.0381	.6516
3	.0381	.0381	.0381	.0381	.6516
4	.0381	.0381	.0381	.0381	.6687
5	.0381	.0381	.0381	.0381	.7545
6	.0381	.0381	.0381	.0381	.9116
7	.0381	.0381	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381	.0381
9	1.7147	1.7909	1.6244	1.9052	.0381
10	1.7528	1.7909	1.5912	1.7909	.0381
11	1.6766	1.848	1.4918	1.7147	.0381
12	1.5432		1.4255	1.5242	.0381
13	1.4098		1.2929	1.5623	.0381
14	1.4861		1.2929	1.448	.0381
15	1.4861		1.326	1.4289	.0381
16	1.3908	1.6385	1.2929	1.2574	.0381
17	.0381	1.4098	.0381	.0381	.0381
18	.0381	1.3336	.0381	.0381	
19	.0381	.0381	.0381	.0381	
20	.0381	.0572	.0381	.0381	
21	.0381	.0572	.0381	.0381	
22	.0381	.0381	.0381	.0381	
23	.0381	.0381	.0381	.663	
24	.0381	.0381	.0381		.6962
Max	1.7528	1.848	1.6244	1.9052	.9116
Min	.0381	.0381	.0381	.0381	.0381
Avg	.5446	.5192	.5178	.6012	.3009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 207 / S.Kharkhan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1148	2.0056		2.2481	.0953
2	2.0957	1.8896		2.1148	.0381
3	2.0767	1.8138	2.0386	2.1148	.0381
4	2.0957	1.8299	2.1148	2.1719	.0381
5	2.2291	1.9109	2.1719	2.191	.0381
6	2.4768	2.2447		2.4577	.0381
7	2.6101	2.343	2.7435		.0762
8	2.4958	2.4086	2.8769		.0762
9	.0572	.0572	.0381		3.1626
10	.0572	.0572	.0381		3.4484
11	.0572	.0572	.0572	.0572	3.4675
12	.0572	.0572	.0381	.0572	3.4103
13	.0572	.0381	.0572	.0572	3.2579
14	.0572	.0572	.0572	.0762	3.1626
15	.0572	.0572	.0572	.0572	3.0674
16	.0572	.0572	.0572	.0572	2.7435
17	.0572	.0572	.0572	.0762	
18	.0762	.0572	.0572	.0762	.0762
19	.0762	.0572	.0572	.0762	
20	.0953	.0953	.0762	.0953	
21	.0953	.0953	.0762	.0953	
22	.0953	.0953	.0762	.0953	
23	2.1879	2.4958	2.6101	.0953	
24		2.1051	2.4006		.0953
Max	2.6101	2.4958	2.8769	2.4577	3.4675
Min	.0572	.0381	.0381	.0572	.0381
Avg	.9276	.9143	.8456	.7511	1.4628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 208 / Kagal Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9997		1.0098	.9709
2	.9526	.9808	.9717	.9717	.9522
3	.9145	.9431	.9335	.9335	.9335
4	.9145	.9431	.9717	.9335	.9335
5	.9335	.9619	.9907	.9717	.9335
6	.8954	.9431	1.0288	.9717	.9149
7	.8764	.8962	.9335	.9907	.8596
8	.7811	.8402	.8954	.8954	.7964
9	.7811	.8764	.8507	.8764	.8573
10	.8764	1.0098	.9231	.9526	.9335
11	.8954	.9907	.9593	1.0479	1.086
12	.9335	1.0098	1.0498	1.0479	1.0098
13	.9526	1.0479	1.086	1.086	.9526
14	.9717	1.0288	1.0164	1.0479	1.0669
15	.9335	1.0669	1.0164	1.0479	1.0479
16	.9526	1.2765	1.0164	.9717	1.0479
17	.905	1.086	1.1812	1.0425	1.0669
18	.9231	1.086	1.1622	1.1157	
19	1.1946	1.448	1.2765	1.262	
20	1.3491	1.5242	1.3336	1.3717	
21	1.3306	1.3527		1.262	
22	1.3121	1.3336	1.2574	1.2254	
23	1.2071	1.2003	1.1622	1.1273	.9907
24		1.0562	1.0479		1.0269
Max	1.3491	1.5242	1.3336	1.3717	1.086
Min	.7811	.8402	.8507	.8764	.7964
Avg	.9895	1.0792	1.0484	1.0506	.9674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 402 / 33KV Shahu LIS - KGL-

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 33 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.4001	.6859	1.3146	1.0288	.3429
4	.8002	.6859	1.3717	1.2574	
5	.9717	.6859	1.3717	1.3717	
6	1.0288	.743	1.3717	1.3717	
7	1.1431	1.086	1.3717	1.3717	
8	1.2574	1.3717	1.3717	1.3717	
9	1.3717	1.4289	1.3717	1.3717	
10	1.4289	1.4289	1.3717	.9717	
11	1.4289	1.4289	1.3717	1.086	
12	1.3717	1.3717	.9717	.9717	
13		1.3717	1.3717	.9717	
14	.9717	1.3717	1.3717	.9717	
15	1.0288	1.4289	.9717	1.3717	
16	1.0288	1.3717	.9717	1.3717	
17	1.0288	1.3717	.9717	1.3717	
18	.2858	.5144	.4572	1.3717	
Max	1.4289	1.4289	1.3717	1.3717	.3429
Min	.2858	.5144	.4572	.9717	.3429
Avg	1.0364	1.1467	1.2110	1.2253	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 201 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	1.6575	1.4861	1.5432	1.5813	1.6575	1.467
2	1.5432	1.6385	1.5051	1.5051	1.5242	1.6004	1.4861
3	1.5432	1.6385	1.5051	1.5242	1.5051	1.5432	1.4861
4	1.5432	1.6194	1.4861	1.5623	1.5051	1.5432	1.4861
5	1.5432	1.6194	1.4861	1.6004	1.5051	1.5432	1.4861
6	1.5432	1.6194	1.5051	1.6766	1.5051	1.5432	1.4861
7	1.6004	1.6956	1.5432	1.6575	1.5051	1.5242	1.4861
8	1.5813	1.7147	1.5813	1.5623	1.5242	1.5432	1.448
9	1.6956	1.7147	1.6385	1.8861	1.9624	2.0957	1.7147
10	1.5813	1.6004	1.7147	2.572	2.4196	2.4768	1.9052
11	1.5813	1.6194	1.9052	2.6673	2.0005	2.4768	2.0957
12	1.0669	1.6766	1.8099	2.2862	2.2862	2.2862	1.7528
13	1.2193	1.6385	1.7147	1.8671	1.6766	1.8099	1.6385
14	1.2193	1.7147	2.0576	2.2862	2.4196	2.2481	1.9243
15	1.2193	1.9052	2.1719	2.4387	2.1148	2.3815	1.8671
16	1.2384	1.2384	2.0005	1.848	2.0957	1.8861	1.9433
17	1.2384	1.0669	1.9433	1.7718	1.9624	1.9814	1.848
18	1.2955	1.4861	1.7147	1.5623	1.5623	1.467	1.4861
19	1.7147	1.4861	1.5432	1.5813	1.5051		1.467
20	1.6575	1.467	1.5242	1.4861	1.5242		1.4861
21	1.6575	1.448	1.4861	1.4861	1.467		1.448
22	1.6194	1.4289	1.5051	1.5242	1.467	1.4861	1.4861
23	1.6385	1.4861	1.5432	1.6004	1.5242	1.467	1.5051
24	1.5051	1.6575	1.4861	1.5432	1.5813	1.6575	1.448
Max	1.7147	1.9052	2.1719	2.6673	2.4196	2.4768	2.0957
Min	1.0669	1.0669	1.4861	1.4861	1.467	1.467	1.448
Avg	1.4805	1.5766	1.6607	1.7933	1.7385	1.8199	1.6187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 202 / 11KV West Block

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.6194	1.7147	1.6194	1.9052	1.8099	1.7147
2	1.9052	1.6194	1.7147	1.5242	1.9052	1.8099	1.9052
3	1.9052	1.6194	1.7147	1.7147	1.9052	1.9052	1.9052
4	1.9052	1.6194	1.7147	1.6194	1.9052	1.9052	1.9052
5	1.8099	1.6194	1.7147	1.6194	1.9052	1.9052	1.9052
6	1.8099	1.6194	1.7147	1.6194	1.7147	1.9052	1.7147
7	1.7147	1.8099	1.9052	1.9052	1.6194	1.8099	1.7147
8	1.8099	1.9052	2.0005	1.8099	2.0005	2.0957	1.9052
9	1.8099	2.4768	2.2862	2.2862	2.0005	1.6194	2.6673
10	1.9052	2.2862	1.9052	2.6673	2.4768	3.0483	2.6673
11	1.7147	2.8578	3.2388	2.6673	2.2862	2.6673	2.2862
12	1.3336	2.4768	2.2862			2.6673	2.8578
13	1.3336	2.4768	2.2862		2.0957	2.2862	2.6673
14	1.3336	2.2862	2.4768	2.4768	2.2862	3.2388	2.6673
15	1.3336	3.0483		2.6673	2.7625	2.4768	3.2388
16	1.3336	2.6673	2.4768	2.8578	2.4768	2.8578	3.0483
17	1.3336	2.6673	2.2862	2.6673	2.2862	2.6673	2.3815
18	1.3336	2.2862	1.9052	2.4768	1.9052	1.7147	2.4768
19	1.5242	2.2862	1.9052	2.2862	1.5242		2.0957
20	1.5242	2.0957	1.7147	1.9052	1.9052	1.5242	2.2862
21	1.5242	1.9052	1.5242	1.9052	1.5242		1.9052
22	1.6194	1.5242	1.5242	1.9052	1.6194	1.9052	1.7147
23	1.6194	1.6194	1.6194	1.7147	1.9052	1.7147	1.7147
24	1.9052	1.6194	1.7147	1.7147	1.8099	1.9052	1.7147
Max	1.9052	3.0483	3.2388	2.8578	2.7625	3.2388	3.2388
Min	1.3336	1.5242	1.5242	1.5242	1.5242	1.5242	1.7147
Avg	1.6353	2.0838	1.9715	2.0741	1.9880	2.1563	2.2108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 203 / KANERI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6097	.8192	.7621	.7621	.4954	.5335
2	.7049	.6478	.7621	.7621	.7621	.5906	.5335
3	.7621	.6859	.7621	.724	.7621	.5716	.5335
4	.8002	.6859	.7621	.7621	.7621	.5906	.5335
5	.8192	.6859	.7811	.8002	.7621	.5906	.724
6	.8192	.6859	.9335	.8002	.8764	.5906	.8002
7	.8954	.9526	1.0288	.8573	1.1241	.8573	.8002
8	.7621	.8764	.8764	.4191	1.1622	1.1431	.8573
9	.5144		1.2574	.8954	1.2003	1.2765	.9145
10	.4191				1.2003	1.1812	1.0669
11	.4001				1.7147	.9717	.8002
12	.4572				1.448	1.105	1.1431
13	.4763				1.7909	1.2193	1.0479
14	.6478				1.8099	1.467	1.7909
15	.5716				1.3908	1.7909	1.2955
16	.5335		1.448		1.4861	1.3146	1.2193
17	.5525		1.1812		1.4289	1.2955	1.4098
18	.5335		1.0098	1.6194	.9335	1.0288	1.1622
19	.7049	1.2193	1.2193	1.4861	.5144		1.1431
20	.8764	1.2003	1.105	1.448	1.0669		1.1622
21	.8383	1.1622	1.0669	1.3908	.6859	.743	1.1622
22	.8383	1.1622	1.2574	1.5242	.6668	.5144	1.2765
23	.7621	1.2384	.9526	1.1622	.5906	.6097	1.2384
24	.7811	.6287	.8573	.8002	.7811	.5335	.5716
Max	.8954	1.2384	1.448	1.6194	1.8099	1.7909	1.7909
Min	.4001	.6097	.7621	.4191	.5144	.4954	.5335
Avg	.6763	.8887	1.0045	1.0133	1.0701	.9310	.9883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 204 / 11 KV PANCHAGANGA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8099	.9526	1.3336	1.4289	1.7147	1.5242	1.9052
2	1.8099	.9526	1.3336	1.4289	1.7147	1.5242	1.9052
3	1.8099	.7621	1.3336	1.9052	1.8099	1.5242	1.9052
4	1.8099	.7621	1.4289	1.5242	1.8099	1.5242	1.9052
5	1.5242	.7621	1.4289	1.7147	1.8099	1.5242	2.0957
6	1.4289	.7621	1.5242	1.9052	1.8099	1.5242	2.2862
7	1.7147	.7621	1.7147	1.9052	2.191	1.9052	2.4768
8	1.1431	.7621	1.4289	1.7147	1.8099	1.7147	1.3336
9	1.1431	1.7147	2.2862	3.0483	2.3815	2.2862	2.2862
10	.9526	1.3336	1.5242	2.6673	2.4768	3.0483	2.6673
11	.9526	1.7147	2.6673	3.0483	3.2388	2.2862	2.4768
12	.9526	1.7147	2.2862	1.7147	2.2862	1.5242	2.8578
13	.9526	1.7147	1.5242	2.2862	2.4768	2.6673	2.6673
14	.9526	1.7147	2.0957	2.4768	2.4768	2.0957	2.8578
15	.9526	1.3336	2.8578	2.6673	2.0957	2.8578	2.7625
16	.9526	1.1431	2.0957	2.2862	2.2862	1.9052	2.0005
17	.7621	.9526	2.0957	2.2862	1.6194	2.0957	2.0957
18	.9526	1.3336	2.0957	2.0957	1.7147	1.3336	2.0957
19	.7621	1.1431	2.2862	1.1431	1.5242		1.7147
20	.7621	.7621	1.7147	1.1431	1.5242		1.5242
21	.7621	.9526	2.0957	1.1431	1.9052	2.0957	1.1431
22	.9526	1.1431	2.0957	1.9052	2.0957		1.1431
23	.9526	1.1431	1.5242	1.8099	1.5242		1.7147
24	1.8099	.9526	1.5242	2.0005	1.1431	1.5242	2.0957
Max	1.8099	1.7147	2.8578	3.0483	3.2388	3.0483	2.8578
Min	.7621	.7621	1.3336	1.1431	1.1431	1.3336	1.1431
Avg	1.1907	1.1352	1.8457	1.9687	1.9766	1.9243	2.0798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 205 / 11KV MainRoad

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.7811	1.2955	1.1622	.8002	.6859	.9907
2	.8192	.8002	1.1812	.9907	.7621	.724	.9145
3	.8192	.8192	.9526	1.086	.7049	.724	.8002
4	.8002	.8192	.9145	1.2193	.7049	.724	.7049
5	.8002	.8192	.9145	1.1431	.7049	.724	.743
6	.8002	.8192	1.2193	.8002	.8002	.724	.7811
7	.743	.8192	.8192	.8192	.7049	.724	.8002
8	.724	.7811	.8954	.7811	.8002	.8954	.7621
9	.7621	.8002	.8192	.8192	.8383	1.086	.8383
10	.743	.6859	.9145	1.3336	1.086	1.086	1.4289
11	.743	.9907	1.0479	1.5051	1.086	.6859	1.467
12	.8002	.8573	1.2765	1.3717	.9145	.9717	1.2384
13	.7621	.7811	1.2384	.8002	.8192	.9526	1.3336
14	.7621	.8383	1.1431	.9907	.8764	.8573	1.4098
15	.743	.8573	1.4098	1.0669	.8954	.9335	1.4098
16	.743	.8573	.9717	1.2003	.8383	.9526	1.3908
17	.743	.7811	.9907	.7811	.9717	.724	1.0479
18	.7621	.8192	1.0288	.7621	.7621	.724	1.0098
19	.7811	.8002	.743	.9717	.724		.9145
20	.7621	.8002	.7811	.8192	.743		.8764
21	.8002	.6478	.7621	.7621	.724	.7621	.7811
22	.8192	.8002	.8573	.8192	.7621	.743	.7811
23	.8002	.8573	1.1812	.6859	.7049	1.2003	.743
24	.8383	.7811	1.2574	1.2765	.8002	.7621	1.1431
Max	.8383	.9907	1.4098	1.5051	1.086	1.2003	1.467
Min	.724	.6478	.743	.6859	.7049	.6859	.7049
Avg	.7772	.8089	1.0256	.9986	.8137	.8348	1.0129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 206 / 11KV Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4098	1.3717	1.7528	1.6385	1.7147	1.6385	1.6766
2	1.5242	1.3717	1.7528	1.6385	1.7147	1.7147	1.6385
3	1.5242	1.3717	1.7528	1.5623	1.6766	1.7147	1.6385
4	1.4861	1.3717	1.7528	1.6385	1.6385	1.7528	1.6385
5	1.4861	1.3717	1.7528	1.6004	1.6385	1.7528	1.6385
6	1.448	1.3717	1.8671	1.5242	1.6766	1.7528	1.6004
7	1.4861	1.448	2.0195	1.7528	1.7909	1.7147	1.6004
8	1.4861	1.5623	1.9433	1.9052	1.7147	1.9052	1.6004
9	1.4861	2.4006	2.4006	2.1719	2.0957	2.4006	2.2481
10	1.4098	2.8578	3.2388	3.1245	2.0957	2.7054	2.0957
11	1.448	3.0102	3.9247	3.2769	2.4768	2.7054	2.0957
12	1.3336	2.7435	4.039	3.9247	2.4768	2.3624	2.5149
13	1.3336	2.8959	3.1626	3.5437	2.21	2.4006	1.9814
14	1.2955	2.8578	4.1533	3.4675	2.1719	2.3243	2.0957
15	1.2574	2.8959	4.039	3.3913	2.3624	2.3243	2.3624
16	1.2574	2.934	2.2481	2.934	2.4006	1.9814	2.4387
17	1.2574	2.4006	2.0576	3.1245	2.0957	2.1338	1.7528
18	1.2574	2.4768	1.7528	1.9052	2.0957	1.6766	1.7147
19	1.2193	1.2574	1.7147	1.6004	1.5623		1.6004
20	1.2574	1.4098	1.6766	1.2955	1.448		1.5242
21	1.3336	1.5623	1.6004	1.3336	1.5242	1.4098	1.3336
22	1.4098	1.6766	1.829	1.6385	1.5242	1.2955	1.4098
23	1.3717	1.7528	1.6766	1.7909	1.6385	1.7147	1.9052
24	1.4098	1.3336	1.448	1.5623	1.7147	1.829	1.6766
Max	1.5242	3.0102	4.1533	3.9247	2.4768	2.7054	2.5149
Min	1.2193	1.2574	1.448	1.2955	1.448	1.2955	1.3336
Avg	1.3829	1.9878	2.3148	2.2227	1.8941	1.9641	1.8242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 207 / 11 KV UJALAIWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.362	.381	.381	.381	.4001	.3429
2	.381	.362	.381	.381	.381	.4001	.3239
3	.381	.362	.381	.362	.381	.4191	.3239
4	.381	.381	.381	.362	.381	.4191	.3239
5	.381	.381	.381	.381	.4001	.4191	.3429
6	.4001	.381	.4191	.4191	.4191	.4191	.4001
7	.4001	.381	.4191	.4191	.4001	.4191	.4191
8	.4191	.381	.4001	.4191	.4191		.362
9	.362	.4382	.381	.381	.4001	.362	.3239
10	.3239	.381	.4572	.381	.4763	.4191	.4572
11	.3239	.4001	.4954	.4191	.5144	.4191	.4191
12	.2858	.4382	.5144	.4382	.5144	.4954	.4001
13	.3048	.4001	.4954	.4191	.4954	.4382	.4191
14	.3048	.4001	.4382	.4191	.4954	.4572	.4572
15	.3239	.4572	.4572	.4572	.5144		.4191
16	.3429	.4572		.5144	.5144		.4191
17	.4001	.4763	.4572	.4763	.5144	.5335	.4382
18	.4001	.4763	.4763	.4572	.4763	.4954	.4572
19	.4763	.5335	.4763	.5335	.4954		.4954
20	.5335	.5525	.4763	.5144	.5144		.5335
21	.5144	.5144	.4954	.4954	.4954	.4954	.5335
22	.4572	.4954	.4763	.4954	.4763	.4763	.4954
23	.4572	.4382	.4572	.4382	.4572	.381	.4572
24	.703	.4001	.4191	.4001	.4191	.4001	.381
Max	.703	.5525	.5144	.5335	.5144	.5335	.5335
Min	.2858	.362	.381	.362	.381	.362	.3239
Avg	.4016	.4271	.4398	.4318	.4557	.4352	.4144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 208 / KANERI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	.1905	.1715	.2477	.2286	1.2003	1.0479
2	2.21	.1905	.1715	.2477	.2286	1.2574	1.0669
3	2.21	.1905	.1715	.2477	.2096	1.3336	1.086
4	2.2862	.1905	.1715		.2096	1.4289	1.086
5	2.3624	.1905	.1715		.2096	1.4289	1.2384
6	2.4387	.1905	.1905		.2477	1.6766	1.5242
7	2.4387	.1905	.2286	.0762	.2096	2.0005	1.5813
8	2.4577	.1905	.2096	.0953	.2286	.1334	1.5242
9	2.6673	2.915	2.5911		.2477	.1334	.0762
10	2.6101	2.7435	2.8006	1.2384	.2667	.1334	.1715
11	2.3815	2.7816	2.6673	2.3624	.2096	.1334	.1715
12	2.4196		2.3053	2.3815	.2286	.2286	.1905
13	2.3624		2.2291	2.3434	.2286	.1524	.1334
14	2.2672		2.2672	2.3243	.2286	.1524	.2096
15	2.4196		2.3053	2.3053	.1715	.1524	.2286
16	2.4006	2.4768	1.9433	2.2481	.1715	.1715	.2858
17	.1524	2.1148	.0381	1.9814	.1715	.1905	.1524
18	.1905	2.0767	.1143	.2477	.2286	.1715	.1905
19	.2286	.2096	.1524	.2286	.1905		.2286
20	.2096	.2286	.1334	.3429	.1143		.2667
21	.1905	.1905	.1715	.2477	.1524	.0191	.2858
22	.2096	.2096	.1524	.3048	.1905	.0191	.2858
23	.2096	.1524	.1715	.2286	.2286	.0953	.2667
24	2.3815	.2096	.1715	.2477	.2286	.2286	.0953
Max	2.6673	2.915	2.8006	2.3815	.2667	2.0005	1.5813
Min	.1524	.1524	.0381	.0762	.1143	.0191	.0762
Avg	1.7496	.8916	.9042	.9974	.2096	.5655	.5581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 209 / UJALAIWADI SHETI PUMP
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.4954		.5144	.4382	.0953	.0572
2	.0191	.4954		.4001	.4382	.0953	.0572
3	.0191	.5335	.4191	.362	.4191	.0762	.0572
4	.0191	.5716	.4001	.3429	.4191	.0762	.0572
5	.0191	.5906		.381	.4191	.0762	.0572
6	.0191	.5906		.4763	.4954	.0762	.0572
7	.0381	.6478	.7621		.0762	.0762	.0762
8	.0381	.5906	.6859		.0762	.1143	.0572
9	.0191	.0572	.0572	.0762	.5144	.5716	.5906
10	.0191	.0572	.0572	.0953	.6668	.7621	.6859
11	.0572	.0762	.0572	.0762	.8954	.724	.6287
12	.0381	.0762	.0572	.0953	.7621	.7049	.6287
13	.0191	.0572	.0572	.0762	.743	.5906	.5716
14	.0572	.0572	.0572	.0572	.6668	.5716	.6097
15	.0381	.0572	.0572	.0572	.6478	.2286	.5906
16	.0381	.0572	.0572	.0762	.6478	.7049	.5716
17	.0953	.1143	.0572	.0762	.0572	.0953	.0762
18	.0762	.0762	.0762	.0572	.0953	.0953	.0572
19	.0762	.0762	.0762	.0572	.0762		.0572
20	.0572	.0762	.0762	.0572	.0953		.0572
21	.0762	.0572	.0762	.0572	.0762	.0762	.0572
22	.0762	.0762	.0762	.0762	.0953	.0762	.0572
23	.724	.6859	.6287	.5144	.0762	.0762	.0572
24	.0191	.6097		.5525	.4763	.0953	.0762
Max	.724	.6859	.7621	.5525	.8954	.7621	.6859
Min	.0191	.0572	.0572	.0572	.0572	.0762	.0572
Avg	.0699	.2826	.1996	.2061	.3906	.2754	.2437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 201 / 11KV Randeviwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
1	.0457
2	.0457
3	.0457
4	.0457
5	.0457
6	.0457
7	.0457
24	.0457
Max	.0457
Min	.0457
Avg	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 202 / M Sangaon Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7888	.9522	.7773	.7888	.8488	
2		.7362	.9522	.7316	.7888	.7922	
3	.7059	.7362	.9055	.7316	.7888	.7282	
4	.7059	.7802	.8501	.7316	.8402	.7356	
5	.7602	.823	.9877	.7773	.8745	.8488	
6	.9231	.823	1.0534	.9145	.9259	1.0751	
7	.8688	.8745	.7621	.7773	.9259	.8316	
8	.7602	.8322	.7468	.7316	.823	.7282	.1086
9	.6516	.7888	.6401	.7773	.7373	.8316	.3258
10		.7011		.6687	.8573	.2481	.4344
11		.7865			.7682	.2481	.4835
12		.7682	.7316	.7716	.9412	.2429	.5144
13		.8869	.9231	.8402	.9231	.7773	.5258
14		.8962	.8688	.8402	.7842	.7773	
15		.8962	.7773	.8745	1.0164		.8413
16		.7865		.8745	.9145		.8322
17		.9055	.8688	.7716	.8871	.9231	.7282
18		.9425	.8688	.7716		.7287	.7975
19		1.0791	.9602	.9259			1.0288
20		1.2567	1.0059	.9774			1.2346
21		1.2323	.9145	1.0288	.9896		1.1831
22		1.1643	.9145	1.0288	1.1203		1.1831
23		1.0374	.9145	.9774	.9619		1.0288
24		.7888	.9619	.823	.9259	.9054	
Max	.9231	1.2567	1.0534	1.0288	1.1203	1.0751	1.2346
Min	.6516	.7011	.6401	.6687	.7373	.2429	.1086
Avg	.7680	.8880	.8838	.8315	.8849	.7218	.7500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 203 / Sulkud AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0739	.0474	.061	1.6461	.8745	
2	.081	.056	.0486	.061	1.6461	.8745	
3	.081	.056	.0486	.061	1.6461	.8259	
4	.0648	.056	.0486	.061	1.7318	.8259	
5	.081	.0739	.0633	.0762	1.749	.9231	
6	.0648	.0924	.0663	.0762	2.0233	1.0322	
7	.0648	.0924	.0457	.0762	.1543	1.166	
8	.081	.0739	.0457	.1067	.1029	.8356	
9	2.5587	2.8166	2.7496	2.7092	.0857	.0434	
10	2.8178	2.8166	2.8669	2.7206	.0686	.0457	
11		2.8669	2.7496	2.6749	.0701	.0503	.0377
12		2.4697	2.5987	2.5892	.0537	.0457	.0377
13			2.3975	2.3663	.0486	.0457	.0377
14			2.2672	2.2634	.052	.0457	.0377
15			2.2186	2.0062	.0724	.0457	.0189
16		2.4366	1.8461	1.8519	.0554	.0457	.0377
17		2.2377	.0457	.0686	.052	.061	.0377
18		2.1879	.0648	.0686		.061	.5487
19		.0486	.061	.0857			.0739
20		.0829	.0762	.0857			.0924
21		.0509	.0762	.0857	.0671		.0747
22		.052	.061	.0686	.0503		.0739
23		.0566	.061	1.7661	.0503		.0739
24	.081	.0739	.0474	.061	1.6975	.0497	
Max	2.8178	2.8669	2.8669	2.7206	2.0233	1.166	.5487
Min	.0648	.0486	.0457	.061	.0486	.0434	.0189
Avg	.5506	.8939	.8584	.9188	.6249	.4156	.0910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 201 / 11KV Arya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7625	.5601	1.4937	1.4937	1.7924	1.6461	1.1222
2	.9686	.5601	1.531	1.531	1.7924	1.6991	1.0808
3	1.0004	.5601	1.4563	1.4937	1.6804	1.6263	1.0288
4	1.046	.5601	1.5684	1.4937	1.7364	1.6632	1.1584
5	1.1043	.5601	1.643	1.4937	1.7177	1.5939	1.1462
6	1.134	.5601	1.2323	1.3443	1.6804	1.6297	1.2567
7	.9259	.5975	1.4563	1.643	1.251	1.1831	1.6297
8	.8413	.6348	1.1203	1.1203	1.1576	1.387	1.1317
9	.6908	1.1949	1.643	1.0456	1.3443	1.3213	1.448
10	.5975	1.2071	1.5684	1.5844	1.531	1.9418	1.6804
11	.5975	1.423	1.4901	2.2481	1.4937	1.8671	1.643
12	.5601		1.4335	2.0748	1.4937	1.643	
13	.5601	3.53	1.2986	2.0911	1.4937	1.1949	1.2696
14	.5601	1.9993	1.4998	1.6095	1.6804	1.4937	1.5684
15	.5601	1.4083	1.6108	1.8656	1.7924	1.531	1.4937
16	.5601	1.7924	1.7002	2.1253	1.5684	1.643	1.3443
17	.5601	1.885	1.2012	1.6263	1.4937	1.3535	1.8671
18	.5601	1.8671	1.2567	1.3889		1.2696	1.1949
19	.5601	1.8107	1.2696	1.419			1.1949
20	.5601	1.7177	1.1949	1.7924	1.267	1.2003	1.1203
21	.5601	1.643	1.1576	1.7924	1.2803	1.2209	1.1431
22	.5228	1.643	.7842	1.8671	1.3256	1.1043	1.0479
23	.5228	1.643	1.1317	2.3899	1.307	1.2003	1.086
24	.7613	.5601	1.4003	1.4937	1.8298	1.6617	1.1584
Max	1.134	3.53	1.7002	2.3899	1.8298	1.9418	1.8671
Min	.5228	.5601	.7842	1.0456	1.1576	1.1043	1.0288
Avg	.7115	1.3008	1.3809	1.6678	1.5322	1.4815	1.2963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 202 / 11 KV Managal Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.8589	.8215	.8589	.7468	.5234	.431
2	.4531	.8215	.8215	.8589	.7468	.5468	.431
3	.3658	.8215	.7842	.8589	.7468	.6081	.4978
4	.3041	.8402	.7842	.8589	.7468	.5425	.5106
5	.3277	.8215	.8215	.8589	.7468	.539	.6093
6	.2229	.8775	.7842	.8402	.8215	.602	.6401
7	.1593	.8962	.9335	.9709	.9709	.8471	.7802
8	.2454	.9335	1.0456	1.0456	1.0829	.945	.5049
9	.8589	1.2696	1.2323	1.3443	1.358	1.286	1.1105
10	.8215	1.0814	1.7558	1.848	1.4937	1.8671	1.531
11	.8215	1.2071	1.701	1.8111	1.4937	1.7177	1.587
12	.7842	1.6108	1.7375	1.7002	1.4937	1.4937	
13	.8215	1.379	1.3908	1.4632	1.419		1.2696
14	.8215	1.3937	1.3847	1.3443	1.4937	1.4937	1.1203
15	.8215	1.4148	1.4706	1.4449	1.5684	1.4937	1.307
16	.8402	1.5746	1.6095	1.6221	1.2696	1.419	1.3443
17	.8402	1.576	1.4266	1.587	1.4563	1.4661	1.2696
18	.8962	1.4661	1.6263	1.5684		1.4937	1.0082
19	.8962	1.1389	1.531	.9709			1.307
20	.8589	.9335	1.1576	.9335	.3506		1.2696
21	.8589	.8589	1.1203	.9709	.5121	.5014	1.1622
22	.8589	.8962	.8962	.9709	.4973	.4801	1.0669
23	.8589	.7468	.8589	.8402	.57	.7265	.8573
24	.4641	.8589	.8589	.8589	.7842	.4641	.7421
Max	.8962	1.6108	1.7558	1.848	1.5684	1.8671	1.587
Min	.1593	.7468	.7842	.8402	.3506	.4641	.431
Avg	.6493	1.0949	1.1898	1.1846	1.0168	1.0027	.9721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 203 / 11 KV KORGAONKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.5228	.7842	.9709	.8215	.8488	.7095
2	.8865	.5228	.7468	.9335	.7842	.8764	.743
3	.8962	.5228	.8589	.9709	.7468	.8488	.6979
4	.7545	.5228	.8589	.9709	.7468	.8299	.7023
5	.724	.5228	.8962	.8215	.7468	.8002	.7316
6	.583	.5228	.7167	.8215	.8215	.8029	.7655
7	.5312	.5228	.7842	.8589	.8962	.8589	.8676
8	.503	.6722	.8589	.8962	.8402	.8865	.9431
9		.9709	1.2136	.9709	.9709	.9431	.7682
10	.5228	.7316	1.3717	1.2955	1.1203	1.2696	.8962
11	.5228	.9717	1.3203	1.1431	1.1203	1.1317	.8962
12	.5601	.8299	1.2449	1.0791	.8962	.7468	
13	.5228	.8029	1.0374	1.1203	.8215	.9709	.9335
14	.4854	.8299	1.3443	1.1317	.9709	.8402	.8962
15	.4854	.7023	1.5466	1.0751	1.0456	.8962	.8215
16	.4854	.8488	1.6766	.8865	1.0456	.9335	.7468
17	.4481	.8299	1.2883	1.0751	.9335	1.0185	.9335
18	.4481	.7811	.8215	.9335		.8589	.8589
19	.4854	.8488	1.0456	.7842			.8402
20	.5228	.8402	1.0456	.9709	.8859	.1696	.7468
21	.5228	.8215	1.0456	.9335	.9391	.3601	.7621
22	.5228	.9709	1.0082	.8962	.961		.8192
23	.5228	.9709	.9709	.8962	.7133	.6135	.6097
24	.0914	.5228	.7468	.9335	.8589	.9242	.6036
Max	.8962	.9717	1.6766	1.2955	1.1203	1.2696	.9431
Min	.0914	.5228	.7167	.7842	.7133	.1696	.6036
Avg	.5619	.7336	1.0514	.9737	.8949	.8377	.7954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 204 / 11 KV Silver Zone

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.531	2.2032	2.0538	2.1658	1.9805	2.0351
2	1.828	1.5684	2.0911	1.9791	2.1472	1.8665	2.0182
3		1.5684	2.0911	1.9605	2.1472	1.9753	2.0005
4	1.8656	1.5684	2.0911	2.0165	2.0911	1.8823	1.9993
5	1.7372	1.5684	2.0911	1.9605	2.0538	1.8671	1.9044
6	1.5581	1.531	2.1658	1.9605	1.9605	1.8296	1.8296
7	1.4582	1.531	1.9605	1.9044	1.9791	1.5089	1.9044
8	2.9313	1.7924	2.0911	2.0165	1.9791	1.6461	1.7718
9	1.5684	2.3525	2.5393	2.3899	2.2405	2.5972	2.0271
10	1.5684	2.7915	3.3196	3.2819	3.0807	3.2861	2.9874
11	1.587	3.3573	3.5082	3.2388	3.5101	3.3608	3.0247
12	1.643	3.1554	3.1927	2.8778	3.1741	3.3608	
13	1.4937	2.8567	2.8567	2.5766	3.2114		2.838
14	1.4937	3.2156	3.006	3.1741	3.2861	2.9127	2.8006
15	1.5684	3.1554	2.809	2.8349	3.3608	3.062	2.7633
16	1.5684	3.1741	2.7915	3.0178	3.1367	3.1367	2.4646
17	1.4937	3.4728	3.1499	2.999	3.3608	3.1554	2.6139
18	1.4937	2.9874	2.6217	2.3228		2.2779	2.0911
19	1.5684	2.4832	2.3899	2.2965			2.0538
20	1.5684	2.3899	2.2405	2.1658	1.7918	1.8404	1.7177
21	1.5684	2.2032	2.2405	2.1658	1.9978	2.0851	1.829
22	1.587	2.3339	2.2405	2.1658	1.905	2.0119	1.8861
23	1.587	2.3339	2.2405	2.2405	2.0351	2.0936	1.6956
24	1.9231	1.5684	2.2032	2.1658	2.0165	2.0182	2.0911
Max	2.9313	3.4728	3.5082	3.2819	3.5101	3.3608	3.0247
Min	1.4582	1.531	1.9605	1.9044	1.7918	1.5089	1.6956
Avg	1.6684	2.3538	2.5056	2.4069	2.4832	2.3525	2.1890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 205 / 11 kV VILSON ROOFING
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5117	1.8671	2.9874	2.6139	2.8753	2.9569	2.4451
2	3.5818	1.9605	3.2114	2.4646	2.9874	2.6505	2.5873
3	3.6031	1.9605	3.0994	2.6513	2.838	2.7801	2.3891
4	3.5667	1.9044	2.8753	2.6139	2.838	2.5606	2.268
5	3.6408	1.8671	3.1367	2.6886	2.7633	2.4434	2.1216
6	3.6031	1.8671	2.9874	2.4646	2.7073	2.3777	1.8604
7	2.7641	1.8671	2.7073	2.2779	2.7073	2.2744	1.9909
8	2.0119	2.6886	2.0911	1.9418	2.726	2.268	2.1033
9	1.8671	3.2861	4.0329	2.838	3.1367	3.3048	2.7166
10	2.0911	3.1499	3.8711	3.8866	3.7342	3.5848	2.7073
11	2.0538	4.1307	4.4963	4.1914	3.8089	4.1076	3.4541
12	2.0911	3.5101	4.0581	3.4934	3.3608	4.1823	
13	1.9044	2.5206	2.915	2.2779	2.9874	2.4272	3.1367
14	1.8671	3.7902	3.4139	2.8597	3.1367	2.2405	3.4355
15	1.8298	4.425	3.6222	2.8715	3.4355	2.9874	3.5475
16	1.8671	4.2383	3.7912	2.9127	3.6595	3.2861	3.5848
17	1.8671	3.4751	4.0472	3.2674	2.9874	2.7721	2.838
18	1.9418	3.2198	3.5437	3.0178		2.5393	2.6139
19	1.9418	3.3008	2.7073	3.1554			2.6886
20	1.8671	3.2674	2.9874	2.6139	2.5072	2.0271	2.452
21	1.7924	3.2861	2.2779	2.5766	2.9729	2.0622	2.6101
22	1.8671	3.5848	1.419	2.6139	2.6703	1.9719	2.6863
23	1.9418	3.2861	3.1367	2.7633	2.5463	3.2579	2.6673
24	3.6591	1.7177	3.1741	2.5393	2.9874	3.1971	2.6505
Max	3.6591	4.425	4.4963	4.1914	3.8089	4.1823	3.5848
Min	1.7924	1.7177	1.419	1.9418	2.5072	1.9719	1.8604
Avg	2.4472	2.9238	3.1913	2.8165	3.0170	2.7939	2.6763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 206 / 11KV Mahalaxmi

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5091	.7842	2.1658	2.5206	2.1658	2.1491	1.869
2	1.7528	.7842	2.3339	2.4272	2.4272	2.2731	1.9845
3	1.6301	.7842	2.4272	2.5393	2.3899	2.3102	1.9004
4	1.8298	1.1203	2.5393	2.4646	2.4646	2.3045	1.9774
5	1.8473	1.4937	2.5393	.9335	2.3899	2.3101	1.8473
6	1.922	1.4937	1.1203	2.1658	2.4272	2.2744	1.7924
7	2.2032	1.4937	1.6804	2.1658	2.3899	1.8814	2.3405
8	.5765	1.0456	.7842	1.4937	.7842	.679	.5716
9	.7842	1.6804	1.643	2.3152	1.1203	1.1191	1.0166
10	.7842	1.1584	2.5048	1.8671	1.3443	3.4355	3.2065
11	.7468	1.6787	1.7541	2.5652	2.5579	3.3608	3.3608
12	.7468	1.5123	3.2861	1.9521	2.6139	3.2861	
13	.7468	1.1088	1.8298	1.6655	2.6139		1.9605
14	.7468	2.1582	1.8671	3.1554	2.5766	2.3899	2.0911
15	.7468	1.1157	1.8473	2.5503	2.6139	2.2405	2.0165
16	.7468	2.3655	1.9044	1.1946	1.1949	1.531	1.3817
17	.7842	1.7364	1.8665	2.7721	.9335	1.1403	2.1658
18	.7842	1.643	1.5684	2.2592		1.9791	1.7924
19	.7842	1.6057	1.9418	2.2032			2.5393
20	.7842	1.5684	1.3443		1.8861	1.1191	2.0911
21	.8215	1.4937	2.2405	2.0538	2.1582	1.3672	1.9243
22	.8299	2.0911	2.2405	2.2405	1.4449	1.7718	1.6385
23	.8299	1.7924	1.9605	2.6513	2.1658	2.3777	2.6482
24	.4851	.8215	2.4272	2.5393	1.8671	2.2862	2.0233
Max	2.2032	2.3655	3.2861	3.1554	2.6139	3.4355	3.3608
Min	.4851	.7842	.7842	.9335	.7842	.679	.5716
Avg	1.0593	1.4387	1.9924	2.2041	2.0241	2.0721	2.0061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 201 / 11 KV Vardhaman Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768		1.9433	2.4768		2.0957	1.9433
2	2.2862		1.9433	2.2862		2.1338	1.9052
3	2.0957		1.9814	2.0957		2.0195	1.8671
4	1.9052		1.9814	1.9052		2.0576	1.8671
5	2.0195		2.0195	1.9052		1.9814	1.7909
6	2.0576		1.9624	1.7909		1.9433	1.6385
7	1.829		2.0195	2.0195		1.9433	1.448
8	1.7718		2.0195	1.829		2.0767	1.448
9	1.6385	2.0195	2.7625	2.1148	2.6292	2.5911	
10	1.6766	2.572	2.553	3.1055	2.3624	2.8578	
11	1.6956	2.3243	3.0102	2.8959	3.1626	2.8578	
12		2.191	2.8578	2.934	3.2007	3.2007	
13		2.553	2.4768	2.4768	2.6673	2.9531	
14		2.6292	2.9721	3.0102	3.1626	3.3532	
15		2.8006	3.2007	3.1436	3.2388	3.2007	
16		2.934	3.1817	2.2862	2.8578	2.8578	
17		2.6101	2.4768		1.9624	2.21	2.553
18		2.3624	2.0195			1.7909	2.4768
19		2.21	1.9052		2.191		2.3243
20		1.7909	2.0386		1.5623		1.7337
21		2.0386	2.7244		2.0957		2.21
22		1.9624	2.4768		2.21	2.5911	2.5911
23		1.9814	3.0102		2.3434	2.0957	2.2862
24	2.3434		2.0195	2.4006		2.3243	2.0576
Max	2.4768	2.934	3.2007	3.1436	3.2388	3.3532	2.5911
Min	1.6385	1.7909	1.9052	1.7909	1.5623	1.7909	1.448
Avg	1.9830	2.3320	2.3982	2.3927	2.5462	2.4350	2.0088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 202 / 11 KV Mather & Platt
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193		1.4861	1.448		1.3336	1.2574
2	1.2193		1.3336	1.3717		1.2955	1.2574
3	1.2193		1.3717	1.3717		1.2955	1.2765
4	1.2193		1.448	1.448		1.3336	1.2765
5	1.2384		1.5242	1.4861		1.3336	1.2574
6	1.2384		1.5623	1.5242		1.3336	1.2955
7	1.2384		1.5432	1.5623		1.2955	1.3717
8	1.3336		1.6766	1.448		1.3336	1.4861
9	1.3336		1.9433	1.467	1.7718	1.5242	
10	1.3146	1.6385	1.9052	2.0957	1.9052	1.7337	
11	1.3146	1.9433	1.7909	2.0957	1.829	1.829	
12	1.2955	1.8671	1.9433	2.0386	2.0576		
13	1.3146	1.6385	1.5242	1.7718	1.7528	2.0386	
14	1.3146	1.9433	1.9433	1.6956	1.7909	1.9624	
15	1.3146	1.829	1.8099	1.7909	1.7909	1.9052	
16	1.3146	1.5432	1.9052	1.6385	1.6385	1.9433	
17		1.7147	1.7528		1.6766	1.9433	1.7337
18		1.6385	1.5623			1.7147	1.6385
19		1.5051	1.5813		1.3336		1.3717
20		1.467	1.4861		1.3146		1.2193
21		1.467	1.4289		1.2955		1.2003
22		1.467	1.448		1.3336	1.3146	1.2003
23		1.4861	1.5242		1.2384	1.3336	1.2193
24	1.2384		1.5242	1.5242		1.3336	1.2955
Max	1.3336	1.9433	1.9433	2.0957	2.0576	2.0386	1.7337
Min	1.2193	1.467	1.3336	1.3717	1.2384	1.2955	1.2003
Avg	1.2754	1.6535	1.6258	1.634	1.6235	1.5565	1.3348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 205 / 11 KV Patel Petro feeder SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478		.7049	.6668		.724	.8002
2	.6478		.7049	.6668		.6859	.724
3	.6478		.7049	.6478		.6859	.724
4	.6478		.724	.6478		.724	.724
5	.6478		.724	.6478		.743	.724
6	.6478		.724	.6668		.743	.724
7	.6668		.743	.6859		.7811	.6859
8	.6859		.8383	.6478		.743	.724
9	.724	1.5242	1.5813	1.5432	1.6385	1.2765	
10	.724	1.5051	2.21	1.2193	1.6575	1.5432	
11	.7049	1.848	1.1812	1.3908	1.6385	1.6194	
12	.6859	1.9624	1.2955	1.0479	1.7337	1.9814	
13	.724	1.8099	1.9433	1.7718	2.0195	1.467	
14	.724	1.3336	1.9433	1.448	2.3624	1.5051	
15	.743	1.7337	1.7528	1.1241	2.21	1.4861	
16		1.3908	1.6385	1.1241	1.7718	1.8099	
17		1.3908	1.4289		2.0386	1.2574	1.3146
18		.8383	1.2193			1.2765	1.7147
19		.8002	.743		1.086		.8954
20		.724	.6859		.724		.743
21		.6859	.7049		.743		.743
22		.724	.6668		.743	1.7909	.6859
23		.724	.6478		.743	.9907	.6668
24	.6478		.724	.6668		.724	.9526
Max	.743	1.9624	2.21	1.7718	2.3624	1.9814	1.7147
Min	.6478	.6859	.6478	.6478	.724	.6859	.6668
Avg	.6823	1.2663	1.0931	.9773	1.5078	1.1694	.8466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 206 / 11KV Devi gas

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621		.8383	.8383		.8002	.9145
2	.7621		.8002	.8002		.8002	.8002
3	.7621		.8002	.8002		.7621	.8002
4	.7621		.8002	.7621		.7621	.8002
5	.8383		.7811	.7621		.7621	.8002
6	.9335		.8383	.7621		.7621	.8002
7	1.0098		.7811	.7621		.7049	.8573
8	.6478		1.1431	.8573		.724	.9907
9	.6859	1.0288	1.0669	1.1812	1.448	1.2765	
10	.6859	1.0479	1.4861	1.2574	1.5242	1.6004	
11	.6859	1.4289	1.4098	1.7528	1.6956	1.2193	
12	.6668	1.3146	1.5242	1.5813	1.5432	1.0098	
13	.6859	1.4289	1.467	1.4289	1.4098	1.448	
14	.7049	1.1812	1.6766	1.5432	1.6766	1.2193	
15	.7049	1.1431	1.3336	1.2574	1.4861	1.6385	
16	.7049	1.086	1.448	1.6194	1.5242	1.5051	
17		1.4289	1.3336		1.7909	1.6956	1.7528
18		1.2955	1.3336			1.4861	1.5432
19		1.105	1.2193		1.0669		1.3527
20		1.1241	1.2384		1.1622		1.2384
21		.9717	1.1812		1.2003		1.2003
22		1.0669	1.0669		1.1622	1.0479	.9907
23		.9907	.9907		.9717	1.0479	.7621
24	.8192		.9526	.9717		.8383	.9907
Max	1.0098	1.4289	1.6766	1.7528	1.7909	1.6956	1.7528
Min	.6478	.9717	.7811	.7621	.9717	.7049	.7621
Avg	.7542	1.1761	1.1463	1.1140	1.4044	1.1005	1.0372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 201 / Mhakve AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1006	.1886	1.5813	
2	.1543	.1715	.1006	.1886	1.5813	
3	.1543	.1715	.1006	.1886	1.5813	
4	.1543	.1715	.1006	.1886		
5	.1543	.1715	.1006	.1886	1.5813	
6	.1543	.2286	.1174	.1886	1.7528	
7	.1715	.2286	.1174	.1886	.2096	1.2003
8		.1524	.0838	.2477	.2096	1.2955
9	2.0386		2.1795	2.4006	.2667	1.3336
10	2.1529	2.5149		2.4577		1.105
11		2.1874	2.1776			.1524
12		2.0687	1.9033	2.3624		.1334
13	2.0576		2.0576	2.2672		.1334
14	2.21		2.0576	2.2481	.1886	.1143
15	2.1338		1.6632	2.191	.1886	.0953
16	2.0195	1.8991			.2058	.1143
17	.1524	1.8652		.2286	.2572	.1334
18	.1334	1.9161		.2858	.1543	
19	.2858	.1017	.2058	.2477		.1524
20	.2667	.1187	.2229			.1524
21	.2858	.1357	.2229			.1524
22	.2286	.1187	.2229	.1905		.1715
23	.2286	.1187	.2058	1.7528		.1524
24	.1715	.2286	.1174	.2058	1.6766	
Max	2.21	2.5149	2.1795	2.4577	1.7528	1.3336
Min	.1334	.1017	.0838	.1886	.1543	.0953
Avg	.7371	.7370	.7029	.9203	.8168	.412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 202 / Mhakve Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3429	.3511	.3547	.2096	.2987	.2477
2	.3361	.3429	.3511	.3547	.2096	.2801	.2477
3	.3361	.3429	.3511	.3547	.2096	.2801	
4	.3361	.3429	.3511	.3547		.2801	.2477
5	.3361	.362	.3696	.3734	.3239	.2801	.2477
6	.3547	.4001	.3881	.3921	.381	.2987	.2667
7	.3734	.362	.3881	.4108	.362	.3174	.2858
8		.3429	.3511	.362	.3429	.3361	.2858
9	.3048		.3142	.3239	.3429	.3361	.3048
10	.3429	.3048		.362	.3174	.3547	.3048
11		.3142			.3361	.3921	.2477
12		.3326	.4481	.381	.3547	.3174	.362
13	.362	.3326	.4294	.381	.3734		.3429
14	.3429	.3326	.4294	.381	.3734		.3429
15	.3239	.2957		.362	.3361		.362
16	.3239	.3511			.3361		.4191
17	.3429	.3881	.3547	.3429	.3734		.3239
18	.2858	.3881	.3921	.4763	.3734		
19	.4191	.3881	.4668	.5144			.4191
20	.5906	.5914	.5788				
21	.5525	.5175	.5601				.5525
22	.5335	.4805	.5228	.4382			.4954
23	.4191	.3696	.4481	.381	.3361		.381
24	.3547	.381	.3696	.3921	.3239	.3174	.2667
Max	.5906	.5914	.5788	.5144	.381	.3921	.5525
Min	.2858	.2957	.3142	.3239	.2096	.2801	.2477
Avg	.3765	.3742	.4108	.3846	.3271	.3145	.3311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 203 / Kenavade Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.3717		1.1831	.0953		
2	1.2003	1.3336		1.1488			
3	1.2003	1.3336	1.1603	1.0631	.0953		
4	1.2003	1.3336	1.1603	1.0631	.0953		
5	1.2517	1.3146		1.0631	.1143		
6	1.4403	1.5813		1.286	.1143		
7	1.4575	1.7337	1.5415	1.4232	.1334		
8	1.2431	1.5242	1.3757	1.3527	.1524		
9	.1524	.1492			1.5623		
10	.1334				1.8347	.3601	
11	.1326				1.8004	1.166	
12					1.6975	1.3717	
13	.1143			.1334	1.5604		
14	.1334		.1372	.1524	1.5775		
15	.1524	.1492	.12	.1524	1.4575		
16	.1334	.1492	.12		1.4403		
17	.1524	.1823	.12		.1372		
18	.1715	.1658	.12	.1334	.1372		
19	.1524	.1492	.12	.1524			.0953
20	.1334	.1492	.1372				.0953
21	.1334	.1326	.12				.0762
22	.1334	.116	.12	.1143			.0762
23	1.448	1.2763	1.4575	.1143			.0762
24	1.2346	1.448		1.3546			
Max	1.4575	1.7337	1.5415	1.4232	1.8347	1.3717	.0953
Min	.1143	.116	.12	.1143	.0953	.3601	.0762
Avg	.6408	.8207	.5578	.7431	.8238	.9659	.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 401 / G.Shirgaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	4.5782
Max	4.5782
Min	4.5782
Avg	4.5782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 403 / sidhnerli

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	3.2487
Max	3.2487
Min	3.2487
Avg	3.2487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 404 / 33 KV Samir

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	4.0124
Max	4.0124
Min	4.0124
Avg	4.0124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 405 / kagal

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	4.0124
Max	4.0124
Min	4.0124
Avg	4.0124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 406 / 33 KV Menon BRG

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	3.8066
Max	3.8066
Min	3.8066
Avg	3.8066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 601 / 110KV Shahu CoGen NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 132 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-MAY-17
HR	Load (MW)
24	2.8807
Max	2.8807
Min	2.8807
Avg	2.8807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 404 / 33Kv Raymond

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)
22		3.9918
24	4.0638	
Max	4.0638	3.9918
Min	4.0638	3.9918
Avg	4.0638	3.9918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 406 / 33KV Anshul

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	3.8452
Max	3.8452
Min	3.8452
Avg	3.8452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 407 / MUDSHINGI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	1.4563
Max	1.4563
Min	1.4563
Avg	1.4563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 401 / 33KV Oswal Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	3.8066
Max	3.8066
Min	3.8066
Avg	3.8066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 402 / 33KV Metro Feeder

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 404 / 33KV Kirloskar Feeder

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	4.4239
Max	4.4239
Min	4.4239
Avg	4.4239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 405 / 33KV Minor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	2.8778
Max	2.8778
Min	2.8778
Avg	2.8778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 406 / 33KV Apple Spong

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	2.4691
Max	2.4691
Min	2.4691
Avg	2.4691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 407 / Mantri Metal

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	2.6886
Max	2.6886
Min	2.6886
Avg	2.6886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 408 / 33KV KOEL Exp NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	3.922
Max	3.922
Min	3.922
Avg	3.922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 409 / 33KV UTP

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	3.6523
Max	3.6523
Min	3.6523
Avg	3.6523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 410 / 33KV GPI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	4.2593
Max	4.2593
Min	4.2593
Avg	4.2593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 411 / 33 kv Hupari Feeder

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	.8779
Max	.8779
Min	.8779
Avg	.8779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 201 / 11KV KAPASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.0566	.0572		.0953	.2075
2	.0572	.0572	.0566			.0953	.2263
3	.0572	.0572	.0566	.0572		.0953	.2641
4	.0572	.0381	.0566	.0572		.1143	.2829
5	.0572	.0381	.0566	.0572		.1334	.2641
6	.0572	.0572	.0566	.0572		.1334	.3584
7	.0572	.0762	.0566	.0572		.1143	.4715
8	.0572	.0572	.0566	.0572		.2096	.3206
9	1.2003	.7811	.7167	.6478		.0191	
10	1.2003	.6859	.6224	.6478		.0377	
11	.9907	.6224	.5716			.0377	
12	.8192	.547	.5335	.4191			.0762
13	.8573	.6224		.4382		.0566	.0762
14	.724	.5847	.4001	.4382			.0572
15	.6287	.5847	.3429				.0572
16	.5335	.3395	.3239			.0754	.0572
17	.0381	.0754	.0762			.0566	.0572
18	.0381		.0762		.1143	.0943	.0572
19	.0572	.0754	.0572				.0572
20	.0572		.0572		.0381		.0762
21	.0762	.0566	.0572		.0381		.0762
22	.0572	.0566	.0572		.0381		
23	.0572		.0572		.0381		.0953
24	.0572	.0381	.0566	.0572		.0381	.0377
Max	1.2003	.7811	.7167	.6478	.1143	.2096	.4715
Min	.0381	.0381	.0566	.0572	.0381	.0191	.0377
Avg	.3271	.2614	.1939	.2345	.0533	.0879	.1588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 202 / 11 KV Hasoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.6668		.4001	.0762	
2	.381	.6668	.2263	.4001	.0762	
3	.381	.6287	.4715	.381	.0762	
4	.4191	.6668	.3961	.381	.0762	
5	.4572	.6859	.3961	.4382	.0762	
6	.5335	.7621		.5716	.0762	
7	.6097	.7049	.4338	.4572	.0762	
8	.0953	.0762	.0943	.0572		
9	.0762	.0762	.0943	.0572	.5525	
10	.0762	.0762	.0943	.0572	.6478	
11	.0762	.0566	.1524		.6478	
12	.1143		.0762	.0762	.724	
13	.0953		.0762			
14	.0953		.0762	.0381	.8002	
15	.0762		.0762			.1905
16	.0762		.0762			
17	.0953		.0762			
18	.0762	.1509	.0762			
19	.0572	.132		.0572		.2096
20	.0762		.0762	.0572		.2096
21	.0762	.0754	.0762	.0572		.2096
22	.8383	.5658	.4954	.0953		
23	.724		.4572	.0953		.1905
24	.4191	.6287		.4191	.0762	
Max	.8383	.7621	.4954	.5716	.8002	.2096
Min	.0572	.0566	.0762	.0381	.0762	.1905
Avg	.2643	.4138	.1999	.2276	.3063	.2020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 203 / 11 KV MUGALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.1132	.1524	.5144	.5716	.3772
2	.1715	.1715	.1132	.1524	.4954	.5335	.3961
3	.1715	.1334	.1509	.1334	.4954	.4954	.3772
4	.1905	.1334	.1509	.1334	.5716	.4572	.3961
5	.1905	.1524	.1509	.1524	.5716	.4954	.415
6	.1905	.1905	.1509	.1715	.1715	.5335	.4715
7	.1905	.1905	.1509	.0572	.2096	.5335	.4715
8	.1905	.1905	.1509	.0572			.5281
9	1.2384	.9145	.8488	.8764	.1905		
10	1.086	.8383	.7545	.8192	.1905		
11	.9526	.679	.7621		.1905	.1132	
12	.8002	.6602	.6668	.7621	.1905	.1509	
13	.8002		.6478	.8002	.1905	.1509	
14		.6224	.6668	.743		.132	
15	.7621	.6036	.6668			.132	
16	.724	.6036	.6478	.6668	.1715		
17	.2286	.1509	.1715	.1715	.1905		
18	.2096	.132	.1905	.1715	.1905	.1886	
19	.2096	.132	.0191	.1715			
20	.2096		.1715	.1715	.1334		
21	.1905	.132	.1905		.1143		
22	.1905	.132	.1715	.6097	.1143		
23	.1905		.1905	.6097	.1334		
24	.1905	.1905	.1132	.1715	.5335	.1334	.0754
Max	1.2384	.9145	.8488	.8764	.5716	.5716	.5281
Min	.1715	.132	.0191	.0572	.1143	.1132	.0754
Avg	.4117	.3393	.3338	.3693	.2782	.3301	.3898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 204 / 11 KV LINGNOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8002		.6859	.0572	.0572	.0377
2	.724	.7621	.6602	.6859	.0381	.0381	.0377
3	.6859	.7621	.8488	.6668	.0572	.0381	.0377
4	.7621	.8002	.7922	.6668	.0572	.0381	.0377
5	.8383	.8764	.8676	.7049	.0572	.0381	
6	.9145	.9907		.7621	.0572	.0572	.0377
7	.8383	.9526	1.0374	.8002	.0762	.0572	.0377
8	.0572	.0762	.0943			.0572	.0377
9	.0572	.0572	.0943		.9335	1.0288	
10	.0572	.0572	.0754	.0762	1.1431	.9808	
11	.0572	.0566	.0572		1.1431	1.0185	
12	.0381	.0377	.0572	.0572	.9907	.9431	.8002
13	.0381		.0572	.0572	1.0288	.8488	.8002
14	.0381		.0572	.0572	1.0288	.7922	.7621
15	.0381		.0572		.9145	.7545	.7621
16	.0381		.0953	.0572	.8002	.8488	.3429
17	.0381		.0953	.0381	.0572	.0377	.0381
18	.0762		.0762	.0381	.0572	.0377	.0381
19	.0572		.0572	.0381			
20	.0762	.0377	.0572	.0381	.0572		.0572
21	.0572	.0377	.0572		.0572		.0572
22	.9145	.9431	.7811	.0572	.0572		
23	.9145		.7621	.0572	.0572		.0572
24	.7621	.8002		.724	.0572	.0381	.0377
Max	.9145	.9907	1.0374	.8002	1.1431	1.0288	.8002
Min	.0381	.0377	.0572	.0381	.0381	.0377	.0377
Avg	.3684	.5030	.3208	.3299	.3992	.4058	.2232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 205 / 11 KV Arjunwada Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.0943		.4954	.4191	.0943
2	.1143	.0953	.0943		.4763	.4191	.132
3	.0953	.0953	.1132		.4763	.381	.1886
4	.1143	.0953	.1132		.5144	.381	.2829
5	.1143	.0953	.1132		.5335	.9907	.3018
6	.1334	.1143	.1132		.0762	.4572	.3206
7	.1334	.1143	.1132		.1143	.4954	.3395
8	.1334	.1143	.1132				.3206
9	.9907	.8002			.1334		
10	.9907	.8002			.1334		
11	.8573	.7167		.0762	.1143	.0754	
12	.7621	.6602	.6859	.743	.1143	.0754	.0953
13	.6859		.6859	.724	.1334	.0754	.0953
14	.724	.6602	.5525	.6478	.0953	.0754	.1524
15	.724	.6413			.1143	.0754	.1715
16	.6668	.6036	.3239	.6097	.1143		.1905
17	.0572	.1132		.0953	.1143		.1905
18	.0762	.1132	.0762	.0953	.1334	.0943	.1905
19	.0762	.132	.0762	.0953			.2286
20	.0953	.1029	.0572	.0953	.0953		.2286
21	.0953	.1132	.0762	.0953	.0762		.2286
22	.1143	.1132	.0762	.5716	.0953		
23	.0953		.0762	.5716	.0762		.2286
24	.1143	.1143	.0943		.5144	.0762	.0566
Max	.9907	.8002	.6859	.743	.5335	.9907	.3395
Min	.0572	.0953	.0572	.0762	.0762	.0754	.0566
Avg	.3366	.2965	.1920	.3684	.2156	.2922	.2019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 206 / 11 KV Vadgaon Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.362	.3772		.3239	.3429	.2829
2	.3048	.3429	.3584		.2858	.3429	.2641
3	.3048	.3429	.3395		.2858	.3239	.2829
4	.2858	.3239	.3206		.3429	.3048	.2452
5	.3239	.3429	.3584		.3429	.3239	.2641
6	.3429	.4191	.3584		.4001	.4001	.3395
7	.4001	.4001	.415		.381	.4382	.3772
8	.381	.381				.4001	.3772
9	.381	.3429	.3772		.4191	.4763	
10	1.2003	.3429	.3395		.4001		
11	.2858	.3395			.3429	.3584	
12	.3048	.3018		.3429	.3239		
13	.3048	.3395		.3429	.362	.4527	.4572
14	.3048	.3018		.3048	.4001	.415	.4763
15	.2858	.3206				.4527	
16	.3048	.3584				.4338	.4382
17	.3048	.3584		.381			.4382
18	.3239	.3772		.5716	.5335		.4382
19	.5525	.5847		.6097			.5906
20	.724	.7167		.6478	.6859		.7621
21	.6668	.6036		.6097	.6478		.743
22	.5716	.5658		.5144	.5716		
23	.4572			.4191	.4382		.5716
24	.381	.381	.3961		.362	.362	.3018
Max	1.2003	.7167	.415	.6478	.6859	.4763	.7621
Min	.2858	.3018	.3206	.3048	.2858	.3048	.2452
Avg	.4183	.3978	.3640	.4744	.4131	.3885	.4250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 207 / 11 KV BALEGHOL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.2641		.2286	.2096	.2075
2	.2286	.2477	.2641		.2286	.1905	
3	.2096	.2286	.2641		.2477	.1715	.2075
4	.2096	.2286	.2452		.2477	.1715	.2263
5	.2286	.2286	.3018		.2667	.1905	
6	.2286	.2667			.2858	.2477	
7	.2667	.3048	.3206		.3048	.2286	.2829
8	.2667	.3048	.3206			.2477	.2641
9	.2667	.3048	.2452		.2667	.3429	
10	.2477	.2667	.2641		.2477		
11	.2477	.2452			.2477	.3584	
12	.2286	.2452		.2477	.2667	.3018	.3239
13	.2477	.2452		.2477	.2667	.3206	.2858
14	.2477	.2263		.2477	.2858	.3018	.2858
15	.2477	.2452				.2641	
16	.2667	.2452		.1715	.3239	.3206	.2667
17	.2667	.3206		.2858	.381	.3206	.3048
18	.2858	.3772		.3239	.3429	.3772	.2858
19	.362	.3772		.381			.381
20	.4763	.4715		.381	.2667		.4572
21	.4382	.4527			.362		.4191
22	.4001	.3961		.3239	.3239		
23	.362			.2667	.2667		.3429
24	.2858	.2858	.2829		.2477	.2286	.1886
Max	.4763	.4715	.3206	.381	.381	.3772	.4572
Min	.2096	.2263	.2452	.1715	.2286	.1715	.1886
Avg	.2818	.2948	.2773	.2877	.2812	.2663	.2956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 208 / 11 KV JAINAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6097	.6413		.5906	.5335	.5658
2	.5335	.5716	.5847		.5335	.4954	.547
3	.4954	.5144	.5658		.5335	.4763	.5281
4	.5144	.4954	.5658		.5716	.4572	.547
5	.5335	.5144	.6224		.5906	.5144	.5658
6	.5906	.6097			.6668	.6097	.6224
7	6.7635	.5144				.5716	.547
8	.4763	.4763	.4904		.4954	.4572	.6036
9		.5144	.5281		.5525	.4763	
10	.4954	.5144	.5093		.5525		
11	.4572				.5525	.547	
12	.4954	.6224		.4572	.6287		.5906
13	.5335	.6224		.5144	.5525	.6413	.6287
14	.4954	.5847		.5335	.6668	.679	.6668
15	.4954				.5906		
16	.4572	.5658			.6668	.6979	.6668
17	.4954	.6036		.6859	.6859	.7167	.6668
18	.5335	.5281		.743	.6287	.6602	.6859
19	.7049	.7356		.8192			.7811
20	.9145	.9054		.8764	.8573		1.0098
21	.8954	.8299		.8383	.8192		.9335
22	.8573			.7811	.7621		
23	.724			.6859	.6097		.724
24	.6097	.6478	.6602		.6287	.5716	.5658
Max	6.7635	.9054	.6602	.8764	.8573	.7167	1.0098
Min	.4572	.4763	.4904	.4572	.4954	.4572	.5281
Avg	.8540	.5990	.5742	.6935	.6244	.5691	.6551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045] BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 209 / 11 KV Madyal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 201 / 11 Kv Sonage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.3663		
10		.0171	
14			.0171
16		.0181	
17		.0179	
18		.0181	
19		.0183	
20		.0181	
24	2.4691		
Max	2.4691	.0183	.0171
Min	2.3663	.0171	.0171
Avg	2.4177	.0179	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 202 / 11 KV HAMIDWADA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
10		1.5775	
14			1.2136
16		1.0608	
17		.0181	
18		.0183	
19		.0179	
20		.0183	
24	.0171		
Max	.0171	1.5775	1.2136
Min	.0171	.0179	1.2136
Avg	.0171	.4518	1.2136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 203 / 11 KV ARJUNNAGAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6173		
10		.6173	
14			.6836
16		.6584	
17		.7023	
18		.7842	
19		.9335	
20		1.1949	
24	.6516		
Max	.6516	1.1949	.6836
Min	.6173	.6173	.6836
Avg	.6345	.8151	.6836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045] BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 204 / 11 KV SURUPALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 205 / 11 KV Banage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2058		
10		3.0864	
14			2.774
16		2.5339	
17		.1433	
18		.1478	
19		.1433	
20		.1448	
24	.2058	3.0864	
Max	.2058	3.0864	2.774
Min	.2058	.1433	2.774
Avg	.2058	1.3266	2.774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 206 / CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7888		
10		.0514	
14			.0526
16		.0373	
17		.037	
18		.0549	
19		.0543	
20		.0549	
24	.823		
Max	.823	.0549	.0526
Min	.7888	.037	.0526
Avg	.8059	.0483	.0526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045] BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 201 / 11 KV MURGUD Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0572		
2	.0566		
3	.0572		
4	.0566	.0514	.0716
5	.0572		
6	.0572		
7	.0572		
8	.0572	.0514	.0686
9	2.6749	2.0622	2.3266
10	2.8464	2.3472	
11	2.8121		
12	2.7435	2.079	
13			2.3045
14		2.0622	2.4939
15		2.1125	
16		2.079	
18		.0514	
20		.0526	
22	.0514	.0701	
23	.0514	.0693	
24	.0572	.0514	
Max	2.8464	2.3472	2.4939
Min	.0514	.0514	.0686
Avg	.7796	1.0107	1.4530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045] BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 208 / 11 KV Murgud VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348			
2	.6348		.6154	
3	.6348			
4	.5975		.6516	
5	.6283			
6	.6653		.7421	
7	.6219		.6878	
8	.5914	.6173	.6878	
9			.695	.1696
10				.2058
11				.703
12			.7682	.6859
13			.905	
14		.724	.8048	
15		.724		
16		.724		
18		.7373		
20		1.0498		
22	.8589	.905		
23	.7186	.7602		
24	.679	.6805	.7316	
Max	.8589	1.0498	.905	.703
Min	.5914	.6173	.6154	.1696
Avg	.6605	.7691	.7289	.4411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045] BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 403 / 33 KV Sonali LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)
3		.2572
4		.3601
5		.463
6		.5258
8	.5658	.5596
9	.5658	.5721
10	.5658	
11	.5658	
12	.5658	
13	.5144	.4115
14	.5658	.5721
15	.5144	
16	.5258	
Max	.5658	.5721
Min	.5144	.2572
Avg	.5499	.4652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 201 / Bhadgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6057	1.6956		1.595	.0857		
2	1.5729	1.643		1.4563	.0857		
3	1.5238	1.6278	1.6221	1.387	.0857		
4	1.5565	1.6787	1.6712	1.3523	.0857		
5	1.7859	1.7269	1.8842	1.439	.1029		
6	1.9662	2.1195		1.8378	.1029		
7	1.8515	1.9719	1.9662	1.7857	.0857		
8	.0819	.0983	.0819	.0876	.0857		
9	.0983	.081	.0914	.0678	2.1434		
10	.0983	.0655	.1227	.0848	2.9321	1.491	
11	.0819	.0655	.1006	.1029	2.9492	1.4255	
12	.0486	.0819	.0848	.1017	3.0178	1.8023	
13	.0503	.0819	.0848	.1029	2.8178	1.7976	
14	.0324	.0791	.0838	.1029	2.6543	1.7814	
15	.0838	.0791		.0857	2.5149		1.3717
16		.0983	.0693		2.2045	1.1797	1.3413
17	.1341	.1147	.0686	.0686	.0671	.0492	.0686
18	.0838	.1107	.0686		.081	.0492	.0678
19	.081	.0983	.0876	.0857		.0655	.0848
20	.0983	.0819	.104	.0857			.0857
21	.0838	.0819	.0867	.0857			.1017
22	2.304	2.2611	1.7604	.0857			.0857
23	2.2043	2.1464	1.8378	.1029			.0886
24	1.5432	2.1195		1.7364	.0857		
Max	2.304	2.2611	1.9662	1.8378	3.0178	1.8023	1.3717
Min	.0324	.0655	.0686	.0678	.0671	.0492	.0678
Avg	.8248	.8420	.6251	.6291	1.1678	1.0713	.3662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 202 / Sonali AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1802		.1052	1.2517		.3441
2	.1638	.1802		.104	1.2517		.3932
3	.1638	.1658	.0983	.104	1.2346		.426
4	.1638	.1823	.0983	.1052	1.2346		.4096
5	.1581	.1844	.0983	.104	1.2346		.426
6	.1638	.1823		.104	.0857		.4424
7	.1638	.1677	.0983	.104	.1029		.4588
8	.1311	.1326		.1063	.1029		.4588
9	.1147	2.9673	2.7199	2.5819	.1372		.0164
10		2.8509		2.649	.1372		.0328
11	3.0007	2.7199	2.4086	2.4863	.144	.6062	.0343
12	3.2236	2.6216	2.4413	2.3537	.144	.0164	.0354
13	3.1207	2.4741	2.6216	2.4006	.1372	.0162	.0347
14	2.8826	2.3758	2.5724	2.3834	.1406	.0162	.0362
15	2.7092	2.3758		2.3491	.1265	.0164	.0343
16	2.6749	2.3266	1.933	1.989	.128	.0328	.0343
17	.1886	.1311	1.7833	.12	.1341	.0328	.0362
18	.2401	.1638	1.5939	.12	.1296	.0328	.0343
19	.2105	.1311	.1227	.0857		.0328	.0362
20	.213	.1311	.1052	.0857		.0164	.0362
21	.218	.1475	.104	.0857		.0164	.0543
22	.1966	.1423	.1029	1.5432		.0164	.0362
23	.1966	.1475	.104	1.4918		.0164	.0354
24	.1638	.1802		.1052	1.3717		.0164
Max	3.2236	2.9673	2.7199	2.649	1.3717	.6062	.4588
Min	.1147	.1311	.0983	.0857	.0857	.0162	.0164
Avg	.8968	.9693	1.118	.9861	.4857	.0668	.1626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 203 / Sawarde VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5973	.6401	.5243	1.1763	.985	.5228	.7865
2	.5611	.6154	.5079	1.1273	.985	.4887	.7701
3	.5611	.6036	.5407	1.1088	.985	.4755	.7373
4	.543	.6335	.5407	1.0974	.985	.4706	.7537
5	.6154	.695	.5898	1.134	1.0208	.499	.8029
6	.7059	.7421	.639	1.2308	1.7013	.6161	.8684
7	.6516	.7499	.5735	1.1403	1.1283	.6154	.9175
8	.5365	.6584	.5243	1.1949	1.0566	.567	.8848
9	.5407	.6805	.5243	1.1222	1.0208		.9667
10		.5571	.5731	.5784		.6226	.9175
11	.591	.5243	.5609	.6024	.6733	.5851	.9955
12	.5973	.5243	.5083	.5792	.6984	.6062	.6878
13	.5552	.5079	.5784	.5731		.583	.5792
14	.567	.4752	.5609	.591	.6626	.6316	.6584
15	.4801	.4752		.5731	.6268		.6878
16		.4915	.5014	.4656	.6154		.5847
17	.5014	.4744	.5731	.4835	.6516	.6226	.6089
18	.5373	.5407	.5847		.6516	.5898	.6468
19	.8596	.7537	.8413	1.5708		.7373	.7783
20	.9694	.9012	1.0059	1.5402		.6226	1.0566
21	.905	.852	.9145	1.4864		.6718	.9412
22	.9231	.7373	.7796	1.3432		.9831	.8962
23	.7316	.6226	1.4335	1.1462	.5853	.8848	.7682
24	.6335	.6516	.5407	1.226	1.0387	.5544	.8029
Max	.9694	.9012	1.4335	1.5708	1.7013	.9831	1.0566
Min	.4801	.4744	.5014	.4656	.5853	.4706	.5792
Avg	.6438	.6295	.6487	1.0040	.8929	.6167	.7957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 201 / 11KV WALWA VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5611	.7023	.6283		.3982	
2		.543	.7095			.3982	
3		.6154	.6348	.6099		.4163	
4		.6154	.6653			.4525	
5		.6878	.7468			.543	
6	.9907	.9774	.9795	.8501	.9907	.6878	
7	.8383	.9511	.924	.7762	.8383	.6154	
8	.724	.905	.7392	.7392	.7621	.5611	
9		.7133		.6653	.7621	.543	
10		.6468			.6878	.5175	
11		.6099		.5335	.6516	.462	
12		.6099			.6154	.5175	
13			.7947	.5716	.6154	.4805	
14	.6878	.5914		.5335	.6516		
15	.6697	.6838			.695		.7421
16	.7059	.7023		.6287			
17	.7133	.7023			.8215	.5544	.7095
18	.7682	.7577	.7947		.8869	.7392	.905
19	.8775	.9055	.9795	.9145		.924	1.0136
20	.9955	.9979	1.0164	.9145			1.1765
21	.8869	.8688	.8871		.6516		1.1765
22	.8688	.8145	.8131		.6516		
23	.695	.6653		.7621	.4706		.8688
24	.6478		.6908	.6468	.6859	.4344	
Max	.9955	.9979	1.0164	.9145	.9907	.924	1.1765
Min	.6478	.543	.6348	.5335	.4706	.3982	.7095
Avg	.7907	.7330	.8052	.6982	.7149	.5438	.9417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 202 / 11KV SHELEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
23	3.7723
24	4.201
Max	4.201
Min	3.7723
Avg	3.9867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 203 / 11 KV THIKPURLI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5068	.5601	.5359			
2		.4887	.5601				
3		.5121	.5544	.5359			
4		.543	.5601				
5		.6335	.5914				
6	.8002	.7602	.7762	.6283	.8764		
7	.724	.724	.6653	.7023	.724		
8	.6859	.6516	.5914	.5914	.6478		
9	.4954	.5853		.5175	.4954		
10	.4938	.5544			.4887		
11	.4706	.4805		.5335	.4706		
12		.4435					
13	.4706	.4435	.6653	.5335	.4706		
14	.5068	.499		.5716	.5068	.4435	
15	.543	.499			.543	.4435	.4163
16	.543			.5335			
17	.5792	.6653				.4805	.543
18	.543	.5175	.6653		.7095		.7964
19	.6878	.7023	.7392	.8383			.8869
20	.7421	.8131	.8131	.8573			.9412
21	.724	.7602	.7392				.905
22	.695	.7682	.7392				
23	.6154	.6653		.6097			.7316
24	.5716	.543	.5544	.5544	.5716		
Max	.8002	.8131	.8131	.8573	.8764	.4805	.9412
Min	.4706	.4435	.5544	.5175	.4706	.4435	.4163
Avg	.6051	.5983	.6516	.6102	.5913	.4558	.7458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 204 / 11 KV ARJUNWADA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
23	3.858
24	4.1152
Max	4.1152
Min	3.858
Avg	3.9866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 205 / 11 Kv Gahininath Ag LIS
Expres Feeder KV- 11 / INCOMING

PURELY LIS FEEDERS

DATE	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
4			.0924
7	.0914		.1109
8	.0905		
9	.0905		.0924
10	.0934		
11	.0934		.0953
12	.0934		
13		.0924	
14	.0934		
15	.0934		
16	.0934		
Max	.0934	.0924	.1109
Min	.0905	.0924	.0924
Avg	.0925	.0924	.0978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 201 / 11 KV DHAMOD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1104			.5765		.0173	.0191
2	1.0745	1.0974					.0191
3	1.0745		1.0402	.5868			.0191
4	1.0745	1.0974	1.0402				.0191
5	1.1104						.0191
6	1.1641	1.1317				.0173	.0191
7	1.1999	1.1269	1.1096				.0191
8	1.2715	1.286	1.1443			.0171	.0191
9		.017			.7762	1.1616	1.3253
10	.017	.017			1.2752	1.4022	1.4327
11	.0173	.0191			1.1145	1.5257	
12	.017	.0191			1.1616	1.4563	
13	.017	.0191	.017		.964	1.387	1.4327
14	.0171	.0191	.0168		.9816	1.3176	1.3969
15	.017	.0191	.017		1.3466	1.3176	1.3969
16	.0171	.0191	.0158		1.3466	1.3523	1.379
17	.017	.0191	.0164		.0171	.0191	.0191
18	.0171	.0191	.017	.0191	.0171	.0191	.0191
19	.0171	.0191	.0166			.0191	.0191
20	.0171	.0191	.0168	.0191	.0171		.0191
21	.0171	.0191	.017		.0175		.0191
22	.017	.0191	.017	.0191	.0175	.0191	
23	1.3176	1.387	.5765			.0191	.0191
24	1.2536	1.2656		.583		.0173	.0191
Max	1.3176	1.387	1.1443	.5868	1.3466	1.5257	1.4327
Min	.017	.017	.0158	.0191	.0171	.0171	.0191
Avg	.5162	.4122	.3385	.3006	.6964	.6520	.4119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 202 / 11 KV KELOSHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0191	.0168		.0173	.6241
2	.0191	.017	.0191				.6241
3	.0191		.0191	.0168			.6241
4	.0191	.0171	.0191				.6762
5	.0191		.0191				.9362
6	.0191	.017	.0191	.0166		.333	1.1616
7	.0191	.017	.0191				1.1789
8	.0191	.017		.017		.4287	1.1963
9		1.8347		2.1605	.0191	.0171	.0191
10	2.2119	2.3752			.0185		.0191
11	2.2977	2.4099		2.3101	.017		
12	2.1152	2.4099			.0171		
13	2.1152		2.1776		.0171	.0191	
14	1.9765		2.5377		.0171	.0191	
15			2.3663		.0171	.0191	
16		2.1498	1.869		.0171	.0191	
17	.9882	2.0285	1.2378		.0171	.0191	.0191
18	.0173	1.8898	1.4575	.0191	.0171	.0191	.0191
19	.0171	.0191	.017			.0191	.0191
20	.0171	.0191	.0168	.0191	.0171		.0191
21	.017	.0191	.0168		.0171		.0191
22	.0166	.0191	.0166	.0191	.0173	.0191	
23	.017	.0191	.0168			.0191	.0191
24	.0762	.0171	.0191	.0168		.0171	.0191
Max	2.2977	2.4099	2.5377	2.3101	.0191	.4287	1.1963
Min	.0166	.017	.0166	.0166	.017	.0171	.0191
Avg	.5731	.8498	.6254	.4612	.0174	.0704	.4231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 203 / 11KV DHAMOD-KELOSHI

GAOTHAN FEEDER

VILLAGE Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612		.1595	.1865		.1543	.1595
2	.1433	.1543	.1595				.1595
3	.1433		.1595	.1696			.1595
4	.1791	.1543	.1595				.1595
5	.2149		.1772				.2126
6	.1433	.2743	.2303	.2374		.2601	.3012
7	.1433	.2743	.2835				.3189
8	.2149	.2572		.2374		.3086	.3366
9		.2743		.2652	.3696		.2865
10	.1696	.1886			.2772	.1734	.2865
11	.2058	.2481			.2543	.2303	
12	.2058				.3121		
13	.2058				.2947	.2126	.1791
14	.12	.2126			.2427	.2303	.197
15	.1357	.2303	.2683		.208	.2481	.197
16	.12	.1417			.2254	.2481	.2328
17	.1543	.2481	.1326		.3121		.2686
18	.2572	.3366	.1357	.3239	.3121	.3721	.2507
19	.2915	.3721	.4409			.3544	.4119
20	.3601	.4075	.373	.4251	.3429		.2686
21	.3222	.3366	.3391		.3467		.3582
22	.2883	.2835	.2743	.2957	.2774	.2835	
23	.2058	.1949	.218			.2303	.2328
24	.1791	.1715	.1595	.1865		.1372	.1772
Max	.3601	.4075	.4409	.4251	.3696	.3721	.4119
Min	.12	.1417	.1326	.1696	.208	.1372	.1595
Avg	.1985	.2506	.2294	.2586	.2904	.2460	.2454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION

Feeder No / Name : 201 / 11KV TARALE AG (TARLE) FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION

Feeder No / Name : 202 / 11 KV TARALE GAOTHAN FEEDER

VILLAGE(TARLE) Feeder KV- 11

/ OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 201 / 11 KV SHIRGAON AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17
HR	Load (MW)
24	.5087
Max	.5087
Min	.5087
Avg	.5087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 202 / 11 KV PARITE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17
HR	Load (MW)
24	.9389
Max	.9389
Min	.9389
Avg	.9389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 203 / 11 KV AWALI-RADHANAGARI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17
HR	Load (MW)
24	1.0442
Max	1.0442
Min	1.0442
Avg	1.0442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 205 / 11 KV Awali Vg

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
19			.6516
21		.7202	
23	.2229		
24	.3429		
Max	.3429	.7202	.6516
Min	.2229	.7202	.6516
Avg	.2829	.7202	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 206 / 11KV Kanthewadi Ag.

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17
HR	Load (MW)
24	.5365
Max	.5365
Min	.5365
Avg	.5365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 207 / 11 KV Shirgaon VG
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	02-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
19			.5014
21		.5194	
24	.3403		
Max	.3403	.5194	.5014
Min	.3403	.5194	.5014
Avg	.3403	.5194	.5014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144028 / 33/11KV HASANE SUB-STATION

Feeder No / Name : 201 / 11KV DIGAS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 201 / 11 KV SOLANKUR AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
9	3.5151	3.1722	
10			2.6406
11	2.9492	3.2674	3.0178
12	2.9835	3.1786	2.8978
13	3.4808		3.4637
14	3.4294		3.2065
15	3.3608		3.0178
16	2.9492	3.7146	
17	2.6063	3.5482	
18		3.1971	
Max	3.5151	3.7146	3.4637
Min	2.6063	3.1722	2.6406
Avg	3.1593	3.3464	3.0407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 202 / 11KV KALAMMAWADI FEEDER SEPERATION/PURE AG
 AG(SOLANKUR) Feeder KV- 11 /
 OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4458				
2	.4458	.4458				
3	.4115	.4458	.4755			
4	.4115	.4458	.439			
5	.4801	.4801	.439			
6	.5487	.583				
7	.6173	.6516	.6335			
8	.6173	.6001	.6805			
11						.1372
12						.1372
13					.1372	.1715
14					.1372	.1734
15				.197	.2058	.1715
16				.2103		.1715
23	.4458	.5068				
24	.4801	.4458				
Max	.6173	.6516	.6805	.2103	.2058	.1734
Min	.4115	.4458	.439	.197	.1372	.1372
Avg	.4904	.5051	.5335	.2037	.1601	.1604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 203 / 11KV SOLANKUR VILLETTE

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5487		.2743	.4458	.0514	
2	.4458	.5144	.5544	.2743	.4458	.0343	
3	.4458	.5144	.5249	.2743	.4458	.0343	
4	.4801	.5144	.5544	.3086	.4458	.0343	
5	.5487	.6859	.6283	.3429	.5144	.0343	
6	.6859	.7888	.8871	.4801	.6516		
7	.6516	.7202	.8501	.5144	.6001		
8	.6173	.6859	.6838	.3772	.5487		
9	.5144	.6173		.3772	.6001		
10	.5487	.6173	.6859	.3772	.6661		
11	.4801	.6838	.7545	.4458			.1029
12		.6838	.6516	.4801			.1029
13	.5144	.6653	.6859	.5487			.2058
14	.5144	.6653	.6516	.4801	.6626		.1715
15	.5144	.6653	.6516	.5144	.8059	.0343	.9259
16	.5487	.7392		.6859	.8059		.9602
17	.6173	.7682			.7522	.1372	.8916
18	.6859	.7392					.9259
19	.7888	.9214	.5487				1.0288
20	1.0288	1.086	.5144				1.166
21	.9259	.8688	.4801	.6173			
22	.7888		.4458	.6344			
23	.6859	.6878	.3772	.5487			.823
24	.5144	.6001		.2743	.4801	.0686	
Max	1.0288	1.086	.8871	.6859	.8059	.1372	1.166
Min	.4458	.5144	.3772	.2743	.4458	.0343	.1029
Avg	.6098	.6948	.6184	.4415	.5914	.0536	.6640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 204 / 11KV AAINI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1715		.0343	.0514	.0686	
2	.1372	.1715	.1829	.0343	.0514	.0686	
3	.1372	.1715	.1848	.0343	.0343	.0686	
4	.1372	.1715	.1848	.0343	.0343	.0686	
5	.1715	.1886	.1848	.0343	.0343		
6	.2058	.2229	.2587	.0343	.0514		
7	.2058	.2743	.2561	.0686	.0686		
8	.2058	.2401	.1991	.0686	.0686		
9	.2058	.2401			.1029		
10	.2058	.2743	.2229	.0686			
11	.1372	.2772	.2058		.1433		
12	.1715	.2561	.1715		.1075		
13	.1372	.2218	.2058			.1372	
14	.1372	.1848	.1715		.1433	.1715	
15	.1372	.2218	.1372		.1267		
16	.1715	.3326			.1075		
17	.2401	.2926			.1433	.2058	.2401
18	.2401	.2587				.2401	.2743
19	.2743	.2865		.0686			.3772
20	.3429	.3258		.0686			.3772
21	.3086	.3326	.0343	.0514			
22	.2572		.0686	.0514			
23	.2058	.2218	.0686	.0514			.2401
24	.1715	.1715		.0343	.0514	.0857	
Max	.3429	.3326	.2587	.0686	.1433	.2401	.3772
Min	.1372	.1715	.0343	.0343	.0343	.0686	.2401
Avg	.1951	.2396	.1711	.0492	.0825	.1239	.3018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 201 / 11 KV KALAMMAVADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3174	.3292	.3292	.2241	.2561	
2	.3292	.3174	.3109	.3292	.2241	.2561	
3	.3292	.3174	.3475	.3292	.2241	.2561	
4	.3292	.3174	.2926	.3292	.2241	.2561	
5	.3109	.3174	.3292	.3292	.2241	.2614	
6	.4024	.3734	.3658	.4024			
7	.3841	.3921	.4024	.4024	.2614		
8	.3658	.3361	.3841	.3841	.2987		
9	.4066	.3292	.4207		.2241		
10	.3511	.3292	.3841	.4108			
11		.3475	.4207	.3734			
12	.3326	.3658	.439	.3734	.4251		.4572
13	.3326	.3475	.4207	.3174	.3696	.439	.439
14	.3326	.3475	.4024	.3174	.3511	.4938	.4207
15	.3511	.3658	.4024	.4108	.3881	.4755	.439
16	.3326	.3475		.4108	.4108	.4207	.4024
17	.3696	.4024			.3734	.439	.3658
18	.3547	.439	.2926			.3658	.4024
19	.4854	.4755	.5487		.4481	.439	.5121
20	.5601	.5487	.5853				.5304
21	.5041	.5304	.5601			.439	.4938
22	.4668	.4572	.4755		.1307		.4572
23	.4108	.4024	.4024		.3174		.4024
24	.3475	.3475		.3475	.2427	.2801	
Max	.5601	.5487	.5853	.4108	.4481	.4938	.5304
Min	.3109	.3174	.2926	.3174	.1307	.2561	.3658
Avg	.3791	.3780	.4055	.3623	.2979	.3627	.4435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 202 / 11 KV Kudutri Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.112	.1307	.112			
2	.0747	.112	.1307	.112			
3	.0747	.0934	.112	.112			
4	.0747	.0934	.112	.112			
5	.0934	.112	.112	.112			
6	.1494	.168	.1494	.1867			
7	.168	.1867	.168	.1867			
8	.1307	.57	.1494	.1867			
9	.1478	.1867	.1494				
10	.1478	.1867		.1867			
11		.168	.1307	.2241	.1478		
12	.1478	.1307	.168	.168	.2218		.168
13	.0924	.1097	.168	.1494	.2218		.1646
14	.1109	.1097	.1463	.1307	.1848		.168
15	.0924	.128	2.6886	.1867	.1109	.056	.168
16	.1478	.128		.1494	.168	.2241	.1867
17	.1663	.1646			.1867	.2987	.2427
18	.1867	.2012			.2614	.2427	.2427
19	.2054	.2378	.1867		.2801	.2614	.2614
20	.2614	.2561	.3361				.2801
21	.2427	.2378	.2614				.2614
22	.2054	.2241	.2427				.2054
23	.1494	.1463	.1307				.1494
24	.0934	.1307		.112			
Max	.2614	.57	2.6886	.2241	.2801	.2987	.2801
Min	.0747	.0934	.112	.112	.1109	.056	.1494
Avg	.1416	.1747	.2986	.1517	.1981	.2166	.2082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 203 / Fejiwade Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.6908	
2		.6908	
3		.6104	.6371
4		.6104	.6036
5		.6104	
6		.6274	
7		.5935	.7209
8			.7042
23	.6952	.6874	
Max	.6952	.6908	.7209
Min	.6952	.5935	.6036
Avg	.6952	.6401	.6665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 204 / 11 KV Piral Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8564			
2	1.7764			
3	1.7284			
4	1.6964			
5	1.6804			
6	1.8564			
7	2.0645			
8	2.3365			
9	2.6235	2.3868	2.9127	
10	2.8016	2.3868	3.0087	1.9204
11		2.1879	2.8327	2.0005
12	2.6355	2.0553	2.8327	1.9044
13	2.6379		2.8327	1.8084
14	2.6379		2.7206	1.8404
15	2.7681		2.3045	1.6004
16	2.6543	1.9393		1.4403
17		2.0885		
18		2.0719		
24	2.0165			
Max	2.8016	2.3868	3.0087	2.0005
Min	1.6804	1.9393	2.3045	1.4403
Avg	2.2357	2.1595	2.7778	1.7878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 146004 / 110KV/33KV/11KV RHE

Feeder No / Name : 601 / R.M.MOHITE HYDRO GN.

Feeder KV- 100 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	6.2352
Max	6.2352
Min	6.2352
Avg	6.2352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 148019 / 220/110/33 KV BIDRI

Feeder No / Name : 601 / DVSSK BIDRI CO-GN.

Feeder KV- 100 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	18.7056
Max	18.7056
Min	18.7056
Avg	18.7056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 201 / DEVAL CLUB

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8025	.8078	.7682	.8131	.7644	.7484
2	.7125	.7423	.7171	.7064	.6988	.6874
3	.6897	.7072	.7004	.6859	.6737	.6584
4	.6645	.6874	.6843	.6714	.6577	.644
5	.6569	.6798	.66	.6683	.6432	.6386
6	.6706	.7049	.6752	.6958	.6904	.6645
7	.6455	.6699	.6676	.6904	.6714	.6554
8	.66	.7087	.6866	.6897	.6828	.692
9	.7011	.7727	.7705	.759	.7186	.7369
10	.727	.8535	.8383	.849	.7964	.7537
11	.8695	1.025	1.0021	1.0463	1.025	.916
12	.9922	1.1827	1.1629	1.1271	1.249	.9983
13	1.1065	1.217	1.1789	.6805	1.2803	.9854
14	1.1027	1.1782	1.1378	1.2971	1.2628	.9755
15	1.0273	1.1126	1.1073	1.2209	1.2216	.9206
16		1.1004	1.0905	1.2529	1.0852	.9457
17		1.0776	1.0844	1.2315	1.1713	1.0433
18		.2225	1.15	1.2513	1.1759	1.0311
19		1.5371	1.2986	1.1919	1.214	1.1728
20		1.4868	1.3535	1.4266	1.3329	1.2864
21		1.342	1.2551	1.3451	1.2163	1.2513
22		1.0768	1.1507	1.1286	1.0174	1.1363
23		.964	1.0326	1.0166	.9198	1.0707
24		.8665	.9015	.9252	.823	.9694
Max	1.1065	1.5371	1.3535	1.4266	1.3329	1.2864
Min	.6455	.2225	.66	.6683	.6432	.6386
Avg	.8019	.9468	.9614	.9738	.9580	.8993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 201 / KATYAANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3102	.3285	.1448	.2683
2		.3239		.2622
3		.3262		.2622
4	.1997	.3346		.2919
5	.2027	.333		.3018
6	.2599	.3734	.2721	.3467
7	.4717	.5075	.4336	.1844
8	.5677	.5594	.6043	
9	.5708	.5235	.6424	
10	.5418	.4984	.5777	
11	.4603	.4077	.3993	
12	.3978	.2477		
13	.3841			
14	.3711	.2644		
15	.3391	.3201		
16	.3658	.3551		
17	.4641	.4755	.1707	
18	.535	.5243	.2926	
19	.4976	.4191	.2774	
20	.4115	.3879	.2766	
21	.3742	.3574	.2469	
22	.3589	.2538	.2492	
23	.3544		.2812	
24	.3483	.1981	.2721	
Max	.5708	.5594	.6424	.3467
Min	.1997	.1981	.1448	.1844
Avg	.3994	.3782	.3427	.2739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 201 / 11KV I.T.Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.037	.0354	.0183	.0185	.0181	.0177
2	.0362	.037	.0354	.0181	.0185	.0181	.0177
3	.0362	.037	.0354	.0183	.0185	.0183	.0354
4	.0362	.037	.0354	.0183	.0185	.0181	.0177
5	.0362	.037	.0354	.0183	.0185	.0181	.0177
6	.0362	.037	.0354	.0181	.0185	.0181	.0177
7	.0362	.037	.0354	.0183	.0185	.0181	.0177
8	.0362	.037	.0354	.0183	.0185	.0181	.0177
9	.0362	.0543	.0532	.037	.037	.0181	.0177
10	.0354	.0724	.0569	.0532	.1456	.0362	.0185
11	.0532	.0543	.1128	.0709	.1774	.0181	.0185
12	.054	.0724		.0709	.0793	.0181	.0185
13	.054	.0724	.037	.0709	.181	.0362	.0185
14	.0532	.0905	.1838	.0709	.1797	.0181	.0185
15	.0646	.0543	.1669	.0709	.1835	.0362	.0185
16	.057	.0724	.0884	.0709	.1812	.0362	.0185
17	.0562	.0709	.0213	.0924	.1677	.0354	.0362
18	.0554	.0709	.0551	.0739	.1638	.0354	.0181
19	.0554	.0709	.0663	.0739	.0446		.0181
20	.037	.0532	.0366	.037	.0362	.0354	.0181
21	.037	.0532	.0366	.037	.0362	.0354	.0181
22	.037	.0354	.0366	.037	.0181	.0354	
23	.037	.0354	.0366	.037	.0181	.0354	.0181
24		.037	.0354	.0366	.037	.0181	.0177
Max	.0646	.0905	.1838	.0924	.1835	.0362	.0362
Min	.0354	.0354	.0213	.0181	.0181	.0181	.0177
Avg	.0440	.0527	.0568	.0453	.0764	.0258	.0196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 202 / HOCKY STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2664	.2872	.2862	.3001	.2879	.2818	.247
2	.2504	.2549	.2592	.2824	.2788	.2481	.2355
3	.2488	.2519	.2511	.2755	.2727	.2443	.2249
4	.245	.2504	.2435	.2747	.2658	.2412	.2038
5	.245	.2481	.2508	.2519	.2488	.2435	.2271
6	.2435	.2435	.2515	.2341	.2488	.2427	.2271
7	.2397	.2159	.2477	.2511	.1311	.2227	.2294
8	.2052	.2353	.2317	.2286	.2176	.2042	.2096
9	.2014	.2305	.2527	.2128	.2298	.2255	.2321
10	.218	.2544	.2283	.2256	.2191	.2143	.2199
11	.187	.2412	.2359	.2527	.2605	.2728	.2305
12	.2104	.2275	.128	.2572	.1349	.2987	.2374
13	.184	.2298	.1294	.258	.2635	.2643	.1966
14	.2096	.212	.2648	.2618	.2534	.301	.196
15	.215	.2321	.2605	.2767	.2689	.1547	.2551
16	.2344	.2359	.1341	.2687	.259	.1166	.2397
17	.2229	.2294	.1166	.2666	.259	.2748	.2313
18	.2021	.2256	.1486	.2341	.1334	.2447	.2283
19	.2277	.2397	.2255	.2422	.1158	.1326	.2237
20	.2911	.2957	.3041	.3002	.1463	.2477	.2658
21	.3101	.3148	.317	.3317	.1654	.3011	.2987
22	.3185	.3171	.3124	.3193	.1669	.2995	.1608
23	.3223	.3334	.3109	.3116	.1806	.3003	.3116
24	.3246	.3155	.3117	.3094	.2963	.301	.2908
Max	.3246	.3334	.317	.3317	.2963	.3011	.3116
Min	.184	.212	.1166	.2128	.1158	.1166	.1608
Avg	.2426	.2551	.2376	.2678	.2210	.2449	.2343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 204 / RENUKA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1594	2.1334	2.2199	3.8759	3.8355	2.1136	3.6381
2	2.0199	2.0279	2.0767	3.6109	3.5408	1.9784	3.427
3	1.9536	1.9322	1.9837	3.5104	3.4608	1.9071	3.3196
4	1.9376	1.9056	1.9403	3.4677	3.4364	1.8857	3.248
5	1.8987	1.8787	1.9594	3.4524	3.4235	1.8837	3.2587
6	1.9094	1.8481	1.9814	3.5058	3.3316	1.9182	3.341
7	1.8523	1.8566	1.8731	3.4509	3.5294	1.8237	3.28
8	1.8034	1.7877	1.832	3.3931	3.2874	1.7886	3.2869
9	1.8024	1.837	1.951	3.6534	3.6452	1.8549	3.4438
10	1.9189	1.9403	2.0208	4.2196	4.2406	1.9712	3.6818
11	1.8983	1.9102	2.0419	5.0793	5.0743	2.1068	3.8479
12	1.9067	2.0688	1.0341	5.2729	2.7686	2.1658	2.0081
13	1.8876	2.1346	2.7844	5.3567	3.0792	2.0919	3.9835
14	1.8762	2.0527	2.4221	5.2294	5.1189	2.0614	3.8631
15	.612	2.1551	2.2727	5.0968	5.2446	2.1418	3.9081
16		2.2467	1.1667	5.3018	5.1273	2.1841	3.9438
17		2.1171	.7354	5.1427	5.1218	2.1011	3.9902
18	1.3018	2.0477	2.3579	5.1662	2.5423	2.0393	4.0562
19	2.1005	2.1978	5.3148	5.2117	.3932	1.025	4.3046
20	2.4089	2.5903	5.7141	5.4702	1.3367	2.6307	5.1166
21	2.36	2.5095	5.1394	5.0528	1.3413	4.1366	4.8748
22	2.386	2.4714	4.7737	4.712	1.2551	4.6334	2.3807
23	2.4135	2.4989	4.5123	4.4559	1.2338	4.3767	4.5416
24	2.3396	2.3325	3.3387	4.2181	3.1407	3.2004	4.1823
Max	2.4135	2.5903	5.7141	5.4702	5.2446	4.6334	5.1166
Min	.612	1.7877	.7354	3.3931	.3932	1.025	2.0081
Avg	1.9430	2.1034	2.6436	4.4544	3.2712	2.3342	3.7053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 205 / SUBHASH NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9631	1.9505	2.0127	1.8848	.9055	.8871	.8764
2	1.8069	1.805	1.8831	1.7981	.8686	.8501	.8192
3	1.762	1.7798	1.7809	1.7217	.8316	.8316	.8002
4	1.7322	1.7433	1.7581	1.6912	.8316	.8316	.7621
5	1.7063	1.7212	1.7734	1.6844	.8501	.8316	.8192
6	1.6758	1.6802	1.8129	1.7042	.8686	.8501	.8002
7	1.5611	1.6937	1.8031	1.6903	.8686	.7762	.8002
8	1.7391	1.6513	1.7863	1.7286	.9055	.8779	.8192
9	1.7379	1.7935	1.8244	1.7878	.9425	.9145	.8954
10	1.6865	1.8034	1.8046	1.8411	.9335	.8775	.8686
11	1.5889	1.7589	1.8031	1.7886	.9149	.8589	.7947
12	1.5279	1.7371		1.7597		.8589	.8131
13	1.5508	1.7059	2.2562	1.7604	.8589	.8402	.8131
14	1.6202	1.7444	1.95	1.7954	.8589	.8589	.8501
15	1.765	1.8363	1.9631	1.8541	.9335	.9335	.0739
16	1.7269	1.8225	.9938	1.9174	.8962	.9335	.8871
17	1.6387	1.6354	.3696	1.6476	.8131	.743	.8589
18	1.6758	1.7048	1.9441	1.8448		.8383	.7468
19	2.1226	2.13	2.3282	2.3891			.9335
20	2.5215	2.6474	2.476	2.6396		1.3146	1.1949
21	2.4061	2.4943	1.2757	2.5217		1.0479	1.1949
22	2.2895	2.3121	2.252	2.3276		.9145	
23	2.3186	2.3267	2.2044	2.2656		.9907	1.1949
24	2.1746	2.1841	2.1285	2.0899	.9795	.961	.8954
Max	2.5215	2.6474	2.476	2.6396	.9795	1.3146	1.1949
Min	1.5279	1.6354	.3696	1.6476	.8131	.743	.0739
Avg	1.8458	1.9026	1.8341	1.9222	.8859	.8966	.8483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 207 / BHAVANI MANDAP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9899	.9358	.9869
2	.8505	.865	.9099
3	.8109	.8017	.8688
4	.7918	.7865	
5	.7865	.7834	
6	.8192	.8101	
7	.9709	.8154	
8	.7895	.8017	
9	.884	.8932	
10	.961	1.0075	
11	1.3375	1.3458	
12	1.6804	1.7574	
13	1.7833	1.9906	
14	1.8054	1.9646	
15	1.5867	1.6644	
16	1.4617	1.7459	
17	1.5828	1.6301	
18	1.6286	1.8237	
19	1.6164		
20	1.9204	1.9334	
21	1.877	1.973	
22	1.4769	1.5348	
23	1.1004	1.1637	
24	.9808	1.0509	
Max	1.9204	1.9906	.9869
Min	.7865	.7834	.8688
Avg	1.2705	1.3078	.9219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 201 / SAMBHAJI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.8954	1.874	1.7208	1.7021	1.7482	1.5321
2	.7545	.8383	1.7246	1.6671	1.5939	1.6164	1.4693
3	.7373	.8383	1.6004	1.6133	1.5478	1.5783	1.3984
4	.7202	.8383	1.5352	1.5615	1.4777	1.5562	1.3885
5	.703	.9526	1.5411	1.5272	1.4918	1.599	1.3809
6	.6859	.8573	1.6069	1.576	1.4834	1.6383	1.4312
7	.6173	.6859	1.5209	1.48	1.4239	1.4859	1.3584
8	.6001	.6859	1.4552	1.43	1.3546	1.4144	1.3657
9	.6173	.7545	1.5089	1.5184	1.4579	1.5253	1.3756
10	.6001	.8865	1.6461	1.5981	1.6324	1.6168	1.5017
11	.6602	.811	1.7528	1.6228	1.6447	1.6271	1.5482
12	.679	.7733	.8848	1.6431	.8429	1.656	1.5169
13	.6602	.7545	1.9818	1.5603	1.5783	1.6046	1.4696
14	.7167	.7922	1.954	1.5809	1.6821	1.6278	1.4876
15	1.6975	.9242	1.8815	1.7661	1.8143	1.7033	1.6145
16	1.7147	.9431	1.8876	1.8027	1.8374	1.7588	1.7207
17	1.6409	.8865	.9823	1.7273	1.8336	1.7992	1.6995
18	.724	.9431	1.9742	1.7905	1.8843	1.787	1.6266
19	.9526	1.0751	2.1361	2.0375	1.9198	.9175	1.7634
20	1.086	1.1694	2.239	2.2044	2.2506	2.0816	2.2195
21	1.086	1.1128	2.2275	2.1879	2.1696	2.1651	2.1388
22	1.086	1.094	2.1628	2.1121	2.1106	2.0641	1.1027
23	1.0669	1.0374	2.0512	1.9692	2.0199	1.9265	1.9402
24	.8059	.9907	1.9823	1.8717	1.8206	1.8498	1.853
Max	1.7147	1.1694	2.239	2.2044	2.2506	2.1651	2.2195
Min	.6001	.6859	.8848	1.43	.8429	.9175	1.1027
Avg	.8910	.8975	1.7546	1.7320	1.6906	1.6811	1.5793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 202 / JAIL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1561	1.2477	1.2464	1.2613	1.1431	1.201	1.1755
2	1.0631	1.1075	1.1393	1.1549	1.041	1.0559	1.0707
3	1.0193	1.0854	1.0752	1.069	1.028	1.0163	1.0075
4	.9884	1.0679	1.0493	1.0584	.9934	1.0086	.9446
5	.9838	1.1061	1.0543	1.0471	.9858	1.0391	.9129
6	1.0132	1.0368	1.0959	1.0739	.9919	1.0601	.9225
7	.9899	1.0037	1.0886	1.0553	.9743	.9777	.9221
8	.8768	.9623	1.0132	.9693	1.137	.9576	.9046
9	.9042	1.0031	1.0572	1.0665	1.0369	1.0109	.9457
10	.8855	1.0978	1.0983	1.0608	1.0799	1.0315	.9122
11	.9236	1.0776	1.0439	1.0166	1.0624	.9998	.8848
12	.8722	.9915	.5335	.9983	.519	.9983	.9012
13	.9116	.9526	.567	.9538	1.0082	.9701	.8931
14	.9053	1.0433	1.2048	.9693	1.0372	1.0494	.8593
15	.9284	1.0234	1.1637	1.001	1.0071	1.0547	.8863
16	.9014	.9785	1.078	.9865	1.0486	1.0585	.8908
17	.8869	.9236	.5639	.9934	1.0593	1.06	.8756
18	.8884	.913	.5815	1.0463	1.0879	1.0082	.8817
19	.961	1.0578	1.0113	1.289	1.132	.5357	.9896
20	1.3554	1.4087	1.4706	1.4712	1.3287	.6409	1.3314
21	1.4055	1.4502	1.3892	1.4361	1.3428	.9686	1.3576
22	1.4416	1.4403	1.4898	1.366	1.3794	1.3233	.7278
23	1.4329	1.4697	1.499	1.3489	1.3432	1.367	1.3469
24	1.267	1.3584	1.411	1.3226	1.2468	1.3004	1.3093
Max	1.4416	1.4697	1.499	1.4712	1.3794	1.367	1.3576
Min	.8722	.913	.5335	.9538	.519	.5357	.7278
Avg	1.0401	1.1170	1.0802	1.1256	1.0839	1.0289	.9939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 204 / KALAMBA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5061	2.6778	2.4836	2.4699	2.7835	2.7633	2.487
2	2.3308	2.4386	2.3179	2.319	2.5518	2.5682	2.3312
3	2.2565	2.3952	2.2359	2.2153	2.455	2.5415	2.2283
4	2.226	2.3754	2.1778	2.1757	2.4044	2.5057	2.1834
5	2.2271	2.4065	2.1856	2.1602	2.431	2.6413	2.1628
6	2.2641	2.3725	2.3535	2.2508	2.6551	2.7496	2.2809
7	2.4212	2.386	2.4703	2.3686	3.0282	2.9934	2.4364
8	2.3929	2.4335	2.4166	2.3038	3.2251	3.1017	2.5392
9	2.3823	2.3819	2.4204	2.3396	3.3265	3.1512	2.5183
10	2.2935	2.2481	2.3564	2.1993	3.3676	2.9722	2.5759
11	2.1811	2.181	2.3549	2.2599	3.229	2.787	2.5667
12	1.9395	2.194	1.2209	2.2698	1.6743	3.0171	2.5122
13	1.9859	2.2112	1.3717	2.2303	2.8738	2.9416	2.6269
14	2.1186	2.2159	2.5979	2.2161	2.7823	2.8678	2.6955
15	2.1704	2.2466	2.5774	2.1552	1.4137	2.8616	2.6257
16	2.2154	2.2603	2.3777	2.2138	2.5202	2.8247	2.6658
17	2.2512	2.2773	1.2727	2.2074	3.1575	2.8943	2.8227
18	2.2123	2.3695	2.2219	2.7531	3.0849	2.9801	3.0358
19	2.4562	2.8159	3.0266	3.5247	3.3154	1.6171	3.2445
20	3.1299	3.293	3.3494	3.7899	3.3209	1.422	3.8218
21	3.3356	3.4503	3.3638	3.8024	3.6	1.7741	3.9888
22	3.3089	3.3492	3.2876	3.6492	3.4515	3.5627	2.1102
23	3.1817	3.0986	3.0506	3.3619	3.3387	3.3509	3.5609
24	2.8261	2.8975	2.8215	2.9728	2.9554	3.1291	3.1375
Max	3.3356	3.4503	3.3638	3.8024	3.6	3.5627	3.9888
Min	1.9395	2.181	1.2209	2.1552	1.4137	1.422	2.1102
Avg	2.4422	2.5407	2.4297	2.5920	2.8727	2.7508	2.7149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 205 / JARAG NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1488	1.2567	2.652	2.5392	2.4242	2.4608	2.2603
2	1.0631	1.2012	2.3769	2.3762	2.3011	2.3099	2.1468
3	1.0288	1.2012	2.1938	2.2901	2.1994	2.2634	2.066
4	.9945	1.2012	2.1613	2.1765	2.1274	2.226	2.0176
5	.9945	1.2752	2.1354	2.178	2.1193	2.3052	1.9955
6	.9602	1.1458	2.1788	2.2443	2.1247	2.2314	2.0103
7	.8745	.9979	2.0949	2.095	2.0507	2.0942	1.9059
8	.8573	.961	2.0401	2.0371	1.9425	2.0355	1.9064
9	.8402	.961	1.9822	2.0211	1.9041	1.9464	1.8454
10	.7888	.8962	1.9353	1.9048	1.9227	1.9319	1.8195
11	.8596	.8596	1.841	1.8168	1.262	1.9182	1.7718
12	.8962	.9511	.9313	1.8076	.8185	1.9929	1.9379
13	.8962	.961	2.3251	1.8922	2.1833	2.0104	2.0324
14	.9511	.9694	2.4592	1.9079	2.0629	2.0797	2.0004
15	1.0242	.9877	2.2824	1.9631	2.1193	2.1064	2.0077
16	.9877	1.0242	2.114	1.975	2.0942	2.1597	2.05
17	.9694	.961	1.7924	1.9864	2.1071	2.1269	2.0961
18	.9511	.9511	.1387	2.1704	2.0699	2.1239	2.0641
19	1.3352	1.4266	3.3356	2.8498	2.4181	1.0837	2.4421
20	1.5912	1.5524	3.3935	3.2233	3.2411	2.1022	3.0757
21	1.5729	1.5546	3.2891	3.1946	3.2084	3.261	3.0879
22	1.5364	1.5181	3.1739	3.0673	3.0742	3.0727	1.6118
23	1.4815	1.4632	3.0428	2.9081	2.9729	2.9104	3.0148
24	1.2003	1.3169	2.7969	2.7725	2.633	2.6337	2.7373
Max	1.5912	1.5546	3.3935	3.2233	3.2411	3.261	3.0879
Min	.7888	.8596	.1387	1.8076	.8185	1.0837	1.6118
Avg	1.0752	1.1498	2.2778	2.3082	2.2242	2.2244	2.1627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 206 / 11KV I.T.I.FEEDER
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)
24	.0171	.0171
Max	.0171	.0171
Min	.0171	.0171
Avg	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 211 / 11KV INCOMER NO.1

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7191	2.7892	2.7831	2.6917	2.7923	4.3926	2.4844
2	2.4813	2.5118	2.5423	2.4874	2.5484	4.0695	2.2131
3	2.3777	2.4173	2.4295	2.3807	2.4417	3.8988	2.1552
4	2.2923	2.3472	2.3442	2.1887	2.3746	3.7738	2.1033
5	2.2497	2.2801	2.3045	1.7558	2.3472	3.7281	2.0637
6	2.2862	2.2923	2.3533	1.7894	2.3777	3.7525	2.0454
7	2.3655	2.332	2.4265	1.8412	2.5423	3.8287	2.1795
8	2.3442	2.2801	2.3442	1.768	2.5332	3.8592	2.1521
9	2.3106	2.271	2.332	2.4356	2.5728	4.4749	2.143
10	2.207	2.2801	2.3381	2.521	2.5972	4.1671	2.2527
11	2.0942	2.2314	2.3228	2.3899	2.4996	4.2219	2.1948
12	1.8961	2.2009	2.2923	2.3472	2.3228	4.3774	2.1978
13	1.8961	2.2222	.2103	2.3472	2.2497	4.7401	2.2283
14	1.9601	2.1856	2.8258	2.2344	2.4295	4.6609	2.1978
15	2.3198	2.2314	2.5758	2.271	2.4478	4.6487	2.2039
16	2.6002	2.332	2.5728	2.3503	1.9692	4.7645	2.3106
17	2.6337	2.335	2.5393	2.3472	2.6277	4.4292	2.3899
18	2.649	2.3106	1.4266	2.3716	2.6277	4.5237	2.463
19	2.2009	2.3716	2.3289	3.0422	2.5667	2.6581	2.4539
20	3.0971	3.2769	3.4537	3.5269	5.1029	1.8473	3.2434
21	3.28	3.4476	3.4812	3.6031	4.8316	2.1735	3.4202
22	3.283	3.3562	3.3196	3.4781	5.2096	3.1672	3.3623
23	3.2648	3.2708	3.1946	3.344	4.8773	3.091	3.2373
24	3.1672	3.1428	3.0636	3.1184	4.9108	2.8593	3.0971
Max	3.283	3.4476	3.4812	3.6031	5.2096	4.7645	3.4202
Min	1.8961	2.1856	.2103	1.7558	1.9692	1.8473	2.0454
Avg	2.4990	2.5298	2.4919	2.5263	2.9917	3.8378	2.4497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 412 / 33kv Shenda Park out going NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.858	4.2135	3.9918	4.9897	4.5782	3.9363	4.321
2	3.7551	3.9363	3.5482	4.4353	4.4753	3.6037	4.2181
3	3.6523	3.9363	3.5482	4.269	4.1667	3.6037	4.1152
4	3.4465	3.9363	3.4928	4.2135	4.0638	3.6037	4.0124
5	3.4465	4.1581	3.4374	4.3244	4.0638	3.7146	3.858
6	3.3436	3.7146	3.7146	4.4353	4.1667	3.8255	4.1152
7	3.2922	3.4374	3.6591	4.3244	4.0638	3.4374	4.0124
8	3.1893	3.3265	3.6591	4.4907	4.0124	3.4374	4.4353
9	3.1893	3.6037	3.6591	4.5462	4.2181	3.4928	4.2181
10	3.1379	3.6037	3.6591	4.4753	4.9343	3.4928	4.2696
11	3.3471	3.5482	3.6591	4.7325	2.2731	3.6037	4.3724
12	3.2373	3.4374		4.9897		3.7146	4.3724
13	3.1824	3.4374	4.4353	4.8868	5.1006	3.6037	4.3724
14	3.4019	3.4374	3.9918	5.0412	4.9897	3.6037	4.3724
15	2.6886	3.6591	3.9918	5.0926	5.4887	3.6037	4.6296
16	2.5789	3.9918		5.0412	5.3778	3.6591	4.6296
17	2.6337	3.7146	3.7146	4.784	5.3778	3.8809	4.4239
18	3.4019	3.5482	3.5482	4.0638	5.1006	4.1581	4.3724
19	4.225	4.7125	4.9897	5.9156	3.2156		5.144
20	4.8788	5.1006	6.7084	6.07	5.156	3.9363	6.07
21	4.8234	4.8788	6.2649	5.7613	4.9897	6.0985	5.8642
22	4.9897	4.9897	5.9322	5.4527	4.8234	5.7659	
23	4.8788	4.9897	5.7659	5.4012	4.7125	5.6013	5.7099
24	4.0124	4.4907	4.4353	5.2669	4.7325	4.2135	5.0412
Max	4.9897	5.1006	6.7084	6.07	5.4887	6.0985	6.07
Min	2.5789	3.3265	3.4374	4.0638	2.2731	3.4374	3.858
Avg	3.6079	3.9918	4.2639	4.8751	4.5253	3.9822	4.5630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 413 / 33KV RAMANANDNAGAR I/C
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	25.1486	25.7774	25.8917	27.4349	27.6063	22.4052	25.8917
2	22.8052	23.2625	23.6054	25.1486	25.0343	20.4047	23.2053
3	21.6621	21.9479	22.4052	23.8341	23.9484	19.3759	22.348
4	20.7476	21.3763	21.3192	19.7188	23.2625	18.7472	21.605
5	20.2904	20.6333	21.0334	19.4902	22.9196	18.4042	21.2049
6	20.519	20.8048	21.3763	19.9474	23.2625	18.5185	21.3763
7	20.9763	21.1477	21.7764	20.4618	23.9484	18.9758	22.6909
8	20.4047	20.4047	21.2049	20.1189	23.6626	18.5757	22.6338
9	20.1761	20.4618	21.2049	23.434	24.2913	20.2904	22.6338
10	20.0046	20.6905	21.2049	24.5771	25.1486	19.6045	23.7197
11	19.2616	20.519	21.262	24.8629	25.0343	19.9474	23.434
12	18.1185	20.1761	21.2049	25.6059	25.7774	20.4047	23.8341
13	18.1185	20.1189	13.0316	25.7202	25.6059	22.1765	24.177
14	18.5185	19.8903	26.6919	25.0343	25.9488	21.7193	23.5483
15	19.1473	20.1761	23.434	25.0915	25.7774	21.3763	23.7197
16	19.8903	21.6621	23.3768	26.0631	23.8341	21.8336	24.5199
17	19.9474	22.1765	22.4052	25.8917	27.1491	20.519	24.8057
18	19.8903	21.605	12.0599	25.3201	27.2063	19.4902	25.1486
19	20.0046	21.4907	20.6905	27.1491	22.6909	24.6342	24.9772
20	27.6063	29.3782	***	***	21.6621	15.6607	***
21	28.8638	***	***	***	25.6059	21.0906	***
22	28.8638	***	***	***	26.006	***	***
23	29.1496	29.4925	***	***	24.8629	***	***
24	28.6352	28.7495	***	***	24.4628	28.7495	***
Max	29.1496	30.9214	34.6365	36.0083	27.6063	31.493	34.5222
Min	18.1185	19.8903	12.0599	19.4902	21.6621	15.6607	21.2049
Avg	22.0313	23.0363	23.6054	25.9750	24.7795	21.4645	25.4773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 208 / RAJARAMPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.7167	.7356	.6173	.7167	.6516	.679
2	.6173	.6979	.6979	.6173	.679	.6516	.6413
3	.6173	.6979	.679	.6001	.679	.6173	.5658
4	.6001	.6979	.6602	.6001	.6602	.6344	.5658
5	.583	.7356	.6602	.6173	.6602	.6344	.5658
6	.583	.7167	.6602	.5487	.6979	.6001	.6413
7	.6001	.7167	.679	.6001	.7167	.6516	.6413
8	.583	.7167	.7167	.6344	.7167	.6173	.679
9	.7356	.7356	.7545	.7545	.8676	.7545	.679
10	.7545	.7716	.9242	.8589	.8775	.9242	.6979
11	1.0751	1.2003	1.3769	1.4377	1.4003	1.3392	1.1128
12	1.3014	1.3375	1.4523	1.5497	1.4937	1.5466	1.3957
13	1.2136	1.2517	1.5466	1.4937	1.5123	1.6221	1.3769
14	1.2883	1.3032	1.4712	1.4937	.9522	1.5466	1.3014
15	1.226	1.3203	1.5089	1.475	1.5497	1.4335	1.2071
16	1.2637	1.5278	1.3957	1.5123	1.4937	1.4415	1.2637
17	1.2637	1.4937	1.166	1.5466	1.4918	1.5339	1.2346
18	1.3769	1.4937	1.3375	1.5844	.8402	1.5684	1.2689
19	1.6409	1.7924	1.4918	1.7541	1.4746		1.4403
20	1.7164	1.7737	1.406	1.773	1.5261	1.6263	1.5604
21	1.5466	1.4563	1.1317	1.4523	1.3032	1.3306	1.3717
22	.9997	.9896	.8573	1.0185	.8745	.9335	
23	.8865	.8962	.7888	.9242	.7888	.7468	.8402
24	.6859	.811	.811	.703	.7922	.6859	.6602
Max	1.7164	1.7924	1.5466	1.773	1.5497	1.6263	1.5604
Min	.583	.6979	.6602	.5487	.6602	.6001	.5658
Avg	.9907	1.0771	1.0379	1.0903	1.0319	1.0475	.9735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 209 / 11 KV VARDHAMAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.415	.415	.3429	.3772	.3429	.3772
2	.3086	.415	.3772	.3429	.3395	.3429	.3584
3	.3086	.415	.3772	.3086	.3584	.3258	.3395
4	.3258	.415	.3772	.3258	.3584	.3258	.3395
5	.3258	.3772	.3772	.3258	.3584	.3601	.3584
6	.3086	.3961	.3772	.3086	.3772	.3429	.3584
7	.3086	.3772	.415	.3429	.3772	.3086	.3772
8	.2915	.3772	.3961	.3601	.3772	.3258	.3772
9	.3584	.3429	.3772	.3772	.415	.3772	.3584
10	.3584	.3601	.4527	.4481	.4854	.4527	.3772
11	.4527	.4115	.6036	.5788	.5601	.6036	.3772
12	.5093	.5144	.7356	.6348	.6722	.6036	.4527
13	.5228	.4801	.679	.6161	.6535	.7356	.6036
14	.4854	.4801	.6036	.5975	.6161	.6036	.4527
15	.4904	.4801	.6036	.5788	.5601	.6036	.4527
16	.4527	.5281	.6036	.5601	.5788	.5914	.4527
17	.5281	.5228			.6173	.6099	.4287
18	.5281	.6161	.2401	.679	.583	.5975	.463
19	.6036	.7095	.6516	.679	.5487		.5487
20	.6036	.7095	.6859	.679	.6173	.6653	.6173
21	.6036	.6161	.5144	.679	.5658	.5544	.5144
22	.5281	.5228	.4115	.5281	.4801	.4668	
23	.4527	.4854	.4115	.4715	.4115	.4481	.4115
24	.3429	.4527	.4338	.3429	.4527	.3429	.415
Max	.6036	.7095	.7356	.679	.6722	.7356	.6173
Min	.2915	.3429	.2401	.3086	.3395	.3086	.3395
Avg	.4309	.4758	.4835	.4829	.4892	.4753	.4266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 210 / 11 KV SHAHUPURI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5059	1.5779	1.6129	1.4521	1.5489	1.5295	1.4409
2	1.3748	1.3799	1.4305	1.3607	1.4101	1.411	1.2738
3	1.2529	1.261	1.2857	1.2151	1.311	1.3492	1.1734
4	1.2319	1.2526	1.2302	1.1873	1.2504	1.3169	1.1582
5	1.211	1.2571	1.221	1.1656	1.229	1.2849	1.1663
6	1.2087	1.2224	1.2226	1.1591	1.2012	1.2696	1.3203
7	1.2006	1.2331	1.2801	1.1481	1.2035	1.2372	1.2293
8	1.1785	1.3735	1.3609	1.2155	1.3857	1.305	1.2889
9	1.4809	1.8731	1.6421	1.5954	1.7132	1.5253	1.3816
10	1.7559	2.3792	2.5413	2.29	2.5012	2.2904	1.5911
11	2.2519	3.2373	3.3251	3.1702	3.4343	3.0664	1.9416
12	2.5785	3.5905	3.7677	3.6012	3.7902	3.6254	2.2569
13	2.593	3.6309	3.9269	3.7643	3.9587	3.7669	2.3901
14	2.5438	3.6477	3.7593	3.7101	3.8359	3.6326	2.4499
15	2.4356	3.5669	3.7751	3.7197	3.7829	3.5705	2.4379
16	2.4333	3.6748	3.9303	3.7693	3.7213	3.5655	2.4722
17	2.4659	3.7457	3.0377	3.7635	3.6378	3.5911	2.3053
18	2.4514	3.5323	2.9984	3.6691	3.4748	3.4206	2.2234
19	2.5846	3.4248	2.9756	3.3834	3.2545	1.6766	2.2736
20	2.7064	3.2053	2.7545	3.0375	2.9249	2.0594	2.5766
21	2.4911	2.7126	2.3735	2.6584	2.5873	2.5	2.4051
22	2.1605	2.1452	1.9852	2.154	2.0972	2.0477	1.2422
23	1.9187	1.9468	1.7611	1.8902	1.8103	1.765	1.9368
24	1.6236	1.8473	1.7699	1.619	1.7288	1.6366	1.7366
Max	2.7064	3.7457	3.9303	3.7693	3.9587	3.7669	2.5766
Min	1.1785	1.2224	1.221	1.1481	1.2012	1.2372	1.1582
Avg	1.9433	2.4466	2.3737	2.4041	2.4497	2.2685	1.8197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 211 / Takala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	1.0562	1.094	.7888	1.0185	.8573	.9619
2	.823	1.0374	1.0185	.7716	.9808	.8745	.9054
3	.7888	1.0185	.9808	.823	.9808	.7888	.8299
4	.7716	1.0185	.9431	.7888	.9431	.7888	.8299
5	.7716	.9619	.9242	.7888	.9431	.7716	.8299
6	.7716	.9619	.9997	.7716	.9242	.7716	.8865
7	.7373	.9242	.9997	.823	.9242	.7888	.8676
8	.7373	.9808	.9242	.7716	.9242	.7716	.8488
9	.8488	.7922	.9431	.8865	.9242	.8865	.9054
10	.9242	.8059	.9242	.9522	.8962	.9242	.8676
11	.9431	.7202	.9808	.9709	.9335	.9054	.8676
12	.5281	.8059	.9997	.8589	.9522	.9808	.8299
13	.9149	.8059	.9997	.8962	.9522	.9997	.9054
14	.9522	.7888	.9808	.9522	.9522	1.0374	.9619
15	.9808	.8745	1.0185	1.0082	.9896	1.4335	1.0185
16	.9808	.9431	1.0751	.9896	1.0082	1.0534	1.0185
17	1.0185	.9997	.823	1.0185	.9259	1.0349	.8745
18	.9431	1.0082	.823	.9619	.8402	1.0269	.7716
19	1.0185	1.1203	.9602	1.1317	.9088		.8916
20	1.226	1.2696	1.0631	1.2637	1.0802	1.1088	1.1145
21	1.2449	1.2323	.9774	1.226	1.0288	1.1273	1.0288
22	1.2449	1.2136	.9774	1.1883	1.0288	1.1016	
23	1.2449	1.251	.9602	1.2449	.9774	1.0456	1.0288
24	.9259	1.1694	1.1883	.8573	1.094	.9088	.9619
Max	1.2449	1.2696	1.1883	1.2637	1.094	1.4335	1.1145
Min	.5281	.7202	.823	.7716	.8402	.7716	.7716
Avg	.9256	.99	.9824	.9473	.9638	.9560	.9133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 212 / MAULI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6602	.679	.6344	.6413	.583	.6036
2	.583	.6224	.6224	.6001	.6413	.6001	.5847
3	.6173	.6224	.6036	.6173	.6413	.6173	.5658
4	.6001	.6036	.6036	.6173	.6413	.5658	.5658
5	.6001	.6224	.6036	.6001	.6224	.6001	.5658
6	.583	.6413	.6413	.5658	.6224	.583	.5658
7	.583	.6413	.6036	.6173	.6224	.583	.5281
8	.5487	.6413	.6036	.583	.6224	.5487	.5658
9	.5658	.6602	.5847	.6413	.5847	.6413	.547
10	.5847	.6001	.679	.5601	.6348	.6224	.6036
11	.5847	.6173	.7356	.6535	.6722	.7733	.6979
12	.6413	.6859	.8299	.7095	.7282	.811	.6979
13	.6535	.7716	.811	.7282	.6908	.811	.7356
14	.7095	.703	.7733	.7282	.7468	.811	.7545
15	.6584	.703	.7545	.5975	.6908	.7922	.7356
16	.6413	.7545	.8299	.5975	.7095	.7762	.811
17	.6979	.7468		.7167	.7545	.7762	.703
18	.7356	.8029	.9602	.9619	.7545	.8029	.7202
19	.8865	1.0082	.9602	1.0562	.7888		.9431
20	1.094	1.0642	.9602	1.1506	.9774	.961	1.0288
21	.9997	.9709	.8745	1.0185	.8916	.924	.9602
22	.9054	.8589	.7888	.8865	.8059	.8029	
23	.8299	.8029	.7202	.811	.7373	.7282	.8059
24	.6687	.7167	.7356	.6859	.6979	.6344	.6413
Max	1.094	1.0642	.9602	1.1506	.9774	.961	1.0288
Min	.5487	.6001	.5847	.5601	.5847	.5487	.5281
Avg	.6905	.7301	.7373	.7224	.7050	.7108	.6927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 213 / Panjarpol

Feeder KV- 11 / OUTGOING

**SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0754	.0754	.0686	.0754	.0686	.0754
2	.0686	.0566	.0754	.0686	.0754	.0686	.0754
3	.0686	.0566	.0754	.0686	.0754	.0686	.0754
4	.0686	.0566	.0754	.0686	.0566	.0686	.0754
5	.0686	.0566	.0754	.0686	.0566	.0686	.0754
6	.0686	.0566	.0566	.0686	.0754	.0857	.0754
7	.0686	.0566	.0754	.0857	.0943	.0857	.0754
8	.0686	.0566	.0754	.0857	.0943	.0857	.0754
9	.0754	.132	.1132	.1132	.1132	.132	.1132
10	.0754	.1715	.1698	.1867	.1867	.1698	.1698
11	.0566	.12	.2075	.2054	.2427	.2075	.2075
12	.0566	.2058	.1886	.1867	.2987	.2263	.2075
13	.0747	.1543	.2075	.2241	.2801	.2263	.2075
14	.0747	.12	.132	.1494	.168	.1698	.1132
15	.0754	.2401	.2263	.1867	.1867	.1886	.1509
16	.0754	.1886	.2075	.2054	.2241	.1848	.1698
17	.0566	.2241			.2058	.2218	.2058
18	.0754	.1867	.1886	.1698	.1886	.168	.1372
19	.0943	.1867	.1543	.1886	.1715		.9431
20	.0943	.1494	.1029	.1132	.1029	.1478	.12
21	.0754	.0934	.0857	.0943	.0686	.0924	.0857
22	.0754	.0747	.0857	.0943	.0686	.0934	
23	.0754	.0747	.0686	.0754	.0686	.0747	.0686
24	.0686	.0754	.0754	.0686	.0754	.0686	.0754
Max	.0943	.2401	.2263	.2241	.2987	.2263	.9431
Min	.0566	.0566	.0566	.0686	.0566	.0686	.0686
Avg	.0720	.1195	.1217	.1237	.1356	.1292	.1556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 221 / 11 INCOMER NO.I

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5836	1.6537	1.6796	1.5379	1.6126	1.5714	1.5455
2	1.4114	1.4297	1.4876	1.3763	1.3733	1.355	1.3321
3	1.291	1.3336	1.3443	1.2772	1.2833	1.2925	1.2407
4	1.2681	1.294	1.2971	1.2498	1.2574	1.2544	1.2148
5	1.2468	1.2711	1.2772	1.2178	1.2376	1.2437	1.1995
6	1.2666	1.2894	1.3093	1.2361	1.2833	1.3032	1.2376
7	1.2483	1.2849	1.3032	1.2148	1.2635	1.3062	1.2452
8	1.2422	1.3154	1.3443	1.2574	1.3321	1.3138	1.2986
9	1.358	1.672	1.5653	1.5165	1.5714	1.4342	1.4083
10	1.6065	2.143	2.0271	1.9768	2.0241	1.8717	1.5348
11	1.925	2.8075	2.6322	2.5972	2.742	2.4996	1.8534
12	2.2085	3.0803	3.03	2.9569	3.0285	3.0239	2.1171
13	2.3868	3.1321	3.1169	3.0636	2.8746	3.1062	2.1704
14	2.3807	3.1382	3.0925	3.0407	3.2449	3.123	2.1628
15	2.268	3.0255	2.9965	2.9249	3.0758	2.9767	2.1613
16	2.1308	3.0209	2.995	2.9919	3.094	2.8776	2.1521
17	2.1353	2.998	2.9843	2.9797	3.152	2.9371	2.1963
18	2.1475	2.9462	1.6141	2.9157	3.0849	2.9386	2.1872
19	2.3533	2.8258	3.0224	2.9813	2.9081	2.745	2.2603
20	2.6414	3.0986	3.0148	2.9477	2.963	2.8121	2.6033
21	2.5758	2.8365	2.7084	2.6566	2.7953	2.6017	2.5575
22	2.2177	2.3365	2.1826	2.3122	2.2847	2.1475	2.274
23	1.9845	2.021	1.8961	1.9982	1.9875	1.8458	2.1033
24	1.8122	1.8991	1.7406	1.8	1.8442	1.7132	1.9128
Max	2.6414	3.1382	3.1169	3.0636	3.2449	3.123	2.6033
Min	1.2422	1.2711	1.2772	1.2148	1.2376	1.2437	1.1995
Avg	1.8621	2.2439	2.1526	2.1678	2.2216	2.1373	1.8320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 411 / 33 KV MIDC FEEDER

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.0377	14.9194	15.4442	14.2489	15.4921	15.0377	15.1972
2	14.8491	14.681	14.6365	14.0261	15.2538	14.8835	14.8457
3	14.832	14.6245	14.4547	14.0946	15.2538	14.9177	14.6193
4	14.9863	14.5679	14.6725	15.8779	15.1406	14.7806	14.4822
5	14.4548	14.5679	14.2044	14.0946	15.0154	14.6091	14.6073
6	14.609	14.4428	14.249	13.8718	14.8097	14.4891	14.7205
7	14.1461	14.5233	14.3056	13.8032	14.7977	14.4376	14.4462
8	14.2147	14.8868	14.7051	13.9918	14.9554	14.249	14.7531
9	14.9795	16.929	15.331	14.988	16.3238	25.2195	27.3611
10	15.2744	***	16.4746	***	***	***	***
11	16.3975	***	17.5944	***	***	***	***
12	16.3614	***	18.4791	***	***	***	***
13	16.6873	***	18.5802	***	***	***	***
14	16.8804	***	17.9458	***	***	***	***
15	16.4627	***	17.7606	***	***	***	***
16	16.3941	***	17.8858	***	***	***	***
17	16.4387	***	13.8546	***	***	***	***
18	16.8022	***	16.8724	***	***	***	***
19	17.6269	21.9834	17.3526	22.1554	22.5309	***	***
20	17.987	20.2561	16.9754	19.081	19.2559	***	***
21	17.6955	17.6955	16.1008	17.8326	17.5411	29.1993	29.664
22	16.5398	16.0951	15.3292	16.8022	16.0837	19.3382	11.797
23	16.0185	15.815	15.072	16.4866	15.6036	16.6519	15.5007
24	14.7291	15.4973	15.1577	15.3121	16.1386	14.832	15.0806
Max	17.987	55.4699	18.5802	48.5237	74.4	91.2381	89.1377
Min	14.1461	14.4428	13.8546	13.8032	14.7977	14.249	11.797
Avg	15.8502	27.9335	15.9766	26.6378	31.2267	44.3533	43.8795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 206 / HSC BOARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3064	.3185	.317	.3201	.3193	.3132
2	.2896	.2972	.3018	.2987	.2995	.2911
3	.2728	.2835	.2789	.2919	.2926	.2667
4	.2622	.2843	.2743	.2843	.2881	.2568
5	.2652	.2705	.2865	.282	.2759	.2637
6	.2835	.2789	.301	.3003	.2865	.2759
7	.2766	.2675	.2964	.2797	.2926	.2766
8	.2721	.2683	.298	.282	.2705	.2644
9	.2568	.2728	.2934	.3025	.2751	.2751
10	.2553	.2774	.2957	.2919	.2766	.2766
11	.25	.2865	.2888	.2705	.2705	.2606
12	.2408		.3003	.2896	.2904	.2751
13	.2553	.3986	.2904	.2858	.282	.2904
14	.2538	.3521	.2835	.2698	.2797	.2774
15	.2583	.3178	.2926	.2743	.2896	.2964
16	.2599	.3132	.3018	.2926	.3033	.2934
17	.2705	.1196	.2873	.2926	.2865	.2804
18	.2675	.3246	.2713	.2843	.2789	.2736
19	.2964	.362	.3506	.2789	.2949	.3132
20	.3475	.4009	.3688	.362		.3658
21	.3589	.3978	.3742	.3612	.1547	.3711
22	.3765	.3955	.3841	.3742	.4496	.381
23	.3902	.3925	.3986	.3871	.426	.3765
24	.3658	.3757	.3688	.3643	.362	.3719
Max	.3902	.4009	.3986	.3871	.4496	.381
Min	.2408	.1196	.2713	.2698	.1547	.2568
Avg	.2888	.3155	.3127	.3050	.2976	.2995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 207 / RAJENDRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6493	.6676	.6584	.6371	.6455	.628	.6135
2	.6081	.6264	.6249	.5937	.6074	.5822	.5677
3	.5921	.5845	.5921	.5708	.5777	.567	.5464
4	.5685	.5723	.567	.5502	.5586	.5571	.5243
5	.5586	.5624	.5609	.5342	.5525	.5426	
6	.554	.5617	.5746	.5517	.5708	.5601	
7	.455	.4679	.5045	.5601	.5342	.5258	
8	.4344	.4763	.4862	.4778	.4595	.4588	
9	.4313	.4367	.439	.4321	.4572	.41	
10	.4016	.423	.413	.4169	.423	.4199	
11		.4222	.4359	.4009	.4108	.3978	
12		.4237		.4214	.439	.4184	
13		.4336	.5609	.426	.4504	.4207	
14		.4374	.503	.4367	.4504	.4321	
15		.474	.5274	.4496	.474	.4397	
16		.4877	.5114	.4641	.4816	.4717	
17		.4633	.2119	.4786	.4893	.4717	
18		.4618	.5548	.4923	.4725	.4649	
19		.5586	.6546	.6241	.5418	.4877	
20		.7804	.74	.7529	.7346		
21		.7567	.74	.7682	.724	.1654	
22		.7888	.7598	.8002	.7407	.7819	
23		.8131	.7476	.7819	.7461	.7446	
24		.7598	.7034	.7293	.7118	.6935	
Max	.6493	.8131	.7598	.8002	.7461	.7819	.6135
Min	.4016	.4222	.2119	.4009	.4108	.1654	.5243
Avg	.5253	.5600	.5683	.5563	.5522	.5062	.5630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 201 / 11 KV INDUSTRIAL FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.8764	.724	.6097	.724	.6478
2	.6097	.5716	.8764	.724	.6097	.724	.6859
3	.6097	.5716	.8764	.724	.6478	.724	.6859
4	.6097	.5716	.8764	.6859	.6859	.724	.6859
5	.6097	.5335	.8764	.7621	.724	.724	.6859
6	.5716	.5335	.8764	.724	.7621	.724	.6859
7	.6097	.5716	.8383	.7621	.7621	.724	.6859
8	.5335	.5335	.8002	.724	.7621	.6859	.6478
9	.5335	.5335	.5716	.5335	.6097	.6097	.5716
10	.5335	.8002	.7621	.8002	.8002	.8002	.6859
11	.5716	.8383	.8383	.8002	.9145	.9526	.9145
12	.5716	.8002	.8002	.8002	.8002	.8383	.6859
13	.5716	.8002	.8383	.7621	.7621	.7621	.7621
14	.5335	.8002	.8002	.7621	.7621	.724	.7621
15	.5716	.9145	.8002	.7621	.8383	.8383	.8764
16	.5716	.8383	.8764	.8002	.9145	.8002	.8383
17	.5716	.8383		.8002	.7621	.7621	.6859
18	.5716	.6859	.6478	.6478	.6859	.6859	.6859
19	.5335	.7621	.6097	.6097	.6478		.6859
20	.5335	.8002	.6478	.5716	.6478	.5716	.724
21	.5716	.8383	.6097	.5716	.5335	.6478	
22	.5335	.8764	.6859	.724	.6859	.6859	.7621
23	.5335	.8383	.6859	.6097	.6097	.6478	.7621
24	.5335	.5335	.8383	.6859	.5716	.6859	.6478
Max	.6097	.9145	.8764	.8002	.9145	.9526	.9145
Min	.5335	.5335	.5716	.5335	.5335	.5716	.5716
Avg	.5653	.7065	.7787	.7113	.7129	.7290	.7157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 202 / 11 KV SAMARAT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7223	1.8041	1.8	1.6903	1.7989	1.7246	1.5547
2	1.6064	1.6645	1.6819	1.6156	1.6851	1.589	1.4518
3	1.4869	1.5615	1.5965	1.5249	1.6178	1.5196	1.371
4	1.4083	1.4921	1.4533	1.4792	1.5413	1.4442	1.3405
5	1.3702	1.4334	1.4495	1.4632	1.4967	1.4274	1.3611
6	1.3816	1.4174	1.5184	1.5661	1.5006	1.4746	1.4266
7	1.4373	1.3687	1.5432	1.5554	1.5043	1.4404	1.4015
8	1.419	1.4106	1.4159	1.5425	1.448	1.4541	1.448
9	1.3718	1.3741	1.3755	1.4518	1.4304	1.3969	1.4358
10	1.3001	1.3611	1.3487	1.3328	1.3641	1.3794	1.3108
11	1.2224	1.2445	1.3449	1.3864	1.4068	1.4304	1.3047
12	1.2354	1.2529	1.4305	1.4371	1.4022	1.4693	1.3489
13	1.0761	1.2735	1.5333	1.4102	1.403	1.5348	1.3314
14	1.1995	1.4205	1.4001	1.3959	1.4107	1.5356	1.3649
15	1.4	1.5348	1.5029	1.4417	1.4293	1.579	1.419
16	1.4213	1.5699	1.5135	1.4526	1.469	1.5798	1.435
17	1.3238	1.4033	.7636	1.4183	1.4792	1.5851	1.3801
18	1.2917	1.4476	1.6796	1.5387	1.4152	1.5478	1.3939
19	1.467	1.592	1.6995	1.8145	1.4807	.7674	1.563
20	1.7825	1.8991	1.7543	1.9753	1.8199	1.9464	1.9342
21	1.7962	1.8823	1.7452	1.8892	1.8366	1.8534	1.0113
22	1.9471	1.89	1.8602	1.8884	1.9204	1.7665	1.9639
23	2.0051	2.0446	1.9113	1.9342	1.9563	1.7901	2.0515
24	1.8762	1.9601	3.5021	1.8679	1.9029	1.7962	1.8366
Max	2.0051	2.0446	3.5021	1.9753	1.9563	1.9464	2.0515
Min	1.0761	1.2445	.7636	1.3328	1.3641	.7674	1.0113
Avg	1.4812	1.5543	1.6177	1.5863	1.5716	1.543	1.4767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 203 / 11 KV HUTATMA PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8383	.8383	.8383	.8383	.8383	.8383
2	.8383	.8002	.8383	.8383	.8002	.8764	.8383
3	.8383	.8002	.8383	.8764	.8002	.8764	.8383
4	.8383	.7621	.8383	.8764	.8383	.8764	.8002
5	.8383	.8002	.8383	.8764	.8383	.8764	.8002
6	.8383	.8383	.8383	.8764	.8764	.8764	.8383
7	.8764	.8002	.8383	.8383	.8383	.8383	.7621
8	.8764	.8002	.8383	.8383	.8002	.8383	.8002
9	.8764	.8383	.8383	.9145	.9526	.7621	.9145
10	.8383	.9907	1.105	1.1431	1.105	1.0669	1.0669
11	.6097	1.2193	1.4861	1.4098	1.2574	1.3717	1.2193
12	.8002	1.2574	1.6004	1.4098	1.2193		1.2193
13	.8383	1.3717	1.4098	1.3336	1.4098	1.448	1.1431
14	.8764	1.3336	1.2955	1.3717	1.3336	1.3336	1.2193
15	.8764	1.3717	1.448	1.448	1.4861	1.4861	1.2193
16	.8764	1.2955	1.5623	1.4098	1.448	1.448	1.3336
17	.8002	1.3336		1.4098	1.3717	1.3717	1.2574
18	.8383	1.1431	1.3336	1.2955	1.2574	1.2955	.9907
19	.8002	1.105	1.1812	1.0288	1.1431	.9145	.9907
20	.8383	.9526	.9526	.9145	.9145	.8383	.9907
21	.8383	.8764	.9145	.8383	.8383	.8002	
22	.8383	.9145	.9145	.9145	.8002	.8002	.9145
23	.8383	.9145	.8764	.8764	.8764	.8383	.8764
24	.8383	.8383	.8383	.8383	.8764	.8764	.8383
Max	.8764	1.3717	1.6004	1.448	1.4861	1.4861	1.3336
Min	.6097	.7621	.8383	.8383	.8002	.7621	.7621
Avg	.8335	1.0082	1.0636	1.0590	1.0383	1.0238	.9874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 205 / RADHA KRISHNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	1.134		1.105	1.0962	1.0562	1.0288
2	.9335	1.0962	1.0456	1.0669	1.0584	1.0185	.9526
3	.9335	1.0584	1.0082	1.0288	1.0195	.9808	.9145
4	.9335	1.0195	.9709	.9907	.9818	.9145	.8764
5	.9431	.9818	.9709	.9907	.9808	.9145	.9145
6	.9709	.9808	1.0456	.9907	1.0185	.9526	.9145
7	.8962	.9808	.9335	1.0288	.9431	.9526	.9145
8	.8962	1.0562	.9709	1.0288	1.0456	1.0082	.8764
9	.9907	1.1694	1.2323	1.1812	1.1203	1.0829	.9907
10	1.2193	1.5623	1.5796	1.4306	1.4937	1.5623	1.1431
11	1.6004	2.3624	2.2588	2.2634	2.1285	2.4006	1.5242
12	1.7528	2.4006	2.553	2.4191	2.4646	2.4768	1.6004
13	1.7909	2.4387	2.3693	2.4094	2.3525	2.4768	1.7528
14	1.7528	2.4006	2.3693	2.424	2.3525	2.4387	1.6766
15	1.6766	2.4006	2.5172	2.3899	2.3525	2.4006	1.7528
16	1.7147	2.4768	2.452	2.3624	2.3899	2.4006	1.6766
17	1.7353	2.1658		2.3243	2.3152	2.3624	1.6804
18	1.773	2.3525	2.2862	2.4768	2.3899	2.3243	1.6804
19	2.3765	2.4646	2.2481	2.4006	2.3525		1.7551
20	1.9616	1.9791	1.6385		2.0165	2.21	1.8298
21	1.5844	1.6804	1.448	1.6766	1.531	1.4861	
22	1.3203	1.419	1.448	1.4712	1.3817	1.3717	1.3443
23	1.3203	1.307	1.2955	1.2449	1.307	1.2193	1.2696
24	1.0829	1.1765	1.2323	1.1812	1.1317	1.1576	1.1431
Max	2.3765	2.4768	2.553	2.4768	2.4646	2.4768	1.8298
Min	.8962	.9808	.9335	.9907	.9431	.9145	.8764
Avg	1.3804	1.6693	1.6306	1.6472	1.6343	1.6160	1.3136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 211 / 11 INCOMER NO.I

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.829	1.829	1.829	1.829	1.829	1.829
2	1.5242	1.5242	1.829	1.829	1.829	1.829	1.829
3	1.5242	1.5242	1.829	1.829	1.829	1.829	1.5242
4	1.5242	1.5242	1.829	1.829	1.829	1.829	1.5242
5	1.5242	1.5242	1.829	1.829	1.829	1.829	1.5242
6	1.5242	1.5242	1.829	1.829	1.829	1.829	1.829
7	1.5242	1.5242	1.829	1.829	1.829	1.829	1.829
8	1.5242	1.5242	1.829	1.829	1.829	1.5242	1.5242
9	1.5242	1.829	1.829	1.829	1.829	1.829	1.829
10	1.5242	2.1338	2.1338	2.1338	2.1338	2.1338	2.1338
11	1.5242	2.4387	2.7435	2.7435	2.7435	2.7435	2.4387
12	1.5242	2.4387	3.0483	2.7435	2.7435	2.7435	2.7435
13	1.5242	2.4387	2.7435	2.7435	2.7435	2.7435	2.4387
14	1.5242	2.4387	2.7435	2.4387	2.4387	2.7435	2.4387
15	1.5242	2.7435	2.7435	2.7435	2.7435	3.0483	2.7435
16	1.5242	2.7435	2.7435	2.7435	2.7435	3.0483	2.7435
17	1.5242	2.7435	2.7435	2.7435	2.7435	3.0483	2.7435
18	1.5242	2.4387	2.7435	2.7435	2.7435	2.7435	2.4387
19	1.5242	2.1338	2.4387	2.4387	2.1338	2.4387	2.1338
20	1.829	2.4387	2.1338	2.1338	2.1338	1.829	2.1338
21	1.5242	2.1338	1.829	1.829	1.829	1.829	2.1338
22	1.829	1.829	1.829	1.829	1.829	1.829	1.829
23	1.829	2.1338	1.829	1.829	1.829	1.829	1.829
24	1.829	2.1338	1.829	1.829	1.829	1.829	1.829
Max	1.829	2.7435	3.0483	2.7435	2.7435	3.0483	2.7435
Min	1.5242	1.5242	1.829	1.829	1.829	1.5242	1.5242
Avg	1.5877	2.0703	2.1973	2.1719	2.1592	2.1973	2.0830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 411 / 33 KV Incomer no I

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.678	3.9438	4.2295	4.0009	4.0009	3.9438	
2	3.658	3.7723	4.0581	3.8866	3.8295	3.8866	
3	3.5437	3.658	3.9438	3.8295	3.7723	3.7723	
4	3.4865	3.5437	3.8295	3.7723	3.7723	3.658	
5	3.4865	3.4865	3.8295	3.8866	3.7723	3.658	
6	3.5437	3.5437	4.0009	3.8866	3.9438	3.7723	
7	3.5437	3.5437	3.8866	3.8866	3.8295	3.7723	
8		3.658	3.7723	3.9438	3.8866	3.8295	
9	3.4865	3.7151	3.8295	3.8866	3.9043	3.7151	
10	3.658	4.5725	4.6868	4.6868	4.537	4.6296	
11	3.8866	5.5441	5.7728	5.7156	5.4893	6.0585	
12	4.1152	5.6013	6.1728	5.8871	5.6013	6.0014	
13	4.1152	5.7728	6.0014	5.7728	5.7693	6.0585	
14	4.2295	5.7728	5.7728	5.8299	5.6573	5.8299	
15	4.3439	6.0585	6.1728	6.0014	5.9374	6.1728	
16	4.3439	5.9442	6.2872	5.8871	5.9934	6.0014	
17	4.2295	5.4893		5.8299	5.8253	5.8871	4.8011
18	4.2867	5.4332	5.8299	5.8299	5.6013	5.6584	4.6296
19	5.0297	5.7133	5.6584	5.6584	5.4893	.9145	4.9154
20	4.9154	5.2652	5.2584	5.4298	5.0972		5.2092
21	4.5725	4.8731	4.6868	4.8011	4.369		
22	4.3439	4.7611	4.6296	4.8011	4.5153		4.7439
23	4.3439	4.8011	4.4582	4.3439	4.401		4.6296
24	3.8089	4.1152	4.4582	4.1152	4.1152	4.2295	
Max	5.0297	6.0585	6.2872	6.0014	5.9934	6.1728	5.2092
Min	3.4865	3.4865	3.7723	3.7723	3.7723	.9145	4.6296
Avg	4.0282	4.6909	4.8359	4.8154	4.7129	4.5725	4.8215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 413 / 33 KV POWE T/F NO.I

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.829	2.0576	1.829
2	1.6004	1.6004	1.829	1.829
3	1.6004	1.6004	1.829	1.6004
4	1.6004	1.6004	1.829	1.6004
5	1.6004	1.6004	1.829	1.6004
6	1.6004	1.6004	1.829	1.6004
7	1.6004	1.6004	1.829	1.6004
8	1.6004	1.6004	1.829	1.6004
9	1.6004	1.6004	1.829	1.829
10	1.3717	2.0576	2.0576	2.0576
11	1.3717	2.5149	2.7435	2.7435
12	1.3717	2.7435	2.9721	2.7435
13	1.3717	2.5149	2.7435	2.7435
14	1.3717	2.5149	2.7435	
15	1.6004	2.7435	2.7435	
16	1.6004	2.7435	2.9721	
17	1.6004	2.7435	2.9721	
18	1.6004	2.7435	2.2862	
19	1.3717	2.5149	2.5149	
20	1.6004	2.2862	2.2862	
21	1.6004	2.0576	2.0576	
22	1.6004	2.0576	1.829	
23	1.829	2.0576	1.829	
24	1.829	2.0576	1.829	
Max	1.829	2.7435	2.9721	2.7435
Min	1.3717	1.6004	1.829	1.6004
Avg	1.5718	2.1243	2.2196	1.9521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 201 / 11 KV AMBAI DEFENCE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8387	.8263	.8501	.9097	.9111	.8983	.7735
2	.8006	.7179	.8069	.8504	.8307	.8494	.7457
3	.7504	.7056	.7394	4.63	.7705	.7902	.71
4	.7226	.6779	.7188	.7655	.7221	.783	.6989
5	.6947	.711	.7077	.7518	.7316	.7662	.6616
6	.6917	.7354	.7058	.7378	.724	.7685	.6467
7	.6022	.6138	.6325	.6974	.6253	.7109	.6856
8	.5775	.551	.6067	.6818	.6409	.6814	.6772
9	.5547	.5439	.5884	.6365	.6226	.6388	.6075
10	.5387	.5651	.6346	.6425	.6184	.6517	.5791
11	.4516	.591	.552	.6289	.6491	.6567	.5883
12	.4742	.5823	.5597	.6343	.6615	.6669	.5455
13	.5258	.5832	.5505	.6478	.6139	.6292	.5426
14	.5312	.5777	.5885	.5951	.6055	.6269	.5546
15	.5443	.6152	.6144	.6352	.7116	.6468	.591
16	.5418	.6476	.6171	.6527	.7007	.67	.6604
17	.537	.6559	.3304	.6725	.6786	.713	.6316
18	.5266	.6059	.013	.6661	.6782	.6612	.641
19	.7243	.6988	1.0667	.8574	.7884	.6989	.727
20	.8109	.8978	1.0179	.9299	.9333	.8998	.9219
21	.8004	.885	.9558	.9095	.9553	.8858	.9179
22	.868	.8827	.9745	.9777	.9762	.8843	.4771
23	.9103	.9513	.9779	1.0157	1.0111	.9097	1.0793
24	.9126	.8772	.8861	.992	.9926	.9141	.935
Max	.9126	.9513	1.0667	4.63	1.0111	.9141	1.0793
Min	.4516	.5439	.013	.5951	.6055	.6269	.4771
Avg	.6638	.6958	.6956	.9216	.7564	.7501	.6916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 202 / 11 KV VIDYAPEETH

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5932	.2835	.6082	.5909	.5638	.6074	.5466
2	.5802	.2658	.5982	.584	.5577	.6013	.5229
3	.5576	.2481	.5944	.5614	.538	.5755	.5011
4	.5546	.2454	.5922	.5634	.5161	.5717	.5025
5	.5711	.2614	.5929	.5833	.5331	.5914	.5269
6	.6185	.2829	.6466	.6383	.5744	.6148	.5269
7	.6815	.3109	.659	.7033	.6142	.6741	.5786
8	.6528	.3077	.6414	.6815	.6312	.6386	.5771
9	.6143	.2865	.6702	.6635	.6445	.658	.5383
10	.606	.3658	.7213	.7871	.7148	.7213	.5376
11	.5567	.5093	.9242	.9337	.9615	.9425	.5258
12	.5285	.5093	1	1.0608	1.0435	.9794	.5316
13	.5485	.4715	1.0209	1.0185	1.0458	.9954	.5324
14	.5548	.5093	.9989	1.0391	.9768	1.0569	.5205
15	.5516	.547	.9886	.9957	1.0153	1.0183	.5263
16	.5278	.547	1.0302	.9932	1.0328	1.0447	.524
17	.5327	.4527	.6407	.9756	1.0124	1.0011	.5217
18	.5521	.3395	.3494	.8604	.8539	.7753	.4969
19	.3045	.3395	.6891	.6817	.4521	.5782	.5578
20	.3045	.3395	.7087	.6794	.7303	.6097	.602
21	.3224	.3395	.6861	.6607	.7038	.6098	.5967
22	.3258	.3584	.6814	.6672	.6756	.5863	.3018
23	.3045	.3395	.6578	.6453	.6544	.5855	.5906
24	.319	.2926	.6318	.6204	.6112	.5906	.5614
Max	.6815	.547	1.0302	1.0608	1.0458	1.0569	.602
Min	.3045	.2454	.3494	.5614	.4521	.5717	.3018
Avg	.5110	.3647	.7222	.7579	.7357	.7345	.5312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 203 / Siber

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2516	.5611	1.3106	1.2592	1.2161	1.2128	1.1633
2	1.1702	.5487	1.3293	1.244	1.1719	1.1808	1.0857
3	1.193	.5068	1.2853	1.1984	1.1279	1.1709	1.0803
4	1.1435	.4835	1.2654	1.1549	1.1058	1.1473	1.043
5	1.1481	.5716	1.299	1.1672	1.15	1.1585	1.0705
6	1.1421	.6036	1.2559	1.2106	1.2582	1.2641	1.0941
7	1.1184	.499	1.1822	1.1513	1.1291	1.137	1.0827
8	1.0682	.4572	1.0549	1.0019	1.0823	1.0301	.976
9	1.0902	.4656	1.1305	1.0697	1.0763	1.0374	.947
10	1.0841	.5544	1.2341	1.1222	1.2209	1.1693	.9959
11	1.0082	.6413	1.2806	1.2609	1.2677	1.2295	.9808
12	.9556	.6224	1.2661	1.2944	1.2801	1.3163	.9296
13	.8623	.547	1.1747	1.2898	1.2014	1.3027	.9244
14	.8754	.5658	1.2082	1.2618	1.2319	1.2737	.8682
15	1.041	.6036	1.2585	1.3012	1.3196	1.3126	.9097
16	1.0744	.6036	1.3636	1.2471	1.3287	1.2859	.9404
17	1.0359	.6036	1.3042	1.2277	1.2786	1.2204	.9637
18	.9585	.4715	1.0887	1.1033	1.0987	1.0926	.8547
19	.5249	.6224	1.4175	1.3575	1.1957	1.078	1.1376
20	.6584	.7167	1.4808	1.4716	1.4712	1.3476	1.4091
21	.695	.6979	1.4884	1.4705	1.4274	1.3537	1.396
22	.7207	.6979	1.4998	1.4578	1.415	1.3057	.7377
23	.6584	.7356	1.4496	1.4413	1.4037	1.2981	1.4258
24	.6465	.6219	1.4051	1.3575	1.3012	1.2883	1.2944
Max	1.2516	.7356	1.4998	1.4716	1.4712	1.3537	1.4258
Min	.5249	.4572	1.0549	1.0019	1.0763	1.0301	.7377
Avg	.9635	.5834	1.2930	1.2551	1.2400	1.2172	1.0546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 211 / 11 INCOMER NO.I

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / INCOMING

UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.414	1.4483	1.4849	1.4003	1.43	1.4072	1.2071
2	1.2929	1.3283	1.3386	1.2963	1.3123	1.2677	1.1283
3	1.2357	1.2711	1.3112	1.2689	1.2403	1.2243	1.0871
4	1.2117	1.2357	1.2369	1.2094	1.2026	1.1854	1.0505
5	1.1397	1.2003	1.2083	1.1648	1.1866	1.1648	1.0219
6	1.1751	1.222	1.2426	1.206	1.2357	1.2037	1.0802
7	1.1911	1.2597	1.2369	1.2631	1.2574	1.2254	1.126
8	1.1283	1.1671	1.2037	1.2003	1.1614	1.2026	1.0802
9	1.0837	1.126	1.1283	1.134	1.1831	1.1237	1.0162
10	1.0597	1.1351	1.1774	1.1706	1.214	1.1694	.9671
11	1.0757	1.262	1.326	1.2609	1.3466	1.2769	1.0048
12	1.0471	1.4129	1.4186	1.4792	1.4643	1.3729	1.0174
13	.9854	1.4403	1.4083	1.4941	1.4781	1.4209	.9854
14	.9957	1.366	1.3935	1.4883	1.422	1.4255	.9659
15	1.0448	1.4038	1.398	1.4849	1.4369	1.4621	.9648
16	1.07	1.4586	1.4678	1.4838	1.5181	1.5352	1.0151
17	1.0677	1.5078	1.5284	1.4929	1.5455	1.5192	1.054
18	1.046	1.4632	.9968	1.4678	1.4861	1.5101	1.0265
19	1.0048	1.2929	.7647	1.3249	1.3077	1.2997	1.0014
20	1.3443	1.3775	1.5524	1.4803	1.3237	1.2231	1.3009
21	1.4278	1.5341	1.5455	1.5226	1.5043	1.3729	1.4186
22	1.4632	1.4781	1.4929	1.5043	1.4506	1.3557	1.3946
23	1.5272	1.4895	1.5009	1.5569	1.4678	1.3489	1.414
24	1.5181	1.5261	1.4872	1.5238	1.4712	1.3409	1.4632
Max	1.5272	1.5341	1.5524	1.5569	1.5455	1.5352	1.4632
Min	.9854	1.126	.7647	1.134	1.1614	1.1237	.9648
Avg	1.1896	1.3503	1.3271	1.3699	1.3603	1.3183	1.1163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 411 / 33 KV Incomer no I NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 33 / INCOMING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.6445	5.5967	5.8624	5.6214	5.5619	5.6224	4.833
2	5.176	5.1647	5.4166	5.2558	5.1715	5.1766	4.5016
3	4.9359	4.9612	5.2915	5.1644	4.9702	5.0858	4.433
4	4.8102	4.804	5.108	4.7987	4.7439	4.9143	4.2731
5	4.5702	4.8354	5.0172	4.6958	4.7308	4.88	4.2045
6	4.7073	5.064	5.0515	4.89	5.0172	5.108	4.3876
7	4.7073	4.8708	4.9949	4.9359	4.9497	5.1887	4.673
8	4.4789	4.5404	4.7102	4.7073	4.6622	4.8474	4.4103
9	4.3074	4.3828	4.652	4.5702	4.6525	4.652	4.1132
10	4.2731	4.6725	4.9471	4.7757	4.876	4.9471	4.1741
11	4.1107	5.427	5.3817	5.3658	5.6327	5.6098	4.2427
12	3.9752	5.8042	5.7929	5.934	6.0322	5.9073	4.2799
13	3.8478	5.6688	5.7016	5.9534	5.9876	6.147	4.1186
14	3.9066	5.3704	5.7243	5.9145	5.8042	5.9756	3.9163
15	4.1975	5.5641	5.7243	6.0025	5.9174	6.0213	4.0295
16	4.2318	5.8042	6.0441	5.947	6.2037	6.2614	4.221
17	4.2215	6.0219	5.4054	5.9271	6.2037	6.2271	4.3004
18	4.0535	5.499	3.1879	5.5967	5.7361	5.9535	4.0341
19	4.1358	5.1766	4.0663	5.3658	5.084	5.1417	4.2455
20	5.5144	5.7579	6.2611	6.0733	5.8488	5.3355	5.4732
21	5.727	6.0442	6.1354	6.0219	6.226	5.69	5.7476
22	5.8997	5.9294	6.0554	6.0289	5.986	5.5644	4.2524
23	6.1042	6.0888	5.9756	6.1951	6.0546	5.6214	5.8734
24	6.0329	6.0288	5.9756	6.0213	5.8785	5.667	5.7817
Max	6.1042	6.0888	6.2611	6.1951	6.226	6.2614	5.8734
Min	3.8478	4.3828	3.1879	4.5702	4.6525	4.652	3.9163
Avg	4.7321	5.3782	5.3535	5.4901	5.4971	5.4811	4.5217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 412 / 33 KV POWE T/F NO.I

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3896	4.4067	4.5782	4.2524	4.2867	4.321	3.6694
2	3.9781	4.0295	4.1152	3.9781	3.9266	3.8752	3.3951
3	3.7723	3.8923	4.0638	3.9095	3.7723	3.8409	3.2922
4	3.6866	3.8066	3.8066	3.618	3.6523	3.6866	3.2065
5	3.4465	3.6523	3.7723	3.4979	3.6008	3.6523	3.1379
6	3.5837	3.7894	3.8066	3.6351	3.7723	3.8066	3.3779
7	3.5665	3.8409	3.8237	3.7551	3.8066	3.9438	3.5322
8	3.3951	3.5494	3.6523	3.5665	3.5151	3.7894	3.3436
9	3.2236	3.4122	3.4808	3.4294	3.5665	3.4979	3.1207
10	3.1893	3.5151	3.6523	3.4808	3.6351	3.6351	3.1207
11	3.2065	3.9952	4.1667	3.9095	4.1838	4.1667	3.2065
12	3.0521	4.4067	4.4239	4.4925	4.5782	4.5782	3.2922
13	2.915	4.441	4.4067	4.5439	4.6296	4.6811	3.1379
14	3.0007	4.0124	4.3896	4.4753	4.4067	4.5096	3.0007
15	3.155	4.1667	4.321	4.5782	4.4067	4.6125	3.0521
16	3.1893	4.3896	4.561	4.561	4.7325	4.8525	3.1893
17	3.2407	4.6468	4.6639	4.5268	4.7497	4.8011	3.2579
18	3.155	4.4582	2.4691	4.3896	4.6125	4.8697	3.155
19	3.0007	3.8923	2.4348	3.9266	3.7894	3.9781	3.0007
20	4.1667	4.2867	4.6811	4.561	4.2867	3.9095	4.0295
21	4.3724	4.6296	4.6125	4.5953	4.6982	4.321	4.321
22	4.4582	4.4753	4.4582	4.5268	4.4753	4.2696	4.2524
23	4.7325	4.561	4.4925	4.7154	4.5268	4.2524	4.321
24	4.6811	4.7497	4.5439	4.6296	4.5268	4.2524	4.5439
Max	4.7325	4.7497	4.6811	4.7154	4.7497	4.8697	4.5439
Min	2.915	3.4122	2.4348	3.4294	3.5151	3.4979	3.0007
Avg	3.6066	4.1252	4.0574	4.1481	4.1724	4.1710	3.4565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 402 / 33KV MIDC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)
1	18.5185	26.749
2	16.6667	24.76
3	15.9122	23.5254
4	15.3635	22.6338
5	15.0206	22.2223
6	15.3635	22.6338
7	16.118	23.2511
8	16.0494	23.1825
9	15.9808	24.0741
10	17.6955	26.3375
11	21.9479	29.5611
12	26.4747	***
13	27.5721	***
14	27.6406	***
15	26.8862	***
16	26.8176	***
17	27.0234	21.9479
18	27.3663	21.9479
19	25.8574	22.5652
20	10.974	26.9548
21	***	27.2291
22	***	25.4459
23	***	22.4966
24	29.904	21.4678
Max	39.3005	36.214
Min	10.974	21.4678
Avg	22.8595	26.5947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 201 / 11KV KASABA BAWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2097	2.2505	2.2754	2.0445	1.7601	2.0096	1.7684
2	2.0758	2.1535	2.1891	1.9243	1.6911	1.9007	1.6814
3	2.0521	2.0982	2.1655	1.9083	1.6562	1.8469	1.6517
4	2.03	2.0649	2.1472	1.8946	1.6478	1.8189	1.6433
5	2.0571	2.0731	2.1457	1.9473	1.7256	1.8332	1.7037
6	2.176	2.1405	2.3113	2.07	1.8142	1.8862	1.7787
7	2.0845	2.1785	2.2775	2.0323	1.9157	1.9361	.628
8	2.0761	2.1423	2.1845	1.99	1.9142	1.8772	1.8991
9	2.0754	2.1912	2.2244	2.0518	1.9047	1.89	1.9491
10	1.9719	2.2478	2.1996	2.0815	2.0268	1.9769	1.9929
11	1.9975	2.2179	2.3432	2.1956	2.0716	1.9801	1.9664
12	2.0375	2.1741	2.3592	2.1666	1.708	2.0958	1.9091
13	2.0685	2.2108	2.3093	2.1647	1.4588	2.0988	1.9481
14	2.083	2.1586	2.223	2.108	1.9422	2.0678	1.9715
15	2.1767	2.1466	2.2253	2.2009	1.9664	2.0845	2.0171
16	2.1617	2.2661	2.3294	2.1445	2.0504	2.1148	2.0398
17	2.1836	2.3124	.6584	2.2141	2.1238	2.1163	2.132
18	2.2268	2.378	.6257	2.4702	2.1194	2.1527	2.1617
19	2.5956	2.9963	2.5419	2.4735	2.1335	.7827	2.5918
20	2.9942	3.291	2.901	2.6865	2.7913	2.6272	2.9942
21	2.9231	3.1232	2.7795	2.5363	2.6947	2.6495	1.0227
22	2.8406	2.9671	2.6695	2.3609	2.5365	2.45	.9701
23	2.728	2.7585	2.4481	2.2227	2.4329	2.256	2.5533
24	2.4476	2.4657	2.3794	2.1156	2.0022	2.0891	2.094
Max	2.9942	3.291	2.901	2.6865	2.7913	2.6495	2.9942
Min	1.9719	2.0649	.6257	1.8946	1.4588	.7827	.628
Avg	2.2614	2.3753	2.2047	2.1669	2.0037	2.0225	1.8778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 202 / 11 KV KOLHAPUR SUGAR MILL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267	.0187	.04	.0187	.056	.0943	.2075
2	.028	.0187	.0583	.0164	.0373	.0943	.2075
3	.0213	.0187	.1097	.0164	.0373	.0943	.2096
4	.0267	.02	.0594	.0164	.0373	.0943	.2096
5	.0227	.0213	.0583	.0187	.1132	.0943	.2096
6	.0227	.0213	.0594	.0191	.132	.1132	.2096
7	.0227	.0183	.068	.0191	.132	.1886	.1886
8	.0227	.032	.0693	.0191	.1307	.1886	.3206
9	.016	.032	.0594	.0061	.1307	.2075	.3395
10	.0267	.0514	.0526	.0754	.1886	.2452	.3361
11	.132	.0629	.032	.1132	.1829	.2641	.3547
12	.132	.056	.0423	.0943	.1509	.2641	.298
13	.132	.056	.0423	.0867	.1867	.2452	.3174
14	.132	.056	.0423	.0754	.2054	.2452	.3361
15	.0133	.0457	.0423	.0754	.1867	.2641	.3547
16	.0133	.04	.0423	.1132	.2075	.2829	.3174
17	.0187	.0629		.0333		.2829	.3772
18	.016	.0583		.0754	.1867	.2641	.3395
19	.0187	.0583	.0366	.0377	.2075		.3395
20	.0187	.0594	.0351	.0566	.1698	.2614	.3206
21	.0187	.0629	.0175	.056	.1698	.2987	
22	.0187	.0629	.0187	.0566	.1132	.2641	
23	.0187	.0629	.0189	.0377	.1132	.2075	.2452
24	.028	.0187	.0446	.0164	.056	.0943	.2075
Max	.132	.0629	.1097	.1132	.2075	.2987	.3772
Min	.0133	.0183	.0175	.0061	.0373	.0943	.1886
Avg	.0395	.0423	.0477	.0481	.1361	.2023	.2839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 203 / 11KV ULAPEMALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.128	.128	.1097	.1097	.2012	.1097
2	.0914	.128	.128	.1097	.0914	.2012	.1097
3	.0914	.1097	.1294	.1097	.0914	.2012	.1097
4	.0914	.1097	.128	.1097	.0914	.1829	.1097
5	.0914	.128	.1463	.1097	.1097	.1829	.1097
6	.1097	.128	.1463	.1097	.1097	.1829	.1097
7	.0914	.128	.1463	.1097	.0914	.1829	.1097
8	.1097	.1829	.128	.1097	.0549	.1829	.0914
9	.1646	.2561	.2012	.2195	.0732	.2743	.128
10	.1829	.2378	.1829	.2012		.2561	.128
11	.1829	.2561	.2378	.2195	.1829	.2561	.128
12	.2012	.2012		.2012	.1829	.2561	.1463
13	.1829	.1829		.2012	.1646	.2561	.1646
14	.1463	.1829	.2195	.1829	.2195	.2561	.1463
15	.1646	.2012	.2561	.2012	.2012	.2561	.1646
16	.1646	.1829	.2743	.2012	.2195	.2378	.1463
17	.1829	.1829		.1463	.1829	.2561	.1463
18	.1829	.1829		.1829	.1829	.2378	.1463
19	.2012	.1829	.0914	.1097	.2012		.1829
20	.2195	.2012	.128	.128	.2195	.1097	.1829
21	.2195	.2195	.128	.128	.2195	.1097	
22	.2012		.128	.1097	.2195	.1646	
23	.2012	.1829	.128	.1097	.2195	.1463	.1463
24	.1097	.128	.128	.1097	.1097	.2012	.1097
Max	.2195	.2561	.2743	.2195	.2195	.2743	.1829
Min	.0914	.1097	.0914	.1097	.0549	.1097	.0914
Avg	.1539	.1749	.1592	.1471	.1543	.2084	.1330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 204 / 11 KV WADANAGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.6099	.6468	.5729	.5729	.5729	.5359
2	.5914	.5914	.6283	.5544	.5544	.5729	.5175
3	.5914	.5729	.6283	.5544	.5544	.5729	.5175
4	.5914	.5729	.6283	.5544	.5544	.5729	.5175
5	.6099	.5914	.6468	.5544	.5729	.5914	.5544
6	.6283	.6283	.6838	.5914	.5914	.6283	.5729
7	.5914	.5914	.6468	.5729	.5914	.6099	.6099
8	.5544	.5544	.5359	.5914	.5729	.5175	.499
9	.5359	.5359	.5914	.5544	.5914		.5729
10	.5175	.5729	.5544	.5544	.5729	.5175	.5544
11	.5175	.6283	.6099	.5914	.5359	.5544	.5544
12	.5544	.6099	.5914	.499	.5544		.6468
13	.5544	.6099	.5544	.5914	.5914	.6099	.5544
14	.5729	.6099	.5914	.6099	.5175	.6099	.6099
15	.5729	.5914	.6099	.6283	.5914	.6653	.6283
16	.5729	.6099		.6468	.6283	.6468	.6838
17	.5544	.6099		.6283	.6283	.499	.6838
18	.5729	.6283		.7023	.5544	.5914	.6468
19	.7207	.7762	.7207	.7207	.5729		.7762
20	.8316	.8501	.7392	.7947	.7947	.7207	.8686
21	.8316	.8131	.7392	.7762	.7577	.6838	
22	.8316	.8316	.7207	.7577	.7392	.7023	
23	.7207	.7577	.6283	.6838	.6838	.6099	.7577
24	.6468	.7282	.6653	.5729	.6099	.5914	.5544
Max	.8316	.8501	.7392	.7947	.7947	.7207	.8686
Min	.5175	.5359	.5359	.499	.5175	.499	.499
Avg	.6199	.6448	.6362	.6191	.6037	.6020	.6099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 205 / 11 KV Sarwal AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6935		.3294			
2		.6762		.3294			
3		.6415	.4508	.3294			
4		.6241	.5201	.3294			
5		.6241	.5201	.3121			
6		.6241		.3121			
7		.5895	.5028	.3294			
9				.5028	.4334	.5201	.5721
10				.5721	.5028	.6415	.5895
11				.6068	.5201	.6415	.5895
12				.5973	.5375	.6241	.5895
13				.6068	.5201	.6241	1.2851
14				.6068	.5201	.6068	.5201
15				.6241	.5375	.6241	.5201
16				.5721	.5201	.6241	.5375
22	.6935	.6241	.3121				
23	.7282	.6588	.3294				
24		.7282		.3294			
Max	.7282	.7282	.5201	.6241	.5375	.6415	1.2851
Min	.6935	.5895	.3121	.3121	.4334	.5201	.5201
Avg	.7109	.6484	.4392	.4556	.5115	.6133	.6504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 202 / 11KV FILTER HOUSE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	1.094	2.2514	2.3472	2.0464
2	.9335	.9335	2.151	2.1285	1.9311
3	.8402	.8215	2.0088	1.9526	1.8232
4	.8402	.8676	1.9772	1.8873	1.7456
5	.8402	.8962	1.8831	1.7806	1.7339
6	.8402	.9335	1.9429	1.7902	1.7131
7	.8775	.9522	1.9444	1.7871	1.7932
8	.9149	.9522	2.053	1.8248	1.7879
9	.9896	1.0269	2.1113	1.9984	1.9338
10	1.0456	1.1273	2.3365	.9945	1.9455
11	1.1203	1.1458	2.4474	.9907	2.074
12	.9335	1.1584	1.3085		2.2718
13	1.0456	1.1088	2.5625	1.4228	2.1567
14	1.0456	1.0456	2.4653	1.2986	2.1034
15	1.1203	1.2323	2.3449	1.134	2.1388
16	1.0642	1.251	2.5743	1.1065	2.1867
17	1.0829	1.2323	1.2772	2.0523	2.194
18	1.1016	1.251		2.1755	1.0837
19	1.1576	1.1763	.0023	2.2028	1.0669
20	1.1763	1.2136		2.2534	2.2196
21	1.1949	1.1949	.003	2.2733	2.175
22	1.1883	1.2136		2.298	2.1768
23	1.2449	1.2637	2.6455	2.3405	1.1256
24	1.0829	1.1694	2.4836	2.3982	1.0456
Max	1.2449	1.2637	2.6455	2.3982	2.2718
Min	.8402	.8215	.0023	.9907	1.0456
Avg	1.0272	1.0942	1.9416	1.8451	1.8530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 203 / 11KV AKASHWANI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2188	2.2649	2.4034	2.3049	2.2398	2.1837	2.1243
2	2.0675	2.1194	2.2173	2.1822	2.0855	2.0176	1.9791
3	1.9623	1.9494	2.0043	2.0447	1.9577	1.8846	1.8726
4	1.9143	1.861	1.9208	1.9924	1.877	1.8179	1.7543
5	1.7821	1.8405	1.8301	1.9509	1.8263	1.7871	1.7154
6	1.7684	1.8351	1.892	1.949	.9328	1.8387	1.7368
7	1.8694	1.8774	1.8965	1.9921	1.8614	1.8004	1.7295
8	1.8656	1.866	1.8557	1.9164	1.8677	1.8408	1.7691
9	1.9296	1.9235	1.9597	2.0024	1.9699	1.9128	1.7867
10	1.9764	2.1445	2.1156	1.0639	2.1883	2.0317	1.9265
11	1.978	2.295	2.3133	1.1027	2.3069	2.2055	1.9528
12	1.9746	2.4342	1.2452	.6615	2.5175	2.146	1.0044
13	1.9204	2.4321	2.4914		2.4859	1.9356	1.9494
14	1.936	2.3636	2.5324	1.3923	2.4455	1.9029	2.007
15	1.9803	2.4676	2.5214	1.4175	2.5031	2.4078	2.0667
16	2.0507	2.5834	2.5628	1.3771	2.6657	2.8231	2.042
17	2.0241	2.5091	1.3093	2.6488	2.6227	2.7339	1.9581
18	2.0251	2.5633	1.2269	2.54	1.326	2.5678	1.8639
19	2.1312	2.5057		2.3908	1.2026	1.2719	1.9402
20	2.3514	2.5625	1.2879	2.5507	2.3301	.9869	2.3358
21	2.3739	2.5194	1.3382	2.5673	2.4025		2.5042
22	2.3547	2.487	2.4169	2.4935	2.3058	2.8213	2.5284
23	2.42	2.5872	2.4074	2.4554	2.415	2.6036	2.5389
24	2.3396	2.5002	2.4741	2.3914	2.3718	2.4311	2.3952
Max	2.42	2.5872	2.5628	2.6488	2.6657	2.8231	2.5389
Min	1.7684	1.8351	1.2269	.6615	.9328	.9869	1.0044
Avg	2.0506	2.2705	2.0097	1.9734	2.1128	2.0849	1.9784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 205 / 11KV LAXMIPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1476	2.3087	2.3797	.5038	.455	2.1546	.4563
2	2.0531	2.1087	2.2075	.4578	.4424	2.0191	.4264
3	1.96	1.9555	2.1193	.402	.4031	1.9087	.3936
4	1.8164	1.8748	2.005	.3713	.3692	1.8541	.3568
5	1.7997	1.8473	2.0115	.3799	.35	1.8431	.3585
6	1.8126	1.8717	1.9399	.3538	.32	1.8397	.3742
7	1.81	1.8755	1.9658	.3406	.3431	1.8852	.3345
8	1.8957	1.8476	1.9768	.3454	.3446	1.9311	.3414
9	1.941	2.0818	2.1094	.3727	.3887	2.1353	.3551
10	2.0311	2.5187	2.6436	.2141	.4008	2.5168	.4405
11	2.2186	3.2183	3.3535	.0831	.4287	3.1188	.4157
12	2.3575	3.4455	1.8519		.4394	3.5871	.2309
13	2.4432	3.6382	3.7761	.314	.4161	3.7929	.4355
14	2.392	3.5559	3.7376	.2545	.4069	3.6946	.4527
15	2.436	3.6344	3.6042	.2141	.3723	3.6652	.4591
16	2.31	3.7675	3.6809	.2408	.4203	3.6222	.4319
17	2.3371	3.8497	1.8877	.4434	.5848	3.5448	.4157
18	2.3707	3.8283	1.8488	.4289	.3368	3.3913	.4081
19	2.6231	3.7281		.2263	1.6194	1.7406	.4275
20	2.9212	3.7643		.3879	3.2666	1.7086	.4519
21	2.9268	3.4911		.4809	3.0357	.2614	.4542
22	2.7203	3.0232	.3932	.4395	2.5911	.2454	.4626
23	2.6067	2.7064	.5791	.4527	2.4469	.4222	.474
24	2.3903	2.4756	1.4822	.4839	1.5106	1.3687	.4485
Max	2.9268	3.8497	3.7761	.5038	3.2666	3.7929	.474
Min	1.7997	1.8473	.3932	.0831	.32	.2454	.2309
Avg	2.2634	2.8507	2.2645	.3561	.9039	2.2605	.4086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 206 / 11KV USHA TALKIES FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3076	2.3158	2.3262	2.4771	2.2614	2.32	2.3579
2	2.1586	2.0812	2.1681	2.318	2.1268	2.1498	2.2139
3	1.9981	1.9799	2.074	2.162	2.071	2.0523	2.1038
4	1.8583	1.89	2.0226	2.0915	2.0035	2.0096	1.994
5	1.8431	1.8743	2.0111	2.0446	1.9631	1.9741	1.9532
6	1.8248	1.913	2.0572	2.0595	1.9935	2.0169	1.9822
7	1.9125	1.9538	2.0405	2.1037	1.9787	2.0296	2.0119
8	1.9525	1.9715	2.0369	2.1769	2.0542	2.069	2.03
9	1.9773	2.141	2.1388	2.2379	2.2485	2.1927	2.0889
10	2.1834	2.5191	2.6105	1.2231	2.7427	2.5408	2.2976
11	2.4718	3.2625	3.3372	1.5691	3.4469	3.1695	2.4566
12	2.6752	3.5511	1.8961	1.3146	3.818	3.4819	1.2818
13	2.6612	3.6946	3.7875	1.9357	3.7929	3.3668	2.6394
14	2.7286	3.6397	3.767	1.9212	3.6938	3.5189	2.6521
15	2.7279	3.7208	3.7243	1.9418	3.647	3.7208	2.6078
16	2.7206	3.7647	3.7735	1.9044	3.6641	3.6282	2.6116
17	2.6833	3.7841	1.925	3.8308	3.7361	3.5642	2.6372
18	2.6577	3.7643	1.8656	3.7509	1.9204	3.4438	2.5861
19	2.8197	3.5284		3.4995	1.861	1.685	2.6888
20	2.87	3.2408		3.277	3.2712	1.4365	2.9142
21	2.7515	3.0781	.2629	3.0427	3.0102	.2172	2.8323
22	2.5846	2.8106	3.1876	2.6665	2.7377	2.4719	2.6471
23	2.5926	2.6444	2.9135	2.4693	2.5787	2.8898	2.5059
24	2.4733	2.5804	2.6052	2.4979	2.3858	2.5492	2.4467
Max	2.87	3.7841	3.7875	3.8308	3.818	3.7208	2.9142
Min	1.8248	1.8743	.2629	1.2231	1.861	.2172	1.2818
Avg	2.3931	2.8210	2.4787	2.3548	2.7086	2.5208	2.3559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 208 / 11KV BLOOD BANK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6908	.6602	1.4099	1.4472	1.443	1.4045	1.4193
2	.6908	.6161	1.3622	1.3664	1.3657	1.3187	1.339
3	.5975	.5975	1.2666	1.2952	1.2898	1.2468	1.2822
4	.5975	.5544	1.2468	1.2346	1.2623	1.2562	1.2936
5	.5975	.5228	1.2562	1.227	1.2963	1.2734	1.2331
6	.5975	.5228	1.2316	1.3171	1.3104	1.2791	1.261
7	.6161	.5601	1.2395	1.2932	1.2483	1.2115	1.2856
8	.6348	.5601	1.2738	1.3196	1.2917	1.23	1.2745
9	.6535	.6535	1.4228	1.4293	1.5459	1.3864	1.3196
10	.7095	.8962	1.8896	.8916	1.959	1.8309	1.3311
11	.8215	1.1389	2.2759	1.1553	2.3305	2.1849	.4024
12	.8029	1.0719	1.2102	1.1812	2.4634	2.3201	.7103
13	.8215	1.1273	2.2386	1.1797	2.38	2.2859	1.6545
14	.8029	1.0903	2.1712	1.169	2.2839	2.2939	1.6149
15	.8215	1.1203	2.3516	1.1995	2.3205	2.3011	1.632
16	.8402	1.1883	2.4478	1.2193	2.4745	2.3449	1.624
17	.8029	1.1763	1.201	2.4619	2.434	2.2578	1.6133
18	.7842	1.1763		2.3868	1.2422	1.1035	1.5036
19	.8589	1.1203		2.287	1.038	2.1018	1.664
20	.8962	.9709	1.1446	2.1288	2.0733		1.9162
21	.8589	.8962	1.0014	1.9421	1.9006	.5838	1.8227
22	.8029	.7842	1.8223	1.7947	1.7002	1.6935	1.6948
23	.7545	.7655	1.6686	1.645	1.6351	1.5686	1.619
24	.7095	.6979	1.5253	1.5451	1.53	1.4979	1.5032
Max	.8962	1.1883	2.4478	2.4619	2.4745	2.3449	1.9162
Min	.5975	.5228	1.0014	.8916	1.038	.5838	.4024
Avg	.7402	.8528	1.5753	1.5049	1.7424	1.6511	1.4172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 411 / 33 KV Nagala Park

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.3295	6.3295	6.4415	5.715	5.4893	5.0972	4.6399
2	6.1614	5.7105	6.1054	5.4887	5.2092	4.8731	4.313
3	5.7133	5.3224	5.7133	5.2058	4.9291	4.7531	4.0175
4	5.3212	5.156	5.6573	4.9794	4.7611	4.6965	3.7912
5	5.2652	5.2092	5.6573	4.9794	4.8171	4.8097	3.8477
6	5.4893	5.3778	5.8282	5.0412	4.8663	4.8663	4.1872
7	5.4893	5.4887	5.7716	5.036	4.8171	4.8097	4.0889
8		5.655	5.9414	5.1492	5.036	4.8663	4.1307
9	5.9374	6.4415	6.5072	5.6584	5.715	5.6584	4.357
10	6.6655	7.7618	8.0659		6.7215	6.7215	4.9291
11	7.5057	9.6468	9.9143		8.1779	7.7858	4.6491
12	7.5617	9.8131	10.3624		8.85	8.3459	
13	7.8418	9.9794	10.4184		8.3459	8.2899	5.8253
14	7.6738	9.425	9.8583		8.2339	8.2899	5.6573
15	7.6738	9.8131	9.9143		8.4019	8.85	5.6013
16	7.7298	10.1458	10.2504		8.738	8.626	5.7693
17	7.6738	10.1383		8.514	8.85		5.7105
18	7.8978	10.5864		8.57			27.8315
19		10.5864		8.0659			6.5975
20	9.1301	9.8023		8.4019	9.7462		6.8039
21	8.514	8.626		7.5617	8.3459		6.2649
22	7.5617	7.7858	5.8814	6.7776	7.6178	5.6013	5.6573
23	7.276	7.6389	6.7215	6.4415	6.2243	5.4332	5.4887
24	7.0576	6.8747	7.0576	6.2734	5.8814	5.7716	4.9228
Max	9.1301	10.5864	10.4184	8.57	9.7462	8.85	27.8315
Min	5.2652	5.156	5.6573	4.9794	4.7611	4.6965	3.7912
Avg	6.9759	7.8881	7.4772	6.3447	6.8080	6.2182	6.0470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 201 / 11KV S.T. STAND FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2369	2.3149	2.332	1.1927	2.2639	2.2092	2.0469
2	1.1218	2.1485	2.0677	1.0844	2.1295	2.0641	1.9559
3	1.0463	2.0256	2.0124	1.0334	2.0593	1.9814	1.8854
4	.9831	1.9353	1.956	.9884	1.9563	1.9026	1.8558
5	.9496	1.9026	1.9385	1.9071	1.9018	1.7587	1.8252
6	.9541	1.8458	1.9427	1.9087	1.8661	1.7806	1.7805
7	1.8223	1.8805	1.9216	.9907	1.8428	1.7798	1.8755
8	1.9838	2.0035	2.1501	1.0989	2.2331	1.9867	1.8652
9	2.1611	2.3403	2.4377	2.3175	2.3365	2.2472	2.1832
10	2.4103	1.3093	2.9679	2.8217	2.9015	2.5855	2.271
11	2.6396	1.2155	3.26	3.1091	2.8111	3.007	2.4911
12	1.342		3.5461	1.6293	3.3518	1.5455	1.2986
13	2.7839	.0975	3.4021	2.9742	3.4183	2.4486	2.5867
14	2.8449	3.8331	3.3781	2.2437	1.717	3.5974	2.6549
15	2.8678	3.6949	3.603	1.7846	1.7185	3.3482	2.7419
16	2.9829	4.0341	3.593	1.7766	3.6231	3.5031	2.8427
17	2.9422	3.837	1.8122	1.6221	3.5651	3.4025	2.778
18	2.857	3.6454	1.5485	1.7177	3.5555	3.3809	2.7811
19	3.0705	3.6447	1.6118	1.6804	3.2127	1.7764	3.0232
20	3.2084	3.6528	3.3017	***	3.3905	3.2876	3.3152
21	3.1706	3.2974	3.1946	1.4937	3.1881	3.0158	3.1489
22	3.0076	3.0377	2.9384	1.3957	3.0786	2.8887	1.5905
23	2.8279	2.7607	2.8386	1.3769	2.8148	2.5686	2.8363
24	2.5541	2.6644	2.5376	2.3419	2.5878	2.388	2.5043
Max	3.2084	4.0341	3.603	16.8039	3.6231	3.5974	3.3152
Min	.9496	.0975	1.5485	.9884	1.717	1.5455	1.2986
Avg	2.2404	2.5705	2.5955	2.3872	2.6468	2.5189	2.3391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 202 / 11 KV LINE BAZAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5746	1.1051	1.0883	.5556	1.02	.9838	.9488
2	.5418	1.0776	1.0153	.5121	.4854	.9594	.9312
3	.5205	1.0646	1.0038	.5053	.9335	.9282	.9137
4	.5167	1.041	.9901	.5022	.9305	.9354	.9019
5	.5152	1.0025	.9782	.9728	.9406	.9457	.9154
6	.538	1.0417	1.0712	.5373	.996	.9663	.9488
7	.9835	1.0304	1.0419	.5373	.9713	.9444	.9132
8	.9128	.9823	1.0126	.9998	.9503	.9122	.873
9	.9054	1.0334	1.0427	1.0478	.5304	.936	.8953
10	.9319	.5777	1.1898	1.0505	.543	1.0023	.9122
11	.9537	.5929	1.195	1.0969	.5853	1.0547	.8745
12	.5037	.6066	1.2456	.5921	.5434	.5517	.4931
13	.983	1.155	1.195	1.1448	.5121	1.1207	.9669
14	.9822	1.3006	1.1927	1.1393		1.0959	.9827
15	.9825	.6081	1.1925	1.1749		1.1151	.9751
16	.9787	1.1782	1.2094	1.1751	.4887	1.0363	.9827
17	.9298	1.0749	.5975	1.0982	.4805	1.0041	1.0379
18	.9578	1.0678	.6219	1.1201	.4344	1.005	.9823
19	1.0924	1.2327	1.2955	1.1751	.4525	.5556	1.2197
20	1.3027	1.4615	1.3914	1.3519	.6516	1.3323	1.4907
21	1.302	1.3842	1.3816	1.3289	.6283	1.2649	1.3954
22	1.2925	1.3464	1.3207	1.2601	.6036	1.2431	.7209
23	1.2895	1.305	1.2232	1.2243	.5487	1.1599	1.3333
24	1.2026	1.193	1.1639	1.1248	.5041	1.068	1.1484
Max	1.3027	1.4615	1.3914	1.3519	1.02	1.3323	1.4907
Min	.5037	.5777	.5975	.5022	.4344	.5517	.4931
Avg	.9039	1.0610	1.1108	.9678	.6697	1.0050	.9899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 203 / 11 KV EXCISE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9464	3.6485	3.7317	1.8945	3.6734	3.5981	3.4286
2	1.8557	3.4005	3.4273	1.7558	3.4423	3.4316	3.2219
3	1.7185	3.2394	3.2	1.6728	3.2958	3.2821	3.1192
4	1.6377	3.1241	3.1398	1.6347	3.1889	3.1344	3.091
5	1.5493	3.0278	3.0418	3.3425	1.5783	3.0834	3.0475
6	1.5272	3.0155	3.0773	1.6446	3.2333	3.2264	3.0355
7	3.0193	2.9721	3.1517	1.6484	3.2015	3.1024	2.9563
8	3.0845	3.1106	3.1708	3.3634	3.3861	3.1982	3.0933
9	3.0461	3.3543	3.2661	3.4843	3.4857	3.3718	3.2001
10	3.0635	1.8534	3.7555	3.6664	3.936	3.7088	3.0533
11	3.2352	2.0492	4.3382	4.0864	4.1991	4.2075	3.303
12	1.7116	2.2428	4.4655	2.1232	4.2833	2.1864	1.7048
13	3.4145	4.3146	4.47	4.1697	4.2551	4.2139	3.5343
14	3.4326	4.147	4.4149	4.0315	2.1384	4.161	3.5532
15	3.5227	2.2314	4.3762	4.2669	2.159	4.3633	3.7013
16	3.5408	4.5211	4.4824	4.4402	4.401	4.5432	3.738
17	3.3899	4.3502	2.2497	4.2336	4.3329	4.355	3.5356
18	3.3055	4.1152	1.5638	4.1156	4.2214	4.2647	3.1802
19	3.5405	4.3593	4.3694	4.2798	4.1145	2.095	3.4697
20	3.9985	4.5364	4.4605	4.4189	4.5535	4.0907	4.1434
21	3.9426	4.4265	4.1709	4.4597	4.3556	3.9753	4.1465
22	3.9674	4.3395	4.1181	4.329	4.2086	3.9156	2.1049
23	4.0907	4.2654	4.0535	4.3063	4.1509	3.9048	4.2472
24	3.9826	3.9955	3.9863	3.9279	4.0777	3.7997	3.9855
Max	4.0907	4.5364	4.4824	4.4597	4.5535	4.5432	4.2472
Min	1.5272	1.8534	1.5638	1.6347	1.5783	2.095	1.7048
Avg	2.9801	3.5267	3.6867	3.3873	3.6613	3.6339	3.3164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 204 / 11KV SHAHU COLLEGE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1797	2.3354	2.3064	1.0943	2.1537	2.1249	1.9727
2	1.1035	2.1441	2.0551	1.0197	1.9821	2.0283	1.8927
3	1.0433	1.9932	1.998	.9907	1.9068	1.9814	1.7932
4	1.0021	1.9433	1.9507	.9534	1.8145	1.9219	1.763
5	.9648	1.8805	1.938	1.9151	1.7932	1.8861	1.7655
6	.9777	1.8899	1.9488	.9739	1.8527	1.8842	1.7261
7	1.9113	1.8705	1.9594	.9808	1.877	1.9387	1.7267
8	1.9742	1.9604	1.9579	1.9563	1.9859	1.9974	1.8237
9	1.906	1.9982	2.0834	2.0525	1.9898	1.9545	1.8743
10	1.8922		2.0568	2.0255	2.0259	2.0172	1.8705
11	1.8728		1.6143	1.9874	1.9143	1.9797	1.936
12	.9541		1.2569	1.0326	1.9609	.9998	.9907
13	1.9913		2.1578	2.0498	1.8983	1.9951	1.7638
14	1.9535	1.0164	2.1823	***	1.0044	2.0904	1.8812
15	1.9667		2.143	2.1258	1.0646	2.1494	1.8772
16	1.9965	.9877	2.0865	2.0374	1.9685	2.1613	2.0031
17	2.0157	1.0031	.7804	1.9437	2.0062	2.08	1.9482
18	2.021	1.1852	1.1843	1.9288	2.0215	1.961	1.8706
19	2.2028	1.1767	2.4518	2.3396	1.9646	1.0463	2.0559
20	2.5659	1.2134	2.5391	2.5682	2.3644	2.3594	2.412
21	2.5255	1.2748	2.4364	2.5808	2.3255	2.2477	2.4497
22	2.58	1.2586	2.4539	2.5366	2.3807	2.2913	1.2872
23	2.6151	1.315	2.4097	2.5526	2.4358	2.2441	2.6109
24	2.4997	1.1576	2.4166	2.3777	2.3141	2.1712	2.3438
Max	2.6151	2.3354	2.5391	130.2799	2.4358	2.3594	2.6109
Min	.9541	.9877	.7804	.9534	1.0044	.9998	.9907
Avg	1.8215	1.5581	2.0153	7.1793	1.9586	1.9796	1.9016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 205 / RAW WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4291	.8085	.4183		.3395	3.051	2.6746
2	.4245	.8078	.4183		.3395	2.8473	2.6024
3	.4191	.8063	.4183		.3206	2.716	2.5618
4	.4336	.8124	.417		.3206	2.6448	2.5387
5	.4435	.8169	.417	.3206	.3395	2.6425	2.5252
6	.4443	.8108	.3985		.415	2.6555	2.5669
7	.7663	.8055	.3803		.415	2.5665	2.5162
8	.7872	.8047	.3925	.3395	.381	2.644	2.5058
9	.7769	.9587	.3969	.3772	.4191	2.8856	2.5745
10	.8745	.5479	.415	.4939	.4338	2.9167	2.5911
11	.9255	.3262	.5658	.6072	.5281	3.323	2.5225
12	.474		.5658		.5228	1.7657	1.4129
13	.9072		.5601	.6066	.5093	***	2.6799
14	.8958	.3018	.5601	.5877		2.9677	2.6587
15	.8874		.5658	.5871		2.4857	2.6799
16	.8935	.6097	.5658	.5823	.5093	3.5109	2.7408
17	.8918	.6281		.5658	.5658	3.3238	2.7439
18	.8994	.552		.5281	.4715	3.1024	2.6528
19	.854	.4758	.4572	.4572	.4108	1.5074	2.6513
20	.8631	.4758	.3772	.4527	.3921	.2001	3.0487
21	.8434	.4325	.3395	.4108	.3734	3.5326	3.0258
22	.6249	.2432	.3429	.1097	.1867	3.1444	1.5104
23	.8261	.4158	.3395	.3696	.3696	2.9824	3.0308
24	.7823	.3772	.4187	.3206	.3772	3.0594	2.9375
Max	.9255	.9587	.5658	.6072	.5658	19.0659	3.0487
Min	.4191	.2432	.3395	.1097	.1867	.2001	1.4129
Avg	.7236	.6104	.4423	.4539	.4064	3.3976	2.5814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 206 / APPLE HOSPITAL.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0076	.0724	.054	.0854	.1082	.1364	.0521
2	.0076	.0739	.0551	.0297	.0806	.1219	.0525
3		.0701	.0541	.0145	.1126	.0968	.0526
4	.0267	.052	.0545	.0526	.0869	.0817	.0529
5	.016	.0709	.072	.0892	.0768	.1479	.0379
6	.016	.0732	.0735	.1067	.0817	.1078	.0378
7	.1082	.0701	.072	.0533	.1379	.16	.035
8	.1439	.0716	.052	.1243	.1501	.0837	.0697
9	.1897	.0709	.0551	.1684	.1646	.1372	.0543
10	.2522		.1109	.232	.2577	.132	.0895
11	.2416		.112	.214	.2648	.1307	.0732
12	.1158		.112	.1265	.2438		
13	.2131		.1097	.2491	.24	.1109	.0716
14	.2359	.0934	.0914	.2096	.1273	.1109	.0701
15	.2018	.112	.112	.2067	.1303	.0905	.0686
16	.2044	.112	.112	.1823	.2108	.0876	.0678
17	.1973	.0943		.2009	.2072	.0734	.1086
18	.1948	.0927		.1991	.1799	.0734	.0732
19	.0905	.072	.0671	.157	.1684		.0701
20	.0886	.0751	.0876	.1554	.1874	.0707	.0732
21	.0914	.0722	.0747	.1669	.1646	.0729	.0724
22	.0724	.0901	.0549	.1639	.1646	.0687	
23	.0701	.0693	.0914	.1562	.1501	.0729	.0747
24	.0549	.0739	.0717	.1704	.1595	.0724	.0537
Max	.2522	.112	.112	.2491	.2648	.16	.1086
Min	.0076	.052	.052	.0145	.0768	.0687	.035
Avg	.1235	.0791	.0795	.1464	.1607	.1018	.0642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 207 / 11 KV STP Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774	***	***	***	***	***	.6765
2	.208	***	***	***	***	.4862	.4674
3	.1722	.4062	.3886	.144	.5138	.5011	.5855
4	.25	***	***	***	***	.5535	.4666
5	.2126	***	***	***	***	.447	.5409
6	.1494	.0876	.5433	.1494	.4836	.4889	.5543
7	.6497	***	***	***	***	.395	.3198
8	.3723	***	***	***	***	.2606	.5625
9	.3767	.1738	.5499	.4323	.4458	.445	.7552
10	.7074	***	***	***	***	.6574	.4828
11	.488	***	***	***	***	.4976	.5001
12	.1486		.7639	.1677	.7465	.2576	.314
13	.4476	***	***	***	***	.5912	.4761
14	.4461	***	***	***	***	.8612	.5024
15	.399	.1875	.5847	.4872	.2477	.6958	.7754
16	.6744	***	***	***	***	.4479	.5077
17	.4178	***	***	***	***	.5117	.5064
18	.1905	.5666	.1311	.2241	.539	.5094	.4946
19	.5119	***	***	***	***	.1981	.2065
20	.3806	***	***	***	***	.5508	.6716
21	.1821	.4203	.4555	.3511	.5118	.2926	.7507
22	***	***	***	***	***	.2999	.2492
23	***	***	***	***	***	.3677	.8004
24	.9158	.6276	.5612	.301	.6777	.4679	.5428
Max	50.207	50.3819	50.4144	50.3802	50.3579	50.3201	.8004
Min	.1486	.0876	.1311	.144	.2477	.1981	.2065
Avg	4.5303	35.0093	33.6009	33.5304	33.6402	2.5460	.5296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 202 / 11KV RANKALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4632	1.4083	1.419	1.3535	1.3676	1.2437
2		1.3717	1.3352	1.251	1.2254	1.3817	1.1888
3	1.2437	1.2803	1.3169	1.1763	1.1523	1.307	1.1706
4	1.2437	1.2803	1.2803	1.2323	1.2071	1.307	1.134
5	1.2437	1.2437	1.2803	1.3256	1.2986	1.3256	1.134
6	1.2254	1.1888	1.2437	1.3256	1.2986	1.2883	1.1157
7	1.1523	1.1523	1.2254	1.2696	1.2254	1.2382	1.0974
8		1.134	1.2254	1.2197	1.262	1.1827	1.1888
9		1.1706	1.1888	1.2254	1.2012	1.2071	1.1523
10	1.0679	1.1584	1.2437	1.1706	1.2071	1.1888	1.1523
11	1.0791	1.1222	1.1706	1.134	1.2254	1.1946	1.1888
12	1.0791	1.1871	1.2071	1.2071		1.2715	1.134
13	1.1458	1.1871	1.6095	1.2437	1.1706	1.2489	1.1888
14	1.1827	1.1871	1.3169	1.262	1.2803	1.267	1.2071
15	1.2567	1.2437	1.3717	1.2986	1.3717	1.3032	1.2803
16	1.2567	1.307	1.3535	1.3169	1.3535	1.3352	1.3169
17	1.2254	1.3256		1.2803	1.3535	1.2986	1.2437
18	1.1765	1.2254	1.4327	1.39	1.2536	1.2803	1.1888
19	1.5729	1.5546	1.7193	1.6827	1.4175		1.5203
20	1.7375	1.829	1.8473	1.829	1.7375	1.6827	1.8461
21	1.7375	1.7741	1.7741	1.829	1.7556	1.6644	
22	1.7193	1.7558	1.7187	1.7558	1.7193	1.5912	1.829
23	1.7375	1.6827	1.6263	1.6278	1.6817	1.5364	1.7558
24		1.5364	1.4998	1.5708	1.4815	1.4969	1.39
Max	1.7375	1.829	1.8473	1.829	1.7556	1.6827	1.8461
Min	1.0679	1.1222	1.1706	1.134	1.1523	1.1827	1.0974
Avg	1.3202	1.3484	1.4085	1.3768	1.3580	1.3463	1.2899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 203 / 11KV MAHALAXMI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0745	1.1104	1.1104	1.0745	1.0387	1.0534	.9492
2		1.0745	1.0566	.8954	.9671	1.0082	.9313
3	.985	1.0208	1.0208	.8417	.9671	1.0082	.8954
4	.9313	.9492	1.0029	.8954	.9671	1.0082	.8775
5	1.0185	.9313	1.0029	.9671	.9313	.9896	.8596
6	1.0185	.9313	1.0029	1.0208	.985	.9709	.8238
7	.9431	.9134	.9671	1.0374	.8954	.924	.8596
8	.8775	.9313	.9313	.9134	.905	.9328	.8417
9	.9313	.9492	.9313	.8954	.9593	.9511	.8775
10	.9412	.9134	.9568	.9313	.9313	.9593	.8417
11	.8417	.9313	.9036	.8954	.8238	.9134	.7701
12	.8688	.9134	.8505	.8417		.9492	.8238
13	.8869	.8775	.9391	.9134	.8417	.9313	.8238
14	.9412	.9313	.9808	.8954	.9492	.9671	.8775
15	.9694	.9313	.9391	.9492	.9492	.9671	.8954
16	.9412	.9313	.9214	.9671	.9313	.9671	.9134
17	.9214	.9134		.9134	.9671		.9313
18	.8954	.9671	1.0387	.9671	.9391	1.0029	.8954
19	1.2894	1.3073	1.379	1.3256	1.1163		1.1283
20	1.4506	1.4685	1.4506	1.4327	1.4506	1.5939	1.5043
21	1.4327	1.4327	1.379	1.3969	1.4118	1.3432	
22	1.4506	1.4506	1.3969	1.3969	1.3756	1.3432	1.7193
23	1.3611	1.379	1.2536	1.2536	1.3491	1.1641	1.4327
24	1.1641	1.182	1.2178	1.1462	1.1283	1.1493	1.0387
Max	1.4506	1.4685	1.4506	1.4327	1.4506	1.5939	1.7193
Min	.8417	.8775	.8505	.8417	.8238	.9134	.7701
Avg	1.0494	1.0559	1.0710	1.0320	1.0339	1.0499	.9788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 205 / PUIKHADI WATER WORKS NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0189	1.0363	.9968	.9717	1.0193	.9831	1.029
2	.5247	.9954	.8149	.9465	1.0212	.9858	1.0294
3	1.0132	.9363	.9123	1.0113	1.022	.9869	1.0132
4	1.0128	.8463	.9905	.9305	1.06	1.0076	1.0325
5	1.0109	.9724	1.0367	1.0452	1.0589	1.0296	1.0321
6	.9107	1.1218	1.0721	1.1598	.9583	.8876	.993
7	.8692	1.0447	1.0447	1.1267	1.1606	1.1236	1.0684
8	.921	1.1643	1.0017	1.0585	1.0928	1.0943	1.1637
9	.8162	1.0905	.8623	1.0688	.9976	.5384	1.0478
10	.9166	.9275	.8009	1.012	.9693	.9999	1.0437
11	1.0439	.8555	.9583	1.0601	1.0509	1.0696	.2934
12	1.0328	1.0627	.9237	.8997	.4828	.9477	.0484
13	1.0063	1.0665	.9214	.8444	.807	.8448	.0335
14	.8842	1.0612	.8889	1.0502	1.0231	.8779	.0343
15	.8155	.9492	.7419	1.0498	1.0048	.9663	
16	1.0101	.8482	.7765	.8101	.8753	1.0059	.0335
17	.9722	.8742	.6211	.7808	.7887	.7377	.0377
18	1.029	1.1033	1.1419	1.0734	1.0344	.9541	.0377
19	1.0287	1.0264	.9671	1.0417	1.0363	.4965	.0392
20	.9577	.8414	.8482	.8642	1.0469	1.012	.0735
21	.8141	.8322	1.0071	1.0021	1.0424	1.0374	.0084
22	1.0555	1.034	1.0619	1.0582	1.0397	.8626	.0377
23	1.0673	1.037	1.0254	.862	.8528	.7685	.0189
24	1.0227	1.0283	1.017	.9248	.8505	.9477	.5281
Max	1.0673	1.1643	1.1419	1.1598	1.1606	1.1236	1.1637
Min	.5247	.8322	.6211	.7808	.4828	.4965	.0084
Avg	.9481	.9898	.9347	.9855	.9707	.9236	.5077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 206 / K N Patil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.051	1.0936	1.1512	.9717	.9586	.9907	.8306
2	.5335	1.0563	1.075	.8763	.8638	.9144	.4945
3	.4572	.9613	1.075	.8382	.8268	.9144	.8306
4	.9562	.9613	.98	.8382	.8268	.8954	.7544
5	.9747	.98	.98	.8954	.8268	.9144	.868
6	1.051	.98	1.0563	.9144	.9586	.9335	.8866
7	1.1064	1.0936	1.1123	1.0239	1.7717	1.005	.9053
8	.5335	1.0936	1.0936	.9862	.977	.9629	1.0003
9	.9377	1.0563	1.0376	1.0003	.9725	.9586	.9443
10	.9747	.9693	1.0376	.9629	.9816	.977	.9256
11	.9192	.8779	1.0376	.868	.9629	.8962	.9053
12	.9377	.9459	.9613	.8866	.4572	.9097	.8866
13	.924	.9278	.9426	.868	.8866	.9542	1.6708
14	.98	.951	.9613	.8866	.868	.9097	.8291
15	.9853	.951	.98	.9053	.924	.986	.8866
16	1.075	.951	1.0563	.868	.9053	.986	.5506
17	.9426	.9278	.7853	.868	.8866	.9725	.7685
18	.9327	.9426	.9679	.9613	.887	.8866	1.0624
19	1.2057	1.1294	1.1641	1.1885	.9327	.4572	1.2258
20	1.4327	1.5089	1.302	1.3207	1.2958	.823	1.5851
21	1.4141	1.4903	1.2834	1.3596	1.2834	1.4171	.8383
22	1.3954	1.3954	1.2895	1.2834	1.2706	1.246	1.4411
23	1.3767	1.3767	1.2517	1.2274	1.1755	1.19	1.4223
24	1.2647	1.2647	1.2258	1.086	1.0765	1.0239	1.0967
Max	1.4327	1.5089	1.302	1.3596	1.7717	1.4171	1.6708
Min	.4572	.8779	.7853	.8382	.4572	.4572	.4945
Avg	1.0151	1.0786	1.0753	.9952	.9907	.9635	.9837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 211 / 11 KV Incomer no. - I - NON SHEDDABLE WATER SUPPLY AND
Puikha Feeder KV- 11 / INCOMING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4829	2.6406	2.4737	2.46	2.1856	2.1651	2.037
2	2.0325	2.3457	2.0439	2.268	1.9799	1.9845	1.8381
3	1.8861	2.2382	1.9616	2.1674	1.8839	1.8861	1.7467
4	2.005	2.2039	1.8816	2.1171	1.8404	1.8381	1.6918
5	2.005	2.1605	1.8427	2.1011	1.8176	1.8107	1.669
6	2.0393	2.1856	1.9433	2.1559	1.8473	1.8084	1.7032
7	2.1674	2.2108	2.2016	2.2016	1.8839	1.8633	1.7238
8	2.2519	2.3343	2.3548	2.2177	1.8953	1.8381	1.797
9	2.2428	2.3114	2.4211	2.2451	1.8679	1.8038	1.8701
10	2.2039	2.2931	2.4326	2.1514	1.8313	1.8084	1.7444
11	2.1468	2.1468	2.364	1.7673	1.8381	1.7924	1.7078
12	2.0279	2.0645	1.7787	1.7535	1.813	1.8084	1.7535
13	2.0142	1.7856	1.7856	1.797	1.7924	1.893	1.7467
14	2.021	1.7718	2.021	1.8084	1.7513	1.877	1.6735
15	2.0759	2.1216	1.9319	1.8724	1.8656	1.9182	1.7764
16	2.1811	2.2359	1.9913	1.9159	1.9273	1.989	1.8221
17	2.2405	2.268	1.9913	1.8976	1.9387	1.9502	1.6278
18	2.2771	2.364	2.1559	1.8473	1.9273	1.9273	1.909
19	2.2748	2.3045	2.5194	2.1605	1.8587	1.9593	1.8861
20	2.8829	2.9424	2.8715	2.652	2.0599	.0732	2.652
21	2.963	3.0133	2.9218	2.6978	2.668	2.5743	2.7641
22	2.9401	2.9767	2.8395	2.6406	2.6017	2.4897	2.7275
23	2.9264	2.6658	2.7869	2.636	2.5172	2.3411	2.684
24	2.9035	2.5423	2.7458	2.4097	2.4257	2.2977	2.6086
Max	2.963	3.0133	2.9218	2.6978	2.668	2.5743	2.7641
Min	1.8861	1.7718	1.7787	1.7535	1.7513	.0732	1.6278
Avg	2.2997	2.3386	2.2609	2.1642	2.0008	1.9041	1.9650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 212 / 11KV Incomer no. - II- NON SHEDDABLE WATER SUPPLY AND
Puikhad Feeder KV- 11 / INCOMING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.0576	2.0576	2.0576	1.6004
2	1.829	1.829	1.829	1.829	1.6004
3	1.829	1.829	1.829	1.829	1.6004
4	1.829	1.829	1.829	1.829	1.6004
5	1.829	1.829	1.829	1.829	1.6004
6	1.829	2.0576	2.0576	2.0576	1.6004
7	1.829	2.0576	2.0576	2.0576	1.6004
8	1.6004	1.829	1.829	2.0576	1.6004
9	1.6004	2.0576	1.829	1.829	1.6004
10	1.6004	1.829	1.6004	1.829	1.6004
11	1.6004	1.6004	1.829	1.829	1.6004
12	1.3717	1.829	1.829	1.829	1.3717
13	1.3717	1.829	1.829	1.829	1.3717
14	1.6004	1.829	1.829	1.829	1.3717
15	1.6004	1.829	1.829	1.829	1.3717
16	1.829	1.829	1.829	1.829	1.3717
17	1.829	1.829	.4572		1.3717
18	1.829	1.829	2.0576		1.6004
19	2.0576	2.0576	2.2862		1.6004
20	2.5149	2.5149	2.5149		2.2862
21	2.5149	2.5149	2.5149		2.2862
22	2.5149	2.5149	2.5149		.6859
23	2.5149	2.5149	2.5149		2.0576
24	2.2862	2.2862	2.2862		1.829
Max	2.5149	2.5149	2.5149	2.0576	2.2862
Min	1.3717	1.6004	.4572	1.829	.6859
Avg	1.8862	2.0005	1.9528	1.8862	1.5908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 403 / 33 KV T/F I/C PUIKHADI I NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.5149	2.2862	2.2862	2.0576	2.0576	1.829
2	1.829	2.2862	2.0576	2.0576	1.829	1.829	1.6004
3	1.829	2.0576	1.829	2.0576	1.829	1.829	1.6004
4	2.0576	2.0576	1.829	2.0576	1.829	1.829	1.6004
5	1.829	2.0576	1.829	2.0576	1.829	1.6004	1.6004
6	2.0576	2.0576	2.0576	2.0576	1.829	1.829	1.6004
7	2.0576	2.0576	2.0576	2.0576	1.829	1.829	1.6004
8	2.0576	2.2862	2.2862	2.0576	1.829	1.829	1.829
9	2.0576	2.0576	2.2862	2.0576	1.829	1.6004	1.829
10	2.0576	2.2862	2.2862	1.829	1.829	1.829	1.6004
11	2.0576	2.0576	2.2862	1.6004	1.829	1.6004	1.6004
12	1.829	2.0576	1.829	1.6004	1.829	1.829	1.6004
13	1.829	1.6004	1.829	1.829	1.6004	1.829	1.6004
14	1.829	1.829	1.829	1.6004	1.6004	1.829	1.6004
15	2.0576	2.0576	1.829	1.829	1.829	1.829	1.6004
16	2.0576	2.2862	1.829	1.829	1.829	1.829	1.829
17	2.0576	2.2862	1.3717	1.829	1.829	1.829	1.3717
18	2.0576	2.2862	2.2862	1.829	1.829	1.829	1.829
19	2.0576	2.2862	2.5149	2.0576	1.829	1.6004	1.829
20	2.7435	2.9721	2.7435	2.5149	2.0576		2.5149
21	2.7435	2.9721	2.7435	2.5149	2.5149	2.2862	2.7435
22	2.7435	2.7435	2.7435	2.5149	2.5149	2.2862	2.5149
23	2.7435	2.5149	2.7435	2.5149	2.2862	2.2862	2.5149
24	2.7435	2.5149	2.7435	2.2862	2.2862	2.0576	2.5149
Max	2.7435	2.9721	2.7435	2.5149	2.5149	2.2862	2.7435
Min	1.829	1.6004	1.3717	1.6004	1.6004	1.6004	1.3717
Avg	2.1529	2.2577	2.1719	2.0386	1.9243	1.8688	1.8481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 404 / 33KV T/F I/C PUIKHADI II NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.0576	2.0576	2.0576	1.829	1.829	1.829
2	2.0576	2.0576	2.0576	2.0576	1.829	1.829	1.6004
3	1.829	2.0576	1.829	1.829	1.829	1.829	1.6004
4	1.829	1.829	1.829	1.829	1.829	1.829	1.6004
5	1.829	1.829	1.829	1.829	1.829	1.829	1.6004
6	1.829	2.0576	2.0576	2.0576	2.0576	1.829	1.6004
7	1.829	2.0576	2.0576	2.0576	2.0576	1.829	1.6004
8	1.829	2.0576	2.0576	2.0576	2.0576	2.0576	1.6004
9	1.6004	2.0576	1.829	1.829	1.829	1.829	1.6004
10	1.6004	2.0576	1.829	2.0576	1.829	1.829	1.6004
11	1.829	1.829	1.829	1.829	1.829	1.829	1.6004
12	1.3717	1.829	1.829	1.829	1.829	2.0576	1.3717
13	1.3717	1.829	1.829	1.829	1.829	1.829	1.3717
14	1.6004	1.829	1.829	1.829	1.829	1.829	1.3717
15	1.6004	1.829	1.829	1.829	2.0576	2.0576	1.6004
16	1.829	1.829	1.829	1.829	1.829	2.0576	1.3717
17	1.829	1.829	.9145	1.829	1.829	1.829	1.6004
18	1.829	2.0576	2.0576	1.6004	1.829	2.0576	1.6004
19	1.829	2.0576	2.2862	2.2862	1.829	1.829	1.6004
20	2.5149	2.5149	2.5149	2.5149	2.5149	.4572	2.2862
21	2.5149	2.5149	2.5149	2.5149	2.5149	2.0576	2.2862
22	2.5149	2.5149	2.5149	2.5149	2.5149	2.0576	.6859
23	2.5149	2.5149	2.5149	2.5149	2.2862	2.0576	2.2862
24	2.5149	2.5149	2.2862	2.0576	2.0576	1.829	2.0576
Max	2.5149	2.5149	2.5149	2.5149	2.5149	2.0576	2.2862
Min	1.3717	1.829	.9145	1.6004	1.829	.4572	.6859
Avg	1.9147	2.0671	2.0005	2.0195	1.9814	1.8480	1.6385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 201 / 11 KV MASKUTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5363	1.5538	1.5356	1.4525	1.4113	1.4769	1.3374
2	1.3962	1.4022	1.4245	1.3561	1.3322	1.384	1.2491
3	1.2669	1.3017	1.3794	1.3439	1.2803	1.3138	1.1812
4	1.2422	1.2574	1.3336	1.3294	1.2636	1.3016	1.166
5	1.3024	1.2879	1.334	1.3603	1.2849	1.3279	1.2079
6	1.3047	1.2834	1.3273	1.4495	1.3319	1.3604	1.2308
7	1.2605	1.1896	.6516	1.2963	1.2094	1.2233	1.1942
8	1.1995	1.2331	1.3043	1.3359	1.1717	1.1803	1.1919
9	1.2438	1.3367	1.3588	1.3755	1.2552	1.2235	1.2414
10	1.3032	1.3367	1.3565	1.3813	1.3229	1.2636	1.3687
11	1.3116	1.3245	1.355	1.3851	1.2857	1.3043	1.2491
12	1.3003	1.4133	1.4395	1.4226	1.3466	1.2932	.6805
13	1.3299	1.4133	1.4068	1.4217	1.345	1.0109	
14	1.3374	1.4281	1.3969	1.4072	1.3375	1.5669	.2401
15	1.3153	1.3809	1.3824	1.4026	1.3824	1.4685	1.608
16	1.3543	1.4095	1.4514	1.3278	1.4103	1.4228	.7834
17	1.1841	.7415	.7354	1.3786	.692	1.4937	.4451
18	1.3306	1.393	.2652	1.483	1.2853	1.4735	.5517
19	1.541	1.7457	.5022	1.701	1.5615	.7758	.6655
20	1.9875	2.1285	.6531	.9412	1.9951	.0008	.4108
21	1.9955	2.0489	1.736	1.9997	1.9464	2.1064	1.1782
22	1.9776	1.9791	1.6362	2.0378	1.8858	1.97	2.1491
23	1.9492	1.8069	1.8717	1.8412	1.8351	1.7124	1.9498
24	1.7101	1.7093	1.7008	.8726	1.6324	1.5756	1.563
Max	1.9955	2.1285	1.8717	2.0378	1.9951	2.1064	2.1491
Min	1.1841	.7415	.2652	.8726	.692	.0008	.2401
Avg	1.4450	1.4627	1.2724	1.4293	1.4085	1.3429	1.1236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 202 / 11KV GANGAVES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5217	.4674	.534	.4946	.4742	.4846	.4679
2	.4709	.4287	.4907	.4359	.4317	.4466	.4534
3	.4226	.4038	.4582	.429	.4045	.4314	.4058
4	.4149	.3977	.4317	.4245	.4038	.4321	.4058
5	.4496	.3977	.4514	.4611	.403	.4306	.4435
6	.4603	.4039	.4702	.5037	.4022	.4641	.4473
7	.4465	.3961	.2385	.4557	.3794	.4359	.4267
8	.5095	.4264	.4626	.5057	.418	.4337	.429
9	.5148	.4809	.517	.5586	.4809	.4837	.4481
10	.583	.7925	.6816	.7171	.7262	.6398	.6592
11	.652	.8977	.8524	.9276	.9915	.8273	.6306
12	.7701	.9214	.8953	.869	1.0128	.8536	.6724
13	.7636	.9351	.8886	.9236	.9518	.913	.6569
14	.7396	.9968	.8806	.9366	1.0036	.9366	.6569
15	.7046	.9708	.8867	.9145	.932	.9107	.6462
16	.7727	1.0143	.9479	.9482	1.0258	.8741	.3445
17	.7968	.5068	.5449	.9968	.5182	1.0151	.4016
18	.7826	1.012	.9225	1.0676	.9937	.9903	.7583
19	.9587	1.2123	1.0818	1.0984	1.0212	.49	.9152
20	1.0361	1.1771	1.0311	1.0596	1.0269	.9137	.4908
21	.9145	.9715	.9446	.9632	.8815	.8086	.4641
22	.6958	.7507	.6889	.679	.6744	.6432	.6998
23	.5769	.6211	.6081	.5811	.588	.2881	.6257
24	.5929	.5574	.5849	.5578	.5376	.5202	.5209
Max	1.0361	1.2123	1.0818	1.0984	1.0269	1.0151	.9152
Min	.4149	.3961	.2385	.4245	.3794	.2881	.3445
Avg	.6479	.7142	.6873	.7295	.6951	.6528	.5446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 203 / 11KV MAHADWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5154	1.4632	1.4449	1.4118	1.4045	1.423	1.39
2	1.4045	1.3306	1.3676	1.3394	1.3169		1.3169
3	1.2936	1.2197	1.2936	1.267	1.2197	.9774	1.1706
4	1.2936	1.2323	1.2696	1.267	1.1949	.8688	1.1706
5	1.2936	1.2567	1.2696	1.3756	1.2197	1.307	1.2323
6	1.307	1.3306	1.2883	1.448	1.2696	1.2637	1.2449
7	1.3306	1.2437		1.4327	1.2936	1.2883	1.2567
8	1.4045	1.3535	1.4415	1.4842	1.3306	1.386	1.4045
9	1.4784	1.4632	1.5364	1.5927	1.4266	1.4815	1.4632
10	1.4998	1.5402	1.6832	1.5927	1.4998	1.6297	1.6095
11	1.5912	1.8823	1.7924	1.7918	1.9753	1.9547	1.4548
12	1.7194	1.8823	1.8461	1.9547	1.9547	1.8267	1.5592
13	1.6832	1.9022	1.829	1.957	1.9547	1.8823	1.6651
14	1.7013	1.9022	1.7924	1.8665	1.9022	1.7909	1.6461
15	1.6655	1.922	1.7737	1.848	1.8656	1.7193	1.6263
16	1.6297	1.922	1.7558	1.8839	1.9022	1.7741	
17	1.7013			1.9387		1.9387	
18	1.7375	1.9342	2.1033	2.0851	1.97	1.9753	1.8642
19	2.2923	2.4893	2.3838	2.2805	2.2744		2.3461
20	2.4356	2.6863	2.5941	2.4451	2.5789	2.3529	
21	2.2081	2.3529	2.524	2.2207	2.2744	2.3282	
22	1.9185	2.0271	2.1132	1.9547	1.9728	2.0633	2.2262
23	1.9022	1.8473	1.829	1.7924	1.7918	1.829	1.9753
24	1.5524	1.5729	1.6461	1.5729	1.4998	1.6078	1.4632
Max	2.4356	2.6863	2.5941	2.4451	2.5789	2.3529	2.3461
Min	1.2936	1.2197	1.2696	1.267	1.1949	.8688	1.1706
Avg	1.6483	1.7286	1.7535	1.7418	1.6997	1.6668	1.5543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 204 / MIRABAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1458	1.1088	1.1157	1.1088	1.1949	1.0534	.9979
2	1.0349	1.0349	1.0425	1.1088	.961	1.0164	.924
3	.961	.9709	1.0082	.9774	.8871	1.0082	.8871
4	.961	.9709	.9709	.9774	.8589	.9896	.924
5	.9979	.9979	.9709	1.0136	.8871	.9896	.924
6	.9979	1.0082	.9896	1.0498	.8962	1.0456	.9431
7	.9511	.9145		.9877	.8871	.9335	.961
8	.9412	.9511	1.0534	.9671	.8962	.9412	.9511
9	.9774	.9774	1.0974	1.0029	.924	.985	.961
10	1.0136	1.1104	1.0679	1.134	1.086	1.0566	1.0136
11	1.0498	1.134	1.0974	1.0099	1.086	1.1104	1.0059
12	1.1041	1.1462	1.1104	1.0631	.8954	1.1222	1.0136
13	1.0974	1.0745	1.2757	1.0387	.905	.2263	1.0029
14	1.1523	1.1706	1.1462	1.0791	1.1706	1.2936	.9877
15	1.1222	1.134	1.1584	1.0791	1.1706	1.3032	.9425
16	1.1523	1.1706	1.1584	1.1041	1.1827	1.2803	
17	1.1041			1.1222		1.267	
18	1.0631	1.1157	1.2742	.9816	1.0277		1.0679
19	1.3394	1.4327	1.4175	1.3112	1.1999		1.4148
20	1.5927	1.6108	1.4529	1.5592	1.5203	1.3169	
21	1.2071	1.5384	1.4529	1.3969	1.448	1.3169	
22	1.5364	1.4842	1.448	1.3032	1.448	1.3535	1.4299
23	1.386	1.3717	1.3169	1.307	1.3306	1.2894	1.4045
24	1.1827	1.2071	1.2071	1.1222	1.1088	1.1458	1.0349
Max	1.5927	1.6108	1.4529	1.5592	1.5203	1.3535	1.4299
Min	.9412	.9145	.9709	.9671	.8589	.2263	.8871
Avg	1.1280	1.1581	1.1742	1.1169	1.0857	1.0929	1.0396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 206 / 11 KV SAKOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.932	.876	.9619	.9419	.8745	.9334	.8802
2	.8314	.8177	.8831	.8669	.8078	.876	.788
3	.7609	.7659	.8368	.8425	.7788	.836	.7293
4	.7503	.7548	.8074	.8288	.738	.8151	.7126
5	.852	.7887	.8067	.8673	.7758	.8091	.7506
6	.8566	.7903	.8429	.9111	.8242	.8364	.7979
7	.884	.8528	.4603	.9548	.8547	.8475	.8718
8	.8955	.8696	.9366	1.0219	.8871	.9123	.8856
9	.8993	.9054	.9431	1.0296	.9473	.941	.9145
10	.9522	.9168	.9747	1.0097	1.0212	.937	.9404
11	.9221	.9968	.9914	1.0265	1.0517	.9633	.9549
12	.9023	1.0627	1.0675	1.0387	1.0071	1.0002	.9298
13	.9365	1.0749	1.0425	1.0267	1.0593	1.0662	.9206
14	.9372	1.0734	.9785	1.0294	1.0372	1.029	.8955
15	.9579	1.0609	.9812	1.0225	1.0258	1.0669	.9252
16	.9675	1.0616	1.0524	1.0273	.6553	1.041	.49
17	.9644	.5281	.3955	1.0463	.1326	1.0818	.4954
18	1.0025	1.0267	1.2917	1.0712	1.243	1.041	.9437
19	1.0803	1.1755	1.278	1.2186	1.1652	.5464	1.0913
20	1.2853	1.3687	1.3276	1.3222	1.3172	1.2677	.6211
21	1.2685	1.2546	1.2467	1.2624	1.206	1.2186	.6165
22	1.1477	1.1812	1.1645	1.1073	1.1056	1.1024	1.1264
23	1.1142	1.1749	1.1382	1.0913	1.1176	1.0677	1.1881
24	1.0536	1.0341	1.0546	1.067	1.009	1.021	1.0745
Max	1.2853	1.3687	1.3276	1.3222	1.3172	1.2677	1.1881
Min	.7503	.5281	.3955	.8288	.1326	.5464	.49
Avg	.9648	.9755	.9777	1.0263	.9434	.9690	.8560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 207 / SHUKRAWAR GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7842	.7762	.7762	.7095	.6908	.6653
2	.7468	.7392	.7392	.7392	.6653	.6722	.6283
3	.7095	.6722	.7468	.7023	.6348	.6535	.5914
4	.7095	.6722	.6908	.7023	.6283	.6535	.5914
5	.7468	.7023	.6908	.7392	.6722	.6722	.6653
6	.7468	.7095	.7095	.7392	.6653	.6908	.679
7	.7023	.6653		.7392	.7095	.6908	.7468
8	.7023	.7392	.7207	.7682	.7392	.7133	.7392
9	.7316	.7682	.7316	.8688	.7682	.724	.7392
10	.7316	.7602	.8145	.8688	.7682	.8048	.7316
11	.7133	.7964	.8048	.7421	.8326	.7964	.7762
12	.695	.7964	.8326	.7087	.8238	.8048	.7682
13	.724	.7964	.8048	.7164	.8326	.8238	.7602
14	.7421	.8048	.7964	.823	.8413	.8326	.7682
15	.7499	.8131	.8048	.8316	.8048	.8413	.7947
16	.7783	.8779	.8413	.8686	.8413	.8413	
17	.823			.8869		.8779	
18	.788	.823		.9816	.8328	.8859	.8326
19	.9412	1.0692	.5548	1.0277	.9745		1.0029
20	1.0745	1.1462	.7712	1.0692	1.1517	1.0498	
21	1.0136	1.0745		1.0387	1.0566	1.0029	
22	.9511	1.0317	.8596	.9877	1.0317	1.0631	1.0745
23	.9511	.9425	.9877	.9055	.9511		1.0242
24	.8501	.8501	.8686	.8871	.7392	.7947	.7392
Max	1.0745	1.1462	.9877	1.0692	1.1517	1.0631	1.0745
Min	.695	.6653	.5548	.7023	.6283	.6535	.5914
Avg	.7961	.8276	.7773	.8383	.8119	.7991	.7659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 208 / 11 KV LAXTIRTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.5853	.6584	.5792	.4805	.5601	.5601
2	.6154	.543	.6468	.543	.4481	.5415	.5228
3	.5792	.5121	.6283	.543	.4108	.5415	.4854
4	.5792	.5175	.6161	.543	.3772	.5228	.4854
5	.5792	.5487	.6161	.5792	.4108	.5228	.4854
6	.5853	.5914	.6348	.5792	.415	.5041	.4904
7	.5853	.5316		.5373	.3982	.4854	.4805
8	.5316	.5609	.5304	.5014	.394	.4706	.4805
9	.5258	.5895	.567	.4656	.4207	.4656	.4805
10	.5609	.5201	.5721	.4908	.4344	.4733	.439
11	.5548	.3121	.5609	.4508	.4706	.4161	.3429
12	.583	.3467	.6173	.463	.4344	.4458	.3856
13	.583	.3467	.6241	.4578	.4607	.4557	.394
14	.6274	.5895	.631	.5144	.5175	.5014	.4024
15	.6516	.6379	.6241	.4917	.5121	.5121	.4435
16	.6516	.6733	.6104	.5434	.5121	.5121	
17	.6104			.5609		.4961	
18	.5765	.6001	.6379	.5895	.4239	.4854	.4298
19	.6762	.7108	.6173	.631	.5784		.6805
20	.7442	.8505	.7545	.6661	.7522	.7888	
21	.7522	.7973	.7712	.6805	.7343	.695	
22	.7421	.7973	.7522	.6584	.7421	.7762	.7796
23	.7316	.7865	.7023	.6154	.7023	.6653	.7392
24	.724	.6401	.7133	.6154	.5359	.5975	.5975
Max	.7522	.8505	.7712	.6805	.7522	.7888	.7796
Min	.5258	.3121	.5304	.4508	.3772	.4161	.3429
Avg	.6251	.5908	.6403	.5542	.5029	.5407	.5053

From 01-MAY-17 and 07-MAY-17

Feeder No / Name :	211 / 11KV Incomer - I Dudhali	NON SHEDDABLE WATER SUPPLY AND
s/s Feeder KV- 11 / INCOMING		UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2769	3.3471	3.3471	3.2495	3.1337	3.1855	2.9355
2	2.9355	2.9965	3.0178	2.9508	2.8075	2.8258	2.6459
3	2.7831	2.8288	2.8685	2.8319	2.6795	2.6825	2.524
4	2.6795	2.7496	2.7374	2.7465	2.5667	2.5972	2.4478
5	2.6277	2.713	2.7008	2.6856	2.5423	2.5697	2.4143
6	2.6581	2.713	2.7374	2.7343	2.5484	2.6155	2.4661
7	2.7008	2.6612	2.7862	2.8075	2.5606	2.6886	2.521
8	2.46	2.5667	2.7221	2.6185	2.4722	2.5057	2.399
9	2.588	2.7069	2.7831	2.7801	2.5789	2.6337	2.5606
10	2.6703	2.8715	2.9294	2.8837	2.7953	2.8166	2.7221
11	2.8227	3.0575	3.0575	3.094	2.8776	3.0331	2.8258
12	2.8502	3.1489	3.2068	3.0453	2.8685	3.152	2.905
13	2.9416	3.2068	3.28	3.2038	3.0087	2.1399	2.2314
14	2.9935	3.2038	3.3227	3.1428	2.9569	2.8319	2.2222
15	2.9935	3.1763	3.2556	3.1489	3.1642	3.5086	3.091
16	3.0178	3.1946	3.3318	3.1794	3.2434	3.4385	3.0727
17	3.0575	3.2312	3.3501	3.1916	3.2495	3.408	3.0727
18	3.0727	3.2526	1.4297	3.283	3.3318	3.4537	2.6978
19	3.1733	3.283	2.0759	3.7982	3.2099	3.4598	2.7557
20	4.3134	4.5146	3.1581	4.225	4.2311	.9694	3.6062
21	4.4353	4.6213	3.4141	4.1975	4.4445	2.649	4.228
22	4.2798	4.3713	3.6336	4.225	4.164	3.9598	4.4018
23	4.0604	4.0482	3.85	3.8714	3.8866	3.3349	4.0939
24	3.783	3.7068	3.5178	3.5848	3.6519	3.3745	3.7982
Max	4.4353	4.6213	3.85	4.225	4.4445	3.9598	4.4018
Min	2.46	2.5667	1.4297	2.6185	2.4722	.9694	2.2222
Avg	3.1323	3.2571	3.0214	3.2283	3.1239	2.9097	2.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 212 / 11KV Incomer - II Dudhali NON SHEDDABLE WATER SUPPLY AND
s/s. Feeder KV- 11 / INCOMING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0148	3.0788	3.094	2.9203	2.8807	2.9203	2.7008
2	2.7039	2.7496	2.7465	2.6795	2.585	2.585	2.4387
3	2.5697	2.6307	2.6277	2.6002	2.4539	1.3321	2.2862
4	2.4874	2.5667	2.5027	2.5301	2.3624	2.0424	2.2192
5	2.4326	2.5088	2.4691	2.4661	2.3259	2.399	2.1826
6	2.4417	2.4844	2.5149	2.4996	2.3503	2.4417	2.2283
7	2.4417	2.4935	2.5423	2.5393	2.3624	2.399	2.2619
8	2.3899	2.4966	2.6216	2.4783	2.335	2.3503	2.2253
9	2.4569	2.5667	2.5667	2.6094	2.4508	2.4783	2.3137
10	2.5575	2.7252	2.7862	2.6703	2.6581	2.6185	2.524
11	2.774	2.9325	3.0239	2.7343	2.7618	2.6825	2.6185
12	2.8197	2.8045	3.1855	3.0148	3.0239	2.9172	2.6856
13	2.9782	2.8868	3.2617	3.1337	3.03	3.1855	2.8227
14	3.0239	3.1733	3.2343	3.155	3.0422	3.1916	2.841
15	3.027	3.1733	3.2099	3.0666	2.9782	3.1885	2.7679
16	3.0148	3.1946	3.28	3.0697	3.0239	3.1946	2.7648
17	2.9904	3.219	3.2769	3.1062	2.7221	3.0971	2.8227
18	3.0971	3.2556	1.7558	3.1489	2.9325	3.1306	2.8746
19	3.2251	3.3105	3.847	3.5696	3.3379	3.2404	2.9782
20	4.2097	4.3743	4.1732	4.2311	4.0543	1.2955	4.0177
21	4.3317	4.5146	4.353	4.3347	4.2951	3.6793	3.6214
22	4.0847	4.1701	4.0543	3.9994	3.9567	3.7525	4.0268
23	3.6946	3.6702	3.5787	3.5879	3.5543	3.3989	3.8165
24	3.5147	3.4476	3.3135	3.2922	3.2739	3.094	3.5056
Max	4.3317	4.5146	4.353	4.3347	4.2951	3.7525	4.0268
Min	2.3899	2.4844	1.7558	2.4661	2.3259	1.2955	2.1826
Avg	3.0117	3.1012	3.0841	3.0599	2.9480	2.7756	2.8144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 413 / 33 KV Incomer No. II
Dudhali s Feeder KV- 33 /
INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	18.9987	19.2044	19.4788	19.2044	17.5583	17.7641	16.7353
2	17.0782	17.284	17.1468	17.6269	15.7751	15.7751	15.0892
3	16.2552	16.4609	16.3238	17.0782	14.952	12.0713	14.3347
4	15.6379	16.0494	15.5007	16.5981	14.3347	13.5117	13.9232
5	15.2949	15.7751	15.2949	16.1866	14.1976	14.7462	13.7174
6	15.5007	15.7751	15.5693	16.5295	14.2661	15.0892	14.0604
7	15.5007	15.5693	15.7751	16.8039	14.2661	15.1578	14.2661
8	14.5405	15.1578	15.6379	15.9122	14.129	14.6777	13.786
9	15.0206	16.2552	16.6667	16.5981	14.952	15.4321	14.5405
10	15.7065	17.1468	17.8327	17.1468	16.5295	16.3238	15.7751
11	16.8039	18.5185	18.9987	18.107	17.1468	17.0096	16.5295
12	17.0782	18.3814	19.8217	18.5185	18.1756	18.9301	17.284
13	17.9698	18.7243	20.3018	19.6159	18.5185	16.3238	15.5693
14	18.1756	18.9301	20.3018	19.2044	18.3128	18.5871	15.4321
15	18.1756	18.5871	20.096	19.2044	18.7243	20.439	17.7641
16	18.1756	18.7929	20.6447	19.273	18.1756	20.3018	17.7641
17	18.2442	19.6845	20.7133	19.3416	18.107	19.8217	17.8327
18	18.1756	19.8217	8.0933	19.273	18.7929	19.6159	16.4609
19	18.6557	19.8217	18.45	21.8793	19.2044	19.5474	16.6667
20	24.8286	26.2003	23.1139	25.2401	24.4856	4.6639	22.4966
21	25.3773	26.8176	24.417	24.8972	25.6516	18.7243	20.5762
22	24.0741	24.8286	23.9369	24.0741	23.7998	22.771	24.2113
23	22.9767	23.0453	22.9081	22.0165	21.8107	19.6845	22.9767
24	21.9479	21.8107	20.7133	20.3018	20.3704	19.2044	21.3306
Max	25.3773	26.8176	24.417	25.2401	25.6516	22.771	24.2113
Min	14.5405	15.1578	8.0933	15.9122	14.129	4.6639	13.7174
Avg	18.3414	19.1101	18.6557	19.1930	18.0099	16.9239	17.0468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 146017 / 110/33KV CHAMBUKHADI

Feeder No / Name : 401 / 33KV DUDHALI

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	18.8615	19.0672	19.3416	19.0672	17.4211	17.5583	16.5295
2	16.941	17.1468	17.0782	17.4897	15.7065	15.6379	14.952
3	16.0494	16.2552	16.118	16.8725	15.0892	12.0028	14.1976
4	15.4321	15.8436	15.3635	16.3923	14.2661	13.5117	13.786
5	15.1578	15.5693	15.2264	16.0494	14.0604	14.5405	13.5803
6	15.3635	15.5693	15.3635	16.3238	14.1976	15.0206	13.8546
7	15.3635	15.4321	15.6379	16.5981	14.1976	15.0892	14.129
8	14.6777	15.0892	15.5693	15.7065	13.9918	14.7462	13.6489
9	14.8834	16.0494	16.5295	16.4609	14.952	15.2949	14.6777
10	15.5693	17.0782	17.6269	17.0096	16.3923	16.1866	15.7065
11	16.6667	18.3128	18.7929	17.9013	17.0096	16.8725	16.3923
12	16.941	18.2442	19.6159	18.3128	17.9698	18.7243	17.0782
13	17.8327	18.5871	20.096	19.4788	18.3128	16.2552	15.4321
14	18.0384	18.6557	20.1646	19.0672	18.107	18.45	15.2949
15	18.0384	18.3814	19.9589	19.0672	18.5871	20.3018	17.6269
16	18.0384	18.6557	20.5076	19.1358	18.0384	20.1646	17.6269
17	18.107	19.5474	20.5076	19.2044	17.9698	19.6845	17.6955
18	18.0384	19.6159	8.0933	19.1358	18.5871	19.4102	16.3923
19	18.5185	19.6845	18.2442	21.605	19.0672	19.4102	16.4609
20	24.6914	25.9945	22.771	25.0343	24.2799	4.8011	22.2223
21	25.1715	26.6804	24.0741	24.6914	25.4459	18.5185	20.439
22	23.8683	24.6914	23.6626	23.8683	23.594	22.5652	23.9369
23	22.7024	22.8395	22.7024	21.8107	21.605	19.4102	22.8395
24	21.7529	21.605	20.5076	20.1646	20.1646	18.9987	21.1249
Max	25.1715	26.6804	24.0741	25.0343	25.4459	22.5652	23.9369
Min	14.6777	15.0892	8.0933	15.7065	13.9918	4.8011	13.5803
Avg	18.1961	18.9415	18.4814	19.0187	17.8755	16.7982	16.9010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 146017 / 110/33KV CHAMBUKHADI

Feeder No / Name : 402 / 33 KV BALINGA

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3608	3.3608	3.3608	3.3608	3.4294	3.3608	3.3608
2	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608
3	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608
4	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608
5	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608
6	3.3608	3.3608	3.3608	3.3608	3.3608	3.4294	3.3608
7	3.4294	3.4294	3.4294	3.3608	3.3608	3.4294	3.3608
8	3.4294	3.4294	3.4294	3.3608	3.3608	3.2922	3.3608
9	3.4294	3.4294	3.4294	3.4294	3.2922	3.3608	3.3608
10	3.4294	3.4294	3.4294	3.4294	3.2922	3.3608	3.4294
11	3.4294	3.4294	3.4294	3.3608	3.3608	3.4294	3.4294
12	3.4294	3.3608	3.4294	3.3608	3.4294	3.4294	3.4294
13	3.4294	3.3608	3.4294	3.3608	3.3608	3.4294	3.3608
14	3.4294	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608
15	3.3608	3.3608	3.4294	3.4294	3.3608	3.3608	3.3608
16	3.4294	3.3608	3.4294	3.4294	3.3608	3.3608	3.3608
17	3.4294	3.4294	3.3608	3.3608	3.3608	3.3608	3.4294
18	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608	3.3608
19	3.4294	3.3608	3.3608	3.3608	3.4294	3.4294	3.3608
20	3.3608	3.3608	10.0137	3.0178	3.4294	3.4979	3.3608
21	3.4294	3.3608	3.3608	3.4979	3.4294	3.3608	3.3608
22	3.4294	3.3608	3.3608	3.4979	3.3608	3.3608	3.3608
23	3.3608	3.3608	3.3608	3.4294	3.3608	3.3608	3.3608
24	3.3608	3.4294	3.4294	3.4294	3.3608	3.3608	3.4294
Max	3.4294	3.4294	10.0137	3.4979	3.4294	3.4979	3.4294
Min	3.3608	3.3608	3.3608	3.0178	3.2922	3.2922	3.3608
Avg	3.3980	3.3808	3.6666	3.3751	3.3694	3.3808	3.3751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 146017 / 110/33KV CHAMBUKHADI

Feeder No / Name : 404 / 33KV SHINGNAPUR W/W NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.9383	4.8697	4.8011	4.8697	4.7325	4.8011	4.8011
2	4.9383	4.8697	4.7325	4.8011	4.7325	4.8697	4.8697
3	4.9383	4.8697	4.8011	4.8011	4.7325	4.8697	4.8697
4	4.9383	4.8697	4.8697	4.8011	4.7325	4.8697	4.8697
5	4.8697	4.8011	4.8697	4.8011	4.7325	4.8697	4.8697
6	5.0755	5.0069	4.8697	4.9383	4.9383	5.0755	5.0755
7	5.144	5.144	5.0069	5.0069	4.9383	5.144	5.0755
8	5.0069	5.0755	5.0755	5.0069	5.0069	5.144	5.0755
9	4.1838	5.144	5.2126	5.0755	5.0069	5.0755	5.0755
10	5.144	5.2126	5.2126	5.144	5.144	5.144	5.144
11	5.144	5.2126	5.2126	5.144	5.2126	5.2126	5.144
12	5.2126	3.7037	5.2126	5.144	5.144	5.2812	1.3717
13	5.2126	3.7037	5.2126	5.144	5.0755	5.144	3.2236
14	5.144	3.5665	5.0755	5.0755	5.0069	5.0755	2.9492
15	5.144	3.9781	5.144	5.144	5.0755	5.0755	1.3717
16	5.144	5.0069	5.144	5.144	5.0755	5.0755	2.6063
17	5.144	4.9383	4.1152	5.0755	5.0755	5.0755	3.2236
18	4.9383	4.1152	3.4294	4.2524	4.2524	4.0466	1.6461
19	4.1838	4.8697	4.8697	4.9383	4.8697	4.5953	1.3717
20	4.9383	4.9383	4.5268	4.8697	4.9383	2.8121	1.4403
21	4.9383	4.9383	4.8697	4.8697	4.9383	3.9781	3.0864
22	5.0069	5.0069	4.9383	4.9383	4.8697	5.0069	1.5089
23	5.0069	5.0069	4.9383	4.8697	4.8011	4.9383	1.3717
24	4.9383	5.0069	4.9383	4.8011	4.8011	4.8011	1.9204
Max	5.2126	5.2126	5.2126	5.144	5.2126	5.2812	5.144
Min	4.1838	3.5665	3.4294	4.2524	4.2524	2.8121	1.3717
Avg	4.9697	4.7440	4.8783	4.9440	4.9097	4.8325	3.4151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 205 / Nagaon Jackwell

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3353	.3658	.3506	.3506	.3353	.3506
4	.3353	.3658	.3506	.3506	.3353	.3353
5	.3353	.3658	.3506	.3506	.3353	.3506
6	.3506	.3506	.3506	.3506	.3506	.3506
7	.3506	.3658	.3506	.3506	.3506	.3506
8	.3353	.3353	.3506	.3506	.3506	.3506
9	.3506	.3506	.3658	.3506	.3506	.3506
10	.3506	.3506	.3506	.3353	.3506	.3506
11	.3506	.3506	.3353	.3353	.3353	.3506
12	.3506	.3506	.3506	.3353	.3353	.3353
13	.3353	.3353	.3353	.3353	.3201	.3353
14	.3353	.3506	.3353	.3353	.3201	.3201
15	.3353	.3353	.3353	.3353	.3201	.3353
16	.3506	.3506	.3353	.3353	.3201	.3353
17	.3506	.3353	.3506	.3353	.3353	.3353
18	.3353		.3353	.3353	.3353	.3201
Max	.3506	.3658	.3658	.3506	.3506	.3506
Min	.3353	.3353	.3353	.3353	.3201	.3201
Avg	.3430	.3506	.3458	.3420	.3363	.3411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144030 / 33/11KV GPI S/STN

Feeder No / Name : 201 / 11KV TRYAMBOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.5975	.5975	.5975	.4805	.4805	.5228
2	.5175	.5544	.5914	.5975	.4755	.4854	.5228
3	.5121	.5544	.5914	.5975	.4755	.4854	.5228
4	.5175	.5544	.5853	.5975	.4805	.4755	.5228
5	.5914	.5975	.5853	.5975	.4755		.5228
6	.6722	.6722	.5175	.5975	.5121		.5975
7	.5228	.5228	.4481	.5175	.439		.5281
8	.5175	.5175	.4481	.5228	.4481		.5068
9	.4435	.5121	.4435	.5121	.439		.5228
10	.4435	.439	.439	.5121	.5041	.3658	.4435
11	.4435	.439	.439	.4344	.4435	.439	.439
12	.4435	.4435	.439	.4344	.439	.439	.439
13	.4435	.439	.5121	.439	.439	.439	.5121
14	.4481	.4435	.7392	.4435	.4435	.439	.439
15	.439	.4481	.5228	.4481	.4435	.439	.5228
16	.4481	.4435		.4481	.4755	.4706	.5228
17	.4435	.439		.439	.439	.5121	.5175
18	.5121	.4298	.6379	.567		.5068	.5121
19	.6447	.567	.7087	.631	.4908		.6447
20	.7164	.6447	.788	.6447	.6653	.724	.7964
21	.7964	.6584	.7964	.724	.6584	.5792	.7964
22	.8131	.6653	.7316	.6584	.6584	.7316	
23	.7392	.6653	.7545	.5914	.5914	.5914	.7392
24	.6722	.5975	.5914	.5975	.5228	.5121	.5914
Max	.8131	.6722	.7964	.724	.6653	.7316	.7964
Min	.439	.4298	.439	.4344	.439	.3658	.439
Avg	.5525	.5352	.5867	.5479	.4974	.5064	.5515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144030 / 33/11KV GPI S/STN

Feeder No / Name : 211 / 11KV I/C I

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.4845	1.4601	1.3672	1.4022	1.3443	1.1401
2	1.2711	1.3596	1.3565	1.2955	1.3093	1.2788	1.1035
3	1.23	1.3214	1.323	1.2666	1.2772	1.2391	1.0913
4	1.201	1.3047	1.2925	1.2529	1.2635	1.2132	1.0715
5	1.2178	1.3154	1.2955	1.259	1.2772	1.2269	1.0791
6	1.323	1.4297	1.4464	1.3443	1.422	1.3489	1.166
7	1.4175	1.4739	1.4556	1.4129	1.483	1.3855	1.2346
8	1.3535	1.387	1.4525	1.3596	1.4358	1.3458	1.1065
9	1.323	1.355	1.4007	1.3108	1.3885	1.3306	1.3626
10	1.3108	1.2925	1.2925	1.3032	1.4373	1.2437	1.2376
11	1.2361	1.2574	1.2681	1.291	1.3748	1.2818	1.1843
12	1.1995	1.2529	1.2513	1.2437	1.3336	1.2209	1.2544
13	1.2071	1.2574	1.2711	1.2163	1.1706	1.2254	1.2376
14	1.2163	1.2269	1.2894	1.2742	1.2346	1.2209	1.2529
15	1.2422	1.2468	1.3397	1.2483	1.2483	1.3733	1.2087
16	1.1934	1.2529	1.3443	1.2437	1.259	1.358	1.2193
17	1.2605	1.2376	.6203	1.2376	1.2468	1.2452	1.2452
18	1.3108	1.2071	1.4922	1.2925	1.291	1.3733	1.2651
19	1.2635	1.2605	1.6476	1.0745	.6889	1.3413	1.2376
20	1.6796	1.7177	1.7558	1.7071	1.5394	.3658	1.6872
21	1.7421	1.7833	1.7833	1.8016	1.7726	.8383	1.7802
22	1.768	1.7802	1.7497	1.8077	1.7025	1.4175	1.7528
23	1.7909	1.7833	1.7223	1.7635	1.6796	1.448	1.7345
24	1.7269	1.6949	1.5729	1.6065	1.5364	1.2666	1.6095
Max	1.7909	1.7833	1.7833	1.8077	1.7726	1.448	1.7802
Min	1.1934	1.2071	.6203	1.0745	.6889	.3658	1.0715
Avg	1.3722	1.4034	1.4118	1.3742	1.3656	1.2472	1.3026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144030 / 33/11KV GPI S/STN

Feeder No / Name : 411 / 33KV I/C-1

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7193	1.9547	2.0005	1.8861	1.7718	1.8861	1.7718
2	1.6478	1.773	2.0005	1.8861	1.7718	1.8861	1.7718
3	1.6655	1.7918	2.0005	1.8861	1.7718	1.8861	1.7718
4	1.6832	1.7541	2.0005	1.8861	1.7718	1.8861	1.7718
5	1.7918	1.8604	2.0005	1.8861	1.7718		1.7718
6	1.9753	2.1399	2.0005	2.0576	2.0005		1.8861
7	1.9004	2.009	2.2862	2.5149	2.2291		2.0005
8	1.7918	2.9321	2.8006	2.5149	2.1148		1.4289
9	1.7375	3.2922	3.0293	3.6008			2.8006
10	1.3575	3.0247	2.6863	2.9081	3.1436	2.6057	2.572
11	1.4815	2.2405	2.2177	2.6326	2.2965	2.6886	3.5117
12	1.5684	2.2177	2.1285	2.4394	2.1285	2.2634	2.7984
13	1.5684	2.6326	2.3434	2.9081	2.6612	2.32	4.0055
14	1.7741	2.2862	2.8292	2.4897	2.2731	2.3525	2.3348
15	1.6832	2.572	2.4897	2.4646	2.6326	2.6029	2.6063
16	1.6832	2.7446		2.9424	2.3765	2.4331	3.6923
17	1.7918	3.2007		2.2405	2.8292	2.6292	3.8409
18	1.7918	1.829	2.2862	2.4577		2.8578	3.1047
19	2.1176	2.2862	2.5149	2.2862	1.3146	1.4289	2.2497
20	2.384	2.4577	2.572	2.4577	2.4646	1.6004	2.6063
21	2.4394	2.3434	2.5149	2.5149	2.4577	1.4289	2.4983
22	2.4143	2.3434	2.5149	2.3434	2.2862	2.2862	
23	2.2262	2.2862	2.3434	2.2291	2.0576	2.0005	2.2497
24	2.1148	2.0576	2.0576	1.8861	1.8861	1.8861	1.8861
Max	2.4394	3.2922	3.0293	3.6008	3.1436	2.8578	4.0055
Min	1.3575	1.7541	2.0005	1.8861	1.3146	1.4289	1.4289
Avg	1.8462	2.3346	2.3463	2.3883	2.1823	2.1541	2.4753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 201 / 11KV Auxilliary

Feeder KV- 11 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10					.0191	
11		.0381			.0377	.0381
12		.0381	.0381		.0381	.0377
13		.0377	.0381		.0381	.0377
14		.0377			.0381	.0377
15		.0381			.0381	.0377
16		.0381	.0381	.0381	.0572	.0381
24	.0191		1.8656			
Max	.0191	.0381	1.8656	.0381	.0572	.0381
Min	.0191	.0377	.0381	.0381	.0191	.0377
Avg	.0191	.0380	.4950	.0381	.0381	.0378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 202 / Shirol

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6598	1.448	1.5729	1.448	1.5278		1.39
2	1.5844	1.448	1.5203	1.4266	1.5089		1.3756
3	1.5466	1.3957	1.448	1.3756	1.4523		
4	1.5089	1.4146	1.448	1.3575	1.4901		1.3394
5	1.4901	1.4861	1.4842	1.4299	1.5089		1.4118
6	1.6221	1.5089	1.6289	1.5384	1.5466		1.448
7	1.6975	1.6221	1.7918		1.6598		1.4998
8	1.7164	1.7718	1.9366		1.6598		1.5364
9		2.1691	2.0748		1.6409	2.0182	1.8461
10		2.3577	2.452		2.2634	2.2634	2.0119
11		2.7915	2.6406		1.2449	2.6029	2.0633
12		2.3765	2.2634		2.3765	2.4143	1.9204
13		2.452	2.3954		2.3388	2.2634	1.828
14		2.4143			2.1879	2.2634	1.9589
15		2.5652	2.6029		2.3577	2.5463	1.9404
16		2.5274	2.6406	2.3388	2.2634	2.4143	1.9959
17	1.5655	2.6425		2.2068			2.1125
18	1.4901	1.9728	1.905	2.1502		2.2081	2.0182
19	1.7353	2.2443	1.9185	2.037			1.9805
20	1.8484	2.0814	1.8461	2.0182		1.6832	2.0182
21	1.8671	2.0633	1.7013	1.9993		1.8107	1.9616
22	1.773	2.0271	1.7013	1.9616		1.6461	
23	1.6975	1.8461	1.6651	1.8861		1.5729	1.7918
24	1.6787	1.5278	1.701	1.5565	1.6409		1.4266
Max	1.8671	2.7915	2.6406	2.3388	2.3765	2.6029	2.1125
Min	1.4901	1.3957	1.448	1.3575	1.2449	1.5729	1.3394
Avg	1.6551	2.0064	1.9245	1.7820	1.8040	2.1313	1.7671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 204 / Tarabai Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8473	1.848	1.8656	1.829	2.0328		1.7193
2	1.7193	1.8665	1.7924	1.7193	1.8665		1.5729
3	1.6644	1.7187	1.7193	1.6461	1.8111		1.4632
4	1.6278	1.6632	1.6827	1.6461	1.7372		1.4632
5	1.5546	1.6095	1.7193	1.6461	1.6817		1.4998
6	1.5364	1.5708	1.701	1.6461	1.643		1.4998
7	1.4815	1.6448	1.6644	1.6278	1.6078		1.4998
8	1.6461	1.6448	1.7193		1.7002		1.4998
9		1.7558	1.9035		1.7924	1.8656	1.6095
10		1.8473	2.0698		2.1033	1.957	1.6461
11		1.5912	1.9774		1.9387	1.8656	1.6827
12		1.7375	2.0883		1.9204	2.1033	1.7375
13		1.701	2.1437		2.0485	1.9753	1.7193
14		2.0668			1.957	2.0302	1.829
15		2.1948	2.2177		2.1948	2.2314	1.9204
16		2.1033	2.0513	1.9589	2.1765	2.1399	1.9204
17	1.885	1.9936		1.9589			1.957
18	1.848	1.957	1.9753	2.1068		1.9387	1.8656
19	2.1807	2.2314	2.1399	2.2916			2.1399
20	2.3777	2.4508	2.3594			2.1399	2.524
21	2.3777	2.4508	2.4326			2.1399	2.4691
22	2.2731	2.268	2.371			2.0668	
23	2.2177	2.268	2.1948	2.2361		2.0302	2.4143
24	1.9753	2.0328	1.8656	2.0485			1.8107
Max	2.3777	2.4508	2.4326	2.2916	2.1948	2.2314	2.524
Min	1.4815	1.5708	1.6644	1.6278	1.6078	1.8656	1.4632
Avg	1.8883	1.9257	1.9843	1.8739	1.8882	2.0372	1.8028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 206 / Vikramnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1763	1.1949	1.1458	1.0349	1.1576		1.0719
2	1.1389	1.1203	1.0719	.9979	1.1016		.9979
3	1.1016	1.0562	.9979	.9979	1.0751		.961
4	1.0642	.9997	.9979	.9979	1.0269		.961
5	1.0269	1.0374	.9979	1.0349	1.0562		.9979
6	1.0456	1.0456	1.0719	1.0719	1.0456		1.0164
7	.9335	.9431	.9795		.9335		.961
8	.9522	.9522	.924		.9522		.9055
9		.9709	1.0456		.9709	.9335	.9055
10		.9896	1.0829		.9709	.9709	.924
11		1.0269			1.0456	1.0829	.924
12		1.0082	1.0642		1.0082	1.0269	.8871
13			1.0829		1.0269	1.0082	.8871
14		1.1949			.9896	1.1203	.9335
15		1.2323	1.0829		1.1016	1.0642	.961
16		1.1389	1.1949	1.1016	1.0829	1.1016	.9896
17	.9709	1.1273		1.0829			1.0642
18	.9335	1.0349	1.2012			.961	.9896
19	1.1576	1.2936	1.2752	1.5123			1.2136
20	1.3443	1.3676	1.3306	1.531		1.2382	1.363
21	1.363	1.3676	1.3121	1.3817		1.2752	
22	1.3817	1.423	1.3306	1.4003		1.2752	1.363
23	1.4003	1.3491	1.2567	1.3817		1.2567	1.363
24	1.2323	1.251	1.2567	1.1088	1.2136		1.1088
Max	1.4003	1.423	1.3306	1.531	1.2136	1.2752	1.363
Min	.9335	.9431	.924	.9979	.9335	.9335	.8871
Avg	1.1389	1.1359	1.1287	1.1883	1.0446	1.1011	1.0326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 207 / Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4904	.061	.0533	.547		.0495
2	.5525	.4904	.0572	.0495	.5281		.0495
3	.5335	.4904	.0572	.0495	.5093		.0457
4	.5335	.4763	.0572	.0457	.4904		.0457
5	.5144	.4763	.0572	.0438	.4715		.0457
6	.5144	.4904	.0572	.0476	.4715		.0476
7	.5335	.4527	.0572		.5093		.0457
8	.5335	.5093	.0572		.5093		.0457
9		.6097	.8299		.7621	.5716	.0648
10		.7811	.9997		.9526	.7049	.0724
11		.9335	1.0185		.9907	1.0098	.0762
12		.9907	1.0185		1.086		.0781
13		.8764	.9619		1.0669	.9145	.7733
14		.9907			.9526		.0838
15		1.105	1.2449		1.086	.9526	.0838
16		1.1241	1.094	.8488	1.1241	1.0098	.08
17	.547	.1086		.9054			.724
18	.5281	.0953	.0686	.8676		.0914	.724
19	.5093	.0895	.0914	.811			.6478
20	.5281	.0686	.0762	.6413		.0572	.6859
21	.5281	.0667	.0629	.6036		.0572	
22	.5281	.0648	.061	.5847		.0572	.6478
23	.547	.0648	.0629	.5847		.0572	.6097
24	.5335	.5093	.061	.0572	.5658		.0533
Max	.5525	1.1241	1.2449	.9054	1.1241	1.0098	.7733
Min	.5093	.0648	.0572	.0438	.4715	.0572	.0457
Avg	.5311	.5148	.3688	.4129	.7425	.4985	.2513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 212 / 11KV I/C II

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5098	2.4463	2.5377	2.492	2.5377	3.6351	3.155
2	5.3269	2.3777	2.4234	2.3548	2.4006	3.6351	3.3608
3	5.2126	2.2634	2.332	2.3091	2.3548	3.5437	
4	5.0983	2.1719	2.2862	2.2405	2.3091	3.4979	
5	5.1212	2.1491	2.2634	2.2634	2.2862	3.5437	
6	5.3955	2.1719	2.3777	2.4006	2.4006	3.658	
7	5.4184	2.1948	2.3777	2.3777	2.332	3.7952	
8	3.7266	3.8637	3.5208	3.4522	2.1948	3.6808	
9	5.3955	5.7842	6.0357	5.2355	2.332	3.2693	
10	5.6013	6.2414	6.3786	5.4184	2.6978	2.3548	
11	5.5556	6.2872	6.5158	5.0297	2.8578	2.7435	
12	5.487	5.3041	6.5844	5.6242	2.9492	2.8578	
13	5.5098	4.8011	6.4929	5.6699	3.1093	2.9035	
14	5.4641	6.0128	6.3786	5.5327	2.8807	2.7892	
15	5.3727	6.4243	6.6758	5.7613	3.1093	2.995	
16	5.4641	6.4929	6.6987	5.487	3.1779	3.1093	
17	5.3955	6.31	.5487	2.995	3.155	3.2236	
18	5.3041	6.0357	2.0348	3.1321	2.7892	3.2693	
19	2.6292	3.2236	2.4234	3.2465	2.2405	1.5546	
20	3.0407	3.5437	3.4751	3.4751	1.669	3.1321	
21	3.0178	3.1779	3.1779	3.2236	3.1779	2.9492	
22	2.9721	3.0636	3.0178	3.0636	3.0407	2.9492	
23	2.9035	2.9492	2.8121	2.995	2.9492	2.7435	
24	2.652	2.6978	2.6063	2.7206	2.652	2.492	
Max	5.6013	6.4929	6.6987	5.7613	3.1779	3.7952	3.3608
Min	2.6292	2.1491	.5487	2.2405	1.669	1.5546	3.155
Avg	4.6906	4.0828	3.8323	3.6875	2.6501	3.0969	3.2579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 201 / Kay Industry

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.2667	.2667	.0381	.2667	.0381
3	.0381	.0381	.2858	.2858	.2667	.2667	.2667
4	.0381	.2667	.2667	.2858	.2667	.2667	.2858
5	.0381	.2858	.2667	.2667	.2858	.2667	.2667
6	.0381	.2858	.2858	.2667	.3048	.3048	.2858
7	.0381	.2667	.3239	.2858	.3048	.3048	.2858
8	.0381	.2667	.2667	.2667	.2667	.3048	.3239
9	.0381	.2858	.2667	.2858	.2667	.2858	.2858
10	.0373	.2614	.2614	.2801	1.7924	.2614	.2667
11	.0373	.2614	.2614	.2987	1.8671	.2614	.2667
12	.0373	.2614	.2427	.2614	.2614	.2614	.2667
13	.0373	.2801	.2427	.2614	.2427	.2614	.2667
14	.0373	.2801	.2801	.2614	.2614	.2801	.2667
15	.0373	.2614	.2987	.2614	.2801	.2801	.2667
16	.0373	.0373	.2987	.2614	.2614	.2801	.3048
17	.0381	.0381		.0381	.0381	.2667	.2614
18	.0381	.0381	.0381	.0381	.0381		.2614
19	.0381	.0381	.0381	.0381	.0381		.2614
20	.0381	.0381	.0381	.0381	.0381	.0572	
21	.0381	.0381	.0381	.0381	.0381	.0381	
22	.0381	.0381	.0381	.0381	.0381	.0381	
23	.0381	.0381	.0381	.0381	.0381	.0381	.0373
24	.2667	.0381	.0381	.0381	.0381	.0381	.0381
Max	.3048	.2858	.3239	.2987	1.8671	.3048	.3239
Min	.0373	.0373	.0381	.0381	.0381	.0381	.0373
Avg	.0585	.1550	.1922	.1849	.3046	.2122	.2305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 202 / Sakal Press

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.743	.9717	1.0288	.9526	2.1948	.9907
2	.8954	.724	.9145	.9717	.9907	1.0288	1.086
3	.8573	.743	.9526	.9145	.8764	.8764	.9335
4	.8002	.743	.8383	.8383	.8002	.7811	.8383
5	.7621	.724	.743	.8002	.7621	.8002	.8002
6	.743	.743	.743	.8002	.7811	.8002	.7811
7	.7049	.743	.7621	.7621	.8764	.8192	.8002
8	.743	.7811	.7621	.8002	.8383	.8192	.8573
9	.743	.6668	.6859	.6287	.8383	.7049	.8002
10	.5601	.6908	.7095	.7655	.7842	.7095	.724
11	.0362	.7095	.6908	.7842	.7468	.7095	.724
12	.5228	.7095	.7095	.7468	.7095	.6908	.7621
13	.6535	.7095	.7095	.5975	.6535	.6722	.8192
14	.6722	.7095	.7468	.6161	.7095	.7842	.8954
15	.6348	.7842	.7655	.6348	.7468	.9149	.7621
16	.6535	.8215	.7655	.6348	.7842	.8589	.8192
17	.6668	.743		.6859	.7811	.8192	.7842
18	.6859	.724	.362	.6478	.8002		.7842
19	.724	.743	.6287	.6287	.8192		.8402
20	.743	.724	.724	.6668	.8002	.8002	
21	.7621	.724	.724	.6859		.8002	
22	.7621	.6859	.6668	.743	.743	.7621	
23	.743	.7049	.7811	.6859	1.1241	.7621	.8962
24	.8573	.743	.724	.7811	.6478	.9145	.9145
Max	.8954	.8215	.9717	1.0288	1.1241	2.1948	1.086
Min	.0362	.6668	.362	.5975	.6478	.6722	.724
Avg	.7001	.7307	.7426	.7437	.8072	.8647	.8387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 203 / Menon Metallics

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.3239	.2858	.6097	.6668	.5906	.4191
2	.7049	.3239	.2858	.6287	.6859	.6097	.4001
3	.6859	.3239	.2858	.6097	.6478	.6097	.4191
4	.4572	.3239	.3429	.5335	.6668	.5716	.381
5	.6859	.3239	.362	.6097	.6859	.5716	.4191
6	.4382	.3429	.362	.4001	.6859	.4191	.4001
7	.6859	.3429	.381	.6859	.6859	.4191	.6478
8	.3239	.3239	.4382	.6668	.7049	.6478	.6478
9	.3048	.4001	.8764	.7811	.743	.7621	.5335
10	.2987	.5041	.7842	.7468	.6348	.8402	.6097
11	.2801	.5601	.5975	.5041	.5601	.8589	.743
12	.2801	.5415	.7468	.8402	.8402	.7655	.8002
13	.2801	.5228	.7655	.8775	.8962		.7811
14	.2801	.5041	.7842	.8029	.8589	.7095	.8002
15	.2987	.5041	.8775	.8215	.7842	.5041	.5335
16	.3174	.5228	.8402	.7468	.7095	.5228	.4763
17	.3048	.3429		.4001	.6668	.6097	.5228
18	.3048	.3429	.8573	.4382	.6478		.5975
19	.3239	.3429	.6287	.7621	.6097		.6535
20	.3239	.3239	.6478	.743	.6097	.6287	.5228
21	.3239	.3048	.5906	.6859	.6287	.6097	
22	.3239	.2858	.3429	.6097	.4191	.5906	
23	.3239	.2858	.6097	.6668	.4191	.381	.4481
24	.4572	.3239	.2858	.6287	.6478	.5716	.381
Max	.724	.5601	.8775	.8775	.8962	.8589	.8002
Min	.2801	.2858	.2858	.4001	.4191	.381	.381
Avg	.4055	.3851	.5643	.6583	.6711	.6092	.5517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 204 / Budhale

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.7621	.724	.8002	.7811	1.4098	1.2765
2	.7811	.7621	.7811	.7811	.7811	1.3717	1.2765
3	.8002	.7621	.7621	.7811	.8002	1.3527	1.2384
4	.8002	.7621	.7621	.8002	.7811	1.3717	1.2955
5	.8192	.7621	.7811	.8002	.8002	1.3527	1.2955
6	.8002	.7621	.7811	.7811	.7811	1.4098	1.2765
7	.7049	.7811	.743	.7811	.7621	1.4289	1.3527
8	.7621	.7621	.9907		.8002	1.3717	1.4289
9	.7621	1.1431	1.2384	.9145	.9335	2.1338	1.4861
10	.7468	1.1576	1.2696	1.643	1.1949	2.0165	2.9721
11	.7282	1.1949	1.2883	1.9605	1.1949	1.9418	2.7054
12	.7468	1.0829	1.0829	1.587	1.2696	1.9791	2.2481
13	.7468	1.0456	1.0082	1.4563	1.1763	2.0351	2.3243
14	.6161	1.0269	1.4937	1.5497		2.2032	2.3624
15	.7468	1.0456	1.7551	1.6057	2.6513	2.3339	2.7244
16	.7282	1.1576	1.1389	1.4937	2.3152	1.9978	2.1529
17	.7621	1.1241		1.1622	1.8671	2.2862	
18	.743	1.0288	.9145	.8383	1.6956		
19	.7621	.9335	.8192	.8764	1.5432		
20	.743	.8383	.7811	.8192	1.4098	1.4861	1.4003
21	.743	.7621	.8002	.7811	1.2765	1.3146	1.307
22	.7621	.7811	.8002	.8192	1.2765	1.2955	1.2323
23	.743	.7621	.8002	.7811	1.3146	1.2384	
24	.8002	.7621	.7049	.8002	.8002	1.3336	1.2384
Max	.8192	1.1949	1.7551	1.9605	2.6513	2.3339	2.9721
Min	.6161	.7621	.7049	.7811	.7621	1.2384	1.2323
Avg	.7570	.9151	.9661	1.0701	1.2264	1.6666	1.7297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 205 / Chintamani
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.5906	.5716	1.0974	
2	.6097	.6097	.6097	.5906	1.1088	
3		.6097	.6097	.5716	1.1355	
4	.6097	.6097	.6478	.5906	1.1698	
5	.6097	.6287	.6668	.6097	1.1508	
6	.6097	.6478	.6859	.5906	1.246	
7	.6287	.6287	.5906	.6859	1.2956	
8	.6097	.6668	.5906	.6668	1.3032	
9	.5906	.7621	.7811	.7811	1.566	
10	.5788	.7842	1.1576	.9335	2.0607	
11	.5788	.8029	1.2696	1.0082	2.1075	
12	.5975	.7468	1.1576	.8962	1.9205	
13	.6161	.6908	.7842	.7468		
14	.6161	.9709	.8029	1.3817		.7468
15	.5975	1.1016	.8029	1.4377		.9335
16	.6535	1.1203	1.1576	1.1576	.9335	
17	.6478	1.0479		1.0288		
18	.6287	.8954	.9145	.8002		
19	.6478	.743	.6859	.7811		
20	.6287	.6287	.6287	.6287		
21	.6287	.5335	.5144	.5525		
22	.6287	.5906	.5525	.5335		
23	.6097	.5335	.5144	.5335		
24	.5906	.6097	.5335	.5716	.5335	
Max	.6535	1.1203	1.2696	1.4377	2.1075	.9335
Min	.5788	.5335	.5144	.5335	.5335	.7468
Avg	.6142	.7322	.7500	.7771	1.3306	.8402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 206 / Gainmax

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.5716	.9526	1.9128	.9907	1.0669	.9907
2	.9145	.5716	.9907	.9907	1.0288	1.105	1.0098
3	.9717	.5716	.9717	.9717	1.0479	1.0669	1.0288
4	.9526	.6097	.9145	1.0288	.9907	.9717	.9907
5	.9907	.6478	.9717	.9526	1.0669	.7049	.9526
6	.9907	.6859	.9907	.743	1.2955	1.0288	.9145
7	.9526	.8002	.9907	1.0288	1.4861	1.0098	1.3717
8	.8383	.8002	.724	.743	1.2765	.724	1.0288
9	.5716	1.0288	1.2193	1.2384	1.4098	1.2955	1.105
10	.5601	1.4563	1.1203	1.2696	1.5684	1.4563	1.6194
11	.5228	1.5497	1.0456	1.3256	1.643	1.531	1.4098
12	.5228	1.4003	.9709	1.307	1.531	1.4937	1.2765
13	.5415	1.2136	.9522	1.1949	1.5123	1.4563	1.5813
14	.5228	1.4563	1.1576	1.1949	1.5497	1.6244	1.7147
15	.5601	1.5497	1.2323	1.2136	1.307	1.7551	1.5242
16	.5415	1.7364	1.1389	1.2136	1.0829	1.4563	1.6766
17	.5906	1.3146		1.4098	1.0288	1.0669	1.1203
18	.6097	1.0669		1.0288	1.0098		.9709
19	.5716	.9145		.9145	1.0098		.8962
20	.5716	.9526		.9907	1.0288		.9335
21	.5716	1.0288	.9526	1.0669	1.0288	.5906	.9149
22	.5716	.9526	.8764	1.1241	1.0288	.9526	.9335
23	.5716	.9526	.9145	1.0288	1.0669	1.0669	.9335
24	.8383	.5716	.8002	.9717	1.0288	1.0288	.9717
Max	.9907	1.7364	1.2323	1.9128	1.643	1.7551	1.7147
Min	.5228	.5716	.724	.743	.9907	.5906	.8962
Avg	.6994	1.0168	.9944	1.1193	1.2091	1.1644	1.1612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 211 / 11KV I/C I

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	.9145	1.1431	1.3717	1.3717	1.3717	1.6004
2	1.6004	.9145	1.3717	1.3717	1.3717	1.6004	1.3717
3	1.3717	.9145	1.6004	1.829	1.6004	1.829	1.6004
4	1.6004	1.1431	1.6004	1.6004	1.6004	1.6004	1.6004
5	1.3717	1.1431	1.1431	1.6004	1.3717	1.3717	1.3717
6	1.1431	1.1431	1.1431	1.3717	1.6004	1.6004	1.3717
7	1.1431	1.1431	1.1431	1.3717	1.6004	1.3717	1.3717
8	1.1431	1.1431	1.3717	1.3717	1.3717	1.6004	1.3717
9	.9145	1.1431	1.6004	1.6004	1.6004	1.6004	1.6004
10	.9145	1.3717	1.829	1.6004	1.829	1.6004	1.829
11	.9145	1.6004	1.829	1.829	1.829	1.829	1.829
12	.9145	1.6004	1.6004	1.6004	1.6004	1.6004	1.6004
13	.9145	1.3717	1.6004	1.6004	1.829	1.6004	1.6004
14	.9145	1.3717	1.6004	1.6004	1.6004	1.6004	1.829
15	.9145	1.3717	1.829	1.829	1.829	2.0576	1.829
16	.9145	1.1431	1.829	1.829	1.829	1.829	2.0576
17	.9145	1.1431		1.3717	1.6004	1.829	1.829
18	.9145	.9145	1.6004	1.3717	1.3717	1.6004	1.6004
19	.9145	.9145	1.1431	1.3717	1.3717	.6859	1.6004
20	.9145	.9145	1.1431	1.3717	1.3717	1.3717	1.3717
21	.9145	.9145	1.3717	1.3717	1.3717	1.3717	1.3717
22	1.1431	.9145	1.3717	1.3717	1.3717	1.3717	1.3717
23	.9145	.9145	1.3717	1.3717	1.3717	1.3717	1.3717
24	.9145	1.1431	1.3717	1.3717	1.6004	1.1431	1.3717
Max	1.829	1.6004	1.829	1.829	1.829	2.0576	2.0576
Min	.9145	.9145	1.1431	1.3717	1.3717	.6859	1.3717
Avg	1.0860	1.1336	1.4612	1.5146	1.5527	1.5337	1.5718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 212 / 11KV I/C II

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.829	2.0576	2.0576	2.0576	2.0576	2.0576
2	2.0576	1.829	1.829	1.829	2.0576	2.0576	2.0576
3	2.0576	1.829	1.829	1.829	1.829	2.0576	1.829
4	2.0576	1.829	2.0576	1.829	1.829	2.0576	1.829
5	2.0576	1.829	1.829	1.829	1.829	2.0576	2.0576
6	2.0576	2.0576	2.0576	1.829	2.2862	2.0576	2.2862
7	2.0576	2.0576	2.0576	2.0576	2.2862	2.2862	2.2862
8	1.829	2.0576	2.0576	1.6004	2.5149	2.2862	2.5149
9	1.829	2.7435	2.7435	2.0576	2.7435	2.9721	2.7435
10	1.829	3.4294	3.4294	3.2007	3.2007	3.4294	3.658
11	1.829	3.658	3.8866	3.658	3.8866	3.8866	4.3439
12	1.829	3.658	3.658	4.3439	4.1152	3.8866	3.8866
13	1.829	3.2007	3.658	3.4294	3.658	3.658	3.658
14	1.829	3.4294	3.2007	4.1152	2.7435	3.4294	3.658
15	1.829	3.658	3.658	3.8866	4.1152	3.8866	4.5725
16	1.829	3.8866	3.8866	3.8866	4.1152	3.658	3.8866
17	1.829	3.658		4.1152	3.8866	3.658	4.1152
18	1.829	2.9721	2.9721	3.4294	3.658	3.4294	3.4294
19	1.829	2.5149	1.6004	2.5149	2.5149	1.3717	2.5149
20	1.829	2.5149	1.3717	2.2862	2.2862	1.6004	2.2862
21	1.829	2.0576	1.829	2.2862	2.2862	1.829	2.0576
22	1.829	2.0576	2.0576	2.0576	2.0576	2.0576	2.0576
23	1.829	2.0576	2.0576	2.0576	2.0576	2.0576	2.2862
24	1.829	2.0576	2.0576	2.0576	2.0576	2.0576	2.2862
Max	2.0576	3.8866	3.8866	4.3439	4.1152	3.8866	4.5725
Min	1.829	1.829	1.3717	1.6004	1.829	1.3717	1.829
Avg	1.8957	2.6197	2.5149	2.6768	2.7530	2.6578	2.8483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 412 / 33KV T/F I

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	.9145	1.1431	1.3717	1.3717	1.3717	1.3717
2	1.6004	.9145	1.3717	1.3717	1.3717	1.6004	1.3717
3	1.3717	.9145	1.6004	1.829	1.6004	1.829	1.6004
4	1.6004	1.1431	1.6004	1.6004	1.829	1.6004	1.6004
5	1.3717	1.1431	1.3717	1.6004	1.3717	1.3717	1.3717
6	1.1431	1.1431	1.1431	1.3717	1.6004	1.6004	1.6004
7	1.3717	1.1431	1.1431	1.3717	1.6004	1.6004	1.3717
8	1.1431	1.1431	1.3717	1.3717	1.6004	1.6004	1.3717
9	.9145	1.1431	1.6004	1.6004	1.6004	1.6004	1.6004
10	.9145	1.3717	1.829	1.6004	1.829	1.6004	1.829
11	.9145	1.6004	1.829	1.829	1.829	1.829	1.829
12	.9145	1.6004	1.6004	1.6004	1.829	1.6004	1.6004
13	.9145	1.3717	1.6004	1.6004	1.829	1.6004	1.6004
14	.9145	1.3717	1.6004	1.6004	1.6004	1.6004	1.829
15	.9145	1.3717	1.829	1.829	1.829	2.0576	1.829
16	.9145	1.3717	1.829	1.829	1.829	1.829	1.829
17	.9145	1.1431		1.3717	1.6004	1.829	1.829
18	.9145	1.1431	1.6004	1.3717	1.3717	1.6004	1.6004
19	.9145	1.1431	1.1431	1.3717	1.3717	.9145	1.6004
20	.9145	1.1431	1.1431	1.3717	1.3717	1.3717	1.3717
21	.9145	.9145	1.3717	1.3717	1.3717	1.3717	1.3717
22	.9145	.9145	1.3717	1.3717	1.3717	1.3717	1.3717
23	.9145	.9145	1.3717	1.3717	1.3717	1.3717	1.3717
24	.9145	1.1431	1.3717	1.6004	1.6004	1.1431	1.3717
Max	1.829	1.6004	1.829	1.829	1.829	2.0576	1.829
Min	.9145	.9145	1.1431	1.3717	1.3717	.9145	1.3717
Avg	1.0860	1.1717	1.4711	1.5242	1.5813	1.5527	1.5623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 413 / 33KV T/F II

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.829	2.0576	2.0576	2.0576	2.0576	2.0576
2	2.0576	1.829	2.0576	1.829	2.0576	2.0576	2.0576
3	2.0576	1.829	1.829	2.0576	1.829	2.0576	1.829
4	2.0576	1.829	2.0576	1.829	1.829	2.0576	1.829
5	2.0576	1.829	1.829	1.829	1.829	2.0576	1.829
6	2.0576	2.0576	2.0576	1.829	2.2862	2.0576	2.2862
7	2.0576	2.0576	2.2862	2.0576	2.2862	2.2862	2.2862
8	1.829	2.0576	2.0576	1.6004	2.5149	2.2862	2.5149
9	1.829	2.5149	2.7435	1.829	2.7435	2.9721	2.9721
10	1.829	3.2007	3.4294	3.2007	3.2007	3.4294	3.8866
11	1.829	3.658	3.8866	3.4294	3.8866	3.8866	4.3439
12	1.829	3.658	3.658	4.3439	4.1152	3.8866	3.8866
13	1.829	3.2007	3.658	3.4294	3.658	3.658	3.658
14	1.829	3.4294	3.2007	4.1152	2.7435	3.4294	3.658
15	1.829	3.658	3.658	3.8866	3.8866	3.8866	4.5725
16	1.829	3.8866	3.8866	4.1152	4.1152	3.8866	4.1152
17	1.829	3.658		4.1152	3.8866	3.658	4.1152
18	1.829	3.2007	2.9721	3.4294	3.658	3.4294	3.4294
19	1.829	2.5149	1.6004	2.5149	2.5149	1.829	2.5149
20	1.829	2.5149	1.3717	2.2862	2.2862	1.6004	2.2862
21	1.829	2.2862	1.829	2.2862	2.2862	1.829	2.0576
22	1.829	2.0576	1.829	2.0576	2.0576	2.0576	2.0576
23	1.829	2.0576	2.0576	2.0576	2.0576	2.0576	2.2862
24	1.829	2.0576	2.0576	2.0576	2.0576	2.0576	2.2862
Max	2.0576	3.8866	3.8866	4.3439	4.1152	3.8866	4.5725
Min	1.829	1.829	1.3717	1.6004	1.829	1.6004	1.829
Avg	1.8957	2.6197	2.5248	2.6768	2.7435	2.6863	2.8673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 414 / 33KV I/C-2

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.3978	12.3572	13.4203	14.4148	14.5062	15.0092	14.0718
2	15.3293	12.4943	13.7746	14.9291	14.9635	15.6493	14.4605
3	14.9863	12.4943	14.5176	14.8148	15.272	15.8322	14.5176
4	14.632	12.7114	14.7463	15.3064	15.2949	16.0151	14.7463
5	14.3119	12.9058	14.0604	15.2378	14.7348	14.8948	14.2775
6	14.0261	13.5002	14.1176	14.3004	15.9123	15.3979	15.0435
7	14.2089	13.626	14.6777	15.615	16.6667	15.6607	15.9123
8	13.6717	13.6145	15.0892	14.049	17.3411	15.3407	16.701
9	12.1514	14.9863	17.8441	14.8491	17.3297	13.0316	18.4271
10	11.8667	19.6879	20.9717	19.1816	15.9808	20.9717	22.2908
11	11.206	22.3252	21.6141	21.1763	18.107	22.9481	24.8286
12	11.1934	21.3032	22.7058	24.3256	23.7517	22.1377	22.931
13	11.3615	19.4456	21.4346	20.5979	21.6278	22.0942	21.8908
14	11.8416	18.9769	20.2172	22.0931	17.6955	15.9808	22.7252
15	11.9102	20.2298	23.203	23.8387	21.6815	23.3276	23.8683
16	11.9662	21.6324	22.468	23.5963	23.8089	22.7927	23.9483
17	12.22	19.9245	16.118	21.8907	21.8907	21.6964	22.4508
18	12.1514	17.9012	2.6863	18.9301	20.4276	15.8436	20.6368
19	12.2085	14.4833	11.0311	16.8267	17.7183	14.4719	16.6839
20	12.1514	14.4605	11.0311	15.8894	15.4092	9.4193	16.4975
21	12.2771	13.7289	12.9972	15.2836	15.3635	12.4943	15.3006
22	12.3457	13.0544	13.8203	14.9977	14.529	14.2204	14.4468
23	12.3572	13.1345	13.9461	14.5519	14.9863	13.9118	14.8457
24	13.1574	12.8373	13.5117	15.0206	15.3063	14.3119	14.7234
Max	15.3978	22.3252	23.203	24.3256	23.8089	23.3276	24.8286
Min	11.1934	12.3572	2.6863	14.049	14.5062	9.4193	14.0718
Avg	12.8721	15.9090	15.8335	17.5715	17.5127	16.8106	18.1761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 204 / INDIRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6348	.6908	.6283	.6722	.6535	.6161
2	.5847	.5788	.6348	.5914	.5975	.5975	.5601
3	.5658	.5601	.5788	.5601	.5601	.5601	.5228
4	.5093	.5228	.5601	.5041	.5601	.5228	.5228
5	.5281	.5415	.5601	.5041	.5601	.5228	.5041
6		.5415	.5788	.5228	.5415	.5228	.5041
7	.5658	.5041	.5788	.5228	.5415	.5415	.5228
8	.5281	.5228	.5975	.5601	.5788	.5415	.5228
9	.5228	.6348	.5975	.6535	.6348	.6161	.5601
10	.5975	.7468	.7095	.7095	.7468	.7468	.6348
11	.7655	.8775	.8775	.9149	.9522	.9149	.7095
12	.8775	.9709	.9709	.9709	1.0829	.9896	.7655
13	.8589	1.0456	1.0269		1.0642	1.0829	.8029
14	.8402	.9896	.9896	.9709		1.0082	.7842
15	.8962	.9896	.9522			.9896	.8215
16	.8589		.9709	.9896		1.0082	.8215
17	.8962	1.0082	1.0456	.9709		1.0456	.7842
18	.8962	1.0269		1.0269		1.0456	.7282
19	.9709	1.0642	1.2136			1.0829	.7842
20	1.531	1.0829	1.1016			.9709	.7842
21	.8589	.9522	.9896	.5601		.8589	.6908
22	.7282	.7468	.7468	.9335		.6908	.6908
23	.7095	.7095	.6535	.7468		.6535	.6908
24	.6478	.6722	.7468	.6535	.6908	.6722	.5975
Max	1.531	1.0829	1.2136	1.0269	1.0829	1.0829	.8215
Min	.5093	.5041	.5601	.5041	.5415	.5228	.5041
Avg	.7556	.7793	.7988	.7247	.6988	.7850	.6636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 205 / GANESH TAIKIES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9522	.961	1.1273	1.0349	1.0534	.9979	.9979
2	.8962	.924	1.0719	.961	.9795	.924	.9425
3	.8589	.8131	.961	.924	.924	.8316	.8501
4	.8029	.8316	.924	.924	.924	.7392	.8316
5	.8029	.8501	.8871	.8871	.8871	.7392	.8316
6	.8402	.8871	.924	.8871	.9055	.7762	.8316
7	.8962	.8871	.961	.8871	.9055	.8131	.8871
8	.8962	.8686	.9425	.961	.924	.8686	.8501
9	.8962	.8871		.961	.9425	.9425	.8501
10	.9055	.9979	1.0349	.9795	1.0349	.9795	.9055
11	1.1827	1.2382	1.2567	1.2936	1.2752	1.2197	1.0719
12	1.3121		1.4045	1.4969	1.386	1.423	1.1458
13	1.3491	1.3676	1.4784	1.4969	1.4784	1.46	1.2012
14	1.2936	1.3676	1.4415	1.4969		1.5339	1.1458
15	1.3491	1.4045	1.46			1.5154	1.2012
16	1.4415		1.46	1.4784		1.5524	1.2012
17	1.3676	1.46	1.4784	1.3676		1.4969	1.1827
18	1.3676	1.6263		1.5154		1.5339	1.1458
19	1.4784	1.7002	1.7926			1.6263	1.2012
20	1.5154	1.7002	1.6263			1.5339	1.2012
21	1.3306	1.46	1.4415	1.6263		1.3121	1.1088
22	1.1458	1.1458	1.1643	1.2936		1.0903	1.0534
23	1.0534	1.0903	.961	1.1088		.9795	.9979
24	.9145	.9979	1.1458	1.0164	1.0534	1.0349	.961
Max	1.5154	1.7002	1.7926	1.6263	1.4784	1.6263	1.2012
Min	.8029	.8131	.8871	.8871	.8871	.7392	.8316
Avg	1.1187	1.1576	1.2248	1.1713	1.0481	1.1635	1.0249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 206 / 11 KV Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.0377	.2075	.1886	.2641	.3206	.3772
2		.0373	.2075	.1886	.2641	.2829	.3395
3	.1905	.0373	.1886	.1886	.2452	.2452	.3206
4	.1905	.0377	.1886	.1698	.2452	.2263	.3206
5	.2096	.0377	.2075	.1886	.2641	.2263	.3395
6	.2286	.0377	.2075	.1886	.1698	.2452	.3584
7	.2477	.0373	.2263	.1886	.1698	.2452	.3584
8	.3018	.1509	.3395	.2829	.2641	.2641	.3772
9	.1509	.3018	.3961	.3772	.2263	.3206	.3018
10	.1509	.2801	.415	.3395	.3772	.2641	.3395
11	.132	.3547	.4338	.4715	.415	.3206	.3584
12	.1509	.4108	.4527	.4715	.4715	.3018	.4338
13	.132	.3584	.4338	.415	.4338	.3018	.4338
14	.132	.2641	.415	.415		.2452	.3584
15	.1132	.3395	.415			.3018	.3395
16	.0943		.3772	.415		.4715	.3961
17	.0754	.4338	.3772	.415		.4715	.3961
18	.0566	.415		.4338		.5281	.3772
19	.0377	.3772	.2263			.3395	.3018
20	.0377	.2829	.2829			.415	.2641
21	.0377	.2641	.2263	.1509		.3584	.1698
22		.2263	.132	.1886		.3584	.2075
23	.0377	.1886	.1886	.2641		.2829	.1886
24	.2452	.0377	.2075	.1886	.2829	.2452	.2829
Max	.3018	.4338	.4527	.4715	.4715	.5281	.4338
Min	.0377	.0373	.132	.1509	.1698	.2263	.1698
Avg	.1438	.2152	.2936	.2919	.2924	.3159	.3309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 212 / 11KV I/C II

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2407	1.2315	1.4144	1.3016	2.3929	1.4388	1.4022
2	1.2437	1.1888	1.3656	1.2925	2.332	2.274	1.89
3	1.2071	1.0852	1.326	1.2772	2.268	2.2161	1.89
4	1.1675	1.0303	1.2437	1.198	2.2161	2.1704	1.768
5	1.1431	.9724	1.2102	1.1401	2.1856	2.0424	1.7253
6	1.1523	.9785	1.201	1.1492	2.2161	2.0515	1.7741
7	1.1919	.9785	1.2285	1.1919	1.2772	2.1765	2.0454
8	1.2285	1.0395	1.2437	1.1949	1.2315	2.1887	2.1094
9	2.652	2.6429	2.7161	2.6978	1.2407	2.2039	2.0424
10	2.8532	2.9325	3.0575	2.9203	1.2864	1.701	1.5333
11	2.8258	3.0575	3.2648	2.9904	1.5394	1.4998	1.3443
12	3.1062	3.4019	3.4598	3.3166	1.8625	1.7193	1.6065
13	3.1672	3.4324	3.5818	3.4598	1.9448	1.8381	1.7589
14	3.1032	2.1826	3.4294	3.3653	1.9906	1.9479	1.7345
15	3.0453	1.7863	3.3867	3.3318	1.9082	1.9174	1.6491
16	3.0361	2.1033	3.3684	3.4019	1.9784	2.0454	1.7132
17	3.03	3.3532	3.1642	3.283	1.9692	2.0607	1.7528
18	1.5364	3.4263	2.0332	2.0058	2.0332	1.9997	1.7436
19	1.5973	3.408	2.0271	2.1369	2.0546	2.0668	1.6461
20	1.7375	2.1674	2.1582	1.9022	2.146	2.0058	1.6674
21	1.7345	2.1613	2.1369	.9755	2.1125	2.0576	1.6369
22	1.6461	1.89	1.8595	2.3015	1.8351	1.8442	1.4144
23	1.3291	1.4815	1.3778	2.5118	1.512	1.5546	1.3931
24	1.2041	1.3687	1.2894	2.4569	1.4388	1.3961	1.3687
Max	3.1672	3.4324	3.5818	3.4598	2.3929	2.274	2.1094
Min	1.1431	.9724	1.201	.9755	1.2315	1.3961	1.3443
Avg	1.9658	2.0542	2.1893	2.2001	1.8738	1.9340	1.6921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 401 / 33KV Gandhinagar I/C
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.904	9.5565	10.8362	10.1464	14.5485	11.262	10.4698
2	9.5336	9.1844	10.451	9.7039	13.902	13.3608	11.6752
3	9.2399	8.5934	9.9097	9.4422	13.4808	12.9218	11.4272
4	8.8752	8.2504	9.4982	9.1118	13.2293	12.5378	10.8917
5	8.8151	8.1002	9.2364	8.8375	13.0567	12.1674	10.8099
6	8.9283	8.1556	9.417	8.9849	12.0485	12.4828	11.1689
7	9.1678	8.2796	9.5302	9.2364	9.5565	13.0178	11.957
8	9.1907	8.2927	9.6542	9.5857	9.3376	13.0864	12.5143
9	14.3548	14.9057	15.3904	15.4212	9.5987	12.2909	11.5124
10	15.2298	16.3375	16.9707	16.3787	10.2892	10.8757	10.2029
11	15.8619	17.9973	18.5597	17.9698	12.2897	11.7227	10.5355
12	17.2017	15.2264	20.3109	19.9315	14.2158	13.3059	11.7992
13	17.5446	18.6008	20.7648	20.3018	14.5777	14.1792	12.6515
14	17.2497	14.4902	20.3373	19.9177	11.0425	14.5153	12.4851
15	17.2176	13.2499	20.076	14.8148	10.7682	14.3222	12.1291
16	17.1491	11.1797	20.1446	19.5748	10.9054	14.808	12.6143
17	15.8591	19.9691	18.1573	18.2167	10.974	15.0949	12.7887
18	11.4009	20.0789	11.4541	14.6886	11.3169	15.263	12.6395
19	12.021	18.9975	15.2269	11.9342	9.6022	14.2604	12.1714
20	13.2425	15.9797	16.1289	11.3169	11.5226	14.4651	12.7887
21	12.8966	15.351	15.5904	5.1857	11.5912	14.5656	12.2502
22	11.9467	13.5563	13.5254	14.6359	10.4938	12.8704	11.2214
23	10.7254	11.5363	11.2998	15.9917	8.9163	11.4118	10.9865
24	9.9726	10.6276	10.6041	14.2616	11.9524	10.4115	10.6265
Max	17.5446	20.0789	20.7648	20.3018	14.5777	15.263	12.7887
Min	8.8151	8.1002	9.2364	5.1857	8.9163	10.4115	10.2029
Avg	12.6470	13.1874	14.2948	13.5663	11.6340	13.1333	11.6799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 412 / 33KV T/F I

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8066	3.9438	4.0466	3.9438	4.1838	3.9781	3.4979
2	3.7037	3.7723	3.9095	3.6351	3.9095	3.8066	3.4294
3	3.6008	3.4979	3.7037	3.5665	3.8066	3.6351	3.3265
4	3.4294	3.3951	3.5322	3.4294	3.6008	3.4979	3.155
5	3.3265	3.2922	3.4294	3.3608	3.4637	3.3265	3.155
6	3.3265	3.2922	3.4637	3.3951	3.4979	3.4637	3.155
7	3.3265	3.3951	3.5322	3.4979	3.6008	3.4637	3.2236
8	3.2922	3.2922	3.5665	3.5322	3.4637	3.4294	3.155
9	3.2579	3.2579	3.4637	3.6008	3.5322	3.4294	3.3265
10	3.2922	3.6694	3.4294	3.6694	3.7037	3.5665	3.2922
11	3.4294	4.1152	4.0809	4.1495	4.3553	4.1838	3.8066
12	3.7723	4.7668	4.8354	4.8697	5.144	4.8354	4.1152
13	3.9781	5.0412	5.1783	5.0755	5.2469	5.2126	4.2524
14	4.0124	4.904	5.2126	5.1783	5.2469	5.3841	4.3553
15	4.0124	4.8011	5.1097	5.0412	5.2812	5.2469	4.2181
16	4.0809	4.8697	5.0755	5.0755	5.1097	5.1783	4.2181
17	4.1838	5.1097	5.4527	5.2126	5.2126	5.4184	4.3896
18	4.2867	5.144	5.487	5.2126	5.3841	5.5556	4.3896
19	4.2867	5.0412	5.3155	5.727	3.6694	5.3841	4.2867
20	5.2126	5.7956	6.2071	5.8299	5.5213	4.8011	4.8011
21	5.1783	5.7956	6.07	.3429	5.6584	5.2812	4.7668
22	4.8354	5.3155	5.487	3.738	5.2812	4.7325	4.3896
23	4.4582	4.561	4.7325	4.9383	4.6296	4.2867	4.3896
24	4.2181	4.2867	4.1495	4.6296	4.3553	3.9095	4.2524
Max	5.2126	5.7956	6.2071	5.8299	5.6584	5.5556	4.8011
Min	3.2579	3.2579	3.4294	.3429	3.4637	3.3265	3.155
Avg	3.9295	4.3481	4.5196	4.1938	4.4524	4.3753	3.8895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 413 / 33KV T/F II

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1431	1.3717	1.1431	2.2862	1.3717	1.3717
2	1.1431	1.1431	1.3717	1.1431	2.2862	2.0576	1.829
3	1.1431	.9145	1.1431	1.1431	2.0576	2.0576	1.829
4	1.1431	.9145	1.1431	1.1431	2.0576	2.0576	1.6004
5	1.1431	.9145	1.1431	1.1431	2.0576	1.829	1.6004
6	1.1431	.9145	1.1431	1.1431	1.6004	2.0576	1.829
7	1.1431	.9145	1.1431	1.1431	1.1431	2.0576	2.0576
8	1.1431	.9145	1.1431	1.1431	1.1431	2.0576	2.0576
9	2.7435	2.7435	2.7435	2.7435	1.1431	2.0576	2.0576
10	2.7435	2.9721	2.9721	2.9721	1.1431	1.3717	1.1431
11	2.7435	3.2007	3.2007	2.9721	1.6004	1.3717	1.3717
12	2.9721	3.4294	3.4294	3.4294	1.829	1.6004	1.6004
13	2.9721	3.4294	3.4294	3.4294	1.829	1.829	1.6004
14	2.9721	1.6004	3.4294	3.2007	1.829	1.829	1.6004
15	2.9721	1.829	3.2007	3.2007	1.829	1.829	1.6004
16	2.9721	2.7435	3.4294	3.2007	1.829	2.0576	1.6004
17	2.2862	3.2007	2.5149	2.5149	1.829	1.829	1.6004
18	1.3717	3.2007	1.829	1.829	2.0576	1.829	1.6004
19	1.6004	2.5149		2.0576	1.829	1.829	1.6004
20	1.6004	2.0576	2.0576	1.829	2.0576	1.829	1.6004
21	1.6004	2.0576	2.0576	1.1431	2.0576	2.0576	1.6004
22	1.3717	1.6004	1.6004	2.2862	1.6004	1.6004	1.3717
23	1.1431	1.3717	1.3717	2.2862	1.3717	1.3717	1.3717
24	1.1431	1.3717	1.1431	2.2862	1.3717	1.3717	1.3717
Max	2.9721	3.4294	3.4294	3.4294	2.2862	2.0576	2.0576
Min	1.1431	.9145	1.1431	1.1431	1.1431	1.3717	1.1431
Avg	1.8480	1.9624	2.0874	2.1052	1.7433	1.8004	1.6194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 201 / 11KV SARALASHKAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1912	1.3199	1.3679	.5807	1.2285	.6607	1.3619
2	1.1752	1.3214	1.3717	.586	1.2316	.6706	1.3062
3	1.1843	1.3222	1.3809	.5998	1.2377	.692	1.3115
4	1.1996	1.3237	1.3801	.6005	1.3313	.7019	1.3306
5	1.2079	1.3222	1.3923	.6104	1.2559	.7042	1.3329
6	1.2087	1.3085	1.39	.6135	1.3641	.695	1.3252
7	1.1957	1.2993	1.3778	.5777	1.3313	1.3519	1.3275
8	1.1447	1.3252	1.3931	1.2483	1.329	1.3306	1.2986
9	.6013	.6302	1.5036	1.2354	.6729	1.5439	1.4106
10	.6173	.6935	.7667	1.2674	1.7055	.8459	1.6461
11	1.2156	1.5714	.8802	1.2826	1.7497	2.0249	1.7802
12	.6112	1.5661	1.6454	1.2072	1.7863	1.8328	1.7071
13	1.1919	1.5676	.8566	1.1141	.6668	1.6781	1.6537
14	.6302	1.6179	1.6057	1.5135	.8573	1.7513	1.5912
15	.6302	1.6217	1.7421	1.579	.8573	1.5798	1.6819
16	1.1927	.8604	1.592	1.5661	.7621	1.5897	.8368
17	1.1813	1.6034	.7644	1.3581		1.579	.7956
18	1.2749	1.4159	.5716	1.2963		1.5402	1.3016
19	1.2818	1.3329	1.1714	1.2955		1.2483	.6066
20	.612	1.3222	1.1744	1.3016		.9846	.6089
21	1.2871	1.2125	1.1729	1.3313		1.2986	.6379
22	.6386	1.3062	.586	1.2986		1.2749	1.2026
23	1.3009	1.3054	.5624	1.3062		1.1919	.6081
24	1.3085	1.3275	1.2285	1.2079	.5716	.615	1.281
Max	1.3085	1.6217	1.7421	1.579	1.7863	2.0249	1.7802
Min	.6013	.6302	.5624	.5777	.5716	.615	.6066
Avg	1.0451	1.3124	1.2032	1.1074	1.1729	1.2244	1.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 202 / 11 KV MAULI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.2384	1.9052		1.7147		1.9052
2	1.6194	1.2384	1.9052		1.8099		1.9052
3	1.5242	1.2384	2.0005				1.9052
4	1.5242	1.3336	1.7147		1.8099		1.8099
5	1.5242	1.3336	1.7147		2.0005		1.8099
6	1.5242	1.3336	1.4289		1.9052		1.7147
7	1.5242	1.3336	1.7147		1.9052	1.5242	1.5242
8	1.3336	1.8099	2.0957	2.0957	2.0957	2.191	2.0957
9			2.4768	2.3815		2.4768	2.4768
10				2.0957	2.2862		2.572
11	1.3336	2.572		1.9052	2.0957	2.6673	2.6673
12	1.3336	1.8099	1.8099	2.3815	2.191	1.8099	1.9052
13	1.3336	2.2862	1.8099	2.2862	2.2862	2.4768	2.572
14		2.4768	2.2862	1.9052	2.4768	2.8578	2.4768
15		2.3815	2.7625	2.0957	2.7625	2.0957	2.2862
16	1.4289		2.4768	2.4768	1.8099	2.8578	
17	1.4289	2.4768		2.3815		2.8578	
18	1.4289	2.2862		2.2862		2.6673	2.2862
19	1.4289	2.3815	2.0957	2.2862		2.6673	
20	1.4289	2.2862	1.5242			1.8099	
21	1.2384	2.0957	1.9052	1.5242		1.9052	
22		2.191		2.0957		2.0957	1.6194
23	1.2384	2.191		1.9052		2.0957	
24	2.0957	1.2384	2.0957	2.0005	1.8099		1.9052
Max	2.0957	2.572	2.7625	2.4768	2.7625	2.8578	2.6673
Min	1.2384	1.2384	1.4289	1.5242	1.7147	1.5242	1.5242
Avg	1.4690	1.8825	1.9846	2.1314	2.0640	2.3160	2.0798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 203 / G' BLOCK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.9526	1.7147		1.5242		1.1431
2	1.2384	.9526	1.8099		1.6194		1.1431
3	1.2384	.8573	1.7147		1.7147		1.1431
4	1.2384	.8573	1.7147		1.7147		1.1431
5	1.2384	.9526	1.5242		1.5242		1.1431
6	1.1431	.9526	1.2384		1.7147		1.2384
7	1.1431	.8573	1.3336		1.7147	1.7147	1.2384
8	1.0479	1.0479	1.3336	1.7147	1.5242	1.7147	1.2384
9			1.7147	1.5242		1.9052	2.0957
10				1.9052	1.6194		2.191
11	.7621	1.7147		1.9052	1.7147	2.0957	2.191
12		1.4289	2.191	1.5242	1.6194	1.4289	
13	.7621	.8573	1.2384	2.0957	1.9052	1.4289	1.8099
14		1.7147		1.7147	1.0479	2.0957	1.9052
15		1.8099		1.8099	2.0957	1.6194	1.5242
16			1.9052	2.0957	2.0957	1.6194	
17	.9526	1.4289		2.0957		1.6194	
18	.8573	1.4289		1.4289		1.4289	.9526
19	.9526	.9526		1.5242		1.7147	
20	.9526	1.5242	1.3336	1.1431		1.7147	
21	.9526	1.8099	1.0479	1.0479		1.3336	
22		1.3336		1.7147		1.7147	.9526
23	.9526	1.3336		1.7147		1.7147	1.5242
24	1.2384	.9526	1.5242	1.7147	1.6194		1.1431
Max	1.2384	1.8099	2.191	2.0957	2.0957	2.0957	2.191
Min	.7621	.8573	1.0479	1.0479	1.0479	1.3336	.9526
Avg	1.0255	1.2248	1.5559	1.6867	1.6730	1.6790	1.4289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 204 / 11 KV Maharashtra Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	1.2384	1.5242		1.6194		1.5242
2	.1905	1.2384	1.5242		1.5242		1.5242
3	.1905	1.2384	1.5242		1.7147		1.5242
4	.1905	1.1431	1.6194		1.5242		1.5242
5	.1905	1.1431	1.5242		1.4289		1.4289
6	.0953	1.2384	1.5242		1.4289		1.4289
7	.0953	1.3336	1.6194		1.7147	1.7147	1.8099
8	.0953		1.9052	1.9052	1.9052	1.9052	2.0957
9			2.3815	1.8099		2.191	2.4768
10				1.9052	2.3815		2.4768
11	.0953	2.572			2.4768	2.7625	2.6673
12	.0953	2.3815	2.4768	2.0957	2.191	2.2862	2.572
13	.0953	2.191	2.3815	2.0957	2.0957		2.3815
14		2.572		2.2862	2.0957	2.6673	2.4768
15		2.3815	2.4768		2.2862	2.3815	2.3815
16	.0572		2.2862	2.4768	2.191	2.3815	
17	.0572	2.2862		2.3815		2.4768	
18	1.3336	2.0005	1.3336	2.0957		2.191	2.0957
19	1.3336	1.8099	1.7147	1.8099		1.7147	2.0957
20		1.7147	1.7147	1.6194		1.7147	
21	1.3336	1.7147	1.7147	1.6194		1.8099	
22		1.6194		1.7147		1.8099	1.7147
23	1.3336	1.5242		1.8099		1.7147	
24	.0953	1.2384	1.5242	1.6194	1.7147		1.6194
Max	1.3336	2.572	2.4768	2.4768	2.4768	2.7625	2.6673
Min	.0572	1.1431	1.3336	1.6194	1.4289	1.7147	1.4289
Avg	.3927	1.7290	1.8205	1.9496	1.8933	2.1148	1.9904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 206 / DEVAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.7621	.9526		.7621		.8573
2	.9526	.7621	.8573		.7621		.8573
3	.9526	.7621	.8573		.7621		.8573
4	.9526	.7621	.8573		.8573		.8573
5	.9526	.7621	.7621		1.4289		.8573
6	.7621	.6668	.7621		.8573		.8573
7	.7621	.6668	.7621		.8573	.9526	.8573
8	.8573	1.2384	.8573	1.0479	1.1431	1.1431	1.2384
9			1.5242	.6668		1.2384	2.2862
10					1.9052		2.4768
11	.6668	1.5242		1.2384	1.9052	1.7147	2.191
12	.6668	1.9052	1.5242	1.4289	1.6194	2.0957	2.0957
13	.6668	1.9052	1.7147	1.3336	1.1431	1.1431	1.8099
14		2.0957		1.9052	1.9052	1.9052	2.0957
15		2.0005	2.4768	2.0957	1.4289	2.191	.9526
16	.7621		2.0957		1.8099	2.191	
17	.8573	1.8099		2.0957		1.4289	
18	.6668	1.8099		1.9052		1.3336	1.7147
19	.6668	1.3336	.8573	1.8099		.6668	
20	.6668	1.4289	2.0005	1.1431		1.3336	
21	.6668	1.3336	1.1431	.7621		1.3336	
22	.6668	1.2384		.7621		1.3336	1.1431
23	.7621	1.2384		.7621		.9526	
24	.9526	.7621	1.0479	.9526	.7621		.8573
Max	.9526	2.0957	2.4768	2.0957	1.9052	2.191	2.4768
Min	.6668	.6668	.7621	.6668	.7621	.6668	.8573
Avg	.7907	1.2747	1.2384	1.3273	1.2443	1.4348	1.3813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 211 / 11KV I/C I
Feeder KV- 11 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5995	3.6923	3.3699	3.3265	3.4751	3.4134
2	2.6063	3.2808	3.2762	2.8784	3.4728	2.979
3	2.604	3.3311	3.2945	2.9424	3.5391	2.9424
4	2.6063	3.3311	3.3288	2.9035	3.4888	2.9424
5	2.5949	3.0041	2.6429	2.8898	3.1001	2.9218
6	2.5995	2.9995	2.0736	2.9195	3.0064	2.9561
7	2.5903	2.9424	2.0233	2.8852	3.0087	2.9675
8	2.7092	3.0338	2.6337	3.1276	3.315	3.3653
9	3.3653	3.6831	4.0398	3.8523	3.7997	4.1495
10	4.145	4.8583	3.6054	4.6914	5.4024	5.8391
11	4.8468	5.7202	4.0375	3.8363	5.2126	5.7499
12	5.1738	5.7956	4.2478	4.9268	5.4321	6.0837
13	5.1463	5.4207	4.353	4.5542	5.3384	6.0997
14	4.8628	4.7965	4.9223	4.3964	4.8194	5.4298
15	5.5693	5.4115	5.3887	5.2881	5.5899	5.9579
16	5.7087	5.8871	5.3109	5.2309	5.4184	5.4527
17	5.7933	5.0732	5.2515	4.6868	4.8834	5.5396
18	4.9817		4.9451	4.5359	4.8743	5.1097
19	4.4993	1.358	4.5199	3.8112	4.2501	4.3827
20	3.8523	3.315	4.1678	2.0988	1.3329	4.2798
21	3.9209	3.6923	2.1148	2.6109	3.3471	4.0969
22	3.8043	3.6854	3.1779	3.0247	3.6488	3.722
23	3.8363	3.514	3.4476	3.6877	3.7174	3.7311
24	3.8455	3.4705	3.3905	3.7997	3.61	3.6786
Max	5.7933	5.8871	5.3887	5.2881	5.5899	6.0997
Min	2.5903	1.358	2.0233	2.0988	1.3329	2.9218
Avg	3.9276	3.9694	3.7318	3.7044	4.0451	4.3246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 212 / 11KV I/C II

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.31	2.2291	3.1161	3.0819	2.8807	3.1184	3.0681
2	1.4426	2.2451	3.0841	3.0498	2.9607	3.0361	2.931
3	1.3512	2.2474	3.1413	2.8052	2.9904	3.011	3.0933
4	1.2734	2.2657	3.0384	2.9172	2.9264	2.995	3.0293
5	1.2551	2.2748	3.0133	2.979	2.9401	2.9012	3.0293
6	1.1957	2.2611	3.0521	2.7138	2.9858	2.9561	3.0636
7	1.3054	2.1171	3.1642	2.9767	3.0407	3.2396	3.2625
8	1.2666	2.1834	3.3242	3.139	3.267	3.235	3.4042
9	1.1591	2.3274	3.8043	3.4957	3.802	3.722	3.5414
10	.8939	3.4705	4.257	3.7037	3.9232	4.2433	4.0375
11	.8322	4.0375	4.1587	4.0787	3.8249	4.5085	4.6068
12	.8116	4.3027	5.08	3.6694	3.9621	4.6776	4.6708
13	.8185	4.273	4.6479	4.2547	3.7814	4.7737	4.7028
14	.8573	4.3804	4.4627	4.3416	3.8729	4.4833	4.0398
15	.8802	4.6776	4.7417	4.4513	4.1998	4.7828	3.93
16	.8711	4.1998	4.6456	4.1221	4.2638	4.5679	3.8272
17		4.4399	4.6571	4.433	4.321	4.6251	3.9415
18	1.0928	3.8272	.1143	4.1953	3.9163	4.0832	3.6671
19	2.3388	3.6466	1.7193	3.4591	3.7014	3.9255	3.3425
20	2.316	3.1093	1.7032	3.5391	2.1674	3.123	3.1893
21	1.2071	3.0133	2.9378	2.8006	2.636	2.9447	3.4751
22	2.3525	3.3128	2.8578	2.899	3.0087	3.1504	2.9561
23	2.2428	2.9995	3.0887	3.3173	3.0156	3.3173	2.9492
24	2.2314	3.1321	3.2167	3.2785	3.0956	3.4179	3.3722
Max	2.3525	4.6776	5.08	4.4513	4.321	4.7828	4.7028
Min	.8116	2.1171	.1143	2.7138	2.1674	2.9012	2.931
Avg	1.3611	3.2072	3.3761	3.4876	3.3952	3.7016	3.5471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 412 / 33KV I/C II

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0124	6.7215	9.4993	9.3964	8.7792	9.5336	9.4307
2	4.2867	6.7558	9.3964	9.225	9.0192	9.2593	9.0192
3	4.0809	6.7558	9.5679	8.4705	9.0192	9.1221	9.3964
4	3.8409	6.7901	9.1564	8.8477	8.9163	9.0535	9.1564
5	3.7723	6.8244	9.1564	8.9849	8.8477	8.7449	9.1564
6	3.6351	6.7558	9.2593	8.2648	9.0878	8.9506	9.225
7	3.8409	6.3443	9.4993	8.9849	9.2936	9.9109	9.9109
8	3.8752	6.5501	10.2195	9.6022	9.9451	9.8766	10.3567
9	3.4637	6.7215	11.4884	10.5624	11.5226	11.2483	10.8025
10	2.7092	10.4938	12.9287	11.4541	11.8999	12.8944	12.1399
11	2.5034	12.2428	12.5858	12.4486	11.5912	13.4774	13.9918
12	2.4348	12.9973	15.535	10.7682	12.0713	14.1633	14.1976
13	2.4691	13.0316	14.1976	12.9973	11.4884	14.6091	14.369
14	2.572	13.1002	13.3745	13.203	11.797	13.5803	12.3114
15	2.6406	14.2661	14.4719	13.6489	12.7572	14.5405	12.0713
16	2.6063	12.7915	14.129	12.62	13.0316	14.0261	11.6598
17		13.3402	14.2318	13.546	13.2373	13.9918	12.1399
18	3.2579	11.7627	.5487	12.7915	12.0028	12.8258	11.2483
19	7.0302	11.214	5.2812	10.6653	11.2826	12.0713	10.3224
20	6.9959	9.6022	5.2126	10.8025	6.9616	9.3279	9.7051
21	3.2922	9.2936	8.9849	8.4705	8.0247	8.9849	10.631
22	7.1331	10.1852	8.7106	8.7792	9.2593	9.5679	9.1221
23	6.7558	9.225	9.3279	10.048	9.1907	10.1509	8.9506
24	6.7215	9.6022	9.808	9.9794	9.465	10.3224	10.2195
Max	7.1331	14.2661	15.535	13.6489	13.2373	14.6091	14.369
Min	2.4348	6.3443	.5487	8.2648	6.9616	8.7449	8.9506
Avg	4.0839	9.7237	10.2738	10.6067	10.3538	11.2597	10.8139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP

Feeder No / Name : 401 / 33KV Gandhinagar

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	24.3485	25.5144	15.2949	7.6818	11.0425	12.7572	13.4431
2	23.2511	24.1427	14.6091	7.3388	10.5624	16.3923	15.8436
3	22.7024	22.9767	17.5583	7.2017	10.2881	16.0494	15.5693
4	22.0165	22.2908	21.8107	6.9273	9.9451	15.7751	15.0892
5	21.8793	21.9479	22.0851	6.5844	9.7394	15.2949	14.6777
6	22.9081	22.9767	19.8903	6.7215	9.808	15.7751	15.1578
7	25.2401	25.2401	16.3238	6.9959	7.2702	17.284	16.3238
8	23.594	23.8683	23.8683	7.2017	6.9959	17.5583	17.6955
9	24.3485	26.2003	25.583	11.5912	7.2702	16.3238	17.6269
10	28.738	27.1605	24.1427	12.4829	7.5446	13.1002	19.6845
11	28.8752	23.594	29.0124	13.1687	8.9163	19.273	18.7929
12	***	***	***	15.1578	10.5624	22.0851	19.1358
13	29.7668	***	***	15.5007	10.9054	24.9657	24.417
14	29.2867	19.0672	***	28.738	11.0425	25.3773	24.6914
15	29.7668	18.107	***	29.0124	10.7682	27.1605	24.1427
16	28.8066	21.5364	***	29.4925	10.8368	27.7092	24.6914
17	28.1208	***	***	28.5323	26.4061	26.2689	25.2401
18	15.0206	***	23.7312	18.7929	20.1646	21.5364	12.963
19	15.3635	***	5.4184	18.5185	9.7394	16.7353	17.0096
20	18.7243	21.9479	12.4143	9.7394	11.5912	11.0425	19.4102
21	18.9301	22.2908	12.1399	.6859	12.62	16.8725	19.4788
22	26.8176	28.2579	10.7682	10.4938	11.8656	18.0384	17.284
23	28.1208	29.0124	8.7792	12.2085	10.7682	16.3923	17.0782
24	***	27.5035	7.8875	11.7284	11.7284	14.8148	16.2552
Max	35.6311	33.9507	34.0193	29.4925	26.4061	27.7092	25.2401
Min	15.0206	18.107	5.4184	.6859	6.9959	11.0425	12.963
Avg	25.0986	25.7288	21.0963	13.4374	11.1826	18.5243	18.4042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP

Feeder No / Name : 403 / 33KV Sugarmill

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	24.76	26.6804	24.6914	23.5254	21.3992	27.0234	24.8972
2	22.7024	24.5542	22.428	21.9479	20.8505	24.1427	23.1825
3	21.1934	23.1139	21.1934	20.6447	19.8903	22.8395	22.4966
4	20.7133	22.428	21.9479	20.3018	19.273	22.3594	21.8107
5	20.096	21.3306	21.3992	20.096	18.7929	21.7421	21.262
6	19.7531	21.1934	21.0563	20.096	19.2044	21.9479	21.7421
7	20.1646	21.8793	20.5762	20.7133	19.7531	22.6338	22.3594
8	19.8217	21.5364	21.8107	20.5076	19.8903	22.5652	22.9081
9	19.8903	21.262	22.0851	22.2223	21.0563	23.7312	23.3196
10	20.6447	22.9767	23.7998	23.8683	23.7998	26.8862	25.926
11	20.9191	23.6626	25.0343	25.583	25.7202	28.8066	26.1317
12	21.5364	18.45	25.3773	26.4747	27.5035	***	27.6406
13	22.0165	18.3128	25.3773	26.4061	26.8176	29.4925	27.8464
14	22.2223	25.0343	25.9945	21.8793	25.926	***	27.0919
15	22.7024	25.3773	26.1317	27.1605	26.749	***	27.3663
16	22.9767	27.3663	27.4349	28.5323	28.3265	***	27.915
17	22.6338	28.3265	26.0631	27.8464	28.3265	***	28.1893
18	22.0851	26.9548	6.653	24.8286	26.1317	***	26.749
19	22.0851	26.1317	25.1715	23.9369	24.6914	29.2181	25.5144
20	26.8176	29.6983	***		27.3663	19.5474	***
21	27.1605	29.5611	27.5721		28.3265	28.2579	***
22	29.081	***	26.5432		26.8862	28.2579	***
23	29.2181	***	25.7888		25.926	28.8752	***
24	28.8066	29.7668	25.6516		25.3773	27.5721	***
Max	29.2181	30.3155	30.3841	28.5323	28.3265	32.9219	33.1962
Min	19.7531	18.3128	6.653	20.096	18.7929	19.5474	21.262
Avg	22.9167	24.8314	23.7569	23.5037	24.0827	26.7462	26.3861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP

Feeder No / Name : 404 / 33KV Nagala

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	22.2223	22.1537	22.5652	19.6845	21.8107	18.1756	15.8436
2	20.439	20.096	20.3704	17.8327	16.8725	16.3923	14.6091
3	19.3416	19.0672	19.4102	16.8039	15.9122	15.5007	14.0604
4	18.107	18.3128	18.45	15.9808	15.5007	14.952	12.963
5	17.6955	17.8327	17.8327	15.4321	15.2264	14.6777	12.1399
6	17.7641	17.9698	18.107	15.7065	15.2949	15.0206	12.3457
7	17.6269	18.1756	18.0384	15.8436	15.4321	15.0206	13.1687
8	17.7641	17.6269	18.2442	15.5693	15.5007	15.0206	13.1687
9	18.45	18.5871	19.2044	16.5295	16.6667	16.6667	13.5117
10	19.4788	21.4678	22.0851	17.4211	18.9987	18.5871	14.4033
11	22.1537	27.5035	27.7092	14.8834	24.0055	23.1139	14.952
12	23.594	***	***	9.8766	27.7778	24.9657	15.5007
13	24.76	***	***	24.0741	27.8464	26.0631	18.45
14	24.76	***	***	28.3265	26.8176	26.2689	18.45
15	24.0055	***	***	27.0919	26.1317	24.8972	17.9698
16	24.0055	***	***	26.5432	26.4747	27.6406	17.6955
17	24.2113	***	***	27.0234	27.1605	27.0234	18.3814
18	24.5542	***		27.0234	29.3553	26.6118	18.3814
19	25.3087	***		***	28.738	25.1715	18.2442
20	28.6009	***	16.1866	***	***	2.4691	22.2908
21	28.9438	***	16.941	***	***	1.8519	22.1537
22	26.6804	27.5721	19.1358	***	26.6118	19.8217	19.9589
23	24.0741	24.6228	20.7133	***	23.9369	18.3814	18.2442
24	23.7312	23.9369	20.9877	***	19.7531	17.6955	17.4897
Max	28.9438	33.1962	32.7161	46.7765	31.1386	27.6406	22.2908
Min	17.6269	17.6269	16.1866	9.8766	15.2264	1.8519	12.1399
Avg	22.4280	25.4716	23.1357	24.8000	22.6538	18.8329	16.4324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP

Feeder No / Name : 405 / Shahumill

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.4321	10.0823	21.605	17.0782	21.1249	21.0563	16.3238
2	17.5583	9.808	21.1934	17.0096	17.1468	18.45	16.3238
3	14.5405	9.7394	17.1468	16.941	18.8615	21.1934	15.6379
4	13.4431	9.5336	20.7819	17.1468	19.7531	22.6338	19.273
5	13.3059	10.0137	18.0384	17.0782	21.9479	20.9877	19.4102
6	16.5295	12.963	17.284	17.0782	20.7133	20.7133	21.3992
7	16.941	14.4719	21.1249	17.5583	22.771	22.6338	22.0851
8	14.4719	11.797	21.3992	15.2949	22.5652	22.0165	22.0165
9	8.0933	15.5693	23.0453	22.1537	22.9081	20.7819	22.3594
10	8.0247	16.3238	24.6914	22.0165	25.3087	24.0055	22.9081
11	6.7215	21.8107	23.6626	24.2113	24.6914	25.0343	23.3196
12	6.5158	25.0343	22.4966	23.3882	25.9945	21.3306	21.8107
13	6.653	19.4788	22.0165	22.0851	23.594	22.0165	16.2552
14	6.653	23.1825	22.771	23.7312	23.2511	22.6338	19.5474
15	7.7504	23.6626	23.594	23.7998	25.2401	19.4102	18.5871
16	7.7504	23.1825	25.583	23.0453	25.1715	23.594	19.5474
17	7.7504	21.8793	18.5185	22.2908	23.5254	22.771	19.9589
18	8.0247	24.3485	8.5734	22.1537	24.0741	23.2511	21.3306
19	8.4362	17.4211	21.1249	22.3594	17.8327	19.5474	17.0782
20	10.0823	22.3594	23.4568	23.9369	22.8395	19.1358	20.0275
21	10.3567	21.4678	18.9987	22.0165	20.3018	20.7819	20.096
22	10.631	17.9013	17.4897	18.9987	19.3416	19.1358	18.1756
23	10.6996	21.0563	19.0672	19.8903	22.428	23.5254	18.5185
24	15.3063	21.262	17.284	20.8505	21.5364	18.1756	19.4102
Max	17.5583	25.0343	25.583	24.2113	25.9945	25.0343	23.3196
Min	6.5158	9.5336	8.5734	15.2949	17.1468	18.1756	15.6379
Avg	10.9030	17.6812	20.4561	20.5047	22.2051	21.4507	19.6417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP

Feeder No / Name : 407 / 33KV Bapat Camp Minor
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	20.5076	21.262	19.8217	16.3923	19.9589	18.8615
2	28.3265	18.9987	19.4102	18.1756	19.3416	21.3306	20.3018
3	27.0234	18.107	18.3128	17.284	17.8327	20.8505	19.9589
4	25.9945	17.1468	17.8327	16.7353	17.0782	20.096	19.273
5	25.3773	16.6667	17.284	16.1866	16.5981	19.7531	18.9987
6	25.5144	16.5295	17.1468	16.6667	16.4609	20.0275	19.5474
7	26.8176	17.6269	17.9698	17.7641	17.1468	21.262	21.3306
8	25.2401	17.0096	18.7929	17.8327	17.6955	22.1537	21.5364
9	25.9945	28.738	29.1496	26.4061	18.5871	23.3196	22.8395
10	27.915	***	***	29.7668	21.1934	21.262	20.1646
11	28.3951	***	***	***	23.9369	23.7998	21.3992
12	28.9438	***	***	29.3553	24.8286	25.3087	22.3594
13	29.2867	29.904	***	***	25.1715	25.9945	22.5652
14	29.4239	29.2181	***	***	25.7202	25.2401	22.428
15	29.2181	***	***	***	25.583	25.926	22.9081
16	29.6983	***	***	***	26.6118	27.8464	23.7312
17	29.6297	***	***	***	26.6804	27.5721	23.7998
18	28.3951	***	12.2771	24.4856	25.8574	23.3196	23.3196
19	26.4061	***	17.6269	22.2223	15.0206	25.7888	22.6338
20	24.3485	28.3951	23.3196	22.4966	20.5076	17.4211	26.1317
21	24.4856	27.7778	25.1029	16.3923	22.9767	23.594	26.749
22	24.2799	25.926	23.6626	23.7998	23.8683	23.1139	25.2401
23	23.9369	24.9657	22.9081	24.0741	22.9081	22.1537	24.3485
24	***	24.2799	21.8793	22.9081	20.9191	20.8505	23.6626
Max	33.3791	37.4486	37.5172	34.0193	26.6804	27.8464	26.749
Min	23.9369	16.5295	12.2771	16.1866	15.0206	17.4211	18.8615
Avg	27.4454	26.6747	25.4001	24.1884	21.2049	22.8310	22.2537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 201 / SHRIRAM

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17
HR	Load (MW)
1	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 204 / MAHALAXMI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17
HR	Load (MW)
1	1.9814
Max	1.9814
Min	1.9814
Avg	1.9814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 205 / 11KV HIGHWAY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5687	1.1812	2.553	2.3929	2.4768	2.1567	2.5835
2	2.3701	1.2041	2.4463	2.1719	2.4158	2.2939	2.3929
3	2.2634	1.1203	2.4234	2.21	2.4539	2.3777	2.4158
4	2.4006	1.1736	2.4234	2.1491	2.4006	2.553	2.3853
5	2.4234	1.1736	2.4158	2.1643	2.3015	2.5072	2.3472
6	2.3396	1.166	2.3091	2.0957	2.3701	2.4158	2.3853
7	2.2481	1.166	2.4234	2.2634	2.4234	2.4691	2.5225
8	2.3548	1.2193	2.553	2.2862	2.5072	2.553	2.5072
9	1.5699	1.829	2.4082	2.2253	2.5682	2.4996	2.5911
10	1.0974	2.2862	2.6673	3.1626	2.9264	2.6292	2.5835
11	1.0974	2.6749	2.9111	3.2998	3.0788	2.8578	2.8045
12	1.0669	2.9416	2.995	3.2541	3.1626	2.9416	2.6825
13	1.0898	2.8273	3.0636	3.2388	3.2312	2.9645	2.6749
14	1.0669	2.652	2.5835	2.7282	2.6597	2.9188	2.4615
15	1.0822	2.9188	2.9492	3.3989	2.9874	3.155	2.8349
16	1.0745	2.9569	2.9492	3.4217	3.1398	3.2465	2.8959
17	1.1203	2.7511	2.9721	3.3455	2.8654	3.1703	2.8426
18	1.1507	2.8349		3.376	2.9797	3.1474	2.6292
19	1.1279	2.7968		2.995	2.8578	3.1245	2.7816
20	1.1736	2.9035	2.1643	2.8807	2.6292		2.6063
21	1.2117	2.7054	2.7054	2.4006	2.3929	.1143	2.332
22	1.1812	2.652	1.8671	2.4844	1.5623	2.9721	2.0957
23	1.2041	2.6978	2.4006	2.6292	1.6232	2.774	2.2329
24	3.1665	2.7664	2.5987	2.6597	1.6537	2.6139	2.2253
Max	4.5687	2.9569	3.0636	3.4217	3.2312	3.2465	2.8959
Min	1.0669	1.1203	1.8671	2.0957	1.5623	.1143	2.0957
Avg	1.7271	2.1916	2.5810	2.7181	2.5695	2.6285	2.5339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 206 / JUMBO

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5301	1.9738	3.0331	2.8045	2.0424	2.1643	2.3624
2	2.8121	1.9204	2.6749	2.431	2.8883	2.8807	3.1626
3	3.1321	1.8747	2.4539	2.6673	3.094	3.0026	3.0864
4	2.9264	1.8823	2.7359	2.271	3.0026	2.8807	2.7359
5	2.5377	1.989	2.3853	2.5072	2.934	2.7816	2.6673
6	2.5987	1.9585	2.2862	2.3853	3.0636	2.9416	3.0102
7	2.3243	2.0957	2.7282	2.6673	2.9569	3.0331	2.7587
8	2.2939	2.2024	2.6063	2.7816	3.6885	3.5132	3.6504
9	1.8976	2.3548	2.5225	2.5606	3.1017	2.9492	2.4996
10	1.9052	2.8807	4.1	3.4598	3.818	3.6732	3.8485
11	1.9052	3.5284	4.7097	4.5039	4.7097	4.9688	4.0771
12	1.9052	3.7723	4.9154	4.2905	4.5572	4.8087	4.2753
13	1.9357	3.6046	5.1288	4.4734	4.7554	4.0619	3.6504
14	1.9662	3.6427	4.1305	4.3972	4.3743	4.0009	4.6868
15	1.9509	3.7571	4.8697	4.8011	4.9688	4.8697	4.5801
16	1.9204	4.0847	4.9078	5.0221	4.3667	4.7401	4.321
17	1.9204	3.94	4.7706	4.3286	4.7935	4.3896	4.5496
18	1.8214	3.7418	4.3896	4.8621	4.5725	5.045	4.2905
19	1.8366	3.6427	4.4734	3.9628	3.9171	4.5115	3.9095
20	1.4861	3.5742	3.9171	3.2846	3.3227	2.7206	3.6504
21	1.6004	3.0407	3.1703	2.1338	2.4691	2.4996	2.7664
22	1.7909	2.6749	3.3989	2.492	2.5758	2.3015	3.2617
23	1.8976	3.0102	3.2084	2.6063	2.5682	2.7816	2.8502
24	4.763	3.3455	3.1321	2.6139	2.4844	2.5301	3.2084
Max	4.763	4.0847	5.1288	5.0221	4.9688	5.045	4.6868
Min	1.4861	1.8747	2.2862	2.1338	2.0424	2.1643	2.3624
Avg	2.2358	2.9372	3.6104	3.3462	3.5427	3.5021	3.4941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolu S/stn

Feeder No / Name : 207 / 11KV SWARAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.8595	2.6368		2.8883	2.7511	2.8654
2	2.1643	1.8519	2.7587	1.8671	2.6444	2.774	2.934
3	2.1186	1.8976	2.6368	2.3929	2.9569	2.652	2.8883
4	2.0043	1.9052	2.7282	2.6444	2.7206	2.4996	2.9111
5	1.9052	1.9357	2.6292	2.7054	2.6063	2.652	2.7282
6	1.8823	1.9433	2.553	2.7206	2.5149	2.6368	2.6597
7	1.9204	1.9509	2.8045	2.6597	2.6444	2.5377	2.5682
8	1.7452	2.0652	2.7968	2.4996	2.8197	2.6901	2.652
9	1.6918	2.1567	2.4539	2.492	2.873	2.6978	3.0788
10	1.6918	2.8959	3.2236	2.995	3.2236	3.0483	3.2693
11	1.6766	3.1474	3.4827	3.3608	3.7113	3.597	3.719
12	1.6232	3.4903	3.9857	3.8485	3.5589	3.5513	3.879
13	1.5927	3.4903	3.658	3.7723	3.3303	3.6427	3.4217
14	1.6156	3.1093	3.3303	3.5361	3.2541	3.2541	3.4827
15	1.6004	3.2312	3.6961	3.6351	3.2922	4.0238	3.437
16	1.608	3.2084	3.5742	3.7952	3.5818	3.6885	3.3227
17	1.6461	2.8959	3.3074	3.8714	3.2007	3.9933	3.315
18	1.6461	2.8197		3.3684	2.6368	3.7113	3.1626
19	1.6461	2.3243		2.5911	1.8366	2.8349	2.2405
20	1.6232	2.05	.0762	2.5835	1.9738	1.8214	2.1948
21	1.7299	2.1567	2.1491	1.9662	2.0424	2.3396	1.8823
22	1.7833	2.2786	1.9966	2.1491	2.0348	2.431	2.1872
23	1.7756	2.3243		2.5987	1.669	2.4996	2.2024
24	3.9514	2.3396		3.094	2.4768	2.9874	2.2177
Max	3.9514	3.4903	3.9857	3.8714	3.7113	4.0238	3.879
Min	1.5927	1.8519	.0762	1.8671	1.669	1.8214	1.8823
Avg	1.8625	2.4720	2.8239	2.9194	2.7705	2.9715	2.8842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 401 / 33 KV MPM

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	22.5652	12.8258	25.926	27.5035	23.1825	25.2401	27.6406
2	24.2113	12.8258	24.3485	22.2908	23.5254	27.6406	29.6297
3	22.2223	12.8944	28.6009	27.3663	22.7024	***	29.2181
4	21.7421	12.963	26.2689	27.915	23.1139	29.081	29.8354
5	24.4856	13.1002	24.2113	27.915	21.1934	26.5432	24.6914
6	21.1934	13.8546	24.9657	22.2908	21.7421	23.4568	27.8464
7	17.6955	13.9918	25.1029	26.6118	22.771	25.6516	26.6118
8	15.5007	13.786	25.6516	26.5432	24.8972	26.6804	25.8574
9	13.1002	18.8615	***	23.1825	26.4747	***	***
10	13.0316	26.4061	***	26.9548	29.4239	***	***
11	12.0028	***	***	***	***	***	***
12	12.0028	29.9726	***	***	***	***	***
13	11.8656	28.8752	***	29.7668	***	***	***
14	12.2771	28.0522	***	***	26.8862	***	***
15	12.4829	***	***	***	29.1496	***	***
16	12.4143	***	***	***	***	***	***
17	12.5515	***	***	***	***	***	***
18	12.62	***	.1372	***	29.904	***	***
19	12.7572	22.428	16.8039	25.3087	25.583	28.9438	26.5432
20	12.6886	18.9301	17.5583	21.7421	22.4966	18.9301	27.9836
21	12.8258	17.1468	17.5583	21.1934	21.6736	19.4788	25.7888
22	12.8944	20.5076	24.6228	22.0851	29.4239	21.605	25.7202
23	12.7572	24.6228	22.7024	24.2799	29.9726	22.5652	25.0343
24	12.7458	28.8752	27.0234	24.9657	27.0919	***	28.1208
Max	24.4856	38.4774	38.9575	39.4376	33.8135	38.9575	41.5638
Min	11.8656	12.8258	.1372	21.1934	21.1934	18.9301	24.6914
Avg	15.4431	22.4995	27.1148	28.2379	26.9062	28.9809	30.7099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolu S/stn

Feeder No / Name : 402 / Shiye (Sugar Mill)

Feeder KV- 33 / INCOMING

DATE	01-MAY-17
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 403 / 33KV Shirolī Minor

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	20.1303	17.1468	21.7421	20.7819	20.7819	21.7421	21.3992
2	14.6777	17.284	20.2332	20.3704	20.3018	21.7421	19.5474
3	14.4719	17.284	20.2332	19.273	20.5076	22.0165	19.5474
4	13.786	17.4897	20.2332	20.2332	20.439	21.8793	19.1358
5	13.6489	17.4211	18.5871	17.7641	20.3018	20.0275	19.2044
6	13.4431	17.284	18.5871	15.5007	20.5762	19.8217	19.3416
7	13.5117	16.8725	18.7243	16.4609	20.8505	20.8505	20.096
8	12.8944	17.5583	20.0275	18.8615	22.5652	22.0851	22.3594
9	12.62	19.4788	23.594	25.2401	24.9657	24.1427	25.3773
10	12.0028	24.2799	28.6694	22.2908	27.7092	***	***
11	12.3457	29.7668	***	26.4747	24.6914	***	***
12	12.1399	***	***	25.0343	28.738	***	***
13	12.0713	***	***	27.8464	26.5432	***	***
14	12.2771	29.4925	29.4925	29.8354	26.6804	29.8354	29.904
15	12.3457	***	***	***	***	***	***
16	12.2085	29.9726	***	***	***	***	29.7668
17	9.6708	***	***	***	29.081	***	***
18	12.963	28.1208	.2058	29.3553	27.2977	29.3553	28.3951
19	17.4897	26.1317	9.8766	25.583	20.1646	25.6516	25.3087
20	17.4897	22.1537	15.9122	23.5254	11.7284	11.3169	24.5542
21	13.1002	22.2223	20.5076	16.0494	15.1578	20.2332	24.417
22	17.284	22.3594	20.8505	20.9191	19.273	22.1537	21.9479
23	17.1468	21.8107	21.262	23.1825	21.9479	23.1825	22.0851
24	17.0782	22.3594	21.4678	23.1139	22.7024	22.7024	23.2511
Max	20.1303	32.4417	34.9795	31.2758	30.7271	33.402	34.9109
Min	9.6708	16.8725	.2058	15.5007	11.7284	11.3169	19.1358
Avg	14.0332	23.4483	22.7967	23.3339	23.0767	25.0915	25.5287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 405 / 33 KV Saroj

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	27.8007	7.7504	26.749		24.8286	***	28.6694
2	24.4856	8.3676	27.6406	23.7312	***	29.0124	***
3	23.5254	10.3567	29.4925	29.6297	28.6694	***	***
4	24.8286	10.4938	29.2181	***	***	***	***
5	20.9877	10.4938	28.3265	28.3265	26.6118	27.9836	***
6	19.8903	10.1509	25.0343	***	27.7778	29.8354	28.9438
7	20.5076	13.7174	26.6118	***	29.9726	***	***
8	17.1468	13.3059	25.6516	***	29.0124	29.8354	***
9	8.3676	20.9191	26.8862	***	29.4925	28.3265	***
10	6.1728	***	26.8176	***	***	***	***
11	5.9671	***	***	***	***	***	***
12	5.7613	***	***	***	***	***	***
13	5.6927	***	***	***	***	***	***
14	6.0357	***	***	***	***	***	***
15	6.3786	***	***	***	***	***	***
16	6.4472	***	***	***	***	***	***
17	6.5158	***	29.1496	***	***	***	***
18	6.5844	***	.2058	***	***	***	***
19	6.5844	***	***	***	***	***	***
20	6.2414	***	***	***	***	23.3882	***
21	6.31	28.3265	25.7202	28.5323	29.081	***	28.0522
22	6.31	***	29.5611	***	***	***	***
23	6.5844	28.9438	8.2991	***	***	***	***
24	6.653	***		***	***	***	***
Max	27.8007	41.5638	36.4884	42.1811	41.9754	40.878	40.4664
Min	5.6927	7.7504	.2058	23.7312	24.8286	23.3882	28.0522
Avg	11.7408	26.0831	27.6556	33.4944	33.2619	33.0019	33.3562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 406 / 33 KV Kolhapur Steel NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.3796		.8916				
2	9.9451		1.166				
3	10.4253		1.3717	.4801	.0686	.6173	
4	11.1111		1.3717	1.3032	.8916	.6859	
5	9.7394		1.3717	.8916	.0686	.0686	
6	.6173		1.0974	1.3032	1.3717		
7	1.166	1.2346	1.3717	1.4403	1.3717	.8916	
8	1.3032	1.0288				.6859	
9	.1372	1.2346		2.4006	2.6749	3.7723	
10		1.3717	1.3717	6.2414	4.1838	6.4472	
11		.4801	3.2922	6.1043	6.9273	6.9959	
12			6.653	5.9671	7.0645	5.0755	.0686
13		.7545	7.1331	6.4472	6.7215	6.7215	
14		1.4403	5.8985	4.1152	6.9959	6.9273	
15			6.9273	3.9781	4.8697	4.6639	
16		1.166	3.2922	5.487	3.8409	3.7037	.2058
17		1.3717	.0686	3.9781	3.5665	3.5665	
18		1.3717		2.6063	3.9095	3.9781	
19		1.4403			1.2346	.4115	
20		1.4403				.0686	1.4403
21		1.3032					4.2524
22		1.3717					4.1152
23		1.166				.2743	5.5556
24		1.4403				.0686	11.6598
Max	11.1111	1.4403	7.1331	6.4472	7.0645	6.9959	11.6598
Min	.1372	.4801	.0686	.4801	.0686	.0686	.0686
Avg	6.0916	1.2260	2.8852	3.5162	3.4851	2.9276	3.8997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 407 / Hind Gear

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7723	1.4403	4.8011	6.2414	5.7613	5.8299	6.5844
2	3.2922	2.1262	4.6639	6.5158	6.0357	6.4472	6.3786
3	3.5665	1.989	4.8697	5.7613	6.5844	6.4472	6.2414
4	3.7723	2.0576	4.8697	6.4472	6.653	6.653	6.7901
5	3.5665	2.1948	4.4582	6.4472	6.5158	6.3786	6.653
6	3.7037	2.2634	4.6639	6.5158	6.5844	6.5844	6.2414
7	2.1262	2.332	4.6639	6.653	6.4472	6.9959	6.9273
8	3.7037	2.8807	5.2126	6.5844	6.5158	6.8587	6.4472
9	1.8519	3.6351	5.6242	6.3786	5.8299	6.31	6.4472
10		3.7723	6.9273	6.31	7.1331	6.8587	6.7215
11		6.1043	6.5158	7.8875	8.9849	8.0247	7.7504
12		5.9671	5.6242	8.2305	8.8477	8.2991	8.8477
13		5.9671	5.8985	8.3676	8.642	7.8875	8.2991
14		3.7037	5.2812	6.2414	8.642	8.2305	7.9561
15		4.4582	6.5158	6.9273	8.5048	8.5048	7.6132
16		6.5158	5.8985	6.4472	8.8477	8.3676	8.642
17		7.0645	5.9671	6.9273	8.2991	6.8587	8.5048
18		6.3786	.0686	6.7901	8.642	6.9959	7.2702
19		7.5446	3.7723	6.7901	6.7901	7.2017	6.4472
20	.6173	7.5446	4.7325	6.8587	6.653	4.0466	6.9273
21	.9602	6.31	4.6639	5.7613	4.7325	5.6242	6.1043
22	1.4403	4.4582	5.5556	6.1728	5.6242	6.0357	6.2414
23	1.5775	4.7325	6.2414	6.653	6.3786	6.7901	6.0357
24	2.652	4.9383	6.8587	6.653	6.5158	6.653	6.0357
Max	3.7723	7.5446	6.9273	8.3676	8.9849	8.5048	8.8477
Min	.6173	1.4403	.0686	5.7613	4.7325	4.0466	6.0357
Avg	2.6145	4.4325	5.1812	6.6901	7.0902	6.8702	7.0045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAY-17 and 07-MAY-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 408 / 33KV GPI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17	06-MAY-17	07-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2812	16.5981	12.963	11.3855	13.5117	13.6489	14.2661
2	3.0178	14.952	14.0604	13.3059	15.1578	13.9232	11.1797
3	2.4691	12.4829	14.6777	15.0892	15.9122	14.7462	16.4609
4	2.9492	13.2373	15.2949	15.0206	13.9918	15.2949	12.62
5	2.8121	12.8944	12.3457	14.2661	15.0892	8.9849	14.129
6	2.6749	15.1578	13.786	12.963	12.7572	12.963	13.6489
7	2.7435	12.62	14.6091	15.7751	15.9122	14.8834	12.8944
8	2.6749	12.3457	13.3059	13.8546	15.2264	13.9918	14.0604
9	2.6749	12.8258	14.4719	17.1468	15.2949	15.1578	15.1578
10	1.7833	11.3169	16.5981	14.2661	16.5981	15.4321	15.5693
11	1.8519	17.4897	17.284	15.8436	14.952	14.2661	16.1866
12	1.8519	14.6091	17.284	17.284	15.0206	15.6379	15.2264
13	1.989	12.963	13.2373	11.6598	15.1578	14.952	14.6777
14	2.8807	13.9232	15.5693	16.5295	15.4321	16.118	15.5693
15	1.9204	14.129	15.6379	16.941	14.8148	17.284	15.9122
16	1.8519	15.4321	16.2552	17.0096	13.7174	15.5007	16.2552
17	3.0864	2.6749	14.129	13.8546	13.5117	13.4431	12.8258
18	3.0864	13.5803	14.0604	15.9122	14.4033	13.786	17.0096
19	3.0864	10.9054	17.0096	15.7065	16.118	14.8834	15.0206
20	3.155		15.9808	18.9987	14.8834	14.7462	17.1468
21	3.155	12.4143	15.3635	15.5007	13.9918	14.8148	16.2552
22	7.4074	13.3059	12.963	16.5295	14.4719	17.7641	16.3238
23	9.5336	14.8148	11.8656	14.6091	12.7572	15.2949	13.1687
24	16.118	14.8834	13.786	13.786	15.4321	12.8258	13.1687
Max	16.118	17.4897	17.284	18.9987	16.5981	17.7641	17.1468
Min	1.7833	2.6749	11.8656	11.3855	12.7572	8.9849	11.1797
Avg	3.7523	13.2850	14.6891	15.1349	14.7548	14.5976	14.7805