

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 201 / 11 Kv Hutatma

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6838	.6602	.6722	.6584	.6838	.6219	.7095
2	.6838	.6602	.6722	.6584	.6838	.6283	.7095
3	.7095	.6602	.6535	.6767	.6838	.5914	.7095
4	.7392	.6602	.6535	.6401	.7095	.5914	.7468
5	.8316	.7545	.7282	.695	.7468	.6348	.8316
6	.8871	.9149	.8686	.8145	.7842	.7468	.9055
7	.905	.8589	.9055	.8145	.8501	.8029	.9593
8	.6878	.7421	.724	.5792	.7095	.6516	.5973
9	.6468	.6516	.6697	.4525	.5792	.6516	.5316
10	.6335	.724	.6024	.394	.0259	.5548	.591
11	.631	.724	.5552	.4163	.6447	.5552	.6335
12		.5973	.7343		.591	.6626	.6516
13		.6697	.7522		.6516	.6089	.8145
14	.7059	.6335	.7522		.6154	.6516	.8145
15	.7059	.5611	.6584		.6154	.6584	.6516
16	.7059	.6401	.695		.7133	.5121	.6697
17	.6733	.6401	.6805		.6805	.5973	.6516
18		.5847	.7133		.7164	.6201	.6661
19	.905	.8238	.9145		.8238	.8688	.7602
20	.9694	.8686	.9694		.8596	.9877	.8962
21	.9795	.8871	1.0059		.8775	.9795	.9149
22	.8299	.8686	.9335		.8131	.8775	.9149
23	.7356	.8029	.9335		.7468	.8131	.9149
24	.7095	.6979	.6722	.6767	.7392	.6401	.7655
Max	.9795	.9149	1.0059	.8145	.8775	.9877	.9593
Min	.631	.5611	.5552	.394	.0259	.5121	.5316
Avg	.7600	.7203	.7550	.6230	.6894	.6879	.7505

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 202 / 11 Kv Walwa Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.2715	.2772	2.4587	2.5652	2.5434	2.431
2	.181	.2715	.2772	2.3739	2.4646	2.4813	2.431
3	.1991	.2715	.2772	2.3739	2.431	2.4813	2.3807
4	.2172	.2715	.2772	2.3739	2.431	2.4478	2.4813
5	.2715	.3077	.2987	2.4078	2.696	2.4478	2.5604
6	.2715	.3544	.3174	2.4078	2.7469	2.4417	2.6282
7	.3077	.3189	.3258	2.713	2.8317	2.4417	2.649
8	.3077	.3174	.2801	.3077	.3174	.2587	.2572
9	2.9675	3.0182	.2353	.2353	.2614	.2241	2.9508
10	2.9675	3.2922	.2263	.2328	.2075	.2452	2.7469
11	3.0178	.6767	.2075	.2263	.2263	.2452	2.8826
12	2.3472	.6767	.2452			.2263	2.9165
13	2.5434	3.4389	.2452			.2641	2.9673
14	2.6282	3.2579	.2452		.3018	.2641	3.086
15	2.6322	2.9492	.2452		.3018	.2452	2.9504
16	2.6155	3.1207	.2452		.2641	.2263	2.713
17	.1886	.2172	.2829		.2829	.2263	.2715
18		.2103	.2641		.3018	.2263	.2829
19	.2987	.298	.2641		.3206	.2987	.2987
20	.362	.3258	.2641		.3772	.3292	.3292
21	.3439	.3475	.3109		.3961	.3292	.3258
22	.3258	.3511	3.2007		3.0521	2.6322	.3109
23	.2896	.2801	2.8656		2.6993	2.6282	.2926
24	.2561	.2926	.2772	2.713	2.5652	2.5434	2.431
Max	3.0178	3.4389	3.2007	2.713	3.0521	2.6322	3.086
Min	.181	.2103	.2075	.2263	.2075	.2241	.2572
Avg	1.1183	1.0474	.4981	1.7353	1.3655	1.1957	1.8990

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 203 / 11 Kv.Bawachi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.7435	2.5789		2.0119	2.0485	2.0485
2		2.7435	2.5972		2.0119	2.0851	2.0485
3		2.7435	2.5789		2.0485	2.0851	2.0851
4	2.3529	2.7435	2.7252		2.0485	2.1948	2.1033
5	2.3529	2.7435	2.8349		2.1948	2.4874	2.396
6	2.6244	3.0178	2.8898		2.3594	2.963	2.524
7	2.9864	2.8715	3.091		2.4508	2.9813	2.652
8	2.9864	2.9264	3.1642		2.524	2.9995	2.6337
9	3.0769	3.1824	3.0178		2.9447	2.8166	2.7618
10	3.1093	3.0178	3.0544		2.963	2.8166	2.7435
11	3.1276	2.9264	2.9447	.1886	2.2497	2.9874	2.7435
12	2.4874	2.9264	2.7435		2.2497	2.9264	2.5606
13	2.1216	2.8349	2.9264		1.9753	2.6703	2.7435
14	2.3228	2.8349	2.9264		2.0119	2.6703	2.7149
15	2.7435	2.8669	2.9995		1.957	2.6886	2.7149
16	2.4508	2.524	2.9264		.8596	.8962	1.8099
Max	3.1276	3.1824	3.1642	.1886	2.963	2.9995	2.7618
Min	2.1216	2.524	2.5789	.1886	.8596	.8962	1.8099
Avg	2.6368	2.8529	2.8750	.1886	2.1788	2.5198	2.4552

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 204 / 11 KV Padawalwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.4746	1.3603	.1886	.2452	.2263	.2263
2	1.9433	1.4746	1.3279	.1886	.2263	.1886	.2263
3	1.9433	1.4575	1.3279	.1886	.1886	.1886	.1886
4	1.9433	1.6194	1.4737	.2452	.1886	.1867	.1886
5	2.1052	1.6194	1.5546	.2641	.1886	.2241	.2263
6	2.1862	1.7814	1.9109	.3395	.2263	.2926	.2829
7	2.13	1.8947	1.6842	.3395	.3584	.3658	.3018
8	.2829	.2686	.2452	.3206	.3584	.3045	.2641
9	.2263	.2715	2.3967	2.7206	3.0121	2.915	.2263
10	.2075	.2686	2.3967	2.8121	2.9797	2.7044	.1886
11	.2075	.2507	2.3594	2.6063	2.5911	2.4939	.1886
12	.2452	.2353	2.1956		2.0081	2.332	.2075
13	.2452	.2263	1.9662		2.1862	2.0891	.1886
14	.2452	.2075	1.9662		2.0891	2.0243	.1663
15	.2452	.2075	2.0972		.1219	2.0891	.1698
16	.2263	.2452	1.8947		1.8947	1.8947	.1753
17	.2263	.2452	.2587		.2641	.2218	.2896
18	.2829	.2452	.2402		.3018	.2452	.3439
19	.3206	.2641	.3658		.3395	.3018	.3801
20	.3395	.2829	.2587		.3395	.3395	.4066
21	.3206	.2829	.2641		.3584	.3018	.3696
22	1.8233	1.6518	.2263		.3018	.2641	2.4939
23	1.6712	1.4899	.2263		.2263	.2263	.3206
24	2.17	1.5402	1.3765	.2075	.2452	.2263	.2641
Max	2.1862	1.8947	2.3967	2.8121	3.0121	2.915	2.4939
Min	.2075	.2075	.2263	.1886	.1219	.1867	.1663
Avg	.9783	.8127	1.3073	.8684	.8850	.9436	.3452



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 205 / 11 KV Hutatma Dudh Sangh NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1509	.1509	.1509	.132	.2263	.1886
2	.0943	.1509	.1509	.1132	.1132	.1886	.1698
3	.0943	.1509	.1509	.0943	.0943	.1886	.1509
4	.0943	.1509	.132	.1132	.0943	.1509	.0943
5	.0943	.132	.1132	.1132	.0943	.1509	.0943
6	.0943	.132	.0943	.1132	.0943	.1132	.0943
7		.1132	.1132	.0943	.0943	.1132	.1132
8		.0943	.0943	.1132	.0943	.0943	.1132
9	.1132	.132	.1132	.1132	.132	.132	.1132
10		.1886	.1886	.2075	.1698	.1509	.1132
11		.1886	.1886	.2075	.1886	.2075	.1886
12		.1886	.2263		.2075	.2452	.2829
13		.2829	.2263		.2829	.2452	.2829
14		.2263	.2263		.1886	.132	.1698
15	.1132	.1886	.1698		.1698	.1509	.1509
16	.1132	.1509	.1886		.132	.1509	.1698
17	.1132	.2641	.2075		.132	.1886	.1698
18	.1132	.1698	.2075		.1886	.2263	.1886
19	.1698	.1698	.2075		.2263	.2452	.2829
20	.1509	.132	.2263		.3018	.1886	.1886
21	.2829	.1886	.2075		.3395	.2075	.1886
22	.2075	.1698	.1886		.2075	.1886	.1886
23	.1886	.2452	.1886		.1886	.1886	.2263
24	***	.1886	.1698	.1886	.1509	.2263	.1886
Max	13.3539	.2829	.2263	.2075	.3395	.2452	.2829
Min	.0943	.0943	.0943	.0943	.0943	.0943	.0943
Avg	.9109	.1729	.1721	.1352	.1674	.1792	.1713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 206 / 11KV Ahirwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3361	.3174	.3077	.2987	.2926	.3018
2	.2896	.3361	.3174	.3077	.2614	.2926	.3018
3	.2896	.3361	.3174	.3077	.2614	.2587	.2641
4	.2896	.3361	.3547	.3258	.3142	.2587	.2641
5	.2896	.3734	.3511	.3982	.3142	.2987	.2641
6	.3982	.4481	.3696	.4163	.3361	.3361	.2987
7	.362	.3734	.4066	.3658	.3511	.3403	.2896
8	.3077	.3511	.2896	.362	.2957	.2926	.2896
9	.362	.3258	.2658	.2883	.3077	.2481	.3439
10	.3258	.2715	.2515	.285	.2543	.2155	.3077
11	.2835	.2715	.2103	.285	.2543	.1928	.2715
12	.2865	.2896	.2374		.2601	.2658	.2534
13	.2865	.3258	.2715		.2715	.2561	.2715
14	.2896	.2534	.2715		.2534	.2561	.2715
15	.2957	.2353	.2587		.2172	.2561	.2715
16	.3142	.2534	.2804		.3077	.2534	.2715
17	.2658	.2804	.2804		.3121	.3189	.2658
18	.2743	.2804	.2774		.2915	.2896	.2515
19	.4207	.3982	.3696		.4163	.4287	.3982
20	.5228	.4481	.4251		.4298	.5544	.5304
21	.5041	.4668	.439		.4477	.5041	.499
22	.4481	.4294	.3658		.362	.4294	.4668
23	.3734	.3547	.3292		.3475	.3439	.3206
24	.3361	.3547	.3174	.3109	.2987	.3109	.3206
Max	.5228	.4668	.439	.4163	.4477	.5544	.5304
Min	.2658	.2353	.2103	.285	.2172	.1928	.2515
Avg	.3385	.3387	.3156	.3300	.3110	.3123	.3162

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 207 / 11KV Nagthane AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0566	.0566	.7287	.8097	.924	1.8652
2	.0377	.0566	.0566	.7287	.7773	.8779	1.8328
3	.0566	.0566	.0566	.7287	.7773	.8596	1.8328
4	.0566	.0566	.0566	.7287	.7773	.8238	1.7242
5	.0566	.0566	.0566	.7287	.7773	.8501	1.7404
6	.0566	.0566	.0754	.7773	.8097	.8871	1.7566
7	.0566	.0754	.0754	.7773	.8421	.9054	1.8814
8	.0754	.0566	.0754	.0566	.0566	.0566	.6663
9	1.4146	1.1174	.0566	.0566	.0069	.0566	2.2929
10	1.1984	1.1888	.0566	.0566	.0754	.0754	2.2672
11	1.1822	1.1336	.0566	.0377	.0754	.0566	2.2767
12		1.2483	.0566			.0754	2.3529
13			.0754			.0566	2.4291
14	1.1498	1.0526	.0754		.0754	.0566	2.3481
15	1.1498	1.0526	.0754		.0754	.0566	2.2719
16	1.0688	1.0526	.0566		.0754	.0566	2.191
17	.0566	.0566	.0566		.0566	.0566	.6663
18	.0754	.0754	.0566		.0566	.0566	.0754
19	.0754	.0754	.0566		.0566	.0754	.0566
20	.0566	.0754	.0566		.0566	.0754	.0754
21	.0566	.0754	.0566		.0566	.0754	.0566
22	.0754	.0566	.8478		.9431	.7773	.0566
23	.0754	.0754	.8478		.8676	.8259	.0566
24	.0377	.0566	.0566	.6478	.8421	.9431	.8745
Max	1.4146	1.2483	.8478	.7773	.9431	.9431	2.4291
Min	.0377	.0566	.0566	.0377	.0069	.0566	.0566
Avg	.3685	.3854	.1272	.5045	.4067	.3984	1.4020

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 208 / 11KV Kisan No 3 LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0183	.0181	.0181	.0181	.0181
2	.0566	.0183	.0181	.0181	.0181	.0181
3	.0514	.0183	.0181	.0181	.0181	.0724
4	.0566	.0183	.0181		.0181	.0724
5	.1294	.0183	.0181	.0181	.0181	.0724
6	.237	.2149	.1795	.0181	.0181	.1124
7	.2566	.2358	.2332	.0181	.0181	.2229
8	.4597	.4192	.2305	.0181	.0181	.2576
9	.4891	.4611	.2494	.0181	.0181	.4795
10	.4799	.4779	.232	.0181	.0181	.4761
11	.4742	.476	.2305	.0181	.0181	.4769
12	.4735	.4565	.2293	.0181	2.332	.4769
13	.4531	.4538	.2293	.0181	2.0891	.4735
14	.4599	.463	.2282	.0181	.0181	.4723
15	.4761	.463	.2278	.0181	.0181	.0678
16	.1633	.4748	.2278	.0181	.0181	.2509
24	.0004					
Max	.4891	.4779	.2494	.0181	2.332	.4795
Min	.0004	.0183	.0181	.0181	.0181	.0181
Avg	.2797	.2930	.1618	.0181	.2922	.2513

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 401 / 33KV Walwa LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3306	1.7558	1.5364	.6584	.7682	.9877
2	1.386	1.7558	1.5364	.6584	.8779	1.2071
3	1.3306	1.7558	1.5364	.9877	.8779	1.3169
4	1.7187	1.7558	1.6461	.9877	1.3169	1.3169
5	1.7187	1.9753	1.7558	1.2071	1.4266	1.5364
6	1.7187	1.9753	1.8656	1.4266	1.6461	1.5912
7	1.7187	1.8107	1.9753	1.4266	1.9753	1.9204
8	1.7187	1.7558	1.9753	1.4266	1.8656	1.8107
9	1.7741	2.0302	1.9753	1.5912	.7133	1.8656
10	1.7558	2.0851	1.9753	1.9753	.7133	1.8656
11	2.0851	2.0302	1.9753	1.9753	.7133	1.8656
12	1.262	2.0302	1.9753	1.9753	1.701	1.8656
13	1.5364	2.0302	1.9204	1.9204	1.9204	1.8656
14	1.701	2.0302	1.9204	1.8656	1.9204	1.8656
15	1.8107	1.6461	1.9204	1.8656	1.9753	1.8656
16	1.262	1.6461	1.3169	1.3169	1.262	1.8656
Max	2.0851	2.0851	1.9753	1.9753	1.9753	1.9204
Min	1.262	1.6461	1.3169	.6584	.7133	.9877
Avg	1.6142	1.8793	1.8004	1.4540	1.3546	1.6633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 201 / 11 Kv. Shigaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0394	.04	.0526	1.07	1.07	.9869	.8688
2	.04	.04	.0533	1.0402	.9511	.9164	.8362
3	.0423	.04	.0549	1.0235	.9031	.8573	.8173
4	.0463	.0343	.0564	.9957	.8916	.8688	.7095
5	.0457	.0343	.0572	.9633	.9181	.8688	.6859
6	.0457	.0343	.0594	.9633	.9181	.8509	.7482
7	.044	.0343	.0533	.9755	.8949	.8509	.7922
8	.0326	.032	.0434	.0495	.0234	.0291	.0351
9	1.6461	1.4842	.0337	.0309	.0269	.04	1.4074
10	1.6762	1.5466	.0343	.0549	.0225	.0171	1.4969
11	1.5339	1.6004	.0332	.04	.0343	.032	1.2944
12	1.358	1.4175	.0297			.0171	1.3426
13	1.406	1.1296	.0332			.024	1.2803
14	1.1584	1.1584	.0337		.04	.0286	1.1145
15	1.1888	1.1279	.0366		.04	.028	1.07
16	.9002	1.0536	.0335		.04	.0263	1.0254
17	.0686	.04	.0366		.0343	.0343	.0274
18	.0457	.0394	.0412		.061	.0442	.0274
19	.0452	.0777	.0472		.061	.0343	.032
20	.0457	.0766	.0503		.061	.032	.0518
21	.0457	.0629	.0396		.0686	.0297	.0343
22	.0594	.0472	1.3435		1.6118	1.1138	.0354
23	.0594	.0465	1.2346	1.2793	1.1126	1.0254	.0377
24	.0377	.061	.0419	1.1138	1.1294	1.057	.8977
Max	1.6762	1.6004	1.3435	1.2793	1.6118	1.1138	1.4969
Min	.0326	.032	.0297	.0309	.0225	.0171	.0274
Avg	.4838	.4691	.1472	.7385	.4961	.4089	.6945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 202 / 11 Kv. Bhadkambe LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3658	.3734	.2263	.3772	.3658
2	.3881	.3658	.3734	.2263	.3658	.3696
3	.3841	.3658	.3881	.2263	.3658	.3696
4	.3801	.3658	.3881	.2263	.3734	.3841
5	.3801	.3658	.3881	.2263	.3658	.3841
6	.3982	.3658	.4066	.2263	.3658	.3841
7	.4163	.3658	.3841	.0934	.3658	.3841
8	.3898	.3658	.3801	.2172	.3841	.3801
9	.3982		.3881	.2172	.3658	.4108
10	.4207	.3658	.3881	.3797	.3841	.4066
11	.3658	.3658	.3841	.4024	.0914	.0019
12	.3658	.3881	.3841	.3658	.3881	.3881
13	.3658	.3841	.3801	.3658	.3658	.3881
14	.3658	.3696	.3801	.3658	.3881	.3881
15	.3658	.3696	.3761	.3658	.3696	.3841
16	.2378	.2427	.218	.2195	.2218	.2353
Max	.4207	.3881	.4066	.4024	.3881	.4108
Min	.2378	.2427	.218	.0934	.0914	.0019
Avg	.3743	.3608	.3738	.2719	.3462	.3515

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 203 / 11 Kv.Pokharni Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0747	.0747	.0914	.0716	.0895	.0895
2	.0914	.056	.0747	.0914	.0716	.0895	.0914
3	.0905	.0747	.0924	.0905	.0724	.0876	.0914
4	.1086	.0747	.0914	.0905	.0905	.0876	.1086
5	.1267	.112	.0924	.0895	.1086	.1052	.1254
6	.128	.112	.1109	.0905	.1267	.12	.1433
7	.1063	.1307	.1052	.0924	.12	.1372	.0867
8	.0848	.1097	.0474	.0876	.064	.0857	.0819
9	.0876	.1097	.0648	.0625	.0617	.0857	.1147
10	.1075	.1311	.0655	.0663	.0648	.1052	.08
11	.1658	.1029	.0762	.0671	.0671	.081	.1204
12	.1029	.096	.0903			.081	.1265
13	.1029	.1006	.0937			.0829	.128
14	.1715	.116	.096		.1029	.0663	.1134
15	.1578	.1296	.0949		.1029	.0625	.0949
16	.1227	.128	.0781		.0857	.0762	.0762
17	.1052	.1448	.08		.0914	.0781	.0762
18	.0781	.1097	.08		.0343	.0633	.0297
19	.1307	.128	.12		.1219	.1187	.116
20	.112	.1448	.1417		.1372	.1417	.1417
21	.1494	.1254	.1254		.1017	.1417	.1267
22		.1075	.128		.1029	.1433	.1086
23	.0934	.0905	.1086	.1086	.1052	.1227	.0724
24	.0905	.0747	.0895	.0905	.0895	.1097	.1063
Max	.1715	.1448	.1417	.1086	.1372	.1433	.1433
Min	.0781	.056	.0474	.0625	.0343	.0625	.0297
Avg	.1133	.1077	.0926	.0861	.0907	.0984	.1021



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 204 / 11 Kv Shigaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.2641	.3206	.3018	.3018	.2641	.3018
2	.3326	.2641	.3174	.3018	.3018	.2641	.3018
3	.3361	.2641	.3361	.3206	.3018	.2641	.3395
4	.3584	.3174	.3395	.3206	.3206	.3206	.3395
5	.415	.3361	.3547	.3206	.3395	.3395	.3772
6	.4854	.3511	.3772	.3395	.3772	.3734	.4338
7	.462	.3696	.3881	.3696	.3696	.3734	.3881
8	.3045	.3326	.3012	.2865	.3012	.2801	.3366
9	.3077	.2686	.2454	.2774	.2658	.2614	.3012
10	.3012	.2743	.2279	.2572	.2279	.2402	.2629
11	.2481	.2561	.2454	.2427	.2279	.2303	.2427
12	.2303	.2481	.2427		.2058	.2835	.2804
13	.2378	.3224	.2629	.2915	.2279	.3366	.2835
14	.2303	.3077	.2686		.2507	.3403	.2896
15	.2303	.2957	.2835		.2195	.3366	.2743
16	.2328	.2926	.2774		.2303	.3189	.2534
17	.2534	.2926	.2743		.2279	.3086	.2572
18	.2713	.3326	.2818		.2713	.2883	.2515
19	.3721	.3734	.4119		.3582	.4075	.3856
20	.4119	.4294	.4755		.4435	.4706	.4706
21	.3734	.4066	.4251		.3696	.439	.4435
22		.3734	.3772		.3361	.3961	.4108
23	.3395	.3584	.3018	.3584	.3206	.3772	.3584
24	.3395	.3018	.3206	.3018	.3018	.2829	.3018
Max	.4854	.4294	.4755	.3696	.4435	.4706	.4706
Min	.2303	.2481	.2279	.2427	.2058	.2303	.2427
Avg	.3220	.3180	.3190	.3064	.2958	.3249	.3286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 205 / 11 Kv Pokharni Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.888	.6859	.6019	.0716	.0514	.0678	.0686
2	.884	.6859	.5944	.0709	.0514	.0678	.0693
3	.8488	.7649	.5647	.0724	.0543	.0457	.0716
4	.8749	.7859	.5719	.0739	.0724	.0457	.0724
5	.8796	.8573	.5569	.0732	.0732	.0553	.0905
6	.8688	.9328	.5792	.0739	.0924	.0543	.1097
7	.8993	.9602	.643	.0716	.0886	.0617	.0838
8	.0532	.0676	.0705	.0671	.0701	.0442	.0633
9	.052	.0648	.9957	1.3375	1.3272	1.3108	.0514
10	.052	.0667	1.0822	1.07	1.2037	1.4022	.0474
11	.0511	.0533	1.07	1.1439	1.2498	1.0185	.0625
12	.0427	.0503	1.0562	1.0686	1.1317	.9568	.0509
13	.0457	.0602	.9412	.9065	1.1317	.8916	.0514
14	.0465	.0678	.9145		1.0288	.8322	.0457
15	.0472	.0514	.8741		1.0288	.7529	.061
16	.0457	.0503	.823		.7145	.7002	.0351
17	.0533	.0509	.0556		.032	.0274	.0442
18	.0267	.0503	.0556		.0419	.04	.061
19	.0457	.0671	.0655		.0396	.0857	.0829
20	.0533	.0829	.0701		.0457	.0857	.0876
21	.0857	.0819	.0678		.0495	.0857	.0905
22	.743	.7133	.0732		.0503	.0886	1.2492
23	.7145	.6516	.0543	.0655	.0857	.0686	1.1138
24	.8916	.6222	.5424	.0693	.064	.0857	.0655
Max	.8993	.9602	1.0822	1.3375	1.3272	1.4022	1.2492
Min	.0267	.0503	.0543	.0655	.032	.0274	.0351
Avg	.3831	.3552	.5385	.4157	.4074	.3698	.1596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 206 / Hutatma Sureshkumar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2241	.2587	.0191	.1132	.181
2	.2587	.2241	.2587	.0191	.1132	.1848
3	.2587	.2614	.2743	.0191	.132	.2378
4	.2801	.2614	.2743	.0191	.132	.2743
5	.2957	.2801	.2743	.0191	.1509	.2743
6	.2957	.2987	.2926	.0191	.1509	.2743
7	.2743	.2987	.2715	.0191	.1698	.2743
8	.2743	.2926	.2743	.0191	.1698	.2896
9	.2715	.2926	.2743	.0191	.1698	.2715
10	.2896	.2926	.2715	.1294	.132	.2743
11	.2926	.2926	.2715	.1294	.1698	.2772
12	.2926	.2743	.2926	.3018	.2926	.2957
13	.2926	.2743	.2743	.2926	.1829	.2743
14	.3658	.2715	.2743	.2926	.181	.2743
15	.2926	.2715	.2772	.2926	.181	.2772
16	.2926	.2715	.0189	.2926	.1829	.2772
Max	.3658	.2987	.2926	.3018	.2926	.2957
Min	.2378	.2241	.0189	.0191	.1132	.181
Avg	.2853	.2739	.2583	.1189	.1640	.2633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 207 / 11KV Bahadurwadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0175	.0171	.431	.4344	.4012	.3668
2	.0187	.0175	.0175	.4214	.4054	.3961	.3475
3	.0187	.0175	.0171	.4108	.3814	.3961	.3668
4	.0185	.0183	.0173	.431	.3814	.3765	.3864
5	.0187	.0183	.0179	.4458	.3864	.3765	.3814
6	.0377	.0183	.0362	.4666	.4012	.3715	.3909
7	.0377	.0183	.0526	.4401	.3948	.3715	.4001
8	.0332	.0183	.0503	.0149	.016	.037	.0339
9	.6173	.5117	.0171	.0143	.0158	.0187	.571
10	.703	.5796	.0173	.0154	.0151	.0171	.5647
11	.6481	.5944	.017	.0156	.0152	.0177	.4401
12	.5418	.5281	.016			.017	.535
13	.5792	.4572	.0328			.0305	.5213
14	.4287	.4548	.0332		.0179	.0164	.423
15	.4458	.4489	.0332		.0181	.0166	.4572
16	.3429	.4287	.0162		.0179	.0151	.443
17	.0171	.0171	.0332		.0179	.0156	.0145
18	.0166	.0173	.0335		.0305	.0162	.0149
19	.0168	.0175	.0347		.0164	.0183	.017
20	.0168	.0171	.0362		.0168	.0354	.0366
21	.0057	.0168	.0347		.0171	.0366	.0366
22	.0173	.0164	.5401		.5001	.4694	.037
23	.0173	.016	.5117	.5135	.4172	.4344	.0187
24	.0183	.0175	.016	.4401	.4633	.4012	.3666
Max	.703	.5944	.5401	.5135	.5001	.4694	.571
Min	.0057	.016	.016	.0143	.0151	.0151	.0145
Avg	.1931	.1785	.0687	.3123	.1991	.1793	.2988

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 401 / 33KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.9619	.7356	.7922	.8488	.679
2	.8488	.9619	.8488	.9054	.7922	.679
3	.9054	.9619	.8488	.9619	.7922	.679
4	.9619	.9619	.9619	.9619	.9619	.679
5	.9619	.9619	.9619	.9619	.9619	.679
6	.9619	.9619	.9619	.9619	.9619	.679
7	.9619	.9619	.9054	.9619	.9619	.679
8	.9054	.9619	.9054	.9619	.9619	.679
9	.9619	.9619	.9619	.9619	.9619	.7356
10	.9619	.9619	.9619	.9619	.9619	.6653
11	.9619	.9619	.4527	.9619	.4435	.2241
12	.9619	.9054	.4527	.9619	1.0082	.679
13	.9619	.9054	.4527	.9619	.9619	.679
14	.9619	.9054	.7356	.9619	.7922	.679
15	.9054	.9054	.743	.9619	.7922	.679
16	.5658	.7356	.5144	.7356	.679	.5716
24					.9619	
Max	.9619	.9619	.9619	.9619	1.0082	.7356
Min	.5658	.7356	.4527	.7356	.4435	.2241
Avg	.9124	.9336	.7753	.9336	.8709	.6465

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 201 / 11 KV Krishnamai AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2086	1.2548	.9808	1.1172
2				1.1911	1.2548	.9709	1.124
3				1.1567	1.2007	.9488	1.0759
4				1.1987	1.2056	.9488	1.0925
5				1.1736	1.2094	.8992	1.0629
6				1.1729	1.2376	.9252	1.0399
7				1.1816	1.1686	.9046	1.0539
8	.2561	.1661					.1943
9	1.7048	1.5722					1.3344
10	1.752	1.4609					1.592
11	1.7833	1.4799					.8749
12	1.6507	1.4739					1.3618
13	1.7864	1.3515					1.6209
14	1.7978	1.3138					1.603
15	1.7871	1.3176					1.6623
16	1.7356	1.264					1.6781
21			.2172	.1959	.1585	.1509	
22			1.1845	.618	1.0323	1.089	
23			1.2227	1.2629	1.0296	1.1576	
24			.644	1.2353	1.1084	1.0798	.5344
Max	1.7978	1.5722	1.2227	1.2629	1.2548	1.1576	1.6781
Min	.2561	.1661	.2172	.1959	.1585	.1509	.1943
Avg	1.5838	1.2667	.8171	1.0541	1.0782	.9141	1.1778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 202 / 11KV Mahalaxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2197	.924	.9522	1.2382	1.2437	1.2197
2	1.2567	.924	.9522	1.2567	1.2437	1.2323
3	1.2567	.924	.961	1.2567	1.2437	1.251
4	1.2567	.924	.961	1.2752	1.2437	1.251
5	1.2752	.924	.9522	1.2752	1.2437	1.251
6	1.2752	.924	.9709	1.2936	1.2437	1.2254
7	1.2752	.961	1.0719	1.2536	1.2936	1.2437
8	1.262	.961	1.0719	1.386	1.3169	1.2803
9	1.3169	.9795	1.0534	1.3491	1.3169	1.3676
10	1.3676	1.0456	.8131	1.3676	1.3169	1.3306
11	1.3306	1.0456	.9877	1.3817	1.134	
12	1.0829	1.0349	1.0059	1.3253	1.2936	1.3121
13	.961	.9877	.9671	1.3535	1.2936	1.267
14	.961	.9979	1.2851	1.3535	1.2803	1.262
15	.9709	.9795	1.2851	1.2803	1.2803	1.2936
16	.8478	.9795	1.2308	1.2936	1.2803	1.2936
24	.0257					
Max	1.3676	1.0456	1.2851	1.386	1.3169	1.3676
Min	.0257	.924	.8131	1.2382	1.134	1.2197
Avg	1.1142	.9698	1.0326	1.3087	1.2668	1.2721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 203 / 11KV Yashwant AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8383	.9054	.6554	.8048
2				.8139	.9054	.663	.788
3				.7956	.8886	.663	.788
4				.7969	.8648	.663	.779
5				.788	.8648	.663	.7712
6				.78	.8648	.7625	.7545
7				.7625	.8192	.7377	.8478
9	1.5261	1.3717					1.3717
10	1.6804	1.406					1.3889
11	1.6461	1.5089					
12	1.4243	1.4582					1.3904
13	1.4243	1.3735					1.3748
14	1.4419	1.3226					1.0898
15	1.4419	1.1869					1.2378
16	1.3748	1.1191					1.17
22			.8478		.8383	.8718	
23			.8987	.9054	.7865	.8551	
24				.8718	.7865	.7865	.8122
Max	1.6804	1.5089	.8987	.9054	.9054	.8718	1.3904
Min	1.3748	1.1191	.8478	.7625	.7865	.6554	.7545
Avg	1.4950	1.3434	.8733	.8169	.8524	.7321	1.0246



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 204 / 11 KV Ashta PWW

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.157	.1563	.157	.157	.157	.1555	.1555
2	.157	.1577	.1578	.1563	.1562	.1555	.1555
3	.1578	.1577	.1593	.1563	.1562	.1555	.1562
4	.1578	.1577	.1578	.157	.1562	.1555	.1562
5	.1585	.1577	.1578	.1563	.157	.1563	.1562
6	.1585	.1577	.1585	.1577	.1578	.1563	.1562
7	.1577	.1563	.1585	.1555	.157	.1563	.1563
8	.1555	.1562	.1562	.1555	.1555	.1562	.1547
9	.1585	.1578	.1555	.1555	.1585	.1585	.1563
10	.1601	.1578	.157	.0854	.1585	.1578	.1578
11	.1601	.1578	.1563	.0587	.1601	.1578	.0854
12	.0869	.1578	.1563		.1593	.157	.1578
13	.1555	.1547	.1547		.157	.1563	.1555
14	.1562	.1555	.1555	.0038	.157	.1547	.1554
15	.1562	.1555	.1563	.0869	.1547	.1547	.157
16	.0846	.1563	.0846	.0846	.1547	.1547	.1562
17	.1547	.1555	.1547	.0838	.1547	.1547	.1554
18	.1547	.1555	.1555	.0838	.1547	.1547	.1539
19	.1562	.157	.1562	.0838	.1554	.1547	.154
20	.1555	.1555	.1563	.0846	.1562	.1555	.1532
21	.157	.1563	.1563	.0846	.1562	.0846	.1562
22	.1585	.157	.1585	.0854	.1539	.1555	.1562
23	.1585	.1563	.1577	.1563	.1539	.1555	.157
24	.157	.1563	.1555	.1562	.1562	.1539	.1555
Max	.1601	.1578	.1593	.1577	.1601	.1585	.1578
Min	.0846	.1547	.0846	.0038	.1539	.0846	.0854
Avg	.1513	.1567	.1537	.1157	.1564	.1528	.1529

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 205 / 11KV Tryambkeshwar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.0739	.0747	.2427	.0914	.1753
2	.1097	.0739	.0739	.2427	.0914	.1734
3	.1267	.0739	.0739	.2427	.0914	.1753
4	.1267	.0739	.0747	.2427	.0914	.1734
5	.1267	.0739	.0747	.2427	.0914	.1734
6	.1267	.0739	.0747	.2427	.1417	.1734
7	.124	.0732	.0747	.2427	.2303	.1772
8	.1734	.1753	.1772	.2427	.2303	.1753
9	.1949	.1753	.2254	.2454	.2303	.1734
10	.1772	.1772	.2254	.2454	.2303	.1949
11	.1772	.1772	.2229	.1433	.1433	
12	.0739	.1772	.2229	.1254	.1417	.0924
13	.1829	.1543	.2204	.1254	.1417	.0914
14	.1848	.2279	.2229	.1227	.1417	.0914
15	.1848	.2279	.2229	.1227	.1417	.0924
16	.1475	.2279	.2229	.1254	.1417	.0914
24	.0019					
Max	.1949	.2279	.2254	.2454	.2303	.1949
Min	.0019	.0732	.0739	.1227	.0914	.0914
Avg	.1382	.1398	.1553	.1998	.1482	.1483

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 206 / 11KV Dhadak LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3688	.4858	.3258	.2818	.2241	.8029
2	.3856	.4858	.3391	.2984	.2241	.8029
3	.3856	.4858	.3391	.2984	.2614	.8029
4	.3856	.5182	.3429	.2984	.2614	.8029
5	.3856	.5182	.3429	.2984	.2987	.7935
6	.3856	.5182	.3391	.2984	.2683	.8002
7	.3637	.8097	.8048	.5376	.7964	.8192
8	.8192	.8097	.8309	.9389	.8238	.852
9	.7373	.8421	.7956	.9054	.8954	.8684
10	.7545	.8718	.7459	.9496	1.0566	.8886
11	.6859	.9724	.8122	.9602	.4801	
12	.7042	.9724	.852	.9602	.8886	.9221
13	.7042	.8259	.8162	.9602	.8886	.8848
14	.8916	.7865	.8356	.9496	.8619	.6718
15	.8916	.6962	.8356	.6783	.8718	.9221
16	.9945	.3688	.7865	.6859	.8718	.5868
24	.0716					
Max	.9945	.9724	.852	.9602	1.0566	.9221
Min	.0716	.3688	.3258	.2818	.2241	.5868
Avg	.5832	.6855	.6340	.6437	.6233	.8147

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 201 / 11KV Bagni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4373	1.1934	1.1203	.0549	.056	.0554	.0914
2	1.4373	1.0974	1.1012	.0554	.056	.0554	.0924
3	1.4022	1.1111	1.085	.0549	.0566	.056	.0739
4	1.4022	1.1561	1.0562	.0554	.0566	.056	.0732
5	1.4022	1.1702	1.0722	.0549	.0754	.0747	.0914
6	1.3599	1.1843	1.1012	.0739	.0943	.0943	.0924
7	1.3763	1.2018	1.1683	.0754	.0934	.0732	.0914
8	.0549	.0895	.0716	.1075	.0739	.0895	.1109
9	.0554	.0732	1.5684	1.8623	1.6385	1.8947	.0732
10	.0914	.0358	1.8564	1.8343	1.7166	1.7604	.0724
11	.0924	.0554	1.8564	1.7078	1.9662	1.6762	.0724
12	.0914	.0724	1.7284	1.7166	1.8138	1.6248	.0732
13	.0924	.0739	1.5023		1.6324	1.5432	.0549
14	.0924	.0905	1.5655		1.6004	1.5466	.0554
15	.0914	.0895	1.5813		1.5684	1.4864	.0732
16	.0739	.0914	1.5339		1.4864	1.439	.0739
17	.0739	.0724	.0509		.0509	.048	.0895
18	.0924	.0532	.048		.052	.0474	.0886
19	.0934	.0739	.0648		.0716	.081	.1097
20	.0924	.0732	.0905		.0709	.096	.1294
21	.0732	.0732	.0732		.0716	.1097	.1294
22	1.247	1.2334	.0739		.0732	.0924	1.5043
23	1.1683	1.2003	.0739		.0732	.0924	1.4403
24	1.4373	1.1248	1.1203	.0554	.056	.0747	.0924
Max	1.4373	1.2334	1.8564	1.8623	1.9662	1.8947	1.5043
Min	.0549	.0358	.048	.0549	.0509	.0474	.0549
Avg	.6180	.5288	.9402	.5930	.6043	.5903	.2021

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 202 / 11KV Ashta Chadoli Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6249	.5182	.064	.0743	.0655	.0602
2	.6097	.6173	.4801	.0633	.0743	.064	.0594
3	.6097	.6097	.4801	.0633	.0743	.064	.061
4	.6173	.5792	.4641	.0625	.0734	.0655	.0617
5	.6173	.5719	.4744	.0633	.088	.081	.0762
6	.5864	.5647	.4744	.0791	.1027	.1134	.0926
7	.5864	.535	.5761	.1094	.088	.096	.0926
8	.0594	.048	.0781	.0972	.0734	.08	.0781
9	.0474	.0469	.7842	.7562	.7727	.8259	.0781
10	.0486	.0474	.8259	.8025	.787	.7537	.0625
11	.048	.064	.7373	.7164	.7842	.6081	.0457
12	.0648	.064	.7459	.7164	.7274	.6325	.0457
13	.0663	.0648	.7287		.6882	.6097	
14	.064	.064	.6226		.68	.6173	
15	.0474	.0791	.7459		.6882	.6249	.0594
16	.0663	.0791	.6325		.5898	.6325	.0594
17	.0838	.0781	.048		.048	.048	.0594
18	.0926	.0791	.064		.048	.0486	.0594
19	.1357	.096	.0625		.0972	.0829	.0734
20	.1296	.0972	.0972		.096	.0819	.088
21	.112	.0949	.0995		.0949	.0753	.088
22	.6962	.6562	.0937		.096	.0762	.7335
23	.6718	.6154	.0791		.081	.0743	.6097
24	.7869	.6478	.5668	.0633	.0743	.0648	.0594
Max	.7869	.6562	.8259	.8025	.787	.8259	.7335
Min	.0474	.0469	.048	.0625	.048	.048	.0457
Avg	.3107	.2927	.4366	.2813	.2917	.2703	.1229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 203 / 11KV SHIGAON RIVER AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0183	.0177	1.7364	1.8099	1.6289	1.829
2	.037	.0185	.0177	1.7193	1.8099	1.3765	1.922
3	.037	.0185	.0175	1.7375	1.829	1.3904	1.922
4	.037	.0185	.0179	1.7558	1.829	1.3748	1.9387
5	.0366	.0366	.0179	1.7375	1.829	1.4083	1.9589
6	.0366	.037	.0358	1.7013	1.9022	1.5432	1.9959
7	.0366	.037	.0362	1.7193	1.9387	1.5912	1.9547
8	.0366	.0366	.0362	.0549	.0362	.0358	.037
9	2.5072	2.3529	.0549	.037	.0366	.0362	2.5431
10	2.6505	2.5072	.0549	.037	.0362	.037	2.6223
11	2.7221	2.5431	.0549	.037	.0183	.037	2.4006
12	2.7069	2.4356	.0554	.037		.0366	2.5072
13	2.4394	2.4434	.0554			.037	2.5869
14	2.3891	2.364	.0739		.0358	.0366	2.6223
15	2.3282	2.3167	.0732		.0358	.037	2.5514
16	2.0774	2.2081	.0554		.0362	.0366	2.5072
17	.0543	.037	.0549		.0366	.0366	.0358
18	.0549	.0366	.0554		.0366	.037	.0351
19	.0554	.037	.0554		.037	.0366	.0351
20	.0549	.0366	.0549		.037		.0344
21	.0554	.0362	.0554		.0358	.0366	.0362
22	.0185	.0358	1.9022		1.7924	1.885	.0366
23	.0185	.0177	1.9022		1.7741	.037	.0366
24	.037	.0185	.0175	1.8111	1.8099	1.7558	1.8099
Max	2.7221	2.5431	1.9022	1.8111	1.9387	1.885	2.6223
Min	.0185	.0177	.0175	.037	.0183	.0358	.0344
Avg	.8527	.8186	.1989	1.0862	.8519	.6290	1.4983

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 205 / 11KV BAGNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3696	.3292	.2926	.3018	.3292	.3475
2	.3395	.3696	.3292	.2957	.3018	.3174	.3511
3	.3395	.3292	.3326	.2957	.3018	.3174	.3326
4	.3395	.3292	.3326	.2926	.3018	.3361	.3292
5	.3772	.3696	.3511	.2957	.3395	.3511	.3292
6	.4481	.3696	.3921	.3292	.3772	.3696	.3511
7	.3547	.3696	.3326	.3142	.3326	.3658	.3511
8	.3109	.3109	.3326	.2402	.2865	.3109	.2743
9	.2772	.3142	.3142	.2328	.2926	.3326	.2715
10	.2926	.3142	.2957	.2126	.2743	.3292	.2658
11	.3326	.3361	.3326	.197	.2957	.3142	.2774
12	.3326	.3326	.3511	.197	.2926	.3142	.2507
13	.3361	.3326	.3142		.3142	.3142	.3045
14	.3658	.3326	.3511		.3292	.3326	.3224
15	.3696	.3547	.3511		.3292	.3921	.362
16	.3292	.3361	.3511		.3077	.3696	.3045
17	.3696	.3326	.3511		.3326	.3696	.3086
18	.4024	.3326	.3881		.3696	.3696	.3353
19	.499	.4435	.4251		.462	.3547	.4252
20	.5175	.5041	.462		.499	.4066	.4805
21	.5121	.4668	.462		.462	.439	.4108
22	.4938	.4435	.462		.3921	.4066	.415
23	.4572	.4108	.4066		.3511	.3511	.3772
24	.3772	.4024	.3696	.3326	.3018	.3326	.3511
Max	.5175	.5041	.462	.3326	.499	.439	.4805
Min	.2772	.3109	.2957	.197	.2743	.3109	.2507
Avg	.3797	.3669	.3633	.2714	.3395	.3511	.3387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 201 / 11 Kv Ashta Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	1.6156
Max	1.6156
Min	1.6156
Avg	1.6156



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 202 / 11KV PATOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.192
Max	.192
Min	.192
Avg	.192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 203 / 11 KV Ashta Gaothan 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.8488
Max	.8488
Min	.8488
Avg	.8488

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 204 / 11KV BAWACHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6573	.711	.356	.6037	.6009	.3559	.6294
2	.6394	.6973	.3446	.5923	.5903	.3415	.5979
3	.615	.6534	.3284	.5933	.5628	.3392	.5938
4	.6523	.6592	.3261	.5723	.579	.3396	.5885
5	.7186	.7049	.3377	.5999	.5396	.3585	.5796
6	.8394	.7838	.4102	.6878	.6352	.4353	.7749
7	.7712	.7811	.45	.6922	.7466	.5026	.7484
8	.6535	.7034	.4183	.6762	.6304	.4078	.5767
9	.5517	.5853	.3323	.5998	.5144	.305	.5536
10	.5221	.5412	.3535	.4862	.4618	.3044	.5319
11	.4969	.2835	.5313	.4412	.2861	.446	.5254
12	.5224	.2713	.4856	.4298	.2694	.4209	.458
13	.5125	.2827	.5584	.2393	.3017	.4481	.4489
14	.5213	.2839	.5523	.2446	.2811	.4512	.3925
15	.5617	.2915	.5501	.2606	.2821	.4815	.4504
16	.5129	.2745	.5263	.2462	.2744	.4475	.5171
17	.5212	.2713	.5546	.2599	.2488	.4803	.474
18	.546	.2614	.4786	.266	.2579	.4917	.5197
19	.7305	.2958	.634	.2865	.3251	.6203	.619
20	.8757	.4413	.8027	.3628	.4427	.8063	.7038
21	.9023	.5054	.7258	.3742	.444	.7621	.7102
22	.871	.4589	.6893	.3574	.4152	.7118	.7331
23	.7669	.4335	.6893	.3628	.4093	.6916	.7356
24	.6778	.692	.3825	.6417	.3483	.3875	.6542
Max	.9023	.7838	.8027	.6922	.7466	.8063	.7749
Min	.4969	.2614	.3261	.2393	.2488	.3044	.3925
Avg	.6517	.4945	.4924	.4532	.4353	.4724	.5882

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 205 / 11 KV Bawachi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.3922	1.2688	.3887	.4096	.2365	.4102
2	2.6943	2.412	1.0067	.4081	.4089	.2399	.3868
3	2.6416	2.3685		.4089	.2411	.2388	.3894
4	2.6174	2.376		.3898	.4237	.2438	.4123
5	2.6585	2.3861		.4081	.2317	.2499	.4398
6	2.7709	2.5252		.5324	.2652	.2796	.5125
7	2.9043	2.685		.4977	.5335	.2872	.4557
8	.3593	.3726		1.0845	1.2433	.2309	.3997
9	.3704	.381		3.4514	3.4892	1.6653	.3662
10	.3498	.3772	2.0188	3.7344	3.3485	2.2607	.3593
11	.3849	.2004	3.3318	3.7097	2.0225	3.4156	.3458
12	.3757	.2119	3.2236	3.6298	2.027	3.5406	.3639
13	.3961	.2383	3.344	1.957	1.9835	3.5017	.3514
14	.3898	.2314	3.2571	1.6255	1.9308	3.3509	.3784
15	.3902	.2121	3.075	1.6743	1.8505	3.2427	.3742
16	.378	.1986	2.9546	1.2986	1.8066	2.4918	.3738
17	.4214	.2284	.3376	.1951	.206	.3376	.4007
18	.4351	.2259	.342	.2088	.2319	.2683	.4045
19	.4763	.2658	.4213	.2431	.27	.4201	.4473
20	.5502	.2921	.4871	.2507	.2849	.4893	.4725
21	1.0821	.6746	.4664	.2606	.2804	.4824	1.1151
22	2.5011	1.44	.4436	.2652	.2735	.4672	3.2338
23	2.6216	1.4066	.4228	.2469	.2669	.4298	3.2666
24	1.6396	2.2249	.2926	.4054	.2202	.2369	1.8825
Max	2.9043	2.685	3.344	3.7344	3.4892	3.5406	3.2666
Min	.3498	.1986	.2926	.1951	.206	.2309	.3458
Avg	1.3397	1.0970	1.5702	1.1364	1.0104	1.1920	.7309

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 206 / 11KV Ashta Pump House

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.7602	.076	.7964	1.6076	.956	1.688
2	.8413	.724	.0724	.7964	1.5491	.8546	1.6311
3	.8413	.695	.0742	.7682	1.4966	.8392	1.5777
4	.8596	.695	.0778	.7316	1.4533	.8236	1.5577
5	.8413	.7133	.0796	.7499	1.46	.8182	1.5345
6	.8413	.7316	.0796	.7865	1.5225	.8401	1.6133
7	.8596	.7682	.0814	.8048	1.696	.9114	1.7694
8	.823	.7602	.0778	.8048	1.6541	.9262	1.6545
9	.695	.724		.6335	1.5287	.9029	1.4616
10	.6767	.724	.0688	.7316	1.5829	.8269	1.531
11	.695	.0742	.8048	.7682	.9465	1.4319	1.5569
12	.6767	.0706	.8596	.7499	1.013	1.6552	1.6514
13	.6767	.076	.823		1.0522	1.7024	1.736
14	.7316	.0833	.7682		1.0436	1.669	1.7139
15	.7316	.076	.7316		.9652	1.672	1.7848
16	.7499	.076	.7499		.9194	1.4102	1.7177
17	.823	.0724	.7421		.8761	1.5792	1.6446
18	.8596	.076	.7602		.8239	1.6212	1.6035
19	.9877	.0887	.9593		.923	1.9199	1.8815
20	1.0608	.1032	1.0317		1.2497	2.2461	1.1485
21	1.0317	.0977	1.0059		1.2292	2.1655	.8771
22	.9412	.0923	1.0608		1.1794	2.1171	1.1629
23	.8688	.0887	.905		1.151	1.9521	1.9151
24	.8779	.7964	.0833	.8145	.9671	1.0971	1.8873
Max	1.0608	.7964	1.0608	.8145	1.696	2.2461	1.9151
Min	.6767	.0706	.0688	.6335	.8239	.8182	.8771
Avg	.8271	.3820	.5206	.7643	1.2454	1.3724	1.5958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 201 / 11KV KOREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8479	.8253	.7712	.7737	.773	.788	.8093
2	.8047	.7943	.7289	.7465	.7518	.7608	.7579
3	.8002	.7655	.7149	.7396	.7291	.7517	.7491
4	.804	.764	.7499	.757	.7049	.7712	.7796
5	.9206	.8089	.8082	.7669	.804	.8345	.8809
6	1.166	.9259	1.0267	.9815	1.0227	1.0745	1.0947
7	1.1416	1.028	1.0692	.9753	1.1694	1.0707	1.0646
8	.9088	.881	.8871	.841	.9229	.5262	.8657
9	.7909	.7865	.713	.7346	.7743	.7587	.7819
10	.807	.7819	.7384	.6366	.7095	.7952	.7785
11	.8122	.7503	.7731	.7121	.7539	.7272	.7056
12	.7729	.6732	.6733	.591	.7571	.6779	.7226
13	.7301	.6929	.6893	.3376	.6752	.6569	.6851
14	.7621	.7259	.7428	.3589	.6943	.7431	.7115
15	.7524	.7112	.7636	.4108	.7422	.7651	.7705
16	.7682	.7329	.7382	.3742	.7888	.7703	.7396
17	.7457	.7529	.7361	.3544	.7671	.7644	.7071
18	.8381	.7312	.8512	.4351	.7929	.807	.7339
19	1.0041	.8882	1.0625	.487	1.0166	.9639	1.0106
20	1.1845	1.1715	1.2529	.567	1.1877	1.2771	1.2216
21	1.2169	1.1526	1.1816	.5883	1.1355	1.2277	1.15
22	1.1591	1.0579	1.0732	.5914	1.0844	1.0867	1.0726
23	.9721	.9136	.9309	.5129	.9075	.9573	.934
24	.8806	.7979	.8184	.8207	.8108	.8383	.807
Max	1.2169	1.1715	1.2529	.9815	1.1877	1.2771	1.2216
Min	.7301	.6732	.6733	.3376	.6752	.5262	.6851
Avg	.8996	.8381	.8539	.6289	.8532	.8498	.8556

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 202 / 11KV Bhadurwadi AG  
(Koregaon) Feeder KV- 11 /  
OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2206	.2187	.1981	2.1602	2.0668	2.0142	2.1362
2	.2214	.2168	.1784	2.0037	2.0125	1.9204	2.0176
3	.2423	.1981	.0975	1.8917	1.9795	1.8519	1.9773
4	.2484	.192	.096	1.8096	1.864	1.8336	1.9334
5	.2484	.1896	.1292	1.8073	1.8587	1.7829	1.9067
6	.2601	.2214	.2057	2.002	1.9502	1.7598	1.9883
7	.2819	.2362	.2206	2.1856	2.0624	1.925	2.0646
8	.4237	.3504	.2789	.2473	.2147	.2309	.4841
9	3.2709	2.926	.2348	.2489	.2002	.2138	2.9052
10	3.3608	3.0485	.2576	.2511	.2614	.2086	3.1565
11	3.3379	3.0645	.2507	.2386	.2652	.2172	3.0441
12	3.2485	2.9904	.1973		.0914	.229	2.9001
13	3.1318	2.8896	.1911			.2279	2.8533
14	2.9523	2.8041	.1935		.2482	.2195	2.7612
15	2.8262	2.6924	.2225	.093	.2473	.2108	2.8201
16	2.809	2.6888	.2483	.1196	.2262	.2126	2.7953
17	.2092	.1878	.2553	.1212	.2363	.2348	.2226
18	.2182	.2165	.2423	.1273	.221	.2508	.229
19	.2378	.2256	.237	.1372	.2483	.2222	.2316
20	.2771	.229	.2282	.1456	.261	.2446	.257
21	.2316	.232	.4064	.192	.3332	.3543	.2588
22	.1995	.2313	2.5218	1.3451	2.3358	2.2611	.2313
23	.2202	.2088	2.4322	1.326	2.2497	2.2767	.179
24	.2161	.2191	1.3754	2.2329	2.1704	2.1811	1.0174
Max	3.3608	3.0645	2.5218	2.2329	2.3358	2.2767	3.1565
Min	.1995	.1878	.096	.093	.0914	.2086	.179
Avg	1.2039	1.1116	.4541	.9850	1.0263	.9618	1.6821

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 203 / 11KV Koregaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7185	1.3441	1.5203	.0282	.0293	.0446	.0457
2	1.7185	1.3441	1.5565	.0282	.0297	.0463	.0457
3	1.7236	1.3123	1.7741	.0282	.0301	.0497	.0463
4	1.7444	1.2498	1.6244	.0423	.0305	.0497	.0492
5	1.6804	1.2498	1.6385	.0423	.0309	.0509	.0492
6	1.6484	1.2963	1.6876	.0335	.0469	.0514	.0492
7	1.6358	1.3117	1.6762	.048	.0617	.0526	.0492
8	.0492	.0497	.0326	.0486	.0312	.0423	.032
9	.0469	.0312	2.1765	2.2558	2.4777	2.3644	.0297
10	.0282	.0274	2.3758	2.3525	2.6379	2.4577	.0248
11	.0312	.0274	2.3205	2.3482	2.5888	1.9433	.0377
12	.0389	.0372	2.3482	2.3205	2.4777	2.1125	.0406
13	.0372	.048	2.2834		2.2613	2.1605	.0383
14	.0236	.0423	2.1765		2.2138	2.0241	.04
15	.0271	.0423	2.1538		2.1091	1.9845	.0423
16	.0316	.0406	2.0965		2.0622	1.8747	.0232
17	.0305	.0465	.0423		.0389	.0291	.0269
18	.0271	.0349	.04		.0383	.0343	.0286
19	.04	.04	.0297		.0457	.0343	.0412
20	.0389	.0389	.0486		.048	.0383	.0394
21	.0316	.0377	.0446		.0463	.036	.0429
22	1.3757	1.5684	.0339		.0452	.0412	1.6446
23	1.3748	1.4687	.0309		.0446	.0446	1.7124
24	1.7497	1.3426	1.5364	.0282	.029	.0446	.0446
Max	1.7497	1.5684	2.3758	2.3525	2.6379	2.4577	1.7124
Min	.0236	.0274	.0297	.0282	.029	.0291	.0232
Avg	.7022	.5847	1.3020	.7388	.8106	.7338	.1760



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 201 / 11KV MARDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4213	1.2041	.2858	.2972	.2896	.2782	1.1622
2	1.3527	1.1698	.2782	.282	.2858	.2667	1.1088
3	1.307	1.0936	.282	.282	.2858	.2667	1.086
4	1.2917	1.086	.2782	.2743	.2782	.2629	1.0631
5	1.2689	1.0631	.282	.2667	.2743	.2705	1.0669
6	1.307	1.0936	.2934	.2743	.301	.2896	1.1698
7	1.5813	1.3756	.3125	.2972	.3239	.2972	1.4518
8	.6744	.4572	.2553	.2362	.2477	.2477	.4725
9	.1715	.202	1.8519	2.1148	2.0424	1.8976	.1562
10	.1638	.1677	2.1605	2.2939	2.1376	2.0386	.141
11	.1715	.1829	2.1872	2.2862	2.2596	2.0919	.16
12	.1753	.1753	2.3358	2.3053	2.2824	2.0767	.1029
13	.2172	.1905	2.3129	2.2519	2.1148	2.1338	.1867
14	.2172	.2134	2.2405	2.2443	2.0424	2.0652	.2096
15	.2134	.2324	2.1643	2.1186	1.8709	2.05	.2058
16	.2172	.2248	2.1033	2.0309	1.8785	1.9204	.2134
17	.2172	.2096	.6401	.7087	.5258	.4954	.2134
18	.1981	.2134	.1867	.1905	.1981	.2134	.1905
19	.2401	.2058	.1905	.2248	.221	.2248	.2096
20	.3544	.3353	.3315	.3315	.3429	.3239	.3315
21	.3696	.3544	.3544	.3544	.3391	.3467	.3582
22	1.1965	.3544	.3582	.3467	.3353	1.1622	1.3108
23	1.3184	.3544	.3467	.3467	.3277	1.2384	1.4708
24	1.3146	.3125	.3086	.301	.301	1.2498	1.4518
Max	1.5813	1.3756	2.3358	2.3053	2.2824	2.1338	1.4708
Min	.1638	.1677	.1867	.1905	.1981	.2134	.1029
Avg	.7067	.5197	.9309	.9442	.8961	.9878	.6456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 202 / 11KV KARANDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.768	1.3108	.6516	.6668	.6516	.644	1.4899
2	1.5813	1.2117	.6401	.6401	.6401	.6211	1.4137
3	1.4556	1.1812	.6249	.6401	.6287	.6097	1.3641
4	1.406	1.1355	.6173	.6325	.6173	.602	1.3489
5	1.4098	1.185	.6249	.6363	.6287	.6211	1.3032
6	1.5394	1.3832	.7202	.6744	.6897	.6973	1.4708
7	1.989	1.9204	.6973	.6668	.6935	.7087	1.9395
8	.6554	.5563	.5144	.5906	.5373	.5449	.4992
9	.423	.4839	2.6025	2.713	3.296	2.8921	.4268
10	.3925	.4382	2.6558	.0267	2.9492	3.3989	.3658
11	.4001	.442	3.315			3.2884	.362
12	.4992	.4649	1.9585		.9526	3.2808	.4382
13	.5296	.522	3.5208	2.4044	3.4903	3.0902	.4954
14	.5487	.5601	3.3379	3.1283	2.7206	2.6063	.522
15	.602	.5716	3.2541	3.2884	3.2769	2.6635	.5335
16	.5944	.5792	3.1436	3.235	3.1017	2.7092	.5411
17	.5525	.5601	.6363	2.7816	1.97	.4649	.5449
18	.4763	.5487	.4915	2.5758	2.0576	.4496	.4839
19	.6249	.6211	.5868	.5906	.5944	.522	.5601
20	.964	.884	.8764	.8269	.8497	.9221	.8535
21	.9259	.8802	.8878	.8497	.8573	.9183	.8993
22	.4954	.9107	.9031	.8269	.8345	1.8328	2.0309
23	1.4822	.8688	.8459	.7926	.7811	1.829	2.1414
24	2.0501	.7011	.7202	.6897	.6935	1.6499	2.0348
Max	2.0501	1.9204	3.5208	3.2884	3.4903	3.3989	2.1414
Min	.3925	.4382	.4915	.0267	.5373	.4496	.362
Avg	.9736	.8300	1.4511	1.3581	1.4571	1.5653	1.0026

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 204 / 11 KV FALKEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6046	2.9797	.3582	.3887	.3582	.3429	3.0636
2	3.4827	2.8807	.3506	.3734	.3506	.3429	2.8883
3	3.0178	2.7664	.3429	.3734	.3658	.3429	2.7968
4	2.8502	2.6825	.3506	.381	.381	.3353	2.6673
5	2.8807	2.7664	.3582	.3887	.3887	.3658	2.7892
6	3.2465	3.0102	.4191	.4572	.4649	.4344	3.0712
7	3.9476	3.2846	.4572	.4725	.4877	.4649	3.4751
8	1.1888	.7011	.4115	.4725	.442	.4344	.7697
9	.3887	.3277	3.597	3.6656	.4039	4.6563	.381
10	.3125	.3201	3.597	4.8316		4.8468	.282
11	.2362	.2896	3.9781	4.4734	2.5987	4.7554	.1981
12	.2439	.282	2.7664	1.9814	4.5268	4.2753	
13	.2515	.2896		1.6004	4.2067	4.2905	.2515
14	.3048	.3048		3.7494	4.4505	4.1686	.2667
15	.3048	.2972	4.2295	3.9095	4.2676	3.8485	.2743
16	.2972	.2896	4.3743	4.161	4.1762	3.9095	.282
17	.221	.282	.7621	.9983	.6935	.4954	.282
18	.2896	.2972	.2743	.282	.3048	.0457	.2591
19	.3048	.3201	.3429	.3201	.3582	.3582	.3277
20	.4954	.4877	.4954	.4877	.503	.5182	.4877
21	.503	.4877	.5182	.4877	.503	.5106	.5106
22	3.2541	.4725	.5106	.4801	.4725	3.2769	3.8028
23	3.5361	.442	.4572	.4572	.4191	3.3836	3.9933
24	3.8371	.381	.4191	.381	.3658	3.376	3.9171
Max	3.9476	3.2846	4.3743	4.8316	4.5268	4.8468	3.9933
Min	.221	.282	.2743	.282	.3048	.0457	.1981
Avg	1.6250	1.1101	1.3350	1.4822	1.3691	2.0741	1.6103

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 403 / 33 KV Walwa

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	29.9383	25.103	21.2277	24.1426	21.9822
2	***	***	28.6694	23.0795	20.0617	22.085	20.6105
3	***	29.2182	19.2044	21.9822	18.6558	21.5707	19.8902
4	***	29.0124	18.7243	21.2963	18.4157	21.1591	19.3759
5	***	29.3554	18.8271	21.2963	18.6901	21.4335	19.4102
6	***	***	21.0905	23.4911	22.1536	23.937	21.6393
7	***	***	23.6283	26.8862	25.1373	27.0234	24.177
8	18.1756	18.3471	16.2209	18.2099	16.8724	19.5817	17.1811
9	29.561	29.1153	25.1715	***	***	25.583	26.7833
10	***	***	***	***	***	***	27.915
11	***	29.1839	***	***	***	***	28.4637
12	***	29.1153	***	***	***	***	27.3663
13	28.3952	28.1208	***	***	***	***	27.9836
14	26.9205	25.5144	26.9205	***	***	***	27.2978
15	26.6461	25.2743	***	***	***	***	26.406
16	26.3717	25.0001	***	21.6735	***	29.9383	26.749
17	18.6557	18.93	16.118	14.9863	14.952	15.295	17.284
18	17.5927	16.8724	16.7352	13.7174	15.9465	16.3238	16.8038
19	20.0617	19.273	18.4843	15.6036	18.7586	18.7586	18.6215
20	22.3594	22.4966	21.7079	18.5186	22.1193	22.3594	21.4335
21	22.5309	22.085	21.2963	18.1413	21.3649	21.6736	15.5008
22	***	***	***	27.332	29.9383	27.4691	29.0467
23	***	***	***	26.6461	29.8011	27.0234	***
24	***	***	28.1208	23.4568	26.6118	24.3827	***
Max	37.8602	35.4596	38.889	38.3402	38.203	38.3059	36.3855
Min	17.5927	16.8724	16.118	13.7174	14.952	15.295	15.5008
Avg	28.8384	27.5135	26.3775	25.3258	26.2746	26.2975	23.8755

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 404 / 33KV Kasbe Digraj  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	1.9136
Max	1.9136
Min	1.9136
Avg	1.9136

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 405 / 33 KV Nagaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	1.1694
Max	1.1694
Min	1.1694
Avg	1.1694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 406 / 33 KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.7442
Max	.7442
Min	.7442
Avg	.7442

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 407 / 33 KV Kasturi

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.9465	16.1523	16.5638	16.358	6.893	11.4541	14.6777
2	17.4554	16.0837	15.9808	16.701	2.7092	13.203	16.5295
3	16.6667	17.2497	17.2154	17.3869	2.1948	12.2771	15.6722
4	16.6667	17.5583	16.9067	17.1811	5.7613	13.3745	16.1523
5	16.5981	16.3238	16.5981	16.4266	4.6982	12.1399	16.701
6	16.8039	17.1468	17.0439	17.1468	6.7901	11.1111	17.0439
7	17.2497	16.8039	16.9067	17.1125	5.3155	11.3512	16.1523
8	16.358	16.701	15.0206	16.3923	7.3731	10.7682	13.1344
9	15.9808	16.9067	16.0151	7.5789	9.1564	11.9685	15.9465
10	15.9465	17.4211	11.8313	2.1948	12.1399	14.4033	16.0837
11	10.9397	14.9863	14.6091	1.9547	13.3059	17.1468	14.9863
12	13.2373	16.358	16.4266	1.9204	11.6598	8.2305	14.129
13	14.6777	15.9808	14.6091	1.9547	12.6543	10.2195	15.4664
14	15.9465	16.0151	16.118	1.9547	11.1454	15.7408	15.2949
15	16.0494	15.3292	15.0892	1.9204	12.8258	16.5981	16.3238
16	15.8779	14.369	15.4664	1.9547	12.5515	15.9122	14.129
17	15.4321	16.7353	16.9753	2.1948	12.8944	15.4664	16.5295
18	14.952	17.4897	15.535	2.2291	11.9685	16.8039	17.2154
19	16.5981	16.5638	15.0892	2.2291	12.5515	16.7353	16.8382
20	16.3923	17.0439	14.4033	2.2634	11.3169	17.2497	16.8725
21	15.8093	15.6036	14.9177	2.2634	12.38	16.3238	16.2552
22	14.8491	15.6036	15.8436	2.4006	11.1797	16.701	16.7696
23	16.2209	14.4033	15.5007	3.7037	13.7174	16.8725	17.1125
24	19.9452	15.7751	15.0549	3.738	10.4938	15.9465	16.358
Max	19.9452	17.5583	17.2154	17.3869	13.7174	17.2497	17.2154
Min	10.9397	14.369	11.8313	1.9204	2.1948	8.2305	13.1344
Avg	15.9417	16.2752	15.6550	7.3817	9.7365	14.0832	15.9322



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 201 / 11 KV ISLAMPUR-I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.885	1.9044	1.8671	1.9044	1.8671	1.8671	1.7924
2	1.8671	1.8298	1.8298	1.8298	1.7741	1.7551	1.7926
3	1.8298	1.8298	1.8298	1.7177	1.7551	1.6804	1.7741
4	1.7924	1.8298	1.8107	1.7177	1.7551	1.6804	1.7741
5	1.8656	1.8298	1.7926	1.7551	1.8107	1.7551	1.8111
6	2.0119	1.8671	1.922	1.8671	1.9589	1.885	2.0165
7	1.9022	1.7924	1.885	1.7551	1.8298	1.848	1.9044
8	1.7372	1.7741	1.6827	1.6804	1.7177	1.7741	1.7551
9	1.7372	1.6263	1.5524	1.5893	1.5364	1.6263	1.5524
10	2.0271	2.0271	2.0485		1.9909	1.9909	1.9185
11	1.7924	1.8099	1.8656		1.8656	1.829	1.8461
12	1.5565	1.9022	1.9387	2.1132	1.848	1.8823	1.9547
13	1.5893	1.922	2.0119			1.8823	1.9547
14	2.1948	1.9589	2.0119		3.3494	2.0328	1.9909
15	2.2177	1.9959	2.1068		2.3411	2.1068	2.0851
16	2.1807	1.9387	2.0328		2.1582	2.0328	2.0485
17	2.1582	1.9753	1.9959		2.1948	1.9589	2.0851
18	1.9547	1.9022	1.9959		2.0119	1.9044	2.0851
19	2.4143	2.7069	2.6981	2.6612	2.7069	2.726	2.7069
20	2.6703	2.5873		2.524	2.5606	2.6886	2.6242
21	2.5133	2.4272	2.5873	2.3777	2.3777	2.4764	2.4764
22	2.3655		2.4394	2.3655	2.3411	2.4025	2.3777
23	2.2546	2.2032	2.2405	2.2032	2.1948	2.1582	2.1948
24		2.0328	2.0165	1.9791	1.9791	1.9022	1.9387
Max	2.6703	2.7069	2.6981	2.6612	3.3494	2.726	2.7069
Min	1.5565	1.6263	1.5524	1.5893	1.5364	1.6263	1.5524
Avg	2.0225	1.9858	2.0070	2.0025	2.0837	1.9936	2.0192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 202 / 11 KV Peth Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.0082		1.0719	.9979	1.0456	1.0349
2	1.0456	.9709	.8215	1.0456	.9896	1.0082	.961
3	.9979	.9709	.7842	.961	.961	.9709	.924
4	.9979	.9709	.7762	.9709	.9709	.9709	.924
5	1.0349	.9709	.8131	1.0082	1.0082	.9709	1.0082
6	1.2071	1.0562	1.1203	1.1458	1.2567	1.1458	1.2437
7	1.1088	1.0562	1.1203	1.0829	1.0719	1.0242	1.134
8	.9979	.9431	.9335	.9709	1.0349	.9877	.9877
9	.9877	.8688	.8326	.8413	1.0136	.9774	.905
10	1.0029	.9568	.8859		.9313	.8596	.9816
11	1.086	.9922	.9568		1.0029	.8954	.8859
12	1.086	.9568	.9568	.9671	1.0029	.8688	1.0277
13	1.1222	.8954	.9774		.9412	.8954	.8954
14	1.0242	.8779	.924		.905	.9877	.8954
15	.8589	.9412	1.0608		1.0136	.9412	.8954
16		.8596	.9145		.9412	.9145	.9774
17	1.0242	.9313	1.0349		.9511	1.0974	.9511
18	1.0719	.905	.961		1.0242	.9877	.9877
19	1.3443	1.3535	1.3306		1.2197	1.4415	1.3676
20	1.3443	1.4998			1.6263	1.6263	1.6263
21	1.531	1.5154	1.5893		1.4784	1.4632	1.5684
22	1.419	1.3676	1.4118		1.3817	1.39	1.4563
23	1.1949	1.1949	1.2437		1.1949	1.1706	1.307
24	1.1088	1.1203	1.094	1.1088	1.1203	1.0456	1.0608
Max	1.531	1.5154	1.5893	1.1458	1.6263	1.6263	1.6263
Min	.8589	.8596	.7762	.8413	.905	.8596	.8859
Avg	1.1181	1.0493	1.0247	1.0159	1.0850	1.0703	1.0836

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 203 / 11 KV LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0166		1.0082	.0183	.9313	1.0242
2	1.0517		.2743	.0181	.9671	1.0719
3	1.0517		.2743	.0185	1.0745	1.1088
4	1.0974		.2743	.037	1.086	1.1088
5	1.0974		.2774	.0373	1.0631	1.0456
6	.3224		.2774	.0754	1.0985	.8413
7	.2865		.2774	.1132	1.134	.8048
8	.2896		.3772	.112	1.182	.8131
9	.2926		1.1576	.1402	1.1827	1.1458
10	.2987		1.2567	.3224	1.2197	1.0719
11	.2926		1.1458	1.0349	1.1827	1.0719
12	.2926	1.0719	1.1827	1.1827	1.1827	1.0456
13	.9979	1.2567	1.1827	1.1827	1.1458	1.0082
14	1.1458	1.1827	1.1458	1.1088	1.1088	.8871
15	1.1827	1.1827	1.1827	1.1458	1.1088	.0255
16	.3395	.2641	.4904	.3018	.3395	.0394
Max	1.1827	1.2567	1.2567	1.1827	1.2197	1.1458
Min	.2865	.2641	.2743	.0181	.3395	.0255
Avg	.6910	.9916	.7366	.4281	1.0630	.8821

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 204 / 11 KV ISLAMPUR-II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2054	.1886	.2218	.1867	.2241	.2241
2	.2218	.2054	.1886	.1848	.1848	.1867	.1867
3	.1829	.2054	.1867	.1848	.1791	.1867	.1867
4	.1829	.2054	.1867	.1848	.1791	.1867	.1867
5	.1848	.2054	.1867	.1867	.1867	.1867	.1886
6	.2195	.2263	.2241	.1848	.2218	.2218	.2218
7	.1848	.2075	.1867	.1867	.1848	.1848	.1848
8	.1848	.1867	.1867	.1867	.1494	.1848	.1478
9	.1463	.1433	.1772	.1075	.1478	.1227	.1646
10	.1417	.1417	.1417		.1052	.1402	.1433
11	.1417	.1402	.1402		.1227	.124	.1791
12		.1402	.1402	.1543	.1402	.1372	.1612
13		.1433	.1402	.1595	.1417	.1578	.1791
14		.1463	.1433	.1448	.1433	.1433	.1791
15		.1463	.1448	.1829	.1448	.0554	.1791
16		.1448	.1463	.1463	.1433	.037	.181
17	.1448	.181	.1463	.1829	.1463	.1494	.0914
18	.1448	.181	.1478	.1478	.1463	.1867	.1829
19	.2587	.2195	.2218	.2587	.2218	.2587	.2218
20	.2587	.2587		.2587	.2587	.2987	.2587
21	.2801	.2587	.2587	.2614	.2987	.2614	.2587
22	.2614	.2587	.2587	.2614	.2614	.2614	.2561
23	.2427	.2241	.2587	.2614	.2241	.2614	.2218
24	.1463	.2241	.2241	.2218	.2241	.2241	.2241
Max	.2801	.2587	.2587	.2614	.2987	.2987	.2587
Min	.1417	.1402	.1402	.1075	.1052	.037	.0914
Avg	.1973	.1916	.1837	.1941	.1810	.1826	.1921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 205 / 11 KV ISLAMPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.2606	.0377	.0381	.0187	.0187	.2054
2	.2804	.2115	.0189	.0381	.0187	.0187	.208
3	.2534	.2115	.0189	.0381	.0187	.0187	.208
4	.2454	.2115	.0187	.0381	.0189	.0187	.2378
5	.2804	.2286	.0187	.0381	.0373	.0187	.2709
6	.3292	.2675	.0373	.0381	.0373	.0187	.301
7	.3292	.2715	.0373	.0381	.0373	.0373	.3048
8	.0366	.0377	.037	.0572	.0373	.0373	.0351
9	.0179	.0373	.3437	.4428	.3395	.3086	.0377
10	.0181	.0373	.3437		.4062	.3395	.0381
11	.037	.0179	.3311		.4374	.4062	.0191
12	.037	.0377	.3353		.4374	.4012	.0381
13	.0377	.0377	.3567		.463	.3704	.0191
14	.0377	.0377	.3612		.3704	.3658	.0191
15	.0377	.0943	.3185		.3311	.3353	.0191
16	.0377	.0373	.2934	.3125	.3311	.3353	.0373
17	.0377	.0377	.0373	.0377	.0381	.0358	.0373
18	.0377	.0377	.0373	.0377	.0373	.0366	.0191
19	.0377	.0377	.0373	.0373	.0373	.0377	.0191
20	.0377	.0373		.0377	.0373	.0373	.0373
21	.0377	.0373	.0373	.0373	.0373	.0373	.0373
22	.3125	.037	.0373	.0373	.0373	.2378	.3696
23	.2934	.0377	.0373	.0185	.0373	.2378	.3696
24		.2606	.0377	.0373	.0189	.0187	.2054
Max	.3292	.2715	.3612	.4428	.463	.4062	.3696
Min	.0179	.0179	.0187	.0185	.0187	.0187	.0191
Avg	.1359	.1067	.1378	.0756	.1509	.1553	.1289

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7335	2.9859	2.8212	2.5824	1.4533	2.4943	2.4287
2	2.7663	2.8548	2.8037	2.4691	1.6125	2.524	2.5202
3	2.7511	2.8205	2.6482	2.4242	1.6628	2.3632	2.3731
4	2.6337	2.9226	2.6459	2.3076	1.5417	2.4043	2.3807
5	2.7343	2.7888	2.633	2.239	1.7597	2.3396	2.354
6	2.8585	2.8589	2.5728	2.2839	1.6317	2.5392	2.3708
7	2.8075	2.6943	2.7823	2.1674	1.7947	2.7412	2.3023
8	2.604	2.7526	2.5636	1.7117	1.7573	2.4691	2.3503
9	3.0804	3.0941	2.8731	1.3649	2.3187	2.7519	2.9523
10	3.9795	3.7159	3.6286	1.1378	2.9927	3.8051	3.786
11	4.3918	3.786	3.9746	1.1698	3.4218	3.8214	1.9883
12	4.5032	3.9735	4.2494	.6615	3.7639	3.8515	3.5384
13	3.9499	3.8241	3.7106	.6562	3.0567	3.514	3.7319
14	4.2188	3.3836	3.6188	.6523	3.142	3.3021	3.5551
15	4.3286	3.6252	4.3659	.6584	3.5151	3.6938	4.0665
16	4.2691	3.7358	4.1403	.6607	3.4416	3.591	3.9834
17	4.0958	3.5559	3.8516	.6302	3.3235	3.5643	3.812
18	3.9864	3.6222	3.2465	.6234	3.0956	3.317	3.3234
19	2.6943	3.4073	2.9351	.6165	3.0125	3.1184	3.136
20	2.9785	3.0941	2.8243	.6821	2.9561	2.7389	3.1062
21	2.9454	2.6551	2.4306	.804	2.354	2.3503	2.8494
22	3.0849	2.7382	2.5103	.8276	2.5392	2.3769	2.9676
23	3.062	2.7397	2.4691	1.5691	2.6688	2.5442	3.1009
24	1.5806	2.8296	2.7625	2.1513	2.1087	1.3748	2.7328
Max	4.5032	3.9735	4.3659	2.5824	3.7639	3.8515	4.0665
Min	1.5806	2.6551	2.4306	.6165	1.4533	1.3748	1.9883
Avg	3.2933	3.1858	3.1276	1.3771	2.5385	2.8996	2.9879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV SAKHRALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3613	.3756	.3567	.3574	.3536	.3483	.374
2	.3521	.3657	.3475	.3445	.3483	.3414	.3695
3	.3475	.3634	.3513	.3407	.3452	.3392	.3664
4	.3951	.3641	.3544	.3407	.3355	.3498	.3771
5	.4798	.3817	.3582	.3407	.4351	.3955	.4359
6	.5293	.4747	.4462	.4199	.5301	.4939	.775
7	.5514	.5067	.5372	.4695	.5457	.516	.5167
8	.405	.4199	.3963	.3674	.378	.3757	.4382
9	.3414	.3759	.3269	.3293	.3216	.3201	.3818
10	.3323	.3346	.3231	.3071	.327	.3346	.3685
11	.3147	.3399	.3208	.3026	.3117	.3079	.3144
12	.3361	.3292	.3232	.2942	.3102	.2964	.3163
13	.3185	.3346	.333	.1608	.3361	.3239	.3239
14	.3483	.3361	.3216	.1661	.3307	.3246	.3323
15	.3795	.3285	.3231	.1593	.33	.3216	.3285
16	.346	.3111	.33	.1616	.1372	.3422	.3315
17	.3559	.3407	.3269	.1623	.3376	.3384	.3512
18	.3467	.37	.3486	.1715	.3514	.3456	.3596
19	.4618	.4237	.3925	.1791	.4512	.426	.4359
20	.572	.5128	.5137	.2667	.5571	.5692	.5516
21	.5015	.5045	.5167	.2439	.5236	.5442	.5727
22	.4802	.4915	.4878	.2561	.5	.4893	.515
23	.4755	.4793	.4534	.4816	.45	.4534	.4946
24	.2202	.3992	.406	.375	.3954	.2294	.403
Max	.572	.5128	.5372	.4816	.5571	.5692	.775
Min	.2202	.3111	.3208	.1593	.1372	.2294	.3144
Avg	.3980	.3943	.3831	.2916	.3851	.3803	.4181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV BAHE AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0189	1.9833	2.3799	2.1856	2.1765	.0187
2	.0171	.0185	1.949	2.2771	2.085	2.0828	.0187
3	.0171	.0185	1.9342	2.2428	2.0301	2.0485	.0187
4	.0171	.0185	1.941	2.221	2.0027	1.6942	.0187
5	.0171	.0185	1.9993	2.2713	2.0576	2.0736	.0189
6	.0171	.0185	2.2736	2.3079	2.2656	2.2623	.0189
7	.0171	.0185	2.3845	2.532	2.1788	2.316	.0189
8	.0194	.0185	.3253	.4686	.1397	.1829	.0189
9	1.8278	3.2316	.02	.0171	.0187	.0171	3.3311
10	3.5825	3.2716	.0171	.0185	.0171	.0187	3.3894
11	3.4408	3.2099	.0171		.0171	.0187	3.37
12	2.9801	3.1699	.0171			.0187	3.3299
13	2.8292	2.9459	.0171			.0187	3.1527
14	2.8166	2.8304	.0171		.0171	.0187	2.8898
15	2.8212	2.6829	.0171		.0182	.0907	2.7275
16	2.7406	2.6566	.0171		.0171	.0187	2.7492
17	.251	.2029	.0194	.008	.0171	.0187	.2441
18	.0185	.0189	.0171		.0069	.0187	.02
19	.0185	.0189	.0182		.0422	.0187	.0189
20	.0185	.0189	.0171		.0708	.0187	.0189
21	.0185	.0372	.0171	.0011	.0171	.0187	.0189
22	.0185	2.1948	2.6532	1.406	2.3812	.0187	.0189
23	.0185	2.2223	2.7355	2.58	2.4535	.0187	.0189
24	.0171	1.1605	2.2896	2.5503	2.3331	.9488	.0187
Max	3.5825	3.2716	2.7355	2.58	2.4535	2.316	3.3894
Min	.0171	.0185	.0171	.0011	.0069	.0171	.0187
Avg	.9815	1.2509	.9457	1.5521	1.0169	.6724	1.0611



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV DUDH SANGH FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7845	1.0597	.9168	.9819	1.0199	1.0649	.9662
2	.7769	1.0015	.9473	.9417	.976	1.0489	.971
3	.7304	.9901	.8804	.8849	.931	1.0057	1.0071
4	.7217	.9684	.8985	.8899	.9166	.9594	1.0099
5	.7053	.8284	.8672	.8036	.9035	.9619	.7308
6	.644	.821	.8167	.8067	.8939	.9677	.6453
7	.5482	.6886	.7638	.6396	.7437	.856	.6158
8	.5359	.6047	.6626	.587	.6167	.6876	.5363
9	.959	.8903	.8272	.919	.7694	.8234	.9079
10	1.1704	1.0991	.9896	1.1033	.9688	1.0742	1.1007
11	1.3068	1.2691	1.25	1.2504	1.1778	1.3074	1.3394
12	1.2542	1.2973	1.2298	1.1105	1.234	1.2965	1.2197
13	1.1496	1.1991	1.0597	.6129	1.0757	1.1174	1.1599
14	1.0389	1.0722	.981	.57	1.0726	.9065	1.1332
15	1.0318	1.0343	1.033	.562	1.1201	.932	1.1363
16	.9446	.9427	.9358	.4833	.9959	.8911	1.0076
17	.9511	1.0107	.8411	.4601	.9206	.7632	.9158
18	1.0429	1.09	.9591	.4803	1.0473	.6739	.8411
19	1.0655	1.108	.9844	.4693	1.0871	.6858	.8562
20	.8633	1.0882	.8824	.5624	1.0602	.776	.8914
21	.9755	1.0957	.8379	.5163	1.0966	1.0345	.9432
22	1.0079	.9448	.8659	.5035	1.0691	1.0736	1.0597
23	1.0212	1.0277	1.0831	.9387	1.0492	1.0058	1.1266
24	.5447	1.03	1.0071	.9958	1.0627	.5415	.9856
Max	1.3068	1.2973	1.25	1.2504	1.234	1.3074	1.3394
Min	.5359	.6047	.6626	.4601	.6167	.5415	.5363
Avg	.9073	1.0067	.9384	.7530	.9920	.9356	.9628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV NAGARPALIKA PWW  
FEEDER Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8375	.8391	.8387	.813	.8311	.8379	.8206
2	.8401	.833	.8372	.8166	.8284	.8371	.8206
3	.8375	.8303	.8353	.8143	.8277	.8348	.8198
4	.7758	.8292	.8338	.8135	.8273	.7971	.8171
5	.7685	.7697	.8482	.7224	.756	.7678	.7941
6	.8558	.8366	.8513	.6992	.8575	.8368	.8076
7	.8981	.908	.9149	.8634	.8612	.8722	.8735
8	.8827	.9115	.9073	.8935	.8853	.9118	.8861
9	.9103	.9478	.9252	.9305	.8903	.9503	.9119
10	.9179	.9214	.9214	.929	.9145	.9218	.9199
11	.9214	.8945	.6028	.926	.9195	.9218	.9195
12	.8318	.857	.8842	.8681	.8987	.9183	.8799
13	.8769	.8562	.8777	.4496	.8101	.9004	.8677
14	.8903	.8662	.8865	.4588	.8853	.8402	.9084
15	.8907	.8914	.8872	.4599	.8888	.8444	.9119
16	.6843	.8899	.8884	.4839	.9092	.8818	.8568
17	.1101	.8738	.8947	.4687	.8802	.8924	.8799
18	.8939	.8738	.8888	.4443	.4626	.9172	.8968
19	.9111	.8492	.8918	.466	.8818	.9172	.8579
20	.9501	.8047	.8156	.4332	.8705	.8678	.807
21	.9188	.7655	.751	.4332	.655	.7427	.7678
22	.7308	.7608	.3654	.2987	.4751	.4222	.6725
23	.7598	.7994	.6985	.7091	.5837	.6051	.6445
24	.3989	.8174	.8174	.8145	.8277	.434	.8072
Max	.9501	.9478	.9252	.9305	.9195	.9503	.9199
Min	.1101	.7608	.3654	.2987	.4626	.4222	.6445
Avg	.8039	.8511	.8276	.6671	.8095	.8197	.8395

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV Kapuskhed Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3251	.3481	.3315	.3425	.3212	.319	.3186
2	.3235	.3443	.325	.2652	.3167	.3136	.3151
3	.3212	.339	.3273	.3178	.3147	.3106	.3098
4	.3205	.3378	.33	.3155	.3113	.3129	.3109
5	.3867	.3512	.3955	.3681	.458	.386	.3837
6	.5312	.5423	.4765	.4577	.5217	.4771	.4925
7	.4695	.5413	.4965	.421	.5243	.4531	.4348
8	.4138	.4016	.4085	.3376	.4005	.357	.3486
9	.3327	.3564	.325	.3193	.3342	.2823	.3002
10	.343	.3107	.2923	.3002	.2694	.2409	.2831
11	.2831	.3372	.282	.2846	.2912	.2846	.2409
12	.2553	.317	.311	.2812	.3467	.2409	.2389
13	.3025	.2999	.3171	.1437	.3239	.271	.2527
14	.2995	.2856	.3132	.1433	.3124	.298	.2631
15	.3395	.3178	.3357	.1456	.3014	.2877	.2772
16	.3368	.3365	.3437	.1345	.3086	.2842	.3186
17	.3547	.3999	.3795	.1307	.2865	.2692	.3725
18	.3784	.4195	.3619	.1738	.192	.3014	.3657
19	.5529	.5308	.4226	.2187	.4073	.4767	.4622
20	.5094	.5062	.5197	.2332	.5479	.5164	.5731
21	.4683	.469	.4741	.2374	.458	.511	.548
22	.4333	.4411	.4607	.2286	.4378	.4373	.4586
23	.3909	.4085	.4226	.4098	.3906	.3894	.4096
24	.1814	.3607	.3573	.3452	.347	.1745	.3497
Max	.5529	.5423	.5197	.4577	.5479	.5164	.5731
Min	.1814	.2856	.282	.1307	.192	.1745	.2389
Avg	.3689	.3876	.3754	.2731	.3635	.3415	.3595

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 207 / 11 KV SAKHRALE Ag FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5693	.5247	.0189	.0171	.0185	.0171	.4321
2	.5693	.5247	.0189	.0171	.0185	.0171	.4321
3	.5693	.5247	.0189	.0171	.0185	.0171	.4268
4	.5376	.4877	.0189	.0171	.0185	.0171	.4268
5	.5376	.4012	.0189	.0171	.0185	.0171	.4268
6	.5376	.4161	.0189	.0171	.0185	.0171	.506
7	.5693	.4572	.0189	.0171	.0185	.0171	.5624
8	.0171	.0185	.0189	.0171	.0177	.0171	.0185
9	.0171	.0185	.8322	.8962	.9172	.8322	.0158
10	.0189	.0189	.9282	.9602	.9488	.8749	.0189
11	.0189	.0189	.9282	.9282	.9488	.8436	.0189
12	.0189	.0189	.9282		.8539	.7499	.0189
13	.0189	.0189	.8322		.7907	.7186	.0189
14	.0189	.0189	.8322		.759	.6874	.0189
15	.0189	.0189	.7682		.6958	.6562	.0189
16	.0189	.0189	.7362		.6722	.6249	.0189
17	.0189	.0189			.0158	.0185	.0189
18	.0189	.0189	.0171		.0171	.0185	.0189
19	.0189	.0189	.0171		.0171	.0185	.0189
20	.0189	.0189	.0171		.0171	.0185	.0189
21	.0189	.0189	.0171		.0171	.0185	.0189
22	.6478	.0189	.0171		.0171	.5121	.6401
23	.6478	.0189	.0171		.0171	.506	.664
24		.5851	.0189	.0171	.0185		.4744
Max	.6478	.5851	.9282	.9602	.9488	.8749	.664
Min	.0171	.0185	.0171	.0171	.0158	.0171	.0158
Avg	.2368	.1760	.3069	.2449	.2863	.3146	.2189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 209 / 11 KV Siddhanath LIS  
feeder Feeder KV- 11 /  
OUTGOING

PURELY LIS FEEDERS

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3321	.3812	.3812	.607	.6154	.1257
2	.3479	.3812	.3812	.7892	.7838	.1421
3	.3479	.3812	.3812	.788	.7857	.1433
4	.3479	.3812	.3812	.7861	.7808	.1353
5	.3479	.3812	.3812	.7865	.7804	.1356
6	.3479	.3812	.3812	.7869	.7815	.1349
7	.3479	.3812	.3812	.7903	.4984	.1456
8	.3479	.3812	.3812	.7903	.1448	.1463
9	.3637	.3812	.3812	.7896	.1436	.1791
10	.3647	.3978	.3681	.7876	.1267	.2199
11	.3812	.3978	.3681	.8112	.1326	.2207
12	.3812	.3812	.3681	.8212	.1509	.2191
13	.3812	.3812	.3521	.4431	.1528	.1999
14	.3812	.3812	.3681	.8046	.1528	.2208
15	.3812	.3481	.3681	.8046	.1501	.1852
16	.3647	.3277	.3361	.8023	.1482	.1513
17				.423	.0709	.0834
Max	.3812	.3978	.3812	.8212	.7857	.2208
Min	.3321	.3277	.3361	.423	.0709	.0834
Avg	.3604	.3779	.3725	.7419	.3764	.1640

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 401 / 33 KV EXPRESS FEEDER  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5327	6.557	6.4661	6.2872	5.4046	6.7101	7.3097
2	5.6356	6.3855	6.4661	6.2872	5.3704	6.7787	7.2411
3	5.2927	6.4884	6.4318	6.0356	5.1201	6.8816	7.2754
4	5.4526	6.4884	6.3975	5.8985	5.1201	6.8473	7.2411
5	5.2469	6.3512	6.3289	5.727	4.892	6.5616	7.4691
6	5.4869	6.3632	6.3289	5.8299	5.1766	6.3558	7.4811
7	5.4755	6.0785	6.2946	6.0814	5.223	6.6759	7.56
8	3.9781	5.6104	6.1351	5.5784	5.2109	6.7444	7.0473
9	5.3498	6.3975	6.4884	5.144	5.7922	7.1674	7.4588
10	5.9071	6.5913	5.0755	4.7548	6.6073	5.1783	7.915
11	6.8758	6.8656	7.2703	5.4732	6.9159	4.892	8.1087
12	7.4349	6.9342	7.0188	5.8282	7.2246	7.4229	8.0625
13	7.1845	6.7849	6.7787	4.2524	7.2703	7.7538	7.9819
14	7.5257	6.6701	6.7444	4.1495	6.9959	7.4691	7.8447
15	7.1845	6.8535	6.8587	4.4582	7.236	7.8344	8.0384
16	7.2411	6.8313	6.813	4.8011	7.2703	7.6063	8.3248
17	7.1159	6.5227	6.8015	4.4925	6.7215	6.5347	8.1876
18	6.6941	5.998	6.0356	4.3553	6.493	6.8072	7.8687
19	6.557	5.5538	6.0699	4.1838	6.2872	6.7164	7.7315
20	6.557	5.6447	6.1957	4.1495	6.3215	7.4349	7.7435
21	6.1112	5.6447	5.9213	3.4294	6.493	7.0696	7.3663
22	6.3512	6.4198	5.967	3.2922	6.6987	7.3663	7.8224
23	6.4095	6.773	6.2872	5.108	7.3274	7.3663	8.1191
24	5.9213	6.3872	6.3672	5.4413	6.7541	7.2931	7.7898
Max	7.5257	6.9342	7.2703	6.2872	7.3274	7.8344	8.3248
Min	3.9781	5.5538	5.0755	3.2922	4.892	4.892	7.0473
Avg	6.1884	6.3831	6.3976	5.0433	6.2469	6.8945	7.7079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 201 / 11 KV RHX &amp; TAKARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7095	.7095	.6348	.6413	.6413	.6161
2	.6908	.6979	.6979	.6161	.6224	.6413	.6161
3	.6908	.6979	.6979	.6161	.6224	.6413	.6161
4	.7095	.7167	.6979	.6348	.6413	.6602	.6535
5	.7392	.7545	.7095	.6722	.6602	.7167	.6908
6	.8775	.8402	.8215	.8215	.811	.8215	.8215
7	.9231	.8954	.8775	.7964	.8299	.8507	.7796
8	.815	.7888	.6935	.7442	.7343	.7343	.7108
9	.6836	.7202		.6661		.6173	.631
10	.7628	.6935	.6783	.6859	.6104	.6516	.5895
11	.7442	.703	.7461		.6783	.6371	.7011
12		.7042	.7291		.6952	.6516	.6588
13	.7796	.6415	.703		.6516	.5868	.6733
14	.7011	.631	.7011		.6935	.7108	.6836
15	.5144	.7186	.7362		.6859	.7186	.6733
16	.7888	.7628	.7202		.6783	.631	.6952
17	.8322		.6516		.7122	.6859	.6859
18			.7461		.8048	.7461	.759
19	1.0631	1.2048	.9391		.9922	.9568	.9326
20	1.086				1.0498	1.0679	1.0498
21	1.0242	1.0136	.924		.9055	.924	.9412
22	.8686	.9425	.8775		.8589	.8871	.9145
23	.7207	.7947	.7842		.7468	.7842	.8501
24	.7392	.7207	.7282	.6722	.6602	.6535	.6535
Max	1.086	1.2048	.9391	.8215	1.0498	1.0679	1.0498
Min	.5144	.631	.6516	.6161	.6104	.5868	.5895
Avg	.7938	.7787	.7532	.6873	.7385	.7341	.7332

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 202 / 11 KV TAKARI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6562	.6401	.0754	.0747	.0747	.0754	.6154
2	.6562	.6154	.0754	.0747	.0747	.0754	.5761
3	.6241	.6154	.0754	.0747	.0747	.0754	.5601
4	.5921	.6154	.0754	.0934	.0934	.0754	.5601
5	.6009	.6478	.0747	.0934	.0924	.0754	.5668
6	.6964	.6722	.0924	.0924	.0924	.0934	.7125
7	.8097	.7682	.1294	.1109	.0924	.1132	.7499
8	.112	.112	.132	.1132	.112	.1494	.0943
9	.1109	.112		1.1012		1.2597	.0924
10	.1132	.1463	1.1043	1.2308	1.358	1.278	.0934
11	.1109	.1494	1.2323		1.3108	1.186	.0924
12		.132	1.1523		1.1984	1.1498	.0934
13	.0747	.112	1.0753		1.1523	.9804	.0934
14	.0754	.0943	1.0279		1.0437	.8962	.0943
15	.0754	.1132	.9804		1.0279	.8482	.0943
16	.0943	.112	.9374		.9374	.8223	.0943
17	.0943		.0943		.1132	.0943	.1132
18			.0943		.132	.1132	.1132
19	.1307	.1132	.112		.1132	.112	.1132
20					.1132	.112	.1132
21	.0943	.0943	.0934		.1132	.112	.0943
22	.7537	.0943	.0934		.0943	.6401	.7522
23	.7449	.0934	.0934		.0754	.6802	.7907
24	.8097	.7116	.0943	.0747	.0747	.0754	.6316
Max	.8097	.7682	1.2323	1.2308	1.358	1.278	.7907
Min	.0747	.0934	.0747	.0747	.0747	.0754	.0924
Avg	.3824	.3221	.4052	.2849	.4158	.4622	.3294



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 203 / 11 KV RETHRE HARNAX AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 FEEDER Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0514	.9374	.9061	.9488	1.0155	.0895
2	.0709	.0526	.933	.8642	.9061	1.0155	.0905
3	.0701	.0526	.933	.8333	.9061	1.0402	.0905
4	.0701	.0526	.9488	.7926	.9488	1.0722	.0905
5	.0693	.0532	1.0242	.8025	.9804	1.0911	.0914
6	.0724	.0716	1.1523	.9374	1.1069	1.1523	.0914
7	.0876	.0625	1.2037	1.0311	1.1385	1.2323	.0838
8	.0848	.0625	.0549	.0678	.0474	.0537	.096
9	1.6907	1.6575		.0709		.0709	1.5074
10	1.8067	1.7368	.048	.0838	.0701	.0373	1.4899
11	1.6078	1.7204	.0663		.0655	.0312	1.6057
12			.0617			.0838	1.6057
13		1.5402	.064			.081	1.587
14	1.3279		.0347		.0633	.0709	1.4723
15	1.3443	1.3279	.0358		.061	.0709	.5182
16	1.2963	1.4243	.0312		.0686	.0671	1.3279
17	.0492		.061		.081	.0848	.0848
18			.08		.0829	.0848	.1097
19	.0663	.0867	.0867		.0678	.0867	.1109
20					.0857	.0895	.1086
21	.0549	.0678	.0867		.0716	.0905	.0943
22	.0724	1.0437	1.0437		.4481	.0895	.0747
23	.0686	1.012	.9686		1.0911	.0905	.0732
24	.0701	.048	.953	.9374	.9488	1.0185	.0886
Max	1.8067	1.7368	1.2037	1.0311	1.1385	1.2323	1.6057
Min	.0492	.048	.0312	.0678	.0474	.0312	.0732
Avg	.5026	.6381	.4913	.6661	.4852	.4092	.5243

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 204 / 11KV Bhavaninagar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5243	.3315	.547	.0069	.4915	.5344
2	.5243	.4973	.547	.4534	.5407	.5407
3	.5243	.4858	.547	.5344	.5533	.5407
4	.5243	.5182	.547		.57	.547
5	.5182	.5243	.547	.5407	.5636	.5407
6	.5304	.5243	.547	.5407	.57	.547
7	.5121	.5218	.5407	.547	.5155	.5344
8	.5636	.5636	.2785	.5344	.5344	.5281
9	.5765	.5636			.5636	.5636
10	.57	.57	.5344	.5533	.5636	.5506
11	.57	.57	.5407	.5407	.5281	.5093
12		.5344	.5281	.5281	.5506	.5281
13		.57	.5344	.5281	.5441	.5344
14	.4858		.5344	.5281	.5765	.5441
15	.5182	.5636	.5344	.5344	.5571	.5506
16	.5312	.5304	.5281	.5407	.5571	.5506
Max	.5765	.57	.547	.5533	.5765	.5636
Min	.4858	.3315	.2785	.0069	.4915	.5093
Avg	.5338	.5246	.5224	.4936	.5487	.5403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 201 / 11 KV BAHE GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2195	.2195	.2195	.2195	.2218	.2195
2	.2218	.2149	.2218	.1991	.2195	.2218	.2195
3	.2033	.2195	.2033	.2012		.2218	.2241
4	.2012	.2715	.2012	.2012		.2402	.2353
5	.3077	.3077	.2957	.2896	.2926	.2743	.2926
6	.3403	.3841	.3511	.2507	.3258	.3696	.3511
7	.2804	.3222	.2686	.2507	.2835	.2865	.3012
8	.2058	.2229	.2103	.1949	.2058	.208	.2204
9		.1966	.1802	.1619	.192	.1658	.1802
10	.1875	.1823	.1739	.1581	.1698	.1829	
11	.208	.1423	.1718	.1475	.16	.1677	
12	.208	.2012	.1898	.1311	.1781	.1943	
13	.2204	.1886	.1898	.156	.1907	.1823	.2321
14	.2229		.1989		.1696	.1928	.213
15	.208	.2427	.2012		.1865	.208	.2012
16	.2321	.208			.218	.2155	.2229
17	.176	.2035	.2149		.1943	.2012	.2267
18	.1619	.2155	.1943		.1989	.1781	.2469
19	.3155	.2427	.2229		.2427	.3012	.2818
20	.3012	.2534	.2865		.2896	.3189	.333
21	.2591	.2587	.2715		.2743	.2896	.3045
22	.2353	.2926	.2772		.2957	.2743	.3109
23	.2561	.2378	.2427		.2402	.2378	.2561
24	.2378	.2402	.2402	.2195	.2195	.2195	.2218
Max	.3403	.3841	.3511	.2896	.3258	.3696	.3511
Min	.1619	.1423	.1718	.1311	.16	.1658	.1802
Avg	.2353	.2378	.2273	.1986	.2258	.2322	.2521

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 202 / 11 KV KHARATWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.253	.216					.3281
2	.25	.216					.3361
3	.25	.2214					.3321
4	.25	.2241					.3321
5	.253	.2315					.3361
6	.2591	.2439					.3321
7	.2526	.2743					.3281
9			.5281	.506	.6081	.6226	
10			.5441	.5376	.6964	.6249	
11			.5761	.5761	.6802	.583	
12			.5535		.6154	.6562	
13		.1886	.5624		.6062	.6081	
14		.1949	.5761		.6154	.6554	
15			.5281		.6154	.6154	
16					.6718	.5898	
17						.0179	
19	.0179						
22	.2372					.3906	.3077
23	.2372					.3906	.3201
24	.2656					.3906	.3479
Max	.2656	.2743	.5761	.5761	.6964	.6562	.3479
Min	.0179	.1886	.5281	.506	.6062	.0179	.3077
Avg	.2296	.2234	.5526	.5399	.6386	.5121	.3300

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 203 / 11 KV HUBALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0543	.9282	.9779	.9602	.8162	.0566
2	.0537	.0554	.8592	.9779	.9555	.828	.0566
3	.0537	.056	.8592	.9779	.9282	.7773	.0566
4	.0532	.056	.8592	.9667	.9339	.7773	.0566
5	.0351	.0566	.8802	.9667	.8802	.7773	.0566
6	.0701	.0566	.9122	1.0059	.9717	.8124	.0566
7	.0532	.0554	.9646	1.0111	1.0159	.8436	.0566
8	.0716	.056	.0366	.0554	.0566	.0566	.0543
9	1.4752	1.4091	.0486	.0377	.0377	.0377	1.4575
10	1.5083	1.4413	.048	.0377	.0377	.0366	1.5402
11	1.5729	1.4899	.0497	.0377	.0343	.0373	1.6194
12	1.5729	1.4899	.0354			.037	1.5364
13	1.7926	1.4899	.0354			.0373	1.5524
14	1.5565	1.4251	.1989		.0566	.0377	1.5384
15	1.5074	1.3279	.0354		.0566	.0554	1.5238
16	1.4091	1.2944			.0566	.056	1.4737
17	.0377	.0377	.0354		.0377	.0377	.0189
18		.0377	.0358		.0566	.056	.0189
19	.0492	.0566	.0486		.0566	.0566	.0566
20	.0566	.0754	.048		.0754	.0566	.0566
21	.056	.0566	.048		.0754	.0566	.0566
22	.056	.9014	.9602		.8855	.0566	.0566
23	.0566	.933	.9762		.9014	.0566	.0377
24	.0526	.0566	.8905	1.0111	.933	.0373	.0566
Max	1.7926	1.4899	.9762	1.0111	1.0159	.8436	1.6194
Min	.0351	.0377	.0354	.0377	.0343	.0366	.0189
Avg	.5741	.5820	.4258	.6720	.4547	.2682	.5438

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 201 / 11 KV MANCHHINDRANAT

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6036	.6036	.6224	.6036	.547	.5847
2	.5906	.6036	.6097	.6036	.5906	.5658	.5847
3	.5906	.5658	.6097	.6036	.5906	.5658	.5847
4	.6036	.6036	.6036	.6224	.6036	.5716	.5906
5	.6859	.679	.679	.679	.8962	.6602	.6602
6	.8589	.811	.8962	.6979		.8865	.8775
7	.8215	.7762	.7682	.7167	.8131	.8316	.7762
8	.5853	.6219	.5611	.5359	.5853	.6089	.6219
9	.5731		.5373	.4572	.5194	.4835	.4835
10	.5316	.5721	.4961	.4161	.5014	.503	.4961
11	.5434	.5609	.5083	.3506	.5144	.4917	.5028
12		.5493	.5201	.4334	.5434	.4854	.5028
13	.5258	.5258	.4557		.5138	.8149	.4681
14	.5316	.5316	.5258		.4835	.4733	.4961
15	.4908	.5493	.4908		.5014	.5194	.4961
16	.5552	.5434	.443		.4161	.4961	.5144
17	.4694	.5256	.4801		.5144	.4458	.4409
18		.5087	.5548		.5144	.4801	.503
19		.788	.8145		.7796	.7522	.9134
20		.8596	.8779		.8962	.8962	.9511
21	.924	.8413	.8413		.8686	.8316	.8589
22	.8316	.7282	.7762		.8131	.7655	.7842
23	.679	.679	.679	.679	.6602	.6722	.6722
24	.6413	.6224	.6224	.6224	.6036	.6224	.6036
Max	.924	.8596	.8962	.7167	.8962	.8962	.9511
Min	.4694	.5087	.443	.3506	.4161	.4458	.4409
Avg	.6318	.6370	.6231	.5743	.6229	.6238	.6237

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 202 / 11KV KRISHNA LIS

PURELY LIS FEEDERS

YEDEMACHHINDR Feeder KV- 11 /  
OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5535	.5601	.5601	.4641	.4696	.5535
2	.5601	.5601	.5535	.5668	.5601	.5601
3	.5601	.5601	.5535	.5668	.5601	.5535
4	.5601	.5601	.5601	.5601	.5668	.5601
5	.5535	.5601	.5601	.5601	.5601	.5535
6	.5601	.5535	.5601	.5601	.5668	.5441
7	.5601	.5668	.5535	.5468	.5668	.5535
8	.5668	.5601	.5601	.5601	.5535	.5668
9	.5761	.5668	.5668	.5967	.5735	.5735
10	.2187	.5668	.5668	.5967	.5898	.5735
11	.583	.5668	.5668	.5601	.5601	.5668
12		.5376	.5668	.5601	.5668	.5601
13	.5556	.5535	.5535	.5535	.5601	.5535
14	.5601	.5535	.5601	.5535	.5601	.4218
15	.5376	.5535	.5601	.5668	.5735	.5376
16	.5668	.5335	.5668	.5441	.5668	.5312
Max	.583	.5668	.5668	.5967	.5898	.5735
Min	.2187	.5335	.5535	.4641	.4696	.4218
Avg	.5381	.5571	.5605	.5573	.5597	.5477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 203 / 11KV Kilemachindragad Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2269	1.182	.1423	.1524	.1638	.1423	1.086
2	1.2226	1.134	.1372	.1524	.1355	.1475	1.086
3	1.2094	1.0631	.1475	.1524	.1475	.1475	1.0631
4	1.2226	1.0517	.1475	.1524	.1638	.1475	1.0745
5	1.2226	1.1568	.1475	.1524		.1905	1.1104
6	1.3847	1.3321	.2035	.1905	.0762	.2035	1.5238
7	1.5775	1.5775	.2204	.1905	.1715	.2204	1.56
8	.1638	.1486	.1844	.1905	.1524	.1783	.1802
9	.1423	.1265	2.2085	1.6004	2.5065	2.3579	.1147
10	.1147	.1265	2.3137	1.9765	2.3312	2.4006	.0947
11	.1265	.1311	2.2885	2.1672	2.2634		.1219
12		.1158	2.2192		2.1026	2.1498	.1219
13		.1082	1.8031		1.7833	1.9765	.1021
14		.1217	1.7337		1.7857	1.8898	.1265
15	.1696	.1475	1.893		1.7703	1.8204	.125
16	.1638	.1158	1.7684		1.5604	1.7177	.1082
17	.1783	.1217	.1082		.1021	.1389	.1353
18		.1353	.1353			.1353	.1488
19		.1638	.1966		.1802	.1562	.1638
20		.1844	.1677		.1865	.1638	.1429
21	.1783	.1844	.1638		.1802	.1677	.1635
22	1.491	.2012	.1619		.1844	1.3969	1.6832
23	1.4175	.1802	.1524	.1638	.1638	1.2757	1.6124
24	1.382	1.3112	.1677	.1905	.1429	.1638	1.1871
Max	1.5775	1.5775	2.3137	2.1672	2.5065	2.4006	1.6832
Min	.1147	.1082	.1082	.1524	.0762	.1353	.0947
Avg	.8108	.5050	.7838	.5717	.8297	.8386	.6182



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 201 / 11 KV RAJARAM NAGER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2667	.2858	.2667	.2667	.2667	.2561
2	.2858	.2286	.3048	.2477	.2667	.2667	.2378
3	.2667	.2286	.2858	.2477	.2286	.2286	.2195
4	.3048	.2667	.2667	.2477	.2286	.2286	.2195
5	.2667	.2667	.2477	.2667	.2667	.2667	.2378
6	.2667	.2667	.2667	.2477	.2667	.3048	.2561
7	.2858	.3048	.2858	.3048	.3048	.2858	.2743
8	.3048	.2667	.2667	.3048	.2667	.3048	.2743
9	.3239	.2667	.2667	.3239	.2286	.2477	.2378
10	.2858	.2667	.2286	.3048	.2378	.2477	.2667
11	.3048	.2477	.2286	.3048	.2378	.2477	.2667
12	.3239	.2477	.2477		.2378	.2667	.3048
13	.3048	.2858	.2477		.2561	.2667	.2667
14	.3239	.2667	.2667		.2561	.2858	.2667
15	.3239	.2667	.2858		.2561	.2667	.2667
16	.3048	.2858	.2858		.2743	.2858	.2667
17	.3239	.2667	.2858		.2926	.2858	.2858
18	.2667	.3048	.2286		.2858	.2926	.362
19	.3048	.3429	.3429		.3429	.3475	
20	.3429	.3239	.362		.3429	.3475	.3429
21	.3048	.3048	.3429		.3048	.3292	.3239
22	.3048	.3048	.3048	.3048	.3239	.3292	1.2765
23	.3048	.2667	.2667	.2667	.3048	.3109	.3048
24	.3048	.2667	.2858	.2667	.2667	.2667	.2743
Max	.3429	.3429	.362	.3239	.3429	.3475	1.2765
Min	.2667	.2286	.2286	.2477	.2286	.2286	.2195
Avg	.3009	.2754	.2786	.2790	.2727	.2824	.3169

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 202 / 11 KV Uran-Islampur

GAOTHAN FEEDER

Gaothan. Feeder KV- 11 /  
OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.9907	1.0288	.9145	.9145	.9335	.9694
2	.9717	.9526	.9717	.8383	.8764	.8764	.9145
3	1.0288	.9145	.9145	.8383	.8764	.8764	.8779
4	1.0288	.9145	.9145	.8764	.9145	.8764	.8779
5	1.2003	.9907	.9907	.9526	.9526	.9717	.8779
6	1.2574	1.1431	1.1812	1.1241	1.0288	1.2384	.9511
7	1.2574	.9907	.9145	.9907	.9907	.9907	.9694
8	1.0288	.8002	.8573	.8383	.8002	.8002	.8413
9	1.0098	.8002	.8192	.8192	.8383	.8002	.7499
10	.9717	.8383	.8764	.8764	.8779	.8192	.8383
11	.9526	.8573	.8383	.4954	.8596	.9145	.8764
12	.9526	.8573	.8764		.8413	.8192	.9526
13	.9526	.8383	.9145		.8596	.8192	1.0288
14	.9526	.8383	.9907		.8596	.9145	1.0669
15	.9526	.8383	.9526		.8962	.9335	.9526
16	1.1622	.9145	1.105		1.0791	1.0479	1.0288
17	1.0669	.9526	1.0098		1.0242	1.0098	1.1431
18	.9526	1.1622	.9526		1.0288	.9877	1.2193
19	1.2955	1.4289	1.3146		1.4098	1.2986	1.5051
20	1.4098	1.2765	1.2955		1.2955	1.3169	1.3717
21	1.2574	1.2384	1.2955		1.3146	1.2437	1.3336
22	1.2193	1.2193	1.2003	.9907	1.2574	1.2437	1.2765
23	1.1812	1.1622	1.1431	.9526	1.105	1.1523	1.1812
24	1.1241	1.0288	1.0669	1.0288	.9526	.9717	1.0242
Max	1.4098	1.4289	1.3146	1.1241	1.4098	1.3169	1.5051
Min	.9526	.8002	.8192	.4954	.8002	.8002	.7499
Avg	1.0931	.9979	1.0177	.8955	.9939	.9940	1.0345

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 203 / 11KV Mahadev Nagar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	.9526	1.0098	.9335	.9526	.9335	.9328
2	1.0288	.8764	1.0288	.8573	.9145	.9145	.8779
3	1.0098	.8383	.9907	.8002	.8764	.8764	.8413
4	1.0098	.8383	.9526	.7621	.8764	.8764	.8413
5	1.2003	.8764	.9717	.7811	.9145	.9335	.8413
6	1.1431	.9145	1.0098	.8383	.9526	1.0669	.8779
7	1.0098	.9145	1.1431	.9145	.9145	.8954	.9145
8	.9717	.9907	.9717	.9145	.9526	.9717	.9511
9	.9717	.8002	.7811	.7621	.8002	.8002	.8048
10	1.1241	.8383	1.086	.9145	1.0608	.8383	.8764
11	.9907	.9145	.9145	.8002	.9511	.9145	.9526
12	1.0479	.9717	.9907		.9511	.9335	.9907
13	.381	.8954	.9145		.9145	.9335	1.0669
14	.381	.8954	.9526		.9877	.9907	1.0669
15	1.2384	.9335			.9877	.9717	1.0288
16	1.1622	.8383	.9145		.9877	.8954	.9907
17	1.105	.9526	.9526		.9877	.9335	1.0669
18	1.0669	1.2765	.9335		1.0098	.9511	1.086
19	1.3717	1.5432	1.4098		1.5242	1.4632	1.6004
20	1.448	1.4098	1.3336		1.4861	1.4632	1.3717
21	1.2955	1.3336	1.2003		1.2955	1.3169	1.3336
22	1.2955	1.2384	1.1431	1.1431	1.2574	1.262	1.1812
23	1.2574	1.105	1.0288	1.0669	1.2193	1.134	1.105
24	1.1622	1.0669	1.0288	.9717	.9907	1.0098	.9877
Max	1.448	1.5432	1.4098	1.1431	1.5242	1.4632	1.6004
Min	.381	.8002	.7811	.7621	.8002	.8002	.8048
Avg	1.0741	1.0090	1.0288	.89	1.0319	1.0117	1.0245

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV KHED GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3662	***	***	***	***	***	
2	.3502	***	***	***	***		
3	.3406	.3003					
4	.3311	***	***	***	***		
5	.3307	***	***	***	***		
6	.3323	.2442					
7	.333	***	***	***	***	.1139	.1395
8		***	***	***	***	.2694	.2614
9			.3086	.293	.2648	.2835	.2683
10		***	***	***	***	.2694	.2652
11		***	***	***	***	.2652	.242
12			.3235	.2995	.298	.2721	.2378
13		***	***	***	***	.2774	.2515
14		***	***	***	***	.2675	.242
15		.1395	.3067	.277	.205	.258	.2324
16		***	***	***	***		
17		***	***	***	***		
18		.389					
19		***	***	***	***		
20		***	***	***	***		
21	.0751	.3487					
22	***	***	***	***	***		
23	***	***	***	***	***		
24	.8913						
Max	24.9715	24.9715	24.9715	24.9715	24.9715	24.9715	.2683
Min	.0751	.1395	.3067	.277	.205	.1139	.1395
Avg	4.8449	19.0936	21.0780	21.0744	21.0690	2.7248	.2378

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV WALWA FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.8669
Max	.8669
Min	.8669
Avg	.8669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV LIS BOR FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.543
Max	.543
Min	.543
Avg	.543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV KHED AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV BORGON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	1.0311
Max	1.0311
Min	1.0311
Avg	1.0311

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 401 / 33 KV Borgaon (from EHV NON SHEDDABLE EXPRESS HV FEEDERS  
 Borgao Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2862	2.2862	2.7435
2		2.0576	2.0576	2.5149
3		2.0576	2.0576	2.5149
4		2.0576	2.0576	2.5149
5		2.0576	2.0576	2.5149
6		2.0576	2.2862	2.7435
7		2.2862	2.2862	2.9721
8		2.0576	2.0576	2.0576
9		2.9721	2.9721	2.0576
10		3.2007	3.2007	2.0576
11		3.4294	3.2007	2.0576
12		3.2007	2.9721	2.2862
13		3.2007	2.9721	2.0576
14	1.829	2.9721	3.2007	2.2862
15	1.829	2.9721	2.9721	1.829
16	2.9721	2.9721	2.5149	2.2862
17	2.2862	2.2862	2.2862	2.2862
18	2.0576	2.2862	2.2862	2.0576
19	2.7435	2.9721	2.9721	2.9721
20	2.9721	3.2007	3.2007	3.4294
21	2.7435	2.9721	3.2007	3.2007
22	2.7435	2.7435	3.4294	3.4294
23	2.7435	2.7435	3.4294	3.4294
24	2.5149	2.5149	3.2007	2.9721
Max	2.9721	3.4294	3.4294	3.4294
Min	1.829	2.0576	2.0576	1.829
Avg	2.4941	2.6482	2.7149	2.5530

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV Kasegaon Gaothan-  
Village Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.439		.415			
2	.415	.3109		.415			
3	.415	.3174		.415			
4	.415	.3734		.415			
5	.5228	.4525		.4904			
6	.6535	.5249		.5788			
7	.6535	.5853		.6161	.6283		
8	.5228	.5359		.5228	.4854		
9		.4938	.4435		.4805	.5121	.4755
10	.4435	.4706	.4477	.4066	.439	.4481	.439
11	.4805	.5068	.3982		.439	.4108	.3982
12	.4435	.394	.362		.3982	.4066	.362
13	.4344	.362	.333	.3361	.4251		.362
14	.4344	.4298	.3681	.3361	.439		.362
15	.4344	.3982	.3856	.2987		.4706	.3292
16	.4207	.4755		.4066		.5068	
17	.462	.4755			.5175		.5175
18	.5175				.6283		.6653
19	.6348				.7468		.7468
20	.6697				.7468		.7468
21	.5914				.6348		.6722
22	.5304				.5658		.6036
23	.4755				.5281		.4904
24	.4527	.4527	.4435	.4527	.6283	.4527	.4805
Max	.6697	.5853	.4477	.6161	.7468	.5121	.7468
Min	.415	.3109	.333	.2987	.3982	.4066	.3292
Avg	.4973	.4443	.3977	.4361	.5457	.4582	.5101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV Nerle Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6413		.6602			
2	.6036	.6283		.5658			
3	.6036	.5544		.5658			
4	.6036	.5601		.5658			
5	.6097	.6348		.6602			
6	.6348	.5281		.7095			
7	.5228	.5228		.6348	.5175		
8	.4481	.415		.5228	.5228		
9		.5975	.4066	.4904	.4108	.5228	.5121
10	.4904	.7095	.679	.4527	.6535	.4854	.5121
11	.679	.8402	.6722	.415	.679	.679	.4805
12	.7468	.8589	.8215		.6535	.5975	.5544
13	.7468	.7207	.7842	.4805	.6653	.7207	.5544
14	.7922	.7392	.8215	.4805		.7392	.5914
15	.811	.8501	.8589	.5914		.7095	.7468
16	.7468	.8299		.415		.6224	
17	.7095				.8299		.8962
18	.7167				.9054		.9335
19	.8589				.9431		1.0082
20	.9054				.9054		1.0185
21	1.0269				.8299		.9808
22	.8962				.7545		.9431
23	.8865	.8299			.6602		.8676
24	.8299	.8299	.4066	.7545	.5975	.8676	.5175
Max	1.0269	.8589	.8589	.7545	.9431	.8676	1.0185
Min	.4481	.415	.4066	.415	.4108	.4854	.4805
Avg	.7228	.6828	.6813	.5603	.7019	.6605	.7411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV Tambave Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.362		.3772			
2	.415	.362		.3772			
3	.415	.3142		.3772			
4	.415	.3142		.3772			
5	.4854	.3841		.4527			
6	.5228	.3841		.5415			
7	.4481	.4344		.5228	.4805		
8	.4108	.3841		.4668	.4108		
9		.362	.3696		.3696	.4435	.3326
10	.3547	.3439	.3658	.4108	.362	.415	.3696
11	.3881	.3326	.362	.462	.3982	.4024	.4024
12	.3881	.3258	.3982	.1478	.3982	.3658	.439
13	.3326	.3109	.3506	.2614	.3292	.3439	.439
14	.2926	.3292	.298	.2614		.3258	.3658
15	.2926	.2926	.298	.2987		.3439	.3258
16	.3224	.3224		.3772		.3658	
17	.3658				.4066		.4066
18	.3658				.4805		.4805
19	.4024				.5228		.5601
20	.439				.5228		.5601
21	.4108				.4481		.5228
22	.3801				.4527		.4904
23	.4572				.415		.4338
24	.4527	.415	.3696	.415	.4805	.4527	.4435
Max	.5228	.4344	.3982	.5415	.5228	.4527	.5601
Min	.2926	.2926	.298	.1478	.3292	.3258	.3258
Avg	.3988	.3514	.3515	.3829	.4318	.3843	.4381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV Wategaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3439		.3395			
2	.3429	.2534		.3018			
3	.3429	.2561		.3018			
4	.3429	.2561		.3018			
5	.381	.3045		.3361			
6	.4763	.3045		.3734			
7	.4191	.3881		.3921	.3696		
8	.381	.3696		.4108	.3361		
9		.2957	.2957		.3326	.3361	.3292
10	.3658	.3224	.2957	.2772	.2957	.3361	.3109
11	.3326	.3403	.2957	.2587	.2957	.2987	.2926
12	.3326	.197	.3326	.2587	.1646	.0366	.2926
13	.2926	.2865	.2926	.2587	.0377	.0549	
14	.3292	.3801	.2195	.2587	.1646	.3658	.2926
15	.3292	.3801	.2926	.2957		.2896	.2715
16	.3258	.3841		.2926		.2896	
17	.3658	.3658			.4066	.2926	.4435
18	.4572	.3696			.4805	.439	.5544
19					.5228	.5544	.5975
20	.6697				.5228		.5975
21	.4706				.4668		.5228
22	.439	.4481			.415		.4904
23	.3921				.3772		.415
24	.381	.4527	.3326	.3772	.3696	.3734	.3696
Max	.6697	.4527	.3326	.4108	.5228	.5544	.5975
Min	.2926	.197	.2195	.2587	.0377	.0366	.2715
Avg	.3869	.3349	.2946	.3147	.3474	.3056	.4129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 205 / 11 KV KASEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.5203	***	***	***	***	
2	1.5242	1.5203	***	***	***	***	
3	1.5242	1.4232	***	***	***	***	
4	1.5242	1.4232	***	***	***	***	
5	1.5623	1.3904	***	***	***	***	
6	1.6004	1.3904	***	***	***	***	
7	1.7528	1.3916	***	***	***	***	
8	***	***		.0914	.1219		***
9	***	***	2.0485		2.0485	1.8278	***
10	***	***	2.0934	1.5779	2.3685	1.8591	***
11	***	***	2.1376	1.5432	2.4006	1.8747	***
12	***	***	2.0729		2.3685	1.8364	***
13	***	***	1.9444	.7621	2.2672		***
14	***	***	1.7593	.7621	2.2672	.7621	***
15	***	***	1.8056	.7621		1.749	***
16	***	***		1.9907		1.6049	***
17	***	***	***	***	***		.8535
18	***	***	***	6.8587	***	***	***
19	***	***	***		.1219	***	.1219
20	***	***	***		***	***	.1219
21	.1067	***	***		.1219	***	.1219
22	1.5546	***	***	***	***		1.7604
23	1.6194	***	***	***	***		1.6004
24	1.6004	***	***	***	***	1.4083	1.5684
Max	175.3698	166.8955	179.8509	145.6487	186.8315	188.2338	187.4717
Min	.1067	1.3904	1.7593	.0914	.1219	.7621	.1219
Avg	71.0367	97.6745	98.7306	64.7538	74.5911	91.7687	91.6135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 206 / 11 KV NERLE AG. FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	1.7394	2.1125			***
2	***	***	1.7394	2.0485			***
3	***	***	1.7394	2.0485	1.6644		***
4	***	***		2.0485	1.6644		***
5	***	***	1.7394	2.1125			***
6	***	***		2.1765			***
7	***	***		2.2405	2.0622		***
8	.061	***	***	.0914	***	***	
9	2.0934	2.2028	***	***	***	***	3.0727
10	2.1559	2.2653	***	***	***	***	2.9287
11	2.1491	2.2994	***	***	***	***	2.5459
12	2.2184	2.2685	***	***	***	***	2.4669
13	2.3122	2.1451	***	***	***	***	2.4215
14	2.2994	2.1872	***	***	***	***	2.3434
15	2.4691	2.0934	***	***	***	***	2.3278
16	1.9509	1.9372	***	***	***	***	
17	.061	***	***	***	***	***	.0914
18	.0914	***		***	.061		***
19	***	***		***	.0914	***	.1219
20	***	***	***	***	***	***	.1219
21	***			***	.0914	***	.1219
22	***				2.3365	***	.1219
23	***	1.7394			2.2405	***	***
24	***	1.7394	2.1125	2.1765	1.9372	***	***
Max	156.3026	181.436	185.9475	189.0421	189.0568	188.2338	185.2768
Min	.061	1.7394	1.7394	.0914	.061	105.2144	.0914
Avg	72.5214	74.8258	93.8498	90.9934	72.5366	138.2535	62.6222



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 207 / 11 KV Wategaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	1.2963		.1524			
2	1.6004	1.3443		.1524			
3	1.6004	1.3283		.1524			
4	1.6004	1.4074		.1524			
5	1.9433	1.3904		.1829			
6	2.0576	1.4685		.1829			
7	1.5242	1.5023		.1829	.1829		
8	.1219	.108		.2134	.1829		***
9	.061	.0781	2.1765		2.1125	1.6667	***
10	.0781	***	2.1445	1.7528	2.0622	1.6821	***
11	.0781	.0617	2.1125	1.7375	1.8122	1.6975	.8095
12	.0937	.0617	1.7654		1.5741	1.6821	.809
13	***	***	1.5586	.7621	1.4998	1.3735	1.0547
14	***	.0469	1.4815	.7621	1.531	1.1728	.0469
15	.0791	.0625	1.4506	.7621		1.2146	.0463
16	.0648	.0463		1.5089		1.2308	
17	.1524				.1829		.1524
18	.1852				.1829		.1829
19					.2134		.2439
20	.216				.2134		.2743
21	.1852				.2134		.2743
22	1.5708				.1829		1.7604
23	1.4413				.1829		1.6004
24	1.6766	1.2963		.1829		1.0883	1.3916
Max	128.0927	185.2323	2.1765	1.7528	2.1125	1.6975	188.2948
Min	.061	.0463	1.4506	.1524	.1829	1.0883	.0463
Avg	11.6878	22.2910	1.8128	.5893	.8220	1.4232	34.8408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 208 / 11 KV Tambave Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.061		2.1125			***
2	.0762	.061		1.9204			***
3	.0762	.0617		1.8884			***
4	.0762	.0772		1.8884			***
5	.0762	.0762		1.8884			***
6	.0762	.0762		1.9204			***
7	.0762	.061		1.9204	1.8976		***
8	2.8487	.061		.0914	.061		***
9	2.8487	2.7587	.061		.061	***	3.1367
10	2.8807	2.8349	.061	.0463	.0633	***	3.1367
11	2.8433	2.9371	.0648	.0625	.0633	***	3.0777
12		1.6842	.0469	.0781	.0633	***	3.0933
13	2.8622	2.4846	.0469	.0463	.0469	***	3.0933
14	2.8147	2.5617	.0469	.0463	.0617	***	2.9371
15	2.5301	2.5621	.0625	.0617		***	2.8704
16	2.359	2.4684		.0617		***	
17	.061				.061	***	.0914
18	.0762				.061	***	***
19					.0914	***	***
20	.0762				.1219	***	***
21	.0762				.1219	***	***
22	.0762				1.9509	***	***
23	.0762				1.829	***	***
24	.0762	1.9204	1.6129	2.2085	1.8976	***	***
Max	2.8807	2.9371	1.6129	2.2085	1.9509	120.4086	140.3446
Min	.061	.061	.0469	.0463	.0469	71.7117	.0914
Avg	1.0472	1.3381	.2504	1.0151	.5283	91.3421	65.2410

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 209 / 11 KV Someshwar

PURELY LIS FEEDERS

Bhairavnath LI Feeder KV- 11 /  
OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4435				
2	.5716	.4435				
3	.5716	.5415				
4	.2858	.5415				
5	.2858	.567				
6	.2858	.567				
7	.3429	.6468		.7023		
8	.2743	.6653		.6653		
9	.5121	.6767	.7655	.7207	.905	.8954
10		.695	.7207		.905	.9055
11	.5068	.6697		.6584	.8962	.9055
12	.6516	.6485	.7095	.8779		.9055
13	.6036	.7011	.6767	.8688	.8507	.7095
14	.6036	.7011	.6401	.8507	.8507	.7095
15	.1629	.6241	.6767			.6908
16	.1629	.6001			.8869	.8962
24						.8954
Max	.6516	.7011	.7655	.8779	.905	.9055
Min	.1629	.4435	.6401	.6584	.8507	.6908
Avg	.4262	.6083	.6982	.7634	.8824	.8348

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 210 / 11 KV Krishna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	.5895				
2	1.7147	.5895				
3	1.7147	.6687				
4	1.7147	.8916				
5	1.7147	1.2094				
6	1.7337	1.2795				
7	1.8671	1.6644				
8	1.7193	1.6289		.0754		
9	1.7558	1.6461	1.595	1.7551	1.8473	1.7147
10		1.6289	1.5604	1.7737	1.7918	1.7002
11	1.7741	1.6461	1.5927	1.7737	1.7194	1.7177
12	1.7926	1.6632	1.5249	1.4661	1.7375	1.7528
13	1.7741	1.6289	1.5074	1.4506	1.7194	1.6297
14	1.6827	1.6118	1.4754	1.2357	1.7375	1.595
15	1.6827	1.6289	1.1568		.7682	1.7353
16	.9945	1.7164			.7865	
Max	1.8671	1.7164	1.595	1.7737	1.8473	1.7528
Min	.9945	.5895	1.1568	.0754	.7682	1.595
Avg	1.6900	1.3557	1.4875	1.3615	1.5135	1.6922

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 202 / 11 KV YELUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.3772	.3961	.3772
2	.3584	.3395	.3584	.3772	.3772	.3395
3	.3584	.3395	.3395	.3584	.3772	.3395
4	.3584	.3395	.3395	.3584	.3772	.3395
5	.3772	.415	.415	.415	.4338	.415
6	.4715	.4715	.5281	.4904	.5281	.4715
7	.5228	.4904	.5093	.4251	.4801	.4527
8	.4066	.4066	.4119	.3658	.3772	.3696
9	.3841	.3601	.394	.3898	.3429	.4251
10	.3429	.3429	.3086	.3012	.3086	.3429
11	.3086	.3086	.2915	.3189	.3086	.3086
12	.3429	.4458	.1829	.2658	.2743	.3258
13	.3429	.2743	.4458	.2629	.2743	.3258
14	.3429	.3086	.2743	.2743	.2743	.2743
15	.3429	.3258	.2743	.2915	.2915	.2401
16	.3944	.3258	.2572	.2915	.2915	.2229
17	.2229	.2743	.2401	.3258	.0343	.2454
18	.3475	.3681	.3898	.3944	.3155	.2804
19	.3658	.5068	.4887	.5731	.1097	.4656
20	.6224	.6283	.5601	.6283	.5544	.5914
21	.5175	.5788	.5415	.5601	.5281	.547
22	.547	.5281	.5281	.5228	.5093	.5281
23	.4715	.4527		.4294	.4527	.4527
24	.415	.3961	.415	.4108	.415	.3961
Max	.6224	.6283	.5601	.6283	.5544	.5914
Min	.2229	.2743	.1829	.2629	.0343	.2229
Avg	.3976	.4002	.3857	.3920	.3597	.3782

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 203 / 11 KV Aitwadi Kh -Gaothan-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.2641	.3395	.3547	.3584	.3018
2	.3395	.2641	.3395	.3547	.3584	.3018
3	.3206	.2641	.3206	.3547	.3395	.3018
4	.3018	.2641	.3206	.3734	.3395	.3018
5	.3584	.3395	.3772	.4108	.3961	.415
6	.3961	.4527	.4854	.4481	.4715	.4527
7	.4481	.415	.462	.4435	.4287	.4527
8	.3696	.4108	.3582	.4024	.3258	.3696
9	.3109	.3086	.3077	.3045	.2915	
10	.2743	.3086	.2743	.3189	.2915	.2401
11	.2743	.3086	.2401	.2454	.2401	.1715
12	.2743	.3086		.2865	.2743	.2058
13	.3086	.3429	.3086	.3366	.2743	.2401
14	.3086	.3429	.3086		.3086	.3086
15	.3429	.3086	.3086	.3086	.3429	.3086
16	.3429	.2804	.3429		.3086	.3086
17	.3086	.2915	.3086		.4458	.3155
18	.3506	.3721	.3898	.3814	.4207	.3155
19	.3982	.4706	.5068	.5788	.4298	.4656
20	.5281	.5175	.5304	.5788	.5914	.5544
21	.5281	.4854	.5175	.5228	.5281	.5658
22	.4904	.4668	.4668	.4668	.4904	.4904
23	.4158	.3772		.3921	.3772	.4527
24	1.6651	.3395	.3395	.3547	.3584	.3395
Max	1.6651	.5175	.5304	.5788	.5914	.5658
Min	.2743	.2641	.2401	.2454	.2401	.1715
Avg	.4173	.3543	.3706	.3913	.3746	.3556

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 204 / 11 KV WASHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2641	.3206	.3018	.3018	.2641
2	.3206	.2641	.3018	.3018	.3018	.2641
3	.3018	.2641	.3018	.3018	.2829	.2641
4	.3018	.2641	.3018	.3018	.3018	.2641
5	.3772	.3395	.3206	.3395	.3584	.2641
6	.415	.415	.4668	.4527	.4527	.4527
7	.4668	.4527	.462	.4066	.3601	.415
8	.3696	.3658	.443	.3801		.3696
9	.4024	.3772	.2534	.3086	.3086	.3326
10	.3429	.3086	.2743	.2743	.3258	.823
11	.3086	.2743	.2915	.2229	.3086	.8573
12	.3429	.2743	.2572	.2229	.3086	.2743
13	.3429	.2743	.2229	.2229	.3086	.2401
14	.3258	.2743	.2401	.2401	.3086	.2743
15	.3086	.2743	.3258	.2743	.3086	.2743
16	.2915	.3086	.2743	.2915	.3086	.3086
17	.2572	.2572	.2743	.3121	.3086	.3155
18	.3403	.3189	.3544	.3429	.3155	.3155
19	.4435	.4755	.4525	.567	.415	.4805
20	.5658	.5544	.499	.5544	.5658	.6348
21	.4715	.5228	.4668	.4854	.5281	.5658
22	.4527	.4481	.4527	.4294	.4527	.4715
23	.415	.3772		.3361	.415	.415
24	.3584	.3395	.3206	.3174	.3018	.3018
Max	.5658	.5544	.499	.567	.5658	.8573
Min	.2572	.2572	.2229	.2229	.2829	.2401
Avg	.3693	.3454	.3425	.3412	.3543	.3934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 205 / 11 KV Aitwade Kh Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0377	1.5927	1.6741	1.5912	.0377
2	.0566	.0377	1.5424	1.6078	1.5249	.0377
3	.0566	.0377	1.4918	1.5581	1.4746	.0377
4	.0566	.0377	1.4918	1.5249	1.4091	.0377
5	.0566	.0377	1.543	1.5249	1.4586	.0566
6	.0754	.0754	1.6108	1.6575	1.5581	.0754
7	.0754	.0754	.0914	1.6907	1.6118	.0754
8	.0754	.0754	.0724	.0754	.0514	.0754
9	1.7635	1.5089	.0366	.037	.0343	2.3537
10	2.2291	1.6118	.0343	.0366	.0343	2.4348
11	2.2977	1.7833	.0343	.0366	.0343	2.4348
12	2.4006	1.8861	.0343		.0686	2.2977
13	2.6063	2.0919	.0343		.0343	2.2291
14	2.7778		.0343	.0358	.0343	2.2291
15	2.4006	2.1948	.0343	.0358	.0343	2.2291
16	2.0919	2.6749	.0343	.0358	.0343	2.1262
17	1.6118		.0343		.0343	.0351
18	.0347	1.8176	.0526	.0549	.0358	.0351
19	.0543	.0566	.0754	.056	.0739	.0754
20	.0754	.0566	.0754	.0754	.0754	.0754
21	.0754	.0566	.0754	.0754	.0754	.0754
22	.0566	1.8442	1.95	1.6244	.0754	.0754
23	.0566	1.6766		1.6741	.0754	.0754
24	.0566	.0377	1.6263	1.7901	.0739	.0566
Max	2.7778	2.6749	1.95	1.7901	1.6118	2.4348
Min	.0347	.0377	.0343	.0358	.0343	.0351
Avg	.8791	.8960	.5914	.8039	.4795	.8030



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 207 / 11 KV WASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6964	.8619	***	***	***	***	.4062
2	.7045	.7956	***	***	***	***	.4062
3	.6718	.7956	***	***	***	***	.4904
4	.663	.7956	***	***	***	***	.5624
5	.7712	.9282	***	***	***	***	.7499
6		1.0277	***	***	***	***	.8962
7	.8718	1.094	***	***	***	.381	.0701
8	***	***	.0732		.0943	.381	***
9	***	***	1.8461		1.8564	.381	***
10	***	***	1.8861		1.8233		***
11	***	***	1.8519		1.4746	1.5432	***
12	***	***	1.7147		1.247	1.5432	***
13	***	***	1.4403	.381	1.1203	1.4746	***
14	***	***	1.2346	.381	.9922		.4153
15	***	***	1.166	.381	.9602	.3086	***
16	***	***	1.0974		.8539	.8916	***
17	***	***	***		***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	.0943	***	***	***	***	.1132	***
22	1.2266	***	***	***	***	.8855	1.2452
23	1.1603	***	***	***	***	.8322	1.2597
24	.7287	***	***	***	***	.0754	.4801
Max	131.1864	117.8523	111.7201	120.7897	121.265	113.2632	131.1712
Min	.0943	.7956	.0732	.381	.0943	.0754	.0701
Avg	39.3830	65.4688	58.2390	84.1650	65.2951	38.8639	50.4295

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 208 / 11 KV YELUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3279	1.3765	.0943	.0754	.0943	.7316
2	1.2955	1.3603	.0943	.0754	.0943	.7316
3	1.3108	1.3603	.0943	.0754	.0943	.7316
4	1.3108	1.3603	.0943	.0754	.0943	.8025
5	.4144	1.4255	.0943	.0754	.0943	.9568
6	1.5912	1.5415	.1132	.0943	.1132	1.1873
7	1.7901	1.5581	.0943	.0934	.0686	1.3125
8	.0943	.0895	.1109	.0924	.0857	.0876
9	.0754	.0857	2.6189	2.5857	2.2119	.0724
10	.0857	.0686	2.572	2.4531	2.2119	.0686
11	.0857	.0686	2.5206	2.1628	1.8004	.0686
12	.0686	.0686	2.2291	1.9595	1.8004	.0686
13	.0686	.0857	1.6804	1.6518	1.749	.0857
14	.0857	.0686	1.5775	1.5384	1.749	.0686
15	.0857	.0686	1.5775	1.4723	1.5261	.0686
16	.0857	.0686	1.6289	1.3599	1.2689	.0686
17	.0686	.0686	.0229	.0686	.0343	.0701
18	.0857	.0905	.0905	.1029	.0701	.0701
19	.1109	.1294	.1307	.1463		.1267
20	.133	.1509	.132	.1294	.132	.1478
21	.132	.132	.132	.112	.1132	.132
22	1.9062	.1132	.1132	.1132	1.1363	1.6575
23	1.757	.0943		.1132	1.0883	.1307
24	1.3765	1.4089	.0943	.0754	.0943	.7621
Max	1.9062	1.5581	2.6189	2.5857	2.2119	1.6575
Min	.0686	.0686	.0229	.0686	.0343	.0686
Avg	.6394	.5351	.7787	.6959	.7707	.4253

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 209 / 11 KV Kundalwadi Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	2.0348		2.0348	2.0687	.0377
2	***	***	2.0348		1.933	1.9784	.0377
3	***	***	1.9784		1.8991	1.8945	.0377
4	***	***	1.9448		1.8482	1.8442	.0377
5	***	***	1.9669		1.8991	1.8652	.0566
6	***	***	2.1195		2.0348	1.8991	.0566
7	***	***	2.1795		2.1365	.0514	.0566
8	.0754	.0754	***	***	***	***	.0377
9	3.0864	3.4979	***	***	***	***	3.0498
10	3.2579	3.0521	***	***	***	***	3.0864
11	3.3265	3.0178	***	***	***	***	2.915
12	2.915	3.0864	***	***	***	***	2.915
13	2.7778	2.915	***	.381	.381	***	2.8121
14	2.7778	2.8807	***	.381	***	***	8.059
15	2.915	2.8121	***	.381	***	***	2.9492
16	3.1207	2.8121	***		***	***	3.0864
17	***	***	***		***	***	.0351
18	***	***	***	***	***	***	.037
19	***	***	***	***	***	***	.037
20	***	***	***	***	***	***	.0566
21	***	.0566	.0754		.0754	***	.0758
22	***	2.4417	2.572		2.3739	***	.0377
23	***	2.3061			2.2721	***	.0377
24	***	.0377	2.1704		2.2552	***	.0377
Max	99.9079	102.9562	86.9525	97.1652	87.7146	81.999	8.059
Min	.0754	.0377	.0754	.381	.0754	.0514	.0351
Avg	48.8987	35.0002	34.5845	52.6182	31.4325	44.0473	1.2327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 202 / 11 KV ITKARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1494	1.5089	1.8861	1.9753	1.6804	.1372
2	.1294	.1307	1.4746	1.7147	1.6575	1.6461	.12
3	.1294	.1307	1.4746	1.7147	1.6244	1.6461	.12
4	.1478	.1307	1.5729	1.7833	1.5912	1.6461	.12
5	.2033	.168	1.6095	1.8519	1.6907	1.829	.1372
6	.2218	.2075	1.6461	2.1365	1.8107	1.9022	.2126
7	.2172	.1848	2.2081	1.9393	1.861	1.9204	.1949
8	.1791	.1578	.181	.1463	.1478	.181	.1949
9		2.9058	.1372	.1463	.1267	.1372	3.0653
10	3.0178	2.8349	.1372	.1463	.1086	.1417	3.4019
11	2.8807	2.5968	.1372	.1612	.1086	.1463	3.2247
12	2.572	2.5968	.1372	.1612	.1448	.1448	2.8349
13	2.4874	2.1672	.1595	.1612	.1448	.1478	2.5072
14	2.3891	2.1152	.1646		.1433	.1663	2.4356
15	2.3167	1.8519	.128		.1629	.181	2.2923
16	2.1719	1.7833	.1433		.1629	.1463	2.0271
17	.12	.1402	.1463		.1753	.1478	.1372
18	.1372	.1578	.1663		.1928	.1463	.1543
19	.1829	.1829	.2012		.2195	.1829	.181
20	.2033	.1715	.2587		.2058	.2149	.1848
21	.1867	.1829	.2402		.2195	.2172	.1867
22	.1867	2.0119	2.1948		2.4508	.181	.168
23	.1698	1.8461	2.1262		2.0576	.1848	.1494
24	.1663	.1698	1.6118	2.0233	1.9006	1.7833	.1433
Max	3.0178	2.9058	2.2081	2.1365	2.4508	1.9204	3.4019
Min	.12	.1307	.128	.1463	.1086	.1372	.12
Avg	.8941	1.0406	.8236	1.1409	.8701	.6967	1.0138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 204 / 11 KV ITKARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3292	.3326	.3326	.3292	.3326	.3326
2	.3292	.2926	.3326	.3326	.3292	.3292	.3326
3	.2926	.2926	.3326	.3326	.2926	.3292	.3326
4	.2926	.2926	.3326	.3326	.2926	.3292	.3326
5	.3292	.3109	.3696	.3326	.3292	.3696	.3658
6	.3841	.3292	.439	.439	.4024	.4024	.4207
7	.3658	.3841	.4066	.4024	.3841	.3696	.4024
8	.3109	.3292	.3326	.2957	.4207	.3326	.3361
9		.2743	.3696	.2772	.439	.3696	.3511
10	.3326	.3326	.3292	.2772	.4066	.3475	.3696
11	.3292	.3734	.3292	.2378	.4066	.4024	.2353
12	.3292	.3734	.2561	.2561	.3109	.0934	.2353
13	.2561	.3361	.3109	.2561	.3109	.0934	.2743
14	.2561	.3361	.3109		.3109	.2241	.2743
15	.2957	.3547	.2896		.3511	.2743	.3142
16	.2218	.3361	.3142		.3109	.2772	.3142
17	.2957	.3142	.3142		.3734	.2957	.3142
18	.2957	.2957	.3361		.3734	.2957	.3326
19	.4207	.439	.4207		.439	.4024	.4024
20	.4572	.4805	.4572		.4805	.439	.439
21	.4572	.439	.439		.439	.439	.439
22	.4207	.3696	.439		.3696	.4207	.4207
23	.3841	.3658	.3696		.3696	.3881	.4024
24	.3658	.3658	.3696	.3696	.4024	.3696	.3511
Max	.4572	.4805	.4572	.439	.4805	.439	.439
Min	.2218	.2743	.2561	.2378	.2926	.0934	.2353
Avg	.3370	.3478	.3556	.3196	.3697	.3303	.3469

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 205 / Shivtirtha Express Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0617	.0686	.0686	.0693	.0686	.0747
2	.0693	.061	.0686	.0686	.0381	.0686	.0747
3	.0686	.0602	.0686	.0686	.0389	.0686	.0747
4	.0693	.0191	.0229	.0305	.0194	.0343	.0686
5	.0686	.0232	.0152	.0274	.0221	.0229	.0267
6	.0554	.0038	.0042	.0248	.0191	.0061	.0065
7	.0038	.0038	.0038	.0183	.0046	.0191	.0183
8	.0038	.0191	.0038	.0191	.0168	.0152	.0076
9		.0191	.0061	.0191	.0072	.0057	.0061
10	.0038	.0051	.0091	.0046	.0381	.0084	.0076
11	.0038	.0754	.0747	.0754	.0572	.0152	.0076
12	.0686	.0953	.0754	.0754	.0739	.0943	.0943
13	.0857	.0953	.0943	.0754	.0943	.0943	.0754
14	.0686	.0754	.0943		.0381	.0943	.0754
15	.0686	.0171	.0943		.0572	.0943	.0152
16	.0229	.0116	.0943		.0343	.0282	.0152
17	.0152	.005	.0943		.0343	.0248	.0053
18	.0038	.0038	.0179		.0343	.0206	.0057
19	.005	.0038	.0137		.0061	.0175	.0183
20	.0046	.0061	.0152		.0038	.0152	.0229
21		.0038	.0152		.0038	.0152	.005
22	.0465	.0686	.0739		.0686	.0754	.0351
23	.0762	.0686	.0754		.0686	.0739	.0754
24	.0701	.0693	.0686	.0754	.0732	.0686	.0747
Max	.0857	.0953	.0943	.0754	.0943	.0943	.0943
Min	.0038	.0038	.0038	.0046	.0038	.0057	.005
Avg	.0432	.0365	.0489	.0465	.0384	.0437	.0371

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 201 / 11 KV Karanjawade Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3506	.3506	.3856	.3506	.3155	.3506
2	.3155	.3506	.3506	.3856	.3506	.3155	.3506
3	.3155	.3506	.3155	.3506	.3506	.3155	.3506
4	.3506	.3856	.3506	.3506	.3506	.3506	.3506
5	.3506	.4207	.3856	.3856	.3856	.3506	.3506
6	.3856	.4557	.3155	.4207	.3856	.3856	.3856
7	.3155	.3856	.3155	.3155	.3506	.3155	.3155
8	.3506	.4557	.3506	.3506	.3856	.3189	.3155
9	.3856	.4207	.2804	.3856	.3856	.2835	.3506
10	.3856	.3856	.3155	.3856	.3506	.3544	.3155
11	.3506	.3506	.2804	.2804	.3155	.2835	.3506
12	.3155	.3506	.3506	.3506	.3155	.3189	.3506
13	.3856	.3506	.3506	.2629	.3506	.2481	.3155
14	.3155	.3856	.3155		.2804	1.7284	.2454
15	.3155	.4207	.3155		.2454	.3189	.3155
16	.3155	.3506	.3506		.2454	.3189	.3155
17		.3506	.3506		.2454	.2481	.3155
18	.2987	.3506	.2804		.2804	.2804	.3155
19	.3856	.4207	.3506		.3856	.4207	.3506
20	.5258	.5258	.4908		.4908	.4557	.5258
21	.5959	.5258	.4557		.4557	.4908	.5258
22	.5258	.5258			.3856	.4207	.4207
23	.4557	.4908	.4207		.3506	.3856	.3506
24	.3155	.3856	.3856	.4207	.3506	.3506	.3506
Max	.5959	.5258	.4908	.4207	.4908	1.7284	.5258
Min	.2987	.3506	.2804	.2629	.2454	.2481	.2454
Avg	.3727	.4061	.3490	.3593	.3476	.3990	.3535

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 202 / 11 KV Devarde AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3123	1.2193	.0747	.0747	.112	.0943	.9686
2	1.2811	1.2193	.0747	.0747	.112	.0943	.9374
3	1.2811	1.2193	.0747	.0747	.112	.0943	.9374
4	1.3123	1.2811	.0943	.0747	.112	.0934	.9998
5	1.3123	1.3435	.0943	.0747	.112	.112	1.2498
6	1.3748	1.3272	.112	.0747	.112	.112	1.406
7	1.5935	1.1728	.112	.0934	.1494	.112	1.406
8	.0934	.112	.112	.0934	.112	.1307	.112
9	.0747	.112	2.5286	2.3434	2.6871	2.3434	.112
10	.0747	.0934	2.6246	2.1247	2.6246	2.1872	.0934
11	.0747	.112	2.4966	1.9685	2.3122	2.2138	.0934
12	.0747	.112	2.1559		2.1247	1.9925	.112
13	.112	.1132	1.8747		1.9685	1.7924	.0943
14	.112	.1132	1.9372		1.8747		.0754
15	.112	.1132	1.8747		1.8747	1.7166	.0943
16	.0747	.1132	1.5623		1.6872	1.3927	.1132
17		.0943	.112		.0934	.112	.132
18	.0747	.0754	.112		.1494	.112	.1132
19	.0934	.1509	.112		.1494	.112	.1132
20	.0934	.0943	.112		.1307	.1494	.1132
21	.0934	.1307	.112		.1307	.112	.1132
22	1.5242	.1494			.132	1.1561	1.5935
23	1.4632	.112	.112		.132	1.0936	1.5623
24	.0747	1.2498	.0934	.0934	.112	.1132	.9686
Max	1.5935	1.3435	2.6246	2.3434	2.6871	2.3434	1.5935
Min	.0747	.0754	.0747	.0747	.0934	.0934	.0754
Avg	.5951	.4931	.8073	.5971	.7965	.7583	.5631



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 203 / KARVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0602	.0753	.3567	.602	.6836	.6539	.0594
2	.0602	.0602	.3269	.602	.6539	.6539	.0594
3	.0602	.0602	.2972	.602	.6539	.6241	.0594
4	.0602	.0903	.3567	.602	.7133	.6836	.0594
5	.0753	.0903	.4161	.6321	.8128	.7133	.0892
6	.0903	.1204	.535	.6321	.9031	.9214	.0892
7	.1204	.1204	.5944	.7526	.8916	.9214	.1189
8	.1204	.1204	.0594	.0753	.0892	.08	.1204
9	.7526	.6622	.0892	.0753	.0903	.0892	.9214
10	.8128	.6923	.0903	.0892	.0753	.0594	.7727
11	.6923	.6622	.0903	.0743	.0903	.0892	.7133
12	.5117	.6622	.0903			.0594	.6836
13	.5719	.5268	.0903			.0892	.6241
14	.5719	.5418	.0753		.0753	.0594	.5944
15	.602	.5719	.0753		.0753	.0892	.6241
16	.0602	.5418	.0903		.0753	.0594	.5944
17		.0753	.0892		.0903	.0594	.0594
18	.0753	.0753	.0743		.1189	.0892	.0743
19	.0903	.1189	.0892		.0892	.0892	.0892
20	.0903	.0892	.0892		.0892	.0892	.0892
21	.0903	.0892	.1189		.104	.0892	.0892
22	.0903	.3715			.743	.0892	.0892
23	.0903	.3715	.7526		.7133	.0892	.0743
24	.4458	.0753	.3715	.6622	.6836	.6836	.0594
Max	.8128	.6923	.7526	.7526	.9031	.9214	.9214
Min	.0602	.0602	.0594	.0743	.0753	.0594	.0594
Avg	.2694	.2860	.2269	.4501	.3870	.2968	.2836

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 204 / Ganesh Chikurde LIS Feeder PURELY LIS FEEDERS  
Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1448	.0905	.1448	.1448	.1629
2	.1448	.1448	.0724	.1448	.1448	.1629
3	.1448	.1448	.0724	.1448	.1448	.1629
4	.1448	.1448	.0724	.1448	.1448	.1629
5	.1448	.1448	.1629	.1448	.1448	.1629
6	.1448	.1448	.1629	.1629	.1448	.1629
7	.181	.1629	.2172	.1448	.1448	.1629
8	.1629	.1629	.181	.1448	.1448	.181
9	.1629	.1629	.181	.1448	.1448	.0724
10	.1629	.1629	.181	.0543	.1448	.1629
11	.1629	.1448	.181	.1267	.0724	.1629
12	.1629	.1629	.181	.181	.0724	.1629
13	.1629	.1629	.181	.181	.0724	.1629
14	.1629	.1629	.181	.181	.0724	.1629
15	.1629	.1629	.181	.181	.0724	.1629
16		.1629	.1629	.181	.0724	.1448
20						.1448
Max	.181	.1629	.2172	.181	.1448	.181
Min	.1448	.1448	.0724	.0543	.0724	.0724
Avg	.1569	.1550	.1539	.1505	.1177	.1565

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 401 / 33KV MIDC (FROM PETH EHV) NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	16.118	16.5295	15.9122	14.129	17.0782	14.5405
2	15.3635	16.8725	15.4321	14.4033	17.0782	14.8148
3	15.1578	15.8436	15.0892	14.3347	16.4609	14.1976
4	15.2949	16.118	14.4033	13.7174	16.4609	14.1976
5	14.5405	16.0494	14.1976	14.129	16.2552	14.0604
6	15.2264	16.7353	14.3347	14.8834	16.8725	14.6091
7	15.3635	17.8327	15.1578	15.5007	17.5583	14.7462
8	12.963	13.786	11.1797	11.1797	12.5515	12.7572
9	19.6159	17.1468	11.5912	15.6379	15.9808	19.5474
10	21.6736	19.6159	12.2085	18.2442	16.4609	21.3306
11	22.3594	20.7819	12.8944	19.6159	17.1468	22.1537
12	22.428	20.8505	12.7572	20.1646	18.7929	21.5364
13	21.8793	19.9589	9.3964	19.2044	18.7929	21.7421
14	20.0275	18.6557	9.1907	18.107	17.1468	19.6845
15	20.6447	19.6845	9.6708	18.8615	18.2442	20.5076
16	20.6447	19.8903	11.797	18.45	17.5583	20.7133
17	14.4033	14.6091	9.5336	13.5117	14.0604	15.9122
18	14.129	13.0316	9.3279	13.4431	13.2373	15.1578
19	13.4431	13.2373	9.3964	13.5803	13.1002	14.4719
20	13.5117	13.3745	10.0137	13.786	13.6489	14.8834
21	12.4143	12.3457	9.465	12.6886	12.8944	13.9232
22	15.9122	15.9122	12.4829	16.2552	14.129	16.1866
23	16.5981	16.2552	13.6489	16.8039	15.1578	16.941
24	15.8436	16.4609	13.5803	16.3923	15.0892	16.8725
Max	22.428	20.8505	15.9122	20.1646	18.7929	22.1537
Min	12.4143	12.3457	9.1907	11.1797	12.5515	12.7572
Avg	16.8982	16.7324	12.1942	15.7093	15.9065	16.8953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 403 / (Kurloop)Shirala

Feeder KV- 33 / INCOMING

DATE	01-APR-17
HR	Load (MW)
24	9.8857
Max	9.8857
Min	9.8857
Avg	9.8857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 404 / 33KV Islampur( From Peth      NON SHEDDABLE EXPRESS HV FEEDERS  
EHV) Feeder KV- 33 / INCOMING      (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	05-APR-17
HR	Load (MW)
1	5.487
Max	5.487
Min	5.487
Avg	5.487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 405 / 33 KV Dindayal Sut Girani NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	1.2894
Max	1.2894
Min	1.2894
Avg	1.2894

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 406 / 33 KV Echo Board

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	3.0087
Max	3.0087
Min	3.0087
Avg	3.0087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 407 / 33 KV Kasegaon Feeder  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	5.2126
Max	5.2126
Min	5.2126
Avg	5.2126



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 201 / 11 KV BIUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3287	4.2258	.1749	.1688	.1505	.0705	1.9204
2	4.1609	3.4751	.1749	.1699	.1524	.0705	1.9753
3	4.1316	3.4244	.1749	.1699	.1349	.0705	1.9753
4	4.0788	3.3482	.1749	.1688	.1356	.0705	1.8964
5	4.2341	3.4294	.1749	.1688	.1364	.0846	1.8747
6	4.3438	3.6789	.1749	.1699	.1631	.0846	1.8442
7	4.3214	3.5734	.1749	.1856	.1966	.0846	1.7593
8	.1829	.3951	.2652	.2134	.1951	.0846	.0914
9	.1699	.1665	5.7723	5.7247	6.368	2.2558	.0762
10	.1951	.0762	5.964	5.9213	6.3863	2.4905	.061
11	.1341		5.8223	5.6394	5.9004	2.2085	.064
12	.1505		5.5746	2.8959	5.298	2.0645	.061
13	.1816	.2652	5.2987		4.952	2.1125	.0617
14	.1654	.1749	3.8257		4.8316	1.9204	.0625
15	.1524	.0762	1.5844		4.8438	2.0805	.0625
16	.192	.1467	2.8258	2.1338	4.792	1.9524	.0914
17	.1505	.2652	.5182	.6859	.5544	.0937	.096
18	.1654	.2793	.1387	.0762	.1467	.0772	.0914
19	.1654	.2652	.1676	.0762	.1608	.061	.0434
20	.1665	.2652	.1676	.0762	.1467	.0937	.0903
21	.1654	.189	.1688	.0762	.1608	.0926	.0914
22	4.7284	.1608	.1676	.0762	.1608	1.9528	2.1373
23	5.0755	.1608	.1534	.0762	.1467	2.0679	2.2253
24	4.6963	2.127	.1749	.1688	.0762	.0705	1.9444
Max	5.0755	4.2258	5.964	5.9213	6.3863	2.4905	2.2253
Min	.1341	.0762	.1387	.0762	.0762	.061	.0434
Avg	1.9349	1.3713	1.6589	1.1925	1.9246	.9256	.8582

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 202 / 11 KV SHIRALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.8261	.0309	.0793	.0712	.0751	.6203
2	.8602	.7948	.0309	.0793	.0716	.0751	.6081
3	.8329	.7697	.0008	.0534	.0705	.0751	.631
4	.82	.7934	.0309	.0709	.0709	.0751	.6111
5	.8322	.8051	.0309	.0751	.0789	.0751	.6211
6	.8737	.8863	.0728	.0762	.0777	.0842	.6623
7	.9556	.9168	.0724	.0808	.0815	.0938	.7145
8	.0743	.0575	.0576	.117	.1006	.0785	.0743
9	.0636	.0491	1.1599	1.0131	1.1298	1.0315	.0793
10	.0758	.0637	1.0932	1.0051	1.0695	.9286	.0728
11	.0766	.0678	1.0642	.9233	.9541	.8951	.0712
12	.0777	.0755	1.0086	.4919	.9164	.8577	.0717
13	.0858	.0797	.9389		.8504	.8276	.0591
14	.0804	.0766	.9275		.8566	.8097	.0747
15	.0846	.0785	.8612		.8798	.7933	.0835
16	.0796	.0717	.8188	.3925	.8672	.8631	.08
17	.0293	.0682	.0777	.0591	.077	.0865	.0743
18	.0831	.0758	.0812	.0431	.0903	.0831	.0941
19	.0819	.0861	.0797	.0541	.0819	.0823	.0933
20	.0865	.093	.0858	.0476	.0972	.0884	.0971
21	.1128	.0941	.0842	.0499	.0968	.1258	.1452
22	.8178	.069	.0774	.0404	.0358	.6691	.7563
23	.8268	.0553	.0838	.0404	.0797	.6367	.711
24	.8757	.3666	.0823	.0637	.0465	.3799	.6763
Max	.9556	.9168	1.1599	1.0131	1.1298	1.0315	.7563
Min	.0293	.0491	.0008	.0404	.0358	.0751	.0591
Avg	.4023	.3050	.3688	.2312	.3647	.4079	.3243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 203 / 11 KV NATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0579	.5243	.4374	.3269	.3932	.061
2	.061	.0594	.5243	.4374	.2972	.3563	.061
3	.061	.0594	.4915	.4218	.301	.3563	.0602
4	.061	.0579	.4915	.4167	.3048	.3239	.0602
5	.061	.0594	.5571	.4167	.2972	.3887	.061
6	.0762	.0892	.5898	.4218	.3269	.3239	.061
7	.0781	.0903	.6299	.4687	.4268	.3768	.0914
8	.0937	.0892	.0457	.0772	.0892	.0457	.0762
9	.9145	.6401	.0457	.0594	.0594	.0457	.6923
10	.9633	.583	.0446	.061	.061	.061	.6249
11	.9031	.9496	.0457	.0594	.0594	.061	.5624
12	.884	1.0004	.0457	.0602	.061	.061	.4877
13	.8535	.9614	.029		.0594	.061	.4572
14	.8322	.9221	.0457		.061	.061	.3658
15	.8322	.9221	.0594		.0457	.061	.3658
16	.8025	.7449	.061		.061	.061	.3353
17		.061	.0617		.061	.061	.061
18	.0743	.0762	.061		.0457	.0762	.0892
19	.0892	.0762	.0762		.061	.0937	.0914
20	.088	.0762	.0762		.061	.0914	.0743
21	.0734	.0762	.0762		.061	.0762	.0743
22	.0724	.6062	.5624		.0305	.061	.0892
23	.0587	.5735	.5468		.426	.061	.0587
24	.0594	.0602	.5506	.0594		.3887	.0617
Max	.9633	1.0004	.6299	.4687	.4268	.3932	.6923
Min	.0587	.0579	.029	.0594	.0305	.0457	.0587
Avg	.3502	.3705	.2601	.2613	.1558	.1644	.2093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 204 / 11 KV KAPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0181	1.4571	1.4396	1.8306	1.7794	2.0615	1.1519
2	1.5012	1.411	1.4007	1.714	1.6804	1.9044	1.1557
3	1.4837	1.3606	1.3039	1.5886	1.6366	1.829	1.1656
4	1.4692	1.4435	1.3466	1.6023	1.6532	1.7535	1.1934
5	1.512	1.4982	1.5882	1.6446	1.7821	1.8984	1.2258
6	1.6092	1.7098	1.9332	2.0358	2.2032	2.2672	1.3282
7	1.7756	1.7829	2.4343	2.6528	2.8052	2.5248	1.4575
8	.5514	.554	.62	.5609	.6028	.6972	.498
9	3.511	3.3791	1.9806	1.8179	1.973	1.7812	3.5624
10	3.517	3.1789	1.9158	1.7893	1.8601	1.6998	3.4183
11	3.1078	2.843	1.8732	1.6369	1.6949	1.5893	3.0582
12	2.8205	2.5498	1.7459	.7582	1.5969	1.4792	3.0152
13	2.7443	2.2615	1.6849	.1859	1.5111	1.4868	2.7725
14	2.5949	2.1514	1.6225	.2012	1.5097	1.483	2.6078
15	2.5622	2.2192	1.5341	.2065	1.483	1.4456	2.4852
16	2.6193	2.2343	1.4091	.4641	1.4807	1.4792	2.29
17	.472	.5501	.4443	.2309	.4043	.479	.4386
18	.5354	.4586	.468	.2439	.4487	.4619	.4969
19	.5388	.491	.4889	.2652	.4942	.5156	.5319
20	.5578	.4817	.5342	.2972	.5095	.5365	.5393
21	.5121	.5079	.5456	.2911	.5167	.5396	.5342
22	1.5387	1.7505	2.3777	1.3154	2.6463	1.3333	1.4044
23	1.4929	1.6769	2.4638	1.3062	2.368	1.2475	1.3496
24	1.5055	1.7292	1.9605	2.0077	1.1988	1.5348	.972
Max	3.517	3.3791	2.4638	2.6528	2.8052	2.5248	3.5624
Min	.472	.4586	.4443	.1859	.4043	.4619	.4386
Avg	1.7313	1.6533	1.4632	1.1103	1.4933	1.4178	1.6105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 205 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	04-APR-17
HR	Load (MW)
11	.4024
12	.4066
Max	.4066
Min	.4024
Avg	.4045

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 206 / 11 KV BIUR GAOTAHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6192	.5914	.6192	.5447	.5979	.5716	.5898
2	.5765	.5746	.5472	.5503	.5255	.5038	.525
3	.5342	.5464	.4904	.5218	.4816	.5019	.5255
4	.5681	.5826	.4858	.5391	.4599	.4977	.5178
5	.6138	.6466	.6081	.5811	.4294	.6237	.5548
6	.6942	.703	.7229	.6927	.49	.7099	.6278
7	.8412	.82	.7811	.8063	.6062	.8337	.809
8	.7681	.8391	.7685	.8215	.7335	.7258	.8108
9	.6634	.7861	.7076	.6451	.7121	.6816	.7173
10	.6756	.7072	.6976	.6519	.7384	.6298	.6638
11	.5552	.7404	.7491	.6382	.7365	.6493	.6176
12	.4016	.7011	.6771	.6752	.6858	.5369	.6413
13	.5548	.6477	.6306	.3955	.6672	.4904	.5777
14	.5556	.7301	.6661	.285	.4961	.5148	.5308
15	.6302	.7175	.5361	.3025	.5548	.4862	.4756
16	.6919	.6454	.5788	.2831	.5343	.4919	.5274
17	.6272	.6294	.5712	.2686	.6039	.511	.5807
18	.6741	.7034	.5969	.3528	.6214	.5752	.6515
19	.8273	.785	.7771	.3601	.7701	.7952	.7834
20	1.0795	.9766	1.017	.5003	1.0372	1.0945	.9583
21	.9968	1.0006	1.0239	.5072	1.0425	1.0559	.8794
22	.8844	.9176	.8953	.8493	.8234	.9294	.8608
23	.7651	.8223	.8185	.7488	.7209	.8038	.7537
24	.687	.679	.6836	.6274	.6322	.6242	.6468
Max	1.0795	1.0006	1.0239	.8493	1.0425	1.0945	.9583
Min	.4016	.5464	.4858	.2686	.4294	.4862	.4756
Avg	.6869	.7289	.6937	.5479	.6542	.6599	.6594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 207 / 11 KV NATH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0343	.0354	.0549	.0351	.0351	.0366
2	.0554	.0347	.0351	.0549	.0354	.0351	.037
3	.0554	.0339	.0351	.0554	.0339	.0351	.0366
4	.0554	.0332	.0351	.0554	.0343	.0354	.0554
5	.0739	.0339	.0724	.0554	.0343	.0351	.0554
6	.0739	.0514	.0724	.0554	.0709	.0716	.0739
7	.0739	.0532	.0537	.0554	.0486	.0532	.0732
8	.056	.0514	.0537	.0739	.0514	.0532	.0532
9	.0554	.0354	.0351	.0351	.0343	.0351	.0554
10	.0709	.0351	.0358	.0343	.0351	.0343	.0686
11	.0343	.0537	.0358	.0514	.0343	.0339	.0686
12	.0678	.0724	.0686	.0339	.0351	.0332	.0366
13	.0343	.0347	.0343		.0343	.0343	.0509
14	.0335	.0351	.0343		.0514	.0343	.0686
15	.0709	.0351	.0343		.0339	.0678	.0343
16	.0514	.0532	.0701		.0343	.0343	.0343
17	.0532	.0351	.0554		.0358	.0514	.0347
18	.0514	.0351	.0554		.0351	.0549	.0724
19	.0709	.0895	.0924		.0905	.0924	.0716
20	.1086	.0895	.1109		.0905	.0914	.1086
21	.1086	.0905	.0739		.0905	.0924	.0886
22	.0686	.0716	.0739		.0716	.0554	.0905
23	.0526	.0537	.0732		.0537	.0518	.0514
24	.0554	.0335	.0351	.0554		.0354	.037
Max	.1086	.0905	.1109	.0739	.0905	.0924	.1086
Min	.0335	.0332	.0343	.0339	.0339	.0332	.0343
Avg	.0620	.0491	.0546	.0516	.0480	.0494	.0581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 208 / 11 KV SHIRALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6111	1.5928	1.432	1.5322	1.5463	1.4106	1.5017
2	1.5733	1.5211	1.3314	1.4674	1.4819	1.3276	1.4637
3	1.5509	1.499	1.3108	1.4484	1.4426	1.3223	1.4485
4	1.5162	1.4838	1.2986	1.4485	1.427	1.304	1.4548
5	1.6099	1.5166	1.4594	1.5173	1.4883	1.4289	1.5215
6	1.7307	1.6309	1.6339	1.6461	1.637	1.6087	1.6127
7	1.9448	1.7886	1.7848	1.7963	1.9365	.9358	1.8328
8	1.6674	1.6354	1.5173	1.6682	1.6644	1.3832	1.6293
9	1.4937	1.4433	1.294	1.3733	1.422	1.326	1.4587
10	1.5401	1.4975	1.3878	1.2818	1.3062	1.406	1.4319
11	1.6926	1.576	1.5295	1.3222	1.3108	1.5828	1.4746
12	1.8054	1.5645	1.6072	1.4259	1.2689	1.6796	.8291
13	1.7063	1.576	1.6591	.7392	1.5836	1.6408	1.6187
14	1.6887	1.4563	1.6881	.7461	1.7513	1.5676	1.5081
15	1.7055	1.422	1.8137	.7567	1.6179	1.7383	1.5333
16	1.5844	1.4518	1.7383	.6927	1.6027	1.5783	1.5455
17	1.6773	1.5112	1.6998	.6607	1.7361	1.6537	1.576
18	1.5958	1.4693	1.6666	.6722	1.5927	1.6956	1.5683
19	1.7559	1.8214	1.8422	.7438	1.6918	1.8846	1.7155
20	2.1117	2.0028	2.0473	.9998	2.0409	2.1026	2.1285
21	1.9951	1.8999	1.938	1.0463	1.9334	2.0721	2.0515
22	1.8564	1.7512	1.9173	.9816	1.7459	1.9121	1.8846
23	1.8763	1.6057	1.8846	.8924	1.6263	1.752	1.7421
24	1.7022	1.6323	1.5493	1.6118	.7941	1.5226	.849
Max	2.1117	2.0028	2.0473	1.7963	2.0409	2.1026	2.1285
Min	1.4937	1.422	1.294	.6607	.7941	.9358	.8291
Avg	1.7080	1.5979	1.6263	1.1863	1.5687	1.5765	1.5575



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 209 / 11 KV KAPARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4436	.5529	.5682	.5454	.4789	.5285	.6038
2	.4401	.5212	.5335	.5316	.4519	.4858	.5504
3	.4261	.514	.5297	.5427	.4477	.4698	.5433
4	.5285	.5075	.5171	.5452	.4652	.4828	.5462
5	.543	.5582	.5457	.5887	.4904	.4885	.5868
6	.5933	.5567	.6264	.6503	.615	.5514	.6303
7	.5639	.6371	.6504	.6585	.6348	.192	.6161
8	.5226	.5514	.6013	.6297	.5316	.2447	.5746
9	.5552	.567	.4858	.5647	.4607	.4733	.5304
10	.8189	.735	.503	.6161	.4336	.5019	.5758
11	.9072	.8741	.6386	.5452	.5708	.5838	.5548
12	.7594	.8482	.5891	.4893	.6946	.8143	.2926
13	.8337	.8047	.5407	.3018	.6482	.868	.4984
14	.8554	.6683	.5632	.2911	.7906	.8619	.5311
15	.8825	.9583	.5559	.2869	.815	.7365	.5692
16	.8246	.7	.6336	.2884	.7697	.5975	.5746
17	.6752	.5704	.5304	.2637	.7251	.6356	.5442
18	.5319	.5701	.4721	.2599	.6169	.5485	.495
19	.6844	.5579	.5664	.3079	.548	.6009	.6184
20	.7354	.6988	.7139	.3532	.6321	.7422	.7102
21	.6801	.6253	.7666	.3666	.5658	.731	.7632
22	.7137	.6729	.7601	.3688	.6687	.711	.7549
23	.5754	.6595	.6893	.3822	2.9685	.6557	.6295
24	.5095	.5777	.5724	.5617	.3113	.5506	.6135
Max	.9072	.9583	.7666	.6585	2.9685	.868	.7632
Min	.4261	.5075	.4721	.2599	.3113	.192	.2926
Avg	.6502	.6453	.5897	.4558	.6806	.5857	.5795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 401 / 33 KV GLUCOSE EXPRESS

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.7773	.6882	.6539	.5898	.7373	.7042
2	.8048	.7287	.6316	.5967	.6882	.6802	.6962
3	.7459	.6722	.6316	.6036	.5407	.6882	.6882
4	.7956	.8139	.583	.639	.7042	.6316	.6962
5	.7956	.6882	.583	.6464	.823	.6316	.7373
6	.8048	.6722	.639	.8453	.7865	.6882	.8951
7	.9054	.763	.639	.7459	.7865	.7956	.9054
8	.8453	.7122	.639	.8551	.763	.6802	.7459
9	.8951	.7865	.6882	.8551	.8745	.6802	.9448
10	.7865	.7373	.7202	.7287	.7682	.763	.8745
11	.7459	.7373	.7373	.7773	.7373	.8436	.4915
12	.6882	.7373	.7865	.8162	.7202	.7202	.583
13	.8139	.7459	.7373		.7373	.7682	.639
14	.763	.6962	.7373		.7773	.9156	.6882
15	.8951	.6962	.7373		1.549	.7773	.5898
16	.6882	.639	.7287		.8162	.6722	.5898
17	.6722	.7459	.7545		.7682	.8356	.6882
18	.8139	.6316			.7956	.7545	.639
19	.6882	.6167	.6962		.7459	.7545	.7865
20	.5596	.6722	.6464		.7459	.7042	.7545
21	.6539	.7373	.6962		.7459	.8551	.6882
22	.7202	.7459	.7042		.8648	.8648	.7956
23	.7287	.7459	.7956		.7459	.503	.8356
24	.7956	.8356	.6882	.6539		.7287	.6613
Max	.9054	.8356	.7956	.8551	1.549	.9156	.9448
Min	.5596	.6167	.583	.5967	.5407	.503	.4915
Avg	.7667	.7223	.6908	.7244	.7858	.7364	.7216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 201 / 11 KV CHARAN AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0686					.1543
2	.1372	.0686					.1543
3	.12	.0686					.1372
4	.12	.0686					.1372
5	.12	.0686					.1372
6	.1372	.1029					.1543
7	.1543	.1029					.1886
9			.3429	.3601		.3772	
10			.4115	.3601		.3772	
11			.3772			.3601	
12			.3429			.3429	
13			.3601		.2401	.2743	
14			.2743		.3944	.2743	
15			.3429		.3601	.2743	
16			.3086		.3772	.1029	
17					.2915		
18					.2572		
22	.12					.1543	.12
23	.1029		.0171			.1715	.1543
24		.1029					.1543
Max	.1543	.1029	.4115	.3601	.3944	.3772	.1886
Min	.1029	.0686	.0171	.3601	.2401	.1029	.12
Avg	.1276	.0815	.3086	.3601	.3201	.2709	.1492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 202 / 11 KV MANDOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429	.3429	.3429	.3086	.3086	.3086
2	.2915	.3086	.3086	.3258	.3086	.2915	.2915
3	.2915	.3086	.3086	.2915	.3086	.2915	.2915
4	.2915	.3086	.3086	.2915	.3086	.2915	.2915
5	.2915	.3086	.3429	.2915	.3086	.3086	.2915
6	.3772	.4115	.463	.3086	.3772	.3601	.3772
7	.4801	.5144	.5658	.4973	.5487	.4973	.4801
8	.5487	.5144	.5658	.5487		.5316	.4973
9	.4801	.4801	.5487	.4973		.463	.4287
10	.4801	.4801	.4801	.3944		.463	.4115
11	.3201	.4801	.4458	.4801		.463	.4458
12	.5144	.3944	.4115	.4115		.4458	.4458
13	.4458	.4287	.4115	.3772	.5316	.4458	.4115
14	.4458	.4115	.3944		.6001	.4115	.4115
15		.4458	.4287		.5316	.4801	.463
16	.5144	.4458	.3944		.4801	.4115	.4801
17	.5487	.4973	.4287		.5487	.4115	.5487
18	.5487	.6173	.5658		.2572	.5144	.5487
19	.6516	.7202	.6516		.703	.583	.6859
20	.6859	.7716	.7202		.7202	.7202	.6859
21	.6173	.6859	.6344		.6859	.6687	.6173
22	.5144	.5316	.3772		.5316	.5316	.463
23	.4458	.4115	.4115		.4115	.4115	.3601
24		.3772	.3601	.3429	.3429	.3258	.3429
Max	.6859	.7716	.7202	.5487	.7202	.7202	.6859
Min	.2915	.3086	.3086	.2915	.2572	.2915	.2915
Avg	.4588	.4665	.4530	.3858	.4639	.4430	.4408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 203 / 11 KV CHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2743	.2915	.2401	.2743	.2743
2	.2572	.2743	.2743	.2743	.2401	.2401	.2401
3	.2572	.2743	.2743	.2743	.2401	.2401	.2401
4	.2572	.2743	.2743	.2743	.2401	.2401	.2401
5	.2572	.2743	.3086	.2915	.2743	.2743	.2401
6	.463	.3429	.3601	.3086	.3429	.3429	.3429
7	.463	.4458	.4801	.4287	.5144	.463	.4458
8	.463	.4458	.4973	.4801		.3944	.3944
9	.3772	.4115	.3944	.3944		.3944	.3944
10	.4115	.3429	.4115	.3772		.3429	.3772
11	.3772	.4115	.3772	.3944		.3944	.3944
12	.4115	.3772	.3772	.4115		.3601	.3944
13	.4115	.3429	.3772	.3944	.4287	.4115	.463
14	.4115	.3772	.3601		.1372	.2743	.3944
15	.3429	.3429	.3429		.4115	.3429	.2915
16	.4115	.3086	.3086		.4458	.3429	.0857
17	.4458	.3601	.3429		.463	.4115	.1372
18	.4115	.3772	.3772		.4801	.4115	.463
19	.5487	.5144	.5316		.5316	.4801	.463
20	.583	.583	.6344		.6173	.6516	.6516
21	.4801	.5316	.5487		.5487	.5144	.6001
22	.4458	.4801	.4973		.4973	.4801	.4973
23	.3429	.3944	.3772		.3944	.3601	.3944
24		.3086	.3258	.3086	.3086	.3086	.3086
Max	.583	.583	.6344	.4801	.6173	.6516	.6516
Min	.2572	.2743	.2743	.2743	.1372	.2401	.0857
Avg	.3959	.3779	.3886	.3503	.3872	.3729	.3637

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 204 / 11 KV MANDOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.0171	.0171	.0171	.0171	1.0631
2	.7202	.6859		.0171	.0171	.0171	.9945
3	.7202	.6859	.0171	.0171	.0171	.0171	.9602
4	.6859	.6859	.0171	.0171	.0171	.0171	.9602
5	.6687	.6516	.0171	.0171	.0171	.0171	.9259
6	.6687	.6516	.0171	.0171	.0171	.0171	.8916
7	.6859	1.2003	.0171	.0171	.0171	.0171	.8745
8	.0171		.0171	.0171		.0171	.0171
9	.0171		1.3717	1.3375		1.5604	.0171
10	.0171		1.3717	1.286		1.5604	.0343
11	.0171		1.4403	1.0288		1.5261	.0343
12	.0171		1.406			1.5432	.0343
13	.0171		1.4232		1.286	1.4403	.0343
14	.0171		.3772		1.286	1.3717	.0343
15	.0171	.0171	.3772		1.4403	1.3717	.0171
16	.0171	.0171	.9088		1.3717	1.406	.0171
17	.0171	.0171	.0171		1.2689	.0171	.0171
18	.0171	.0171	.0171		1.3546	.0171	.0171
19	.0171	.0171	.0171		.0171	.0171	.0171
20	.0171	.0171	.0171		.0171	.0171	.0171
21	.0171	.0171	.0171		.0171	.0171	.0171
22	.8916	.0171	.0171		.0171	1.1317	.9602
23	.823	.0171	.0171		.0171	1.166	1.0117
24	.5487	.7888	.0171	.0171	.0171	.0171	1.1145
Max	.8916	1.2003	1.4403	1.3375	1.4403	1.5604	1.1145
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.3086	.3681	.3884	.3172	.4331	.5965	.4201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 401 / 33 KV WARNAWATI

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.072	.0617	.0772	.0669	.072	.072
2	.0669	.072	.0514	.072	.0669	.072	.0617
3	.0617	.072	.0566	.072	.0669	.072	.0617
4	.0617	.072	.0669	.0669	.0669	.072	.0566
5	.0617	.0874	.0617	.0617	.072	.072	.0617
6	.0669	.0772	.0669	.0617	.072	.0772	.072
7	.072	.0617	.0823	.072	.0566	.0772	.0772
8	.0772	.0566	.0617	.0412		.0772	.0772
9	.072		.072	.0566		.0669	.0669
10	.0669	.0617	.0617			.0669	.0669
11	.0669	.0514	.0669			.0617	.0514
12	.072	.0514	.0566	.0514		.072	.0514
13	.0669	.0514	.0669	.0514	.0617	.0669	.0566
14	.0669	.0514	.0617		.0566	.0617	.0514
15	.0669	.0514	.0669		.0617	.072	.0514
16	.0617	.0514	.0617		.0514	.0772	.0514
17	.0617	.0514	.0514		.0514	.0412	.0514
18	.0617	.0514			.0566	.0617	.0514
19	.0669	.108	.0669		.072	.0669	.0514
20	.0772	.0772	.0772		.0772	.072	.0617
21	.0977	.072	.072		.0874	.0772	.0669
22	.072	.0669	.0823		.0772	.072	.0669
23	.072	.0669	.0772		.072	.072	.0669
24	.0669	.072	.0617	.072	.072	.072	.072
Max	.0977	.108	.0823	.0772	.0874	.0772	.0772
Min	.0617	.0514	.0514	.0412	.0514	.0412	.0514
Avg	.0686	.0655	.0658	.0630	.0666	.0697	.0615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 201 / 11 KV KANDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3279	1.4022	.0362	.0362	.0362	.0343	1.2631
2	1.3272	1.326	.0362	.0362	.0362	.0343	1.2163
3	1.2654	1.3413	.0362	.0362	.0362	.0343	1.2163
4	1.2803	1.2193	.0343	.0358	.0362	.0343	1.1717
5	1.3117	1.2498	.0343	.0358	.0362	.0343	1.1843
6	1.4582	1.3413	.0343	.0358	.0362	.0343	1.3435
7	1.6409	1.531	.0343	.0351	.1886	.0343	1.4746
8	.0351	.0267	.0343	.0362	.0362	.0343	.0351
9	.0362	.0267	.0328	.0324	.0354	.0339	.0366
10	.0358	.0267	.0366	.0366	.0343	.0328	.0351
11	.0354	.0343	.0362		.0343	.0354	.0358
12	.0362	.0343	2.1051		2.146	2.0576	.0366
13	.0362	.0343	2.0485		2.3061	2.2298	.0351
14	.0362	.0343	2.0567		2.3491	2.3061	.0351
15	.0362	.0343	1.7924		2.2634	2.2043	.0358
16	.0351	.0343			2.1365	2.2634	.0358
17	.0362	.0343	1.8564		2.0388	2.1293	.0362
18	.0362	.0343	1.989		1.8233	2.1216	.0362
19	.0358	.0343	1.8896		1.7238	1.8399	.037
20	.0358	.0343	.0354		.0343	.0354	.0362
21	.0362	.0343	.0354		.2715	.0351	.2772
22	1.5249	.0343	.0362		.0343	1.3279	1.7238
23	1.6289	.0366	.0362		.0343	1.2944	1.6385
24	1.491	1.4685	.0362	.0362	.0362	.0366	1.2793
Max	1.6409	1.531	2.1051	.0366	2.3491	2.3061	1.7238
Min	.0351	.0267	.0328	.0324	.0343	.0328	.0351
Avg	.6150	.4753	.6219	.0357	.7393	.8441	.5940



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 202 / 11 KV SAGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9374	.9717	.0267	.0259	.0305	.0267	.9998
2	.9217	.8745	.0267	.0244	.0305	.0229	.9722
3	.9374	.8745	.0267	.0236	.0305	.0229	.9722
4	.9686	.8745	.0267	.0229	.0305	.0229	.9686
5	.9877	.8745	.0267	.0202	.0305	.0229	.9686
6	1.1702	1.086	.0267	.024	.0305	.0229	1.186
7	1.0595	1.0688	.0267	.0267	.0305	.0267	1.1227
8	.0259	.0305	.0267	.0194	.0305	.0267	.0202
9		.0267	1.8785	2.0317	1.9292	1.9951	.0324
10	.0305	.0267	1.8023	1.9498	1.8623	1.9006	.032
11	.0305	.0267	1.6385		1.1843	1.757	.032
12	.0305	.0267	1.4403		1.8023	1.6221	.0328
13	.0305	.0267	1.5203		1.7804	1.6766	.032
14	.0305	.0267	1.5729		1.668	1.543	.032
15	.0305	.0267	1.5684		1.7532	1.6289	.0332
16	.0305	.0267	1.5844		1.5746	1.4752	.0328
17	.0305	.0267	.0164		.0191	.0152	.0305
18	.0305	.0267	.0175		.0267	.0141	.0305
19	.0305	.0267	.0255		.0191	.0194	.0305
20	.0305	.0267			.0229	.021	.0305
21	.0305	.0267	.0236		.0267	.0191	.0305
22	1.3279	.0267	.0259		.0267	1.2163	1.3927
23	1.2955	.0267	.0274		.0305	1.1683	1.2955
24	1.0623	1.4022	.0229	.0267	.0305	.0229	.9998
Max	1.3279	1.4022	1.8785	2.0317	1.9292	1.9951	1.3927
Min	.0259	.0267	.0164	.0194	.0191	.0141	.0202
Avg	.4809	.3524	.5817	.3814	.5834	.6787	.4713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 204 / 11 KV KANDE GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1848	.1886	.2263	.1848	.1991	.1494
2	.1886	.1829	.1886	.2263	.1848	.2012	.1509
3	.1886	.1848	.1886	.2263	.1829	.2012	.1509
4	.1886	.1848	.1867	.2263	.1829	.2012	.1509
5	.1886	.1848	.1867	.2263	.1829	.2012	.1509
6	.2263	.2218	.2241	.2641	.2772	.2195	.1886
7	.2561	.2218	.2614	.2587	.2241	.2195	.1867
8	.181	.2218	.2353	.2195	.2218	.2195	.1478
9	.2195	.2058	.197	.181	.181	.181	.1478
10	.2195	.2058	.1991	.1791	.181	.1772	.1433
11	.2218	.181	.2012		.1772	.1734	.1402
12	.2195	.2058	.181		.181	.1696	.1417
13	.2195	.1886	.1753		.1829	.1734	.1417
14	.2218	.1715	.1372		.1791	.1753	.1075
15	.2241	.1715	.1715		.1791	.1791	.1417
16	.2172	.1715	.1715		.1753	.1772	.1402
17	.2195	.1543	.1372		.181	.1715	.1463
18	.2195	.1715	.1753		.2172	.1715	.1848
19	.2561	.2561	.2195		.2534	.2149	.2218
20	.2743	.2896	.2587		.2987	.2587	.2772
21	.2587	.2534	.2587		.2715	.2587	.2772
22	.2218	.2614	.2614		.2534	.2241	.2561
23	.2033	.2263	.2614		.2172	.1867	.2218
24	.1886	.1848	.2263	.2263	.2218	.1991	.1867
Max	.2743	.2896	.2614	.2641	.2987	.2587	.2772
Min	.181	.1543	.1372	.1791	.1753	.1696	.1075
Avg	.2171	.2036	.2038	.2237	.2080	.1981	.1730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 205 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1052	.0905	.1086	.1063	.12	.0724
2	.1097	.1052	.0905	.1109	.1063	.12	.0724
3	.1097	.1052	.0905	.1109	.1075	.1227	.0724
4	.1097	.1052	.0905	.1109	.1075	.1052	.0724
5	.1086	.1052	.0905	.1086	.1075	.12	.0732
6	.1097	.1227	.1029	.1086	.1254	.1372	.1097
7	.1372	.1227	.1372	.1387	.124	.1372	.1052
8	.1029	.1227	.1372	.1006	.124	.1372	.1006
9	.1052	.1219	.1467	.0972	.128	.1463	.1017
10	.1052	.1296	.1524	.096	.0983	.1341	.0995
11	.1052	.1619	.141		.1341	.1311	.0972
12	.1052	.1524	.1638		.1296	.128	.0949
13	.1063	.1372	.1562		.1341	.1326	.1006
14	.1063	.1219	.096		.0983	.1341	.0983
15	.1063	.1219	.1562		.1006	.1357	.0995
16	.1753	.1219	.0937		.0972	.1341	.1006
17	.1791	.1372	.1738		.1372	.1311	.1227
18	.1753	.1677	.1898		.1715	.1638	.1402
19	.1753	.2058	.1357		.1991	.1341	.1578
20	.2126	.2229	.208		.2534	.1734	.2126
21	.1949	.2058	.1402		.2058	.1387	.2149
22	.1753	.1753	.1097		.181	.1097	.1595
23	.1417	.1448	.1109		.1433	.1086	.1402
24	.1097	.1086	.1109	.1109	.1063	.1267	.1086
Max	.2126	.2229	.208	.1387	.2534	.1734	.2149
Min	.1029	.1052	.0905	.096	.0972	.1052	.0724
Avg	.1323	.1388	.1298	.1093	.1344	.1317	.1136

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11 KV CHIKHALI S/S

Feeder No / Name : 401 / 33 KV JYOTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5533	.5144	.5144	.3086	.5144	.547
2	.5533	.5144	.5658	.5144	.5658	.547
3	.5533	.5144	.5658	.5144	.5658	.547
4	.5533	.5144	.5658	.5144	.5658	.547
5	.5533	.5658	.5658	.5144	.5658	.547
6	.5596	.5658	.5658	.5658	.5658	.5533
7	.5596	.5658	.5658	.5658	.5658	.5596
8	.5344	.5658	.5658	.5658	.5658	.5344
9	.5658	.5658	.5533	.5533	.5533	.5407
10	.5658	.5658	.5658	.5344	.5407	.5344
11	.5658	.5658	.5658	.5596	.5533	.5344
12	.5658	.5658	.5658	.5533	.5344	.5533
13	.5658	.5658	.5658	.5344	.5344	.5596
14	.5658	.5658	.5658	.5533	.547	.5533
15	.5658	.5658	.5533	.5596	.5344	.5596
16	.5658	.5658	.4212	.5344	.5407	.5533
Max	.5658	.5658	.5658	.5658	.5658	.5596
Min	.5344	.5144	.4212	.3086	.5144	.5344
Avg	.5592	.5530	.5520	.5279	.5508	.5482

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 201 / 11 KV WAKURDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1425	.1904	3.3387	3.1569	1.3435	1.1203	.0648
2	.141	.1904	3.2697	3.0624	1.3108	1.0883	.0648
3	.1456	.1926	3.1943	2.9264	1.2631	1.0242	.0667
4	.1463	.1926	3.1036	2.7617	1.2308	1.0364	.0638
5	.1486	.2077	3.0038	2.7542	1.2146	1.0364	.0572
6	.1486	.2092	2.8917	2.9509	1.2289	1.0978	.0526
7	.1593	.2275	2.6372	2.4825	1.1961	1.1142	.0686
8	.1623	.3129	.1387	.1819	.0791	.0869	.0438
9	4.6228	3.9038	.0907	.1082	.0791	.1	
10	4.5847	3.8557	.1433	.1486	.0351	.0892	.9069
11	4.7013	3.7998	.1425	.1493	.0351	.0594	.9069
12	4.6718	3.2282	.1143	.1113	.0343	.0594	
13	4.3698	3.3478	.1356	.1075	.0343		1.1248
14	4.1204	3.4058	.1425	.1128	.032	.0297	1.0623
15	4.1838	3.4758	.141	.112	.032	.0297	1.0623
16	3.7822	3.5856	.1403	.1067	.0343	.0762	1.0185
17		.1654	.1448	.1204	.0343	.0724	.0648
18	.1443	.1673	.1958	.1273	.0648	.0732	.0648
19	.1766	.205	.2092	.1395	.104	.0747	.0914
20	.2201	.2523	.2469	.141	.1174	.08	.0914
21	.2285	.253	.2722	.2439	.088	.084	.0914
22	.2382	3.6329	3.3988	1.6644	1.1633	.0814	.0914
23	.198	3.6405	3.4354	1.8961	1.2289	.0674	.061
24	.1501	1.9729	3.4179	3.3196	1.4419	1.1363	.0777
Max	4.7013	3.9038	3.4354	3.3196	1.4419	1.1363	1.1248
Min	.141	.1654	.0907	.1067	.032	.0297	.0438
Avg	1.6342	1.6923	1.4145	1.2036	.5594	.4225	.3272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 202 / 11 KV TAKAVE AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5335	.0857	.0848	.0772	.0983	.933
2	.5144	.5401	.0857	.0819	.0772	.0983	.9172
3	.5144	.5401	.0686	.0819	.0772	.096	.9122
4	.535	.5468	.0686	.08	.0781	.0995	.9175
5	.6241	.6405	.0686	.08	.0791	.1029	.9503
6	.6241	.7253	.0829	.0857	.0791	.0848	1.0031
7	.8124	.8436	.1006	.0838	.0838	.1029	.9842
8	.0949	.1174	.1029	.1296	.0762	.1147	.0819
9	.0701	.1029			2.1963	1.8275	
10	.1075	.1029	2.1026	1.7436	1.9448	1.8442	.0937
11	.1254	.1029	2.1026	1.7436	1.9448	1.6741	.0937
12	.1214	.0857	1.9227		1.5546	1.5061	
13	.1134	.0857	1.9227		1.5546	1.3603	.0857
14		.0762	1.7078		1.4083	1.1069	.0869
15		.0914	1.7695		1.4083	1.2803	.0869
16	.1134	.0762	1.7901		.064	1.2483	.0754
17	.1619	.0914	.1326		.064	.0724	.0754
18	.1492	.1067	.1147		.1235	.0914	.088
19	.156	.12	.1433		.1526	.1372	.1029
20	.1402	.12	.1254		.1341	.12	.1227
21	.1417	.12	.1214		.1214	.1214	.1387
22	.8223	.1029	.12		.1063	1.1012	1.2742
23	.6249	.0857	.1086		.1052	1.0202	1.2289
24	.5487	.5335	.0857	.0857	.0772	.0983	.9488
Max	.8223	.8436	2.1026	1.7436	2.1963	1.8442	1.2742
Min	.0701	.0762	.0686	.08	.064	.0724	.0754
Avg	.3468	.2705	.6493	.3891	.5662	.6420	.5092

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 203 / 11 KV PADALI AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0259	.0305	.7106	.8916	.9247	.5201	.029
2	.0259	.0305	.6931	.8726	.8535	.5087	.029
3	.0274	.0305	.6802	.8219	.8036	.4808	.029
4	.0274	.0305	.7129	.7876	.7549	.4839	.0293
5	.0278	.0305	.7488	.7899	.7826	.4329	.0297
6	.0324	.0305	.8145	.8581	.8478	.49	.0297
7	.1372	.048	.949	1.0966	1.0174	.5128	.0648
8	.1342	.0404	.0995	.1364	.0747	.0591	.1417
9	1.2711	1.0597		.0084	.0313	.0297	.4603
10	1.3163	1.0257	.0206	.0332	.0274	.0495	.7339
11	1.294	.9987	.0206	.0339	.0274	.0488	.7446
12	1.1545	.9576	.0213			.0297	.426
13	1.053	.9495	.0213			.0297	.6242
14	1.0147	.9896	.0233		.0229	.0301	.6332
15	1.0121	.9656	.0225		.0229	.0301	.6553
16	.9854	1.0448	.0213		.0278	.0335	.4359
17	.077	.1006	.0221	.0366	.0286	.1143	.1585
18	.0305	.0686	.09	.0854	.0915	.1006	.0358
19	.0709	.0305	.1531	.0914	.0991	.1356	.1685
20	.0419	.0305	.1116	.0922	.05	.1402	.1593
21	.0305	.0267	.0358		.0457	.0301	.1509
22	.0305	.889	1.0061	.5655	.6242	.0374	.1387
23	.0305	.8463	1.059	.5967	.6424	.0297	.0305
24	.0259	.4824	.8646	.9598	.7713	.2347	.029
Max	1.3163	1.0597	1.059	1.0966	1.0174	.5201	.7446
Min	.0259	.0267	.0206	.0084	.0229	.0297	.029
Avg	.4115	.4474	.3870	.4865	.3896	.1913	.2486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 204 / 11 KV PADALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1829	.1715	.1791	.181	.181	.1991
2	.181	.1829	.1715	.181	.181	.181	.1991
3	.0274	.1646	.1715	.181	.1791	.1791	.1991
4	.181	.1629	.1715	.1791	.181	.1791	.1991
5	.181	.181	.1886	.1772	.181	.1791	.1991
6	.2353	.2172	.2328	.2303	.2149	.2328	.2303
7	.2374	.1886	.2279	.2279	.2279	.2629	.2254
8	.2374	.2012	.1509	.218	.1989	.2012	.1844
9	.1865	.1886			.1638	.1865	
10	.1492	.1715	.0903	.125	.144	.1509	.1296
11	.1372	.1715	.0903	.125	.144	.1492	.1296
12	.1214	.1543	.0995		.1423	.1492	
13	.1174	.1543	.0995		.1423	.1677	.1311
14	.1326	.1543	.1357		.1562	.1402	.1341
15	.1357	.1543	.1357		.1562	.1372	.1341
16	.0972	.1372	.1147		.156	.1341	.1492
17	.0772	.1543	.1147		.156	.1311	.1492
18	.0926	.1829	.1718		.1698	.1638	.1638
19	.2058	.2134	.2254		.2347	.2229	.2374
20	.181	.2134	.2507		.2686	.2629	.2686
21	.0114	.2229	.2534		.2534	.2686	.2481
22	.2012	.1886	.2561		.2378	.2507	.2303
23	.1848	.1715	.2172		.1991	.2172	.2195
24	.181	.1829	.1715	.1991	.1791	.1991	.1991
Max	.2374	.2229	.2561	.2303	.2686	.2686	.2686
Min	.0114	.1372	.0903	.125	.1423	.1311	.1296
Avg	.1531	.1791	.1701	.1839	.1853	.1886	.1891



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 205 / 11 KV WAKURDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2279	***	.1886	.2012	.181	.1646	.1991
2	.2279	.1663	.1886	.1991	.1612	.1629	.1991
3	.2279	.168	.1886	.181	.1612	.1629	.2012
4	.2279	.168	.1886	.1772	.1612	.1646	.1991
5	.2534	.1663	.1886	.1772	.1629	.1646	.2012
6	.2534	.1848	.2715	.2172	.2195	.2218	.2507
7	.2454	.2254	.2686	.2303	.2279	.2195	.2743
8	.2454	.218	.2507	.2543	.2056	.2204	.2743
9	.2374	.2229			.208	.2035	
10	.2347	.2229	.208	.192	.1739	.1844	.2315
11	.2204	.2058	.208	.192	.176	.2204	.2315
12	.2321	.1829	.2374		.1907	.2056	
13	.2214	.2058	.2374		.1907	.1677	.2143
14	.2107	.1981	.1875		.1806	.1677	.2107
15	.2241	.2134	.1875		.1806	.1677	.2107
16	.2187	.2401	.2054		.1957	.2315	.2054
17	.2315	.2572	.2054		.2006	.2347	.2054
18	.2343	.2915	.2932		.2364	.2743	.2743
19	.3222	.3429	.3391		.3018	.3391	.3429
20	.362	.3944	.394		.362	.3772	.4119
21	.3475	.3429	.4075		.362	.3761	.394
22	.2987	.2915	.2957		.2957	.2915	.3258
23	.2241	.2401	.2402		.2033	.2534	.2241
24	.2279	.1848	.2058	.2012	.181	.1646	.1991
Max	.362	17.2853	.4075	.2543	.362	.3772	.4119
Min	.2107	.1663	.1875	.1772	.1612	.1629	.1991
Avg	.2482	.9425	.2429	.2021	.2133	.2225	.2491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 206 / 11 KV TAKAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3421	.358	.3326	.3498	.314	.3163	.3454
2	.3322	.3489	.3265	.3406	.3071	.3101	.3385
3	.3315	.3232	.322	.3367	.3041	.3063	.3324
4	.3383	.3224	.3174	.3336	.3003	.3124	.3279
5	.679	.3692	.3242	.3306	.3239	.314	.3454
6	.2972	.501	.4668	.4542	.4369	.4611	.5443
7	.3963	.5843	.5076	.6059	.5358	.5982	.6081
8	.3658	.5247	.4435	.5951	.4993	.5008	.5847
9	.3311	.4889	.2401	.2698	.4749	.4138	.2911
10	.2904	.4718	.4511	.4256	.3952	.4366	.4241
11	.4012	.4443	.4351	.386	.3967	.3898	.4241
12	.3852	.4527	.3986	.2401	.365	.4504	.2164
13	.4443	.4413	.3849	.1936	.346	.4685	.3536
14	.0572	.4104	.3399	.173	.2903	.3761	.3406
15		.378	.3201	.2134	.304	.3604	.3901
16		.4268	.3742	.192	.3101	.3975	.3921
17	.506	.4291	.3971	.234	.346	.4191	.4158
18	.4428	.458	.4275	.2667	.4337	.4906	.4915
19	.3963	.5212	.5723	.2782	.5883	.6615	.6028
20	.7819	.6028	.7469	.4009	.7415	.7728	.756
21	.738	.5959	.7053	.378	.7691	.7377	.7469
22	.6668	.5495	.6108	.3346	.6508	.6325	.6447
23	.4765	.4355	.4752	.2622	.4481	.5137	.4534
24	.3498	.3852	.3524	.3605	.3629	.3597	.3782
Max	.7819	.6028	.7469	.6059	.7691	.7728	.756
Min	.0572	.3224	.2401	.173	.2903	.3063	.2164
Avg	.4250	.4510	.4280	.3315	.4268	.4583	.4478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 201 / 11 KV MANGLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.2986	.5698	.5636	.5022	.1791	.2149
2	1.2346	1.2354	.5476	.5151	.4946	.1772	.2149
3	1.211	1.2148	.5388	.5136	.4862	.208	.2149
4	1.2094	1.2383	.5662	.5083	.4839	.2454	.2126
5	1.2674	1.251	.6025	.5563	.5373	.2865	.2481
6	1.4015	1.374	.665	.6554	.6028	.3012	.2804
7	1.4658	1.4529	.7257	.6553	.6424	.3258	.3155
8	.8702	.8909	.6756	.6142	.6485	.2686	.2804
9	.5443	.6073	1.7042	1.7307	1.6972	.2303	.2454
10	.5617	.5879	1.8122	1.7696	1.7435	.2481	.2204
11	.6188	.6024	1.776	1.7587	1.8665	.2658	.2204
12	.6335	.6032	1.8028	1.7482	1.7855	.2629	
13	.612	.5984	1.7726	.2789	1.72	.2629	.3086
14	.5845	.6108	1.7345	.2881	1.6506	.2835	.2949
15	.5945	.6455	1.749	.2835	1.5931	.2658	.2683
16	.6398	.6924	1.7478	.9236	1.6393	.2658	.2713
17	.7202	.642	.9495	.442	.812	.3544	.3467
18	.74	.6714	.7674	.3574	.6775	.3761	.3898
19	.8855	.817	.8589	.4245	.7628	.4252	.439
20	.9838	.9614	.9876	.5037	.904	.4607	.4409
21	.9298	.8853	.8836	.4877	.8911	.4252	.4031
22	1.5546	.7821	.7964	.7903	.8726	.3544	.3052
23	1.5394	.7215	.7293	.6995	.7022	.2835	.2058
24	1.3481	.6508	.5681	.5967	.5685	.2353	.0354
Max	1.5546	1.4529	1.8122	1.7696	1.8665	.4607	.4409
Min	.5443	.5879	.5388	.2789	.4839	.1772	.0354
Avg	.9776	.8765	1.0638	.7360	1.0118	.2913	.2773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 202 / 11 KV DE VWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3306	1.3535	.4024	.4435	.4481	.3932	1.3535
2	1.2936	1.3306	.4115	.4435	.4435	.3841	1.2308
3	1.2936	1.2936	.4207	.4435	.4435	.3795	1.1946
4	1.3676	1.2567	.4161	.4435	.4481	.3887	1.2803
5	1.4045	1.2567	.4115	.439	.4481	.3978	1.3535
6	1.4415	1.3491	.4161	.439	.4435	.3932	1.6095
7	1.4045	1.3306	.4252	.4435	.4435	.4024	1.2254
8	.4435	.4481	.3887	.4251	.4066	.4024	.439
9	.4481	.4251	1.9559	2.0302	2.0851	1.8945	.439
10	.4715	.4031	2.0111	2.0668	2.1132	1.9387	.439
11	.4481	.3944	1.9204	2.1658	2.1384	2.0485	.4115
12	.4435	.4024	1.8378		.7537	2.1538	.3856
13	.4435	.3932	1.8073		1.6907	1.8099	.3944
14	.4338	.3841	1.7364		1.6057	1.6644	.3988
15	.439	.3704	1.6118		1.5223	1.7372	.407
16	.4435	.3749	1.4419		1.5424	1.7375	.4115
17	.4435	.3841	.4075		.4115	.4344	.407
18	.4435	.3932	.439		.4207	.439	.407
19	.4435	.3841	.439		.4252	.4344	.3932
20	.4435	.3887	.439		.4344	.4344	.4527
21	.4435	.3795	.4207		.4298	.4344	.3932
22	1.6461	.3932	.4207	.4435	.439	1.6461	1.5089
23	1.4632	.4024	.4435	.4481	.4161	1.5729	1.5947
24	1.3306	1.3535	.3887	.4435	.4481	.4024	1.4632
Max	1.6461	1.3535	2.0111	2.1658	2.1384	2.1538	1.6095
Min	.4338	.3704	.3887	.4251	.4066	.3795	.3856
Avg	.8420	.7019	.8755	.7942	.8501	.9968	.8164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 203 / 11 KV MANGLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.451	1.3504	.0655	.1059	.0792	.0545	1.5844
2	1.414	1.3111	.0651	.1061	.0796	.0547	1.4277
3	1.3718	1.3245	.0663	.1061	.0796	.0551	1.4179
4	1.3638	1.3371	.0661	.1052	.0816	.0555	1.4575
5	1.3954	1.3161	.0663	.1056	.0492	.0576	1.5257
6	1.4358	1.4597	.0665	.1036	.0419	.0533	1.661
7	1.5124	1.4781	.0657	.0926	.0937	.064	.8249
8	.0621	.0785	1.0694	1.2281	1.1782	1.2302	.0926
9	.0754	.0842	2.3918	2.3826	2.3762	2.4879	.0514
10	.093	.0675	2.3166	2.4615	2.3956	2.3735	.0541
11	.0842	.0751	2.2927	2.2588	2.5171	2.3937	.0515
12	.0839	.0741	2.162	.4934	2.335	2.3004	
13	.074	.0735	2.108		2.2927	2.1351	.0594
14	.0777	.0642	2.0512		2.2447	1.9421	.091
15	.0667	.0636	2.0996		2.2082	1.9258	.0919
16	.0712	.0661	2.1487	.9709	2.138	1.8077	.0953
17	.1017	.0699	.088	.0545	.0646	.0697	.0987
18	.1151	.0699	.1211	.0671	.0713	.0517	.1229
19	.1169	.0804	.1178	.0739	.0777	.0189	.1093
20	.0839	.0808	.0991	.0743	.0852	.03	.1067
21	.7355	.0817	.096	.0728	.0926	.9694	.8246
22	1.5775	.0743	.0979	.1256	.0768	1.8378	1.6751
23	1.5135	.0667	.0937	.0861	.064	1.7463	1.6004
24	1.4453	.682	.0659	.0792	.0823	.94	1.1306
Max	1.5775	1.4781	2.3918	2.4615	2.5171	2.4879	1.6751
Min	.0621	.0636	.0651	.0545	.0419	.0189	.0514
Avg	.6801	.4762	.8284	.5311	.8669	1.0273	.7024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 204 / 11 KV CHIKHALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.543	2.6711	2.4714	2.1658	2.4261	.4496
2	.5433	.5407	2.6147	2.2031	1.9121	2.393	.3772
3	.5392	.5202	2.5491	2.0199	1.8264	1.4845	.3703
4	.5385	.5301	2.6025	2.039	1.8602	2.319	.3757
5	.5357	.5258	2.7046	2.255	2.009	2.2927	.3807
6	.5476	.3124	2.8174	2.4333	2.2714	2.508	.4397
7	.5441	.4679	2.3152	2.2059	2.0126	2.0599	.4748
8	2.6871	2.6197	.6516	.4268	.5205	.5365	2.2939
9	4.8747	4.7032	.7316	.5228	.538	.5125	3.8367
10	4.8194	4.5458	.679	.5209	.5579	.5385	3.6995
11	4.8831	4.3751	.6554	.5285	.5215	.6005	3.6077
12	4.5481	4.1926	.6196	.5461	.4831	.6447	3.219
13	4.4986	4.0459	.6325	.2423	.4778	.599	2.7747
14	4.4734	3.7662	.6173	.2743	.4893	.3937	2.697
15	4.3347	3.6118	.6764	.3201	.4973	.5537	2.9675
16	3.3398	2.8815	.6672	.2995	.4055	.5697	1.9791
17	.6874	.5643	.6912	.2934	.5068	.6014	.6398
18	.7224	.6607	.7057	.3003	.6146	.6767	.6302
19	.6646	.7049	.7057	.2736	.6394	.6089	.6089
20	.6531	.5874	.6044	.2812	.5495	.5571	.6249
21	.6074	1.797	2.0432	1.5364	1.7738	.4618	.548
22	.5921	3.1124	3.6107	3.1352	2.9127	.4877	.5076
23	.5655	2.9218	2.9736	2.8989	2.7313	.4862	.4549
24	.5548	1.7281	2.8212	2.6094	2.5115	1.4632	.4176
Max	4.8831	4.7032	3.6107	3.1352	2.9127	2.508	3.8367
Min	.5357	.3124	.6044	.2423	.4055	.3937	.3703
Avg	1.9724	2.0941	1.5984	1.2766	1.2828	1.0740	1.4323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 205 / 11 KV DEOWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1132	.0716	.1132	.0943	.0724	.1132
2	.0953	.0943	.0543	.1132	.0953	.0532	.112
3	.0943	.0943	.0554	.112	.1132	.0537	.112
4	.1132	.1132	.0732	.112	.1132	.0876	.1307
5	.132	.132	.1052	.1307	.132	.104	.1509
6	.1886	.168	.1417	.168	.1867	.124	.1886
7	.1772	.156	.1791	.1698	.1578	.1463	.156
8	.1402	.104	.1595	.1086	.124	.1227	.1387
9	.1475	.1017	.1387	.1357	.1341	.1526	.2149
10	.1134	.1029	.1448	.1341	.112	.1402	.1372
11	.1174	.104	.124	.1017	.0937	.1219	.1174
12	.1029	.1029	.1052	.0663	.0914	.1094	.0983
13	.104	.1017	.0857		.0781	.0926	.0995
14	.1063	.1227	.0829		.064	.112	.1029
15	.12	.104	.0983		.0819	.1174	.124
16	.128	.12	.1357		.1107	.1372	.1187
17		.1829	.125		.1311	.1389	.1595
18	.1406	.197	.1372		.1526	.1677	.1595
19	.2058	.2126	.1886		.1753	.2058	.2481
20	.2279	.181	.2126		.197	.2303	.2402
21	.1829	.168	.181		.1463	.2353	.1989
22	.1663	.1478	.1494	.1494	.1663	.1494	.1753
23	.1307	.1307	.1307	.1307	.1307	.1307	.1509
24	.1143	.1132	.0914	.1132	.112	.0914	.1132
Max	.2279	.2126	.2126	.1698	.197	.2353	.2481
Min	.0943	.0943	.0543	.0663	.064	.0532	.0983
Avg	.1375	.1320	.1238	.1239	.1247	.1290	.1484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 206 / 11 KV DHANTAKE WARANA

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0716	.0716		.0537		.2126
3	.1448	.1433	.1791	.197	.1772	.2126
4	.1433	.1433	.1791	.1949	.1772	.2126
5	.1433	.1433	.2149	.1949	.1772	.2126
6	.1433	.1433	.2149	.197	.2126	.2126
7	.1433	.1433	.2328	.197	.2126	.1949
8	.1433	.1433	.2303	.2126	.2303	.2149
9	.1629	.0179	.2303	.1949	.2303	.2149
10	.1612	.2149	.2126	.1949	.2126	.2279
11	.1463	.2149	.2172	.2149	.2149	.2103
12	.1646	.2328	.2126	.2149	.2126	.2103
13	.1698	.2328	.2103	.2149	.2126	.2058
14	.1448	.2328	.208	.2149	.1949	.2035
15	.1307	.2149	.2058	.2149	.2149	.1966
16	.0191	.2149	.2126	.2149	.2353	.2126
17	.0191	.1791	.2058	.2149	.2149	.2149
18	.0191	.1791	.197	.2149	.2328	.2172
24						.208
Max	.1698	.2328	.2328	.2149	.2353	.2279
Min	.0191	.0179	.1791	.0537	.1772	.1949
Avg	.1218	.1686	.2102	.1974	.2102	.2108



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 401 / 33KV INGRUL KAPARI LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6984	.4298	.4344	.6984	.4298	.6984
2	.6984	.4344	.4344	.6984	.4298	.6984
3	.7059	.4887	.543	.691	.5373	.6984
4	.7059	.4887	.543	.691	.5373	.6984
5	.7522	.4887	.543	.691	.5373	.7762
6	.7522	.4938	.6516	.691	.6447	.7522
7	.7362	.4938	.6516	.6984	.6447	
8	.7362	.4887	.6516	.6984	.6447	
9	.7522	.499	.6516	.7602	.6447	.7602
10	.7602	.499	.6379	.7602	.7602	.7059
11	.7602	.4435	.631	.7059	.823	.6984
12	.7522	.439	.6447	.6516	.7922	.6984
13	.7522	.439	.6447	.6516	.7762	.6984
14	.7133	.4344	.6516	.6516	.7602	.6984
15	.7207	.4344	.6516	.6516	.7842	.7133
16		.4298		.543		
Max	.7602	.499	.6516	.7602	.823	.7762
Min	.6984	.4298	.4344	.543	.4298	.6984
Avg	.7331	.4640	.5977	.6833	.6498	.715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 201 / 11 KV KANDUR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1092	1.0155	.0434	.0434	.032	.0446	1.3748
2	1.0437	1.0155	.0429	.0406	.032	.0446	1.3748
3	1.0402	1.0155	.0429	.0406	.0316	.0457	1.3279
4	1.0722	.9998	.0579	.0417	.032	.0446	1.3279
5	1.1385	1.0623	.0579	.0417	.0324	.0457	1.406
6	1.2651		.0572	.0429	.0324	.0492	1.406
7	1.25		.0587	.0406	.0293	.0492	1.3904
8	.0417		.0556	.0412	.0244	.048	.0452
9	.0324	.0533	2.2531	2.251	2.4249	2.2775	.0389
10	.0312	.0564	2.3434		2.1956	2.4905	.0406
11	.029	.0533	2.1872	2.0243	2.4291	2.5069	.0412
12	.0293	.0518	2.3365		2.2119	2.13	.04
13	.0297	.0518	2.1872		2.2186	2.0485	.0429
14	.0305	.0518	2.0557		2.2024	1.9919	.0417
15	.0446	.0518	1.9444		2.1464	1.9595	.0412
16	.044	.0511	1.906		2.0405	1.7859	.04
17	.0429	.0511	.0394		.0423	.0423	.0412
18	.0549		.0389		.044	.0366	.0417
19	.0463					.0412	
20	.0469	.0587			.0446	.0463	.0417
21	.0446	.0579			.0446	.0417	.0417
22	1.4327	.0587			.0457	1.6032	1.6004
23	1.3108	.0594	.0417	.0312	.044	1.5708	1.5181
24	1.2334	1.2346	.0587	.0429	.0316	.0446	1.4403
Max	1.4327	1.2346	2.3434	2.251	2.4291	2.5069	1.6004
Min	.029	.0511	.0389	.0312	.0244	.0366	.0389
Avg	.5185	.3711	.8904	.3902	.8005	.8745	.6393

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 202 / 11 KV PUNVAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1478	.1478	.1307	.1448	.1494	.1097
2	.1494	.1494	.1463	.1307	.1267	.1307	.1097
3	.1294	.1494	.1478	.1307	.128	.1294	.1097
4	.1478	.1494	.1663	.1307	.1463	.1478	.1463
5	.1829	.1848	.1848	.1829	.181	.1829	.1463
6	.2172	.2353	.2195	.2402	.2353	.2012	.1463
7	.2328	.2686	.2229	.2328	.2454	.2328	.1372
8	.208		.2155	.197	.1989	.1753	.1844
9	.2035	.2012	.2058	.1619	.1943	.1823	.1865
10	.1619	.1739	.1865	.1865	.0019	.1423	.1753
11	.1781	.1562	.1715	.1543	.1562	.128	.1715
12	.1802	.1543	.1526	.1	.144	.128	.156
13	.1581	.1457	.1526		.1311	.1389	.1578
14	.1457	.1311	.1543		.1492	.1406	.1772
15	.1509	.1372	.1753			.1543	.1753
16	.1875	.1635	.1907		.2187	.1875	.1928
17	.1829	.2027	.1928		.2591	.2286	.1928
18	.192		.2126		.2241	.2229	.2149
19	.2204					.2374	.2896
20	.2686	.2572			.2601	.2947	.2896
21	.2195	.2303			.2507	.2804	.2534
22	.2012	.1991			.2149	.2353	.2195
23	.1646	.1829	.1867	.1848	.1848	.1829	.1867
24	.1663	.1478	.1463	.1494	.1463	.1663	.1097
Max	.2686	.2686	.2229	.2402	.2601	.2947	.2896
Min	.1294	.1311	.1463	.1	.0019	.128	.1097
Avg	.1833	.1794	.1789	.1652	.1792	.1833	.1766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 203 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1307	.1307	.1307	.1307	.1307	.1509
2	.132	.1307	.132	.1307	.132	.1307	.132
3	.132	.132	.132	.128	.132	.132	.132
4	.1494	.132	.1494	.128	.1494	.132	.1509
5	.168	.1509	.1698	.197	.168	.1509	.1886
6	.2075	.2378	.2054	.2195	.2075	.2402	.1886
7	.2172	.2378		.2149	.2686	.2561	.2012
8	.1772		.2507	.1772	.1753	.1991	.1753
9	.1715	.1886	.2229	.1696	.1509	.1526	.1715
10	.1677	.1943	.1526	.1865	.1619	.1739	.1734
11	.1658	.1739	.1526	.1526	.1638	.1475	.1753
12	.1677	.1562	.1543		.1658	.1457	.1595
13	.1677	.1619			.1526	.1457	.1578
14	.1658	.1526	.1578		.1543	.1543	.1772
15	.1844	.1509	.1886		.2126	.1677	.197
16	.2105	.1638	.1928		.176	.1658	.197
17	.1718	.16	.1928		.1829	.1658	.1949
18	.1781		.1791		.1943	.1638	.1791
19	.2401					.2374	.2534
20	.2715	.2629			.2686	.2658	.2353
21	.2195	.2328			.2353	.2303	.2195
22	.2033	.2195			.2195	.2534	.2012
23	.1663	.181	.1829	.168	.1663	.2195	.1886
24	.1663	.1494	.1463	.1494	.1494	.1494	.1886
Max	.2715	.2629	.2507	.2195	.2686	.2658	.2534
Min	.132	.1307	.1307	.128	.1307	.1307	.132
Avg	.1813	.1762	.1718	.1655	.1790	.1796	.1829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 201 / 11 KV KARMALA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6744	.3033	.3002	.3372	.1886	.2256
2	.5487	.6744	.3033	.2644	.3372	.1886	.2286
3	.5487	.6744	.3033	.2644	.3372	.1886	.2462
4	.6249	.7037	.3033	.2644	.3372	.1829	.2606
5	.6858	.7525	.3033	.2621	.3372	.1886	.3616
6	1.0311	1.0612	.3976	.3353	.3765	.2452	.5075
7	1.7743	.9907	.4927	.4847	.2286	.2829	.5792
8	.5243	.5801	.4549	.5151	.4972	.2641	.2195
9	.3673	.3296	1.8229	1.5089	1.8797	.7682	.1928
10	.3239	.2987	1.8496	1.3733	1.467	.7045	.1715
11	.3452	.2987	1.6575		.7133	.5801	.1715
12	.341	.2987	1.2971		.6325	.4915	.1715
13	.3452	.3353	1.1912		1.294	.4588	.1417
14	.3239	.2987	1.1203		1.3382	.4096	.1417
15	.3239	.3353	.9507		1.262	.362	.1696
16	.3239	.3353	1.0468		1.198	.3841	.1619
17	.3627	.3599	.3734		.4172	.2195	.16
18	.3753	.3787	.3353		.4165	.1753	.1875
19	.4111	.4542	.3926	.3048	.4542	.1227	.2507
20	.5273	.5304	.5273	.3048	.5304	.2957	.2865
21	.5087	.4927	.5087	.3048	.5115	.2743	.2743
22	1.0365	.4927	.49	.3048	.4927	.2896	.3765
23	1.118	.4361	.4527	.2286	.4549	.2572	.2858
24	.8576	.3353	.3222	.3391	.3391	.1886	.2225
Max	1.7743	1.0612	1.8496	1.5089	1.8797	.7682	.5792
Min	.3239	.2987	.3033	.2286	.2286	.1227	.1417
Avg	.5946	.5051	.7167	.4600	.6746	.3213	.2498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 203 / 11 KV PADALIWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1006	.6081	.7449	.8223	1.2803	.096
2	.1075	.1006	.6081	.6802	.8223	1.2803	.0949
3	.1052	.1006	.6081	.6802	.8223	1.2803	.0949
4	.1052	.1006	.6081	.6802	.8223	1.2803	.1107
5	.1227	.1006	.6401	.7125	.8223	1.2803	.1107
6	.1387	.1174	.7682	.7773	.8539	1.3123	.1265
7	.1387	.1341	.8002	.8583		1.2803	.128
8	.1029	.1341	.0934	.1296	.0791	.0987	.1423
9	2.9504	1.2239	.08	.0972	.0949	.08	1.1069
10	2.7854	.6554	.0937	.0791	.0846	.0972	1.1227
11	2.73	1.0159	.0972		.08	.0819	1.1069
12	2.6282	1.1142	.0972		.08	.096	1.0595
13	2.8292	1.0562	.1134		.08	.0983	1.0437
14	2.7161	1.0242	.1134		.08	.0972	.9804
15	2.6749	1.0242	.1134		.08	.0949	.9804
16	2.6235	.9922	.1134		.08	.0937	.9488
17	.0503	.0823	.1134		.0934	.0983	.0949
18	.1006	.096	.1296		.12	.1107	.0949
19	.1174	.1067	.1296		.12	.128	.112
20	.1006	.1067	.1296		.12	.128	.1265
21	.0924	.08	.1134		.12	.1107	.096
22	.1006	.7202			1.1843	.112	.0949
23	.1006	.7042	.6802		1.2483	.0949	.0949
24	.1132	.1006	.7682	.7773	.8223	1.3123	.0949
Max	2.9504	1.2239	.8002	.8583	1.2483	1.3123	1.1227
Min	.0503	.08	.08	.0791	.0791	.08	.0949
Avg	.9852	.4580	.3313	.5652	.4144	.4970	.4193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 201 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0166	.0166	1.1045	1.1305	***	***	***
2	.0166	.0166	1.0599	1.0462	***	***	***
3	.0166	.0166	.9783	.9699	1.0788	1.1484	.0574
4	.0166	.0166	.9396	.9088	***	***	***
5	.0166	.0166	.9229	.9218	***	***	***
6	.0332	.0475	.985	1.0294	1.1795	1.1376	.074
7	.0484	.0536	1.0534	1.2319	***	***	***
8	.085	.0774	.2329	.2935	***	***	***
9	2.1173	2.21	.0631	.0453	.0816	.0774	2.1074
10	2.1458	2.2447	.0315	.013	***	***	***
11	2.1199	2.2231	.0193		***	***	***
12	2.0507	2.1776	.0166	.0061	.044	.0242	2.1458
13	1.9507	2.0315	.0166	.017	***	***	***
14	1.8478	2.0148	.0166	***	***	***	***
15	1.8864	1.9458	.0166	.0166	.0558	.0166	2.0622
16	1.817	1.8363	.0166	***	***	***	***
17	.41	.2871	.028	***	***	***	***
18	.0616	.0332	.0425	.0343	.0336	.0166	.0332
19	.0885	.0332	.0261	***	***	***	***
20	.0885	.0425	.0166	***	***	***	***
21	.0627	.0166	.0166	.0166	.0717	.0166	.0597
22	.017	1.2808	1.4072	***	***	***	***
23	.0166	1.3134	1.4613	***	***	***	***
24	.0166	.6952	1.2954	1.3893	1.3715	.6872	.0166
Max	2.1458	2.2447	1.4613	25.6345	25.7008	25.5848	25.9992
Min	.0166	.0166	.0166	.0061	.0336	.0166	.0166
Avg	.7061	.8603	.4903	8.0542	16.9883	16.9098	17.1246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 202 / 11 KV KOKARUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8657	.6135	.0152	.0154	.0156	***	***
2	.8055	.5937	.0152	.0154	.0156	***	***
3	.7834	.5677	.0152	.0154	.0156	.0156	.661
4	.7845	.5221	.0152	.0154	.0156	***	***
5	.7979	.5388	.0152	.0154	.0156	***	***
6	.9046	.6097	.0152	.0154	.0156	.0156	.6587
7	.9961	.6006	.0152	.0154	.0156	***	***
8	.0156	.0156	.1059	.1175	.1973	***	***
9	.0156	.0156	1.8617	1.8732	1.8038	1.7841	.0164
10	.0156	.0156	1.7734	1.8481	2.018	***	***
11	.0156	.0156	1.5592	1.8023	2.0309	***	***
12	.0156	.0156	1.7844	.9831	1.9319	1.7129	.0156
13	.0164	.0156	1.7402		1.8264	***	***
14	.0156	.0156	1.6819		***	***	***
15	.0152	.0156	1.6803		1.6743	1.6061	.0156
16	.0156	.0156	1.6534	1.3535	***	***	***
17	.0156	.0156	.0154	.0156	***	***	***
18	.0156	.0156	.0154	.0156	.0164	.0158	.0156
19	.0186	.0156	.0154	.0156	***	***	***
20	.0156	.0156	.0154	.0156	***	***	***
21	.088	.0156	.0154	.0156	.0154	.0615	.075
22	.7506	.0152	.0154	.0156	***	***	***
23	.7354	.0152	.0154	.0156	***	***	***
24	.7735	.3125	.0152	1.25	.0156	.5049	.7544
Max	.9961	.6135	1.8617	1.8732	50.7084	50.7336	50.3066
Min	.0152	.0152	.0152	.0154	.0154	.0156	.0156
Avg	.3538	.1920	.5862	.4497	15.1167	33.7291	33.4839



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 203 / 11 KV KOKARUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.3391	.3681	.3258	.3429	.3258	.3467
2	.3467	.3391	.3506	.3258	.3429	.3258	.3294
3	.3467	.3222	.3506	.3086	.3429	.3258	.3294
4	.3814	.3222	.3681	.3086	.3772	.3601	.3294
5	.4334	.39	.4382	.3601	.4287	.4115	.3641
6	.5548	.5256	.5375	.4458	.4973	.5144	.4854
7	.5721	.5426	.5548	.5487	.5487	.5487	.5721
8	.5201	.5087	.5201	.5144	.4801	.5144	.5375
9	.4681	.4409	.4801		.8745	.4973	.4458
10	.4854	.5087	.4115		.8573	.4854	.4115
11	.4854	.5087	.4458	.4508	.823	.4161	.463
12	.4681	.5087	.4801	.5201	.8059	.4508	.4973
13	.4854	.4748	.4973	.4748	.4973	.4681	.4458
14	.5028	.4409	.5144	.5087	.4458	.4458	.463
15	.4681	.5087	.5487	.4748	.463	.4458	.5487
16	.5201	.4917	.4801	.4239	.4458	.583	.5487
17	.5375	.5596	.5144	.4748	.5316	.5487	.5658
18	.5721	.5087	.583	.4801	.5487	.5487	.6173
19	.6588	.6783	.6344	.6173	.6859	.6935	.7373
20	.7282	.7122	.7802	.6859	.7293	.7975	.7202
21	.6104	.6613	.6344	.6173	.6299	.7108	.6516
22	.5258	.5609	.5144	.5487	.4973	.6068	.583
23	.4207	.4733	.3258	.4287	.4508	.4681	.463
24	.3814	.3561	.4031	.3258	.3601	.3429	.3814
Max	.7282	.7122	.7802	.6859	.8745	.7975	.7373
Min	.3467	.3222	.3258	.3086	.3429	.3258	.3294
Avg	.4925	.4868	.4890	.4623	.5420	.4932	.4932

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 201 / 11 KV Dafalapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.3429	.2957	1.2003	.8383	.7716	.788
2	.3142	.3048	.2926	1.2003	.8383	.7373	.788
3	.3142	.3048	.2957	1.2003	.8383	.6859	.788
4	.2915	.3429	.2957	1.3717	.8718	.7716	.788
5	.462	.3963	.4251	1.5432	.9389	1.3435	.8859
6	.7207	.583	.6653	1.5947	1.4922	1.6221	.9313
7	.6535	.5182	.6468	1.869	1.861	1.5394	1.0082
8	.4938	.4458	.4435	.4904	.3921	.4096	.2772
9	1.5402	1.4403	.3696	.3584	.3734	.3201	.8686
10	1.5684	1.2763	.3326	.3395	.3174	.2949	1.3998
11	1.4232	1.3289	.3018	.2987	.2591	.2743	1.286
12	1.0974	1.2757	.2263	.2987	.3206	.2926	1.2174
13	1.0631	1.2715	.3018	.2987	.2622	.2801	.9431
14	.9012	1.2536	.3206		.2401	.2772	.8059
15	1.1633	1.3643	.2641		.2572	.2957	1.1883
16		1.3253	.2641		.2294	.3142	1.0288
17	.3086	.3142	.3584		.253	.3326	.3395
18		.3696	.4527		.3601	.3696	.3584
19	.4458	.5487	.5847		.5079	.6535	.5093
20	.4588	.5729	.6036		.5658	.6535	.547
21	.4287	.5175	.5658		.5144	.5729	.5658
22	.3605	.4251	1.3717		1.2689	1.1104	.4527
23	.3086		1.3375			.8596	.3772
24	.3292	.2915	.3109	1.286	.8886	.7011	.8059
Max	1.5684	1.4403	1.3717	1.869	1.861	1.6221	1.3998
Min	.2915	.2915	.2263	.2987	.2294	.2743	.2772
Avg	.6801	.7310	.4719	.9536	.6387	.6451	.7895

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 202 / 11 KV Baj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.2458	.3142	1.5432	1.0898	1.0669	1.0277
2	.3511	.2572	.3142	.1543	1.1203	1.0669	1.0387
3	.3511	.2486	.3142	1.5432	1.0059	1.2003	1.0387
4	.3475	.2401	.3142	1.6289	1.0395	1.2003	1.0277
5	.462	.3772	.4251	.1835	1.1065	1.5242	1.1641
6	.6099	.4475	.5729	2.0405	1.8442	1.9509	1.5415
7	.5729	.4807	.5359	2.332	2.2801	2.13	1.6832
8	.4207	.3601	.3511	.415	.4108	.3481	.439
9	1.9591	1.7833		.3206	.2987	.2622	1.3611
10	1.9418	1.5432		.3206	.2987	.2458	1.587
11	1.7071	1.5581		.2427	.2743	.2218	1.406
12	1.3599	1.4685	.3018	.2614	.2743	.2587	1.3375
13	1.1431	1.6124	.3395		.2743	.2957	1.3375
14	1.3108	1.576	.3395		.2572	.2926	1.3203
15	1.6712	1.7541	.3018		.2401	.2772	1.5432
16		1.825	.3206		.2439	.2561	1.8176
17			.3772		.2785	.2926	
18			.415		.3277	.3734	
19	.4115	.5175	.4715		.5144	.5544	.547
20	.3605	.5175	.5093		.5144	.5175	.547
21	.3258	.4024	.4338		.4588	.4755	.4904
22	.2915	.3881	1.8004		1.0364	1.4864	.4338
23	.2458		1.7147			1.1641	.3961
24	.3696	.2622	.3086	1.6289	1.1736	1.0212	1.0566
Max	1.9591	1.825	1.8004	2.332	2.2801	2.13	1.8176
Min	.2458	.2401	.3018	.1543	.2401	.2218	.3961
Avg	.7888	.8507	.5131	.9704	.7114	.7701	1.0974

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 203 / 11KV Mirwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2178	.9907	1.0425	.1698	.2054	.1715	.1848
2	1.2178	.9907	1.0534	.1698	.2054	.1638	.1848
3	1.2178	1.065	1.0099	.1698	.2054	.1658	.1848
4	1.2178	.9907	1.0208	.2263	.2054	.1638	.1867
5	1.5947	1.3032	1.2449	.3018	.2614	.2286	.2378
6	1.9938	1.6409	1.576	.3584	.4108	.3277	.3326
7	2.6467	2.1605	1.8073	.3772	.4108	.3201	.3841
8	.2957	.2915	.2402	.2829	.2987	.2458	.2926
9	.2195	.1677	1.8031	2.2805	2.4143	2.1792	.2012
10	.1829	.1886	1.8861	2.2977	2.3807	2.0481	.168
11	.12	.1494	1.5947	2.1293	2.4348	2.1262	.1698
12	.1543	.1494	1.7318		1.9757	2.1616	.1886
13	.1219	.1509	1.749		1.8515	2.0911	.1698
14	.1543	.1463	1.6632		1.704	1.9342	.1698
15	.1311	.1509	1.8004		2.1605	1.773	.1698
16		.1663	1.8861		1.9989	2.0199	.2075
17	.1886	.1848	.2075		.1629	.1663	.2263
18		.1848	.2452		.1802	.1848	.2452
19	.2743	.3326	.2829		.2818		.3018
20	.2294	.3292	.3206		.3048	.3475	.3395
21	.2572	.2743	.2829		.2743	.3174	.3206
22	1.2193	1.6832	.2263		.2229	.2772	2.0919
23	1.166		.2075			.2012	1.7147
24	1.2357	1.065	1.0277	.1886	.2054	.1372	.2012
Max	2.6467	2.1605	1.8861	2.2977	2.4348	2.1792	2.0919
Min	.12	.1463	.2075	.1698	.1629	.1372	.168
Avg	.7753	.6416	1.0796	.7460	.9024	.8588	.3697

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 204 / 11 Kv Baj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.132	.0857	.1132	.112	.1509	.0943
2	.0934	.1067	.0943	.1132	.112	.1509	.0943
3	.0943	.132	.0943	.1132	.112	.1509	.0943
4	.0943	.116	.0943	.132	.112	.1509	.0934
5	.1494	.132	.168	.1698	.1307	.1311	
6	.1867		.2218	.2075	.2054	.1509	.168
7	.2452	.1326	.2218	.1886	.2054	.1698	.1867
8	.1867	.12	.1543	.1509	.1307	.132	.1494
9	.1494	.132	.2988	.132	.112	.132	.1509
10	.1307	.1372	.1294	.132	.1307	.1509	.1132
11	.132	.1307	.132	.0747	.1509	.112	.1132
12	.12	.112	.132	.112	.1886	.1132	.1132
13	.1509	.1307	.1132	.112	.1698	.0943	.8865
14	.1311	.112	.132		.168	.0934	.1132
15	.132	.0943	.132		.1372	.0754	.1132
16		.1132	.1132		.1509	.0943	.1132
17	.1372	.1867	.132		.1698	.1494	.132
18		.2241	.1886		.1886	.2054	.1509
19	.1886	.2587	.2263		.2263	.2614	.1698
20	.1886	.2452	.2641		.2263	.2801	.2263
21	.1886	.2241	.1886		.1886	.2075	.1886
22	.1311	.1509	.1509		.1543	.1509	.1509
23	.1067		.132			.1307	.132
24	.112	.132	.112	.1132	.112	.1509	.1132
Max	.2452	.2587	.2988	.2075	.2263	.2801	.8865
Min	.0934	.0943	.0857	.0747	.112	.0754	.0934
Avg	.1429	.1480	.1547	.1332	.1563	.1496	.1679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 205 / 11 KV Dafalapur GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1029	.112	.1132	.112	.1372	.1307
2	.112	.1029	.1132	.1132	.112	.1509	.1307
3	.1132	.0983	.112	.1132	.112	.1219	.1307
4	.112	.1132	.112	.132	.112	.1509	.1307
5	.1494	.0914	.168	.132	.1307	.1357	.1494
6	.1698	.1509	.2033	.1509	.168	.1509	.1663
7	.1509	.1372	.2427	.1509	.1494	.1698	.1867
8	.1307	.12	.1132	.132	.1307	.132	.1307
9		.12		.1132	.112	.132	.0943
10	.1307	.1509	.112	.1132	.1494	.1509	.1307
11	.12	.1867	.132	.1307	.1385	.1494	.132
12	.12	.1494	.132	.1307	.1886	.1494	.1509
13	.1372	.1867	.1509	.1494	.1475	.1494	.132
14	.1372	.1494	.1509		.1698	.1294	.132
15	.132	.1478	.1509		.1372	.132	.132
16		.1494	.1509		.1492	.1543	.132
17	.1372	.1867	.2263		.1526	.1478	.1509
18		.168	.2263		.1524	.1867	.1509
19	.2075	.2614	.2641		.1981	.2241	.2263
20	.2075	.2427	.2641		.2229	.2241	.2452
21	.1619	.2075	.2075		.1802	.2075	.1886
22	.1372	.1698	.1886		.1698	.1867	.1886
23			.1509			.168	.1509
24		.132	.1307	.132	.1307	.1372	.1494
Max	.2075	.2614	.2641	.1509	.2229	.2241	.2452
Min	.112	.0914	.112	.1132	.112	.1219	.0943
Avg	.1410	.1533	.1658	.1290	.1489	.1574	.1518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 206 / 11 KV ANKALE DORLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7551		1.1871	.2641	.2614	.3429	.3142
2	1.7737		1.1488	.2641	.2614	.3429	.3109
3	1.7364		1.1999	.2641	.2614	.3277	.3142
4	1.7177		1.1871	.3584	.2614	.3277	.3142
5	1.9281		1.3073	.4338	.2987	.4572	.3696
6	2.3834		1.6301	.5093	.5415	.5601	.5175
7	2.8464		2.2018	.5847	.6161	.4973	.5914
8	.4435		2.2539	.4527	.4854	.3315	.439
9	.3511			2.5377	2.6155	2.6216	.4938
10	.3326	1.7661	2.7166	2.6235	2.7846	2.7362	.4251
11	.2915	.3326	2.1776	2.5484	2.6063	2.8045	.415
12	.2915	.3475	2.0919		2.5034	2.6699	.415
13	.1886	.3696	1.989		2.0972	2.3834	.3961
14	.2572	.3109	1.9033		2.3148	2.4099	.3772
15	.2229	.3475	2.1776		2.1136	2.4006	.3961
16		.3326	1.9376		1.8084	2.3312	.3018
17		.2957	.3206		.1966	.2572	.3584
18		.3511	.415		.2949	.3511	.3961
19		.5304	.4904		.4588	.499	.4904
20		.5359	.5281		.4752	.5544	.5281
21		.462	.415		.4096	.4938	.4527
22		1.7528	.3206		.2743	.4066	2.1948
23			.3018			.3326	1.9204
24	1.7353		1.2178	.2829	.2614	.2743	.3326
Max	2.8464	1.7661	2.7166	2.6235	2.7846	2.8045	2.1948
Min	.1886	.2957	.3018	.2641	.1966	.2572	.3018
Avg	1.1409	.5950	1.3530	.9270	1.0523	1.1131	.5444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 201 / 11 KV Billur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17	05-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145		.1696	.1357
2	.9145		.1696	.1357
3	.9145		.1696	.1187
4	1.0669		.1696	.1357
5			.1696	.1696
6	1.1431		.2543	.2204
7	.1524		.2543	.2543
8	.1524		.1696	.1696
9	.1524		1.4918	1.1603
10	.1524		1.3413	1.326
11		1.1105	1.1603	
12	.1524	1.1603		
13	.1524	1.1603		
14	.1524	1.1603		
15	.1524	1.326		
16		1.4918		
17		.1696		
18		.1696		
19		.1696		
20		.1696		
21		.1696		
22		.2204		
23		.1696		
24	1.0669		.1696	.1696
Max	1.1431	1.4918	1.4918	1.326
Min	.1524	.1696	.1696	.1187
Avg	.5171	.6652	.4741	.3632



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 202 / 11kv salmalgewadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17	05-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717		1.989	1.989
2	1.3717		1.989	1.989
3	1.3717		1.989	1.989
4	1.3717		1.989	1.989
5	1.5242		2.3205	2.1548
6	1.5242		2.4863	2.4863
7	1.9719		2.652	2.652
8	.0762		.3391	.3391
9	2.572		1.6575	1.4918
10	2.4006		1.4089	1.6766
11	2.2291	1.3426	1.4089	
12	2.1434	1.2717	.2543	
13	1.8623	1.1603		
14	2.0576	1.1603		
15	2.1434	1.3565		
16		1.4918		
17		.2543		
18		.2543		
19		.4239		
20		.5087		
21		.5087		
22		2.652		
23		2.4863		
24	1.6461		2.3205	2.1548
Max	2.572	2.652	2.652	2.652
Min	.0762	.2543	.2543	.3391
Avg	1.7274	1.1440	1.7542	1.9010

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 203 / 11 KV Wajrawad ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17	05-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		1.326	1.1603
2	.2286		1.326	1.1869
3	.2286		1.1603	1.1603
4	.2286		1.1603	1.326
5	.2286		1.326	1.326
6	.3048		1.4918	1.4918
7	.3048		1.8233	1.8233
8	.2286		.2543	.2543
9	1.5242		.1696	.1696
10	1.3717		.1696	.1696
11	1.3717	.1357	.1357	
12	1.3717	.1696	.1187	
13	1.1431	.1696		
14	1.1431	.1696		
15	1.2193	.1696		
16		.1696		
17		.1696		
18		.1696		
19		.2543		
20		.3391		
21		.2543		
22		1.989		
23		1.8233		
24	.2286		1.6575	1.326
Max	1.5242	1.989	1.8233	1.8233
Min	.2286	.1357	.1187	.1696
Avg	.7097	.4602	.9322	1.0358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 204 / 11 Kv Billur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	03-APR-17	04-APR-17	05-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524		.0924	.0739
2	.1524		.0924	.0739
3	.1524		.0924	.0924
4	.1524		.0924	.0924
5	.1524		.0924	.0924
6	.1524		.1848	.1294
7	.1524		.2772	.1848
8	.1524		.1848	.1294
9	.2286		.0924	.0924
10	.2286		.0924	.0924
11	.1524	.0739	.0739	
12	.1524	.0924	.0739	
13	.1524	.0924		
14	.0762	.0924		
15	.1524	.0924		
16		.0924		
17		.0924		
18		.0924		
19		.1848		
20		.2772		
21		.1848		
22		.1294		
23		.0924		
24	.1524		.0924	.0924
Max	.2286	.2772	.2772	.1848
Min	.0762	.0739	.0739	.0739
Avg	.1572	.1223	.1180	.1042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 205 / 11 kv Wajrwad Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524			.1848	.1478		
2	.1524			.1478	.1478		
3	.1524			.1294	.1478		
4	.1524			.1478	.1478		
5	1.0669			.1848	.1848		
6	.1524			.2772	.2218		
7	.1524			.3696	.2772		
8	.1524			.2772	.2218		
9	.2286			.1848	.1848		
10	.2286			.1478	.1848		
11	.2286		.1478	.1478			
12	.2286		.0924	.1478			
13	.2286		.1478				
14	.2286		.1663				
15	.2286		.1478				
16			.1478				
17			.1478				
18			.1848				
19			.2772				
20			.3696				
21			.2772				
22			.2218				
23			.2402				
24	.1714	.0857	.0857	.2877	.2534	.1029	.1029
Max	1.0669	.0857	.3696	.3696	.2772	.1029	.1029
Min	.1524	.0857	.0857	.1294	.1478	.1029	.1029
Avg	.2441	.0857	.1896	.2027	.1927	.1029	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 206 / 11 kv Gugwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17	05-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0848	.0678
2	.0762		.0848	.0663
3	.0762		.0848	.0678
4	.0762		.0848	.0678
5	.0762		.0678	.0829
6	.0762		.0848	.0848
7	.0762		.0848	.0848
8	.0305		.0678	.0848
9	.0305		.3315	.1658
10	.0152		.2486	.2486
11	.0305	.2652	.2486	
12	.0305	.2543		
13	.0305	.1696		
14	.0457	.1658		
15	.0457	.2543		
16		.3315		
17		.0509		
18		.0509		
19		.0848		
20		.0848		
21		.0848		
22		.0848		
23		.0848		
24	.0305		.0848	.0663
Max	.0762	.3315	.3315	.2486
Min	.0152	.0509	.0678	.0663
Avg	.0514	.1513	.1298	.0989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 201 / 11 KV SHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8848	.5571	.7865	.1966	.2622	.2294	.1966
2	.852	.5571	.7537	.1966	.3113	.1966	.1966
3	.852	.5571	.7537	.1966	.2622	.1966	.1966
4	.9503	.6554	.9175	.1966	.2622	.1802	.1966
5	1.4746	1.3108	.9175	.3441	.3277	.3932	.2622
6	1.6876	1.6057	1.1142	.5415	.3932	.5243	.3277
7	2.1464	2.0317	.852	.4588	.426	.3932	.3768
8	.2622	.3277	.3277	.2949	.3277		.2785
9	.2294	.2622	1.3435	1.6712	1.278	1.6549	.2622
10	.2294		1.6385	.9012	1.7695	1.7368	.2458
11	.2622	.2294	1.7695	1.6549	1.7695	1.6712	.2458
12	.2622	.2294	1.5729			1.5893	.2622
13	.2622	.2294	1.5565			1.5893	.2294
14	.2785	.2294	1.491		1.8515	1.3927	.2458
15	.2622	.2294	1.5729		1.7532	1.5565	.2458
16	.2458	.2294	1.5893		1.7532	1.7368	.2294
17	.1966	.2294	.1966		.2294	.2458	.2458
18	.2785	.2622	.2949		.2458	.2949	.2622
19	.1966	.3277	.4096		.3113	.3441	.3277
20		.4096	.4096		.3932	.426	.3932
21	.2949	.3605	.3441		.3932	.3768	.3932
22	.6554	1.1142	.2949		.2949	.2785	1.4419
23	.6226	.9175	.2294		.2458	.2294	1.1142
24	.9012	.6062	.7865	.213	.2987	.2294	.1966
Max	2.1464	2.0317	1.7695	1.6712	1.8515	1.7368	1.4419
Min	.1966	.2294	.1966	.1966	.2294	.1802	.1966
Avg	.6212	.5856	.9134	.5722	.6891	.7594	.3489

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 202 / 11 KV Walekhindi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.663	.6554	.6882	.1475	.1147	.0663	.0819
2	.663	.6554	.6554	.1475	.1147	.0663	.0819
3	.6299	.6554	.5898	.1311	.1147	.0663	.0819
4	.6962	.6554	.5243	.1311	.1147	.0663	.0819
5	.9116	.8192	.6554	.1475	.1311	.0829	.1147
6	1.0608	1.0159	.7701	.1638	.1475	.116	.1311
7	1.2266	1.1305	.7209	.1802	.1475	.1326	.1475
8	.2155	.2294	.213	.1802	.0983	.0663	.0983
9	.1989	.1966	.9667	1.065	1.1142	1.0814	.1147
10	.2321	.1966	.9831	1.1633	1.3763	1.278	.0983
11	.0829	.1966	1.0159	.1341	1.1961	1.278	.1311
12	.1823	.1638	1.065			1.2452	.0983
13	.2321	.1802	.8848			1.0442	.0983
14	.2155	.213	.9667		1.2125	.9339	.0819
15	.2155	.2294	.8684		1.2452	1.0814	.0983
16	.1989	.0983	.9667		1.1633	1.0814	.0819
17	.2321	.1311	.1475		.2458	.1147	.0983
18	.2294	.1311	.1475		.1966	.0983	.0829
19	.1966	.2458	.1638		.1802	.1475	.1174
20		.2458	.1638		.1966	.1638	.1326
21	.213	.0983	.1802		.1802	.1147	.0995
22	.6882	.8029	.1638		.0655	.0983	.9614
23	.6882	.7701	.1475		.0655	.0819	.9448
24	.6796	.6718	.7045	.1147	.1147	.0655	.0819
Max	1.2266	1.1305	1.065	1.1633	1.3763	1.278	.9614
Min	.0829	.0983	.1475	.1147	.0655	.0655	.0819
Avg	.4588	.4328	.5980	.3088	.4335	.4405	.1725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 203 / 11 KV SHINGANHALI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.2012	.1677	1.0898	1.1401	1.0059	1.0059
2	.1677	.2012	.1509	1.0562	1.1736	.9724	1.0059
3	.1677	.2012	.1341	1.0562	1.1736	.9724	1.0059
4	.1844	.2012	.1341	1.073	1.1736	.9221	1.0059
5	.2515	.3353	.3018	1.5424	1.3413	1.3413	1.4586
6	.4024	.3688	.4024	1.7604	1.8351	1.6766	1.6766
7	.3185	.285	.3185	2.079	1.9448	1.3413	1.8107
8	.2347	.2347	.218	.2683	.2347	.2012	.218
9	1.6933	1.7436	.1677	.218	.1677	.218	1.3916
10	1.7269	1.7939	.1174	.1677	.1509	.1844	1.5927
11	1.576	1.5257	.112	.1341	.1509	.1509	1.4419
12	1.4754	1.4419	.1307	.1677		.1341	1.3245
13	1.5089	1.3413	.1341	.1677		.1341	1.2239
14	1.4754	1.3748	.1341		.1509	.1174	1.1233
15	1.3077	1.6095	.1341		.1509	.1341	1.291
16	1.4419	1.6766	.1509		.1509	.1341	1.2742
17	.2012	.1509	.1509		.1844	.1677	.1677
18	.2347	.1677	.218		.1677	.1966	.2012
19	.2012	.2683	.3353		.3018	.2622	.2683
20		.3353	.3353		.3353	.3185	.3353
21	.2683	.3018	.3018	.3018	.285	.3353	.2683
22	.2347	.2347	1.8442	1.7772	1.7436	1.4586	.2012
23	.2012	.2012	1.4922	1.4419	1.3413	1.2071	.1677
24	.2012	.2012	.2012	.2622	1.1736	1.073	1.0059
Max	1.7269	1.7939	1.8442	2.079	1.9448	1.6766	1.8107
Min	.1677	.1509	.112	.1341	.1509	.1174	.1677
Avg	.6808	.6832	.3245	.8567	.7487	.6108	.9361



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 204 / 11 Kv Walekhindi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.056	.0373	.056	.056	.056	.056
2	.0373	.056	.0373	.0373	.056	.056	.056
3	.0373	.056	.0373	.0373	.056	.056	.056
4	.0373	.056	.0373	.0373	.056	.056	.056
5	.0747	.0747	.0373	.056	.056	.056	.0747
6	.0934	.0934	.0747	.0747	.0671	.0747	.0934
7	.0747	.0934	.0747	.056	.0934	.0934	.0747
8	.056	.056	.056	.056	.0934	.0934	.056
9	.056	.0747	.056	.056	.0747	.0747	.056
10	.0747	.0934	.056	.056	.0747	.056	
11	.0373	.0747	.056	.056	.0747	.0747	.056
12	.0747	.0934	.056	.056		.056	.056
13	.0373	.0747	.056	.056		.0747	.056
14	.0373	.0747	.056			.056	.056
15	.0373	.0747	.056			.056	.056
16	.056	.056	.056		.0934	.0747	.056
17	.056	.0747		.0747	.0747	.0747	.056
18	.0934	.0747	.0934	.0747	.112	.0747	.0747
19	.0747	.1494	.112	.1307	.112	.112	.1307
20		.1307	.112	.1307	.1307	.1307	.112
21	.0934	.112	.0934	.0934	.0934	.0934	.0934
22	.0747	.0747	.0747	.0747	.0747	.0747	.0747
23	.0747	.056	.056	.056	.056	.056	.056
24	.056	.0747	.056	.056	.056	.056	.056
Max	.0934	.1494	.112	.1307	.1307	.1307	.1307
Min	.0373	.056	.0373	.0373	.056	.056	.056
Avg	.0601	.0794	.0625	.0658	.0780	.0724	.0682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 205 / 11 KV SHEGAON GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1494	.112	.112	.1494	.1307	.1307
2	.1494	.1494	.0934	.112	.1307	.0934	.1307
3	.1494	.1494	.0934	.112	.1307	.0934	.1307
4	.1494	.1494	.0934	.112	.1307	.0934	.1307
5	.3361	.1867	.1307	.1307	.1307	.168	.1867
6	.2427	.2241	.2241	.2241	.2241	.2427	.2614
7	.2614	.2614	.2241	.2241	.1867	.2614	.2241
8	.2427	.2801	.2241	.2241	.168	.2427	.1867
9	.2427	.2987	.2801	.3174	.112	.2801	.2801
10	.2054	.2427	.2241	.2241	.2054	.2241	.2427
11	.2241	.0747	.2054	.2054	.2241	.2241	.2054
12	.2241	.2241	.1867	.1867		.2054	.1867
13	.168	.0373	.168	.168		.1494	.168
14	.0373	.0373	.168		.2241	.1867	.1867
15	.168	.1494	.1867		.1867	.2054	.2054
16	.2054	.1494	.2241		.2241	.2427	.168
17	.2987	.2241	.2241		.2054	.2427	.1867
18	.2987	.2801	.2614		.3174	.2054	.2987
19	.2241	.3174	.3547		.2987	.3361	.2614
20		.3361	.3547		.4108	.3361	.2801
21	.2427	.2987	.2987		.3174	.2987	.2427
22	.2054	.2054	.2054		.2427	.2054	.2054
23	.168	.1494	.168		.2241	.168	.1494
24	.168	.1494	.1307	.1307	.1494	.168	.1307
Max	.3361	.3361	.3547	.3174	.4108	.3361	.2987
Min	.0373	.0373	.0934	.112	.112	.0934	.1307
Avg	.2070	.1968	.2015	.1774	.2088	.2085	.1992

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 202 / 11KV Khojanwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2926	.439	.3292		1.9814
2		.2926	.4024	.3292		1.9052
3		.2743	.4024	.3292		1.929
4		.2743	.439	.3292		2.0062
5		.3292	.462	.3658		2.1872
6		.439	.5041	.4024		2.5301
7		.3658	.5601	.5487		3.0769
8			.5601	.5487		2.1091
9			.5601	.5121		.2743
10			.4854	.5121		.2801
11		2.3624	.462			.3734
12		2.3624				.3658
13		2.2862				.4572
14		2.2862				.4481
15		2.21				.4294
16		2.392				.4066
17		.2772				.3734
18	.2926	.3326	2.5911			.3734
19	.3292	.3734	2.5911		.4668	
20		.5281	2.4387		.5228	
21		.4904	2.2862		.4854	
22		.4668	2.2862		.3734	
23		.4668	2.2862		.2987	
24		.2926	.4435	2.21		.3326
Max	.3292	2.392	2.5911	2.21	.5228	3.0769
Min	.2926	.2743	.4024	.3292	.2987	.2743
Avg	.3109	.9236	1.1222	.5833	.4294	1.1494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 203 / 11 KV SINDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9907	.2926		.1829
2			1.0364	.2926		.1829
3			1.0494	.2926		.1848
4			1.0802	.2926		.2218
5			1.186	.2926		.2801
6			1.8623	.3292		.4715
7			2.1605	.3292		.4108
8			1.9204	.4024		.3734
9			1.5813	2.0119		
10			1.5623	1.5089		.2772
11		.2263	1.4661			.2801
12		.2263				.2241
13		.2263				.2801
14		.2263				.2801
15		.2241				.2402
16		.2241				.2241
17		.2263				2.4577
18		.2801	.1867			2.5692
19	.2683	.2829	.2801			
20		.3772	.2743		1.2289	
21		.2801	.3292		1.1603	
22		.2241	.3292		1.989	
23		.2241			1.8023	
24	1.3717		.2218	.2561		1.6804
Max	1.3717	.3772	2.1605	2.0119	1.989	2.5692
Min	.2683	.2241	.1867	.2561	1.1603	.1829
Avg	.82	.2499	1.0304	.5728	1.5451	.6012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 204 / 11 Kv Umrani Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0486	.0486		.0486
2			.0324	.0486		.0324
3			.0324	.0486		.0324
4			.0486	.0648		.0324
5			.0486	.0648		.0486
6			.0972	.081		.0972
7			.0648	.0648		.081
8			.0486	.0648		.0648
9			.0486	.0648		.0648
10			.0486	.0732		.0648
11		.0486	.0486			.0648
12		.0486				.0648
13		.0324				.081
14		.0324				.0648
15		.0324				.0486
16		.0486				.0486
17		.0486				.0324
18	.0972	.0648	.0503			.0324
19	.0972	.081	.081		.081	
20		.0972	.1296		.1457	
21		.081	.1457		.1296	
22		.081	.1296		.0972	
23		.0648	.0648		.0486	
24			.0486	.0486		.0486
Max	.0972	.0972	.1457	.081	.1457	.0972
Min	.0972	.0324	.0324	.0486	.0486	.0324
Avg	.0972	.0586	.0676	.0611	.1004	.0554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 201 / 11 KV DEVANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2721	.5838	.3628	4.0032	3.8881	3.7175	3.6214
2	.2721	.5678	.362	3.9628	3.8836	3.6565	3.568
3	.2721	.5846	.3658	3.9491	3.85	3.6176	3.501
4	.2721	.6059	.3856	3.946	3.8226	3.6512	3.5155
5	.3201	.6585	.397	4.5343	3.9224	3.9453	3.5589
6	.3521	.7994	.4809	5.6386	5.2888	5.1257	4.3954
7	.3201	.849	.8913	5.7392	3.1139	5.275	4.6937
8	.3201	1.4106	.785	.5571	.3772	.6669	1.7054
9	2.1125	2.6536	.5761	.5396	.3216	.5914	4.0298
10	2.0965	2.7267	.6116	.5541	.2667	.5578	4.0459
11	2.0805	2.6635	.618	.5777	.2949	.5184	4.151
12	1.9204	2.5141	.5934	.1562	.3025	.5552	4.1099
13	1.8404	2.3823	.5434		.3254	.559	3.7487
14	1.8564	2.412	.5312		.2926	.3583	3.6039
15	2.0805	2.7892	.5228		.2827	.4269	4.0787
16	2.0325	2.8067	.5091	.5625	.3041	.5217	4.5268
17	.192	.2561	.5708	.3757	.3315	.7027	.5945
18	.3201	.3125	.5945	.3879	.4161	.7591	.6303
19	.2881	.3917	.6996	.4115	.439	.8863	.7834
20	.2561	.4222	.7446	.4344	.3765	.849	.8132
21	.2241	.4153	2.0424	2.1155	1.864	2.1712	.8093
22	.2561	.3887	4.132	4.4209	2.3434	4.1229	.6783
23	.2561	.365	4.0311	4.3477	2.2687	3.9103	.6638
24	.2721	.6326	2.2123	4.087	3.9628	3.8397	2.0132
Max	2.1125	2.8067	4.132	5.7392	5.2888	5.275	4.6937
Min	.192	.2561	.362	.1562	.2667	.3583	.5945
Avg	.8536	1.2580	.9818	2.4429	1.7725	2.1244	2.8267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 202 / 11 KV PACCHPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.044	.0587		.3668	.3374	.2896	.2934
2	.044	.0587		.3668	.3374	.2896	.2934
3	.044	.0587		.3668	.3374	.2896	.2934
4	.044	.0587		.3814	.3374	.2896	.2934
5	.0734	.0734		.6602	.3961	.3475	.2934
6	.088	.0587		.7335	.7188	.5937	.4548
7	.0587	.0734	.0869	.6895		.695	.4988
8	.044		.0579	.0587		.0579	.0587
9	.5135		.0579	.044		.0579	.3227
10	.5575		.0434	.044		.0579	.4401
11	.5428		.0434	.0587		.0579	.5281
12	.5135		.044			.0434	.4401
13	.5868		.044			.0434	.3668
14	.4694		.044			.0434	.3668
15	.5135		.044			.0434	.3814
16	.5135		.044			.0434	.4108
17	.0587		.044			.0434	.0587
18	.0587		.044			.044	.0587
19	.0587		.0587			.0734	.0587
20	.0587		.0734			.0734	.0734
21	.0587		.088			.0734	.0734
22	.0587		.3227	.4108		.3521	.044
23	.0587		.3668	.4108		.3374	.044
24	.044	.0587		.3668	.3374	.2896	.2934
Max	.5868	.0734	.3668	.7335	.7188	.695	.5281
Min	.044	.0587	.0434	.044	.3374	.0434	.044
Avg	.2127	.0624	.0887	.3542	.4003	.1887	.2684

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 203 / 11 KV Rawalgundwadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1052	1.9595		.3401	.502	.421	.4801
2	2.1052	1.9595		.3401	.502	.421	.4801
3	2.1052	1.9595		.3401	.502	.421	.4801
4	2.1052	1.9595		.3401	.502	.4372	.4858
5	2.4615	1.9595		.3887	.5506	.4534	.502
6	2.6073	2.4777		.4534	.583	.5344	.502
7	2.5911	2.5911	1.7814	.5182		.5182	.5668
8	.3401		.2267	.3239		.421	.583
9	.3239		1.6194	2.4453		2.5425	.502
10	.3563		1.8947	2.5587		2.6235	.4534
11	.3401		2.2672	2.4615		1.3927	.4534
12	.3725		2.2996			2.1214	.4049
13	.3887		2.1628			2.1376	.421
14	.3887		2.1628			2.1376	.3563
15	.3887		2.2119			2.5101	.421
16	.3887		2.4086			2.5425	.3887
17	.2915		.3277		.2267	.2267	.3563
18	.2591		.2949		.3563	.4001	.3563
19	.2429		.3201		.4372	.4641	.3887
20	.2267		.3201		.4858	.4641	.3563
21	.2267		.4001		.4858	.4641	.3887
22	2.1862		.426	.5668	.4534	.4961	1.9433
23	1.9814		.4588	.5182	.421	.4961	2.332
24	2.1052	2.0243		.3401	.502	.421	.4858
Max	2.6073	2.5911	2.4086	2.5587	.583	2.6235	2.332
Min	.2267	1.9595	.2267	.3239	.2267	.2267	.3563
Avg	1.1203	2.1113	1.2696	.8525	.4650	1.0445	.587



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 204 / 11 kv Rawalgundwadi Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0886		.0716	.0724	.0724	.0895
2	.0532	.0886		.0716	.0724	.0724	.0895
3	.0532	.0886		.0716	.0724	.0724	.0895
4	.0532	.0886		.1075	.0724	.0724	.0895
5	.0532	.1063		.1791	.0905	.1086	.1075
6	.0709	.1417		.1254	.1448	.1629	.1433
7	.0709	.1417	.1075	.0895		.1267	.1433
8	.1063		.0895	.1433		.1086	.1433
9	.0886		.0716	.1254		.1086	.0716
10	.0886		.0895	.0886		.0905	.0716
11	.0886		.0716	.0709		.1448	.0716
12	.0886		.0895	.1063		.1086	.0895
13	.0709		.0895	.1063		.1086	.0716
14	.0709		.0895			.1086	.0895
15	.0709		.0716			.1086	.1075
16	.124		.0537	.0905		.0905	.0895
17	.1417		.0537	.0905		.1267	.0716
18	.124		.0537			.1612	.0716
19	.1417		.1791			.2149	.1075
20	.1417		.1791	.2172		.2149	.2149
21	.1063		.2507		.181	.1612	.197
22	.0886		.1075	.1267	.1448	.1254	.1086
23	.0886		.1254	.0905	.0905	.0895	.1086
24	.2229	.0886		.0716	.0724	.0905	.0895
Max	.2229	.1417	.2507	.2172	.181	.2149	.2149
Min	.0532	.0886	.0537	.0709	.0724	.0724	.0716
Avg	.0949	.1041	.1043	.1076	.1014	.1187	.1053

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 205 / 11 kv Pachhapur Amrutwadi  
gav Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0183		.0185	.0181	.0181	.0185
2	.0183	.0183		.0185	.0181	.0181	.0185
3	.0183	.0183		.0185	.0181	.0181	.0185
4	.0183	.0183		.0185	.0181	.0181	.0185
5	.0366	.0366		.037	.0181	.0362	.0185
6	.0183	.0549		.037	.0724	.0724	.0554
7	.0366	.0732	.0739	.037		.0905	.0554
8	.0366		.0185	.037		.0362	.0554
9	.0183		.0185	.037		.0181	.0185
10	.0183		.037	.0183		.0181	.0185
11	.0183		.0185	.0183		.0181	.0185
12	.0183		.0185	.0183		.0181	.0185
13	.0183		.0185			.0181	.0185
14	.0183		.0185			.0181	.0185
15	.0183		.0185			.0181	.0185
16	.0183		.0185			.0181	.0185
17	.0366		.0185		.0181	.0181	.0185
18	.0183		.0185		.0181	.037	.0185
19	.0366		.0554		.0543	.0924	.0554
20	.0549		.037		.0905	.0924	.0554
21	.0366		.0185		.0905	.0924	.037
22	.0183		.0185	.0543	.0543	.037	.0362
23	.0183		.037	.0181	.0181	.0185	.0181
24	.0183	.0183		.0185	.0181	.0181	.0185
Max	.0549	.0732	.0739	.0543	.0905	.0924	.0554
Min	.0183	.0183	.0185	.0181	.0181	.0181	.0181
Avg	.0244	.0320	.0272	.0270	.0375	.0358	.0277

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 201 / 11 KV Kosari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.0514	.1715	.7888	.7716	.823	.6687
2	.1372	.0514	.1886	.7888	.7716	.7373	.6344
3	.12	.0514	.1886	.823	.7888	.7373	.6173
4	.1715	.0686	.1886	.8916	.7888	.7202	.6344
5	.2058	.0857	.2229	1.0631	.8059	.7202	.6687
6	.2572	.1029	.2743	1.3203	1.2003	1.2003	.9774
7	.2572	.1029	.2743	1.2174	1.3375	1.2346	.7545
8	.1372		.1715	.1543	.2058	.2229	.1372
9	1.1488		.1715	.1886		.2058	1.1145
10	1.1145	.4287	.2058	.2058	.12	.1886	1.0288
11	1.166	.463	.1886	.2058	.12	.1886	1.0288
12	1.0974	.5487	.1715	.2058	.1029	.2229	1.0631
13		.9774	.1715		.1029	.1886	
14	1.046	1.1488	.1886		.0857	.2229	1.1317
15	1.0802	.8916	.1886		.1029	.2229	1.286
16	.9088	.9431	.1715		.0857	.2229	1.1145
17	.1543	.1677	.2058		.1886	.1067	.1372
18	.1543	.1677	.1715		.2743	.2134	.2058
19	.1543	.2915	.2229		.2401	.2401	.2915
20		.3086	.2572		.2915	.2743	.0343
21		.2572	.2401		.2572	.2572	.2743
22	.0514	.2058	.9431		.8573	.9602	
23	.0686	.1886	.8402		.9088	.8402	.2572
24	.0686	.0686	.1886	.7888		.8573	.2743
Max	1.166	1.1488	.9431	1.3203	1.3375	1.2346	1.286
Min	.0514	.0514	.1715	.1543	.0857	.1067	.0343
Avg	.4597	.3442	.2586	.6648	.4731	.4920	.6516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 202 / 11 KV Kumbharwadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2651	.5335	1.0288	.2439	.2915	.2915	.3086
2	1.2651	.503	.9431	.2286	.2915	.2915	.2915
3	1.2955	.5182	.9602	.2286	.2915	.2915	.3086
4	1.326	.5487	.9602	.2591	.3086	.3086	.3258
5	1.4175	.6097	1.046	.3353	.3429	.3429	.3429
6	1.4937	.9907	1.2174	.4115	.5316	.5144	.5144
7	1.7223	1.1431	1.326	.4268	.5144	.4973	.5316
8	.2896	.2743	.3201	.3048	.4287	.3429	.4115
9	.3258	.2743	1.3717	1.9719		1.6156	.3353
10	.3429	.2915	1.2041	2.0233	1.286	1.89	.2896
11	.3601	.2743	.5335	1.9204	2.1605	1.9814	.2896
12	.3601	.3258	.7164		1.2174	1.89	.3048
13		.3086	.9755		1.9376	1.8595	
14	.3258	.2915	1.4632		1.9719	1.768	.3201
15	.3086	.2915	1.7985		1.9719	1.7528	.3201
16	.3086	.2743	1.6309		2.0233	1.7375	.3353
17	.2591	.2896	.2896		.3086	.2401	.3201
18	.2591	.3048	.2896		.3772	.3353	.3963
19	.2743	.4115	.3963		.4287	.3944	.442
20	.2591	.4287	.381		.4458	.4287	.4572
21	.2743	.3772	.3506		.4458	.4287	.4115
22	.5487	1.046	.2896		.3429	.3429	1.5699
23	.5639	1.0288	.2743		.3086	.3086	1.448
24	1.2651	.5639	1.046	.2591		.2915	.2915
Max	1.7223	1.1431	1.7985	2.0233	2.1605	1.9814	1.5699
Min	.2591	.2743	.2743	.2286	.2915	.2401	.2896
Avg	.7004	.4960	.8672	.7178	.8285	.8394	.4594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 203 / 11 KV Birnal GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029		.1029	.0857	.1029	.12	.12
2	.0857	.0857	.12	.0686	.1029	.12	.12
3	.12	.0857	.1029	.0686	.1029	.12	.1029
4	.1372	.1029	.0857	.0857	.1029	.12	.1029
5	.1715	.12	.1029	.12	.1372	.12	.1029
6	.2058	.1543	.1543	.1886	.1886	.2058	.1715
7	.1886	.1715	.1886	.2401	.2058	.2058	.1886
8	.1715	.12	.1543	.1715	.1372	.1543	.1543
9	.1372	.1372	.1715	.1372		.1543	.1372
10	.1886	.0857	.1372	.1715	.12	.1886	
11	.1715	.0857	.1029	.1543	.1543	.1543	.1372
12	.1372	.1029	.1372	.1543	.1372	.12	.1543
13		.1543	.1543	.12	.1372	.1372	
14	.12	.1715	.12		.1372	.12	.1372
15	.12	.1029	.1372		.1029	.1029	.12
16	.12	.1543	.12		.1029	.1029	.12
17	.12	.1715	.1372		.1372	.0934	.12
18	.2058	.1524	.1715		.1886	.1677	.1715
19	.1715	.2401	.2401		.2572	.2058	.2229
20	.1372	.2401	.2572		.2915	.2572	.2401
21	.12	.2058	.2229		.2229	.2401	.1886
22	.1372	.1886	.1372		.1543	.1715	.1543
23	.1029	.1372	.12		.1543	.1543	.1372
24	.12	.1029	.12	.1029		.12	.12
Max	.2058	.2401	.2572	.2401	.2915	.2572	.2401
Min	.0857	.0857	.0857	.0686	.1029	.0934	.1029
Avg	.1431	.1423	.1458	.1335	.1536	.1523	.1465

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 204 / 11 KV Dhawadwadi GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0686	.0514	.0343	.0686	.0514	.0514
2	.0343	.0686	.0514	.0343	.0686	.0514	.0514
3	.0343	.0686	.0514	.0343	.0686	.0514	.0514
4	.0514	.0686	.0514	.0514	.0686	.0514	.0514
5	.0686	.0857	.0686	.0857	.0857	.0686	.0514
6	.1029	.12	.12	.12	.12	.1029	.1029
7	.1029	.0857	.0857	.12	.1029	.0686	.0686
8	.0514	.0514	.0686	.0686	.0514	.0229	.0514
9	.0686	.0171	.0514	.0686		.0343	.0686
10	.0686	.0171	.0686	.0343	.0686	.0343	
11	.0686	.0514	.0686	.0514	.0514	.0343	.0343
12	.0514	.0514	.0686	.1543	.0686	.0514	.0514
13		.0514	.0686	.0686	.0686	.0514	
14	.0514	.0343	.0686		.0686	.0457	.0514
15	.0514	.0514	.0686		.0514	.0514	.0514
16	.0514	.0514	.0686		.0686	.0514	.0514
17	.0857	.061	.0686		.0686	.061	.0514
18	.0857	.0457	.0857		.0857	.0762	.0686
19	.0857	.0857	.1372		.12	.1029	.1029
20	.0857	.0857	.12		.12	.1029	.1029
21	.0857	.0857	.1029		.0857	.0857	.1029
22	.0686	.0686	.0857	.0857	.0514	.0857	.0514
23	.0686	.0686	.0686	.0686	.0514	.0686	.0514
24	.0514	.0686	.0514	.0686	.0686	.0514	.0514
Max	.1029	.12	.1372	.1543	.12	.1029	.1029
Min	.0343	.0171	.0514	.0343	.0514	.0229	.0343
Avg	.0656	.0630	.0750	.0718	.0753	.0607	.0623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 205 / 11 KV Hivare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7926	.2896	.6173	.061	.1029	.1029	.1029
2	.7926	.2743	.6001	.061	.1029	.1029	.1029
3	.823	.3048	.5658	.061	.1029	.1029	.1029
4	.8535	.3353	.583	.0762	.1029	.1029	.1029
5	.945	.4268	.6001	.1067	.12	.12	.12
6	1.0517	.5487	.7545	.1524	.1715	.1715	.1543
7	1.1431	.8688	.9602	.1981	.2229	.2058	.2229
8	.1219	.0914	.0914	.1067	.1543	.1543	.1372
9	.1372		.9145	1.2003		1.2193	.1219
10	.1543		1.0364	1.3717	1.1488	1.4175	
11	.1543		1.1584	1.3375	1.5604	1.4022	.1524
12	.1543	.0343	1.1736		1.5775	1.3717	.1524
13		.0343	1.1888		1.5432	1.4327	
14	.1372	.0343	1.1279		1.5261	1.4022	.1372
15	.1372	.1029	1.1736		1.5261	1.3565	.1219
16	.1029	.1372	1.1431		1.3375	1.2955	.1219
17	.0914	.1219	.0914		.1372	.1219	.1524
18	.0762	.1067	.1067		.1715	.1524	.061
19	.0762	.1886	.1219		.1886	.1543	.1677
20	.0762	.1886	.1372		.2058	.1715	.1829
21	.0914	.1715	.1067		.1886	.1543	.1677
22	.2591	.703	.0914		.12	.12	.884
23	.2743	.6687	.0914		.1029	.1029	.8383
24	.7926	.3048	.6344	.0762		.1029	.1029
Max	1.1431	.8688	1.1888	1.3717	1.5775	1.4327	.884
Min	.0762	.0343	.0914	.061	.1029	.1029	.061
Avg	.4017	.2827	.6279	.4007	.5643	.5434	.2005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 206 / 11 KV Pratapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.061	.0857	1.2955	1.4746	1.6118	1.1145
2	.061	.061	.0857	1.2955	1.4746	1.5775	1.0974
3	.061	.061	.0857	1.326	1.4746	1.5604	1.0974
4	.0914	.061	.0857	1.3717	1.4918	1.5604	1.1145
5	.1067	.0762	.0857	1.4632	1.5604	1.5604	1.1488
6	.1219	.1067	.1372	1.5851	1.7833	1.8004	1.3032
7	.1372	.1067	.1372	1.6309	1.9376	1.9204	.8573
8	.1067	.0762	.0914	.1067	.0857	.0857	.0457
9	1.7661	1.2689	.0762	.0857		.0762	1.3413
10	1.989	1.4575	.0305	.0686	.0857	.0914	
11	2.0405	1.6289	.0305	.1029	.0857	.0762	1.3717
12	1.989	1.2346	.061		.1029	.0762	1.5242
13		1.6118	.0762		.1029	.0762	
14	1.9719	1.6804	.061		.0857	.1067	1.6004
15	1.8004	1.5432	.061		.1029	.0762	1.7223
16	1.5261	1.7147	.0914		.0686	.061	1.4784
17	.0762	.061	.0762		.0686	.0686	.0305
18	.0914	.061	.0914		.0857	.0762	.061
19	.0914	.1029	.1524		.1372	.1029	.1067
20	.0762	.1029	.1524		.1715	.1029	.1372
21	.0762	.12	.1372		.1372	.1372	.1219
22	.061	.0857	1.4175		1.7318	.6859	.1067
23	.061	.0857	1.3565		1.749	.8745	.0914
24	.0762	.061	.0857	1.2955	1.4918	1.6289	1.0802
Max	2.0405	1.7147	1.4175	1.6309	1.9376	1.9204	1.7223
Min	.061	.061	.0305	.0686	.0686	.061	.0305
Avg	.6278	.5596	.1980	.9689	.7604	.6664	.8433



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 201 / 11 KV JIRGYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1715	1.4089	1.5402	1.4091	1.1431
2	.1715	.1524	.1715	1.4089	1.5402	1.4091	1.1431
3	.1715	.1524	.1715	1.4089	1.5402	1.442	1.1431
4	.1905	.1715	.1715	1.4918	1.6057	1.4582	1.1288
5	.2477	.2286	.2667	1.8233	1.7869	1.4737	1.1728
6	.362	.381	.4191	2.4863	2.0873	2.1445	1.6324
7	.362	.3429	.3429	2.4034	2.2138	2.3158	1.7695
8	.2286	.2477	.2286	.1905	.2477	.2477	.2286
9	2.0481	1.8976	.1905	.1905	.1524	.1905	1.5971
10	2.13	1.9364	.1905	.1143	.1334	.1715	1.692
11	2.13	1.7497		.0953	.1524	.1334	1.6288
12	2.0481	1.8122	.1905	.1143	.1524	.1334	1.6288
13	1.8399	1.7966	.1143	.1334	.1334	.1334	1.5089
14	1.7404	1.7185	.0953	.1334	.1334	.1334	1.5242
15	1.9062	1.9134	.1143		.1524	.1143	1.5394
16	.3315	2.0399	.1905		.1524	.1524	1.7071
17	.0953	.1334	.1905		.1524	.1715	.1334
18	.1524	.1524	.1905		.1334	.1905	.1524
19	.2096	.2286			.2477	.2477	.2286
20	.2286	.2858	.2858		.3048	.2858	.3048
21	.1715	.2477	.1905		.2477	.2477	.2477
22	.1715	.2286	1.8233		1.7394	1.6288	.1905
23	.1524	.1905	1.5746		1.5708	1.3763	.1715
24	.1715	.1524	.1715	1.4089		1.4255	1.2037
Max	2.13	2.0399	1.8233	2.4863	2.2138	2.3158	1.7695
Min	.0953	.1334	.0953	.0953	.1334	.1143	.1334
Avg	.7263	.7630	.3389	.9875	.7878	.7765	1.0342

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 202 / 11 KV SHINGANAPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5468	.3277	.5079	.1905		.1715	.2096
2	.5468	.3315	.5079	.1905		.1715	.2096
3	.5468	.3315	.5079	.1905		.1715	.2096
4	.578	.3605	.5079	.1905		.1905	.2096
5	.6481	.4588	.4858	.1905		.2286	.2477
6	.8796	.6964	.6539	.2858		.2858	.3429
7	.8642	.8907	.8215	.381		.362	.3048
8	.1715	.2286	.1905	.2858		.1905	.2096
9	.1334	.2477	.6554	.8097		.8097	.1905
10	.1143	.1524	.7373	.7935		.8907	.1334
11	.0953	.1524	.6554	.7125		.8848	
12	.1715	.1524	.5735			.8029	
13	.1524	.1905	.5735			.8029	
14	.1334	.1905	.4915		.5407	.8192	.1715
15	.1143	.1524	.5735		.8192	.8192	.1715
16	.0953	.1905	.6554		.8192	.9892	.1905
17	.1143	.1524	.1905		.1334	.1715	.1905
18	.1334	.1524	.1905		.0953	.1524	.2096
19		.2286			.2286	.2477	.3048
20		.2858	.2858		.2477	.3239	.3048
21		.2667	.2858		.2477	.2858	.3429
22	.3605	.5256	.1905		.2096	.2286	.6636
23	.3887	.3605	.1905		.1905	.2096	.5401
24	.5468	.3441	.5079	.1905		.1715	.2096
Max	.8796	.8907	.8215	.8097	.8192	.9892	.6636
Min	.0953	.1524	.1905	.1905	.0953	.1524	.1334
Avg	.3493	.3071	.4757	.3676	.3532	.4326	.2651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 203 / 11 KV JIRGYAL GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0953	.0953	.0953	.0762	.0762
2	.0953	.0762	.0953	.0953	.0953	.0762	.0762
3	.0953	.0762	.0953	.0953	.0953	.0762	.0762
4	.0953	.0953	.0953	.0953	.0953	.0762	.0762
5	.1143	.0953	.0953	.1334	.1143	.0953	.0953
6	.1524	.1143	.1334	.1334	.1143	.1143	.1143
7	.1143	.1143	.1143	.1905	.1524	.0762	.0953
8	.1143	.0953	.0953	.0953	.0762	.0572	.0762
9	.0572	.0953	.0762	.0762	.0572	.0572	.0572
10	.0572	.0762	.0572	.0381	.0381	.0572	.0572
11	.0572	.0762	.0572	.0572	.0381	.0381	.0381
12	.0953	.0762	.0953	.0762	.0572	.0572	.0572
13	.0762	.0762	.0953	.0762	.0762	.0381	.0762
14	.0381	.0572	.0572	.0381	.0572	.0381	.0381
15	.0381	.0572	.0572		.0381	.0191	.0381
16	.0381	.0572	.0953		.0381	.0381	.0572
17	.0572	.1143	.0953		.0572	.0572	.0762
18	.0953	.0953	.1334		.0953	.0953	.1143
19	.0572	.1715			.1334	.1334	.1715
20	.0953	.1334	.1524		.1334	.1715	.1905
21	.1143	.1524	.1524		.1334	.1334	.0762
22	.0953	.1334	.1143		.1143	.0953	.0953
23	.0762	.0953	.1905		.0762	.0762	.0762
24	.0953	.0762	.0953	.0953		.0762	.0762
Max	.1524	.1715	.1905	.1905	.1524	.1715	.1905
Min	.0381	.0572	.0572	.0381	.0381	.0191	.0381
Avg	.0842	.0953	.1019	.0927	.0862	.0762	.0826

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 204 / 11 KV EKUNDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.3605	.3637	.2858	.2667	.2667	.2858
2	.4096	.3605	.3637	.2858	.2667	.2667	.2667
3	.4096	.3768	.3637	.2858	.2667	.2858	.2667
4	.4096	.4096	.3953	.2858	.2858	.3239	.3239
5	.506	.4696	.4915	.2858	.3429	.4001	.4001
6	.7116	.7125	.639	.4763	.4954	.4382	.4572
7	.7432	.8097	.6706	.4763	.4763	.4763	.4763
8	.362	.3048	.3429	.381	.4001	.3239	.362
9	.3048	.2286	.4973	.663	.4858	.6958	.3048
10	.2096	.1715	.5801	.5801	.6478	.5487	.2286
11	.1334	.1524	.4973	.5636	.5898	.5335	.1524
12	.0953	.1334	.4973		.5243	.4816	.1524
13	.1143	.0953	.4144		.4641	.4371	.1524
14	.1143	.1334	.4144		.4424	.4915	.1334
15	.0953	.1143	.4973		.426	.5407	.1524
16	.0762	.1334	.4973		.5407	.6642	.1715
17	.1715	.1715	.1905		.1715	.1524	.1524
18	.2477	.2096	.1905		.2477	.1715	.1715
19	.2858	.362			.3429	.3239	.3429
20	.2858	.4001	.2858		.381	.4001	.381
21	.2477	.362	.2858		.3239	.3048	.3048
22	.4858	.5506	.2858		.2858	.2667	.6718
23	.3887	.4321	.2477		.2858	.2858	.5243
24	.4096	.3768	.3795	.4763		.2667	.2667
Max	.7432	.8097	.6706	.663	.6478	.6958	.6718
Min	.0762	.0953	.1905	.2858	.1715	.1524	.1334
Avg	.3178	.3263	.4083	.4205	.3896	.3894	.2959

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 201 / 11 KV TIPPEHALLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.0857
2	.1029	.0857	.8916
3	.1029	.1029	.0857
4	.1029	.1029	.0857
5	.1372	.12	.9259
6	.2229	.1715	1.3717
7	.2058	.2058	1.3375
8	1.8861	.2058	.1543
9	1.3203	.1372	.1715
10		.12	.1715
11	1.6118	.1029	.1715
12	1.4575	.12	.1715
13		.1029	.1372
14	1.4232	.12	
15	.2572	.1029	.1372
16	1.1488	.1372	.1372
17	.12	.1543	.1886
18	.1372	.1372	.1543
19	.1543	.1543	.1543
20	.1543	.2058	.2058
21	.1543	1.1317	
22	.0686		.2915
23	.0857	1.0631	.9088
24	1.5604	.0857	.9602
Max	1.8861	1.1317	1.3717
Min	.0686	.0857	.0857
Avg	.5690	.2155	.4045

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.12	.2743	.2572
2	.1372	.2743	.2401
3	.1029	.2401	.1886
4	.1715	.2401	.2229
5	.1029	.2058	.2572
6	.1029	.2229	.2401
7	.1029	.2572	.2401
8	.1029	.2572	.1886
9	.12	.2058	.1543
10	.2058	.3429	.1715
11	.2058	.3944	
12	.2572	.4115	1.5089
13	.2058	.3601	.2229
14	.1543	.2572	.1715
15	.3258	.2743	.1372
16	.1543	.2229	.1029
17	.2229	.2572	.1029
18	.2572	.2572	.0857
19	.12	.3258	.1029
20	.3429	.3429	.1886
21	.3601	.3601	.2058
22	.2572	.4287	.2058
23	.2572	.3429	
24	.2229	.3258	.3258
Max	.3601	.4287	1.5089
Min	.1029	.2058	.0857
Avg	.1922	.2951	.2510

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 203 / 11 KV MALLAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1543	.8745
2		.1543	.5144
3		.1543	1.406
4		.1715	
5		.1886	1.4746
6		.2058	2.3148
7		.2229	2.572
8		.1715	2.572
9		.1372	.1543
10		.1543	.1543
11		.1372	.1543
12		.1372	.1372
13		.1372	.1372
14		.1543	.1543
15		.1543	.1715
16		.1372	.1543
17		.1886	.1715
18		.1372	.1715
19		.2058	.2058
20		.2401	.2229
21		.2058	.2229
22		2.0405	1.9376
23		1.8176	1.6118
24	1.3717	.1715	.9774
Max	1.3717	2.0405	2.572
Min	1.3717	.1372	.1372
Avg	1.3717	.3158	.8029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 204 / 11 KV Jath

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5604	1.6289
2			1.5261	1.6118
3			1.6461	1.5432
4			1.7833	1.5947
5			1.5947	1.6118
6			1.8519	1.7661
7			.1886	1.8347
8			1.6632	1.7661
9			1.406	1.5261
10		1.5604	1.5261	1.5089
11		1.5604	1.5604	.4115
12		1.4918	1.5604	.2229
13		1.5947	1.6975	.1886
14		1.5947	1.6975	1.749
15		1.6289	1.8004	1.749
16		1.6461	1.8176	1.6461
17		1.7147		1.6289
18		1.6804	1.8347	1.8347
19		2.1434	2.2119	
20		2.1776	2.2977	
21		2.0405	2.1948	
22		2.1434	2.0405	
23		1.7147	1.9547	
24	.8573		1.6632	
Max	.8573	2.1776	2.2977	1.8347
Min	.8573	1.4918	.1886	.1886
Avg	.8573	1.7637	1.6990	1.4346



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 205 / 11 KV Rampur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1317	1.3032	.1543	.1543
2		1.0288	1.2689	.1543	.1372
3		1.0631	1.2346	.1715	.1372
4		1.2003	1.2346	.1715	.1543
5		1.3717	1.2689	.1715	.1715
6		1.869	1.5604	.2058	.1715
7		2.0576	1.8861	.1886	.1715
8		2.0576	1.8861	.2229	.1543
9		.1543	1.8519	1.7318	1.2517
10		.1029	2.2119	1.9033	2.2977
11		.1029	2.0405	1.9033	.6516
12		.1029	2.0233	1.9033	2.3148
13		.12	1.869	1.9033	2.1605
14		.12	1.6975	1.9033	
15		.12	1.7833	1.9033	2.1434
16		.12	1.8861	2.1091	
17		.1372	1.8861	.1543	
18		.1372		.1543	
19		.1543	.2229	.1543	
20		.1886	.2058	.1886	
21		.2058	.2229	.1715	
22		1.4746	.1886	.1715	
23		1.3717		.1543	
24	1.3717	1.0631	1.3032	.1543	.12
Max	1.3717	2.0576	2.2119	2.1091	2.3148
Min	1.3717	.1029	.1886	.1543	.12
Avg	1.3717	.7273	1.4107	.7502	.8128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 206 / 11 KV Achakanhalli AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0857	.9088
2		.0857	.0857	.8573
3		.0857	.0857	.7888
4		.0857	.0857	.9088
5		.0857	.0857	.9602
6		.0857	.0857	1.9204
7		.0857	.0857	.5487
8		.0857	.0857	.5487
9		.0857	.0857	.0857
10		.0857	.0857	.0857
11		1.3546		.0857
12		1.6632	.0857	.0857
13		1.5775	.0857	.0857
14		1.4403	.0857	.0857
15		1.5604	.0857	.0857
16		.0857	.0857	.0857
17		.0857	.0857	.0857
18		.0857	.0857	.0857
19		.0857	.0857	.0857
20		.0857	.0857	.0857
21		.0857	.0857	
22		.0857	1.0974	.0857
23			.9602	.0857
24	1.3717	.0857	.0857	.9259
Max	1.3717	1.6632	1.0974	1.9204
Min	1.3717	.0857	.0857	.0857
Avg	1.3717	.3973	.1677	.4160

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 207 / 11 KV SUGAR FACTORY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0857	.0857
2		.0857	.0857	.0857
3		.0857	.0857	.0857
4		.0857	.0857	.0857
5		.0857	.0857	.0857
6		.0857	.0857	.0857
7		.0857	.0857	.0857
8		.0857	.0857	.0857
9		.0857	.0857	.0857
10		.0857	.0857	.0857
11		.0857	.0857	.0857
12		.0857	.0857	.0857
13		.0857	.0857	.0857
14		.0857	.0857	.0857
15		.0857	.0857	.0857
16		.0857	.0857	.0857
17		.0857	.0857	.0857
18		.0857	.0857	.0857
19		.0857	.0857	.0857
20		.0857	.0857	.0857
21		.0857	.0857	.0857
22		.0857	.0857	.0857
23		.0857	.0857	.0857
24	.1086	.0857	.0857	.0857
Max	.1086	.0857	.0857	.0857
Min	.1086	.0857	.0857	.0857
Avg	.1086	.0857	.0857	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 208 / 11 kv Achakanhallii Gav  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857
2	.0857	.0857	.0857
3	.0857	.0857	.0857
4	.0857	.0857	.0857
5	.0857	.0857	.0857
6	.0857	.0857	.0857
7	.0857	.0857	.0857
8	.0857		.0857
9	.0857		.0857
10	.0857		.0857
11	.0857		.0857
12	.0857		.0857
13	.0857		.0857
14	.0857		.0857
15	.0857		
16	.0857		.0857
17	.0857		.0857
18	.0857		.0857
19	.0857		.0857
20	.0857		
21	.0857		.0857
22	.0857		.0857
23	.0857	.0857	.0857
24	.0857	.0857	.0857
Max	.0857	.0857	.0857
Min	.0857	.0857	.0857
Avg	.0857	.0857	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 201 / 11kv k mahankal

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0166	.9145	1.0059	1.0456	.9709	.9709	1.1203
2	1.0608	.9145	1.0059	1.0082	.9335	.9709	1.0829
3	1.0974	.8779	.9694	.9896	.8775	1.0082	1.0269
4	1.0791	.9511	1.0242	.9896	.9335	.9709	.9896
5	1.0985	.9511	1.0608	1.0082	.9896	1.0829	1.0456
6	1.2071	.9877	1.1706	1.0269	1.0456	1.1203	1.0829
7	1.0791	.9877	1.1157	1.0829	1.0974	1.0456	1.0642
8	.8962		.9511	.9709	.9694	.8589	.9522
9	.9328	1.1157	.8779	1.0082	.9694	.9149	.8962
10	1.0791	1.0974	1.0059		1.0242	1.1576	1.0456
11	1.1523	1.0608	.9877		1.0317	1.1949	1.1016
12	1.134	.9877	1.0059		1.086	1.1949	1.1203
13	1.0974	.9694	1.0059		1.0974	1.1576	1.0829
14	1.0791	.9328	1.0791		1.0791	1.0829	1.1203
15	1.0791	.8962	1.1706		1.0608	1.1203	1.0829
16	1.0974	.8413	1.0608		1.0608	1.0269	1.0829
17		.8413	1.0608		1.0791	1.1203	1.0456
18		.9328	1.1706		1.134	1.1016	1.0456
19		1.2437	1.4083		1.3535	1.419	1.4937
20	1.2803	1.3717	1.4449		1.3169	1.4937	1.4937
21	1.262	1.3717	1.3535		1.3169	1.419	1.419
22	1.1523	1.262	1.1706		1.2071	1.307	1.307
23	1.0059	1.1523	1.1157		1.0349	1.2323	1.1389
24	1.0517	.9694	1.0608	1.0829	1.0082	1.0082	1.1763
Max	1.2803	1.3717	1.4449	1.0829	1.3535	1.4937	1.4937
Min	.8962	.8413	.8779	.9709	.8775	.8589	.8962
Avg	1.0923	1.0274	1.0951	1.0213	1.0699	1.1242	1.1257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 202 / 11KV KUCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1578	.1227	1.6827	1.7177	2.2085	1.9105
2	.1867	.1402	.1227	1.6651	1.7177	2.2436	1.8755
3	.2054	.1402	.1052	1.6301	1.6651	2.1971	1.9281
4	.1886	.1578	.1402	1.6827	1.8755	2.2325	1.9631
5	.2054	.1578	.1753	1.7353	1.9631	2.2148	2.0157
6	.2218	.1928	.2103	1.858	2.1033	2.2611	2.1033
7	.1848	.1928	.2103	2.1735	2.226	2.3137	2.191
8	.2218		.1578	.1753	.2103	.1402	.1753
9	2.6797	.1928	.1753	.1753	.1578	.1402	2.552
10	2.6612	.1578	.1578		.1578	.1402	2.5415
11	2.7166	.1227	.1753		.1578	.1578	2.822
12	2.3655	.2103	.1402		.0526	.1753	2.8045
13	2.4025	.1578	.1578		.1578	.1753	2.7168
14	2.5503	2.2786	.1753		.1402	.1578	2.7168
15	2.6612	2.0858	.1227		.1402	.1753	2.5065
16		1.7177	.1578		.1753	.1753	2.6292
17	2.7721	.1227	.1753		.2103	.1578	.1928
18		.1402	.1753		.2103	.1753	.2279
19		.1753	.2103		.2279	.2279	.2103
20		.2279	.2454		.2103	.2804	.2279
21	.1848	.1928	.2454		.2279	.2629	.2454
22	.1753	.1928	1.9456		2.2436	2.2436	.2279
23	.1753	.1402	1.7528		2.1384	1.9806	.2103
24	.1848	.1578	.1402	1.7177	1.7528	2.1735	1.9456
Max	2.7721	2.2786	1.9456	2.1735	2.2436	2.3137	2.822
Min	.1753	.1227	.1052	.1753	.0526	.1402	.1753
Avg	1.1564	.4092	.3082	1.4496	.9100	1.0254	1.6225

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 203 / 11 KV HINGANGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3211	.3856	1.5775	.3856	.4207	.3856	.4251
2	2.268	.3856	1.5775	.3506	.4207	.3856	.4251
3	2.3034	.3506	1.5424	.3506	.3856	.4207	.4066
4	2.3388	.4031	1.4899	.3681	.4207	.3856	.462
5	2.3034	.4207	1.4899	.4382	.4382	.4557	.499
6	2.4983	.4557	1.4723	.4908	.4733	.4908	.5175
7		.4557	1.6126	.4733	.5434	.4733	.5175
8	.4252		.3856	.4908	.4908	.4557	.5729
9	.4382	.4207	2.1384	2.6292	2.4539	3.1725	.499
10	.4207	.4382	2.191		2.3137	3.4004	.5175
11	.4557	.4031	2.3838		.929	3.2427	.4805
12	.4733	.4733	2.1209		3.0849	2.8395	.499
13	.4557	.4031	2.1735		3.12	2.6292	.462
14	.4733	.4031	2.2786		3.155	2.7694	.4251
15	.4733	.3856	2.4013		3.1725	2.8045	.4435
16	.4733	.4382	2.3487		2.857	2.822	.4251
17		1.0341	.4031		.4382	.4031	.499
18		.4207	.4382		.4733	.4382	.499
19		.4382	.4908		.5083	.4733	.5544
20		.4908	.5083		.5258	.5258	.5914
21	.4031	.4908	.5083		.5258	.5359	.5729
22	.3856	1.6651	.4557		.4557	.4805	2.5503
23	.4031	1.6126	.4382		.4382	.4805	2.2177
24	2.3137	.3856	1.6126	.4031	.4557	.4207	.462
Max	2.4983	1.6651	2.4013	2.6292	3.1725	3.4004	2.5503
Min	.3856	.3506	.3856	.3506	.3856	.3856	.4066
Avg	1.1383	.5548	1.4183	.6380	1.1875	1.2871	.6468

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 204 / 11KV Ranjani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.1478	.2402	1.3306	1.3676	1.2197	1.3717
2	.2402	.1294	.2218	1.2936	1.3306	1.2323	1.3352
3	.2402	.1294	.1848	1.2936	1.4415	1.1949	1.4266
4	.2218	.1663	.2587	1.4415	1.848	1.2012	1.4998
5	.2957	.2218	.3142	1.7002	1.9589	1.6448	1.6095
6	.4066	.3696	.3696	1.9035	2.1992	2.1992	1.7375
7	.2957	.3696	.2587	2.3101	2.2731	2.1807	1.6827
8	.2614		.2033	.2402	.2033	.1829	.2743
9	2.3101	.2402	.2033	.2033	.1478	.1646	1.6461
10	2.5688	.1663	.1663		.1663	.1829	2.1216
11	2.4579	.1848	.1478		.1663	.1646	2.2862
12	2.3285	.1848	.1478		.1663	.1646	2.1948
13	2.2177	.2033	.1848		.1848	.2012	2.1033
14	2.1807	2.2916	.1848		.1829	.1829	2.0485
15	1.9959	2.3101	.2218		.128	.2195	2.2314
16	1.7002	1.848	.2218		.1829	.2012	2.2131
17		.2587	.2033		.2195	.2195	.2012
18		.2218	.2772		.2743	.2926	.2378
19		.3326	.3326		.3142	.4024	.3475
20		.4435	.3511		.3326	.3658	.3658
21	.2218	.4435	.3326		.3696	.3475	.3292
22	.1848	.3326	1.7372		1.7372	1.5546	.2561
23	.1848	.2957	1.386		1.2197	1.4083	.2378
24	1.0059	.1663	.2587	1.3491	1.386	1.1827	1.3717
Max	2.5688	2.3101	1.7372	2.3101	2.2731	2.1992	2.2862
Min	.1848	.1294	.1478	.2033	.128	.1646	.2012
Avg	1.0789	.4982	.3504	1.3066	.8250	.7629	1.2971



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 205 / 11KV Langerpeth Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9938	.112	2.2779	.1494	.1646	.1848	.1646
2	2.9938	.112	2.2405	.1307	.1646	.1663	.1646
3	3.0678	.0934	2.2032	.1307	.1463	.1646	.1463
4	3.0247	.1307	2.2405	.168	.2195	.1646	.2195
5	3.2114	.2054	2.2592	.2054	.2561	.2218	.2561
6	3.4743	.3361	2.2592	.2614	.2926	.2743	.2926
7	3.1971	.3361	2.4086	.2614	.2926	.2378	.2743
8	.1867		.1867	.1867	.2012	.1829	.2012
9	.1494	.168	2.2779	2.8753	3.4751	3.3471	.1646
10	.168	.168	2.782		3.53	3.5665	.1646
11	.1867	.168	2.8193		3.5665	3.5117	.1646
12	.1867	.1307	2.8006		3.3288	3.4202	.1646
13	.1867	.112	2.5206			3.3288	.1463
14	.168	.1867	2.2032		3.5117	3.2922	.128
15	.168	.1307	2.0538		2.1399	3.3653	.1463
16	.1494	.1867	2.3712		.2012	3.2556	.1829
17		1.4003	.168		.2012	.1646	.1829
18		.2241	.2054		.2402	.1829	.2561
19		.2801	.3174		.2926	.2926	.3109
20	.168	.2987	.2987		.2743	.3109	.2926
21	.168	.2987	.2614		.2378	.2378	.2926
22	.1494	2.4086	.2054		.2195	.2012	3.658
23	.1307	2.3152	.1867		.1829	.2012	3.3836
24	3.0308	.1307	2.2779	.168	.1829	.1829	.1829
Max	3.4743	2.4086	2.8193	2.8753	3.5665	3.5665	3.658
Min	.1307	.0934	.168	.1307	.1463	.1646	.128
Avg	1.2933	.4319	1.6594	.4537	1.0140	1.2691	.4809

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 206 / 11KV S.Factory Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2054	.2054	2.5415	2.9797	2.6642	2.6467
2	.2987	.1867	.1867	2.5065	2.9447	2.6993	2.5941
3	.3174	.1867	.168	2.4539	2.8921	2.6642	2.5941
4	.3109	.2427	.2427	2.4539	2.857	2.7343	2.5591
5	.3292	.3174	.2801	2.6467	2.8921	2.6818	2.6292
6	.4108	.3361	.3361	2.9447	2.9797	2.7343	2.6642
7	.3734	.3361	.3174	2.9622	2.4188	3.1375	2.7343
8	.3547		.2241	.3506	.298	.333	.2629
9	3.5288	.2054	.2241	.3506	.2454	.3856	3.2427
10	3.4355	.3174	.2054		.3155	.298	3.6107
11	3.3608	.2987	.1307		.3506	.3155	3.4004
12	3.5475	.3174	.168		.298	.333	3.4004
13	3.4541	.2801	.1578		.3155	.2629	3.3303
14	3.3234	3.0247	.1578		.3155	.2804	3.2251
15	3.0434	3.3608	.1753		.3506	.3155	.9991
16	3.006	3.062	.1928		.298	.3506	2.9096
17		.2054	.1753		.3506	.4031	.2804
18		.2987	.1227		.3681	.3856	.3506
19		.2801	.298		.4031	.4733	.4481
20	.2614	.3547	.3155		.3856	.5258	.4557
21	.2801	.3547	.298		.3856	.4382	.4382
22	.2427	.2987	2.489		3.1375	2.7694	.3506
23	.2427	.2427	2.6116		2.6467	2.7343	.3155
24	.3109	.2241	.2241	2.5766	2.9973	2.6116	2.6818
Max	3.5475	3.3608	2.6116	2.9622	3.1375	3.1375	3.6107
Min	.2427	.1867	.1227	.3506	.2454	.2629	.2629
Avg	1.4631	.6494	.4128	2.1787	1.3927	1.3555	2.0052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 207 / 11 KV Express MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.0526	.0526	.0701	.0526	.0701	.0701
2	.0876	.0526	.0526	.0701	.0526	.0701	.0701
3	.0886	.0526	.0526	.0701	.0351	.0876	.0526
4	.0709	.0526	.0351	.0701	.0351	.0701	.0526
5	.0701	.0526	.0351	.0701	.0351	.0701	.0526
6	.0709	.0351	.0701	.0701	.0351	.0701	.0701
7	.0701	.0351	.0701	.0526	.0526	.0701	.0701
8	.0876		.0526	.0876	.0526	.0701	.0876
9	.0876	.0876	.0701	.0701	.0526	.0876	.0876
10	.1578	.0876	.1578		.0701	.0876	.1227
11	.1753	.1402	.1052		.1052	.1402	.1052
12	.1227	.1052	.1227		.1052	.1402	.1052
13	.1052	.0876	.1052		.1227	.1052	.0876
14	.0876	.0526	.0701		.1227	.0701	.0701
15	.0876	.0526	.0701		.0876	.0701	.0526
16	.1227	.0526	.0876		.0526	.0701	.0701
17		.0526	.0526		.0526	.0526	.0526
18		.0526	.0526		.0526	.0526	.0351
19		.0701	.0701		.0351	.0701	.0526
20	.0701	.0701	.0701		.0701	.0701	.0701
21	.0526	.0701	.0701		.0876	.0701	.0701
22	.0701	.1052	.1052		.1227	.1052	.1227
23	.0526	.0876	.1052		.1052	.0876	.0876
24	.1052	.0526	.0876	.0876	.0701	.0876	.0876
Max	.1753	.1402	.1578	.0876	.1227	.1402	.1227
Min	.0526	.0351	.0351	.0526	.0351	.0526	.0351
Avg	.0928	.0678	.0760	.0719	.0694	.0811	.0752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 208 / 11KV Langerpeth Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.298		.3155	.2629	.2103	.2804	.2103
2	.2804		.2804	.2454	.1928	.2629	.2103
3	.2804		.2279	.2454	.2279	.2629	.1753
4	.2835		.3155	.2804	.2629	.2454	.2454
5	.3189		.3506	.3155	.3155	.3155	.2804
6	.3856		.3856	.3506	.3681	.3856	.333
7	.4031		.3856	.3856	.3856	.3506	.333
8	.298		.298	.298	.2629	.2103	.2629
9	.298		.3734	.333	.2629	.2454	.298
10	.3155		.1402		.2629	.2279	.3155
11	.298	.1227	.1578		.2629	.2804	.333
12	.2103	.2103	.1578		.2658	.2629	.2804
13	.1928	.1578	.1578		.1949	.2454	.2454
14	.1753	.1928	.2454		.1928	.2103	.1928
15	.1753	.2103	.2279		.1928	.1753	.1928
16	.1402	.1052	.1928		.1753	.1928	.2103
17		.2629	.2279		.298	.1753	.1928
18		.3506	.2454		.3155	.2804	.298
19		.4733	.4207		.4382	.3856	.4207
20		.5609	.4382		.4031	.4207	.4733
21		.5258	.4382		.4382	.4382	.4382
22		.4557	.4207		.4031	.3681	.4207
23		.3506	.333		.3155	.2804	.3506
24	.298		.3155	.298	.3155	.2804	.2454
Max	.4031	.5609	.4382	.3856	.4382	.4382	.4733
Min	.1402	.1052	.1402	.2454	.1753	.1753	.1753
Avg	.2736	.3061	.2938	.3015	.2901	.2826	.2899

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 202 / 11KV Shirdhon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1213	1.7802	1.9894	.3953	.3071	.4656	.3845
2	4.1126	.8383	1.9827	.3677	.3071	.416	.3674
3	3.9674	1.6706	1.9471	.3934	.3033	.4229	.3982
4	3.924	2.2666	1.9319	.4054	.3418	.4657	.3811
5	3.9971	.9313	1.9753	.4214	.3486	.4862	.3856
6	4.4483	1.9262	2.292	.4473	.3906	.5491	.4611
7	5.4291	2.447	2.9718	.4538	.2484	.5906	.5927
8	.3677	.1821	.3813	.5764	.687	.6562	.6093
9	.3731		.0015	5.6181	6.7935	6.6141	.5331
10	.3963		2.2604	6.3892	6.182	6.134	.57
11	.4077		2.7092	5.8842	2.3739	5.8215	.4923
12	.3719			1.2559	5.897	5.2126	.5762
13	.4398		3.7319	.3948	5.1416	6.2384	.4135
14	.4652	.3799	5.5133	.5871	5.6501	5.1357	.4553
15	.5708	.4168	3.091	.5216	3.4309	6.198	.5167
16	.3216	.4138	4.4795	3.7635	6.5158	6.419	.5753
17	.3246	.3792	.4389	.2035	.439	.3529	.5891
18		.4511	.4157	.359	.5311	.4262	.5723
19		.5474	.4912	.4679	.5829	.5075	.5716
20	.2058	.527	.5434	.5272	.6809	.6104	.5846
21	.2378	.5765	.532	.5317	.6325	.5927	2.8426
22	.7865	3.014	.4626	.3894	.5575	.5331	2.5629
23	1.7303	3.1642	.4451	.3307	.4808	.4195	2.6223
24	2.9401	2.037	1.2488	.3581	.4153	.4424	2.7046
Max	5.4291	3.1642	5.5133	6.3892	6.7935	6.6141	2.8426
Min	.2058	.1821	.0015	.2035	.2484	.3529	.3674
Avg	1.8154	1.2605	1.8190	1.2934	2.0516	2.3213	.8651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 203 / 11KV Borgaon Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3679	.3506	.3263	.3391	.3814	.3784	.3512
2	.3468	.1882	.324	.3157	.3776	.3346	.3458
3	.346	.3368	.3399	.3141	.3768	.3315	.3247
4	.3445	.3361	.3218	.3353	.3791	.3512	.305
5	.3733	.3799	.3233	.3573	.4275	.3704	.3141
6	.4656	.4942	.4027	.4201	.4694	.4316	.3862
7	.4203	.4748	.4084	.4115	.2462	.4146	.3921
8	.3392	.2469	.3288	.3586	.343	.3753	.3075
9	.386		.3544	.3822	.3308	.3623	.341
10	.4148		.3891	.3795	.3843	.341	.3814
11	.3768		.3696	.4321	.202	.4306	.4078
12	.4058		.3874	.4588	.3944	.419	.4504
13	.486		.4047	.2347	.3989	.4094	.4352
14	.451	.5013	.3725	.2378	.3664	.3296	.4314
15	.3913	.4809	.3772	.2233	.3535	.3665	.4152
16	.1829	.4079	.3841	.2309	.3494	.3456	.192
17	.1981	.3637	.3327	.1898	.4374	.3452	.373
18	.2317	.3563	.4462	.1989	.4815	.367	.3814
19	.2599	.2446	.4482	.2256	.5756	.4474	.4127
20	.2743	.631	.602	.3079	.6576	.6493	.5464
21	.2713	.6289	.559	.3102	.6093	.6086	.5182
22	.2606	.4915	.5678	.2637	.5416	.4751	.2606
23	.4271	.422	.4415	.2362	.4648	.3916	.202
24	.6223	.3567	.3294	.3702	.3875	.3995	.3329
Max	.6223	.631	.602	.4588	.6576	.6493	.5464
Min	.1829	.1882	.3218	.1898	.202	.3296	.192
Avg	.3601	.4049	.3975	.3139	.414	.4031	.3670

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 204 / 11KV Borgaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5351	2.9319	3.6565	.4747	.5506	.5293	.6097
2	4.4307	1.3306	3.4427	.4664	.5491	.4636	.5929
3	4.3119	2.778	3.2596	.4784	.527	.462	.5618
4	4.2913	2.5783	3.158	.5161	.5412	.4755	.5656
5	4.3805	2.6355	3.174	.5518	.5868	.5601	.6074
6	4.8293	1.6312	3.4896	.6436	.6287	.4725	.7771
7	5.6851	3.9175	3.8287	.5809	.3338	.628	.7849
8	.5759	.253	.3837	.6753	.6165	.6726	.7666
9	.6973		5.2397	6.9307	6.4655	6.1387	.8981
10	.711		5.6545	4.3354	6.813	6.5057	.9267
11	.7339		6.0586	6.6168	3.4027	7.0542	.8697
12	.7065		6.0129	3.4354	7.1944	7.22	.8433
13	.7251		5.5292	.2484	6.9315	7.395	.8357
14	.8025	.644	5.7567	.2736	7.1689	7.6677	.8347
15	.7171	.6413	6.0968	.2827	7.4081	7.1223	.8402
16	.3711	.5956	6.0228	2.8883	6.33	7.2647	.8143
17	.3003	.642	.5914	.3018	.6291	.6535	.8589
18	.2652	.7281	.5449	.3521	.6493	.7686	.8741
19	.2553	.3338	.6112	.3178	.7975	.8072	.9976
20	.2904	.5712	.7392	.3612	.881	.8459	.9907
21	.2873	.6154	.7296	.3567	.8297	.7857	4.0909
22	1.6369	3.8731	.644	.3536	.7539	.7433	3.2053
23	3.0581	3.8966	.5522	.3086	.6493	.6681	3.3638
24	3.8699	3.2885	2.0317	.301	.5423	.6007	3.4896
Max	5.6851	3.9175	6.0968	6.9307	7.4081	7.6677	4.0909
Min	.2553	.253	.3837	.2484	.3338	.462	.5618
Avg	2.0195	1.7835	3.2170	1.3355	2.5742	2.7710	1.2500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 205 / 11KV Shivganga Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3761	.0554	.3366	.3721	.153	.3582	.1943
2	.3582		.3189	.3224		.1753	.2743
3	.362	.0549	.3366	.3582	.153	.1753	.2328
4	.3801	.0549	.3366	.3801	.1391	.1696	.2686
5	.3841	.0549	.3366	.3761	.1391	.1696	.2865
6	.4024	.0549	.3582	.3544	.1391	.1562	.3109
7	.1886	.0532	.3467	.1337		.1526	.3641
8	.1355		.1204	.1492	.1174	.116	.1658
9	.141		.1124	.1158	.1509	.1162	.1753
10	.1677		.2006	.1406	.1269	.1174	.1372
11	.1677		.2286	.1183		.1875	.1943
12	.1677		.2006	.128	.204	.192	.2347
13	.2012		.1286		.1739	.1303	.2347
14	.2012	.2629	.1437		.2229	.1593	.2347
15	.1619	.2804	.1875		.2743	.1852	.1829
16		.2315	.153		.2229	.1543	.1829
17		.2534	.1966		.1932	.2031	.1629
18		.181	.1217		.1353	.1012	.1629
19		.1991	.2896		.2452	.1475	.2218
20		.439	.4572		.4435	.2378	.2801
21		.2926	.4207		.415	.3696	.3547
22		.362	.4163		.1109	.3982	.3292
23		.1718	.394		.4163	.3982	
24	.3366	.0554	.3366	.4075	.153	.4119	.176
Max	.4024	.439	.4572	.4075	.4435	.4119	.3641
Min	.1355	.0532	.1124	.1158	.1109	.1012	.1372
Avg	.2583	.1798	.2699	.2582	.2061	.2076	.2331



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 206 / 11KV Shirdhon Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054		.2218	.2218	.1494	.2033	.2218
2	.1867		.2427	.1829	.1494	.1848	.2054
3	.1886		.2241	.2149	.1494	.1848	.1867
4	.1886		.2103	.2561	.1494	.2054	.2054
5	.2075		.1867	.2561	.1867	.2241	.2054
6	.2641		.2614	.2772	.2054	.2427	.2561
7	.2561		.2328	.2561		.2195	.2481
8	.2254		.2279	.2347	.1734	.2035	.1509
9	.2374		.1886	.1907	.1509	.2103	.2058
10	.1509		.2155	.1677	.2229	.2058	.1823
11	.1509		.1781	.2012		.2229	.1865
12	.1509			.1823	.218	.2254	.1865
13	.2012		.2572		.2347	.2427	.1865
14	.218	.3258	.2454		.2254	.2481	.1865
15	.2035	.2713	.2454		.2427	.2481	.1715
16		.2515	.2279		.2507	.2629	.1715
17		.2622	.2058		.208	.2743	.1357
18		.2743	.208		.2229	.2254	.1187
19		.3012	.3403		.3658	.3045	.1734
20		.4344	.5487		.3841	.4163	.2402
21		.3841	.3658		.3696	.3696	.2402
22		.2957	.3109		.3292	.3292	1.7741
23	.0549	.2743	.2587		.2772	.2926	
24	.2241		.2218	.2587	.1494	.2218	.2218
Max	.2641	.4344	.5487	.2772	.3841	.4163	1.7741
Min	.0549	.2515	.1781	.1677	.1494	.1848	.1187
Avg	.1950	.3075	.2533	.2231	.2279	.2487	.2635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 207 / 11KV Alkud Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.132	.1698	.9488	.9995	1.0883	1.0402
2	.1698		.1886	.9282	.9995	1.0364	1.0242
3	.1698	.1494	.1698	.9922	1.0322	1.1336	1.0082
4	.1886	.1494	.1886	1.1142	1.0322	1.1633	1.0202
5	.2263	.2054	.2075	1.2125	1.1105	1.278	1.0202
6	.3018	.2801	.2829	1.3763	1.1105	1.3927	1.2597
7	.3018	.2641	.2641	1.6549		1.704	1.2452
8	.2427		.1867	.2218	.1848	.2241	.2195
9	1.5565		.1886	.168	.1886	.2075	1.491
10	1.5061		.1494	.1478	.1698	.1307	1.1683
11	1.4575		.1848	.1063		.168	1.3763
12	1.3279		.1646	.1052	.1307	.1509	1.5893
13	1.3603		.1294		.128	.1509	1.5565
14	1.3603	.3812	.1109			.1307	1.5893
15	1.2018	1.085	.128		.1698	.1294	1.5402
16		1.4575	.1494		.1509	.1494	1.5565
17		1.3443	.1646		.1294	.168	.1663
18		.1478			.1867	.168	.1663
19		.2218	.1867		.2452	.2054	.1886
20		.2829	.2829		.2452	.2452	.2263
21		.2452	.2263		.2263	.2075	.2452
22		.2075	1.2616		1.3603	1.3108	
23	.132	.1886	1.0082		1.2163	1.1961	
24	.1886	.132	.1698	.953	.9995	1.0911	1.0402
Max	1.5565	1.4575	1.2616	1.6549	1.3603	1.704	1.5893
Min	.132	.132	.1109	.1052	.128	.1294	.1663
Avg	.6977	.4044	.2680	.7638	.5722	.6179	.9881

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 201 / 11Kv Dudhebhavi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2035	.1677	.218	1.2431	.8383	.9724	
2	.218	.1509		1.6244	.8478	.9614	
3	.2035	.1357	.2012	1.4586	.9221	.9116	
4	.1844	.1357	.2012			.9054	
5	.2204	.1341	.2155		1.0174	1.0174	
6	.2515	.1677	.2321		1.0898	1.3413	
7	.2713	.1677	.2347		1.1022	1.7604	
8						.2515	.1509
9	1.4251		.2012		.2347	.2012	1.3413
10	1.3413		.1677	.1677	.218	.1677	1.1869
11	1.4918		.2012		.218	.1677	1.2574
12			.1677	.1677	.2012	.1677	1.3565
13		1.6766	.1677		.2012	.1677	1.4413
14		1.5089	.1677		.2012		1.3413
15		1.4083	.1677		.218	.1341	1.4413
16		1.4083	.1341		.2012	.1341	1.5089
17	.1677	1.1736	.1341		.2035		.2515
18	.2012	.8383			.218		.2515
19	.1677	.2347			.2515		.1677
20	.1677	.2515			.2515		.2543
21	.1677	.2515			.2515		.2515
22	.1677			1.0059	1.1736		.2543
23	.1696			1.0174	1.1401		.285
24	.1844	.1677	.218	1.1736	.9326	1.0395	1.0898
Max	1.4918	1.6766	.2347	1.6244	1.1736	1.7604	1.5089
Min	.1677	.1341	.1341	.1677	.2012	.1341	.1509
Avg	.4003	.5870	.1894	.9823	.5424	.6438	.8136

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 202 / 11KV Nagaj

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3565		.6036	.6464	.4024	.3688	
2	1.4413			.6539	.4409	.3521	
3	1.4251		.6036	.5197		.3521	
4	1.3565		.6036			.3688	
5	1.2574		.7209		.4409	.4024	
6	1.4413		.8383		.4694	.4527	
7	1.5089		.9221		.5087	.4862	
8						.4024	.4359
9	.3521		1.0059		.1296	1.3413	.407
10	.3391		.9221	1.291	1.4419	1.2574	.4359
11	.39		.8383		1.3565	1.3413	.407
12			1.0059		1.3565	1.1736	.3688
13		.7545	.8383		1.2717	1.1736	.3561
14		.8383	.8383		1.1736	1.3413	.3688
15		.7545	1.0059		1.3413	1.1736	.3561
16		.7545	1.0059		1.3916	1.3413	.4191
17		.7042	.5197		.3521		.4191
18		.6706	.5365		.3688		.3688
19		.6371	.5533		.4191		.4191
20		.6706			.4748		.4191
21		.5868			.4748		.4191
22				.4409	.4409		1.0059
23				.4024	.4409		1.0059
24	1.2717		.6371	.5197	.407	.4191	.3856
Max	1.5089	.8383	1.0059	1.291	1.4419	1.3413	1.0059
Min	.3391	.5868	.5197	.4024	.1296	.3521	.3561
Avg	1.1036	.7079	.7777	.6391	.7192	.8087	.4704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 203 / 11KV Chorochi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059		.4973	.1677	.1696	.1989	
2	1.1869			.1823	.1844	.1823	
3	1.0059		.4973	.1677	.1696	.1844	
4	1.0174		.4973			.2012	
5	1.3413		.503		.1865	.1989	
6	1.5261		.5304		.2012	.2347	
7	1.3413		.5801		.2012	.2515	
8						.2347	.1509
9	.1677		.6706		.8718	.6706	.1696
10	.1823		.6706	.8383	.9221	.7545	
11	.1677		.5868		.8886	.7545	
12			.6706		.8288	.6706	
13		.8383	.6706		.8288	.8383	
14			.5868		.8383	1.0059	
15			.5868		.8383	.8383	
16			.6706		.8383	.6706	
17			.1844		.2012		
18		.3018	.1823		.218		
19		.2347			.2347		
20		.2515			.2347		.2012
21		.2515			.2347		.2012
22				.2012	.218		.6706
23				.2035	.2035		.6706
24	.8383		.5365	.1696	.1677	.2012	.1677
Max	1.5261	.8383	.6706	.8383	.9221	1.0059	.6706
Min	.1677	.2347	.1823	.1677	.1677	.1823	.1509
Avg	.8892	.3756	.5366	.2758	.44	.4759	.3188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 204 / 11KV Chorochi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3688	.1006	.3688	1.1736	1.5261	1.7101	
2	.373	.1006		1.2574	1.8442	1.6244	
3	.3561	.1017	.3521	1.4251		1.5746	
4	.3688	.1017	.3521			1.5927	
5	.3561	.1677	.3812		2.0119	1.6766	
6	.4024	.2012	.431		2.2043	1.9281	
7	.407	.2012	.4359		2.0119	2.431	
8						.3856	.1677
9	2.4863		.2347		.0335	.3353	1.5089
10	2.3472		.2012	.1677	.3521	.2515	1.5261
11	2.42		.1677		.3561	.285	1.6766
12			.1677	.1677	.3353	.2347	1.5261
13		1.0059	.2012		.3353	.2347	1.6766
14		1.3413	.2012		.3353	.2012	1.5261
15		1.5089	.2012		.3521	.1677	1.4251
16		1.2955			.3521	.2012	1.5261
17		1.4083	.2347		.3521		.2515
18		1.2574	.2515		.3521		.2515
19		.4152	.2515		.4359		.2515
20	.1006	.4359			.4578		.2543
21	.1006	.4024			.4409		.2543
22	.1006			1.1736	1.8652		.3353
23				1.3565	1.8442		.3353
24	.3521	.1006	.39	1.1736	1.3413	1.7604	1.6766
Max	2.4863	1.5089	.4359	1.4251	2.2043	2.431	1.6766
Min	.1006	.1006	.1677	.1677	.0335	.1677	.1677
Avg	.7528	.5968	.2837	.9869	.9114	.9762	.9512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 205 / 11KV Nagaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)
1	.208	.0857
2	.1907	.0857
3	.1886	.0857
4	.1734	.0857
5	.1886	.1387
6	.2058	.1372
7	.2427	.1372
9	.218	
10	.1886	
11	.208	
18	.0686	
24	.1734	.0857
Max	.2427	.1387
Min	.0686	.0857
Avg	.1879	.1052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 206 / 11 KV Dudhebhavi Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2947	.208	.6135	.6001	.6068	.4681	
2	.2947	.1715		.6588	.6001	.4557	
3	.2572	.1715	.6135	.6001		.4161	
4	.2572	.1715	.5895			.4161	
5	.3121	.1734	.6485		.823	.4733	
6	.3086	.2743	.6935		.8916	.5028	
7	.3086	.3429	.6588		.8842	.5721	
8						.4207	.4287
9	.3772		.5144		.4908	.3429	.5201
10	.3944		.5144	.3467	.4508	.3772	.4681
11	.3944		.5144		.4733	.3429	.463
12			.583	.4801	.4908	.3429	.5201
13			.5144		.4508	.4287	.4854
14		.5375	.6001		.4557	.4287	.4458
15		.5609	.6001		.4681	.4287	.4508
16		.5609	.503		.4854	.5144	.6516
17	.2572	.6068	.703		.5609		.6001
18	.2401	.6588	.663		.631		.5144
19	.2058	.7716	.6539		.6836		.6001
20	.2401	.8745			.6935		.6001
21	.2743	.7802			.6379		.5201
22	.2743			.7975	.5609		.4801
23	.1006			.6001	.5434		.4801
24	.3467	.2058	.6588	.6001	.5548	.5201	.4801
Max	.3944	.8745	.703	.7975	.8916	.5721	.6516
Min	.1006	.1715	.503	.3467	.4508	.3429	.4287
Avg	.2855	.4419	.6022	.5854	.5923	.4383	.5123



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 201 / 11KV Shelkewadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.1791	.2402	.9922	1.0364	1.0242	1.2346
2	.2402	.1791	.2402	1.0082	1.0364	1.0082	1.2346
3	.2218	.181	.2772	.9922	1.0486	.9922	1.2346
4	.2614	.181	.3361	1.0364	1.1469	1.0364	1.2146
5	.2614	.2241	.4108	1.2266	1.2651	1.278	1.2631
6	.2641	.4527	.5658	1.9616	1.8785	1.7939	1.326
7		.3921	.4527	2.0856	2.3594	1.1065	1.4918
8	.3326		.2801	.3772	.2896	.3109	.2195
9	2.3205		.2402	.2801	.1991	.2772	2.0222
10	2.304	.2454	.2172	.2402	.2172	.2402	1.9559
11	2.2801	.2804	.1949		.2587	.2587	2.1125
12	2.0719	.3155	.1949		.2561	.2012	1.9662
13	1.0595		.2172		.2507	.2012	
14	1.2163	1.1142	.181		.2402	.2033	
15	.3567	1.7238	.2218	.2172	.2587	.2402	
16	1.9113	1.0437	.2402	.2172	.2587	.2172	1.4419
17		.2614	.2561	.2378	.1448	.2534	1.4419
18		.3361	.2587	.2743	.1991	.2926	.2686
19		.4108	.3361	.3292	.2801	.4108	.362
20		.4481	.3961	.4066	.4527	.4715	.439
21		.3734	.3772	.3982	.3961	.4108	.3982
22		.3174	1.7269	1.704	1.6078	1.6549	.3582
23	.1829	.2801	1.2616	1.1012	1.3272	1.2955	.2987
24	.7287	.1829	.2402	1.0242	1.1012	1.0883	1.2346
Max	2.3205	1.7238	1.7269	2.0856	2.3594	1.7939	2.1125
Min	.1829	.1791	.181	.2172	.1448	.2012	.2195
Avg	.9583	.4344	.3901	.8055	.7296	.6778	1.1199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 202 / 11 KV GATHNANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6249	.1109	.6481	.168	.1646	.168	.168
2	.503	.1109	.6481	.168	.1629	.168	.168
3	.4531	.1109	.703	.168	.1612	.168	.168
4	.5937	.1109	.7811	.1867	.181	.1886	.1886
5	.8684	.1307	.8907	.2263	.197	.2263	.2075
6	1.2944	.2054	1.0322	.2829	.2534	.3206	.2641
7	1.3443	.2263	.933	.2263		.2641	.2263
8	.1097		.128	.2402	.181	.1663	.1463
9	.0934		.8065	1.278	1.1797	1.5424	.1267
10	.104	.1086	.759	1.1984	1.1797	1.2763	.0905
11	.0895	.0876	.6622		1.0688	.9922	.0905
12	.0895	.0678	.7977		.9488	.9922	.0905
13	.0701		.7164		.9374	.9488	.0905
14	.0686	.0905	.7202		.8962	.9442	.0724
15	.0857	.0905	.9282		.9602	1.0883	.0732
16	.0724	.0791	1.0082	1.1142	.9922	1.3927	.0914
17		.112	.0857	.0895	.1063	.1052	.0905
18		.1494	.124	.1075	.1214	.1227	.1086
19		.1867	.2241	.1448	.1867	.1867	.1448
20		.2241	.2263	.2353	.2263	.2641	.2149
21		.2054	.2241	.2172	.2075	.2427	.1991
22		.9602	.2054	.2172	.1867	.2054	1.1797
23	.2591	.7343	.1867	.1791	.1698	.1867	.9175
24	.7621	.2968	.6481	.1867	.1829	.1867	.168
Max	1.3443	.9602	1.0322	1.278	1.1797	1.5424	1.1797
Min	.0686	.0678	.0857	.0895	.1063	.1052	.0724
Avg	.4159	.2095	.5870	.3492	.4718	.5145	.2202

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 203 / 11KV Raiwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3894	.0543	.443	.056	.0724	.056	.056
2	.3963	.0549	.443	.056	.0724	.056	.056
3	.3201	.0549	.5117	.056	.0732	.056	.0747
4	.3858		.5117	.0566	.0724	.0566	.0934
5	.4475	.0747	.5624	.0754	.0914	.0754	.132
6	.5401	.1698	.5937	.1698	.1629	.1886	.1698
7	.6562	.1307	.5575	.1509	.128	.1132	.1509
8	.0747		.0739	.0943	.0905	.0934	.0747
9	.0754		.5624	.6401	.6478	.7682	.0732
10	.0554	.0532	.5312	.6859	.7125	.759	.0732
11	.0554	.0532	.4967		.6401	.6718	.0724
12	.0549	.0543	.4371		.5418	.5719	.0724
13	.0354		.4572		.4904	.5418	.0732
14	.0358	.0554	.4254		.4401	.5792	.0724
15	.0347	.0543	.4755		.4816	.6622	.0724
16	.0543	.0526	.4401	.5937	.5487	.5796	.0724
17		.0732	.052	.0358	.052	.0724	.0732
18		.0924	.0739	.0716	.0876	.0905	.0739
19		.1109	.1132	.0905	.1097	.1307	.1086
20		.112	.1307	.128	.132	.1307	.1463
21		.0943	.1109	.1097	.0943	.0934	.1086
22		.5792	.0754	.0914	.0943	.0739	.7209
23	.4062	.5155	.056	.0724	.0754	.056	.5182
24	.3894	.2107	.443	.056	.0724	.056	.056
Max	.6562	.5792	.5937	.6859	.7125	.7682	.7209
Min	.0347	.0526	.052	.0358	.052	.056	.056
Avg	.2448	.1325	.3574	.1732	.2493	.2722	.1331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 204 / 11 KV Shelkewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.1886	.2378	.2241	.1791	.2054	.2241
2	.1886	.1867	.2378	.2241	.181	.2054	.2241
3	.1886	.1867	.2772	.2241	.181	.2241	.2241
4	.1886	.2054	.3326	.2241	.2195	.2427	.2801
5		.2263	.3772	.2641	.2534	.2829	.3361
6	.415	.3772	.3961	.3772	.4119	.415	.3734
7		.3772	.3258		.362	.3206	.3292
8	.2686		.2926	.3841	.2534	.2743	.2507
9	.1753		.2103	.3142	.2195	.2427	.2103
10	.1991	.2328	.1928	.2172	.1991	.2507	.1928
11	.1991	.2328	.1612		.1949	.2103	.2149
12	.2149	.2254	.1791		.2149	.1949	.1991
13	.2481		.1991		.2218	.2303	.1991
14	.2378	.2303	.2054		.2054	.2279	.2012
15	.2328	.2126	.2054	.1991	.2033	.2126	.2172
16	.2195	.2229	.1848	.2149	.1848	.2149	.1433
17		.2454	.2195	.2172	.2279	.2486	.1448
18		.3045	.2279	.2534	.2454	.2984	.2534
19		.3761	.3292		.3658	.3898	.3258
20		.394	.4251		.462	.4163	.4207
21		.3658	.3696	.3841	.4294	.3881	.3801
22		.3109	.2957	.3109	.3292	.3292	.3077
23	.2075	.2715	.2561	.2534	.2614	.2561	.2149
24	.2452	.2075	.2378	.2241	.2172	.2241	.2241
Max	.415	.394	.4251	.3841	.462	.4163	.4207
Min	.1753	.1867	.1612	.1991	.1791	.1949	.1433
Avg	.2273	.2657	.2657	.2653	.2593	.2711	.2538

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 205 / 11 KV GHATNANDRE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.1227	.0943	.1132	.0905	.112	.0943
2	.0905	.1227	.0943	.1132	.0914	.112	.0943
3	.0924	.1227	.132	.1132	.0905	.112	.0943
4	.0924	.124	.1698	.1132	.1075	.112	.132
5	.1307	.1629	.2241	.1509	.128	.1509	.1886
6	.2427	.2614	.2614	.2263	.0905	.2641	.2452
7		.2587	.2054	.2452	.1991	.2263	.2218
8	.1052		.0716	.1509	.1629	.1307	.1663
9	.1052		.0716	.128	.1463	.1109	.1478
10	.0867	.1294	.0895	.0905	.1086	.1097	.112
11	.0895	.1294	.0895		.1097	.0886	.0924
12	.1254	.116	.0905		.1097	.0876	.0905
13	.124		.1109		.0924	.0914	.0914
14	.104	.0995	.0943		.0934	.0924	.0724
15	.1052	.104	.0754	.0895	.0924	.0914	.0732
16	.124	.1387	.0934	.1267	.1109	.0914	.0914
17		.1387	.0747	.128	.1086	.1294	.1086
18		.1753	.1433	.128	.1417	.1595	.1433
19		.2279	.2012	.1829	.1867	.2012	.181
20		.2279	.2427	.2172	.2263	.2218	.2534
21		.197	.2054	.181	.1886	.2218	.1612
22		.181	.132	.1433	.1509	.168	.1629
23	.1052	.1254	.0943	.1267	.1307	.1132	.0895
24	.1075	.1227	.0943	.1132	.0905	.112	.0943
Max	.2427	.2614	.2614	.2452	.2263	.2641	.2534
Min	.0867	.0995	.0716	.0895	.0905	.0876	.0724
Avg	.1141	.1566	.1315	.1441	.1270	.1379	.1334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 206 / 11KV Raiwadi Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0678	.1029	.0867	.1086	.1052	.0867
2	.0377	.0678	.1029	.0876	.1086	.1063	.0867
3	.0377	.0686	.1029	.0857	.1075	.1063	.0867
4	.0566	.0701	.1267	.0876	.1097	.1075	.1109
5	.0566	.0914	.1629	.1063	.1109	.1097	.1294
6	.0943	.1307	.1629	.1494	.1646	.1307	.1294
7	.0943	.1143	.1417	.1334	.181	.1132	.0754
8	.0747		.1075	.112	.128	.0934	.0905
9	.0905		.0876	.0914	.0724	.0747	.0905
10	.0709	.104	.0876	.0905	.1086	.0709	.0848
11	.124	.1214	.0838		.0876	.0857	.1006
12	.1063	.1457	.1006		.1029	.1029	.1052
13	.1017		.1017		.1017	.104	.1075
14	.0867	.1357	.1075		.0895	.1029	.0905
15	.104	.1134	.1063	.0543	.1063	.1006	.0914
16	.0876	.128	.104	.1097	.0857	.0867	.0543
17		.1357	.1187	.1267	.0509	.0857	.0905
18		.1543	.124	.1267	.0838	.0848	.0934
19		.1595	.128	.128	.1612	.124	.0905
20		.1772	.128	.1646	.1772	.1433	.128
21		.1753	.1307	.1629	.1448	.1578	.1075
22		.124	.1254	.1267	.1402	.1402	.124
23	.0181	.1029	.0886	.1075	.1227	.0857	.0886
24	.0377	.0671	.1029	.0876	.1086	.1052	.0867
Max	.124	.1772	.1629	.1646	.181	.1578	.1294
Min	.0181	.0671	.0838	.0543	.0509	.0709	.0543
Avg	.0732	.1169	.1140	.1113	.1151	.1053	.0971

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 207 / 11KV Jakhapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.0754	.2401	.192	.2721	.3113
2	.0373	.0377	.0754	.144	.1966	.2561	.2949
3	.0373	.0377	.0754	.144	.1966	.2721	.2949
4	.0566	.0377	.0754	.1943	.2458	.2915	.3277
5	.0754	.0566	.0934	.2622	.3077	.3605	.3277
6	.1307	.1132	.0934	.4807	.4481	.6036	.3277
7		.1132	.112	.5868	.664	.426	.3932
8	.1307		.0754	.1132	.0914	.132	.0943
9	.639		.0754	.0943	.1086		.6796
10	.639	.0943	.0754	.132	.1086		.6299
11	.6062	.1132	.0566		.0754		.5304
12	.4752	.1132	.0566		.0566		.4915
13	.4049		.0754		.0934	.0754	.4096
14	.5243	.3932	.0566		.0566	.0754	.3887
15	.5601	.4424	.0754	.0566	.0754	.0943	.5079
16	.4534	.5079	.0754	.0566	.0943	.1132	.502
17		.0754	.0943	.0739	.1132	.1494	.0914
18		.0943	.132	.1307	.132	.1867	.0537
19		.0943	.132	.0914	.1132	.112	.0905
20		.1132	.1698	.0914	.1132	.0934	.1086
21		.0754	.0754	.0724	.0943	.0754	.1075
22		.0566	.3647	.4534	.4752	.426	.0914
23	.0377	.0566	.2753	.3201	.3401	.3277	.0905
24	.0373	.0377	.0754	.2401	.2241	.2881	.3113
Max	.639	.5079	.3647	.5868	.664	.6036	.6796
Min	.0373	.0377	.0566	.0566	.0566	.0754	.0537
Avg	.2872	.1286	.1059	.1989	.1924	.2315	.3107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 208 / 11 KV AGALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.68	.0934	.5079	.1494	.1075	.132	.1509
2	.6325	.0934	.5079	.1494	.1086	.132	.1509
3	.6009	.0934	.5407	.1509	.1097	.132	.1509
4	.6642	.112	.5898	.1698	.1433	.1509	.1886
5	.8065	.1509	.663	.1886	.181	.1886	.2614
6	1.1227	.3772	.7459	.3206	.2926	.3395	.3174
7	1.0437	.3206	.7459	.2829	.2715	.2641	.2801
8	.1867		.2614	.2075	.1791	.1867	.168
9	.168		.7701		1.1822	1.1361	.1132
10	.168	.1886	.7373		1.1843	1.073	.0943
11	.0934	.1509	.7045		1.1934	.8718	.1132
12	.1109	.1132	.6226		1.0486	.6036	.1097
13	.1086		.6241		.9717	1.0059	.1097
14	.1294		.5571		.9175	1.0774	.1086
15	.1254		.6062		.9614	1.1934	.1086
16	.2743	.1509	.7373	.6154	.9503	1.1934	.1097
17		.1509	.1097	.1075	.132	.1132	.1086
18		.1867	.1307	.1612	.1663	.1509	.1463
19		.2241	.2075	.2172	.2241	.2241	.1991
20		.2614	.2641	.2926	.2641	.2801	.2743
21		.2241	.2427	.2561	.2263	.2241	.2172
22		.7373	.1886	.181	.1698	.1867	.9012
23	.1475	.5898	.1509	.1629	.1509	.1509	.5921
24	.8676	.1423	.5079	.1494	.1448	.132	.1509
Max	1.1227	.7373	.7701	.6154	1.1934	1.1934	.9012
Min	.0934	.0934	.1097	.1075	.1075	.1132	.0943
Avg	.4406	.2295	.4885	.2213	.4700	.4643	.2135



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 201 / 11 KV LONARWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7438	.3944	.6654	1.6392	2.9641	3.0617	3.4105
2	.7354	.3891	.6593	1.4952	3.016	2.9455	3.4963
3	.7374	.4109	.6486	1.448	3.1024	2.9016	3.3075
4	.7661	.4502	.6447	1.4419	3.1459	2.8288	3.3714
5	.8954	.4969	.6844	1.5927	3.784	2.99	3.4709
6	1.2513	.5967	.9	2.3426	4.899	4.7762	3.8866
7	1.2982	.6992	.9694	3.1878	5.8004	5.5803	4.3412
8	.2073	.6352	.8383	.6805	.9848	.9633	.7918
9	4.8971	.8032	.6438	.7704	.6912	.8133	2.5164
10	5.5586	1.6743	.5699	.5864	.6565	.6219	5.0099
11	5.6781	3.1108	.5167	.4077	.5758	.6569	5.2879
12	5.6556	3.1388	.5129	.2743	.6337	.6817	4.9804
13	5.3955	3.0279	.5537		.5704	.7139	4.4947
14	4.9905	2.7866	.5257	.2286	.5826	.7032	4.1103
15	4.8838	3.3997	.5533	.4344	.5642	.6509	4.1858
16	2.6116	4.1057	.4958	.3719	.5609	.6828	4.3839
17	.3551	.7872	.5647	.426	.5832	.7178	.6904
18		.8025	.6257	.5289	.7285	.8139	.8164
19	.0434	.9534	1.0852	.6882	1.0791	.9991	1.172
20	.3605	1.0859	1.3237	.868	1.2795	1.2203	1.3756
21	.6514	1.0417	1.391	.993	1.3295	1.3853	1.3233
22	.6207	.9175	4.8478	2.3312	4.0711	3.8992	1.1904
23	.4883	.7792	4.4841	3.6949	3.7521	3.8477	.9381
24	.5944	.5552	2.1418	3.9421	3.1535	3.3318	2.1086
Max	5.6781	4.1057	4.8478	3.9421	5.8004	5.5803	5.2879
Min	.0434	.3891	.4958	.2286	.5609	.6219	.6904
Avg	2.1487	1.3768	1.1186	1.3206	2.0212	1.9911	2.9442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 202 / 11KV Kokle Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4476	.1105	1.4051	.2873	.5026	.4664	.5167
2	1.3664	.093	1.3081	.253	.4858	.4367	.4916
3	1.3489	.0892	1.2365	.2423	.5128	.4811	.4855
4	1.4956	.0892	1.3687	.2462	.5567	.5128	.5186
5	1.8961	.0991	1.4762	.2797	.6312	.5874	.5917
6	2.5058	.1242	1.8035	.4443	.8272	.72	.7644
7	2.769	.1288	1.8858	.4725	.8303	.7198	.7091
8	.4726	.0831	.7804	.5609	.8079	.7675	.3056
9	.4767	.0793	1.7516	1.7908	1.996	2.1529	.3018
10	.4119	.1044	1.8686	2.127	2.0433	2.2714	.5582
11	.4016	.1326	1.8343	1.0966	1.9288	2.2189	.4198
12	.4169	.0975	1.3001	.2751	1.8942	2.0957	.4458
13	.4809	.1806	1.613		1.6093	1.937	.4173
14	.426	.112	1.7223	.2454	1.5947	1.8625	.4161
15	.4306	1.6949	1.7352	.2728	1.6668	1.808	.3948
16	.2202	1.23	1.4365	.7156	1.7383	1.7681	.3574
17	.1471	.5609	.3828	.2827	.4134	.4573	.4403
18		.5594	.462	.3041	.4914	.6081	.4855
19	.0884	.654	.6026	.3948	.6866	.7201	.6943
20	.1593	.7332	.675	.4687	.7758	.7697	.778
21	.1379	.9377	.6468	.4565	.727	.7293	1.0201
22	.1372	1.5747	.5483	.3925	.5658	.6382	2.0439
23	.1456	1.5067	.5056	.5535	.4992	.5856	1.7978
24	.7629	.804	.9779	.4891	.5171	.4748	1.1516
Max	2.769	1.6949	1.8858	2.127	2.0433	2.2714	2.0439
Min	.0884	.0793	.3828	.2423	.4134	.4367	.3018
Avg	.7889	.4908	1.2220	.5501	1.0126	1.0746	.6711

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 203 / 11 KV IRALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831		1.3904	.168	.2263	.168	.2353
2	.9831		1.4575	.1494	.2452	.1698	.2172
3	1.0277		1.4918	.1494	.2641	.2075	.2172
4	1.1603		1.4918	.1494	.3018	.2452	.2378
5	1.576		1.56	.1494	.3584	.2641	.2561
6	2.0348		1.56	.3361	.3961	.2801	.2561
7	2.0687		1.6108	.3326	.3584	.2614	.2561
8	.2075		.2172	.2772	.2075	.2427	
9	.1848		1.286	1.4899	1.5074	1.6461	
10	.1848		1.3904	1.5223	1.4746	1.7193	.1307
11	.1848	.2218	1.4754		1.4255	1.5432	.1663
12		.2012	.8718		1.3108	1.4575	.1509
13	.1663	.1829	.0838		1.1797	1.3904	.1886
14	.1848	.1991	.8619		1.1469	1.3717	.2075
15	.1829	.2172	.9488		1.1469	1.2717	.1433
16		.2378	.7907		1.1105	1.0174	
17		1.3769	.1886		.197	.2353	
18		1.1041	.2054		.2241		.2686
19	.2452	.2534			.3174	.2561	.3511
20	.2452	.2353	.2452		.3361	.2743	.3921
21		.2715	.2452		.2987	.2534	.3547
22		1.2717	.2241		.1867	.2715	1.4251
23		1.406	.2241		.168	.2561	1.2803
24	.9717	1.2717	.2641	.2054		.168	.2561
Max	2.0687	1.406	1.6108	1.5223	1.5074	1.7193	1.4251
Min	.1663	.1829	.0838	.1494	.168	.168	.1307
Avg	.7407	.6036	.8733	.4481	.6256	.6509	.3496

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 204 / 11 KV LONARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1463	.1829	.1494	.1478	.1294	.168
2	.132	.1478	.1663	.1494	.1494	.1294	.168
3	.1494	.1478	.1663	.1307	.168	.1307	.1478
4	.1494	.168	.1478	.1307	.1698	.1494	.1663
5	.1867	.1867	.1478	.1294	.1886	.1494	.1478
6	.2054	.1867	.1663	.1294	.2263	.1867	.1663
7	.2054	.1867	.1848	.1848	.2054	.2054	.1848
8	.1227		.1663	.1867	.1772	.1867	
9	.1595	.1867	.1663	.1629	.1578	.1267	
10	.1595	.132	.1494		.1402	.1254	
11	.1595	.1629	.128	.1372	.1402	.1086	.1214
12	.1595	.1646	.128		.1715	.128	.1417
13	.1433	.1478	.1448		.1543	.1294	.1433
14	.1433	.1463	.1448		.1254	.1478	.1433
15	.1433	.1663	.1448		.124	.1307	.1433
16		.1867	.1267		.1227	.1307	.0886
17			.1402		.1227	.1494	.1492
18			.1715		.1433	.1663	.1696
19	.2218		.1791		.2195	.1848	.2126
20	.2378		.1791		.2378	.2012	.2353
21	.2218		.1791		.2195	.2033	.2218
22	.2033		.1867		.1848	.1848	.1848
23	.1382	.2033	.1867	.168	.1478	.1848	.1663
24	.132	.1646	.1829	.1494	.1478	.1478	.1867
Max	.2378	.2033	.1867	.1867	.2378	.2054	.2353
Min	.1227	.132	.1267	.1294	.1227	.1086	.0886
Avg	.1669	.1665	.1611	.1507	.1663	.1549	.1646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 205 / 11 KV KOKLE GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1097	.1307	.1294	.1267	.1307	.112
2	.0943		.1307	.1109	.1267	.1109	.112
3	.0943			.1109	.128	.0924	.132
4	.1132		.1294	.1109	.1294	.0934	.0747
5	.1132		.1109	.1109		.0943	.0943
6	.1132		.1109	.1294	.132	.0943	.1132
7	.112		.128	.1294	.112	.0943	.1132
8	.0934			.1109	.0934	.0934	
9	.0943			.1132	.0943	.1132	
10	.1132		.128	.0953	.0943	.1132	
11	.1132	.112	.0754		.0943	.1132	.1294
12		.1132	.0754		.0934	.112	.1294
13	.1132	.112	.0914		.0924	.1132	.1254
14	.1075	.112	.0914		.0924	.0943	.1254
15	.1075	.1307	.0739		.0924	.112	.1075
16		.132	.0747		.0924	.112	.1097
17		.1307	.0895		.0924	.1132	.0886
18		.1494	.1086		.1097	.132	.104
19	.1478	.1478	.1448		.128	.1307	.1578
20	.1646	.1663	.1448		.1448	.1494	.156
21	.1494	.168	.1494		.1448	.1307	.1663
22	.132	.1478	.1478		.1494	.1294	.132
23	.1254	.1478	.1478	.1509	.1494	.132	.1478
24	.0943	.1097	.1294	.1294	.1267	.1307	.1132
Max	.1646	.168	.1494	.1509	.1494	.1494	.1663
Min	.0934	.1097	.0739	.0953	.0924	.0924	.0747
Avg	.1145	.1326	.1149	.1193	.1148	.1140	.1211

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 206 / 11 KV IRALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132		.0934	.0934	.0747	.0924	.0754
2	.1132		.0747	.0934	.0747	.0924	.0754
3	.1132		.0747	.0934	.0943	.0924	.0754
4	.1307		.0747	.0934	.1132	.0943	.0934
5	.1478		.0747	.112	.1132	.0943	.0934
6	.1663		.0747	.112	.132	.132	.0934
7	.1478			.1109	.132	.132	.0934
8	.0747		.0739	.0924	.0754	.132	
9	.0914			.0943	.0754	.0914	
10	.0886		.0924	.0747	.0754	.2378	
11	.0886	.112	.0177		.0754	.0732	.056
12	.0886	.0754	.0179		.0754	.0732	.0566
13	.0747	.0747	.037		.056	.0739	.0566
14	.0566	.0747	.037		.0566	.0739	.0566
15	.0566	.0924	.0566		.0566	.056	.0566
16		.0934	.0351		.0566	.056	.0381
17			.0377		.0566	.0739	.0739
18			.0572		.0747	.0914	.0895
19	.1132		.1143		.1109	.0924	.128
20	.1334		.1132		.112	.1109	.1307
21	.132		.1132		.112	.0747	.1307
22	.1132		.1132		.0934	.0934	.112
23			.0934	.0934	.0934	.0924	.0934
24	.1109	.0732	.0934	.0934	.0747	.0934	.0924
Max	.1663	.112	.1143	.112	.132	.2378	.1307
Min	.0566	.0732	.0177	.0747	.056	.056	.0381
Avg	.1077	.0851	.0714	.0964	.0860	.0967	.0843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 201 / 11 KV Shindewadi (H) Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1879		1.5581	.3142	.2195	.2987	
2	2.2542	1.0774	1.6741	.2957	.1829	.2614	.3109
3	2.4863	1.1105	1.873	.3142	.2378	.2241	.3841
4	2.5857	1.1437	1.9725	.3511	.2743	.3547	.4024
5	2.7183	1.2266	2.0885	.4435	.3292	.3921	.4207
6	2.967	1.326	2.2211	.5175	.4207	.4294	.4572
7	2.5857	2.4863	2.4531	.4435	.4572	.4668	.4755
8	.3547	.3361	.3174	.2772	.3109	.3174	.4024
9	.2987	.2241	2.9172	2.1879	2.7183	2.7018	.2561
10	.2801	.2427	3.2156	2.967	2.8509	2.9007	.2378
11	.2427	.2614	2.8675	2.9007	3.0498	2.8178	.2195
12	.2614	.2427	2.6852			2.7515	.2378
13	.2427	.2241	2.6852			2.5692	.1829
14	.2614	.2054	2.42		2.8675	2.7349	.1646
15	.2987	.2427	2.5857		2.7183	2.6023	.2012
16	.3361	.2801	2.7846		2.6189	2.652	.2195
17	.2987	.3361	.2033		.2614	2.652	.2743
18		.3734	.2772		.3547	.2378	.3292
19		.4854			.4854	.2743	.4207
20		.5788	.4805		.5788	.3109	.6219
21		.4108	.4251		.4668	.439	.4755
22		1.6244	.3696		.3734	.4572	2.1548
23		1.5581	.3326		.4108	.4024	2.0553
24	2.0388		1.4918	.3142	.2561	.3361	.3658
Max	2.967	2.4863	3.2156	2.967	3.0498	2.9007	2.1548
Min	.2427	.2054	.2033	.2772	.1829	.2241	.1646
Avg	1.2611	.7271	1.7347	.9439	1.0202	1.2327	.4900

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 202 / 11 KV Kuktoli Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5857		1.8233	.2241	.1663	.1867	.2218
2	2.4863	1.1934	1.6409	.2427	.1294	.1494	.2402
3	2.42	1.2431	1.5083	.2427	.1109	.112	.2033
4	2.4531	1.2929	1.9227	.2614	.1478	.1307	.1848
5	2.5857	1.2597	1.989	.2801	.1848	.168	.2218
6	2.652	1.3592	2.1051	.3174	.2218	.2054	.2218
7	2.7846	2.0388	2.0388	.2801	.2587	.2614	.2402
8	.2054	.1848	.168	.1494	.1663	.2241	.2033
9	.1307	.1478	2.1879	2.4863	2.5526	2.8509	.1294
10	.112	.1478	2.4366	2.5194	2.7846	3.1327	
11	.1307	.1294	1.6575	2.9007	3.0498	3.0664	.1109
12	.112	.0924	2.0885		2.7183	3.0996	.0924
13	.1372	.0924	2.0553		2.7183	3.0664	.0739
14	.1494	.0739	1.8564		2.6355	3.0167	.0554
15	.168	.1109	2.1051		2.8841	2.967	.0924
16	.2241	.1294	2.1548		2.7349	3.0498	.1294
17	.2054	.2033	.112		.1867	.1848	.1663
18		.2402	.1494		.2241	.2772	.1848
19		.3142			.2614	.2402	.2033
20		.3696	.2987		.3547	.2218	.2402
21		.3326	.2801		.3174	.2033	.3142
22	1.326	1.7072	.2801		.2801	.1848	2.2874
23		1.9559	.2241		.2614	.2033	2.0885
24	2.6023		1.8564	.2241	.1848	.2241	.2033
Max	2.7846	2.0388	2.4366	2.9007	3.0498	3.1327	2.2874
Min	.112	.0739	.112	.1494	.1109	.112	.0554
Avg	1.2353	.6645	1.4321	.8440	1.0639	1.1428	.3526



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 203 / 11 KV Kongnoli Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402		.1867	1.326	1.4255	1.5912	.6796
2	.2402	.1494	.168	1.326	1.3757	1.5415	.7127
3	.2587	.168	.2054	1.3923	1.5581	1.6741	.6962
4	.2957	.1867	.2427	1.4586	1.7901	1.8564	.7459
5	.3326	.2241	.2801	1.5912	1.8564	1.9725	.6962
6	.3881	.2614	.2614	1.8067	1.989	2.0885	.7127
7	.4251	.2801	.2987	2.0553	2.0885	2.2874	.6962
8	.2587	.3547	.2054	.2427	.2427	.2427	.1663
9	2.9835	.6203	.1867	.2241	.2801	.2241	1.9559
10	3.083	.5868	.168	.2241	.2614	.2054	1.8233
11	3.0498	1.9448	.0373	.1867	.2427	.2241	2.3703
12	2.9835	1.8442	.168	.168	.2241	.2241	2.3205
13	2.9835	1.3245	.2054	.2054	.1867		2.2874
14	2.9835	1.358	.168		.168		2.8841
15	2.8841	1.073	.1867		.2241	.2427	2.7183
16	2.3205	1.1736	.2241		.2427	.2987	2.8178
17	.2218	.1867	.2427		.2987	.3174	.2987
18		.3547	.2241		.3547	.3361	.3547
19		.4481			.4481	.4294	.4251
20		.3174	.4481		.5415	.4668	.499
21			.4294		.4108	.5365	.4435
22	.1848	.2987	1.5912		1.9227		.3734
23		.2614	1.4255		1.8233	.5801	.2987
24	.2587		.2155	1.3757	1.5083	1.7238	.663
Max	3.083	1.9448	1.5912	2.0553	2.0885	2.2874	2.8841
Min	.1848	.1494	.0373	.168	.168	.2054	.1663
Avg	1.3882	.6389	.3378	.9702	.8943	.9078	1.1516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 204 / 11 KV Karoli Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475		.2195	.3109	.2012	.2195	.3109
2	.3292	.3292	.1829	.3292	.1829	.1829	.3475
3	.3475	.3475	.2012	.3292	.2195	.2012	.3109
4	.3658	.3658	.2378	.3658	.2561	.2378	.3292
5	.439	.3841	.2743	.439	.2743	.2926	.4024
6	.4938	.4024	.3292	.5304	.2926	.3658	.439
7	.4024	.3841	.4024	.4207	.3475	.439	.4755
8	.3658	.3292	.3292	.3841	.3292	.3841	.3109
9	.3658	.3109	.3475	.3109	.2926	.3475	.2926
10	.2926	.3658	.3109	.2926	.2561	.3292	.2561
11	.3109	.3292	.2353	.2561	.2378	.2743	.2195
12	.2926	.2926	.2926	.2561	.2195	.2195	.2012
13	.2378	.2195	.2353	.2012	.2012	.2195	.1829
14	.2195	.1829	.2896		.1829	.2012	.1646
15	.2378	.2561	.2896		.2012	.2012	.2378
16	.2561	.2743	.2896		.2195	.2743	.2926
17	.2195	.3109	.3109		.2561	.3109	.3292
18		.3475	.3841		.3475	.3658	.3658
19		.4207			.4207	.4024	.439
20		.5304	.5487		.5487	.4938	.567
21		.4938	.4938		.4938	.5304	.4755
22	.3658	.3658	.439		.3658	.3658	.3658
23		.2926	.3292		.2926	.3475	.3292
24	.3658		.2561	.3292	.2378	.2561	.3109
Max	.4938	.5304	.5487	.5304	.5487	.5304	.567
Min	.2195	.1829	.1829	.2012	.1829	.1829	.1646
Avg	.3292	.3425	.3143	.3397	.2865	.3109	.3315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 201 / 11 KV Deshing GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347			.2683	.285	.218
2		.2347		.2515	.2515	.218
3	.2515	.2012		.2347	.218	.218
4	.2515	.2012		.2012	.2012	.218
5	.2515	.1844		.2347	.2515	.2347
6	.2683	.2515		.2515	.2515	.3018
7	.285	.3185		.285	.285	.2515
8	.218	.3018		.218	.2347	.2012
9	.2012	.2515	.1943	.2012	.2012	.1677
10	.1844	.2515	.218	.1677	.2012	.1341
11	.2012	.2347	.1677	.1844	.2347	.1341
12	.2347	.218		.2012	.218	.1341
13	.218	.1844		.218	.2614	.1341
14	.2012	.218		.218	.2347	.1341
15	.2347	.2347		.218	.218	.1509
16	.218	.2347		.218	.218	.2012
17	.218	.2515		.2012	.2347	.2012
18		.3018		.218	.2515	
19		.4191		.3018	.4191	.3018
20		.4191		.4024	.4191	.3353
21		.4024	.4024	.4024	.4024	.4191
22		.3185	.3353	.3521	.3353	.2683
23		.2515	.3353	.3185	.2683	.2683
24	.2515			.2012	.3185	.2347
Max	.285	.4191	.4024	.4024	.4191	.4191
Min	.1844	.1844	.1677	.1677	.2012	.1341
Avg	.2308	.2675	.2755	.2487	.2673	.2209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 202 / 11 KV BANEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174			.8383	1.5257	1.5089
2	.1174	.0671		.8383	1.5592	1.5089
3	.1341	.0838		.8383	1.5089	.3521
4	.1509	.0838		.9221	1.5089	.3688
5	.1509	.0838		1.2574	1.5592	.3856
6	.1341	.1006		1.4922	1.7101	.4862
7	.1341	.1341		1.8107	1.8945	.4862
8	.1174	.1341		.1174	.1174	
9	1.5592	1.9113	.1006	.1174	.1006	2.1795
10	2.1795	2.0622	.1174	.1341	.1341	2.2466
11	1.8442	2.0119	.1341	.1509	.1174	2.2466
12	1.8442	1.9616		.1341	.1174	2.1795
13	1.8442	1.9448		.1341	.1174	2.1125
14	1.8442	1.6766		.1174	.1174	2.2131
15	1.8442	1.5089		.1174	.1006	2.2634
16	1.9281	1.7436		.1006	.1006	
17	.0838	.1174		.1341	.1006	.1677
18		.1174		.1341	.1677	
19		.1844		.1677	.1677	.1844
20		.1844		.218	.1677	.1844
21		.1509	.1341	.1677	.1509	.1677
22		.1341	.5868	1.5927	1.6095	.1677
23		.1006	.7545	1.5089	1.5424	.1677
24	.1174			.1341	1.5089	1.5257
Max	2.1795	2.0622	.7545	1.8107	1.8945	2.2634
Min	.0838	.0671	.1006	.1006	.1006	.1677
Avg	.8970	.7499	.3046	.5491	.7377	1.1002

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 203 / 11 KV MORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059			.1509	.1509	.1174
2	1.0059	.8383		.1509	.1341	.1174
3	1.0898	.8383		.1341	.1341	.1174
4	1.1736	.8383		.1341	.1341	.1174
5	1.4251	1.0562		.1509	.1509	.1341
6	1.6766	1.1401		.1677	.1677	.1844
7	1.6766	1.3916		.1677	.1844	.1844
8	.1844	.1174		.1341	.1509	.1509
9	.1677	.1174	1.6766	1.6263	2.0957	.1341
10	.1677	.1509	1.8442	2.079	2.0957	.1341
11	.1341	.1509	1.8442	2.1628	2.0957	.1341
12	.1341	.1174		1.8442	2.079	.1341
13	.1341			1.9113	2.0119	.1341
14	.1341	.1174		1.8442	1.861	.1341
15	.1341	.1509			1.8442	.1174
16	.1509	.1341			1.7269	
17	.1509	.1341		.1341	.1174	.1341
18		.1509		.1677	.1341	.1509
19		.2347		.2012	.2347	.1677
20		.2347		.218	.2347	.1677
21		.1677	.1677	.2012	.218	.1844
22		1.3916	.1341	.1509	.1844	1.0059
23		1.3077	.1509	.1509	.1509	1.1736
24	1.0059			.1341	.1509	.1174
Max	1.6766	1.3916	1.8442	2.1628	2.0957	1.1736
Min	.1341	.1174	.1341	.1341	.1174	.1174
Avg	.6418	.5134	.9696	.6371	.7684	.2238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 204 / 11 KV KHARSHING AG SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174			.6706	1.1736	.9892
2	.1341	.0671		.6706	1.1736	1.0059
3	.1509	.0838		.6706	1.2071	.9892
4	.1174	.0838		.8383	1.2574	.9892
5	.1341	.0838		1.0059	1.2071	1.0059
6	.1341	.0838		1.2574	1.3916	1.0395
7	.1509	.1341		1.4083	1.5089	1.1736
8	.1341	.0838		.1134	.1509	.1509
9	1.0898	1.358	.0671	.1341	.1341	1.5089
10	1.4922	1.1904	.0838	.1341	.1006	1.5424
11	1.5089	1.1736	.1006	.1174	.1006	1.6095
12	1.0898	1.0395		.1174	.1509	1.643
13	1.0898	1.1233		.1006	.1509	1.6095
14	1.1401	1.1736		.1006	.1174	1.643
15	1.2574	1.1736		.1174	.1341	1.6095
16	1.3748	1.358		.1174	.1341	1.6095
17	.0671	.1006		.1341		.1341
18		.1006		.1341	.1509	
19		.1844		.1509	.1844	.1341
20		.1844		.2012	.1844	.1341
21		.1677		.1677	.1844	.1509
22		.1174		1.2071	1.0562	.1509
23		.1006		1.1736	1.0898	.1509
24	.1341			.1341	1.1904	1.0898
Max	1.5089	1.358	.1006	1.4083	1.5089	1.643
Min	.0671	.0671	.0671	.1006	.1006	.1341
Avg	.6287	.5075	.0838	.4532	.6145	.9593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 205 / 11 KV SONI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0503	.0503
2	.0503	.0671	.0503
3	.0335	.0671	.0503
4	.0503	.0671	.0503
5	.0503	.0671	.0503
6	.0503	.0671	.0503
7	.0503	.0671	.0503
8	.0335	.0671	.0503
9	.0671	.0838	.0671
10	.0671	.0503	.0671
11	.0503	.0838	.0671
12	.0503	.0838	.0671
13	.0503	.0838	.0671
14	.0503	.0838	.0671
15	.0671	.0838	.0671
16	.0671	.0503	.0671
Max	.0671	.0838	.0671
Min	.0335	.0503	.0503
Avg	.0514	.0702	.0587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 201 / KHANDERAJURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477		.2477	1.9062	2.13	1.9826	1.6484
2	.2286		.2477	1.8515	2.13	1.9826	1.5684
3	.2286		.2096	1.8515	2.13	1.9826	1.5684
4	.2667		.2096	1.8351	2.13	2.0243	1.5364
5	.2858		.2667	1.7859	2.13	2.2996	1.6484
6	.4001		.381		2.1862	2.6397	1.8461
7	.362		.362	2.0885	2.4291	2.6871	1.3927
8	.3048		.3429	.2858	.2477	.3048	.2286
9	2.3967		.2477	.2286	.2477	.2096	2.3594
10	2.4615		.1905	.2286	.1905	.2286	1.8351
11	2.5425		.1905	.2477	.1524	.2667	2.4905
12	2.4615	1.3426	.0953	.2096		.2667	.9614
13	2.834	1.4419				.1905	1.7772
14	2.7692	1.2266			.1524	.1524	2.5194
15	2.834	1.9113	.1524		.1905	.1524	2.7328
16	1.1498	1.6766	.1524		.2477	.1715	2.6155
17	.2096	.1143	.1905		.2667	.2477	
18		.1524	.3048		.3048	.2858	
19		.1905	.4191		.3429	.3429	.3429
20		.362	.4382		.3429	.362	.3429
21			.4191		.3239	.3429	.3429
22		.3048	1.491		2.431	2.0317	.3048
23		.2858	1.8515		2.1963	1.9334	.2858
24	.3239		.2667		2.13	2.0153	.1733
Max	2.834	1.9113	1.8515	2.0885	2.431	2.6871	2.7328
Min	.2096	.1143	.0953	.2096	.1524	.1524	.1733
Avg	1.2393	.8190	.3944	1.1381	1.1379	1.0460	1.3873



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 202 / 11 KV Khatav

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.3765		.8848
2	1.4413		.852
3	1.6057		.8192
4	1.6876		.7956
5	1.8023		.8288
6	2.2348		.852
7	2.5263		1.0814
8	.2477		.1524
9	.2096		1.1142
10	.1905		1.3592
11			1.3441
12			1.4089
13			1.4251
14			1.6385
15			1.8896
16	.1905		1.8233
17	.2286		
19		.1905	
20		.2286	
21		.1905	
22		.9221	
23		.9614	
24	1.3435		.9448
Max	2.5263	.9614	1.8896
Min	.1905	.1905	.1524
Avg	1.1604	.4986	1.1302

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 203 / 11 KV Mallewadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575		.6554	.1334	.1334	.1334	.1334
2	1.5912		.7127	.1334	.1334	.1334	.1334
3	1.5729		.6226	.1334	.1334	.1334	.1334
4	1.6385		.6371	.1334	.1334	.1334	.1334
5	1.6712		.6874	.1524	.1334	.1524	.1524
6	1.8679		.8684		.1905	.1905	.1905
7	1.9826			.2096	.2286	.2286	.2096
8	.2096		.1524	.1715	.1715	.1524	.1715
9	.2096		.663	1.3765	1.9006	2.0645	.1143
10	.1905		1.4255	1.5384	1.9006	2.0153	.1334
11	.1715		1.6741	1.6964	1.9334	2.0645	.1143
12	.1715		1.6876			1.9109	.1143
13	.1715		1.4899			1.9433	.1334
14	.1905		1.3599		1.4091	1.9757	.1334
15	.1905	.0381	.1376		1.8023	1.9433	.0953
16	.1905	.0381	1.3765		1.9662	1.917	.0953
17	.1715	.0381			.1715	.1334	.0953
18		.8192	.1334		.1715	.1143	.1143
19		.1905	.1715			.1715	.1905
20		.2477	.2096		.1905	.1905	.2096
21		.2096	.2096		.2096	.2096	.1905
22			.1524		.1905	.1715	1.6575
23		.431	.1524		.1524	.1524	1.6057
24	1.704		.6133	.2096	.1334	.1334	.1524
Max	1.9826	.8192	1.6876	1.6964	1.9662	2.0645	1.6575
Min	.1715	.0381	.1334	.1334	.1334	.1143	.0953
Avg	.8641	.2515	.7178	.5353	.6376	.7654	.2670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 204 / 11 kv shivganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572		.0572	.0572	.0762	.0762	.0572
2	.0572		.0572	.0572	.0572	.0762	.0572
3	.0572		.0572	.0572	.0572	.0572	.0572
4	.0762		.0572	.0572	.0572	.0572	.0953
5	.0762		.0572	.0572	.0572	.0572	.0953
6	.0762		.0762		.0572	.0572	.0762
7	.0762		.0762	.0572	.0762	.0572	.0762
8	.0762		.0762	.0762	.0762	.0572	.0762
9	.0762		.0572	.0572	.0953	.1715	.0381
10	.1905		.0572	.0953	.1905	.1905	.1905
11	.3048		.0953	.0572	.2858	.2477	.3048
12	.1143		.1524	.0762		.2477	.0381
13	.0572		.0953			.1905	.0762
14	2.7692		.2477		.0381	.1715	.0762
15	.1524		.0381		.0953	.1143	.2667
16	.1715	.1715	.2286		.0762	.0572	.2096
17	.0953	.1715	.1905		.0381	.1715	.1143
18		.1334	.1524		.1334	.1524	.0381
19		.0572	.0572		.1143	.1905	.0762
20		.1905	.0953		.1143	.0572	.0572
21		.1905	.1524		.0953	.0953	.0572
22		.0762	.0572		.0953	.0762	.0572
23		.0572	.0572		.0572	.0762	.0572
24	.0572		.0762	.0572	.0762	.0572	.0762
Max	2.7692	.1905	.2477	.0953	.2858	.2477	.3048
Min	.0572	.0572	.0381	.0572	.0381	.0572	.0381
Avg	.2523	.131	.0969	.0635	.0918	.1151	.0969

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 205 / 11KV Salgare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0572	.2713	.6001	.583	.6882
2	.0762		.0572	.2683	.6001	.583	.6722
3	.0762		.0572	.2683	.6001	.583	.6722
4	.0762		.0762	.2683	.6001	.5898	.6401
5	.1143		.0762	.3018	.6068	.6554	.6964
6	.1715		.1143	.373	.6935	.8192	.8421
7	.1143		.1143	.7461	1.0923	1.0322	1.1012
8	.0953		.0762	.1334	.1334	.1524	.1715
9	.7619		.0572	.0953	.1143	.1524	1.1174
10	.9259		.0572	.0953	.1143	.1334	1.278
11	1.0288		.0572	.0762	.1143		1.3603
12	.9339		.0572	.0953			1.3927
13	.9503		.1334				1.3426
14	.9221		.1334		.2667		1.3748
15	.8848		.1334		.1905	.1524	1.4754
16	.8684	.3224	.0953		.1334	.1715	1.326
17	.0953	.0762			.1334	.1715	.1524
18		.0572	.1334		.1905	.1715	.1524
19			.1715		.2096	.2096	.2096
20		.0762	.1715		.2096	.2286	.2096
21		.0762	.1905		.2286	.2286	.1905
22		.0762	.4696		.8002	.8421	.1715
23		.0572	.3077		.724	.7449	.1334
24	.0762		.0572	.2713	.6001	.6668	.7042
Max	1.0288	.3224	.4696	.7461	1.0923	1.0322	1.4754
Min	.0762	.0572	.0572	.0762	.1143	.1334	.1334
Avg	.4582	.1059	.1241	.2511	.4071	.4436	.7531

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 206 / Salgare gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1715	.1905	.1715	.1905	.1905
2	.1715		.1715	.1905	.1715	.1905	.1905
3	.1715	.1524	.1715	.1905	.1715	.1905	.1905
4		.1524	.2096	.1905	.1715	.2096	.1905
5	.2477	.1715	.2286	.2286	.1715	.2477	.2286
6	.3326	.1905	.2858		.2096	.3048	.3429
7	.2957	.2477	.3511	.3239	.2667	.2667	.2858
8	.2667	.1905	.2858	.2858	.2477	.1715	.2858
9	.2286	.1905	.1905	.2477	.2667	.2667	.2286
10	.2286	.1524	.1905	.2477	.2858	.2286	.2667
11	.2477		.2286	.2477	.3048	.2096	.1524
12	.2858	.3239	.1905	.2477		.3048	.1905
13	.2858	.3292	.2477			.2667	.1524
14	.2477	.2667	.1905		.1715	.1905	.1524
15	.2858	.2667	.1524		.1905	.2096	.1524
16	.2477	.2477	.2286		.2096	.2286	.1715
17	.2667	.2667	.2328		.3048	.2858	.2286
18		.2096	.181		.3048	.2858	.2286
19		.1848	.2096		.3239	.2858	.3429
20		.3547	.3239		.3429	.381	.4191
21		.3239	.3048		.3239	.2477	.2286
22		.2477	.2477		.2858	.2477	.2096
23		.1905	.2286		.2477	.2286	.1905
24	.1524	.1524	.1905	.2858	.1715	.1905	.1905
Max	.3326	.3547	.3511	.3239	.3429	.381	.4191
Min	.1524	.1524	.1524	.1905	.1715	.1715	.1524
Avg	.2421	.2257	.2256	.2397	.2416	.2429	.2254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 201 / 11 Kv Arag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
10		.1524	.1143
11		.1715	.1715
12		.1905	.2096
13		.2096	
24	.1715		
Max	.1715	.2096	.2096
Min	.1715	.1524	.1143
Avg	.1715	.181	.1651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 202 / 11 KV Bedag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3201	.3658	.442	.4572	.3887	.3277
2		.3048	.3506	.4115	.4268	.3734	.3201
3		.3048	.3506	.3963	.4115	.3658	.3201
4		.3277	.3582	.4191	.4268	.3658	.3353
5		.381	.4191	.4572	.442	.4039	.3582
6		.3963	.442	.4572	.4649	.4268	.381
7		.3353	.3887	.381	.4725	.3887	.3353
8		.3125	.3506	.3582	.4115	.3582	.2972
9		.3125	.3734	.3658	.3887	.3506	.3277
10		.3506	.6958	.8354	.3963	.3582	.3353
11		.3506	.6882	.8029	.4191	.3582	.3429
12		.3582	.7545	.8551	.4344	.3658	.3658
13		.3353	.7796	.8495	.4344	.381	.3658
14		.2972	.4191	.442	.442	.3734	.3887
15		.381	.4191	.442	.4191	.3734	.381
16		.381	.4344	.4725	.4191	.381	.381
17		.3734	.4344	.4649	.3963	.381	.4115
18		.3658	.4344	.503	.4344	.4191	.4496
19		.4954	.5411	.5944	.5411	.5411	.5411
20		.4954	.5563	.5716	.5106	.503	.5106
21		.4725	.5487	.5487	.4877	.4725	.4801
22		.4725	.5335	.5411	.4877	.442	.442
23		.4115	.4954	.5182	.4801	.3963	.3734
24	.3048		.7621				
Max	.3048	.4954	.7796	.8551	.5411	.5411	.5411
Min	.3048	.2972	.3506	.3582	.3887	.3506	.2972
Avg	.3048	.3711	.4957	.5274	.4437	.3986	.3814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 203 / 11 KV Vijaynagar  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	04-APR-17
HR	Load (MW)	Load (MW)
10		.1143
11		.1143
12		.1905
24	.2477	
Max	.2477	.1905
Min	.2477	.1143
Avg	.2477	.1397



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 204 / 11 KV Bedag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
10		.2096	.2477
11		.2096	.2477
12		.1715	.1905
13		.1715	
24	.2096		
Max	.2096	.2096	.2477
Min	.2096	.1715	.1905
Avg	.2096	.1906	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 205 / 11 KV rade ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5149	1.7375	2.1795	.3582	.381	.381	.3506
2	2.5072	1.6613	2.1338	.3506	.3734	.381	.3429
3	2.4996	1.6232	2.1033	.3429	.3658	.381	.3429
4	2.492	1.669	2.1338	.3658	.3734	.3734	.3429
5	2.5987	1.768	2.1795	.3963	.381	.3429	.3582
6	2.9721	2.4234	2.492	.4268	.3963	.4039	.3963
7	1.4251	1.2651	1.166	.3963	.3963	.2515	.4268
8	.3353	.3048	2.0881	2.6901	2.8121	2.5072	.3658
9	.2058	.3277	2.9492	3.1398	3.0407	2.7664	.3353
10	.2134	.3125	5.4047	6.0795	3.1703	2.9492	.2591
11	.2362	.282	5.5022	5.3414	2.9569	2.7587	.2743
12	.2515	.2972	5.3803	.588	2.8959	2.8883	.1905
13	.2896	.3048	5.2919	.2591	2.9645	2.9264	.221
14	.2972	.2743	2.9797	.541	2.9874	3.0559	.2134
15	.2515	.282	3.0636	1.5394	3.0712	3.1474	.2439
16	.2515	.2896	2.332	1.6004	1.3946	1.1431	.2515
17	.2743	.3125	.2439	.282	.2972	.2896	.2286
18	.3125	.3277	.3277	.3277	.3125	.3277	.2058
19	.2515	.4115	.4649	.4649	.442	.4725	.4344
20	.2515	.4344	.4725	.4801	.4496	.4801	.4572
21	1.8595	2.1719	.442	.4725	.4268	.4572	2.6978
22	1.8671	2.3396	.3963	.442	.4191	.4115	2.8578
23	1.8442	2.3701	.3582	.4115	.3963	.3734	2.7435
24	.7621						
Max	2.9721	2.4234	5.5022	6.0795	3.1703	3.1474	2.8578
Min	.2058	.2743	.2439	.2591	.2972	.2515	.1905
Avg	1.1152	1.0083	2.2646	1.1868	1.3350	1.2813	.6322

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 206 / 11 Kv Bolwad Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
10		2.1125	2.2405
11		2.1765	2.5606
12		2.1445	.192
13		2.1445	
24	1.9966		
Max	1.9966	2.1765	2.5606
Min	1.9966	2.1125	.192
Avg	1.9966	2.1445	1.6644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 201 / 11 kv Erandoli Gav.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3018	.4024	.3961	.3772	.4108	
2	.3772	.2829	.4024	.3961	.3772	.3584	
3	.3584	.2829		.3772	.3395	.4066	
4	.3584	.3018	.4481	.3961	.3395	.4207	
5	.415	.3584		.4338	.3961	.4163	
6	.4904	.4854	.4904	.4715	.4715	.4477	
7	.4525	.4938	.4024	.4066	.4207	.5014	
8	.4163	.3898	.4119	.4252	.4525	.394	
9	.4334	.3641	.4031	.3721	.3582	.3898	
10		.463	.5138	.4409	.5375		.3761
11		.5083	.5316	.3988	.4755		.5028
12		.5552	.4801	.3688	.5028		.5083
13		.5014	.3898	.3988	.5258		.5201
14		.4207	.3898		.4252		.4784
15		.4435	.4119		.4119		.4477
16		.4668	.4161		.4557		.4477
17		.5121	.4748		.5014		.4801
18		.5731	.5138		.5304		.4748
19		.57	.6661		.6661		.567
20		.5935	.7164		.6556		.6805
21		.6036	.6626		.6626		.6154
22		.5426	.6401		.5853		.567
23			.5175		.4805		.4668
24	.4683	.3361	.4066	.4294	.4108	.4108	
Max	.4904	.6036	.7164	.4715	.6661	.5014	.6805
Min	.3584	.2829	.3898	.3688	.3395	.3584	.3761
Avg	.4143	.4500	.4860	.4080	.4733	.4157	.5095

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 203 / 11 KV Takali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5414	.4085	.4534	2.7858	1.653	2.982	1.515
2	.5399	.4134	.25	2.6521	1.6049	3.0214	1.4266
3	.5371	.4096	.4424	2.6353	2.9546	2.7984	1.4038
4	.5227	.4127	.4764	2.6162	2.9401	3.0005	1.3123
5	.5531	.4476	.2484	2.6844	3.0517	2.616	1.3245
6	.5651	.4878	.5357	3.0856	1.6743	3.3547	1.387
7	.554	.4817	.4937	3.8851	4.0123	3.5014	1.5661
8	.5022	.4298	.4784	1.097	1.2068	2.845	.8307
9	3.8828	2.9912	.4389	.4363	.5323	.4157	1.954
10	2.383	1.784	.3757	.4184	.4337	.2096	4.3065
11	2.3571	3.4043	.3726	.4436	.4134	.2141	4.402
12	2.3122	3.5069	.4113	.3963	.4081	.2256	4.3564
13	2.3365	3.4947	.4304	.397	.3528	.2187	4.0592
14	2.3198	1.8153	.4342	.2233	.4045	.2317	4.0459
15	2.3548	1.8991	.501	.218	.4213	.2401	4.1434
16	2.162	4.0017	.5144	.2683	.4367	.2157	4.055
17	.8406	1.5425	.5099	.3094	.4755	.2401	1.1599
18	.3437	.4106	.5853	.3384	.5655	.2919	.6051
19	.3574	.4702	.6965	.3711	.7141	.317	.6226
20	.3246	.6546	.7697	.4031	.7951	.346	.6748
21	.1943	.3445	.7651	.4001	.7811	.3368	.6672
22	.2515	.6234	3.2114	1.8816	3.5427	1.6187	.6325
23	.2378	.5251	3.2023	1.989	3.5803	1.6857	.5872
24	.5804	.4481	1.8723	3.1389	3.2891	2.8464	.2865
Max	3.8828	4.0017	3.2114	3.8851	4.0123	3.5014	4.402
Min	.1943	.3445	.2484	.218	.3528	.2096	.2865
Avg	1.1481	1.3086	.7696	1.3781	1.5102	1.4072	1.9718

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 204 / 11 kv Erandoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6677		4.0945	.5788	.6917	.5885	.3414
2	4.4924		3.9565	.5753	.6516	.6454	.3307
3	4.4246		1.9334	.5708	.6455	.5948	.333
4	4.3393		3.7692	.5731	.6447	.6851	.3246
5	4.5057		1.9265	.6028	.727	.6403	.3323
6	4.9303		3.8123	.6637	.8184	.7568	.3734
7	5.0592		2.3693	.6497	.7652	.7459	.3856
8	2.2354		2.3948	.5788	.5967	.6173	.3849
9	.4567		4.7302	4.5576	6.0029	2.968	.3536
10	.2248		5.5914	5.602	6.243	3.4469	.5372
11	.2058	.2408	5.2647	5.8823	2.6818	2.6528	.5603
12	.2233	3.6778	5.2845	2.3883	6.0166	3.3234	.5801
13	.2683	1.5944	4.4841	.53	6.3169	3.3554	.6353
14	.282	.458	4.9543	.2667	6.1599	2.6787	.6318
15	.2622	.4396	5.0327	.2507	6.1885	3.014	.6748
16	.2797	.5502	4.4208	.9556	6.1195	3.3981	.6597
17	.2629	.2347	1.8107	2.6398	3.3677	2.7054	.655
18	.2583	.4434	.5	.2926	.5291	.3048	.6771
19	.2462	.2789	.651	.3155	.744	.3551	.7884
20	.2789	.7377	.8122	.4649	.9196	.4672	.9751
21		.7415	.8206	.4915	.9463	.4915	1.0117
22	1.3329	4.2324	.7655	.4786	.9175	.4969	5.3155
23	.9465	4.4868	.6912	.4496	.8078	.4496	5.5291
24	2.1956	2.4287	2.2531	.6594	.716	.6274	2.9279
Max	5.0592	4.4868	5.5914	5.8823	6.3169	3.4469	5.5291
Min	.2058	.2347	.5	.2507	.5291	.3048	.3246
Avg	1.8426	1.4675	3.0135	1.2924	2.5091	1.5004	1.0549

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 205 / 11 kv VEDANT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	06-APR-17
HR	Load (MW)
8	.4557
Max	.4557
Min	.4557
Avg	.4557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 206 / 11 KV VanKochiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9754	2.6365	3.4138	.4801	.2591	.6173	.2896
2	3.8553	2.6365	1.6232	.4801	.2515	.5983	.2896
3	3.8378	1.5394	2.2541	.4801	.2439	.5906	.2743
4	3.7704	1.9795	1.166	.4877	.2515	.6059	.3048
5	4.1194	2.0881	2.3701	.5639	.3048	.6897	.3429
6	4.0495	2.7854	2.866	.7049	.3658	.8345	.3963
7	3.9228	2.572	1.105	.663	.3429	.7392	.3734
8	.4687	.442	2.0216	2.1453	2.6787	2.572	.2743
9	.4077	.3658	4.1266	4.9184	4.8926	5.3898	.2362
10	.2134	.0838	4.7508	5.3448	5.176	2.7968	.4496
11	.16	.3658	4.2665	5.2588	5.1659	2.2786	.2972
12	.2134	.3582	3.0981	.1372	5.045	2.8654	.0457
13	.2134	.4077	4.3286	.3544	5.0251	1.3336	.3239
14	.2362	.4001	4.4963	.1905	5.1697	2.9264	.381
15	.221	.423	4.7601	1.2346	5.4888	3.0483	.4154
16	.2134	.4687	3.2258	1.5013	4.2333	1.6537	.3963
17	.2362	.2362	.5601	.2286	.5678	.2362	.0229
18	.2134	.4458	.5334	.2515	.5487	.282	.522
19		.381	.7468	.4115	.9221	.3582	.7964
20	.0914	.8497	.8154	.4115	.9335	.3963	.8382
21	1.0822	1.9433	.7544	.4191	.8306	.3734	2.8388
22	1.1431	3.6564	.644	.3353	.7735	.3353	4.9939
23	.9755	3.7372	.5182	.2743	.6782	.3125	4.8141
24	1.8515	1.7372	.2477	.2477		.2858	
Max	4.1194	3.7372	4.7601	5.3448	5.4888	5.3898	4.9939
Min	.0914	.0838	.2477	.1372	.2439	.2362	.0229
Avg	1.5422	1.3558	2.2789	1.1469	2.1804	1.3383	.8659



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 201 / 11 KV lignoor gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2593	.2585	.3094	.3223	.2697	.1463	.3079
2	.2631	.2454	.3041	.3079	.2348	.1395	.2806
3	.2616	.2263	.2934	.1562	.2321	.1364	.2791
4	.2608	.2271	.2866	.144	.2313	.1303	.2435
5	.2646	.2229	.2873	.1524	.2529	.1349	.2431
6	.276	.2336	.2926	.1623	.2661	.1425	.2652
7	.2454	.2306	.2454	.1349	.2439	.1463	.2195
8	.2245	.226	.2282	.1196	.2096	.1204	.2015
9	.279	.1494	.2549	.1265	.2115	.1417	.24
10	.3666		.3719	.1905	.33	.3422	.2851
11	.3494		.4199	.1974	.3673	.4049	.269
12	.3314		.4031	.176	.1974	.4241	.4344
13	.3119	.2736	.3959	.1959		.3799	.4089
14	.317	.2843	.3422	.1738	.3494	.3738	.362
15	.2928	.2698	.3231	.157	.3285	.3239	.3641
16	.2745	.2218	.3071	.1334	.2736	.2788	.3397
17	.3041	.1753	.1448	.1364	.2738	.2481	.3451
18	.1776	.4058	.2911	.1296	.2766	.2339	.3307
19		.4281	.3892	.1677	.3944	.3124	.383
20		.4901	.5289	.2522	.5576	.5244	.5792
21		.5465	.4962	.2576	.2812	.4401	.5434
22		.4885	.4732	.2218	.2408	.397	.4915
23	.2782	.3993	.3856	.1913	.2088	.3742	.439
24	.1578	.3673	.1875	.3193	.3504	.1753	.3475
Max	.3666	.5465	.5289	.3223	.5576	.5244	.5792
Min	.1578	.1494	.1448	.1196	.1974	.1204	.2015
Avg	.2748	.3033	.3317	.1886	.2862	.2696	.3418

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 202 / 11 KV Shindewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6635	.1457	.9289	.1639	.1791	.0762	.1818
2	2.593	.1457	.823	.1639	.1791	.0686	.1818
3	2.5854	.1653	.8154	.061	.1715	.0686	.1742
4	2.5778	.1653	.8908	.061	.1715	.0686	.1742
5	2.6082	.184	.8603	.061	.1829	.0686	.1894
6	2.9024	.184	.913	.061	.1753	.061	.2158
7	2.6353	.1724	.6705	.061	.1563	.0686	.2104
8	.18	.1444	.9322	1.1355	1.4929	1.3336	.1719
9	.1596		1.0974	1.3641	1.7832	1.4022	.2088
10	.1284		1.1355	1.4403	1.7669	1.4834	.061
11	.1135		1.7577	1.4098	1.5927	1.5615	.0686
12	.1391	.0381	1.3565	.061		.9899	.0686
13	.1742	.0457	1.1088	.0686		1.8328	.0686
14	.1818	.0533	1.0845	.0686	1.6229	1.688	.061
15	.1894	.0381	1.3359	.0686	1.6903	1.6038	.061
16	.202	.8612	1.3794	.061	1.8974	1.668	.0457
17	.1993	.4191	.0457	.0686	.1418	.0751	.1813
18	.0457	.0381	.1665	.0533	.1467	.1456	.2195
19		.2082	.2158	.0914	.197	.2145	.2934
20		.2058	.2362	.0991	.2034	.2652	.2553
21		.9779	.2172	.0914	.0914	.2275	1.5814
22	.0076	1.0601	.1981	.0838	.0914	.1715	1.768
23	.1642	1.0403	.1629	.0762	.0838	.202	1.8214
24		.0943		.0943	.0953		.1132
Max	2.9024	1.0601	1.7577	1.4403	1.8974	1.8328	1.8214
Min	.0076	.0381	.0457	.0533	.0838	.061	.0457
Avg	1.0225	.3041	.7971	.2904	.6415	.6672	.3490

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 203 / 11Kv Landgewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.0381	.7293	.0572	.0762		.0572
2	.9945	.0381	.6962	.0572	.0762		.0572
3	.9945	.0381	.6962		.0762		.0572
4	.9945	.0572	.6962		.0762		.0572
5	.9945	.0572	.6962		.0762		.0572
6	.9779	.0572	.6962		.0762		.0762
7	1.0774	.0572	.779		.0572		.0572
8	.056	.0381	.0566		.0572		.0572
9	.0572		.8785		1.2163		.0572
10	.0381		1.0159		1.3599	1.0722	.0762
11	.0572		.0429		1.3603	1.2003	.0762
12	.0381		.0762			1.2483	.0572
13	.0572		.0572			.0381	.0572
14	.0572		.0572		.1143	.0381	.0572
15	.0762		.0762		.0953	.0572	.0572
16	.0762		.9335		.0762	.0572	.0572
17	.0572				.0572	.0381	.0572
18		.0572	.0572		.0572	.0572	.0762
19			.0762		.0762	.0762	.0762
20		.0747	.0762		.0953	.0953	.1132
21		.0747	.0762			.0953	.1132
22		.8453	.0762			.0572	1.4752
23	.0381	.8122	.0762			.0572	1.5249
24		.779		.0572	.0762		.0572
Max	1.0774	.8453	1.0159	.0572	1.3603	1.2483	1.5249
Min	.0381	.0381	.0429	.0572	.0572	.0381	.0572
Avg	.4243	.2160	.3919	.0572	.2714	.2991	.1861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 204 / 11 kv Lingnoor

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.4398	.4382	.3618	.4117	.1837	.33
2	.6879	.4519	.4321	.4144	.6343	.1844	.3087
3	.6841	.439	.4267	1.7208	4.1213	2.2184	3.6176
4	.6803	.4436	.4359	1.8724	4.3126	2.3762	3.7822
5	.6803	.4215	.4671	1.9433	4.5183	2.5934	3.8416
6	.8802	.4658	.4944	2.1597	4.8007	2.6505	3.964
7	.4588	.455	.4915	2.6558	4.6441	2.745	3.637
8	.9789	.4306	.5297	.189	.3593	.471	.3753
9	6.6864		.5348	.1882	.4165	.1456	.3512
10	6.1523		.2187	.1875	.4443	.276	
11	6.1283			.1791	.3902	.3428	
12	6.1702			.048	.1692	.3481	.0526
13	5.3803		.3681			.3784	3.8868
14	5.9469	.0518	.3993	.0434	.3237	.3399	5.0919
15	5.9541	1.217	.3852	.2134	.3799	.3692	4.9451
16	6.1827	1.1888	.458	.2263	.4511	.386	4.5935
17	.4451	.0046	.2362	.221	.4648	.373	.3934
18	.2568	.0739	.4054	.2462	.4952	.3361	.4635
19		1.8287	.4923	.2667	.58	.442	.564
20		.6165	.5716	.3125	.3909	.567	.6529
21		1.6259	.5731	.3079	.3239	.4824	.5999
22		.5112	.4885	.3056	.2827	.4302	.5449
23	.032	.4725	.4511	.2774	.2111	.3649	.5114
24	.1928	.4557	.2088	.4226	.4092	.1821	.4038
Max	6.6864	1.8287	.5731	2.6558	4.8007	2.745	5.0919
Min	.032	.0046	.2088	.0434	.1692	.1456	.0526
Avg	2.7648	.6102	.4321	.6419	1.2841	.7994	1.9505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 205 / 11 KV Khatav ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	***	.2987	1.4918	1.5402		1.7695
2	.3772	***	.2987	1.4746	1.4091		1.704
3	.3772		.2987		.3018		.3018
4	.3772		.2987		.3018		.3018
5	.3772		.0373		.3018		.3206
6	.3961		.4108		.3395	***	.3772
7	.3395		.3395	***	***		***
8	.1867		.3395		.2829		.2614
9	1.8233		.3361		.2829		2.2211
10	1.8564		.2058		.1886	.3361	2.1216
11	1.8399		.2641		.2641	.3395	1.7901
12	1.6907		.3547			.2829	2.0885
13	2.0645		.2987			.3395	
14	1.5402		.2957		***	.3547	
15	2.0388		.3361		.3018	.2801	
16	2.0056		.3361		.3772	.3696	
17	.2641				.415	.4294	.3018
18		.1459	.3475			.3696	.3395
19		.3734	.4338		.4854	.4338	.4904
20		.4527	.5093		.4527	.4904	.5281
21		.4108	.4904			.4527	.5093
22		.3772	1.8399			1.5912	.5093
23	***	.3395	1.6575			1.8896	.4715
24	***	.3395		1.4746	1.6907		1.8679
Max	152.6235	152.6046	1.8399	76.208	152.6801	76.208	76.208
Min	.1867	.1459	.0373	1.4746	.1886	.2801	.2614
Avg	16.9985	34.1622	.4558	20.1623	13.2124	5.6111	4.7242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 201 / 11 KV Arag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6355	.6611	.6868	.6386	.6202	.6569	.6559
2	.6158	.6354	.6792	.6127	.6021	.6459	.6036
3	.6005	.643	.6459	.6051	.5944	.6202	.6173
4	.5929	.6687	.6459	.5898	.5944	.584	.6202
5	.2972	.7021	.6973	.5974	.5944	.5554	.6354
6	.3353	.7278	.8124	.6569	.6501	.6221	.7392
7	.6577	.6647	.8061	.6767	.7213	.7691	.7419
8	.7154	.6322	.7757	.6577	.6213	.768	.6792
9	.6618		.694	.6872	.655	.7049	.709
10	.7743		.7785	.714	.6916	.7539	.805
11	.908		.8166	.7568	.7608	.7506	.805
12	.9711	.4725	.8375	.76		.7953	.9459
13	.9431	.9561	.8802	.3658		.8855	.8431
14	.8124	.8623	.8222	.4039	.9561	.8703	.7648
15	.8179	.887	.7819	.4115	.9002	.8334	.8246
16	.8459	.8973	.772	.4344	.9049	.7833	.8398
17	.8516	.8869	.503	.381	.8973	.8181	.7724
18	.4039	.9536	.9865	.4191	.9326	.9097	.8082
19		1.1736	1.1546	.5411	1.1721	1.0722	1.0286
20		1.2056	1.2479	.5563	1.1873	1.1607	1.0452
21	.3201	1.1462	1.1751	.5182	1.0456	1.0917	.9738
22	.9507	.9815	.9533	.4572	.9221	.9917	.8215
23	.8021	.8063	.7903	.4115	.7834	.831	.743
24	.3077	.3439	.3439	.362	.3258	.3658	.3761
Max	.9711	1.2056	1.2479	.76	1.1873	1.1607	1.0452
Min	.2972	.3439	.3439	.362	.3258	.3658	.3761
Avg	.6737	.8051	.8036	.5506	.7788	.7850	.7666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 202 / Arag mix Laxmiwadi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0588	.6824	.988	.5649	.7659	.7053	.743
2	3.8209	.6483	.9726	.5308	.7735	.6977	.7166
3	3.7855	.6824	.9726	.5496	.7582	.6824	.7166
4	1.9281	.7582	.9955	.5496	.7318	.6712	.7278
5	1.9281	.7848	1.0183	.5572	.7166	.6335	.7506
6	2.2634	.8983	1.0753	.6443	.8072	.6977	.8377
7	4.9626	.3201	1.1568	.599	.7358	.7394	.7663
8	.6559		.5689	.6331	.6635	.7049	.2515
9	.652		4.5435	4.4897	4.8369	5.249	.2532
10	.7013		5.0421	5.0183	5.7666	5.0928	.5533
11	.6977		5.063	5.3231	5.5026	5.141	.5043
12	.1067		5.0183	1.8214	2.7968	5.1563	1.8108
13		.8871	4.7992			4.4124	.542
14	.0305	3.0677	5.0307		4.0609	5.4077	.652
15	.743	.6828	5.407		5.5818	5.6242	.6483
16	.7659	.7053	5.6023	2.6368	5.3403	5.7919	.6635
17	.8113	.7053	.2058	.6325	.6143	.6102	.5721
18	.4039	.7467	.652	.3353	.7314	.6861	1.9402
19		.9244	.8148	.381	.8261	.7503	.7575
20		.723	.9858	.5106	1.001	.9248	.9781
21		1.0199	.891	.5106	.9781	.9211	.9063
22	.739	4.0215	.743	.4801	.9592	.9099	4.843
23	.6748	4.1511	.6295	.4344	.8758	.8229	5.0425
24	2.3998	1.3683	.7305	.6792	.7506	.7659	2.953
Max	4.9626	4.1511	5.6023	5.3231	5.7666	5.7919	5.0425
Min	.0305	.3201	.2058	.3353	.6143	.6102	.2515
Avg	1.6065	1.2515	2.2461	1.3277	2.0250	2.2416	1.2138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 203 / 11 KvAshoknagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1132	.1509	2.1464	2.1956	1.7604	2.0729
2	.1509	.1132	.1509	2.0388	2.0729	2.2119	2.0153
3	.1698	.1132	.1509	2.0222	2.0005	2.2119	1.9826
4	.1698	.1132	.1509	2.0222	1.9044	2.2119	1.9826
5	.1698	.132	.1509	1.989	1.9757	2.3266	1.9989
6	.1698	.1509	.1698	2.2874	2.6658	2.5692	2.17
7	.1698		.1698	2.5526	2.7035	2.6852	1.2955
8	.1132		.1509	.1509	.132	.1698	.1509
9	2.2186		.1509	.1509	.1132	.1132	2.3967
10	2.3525		.132	.1698	.1132	.1698	3.1855
11	2.4777		.1509	.1698	.132	.1509	1.8442
12	2.2834		.1509	.132		.1509	
13	1.9919	1.9989	.1509			.1132	2.0056
14	2.1125		.1509		.132	.132	2.2131
15	2.0317	1.9433	.1698		.132	.1698	2.3304
16	1.9919	1.9989	.1509		.132	.1509	1.9616
17	.1132	.132			.1509	.1509	.1509
18			.1509		.2075	.1698	.3772
19		.2263	.1886		.2452	.2075	.2452
20		.2263	.1886		.2452	.2263	.2452
21		.2263	.2075		.2263	.2263	.2452
22	.132	.1886	2.2939		2.536	2.4086	.2075
23	.1132	.1509	2.4577		2.5396	2.3482	.1886
24	.1698	.1132	.1509	2.3266	2.3266	2.2939	2.2672
Max	2.4777	1.9989	2.4577	2.5526	2.7035	2.6852	3.1855
Min	.1132	.1132	.132	.132	.1132	.1132	.1509
Avg	.9626	.4963	.3518	1.3968	1.1310	1.0554	1.4579



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 204 / railway station Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2722	.1995	.2344	1.9309	1.9643	2.0618	2.0858
2	.2722	.1987	.2139	1.864	1.842	2.0367	2.0621
3	.2715	.1972	.2117	1.8374	1.8031	1.9155	2.0009
4	.2692	.1964	.2117	1.8052	1.7985	1.8781	1.9532
5	.2646	.1979	.2336	1.8181	1.8458	1.9555	1.9365
6	.2852	.229	.192	2.0378	2.0599	2.4292	2.1087
7	.2875	.0907	.1949	2.4827	2.4036	2.7218	2.3028
8	.2985		.0815	.195	.2755	.2776	.2717
9	2.4269		.1585	.1249	.2254	.1653	2.5766
10	2.2858		.1038	.1447	.2018	.1752	1.6998
11	2.5242		.065	.17	.1979	.1402	2.2989
12	2.6782		.0581	.194	.093	.1732	2.5938
13	2.7369	1.4805	.0574	.0823		.1366	2.5578
14	2.6338	.1974	.0754	.0869	.1926	.0807	2.6878
15	2.4067	2.2386	.0754	.0884	.1941	.1066	2.7213
16	2.3007	2.3823	.0635	.0907	.2237	.1819	2.2444
17	.0868	.1592	.077	.0991	.2239	.1745	.1979
18	.093	.1608	.1644	.1128	.273	.1964	.1949
19		.185	.2524	.1257	.3639	.2768	.0766
20		.2965	.3443	.1547	.3776	.3428	.3375
21		.301	.4091	.1654	.4175	.421	.33
22	.2153	.2745	2.1422	1.0852	2.2279	2.3289	.3269
23	.2094	.2458	2.1513	1.1767	2.2878	2.3626	.2958
24	.2402	.2185	1.2418	2.0553	2.191	2.1902	1.1749
Max	2.7369	2.3823	2.1513	2.4827	2.4036	2.7218	2.7213
Min	.0868	.0907	.0574	.0823	.093	.0807	.0766
Avg	1.0980	.4973	.3756	.8303	1.0297	1.0304	1.5432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 205 / Malwadi Ag feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9182	.217	2.9492	.2737	.2951	.292	.3702
2	3.8221	.2162	2.87	.2654	.2882	.2882	.3679
3	3.7771	.204	2.8418	.2646	.2867	.2859	.3346
4	3.7689	.2025	2.8395	.2638	.314	.2859	.3384
5	3.8177	.2139	2.8601	.276	.314	.2748	.3519
6	4.3945	.2821	2.9927	.3344	.3791	.321	.4171
7	5.0138	.1318	3.3882	.3285	.3771	.3664	.4323
8	.4648		.4876	.3003	.3814	.3669	.4323
9	.4549		3.8409	3.5159	4.622	4.8758	.4641
10	.3399		4.2044	4.5537	5.1824	5.0301	.41
11	.3443		4.4122	5.0432	5.3266	4.8771	.4016
12	.0511		4.446	2.6132		4.9502	.3936
13		.4706	4.3016			5.1448	.3718
14	.0206	2.5975	4.3115		.6249	5.3825	.3601
15	.3557	.2949	4.3515		1.9281	5.4938	.3088
16	.4392	.2768	4.3279	2.0576	3.922	5.4609	.339
17	.4891	.3186	.3425	.3788	.2385	.4157	.3875
18	.2545	.3399	.1844	.1966	.3921	.4558	.3733
19		.3397	.3988	.1997	.4473	.4997	.4171
20		.4012	.4709	.2515	.4923	.543	.5127
21		.4389	.4187	.2378	.4709	.5226	.579
22	.3799	2.9885	.371	.208	.3982	.2439	4.4224
23	.2946	3.0739	.3269	.1913	.3596	.4422	5.1202
24	1.9631	1.722	1.4818	.2951	.2958	.3317	2.8254
Max	5.0138	3.0739	4.446	5.0432	5.3266	5.4938	5.1202
Min	.0206	.1318	.1844	.1913	.2385	.2439	.3088
Avg	1.7182	.7753	2.4758	1.0500	1.2426	1.9646	.8638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 202 / 11 KV BHIVARGI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 203 / 11 KV ANKALGI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 204 / 11 KV SANKH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 205 / 11 KV ANKALGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 206 / 11 KV ASANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 207 / 11 KV SANKH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 201 / 11 KV AKKALWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.0953	.0762	.9717	.8907	.9602	.8907
2	.1334	.0953	.0762	1.0402	.9012	1.0159	.9012
3	.1334	.0953	.0762	1.0526	1.0059	1.065	.9717
4	.1334	.1143	.0953	1.1469	1.0774	1.2574	.9831
5	.1524	.1143	.0953	1.3108	1.2574	1.3413	1.0774
6	.2096	.1143	.0953	1.4413	1.3717	1.3904	1.1736
7	.2096	.1334	.1334	1.4413	1.3413	1.4089	1.1869
8	.1334	.1334		.1524	.1524	.1143	.0953
9	.9116	1.1336	.0953	.1143	.0953	.1334	.9488
10	1.2431	1.1012	.1524	.1334	.1334	.1143	.8002
11	1.2289		.1524	.1143	.0953	.1334	.9602
12	1.0526		.1334	.0953	.1524	.1143	.9488
13	1.012		.1143		.1143	.1334	.9488
14	1.0202		.1334		.0953	.1334	.9374
15	1.004		.1334		.0953	.1334	.9488
16	.9878		.0953		.1143	.1143	.9804
17	.0953		.1143		.1143	.1334	.1143
18	.1143		.1334		.1334	.1334	.1143
19	.1334		.1715		.1524	.2096	.1524
20	.1715		.1715		.1905	.1524	.1715
21	.1715		.1524		.1715	.1715	.1334
22	.1524		1.1603		1.065	1.0774	.1334
23	.0953	.0953	.9945		.9602	.9831	.1143
24	.1334	.0953	.0953	.9717	.8802	.9602	.9602
Max	1.2431	1.1336	1.1603	1.4413	1.3717	1.4089	1.1869
Min	.0953	.0953	.0762	.0953	.0953	.1143	.0953
Avg	.4494	.2768	.2022	.7682	.5234	.5577	.6936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 202 / 11 KV BORGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	.9842	1.0753	.1524	.1905	.1715	.1524
2	1.1092	.9998	.9804	.1715	.1715	.1905	.1715
3	1.1574	1.1043	1.085	.1715	.1715	.1905	.1715
4	1.2631	1.2803	1.166	.1905	.1905	.2477	.1905
5	1.5746	1.5364	1.1822	.2286	.2667	.2858	.2286
6	1.9784		1.2163	.2858	.3429	.3048	.2858
7	1.9662	1.9364	1.5684	.2858	.3239	.3048	.2858
8	.2477	.2286	.2096	.2858	.2477	.2286	.2286
9	.1905	.1905	1.4083	1.5497	1.7604	1.6804	.2096
10	.1715	.1524	1.4723	1.1574	1.531	1.5699	.1905
11	.1715		1.4089	1.387	1.5154	1.4632	.1905
12	.1905		1.4089	.1334	1.5242	1.4327	.1715
13	.2096		1.4175		1.326	1.3717	.1524
14	.2096		1.3108		1.3108	1.448	.1524
15	.2286		1.326		1.4327	1.448	.1715
16	.2096		1.4661		1.4632	1.4937	.1524
17	.1905		.1715		.1905	.0953	.1905
18	.2477		.1905		.1715	.1524	.1715
19	.2858		.2477		.2477	.2477	.2286
20	.2667		.2477		.2667	.2667	.2667
21	.2477		.2096		.2286	.2286	.1905
22	1.1405		.1905		.1905	.2096	1.4723
23	.9998	.9962	.1715		.1715	.1715	1.2186
24	1.0802	.9842	.9804	.1524	.1905	.1715	.1524
Max	1.9784	1.9364	1.5684	1.5497	1.7604	1.6804	1.4723
Min	.1715	.1524	.1715	.1334	.1715	.0953	.1524
Avg	.6829	.9448	.9213	.4732	.6428	.6406	.2915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 203 / 11 KV BALGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.1334	1.5061	1.3765	1.2003	1.5384
2	.1715	.1334	.1334	1.5203	1.4255	1.2289	1.6221
3	.1715	.1334	.1107	1.8623	1.5424		1.6518
4	.1905	.3048	.1898	1.9334	1.6244	1.5089	1.7204
5	.2477	.3429	.2372	2.13	1.7604	1.5089	1.9062
6	.381	.4001	.362	2.323	2.1434	1.6108	2.0957
7	.3048	.3429	.362	2.4756	2.0287	1.7238	2.0008
8	.2477	.2477	.3048	.2286	.1905	.1334	.2286
9	2.0388	2.0165	.1905	.1524	.2096	.1334	1.7078
10	2.0719	1.9845	.1524	.1524	.2096	.1524	1.8404
11	2.0481		.1905	.1905	.2286	.1334	1.8884
12	1.9595		.1524		.2096	.1334	1.5971
13	1.8623		.1334		.1715	.1524	1.6604
14	1.8947		.2096		.1524	.1524	1.6716
15	1.8947		.1905		.1905	.1905	1.7869
16	1.8084		.1905		.1715	.2286	1.8027
17	.1715		.1715			.1905	.1715
18	.2477		.1715			.1524	.1715
19	.2286		.2667		.1905	.1905	.2096
20	.2477		.2858		.1905	.2477	.2858
21	.2096		.2667		.1715	.2286	.2096
22	.1905		1.8564		1.2125	1.7404	.2096
23	.1715	.1524	1.6244		1.1523	1.6221	.1715
24	.1524	.1524	.1334	1.5061	1.3923	1.1523	1.5684
Max	2.0719	2.0165	1.8564	2.4756	2.1434	1.7404	2.0957
Min	.1524	.1334	.1107	.1524	.1524	.1334	.1715
Avg	.7944	.5287	.3341	1.3317	.8157	.6833	1.2382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 204 / 11 KV AKKALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0572	.0572	.0572	.0572
2	.0762	.0762	.0762	.0762	.0572	.0572	.0572
3	.0762	.0762	.0762	.0762	.0762		.0762
4	.0953	.0953	.0953	.0953	.0953	.0953	.0762
5	.1334	.0953	.0953	.0953	.0953	.1143	.0953
6	.1524	.0953	.0953	.0953	.1334	.0953	.1334
7	.1524	.1143	.1334	.1143	.1334	.0953	.1715
8	.0953	.1143	.1334	.0762	.1143	.0953	.1334
9	.0953	.0953	.1334	.0762	.0953	.0762	.0953
10	.0953	.0762	.1143	.0953	.0953	.0762	.0953
11	.0762		.0762	.0762	.0953	.0762	.0762
12	.0762		.0953	.0762		.0762	.0762
13	.0953		.0762			.0762	.0762
14	.0572		.0762		.0762	.0762	.0762
15	.0762		.0762		.0762	.0762	.0762
16	.0953		.0953		.0762	.0762	.0953
17	.0953		.0762		.0953	.0953	.0953
18	.1334		.1143		.0953	.0953	.1143
19	.1715		.1143		.1334	.1715	.1334
20	.2096		.1334		.1334	.1715	.1334
21	.1905		.0953		.1143	.1715	.1143
22	.1524		.0762		.0953	.1334	.0762
23	.1143	.0762	.0762		.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0762	.0762	.0572
Max	.2096	.1143	.1334	.1143	.1334	.1715	.1715
Min	.0572	.0762	.0762	.0572	.0572	.0572	.0572
Avg	.1112	.0889	.0953	.0835	.0953	.0961	.0945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 205 / 11 KV BORGI BALGAON

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0762	.0762	.0762	.0762	.0762
2	.0762	.0953	.0762	.0762	.0762	.0762	.0953
3	.0953	.1143	.0762	.0953	.0953		.0762
4	.1143	.1334	.0953	.1334	.1143	.1334	.1143
5	.1334	.1524	.1524	.1715	.1524	.1715	.1524
6	.1905	.1715	.2096	.1905	.1905	.1905	.2096
7	.1715	.1905	.1715	.1524	.1524	.1905	.1715
8	.1334	.1334	.1334	.0953	.1143	.1143	.0953
9	.1143	.0762	.1143	.0953	.0953	.0762	.0953
10	.0953	.0762	.0953		.1334	.0953	.1143
11	.0953		.0953	.1143	.1143	.1143	.0953
12	.0953		.1143	.0953		.1143	.1334
13	.0953		.0953			.0762	.0953
14	.0953		.0953		.1143	.0762	.0953
15	.1143		.0953		.1143	.0953	.0953
16	.1524		.1143		.0953	.1143	.1334
17	.1524		.1334		.1334	.0953	.1524
18	.1905		.1715		.1524	.1334	.1715
19	.1905		.1715		.1905	.2286	.2286
20	.1524		.2096		.1905	.2286	.2286
21	.1524		.1524		.1905	.1524	.1715
22	.1143		.1334		.1334	.1143	.1143
23	.0953	.0953	.0953		.0762	.0953	.0762
24	.0953	.0953	.0953	.0762	.0762	.0762	.0762
Max	.1905	.1905	.2096	.1905	.1905	.2286	.2286
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1246	.1191	.1239	.1143	.1264	.1234	.1278

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 201 / 11 KV SUSLAD AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6892	2.0481	.2987		.362	.4108
2		1.722	2.0485	.2614		.3801	.4108
3		1.7506	2.0165	.2614		.4024	.4338
4		1.845	2.0965	.2926		.3696	.5281
5			2.1538	.3142		.3696	.5014
6		2.4996	2.3758	.3547		.3881	.4887
7		2.4215		.4481		.3881	.4784
8		.2865	.4207	.4854		.4066	.4294
9	.2152	.3045	2.5101		2.8346	3.155	.2743
10	.2303	.3142	2.9014		2.672	3.3634	.246
11	.2152	.3142	2.7168		2.672	3.0982	.2303
12	.2303	.2957	2.8166		2.7206		.2152
13	.2152	.3045	2.6063		2.753	2.561	
14	.1991	.3294	2.7168		2.7035	2.6684	.2301
15	.2147	.2774	2.7759		2.5069	2.6282	.2457
16	.2152	.2103	2.5968		2.5232	2.5549	.2306
17	.2457	.2804	.4119		.2713	.4458	.246
18		.3109	.4119		.3258	.4207	
19	.2918	.3475	.4656		.1008	.4656	.3429
20	.3229	.4207	.4298		.4344	.4706	.3609
21	.3378	.4207	.3403		.4344	.4706	.3601
22		2.3148	.3582		.4344	.4525	
23		2.1376	.2614		.3801	.4344	1.6892
24	2.332	1.6104	2.3122	.2743		.362	.4294
Max	2.332	2.4996	2.9014	.4854	2.8346	3.3634	1.6892
Min	.1991	.2103	.2614	.2614	.1008	.362	.2152
Avg	.4050	.9742	1.7301	.3323	1.5845	1.1573	.4182

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 202 / 11 KV UMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.2374	.2454		.2804	.333
2		.2406	.2401	.2507		.2454	.3155
3		.2578	.2743	.2534		.2865	.2804
4		.2743	.3086	.2534		.2865	.3155
5			.3086	.2896		.3224	.3429
6		.394	.4298	.3258		.3506	.3856
7		.4344	.394	1.0029		.3856	.3506
8		.3506	.394	.3658		.3506	.2743
9	.2058	.3506	.3224		.3155	.3155	.2401
10	.206	.3155	.2865		.3045	.3155	.1845
11	.2406	.333	.2534		.2865	.333	.1843
12	.2583	.2804	.2561		.2743	.3292	.1691
13	.275	.3155	.3224		.2743	.3292	
14	.2401	.3155	.3224		.2507		.184
15	.206	.2743	.3224		.2507		.1845
16	.2401	.3292	.2865		.2614		.215
17	.275	.2926	.3292		.2865		.2306
18		.3881	.2896		.3658	.3403	
19	.3772	.639	.4024		.3772	.3856	.3067
20	.412	.4207	.4298		.2561	.4207	.3382
21	.3781	.4024	.4024		.2743	.394	.3993
22		.3155	.3582		.3086	.3582	
23		.2713	.3224		.3086	.3582	.246
24	.2865	.2918	.2374	.2743		.3086	.3403
Max	.412	.639	.4298	1.0029	.3772	.4207	.3993
Min	.2058	.2401	.2374	.2454	.2507	.2454	.1691
Avg	.2770	.3360	.3221	.3624	.293	.3348	.2772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 203 / 11 KV SONALGI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3839	.4435	2.2211		2.2891	2.2291
2		.369	.4755	2.2119		2.3472	2.1605
3		.3839	.4755	2.5101		2.3868	2.1434
4		.3997	.4481	2.6216		2.3205	2.2634
5			.5228			2.3434	2.2634
6		.4656	.6036	2.6871		2.7349	2.17
7		.4298	.5975	2.6216		2.6871	2.5396
8			.5544	.3932		.3315	.4458
9	1.9065	2.2405	.5175		.3734	.3441	1.9987
10	2.1191	2.2809	.5544		.3961	.4805	2.0577
11	2.2085	2.3845	.439		.3734	.4805	1.9631
12	2.1445	2.3644	.4435		.3921	.4854	1.9987
13	2.1498	2.3868	.3582		.3921	.4854	
14	2.1832	2.1052	.4298		.3658		2.0295
15	2.1498	2.0557	.4298		.3734		1.9963
16	2.214	2.0309	.4656		.5175		1.9018
17	.0365	.407	.4656		.4961		.3378
18		.3582	.4298		.5359	.439	
19	.3844	.5373	.4115		.5175	.1288	.3839
20	.3685	.6516	.4656		.5359	.5121	.3382
21	.3997	.6401	.4908		.4908	2.2977	.3378
22		.6468	2.2085		2.3491		
23		.5487	2.2291		2.3491	2.3148	.3374
24	.4534	.3681	.4805	2.1605		2.2805	2.2291
Max	2.214	2.3868	2.2291	2.6871	2.3491	2.7349	2.5396
Min	.0365	.3582	.3582	.3932	.3658	.1288	.3374
Avg	1.4398	1.1108	.6225	2.1784	.6972	1.4573	1.6250



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 204 / 11 KV UMADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0705	2.4615	.6089		.7164	.8619
2		2.1191	2.5069	.6089		.631	.8192
3		2.1525	2.4905	.6268		.631	.7935
4		2.1805	2.5194	.6984		.631	.7287
5			2.4615	.7522		.7011	.8097
6		2.9007	2.6871	.7522		.964	.8907
7		2.8502	2.5606	1.0029		.964	1.0082
8		.6783	.6554	.9671		.7545	.9555
9	.6457	.6718	2.536		3.0407	3.1722	.9225
10	.6142	.7537	2.5692		3.1131	2.8807	.8906
11	.615	.7293	2.5692		2.9287	2.8673	.8241
12	.6449	.7293	2.5396		2.8826	2.8807	.7985
13	.615	.7625	2.6189		2.8664	2.915	
14	.5835	.6762	2.7183		3.0312		.8292
15	.615	.6859	2.6871		3.1131	2.9473	.7995
16	.6142	.6135	2.6216		3.0407	2.753	.8425
17	.6457	.5959	.5898		.631	.583	.7965
18		.5992	.663		.8402	.6478	
19	.6112	.639	.663		.8907	.8745	.7371
20	.615	.6783	.6449		.9831	.8421	.7055
21	.6142	.6783	.663		.9431	.8421	.6765
22		2.5911	.663		.7888	.8848	
23		2.4939	.6516		.788	.8951	1.9987
24	2.5911	2.0526	2.4291	.631		.8059	.8951
Max	2.5911	2.9007	2.7183	1.0029	3.1131	3.1722	1.9987
Min	.5835	.5959	.5898	.6089	.631	.583	.6765
Avg	.7711	1.3436	1.9238	.7387	1.9921	1.4254	.8849

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 205 / 11 KV SUSLAD GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0515	.0509	.0701		.0625	.0701
2		.0686	.0686	.0732		.0686	.0701
3		.0858	.0514	.0732		.0716	.0701
4		.1029	.0857	.0914		.0537	.0876
5			.0857	.1254		.0537	.1227
6		.1543	.1227	.1417		.1433	.1227
7		.1612	.1075	.1595			.1372
8		.1254	.1075	.1063		.1075	.12
9	.0087	.0914	.0716		.1029	.0857	.0086
10	.0069	.0716	.0701		.1052	.0876	.0069
11	.0859	.0895	.0686		.1029	.0876	.0859
12	.0069	.1075	.0686		.1029	.0876	.0858
13	.0516	.1075	.0686			.0876	
14	.0086	.1052	.0732			.0701	.0052
15	.0857	.0876	.0732			.0876	.0686
16	.0103	.1017	.0716		.0351	.1029	.0858
17	.0123	.1214	.1075		.1252	.0914	.0859
18		.1029	.1663		.1486	.0857	
19	.1373	.1612	.1663		.1486	.1052	.0139
20	.0123	.1463	.1478		.1337	.12	.1375
21	.1206	.1463	.1075		.1337	.1029	.0154
22		.0857	.0895		.0743	.0876	
23		.0848	.0895		.0762	.0876	.12
24	.0549	.007	.1075	.0724		.0762	.0701
Max	.1373	.1612	.1663	.1595	.1486	.1433	.1375
Min	.0069	.007	.0509	.0701	.0351	.0537	.0052
Avg	.0463	.1029	.0928	.1015	.1074	.0876	.0757

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 201 / 11 KV MADGYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.905	.6249	.1402		.1402	
2	.6401	.905	.6249	.1402		.1402	
3	.6249	.8764	.6249	.1402		.1402	
4	.6249	.8573	.6249	.1402		.1753	
5	.6859	.9835	.6249	.1753		.2103	
6	1.3603	1.2717		.2804		.3506	
7	1.4403	1.6108	1.0936	.3506		.3155	
8	.2279	.3391	.1562	.2804	.2279	.2454	
9	.1715	.2629	.7621		1.0936		.2195
10	.1372	.2241	.6687		.9907		.1829
11	.1848	.2241	.8509		.8916		.1612
12	.2218	.1372	.7716		.8916		.1227
13	.2218	.12	.7133		.8916		.1227
14	.2218	.12	.8459		.7964		.1227
15	.1829	.1227	.8859		.9412		.1227
16	.1829	.1227	1.0433		1.086		.1052
17	.2241	.1402	.1402		.1402		.1402
18	.2801	.1578	.1402		.1578		.1578
19	.2801	.2804	.2103		.2804		.2103
20	.2241	.3155	.2454		.3155		.2629
21	.2241	.2279	.2454		.2454		.2454
22	.8402	.8907	.1753		.1753		1.1203
23	.924	.6718	.1578		.1578		
24	.6859	.905	.6249	.1402		.1402	
Max	1.4403	1.6108	1.0936	.3506	1.0936	.3506	1.1203
Min	.1372	.12	.1402	.1402	.1402	.1402	.1052
Avg	.4772	.5280	.5589	.1986	.5802	.2064	.2355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 202 / 11 KV SONYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4842	1.2811	1.406	.2846		.2846	
2	1.4842	1.3435	1.406	.2846		.2846	
3	1.5023	1.3435	1.406	.2846		.2846	
4	1.5023	1.3435	1.406	.2846		.2846	
5	1.6804	1.829	1.406	.3521		.3521	
6	2.5149	1.7814	1.9814	.4481		.5182	
7	2.1052	2.1052	1.9814	.5535		.5121	
8	.4111	.6401	.2812	.4012	.3163	.3437	
9	.3521	.6401	1.5242		2.0005		.4344
10	.3201	.4801	1.4861		1.9204		.4744
11	.3953	.5121	1.6347		1.7185		.3125
12	.3953	.3163	1.5146		1.6004		.3125
13	.3906	.3201	1.4662		1.4861		.3125
14	.4321	.3201	1.5003		1.3756		.3086
15	.5468	.3201	1.5432		1.5203		.3125
16	.6401	.3201	1.8534		1.8099		.3201
17	.6478	.3163	.3125		.3125		.3841
18	.7287	.3479	.3437		.3437		.3163
19	.8145	.4161	.3841		.3795		.4481
20	.4572	.4161	.4161		.4161		.4801
21	.4877	.3125	.3898		.4111		.3841
22	1.1717	1.6204	.3201		.3201		2.0243
23	1.2498	1.3889	.2846		.3125		
24	1.448	1.2811	1.406	.2846		.2846	
Max	2.5149	2.1052	1.9814	.5535	2.0005	.5182	2.0243
Min	.3201	.3125	.2812	.2846	.3125	.2846	.3086
Avg	.9651	.8748	1.1522	.3531	1.0152	.3499	.4875

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 203 / 11 KV UTAGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562	.2401	.1581	1.1888		1.3375	
2	.1619	.2401	.1772	1.1888		1.3717	
3	.1562	.2401	.1581	1.1888		1.3717	
4	.1581	.2401	.1581	1.1888		1.3717	
5	.2401	.2915	.2056	1.1888		1.3717	
6	.3563	.4049	.3239	2.0062		2.13	
7	.3239	.4534	.3239	1.8519		1.7833	
8	.1875	.2439	.16	.2439	.1875	.2315	
9	1.6575	1.5242	.1875		.1875		1.382
10	1.406	1.6872	.1875		.1875		1.4148
11	1.2308	1.6872	.2743		.1543		1.3969
12	.7964	1.5242	.2229		.1543		1.3375
13	1.3321	1.448	.2286		.1486		1.2631
14	1.3032	1.448	.2317		.1448		1.1873
15	1.4861	1.6347	.2675		.1337		1.4861
16	1.829	1.6651	.2494		.1372		1.6347
17	.3858	.1219	.2187		.1524		.1189
18	.3858	.1524	.1875				.1486
19	.3953	.25	.2591		.2241		.2134
20	.3048	.2881	.2591		.2401		.25
21	.2934	.2214	.1581		.2056		.2187
22	.2778	.1581	1.5242		1.5242		.144
23	.2812	.1581	1.1888		1.3717		
24	.1562	.2343	.1581	1.1888		1.3375	
Max	1.829	1.6872	1.5242	2.0062	1.5242	2.13	1.6347
Min	.1562	.1219	.1581	.2439	.1337	.2315	.1189
Avg	.6359	.6899	.3112	1.2483	.3436	1.3674	.8711

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 204 / 11 KV SONYAL GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0747	.1109	.0747		.0924	
2	.0934	.0754	.1109	.0747		.0924	
3	.0934	.0754	.1109	.0747		.0924	
4	.112	.0747	.1109	.0934		.112	
5	.1886	.1478	.1867	.1698		.1867	
6	.2829	.1829	.9374	.2829		.3361	
7	.2614	.2561	.2427	.2987		.3142	
8	.2033	.2195	.1848	.2279	.2195	.2012	
9	.1646	.1829	.1612		.1629		.1463
10	.1448	.1097	.1417		.1254		.1463
11	.1463	.1097	.1097		.1254		.128
12	.1097	.1063	.0895		.1254		.1097
13	.1097	.0895	.0914		.1075		.1086
14	.1097	.0895	.0895		.1063		.0895
15	.1097	.1075	.1097		.1052		.0895
16	.128	.1254	.1086		.1214		.1075
17	.2195	.1578	.1372		.156		.0937
18	.2743	.176	.16		.1718		.108
19	.2743	.3045	.2865		.2629		.2454
20	.2195	.2926	.2835		.3012		.2835
21	.1829	.2012	.1829		.2353		.2172
22	.1494	.1494	.1478		.1663		.1629
23	.112	.1109	.0924		.1294		
24	.0924	.0747	.1109	.0934		.1109	
Max	.2829	.3045	.9374	.2987	.3012	.3361	.2835
Min	.0924	.0747	.0895	.0747	.1052	.0924	.0895
Avg	.1615	.1456	.1791	.1545	.1639	.1709	.1454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 205 / 11 KV UTAGI VHASPETH

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0543	.0739	.056		.0554	
2	.056	.0549	.0739	.056		.0554	
3	.056	.0549	.0739	.056		.0554	
4	.056	.0549	.0739	.056		.0554	
5	.0747	.0924	.0732	.056		.0739	
6	.0934	.112	.1109	.0554		.0934	
7	.0747	.112	.0924	.0732		.0732	
8	.056	.1086	.0554	.0366	.1097	.0739	
9	.0732	.1086	.0732		.1109		.0895
10	.0732	.0905	.0914				.0905
11	.1086	.0905	.0732		.1097		.0914
12	.1086	.0934	.0701		.0914		.0924
13	.1086	.0747	.0857		.1097		.0924
14	.0905	.056	.0876		.1097		.0739
15	.0876	.056	.104		.1478		.0914
16	.1029	.056	.1029		.1663		.0914
17	.1029	.0914	.1097		.1848		.1109
18	.1075	.1109	.0924				.1109
19	.1254	.1663	.1294		.1867		.1294
20	.1254	.1463	.1478		.1867		.1478
21	.1075	.1307	.1463		.168		.1097
22	.0905	.0914	.1097		.1294		.0914
23	.0905	.0739	.0739		.1097		
24	.056	.0543	.0739	.056		.0554	
Max	.1254	.1663	.1478	.0732	.1867	.0934	.1478
Min	.056	.0543	.0554	.0366	.0914	.0554	.0739
Avg	.0867	.0890	.0916	.0557	.1372	.0657	.1009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 201 / 11 KV SIDHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1638	.1638	1.1469		1.1469	1.3108
2	.1638	.1638	.1638	1.1469	1.1469	1.1469	1.3108
3	.1638	.1638	.1638	1.1469	1.1469	1.1469	1.1469
4	.1638	.1638	.1638	1.3108	1.3108	1.1469	1.1469
5	.1638	.1638	.1638	1.3108	1.3108	1.4746	1.1469
6	.1638	.1638	.2458	1.4746	1.4746	1.6385	1.1469
7	.1638	.1638	.2458	1.4746	1.4746	1.6385	1.1469
8	.1638	.1638	.2458	.1638	.1638	.1638	.1638
9				.1638	.1886	.1638	1.1469
10				.1638	.1886		
11				.1638	.1886		
12				.1638	.1638		
13					.1638		
14				.1638	.1638		
15				.1638	.1638		
16				.1638	.1638	.1638	1.3108
24	.1638	.1638	.1638	1.1469	1.1469	1.1469	1.3108
Max	.1638	.1638	.2458	1.4746	1.4746	1.6385	1.3108
Min	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Avg	.1638	.1638	.1911	.7168	.6600	.9980	1.1171



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 202 / 11 KV DARIKONUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049	.4858	.4049	.081	.081	.081	.081
2	.4049	.4858	.4049	.081	.081	.081	.081
3	.4858	.4858	.4049	.081	.081	.081	.081
4	.4858	.6478	.4858	.081	.081	.081	.081
5	.8097	.6478	.6478	.081	.081	.081	.081
6	.9717	.8097	.6478	.081	.081	.081	.1619
7	.4858	.8097	.6478	.1619	.081	.081	.1619
8	.1619	.081	.081	.1619	.081	.081	.1619
9				.8097	.8192	.6478	.1619
10				.8097	.8192		
11				.8097	.6554		
12					.6478		
13					.6478		
14					.6478		
15					.6478		
16				.6478	.6478	.6478	.081
24	.4049	.4858	.4049	.081	.081	.081	.081
Max	.9717	.8097	.6478	.8097	.8192	.6478	.1619
Min	.1619	.081	.081	.081	.081	.081	.081
Avg	.5128	.5488	.4589	.3052	.3683	.1841	.1104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 203 / 11 KV SHEDYAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0747	.056	.056	.056	.056	.056
2	.0566	.0747	.056	.056	.056	.056	.056
3	.0566	.0747	.056	.056	.056	.056	.056
4	.0566	.0747	.056	.056	.056	.056	.056
5	.0566	.0747	.056	.056	.056	.056	.056
6	.0566	.0747	.056	.056	.056	.056	.056
7	.0566	.0747	.056	.056	.056	.056	.056
8	.0566	.0747	.056	.056	.056	.056	.056
9				.0566	.0566	.0566	.0566
10				.0566	.0566		
11				.0566	.0566		
12				.0566	.0566		
13				.0566	.0566		
14				.0566	.0566		
15				.0566	.0566		
16				.0566	.0566	.0566	.0566
24	.0566	.0747	.056	.056	.056	.056	.056
Max	.0566	.0747	.056	.0566	.0566	.0566	.0566
Min	.0566	.0747	.056	.056	.056	.056	.056
Avg	.0566	.0747	.056	.0563	.0563	.0561	.0561

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 204 / 11 KV SHEDYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.6783	.6783	.0848	.0848	.081	.0848
2	.6783	.6783		.0848	.0848	.0848	.0848
3	.6783	.6783	.6783	.0848	.0848	.0848	.0848
4	.6783	.8478	.6783	.0848	.0848	.0848	.0848
5	1.0174	1.0174	.6783	.0848		.0848	.0848
6	1.0174	1.3565	.9326	.1696	.0848	.0848	.1696
7	.6783	1.3565	1.0174	.1696	.0848	.1696	.1696
8	.1696	.0848	.0848	.1696	.0848	.1696	.1696
9				.9326	.8478	1.1469	
10				.9326	.9326		
11				.9326	1.0174		
12					1.0174		
13					.1017		
14					1.0174		
15					.9717		
16				1.1022	1.0174	1.1869	.0943
24	.6783	.6783	.6783	.0848	.0848	.0848	.0848
Max	1.0174	1.3565	1.0174	1.1022	1.0174	1.1869	.1696
Min	.1696	.0848	.0848	.0848	.0848	.081	.0848
Avg	.6971	.8196	.6783	.3783	.4751	.2966	.1112

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 205 / 11 KV DARIKONUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0747	.056	.056	.056	.056	.0373
2	.0377	.0747	.056	.056	.056	.056	.0373
3	.0377	.0747	.056	.056	.056	.056	.0373
4	.0377	.0747	.056	.056	.056	.056	.0373
5	.0377	.0747	.056	.056	.056	.056	.0373
6	.0566	.0747	.056	.056	.056	.056	.056
7	.0566	.0747	.0747	.056	.056	.056	.056
8	.0566	.0747	.056	.056	.056	.056	.056
9				.0566	.0566	.0566	.0566
10				.0566	.0566		
11				.0566	.0566		
12				.0566	.0566		
13				.0566	.0566		
14				.0566	.0566		
15				.0566	.0566		
16				.0566	.0566	.0566	.0566
24	.0377	.0747	.056	.056	.056	.056	.0373
Max	.0566	.0747	.0747	.0566	.0566	.0566	.0566
Min	.0377	.0747	.056	.056	.056	.056	.0373
Avg	.044	.0747	.0581	.0563	.0563	.0561	.0459

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 206 / 11 KV SIDDHANATH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.0754	.0754	.0754	.0943	.0943
2	.0754	.0943	.0754	.0754		.0943	
3	.0754	.0943	.0754	.0754	.0754	.0943	.0943
4	.0943	.0943	.0754	.0754	.0754	.0943	.0943
5	.0943	.0943	.0754	.0754	.0754	.0943	.0943
6	.0943	.0943	.0943	.0754	.0754	.0943	.0943
7	.0943	.0943	.0943	.0754	.0754	.0943	.0943
8	.0943	.0943	.0754	.0754	.0754	.0943	.0943
9				.0754	.0754	.0943	.0943
10				.0754	.0754		
11				.0754	.0754		
12				.0754	.0754		
13				.0754	.0754		
14				.0754	.0754		
15				.0754	.0754		
16				.0754	.0754	.0754	.0754
24	.0754	.0943	.0754	.0754	.0754	.0943	.0943
Max	.0943	.0943	.0943	.0754	.0754	.0943	.0943
Min	.0754	.0943	.0754	.0754	.0754	.0754	.0754
Avg	.0859	.0943	.0796	.0754	.0754	.0926	.0924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 207 / 11 KV DARIBADCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2458	.2458	.2458	1.1469	1.1469	1.1469	1.3108
2	.2458	.2458	.2458	1.1469	1.1469	1.1469	1.3108
3	.2458	.2458	.2458	1.3108	1.1469	1.1469	1.3108
4	.2458	.2458	.2458	1.3108	1.4746	1.3108	1.3108
5	.3277	.2458	.2458	1.4746	1.4746	1.6385	1.3108
6	.3277	.3277	.2458	1.6385	1.8023	1.8023	1.3108
7	.3277	.3277	.2458	1.6385	1.8023	1.8023	1.3108
8	.3277	.3277	.2458	.2458	.3277	.2458	.1638
9				.2458	.2458	.2458	1.1469
10				.2458	.2458		
11				.2458	.2458		
12				.2458	.2458		
13				.2458	.2458		
14				.2458	.2458		
15				.2458	.2458		
16				.2458	.2458	.1638	1.3927
24	.2458	.2458	.2458	1.1469	1.1469	1.1469	1.3108
Max	.3277	.3277	.2458	1.6385	1.8023	1.8023	1.3927
Min	.2458	.2458	.2458	.2458	.2458	.1638	.1638
Avg	.2822	.2731	.2458	.7662	.7903	1.0724	1.1991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 208 / 11 KV MUCHANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1469	.8192	1.1469	.1638	.1638	.1638	.1638
2	1.1869	.8192	1.1469	.1638	.1638	.1638	.1638
3	1.1469	.8192	1.1469	.1638	.1638	.1638	.1638
4	1.3108	1.1469	1.4746	.1638	.1638	.1638	.1638
5	1.8023	1.1469	1.4746	.1638	.1638	.1638	.1638
6	1.9662	1.8023	1.8023	.1638	.1638	.1638	.2458
7	1.4746	1.8842	1.8023	.1638	.1638	.1638	.2458
8	.1638	.1638	.1638	.1638	.1638	.1638	.2458
9				1.4746	1.4746	1.4746	.1638
10				1.6385	1.4746		
11				1.3108	1.4746		
12					1.4746		
13					1.2289		
14					1.2289		
15					1.3108		
16				1.7204	1.5402	1.6385	.1638
24	1.1469	.8192	1.1469	.1638	.1638	.1638	.1638
Max	1.9662	1.8842	1.8023	1.7204	1.5402	1.6385	.2458
Min	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Avg	1.2606	1.0468	1.2561	.5860	.7460	.4170	.1862

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 201 / 11 KV TIKONDI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4372	.3887	.3605	.0819	.0995	.0671	.0995
2	.421	.4096	.3563	.0648	.0829	.0678	.1006
3	.4161	.3932	.3401	.0648	.0838	.0678	.1006
4	.4321	.3978	.3563	.081	.1147	.0829	.116
5	.4534	.3768	.4096	.0972	.1311	.1326	.1326
6	.6478	.5344	.4588	.1311	.1658	.1638	.1638
7	.6316	.583	.426	.1966	.1781	.1638	.1802
8	.1311	.0995	.1296	.1943	.1677	.1357	.1966
9	.1475	.1326	.4372	.5182	.583	.583	.1823
10	.1492	.0995	.5182	.5506	.5441	.5441	.1658
11	.1147	.1147	.4049		.5121	.5182	.1341
12	.0983	.0972	.3841		.421	.4534	.1006
13	.0655	.081	.3521		.421	.421	.1017
14	.0655	.081	.3521		.3841	.421	.1006
15	.0663	.096	.3563		.3887	.426	.116
16	.0829	.112	.4534	.4534	.1989	.5344	.1311
17	.1006	.1134	.0972	.1372	.1187	.0829	.1357
18	.1326	.1296	.128	.1357	.1357	.116	.1696
19	.1492	.1457	.1296	.1187	.1357	.1823	.1696
20	.0829	.1457	.1296	.1187	.1357	.1638	.1677
21	.0655	.1311	.1311	.1187	.1017	.1638	.1526
22	.3887	.4915	.0983	.1174	.0995	.1311	.5967
23	.3887	.4588	.0819	.1174	.0995	.0995	.5182
24	.4372	.3887	.3605	.0819	.1006	.0671	.0995
Max	.6478	.583	.5182	.5506	.583	.583	.5967
Min	.0655	.081	.0819	.0648	.0829	.0671	.0995
Avg	.2544	.2501	.3022	.1779	.2252	.2412	.1722



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 202 / 11 KV KONTEBOBLAD AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9012	.7287	.8619	.1966	.1989	.2321	.1989
2	.8848	.7537	.8288	.1802	.1823	.218	.1989
3	.8785	.7956	.8192	.1781	.1802	.218	.1966
4	.8785	.8288	.852	.1943	.2321	.2321	.2321
5	.8848	.8848	.9012	.2267	.2984	.2652	.2458
6	1.3765	1.1012	1.0442	.2429	.3563	.3605	.2622
7	1.4899	1.2955	1.1603	.2949	.2915	.3277	.2984
8	.2622	.1989	.2652	.2622	.2543	.2035	.2652
9	.213	.0995	.9831	1.3108	1.2955	1.2308	.2486
10	.2486	.213	1.065	1.1469	1.2483	1.2163	
11	.2486	.1966	1.0486		1.1523	1.2163	.1341
12	.2652	.1781	1.004		1.0364	1.1174	.2155
13	.2294	.1781	.9878		1.0364	1.004	.2321
14	.2294	.176	.9717		1.0814	.9503	.2321
15	.2321	.16	1.004		1.0364	1.1142	.2012
16	.2321	.1457	1.1012	1.1142	1.2308	1.1984	.2294
17	.2155	.1943	.1781	.2374	.2012	.1311	.2713
18	.1492	.2105	.213	.2374	.2374	.1311	.2683
19	.2347	.2458	.2458	.2713	.3052	.1989	.3018
20	.1341	.2622	.2294	.3052	.3052	.2652	.3018
21	.116	.2458	.2486	.2683	.2683	.2622	.2683
22	.8848	1.0486	.2155	.2515	.2347	.2155	1.1271
23	.7287	.9503	.213	.2155	.2321	.2155	1.0526
24	.7859	.7449	.8619	.1966	.2012	.2683	.2012
Max	1.4899	1.2955	1.1603	1.3108	1.2955	1.2308	1.1271
Min	.116	.0995	.1781	.1781	.1802	.1311	.1341
Avg	.5293	.4932	.7210	.3858	.5457	.5330	.3123

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 203 / 11 KV PANDOZARI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4807	.3978	.5304	1.5249	1.4575	1.4575	1.3927
2	.4694	.4144	.4973	1.5249	1.491	1.4255	1.3927
3	.503	.4424	.4915	1.4918	1.5061	1.4582	1.3927
4	.5304	.4752	.5243	1.4746	1.6164	1.5061	1.3763
5	.5636	.5079	.5571	1.5565	1.7284	1.7328	1.3603
6	.6882	.664	.7373	2.0317	1.9204	1.7604	1.6194
7	.6718	.7373	.7956	2.2045	2.1285	1.9134	1.6804
8	.5735	.6062	.6796	.547	.5197	.5256	.431
9	1.9271	1.9109	.6062	.4096	.5138	.5365	1.5074
10	1.7328	1.8623	.5898	.5407	.547	.5197	1.4089
11	.8192	1.6712	.5407		.5571	.5365	1.3765
12	1.4089	1.7695	.5506		.5668	.5304	1.3765
13	1.4413	1.6712	.5992		.2429	.5138	1.3441
14	1.4091	1.5708	.502		.3521	.4752	1.4575
15	1.6194	1.6842	.4696	.3222	.3978	.4752	1.5524
16	1.7328	1.8138	.5182	.3856	.4372	.5304	1.6484
17	.4049	.3768	.5441	.4917	.4748	.5636	.373
18	.4144	.4588	.5601		.5596	.6226	.4527
19	.5138	.6062	.5992	.7209	.6036	.663	.5868
20	.431	.6554	.5898	.6706	.6443	.6962	.6371
21	.3932	.6133	.5407	.5426	.547	.5801	.5533
22	.4096	.547	1.873	1.7814	1.8299	1.704	.503
23	.3978	.5304	1.6244	1.6356	1.7328	1.5074	.5138
24	.4807	.3978	.5304	1.5581	1.5061	1.4737	1.4089
Max	1.9271	1.9109	1.873	2.2045	2.1285	1.9134	1.6804
Min	.3932	.3768	.4696	.3222	.2429	.4752	.373
Avg	.8340	.9327	.6688	1.1271	.9950	.9878	1.1394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 204 / 11 KV TIKONDI GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0934	.0934	.0934	.0934	.0747	.0747
2	.0747	.0754	.0943	.0934	.0934	.0739	.0754
3	.0754	.0754	.0754	.0747	.0924	.0747	.0754
4	.0754	.0943	.0943	.0739	.1109	.0934	.0747
5	.112	.112	.112	.0924	.1646	.1294	.0934
6	.1867	.1307	.1307	.1294	.2195	.1829	
7	.1867	.1494	.1132	.168	.1646	.1646	.0747
8	.1478	.1478	.0934	.1307	.1494	.1307	.0566
9	.1109	.1109	.0924	.112	.1478	.1109	.0566
10	.1109	.0924	.1109	.1109	.1463	.112	
11	.1097	.0914	.1097		.128	.0747	.0747
12	.128	.1097	.1097		.0934	.0914	.1294
13	.128	.1086	.1086		.0924	.0914	.112
14	.1109	.1267	.1086		.0924	.0914	.0934
15	.1294	.1075	.0895	.0934	.0046	.0914	.0914
16	.1109	.1254	.1075	.0924	.1109	.0724	.0914
17	.128	.1254	.1075	.112	.112	.0724	.0924
18	.128	.1448	.1086	.112	.1494	.1097	.1867
19	.1829	.2172	.1448	.1848	.168	.1663	.2033
20	.1294	.2012	.1646	.1867	.168	.2033	.2218
21	.1294	.1829	.128	.168	.1478	.1478	.1646
22	.112	.1294	.1109	.1097	.1097	.1307	.1663
23	.0934	.112	.0924	.1097	.0739	.0747	.1463
24	.0924	.0934	.0934	.0924	.112	.0747	.0747
Max	.1867	.2172	.1646	.1867	.2195	.2033	.2218
Min	.0747	.0754	.0754	.0739	.0046	.0724	.0566
Avg	.1195	.1232	.1081	.1170	.1227	.1100	.1105

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 205 / 11 KV PANDOZARI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0381	.0572	.0381	.0381	.0381
2	.0381	.0572	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0572	.0381	.0572	.0381	.0381
4	.0381	.0572	.0572	.0572	.0572	.0572	.0381
5	.0572	.0572	.0762	.0572	.0762	.0572	.0572
6	.0953	.0953	.1143	.0953	.0762	.0953	.0953
7	.1143	.1143	.1143	.1143	.0953	.0953	.0953
8	.0953	.0762	.0762	.0953	.0762	.0762	.0572
9	.0572	.0572	.0572	.0572	.0381	.0762	.0572
10	.0381	.0381	.0572	.0572	.0381	.0191	.0381
11	.0381	.0572	.0572		.0381	.0381	.0381
12	.0381	.0381	.0381		.0381	.0381	.0381
13	.0381	.0191	.0381			.0381	.0381
14	.0381	.0191	.0381		.0381	.0191	.0381
15	.0762	.0191	.0381		.0381	.0191	.0191
16	.0381	.0381	.0572	.0381	.0572	.0381	.0381
17		.0381	.0572	.0381	.0381	.0191	.0381
18	.0762	.0572	.0953	.0572	.0572	.0381	.0381
19	.1334	.0762	.0953	.0762	.1143	.0953	.0762
20	.1334	.1334	.1334	.0953	.1143	.1143	.0953
21	.1143	.0762	.1143	.0762	.0762	.1143	.0762
22	.0762	.0762	.0762	.0381	.0572	.0572	.0572
23	.0572	.0572	.0381	.0381	.0381	.0381	.0381
24	.0381	.0572	.0381	.0572	.0381	.0381	.0381
Max	.1334	.1334	.1334	.1143	.1143	.1143	.0953
Min	.0381	.0191	.0381	.0381	.0381	.0191	.0191
Avg	.0654	.0588	.0667	.0622	.0580	.0540	.0508

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 206 / 11 KV KAGNARI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.1696	.3353	1.8442	1.749	1.6356	1.5384
2	.3052	.1357	.3185	1.8107	1.7695	1.6385	1.5402
3	.3222	.1509	.3185	1.7404	1.8067	1.6876	1.5402
4	.3391	.1509	.3315	1.757	1.8299	1.6518	1.5384
5	.3521	.1696	.3647	1.9062	1.8884	1.7328	1.5384
6	.3856	.2543	.4807	2.1548	2.0485	1.8185	1.7166
7	.4191	.2883	.6203	2.2131	2.1925	1.7711	1.9524
8	.407	.3018	.5365	.6371	.5868	.4917	.4191
9	2.2045	1.3094	.503	.5365	.1802	.502	1.8785
10	2.13	1.8623	.3561	.4527	.4534	.5197	1.9685
11	2.0481	1.917	.39		.5304	.57	1.9109
12	2.0405	2.0957	.407		.5138	.57	1.7328
13	1.9109	2.0287	.4239		.4973	.3222	1.7204
14	1.9271	1.2763	.4359		.4915	.3052	1.7004
15	1.5844	1.757	.4191		.4475	.3185	1.6518
16	1.6964	1.8945	.4191	.2347	.5182	.3018	1.8185
17	.3768	.3185	.431	.3561	.5256	.3391	.4239
18		.373	.4641	.39	.5087	.3222	.4694
19	.2347	.4748	.4641	.4578	.5087	.3391	.503
20	.2012	.4694	.503	.4694	.4694	.3521	.503
21	.1696	.4191	.4191	.3688	.4191	.285	.4359
22	.2012	.373	2.0454	1.9364	1.9524	.8192	.3149
23	.1357	.3561	1.9951	1.9271	1.8724	1.8099	.3315
24	.3018	.1696	.3353	1.8778	1.7814	1.6804	1.5384
Max	2.2045	2.0957	2.0454	2.2131	2.1925	1.8185	1.9685
Min	.1357	.1357	.3185	.2347	.1802	.285	.3149
Avg	.8693	.7798	.5549	1.2143	1.0642	.9077	1.2786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 207 / 11 KV KAREWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.7682	.8421	.1898	.2012	.1989	.2155
2	.9602	.7682	.8002	.1718	.1865	.1844	.2155
3	.9442	.7432	.8002	.1718	.1989	.1844	.2012
4	.9282	.7748	.8162	.1718	.2347	.2155	.1989
5	.9282	.8002	.8745	.1898	.2486	.2486	.1966
6	1.1702	.9602	.9717	.2214	.2753	.2915	.3441
7	1.1544	1.0402	.9922	.253	.2915	.3521	.3401
8	.176	.1475	.112	.208	.2515	.3052	.2753
9	.2105	.1966	.9488	1.1203	1.2018	1.1227	.2785
10	.2294	.1943	1.0279	.8697	1.1544	1.1069	.2458
11	.2294	.2155	.8539		1.0753	1.0722	.2429
12	.2458	.2753	.8223		1.0562	1.085	.2321
13	.2321	.2591	.8124		1.0402	1.0364	.2294
14	.1989	.08	.8436		1.0437	1.0202	.2294
15	.0829	.144	.3593		1.0562	1.0978	.2429
16	.1475	.176	.7116	.4696	1.0562	1.1012	.2321
17	.1326	.208	.0949	.1865	.1865	.0819	.2543
18	.1326	.192	.1265	.1696	.218	.1475	.2713
19	.1147	.208	.2056	.1696	.218	.2486	.2683
20	.1147	.2429	.2561	.2347	.2515	.1989	.2347
21	.0655	.1943	.2401	.285	.2515	.213	.218
22	.9069	1.0526	.2241	.2515	.2458	.2155	1.1822
23	.8421	.9602	.2286	.213	.1943	.2155	1.1227
24	.9878	.7842	.8421	.1898	.1989	.1966	.213
Max	1.1702	1.0526	1.0279	1.1203	1.2018	1.1227	1.1822
Min	.0655	.08	.0949	.1696	.1865	.0819	.1966
Avg	.5044	.4744	.6170	.3019	.5140	.5059	.3202

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 201 / 11 KV SANMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953	.1905	.0953
6	.1905	.1905	.1905	.1905	.0953	.1905	.1905
7	.1905	.1905	.1905	.1905	.1905	.0953	.0953
8	.1905	.0953	.0953	.1905	.1905	.0953	.0953
9	.0953	.0953	.0953	.0953	.0953	.0953	.0953
10	.0953	.0953	.0953	.0953	.0953	.0953	.0953
11	.0953	.0953	.0953	.0953		.0953	.0953
12	.0953	.0953	.0953		.0953	.0953	.0953
13	.0953	.0953	.0953		.0953	.0953	.0953
14	.0953	.0953	.0953		.0953	.0953	.0953
15	.0953	.0953	.0953		.0953	.0953	.0953
16	.0953	.0953	.0953		.0953	.0953	.0953
17	.0953	.0953	.0953		.0953	.0953	.0953
18	.0953	.0953	.1905		.1905	.0953	.0953
19	.1905	.1905	.1905	.1905	.1905	.1905	.1905
20	.1905	.1905	.1905	.1905	.1905	.1905	.1905
21		.1905	.1905	.1905	.1905	.1905	.1905
22	.0953	.1905	.1905	.0953	.0953	.1905	.1905
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1160	.1191	.1231	.1289	.1201	.1191	.1151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 202 / 11 KV GHOLESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499	.5068	.503	.2241	.3361	.2075	.1698
2	.4915	.543	.5083	.2427	.3395	.2075	.1698
3	.4287	.5373	.4938	.2829	.2427	.3584	.1886
4	.5083	.5258	.5788	.3239	.2614	.4338	.2452
5	.8059	.5258	.7167	.362	.3547	.5281	.3018
6	1.7372	1.0454	1.0288	.4763	.547	.4904	.5658
7	1.4045	1.3676	1.0374	.4527	.4854	.3109	.3772
8	.2263	.2427	.3174	.2587	.2427	.2241	.2452
9	.168	.2075	1.0456	.9054	1.1506	1.0829	.1494
10	.1494	.1698	1.251	1.0562	1.1883	1.2136	.1494
11	.1494	.1307	1.0454	.9431	1.1949	1.1694	.1097
12	.1509	.1307	1.0185		1.3443	.7922	.1097
13	.1509	.1307	1.0374		1.307	.7356	.1097
14	.1494	.1494	.743		1.2826	.7922	.1097
15	.1417	.1478	1.0098		.9522	.8299	.1307
16	.1791	.1294	.9619		.8962	.8865	.1494
17	.2054	.2033	.2075		.2452	.2075	.2054
18	.2829	.2378	.3018		.2075	.2829	.2987
19	.3206	.3547	.3395	.4481	.3395	.3395	.3547
20	.3018	.4338	.3961	.5601	.415	.4338	.4338
21	.3018	.3584	.3395	.3734	.3018	.3584	.3206
22	.4024	.5281	.2829	.3361	.2641	.2829	.4668
23	.4207	.4915	.2829	.3206	.2641	.2452	.4481
24	.499	.5415	.5079	.2452	.3206	.2452	.2075
Max	1.7372	1.3676	1.251	1.0562	1.3443	1.2136	.5658
Min	.1417	.1294	.2075	.2241	.2075	.2075	.1097
Avg	.4198	.4016	.6648	.4595	.6035	.5274	.2507



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 203 / 11 KV KONIKUNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.427		.2778	.0943	.0934	.0943	.0943
2	.4001		.25	.0943	.0924	.0943	.0943
3	.3768		.2968	.0943	.0914	.0943	.0943
4	.4862		.3201	.0953	.0924	.1132	.0934
5	.663		.3521	.1143	.112	.132	.112
6	1.073		.421	.1524	.1698	.0943	.1307
7	.7968		.5201	.132	.128	.0914	.128
8	.0924		.0905	.1254	.1075	.0905	.0895
9	.0934		.4862		.9221	.7209	.0886
10	.0886	.3953	.5407		.9503	.7432	.0876
11	.0876	.0857	.5992		.8583	.6562	.0857
12	.0886	.0886	.6241		.8697	.5792	.0867
13	.0914	.0934	.6539		.8551	.5792	.0857
14	.0905	.0934	.6226		.828	.5944	.0876
15	.0848	.0943	.6167		.759	.6173	.0867
16	.081	.0943	.5944		.6019	.6327	.0858
17	.0857	.0934	.0934		.0934	.0914	.0895
18	.0914	.0943	.0934		.0943	.0924	.0914
19	.112	.0943	.0924	.1267	.0934	.0924	.0924
20	.1132	.0943	.1294	.1463	.1307	.1478	.112
21		.0943	.1307	.1294	.0934	.1307	.0943
22		.3201	.112	.0934	.0943	.112	.4161
23		.2968	.0934	.0924	.0943	.0934	.4424
24	.4321		.2932	.0943	.0943	.0943	.0934
Max	1.073	.3953	.6539	.1524	.9503	.7432	.4424
Min	.081	.0857	.0905	.0924	.0914	.0905	.0857
Avg	.2788	.1452	.3460	.1132	.3466	.2826	.1234

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 204 / 11 KV SANAMADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0743	.0734	.0734	.0734	.0734	.0734
2	.0753	.0743	.0734	.0734	.0734	.0734	.0734
3	.0781	.0743	.0734	.0734	.0734	.0734	.0734
4	.0857	.0743	.0734	.0734	.0734	.0734	.0734
5	.0876	.0743	.0734	.1027	.1027	.1027	.0734
6	.0876	.0743	.0734	.1467	.1467	.1614	.0734
7	.0886	.0743	.0734	.176	.176	.1907	.088
8	.0762	.0743	.0734	.0734	.0734	.1907	.0734
9	.1372	.1505	.0743		.0734	.0734	.0734
10	.1677	.1505	.0743		.0734	.0734	.1174
11	.1739	.1189	.0743		.0734	.0734	.1174
12	.1372	.104	.0743		.0734	.0734	.1027
13	.1389	.1174	.0743		.0734	.0734	.0734
14	.1189	.1174	.0743		.0734	.0734	.088
15	.1174	.088	.0743		.0734	.0734	.0724
16	.1027	.0734	.0743		.0734	.0734	.1014
17	.0734	.0734	.0743		.0734	.0734	.0724
18	.0734	.0734	.0743		.0734	.0734	.0724
19	.0734	.0734	.0743	.0734	.0734	.0734	.0734
20	.0753	.0734	.0734	.0734	.0734	.0734	.0734
21	.0753	.0734	.0734	.0734	.0734	.0734	.0734
22	.0753	.0734	.0734	.0734	.0734	.0734	.0734
23	.0743	.0734	.0734	.0734	.0734	.0734	.0734
24	.0724	.0734	.0734	.0734	.0734	.0734	.0734
Max	.1739	.1505	.0743	.176	.176	.1907	.1174
Min	.0724	.0734	.0734	.0734	.0734	.0734	.0724
Avg	.0974	.0876	.0738	.0881	.0820	.0881	.0805

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 205 / 11 KV GHOLESHWAR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0943	.0924	.0886	.0867	.0934
2	.0895	.0895	.0953	.0924	.0943	.0857	.0943
3	.0914	.0914	.0953	.0934	.1867	.0886	.0943
4	.0934	.0934	.0943	.0934	.2829	.181	.0943
5	.2829	.2829	.0934	.1886	.2858	.2801	.1867
6	.1829	.1829	.1905	.2858	.2858	.1886	.2772
7	.1848	.1848	.1848	.2743	.1696	.1772	.1829
8	.0886	.0886	.1734	.1734	.1638	.0905	.1677
9	.1753	.0857	.0895	.1715	.0886	.0857	.1696
10	.1734	.0848	.0895	.1734	.0886	.0848	.1677
11	.0857	.0867	.0886	.0905	.0876	.0848	.0857
12	.0867	.0857	.0886		.0857	.0838	.0867
13	.0876	.0876	.0867		.0876	.0857	.0895
14	.0876	.0895	.0867		.0857	.0867	.0886
15	.0867	.0867	.0876		.0848	.0886	.0914
16	.1658	.0848	.0886		.1696	.0895	.0934
17	.1646	.1715	.1734		.1646	.0876	.0895
18	.197	.1753	.2658		.168	.1734	.1753
19	.2427	.2601	.2515	.3429	.2054	.2601	.2572
20	.2572	.2715	.2103	.3582	.2614	.2686	.2686
21	.1753	.1829	.2715	.2743	.2715	.1829	.181
22	.1886	.1867	.181	.1734	.1772	.1867	.0914
23	.0886	.0934	.0914		.181	.0934	.0914
24	.0867	.0867	.0943	.0914	.0876	.0886	.0934
Max	.2829	.2829	.2715	.3582	.2858	.2801	.2772
Min	.0857	.0848	.0867	.0905	.0848	.0838	.0857
Avg	.1437	.1341	.1361	.1856	.1605	.1337	.1380

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 201 / 11 KV KONTEBOBLAD MIX  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6802	.4744	.7373	.1492	.1334	.1524	
2	.6722	.4744	.7459	.1296	.1334	.1524	
3	.6562	.4744	.8097	.1475	.1524	.1524	
4	.6562	.5668	.8097	.1457	.1524	.1905	
5	.6722	.6478	.9012		.1905	.1905	
6	.1377	.9389	.8002	.16	.1905	.1905	
7	1.1984	1.0242		.1581	.1905	.1905	
8	.112	.1334	.081	.1619	.1905	.1905	
9	.1334	.1524	.6478	.8907	1.2431	1.1603	
10	.1143	.1524	.8029	.9717	1.3336	1.0898	
11	.1143	.0953		.8907	1.073	.9945	
12	.1143	.0572	.9012		.9945		.0762
13	.1334	.0953			.9116		.0762
14	.0953	.1143	.7459		.8288		.0953
15	.1334	.1143	.7116		.7716		.0953
16	.1334	.1334	.8002		.8796		.0953
17	.1143	.1334			.1334		.1524
18	.0762	.1524	.116		.1334		.1905
19	.0953	.1715	.1311	.0953	.1334		.1715
20	.1524	.1524	.1492	.1143	.1334		.1524
21	.1524	.1715	.1677	.0953	.1334		.1715
22	.5535	.8192	.1174	.1143	.1334		.9717
23	.4744	.6478	.1578	.1143	.1334		.8907
24	.6802	.8192		.1372	.1334	.1524	
Max	1.1984	1.0242	.9012	.9717	1.3336	1.1603	.9717
Min	.0762	.0572	.081	.0953	.1334	.1524	.0762
Avg	.3357	.3632	.5439	.2797	.4349	.4006	.2616

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 202 / 11 KV JALYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7611	.6325	.9012	.2458	.2846	.3048
2	.7611	.6325		.2515	.2846	.3048
3	.7522	.6325		.2347	.3201	.3429
4	.7449	.7116		.2035	.3201	.3429
5	.7611	.7907		.3605	.3521	.381
6	1.1305	.9962			.4001	.381
7	.1131	1.0279		.3605	.3201	.381
8	.2429	.1886		.3315	.3041	.381
9	.2829	.1886		1.1603	.3041	.9724
10	.3018	.2452		1.0279		.8855
11	.2829	.3772	1.2146	1.0279	.9762	.9488
12	.2829	.3395	1.065		.9602	
13	.2829	.1886	1.1069		.8802	
14	.2263		1.0279		.8002	
15	.2263	.2987	.9602		.8002	
16		.2829	1.0526		.9602	
17		.3467	.3239		.2477	
18		.3361	.3429		.2858	
19	.3479	.2858	.362	.3163	.2858	
20	.3479	.3048	.3429	.3163	.3239	
21	.3479	.3429	.3277	.3479	.3429	
22	.6642	.8907	.2915	.3005	.381	
23	.6009	.9012	.3277	.2688	.3239	
24	.7773	.6325	.8192	.2949	.2846	.3048
Max	1.1305	1.0279	1.2146	1.1603	.9762	.9724
Min	.1131	.1886	.2915	.2035	.2477	.3048
Avg	.4876	.5032	.6977	.4406	.4671	.4942

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 203 / 11 KV GIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0953	.0762	.7287	.4687	.4572
2	.1334	.0953	.0762	.6478	.3163	.4572
3	.1334	.0953	.0572	.7287	.4744	.4572
4	.1334	.0953	.0572		.5535	.5868
5	.1334	.1143	.0762	.7202	.5735	.6706
6	.1715	.1334	.0953	.8002	.8048	.7545
7	.1334	.1334	.0934	.8907	.8002	.7545
8	.1524	.0953	.0762	.0486	.1334	.0572
9	.8322	.6097	.0762		.1334	.1905
10	.9069	.703	.0572		.1334	.0953
11	.8642	.6325	.0572	.0648	.0953	.0572
12	.7621	.6325	.0762		.0953	.0095
13	.6097	.6325	.0572		.0572	.0095
14		.6802			.0572	.0114
15	.6097	.6478	.0572		.0762	
16	.6173	.7373	.0572		.0953	
17	.0762		.0572		.0572	
18	.0762	.0762	.0762		.0762	
19	.0762		.0572	.1143	.0762	
20	.0953	.0762	.0762	.1334	.0953	
21	.1143	.0762	.0503	.1143	.0953	
22	.1143		.7373	.5716	.4572	
23	.0953	.0572	.6478	.4572	.4572	
24	.2858	.0953	.0572	.6554	.4572	.4572
Max	.9069	.7373	.7373	.8907	.8048	.7545
Min	.0762	.0572	.0503	.0486	.0572	.0095
Avg	.3173	.3102	.1220	.4769	.2767	.3351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 201 / 11 KV KANKESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5953		3.7289	.2385	.2942	.2416	.2747
2	2.5038	1.247	3.6534	.2355	.2934	.237	.2694
3	2.4345	2.7682	3.6534	.234	.301	.2347	.2526
4	2.4116	2.8326	3.4873	.2504	.3033	.2347	.2519
5	2.4032	3.1028	3.2099	.2736	.3094	.2572	.258
6	2.537	3.3733	3.3753	.2774	.3056	.2713	.2782
7	2.8418	1.9166	3.7377	.2828	.2862	.3113	.2965
8	.2872	.7764	2.1963	.3087	.3495	.2804	.3056
9	.2045	.6964	4.6868	5.0408	4.3195	5.1219	.2938
10	.2199	.2529	5.4702	6.0459	6.1042	5.8738	.2992
11	.2376	.2405	5.8776	3.3798	5.9861	6.1324	.338
12	.166	.2245	5.7872	3.3775	5.8966	6.3431	.3163
13	.226	.2107	5.6611		6.2175	3.4858	.2995
14	.2298	.2321	5.5888		6.0246	3.2236	.277
15	.1999	.1976	5.554		5.7228		.2618
16	.109	.2008	5.5106	.25	5.6874	5.2759	.2286
17	.1296	.2422	3.1413	2.4775	3.2	3.1474	.2519
18	.2658	.2521	.3113	.1379	.2461	4.0089	.2423
19	.2767	.3067	.3342	.1509	.3025	2.4394	.2915
20	.1707	.3608	.3658	.1989	.3627	.3597	.3395
21	.1799	.3585	.3642	.2111	.3635	.3658	.3536
22		3.8958	.3285	.2119	.3464	.354	4.7714
23		4.0447	.2808	.1905	.3125	.314	5.6162
24	.1311	2.066	1.8705	.2778	.2949	.2778	3.2381
Max	2.8418	4.0447	5.8776	6.0459	6.2175	6.3431	5.6162
Min	.109	.1976	.2808	.1379	.2461	.2347	.2286
Avg	.9437	1.2956	3.2573	1.1453	2.2429	2.1214	.8169

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 202 / 11 KV MHAISHAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487		.6219	.5487	.5487	.5853	.5487
2	.5487	.6099	.6219	.5121	.5487	.5487	.5487
3	.5487	.5304	.6219	.4755	.5487	.5487	.5487
4	.5487	.5544	.6219	.5121	.5487	.5487	.5487
5	.5853	.5914	.6219	.5487	.567	.5853	.5853
6	.695	.6653	.6584	.6219	.6767	.6401	.695
7	.567	.6283	.6401	.5487	.6219	.6219	.567
8	.5415	.6468	.5487	.5853	.567	.5304	.5487
9	.5415	.5729	.5121	.5304	.5304	.4938	.6767
10	.5228	.5175	.4938	.5304	.5304	.4572	.6767
11	.0678	.6468	.5853		.5853	.4938	.6584
12	.0678	.5359	.567		.6767	.5853	.695
13	.5914	.5544	.567			.5853	.7133
14	.5914	.6838	.6584		.6767		.6401
15	.5914	.6468	.567		.7499		.7133
16	.6283	.7762	.7316		.7316	.6767	.7133
17	.567	.7577	.6584		.7133	.6036	.7865
18	.6401	.6838	.7316		.7133	.6401	.7133
19	.8779	.924	.7865		.9145	.8413	.9511
20		1.0242	.9328		1.0425	.9511	.9694
21		.9511	.8779		.9694	.8413	.9145
22		.823	.823		.8413	.7865	.8596
23		.7499	.6767		.6767	.695	.7682
24	.6036		.7133	.5853	.5853	.6767	.6036
Max	.8779	1.0242	.9328	.6219	1.0425	.9511	.9694
Min	.0678	.5175	.4938	.4755	.5304	.4572	.5487
Avg	.5437	.6852	.6600	.5454	.6767	.6335	.6935



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 203 / 11 KV MAHAVEER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.9027	2.0165	2.0805	2.0024
2	.9012			1.9043	1.993	2.0587	1.9986
3	.9012			1.8928	1.9831	2.0145	1.9986
4	.9012			1.9033	1.9777	2.0313	1.9872
5	.9012			1.9469	1.9777	2.0393	1.9658
6	.9012			1.9846	1.9582	2.0363	1.9559
7	.8848			2.0237	1.9666	2.0553	1.9586
8				1.9673	1.0684	1.089	1.0471
9	.8619	1.5434					1.5345
10	1.0277	1.9547					1.9082
11	1.094	1.9107					2.1285
12	1.0442	2.0451					2.1407
13	.9282	.8901					2.1559
14	.9282	1.176					2.143
15	1.0774	2.3074					2.1415
16	1.0442	2.2737					2.1822
17		1.2498					1.1652
18		1.0277		.0259			
19				.0046			
20		1.0242					
22			1.533	.6744	1.6941	1.6045	
23			1.9419	1.105	2.0759	2.069	
24	.9339		1.073	1.9767	2.0667	2.0599	.9339
Max	1.094	2.3074	1.9419	2.0237	2.0759	2.0805	2.1822
Min	.8619	.8901	1.073	.0046	1.0684	1.089	.9339
Avg	.9554	1.5821	1.5160	1.4856	1.8889	1.9217	1.8527

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 204 / 11 KV NARWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8531		6.1454	.4761	.4656	.4868	.5151
2	3.6381	3.1333	6.1423	.455	.4732	.4534	.506
3	3.5894	4.0661	6.0494	.4504	.4656	.4473	.503
4	3.5543	4.1362	5.9549	.467	.4717	.4473	.503
5	3.6031	4.5014	5.9454	.4883	.4748	.4746	.5121
6	3.911	1.9052	6.4952	.5156	.5487	.5202	.5258
7	4.51	6.4578	6.7798	.5639	.5685	.5792	.5884
8	.555	.7153	.0527	.5613	.5822	.5929	.3307
9	.5142	.5249	.5426	7.9815	7.4333	7.1197	
10	.5125	.5369	7.4665	7.5164	7.1804	7.742	.4253
11	.5519	.5443	7.5124	8.3101	7.9835	7.6817	.471
12	.5336	.5083	7.9788	1.2605	4.3423	7.4684	.4634
13	.4074	.4595	7.9329		4.0786	4.1061	.5182
14	.5671	.4489	8.2244		4.3027		.5212
15	.555	.4353	7.9805		8.2777		.535
16	.5489	.4397	7.7742	3.6168	7.5034	.0183	.567
17	.5914	.5293	.4963	.7697	.4923	7.7473	.567
18	.6005	.6383	.5004	.317	.5258	.9023	.6066
19	.5367	.6639	.6307	.3704	.6341	.6402	.6432
20	.3094	.7362	.7217	.4298	.7179	.7712	.7026
21		.6996	.7066	.4207	.7102	.7453	.6798
22		6.8816	.6173	.381	.6295	.6995	8.2488
23		7.0493	.5491	.3567	.5264	.6173	8.1893
24	.2347	3.7464	3.2921	.4944	.4702	.5097	4.4719
Max	4.51	7.0493	8.2244	8.3101	8.2777	7.7473	8.2488
Min	.2347	.4353	.0527	.317	.4656	.0183	.3307
Avg	1.6037	2.1634	4.4372	1.7239	2.4941	2.3078	1.3737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 205 / 11 KV MHAISHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0671		.1638	5.2652	5.1189	5.1746	4.4563
2	2.074	.0486	.163	5.1128	4.902	5.0763	4.4197
3	2.071	.0945	.1638	4.9589	4.7805	5.0141	4.4022
4	2.0725	.1441	.1615	4.8438	4.6822	4.9135	4.3092
5	2.0748	.1433	.163	4.8133	4.5717	4.8244	4.2962
6	2.2035	.0328	.1787	4.8529	4.6409	4.8497	4.4372
7	2.2104	.1456	.2004	5.0359	4.8701	5.0353	4.5896
8	.2236	.1126	.2187	2.9751	2.8742	2.8725	2.5454
9	5.4466	3.1661	.1798	.1897	.245	.2045	3.6442
10	6.0257	4.638	.1399	.1741	.1961	.1907	5.3208
11	5.9854	4.1876	.1348	.109	.2014	.213	5.572
12	3.4645	4.835	.1684	.1151	.2113	.2144	5.5373
13	5.6432	5.0077	.1653		.2268	.1334	5.4772
14	5.5677	2.9271	.1684	.1014	.2167	.1425	5.287
15	5.5476	2.7006	.1924	.125	.2151		5.2306
16	5.4405	5.4948	.1901	.1219	.2315	.1524	5.204
17	3.0026	3.1402	.1993	.0854	.2113	.1257	2.9137
18	.2195	.2067	.2038	.1036	.2283	.2189	.1791
19	.2099	.2248	.2038	.1181	.2184	.2083	.1984
20	.1143	.2195	.189	.1196	.2551	.2092	.1738
21	.1181	.2115	.2092	.125	.2466	.2014	.1837
22		.2054	3.7273	1.1683	3.7105	3.0944	.1829
23		.1676	5.4801	2.8418	5.2334	4.7847	.1646
24	2.1052	.0998	3.0346	5.3094	5.253	4.9172	2.1989
Max	6.0257	5.4948	5.4801	5.3094	5.253	5.1746	5.572
Min	.1143	.0328	.1348	.0854	.1961	.1257	.1646
Avg	2.9040	1.6589	.6666	2.1159	2.2309	2.2944	3.3718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 206 / 11 KV NARWAD GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2225		.211	.2065	.2217	.209	.2316
2	.2225	.1623	.1989	.2004	.2004	.2029	.2225
3	.221	.1996	.195	.1989	.1973	.2006	.2194
4	.2187	.1943	.1912	.2156	.1943	.1983	.221
5	.2408	.2042	.1905	.2126	.1943	.2214	.2606
6	.2812	.253	.2469	.2484	.2743	.2574	.282
7	.2736	.2499	.2454	.217	.2681	.2681	.2758
8	.2269	.2408	.2164	.1943	.2427	.2212	.2476
9	.1918	.2126	.1014	.1859	.2098	.1915	.2255
10	.1775	.192	.1585	.17	.1968	.193	.2095
11	.1615	.1973	.1752	.0914	.1907	.1837	.1943
12	.1263	.1973	.1889	.0907	.0983	.2095	.2118
13	.1246	.1943	.1867			.1235	.2179
14	.2461	.2034	.1996	.1204			.2034
15	.2324	.2164	.1867	.1242	.1109		.2065
16	.2191	.2316	.1958	.1227	.2704	.1921	.2126
17	.2567	.2484	.2522	.1273	.3033	.2919	.2309
18	.3117	.2781	.2377	.1509	.317	.2896	.2736
19	.2835	.3216	.3033	.1372	.3601	.3551	.3178
20	.1638	.423	.3818	.2004	.422	.4062	.4199
21		.4092	.397	.208	.4081	.4169	.3856
22		.3597	.365	.2004	.3728	.3711	.3727
23		.3315	.3079	.1654	.2839	.3086	.2804
24	.1097	.1372	.2499	.2423	.2469	.2572	.2499
Max	.3117	.423	.397	.2484	.422	.4169	.4199
Min	.1097	.1372	.1014	.0907	.0983	.1235	.1943
Avg	.2149	.2460	.2326	.1753	.2538	.2531	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 207 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492		.0497	.048	.0663	.0554	.0492
2	.0492	.0339	.0509	.048	.0663	.0554	.0492
3	.0492	.0339	.0509	.048	.0663	.0554	.0492
4	.0492	.0339	.0509	.048	.0663	.0554	.0492
5	.0492	.0324	.0509	.048	.0663	.0554	.0492
6	.0492	.0486	.0503	.048	.0663	.0554	.0492
7	.0474	.0486	.0678	.048	.0663	.0554	.0474
8	.0503	.0655	.0671	.064	.0663	.0739	.0663
9	.0503	.0655	.0678	.064	.0663	.0739	.0663
10	.0671		.0678	.064	.0739	.0739	.0633
11	.0678	.0663	.0678		.0739	.064	.0633
12	.0678	.0663	.0678		.0739	.0663	.0633
13	.0678	.0663	.0678		.0739		.0655
14	.0663	.0663	.0655		.0739		.0655
15	.0663	.0663	.0655		.0739		.0671
16	.0648	.0663	.0655		.0739	.0648	.0671
17	.0648	.0497	.0655		.0554	.064	.0671
18	.0509	.0497	.0655		.0554	.0663	.0671
19	.0509	.0486	.0655		.0554	.0663	.0663
20		.0486	.0655		.0554	.0655	.0663
21		.0503	.0655		.0554	.0678	.0663
22		.0492	.0655		.0554	.0655	.0671
23		.0492	.064		.0554	.0492	.0678
24	.0492		.0497	.048	.0663	.0554	.0492
Max	.0678	.0663	.0678	.064	.0739	.0739	.0678
Min	.0474	.0324	.0497	.048	.0554	.0492	.0474
Avg	.0563	.0526	.0617	.0524	.0653	.0621	.0603

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 203 / 11 KV Subhashnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5624	.4595	.5182	.4954	.4999	.5274	.5365
2	.5274	.4458	.5068	.4733	.4824	.5014	.5129
3	.5213	.4435	.4915	.4679	.4656	.4969	.4938
4	.5068	.4306	.4755	.4458	.4504	.4435	.4908
5	.5136	.4359	.4832	.4435	.4755	.4687	.4984
6	.6036	.4931	.586	.5182	.551	.5571	.599
7	.6592	.5693	.5914	.5769	.6051	.5784	.6257
8	.615	.5754	.5525	.5655	.5639	.5472	.5868
9	.5487	.5426	.5114	.4984	.5114	.4946	.5136
10	.567	.5632	.4877	.4473	.5296	.519	.5312
11	.5738	.5754	.471	.4656	.5517	.5243	.5456
12	.5738	.6287	.4999	.4618	.5533	.5738	.5723
13	.6234	.6165	.4969	.4481	.5609	.5784	.5792
14	.5609	.5434	.4854	.4435	.5007	.5319	.5502
15	.6211	.5982	.5274	.4786	.5396	.5472	.5815
16	.6013	.6081	.5647	.5144	.5464	.5944	.5571
17	.6554	.6371	.5815	.5799	.5601	.602	.5487
18	.6935	.7194	.647	.6043	.66	.6973	.6257
19	.8512	.7834	.7781	.7529	.772	.8147	.8002
20	.7324	.8223	.8269	.7705	.836	.8581	.8535
21	.6424	.7735	.7712	.7164	.7888	.7964	.7766
22	.6836	.7331	.7301	.6874	.7285	.7468	.7484
23	.5929	.6882	.6546	.6493	.6699	.7202	.6668
24	.4946	.5792	.5281	.5365	.5921	.5975	.5594
Max	.8512	.8223	.8269	.7705	.836	.8581	.8535
Min	.4946	.4306	.471	.4435	.4504	.4435	.4908
Avg	.6052	.5944	.5736	.5434	.5831	.5966	.5981

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 201 / 11 KV Dhavali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2192		2.0805	.0191	.0191	.0191	.0221
2	2.2192	1.7337	2.0805	.0191	.0191	.0191	.0111
3	2.2192	1.7337	2.0805	.0191	.0191	.0191	.0124
4	2.2192	1.8204	2.0805	.0191	.0191	.0191	.0152
5	2.2192	1.893	2.0805	.0191	.0191	.0191	.0171
6	2.2885	1.9631	2.1033	.0191	.0191	.0191	.0175
7	2.2018	1.9071	1.9669	.0191	.0191	.0191	.0156
8	.0191	.0191	.0191	.0191	.0191	.0191	.0082
9	.0191	.0191	2.3579	2.2885	2.489	2.7519	.0191
10	.0191	.0191	2.4013	2.4539	2.4619	2.6006	.0191
11	.0191	.0191	2.5486	2.3752	2.3663	2.6353	.0191
12	.0191	.0191	2.4619		2.332	2.6526	.0191
13	.0191	.0191	2.4619		2.332		.0191
14	.0191	.0191	2.4619		2.3663		.0191
15	.0191	.0191	2.4792		2.4348		.0191
16	.0191	.0191	2.4863		2.4966	2.4966	.0191
17	.0191	.0191	.0191		.0191	2.1434	.0191
18	.0191	.0191	.0191		.0191	.0198	.0191
19	.0191	.0191	.0191		.0191	.0236	.0191
20		.0191	.0191		.0191	.0206	.0191
21		.0191	.0191		.0191	.0221	.0191
22		2.191	.0191		.0191	.0221	1.5746
23		2.1672	.0191		.0191	.0259	2.5659
24	2.2192		2.1152	.0191	.0191	.0191	.0206
Max	2.2885	2.191	2.5486	2.4539	2.4966	2.7519	2.5659
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0082
Avg	.9017	.7126	1.5167	.6075	.8160	.7422	.1887

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 202 / 11 KV Nilaji Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	2.9237	2.8685	2.8639	2.8334
2	.0191	.0191	.0191	2.9256	2.7915	2.8003	2.8067
3	.0191	.0191	.0191	2.9088	2.7751	2.753	2.755
4	.0191	.0191	.0191	2.8783	2.7351	2.7439	2.6102
5	.0191	.0191	.0191	2.8913	2.7161	2.7629	2.5995
6	.0191	.0191	.0191	2.9317	2.8098	2.8132	2.6498
7	.0191	.0191	.0191	2.9732	2.8001	2.7396	2.7915
8	.0191	.0503	.0191	.0191	.1565	.0374	.0732
9	3.8192	3.557	.0191	.0191	.0191	.0191	3.5147
10	3.888	3.5976	.0191	.0191	.0191	.0191	3.5619
11	3.9015	3.8569	.0191	.0191	.0191	.0191	3.7479
12	3.5456	3.8714	.0191	.0191	.0191	.0191	3.7128
13	3.6493	3.7197	.0191	.0191	.0191		3.5985
14	3.6128	3.3402	.0191		.0191		3.5395
15	3.5372	3.3235	.0191		.0191		3.4995
16	3.7852	2.6776	.0191		.0191	.0191	3.4939
17	.2355	.0206	.0191		.0191	.0191	.0915
18	.0191	.0191	.0191		.0191	.0191	.0191
19	.0191	.0191	.0191		.0191	.0191	.0191
20	.0191	.0191	.0191		.0191	.0191	.0191
21	.0191	.0191	.0191	.0678	.0191	.026	.0191
22	.0191	.0191		1.5653	2.8902	2.8016	.0191
23	.0191	.0191	2.9652	1.5935	2.9691	2.8795	.0191
24	.0343		1.6248	2.9435	2.8799	2.8551	1.3245
Max	3.9015	3.8714	2.9652	2.9732	2.9691	2.8795	3.7479
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	1.2615	1.2288	.2170	1.5716	1.1933	1.3452	2.0549



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189		.3155	.3155	.3018	.3077	.3403
2	.3012	.2715	.3155	.298	.3086	.3077	.3395
3	.3012	.2715	.3155	.298	.2743	.3045	.3224
4	.3012	.2715	.3155	.298	.2629	.3224	.3224
5	.3189	.2896	.3155	.3155	.2629	.3544	.3582
6	.3189	.3045	.3189	.3155	.2686	.3898	.3582
7	.3506	.3294	.3441	.3052	.2743	.3772	.3224
8	.407	.3856	.373	.3688	.3521	.4287	.407
9	.407	.421	.4321	.5144	.3856	.5375	.4801
10	.503	.4973	.4527	.5658	.5087	.5487	.5365
11	.547	.4641	.503	.5596	.3856	.5658	.5636
12	.502	.4475	.5304	.57	.4858	.5596	.503
13		.4527	.57	.5636	.4973		.5144
14	.39	.4191	.5935		.503		.5144
15	.4578	.4578	.5533		.4694		.5144
16	.4588	.4191	.5365		.4527	.5426	.4973
17	.4915	.4801	.4915		.503	.6001	.4748
18		.4424	.4696		.5087	.57	.4694
19	.3772	.4862	.4527		.4801	.5375	.5093
20		.4239	.4287		.4557	.4607	.3582
21		.4207	.4115		.443	.4119	.4024
22		.3582	.3898		.4163	.394	.3109
23		.3403	.3277	.3401	.3292	.3801	.3326
24	.3494		.3506	.3401	.3315	.3258	.3403
Max	.547	.4973	.5935	.57	.5087	.6001	.5636
Min	.3012	.2715	.3155	.298	.2629	.3045	.3109
Avg	.3945	.3934	.4211	.3979	.3942	.4394	.4205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 204 / 11 KV Takali Bolwad Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1628		1.8351	.168	.1663	.1646	.181
2	2.1879	1.1336	1.8351	.168	.1663	.1646	.181
3	2.1548	1.2146	1.8351	.168	.1478	.1663	.1829
4	2.1382	1.2146	1.8351	.168	.1478	.1663	.1829
5	2.1382	1.4575	1.8351	.1867	.1663	.1867	.1848
6	2.1382	1.7859	1.989	.1867	.1867	.2054	.1848
7	2.3537	2.0553	1.9109	.2012	.181	.1907	.2012
8	.1646	.1772	.1629	.1433	.1629	.1433	.1791
9	.1629	.1509	2.3137	2.0222	2.1714	2.2211	.1433
10	.1612	.1387	2.1879	1.9662	2.2377	2.2874	.1578
11	.1595	.1372	2.652	1.9826	1.8244	2.1879	.1357
12	.1543	.1526	2.5526		1.9044	2.0645	.1357
13	.1543	.1509	2.5526		1.8884		.1372
14	.1543	.1475	2.5069		1.8947		.1402
15	.1543	.1402	2.4577		1.7078		.1402
16	.144		2.3482		1.7078	1.7695	.1372
17	.1326	.1147	.1372		.1417	1.704	.1612
18	.1526		.1543		.1433	.1526	.1433
19	.2149	.2012	.2012		.2218	.1829	.1663
20		.2218	.2218		.2218	.2218	.1848
21		.2241	.2033		.2241	.2241	.1848
22		1.7901	.2054		.2054	.2012	1.6575
23	.0191	1.8842	.168		.1848	.1829	1.6575
24	2.2119		1.8351	.168	.1663	.1646	.1791
Max	2.3537	2.0553	2.652	2.0222	2.2377	2.2874	1.6575
Min	.0191	.1147	.1372	.1433	.1417	.1433	.1357
Avg	.9245	.7246	1.4973	.6274	.7571	.7120	.2891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 206 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886		.2641	.2641	.2641	.2858	.2452
2	.1886	.2452	.2641	.2641	.2641	.2858	.2452
3	.1886	.2452	.2641	.2641	.2263	.2667	.2452
4	.1886	.2452	.2641	.2641	.2263	.2667	.2452
5	.1886	.2829	.2641	.2641	.2829	.2858	.2452
6	.2452	.3206	.3018	.2829	.2829	.3048	.2829
7	.2263	.3018	.2641	.2829	.2641	.2641	.2641
8	.1886	.2452	.2452	.2075	.2641	.2614	.2263
9	.132	.2263	.2263	.1886	.2263	.2829	.2075
10	.132	.2263	.1698	.168	.2263	.2263	.1886
11	.132	.2263	.2263	.1524	.1509	.2263	.1886
12	.1509	.2452	.2641	.1524	.2641	.2452	.1886
13	.132	.2452	.2452	.1905	.2452		.1886
14	.132	.2452	.2452		.2452		.1886
15	.2075	.2452	.2263		.2641		.1886
16	.2263	.2263	.2263		.2452	.1886	.1886
17	.1886	.2263	.2263		.1886	.2263	.1698
18	.2263	.2452	.2263		.1886	.2263	.2263
19	.3018	.2829	.3206		.2452	.2829	.2829
20		.3206	.3206		.2829	.3018	.3206
21		.3206	.3018		.2667	.2829	.3206
22	.0191	.3239	.2829		.2667	.3018	.3206
23	.0191	.3018	.2829		.3048	.2829	.1886
24	.1886		.2641	.2641	.2641	.3018	.2452
Max	.3018	.3239	.3206	.2829	.3048	.3048	.3206
Min	.0191	.2263	.1698	.1524	.1509	.1886	.1698
Avg	.1723	.2633	.2578	.2293	.2479	.2665	.2334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 202 / 11 KV Malgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.3277	.3742	2.2878	2.0134	2.2398	2.2436
2	.4641	.3109	.3719	2.111	2.175	2.0424	2.1079
3	.4633	.3102	.3673	1.9875	2.1384	2.0142	2.0652
4	.4771	.3147	.3711	1.9608	2.2146	1.9829	1.9974
5	.4931	.3361	.3993	1.9982	2.2321	2.0896	1.9791
6	.5647	.4199	.4877	2.5286	2.4859	2.5217	2.2108
7	.5975	.4473	.4999	3.11	2.9371	3.2785	2.556
8	.5815	.4054	.4382	.3849	.4062	.4672	.4153
9	2.889	2.2763	.4016	.4191	.423	.4557	2.5774
10	3.1939	2.7	.3765	.397	.3399	.4603	2.7907
11	2.7183	2.2009	.4062	.4214	.3643	.4039	2.8548
12	2.4882	.5548	.4245	.4504	.3704	.4252	2.9294
13	2.8349	2.6459	.4176	.4367	.4146	.4222	2.8487
14	2.8471	2.5446	.4237	.4268	.4047	.4534	2.6231
15	2.9477	2.8052	.3635	.4115	.4146	.4412	2.7
16	2.3685	2.9005	.3871	.4115	.4641	.365	2.8212
17	.3605	.6348	.4374	.1638	.4694	.4237	.4679
18	.4397	.4923	.5037	.3254	.5563	.506	.535
19	.4047	.5281	.5441	.5754	.5677	.644	.5662
20	.4306	.599	.6013	.6257	.6424	.7377	.6485
21	.3871	.5853	.5761	.6356	.6005	.913	.6135
22	.3856	.5182	2.9005	2.7664	2.4501	2.6627	.5853
23	.3574	.423	2.9241	2.6185	2.4463	2.6353	.5182
24	.3338	.3826	2.5286	2.2931	2.3129	2.4196	.4435
Max	3.1939	2.9005	2.9241	3.11	2.9371	3.2785	2.9294
Min	.3338	.3102	.3635	.1638	.3399	.365	.4153
Avg	1.2294	1.0693	.7303	1.2395	1.2435	1.2919	1.7541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 201 / Soni Gavathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6521	.5938	.5771	.5442	.5809	.5809	.5651
2	.6075	.5583	.5778	.2942	.5793	.5816	.5522
3	.6007	.5514	.5755	.2949	.5672	.5717	.5461
4	.5854	.5748	.5641	.2766	.558	.5717	.5618
5	.6361	.6051	.5883	.2873	.5735	.596	.5876
6	.7438	.6817	.7303	.3422	.6619	.6719	.6651
7	.7038	.5994	.6278	.3498	.6299	.6521	.5761
8	.5583	.5971	.4803	.2713	.5875	.4862	.462
9	.559	.5677	.4952	.2698	.5094	.5014	.4552
10	.5739	.5546	.479	.253	.4967	.3864	.4481
11	.5672	.5518	.5091	.2423	.502	.5	.5297
12	.546	.5491	.5266	.2522	.5399	.5161	.5373
13	.565	.2698	.5289	.2896	.5208	.533	.5674
14	.6015	.5178	.5636	.2797	.534	.5533	.5392
15	.5974	.5308	.5662	.2995	.5441	.5525	.5297
16	.5818	.5201	.5605	.2919	.5638	.5571	.5407
17	.529	.5951	.5289	.2683	.5529	.5188	.5395
18	.5791	.6276	.599	.2782	.5456	.6607	.5868
19	.7901	.8529	.8033	.7625	.7632	.827	.7358
20	.4161	.9615	.9461	.9553	.8816	.9569	.8905
21		.9168	.8772	.8688	.849	.9191	.86
22	.7659	.8358	.7952	.7807	.7986	.7775	.7704
23	.7198	.7251	.6614	.6885	.7167	.6836	.655
24	.7585	.5999	.631	.5518	.6009	.6037	.5895
Max	.7901	.9615	.9461	.9553	.8816	.9569	.8905
Min	.4161	.2698	.479	.2423	.4967	.3864	.4481
Avg	.6190	.6224	.6164	.4164	.6107	.6150	.5955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 202 / 11 KV Bhose Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6075	.6479	.5994	.5955	.6049	.566	.5872
2	.4896	.5523	.5551	.3125	.6014	.5384	.566
3	.546	.5361	.5487	.3113	.5984	.5448	.563
4	.5452	.5254	.5395	.3025	.5931	.5372	.5365
5	.5426	.4412	.4351	.3025	.5899	.4332	.5346
6	.5594	.4538	.4664	.2233	.4637	.4557	.4335
7	.5502	.4717	.4544	.2362	.4306	.4618	.4342
8	.716	.4191	.4149	.2397	.3913	.4321	.3855
9	.8204	.374	.4283	.2801	.5076	.355	.4252
10	.6432	.3818	.3586	.3338	.7198	.4218	.4405
11	.7921	.7147	.4584	.3147	.7653	.5536	.6908
12	.8348	.5247	.7136	.3688	.8001	.7455	.711
13	.7986	.4176	.7155	.3864	.6607	.9039	.6698
14	.493	.672	.5932	.3551	.6104	.7122	.6169
15	.6557	.6559	.8032	.3414	.6729	.7773	.5647
16	.7804	.9985	.9865	.4256	.967	.6817	.6722
17	.7446	.6531	.8002	.3399	.7604	.6853	.6572
18	.6644	.539	.7887	.2473	.5296	.7188	.6615
19	.5834	.5759	.5762	.2035	.4885	.5405	.4382
20	.3022	.6253	.5423	.2671	.5678	.5731	.5331
21		.5007	.5281	.2675	.5613	.5253	.5346
22	.4704	.595	.7114	.2808	.5276	.7083	.7
23	.6882	.6348	.6969	.6966	.5052	.7304	.6577
24	.6859	.6466	.6506	.6058	.6237	.5908	.6517
Max	.8348	.9985	.9865	.6966	.967	.9039	.711
Min	.3022	.374	.3586	.2035	.3913	.355	.3855
Avg	.6310	.5649	.5986	.3432	.6059	.5914	.5694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 203 / 11 KV Siddhewadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2643	.7301	.5506	.0857	.0943	.0943	.1132
2	1.0591	.7141	.5344		.0943	.0943	.1132
3	.8226	.7118	.5344		.0943	.0943	.1132
4	.823	.7716	.5344		.0943	.0943	.1132
5	1.0921	.8284	.5668		.0934	.1132	.1132
6	1.3969	1.073	.5992		.0934	.132	.132
7	2.1467	1.4969	.7449		.112	.1132	.0943
8	.1963	.1986	.1132		.0934	.1307	.1132
9	.2001	.197	.8907		1.0722	1.1498	.1132
10	.2047	.1986	.9145		1.2146	1.1822	.1029
11	.1036	.1871	.9907		1.166	1.1822	.0857
12		.1932	.945		1.0526	1.1498	.1029
13	.1204	.0983	.8383		.8097	1.0526	.1029
14	.1654	.1864	.8535		.8583	1.1012	.1029
15	.1639	.1887	.884		.9717	1.2146	.1029
16	.197	.208	.9145		1.0364	1.247	.1029
17	.1948	.17	.1029		.0934	.0943	.1029
18	.2138	.2515	.12		.0934	.1132	.1029
19	.2217	.2382	.1372		.1307	.132	.12
20	.1235	.2466	.1372		.132	.132	.1715
21		.2966	.1372		.132	.132	.1372
22	.7118	1.3941	.1029		.1132	.132	.9907
23	.8276	1.3859	.1029	.0934	.112	.1132	.8535
24	1.0183	1.0441	.5668	.0857	.0934	.1132	.1132
Max	2.1467	1.4969	.9907	.0934	1.2146	1.247	.9907
Min	.1036	.0983	.1029	.0857	.0934	.0943	.0857
Avg	.6031	.5420	.5340	.0883	.4105	.4628	.1797

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 204 / Soni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336		.7935	.1372	.0137	.1509	.1509
2	.6478		.7935		.1509	.1509	.1509
3	.7202		.7935		.1509	.1509	.1509
4	.8097		.7773		.1509	.1509	.1509
5	.9717		.6478		.1867	.1698	.1886
6	1.2003		.6802		.2241	.2075	.2263
7	1.4563		.9717		.2054	.2075	.2075
8	.168		.1698		.2241	.2241	.2075
9	.2054		1.2793		1.7604	1.668	
10	.1867		1.2955		1.6032	1.587	
11		.0754	.945		1.6356	1.4089	
12			1.0669		1.4575	1.3279	
13			1.2346		1.3603	1.2793	.2058
14		.6964	1.3565		1.247	1.2955	.2058
15		.1132	1.326		1.3765	1.5223	.2058
16		.1132	1.4632		1.3441	1.4089	.1543
17	.2054	.1698	.1372		.168	.1509	.2058
18	.2614	.1509	.1715		.2241	.1886	.2572
19	.2241	.2075	.2229		.2614	.2641	.2915
20		.2263	.2058		.2427	.2452	.2572
21		.2263	.1543		.1886	.2452	.2401
22		.9717	.1715		.1886	.1886	1.5242
23		.9069	.1543	.1867	.1698	.1698	1.326
24	1.2098		.8259	.1372	.168	.1698	.1509
Max	1.4563	.9717	1.4632	.1867	1.7604	1.668	1.5242
Min	.168	.0754	.1372	.1372	.0137	.1509	.1509
Avg	.6715	.3507	.7349	.1537	.6126	.6055	.3229



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 206 / 11kv Karoli AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5506	.2721	.4534	.1715	.1698	.1698	.2829
2	.4001	.2561	.4534		.1698	.1698	.2829
3	.5601	.2561	.4534		.1698	.1698	.2641
4	.6478	.2915	.4534		.1886	.1886	.2641
5	.8802	.3563	.4858		.2263	.2263	.2829
6	1.1336	.4696	.583		.3174	.3961	.3395
7	1.0722	.8421	.6964		.2987	.3395	.3395
8	.168	.168	.1698		.2054	.2801	.3206
9	.1307	.1307	.3077		.9922	1.0159	.2829
10	.1307	.0934	.2743		1.0202	1.0364	.2572
11	.1307	.0934	.7164		.9393	1.0688	.3086
12	.1307	.112	.7011		.9717	1.0202	.2401
13	.1494		.7011		.8097	.8907	.2572
14	.1307	.112	.7468		.6964	.8097	.2572
15	.1307	.1307	.7773		.9231	.9393	.2572
16	.1307	.2054	.7773		.8907	1.004	.2401
17	.1867	.1494	.1029		.1867	.2452	.2572
18	.1867	.1698	.1715		.112	.3018	.2572
19	.2241	.3018	.2572		.2801	.3961	.2915
20		.3395	.2572		.3584	.3961	.3601
21		.2641	.2401		.3206	.3772	.3258
22	.3841	.6316	.2058		.2829	.3018	1.0059
23	.2721	.5506	.2058	.1867	.2452	.2829	.7316
24	.5811	.2881	.4858	.1715	.168	.1886	.2829
Max	1.1336	.8421	.7773	.1867	1.0202	1.0688	1.0059
Min	.1307	.0934	.1029	.1715	.112	.1698	.2401
Avg	.3778	.2819	.4449	.1766	.4560	.5089	.3329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 207 / 11KV Bhose AG Spare  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0943	.2263	1.5394	1.6194	1.6356	1.6518
2	.1132	.0943	.2075		1.6004	1.6004	1.6356
3	.1132	.0943	.2075		1.6004	1.6004	1.6356
4	.1132	.0943	.2075		1.7004	1.7166	1.6356
5	.132	.0943	.2263		1.7604	1.8138	1.6518
6	.132	.1132	.2452		1.8404	1.9919	1.7166
7	.1509	.1132	.132		2.1445	2.2024	1.9595
8	.1307	.0934	.132		.112	.112	.1132
9	2.5606	2.0567	.132		.1307	.1494	2.2186
10	2.672	2.2672	.12		.0747	.1494	2.21
11	2.5911	2.2672	.12		.0747	.112	2.1643
12	2.4777	1.9919	.12		.1307	.0747	2.0119
13	2.2186		.12	.1307	.1307	.0747	1.89
14	2.2024	1.9919	.12	.112	.1307	.056	2.0119
15	2.3805	2.332	.1029	.112	.112	.0747	2.3663
16	2.1862	2.3482	.1372	.1307	.1307	.1494	2.0881
17	.1307	.1509	.1372	.1494	.1494	.1509	.1372
18	.1307	.132	.1372	.168	.168	.1698	.1715
19	.168	.1698	.1372	.168	.1494	.1886	.2058
20		.1509	.1543	.1867	.1886	.2075	.1715
21		.1509	.1715	.1494	.1698	.1886	.1543
22	.0934	.2263	1.89	1.9204	1.9271	1.7814	.1372
23	.0943	.2263	1.7985	1.8404	1.7976	1.7328	.1372
24	.1132	.0943	.2452	1.7071	1.7004	1.668	1.668
Max	2.672	2.3482	1.89	1.9204	2.1445	2.2024	2.3663
Min	.0934	.0934	.1029	.112	.0747	.056	.1132
Avg	.9554	.7543	.3011	.6396	.8143	.8167	1.3226

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 201 / 11 KV Savali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.9335	1.0829	.8676	.8402
2	.1867	.2054	.1867	.9335	1.1317	.8215	.8316
3	.2241	.2075	.1886	.9335	1.2071	.8299	.8316
4	.2218	.2241	.1867	.5601	1.2696	.8215	.8402
5	.1848	.2263	.2241	.5914	1.3817	.9808	.8402
6	.2241	.2263	.2263	.8131	1.4712	1.1949	.9335
7	.2263		.2241	1.2323	1.5089	1.419	1.307
8	.2241		.1886	.2218	.1494	.1886	1.3443
9	1.3957		.1867	.1848	.1867	.1867	1.2323
10	1.531	1.0082	.1886	.1867	.1509	.1867	1.3443
11	1.4712	1.0349	.1867	.1886	.168	.1698	1.358
12	1.3817	1.1203	.2075		.1663	.1509	1.307
13	1.358	1.1576	.168		.1867	.168	1.2323
14	.9709	.8962	.1698		.1848	.1867	1.1317
15	1.1317	.961	.168		.2054	.1886	1.2323
16	1.2323	.961	.1886		.2054	.2263	1.3203
17	.1886	.1867	.1867		.2054	.2241	.0189
18	.1867	.1867	.1886		.2241	.2587	.2614
19	.2427	.2263	.2801		.2263	.2987	.2641
20		.2641	.2772		.2641	.2987	.3018
21		.2614	.2614		.2641	.2801	.3018
22	.1132	.2614	.9979		.9709	.9979	.2614
23	.1886	.2263	.9335	.8962	.9054	.8501	.2452
24	.1886	.1494	.2241	.9335	.8215	.8589	.8316
Max	1.531	1.1576	.9979	1.2323	1.5089	1.419	1.358
Min	.1132	.1494	.168	.1848	.1494	.1509	.0189
Avg	.6028	.4847	.2678	.6622	.6058	.5273	.8505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 202 / 11 KV SAIPRASAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.415	.679	.6535	.6036	.6036	.5601
2	.7468	.4294	.6413	.6535	.5975	.5601	.5601
3	.6722	.4481	.6348	.6535	.5975	.4904	.5601
4	.6413	.4715	.6036	.5601	.5658	.4481	.5601
5	.6036	.4668	.5975	.5544	.5601	.4527	.5975
6	.5601	.5041	.5658	.5788	.5658	.4668	.6908
7	.5658		.5228	.5975	.5601	.5601	.5601
8	.5228		.4904	.4805	.6036	.5415	.5415
9	.5658		.5228	.5601	.6348	.5658	.6535
10	.6722	.6722	.7167	.462	.7922	.8029	.6908
11	.679	.8589	.7095	.4338	.6908	1.0456	.8215
12	.6348	1.0829	.7167	.4108	.7023	1.2071	.9997
13	.6722	1.0642	.7468		.8962	1.1203	.9709
14	.7167	.7282	.8488		.8962	.9709	1.0185
15	.7468	.9522	.8775		.8775	1.0185	.9709
16	.811	.9795	.9054		.9709	1.0374	.9997
17	.7842	1.0534	.9149		.9795	1.0456	1.1389
18	.6602	.6348	.6348		.7468	.7842	1.1317
19	.7095	.6413	.6348		.7095	.5975	1.0456
20		.6161	.6161		.6413	.6653	.9808
21		.6602	.7282		.7545	.6161	.9054
22		.7282	.8029		.7095	.6348	.8215
23	.3018	.7733	.6908	.679	.8299	.6908	.7842
24	.8488	.4108	.7095	.6722	.5975	.6161	.6535
Max	.8488	1.0829	.9149	.679	.9795	1.2071	1.1389
Min	.3018	.4108	.4904	.4108	.5601	.4481	.5415
Avg	.6623	.6948	.6880	.5678	.7118	.7309	.8007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 203 / 11 KV Savali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2614	.2614	.2987	.2801	.3018	.3174
2	.2263	.2614	.2452	.2957	.3018	.2614	.3174
3	.2263	.2241	.2427	.2987	.3018	.2641	.3174
4	.2241	.2263	.2263	.2587	.2801	.2614	.3142
5	.2614	.2614	.2614	.2772	.2801	.3018	.3361
6	.2641	.3142	.3206	.3174	.2987	.3206	.3547
7	.2614	.3547	.2829	.3142	.2218	.3174	.3142
8	.2641	.2829	.2427	.2427	.2614	.2987	.2614
9	.2987	.2829	.3018	.2402	.2614	.3018	.2614
10	.3361		.3174	.2054	.3018	.3174	.3921
11	.3584	.4066	.3772	.2263	.3361	.3395	.3734
12	.3734	.3734	.3584	.2614	.3361	.3734	.3511
13	.3361	.3696	.2829		.3361	.3395	.3361
14	.3395	.4108	.3174		.3361	.3395	.3361
15	.3584	.3921	.3395		.3361	.3734	.3584
16	.3734	.2957	.3772		.3361	.3734	.3734
17	.415	.3174	.4294		.3174	.415	.3206
18	.4481	.3511	.415		.3734	.4481	.3584
19	.5658	.4338	.499		.4294	.5415	.4904
20		.4668	.4668		.4715	.5359	.5415
21		.4294	.3921		.415	.4481	.4338
22	.1307	.415	.3547		.3921	.3921	.3921
23	.2987	.3395	.3547	.2987	.3584	.3921	.3547
24	.2667	.3018	.2987	.2957	.2801	.3174	.3174
Max	.5658	.4668	.499	.3174	.4715	.5415	.5415
Min	.1307	.2241	.2263	.2054	.2218	.2614	.2614
Avg	.3131	.3379	.3319	.2736	.3268	.3573	.3552

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 204 / BOTHRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0765	.7171	.9099	.977	.9816	.9629	1.0376
2	1.2289	.796	.9426	.9053	.977	.9099	1.0376
3	1.1001	.9443	.9862	.9007	.9401	.868	1.0376
4	1.2525	.9862	.9443	.6767	.8596	.8722	.9613
5	1.2087	.8638	.7967	.9007	.7468	.9053	.9613
6	1.214	.7506	.6797	.8268	.7898	.868	1.0003
7	1.0951	.7544	.7967	.5864	.8306	.9401	.8696
8	1.1001	.6984	.7544	.6035	.7136	.9053	.6409
9	1.2072	.7617	.8344	.6984	.6005	.98	.98
10	1.5166	.5335	1.0189	.8306	.8306	1.3272	1.1325
11	1.669	1.2834	1.6297	.759	.98	1.4156	1.3657
12	1.7375	1.2475	1.6225	.6458	1.0563	1.4411	1.5105
13	1.736	1.19	1.4358	.3048	1.1512	1.4156	1.4156
14	1.8199	.7114	1.4788	.2286	1.0173	1.3207	1.3272
15	1.9631	1.3581	1.5478	.3048	1.246	1.2699	1.4358
16	1.8961	1.2773	1.4788	.3048	1.1698	1.2632	1.3207
17	1.6613	1.3207	1.5851	.3048	1.0951	1.3581	.9107
18	1.5173	1.0967	1.4041	.2286	.8661	1.2849	.9443
19	1.1153	.7205	.7544	.2286	.6035	1.0951	.9485
20	.4572	.6797	.4134	.2286	.5311	1.1698	.9629
21		.381	.3764	.2286	.4527	1.0563	.8823
22	.112	.3216	.434	.2286	.49	1.131	1.2445
23	.5289	1.0616	1.0902	.6782	.6451	1.0563	1.4223
24	.6813	.836	.9816	.8245	.9053	.9816	1.2662
Max	1.9631	1.3581	1.6297	.977	1.246	1.4411	1.5105
Min	.112	.3216	.3764	.2286	.4527	.868	.6409
Avg	1.2563	.8871	1.0374	.5585	.8533	1.1166	1.1090

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 205 / 11 KV REX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2801	.5281	.6468	.5601	.3174	.5544
2	.2987	.3772	.547	.6348	.5658	.3206	.5601
3	.3395	.415	.5601	.6283	.5281	.2987	.5601
4	.3772	.547	.547	.6348	.5228	.2987	.5601
5	.4854	.547	.5228	.6535	.5601	.2829	.5601
6	.5281	.4904	.547	.6468	.5658	.2801	.5415
7	.4854	.415	.5415	.5041	.5601	.2772	.5228
8	.3772	.3547	.5281	.5601	.5975	.2801	.5228
9	.4854	.3921	.5788	.5729	.6036	.2801	.5975
10	.5601	.4108	.5281	.5975	.6348	.4251	.6348
11	.5601	.4668	.5415	.5975	.6535	.4481	.5975
12	.5788	.4854	.5658	.6224	.6535	.4527	.5658
13	.3944	.5041	.5601		.5975	.4108	.5601
14	.5281	.4854	.6099		.6348	.4108	.6036
15	.5041	.5544	.6348		.6348	.3772	.5601
16	.6036	.5415	.6602		.5601	.3734	.5601
17	.5788	.5601	.6348		.4854	.4108	.6224
18	.6036	.5975	.6602		.5228	.4108	.6535
19	.5788	.5975	.6653		.5281	.3361	.679
20		.5847	.7095		.4904	.4294	.6535
21		.5415	.6161		.5788	.3921	.679
22	.1494	.547	.6535		.5281	.3734	.6908
23	.132	.5281	.6722	.5601	.5041	.4294	.6602
24	.2263	.1494	.5041	.6468	.5601	.3395	.4294
Max	.6036	.5975	.7095	.6535	.6535	.4527	.6908
Min	.132	.1494	.5041	.5041	.4854	.2772	.4294
Avg	.4397	.4739	.5882	.6076	.5679	.3606	.5887

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV Malgaon

Feeder No / Name : 201 / 11 KV malgaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154		.6099	.6287	.5359	.5914	.5068
2	.6154		.6099	.6097	.5228	.5544	.4525
3	.6219		.5914	.6097	.5228	.5544	.4525
4	.7023		.5914	.6097	.5228	.5544	.4525
5	.7023		.5729	.6478	.6099	.5914	.5068
6	.7059		.6668	.6653	.6838	.6653	.543
7	.695		.5973	.6653	.6154	.5973	.543
8	.543		.5194	.5373	.5068	.4681	
9	.4938		.4681	.4835	.443	.4784	.4344
10	.5611	.6201	.4784	.4477	.4801	.4681	.4508
11	.5792	.6556	.5316	.2896	.5028	.5487	.4854
12	.6668	.6485	.5197	.3681	.5083	.5197	.5434
13	.6335	.6516	.5087	.3721	.5316		.5373
14	.543	.5784	.5087	.3898	.5373		.5194
15	.5792	.5847	.5144		.5731		.5014
16	.543	.6154	.5087		.5426	.6274	.5194
17	.6805	.6241	.5426		.5487	.724	.5973
18	.6805	.6539	.6104		.6299	.7602	.6089
19	.8326	.815	.8507		.8505	.8145	.7682
20		.9231	.9425		.9774	.905	.8869
21		.9055	.9055		.9055	.905	.8688
22		.8402	.8029		.8029	.8688	.8059
23			.6859		.7095	.8573	.6805
24	.6154		.6348	.6287	.5914	.5914	.543
Max	.8326	.9231	.9425	.6653	.9774	.905	.8869
Min	.4938	.5784	.4681	.2896	.443	.4681	.4344
Avg	.6305	.7012	.6155	.5302	.6106	.6498	.5743



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV Malgaon

Feeder No / Name : 202 / 11 KV Cannal AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2811		.945	.381	.4191	.4001	.4572
2	1.2811		.9686	.381	.4001	.381	.381
3	1.2811		.9686	.381	.381	.381	.381
4	1.3117		.9374	.4191	.381	.381	.381
5	1.406		.9646	.4572	.4191	.381	.381
6	1.4175		1.1203	.4954	.4954	.4191	.4191
7	1.5653		1.186	.362	.4763	.4191	.4763
8	.4001		.3429	.4001	.4572	.4191	
9	.4382		1.2803	1.6004	1.6461	1.6876	.4954
10	.4382	.2858	1.5242	1.8138	1.6766	1.8461	.4572
11	.4763	.3048	1.5586	1.7604	1.2346	1.8278	.362
12	.5144	.3048	1.2041		1.3435	1.7284	.4763
13	.5144	.2096	1.2654		1.6872		.4572
14	.5144		1.4969		1.7328		.4763
15	.5335	.5376	1.5466		1.7652		.4954
16	.5335	.4001	1.5586		1.7869	1.768	.4382
17	.5144	.4763	.381		.4763	.5335	.3048
18	.5335	.4954	.5144		.4191	.4763	.4572
19		.5525	.381		.5335	.5716	.5335
20		.5335	.5335		.4572	.5716	.4954
21		.5144	.5335		.4763	.5716	.4763
22		1.1544	.4954		.4382	.5335	1.6278
23			.4382		.4191	.4763	1.5708
24	1.2654		.9755	.4001	.4382	.4001	.4572
Max	1.5653	1.1544	1.5586	1.8138	1.7869	1.8461	1.6278
Min	.4001	.2096	.3429	.362	.381	.381	.3048
Avg	.8537	.4808	.9634	.7376	.8317	.7702	.5416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 201 / 11 KV Anjani AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7343	.3401	.217	.1143	.0914
2	.7343	.3441	.1981	.0953	.0914
3	.6859	.3481	.1981	.0953	.0924
4	.7164	.3401	.2195	.1143	.0905
5	.7968	.3605	.2469	.132	.1086
6	.8592	.5376	.3227	.1698	.1254
7	1.1683	.8322	.3462	.168	.1417
8	.1478	.128	.0953	.128	.1294
9	.1086		.4725	1.1248	1.3443
10	.1075		.8745	1.0753	1.1092
11	.128	.0924	1.1498	1.1203	1.1843
12	.1254	.1109	1.0562		1.1203
13	.0886	.0934	1.0242		.9568
14	.0716	.0943	1.0242		.884
15	.0905	.0762	1.0562		1.0526
16	.0716	.0572	1.1174		.6249
17	.0905	.0762	.1463		
18	.1109	.0953	.1294		
19	.0905	.1143	.112		
20	.1254	.0953	.1509		
21		.0762	.132		
22	.3441	.2401	.1143		
23	.3361	.2401	.0953		
24	.7842	.3441	.2202	.1143	.0905
Max	1.1683	.8322	1.1498	1.1248	1.3443
Min	.0716	.0572	.0953	.0953	.0905
Avg	.3703	.2289	.4466	.3710	.5434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 202 / 11 KV Bastavade Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1698	.1867	.6573	.6478	.612	.5487
2	.1867	.1698	.1867	.631	.6478	.612	.5335
3	.1886	.1663	.1886	.6344	.6478	.612	.5487
4	.2263	.1829	.1886	.6573	.6562	.612	.6001
5	.2641	.181	.2075	.743	.6562	.6203	.6287
6	.2829	.2507	.2829	.8383	.7773	.8535	.6748
7	.3206	.3258	.3206	1.2809	1.3603	1.2498	.9031
8	.2402	.2195	.2241	.2241	.2195	.2427	.2012
9	1.1288		.1867	.1867	.181	.1867	.8642
10	1.0562		.1494	.168	.1663	.1494	1.0753
11	.7373	.9414	.1463	.1663	.1494	.1478	1.0722
12	.8097	.8768	.1829	.1663	.1463	.1478	.9282
13	.9282	.8619	.1417	.1494	.1612	.128	.8259
14	.8583	.8069	.1448		.1294	.1433	.759
15	1.0082	.8619	.1629		.1086	.1478	.8697
16	1.0883	1.0822	.1463		.1463	.1848	.8802
17	.1463	.1848	.1646		.1595		
18	.1829	.181	.1848		.1646	.1829	.2149
19	.1663	.2378	.2218		.2587	.2987	.2481
20	.2195	.2614	.2641		.2801	.3206	.2896
21		.2427	.2641		.2614	.2987	.2507
22	.2033	.2263	1.0385		1.1439	.8619	.2075
23	.168	.2075	.9659		.8802	.7042	.1867
24	.1867	.168	.1867	.6767	.6882	.6259	.5761
Max	1.1288	1.0822	1.0385	1.2809	1.3603	1.2498	1.0753
Min	.1463	.1663	.1417	.1494	.1086	.128	.1867
Avg	.4689	.4003	.2641	.5128	.4433	.4323	.6038

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 203 / 11 KV Dongarsoni AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2195	.2743	1.7375	1.5546	1.4937	1.0416
2	.2614	.2218	.2743	1.7375	1.5729	1.4937	1.0145
3	.2987	.2172	.2772	1.7497	1.5729	1.5123	1.0974
4	.415	.2507	.2772	2.1052	1.6194	1.5123	1.3435
5	.5281	.3366	.499	2.4249	1.7764	1.6964	1.5684
6	.6413	.4835	.679	2.5692	2.4036	2.3703	1.749
7	.6224	.4607	.6224	2.9338	2.3045	2.6052	1.8084
8	.3077	.2686	.4338	.4435	.4024	.4066	.3696
9	2.1538		.3326	.2896	.3045	.2772	1.6032
10	2.1285		.2402	.2686	.3109	.2353	1.6324
11	1.945	1.8623	.2012	.2534	.2534	.2328	1.1869
12	1.9364	1.7284	.2328	.2507	.2172	.0133	1.6057
13	1.8623	1.8564	.1677	.2279	.2172	.0271	1.3763
14	1.8564	.8025	.2058		.2172	.2401	1.5074
15	2.0729	1.2176	.2126		.2279	.208	1.5497
16	2.2405	1.4883	.2328		.2103	.2507	1.9524
17		.2507	.3439		.2507		.3258
18	.2865	.4805	.3439		.4938	.4706	.4835
19	.3077	.6348	.5788		.5729	.0543	.543
20	.3403	.5788	.5975		.6161	.0543	.5121
21		.4668	.4854		.4668	.439	.4119
22	.2012	.3174	2.8509		2.3594	2.1052	.3439
23	.2012	.2772	2.17		2.1605	1.8084	.2686
24	.2743	.2172	.2743	1.8122	1.6804	1.713	1.4784
Max	2.2405	1.8623	2.8509	2.9338	2.4036	2.6052	1.9524
Min	.2012	.2172	.1677	.2279	.2103	.0133	.2686
Avg	.9610	.6653	.5337	1.3431	.9902	.9226	1.1156

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 204 / 11 KV Jarandi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.128	.1905	1.2018	1.1843
2	.1905	.1311	.1905	1.2018	.8097
3	.2286	.1311	.1905	1.2498	1.0364
4	.2858	.1475	.2286	1.4529	1.1336
5	.3429	.2241	.3048	1.6404	1.1822
6	.4382	.3277	.4572	1.9685	1.6804
7	.4382	.3201	.4572	1.9204	1.3748
8	.3429	.2486	.2477	.3239	.2949
9	1.2809		.2096	.3239	.2241
10	1.1843		.1905	.2477	.2667
11	.8539	1.3923	.1715	.1905	.2096
12	1.0155	1.5203	.1905	.1905	.1905
13	1.0517	1.4373	.1905	.2096	.1715
14	1.0936	1.3923	.1905		.1905
15	1.3603	1.4723	.1715		.2096
16	1.2342	1.7532	.1715		.2286
17	.1475	.2477	.2096		
18	.208	.2667	.2667		
19	.1966	.3429	.362		
20	.192	.362	.3429		
21		.2858	.2858		
22	.116	.2286	1.9524		
23	.128	.2096	1.5364		
24	.1905	.1296	.1905	1.2793	1.2483
Max	1.3603	1.7532	1.9524	1.9685	1.6804
Min	.116	.128	.1715	.1905	.1715
Avg	.5526	.5772	.3708	.9572	.6845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 205 / 11 KV Savalaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5757	.471	.5467	.5387	.5014	.5467	.5624
2	.57	.4681	.5399	.533	.5003	.5414	.5574
3	.6097	.469	.5413	.5326	.5034	.5391	.5628
4	.6693	.4685	.5643	.5922	.5426	.5395	.6406
5	.7472	.5132	.5996	.6712	.5925	.5977	.7151
6	.9234	.7072	.8739	.8141	.7762	.9031	.8701
7	.951	.7735	.8589	.8741	.8113	.8471	.82
8	.6747	.6824	.6314	.5845	.616	.6186	.5874
9	.6078	.197	.5384	.498	.4836	.5521	.519
10	.5567		.4687	.5049	.5445	.5347	.4939
11	.5518	.6699	.5098	.4786	.5222	.5052	.4954
12	.5866	.6521	.5203	.4523	.49	.1757	.5045
13	.5841	.6561	.5243	.4569	.5836	.5474	.5556
14	.6218	.5937	.5057	.1886	.5685	.554	.5479
15	.5857	.5805	.5268	.1894	.5897	.5811	.5503
16	.5464	.5651	.5277	.1669	.5767	.4896	.5098
17	.6184	.6093	.5007	.1875	.6127	.2183	.5171
18	.6215	.6264	.5578	.2237	.5828	.6097	.5499
19	.6721	.8046	.8303	.2656	.7811	.8417	.7746
20	.7232	1.0372	1.0109	.3216	1.0036	1.012	.985
21	.2397	.9286	.916	.3155	.8884	.9403	.8703
22	.663	.7991	.7947	.2743	.7811	.817	.7604
23	.5651	.6535	.6539	.234	.6509	.6604	.6736
24	.5742	.5085	.5757	.5506	.5439	.5784	.5754
Max	.951	1.0372	1.0109	.8741	1.0036	1.012	.985
Min	.2397	.197	.4687	.1669	.4836	.1757	.4939
Avg	.6266	.6276	.6299	.4354	.6270	.6146	.6333

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 207 / 11 KV Savlaj Water Supply NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0145	.0149	.0118	.0286	.0312	.0305
2	.1761	.0149	.0149	.0114	.029	.0305	.029
3	.17	.0143	.0143	.0143	.0293	.0305	.0286
4	.1909	.0145	.0143	.0149	.0282	.0312	.0297
5	.1604	.0143	.0154	.0149	.061	.1578	.0301
6	.1775	.0145	.0156	.0156	.1223	.1745	.1124
7	.0759	.0147	.0158	.016	.125	.16	.0158
8	.0518	.0297	.0151	.0301	.1586	.1901	.029
9	.1677		.0316	.0312	.1539	.2096	.0324
10	.1669		.0655	.0305	.2218	.2034	.032
11	.154	.032	.0312	.0297	.1837	.2153	.0305
12	.0625	.032	.0259	.1196	.1623	.1806	.0297
13	.061	.0312	.029	.1273	.1145	.144	.029
14	.0297	.0305	.0267	.0808	.0328	.1426	.0819
15	.029	.0149	.0282	.08	.0324	.1463	.1147
16	.029	.1718	.0301	.08	.045	.1463	.1014
17	.0297	.0152	.0282	.0914	.1801		.1418
18	.029	.0305	.0301	.0983	.1755	.0221	.1402
19	.0282	.1319	.0152	.1082	.1783	.0141	.1436
20	.029	.0457	.0152	.1082	.1775	.0141	.1478
21		.0309	.0139	.0884	.1501	.0112	.1121
22	.0297	.0309	.0137	.0244	.0484	.016	.1486
23	.029	.0312	.0133		.032	.032	.1471
24	.08	.0297	.0301	.0122	.0282	.0316	.117
Max	.1909	.1718	.0655	.1273	.2218	.2153	.1486
Min	.0282	.0143	.0133	.0114	.0282	.0112	.0158
Avg	.0925	.0359	.0228	.0539	.1041	.1015	.0773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 209 / 11 KV Savlaj Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	.7042	.9998	.2427	.2507	.3206	.3326
2	1.1584	.7209	.945	.2427	.2561	.3174	.3361
3	1.1873	.7125	.945	.2452	.2587	.3174	.3361
4	1.4883	.7042	1.0722	.2829	.2896	.3361	.3772
5	1.7124	.7449	1.1203	.3772	.3898	.4294	.4854
6	1.8023	1.1797	1.4083	.5281	.4656	.5658	.5975
7	1.8404	1.6004	1.749	.5041	.4706	.4904	.5281
8	.2926	.3658	.3475	.4251	.5121	.3734	.4207
9	.2402		1.4998	1.8818	2.3685	1.8138	.3475
10	.2378		1.4723	1.8976	1.9845	2.0325	.2241
11	.2195	.2033	1.0669	1.3603	1.656	1.9204	.2241
12	.2195	.1991	1.2793		1.6248	1.7284	.2241
13	.2218	.1829	1.3496			1.5278	.2218
14	.2195	.1991	1.3756		1.3592	1.5699	.2195
15	.2218	.2149	1.4784		1.6164	1.8278	.2172
16		.197	1.6446		1.6194	2.0466	.2561
17	.1494	.2561	.2328		.2926		.3258
18	.1478	.2743	.197		.3475	.362	.3224
19	.2241	.3475	.3921		.499	.4805	.3658
20	.2218	.4481	.4481		.5415	.5228	.4706
21		.3547	.3734		.4108	.4481	.4298
22	.7377	1.3283	.3361		.3547	.3921	2.1125
23	.7209	1.1248	.2614		.3174	.3547	1.8343
24	1.2191	.7125	1.0311	.2587	.2896	.3206	
Max	1.8404	1.6004	1.749	1.8976	2.3685	2.0466	2.1125
Min	.1478	.1829	.197	.2427	.2507	.3174	.2172
Avg	.7116	.5807	.9594	.6872	.7902	.8912	.4874



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 205 / 11 KV Manjarde Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5205	.8314	.1501	.1448	.1372	.1509
2	.5197	.804	.1555	.1425	.1341	.1494
3	.5136	.7819	.1547	.1395	.1311	.1539
4	.5205	.8017	.1578	.1379	.1364	.1623
5	.5472	.8421	.1715	.1486	.1524	.1875
6	.5959	.8901	.2073	.2141	.2035	.2195
7	.8101	1.1325	.2614	.2522	.2332	.266
8	.2591	.4275	.2606	.234	.2423	.2462
9	.1486	1.1904	1.6347	1.8298	1.7985	.1646
10	.1189	1.1355	1.7474	2.0332	1.9806	.128
11	.1036	1.089	1.752	2.0645	1.9448	.1303
12	.0975	1.0037	1.7886	1.9989	1.9601	.1387
13	.1014	1.0128	.2103	1.9182	1.8602	.1448
14	.1204	.9457	.1745	1.7741	1.6758	.1616
15	.1029	1.3954	.1738	1.7917	1.8267	.1585
16	.1044	1.5165	1.4784	1.8762	1.8686	.1349
17	.1135	.1196	.2705	.3544	.6066	.1768
18	.1509	.1174	.1471	.1547	.1882	.1875
19	.1677	.1494	.1837	.192	.1837	.2134
20	.2157	.1989	.2027	.2134	.2195	.2317
21	.2103	.1997	.1981	.218	.2073	.2301
22	.9938	.1738	.1814	.1898	.1966	1.6827
23	.9206	.1623	.1745	.1738	.1692	1.6674
24	.8657	.157	.1608	.1494	.1692	1.528
Max	.9938	1.5165	1.7886	2.0645	1.9806	1.6827
Min	.0975	.1174	.1471	.1379	.1311	.128
Avg	.3676	.7116	.4999	.7644	.7594	.3589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 207 / 11 KV S S Industries  
 Manjarde Feeder KV- 11 /  
 OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
 (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)
4		***
5		***
6	***	***
7	***	***
8	***	***
9	***	***
10	***	***
11	***	***
12	***	
13	***	***
14	***	***
15	***	***
16	***	***
18	***	
19	***	
20	***	***
21	***	***
22	***	***
23	***	***
24	***	***
Max	45.7248	45.7248
Min	45.7248	45.7248
Avg	45.7248	45.7248

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 201 / 11 KV Manerajuri Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394		.3547	1.4918	1.3889	1.3108	1.7328
2	.443		.3206	1.2803	1.4373	1.2146	1.7604
3	.4733		.3361	1.3108	1.4232	1.1069	1.186
4	.5068		.3395	1.326	1.5844	1.1843	1.2631
5	.5373		.3734	1.6766	1.7328	1.2955	1.326
6	.567		.7167	1.8778	1.9766	1.8884	1.5746
7	.6447		.6036	2.2552	2.1925	2.1872	1.6004
8	.5249		.5249	.4607	.2865	.4715	.4706
9	1.4685		.3921	.4527	.4163	.4481	1.7924
10	2.1538		.415		.3761	.4338	1.7444
11	1.9281	1.7695	.3696		.3395	.3475	1.7328
12	1.8945	1.7814	.3326		.3734	.362	1.7604
13	1.7695	1.8623	.3772		.3734	.2804	1.8278
14	1.8442	1.9227	.3045		.3772	.3189	1.6129
15	1.8821	1.9006	.3189		.3547	.3292	1.4883
16	2.0622	1.9109	.3721		.3772	.3582	1.692
17	.394	1.6057	.4119	.3544	.4294		.4477
18		.5281	.4706	.3982	.4904	.5487	.5068
19		.6722	.6201	.4298	.6535	.5731	.5487
20		.6036	.7164	.4887		.6722	.591
21		.5281	.6878	.5194		.5792	.6201
22		.4854	1.9281	1.166	.2829	1.4083	.5373
23		.415	1.7804	1.2963	.2452	1.3592	.4252
24	.3761		.3772	1.6385	1.3923	1.3765	1.7444
Max	2.1538	1.9227	1.9281	2.2552	2.1925	2.1872	1.8278
Min	.3761	.415	.3045	.3544	.2452	.2804	.4252
Avg	1.1036	1.2297	.5602	1.0837	.8411	.8719	1.2494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 202 / 11 KV Yogewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3441	.5087	.9503	.2195	.2561	.1867	.2126
2	1.4373	.4915	.8907	.2218	.2715	.2075	.2172
3	1.5586	.4801	.8951	.2241	.3189	.1867	.2149
4	1.8404	.5668	.8962	.2772	.3582	.1886	.2481
5	1.866	.7209	.9667	.3142	.3801	.2427	.2896
6	1.7604	.8886	1.085	.3544	.3856	.3772	.362
7	1.7078	1.3395	1.1683	.3403		.3772	.394
8	.3224	.2641	.2075	.3012	.2149	.2987	.3292
9	.3224		1.1683	1.5844	1.7604	1.4403	.3258
10	.3224		1.4089		1.6604	1.2029	.2686
11	.2829	.1886	1.3927		1.6004	1.4232	
12	.2658	.1867	1.3599		1.5565	1.4918	.2658
13	.3045	.1698	1.5089		1.3599	1.3599	.2328
14	.2686	.1698	1.4922		1.3927	1.3904	.2835
15	.2896	.168	1.4922		1.4419	1.3923	.3045
16	.2614	.1698	1.576		1.4089	1.4403	.3012
17	.2835	.2075	.2829	.2149	.2263		.2926
18		.2614	.3012	.2534	.2614	.2804	.3077
19		.3174	.3366	.2686	.2829	.3582	.3224
20		.3206	.3206	.3109	.3361	.3898	.3366
21		.2987	.2835	.3439	.3174	.3224	.3582
22	.6371	1.1469	.2829	.3224		.2804	1.2003
23	.5407	1.0688	.2328	.2835		.2686	1.2631
24	1.2643	.503	.9922	.2172	.2353	.2263	.2534
Max	1.866	1.3395	1.576	1.5844	1.7604	1.4918	1.2631
Min	.2614	.168	.2075	.2149	.2149	.1867	.2126
Avg	.8440	.4744	.8955	.3560	.7631	.6666	.3732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 203 / 11 KV Bhosalenagar Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3757	.5735	.9945	.2218	.2534	.1867	.1791
2	1.4883	.547	.9282	.1829	.2561	.1867	.1772
3	1.5708	.5533	.8907	.1848	.2715	.1886	.1753
4	1.6964	.6443	.9339	.1867	.2865	.1886	.2172
5	1.7394	.6796	.9878	.2075	.3012	.2054	.2126
6	1.6716	.8139	1.1437	.1949	.2804	.2614	.2987
7	1.6804	1.291	1.1683	.3045	.2835	.3018	.3109
8	.2896	.1417	.2452	.2686	.2865	.2829	.3224
9	.2686		1.5023	1.4563	1.8818		.3544
10	.2279		1.4998		1.9524	1.6549	
11	.2686	.1867	1.6057		1.8842	1.6244	.197
12		.1886	1.6385		1.7604	1.5181	.2149
13		.2241	1.5592		1.6617	1.5223	.2715
14	.2452	.2241				1.4403	.298
15	.2126	.2587	1.4523		1.5971	1.4864	.3292
16	.2149	.2801	1.5061		1.5708	1.6409	.3258
17	.2865	.2829	.2328	.1928	.3174		.3403
18		.3174	.2896	.2328	.415	.1646	.3544
19		.3961		.2658	.4668	.362	.3721
20		.3547	.2686	.2865	.4668	.4066	.394
21		.3018	.2896	.3366	.3584	.3326	.3982
22	.6203	1.1797	.2507	.3045	.2829	.2987	1.2803
23	.6104	1.1469	.2328	.2715	.2427	.2534	1.3916
24	1.2498	.5935	1.0402	.2172	.2328	.2263	.2218
Max	1.7394	1.291	1.6385	1.4563	1.9524	1.6549	1.3916
Min	.2126	.1417	.2328	.1829	.2328	.1646	.1753
Avg	.8732	.5082	.9391	.3127	.7526	.6697	.3755

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 204 / 11 KV Manerajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.128	.3206	.362	.3395	.3206	.2957
2	.3361	.1294	.3018	.3292	.3361	.3206	.2987
3	.3292	.1307	.2987	.2957	.3696	.3361	.2772
4	.3696	.1132	.3018	.2987	.3841	.3206	.2987
5	.3982	.124	.3174	.3395	.3982	.3547	.3326
6	.4251	.1254	.3658	.4119	.415	.4108	.4481
7	.4481	.1075	.3511	.3761	.4108	.3395	.3326
8	.3881		.3961	.3761	.3696	.3734	.3361
9	.3109		1.5023	.4119	.2987	.3547	.3881
10	.3077		.362		.3206	.5792	.5281
11	.4252	.3511	.4207		.3658	.6161	.5788
12	.4252	.439	.4251		.3734	.5658	.5847
13	.4252	.462	.3721		.3772	.4904	.5975
14	.394	.5041	.394		.3439	.4108	.5914
15	.362	.5249	.591		.3475	.4904	.6224
16	.3366	.6283	.4835		.3439	.5658	.6161
17	.394	.462	.543	.6413	.3292		.6413
18		.6036	.567	.5975	.3258	.5415	.6219
19		.8402	.6268	.6099	.6335	.5658	.6468
20		.7468	.6697	.567	.7059	.6413	.6722
21		.6036	.695	.6099	.5304	.5175	.6653
22	.1254	.4668	.6613	.5658	.4805	.4481	.4715
23	.1254	.4108	.4607	.3734	.3734	.4108	.3801
24	.3841	.1267	.3584	.4477	.3734	.3395	.3395
Max	.4481	.8402	1.5023	.6413	.7059	.6413	.6722
Min	.1254	.1075	.2987	.2957	.2987	.3206	.2772
Avg	.3544	.3823	.4911	.4479	.3978	.4484	.4819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 205 / 11 KV AG LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362		.0362	.0362	.0183	
2	.0366	.0179	.0358	.0366	.0181	.0358
3	.0358	.0181	.0732	.037	.0554	.0362
4	.0543	.0183	.0732	.0362	.0537	.0354
5	.0549	.0185	.0724	.0537	.0549	.0358
6	.0532	.0189	.0732	.0549	.0543	.0358
7	.0554		.0747	.0543	.0549	.0351
8	.0732		.0754	.0724	.0373	.0351
9	.0724		.056	.0716	.0377	.0343
10	.0732		.0566	.0724	.037	.0537
11	.0739	.0366	.0537	.0537	.0354	.0532
12	.0747	.0362	.0543	.0747	.0701	.0543
13	.0739	.0366	.0543	.0754	.0354	.0549
14	.0709	.037	.0724	.0747	.0351	.0716
15	.0716	.0373	.0739	.0754	.0358	.0709
16	.0709		.0739	.0732	.0351	.0895
24	.0905					
Max	.0905	.0373	.0754	.0754	.0701	.0895
Min	.0358	.0179	.0358	.0362	.0181	.0343
Avg	.0630	.0275	.0631	.0595	.0418	.0488

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 206 / Yogewadi Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1254	.168	.1307	.1463	.1307	.1463
2	.1509	.1267	.132	.132	.1509	.132	.1494
3	.1478	.128	.132	.1063	.168	.1307	.1509
4	.1867	.1294	.1307	.1254	.1663	.132	.1478
5	.2218	.1478	.1509	.1463	.1629	.1494	.1867
6	.2263	.2149	.2075	.197	.1867	.1867	.2054
7	.2378	.197	.168	.1612	.1886	.1478	.1848
8	.2452	.3224	.2263	.1612	.1307	.3109	.128
9	.2012		.2896	.3012	.1132	.3881	.4108
10			.3547		.1478	.1097	.4338
11	.2835	.1646	.4119		.1307	.415	.4435
12	.2865	.181	.3582			.4668	.4024
13	.1433	.2957	.1063		.112	.3734	.3772
14	.2149	.362	.1791		.1267	.1829	.3547
15	.2715	.4024	.4784		.1433	.3361	.3395
16	.1791	.4066	.3721		.1267	.415	.2987
17	.2686	.4435	.3189	.3734	.0934		.2743
18		.3696	.2865	.3326	.0943	.1494	.2534
19		.2896	.2865	.2743	.1646	.3734	.2587
20		.2614	.2686	.1848	.1629	.4527	.2452
21		.2075	.2534	.168	.1646	.2587	.2427
22	.1791	.2054	.1949	.1698	.1698	.1867	.1886
23	.1612	.2263	.1612	.1478	.1494	.1646	.168
24	.1698	.1417	.1886	.1478	.1494	.1509	.1478
Max	.2865	.4435	.4784	.3734	.1886	.4668	.4435
Min	.1433	.1254	.1063	.1063	.0934	.1097	.128
Avg	.2074	.2431	.2427	.1918	.1456	.2497	.2558



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 201 / 11 KV Waifale Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.1715		.4191	.3429	.4001	.4763
2	.3772	.1715		.4191	.3429	.4001	
3	.3772	.5093		.4191	.3429	.4001	.4763
4	.4715	.4715		.4191	.3429	.4001	.4763
5	.5658	.2286		.4191	.3921	.4572	.4763
6	.6224	.3429		.5335	.462	.5716	.5335
7	.4715	.3361		.4668	.4066	.4954	.5335
8	.4294	.2614		.4191	.2801	.381	.4001
9	.3584	.4715	.6602	.2829	.2829	.362	.381
10	.362		.5228	.2858	.2477	.3429	.3239
11	.381		.5228		.3048	.3239	.362
12	.5144		.3921		.3429	.362	.4001
13	.4954	.5335	.4294	.2858		.362	.4001
14		.4904	.4525			.381	.4191
15	.4954		.5175		.4382	.381	.4382
16	.5144		.4805		.2286	.4191	2.0631
17	.4763	.5658	.4954		.4527		
18		.547	.5716		.5601	.4763	
19		.5847	.6859		.7392	.5716	.7049
20	.3048	.5658	.6859		.7023	.7621	.7049
21	.2858	.5847	.5716		.5788	.8002	.4715
22	.2477		.5144		.4668	.6348	.5716
23	.1905		.4763		.4481	.5658	.4294
24	.3772	.1715		.4191		.4001	.3429
Max	.6224	.5847	.6859	.5335	.7392	.8002	2.0631
Min	.1905	.1715	.3921	.2829	.2286	.3239	.3239
Avg	.4186	.4122	.5319	.3990	.4145	.4631	.5421

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 202 / 11 KV Waifale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.0953		1.9719	1.7528	1.7147	1.7147
2	.381	.0953		1.9719	1.7528	1.7147	1.7147
3	.3772	1.7147		1.9719	1.7528	1.7147	1.7147
4	.4715	2.2977		1.9719	1.7528	1.7147	1.7147
5	.5335	.1905		1.9719	2.0119	2.0233	1.749
6	.6224	.3048		2.5819	2.8673	2.4577	1.9204
7	.5847	.3772		2.652	2.5069		2.0687
8	.3772	.2614		.4191	.3772		.4001
9	2.0062	1.3375	.2667	.3048	.2829	.3018	1.8519
10	1.9071		.2667	.2667	.2477	.2667	1.8898
11	1.8229		.2477		.2096	.2096	1.6297
12	.9945		.2286		.2477	.2096	1.543
13	1.5424	1.406	.2286	.2096		.2096	1.6124
14	1.7528	1.6804	.2286			.2286	1.5257
15	1.8519		.2286		.2477	.2286	1.7684
16	1.9204		.2096		.2286	.2858	
17	.2801	.3018	.3048		.3395		
18	.3326	.3772	.381		.3921	.3429	
19		.4527	.4763		.5175	.4954	.4904
20		.415	.4763		.5041	.5144	.4527
21	.1334	.415	.4763		.4294	.5144	
22	.0953		2.4863		2.343	2.0119	.4715
23			2.2291		1.9951	1.8652	.3239
24	.381	.0953		1.9719		1.7147	.2858
Max	2.0062	2.2977	2.4863	2.652	2.8673	2.4577	2.0687
Min	.0953	.0953	.2096	.2096	.2096	.2096	.2858
Avg	.8928	.6952	.5823	1.5221	1.0838	.9876	1.3421

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 203 / 11 KV Biranwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288			.2286	.1715	.1905	.1905
2	1.0288	.7316		.2286	.1715	.1905	.1905
3	1.0288	.1524			.1715	.1905	.1905
4	1.0288	.1334		.2286	.2241	.1905	.1905
5	1.0288	.8596		.2286	.4481	.2858	.1905
6	1.0288	1.1999		.381	.4294	.4382	.381
7	1.4918	1.8404		.5144		.4763	.4572
8	.1905	.2829		.381	.2829	.381	.3048
9	.1334	.1905	.6001	1.6461	2.3975	2.1963	.1905
10	.1143		1.5432		2.1963	2.1125	.1905
11	.1143		1.5775		2.146	2.0687	.1715
12	.1715		1.5432		1.8861	1.9719	.1715
13	.1143	.1334	1.5432			1.9204	.1715
14		.1334	1.6289			1.9719	.1715
15	.1905		1.7974		2.1628	2.1704	.1715
16	.1905		1.8652		2.1125	2.2131	.1905
17	.1524	.1905	.2286		.2075		
18		.2286	.2858		.2614	.2477	
19		.2858	.3429		.3547	.3048	.3239
20	.2477	.3239	.3429		.3361	.3429	.3048
21	.2477	.3048	.2477		.2987	.3239	.3429
22	.8063		.2477		.2263	.2477	2.0957
23	.7522		.2286		.2096		2.3411
24	1.0288	.7316		.2286		.1715	1.9035
Max	1.4918	1.8404	1.8652	1.6461	2.3975	2.2131	2.3411
Min	.1143	.1334	.2286	.2286	.1715	.1715	.1715
Avg	.5771	.4827	.9349	.4517	.8347	.9367	.4926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 204 / 11 KV Agrani agro express NON SHEDDABLE EXPRESS HV FEEDERS  
 fdr Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.04		.0476	.0286	.0705	.0762
2	.04	.0381		.0476	.0324	.0743	.0762
3	.04	.04		.0476	.04	.0781	.0762
4	.0648	.0381		.0476	.0381	.0476	.0762
5	.04	.0171		.0495	.0457	.0762	.0762
6	.0095	.0438		.0495	.0895	.0286	.0743
7	.0533	.0057		.0038	.0686	.0743	.0495
8		.021		.0191	.0419	.0667	.0724
9	.0152	.0705	.0533	.0095	.061	.0419	.0533
10	.0133		.0381	.0095	.0705	.0572	.1029
11	.0381		.0248		.0114	.0705	.1048
12	.0362		.0419		.0133	.0572	.0514
13	.04		.0419	.04		.04	.0514
14	.0419	.0381	.0381			.0381	.0819
15	.0381		.0229		.0476	.0114	.0248
16	.0152		.0553		.0381	.0533	.08
17	.0362	.0152	.04		.0362		
18	.0229	.0362	.0495		.0286	.0095	
19	.0133	.0343	.0495		.0095	.0095	.0705
20	.0152	.0324	.0495		.0705	.0095	.0705
21	.0171	.0381	.0152		.0533	.0991	.0743
22	.0229		.0152		.0267	.0762	.0553
23	.0705		.0495		.0991	.0762	.0495
24	.0152	.0724		.0476		.08	.0762
Max	.0705	.0724	.0553	.0495	.0991	.0991	.1048
Min	.0095	.0057	.0152	.0038	.0095	.0095	.0248
Avg	.0310	.0363	.0390	.0349	.0453	.0542	.0693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 201 / 11 KV Savarde Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1494	.2427		.3477	.6001	.4512
2	.1848	.1663	.2241	.6626	.3525	.5639	.4868
3	.1663	.1494	.2241	.6344	.1294	.5357	.4664
4	.1848	.1886	.2075	.6259	.4268	.5716	.4934
5	.2241	.1886	.2614		.5093	.6455	.5213
6	.3206	.2452	.3174		.8855	.9374	.679
7	.3584	.2829	.3395		1.0031	1.2809	.6249
8	.2772	.2054	.3174		.2587	.2987	
9	1.1888		.2054		.2614	.2957	1.1265
10	1.0837		.168		.2427	.2614	.7811
11	1.0084	.8482	.1829		.2033	.2353	.7907
12	.8859	.9442	.2172		.2587	.2743	.9105
13	.8288	.8482	.2172		.2378	.2012	.9181
14	.7876	.8259	.2172		.2241	.1829	.0914
15	.9259	.8097	.2378		.2195	.0905	.3315
16	1.0883	1.1174	.2402		.2012		.426
17	.2218	.2561	.2587		.4108		.1867
18		.2774	.2987		.5228	.4668	.2241
19		.2801	.3734		.2987	.5041	.2241
20		.2987	.3361		.3174	.4294	.2054
21		.2829	.3174				.1698
22	.1867	.2452	.8173			1.0494	.1698
23	.1494	.2241	.7628		.7621	.7964	.1509
24	.2033	.1494	.2241	.7002	.3567	.6287	.5921
Max	1.1888	1.1174	.8173	.7002	1.0031	1.2809	1.1265
Min	.1494	.1494	.168	.6259	.1294	.0905	.0914
Avg	.5230	.4083	.3004	.6558	.3832	.5167	.4792

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 202 / 11 KV Khujgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3334	.2069	.3578	2.2637	2.1729	2.2283	2.0862
2	.3153	.2069	.3578	2.1195	2.1214	2.0223	1.8938
3	.3153	.2256	.3976	2.0955	2.1338	1.9818	1.8785
4	.3334	.2082	.3787	2.0955	2.1033	2.0332	1.9014
5	.4319	.3222	.3787	2.0972	2.1626	2.1433	2.0576
6	.5877	.341	.5304	1.2955	2.7443	2.8319	2.4565
7	.6066	.4927	.5877	1.829	3.4728	3.7647	2.8346
8	.8292	.5102	.5289	.3048	.5475	.4664	.6397
9	3.8062		.3204	.2286	.4153	.4688	2.9325
10	3.598		.3187	.2286	.378	.4458	2.9363
11	3.3501	2.9316	.3812		.3353	.4688	2.7443
12	3.1827	3.1169	.305		.3153	.4458	2.1026
13	3.0312	2.2557		.1524	.4151	.4435	2.4432
14	2.8496	2.6368	.1648	.1524	.3372	.3452	2.6197
15	3.4555	2.4234	.2957	.1524	.3578	.3431	3.8647
16	3.653	2.8655	.442	.1524	.4504	.3372	4.4244
17	.3494	.2972	.5182	.2286	.4847	.2286	.7792
18	.2286	.4504	.5212	.381	.6005	.5001	1.0694
19		.49	.5974	.381	.6409	.4728	1.2445
20		.5849	.5791	.381	.6409	.6222	1.1512
21		.4738	.6424	.4572	.7373	.7159	.8866
22	.2831	.4527	2.7877	1.829	3.289	3.12	.7731
23	.2069	.434	2.7797	1.6766	2.9112	2.8426	.7171
24	.2774	.2831	1.6347	2.3399	1.3717	2.3319	1.1856
Max	3.8062	3.1169	2.7877	2.3399	3.4728	3.7647	4.4244
Min	.2069	.2069	.1648	.1524	.3153	.2286	.6397
Avg	1.5250	1.0095	.6872	1.0383	1.2975	1.3168	1.9843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 201 / 11 KV KUMTHE NAGAON

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413		.8002	.6224	.6859	.5601	.7011
2	.6036		.7621	.5847	.6478		.6154
3	.5975		.7621	.5847	.6478	.5281	.6219
4	.6099		.6097	.5975	.6287	.5093	.5784
5	.6838		.6097	.6099	.6287	.5906	.5721
6	.7499		.6478	.6584	.6097	.6668	.567
7	.6908		.6478	.567	.6097	.5729	.5914
8	.567		.5014	.4525	.4252	.4656	.4298
9	.5194	.5487	.4854		.4298	.3856	.3887
10		.4908	.4908		.4748	.4115	.4409
11		.5373	.463		.5316	.4191	.4508
12		.5014	.4908		.5201	.4748	.4508
13		.5083	.5028	.4557	.4801	.5316	.4801
14		.5249	.5258	.4961	.5201	.4854	.4508
15		.5014	.5201	.5014	.5373	.5373	.4607
16		.543	.5083	.4755	.5249	.5373	.4908
17		.5316	.4656		.4656		.4508
18		.5487	.591		.543	.5087	.5487
19		.6878	.8145		.7964	.6661	.8145
20		.8316	1.0059		.9425	.8145	.9425
21		.9522	.9145		.8871	.8871	.9055
22		.9145	.8402		.7577	.8326	.695
23		.9145	.7207		.6908	.8131	.695
24	.6413		.8002	.6535	.724	.6161	.7682
Max	.7499	.9522	1.0059	.6584	.9425	.8871	.9425
Min	.5194	.4908	.463	.4525	.4252	.3856	.3887
Avg	.6305	.6358	.6450	.5584	.6129	.5825	.5880

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 202 / 11 KV KAVALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478		.1578	.1612	.1578	.1294	.1494
2	.1478		.1417		.1629		.1494
3	.1307		.1478	.1448	.1433	.112	.1294
4	.132		.1417	.1463	.1387	.1132	.128
5	.1509		.1448	.1478	.1595	.132	.1463
6	.168		.1646	.1663	.1578	.168	.1478
7	.1629		.1629	.1509	.1612	.1646	.1478
8	.124		.1509	.1448	.1174	.1052	.0829
9	.116	.1294	.1147		.0857	.1029	.0716
10		.1214	.1341		.0678	.1387	.1086
11		.1715	.1526		.0549	.1543	.104
12		.1543	.1677		.0819	.1075	.1086
13		.1132	.1402	.0886	.0972	.0876	.1086
14		.0943	.0914	.0924	.1086	.1063	.1075
15		.0943	.0895	.0934	.0895	.1097	.1052
16		.112	.0876	.1109	.0943	.1109	.0867
17		.0943	.1509		.1017		.0895
18		.0943	.1578		.12	.1475	.0895
19		.132	.1595		.1928	.1578	.1132
20		.1698	.2075		.197	.1791	.1646
21		.1886			.1646	.1829	.1494
22		.1791	.2033		.1646	.1663	.1509
23		.181	.1629		.1294	.1595	.132
24	.1478		.1595	.1595	.1595	.1294	.1494
Max	.168	.1886	.2075	.1663	.197	.1829	.1646
Min	.116	.0943	.0876	.0886	.0549	.0876	.0716
Avg	.1428	.1353	.1475	.1339	.1295	.1348	.1217



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 203 / 11 KV Nagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.1143	.6773	.5487	.6308	.7287
2	.1143		.0953	.6554	.5312		.68
3	.1143		.0953	.6173	.5312	.6167	.6481
4	.1143		.0953	.6097	.6009	.6241	.7522
5	.1143		.0953	.6321	.6642	.664	.7432
6	.1334		.1143	.6308	.7407	.6874	.7499
7	.1334		.1143	.7926	.8905	.8488	.7562
8	.1334		.0953	.1143	.1143	.1524	.0762
9	1.1523	.7316	.0953		.0953	.1143	.945
10		.8951	.1143		.1143	.1143	.9907
11		.9172	.1143		.1524	.1143	.9646
12		.9568	.1143		.1524	.0953	1.0494
13		.7876	.1143	.1334	.1143	.1143	1.0822
14		.8535	.1143	.1524	.1143	.1143	1.0494
15		.8579	.1334	.1715	.1334	.1143	1.0526
16		.8177	.1524	.1524	.1334	.1143	.9907
17		.1334	.0953		.1715		.1143
18		.1334	.1143		.2667	.1334	.1334
19		.1334	.1334		.1715	.1334	.1715
20		.1143	.1334		.1334	.1524	.1334
21		.1143	.1143		.1524	.1524	.1334
22		.1143	.7274		.7562	.6009	.1524
23		.1143	.7842		.787	.6722	.1334
24	.1143		.1143	.7253	.5487	.6573	.7611
Max	1.1523	.9568	.7842	.7926	.8905	.8488	1.0822
Min	.1143	.1143	.0953	.1143	.0953	.0953	.0762
Avg	.2238	.5117	.1662	.4665	.3591	.3464	.6247

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 204 / 11 KV Kumthe Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4098	.9526	1.4289	6.311	4.9657	6.1996	4.8552
2	1.4098	.9526	1.4098	5.7952	4.9123	4.9154	4.4706
3	1.4098	.9526	1.4098	5.6598	4.731	4.1129	4.2981
4	1.486	1.0669	1.486	5.5327	3.9931	4.2867	4.235
5	1.7719	1.1812	1.5813	5.8352	4.1243	4.7621	4.523
6	1.9814	1.3336	1.7719	8.4477	8.1209	8.6248	6.7557
7	1.7909	1.2574	1.7719	***	***	***	7.7199
8	6.6111	3.5437	1.4479	1.2384	1.4479	1.2384	5.4107
9	***	7.0317	1.0669	.6859	1.3908	1.5051	***
10	***	6.1881	.7431	.6478	1.5813	1.5432	***
11	9.6403	6.4632	.8383	.8383	1.4479	1.6003	***
12	9.4879	6.7949	.9907	.7621	1.5241	1.5622	***
13	8.0399	6.1668	1.105	.9907	1.6575	1.5622	***
14	8.6115	7.465	1.1431	1.0288	1.467	1.6003	***
15	9.2212	7.0934	1.105	1.2003	1.3717	1.7719	***
16	8.9544	9.1297	1.0288	1.0098	1.3908	1.7528	***
17	.6478	1.1431	1.1431	1.0288	1.486	1.448	.9907
18	.9145	1.2955	1.2955	1.1812	1.829	2.3624	1.3717
19	1.2955	1.4479	1.8481	1.5242	2.2862	3.0293	1.7527
20		1.7338	2.3815	1.9814	2.8196	3.0674	2.0576
21	1.1431	1.7909	5.3536	4.1152	5.3726	5.2964	2.1148
22	1.0669	1.7146	8.6504	6.4396	8.9171	8.0315	2.0386
23	1.0288	1.5051	8.079	6.2491	8.5704	7.7808	1.4861
24	1.1812	1.1431	6.0776	6.3245	6.957	6.8978	2.4441
Max	12.0476	9.1297	8.6504	10.1299	10.5471	10.4252	12.0325
Min	.6478	.9526	.7431	.6478	1.3717	1.2384	.9907
Avg	4.4038	3.3061	2.2982	3.5399	3.8713	3.9740	6.1526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 205 / 11 KV Kavalapur Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488		.6325	.1886	.1698	.1509	.1886
2	.8025		.5937	.1698	.1698		.1698
3	.8124		.5864	.1698	.1698	.132	.1698
4	.8697		.6642	.1509	.1698	.132	.1698
5	.933		.8905	.1698	.1698	.1509	.1698
6	.9998		.9602	.1886	.1698	.1698	.1886
7	1.3565		.9602	.2241	.1698	.1886	.1886
8	.1867		.168	.1886	.1663	.0168	.1867
9	.168	.168	1.0957		1.2803	1.4083	.1294
10		.1254	1.0494		1.4175	1.3889	.1494
11		.1294	.9877		1.5497	1.4217	.1294
12		.1448	.9536		1.3426	1.358	.1307
13		.1433	.9808	.1254	1.0717	1.2498	.1463
14		.1463	.9829	.1463	1.2037	1.2809	.1075
15		.1267	1.0669	.1478	1.2193	1.0669	.1267
16		.1294	1.1294	.8745	1.2654	1.174	.128
17		.1417	.128		.1433		.1075
18		.1448	.1294		.1629	.2481	.1448
19		.1848	.2614		.2172	.2103	.181
20		.2263	.2641		.2075	.2172	.2075
21		.2263	.2641		.2075	.2075	.1886
22		.7202	.2263	.1886	.1886	.2075	.9998
23		.68	.1886	.1886	1.2163	.2075	.8642
24	.8535		.6478	.1886	.1698	.3584	.1886
Max	1.3565	.7202	1.1294	.8745	1.5497	1.4217	.9998
Min	.168	.1254	.128	.1254	.1433	.0168	.1075
Avg	.7831	.2292	.6588	.2207	.5924	.5885	.2234

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 201 / 11 KV PED AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.1102	2.0378	1.5638	1.2689
2				1.9685	1.909	1.5966	1.2696
3				1.874	1.8336	1.5874	1.2529
4				1.7749	1.7368	1.6949	1.2239
5				1.8503	1.8686	1.8587	1.2811
6				2.4394	2.3708	2.3221	1.5714
7				3.0224	3.0186	3.0216	1.893
8	.2385	.2073					.3643
9	2.9005	2.1674					1.8016
10	2.9843	2.1201			2.4249		2.3076
11	2.8723	1.9235					2.3198
12	2.9355	1.9624					2.2329
13	2.5248	2.0294					2.0919
14	2.5057	1.9456					2.1453
15	2.6848	2.2138					2.3403
16	2.854	2.3525			.128		2.5751
19					.181		
20					.181		
21			.2522	.2233	.2332	.4664	
22			2.7618	2.8212	5.336	2.652	
23			2.6909	2.2847	2.7465	2.5598	
24	.1543		2.4691	2.1925	2.3304	2.2298	
Max	2.9843	2.3525	2.7618	3.0224	5.336	3.0216	2.5751
Min	.1543	.2073	.2522	.2233	.128	.4664	.3643
Avg	2.2655	1.8802	2.0435	2.0510	1.8891	1.9594	1.7462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 202 / 11 KV HATNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3702	.7019	.7019		.1105	.1128	.125
2	1.2727	1.2727	.6958		.1151	.1151	.1196
3	1.2056	1.2056	.6912		.112	.1174	.1204
4	1.1805	1.1805	.6981		.1135	.1158	.1196
5	1.2399	1.2399	.7164		.1235	.1334	.1303
6	1.6065	1.6065	.9938		.1715	.1585	.1753
7	1.9364	1.9364	1.2155		.1829	.1806	.1661
8	.1486	.1486	.1417		1.4297	1.2254	.1433
9	.1517	.1517	.1364		2.3152	2.0309	.1219
10	.1257	.1257	.1158		4.252	2.0492	.0922
11	.1212	.1212	.1029		2.2695	1.9174	.0991
12	.1219	.1219	.1151	.1486	2.0546	2.0332	.1067
13	.125	.125	.109	.1692	1.8938	2.2268	.1075
14	.1288	.1288	.1067	.1456	1.9387	2.2199	.1288
15	.1326	.1326	.1097	.1562	1.9906	2.3845	.1158
16	.1463	.1463	.1059	1.8404	3.7906	1.0616	.1075
17	.1417	.1417	.1326	.5312	.1478	.1135	.125
18	.1539	.1539	.1509	.1844	.1517	.1395	.1372
19	.1478	.1478	.1677	.1783	.3481	.192	.1433
20			.1738	.1951	.3435	.1928	.1631
21	.1075	.1075	.823	.1753	.3224	.1776	1.2178
22	.7781	.7781	1.2742	.1684	.2816	.1669	1.9387
23	.7522	.7522	1.2254	.1517	.1235	.1364	1.9662
24	.711	.711	1.1225	.1113	.1143	.125	1.6773
Max	1.9364	1.9364	1.2742	1.8404	4.252	2.3845	1.9662
Min	.1075	.1075	.1029	.1113	.1105	.1128	.0922
Avg	.6003	.5712	.4928	.3197	1.0290	.8053	.3895

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 204 / 11KV HATNUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	05-APR-17
HR	Load (MW)
10	.1646
16	.1646
19	.3189
20	.4207
21	.3881
22	.3547
Max	.4207
Min	.1646
Avg	.3019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 206 / 11 KV PED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0964	.0922	.0972	.0926	.0869	.0892	.0907
2	.096	.0907	.0941	.0918	.0846	.0876	.0888
3	.0979	.0911	.0895	.0914	.085	.0884	.0873
4	.0975	.0876	.0934	.0907	.0903	.0861	.0876
5	.117	.1151	.104	.1036	.1075	.1109	.1055
6	.1646	.1547	.1654	.1475	.1547	.1661	.1642
7	.1749	.1722	.1627	.1604	.1467	.1627	.1574
8	.1257	.1501	.1269	.1231	.0998	.1078	.1101
9	.0991	.0918	.0987	.0945	.0934	.0899	.0846
10	.1048	.0876	.0949	.0987	.1288	.08	.0777
11	.1006	.0861	.0956	.0743	.0854	.072	.0758
12	.1044	.0854	.0979	.0865	.0987	.0911	.0777
13	.1002	.0899	.1067	.0899	.0972	.0892	.08
14	.0914	.1029	.0907	.0934	.0834	.0808	.08
15	.0972	.1082	.0934	.0758	.0819	.0899	.0758
16	.104	.0995	.0922	.0739	.1543	.0987	.0777
17	.0998	.0941	.0979	.0777	.0842	.096	.0827
18	.1151	.1223	.1181	.0979	.1109	.1166	.1014
19	.1299	.1715	.1699	.1551	.294	.165	.1722
20	.1246	.1818	.1772	.1688	.3113	.1661	.168
21	.1517	.1623	.1661	.1482	.2801	.1463	.16
22	.1254	.1368	.1417	.1398	.2216	.141	.1318
23	.1075	.1261	.1166	.1113	.1033	.1147	.1025
24	.2145	.1094	.1002	.1002	.0975	.1055	.0884
Max	.2145	.1818	.1772	.1688	.3113	.1661	.1722
Min	.0914	.0854	.0895	.0739	.0819	.072	.0758
Avg	.1183	.1171	.1163	.1078	.1326	.1101	.1053

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 208 / VIJAYNAGAR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	05-APR-17
HR	Load (MW)
10	.1097
16	.1463
19	.2353
20	.3258
21	.2896
22	1.3123
Max	1.3123
Min	.1097
Avg	.4032



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV PANMALEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7768	3.6054	3.395	.3481	.3565	.3193	.3498
2	3.5642	3.5147	3.2091	.3293	.3445	.3011	.3338
3	3.2944	3.3989	3.1585	.3315	.3279	.2827	.394
4	2.7569	3.3501	3.0449	.3138	.3271	.3367	.4337
5	2.8189	3.4286	3.0171	.3075	.3687	.3681	.4775
6	3.051	3.5932	3.0826	.3871	.4201	.4344	.5578
7	3.9841	4.1023	3.4061	.4736	.5007	.4946	.5373
8	.3806	.3681	.4968	.5137	.503	.4656	.5186
9	.4064	.4481	4.2404	3.0392	6.8015	2.6856	.5632
10	.4634	.535	5.1643	6.0852	6.608	3.2121	.6276
11	.4965	.5357	5.0213	6.046	6.8301	6.7505	.6649
12	.5489	.518	4.3709	2.9414	6.5931	1.9479	.5175
13	.4779	.5125	4.9974	.1654	6.1904	6.2925	.5441
14	.4397	.4174	4.971	.1722	6.041	6.4388	.5683
15	.4687	.4435	5.0615	.1783	6.0055	6.4151	.5727
16	.4611	.4914	2.7397	2.7816	6.1606	6.0881	.559
17	.4626	.5026	.4389	.2484	.4275	.3376	.5746
18	.3818	.3677	.4992	.2561	.5201	.2048	.6504
19	.3595	.3782	.5142	.2492	.5494	.4893	.6242
20	.3353	.4565	.4898	.2667	.6021	.5302	.5776
21	.3789	.3842	.4664	.4703	.5681	.4862	.9378
22	4.0185	4.1979	.4195	.4369	.5259	.4504	5.9092
23	4.0718	4.0066	.3951	.4035	.4584	.405	5.6806
24	4.0106	3.8432	1.7699	.3573	.3809	.3649	3.1356
Max	4.0718	4.1979	5.1643	6.0852	6.8301	6.7505	5.9092
Min	.3353	.3677	.3951	.1654	.3271	.2048	.3338
Avg	1.7254	1.8083	2.6821	1.1293	2.4338	1.9209	1.0962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1715	.2033	.1867	.1886	.1715	.168
2	.1494	.1524	.1867	.1698		.1524	.1698
3	.132	.1334	.1829	.1463		.1524	.1509
4	.1698	.1509	.1663	.1294		.1886	.1867
5	.2054	.1848	.2241	.1307		.2241	.2241
6	.2614	.2378	.2801	.168		.2587	.2614
7	.2614	.2402	.2402	.2402		.2328	.2218
8	.2172	.181	.1848	.2088		.1829	.1991
9	.1629	.1646	.1595	.1829	.1463	.1646	.1612
10	.1463	.1612	.1448	.1612	.1629	.1648	.1646
11	.1402	.1629	.1629	.1578	.1646	.1772	.1478
12	.1612	.1629	.1646	.1402	.1448	.1612	.1629
13	.1829	.1629	.1646		.1463	.1478	.1646
14	.2149	.1463	.168		.1448	.1494	.1848
15	.2012	.1663	.1612		.128	.17	.1646
16	.1629	.1663			.1448	.1663	.1478
17	.1829	.1433	.1629		.1646	.1663	.168
18	.1991	.1595	.181		.1991	.1823	.1772
19	.2195	.2534	.2149		.2561	.2587	.2772
20	.2587	.2561	.2402		.3326	.3109	.3109
21	.2561	.2402	.2218	.2587	.2926	.2772	.2743
22	.2353	.2334	.2195	.2427	.2772	.2641	.2614
23	.1867	.2218	.2054	.2054	.2241	.2241	.2054
24	.1698	.1698	.2033	.1867	.1886	.1886	.1867
Max	.2614	.2561	.2801	.2587	.3326	.3109	.3109
Min	.132	.1334	.1448	.1294	.128	.1478	.1478
Avg	.1928	.1843	.1932	.1822	.1945	.1974	.1976

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV SHIRGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3048	.2858		.3048	.362
2		.3048	.2858	.2667		.2477	.3429
3	.3048	.3048	.2667	.2667		.2286	.3048
4	.3429	.2858	.2667	.2477		.2667	.362
5	.381	.3048	.3048	.2477		.3429	.4191
6	.4382	.3239	.4001	.2858		.4191	.4572
7	.4382	.362	.4191	.3239	.4001	.381	.4001
8	.362	.2667	.4001	.2667	.3429	.3239	.362
9	.362		.2286	.2858	.2667	.3048	.2667
10	.2477	.381	.3239	.2667	.3048	.2096	.2858
11	.2667	.3048	.2858	.2667	.3239	.2477	.2972
12	.2858	.3239	.2858	.2667	.3239	.2667	.2953
13	.3048	.2667	.2858		.2858	.2667	.2667
14	.3239	.2858	.2477		.2667	.2858	.2858
15	.3429	.3239	.3048		.3048	.3125	.2477
16	.3239	.362			.2667	.2477	.2667
17	.3048	.3239	.3048		.2858	.2667	.2858
18	.3429	.3429	.3239		.3239	.3163	.3429
19	.4572	.4572	.362		.4001	.4191	.4763
20	.362	.5335	.4954		.5144	.5335	.5144
21	.4382	.4763	.4954	.4763	.4763	.5335	.4954
22	.4001	.4191	.4191	.4572	.4572	.5144	.4763
23	.4001	.381	.362	.381	.4001	.4572	.4191
24	.381	.362	.1905	.3429		.3429	.4001
Max	.4572	.5335	.4954	.4763	.5144	.5335	.5144
Min	.2477	.2667	.1905	.2477	.2667	.2096	.2477
Avg	.3545	.3496	.3289	.3084	.3497	.3350	.3597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4137	.391	.455	4.1426	3.7746	3.7601	3.5429
2	.4088	.378	.4369	3.9483	3.5947	3.6889	3.453
3	.3751	.3567	.4153	3.7258	3.4773	3.5597	3.396
4	.4091	.3742	.398	3.7136	3.4278	3.5246	3.3944
5	.4923	.4184	.4695	3.6229	1.8945	3.5673	3.4164
6	.6074	.4997	.5952	3.7898	1.989	3.7769	3.5445
7	.5976	.5419	.567	4.0196	4.019	4.1125	3.674
8	.8692	.9339	.5112	.5148	.5556	.423	.8556
9	5.0416	4.5542	.4965	.5445	.4618	.3566	4.3763
10	5.3879	5.041	.4771	.5396	.4287	.3254	4.5797
11	5.5247	4.7018	.4596	.5411	.4287	.304	2.4806
12	5.3292	5.3689	.3248	.533	.4535	.341	1.6385
13	5.3156	5.2315	.2172	.234	.3578	.4056	4.8333
14	5.3285	4.8559	.4068	.1555	.2849	.407	5.0259
15	5.2729	4.9204	.4911	.2172	.3909	.4159	5.2141
16	5.2241	4.9527	.2629	.2233	.458	.4412	5.125
17	.4085	.4596	.5555	.2309	.5243	.5289	.4771
18	.5112	.5033	.5487	.2576	.5634	.5622	.4809
19	.5099	.6131	.0412	.2538	.5521	.5369	.5407
20	.5234	.6384	.5743	.2759	.5959	.5982	.6513
21	.503	.5826	.9381	.8154	.9522	.8064	.5969
22	.4664	.4967	4.542	4.2244	4.2905	4.3145	.5278
23	.4401	.4929	4.5538	4.1804	4.2714	3.9891	.4816
24	.427	.4233	2.6124	4.1244	4.0394	3.8203	1.9456
Max	5.5247	5.3689	4.5538	4.2244	4.2905	4.3145	5.2141
Min	.3751	.3567	.0412	.1555	.2849	.304	.4771
Avg	2.0995	1.9888	.8896	1.8679	1.7411	1.8569	2.6772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.917	1.3599	1.5546	.1448		.1524	.1294
2	1.8299	1.3123	1.4746	.1294		.1334	.1307
3	1.7814	1.3108	1.4243	.1307		.1143	.1494
4	1.7394	1.2483	1.4419	.1294		.1509	.1478
5	1.8351	1.3272	1.4575	.1463		.1848	.1663
6	1.8138	1.3763	1.4548	.168			.197
7	2.0972	1.7284	1.3441	.2058	.1848		.2218
8	.1341	.1646	.124	.1543	.1867		.1829
9	.1595		1.8244	2.769	2.7035	2.8837	.168
10	.0914	.1698	2.4086	2.6558	2.9607		.1663
11	.0895	.128	2.3758	2.5425	2.8673	2.4981	.1701
12	.1097	.1254	2.5069	.1166	2.8807	2.652	.1701
13	.1075	.1578	2.2672		2.8673	2.9635	.1719
14	.1267	.1402	2.3644		2.6726	2.9797	.181
15	.1097	.1254	2.3967		1.4746	2.8018	.1753
16	.1086	.1646			1.3763	2.5777	.1829
17	.0905	.1372	.1174		.1086	.112	.2054
18	.1097	.1543	.1029		.1463	.1265	.1739
19	.1448	.1886	.12		.181	.168	.2195
20	.1829	.1629	.2195		.2103	.2033	.2436
21	.1646	.1791	.2033	.2172	.197	.2033	.2195
22	1.3763	1.7976	.1867	.1848	.1848	.1867	2.5194
23	1.4419	1.7532	.1478	.1494	.1698	.1663	2.5857
24	1.9989	1.3603	1.6004	.1433		.1509	.1478
Max	2.0972	1.7976	2.5069	2.769	2.9607	2.9797	2.5857
Min	.0895	.1254	.1029	.1166	.1086	.112	.1294
Avg	.8150	.7205	1.2660	.6242	1.2572	1.0705	.3761

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV PANMALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2509	.2214	.2225	.1951	.196	.1974	.2427
2	.2279	.202	.2006	.1741	.1729	.173	.2199
3	.2298	.1764	.2005	.1794	.1722	.1699	.2206
4	.2538	.2075	.2014	.1814	.1809	.1989	.2481
5	.2591	.2267	.2255	.2063	.1991	.2012	.2494
6	.3029	.272	.2719	.2699	.2492	.253	.3056
7	.3336	.3086	.269	.3246	.2808	.2698	.3433
8	.3468	.2678	.2288	.2812	.2626	.2816	.2545
9	.2869	.2267	.1961	.1976	.2	.1909	.2172
10	.2233	.1778	.1982	.1907	.1768	.0953	.1928
11	.2038	.1916	.1685	.1714	.1813	.1731	.1673
12	.198	.154	.1922	.1859	.1677	.077	.157
13	.2293	.1586	.1835	.096	.1949	.1674	.176
14	.221	.1855	.248	.0983	.2233	.184	.1992
15	.2053	.1945	.2214	.096	.2172	.1851	.2079
16	.226	.1968	.1059	.0903	.193	.1658	.1995
17	.2221	.1741	.2149	.0876	.1996	.1764	.2141
18	.2271	.184	.2218	.0956	.2	.1928	.2168
19	.3326	.306	.2821	.1551	.3161	.3425	.3805
20	.3574	.4011	.3145	.1955	.4066	.4393	.3913
21	.3223	.3765	.3536	.3265	.3561	.4218	.3921
22	.3063	.2892	.2799	.2928	.3067	.3776	.3109
23	.2564	.2477	.2405	.2431	.2648	.2664	.2654
24	.2429	.2471	.2271	.2031	.2071	.2325	.2431
Max	.3574	.4011	.3536	.3265	.4066	.4393	.3921
Min	.198	.154	.1059	.0876	.1677	.077	.157
Avg	.2611	.2331	.2279	.1891	.2302	.2264	.2506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 207 / 11KV NIMBLAK CHIKAL GOTHAN SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1334	.168	1.989		1.9204	1.9559
2	.1494	.1143	.1509	1.9498		1.8842	1.8679
3	.1509	.1143	.1494	1.7924		1.7814	1.8351
4	.1886	.1509	.1307	1.8351		1.7124	1.7736
5	.2263	.1646	.1698	1.9989		1.7764	1.7736
6	.2641	.1791	.2075	2.0243		1.8842	1.8023
7	.2241	.1829	.1867	2.13		2.0805	1.9062
8	.1494	.1448	.1698	.2054	.1698	.181	.1867
9	2.8837		.1448	.2054	.1991	.1463	2.3868
10	3.2217		.1494	.2241	.1829	.1478	2.5434
11	3.0476	2.2542	.168	.2241	.2149	.1792	2.5819
12	3.0001	2.5194	.1848	.2427	.1991	.1867	1.4737
13	3.0476	2.5692	.2033		.1829	.1646	1.5893
14	2.8487	2.4531	.2054		.1433	.1663	2.2377
15	2.8346	2.8837	.2241		.1629	.1774	2.1548
16	2.7206	2.6355			.1646	.2054	2.3205
17	.1753	.2218	.2402		.1791	.2012	.2054
18	.2012	.2801	.2241		.197	.2353	.1848
19	.1791	.2402	.2452		.2195	.2353	.2614
20	.1463	.2641	.2641		.2012	.2452	.2509
21	.1402	.2427	.2452	.2452	.1753	.2054	.2452
22	.1646	.2263		2.8837	2.1925	2.2542	.2263
23	.1663	.1867	1.9725	2.7183	2.0805	2.1548	.2075
24	.1698	.1509	.1698	1.9989		2.0972	2.0553
Max	3.2217	2.8837	1.9725	2.8837	2.1925	2.2542	2.5819
Min	.1402	.1143	.1307	.2054	.1433	.1463	.1848
Avg	1.1021	.8324	.2715	1.4167	.4290	.9260	1.4178

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 208 / 11kv VISAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5565	.7842	1.0883	.1294			.1307
2	1.5061	.7701	1.085	.112	.1132		.1307
3	1.4575	.7449	1.065	.0943	.1132		.1109
4	1.5074	.7522	1.0526	.0934	.1132		.1294
5	1.5223	.7907	1.0242	.1109	.1509		.1307
6	1.5546	.852	1.0467	.1463	.1867		.168
7	1.7859	1.1043	.9962	.1701	.1867		.2241
8	.1791	.1448	.1791	.2195	.1663		.2218
9	.1463		1.3603	1.8351	2.0485	2.0005	.1867
10	.1254		1.6712	1.9662	2.13	1.6644	.1698
11	.1267	.0747	1.8564	1.9662	1.9845	2.1879	.1494
12	.1463	.1254	1.8023	.1457	2.1136	2.0729	.1698
13	.1267	.1267	1.704		2.0081	1.8623	.1698
14	.1463	.1052	1.8515		1.9334	1.9662	.168
15	.1448	.112	1.8842		1.9227	1.9334	.1886
16	.1646	.1463			1.8187	1.6404	.1886
17	.1629	.1267	.1254		.0905	.128	.168
18	.1829	.1646	.1267		.128	.1433	.1502
19	.1991	.1848	.1646		.1433	.1646	.168
20	.1433	.1848	.168		.1646	.1848	.2218
21	.1267	.1756	.168	.168	.1629	.1848	.2241
22	.8642	1.2631	.1494	.1698	.1646	.1509	1.989
23	.8065	1.1843	.1433	.1509	.168	.1478	1.9559
24	1.6385	.8002	1.0911	.1294		.1509	.1478
Max	1.7859	1.2631	1.8842	1.9662	2.13	2.1879	1.989
Min	.1254	.0747	.1254	.0934	.0905	.128	.1109
Avg	.6800	.4872	.9480	.4755	.8187	1.0364	.3192



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 209 / WASUMBE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.5754	.5639	.5868	.5716	.522	.5601
2	.6097	.5449	.5449	.5754	.5563	.5144	.5563
3	.602	.5258	.5335	.5601	.5373	.5106	.5487
4	.5944	.5182	.5182	.5373	.5182	.4954	.5373
5	.522	.5182	.4496	.4649	.4763	.4725	.4725
6	.5639	.4915	.4992	.5068	.4877	.4611	.5182
7	.6173	.503	.5258	.5144	.5411	.4954	.5525
8	.4954	.5258	.5335	.5144	.5411	.503	.5258
9	.5296	.5563	.4954	.4954	.5296	.4572	.5068
10	.5639	.6401	.5258	.4763	.5335	.5258	.5639
11	.6249	.6935	.6668	.5335	.6211	.0152	.5601
12	.5982	.6973	.6211	.5335	.6592	.6706	.6135
13	.5487	.5754	.6173	.583	.6516	.6287	.6249
14	.4725	.5449	.5373	.5182	.522	.5563	.6478
15	.4877	.5601	.4839	.4725	.5335	.5868	.5677
16	.583	.6554	.442	.4458	.5373	.5982	.5449
17	.5754	.644	.4725	.4763	.5296	.663	.602
18	.5944	.6401	.5335	.4763	.5411	.5716	.5944
19	.3086	.6859	.5792	.4839	.5449	.6935	.6516
20	.4534	.8078	.7202	.6554	.6668	.8002	.7468
21		.7545	.7506	.6783	.7621	.7659	.7697
22	.4344	.6783	.7202	.6783	.7087	.6935	.7278
23	.6325	.6287	.6706	.6668	.6668	.6859	.7011
24	.5639	.5792	.6097	.602	.6135	.6211	.6173
Max	.6706	.8078	.7506	.6783	.7621	.8002	.7697
Min	.3086	.4915	.442	.4458	.4763	.0152	.4725
Avg	.5498	.6060	.5673	.5432	.5771	.5628	.5963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 210 / KAWATHE EKAND INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.423	.7011	.7659	.724	.743	.7468
2	.7202	.4344	.6859	.7164	.7354	.7392	.7164
3	.724	.4268	.6783	.6287	.6821	.6973	.6363
4	.7011	.4115	.6783	.5982	.6897	.6897	.6401
5	.663	.362	.6706	.5982	.663	.6592	.6363
6	.644	.3391	.6706	.5373	.583	.5944	.6401
7	.583	.3163	.644	.4725	.4687	.503	.5487
8	.4572	.2515	.4915	.3887	.4191	.4572	.4115
9	.3925	.2362	.5258	.3163	.4191	.4458	.3734
10	.3772	.2324	.5144	.3163	.4153	.4191	.4001
11	.4382	.2743	.5068	.4725	.4153	.4801	.4763
12	.6516	.7011	.6706	.5868	.6401	.7811	.6668
13	.7392	.7735	.8421	.6173	.6363	.8726	.6973
14	.7392	.6859	.8421	.4801	.6668	.7583	.7202
15	.7316	.6401	.7964	.5373	.6783	.6935	.7583
16	.6592	.7049	.8154	.5411	.6706	.6897	.7964
17	.6668	.6859	.7888	.442	.7278	.6821	.7735
18	.7011	.6973	.5944	.3925	.7049	.6401	.7506
19	.6287	.7125	.4611	.4572	.5906	.4763	.602
20	.5373	.5525	.6059	.503	.5639	.5487	.4572
21	.2934	.5411	.6287	.4763	.5335	.3391	.4915
22	.1715	.5106	.6135	.5373	.6211	.3315	.522
23	.2096	.4306	.6478	.6059	.5982	.4306	.6059
24	.4039	.6859	.743	.7049	.6935	.7049	.6859
Max	.7392	.7735	.8421	.7659	.7354	.8726	.7964
Min	.1715	.2324	.4611	.3163	.4153	.3315	.3734
Avg	.5633	.5012	.6590	.5289	.6058	.5990	.6147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 208 / 11 KV MATKUNKI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4387	1.4632	1.768	.221	.2515	.282	.2515
2	2.3472	1.3565	1.6918	.221	.2439	.2743	.2362
3	2.2329	1.3336	1.6842	.2134	.2362	.2743	.2286
4	2.1643	1.326	1.6156	.2134	.2362	.2667	.2286
5	2.1338	1.3032	1.5851	.221	.2362	.2743	.2286
6	2.4539	1.5394	1.6232	.2515	.2743	.282	.2667
7	3.0255	1.8671	1.8823	.3125	.3353	.3887	.3506
8	.6249	.282	1.6842	.3353	.3353	.3887	.381
9	.221	.2134	2.1795	2.4768	2.873	.2743	.3201
10	.221	.1829	3.0407	3.315	3.6808		.3048
11	.2362	.2286	3.0636	3.3074	3.7647		.2972
12	.2058	.2439	3.0712	3.155	2.7282		.1981
13	.2591	.2058	2.9797		3.0559	.221	.221
14	.2591	.2058	2.1795		3.1321	3.2998	.221
15	.2591	.2058	2.5758		3.0102	3.879	.1981
16	.2362	.221	2.7054	.602	.4344	4.0619	.1981
17	.2743	.221	2.4539	2.0881	.1677	3.4446	.1296
18	.2972	.2591	.2439	.3048	.2896	.282	.2439
19	.3277	.282	.2058	.3582	.2591	.3125	.16
20	.2972	.3734	.282	.3658	.3506	.3887	.2058
21		.3658	.3353	.381	.4039	.381	.282
22	.9755	1.7147	.3125	.3506	.3658	.3429	2.3091
23	1.5546	2.0119	.2591	.3353	.3048	.3048	2.7206
24	1.4937	1.9662	.2439	.2743	.2896	.2667	2.8273
Max	3.0255	2.0119	3.0712	3.315	3.7647	4.0619	2.8273
Min	.2058	.1829	.2058	.2134	.1677	.221	.1296
Avg	1.0669	.8072	1.6528	.9192	1.1358	.9472	.5420

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 201 / 11 KV ANKALKHOP GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.2058	.2058	.2058	.2058	.1886
2	.1715	.2058	.1715	.2058	.2058	.2058	.1715
3	.1372	.2058	.1715	.2058	.2058	.2058	.2058
4	.1372	.2058	.2058	.2058	.0686	.2058	.2058
5	.1715	.2401	.2401	.2401	.0686	.2058	.1715
6	.2058	.3086	.2743	.2743	.1029	.2743	.1715
7	.2401	.2401	.2058	.2401	.1029	.2401	.1715
8	.1715	.2058	.1715	.1715	.0686	.1715	.1715
9	.1715		.1715	.1715	.0686	.1715	
10	.1715		.1715	.3086	.1029	.1715	.1372
11	.1715	.1715	.1372	.1715	.1372	.1715	.1372
12	.2058	.2058	.2401	.1715	.2058	.1715	.1715
13	.2401	.2401	.2058	.1715	.2401	.2058	.2058
14	.2058	.2743	.2058		.2058	.2058	.1715
15	.2058	.2058	.2058		.2058	.1715	.2058
16	.2058	.2058	.2743		.2401	.2058	.2058
17	.2058	.2058	.1715		.2058	.3086	
18	.2058	.2058	.2058		.2058	.3429	.2058
19	.3086	.2401	.3086		.2743	.3429	.2401
20	.3429	.3086	.3772		.3429	.3429	.2743
21		.3772	.3429		.2743	.3086	.3086
22	.3429	.3429	.3429	.2743	.2743	.2401	.3086
23	.2743	.2743	.3086	.2401	.2401	.2401	.2401
24	.2058	.2058	.2058	.2058	.2058	.2401	.2058
Max	.3429	.3772	.3772	.3086	.3429	.3429	.3086
Min	.1372	.1715	.1372	.1715	.0686	.1715	.1372
Avg	.2117	.2401	.2301	.2165	.1858	.2315	.2034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 202 / 11 KV AUDUMBER GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	2.2805	4.2524	.2058	.2401	.2401	.2401
2	.1372	2.2805	4.2524	.1886	.2401	.2401	.2229
3	.1372	2.2805	4.2524	.1886	.2401	.2401	.2229
4	.1372	2.2977	4.2867	.1886	.2401	.2401	.2058
5	.1372	2.332	4.6982	.2401	.2058	.2744	.2229
6	.1372	2.5034	4.9726	.2915	.2401	.3086	.2401
7	.1372	2.1776	5.1783	.2058	.3086	.2744	.2744
8	.1372	.1715	.2401	.1715	.2058	.2058	
9	.1372		6.1385	3.1722	6.893	6.4472	
10	.1372		6.0699	6.3436	7.3045	8.059	
11	.1372	.1715	3.6351	6.5329	6.5158	7.5103	
12	.1543	.2058	3.5665	.1715	5.8985	7.8875	
13	.1715	.2058	3.6523	.1715	5.3155	7.2931	
14	.2058	.2058	3.6008		7.0302	6.8854	.1715
15	.205	.2058	3.5494		6.6187	6.6872	.1372
16	.1886	.2401	3.3608		6.8244	3.4122	.1715
17	.1886	.2401	.1715		.2058	.1715	
18	.1886	.2058	.1886		.2401	.2229	.2229
19	.2401	.2401	.2743	.2744	.3086	.2572	.2401
20	.2915	.2744	.2743	.2744	.3086	.2743	.2401
21		.3086	.2572	.2744	.2744	.2743	.2401
22		.2743	.3258	.2744	.3086	.2401	.1543
23	2.4006	3.9094	.2229	.2401	.2744	.2572	.1543
24	2.8464	2.332	4.2867	.2058	.2401	.2744	.2401
Max	2.8464	3.9094	6.1385	6.5329	7.3045	8.059	.2744
Min	.1372	.1715	.1715	.1715	.2058	.1715	.1372
Avg	.3905	1.1520	2.9878	1.0324	2.3534	2.4241	.2118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 203 / 11 KV BHILAWADI GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4801	.5144	.4458	.5487	.583	.5144
2	.5144	.4801	.4801	.4458	.5144	.5487	.0514
3	.4458	.4801	.4801	.4458	.5144	.5487	.4801
4	.4115	.4458	.4801	.4458	.5144	.4801	.4973
5	.5144	.4801	.5487	.4458	.5487	.5144	.5144
6	.6173	.6516	.6173	.6859	.6516	.6173	.5487
7	.6516	.6516	.5144	.6173	.5144	.583	.583
8	.4458	.4115	.4458	.4115	.4458	.4458	.3601
9	.4458		.3772	.4115	.4458	.3772	.4287
10	.4115		.4115	.3429	.4115	.3944	.4458
11	.4115	.4115	.3772	.3429	.4115	.3772	.4458
12	.4458	.4458	.4115	.3772	.4115		.4115
13	.4458	.4801	.4115	.4115	.4115	.4801	.4115
14	.4801	.5144	.4115		.5144	.4287	.3772
15	.5487	.5144	.4458		.5144	.4973	.4287
16	.5144	.5144	.4801		.4458	.5144	.4801
17	.4801	.5487	.3772		.4973	.4458	
18	.5144	.5144	.3772		.583	.6344	.5487
19	.6516	.6173	.6859		.6859	.6344	.583
20	.7202	.7202	.6859		.7545	.7716	.6173
21		.6859	.6516		.7202	.7202	.7545
22	.6173	.6516	.6516	.6516	.6859	.6687	.6516
23	.5487	.6173	.5487	.583	.6173	.6001	.6173
24	.583	.4801	.5487	.5144	.5487	.6173	.5487
Max	.7202	.7202	.6859	.6859	.7545	.7716	.7545
Min	.4115	.4115	.3772	.3429	.4115	.3772	.0514
Avg	.5204	.5362	.4973	.4737	.5380	.5427	.4913

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 204 / 11 KV NAGATHANE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.3429	.3429	.3429	.3086	.2743	1.7833
2	.2401	.3429	.2743	.3429	.2743	.2401	.3086
3	.2058	.3429	.2058	.3429	.2058	.2058	.2915
4	.2058	.3429	.3429	.3429	.2058	.2743	.2743
5	.2743	.4458	.3429	.4115	.2058	.3429	.3086
6	.3429	.5144	.3772	.4458	.2743	.4458	.3429
7	.4115	.4115	.4458	.4801	.3429	.4115	.4115
8	.2743	.3429	.4458	.3772	.2401	.3086	.3086
9	.2401		.2058	.3429	.2401	.2743	.3086
10	.2058		.1715	.4801	.2401	.2743	.2743
11	.2058	.2743	.1715	.2401	.2401	.2743	.2401
12	.1715	.3086	.3086	.2401	.2401	.2743	.2058
13	.2743	.3086	.3086	.2401	.2401	.2743	.2058
14	.2743	.3086	.3086		.3429	.3429	.2401
15	.3429	.2743	.3429		.3429	.3086	.2401
16	.2743	.3086	.3429		.3429	.3086	.2743
17	.3086	.3429	.2743		.3429	.3086	
18	.3429	.3086	.2401		.2401	.4115	.3086
19	.3772	.3429	.4458		.4115	.4115	.3086
20	.4458	.3772	.5144		.4801	.3429	.3086
21		.4115	.4801		.4801	.4458	.3086
22	.4801	.2743	.4115	.3772	.4458	.4115	.3086
23	.4115	.2743	.4115	.3772	.4115	.3772	.2401
24	.2743	.3772	.2401	.3048	.3429	.4115	.2743
Max	.4801	.5144	.5144	.4801	.4801	.4458	1.7833
Min	.1715	.2743	.1715	.2401	.2058	.2058	.2058
Avg	.2967	.3445	.3315	.3555	.3101	.3315	.3511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 205 / 11 KV ANKALKHOP AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9875	1.5745	1.7262	.0343	.0343	.0343	.0343
2	1.909	1.5486	1.6949	.0343	.0343	.0343	.0343
3	1.8815	1.5112	1.6957	.0343	.0343	.0343	.0343
4	1.9044	1.4609	1.7002	.0343	.0343	.0343	.0343
5	1.8983	1.4152	1.7025	.0343	.0343	.0343	.0343
6	1.9623	1.4617	1.7306	.0343	.0343	.0343	.0343
7	2.0789	1.6317	2.0065	.0495	.1021	.0343	.1059
8	1.1812	.9618	1.009	.0724	.0427	.0412	.0396
9	.0343		2.1026	2.0652	2.2962	2.2999	.0473
10	.0343		2.87	2.9302	2.7123	3.0099	.0343
11	.0343	.0343	3.139	2.9309	2.8769	3.1821	.0343
12	.0343	.0343	3.1592	1.5691	2.9584	3.381	.0343
13	.0343	.0343	3.1547	.1852	3.0368	3.4374	.0343
14	.0343	.0358	3.0689		2.87	3.3501	.0343
15	.0343	.0343	2.9774		2.7313	2.9885	.0343
16	.0343	.0343	2.7999		2.7931	1.5752	.0343
17	.0343	.0343	1.5318	1.0601	1.4723	1.5966	
18	.0343	.0343	.0343		.0373	.0343	.0343
19	.0008	.0358	.0343	.0023	.0343	.0343	.0343
20	.0343	.0373	.0358		.0343	.1044	.0343
21	.0244	.0366	.0343		.0351	.0831	.0366
22	.7995	1.4693	.0343	.0343	.0343	.0716	1.7932
23	1.6225	1.7261	.0351	.0343	.0343	.1067	2.38
24	1.7901	1.6713	.8573	.0343	.0343	.0351	1.323
Max	2.0789	1.7261	3.1592	2.9309	3.0368	3.4374	2.38
Min	.0008	.0343	.0343	.0023	.0343	.0343	.0343
Avg	.8091	.7645	1.6306	.6208	1.0142	1.0655	.2728



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 206 / 11KV AUDUMBER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.649	2.1262		.0343		
2	2.5819	2.0919		.0343		
3	2.5484	2.1262		.0343		
4	2.5484	2.1434		.0343		
5	2.5149	2.1434		.0343		
6	2.4813	2.3148		.0343		
7	2.431	2.0576		.0343		
8	.0335	.0343	.0343	.0343		
9	.0335	.0343	2.9835	3.0178		
10	.0335	.0343	2.9492			
11	.0343		3.5151			
12	.0343		3.4294			
13	.0335		3.5151			
14	.0343		3.4294			.0335
15	.0343		3.3779			.0335
16	.0343		3.1893		3.2579	.0335
17	.0343		.0343		.0343	
18	.0343		.0229			.0343
19	.0343		.0343			.0335
20	.0343		.0343		.0343	.0343
21			.0343		.0343	.0335
22	2.2634		.0343		.0343	1.8778
23	2.2634	1.8861	.0343		.0343	1.6766
24	2.6406	2.2291	2.0576	.0343		
Max	2.649	2.3148	3.5151	3.0178	3.2579	1.8778
Min	.0335	.0343	.0229	.0343	.0343	.0335
Avg	1.1028	1.6018	1.6888	.3327	.5716	.4212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 207 / 11 KV BHILAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	1.4746	1.7147	1.406	3.5665
2	.0343	.0343	.0343	1.4403	1.5775	1.4403	3.4637
3	.0343	.0343	.0343	1.4403	1.5089	1.4746	3.4465
4	.0343	.0343	.0343	1.4403	1.5089	1.4403	3.4294
5	.0343	.0343	.0343	1.4403	1.6118	1.3717	.3326
6	.0343	.0343	.0343	1.4403	1.749	1.3032	3.275
7	.0343	.0343	.0343	1.4575	1.6461	1.2346	3.2922
8	.0343	.0343	.0343	.0343	.0343	.0343	.0343
9	2.8807		.0343	.0343	.0343	.0343	2.332
10	3.0864		.0343	.0343	.0343	.0343	2.4006
11	3.155		.0343	.0343	.0343	.0343	2.332
12	3.0864	2.2634	.0686	.0343	.0343	.4287	2.4006
13	2.9492	2.332	.0686	.0343	.0343	.0343	2.4691
14	2.9492	2.1948	.0686		.0343	.0343	2.5377
15	2.8121	2.4006	.0686		.0343	.0343	2.5377
16	2.6749	2.4006	.0686		.0343	.0343	2.5377
17	.0343	2.2634	.0686		.0343	.0343	
18	.0343	.0343	.0686		.0343	.0343	.0343
19	.0343	.0343	.0686		.0343	.0343	.0343
20	.0343	.0343	.0686		.0343	.0343	.0343
21		.0343	.0686		.0343	.0343	.0343
22	.0343	.0343	1.6461	1.6461	1.5775	3.4465	.0343
23	.0343	.0343	1.7147	1.6804	1.4403	3.6351	.0343
24	.0343	.0343	.0343	1.5775	1.7833	1.4403	3.6351
Max	3.155	2.4006	1.7147	1.6804	1.7833	3.6351	3.6351
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	1.0482	.6843	.1858	.9527	.6916	.7945	1.9230

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 208 / 11 KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1372	.1372	2.0576	2.0233	1.6118	1.8347
2	.1029	.1372	.1372	1.8861	1.8861	1.4746	.1783
3	.1029	.1372	.1372	1.7147	1.7833	1.406	1.749
4	.1372	.1372	.1372	1.7147	1.7147	1.3032	1.7147
5	.1372	.1372	.1715	1.7147	1.7833	1.2689	1.8861
6	.1372	.2058	.1715	1.9204	1.8519	1.3032	1.989
7	.1372	.2058	.1715	2.0576	1.9204	1.3032	2.1948
8	.1372	.1372	.2058	.1372	.1372	.1372	.0343
9	3.2922	2.6063	.2058	.1715	.1372	.1372	3.155
10	3.4294		.1372	.2058	.1372	.1372	3.3608
11	3.6351	3.4979	.1372	.2058	.1372	.1372	3.0178
12	3.6008	3.2236	.1372	.2058	.1372	.1372	3.0864
13	3.155	3.0864	.1372	.1715	.1372	.1372	3.155
14	3.155	2.7778	.1372		.1372	.1372	2.6749
15	2.8121	2.915	.1372		.1372	.1372	2.7092
16	2.8121	2.8121	.1372		.1372	.1372	2.7435
17	.1372	.1372	.1372		.1372	.1372	
18	.1372	.1372	.2058		.2401	.1372	.1029
19	.1372	.1715	.0914		.2058	.1372	.1029
20	.2058	.1715	.1372		.1715	.2058	.1029
21		.1372	.1372		.1372	.1372	.1029
22	.1372	.1372	2.332	2.0576	1.9204	1.6804	.1029
23	.1372	.1372	2.332	2.0919	1.7833	2.0576	.1029
24	.1029	.1372	.1372	2.1948	2.1262	.1372	3.3608
Max	3.6351	3.4979	2.332	2.1948	2.1262	2.0576	3.3608
Min	.1029	.1372	.0914	.1372	.1372	.1372	.0343
Avg	1.2122	1.0139	.3311	1.2817	.8716	.6473	1.7157

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 201 / 11 KV YELAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6217	1.3794	1.3322	.2852	.2953	.3166	.2915
2	1.5386	1.3229	1.2041	.2629	.2922	.3174	.2766
3	1.5245	1.2903	1.1507	.2652	.2884	.3151	.2971
4	1.5158	1.3161	1.1652	.2831	.3063	.3371	.3121
5	1.5493	1.371	1.1507	.314	.3485	.3477	.3523
6	1.7315	1.5731	1.213	.4068	.4401	.4174	.4113
7	1.9974	1.8454	1.2784	.4129	.4279	.4478	.4523
8	.3418	.3563	.3932	.4487	.4424	.4695	.4226
9	.3508	.2876	1.7764	1.9109	1.9238	1.9741	.3441
10	.3599	.3014	1.9463	2.0107	2.1521	1.7292	.354
11	.3338	.3437	2.1071	1.9974	2.3952	2.111	.2584
12	.3035	.2758	2.0157	.5426	2.1609	2.0926	.2814
13	.302	.2591	1.9246		1.8945	1.9635	.292
14	.2913	.2968	1.6499		1.9085	1.7437	.2907
15	.2953	.2968	1.7093		1.7448	1.7345	.3239
16	.2882	.2922	1.6488	.5647	1.9243	1.7901	.3548
17	.2644	.3147	.2294	.141	.3037	.1273	.3841
18	.3212	.3391	.2873	.141	.3064	.3407	.3618
19	.4226	.3525	.3239	.1821	.3182	.3788	.4344
20	.4309	.3803	.3788	.176	.378	.4212	.458
21	.2065	.4252	.3834	.1722	.3609	.3795	.5182
22	1.3717	1.4312	.3557	.1669	.3553	.3553	1.9091
23	1.5882	1.3386	.3367	.1425	.35	.3311	1.7473
24	1.6042	1.4369	.9509	.3105	.2998	.3155	.9442
Max	1.9974	1.8454	2.1071	2.0107	2.3952	2.111	1.9091
Min	.2065	.2591	.2294	.141	.2884	.1273	.2584
Avg	.8565	.7844	1.1213	.5303	.9007	.8649	.5030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 202 / 11 KV Laxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.452	1.9044	2.2405	1.2382	2.3011	1.9978
2	2.4143	1.848	2.3011	1.2382	2.2822	2.1125
3	2.452	1.848	2.3577	1.2382	2.3011	2.1313
4	2.4709	1.8858	2.3577	1.2567	2.2822	2.2068
5	2.5086	1.9044	2.3765	1.307	2.2822	2.2257
6	2.584	1.9044	2.4897	1.3443	2.4331	2.32
7	2.6595	1.9993	2.5652	1.7353	2.3577	2.3954
8	2.6972	2.7349	1.3611	2.6406	2.4897	2.5086
9	2.9235	2.6783	2.0182	2.6972	2.5652	2.584
10	2.9235	2.8292	2.1691	2.7349	.2343	2.6029
11	2.9235	2.7349	2.4897	2.7538	2.6029	2.584
12	2.8292	2.5463	2.6595	2.6783	2.5463	2.4897
13	2.6783	2.5463	2.5652	2.6406	2.5274	2.3954
14	2.6783	2.5086	2.584	2.6595	2.5463	2.452
15	2.4331		2.5652	1.5466	2.5652	2.584
16	1.7375		2.0936	1.3014	1.8484	1.9616
Max	2.9235	2.8292	2.6595	2.7538	2.6029	2.6029
Min	1.7375	1.848	1.3611	1.2382	.2343	1.9616
Avg	2.5853	2.2766	2.3246	1.9382	2.2603	2.3470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 203 / 11 KV Yelavi Bu'wadi  
Gaonthan Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9583	.9267	.8611	.9027	.9191	.9313	.932
2	.9313	.8935	.804	.8344	.8897	.9153	.8806
3	.9621	.8927	.7785	.8337	.9046	.9333	.8956
4	1.0014	.9614	.8165	.9077	.9423	.9636	.9145
5	1.1532	1.1191	1.1027	1.0478	1.0463	1.0836	1.0757
6	1.4815	1.4071	1.3225	1.3835	1.4169	1.4132	1.426
7	1.3694	1.4061	1.3904	1.4072	1.3751	1.3454	1.3123
8	.9488	1.022	.9907	.9648	.9856	.9557	.9597
9	.8108	.8711	.7483	.7611	.7309	.815	.7489
10	.7038	.8219	.6722	.6817	.6348	.6531	.6051
11	.6839	.6984	.663	.6685	.6512	.6788	.6634
12	.7207	.7689	.7156	.6725	.6904	.743	.6691
13	.7747	.8063	.7023	.7085	.7278	.7484	.727
14	.7198	.7751	.7423	.3917	.7909	.7779	.7792
15	.8568	.5556	.759	.3986	.7552	.8006	.8135
16	.8652	.4725	.7476	.4024	.8147	.7998	.7385
17	.8665	.7903	.7507	.4199	.8127	.407	.8527
18	.9211	.9061	.7665	.4435	.899	.8494	.8512
19	1.2685	1.0311	1.2666	.5502	1.1668	1.2102	1.2528
20	1.5794	1.5577	1.499	.7575	1.4807	1.5204	1.5204
21	.7575	1.4758	1.4583	.7225	1.3782	1.4621	1.4568
22	1.246	1.3527	1.3252	.6851	1.3108	1.3764	1.4137
23	1.1077	1.1949	1.1535	.6036	1.129	1.1809	1.2137
24	.9968	.9957	.9983	.969	1.0112	.9957	1.0102
Max	1.5794	1.5577	1.499	1.4072	1.4807	1.5204	1.5204
Min	.6839	.4725	.663	.3917	.6348	.407	.6051
Avg	.9869	.9876	.9598	.7549	.9777	.9817	.9880

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 204 / 11 KV Burungwadi

Industrial Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.548	.5142	.4641	.5052	.5006	.4905	.5171
2	.5493	.5605	.4423	.4938	.4736	.491	.5075
3	.5121	.4977	.5085	.4923	.5264	.5095	.5016
4	.5346	.5018	.5232	.4961	.5266	.5214	.5128
5	.596	.4998	.631	.5491	.5341	.5929	.5861
6	.6087	.4199	.618	.5834	.6002	.5936	.5853
7	.3711	.33	.6253	.6135	.5799	.5281	.5715
8	.7289	.4736	.671	.6074	.7472	.8198	.6203
9	.9507	.5468	.9022	.7652	.9298	1.1778	.7545
10	.7991	.5982	.9925	.7751	.9957	1.1695	1.2125
11	.8835	.5346	.9084	.7847	.9842	1.3235	1.3946
12	.9054	.2385	.9012	.7377	.9583	.9096	1.2511
13	.8958	.5464	.9739	.6992	.9061	.8569	1.1263
14	.8297	.9537	1.1439	.3757	.9484	.9598	1.274
15	.9267	.9606	1.2662	.3849	.8419	1.0509	1.4224
16	.7857	.7568	1.3622	.3452	.8718	.9869	1.3339
17	.7411	.562	1.4102	.2949	.7583	.3422	1.3081
18	.6421	.4452	.8818	.3117	.7811	.6782	.7804
19	.6977	.5258	.9248	.4047	.889	.7678	.8139
20	.4841	.5498	.7301	.3414	.6367	.6739	.7907
21	.1974	.5159	.7636	.3681	.8196	.7465	.7446
22	.4386	.529	.683	.3041	.8088	.7388	.7314
23	.5533	.551	.6066	.3201	.5447	.6485	.6135
24	.6562	.4835	.555	.509	.4961	.5342	.5864
Max	.9507	.9606	1.4102	.7847	.9957	1.3235	1.4224
Min	.1974	.2385	.4423	.2949	.4736	.3422	.5016
Avg	.6598	.5456	.8120	.5026	.7358	.7547	.8559

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 205 / 11Kv Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1084	2.9612	2.8553	2.911	3.2202	2.455	3.1428
2	3.0986	3.122	2.7987	3.0694	3.2401	2.5802	3.1217
3	2.9434	3.027	2.6812	3.0677	3.0517	2.6259	3.086
4	2.9283	2.7978	2.7067	2.9541	2.9365	2.7183	2.9655
5	2.8957	2.8534	2.7678	3.0855	2.9909	3.0034	3.0178
6	3.0447	3.014	2.8835	2.9394	3.0258	2.9683	3.0883
7	3.0632	2.9837	3.0045	2.8125	2.8978	2.7612	2.9906
8	3.1655	3.2777	3.312	3.257	3.3672	3.1575	3.2213
9	3.0024	2.8418	3.0653	2.9816	2.8692	2.8239	2.958
10	2.6086	2.367	2.5252	2.6271	2.3026	2.3381	2.3221
11	2.9419	2.6206	2.8251	2.7681	2.4446	2.6152	2.6122
12	3.0529	1.9549	2.7751	2.6521	2.5356	2.8062	2.5656
13	3.6936	2.9279	3.5806	3.3507	2.9183	3.6723	3.4874
14	4.0625	3.7971	3.7418	1.8511	3.1487	3.6569	3.6711
15	3.9775	3.5965	3.7798	1.8168	3.3975	3.6227	3.667
16	3.7709	3.5651	3.5523	1.7825	3.7138	3.6957	3.5151
17	3.7277	3.5521	3.8009	1.7276	3.4386	1.7749	3.3905
18	3.4126	3.2773	3.2773	1.7177	3.1564	2.0524	2.9382
19	2.7843	2.4322	2.6471	1.2475	2.6705	2.3247	2.3657
20	2.6022	2.3672	2.5368	1.1736	2.5282	2.2586	2.2351
21	.7575	2.1986	2.2556	1.0387	2.1136	1.9852	2.1472
22	2.3384	2.1563	2.4838	1.0669	2.351	2.2348	2.4053
23	3.4307	3.0655	3.2561	1.5623	2.7723	3.0159	3.3331
24	3.0925	2.9942	3.0327	2.8558	2.8689	2.7247	3.0716
Max	4.0625	3.7971	3.8009	3.3507	3.7138	3.6957	3.6711
Min	.7575	1.9549	2.2556	1.0387	2.1136	1.7749	2.1472
Avg	3.0627	2.9063	3.0061	2.3465	2.915	2.7447	2.9716



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 206 / Yelavi Ag -2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0003	2.6557	1.8918	.3227	.3345	.3515	.3143
2	2.8227	2.5674	1.8642	.309	.3298	.3261	.2995
3	2.74	2.4409	1.8336	.3026	.3266	.3243	.3033
4	2.7579	2.4486	1.8805	.3134	.3254	.3391	.3125
5	2.8243	2.5293	1.9866	.343	.3536	.3661	.3332
6	3.4576	3.1774	2.2658	.4248	.418	.4283	.3656
7	4.3751	4.1663	2.5758	.5457	.5567	.5075	.4748
8	.4961	.4572	.6064	.5015	.4756	.5327	.4396
9	.3185	.3307	3.7963	3.7227	4.3355	3.9466	.2873
10	.2912	.2866	3.8317	3.7986	4.3062	3.7639	.3157
11	.2932	.2648	3.6969	3.6885	4.1831	4.2554	.2778
12	.2814	.2824	3.4888	1.874	3.8996	4.0223	.2149
13	.2972	.2614	3.3867		3.671	3.5429	.2553
14	.2978	.2645	3.2823		3.5733	3.4179	.2972
15	.2761	.2774	3.3097		3.6	3.6907	.3042
16	.2635	.2659	2.8266	1.3733	3.5237	3.5802	.3423
17	.2987	.2953	.2039	.2934	.3098	.2119	.3283
18	.3364	.2785	.3258	.2538	.306	.3125	.3423
19	.3458	.3609	.3815	.3086	.3934	.4123	.3357
20	.4214	.4527	.4419	.3948	.4976	.4512	.4738
21	.365	.4275	.4229	.3849	.4526	.3887	.4555
22	2.9599	2.7364	.4075	.3734	.4264	.382	4.1207
23	3.0983	2.6078	.3185	.3483	.3871	.3695	3.9202
24	3.0582	2.5057	.3406	.3506	.369	.3467	2.0168
Max	4.3751	4.1663	3.8317	3.7986	4.3355	4.2554	4.1207
Min	.2635	.2614	.2039	.2538	.306	.2119	.2149
Avg	1.4865	1.3476	1.8903	.9632	1.5564	1.5113	.7138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 201 / 11 KV VASAGADE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3308		.3163	.3186	.1753	.3147	.3399
2	.3098		.3307	.2938	.1692	.2987	.3113
3	.3067		.2978	.3102	.1661	.2811	.2958
4	.3262		.294	.3291	.1623	.2781	.3079
5	.3471		.3063	.3329	.1738	.2926	.3178
6	.343		.3669	.3489	.1791	.3681	.3315
7	.3247		.3795	.3178	.1578	.341	.3132
8	.3026	.0991	.3052	.2561	.1212	.266	.266
9	.2534		.2729	.2382	.1204	.2484	.2386
10	.2713		.2565	.2298	.1143	.249	.0328
11	.2603		.2646	.2591	.1288	.2793	.2313
12	.2903	.3558	.2652	.3005	.1471	.2793	.2835
13	.3079	.3716	.2934	.3046	.1578	.2865	.3109
14	.3134	.3704	.3009	.2964	.1638	.274	.0556
15	.3101	.3414	.3071		.2004	.3445	.1326
16	.2629	.3274	.2774		.1966	.3353	.2979
17	.0937	.3172	.287	.2938	.305	.3376	.3101
18	.1959	.386	.3406	.2965	.3125	.3246	.3124
19	.269	.4968	.4527	.4173	.4549	.4561	.4763
20	.2705	.5283	.4954	.2683	.4797	.4832	.4786
21		.4894	.4686	.4397	.439	.4657	.4997
22	.1067	.4416	.4119	.4801	.4306	.4229	.4901
23		.3883	.3664	.4243	.3871	.3888	.4641
24	.1698	.1852	.3231	.333	.33	.3656	.3728
Max	.3471	.5283	.4954	.4801	.4797	.4832	.4997
Min	.0937	.0991	.2565	.2298	.1143	.2484	.0328
Avg	.2712	.3642	.3325	.3222	.2364	.3325	.3113

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 202 / 11KV KHATAV GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201		.3147	.2907	.1623	.3026	.292
2	.2984		.3079	.2869	.1585	.3025	.2869
3	.2991		.2894	.3033	.1547	.2819	.2846
4	.3506		.3307	.3626	.1974	.326	.3452
5	.4552		.4064	.4119	.2294	.3915	.4317
6	.4801		.4626	.4687	.2507	.4313	.4756
7	.4458		.4527	.471	.2332	.4412	.4641
8	.378		.3685	.3613	.1913	.3121	.3826
9	.3048		.3033	.3351	.16	.3002	.3186
10	.3087	.1776	.2578	.3216	.1524	.2909	.2874
11	.3066	.3334	.2736	.3033	.16	.3075	.2745
12	.3193	.334	.2732	.2964	.1578	.2801	.2782
13	.3014	.362	.2911	.2381	.1562	.3073	.2833
14	.2641	.3605	.3299	.2363	.144	.2905	.234
15	.2801	.3742	.2995	.1052	.1318	.2435	.2309
16	.2961	.3552	.2622		.1364	.2435	.2381
17	.1196	.3378	.2424	.2485	.2662	.253	.2439
18	.0914	.3258	.2835	.257	.2781	.2567	.2404
19	.2553	.458	.41	.2454	.4466	.3843	.4336
20	.2759	.5083	.4725	.2774	.4931	.4802	.4634
21		.5041	.4466	.4683	.4525	.458	.4474
22		.4519	.4035	.4462	.4237	.405	.4374
23		.3799	.3603	.4222	.3628	.3565	.4039
24	.1698	.1799	.3117	.3178	.3109	.3334	.3208
Max	.4801	.5083	.4725	.471	.4931	.4802	.4756
Min	.0914	.1776	.2424	.1052	.1318	.2435	.2309
Avg	.3010	.3628	.3398	.3250	.2421	.3325	.3374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 203 / 11 KV SUKHWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171		.0181	.8962		1.004	.9922
2	.0171		.0179	.9069		1.0277	1.004
3	.0175		.0181	.9069		.9831	1.004
4	.0175		.0183	.8962		.9831	1.0159
5	.0177		.0183	.9172		1.004	1.0486
6	.0177		.0181	.9374		1.0688	1.1012
7	.0177		.0179	.9686		1.1203	1.1336
8	.0175		.0181	.016		.017	.0171
9	1.4754		.0183	.0162		.0175	1.3226
10	1.576		.0181	.0164		.0173	1.3763
11	1.5581	1.3123	.0179	.0164		.0173	1.4419
12	1.6095	1.2955	.0177	.0114		.0175	1.4586
13	1.5581	1.2803	.0177	.0145		.0177	1.4754
14	1.5424	1.4548	.0175	.0143		.0177	1.4754
15	1.5581	1.3443	.0175	.0143		.0175	1.3923
16	1.6095	1.2003	.0171			.0175	1.3748
17		.017	.0171	.0179	.0181	.0145	.0181
18		.0175	.0171	.0181	.0179	.0145	.0183
19		.0175	.0173	.0177	.0177	.0168	.0181
20		.0179	.0181		.0179	.0179	.0183
21		.0177	.0183	.0181	.0181	.0181	.0181
22		.0181	1.1142	1.1142	1.0883	1.1012	.0183
23		.0181	1.0688	1.1271	1.065	1.0688	.0181
24	.0175		.0179	1.0242	1.1065	1.0486	1.0242
Max	1.6095	1.4548	1.1142	1.1271	1.1065	1.1203	1.4754
Min	.0171	.017	.0171	.0114	.0177	.0145	.0171
Avg	.7438	.6163	.1073	.4494	.4187	.4437	.8244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 204 / 11 KV WASAGADE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5223		1.094	.1848		.2172	.2075
2	1.4723		1.0486	.1848		.2195	.1886
3	1.4723		1.0608	.2054		.1829	.1867
4	1.4548		1.0159	.2054		.181	.2054
5	1.4685		1.004	.2054		.2149	.2075
6	1.5623		1.1142	.2033		.2378	.2452
7	1.6762		1.1984	.2218		.2561	.2427
8	.2427		.2012	.2427		.2896	.2427
9	.2614		1.8084	1.8976		2.1872	.2218
10	.2402		1.9919	1.9608		2.234	.1867
11	.2561		1.8679	1.9845		2.2725	.2218
12	.2772	.1791	1.8679			2.2996	.2427
13	.2743	.2126	1.7814			2.3594	.2149
14	.2743	.1612	1.7814			.1311	.2195
15	.2743	.181	1.7368			1.3927	.2195
16	.2534	.1791	1.668			1.3765	.2534
17		.181	.2218	.2353	.2103	.2427	.2896
18		.197	.2427	.2195	.2328	.2427	.2743
19		.1991	.2452	.2715	.2481	.2427	.2534
20		.197	.2452		.2865	.2427	.2743
21		.1991	.2452	.3077	.298	.2427	.2715
22		1.1843	.2263	.2926		.2263	1.7204
23		1.1336	.1886	.2715	.2328	.2263	1.6575
24	1.7004		1.0814	.1867	.2561	.2534	.2075
Max	1.7004	1.1843	1.9919	1.9845	.298	2.3594	1.7204
Min	.2402	.1612	.1886	.1848	.2103	.1311	.1867
Avg	.8637	.3503	1.0391	.5156	.2521	.7488	.3523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 201 / 11 KV Tasgaon I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	1.0082	.9425	.9335		2.05	2.0343
2	.9808	.924	.924	.9335		1.9632	1.955
3		.8871	.8871	.9149		1.8805	1.9365
4		.8779	.9055	.8962		1.8595	1.8875
5		.924	.9149	.8962		1.8412	1.8875
6	1.0456	.9335	.9795	.9522		1.9365	1.9997
7	.9231	.9313	.8238	.8962		1.9318	1.9654
8		.8596	.8059	.8326	.8962	1.6987	1.7776
9	.905	.8238	.8238	.7964	.8842	1.7909	1.765
10	.9991	.7973	.9492	.8688	.3561	2.006	2.01
11	1.0745	.8145	1.0099		.4382	2.1428	2.079
12		.8859	.9568		.4908	2.079	2.1666
13	1.1218	.9036	1.0099		.4477	2.1666	2.1428
14		.9231	1.0387			2.1845	2.1596
15	1.1157	.9412	1.0679			2.2992	2.2679
16	1.1403	1.0099	1.1403		1.1584	2.4802	2.3606
17	1.0631	.964	1.0099				2.3966
18	.964	.9991	.964				2.162
19	1.2308	1.2536	1.1765		1.2357	1.4148	2.6749
20		1.3756	1.3491		2.7557	1.4266	2.9325
21		1.2986	1.2936		2.7328	1.3306	2.7568
22	1.2936	1.2752	1.2696		1.3413	1.3491	2.6532
23	1.2696	1.1576	1.1949		2.5431	1.2382	2.5666
24	1.0642	1.0642	.9795	1.0456	2.3771	2.3891	2.2923
Max	1.2936	1.3756	1.3491	1.0456	2.7557	2.4802	2.9325
Min	.905	.7973	.8059	.7964	.3561	1.2382	1.765
Avg	1.0726	.9930	1.0174	.9060	1.3583	1.8845	2.2012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 202 / 11 KV Tasgaon II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0136	.985	2.1003	1.1279	2.0004	2.2375
2		.9774	.9568	2.0237	1.0974	1.9021	2.111
3		.8954	.9214	1.945	1.0364	1.8256	2.0138
4		.9214	.9036	1.945	1.0059	1.7776	1.9957
5		.9313	1.8869	1.945	.9755	1.8046	1.973
6		.9671	2.0606	1.9652	1.0364	2.0301	2.1452
7	.9979	.9328	2.0704	2.0302	1.1279	1.9724	2.0889
8		.7701	1.7204	1.7383	1.7776	1.6204	1.7193
9	.7343	.7602	1.5013	1.6236	1.6013	1.4282	1.5347
10	.823	.7343	1.6194	1.5448	1.1839	1.4605	1.6546
11	.823	.8048	1.7341	.3353	1.0166	1.5528	1.6442
12		.8145	1.7558		1.4163	1.4861	1.9955
13	1.0751	.8596	1.8229		1.1522	.7011	1.9394
14		.9328	1.8995		.7011	.9522	1.9955
15	1.1203	.8688	1.9854		.7316	1.6541	2.0633
16	1.1016	.8962	1.9955		1.3599	2.1348	2.0343
17	1.0269	.8871	1.9464		.7011	1.0669	2.082
18	1.0751	.9808	2.0361		1.1279	1.9867	2.142
19	1.358	1.1883	2.5207	.9755	2.2668	.0305	2.5207
20		1.3957	2.946	1.4327	1.1888	3.4119	2.9344
21		1.3203	2.8401	1.6461	2.6354	3.261	2.8589
22	1.3769	1.307	2.6848	1.5546	1.3108	3.0258	2.66
23	1.2637	1.1949	2.5119	1.4632	2.3522	2.7341	2.4814
24	1.0679	1.0608	2.2205	2.3301	2.2672	2.3152	2.2857
Max	1.3769	1.3957	2.946	2.3301	2.6354	3.4119	2.9344
Min	.7343	.7343	.9036	.3353	.7011	.0305	1.5347
Avg	1.0649	.9756	1.8969	1.6823	1.3416	1.8390	2.1296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 203 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.5761	.7205	.69	.2743	.5877	.5572
2	.3048	.6035	.6679	.6714	.2743	.6409	.5877
3	.2743	.6409	.6679	.6714	.2743	.6409	.5572
4	.3048	.6409	.6679	.7019	.2743	.6409	.5572
5	.3353	.7289	.7354	.7697	.3048	.7087	.7354
6	.3658	.7844	.7884	.7884	.3353	.7579	.7392
7	.7926	.6792	.7659	.7697	.3963	.751	.7659
8	.3963	.6748	.7659	.7884	.7392	.7354	.7358
9	.7547	.6714	.6981	.6981	.7289	.7324	.6714
10	.7205	.7019	.6254	.5906	.634	.6714	.6527
11	.7019	.7205	.5689	.5949	.634	.6559	.4725
12	.3353	.5994	.5195	.5334	.55	.5334	.3976
13	.5239	.5384	.4306	.2134	.3597	.442	.6035
14	.1829	.4287	.3475	.1829	.1524	.3814	.6714
15	.5106	.3715	.508	.2439	.3048	.5572	.6714
16	.6222	.7049	.6222	.3048	.7087	.7087	.69
17	.6714	.7354	.6595	.3353	.3658	.3658	.7354
18	.7205	.7659	.4542	.3353	.3658	.508	.7205
19	.7205	.7205	.7884	.3658	.7392	.5994	.6937
20	.3658	.7205	.7392	.3963	.7169	.5645	.6299
21	.061	.6135	.7019	.3658	.7019	.4493	.4702
22	.0953	.4916	.6409	.3353	.3353	.4611	.5457
23	.5277	.6401	.4167	.2439	.5805	.6066	.55
24	.6066	.6487	.629	.6104	.5877	.5877	.5544
Max	.7926	.7844	.7884	.7884	.7392	.7579	.7659
Min	.061	.3715	.3475	.1829	.1524	.3658	.3976
Avg	.4666	.6417	.6304	.5084	.4724	.5953	.6236



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 204 / 11KV NEW TASGAON

INDUSTRIAL FE Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1631	.1585	.0915	.0381	.061	.1814
2	.1029	.0914	.1577	.0286		.0114	.1082
3	.1105	.0953	.1577	.0286			.0945
4	.1105	.1539	.1692	.0991	.0914		.141
5	.1067	.08	.2039	.1814	.0914	.0953	.1581
6	.1029	.1768	.1877	.1806	.0953	.1029	.2039
7	.2096	.1791	.1905	.2225	.0991	.1783	.201
8	.1181	.2004	.2515	.1753	.2361	.1821	.1886
9	.304	.3296	.3421	.2001	.3734	.3563	.3372
10	.3867	.4497	.4321	.1962	.4435	.4624	.3601
11	.461	.3856	.5167	.2039	.4915	.442	.402
12	.2629	.4001	.4946	.2616	.5434	.5205	.5777
13	.4706	.3281	.4858	.1334	.4443	.41	.4367
14	.2096	.3901	.4248	.1296	.2248	.4497	.4287
15	.4565	.4572	.5346	.1219	.2705	.474	.4172
16	.5575	.4058	.5311	.1181	.4172	.4607	.4549
17	.5537	.4321	.4625	.1372	.2248	.2401	.4794
18	.4763	.4344	.4816	.1181	.2477	.4327	.3647
19	.4115	.4095	.3597	.1334	.4458	.3719	.359
20	.2172	.3505	.2507	.1372	.2923	.3489	.2885
21	.0953	.2997	.2618	.1372	.2743	.3201	.2428
22	.2504	.2542	.2126	.1334	.141	.2088	.2339
23	.2035	.2389	.1973	.1181	.1817	.2277	.1867
24	.2058	.1867	.1738	.1334	.1265	.1273	.1654
Max	.5575	.4572	.5346	.2616	.5434	.5205	.5777
Min	.0953	.08	.1577	.0286	.0381	.0114	.0945
Avg	.2703	.2872	.3183	.1425	.2634	.2947	.2922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 205 / 11 KV NIMANI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2641	.2263			.2667
2			.2667	.2263			.2667
3			.2667	.2263			.2667
4		.2195	.2667	.2263			.2667
5		.2987	.3395	.3018			.3048
6		.3429	.3772	.3772			.3772
7	.1509	.3206	.3584	.3018			.3018
8		.2263	.2241	.2263	.2427	.2218	.2241
9	.2218	.2054	.2195	.2218	.1478	.2218	.1463
10	.1463	.1848	.1494	.1494		.197	.1463
11	.1463	.2218	.1463	.1494	.1478	.1463	.1463
12		.1867	.1463	.1646	.1463	.1646	.1478
13	.2218	.2218	.2218			.2195	.2195
14		.2218	.2218			.2241	.2241
15	.1463	.2402	.2218			.2241	.2241
16	.1478	.2218	.1478		.1478	.2218	.2241
17	.1478	.2218	.1494				.2149
18	.2172	.2172	.2195			.2149	.2126
19	.4066	.3511	.3696		.4435	.3292	.3658
20		.4481	.4435		.462	.4668	.4435
21		.4338	.4527		.4904	.415	.4481
22	.3772	.415	.3018			.3772	.3772
23	.3772	.3206	.3018		.3395	.3018	.3018
24	.3018	.3048	.2829	.2263	.3429	.2987	.2641
Max	.4066	.4481	.4527	.3772	.4904	.4668	.4481
Min	.1463	.1848	.1463	.1494	.1463	.1463	.1463
Avg	.2315	.2774	.2650	.2326	.2911	.2653	.2659

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 208 / 11 KV NIMANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.141	.1143	.1257	1.4822	1.7528	1.467	1.4365
2	.1372	.1143	.1257	1.4137	1.6499	1.3946	1.3603
3	.1334		.1257	1.3908	1.6004	1.2689	1.3222
4	.1334		.1219	1.3679	1.5585	1.2651	1.2917
5	.1334		.1181	1.3603	1.5203	1.2308	1.2612
6	.141		.1181	1.3717	1.4975	1.2536	1.2727
7	.1334		.1181	1.7147	1.7833	1.4784	1.3451
8	.1448		.1257	1.4365	1.1927	1.1736	1.0669
9	2.0805	1.5966	.1334	.1105	.1334	.1219	1.6309
10	2.5796	1.8861	.0991	.0762	.1105	.1143	2.0271
11	2.5225	2.0538	.0876	.0991	.1105	.1029	2.0538
12	2.5568	2.0995	.0838	.0914	.1105	.1029	1.9357
13	2.3091	2.0462	.1029		.0953	.1143	2.0576
14	2.3015	1.7147	.1105		.2286	.1181	2.1224
15	2.1681	1.7528	.1143		.0876	.0991	1.9852
16	2.1948	1.7718	.1067	.0533	.1257	.1181	2.0081
17	1.6956	1.246	.1181	.1448	.1296	.1219	1.4213
18	.1524	.1334	.1296	.1524	.141	.1334	.1257
19	.1562	.1448	.1296	.1524	.1562	.1562	.1219
20	.1753	.1638	.1562	.1715	.1753	.1753	.1562
21		.1715	.1715	.1638	.1753	.1753	.1715
22	.1448	.1715	1.4403	1.7223	1.1507	1.4975	.1715
23	.1372	.1524	1.5089	1.7871	1.5889	1.5394	.1524
24	.1181	.1296	1.5318	1.8633	1.5966	1.5165	.1372
Max	2.5796	2.0995	1.5318	1.8633	1.7833	1.5394	2.1224
Min	.1181	.1143	.0838	.0533	.0876	.0991	.1219
Avg	.9735	.9702	.2918	.8631	.7780	.6975	1.1931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 201 / 11 KV NIMANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5123	1.2018	1.3717	.1905	.1905	.1715	.1715
2		1.2003	1.358	.1715	.1905	.1524	.1524
3		1.1717	1.3757	.1715	.1715	.1524	.1524
4		1.2498	1.326	.1715	.1715	.1715	.1715
5		1.3283	1.3748	.1905	.1905	.1905	.1905
6		1.4548	1.3889	.2096	.2096	.2286	.2286
7		1.6842	1.4685	.2096	.2096	.2286	.2096
8		.1905	.1905	.2286	.1905	.1715	.1905
9		.1524	2.0466	2.1925	2.5617	2.1872	.1905
10		.1524	1.9925		2.6086	2.3245	.2286
11		.1524	1.9204		2.372	2.2929	.2096
12		.1524	1.9766		2.1914		.1334
13		.1524	1.7654		2.0466	1.7604	.1905
14			1.8404		2.0399	2.1348	.1524
15		.1524	1.7711		1.9685	2.2297	.1715
16	.1905	.1524	1.7394		1.8442	2.1605	.1715
17	.1905	.1524		.4191	.1905		.1905
18	.1905	.1905			.2096	.1715	.2286
19	.2286	.2096	.2096	.2477	.2096	.2096	.2477
20	.2477	.2477	.2286	.2667	.2477	.2477	.2667
21	.1715	.2477	.2096	.2286	.2286	.2096	.2477
22	1.4723	1.7553	.2096	.2286	.2096	.2096	2.0965
23	1.4251	1.5154	.2096	.1905	.1905	.1905	2.0557
24	1.5432	1.2631	1.439	.1905	.1905	.1905	.1715
Max	1.5432	1.7553	2.0466	2.1925	2.6086	2.3245	2.0965
Min	.1715	.1524	.1905	.1715	.1715	.1524	.1334
Avg	.7172	.7013	1.2460	.3442	.8681	.8175	.3508

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 202 / 11 KV TURACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0572	.8592	.9259	.7716	.6706
2	.0762	.0572	.0572	.8488	.9488	.759	.6327
3	.0762	.0572	.0572	.8333	.9259	.759	.6401
4	.0572	.0572	.0572	.8436	.9282	.7432	.6401
5	.0572	.0762	.0762	.8697	.9945	.7499	.6401
6	.0572	.0953	.1143	.8697	.9414	.7621	.7343
7	.0572	.0953	.1143	.9217	.9646	.8855	.7907
8	.0572	.0953	.1143	.0953	.0572	.0953	.0762
9	1.0774	.9259	.0953	.0953	.0762	.0953	.8951
10	1.0185	1.0155	.0762		.0762	.0762	1.0494
11	1.0311	.9755	.0762		.0762	.0762	1.0155
12	1.0595	.8124	.0572		.0953	.0762	.9061
13	1.0311	.9602	.0572		.0953	.0762	.9374
14	1.0467	.933	.0572		.0953	.0762	.9105
15	1.034	.9374			.0953	.0762	.9374
16	1.0155	.9686	.0572		.1143	.0953	.9374
17		.0953	.0762				.0762
18		.0953	.0762		.1143	.0953	.0953
19	.0953	.0953	.0953		.1143	.1143	.0953
20	.0953	.0953	.0953		.1143	.0953	.0953
21	.0953	.0953	.0953		.1143	.0953	.0953
22	.0762	.0953	.8642		.8592	.7811	.0762
23	.0762	.0572	.8642		.8436	.7716	.0762
24	.0572	.0572	.0572	.8592	.9646	.7926	.7621
Max	1.0774	1.0155	.8642	.9217	.9945	.8855	1.0494
Min	.0572	.0572	.0572	.0953	.0572	.0762	.0762
Avg	.4238	.3669	.1456	.7096	.4581	.3878	.5744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 203 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4294	.4191	.4572	.3988	.4191	.4294
2	.3121	.4191	.4191	.4382	.4031	.4001	.415
3	.3045	.4191	.3961	.4191	.3544	.381	.3961
4	.3366	.4382	.4191	.4191	.3658	.3734	.415
5	.439	.4763	.4382	.4572	.4435	.4251	.4668
6	.4706	.6097	.5335	.5906	.4854	.5335	.5847
7	.5895	.6668	.6097	.6478	.6036	.6283	.6099
8	.4382	.4706	.4668	.5144	.4508	.4344	.4572
9	.3898	.4298	.3801	.3982	.394	.3721	.3761
10	.3761	.3856	.4024		.394	.3681	.4382
11	.3601	.3856	.4477		.394	.3544	.4207
12	.4207	.3582	.4031		.3721	.4075	.4075
13	.4477	.3641	.4207		.4075	.4075	.4119
14	.4656	.3898	.3944		.4344	.4207	.4119
15	.4706	.3898			.4252	.4382	.394
16	.499	.4163	.4656		.4298	.394	.3721
17	.4572	.4207	.4755		.4252		.4119
18	.3761	.4298	.5068		.4706	.4656	.4477
19	.543	.543	.6099		.6161	.6287	.567
20	.7207	.6767	.6283		.7023	.7621	.7207
21	.5601	.6535			.6283	.6668	.6283
22	.5175	.5847	.567		.5975		.5415
23	.4668	.4954	.5175		.5281	.499	.4805
24	.4298	.4251	.4572	.4435	.4298	.4763	.462
Max	.7207	.6767	.6283	.6478	.7023	.7621	.7207
Min	.3045	.3582	.3801	.3982	.3544	.3544	.3721
Avg	.4485	.4699	.4717	.4785	.4648	.4662	.4694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi ( Malwadi )

Feeder No / Name : 201 / 11 KV MALWADI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0977	.104	.061	.0914	.1406	.1189	.0838
2	.0869	.0894	.061	.0914	.1189	.1021	.0762
3	.0793	.0894	.0503	.0914	.1189	.0894	.0854
4	.0693	.0827	.0503	.0914	.1097	.0667	.0854
5	.076	.06	.0762	.0914	.1097	.044	.0854
6	.0894	.0667	.0762	.0914	.0894	.0747	.1021
7	.0894	.0762	.0838	.0914	.0894	.08	.1021
8	.0857	.0667	.0838	.1372	.1143	.0762	.1524
9	.1021	.1715	.1524	.1372	.1715	.1715	.1905
10	.1406	.2286	.1715	.0838	.1905	.2096	.2328
11	.1739	.2286	.2058	.0838	.2096	.2096	.2572
12	.1949	.2858	.2401		.2477	.2477	.2915
13	.2858	.3077	.2229		.2686	.2667	.2915
14	.2686	.2686	.2058		.3048	.2328	.2401
15	.2667	.2096	.2058		.2477	.2667	.2401
16	.2477	.2096	.1886		.2286	.2096	.2229
17	.1905	.2096	.1715		.2096	.1905	.2058
18	.1905	.1905	.1715		.1715	.1715	.1543
19	.1905	.1524	.1543	.0457	.1715	.1715	.1372
20	.1905	.1524	.1543		.1524	.1524	.1372
21	.1715	.1524	.1715		.1524	.0838	.1372
22	.0667	.0914	.1715	.0914	.0838	.1562	.1372
23	.1149	.1406	.1543		.1562	.1581	.1372
24	.1149	.1143	.0914	.1543		.1562	.1252
Max	.2858	.3077	.2401	.1543	.3048	.2667	.2915
Min	.0667	.06	.0503	.0457	.0838	.044	.0762
Avg	.1493	.1562	.1407	.0981	.1677	.1544	.1629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi ( Malwadi )

Feeder No / Name : 203 / 11 KV MALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0953	.1143	.7621	.8025	.8025	.5487
2	.1334	.0953	.1143	.7621	.7716	.7676	.5155
3	.1334	.0953	.1143	.7621	.7716	.7499	.463
4	.1524	.1143	.1334	.7621	.7716	.7042	.463
5	.1905	.1143	.1524	.7621	.8124	.6944	.4744
6	.2096	.1334	.1715	.7621	.8592	.6958	.5117
7	.1905	.1334	.1905	.7621	.8592	.9282	.6401
8	.1524	.1143	.1905	.12	.1143	.1334	.1143
9	1.5223	1.0235	.1334	.0857	.1334	.0953	1.2955
10	1.5844	1.2029	.1029	.1143	.1524	.1524	1.3592
11	1.4403	1.1544	.12	.1143	.1524	.1715	1.5775
12	1.2346	1.0802	.12		.1715	.1715	1.5775
13	1.2967	.9877	.12		.1715	.1524	1.3546
14	1.1111	.9414	.1372		.1715	.1524	1.3375
15	1.0059	.9259	.1372		.1524	.1524	1.2003
16	.9831	.8128	.12		.1334	.1905	1.0802
17	.1334	.1143			.1524	.1905	.12
18	.1334	.1143	.1372		.1524	.1524	.12
19	.1715	.1334	.1543		.1524	.1715	
20	.1524	.1715			.1715	.1905	
21	.1715	.1524	.1715		.1715	.1715	
22	.1143	.1524	1.0288	.9414	.9922	.7335	.1372
23	.1143	.1334	.8573		.8796	.6539	.1543
24	.1334	.1524	.1334	.8573		.8642	.6171
Max	1.5844	1.2029	1.0288	.9414	.9922	.9282	1.5775
Min	.1143	.0953	.1029	.0857	.1143	.0953	.1143
Avg	.5249	.4229	.2116	.5821	.4206	.4101	.7458



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 201 / 11 KV ARWADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2652	1.6575			1.7072
2			.2652	1.5912			1.6244
3			.2652	1.5581			1.6244
4			.2652	1.5912			1.5912
5			.2984	1.6244			1.5912
6			.2984	1.9559			1.8896
7	.2267	.2105	.3149	2.1879			2.3205
8	.2374	.1619	.2984	.2622	.2984	.1423	.3149
9	2.7778	1.5249	.1638	.2321	.2785	.1326	2.6216
10	2.9007	1.6575	.1966	.2155		.1989	
11	2.9835	2.0885	.1311				2.6543
12		2.0056	.1638		.2753	.3149	2.4905
13	2.652	1.5912	.1326		.2372	.2984	2.7846
14		2.0719	.1326			.2652	2.7515
15	2.6852	1.989	.0995			.2984	2.8178
16	2.4577	2.0719	.1311			.2652	2.8509
17	.2561	.2321	.1311				.2984
18	.3041	.2155	.2622			.3647	.2949
19		.2652				.3812	.0328
20		.3647	.1638		.1875	.431	.3277
21		.3481	.1311			.431	.3605
22	.1658	.2984	1.989			2.1548	.3315
23	.1619	.2818	1.989		1.0688	2.0553	.2652
24	.2267	.16		1.757	1.757	1.0242	1.7238
Max	2.9835	2.0885	1.989	2.1879	1.757	2.1548	2.8509
Min	.1619	.16	.0995	.2155	.1875	.1326	.0328
Avg	1.3874	.9744	.3676	1.3303	.5861	.5839	1.5335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 204 / 11 KV DHAVLI Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.1506	.0503			.0619
2			1.9509	.0503			.0549
3			1.9204	.0503			.0572
4			1.9204	.0503			.0549
5			1.9444	.0503			.0549
6			2.0622	.0533			.06
7	2.4966	2.5606	2.3087	.08		.0613	.0594
8	.0591	.0819	.0857	.0667	.1067	.1006	.104
9		.064	2.915	3.1093	3.0664	2.9127	.0457
10	.0396	.0629	2.6882	2.9127		3.1367	.0572
11	.0457	.0549	2.753	2.8487			.0819
12		.0572	2.0165		3.1493	3.0727	.0229
13	.0591	.0686	2.2455		3.0476	2.9447	.0286
14		.0566	2.4326			2.9127	.0343
15	.0572	.0566	2.7206			2.8807	.0286
16	.0724	.0533	2.4996		2.6246	2.9447	.0629
17	.0781	.1006	.0164				.096
18	.1006	.1006	.1143			.4012	.1147
19	.088	.0827	.0907			.1086	.1166
20		.0886	.0914		.0914	.1063	.1029
21		.0857	.0914			.105	.0823
22	2.0309	2.372	.0686			.0587	2.9729
23	2.0557	2.4036	.0457		.0663	.057	2.9127
24	2.6246	2.0557	2.2497	.0457	.0613	.0709	.0644
Max	2.6246	2.5606	2.915	3.1093	3.1493	3.1367	2.9729
Min	.0396	.0533	.0164	.0457	.0613	.057	.0229
Avg	.7544	.5781	1.5576	.7807	1.5267	1.3672	.3055

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 401 / 33KV Hatnoor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	16.2918	15.1098	15.794	15.9774	16.3604	15.2469	16.4677
2	15.7031	14.4125	15.4064	14.8937	15.5407	14.7325	15.3275
3	15.2572	14.0604	14.8715	14.5062	15.1634	14.2662	14.7445
4	15.1098	13.7518	14.8594	14.4033	14.8149	14.0261	14.5628
5	15.3361	14.1049	14.8577	14.2319	10.8368	13.8786	14.9383
6	16.3957	14.2753	15.7922	14.7325	15.0172	13.9815	15.5464
7	16.3238	14.3827	16.2638	14.952	12.0371	13.5277	15.7853
8	13.9369	12.6864	13.9483	13.1722	13.9284	13.4123	13.4717
9	13.5357	12.5103	13.4911	12.2719	13.7334	12.8738	12.7298
10	14.481	12.6818	13.8443	12.5669	12.9973	13.6054	13.7175
11	15.072	14.7102	15.6002	8.2922	11.6826	13.331	14.3255
12	10.3567	16.0391	16.3638	6.7707	12.4554	15.6791	15.8413
13	16.8702	14.9269	16.3215	5.0069	11.0769	14.4833	16.3215
14	12.4829	14.9726	15.6962	4.6639	11.2483	14.3713	16.669
15	16.8439	15.2469	16.6438	4.8011	11.797	15.79	17.2109
16	17.3731	16.8244	16.1706	4.6639	14.5999	17.4086	16.9868
17	16.9891	16.4404	15.7522	4.5953	14.5519	13.1344	17.5378
18	16.6724	16.7341	15.6219	4.5953	16.6392	13.2888	16.9273
19	15.9237	17.947	17.7183	11.8999	16.8153	13.7906	17.7069
20	14.6434	20.6751	20.8848	14.9863	17.5983	21.1266	19.9223
21	1.6461	19.9783	20.4116	15.2949	19.5199	19.8445	19.3896
22	13.7975	18.5769	19.0466	15.2264	14.7462	18.9529	18.8169
23	16.7033	17.915	17.9389	14.4033	17.8498	19.0107	18.0899
24	16.2037	16.6507	16.9359	17.3011	16.7558	17.7366	12.9657
Max	17.3731	20.6751	20.8848	17.3011	19.5199	21.1266	19.9223
Min	1.6461	12.5103	13.4911	4.5953	10.8368	12.8738	12.7298
Avg	14.7479	15.6506	16.2598	11.4254	14.4903	15.3125	16.0835

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 406 / 33 KV Sut Girani

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	1.6004
Max	1.6004
Min	1.6004
Avg	1.6004

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 407 / 33kv punadi LIS

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-APR-17
HR	Load (MW)
24	1.7353
Max	1.7353
Min	1.7353
Avg	1.7353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 201 / 11 KV Kasabe Digraj

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.4527	.4527	.4338	.4527	.4715	.4527
2	.5093	.4527	.4338	.4338	.4338	.4715	.4527
3	.5093	.4527	.4338	.4338	.4338	.4715	.4527
4	.5093	.4527	.4338	.4338	.4338	.4904	.4715
5	.5093	.4904	.4715	.4338	.4904	.4904	.4904
6	.5658	.547	.4904	.4715	.4904	.4904	.4715
7	.4715	.4338	.4338	.3772	.4338	.4338	.415
8	.3961	.3961	.415	.3961	.3772	.3772	.415
9	.4527	.415	.3772	.3772	.4715	.6401	.6099
10	.4715	.547	.6224	.4527	.6653	.6036	.7023
11	.547	.6653	.6036	.6413	.6838	.4251	.6653
12	.5658	.7577	.5093	.4338	.6838	.5914	.6099
13	.6036	.6283	.5093	.5175	.6838	.6838	.6099
14	.6413	.6653	.5359	.6468	.6838	.6653	.6283
15	.811	.7947	.695		.5544	.6344	.6838
16	.7922	.6283	.695		.7392	.5228	.6653
17	.7095	.6283	.7207		.5093	.7468	.6468
18	.695	.5359	.6161		.6036	.6348	.7023
19	.7842	.8215	.8029		.6224	.5788	.7468
20	.9709	.8029	.8589		.6602	.7282	.6722
21	.5415	.6036	.5601		.5847	.6224	.5975
22	.811	.5847	.5788		.5658	.5847	.5847
23	.547	.5281	.5093	.4904	.5281	.5281	.5093
24	.7167	.4715	.4527	.4715	.4715	.4715	.4527
Max	.9709	.8215	.8589	.6468	.7392	.7468	.7468
Min	.3961	.3961	.3772	.3772	.3772	.3772	.415
Avg	.6100	.5732	.5505	.4653	.5524	.5566	.5712

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5596	.4527	.6173				
2	.5596	.4527	.6173				
3	.5596	.4527	.6173				
4	.5596	.4527	.6173				
5	.5596	.4578	.6516				
6	.6001	.4973	.6516				
7	.583	.5144	.6687				
9			.7802	.763	1.8176	.8745	
10			.9536	.8309	1.9204	.8573	
11			.9362	.8402	1.8862	.8745	
12			.9536		.9431	.8745	
13			.9362		.9088	.9259	
14			.9015		.9259	.8916	
15			.9015		.9259	.8916	
16			.7975	.6952	.8745	.7888	
22	.463	.6173					.6173
23	.463	.6173					.6001
24	.5596	.463	.6173				
Max	.6001	.6173	.9536	.8402	1.9204	.9259	.6173
Min	.463	.4527	.6173	.6952	.8745	.7888	.6001
Avg	.5467	.4978	.7637	.7823	1.2753	.8723	.6087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 203 / 11 KV TUNG VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.1698	.1698	.1886	.1886	.1886
2	.1698	.1698	.1698	.1698	.1886	.1886	.1886
3	.1698	.1698	.1698	.1698	.1886	.1886	.1886
4	.1698	.1698	.1698	.1698	.1886	.2075	.1886
5	.3395	.1886	.2641	.1886	.2263	.2452	.2075
6	.3395	.2829	.3018	.2829	.2829	.3395	.3206
7	.3018	.2641	.2829	.2452	.2641	.2829	.2641
8	.2641	.2641	.2263	.1886	.2263	.2263	.2452
9	.2263	.2452	.2149	.2452	.2641	.2263	.2641
10	.2452	.2452	.2507	.2452	.2641	.2641	.3018
11	.2263	.1886	.1753	.2075	.2452	.2075	.2641
12	.2641	.2263	.2328	.2641	.2263	.2075	.2452
13	.2452	.2263	.2328	.2012	.2263	.2263	.2075
14	.2452	.2075	.2075	.2058	.2075	.2452	.2263
15	.2263	.2452	.1886		.2263	.1509	.2075
16	.2263	.1509	.2075		.2075	.132	.2263
17	.2267	.2263	.2641		.2641	.2374	.2452
18	.2458	.2452	.2452		.2641	.2241	.2641
19	.2896	.3018	.3395		.3018	.3155	.3206
20	.3292	.3395	.3584		.3584	.3475	.3961
21	.3109	.3206	.3206		.3395	.3109	.3584
22	.2829	.3018	.3018		.3206	.3206	.3206
23	.2452	.2641	.2452	.2641	.3395	.2829	.2829
24	.1886	.1886	.1698	.1698	.2075	.3395	.2075
Max	.3395	.3395	.3584	.2829	.3584	.3475	.3961
Min	.1698	.1509	.1698	.1698	.1886	.132	.1886
Avg	.2478	.2334	.2379	.2117	.2507	.2461	.2554



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 205 / 11 KV TUNG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1961	.8907	1.153				
2	1.1961	.852	1.153				
3	1.1961	.852	1.0852				
4	1.1961	.852	1.0174				
5	1.1961	.852	1.0174				
6	1.1961	.9717	.9835				
7	1.2452	1.085	1.0343				
9			1.4419	1.5402	2.1195	1.7465	
10			1.2597	1.6385	2.0856	1.7126	
11			1.5581	1.5729	2.0178	1.933	
12			1.5581		1.9161	1.8313	
13			1.5912		1.8482	1.7804	
14			1.3927		1.7804	1.7295	
15			1.3603		1.7804	1.7126	
16			1.4091		1.6956	1.7635	
22	.9717	1.2209					1.5939
23	1.0202	1.1869					1.4419
24	1.5382	.9282	1.17				
Max	1.5382	1.2209	1.5912	1.6385	2.1195	1.933	1.5939
Min	.9717	.852	.9835	1.5402	1.6956	1.7126	1.4419
Avg	1.1952	.9691	1.2616	1.5839	1.9055	1.7762	1.5179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 206 / 11 KV Vasant LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3018	.2452	.1698	.2263	.3395
2	.2829	.3018	.2452	.1698	.2263	.3395
3	.2829	.3018	.2452	.1698	.2263	.3395
4	.2829	.3018	.2452	.2075	.2263	.3395
5	.2829	.3018	.2452	.2075	.2263	.3395
6	.3395	.3395	.2452	.3395	.2641	.3395
7	.415	.3395	.2641	.3206	.3018	.3206
8	.4338	.2452	.2829	.3206	.3018	.3206
9	.5093	.2829	.3772	.3772	.3018	.3772
10	.5093	.3018	.3772	.3772	.3206	.3772
11	.4904	.3395	.3772	1.0374	.3395	.3772
12	.4715	.3395	.3772	.3395	.3395	.3772
13	.415	.3395	.3772	.3395	.3395	.3772
14	.3772	.3395	.3584	.3395	.3584	.3772
15	.3772	.3395	.3584	.3395	.3395	.3772
16	.3772	.3395	.3772	.3395	.3772	.3772
Max	.5093	.3395	.3772	1.0374	.3772	.3772
Min	.2829	.2452	.2452	.1698	.2263	.3206
Avg	.3831	.3159	.3124	.3372	.2947	.3560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 202 / 11 KV KAVALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1574	.1673	.1642	.1703	.1616	.1402	.1467
2	.157	.1677	.157	.16	.152	.1383	.1387
3	.157	.1612	.1539	.157	.1562	.1425	.1364
4	.1547	.16	.1528	.1562	.1456	.1395	.1391
5	.1513	.1547	.1425	.1517	.152	.133	.1357
6	.1795	.1669	.1619	.1452	.1524	.1372	.1368
7	.1825	.1867	.1749	.1677	.1909	.1772	.1513
8	.1486	.1844	.1791	.1802	.1859	.165	.152
9	.1265	.1749	.1478	.157	.1417	.1242	.1216
10	.1395	.1543	.1547	.141	.0819	.1406	.096
11	.1558	.1661	.1661	.1501	.0945	.1715	.0995
12	.141	.1787	.1814	.1509	.0907	.1829	.1078
13	.1151	.1814	.1985	.1017	.112	.1722	.1075
14	.1494	.1734	.1951	.0922	.1128	.1147	.1158
15	.1517	.1044	.1109	.1006	.1075	.1029	.1059
16	.1482	.1082	.093	.0968	.1063	.096	.1021
17	.1326	.1059	.1608	.093	.0995	.1395	.0991
18	.1113	.1075	.1871	.0972	.1276	.1444	.0808
19	.1646	.0949	.1715	.1669	.1456	.1814	.0937
20	.2187	.1814	.2324	.2248	.2176	.1951	.1246
21		.2138	.2282	.2145	.2103	.2122	.1871
22	.1478	.2065	.2187	.2084	.1962	.2035	.1718
23	.2039	.2134	.2023	.208	.1787	.141	.1654
24	.1837	.1829	.1703	.1749	.1593	.1627	.144
Max	.2187	.2138	.2324	.2248	.2176	.2122	.1871
Min	.1113	.0949	.093	.0922	.0819	.096	.0808
Avg	.1556	.1624	.1710	.1528	.1450	.1524	.1275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 205 / 11 KV Kavalapur Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9995	.6523	.8524	.1852	.1688	.1497	.1658
2	.9564	.6375	.8078	.1753	.168	.149	.1612
3	.916	.6546	.7884	.1741	.1677	.1425	.1612
4	.9137	.6847	.7903	.1718	.1566	.1379	.1612
5	.9701	.7019	.8169	.1791	.1482	.1379	.136
6	1.1927	.8459	.9343	.1955	.1741	.1688	.1703
7	1.4883	1.1142	1.0833	.2157	.1772	.192	.1741
8	.2176	.2077	.2709	.3178	.2976	.1757	.184
9	.1753	.1879	1.3146	1.5337	1.6171	1.6716	.1543
10	.1818	.1528	1.2734	1.5604	1.8278	1.7787	.1437
11	.141	.1315	1.3413	1.5947	1.8393	1.7215	.1425
12	.1067	.1417	1.1789	.3456	1.7551	1.7741	.144
13	.1376	.1406	1.3058	.1391	1.5539	1.6671	.16
14	.1501	.1456	1.3207	.1909	1.4529	1.52	.1505
15	.1593	.1494	1.302	.1856	1.4956	1.4392	.1227
16	.1562	.1326	1.4666	.7735	1.5466	1.4933	.1208
17	.1345	.1524	.149	.1475	.149	.1105	.1368
18	.1772	.1558	.2065	.2	.1734	.1276	.1444
19	.1718	.1989	.25	.2134	.2126	.1856	.1905
20	.2084	.2427	.3006	.2401	.2301	.245	.2244
21	.3071	.3304	.2858	.2244	.2244	.2301	.3045
22	.7766	.9587	.2458	.2084	.2046	.213	1.2106
23	.7651	.9187	.2145	.1959	.1753	.1844	1.2136
24	.6466	.8848	.1939	.1734	.1566	.1688	1.0414
Max	1.4883	1.1142	1.4666	1.5947	1.8393	1.7787	1.2136
Min	.1067	.1315	.149	.1391	.1482	.1105	.1208
Avg	.5021	.4385	.7789	.3975	.6697	.6577	.2883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 201 / 11 KV Mouje Digraj

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0158	.0274	.0168	.0019	.0191	.0191	.0191
2	.0158	.0282	.0168	.0019	.0191	.0191	.0191
3	.0158	.0282	.0168	.0019	.0191	.0191	.0191
4	.0158	.029	.0168	.0019	.0191	.0191	.0191
5	.0158	.029	.0168	.0019	.0191	.0191	.0191
6	.016	.029	.0168	.0019	.0191	.0191	.0191
7	.0141	.0286	.0168	.0019	.0191	.0191	.0191
8	.0191	.0191	.0191	.0019	.0191	.0191	.0191
9	.0191				.0328	.0339	.0191
10	.0191	.0191	.0312		.0328	.0324	.0191
11	.0191	.0191	.0474		.0339	.032	.0191
12	.0191	.0191	.0474		.0339	.032	.0191
13	.0191	.0191	.0474		.0343	.0316	.0191
14	.0191	.0191	.0474		.0343	.0316	.0191
15	.0191	.0191	.0474		.0347	.0316	.0191
16	.0191	.0191	.0474		.0347	.0316	.0191
17	.0191	.0191	.0019		.0191	.0019	.0191
18	.0191	.0191			.0191	.0019	.0191
19	.0191	.0191	.0019		.0191	.0191	.0191
20	.0191	.0191	.0019		.0191	.0191	.0191
21	.0191	.0191	.0019		.0191	.0191	.0191
22	.0274	.0164	.0019		.0191	.0191	
23	.0274	.0164	.0019		.0191	.0191	
24	.0162		.0168	.0019	.0191		.0191
Max	.0274	.029	.0474	.0019	.0347	.0339	.0191
Min	.0141	.0164	.0019	.0019	.0191	.0019	.0191
Avg	.0186	.0218	.0218	.0019	.0240	.0221	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 203 / 11 kv PWW Bramhnal

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4036	.3831	.5006	.3646	.4932	.3559	.362
2	.3978	.3981	.4997	.3659	.4926	.3575	.3647
3	.398	.4016	.493	.3656	.4917	.3566	.365
4	.3973	.4015	.4935	.3648	.4916	.442	.5414
5	.4448	.4551	.4929	.3651	.4918	.4584	.5412
6	.4854	.4557	.4942	.4485	.4936	.4808	.5425
7	.5278	.4735	.4968	.461	.4996	.484	.5445
8	.5474	.3307	.4937	.4668	.5078	.5317	.5203
9	.4658	.4343	.1997	.2124	.5305	.6019	.5358
10	.4658	.4988	.3296	.2157	.4502	.3858	.5077
11	.3675	.5176	.1423		.3309	.1543	.428
12	.2658	.4016	.0867		.2303	.0857	.34
13	.2328	.4614	.0867	.0111	.1772	.0857	.31
14	.2328	.2754	.0857	.012	.1772	.0857	.3086
15	.0526	.08	.0893	.0116	.181	.0857	.1734
16	.0526	.08	.0857	.0109	.181	.0857	.1734
17	.0154	.0817	.087	.001	.186	.0407	
18	.2764	.0625	.0838	.0101	.1829	.0949	.208
19	.2767	.0474	.1341	.0106	.2881	.0838	.208
20	.2767	.2214	.2686	.0006	.4084	.2155	.208
21	.3763	.3077	.2694		.4083	.2155	.2902
22	.317	.4668	.2893	.2076	.356	.4077	.4119
23	.2395	.3792	.3698	.2052	.3606	.4072	.4122
24	.4038	.2026	.3684	.3702	.3588	.2008	.416
Max	.5474	.5176	.5006	.4668	.5305	.6019	.5445
Min	.0154	.0474	.0838	.0006	.1772	.0407	.1734
Avg	.3300	.3257	.2892	.2134	.3654	.2793	.3788

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 204 / 11 KV Express LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3174	.3045	.3326	.3142	.3018
2	.2987	.3174	.3045	.3326	.3142	.3018
3	.2987	.3361	.3045	.3326	.3326	.3018
4	.2987	.3361	.3045	.3326	.3361	.3018
5	.2987	.3361	.3045	.3326	.3361	.3018
6	.2987	.3361	.3045	.3326	.3361	.3018
7	.2987	.3361	.3045	.3326	.3361	.3018
8	.3361	.2801	.3045	.3361	.3361	.3018
9	.3361	.3361		.3361	.3361	.3018
10	.3361	.3361	.3361	.3361	.3361	.3395
11	.3361	.3361	.3361	.3361	.3361	.3395
12	.3361	.3326	.3361	.3361	.3361	.3395
13	.3361	.3142	.3361	.3361	.3361	.3395
14	.3361	.3142	.3361	.3361	.3361	.3361
15	.3361	.3142	.3361	.3361	.3361	.3361
16	.3361	.2328	.3361	.3361	.3361	.3361
Max	.3361	.3361	.3361	.3361	.3361	.3395
Min	.2987	.2328	.3045	.3326	.3142	.3018
Avg	.3197	.3195	.3192	.3346	.3331	.3177

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 205 / 11 KV Yeshwant Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2403	1.1862	2.4467		2.229	2.4673	2.3864
2	2.2632	1.1961	2.4482		2.2839	2.4692	2.391
3	2.2681	1.2144	2.4086		2.2881	2.4804	2.3868
4	2.2654	1.2106	2.4017		2.2877	2.4931	2.3834
5	2.2839	1.211	2.4094		2.2896	2.5015	2.3853
6	2.2961	1.246	2.4238		2.3091	2.6884	2.6429
7	.8379	2.0812	2.4551		2.5244	2.7282	2.638
8	2.4768	1.691	2.2017		2.638	2.8715	2.5884
9	2.4734	2.3628	.775		2.6821	2.886	2.8422
10	2.4486	2.5827	2.1616		2.6646	2.7675	2.7744
11	2.4128	2.5793	2.0027		2.6722	2.7613	2.7816
12	2.4207	2.0248	2.4615		2.6585	2.7731	2.7892
13	2.4211	2.2333	2.4851		2.6947	2.7574	2.8174
14	2.4097	2.3529	2.4947		2.6936	2.8031	2.8139
15	2.2992	2.3339	2.4974		2.676	2.769	2.7915
16	2.3019	2.0176	2.1952		2.6738	2.3948	2.7937
24	.072	.0922		.109	.0739	.0975	.1707
Max	2.4768	2.5827	2.4974	.109	2.6947	2.886	2.8422
Min	.072	.0922	.775	.109	.0739	.0975	.1707
Avg	2.1289	1.7421	2.2668	.109	2.3729	2.5123	2.4928



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 206 / 11 KV NAWARASWADI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.0838	.1957	.3189	.298	.3045
2	.2012	.0838	.1957	.3189	.298	.3045
3	.2012	.0838	.1957	.3189	.298	.3045
4	.2012	.0838	.1957	.3189	.3189	.3045
5	.1844	.1017	.1957	.3189	.3189	.3045
6	.1753	.1017	.1957	.3189	.3189	.3045
7	.1907	.3012	.1957	.3189	.3012	.3045
8	.1865	.1357	.1806	.3189	.3224	.3045
9	.1865	.1844		.3189	.2454	.3045
10	.1715	.2126	.3086	.3189	.2058	.4525
11	.1715		.3086	.3189	.2058	.4525
12	.1715	.2126	.3086	.3189	.2058	.4525
13	.1734	.2012	.3086	.3395	.3086	.4572
14	.1734	.2012	.3086	.3189	.3086	.4572
15	.208	.2012	.3086	.2328	.3086	.4668
16	.208	.1806	.3086	.2328	.3086	.4668
Max	.208	.3012	.3086	.3395	.3224	.4668
Min	.1715	.0838	.1806	.2328	.2058	.3045
Avg	.1878	.1580	.2474	.3094	.2857	.3716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244037 / 33/11 KV PRAKASH AGRO

Feeder No / Name : 201 / 11 KV Haripur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0373	.0377	1.004	1.065	.9555	.8802
2	.0377	.0377	.0377	.9602	1.065	.9555	.8802
3	.0377	.0377	.0377	.9442	1.0526	.9555	.9069
4	.0377	.0377	.0377	.9172	1.0364	.9555	.9175
5	.0377	.0377	.0377	.9014	1.0364	.9555	.9012
6	.0377	.0377	.0377	.9282	1.094	.9555	.9175
7	.0377		.0377	.9646		.9488	.9779
8	.0377				.0152	.0189	.0377
9	1.3599	1.3279	.0189		.0189	.0189	1.1768
10	1.4918	1.3757	.0189	.0179	.0377	.0189	1.2323
11	1.6095	1.4255	.0377	.0177	.0377	.0189	1.1227
12	1.5729	1.4089	.0189		.0377	.0189	1.1544
13	1.5249	1.3763	.0187		.0377	.0189	1.278
14	1.5074	1.3426	.0373		.0189	.0189	1.2616
15	1.5424	1.3094	.0189		.0189	.0189	1.2125
16	1.5089	1.278	.0187		.0377	.0189	1.1797
17	.0154	.0189	.0324		.0377	.0189	.037
18	.016	.0377	.0145		.0377	.0189	.0354
19	.0366	.0377	.0362		.0377	.0189	.0351
20	.0362	.0377	.0366		.0377	.0189	.0549
21	.0362	.0377	.0362		.0377	.0189	.0377
22	.0189	.0377	.9762		1.1317	.7926	.0377
23	.0189	.0377	.9762		1.004	.8642	.0566
24	.0377	.0373	.0377	.9686	1.1736	1.004	.8855
Max	1.6095	1.4255	.9762	1.004	1.1736	1.004	1.278
Min	.0154	.0189	.0145	.0177	.0152	.0189	.0351
Avg	.5265	.5160	.1130	.7624	.4395	.4003	.7174

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 201 / 11 kv Dudhgaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	2.1909	1.8389	2.0271	2.4928
2	.0171	.0171	.0171	2.1353	1.7947	1.9921	2.4516
3	.0171	.0171	.0171	2.0896	1.7669	1.9418	2.3968
4	.0171	.0171	.0171	2.0576	1.7238	1.9166	2.3304
5	.0171	.0171	.0171	1.9958	1.6935	1.8915	2.255
6	.0175	.0171	.0175	2.0218	1.6766	1.8663	2.3495
7	.0171	.0171	.0171	2.0218	1.6796	1.9296	2.6185
8	.0175	.0145	.0171	.2625	.1924	.2648	.4199
9	2.761	2.8056	.0171		.0183	.0133	3.0795
10	3.0504	2.9165	.0152		.0133	.0171	3.1352
11	3.1764	2.9629	.0152		.0133	.0171	3.1353
12	3.0878	2.9157	.0152		.0133	.0152	3.0003
13	2.9789	2.7915	.0152		.0133	.0152	2.8215
14	2.9157	2.5774	.0152		.0133	.0152	2.9565
15	2.8842	2.4364	.0152		.0133	.0152	2.9974
16	2.8204	2.3617	.0152		.0133	.016	2.9332
17	.5125	.4244	.0152		.0133	.0152	.2808
18	.0162	.0133	.0152		.0163	.0152	.0171
19	.016	.0164	.0152		.0171	.0152	.0175
20	.016	.0171	.0152		.0148	.016	.0177
21	.016	.0171	.0152		.0148	.0156	.0179
22	.0173	.0171	2.2832	1.086	2.0249	2.4607	.0168
23	.0171	.0171	2.2421	2.0041	2.0523	2.537	.0171
24	.0342	.0171	1.318	2.0347	2.0243	2.2436	1.2003
Max	3.1764	2.9629	2.2832	2.1909	2.0523	2.537	3.1353
Min	.016	.0133	.0152	.2625	.0133	.0133	.0168
Avg	1.0191	.9351	.2575	1.8091	.7773	.8864	1.7899

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 202 / 11 KV Kavathe Piran  
 Village Feeder KV- 11 /  
 OUTGOING

GAOTHAN FEEDER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7205	.6996	.7072	.7596	.7007	.7181	.7183
2	.7015	.6885	.6996	.7436	.6943	.6983	.6977
3	.7091	.6851	.6939	.7398	.679	.6914	.6992
4	.7422	.6847	.6806	.7322	.6798	.6724	.6931
5	.8082	.7342	.7506	.7497	.7051	.7204	.7621
6	.9995	.9663	.9358	.9066	.9637	.9135	.9507
7	.9203	.9404	.8371	.8562	.9457	.8936	.8665
8	.7449	.7832	.7019	.7335	.7537	.7489	.7415
9	.6455	.6604	.6158	.3216	.6104	.5807	.5503
10	.5311	.5898	.5621	.3025	.6157	.5754	.5259
11	.5611	.5792	.6157	.3094	.5974	.4961	.5342
12	.5799	.6504	.6203	.2926	.6256	.5357	.5613
13	.6137	.6539	.5822	.301	.6279	.6356	.5913
14	.6577	.6272	.6127	.3437	.6073	.6501	.6317
15	.6561	.6486	.6172	.3513	.6264	.6855	.6454
16	.6051	.6463	.6481	.3056	.6287	.6935	.6615
17	.691	.6097	.6481	.1829	.6236	.5853	.7408
18	.748	.5944	.6219		.6816	.5484	.7175
19	.9687	.8725	.8261	.4138	.8345	.8513	.8749
20	1.1012	1.0753	1.0463	.6074	1.0555	1.0246	1.0292
21	1.0692	1.0113	1.0345	.5883	1.0974	1.0745	1.0511
22	.9638	.9473	1.0003	.5228	.9877	1.046	1.0207
23	.9345	.9149	.8757	.894	.8791	.9122	.944
24	.7678	.7677	.788	.8015	.7689	.7852	.7773
Max	1.1012	1.0753	1.0463	.9066	1.0974	1.0745	1.0511
Min	.5311	.5792	.5621	.1829	.5974	.4961	.5259
Avg	.7684	.7513	.7384	.5548	.7496	.7390	.7494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 203 / 11 KV Kavathe Piran Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0114	.0091	.0114	1.0802	.8785	.8745	1.0974
2	.0114	.009	.0114	1.0802	.8886	.8745	1.0974
3	.0118	.0093	.0114	1.0802	.8817	.8745	1.0974
4	.0118	.0095	.0114	1.0802	.8916	.8745	1.0974
5	.0114	.0097	.0114	1.0802	.8619	.8745	1.0974
6	.012	.0099	.0107	.9945	.8817	.7888	1.1065
7	.0114	.0097	.0114	.9774	.8886	.823	1.1736
8	.0107	.0088	.0103	.0114	.009	.0114	.0095
9	1.3565	1.3226	.0088		.0086	.0114	1.4083
10	1.3889	1.3717	.0095		.0114	.0141	1.2651
11	1.4232	1.3717	.0095		.0114		1.3125
12	1.406	1.4746	.0095		.0114		1.3283
13	1.3904	1.4083	.0095		.0114	.0095	1.3435
14	1.358	1.4746	.0095		.0114	.0095	1.3717
15	1.3717	1.406	.0095		.0114	.0095	1.3565
16	1.3546	1.3717	.0095		.0114	.0084	1.3717
17	.0128	.0095	.0114		.0114	.0093	.0128
18	.013	.0088	.0114		.0114	.0095	.0114
19	.0114	.0114	.0114		.0114	.0095	.0112
20	.0114	.0114	.0114		.0114	.0114	.0111
21	.0114	.0107	.0114		.0114	.0114	.0114
22	.0088	.0114	1.1831		.9259	1.1191	.0116
23	.0095	.0114	1.1145	.9665	.8745	1.1317	.0112
24	.0114	.0093	.0107	1.0802	.9116	.8745	1.1317
Max	1.4232	1.4746	1.1831	1.0802	.9259	1.1317	1.4083
Min	.0088	.0088	.0088	.0114	.0086	.0084	.0095
Avg	.4680	.4733	.1054	.9431	.3766	.4198	.8228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 204 / 11 KV samdoli Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2378	.2012	.2263	.2454	.2263	.2534
2	.2507	.2402	.2012	.2263	.2454	.2263	.2561
3	.2534	.2378	.2058	.2263	.2481	.2263	.2561
4	.2481	.2353	.2204	.2263	.2454	.2263	.2561
5	.2629	.2303	.2401	.2263	.2454	.2263	.2561
6	.3077	.2715	.2629	.2452	.2629	.2801	.2865
7	.2172	.2172	.2149	.1886	.8886	.2427	.2172
8	.2195	.2172	.1991	.1698	.181	.2054	.1991
9	.1848	.1848	.2012		.1848	.1867	.1848
10	.2218	.2195	.2012		.2054	.2218	.2241
11	.2427	.2195	.2012		.2054	.2218	.2241
12	.2378	.2353	.2012		.2054	.1829	.2263
13	.2587	.2561	.2012		.2054	.2218	.2427
14	.2534	.2378	.2012		.2054	.2218	.2427
15	.2561	.2195	.2012		.2241	.2241	.2641
16	.2454	.2195	.2195		.2241	.2195	.2614
17	.2629	.1991	.2195		.2427	.2172	.2587
18	.3045	.2218	.2378		.2614	.2561	.2801
19	.3326	.3292	.3292		.3361	.3326	.2987
20	.3292	.3982	.3734		.3921	.4108	.3109
21	.3224	.3658	.3734		.3921	.3547	.3045
22	.3961	.3403	.3734		.3547	.3439	.3224
23	.3174	.2743	.3018	.298	.2829	.3012	.2629
24	.2686	.2987	.2401	.2263	.2835	.2263	.2896
Max	.3961	.3982	.3734	.298	.8886	.4108	.3224
Min	.1848	.1848	.1991	.1698	.181	.1829	.1848
Avg	.2686	.2544	.2426	.2259	.2820	.2501	.2574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 205 / 11 KV Samdoli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.5658	.9054	.0189	.0189	.0189	.0189
2	.679	.5658	.9054	.0189	.0189	.0189	.0189
3	.6602	.5658	.9054	.0189	.0189	.0189	.0189
4	.6602	.5658	.9054	.0189	.0189	.0189	.0189
5	.6602	.5658	.8865	.0189	.0189	.0189	.0189
6	.679	.5658	.9054	.0189	.0189	.0189	.0189
7	.7167	.6224	1.0185	.0189	.0189	.0189	.0189
8	.0189	.0189	.0189	.0189	.0189	.0189	.0189
9	.0189	.0189	1.5655		1.773	1.773	.0189
10	.0189	.0189	1.6032		1.773	1.7541	.0189
11	.0189	.0189	1.6032		1.773	1.6221	.0189
12	.0189	.0189	1.5655		1.5655	1.5844	.0189
13	.0189	.0189	1.5089		1.5466	1.4712	.0189
14	.0189	.0189	1.5089		1.4901	1.4712	.0189
15	.0183	.0189	1.5089		1.4712	1.4335	.0189
16	.0189	.0189	1.4146		1.4901	1.4523	.0189
17	.0189	.0189	.0189		.0189	.0189	.0189
18	.0189	.0189	.0189		.0189	.0189	.0189
19	.0189	.0189	.0189		.0189	.0189	.0189
20	.0189	.0189	.0189		.0189	.0189	.0189
21	.0189	.0189	.0189		.0189	.0189	.0189
22	.5847	.9431			.0189	.0189	1.2637
23	.5847	.9619	.0189	.0189	.0189	.0189	1.226
24	.7167	.5658	.9431	.0189	.0189	.0189	.0189
Max	.7167	.9619	1.6032	.0189	1.773	1.773	1.2637
Min	.0183	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.2884	.2814	.8603	.0189	.5494	.5360	.1211

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 206 / 11 KV Shaurya Industries NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0377	.0686	.0905
2	.0343	.0343	.0343	.0343	.0343	.0686	.0905
3	.0343	.0343	.0343	.0343	.0343	.0686	.0905
4	.0343	.0343	.0343	.0343	.0343	.0686	.0905
5	.0343	.0343	.0343	.0343	.0343	.0686	.0905
6	.0343	.0343	.0343	.0343	.0343	.0686	.0905
7	.0343	.0343	.0343	.0343	.0343	.0686	.0905
8	.0343	.0343	.0343	.0343	.0343	.0686	.0343
9	.0724	.0343	.0537		.0343	.1029	.0724
10	.0739	.0724	.0514		.0686	.0905	.0686
11	.0732	.0724	.0686		.0686	.0914	.0686
12	.0686	.0724	.0686		.0686	.0905	.0686
13	.0686	.0362	.0686		.0686	.0905	.0686
14	.0686	.0914	.0686		.0686	.0905	.0343
15	.0686	.0914	.0686		.0686	.0905	.0343
16	.0514	.0724	.0686		.0686	.0914	.0343
17	.0343	.0905	.0514		.0343	.0905	.0343
18	.0343	.0343	.0514		.0343	.0905	.0343
19	.0343	.0343	.0514		.0343	.0905	.0343
20	.0343	.0343	.0343		.0343	.0905	.0343
21	.0343	.0343	.0343		.0343	.0724	.0343
22	.0343	.0343	.0189		.0343	.0905	.0343
23	.0343	.0343	.0343	.0343	.0686	.0905	.0343
24	.0343	.0343	.0343	.0343	.0343	.0686	.0905
Max	.0739	.0914	.0686	.0343	.0686	.1029	.0905
Min	.0343	.0343	.0189	.0343	.0343	.0686	.0343
Avg	.0456	.0478	.0459	.0343	.0459	.0821	.0603



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 201 / 11 KV Budhgaon Village

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.3315	
5	.4915	.663				
6			.1475			
7	.4096	.7209		.7865	.5243	
9		.6554		.5138		
11	.7865					.7293
12		.5735				
13	.663			.431		
14			.8192			
15		.4973				
16	.6962					
19	.9231	.9012				
20				.6718		
21		.9503				
22	.9012					
23			.8192			
24	1.3516	.7537	.7537	.8192	.5407	
Max	1.3516	.9503	.8192	.8192	.5407	.7293
Min	.4096	.4973	.1475	.431	.3315	.7293
Avg	.7778	.7144	.6349	.6445	.4655	.7293

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 202 / 11 KV Kaleran ( Kavalpur ) SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.121	1.291	.2766	.2454	.2591	.2698
2	1.5813	1.1233	2.0843	.2568	.2446	.2561	.2561
3	1.5257	1.1058	.9983	.2561	.2401	.2408	.3047
4	1.4685	1.0959	1.028	.2561	.2893	.2469	.2591
5	2.7709	2.1087	1.044	.2583	.2134	.2347	.2606
6	1.656	1.2109	1.9585	.2797	.2705	.2858	.3429
7	3.3928	3.0931	1.278	.3597	.3429	.2904	.2789
8	.3201	.6203	.4679	.2492	.2385	.2401	.3421
9	.2705	.2941	1.925	4.4721	2.6193	2.4341	.2545
10	.2378	.237	2.1651	2.5888	2.6833	2.7275	.2149
11	.2667	.2271	2.079	2.5934	2.6581	4.851	.2042
12	.2195	.2027	2.0774	2.1171	2.6017	2.6216	.2065
13	.3117	.2065	1.7779		2.5766	2.5187	.218
14	.2477	.2073	3.4499		2.4326	4.6738	.2035
15	.2477	.288	2.1826		2.3975	2.5492	.1943
16	.2854	.2218	2.1971	1.5653	2.4234	4.7398	.2103
17	.2263	.2233	.6531	.7987	.6783	1.2155	.2035
18	.2561	.2126	.2279	.2629	.2423	.1951	.2141
19	.3668	.3296	.2797	.25	.2629	.253	.2675
20	.3353	.317	.3414	.4169	.33	.3544	.3208
21	.2195	.381	.3391	.3384	.3216	.3102	.3551
22	2.2862	1.3009	.3376	.3109	.3163	.3147	1.9677
23	1.2369	1.4335	.4039	.3048	.3018	.317	2.1224
24	2.505	2.3297	1.3005	.3353	.3274	.2827	2.0795
Max	3.3928	3.0931	3.4499	4.4721	2.6833	4.851	2.1224
Min	.2195	.2027	.2279	.2492	.2134	.1951	.1943
Avg	.9955	.8288	1.3286	.8832	1.0524	1.3505	.4813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 203 / 11 KV Bisur village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2248	.2237	.2141	.2157	.2256	.2206	.2271
2	.2206	.2202	.3993	.21	.2168	.2111	.2199
3	.2157	.2134	.2046	.2065	.2145	.2328	.3081
4	.2191	.2084	.4106	.2027	.3261	.21	.213
5	.5095	.4142	.2107	.2149	.2244	.213	.2199
6	.2843	.2328	.4487	.245	.2622	.2587	.4907
7	.463	.4573	.2667	.4481	.4828	.2606	.2511
8	.234	.234	.237	.2294	.2347	.2412	.3858
9	.1829	.3529	.1768	.3305	.1692	.1692	.1738
10	.1608	.173	.1383	.1616	.1357	.1406	.1524
11	.2961	.1619	.1311	.1429	.1467	.2724	.1501
12	.1562	.2987	.1471	.1322	.1463	.1391	.1517
13	.2854	.1787	.1505	.2943	.1505	.16	.1658
14	.1806	.1859	.2947	.1509	.1635	.2751	.176
15	.1913	.3369	.1715	.1722	.1642	.176	.1779
16	.2809	.1989	.168	.1734	.1692	.2668	.1772
17	.1848	.366	.1635	.1597	.1604	.1547	.16
18	.1699	.189	.1692	.1654	.1619	.1608	.1524
19	.5095	.4593	.2229	.192	.216	.2191	.2115
20	.317	.3227	.3372	.5674	.3174	.6074	.3174
21	.2286	.58	.3083	.2919	.2999	.3311	.4999
22	.5727	.2923	.3052	.29	.2865	.3006	.298
23	.2884	.2808	.5614	.2915	.2736	.2968	.4622
24	.4653	.4401	.4453	.5298	.3925	.2496	.386
Max	.5727	.58	.5614	.5674	.4828	.6074	.4999
Min	.1562	.1619	.1311	.1322	.1357	.1391	.1501
Avg	.2851	.2925	.2618	.2508	.2309	.2403	.2553

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 204 / 11 KV Budhgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.0497				
3							.3277
4					.3605		
5	.0655	.0492					
6			.0332				.3647
7	.0655	.0492		.0131	.5243		
8							.0648
9		.6316		.0492			
11	.7293					.0492	
12		.6554					
13	.663			.0492			
14			.0497			.0492	
15		.5304					
16	.5967					.0486	
19	.0648	.0497					
20				.0497		.0492	
21		.0663					.0497
22	.0492						
24	.0648	.0486	.4144	.3277	.4915		.4475
Max	.7293	.6554	.4144	.3277	.5243	.0492	.4475
Min	.0492	.0486	.0332	.0131	.3605	.0486	.0497
Avg	.2874	.2601	.1368	.0978	.4588	.0491	.2509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 205 / 11 KV Express college  
feeder Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.2033				
3							.1307
4			.1478		.1132		
5	.1463	.1698					
6			.1478				.168
7	.112	.1698		.132	.1132		
8							.1494
9		.1886		.0934			
11	.168					.1698	
12		.1494					
13	.0747			.0934			
14			.1294			.1509	
15		.1109					
16	.1307					.132	
19	.0943	.0739					
20				.0934		.1132	
21		.0924					.0934
22	.1886						
23			.0943				.0934
24	.1372	.1698	.1663	.1867	.1494		.1132
Max	.1886	.1886	.2033	.1867	.1494	.1698	.168
Min	.0747	.0739	.0943	.0934	.1132	.1132	.0934
Avg	.1315	.1406	.1482	.1198	.1253	.1415	.1247

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 207 / 11 KV Jyptirling LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.1109			
3						.0754
4				.0566		
5	.0686	.0943				
6			.0924			.0754
7	.0747	.0189		.0566		
8						.1132
9		.0754				
11	.1132				.1132	
12		.0754				
13	.0943					
14			.0754		.1132	
15		.0739				
16	.0943				.1132	
24	.0754					
Max	.1132	.0943	.1109	.0566	.1132	.1132
Min	.0686	.0189	.0754	.0566	.1132	.0754
Avg	.0868	.0676	.0929	.0566	.1132	.088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 208 / 11 KV Bisur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8421	.5205	.628	.0914	.0937		.0922
2	.7773	.49	1.0875	.0907	.0892		.0914
3	.7644	.4915	.5914	.0907	.0899		.1359
4	.7369	.4954	1.0425	.0975	.1425		.0945
5	1.5912	.8787	.5799	.1052	.0914		.0488
6	.8192	.5517	1.1934	.128	.1151	.0762	.1928
7	.9396	1.1957	.6523	.1798	.1875	.093	.1273
8	.0975	.1235	.3978	.378	.4451	.5114	.1654
9	.1448	.2046	.9915	1.9952	1.0326	1.0646	.0983
10	.112	.1097	.9777	1.118	1.0852	1.1858	.0899
11	.1799	.0884	1.057	1.1325	1.1713	2.2538	.0998
12	.1006	.1227	1.086	.1738	1.2353	1.1896	.0968
13	.1456	.0472	1.0715		1.1302	1.1302	.0983
14	.0861	.0594	1.9083		1.1096	1.9779	.1006
15	.0854	.1288	1.0532		1.0532	1.025	.0991
16	.1433	.0899	1.028	.4321	1.0402	1.8595	.0854
17	.0053	.1075	.0754	.0975	.0503	.0998	.1113
18	.093	.1257	.1097	.0998	.0259	.1296	.1181
19	.1863	.2073	.1227	.1166	.0975	.1501	.125
20	.1044	.0975	.1265	.1662	.1067	.2096	.1235
21	.3437	.3506	.1036	.1059	.0823	.1387	.5329
22	.5617	.647	.1021	.1021	.0762	.1204	.8711
23	.5662	.6935	.1577	.0914	.0152	.1021	1.7558
24	1.4273	1.1018	.599	.1659	.0434	.093	.871
Max	1.5912	1.1957	1.9083	1.9952	1.2353	2.2538	1.7558
Min	.0053	.0472	.0754	.0907	.0152	.0762	.0488
Avg	.4522	.3720	.6976	.3313	.4421	.7058	.2594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 201 / 11 kV Dudhgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4382	.362	.381	.362	.3429	.381
2	.4191	.4572	.362	.362	.3429	.3429	.381
3	.381	.4572	.3429	.362	.3429	.3239	.381
4	.381	.381	.381	.381	.362	.362	.381
5	.4001	.381	.4001	.362	.4191	.381	.4001
6	.4191	.4001	.4382	.3429	.4572	.381	.4763
7	.362	.362	.3429	.3429	.381	.362	.362
8	.362	.3429	.3429		.3429	.3045	.3429
9	.3239	.3429	.439		.3048	.3658	.3429
10	.3429	.3292	.4207		.4163	.3921	.4001
11	.3239	.3142	.4207		.4163	.4108	.381
12	.4001	.3258	.439		.4163	.4481	.4572
13	.4001	.3366	.4024		.4163	.4294	.462
14	.381	.3467	.4572		.4525	.4481	.462
15	.381	.3761	.4163		.4525	.4854	.4382
16	.362	.3506	.3982		.4525	.4527	.4382
17	.362	.3721	.5304		.4252	.4191	.4191
18	.462	.4119	.4207		.4344	.4954	.4191
19	.5792	.4706	.6335		.4961	.5144	.5175
20	.591	.5175	.5973		.5373	.5716	.6036
21	.5068	.5121	.4572		.4344	.5335	.5853
22	.5068	.4656	.4435		.4572	.4954	.5544
23	.5144	.4024	.3881		.3982	.4382	.4805
24	.9716	.4763	.4001	.381	.381	.362	.381
Max	.9716	.5175	.6335	.381	.5373	.5716	.6036
Min	.3239	.3142	.3429	.3429	.3048	.3045	.3429
Avg	.4405	.3988	.4265	.3644	.4126	.4193	.4353



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 202 / 11 kV Sawalwadi Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6481	.5944	.8002	.0381		.0381	.0381
2	.6481	.5647	.7748	.0381	.0191	.0381	.0381
3	.6097	.5418	.7748	.0381	.0191	.0381	.0381
4	.6097	.5487	.8002	.0381	.0191	.0381	.0381
5	.5944	.5182	.7935	.0381	.0191	.0381	.0381
6	.5944	.5247	.7748	.0381	.0381	.0381	.0381
7	.6327	.5155	.8482	.0381	.0381	.0381	.0381
8	.0191	.0381	.0381	.0381	.0381	.0381	.0381
9	.0381	.0381	1.0494		1.2018	1.2308	.0381
10	.0381	.0381	1.1498		1.2631	1.326	.0381
11	.0381	.0381	1.1498		1.3763	1.291	.0381
12	.0191	.0381	1.166		1.4091	1.1603	.0381
13	.0381	.0381	1.1336		1.3435	1.1603	.0381
14	.0191	.0381	1.0883		1.3272	1.1437	.0381
15	.0381	.0381	1.0562		1.2944	1.1271	.0381
16	.0381	.0191	1.0082		1.2616	1.0608	.0381
17	.0381	.0191	.0381		.0191	.0381	.0381
18	.0381	.0191	.0381		.0191	.0381	.0381
19	.0381	.0191	.0381		.0191	.0191	.0381
20	.0381	.0191	.0381		.0381	.0381	.0381
21	.0381	.0191	.0381		.0381	.0381	.0381
22	.6249	.7362	.0381		.0381	.0381	.7621
23	.6249	.7748	.0381		.0381	.0381	.7773
24	.6481	.5944	.7935	.0381	.0381	.0381	.0381
Max	.6481	.7748	1.166	.0381	1.4091	1.326	.7773
Min	.0191	.0191	.0381	.0381	.0191	.0191	.0381
Avg	.2796	.2639	.6444	.0381	.4746	.4204	.0991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 203 / 11 kV Dharan Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5761	.4481	.4858	1.0059	.8192	.8097	.9054
2	.5761	.4481	.4915	.9779	.7865	.7956	.8951
3	.5601	.4428	.4696	.9779	.7956	.7611	.8951
4	.5376	.4744	.4641	.9282	.7956	.7956	.9614
5	.5376	.4744	.4641	.852	.7625	.7865	1.0111
6	.5441	.4801	.4534	.852	.7459	.779	.9602
7	.5668	.4961	.5079	.8356	.7209	.8029	1.0159
8	.0191	.0191	.0191	.0191	.0381	.0191	.0191
9	1.1568	1.1797	.7274		.8421	.7935	1.2929
10	1.2452	1.2407	.7865		.8619	.8785	1.2125
11	1.2308	1.1105	.7537		.8453	.7209	1.1822
12	1.2452	1.1305	.7045		.8122	.7956	1.2763
13	1.1984	1.1768	.7209		.7956	.779	1.291
14	1.1961	1.1012	.7373		.7625	.7459	1.3395
15	1.2125	.5801	.6226		.7459	.7127	1.3077
16	1.2125	.9878	.6226		.7127	.7545	1.291
17	.0381	.0191	.0381		.0191	.0191	.0191
18	.0381	.0191	.0381		.0381	.0381	.0381
19	.0381	.0381	.0381		.0381	.0381	.0381
20	.0381	.0381	.0381		.0381	.0381	.0381
21	.0381	.0381	.0381		.0381	.0381	.0381
22	.4161	.4801	1.1022		.9282	.8907	.5937
23	.4858		1.0852		.9012	.9282	.6249
24	.5761	.4973		1.0059	.8097	.8684	.9054
Max	1.2452	1.2407	1.1022	1.0059	.9282	.9282	1.3395
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.6368	.5618	.4960	.8283	.6105	.6079	.7980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 205 / 11 KV A1 PPS Express

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4527	.4527	.5658	.6161	.5788
2	.4108	.4527	.4668	.5847	.6283	.6535
3	.4481	.4904	.4715	.6036	.6224	.6535
4	.4854	.5658	.4435	.6036	.6099	.6535
5	.5601	.4904	.4715	.6036	.6413	.6722
6	.6348	.6413	.4715	.6036	.6161	.6584
7	.6348	.5975	.6161	.5792	.6516	.7655
8	.6722	.6908	.6584	.679	.8029	.7207
9	.6099	.6908	.6468	.7545	.8402	.7842
10	.6767	.7282	.7095	.8215	.8589	.5601
11	.6535	.7468	.6908	.8029	.7922	.4481
12	.6535	.7392	.6979		.7947	.7095
13	.6722	.7468	.6979	.8029	.7947	.7282
14	.6535	.7468	.6979	.8029	.8029	.7282
15	.6535	.7468	.7167	.7655	.8029	.6722
16	.6535	.7545	.7167	.7655	.7842	.5788
Max	.6767	.7545	.7167	.8215	.8589	.7842
Min	.4108	.4527	.4435	.5658	.6099	.4481
Avg	.5927	.6426	.6016	.6893	.7287	.6603

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 201 / 11 KV Nandre Village

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	.9619	.9808	.9997	.9997	.9619	.9997
2	.9431	.9431	.9431	.9619	.9242	.9431	.9619
3	.9431	.9054	.9431	.9619	.9242	.9242	.9431
4	.9431	.9054	.9619	.8865	.9242	.9431	.9431
5	.9511	1.0082	1.0185	.8865	.9149	.9619	1.0082
6	.9795	1.1389	1.0751	1.0829	1.0164	1.0164	1.1088
7	.9694	.9055	.9242	.9431	.8962	.924	.8962
8	.823	.8779	.8215	.8596	.823	.7628	.8413
9	.8131	.7973	.8328	.8962	.8871	.7888	.8596
10	.8059		.7783	.823	.823	.7712	.8505
11	.8669	.8688	.8145		.8238	.8682	.8682
12	.9774	.9134			.815	.9412	.8596
13	.8589	.8145	.8131		.815	.8869	.8775
14	.8842	.8596	.8501	.6468	.8596	.8238	.8688
15	.8682	.8413	.8779		.8413	.8417	.8507
16	.8238	.8326	.7783		.8871	.7783	.8775
17	.8145	.8417	.7202		.8954		.8507
18	.823	.8402	.7619		.7969	.7682	.8865
19	1.1458	1.1517	1.0745		1.0229	1.0387	1.1458
20	1.2936	1.2308	1.262		1.2803	1.3121	1.3676
21		1.2536	1.2382		1.262	1.2752	1.3676
22	.5601	1.2127	1.2449		1.2449	1.2637	1.3491
23	.6979	1.0387	1.1317		1.0751	1.1317	1.1883
24	2.1124	.6099	.9896	1.0374	1.0374	1.0185	1.0269
Max	2.1124	1.2536	1.262	1.0829	1.2803	1.3121	1.3676
Min	.5601	.6099	.7202	.6468	.7969	.7628	.8413
Avg	.9529	.9458	.9494	.9155	.9496	.9542	.9916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 202 / 11 kV Nandre Ag

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3161	.333	.0377	.0377	.0377	.0377
2	.4344	.3241	.3418	.0377	.0377	.0566	.0377
3	.4401	.3121	.3418	.0377	.0377	.0566	.0377
4	.463	.3081	.3286	.0377	.0377	.0377	.0377
5	.4515	.3041	.333	.0566	.0377	.0566	.0377
6	.4572	.3241	.3429	.0377	.0566	.0566	.0566
7	.463	.3269	.3243	.0566	.0566	.0566	.0566
8	.0566	.0377	.0566	.0566	.0754	.0566	.0566
9	.0566	.0566	.5007	.5268	.5647	1.3957	.0566
10	.0566		.4858	.571	.5792	.535	.0566
11	.0566	.0566	.5428	.5498	.602	.5719	.0566
12	.0566	.0754			.5864	.5944	.0566
13	.0566	.0754	.543		.5573	.571	.0566
14	.0754	.0754	.5428		.5647	.5569	.0566
15	.0566	.0754	.5213		.535	.535	.0377
16	.0566	.0754	.5001		.5247	.5401	.0377
17	.0566	.0754	.0549		.0566		.0566
18	.0566	.0754	.0566		.0566	.0566	.0366
19	.0566	.0566	.0566		.0566	.0377	.0377
20	.0754	.0566	.0566		.0566	.0566	.0566
21		.0754	.0754		.0566	.0377	.0566
22	.3185	.3311	.0566		.0566	.0377	.4167
23	.3121	.3418	.0377		.0566	.0377	.4115
24	.8802	.3144	.3612	.0377	.0377	.0566	.0377
Max	.8802	.3418	.543	.571	.602	1.3957	.4167
Min	.0566	.0377	.0377	.0377	.0377	.0377	.0366
Avg	.2365	.1770	.2954	.1703	.2219	.2624	.0785

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 203 / 11 KV Malbhag Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0566	.0566	.2641	.2263	.2452	.2075
2	.0377	.0566	.0566	.2452	.2263	.2263	.2075
3	.0377	.0566	.0566	.2075	.2263	.2263	.2075
4	.0377	.0566	.0566	.2075	.2263	.2263	.2075
5	.0377	.0566	.0566	.2263	.2263	.2263	.2075
6	.0377	.0566	.0566	.2075	.2452	.2263	.2075
7	.0377	.0566	.0754	.2452	.2641	.2263	.2263
8	.0566	.0566	.0754	.0566	.0566	.0566	.0943
9	.5093	.4338	.0754	.0754	.0754	.0943	.4338
10	.5658		.1132	.0943	.0754	.1509	.5093
11	.5658	.5281	.132	.0943	.0754	.1132	.4527
12	.4904	.4904	.132	.0943	.0754	.132	.4715
13	.4715	.4338	.0943	.0566	.0566	.132	.4527
14	.4527	.4338	.0943	.0754	.0754	.132	.4527
15	.4338	.3961	.0943		.0754	.1132	.4338
16	.4338	.3395	.0943		.0566	.1132	.3961
17	.0943	.0943	.0754		.0754		.1132
18	.1132	.0943	.0943		.0566	.0943	.132
19	.0754	.0566	.0377		.0566	.0566	.0943
20	.0566	.0377	.0377		.0377	.0754	.0754
21	.0566	.0566	.0377		.0377	.0754	.0754
22	.0566	.0566	.2641		.2829	.2263	.0566
23	.0566	.0566	.3206		.3018	.2075	.0566
24	.0377	.0566	.0566	.2829	.2452	.2641	.2263
Max	.5658	.5281	.3206	.2829	.3018	.2641	.5093
Min	.0377	.0377	.0377	.0566	.0377	.0566	.0566
Avg	.1996	.1747	.0935	.1622	.1399	.1583	.2499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 206 / 11 KV DATNAGAR

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9069	.8459	.8497	.8383	.8192	.8154	.8421
2	.8307	.7811	.7888	.7735	.7583	.7583	.7811
3	.7888	.743	.7392	.724	.7202	.7278	.7583
4	.7697	.7125	.7087	.7049	.6973	.6897	.7202
5	.7392	.6821	.6783	.6821	.6821	.6668	.6973
6	.7392	.6973	.7049	.7049	.7125	.6897	.7049
7	.7583	.6859	.7202	.7049	.743	.7506	.7621
8	.7506	.6897	.7087	.743	.7049	.7202	.7125
9	.6325	.644	.602	.602	.5944	.5754	.602
10	.5677	.6135	.5563	.5754	.5868	.5677	.5639
11	.5487	.5639	.5563	.5335	.5868	.5563	.5601
12	.5563	.5792	.5639	.5411	.5639	.5716	.5792
13	.5716	.5792	.5411	.5563	.5601	.5754	.5639
14	.6173	.5906	.583	.5677	.5716	.5754	.5639
15	.6173	.6287	.5868	.5639	.6097	.602	.5944
16	.6287	.6363	.602	.583	.6173	.5982	.602
17	.6211	.6325	.6249	.6097	.6097	.6516	.6325
18	.6401	.6173	.6173	.6059	.6211	.6668	.6249
19	.7583	.7316	.7278	.6706	.7278	.7202	.7202
20	.884	.884	.8993	.8421	.9183	.8954	.9221
21	.865	.884	.9297	.8573	.9335	.9297	.9259
22	.8612	.8993	.9107	.8688	.9183	.9297	.9145
23	.8802	.9259	.9297	.9069	.9602	.9526	.9488
24	1.2544	.8993	.9297	.8878	.9107	.9297	.8916
Max	1.2544	.9259	.9297	.9069	.9602	.9526	.9488
Min	.5487	.5639	.5411	.5335	.5601	.5563	.5601
Avg	.7412	.7145	.7108	.6937	.7137	.7132	.7162

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 210 / 11 KV Dhamni

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
1	1.3306
2	1.2936
3	1.2567
4	1.2696
5	1.2936
6	1.3717
7	1.3717
8	1.3169
9	1.4998
10	1.5364
11	1.4632
12	1.9204
13	1.7558
14	1.7193
15	1.6827
16	1.6461
17	1.6289
18	1.6651
19	1.6289
20	1.3611
21	1.3253
22	1.3253
23	1.3432
24	1.4784
Max	1.9204
Min	1.2567
Avg	1.4785



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 401 / 33KV KASABE DIGRAJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
1	7.9818
2	7.9012
3	7.7103
4	7.7103
5	7.9012
6	8.3402
7	8.6877
8	4.7239
9	10.0995
10	10.631
12	9.4616
13	10.0463
14	9.7805
15	9.8337
16	8.9723
17	2.0416
24	6.0357
Max	10.631
Min	2.0416
Avg	8.1093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 404 / 33 KV MADHAVNAGAR(EHV)

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	29.6983	***	27.8121	27.9836	***	***
2	***	29.2868	29.8011	26.3376	27.812	***	***
3	***	28.7037	28.9094	25.2058	27.0577	***	29.2525
4	***	28.155	28.258	24.7942	26.3374	29.3897	28.155
5	***	27.5035	27.6749	24.2799	26.1317	28.9095	27.4348
6	***	27.7436	29.1838	23.9713	26.8518	29.4925	28.2237
7	***	28.0521	29.561	23.594	27.1948	29.2867	28.1208
8	29.424	27.0577	28.3265	22.0851	25.7202	28.5323	28.498
9	***	***	***	20.0617	***	***	***
10	***	***	***	19.7188	***	***	***
11	***	***	***	14.9178	***	***	***
12	***	***	***	13.546	***	***	***
13	***	***	***	14.7119	***	***	***
14	***	***	***	13.2031	***	***	***
15	***	***	***	19.7188	***	***	***
16	***	***	***	20.5762	***	***	***
17	***	***	***	20.7477	***	***	***
18	***	***	***	21.3306	***	***	***
19	***	29.4582	***	25.1372	***	***	***
20	***	***	***	29.1839	***	***	***
21	21.9479	***	***	28.9438	***	***	***
22	26.9204	***	***	28.7723	***	***	***
23	29.0467	***	***	29.1153	***	***	***
24	29.1496	29.7668	***	27.915	***	***	***
Max	41.461	38.7861	40.9809	29.1839	40.7751	41.2208	41.701
Min	21.9479	27.0577	27.6749	13.2031	25.7202	28.5323	27.4348
Avg	33.5134	31.6073	33.2419	22.7367	32.7204	34.4922	34.1679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 405 / 33KV SANGLI CITY -NEW

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	***	***	***	***	***	***	***
3	***	***	***	***	***	***	***
4	***	***	***	***	***	***	***
5	***	***	***	***	***	***	***
6	***	***	***	***	***	***	***
7	***	***	***	***	***	***	***
8	***	***	***	***	***	***	***
9	***	***	***	***	***	***	***
10	***	***	***	***	***	***	***
11	***	***	***	***	***	***	***
12	***	***	***	***	***	***	***
13	***	***	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	***	***	***	***	***	***	***
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	***	***	***	***
Max	65.4322	58.8821	63.306	59.4994	62.9287	63.4089	63.3746
Min	38.8203	36.6256	37.4829	35.8025	36.557	36.9685	37.3458
Avg	48.9070	45.7348	47.3437	44.6160	47.4295	47.8210	47.6324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 203 / 11 KV WATER WORKS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.3856	.3887	.3887	.3948	.397	.381
2	.3909	.3917	.3879	.3925	.3925	.397	.3864
3	.3887	.3925	.3871	.3536	.3864	.3673	.3887
4	.3871	.3909	.3574	.3536	.3506	.3574	.3498
5	.3536	.3559	.3574	.3528	.3528	.3574	.349
6	.3597	.3574	.362	.3574	.3597	.3635	.3528
7	.362	.3605	.3643	.3567	.365	.3605	.3117
8	.378	.3833	.3841	.3894	.3841	.3864	.3795
9	.3849	.3955	.4016	.4039	.4047	.3955	.3993
10	.3986	.3727	.4039	.3978	.3955	.4001	.3955
11	.4024	.3483	.3948	.397	.394	.3917	.3749
12	.4024	.397	.3948	.3871	.394	.3902	.3849
13	.3894	.3871	.3849	.3795	.381	.3833	.3795
14	.3871	.3818	.3673	.3788	.3795	.3818	.3803
15	.3879	.3856	.3757	.3772	.3788	.3917	.3795
16	.3871	.3856	.3795	.3849	.3772	.3955	.3826
17	.2614	.3765	.3742	.3849	.3803	.3803	.3757
18	.3742	.3772	.381	.3788	.2218	.3742	.3765
19	.3871	.378	.3818	.3871	.3826	.378	.3818
20	.3909	.3871	.3879	.3955	.3902	.3841	.3925
21	.3597	.3833	.3864	.3909	.3879	.3841	.3887
22	.0282	.3955	.3909	.4001	.4031	.3909	.3917
23	.4024	.3963	.3894	.3643	.4016	.381	.3887
24	.3894	.3955	.3871	.3978	.3955	.3795	.3833
Max	.4024	.397	.4039	.4039	.4047	.4001	.3993
Min	.0282	.3483	.3574	.3528	.2218	.3574	.3117
Avg	.3641	.3817	.3821	.3813	.3772	.3820	.3773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 205 / SANGLI COLLEGE CORNER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5554	1.3938	1.3725	1.3458	1.499	1.374	1.419
2	1.4159	1.2742	1.2605	1.2216	1.374	1.2102	1.2948
3	1.3298	1.2026	1.1835	1.1454	1.3161	1.1538	1.2079
4	1.2864	1.1538	1.1203	1.1073	1.2498	1.0875	1.1492
5	1.2384	1.1271	1.0959	1.0738	1.2048	1.0677	1.121
6	1.2277	1.089	1.0639	1.044	1.134	1.0715	1.0837
7	1.2315	1.0989	1.0745	1.0684	1.1294	1.1096	1.0722
8	1.0669	.961	.9671	.9526	1.0082	.9724	.9282
9	.9404	.9099	.8619	.8627	.9061	.8833	.8756
10	1.0966	1.0059	.9587	.8566	1.0837	1.0303	1.07
11	1.1759	1.0402	1.0707		1.1302	1.1454	1.1012
12	1.1431	1.0501	1.1256		1.1972	1.1424	1.057
13	1.134	1.0364	1.1195		1.1568	1.1873	1.0905
14	1.1416	.9717	1.0677		1.0562	1.0852	.9633
15	1.2483	1.0776	1.1721		1.1988	1.2033	1.1218
16	1.2727	1.1294	1.2384		1.2513	1.2308	1.1606
17	1.2361	1.1035	1.1904		1.2521	1.2193	1.1142
18	1.1546	1.041	1.1759	.1357	1.1972	1.1843	1.1302
19	1.2932	1.0753	1.198	1.5463	1.2513	1.2513	1.2026
20	1.4594	1.3001	1.454	1.6575	1.4937	1.4914	1.4518
21	1.3321	1.3161	1.4114	1.6019	1.5097	1.4586	1.4259
22	1.3535	1.3817	1.435	1.5966	1.4716	1.4701	1.4998
23	1.4091	1.467	1.4868	1.6621	1.5828	1.5577	1.5539
24	1.454	1.4678	1.4868	1.6171	1.5539	1.5409	1.5554
Max	1.5554	1.4678	1.4868	1.6621	1.5828	1.5577	1.5554
Min	.9404	.9099	.8619	.1357	.9061	.8833	.8756
Avg	1.2582	1.1531	1.1913	1.2056	1.2587	1.2137	1.1937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 201 / 11KV GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7239	1.656	.8391	1.5368	1.5939	1.6482	1.5775
2	1.6069	1.5653	.7857	1.4373	1.5217	1.5036	1.4743
3	1.5303	1.5272	1.4415	1.419	1.5057	1.4438	1.3984
4	1.5097	1.4754	1.4141	1.3793	1.4762	1.4179	1.3633
5	1.5524	1.451	1.4442	1.3485	1.4655	1.4223	1.3139
6	1.6256	1.5006	1.5044	1.3537	1.4914	1.4823	1.3764
7	1.56	1.4442	1.5059	1.4099	1.5482	1.5219	1.3976
8	1.4578	1.4251	1.4205	1.4243	1.5303	1.4628	1.3971
9	1.4052	1.4596	1.4647	1.4136	1.3683	1.4381	1.411
10	1.5855	1.5528	1.6541	1.5158	1.5813	1.7056	1.7709
11	1.8869	1.6644	1.7517	1.6629	1.7608	1.8061	1.9311
12	2.0912	1.8039	1.9386	1.579	1.8389	1.8054	1.688
13	2.0256	1.7566	1.8789	.9092	1.8785	1.8656	1.9792
14	2.015	1.7223	1.8965	.8848	1.8641	1.8427	1.9155
15	2.015	1.8084	1.9637	.9069	1.8968	1.9212	1.9374
16	2.0556	1.7067	2.0011	.9412	1.9075	1.9982	1.9837
17	2.0664	.9015	1.9394	.9617	1.9479	1.9338	1.9883
18	2.1483	1.7173	1.8998	.9579	1.9677	1.9464	2.1094
19	2.67	2.1727	2.3624	1.1218	2.4798	2.4947	2.6186
20	1.4457	2.3015	2.5941	1.3024	2.6612	2.6715	2.6772
21	2.6006	2.2558	2.4974	1.2658	2.5164	2.4554	2.4592
22	2.2077	2.0611	2.1346	1.1385	2.1872	2.2219	2.2131
23	2.0256	1.8923	1.9856	1.0227	1.9967	1.9562	1.9951
24	1.8328	1.7932	.9595	1.6499	1.7875	1.8073	1.656
Max	2.67	2.3015	2.5941	1.6629	2.6612	2.6715	2.6772
Min	1.4052	.9015	.7857	.8848	1.3683	1.4179	1.3139
Avg	1.8602	1.6923	1.7199	1.2726	1.8239	1.8239	1.8180

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 202 / 11KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6669	2.4997	2.7363	2.6711	2.3694	2.8824	2.7961
2	2.6962	2.4597	2.6314	2.5107	2.2666	2.8019	2.713
3	2.6798	2.3609	2.5427	2.4955	2.2499	2.7549	2.6551
4	2.6299	2.3522	2.4923	2.3009	2.1944	2.7176	2.6288
5	2.6799	2.3137	2.4527	2.284	2.1743	2.6826	2.6322
6	2.7206	2.4413	2.5073	1.9738	2.1809	2.763	2.6212
7	2.558	2.532	2.6532	1.7231	2.0563	2.7327	2.6353
8	2.5499	2.3704	2.6516	1.5684	2.0794	2.7389	2.4497
9	2.604	2.5332	2.7893	1.5177	1.7155	2.833	2.5145
10	2.8966	2.6269	3.0913	1.5524	2.3217	2.9767	3.0998
11	3.4165	2.7178	3.4179	1.8566	3.3059	3.3458	3.4639
12	3.5273	2.7552	3.5801	2.0576	3.4392	3.4229	3.5851
13	3.5504	2.7982	3.5769	1.464	3.6759	3.3581	3.5412
14	3.6723	2.9119	3.6036	1.4056	3.6119	3.3101	3.3646
15	3.5845	2.9091	3.5414	1.4129	3.5986	3.2982	3.3342
16	3.5383	2.9006	3.7071	1.4453	3.5578	3.2948	3.4183
17	3.5319	2.0347	3.6292	1.4605	3.5208	3.3482	3.3421
18	3.4461	2.966	3.528	1.4331	3.4187	3.3143	3.3493
19	3.8935	3.0872	3.682	1.5851	3.5799	3.6465	3.6805
20	2.8072	3.4332	3.9757	1.8549	3.8603	3.9002	3.8901
21	2.0491	3.3415	3.7662	1.991	3.7612	3.7155	3.5525
22	2.3518	3.1192	3.3661	1.8473	3.3208	3.2815	3.2099
23	2.6932	2.9996	3.0665	1.7814	3.1877	3.117	3.1032
24	2.8125	2.7911	2.7614	1.7093	2.8838	3.0205	2.8434
Max	3.8935	3.4332	3.9757	2.6711	3.8603	3.9002	3.8901
Min	2.0491	2.0347	2.4527	1.4056	1.7155	2.6826	2.4497
Avg	2.9815	2.7190	3.1563	1.8293	2.9305	3.1357	3.101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 203 / 11KV VAKHARBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5249	1.4811	1.4845	1.47	1.4409	1.4554	1.5638
2	1.3641	1.3946	1.3801	1.3672	1.3741	1.3097	1.4396
3	1.3496	1.304	1.3005	1.3527	1.3565	1.2807	1.4098
4	1.3248	1.3005	1.243	1.289	1.3072	1.242	1.2969
5	1.3382	1.2453	1.2239	1.2262	1.2746	1.2125	1.2793
6	1.3798	1.2437	1.262	1.246	1.2721	1.2491	1.278
7	1.3847	1.2573	1.3169	1.2866	1.348	1.4123	1.326
8	1.4312	1.2544	1.2902	1.2155	1.3409	1.3466	1.262
9	1.4003	1.2973	1.3424	1.2319	1.3395	1.3314	1.3253
10	1.4568	1.4426	1.6125	1.454	1.4898	1.5036	1.6221
11	2.0744	1.7273	2.0376	1.8641	1.8412	2.0485	2.0123
12	2.4927	2.1009	2.3505	2.2505	1.9845	2.1841	2.3211
13	2.308	2.164	2.2611	1.1713	2.1612	2.1544	2.28
14	2.3098	2.0687	2.1693	1.1485	2.1801	2.1727	2.2969
15	2.2218	2.0777	2.1506	1.1606	2.2527	2.1758	2.2468
16	2.4672	2.0249	2.2023	1.2132	2.297	2.2116	2.2888
17	2.3751	1.0669	2.2863	1.2026	2.2657	2.3022	2.2284
18	2.3659	2.058	2.2381	1.1568	2.2588	2.2947	2.2214
19	2.7125	2.4612	2.481	1.1591	2.5766	2.5267	2.601
20	1.4449	2.4855	2.5949	1.3222	2.6887	2.6201	2.7046
21	2.5844	2.4911	2.4459	1.3161	2.572	2.4204	2.396
22	2.1765	2.1658	2.1879	1.1797	2.2184	2.1483	2.1128
23	1.8062	1.768	1.8383	.9496	1.8344	1.8221	1.8145
24	1.7699	1.6065	1.6248	1.6095	1.5829	1.6149	1.6351
Max	2.7125	2.4911	2.5949	2.2505	2.6887	2.6201	2.7046
Min	1.3248	1.0669	1.2239	.9496	1.2721	1.2125	1.262
Avg	1.8777	1.7286	1.8469	1.3268	1.8441	1.8350	1.8734



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 201 / 11 KV Balaji Mill Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7545	.7023	.6653	.7733	.7392	.7842
2	.7468	.7167	.6838	.6535	.7545	.7023	.7392
3	.7468	.7167	.6767	.6348	.7167	.695	.7023
4	.7468	.6908	.695	.6348	.7095	.6516	.695
5	.7167	.6535	.6838	.6348	.6908	.6516	.6584
6	.6602	.6468	.7023	.6535	.6908	.6468	.6767
7	.5975	.5544	.5975	.6036	.5304	.5175	.567
8	.4835	.5487	.6283	.5249	.5304	.462	.5228
9	.5853	.5487	.7282	.543	.443	.5083	.6036
10	.7922	.7023	.7468	.5847	.6219	.6516	.7167
11	.8299	.8299	.7545	.6335	.7842	.7733	.7545
12	.8676	.9808	.8299		.9242	.8676	.811
13	.8299	.9054	.8488		.9054	.9431	.8299
14	.8299	.9808	.8676		.8488	.8865	.811
15	.8865	.9054	.7655		.9242	.8488	.9431
16	.8865	.8676	.8299		.8488	.9619	.8402
17	.8865	.7842	.7468		.7468	.7655	.8299
18	.8676	.7733	.8029		.811	.7842	.7655
19	.8488	.7356	.7733		.7733	.8865	.8488
20		.7282	.811		.7167	.8488	.7842
21	.7167	.8215	.8029		.7842	.8865	.8589
22	.8299	.8676	.8299		.8402	.8488	.9149
23	.8488	.8865	.7922		.8029	.9054	.8962
24		.7922	.7095	.7545	.811	.7842	.8029
Max	.8865	.9808	.8676	.7545	.9242	.9619	.9431
Min	.4835	.5487	.5975	.5249	.443	.462	.5228
Avg	.7722	.7663	.7504	.6267	.7493	.7590	.7649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 202 / 11 KV Circuit House

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3584	.3018	.2614	.2829	.2957	.3395
2	.3361	.3206	.3018	.2641	.2641	.2614	.3018
3	.3018	.2829	.2614	.2263	.2641	.2614	.2641
4	.3018	.2829	.2614	.2263	.2263	.2427	.2641
5	.3018	.2452	.2452	.2263	.2263	.2427	.2263
6	.2641	.2263	.2263	.2263	.2263	.2263	.1886
7	.2263	.2263	.2075	.2195	.2263	.2241	.2263
8	.2263	.2075	.2075	.2075	.1886	.2075	.1886
9	.2614	.2829	.2075	.2427	.1886	.2075	.1698
10	.2263	.2641	.2263	.2263	.2075	.2241	.1698
11	.3018	.3206	.2452	.2427	.2452	.2263	.2263
12	.2641	.3018	.2263		.2829	.2614	.2263
13	.2641	.3206	.2641		.2452	.2641	.2452
14	.3018	.3018	.2641		.3018	.3018	.2829
15	.3206	.3395	.2829		.3395	.2829	.3206
16	.3206	.3584	.2614		.3772	.2641	.3206
17	.3018	.2263	.2829		.3206	.2263	.3206
18	.2641	.2263	.2427		.2829	.2263	.2801
19	.3584	.2427	.3696		.3361	.2641	.2987
20		.2801	.3326		.4108	.3206	.3292
21	.3511	.3206	.3326		.3361	.3395	.3361
22	.3696	.3395	.3881		.3772	.3395	.3734
23	.4715	.415	.4294		.3696	.3961	.3921
24	.4294	.4527	.3734	.3326	.3734	.3511	.3772
Max	.4715	.4527	.4294	.3326	.4108	.3961	.3921
Min	.2263	.2075	.2075	.2075	.1886	.2075	.1698
Avg	.3095	.2976	.2809	.2418	.2875	.2691	.2778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 201 / 11 KV MADHAVNAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.8383	.7095	.7167		.679	.7167
2	.6979	.7621	.679	.6602		.6224	.7167
3	.6979	.7621	.6224	.6602		.6224	.679
4	.6979	.724	.6161	.6602		.6224	.679
5	.6979	.724	.6036	.6602		.6224	.679
6	.7167	.6668	.6161	.6979		.679	.679
7	.7167	.7621	.6224	.679		.7167	.679
8	.6602	.8002	.5658	.4904		.5281	.5658
9		.7602	.7621		.6413	.7621	.6602
10		.7783	.8573		.7922	.8764	.8507
11		.8145	.9717		.9431	1.0098	.9593
12		.8688	.8954		.8299	.9526	.905
13		.7133	.7811		.7356	.8383	.8326
14		.8145	.8573		.7733	.9526	.9231
15		.9774	.9335		.811	1.0479	.9412
16		.9231	.9335		.8865		.9593
17		.9328	.9593		.9231	.9808	.9526
18	.9526	.9619	.905		.9412	.9808	.9145
19	1.4098	.9328	1.1041		1.0679	.9997	
20	1.7528	.9242	1.0136		1.0136	.9808	1.0669
21	.8002	.811	.8688		.9955	.9619	1.0479
22		.7922	.8596	.724	.9328	.8865	1.0098
23	.8002	.7545	.8316	.724	.9055	.8299	.9526
24	.8676	.8954	.7468	.8299		.7842	.7733
Max	1.7528	.9774	1.1041	.8299	1.0679	1.0479	1.0669
Min	.6602	.6668	.5658	.4904	.6413	.5281	.5658
Avg	.8785	.8206	.8048	.6821	.8795	.8233	.8323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 203 / 11 KV SIE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1524	.1509	.1524		.132	.1132
2	.132	.1524	.1509	.1715		.132	.1132
3	.132	.1334	.1509	.1334		.132	.1132
4	.132	.1334	.132	.1524		.132	.1132
5	.132	.1334	.1509	.1524		.132	.1132
6	.1509	.1334	.1509	.1715		.1509	.1132
7	.1698	.1334	.1509	.1509		.1509	.1132
8	.1132	.1524	.132	.1132		.1132	.1132
9	.4515	.3567	.5716		.442	.6859	.5719
10	.4877	.4012	.6668		.503	.6668	.602
11	.5335	.2824	.7049		.5639	.724	.602
12	.5182	.3418	.6287		.5487	.7049	.5498
13	.4877	.3418	.5716		.5487	.7049	.4904
14	.4515	.3567	.5144		.5487	.6859	.4755
15	.4365	.3715	.4572		.5335	.6668	.4904
16		.3715	.5335		.5268		.4904
17	.0953	.1132	.0943		.1132	.1132	.1334
18	.0762	.1132	.132		.132	.132	.1334
19		.132	.1509		.132	.1509	.1524
20		.132	.1698		.1698	.1509	.1524
21	.1524	.1509	.1509		.1698	.1509	.1524
22	.1524	.1509	.1509		.1509	.1509	.1524
23	.1524	.1509	.1509		.1509	.1509	.1524
24	.1509	.1524	.1509	.1524		.1509	.1509
Max	.5335	.4012	.7049	.1715	.5639	.724	.602
Min	.0762	.1132	.0943	.1132	.1132	.1132	.1132
Avg	.2495	.2101	.2904	.1500	.3489	.3072	.2649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 205 / 11 KV COTTON MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.2193	1.2826	1.2826		1.2826	1.226
2	1.3203	1.2193	1.2449	1.2826		1.2826	1.2449
3	1.3203	1.2193	1.2449	1.2826		1.2826	1.2449
4	1.3203	1.2384	1.1694	1.2826		1.2826	1.2449
5	1.3203	1.2384	1.1694	1.2826		1.2826	1.2449
6	1.3014	1.2574	1.1694	1.2826		1.2826	1.2449
7	1.2449	1.2574	1.1694	1.1883		1.226	1.2449
8	1.2071	1.2574	1.2826			1.2826	1.2071
9		1.3769	1.3336		1.3957		1.4335
10		1.5278	1.5051		1.5089		1.4523
11		1.5844	1.5432		1.5466	.9526	1.5844
12		1.4901	1.4289		1.4335	1.2384	1.3957
13		1.3957	1.3336		1.358	1.3146	1.3769
14		1.4712	1.4289		1.3769	1.3908	1.4146
15	1.7147	1.4901	1.5242		1.3957	1.5051	1.6409
16		1.4523	1.467		1.3957		1.5844
17		1.4335	1.4335		1.4146	1.4146	1.5623
18	1.3717	1.3957	1.4146		1.3957	1.358	1.5242
19	1.4098	1.3392	1.4146		1.4146	1.3203	
20		1.358	1.226		1.2826	1.2826	1.2003
21	1.2955	1.3203	1.2826		1.226	1.3014	1.2193
22	1.2574	1.3203	1.3014	1.1812	1.3014	1.2826	1.2384
23	1.2574	1.3203	1.3014	1.2003	1.3014	1.2449	1.2384
24	1.3203	1.1812	1.3203	1.2826		1.2826	1.226
Max	1.7147	1.5844	1.5432	1.2826	1.5466	1.5051	1.6409
Min	1.2071	1.1812	1.1694	1.1812	1.226	.9526	1.2003
Avg	1.3321	1.3485	1.3330	1.2548	1.3832	1.2901	1.3476

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 201 / 11 KV OM COLD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1653	1.0151	1.0517	2.1868	.599	1.9107	1.986
2	2.1047	.9846	.9526	2.1505	.599	1.8766	1.9372
3	2.1178	1.0334	1.041	1.9693	.6523	1.7711	1.9669
4	1.9907	1.0578	.9511	1.8347	.6462	1.7966	1.9601
5	1.9785	.9297	.9267	1.7223	.6142	.9968	1.986
6	1.9791	1.0181	.852	1.4472	.6158	1.7736	1.8854
7	2.13	1.102	1.1142	1.3698	1.217	1.7724	2.2383
8	2.2167	2.3548	1.0578	1.3929	1.2758	1.8275	2.0202
9	2.4569	2.2204	1.169	.7727	1.7071	2.1361	1.0319
10	2.8172	2.6494	1.4022	1.6041	2.2816	2.3613	2.5362
11	2.9336	2.7027	1.5287	.8093	2.6406	2.6189	2.7252
12	2.8955	2.5627	2.9531	.7819	1.3672	2.3371	2.7138
13	2.5547	2.6886	1.5059	.6889	1.3077	2.0784	1.3138
14	2.5416	2.3806	1.23	.6965	1.1401	1.0334	2.4295
15	2.9653	1.8983	1.4784	.7087	2.7572	1.23	1.3794
16	3.0996	2.2742	1.5165	.7148	2.7572	1.1827	2.6505
17	1.4342	1.23	2.8336	.7057	2.5893	2.1453	2.8332
18	1.5684	1.3032	1.419	.7179	1.3032	2.239	2.4754
19	2.4364	1.2696	2.5939	.7194	2.9388	2.3121	2.1887
20	1.2071	1.1599	1.2818	.6996	2.2176	2.1133	2.1281
21		.9938	2.0636	.6645	2.0671	1.9143	1.0319
22	.381	1.0105	2.1435	.6508	2.01	1.9875	2.0044
23	1.9677	1.0928	2.2252	1.2102	1.0059	2.1682	2.0788
24	.9877	1.1142	2.2054	.5898	1.8099	1.0776	2.0751
Max	3.0996	2.7027	2.9531	2.1868	2.9388	2.6189	2.8332
Min	.381	.9297	.852	.5898	.599	.9968	1.0319
Avg	2.1274	1.5853	1.5624	1.1170	1.5883	1.8609	2.0657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 202 / 11 KV KVC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2136	.5136	1.1164	1.8534	.7689	2.2712	1.9883
2	2.2298	.9381	1.1393	1.7951	.7712	2.2318	2.0469
3	2.1737	.932	1.1683	1.7116	.7758	2.2489	1.9212
4	2.1691	1.1614	1.1606	1.7181	.7552	2.277	1.8907
5	2.1734	1.1751	1.1515	1.624	.759	2.307	1.9928
6	2.2674	1.1446	1.1111	1.6164	.929	2.1915	2.0126
7	2.311	1.1507	1.1233	1.6729	1.6012	2.3105	2.1026
8	2.2613	2.588	1.2536	1.62	1.6941	2.6667	2.361
9	2.5787	2.7781	1.1111	.7971	2.4097	3.3395	1.4228
10	3.4768	3.244	1.4091	1.4922	3.0727	3.8542	3.6336
11	3.4286	3.2274	1.4739	.7377	3.4873	3.8169	3.642
12	3.4149	3.3181	2.8486	.7506	1.9113	4.0981	3.5117
13	3.3358	3.2293	1.4205	.7674	1.8458	3.3016	1.8084
14	3.3771	3.1965	1.3794	.7499	1.6072	1.7269	3.1284
15	3.5928	3.6526	1.5325	.7895	3.7753	1.8976	1.9014
16	3.5008	3.7466	1.4998	.8017	3.5826	1.9639	3.6329
17	1.7749	1.7924	2.6699	.8002	3.6001	3.5543	3.6616
18	1.4289	1.5859	1.3481	.7926	1.5402	2.793	3.2006
19	2.7366	1.4655	2.2321	.8032	2.9304	2.7625	3.1219
20	1.2209	1.2673	1.0128	.8093	2.091	2.3671	2.8482
21	.003	1.2239	1.9544	.788	2.3783	2.2618	2.4987
22	.3041	1.2483	1.9068	.759	2.4004	2.2512	2.3469
23	.9831	1.1317	1.7785	1.5105	2.3986	2.0561	2.4478
24	.5098	1.1546	1.8052	.7788	2.2546	1.0433	2.42
Max	3.5928	3.7466	2.8486	1.8534	3.7753	4.0981	3.6616
Min	.003	.5136	1.0128	.7377	.7552	1.0433	1.4228
Avg	2.2278	1.9527	1.5253	1.1475	2.0558	2.5664	2.5643

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 203 / 11 KV DIAMOND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4057	1.3893	1.4502	2.2228	.6066	2.3562	2.6436
2	2.3083	1.2376	1.3474	2.1716	.5929	2.4485	2.6131
3	2.2954	1.4411	1.3763	2.247	.628	2.4345	2.6429
4	2.4482	1.4388	1.3984	2.2764	.5868	2.6067	2.5171
5	2.5855	1.4502	1.2521	2.2668	.2561	2.6722	2.4958
6	2.7936	1.3702	1.2734	2.7551	.2561	2.8266	2.3991
7	2.68	1.4601	1.3466	2.6071	.4831	2.9147	2.809
8	2.6975	3.1611	1.4319	2.1567	.4961	2.2567	2.3114
9	2.6421	3.3632	1.3367	1.1332	2.2161	3.0796	1.3695
10	2.8743	3.1377	1.4007	.4618	2.6261	3.3446	3.2487
11	2.979	3.9855	1.5043	.2446	3.1528	3.485	3.4393
12	2.6117	4.0842	2.6086	.2477	1.5935	2.7776	3.1581
13	2.4169	3.8753	1.4098	.2393	1.5524	3.0423	1.659
14	2.7688	3.3164	1.4609	.2462	1.4441	1.5927	3.1025
15	2.9751	3.8759	1.1767	.2454	2.4943	1.6072	1.5127
16	3.0205	3.9003	1.2628	.2454	2.9317	1.6918	3.0415
17	1.4457	1.7962	2.7856	.2462	3.0287	3.2937	3.3936
18	1.5242	1.8564	1.4617	.2614	1.4396	3.1901	3.2829
19	2.4364	1.6598	2.9696	.266	2.9531	3.2838	3.4109
20	1.4083	1.5348	1.4662	.266	2.1858	2.4539	3.0067
21	1.2574	1.3618	2.6164	.2576	2.7957	2.8242	1.5676
22	1.1767	1.3832	2.6823	.4557	2.7984	2.5453	2.9328
23	2.1399	1.5318	2.8271	.8276	2.8405	2.3868	3.0868
24	1.3184	1.3801	2.2851	.6249	2.339	1.464	2.873
Max	3.0205	4.0842	2.9696	2.7551	3.1528	3.485	3.4393
Min	1.1767	1.2376	1.1767	.2393	.2561	1.464	1.3695
Avg	2.3004	2.2913	1.7555	1.0405	1.7624	2.6074	2.6882



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 204 / 11KV NATRAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5535	1.1744	1.1629	2.5246	.7697	2.7648	2.636
2	2.3499	1.1972	1.1652	2.508	.7453	2.6867	2.5872
3	2.4348	1.137	1.1401	2.4169	.7415	2.6322	2.5453
4	2.3575	1.0905	1.0768	2.3838	.7506	2.5709	2.4424
5	2.2386	1.0174	1.07	2.3049	.7476	2.5455	2.4943
6	2.3212	1.0517	1.1058	2.475	.7796	2.6227	2.6291
7	2.2377	1.0349	1.1157	2.2445	1.5379	2.4535	2.5492
8	2.0824	1.9395	1.038	1.8128	1.5074	2.2039	2.7549
9	2.4744	2.4318	1.2483	.7872	2.8708	2.7446	1.6789
10	2.9424	3.301	1.72	1.4152	3.9613	3.6136	4.0329
11	3.7102	3.5159	1.8	.7194	4.1007	4.2079	4.3888
12	4.095	3.5181	3.3517	.7095	2.162	4.0893	4.3675
13	3.5784	3.3223	1.7132	.7583	1.9235	3.5362	2.1536
14	3.4866	3.4501	1.861	.8192	1.8221	2.0104	3.8043
15	3.8098	3.8222	1.9646	.7933	3.9308	2.2207	2.2794
16	4.1148	3.7043	1.8892	.7964	3.9895	2.1155	4.2897
17	2.1338	1.9364	3.954	.7895	4.1687	4.3385	4.2238
18	2.1003	1.9608	1.858	.7971	2.1125	4.0878	3.7189
19	2.6269	1.6659	3.1567	.8391	3.4438	3.6519	3.3604
20	1.3588	1.6362	1.5905	.833	3.2548	3.3364	3.4429
21	.0221	1.3824	2.8376	.8833	3.2053	2.857	2.8113
22	.1936	1.2155	2.6069	.7819	3.1575	2.745	2.8703
23	1.3664	1.2071	2.5524	1.4198	2.8463	2.7016	2.77
24	1.1264	1.1294	2.5206	.7743	2.712	1.3291	2.6777
Max	4.1148	3.8222	3.954	2.5246	4.1687	4.3385	4.3888
Min	.0221	1.0174	1.038	.7095	.7415	1.3291	1.6789
Avg	2.4048	2.0351	1.8958	1.3578	2.3851	2.9194	3.0629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 205 / 11 KV OMKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.954	1.7139	1.7703	3.5425	.8985	3.7976	3.8272
2	3.8243	1.973	2.0744	3.7662	.9503	3.7098	3.4469
3	3.2575	1.454	1.8732	3.1828	1.0105	3.6675	3.5589
4	3.6092	1.6507	1.9014	3.4945	.996	3.722	3.1535
5	3.6774	1.7436	1.9906	3.2107	1.0943	3.3411	3.5299
6	3.1969	1.9006	1.9707	3.5738	1.0806	3.7622	3.1504
7	3.0969	1.8915	2.0203	2.4969	1.983	3.0695	3.956
8	3.2722	3.4316	1.8328	1.4097	2.1765	3.1739	3.2442
9	2.7476	3.7722	1.275	.6683	2.7244	3.3543	1.653
10	3.1209	3.5654	1.7452	1.2528	3.7167	3.1051	3.6191
11	3.5219	3.9624	2.3602	.6325	3.091	2.9535	3.722
12	3.0569	4.296	4.35	.6188	1.7261	4.0891	4.0787
13	4.3057	3.8956	2.2885	.5822	2.1293	3.2994	2.2154
14	4.369	4.0043	1.9951	.6607	2.0378	1.7543	4.2219
15	3.5359	4.0703	2.4341	.647	4.5968	2.066	2.2961
16	4.8615	4.2666	2.5225	.6356	4.228	1.9989	4.27
17	2.4227	1.9928	2.7193	.6356	3.7361	3.2846	4.0543
18	1.8031	1.8755	1.8069	.6562	1.7414	3.5285	3.553
19	3.5071	1.8145	3.4859	.6592	3.4014	2.6704	3.2779
20	1.7436	1.7993	1.4914	.6554	3.3488	3.4705	3.4454
21	1.2955	1.643	3.4399	.6996	3.1476	2.7221	2.7389
22	1.7017	1.8915	3.3869	.8253	3.3471	4.116	3.8055
23	3.7334	1.7749	3.2708	1.4472	3.7285	3.373	3.9684
24	1.7444	2.0782	3.3913	.9678	3.1941	1.9456	3.4699
Max	4.8615	4.296	4.35	3.7662	4.5968	4.116	4.27
Min	1.2955	1.454	1.275	.5822	.8985	1.7543	1.653
Avg	3.1400	2.6026	2.3915	1.5384	2.5035	3.1656	3.4274

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 206 / 11 kv Adimaya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449			1.1694		1.1694	1.2955
2	1.2071			1.1317		1.1317	1.2574
3	1.2071			1.1317		1.1694	1.2193
4	1.1883			1.094		1.2071	1.2003
5	1.1694			1.094		1.2449	1.2765
6	1.1506			1.0751		1.226	1.3717
7	1.1694			1.0562	.9335	1.1883	1.3336
8	1.1883	.1524		1.0374	.9145	1.3203	1.4289
9	1.5089				1.5432	1.7353	
10	1.8484	.3772		.8573	1.9433	1.9239	1.9052
11	1.7353	.3206			2.0957	2.0559	1.6385
12	1.5466	.1509	1.6194			2.0559	1.6956
13	1.6409	.1509				1.905	
14	1.6032	.3772					1.5051
15	1.5089	.3395			2.1148		
16	1.6032	.3206			1.9243		1.6766
17			1.773		1.9239	2.191	1.8296
18						1.6385	1.6975
19	1.467		1.3392		1.4146	1.467	1.5655
20					1.226	1.3336	1.4523
21			1.1317		1.2071	1.2574	1.094
22			1.3014		1.4901	1.3146	1.2637
23	.1524		1.2826	.9145	1.3769	1.3527	1.2826
24			1.1506		1.2449		1.3203
Max	1.8484	.3772	1.773	1.1694	2.1148	2.191	1.9052
Min	.1524	.1509	1.1317	.8573	.9145	1.1317	1.094
Avg	1.3411	.2737	1.3711	1.0561	1.5252	1.4944	1.4433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 207 / 11 kv mandhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6541	1.012	1.2163	2.6706	.7034	2.4568	2.511
2	2.544	.9587	1.1835	2.5964	.6699	2.4752	2.4752
3	2.5436	1.1187	1.1888	2.5107	.692	2.452	2.4181
4	2.4211	1.1584	1.1485	2.3152	.7156	2.3647	2.2733
5	2.4046	1.1843	1.1873	2.311	.7194	2.1382	2.287
6	2.2233	1.1934	1.1706	2.2167	.7186	2.4031	2.2627
7	1.9629	1.1881	1.1706	1.7973	1.3939	2.3947	2.5621
8	2.7008	2.3678	1.153	1.4272	1.3985	2.2803	2.4074
9	3.3665	3.3107	1.5485	.6683	3.027	3.3024	1.5127
10	3.4238	3.6685	1.8503	1.2773	3.2952	3.9175	3.5406
11	3.6339	4.1002	2.0309	.5502	4.1275	3.7555	3.7898
12	3.6033	4.1825	3.9613	.4489	2.0195	3.9569	4.119
13	3.2209	3.468	1.8473	.471	1.9601	3.6446	1.9707
14	3.5498	3.5011	1.6179	.4626	1.8595	1.8038	3.4316
15	3.646	3.5858	2.0911	.6744	3.6763	2.1033	1.9738
16	3.8927	3.6675	1.8183	.6783	3.9697	1.9974	3.3067
17	1.6446	1.9479	3.2446	.695	3.3499	3.3379	3.3168
18	1.9464	1.7734	1.6545	.6981	1.7581	3.8249	3.559
19	3.0072	1.7467	3.3147	.6889	3.3593	3.7959	3.6713
20	1.5257	1.643	1.4182	.695	3.4579	3.2816	3.12
21	.0343	1.5821	2.6919	.6615	2.6753	2.9447	2.946
22	1.0601	1.3862	2.519	.618	3.0174	2.7861	2.9544
23	1.9845	1.4182	2.4182	1.2262	2.8355	2.511	2.5614
24	1.0197	1.2262	2.1567	.6386	2.5188	1.2551	2.404
Max	3.8927	4.1825	3.9613	2.6706	4.1275	3.9569	4.119
Min	.0343	.9587	1.1485	.4489	.6699	1.2551	1.5127
Avg	2.5006	2.1829	1.9001	1.2082	2.2466	2.7993	2.8073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 208 / 11 KV Devika

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3906	.1791	.1905	.3588	.2324	.3436	.4314
2	.3974	.1814	.1974	.3535	.2324	.3512	.4107
3	.4035	.1867	.1905	.3535	.2324	.3497	.4016
4	.405	.1783	.1974	.3527	.2317	.3535	.3978
5	.4572	.1928	.1913	.3542	.2317	.3761	.4146
6	.4822	.2058	.205	.3806	.237	.4305	.477
7	.5051	.2218	.2218	.4624	.5243	.4437	.4618
8	.4801	.4916	.2454	.4816	.5068	.4027	.458
9	.4681	.4801	.25	.2545	.4801	.4294	.2423
10	.4508	.5438	.2774	.4458	.4855	.4393	.4694
11	.494	.5992	.2873	.25	.4702	.4325	.5274
12	.5106	.556	.5243	.2096	.2431	.4393	.5182
13	.5113	.5793	.2987	.2241	.2606	.4614	.2683
14	.4537	.5499	.2995	.2263	.2423	.2683	.4474
15	.4765	.5793	.2865	.2263	.5258	.2766	.2774
16	.4652	.5712	.314	.2126	.5228	.2614	.5106
17	.2797	.3193	.5636	.2126	.4778	.5289	.5287
18	.2964	.3307	.2873	.218	.2583	.5281	.5104
19	.519	.2919	.4892	.2187	.4875	.4603	.4831
20	.2561	.2469	.2462	.2263	.4454	.4786	.4595
21	.2004	.1898	.3618	.2263	.3814	.4633	.374
22	.1844	.1882	.3685	.2233	.355	.4618	.3262
23	.3514	.1875	.3504	.4138	.3413	.4397	.3481
24	.1791	.1905	.3519	.2309	.342	.2256	.3474
Max	.519	.5992	.5636	.4816	.5258	.5289	.5287
Min	.1791	.1783	.1905	.2096	.2317	.2256	.2423
Avg	.4007	.3434	.2998	.2965	.3645	.4019	.4205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 402 / 33 KV Shah Presicast Unit NON SHEDDABLE EXPRESS HV FEEDERS  
 III Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0493	.8573	.823	1.0836	.9945	1.0493	1.0916
2	1.1059	.8916	.823	1.0493	1.0288	1.1059	1.1145
3	1.1745	.9259	.8573	1.1745	1.0288	1.1402	1.1659
4	1.1745	.9602	.9259	1.1745	1.0288	1.2088	1.2117
5	1.1402	.9259	.8916	1.2088	1.0288	1.1745	1.1945
6	1.1745	.9602	.8916	1.2088	.9945	1.1745	1.1488
7	1.1745	.9602	.8916	1.2088	1.3146	1.1745	1.1659
8	1.1745	1.1774	.823	1.2088	1.2574	1.1179	1.1202
9	1.072	3.3179	.7888	.9259	1.1202	.9922	.7888
10	1.0604	4.3878	1.9204	1.2231	1.1546	1.0035	1.1317
11	1.1059	5.0858	3.4294	.9945	5.0697	2.0792	1.1317
12	1.0607	5.1201	5.0869	.9945	3.9781	3.0521	2.955
13	1.1063	3.8494	3.738	.9602	1.406	3.7723	3.6694
14	1.0836	1.7009	2.7092	.9945	2.8121	3.0864	4.9726
15	1.1059	1.1059	2.2634	.9945	4.5039	2.8464	3.8409
16	1.1063	4.2181	4.4239	.9945	3.5779	3.0864	2.7549
17	.7545	3.6694	4.88	.9945	4.014	3.4523	1.0151
18	.8916	3.6694	1.3717	1.0288	3.2236	3.1093	1.0151
19	1.1774	3.738	1.0836	.9945	1.0836	1.1431	1.0151
20	.8916	1.5775	.8573	.9945	1.0493	1.1431	1.0836
21		.8916	1.2088	.9945	1.1745	1.1316	1.0836
22	.7545	.8573	1.1745	.9945	1.1059	1.1088	1.1402
23	1.1545	.8573	1.1402	1.3146	1.0493	1.1545	1.0493
24	.9259	.8916	1.0493	.9945	1.0836	.8573	1.1179
Max	1.1774	5.1201	5.0869	1.3146	5.0697	3.7723	4.9726
Min	.7545	.8573	.7888	.9259	.9945	.8573	.7888
Avg	1.0617	2.1915	1.8355	1.0712	1.9201	1.7568	1.6241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 201 / 11 KV Mahavir

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)
1	.1524	.0762
2	.0762	.0762
3		.0762
4		.0762
5		.0762
6		.0762
7		.0762
8		.0762
9		.1524
10		.1524
11		.1524
12		.1524
13		.1524
14		.1524
15		.1524
16		.1524
17		.1524
18		.1524
19		.1524
20		.1524
21		.1524
22		.1524
23		.1524
24		.1524
Max	.1524	.1524
Min	.0762	.0762
Avg	.1143	.127

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 202 / DATTANAND FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6859	.7621	.7621	.7621	.7621	.7621
2	.7621	.7621	.7621	.7621	.7621	.7621	.7621
3	.7621	.7621	.8383	.7621	.7621	.7621	.7621
4	.8383	.7621	.8383	.7621	.7621	.8383	.7621
5	.8383	.7621	.8383	.7621	.7621	.8383	.8383
6	.8383	.7621	.8383	.7621	.7621	.8383	.7621
7	.7621	.7621	.8383	.7621	.7621	.8383	.7621
8	.8383	.7621	.8383	.7621	.7621	.9145	.8383
9	.8383	.8383	.8383	.8383	.7621	.9145	.9145
10	.9145	.9145	.9145	.8383	.8383	1.0669	.9907
11	.9145	.9907	.9907	.7621	.9907	1.0669	1.0669
12	.9907	.9907	.9907	.7621	1.0669	1.1431	.9907
13	.9145	.9145	.8383	.7621	.9907	1.0669	.9907
14	.8383	.9145	.8383	.7621	.9145	.9907	1.0669
15	1.0669	.9907	.9145	.7621	1.0669	1.1431	1.0669
16	.9907	.8383	.9145	.7621	.9907	1.0669	1.0669
17	.9907	.8383	.9145	.7621	.9907	.9907	.9907
18	.9145	.7621	.7621	.7621	.9145	.9145	.9145
19	.8383	.7621	.7621	.7621	.8383	.8383	.8383
20	.7621	.7621	.7621	.7621	.8383	.7621	.8383
21	.7621	.7621	.7621	.6859	.8383	.8383	.7621
22	.6859	.7621	.7621	.7621	.7621	.7621	.7621
23	.6859	.7621	.7621	.7621	.7621	.7621	.7621
24	.6859	.7621	.7621	.7621	.7621	.7621	.7621
Max	1.0669	.9907	.9907	.8383	1.0669	1.1431	1.0669
Min	.6859	.6859	.7621	.6859	.7621	.7621	.7621
Avg	.8415	.8161	.8351	.7653	.851	.9018	.8764



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 203 / 11 KV Godavari

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	1.2193	.9145	1.2193	.6097	1.0669	1.2193
2	.7621	1.2193	.9145	1.2193	.6097	.9145	1.2193
3	.7621	1.2193	.9145	1.2193	.4572	.9145	1.2193
4	.6097	1.2193	.7621	1.2193	.4572	.9145	1.2193
5	.6097	1.2193	.9145	1.2193	.6097	.9145	1.2193
6	.7621	1.2193	.9145	1.2193	.6097	1.0669	1.3717
7	.7621	.9145	.9145	.9145	.6097	.9145	1.0669
8	.9145	.9145	.9145	.6097	.6097	.9145	1.0669
9	1.0669	1.0669	1.0669	.6097	1.0669	1.2193	1.2193
10	1.3717	1.2193	1.3717	.6097	1.2193	1.3717	1.5242
11	1.3717	1.6766	1.3717	.6097	1.3717	1.5242	1.829
12	1.5242	1.829	1.3717	.6097	1.3717	1.5242	1.829
13	1.5242	1.6766	1.2193	.6097	1.5242	1.3717	1.829
14	1.3717	1.2193	1.0669	.6097	1.5242	1.2193	1.6766
15	1.5242	1.6766	1.2193	.6097	1.6766	1.5242	1.6766
16	1.5242	1.6766	1.2193	.6097	1.829	1.5242	1.829
17	1.3717	1.6766	1.3717	.6097	1.6766	1.5242	1.829
18	1.3717	1.2193	1.2193	.4572	1.829	1.3717	1.6766
19	1.0669	1.0669	1.0669	.4572	1.2193	1.0669	1.2193
20	1.0669	.9145	1.0669	.4572	1.0669	1.0669	1.0669
21	.6097	.7621	.7621	.4572	.9145	.9145	.9145
22	.9145	.7621	.7621	.6097	.9145	.9145	.9145
23	.9145	.9145	1.2193	.6097	.9145	1.3717	1.3717
24	1.2193	.9145	1.3717	.6097	1.0669	1.2193	1.2193
Max	1.5242	1.829	1.3717	1.2193	1.829	1.5242	1.829
Min	.6097	.7621	.7621	.4572	.4572	.9145	.9145
Avg	1.0733	1.2257	1.0796	.7494	1.0733	1.1812	1.3844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 401 / 33 KV Parvati Agro Plast      NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2174	1.286	2.1091	.7545		2.2291	1.1831
2	1.406	1.3203	1.8347	.7888		2.2462	1.1317
3	1.3546	1.1145		.7373		2.1605	.9602
4	1.3546	1.5261	.8059	.7716		1.869	.9431
5	1.4575	1.1317	1.2174	.7545		1.7833	.6687
6	1.5604	1.0117	1.5947	.6687		1.9204	.6516
7	1.2003	.8745	1.5432	.6344		1.869	.6173
8	.9088	.8402	1.3717	.463		1.5089	.6173
9	.9259	.6859	1.3717		.3429	1.6461	.703
10	1.1317	.8059	1.2346		.3601	1.7318	.7545
11	1.0631	.9431	1.2517		.2743	1.749	.823
12	1.3375	1.0631	1.4575		.1715	1.9204	.9602
13	1.9376	1.0117	1.4746		.9259	1.7833	1.3546
14	1.8519	1.1145	1.3717		.7373	1.8004	1.3546
15	1.7318	1.1145	1.3717		.6687	1.7833	1.4746
16	1.8004	1.4403	1.2003		.8059	2.0233	1.8347
17	1.5432	1.3717	1.4403		.9431	2.1091	1.9719
18	1.4746	1.3717	.0171		1.0802	2.1605	1.8519
19	1.3203	1.1145	1.0117		1.3889	2.0576	1.7833
20	1.1145	1.5432	1.1831		1.5432	2.0748	1.5604
21	.4458	1.4403	.9945		1.8519	1.5432	.9088
22	.6516	1.5432	.8059		1.9719	1.3546	.8059
23	.8745	1.5947	.703		2.2291	1.3717	.9088
24	1.1317	1.7833	.7545		2.3148	1.3546	.8916
Max	1.9376	1.7833	2.1091	.7888	2.3148	2.2462	1.9719
Min	.4458	.6859	.0171	.463	.1715	1.3546	.6173
Avg	1.2832	1.2103	1.2226	.6966	1.1006	1.8354	1.1131

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 404 / 33KV BASHKO

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)
1	.583	1.9719
2	1.1831	2.2462
3	2.0919	2.1605
4	2.2462	3.6694
5	2.2119	3.1722
6	3.6351	2.1434
7	4.0981	2.0062
8	2.9664	2.1948
9	2.2119	2.1091
10	2.1434	2.1948
11	2.7949	2.7092
12	2.5034	2.2977
13	.7202	2.5549
14	3.8752	2.8292
15	3.9781	3.7037
16	3.8066	4.0809
17	4.0295	3.7209
18	3.9781	3.5494
19	3.738	3.2579
20	3.8752	3.4294
21	3.3779	3.4465
22	3.8237	2.0405
23	2.5206	2.3663
24	2.2462	2.1434
Max	4.0981	4.0809
Min	.583	1.9719
Avg	2.8599	2.7499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 201 / 11 KV Ankur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8882	.6493	.8627	.8841	.6584	1.1332	.9755
2	.8748	.6363	.7773	.9137	.6516	1.1637	.9846
3	.8474	.6477	.7156	.8871	.6524	1.1576	.9312
4	.8428	.6668	.6851	.6066	.6569	1.1492	.82
5	.82	.692	.708	.8672	.6759	.9869	.7468
6	.7949	.8405	.6897	.8535	.6401	.9084	.7125
7	1.0836	.8764	.8535	.7819	.637	.7773	1.1904
8	1.1248	1.0223	1.0547	.6858	.7339	.897	1.7097
9	1.7528	1.4331	1.6324	.6882	1.262	1.3657	2.4005
10	1.9494	1.797	2.0706	.7088	1.7703	1.7993	2.8471
11	1.8305	1.0204	1.906	.6889	2.0728	1.954	2.7587
12	1.8054	.0869	2.034	.8078	1.7985	2.0805	2.5797
13	1.7832	1.5547	1.6102	.6973	1.5348	1.8618	2.6696
14	1.8353	1.6842	1.8053	.644	1.9319	2.4882	2.6902
15	2.0645	2.1079	1.6903	.6714	2.1224	2.6459	2.5431
16	1.0936	2.2162	2.1902	.631	1.0418	2.3956	2.7953
17	.913	1.6941	1.5569	.6539	1.9772	1.3093	2.9927
18	1.6179	1.7155	1.6317	.628	1.9661	1.3466	3.2876
19	1.5455	1.3641	1.5867	.6234	1.6808	1.3634	3.1687
20	.8032	1.0311	1.3195	.615	1.6275	1.3336	2.8194
21	.4337	.8879	1.2787	.5929	1.2902	1.4777	2.6848
22	.8085	.8429	.7484	.5807	1.2658	.7438	1.4563
23	.8231	.887	1.1873	.5769	1.1728	1.158	2.2657
24	.8018	.682	1.0554	.9412	.7461	1.1111	1.3321
Max	2.0645	2.2162	2.1902	.9412	2.1224	2.6459	3.2876
Min	.4337	.0869	.6851	.5769	.637	.7438	.7125
Avg	1.2141	1.1265	1.3188	.7179	1.2736	1.4420	2.0568

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 202 / 11 KV LOKMAT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0775	.9225	.9937	.9282	.7339	1.0692	1.0753
2	1.0304	1.0121	.9252	.4908	.7888	.9922	1.0563
3	.9907	1.0135	.8848	.8319	.7865	.9297	.9991
4	.9031	1.0059	.8695	.8017	.8124	.91	.9915
5	.8871	1.006	.8756	.817	.8589	.8969	.9922
6	.865	.9061	.9076	.767	.9259	.8855	1.0181
7	.999	.9236	1.0193	.7095	.9511	.8673	1.0471
8	1.0356	.9481	.9762	.6893	.9686	.9298	1.1515
9	1.829	1.6057	1.7879	.6828	1.5295	1.0463	1.8096
10	2.415	2.0675	2.2824	.4633	2.1514	2.386	2.3921
11	2.7435	1.1043	2.4683	.4717	2.2055	2.697	2.553
12	2.5389	.0084	2.6422	.7941	2.3853	2.5354	2.3083
13	2.2923	1.3893	2.2931	.8117	1.9174	2.1514	2.0416
14	2.2893	2.066	1.201	.4458	2.2901	2.2207	2.0439
15	2.6741	2.1124	2.5301	.4588	1.2209	2.4989	2.1521
16	1.3801	2.2085	2.5682	.4847	1.278	2.7145	2.2816
17	1.2681	2.0226	2.4097	.4748	2.4272	1.3253	2.1834
18	2.21	2.0092	2.0515	.4664	2.0546	1.1675	1.9662
19	1.8809	1.6049	1.7406	.4649	1.6659	.9534	1.695
20	.8642	1.3901	1.528	.4725	1.5988	.836	1.5257
21	.8909	1.1614	1.3489	.4542	1.3436	1.3108	1.355
22	.8973	1.0539	.6706	.4291	1.2338	.6493	1.2288
23	1.0517	1.0349	1.1641	.4679	1.2106	1.1424	1.2323
24	1.105	1.0349	1.7002	.7171	.9001	1.1451	1.1957
Max	2.7435	2.2085	2.6422	.9282	2.4272	2.7145	2.553
Min	.8642	.0084	.6706	.4291	.7339	.6493	.9915
Avg	1.5049	1.3172	1.5766	.6081	1.4266	1.4275	1.5956

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 206 / 11 KV MIDC Water Supply

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377		.0377	.0377	.0377	.0377	
2	.0377		.0377			.0377	.0377
3	.0377		.0377	.0377	.0377	.0377	.0377
4	.0377		.0377	.0377	.0377	.0377	.0377
5	.0377		.0377		.0377	.0377	.0377
6	.0377		.0377	.0377	.0377	.0377	.0377
7	.0377		.0377			.0377	
8	.0377		.0377	.0377	.0377	.0377	.0377
9			.0377	.0377	.0377	.0377	.0377
10		.0377	.0377		.0377	.0377	.0377
11		.0377	.0377		.0377	.0377	.0377
12		.0377	.0377	.0377	.0377	.0377	.0377
13		.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377		.0377	.0377	.0377
15	.0377	.0377	.0377		.0377	.0377	.0377
16	.0377	.0377	.0377			***	.0377
17	.0377	.0377	.0377		.0377		.0377
18	.0377	.0377	.0377				.0377
19	.0377	.0377	.0377		.0377		.0377
20		.0377	.0377		.0377		.0377
21		.0377	.0377		.0377	.0377	.3772
22		.0377			.0377		
23		.0377	.0377		.0377	.0377	.0377
24	.0377		.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	51.2278	.3772
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.0377	.0377	2.7319	.0539

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 207 / 11 KV Bharat Steel

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2972	.2424	.2324	.237	.266	.2302	.234
2	.3018	.2393	.2423	.2347	.2606	.2363	.25
3	.3033	.237	.2446	.2431	.2606	.24	.234
4	.3087	.2386	.2446	.2362	.2675	.2355	.2355
5	.2896	.2386	.253	.2362	.2599	.2561	.2355
6	.2934	.2584	.2565	.234	.2431	.25	.2622
7	.3543	.2374	.2466	.2385	.2332	.2409	.245
8	.5038	.5796	.4854	.2492	.5464	.5819	.6448
9	1.0997	2.6178	1.4625	.2324	3.2861	1.0894	1.4384
10	2.6901	2.7012	2.6543	.2416	3.4309	2.6177	1.7894
11	2.7892	2.4729	2.7046	.2279	1.5104	2.575	2.5529
12	1.9814	2.6817	2.9066	.2363	1.3649	1.8419	2.4558
13	2.4882	2.6414	2.5621	.2408	.3543	1.2613	2.13
14	2.428	2.6497	2.6314	.237	.4238	2.2947	2.5956
15	2.652	2.7275	2.7892	.2362	.4782	2.3846	2.7374
16	1.1843	2.5651	2.0347	.2317	1.1203	1.2589	2.5164
17	2.6612	2.5979	2.1391	.2416	2.431	.852	2.5423
18	2.652	1.3039	2.1201	.2446	2.3236	1.0014	2.7168
19	2.6394	2.4143	2.5721	.2507	2.668	1.1744	3.0186
20	2.5179	2.7062	2.3674	.2309	2.7016	.9625	1.4159
21	.2424	2.4562	1.0403	.2408	2.6718	1.1142	.3269
22	.2378	.663	.2462	.2583	1.2841	.2271	.2782
23	.2294	.2362	.2393	.2568	.247	.256	.2766
24	.2363	.221	.2454	.2652	.231	.2439	.2293
Max	2.7892	2.7275	2.9066	.2652	3.4309	2.6177	3.0186
Min	.2294	.221	.2324	.2279	.231	.2271	.2293
Avg	1.3076	1.4970	1.3717	.2409	1.2027	.9761	1.3067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 208 / 11 KV Ashtavinayak

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
15	.3772
Max	.3772
Min	.3772
Avg	.3772



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 201 / 11 KV MIRAJ CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6088	3.1604	3.1572	3.1514	1.6712	3.3028	3.4438
2	3.4355	3.0171	3.0133	3.0422	1.6072	3.1931	3.2841
3	3.3445	2.9157	2.9439	2.9447	1.5546	1.5973	3.2249
4	3.2658	2.8745	2.8967	2.8584	1.5188		3.1619
5	3.1863	2.8209	2.8075	2.7862	1.5021	2.07	3.1112
6	3.2914	2.9016	2.9515	2.8391	1.5501	2.0906	3.2734
7	3.3722	2.9569	2.966	2.9939	1.624	2.1559	3.3105
8	3.1505	2.9887	3.1626	2.9454	1.6499	3.3353	3.3278
9	3.1176	3.017	3.0918	2.8775	1.5996	3.1386	3.1543
10	3.3196	3.0337	2.9582	3.0118	3.2166	3.1313	3.0354
11	3.206	2.9668	2.7587	2.9278	3.267	2.9126	1.8396
12	3.2304	3.0009	2.6315	2.8418	3.1962	1.5348	3.1367
13	3.2221	3.0208	2.6116	2.773	3.024	1.1443	3.0828
14	3.1543	2.9876	2.5629	2.719	2.891	3.0921	2.8456
15	3.2015	2.8281	2.6048	1.403	2.9554	3.0517	2.8843
16	3.2159	2.9567	2.8062	1.4251	3.0456	3.1138	3.006
17	3.1795	2.9942	2.9592	1.733	3.1548	3.0156	2.8593
18	3.2091	3.1016	2.9653	1.6972	3.1143	3.1989	3.2594
19	1.829	3.5531	3.6786	1.8252	3.6803	3.8647	4.0398
20	1.9944	3.8961	3.4766	2.0858	2.1605	4.1267	4.3908
21	3.7317	3.9146	3.6065	2.05	4.153	4.1831	4.2789
22	3.7129	3.8639	3.6976	1.9669	4.0642	4.079	4.209
23	3.5917	3.7237	2.4486	1.9456	3.8561	3.9072	3.9872
24	3.6149	3.3158	3.4049	3.3275	3.5269	3.6108	3.6764
Max	3.7317	3.9146	3.6976	3.3275	4.153	4.1831	4.3908
Min	1.829	2.8209	2.4486	1.403	1.5021	1.1443	1.8396
Avg	3.2161	3.1588	3.0067	2.5071	2.6493	2.9935	3.3260

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 204 / 11 KV MEDICAL COLLEGE  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3677	.1646	.1448	.1448		.3178	.1848
2	.1612	.1463	.1463	.128		.2987	.1629
3	.1629	.1463	.128	.1254			.1629
4	.1448	.1463	.128	.1063		.1372	.1433
5	.1578	.1294	.128	.1227		.1848	.1612
6	.1991	.1478	.2033	.1612		.1478	.1848
7	.2561	.1829	.2195	.181		.2012	.2378
8	.2353	.1629	.2195	.1433		.1595	.1663
9	.2926	.1928	.2378	.1991		.2303	.2743
10		.1991	.3142	.2378	.2957	.2835	.2454
11	.2926	.2103	.3109	.2303	.2926	.2303	.2804
12	.2743	.2126	.2896	.1543		.2658	.2629
13	.2561	.1928	.2507	.1417		.1949	.2427
14	.2195	.1448	.1991	.1991		.1772	.1886
15	.2743	.1646	.2378			.197	.2126
16	.2012	.1448	.2126			.197	.2507
17	.181	.1612	.1578			.1402	.1402
18	.1753	.1543	.181		.1886	.1417	.1526
19		.1595	.1829		.1734	.2172	.197
20		.1595	.1791			.2149	.197
21	.181	.1595	.1629		.197	.2012	.1991
22	.1829	.1595	.1402		.1829	.1991	.2012
23	.1829	.1629	.1402		.1829	.2012	.1829
24	.181	.1829	.1448	.1417	.128	.1829	.181
Max	.3677	.2126	.3142	.2378	.2957	.3178	.2804
Min	.1448	.1294	.128	.1063	.128	.1372	.1402
Avg	.2181	.1662	.1941	.1611	.2051	.2053	.2005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 205 / 11KV Dairy Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1788	2.0502	1.9639	2.0131	1.0471	2.0218	2.0473
2	2.0325	1.937	1.8503	1.8827	.9602	1.9026	1.942
3	1.9571	1.8657	1.7901	1.8279	.897	1.8199	1.8533
4	1.8919	1.8208	1.713	1.7775	.8733	1.7682	1.7848
5	1.8076	1.7772	1.6659	1.7406	.8551	1.7221	1.7673
6	1.8431	1.7894	1.7549	1.736	.8665	1.7681	1.7189
7	1.8282	1.6381	1.7065	1.6692	.8863	1.7478	1.7078
8	1.6674	1.5996	1.5636	1.635	.8284	1.6187	1.637
9	1.8027	1.7158	1.6758	1.6882	.8352	1.6149	1.7202
10	2.1104	1.6711	1.9318	1.752	1.7467	1.8313	1.9117
11	2.1995	1.7867	1.8656	1.8645	1.9143	1.9738	2.1555
12	2.2779	1.8119	2.0671	2.0058	1.8988	2.1315	1.118
13	2.328	1.8523	2.2017	2.1342	1.9601	2.2459	2.215
14	2.3365	1.9698	2.2626	1.1195	2.1352	2.1468	2.1696
15	2.3453	1.922	2.2503	1.0654	2.2177	2.1427	2.1571
16	2.3596	1.8892	2.2268	1.0319	2.307	2.1647	1.9264
17	2.1894	1.8275	2.243	1.0707	2.1636	2.1062	1.6553
18	1.9483	1.769	2.1588	1.0585	2.0931	2.0987	2.1662
19	.9938	2.0709	2.3937	1.0166	2.3212	2.3308	2.3541
20	1.2833	2.2931	2.6017	1.2696	1.3314	2.6086	2.6587
21	2.4438	2.3263	2.5281	1.2574	2.5465	2.5419	2.5385
22	2.4723	2.2893	2.4355	1.2178	2.54	2.4027	2.4905
23	2.4066	2.3529	2.3022	1.2026	2.4157	2.4181	2.4174
24	2.2584	2.2409	2.1765	2.0972	1.1568	2.261	2.2634
Max	2.4723	2.3529	2.6017	2.1342	2.5465	2.6086	2.6587
Min	.9938	1.5996	1.5636	1.0166	.8284	1.6149	1.118
Avg	2.0401	1.9278	2.0554	1.5472	1.6166	2.0579	2.0157

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 206 / Vidya nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7	1.583	1.6111	1.5421	.7987	1.5358	1.6274
2	1.5509	1.5148	1.5615	1.4884	.74	1.4673	1.5302
3	1.5469	1.4813	1.4937	1.4571	.7247	1.4219	1.4757
4	1.5097	1.4347	1.4346	1.4071	.7087	1.4021	1.4244
5	1.5219	1.4308	1.4036	1.4093	.7011	1.4163	1.4165
6	1.7412	1.4898	1.456	1.4163	.7156	1.4626	1.3919
7	1.5234	1.4674	1.4695	1.3697	.7423	1.3979	1.4215
8	1.3538	1.3207	1.3049	1.2422	.6683	1.2414	1.2292
9	1.1799	1.2456	1.1309	1.1816	.5723	1.0989	1.1231
10	1.1399	1.1218	1.0326	1.1797	1.0539	1.0692	1.0864
11	1.1313	1.1195	1.0181	1.114	1.025	1.0028	1.1195
12	1.2083	1.138	1.0384	1.1119	1.0349	1.0235	1.1481
13	1.2237	1.129	1.0683	1.1085	1.009	1.1271	1.1805
14	1.2706	1.1511	1.1401	1.1652	1.0311	1.1325	1.1692
15	1.3074	1.1311	1.1721	.6241	1.2209	1.1721	1.198
16	1.2151	1.2186	1.1927	.6089	1.1623	1.1873	1.211
17	1.2437	1.1828	1.1688	.602	1.0882	1.1709	1.182
18	1.2857	1.1921	1.2152	.5723	1.1946	1.236	1.1786
19	.7933	1.6133	1.5718	.7011	1.5728	1.5512	1.64
20	.9114	1.8171	1.664	.8916	.9587	1.9067	1.9035
21	1.7233	1.8614	1.8288	.9214	1.8698	1.8972	1.8633
22	1.8913	1.8721	1.8218	.9122	1.888	1.9203	1.8704
23	1.8182	1.8711	1.8023	.9214	1.8646	1.9204	1.8206
24	1.7071	1.7267	1.7154	1.6134	.9175	1.7878	1.7286
Max	1.8913	1.8721	1.8288	1.6134	1.888	1.9204	1.9035
Min	.7933	1.1195	1.0181	.5723	.5723	1.0028	1.0864
Avg	1.3958	1.4214	1.3882	1.1067	1.0526	1.3979	1.4142

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 401 / 33 KV Bedag outgoing(  
Crossove Feeder KV- 33 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	23.083	15.2664	19.616	23.7254	21.2907	20.9649	20.942
2	22.6337	14.7006	18.7357	21.948	10.5167	19.7789	20.2676
3	22.1822	14.6463	17.7413	20.4024	10.0595	19.5074	19.8103
4	21.5621	15.0806	17.0153	19.8932	10.0595	18.9958	18.5472
5	22.1582	15.8939	16.8541	21.0334	10.0595	19.5336	18.4397
6	25.1304	18.1802	19.7028	23.6809	10.974	23.6672	21.425
7	24.2159	19.9961	20.0103	25.5087	14.6319	28.7494	23.9597
8	8.0933	7.6886	6.9365	8.1458	5.0297	7.6063	6.8318
9	27.4166	22.1046	23.2237	26.0831	13.7174	25.8574	25.5693
10	29.1838	26.106	27.9104	27.6727	28.6311	27.8578	26.5644
11	25.0286	24.8606	27.2886	25.2378	23.3928	27.2337	27.8538
12	26.5403	21.1374	20.6991	15.272	28.1321	25.0114	28.155
13	28.4591	19.7394	24.1381	5.1623	28.6408	24.2199	24.5771
14	28.5322	26.2375	25.6945	5.2687	27.8213	25.9974	25.7602
15	29.9669	26.1363	26.5387	2.7435	27.6407	28.8037	26.9159
16	26.1832	26.4232	25.9431	9.6022	29.2193	20.3733	27.6229
17	7.0159	8.8454	8.0636	5.9442	8.9535	7.396	6.9541
18	5.7082	5.5127	5.6756	2.7435	5.6756	5.4544	5.3887
19	2.2862	6.39	6.7124	3.2007	6.4929	6.1328	6.4963
20	1.829	7.204	7.8761	3.658	4.1152	7.7686	7.8223
21	3.7357	7.1131	7.8618	3.658	7.8361	7.5171	7.6989
22	16.9182	23.1253	26.0174	12.8029	21.9565	24.9657	27.38
23	16.7238	22.748	26.637	12.8029	24.1284	23.9232	28.2945
24	20.1761	18.7386	22.4737	24.0078	22.5851	22.748	24.5702
Max	29.9669	26.4232	27.9104	27.6727	29.2193	28.8037	28.2945
Min	1.829	5.5127	5.6756	2.7435	4.1152	5.4544	5.3887
Avg	19.3651	17.2448	18.7236	14.5916	16.7317	19.5860	19.9103

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3688		.3948	.3536	.2568	.3292	.3681
2	.3102	.2766	.3452	.333	.2477	.3048	.3307
3	.3071	.3155	.3391	.333	.2462	.301	.3277
4	.3506	.3125	.3803	.3719	.2843	.3338	.3589
5	.3582	.3285	.3856	.3742	.2896	.333	.3582
6	.3826	.3422	.3765	.3727	.3147	.4283	.4115
7	.3826	.3452	.394	.3757	.3216	.4237	.3749
8	.4489	.4466	.4077	.423	.4077	.4984	.4633
9	.4748	.5098	.5205	.5685	.471	.5891	.5639
10	.583	.5601	.5578	.6455	.5662	.6417	.6409
11	.6577	.5944	.6142	.6592	.6005	.6661	.6767
12	.631	.5777	.6188	.6699	.5731	.6523	.5921
13	.522	.57	.6112	.7026	.5738	.6531	.5959
14	.1082	.5205	.6523	.6676	.5716		.6013
15	.5266	.5228	.5944	.6508	.5609		.5792
16	.5761	.5289	.6089	.6203	.5617	.6188	.5647
17	.6112	.567	.6287	.6371	.5898	.7263	.5975
18	.3422	.5838	.6158	.6295	.6234	.7133	.5274
19	.4329	.5388	.5632	.5815	.5578	.6775	.5563
20	.4443	.5357	.5327	.5472	.5388	.5738	.4321
21		.5304	.4748	.5365	.5502	.5274	.4557
22		.4877	.4611	.4809	.5144	.4778	.4435
23		.4146	.4146	.4176	.3955	.413	.3803
24		.4009	.4054	.3688	.3795	.4245	.3803
Max	.6577	.5944	.6523	.7026	.6234	.7263	.6767
Min	.1082	.2766	.3391	.333	.2462	.301	.3277
Avg	.4410	.4700	.4957	.5134	.4582	.5140	.4825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 205 / 11 KV JACKWELL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054		.1985	.1974	.1989	.2039	.3616
2	.2046		.197	.2012	.1962	.2084	.3708
3	.3666	.3746	.2545	.2862	.1943	.2065	.3704
4	.3658	.3742	.3719	.3677	.3593	.37	.3681
5	.3673	.3734	.3685	.3681	.3601	.3688	.3673
6	.378	.3776	.3719	.37	.3666	.3727	.37
7	.3871	.3795	.3791	.3746	.3776	.3788	.3742
8	.3612	.3807	.3624	.3711	.3829	.3574	.3738
9	.3673	.3666	.37	.3883	.3807	.3723	.3761
10	.3788	.3647	.3807	.3837	.3822	.386	.3803
11	.3723	.3647	.3871	.3837	.3696	.3791	.3624
12	.3662	.3681	.3795	.3715	.362	.3715	.3647
13	.3631	.3685	.3719	.3639	.3727	.3738	.3647
14	.3673	.3647	.3635	.3631	.3677	.3658	.3658
15	.3647	.3643	.3708	.3643	.3768		.365
16	.3673	.3692	.3708	.3662	.3734	.024	.3704
17	.2237	.3681	.3681	.3841	.3658	.3605	.3696
18	.3586	.3601	.3605	.3643	.3635	.3643	.3654
19	.3628	.3601	.3616	.362	.3647	.3635	.3647
20	.3673	.3631	.3658	.3673	.3673	.3628	.3681
21	.3647	.3589	.3654	.3681	.3662	.362	.3696
22		.3711	.3799	.3723	.3727	.373	.3738
23		.3772	.3772	.3677	.3711	.3673	.3719
24		.3688	.3083	.2023	.2031	.3662	.3441
Max	.3871	.3807	.3871	.3883	.3829	.386	.3803
Min	.2046	.3589	.197	.1974	.1943	.024	.3441
Avg	.3457	.3690	.3494	.3462	.3415	.3330	.3680

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 201 / 11 KV KRIPAMAYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1755	.4899	1.1233	1.0753	1.0273	1.0915	1.1218
2	1.0804	.9865	1.0455	1.0037	.9514	1.0044	1.0296
3	1.0835	.9578	1.0113	.9953	.9396	.9882	1.0085
4	1.0688	.9202	.9784	.9778	.9215	.9777	.996
5	1.0229	.8945	.94	.9501	.917	.9722	.9682
6	1.0583	.8922	.9928	.9318	.9111	.9543	.9423
7	1.0846	.9368	1.0705	.9627	1.0004	1.041	1.0347
8	1.1294	.986	1.0545	1.013	1.0189	1.1164	1.0444
9	1.1488	1.1563	1.1146	1.068	1.2721	1.2536	1.3499
10	1.3228	1.341	1.3094	1.1392	1.4989	1.4178	1.3897
11	1.4583	1.4609	1.372	1.2563	1.5927	1.442	1.5434
12	1.5133	1.5263	1.4712	.6811	1.5931	1.4792	1.5316
13	1.4941	1.5024	1.3702	.728	1.4249	1.365	1.4503
14	1.4418	1.3245	1.1614	.687	1.2669	1.2212	1.2483
15	1.5415	1.3609	1.3118	.5969	1.4693	1.3289	1.3182
16	1.5243	1.4024	1.3287	1.2187	1.4605	1.3721	1.3729
17	1.5148	1.4465	1.4156	1.2595	1.4984	1.1393	1.3671
18	1.4399	1.4491	1.3807	1.2475	1.4211	1.1134	1.3409
19	1.3399	1.3176	1.3033	1.2262	1.3636	1.2271	1.2763
20	1.4395	1.3525	1.3668	1.2879	1.4043	1.3185	1.1149
21	.9362	1.3091	1.2925	1.2472	1.3266	1.2753	1.2085
22	1.1563	1.2916	1.286	1.1814	1.33	1.2921	1.2151
23	1.1315	1.2927	1.2582	1.1721	1.2829	1.2797	1.1923
24	1.195	1.2321	1.1848	1.1113	1.1923	1.2544	1.1467
Max	1.5415	1.5263	1.4712	1.2879	1.5931	1.4792	1.5434
Min	.9362	.4899	.94	.5969	.9111	.9543	.9423
Avg	1.2626	1.2012	1.2143	1.0424	1.2535	1.2052	1.2172



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 202 / 11 KV GMIE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1728	1.2384	1.5661	1.6194	1.0059	1.4571	1.5234
2	1.2651	1.0402	1.5463	1.6232	1.0783	1.5043	1.6796
3	1.4876	1.0273	1.5295	1.4548	1.0768	1.4975	1.6057
4	1.5745	1.0021	1.6347	1.4868	1.057	1.4502	1.6423
5	1.4975	1.454	1.5409	1.3626	1.0715	1.4678	1.5264
6	1.5318	1.4426	1.3855	1.3443	1.0578	1.3954	1.5082
7	1.4746	1.5737	1.48	1.3839	1.3794	1.2521	1.438
8	1.3649	1.3763	1.4327	1.3733	1.0905	1.2757	1.4159
9	1.4411	1.669	1.4373	1.1241	1.0837	1.5348	1.3504
10	1.7505	1.8953	1.4899	1.2445	1.4647	1.7642	1.6499
11	1.8717	1.9563	1.8016	.961	1.6964	2.0035	1.8724
12	2.0363	2.0698	1.5493	.7247	1.7878	1.9098	1.9395
13	1.9357	1.7139	1.8557	.7651	1.3733	1.8176	1.6362
14	1.8298	1.8198	1.8633	.9747	1.6293	1.8496	1.954
15	1.8198	1.973	1.8557	.7689	1.749	1.8625	2.0812
16	1.7421	1.8778	1.9227	.8063	1.7261	2.0858	2.2558
17	1.7909	1.8755	1.8237	.7849	1.5447	1.9532	1.9303
18	1.8404	1.9288	1.7985	.6554	1.8412	1.9448	1.6911
19	1.7002	1.7132	1.5501	.6866	1.5905	1.7833	1.6453
20	1.7124	1.07	1.5554	.7583	1.5867	1.6286	1.5706
21	.961	1.0143	1.5569	.7727	1.2445	1.6369	1.5607
22	1.4655	1.028	1.6408	.8032	1.2369	1.5188	1.6103
23	1.7208	1.656	1.7368	.9114	1.2826	1.3999	1.8016
24	1.2384	1.6941	1.7421	.9099	1.5112	1.2734	1.7436
Max	2.0363	2.0698	1.9227	1.6232	1.8412	2.0858	2.2558
Min	.961	1.0021	1.3855	.6554	1.0059	1.2521	1.3504
Avg	1.5927	1.5462	1.6373	1.0542	1.3819	1.6361	1.6930

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 203 / 11 KV INDIAN OIL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9076	.6737	.8147	.8246	.8185	.8147	.8269
2	.8459	.6432	.7697	.8055	.7918	.7636	.7727
3	.8055	.6158	.727	.7575	.7545	.7476	.7438
4	.7933	.5967	.7141	.7438	.7392	.727	.727
5	.7804	.5891	.7004	.7225	.7263	.7133	.7217
6	.8032	.5914	.7301	.708	.7476	.7308	.7225
7	.8147	.5838	.7506	.7316	.7621	.7491	.7598
8	.7994	.5624	.836	.7743	.8451	.7811	.8299
9	.9236	.5617	1.028	.9503	1.0181	.9236	.945
10	1.0517	.5914	1.0959	1.0433	1.23	1.1004	1.0989
11	1.1576	.5266	1.2978	1.1325	1.2109	1.2064	1.2513
12	1.0265	.4854	1.3344	1.2155	1.1767	1.275	1.3291
13	1.0555		1.3214	1.2102	1.2071	1.3123	1.3664
14	1.1698	.9351	1.2399	1.1546	1.166	1.2605	1.2932
15	1.2186	.9084	1.2826	1.1317	1.1942	1.2498	1.2696
16	1.2155	.8482	1.2216	1.1515	1.2369	1.2323	1.2338
17	1.182	.8596	1.1782	1.1416	1.2475	1.2155	1.214
18	1.1164	.8436	1.1203	1.054	1.1927	1.1363	1.1256
19	1.1881	.9511	1.1896	1.0951	1.1965	1.1645	1.1637
20	1.0776	1.07	1.2193	1.1675	1.3032	1.2186	1.2605
21	.9694	1.0898	1.2079	1.1812	1.2544	1.1942	1.2216
22	.9351	1.038	1.0989	1.1081	1.0974	1.0883	1.121
23	.8109	.9808	1.0014	1.0021	1.0212	1.0265	1.0029
24	.7255	.8733	.9114	.9015	.9252	.9	.9198
Max	1.2186	1.0898	1.3344	1.2155	1.3032	1.3123	1.3664
Min	.7255	.4854	.7004	.708	.7263	.7133	.7217
Avg	.9739	.7574	1.0330	.9879	1.0360	1.0221	1.0384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 204 / 11KV WATER FILTER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2317	.173	.2164	.2202	.2241	.2195	.2827
2	.2324	.1715	.2134	.2187	.237	.2187	.2843
3	.2705	.2827	.253	.2583	.2728	.2637	.2919
4	.2934	.3132	.2827	.2858	.2835	.2827	.2957
5	.2934	.298	.2812	.3003	.2827	.2827	.282
6	.2858	.2751	.2751	.3208	.2865	.2919	.2843
7	.2835	.2751	.2728	.285	.285	.2934	.2858
8	.2446	.234	.237	.2416	.2408	.2378	.2439
9	.2507	.2416	.2423	.2439	.2462	.237	.2416
10	.2743	.2309	.2881	.2881	.3041	.2835	.2881
11	.2865	.2812	.3086	.3033	.298	.3018	.3018
12	.2995	.301	.2904	.2843	.2888	.2904	.301
13	.3193	.3467	.3292	.3262	.3262	.3528	.3338
14	.2728	.3467	.3155	.3117	.3285	.3536	.2987
15	.2782	.3353	.3224	.314	.3269	.1791	.298
16	.3216	.3102	.2827	.3086	.3285	.1646	.3201
17	.3071	.2957	.3292	.3353	.3163	.1974	.3346
18	.3384	.301	.3262	.3246	.3201	.3399	.3277
19	.3399	.2919	.3307	.3292	.3208	.3102	.3216
20	.3628	.317	.3422	.3224	.4245	.3216	.3399
21	.3323	.3071	.317	.3147	.4275	.3056	.3064
22	.1067	.2987	.2835	.3102	.3871	.3025	.2782
23	.1242	.2568	.2652	.2507	.3224	.2637	.2469
24	.1753	.2644	.237	.2545	.25	.2522	.2317
Max	.3628	.3467	.3422	.3353	.4275	.3536	.3399
Min	.1067	.1715	.2134	.2187	.2241	.1646	.2317
Avg	.2719	.2812	.2851	.2897	.3053	.2728	.2925

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 205 / 11KV SIDHIVINAYAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		***				***	
2		***	***	***	***	***	***
3	***	***	***	***	***	***	***
4	***	***	***	***	***	***	***
5	***	***	***	***	***	***	***
6	***	***	***	***	***	***	***
7	***	***	***	***	***	***	***
8	***	***	***	***	***	***	***
9	***	***	***	***	***	***	***
10	***	***	***	***	***	***	***
11	***	***	***	***	***	***	***
12	***	***	***		***	***	***
13	***	***	***		***	***	***
14	***	***	***		***	***	***
15	***	***	***		***	***	***
16	***	***	***		***	***	***
17	***	***	***		***	***	***
18	***	***	***	***	***	***	***
19	***	***	***		***	***	***
20	***	***	***		***	***	***
21	***	***	***		***	***	***
22	***	***	***		***		
23	***	***			***		
24	***						
Max	152.416	152.416	152.416	152.416	152.416	152.416	152.416
Min	76.208	76.208	76.208	76.208	152.416	76.208	152.416
Avg	145.488	132.5357	148.7870	138.56	152.416	148.7870	152.416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 206 / 11KV GULMOHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1997	.2012	.2058	.1989	.2103	.2004
2	.2126	.1974	.1981	.192	.1928	.1974	.1943
3	.2096	.1905	.1913	.1898	.1837	.1936	.1898
4	.2012	.1875	.1859	.1821	.1814	.1859	.1852
5	.2035	.1859	.1859	.1821	.189	.1882	.1859
6	.2119	.1882	.1966	.1776	.1928	.2035	.2012
7	.2271	.1859	.2119	.1844	.2027	.1989	.2088
8	.202	.1913	.1829	.1905	.1791	.1707	.1738
9	.2271	.2042	.2119	.1707	.1852	.1791	.1913
10	.2553	.2187	.2401	.173	.1966	.208	.1936
11	.2637	.2301	.2347	.1661	.2362	.2263	.2042
12	.2469	.2317	.208	.1738	.2484	.2408	.2164
13	.2522	.205	.2271	.1722	.2347	.2073	.2073
14	.2728	.2187	.2378	.1638	.2248	.234	.2241
15	.2576	.2263	.2218	.1661	.2149	.2401	.2218
16	.2629	.2233	.218	.1715	.202	.2134	.2309
17	.237	.2241	.2149	.1738	.1844	.2286	.189
18	.2164	.2233	.2027	.1814	.2004	.2362	.208
19	.2713	.2462	.2324	.2065	.2202	.2507	.2248
20	.2919	.2774	.2637	.2492	.2782	.3125	.269
21	.2385	.253	.2576	.2401	.2401	.2721	.2622
22	.2393	.2355	.2515	.2393	.2317	.2515	.2439
23	.2263	.2332	.2469	.221	.2431	.2469	.2324
24	.205	.2126	.2218	.2058	.2195	.2248	.2233
Max	.2919	.2774	.2637	.2492	.2782	.3125	.269
Min	.2012	.1859	.1829	.1638	.1791	.1707	.1738
Avg	.2356	.2162	.2185	.1908	.2117	.2217	.2117

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 201 / 11KV Jagdish IRON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8846	1.7169	.7634	.7533	.7368	2.8525	2.3556
2	1.7863	1.7063	.7246	.7678	.7278	2.8037	2.2496
3	1.7332	1.7459	.7605	.743	.7263	3.5025	2.2717
4	1.7787	1.4723	.7583	.769	.7154	2.806	2.1529
5	1.6637	1.4418	.7521	.7575	.7184	2.3091	2.1239
6	1.7158	1.384	.6637	.7319	.7285	1.5067	2.3129
7	1.5682	.7729	.6622	.6538	.6325	2.1784	2.1955
8	.9926	.8086	.6599	.6573	.6543	1.4386	2.0759
9	1.5375	.7155	.6203	.6173	.6146	2.0397	1.4007
10	.9511	1.0844	.7665	.6584	2.2695	2.196	2.1971
11	1.7414	1.1195	1.1064	.6523	2.2047	2.8106	1.2712
12	1.4089	1.0515	.8619	.7285	2.2782	2.9257	1.7545
13	1.2475	1.2727	.7529	.5502	2.2931	2.7881	1.6653
14	.5952	1.8011	.7911	.5609	2.1689	2.6612	.9297
15	1.1172	1.7348	.7533	.554	2.4821	2.3433	1.4494
16	1.0588	1.2165	.7216	.5586	2.4699	2.3413	1.2157
17	1.7588	.8322	.7304	.5563	2.3605	2.2581	1.8153
18	1.041	.5586	.74	.5617	2.2664	2.3114	2.2504
19	.8863	.7514	.5914	.5677	2.2519	2.3845	2.1559
20	.5845	.8311	.7464	.57	1.1751	2.271	2.2214
21	.7903	.7389	.6996	.5738	1.3137	2.2275	2.396
22	.8261	.7331	.6977	.5738	2.3352	2.2771	2.3259
23	1.5753	.7267	.7564	.7031	3.722	2.2679	2.3434
24	1.7947	1.3679	.762	.733	1.7938	2.3066	2.2664
Max	1.8846	1.8011	1.1064	.769	3.722	3.5025	2.396
Min	.5845	.5586	.5914	.5502	.6146	1.4386	.9297
Avg	1.3349	1.1494	.7434	.6481	1.6517	2.4086	1.9748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 202 / 11 KV Mahabal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	2.7495	2.6916	2.4497	.6308	2.7968	2.5568
2	1.8496	2.4188	2.4546	2.5377	.6493	2.4981	2.3289
3	2.2978	2.7046	2.7313	2.6242	.6836	2.6425	2.2656
4	2.1392	2.2351	2.669	2.5202	.7244	2.5278	2.2954
5	2.1816	2.5087	2.5745	2.6347	.7587	1.9738	2.2527
6	2.1536	2.6338	2.6478	2.6236	.9198	2.5297	2.1765
7	2.1674	2.5377	2.7151	1.3412	.9606	2.3657	1.9844
8	2.5245	2.7865	2.8921	.6584	.9697	2.9592	1.9052
9	3.4619	3.77	1.5127	.4931	3.4062	3.4724	3.0254
10	1.813	3.368	2.6924	.6698	3.7448	3.2737	3.7344
11	3.5383	3.848	2.0418	.6615	3.5803	2.2169	3.5002
12	3.0224	3.0193	3.2183	.6684	3.3989	3.8659	3.6433
13	3.0689	3.1687	3.0765	.5144	3.2327	3.7197	3.0514
14	3.1078	2.9356	2.9821	.5144	3.0475	3.4528	3.0696
15	3.6441	3.5105	3.3456	.5258	3.075	3.7089	3.4012
16	3.0917	3.2335	2.5328	.5289	2.7081	3.9748	3.7635
17	3.7974	3.6402	2.8645	.5258	2.2054	3.1979	3.6494
18	3.5094	1.4403	1.7629	.5129	2.3396	3.7045	3.7128
19	2.8102	2.5353	1.2529	.5213	2.0778	3.5193	3.7913
20	1.0616	2.6833	2.9576	.5197	1.0189	3.517	3.3761
21	1.15	2.3312	2.4737	.5251	1.7749	3.0308	2.9729
22	1.8747	2.1281	2.1536	.5182	2.3785	3.0689	2.9081
23	2.5308	2.2998	1.9905	.6322	2.3544	2.7633	2.809
24	2.3468	2.7038	2.8235	1.929	1.4409	2.9691	2.3678
Max	3.7974	3.848	3.3456	2.6347	3.7448	3.9748	3.7913
Min	1.0616	1.4403	1.2529	.4931	.6308	1.9738	1.9052
Avg	2.5357	2.7996	2.5441	1.1521	2.0034	3.0729	2.9392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 203 / 11KV Shreeji

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6264	.5913	.6192	.6005	.3951	.6714	.6504
2	.6276	.6115	.5883	.5982	.3932	.6807	.6733
3	.596	.6428	.658	.63	.394	.6188	.6733
4	.6451	.6463	.6733	.6409	.4024	.6667	.6966
5	.6074	.6455	.6518	.6287	.3925	.6341	.7057
6	.6143	.6603	.674	.6405	.4214	.6651	.7461
7	.6444	.663	.6306	.6104	.4385	.6129	.7202
8	.6268	.6927	.7559	.4085	.4309	.6374	.7103
9	.5632	1.1569	.6249	.2911	1.2158	1.2327	1.0273
10	1.3839	1.4277	1.4356	.3522	1.4253	1.3418	1.4914
11	1.4849	1.5152	1.5004	.3863	1.4259	1.5676	1.507
12	1.4261	1.4179	1.4844	.3263	1.3885	1.5918	1.4723
13	1.4015	1.3679	1.4785	.2888	1.3268	1.4907	1.286
14	1.3805	1.3619	1.3769	.25	1.2796	1.555	1.3607
15	1.318	1.286	1.4809	.2667	1.275	1.62	1.3329
16	1.2933	1.3325	1.5088	.2644	1.2979	1.5321	1.3456
17	1.3121	1.3153	1.5453	.2942	1.3847	1.459	1.3375
18	1.209	.6516	1.3951	.3018	1.3565	1.4577	1.2091
19	1.0261	1.0631	.6676	.3109	1.0898	1.4273	1.041
20	.4992	.8184	.8386	.3056	.5182	1.0105	.8947
21	.589	.5983	.6674	.3147	.6261	.762	.6154
22	.5898	.5239	.5295	.3201	.5584	.6142	.5487
23	.6219	.5872	.5921	.3909	.6523	.6055	.6256
24	.6213	.5936	.6058	.6089	.4538	.7049	.6946
Max	1.4849	1.5152	1.5453	.6409	1.4259	1.62	1.507
Min	.4992	.5239	.5295	.25	.3925	.6055	.5487
Avg	.9045	.9238	.9576	.4179	.8559	1.0483	.9736



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 204 / 11KV JK ICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8669	1.8572	1.8782	1.7526	1.4654	1.8915	2.0157
2	1.8473	1.9056	1.7768	1.805	1.4506	1.856	1.9318
3	1.7319	1.9102	1.7162	1.7993	1.4499	1.8153	1.9219
4	1.7737	1.8808	1.7107	1.77	1.4552	1.8443	1.9044
5	1.7025	1.8549	1.7318	1.8698	1.4682	1.9279	1.9273
6	1.6294	1.8976	1.5961	1.8703	1.4837	1.8495	1.8442
7	1.8284	1.8053	1.7177	1.792	1.4822	2.0614	1.7612
8	1.9433	1.9349	1.826	1.5175	1.5043	1.9092	1.8282
9	1.2376	2.1072	1.1126	.961	2.2276	2.2699	2.3033
10	1.3009	2.3079	3.0273	1.502	2.3738	2.4299	2.7365
11	2.9694	2.9062	3.1703	1.392	2.7042	2.7382	2.8233
12	2.9206	2.868	3.1226	1.4653	2.9275	2.6518	2.7513
13	2.7949	2.7541	2.9477	.9496	2.8076	2.4588	2.5825
14	2.7069	2.5851	2.8407	.9419	2.5705	2.6535	2.5564
15	2.8816	3.0435	3.0941	.9534	2.7442	2.3529	2.8133
16	2.7648	3.3789	2.9465	.9419	2.8776	2.2396	3.0658
17	2.6995	3.1436	3.1615	.9358	2.4703	1.6951	2.9065
18	2.4463	1.4022	2.7355	.9724	2.4901	2.3419	2.7277
19	2.0352	2.3541	1.3199	.9793	1.9265	2.1902	2.271
20	1.0921	1.9265	2.3213	.9785	.9732	2.1026	1.8862
21	1.8839	2.1148	1.8938	.9892	1.6515	1.9585	1.8983
22	1.9037	1.9884	1.8069	.993	1.685	1.9911	2.0416
23	1.9632	2.1111	1.7796	1.4753	2.0526	2.0866	2.0554
24	1.9166	2.0325	1.8948	1.7093	1.6118	2.0727	2.0493
Max	2.9694	3.3789	3.1703	1.8703	2.9275	2.7382	3.0658
Min	1.0921	1.4022	1.1126	.9358	.9732	1.6951	1.7612
Avg	2.0767	2.2529	2.2137	1.3465	1.9939	2.1412	2.2751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 205 / 11KV Shakti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9158	1.2944	1.3706	1.374	.7023	1.0858	1.1469
2	2.729	1.3771	1.374	1.2586	.6554	1.0378	1.1096
3	2.7027	1.3679	1.2726	1.3401	.6584	1.0722	1.1233
4	2.7861	1.3184	1.26	1.2161	.6542	.9635	1.0829
5	2.8711	1.3138	1.3077	1.2399	.6733	.9297	1.0669
6	2.8807	1.3626	1.3398	1.3023	.6683	.9983	1.0105
7	1.1896	1.4136	1.393	1.0715	.6036	1.0516	1.0349
8	1.4784	1.5317	1.6661	.7061	.8139	1.6278	1.4114
9	1.0288	2.2039	1.086	.4466	2.3076	2.2982	2.1106
10	1.2155	2.187	2.6744	.6162	2.5857	2.6612	1.9667
11	2.2807	2.8538	2.6086	.5918	3.1912	3.0788	2.1308
12	2.3144	2.5512	2.979	.5868	3.6831	3.3774	3.3132
13	2.4451	2.6356	3.3497	.4527	3.2815	3.4236	3.1672
14	2.4596	2.0927	3.2854	.4161	2.9058	3.203	3.1858
15	2.6934	2.6008	3.6973	.439	3.312	4.2452	3.6275
16	2.4004	2.5756	4.0084	.4458	3.4355	4.0638	3.7395
17	2.6117	2.636	3.4802	.442	2.9287	3.573	2.6204
18	2.2131	1.1927	2.7366	.4633	2.3502	2.5568	2.0858
19	2.2511	2.1589	1.0707	.4885	2.5735	2.2588	1.9464
20	1.0341	2.0706	1.989	.5053	1.2407	1.999	1.8378
21	.003	1.8736	1.696	.519	1.7833	1.6651	1.6164
22	.9457	1.5516	1.435	.5167	1.6263	1.6173	1.5059
23	1.2315	1.6701	1.7985	.7266	1.6255	1.6072	1.4525
24	2.1384	1.318	1.3681	1.1635	.8082	1.1599	1.1576
Max	2.9158	2.8538	4.0084	1.374	3.6831	4.2452	3.7395
Min	.003	1.1927	1.0707	.4161	.6036	.9297	1.0105
Avg	2.0342	1.8813	2.0936	.7637	1.8778	2.1481	1.9354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 206 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0246	1.1972	.9811	.9595	1.1256	1.2636	1.3055
2	1.0913	1.2498	.7581	1.0978	.9313	1.1195	1.3496
3	.9214	1.1926	.6573	1.1492	1.0509	1.1401	1.3313
4	.9469	1.0288	.7013	1.1507	.9815	1.0887	1.2255
5	.855	.9496	.6162	1.0372	.9709	1.1353	1.2392
6	.8436	1.1309	.6281	1.1515	.9358	.9993	1.2095
7	.9884	.9206	.6261	1.0692	.9381	1.2559	.9816
8	.9385	1.0997	.5183	.6272	.929	1.3374	1.1018
9	.5243	1.2605	.3102	.3216	1.0635	1.3062	1.4663
10	.5784	1.1808	.8872	.5578	1.5265	1.5505	1.7429
11	1.6042	1.1616	1.0547	.5927	1.6392	1.6621	1.8133
12	1.814	1.4117	1.0216	.4725	1.7909	1.5827	1.4005
13	1.8686	1.4015	1.0199	.3025	1.6934	1.5562	1.6545
14	1.73	1.4108	.9897	.2942	1.6522	1.6465	1.7562
15	1.7048	1.512	.9176	.3109	1.768	1.8008	2.0805
16	1.4952	1.5819	.893	.3292	1.8739	1.7887	2.0975
17	1.5726	1.6592	.9925	.3224	1.7718	1.7625	1.8928
18	1.5501	.8543	.8055	.3056	1.8016	1.7089	1.8655
19	1.2978	1.1473	.4222	.3285	1.5745	1.6762	1.6499
20	.6622	1.2483	.8802	.362	.7659	1.5987	1.5631
21	.7339	1.2239	1.0288	.3597	1.2573	1.4883	1.4282
22	.9984	1.074	1.0555	.3833	1.4708	1.3702	1.4076
23	1.1607	1.2575	1.1	.9282	1.4665	1.3051	1.4579
24	1.0623	1.3374	1.0412	1.0922	1.278	1.2441	1.368
Max	1.8686	1.6592	1.1	1.1515	1.8739	1.8008	2.0975
Min	.5243	.8543	.3102	.2942	.7659	.9993	.9816
Avg	1.1653	1.2288	.8294	.6461	1.3440	1.4328	1.5162

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 207 / 11 KV Priyanka

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7995	.9656	1.7802	1.4739	1.1873	1.5051	1.6777
2	1.7353	1.1774	1.7829	1.3991	1.2064	1.5257	1.7063
3	1.6271	1.1858	1.7252	1.4095	1.1904	1.5333	1.6407
4	1.6034	1.2331	1.5989	1.4693	1.2034	1.4396	1.6651
5	1.5524	1.211	1.4853	1.3782	1.198	1.4357	1.6628
6	1.4979	1.2925	1.3344	1.2976	1.2697	1.4945	1.7156
7	1.7482	1.3177	1.4291	1.2148	1.2796	1.7696	1.8733
8	1.3862	1.2879	1.6179	1.1946	1.2834	1.8899	1.8343
9	1.07	1.659	.9724	.7034	1.757	2.0942	2.172
10	1.1332	2.0595	2.1634	1.3245	2.3518	2.4017	2.5812
11	2.4973	2.1431	2.5078	2.2147	2.4897	2.575	2.7212
12	2.5404	2.4282	2.512	.7827	2.5221	2.6677	2.8494
13	2.3918	2.4772	2.5663	.4824	2.4782	2.6814	2.4726
14	2.3784	2.3049	2.543	.7606	2.1986	1.214	2.4794
15	2.4908	2.5288	2.6109	.8109	2.6192	2.6617	2.6166
16	2.3693	2.5312	2.4444	.804	2.8563	2.8096	2.578
17	2.5394	2.5661	2.5804	.7918	2.5682	2.1712	2.5923
18	2.2973	1.2369	2.0755	.7888	2.4265	2.122	2.4234
19	1.877	2.0561	1.0791	.759	1.9753	1.7231	2.2588
20	.8756	1.9479	1.7444	.7423	.9488	1.6689	2.1109
21	.434	1.8374	1.563	.7247	1.5476	1.6057	1.9894
22	.4412	1.8724	1.4857	.7308	1.5261	1.6686	1.9593
23	.5014	1.8976	1.5185	1.2155	1.6266	1.7078	1.0235
24	1.3779	1.2628	1.699	1.3525	1.3962	1.6103	1.6183
Max	2.5404	2.5661	2.6109	2.2147	2.8563	2.8096	2.8494
Min	.434	.9656	.9724	.4824	.9488	1.214	1.0235
Avg	1.6735	1.7700	1.8675	1.0761	1.7961	1.9157	2.0926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 210 / 11KV Saptrang

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9619	.8676	1.1389	.5014	.3688	.6219	.6089
2	.8589	.8383	1.0185	.4805	.3277	.5434	.5731
3	.7343	.8383	.788	.5729	.3277	.591	.5853
4	.8048	.7922	.8779	.3544	.3521	.6219	.543
5	.6836	.7922	.7186	.4298	.3521	.5487	.543
6	.5853	.7468	.5068	.4706	.3048	.5014	.4961
7	.3429	.5175	.4755	.5175	.2858	.5068	.3772
8	.4344	.3696	.5121	.3725	.2858	.2164	.4115
9		.7621			.7545	.7167	.5601
10		1.6221	.7545	.0693	.7621	.7922	.7922
11	.8676	1.5844	.9054	.061	.8764	.9431	.8676
12	1.3957	1.2449	.8299	.0747	.9526	.9054	.7545
13	1.5089	1.3203	.7545		.9526	.7922	.8676
14	1.5089	1.1694	.5658		.9145	.8383	.9431
15	1.5466	1.4712	.6036		.9145	.8676	.9054
16	1.5466	1.5089	.4904		.7621	.5658	.8676
17	.9431	1.4712	.8299		.8383	.8676	.6413
18	1.5242		.3582		.4344	.8676	.4298
19	1.4098	.7468			.2984	.8299	.5487
20		.6161	.5249			.7545	.6283
21	.4854	1.1506	.3224		.5544	.6722	.6348
22	.5658	1.2071	.3658		.6219	.6722	.6722
23	.7545	1.1883	.3149	.3521	.6283	.6219	.5658
24	1.0269	.8676	1.226	.6348	.3688	.6535	.6089
Max	1.5466	1.6221	1.226	.6348	.9526	.9431	.9431
Min	.3429	.3696	.3149	.061	.2858	.2164	.3772
Avg	.9757	1.0302	.6765	.3763	.5756	.6880	.6428

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 401 / 33KV Super Craft Foundry      NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	1.3306	5.5881	4.6457	1.5409	7.145	6.9502
2	.04	1.2895	5.9465	4.2678	1.4952	6.7747	6.8073
3	.0377	1.2895	5.6447	5.8574	1.4952	5.8213	6.8759
4	.056	1.2895	4.8388	5.3189	1.4952	7.0816	6.9501
5	.048	1.2757	5.2178	5.3823	1.4952	6.5615	6.4186
6	.04	1.2757	4.521	4.4411	1.5763	6.3923	6.8359
7	.032	1.2889	5.4287	4.0106	1.5512	7.073	6.9787
8	.136	1.306	4.169	4.6685	1.534	6.6015	6.7444
9		1.6369	3.738	3.5322	2.2405	6.2603	6.5787
10		1.6872	5.775	1.4883	2.3263	7.4245	7.3331
11	.12	3.3134	4.6793	1.4255	5.2069	6.6907	6.7987
12	.156	2.9698	5.555	1.3683	5.7042	6.7987	6.6444
13	.044	4.6159	5.5127	1.3546	6.8416	6.9187	6.8005
14	.04	5.2726	5.8385	1.4232	7.4303	7.3868	6.9719
15	.028	4.9125	5.1012	1.4232	7.0245	5.9585	7.356
16	.0309	4.4187	4.4856	1.3889	6.7559	6.1786	7.3972
17	.3961	5.4509	4.3141	1.3717	4.9897	5.4618	5.9562
18	.096	4.3553	1.9593	1.3203	1.8004	3.0235	2.2428
19	.096	2.8464	1.3717	1.3546	1.2998	1.5489	1.5992
20		1.3032	1.4329	1.3717	1.3032	1.3946	1.4015
21		1.3392	1.4197	1.3546	1.3169	1.4232	1.4575
22	.02	1.4129	2.6338	1.3203	2.1348	2.5377	1.5306
23	.024	2.8653	1.905	1.3969	2.8995	3.0636	2.8407
24	.0412	1.8107	4.7336	2.7863	5.7762	7.2668	6.9159
Max	.3961	5.4509	5.9465	5.8574	7.4303	7.4245	7.3972
Min	.02	1.2757	1.3717	1.3203	1.2998	1.3946	1.4015
Avg	.0769	2.5232	4.2421	2.6780	3.2181	5.5328	5.5994

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 201 / 11 KV Shivaji Road Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.2286	.3048
2	.2286	.2286	.2286	.2286	.2286	.2286	.2286
3	.2286	.2286	.2286	.2286	.2286	.2286	.2286
4	.2286	.2286	.2286	.2286	.2286	.2286	.2286
5	.2286	.2286	.2286	.2286	.2286	.2286	.2286
6	.2286	.2286	.2286	.2286	.2286	.2286	.2286
7	.2286	.2286	.2286	.2286	.2286	.2286	.2286
8	.2286	.2286	.2286	.2286	.2286	.2286	.2286
9	.2286	.2286	.2286	.2286	.2286	.2286	.2286
10	.2286	.2286	.2286	.2286	.2286	.2286	.2286
11	.3048	.2286	.3048	.2286	.2286	.3048	.2286
12	.3048	.2286	.3048	.3048	.3048	.3048	.1524
13	.3048	.2286	.3048	.3048	.3048	.3048	
14	.3048	.2286	.3048	.3048	.3048	.3048	.381
15	.3048	.2286	.3048	.3048	.3048	.3048	.3048
16	.3048	.2286	.3048	.3048	.3048	.3048	.3048
17	.3048	.2286	.3048	.2286	.3048	.3048	.3048
18	.3048	.2286	.3048	.2286	.3048	.3048	.3048
19	.381	.381	.381	.381	.381	.381	.381
20	.381	.381	.4572	.381	.4572	.4572	.4572
21	.381	.381	.4572	.381	.4572	.4572	.4572
22	.381	.381	.381	.381	.381	.381	.381
23	.381	.381	.381	.381	.381	.381	.381
24	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Max	.381	.381	.4572	.381	.4572	.4572	.4572
Min	.2286	.2286	.2286	.2286	.2286	.2286	.1524
Avg	.2921	.2667	.2985	.2826	.2953	.2953	.2915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 203 / 11 KV Darga Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.5242	1.5242	1.448	1.448	1.448	1.5242
2	1.448	1.3717	1.448	1.3717	1.3717	1.2955	1.3717
3	1.448	1.3717	1.3717	1.2955	1.2955	1.2193	1.2955
4	1.448	1.3717	1.3717	1.2955	1.2955	1.2193	1.3717
5	1.448	1.3717	1.3717	1.2955	1.2955	1.2193	1.3717
6	1.5242	1.448	1.448	1.3717	1.448	1.2955	1.448
7	1.5242	1.3717	1.448	1.3717	1.3717	1.2955	1.448
8	1.448	1.3717	1.3717	1.2955	1.3717	1.1431	1.3717
9	1.448	1.3717	1.3717	1.3717	1.2955	1.3717	1.3717
10	1.448	1.448	1.3717	1.3717	1.3717	1.448	1.448
11	1.448	1.448	1.3717	1.3717	1.3717	.9145	1.448
12	1.448	1.3717	1.3717	1.3717	1.448	1.3717	1.448
13	1.2955	1.3717	1.448	1.2955	1.448	1.448	1.448
14	1.2955	1.3717	1.448	1.448	1.3717		1.3717
15	1.3717	1.448	1.3717	1.3717	.5335	1.5242	1.3717
16	1.448	1.3717	1.3717	1.2955	.9145	1.6004	1.3717
17	1.448	1.448	1.448	1.3717	1.5242	1.6004	1.3717
18	1.448	1.448	1.448	1.3717	1.5242	1.6004	1.448
19	1.7528	1.6766	1.7528	1.5242	1.829	1.829	1.6766
20	1.9052	1.829	1.9814	1.7528	2.0576	1.9814	1.9814
21	1.7528	1.9052	1.9814	1.7528	1.9814	2.0576	1.9814
22	1.6766	1.829	1.9052	1.7528	1.9052	1.9052	1.829
23	1.6766	1.7528	1.7528	1.6766	1.829	1.829	1.829
24	1.6004	1.6766	1.6004	1.5242	1.6766	1.7528	1.6766
Max	1.9052	1.9052	1.9814	1.7528	2.0576	2.0576	1.9814
Min	1.2955	1.3717	1.3717	1.2955	.5335	.9145	1.2955
Avg	1.5147	1.4988	1.5146	1.4321	1.4575	1.4943	1.5115



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 204 / 11 KV Laxmi Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.7528	1.7528	1.7528	1.7528	1.7528	1.7528
2	1.829	1.6766	1.6766	1.6004	1.6766	1.6004	1.6004
3	1.7528	1.6004	1.6004	1.6004	1.6004	1.5242	1.5242
4	1.6766	1.6004	1.6004	1.5242	1.5242	1.5242	1.5242
5	1.6766	1.6004	1.5242	1.5242	1.5242	1.5242	1.5242
6	1.7528	1.6004	1.6766	1.6004	1.5242	1.6004	1.6004
7	1.6766	1.5242	1.6004	1.5242	1.5242	1.6004	1.6004
8	1.6004	1.5242	1.448	1.448	1.448	1.448	1.448
9	1.5242	1.5242	1.448	1.448	1.448	1.3717	1.448
10	1.6766	1.6004	1.5242	1.448	1.5242	1.5242	1.6004
11	1.9052	1.6766	1.7528	1.3717	1.829	1.829	1.829
12	1.9814	1.7528	1.7528	1.6766	1.7528	1.9052	1.9052
13	1.829	1.7528	1.9052	1.6766	1.829	1.829	1.9052
14	1.9052	1.7528	1.9052	1.6766	1.829	1.829	1.829
15	1.9052	1.6766	1.829	1.6766	1.829	1.7528	1.829
16	1.829	1.7528	1.7528	1.6004	1.829	1.7528	1.9052
17	1.9052	1.7528	1.9052	1.6766	1.829	1.829	1.9052
18	1.9052	1.7528	1.9052	1.6766	1.9052	1.9052	1.829
19	2.4387	2.1338	2.3624	2.1338	2.3624	2.3624	2.21
20	2.6673	2.3624	2.5911	2.4387	2.6673	2.6673	2.5911
21	2.5149	2.3624	2.5911	2.3624	2.5911	2.5911	2.5149
22	2.21	2.21	2.2862	2.21	2.2862	2.2862	2.2862
23	2.1338	2.1338	2.21	2.0576	2.1338	2.21	2.1338
24	1.9814	2.0576	1.9814	1.9052	1.9814	1.9814	1.9052
Max	2.6673	2.3624	2.5911	2.4387	2.6673	2.6673	2.5911
Min	1.5242	1.5242	1.448	1.3717	1.448	1.3717	1.448
Avg	1.9243	1.7973	1.8576	1.7338	1.8417	1.8417	1.8417

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 205 / 11 KV Shivneri Chowk

SHEDDABLE URBAN

Feeder Feeder KV- 11 /  
OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.2193	1.2193	1.2193	1.1431	1.2193	1.2193
2	1.2193	1.1431	1.1431	1.1431	1.0669	1.1431	1.1431
3	1.2193	1.1431	1.1431	1.1431	1.0669	1.1431	1.1431
4	1.2193	1.1431	1.0669	1.0669	1.0669	1.0669	1.0669
5	1.2193	1.0669	1.0669	1.0669	1.0669	1.0669	1.0669
6	1.2955	1.1431	1.1431	1.1431	1.1431	1.1431	1.1431
7	1.2955	1.1431	1.1431	1.1431	1.1431	1.1431	1.1431
8	1.2193	1.1431	1.1431	1.1431	1.2193	1.1431	1.1431
9	1.2193	1.2193	1.1431	1.1431	1.1431	1.1431	1.2193
10	1.2955	1.2955	1.2193	1.1431	1.1431	1.1431	1.1431
11	1.3717	1.2193	1.2193	1.1431	1.2193	1.2193	1.1431
12	1.3717	1.2193	1.1431	1.0669	1.1431	1.2193	1.1431
13	1.2955	1.2193	1.1431	1.0669	1.1431	1.0669	1.1431
14	1.2193	1.0669	.9907	.9907	1.0669	1.0669	1.0669
15	1.2193	1.0669	1.0669	.9907	1.0669	1.0669	1.0669
16	1.2193	1.1431	1.0669	1.0669	1.1431	1.0669	1.1431
17	1.2193	1.2193	1.1431	1.1431	1.1431	1.1431	1.1431
18	1.2193	1.2955	1.2193	1.1431	1.2193	1.2193	1.2193
19	1.448	1.448	1.448	1.2955	1.448	1.448	1.448
20	1.5242	1.5242	1.6004	1.448	1.6004	1.6004	1.6004
21	1.5242	1.5242	1.5242	1.448	1.5242	1.6004	1.5242
22	1.448	1.448	1.448	1.0669	1.5242	1.5242	1.448
23	1.3717	1.448	1.448	1.3717	1.448	1.448	1.448
24	1.2955	1.2955	1.2955	1.2193	1.3717	1.3717	.381
Max	1.5242	1.5242	1.6004	1.448	1.6004	1.6004	1.6004
Min	1.2193	1.0669	.9907	.9907	1.0669	1.0669	.381
Avg	1.3019	1.2415	1.2161	1.1590	1.2193	1.2257	1.1812

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 401 / 33 KV SAHYADRI STARCH  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.4527	5.4527	5.5213	5.4527	5.487	5.2812	5.5899
2	5.727	5.2812	5.727	5.5556	5.5899	5.2469	5.5556
3	5.3498	5.2126	5.5213	5.2126	5.5213	5.1097	5.3841
4	5.3498	5.2812	4.9383	5.3498	5.4184	5.1097	5.3841
5	5.4184	5.1097	5.2126	5.4184	5.2469	5.0755	5.4184
6	5.4184	5.1783	5.3841	5.487	5.1783	5.2126	5.4527
7	5.4527	5.1783	5.4527	5.5899	5.3841	5.2126	5.4527
8	5.3155	5.0412	5.2469	5.3841	5.2812	5.1783	5.3155
9	5.2812	4.9726	4.904	5.487	5.5213	5.2469	5.3498
10	5.3841	5.0755	5.2469	5.2469	5.6584	5.1783	5.487
11	5.4184	5.3841	5.2469	5.144	5.8299	5.0755	5.3155
12	5.1783	5.2812	5.1097	5.1097	5.487	5.5899	5.2812
13	5.3498	5.4184	5.144	5.0755	5.3841	5.6242	5.6242
14	5.3841	5.3155	4.9726	5.0755	4.6982	5.5899	5.3841
15	5.3155	5.4184	5.2126	5.487	5.0412	5.727	5.1783
16	5.2812	5.3155	5.3155	5.5899	5.144	5.5556	5.4527
17	4.8697	5.3498	5.2126	5.5556	5.0069	5.3841	5.727
18	5.2126	5.3155	5.0412	5.4184	5.0069	5.5213	5.727
19	5.487	5.2812	5.0412	5.5213	5.1097	5.5213	5.6927
20	5.4527	5.2126	5.1097	5.487	5.0412	5.3841	5.5556
21	1.6461	5.3498	5.2469	5.4184	5.1783	5.2469	5.6584
22	3.8066	5.8299	5.5213	5.4527	5.2812	5.5556	5.8985
23	5.2469	6.0014	5.5899	5.5899	5.4527	5.2469	5.8299
24	5.3498	5.6927	5.5899	5.5899	5.2812	5.4184	5.1097
Max	5.727	6.0014	5.727	5.5899	5.8299	5.727	5.8985
Min	1.6461	4.9726	4.904	5.0755	4.6982	5.0755	5.1097
Avg	5.1312	5.3312	5.2712	5.4041	5.3012	5.3455	5.4927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 402 / 33KV SONI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 403 / 33 KV MIRAJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	***	***	***	***	***	***	***
3	***	***	***	***	***	***	***
4	***	***	***	***	***	***	***
5	***	***	***	***	***	***	***
6	***	***	***	***	***	***	***
7	***	***	***	***	***	***	***
8	***	27.1605	28.9438	29.081	***	***	***
9	***	***	***	***	***	***	***
10	***	***	***	***	***	***	***
11	***	***	***	***	***	***	***
12	***	***	***	***	***	***	***
13	***	***	***	20.3018	***	***	***
14	***	***	***	20.1646	***	***	***
15	***	***	***	19.9589	***	***	***
16	***	***	***	***	***	***	***
17	***	***	***	25.7888	***	***	***
18	21.9479	21.3992	22.0165	21.0563	22.2908	22.2908	22.2908
19	21.3992	23.1139	24.0741	23.1825	24.5542	25.1029	24.6228
20	23.1825	27.915	29.2181	28.2579	***	***	***
21	15.9122	28.0522	28.2579	27.9836	***	***	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	***	***	***	***
Max	65.638	59.6709	62.963	60.4939	63.5117	62.0028	63.1002
Min	15.9122	21.3992	22.0165	19.9589	22.2908	22.2908	22.2908
Avg	46.5564	42.1268	45.4276	39.8520	47.6195	46.4564	48.5883

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 404 / 33 KV Madhavnagar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	16.3923	16.8038	17.0096	16.941	7.3388	11.8656	13.5803
2	16.5295	16.8038	16.5295	17.0096	7.2702	12.8258	13.2373
3	16.3923	17.0782	14.632	16.8724	7.0645	12.8258	13.1687
4	15.2492	17.0782	15.0435	16.5981	7.0645	12.7572	14.3347
5	15.5236	16.7352	15.455	17.7641	7.2017	14.5405	12.3457
6	15.9351	16.1865	16.3923	18.4271	7.8875	14.8834	13.0316
7	15.9122	15.1121	16.5981	14.9063	8.1619	14.952	12.0713
8	15.5922	15.1806	16.3237	12.9401	7.9561	12.6886	12.2085
9	17.6955	15.7293	17.6955	9.2821	11.4541	15.2949	13.5117
10	22.428	19.5931	21.0105	9.968	13.8546	17.9698	16.8039
11	23.1139	22.5194	21.6278	10.0366	15.5007	17.6269	18.5185
12	23.1596	24.3256	24.1884	9.625	15.9122	16.4609	18.8615
13	24.4627	22.6338	21.1249	9.2821	15.5693	17.3526	17.3526
14	21.2849	20.8733	20.279	8.6191	16.6667	18.0384	18.9301
15	23.4568	24.8743	20.1189	9.4879	18.6557	19.8217	19.6159
16	24.1198	23.5025	22.771	9.2135	18.6557	20.3018	20.5076
17	22.428	22.7024	22.1537	8.4134	17.3526	19.8217	20.0275
18	23.8455	19.8445	20.3932	7.9333	17.3526	19.0672	18.9987
19	22.3595	18.4957	20.4618	7.3388	15.2264	17.6955	17.1468
20	20.5304	19.3187	20.1189	7.8189	15.9808	17.5583	16.8725
21	11.7056	17.0096	17.5355	7.9561	14.2661	14.8148	14.129
22	17.8556	17.5583	16.4609	8.0933	14.3347	15.2949	13.2373
23	18.4957	17.4211	17.5583	7.5446	12.7572	14.7462	14.4719
24	19.0444	17.2839	17.947	7.3388	12.2771	14.1976	13.3059
Max	24.4627	24.8743	24.1884	18.4271	18.6557	20.3018	20.5076
Min	11.7056	15.1121	14.632	7.3388	7.0645	11.8656	12.0713
Avg	19.3130	18.9443	18.7262	11.2254	12.7401	15.9751	15.6779

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 406 / 33KV KRIPAMAAI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	22.9425	13.7517	23.6626	24.0056	19.4445	23.4225	24.1427
2	23.3539	18.1756	22.771	23.2167	19.5131	22.2908	24.3827
3	24.3142	18.7243	23.1139	22.5995	19.1358	22.5652	23.7312
4	24.2455	18.4157	23.3196	22.8739	18.6558	22.2565	23.6969
5	24.0741	21.5707	22.1193	22.2222	18.3814	21.9822	22.7024
6	23.937	21.5364	21.8793	21.262	18.8958	21.6393	22.5652
7	23.8341	21.7422	22.5309	21.605	21.1591	21.262	22.8739
8	22.5652	20.3361	22.4966	21.3649	19.7188	21.3992	21.6736
9	24.4514	23.7312	25.1372	21.9822	23.4225	25.583	24.3484
10	28.0865	25.3772	26.989	23.4225	28.0179	28.8752	27.8464
11	***	26.7833	29.6639	21.7765	29.6982	***	***
12	***	26.2346	29.7668	16.8724	29.4925	***	***
13	29.904	21.3992	29.9726	17.0096	27.5035	***	29.7325
14	29.8354	28.2237	28.738	18.4843	28.3608	28.9438	***
15	***	27.9836	***	17.8327	28.1207	29.6983	***
16	***	28.5323	***	19.6846	29.6982	***	***
17	29.9726	28.6008	***	19.1358	28.8409	29.2867	***
18	28.498	27.4692	28.5322	18.6215	29.6982	27.9836	27.7092
19	29.6983	25.8231	27.6406	19.5131	28.2922	27.7093	27.2292
20	29.1496	24.2113	29.4925	21.3992	29.6639	29.5953	28.7724
21	21.2277	23.8684	28.6351	20.9534	26.6804	28.3608	27.7435
22	23.9712	23.7312	27.6063	20.5762	26.509	27.0234	27.2635
23	24.6228	27.7435	27.8121	21.0905	25.1715	26.6118	27.332
24	20.7134	25.3773	26.0632	19.856	25.2058	24.0399	27.2635
Max	31.0014	28.6008	30.6242	24.0056	29.6982	30.9328	32.3732
Min	20.7134	13.7517	21.8793	16.8724	18.3814	21.262	21.6736
Avg	26.3318	23.7226	26.6290	20.7233	24.9700	26.3946	27.0305

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 407 / 33KV MIDC MIRAJ

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	29.2181	25.2172	***	24.8743	18.6329	***	***
2	28.6694	25.1486	26.7719	27.572	17.8326	***	***
3	28.8752	25.2172	26.9777	26.4975	17.7641	***	***
4	28.6008	23.7312	26.6347	26.5661	18.4271	29.8126	29.2867
5	28.0521	22.3595	27.572	26.5661	18.7015	***	29.744
6	26.2232	24.5313	25.0114	24.8057	18.8386	***	***
7	25.3544	23.2511	25.6745	25.9489	18.5643	***	29.1495
8	22.8396	22.2223	24.8057	22.2909	18.2214	***	***
9	27.9836	28.1893	***	17.0782	26.2232	***	***
10	***	***	***	17.1468	***	***	***
11	***	***	***	15.9351	***	***	***
12	***	***	***	15.8665	***	***	***
13	***	***	***	14.632	***	***	***
14	***	***	***	15.7293	***	***	***
15	***	***	***	16.5981	***	***	***
16	***	***	***	16.6667	***	***	***
17	***	***	***	16.5295	***	***	***
18	***	***	***	16.3923	***	***	***
19	***	***	26.4975	17.0782	***	***	***
20	28.3951	27.9836	26.5661	17.2839	28.9438	***	***
21	9.4879	24.7371	25.0114	17.5583	25.423	29.0124	***
22	19.9817	26.429	24.6685	17.7641	26.9091	28.4637	28.6008
23	25.423	26.3604	26.7033	18.7015	***	***	***
24	26.0174	***	27.8464	18.7015	***	***	***
Max	39.5748	42.9584	39.6434	27.572	45.9991	49.8629	48.0339
Min	9.4879	22.2223	24.6685	14.632	17.7641	28.4637	28.6008
Avg	29.8669	30.4785	30.2965	19.7826	30.4994	36.5808	35.9949



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 201 / 11KV JACKWELL LIS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5822	1.395	1.4769	1.6682	1.5524	1.3469	1.483
2	1.6473	1.4041	1.5256	1.6057	1.5554	1.5116	1.5708
3	1.6447	1.379	1.5147	1.5565	1.5421	1.5055	1.5612
4	1.644	1.3573	1.556	1.5519	1.5718	1.5364	1.5655
5	1.6179	1.3672	1.5333	1.5425	1.5973	1.541	1.4563
6	1.5025	1.3432	1.557	1.4457	1.6072	1.5626	1.3664
7	1.3676	1.3268	1.3698	1.337	1.4258	1.4075	1.2645
8	1.3642	1.2523	1.2662	1.3325	1.3534	1.241	1.3123
9	1.3816	1.1591	1.2747	1.4091	1.3839	1.2906	1.3363
10	1.2934	1.0921	1.5404	.7118	1.4228	1.2997	1.3633
11	1.4385	1.3832	1.5881	.7522	1.5265	1.5806	1.3847
12	1.4788	1.3741	1.6164	.7606	1.5447	1.6072	1.4708
13	1.5063	1.5421	1.5039	.7446	1.5566	1.5394	1.4739
14	1.2487	1.6248	1.3954	.692	1.3532	1.6137	1.3329
15	1.3536	1.4781	1.251	.6074	1.3271	1.4832	1.2354
16	.6424	1.3531	1.1801	.6516	1.3546	1.3567	1.23
17	1.1885	1.3478	1.2426	.6173	1.1047	1.3142	1.2056
18	1.487	1.3401	1.3344	.6081	1.3417	1.2986	1.2056
19	1.5061	1.6313	1.592	.6066	1.4339	1.443	1.4906
20	.7743	1.449	1.4167	.6112	1.3272	1.2892	1.3491
21	.0015	1.318	1.1498	.6059	1.3009	1.2514	1.1831
22	1.0242	1.0924	1.3383	.7004	1.286	1.254	1.0626
23	1.267	1.2725	1.4884	.695	1.2747	1.3078	1.3748
24	1.3543	1.2833	1.3078	1.3378	1.2959	1.3195	1.291
Max	1.6473	1.6313	1.6164	1.6682	1.6072	1.6137	1.5708
Min	.0015	1.0921	1.1498	.6059	1.1047	1.241	1.0626
Avg	1.3049	1.3569	1.4175	1.0063	1.4183	1.4126	1.3571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 202 / 11KV GANPATI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1704	2.1031	2.0557	2.1167	1.0776	2.1149	1.9997
2	2.0717	1.9303	1.9393	1.9174	1.9349	1.8865	1.8914
3	2.0332	1.8404	1.8633	1.8678	1.8564	1.8598	1.8284
4	1.9909	1.7767	1.8206	1.8362	1.8143	1.8301	1.794
5	1.9588	1.7415	1.8138	1.7954	1.784	1.7886	1.7901
6	2.0191	1.781	1.845	1.8008	1.8362	1.8486	1.8063
7	1.9364	1.7275	1.7873	1.6762	1.7408	1.8713	1.7585
8	1.813	1.727	1.7338	1.6991	1.6789	1.7473	1.6709
9	1.8459	1.7878	1.676	1.6853	1.6213	1.6682	1.5812
10	2.1203	1.9911	1.7089	.9663	1.7829	1.869	1.9292
11	2.5528	2.3809	1.9052	1.1401	2.1816	2.4346	2.4166
12	2.7077	2.4916	2.0957	1.2536	2.4447	2.473	2.4893
13	2.7603	2.5163	2.1773	1.3032	2.5461	2.4154	2.524
14	2.8299	2.4867	2.2238	1.3176	2.516	2.5576	2.5131
15	2.7077	2.4722	2.2336	1.291	2.5408	2.5339	2.5236
16	2.6296	2.4532	2.2175	1.2605	2.5924	2.5545	2.578
17	2.662	2.489	2.3617	1.2582	2.6067	2.6743	2.6229
18	2.7641	2.545	2.393	1.3184	2.5703	2.6707	2.6903
19	3.3895	3.2948	2.9376	1.6575	3.5612	3.3551	3.3517
20	2.0889	3.5422	3.147	1.9364	3.8308	3.7859	3.7731
21	2.9236	3.2845	3.0173	1.8686	3.3968	3.4294	3.3309
22	2.8227	2.6732	2.5916	1.4106	2.7976	2.7238	2.6574
23	2.469	2.4166	2.4516	2.4195	2.5227	2.5273	2.4591
24	2.357	2.1956	2.2321	2.2131	2.2253	2.2892	2.2036
Max	3.3895	3.5422	3.147	2.4195	3.8308	3.7859	3.7731
Min	1.813	1.727	1.676	.9663	1.0776	1.6682	1.5812
Avg	2.4010	2.3187	2.1762	1.6254	2.3108	2.3712	2.3410

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 203 / 11KV SANGLI WADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7225	1.7105	1.6995	1.6476	1.6911	1.8537	1.6636
2	1.6812	1.6598	1.6233	1.6053	1.6244	1.6735	1.611
3	1.6613	1.6758	1.6029	1.5493	1.6273	1.6407	1.5988
4	1.6408	1.6621	1.5851	1.531	1.5956	1.6461	1.6305
5	1.7764	1.5874	1.5817	1.5135	1.672	1.6453	1.7726
6	1.9929	1.6995	1.7048	1.6446	1.8841	1.8219	1.8382
7	1.8991	1.7166	1.6575	1.6613	.4153	1.8309	1.7985
8	1.8236	1.6465	1.608	1.595	1.4754	1.7467	1.7558
9	1.7164	1.6383	1.688	1.6095	1.4924	1.7378	1.7878
10	1.9073	1.8515	1.7749	.865	1.5744	1.8749	1.7947
11	2.0012	1.8475	1.8084	.8817	1.7147	1.9626	1.7947
12	2.0023	1.8176	1.7924	.8695	1.9365	1.9364	1.8983
13	1.9479	1.7665	1.7968	.8665	1.8374	2.0012	1.8773
14	1.9702	1.7254	1.8671	.8634	1.8343	2.0165	1.8109
15	1.9614	1.7063	1.8446	.8551	.9694	1.9936	1.8057
16	1.9353	1.7063	1.7985	.8573	1.9143	1.9685	1.8016
17	1.8671	1.7238	1.7524	.8375	1.8953	1.8297	1.7668
18	1.8533	1.7524	1.8316	.8566	2.0325	1.8686	1.8703
19	2.2809	2.2517	2.1603	.9877	2.3306	2.2704	2.2169
20	1.3077	2.4128	2.2904	1.2338	2.4899	2.3289	2.4198
21	2.1278	2.3373	2.1811	1.1767	2.4364	2.3	2.3478
22	2.1064	2.2275	2.2512	1.1462	2.3053	2.1964	2.2381
23	2.1114	2.0127	1.9845	1.0966	2.1971	2.1575	2.1323
24	1.8741	1.7619	1.8244	1.8103	1.9143	1.9149	1.912
Max	2.2809	2.4128	2.2904	1.8103	2.4899	2.3289	2.4198
Min	1.3077	1.5874	1.5817	.8375	.4153	1.6407	1.5988
Avg	1.8820	1.8291	1.8212	1.2317	1.7858	1.9257	1.881

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 403 / 33 KV- BALAJIMANDIR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1043	1.1163	.9671	.9671	1.0517	1.0517	1.0208
2	1.0631	1.1043	.9671	.9036	.9259	.9465	.9774
3	1.0099	1.0402	.9568	.8939	.8842	.9774	.9671
4	.9465	.9362	.8413	.8505	.8413	.8145	.9671
5	.9465	.9671	.9134	.8505	.9036	.7973	.8688
6	.9134	.9134	.9231	.8688	.8596	.8688	.8779
7	.7716	.7888	.7802	.8059	.7888	.7282	.7522
8	.6836	.7362	.7802	.7522	.7442	.6447	.7059
9	.7888	.8139	.8939	.8413	.7059	.7522	.8145
10	.9991	.9882	1.0099		.7442	.9465	.9362
11	1.1043	1.0517	.9991		.8596	.9465	.9465
12	1.0802	1.1963	1.0402		1.1043	1.1568	.9991
13	1.0402	1.2094	1.0174		1.0631	1.0802	1.1283
14	1.1043	1.2226	1.0402		1.086	1.1403	
15	1.0802	1.2894	1.0517			1.1403	1.3032
16	1.0562	1.262	1.0402		1.1568	1.182	1.2489
17	1.1317	1.0402	.9665		.9991	.9991	1.1283
18	1.0631	.9259	1.0288		1.0174	.8745	.9882
19	1.0745	.9259	1.0802		.9665	1.0802	.9882
20		10.5584	1.0288		1.0288	1.0923	1.0517
21	.9556	1.0802	1.1163		1.0517	1.1694	1.1043
22	1.1317	1.2357	1.1694		1.1694	1.1568	1.1694
23	1.262	1.2357	1.1694		1.1694	1.1694	1.2357
24	1.2226	1.1443	1.0745	1.0631	1.1694	1.0631	1.1043
Max	1.262	10.5584	1.1694	1.0631	1.1694	1.182	1.3032
Min	.6836	.7362	.7802	.7522	.7059	.6447	.7059
Avg	1.0232	1.4493	.9940	.8797	.9692	.9908	1.0123

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 404 / 33 KV -MJP SHERINALA STAGE NON SHEDDABLE EXPRESS HV FEEDERS  
 NO- Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.331	.3327	.3327	.3293	.3293	.3327
2	.1595	.3293	.3327	.331	.3258	.3293	.3344
3	.1595	.3275	.331	.3293	.3275	.563	.3327
4	.3155	.6602	.487	.331	.3293	.563	.4939
5	.3258	.6687	2.9116	.331	.331	.1104	.7259
6	.3224	.3327	.7259	.7259	.7762	.1115	.7293
7	.1543	.3293	.7122	.7225	.7156	.2183	.7225
8	.1578	.3293	.3275	.551	.5475	.2218	.4487
9	.1578	.4767	.3293	.7156	.563	.168	.3344
10	.1578	.7122	.331	.4001	.331	.1624	.5927
11	.3155	.5007	.3293	.2286	.3327	.1098	.4527
12	.0514	.3275	.5979	.4001	.3293	.1098	.1098
13	.1029	.3293	.5527	.4001	.719	.1601	.1098
14	.1052	.719	.326	.4001	.563	.2229	.719
15	.1543	.7225	.487	.4001	.1715	.1686	.7802
16	.3521	.7156	.7122	.4001	.7156	.7762	.7802
17	.1543	.4989	.4955	.4001	.7156	.5579	.7762
18	.2658	.4801	.3829	.4001	.7053	.7602	.7122
19	.2686	.6515	.5944	.4001	.3241	.5544	.7122
20		.7122	.7087	.4001	.3258	.4836	.7156
21	.3018	.6515	.5024	.1715	.3293	.719	.5579
22	.1543	.3327	.331	.1715	.8293	.7156	.331
23	.1578	.3327	.6618	.4001	.5024	.4453	.7225
24	.1595	.3275	.5613	.5596	.331	.331	.5579
Max	.3521	.7225	2.9116	.7259	.8293	.7762	.7802
Min	.0514	.3275	.326	.1715	.1715	.1098	.1098
Avg	.2005	.4916	.586	.4126	.4779	.3705	.5452

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 204 / 11 KV Shivaji Mandai

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5152	.5335	.471	.4649	.4672	.4793	.4755
2	.474	.49	.4466	.423	.4519	.4344	.4359
3	.4588	.4458	.4351	.4191	.4405	.4283	.4169
4	.4565	.4367	.4222	.4054	.4268	.4298	.4115
5	.4504	.4291	.4207	.4031	.4214	.4245	.4108
6	.4626	.4237	.4169	.4009	.4184	.4108	.4016
7	.4717	.423	.4237	.423	.4268	.4336	.4161
8	.4595	.4367	.4275	.4367	.4649	.4481	.4245
9	.4816	.4572	.4633	.4031	.4854	.4512	.4588
10	.538	.5037	.5144	.4504	.5342	.5144	.5335
11	.7064	.6287	.5944	.5601	.6737	.6722	.6904
12	.7849	.6562	.6569	.6112	.692	.7148	.7324
13	.7758	.6386	.7034	.628	.7278	.7186	.7087
14	.7682	.6257	.7049	.6592	.7118	.6996	.6813
15	.7369	.6127	.6485	.6028	.6729	.679	.6653
16	.7446	.5281	.6699	.5906	.6714	.6523	.6874
17	.7316	.6767	.6843	.6013	.6821	.6706	.6958
18	.7956	.6432	.7034	.6219	.6805	.7087	.6958
19	.8954	.7598	.7819	.7164	.8116	.7712	.788
20	.9915	.865	.9328	.9099	.9678	.9221	.9358
21	.0015	.8756	.9099	.8825	.9442	.9038	.897
22	.0838	.711	.7423	.6935	.7339	.7103	.7285
23	.6958	.5731	.5853	.5708	.5921	.5967	.5822
24	.6341	.5228	.5304	.5175	.5243	.535	.519
Max	.9915	.8756	.9328	.9099	.9678	.9221	.9358
Min	.0015	.423	.4169	.4009	.4184	.4108	.4016
Avg	.5881	.5790	.5954	.5581	.6093	.6004	.5997

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 201 / 11KV RAMMANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844		1.5623	1.4118	1.4335	1.5466	1.4861
2			1.5242	1.3032	1.3203	1.4335	1.4098
3			1.5242	1.2308	1.2826	1.358	1.4098
4			1.448	1.2308	1.2449	1.2826	1.3336
5			1.3717	1.2308	1.2826	1.2826	1.3336
6			1.2574	1.1403		1.2826	1.2955
7			1.2193	1.1222			1.2193
8	1.2071		1.105				1.1431
9			1.0669				1.105
10			1.105				1.1812
11	1.448	1.1403	1.2071	1.2955	1.086	1.2489	
12	1.5623	1.2127	1.358	1.2955	1.1765	1.3575	
13	1.448	1.2127	1.358	1.3336	1.2489	1.3717	
14	1.4861	1.2308	1.3957		1.2851	1.3575	
15	1.5242	1.2127	1.358		1.3213	1.3756	
16	1.5242	1.2127	1.358		1.3575	1.4118	
17	1.5242	1.1765	1.3957		1.3756	1.3756	
18	1.4861				1.4712	1.39	
19		1.5623	1.6108		1.7353	1.7528	1.647
20		1.8671	1.9366		1.9993	2.0957	1.9366
21		1.9433	1.9387		1.9239	2.0195	1.8656
22		1.829	1.7737		1.7147	1.9814	1.829
23		1.829		1.6598	1.8484	1.8671	
24	1.6598		1.6766	1.6108	1.5466	1.3756	1.7147
Max	1.6598	1.9433	1.9387	1.6598	1.9993	2.0957	1.9366
Min	1.2071	1.1403	1.0669	1.1222	1.086	1.2489	1.105
Avg	1.4959	1.4524	1.4341	1.3221	1.4555	1.5083	1.4607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 202 / 11KV SHAMRAO NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1475	1.1233	2.0302	1.9776	1.9944	1.9604	2.1003
2	1.057	1.0151	1.9151	1.8046	1.8575	1.8061	1.9784
3	.9884	.9473	1.8641	1.7604	1.7764	1.7341	1.9105
4	.9541	.9122	1.8183	1.7276	1.7413	1.6907	1.8282
5	.9389	.8909	1.7665	1.6911	1.7162	1.6617	1.8199
6	.9579	.8878	1.7231	1.6587	.8695	1.6149	1.7856
7	.9686	.8825	1.688	1.5905	.8947	.8749	1.7886
8	1.5699	.8269	1.5173	.7865	.788	.8131	1.6713
9	.7842	.7781	1.4518	.7621	.743	.7819	1.5554
10	.8391	.8101	1.4434	.7217	.7476	.7415	1.576
11	1.7383	1.6134	1.3908	.9526	1.5889	1.4914	.8406
12	1.858	1.6971	1.3691	1.0555	1.7467	1.6111	.8596
13	1.9258	1.6787	1.3744	1.0852	1.7703	1.7478	.9069
14	1.9479	1.6889	1.4251	.5594	1.8031	1.7497	.8581
15	1.9944	1.6964	1.661	.5716	1.8137	1.739	.9282
16	1.9723	1.7223	1.8682	1.0532	1.8198	1.781	.9427
17	1.9784	1.698	1.7581	.9404	1.8	1.6568	.9419
18	1.9121	.8833	.9282	.9305	1.8391	1.7261	.8756
19	1.0334	1.864	2.024	.945	2.1449	2.0073	1.9319
20	1.3458	2.3853	2.5278	1.2056	2.5118	2.681	2.5316
21	1.3123	2.4059	2.5293	1.2247	2.5534	2.617	2.4577
22	1.2102	2.3693	2.46	1.2026	2.4703	2.5011	2.4021
23	1.1957	2.3403	1.2689	2.3419	2.3859	2.4539	1.2498
24	2.2428	1.1606	2.2618	2.2291	2.2443	2.2546	2.2748
Max	2.2428	2.4059	2.5293	2.3419	2.5534	2.681	2.5316
Min	.7842	.7781	.9282	.5594	.743	.7415	.8406
Avg	1.4530	1.4282	1.7527	1.2824	1.7342	1.7374	1.5840



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 204 / 11KV CIVIL HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3667	.0476	.3955	.3845	.3475	.6928	.6927
2	.045	.0472	.3951	.3845	.3286	.6969	.6954
3	.0457	.0469	.3947	.365	.3275	.6909	.6634
4	.0442	.0472	.3947	.3658	.3298	.7126	.7053
5	.0446	.0431	.3955	.3856	.3483	.7061	.7056
6	.0438	.0507	.357	.4222	.0476	.6394	.7579
7		.0164	.3722	.3639	.0465	.3536	.6782
8	.2309		.2427		.0019	.3578	.581
9	.0255	.0194	.4675	.0156	.0282	.319	.5654
10	.0705	.0446	.5705	.0495	.077	.5327	.8367
11	.493	.4012	.4924	.3913	.5247	.9683	.538
12	.4111	.3726	.4062	.2054	.3799	.7232	.4866
13	.3562	.2168	.418	.3048	.389	.7617	.3475
14	.3867	.3795	.4187		.357	.8573	.3734
15	.3867	.354	.3814		.346	.7895	.3921
16	.157	.1898	.3449		.3102	.6623	.3822
17	.1143	.3204	.3938	.0255	.3753	.5848	.2843
18	.3357	.0579	.0545	.0503	.3362	.716	.3883
19	.0545	.4001	.4012	.0476	.1886	.8108	.6901
20	.0556	.3242	.2904	.0145	.3584	.7739	.546
21		.3429	.3547		.3206	.679	.6806
22		.3048	.2054		.3395	.5456	.6741
23		.2286		.1886	.1698	.5228	.3269
24	.3608	.0332	.338	.3646	.0654	.6626	.6272
Max	.493	.4012	.5705	.4222	.5247	.9683	.8367
Min	.0255	.0164	.0545	.0145	.0019	.319	.2843
Avg	.2014	.1865	.3689	.2405	.2643	.6567	.5675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 205 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4609	.7438	1.4571	1.3568	1.2883	1.3283	1.4144
2	.743	.708	1.3824	1.304	1.2547	1.2471	1.3306
3	.7247	.6805	1.3573	1.2613	1.2395	1.2288	1.3215
4	.7057	.6714	1.304	1.2415	1.2311	1.2067	1.2689
5	.6943	.6653	1.3017	1.2323	1.2666	1.2075	1.259
6	.7514	.6699	1.2788	1.2803	.6668	1.2197	1.2399
7	.6904	.6287	1.2171	1.1187	.647	.6462	1.2064
8	1.1538	.5944	1.0692	.5738	.5578	.5449	1.0388
9	.5456	.5365	.9526	.5091	.4893	.5114	.9571
10	.5114	.5068	.8847	.4755	.4687	.4786	.8901
11	.9602	.9934	.8593	.9205	.8703	.881	.4832
12	1.0106	1.0594	.8047	.8725	.9465	.9426	.487
13	1.0304	1.0601	.8192	.932	.9769	1.0082	.4992
14	1.115	1.0829	.9663	.4976	1.0783	1.0661	.5098
15	1.1653	1.0966	.9953	.5159	1.0699	1.0433	.5517
16	1.1066	1.1189	.9884	.5327	1.0806	1.0181	.5464
17	1.099	1.0486	.9587	.5098	.996	1.0196	.519
18	1.0944	.5426	.5182	.5037	.9966	1.0433	.5357
19	.807	1.4998	1.5333	.7057	1.4765	1.4525	1.3938
20	.945	1.8191	1.7688	.8672	1.6633	.8985	1.6697
21	.8497	1.8267	1.8351	.8741	1.8283	1.7962	1.7802
22	.8787	1.784	1.6466	.8825	1.7105	1.7398	1.7771
23	.8886	1.6781	.8947	1.5885	1.6327	1.8016	.8977
24	1.5436	.8078	1.5326	1.3718	1.4236	1.749	1.5585
Max	1.5436	1.8267	1.8351	1.5885	1.8283	1.8016	1.7802
Min	.5114	.5068	.5182	.4755	.4687	.4786	.4832
Avg	.9365	.9926	1.1803	.9137	1.1192	1.1283	1.0473

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 206 / 11KV TRIMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8934	.9747	1.8671	1.77	1.7273	1.744	1.8488
2	1.0037	.8954	1.7673	1.6217	1.6172	1.6347	1.7193
3	.9694	.8619	1.7101	1.5927	1.5646	1.5519	1.6774
4	.9183	.8261	1.6484	1.5287	1.5093	1.4792	1.576
5	.8916	.8078	1.5912	1.5082	1.4856	1.4685	1.5714
6	.8855	.8109	1.6057	1.467	.7804	1.4784	1.5661
7	.8787	.7628	1.5394	1.4011	.7621	.791	1.5013
8	1.5527	.7689	1.5272	.7385	.7255	.74	1.5051
9	.8741	.7659	1.5684	.759	.7628	.7948	1.6088
10	.993	.788	1.7962	.8345	.9389	.9656	1.8389
11	2.5971	1.954	2.3933	2.1727	2.3853	2.4409	1.2277
12	2.6337	2.0835	2.4249	2.303	2.3582	2.5689	1.2407
13	2.716	2.0611	2.4181	2.2481	2.3956	2.5206	1.2468
14	2.7213	2.13	2.4238	1.1767	2.5659	2.5476	1.2262
15	2.7328	2.1598	2.4588	1.1965	2.5861	2.5755	1.2734
16	2.7617	2.119	2.5385	1.2277	2.6456	2.5713	1.3062
17	2.7465	2.1	2.6113	1.1911	2.5774	1.3176	1.3146
18	2.6596	1.0562	1.3222	1.1568	2.5663	2.4714	1.3359
19	1.4243	2.242	2.7908	1.1805	2.7076	2.6619	2.7682
20	1.5562	2.636	2.9751	1.3748	2.8776	2.9859	2.9927
21	1.4007	2.6467	2.8704	1.3672	2.75	2.8981	2.8563
22	1.2681	2.4272	2.4276	1.2864	2.4699	2.5377	2.5812
23	1.1492	2.2656	1.2338	2.0927	2.2424	2.3594	1.2125
24	1.089	1.1104	2.1346	1.9033	1.9547	2.3098	2.0363
Max	2.7617	2.6467	2.9751	2.303	2.8776	2.9859	2.9927
Min	.8741	.7628	1.2338	.7385	.7255	.74	1.2125
Avg	1.6799	1.5522	2.0685	1.4625	1.9565	1.9756	1.7097

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 403 / 33 KV RISALA ROAD

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	23.9747	19.5816	22.3023	21.9639	21.6221	23.0042	22.5537
2	18.7929	17.764	21.0334	20.3521	20.343	20.9705	20.7477
3	18.4157	16.7695	20.4504	19.5839	19.6468	20.5487	19.7645
4	18.107	16.461	19.7874	19.1381	19.0878	19.9898	19.4558
5	17.9698	16.2209	19.4444	18.8295	18.8478	19.7497	19.1588
6	17.9355	16.4266	19.4787	15.878	18.4019	19.8286	19.1245
7	18.4843	16.941	20.7476	17.356	16.7695	18.45	20.0161
8	20.5487	16.7695	19.9818	14.8834	17.5584	18.7929	19.6388
9	17.6612	16.8038	20.2676	13.9575	16.9753	17.7298	19.8445
10	18.69	17.5583	22.3481	15.1578	18.1757	19.1358	23.1367
11	27.1149	23.4911	26.8382	21.022	26.2723	26.5615	23.9369
12	***	25.7099	28.594	24.2341	28.4523	29.3141	25.7202
13	***	26.317	29.5096	24.5427	29.8675	29.4228	25.6516
14	***	26.3809	29.8183	20.5762	29.7943	28.4282	25.5487
15	***	25.814	29.6228	20.0274	29.4707	27.7127	25.0686
16	***	25.0698	***	20.6105	***	28.3351	25.343
17	***	26.3958	***	21.1591	28.9815	28.6238	25.7545
18	***	23.011	26.3032	21.1934	27.8653	28.9518	25.4801
19	28.9095	28.898	***	22.0508	***	***	26.166
20	***	***	***	27.1606	***	***	***
21	23.2167	***	***	26.9205	***	***	***
22	20.9534	***	***	24.8286	***	***	***
23	22.5995	26.2346	23.9369	24.705	27.1588	27.1833	23.2168
24	25.5728	21.0563	24.4971	23.0167	24.8217	24.6708	24.1198
Max	32.9218	33.1161	36.0232	27.1606	35.4596	35.9054	35.2103
Min	17.6612	16.2209	19.4444	13.9575	16.7695	17.7298	19.1245
Avg	24.5795	22.7631	25.8177	20.7978	25.1113	25.4488	24.1516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 404 / 33KV KOLHAPUR ROAD

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	***	29.2182	***	***	***	***	***
3	***	27.8464	***	***	***	***	***
4	29.8354	28.0522	***	***	***	***	***
5	29.3553	28.1208	***	***	***	***	***
6	***	27.2292	***	***	***	***	***
7	***	26.8176	***	***	27.2291	27.0234	***
8	***	25.9946	29.904	25.3087	23.1139	24.76	***
9	25.9946	24.8286	29.8811	26.1318	25.1715	24.4856	29.5154
10	28.8067	29.4239	***	27.1605	26.2003	27.8464	***
11	***	***	***	***	***	***	***
12	***	***	***	***	***	***	***
13	***	***	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	***	***	***	***	***	***	***
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	29.7668	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	***	***	***	***
Max	43.8958	46.1363	48.5597	41.8382	48.378	49.4056	50.087
Min	25.9946	24.8286	29.8811	25.3087	23.1139	24.4856	29.5154
Avg	35.8192	34.5803	36.3664	33.6291	36.8422	36.7836	35.4874

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 201 / 11 KV SHASTRI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0669	1.8961	1.8772	1.8395	1.9149	1.8961
2	.9907	.9145	1.7633	1.7633	1.7067	1.7633	1.7444
3	.9907	1.7633	1.6871	1.6682	1.6305	1.7444	1.6682
4	.9145	1.6871	1.6871	1.6682	1.6305	1.6682	1.6682
5	.9145	1.6871	1.7437	1.6871	1.6682	1.6682	1.6682
6	.9907	1.8199	1.8576	1.6305	1.7059	1.6682	1.6305
7	.9907	1.7059	1.7059	1.6305	1.6682	1.6682	1.6305
8	.9145	1.6305	1.5928	1.6305	1.5928	1.5739	.8383
9	.8383	1.6305	1.5543	.7621	1.5354	1.5543	1.5354
10	.9907	1.6682	1.7814	.8383	1.7625	1.7248	1.8764
11	1.1431	1.9715	1.8576	.8383	2.0092	1.9904	1.8953
12	1.2193	1.9715	2.1043	.9907	2.1043	2.1231	2.0092
13	1.2193	1.9338	2.1043	.9907	2.1043	2.1231	2.1043
14	1.2193	1.9526	2.2182	.9907	2.1609	2.1231	2.1043
15	1.2193	2.0092	2.149	.9907	2.1609	2.1231	2.0854
16	1.2193	2.0854	2.2182	.9907	2.1609	2.1609	2.1609
17	1.2193	2.0477	2.2559	.9907	2.1797	2.1993	2.1231
18	1.2193	2.0854	2.2559	.9907	2.2175	2.2182	2.1043
19	1.3717	2.388	2.7478	1.1431	2.7101	2.6339	2.6339
20	1.5242	2.6731	2.9765	1.3717	2.9577	2.9765	2.9577
21	1.448	2.6166	2.8822	1.3717	2.7683	2.7683	2.7494
22	1.3717	2.5026	2.6731	1.2955	2.5404	2.5781	2.5592
23	1.2955	2.3321	2.4461	1.2193	2.4649	2.4461	2.4461
24	1.2193	1.1431	2.0862	2.105	2.0485	2.1805	2.1428
Max	1.5242	2.6731	2.9765	2.105	2.9577	2.9765	2.9577
Min	.8383	.9145	1.5543	.7621	1.5354	1.5543	.8383
Avg	1.1463	1.8869	2.0935	1.3098	2.0553	2.0664	2.0097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 202 / 11 KV FRUIT MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1132	.1132	.132	.1132	.1132	.1132
2	.12	.1132	.1132	.132	.1132	.1132	.1132
3	.12	.1132	.1132	.1132	.1132	.1132	.1132
4	.12	.1132	.1132	.1132	.1132	.1132	.1132
5	.12	.1132	.1132	.1132	.1132	.1132	.1132
6	.12	.1132	.1132	.132	.1132	.1132	.1132
7	.0686	.0754	.0754	.1132	.0754	.0754	.0943
8	.1029	.0754	.0943	.0754	.0566	.0943	
9	.1132	.0754	.1132		.0943	.1132	.1132
10	.1438	.0973	.1019	.0042	.1418	.1677	.1212
11	.1821	.135	.1159	.0084	.1741	.1364	.1537
12	.168	.1185	.117	.0171	.1741	.1795	.1537
13	.0278	.0985	.1392	.0107	.1764	.1391	.1273
14	.0084	.132	.0973	.0038	.1042	.1373	.16
15	.0232	.1517	.1732	.021	.1726	.1677	.1604
16	.0549	.1585	.206	.0286	.1917	.2014	.217
17	.0503	.1383	.2385	.0488	.1997	.2008	.1743
18	.17	.1046	.2266	.0572	.2069	.17	.132
19	.2115	.1509	.2132	.045	.2121	.1988	.1509
20	.1886	.1698	.1896	.003	.152	.1886	.1698
21	.1509	.1698	.1698		.1509	.1698	.1463
22	.1509	.1509	.1698		.1509	.1698	.1509
23	.1509	.1509	.1509		.1509	.1509	.132
24	.12	.1132	.132	.132	.1132	.132	.132
Max	.2115	.1698	.2385	.132	.2121	.2014	.217
Min	.0084	.0754	.0754	.003	.0566	.0754	.0943
Avg	.1169	.1227	.1418	.0652	.1407	.1447	.1377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 402 / 33KV SHERINALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6523	3.9609	3.6214	3.7346	3.9609	3.7912	3.7912
2	3.6008	3.7346	3.5082	3.6214	3.7346	3.7912	3.7912
3	3.6008	3.6214	3.3951	3.6214	3.7346	3.7912	3.7912
4	3.6008	3.6214	3.3951	3.6214	3.7346	3.7912	3.7912
5	3.6008	3.6214	3.3951	3.6214	3.8477	3.3385	3.6214
6	3.7037	3.7346	3.6214	3.678	3.8477	3.6214	3.5648
7	2.9835	3.5082	3.1687	3.3951	2.5463	3.3385	3.0556
8	3.1379	3.0556	2.8292	3.3951	3.2253	3.0556	
9	3.4517	3.4517	3.2819		2.9424	3.1687	3.3385
10	3.7912	3.8477	3.9043		3.4517	3.6214	2.8858
11	4.6399	3.9609	3.9609		3.9043	4.1307	3.7912
12	4.357	4.1872	4.3004		4.4702	4.2438	4.0175
13	4.4136	4.357	4.0741		4.4702	4.2438	4.0175
14	4.3004	4.5268	4.0741		4.1307	4.2438	4.3004
15	4.4702	4.4136	4.2438		4.2438	3.9043	4.5833
16	4.0741	4.2438	4.2438		4.4702	4.4136	4.4702
17	4.3004	3.9043	4.1307		3.9043	3.7912	4.4136
18	4.6399	4.0741	3.6763		4.1872	4.2438	4.357
19	5.4887	5.036	5.036		4.9794	5.0926	5.2058
20		4.9228	5.036		5.0926	5.0926	5.3189
21	4.0741	4.8097	4.4136		4.5833	4.8663	4.5268
22	4.357	4.357	.2829		4.6399	4.6965	4.3004
23	4.5268	4.1872	4.3004		4.2438	4.3004	4.5268
24	3.858	4.2438	3.9609	4.0175	4.1872	3.9043	3.9043
Max	5.4887	5.036	5.036	4.0175	5.0926	5.0926	5.3189
Min	2.9835	3.0556	.2829	3.3951	2.5463	3.0556	2.8858
Avg	4.0271	4.0576	3.7439	3.6340	4.0222	4.0199	4.0593



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 201 / 11 KV Government Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6468	.6468	.6219	.6722	.6468
2			.6161	.6283	.6036	.6283	.5975
3			.6161	.6099	.5914	.5914	.5975
4			.6161	.6099	.5914	.5975	.5975
5			.6224	.6161	.6099	.6161	.6036
6			.6413	.6099	.6468	.6348	.6413
7	.6348		.6413	.6036	.6468	.5914	.5847
8			.5228	.5914	.5487	.5487	.4755
9			.4755	.4854	.5304	.462	.462
10		.4525	.4066	.4668	.4887	.4163	.3761
11		.4525	.4066	.4525	.4805	.3801	.3982
12		.5068	.4344	.4706	.4481	.4706	.4298
13		.5068	.4755		.4344	.4572	.4656
14		.5249	.4572		.439	.4706	.5121
15		.5068	.4805		.499	.4706	.4755
16		.5249	.4805		.4805	.4668	.5121
17		.5304	.4706		.4835	.4755	.4805
18		.4835	.5194		.4835	.4938	.4805
19			.7468			.7499	.6733
20		.7602	.8501			.823	.788
21		.8059	.8507			.8326	.8145
22		.823	.8048			.8413	.8326
23		.7682			.8029	.7762	.7783
24			.7023	.6838	.6584	.7023	.6838
Max	.6348	.823	.8507	.6838	.8029	.8413	.8326
Min	.6348	.4525	.4066	.4525	.4344	.3801	.3761
Avg	.6348	.5882	.5863	.575	.5545	.5904	.5795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 202 / 11 KV Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5175	.5175	.5544	.499	1.1249	1.0879
2	.5544	.5175	.4854	.5121	.4668	1.0879	1.0563
3	.5175	.4805	.4854	.4854	.4294	.9562	.98
4	.5041	.4805	.4854	.4854	.4294	.9562	.924
5	.499	.4481	.4904	.462	.4481	.9377	.9287
6	.4854	.4481	.4904	.4668	.4435	.9426	.9426
7	.4715	.4251	.5281	.4572	.4435	.9192	.924
8		.4435	.4481	.4481	.4435	.9053	.8779
9		.462	.4805	.462	.4066	.9192	.9053
10	.439	.4435			.4435	.9144	.9377
11	.4572	.4572			.4435	.8962	.9192
12	.4755	.439	.4755		.4435	.8017	.8962
13	.4755	.439	.4938		.4344	.8962	.8962
14	.4938	.4938	.4251		.462	.9097	.9144
15	.4755	.4755	.499		.4854	.9097	.9327
16	.4938	.4572	.4066		.4066	.924	.8962
17	.4435	.4207	.4435		.5068	.9144	.8962
18	.4938	.4525	.4344		.4656	.9144	.8779
19	.6089		.6154			1.1554	1.1127
20		.6878	.7095			1.3992	1.3737
21	.7087	.6805	.6584			1.4937	1.3737
22	.6653	.6878	.7023			1.4358	1.3556
23	.6653	.6584	.6838		.6468	1.4828	1.3013
24	.4938	.5914	.6099	.5729	.5304	1.2895	1.2773
Max	.7087	.6878	.7095	.5729	.6468	1.4937	1.3737
Min	.439	.4207	.4066	.4481	.4066	.8017	.8779
Avg	.5227	.5047	.5258	.4906	.4639	1.0453	1.0245

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 402 / 33 KV KUPWAD CITY FEEDER NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 33 / INCOMING UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	17.508	15.5476	16.0323	16.2986	16.1866	16.6232	16.701
2	16.47	14.7028	14.9468	14.9691	15.3762	15.2607	15.5007
3	16.1272	14.257	14.501	14.5708	14.7931	14.7588	14.9863
4	15.7842	13.9301	14.158	14.4159	14.5874	14.4159	14.7463
5	15.3853	13.7929	13.5751	13.9535	14.5188	14.4033	14.6605
6	15.4322	13.9644	14.4204	13.9015	14.2318	14.6434	14.9348
7	15.4612	13.702	14.0763	13.2459	14.3038	14.9429	14.5594
8	12.1056	13.051	12.1251	11.8719	12.4806	12.7229	12.7504
9	10.8368	11.2117	11.0962	10.7785	11.3832	11.8507	11.4518
10	11.9959	10.9717	10.5944	10.5292	11.0408	11.31	11.0368
11	11.8244	10.9248	10.3544	10.0584	11.186	11.4683	11.015
12	11.9959	10.6973	10.5258	10.0024	11.2414	11.8244	11.5158
13	12.1753	11.0962	11.2551	10.6287	11.7216	12.0513	11.529
14	11.8273	10.6596	11.7353	9.6708	11.7101	12.1365	11.7559
15	13.7208	12.5361	12.0656	10.0823	12.2514	12.5361	12.0656
16	13.0476	11.7936	12.0313	10.2195	12.4086	12.5361	12.4771
17	12.867	12.0222	12.1068	10.7682	12.2771	12.6898	12.6955
18	12.9973	12.1948	12.3515	11.0083	12.4201	12.4709	11.5547
19	15.735	12.7229	14.8777	11.8655	13.6146	15.2321	14.0695
20	16.3581	17.7841	18.6832	15.8093	17.1126	19.4015	19.2045
21	15.1829	17.6812	18.6626	15.7408	17.1126	18.9095	18.8684
22	16.23	17.723	17.7024	15.9122	16.8039	18.5889	18.3065
23	16.6724	17.687	18.2374	16.0494	18.6071	19.3656	18.4911
24	16.9811	17.2245	17.8138	17.6577	18.0693	18.3093	18.1722
Max	17.508	17.7841	18.6832	17.6577	18.6071	19.4015	19.2045
Min	10.8368	10.6596	10.3544	9.6708	11.0408	11.31	11.015
Avg	14.3634	13.6616	13.9137	12.9170	13.9766	14.5188	14.2937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 203 / 11 KV VISHRAMBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6337			2.2805	2.3045	2.3045	2.2262
2	2.3285			2.0851	2.1948	2.1948	2.0851
3	2.3285			2.0633	2.1948	2.0851	2.0851
4	2.3285			2.0633	2.1948	2.0513	2.0633
5	2.3285			2.0851	2.1948	2.0513	2.0633
6	2.3594			2.0633	2.0851	2.1068	2.0633
7	2.2262			1.9547	2.0851	2.0633	1.9547
8	2.009			1.7918	1.9204	1.7741	1.9547
9	1.9004		1.8107	1.7918	1.8656	1.8296	1.8461
10	1.9004		1.8656	1.885	1.8656	1.9959	1.8804
11	1.9204		1.9204	1.8656	1.9753	2.0302	1.0974
12	2.009		1.9753	1.8804	2.0851	2.0302	2.0416
13	2.009		2.1399	1.9004	2.0851	2.0302	2.0851
14	2.3891		2.0851	1.9204	2.009	2.1399	2.0851
15	2.3891		2.0851		2.1176	2.1948	2.2177
16	2.3348		2.0851		2.2262	2.1948	2.1622
17	2.2805		2.1719		2.1719	2.1176	2.1399
18	2.3594				2.1262		2.3045
19	3.1276		2.7149		2.8172	2.6606	2.9321
20			3.0407		3.0087	3.095	3.1093
21	3.2373		2.8778			2.9864	3.0178
22			2.8778		2.9081	2.9321	2.9264
23	2.6337		2.7692	2.5789	2.8532	2.7692	2.8235
24	2.8166	2.6337		2.552	2.4691	2.524	3.1093
Max	3.2373	2.6337	3.0407	2.5789	3.0087	3.095	3.1093
Min	1.9004	2.6337	1.8107	1.7918	1.8656	1.7741	1.0974
Avg	2.3568	2.6337	2.3157	2.0476	2.2504	2.2679	2.2614

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 201 / 11 KV WALCHAND

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.6592	.6554	.6554	.6706	.6363	.6401
2	.6363	.6173	.6097	.644	.6097	.6363	.6135
3	.6097	.5754	.5677	.6287	.5906	.602	.6135
4	.583	.5639	.5563	.583	.5563	.5677	.5944
5	.5716	.5677	.5373	.5449	.602	.5716	.5373
6	.5906	.602	.5944	.6783	.7125	.6897	.6516
7	.7659	.7011	.6668	.663	.7011	.7087	.6821
8	.7735	.6325	.7583	.7773	.7202	.6668	.6821
9	.8497	.663	.8688	.9031	.8802	.7278	.8192
10	1.0326	.6706	1.0402	.9755	1.025	.9869	1.0479
11	1.3108	.6744	1.166	.964	1.1774	1.2231	1.1698
12	1.2651	.644	1.1812	1.0059	1.2727	1.2346	1.1431
13	1.2612	.6592	1.1203	.945	1.1698	1.1088	1.1469
14	1.1164	.6478	1.0402	.823	1.0707	.9907	.9945
15	1.2117	.6554	1.185	.945	1.1507	1.0822	1.1393
16	1.2346	.6592	1.2155	1.0555	1.2117	1.1431	1.1393
17	1.0517	.6859	1.105	.8802	1.0822	1.0631	.9831
18	.9259	.6325	.9221	.7278	.7659	.8002	.7926
19	.8307	.6859	.7964	.7659	.6783	.7278	.743
20	.8269	.7545	.7926	.8078	.7545	.7659	.7621
21	.4458	.6783	.6401	.7621	.7926	.7659	.7583
22	.6554	.7125	.6783	.743	.7735	.7506	.7659
23	.6744	.6821	.7354	.7202	.7468	.6935	.724
24	.6592	.6706	.6744	.7011	.663	.6783	.6783
Max	1.3108	.7545	1.2155	1.0555	1.2727	1.2346	1.1698
Min	.4458	.5639	.5373	.5449	.5563	.5677	.5373
Avg	.8596	.6540	.8378	.7875	.8491	.8259	.8259

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 207 / 11 KV DOORDARSHAN SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1164	1.086	1.0288	.9983	.9907	1.0174	1.0174
2	1.0326	.9755	.9488	.9107	.9107	.9183	.9183
3	.9755	.9183	.8916	.8688	.8764	.8573	.8688
4	.9221	.8726	.8535	.8192	.8269	.8078	.8383
5	.8802	.8383	.804	.7811	.7926	.7773	.7888
6	.8573	.823	.8078	.7849	.7964	.7773	.7926
7	.9183	.8078	.8383	.8269	.8535	.8612	.8535
8	.865	.8078	.8116	.8269	.823	.8421	.8345
9	.7545	.7811	.7316	.7164	.7545	.7278	.7811
10	.7506	.7697	.6897	.6973	.7468	.7392	.7621
11	.7659	.8002	.7087	.7392	.7621	.7164	.7392
12	.823	.7621	.7164	.7125	.6668	.724	.7049
13	.8345	.7811	.7392	.7316	.7316	.7316	.7049
14	.7888	.8002	.7392	.7316	.7545	.7468	.7583
15	.8269	.8345	.743	.7545	.7583	.7773	.7545
16	.8307	.8535	.7697	.7506	.7735	.7964	.7621
17	.8421	.8421	.7964	.7392	.7926	.804	.8002
18	.8116	.8269	.7964	.7545	.7888	.8154	.8002
19	1.0326	.9412	.9564	.8688	.9145	.9526	.9412
20	1.1393	1.0517	1.1241	1.0707	1.1164	1.0822	1.1126
21	1.0364	1.0822	1.1164	1.0631	1.1317	1.1012	1.1393
22	1.0479	1.0822	1.1355	1.0707	1.1164	1.1012	1.1203
23	1.1355	1.1431	1.1431	1.1241	1.1507	1.1469	1.1698
24	1.1279	1.1241	1.1203	1.0974	1.1317	1.1203	1.105
Max	1.1393	1.1431	1.1431	1.1241	1.1507	1.1469	1.1698
Min	.7506	.7621	.6897	.6973	.6668	.7164	.7049
Avg	.9215	.9002	.8754	.8516	.8734	.8726	.8778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 209 / 11 KV INDUSTRIAL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0729	1.9357	1.9433	1.9357	1.8747	1.9052	1.9585
2	1.9357	1.829	1.829	1.8138	1.768	1.7833	1.7833
3	1.8595	1.7375	1.7452	1.7452	1.6994	1.6918	1.7071
4	1.7985	1.6766	1.6766	1.669	1.6461	1.6461	1.6766
5	1.7528	1.6309	1.6385	1.6156	1.608	1.6156	1.6309
6	1.7756	1.6766	1.6537	1.6309	1.6461	1.6385	1.6537
7	1.7909	1.6537	1.6613	1.5699	1.6309	1.6842	1.6156
8	1.6156	1.5318	1.5165	1.5089	1.4861	1.5546	1.4784
9	1.4251	1.3717	1.3717	1.3794	1.3413	1.3717	1.3641
10	1.5089	1.3946	1.3641	1.3717	1.4022	1.4632	1.4251
11	1.6918	1.4327	1.6309	1.4784	1.6309	1.6232	1.608
12	1.8747	1.4861	1.7375	1.5546	1.7223	1.6842	1.7223
13	1.9204	1.547	1.7756	1.608	1.7452	1.7375	1.7909
14	1.89	1.5165	1.7833	1.6156	1.7604	1.8442	1.7756
15	1.9281	1.5623	1.7985	1.6842	1.8061	1.8595	1.8442
16	1.9052	1.608	1.829	1.6918	1.8442	1.8976	1.8747
17	1.9509	1.608	1.8442	1.6994	1.8747	1.8671	1.8519
18	1.8519	1.5546	1.829	1.6613	1.8214	1.7909	1.8214
19	2.2329	1.8214	2.111	1.9433	2.0957	2.0729	2.0957
20	2.4996	2.1338	2.4387	2.3472	2.4539	2.431	2.5072
21	1.9662	2.2024	2.431	2.2939	2.4691	2.4387	2.4615
22	2.1338	2.1795	2.2481	2.1643	2.3091	2.2862	2.2862
23	2.0805	2.1719	2.2329	2.1643	2.3167	2.2786	2.2786
24	2.0348	2.0805	2.1186	2.0348	2.1643	2.1491	2.1033
Max	2.4996	2.2024	2.4387	2.3472	2.4691	2.4387	2.5072
Min	1.4251	1.3717	1.3641	1.3717	1.3413	1.3717	1.3641
Avg	1.8957	1.7226	1.8420	1.7576	1.8382	1.8465	1.8465

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 201 / 11 KV Madgule AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.3658	.2172	2.6337		2.5339	2.0851
2	.7973	.3982	.2172	2.5606		2.4615	2.0995
3	.2126	.4298	.2195	2.5606		2.4615	2.1033
4	.2126	.4344	.2195	2.5701		2.4796	2.0814
5	.2328	.4024	.2507	2.5339		2.6063	2.1582
6		.3982		2.5339		1.267	2.1719
7	.2507	.3582	.2926	2.7149		2.9864	2.2497
8	.2481	.1629	.2926	.2149		.2896	.2534
9	.985	2.4714	.2534	.2454	.2561	.197	
10	1.7375	2.3998	.2534	.2715	.2561	.2353	
11	2.1357	2.4714	.2172	.2686	.2561	.2172	2.0851
12	2.3102		.2507		.2195	.2172	2.0851
13	2.1719	2.2386	.2149		.2195	.197	2.0633
14	2.4714	2.2207	.2149		.2195	.1991	2.0995
15	2.4691	2.1357	.2126		.2172	.1791	2.0814
16	2.1719	2.0452	.1772		.2534	.1991	1.9909
17	.2865	.2743	.1715		.2896	.2012	.2172
18	.2172	.2743	.2427		.3258	.181	.2534
19	.2686	.3292	.2835		.362	.2896	.3224
20	.3012	.3292	.3898		.3582	.2926	.3224
21	.3045	.2896	.2865		.3582	.3258	.3224
22	1.5123	.2534	2.9683		2.8296	2.5431	.2865
23	.2561	.2534	2.8959		2.7873	2.1719	.2507
24	.1829	.2896	.2534	2.8166		2.6063	2.009
Max	2.4714	2.4714	2.9683	2.8166	2.8296	2.9864	2.2497
Min	.1829	.1629	.1715	.2149	.2172	.1791	.2172
Avg	.9542	.9229	.4781	1.8271	.6139	1.1391	1.4360



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 202 / 11 KV Atpadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1458	.9877	1.1462	1.2437	1.2071	1.1222	1.2437
2	1.1203	1.0136	1.0745	1.2071	1.2127	1.1104	1.267
3	1.1576	1.0387	1.0608	1.2071	1.2254	1.0745	1.2894
4	1.1949	1.1222	1.0608	1.2308	1.2308	1.1104	1.3112
5	1.2696	1.3032	1.1827	1.267	1.262	1.1584	1.3611
6		1.39			1.2308	1.267	1.4118
7	1.3306	1.4118	1.3306	1.2308	1.2308	1.3756	1.2071
8	1.2936	1.4118	1.3676	1.182		1.3756	1.086
9	1.3032	1.4118	1.39	1.1765	1.3535	1.4266	1.3169
10	1.3535	1.4327	.4755	1.1641	1.3535	1.448	1.4632
11	1.3575	1.4327	1.448	1.1765	1.3394	1.4327	1.4998
12	1.379		1.448		1.3394	1.448	1.4632
13	1.4266	1.4327	1.3969		1.39	1.4449	1.4632
14	1.3937	1.4685	1.3611		1.3756	1.4118	1.4266
15	1.4266	1.4327	1.3466		1.4118	1.3969	1.3756
16	1.4299	1.3969	1.3466		1.3756	1.3756	1.3394
17	1.4148	1.4327	1.3717	1.1765	1.4118	1.3352	1.4118
18	1.4118	1.4685	1.5424	1.2071	1.448	1.267	1.5203
19	1.4266	1.576	1.701	1.2127	1.576	1.3253	1.5043
20	1.4118	1.5927	1.7718	1.2437	1.576	1.4118	1.5402
21	1.4327	1.5565	1.576	1.2489	1.576	1.4815	1.4327
22	1.4118	1.4327	1.5203	1.2803	1.448	1.448	1.3032
23	1.3253	1.2894	1.3756	1.2489	1.3394	1.4266	1.2308
24	1.1827	.9412	1.182	1.3169	1.262	1.1765	1.1946
Max	1.4327	1.5927	1.7718	1.3169	1.576	1.4815	1.5402
Min	1.1203	.9412	.4755	1.1641	1.2071	1.0745	1.086
Avg	1.3304	1.3468	1.3251	1.2234	1.3555	1.3271	1.3610

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 203 / 11 KV Pujarwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2561	.2172	.0366		.0543	.0895
2	.2172	.2896	.181	.0366		.0543	.0905
3	.2172	.2926	.181	.0366		.0543	.0732
4	.2507	.3258	.181	.0362		.0543	.0724
5	.2865	.3292	.181	.0362		.0724	.0716
6		.3258		.0362		.0876	.0709
7	.3224	.3582	.2378	.0358		.0905	.0716
8	.0895	.0543	.0543	.0358		.0905	.0543
9	.0905	.0537	.1829	.2896	.3982	.3292	.0537
10		.0537	.1829	.3224	.4163	.4344	.0537
11	.1267	.0537	.1448	.3544	.3982	.4298	
12	.1254		.2534		.3258	.4344	.0549
13	.0905	.1433	.2865		.3258	.394	.0549
14	.0716	.1433	.2865		.362	.3898	.0549
15	.0543	.1433	.2835			.3582	.0366
16	.0537	.1433	.2303			.362	.0549
17	.0543	.0716	.0514		.0732	.0537	.0549
18	.0549	.0716	.052		.0732	.0543	.0905
19	.0905	.0716	.0532		.0732	.0716	.0905
20	.0914	.0716	.0709		.0732	.0724	.0905
21	.0905	.0716	.0716		.0732	.0895	.0905
22	.2534	.2172	.0543		.0724	.0724	.3982
23	.2865	.2172	.0543		.0543	.0732	.3982
24	.2353	.2534	.2172	.0549		.0543	.0905
Max	.3224	.3582	.2865	.3544	.4163	.4344	.3982
Min	.0537	.0537	.0514	.0358	.0543	.0537	.0366
Avg	.1540	.1744	.1613	.1093	.2092	.1763	.0983

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 204 / 11 KV Pujarwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1433	.1829	.1829	.1646	.1772	.1075
2	.1791	.1448	.1829	.1829	.1629	.1417	.1448
3	.1791	.1829	.1829	.1829	.1463	.1417	.1463
4	.1791	.181	.181	.181	.1448	.1448	.181
5	.181	.1829	.2172	.181	.1433	.181	.1829
6		.181		.181	.1629	.2172	.181
7	.2172	.2149	.2172	.181	.1629	.2172	.1448
8	.2172	.1448	.2172	.1791		.2172	.1791
9	.181		.2172	.1991	.1791	.181	.2172
10	.1829	.1448	.2172	.2012	.1791	.1463	.2172
11	.1448	.1448	.181	.1991	.1791	.1448	.2172
12	.1463		.181		.1791	.1433	.2172
13	.181	.1448	.1433		.1791	.181	.2172
14	.181	.1448	.1433		.1791	.1791	.2172
15	.1433	.1448	.1417		.1791	.1772	.2172
16	.1448	.1448	.1417		.1791	.1791	.2172
17	.1791		.1372		.2149	.1448	.2195
18	.181	.1448	.1753		.2507	.1433	.2561
19	.1791	.2172	.1772		.2507	.1448	.2507
20	.2172	.2172	.2126		.2481	.1829	.2507
21	.2195	.2195	.2149		.2481	.181	.2507
22	.181	.2195	.2172		.2126	.1448	.2149
23	.1829	.1829	.181	.1829	.2126	.1433	.2172
24	.1791	.1448	.1829	.1829	.181	.1772	.1086
Max	.2195	.2195	.2172	.2012	.2507	.2172	.2561
Min	.1433	.1433	.1372	.1791	.1433	.1417	.1075
Avg	.1807	.1710	.1846	.1859	.1887	.1680	.1989

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 205 / 11 KV Madgule Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.2172	.2172	.1829	.2353	.2149	.2149
2	.181	.2507	.1791	.1829	.2378	.1791	.2534
3	.181	.2534	.1791	.1829	.2534	.1829	.2561
4	.1791	.2195	.2149	.181	.2561	.1829	.2896
5	.2149	.3258	.2534	.2534	.2534	.2561	.2926
6		.3582		.362	.2378	.3292	.2896
7	.3224	.2715	.3292	.362	.2353	.3658	.2896
8	.3582	.2865	.2926	.2865		.3658	.2561
9	.3258	.2507	.2896	.2715	.2507	.2534	.2534
10	.3258	.2149	.2534	.2743	.2149	.1829	.2172
11	.3292	.2149	.181	.2172	.1791	.181	.2172
12	.2534		.1791		.1791	.1791	.181
13	.2195	.2172	.1791		.181	.2172	.1829
14	.1791	.2172	.1791		.2195	.2149	.2195
15		.2195	.1772		.2195	.2481	.2195
16	.2149	.2195	.1772		.2195	.2149	.2195
17	.2534	.2172	.1715	.2353	.2534	.2534	.2172
18	.2865	.2534	.2103	.2353	.3258	.2743	.2534
19	.2715	.3292	.2835	.2561	.3258	.2896	.3224
20	.2743	.3292	.3898	.2534	.3258	.3292	.3224
21	.2896	.3292	.3582	.2378	.3224	.362	
22	.2507	.2561	.2896	.2353	.2507	.2865	.2865
23	.2534	.2172	.2534	.2195	.2507	.2534	.2507
24	.181	.2195	.2172	.2195	.2172	.2149	.2172
Max	.3582	.3582	.3898	.362	.3258	.3658	.3224
Min	.1791	.2149	.1715	.181	.1791	.1791	.181
Avg	.2512	.2560	.2372	.2447	.2454	.2513	.2488

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 206 / 11 KV Atpadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2178	1.9909	1.1584	.1829		.181	.2172
2	1.1641	1.9879	1.086	.1829		.1791	.2507
3	1.1641	1.9004	1.0498	.1829		.1791	.2534
4	1.267	1.6461	1.0608	.181		.1791	.2195
5	1.9004	1.5927	1.0974	.181		.2149	.2172
6		1.5729		.2172		.2149	.2507
7	1.9909	1.9728	1.3032	.2172		.2149	.2172
8	.2534	.2149	.2172	.2149		.2149	.1791
9	.2195	.2149	.2534	1.448	2.0995	1.6651	.181
10	.181	.2149	.2534	1.5223	2.1357	1.829	.181
11	.1791	.2149	1.7375	1.5384	2.1491	1.828	.181
12	.1448		1.7375		.3982	1.8267	.2172
13	.1433	.2172	1.6834		.3258		.181
14	.181	.2172	1.6118		1.97	1.8099	.1829
15	.1829	.2195	1.6655		1.8804	1.7551	.1829
16	.1478	.2195	1.0631		1.7909	1.6297	.2058
17	.1829	.2195	.1715		.2149	.1448	
18	.181	.2195	.208		.2507	.1829	
19	.2172	.2561	.2481		.2507	.2172	
20	.2149	.2561	.2835		.2534	.2507	.2534
21	.2481	.2534	.2507		.2534	.2715	.2534
22		1.448	.2534		.2172	.2195	1.6461
23	1.9909	1.3032	.2172		.2172	.181	1.6461
24	1.2178	1.7909	1.2308	.1829		.2172	.2195
Max	1.9909	1.9909	1.7375	1.5384	2.1491	1.829	1.6461
Min	.1433	.2149	.1715	.181	.2149	.1448	.1791
Avg	.6632	.8758	.8627	.5210	.9605	.6785	.3493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 401 / 33 KV Soot Girani

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1161	3.2579	3.0407	3.0727	3.0407	3.0407	2.9321
2	3.1161	3.4019	3.1493	3.0727		3.0407	3.0087
3	3.2236	3.3665	3.1493	2.9321		3.2579	3.095
4	3.2579	3.4385	2.963	2.9321		3.3311	3.1824
5	3.1493	3.5294	3.0727	3.0087		3.546	3.2579
6		3.6214		2.9012		3.546	3.3471
7	3.2579	3.638	3.0727	3.1161		3.2236	3.2579
8	3.2579	2.5789	3.0727	2.8704		3.0087	3.1824
9	3.1493	2.6337	3.0087	3.0178	3.1824	3.0407	3.0407
10	3.1824	2.6886	3.1161	3.0178	3.5665	2.9012	2.9321
11	3.0407	2.7149	2.6606	3.0407	3.4208	2.9321	2.7149
12	3.0727		2.7149		3.1493	3.0178	2.8532
13	3.0407	2.9012	2.6863		2.9321	2.8235	2.963
14	3.0407	2.7938	2.7938		2.9321	2.7435	2.8532
15	3.1824	3.0087	3.0298		3.0178	2.552	2.8532
16	2.9864	3.0087	2.6046		3.0727	3.4568	2.8532
17	3.0727	1.2894	2.5206		3.0727	2.9321	2.7692
18	3.0407	1.3432	2.4966		2.963	2.7435	2.7149
19	2.8235	1.3432	2.5514		2.963	2.7149	2.8532
20	2.6863	3.0087	2.9767		3.0727	2.5789	2.8532
21	2.6063	2.9321	3.0624		3.0407	2.4983	2.7435
22	3.0087	3.1493	2.9321		3.1493	2.6863	2.8235
23	3.4208	3.0407	3.1493		3.0407	2.8235	2.9321
24	.1629	3.2922	3.0407	3.0727	3.0407	3.1493	2.963
Max	3.4208	3.638	3.1493	3.1161	3.5665	3.546	3.3471
Min	.1629	1.2894	2.4966	2.8704	2.9321	2.4983	2.7149
Avg	2.952	2.8687	2.9072	3.0046	3.0975	2.9829	2.9575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 201 / 11 KV Nelkaranji AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1694			.3814
2		1.134			.3641
3		1.2071			.3467
4		1.226			.3467
5		1.3957			.3467
6		1.6221			.3641
7		1.9993			.3988
8		.0943			.3814
10			2.2611		
11	.1448		2.2611		
12	.1267		2.2786		
13	.1086		2.191		
14	.0905		2.0858		
15	.1086		2.0683		
16	.0905		2.0508		
21			.4382		
22			.4527		
24	1.3392	1.1883		.415	.3814
Max	1.3392	1.9993	2.2786	.415	.3988
Min	.0905	.0943	.4382	.415	.3467
Avg	.2870	1.2262	1.7875	.415	.3679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 202 / 11 KV Zare AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762			.8383
2		.0762			.7926
3		.0762			.7926
4		.0762			.823
5		.0762			.9145
6		.0914		1.0669	1.0364
7		.1067			1.0669
8		.0762			.0762
9					.0762
10			.061		
11	1.326		.061		
12	1.2955		.061		
13	1.2651		.061		
14	1.2955		.061		
15	1.3565		.061		
16	1.1431		.061		
21			.0914		
22			.9907		
24	.061	.0762		1.0212	.884
Max	1.3565	.1067	.9907	1.0669	1.0669
Min	.061	.0762	.061	1.0212	.0762
Avg	1.1061	.0813	.1677	1.0441	.7301



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 203 / 11 KV Zare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3258			.362
2		.3077			.3258
3		.2896			.3258
4		.2715			.3258
5		.362			.362
6		.362		.4706	.3982
7		.3856			.4706
8		.3801			.3982
9					.362
10			.3258		
11	.362		.3258		
12	.3982		.3077		
13	.4344		.3077		
14	.4163		.3077		
15	.4163		.3361		
16	.362		.362		
21			.543		
22			.4706		
24	.3258	.362		.362	.362
Max	.4344	.3856	.543	.4706	.4706
Min	.3258	.2715	.3077	.362	.3258
Avg	.3879	.3385	.3652	.4163	.3692

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 204 / 11 KV Nelkaranji Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0905			.0905
2		.0905			.0905
3		.0905			.0905
4		.1086			.0905
5		.1267			.1086
6		.1629			.0857
7		.2172			.1448
8		.1448			.1448
9		.1267			
10			.1448		
11			.1629		
12			.181		
13			.1448		
14			.1629		
15			.1448		
16			.1448		
21			.1629		
22			.1448		
24	.1086	.0876		.1086	.0905
Max	.1086	.2172	.181	.1086	.1448
Min	.1086	.0876	.1448	.1086	.0857
Avg	.1086	.1246	.1549	.1086	.1040

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 205 / 11 KV Mitaki AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8063			.0905
2		.8145			.0905
3		.8145			.0905
4		.8326			.0905
5		.8688			.0905
6		1.0136			.0905
7		1.267			.1086
8		.0905			.0905
10			1.448		
11	.0724		1.3575		
12	.0905		1.267		
13	.0905		1.267		
14	.0905		1.267		
15	.0905		1.2489		
16			1.1946		
21			.1086		
22			.0905		
24	.8326	.8326		.0724	.1086
Max	.8326	1.267	1.448	.0724	.1086
Min	.0724	.0905	.0905	.0724	.0905
Avg	.2112	.8156	1.0277	.0724	.0945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 206 / 11 KV Walvan AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762			.5639
2		.0762			.5487
3		.0762			.5487
4		.0914			.5792
5		.1067			.6097
6		.0914			.6706
7		.0914			.7316
8		.0762			.0762
9		1.1431			
10			.0914		
11	1.3565		.0914		
12	1.2803		.0914		
13	1.2193		.1067		
14	1.2346		.1067		
15	1.2498		.1067		
16	1.0974		.0914		
21			.1219		
22			.7011		
24	.0762	.0762		.6859	.5792
Max	1.3565	1.1431	.7011	.6859	.7316
Min	.0762	.0762	.0914	.6859	.0762
Avg	1.0734	.1905	.1676	.6859	.5453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11 KV Zare (Zare) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1254	.1478	.4729	.6859	.587	.5575
2	.1463	.1254	.1478	.4664	.6401	.5647	.5213
3	.1478	.1029	.1463	.5075	.6401	.5575	.4858
4	.1663	.1029	.1463	.5144	.6401	.5721	.4858
5	.1867	.1829	.1867	.5575	.6859	.6161	.5719
6	.2614	.2218	.2218	1.0936	.8381	.7876	.7468
7	.2241	.1829	.2126	1.0425	.9907	.945	.7482
8	.1867	.1907	.1823	.2126	.1448	.1372	.1677
9	.945	.7316	.1433	.1187	.1402	.1214	.9031
10	.9031	.9259	.104		.1017	.1402	.9633
11	.9214	.9332	.0876		.1029	.1174	.9145
12	.7282	.9214	.0867		.1326	.1341	.9031
13	.8025	.9976	.1341		.1357	.1372	.8916
14	.8619	.9701	.1389		.1372	.1387	.8741
15	.8802	.9412	.1357		.1526	.1387	1.0105
16	.8253	.8833	.1341		.128	.16	.8345
17	.1389	.128	.1326		.1581	.1235	.1658
18	.1658	.1677	.1457		.1658	.1715	.1658
19	.2454	.2126	.1753		.1734	.2454	.2481
20	.2353	.2804	.3012		.2172	.3189	.2507
21	.2172	.2481	.2534		.2195	.2715	.2172
22	.2012	.2172	.7926		.7407	.639	.2195
23	.1448	.1829	.7316		.6706	.6093	.1791
24	.1433	.1448	.1478	.5868	.7316	.602	.5868
Max	.945	.9976	.7926	1.0936	.9907	.945	1.0105
Min	.1389	.1029	.0867	.1187	.1017	.1174	.1658
Avg	.4094	.4217	.2098	.5573	.3906	.3682	.5672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / Vibhutwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0867	.0867	.0895	.0762	.0693	.0693
2	.0693	.0867	.0867	.0709	.0701	.0693	.0693
3	.0701	.0867	.0867	.0526	.0701	.0693	.0693
4	.0876	.0686	.0867	.0895	.0701	.0693	.0693
5	.1227	.104	.0867	.1086	.1052	.0867	.0867
6	.1387	.1402	.1734	.2012	.1753	.1734	.156
7	.156	.1214	.1387	.1254	.1402	.1387	.1387
8	.1402	.0867	.104	.1254	.1052	.0867	.0678
9	.1052	.1214	.104	.1029	.1052	.0867	.0857
10	.1214	.0693	.0693		.104	.0857	.0995
11	.0693	.1387	.0857		.104	.0867	.0838
12	.1387	.0867	.0995		.104	.0867	.0848
13	.104	.0867	.1017		.104	.104	.1174
14	.0867	.0867	.1147		.104	.1214	.0995
15	.0867	.0867	.1174		.104	.0857	.1006
16	.0867	.1734	.1475	.1227	.0867	.104	.1147
17	.1387	.104	.1326	.1928	.104	.104	.108
18	.104	.0867	.1134	.1753	.1387	.1214	.112
19	.156	.1907	.1526	.1402	.1734	.1372	.1578
20	.156	.1734	.197	.1928	.156	.1543	.1433
21	.1214	.1387	.2195	.1402	.1214	.1387	.1663
22	.0867	.1214	.1463	.1052	.1214	.1214	.1478
23	.0867	.104	.1097	.0876	.0867	.0867	.1086
24	.0876	.104	.0867	.1075	.0701	.0693	.0867
Max	.156	.1907	.2195	.2012	.1753	.1734	.1663
Min	.0693	.0686	.0693	.0526	.0701	.0693	.0678
Avg	.1079	.1106	.1186	.1239	.1083	.1024	.1060

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9374	1.0242	.9503	.0953	.0762	.0953	.0953
2	.9061	1.0242	.9069	.0762	.0762	.0953	.0953
3	.9061	.9488	.8962	.0762	.0762	.0953	.0953
4	.9488	.9488	.8962	.0762	.0762	.0953	.0953
5	1.0279	1.1012	.8962	.0953	.0953	.0953	.1334
6	1.2483	1.2809	.9922	.1334	.1143	.1334	.1524
7	1.5203	1.4723	1.2003	.343	.1524	.1715	.1524
8	.1143	.1143	.1715	.2204	.1524	.1143	.1524
9	.1143	.1143	1.5223	1.5074	1.757	1.6549	.1143
10	.1334	.1143	1.5893		1.8233	1.8023	.0953
11	.1143	.0953	1.5364		1.7238	1.829	.0857
12	.0953	.0953	1.4899		1.6221	1.5729	.0714
13	.0953	.0953	1.4251		1.6057	1.5402	.0953
14	.0953	.0953	1.4251		1.5384	1.4899	.0953
15	.0953	.0953	1.4899		1.668	1.5061	.1143
16	.1143	.1143	1.2803	1.3435		1.2452	.0857
17	.1143	.1143	.1143	.1715	.0953	.0857	.1334
18	.1715		.1143	.1715	.0953	.1334	.1524
19	.1715	.1905	.3048	.1905	.1143	.1905	.1905
20	.1905	.1905	.1715	.1905	.1524	.1905	.1905
21	.1524	.1715	.1524	.1715	.1524	.1715	.1715
22	1.2763	.9962	.1143	.1143	.1334	.1334	1.1797
23	1.1305	.9762	.0953	.0762	.1143	.1143	1.1203
24	1.0155	1.0688	.9667	.0953	.0762	.0953	.1143
Max	1.5203	1.4723	1.5893	1.5074	1.8233	1.829	1.1797
Min	.0953	.0953	.0953	.0762	.0762	.0857	.0714
Avg	.5287	.5410	.8626	.2860	.5866	.6105	.2076

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 201 / 11 KV Hivtad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3123	.7621	1.2631	.1387		.128	.1326
2	1.2963	.8573	1.2631			.128	.1341
3	1.3443	.8097				.128	.1543
4	1.2955	.7621	1.3603			.1294	.1753
5	1.3599	.9175	1.4586		.197	.168	.2865
6	1.704	1.1279				.2402	
7	2.0317	1.7737	1.9662			.2279	.2172
8	.08	.1715	.1357		.1867	.1337	
9	.0724	.1107	1.9524		1.5432	2.2119	.16
10	.0914	.0926	1.9109		.2652	2.4863	.1677
11	.096	.0655	1.8176		2.4291	2.5857	.1486
12	.1067	.0857	1.8176		2.2253	2.0972	.1269
13	.0934	.0876	1.6446		2.1338	2.1548	.1269
14	.1067		1.7604		2.0729	2.1628	.1166
15	.1067	.0983	1.8027		1.829	2.17	.0987
16	.1341	.1134	1.9433		1.5242	2.1628	.0903
17		.128	.1311		.12	.1341	
18	.141		.1509		.1619	.1715	
19	.2774		.2601		.176	.2328	
20	.2401		.2804		.2401	.3012	.2743
21	.1715		.2374		.2058	.2743	.2772
22	.6706		.1907		.1715	.2454	
23	.7811		.1595		.1463	.1734	
24	1.3443	.7907	1.2483	.1387	.1463	.128	.1475
Max	2.0317	1.7737	1.9662	.1387	2.4291	2.5857	.2865
Min	.0724	.0655	.1311	.1387	.12	.128	.0903
Avg	.6460	.5150	1.1252	.1387	.8764	.8740	.1667



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 202 / 11 KV Shetphale AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1543	.1829			.7621	.7811
2	.1772	.1543	.1791			.8192	.759
3	.1791	.1543	.1848			.8097	.7432
4	.1646	.1543	.2012			.8192	.7682
5	.1829	.2229	.2218		1.2936	.8907	1.0159
6	.2801	.2915	.2801			.9994	
7	.3018	.2572	.2987			1.5775	1.166
8	.1753	.1715	.1829			.0187	
9	1.2803	1.1069	.1829		.1715	.1829	.1204
10	1.2193	1.1561	.181		.1543	.1417	1.1584
11	1.2254	1.2334	.1612		.1578	.1214	1.0997
12	1.1431	1.2498	.1772		.1543	.1595	1.1111
13	1.1584	1.2597	.1543		.1372	.1612	1.2163
14	1.1736		.1526		.1543	.1595	1.1279
15	.1147	1.2717	.1677		.12	.1715	1.0802
16	.8802	1.2334	.1658		.1075	.1943	1.012
17		.176	.1844		.1524	.2187	
18	.1143		.2204		.2058	.3018	
19	.2401		.2686		.2229	.3292	
20	.2915		.3475		.2743	.3506	.2957
21	.2743		.2926		.2801	.2835	.3142
22	.1663		1.0395		1.0669	.9282	
23	.1715		.9602		1.004	.8539	
24	.1848	.1543	.181	.9061	.8859	.8097	.7621
Max	1.2803	1.2717	1.0395	.9061	1.2936	1.5775	1.2163
Min	.1143	.1543	.1526	.9061	.1075	.0187	.1204
Avg	.4903	.6119	.2737	.9061	.3849	.5027	.8548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 203 / 11 KV Banpuri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1372	.1433			.0486	.4755
2	.1734	.1372	.1448			.4572	.4877
3	.1715	.1372	.1463			.4572	.5218
4	.1865	.0137	.1267			.4915	.5312
5	.2103	.1543	.1646		1.0029	.6154	.7274
6	.2328	.1715	.2218			.6706	
7	.2614	.2229	.2587			.8333	.7682
8	.2035	.1753	.1612		.1663	.1372	
9	.8482	.8322			.128	.1029	.8002
10		.8322	.1578		.1029	.1006	.7865
11	.6325	.8697	.1772		.1158	.0995	.7362
12	.6249		.1509		.1067	.1372	.6401
13	.6401	.8192	.1524		.0934	.1492	.2454
14	.5864	.7682	.16			.144	.6661
15	.5335	.6316	.1406			.1296	
16	.4572	.5487	.1581		.1334	.128	.7011
17		.192	.192		.1524	.1492	
18	.1524		.213		.1886	.2195	
19	.2401		.2401		.1943	.2743	
20	.2229		.2896		.0219	.298	.2835
21	.2058		.2507		.1847	.2658	.2534
22	.1715		.7282		.6097	.7202	
23	.1543		.6249		.5761	.5624	
24	.1753	.1372	.1417	.3292	.8596	.4858	.5053
Max	.8482	.8697	.7282	.3292	1.0029	.8333	.8002
Min	.1524	.0137	.1267	.3292	.0219	.0486	.2454
Avg	.3301	.3988	.2237	.3292	.2898	.3199	.5706

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 204 / 11 KV Hivtad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1595	.1294			.0857	.1402
2	.1294	.1543	.128			.0857	.1254
3	.128	.1543	.1294			.0886	.128
4	.1075	.1543	.1097			.0905	.1494
5	.1267	.1543	.1478		.2149	.128	.2427
6	.2195	.1715	.2241			.2012	
7		.1715	.4108			.1949	.1848
8	.2254	.1372	.1326		.2587	.1417	
9	.1086	.1052	.1134		.1543	.12	.1715
10	.1029	.1063	.112		.1067	.124	.1475
11	.1029	.1254	.0949		.1206	.1227	.128
12	.1134	.124	.0934		.1029	.1402	.128
13	.1067	.1052	.1097		.1029	.1372	.1423
14	.012		.1128		.1029	.1174	.1406
15	.124	.208	.1303		.1029	.1341	.1387
16	.1372	.2629	.1219		.0124	.1326	.2715
17		.1715	.1638		.12	.128	
18	.0177		.1844		.1543	.1658	
19	.1715		.2279		.1886	.2279	
20			.2172		.1886	.2328	.1829
21			.1991		.0183	.2103	.1663
22	.1372		.1772		.1372	.1753	
23	.1715		.1402		.1063	.1387	
24	.1307	.1543	.2957	.1214	.1646	.0857	.1387
Max	.2254	.2629	.4108	.1214	.2587	.2328	.2715
Min	.012	.1052	.0934	.1214	.0124	.0857	.1254
Avg	.1252	.1541	.1627	.1214	.1310	.1420	.1604

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 205 / 11 KV Shetphale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.2058	.2926		.2401	.3174
2	.3109	.2058	.2957		.2641	.2987
3	.3142	.2218	.2987		.2641	.3206
4	.2896	.2241	.3326		.2641	.3395
5	.3292	.3395	.3109	.4668	.3395	.5228
6	.4805	.4338	.4152		.415	
7	.4715	.3772			.4115	.4481
8	.2926	.3429	.3326	.5611	.3086	
9	.2534	.3109	.2743	.3429	.3086	.298
10	.2658	.2896	.2353	.2229	.2561	.2865
11	.2572	.2686	.2328	.2534	.2743	.2401
12	.0287	.2481	.2481	.2686	.3224	.2601
13	.2835	.2454	.2686	.2572	.3045	
14	.2743	.2658	.2865	.2572	.3189	.2658
15	.2743	.2865	.3189	.2401	.3189	.2835
16	.2401	.2896	.3012	.2658	.3045	
17		.3224	.3189	.2743	.2572	
18	.3429		.3856	.3429	.3086	
19	.4207		.463	.4344	.4887	
20	.4607		.567	.5144	.5487	.5175
21	.3772		.5228	.4801	.4805	.4854
22	.034		.4435	.4108	.4481	
23	.2401		.3734	.3361	.3772	
24	.3045	.2058		.3582	.2641	
Max	.4805	.4338	.567	.5611	.5487	.5228
Min	.0287	.2058	.2328	.2229	.2401	.2401
Avg	.2984	.2824	.3417	.3493	.3370	.3489

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 206 / 11 KV Banpuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1543	.1612			.1417	.1417
2	.1612	.1543	.1629			.1372	.1402
3	.1646	.1543	.1646			.1372	.1372
4	.1478	.1543	.1848			.1463	.1612
5		.1886	.1829		.1595	.1715	.2402
6	.2402	.2058	.2149			.2427	
7	.2402	.2195	.1991			.2012	.2012
8	.1772	.1595	.1311		.1928	.1543	
9	.1865	.1646	.1372		.1254	.0156	.1387
10	.1715	.1595	.1214		.1372	.1433	.12
11	.1543	.1402	.1417		.1715	.1463	.1029
12	.1715	.1595	.1402		.1715	.1612	.1214
13	.1715	.1417	.1595		.1543	.181	.1402
14	.1886	.1629	.1753		.1543	.1612	.1543
15	.156	.1433	.1734		.1543	.1578	.1492
16	.1715	.1612	.1844		.144	.1372	.1509
17		.1791	.1658		.1524	.1296	
18	.2058		.1865		.1949	.1677	
19	.2195		.208		.2103	.2103	
20	.2561		.2303		.2481	.2126	.2534
21	.1886		.2149		.2172	.197	.2172
22	.1886		.1734		.1829	.1829	
23	.0181		.1612		.1612	.1433	
24	.1646	.1543	.1595	.1387	.0934	.1417	
Max	.2561	.2195	.2303	.1387	.2481	.2427	.2534
Min	.0181	.1402	.1214	.1387	.0934	.0156	.1029
Avg	.1776	.1643	.1723	.1387	.1681	.1592	.1606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 201 / 11 KV Palaskhel

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3049	.362	.362	3.7532	4.7192	4.9787	4.4325
2	.3048	.362	.3811	3.5246	4.5896	4.1387	4.1682
3	.2858	.381	.362	3.2388	4.4917	4.3012	3.8943
4	.2858	.381	.2858	3.1245	4.2044	4.2288	3.638
5	.3049	.4001	.362	3.4484	4.1343	4.3334	3.629
6	.3811	.4192	.4573	3.9247	4.843	4.7553	3.9324
7	.5334	.4763	.5906	5.8318	5.3186	5.365	3.677
8	.5716	.8505	.5334	.5525	.5715	.4953	.5335
9	4.4391	6.0753	.4001	.4573	.4153	.381	4.5573
10	5.2195	6.1484	.343	.3429	.3239	.2477	5.4464
11	5.7065	6.1024	.362	.2858	.362	.2286	5.0792
12	5.6547	6.0736	.343	.4001	.362	.2667	4.7986
13	5.3184	5.567	.3811	.4382	.4382	.2858	4.2874
14	5.1685	5.4722	.4382	.4382	.4001	.3048	4.7226
15	4.8926	5.0949	.4382	.4382	.4001	.2858	4.7866
16	5.0869	5.4193	.4191	.3429	.381	.4573	4.7158
17	.4382	.4192	.4192	.4191	.4953	.4001	.3811
18	.4191	.4382	.4763	.4382	.4763	.4382	.4192
19	.4763	.4953	.4953	.4573	.4763	.5335	.4573
20	.4763	.5715	.5715	.5144	.5144	.6287	.5144
21	.5334	.5525	.5906	.9526	.7621	.6097	.5334
22	.4382	.4763	4.3248	5.5175	5.4127	4.932	.4191
23	.362	.3811	4.6106	5.6289	5.5777	4.995	.362
24	.362	.343	4.3439	5.5152	5.2058	4.8964	1.1073
Max	5.7065	6.1484	4.6106	5.8318	5.5777	5.365	5.4464
Min	.2858	.343	.2858	.2858	.3239	.2286	.362
Avg	1.9985	2.2193	.9288	2.0827	2.2865	2.1870	2.9372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 202 / 11 KV Rajewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.8806	5.1132	4.8781	.4763	.5525	.4954	.6097
2	4.7234	4.8979	3.4484	.4191	.5525	.4954	.5906
3	4.5054	4.7331	4.4734	.4191	.5715	.4954	.5906
4	4.4161	4.8245	3.296	.4382	.5715	.4953	.5906
5	4.784	4.8297	4.3934	.4572	.5334	.5525	.5716
6	5.5582	5.5982	4.454	.4763	.5335	.5525	.6097
7	6.3634	6.5194	4.7493	.6669	.5716	.5525	.6478
8	.4572	.4382	1.5432	1.4098	.8193	1.8671	.6668
9	.4953	.5716	5.7567	6.2971	6.3059	7.3766	.7049
10	.362	.6287	5.9324	5.7476	6.7855	5.868	.8192
11	.4763	.5715	5.9614	5.5557	6.102	5.3346	.8383
12	.5335	.5144	6.0654	1.4289	5.9671	3.2388	.4573
13	.1143	.4954	5.6565	.0572	6.3001	4.7439	.5335
14	.6097	.4573	5.3509		5.9046	4.4963	.5906
15	.5525	.5144	5.7428		6.0759	4.9726	.6859
16	.6669	.5715	5.8154	3.8581	6.3748	5.3536	.743
17	.7049	.5906	.6096	.362	.4763	.6097	.7811
18	.705	.5525	.5144	.5716	.4763	.6669	.8573
19	.7621	.5906	.6669	.6097	.5335	.724	.8383
20	.6859	.6668	.743	.724	.6478	.7811	.8193
21	2.0004	1.6766	.7621	.724	.7431	.8002	1.6385
22	5.9892	5.0976	.5335	.6288	.5906	.6668	6.1273
23	5.6905	4.9959	.4954	.6288	.5334	.6287	5.9808
24	5.0579	5.3555	1.6156	.5906	.5144	.5525	4.401
Max	6.3634	6.5194	6.0654	6.2971	6.7855	7.3766	6.1273
Min	.1143	.4382	.4954	.0572	.4763	.4953	.4573
Avg	2.5456	2.5335	3.4774	1.4794	2.4599	2.1800	1.3206

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 203 / 11 KV Dhole Mala,  
Dighanchi Feeder KV- 11 /  
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0572		.9015	.9896	.7316
2	.0572	.0762	1.0923		.9313	.8954	.6878
3	.0381	.0762	.0572		.9709	.8859	.6447
4	.0381	.0572	.0572		.823	.8573	.6653
5	.0381	.0572	.0572		1.0059	.8842	.6584
6	.0572	.0762	.0762		.9774	1.0164	.695
7	.0953	.0762	.0953	.9134	1.0277	1.1041	.7947
8	.0572	.0857	.1143	.0953	.0953	.0953	.0762
9	1.0903	1.0166	.0953	.0953	.0953	.0762	.9795
10	.9694	.7973	.0953	.0762	.0762		.9328
11	.9816	.9945	.0762	.0572	.0572		.9231
12	1.0924	.9816	.0381	.0572	.0381		.8954
13	.9335	.7973	.0572	.0572	.0381		.9671
14	1.0498	.8775		.0572	.0381		1.0059
15	1.0099	.8573	.0381	.0572	.0381		1.0164
16	.9991	.8063	.0572	.0762	.0381		.9877
17	.0572	.0572	.0762	.0762	.0572	.0572	
18	.0572	.0953	.0953	.0762	.0572	.0572	
19	.0572	.0953	.0762	.0762	.0762	.0762	.0762
20	.0762	.0953	.1143	.0762	.0572	.0953	.0762
21	.0572	.0953	.0953	.0953	.0572	.0953	.0953
22	.0762	.0762		1.0924	1.0924	.9328	.0762
23	.0762	.0572		1.0277	.9991	.7207	.0572
24	.0572	.0762	.0572	.8573	1.0517	1.0791	.7133
Max	1.0924	1.0166	1.0923	1.0924	1.0924	1.1041	1.0164
Min	.0381	.0572	.0381	.0572	.0381	.0572	.0572
Avg	.3783	.3482	.1228	.2733	.4417	.5834	.6253



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.0895	.0716		.1075	.1075	.1075
2	.1075	.104	.0686		.1063	.1052	.1063
3	.1097	.1052	.0701		.0754	.0924	.1052
4	.1086	.1097	.052		.0732	.0867	.1075
5	.128	.1254	.0724		.0886	.128	.1267
6	.1463	.12	.1478		.0857	.1307	.128
7	.1448	.132	.112	.0924	.1052	.1029	.1254
8	.1187	.1227	.0876	.0747	.104	.1097	.1063
9	.0857	.0747	.0537	.0537	.0914	.0709	.1006
10	.0857	.0732	.0526	.0701	.0693		.1029
11	.0867	.0716	.0537	.0857	.0678		.0848
12	.1086	.052	.0537	.0732	.064		.08
13	.1075	.0709	.0347	.0895	.0648		.1147
14	.1132	.0732	.0537	.0934	.0663		.12
15	.0914	.0716	.0514	.0693	.0867		.104
16	.0895	.0693	.0526	.0724	.0838		.1187
17	.1097	.0724	.0537	.0857	.112	.0995	.1006
18	.1029	.0701	.0686	.104	.1063	.0926	.0972
19	.1433	.0732	.1097	.1227	.1227	.1006	.1372
20	.168	.1612	.1867	.1463	.1463	.1543	.1578
21	.1109	.1612	.1848	.1433	.1294	.1595	.1595
22	.0876	.1629		.112	.1075	.1646	.1595
23	.0857	.124		.0914	.12	.1267	.1433
24	.1267	.12	.0857	.0732	.0867	.132	.1267
Max	.168	.1629	.1867	.1463	.1463	.1646	.1595
Min	.0857	.052	.0347	.0537	.064	.0709	.08
Avg	.1122	.1004	.0808	.0918	.0946	.1155	.1175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 201 / 11 KV Kauthuly

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1448		2.572	1.6827	1.5415
2	.1448	.1448		2.4531	1.6301	1.5223
3	.1448	.1448		2.3878	1.5939	1.4661
4	.1448	.1448		2.4863	1.6297	1.5023
5	.2172	.1448		2.4813	1.8427	1.5415
6	.2172	.2172		2.6791	2.3487	1.6644
7	.2172	.2172		2.8121	2.0576	1.8652
8	.2865	.2149		.1696	.1715	.2401
9	3.0178		.1254	.2058	.1526	2.0119
10	2.5484		.1254	.1677	.1187	1.7528
11	2.0119		.1372	.1658	.1372	1.7528
12	2.0119		.1791	.1492	.1372	1.6461
13	1.6766		.1829	.1311	.1372	1.6461
14	1.6766		.1612	.1311	.1029	1.5089
15	1.4754		.1463		.1017	1.5089
16	1.6095		.1433	.1326		1.5775
17	.1433		.1829	.1677		
18	.1433		.1829	.1886		.1433
19	.2149		.2195	.2454	.2743	.2149
20	.2149		.2058	.2835	.2947	.2149
21	.2149		.197	.2865	.298	.2149
22	.2172			2.774	2.4691	.1448
23	.2172			2.1735	1.9071	.1448
24	.1448	.1448	.2172	2.4006	1.7177	1.5775
Max	3.0178	.2172	.2195	2.8121	2.4691	2.0119
Min	.1433	.1448	.1254	.1311	.1017	.1433
Avg	.7940	.1687	.1719	1.2019	.9907	1.1915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 202 / 11 KV Nimbawade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.0288		.1646	.1629	.1448
2	1.0631	1.0288		.1791	.1463	.128
3	1.0631	1.0288		.181	.1463	.128
4	1.0631	1.0288		.1612	.1294	.1448
5	1.1317	1.0974		.1772	.1629	.1595
6	1.4403	1.4403		.1753	.1949	.1907
7	1.6461	1.5775		.1463	.1734	.1715
8	.1433	.1433		.1715	.1715	.1543
9	.1029		1.6461	1.3763	1.8991	.1017
10	.1029		1.4582	2.0553	1.8442	.1187
11	.1029		1.8233	1.9662	1.5912	.1357
12	.1029		1.6385	1.917	1.5912	.1357
13	.1029		1.5912	1.873	1.5089	.1052
14	.1029		1.6057	1.6575	1.4083	.1052
15	.1029			1.6712	1.326	.1052
16	.1029		1.6655	1.5746		.1052
17	.1075		.1478	.1357		.1075
18	.1075		.1829	.1543		.1075
19	.1791		.1791	.2103	.1886	.1433
20	.1791		.1646	.2303	.1907	.1433
21	.1433		.1791	.1949	.2103	.1433
22	1.448		.1433	.1791	.1949	1.6118
23	1.3394		.1463	.1791	.1791	1.6118
24	1.166	1.166		.1791	.1629	.1448
Max	1.6461	1.5775	1.8233	2.0553	1.8991	1.6118
Min	.1029	.1433	.1433	.1357	.1294	.1017
Avg	.5878	1.0600	.8980	.7046	.6468	.2561

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 203 / 11 KV Kauthuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0905		.1463	.1267	.1267
2	.0905	.0905		.1612	.1097	.128
3	.0905	.0905		.1907	.1097	.1109
4	.0905	.0905		.1543	.1294	.1294
5	.0905	.0905		.1715	.1448	.1267
6	.1267	.1448		.208	.1772	.1595
7	.181	.1629		.1886	.1734	.1886
8	.1791	.1254		.2254	.1372	.1372
9	.1715		.0709	.1715	.0848	.1357
10	.1029		.1029	.1187	.1006	.1696
11	.1029		.1772	.1174	.1029	.1696
12	.1029		.1612	.1006	.0857	.2035
13	.0857		.1097	.0995	.0686	.1052
14	.0857		.1433	.0829	.0686	.1052
15	.0857		.124	.0829	.0848	.1052
16	.0857		.1543	.0838		.1753
17	.0895		.1791	.1357		
18	.1791		.2058	.1372		.1433
19	.2149		.2865	.1928	.1886	.1791
20	.2149		.2743	.2126	.2254	.2149
21	.1791		.2534	.2149	.1928	.2149
22	.181		.2378	.1612	.1595	.1448
23	.1448		.1829	.1267	.1433	.1267
24	.1086	.0905	.2172	.2149	.1267	.1267
Max	.2149	.1629	.2865	.2254	.2254	.2149
Min	.0857	.0905	.0709	.0829	.0686	.1052
Avg	.1281	.1085	.1800	.1541	.1305	.1490

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 204 / Nimbawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.181		.2401	.2926	.2534	.2534
2	.2172	.181		.2865	.3045	.2378	.2561
3	.2172	.181		.2743	.0114	.2378	.2378
4	.2172	.181		.2507	.2743	.2218	.2772
5	.2172	.181		.2507	.2713	.2561	.2896
6	.2715	.181		.2572	.3121	.3012	.3366
7	.2715	.2172			.275	.3294	.3641
8	.2149	.2149			.2561	.2915	.2915
9	.1715		.1734		.2218	.2035	.2204
10	.1715		.1612		.1753	.1677	.1753
11	.1715		.1791		.12	.1715	.1753
12	.1715		.1595		.1174		.1753
13	.1715		.3155		.1326	.1372	.1753
14	.1715		.1433		.1326	.1372	.1753
15	.1715				.1475	.1187	.1753
16	.1715		.1791		.1174		.1753
17	.1791		.2835		.1543		.1791
18	.1791		.3086		.2058		.1791
19	.2149		.3658		.2103	.2572	.1791
20	.2507		.3258		.2481	.2947	.2865
21	.2507		.2926		.3012	.333	.2865
22	.2534		.3086		.3721	.3721	.362
23	.2172		.2865		.3403	.3045	.362
24	.2896	.2172	.2172	.2743	.3224	.2534	.2353
Max	.2896	.2172	.3658	.2865	.3721	.3721	.3641
Min	.1715	.181	.1433	.2401	.0114	.1187	.1753
Avg	.2104	.1928	.2466	.2620	.2215	.2440	.2426

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 201 / 11 KV Vithalapur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.0732
Max	.0732
Min	.0732
Avg	.0732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 202 / 11 KV Dighanchi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.2378
Max	.2378
Min	.2378
Avg	.2378

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 203 / 11 KV Rajewadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17
HR	Load (MW)
24	.2012
Max	.2012
Min	.2012
Avg	.2012



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0554
Max	.0554
Min	.0554
Avg	.0554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 205 / 11 KV Dighanchi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.1109
Max	.1109
Min	.1109
Avg	.1109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 201 / 11 KV Gorewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7461	.703	.823	.1075	.0886	.0983	.1052
2	.7122	.6588	.823	.1075	.0886	.1006	.1052
3	.7122	.8573	.8215	.1075	.0886	.1017	.1029
4	.7122	1.0229	.6706	.1075	.0886	.1174	.1029
5	.78	1.2548	.8478	.1254	.1063	.1326	.1372
6	1.2717	1.5089	1.1065	.1595	.1417	.1509	.1715
7	1.7974	1.5769	1.1022	.1949	.1595	.1823	.1677
8	.1578	.1341	.1509	.1578	.1595	.1311	.1526
9	.124	.1326	1.1022	1.5769	1.933	2.0287	.1187
10	.0857		1.2239	1.6108	1.2308	1.6956	.1174
11	.1017		1.2239	1.4582	1.3226	1.4754	.1006
12	.1341		1.0562		1.3077	1.1869	.1006
13	.1187	.1187	1.0898		1.1105	1.1869	.0838
14	.1174	.1187	1.0774		1.153	1.1736	.1174
15	.0995	.1187	1.326		1.2239	1.4243	.1006
16	.1174	.1187	1.3592			1.5089	.1187
17	.0995		.12		.1174	.1187	.0857
18	.1311	.1187	.1402		.1357	.1357	.1372
19	.1457	.2012	.1772	.1928	.1658	.1696	.1578
20	.1638	.2058	.197		.1844	.1865	.2126
21	.1619	.2229	.1791		.1696	.2035	.1928
22	1.1022	1.1022	.1791		.1341	.1372	1.5927
23	.7712	.9835	.1075		.1017	.1029	1.2407
24	.7461	.7291	.8478	.1075	.1063	.0995	.1029
Max	1.7974	1.5769	1.3592	1.6108	1.933	2.0287	1.5927
Min	.0857	.1187	.1075	.1075	.0886	.0983	.0838
Avg	.4629	.5944	.7397	.4626	.4921	.5770	.2344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 202 / 11 KV Bhivghat AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0514	.0671	.6613	.5087	.6952	.5935
2	.0709	.0343	.0678	.6443	.4748	.6706	.5868
3	.0709	.0686	.0671	.6443	.4748	.6516	.5868
4	.0709	.0838	.0678	.6613	.4748	.7975	.6274
5	.0709	.1006	.0838	.6952	.5087	.8573	.6274
6	.0886	.1017	.1017	.8478	.7969	.8916	.6443
7	.1063	.0671	.1017	1.0852	1.0174	1.0414	.8139
8	.0701	.0663	.1006	.1017	.0886	.0857	.0848
9	1.1191	.9724	.0678	.0838	.0532	.052	.8648
10	.9724		.0671	.0857	.0678	.0509	.8551
11	.8987		.0671	.0857	.0838	.0678	.788
12	.8383			.1227	.0848	.0678	.8215
13	.8817	.8987	.0838	.0876	.0829	.0678	.8215
14	.8648	.9221	.0663		.0671	.0838	.788
15	.9556	1.0004	.0829		.0829	.1017	.8551
16	.9945	.9892	.0838			.1017	.9389
17	.1006		.1029		.0829	.1187	.0848
18	.0995	.1357	.1052		.1017	.1187	.0857
19	.0671	.1006	.124	.1227	.096	.1187	.1052
20	.0829	.1017	.1063		.1134	.1006	.1227
21		.1006	.1063		.112	.1017	.1075
22	.0678	.0848	.8987		.5801	.6783	.0886
23	.0503	.0678	.763		.7545	.6783	.0886
24	.0709	.0509	.0671	.6783	.5426	.7291	.5868
Max	1.1191	1.0004	.8987	1.0852	1.0174	1.0414	.9389
Min	.0503	.0343	.0663	.0838	.0532	.0509	.0848
Avg	.3776	.2999	.1500	.4405	.3152	.3720	.5237

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 203 / 11 KV Khanapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0671	.0838	.9665	.9496	1.0059	.8478
2	.0709	.0678	.0848	.9496	.9326	1.0004	.8383
3	.0709	.0848	.0838	.9496	.9326	1.032	.8478
4	.0709	.1029	.0848	.9835	.9326	1.0682	.8383
5	.0709	.1174	.0838	1.0174	1.0174	1.1361	.8718
6	.0709	.1017	.1017	1.1869	1.2039	1.1869	.9221
7	.0886	.1174	.1017	1.56	1.6956	1.4251	1.0852
8	.0876	.0829	.1174	.1017	.1227	.1311	.0838
9	1.17	1.2616	.1187	.0838	.0876	.116	.8648
10	1.1488		.1006	.1029	.0848	.1017	1.1736
11	.8718		.1174	.12	.1006	.1006	1.2407
12	1.1022	1.2574	.1006	.1402	.0829	.1006	1.1401
13	1.291	1.3565	.1006	.1052	.0838	.1017	1.0395
14	1.387	1.3413	.1006		.0857	.0838	1.0227
15	1.4575	1.3748	.0995		.1017	.0671	1.0562
16	1.3565	1.5091	.1006			.0838	1.1233
17	.0848		.1017		.1326	.1174	.0848
18	.1187	.1174	.1372		.1543	.1187	.0857
19	.0857	.1187	.1227		.1326	.1357	.1402
20		.1174	.1227		.1311	.1006	.1402
21	.0838	.1187	.1052		.1326	.1006	.1433
22	.0848	.0838	1.2717		1.1904	1.1869	.1075
23	.0829	.0848	1.1191		1.0277	1.0852	.0895
24	.0709	.081	.0848	.9835	.9665	.9945	.9326
Max	1.4575	1.5091	1.2717	1.56	1.6956	1.4251	1.2407
Min	.0709	.0671	.0838	.0838	.0829	.0671	.0838
Avg	.4782	.4555	.1936	.6608	.5340	.5242	.6967

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 204 / 11 KV Khanapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.2401	.3052	.3045	.2835	.3294	.3018
2	.2629	.2401	.2515	.2865	.2835	.3155	.3052
3	.2629	.3429	.2543	.2865	.2835	.3467	.3018
4	.2629	.3814	.2515	.2865	.2126	.3772	.2883
5	.2804	.4287	.3052	.3045	.2126	.407	.3018
6	.3189	.4115	.4287	.3366	.3012	.3944	.3688
7	.3721	.4508	.4191	.3856	.3721	.4334	.39
8	.2804	.3601	.39	.333	.3721	.3681	.373
9	.3012	.3429	.3052	.2743	.3506	.2915	.2543
10	.1734		.3222	.2915	.3086	.2713	.2743
11	.2743		.2713	.2915	.3121	.2683	.1865
12	.2743	.39	.3052	.2743	.3086	.2713	.3052
13	.2883	.3391	.2683	.298	.3391	.2883	.2543
14	.2915	.3391	.2515		.3391	.285	.2374
15	.3258	.3391	.3018		.3018	.2883	.218
16	.2743	.3561	.3185			.2883	.3353
17	.3258		.3391		.3601	.2713	.373
18	.3391	.4748	.3601		.407	.3688	.4458
19	.3601	.5256	.4508	.4382	.4801	.4578	.4508
20		.5426	.5493	.5083	.4854	.6203	.5434
21	.463	.4694	.5194		.4801	.39	.5316
22	.4161	.4239	.4656		.4458	.3856	.4607
23	.3429	.373	.3582	.3544	.3429	.3052	.3898
24	.2804	.2915	.3391	.3045	.3012	.3086	.3052
Max	.463	.5426	.5493	.5083	.4854	.6203	.5434
Min	.1734	.2401	.2515	.2743	.2126	.2683	.1865
Avg	.3066	.3839	.3471	.3270	.3428	.3472	.3415

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 205 / 11 KV Bhivghat Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772		.1341	.1433	.1417	.1214	.1174
2	.1772		.1372	.1433	.1417	.1052	.1174
3	.1772		.1372	.1433	.1417	.1052	.12
4	.1772		.1509	.1433	.124	.12	.1372
5	.1772		.1677	.1433	.124	.1387	.1372
6	.1772		.1865	.1595	.1772	.1387	.1715
7	.2126		.1696	.1578	.1772	.1402	.1509
8	.1928		.1865	.1753	.1772	.1387	.1526
9	.1772		.1715	.1715	.1417	.1372	.1509
10			.2035	.1928	.2058	.1509	.1865
11	.1886		.1865	.1753	.1715	.1844	.1526
12	.1886		.1865	.2103	.1715	.1844	.1696
13	.1543	.2683	.1509	.2103	.1865	.2035	.1865
14	.1543	.2204	.1341		.1543	.1677	.1696
15	.1526	.2035	.1677		.156	.1677	.1526
16	.1509	.1844	.1696			.1696	.1509
17	.1734		.1865		.1734	.1677	
18	.1943	.2713	.1886		.1658	.1677	
19	.2204	.3086	.2103	.2103	.2427	.1677	
20		.3086	.2303		.2229	.2058	.2629
21		.2229	.2303		.2058	.2012	.2481
22		.2035	.1949		.1907	.1865	.2126
23		.1886	.1595		.1372	.1543	.1949
24	.1772		.1696	.1417	.1417	.12	.1357
Max	.2204	.3086	.2303	.2103	.2427	.2058	.2629
Min	.1509	.1844	.1341	.1417	.124	.1052	.1174
Avg	.1790	.2380	.1754	.1681	.1684	.1560	.1656

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 206 / 11 KV Balawadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1191	1.166	1.0288	.1433	.124	.1357	.1227
2	1.1022	1.166	1.0288	.1433	.124	.1174	.1227
3	1.1022	1.3717	1.0288	.1254	.124	.1326	.1254
4	1.1022	1.5257	1.0395	.1433	.124	.1509	.1402
5	1.1869	1.6461	1.1022	.1612	.1595	.1638	.1543
6	1.6278	1.9161	1.2717	.2126	.1949	.1865	.1886
7	2.2382	2.1293	1.4413	.2303	.1949	.2012	.1715
8	.1227	.1696	.1844	.1753	.1417	.1696	.1753
9	.1063	.1174	1.8107	1.9669	2.1365	2.0622	.0857
10	.1075		1.8442	1.8482	2.0119	1.9281	.0678
11	.1174		1.6263	1.7295	1.8233	1.9161	.1187
12	.1174		1.5424		1.7101	1.8442	.1174
13	.1187		1.3916		1.5581	1.56	
14	.1174		1.4419		1.4754	1.5927	.1509
15	.1326		1.576		1.6617	1.8778	.1341
16	.1341		1.7939			1.95	.1357
17	.1326		.1715		.1492	.1509	.1372
18	.1475	.2713	.1578		.1658	.1526	.1543
19	.1658	.2401	.1949	.2454	.2035	.1844	.1753
20	.1677	.2229	.2328		.218	.1865	.2126
21	.1823	.2229	.2328		.1989	.2012	.2103
22	1.4091	1.4575	.1791		.1844	.1696	1.9616
23	1.2239	1.2209	.1612		.1357	.1509	1.5424
24	1.1191	1.1904	1.0562	.1433	.1417	.1372	.1372
Max	2.2382	2.1293	1.8442	1.9669	2.1365	2.0622	1.9616
Min	.1063	.1174	.1578	.1254	.124	.1174	.0678
Avg	.6292	1.0021	.9808	.5591	.6505	.7218	.2844



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 207 / 11 KV GOREWADI gaovthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0701	.0503	.0532	.0532	.0514	.0335
2	.0709	.0709	.0509	.0532	.0532	.0343	.0339
3	.0709	.0701	.0503	.0532	.0532	.052	.0339
4	.0709	.0693	.0509	.0532	.0532	.0701	.0335
5	.0886	.0857	.0671	.0532	.0532	.0857	.0509
6	.0886	.0686	.1017	.0709	.0709	.0857	.0838
7	.1063	.0867	.1017	.0876	.0886	.104	.1017
8	.1052	.1372	.0838	.0876	.0886	.0514	.0848
9	.0876	.0857	.0848	.0686	.1052	.052	.0671
10	.052		.0848	.0686	.0867	.0838	.0503
11	.0343		.0678	.0686	.0686	.0848	.0678
12	.0693	.0848	.0678	.0686	.0686	.0848	.0509
13	.0686	.0503	.0671	.0701	.052	.0848	.0509
14	.0514	.0509	.0671		.0347	.0678	.0339
15	.052	.0509	.0503		.0686	.0503	.0335
16	.0686	.0503	.0678			.0509	.0509
17	.0686		.0857		.052	.0678	.0857
18	.0857	.0339	.0701		.0686	.1017	.0693
19	.0867	.1187	.1063	.1052	.104	.1006	.1052
20	.0686	.1006	.0886		.12	.1006	.0886
21	.0857	.0848	.0886		.0867	.1017	.0886
22	.0693	.0678	.0709		.0686	.0671	.0709
23	.0686	.0503	.0532		.0514	.0509	.0532
24	.0886	.0693	.0509	.0537	.0532	.052	.0509
Max	.1063	.1372	.1063	.1052	.12	.104	.1052
Min	.0343	.0339	.0503	.0532	.0347	.0343	.0335
Avg	.0741	.0741	.0720	.0677	.0697	.0723	.0614

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 201 / PALASHI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6718	.4801	.6562	.1696	.1905	.1753	.8488
2	.6483	.4374	.6478	.1677	.1905	.1753	.7827
3	.6483	.4218	.6401	.1677	.1905	.1753	.7827
4	.6483	.4218	.6405	.1715	.1905	.1753	.7827
5	.6554	.502	.6636	.2103	.2286	.2126	.7876
6	1.0623	.9556	.8223	.3052	.3475	.3224	1.3565
7	1.3108	1.5424	1.078	.285	.298	.3292	1.382
8	.2012	.2058	.2402	.2454	.2286	.2126	.2477
9	.2096	.1991	1.0059	1.1904	1.3717	.1753	.1562
10	.1715	.1791	.9877	1.1961	1.3889	.1417	.1638
11	.1646	.1402	.9602	1.0082	.8128	.1886	.1696
12	.1595	.1595	1.0031		1.0623	.1753	.1677
13	.197	.1791	.9172			.197	.1619
14	.2149	.1578	1.0155			.1928	.1638
15	.1772	.1417	1.0822		1.4251	.1715	.16
16	.1772	.1612	1.3123		1.4575	.1905	.1492
17	.2328	.1646	.1372		.2103		
18	.2149	.2772	.1715		.2658	.2774	
19	.2534	.2801	.2804		.3258	.2818	.394
20	.2561	.3174	.3224		.3841	.3292	.4031
21	.2561	.3174	.3077		.3258	.3239	.3681
22	.6173	.9259	.2454		.2658	1.5123	1.5769
23	.5365	.7164	.1715		.1928	1.1138	1.2071
24	.7186	.4801	.6718	.1715	.1905	.1753	.945
Max	1.3108	1.5424	1.3123	1.1961	1.4575	1.5123	1.5769
Min	.1595	.1402	.1372	.1677	.1905	.1417	.1492
Avg	.4335	.4068	.6659	.4407	.5247	.3141	.5981

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 202 / 11 KV HIVARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2103	.2149	.6036	.4207	.5218	.2477
2	.2667	.1928	.197	.5801	.4329	.4999	.2477
3	.2667	.1928	.2172	.5868	.4329	.4687	.2477
4	.2667	.1928	.2172	.6133	.4329	.4374	.2427
5	.3048	.1949	.2328	.6687	.4527	.4858	.2427
6	.362	.2865	.362	1.2289	.9659	.8048	.3761
7	.381	.362	.3582	1.3603	1.0517	1.2269	.4207
8	.2926	.3681	.2772	.2686	.2454	.2507	.3077
9	1.0269	1.2689	.2534	.2804	.2204	.7274	1.0269
10	.8573	1.0227	.2481	.2629	.2204	.6882	.8383
11	.7282	.8745	.2149	.2601	.2103	.6874	.743
12	.8124	.828	.2486	.2835	.2303	.7074	.6401
13	.8065	.8179	.2515	.2835		.6836	.7611
14	.9488	.7225	.2267			.5702	.7701
15	1.1012	1.0669	.208		.2103	.7287	.9878
16	.9503	1.1883	.2753		.2279	.8535	1.2239
17	.3086	.2957	.2229		.2103		
18	.2804	.3547	.2804		.2658	.3052	
19	.3012	.3734	.4298		.3258	.3982	.4835
20	.3045	.4108	.4252		.4572	.4763	.4733
21	.3045	.3734	.4207		.4163	.4001	.4525
22	.2481	.3077	.9774		.9221	.3239	.3506
23	.2279	.2534	.6687		.6401	.2667	.2743
24	.2667	.2103	.2172	.6274	.4801	.5376	.2667
Max	1.1012	1.2689	.9774	1.3603	1.0517	1.2269	1.2239
Min	.2279	.1928	.197	.2601	.2103	.2507	.2427
Avg	.4950	.5154	.3186	.5649	.4306	.5674	.5284

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 203 / 11 KV HIVARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0351	.0354	.056	.0362	.0532	.0543
2	.0549	.0351	.0351	.0358	.0362	.0351	.0543
3	.0549	.0351	.0347	.0351	.0362	.0351	.0543
4	.0549	.0351	.0351	.0351	.0354	.0351	.0549
5	.0549	.0351	.0343	.0537	.0354	.0532	.0537
6	.0537	.0532	.052	.0343	.0543	.0532	.0724
7	.0537	.0724	.0686	.0509	.0537	.0732	.0497
8	.0532	.0701	.0895	.0716	.0526	.0549	.0509
9	.0343	.0543	.0351	.0886	.0332	.0532	.0876
10	.0829	.0537	.0514	.1029	.0514	.0716	.0686
11	.0829	.0886	.0693	.0701	.052	.0876	.0532
12	.0686	.0526	.0943	.104	.0876	.0347	.0701
13	.0526	.0347	.0514	.0497		.0532	.0514
14	.0886	.0514	.0503			.0532	.0351
15	.0701	.0339	.0663		.0701	.1029	.0343
16	.0354	.0343	.0857		.0876	.0701	.0876
17	.0537	.0351	.0351		.1063		
18	.0537	.0354	.0537		.1063	.0671	
19	.0543	.0716	.0724		.0732	.052	.1143
20	.0543	.0701	.0934		.0914	.0709	.0895
21	.0543	.0709	.0762		.0914	.0709	.0943
22	.0358	.0526	.0747		.0716	.0549	.0716
23	.0354	.052	.0549		.0532	.0549	.0526
24	.0543	.0351	.0351		.0526	.0532	.0537
Max	.0886	.0886	.0943	.104	.1063	.1029	.1143
Min	.0343	.0339	.0343	.0343	.0332	.0347	.0343
Avg	.0561	.0499	.0577	.0606	.0622	.0584	.0640

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 201 / 11 KV BURLI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2981	3.4933	3.4476	.0943	.1132	.132	.1132
2	4.1301	3.4293	3.3104	.0943	.1132	.1132	.1132
3	4.0409	3.4019	3.1493	.0943	.1132	.1132	.1132
4	4.0409	3.3836	3.1493	.0943	.1132	.1132	.1132
5	4.0409	3.5265	3.1207	.1132	.1132	.132	.0943
6	4.2067	3.7357	3.283	.132	.1132	.132	.1132
7	4.3896	4.161	3.4202	.1132	.1132	.132	.1132
8	.9631	1.0545	.6887	.1132	.0943	.1132	.1132
9	.0943	.0943	5.0298	5.703	6.6644	5.9808	.0943
10	.0943	.0943	6.2986	6.3557	6.629	6.2551	.0943
11	.0943	.0943	6.8781	3.4294	6.8221	5.9534	.0943
12	.0943	.0943	6.6758	3.3836	6.9227	6.2551	.0943
13	.0943	.0943	6.3466		6.9227	6.0608	.0943
14	.0943	.0943	6.0768		6.7307	6.3466	.0943
15	.0943	.0943	6.1637		6.5386	6.0997	.0943
16	.0943	.0943	5.7042		6.0837	5.4618	.0943
17	.0943	.0943	.9631	1.0974	.8259	.9442	.0943
18	.1132	.1132	.1132		.1132	.0943	.1132
19	.1132	.1132	.132		.1132	.1132	.1132
20	.0943	.132	.132		.132	.1132	.132
21	.0943	.1132	.1132		.132	.132	.132
22	3.9232	3.9689	.1132		.132	.1132	5.2127
23	3.9598	3.9598	.0943		.1132	.0943	5.295
24	4.0466	2.1519	1.5912	.0943	.1132	.132	2.9024
Max	4.3896	4.161	6.8781	6.3557	6.9227	6.3466	5.295
Min	.0943	.0943	.0943	.0943	.0943	.0943	.0943
Avg	1.8043	1.5661	3.1665	1.4937	2.3281	2.1304	.6515

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 202 / 11 KV RAMANANDNAGAR 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2787	2.1536	2.0172	2.0477	2.0378	2.0477	2.0477
2	2.0279	1.0364	1.8809	1.8809	1.9418	1.9867	1.9867
3	1.9974	1.9867	1.8504	1.8504	1.9113	1.8809	1.9867
4	1.9974	1.9867	1.8199	1.8504	1.8717	1.8504	1.8504
5	2.1018	1.9867	1.8953	1.9258	1.9464	1.9464	1.9258
6	2.5194	2.2787	2.1872	2.1986	2.3655	2.3959	2.2291
7	2.5591	2.2976	2.2748	2.2519	1.2498	2.3586	2.172
8	2.2329	2.2862	1.9357	2.1506	2.2024	2.2672	2.13
9	2.2444	2.3655	1.8138	2.0683	2.1521	2.3472	2.1948
10	2.396	2.4692	1.8626	1.9379	2.0584	2.3472	2.3533
11	2.4692	2.6025	1.8961	1.0059	2.2741	2.2527	2.4143
12	2.3891	2.4387	1.8579	1.0059	2.3472	2.2024	2.3045
13	2.2741	2.2253	1.7497	.9145	2.0911	1.0364	2.1948
14	2.5416	2.5545	2.4676	.9755	2.4981	2.3777	2.4204
15	2.5721	2.5545	2.4814	1.0059	2.614	2.3472	2.524
16	2.5111	2.4387	2.5728	.823	2.5896	2.2923	2.4204
17	2.4326	2.3015	2.4082	.823	2.4326	2.2832	2.2862
18	2.3777	2.2984	2.1796	.7926	2.0591	2.1872	2.2558
19	2.7588	2.3892	2.6445	1.0669	2.5225	2.6673	2.4676
20	3.1825	1.7985	2.8982	1.4632	2.9591	3.1985	3.0483
21	2.8852	2.6414	2.7328	1.4327	2.838	2.9591	2.9446
22	2.6109	2.6856	2.6109	1.3413	2.6856	2.7465	2.7702
23	2.5484	2.5484	2.4425	1.3108	2.4425	2.5788	2.6398
24	2.3837	2.204	2.1841	2.2146	2.204	2.245	2.2755
Max	3.1825	2.6856	2.8982	2.2519	2.9591	3.1985	3.0483
Min	1.9974	1.0364	1.7497	.7926	1.2498	1.0364	1.8504
Avg	2.4288	2.2720	2.1943	1.5141	2.2623	2.2834	2.3268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 203 / 11 KV SAWANTPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6199	3.5437	1.3337	.1014	.1204	.108	.1094
2	3.4436	3.4417	1.2956	.1	.1189	.1067	.1067
3	3.3493	3.2912	1.1793	.1	.0914	.0903	.1067
4	3.3112	3.3093	1.1279	.1014	.0869	.0903	.1067
5	3.3493	3.3722	1.1346	.1189	.1235	.1094	.0914
6	3.5246	3.5056	1.1613	.1219	.1562	.1107	.1265
7	3.8123	3.7961	1.2422	.0812	.1189	.1067	.1189
8	.7728	.9088	.2972	.1174	.0903	.0947	.1
9	.0903	.0926	2.1214	4.944	5.5165	5.4032	.0705
10	.0869	.108	2.311	5.4736	6.0566	5.6775	.088
11	.08	.104	2.5768	2.934	5.8661	5.3965	.0892
12	.0657		2.4749	2.934	5.8661	5.4736	.0834
13	.088	.1	2.229		5.5155	4.4563	.0857
14	.0686	.088	3.4132		5.1679	4.582	.0857
15	.0869	.0892	4.4676		5.1574	4.803	.0714
16	.0987	.0789	4.6697		4.9935	4.7592	.08
17	.0934	.0823	.7972	.3429	.6676	.8414	.0857
18	.0907	.0789	.0789		.1067	.0777	.0907
19	.1	.104	.1027		.1027	.1143	.0974
20	.1189		.689		.1486	.1174	.1143
21	.104		.1067		.1372	.132	.1189
22	3.5437	1.4775	.1204		.1235	.1235	4.039
23	3.7599	1.5708	.1067		.1107	.1107	4.2962
24	3.6999	2.4768	.5716	.104	.1219	.108	2.4323
Max	3.8123	3.7961	4.6697	5.4736	6.0566	5.6775	4.2962
Min	.0657	.0789	.0789	.0812	.0869	.0777	.0705
Avg	1.5566	1.5057	1.4837	1.2553	1.9402	1.7914	.5331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 204 / 11 KV RAMANANDNAGAR 2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-APR-17	05-APR-17
HR	Load (MW)	Load (MW)
2	.9808	
7		1.1584
Max	.9808	1.1584
Min	.9808	1.1584
Avg	.9808	1.1584



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 201 / 11 KV Dudhondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6476	1.3672	.1577	.1471	.1494	.1547	1.3771
2	1.5725	1.3222	.1732	.1479	.1486	.1547	1.3226
3	1.5413	1.3032	.1608	.1524	.1479	.1555	1.2921
4	1.5462	1.3443	.1578	.1726	.1547	.1721	1.3557
5	1.6354	1.4008	.1981	.1779	.1856	.1911	1.424
6	1.8023	1.5767	.2271	.2034	.1909	.2117	1.5143
7	1.9864	1.6064	.2233	.2202	.2016	.2028	1.7014
8	.2031	.1821	.3459	.2922	.3547	.3664	.1738
9	.2031	.1768	2.5675	2.6345	3.0476	2.564	.1929
10	.1848	.1684	2.761	2.8403	3.0338	2.8144	.1814
11	.1639	.184	2.8128	2.8723	3.0682	2.9119	.1797
12	.1692	.1532	2.7389	1.5638	2.9856	2.8209	.1774
13	.1707	.1486	2.5903		2.9366	2.6296	.1789
14	.1824	.0686	1.3763		2.7054	2.4128	.1675
15	.1709	.0876	2.4051		2.5407	2.2615	.1502
16	.1616	.1554	2.3716	.9579	2.4219	2.05	.0846
17	.2004	.1993	.141	.0998	.1662	.1471	
18	.1977	.176	.1631	.109	.1728	.1357	.185
19	.2187	.2046	.1878	.1181	.1843	.1888	.2107
20	.2229	.2359	.2118	.1273	.2102	.2115	.2237
21	.2796	.2191	.1966	.1135	.1949	.246	.2468
22	1.6309	.1953	.1772	.1052	.1835	1.4484	1.9029
23	1.6019	.1669	.1741	.1006	.1654	1.5017	1.9577
24	1.6651	.8005	.1479	.0876	.157	1.4281	1.6666
Max	1.9864	1.6064	2.8128	2.8723	3.0682	2.9119	1.9577
Min	.1616	.0686	.141	.0876	.1479	.1357	.0846
Avg	.8066	.5601	.9445	.6306	1.0711	1.1409	.7768

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 202 / 11 KV Nagrale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.0671	1.8115	1.8678	1.8435	1.691	.0655
2	.0655	.0671	1.752	1.7955	1.7372	1.7038	.0492
3	.0655	.0671	1.6957	1.7566	1.6741	1.691	.0655
4	.0655	.0671	1.6751	1.6986	1.6785	1.7391	.0655
5	.0819	.0671	1.6362	1.7886	1.6918	1.7595	.0819
6	.0678	.0671	1.7482	2.0149	1.9555	1.8439	.0819
7	.0777	.0717	1.832	2.223	2.1308	2.0782	.0846
8	.1356	.1121	.0778	.1067	.0937	.1151	.1158
9	3.1718	3.3971	.0671	.0671	.0663	.0655	2.966
10	3.2982	3.5139	.0671	.0503	.0663	.0655	3.1817
11	3.3235	3.4072	.0671	.0816	.0497	.0023	3.44
12	3.3017	3.4332	.0671	.0671	.0663	.0561	3.3981
13	3.3395	3.3387	.0572	.0069	.0739	.0777	3.4076
14	3.2896	3.3471	.0671		.0663	.0655	3.4187
15	3.2362	3.2306	.0503		.0663	.0655	3.3588
16	2.7438	3.1085	.1006	.0015	.0497	.0655	2.6151
17	.0747	.0671	.0846		.0663	.0655	.117
18	.1326	.0671	.1227		.0663	.0655	.0655
19	.1699	.0671	.1135	.0008	.0663	.0819	.0655
20	.208	.0838	.0838		.0663	.0819	.0819
21	.186	.1075	.0671	.0008	.0663	.0819	.0819
22	.0838	1.9814	2.0165	1.0387	1.7776	.0655	.0655
23	.0671	1.9571	1.9632	1.0905	1.8305	.0655	.0663
24	.0655	1.0654	1.9212	1.0372	1.8244	.0655	.0655
Max	3.3395	3.5139	2.0165	2.223	2.1308	2.0782	3.44
Min	.0655	.0671	.0503	.0008	.0497	.0023	.0492
Avg	1.1382	1.3650	.7977	.8786	.7947	.5691	1.1252

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 203 / 11 KV Takari Exps

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9584	1.1927	1.1048	1.0745	1.1401	1.1751	1.1218
2	.852	1.1687	1.1108	.9731	1.1462	1.1765	1.0822
3	.791	1.1096	1.1279	.9507	1.1108	1.0429	1.0269
4	.7651	1.0787	1.0535	.9335	1.0486	1.0901	1.0669
5	.8977	1.1403	1.1622	.9785	1.1462	1.1576	1.134
6	.8261	.9831	1.0993	1.0135	1.1523	1.186	1.1751
7	.8566	1.025	1.1218	.9731	1.1576	1.1557	1.145
8	.8824	1.1157	1.2298	1.0498	1.2121	1.2338	1.2338
9	.9838	1.2121	1.387	1.1523	1.273	1.3793	1.3488
10	1.145	1.3184	1.4838	1.2308	1.3191	1.3439	1.3439
11	1.0307	1.2407	1.4049	1.1584	1.2907	1.3153	1.3262
12	.961	1.2056	1.3695	1.1413	1.3134	1.0135	1.3085
13	1.0364	1.2056	1.2665	.3963	1.2669	1.1401	1.3016
14	1.0419	1.2232	1.3695	.3048	1.3016	1.0136	1.3626
15	.9533	1.2056	1.2376	.3353	1.2555	.6401	1.236
16	1.086	1.2056	1.2384	.3048	1.2536	1.273	1.1136
17	1.0193	1.1693	1.1767	.2439	1.2186	1.2711	1.1388
18	1.0913	1.1557	1.2121	.2439	1.2711	1.2296	1.1557
19	.9915	1.1279	1.2902	.4877	1.3439	1.2232	1.0269
20	.8776	1.1965	1.4175	.5487	1.2165	1.1279	1.025
21	1.0163	1.1793	1.3085	.4877	1.2613	1.1218	.9533
22	1.2277	1.1622	1.1751	.6097	1.2165	1.1492	1.0862
23	1.1816	1.134	1.2121	.6706	1.2727	1.1388	1.2102
24	1.105	1.186	1.262	.5792	1.1222	1.1218	1.2132
Max	1.2277	1.3184	1.4838	1.2308	1.3439	1.3793	1.3626
Min	.7651	.9831	1.0535	.2439	1.0486	.6401	.9533
Avg	.9824	1.1642	1.2426	.7434	1.2213	1.1550	1.1723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 204 / 11 KV Nagrale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6724	1.5436	1.5356	1.4872	1.4586	1.5291	1.5307
2	1.6125	1.4807	1.5028	1.4535	1.4426	1.4971	1.4571
3	1.6472	1.4662	1.4762	1.4296	1.4727	1.5333	1.4456
4	1.6766	1.4987	1.4967	1.4621	1.4705	1.5192	1.5505
5	1.7752	1.6762	1.6735	1.6007	1.5538	1.7554	1.712
6	2.1971	2.0039	2.1658	2.0679	2.0578	2.1643	2.1849
7	2.2112	1.8682	2.2098	2.1079	2.0877	2.0366	2.1304
8	1.5752	1.6072	1.6623	1.7021	1.6374	1.6255	1.6526
9	1.3813	1.363	1.2618	1.3382	1.2401	1.2468	1.4011
10	1.2633	1.3519	1.2414	1.2296	1.2483	1.2148	1.238
11	1.3325	1.1593	1.3165	1.1584	1.3234	1.3836	1.3052
12	1.4556	1.4085	1.4022	1.2742	1.3976	1.3245	1.4495
13	1.4693	1.451	1.3435	.6196	1.3915	1.3992	1.4434
14	1.4357	1.4664	1.344	.6158	1.3656	1.3874	1.4342
15	1.4464	1.487	1.4263	.6089	1.4685	1.4639	1.4594
16	1.1763	1.4738	1.4723	.6104	1.454	1.5775	1.4236
17	1.097	1.4891	1.2822	.6165	1.4274	1.4586	1.3786
18	1.4526	1.4457	1.3184	.644	1.4464	1.4979	1.4792
19	2.0744	1.8001	1.832	.8147	1.8443	1.88	1.8717
20	2.2634	2.1887	2.1689	1.025	2.3049	2.242	2.2413
21	2.1304	2.1285	2.0908	1.0021	2.2557	2.2085	2.1635
22	2.013	2.0888	1.9886	1.0105	2.1155	2.1155	2.1521
23	1.872	1.8618	1.8469	.9023	1.9254	1.9898	1.9075
24	1.7132	1.7033	1.571	.7667	1.6183	1.6468	1.6506
Max	2.2634	2.1887	2.2098	2.1079	2.3049	2.242	2.2413
Min	1.097	1.1593	1.2414	.6089	1.2401	1.2148	1.238
Avg	1.6643	1.6255	1.6096	1.1478	1.6253	1.6541	1.6526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 205 / Satteshwar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.6413	.5788	.5093	.6224	.5847
2	.6224	.6224	.5975	.4904	.6348	.6036
3	.6036	.6413	.6224	.4904	.6348	.6224
4	.6224	.6224	.6224	.5093	.6224	.6224
5	.6413	.6036	.6224	.5093	.6413	.6413
6	.6413	.3734	.6036	.4904	.6224	.6413
7	.6602	.6161	.6413	.4904	.6036	.6224
8	.6413	.6413	.6413	.4904	.6224	.6224
9	.6602	.6602	.6413	.5093	.6602	.6413
10	.6602	.6413	.6413	.5281	.6413	.6413
11	.6348	.6413	.6036	.5093	.6413	.6413
12	.6224	.6224	.5658	.4715	.6036	.6224
13	.6224	.6224	.5658	.4904	.5847	.6036
14	.6161	.6036	.6036	.4904	.6036	.5847
15	.6036	.5658	.5847	.4904	.6036	.5847
16	.5847	.5658	.6036	.4527	.5658	.0377
Max	.6602	.6602	.6413	.5281	.6602	.6413
Min	.5847	.3734	.5658	.4527	.5658	.0377
Avg	.6287	.6053	.6087	.4951	.6193	.5823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 202 / 11 KV MIDC PALUS FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5847	.6036	.5415	.6224	.5281	.6036
2	.5175	.5847	.5847	.5415	.6224	.5281	.6036
3	.5359	.6036	.6036	.5228	.6224	.4904	.5847
4	.5304	.6036	.5658	.5281	.6224	.4904	.5658
5	.5121	.6036	.5847	.5658	.6413	.5093	.5847
6	.543	.6036	.5847	.5415	.7167	.547	.5847
7	.5601	.6036	.6413	.5228	.7167	.5658	.547
8	.6722	.6413	.6979	.5658	.6602	.5847	.6602
9	.8029	.6979	.9619	.6036	.9149	.7922	.9511
10	.7455	.7655	1.363	.5847	1.0456	1.2637	1.0425
11	.9114	.7796	1.7164	.5847	1.134	1.2637	.9335
12	.9877	.7545	1.3375		1.1949	1.226	.8029
13	1.0269	.7545	1.1065		1.2449	1.5278	.9808
14	1.0269	1.1443	1.1488		1.4335	1.6804	1.0751
15	1.4523	1.475	1.1616		1.2178	1.9239	1.2323
16	1.6598	1.0751	1.2936		1.3121	1.8861	1.4563
17	1.094	.7922	.8688		1.2323	1.1389	1.0751
18	.9054	.6036	.7373		.7545	.7922	.6602
19	.6979	.6036	.583		.679	.7167	.6413
20	.5847	.6036	.567		.6602	.6224	.6036
21	.5847	.5658	.5601		.6224	.6036	.5847
22	.6224	.6036	.5847		.6224	.6224	.6036
23	.6224	.5847	.5847		.5847	.5847	.6036
24	.5658	.5847	.5847	.5658		.5658	.6224
Max	1.6598	1.475	1.7164	.6036	1.4335	1.9239	1.4563
Min	.5121	.5658	.5601	.5228	.5847	.4904	.547
Avg	.7801	.7174	.8344	.5557	.8642	.8939	.7751

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 203 / 11 KV GONDILWADI AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3757	1.4575	.8768	.3361	.3326	.3361	.2987
2	1.2266	1.442	.8025	.3361	.3142	.3361	.2987
3	1.1401	1.442	.7628	.3206	.3174	.2987	.2829
4	1.0774	1.4089	.7775	.3206	.3174	.3395	.3018
5	1.1469	1.4251	.8429	.3206	.3361	.3772	.3206
6	1.5729	1.4737	.9259	.3361	.3734	.4108	.415
7	2.0891	1.8785	1.0911	.3547	.3734	.3475	.3881
8	.2785	.2957	.2835	.3258	.2801	.3109	.3109
9	.2743	.2534	2.1822	2.7515	2.672	2.7206	.2865
10	.2561	.2772	2.2996	2.4741	2.9492	2.8121	.2534
11	.2772		1.9204	2.3967	2.7854	2.6749	.0362
12		.2561	1.866		2.2565	2.3205	.0362
13		.2149	1.781		2.2455	2.4478	.2534
14		.2195	1.7553		2.2138	2.2291	.2534
15		.2534	1.7604		2.1348	2.1879	.2561
16	.3045	.2896	1.6872		2.0805	2.1136	.2561
17	.3258	.2835	.2835		.2804	.2454	
18	.3658	.3012	.3511		.2534	.2926	.3224
19	.3841	.3658	.3841		.3511	.3326	.3921
20	.4207	.3921	.4294		.3961	.4108	.4527
21	.3511	.3921	.4108		.3961	.4294	.4481
22	1.7004	1.3435	.3961		.3961	.3921	2.3266
23	1.4575	1.1702	.3734		.3584	.3584	2.3482
24	1.5708	1.4575	.9907	.3734		.3584	.3206
Max	2.0891	1.8785	2.2996	2.7515	2.9492	2.8121	2.3482
Min	.2561	.2149	.2835	.3206	.2534	.2454	.0362
Avg	.8798	.7954	1.0514	.8872	1.0615	1.0451	.4721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 204 / 11 KV MINI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1886	.1698	.1698	.1886
2	.1886	.1886	.1886	.1698	.1509	.1509	.1698
3	.1698	.1886	.1886	.1698	.1509	.1509	.1509
4	.1509	.1886	.1698	.1509	.1509	.1698	.1509
5	.1509	.2075	.1886	.1509	.1509	.1698	.1509
6	.1509	.2075	.2075	.1698	.1509	.2075	.1509
7	.1509	.2075	.1886	.1698		.3395	.1698
8	.2263	.3395	.3961	.1698		.3584	.3961
9	.4338	.3584	.3772	.2075		.3506	.3961
10	.3982	.3734	.3772	.3206	.3961	.3841	.4527
11	.4066		.2656	.3584	.415	.3511	.415
12	.3734	.3601	.3258		.3961	.3109	.3772
13	.3395	.3294	.3294		.3584	.3734	.3772
14	.3772	.3429	.3086		.3584		.415
15	.3961	.3429	.285		.3584	.415	.415
16	.3961	.3641	.2721		.3584	.3961	.3961
17	.3961	.3772	.3395		.3772	.3395	.3395
18	.3772	.3206	.3018		.2829	.2829	.3584
19	.3961	.2452	.2452		.2452	.2641	.3018
20	.3395	.2263			.2641	.2641	.2829
21	.2641	.1698			.2452	.2075	.2641
22	.2075	.1698				.2075	.2075
23	.2263	.1698	.1886		.1886	.2075	.2075
24	.2075	.1886	.1886	.1886	.2263	.1698	.1886
Max	.4338	.3772	.3961	.3584	.415	.415	.4527
Min	.1509	.1698	.1698	.1509	.1509	.1509	.1509
Avg	.2880	.2633	.2629	.2012	.2697	.2713	.2884



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 205 / 11 KV MAHADA COLONY

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1478	.1494	.1433	.1478	.1494	.1494
2	.1578	.1494	.1478	.132	.1294	.1509	.1307
3	.1433	.1494	.1294	.1267	.1294	.1294	.1132
4	.1433	.1494	.1307	.1448	.1254	.1478	.1307
5	.1646	.1663	.1509	.1646	.1433	.1867	.1478
6	.1991	.1663	.168	.1791	.1612	.2033	.1867
7	.2328	.1791	.2012	.1928	.1433	.2012	.2172
8	.1928	.1612	.1543	.1886	.1433	.181	.1734
9	.1715	.1791	.1543	.1578	.1543	.1543	.12
10	.1492	.1402	.1254	.156	.1372	.1372	.116
11	.1543		.1402	.1214	.1372	.1372	.1357
12	.156	.156	.1372		.1214	.1543	.1372
13	.156	.1543	.1326		.1227	.1526	.1372
14	.156	.156	.156		.1214	.1402	.1187
15	.1715	.1387	.1372		.1214	.1372	.1227
16	.1715	.1372	.1543		.1543	.1677	.1227
17	.1989	.1526	.1214		.1509	.1715	.1387
18	.2035	.1492	.1715		.1658	.1715	.16
19	.2126	.1734	.1886		.1791	.208	.1886
20	.1753	.1829	.2058		.1829	.2033	.2195
21	.1663	.1848	.1886		.1829	.2012	.2172
22	.1663	.2033	.1677		.1848	.1867	.1867
23	.1478	.168	.1715		.1663	.168	.1698
24	.1543	.1478	.1494	.1578	.1478	.1698	.1478
Max	.2328	.2033	.2058	.1928	.1848	.208	.2195
Min	.1433	.1372	.1214	.1214	.1214	.1294	.1132
Avg	.1709	.1605	.1556	.1554	.1481	.1671	.1537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 206 / 11 KV M.I.D.C. JAWAHAR SHEDDABLE FEEDER HAVING WEEKLY  
 VIDYLAY Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	1.4295	1.6457	1.5586	1.5209	1.563	1.4643
2	.7167	1.3685	1.5963	1.5702	1.5209	1.5253	1.5137
3	.7356	1.4788	1.5963	1.5702	1.5209	1.5253	1.4759
4	.7167	1.4788	1.5775	1.5702	1.5093	1.6007	1.502
5	.679	1.4788	1.5848	1.5586	1.5093	1.608	1.5325
6	.679	1.5471	1.6152	1.608	1.5397	1.6457	1.5325
7	.7167	1.4905	1.634	1.608	1.5397	1.6834	1.4454
8	.9808	1.4483	1.6152	1.6036	1.5282	1.6834	1.4528
9	1.5655	1.5397	1.5775	1.5397	1.5885	1.952	1.695
10	1.6032	2.7052	2.6921	1.4483	1.893	2.1887	1.8904
11	1.6221	3.2188	3.0788	1.3424	1.9576	2.1666	1.8884
12	1.5278	3.1129	2.8685	.7011	1.9795	2.2512	1.4696
13	1.3957	1.1888	1.949	.7011	1.9374	2.3234	1.5848
14	1.3957	2.7778	2.7052	.7011	2.0433	2.5207	1.7705
15	.7975	2.2651	2.7341	.7011	1.8793	2.5293	1.8692
16	.6009	2.553	2.6616	.7011	1.8476	2.5455	1.8692
17	1.6975	2.9388	2.0958	.7316	1.7183	2.4783	1.7111
18	.9808	2.7153	1.608	.7316	1.5963	2.4845	1.4106
19	.679	2.1291	1.608	.7316	1.5282	2.473	1.4411
20	.679	1.7255	1.5775	.7926	1.5775	2.2567	1.4905
21	.6602	1.6573	1.5775	.823	1.5282	2.01	1.5137
22	.7167	1.6385	1.5586	.8535	1.608	1.5819	1.5166
23	.6979	1.6645	1.5397	.823	1.6007	1.4528	1.6007
24	.7468	1.5514	1.634	1.5702	.8535	1.5209	1.5137
Max	1.6975	3.2188	3.0788	1.608	2.0433	2.5455	1.8904
Min	.6009	1.1888	1.5397	.7011	.8535	1.4528	1.4106
Avg	.9727	1.9626	1.9305	1.1475	1.6386	1.9821	1.5898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 201 / 11KV ASAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9391	2.1567	.0343	.0335	.0343	.0339	1.4297
2	1.8233	2.0721	.0343	.0335	.0343	.0343	1.3077
3	1.6728	2.0096	.0343	.0335	.0343	.0343	1.2666
4	1.6941	1.9822	.0343	.0335	.0514	.0343	1.2979
5	1.7387	1.9125	.0343	.0335	.0514	.0343	1.4762
6	1.9121	1.9872	.0343	.0335	.0514	.0343	1.7654
7	1.989	1.9018	.0343	.0335	.0514	.0343	1.8012
8	.0343	.0343	1.523	1.6407	1.6156	1.2003	.0514
9	.0343	.0343	3.0963	3.1176	3.3829	2.7282	.0343
10	.0343	.0343	3.3006	3.0849	3.0617	2.774	.0343
11	.0343	.0343	3.3653	2.9012	3.1908	2.7096	.0343
12	.0343	.0343	3.3368	.5258	3.0612	2.7237	.0396
13	.0351	.0343	3.1028		2.9797	2.6102	.0514
14	.0343	.0343	2.6814		2.6041	2.3663	.0514
15	.0343	.0343	2.5614		2.4588	2.2596	.0343
16	.0419	.0343	2.8102	1.3984	2.3895	1.9971	.0343
17	.0343	.0343	.0503		.0343	.0514	.0343
18	.0343	.0514	.0671		.0343	.0343	.0343
19	.0343	.0514	.0671		.0343	.0343	.0514
20	.0343	.0514	.0671		.0343	.0343	.0514
21	1.1096	.0514	.0671		.0351	.812	1.0418
22	2.4203	.0514	2.4905		.0343	1.7715	2.38
23	2.3708	.0514	2.4905		.0343	1.6934	2.3031
24	2.154	1.0486	.0514	.0335	.0343	.8741	1.8854
Max	2.4203	2.1567	3.3653	3.1176	3.3829	2.774	2.38
Min	.0343	.0343	.0343	.0335	.0343	.0339	.0343
Avg	.8866	.6551	1.3070	.9240	1.0553	1.1214	.7705

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 202 / 11KV MOHITE VADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3056	3.1843	4.7265	4.5249	4.4738	.3026
2	.33	.3079	3.0136	4.5001	4.1815	4.0329	.2869
3	.3285	.3026	2.942	4.1884	3.7007	3.6771	.2861
4	.3463	.1631	2.9789	3.4645	3.6001	3.5795	.3033
5	.3674	.3071	3.1211	4.1381	3.6052	3.5551	.314
6	.442	.3696	3.5269	4.2288	3.7685	3.9239	.378
7	.453	.4248	3.8721	4.4216	4.4559	4.5393	.4481
8	.6752	.6707	.3605	.4652	.426	.4519	.7674
9	7.1224	6.358	.3254	.3773	.3422	.2767	6.2494
10	6.6849	7.0427	.3082	.3498	.3639	.3334	6.6934
11	6.3763	6.3816	.28	.3585	.2922	.3635	6.2886
12	6.2391	6.131	.2995	.4055	.3163	.341	6.0563
13	5.9808	6.081	.3407	.2225	.3849	.3742	6.1557
14	5.6394	5.8566	.3361	.2111	.3544	.3712	5.9785
15	5.5876	5.5773	.298	.2035	.2576	.3399	5.7842
16	4.7851	5.3193	.3453	.2126	.3933	.3811	5.6981
17	.3841	.3029	.4317	.2073	.4466	.3422	.357
18	.4161	.3209	.434	.1951	.4466	.354	.3735
19	.487	.3319	.439	.1875	.4451	.4119	.4542
20	.4869	.3479	.4596	.2301	.4695	.4588	.4927
21	.4588	.575	.4748	.4611	.4664	.4596	.4337
22	.4123	4.3614	3.1238	2.8372	5.6756	.4226	.3517
23	.3338	3.908	3.3036	3.1771	5.7976	.3727	.3357
24	.3491	2.1529	3.9762	5.0869	5.1403	2.1213	.301
Max	7.1224	7.0427	3.9762	5.0869	5.7976	4.5393	6.6934
Min	.3285	.1631	.28	.1875	.2576	.2767	.2861
Avg	2.2938	2.6625	1.5906	1.8690	2.0773	1.4982	2.2954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 203 / 11 KV 4TH SONSAL FEEDER NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0686	.0686	.0686	.0514	.0686	.0857
2	.0343	.0686	.0514	.0686	.0514	.0686	.0686
3	.0343	.0686	.0514	.0686	.0514	.0686	.0686
4	.0343	.0686	.0514	.0686	.0514	.0686	.0686
5	.0686	.0686	.0514	.0686	.0857	.0686	.0686
6	.0686	.0686	.0514	.0686	.0857	.0686	.0686
7	.0857	.0686	.0514	.0686	.0857	.0686	.0686
8	.0857	.0686	.1029	.0686	.0857	.0686	.12
9	.0343		.0343	.0686	.0857	.0686	.0343
10	.0686	.0343	.0343	.0686	.0343	.0686	.0514
11	.0686	.0343	.0343	.0514	.0514	.0686	.0686
12	.0686	.0343	.0343	.0857	.1029	.0796	.0514
13	.0686	.0343	.0514		.0686	.0514	.0514
14	.0686	.0343	.0514		.0686	.0694	.0514
15	.0686	.0686	.0514		.0686	.0747	.0514
16	.0686	.0857	.0514		.0343	.1291	.0514
17	.0686	.0686	.0686	.0008	.0686	.0686	.0514
18	.0686	.0343	.0686		.0686	.0686	.0514
19	.0686	.0343	.0686		.0686	.0686	.0514
20	.0686	.0514	.0686		.0686	.0686	.0686
21	.0686	.0514	.0686		.0686	.1029	.1029
22	.0686	.0514	.0686		.0686	.1029	.1372
23	.0686	.0686	.0686		.0686	.1029	.12
24	.0686	.0686	.0686	.0686	.0857	.0686	.1029
Max	.0857	.0857	.1029	.0857	.1029	.1291	.1372
Min	.0343	.0343	.0343	.0008	.0343	.0514	.0343
Avg	.0629	.0567	.0571	.0638	.0679	.0754	.0714

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 204 / 11KV MOHITE VADGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9549	.969	.9282	.8379	.8367	.9876	.8985
2	.8715	.9903	.9145	.8356	.7388	.9374	.844
3	.868	.9796	.8802	.8257	.7438	.8878	.8364
4	.9297	.9651	.9099	.8905	.8173	.8753	.8973
5	1.0131	.9769	1.0235	.9724	1.0018	.9449	.9804
6	1.2193	1.1771	1.233	1.0696	1.2189	1.1244	1.1763
7	1.3618	1.3078	1.3428	1.198	1.2852	1.3131	1.379
8	1.1286	1.1538	1.0916	1.1553	1.1114	1.075	1.1907
9	.9072	1.0295	.9141	.9225	.8471	.9123	.8882
10	.9115	.926	.9067	.8634	.7473	.9223	.8823
11	.8802	.9172	.9124	.7876	.8198	.8896	.8196
12	.9228	.9842	.9016	.833	.9339	.9354	.9037
13	.9317	1.0547	.9103	.4378	.9842	.9	.8779
14	.9812	1.0314	.8604	.4492	.9795	.8953	.8292
15	.9012	1.0536	.8432	.4519	1.0134	.8067	.8206
16	.884	1.0692	1.0193	.4641	1.0509	.8252	.9208
17	1.0356	1.0669	.916	.4988	1.0326	.804	1.0197
18	1.1378	1.1694	1.1001	.5415	1.1058	.8467	1.0944
19	1.2905	1.3271	1.2373	.5845	1.2772	1.2891	1.2989
20	1.4963	1.5208	1.4895	.8078	1.4723	1.5928	1.5932
21	1.4541	1.4449	1.4746	.7998	1.4994	1.5108	1.4658
22	1.2849	1.3169	.7198	.7335	1.3642	1.31	1.3489
23	1.2197	1.2114	1.1625	.6882	1.2308	1.1694	1.2171
24	1.0414	1.0612	.9907	.9359	.9129	1.0772	.977
Max	1.4963	1.5208	1.4895	1.198	1.4994	1.5928	1.5932
Min	.868	.9172	.7198	.4378	.7388	.804	.8196
Avg	1.0678	1.1127	1.0284	.7744	1.0427	1.0347	1.0483

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 205 / 11 KV RAMAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0671	4.7015	5.8337	5.2298	4.8735	.0686
2	.0514	.0671	4.372	5.2736	4.5267	4.3744	.0671
3	.0686	.0671	4.1368	4.8964	4.0848	4.1	.0671
4	.0686	.0671	4.1228	4.6106	3.7495	3.9781	.0671
5	.0857	.0671	4.1228	4.2943	3.8962	3.9781	.0857
6	.1029	.0671	4.1865	4.2829	3.8962	4.0695	.0838
7	.1029	.0671	4.386	4.4658	4.4772	4.4213	.0857
8	.1029	.0671	.0857	.0686	.0914	.0686	.12
9	3.4507	6.2033	.0983	.1029	.0819	.1029	3.2895
10	3.5894	6.7238	.0655	.0983	.0983	.0983	3.6221
11	3.5285	6.6282	.0655	.0983	.0983	.0983	3.3997
12	3.5285	6.2064	.0819	.0983	.0983	.0983	3.5803
13	5.609	5.5037	.0819		.1147	.0983	5.8738
14	5.6699	5.1193	.0819	.2134	.0983	.0983	5.7004
15	5.6561	4.9155	.0655		.0983	.0819	5.6253
16	5.3094	4.8217	.0983		.1475	.0819	6.0159
17	.0857	.0686	.1006		.12	.0838	.1006
18	.0686	.0857	.1029		.1006	.0857	.12
19	.0686	.1029	.1006		.1006	.1029	.1543
20	.0686	.12	.1006		.1006	.1029	.1543
21	.0686	.1029	.1006		.1006	.1006	.1543
22	.0686	5.2245	6.7711	3.5056	6.3169	.1029	.1372
23	.0686	5.233	6.954	3.597	6.1645	.0857	.1029
24	.0514	2.8426	5.7764	6.2109	5.7309	2.2939	.0838
Max	5.6699	6.7238	6.954	6.2109	6.3169	4.8735	6.0159
Min	.0514	.0671	.0655	.0686	.0819	.0686	.0671
Avg	1.5635	2.5183	2.1150	2.9782	2.0634	1.3992	1.6150

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 206 / 11 KV CHINCHNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4684	2.4272	.0514		.0686	.0686	1.9113
2	2.3106	2.3357	.0514	.0686	.0686	.0686	1.736
3	2.2304	2.1929	.0514	.0686	.0686	.0732	1.6888
4	2.1999	2.1872	.0514	.0686	.0686	.0686	1.7223
5	2.3298	2.1567	.0686	.0686	.0857	.0686	1.7528
6	2.2967	2.1567	.0686	.0686	.0857	.0686	1.9113
7	2.3743	2.2424	.0857	.0686	.0857	.0686	2.0866
8	.2076	.0671	.0686	.0686	.0914	.0686	.0686
9	.0857	.0655	2.5983	3.294	3.517	3.2285	.0686
10	.0857	.0838	2.9169	3.4183	3.5799	3.3223	.0655
11	.0686	.0819	3.1089	3.3341	3.5074	3.355	.0655
12	.0686	.0655	3.5307	1.829	3.4019	3.1466	.0983
13	.0686	.0655	3.5261		3.3059	2.9264	.0655
14	.0686	.0655	3.3036		3.1817	2.6711	.0655
15	.0686	.0655	2.875		3.0857	2.5751	.0819
16	.0686	.0655	2.8467		2.8631	2.5164	.0819
17	.0686	.0686	.253		.1006	.0671	.0838
18	.0686	.0686	.1029		.1006	.0686	.0857
19	.0686	.0857	.1029		.1006	.0686	.0857
20	.0686	.0857	.1006		.1006	.0686	.1029
21	.0686	.0686	.1006		.1006	.0686	.1029
22	2.4623	.0686	.0671		.0671	2.207	2.6785
23	2.6147	.0686	.0671		.0671	2.1415	2.6566
24	2.5651	1.1797	.0514	.0686	.0857	1.166	2.3411
Max	2.6147	2.4272	3.5307	3.4183	3.5799	3.355	2.6785
Min	.0686	.0655	.0514	.0686	.0671	.0671	.0655
Avg	1.0411	.7508	1.0854	1.0354	1.1579	1.2563	.9003



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 201 / 11 KV Wine Park 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.1257	.1006	.08	.0429	.1063	.1048
2	.1949	.1257	.1166	.108	.0429	.1032	.0914
3	.197	.1143	.1349	.1036	.0396	.1063	.0985
4	.2172	.1257	.1132	.0838	.0463	.1063	.1069
5	.2378	.1086	.1105	.0777	.0429	.141	.0796
6	.2172	.1086	.1189	.0869	.0514	.1692	.08
7	.5194	.4854	.6535	.0625	.4527	.6224	.1166
8	.0972		.2534	.072	.6602	.7733	.4607
9	1.2826	.6979	1.0185	.1536	1.1317	.9808	.9335
10	1.8107	.9907	1.0374		.679	.6602	.9431
11	1.1694	1.226	1.2826		.6979	1.5339	1.226
12	1.6221	1.0751	1.0185		.7356	1.2826	1.1317
13	1.9616	.7356	.7356		.7356	.7545	1.1317
14	1.9805	1.226	.7545		1.1317	1.0608	1.1317
15	1.5089	.9054	.7733		1.1694	1.6804	1.1317
16	1.1128	.7545	.7545		.8676	1.6787	1.1317
17	.7545	.3395	1.2071		.3584	1.094	1.226
18	.5658	.6413	.9619		.2452	.8002	.4904
19	.3772	.6979	.7733		.2263	.9335	.2229
20	.2641	.1806	.1677		.2075	.1656	.1802
21	.2263	.1115	.2587		.1867	.1578	.1429
22	.2075	.1395	.156	.0503	.1677	.1738	.0953
23	.1886	.1029	.1404	.0476	.1063	.1174	.0943
24	.08	.1886	.1153	.1257	.0377	.1063	.109
Max	1.9805	1.226	1.2826	.1536	1.1694	1.6804	1.226
Min	.08	.1029	.1006	.0476	.0377	.1032	.0796
Avg	.7088	.4873	.5315	.0876	.4193	.6379	.5192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 202 / 11 KV Andhali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3734	1.8442	2.0485	1.9766	2.1051	.3772
2	.3395	.3734	1.8275	2.0567	1.9292	2.1051	.3772
3	.3206	.3772	1.8107	2.0567	1.9524	2.1051	.3961
4	.3206	.3772	1.8515	2.0567	1.9524	2.1293	.415
5	.3584	.415	2.0056	2.0645	2.0005	2.2634	.4715
6	.4527	.4715	2.2298	2.2024	2.0325	2.3304	.5093
7	.5281	.5847	2.3975	2.3266	2.2885	3.2526	.5093
8	.415		.5093	.4527	.2721	.2683	.4338
9	2.6886	2.8509	.4338	.547	.3361	.3521	2.7854
10	2.9504				.3206	.4338	2.7035
11	2.8509	2.5943	.3395		.2721	.415	2.6216
12	2.8673	2.8656	.3584		.2721	.3584	1.8023
13	2.8673	2.7999	.3584		.2721	.3395	2.4577
14	2.6719	2.7854	.3395		.3734	.3395	2.6216
15	2.6216	2.8673	.3206		.4108	.3961	2.8346
16	2.4905	3.0498	.3206		.4854	.4338	2.915
17	.3277	.5281	.4715		.4854	.5093	.5658
18	.3605	.4904	.4904		.4854	.4715	.4715
19	.3978	.547	.4715		.5228	.6036	.5658
20	.4854	.5658	.4904		.5601	.5847	.5658
21	.4854	.547	.4904		.5601	.5658	.5658
22	.4481	2.3304	2.2405	2.2565	2.4459	.5093	.5658
23	.4108	2.0645	2.1285	2.0557	2.1548	.4904	.5093
24	.3584	.3734	1.8623	2.0485	1.9766	2.1051	.415
Max	2.9504	3.0498	2.3975	2.3266	2.4459	3.2526	2.915
Min	.3206	.3734	.3206	.4527	.2721	.2683	.3772
Avg	1.1810	1.3742	1.1127	1.8477	1.0974	1.0611	1.1857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 203 / 11Kv Andhali Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2427	.2829	.3361	.2075	.3174	.3206
2	.2829	.2427	.2829	.3547	.2263	.3174	.3206
3	.2641	.2427	.3206	.3734	.2241	.3174	.3206
4	.2641	.2801	.3584	.3921	.2054	.3174	.3584
5	.2829	.3361	.4527	.3921	.2641	.4527	.3772
6	.2641	.3734	.5281	.4481	.3584	.547	.5281
7	.3772	.4163	.5281	.4854	.4715	.4477	.5281
8	.3511		.4298	.3881	.3547	.394	.415
9	.3544	.3077	.3294	.3224	.2614	.3403	.3189
10	.3544	.2303	.333		.2801	.3224	.2715
11	.3475	.2865	.3155		.2614	.2835	.2378
12	.3292	.2947	.3224		.2614	.2804	.2614
13	.2957	.2835	.3045		.2614	.3366	.1867
14	.2987	.3189	.2865		.2427	.3189	.1867
15	.3361	.3077	.3045		.2427	.3189	.112
16	1.1128	.3189	.3045		.056	.3012	.0905
17	.4108	.2686	.3155		.1867	.3155	.0724
18	.4481	.1886	.4607		.2054	.3185	.1991
19	.4854	.394	.4607		.3547	.5194	.543
20	.4854		.5359		.5041	.567	.5973
21	.4854	.6224	.499		.5228	.5228	.5228
22	.4481	.4904	.4904	.415	.4108	.4805	.4715
23	.3734	.3772	.3584	.2829	.3734	.3961	.3772
24	.3395	.2427	.3395	.3174	.2263	.2941	.3395
Max	1.1128	.6224	.5359	.4854	.5228	.567	.5973
Min	.2641	.1886	.2829	.2829	.056	.2804	.0724
Avg	.3872	.3212	.3810	.3756	.2901	.3761	.3315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 204 / 11KV BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6636	1.9783	.352	.3459	.3886	.3551	.8856
2	1.6042	1.8937	.3322	.3246	.3833	.333	.8749
3	1.6339	1.88	.3277	.3193	.3787	.336	.8635
4	1.5951	1.8686	.3437	.3178	.3833	.3368	.964
5	1.7688	2.0272	.3612	.3239	.4016	.394	1.1202
6	2.2124	2.2908	.4503	.4031	.4663	.4786	1.6591
7	3.0247	2.5407	.4778	.445	.4992	.4924	2.0873
8	.3444	.4138	.4283	.3292	.3802	.3757	.3589
9	.2324	.2835	2.7275	2.5111	2.8829	1.9837	.2393
10	.192	.1829	2.5797	1.4944	2.761	1.8724	.2355
11	.2355	.1913	2.4714	1.4106	2.4791	2.7199	.2317
12	.2484	.2141	2.2976	1.2582	2.2466	2.8388	.0297
13	.2454	.2423	2.0721		2.1071	2.5454	
14	.2301	.2286	2.1003		2.0058	2.3914	
15	.2477	.2469	2.0386		1.9418	2.3777	.096
16	.2477	.2446	1.97	1.0037	1.9829	2.2626	.3094
17	.3132	.2926	.2095	.2012	.2316	.2492	.3094
18	.3688	.2774	.2408	.2088	.2461	.2758	.3078
19	.4084	.3696	.3239	.2233	.3315	.3901	.4458
20	.4427	.2507	.4267	.2545	.4191	.4366	.535
21	.4244	.4221	.4511	.2545	.4602	.4823	.516
22	2.0203	.4199	.2624	.4671	.4397	1.2414	1.9837
23	2.0858	.4016	.4054	.4427	.4244	1.1919	2.1445
24	1.2795	.9862	.3581	.394	.3825	.7887	1.4693
Max	3.0247	2.5407	2.7275	2.5111	2.8829	2.8388	2.1445
Min	.192	.1829	.2095	.2012	.2316	.2492	.0297
Avg	.9612	.8395	1.0003	.6159	1.0260	1.1312	.8030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 205 / 11 KV MORALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.014	2.7427	.1562	.1859	.1844	.1856	2.8974
2	2.9698	2.6802	.1593	.1669	.1897	.189	2.793
3	2.9294	2.646	.1646	.1715	.1844	.1821	2.7725
4	2.937	2.5955	.1654	.1676	.1897	.1905	2.7412
5	2.995	2.7793	.1661	.1905	.1852	.1853	2.7473
6	3.062	2.8928	.2118	.205	.2118	.2332	2.8365
7	3.2473	3.1138	.2263	.221	.2377	.2248	3.1009
8	.2545	.2248	.4527	.2454	.4298	.2873	.2347
9	.2225	.1821	4.0458	4.5893	4.5664	4.4559	.176
10	.2141	.1829	3.9598	2.5316	4.606	4.6365	.1905
11	.0945	.189	4.0329	2.5865	4.5321	4.385	.2012
12		.2141	4.1655	2.4364	4.4277	4.4132	.2095
13	.1154	.2149	4.215		4.3782	4.2981	.1882
14	.1532	.1943	4.1731		4.1662	4.0794	.1775
15	.1593	.2057	4.1305		4.1175	4.1243	.1608
16	.0991	.2004	4.087	2.0538	4.1411	4.0619	.1692
17	.064	.2164	.1852	.1349	.1875	.2141	.189
18	.1615	.2195	.1943	.1288	.1897	.1996	.2012
19	.2339	.189	.2111	.1364	.2057	.2195	.2126
20	.2317	.2004	.2233	.1364	.2347	.2477	.2202
21	.2454	.2073	.2035	.1395	.253	.4328	.2652
22	2.8883	.1897	.205	.2225	.2195	3.1032	2.9767
23	2.9592	.1852	.2141	.1882	.1928	3.0795	2.9729
24	2.9043	1.3489	.1676	.1875	.1913	1.7368	3.0224
Max	3.2473	3.1138	4.215	4.5893	4.606	4.6365	3.1009
Min	.064	.1821	.1562	.1288	.1844	.1821	.1608
Avg	1.3981	1.0006	1.5048	.8107	1.6009	1.8902	1.3190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 401 / 33 KV SOOTGIRANI

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9547	1.8427	1.8759	1.7306	1.8427	1.8759	1.9718
2	1.9547	1.8256	1.8587	1.8427	1.8416	1.7455	1.8587
3	1.8427	1.8245	1.9718	1.8599	1.785	1.7113	1.8245
4	1.8085	1.8073	1.8073	1.8427	1.785	1.6941	1.9204
5	1.7913	1.8073	1.8587	1.9547	1.7455	1.7113	1.9376
6	1.7913	1.8587	1.8587	1.9547	1.6152	1.7284	1.8587
7	1.8085	1.7284	1.8587	2.0667	1.6547	1.8587	1.8587
8	1.7306	1.8587	1.9718	2.0667	1.7507	1.8587	1.8587
9	1.7306	.2743	1.5192	1.7306	1.5809	1.8587	1.8416
10	1.8256	1.7135	1.9547	.2743	.2229	1.9547	1.9718
11	1.6186	1.7306	1.9376	.2743	1.9204	1.8587	1.9718
12	1.9205	1.5021	1.9204	.2401	1.6152	1.8587	1.8587
13	1.7913	1.8245	1.9204	.2401	1.6323	1.7455	1.9547
14	1.7913	1.7113	1.7925	.2572	1.5809	1.7455	1.6375
15	1.9033	1.8073	1.9033	.2229	1.5809	1.7455	1.6889
16	1.9205	2.085	2.085	.2572	1.485	1.9718	1.8021
17	1.9033	1.6152	2.0496	.2743	1.5809	1.8587	1.8021
18	1.3432	1.8416	1.8427	.2743	1.6941	1.6152	1.8587
19	1.7742	1.5021	1.8427	.2915	1.7113	1.5021	1.8021
20	1.3261	1.5021	1.8427	.2743	1.8073	1.5021	1.6889
21	1.7913	1.5021	1.8427	.2915	1.8416	1.485	1.6323
22	1.7913	1.7284	1.8427	1.8427	1.8587	1.8416	1.9547
23	1.757	1.8416	1.8427	1.8599	1.8416	1.9718	1.8416
24	2.0667	1.8427	.2743	1.7478	1.9547	.2743	1.9718
Max	2.0667	2.085	2.085	2.0667	1.9547	1.9718	1.9718
Min	1.3261	.2743	.2743	.2229	.2229	.2743	1.6323
Avg	1.7890	1.6907	1.8115	1.0697	1.6637	1.7072	1.8487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 203 / 11 KV PALUS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	04-APR-17
HR	Load (MW)
24	.9335
Max	.9335
Min	.9335
Avg	.9335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 201 / KADEPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662	1.9109	.2241	.2195	.1254	.2241	1.8233
2	1.7695	1.8623	.2241	.2195	.1267	.1509	1.8233
3	1.704	1.7814	.2241	.2218	.128	.1509	1.7695
4	1.749	1.7814	.2263	.2195	.1267	.1509	1.7695
5	1.7695	1.7814	.2263	.2561	.1478	.2241	1.8023
6	1.8351	1.7394	.2263	.2957	.0274	.2241	1.8138
7	1.9433	1.9524	.2987	.3326	.1494	.2957	1.7924
8	.3326	.2926	.2987	.3658	.1478	.2926	.2957
9	.2987	.2926	2.5911	2.8182	3.2769	3.0498	.2957
10	.2926	.2957	2.9835		3.1824	3.0148	.3696
11	.2926	.2241	3.0498		3.1161	3.0148	.3734
12	.2926	.2218	3.0803		3.0803	2.8837	.2926
13		.2241	2.915		2.7854	2.7854	.2713
14		.2241	2.8182		2.7206	2.7206	.2987
15	.2926	.2987	2.6871		2.6246	2.7206	.2957
16		.2987	2.5911		2.4326	2.3685	.2957
17		.2987	.2926		.2926	.2241	.2957
18	.2926	.2241	.2561		.2957	.2926	.2957
19	.3658	.2987	.2896		.2957	.2926	.3696
20	.2926	.2241	.2957		.2957	.2987	.2957
21	.2926	.2263	.2957	.1829	.2218	.2987	.2987
22	2.1052	.2263	.2587	.1829	.2241	1.8351	2.0972
23	2.0243	.2241	.2561	.1267	.2241	1.8351	2.0081
24	2.0729	1.9433	.2241	.2218	.1267	.2241	1.8351
Max	2.1052	1.9524	3.0803	2.8182	3.2769	3.0498	2.0972
Min	.2926	.2218	.2241	.1267	.0274	.1509	.2713
Avg	1.0992	.7853	1.1181	.4356	1.0906	1.2322	.9533



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 203 / 11 KV Wangi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0366	.535	.4816	.8322	.6622	.0747
2	.0366	.0366	.4816	.4816	.8429	.6622	.0747
3	.0366	.0366	.4816	.4816	.8535	.602	.0747
4	.0366	.0366	.535	.4877	.8429	.5944	.0747
5	.0747	.0366	.5868	.5487	.8322	.6539	.0747
6	.0747	.0366	.6173	.6173	.8322	.7133	.0747
7	.0747	.0366	.7316	.7133	.8322	.695	.0747
8	.0747	.0366	.0724	.0732	.0747	.0739	.0747
9	1.2803	1.2193	.1478	.0747	.0739	.0739	.9877
10	1.2803	1.0974	.0739		.0732	.0724	1.1248
11	1.1385	1.0494	.1463		.0732	.0739	1.0623
12	1.1248	.9755	.1478		.0693	.0732	1.0623
13	1.1248	.9145	.0732		.0724	.0732	.9998
14	.9755	.8215	.0724		.0701	.0739	.9259
15	.9755	.8322	.0709		.0716	.0739	.9031
16	.9755	.7529	.0716		.0724	.0732	.7895
17	.0366	.0739	.0724		.0732	.0724	.1448
18	.0366	.0732	.0739		.0739	.0739	.0732
19	.0358	.0739	.0747		.0747	.0739	.112
20	.0366	.0747	.0739		.0747	.0747	.112
21	.0366	.1494	.0739	.0934	.0747	.0739	.112
22	.0366	.5868	.7407	.0924	.7316	.0747	.0747
23	.0366	.5418	.6706	1.0456	.8749	.0747	.0732
24	.0747	.0366	.535	.6097	.8215	.7316	.0747
Max	1.2803	1.2193	.7407	1.0456	.8749	.7316	1.1248
Min	.0358	.0366	.0709	.0732	.0693	.0724	.0732
Avg	.4037	.3986	.2983	.4462	.3883	.2706	.3846

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 204 / 11 KV AMARAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1646	.1132	.1097	.1478	.1294	.1307
2	.1097	.1646	.1132	.0914	.1463	.112	.112
3	.128	.1646	.1132	.0905	.1478	.112	.112
4	.128	.1646	.1307	.112	.1463	.1307	.132
5	.1494	.1646	.1294	.1307	.1848	.1494	.132
6	.168	.1646	.1663	.1307	.2033	.168	.1509
7	.2218	.2378	.2218	.2195	.2033	.2195	.2195
8	.1646	.1646	.1417	.181	.1829	.1417	.1433
9	.1387	.128	.12	.1433	.168	.1075	.104
10	.1097	.0848	.1006		.1372	.0686	.1357
11	.104	.0937	.1029		.112	.0867	.1629
12	.1052	.1187	.1017		.0995	.0867	.1791
13	.1052	.12	.116		.0876	.0876	.1791
14	.1646	.1052	.1029		.1052	.0876	.1214
15	.1463	.1402	.0857		.104	.104	.1052
16	.1463	.1029	.128		.1187	.0693	.1006
17	.1463	.0995	.1448		.1174	.0829	.116
18	.1463	.1311	.128		.1372	.116	.1307
19	.1646	.1734	.168		.1595	.1629	.1715
20	.2378	.2172	.1646	.2172	.2033	.181	.208
21	.2195	.197	.2054	.2218	.1829	.1646	.1829
22	.2012	.1494	.1848	.2218	.1663	.1494	.1494
23	.2012	.1494	.1494	.1829	.1494	.168	.1494
24	.1307	.1829	.1307	.1494	.1463	.1294	.1494
Max	.2378	.2378	.2218	.2218	.2033	.2195	.2195
Min	.104	.0848	.0857	.0905	.0876	.0686	.1006
Avg	.1520	.1493	.1360	.1573	.1482	.1256	.1449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 205 / 11 KV Wangi Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2195	.168	.1646	.1478	.1753	.168
2	.1646	.2195	.1494	.1463	.1463	.1753	.1494
3	.1463	.2195	.132	.1494	.1478	.1595	.1307
4	.1478	.2195	.1698	.168	.1463	.1595	.1886
5	.2054	.2743	.1867	.1867	.1848	.2172	.2075
6	.2614	.2743	.2427	.2241	.2241	.2587	.2263
7	.2957	.3109	.2427	.3109	.2172	.2218	.2534
8	.2012	.2012	.1848	.2378	.197	.181	.168
9	.2033	.1886	.1791	.1829	.2374	.1865	.2054
10	.2378	.1823	.1578		.2035	.0926	.1928
11	.2378	.1886	.1612		.1509	.0949	.1734
12	.1463	.1629	.1696		.156	.0848	.1715
13	.1463	.2058	.1875		.1387	.2012	.1357
14	.2012	.2058	.2058		.1898	.2035	.1543
15	.2012	.2204	.2012		.1656	.2204	.1612
16	.2195	.2267	.208		.1829	.2155	.2204
17	.2378	.1696	.1943		.208	.2294	.1677
18	.2561	.176	.1791		.2204	.2105	.2378
19	.2012	.2172	.2507		.2254	.2713	.2427
20	.2743	.2507	.2561	.2195	.2804	.2835	.2804
21	.2561	.2378	.2378	.1848	.2774	.2804	.3086
22	.2561	.2241	.2534	.1848	.2195	.2427	.2402
23	.2378	.2054	.2195	.1646	.2103	.2054	.2195
24	.2054	.2378	.1848	.1829	.1463	.1907	.1867
Max	.2957	.3109	.2561	.3109	.2804	.2835	.3086
Min	.1463	.1629	.132	.1463	.1387	.0848	.1307
Avg	.2135	.2183	.1968	.1934	.1927	.1984	.1996

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 206 / 11 KV CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4419	1.5402	.112	.1097	.0701	.1109	1.7901
2	1.3763	1.5402	.112	.1097	.0716	.1109	1.7238
3	1.4251	1.5402	.112	.1097	.0724	.0739	1.7238
4	1.4419	1.5402	.112	.1109	.0732	.0739	1.8442
5	1.5074	1.5546	.112	.1097	.0924	.112	1.8564
6	1.5729	1.5546	.1494	.112	.0895	.112	1.4723
7	1.6385	1.6385	.1494	.1478	.0895	.1294	1.4998
8	.1097	.0732	.1075	.1017	.0895	.1433	.1478
9	.1109	.0914	2.2542	2.1879	2.1216	2.1879	.1417
10	.0732	.1075	2.6155		2.6825	2.3205	.1109
11	.0732	.104	2.4143		2.4143	2.3205	.104
12	.0886	.1063	2.3205		2.3205	2.0972	.1402
13	.0914	.1052	2.3205		1.9433	1.8351	.1357
14	.0914	.1052	2.2283		2.0317	1.7695	.1463
15	.0914	.1063	2.1628		2.0972	1.9227	.1463
16	.0914	.104	2.0317		1.9433	1.704	
17	.0914	.096	.1235		.0949	.0995	.0983
18	.0914	.0983	.1463		.1029	.088	.1433
19	.0914	.1402	.1075		.1086	.1372	.1402
20	.0914	.1478	.1463	.1075	.0914	.1417	.1463
21	.0914	.1463	.1448	.0905	.1086	.1372	.1478
22	1.6385	.112	.1109	.0895	.1086	1.8564	1.8564
23	1.6057	.112	.1109	.0709	.1109	1.8564	1.7695
24	1.4586	1.5729	.112	.1109	.0701	.1109	1.8442
Max	1.6385	1.6385	2.6155	2.1879	2.6825	2.3205	1.8564
Min	.0732	.0732	.1075	.0709	.0701	.0739	.0983
Avg	.6827	.5932	.8465	.2549	.7916	.8938	.8317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 207 / KADEPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.3772	.2641	.3018	.2743	.2263	.3395
2	.2641	.3772	.2452	.2641	.2772	.2075	.3395
3	.2829	.3772	.2452	.3018	.2743	.2075	.3772
4	.3018	.3772	.2452	.3395	.2772	.2452	.415
5	.3395	.3961	.2452	.3772	.3142	.3018	.4527
6	.3961	.4527	.3584	.4338	.3734	.3584	.4904
7	.4527	.4715	.415	.5093	.3734	.4338	.4338
8	.3018	.3772	.3018	.2641	.3772	.2452	.3584
9	.2641	.3018	.2829	.2452	.2801	.2641	.3206
10	.3395	.3206	.3018		.2263	.3018	.3018
11	.3772	.3547	.3772		.3395	.3018	.3395
12	.3772	.3921	.3772		.3961	.3961	.3395
13	.3772	.3547	.3961		.3772	.3584	.3395
14	.3961	.3772	.3584		.3395	.3584	.3395
15	.3961	.3921	.3206		.3772	.3961	.3361
16	.3961	.3395	.3018		.3206	.4108	.2829
17	.3772	.3395	.2829		.3206	.3395	.2263
18	.3584	.3584	.3018		.2829	.3395	.2686
19	.3961	.415	.3206		.2452	.415	.3292
20	.3961	.3018	.3395		.2452	.3961	.3174
21	.3772	.3018	.3584	.3018	.2263	.415	.3018
22	.415	.3174	.3772	.2987	.2829	.4338	.3018
23	.3961	.2829	.3395	.2772	.2829	.3961	.2829
24	.2452	.3772	.2641	.3018	.2772	.2263	.3772
Max	.4527	.4715	.415	.5093	.3961	.4338	.4904
Min	.2263	.2829	.2452	.2452	.2263	.2075	.2263
Avg	.3521	.3639	.3175	.3243	.3067	.3323	.3421

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 201 / Kadegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.8865	.8402	.8962	.8764	1.0829	.8775
2	.9335	.8501	.8029	.8871	.8299	1.0456	.8686
3	.9335	.8589	.811	.9054	.7392	.9709	.8871
4	.9335	.8865	.811	.9149	.8962	.9335	.8962
5	.9709	.8962	.8488	.9619	.9808	1.0829	.9335
6	1.2136	1.0829	1.1317	.9877	1.2071	1.1949	1.1203
7	1.4937	1.2567	1.2936	1.1949	1.307	1.4003	1.307
8	1.1765	1.2696	1.0974	1.1462	1.3443	1.2071	1.1888
9	.9955	.9877	.9412	.9877	1.1317	1.0745	1.086
10	.985	1.0029	.985		.924	.8859	.8954
11	.9671	.9511	.8954		.9313	.9745	.9036
12	1.1576	.924	.9134		.9313	.8954	.985
13	1.0029	.9149	.9671		.9745	.9313	.9412
14	.9774	.8859	.9955		.9568	.9412	.9231
15	.9328	.8954	.9671		.985	.9511	.9511
16	.9412	.8954	.9412		.8954	.985	.9511
17	.788	.8764	.9465		.985	.9214	.9313
18	.9816	.7973	.9134		1.1222	.8916	.9465
19	1.1462	1.1765	1.1827		1.3032	1.1765	1.0745
20	1.3169	1.2803	1.3535	1.307	1.3394	1.3169	1.4266
21	1.2752	1.2012	1.3306		1.2803	1.2012	1.3535
22	1.1576	1.2012	1.1827		1.2136	1.1088	1.1706
23	1.0082	1.0269	1.0642		1.1203	1.0269	1.0642
24	1.0269	.9149	.8962	.9328	.9979	1.1203	.9335
Max	1.4937	1.2803	1.3535	1.307	1.3443	1.4003	1.4266
Min	.788	.7973	.8029	.8871	.7392	.8859	.8686
Avg	1.0520	.9966	1.0047	1.0111	1.0530	1.0550	1.0257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 202 / MIDC No.1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0328	2.1502	2.2405	2.2445	1.6804	2.1658	2.1068
2	2.0119	2.1845	2.1437	2.1845	1.9022	2.1658	2.0698
3	2.0119	2.1622	2.0119	2.1845	1.8099	2.1068	2.0328
4	2.0119	2.1253	1.9185	2.2257	1.7177	2.1068	2.0328
5	2.0119	2.0883	1.9185	2.0328	1.7909	2.0698	2.0328
6	1.9753	2.1068	1.8823	2.0144	1.7909	2.0513	2.1437
7	1.9959	2.0698	1.8461	2.0513	1.9022	2.0513	2.0485
8	1.8823	2.0119	1.8823	1.7193	1.922	1.9936	2.0119
9	2.0328	2.2032	2.0119	.9202	2.0165	2.0485	2.1658
10	2.1658	2.0883	2.0328		2.1216	2.1253	2.0328
11	2.2822	2.0328	2.1437		2.0698	2.2032	2.1845
12	2.3765	2.0165	2.1845		2.0328	2.0698	1.9959
13	2.1285	2.037	1.9204		1.7918	1.8073	1.8267
14	2.1622	1.9022	2.0725		2.0119	1.9753	1.97
15	2.2822	1.9959	2.1098		2.1285	2.1437	2.0485
16	2.2822	2.0698	2.1285		2.1658	2.1068	2.1098
17	2.2405	2.0698	2.1472		2.2405	2.3765	2.1658
18	2.2634	2.0911	2.0911		2.2822	2.3011	2.2032
19	2.2822	2.0911	2.0698		2.2822	2.2405	2.1658
20	2.1098	2.1658	2.1845		2.1658	2.1658	2.1285
21	2.2257	2.1658	2.2218		2.1098	2.2032	2.1658
22	2.1658	2.0119	2.1807		2.2405	1.9185	2.1658
23	2.0698	1.701	2.0144		2.2592	2.0698	2.1807
24	2.0911	2.2257	2.0538	2.2032	1.3717	2.2032	2.1658
Max	2.3765	2.2257	2.2405	2.2445	2.2822	2.3765	2.2032
Min	1.8823	1.701	1.8461	.9202	1.3717	1.8073	1.8267
Avg	2.1289	2.0736	2.0588	1.9780	1.9920	2.1112	2.0898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 203 / Shalgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.2321	3.0243	3.6389	3.924	4.193	.2359
2	.2389	.2301	2.907	3.4914	3.8043	4.0444	.2351
3	.2256	.2108	2.8068	3.3288	3.725	3.9193	.2336
4	.2374	.2133	2.7778	3.2129	3.5703	3.6847	.2321
5	.2435	.2405	2.8083	3.2373	3.7266	3.6085	.2374
6	.289	.2776	3.1333	3.484	4.0039	3.6243	.276
7	.3231	.3171	3.0636	3.8679	4.3286	4.0779	.3429
8	.5575	.8069	.2985	.3042	.2617	.3086	.7331
9	5.5655	5.8611	.2542	.2424	.2393	.2454	5.7916
10	5.5451	5.7171	.2488	.1417	.2313	.189	5.7183
11	5.7739	5.4397	.2514	.0838	.173	.1822	6.089
12	5.3477	5.3117	.2492	.0671	.208	.2339	5.9648
13	5.4897	5.1387	.213	.1174	.2332	.2585	6.0173
14	5.3182	4.935	.2171	.1425	.2336	.2184	5.9471
15	5.0568	4.7163	.2256	.1379	.2282	.2416	5.6074
16	4.7531	4.7104	.2446	.1456	.2279	.2665	4.987
17	.2576	.2348	.2542	.1501	.2439	.2704	.2315
18	.2599	.2271	.2889	.3246	.2351	.2649	.2439
19	.2927	.2496	.271	.141	.2358	.2717	.2816
20	.314	.3125	.3177	.16	.2622	.2951	.3063
21	.2788	.5108	.5318	.4291	.575	.2976	.2894
22	.2542	3.6631	3.9999	2.3312	4.5168	.2875	.2572
23	.2412	3.5635	4.1055	2.4364	4.4227	.2549	.2265
24	.2389	1.912	3.5799	4.0947	4.0923	2.0935	.2199
Max	5.7739	5.8611	4.1055	4.0947	4.5168	4.193	6.089
Min	.2256	.2108	.213	.0671	.173	.1822	.2199
Avg	1.9725	2.2930	1.5030	1.4880	1.8209	1.3888	2.1127



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 204 / Kadegaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3205	.9488	.1478	.1294	.1294	.1463	1.9662
2	2.1879	.8539	.1463	.128	.0914	.1463	1.8623
3	2.0972	.8124	.1463	.128	.0905	.1494	1.7604
4	2.0317	.8223	.1478	.1267	.1097	.1494	1.7604
5	2.0317	.8223	.1848	.1448	.1294	.1886	1.7604
6	2.2542	.9922	.1886	.2012	.1509	.2075	2.1628
7	2.3205	1.0402	.1791	.2402	.1698	.2075	2.4863
8	.181	.197	.2149	.1663	.1494	.1267	.1791
9	.181	.1829	3.2861	2.9835	3.0521	1.5402	.1848
10	.1829	.128	3.1855		3.0996	1.4575	.181
11	.1478	.1109	2.7349		2.7846	1.4403	.1294
12	.1052	.0934	2.9504		2.7349	1.2803	.0848
13	.1075	.0943	2.7681		1.6129	3.0849	.1267
14	.128	.1848	1.6324		1.7394	3.219	.1267
15	.1029	.1848	1.4864		1.5586	2.8837	.1267
16	.1075	.1829	1.3916		1.2037	2.6825	.1267
17	.1372	.2195	.1772		.1753	.1402	.1433
18	.1928	.2172	.197		.1595	.1715	.1526
19	.2012	.2614	.2378		.197	.1772	.1578
20	.2012	.2614	.2195		.1791	.1791	.1629
21	.1848	.1867	.2054		.1791	.1402	.1734
22	2.3868	.1494	.1663		.1612	2.652	2.5724
23	2.42	.1448	.1494		.1433	2.6155	2.6825
24	2.3205	1.0242	.1478	.1494	.1494	.1463	2.3205
Max	2.42	1.0402	3.2861	2.9835	3.0996	3.219	2.6825
Min	.1029	.0934	.1463	.1267	.0905	.1267	.0848
Avg	1.0222	.4215	.9288	.4398	.8396	1.0472	.9746

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 206 / SHALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3142	.3696	.3018	.3142	.3326	.3658
2	.3326	.2957	.3326	.3174	.3109	.3326	.3658
3	.3361	.2987	.3361	.3174	.2957	.3326	.3658
4	.3361	.3142	.3361	.3395	.3292	.3326	.3658
5	.3734	.3361	.3734	.3547	.3658	.4108	.4024
6	.5228	.462	.5228	.4715	.4435	.4854	.5544
7	.4656	.4755	.4572	.5175	.4854	.4755	.543
8	.4656	.4656	.4344	.5014	.4481	.4477	.3898
9	.3814	.4298	.4207	.4572	.4066	.4207	.3544
10	.3506	.3681	.3467		.3734	.373	.3429
11	.3761	.3224	.2835		.3121	.3429	.298
12	.3582	.2926	.3395		.3467	.3467	.3561
13	.3292	.3696			.3258		.2835
14	.3045	.3856			.3258	.3155	.2835
15	.2804	.2561	.3045		.3391	.3189	.3189
16	.3224	.2835	.3224		.3391	.3544	.3366
17	.2915	.3353	.3185		.3772	.3429	.3506
18	.3772	.3772	.3521		.4557	.4115	.3688
19	.5194	.4961	.5194		.4961	.5373	.4908
20	.567	.5973	.567		.5121	.6154	.5973
21	.5415	.5544	.5415		.5175	.5853	.5304
22	.5175	.4805	.4715		.4805	.5121	.4024
23	.3921	.4066	.3921		.3326	.4435	.3696
24	.3734	.3292	.3696	.3174	.3326	.3326	.3658
Max	.567	.5973	.567	.5175	.5175	.6154	.5973
Min	.2804	.2561	.2835	.3018	.2957	.3155	.2835
Avg	.3936	.3853	.3960	.3896	.3861	.4088	.3918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 207 / 11 KV KHAMBALE-A AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.2362	3.7761	4.3993	4.3553	4.3918	.197
2	.0377	.2347	3.6077	4.2814	4.183	4.2699	.1776
3	.0377	.2336	3.375	4.2448	4.0516	4.0703	.1753
4	.0377	.2162	3.2236	4.2267	4.0238	3.9354	.1738
5	.0377	.2336	3.1931	3.9354	3.9894	3.7418	.1738
6	.1533	.301	3.5174	4.1888	4.2947	3.8668	.2443
7	.1623	.3224	3.677	4.6867	4.4067	4.2614	.3041
8	.3292	.9084	.2976	.2854	.2583	.2781	.8558
9	2.2061	6.1248	.2385	.2466	.2666	.2316	1.4594
10	2.5538	6.0456	.2024	.1311	.2221	.1745	
11	5.8608	6.0669	.2103	.1219	.2021	.1949	3.299
12	6.438	5.6958	.2389	.1143	.1981	.1738	3.2152
13	6.6422	5.2812	.2724	.1143	.217	.1745	6.3384
14	6.377	5.5733	.2724	.1189	.2079	.1987	6.4255
15	5.9564	5.2039	.2408	.1158	.2343	.2183	6.1621
16	5.6847	4.5791	.2435	.1151	.203	.2104	5.9608
17	.2172	.2321	.2293	.1113	.2008	.2195	.229
18	.1539	.2301	.2324	.1181	.2111	.2043	.2336
19	.294	.2686	.2704	.125	.2275	.1995	.2194
20	.3909	.3209	.3209	.1433	.2565	.2801	.2885
21	.3867	.6478	.6429	.5777	.6552	.2606	.2772
22	.3479	4.3132	5.0827	2.4478	5.0099	.2466	.277
23	.3208	1.5508	4.9652	2.8075	4.884	.204	.2504
24	.1848	2.1693	4.2196	4.7893	4.497	2.2923	.2101
Max	6.6422	6.1248	5.0827	4.7893	5.0099	4.3918	6.4255
Min	.0377	.2162	.2024	.1113	.1981	.1738	.1738
Avg	1.8687	2.3746	1.7729	1.7686	1.9690	1.4291	1.6151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 201 / 11 KV Tondoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6543	2.7199	.3361	.181	.2587	.3109	2.713
2	2.556	2.6379	.3361	.1848	.2801	.3109	2.6216
3	2.556	2.556	.3361	.1886		.3109	2.5286
4	2.5069	2.4741	.3361	.1886		.3109	2.5587
5	2.5069	2.4741	.3547	.2195		.3109	2.652
6	2.7349	2.6871	.462	.2507		.4119	2.5606
7	2.8509	2.9165	.499			.4207	
8	.3361	.3292	.3142	.2865		.2957	.2926
9	.3547	.2561				3.9872	
10	.2926	.2772	3.4252	3.4572		3.8321	.2218
11	.2743	.3142	3.2007	3.1786	3.746	3.5208	.2402
12	.2772	.2641	3.1878		3.5968		.2218
13	.3142	.3696	2.9172		.1109	2.8807	.2587
14		2.9384	2.9504		3.7294	3.0849	.2772
15	.3511	.3511	2.6825		3.7792	3.152	.2218
16	.3326	.4251	2.2862		3.4476	2.9172	.2378
17	.3881		.1509		.2926	.2561	.2561
18	.4251	.4435			.3511	.3224	.2743
19	.4251	.4805			.3511	.3582	.3696
20	.3881	.462			.3696		.3326
21	.3326	.4108	.4435		.3881		.3142
22	3.0333	.3734	.3326		.3696	2.9492	2.9001
23	2.9835	.3361	.2926		.3361	3.103	2.8012
24	2.8178	2.8182	.3547	.2218		.3361	2.6216
Max	3.0333	2.9384	3.4252	3.4572	3.7792	3.9872	2.9001
Min	.2743	.2561	.1509	.181	.1109	.2561	.2218
Avg	1.3779	1.2746	1.2599	.8357	1.4271	1.5897	1.2489

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 202 / 11 KV Raigaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.0732	2.6355	2.8807	2.7526	2.9504	.0724
2	.112	.0554	2.4863	2.9492	2.6379	2.8178	.0754
3	.112	.0732	2.4531	3.0178		2.7349	.0739
4	.112	.0924	2.4034	2.6558		2.7349	.0914
5	.112	.0924	2.4034	2.6452		2.5692	.112
6	.1307	.0732	2.5692	2.3868		2.7161	.1433
7	.1494	.0914	2.536			2.9508	.1829
8	.1494	.1097	.1494	.1132		.1494	.1509
9	2.9675	2.6707	.1848			.112	
10	3.0967	3.1161	.1132	.1448	.1463	.1132	2.982
11	3.3425	3.1659	.0924	.128	.112	.0739	3.1459
12	2.8182	3.0333	.0943		.1109		3.0967
13	3.1459	3.0498	.0914		.1109	.0914	3.0967
14	3.2114	2.6852	.0943		.1109	.0895	3.195
15	3.0476	2.8344	.0924		.0924	.0739	3.0148
16	2.6871	2.6686	.0943		.0924	.0754	2.6379
17	.0914		.0924		.1294	.1109	.0983
18	.128	.168			.1509	.1448	.0983
19	.128	.1663			.132	.1478	.1147
20	.1463	.1478			.132		.1311
21	.128	.1478	.0924		.132		.1294
22	.1097	3.2819	3.12		3.1824	.1075	.1109
23	.1097	3.2322	3.2769		3.2156	.0739	.0924
24	.1307	.0914	2.9007	3.12		3.0664	.0732
Max	3.3425	3.2819	3.2769	3.12	3.2156	3.0664	3.195
Min	.0914	.0554	.0914	.1132	.0924	.0739	.0724
Avg	1.0957	1.3531	1.3322	2.0042	.8275	1.1383	.9965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 203 / SOHOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.5304	.5788	.4527	.6099	.5601	.5014
2	.5601	.5175	.5788	.439	.567	.5601	.5228
3	.5601	.5304	.5601	.4435		.5415	.4961
4	.5788	.5175	.5788	.4805		.5601	.5853
5	.5975	.5544	.5975	.5487			.679
6	.7947	.7316	.7468	.6154		.8029	.724
7	.8316	.823	.7842			.9709	.7762
8	.5544	.6401	.6348	.6089		.5975	.5373
9	.6219	.4805	.5975			.6348	
10	.5487	.5601	.4656	.5544	.5729	.6413	.4572
11	.5068	.5792	.5175	.6468	.5487	.5914	.5729
12	.5373	.6036	.5658				.6838
13	.5611	.5853	.5487		.5853	.5914	.7392
14	.5487	.6219	.6036		.5853	.6089	.7207
15	.6584	.5853	.5121		.5487	.6722	.5175
16	.6036	.6154	.5601		.567	.6268	.6099
17	.6099	.5853	.6089		.5914	.6516	.6468
18	.6283	.5853			.6838	.7468	.695
19	.7316	.8048			.7947	.8413	.8048
20	.8131	.8131					1.0164
21	.7762	.7207	.8299		.8131		.8686
22	.6653	.6653	.7164		.7392	.7316	.7392
23	.5729	.4805	.6283		.6283	.6036	.7392
24	.5788	.5544	.5914	.5014		.5914	.5544
Max	.8316	.823	.8299	.6468	.8131	.9709	1.0164
Min	.5068	.4805	.4656	.439	.5487	.5415	.4572
Avg	.6258	.6119	.6098	.5291	.6311	.6563	.6603

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 204 / 11 KV UPALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.683	5.1646	.2286	.2531	.2191	.3292	5.2499
2	4.5374	4.8522	.2283	.2545	.2027	.33	5.0304
3	4.494	4.6567	.2283	.2595	.1334	.3308	4.9992
4	4.5363	4.5267	.2252	.2489	.128	.3269	4.8785
5	4.6041	4.6247	.2321	.3064	.1501	.3557	5.0053
6	4.936	4.8209	.1471	.3829	.1974	.478	5.128
7	5.3261	5.1631	.4778	.2591	.2507	.4845	5.1646
8	.3959	.3563	1.0145	.4487	.346	1.1538	.438
9	.3483	.3411	5.4816	2.649	1.6179	6.0585	.1859
10	.3163	.3437	6.4472	5.2573	5.7928	6.0849	.2709
11	.274	.3216	6.6427	5.4519	6.1942	6.2152	.301
12	.3205	.2949	6.5017	1.9685	4.6571	3.3829	.2907
13	.2911	.2991	6.124		5.3342	5.8794	.3102
14	.2957	.2705	6.1035		5.9221	5.8116	.3071
15	.3274	.3086	5.9		6.0168	5.6951	.2965
16	.3178	.3132	5.6905	1.8458	5.5974	5.5643	.3266
17	.3764	.3224	.3064	.2301	.325	.3558	.317
18	.3449	.3597	.1882	.2279	.4375	.3696	.3258
19	.3806	.4194	.1989	.2195	.5052	.4786	.3982
20	.4382	.4407	.2309	.2561	.5157	.2683	.4195
21	.8474	.4415	.4275	.2332	.4916	.7636	.9731
22	5.5769	.3794	.3789	.2073	.4399	5.8178	6.1839
23	5.6302	.2804	.3346	.1578	.3733	5.6668	6.1195
24	5.1048	2.5628	.2797	.2736	.1844	3.1268	5.5944
Max	5.6302	5.1646	6.6427	5.4519	6.1942	6.2152	6.1839
Min	.274	.2705	.1471	.1578	.128	.2683	.1859
Avg	2.2793	1.7443	2.2508	1.0186	1.9180	2.7220	2.4381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 205 / 11 KV BOMBALEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.0655		2.2043	1.9498	1.8842	.0924
2	.0934	.0655		2.1795	1.8842	1.8351	.0905
3	.0934	.0655		2.13		1.8023	.0943
4	.0934	.0819		2.0972		1.7695	.0914
5	.0934	.0983		2.1704		1.7695	.112
6	.1307	.1147		2.0222		1.8399	.1294
7	.1595	.1638	.0312			1.7404	.1433
8	.1254	.1311		.1254		.168	.1267
9	2.6658	2.5724				.1307	
10	2.8018	2.5029		.0983	.0819	.1075	2.8673
11	2.6707	2.4478			.1132	.1132	2.6871
12	2.556	2.3371			.1132		2.5232
13	2.4086	2.2874			.132	.132	2.6052
14	2.2283	2.1051	.1294		.1294	.1267	2.5396
15	2.3102	2.1051	.1254		.1478	.1494	2.2939
16	2.13	1.8623	.132		.1848	.1509	2.2119
17	.0983		.1294		.1254	.1433	.1147
18	.1311	.1463			.1612	.1448	.1311
19	.1311	.1294			.1646	.1509	.1311
20	.1475	.1663			.168		.1475
21	.1311	.1663	.1509		.168		.1147
22	.1311	1.8399	2.5434		2.2874	.1132	.1147
23	.0983	.0554	2.2405		2.2377	.0895	.0819
24	.1097	.0819		2.2211		1.9826	.0895
Max	2.8018	2.5724	2.5434	2.2211	2.2874	1.9826	2.8673
Min	.0934	.0554	.0312	.0983	.0819	.0895	.0819
Avg	.9021	.9388	.6853	1.6943	.6280	.7783	.8493



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 206 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.5175	.679	.7316	.5544	.3206	.4904
2	.679	.5544	.7356	.724	.5914	.3206	.4656
3	.679	.5914	.7356	.7468		.415	.4854
4	.679	.6653	.7356	.7522		.6413	.5487
5	.679	.6653	.9242	.8676		.6413	.6653
6	.4338	.6838	.4715	.8779		.5281	.695
7	.8676	.9979	.7167			.8962	.7343
8	.7356	.499	.7167			.7095	.7167
9	.7733	.7392	.9619			.8215	
10	.7392	.9795	.7733	.7762	.7655	.7701	.7947
11	.6653	.7282	.7468	.7392	.8402	.7682	.7392
12	.7023	.7095	.7545		.7545		.7207
13	.7207	.6908	.9054		.7545	.7316	.9795
14	.7207	.7468	.9313		.7655	.7164	.924
15	.7207	.7282	.7545		.7545	.5175	.7207
16	.2772	.0122	.1848		.0152	.1886	.3142
Max	.8676	.9979	.9619	.8779	.8402	.8962	.9795
Min	.2772	.0122	.1848	.724	.0152	.1886	.3142
Avg	.6696	.6568	.7330	.7769	.6440	.5991	.6663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 201 / 11 KV WANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.8023	.181	.128	.1433	.0983	1.7004
2	1.9433	1.8399	.1646	.1296	.1052	.1147	1.6876
3	1.8842	1.757	.1829	.1457	.1052	.1147	1.6194
4	1.8785	1.6575	.1448	.1457	.1052	.0983	1.5546
5	1.8351	1.7368	.1829	.1387	.1433	.1296	1.5565
6	1.8623	1.8187	.2378	.2126	.2149	.1638	1.6712
7	1.9334	1.9433	.2402	.2126	.2629	.2458	1.8461
8	.1492	.2012	.2172	2.5396	.1578	.1638	.1829
9	.1475	.1646	2.4531	2.5396	2.769	2.3365	.1463
10	.1543	.1433	2.2939	2.5857	2.6406	2.5069	.1646
11	.1402	.1433	2.343	2.42	2.5446	2.4413	.1696
12	.1372	.1646	2.3102		2.4905	2.4413	.1357
13	.1387	.1867	2.343		2.2405	2.2672	.1526
14	.1402	.1646	2.0809		2.2447	2.0972	.1029
15	.1402	.1646	2.1792		2.0317	2.0405	.12
16	.1753	1.5927	2.13		2.0965	2.0243	.1658
17		.2195	.1113		.1475	.1638	.1696
18	.1791	.2012	.1311		.1475	.1802	.1509
19	.1886	.2012	.156		.1475	.1619	.1677
20	.1791	.1867	.1387		.1677	.1475	.1696
21	.1612	.1829	.156		.1311	.1475	.1526
22	2.0885	.1463	.144		.1341		1.9204
23	2.0809	.1463	.144		.1147	1.8515	1.9498
24	2.0243	1.9662	.1629	.128	.1433	2.3365	1.7532
Max	2.0885	1.9662	2.4531	2.5857	2.769	2.5069	1.9498
Min	.1372	.1433	.1113	.128	.1052	.0983	.1029
Avg	.9350	.7805	.8679	.9438	.8929	1.0554	.8088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 202 / 11 KV TADSAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4115	2.1839	2.5553	2.4989	2.2962	.5457
2	.4515	.4268	2.0531	2.2634	2.3365	2.1712	.5357
3	.4664	.4192	1.9806	2.2173	2.1925	2.0622	.5586
4	.4801	.3887	1.9757	2.1601	2.2017	2.0424	.5739
5	.5033	.431	2.0133	2.2371	2.1883	2.0096	.5891
6	.5472	.4946	2.3064	2.4059	2.4638	2.3404	.7038
7	.541	.623	2.3628	3.0262	3.0354	2.8079	.7194
8	.5247	.6234	.6965	.8817	.9038	.7042	.5494
9	3.4203	2.7328	.5517	.683	.6558	.53	2.0363
10	3.3128	.9892	.6117	.6095	.6447	.5624	3.8988
11	3.328	.0312	.5904	.6087	.6204	.5525	3.9183
12	3.1321	3.3927	.582	.615	.5952	.6001	3.8173
13	2.9417	3.5003	.2957	.6287	.5754	.5906	3.5345
14	2.8456	3.088		.3559	.5281	.5955	3.4911
15	2.8388	3.2632		.3475	.5483	.5251	3.3395
16	2.7485	3.0422	.3805	.3513	.5819	.6455	3.2709
17	.346	.7232	.653	.3513	.7065	.7095	.6554
18	1.4289	.7209	.4161	.3064	.4001	.7392	.5701
19	.6882	.7735	.7198	.3521	.6706	.7834	.6477
20	.7445	.7484	.7173	.3871	.7171	.748	.7076
21	.8505	.6851	.6927	.3536	.6954	.7396	.6782
22	.7869	2.3479	2.6231	1.8061	3.2385	.4512	.6127
23	.5007	2.4196	2.7588	1.8435	2.9447	.583	.5503
24	.4222	1.4525	2.8612	2.5294	2.5171	1.4121	.5205
Max	3.4203	3.5003	2.8612	3.0262	3.2385	2.8079	3.9183
Min	.346	.0312	.2957	.3064	.4001	.4512	.5205
Avg	1.4287	1.4054	1.3648	1.2448	1.4359	1.1334	1.5427

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 203 / 11 KV YERALA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1307	.7449	.8025	.7468	.7537	.0724
2	.1097	.1097	.7287	.8025	.7562	.6882	.0732
3	.1267	.1463	.7125	.8025	.7042	.6882	.0924
4	.1294	.128	.7202	.7968	.6874	.6401	.0739
5	.1294	.1494	.7042	.7773	.7186	.6882	.0914
6	.1646	.168	.7611	.8322	.7253	.7499	.1097
7	.1829	.168	.8421	.8802	.828	.8322	.1646
8	.1307	.1463	.1463	.144	.1187	.144	.1267
9	.1086	.9012	.1494	.128	.112	.1311	1.0486
10	1.1203	.9282	.1254	.1433	.1372	.0983	1.0202
11	1.1385	.9503	.1254	.1433	.128	.0819	1.0322
12	1.0911	.9503	.1254	.1433	.1254	.0829	1.1437
13	1.1203	1.0486	.1267	.1254	.096	.0983	1.065
14	1.0911	.9717	.128		.1254	.1147	.9614
15	1.0753	.9339	.1086		.1097	.1134	.9339
16	1.0562	.9555	.1267		.1433	.1147	.9339
17	.1147	.1267	.128		.1372	.0972	.1475
18	.12	.1097	.1448			.1147	.1677
19	.1543	.1463	.1867		.1402	.1475	.1865
20	.1715	.1463	.168		.197	.1629	.1715
21	.1612	.128	.168		.1463	.1629	.1526
22	.1463	.8192			.8356	.1029	.1372
23	.128	.7935	.8025		.9012	.0905	.1307
24	.1086	.128	.7537	.8025	.8179	.8421	.0732
Max	1.1385	1.0486	.8421	.8802	.9012	.8421	1.1437
Min	.1086	.1097	.1086	.1254	.096	.0819	.0724
Avg	.4162	.4660	.3794	.5231	.4103	.3225	.4213

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 204 / 11 KV AMBAK AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029	.7202	.0724	.08	.0983	.0819	.583
2	.7449	.7202	.0732	.08	.08	.0819	.5668
3	.7449	.6401	.0914	.08	.08	.0819	.5668
4	.7611	.6241	.0905	.08	.096	.0983	.5668
5	.7125	.6081	.0732	.08	.112	.096	.5571
6	.7537	.6882	.0914	.08	.1147	.096	.639
7	.8684	.8029	.1267	.08	.128	.0983	.7125
8	.1134	.0819	.1307	.096	.1147	.0819	.0914
9	.112	.1147	1.1069	.9442	1.2452	1.0978	.0905
10	.096	.112	1.1043	1.094	1.2643	1.1633	.0819
11	.096	.0983	.144	1.0402	.9995	.9779	.096
12	.096	.081	1.0402		1.1633	.9779	.096
13	.112	.0655	.9922		.9831	.9069	.0819
14	.112		.9762		.9122	.8684	.0819
15	.096	1.3717	.8802		.9339	.8097	.0819
16	.112	.1086	.8802		.9012	.8356	.0819
17	.1147	.1097	.144		.0819	.1134	.0819
18	.1147	.128	.096		.0983	.0983	.0819
19	.1147	.128	.096		.1147	.1086	.0983
20	.1147	.128	.096		.1311	.1086	.1147
21	.096	.128	.096		.116	.0983	.1147
22	.8848	.1097	.08		.0983	.6882	1.0159
23	.852	.0732	.08		.0983	.6478	.9995
24	.852	.8002	.0732	.08	.0983	.0983	.5992
Max	.8848	1.3717	1.1069	1.094	1.2643	1.1633	1.0159
Min	.096	.0655	.0724	.08	.08	.0819	.0819
Avg	.3949	.3671	.3598	.3179	.4193	.4298	.3367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 205 / 11 KV HINGANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / INCOMING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4258	.3985	1.9033	2.3602	2.1498	2.1426	.2735
2	.4077	.3658	1.89	2.303	1.938	2.0531	.274
3	.4348	.3666	1.8835	2.2535	1.9052	1.9707	.2679
4	.4422	.4119	1.8763	2.0934	1.8617	1.9173	.2636
5	.4923	.4607	1.9567	2.2771	1.8899	1.9468	.2519
6	.6012	.5495	2.1302	2.3579	2.0705	2.1144	.3155
7	.6195	.5674	2.3117	2.5042	2.4344	2.4082	.4344
8	.5136	.4618	.3483	.3886	.3147	.3342	.4068
9	3.3791	3.3219	.354	.3223	.285	.2705	3.1862
10	3.6054	3.171	.3124	.3246	.2965	.2957	3.472
11	3.5841	3.4195	.1852	.3284	.2866	.2664	3.4713
12	3.2708	3.4362	.3292	.3558	.3041	.2625	3.3242
13	3.1196		.3353	.1791	.2858	.29	3.0259
14	1.5417	2.8155	.3139	.1799	.3182	.3026	2.7328
15	.0038	2.937	.2819	.1882	.3274	.3087	2.6616
16	2.7199	2.7843	.304	.2073	.3631	.3362	2.5236
17	.0213	.4368	.3444	.221	.3642	.3231	.3026
18	.5095	.4321	.2979	.2187	.3749	.3254	.3239
19	.6203	.4504	.2819	.202	.3467	.3345	.3745
20	.6044	.4717	.397	.2309	.4035	.4138	.4081
21	.5815	.5556	.3825	.2362	.3738	.4477	.3795
22	.5213	2.1636	2.5515	1.4007	2.6989	.362	.3216
23	.4549	2.0942	2.6048	1.4396	2.4383	.357	.2885
24	.4359	1.2605	2.2487	1.4708	2.2862	1.2201	.2957
Max	3.6054	3.4362	2.6048	2.5042	2.6989	2.4082	3.472
Min	.0038	.3658	.1852	.1791	.285	.2625	.2519
Avg	1.2046	1.4492	1.0760	1.0018	1.0966	.8751	1.2325

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 206 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.6393	.6195	.622	.5746	.5228	.5752
2	.6398	.6325	.6096	.6144	.5654	.5167	.5845
3	.6554	.5403	.5894	.6213	.5167	.5445	.5829
4	.6504	.5224	.6081	.6236	.5571	.5723	.5673
5	.7133	.5734	.6817	.6258	.5826	.6234	.6307
6	1.0067	.9678	.9389	.8434	.9072	.94	.8672
7	1.1188	1.0871	1.0535	.9842	1.1069	1.0417	1.0425
8	1.0803	.9423	.9435	.9533	.9423	.9301	.8769
9	.7099	.708	.7018	.7774	.6637	.7488	.6809
10	.689	.6256	.6679	.6426	.5856	.665	.6714
11	.6233	.5704	.6872	.5445	.5525	.618	.5834
12	.6516	.578	.5405	.538	.514	.5296	.5997
13	.6977	.6261	.6281	.5422	.514	.548	.6185
14	.6821	.6429	.615	.2721	.5456	.5559	.5734
15	.623	.649	.5722	.2804	.5784	.4847	.5056
16	.6175	.6413	.5821	.2843	.6063	.3523	.5266
17	.7171	.6612	.6226	.3048	.5971	.6112	.6387
18	.727	.7335	.6297	.3582	.6966	.7187	.7301
19	.8939	.8745	.7968	.4199	.9053	.8251	.8181
20	1.1012	.9922	.9865	.4931	.5632	.9719	1.0021
21	1.0052	.9575	.9835	.4862	.554	.7437	1.0192
22	.94	.828	.9739	.4481	.8878	.884	.8833
23	.82	.7381	.7386	.423	.7301	.7431	.7461
24	.6711	.6722	.6487	.6464	.6421	.586	.6226
Max	1.1188	1.0871	1.0535	.9842	1.1069	1.0417	1.0425
Min	.6175	.5224	.5405	.2721	.514	.3523	.5056
Avg	.7776	.7252	.7258	.5562	.6620	.6782	.7061

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 201 / 11KV BHIKWADI-KH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3734	.415	.3881	.3772	.3696	.3772
2	.3734	.3326	.3772	.3881	.3547	.3547	.3734
3	.3734	.3658	.3772	.3881	.3734	.3584	.3772
4	.3734	.4108	.3772	.3881	.3734	.4108	.3772
5	.4668	.4904	.415	.3881	.4527	.4668	.3772
6	.5601	.5975	.5093	.3881	.5093	.5228	.547
7	.5993	.6283	.6224	.0554	.6413	.5601	.5847
8	.4668	.5611	.5304	.4805	.5359	.4854	.5544
9	.5611	.5175	.5788	.3881	.5552	.462	.5788
10	.5415	.4835	.5316	.4251	.5316	.4854	.2743
11	.6653	.4706	.567	.5194	.543	.5373	.5975
12	.6161	.4938	.4755	.6036	.5175	.4108	.6348
13	.4668	.3982	.4805		.462	.4207	.4108
14	.4481	.4572	.499		.3921	.3961	.4108
15	.5359	.4435	.5185		.4108	.543	.3921
16	.5041	.4854	.4805		.4294	.6036	.4854
17	.7282	.4344	.499		.5041	.6135	.6161
18	.5729	.5552	.6468		.5359	.6068	.6161
19	.7282	.6154	.6468		.6099	.6984	.8029
20	.7655	.7356	.6653		.7095	.7947	.7207
21	.679	.7356	.5729		.5601	.6535	.6653
22	.5359	.6348	.5544	.5847	.5415	.5658	.5544
23	.4854	.5041	.462	.4527	.4527	.4715	.4251
24	.4108	.4294	.4527	.3881	.3961	.3772	.3961
Max	.7655	.7356	.6653	.6036	.7095	.7947	.8029
Min	.3734	.3326	.3772	.0554	.3547	.3547	.2743
Avg	.5362	.5064	.5106	.4151	.4904	.5070	.5062



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 202 / 11 KV NEWARI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1795	1.6108	.168	.1629	.1307	.1448	1.2003
2	1.9281	1.5432	.132	.1629	.132	.1463	1.2146
3	1.9281	1.5424	.132	.1629	.132	.1267	1.2125
4	1.8442	1.5384	.132	.1629	.1294	.1254	1.2125
5	1.6766	1.4752	.132	.1629	.1307	.1478	1.2963
6	1.6766	1.6118	.168	.1629	.1698	.1663	1.3923
7	1.7269	1.5089	.168	.1663	.1867	.181	1.4413
8	.1595	.1629	.1646	.1753	.1629	.1646	.1612
9	.1595	.1791	2.6852	2.8349	2.8012	2.9864	.1848
10	.1595	.1663	2.7183	2.713	2.7681	2.8654	.1646
11	.1254	.168	2.5692	2.42	2.6621	2.4697	.1463
12	.1629	.1848	2.4863		2.4863	2.2377	.1448
13	.1629	.1848	2.4863		2.3537	2.1714	.1448
14	.1612	.1663	2.4863		2.3472	2.1382	.1448
15	.1629	.1294	2.3205		2.0719	2.0719	.1448
16	.1433	.1294	2.2708		1.9334	1.873	.1448
17	.1629	.1663	.1086		.1612	.1463	.0905
18	.1629	.1629	.1448		.1629	.1578	.1448
19	.1646	.1629	.1629		.1612	.1475	.1629
20	.1629	.1698	.181		.1829	.1663	.1646
21	.1829	.1886	.181	.1848	.181	.1612	.1646
22	2.0957	.1867	.1629	.1791	.1791	1.5061	1.8945
23	1.9161	.1867	.1457	.168	.1629	1.3927	1.9281
24	1.8442	1.643	.168	.1457	.168	.1646	1.2323
Max	2.1795	1.643	2.7183	2.8349	2.8012	2.9864	1.9281
Min	.1254	.1294	.1086	.1457	.1294	.1254	.0905
Avg	.8771	.6320	.9364	.6643	.9149	.9941	.6722

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 203 / 11 KV DHANEWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1629	1.6078	1.8442	1.989	2.191	.1646
2	.1629	.1629	1.5746	1.8442	1.9616	2.1491	.1629
3	.168	.1646	1.5565	1.8442	1.9448	2.0233	.1646
4	.181	.1646	1.5565	1.8442	1.9062	1.9719	.1629
5	.181	.1829	1.6221	1.8442	1.989	2.0576	.1848
6	.181	.2172	1.6741	1.8778	2.0222	2.0687	.1848
7	.1991	.2454	1.9227	2.0119	2.2131	2.1026	.2614
8	.1991	.181	.1629	.1755	.1734	.181	.1791
9	2.9508	2.6981	.1595	.1753	.1791	.1791	2.6658
10	3.0178	2.6155	.1629	.1753	.1578	.1629	2.6658
11	2.8016	2.7161	.1216	.1734	.1629	.1595	2.7664
12	2.8018	2.6155	.1629	.1543	.1646	.1612	2.8837
13	2.7368	2.4981	.1629		.1629	.156	2.8669
14	2.769	2.4478	.1629		.181	.1696	2.8534
15	2.8502	2.304	.1629		.1629	.1578	2.8837
16	2.4981	2.3304	.1629		.1646	.1595	2.8502
17	.1629	.1734	.181		.1791	.1734	.1174
18	.1791	.1696	.1629		.1629	.1638	.1612
19	.1629	.1991	.1629		.2378	.2507	.1448
20	.2378	.2587	.181		.2534	.2772	.1991
21	.1867	.2195	.1991	.2561	.1829	.2012	.1991
22	.181	1.9227	2.0814	2.1956	2.3061	.2012	.1629
23	.1612	1.8067	2.0814	2.1628	2.2805	.1646	.1629
24	.1457	.1629	1.6409	1.9909	2.0388	2.2291	.181
Max	3.0178	2.7161	2.0814	2.1956	2.3061	2.2291	2.8837
Min	.1457	.1629	.1216	.1543	.1578	.156	.1174
Avg	1.0533	1.1092	.8178	1.2856	.9657	.8213	1.0512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 204 / 11 KV YETGAON AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.243	.1976	2.8578	3.4701	3.208	3.4402	.1947
2	.2437	.1806	2.7318	3.3657	3.1064	3.2922	.1909
3	.2768	.166	2.7105	3.3192	2.9532	3.0506	.1878
4	.2745	.1652	2.7516	3.3131	2.8726	3.03	.1848
5	.2844	.2014	2.9639	3.3192	2.8856	3.1166	.1981
6	.1661	.2513	3.2777	3.4693	2.9961	3.315	.2706
7	.3251	.3049	3.5597	3.1223	3.5336	3.4941	.3182
8	.5958	.3152	.2765	.3155	.2795	.2864	.5263
9	4.7924	4.641	.2199	.255	.2445	.223	4.7992
10	5.0498	4.8032	.2161	.2245	.2468	.2492	5.4596
11	4.9711	4.8741	.1753	.2199	.2359	.2412	5.1132
12	4.7207	4.6601	.1951	.2229	.2207	.2435	5.2831
13	4.6039	4.4494	.1882	.1311	.2488	.2534	4.9051
14	4.4876	4.2168	.1852	.1364	.2557	.2473	4.7857
15	4.4852	4.2042	.1898	.1288	.298	.2488	4.7666
16	4.296	4.1238	.1867	.1196	.3271	.2625	4.9913
17	.2344	.2184	.1982	.1326	.3006	.2919	.1822
18	.2271	.243	.202	.1265	.2359	.2625	.2222
19	.2729	.2637	.2683	.1471	.2767	.2889	.2675
20	.3555	.3555	.3071	.2035	.3797	.3822	.3486
21	.3578	.69	.6159	.6245	.4805	.3597	.3532
22	.3079	3.2791	3.9871	3.6321	3.7242	.338	.2965
23	.242	3.2591	3.7182	3.5103	3.9893	.2717	.242
24	.2361	1.7688	2.0744	3.3825	3.5262	1.8515	.2179
Max	5.0498	4.8741	3.9871	3.6321	3.9893	3.4941	5.4596
Min	.1661	.1652	.1753	.1196	.2207	.223	.1822
Avg	1.7521	1.9930	1.4190	1.5372	1.5344	1.2100	1.8461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 206 / 11 KV YERALA AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.6385	.0324	.0324	.0324	.0339	1.5074
2	1.4899	1.326	.0324	.0324	.0324	.0332	1.4746
3	1.4899	1.2944	.0325	.0324	.0324	.0335	1.3927
4	1.4575	1.278	.0324	.0324	.0324	.0332	1.3435
5	1.4575	1.2631	.0324	.0324	.0324	.0335	1.3272
6	1.4413	1.326	.0324	.0324	.0324	.0497	1.3272
7	1.6032	1.3435	.0486	.0324	.0486	.0514	1.3599
8	.0486	.0324	.0324	.0489	.0486	.0514	.0655
9	.0486	.048	2.0729	2.0405	2.3158	2.3167	.0655
10	.0486	.0486	2.251	2.1214	2.0891	2.0481	.0492
11	.048	.0324	1.7535	2.1376	2.1052	2.2119	.0486
12	.0648	.0486	2.2348		2.0243	2.0317	.0486
13	.0648	.0324	2.1538		2.0243	2.0481	.0486
14	.0819	.0486	2.1052		2.0972	1.9498	.0486
15	.0655	.0324	2.1077		2.0481	1.8023	.0486
16	.0648	.0324	2.0243		1.9919	1.7532	.0486
17	.0648	.0324	.0324		.0324	.0492	.0486
18	.0648	.0486	.0486		.1638	.0492	.0486
19	.0486	.0486	.0486		.0492	.0655	.081
20	.0486	.0486	.0486		.0497	.0655	.081
21	.0486	.0486	.0486		.0497	.0655	.0648
22	1.7652	.0486	.0324	.0486	.0335	1.5729	1.8461
23	1.7695	.0324	.0324	.0486	.0373	1.6385	1.9433
24	1.6404	1.7166	.0324	.0324	.0324	.0373	1.5729
Max	1.7695	1.7166	2.251	2.1376	2.3158	2.3167	1.9433
Min	.048	.0324	.0324	.0324	.0324	.0332	.0486
Avg	.6894	.4937	.7209	.4789	.7265	.8344	.6621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 201 / 11 KV VITA(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1154	3.1299	3.0362	3.0952	2.7306	3.107	3.0971
2	2.9851	2.905	2.8799	2.9645	2.6131	2.8974	2.9744
3	2.9317	2.8006	2.7092	2.9042	2.5495	2.7831	2.9004
4	2.8463	2.8623	2.7043	2.8357	2.5251	2.6718	2.8136
5	2.9363	2.8692	2.7782	2.7518	2.4753	2.7122	2.8555
6	3.0243	2.8661	2.9218	2.7046	2.6437	2.8151	2.8578
7	3.1116	2.8882	3.0392	2.7747	2.8448	3.0301	3.0788
8	3.0811	2.9805	2.9561	2.5735	2.7983	3.0529	2.9362
9	3.1035	3.027	2.9287	2.4965	2.9481	2.8166	3.1012
10	3.3733	3.264	3.272	2.7183	3.408	3.3158	3.3997
11	3.8317	3.4766	3.2366	2.8722	3.6191	3.5399	3.7762
12	3.7769	3.3631	3.4054	1.5089	3.6622	3.5864	3.6634
13	1.0052	3.0689	3.4213	1.4464	3.3402	3.392	3.3238
14	1.4529	3.2697	3.6119	1.4388	3.5795	3.6401	3.6862
15	4.0207	3.408	3.7818	1.4662	3.8416	3.7959	3.7856
16	4.0672	3.4286	3.7711	1.483	3.719	3.7632	3.9735
17	4.1666	3.5551	3.7914	1.4883	3.8196	3.8477	3.8668
18	3.9568	3.5292	3.7144	1.4678	3.7605	3.9094	3.9727
19	4.1502	3.9735	4.2048	1.7223	4.1221	4.228	4.1465
20	4.3095	4.0642	4.4997	1.9776	4.4787	4.5625	4.5488
21	3.7868	3.8013	4.0996	1.8785	3.9179	4.1069	4.1594
22	3.5353	3.5208	3.6572	1.7574	3.6199	3.6626	3.69
23	3.4461	3.4683	3.6489	1.6598	3.5064	3.5605	3.5323
24	3.3357	3.3151	3.9312	3.0956	3.0171	3.3014	3.304
Max	4.3095	4.0642	4.4997	3.0956	4.4787	4.5625	4.5488
Min	1.0052	2.8006	2.7043	1.4388	2.4753	2.6718	2.8136
Avg	3.3063	3.2848	3.4167	2.2117	3.3142	3.4208	3.4768

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 202 / 11 KV LENGARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.649	2.9188	2.7489	2.7534	1.9258	2.6474	2.7302
2	2.7252	2.9858	2.8631	2.7858	1.8275	2.7983	3.0506
3	2.6978	2.7884	2.6452	2.7218	1.8153	2.7625	3.0171
4	2.5103	2.6154	2.6059	2.7961	1.7604	2.6733	2.8997
5	2.537	2.6215	2.5667	2.4329	1.7475	2.4668	2.7015
6	2.4474	2.5801	2.4665	2.2066	1.7878	2.4143	2.5823
7	2.5888	2.556	2.697	1.9906	1.8053	2.6658	2.7039
8	2.7698	2.9424	2.9614	1.8884	2.4181	2.9332	3.0555
9	3.142	3.3341	3.3539	1.8496	2.8979	3.296	3.3676
10	3.6206	3.6702	3.618	1.7779	3.312	3.5825	3.7227
11	3.8356	3.8577	3.9003	1.7734	3.5993	3.4309	3.9765
12	3.658	3.4751	3.5208	.8871	3.3127	3.4332	3.4995
13	2.5793	2.5004	2.6368	.3064	2.4127	2.5488	2.7762
14	3.5449	2.9984	3.6172		3.4168	3.5887	3.7201
15	3.7799	3.6226	3.7582		3.6488	3.7174	4.0615
16	3.5266	3.6565	3.562	.9998	3.4697	3.6512	3.8012
17	3.3379	3.4073	3.256	.9968	3.344	3.485	3.5193
18	3.323	3.2998	3.1299	.9496	3.2937	3.4972	3.485
19	3.3227	3.2937	3.2979	.9244	3.3105	3.4541	3.4713
20	3.3319	3.264	3.3189	1.086	3.3509	3.4362	3.467
21	2.6756	2.7336	2.793	1.0669	2.7587	2.8806	2.8646
22	3.0392	3.0209	3.0925	1.0608	2.8639	3.136	3.307
23	3.3177	3.3821	3.4637	1.1279	3.3547	3.5116	3.5295
24	3.12	3.384	3.1474	2.4722	2.6383	3.2968	3.1756
Max	3.8356	3.8577	3.9003	2.7961	3.6488	3.7174	4.0615
Min	2.4474	2.5004	2.4665	.3064	1.7475	2.4143	2.5823
Avg	3.0867	3.1212	3.1259	1.6752	2.7530	3.1378	3.2702

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 203 / 11 KV BHALWANI(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0439	2.0089	2.0706	2.0264	1.6743	2.0554	2.127
2	2.0203	1.983	1.9944	1.9581	1.6407	1.6423	2.0275
3	1.9833	1.9311	1.9646	1.9097	1.6225	1.813	2.021
4	1.9707	1.9029	1.9708	1.8377	1.5307	1.6781	1.8675
5	1.989	1.9372	1.9456	1.7764	1.5006	1.6179	1.9273
6	1.9989	1.9997	1.9669	1.8126	1.608	1.8229	1.9715
7	1.9799	1.9898	2.1121	1.8244	1.8137	2.1361	2.1993
8	2.0446	2.1818	2.0873	1.6941	2.1414	2.1842	2.2832
9	2.1453	2.335	2.1239	1.9185	2.4592	2.3259	2.5271
10	2.4455	2.4744	2.2249	1.8538	2.5842	2.4394	2.8022
11	2.5633	2.6216	2.3121	1.7726	2.6826	2.4821	2.6002
12	2.5865	2.572	2.2115	1.0044	2.4958	2.4086	2.5191
13	2.1186	2.1281	1.9257	.9587	2.2527	2.098	2.1438
14	2.2626	2.2207	2.0104	.964	2.2196	2.1918	2.1903
15	2.3914	2.3827	2.0596	.9191	2.4212	2.3679	2.332
16	2.5194	2.5888	2.1362	1.0014	2.6654	2.6109	2.4977
17	2.6048	2.5781	2.2028	1.0593	2.6131	2.6559	2.6582
18	2.4951	2.5218	2.1472	1.041	2.5087	2.6886	2.5628
19	2.582	2.3914	2.2436	.9137	2.1456	2.7405	2.5431
20	2.6227	2.4592	2.255	1.0395	2.4943	2.7603	2.7328
21	2.2657	2.2839	2.1986	1.0181	2.2775	2.4462	2.5781
22	2.2375	2.1479	2.2779	1.0029	2.1795	2.3731	2.2893
23	2.268	2.3	2.2642	.9838	2.396	2.4734	2.4478
24	2.2093	2.1986	2.2264	1.8892	2.0107	2.2893	2.2641
Max	2.6227	2.6216	2.3121	2.0264	2.6826	2.7603	2.8022
Min	1.9707	1.9029	1.9257	.9137	1.5006	1.6179	1.8675
Avg	2.2645	2.2558	2.1222	1.4241	2.1641	2.2626	2.3380

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 204 / 11 KV PARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3769	2.3639	2.4402	2.5042	1.4853	2.2275	2.2881
2	2.3476	2.4043	2.4265	2.4897	1.4655	2.1582	1.1462
3	2.2389	2.3845	2.3426	2.4622	1.4216	1.9532	2.1971
4	2.1277	2.1963	2.3251	2.3152	1.4144	2.1079	2.1384
5	2.1437	2.1369	2.3053	2.1627	1.4167	2.1635	2.1864
6	2.2287	2.2108	2.4302	2.0686	1.4601	2.3586	2.2036
7	2.4782	2.431	2.5034	2.0485	1.6263	2.3281	2.4897
8	2.6391	2.6067	2.6223	1.7665	2.1963	2.5922	2.8235
9	2.7435	2.7687	2.7313	1.6636	2.5065	2.9203	2.7896
10	2.6413	2.8383	2.6902	1.5341	2.7899	2.8967	2.9371
11	2.7313	2.9896	2.668	1.3478	2.7763	3.0262	3.0274
12	2.777	2.726	2.529	.6607	2.5141	2.604	2.404
13	2.0964	1.9208	1.8678	.0221	1.6248	1.8869	2.2291
14	2.6002	2.6841	2.5156		2.431	2.7245	2.6532
15	2.9713	2.9462	2.8281		2.7786	3.0506	2.9565
16	2.8525	3.0079	2.7519	.692	2.771	2.9241	2.8914
17	2.6864	2.836	2.6498	.7644	2.7519	2.8448	2.782
18	2.5278	2.8129	2.5804	.7697	2.6387	2.8468	2.8121
19	3.027	2.8563	2.9051	.8421	2.7938	2.9287	2.8395
20	2.9924	3.0353	3.0917	2.0085	2.8288	3.0612	2.9477
21	2.4341	2.5667	2.7427	1.9185	2.4828	2.5792	2.5156
22	2.6955	2.6978	2.7481	1.8343	2.3876	2.5442	2.5644
23	2.8433	2.8258	3.0556	1.7109	2.6848	2.7931	2.6886
24	2.3201	2.7694	2.838	2.0344	2.0393	2.6025	2.4989
Max	3.027	3.0353	3.0917	2.5042	2.8288	3.0612	3.0274
Min	2.0964	1.9208	1.8678	.0221	1.4144	1.8869	1.1462
Avg	2.5634	2.6257	2.6079	1.6191	2.2203	2.5885	2.5421



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 403 / 33KV NAGEVADI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	12.4486	12.2428	13.9232	15.0549	15.7408	17.6955	11.7284
2	11.6598	12.2085	13.3059	13.7174	15.3635	16.5981	12.2428
3	11.4541	11.7627	12.8944	13.1344	15.1921	16.0494	11.8999
4	11.3169	11.4884	12.62	13.0659	14.3004	15.8436	11.6255
5	11.4884	11.4884	13.1687	13.2716	14.5748	15.8436	11.5569
6	12.62	12.3114	14.5748	14.5405	16.0151	17.2154	12.5515
7	15.7751	14.712	18.4843	19.3416	19.1701	21.9822	15.6379
8	13.1687	12.3114	14.2661	16.2209	14.952	17.8327	13.546
9	23.8683	23.8341	18.0727	14.7805	17.5926	19.0329	24.0055
10	27.1605	25.8917	19.1701	14.712	17.3183	19.4788	26.6461
11	26.3375	27.7092	18.7586	15.3635	18.4843	18.6557	23.2511
12	27.0919	27.6749	18.107	14.0604	18.8958	19.7874	26.3032
13	23.4568	25.7202	17.5583	4.9383	18.5185	18.107	24.3142
14	24.3142	24.7257	15.9808	4.6639	19.6845	17.8327	22.4966
15	24.9657	24.2113	15.7408	4.6296	18.9644	15.8779	23.9369
16	24.9657	24.3142	14.8148	10.8711	19.1358	16.2895	24.6228
17	18.1756	18.3128	12.5858	10.7682	15.9808	7.3045	18.7586
18	7.8532	7.9904	7.6475	5.0412	7.9561	7.6818	7.7846
19	8.2991	8.2305	8.7449	5.8642	8.8477	8.3333	8.6763
20	9.6365	9.1221	9.3279	6.7215	10.0823	9.7737	10.0823
21	9.808	9.0878	9.3964	7.6475	9.8423	9.5336	10.2538
22	13.3402	17.0096	18.0727	17.4554	19.1358	14.6091	15.3635
23	14.0947	16.4609	19.4445	17.6612	19.856	15.0206	15.4664
24	12.963	19.1999	16.4266	16.3238	18.7929	16.2346	13.8203
Max	27.1605	27.7092	19.4445	19.3416	19.856	21.9822	26.6461
Min	7.8532	7.9904	7.6475	4.6296	7.9561	7.3045	7.7846
Avg	16.5109	17.0009	14.7120	12.0771	16.0165	15.5256	16.5238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 201 / 11 KV ALSAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1459	2.8673	2.7846	.1753	.2715	.2715	.3506
2	3.1131	2.8018	2.7349	.1715	.2561	.2743	.3506
3	3.0498	2.6235	2.6852	.1715	.2353	.2187	.3086
4	2.9835	2.4806	2.5888	.1865	.2328	.2241	.3086
5	2.9843	2.2725	2.4577	.1865	.2507	.216	.3086
6	2.9172	2.3482	2.4741	.2454	.2835	.2622	.3582
7	2.8182	2.6216	2.4615	.2454	.3258	.2486	.394
8	.2035	.2481	.2343	.2429	.2743	.2115	.3544
9	.1949	.2804	2.982	3.2007	1.3763	3.1493	.394
10	.2481	.2622	3.2114	3.2007	1.4251	2.9504	.3224
11	.2507		2.8673		1.3441	3.3482	
12	.2507		3.195		3.0167		.3189
13	.2279		3.2769		3.1659	1.7814	.3012
14	.208	.2481	3.1131			1.7604	.3721
15	.2303	.2865	3.1131			1.7004	.0886
16	.2629		2.9797			1.7736	.0876
17	.2572	.0351	.1858		.2056	.0781	.3898
18	.2713	.2103	.1715		.3258		.4252
19	.2686	.2865	.2347		.3982		.4477
20	.2658	.2865	.2401		.3982		.4298
21	.2401	.2835	.2374		.394		.4298
22	3.0312	2.8509	.2507		.394		
23	3.1493	2.7854	.2303		.2812	.394	
24	3.2156	2.9492	2.769	.2103	.2658	.2896	.3681
Max	3.2156	2.9492	3.2769	3.2007	3.1659	3.3482	.4477
Min	.1949	.0351	.1715	.1715	.2056	.0781	.0876
Avg	1.4078	1.4514	1.9783	.7488	.7200	1.0640	.3385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 202 / 11 KV BHALWANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0686	1.0957	1.0669	1.1069	.8916
2			.0701	1.0364	1.0031	1.0623	.8619
3			.0716	1.0364	.9602	.9259	.7613
4		.0351	.0716	.9783	.884	.9374	.7613
5		.0701	.0701	.9332	.8278	.7526	.7613
6	.0739	.0739	.0876	1.0364	.8916	.8951	.9326
7	.0739	.1109		1.0517	1.0031	.884	1.0004
8		.0867	.0594	.061	.0655	.081	.0541
9	1.5813	1.4232	.0686	.0716			1.4548
10	1.5813	1.4232	.0587	.08			1.4548
11	1.6004	1.2967	.0678				1.4864
12	1.6004	1.3441			.0724	.0655	1.3435
13	1.5497	1.2963	.0671		.0905	.0857	1.3272
14	1.4842	1.2346	.0663		.0743	.081	1.2498
15	1.3916	1.1728	.0663		.064	.0838	1.2346
16	1.3117	1.1574	.0701		.0663	.0857	1.1431
17	.0926	.061	.081		.0663	.0819	.0867
18	.0791	.1715	.0834		.0876		.0762
19	.0886	.208	.0983		.0876		.0663
20	.0886	.2279	.0886		.0876		.0867
21	.0876	.0867	.0838		.0867		.0867
22	.0724	.0876	1.3123		1.3441		.0886
23		.0701	1.3123		1.2163	1.0802	.0709
24			.064	1.1702	1.0936	1.0936	.9214
Max	1.6004	1.4232	1.3123	1.1702	1.3441	1.1069	1.4864
Min	.0724	.0351	.0587	.061	.064	.0655	.0541
Avg	.7973	.5819	.1858	.7774	.5305	.5814	.7584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 203 / 11 KV KAMLAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4885	.4626	.5037	4.3537	4.0824	4.0037	3.3231
2	.4847	.4411	.4695	4.1099	4.106	3.8066	3.1969
3	.4458	.4466	.4694	3.8965	3.6725	3.4796	3.1092
4	.4405	.4578	.4694	3.6778	3.4114	3.2243	3.1444
5	.4466	.487	.5227	3.6	3.2393	3.1001	2.9593
6	.5385	.5773	.591	3.9742	3.4873	3.4591	3.11
7	.6112	.6512	.663	4.2966	4.0897	3.7099	3.216
8	.5914	.8223	.6105	.6294	.6325	.5051	.4329
9	5.3483	5.6511	.7819	.7468	.6846	.6226	4.4763
10	5.394	5.6108	.8245	.7705	.6854	.7331	4.827
11	5.1387	5.215	.8185	.3826	.6577	.5295	4.6258
12	4.215	5.0327	.7811	.3666	.6241	.5403	4.9848
13	4.1915	5.0198	.6302	.3666	.6755	.6637	4.8895
14	4.5735	4.9977	.5373	.365	.6923	.6651	4.5496
15	4.9353	4.3915	.5258	.3772	.6524	.6134	4.2669
16	4.6895	4.4607	.4777	.3833	.7293	.6584	4.3331
17	.5239	.6059	.5571	.3727	.663	.682	.4481
18	.5007	.6706	.6318	.3818	.6584	.4024	.5031
19	.5824	.7072	.6332	.3307	.6363	.3955	.5148
20	.6218	.7346	.6524	.6363	.6762	.3955	.6472
21	.5521	.6828	.9463	2.7001	.8284	.4367	.6687
22	.5887	.6082	5.016	4.7604	3.3791	2.3541	.6159
23	.4687	.5365	5.0777	4.7089	4.1175	4.0063	.5335
24	.477	.4992	2.8925	4.4414	4.2215	3.7599	1.8058
Max	5.394	5.6511	5.0777	4.7604	4.2215	4.0063	4.9848
Min	.4405	.4411	.4694	.3307	.6241	.3955	.4329
Avg	1.9520	2.0738	1.0868	2.1095	1.9710	1.7811	2.7159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 204 / BHALWANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.128	.1052	.1227	.1387	.1387	.1189
2	.1109	.1109	.1052	.12	.1387	.1214	.1189
3	.1109	.1086	.0905	.1341	.1214	.1214	.1189
4	.1109	.1075	.0905	.1341	.12	.1147	.1353
5	.1463	.124	.1086	.1311	.1372	.1134	.1353
6	.1463	.1448	.1254	.1372	.1402	.1402	.1265
7	.1791	.124	.1417	.1387	.104	.1677	.1265
8	.1113	.125	.1219	.1046	.125	.1036	.1265
9	.0926	.1143	.0995	.1017	.1448	.0995	.0903
10	.1158	.1143	.096	.1014	.0995	.0914	.1158
11	.1158	.104	.0819		.0857	.0903	.088
12	.1158	.104	.1006			.0914	.0892
13	.1219	.0974	.108			.1014	.1082
14	.1189	.1158	.1054		.1048	.088	.12
15	.1219	.0892	.108		.1143	.1097	.1158
16	.1257	.1054	.0937		.1128	.1219	.1158
17	.0914	.0991	.084		.1143	.1067	.1097
18	.0663	.1486	.0945		.2709		.1086
19	.128	.1898	.1524		.1505		.1486
20	.218	.213	.1966		.213		.2321
21	.218	.1943	.1966		.2294		.1966
22	.181	.1753	.1772		.1772		.1753
23	.1478	.1433	.1448		.1433	.1341	.1753
24	.1097	.128	.1214	.1227	.1402	.1387	.1189
Max	.218	.213	.1966	.1387	.2709	.1677	.2321
Min	.0663	.0892	.0819	.1014	.0857	.088	.088
Avg	.1298	.1295	.1187	.1226	.1421	.1155	.1298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 205 / ALSAND / KAMALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.642	.6264	.6264	.6813	.6828	.6813
2	.6226	.6059	.5864	.6157	.6927	.684	.6714
3	.598	.6249	.5757	.6142	.7042	.7019	.6668
4	.5818	.6524	.5731	.618	.7232	.7064	.7034
5	.6493	.7346	.628	.7453	.8057	.772	.852
6	.9206	.9629	.8695	1.0421	1.086	1.0852	1.0791
7	1.1595	1.0936	1.105	1.1282	1.2209	1.0823	1.2201
8	.9541	.9907	.9282	.9952	1.0394	.7726	.9061
9	.825	.8133	.7545	.7754	.8076	.7492	.8017
10	.7393	.6908	.7011	.7787	.7087	.6409	.7826
11	.6527	.6497	.5895	.3887	.6767	.6234	.8001
12	.4893	.6666	.5516	.3559	.2873	.6864	.7887
13	.634	.6536	.6942	.3132	.6592	.687	.7201
14	.6642	.6696	.7338	.3437	.5868	.6605	.7445
15	.7201	.6553	.746	.3422	.5437	.6809	.7438
16	.668	.6668	.724	.3711	.3048	.6483	.7018
17	.7239	.6771	.74	.4016	.6479	.6889	.7551
18	.7789	.7499	.8151	.4466	.8543	.4214	.7711
19	.919	.8802	.9335	.5434	1.0372	.5007	1.0258
20	1.0707	1.0624	1.1519	.5723	1.1254	.5754	1.1042
21	1.0532	1.0257	1.0845	.5548	1.0333	.5609	.9983
22	.8844	.9046	.9533	.4854	.9747	.4938	.8827
23	.6809	.7544	.7682	.4603	.8467	.8269	.8063
24	.6642	.4874	.6748	.6996	.709	.7036	.6889
Max	1.1595	1.0936	1.1519	1.1282	1.2209	1.0852	1.2201
Min	.4893	.4874	.5516	.3132	.2873	.4214	.6668
Avg	.7619	.7631	.7712	.5924	.7815	.6931	.8290

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 206 / 11 KV Umar Kanchan

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7664	2.4291	1.8244	.128	.1402	.1417	.1526
2	2.7161	2.3205	1.8679	.128	.1254	.1254	.1526
3	2.652	2.2939	1.8351	.1267	.1254	.1448	.1658
4	2.5029	2.0805	1.8023	.1267	.1433	.1463	.1658
5	2.3205	2.0005	1.7859	.1254	.1402	.1402	.1658
6	2.1628	2.0325	1.8461	.1402	.1646	.1417	.1629
7	2.0891	2.1862	1.9204	.1402	.1448	.1387	.1629
8	.1341	.1526	.1214	.1475	.1387	.1357	.1417
9	.1402	.1187	2.3594	2.8675	2.8016	2.8182	.1227
10	.1372	.1387	2.5069	2.6052	2.8346	2.4777	.1387
11	.1357	.1387	2.5888		2.8346	2.3967	.1214
12	.1357	.1387	2.5396		1.247	2.4577	.12
13	.1147	.1357	2.6558		2.8178	2.5286	.1326
14	.0995	.1387	2.5263		2.5286	2.4777	.1457
15	.1357	.1372	2.5587		2.4966	2.4453	.1509
16	.1475	.1526	2.4291		2.451	2.2085	.1475
17	.1372	.1187	.144		.1311	.1296	.1696
18	.1526	.1402	.1457		.2774		.156
19	.1734	.1433	.1433		.1734		.1991
20	.1949	.1629	.181		.181		.1791
21	.1578	.1629	.181		.1629		.1578
22	2.4939	2.1548	.1663		.1433		2.4453
23	2.4577		.1294		.1433	.1595	2.6052
24	2.7362	2.4086	1.8785	.128	.1372	.1417	.1526
Max	2.7664	2.4291	2.6558	2.8675	2.8346	2.8182	2.6052
Min	.0995	.1187	.1214	.1254	.1254	.1254	.12
Avg	1.1206	.9516	1.5057	.6058	.9368	1.1240	.3506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 207 / VITA WATER SUPPLY,ALSAND NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.218	.2347	.2155	.1989	.2155	.213	.1943
2	.2155	.218	.2155	.1989	.1966	.2105	.1943
3	.2155	.1989	.2155	.1989	.1802	.1966	.1943
4	.2155	.213	.2155	.1989	.1658	.213	.1943
5	.218	.2294	.2155	.1943	.1326	.213	.1943
6	.218		.2155	.1966	.213	.213	.2294
7		.2321	.2294	.1966	.1989	.213	.2294
8	.2294	.2294	.2294	.2241	.213	.2267	
9	.2321	.2294	.2321	.2321	.2294	.2321	.2294
10	.1989	.2294	.2321	.2155	.2321	.2321	.2321
11	.1989	.213	.2321		.2321	.2294	.2294
12	.1966	.2321	.2321		.1989	.1658	.2321
13	.1823	.213	.2818		.2294	.116	.2294
14	.1966		.116		.1296	.213	
15		.213	.213		.2267	.2294	.2294
16	.2105	.213	.213		.192	.213	
17	.213	.213	.213		.1966	.2294	
18	.213	.2294	.1966		.213		
19	.2294	.2294	.1966		.213		
20	.2105	.2267	.1966		.213		
21	.2105	.2105	.1943		.2105		
22	.2294	.2105	.1989		.2155		.1326
23		.1341				.1326	.2321
24	.2155	.2321	.213	.1989	.2155	.213	.1943
Max	.2321	.2347	.2818	.2321	.2321	.2321	.2321
Min	.1823	.1341	.116	.1943	.1296	.116	.1326
Avg	.2127	.2175	.2136	.2049	.2027	.2055	.2107



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 201 / 11 KV GARDI FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1227	1.6575	1.8023	1.9227	2.079	.1017
2	.1097	.1063	1.6575	1.7368	1.8023	2.0119	.1029
3	.1097	.1075	1.6385	1.7532	1.7204	1.8564	.1029
4	.112	.1254	1.6385	1.7695	1.6842	1.8564	.1052
5	.1307	.1629	1.6385	1.749	1.7328	1.8785	.1417
6	.168	.181	1.8023	1.8461	1.749	1.8785	.1772
7	.2054	.2033	1.8351	1.8673	2.0719	1.8747	.192
8	.1823	.1677	.1311	.1296	.1311	.1463	.1402
9	2.7515	2.7854	.1311	.1134	.1134	.1448	2.9504
10	2.8509	3.1327	.1372	.0886	.0857	.1448	3.155
11	.2652	3.0996	.1372	.0914	.1063	.128	3.2442
12	2.7681	3.0498	.128	.12	.1029	.0949	3.0312
13	2.9338	2.8509			.0972	.0983	3.0312
14	2.8675	2.652	.0926		.0914	.1326	3.0312
15	2.9007	2.652	.096		.1326	.2012	2.982
16	2.4741	2.3537	.092		.1326	.2347	2.7035
17	.1402	.116	.0823		.1372	.1402	.0819
18	.1475	.116	.104		.1372	.1357	.1006
19	.1629	.116	.1578		.181	.2103	.1658
20	.1772	.1326	.181		.2195	.2103	.1638
21	.1734	.1326	.1294		.2195	.181	.1475
22	.1463	1.7901	2.0481		2.1948	.1463	.0983
23	.128	1.7404	1.9662		2.1879	.1372	.0819
24	.1097	.1227	1.6575	1.8351	2.1051	2.1216	.1029
Max	2.9338	3.1327	2.0481	1.8673	2.1948	2.1216	3.2442
Min	.1097	.1063	.0823	.0886	.0857	.0949	.0819
Avg	.9219	1.1675	.8321	1.1463	.8774	.7518	1.0890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 202 / 11kv prabhat steel

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1624	.1722	.3147	.1639	.1673	.1779	.173
2	.1619	.1711	.3147	.1684	.1692	.1783	.1718
3	.1646	.1707	.3151	.1669	.1665	.1818	.1764
4	.1634	.1761	.3151	.1669	.176	.1825	.1753
5	.1639	.1864	.314	.1684	.1784	.1879	.1733
6	.1608	.1822	.3075	.165	.1776	.1867	.1677
7	.1772	.181	.314	.189	.1738	.1829	.1631
8	.615	.3948	.4938	.1844	.2301	.7731	.3921
9	.7077	1.1079	.7053	.1669	.242	.7331	.8497
10	1.0519	.7011	1.4903	.1696	.3402	.9088	.9164
11	1.19	1.0353	.8962	.1665	.594	.7168	1.1313
12	1.4502	1.0535	.7606	.1787	.6565	.6859	1.3525
13	.58	.5884	.804	.1783	.8074	.7594	.8607
14	.6253	.8566	.751	.1768	.7026	1.1107	.5704
15	1.2519	1.0764	.5014	.1749	.6519	.6935	.4447
16	.5849	1.7581	.77	.168	.6093	.5781	.3749
17	.6543	.6909	.7384	.1703	.604	.8029	1.1553
18	.7348	.5405	1.1974	.1696	.6813	.6615	1.0982
19	1.1879	.5908	.6409	.1673	.7556	.8424	.8855
20	.5981	.4733	.639	.1692	.7899	.5441	.6363
21	.1771	.3136	.4218	.1684	.4797	.1639	.5346
22	.168	.3109	.1601	.1623	.1673	.1631	.3044
23	.1615	.2983	.1612	.1585	.1616	.1639	.2538
24	.1578	.1734	.3098	.1658	.1695	.176	.1692
Max	1.4502	1.7581	1.4903	.189	.8074	1.1107	1.3525
Min	.1578	.1707	.1601	.1585	.1616	.1631	.1631
Avg	.5438	.5501	.5682	.1702	.4105	.4898	.5471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 203 / 11 kv Yetgaon AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.8233	.2058	.1886	.1509	.1886	1.7204
2	1.643	1.7204	.2058	.1886	.1334	.1886	1.7238
3	1.6617	1.6385	.2058	.1509	.1143	.1886	1.7736
4	1.6956	1.7204	.2058	.1509	.1143	.1886	1.7859
5	1.7939	1.7901	.2058	.1886	.1524	.2263	1.8842
6	2.146	1.873	.2058	.2452	.2286	.2263	2.0885
7	2.0119	2.1795	.2743	.2587	.3018	.3018	2.2542
8	.2477	.2641	2.0576	.2218	.2829	.2241	.2641
9	.2477	.2452	2.915	2.5149	2.9473	3.0849	.2641
10	.2286	.2452	3.1036	2.8837	2.9675	3.0178	.3018
11	.2286	.2328	2.7435	2.7831	2.9508	2.8502	.2829
12	.2477	.2229	2.5987		2.9508	2.7161	.2263
13	.1886	.1715	2.5484		2.9172	2.7328	.2263
14	.1905	.1886	2.5819		2.8509	2.7664	
15	.2286	.2058	2.5265		2.4813	2.7496	
16	.2263	.2401	2.3205		2.4813		
17	.2641	.2401	.2263		.1886		.1638
18	.2641	.2267	.3174		.2241	.2263	.1595
19	.2829	.3395	.3361		.2263	.3395	.2561
20	.3018	.2915	.3018		.3018	.2987	.3018
21	.2641	.2743	.3018		.3018	.3018	.3018
22	2.0287	.2743	.2641		.2263	2.2801	2.4813
23	2.0287	.2507	.2075		.2263	1.8351	2.2131
24	1.7436	1.8564	.2058	.1886	.1698	.1886	1.8023
Max	2.146	2.1795	3.1036	2.8837	2.9675	3.0849	2.4813
Min	.1886	.1715	.2058	.1509	.1143	.1886	.1595
Avg	.9100	.7715	1.1277	.8303	1.0788	1.2328	1.0703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 204 / 11 KV SALSHINGE FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.3967	2.7324	2.8471	3.0022	2.8349	.3768
2	.1867	.3734	2.5818	2.6063	2.8964	2.7602	.3704
3	.1848	.3528	2.5088	2.5714	2.649	2.6696	.3647
4	.1867	.3883	2.536	2.6219	2.6018	2.7869	.3669
5	.1867	.4321	2.5545	2.7865	2.7877	2.9081	.41
6	.2772	.4885	3.1996	3.2476	3.1543	3.5033	.4451
7	.2957	.6565	4.0882	4.0017	4.0631	3.9583	.5228
8	.3429	.6256	1.1332	1.2765	1.1643	1.1797	.642
9	2.6242	5.0705	.442	.4368	.4961	.4733	4.904
10	2.7166	5.2903	.4092	.4413	.4106	.4241	4.8872
11	2.4034	5.2721	.3967	.3803	.4839	.4329	5.0631
12	2.3807	5.1067	.3696	.4489	.4954	.4687	4.7462
13	2.3137	4.7432	.0526	.2462	.4237	.4992	4.6195
14	2.4813	5.266	.3647	.1905	.4576	.2492	4.8614
15	2.4143	4.984	.4497	.2248	.4893		5.1525
16	2.2801	4.6312	.4726	.2294	.4687	.4245	4.9958
17	.2103	1.2452	.538	.1989	.4625	.5003	1.5067
18	.2347	.4167	.4969	.2256	.4725	.5483	.5251
19	.1075	.3986	.5708	.285	.4885	.6752	.5884
20	.3258	.4919	.5167	.3155	.5487	.6146	.68
21	.3189	.4908	.5274	.2964	.4866	.6359	.7076
22	.2614	2.8776	3.3608	1.7574	3.2183	.5887	.6447
23	.2241	2.9498	3.2347	1.7962	3.2655	.4855	.588
24	.7716	1.8717	2.9336	3.0917	3.0083	1.6011	.4847
Max	2.7166	5.2903	4.0882	4.0017	4.0631	3.9583	5.1525
Min	.1075	.3528	.0526	.1905	.4106	.2492	.3647
Avg	.9964	2.2842	1.5196	1.3552	1.5831	1.3575	2.0189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 206 / 11 kv salshinge Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481	.2263	.2614	.2103	.2286	.1886	.2454
2	.2172	.2096	.2614	.2103	.2096	.1886	.2126
3	.2149	.1905	.2587	.2103	.1905	.2263	.2103
4	.2507	.2286	.2614	.2279	.2477	.2263	.2126
5	.3155	.2667	.2561	.2658	.2858	.2587	.298
6	.4481	.381	.3582	.3544	.4001	.3658	.3856
7	.4119	.5093	.3841	.443	.4481	.4163	.4557
8	.3403	.3921	.3174	.3155	.3361	.3439	.298
9	.3761	.3801	.3584	.2804	.3045	.2835	.298
10	.3582	.3258	.3361	.2804	.3224	.3077	.2629
11	.3258	.3292	.3109	.2835	.2896	.3077	.2743
12	.3052	.2957	.2987	.2743	.2926	.3045	.3109
13	.2572	.3174	.2957		.2561	.3045	.2801
14	.2915	.3361	.3045		.2534		.2801
15	.3052	.3142	.298		.3109		.2801
16	.3506	.2926	.2835		.3109	.3506	.2614
17	.3224	.3077	.2328		.3142	.3155	.2614
18	.3258	.3475			.3696	.298	.2743
19	.4854	.3841	.4119		.4755	.5083	.4066
20	.5281	.4668	.4477		.4805	.4733	.5281
21	.4527	.4108	.4119		.4435	.4207	.4715
22	.415	.3584	.3582		.3734	.3856	.3921
23	.3018	.2829	.2865		.3361	.2804	.2427
24	.2804	.2829	.3045	.2454	.2452	.2263	.2454
Max	.5281	.5093	.4477	.443	.4805	.5083	.5281
Min	.2149	.1905	.2328	.2103	.1905	.1886	.2103
Avg	.3387	.3265	.3173	.2770	.3219	.3173	.3078

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 207 / 11 kv yetgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.0747	.0709	.0747			.1086
2	.1109	.0754	.0716	.0739			.0716
3	.0924	.0754	.0724	.0739		.0754	.0709
4	.0747	.0943	.0716	.0747	.0747	.0754	.0716
5	.0934	.0934	.0716	.0747	.0934	.0934	.1086
6	.1307	.0934	.0895	.112	.112	.0934	.1086
7	.1448	.1294	.0895	.1387	.0914	.1097	.104
8	.1387	.124	.0895	.0857	.1063	.0876	.1029
9	.1075	.0886	.0895	.0867	.0886	.0876	.1052
10	.0895	.1063	.0716	.0867	.0886	.0686	.0701
11	.0876	.104			.0876	.0686	
12	.0886	.0857			.1063	.0995	
13	.0716	.0838	.0678		.0724	.1006	
14	.0716	.0895	.0686		.0724	.0671	
15	.0724		.0678		.0739	.0838	
16	.0716	.0895	.0995		.0739	.0838	
17	.1063	.0895	.0678		.0739	.0972	
18	.0886	.0895	.1029		.0934	.0819	.0995
19	.1267	.1063	.1227		.0886	.124	.1029
20	.1307	.0895	.1267		.1086	.1254	.1254
21	.1307	.0716	.1267		.0924	.1254	.1448
22	.112	.0716	.0924		.0747	.1097	.1097
23	.0943	.0716	.0924		.0747	.1075	.0716
24	.1109	.0934	.0732	.0739	.0754		.1086
Max	.1448	.1294	.1267	.1387	.112	.1254	.1448
Min	.0716	.0716	.0678	.0739	.0724	.0671	.0701
Avg	.1024	.0909	.0862	.0869	.0868	.0936	.0991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 201 / 11 KV Lengare Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.695	.9282	.8215		.0566
2	.0566	.0566	.695	.9282	.8215		.0566
3	.0566	.0754	.695	.9602	.8215		.0566
4	.0566	.0754	.695	1.0242	.8215		.0566
5	.0566	.0943	1.0084	1.1203	.9362		.0566
6	.0566	.0943	1.0686	1.2018	1.1294	.9859	.0566
7		.0754		1.2811	1.358	1.1797	.0566
8	.0566	.0943	.0754	.0566	.0754	.0943	.0566
9	1.2498	1.2018	.0754	.0566	.0754	.0943	1.2651
10	1.3123	1.1149	.0754	.0566	.0754	.0943	1.2651
11	1.1873	1.0562	.0566	.0566	.0754	.0566	1.1728
12	1.0709	.9976	.0566	.0566	.0754	.0566	1.1736
13	1.1288	1.0136	.0566		.0754	.0566	1.1736
14	1.1591	.9587	.0566		.0943	.0566	1.1294
15	1.174	.8901	.0566		.0754	.0566	1.1126
16	1.1574	.9328	.0566		.0943	.0566	1.1126
17	.1132	.0754	.0566		.0754	.0566	.0943
18	.1132	.0754	.0566		.0754	.0566	.0943
19	.1132	.0754	.0566		.132	.0566	.132
20	.132	.0754	.0566		.1698	.0566	.1509
21	.1132	.0754	.0566		.1509	.0566	.132
22	.0943	.7529			.8768	.0566	.1132
23	.0754	.695	.9282	.8215	.8215	.0566	
24	.0566	.0754	.695	.9122	.8215		.0566
Max	1.3123	1.2018	1.0686	1.2811	1.358	1.1797	1.2651
Min	.0566	.0566	.0566	.0566	.0754	.0566	.0566
Avg	.4629	.4453	.3331	.6758	.4396	.1769	.4622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 202 / 11 KV VEJEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6057	3.5978	.4443	.4176	.4404	.5618	3.6705
2	1.5402	3.4957	.4443	.4435	.4427	.5572	3.6931
3	1.5402	3.4568	.4435	.4836	.4359	.3919	3.6107
4	1.5729	3.4576	.4668	.4721	.4305	.3881	3.623
5	1.6057	3.5817	.4721	.4902	.4336	.583	3.8942
6	2.2939	3.7312	.5259	.5169	.495	.6123	4.2486
7		4.1053	.3109	.6381	.5708	.7133	4.949
8	.1886	.916	.7095	.5854	.8093	.8017	1.0958
9	.2263	.5007	5.0793	6.1423	5.1463	5.9033	.2812
10	.2263	.5313	3.4537	6.0585	4.9985	6.1183	.6481
11	.2801	.5194	4.2841	5.8154	6.263	5.5372	.7678
12	.2801	.5224	5.0772	2.7686	5.8518	5.3494	.3818
13	.2829	.5415	5.0815		5.4428	5.1115	
14	.2801	.5453	4.582		4.7451	4.9692	
15	.3395	.543	4.6388		5.3237	4.9771	.4919
16	.3395	.599	5.0519	2.1224	5.1035	5.1376	.3904
17	.1509	.5392	.4923	.3216	.8158	.7739	.7149
18	.0943	.445	.4755	.2827	.5948	.4127	.8089
19	.3048	.461	.5516	.2522	.8042	.4553	.8165
20	.3239	.5217	.317	.2964	.961	.5306	.7741
21	.2858	.527	.5354	.285	.9438	.4994	.6828
22	1.95	.2423	.2202	.266	.7902	3.8767	4.3241
23	2.0178	.4603	.429	.5263	.6824	3.9743	2.4036
24	1.6057	2.0652	.4214	.4412	.5403	2.153	3.9452
Max	2.2939	4.1053	5.0815	6.1423	6.263	6.1183	4.949
Min	.0943	.2423	.2202	.2522	.4305	.3881	.2812
Avg	.8407	1.4961	1.8545	1.4108	2.2111	2.5162	2.1007



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 203 / 11 KV SALSHINGE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3002	.3769	2.3686	2.7492	2.7293	2.681	.3498
2	.3018	.3769	2.3511	2.7221	2.6912	2.6101	.3498
3	.3221	.3814	2.3313	2.7214	2.6691	2.6071	.3483
4	.3259	.3845	2.3489	2.7066	2.7831	2.5633	.3706
5	.3433	.389	2.4486	2.745	2.929	2.5465	.3789
6	.3456	.3921	2.8889	3.1848	3.2605	3.0346	.3845
7	.2149	.367	1.7924	3.7186	3.8805	3.3691	.4298
8	.692	.8383	.4093	.407	.3674	.5151	.519
9	4.4917	4.3141	.2835	.3506	.3742	.2965	4.6769
10	4.7127	4.1652	.2835	.3235	.3228	.3409	4.8308
11	4.1655	4.0128	.3346	.3315	.2835	.3628	4.9741
12	4.1117	4.0009	.3262	.3926	.2987	.3628	4.9931
13	4.135	3.9841	.3521	.2096	.3391	.3719	4.707
14	4.2048	3.805	.3658	.1852	.3338	.3887	4.4597
15	4.4681	3.9155	.3591	.1905	.2728	.3866	4.2513
16	4.2527	4.0055	.3561	.1654	.357	.3919	4.4321
17	.4092	.3948	.3765	.1799	.4406	.4183	.3942
18	.4797	.4458	.2477	.2286	.3713	.4092	.4892
19	.5056	.4908	.4657	.2705	.4252	.4359	.5194
20	.5308	.4962	.4862	.269	.4664	.4878	.5438
21	.524	.7754	.583	.7545	.7667	.4709	.5367
22	.4289	2.5347	1.7307	1.7147	3.1329	.3803	.4596
23	.386	1.4114	2.9812	2.9454	2.9668	.3613	.2058
24	.3353	1.4944	2.6399	2.8575	2.7842	1.4053	.3613
Max	4.7127	4.3141	2.9812	3.7186	3.8805	3.3691	4.9931
Min	.2149	.367	.2477	.1654	.2728	.2965	.2058
Avg	1.7078	1.8230	1.2130	1.3468	1.4686	1.1332	1.8319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 204 / 11 KV Lengare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.3292	.3658	.3658	.3361	.3326	.2957
2	.2614	.3292	.3658	.3475	.2987	.3326	.2957
3	.2427	.3292	.3224	.3292	.2926	.3142	.3361
4	.2427	.3326	.3224	.2801	.3109	.3142	.3361
5	.2614	.3326	.3582	.2054	.3258	.3142	.3361
6	.2987	.3326	.3582	.3361	.3258	.3658	.3361
7		.3982		.4024	.3439	.394	.3326
8	.3361	.3222	.4024	.362	.2926	.3681	.2561
9	.2103	.3113	.2915	.2614	.3121	.2804	.2058
10	.2103	.213	.2294	.2614	.3224	.2713	.1791
11	.3086	.2058	.2561	.3544	.3761	.2507	.2743
12	.3429	.2058	.2561	.3772	.3506	.2507	.3155
13	.3185	.208	.2103		.3155	.2507	.3121
14	.3258	.2743	.2103		.3366	.2103	.3155
15	.3294	.3086	.2561		.3582	.2103	.3155
16	.3086	.3185	.2561		.3403	.2103	.3189
17	.3277	.285	.2801		.2804	.2614	.3121
18	.2126	.2652	.2614		.2743	.2987	.2683
19	.4382	.333	.2987		.3761	.3361	.3721
20	.4887	.3506	.3361		.4887	.3921	.4755
21	.4887	.5014	.4024		.4938	.3734	.4435
22	.4435	.439			.4435	.3361	.4066
23	.3511	.3658	.3841	1.3443	.3921	.2957	
24	.2614	.3475	.3658	.3658	.3361	.3326	.2957
Max	.4887	.5014	.4024	1.3443	.4938	.394	.4755
Min	.2103	.2058	.2103	.2054	.2743	.2103	.1791
Avg	.3161	.3183	.3086	.3995	.3468	.3040	.3189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 205 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1905	.2477	.2096	.1905	.1905
2	.1905	.1524	.1905	.2286	.2096	.1905	.1905
3	.2096	.1524	.1905	.2286	.2096	.1905	.1905
4	.2096	.1524	.2096	.2096	.2096	.1905	.2096
5	.2286	.1715	.2096	.2096	.2286	.1905	.2096
6	.2286	.1905	.2286	.2477	.2286	.2286	.2096
7		.2096		.2286	.2286	.2096	.2096
8	.1905	.1715	.2286	.362	.1905	.1905	.2286
9	.1524	.2096	.1524	.2477	.1524	.1143	.1715
10	.1905	.0953	.0953	.2477	.1905	.2096	.1715
11	.1905	.1905	.1905	.1905	.2286	.1905	.1905
12	.1524	.2477	.2096	.1715	.2477	.2096	.2286
13	.1905		.1905		.2477	.2286	.2286
14	.1715		.1905		.2477	.2096	.1715
15	.1715		.2286		.2286	.1905	.1715
16	.1715		.2477		.2477	.1905	.2286
17	.1715		.2286		.2477	.1905	.1524
18	.1715		.1905		.2096	.2286	.1334
19	.2667	.2286	.2286		.2667	.2667	.3048
20	.3048	.2477	.2667		.3239	.3429	.362
21	.3048	.2858	.3239		.2858	.362	.362
22	.2858	.3048			.2667	.1905	.3239
23	.2477	.2477	.2667	.2286	.2667	.1905	
24	.1905	.1905	.2477	.2477	.2096	.1905	.1905
Max	.3048	.3048	.3239	.362	.3239	.362	.362
Min	.1524	.0953	.0953	.1715	.1524	.1143	.1334
Avg	.2079	.2001	.2139	.2354	.2326	.2119	.2187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 206 / 11 KV VEJEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2858	.2667	.2858	.2477	.2667	.2667
2		.2858	.2667	.2858	.2477	.2667	.2667
3	.2667	.2858	.2667	.2667	.2477	.2667	.2286
4	.2667	.2858	.2858	.2667	.2477	.2477	.2286
5	.3048	.2858	.2858	.2858	.2858	.2477	.2286
6	.3048	.2667	.3048	.2667	.2858	.2858	.2096
7		.2667		.2858	.2477	.2667	.2286
8	.3429	.3239	.3239	.3048	.2286	.2858	.2096
9	.2286	.3429	.2858	.2286	.2477	.2096	.1905
10	.2858	.381	.3048	.2286	.2286	.2286	.1715
11	.3048	.2286	.2667	.2667	.3239	.2096	.1905
12	.3048	.2477	.2667	.3048	.3048	.1905	
13	.2858		.2096		.2858	.1715	
14	.3048		.2096		.2477	.1715	
15	.3048		.2667		.3239	.1905	
16	.2096		.2858		.3239	.1905	
17	.3048		.2667		.3239	.2096	.2667
18	.3048		.2477		.3429	.2667	.4191
19	.381	.3048	.2858		.362	.381	.4572
20	.4572	.3429	.3239		.4382	.362	.5144
21	.4382	.381	.381		.381	.3429	.4763
22	.381	.362			.3239	.3048	.4001
23	.3429	.3048	.3048	.2858	.2858	.2667	
24	.2286	.3048	.3048	.3048	.2477	.2667	.2667
Max	.4572	.381	.381	.3048	.4382	.381	.5144
Min	.2096	.2286	.2096	.2286	.2286	.1715	.1715
Avg	.3083	.3048	.2823	.2762	.2929	.2540	.29

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 207 / 11KV KANDESARWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2705	.2498	.0566	.0566	.0566	.056	.2961
2	.2976	.2498	.0566	.0566	.0566	.0554	.3384
3	.3384	.2534	.0566	.0566	.0566	.0554	.4054
4	.3948	.2667	.0566	.0566	.0566	.0549	.4344
5	.423	.3292	.0566	.0566	.0566	.0549	.4633
6	.4664	.3666	.0566	.0566	.0566	.056	.4344
7		.4801		.0566	.0566	.0554	.5357
8	.0566	.0554	.0566	.0566	.0566	.052	.0566
9	.0566	.0549	.6622	.6539	.535	.5868	.0566
10		.0543	.6097	.6161	.5868	.5716	.0566
11		.0554	.6401	.4401	.4858	.578	.0549
12		.056	.6401		.4599	.6081	.0554
13			.6706		.434	.6081	.0549
14			6.7673		.4207	.5639	.0554
15	.056		.5639		.4146	.5357	.0549
16	.0554		.5357		.4733	.4934	.0549
17	.056		.0566		.0554	.0566	.0549
18	.0549		.0566		.0549	.0566	.056
19	.0554	.0566			.052	.0566	.0526
20	.056	.0566			.0549	.0566	.056
21	.0566	.0943			.0543	.0566	.056
22	.2858	.0754			.0554	.282	.2743
23	.2782	.0754	.0566	.0566	.0554	.282	
24	.2705	.257	.0754	.0566	.0566	.056	.2961
Max	.4664	.4801	6.7673	.6539	.5868	.6081	.5357
Min	.0549	.0543	.0566	.0566	.052	.052	.0526
Avg	.1960	.1715	.6174	.1751	.1959	.2454	.1849

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 201 / 11 KV TEXTILE PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.7011	.5487	.8048	.5959	.8059	.8413
2	.6089	.7011	.5487	.6805	.631	.7712	.8063
3	.6805	.7282	.5144	.6733	.631	.7682	.7619
4	.631	.7442	.5144	.6733	.5895	.8048	.7701
5	.6154	.6516	.5201	.6878	.583	.7783	.7701
6	.6584	.6661	.5201	.724	.5548	.7522	.7343
7	.6626	.6935	.5201	.6935	.5144	.7108	.7108
8	1.0985	.6859	.5375	.7796	.5895	.6935	.8059
9		.8764	.6762	.9015	.9259	.8322	.9259
10	.9412	.8322	.7455	.9214	.9816	.7802	.9882
11	1.0719	.8322	.7628	.8596	.9709	.7802	.9882
12	1.1458	.8669	.7282		.8495	.7802	.7682
13	.6697	.7282			.8596	.7455	.7956
14	.6447	.8322	.7455		.6588	.7802	.8383
15	.631	.8669	.7975		.7712	.8495	.8718
16	.7455	.8495	.8048		.7802	.7975	.9431
17	.6859	.8149	.7802		.7362	.8322	.8859
18	.7011	.7802	.7108		.7628	.8495	.8916
19	.7011	.7282	.6241		.8238	.8322	.8059
20	.6859	.6935	.6154		.8322	.7975	.7545
21	.7011	.6588	.6173		.7802	.7975	.8063
22	.6859	.5548	.6413		.7975	.8669	.7545
23	.6516	.5548	.8596		.8238	.8669	.9335
24	.6516	.6516	.5548	.4024		.7888	.8669
Max	1.1458	.8764	.8596	.9214	.9816	.8669	.9882
Min	.6089	.5548	.5144	.4024	.5144	.6935	.7108
Avg	.7348	.7372	.6473	.7335	.7410	.7942	.8341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 202 / 11 KV PARE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083	1.3599	1.3283	.1478	.1402	.1307	.0716
2	1.4083	1.3279	1.2498	.1086	.1417	.1307	.0686
3	1.4746	1.3283	1.2498	.1075	.1578	.1294	.0671
4	1.4746	1.2803	1.1873	.1086	.1372	.128	.1006
5	1.5424	1.1873	1.1111	.1063	.1402	.1448	.1341
6	1.4922	1.4403	1.1111	.1387	.1448	.1612	.1311
7	1.3916	1.4685	1.1111	.1715	.1433	.1734	.1296
8	.1372	.0754	.1341	.1638	.1448	.116	.104
9	.1402	.1075	1.8461	1.6842	2.2119	2.0153	.1402
10	.1372	.0972	1.8785	1.8233	2.3472	2.2939	.1326
11	.1387	.0709	1.6194	1.9334	1.8785	2.3266	.16
12	.1402	.0709	1.6842		2.0081	.0486	.16
13		.1341	1.6604		2.0885	2.0729	.1417
14	.1372	.1341	1.7166			1.9433	.1433
15	.1387	.1372	1.7166			1.8461	.1448
16	.1387	.1357	1.8107		1.7124	1.7604	.1402
17	.1372	.128	.1158		.144	.0914	.1097
18	.1402	.128	.125		.1619	.0857	.0734
19	.1433	.1372	.1715		.1696	.1387	.1715
20	.1463	.1402	.1402		.1433	.1417	.1791
21	.1402	.1387	.1772		.1433	.1417	.1791
22	1.4746	1.3283	.181		.1433	.1433	1.989
23	1.4685	1.3283	.1433		.1433	.1075	1.8233
24	1.4575	1.5043	1.3283	.1311	.1448	.1463	.0716
Max	1.5424	1.5043	1.8785	1.9334	2.3472	2.3266	1.989
Min	.1372	.0709	.1158	.1063	.1372	.0486	.0671
Avg	.7134	.6329	1.0332	.5521	.6632	.6841	.2736

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083] BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 203 / 11 KV WAZAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	05-APR-17	06-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	2.079	2.079
2		.1132	2.0957	2.0454
3		.1132	2.0957	2.0119
4		.1132	2.0119	1.9448
5		.1132	2.0119	1.9113
6		.1132	1.8442	1.9448
7		.1132	2.0119	1.9281
8		.1132	.1132	
9			.1132	
10	2.6825		.1132	
11	2.7664			
12	3.2693			
14	2.6155			
15	2.3807			
16	2.3472			
17	.1132			
18	.1132			
19	.1132			
20	.1132			
21	.1132			
22	.1132		2.1963	
23	.1132		2.146	
24	2.7435	.1132	2.146	2.0957
Max	3.2693	.1132	2.1963	2.0957
Min	.1132	.1132	.1132	1.9113
Avg	1.3998	.1132	1.6137	1.9951



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 201 / Yashodhan Garment

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1307	.1143	.112	.0762	.1143	.1109
2	.0953	.132	.1143	.112	.0762	.1143	.112
3	.0953	.1143	.0953	.112		.0953	.112
4	.0953	.1132	.0953	.112	.0762	.0953	.112
5	.1143	.1307	.0953	.0943	.0762	.0953	.0943
6	.1143	.1132	.0953	.0914	.0762	.0953	.0943
7	.1143	.1132	.0953	.0924		.0953	.0943
8	.0953	.112	.1143		.0953	.0953	.0943
9	.1294	.1097	.1334		.0953	.1143	.1109
10	.1307	.1267	.1448		.1715	.1109	.1294
11	.132	.1524	.1267		.1715	.128	.1307
12	.1267	.1715	.1448		.1524	.1267	.1109
13	.1294	.1524	.128		.1334	.1267	.1097
14	.128	.1524	.1267		.1334	.1294	.0953
15	.128	.1524	.124		.1143	.128	.1075
16	.124	.1715	.1254		.1143	.1294	.1097
17	.128	.1905	.1254		.1143	.1109	.1294
18	.1097	.1715	.1052		.1334	.128	.124
19	.1294	.1524	.1433		.1524	.1294	.1267
20	.1267	.1524	.1448		.1524	.112	.1097
21	.1267	.0953	.1109	.0953	.1334	.128	.1075
22	.1294	.1334	.128	.1143	.1143	.1143	.1254
23	.1307	.1143	.1294	.1143	.1143	.0934	.12
24	.1109	.132	.1143	.128	.0953	.1143	.1109
Max	.132	.1905	.1448	.128	.1715	.1294	.1307
Min	.0953	.0953	.0953	.0914	.0762	.0934	.0943
Avg	.1190	.1371	.1198	.1071	.1169	.1135	.1117

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 202 / Gardi Textile

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2054	.2477	.2263	.2286	.2096	.2427
2	.2096	.2012	.2286	.2263	.2286	.2286	.2427
3	.2096	.2033	.2286	.2263	.2286	.2286	.2427
4	.2096	.2075	.2286	.2263	.2286	.2286	.2263
5	.2096	.2241	.2286	.2263	.2286	.2286	.2263
6	.2096	.2075	.2286	.2452	.2286	.2286	.2263
7	.1886	.2096	.2286	.2263	.2286	.2477	.2263
8	.1905	.2054	.2286	.0777	.2096	.2286	.2263
9	.2263	.2075	.2286	.0274	.2096	.2477	.2075
10	.2241	.2058	.2614	.2477	.2286	.2614	.2587
11	.2218	.2286	.2427	.1524	.2286	.2427	.2427
12	.2427	.2096	.2241	.1334	.2286	.2263	.2427
13	.2058	.2286	.2427		.2477	.2263	.2241
14	.2263	.2286	.2263		.2477	.2241	.2427
15	.2241	.2286	.2427		.2667	.2402	.2353
16	.2241	.2286	.2241		.2667	.2587	.2402
17	.2172	.2477	.2241		.2477	.2772	.2378
18	.2054	.2477	.2587		.2667	.2587	.2241
19	.2263	.2477	.2614		.2667	.2427	.2427
20	.2075	.2477	.2263		.2667	.2427	.2402
21	.2263	.2286	.2263		.2667	.2263	.2263
22	.2263	.2477	.2452		.2286	.2075	.1905
23	.2241	.2477	.2263		.2286	.1886	.2075
24	.2096	.2195	.2477	.2263	.2241	.2096	.2427
Max	.2427	.2477	.2614	.2477	.2667	.2772	.2587
Min	.1886	.2012	.2241	.0274	.2096	.1886	.1905
Avg	.2156	.2235	.2357	.1898	.2387	.2337	.2319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 203 / GHANWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.4973	.5716	.4525	.4001	.5906	.4572
2	.5415	.4784	.5144	.4207	.381	.5525	.4435
3	.5415	.4755	.4954	.4207	.381	.5525	.4435
4	.5487	.5068	.4954	.4344	.4001	.5716	.439
5	.5973	.5975	.5716	.4835	.4191	.6478	.4706
6	.6767	.5658	.6668	.6268	.4572	.6859	.6036
7	.6626	.6733	.7049	.6379	.5906	.724	.6335
8	.6516	.6613	.724	.6104	.6478	.7049	.5434
9	.6133	.663	.6859	.6203	.724	.6478	.5658
10	.5935	.7186	.5487	.6274	.8002	.5801	.6443
11	.5658	.6859	.5304	.5571	.724	.4973	.6173
12	.6036	.5906	.5571	.583	.6668	.5365	.5761
13	.5548	.5906	.4862		.6287	.5365	.6173
14	.6371	.5716	.4801		.6287	.5426	.5201
15	.5765	.5716	.5144		.6097	.4207	.5731
16	.5801	.5906	.4748		.6097	.5087	.5316
17	.5765	.6097	.4694		.6287	.4854	.5847
18	.5197	.6668	.4372		.6478	.5304	.5182
19	.6661	.743	.6068		.8002	.7011	.6952
20	.7973	.8002	.7619		.8764	.7421	.7701
21	.7164	.7621	.691		.8573	.7421	.724
22	.6767	.6668	.6036		.7049	.6468	.6767
23	.6401	.6097	.5068		.6287	.5611	.5434
24	.567	.5731	.5716	.4656		.6097	.4938
Max	.7973	.8002	.7619	.6379	.8764	.7421	.7701
Min	.5197	.4755	.4372	.4207	.381	.4207	.439
Avg	.6108	.6196	.5696	.5339	.6179	.5966	.5703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 201 / 11 KV PARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3043	1.2574	1.2955	1.2955	1.3527	1.2193	1.3107
2	1.2955	1.2193	1.2574	1.2574	1.2193	1.2003	1.2765
3	1.2574	1.2002	1.2384	1.2383	1.2002	1.1621	1.2574
4	1.2383	1.2574	1.2193	1.2193	1.2002	1.1621	1.2384
5	1.2879	1.2574	1.2002	1.2269	1.2003	1.2193	1.2384
6	1.0098	1.3819	1.3717	1.355	1.3145	1.2383	1.3184
7	1.5768	1.4621	1.5242	1.4305	1.4503	1.486	1.3996
8	1.5242	1.4567	1.3908	1.3832	1.0856	1.4289	1.4503
9	1.4289	1.3501	1.2738	.8192	1.0356	1.3407	1.3228
10	1.2803	1.1822	1.0888	.9904	.7293	1.326	1.2955
11	1.0631	1.3096	1.1079	1.145	1.2345	1.2117	1.1622
12	1.4173	1.281	1.126	1.2765	1.2501	1.2422	1.124
13	1.2613	1.0025	1.2593	1.2167	1.2501	1.2348	1.2193
14	.9853	1.3106	1.2403	.8764	1.3487	1.1967	1.2002
15	1.3836	1.4248	1.165	.9145	1.4114	1.209	1.2193
16	1.4261	1.3717	1.1294	.8573	1.4582	1.1557	1.1812
17	1.4451	1.3337	1.1149	.8954	1.2955	1.1809	1.086
18	1.4503	1.3146	1.105	.8573	1.2384	1.2094	1.1241
19	1.6457	1.4289	1.3336	.9526	1.467	1.2985	1.448
20	1.3229	2.0386	1.8648	1.4289	1.5051	2.0163	2.015
21	1.9414	1.9623	1.8141	1.4098	2.0767	1.9388	1.9029
22	1.8517	1.7337	1.7009	1.3527	1.8099	1.7576	1.72
23	1.5242	1.5432	1.4971	1.4479	1.5432	1.5455	1.4971
24	1.3679	1.3337	1.3908	1.2765	1.3146	1.3527	1.2574
Max	1.9414	2.0386	1.8648	1.4479	2.0767	2.0163	2.015
Min	.9853	1.0025	1.0888	.8192	.7293	1.1557	1.086
Avg	1.3871	1.3922	1.3212	1.1718	1.3330	1.3472	1.3444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 202 / 11 KV PARE AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.5155	.0381	.0381	.0572	.0381	.4999
2	.4744	.506	.0381	.0381	.0572	.0381	.4744
3	.4744	.4877	.0381	.0381	.0572	.0381	.4744
4	.5401	.5535	.0381	.0381	.0572	.0381	.4744
5	.578	.5921	.0381	.0572	.0572	.0572	.4999
6		.4725	.0381	.0572	.0572	.0572	.6718
7	.953	.7468	.0381	.0762	.0572	.0762	.9297
8	.0381	.0381	.0381	.0572	.0762	.0572	.0381
9	.0381	.0381	.9877		1.3565	1.0957	.0381
10	.0381	.0381	.8905	1.0936	1.2346	***	.0381
11	.0381	.0381	.6958	1.0669	1.1873	1.2176	.0381
12	.0381	.0381	.6483		1.1702	1.2003	.0381
13	.0381	.0381	.9414		1.1248	1.1873	.0381
14	.0572	.0381	.9907		1.034	1.0753	.0381
15	.0381	.0381	1.0517		1.0467	.9998	.0381
16	.0572	.0381	1.0517		.9842	.9962	.0381
17	.0572	.0572	.0572		.0572	.0572	.0572
18	.0572	.0572	.0572		.0762	.0572	.0572
19	.0572	.0381	.0572		.0762	.0572	.0572
20	.0572	.0572	.0572		.0762	.0572	.0572
21	.0572	.0381	.0572		.0572	.0572	.0381
22	.6019	.0381	.0572		.0572	.5093	.5967
23	.578	.0381	.0572	.0572	.0572	.5624	.6554
24	.5468	.5247	.0381	.0381	.0572	.0572	.0381
Max	.953	.7468	1.0517	1.0936	1.3565	10.9427	.9297
Min	.0381	.0381	.0381	.0381	.0572	.0381	.0381
Avg	.2568	.2111	.3334	.2213	.4221	.8554	.2469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 203 / 11 KV GHOTI (BK) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5535	.4374	.1143	.1143	.1334	.1143	.6081
2	.4902	.4534	.1143	.0953	.1334	.0953	.6081
3	.4938	.4321	.0953	.0953	.1143	.0953	.583
4	.4999	.4531	.0953	.0953	.1334	.0953	.583
5	.6401	.506	.0953	.1143	.1334	.1334	.6478
6		.6249	.1715	.1524	.1524	.1905	.8322
7	.7716	.7432	.1715	.1715	.1143	.1524	.8124
8	.1334	.1334	.1524	.1524	.1334	.1524	.1334
9	.1334	.1715	.9842		.6562	.9217	.1143
10	.0953	.1334	.9014	.933	.8124	.9259	.0762
11	.0762	.1143	.9014	.8642	.9172	.8905	.0762
12		.1143	.9172		.8642	.8907	.0953
13		.1143			.828	.8482	.1143
14		.0953	.8697		.8333	.8002	.0953
15	.1143	.0953	.8539		.8592	.9217	.1143
16		.0953	.9722	.5468	.8223	.8962	.1143
17	.1524	.1143	.7682	.1334	.1143	.1143	.1334
18	.1905	.1334	.1524	.1143	.0953	.1143	.1524
19	.1524	.1524	.1715	.2096	.2096	.1524	.2096
20	.1905	.2096	.2286	.2096	.2286	.2096	.2286
21	.1905	.2096	.2096	.2096	.2286	.2286	.2096
22	.6167	.1715	.1905	.1715	.1905	.703	.7701
23	.5155	.1334	.1334	.1334	.1334	.6325	.8002
24	.5921	.4586	.1334	.1143	.1334	.9217	.6325
Max	.7716	.7432	.9842	.933	.9172	.9259	.8322
Min	.0762	.0953	.0953	.0953	.0953	.0953	.0762
Avg	.3475	.2625	.4086	.2437	.3739	.4667	.3644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 kv 5MVA VITA NEW S/STN

Feeder No / Name : 201 / 11 KV Harewadi URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4508	.4681	.4207	.4801	.4298	.4908	.4801
2	.4382	.4784	.4207	.4854	.4163	.4557	.4854
3	.4252	.4656	.3988	.4557	.4163	.4557	.4458
4	.4252	.4557	.037	.4508	.4298	.4607	.4607
5	.4382	.463	.3988	.463	.3898	.4961	.4733
6	.4382	.4854	.3988	.4681	.3681	.5316	.463
7	.5935	.503	.4049	.5079	.4862	.6226	.5636
8	.5535	.5967	.4374	.5344	.4744	.7186	.5921
9	.4915	.6081	.502	.547	.6299	.663	.6081
10	.5636	.6299	.547	.6613	.6706	.7293	.4973
11	.7373	.7291	.663	.6371	.6539	.7293	.6226
12	.6859	.6299	.6299		.788	.7209	
13	.6464	.5407	.6133		.5407	.5121	.6464
14	.6613	.6796	.7209		.5407	.5801	.7545
15	.703	.663	.6706		.6882	.639	.8048
16	.6796	.6464	.7045			.6964	.8002
17	.788	.6299	.2241		.6133	.7522	.8322
18	.7362	.6299	.6562		.4801	.7522	.7811
19	.7377	.5407	.6299		.5281	.7842	.7362
20	.6274	.3688	.6371		.6613	.7293	.7042
21	.583	.4557	.5935		.6173	.7377	.663
22	.5895	.4607	.5959		.7011	.6762	.7202
23	.5609	.4784	.5375		.6485	.6104	.6135
24	.4733	.4854	.4382	.4973	.4252	.5434	.5087
Max	.788	.7291	.7209	.6613	.788	.7842	.8322
Min	.4252	.3688	.037	.4508	.3681	.4557	.4458
Avg	.5845	.5455	.5117	.5157	.5477	.6286	.6199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-APR-17 and 07-APR-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 248001 / 220/33 Vita Karve

Feeder No / Name : 401 / 33KV VITA INCOMING

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17	05-APR-17	06-APR-17	07-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	28.4637	27.8464	29.5611	***	27.2291	***	27.3663
2	28.0522	28.5323	29.1496	29.4925	26.2003	***	28.1208
3	27.8464	27.9836	28.8066	28.738	26.1317	***	27.7778
4	27.2291	27.2291	28.1208	28.1208	24.2799	***	26.8862
5	27.3663	26.749	28.2579	27.6406	24.8286	***	26.5432
6	29.1496	27.0919	***	29.6983	26.749	***	27.7778
7	***	***	***	***	***	***	***
8	25.583	24.2113	24.8972	21.5364	21.8107	25.8574	25.1029
9	***	***	***	26.3375	***	***	***
10	***	***	***	25.3087	***	***	***
11	***	***	***	25.7888	***	***	***
12	***	***	***	25.583	***	***	***
13	***	***	***	11.5226	***	***	***
14	***	***	***	11.0425	***	***	***
15	***	***	***	11.1797	***	***	***
16	***	***	***	24.76	***	***	***
17	29.081	29.9726	27.0234	17.6955	29.7668	28.2579	29.8354
18	29.3553	28.6694	26.2003	16.3923	27.9836	28.5323	28.8066
19	28.9438	26.8176	27.9836	18.3814	27.0234	29.4239	29.904
20	***	***	***	21.5364	***	***	***
21	27.915	27.0919	28.8752	21.6736	28.3951	28.8752	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	29.3553	***	***	***
Max	50.0001	50.0687	39.6434	33.059	41.0151	42.2497	49.1084
Min	25.583	24.2113	24.8972	11.0425	21.8107	25.8574	25.1029
Avg	34.7223	34.6080	32.5018	24.0884	32.1217	33.4248	34.8794