

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 201 / 11KV GANESHWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0938	4.4596	2.0409	2.0271	2.1308	.8947	.8947
2	4.1214	4.4018	2.018	2.0607	2.1536	.9069	.9023
3	4.3012	4.3712	2.1628	2.1475	2.2283	.9221	.9221
4	4.3104	4.548	2.303	2.2558	2.3243	.9556	.9526
5	4.7218	4.926	2.4722	2.4219	2.5377	.9739	.9785
6	5.5114	5.5448	2.8532	2.8669	2.8959		1.0059
7	6.6148	6.7246	3.5162	3.3349	3.8363		
8	7.441	7.3008	3.7479	3.7525	4.0482		
9	7.3282	7.1118	5.7781	3.9079	4.0345		
10		1.5454					
11		1.576				2.3365	
12		1.646				4.3103	3.7982
13		1.6278				4.0375	3.8074
14		1.64				3.9064	3.7921
15		1.643				3.7708	3.7357
16		1.637				3.7845	3.7479
17	.1586	1.6308	.4801	.2759	.4618	3.4583	3.8043
18	1.707	1.6704	.8276	.8109	.8322	3.4919	3.8531
19	1.573	1.7742	.9054	1.3584	.8855	3.1474	3.693
20	1.0852	1.7864	.9206	.9236	.8947	.9297	.8977
21	1.7224	1.7254	.852	.8703	.8825	.9069	.8733
22	1.6918	1.704	.8261	.8627	.8718	.8901	.8566
23	3.344	2.396	1.7391	1.2224	.8871	.8993	.884
24	4.417	4.103	2.0942	3.6447	2.7793	.9023	.8871
Max	7.441	7.3008	5.7781	3.9079	4.0482	4.3103	3.8531
Min	.1586	1.5454	.4801	.2759	.4618	.8901	.8566
Avg	3.7731	3.2289	2.0904	2.0438	2.0403	2.1803	2.1203

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 202 / 11 KV SONAI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
8	2.0119		
19		2.0119	
24		1.086	1.0974
Max	2.0119	2.0119	1.0974
Min	2.0119	1.086	1.0974
Avg	2.0119	1.5490	1.0974

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 203 / 11 KV HANUMANWADI  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
9	1.0669		
19		.2401	
24		.9145	.8907
Max	1.0669	.9145	.8907
Min	1.0669	.2401	.8907
Avg	1.0669	.5773	.8907

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 204 / 11 KV MSSK

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	17-FEB-17
HR	Load (MW)
11	.0549
Max	.0549
Min	.0549
Avg	.0549



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 205 / 11 KV SHINGNAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
9	1.5242		
19		.3772	
24		1.0669	1.2146
Max	1.5242	1.0669	1.2146
Min	1.5242	.3772	1.2146
Avg	1.5242	.7221	1.2146

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 206 / 11 KV WANJARWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
12	1.6766		
19		1.5242	
24		.2267	.2401
Max	1.6766	1.5242	.2401
Min	1.6766	.2267	.2401
Avg	1.6766	.8755	.2401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 207 / 11 KV BELHEKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-FEB-17
HR	Load (MW)
24	.2439
Max	.2439
Min	.2439
Avg	.2439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 208 / 11 KV LOHAGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
12	3.2007		
19		2.6673	
24		.1619	.1715
Max	3.2007	2.6673	.1715
Min	3.2007	.1619	.1715
Avg	3.2007	1.4146	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 209 / 11 KV DHANGARWADI  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
12	2.0576		
19		1.829	
24		.3239	.3429
Max	2.0576	1.829	.3429
Min	2.0576	.3239	.3429
Avg	2.0576	1.0765	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 210 / 11 KV LANDEWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9704	3.8592	1.8214	1.8359	1.7711	.4626	.4824
2	3.8988	3.7844	1.8023	1.8221	1.749	.471	.4938
3	3.9048	3.716	1.7741	1.8435	1.7314	.4809	.5045
4	3.8744	3.7296	1.7977	1.7924	1.7787	.503	.5228
5	4.0542	3.8698	1.9212	1.9044	1.9326	.5106	.5479
6	4.3622	3.9278	2.069	2.0409	2.1018	.2553	.551
7	5.208	4.6152	2.5522	2.5972	2.6597	.0053	.0046
8	6.249	5.5952	2.9043	3.1299	3.1482		.0069
9	6.5966	5.3956	4.8202	3.0994	3.2228	.0008	.0038
10	.6584	1.2072			.1692		.0046
11		.9404				.0739	.0008
12		.8414				3.2716	1.5615
13		.8338				3.2846	3.2015
14		.82				3.2838	3.1375
15	.0076	.826				3.219	2.6673
16	.0122	.8246				3.1885	2.8837
17	.0138	.8368				3.1642	2.9713
18	.8582	.855	.407	.4367	.4306	3.1893	2.966
19	.983	.9298	.4496	.8471	.474	2.9988	2.9706
20	1.0394	1.0638	.5228	.5144	.538	.5388	.5129
21	1.0318	1.0624	.5205	.5159	.5304	.5396	.519
22	1.047	1.0196	.503	.5129	.5197	.5312	.5197
23	1.0166	.9908	.6264	.4931	.5014	.5235	.5068
24	3.8348	3.6016	1.8198	2.9888	1.9186	.4778	.4565
Max	6.5966	5.5952	4.8202	3.1299	3.2228	3.2846	3.2015
Min	.0076	.82	.407	.4367	.1692	.0008	.0008
Avg	2.6311	2.2978	1.6445	1.6484	1.4810	1.4079	1.1666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 211 / MORECHINCHORE GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.2561		
19		.2378	
24		.1463	.128
Max	.2561	.2378	.128
Min	.2561	.1463	.128
Avg	.2561	.1921	.128

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 203 / 11 KV SHASTRINAGAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7901	1.387	1.4937		2.0153	
2	1.757	1.387	1.4937	1.6289	1.9433	
3	1.7368	1.6004	1.6156		1.9595	.1372
4	1.7695	1.6766	1.7223		1.9757	
5	1.8187	1.7528	1.89		2.0965	
6	1.9757	1.7985	1.9966		1.9766	
7	2.2119	2.1338	2.2862		2.4985	
8	2.5286		2.3777		2.4669	
9	1.9925					
12						3.0121
15					.061	
19		.1524		.1509	.1372	
20	.1715	.1715		.1509		
21		.1715		.1509	.1696	
22	.0983	.1372		.1132		
23	.0914	.1357		.0943	.1357	
24	1.6057	1.3413	1.5043	1.5432	1.7695	.1372
Max	2.5286	2.1338	2.3777	1.6289	2.4985	3.0121
Min	.0914	.1357	1.4937	.0943	.061	.1372
Avg	1.5037	1.0651	1.8200	.5475	1.4773	1.0955



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 204 / 11 KV KAUTHA MIRI ROAD(AG) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0467	.9999	.5609	.5563	1.0452	.0549	1.5028
2	1.0742	1.0425	.5792	.567	1.0589		1.4556
3	1.0101	.9785	.4557	.3429	.9553		1.3931
4							1.4891
5							1.7314
6							2.0195
7							4.9101
8							5.2218
9						2.1822	2.1567
11	2.6703	2.3533	1.4723	2.3503	2.6292		
12	5.487	4.9291	5.0141	4.9795	5.4115		
13	2.9264	4.8392	2.6505	5.0133	2.2283		
14	5.5075	4.795	4.5363	5.0726	4.1724		
15	2.8182	4.7294	2.4066	4.5984	4.4064		
16	2.8685	4.5862	2.5042	4.4452	2.3426		
17	4.8864	4.6289	1.2635	4.9153	2.4661		
18	2.6536	4.5618	2.745	4.9585	4.4719		
19	3.7609	1.0623	1.7543	4.2032	3.6024	.3185	.0838
20	1.3098	.4572	.7179	1.3537	.6737	.3414	1.2623
21	.6508	1.0653	.6874	1.3135	1.108	.2774	.6341
22	1.1785	1.0486	.631	1.1195	.474	.2073	.8231
23	1.0456	1.0333	.5685	1.0778	1.6697	1.1081	.6914
24	1.0324	.9846	.9679	.887	1.9124	1.4845	1.5829
Max	5.5075	4.9291	5.0141	5.0726	5.4115	2.1822	5.2218
Min	.6508	.4572	.4557	.3429	.474	.0549	.0838
Avg	2.4663	2.5938	1.7362	2.8091	2.3899	.7468	1.7972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 205 / 11 KV WANJOLI EXPRESS      NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING      UTILITY

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0514	.0152		.0549		
2	.0187	.0514	.0152		.0543		
3	.0187	.0514	.0179		.0549		
4	.0187	.0514	.0171		.0549		
5	.0373	.0514	.0179		.0732		
6	.0549	.0514	.0171		.0716		
7	.0543	.017	.0857	.0171	.0532		.0343
8	.0886	.0857	.0857		.0532	.0152	
9	.1063	.0876	.0857	.0514		.0514	
10		.1029					
11		.1029	.1372	.0724		.0857	
12	.0857	.1029		.0724	.0857		.0886
13		.1029		.0709			
14		.1029	.0857	.1063			
15		.1029		.1063			
16		.1029		.1063			
17	.0914	.1029		.104			
18		.1017		.0709			
19	.0514	.0857		.0905	.1357		
20	.0686	.0857					.0532
21		.0857		.0732	.0171		
22	.0171	.0514		.0754			.0543
23	.0686	.0514		.0747	.0171		.0554
24	.0549	.0514	.0171	.0171	.0543	.0457	.0857
Max	.1063	.1029	.1372	.1063	.1357	.0857	.0886
Min	.0171	.017	.0152	.0171	.0171	.0152	.0343
Avg	.0545	.0765	.0498	.0739	.0600	.0495	.0619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 206 / 11 KV CHANDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3479	.4321	.3963		.3321		
2	.3479	.4481	.381		.3321		
3	.3479	.4641	.381		.3321		
4	.3906	.5121	.4572		.3637		
5	.463	.6401	.5944		.4321		
6	.679	.7042	.7316		.6944		.8573
7	.7716	.7682		.7888	.7432		
8		.8002				.8573	
9	.6019	.7202	.7011	.7716		.7716	
10		.5487					
11		.4572	.6001	.5182			
12		.3963		.5182	3.2579		
13		.4115					
14		.3963					
15		.4115					
16		.4572		.442			
17		.4877		.535			
18				.8421			
19	.8745	.8383		.8421	.8573		
20	.823	.823		.7773			.8065
21		.7621		.5937	.5487		.6167
22	.5658	.7011		.5218			.5992
23	.4481	.4572		.4744	.4287		.502
24	.3321	.4481	.4268	.4458	.3479		.463
Max	.8745	.8383	.7316	.8421	3.2579	.8573	.8573
Min	.3321	.3963	.381	.442	.3321	.7716	.463
Avg	.5379	.5689	.5188	.6208	.7225	.8145	.6408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 207 / 11 KV GHODEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4586	.4801	.4115		.4534		
2	.4696	.4321	.4115		.4372		
3	.4534	.4161	.4268		.4372		
4	.4744	.4801	.5182		.4586		
5	.5535	.6401	.6249		.5376		
6	.787	.7202	.884		.7432		.7716
7	.8642	.8002		.8573	.8179		
8	.9014	.8962			.8488	1.0288	
9	.8025	.7682	.8383	.7716		.7926	
10		.6401					
11		.6097	.7202	.7407			
12		.5182		.5556	.4973	.6001	.503
13		.4572		.5182			
14		.4268	.6173	.4725			
15		.4572					
16		.4877					
17		.5487				.6859	
18		.5487		.7116	.6687		
19	.7545	.6859		.8381	.8916		
20	.7373	.6554		.8097			.8855
21		.6097		.6483	.7545		.8697
22	.6173	.5487		.6154			.7274
23	.4801	.442		.502	.5144		.583
24	.4725	.4801	.4115	.463	.4534		.4801
Max	.9014	.8962	.884	.8573	.8916	1.0288	.8855
Min	.4534	.4161	.4115	.463	.4372	.6001	.4801
Avg	.6305	.5729	.5864	.6542	.6081	.7769	.6886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 201 / 11 KV Wadala NO.1

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4321	.4428	.4321	.884
Max	.4321	.4428	.4321	.884
Min	.4321	.4428	.4321	.884
Avg	.4321	.4428	.4321	.884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 202 / 11 kv tamaswadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.698	1.7406	.7606	.8612	.9038	.3368	.3673
2	1.6948	1.7376	.7545	.8794	.9114	.2713	.3932
3	1.7588	1.7344	.7804	.8718	.9191	.3155	.4207
4	1.8748	1.7528	.7788	.8779	.9358	.381	.439
5	1.9266	1.9234	.8444	.9145	.9968	.4603	.5228
6	2.1156	2.2588	1.0075	1.0639	1.1157	.2728	.3155
7	2.4234	2.7892	.8002	1.23	1.2864		
8	2.5332	2.8106	1.1584	1.2788	.6737		
9	1.4296	1.3412	.7987	.6417	.6569		
10		.4968					
11		.4938				1.1142	1.169
12		.3718				1.1873	1.2711
13		.2926				1.1736	1.2559
14		.195				1.0913	1.2483
15		.2378				1.0806	1.2132
16		.3078				1.0974	1.2087
17		.3384				1.1111	1.2376
18	.9572	.9632	.029	.5243	.4344	1.1294	1.2498
19	1.1888	1.2924	.7225	.7072	.6005	.506	.6752
20	1.2438	1.1522	.6737	.6965	.5396	.6264	.4893
21	1.1248	1.07	.5883	.599	.5274	.4908	.4009
22	1.015	.8474	.4496	.5106	.4786	.378	.3292
23	1.5334	1.4998	.8002	.823	.3978	.3795	.2896
24	1.771	2.1685	1.4769	1.5287	1.0333	.6782	.5941
Max	2.5332	2.8106	1.4769	1.5287	1.2864	1.1873	1.2711
Min	.9572	.195	.029	.5106	.3978	.2713	.2896
Avg	1.6431	1.2423	.7765	.8755	.7757	.7041	.7545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 203 / 11 kv rastapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2986	1.2406	.6203	.5959	.6432	1.8427	.3871
2	1.3566	1.2742	.6859	.6569	.6798	1.9006	2.079
3	1.4388	1.4662	.7468	.7621	.7484	2.0165	2.1917
4	1.8626	1.7864	.8871	.8733	.9099	2.1155	2.303
5	2.0484	2.0576	.724	1.0578	1.07	2.1414	2.4981
6	.8078	.7986		.4984	1.1401	2.6597	2.8669
7					.3079	3.2769	3.754
8						3.594	3.5742
9						.9892	1.4053
11	6.5326	6.2886	3.1809	3.2968	3.2922		
12	7.2276	7.261	3.2815	3.7769	3.4736		
13	6.8984	7.2184	3.0879	3.7388	3.5025		
14	6.7398	6.9654	3.0041	3.7159	3.3257		
15	6.746	6.9562	3.4034	3.7342	3.4705		
16	6.8404	6.9684	3.3577	3.5726	3.5132		
17	6.496	6.944	3.3913	3.5985	3.2449		
18	6.4014	7.0324	3.3653	3.6199	3.1977	.724	.7545
19	3.1032	2.8716	1.6613	1.6842	1.3855	1.1492	1.0212
20	1.9722	1.8108	.9953	.9755	.977	1.1142	.9526
21	1.7102	1.6156	.8215	.8093	.7895	.8444	.8185
22	1.512	1.5028	.7118	.6767	.6752	.6996	.7225
23	1.2254	1.32	.5975	.6097	1.6674	1.2879	1.9281
24	1.201	1.5897	.8499	.599	2.2009	.884	2.3655
Max	7.2276	7.261	3.4034	3.7769	3.5132	3.594	3.754
Min	.8078	.7986	.5975	.4984	.3079	.6996	.3871
Avg	3.6710	3.7484	1.8618	1.9426	1.9150	1.7025	1.8514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 205 / 11 KV Bhairawanath  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.3125	.3048	1.1584
Max	.3125	.3048	1.1584
Min	.3125	.3048	1.1584
Avg	.3125	.3048	1.1584



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 206 / 11 KV Nipani Nimgaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.1888	1.1279	1.0364	.3048	.3258
Max	1.1888	1.1279	1.0364	.3048	.3258
Min	1.1888	1.1279	1.0364	.3048	.3258
Avg	1.1888	1.1279	1.0364	.3048	.3258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 207 / 11 KV Sajalpur

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1829	.2561	.1696	.1677	.3395
Max	.1829	.2561	.1696	.1677	.3395
Min	.1829	.2561	.1696	.1677	.3395
Avg	.1829	.2561	.1696	.1677	.3395

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 208 / 11 KV MaliChinchora

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1829	.2012	.1753	.2254	.3961
Max	.1829	.2012	.1753	.2254	.3961
Min	.1829	.2012	.1753	.2254	.3961
Avg	.1829	.2012	.1753	.2254	.3961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 209 / DHRUVTARA EXPRESS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1494	.0739	.1753	.1267	.181
Max	.1494	.0739	.1753	.1267	.181
Min	.1494	.0739	.1753	.1267	.181
Avg	.1494	.0739	.1753	.1267	.181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 210 / 11 KV RASTAPUR NO 2 SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.3239	.3401	.3201	1.0059
Max	.3239	.3401	.3201	1.0059
Min	.3239	.3401	.3201	1.0059
Avg	.3239	.3401	.3201	1.0059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 211 / NATH BABA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.9412	1.1405	1.0364	.2846	.2058
Max	.9412	1.1405	1.0364	.2846	.2058
Min	.9412	1.1405	1.0364	.2846	.2058
Avg	.9412	1.1405	1.0364	.2846	.2058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 212 / LAKHEFAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.6859	.4687	.6706	.1524	.2591
Max	.6859	.4687	.6706	.1524	.2591
Min	.6859	.4687	.6706	.1524	.2591
Avg	.6859	.4687	.6706	.1524	.2591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 201 / 11 kv deogaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2003	.9259	.8573	.2229
2		1.2003	.9259	1.0288	.2229
3		1.2003	.9259	1.1145	.2229
4		1.3032	1.0288	1.2003	.0223
5		1.5432	1.1317	1.286	.2401
6		1.7147	1.2346	.1715	
7		1.749	1.7147	1.9719	
8		1.9204	1.7147	1.9719	
9		1.869	1.5432	1.7147	
19		.3086	.2572		
20		.3086	.2572		
21		.2229	.2572		
22		.2229	.1715	.0291	
23	.2229	.2058	.1715	.2401	.2572
24		1.1145	.823	.2229	.2229
Max	.2229	1.9204	1.7147	1.9719	.2572
Min	.2229	.2058	.1715	.0291	.0223
Avg	.2229	1.0722	.8722	.9841	.2016



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 202 / 11 kv shahapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-FEB-17
HR	Load (MW)
23	.3944
24	.3944
Max	.3944
Min	.3944
Avg	.3944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 205 / 11 kv fattepur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1372	.1372	.1715	1.0702
2			.1372	.1372	.1715	1.0631
3			.1372	.1372	.1715	1.0631
4			.1543	.1543	.1717	1.166
5			.1715	.2058	.1715	1.2517
6						1.2689
7						1.6804
8						2.1776
12	2.2291		2.2977		2.332	
13	2.4691		2.332		2.4006	
14	2.5034		2.2634	2.572	2.5034	
15	2.572		2.1948	2.5034	2.5377	
16		2.1434	2.1948	2.332	2.5034	
17		2.2634	2.3148	2.4006	2.5377	
18			2.3148	2.4006	2.2462	
19		2.1948	2.0405	2.1434		
20		.2058	.1886	.1715	.1715	
21		.1886	.1715		.1372	
22		.1886			.12	
23		.1715	.1372	.1715	.12	
24			.1372	.1372	2.0576	1.0631
Max	2.572	2.2634	2.332	2.572	2.5377	2.1776
Min	2.2291	.1715	.1372	.1372	.12	1.0631
Avg	2.4434	1.0509	1.1367	1.1146	1.2074	1.3116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 206 / 11 kv dedgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3086	.3429	.2572	.7545
2			.3086	.3429	.2572	.7545
3			.3086	.3429	.2572	.7545
4			.3429	.3429	.3429	
5			.4115	.4115	.3429	.8573
6						.9259
7						1.3717
8						1.7147
12	2.0576	1.7147	1.7833		1.8861	
13	2.1262	1.6289	1.7147		1.9204	
14	1.8861	1.7147	1.8176	1.7833	1.8176	
15	1.9547	1.7147	1.749	1.7147	1.8176	
16		1.7147	1.7147	1.7147	1.7147	
17		1.7147	1.7147	1.7147	1.8176	
18		1.7147	1.749	1.7147	1.749	
19		1.4403	1.5432	1.3717	1.5089	
20		.4115	.5316		.4458	
21		.4115	.4115		.3772	
22		.3772	.3429		.3429	
23		.3429	.3429	.2572	.3086	
24			.3086	.3429	.2572	.6516
Max	2.1262	1.7147	1.8176	1.7833	1.9204	1.7147
Min	1.8861	.3429	.3086	.2572	.2572	.6516
Avg	2.0062	1.2417	.9669	.9536	.9678	.9731

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 201 / 11 KV SHASHTRINAGAR 1 SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-FEB-17
HR	Load (MW)
24	.9065
Max	.9065
Min	.9065
Avg	.9065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 202 / 11 KV NEW CHANDA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)
8		1.8823
24	.2772	
Max	.2772	1.8823
Min	.2772	1.8823
Avg	.2772	1.8823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 203 / 11 KV MIRI ROAD 1

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)
8		1.2163
24	.1646	
Max	.1646	1.2163
Min	.1646	1.2163
Avg	.1646	1.2163

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 204 / 11 KV M.L.HIWARE 1 SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-FEB-17
HR	Load (MW)
24	.1478
Max	.1478
Min	.1478
Avg	.1478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 205 / 11 KV MAK A 1

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-FEB-17
HR	Load (MW)
24	.0924
Max	.0924
Min	.0924
Avg	.0924



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 201 / 11 KV SHINGANAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.8029	.7468	.7045	.7842		
2	.8402	.8402	.7468	.7045	.8029		
3	.8775	.8589	.7468	.7373	.8215	.5716	
4	.9335	.8962	.8402	.7865	.8589		
5	1.1016	.9709	.9709	.8684	.8962		
6	1.2883	1.1203	1.1389	.9503	1.0269		
7	1.4377	1.3817	1.2696	1.0562	1.307		
8	1.6244	1.643	1.4937	1.2193	1.4377		
9	1.5497	1.4377	1.475	1.1873	1.3032		
10		.3239					
11		.3239					
12		.2667				1.5123	1.531
13		.2667				1.5497	1.5684
14		.3048				1.5684	1.531
15		.3048				1.5684	1.4563
16	.4954	.3239	.3856	.4572		1.4563	1.475
17	.5144	.381	.4557	.4572		1.419	1.4937
18	.5144	.5906	.5609	.6097		1.419	1.531
19	.724	.7049	.6836	.7621	.743	1.3256	1.2136
20	.6859	.7049	.6836	.7811		.8002	.8002
21	.6478	.6859	.6447	.6668		.7621	.7621
22	.6287	.6097	.5731	.6287		.6668	.724
23	.5716	.4954	.4477	.5716	.463	.5906	.6335
24	.7888	.7842	.7468	.7045	.7655	.5716	
Max	1.6244	1.643	1.4937	1.2193	1.4377	1.5684	1.5684
Min	.4954	.2667	.3856	.4572	.463	.5716	.6335
Avg	.8896	.7093	.8117	.7696	.9342	1.1273	1.2267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 202 / 11 KV DEVSTHAN SHNGNAPUR NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0526	.0526	.0532	.0526		.0701
2	.0526	.0526	.0526	.0532	.0526		.0701
3	.0526	.0701	.0526	.0532	.0701	.0762	.0701
4	.0526	.0701	.0526	.0532	.0701		.0701
5	.0701	.0701	.0526	.0709	.0701		.0701
6	.0701	.0876	.0526	.0709	.0701		.0701
7	.0701	.0876	.0701	.0709	.0701		.0701
8	.0701	.0876	.0701	.0709	.0701		.0701
9	.0701	.0701	.0526	.0701	.0762	.0762	.0701
10	.0701	.0701	.0709	.0709		.0701	.0876
11	.0701	.0701	.0886	.0886		.0701	.0876
12	.0701	.0701	.0709	.0709		.0701	.0876
13	.0701	.0701	.0709	.0876		.0701	.0701
14	.0701	.0701	.0709	.0876		.0701	.0701
15	.0701	.0526	.0532	.0876		.0701	.0701
16	.0526	.0526	.0532	.0526		.0701	.0701
17	.0701	.0526	.0709	.0701		.0701	.0701
18	.0701	.0701	.0709	.0876		.0701	.0701
19	.0876	.0876	.0886	.1052	.0953	.1052	.1052
20	.0876	.0876	.0886	.0876		.1052	.1052
21	.0876		.0886	.0876		.0876	.1052
22	.0701	.0526	.0716	.0701		.0876	.0876
23	.0701	.0526	.0709	.0701	.0762	.0701	.0876
24	.0532	.0701	.0526	.0532	.0701	.0762	
Max	.0876	.0876	.0886	.1052	.0953	.1052	.1052
Min	.0526	.0526	.0526	.0526	.0526	.0701	.0701
Avg	.0679	.0686	.0662	.0727	.0703	.0774	.0785

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 203 / 11 KV PANASWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9616	1.7387	.3239	1.89	1.9022		
2	1.9616	1.7833	.3239	1.89	1.9319		
3	1.9913	1.813	.4001	1.9357	1.9616	.2667	
4	2.0805	1.8576	.4001	2.0119	2.0062		
5	2.2439	1.9319	.4763	2.1033	2.1102		
6	2.5114	2.1251	.5335	2.2253	2.3182		
7	2.7492	2.4669	.6097	2.4234	2.6155		
8	2.7046	.8471		2.7282	2.7492		
9	2.66	.7876		2.6825	2.987		
10		.2858					
11		.2096	2.4082				
12		.1905				2.6749	2.846
13		.1905				3.0464	2.6699
14		.1905				2.809	2.5966
15		.2286				2.8669	2.5966
16	.3239	.2286	.2408	.2477		2.8669	2.5673
17	.3239	.2667	.2559	.3048		2.9538	2.5526
18	.362	.381	.286	.381		2.9538	2.4939
19	.4382	.4382	.3311	.4763	.4954	2.7945	2.3619
20	.4382	.4382	.3612	.4572		.5335	.3658
21	.4191		.3437	.4191		.4062	.3506
22	.4001	.362	.3281	.381		.3749	.3048
23	.381	.3239	.2812	.3239	.3429	.3437	.2812
24	1.9867	1.709	.3239	1.89	1.8873	.2858	
Max	2.7492	2.4669	2.4082	2.7282	2.987	3.0464	2.846
Min	.3239	.1905	.2408	.2477	.3429	.2667	.2812
Avg	1.4410	.9041	.4840	1.3762	1.9423	1.7984	1.8323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 204 / 11 KV GHODEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239	.2858	.2439	.3239		
2	.3239	.3239	.2858	.0244	.3048		
3	.362	.3048	.3239	.2591	.3239	.7621	
4							.381
5							.381
6							.4268
7							.5335
8		.381					.5418
9		.381				.945	.4816
10		.2858			.7095		
11		.3048					
12	.7621	.6241	.4365	.587			
13	.8535	.6241	.6472	.6706			
14	.7926	.6093	.6773	.6859			
15	.7164	.5944	.6472	.6859			
16	.6859	.5796	.6171	.6401		.1524	.1524
17	.5792	.5647	.6321	.6554		.1677	.1677
18	.7011	9.4959	.602	.6401		.1677	.1829
19	.5487	.6093	.602	.6097	.5498	.2591	.3048
20	.4001	.4382	.3201	.381		.3353	.3048
21	.381	.362	.2968	.381		.3048	.2896
22	.381	.3239	.2812	.3429		.2743	.2656
23	.3429	.3239	.2812	.3239	.3547	.2343	.2343
24	.2591	.3429	.2858	.2591	.3239	.4877	
Max	.8535	9.4959	.6773	.6859	.7095	.945	.5418
Min	.2591	.2858	.2812	.0244	.3048	.1524	.1524
Avg	.5258	.8899	.4514	.4619	.4129	.3719	.3320

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 205 / 11 KV BARHANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4382	.4191	.3437	.4001		
2	.4001	.4191	.4191	.3437	.381		
3	.4382	.4191	.4572	.3749	.381	1.0669	
4							.7865
5							.7865
6							.8848
7							1.1469
8		.5716					1.3117
9		.381				1.8138	1.1822
10		.5335			1.1888		
11		.2667					
12	1.3765	1.0848	.7964	1.1873			
13	1.4251	1.0551	1.1873	1.3765			
14	1.3441	1.0402	1.2018	1.3603			
15	1.2955	1.0402	1.1728	1.3441			
16	1.3117	1.0402	1.1584	1.2631		.2401	.2572
17	1.2146	1.0416	1.1004	1.2955		.2572	.2915
18	1.3117	1.0402	1.0425	1.2146		.3429	.3258
19	1.0364	1.0122	.9829	1.1822	1.0848	.5316	.5316
20	.5144	.4763	.4515	.5335		.4801	.5144
21	.4954		.4801	.4954		.463	.4287
22	.4763	.4382	.4287	.4572		.3601	.2572
23	.4572	.4191	.4115	.4382	.3601	.3086	.2572
24	.3281	.4572	.4191	.3437	.4191	.7316	
Max	1.4251	1.0848	1.2018	1.3765	1.1888	1.8138	1.3117
Min	.3281	.2667	.4115	.3437	.3601	.2401	.2572
Avg	.8641	.6934	.7581	.8471	.6021	.5996	.6402

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 206 / 11 KV VITTHALWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1873	1.1004	1.1584	1.1279	.9701		
2	1.1873	1.1149	1.1294	1.1279	.9846		
3	1.2018	1.1294	1.1591	1.1584	1.0136	.4382	
4	1.2742	1.1584	1.2631	1.1888	1.0425		
5	1.4045	1.1873	1.3523	1.2498	1.0715		
6	1.6507	1.2308	1.448	1.3413	1.1294		
7	1.7665	1.4624	1.5203	1.5752	1.4624		
8	1.752	1.5348	1.6651	1.829	1.7231		
9	1.6651	1.7231	1.6362	1.8595	2.21		
10		.3429					
11		.3239					
12		.2858				1.709	1.7684
13		.2858				1.8576	1.8576
14		.2667				1.8278	1.813
15		.3048				1.8576	1.6644
16	.2477	.3429	.2107	.362		1.8724	1.709
17	.3048	.3239	.2559	.4382		1.8724	1.6941
18	.362	.4572	.3161	.5335		1.813	1.6347
19	.5716	.5716	.4214	.5906	.442	1.7387	1.46
20	.5716	.5525	.4365	.5335		.4268	.442
21	.5716	.5525	.4218	.5144		.4268	.4572
22	.5525	.4763	.3906	.4954		.3963	.442
23	.5335	.4572	.3593	.4572	.3944	.3749	.3906
24	1.2342	1.086	1.1584	1.1279	.9701	.4382	
Max	1.7665	1.7231	1.6651	1.8595	2.21	1.8724	1.8576
Min	.2477	.2667	.2107	.362	.3944	.3749	.3906
Avg	1.0022	.7613	.9057	.9728	1.1178	1.2178	1.2778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014161 / 33/ 11 KV MIDC Pandharipul

Feeder No / Name : 201 / 11 kv Spark

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0687	.019	.0876		
2	.0686	.019	.0701	.0876	
3	.0686	.019	.0701	.0701	
4	.0859	.019	.0701	.0701	
5	.0859	.019	.0526	.0701	
6	.0859	.019	.0526	.0701	
7	.0516	.019	.0526	.0701	
8	.0516	.0172	.0526	.0701	
9		.0175	.0701	.0526	
10	.0762	.0351	.0701		
11	.0762	.0351	.0701		
12	.0762		.0701		
13	.0762		.0701		
14	.0762		.0876		
15	.0762		.0701		
16	.0762		.0876		
17	.0762		.0876		
18		.0876	.1052		
19		.0876	.1227		
20		.0876	.0701		
21		.0876			
22		.0876			
23		.0876			
24	.0685	.019	.0876	.0876	.0701
Max	.0859	.0876	.1227	.0876	.0701
Min	.0516	.0172	.0526	.0526	.0701
Avg	.0732	.0435	.0751	.0720	.0701

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014161 / 33/ 11 KV MIDC Pandharipul

Feeder No / Name : 202 / 11 KV Ujjwal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0381	.035	.0175	.0351
2	.0171	.0381	.035	.0175	.0351
3	.0171	.0381	.035	.0175	.0351
4	.0171	.0381	.035	.0175	.0351
5	.0171	.0381	.035	.0175	.0351
6	.0171	.0381	.035	.0175	.0351
7	.0171	.0381	.035	.0175	.0351
8	.0171	.0381	.035	.035	.0351
9	.0173	.0525	.035	.035	
10		.0525	.035		
11	.0191	.0525	.035		
12	.0191	.0525	.035		
13	.0191	.0525	.035		
14	.0191	.0525	.035		
15	.0191	.0525	.035		
16	.0191	.0525	.0525		
17	.0191	.0525	.0525		
18		.035			
19		.035	.035		
20		.035	.0525		
21		.035			
22		.035			
23		.035			
24	.0172	.0381	.035	.0175	.035
Max	.0191	.0525	.0525	.035	.0351
Min	.0171	.035	.035	.0175	.035
Avg	.0179	.0427	.0376	.021	.0351



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014161 / 33/ 11 KV MIDC Pandharipul

Feeder No / Name : 204 / 11 KV Zapwadi AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.7354	.7793	1.2056	1.5518
2	.7011	.7179	.7274	1.3778	1.638
3	.7362	.7179	.71	1.5501	1.7587
4	.7712	.7354	.6754	1.8945	1.8966
5	.8063	.7529	.6927	2.0495	1.9631
6				2.239	2.191
7				3.1001	2.1553
8				3.0657	.0034
9				2.8418	
10			3.3757		
11			3.2379		
12	3.6808	3.3478	3.3757		
13	3.5056	3.4355	3.2379		
14	3.4705	3.4355	2.9624		
15		3.3653	3.1001		
16		3.3478	3.1001		
17	3.2076	3.1173	3.0829		
18		3.1173	2.9279		
19		2.7363	2.4629		
20		.6754	.6889		
21		.8313			
22		.8486			
23		.814			
24	3.3303	.7004	.7966	1.0334	1.085
Max	3.6808	3.4355	3.3757	3.1001	2.191
Min	.7011	.6754	.6754	1.0334	.0034
Avg	2.0911	1.8573	2.1138	2.0358	1.5825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 203 / TARAWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.9846	1.1751
2						.9998	1.1401
3						1.0197	1.1111
4		.0214	.0076	.0625	.0686	1.0029	1.1111
5	.3444	.3718	.1783	.1768	.1707	1.0669	1.1721
6	.375	.3872	.1722	.1707	.1875	1.1462	1.2833
7	.0214	.0366		.0091	.0137	1.4022	1.5516
8						1.7787	2.0317
9						1.8442	2.0851
10						.125	
11	.003						
12	4.1152	3.6672	1.9494	1.9784	2.0546		
13	4.5512	4.2188	2.0271	2.1826	2.1094		
14	4.484	4.161	2.0805	2.242	2.0881		
15	4.5816	4.225	2.1201	2.0835	2.0317		
16	4.6364	4.0238	2.2177	2.1811	2.0409		
17	4.5724	4.0726	2.1719	3.9278	2.0073		
18	4.106	3.9902	2.05	2.1293	2.0088		
19	3.9048	3.85	1.8564	1.9403	1.9052		
20	.3476	.3658	.1814	.1753	.1814	.1829	.2042
21	.3506	.378	.1875	.1936	.1738	.1799	.2088
22	.384	.3566	.1875	.1753	.1722	.192	.192
23	.3566	.3476	.1738	.1692	.1646	.1844	.1768
24	.0426		.0183	.0076	.945	1.1675	1.1172
Max	4.6364	4.225	2.2177	3.9278	2.1094	1.8442	2.0851
Min	.003	.0214	.0076	.0076	.0137	.125	.1768
Avg	2.1869	2.1546	1.0987	1.1650	1.0779	.8851	1.0400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 205 / GEVRAI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2237	2.2039	2.1216	2.2039	2.2268	.2317	.2667
2	2.3289	2.2268	2.1765	2.2984	2.2207	.2408	.2728
3	2.3884	2.2207	2.21	2.3396	2.1887	.2591	.2774
4	2.4006	2.1917	2.239	2.2771	2.2481	.2789	.2911
5		2.3122	2.3045	2.3914	1.9433	.3033	.3567
6	2.5682	2.4661	2.3152	2.5469	2.2298	.3292	.3765
7	2.7115	2.6886	2.8517	3.1459	2.7999		
8	3.1108	3.2663	3.1154	3.0819	3.28		
9	3.2221	3.2358	3.1398	4.635	3.3425		
11						.6508	
12						3.3364	3.2556
13						.6569	3.5178
14						3.2404	3.3852
15						3.1154	3.4797
16						3.0864	3.469
17						3.2632	3.5421
18						3.0483	3.3806
19	.0732	.0747	.0503	.064	.0594	3.0117	2.3442
20	.3871	.4283	.378	.4115	.4374	.4085	.4268
21	.3704	.4191	.3826	.4115	.4496	.4009	.3749
22	.3719	.3749	.3734	.3978	.3856	.3978	.3658
23	.6417	1.0532	.3399	.6447	.3429	.3765	.349
24	2.1338	2.0729	2.1353	2.0972	.2271	.2743	.2469
Max	3.2221	3.2663	3.1398	4.635	3.3425	3.3364	3.5421
Min	.0732	.0747	.0503	.064	.0594	.2317	.2469
Avg	1.7809	1.8157	1.7422	1.9298	1.6255	1.3455	1.5778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 206 / BHENDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-FEB-17
HR	Load (MW)
9	.6842
17	.4534
Max	.6842
Min	.4534
Avg	.5688

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 208 / GONDEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8024	.807	.4218	.3978	.407	1.8816	2.0428
2	.814	.8504	.423	.4332	.4184	1.8827	2.0851
3	.8414	.8574	.4287	.4561	.447	1.917	2.1251
4	.887	.9282	.4527	.4733	.4618	1.9444	2.1868
5	.974	1.0106	.4813	.5316	.487	2.0027	2.2702
6	1.038	1.0746	.5098	.5533	.5281	2.0965	2.5229
7						2.6955	3.1939
8						3.3711	1.9284
9						3.3573	.2721
11	.942	.5922	.3932	.5281	.6219		
12	6.5272	5.5258	3.6626	3.7414	3.5814		
13	4.6274	6.5364	3.8375	3.7952	3.7643		
14	6.8062	7.0988	3.6568	3.5848	3.5677		
15	7.46	6.9594	3.4134	3.4957	3.3219		
16	7.3182	7.0622	3.3116	3.4271	3.3653		
17	7.524	7.2772	3.5482	6.438	3.5368		
18	7.4142	7.0484	3.2556	3.3391	3.4979		
19	6.3626	6.038	3.0178	3.1539	3.1573	.0217	
20	1.0952	1.0996	.5476	.5464	.5578	.5476	.5807
21	1.022	1.038	.5338	.5258	.5396	.5041	.543
22	1.0174	1.0586	.5258	.5064	.4881	.4858	.471
23	.9786	1.022	.4915	.5075	.583	.5921	.575
24	.823	.8184	.3864	.415	1.7764	1.9879	1.9376
Max	7.524	7.2772	3.8375	6.438	3.7643	3.3711	3.1939
Min	.8024	.5922	.3864	.3978	.407	.0217	.2721
Avg	3.2637	3.2352	1.6650	1.8425	1.7554	1.6859	1.6239

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 209 / BHENDA .BK

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.553	2.5454	1.3291	1.3839	1.3748	.1456	.1288
2	2.6094	2.5698	1.3397	1.3893	1.4022	.1578	.1387
3	2.6718	2.6032	1.3542	1.3961	1.3832	.1677	.1486
4	2.678	2.5788	1.3893	1.4525	1.3504	.1783	.1616
5	2.7634	2.4768	1.4228	1.5394	1.4685	.1943	.1814
6	3.2602	2.8578	1.5958	1.6347	1.6789	.202	.1829
7	4.068	3.7556	1.7383	2.05	2.0904		
8	4.2112	4.2158	1.9303	2.2337	2.191		
9	4.0086	3.088	2.0485	3.9178	1.7048		
11						.5975	
12						2.1155	1.9303
13						2.2497	2.2443
14						2.431	2.2596
15						2.2992	2.2634
16						1.9745	2.2855
17						2.1209	2.2862
18						1.7284	2.1803
19	.2424	.2682	.1174	.112	.1219	1.7619	2.0279
20	.3642	.3918	.1852	.1852	.2119	.2134	.2065
21	.3476	.3688	.1745	.1837	.1898	.1928	.1867
22	.3598	.3582	.1837	.1776	.1859	.202	.1928
23	1.5912	2.1322	.9008	.9114	.1852	.1859	.1951
24	2.4996	2.4706	1.323	1.3763	.1448	.1372	.1349
Max	4.2112	4.2158	2.0485	3.9178	2.191	2.431	2.2862
Min	.2424	.2682	.1174	.112	.1219	.1372	.1288
Avg	2.2819	2.1787	1.1355	1.3296	1.0456	.9628	1.0177

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 210 / Bhanashiwra Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-FEB-17
HR	Load (MW)
9	.7522
17	.462
Max	.7522
Min	.462
Avg	.6071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 201 / WAKADI-1

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1456	.1539	.1395	.0953	.1097	1.0037	1.2803
2	.1456	.1524	.141	.096	.1113	.9953	1.3093
3	.1318	.1288	.1097	.0831	.1097	1.009	1.2475
4						1.0159	1.2376
5						1.07	1.3542
6						1.1683	1.4274
7						1.7253	2.0485
8						3.8031	2.2359
9						1.5402	1.6065
11	2.1003	2.0439	1.9456	1.9052	1.8778		
12	2.2024	1.9806	2.159	2.2093	2.1163		
13	2.2283	3.9971	1.9753	2.1346	3.5932		
14	2.0279	1.9639	1.8618	1.9913	1.7665		
15	1.8938	1.6011	1.7977	1.8602	1.6568		
16	1.9288	3.2362	1.784	1.7856	3.2922		
17	1.9143	1.8557	1.7962	1.7589	1.8176		
18	1.8846	1.8237	1.8397	1.7139	1.8031	.0282	.0328
19	1.3824	1.3961	1.1683	1.3032	1.4114	.1257	.1372
20	.2355	.2195	.1303	.157	.1943	.1219	.1501
21	.2096	.1882	.1204	.141	.141	.0953	.1174
22	.189	.1692	.1166	.1288	.1395	.0831	.0785
23	.1799	.1608	.1082	.1242	.9503	1.0425	1.2407
24	.157	.1425	.0991	.112	1.0151	1.1706	1.451
Max	2.2283	3.9971	2.159	2.2093	3.5932	3.8031	2.2359
Min	.1318	.1288	.0991	.0831	.1097	.0282	.0328
Avg	1.1151	1.2479	1.0172	1.0353	1.3003	.9999	1.0597



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 202 / SHIRASGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5394	1.6263	1.4845	1.3992	1.5623		
2	1.5516	1.6278	1.4998	1.4388	1.483		
3	1.5485	1.6339	1.4739	1.4236	1.4464		
4	1.5424	1.6309	1.4769	1.454	1.4373		
5	1.6598	1.6476	1.5165	1.5592	1.4617		
6	1.7772	1.7208	1.6476	1.6507	1.5181		
7	2.0698	2.0058	2.0881	1.9082	1.9982		
8	2.3	2.1704	4.3042	2.053	4.1781		
9	2.2375	2.1841	2.1856	1.7863	2.0424		
11						1.6568	1.5272
12						2.7755	2.7374
13						2.841	2.8075
14						2.5941	2.7359
15						2.5332	2.6063
16						2.5438	2.6627
17						2.6231	2.681
18						2.5545	2.4448
19						2.4387	1.9082
20							.1722
21							.1494
22							.1814
23	1.262	.9816	1.0547	1.0242			.1753
24	1.6034	1.4297	1.3214	1.4982			.1646
Max	2.3	2.1841	4.3042	2.053	4.1781	2.841	2.8075
Min	1.262	.9816	1.0547	1.0242	1.4373	1.6568	.1494
Avg	1.7356	1.6963	1.8230	1.5632	1.9031	2.5067	1.6396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 203 / RAMDOH

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)
8	1.5432	1.4575
Max	1.5432	1.4575
Min	1.5432	1.4575
Avg	1.5432	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 204 / WAKADI - 11

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	16-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
8			1.406
13	1.4575	1.3717	
16	1.3203	1.286	
Max	1.4575	1.3717	1.406
Min	1.3203	1.286	1.406
Avg	1.3889	1.3289	1.406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 205 / SHIRASGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.9602	1.0974	.9945
13	.2572		.3429	
16	.3086		.4115	
Max	.3086	.9602	1.0974	.9945
Min	.2572	.9602	.3429	.9945
Avg	.2829	.9602	.6173	.9945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 206 / 11kv warkhed  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						2.0355	1.6872
2						2.0332	1.6598
3						2.0012	1.7177
4						1.9989	1.7863
5						1.9989	1.8038
6						1.6766	1.7962
7						1.8519	1.7673
8						4.0634	1.8435
9						2.1407	1.8381
11	.2843	.1341	.3231	.061			
12	2.5438	1.9822	2.3541	2.2276	2.1735		
13	2.5309	4.6731	2.4425	2.3624	4.6563		
14	2.5126	2.3899	2.4006	2.489	2.4402		
15	2.5667	2.4135	2.3609	2.3061	2.4234		
16	2.3967	4.6647	2.2809	2.3388	4.6746		
17	2.5972	2.4707	2.3861	2.4006	2.5408		
18	2.5385	2.431	2.4554	2.447	2.5393		
19	2.3167	2.3213	2.412	1.5463	2.3914		
23					.2858	.0983	.2949
24					1.9867	1.7314	1.8099
Max	2.5972	4.6731	2.4554	2.489	4.6746	4.0634	1.8435
Min	.2843	.1341	.3231	.061	.2858	.0983	.2949
Avg	2.2542	2.6089	2.1573	2.0199	2.6112	1.9664	1.6368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 207 / 11 kv chikni khamgoan  
no.3 Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)
8	.9945	.9259
Max	.9945	.9259
Min	.9945	.9259
Avg	.9945	.9259

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014104 / 33/11KV BHANAS HIVARE

Feeder No / Name : 201 / SURESHNAGAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.1562	.1406	1.4842
Max	.1562	.1406	1.4842
Min	.1562	.1406	1.4842
Avg	.1562	.1406	1.4842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014104 / 33/11KV BHANAS HIVARE

Feeder No / Name : 202 / NEWASA PHATA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
18			1.086
24	.6401	.6401	.6335
Max	.6401	.6401	1.086
Min	.6401	.6401	.6335
Avg	.6401	.6401	.8598



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014104 / 33/11KV BHANAS HIVARE

Feeder No / Name : 204 / KHUNEGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.2926	.2172	1.4232
Max	.2926	.2172	1.4232
Min	.2926	.2172	1.4232
Avg	.2926	.2172	1.4232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014156 / 33/11 Kv KHADKA

Feeder No / Name : 202 / 11KV JALKA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2477	.2477	.2477	.2096	.8949
2	.2286	.2477	.2477	.2477	.2096	.8916
3	.2286	.2667	.2477	.2477	.2286	.9214
4						.9214
5						.9783
6						1.142
7						1.866
8						.1143
9						.0549
12	2.2611	2.1376	2.1862	2.4086	2.1862	
13	2.3482	2.3922	2.2348	2.3482	2.0873	
14	2.3482	2.2725	2.2348	2.3482	1.9528	
15	2.2672	1.7444	2.1052	2.2186	1.9372	
16	2.1445	1.9997	2.1376	2.1862	2.0466	
17	2.0805	1.9685	2.0729	2.1862	2.119	
18	1.9528	1.8519	2.1052	2.2085	2.0309	
19	1.6762	1.5051	1.8299	1.8404	1.7158	
20	.2858	.2858	.3048	.3048	.2667	
21	.2667	.2477	.2858	.2667	.2477	
22	.2477	.2477	.2858	.2667	.2096	
23	.2477	.2286	.2667	.2477	.2096	
24	.2286	.2477	.2477	.2477	.2096	.8509
Max	2.3482	2.3922	2.2348	2.4086	2.1862	1.866
Min	.2286	.2286	.2477	.2477	.2096	.0549
Avg	1.1901	1.1182	1.1900	1.2389	1.1167	.8636

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014156 / 33/11 Kv KHADKA

Feeder No / Name : 203 / 11 KV KHADKA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9608	1.8185	1.7901	1.8056	1.8404	.8962
2	1.9608	1.866	1.8827	1.8056	1.8404	.8962
3	1.9608	1.8976	1.8827	1.8056	1.8404	.9522
4	2.1348	2.1052	2.5617	2.0885	2.0567	.8775
5	2.5301	2.6063	2.8654	2.7349	2.8166	1.2071
6	2.8622	3.155	3.2047	3.1161	3.3436	1.773
7	3.1579	3.1893	3.7795		3.8561	2.0351
8	2.1214	2.0359	3.6965	2.2672	3.6408	1.7364
9	2.5263	1.9115	2.0147	2.1862	3.0788	1.2936
10	1.2403	1.3306	1.0425	1.0631	1.3121	1.0498
11	.985	.9412	.8059	.8869	.8505	.7011
12	.7701	.6718	.5658	.7265	.6836	.9015
13	.7421	.6733	.5144	.6733	.6203	
14	.5959	.5434	.4801	.6024	.5487	
15	.6661	.5959	.5487	.6135	.583	
16	.6173	.5658	.583	.7442	.6687	
17	.8149	.6762	.7537	.7087	.7537	
18	1.0745	1.0387	.964	.9412	1.0317	
19	1.5912	1.4377	1.5546	1.6632	1.643	
20	1.6804	1.4003	1.6095	1.5364	1.6057	
21	1.2382	1.4563	1.1765	1.2254	1.2449	
22	1.0242	1.0082	1.0136	1.0269	1.0456	
23	.8413	.8589	.8596	.8589	.9896	
24	1.9608	1.7341	1.6512	1.8056	1.692	.8962
Max	3.1579	3.1893	3.7795	3.1161	3.8561	2.0351
Min	.5959	.5434	.4801	.6024	.5487	.7011
Avg	1.5441	1.4799	1.5750	1.4298	1.6495	1.1705

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014156 / 33/11 Kv KHADKA

Feeder No / Name : 204 / 11 KV MURMA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.0953	.0953	1.6918
2	.1143	.1143	.1143	.0953	.0953	1.7071
3	.1143	.1143	.1143	.0953	.0953	1.7223
4						1.7223
5						1.7375
6						1.768
7						2.0424
8						2.332
9						2.4082
12	3.3276	3.1855	2.8807	3.1173	2.8045	
13	3.2183	2.9264	2.9721	3.0864	2.6216	
14	3.1173	2.8654	2.9721	3.3025	2.8045	
15	3.1173	.1715	2.774	3.1482	2.7587	
16	3.0483	2.6368	2.8654	3.1173	2.652	
17	2.8502	2.7587	2.9416	2.8197	2.8045	
18	2.8197	2.7282	2.774	2.8349	2.6368	
19	2.9874	2.9111	2.7435	2.8349	2.5911	
20	.1334	.1143	.1334	.1143	.1143	
21	.1143	.1143	.1334	.1143	.1334	
22	.1334	.1143	.1334	.1143	.1143	
23	.1143	.1143	.1143	.0953	.0953	
24	.1143	.1143	.1143	.0953	.0953	1.6918
Max	3.3276	3.1855	2.9721	3.3025	2.8045	2.4082
Min	.1143	.1143	.1143	.0953	.0953	1.6918
Avg	1.5899	1.3186	1.4934	1.5675	1.4070	1.8823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014156 / 33/11 Kv KHADKA

Feeder No / Name : 205 / 11 KV PRAVRASANGAM NEW  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1792	1.8623	1.9662	1.9989	1.9334	.0572
2	2.1792	1.8785	1.9662	1.9989	1.9498	.0572
3	2.1792	1.8785	1.9826	1.9989	1.9498	.0572
4	2.2283	1.9006	1.9826	1.9989	1.9662	
5	2.4034	1.989	2.0388	1.9989	1.9989	
6	2.4863	2.1795	2.1051	2.0809	2.146	
7	2.7161	2.34	2.572	2.3594	2.2977	
8		2.2939	2.5604	2.5069	2.3472	
9	2.5484	2.2611	2.343	2.4577	2.1963	
20		.0572	.0762	.0572		
21		.0572	.0572	.0572	.0762	
22		.0572	.0572	.0381	.0762	
23		.0572	.0572	.0381	.0762	
24	2.1792	1.7444	1.9271	1.9989	1.9006	.0572
Max	2.7161	2.34	2.572	2.5069	2.3472	.0572
Min	2.1792	.0572	.0572	.0381	.0762	.0572
Avg	2.3444	1.4683	1.5494	1.5421	1.6088	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014059 / 33/11 KV MIRI

Feeder No / Name : 201 / Miri

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014059 / 33/11 KV MIRI

Feeder No / Name : 203 / Shiral

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014059 / 33/11 KV MIRI

Feeder No / Name : 204 / Adgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
24	.7186
Max	.7186
Min	.7186
Avg	.7186



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014059 / 33/11 KV MIRI

Feeder No / Name : 206 / 11 kv maka hivara gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014059 / 33/11 KV MIRI

Feeder No / Name : 209 / renukaiwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014059 / 33/11 KV MIRI

Feeder No / Name : 210 / kay bee express  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	21-FEB-17
HR	Load (MW)
24	.0191
Max	.0191
Min	.0191
Avg	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014086 / 33/11 KV CHINCHPUR IJADE

Feeder No / Name : 201 / Wadgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-FEB-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014086 / 33/11 KV CHINCHPUR IJADE

Feeder No / Name : 203 / Chinchpur Ijade SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-FEB-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014146 / midsangvi

Feeder No / Name : 202 / 11 kv Bhalgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2058	.2286	.2286	.2286	.4191	.6097
2	.2286	.2058	.2286	.2286	.2286	.4191	.6097
3	.2286	.2058	.2286	.2286	.2286	.4191	.6097
4	.2667	.2401	.2477	.2667	.2477	.4572	.8002
5	.3048	.2572	.2667	.3048	.2667	.5144	1.0288
6						.6478	1.2765
7						1.0288	1.5242
8						1.3336	1.5242
9						1.2193	1.5242
12	1.5242	1.2346		1.4098	1.2765		
13	1.5813	1.4074	1.3908	1.5242			
14	1.5623	1.2378	1.3717	1.4861	1.0288		
15	1.4098	1.2378	1.2193	1.3527	.9907		
16	1.2384	1.2378	1.1241	1.2384	.9907	.1334	.1143
17	1.2384	1.1869	1.1622	1.2384	1.086	.1905	.1715
18	1.2193	.9156	1.2003	1.3146	1.1431	.2096	.1905
19	1.2765	1.0513	1.3717	1.105	1.0288	.4001	.2286
20	.381	.2713	.362	.4001	.3239	.3429	.4001
21	.2743	.2401	.2229	.2401	.2667	.3239	.2515
22	.2667	.2035	.2477	.2667	.2286	.3048	.2667
23	.2286	.2035	.2286	.2286	.2286	.2286	.2286
24	.2286	.2286	.2035	.2286	.2286	.4191	.6097
Max	1.5813	1.4074	1.3908	1.5242	1.2765	1.3336	1.5242
Min	.2286	.2035	.2035	.2286	.2286	.1334	.1143
Avg	.7604	.6539	.665	.7384	.5895	.5006	.6649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014146 / midsangvi

Feeder No / Name : 203 / 11 kv Midsangvi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2286	.2477	.2286	.2286	.2286
2	.2858	.2858	.2286	.2477	.2286	.2286	.2286
3	.2858	.2858	.2286	.2477	.2286	.2286	.2286
4	.3239	.3239	.2667	.2858	.3048	.2667	.2667
5	.4191	.381	.3429	.381	.381	.3239	.4191
6	.6478	.6097	.6097	.5906	.6097	.4191	.5716
7	.9907	1.0479	.9526	.9145	.8573	.8002	.724
8	.8764	.8764	.7049	.7049	.8002	.8954	.6668
9	.7621	.8573	.6859	.7049	.8764	.7811	.6097
10	.5716	.6097	.5335	.6097	.4954	.5716	.362
11	.2858	.3048		.3048	.3239	.2858	.2286
12	.2286	.2667		.2667	.3239	.2667	.1905
13	.1715	.2477	.2286	.2667		.2286	.1524
14	.1905	.2286		.2477	.2286	.2286	.1524
15	.2286	.2286		.2286	.2286	.2286	.1524
16	.2286	.2477	.2667	.2286	.2286	.2286	.1715
17	.3048	.2858	.3048	.2858	.3048	.3048	.1905
18	.4001	.4191	.381	.4001	.381	.381	.2858
19	.7049	.7049	.7049	.8002	.6859	.724	.6287
20	.5716	.4954	.5525	.5716	.4572	.4572	.5716
21	.4191	.3239	.4382	.4382	.4191	.3048	.3429
22	.3239	.3048	.3048	.3048	.3048	.2286	.2858
23	.2858	.2286	.2477	.2286	.2667	.2286	.2286
24	.2858	.2858	.2286	.2477	.2286	.2286	.2286
Max	.9907	1.0479	.9526	.9145	.8764	.8954	.724
Min	.1715	.2286	.2286	.2286	.2286	.2286	.1524
Avg	.4199	.4223	.4220	.4064	.4084	.3778	.3382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014056 / 33/11 KV SHEGAON URBAN

Feeder No / Name : 201 / 11 KV SHEVGAON (U)- SHEDDABLE URBAN  
 KHANDOBA NA Feeder KV- 11 /  
 OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8718			.8383
2	.8718			.8383
3	.8718			.8383
4	.9221			.9221
5	1.0898			1.0898
6	1.5927			1.5927
7	2.0454			1.9281
8	2.1795	2.1971		2.146
9		1.8442		
10		1.5927		
11		1.4251		
12		1.3413		
13		1.1233		
14		1.0898		
15		1.0898		
16		1.1401		
17			1.2574	
18			1.4754	
19			1.6766	
20			1.6095	
21			1.4754	
22			1.2071	
23			1.0227	
24	.8718			.8886
Max	2.1795	2.1971	1.6766	2.146
Min	.8718	1.0898	1.0227	.8383
Avg	1.2574	1.4270	1.3892	1.2314



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014056 / 33/11 KV SHEGAON URBAN

Feeder No / Name : 205 / Amrapur W/S NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING UTILITY

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395			.1698	
2	.3395			.1698	
3	.3395			.1698	
4	.3395			.1698	
5	.3395			.1698	
6	.3395			.1509	
7	.3395			.1509	
8	.3584	.168		.0189	
9		.2427			.2614
10		.2427			
11		.2241			
12		.2427			
13		.2241			
14		.2427			
15		.2427			
16		.112			
17			.3395		
18			.1886		
19			.1886		
20			.1886		
21			.1886		
22			.2452		
23			.2452		
24	.3395			.2829	
Max	.3584	.2427	.3395	.2829	.2614
Min	.3395	.112	.1886	.0189	.2614
Avg	.3416	.2157	.2263	.1614	.2614

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014056 / 33/11 KV SHEGAON URBAN

Feeder No / Name : 206 / 11 KV SHEVGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108			.3734
2	.4108			.3734
3	.4108			.3734
4	.4668			.4668
5	.6535			.6908
6	1.1203			1.1203
7	1.5497			1.419
8	1.251	1.4003		1.2696
9		1.1949		
10		.7468		
11		.5975		
12		.4668		
13		.3547		
14		.3921		
15		.3921		
16		.4108		
18			.6535	
19			1.1203	
20			1.0642	
21			.7468	
22			.5601	
23			.4481	
24	.4294			.3921
Max	1.5497	1.4003	1.1203	1.419
Min	.4108	.3547	.4481	.3734
Avg	.7448	.6618	.7655	.7199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014056 / 33/11 KV SHEGAON URBAN

Feeder No / Name : 207 / 11 KV SHEVGAON (U) SHEDDABLE URBAN  
 Shasrinagar Feeder KV- 11 /  
 OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924			.924
2	.924			.924
3	.924			.924
4	1.0164			1.0164
5	1.2012			1.1458
6	1.6078			1.6078
7	1.922			2.0328
8	2.1253	1.9605		1.885
9		1.7926		
10		1.5708		
11		1.4784		
12		1.386		
13		1.2012		
14		1.0719		
15		1.0349		
16		1.1273		
17			1.2936	
18			1.6632	
19			1.8111	
20			1.7741	
21			1.5154	
22			1.3306	
23			1.1088	
24	.961			.9795
Max	2.1253	1.9605	1.8111	2.0328
Min	.924	1.0349	1.1088	.924
Avg	1.2895	1.4026	1.4995	1.2710

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 201 / 11 KV ERANDGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					1.9281	2.0119
24	.8886	.8288	1.1603	1.2929		
Max	.8886	.8288	1.1603	1.2929	1.9281	2.0119
Min	.8886	.8288	1.1603	1.2929	1.9281	2.0119
Avg	.8886	.8288	1.1603	1.2929	1.9281	2.0119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 202 / 11KV OLD DAHIFAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	3.0864	3.858	3.2579	4.1152	2.7435	4.2867	3.6008
Max	3.0864	3.858	3.2579	4.1152	2.7435	4.2867	3.6008
Min	3.0864	3.858	3.2579	4.1152	2.7435	4.2867	3.6008
Avg	3.0864	3.858	3.2579	4.1152	2.7435	4.2867	3.6008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 203 / 11 KV TALANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0885	1.6766	2.5149	2.6825	2.5149	1.7147	1.8233
24	.8383	.8383	.6706	.7042	.6706	.0663	.0663
Max	2.0885	1.6766	2.5149	2.6825	2.5149	1.7147	1.8233
Min	.8383	.8383	.6706	.7042	.6706	.0663	.0663
Avg	1.4634	1.2575	1.5928	1.6934	1.5928	.8905	.9448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 204 / 11 KV Water Supply EXP NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING UTILITY

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3144	.3144	.3144	.0286	.3144	.3144	.3144
16	.3144	.3144	.2858	.3144	.2858	.3144	.3144
24	.2858	.3144	.3144	.2858	.2858	.2858	.3144
Max	.3144	.3144	.3144	.3144	.3144	.3144	.3144
Min	.2858	.3144	.2858	.0286	.2858	.2858	.3144
Avg	.3049	.3144	.3049	.2096	.2953	.3049	.3144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 205 / 11 KV GHOTAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.1605	1.5432	1.7147	2.1605	2.0576		
16					.4801		
24	.1029	.0857	.12	.0857	.0857	.6344	1.406
Max	2.1605	1.5432	1.7147	2.1605	2.0576	.6344	1.406
Min	.1029	.0857	.12	.0857	.0857	.6344	1.406
Avg	1.1317	.8145	.9174	1.1231	.8745	.6344	1.406



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 206 / 11 KV GHOTAN GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.6687	.5487	.4287	.5144		.5144	.5144
24	.4287	.6859	.6001	.5144	.5144		.5144
Max	.6687	.6859	.6001	.5144	.5144	.5144	.5144
Min	.4287	.5487	.4287	.5144	.5144	.5144	.5144
Avg	.5487	.6173	.5144	.5144	.5144	.5144	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 207 / 11 KV LAKHEFAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						2.0576	3.2579
24	.9431	1.0288	1.1145	1.1145	1.406		
Max	.9431	1.0288	1.1145	1.1145	1.406	2.0576	3.2579
Min	.9431	1.0288	1.1145	1.1145	1.406	2.0576	3.2579
Avg	.9431	1.0288	1.1145	1.1145	1.406	2.0576	3.2579

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 208 / 11KV G&amp;P EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	1.8465	2.2809	2.1171	2.3198	.5624	1.9502
2	2.2375	1.9677	2.1026	2.1437	2.2184	.5548	1.9326
3	2.2192	1.9822	2.0469	2.0561	2.0401	.5693	1.9768
4	2.1011	1.9441	2.0332	2.1293	2.1315	.5838	1.9669
5	2.3152	1.9662	2.0751	2.1178	2.0797	.5853	1.8442
6	2.2428	1.9494	2.0546	2.255	2.0995	.5693	1.9273
7	1.8275	1.9936	1.9022	1.9189	1.9814	.5677	1.9395
8	3.2049	3.5383	3.3188	2.9862	3.2225	1.1092	3.003
9	1.7048	1.9326	1.5234	1.4601	.9419	1.4091	1.3184
10	1.3138	1.5356	1.4297	1.7383	.7011	1.371	1.1462
11	1.3832	1.7665	1.5569	1.7375	.6112	1.6545	1.1805
12	1.3138	1.8404	1.5173	1.8237	.5525	1.4487	1.3931
13	1.1385	1.7688	1.5203	1.8	.5258	1.4365	1.2247
14	1.2651	1.8351	1.5181	1.816	.4633	1.5402	.9823
15	1.2734	1.8244	1.4868	1.8374	.4542	1.1896	1.0509
16	2.2013	3.2156	2.4517	3.0365	1.5542	2.2958	2.0279
17	1.0623	1.7817	1.4167	1.6644	.1997	1.201	1.0806
18	1.0783	1.7048	1.3839	1.7002	.3025	1.1424	1.0265
19	1.086	1.8519	1.3047	1.6507	.3688	1.3496	1.1363
20	1.387	2.0165	1.8854	1.8709	.3841	1.688	1.5539
21	1.8275	2.1727	2.0957	1.9486	.4809	1.7345	1.5592
22	1.9532	2.0972	2.0584	2.1773	.6036	1.7596	1.6956
23	1.9357	1.9479	1.9166	2.1353	.5281	1.8694	1.8313
24	3.7773	2.9004	3.1589	4.1762	2.2017	2.5903	2.9351
Max	3.7773	3.5383	3.3188	4.1762	3.2225	2.5903	3.003
Min	1.0623	1.5356	1.3047	1.4601	.1997	.5548	.9823
Avg	1.8342	2.0575	1.9183	2.0957	1.2069	1.2826	1.6535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 209 / 11 KV NEW DAHIFAL AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.8807	1.8861	2.3148	2.572	2.6578		
24	.0514	.0514	.0514	.0514	.0514	1.3717	1.8861
Max	2.8807	1.8861	2.3148	2.572	2.6578	1.3717	1.8861
Min	.0514	.0514	.0514	.0514	.0514	1.3717	1.8861
Avg	1.4661	.9688	1.1831	1.3117	1.3546	1.3717	1.8861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 210 / 11 KV BODAKHA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 201 / 11 KV DHORJALGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5468	.4999	.6009		.6483	.1265	
2	.6325	.5535	.6325	.6642	.6718	.128	
3	.7116	.5624	.703	.7682	.6944	.112	
4	.8124	.6173	.8124	.8482	.7562	.1134	
5	.9374	.8333	1.0155	1.004	.8592	.1134	
6	1.1431	1.1717	1.3272	1.3117	.9842		
7	1.4815	1.3735	1.6872	1.7078	1.4815		
8	1.9841	1.6766	2.0119	1.9372	1.8138		
9	1.7747	1.5895	1.7593	1.6667	1.6918		
12						1.7747	1.5278
13						1.9814	1.7833
14						1.9204	
15						1.5432	
16						1.8435	
17						1.8673	
18						1.8138	
19	.1781	.1423	.1543		.1562	1.4937	
20	.176	.144	.125		.1562	.1739	
21	.1781	.128	.1265		.1406	.1423	
22	.16	.1265	.1107		.1423	.144	
23	.1619	.1107	.1107		.1265	.1296	
24	.4687		.5468	.5376		.1265	.144
Max	1.9841	1.6766	2.0119	1.9372	1.8138	1.9814	1.7833
Min	.16	.1107	.1107	.5376	.1265	.112	.144
Avg	.7565	.6807	.7816	1.1606	.7374	.8638	1.1517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 202 / 11 KV WADULE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.506		.5535	.4744		.0474
2	.506		.5535	.506		.0474
3	.5937		.6249	.5761		.048
4	.6249		.6562	.6401		.064
5	.703		.7253	.6882		.064
6	.9259		1.0802	1.1523		
7	1.2654		1.3565	1.4864		
8	1.387		1.3889	1.5935		
9	1.3279		1.2955	1.358		
12						1.4784
13						1.4198
14						1.387
15						1.1888
16						1.2037
17						1.2041
18						1.3413
19		.112	.125		.0926	.6859
20		.0972	.0937		.0937	.096
21		.096	.0781		.0781	.0949
22		.096	.0625		.0633	.096
23		.0949	.0625		.0474	.08
24	.4687		.4999	.3953		.0474
Max	1.387	.112	1.3889	1.5935	.0937	1.4784
Min	.4687	.0949	.0625	.3953	.0474	.0474
Avg	.8309	.0992	.6104	.8870	.0750	.5886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 204 / 11 KV GARADWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.0791	.081	.0633	.064	.3479	
2	.08		.081	.064	.0648	.3479	
3	.0791		.08	.064	.0648	.4481	
4	.0791		.0791	.0648	.081	.4481	
5	.0781	.08	.0791	.0648	.08	.5121	
6						.6081	
7						.8697	
8						1.0437	
9						1.0279	1.0936
12	.8535	.9217	.9105	.9804	.9105		
13	.9568	.9568	.8951	.9998	1.0059		
14	1.0517	.9061	.7621	.9804	.9031		
15	1.034	1.0155	.823	.9061	.884		
16	.9877	.9568					
17	.8951	.8749	.8951		.9722		
18	.9014	.7316	.945		.9686		
19	.081	.6874	.8436		.8124	.0937	
20	.08	.1107	.0781		.0937	.0949	
21		.1107	.0781		.0937	.08	
22	.08	.0972	.0633		.0937	.0791	
23	.08	.096	.0633		.0937	.08	
24	.0791		.08	.064		.3163	.427
Max	1.0517	1.0155	.945	.9998	1.0059	1.0437	1.0936
Min	.0781	.0791	.0633	.0633	.064	.0791	.427
Avg	.4398	.5446	.4022	.4252	.4491	.4265	.7603



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 207 / 11 KV WAGHOLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6874	.6249	.8124	.6642	.703	.1581	
2	.6944	.703	.8697	.6642	.7407	.1581	
3	.8025	.7116	.8697	.9282	.8333	.16	
4	.9145	.9105	.9374	1.0402	1.1248	.144	
5	1.0936	.9877	1.1717	1.4737	1.6667	.144	
6	1.3717	1.5586	1.6667	2.2024	1.7284		
7	1.7966	2.0309	2.0679	2.3685	2.2558		
8	2.1605	2.332	2.4387	2.7496	2.4996		
9	1.9966	2.284	2.2994	2.5	2.1605		
12						2.5	
19	.2401	.2372	.2031		.25		
20	.2241	.2241	.1875		.2343		
21		.1943	.1875		.2343		
22	.1898	.192	.1562		.2187		
23		.192	.1581		.2214		
24	1.2342	.6249	.6173	1.1702		.2056	.192
Max	2.1605	2.332	2.4387	2.7496	2.4996	2.5	.192
Min	.1898	.192	.1562	.6642	.2187	.144	.192
Avg	1.0312	.9205	.9762	1.5761	1.0623	.4957	.192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 208 / 11 KV AVHANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.048	.032	.048		1.2651	.1581	
2	.0316		.048	.0474	.0324		
3	.0316		.0474	.0474		.1581	
4	.0312		.0633	.048		.192	
5	.0312	.032	.0625	.048	.0324	.192	
6				.048		.2881	
7						.7522	
8						.6642	
9						.9488	1.1405
12	.8333	.8124	.0772	.7968	1.0311		
13	.9374	.9602	.6554	.7716	1.2651		
14	1.0957	.9259	.8333	.8124			
15	1.1092	.953	.823		.9568		
16	.8951	.9722	.8535		.9061		
17	.8381	.9374	.787		.9061		
18	.759	.884	.7316		.8592		
19	.048	.7499	.828		.6249		
20	.0486	.064	.0469		.0469		
21		.064	.0469		.0469		
22	.048	.0474	.0469		.0474		
23		.0474	.0469		.0474		
24	.032		.0474	.032		.1581	.192
Max	1.1092	.9722	.8535	.8124	1.2651	.9488	1.1405
Min	.0312	.032	.0469	.032	.0324	.1581	.192
Avg	.4261	.5344	.3385	.2946	.5763	.3902	.6663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 209 / 11 KV NANDUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4167	.506	.4744	.4744	.5468	.0949	
2	.4167	.4999	.4744	.5121	.6009	.0949	
3	.5468	.5468	.6562	.6081	.6249	.096	
4	.6249	.5864	.703	.6722	.7116	.096	
5	.7099	.7655	.8179	.7935	.7811	.096	
6	1.0669	.9804	1.2498	1.0364	.9014		
7	1.3272	1.2029	1.448	1.4403	1.2654		
8	1.6004	1.5741	1.6872	1.7284	1.5699		
9	1.5432	1.5123	1.4327	1.3735	1.3279		
12						1.7497	
19	.128	.096	.2031		.0937		
20	.1134	.0949	.125		.125		
21		.096	.1094		.125		
22	.096	.096	.0937		.1094		
23		.0949	.0937		.0949		
24	.3637		.4374	.4902		.0949	.0791
Max	1.6004	1.5741	1.6872	1.7284	1.5699	1.7497	.0791
Min	.096	.0949	.0937	.4744	.0937	.0949	.0791
Avg	.6888	.6180	.6671	.9129	.6341	.3318	.0791

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014078 / 33/11KV BALAMTAKELI

Feeder No / Name : 203 / 11 KV LADJALGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.4138	.6135	.2936	
2	.6335	.4097	.6401	.2318	.2715
3	.724	.3955	.7316	.2406	.2715
4	.9145	.4556	.905	.2732	.2715
5	1.0164	.5195	.905	.2606	.3658
6	1.2012	.688	.9955	.2307	.4572
7	1.2936	.6932	.9955	.1728	.5487
8	1.3717	.7346	1.0974	.1795	.543
24					.181
Max	1.3717	.7346	1.0974	.2936	.5487
Min	.543	.3955	.6135	.1728	.181
Avg	.9622	.5387	.8605	.2354	.3638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014078 / 33/11KV BALAMTAKELI

Feeder No / Name : 204 / 11 KV GOLEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3696
2						.5544
3						.5544
4						.823
5						1.0974
6						1.386
7						1.4632
8						1.1888
17	1.4338	1.9281	1.8505	.8145	1.9204	
18	1.6004	1.8099	.7215	2.0119	1.7375	
19	1.7218	1.6289	1.4425	1.448	1.4784	
20	1.5273	1.448	1.2394	1.267	1.0164	
21	1.4656	.8145	.9768	.9955	.823	
22	1.3842		.8077	.7716	.5544	
23	1.201		.7722	.724	.3658	
24	.7316	1.0907	1.8505	.6756	.543	.3658
Max	1.7218	1.9281	1.8505	2.0119	1.9204	1.4632
Min	.7316	.8145	.7215	.6756	.3658	.3658
Avg	1.3832	1.4534	1.2076	1.0885	1.0549	.8670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014078 / 33/11KV BALAMTAKELI

Feeder No / Name : 205 / 11KV KEDARESHWAR SSK EXP SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0364	.0362	.038	.0362	.037
2	.0343	.0352	.0362	.0363	.0362	.0366
3	.0351	.0367	.0362	.0352	.0362	.0366
4	.0514	.0341	.0362	.0341	.0343	.0366
5	.0514	.0325	.0543	.0326	.0543	.0366
6	.0514	.0309	.0543	.0306	.0549	.0549
7	.0514	.0289	.0543	.0298	.0543	.0554
8	.0514	.0299	.0543	.0277	.0549	.0366
9	.0319		.0732	.0366	.0366	
10	.0325	.0343	.0732	.0366	.0366	
11	.0293	.0362	.0554	.0739	.037	
12	.0314	.0343	.0554	.0739	.037	
13	.0289	.0351	.0554	.0732	.0366	
14	.0301	.0549	.0549	.0732	.0366	
15	.0299	.0549	.0554	.0549	.0366	
16	.031	.0532	.0549	.037	.0366	
17	.0325	.0543	.0649	.0351	.0366	
18	.0328	.0526	.0608	.0343	.0366	
19	.0341	.0537	.0598	.0351	.037	
20	.0335	.0537	.0652	.0343	.037	
21	.0344	.0343	.0687	.0354	.037	
22	.0363	.0362	.0703	.0358	.037	
23	.0376	.0362	.0375	.0362	.037	
24	.0343	.0368	.0362	.0367	.0362	.037
Max	.0514	.0549	.0732	.0739	.0549	.0554
Min	.0289	.0289	.0362	.0277	.0343	.0366
Avg	.0367	.0402	.0543	.0419	.0396	.0408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014078 / 33/11KV BALAMTAKELI

Feeder No / Name : 208 / 11KV SUKALI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.4746	1.0745	1.372	1.4775
10	1.7147	1.4775	1.5512	1.6141
11	1.9719	1.4163	1.4984	1.4838
12	1.8861	1.2814	1.4163	1.5666
13	1.7147	1.2778	1.4838	1.3603
14	1.9281	1.2106	1.4838	1.4838
15	1.97		1.5556	1.3508
16	1.8099	1.0088	1.3451	1.4283
Max	1.9719	1.4775	1.5556	1.6141
Min	1.4746	1.0088	1.3451	1.3508
Avg	1.8088	1.2496	1.4633	1.4707

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014081 / 33/11KV DAHIGAON-NE

Feeder No / Name : 205 / 11 KV BHAVINIMGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1212	.1379	.1341	.1364	.1395	1.0418	1.0753
2	.1296	.1417	.1349	.1387	.141	1.1043	1.1546
3	.128	.1471	.1478	.1532	.1395	1.1164	1.1949
4	.1364	.1494	.1532	.1532	.1402	1.1355	1.2414
5	.1402	.1448	.1578	.1547	.1433	.9762	1.3329
6			.0061			1.1949	1.4563
7						1.6133	1.9319
8						1.9113	2.1925
9						1.8496	2.1674
11	.269	.2629	.0053	.2835	.3193		
12	2.037	2.1826	2.3388	2.4242	2.3198		
13	2.5354	2.2901	2.3114	2.569	2.3251		
14	2.6581	2.2535	2.4036	2.4783	2.2458		
15	2.668	2.271	2.3556	2.4013	2.2215		
16	2.4775	2.3007	2.38	2.3853	2.2809		
17	2.5271	2.3411	2.3975	2.3884	2.2481		
18	2.3815	2.2352	2.1742	2.1818	2.2253		
19	2.1132	1.9517	1.6263	2.0187	2.1902	.1082	.0328
20	.144	.141	.1684	.157	.1349	.1235	.1242
21	.1326	.1288	.1524	.1509	.1257	.1204	.109
22	.16	.1417	.1562	.1638	.1097	.1113	.0945
23	.1524	.1402	.1555	.1631	.2324	.2507	.2995
24	.1395	.1341	.1395	.1509	.9892	.9595	1.0433
Max	2.668	2.3411	2.4036	2.569	2.3251	1.9113	2.1925
Min	.1212	.1288	.0053	.1364	.1097	.1082	.0328
Avg	1.1079	1.0261	.9749	1.0870	1.0880	.9078	1.0300



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 201 / 11 KV KHANAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				1.7147
16	1.5242	1.2574	1.4289	
24				.6859
Max	1.5242	1.2574	1.4289	1.7147
Min	1.5242	1.2574	1.4289	.6859
Avg	1.5242	1.2574	1.4289	1.2003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 202 / 11 KV KARHETAKALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5813	1.5023	1.4706	1.5023	1.6129	
12						2.0873
16						1.9608
24	1.0279		1.1385		1.0279	
Max	1.5813	1.5023	1.4706	1.5023	1.6129	2.0873
Min	1.0279	1.5023	1.1385	1.5023	1.0279	1.9608
Avg	1.3046	1.5023	1.3046	1.5023	1.3204	2.0241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 203 / 11 KV KHANAPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.439	.439		.4207		
16	.1097	.1097	.128			.128
24	.1829		.1829		.1829	.1829
Max	.439	.439	.1829	.4207	.1829	.1829
Min	.1097	.1097	.128	.4207	.1829	.128
Avg	.2439	.2744	.1555	.4207	.1829	.1555

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 204 / 11 KV KARHETAKALI W/S NON SHEDDABLE WATER SUPPLY AND  
EXPRESS Feeder KV- 11 / UTILITY  
OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0953	.0762	.1334	.0572	.0572	.0572
12						.0572
16	.0762	.0572	.0572			.0572
24	.0762		.0572		.0572	.0572
Max	.0953	.0762	.1334	.0572	.0572	.0572
Min	.0762	.0572	.0572	.0572	.0572	.0572
Avg	.0826	.0667	.0826	.0572	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 205 / 11 KV BACK WATER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.4289	1.5242	1.467	1.4861		
16						2.0005
24	1.1431		1.3336		1.2955	
Max	1.4289	1.5242	1.467	1.4861	1.2955	2.0005
Min	1.1431	1.5242	1.3336	1.4861	1.2955	2.0005
Avg	1.286	1.5242	1.4003	1.4861	1.2955	2.0005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014149 / 33/11 KV KHARADGAON S/STN

Feeder No / Name : 201 / 11 KV KHARADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.108	.1067	.108	.108	.2591
2	.1054	.108	.1067	.108	.108	.2778
3		.108	.1067	.1067	.108	.2778
4						.301
5						.4816
6						.587
7						.7074
8						.9907
12	.9031	.743	.7676	.7876		
13	.873	.6321	.8429	.9065		
14	.9297	.7676	.7468	.8471		
15	.9755	.6706	.7621			
16		.7621	.8025			
17	.8025	.6859	.787	.8993		
18	.7716	.5864	.8488	.7316		
19	.4938	.4938	.6874	.5944	.6308	
20	.1619	.1698	.1562	.1524	.1337	
21			.1406	.1372	.1189	
22			.108	.1219	.1054	
23			.1094	.1067	.0903	
24	.1054	.108	.1372	.108	.1235	.1219
Max	.9755	.7676	.8488	.9065	.6308	.9907
Min	.1054	.108	.1067	.1067	.0903	.1219
Avg	.5662	.4572	.4510	.4082	.1696	.4449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014149 / 33/11 KV KHARADGAON S/STN

Feeder No / Name : 202 / 11 KV WADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2932	.3048	.2572	.2778	.2494	.1337	
2	.3704	.3048	.2972	.2968	.3041	.104	
3	.4572	.3658	.431	.2968	.4694	.1189	
4	.5487	.5441	.4012	.4586	.5944		
5	.6401	.6481	.5201	.6009	.7727		
6	.7621	.9568	.8173	.8078	.9482		
7	1.3717	1.3272	1.761	1.6309			
8	2.1451	2.3303	2.0805	2.1033	2.5603		
9	.9259	1.8673	2.0656	1.6975			
12						2.0953	1.9022
13						2.0656	2.021
14						1.9913	1.776
15						1.5009	
16						.4458	
17						1.9616	
19	.1943	.1656	.1783	.1852	.1783		
20	.1852	.1806	.1957	.1698	.6805		
21			.1677	.1543	.1677		
22			.1524	.1543	.1524		
23			.1355	.1389	.1372		
24	.2315	.2469	.2143	.2315	.2201	.1337	
Max	2.1451	2.3303	2.0805	2.1033	2.5603	2.0953	2.021
Min	.1852	.1656	.1355	.1389	.1372	.104	1.776
Avg	.6771	.7702	.645	.6136	.5719	1.0551	1.8997

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014149 / 33/11 KV KHARADGAON S/STN

Feeder No / Name : 203 / 11 KV KHARADGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3658	.3258	.3292	.2804	.3403	
2	.3077	.3841	.3258	.3258	.3155	.3761	
3	.3109	.439	.3439	.4163	.4252	.4298	
4	.439	.5014	.4344	.4656	.5316	.5014	
5	.6219	.6447	.5792	.5552	.6447	.5731	
6	.0732	.7164	.7421	.6767	.7164	.7164	
7	1.0924	.9492	1.0317	.9877		1.0387	
8	.9774	.8954	.9412	.9694	.9231	.9774	
9	.9593	.9671	.905	.9145		.8688	.8596
10	.695	.7343	.5611	.695		.543	.5853
11	.4755	.3761	.4024	.4024		.362	.3658
12	.2561	.2715	.2715	.3142		.2743	
13	.2218	.2715	.2195	.2587			
14	.2402	.2378	.2012	.2218			
15	.2218	.2378	.2195				
16		.2561	.2561				
17	.3658	.2957	.3326	.3292			
18	.3982	.499	.4435	.4024			
19	.7783	.8686	.8131	.8779	.9313		
20	.6401	.7762	.8501	.695	.6805		
21			.6219	.5487	.5792		
22			.3658	.439	.3982		
23			.2743	.3584	.3439		
24	.362	.3475	.3258	.2743	.2454	.2591	
Max	1.0924	.9671	1.0317	.9877	.9313	1.0387	.8596
Min	.0732	.2378	.2012	.2218	.2454	.2591	.3658
Avg	.4881	.5255	.4911	.5208	.5396	.5585	.6036



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014149 / 33/11 KV KHARADGAON S/STN

Feeder No / Name : 204 / 11 KV VARUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.192	.1947	.2	.1894	.1894
2	.2195	.2225	.208	.1894	.2195
3	.2364	.2086	.2	.2058	.2743
4	.2743	.2225	.2286	.2656	.2881
5	.3155	.2751	.2896	.2782	.3338
6	.3525	.333	.3858	.3338	.3807
7	.5357	.598	.6805	.7649	
8	1.0151	.8345	1.1003	.8901	.8623
9	.8288	.7895	.8109	.8177	
24	.1947	.1947	.1957	.1957	.1894
Max	1.0151	.8345	1.1003	.8901	.8623
Min	.192	.1947	.1957	.1894	.1894
Avg	.4165	.3873	.4299	.4131	.3422

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 201 / Bhatkudgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6493	.6036		.5075	.2241
2	.7716	.6584	.631		.5624	.2241
3	.7316	.6859	.6676		.6062	.2241
4	.7316	.7613	.7049		.643	.2241
5	.6668	.8716	.7895		.743	.2427
6	1.1736	1.1294	1.07		.9332	
7	1.2003	1.3889	1.4299		1.4632	
8	1.4003	1.5752	1.5242		1.5741	
9	1.267	1.5158	1.3496	1.2003	1.4198	
20	.2241	.2829	.2477	.2427	.2772	
21	.2427	.2452	.1905	.2427	.2801	
22	.2054	.2263	.1905	.2241	.2614	
23	.2054	.2075	.6668	.1867	.2427	
24	.7716	.6401	.5761		.5075	.2241
Max	1.4003	1.5752	1.5242	1.2003	1.5741	.2427
Min	.2054	.2075	.1905	.1867	.2427	.2241
Avg	.7341	.7741	.7601	.4193	.7158	.2272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 203 / Hingangaon ne Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1867	.1698	.1905	.1543	1.6991
2	.1905	.1867	.1698	.1905	.1543	1.6991
3	.1905	.1867	.1698	.1905	.1543	1.7337
4	.1905	.1867	.1698	.1905	.1543	1.7684
5	.2096	.1867	.1698	.1905	.1543	1.8031
6						2.1033
7						2.6063
8						2.8778
9						2.8416
12	3.3634	2.8995	3.1722	2.9508	2.8086	
13	3.2594	3.0514	2.8807	3.1017	2.9271	
14	3.2421	3.0178	2.3872	3.0013	3.0674	
15	3.4179	2.8837	2.4272	3.0013	3.155	
16	3.2251	3.0849	2.3472	2.9334	3.1901	
17	3.2777	2.6322	2.3472	3.1369	3.0849	
18	3.1375	2.5316	2.3472	3.12	2.8395	
19	2.9729	2.4478	2.3339	2.7808	2.4714	
20	.2241	.2263	.2286	.2204	.2241	
21	.2054	.1886	.2096	.2035	.2054	
22	.2054	.1886	.1905	.1696	.168	
23	.1907	.1698	.1905	.1696	.1307	
24	.1905	.1867	.1698	.1905	.1543	1.6991
Max	3.4179	3.0849	3.1722	3.1369	3.1901	2.8778
Min	.1905	.1698	.1698	.1696	.1307	1.6991
Avg	1.5491	1.3579	1.2267	1.4407	1.3999	2.0832

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 204 / Bhatkudgaon Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191		.0191	.0191	.0191	.0191
8	.0191	.0191		.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	
11	.0191	.0191		.0191	.0191	
12	.0191	.0191		.0191		
13	.0191	.0191	.0191	.0191		
14			.0191	.0191	.0191	
15			.0191	.0191	.0191	
16			.0191	.0191	.0191	
17				.0191	.0191	
18			.0191	.0191	.0191	
19	.0191	.0191	.0191	.0191	.0191	
20	.0191	.0191	.0381	.0191	.0191	
21	.0191	.0191	.0381	.0191	.0191	
22	.0191	.0191	.0381	.0191	.0191	
23	.0191	.0191	.0191	.0191	.0191	
24	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0381	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0220	.0191	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 205 / Bhatkudgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0762	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953
4	.1143	.1143	.1143	.1143	.0953	.1143
5	.1334	.1334	.1143	.1334	.1143	.1334
6	.1905	.1905	.1905	.1905	.1715	.1905
7	.2286	.2477	.2667	.2286	.2477	.2477
8	.2286	.2286	.2477	.2477	.2286	.1905
9	.2286	.1905	.2096	.1715	.1905	.1715
10	.2286	.2096	.1524	.2286	.2096	
11	.1905	.1905	.1334	.1715	.1905	
12	.1334	.1715	.0953	.1334	.1334	
13	.0953	.0762	.0572	.0762	.0762	
14	.0953	.0572	.0572	.0762	.0572	
15	.0953	.0762	.0762	.0953	.0762	
16	.0762	.0762	.0572	.0762	.0953	
17	.0762	.0953	.0572	.0953	.1143	
18	.1334	.0762	.0572	.1334	.1334	
19	.2096	.2096	.1334	.2286	.1905	
20	.1905	.1905	.1143	.2096	.1905	
21	.1334	.1334	.1143	.1524	.1524	
22	.1143	.1143	.0953	.1143	.1334	
23	.1143	.1143	.0953	.0953	.1143	
24	.0953	.0953	.0953	.0953	.0762	.0953
Max	.2286	.2477	.2667	.2477	.2477	.2477
Min	.0762	.0572	.0572	.0762	.0572	.0953
Avg	.1413	.1366	.1175	.1397	.1358	.1429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 206 / 11KV Akhatwade  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1307	.132	.1334	.168	.1894
2	.1524	.1307	.132	.1334	.168	.1894
3	.1524	.1307	.132	.1334	.168	.2195
4	.1715	.1307	.1509	.1524	.1867	.2503
5	.1905	.1494	.1698	.1905	.1867	.3102
6						.6093
7						.9568
8						1.0974
9						.884
12	.9976	.9482	1.2955	.873	.9659	
13	.7145	1.0837	1.1603	.9957	.8802	
14	1.0235	.9362	.8002	.9659	.8288	
15	.9783	.7922	.6935	.8949	.7754	
16	.9362	.6748	.8002	.8069	.86	
17	.9536	.8069	.8002	.8398	.9556	
18	.7981	.7922	.7335	.86	1.001	
19	.7133	.6748	.6935	.6602	.8833	
20	.2075		.1905	.2263	.2263	
21	.1886	.1905	.2096	.1867	.168	
22	.132	.1524	.1524	.168	.1494	
23	.132	.1334	.1524	.168	.1494	
24	.1524	.1307	.132	.1334	.168	.1894
Max	1.0235	1.0837	1.2955	.9957	1.001	1.0974
Min	.132	.1307	.132	.1334	.1494	.1894
Avg	.4859	.4699	.4739	.4734	.4938	.4896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 201 / 11 kv Jeur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5967	.7459
2			.6299	.8288
3			.663	.9116
4			.7127	.9945
5			.7625	1.1603
6			.9503	1.2929
7			1.491	1.8896
8			1.5415	1.9845
9			1.5415	1.5746
12		1.3599		
13		1.3094		
14		1.2616		
15		1.3108		
16		1.3272		
17		1.4746		.1294
18		1.491		.1294
19		1.3108		.2957
20	.3696	.3881		.3511
21		.2134		.3292
22		.2218		.2402
23		.1663		.1848
24			1.5415	.6962
Max	.3696	1.491	1.5415	1.9845
Min	.3696	.1663	.5967	.1294
Avg	.3696	.9862	1.0431	.8082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 202 / 11 kv Dongargan

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.4805	.4066
2		.462	.3696
3		.4805	.3696
4		.5175	.3696
5		.5359	.3696
16	.2402		
17	.2587		
18	.3142		
19	.5914		
20	.5544		
21	.5544		
22	.5359		
23	.4805		
24	.4805	.462	.5175
<b>Max</b>	<b>.5914</b>	<b>.5359</b>	<b>.5175</b>
<b>Min</b>	<b>.2402</b>	<b>.462</b>	<b>.3696</b>
<b>Avg</b>	<b>.4456</b>	<b>.4897</b>	<b>.4004</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 203 / 11 KV PANGARMAL (AG)  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3326	.3326
2		.3326	.3696
3		.3511	.3696
4		.3696	.3696
5		.3696	.3696
16	.3142		
17	.3142		
18	.3475		
19	.4805		
20	.499		
21	.4481		
22	.4066		
23	.3696		
24		.3326	.3224
Max	.499	.3696	.3696
Min	.3142	.3326	.3224
Avg	.3975	.3480	.3556

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 204 / 11 kv Manjarsumba -GFSS-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2587	.2957
2		.2772	
3		.2957	
4		.3142	
5		.4066	
6		.5359	
7		.5359	
8		.5359	
12	.2926		
13	.2587		
14	.2378		
15	.2402		
16	.2587		
17	.2957		
18	.3109		
19	.5175		
20	.4805		
21	.4805		
22	.3326		
23	.2772		
24		.2587	.2957
Max	.5175	.5359	.2957
Min	.2378	.2587	.2957
Avg	.3319	.3799	.2957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 206 / 11 KV SASEWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3326	.3696
2		.3326	.3696
3		.3511	.4066
4		.3696	.4066
5		.4066	.4066
16	.1478		
17	.1463		
18	.1663		
19	.3326		
20	.3511		
21	.3881		
22	.3511		
23	.3326		
24		.3326	.3696
Max	.3881	.4066	.4066
Min	.1463	.3326	.3696
Avg	.2770	.3542	.3881

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 207 / DHANGARWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2218	.2218
2		.2402	.2587
3		.2402	.2957
4		.2957	.3326
5		.3881	.462
6		.5359	.5544
7		.5853	.5544
8		.5175	.5175
9			.4805
10			.3696
12	.2195		
13	.2033		
14	.2012		
15	.1663		
16	.2218		
17	.2561		
18	.3142		
19	.5175		
20	.4435		
21	.3511		
22	.3142		
23	.2772		
24		.2218	.2218
Max	.5175	.5853	.5544
Min	.1663	.2218	.2218
Avg	.2905	.3607	.3881

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 208 / UDARMAL (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)
1		.2402
2		.2587
3		.2587
4		.3142
5		.4066
6		.5544
7		.567
8		.5487
12	.2195	
13	.2195	
14	.1646	
15	.1848	
16	.2218	
17	.2587	
18	.2957	
19	.5175	
20	.5914	
21	.5487	
22	.3326	
23	.2957	
24		.2587
Max	.5914	.567
Min	.1646	.2402
Avg	.3209	.3786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 209 / 11 KV IMAMPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)
1		.3812
2		.3812
3		.4144
4		.4144
5		.431
6		.5898
7		.9503
8		1.0774
12	.9175	
13	.8322	
14	.7449	
15	.7537	
16	.6882	
17	.6554	
18	.6962	
19	.8131	
20	.2218	
21	.2218	
22	.1663	
23	.1663	
24		.3647
Max	.9175	1.0774
Min	.1663	.3647
Avg	.5731	.5560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014038 / 33/11 KV CHICHONDI PATIL

Feeder No / Name : 202 / Takli kazi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6859	.1698	.2075
2	.8535	.1509	.2263
3	.9061	.1886	.2263
4	.9998	.2075	.2263
5	1.0753	.2263	.2452
6	1.1069		
7	1.989		
8	2.0553		
9	1.4969		
12		1.9393	1.5384
13		1.6644	1.5384
14		1.5844	1.4083
15		1.4864	1.1385
16	.1663	1.4083	1.2651
17	.1307	1.4232	1.1591
18	.1494	1.5339	1.0425
19	.2241	1.1126	.8762
20	.2241	.2241	.1867
21	.2263	.2263	.2241
22	.2075	.2075	.2241
23	.1886	.2263	.1867
24	.6249	.1886	.2075
Max	2.0553	1.9393	1.5384
Min	.1307	.1509	.1867
Avg	.7395	.7871	.6737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014038 / 33/11 KV CHICHONDI PATIL

Feeder No / Name : 204 / 11 kv Athwad -GFSS-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2303	.2303	.2303
2	.2126	.2303	.2481
3	.2481	.2481	.2835
4	.3189	.3189	.3721
5	.443	.4607	.4961
6	.6379	.6201	.7087
7	.815	.815	.8505
8	.7796	.7265	.7442
9	.6556	.5316	.6024
10	.4961	.3721	.4075
11	.3189	.3189	.3366
12	.2481	.2658	.2835
13	.2481	.2481	.2481
14	.2126	.2835	.2303
15	.2481	.2658	.2126
16	.2658	.2658	.2481
17	.2835	.2835	.2835
18	.3898	.3544	.3898
19	.5493	.5847	.5316
20	.4961	.5138	.4961
21	.4075	.4075	.4252
22	.3544	.3544	.3898
23	.2835	.2658	.2835
24	.2303	.2303	.2303
Max	.815	.815	.8505
Min	.2126	.2303	.2126
Avg	.3905	.3832	.3972



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014038 / 33/11 KV CHICHONDI PATIL

Feeder No / Name : 205 / 11 kv Renuka Devi ( C.      SEPARATED AG FEEDERS HAVING SPECIAL  
 Patil ) Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1646	1.0105	.9023
2	.1448	1.0669	1.0151
3	.1448	1.0669	1.2452
4	.1646	1.2186	1.3672
5	.2033	1.2967	1.4563
6		1.3441	1.5352
7		2.0405	2.5446
8		2.5911	3.0333
9		2.198	1.7236
12	2.5911		
13	2.672		
14	2.4006		
15	2.2809		
16	2.4528	.1294	.1307
17	1.9966	.1463	.1494
18	2.4996	.1463	.1848
19	2.0805	.2402	.2402
20	.2402	.2402	.2402
21	.2353	.2218	.2172
22	.2126	.2012	.181
23	.1949	.2012	.1595
24	.1829	.9214	.8253
Max	2.672	2.5911	3.0333
Min	.1448	.1294	.1307
Avg	1.1590	.9045	.9528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 201 / Kaudgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							1.4737
8				.1457		1.9281	2.5263
12					2.0622		
15					2.5149		
16			2.332				.0972
24	.1296	.144	.1357	.1296	.1619	.8688	1.166
Max	.1296	.144	2.332	.1457	2.5149	1.9281	2.5263
Min	.1296	.144	.1357	.1296	.1619	.8688	.0972
Avg	.1296	.144	1.2339	.1377	1.5797	1.3985	1.3158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 202 / Mehekari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.1515	1.531
2		1.1302	1.5828
3		1.1431	1.6004
4		1.2376	1.6491
5		1.4053	3.238
6		1.7612	2.1963
7		2.5126	3.1718
8		3.2983	6.4198
9		4.5592	3.4804
16		.109	.2424
17	2.0218	.1105	.1181
18	3.0788	.109	.1326
19	2.9066	.1699	.1699
20	.2149	.2195	.2256
21	.1997	.2042	.2119
22	.1913	.1859	.1882
23	.3239	.2187	.2241
24	1.1683	1.531	2.6452
Max	3.0788	4.5592	6.4198
Min	.1913	.109	.1181
Avg	1.2632	1.1698	1.6126

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 203 / 11 kv Parewadi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.1875
8			2.2405	2.2809	2.2558		
12						2.4478	2.0325
14						2.4863	
16			.1829		.218		2.2405
17						2.4813	
24	.8436	.8749	.8817	.8745	.9061	2.4863	.1718
Max	.8436	.8749	2.2405	2.2809	2.2558	2.4863	2.2405
Min	.8436	.8749	.1829	.8745	.218	2.4478	.1718
Avg	.8436	.8749	1.1017	1.5777	1.1266	2.4754	1.1581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 204 / 11 kv pargaon-GFSS-

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.439
8			.5487	.5853	.6401	.6173	.7316
12					.1372		.2241
15					.1448		
16			.1097				.1867
24	.1829	.1867	.1753	.1867	.1867	.1867	.2241
Max	.1829	.1867	.5487	.5853	.6401	.6173	.7316
Min	.1829	.1867	.1097	.1867	.1372	.1867	.1867
Avg	.1829	.1867	.2779	.386	.2772	.402	.3611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 205 / 11 kv Shahapur -GFSS-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							1.0242
8			1.39	1.4632	1.4842	1.3032	1.4632
12					.6036		.7095
15					.5365		
16							.6219
24	.5487	.6722	.5258	.5975	.6722	.5975	.5975
Max	.5487	.6722	1.39	1.4632	1.4842	1.3032	1.4632
Min	.5487	.6722	.5258	.5975	.5365	.5975	.5975
Avg	.5487	.6722	.9579	1.0304	.8241	.9504	.8833

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 206 / 11 kv Pimpalgaon Landga SEPARATED AG FEEDERS HAVING SPECIAL  
 (AG) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.8745	.8322	.8002		
12							.3563
16			.1219				1.0364
24	.3688	.4191	.4409	.4534	.4359	.0732	.0648
Max	.3688	.4191	.8745	.8322	.8002	.0732	1.0364
Min	.3688	.4191	.1219	.4534	.4359	.0732	.0648
Avg	.3688	.4191	.4791	.6428	.6181	.0732	.4858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 208 / 11 kv Barababhali  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.2286
8			1.3413	1.3904	1.3413		
12							1.0722
14						1.5083	
16			.2134				1.0562
17						1.1904	
24	.4481	.4999	.5087	.4062	.3841	.2149	.1981
Max	.4481	.4999	1.3413	1.3904	1.3413	1.5083	1.0722
Min	.4481	.4999	.2134	.4062	.3841	.2149	.1981
Avg	.4481	.4999	.6878	.8983	.8627	.9712	.6388



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014040 / 33/11 KV DEHARE S/STN

Feeder No / Name : 201 / 11 kv Gawaliwada

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
16	.1357
22	.2835
Max	.2835
Min	.1357
Avg	.2096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014040 / 33/11 KV DEHARE S/STN

Feeder No / Name : 202 / 11 kv Dehare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
17	2.5587
22	.394
Max	2.5587
Min	.394
Avg	1.4764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014040 / 33/11 KV DEHARE S/STN

Feeder No / Name : 203 / 11 KV Nandgaon (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
22	.3814
Max	.3814
Min	.3814
Avg	.3814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 205 / 11 kv Hiware zare  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3986	.4146	.4062	.4397	.4153	.6127	.7095
2	.4207	.4374	.439	.4473	.4466	.6516	.7369
3	.4588	.458	.4641	.4626	.4557	.6973	.7796
4	.2736	.4733		.471	.4672	.7545	.8787
5					.1547	.9046	1.0021
6						1.2605	1.3656
7						1.7436	1.8968
8						1.8282	1.9502
9						.9526	.7202
11	1.262	1.2391	1.2582		1.3504		
12	1.4487	1.3885	1.3733	.9953	1.4655		
13	1.4792	1.4076	1.2696	1.3184	1.4609		
14	1.4769	1.2887	1.1866	1.2704	1.3466		
15	1.4807	1.2772	1.1424	1.2872	1.278		.2469
16	1.4982	1.3634	1.2026	1.4159	1.025		.2904
17	1.1241	1.3321	1.31	1.5211	1.2254		.3292
18	1.2544	1.4083	1.3428	1.5706	1.2971	.3003	.4222
19	.5121	.5502	.2957	.6356	.5319	.1113	.3932
21	.4245	.439	.4207	.426	.4237	.4047	.4618
22	.4123	.4176	.4169	.4237	.4062	.3673	.4351
23	.3993	.4039	.4062	.4009	.5037	.647	.5601
24	.3849	.3864	.4031	.3818	.5594	.6805	.618
Max	1.4982	1.4083	1.3733	1.5706	1.4655	1.8282	1.9502
Min	.2736	.3864	.2957	.3818	.1547	.1113	.2469
Avg	.8652	.8638	.8336	.8417	.8230	.7944	.7665

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 203 / 11 kv Math pimpri SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2915	
2		.2915	
3		.3429	
4		.3944	
5		.583	
8			1.5729
9	1.7284		1.6644
12		1.9719	
14		1.6289	
16		1.9719	
17	.2058	2.2436	.2572
18	.2572	1.6362	.2572
19	.4801		.3086
20	.4973	.4877	.3429
21	.4801		.3429
22	.3772		.3429
23	.3086		.3429
24		.3086	
Max	1.7284	2.2436	1.6644
Min	.2058	.2915	.2572
Avg	.5418	1.0127	.6035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 204 / 11 kv Shiradhon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.5658	
9		1.286	
16		.3429	.4801
17	1.9004	.4801	.5144
18	1.166	.4801	.6001
19	1.0045	.8916	.9431
20	1.0631	1.0288	1.2003
21	1.0288		1.2003
22	.9431		1.0288
23	.6859		.9431
24	1.7147	.5487	
Max	1.9004	1.286	1.2003
Min	.6859	.3429	.4801
Avg	1.1883	.703	.8638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 207 / Ambilwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2572	
2			.2743	
3			.2915	
4			.3258	
5			.3429	
6			.4115	
7			.4801	
8			.4973	.5243
9			.4287	.5761
12	.4915	.4588		
13		.5121		
14		.4374		
15		.4374		
16		.4527	.1372	
17		.4458	.1372	
18		.4973	.1658	
19		.4458	.2401	
20		.2401	.2743	.1372
21		.2058	.2743	.1372
22		.2058		.1372
23		.1886		.1715
24			.2743	
Max	.4915	.5121	.4973	.5761
Min	.4915	.1886	.1372	.1372
Avg	.4915	.3773	.3008	.2806

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 208 / 11 kv Ralegan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2743	
2		.3086	
3		.4801	
4		.3772	
5		.4458	
6		.6001	
9	1.873		
12		2.3529	1.6964
13		2.1948	1.704
14		1.8519	1.7532
15		1.8347	
16			1.7833
17	.2401	1.6278	1.8347
18	.2401	1.6712	1.8004
19	.4973		1.7661
20	.5144	.703	.4973
21	.4973		.4801
22	.433		.3772
23	.3601		.2572
24	.2772	.2572	
Max	1.873	2.3529	1.8347
Min	.2401	.2572	.2572
Avg	.5481	1.0700	1.2682



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 209 / VENKATESHWRA HATCHRIES  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2572	
2		.2743	
3		.2572	
4		.2743	
5		.2743	
6		.2743	
7		.2572	
8		.2401	.2622
9	.2105	.1886	.16
10	.1696	.2058	
11	.1802	.1715	
12	.1677	.1886	
13	.1475	.1715	.1638
14	.144		.213
15	.208		
16	.2641	.1886	.1715
17	.2452	.1867	.1886
18	.2452	.1949	.1886
19	.1715	.2012	.1715
20	.2229		.2058
21		.2054	.1886
22	.2229		.2229
23	.2572		.2058
24		.1949	
Max	.2641	.2743	.2622
Min	.144	.1715	.16
Avg	.2040	.2214	.1952

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014044 / 33/11 KV BHOIRE PATHAR

Feeder No / Name : 202 / Chass

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014044 / 33/11 KV BHOIRE PATHAR

Feeder No / Name : 203 / PIMPALGAON KAUDA (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-FEB-17
HR	Load (MW)
24	.1886
Max	.1886
Min	.1886
Avg	.1886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014044 / 33/11 KV BHOIRE PATHAR

Feeder No / Name : 204 / SONEWADI (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-FEB-17
HR	Load (MW)
1	.1715
2	.1543
24	.1886
Max	.1886
Min	.1543
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 201 / Jakhangaon (New)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	20-FEB-17
HR	Load (MW)
19	.6653
Max	.6653
Min	.6653
Avg	.6653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 202 / Hiware Bazar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	20-FEB-17
HR	Load (MW)
19	.1463
Max	.1463
Min	.1463
Avg	.1463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 204 / Nimgaonwagha GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	20-FEB-17
HR	Load (MW)
19	.3582
Max	.3582
Min	.3582
Avg	.3582

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 205 / HINGANGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	20-FEB-17
HR	Load (MW)
19	.3189
Max	.3189
Min	.3189
Avg	.3189



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 206 / 11 kv Pimpalgaon (AG)  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)
19	.1663	
24		.0503
Max	.1663	.0503
Min	.1663	.0503
Avg	.1663	.0503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014158 / NARAYAN DOH

Feeder No / Name : 201 / 11 KV Nimbodi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)
17		.3982
21		.4382
23		.3681
24	.3601	.4531
Max	.3601	.4531
Min	.3601	.3681
Avg	.3601	.4144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014158 / NARAYAN DOH

Feeder No / Name : 202 / 11 kv Mandwa

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
17	.2378
19	.4119
21	.3506
23	.2427
24	.3479
Max	.4119
Min	.2378
Avg	.3182

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014158 / NARAYAN DOH

Feeder No / Name : 203 / 11 kv Walunj Pargaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
17	2.0243
19	1.6842
21	.4681
23	.3601
24	.3561
Max	2.0243
Min	.3561
Avg	.9786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014158 / NARAYAN DOH

Feeder No / Name : 204 / venkateshwara  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	21-FEB-17
HR	Load (MW)
17	.2075
19	.1509
21	.1509
23	.0943
24	.0914
Max	.2075
Min	.0914
Avg	.139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014032 / 33/11 KV SOLAPUR RD.

Feeder No / Name : 201 / 11 kV Ashoka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9084	.8338	.4275	.4321	.5014	.4222	.5014
2	.8856	.7956	.4207	.4123	.4763	.413	.4809
3	.8688	.7742	.4268	.4024	.4664	.4504	.4618
4	.8216	.7774	.4329	.4077	.4672	.4207	.4656
5	.919	.8658	.4656	.439	.4908	.4656	.4969
6	1.0654	1.0028	.5586	.4984	.5159	.5517	.5906
7	1.0638	1.035	.5921	.5289	.5251	.5639	.5639
8	1.134	1.047	.5662	.5746	.5838	.5792	.5495
9	1.1888	1.2726	.6089	.6927	.6356	.6036	.6302
10	1.2726	1.2848	.6363	.74	.6653	.6676	.6607
11	1.2086	1.2102	.6401		.6318	.6546	.6432
12	1.1888	1.227	.6722		.6424	.6539	.6188
13	1.1782	1.1446	.618	.7735	.5845	.6341	.1722
14	1.0638	1.131	.554	.7522	.5708	.6043	.7125
15	1.076	1.1172	.5731	.6668	.5655	.5906	.6661
16	.9862	1.0562	.5716	.631	.506	.6104	.6287
17	1.0868	1.0502	.5769	.6226	.5037	.599	.6127
18	1.1614	1.0212	.602	.6059	.5502	.6241	.6318
19	1.3808	1.3276	.7042	.7225	.6622	.7468	.7285
20	1.3702	1.3016	.6897	.7011	.6729	.6943	.7064
21	1.2772	1.256	.6379	.6615	.6615	.6653	.6562
22	1.1796	1.1568	.6028	.6409	.6249	.6127	.6173
23	1.0456	1.0196	.519	.5411	.5495	.5601	.5632
24	.9328	.9434	.4496	.506	.455	.5129	.4679
Max	1.3808	1.3276	.7042	.7735	.6729	.7468	.7285
Min	.8216	.7742	.4207	.4024	.455	.413	.1722
Avg	1.0943	1.0688	.5644	.5888	.5629	.5792	.5761

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014032 / 33/11 KV SOLAPUR RD.

Feeder No / Name : 202 / 11 kV Ganj Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.522	.5114	.5418	.5327	.5662	.5578	.5746
2	.4854	.4854	.5114	.5091	.5258	.5243	.5533
3	.4641	.4633	.4969	.4893	.5098	.5068	.5205
4	.4565	.5365	.4931	.5373	.4969	.5929	.5106
5	.487	.554	.5289	.5548	.5434	.602	.5578
6	.7217	.5883	.66	.5937	.759	.6554	.7529
7	.8977	.7575	.9945	.7407	.8558	.8147	.9808
8	.8726	.807	1.009	.8421	.8665	.8802	.9633
9	.9496	.8977	1.0159	.9374	.9953	.9922	1.0181
10	.9221	.8901	1.0212	.9663	1.0532	1.0364	1.0372
11	.8726	.8657	1.0463	.8779	.9686	1.0098	.9907
12	.8726	.9275	1.1073		1.025	1.0235	1.0265
13	.7766	.8954	1.1073		.9892	1.0326	1.0075
14	.2431	.8284	1.0319	1.2544	.897	.8985	.9991
15	.7705	.7529	.8833	1.0875	.7804	.9099	.9488
16	.7392	.7377	.8284	.9671	.7514	.8871	.929
17	.7407	.7834	.865	.9168	.7834	.9374	.948
18	.7979	.8878	.9396	.9823	.8101	1.0646	.9739
19	1.1111	1.3923	1.2201	1.3039	1.1363	1.3801	1.3862
20	1.1111	1.4045	1.3329	1.3359	1.1317	1.3664	1.3824
21	.9488	1.2026	1.1957	1.2353	1.0578	1.2643	1.2445
22	.7484	.8886	.9107	.9168	.8436	.9328	.9175
23	.6645	.7301	.7423	.7385	.7354	.7644	.7827
24	.5594	.6066	.602	.6455	.6188	.6432	.6584
Max	1.1111	1.4045	1.3329	1.3359	1.1363	1.3801	1.3862
Min	.2431	.4633	.4931	.4893	.4969	.5068	.5106
Avg	.7390	.8081	.8786	.8621	.8209	.8866	.9027

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014032 / 33/11 KV SOLAPUR RD.

Feeder No / Name : 203 / 11 kV Darewadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5289	.5617	.5327	.5548	.5708	.5456	.6371
2	.5045	.535	.5121	.5335	.5418	.5258	.615
3	.5053	.5266	.5129	.5281	.5106	.5129	.5914
4	.5228	.5533	.5312	.5319	.5281	.5205	.5952
5	.6417	.6577	.6622	.6424	.6257	.6501	.7636
6	1.1264	1.1957	1.214	1.0372	.9404	1.1431	1.2483
7	1.4967	1.5127	1.4746	1.5882	1.1424	1.5409	1.5821
8	1.5729	1.6209	1.5874	1.7543	1.7101	1.6011	1.6918
9	1.5935	1.579	1.5485	1.6972	1.7055	1.6941	1.7269
10	1.4289	1.4411	1.3999	1.438	1.6278	1.5364	1.5958
11	1.2018	1.2033	1.2323	1.2597	1.2437		1.2993
12	1.0745	1.0654	1.1195		.8901		1.1561
13	1.0692	.9998	1.0585		1.041	.6417	1.0951
14	.9808	.9	.9678	1.1591	.961	1.4106	1.0059
15	.9877	.9244	.9473	1.0791	.9755	1.2902	.9922
16	.9793	.9313	.1997	1.1104	1.0661	1.2856	1.0159
17	.9976	.9831		1.1599	1.1134	1.2917	1.0745
18	1.1111	1.102	1.1081	1.2498	1.1355	1.374	1.1759
19	1.1988	1.23	1.3839	1.3756	1.2269	1.4807	1.3634
20	1.23	1.2178	1.3984	1.3656	1.2437	1.4647	1.3496
21	1.0486	1.1149	1.1949	1.201	1.0761	1.2498	1.2285
22	.9229	.977	.9838	1.0334	.9587	1.1096	1.0867
23	.7796	.7598	.8017	.8124	.7697	.8985	.8543
24	.6028	.6013	.6234	.6645	.618	.7171	.6889
Max	1.5935	1.6209	1.5874	1.7543	1.7101	1.6941	1.7269
Min	.5045	.5266	.1997	.5281	.5106	.5129	.5914
Avg	1.0044	1.0081	.9998	1.0807	1.0093	1.1129	1.1014



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014032 / 33/11 KV SOLAPUR RD.

Feeder No / Name : 205 / 11 kV MES-II

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5022	.4881	.5632	.5228	.6329	.5018	.3967
2	.3727	.4813	.5578	.5205	.6249	.3708	.4157
3	.3688	.4801	.4256	.4763	.5746	.3669	.5445
4	.3666	.503	.4565	.4759	.4329	.3715	.5476
5	.4527	.6314	.5578	.6222	.4123	.4546	.6386
6	.8215	.9461	.8204	.8051	.6211	.7598	.9134
7	.852	.9435	.8383	.7952	.6569	.7625	.9297
8	.8048	.8128	.8459	.8566	.7598	.7308	.8307
9	.7598	.8886	.716	.7266	.9358	.7221	.7263
10	.6653	.8413	.7522	.8836	.8863	.74	.6946
11	.61	.6169	.7918	.7853	.8299	.6504	.5738
12	.66	.4816	.767		.6615	.5228	.5251
13	.5921	.4656	.7457		.4965	.4607	.6878
14	.5655	.4412	.6348		.4245	.4245	.6443
15	.413	.3883	.4572		.3494	.5327	.5761
16	.386	.3849	.4344	.6333	.3387	.6459	.5765
17	.4005	.4009	.4157	.6683	.3936	.4191	.3635
18	.4439	.447	.4599	.6588	.4641	.4237	.4614
19	.6367	.6432	.6043	.6645	.6413	.6348	.6123
20	.7278	.7343	.7038	.7766	.8349	.7106	.6912
21	.6809	.7129	.7122	.7484	.7667	.6889	.6847
22	.5796	.6767	.7617	.7251	.7103	.6203	.6276
23	.4668	.6946	.6973	.6177	.6748	.4874	.6878
24	.3909	.6036	.5952	.5243	.6104	.4203	.647
Max	.852	.9461	.8459	.8836	.9358	.7625	.9297
Min	.3666	.3849	.4157	.4759	.3387	.3669	.3635
Avg	.5633	.6128	.6381	.6744	.6139	.5593	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014162 / 33 KV Vidyut Bhavan

Feeder No / Name : 201 / Market Yard

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	1.7947	1.8237	1.818	1.9708	1.8288	.9998
2	.8391	.8284	.8223	.8581	.9549	1.7604	.9381
3	1.6111	1.6015	1.6812	1.717	1.7711	1.7177	.9
4	.7941	.7804	.8139	.8772	.9435	1.6903	.8787
5	.8177	.8048	.8543	.9099	.964	1.7833	.9297
6	.9701	1.0044	1.0159	1.0448	1.0791	2.2337	1.1081
7	2.8612	2.8654	2.9366	2.8392	2.6528	2.9622	1.4731
8	3.1108	2.9991	3.1592	3.0437	2.982	3.0399	1.5104
9	2.9428	1.5234	3.0361	2.9125	3.0057	3.0193	2.8966
10	1.4419	1.4777	2.7481	2.6334	1.5524	1.4076	1.454
11	1.4083	1.3519	1.3336	1.294	1.371	1.3778	1.3314
12	1.2872	2.2952	2.5605	1.1888	2.4504	2.5415	1.2582
13	1.1645	1.1393	.2675	1.1469	1.1843	2.4257	1.1546
14	1.1271	1.0745	2.3983	1.1088	2.09	2.3224	1.1279
15	1.0761	1.0227	2.7838	2.1369	2.0309	2.3293	1.2513
16	2.0675	1.1477	2.396	1.0898	2.0368	2.3965	1.2582
17	2.1449	2.2348	2.3351		2.0085	2.5667	2.3891
18	2.4592	2.5133	2.5431	2.1967	1.0547	2.5583	1.2643
19	2.9515	2.9054	3.0567	3.6201	2.8199	3.2676	3.0788
20	2.9714	2.9051	3.0289	1.8816	2.9207	3.2408	1.6446
21	2.739	2.7797	2.7995	1.6225	2.7348	2.8906	1.4899
22	2.6136	1.3817	2.6509	1.4807	2.5705	2.8274	1.4327
23	2.4265	2.4107	1.2742	1.4198	1.2376	2.5849	1.3656
24	2.0024	1.0852	2.5575	1.1767	2.5896	2.146	2.1902
Max	3.1108	2.9991	3.1592	3.6201	3.0057	3.2676	3.0788
Min	.7941	.7804	.2675	.8581	.9435	1.3778	.8787
Avg	1.8635	1.7470	2.1199	1.7399	1.9573	2.3716	1.4719

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014162 / 33 KV Vidyut Bhavan

Feeder No / Name : 202 / Sarasnagar  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	1.1027	1.0631	1.0737	1.1339	1.2651	.6798
2	.5944	.5822	.5708	.5845	.5853	1.2199	.6386
3	1.0418	1.0059	1.0029	1.0121	.972	1.2011	.6241
4	.6089	.5906	.5815	.5807	.5746	1.2192	.6348
5	.6615	.6744	.644	.6592	.6638	1.4081	.7194
6	.8893	.9236	.8802	.8657	.8444	1.9715	.9549
7	2.2068	2.3019	2.3004	2.2687	.9351	2.4866	1.243
8	2.3063	2.2462	2.4648	2.3179	2.9032	2.5983	1.3123
9	2.208	1.259	2.0832	2.28	2.5705	2.2889	1.2338
10	1.0875	1.0936	1.7536	1.0921	1.1279	1.0273	1.009
11	.8627	.8703	.849	.8711	.9816	.8695	.8093
12	.7948	1.4032	1.4959	.7956	1.6762	.7827	.7918
13	.7019	.6943	.7423	.7263	.8291	1.4592	.7926
14	.6851	.6798	1.3271		1.3771	1.3633	.7499
15	.6424	.6714	1.2536		1.302	1.3344	.6866
16	.6843	.6981	.0229	.8848	1.3967	1.4386	.6943
17	.7125	1.3352		1.5882	1.418	1.4556	1.4273
18	1.6012	1.4845	1.8686	1.5962	.7971	1.5931	.7872
19	1.9266	1.9586	2.1224	1.9161	2.1857	2.2062	2.1583
20	2.0729	2.0474	2.0874	1.1218	2.2485	2.3072	1.1759
21	1.9054	1.8486	1.9444	1.0852	2.1289	2.1257	1.169
22	1.8023	.977	1.7448	1.0448	1.9249	1.9843	1.0966
23	1.4788	1.4539	.8688	.9297	1.6423	1.7498	.9823
24	1.2292	.6927	.6729	.7842	.7316	1.3965	1.488
Max	2.3063	2.3019	2.4648	2.3179	2.9032	2.5983	2.1583
Min	.5944	.5822	.0229	.5807	.5746	.7827	.6241
Avg	1.2225	1.1915	1.3193	1.1854	1.3729	1.6147	.9941

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 402 / 33 kV KINETIC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.738	3.4637	3.8752	3.8409	3.7723	3.4637	3.8752
2	3.5322	3.3951	3.6694	3.6351	3.6694	3.4294	3.6008
3	3.7723	3.5665	3.8752	3.8066	3.6694	3.5665	3.8752
4	3.6694	3.6694	3.7037	3.7723	3.6694	3.5665	3.6694
5	3.5322	3.8752	3.8752	3.6694	3.8066	3.5665	3.7723
6	3.6008	3.9095	3.6694	3.7723	3.8066	3.6694	3.8066
7	3.8409	4.0466	3.8066	3.9095	3.9095	3.9095	3.9781
8	4.2181	4.2524	3.9095	4.0809	4.0124	4.0124	3.9438
9	5.3155	4.1495	4.4925	3.9095	4.3553	4.2181	4.1152
10	4.6982	4.2181	5.0069	3.5665	4.8697	4.1838	4.1838
11	5.2812	4.9726	5.1783	3.4979	4.3553	4.7668	4.1495
12	5.6584	5.1097	4.9726	3.7723	4.8011	5.0412	4.1838
13	4.7325	3.8066	4.0466	3.5665	4.6296	4.561	3.9781
14	5.5213	5.4184	5.4527	3.738	5.4527	5.8299	4.8354
15	5.9671	4.6982	5.0069	3.738	5.5556	5.7956	5.4527
16	5.3155	5.144	3.8752	3.8409	4.321	4.8697	4.8354
17	4.4582	4.9726	4.8697	3.8752	5.0755	5.0069	4.1495
18	4.904	4.6639	4.8011	3.9095	4.7325	4.6982	4.6639
19	4.4582	4.5953	4.561	3.8066	4.561	4.4582	4.5268
20	4.1495	4.4239	4.1152	3.6694	4.3896	4.2524	4.321
21	3.8752	3.8409	3.4979	3.6694	3.2236	3.8409	3.7037
22	4.1838	4.1838	3.9438	3.6008	3.9095	4.1495	4.2524
23	3.7037	4.1838	4.2867	3.6351	4.1152	3.8409	4.0466
24	3.9438	4.0809	3.738	3.738	3.4979	3.6351	3.9438
Max	5.9671	5.4184	5.4527	4.0809	5.5556	5.8299	5.4527
Min	3.5322	3.3951	3.4979	3.4979	3.2236	3.4294	3.6008
Avg	4.4196	4.2767	4.2596	3.7509	4.2567	4.2638	4.1610

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014034 / 33 KV SAWEDI

Feeder No / Name : 202 / 11 KV FAKIRWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.3032	1.2403	1.3611	1.1218		1.1222
10	1.134	1.1403	1.2127	1.0136		
11	.9412	.9328		1.0136		
12	.8916	.8507	1.1043	.8764	.8402	
13	.8745		1.1568			
14	.7545					
15	.6415		.6733	.6733		
16	.583					
17		.6089				
18		.724				
Max	1.3032	1.2403	1.3611	1.1218	.8402	1.1222
Min	.583	.6089	.6733	.6733	.8402	1.1222
Avg	.8904	.9162	1.1016	.9397	.8402	1.1222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014034 / 33 KV SAWEDI

Feeder No / Name : 209 / 11KV MUKUND NAGAR  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.8461	1.7364	1.8267	1.7353		1.7909
10	1.6644	1.4299	1.7918	1.5203		
11	1.4299	1.4266		1.2489		
12	1.2346	1.2127	1.6651	1.1568	1.1831	
13	1.2346		1.6476			
14	1.0974					
15	.9189		.9036	.9036		
16	.8745					
17		.8238				
18		.9593				
Max	1.8461	1.7364	1.8267	1.7353	1.1831	1.7909
Min	.8745	.8238	.9036	.9036	1.1831	1.7909
Avg	1.2876	1.2648	1.5670	1.3130	1.1831	1.7909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 201 / 11 kV Maliwada

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	1.9952	.9656	.9884	1.0235	.9922	1.0501
2	1.8732	1.8732	.9282	.9343	.9785	.964	1.0189
3	1.8748	1.8686	.9198	.9282	.9526	.9717	.9808
4	1.9266	2.1506	.9358	1.0822	.9427	1.1104	.9739
5	2.1094	2.4112	1.0433	1.2048	1.0174	1.2574	1.0905
6	2.8684	3.0086	1.4068	1.4594	1.3054	1.4906	1.4487
7	3.2784	3.3638	1.6232	1.64	1.4754	1.6514	1.6354
8	3.597	3.719	1.9227	1.8945	1.736	1.7673	1.781
9	3.7556	3.6672	1.9799	1.9692	1.8488	1.8534	1.8305
10	3.7038	3.6672	2.0248	1.941	1.8244	1.9441	1.8503
11	3.7174	3.5376	2.0187	1.864	1.8618	1.9486	1.9037
12	3.751	3.69	2.0233	1.8244	1.8252	2.05	1.9677
13	3.5498	3.5102	2.0012	1.7474	1.7337	1.922	1.9296
14	3.4628	3.3272	1.7962	1.6575	1.6202	1.7917	1.7383
15	3.312	3.3104	1.7223	1.6347	1.5242	1.7833	1.7802
16	3.1656	3.2084	1.6758	1.6751	1.4883	1.8328	1.8115
17	3.44	3.2008	1.7695	1.7032	1.4365	1.8534	1.8587
18	3.6352	3.5148	1.957	1.8374	1.5226	1.9006	1.8938
19	4.1884	4.289	2.1933	2.2077	1.9364	2.2756	2.2649
20	4.0878	4.1336	2.143	2.1293	1.9044	2.1879	2.1735
21	3.565	3.5604	1.858	1.8877	1.6819	1.8922	1.9159
22	3.0926	3.1092	1.544	1.5722	1.5447	1.6118	1.592
23	2.7252	2.6414	1.3649	1.4137	1.3748	1.4114	1.4159
24	2.1994	2.1582	1.1058	1.1454	1.1164	1.169	1.1797
Max	4.1884	4.289	2.1933	2.2077	1.9364	2.2756	2.2649
Min	1.8732	1.8686	.9198	.9282	.9427	.964	.9739
Avg	3.1192	3.1215	1.6218	1.5976	1.4865	1.6514	1.6286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 203 / 11 KV GANESH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.91	.9084	.4557	.4512	.4466	.4854	.4679
2	.8718	.8658	.4283	.439	.4283	.4595	.4435
3	.8748	.852	.423	.4321	.4222	.458	.4367
4	.878	.9312	.4184	.4588	.426	.4847	.4443
5	.9708	1.1538	.4771	.5632	.4809	.6043	.5083
6	1.3154	1.5806	.6493	.8261	.5929	.8093	.7026
7	1.7178	1.8214	.8429	.9107	.708	.9275	.897
8	1.8702	1.9464	.9252	.9785	.8802	1.0219	.9511
9	1.9388	1.9586	.945	.9686	.9465	.9717	.897
10	1.605	1.5806	.7796	.8169	.8878	.8421	.7667
11	1.326	1.3244	.7072	.6706	.7514	.6866	.6783
12	1.2392	1.3138	.6478	.6219	.676	.6081	.6325
13	1.2682	1.1918	.5921	.5898	.5906	.6226	.6028
14	1.1934	1.1112	.551	.5967	.5312	.5891	.5792
15	1.1188	1.0074	.5838	.5632	.5053	.5578	.5815
16	1.076	1.073	.5876	.5716	.5075	.5403	.5853
17	1.2026	1.1492	.6074	.5891	.5182	.5662	.6142
18	1.4404	1.3642	.7125	.6539	.6219	.6798	.7019
19	1.6902	1.614	.8177	.8375	.8147	.8345	.8429
20	1.6858	1.614	.8383	.8299	.8573	.8589	.8634
21	1.5714	1.5576	.7819	.7545	.8032	.7948	.8101
22	1.4266	1.3992	.7385	.7049	.759	.7583	.7446
23	1.2468	1.2438	.6127	.6318	.6348	.6379	.6607
24	1.0136	1.0044	.503	.506	.5449	.519	.5479
Max	1.9388	1.9586	.945	.9785	.9465	1.0219	.9511
Min	.8718	.852	.4184	.4321	.4222	.458	.4367
Avg	1.3105	1.3153	.6511	.6653	.6390	.6799	.6650



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 204 / 11 KV Delhi gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.233	1.2604	.6158	.615	.7049	.6493	.695
2	1.1752	1.1736	.5784	.586	.6653	.6272	.663
3	1.1796	1.2026	.5777	.6097	.6523	.6493	.66
4	1.2194	1.5988	.6104	.7964	.6699	.8528	.6546
5	1.4434	1.8108	.7407	.8893	.7689	.9168	.7758
6	2.1506	2.2862	1.0692	1.153	.9107	1.1881	1.0715
7	2.745	2.684	1.2971	1.3725	1.185	1.3832	1.3603
8	2.876	2.9446	1.4647	1.4807	1.3222	1.4708	1.4403
9	2.9614	2.8562	1.4784	1.5066	1.3961	1.4899	1.4632
10	2.5788	2.5408	1.342	1.2849	1.3207	1.275	1.217
11	2.1262	2.2192	1.2308	1.1385	1.2262	1.1393	1.1858
12	2.047	2.024	1.1119		1.1698	1.0501	1.1027
13	.8108	1.855	1.0761		1.0623	1.0288	1.0585
14	2.0926	1.7528	.9922		.9785	.9968	1.0341
15	1.864		.9396		.8939	.964	.8855
16	1.8808	.2774	.9092		.8375	.9656	.9823
17	1.9098	1.9144	.9351		.9229	1.0402	.9739
18	2.3808	2.6338	1.182	1.6865	1.1081	1.2224	1.2254
19	2.6734	2.8076	1.3481	1.7292	1.2856	1.4495	1.4159
20	2.6338	2.7024	1.3268	1.5813	1.2612	1.4137	1.3382
21	2.3822	2.4554	1.2269	1.3001	1.1454	1.2711	1.2384
22	2.1034	2.108	1.0319	1.2056	1.038	1.1355	1.0867
23	1.8428	1.8138	.9023	1.0082	.884	.9701	.948
24	1.448	1.4098	.6927	.8078	.7354	.7766	.7575
Max	2.9614	2.9446	1.4784	1.7292	1.3961	1.4899	1.4632
Min	.8108	.2774	.5777	.586	.6523	.6272	.6546
Avg	1.9899	2.0144	1.0283	1.1529	1.0060	1.0803	1.0514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 205 / 11 KV CIVIL HOSPITAL  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1166	.1174	.0553	.0533	.0541	.0541	.0659
2	.1188	.1052	.056	.0526	.0522	.0518	.0636
3	.115	.1158	.0553	.0511	.0514	.0518	.0549
4	.115	.1174	.0575	.0495	.0537	.0503	.0564
5	.1128	.1036	.0579	.0492	.0511	.0522	.0629
6	.1196	.1052	.056	.053	.056	.0572	.0655
7	.1082	.1052	.0575	.0556	.0545	.0564	.0625
8	.1456	.122	.0709	.0762	.053	.0575	.0728
9	.1882	.1784	.096	.0941	.0732	.0972	.1033
10	.1936	.1912	.1075	.0964	.0819	.1036	.1174
11	.195	.1936	.109	.1002	.0758	.0979	.1113
12	.1944	.1912	.1097	.0987	.0716	.1109	.1052
13	.1996	.1746	.0926	.0838	.0686	.1082	.1025
14	.1806	.1616	.0846	.0781	.061	.0873	.0903
15	.1776	.1516	.0873	.0621	.061	.1059	.0895
16	.1456	.138	.0838	.0659	.0892	.0846	.0793
17	.1394	.144	.077	.0808	.0918	.0716	.0956
18	.1364	.1418	.0682	.0697	.0644	.0743	.0972
19	.1296	.1356	.0831	.0758	.0922	.0819	.0838
20	.1426	.1266	.0838	.0625	.0846	.0625	.0758
21	.1478	.1272	.0663	.061	.0697	.0629	.0739
22	.1486	.1318	.0606	.0633	.0636	.072	.0762
23	.154	.1266	.0568	.0575	.0587	.0655	.0629
24	.1348	.122	.0533	.0568	.056	.0648	.0587
Max	.1996	.1936	.1097	.1002	.0922	.1109	.1174
Min	.1082	.1036	.0533	.0492	.0511	.0503	.0549
Avg	.1483	.1387	.0744	.0686	.0662	.0743	.0803

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 207 / 11KV Shivaji Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.3224	.2972	.2957	.3246	.3109	.3429
2	.2705	.2911	.2782	.2774	.2987	.2904	.3231
3	.2599	.2827	.2705	.2751	.2957	.2888	.314
4	.2553	.2843	.2698	.2698	.2949	.2751	.3147
5	.269	.3056	.3041	.2926	.3368	.3079	.346
6	.4184	.4733	.4611	.426	.4306	.4298	.4641
7	.6409	.6683	.5967	.6135	.5548	.6203	.6302
8	.6699	.7148	.6691	.6356	.6607	.7019	.6821
9	.6226	.6752	.6325	.6112	.6577	.6752	.6523
10	.5152	.4931	.5281	.5327	.6302	.5815	.5411
11	.4458	.4458	.3628	.4534	.5929	.4824	.4626
12	.4047	.4009	.2949	.4359	.5022	.4519	.4115
13	.4336	.3894	.2721	.4237	.4755	.4077	.3666
14	.4169	.3414	.2683	.4123	.3742	.41	.3041
15	.3879	.3841	.3452	.3887	.3902	.4298	.3361
16	.3765	.4001	.3467	.3925	.3932	.4207	.3704
17	.4054	.3902	.3315	.4047	.4291	.426	.3719
18	.4176	.3795	.4123	.4298	.4199	.4169	.4039
19	.5967	.5304	.5898	.5815	.5235	.5632	.5639
20	.6371	.602	.6462	.5929	.5685	.6394	.5807
21	.618	.5891	.5693	.5746	.5251	.586	.5533
22	.5662	.5121	.551	.5342	.487	.5517	.5342
23	.4938	.4473	.4633	.4771	.4382	.4786	.4702
24	.4153	.3704	.3536	.378	.3452	.3932	.3628
Max	.6699	.7148	.6691	.6356	.6607	.7019	.6821
Min	.2553	.2827	.2683	.2698	.2949	.2751	.3041
Avg	.4513	.4456	.4214	.4462	.4562	.4641	.4459

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 208 / 11KV Balikashram

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0174	1.0067	1.0242	1.0075	1.0761	1.073	1.1858
2	.9572	.9564	.9793	.9663	1.0181	1.0143	1.1248
3	.9206	.9313	.9595	.9457	.9968	.9861	1.0799
4	.9244	.9427	.977	.9236	.9838	.98	1.0875
5	1.0105	1.0258	1.0608	1.0494	1.1004	1.0837	1.1942
6	1.4868	1.4098	1.4906	1.4708	1.4319	1.4784	1.6255
7	2.0104	1.8717	1.9425	1.8526	1.7878	1.9974	2.0896
8	2.0751	2.1094	2.0759	2.1018	2.0866	2.1392	2.2504
9	2.1018	2.1117	2.0713	2.13	2.1209	2.0744	2.1895
10	1.9494	1.8755	1.8816	1.9349	2.0393	1.909	1.9319
11	1.6728	1.7513	1.7017	1.752	1.8176	1.7322	1.7848
12	1.5257	1.6347	1.5158	1.5798	1.7193	1.6415	1.5935
13	1.4327	1.5577	1.483	1.4807	1.5295	1.5402	1.4967
14	1.2872	1.4365	1.3321	1.358	1.3016	1.4571	1.448
15	1.3146	1.3771	1.2529	1.3763	1.2872	1.4137	1.4091
16	1.3123	1.3596	1.2833	1.3977	1.323	1.5767	1.467
17	1.3763	1.3672	1.39	1.3977	1.4129	1.5386	1.4975
18	1.4304	1.4342	1.4899	1.4251	1.5325	1.6385	1.5607
19	1.7886	1.845	1.8503	1.8115	1.8587	1.9342	1.8633
20	1.7848	1.8145	1.8534	1.8221	1.8762	1.9502	1.9075
21	1.7017	1.765	1.752	1.7993	1.7749	1.8404	1.8419
22	1.5905	1.5844	1.6278	1.6415	1.6408	1.7253	1.6842
23	1.3809	1.4281	1.3999	1.4632	1.448	1.579	1.5592
24	1.1546	1.1858	1.1439	1.233	1.198	1.3199	1.3032
Max	2.1018	2.1117	2.0759	2.13	2.1209	2.1392	2.2504
Min	.9206	.9313	.9595	.9236	.9838	.98	1.0799
Avg	1.4669	1.4909	1.4808	1.4967	1.5151	1.5676	1.5907

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 201 / 11 KV L &amp; T

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9835	.9282	.9614		.4847	1.1096	
2	1.0288	.9724	.9945		.5144	1.0288	
3	.9835	.8962	.9175		.4755	1.1218	
4	1.0288	.9282	.9717		.4664	1.0985	
5	1.0288	.9374	.9602		.4664	1.1218	
6	1.0174	.9061	.9602		.5647	1.0288	
7	.9717	.9259	1.0242		.503	.9503	
8	1.0517	.9496	1.0059		.6737	1.1706	
9	1.358	1.4335	1.3443		1.3443	1.5844	
10	1.5684	1.358	1.5844		1.2826		
11	1.8107		1.6598		1.3443		
12	1.7177		1.5844		1.5844		
13			1.5089		1.5684		
14			1.6598		1.6598		
15			1.7353		1.6804		
16		1.7924	1.6598		1.7177		
17		1.6221	1.6409				
18		1.6032	1.4712			1.5844	
19	1.5089	1.5466					
20	1.1584	1.3306			1.3169		
21	1.3443	1.2567			1.1919		
22	1.2308	1.1706		.4443	.9816		1.2696
23	1.1584	1.1584		.4039	1.1462		1.2437
24	1.0402	1.0402	1.0402	.9259	.4755	1.1218	
Max	1.8107	1.7924	1.7353	.9259	1.7177	1.5844	1.2696
Min	.9717	.8962	.9175	.4039	.4664	.9503	1.2437
Avg	1.2217	1.1977	1.2992	.5914	1.0211	1.1746	1.2567

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 202 / 11 KV SHAPE WELL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.7956	.7225		.2012	.7225	
2	.7682	.7701	.6984		.2016	.7621	
3	.8097	.7362	.7225		.2515	.7225	
4	.7682	.7499	.6748		.2515	.7811	
5	.7773	.7621	.6485		.2599	.9069	
6	.8421	.5716	.7145		.2766	.9389	
7	.5609	.5258	.5449		.3102	.4778	
8	.5449	.8288	.7316		.4725	1.0402	
9	1.2696	1.1317	1.2826		.9412	1.5089	
10		1.358	1.4335		.9511		1.773
11	1.2071		1.3443		1.0136		
12	1.1203		1.2071		1.0562		
13			.8413		1.1203		
14			1.5089		1.1949		
15			.9808		1.1317		
16		.8962	1.2826		1.0456		
17		1.1576	1.5844				
18		1.1317	1.4335				
19	.8413	.7545			1.1706		
20	.8288	.9431			.5106		
21	.8288	.9602			.5639		
22	.6935	.7545		.1928	.6539		.8688
23	.8322	.8669		.2263	.7682		1.1827
24	.7773	.7545	.7499	.1928	.1844	.5792	
Max	1.2696	1.358	1.5844	.2263	1.1949	1.5089	1.773
Min	.5449	.5258	.5449	.1928	.1844	.4778	.8688
Avg	.8406	.8657	1.0056	.2040	.6605	.8440	1.2748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 203 / 11 KV VAIBHAV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3468	.365	.2538	.3308	.3482	.2599
2	.3674	.3491	.3738	.2469	.3323	.3605	.2538
3	.3856	.3498	.3582	.25	.314	.3529	.2614
4	.3719	.3475	.362	.2561	.3178	.3714	.2629
5	.3795	.3559	.3658	.2629	.3315	.3704	.2644
6	.3818	.358	.3673	.2629	.3338	.3698	.2728
7	.3666	.3603	.3875	.2477	.3391	.3993	.2561
8	.5453	.5097	.5179	.2561	.4455	.5361	.3208
9	.675	.6353	.7476	.2401	.6181	.822	.7468
10	.7186	.7384	.7735	.2271	.6813	.8634	.4123
11	.6866	.6843	.7463	.2309	.7339	.4199	.4451
12	.3673	.6493	.6818	.2309	.6051	.3826	.4397
13	.6089	.5899	.6257	.2431	.5483	.3315	.3376
14	.7011	.6074	.7346	.2446	.5792	.3597	.3925
15	.3452	.3041	.6958	.25	.6264	.3788	.3887
16	.6722	.6485	.7045	.2522	.6325	.397	.3925
17	.6082	.5186	.6016	.2599	.3467	.3772	.3582
18	.4877	.4526	.4982	.2599	.2865	.333	.602
19	.4131	.413	.2713	.2515	.4039	.2858	.2705
20	.3742	.418	.253	.2454	.3841	.266	.2644
21	.378	.399	.2553	.2515	.4017	.266	.2683
22	.3605	.3981	.2599	.3113	.3765	.2652	.4168
23	.3841	.4144	.2622	.3254	.3703	.2606	.4123
24	.3666	.3696	.3797	.4303	.3315	.3643	.2736
Max	.7186	.7384	.7735	.4303	.7339	.8634	.7468
Min	.3452	.3041	.253	.2271	.2865	.2606	.2538
Avg	.4711	.4674	.4829	.2621	.4446	.3951	.3572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 204 / 11 KV BOLHEGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	1.0136	.961		1.0349	1.0349	
2	.9145	.9412	.9145		.9511	.9511	
3	.8779	.905	.8779		.9145	.9145	
4	.9979	.9877	.961		1.0164	1.0349	
5	1.2696	1.2567	1.1576		1.2197	1.2696	
6	1.9616	2.0165	1.9805		1.7737	2.1125	
7	2.452	2.4897	2.452		2.2405	2.5393	
8	2.3899	2.4897	2.4646		2.4646	2.5019	
9	1.9022	2.0485	1.885		1.9387	2.0119	
10	1.6289	1.7718	1.6118		1.7528		
11	1.5364		1.4022		1.7909		
12	1.3717		1.2894		1.4723		
13			1.0974		1.4175		
14			1.166		1.2689		
15			1.153		1.262		
16		1.1401	1.2689		1.2483		
17		1.286	1.2689			1.3032	
18		1.4243	1.5432			1.5257	
19	2.0416				1.9185		
20	1.9185				1.9204		
21	1.7193	1.701			1.7193		
22	1.5203	1.4784		1.4632	1.5154		1.6263
23	1.267	1.1458		1.2803	1.2071		1.3957
24	1.0349	1.086	1.0456	1.1088	1.1088	1.1088	
Max	2.452	2.4897	2.4646	1.4632	2.4646	2.5393	1.6263
Min	.8779	.905	.8779	1.1088	.9145	.9145	1.3957
Avg	1.5425	1.4813	1.3948	1.2841	1.5071	1.5257	1.511



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 206 / 11 kV PIPELINE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.4045	1.4563		1.4937	1.531	
2	1.3817	1.3676	1.4045		1.419	1.4937	
3	1.2936	1.3306	1.3676		1.3306	1.4563	
4	1.3817	1.2689	1.4563		1.4937	1.5466	
5	1.5844	1.5089	1.6598		1.643	1.6598	
6	2.4143	2.4143	2.4143		2.1879	2.452	
7	3.0556	2.9424	3.0933		2.6886	3.1687	
8	3.2861	3.2114	3.2861		3.1367	3.2861	
9	2.6612	2.6886	2.7351		3.062	2.809	
10	2.2177	2.1948	2.268		2.6612		2.268
11	1.8823	1.9547	1.9547		2.4143		
12	1.7193		1.7909		2.0698		
13			1.6301		1.829		
14			1.5927		1.7558		
15			1.6095		1.7741		
16		1.4883	1.5927		1.6827		
17		1.6651	1.6108				
18		1.8267	1.8823				
19	2.7351	2.7435			2.7069		
20	2.6612				2.809		
21	2.5873	2.9569			2.6612		
22	2.3655	2.5133		2.3899	2.4025		2.5133
23	1.922	2.0165		2.0165	2.0165		2.1658
24	1.5684	1.5684	1.643	1.643	1.643	1.7177	
Max	3.2861	3.2114	3.2861	2.3899	3.1367	3.2861	2.5133
Min	1.2936	1.2689	1.3676	1.643	1.3306	1.4563	2.1658
Avg	2.1208	2.0561	1.9183	2.0165	2.1310	2.1121	2.3157

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 207 / 11 KV Om Sai

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9974	2.1297	2.0813	1.0151	1.6583	2.1041	1.1385
2	2.0568	2.1925	2.0291	1.0136	1.5882	2.0157	1.1126
3	2.0286	2.1152	2.0454	1.0303	1.7688	2.0805	1.0943
4	2.035	2.0866	1.9982	1.0174	1.6408	1.9509	1.1736
5	2.1109	2.2215	2.0104	1.057	1.6949	1.8549	1.214
6	2.2222	2.4235	2.0157	1.0898	1.8458	1.8755	1.1568
7	2.0702	2.0851	1.8808	1.0273	2.0443	1.8473	1.1294
8	2.2588	2.1811	2.0302	1.0067	2.4776	2.0256	1.2003
9	2.9637	2.8696	2.6879	.9938	3.1131	2.8875	1.3466
10	3.1025	3.3532	3.4515	.9275	3.4575	1.6004	1.6057
11	3.1741	1.8549	3.4972		3.5742	1.669	1.7551
12	1.6118	3.3059	3.213		3.5284	1.5082	1.6972
13	1.5181	3.3235	2.9142		3.1596	1.2628	1.5165
14	1.7162	3.4363	3.3608		3.0621	1.4502	1.6979
15	1.7208	1.8099	3.0491		3.0415	1.3314	1.6278
16	3.2891	3.331	3.2686	.6348	3.075	1.3702	1.5874
17	3.0354	3.2476	3.1345	.8985	1.531	1.3603	1.5821
18	1.4746	2.7877	2.8416	.8672	1.4891	1.4967	1.4441
19	2.7503	2.7214	1.5082	.8901	2.758	1.4335	1.4662
20	2.3959	2.2809	1.1317	.8779	2.1682	1.3199	1.291
21	2.111	2.0614	1.0837	.8634	2.1155	1.1599	1.1164
22	2.1018	2.1872	1.089	1.3992	2.1232	1.3054	2.4029
23	1.9707	2.1064	1.1012	1.4952	2.207	1.3565	2.4379
24	1.9342	2.0073	2.0455	1.9151	1.9571	2.3175	1.3214
Max	3.2891	3.4363	3.4972	1.9151	3.5742	2.8875	2.4379
Min	1.4746	1.8099	1.0837	.6348	1.4891	1.1599	1.0943
Avg	2.2354	2.5050	2.3112	1.0537	2.3783	1.6910	1.4632

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 208 / 11 kv 'M' Block  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3517	.3111	.3109		.1551	.2789	
2	.3334	.3155	.2936		.148	.2858	
3	.3155	.2808	.2926		.1635	.2789	
4	.2926	.2724	.2629		.176	.2743	
5	.2743	.2683	.2698		.197	.2698	
6	.3517	.3071	.3064		.2012	.3022	
7	.3734	.2926	.3368		.2138	.2698	
8	.4161	.4321	.4062		.3243	.3567	
9	.6413	.6036	.6859		.6036	.6413	
10	.8299	.6413	.7167		.6722		
11		.7922	.7167		.7545		
12		.7545	.7011		.7545		
13		.6722	.7545		.6722		
14		.6348	.7545		.679		
15			.7545		.7468		
16		.7545	.7922				
17		.6859	.8002				
18		.7356	.6979				
19	.5487	.6979			.6653		
20	.4111	.4557			.3749		
21	.3963	.4752			.4161		
22	.4062	.4801		.2096	.3612		.4481
23	.4012	.4748		.2096	.3616		.4111
24	.4111	.3384	.3246	.3567	.1593	.2972	
Max	.8299	.7922	.8002	.3567	.7545	.6413	.4481
Min	.2743	.2683	.2629	.2096	.148	.2698	.4111
Avg	.4222	.5077	.5357	.2586	.4191	.3255	.4296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014152 / 33/11 Kv G Block

Feeder No / Name : 201 / Chaitnya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.057	1.2631		
2	1.0433	1.0145	1.1736		
3	1.0715	1.0136	1.1145		
4	1.1004	.9869	1.1279		
5	1.1888	1.0848	1.1149		
6	1.2193	1.1888	1.1888		
7	1.3279	1.3927	1.2803		
8	1.1888	1.3283	1.3117	.8002	1.1296
9		1.6975	1.7918	.7922	1.9044
10			2.2634	.9976	2.0748
11			2.3011	1.0562	2.2257
12			2.0748	.7306	1.9993
13					1.9239
14					2.1691
15		2.1502			2.1502
16	2.2032	1.9805		.6935	2.1502
17	1.7924	2.0748		.7202	1.9418
18	1.8671	1.8111		.7468	1.8298
19	1.6118	1.6124		.7133	1.7177
20	1.5074	1.4582		.8991	1.5775
21	1.1584	1.3435			
22	1.2193	1.3123			
23	1.2967	1.3441			
24	1.1296	1.1145	1.2498		
Max	2.2032	2.1502	2.3011	1.0562	2.2257
Min	1.0433	.9869	1.1145	.6935	1.1296
Avg	1.3536	1.4192	1.4812	.8150	1.9072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014152 / 33/11 Kv G Block

Feeder No / Name : 202 / Suraj

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.4024	.4024		
2	.5487	.3856	.3681		
3	.5121	.3772	.3429		
4	.5228	.3437	.3429		
5	.562	.3344	.3768		
6	.6276	.4096	.4382		
7	.7438	.5014	.562		
8	.6602	.5556	.4544	.4572	.3772
9		.8149	.7468	.3368	.884
10		.9389	.7701	.333	.9282
11		1.0029	1.0395	.2317	.9503
12		.9602	.7625	.1467	.9175
13		.9282			.9175
14		1.0387			.8413
15		.9465			1.0242
16	1.0867	.7926		.1905	1.1462
17	.9259	.8065		.1905	1.0288
18	.9175	.8697		.1486	.9724
19	.6661	.5658		.2378	.9282
20	.631	.6068		.2058	.4481
21	.5868	.567			
22	.5407	.5304			
23	.4401	.503			
24	.6097	.4201	.4191		
Max	1.0867	1.0387	1.0395	.4572	1.1462
Min	.4401	.3344	.3429	.1467	.3772
Avg	.6572	.6501	.5404	.2479	.8741

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014152 / 33/11 Kv G Block

Feeder No / Name : 203 / ITI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.631	.7421		
2	.6135	.6173	.7164		
3	.631	.6203	.6805		
4	.6805	.6371	.6661		
5	.6516	.6173	.6836		
6	.6878	.6556	.6733		
7	.6838	.7316	.6516		
8	.6697	.924	1.094	.1677	.2667
9		1.094	1.3203	.2441	.4854
10			1.4563	.3155	.6219
11			1.4523	.3418	.7095
12			1.6598	.2848	.7922
13					.8488
14					.9808
15		1.358			1.0185
16	1.3203	1.2826		.2515	1.094
17	1.0185	1.3203		.2515	1.0562
18	1.358	1.3014		.2515	1.0185
19	.9709	.9054		.2096	.9054
20	.8589	.7577		.2096	.695
21	.695	.7682			
22	.7316	.7842			
23	.7468	.8029			
24	.6626	.6024	.7947		
Max	1.358	1.358	1.6598	.3418	1.094
Min	.6135	.6024	.6516	.1677	.2667
Avg	.8015	.8638	.9685	.2528	.8071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014152 / 33/11 Kv G Block

Feeder No / Name : 205 / Link Road

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.3681	.3441		
2	.4001	.3637	.3521		
3	.3953	.3593	.3521		
4	.4111	.3749	.3479		
5	.4218	.4161	.3681		
6	.6081	.5506	.5601		
7	.7373	.7459	.7773		
8	.8192	.7701	.7701	.7449	.7373
9		.7042	.6882	.7209	.6325
10		.2743			.3018
11		.2347			.2614
12		.2507			.2241
13		.2865			.2427
14		.3361			.3018
15		.3395			.3018
16	.3395	.3658		.3734	.3395
17	.3772	.3734		.3734	.3395
18	.3395	.3292		.3772	.3772
19	.4715	.4668		.4527	.4854
20		.4668		.4527	
21	.415	.4481			
22	.3961	.4251			
23	.3734	.3881			
24	.4096	.3681	.3647		
Max	.8192	.7701	.7773	.7449	.7373
Min	.3395	.2347	.3441	.3734	.2241
Avg	.4572	.4169	.4925	.4993	.3788

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 207 / 11 KV WATER SUPPLY  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-FEB-17	16-FEB-17
HR	Load (MW)	Load (MW)
1	1.2498	1.1812
2	1.1964	1.1888
3	1.1736	1.1812
4	1.204	1.2118
5	1.204	1.227
6	1.2194	1.2194
7	1.3336	1.2422
8	1.547	1.3718
9	1.6004	1.448
10	1.6994	1.448
11	1.7146	1.5318
12	1.73	1.486
13	1.6232	1.4328
14	1.6004	1.3642
15	1.6918	1.326
16	1.547	1.3336
17	1.5242	1.387
18	1.486	1.2802
19	1.2802	1.2574
20	1.3488	1.3488
21	1.3336	1.3032
22	1.2118	1.2346
23	1.2574	1.2422
24	1.2118	1.3566
Max	1.73	1.5318
Min	1.1736	1.1812
Avg	1.4162	1.3168



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 406 / 33 kv RAMDAS

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.846	.4344	.3772	.3201	.4115	.4115
2	.7316	.7088	.4001	.3658	.3086	.3772	.3772
3	.823	.7316	.4115	.3887	.2972	.3658	.3887
4	.7316	.663	.3887	.3887	.3315	.3429	.4687
5	.7316	.7544	.3887	.3887	.2972	.3887	.4344
6	.7316	.7544	.3772	.3887	.3086	.4001	.423
7	.7316	.6858	.3315	.4458	.3086	.3887	.3887
8	.663	.6858	.3429	.3315	.3086	.3315	.3201
9	.6858	.663	.3544	.3201	.2972	.3544	.3544
10	.6402	.6172	.3658	.3086	.3201	.3429	.3315
11	.6402	.6402	.4001	.2972	.3086	.3544	.3315
12	.663	.6402	.3544	.3086	.3201	.3429	.3201
13	.6858	.6858	.3658	.3086	.3315	.3429	.3086
14	.663	.663	.3429	.3201	.3429	.3544	.3086
15	.663	.663	.3429	.3201	.3315	.3658	.3201
16	.663	.6858	.3429	.3086	.3429	.3315	.3201
17	.7088	.6858	.3429	.3086	.3201	.3429	.3315
18	.663	.663	.3315	.3086	.3315	.3315	.3086
19	.6858	.6858	.3315	.3086	.3429	.3544	.3887
20	.6858	.823	.3658	.3086	.3772	.3658	.3772
21	.7316	.8002	.3544	.3315	.4115	.3544	.4001
22	.7316	.7316	.3544	.3201	.3429	.3201	.4115
23	.7088	.6858	.3544	.3201	.3429	.3315	.4115
24	.7774	.846	.423	.3201	.4115	.4001	.4001
Max	.823	.846	.4344	.4458	.4115	.4115	.4687
Min	.6402	.6172	.3315	.2972	.2972	.3201	.3086
Avg	.7030	.7087	.3668	.3372	.3315	.3582	.3682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 410 / 33 KV G Block

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.195	3.0727	3.4202			
2	3.0727	2.9887	3.3951			
3	3.1207	2.9995	3.1824			
4	3.0933	2.9264	3.195			
5	3.1402	3.0464	3.1207			
6	3.5048	3.4494	3.5305			
7	4.1152	4.0186	4.1015			
8	4.1015	4.4119	4.4119	3.2167	3.3836	
9		4.8097	5.1492	3.0636	4.6399	
10			4.9228	2.4206	4.4136	
11			5.2058	2.0862	4.5833	
12			4.8663	2.3022	4.257	
13					4.257	
14					4.5268	
15		5.1492			4.7531	
16	5.3189	4.8663		1.749	4.9794	
17	4.5268	4.9794		1.9227	4.5931	4.1872
18	4.8171	4.8171		1.8547	4.425	
19	4.225	4.1701		2.1262	4.3799	
20	3.4179	3.7037		2.2291	3.2076	
21	2.9835	3.5208				
22	3.3699	3.3916				
23	3.3316	3.3608				
24	3.2819	3.1824	3.4311			
Max	5.3189	5.1492	5.2058	3.2167	4.9794	4.1872
Min	2.9835	2.9264	3.1207	1.749	3.2076	4.1872
Avg	3.6833	3.8350	3.9948	2.2971	4.3384	4.1872

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 201 / Punewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394	.4031	.3955	.3986	.3673	1.4731	1.797
2	.3978	.394	.4115	.3978	.3658	1.483	1.7612
3	.41	.4016	.4085	.4123	.3757	1.4716	1.7337
4	.4489	.4504	.4374	.4626	.4191	1.5684	1.7642
5	.5586	.5815	.5388	.5898	.5479	1.7695	2.0393
6	.6592	.6996	.6333	.6744	.7034	2.0873	2.5316
7		.7072			.7217	3.1222	3.5284
8		.612				3.3951	3.7456
9	.4184	.6409	.6531	.6394	.5136	3.3448	3.5383
10	3.6565	3.3463	3.3966	3.2274	3.5406		.5075
11	3.6923	2.7999	3.2632	2.8814	3.3539		.3467
12	3.2975	2.9035	2.9668	2.854	3.0544		.237
13	3.28	2.9028	2.5972	2.8944	2.0911		.2667
14	2.9569	2.7351	2.4912	2.7572	2.4996		.3056
15	2.7366	2.7816	2.4798	2.6901	2.5332		.3071
16	2.9028	2.9988	2.601	2.8563	2.7519		.3094
17	2.9485	3.094	2.3792	2.9035	2.9043	.2027	.3132
18	.1753	.4001		.0854	.1783	.3163	.3117
19	.5906	.5578	.5632	.5098	.5853	.5243	.535
20	.6409	.6158	.6462	.6249	.695	.6432	.6173
21	.5967	.5929	.6059	.5693	.6485	.6203	.5944
22	.583	.5235	.5403	.5213	.6226	.567	.5639
23	.5228	.4534	.4771	.4512	.7506	.7369	.743
24	.4344	.4115	.3909	.3795	1.3763	1.7795	1.8435
Max	3.6923	3.3463	3.3966	3.2274	3.5406	3.3951	3.7456
Min	.1753	.394	.3909	.0854	.1783	.2027	.237
Avg	1.4683	1.3336	1.3751	1.3537	1.3739	1.4768	1.2601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 204 / Wadner AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6386	.6683	.6386	.6478	.6447	.0945	.1113
2	.6668	.7072	.6706	.6447	.6744	.1105	.1166
3	.7057	.7049	.6668	.6539	.7186	.1227	.1265
4	.7301	.7903	.7476	.7209	.7644	.1608	.1555
5	.8055	.9183	.9412	.8307	.881	.1867	.1951
6	1.0844	1.1203	1.23	.9526	1.0585	.2301	.2431
7	1.4647	1.5432	1.7734	1.3877	1.5043	.221	.2462
8	1.5188	1.704	1.765	1.5478	1.5394		.2042
9	1.291	1.5173	1.4144	1.1843	1.0852	.6935	.9831
10		.125				1.2018	1.3588
11		.0663				1.2384	1.3847
12		.003				1.3672	1.4182
13		.0023				.9755	1.3375
14		.0076				1.2872	1.1774
15						1.2803	1.054
16						1.249	1.0235
17						1.102	1.1233
18			.0343	.0793	.1174	.1044	.1135
19	.1799		.1608	.1814	.1943	.1509	.1844
20	.1799		.1638	.1852	.1959	.1478	.1928
21	.173	.1791	.1494	.1539	.1715	.1387	.1722
22	.1638	.1646	.1494	.1417	.1341	.1311	.1646
23	.4412	.4626	.3254	.4588	.1242	.1151	.1509
24	.6066	.6005	.5792	.5906	.0998	.112	.1303
Max	1.5188	1.704	1.7734	1.5478	1.5394	1.3672	1.4182
Min	.1638	.0023	.0343	.0793	.0998	.0945	.1113
Avg	.71	.6269	.7131	.6476	.6192	.5401	.5570

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 205 / Panoli AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.07	1.0288	1.0037	1.0029	1.0357	.3437	.2743
2	1.1172	.9823	1.0387	.9998	1.0532	.3528	.2782
3	1.1195	1.0547	1.1507	1.0128	1.0974	.3567	.3056
4	1.2102	1.2308	1.2269	1.0814	1.1797	.3955	.3391
5	1.4312	1.4114	1.4342	1.3504	1.3504	.5342	.4755
6	1.8275	1.7154	1.8496	1.8572	1.7924	.6661	.6394
7	2.2062	2.0264	2.2039	2.2474	2.1895	.6539	.6363
8	2.1216	2.0355	2.1757	2.2527	2.0241		.3483
9	1.2376	1.5882	.0023	1.4822	.8756	1.6034	1.3618
10		.2423				1.7505	1.6476
11		.1898				1.6499	1.5943
12		.1387				1.3146	1.5485
13		.1357				1.4952	1.5539
14		.1196				1.4007	1.4662
15		.1379				1.4106	1.5234
16		.1448				1.5402	1.5859
17		.1524				.3346	1.1591
18	.3429	.2804		.2652	.2919	.1395	.2355
19	.506	.4679	.5357	.5098	.5609	.2812	.4847
20	.487	.4694	.5335	.5152	.5685	.4161	.4915
21	.4252	.3887	.4458	.4047	.5121	.4016	.4504
22	.3536	.3269	.3612	.3475	.4283	.3513	.381
23	.9282	.8756	.8619	.6653	.3628	.2964	.3315
24	1.0357	.9892	.9473	1.0143	.3307	.2606	.282
Max	2.2062	2.0355	2.2039	2.2527	2.1895	1.7505	1.6476
Min	.3429	.1196	.0023	.2652	.2919	.1395	.2355
Avg	1.0887	.7555	1.0514	1.0631	.9783	.7804	.8081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 201 / 11 KV NIGHOJ Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3489	1.246	1.4419	1.6103	1.4716	1.4487	.7225
2	.2134	.2065	.2119	.1875	.2119	1.2849	1.4251
3	.2256	.2263	.208	.1867	.2301	1.1706	1.5074
4	.2416	.2469	.2241	.205	.2355	1.1797	1.6095
5	.2545	.2797	.2378	.234	.25	1.2376	1.7856
6	.2766	.282	.2705	.2462	.2728	1.3375	1.9883
7	.0145	.0114			.0091	1.9258	2.5194
8						2.3198	2.6063
9						2.162	2.6642
17	1.0075	.82	.9998	1.249	1.0372	.0526	.0587
18	2.9584	2.742	3.1687	3.2343	2.7458	.1227	.1113
19	2.9774	2.9546	2.9523	3.0879	2.9378	.1882	.1174
20	2.4897	.5053	2.021	2.8395	2.4227	.2355	.2408
21	2.1453	.6661	2.4691	2.6337	2.2535	.2393	.2492
22	1.8077	1.8785	2.3868	2.1795	2.0096	.2248	.2317
23	1.4076	1.829	2.1704	1.8595	1.7284	.2058	.2218
24	1.3565	1.6408	1.8724	1.733	1.5813	.1844	.1898
Max	2.9774	2.9546	3.1687	3.2343	2.9378	2.3198	2.6642
Min	.0145	.0114	.208	.1867	.0091	.0526	.0587
Avg	1.2483	1.0357	1.4739	1.5347	1.2932	.9129	1.0735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 203 / Jawala AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.4648	.2294	.2416	.2233	.2324	.2538
2	1.2208	1.32	.599	.6653	.6638	.2454	.2561
3	1.6262	1.6506	.743	.8368	.8573	.2606	.2637
4	1.835	1.6934	.8474	.98	.9122	.2637	.2683
5	2.1338	2.114	.9313	1.1302	1.1561	.2858	.2843
6	2.5332	2.335	1.0471	1.4396	1.3626	.3254	.3254
7	2.9478	2.8396	1.4761	1.7878	1.5082	.3178	.2355
8	4.0818	4.0772	2.1498	2.2497	2.1186		
9	4.1228	4.0054	2.0218	2.3403	1.8793		
10	2.2604	2.0804	1.1942	1.3832	.8718	1.2254	1.2079
11						1.874	1.6697
12						1.9951	1.5996
13						1.9265	1.6232
14						1.6316	1.5173
15						1.547	1.4777
16						1.4487	1.2849
17						1.6369	.8185
18						.9457	1.0456
19	.3826	.256	.112			.1189	.1151
20	.4862	.5578	.2119	.2431	.2713	.253	.2157
21	.4908	.5456	.2446	.2439	.2728	.2675	.25
22	.4938	.5152	.2423	.2545	.2774	.2804	.2606
23	.5166	.4968	.2462	.253	.2759	.2949	.2797
24	.5152	.4786	.2416	.2484	.2599	.2797	.2576
Max	4.1228	4.0772	2.1498	2.3403	2.1186	1.9951	1.6697
Min	.3826	.256	.112	.2416	.2233	.1189	.1151
Avg	1.6338	1.5894	.7836	.9532	.8607	.8026	.7050

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 207 / Jawala GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9586	1.0912	.5594	.554	.5876	.5632	.5388
2	.9388	1.0944	.5632	.5975	.6051	.5266	.5144
3	.9358	1.2894	.5738	.6203	.615	.6173	.583
4	1.076	1.3474	.5693	.6722	.6622	.6828	.6234
5	1.4968	1.4632	.7872	.7628	.7522	.8124	.7514
6	1.7376	1.704	.9038	.9137	.8352	.9061	.8878
7	1.861	1.7558	.9206	.9076	.8863	.9564	.916
8	1.5028	1.5698	.7804	.7263	.7682	.7682	.7255
9	1.3382	1.3276	.6691	.5434	.6592	.6394	.6775
10	1.0212	1.1218	.5182	.4428	.522		.5845
11	.7576	.9664	.4062	.2126	.3902	.455	.3993
12	.5928	.657	.3841	.269	.2972	.3163	.3285
13	.535	.6066	.253	.2423	.2545	.365	.3048
14	.5182	.7332	.2164	.2515	.2591	.0579	.2583
15	.5442	.5442	.2515	.2576	.2629	.3788	.298
16	.6006	.602	.2774	.2797	.2774	.3818	.2507
17	.6812	.5442	.2385	.3178	.3246	.3528	.3506
18	.8184	.8702	.4275	.3391	.4138	.4222	.3353
19	1.3916	1.3154	.6935	.6996	.7194	.7141	.5959
20	1.4296	1.4144	.8009	.8017	.8528	.7865	.6821
21	1.4936	1.4342	.8185	.7926	.7941	.7743	.7613
22	1.256	1.3504	.7095	.7461	.7232	.7087	.6554
23	1.2072	1.134	.602	.5822	.5838	.6234	.5266
24	1.1508	1.1034	.551	.5251	.586	.5251	.5235
Max	1.861	1.7558	.9206	.9137	.8863	.9564	.916
Min	.5182	.5442	.2164	.2126	.2545	.0579	.2507
Avg	1.0768	1.1267	.5615	.5441	.568	.5798	.5447



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 201 / Takali AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	18-FEB-17
HR	Load (MW)	Load (MW)
24	.8383	.6859
Max	.8383	.6859
Min	.8383	.6859
Avg	.8383	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 202 / Pokari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	17-FEB-17	18-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
10		1.2346	
24	.7468		.0762
Max	.7468	1.2346	.0762
Min	.7468	1.2346	.0762
Avg	.7468	1.2346	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 204 / Karjule(H) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5799						
2	.5708						
3	.5731						
4	.599			.0168			
5	.6333		.0069	.0777		.0777	
6	.7514		.0206	.0274		.0793	
7	.9998						
8	.3841	.9435	.945	.8185	.7971		
9		1.0219	1.0067	.8825	.9099		
10		.9938	2.143	.9602	.9061		
11		.8688	.8909	.8886	.8497		
12		.8954	.8726	.7857			
13		.8711	.8169	.7781			
14		.8352	.8459	.8017		.1905	.333
15		.8535		.7857		.8848	.7506
16				.3094		.9069	.8246
19	.0312					.0023	
20	.0793	.0785		.0419		.9427	.0366
21	.0838	.0815	.0587	.045		.9587	.0823
22	.077	.0648	.08	.0213	.077	.9282	.0815
23		.0145	.0793		.0206	.823	.0815
24	.7926	.0015	.0328	.1646		.2134	.0267
Max	.9998	1.0219	2.143	.9602	.9099	.9587	.8246
Min	.0312	.0015	.0069	.0168	.0206	.0023	.0267
Avg	.4735	.5788	.5999	.4628	.5934	.5461	.2771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 205 / 11 KV TAKALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	17-FEB-17	18-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
10		1.0631	
24	.5316		.4801
Max	.5316	1.0631	.4801
Min	.5316	1.0631	.4801
Avg	.5316	1.0631	.4801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 206 / 11 KV MANDOHAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-FEB-17	17-FEB-17	18-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
10		.1524	
24	.1143		.1143
Max	.1143	.1524	.1143
Min	.1143	.1524	.1143
Avg	.1143	.1524	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 202 / Kadus AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2256	.2462	.2614	.2705	.2431	.0968	.0876
2	.2484	.2622	.2667	.2683	.2576	.1128	.0991
3	.2462	.2652	.282	.2987	.2789	.1135	.1014
4	.2507	.3025	.3262	.3178	.317		
5	.3208	.381	.3932	.4123	.3978		
6	.4664	.5159	.5624	.5693	.5258		
7	.695	.743	.8398	.7849	.8078		
8	.8871	.8939	.964	.8718	.9617		
9	.8558	.8863	.9534	.8825	.9427		
10		.1113					
11		.0846				.519	.4572
12						.9328	.8871
13						.4954	.8101
14							.7735
15							.804
16						.9374	.8368
17						1.0761	.8048
18	.0419	.0297	.0297	.0137	.0701	1.0143	.7773
19	.1395	.1555	.1555	.1448	.1532	.9	.6295
20	.1379	.1585	.1547	.1524	.16	.144	.1585
21	.1212	.1425	.141	.1379	.1509	.1357	.1425
22	.1075	.1128	.1135	.1097	.1204	.1151	.1166
23	.1722	.1616	.1867	.1699	.1052	.1082	.0991
24	.2393	.2393	.25	.2317	.0914	.0892	.0831
Max	.8871	.8939	.964	.8825	.9617	1.0761	.8871
Min	.0419	.0297	.0297	.0137	.0701	.0892	.0831
Avg	.3222	.3162	.3675	.3523	.3490	.4527	.4511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 203 / Ranjangaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2088	.2126	.2286	.2248	.2294	.2149	.2225
2	.2042	.2088	.2301	.2233	.2279	.2195	.2202
3	.2141	.2279	.2324	.2362	.2332	.2248	.2362
4	.2538	.2705	.2614	.2743	.2705	.2751	.2942
5	.3864	.4085	.4062	.4306	.4351	.4207	.4146
6	.6775	.692	.6699	.7171	.6783	.7118	.7148
7	.7842	.8505	.8711	.8124	.772	.9023	.9
8	.8863	.8703	.8566	.8642	.7514	.8505	.8337
9	.7948	.804	.7392	.7385	.6051	.7263	1.3405
10	.6813	.7636	.5921	.6318	.5098	.631	.5525
11	.5617	.5937	.551	.5456	.4344	.4077	.4656
12	.5258	.442	.4169	.5342	.4367	.5045	.4664
13	.4473	.4641	.3849	.5175	.2904	.5114	.4519
14	.423	.5197	.4748	.3833	.615	.4512	.41
15	.4481	.5075	.4016	.4138	.6969	.4153	.4367
16	.41	.4969	.5502	.5037	.2698	.4283	.4351
17	.913	.4656	.5525	.5495	.3071	.471	.4786
18	.4374	.3467	.4664	.3879	.3628	.4809	.4473
19	.5548	.5906	.5876	.6287	.5731	.5822	.6051
20	.5761	.5716	.6074	.6074	.583	.5975	.6081
21	.4763	.4565	.5068	.5152	.4832	.5014	.471
22	.3406	.3399	.3749	.3628	.3368	.3749	.3704
23	.2637	.2522	.2881	.282	.2644	.2797	.2652
24	.2286	.2286	.2408	.2561	.221	.2378	.8695
Max	.913	.8703	.8711	.8642	.772	.9023	1.3405
Min	.2042	.2088	.2286	.2233	.221	.2149	.2202
Avg	.4874	.4827	.4788	.4850	.4411	.4759	.5213

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 204 / Waghunde GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)
9		.6348
14	.3584	
24		.7282
Max	.3584	.7282
Min	.3584	.6348
Avg	.3584	.6815



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 205 / 11 KV WALAVANE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)
9		2.2862
14	1.8107	
Max	1.8107	2.2862
Min	1.8107	2.2862
Avg	1.8107	2.2862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 206 / 11 KV BABURDI AG

Feeder KV- 11 / INCOMING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)
9		2.1948
14	1.8839	
Max	1.8839	2.1948
Min	1.8839	2.1948
Avg	1.8839	2.1948

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 201 / 11 KV BHALWANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3567	.3643	.362	.3559	.2926	.4367	.4313
2	.3643	.3559	.3711	.3643	.2919	.4618	.4854
3	.3765	.362	.378	.3749	.2995	.4725	.4793
4	.3993	.3871	.3925	.3818	.3064	.4725	.5022
5	.4359	.4367	.4146	.4153	.3422	.4755	.5289
6	.6523	.6226	.586	.6158	.5456	.6882	.7453
7	.8299	.7948	.823	.8421	.7217	1.0372	2.1243
8	.7567	.7453	.0983	.0213		1.4091	1.5874
9		.6081	.0122			1.4822	1.6568
10	.6683	.7468	.7164	.7446	.7011	.2995	.4001
11	.5731	.7758	1.0639	.9861	.5807		
12	.8634	.6104	.8802	1.1385	.7103		
13	.9252	.4344	.9534	.7004	.7537		
14	.8215	.5205	.8642	.695	.6333		
15	.7735	.5121	.7834	.6081	.6462	.0015	
16	.724	.538	.7895	.6874	.7369	.2103	.5852
17	.7842	.692	.7895	.7865	.8855	.2202	.3338
18	.7811	.8451	1.1972	.8002	.916	.3102	.5526
19	.7743	.8444	.8451	.8429	.7727	.4412	.426
20	.5929	.7278	.6158	.6203	.6752	.618	.6653
21	.5853	.6363	.5937	.5182	.5601	.5967	.6401
22	.5525	.5655	.5479	.4595	.503	.5144	.5525
23	.4976	.4801	.4641	.4298	.426	.4397	.4633
24	.4169	.3963	.6858	.3338	.4672	.3894	.7278
Max	.9252	.8451	1.1972	1.1385	.916	1.4822	2.1243
Min	.3567	.3559	.0122	.0213	.2919	.0015	.3338
Avg	.6307	.5834	.6345	.5966	.5804	.5488	.7309

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 203 / 11 KV BHANGADEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)
11		.2214
15		.1981
16		.2286
18	.141	.2439
24	.1829	.1524
Max	.1829	.2439
Min	.141	.1524
Avg	.1620	.2089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 204 / 11 KV JAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
7			1.3813
11	1.0669	.7545	
16			.4001
18	1.3336		.5335
24	.6097		.7773
Max	1.3336	.7545	1.3813
Min	.6097	.7545	.4001
Avg	1.0034	.7545	.7731

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 205 / 11 KV INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-FEB-17	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
7			2.7435
11	2.392	.8954	2.6406
12		.9602	
15			2.9492
16			3.155
18	2.5072		2.9835
24	1.89		2.2977
Max	2.5072	.9602	3.155
Min	1.89	.8954	2.2977
Avg	2.2631	.9278	2.7949

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014092 / 33/11 KV SUPA MIDC

Feeder No / Name : 206 / Chairon Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6097	.6097	.6859	.6097	.6097	.724
2	.724	.6097	.6097	.6859	.6097	.6097	.724
3	.724	.6097	.6097	.6859	.5716	.6097	.7621
4	.7621	.6097	.6097	.6859	.5716	.6097	.7621
5	.6859	.6097	.6097	.724	.6097	.6097	.724
6	.724	.6097	.6478	.724	.6097	.6097	.7621
7	.724	.7621	.8383	.6859	.5716	.7621	.9145
8	.724	.6859	.7621	.6859	.5716	.7621	.8383
9	.724	.6859	.5716	.5716	.6097	.7621	.8002
10	.6859	.6478	.5716	.5716	.5716	.6859	.6859
11	.6859	.6097	.5716	.5335	.6097	.6859	.724
12	.6097	.6097	.5716	.3429	.6859	.6859	.724
13	.6097	.5716	.5716	.6478	.6478	.7621	.7621
14	.6478	.5716	.6097	.6478	.6478	.7621	.724
15	.6478	.6478	.6478	.7621	.6478	.8002	.7621
16	.6097	.7621	.6859	.6859	.6478	.9526	.8383
17	.6097	.724	.8383	.724	.6097	.9526	.8764
18	.6097	.6478	.8002	.0381	.6478	.8383	.8002
19	.6097	.6478	.7621	.6097	.6097	.8764	.6859
20	.6478	.6478	.6859	.6097	.6478	.8764	.6859
21	.6859	.6478	.724	.6097	.6478	.8002	.724
22	.6478	.6478	.724	.6097	.6097	.7621	.6859
23	.6097	.6478	.6859	.6097	.6097	.8002	.6859
24	.6097	.6097	.6859	.6097	.6097	.7621	.6859
Max	.7621	.7621	.8383	.7621	.6859	.9526	.9145
Min	.6097	.5716	.5716	.0381	.5716	.6097	.6859
Avg	.6669	.6430	.6669	.6145	.6161	.7478	.7526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014099 / 33/11 KV KANHUR PATHAR

Feeder No / Name : 203 / 11 KV KANHUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1949			
2		.1928			
3		.2303			
4		.3224			
5		.4572			
6		.5975			
7		.5601			
8		.1949			
10			.4298	.362	.4801
11			.2883		.3121
12			.253		.2515
13			.2134		.2353
14			.2267		.2058
15					.1943
16					.2058
17	.2601				
18	.3155				
19	.4572				
20	.4572				
21	.4024				
22	.3658				
23	.2534				
24		.1949			
Max	.4572	.5975	.4298	.362	.4801
Min	.2534	.1928	.2134	.362	.1943
Avg	.3588	.3272	.2822	.362	.2693



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014099 / 33/11 KV KANHUR PATHAR

Feeder No / Name : 205 / Muktidham AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2012			
2		.2012			
3		.2347			
4		.2713			
5		.3601			
6		.4908			
7		.6024			
8		1.2209			
9			1.3272	1.0936	
10			1.2452	1.0486	
11			1.0883		
12			1.0911		
13			1.0837		
14			1.0437		.1017
15					.116
16					1.065
17	.156				
18	.2058				
19	.4207				
20	.4382				
21	.3898				
22	.3544				
23	.2804				
24		.2229			
Max	.4382	1.2209	1.3272	1.0936	1.065
Min	.156	.2012	1.0437	1.0486	.1017
Avg	.3208	.4228	1.1465	1.0711	.4276

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014099 / 33/11 KV KANHUR PATHAR

Feeder No / Name : 207 / 11 Kv Kinhi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.0351			
4		.0354			
6		.0924			
7		.1294			
8		.0914			
10			.0532	.0716	.0678
11			.0503		.0514
12			.0312		.0332
13			.0305		
14			.0305		.0339
15					.032
16				.0343	.0339
17	.0343				
18	.0347				
19	.0724				
20	.1086				
21	.0905				
22	.0543				
23	.0347				
24		.0351			
Max	.1086	.1294	.0532	.0716	.0678
Min	.0343	.0351	.0305	.0343	.032
Avg	.0614	.0698	.0391	.0530	.0420

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014124 / 33/11kv Palaspur

Feeder No / Name : 201 / Nandur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)
9	.5415	.5304
10	.3881	.3801
24	2.2634	2.5857
Max	2.2634	2.5857
Min	.3881	.3801
Avg	1.0643	1.1654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014124 / 33/11kv Palaspur

Feeder No / Name : 202 / Palaspur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)
9	2.304	2.3868
10		2.3758
24	.5601	.6099
Max	2.304	2.3868
Min	.5601	.6099
Avg	1.4321	1.7908

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014124 / 33/11kv Palaspur

Feeder No / Name : 203 / Pokhari GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)
9	.2534	.2481
10	.2035	.1844
24	.1448	.1097
Max	.2534	.2481
Min	.1448	.1097
Avg	.2006	.1807

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014163 / 33/11 KV DHAWALPURI

Feeder No / Name : 202 / 11 KV Sutarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494		.1294		.2429	.2229
2	.1478		.1294		.2591	.2229
3	.1463		.1478		.2949	.2374
4	.1629		.168		.2949	.2401
5	.1791		.168		.3315	.2785
6	.2303		.1829		.3361	.3441
7	.2804		.3326		.5636	.4359
8	.2427		.2987		.7042	.6478
9	.2401	.2801		.2378	.5281	.6081
10	.2204	.1578		.2195	.1389	.1718
11		.1734		.1772	.1677	.16
12		.5535		.7537	.1612	.1619
13		.6401		.7045	.1463	.213
14		.6325		.7701	.1402	.2279
15		.6874		.7865	.1417	.1402
16		.6958		.6718	.0724	.1578
17		.6642		.7537	.0709	.1433
18		.5693		.6882	.1612	.1753
19		.2968		.5121		.3294
20		.2534		.2686	.1734	.3439
21		.2658		.2328	.1595	.3292
22		.2103		.1949	.1433	.3142
23		.1578		.1595	.1417	.2987
24	.1478		.1463		.2267	.1966
Max	.2804	.6958	.3326	.7865	.7042	.6478
Min	.1463	.1578	.1294	.1595	.0709	.1402
Avg	.1952	.4159	.1892	.4754	.2435	.2750

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014163 / 33/11 KV DHAWALPURI

Feeder No / Name : 203 / Kalu Dam

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5203		1.278		.1372	.1526
2	1.5043		1.278		.1372	.1753
3	1.5061		1.3108		.1543	.1928
4	1.5775		1.326		.1753	.2155
5	1.647		1.3923		.2103	.2374
6	1.7147		1.4899		.3155	.3189
7	2.0348		1.7238		.3696	.4108
8	1.9113		1.8945		.3696	.373
9	1.933	1.9113		1.7604	.3856	.3441
10	.2012	.2572		.2804	.2743	.2915
11		.2427		.2804	.2439	.2949
12		.1715		.1928	2.3137	1.9662
13		.1886		.1886	2.3472	2.2436
14		.1886		.2229	2.1628	2.2786
15		.2035		.2254	2.1051	2.1735
16		.1715		.2229	2.2348	2.2786
17		.1886		.2103	2.3371	2.2085
18		.2629		.2401	2.1628	2.1845
19		.298		.3258	2.0287	1.989
20		.3403		.3856	.2561	.4298
21		.2804		.3294	.2401	.4344
22		.2427		.2743	.2103	.4024
23		.2427		.2401	.1753	.3696
24	1.5154		1.2452		.1715	.1417
Max	2.0348	1.9113	1.8945	1.7604	2.3472	2.2786
Min	.2012	.1715	1.2452	.1886	.1372	.1417
Avg	1.5514	.3460	1.4376	.3586	.8966	.9211

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014165 / 33/11 Kv Goregaon

Feeder No / Name : 201 / 11 KV Goregawan GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0526	.0335	.0373	.0373	.0739	.0377	.0566
Max	.0526	.0335	.0373	.0373	.0739	.0377	.0566
Min	.0526	.0335	.0373	.0373	.0739	.0377	.0566
Avg	.0526	.0335	.0373	.0373	.0739	.0377	.0566



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014165 / 33/11 Kv Goregaon

Feeder No / Name : 202 / 11 Kv Goreshwar AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.2454	.2347	.2401	.1886	.2149	1.0364	1.0688
Max	.2454	.2347	.2401	.1886	.2149	1.0364	1.0688
Min	.2454	.2347	.2401	.1886	.2149	1.0364	1.0688
Avg	.2454	.2347	.2401	.1886	.2149	1.0364	1.0688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014165 / 33/11 Kv Goregaon

Feeder No / Name : 203 / 11 Kv Hiwre -Padali SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.3155	.3353	.3391	.4508	.39	.1494	.2033
Max	.3155	.3353	.3391	.4508	.39	.1494	.2033
Min	.3155	.3353	.3391	.4508	.39	.1494	.2033
Avg	.3155	.3353	.3391	.4508	.39	.1494	.2033

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 201 / JAMKHED U-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					1.9231	1.2308
12					1.4415	
16						1.3717
17		1.3306				1.4266
19	1.7556					
20						1.829
21	1.5154					1.4969
24			1.0082	1.0269		
Max	1.7556	1.3306	1.0082	1.0269	1.9231	1.829
Min	1.5154	1.3306	1.0082	1.0269	1.4415	1.2308
Avg	1.6355	1.3306	1.0082	1.0269	1.6823	1.471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 202 / SAKAT AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					.5668	.7537
16						1.4586
17		.503				1.7101
19	.4144					
20						.1524
21						.1524
24			.3932	.8962		
Max	.4144	.503	.3932	.8962	.5668	1.7101
Min	.4144	.503	.3932	.8962	.5668	.1524
Avg	.4144	.503	.3932	.8962	.5668	.8454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 203 / PADALI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12					1.6575	
16						1.6766
17		.0381				1.9243
19	.0381					
20						.0762
21	.0572					.0762
24			.6287	.6668		
Max	.0572	.0381	.6287	.6668	1.6575	1.9243
Min	.0381	.0381	.6287	.6668	1.6575	.0762
Avg	.0477	.0381	.6287	.6668	1.6575	.9383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 204 / RAJURI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					1.704	1.8679
16						.0617
17	2.2801	1.9433				.064
19	1.5043					
20						.0812
21	.1299					.0909
24			.0591	.0591		
Max	2.2801	1.9433	.0591	.0591	1.704	1.8679
Min	.1299	1.9433	.0591	.0591	1.704	.0617
Avg	1.3048	1.9433	.0591	.0591	1.704	.4331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 205 / JAMKHED U - 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					1.1576	
16						.9114
17		.9214				.9568
19	1.1706					
20						1.267
21	1.1283					1.1517
24			.7947	.8131		
Max	1.1706	.9214	.7947	.8131	1.1576	1.267
Min	1.1283	.9214	.7947	.8131	1.1576	.9114
Avg	1.1495	.9214	.7947	.8131	1.1576	1.0717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 206 / SAKAT GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					1.0829	
16						.4572
17		.3881				.4435
19	1.0164					
20						1.0164
21						.5415
24			.2957	.3142		
Max	1.0164	.3881	.2957	.3142	1.0829	1.0164
Min	1.0164	.3881	.2957	.3142	1.0829	.4435
Avg	1.0164	.3881	.2957	.3142	1.0829	.6147



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 207 / RAJURI + PADALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					.6192	.2195
12					.2389	
15						.2073
16					.192	.2557
17	.2229	.1829				.189
18	.2881					
19	.5041					
20						.6192
21	.4184					.4877
24			.2481	.2561		
Max	.5041	.1829	.2481	.2561	.6192	.6192
Min	.2229	.1829	.2481	.2561	.192	.189
Avg	.3584	.1829	.2481	.2561	.3500	.3297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 208 / BHUTWADA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9						1.5424	
16							.0463
17							.0747
20							.2263
21							.1448
24	.0716	.0867	.0655	.0724	.0724		
Max	.0716	.0867	.0655	.0724	.0724	1.5424	.2263
Min	.0716	.0867	.0655	.0724	.0724	1.5424	.0463
Avg	.0716	.0867	.0655	.0724	.0724	1.5424	.1230

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 201 / JAWALA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1448	.1448		.1448	.1448	
2		.1448	.1448		.1429	.1448	
3		.1738	.1448		.1715	.1738	
4		.1738	.1738		.1882	.1738	
5		.2027	.2027		.2027	.1882	
6		.2172	.2317		.2172	.2172	
7		.2172					
8		.2317					
9	.2286			.2172			
10				.1738			
11				.1448	.2286	.2286	
14					.1524		.1524
15				.1448			
16				.1738			.1524
17	.0176	.1448		.1448	.1715		.1882
18	.1738	.1738		.1882	.2027		.1882
19	.0188	.0176		.1858	.2172		.2
20	.2054	.1882		.2			.2143
21	.2201	.2172		.2143			.0229
22		.1882		.1858			.2317
23		.1738					
24	.1524	.0143	.1448	.3382	.1448	.1448	.1524
Max	.2286	.2317	.2317	.3382	.2286	.2286	.2317
Min	.0176	.0143	.1448	.1448	.1429	.1448	.0229
Avg	.1452	.1640	.1696	.1926	.1820	.177	.1669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 203 / JAWALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15			1.0136		
16			.2072		
17	2.1719	1.8576	2.0005	2.6063	
18	2.0995	1.8338	1.8823	2.5339	
19	1.8099	1.7833	1.8823	2.4615	
24			.1219		.695
Max	2.1719	1.8576	2.0005	2.6063	.695
Min	1.8099	1.7833	.1219	2.4615	.695
Avg	2.0271	1.8249	1.1846	2.5339	.695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 204 / HALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6516
2					.643
3					.724
4					.724
5					.8859
6					.1143
7					1.448
15			.0857		
16			1.7861		
17		1.3496	1.7375	1.9547	
18		1.2308	1.448	2.0271	
19	1.3756	1.1431	1.5927	.1929	
20	1.448				
24	.1219				.6081
<b>Max</b>	<b>1.448</b>	<b>1.3496</b>	<b>1.7861</b>	<b>2.0271</b>	<b>1.448</b>
<b>Min</b>	<b>.1219</b>	<b>1.1431</b>	<b>.0857</b>	<b>.1929</b>	<b>.1143</b>
<b>Avg</b>	<b>.9818</b>	<b>1.2412</b>	<b>1.33</b>	<b>1.3916</b>	<b>.7249</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 205 / NANNAJ GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3475	.3475		.3185	.3475	
2		.3475	.3765		.3185	.3475	
3		.362	.3765		.3475	.362	
4		.362	.4633		.3765		
5		.4054	.4633		.4572		
6		.5068	.5502		.5502		
7		.5502					
8		.5068					
9	.5335			.5068			
10				.4287			
11				.4054			
14					.3048		
15				.3572			
16				.3765			
17	.362	.3185		.3572	.4054		.3185
18	.3765	.3668		.4572	.4633		.362
19	.4344	.4054		.4001	.5068		.4001
20	.5068	.4858		.4572			.5068
21	.5213	.5213		.5144			.5213
22		.5135		.4572			
23		.4344					
24	.3048	.3475	.3475		.3185	.362	
Max	.5335	.5502	.5502	.5144	.5502	.362	.5213
Min	.3048	.3185	.3475	.3572	.3048	.3475	.3185
Avg	.4342	.4238	.4178	.4289	.3970	.3548	.4217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 206 / AGHI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.029	.029		.029	.029	
2					.029		
3			.029		.0029	.029	
4		.0434					
5			.0434		.0434	.0434	
6					.0434	.0434	
7		.0434					
8		.0434					
9	.0457			.0286			
10				.0286			
11					.0305		
14					.0305		
16				.0286			
17	.044			.0429	.029		.029
18	.0043	.029			.0043		.0434
19				.0429	.0434		.0434
20		.0434					
21	.044	.044		.0429			
22				.0429			
23		.0429					
24	.0305	.029	.029	.0305	.029	.029	
Max	.0457	.044	.0434	.0429	.0434	.0434	.0434
Min	.0043	.029	.029	.0286	.0029	.029	.029
Avg	.0337	.0386	.0326	.0360	.0286	.0348	.0386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 207 / PARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.724	.5792	.6516
2		.7529	.6081	.695
3		.0743	.6081	.6859
4		.8688	.643	.7529
5		.8977	.7145	.8688
6		1.0136	.8688	.9846
7	1.6671	1.1584	1.2308	
8			1.3032	
9	1.6671			
24	.6668	.724	.5792	.6081
Max	1.6671	1.1584	1.3032	.9846
Min	.6668	.0743	.5792	.6081
Avg	1.3337	.7767	.7928	.7496



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 201 / KHARDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3414	.3475	.3452	.3445	.349	.3483	.3536
2	.3346	.3414	.3475	.3498	.3513	.3513	.3536
3	.3551	.3536	.3567	.3704	.3544	.3612	.3711
4	.3795	.394	.4024	.4062	.3818	.3879	.4115
5	.4793	.4938	.5243	.5091	.5014	.5167	.5182
6	.7369	.7415	.8299	.8749	.6859	.7727	.7872
7	1.0067	.9008	.9214	1.2041	.836	.9145	.9526
8	.9579	.8909	.9008	.9038	.9747	1.696	.9335
9	1.6179	1.5928	1.3291	.7263	.9526	1.48	.9023
10	.7042	.6965	.8162	.6668	.7888	.6714	
11	.2004	.5876	1.1012	.5075	.6508	.586	
12		.8917	.884	.3978	.8475	.7605	
13		.4207	.4458	.346	.4382	.3795	.5609
14		.3742	.397	.1402	.407	.3742	.5037
15	.4534	.3346	.3749	.3391	.3528	.3254	.4191
16	.4656	.3422	.7133	.3132	.6767	.3963	.381
17	.471	.3719	.3795		.2065	.4374	.4801
18	.5213	.4809	.5388	.5929	.6028	.5121	.4931
19	1.3969	.7689	1.2778	1.4594	.7682	.346	.4633
20	.7811	.7834	.7804	.881	.8246	.8954	.868
21	.6432	.6676	.6912	.6653	.7057	.6897	.7087
22	.5578	.5335	.5449	.5563	.5517	.5418	.5777
23	.4565	.4512	.4466	.4504	.455	.455	.4557
24	.3849	.3734	.7446	.7499	.3688	.3955	.3643
Max	1.6179	1.5928	1.3291	1.4594	.9747	1.696	.9526
Min	.2004	.3346	.3452	.1402	.2065	.3254	.3536
Avg	.6307	.5889	.6706	.5980	.5847	.6081	.5647

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 202 / SATEFAL GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.1867		
9	.6219	.6584	.5853			.4755
12	.2926	.2743	.2561		.1829	.2012
16			.1829		.1646	
19	.4207		.2947	.3856		
24				.1867		
Max	.6219	.6584	.5853	.3856	.1829	.4755
Min	.2926	.2743	.1829	.1867	.1646	.2012
Avg	.4451	.4664	.3298	.253	.1738	.3384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 204 / SONEGON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9						2.0388
12	2.8841	3.0664	.2374		2.4863	
16			1.9559		2.42	
19			1.4074	1.929		
24				.3734		
Max	2.8841	3.0664	1.9559	1.929	2.4863	2.0388
Min	2.8841	3.0664	.2374	.3734	2.42	2.0388
Avg	2.8841	3.0664	1.2002	1.1512	2.4532	2.0388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 205 / TELANGSHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.1867	
9	2.6189	2.536	2.2775		
12					2.769
24				.3734	
Max	2.6189	2.536	2.2775	.3734	2.769
Min	2.6189	2.536	2.2775	.1867	2.769
Avg	2.6189	2.536	2.2775	.2801	2.769

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 206 / SATEFAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9						1.989
12	2.3205	2.1548	2.1548		2.4863	
16			1.8233		2.4863	
19			1.4746	1.5432		
24				.3734		
Max	2.3205	2.1548	2.1548	1.5432	2.4863	1.989
Min	2.3205	2.1548	1.4746	.3734	2.4863	1.989
Avg	2.3205	2.1548	1.8176	.9583	2.4863	1.989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 207 / JATEGON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.3734	
9	1.6907	1.2929	1.6741		
12					1.3245
24				.3734	
Max	1.6907	1.2929	1.6741	.3734	1.3245
Min	1.6907	1.2929	1.6741	.3734	1.3245
Avg	1.6907	1.2929	1.6741	.3734	1.3245

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 208 / LONI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9						1.0608
12	2.3205	2.2045	1.9393		2.1879	
16			1.6078		1.9559	
19			1.0688	1.5546		
24				.3734		
Max	2.3205	2.2045	1.9393	1.5546	2.1879	1.0608
Min	2.3205	2.2045	1.0688	.3734	1.9559	1.0608
Avg	2.3205	2.2045	1.5386	.964	2.0719	1.0608

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 209 / ANANDWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.0974	1.2986	1.1157			.7316
11			.7499			
12	.5304	.6219	.6036		.5853	.5544
16			.6219		.5487	
24				.2801		
Max	1.0974	1.2986	1.1157	.2801	.5853	.7316
Min	.5304	.6219	.6036	.2801	.5487	.5544
Avg	.8139	.9603	.7728	.2801	.567	.643



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 201 / PATODA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6406	2.0576	2.4863	2.7149	2.7149	.2353	.2172
Max	2.6406	2.0576	2.4863	2.7149	2.7149	.2353	.2172
Min	2.6406	2.0576	2.4863	2.7149	2.7149	.2353	.2172
Avg	2.6406	2.0576	2.4863	2.7149	2.7149	.2353	.2172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 202 / ARANGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2353	.2353	.2229	2.4863	2.1719
24	.2353					
Max	.2353	.2353	.2353	.2229	2.4863	2.1719
Min	.2353	.2353	.2353	.2229	2.4863	2.1719
Avg	.2353	.2353	.2353	.2229	2.4863	2.1719

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 203 / ARANGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1724	.181	.181	.181	.181
Max	.181	.1724	.181	.181	.181	.181
Min	.181	.1724	.181	.181	.181	.181
Avg	.181	.1724	.181	.181	.181	.181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 205 / PIMPARKHED AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2759	.3258	.3429	1.9004	1.7194
Max	.2896	.2759	.3258	.3429	1.9004	1.7194
Min	.2896	.2759	.3258	.3429	1.9004	1.7194
Avg	.2896	.2759	.3258	.3429	1.9004	1.7194

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014120 / 33/11 KV RAJURI

Feeder No / Name : 201 / RAJURI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1865	.1389	.1696	.1214	.1448	.1753	.1227
2	.2035	.1389	.1696	.124	.1357	.1753	.1267
3	.2374	.144	.1696	.1463	.208	.1772	.2172
4	.2374	.16	.1457	.1848	.2835	.1595	.3292
5	.2572	.1898	.1457	.2614	.3258	.1595	.3841
8		.2987					
9	.3841	.3292	.3506	.3658	.3155	.2804	.3258
10	.2743	.2427	.2896	.2774	.2947	.2804	.2743
11	.1658	.1928	.181	.1989	.2035	.1311	.1492
12	.1134	.1214	.1326	.1341	.1865	.1006	.1341
13	.1389	.12		.0995	.1696	.112	.128
14	.1296	.1227		.1296	.1494	.0905	.0995
15	.1134	.1017	.0972	.1094	.1214	.0857	.0995
16	.1357	.1457	.0983	.0995	.144	.1086	.1006
17	.1402	.1612	.1311	.1296	.144	.1029	.1753
18	.2058	.1772	.2058	.1907	.1372	.1715	.1753
19	.3761	.3582	.3761	.3761	.2033	.3439	.2926
20	.298	.3155	.3761	.3761	.2534	.4075	.3012
21	.218	.2401	.2572	.2427	.2601	.2402	.2926
22	.1989	.2105	.1989	.1802	.2103	.1823	.2058
23	.1823	.1696	.156	.1658	.1886	.1715	.1734
24	.1715	.1524	.1696	.181	.181	.1928	.1389
Max	.3841	.3582	.3761	.3761	.3258	.4075	.3841
Min	.1134	.1017	.0972	.0995	.1214	.0857	.0995
Avg	.208	.1923	.2011	.1950	.2029	.1833	.2022

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014120 / 33/11 KV RAJURI

Feeder No / Name : 202 / RAJURI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.1334	.1143	.0953	.3048	.2778
2	.1143	.1334	.1334	.1334	.0953	.3506	.3858
3	.1143	.1334	.1334	.1334	.1143	.3658	.4049
4					.1143	.3963	.6335
5						.4321	.6097
6						.4858	.7287
7						1.1012	1.2955
8						1.3916	1.6956
9			.3506			1.2191	1.3279
12		1.0802	.945	.8078	1.0848		
13		1.5424	1.0686	.9808	1.1145		
14	1.1431	1.2193		.9031	1.0269	.1524	
15		1.1431	1.1279	.888	1.0648		
16	1.3426		1.0517	.8688	1.034		
17	1.3279		.9568	1.0536	1.0517		
18	1.174	1.3889	.7074	.945	.8688		
19	.9682	.9412	.7074	.7579	.8078	.1524	.1524
20	.2096	.2096	.2096	.2096	.1715	.2096	.1715
21	.1715	.1905	.1905	.1524	.1715	.1524	.1715
22	.1334	.1524	.1524	.1524	.1334	.1524	.1334
23	.1334	.1334	.1143	.0953	.1334	.1334	.1143
24	.1143	.1334	.1524	.0953	.0953	.2778	.3506
Max	1.3426	1.5424	1.1279	1.0536	1.1145	1.3916	1.6956
Min	.1143	.1334	.1143	.0953	.0953	.1334	.1143
Avg	.5431	.6096	.5084	.5182	.5399	.4549	.5635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014120 / 33/11 KV RAJURI

Feeder No / Name : 203 / GHODEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4218	.4572	.5201	.6093	.6097	.1097	.1086
2	.4843	.5573	.5796	.639	.6097	.1097	.1097
3	.5937	.6805	.6748	.639	.7186	.1097	.1267
4	.6722	.8322	.8025	.6773	.6401		
5	.8002	1.0364	1.0822	.7468	.759		
6	.8802	1.3094	1.1279	.9568	.884		
7	1.2029	1.3923	1.5023	1.3763	1.3603		
8	1.4723	1.5684	1.6604		1.4899		
9	1.3735	1.2803	1.4373	1.1873	1.2498		
12						1.5655	1.6164
13						1.1431	1.5339
14						1.1431	1.5203
15						1.2193	1.5655
16						1.2651	1.5181
17						1.5242	1.4632
18						1.3717	1.4685
19	.1848	.1494	.1663	.168	.1307	1.2955	1.2654
20	.2054	.1848	.1463	.168	.1494	.1478	.1646
21	.1646	.1463	.1086	.128	.1478	.1463	.1463
22	.1294	.1086	.1052	.1063	.1294	.1448	.1463
23	.1109	.1017	.0914	.0905	.1109	.1448	.1267
24	.4001	.4365	.4475	.5944	.5944	.1109	.12
Max	1.4723	1.5684	1.6604	1.3763	1.4899	1.5655	1.6164
Min	.1109	.1017	.0914	.0905	.1109	.1097	.1086
Avg	.6064	.6828	.6968	.5776	.6389	.7220	.8125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 201 / KARJAT URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5487	.5373	.6935	.543	.7316	.7468
Max	.5487	.5373	.6935	.543	.7316	.7468
Min	.5487	.5373	.6935	.543	.7316	.7468
Avg	.5487	.5373	.6935	.543	.7316	.7468



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 202 / BABULGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.362	.2984	.3222	.3292	.3189	.3544
Max	.362	.2984	.3222	.3292	.3189	.3544
Min	.362	.2984	.3222	.3292	.3189	.3544
Avg	.362	.2984	.3222	.3292	.3189	.3544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 203 / DURAGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.8478	.8002	.8288	.8288	.9145	2.2043
Max	.8478	.8002	.8288	.8288	.9145	2.2043
Min	.8478	.8002	.8288	.8288	.9145	2.2043
Avg	.8478	.8002	.8288	.8288	.9145	2.2043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 204 / NANADGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4525	.3437	.3361	.4382	.4382	.4938
Max	.4525	.3437	.3361	.4382	.4382	.4938
Min	.4525	.3437	.3361	.4382	.4382	.4938
Avg	.4525	.3437	.3361	.4382	.4382	.4938

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 207 / MAHIJALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1017	.0753	.0772	.1006	.1187	.4801
Max	.1017	.0753	.0772	.1006	.1187	.4801
Min	.1017	.0753	.0772	.1006	.1187	.4801
Avg	.1017	.0753	.0772	.1006	.1187	.4801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 208 / CHAPADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4843	.6325	.6958	.6562	.6249	.2343
Max	.4843	.6325	.6958	.6562	.6249	.2343
Min	.4843	.6325	.6958	.6562	.6249	.2343
Avg	.4843	.6325	.6958	.6562	.6249	.2343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 209 / KOREGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1372	.1562	.144	.1696	.1715	.4458
Max	.1372	.1562	.144	.1696	.1715	.4458
Min	.1372	.1562	.144	.1696	.1715	.4458
Avg	.1372	.1562	.144	.1696	.1715	.4458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 210 / NANDGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.5432	1.2003	.9339	1.2717	1.2003	.503
Max	1.5432	1.2003	.9339	1.2717	1.2003	.503
Min	1.5432	1.2003	.9339	1.2717	1.2003	.503
Avg	1.5432	1.2003	.9339	1.2717	1.2003	.503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 212 / BABHULGAON PURE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1646	.1619	.2721	.181	.1402	.4938
Max	.1646	.1619	.2721	.181	.1402	.4938
Min	.1646	.1619	.2721	.181	.1402	.4938
Avg	.1646	.1619	.2721	.181	.1402	.4938



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 201 / Mirjagaon GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9795	1.0924	.9694	.9593	1.0317	1.0974	
7			1.2127	1.2715		1.3969	
8		1.3466			1.2894	1.3998	
9		1.1104	1.3073	1.3432		1.0208	1.3466
10		.9134		1.1765		.9313	1.0498
11		.7421		.8326		.8596	
12		.6556	.8059	.7865		.8328	.8688
13		.6697	.7442	.7023		.7783	
14		.6089	.591	.7207			
15		.7421	.6268				
16			.6984				
17	.9134	.7947	.7783		.9145		
18		.8131	.9671	1.1104	.9877		
19	1.1765	1.0498	1.1946	1.2127	1.1458		
20		.9231	1.1584		1.0425		
21	.8869	.7762	.7522	.8238	.8316		
22		.6838	.7522		.6468		
23	.6335	.5544	.5853	.5973	.6468		
24				.543	1.1458		
Max	1.1765	1.3466	1.3073	1.3432	1.2894	1.3998	1.3466
Min	.6335	.5544	.5853	.543	.6468	.7783	.8688
Avg	.9180	.8423	.8763	.9292	.9683	1.0396	1.0884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 202 / BELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9526	.7621	.9526	.9526	.9526	1.6956	
7			.9526	.9526		2.2939	
8		.9526			.7621	2.5606	
9		.7621	.5716			1.7147	2.2672
10		.5716		.5716		.381	
11		.381		.2858		.1905	.2858
12		2.0576	2.0348	2.1052		.1905	.1905
13		2.4006	2.2043	2.2672			
14		2.4006	2.2043	2.2672			
15		2.4006	2.0348				
16			2.2043				
17	2.5434	2.2672	2.0576		2.4006		
18		2.2672	1.7147	2.5434	2.5606		
19	2.2291	1.989	1.5432	2.2043	1.989		
20		.7621	.7621		.7621		
21	.7621	.5716	.7621	.5716	.5716		
22		.5716	.5716		.5716		
23	.5716	.381	.5716	.5716	.381		
24				.381			
Max	2.5434	2.4006	2.2043	2.5434	2.5606	2.5606	2.2672
Min	.5716	.381	.5716	.2858	.381	.1905	.1905
Avg	1.4118	1.3437	1.4095	1.3062	1.2168	1.2895	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 203 / OLD KOMBHLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.6859	.6668	.6859	.6287	.6478	.9465	
7			.7049	.6859		1.4918	
8		.6478			.6287	1.6766	
9		.5525	.4954			1.1317	1.6766
10		.4001		.381		.1905	
11		.2477		.1905		.1905	
12		1.5775	1.3565	1.4043		.1905	
13		1.5089		1.5261			
14		1.4403	1.2548	1.4918			
15		1.5432	1.2378				
16			1.3565				
17	1.5939	1.3226	1.4575	1.3904	1.406		
18			1.3375	1.2209	1.335		
19	1.4403	.7712	1.2346	1.3226	1.2517		
20		.5906	.4191		.5716		
21	.5716	.5335	.5144	.5335	.5716		
22		.4763	.4191		.4382		
23	.4191	.4001	.3239	.362	.362		
24				.2858	1.2378		
Max	1.5939	1.5775	1.4575	1.5261	1.406	1.6766	1.6766
Min	.4191	.2477	.3239	.1905	.362	.1905	1.6766
Avg	.9422	.8453	.9141	.8787	.8450	.8312	1.6766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 204 / OLD Malthan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.7901	1.5089	1.6095	1.6461	1.6289	.8192	
7			2.3685	2.4177		.8573	
8		2.3908			2.7664		
9		2.3663	2.4587	2.3758			
10		.3239		.381		.4191	
11				.2667		.3239	
12		.2286	.2667	.2096		2.7435	2.2939
13		.1905		.1905			
14		.1905	.2096	.2096			
15		.2096	.1905				
16			.1715				
17	.3429	.2286	.2096	.1905	.2286		
18		.3048	.4382	.2667			
19	.743	.7049	.724	.7049	.8192		
20		.6859	.6859		.6668		
21	.5525	.5525	.6097	.5716	.6668		
22		.4954	.5335		.4954		
23	.4382	.4191	.4191	.4191	.4572		
24				1.0631	.8192		
Max	1.7901	2.3908	2.4587	2.4177	2.7664	2.7435	2.2939
Min	.3429	.1905	.1715	.1905	.2286	.3239	2.2939
Avg	.7733	.7200	.7782	.7795	.9498	1.0326	2.2939

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 205 / NEW KOMBHALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.7621	.5716	.7621	.7621	.7621	1.4022	
7			.7621	.9526		2.0119	
8		.5716			.5716	2.2939	
9		.381	.381			1.7147	2.0119
10		.381		.381		.381	
11		.1905		.1905		.1905	
12		2.0576	2.0348	2.13		.1905	
13		2.0576	1.6956	2.1548			
14		1.8861	1.8652	2.2672			
15		2.0576	1.8652				
16			1.8652				
17	2.5434	1.8442	2.0576	2.0348	1.989		
18		2.0119	1.8861	1.8652	1.8442		
19	2.0576	.8573	1.7147	1.5261	1.5261		
20		.7621	.7621		.5716		
21	.5716	.5716	.7621	.7621	.5716		
22		.5716	.5716				
23	.381	.5716	.5716	.381	.381		
24				.381	1.5432		
Max	2.5434	2.0576	2.0576	2.2672	1.989	2.2939	2.0119
Min	.381	.1905	.381	.1905	.381	.1905	2.0119
Avg	1.2631	1.0841	1.3038	1.2145	1.0845	1.1692	2.0119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 206 / NEW MALTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.0288	1.0288	1.0402	1.2003	1.2003	.2858	
7			1.5432			.2858	
8		1.6956			2.0348		
9		1.5432	1.5261	1.5432			
10		.1905		.1905		.1905	
11		.1905		.1905		.1905	
12		.1905	.1905	.1905			1.5261
13		.1905	.1905	.1905			
14		.1905	.1905	.1905			
15		.1905	.1905	.1905			
16			.1905				
17	.1905	.1905	.1905	.1905	.1905		
18		.1905	.1905	.1905			
19	.381	.381	.1905	.381	.1905		
20		.381	.381		.2858		
21	.1905	.2858	.381	.1905	.2858		
22		.2858	.1905		.2858		
23	.1905	.1905	.1905	.1905	.1905		
24				.6859	.1905		
Max	1.0288	1.6956	1.5432	1.5432	2.0348	.2858	1.5261
Min	.1905	.1905	.1905	.1905	.1905	.1905	1.5261
Avg	.3963	.4572	.4518	.4082	.5394	.2382	1.5261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 207 / Water supply Mirajgaon  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	17-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)
9		.0381
19	.0754	
Max	.0754	.0381
Min	.0754	.0381
Avg	.0754	.0381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 208 / kalptaru cotton

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.1334	.0191	.0286	.0377	.112	.1334	
7			.1334	.112		.12	
8		.112			.0187	.0191	
9		.1307	.0934	.1143		.0191	.0381
10		.1307		.1334		.1143	.0191
11		.1307		.1143		.1132	.0191
12		.112	.1307	.1143		.1307	.0381
13		.1307	.1494	.1334			
14		.1307	.112	.1143			
15		.1307	.112	.1143			
16			.0934	.0191			
17	.0191	.0133	.1307	.0934	.0191		
18		.0095	.132	.0934	.1143		
19	.0191	.0152		.0934	.1143		.0191
20		.0191	.1132		.0229		
21	.0191	.1143	.1132	.0934	.1143		
22		.0133	.112		.1143		
23	.0191	.0381	.112	.0934	.1143		
24				.1132			
Max	.1334	.1307	.1494	.1334	.1143	.1334	.0381
Min	.0191	.0095	.0286	.0191	.0187	.0191	.0191
Avg	.0420	.0781	.1119	.0992	.0827	.0928	.0267



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 201 / LIFT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1715	.1715	1.9719	1.8861
2				.1715	.1715	1.9719	1.8861
3				.1715	.1715	1.9719	1.8861
4				.1715	.1715	1.9719	1.8861
5				.1715	.1715	1.9719	1.8861
6				.1715	.1715	1.9719	1.8861
7				.1715		2.1434	3.0007
8						2.2291	2.0576
9			.1638			2.2291	2.0481
12			2.0481	2.4006	2.4006		
13			2.0481		3.0007		
14			2.2939		2.3072		
15					2.2832		
16			2.2119		2.2832		
17					2.2939		
18					2.2299		.1656
19	1.8023	1.8023			2.2516	.1652	.1654
20					.1656	.1656	.1656
21					.1638		.1656
22			.1715	.1715	.1715	.1715	.1715
23			.1715	.1715	.1715	.1715	.1715
24				.1715	.1715	1.9719	1.8004
Max	1.8023	1.8023	2.2939	2.4006	3.0007	2.2291	3.0007
Min	1.8023	1.8023	.1638	.1715	.1638	.1652	.1654
Avg	1.8023	1.8023	1.3013	.3741	1.1012	1.5056	1.3268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 202 / BHAMBORA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.7826	5.7888	2.8974	2.905	2.9172	2.8913	2.9035
2	5.7704	5.7918	2.8944	.1631	2.9218	2.8913	2.9127
3	5.7736	5.7918	2.8883	.1661	2.9203	2.9066	2.9218
4	5.7674	5.7948	2.8837	.16	2.9111	2.9172	2.9371
5	5.7582	5.807	2.8837	.0732	2.8974	2.9401	2.9416
6	5.8132	5.9686	2.8883	.0351	2.873	2.902	2.9218
7	5.8894	5.99	2.8974	.349	2.6658	2.7892	2.7328
8	6.0022	5.9016	2.9355	.3262	2.8014	2.9569	2.742
9	5.9442	5.7582	2.8837	.3902	2.87	2.9111	2.9218
10	5.7156	5.7126	2.8563	1.4236	1.6903	2.8608	2.8654
11	5.7248	5.7064	2.8487	2.8761	.1905	.4527	2.8517
12	5.8924	5.7918	2.8624	2.9538	2.4387	3.2023	2.8807
13	5.8406	5.7278	.9465	2.9081	2.905	3.1565	2.8578
14	3.5696	5.7064	3.155	2.9188	2.8807	2.8746	2.838
15	5.9716	5.7216	.5655	2.9081	2.8669	2.8685	.381
16	5.862	3.3226	1.294	2.8471	2.8578	2.8517	2.8639
17	5.8742	5.7064	2.8654	2.9035	2.8532	2.841	2.8822
18	5.7826	5.7186	1.8976	2.873	2.8487	2.8487	2.1125
19	5.74	5.6942	.3551	2.9249	2.6124	2.9035	.7301
20	.4756	1.518	.506	2.8517	.2789	.2317	.7423
21	5.798	2.8258	.5304	2.8487	2.4943	2.8929	.7667
22	5.8376	6.3496	2.6917	1.1218	3.754	2.8852	2.8761
23	5.9382	6.1972	2.902	2.902	2.8746	2.8608	2.8746
24	5.807	5.7492	2.905	2.9203	2.8898	2.8974	2.9157
Max	6.0022	6.3496	3.155	2.9538	3.754	3.2023	2.9416
Min	.4756	1.518	.3551	.0351	.1905	.2317	.381
Avg	5.5138	5.4184	2.3014	1.8646	2.5922	2.6973	2.4739

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 203 / Baradgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1715	.1715	1.286	1.6289
2				.1715	.1715	1.286	1.6289
3				.1715	.1715	1.3717	1.7147
4				.1715	.1715	1.4575	1.8861
5				.1715	.1715	1.5432	2.0576
6				.1715	.1715	1.6289	2.4006
7				.1715		2.4863	3.0007
8					.1715	2.4863	3.0007
9			.1638			2.4863	2.3758
12			2.6216	3.0007	3.0007		
13			2.5396		3.0007		
14			2.6216				
15			2.4577		2.4434		
16			2.3758		2.4463		
17					2.4434		
18					2.2832		
19	2.4577	2.2939			2.1201	.3807	.2855
20					.3799	.3799	.3807
21					.3426		.3807
22			.1715	.1715	.1715	.1715	.1715
23			.1715	.1715	.1715	.1715	.1715
24				.1715	.1715	1.286	1.6289
Max	2.4577	2.2939	2.6216	3.0007	3.0007	2.4863	3.0007
Min	2.4577	2.2939	.1638	.1715	.1715	.1715	.1715
Avg	2.4577	2.2939	1.6404	.4287	1.0619	1.3158	1.5142

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 204 / JALALAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.9719	2.0576	.1715	.1715
2				1.9719	2.0576	.1715	.1715
3				2.0576	2.1434	.1715	.1715
4				2.0576	2.2291	.1715	.1715
5				2.1434	2.4006	.1715	.1715
6				2.2291	2.572	.1715	.1715
7				2.6578	2.572	.1715	.1715
8					2.4863		
9			.1638	2.3148	2.4863		
12						3.2579	3.4408
13						3.658	3.4408
14						3.658	4.0009
15						3.658	3.4008
16			.1638			3.8409	3.4408
17						3.4751	
18							3.4751
19	.1619	.1638			.1829	3.2922	3.2922
20					.1829	.1829	.1829
21					.1829		.1829
22			.1715	.1715	.1715	.1715	.1715
23			.1715	.1715	.1715	.1715	.1715
24				1.9719	2.0576	.1715	.1715
Max	.1619	.1638	.1715	2.6578	2.572	3.8409	4.0009
Min	.1619	.1638	.1638	.1715	.1715	.1715	.1715
Avg	.1619	.1638	.1677	1.7926	1.5969	1.4854	1.3985

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 206 / Berdi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4575	1.5432	.0857	.0857
2				1.5432	1.5432	.0857	.0857
3				1.5432	1.5432	.0857	.0857
4				1.6289	1.6289	.0857	.0857
5				1.6289	1.6289	.0857	.0857
6				1.7147	1.7147	.0857	.0857
7		2.0182		2.1434	1.9719	.0857	.0857
8				1.9719	1.7147		
9			1.8023	1.8861	1.8004		
12						2.572	2.6216
13						2.4463	2.4577
14						2.4463	2.4577
15						2.4463	2.4577
16						2.4463	2.4577
17						2.2248	
18						2.3072	2.3072
19	1.8897				.0828	2.3072	2.1201
20					.1652	.0828	.0828
21					.0828		.0828
22			.0857	.0857	.0857	.0857	.0857
23			.0857	.0857	.0857	.0857	.0857
24				1.4575	1.5432	.0857	.0857
Max	1.8897	2.0182	1.8023	2.1434	1.9719	2.572	2.6216
Min	1.8897	2.0182	.0857	.0857	.0828	.0828	.0828
Avg	1.8897	2.0182	.6579	1.4289	1.1423	1.0598	.9422

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 207 / baradgaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3429	.3429	.3429	.3429
2					.3429	.3429	.3429
3				.3429	.3429	.3429	.3429
4				.3429	.3429	.3429	.3429
5				.3429	.4287	.4287	.4287
6				.5144	.5144	.5144	.5144
7				.5144		.5144	.5144
8							.5144
9			.5316			.5144	.443
10			.3544	.4287	.4287	.3429	.3544
11			.3544	.4287	.4287	.3429	.2658
12			.3544	.3429	.3429	.3429	.2658
13			.3544		.4287	.1829	.2658
14			.2658		.1829	.1829	.2658
15					.1829	.1829	.2658
16			.1772		.1829	.1829	.2658
17					.1829	.1829	
18					.1829	.1829	.1829
19	.4915	.4915			.3658	.5487	.5487
20					.3658	.5487	.5487
21							.5487
22			.5144	.4287	.3658	.5144	.5144
23			.4287	.4287	.3429	.5144	.4287
24				.4287	.4287	.3429	.4287
Max	.4915	.4915	.5316	.5144	.5144	.5487	.5487
Min	.4915	.4915	.1772	.3429	.1829	.1829	.1829
Avg	.4915	.4915	.3706	.4072	.3364	.3609	.3885

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 208 / Sidhatek Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.286	1.286	.0857	.0857
2		1.286	1.286	.0857	.0857
3		1.3717	1.3717	.0857	.0857
4		1.3717	1.3717	.0857	.0857
5		1.5432	1.4575	.0857	.0857
6		1.7147	1.5432	.0857	.0857
7		1.8861	1.9719	.0857	.0857
8		1.3717	1.7147		
9	1.8023	1.3717	1.8004		
12				2.1434	2.0481
13				2.1424	2.0481
14				2.1201	2.0243
15				2.1201	2.2119
16				2.1424	1.9662
17				2.2016	
18					1.8747
19			.0828	2.2016	1.8747
20				.0848	.0828
21					.0816
22	.0857	.0857	.0857	.0857	.0857
23	.0857	.0857	.0857	.0857	.0857
24		1.286	.0826	.0857	.0857
Max	1.8023	1.8861	1.9719	2.2016	2.2119
Min	.0857	.0857	.0826	.0848	.0816
Avg	.6579	1.2217	1.0877	.8896	.7931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 209 / Ganeshwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.9719	1.9719	1.8861	2.2291
2				1.9719	1.9719	1.8861	2.2291
3				2.0576	1.9719	1.8861	2.2291
4				2.0576	2.0576	1.8861	2.3148
5				2.0576	2.0576	1.8861	2.3148
6				2.1434	2.1434	1.8861	2.4006
7				2.4863	2.4863	2.1434	2.6578
8				2.3148	2.2291	2.3148	2.8292
9			.1638	2.1434	2.3148	2.3148	2.3758
14					2.854		
18							.1903
19	.1638	.1677			.1903	.1903	.1903
20					.1905	.1894	.1903
21					.1903		.1905
22			.1715	.1715	.1715	.1715	.1715
23			.1715	.1715	.1715	.1715	.1715
24				1.9719	1.8861	1.8861	2.2291
Max	.1638	.1677	.1715	2.4863	2.854	2.3148	2.8292
Min	.1638	.1677	.1638	.1715	.1715	.1715	.1715
Avg	.1638	.1677	.1689	1.7933	1.5537	1.4785	1.5571



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 211 / Dudhodi Ag

Feeder KV- 11 / INCOMING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1715	.1715	1.9719	1.8861
2				.1715	.1715	1.9719	1.8861
3				.1715	.1715	1.9719	1.8861
4				.1715	.1715	1.9719	1.8861
5				.1715	.1715	1.9719	1.9719
6				.1715	.1715	1.9719	2.0576
7		.1829		.1715		2.4006	2.4006
8						2.4863	2.6578
9			.1638			2.4863	2.0481
12			2.6216	2.572	3.0007		
13		3.119	2.3758		3.0007		
14			2.2939		2.8808		
15			2.2939		2.9733		
16					2.8973		
17					2.7255		
18					2.5006		
19	2.6486	2.9355			2.5034	.1658	.1656
20					.1656	.1671	.1656
21					.1652		.1656
22			.1715	.1715	.1715	.1715	.1715
23			.1715	.1715	.1715	.1715	.1715
24				.1715	2.4777	1.8861	1.8861
Max	2.6486	3.119	2.6216	2.572	3.0007	2.4863	2.6578
Min	2.6486	.1829	.1638	.1715	.1652	.1658	.1656
Avg	2.6486	2.0791	1.4417	.3897	1.4033	1.5548	1.4271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 201 / 11KV WANGDARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
19		2.4996		
20		2.7435		
21		2.5377	2.8121	
22		2.5034		
24	1.89			2.0119
Max	1.89	2.7435	2.8121	2.0119
Min	1.89	2.4996	2.8121	2.0119
Avg	1.89	2.5711	2.8121	2.0119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 202 / 11KV KAUTHA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					1.8519
10			1.9433		
11		1.989	1.989		2.1262
19		.0762			
20		.0762			
21		.1524	.1524		
22		.1524			
24	.0953			.1334	2.1262
Max	.0953	1.989	1.989	.1334	2.1262
Min	.0953	.0762	.1524	.1334	1.8519
Avg	.0953	.4892	1.3616	.1334	2.0348

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 203 / 11KV KASHTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		1.5424			
10		1.4899	1.2651		
11		1.5089	1.3603		
18					1.7147
19		.381			
20		.4001			
21		.4527	.4572		
24	.381			.4382	
Max	.381	1.5424	1.3603	.4382	1.7147
Min	.381	.381	.4572	.4382	1.7147
Avg	.381	.9625	1.0275	.4382	1.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 204 / 11 KV LAHAREPAT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					2.0805
19		.2058			
20		.2401			
21		.2572	.2401		
22		.2401			
24	.1829			.1829	
Max	.1829	.2572	.2401	.1829	2.0805
Min	.1829	.2058	.2401	.1829	2.0805
Avg	.1829	.2358	.2401	.1829	2.0805

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 205 / 11KV WANGDARI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.7392			.8775
10		.7095	.6468		
11		.5975	.5914		
19		.8501			
20		.8029			
21		.7282	.7468		
22		.6348			
24	.5415			.5228	
Max	.5415	.8501	.7468	.5228	.8775
Min	.5415	.5975	.5914	.5228	.8775
Avg	.5415	.7232	.6617	.5228	.8775

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 206 / 11 KV SAIKRUPA IND EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2028	.1048	.0995	.0983	.1067	.1101	.1109
2	.1974	.0998	.0964	.0945	.1063	.1086	.104
3	.1966	.0987	.0968	.0945	.1048	.0975	.1044
4	.2012	.0991	.0983	.0964	.1055	.0968	.1048
5	.2012	.0972	.0998	.0953	.104	.0995	.1116
6	.2096	.1052	.1025	.096	.1063	.1052	.1132
7	.192	.1002	.0922	.0964	.101	.1033	.1014
8	.2034	.0945	.0953	.1044	.1033	.0972	.1059
9	.199	.16	.0892	.0941	.0953	.1886	.0991
10	.2454	.1543	.1014	.1987	.0964	.0907	.1246
11	.3316	.1791	.1296	.2665	.0918	.2155	.1821
12	.3476	.096	.1086	.1212	.0873	.1475	.1128
13	.2866	.0895	.1779	.152	.117	.12	.2016
14	.2636	.1623	.2153	.1795	.181	.1398	.2164
15	.3636	.176	.2122	.1833	.1753	.2115	.1646
16	.4344	.1688	.1619	.1517	.1238	.2115	.1574
17	.4268	.1638	.1204	.1143	.1631	.1844	.1296
18	.3398	.1478	.117	.1216	.1741	.1437	.1162
19	.288	.2524	.1204	.1879	.1859	.1654	.1299
20	.253	.229	.1124	.1753	.1421	.1475	.1299
21	.24	.1995	.1078	.2726	.1276	.1322	.1901
22	.2294	.1995	.1067	.1216	.1273	.1307	.1863
23	.211	.1086	.1307	.1147	.1216	.1254	.136
24	.3105	.101	.1059	.1139	.2283	.1235	.1273
Max	.4344	.2524	.2153	.2726	.2283	.2155	.2164
Min	.192	.0895	.0892	.0941	.0873	.0907	.0991
Avg	.2656	.1411	.1208	.1394	.1282	.1373	.1358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 207 / 11 KV KASHTI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		1.1088			1.1458
10		.961	.961		
11		.8501	.8326		
19		1.1888			
20		1.1643			
21		1.0642	1.1458		
22		1.0829			
24	.8589			.8962	
Max	.8589	1.1888	1.1458	.8962	1.1458
Min	.8589	.8501	.8326	.8962	1.1458
Avg	.8589	1.0600	.9798	.8962	1.1458



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 208 / DHAWALEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
19		1.1317		
20		1.1488		
21		1.0631	1.286	
22		1.0802		
24	.9431			1.0212
Max	.9431	1.1488	1.286	1.0212
Min	.9431	1.0631	1.286	1.0212
Avg	.9431	1.1060	1.286	1.0212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 209 / JANGALEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		1.3146			
10		1.4289	1.467		
11		1.4098	1.4289		
12		1.3908			.0381
19		.1143	.0762		
20		.0953			
21		.0953	.0953		
22		.0953			
24	.0953			.0953	
Max	.0953	1.4289	1.467	.0953	.0381
Min	.0953	.0953	.0762	.0953	.0381
Avg	.0953	.7430	.7669	.0953	.0381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 201 / 11KV ADHALGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
6		1.8435	
7		2.5301	
8		2.7199	
20	.743		.743
21	.743		
22	.8025		
23	.8215		
Max	.8215	2.7199	.743
Min	.743	1.8435	.743
Avg	.7775	2.3645	.743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 204 / 11 KV ADHALGAON GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	16-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.2507	
7		.394	
8		.2629	
13	.1402		
16	.1715		
20	.3982		.4525
21	.394		
22	.3506		
23	.3155		.3086
24	.3155		
Max	.3982	.394	.4525
Min	.1402	.2507	.3086
Avg	.2979	.3025	.3806

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 205 / 11 KV BHAWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.3018	
13	2.4684		
16	2.4996		
20	.4458		.4359
21	.4458		
22	.4359		
23	.4694		
Max	2.4996	.3018	.4359
Min	.4359	.3018	.4359
Avg	1.1275	.3018	.4359

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 206 / 11 KV TAKALI LONAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
6		2.1506	
7		2.4966	
8		2.6092	
20	.6161		
21	.5944		
22	.5575		
23	.5575		1.3672
24			1.4563
Max	.6161	2.6092	1.4563
Min	.5575	2.1506	1.3672
Avg	.5814	2.4188	1.4118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 207 / 11 KV PISORA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.4607	
7		.543	
8		.4525	
13	.1715		
20	.4525		.4525
21	.3582		
22	.3189		
23	.2804		.2804
Max	.4525	.543	.4525
Min	.1715	.4525	.2804
Avg	.3163	.4854	.3665

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 208 / 11 KV KOKANGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
6		1.643	
7		2.0317	
8		2.1628	
20	.2743		.218
21	.2683		
22	.1658		
23	.2486		
Max	.2743	2.1628	.218
Min	.1658	1.643	.218
Avg	.2393	1.9458	.218



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 210 / 11 KV Tandali dumala  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.1638	
13	1.0059		
16	.9145		
20	.2229		.2012
21	.2155		
22	.213		
23	.1989		
Max	1.0059	.1638	.2012
Min	.1989	.1638	.2012
Avg	.4618	.1638	.2012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014122 / 33/11 KV MANDAVGAN

Feeder No / Name : 201 / 11 KV MANDAVGAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2984	.3086	.4372
2		.2984		.4372
3		.3149		.4856
4		.3944		.583
5		.4973		.7701
6		.6024	.7087	.9724
7		.6556	.815	1.3226
8		.591	.7442	1.3599
9			.6274	1.1717
10			.3479	
11		.3567	.3963	
12		1.0212	1.012	
13		.9808	1.0279	.2629
14		.9808	.8688	
15		.9934	1.0311	
16	.9297	.8802	.9374	
17	.9095	1.1633	.9259	
18	1.0416	.724	.9962	
19	1.2018	1.1142	1.0883	.5138
20	.5935	.6661	.6001	
21	.5087	.5197	.463	.5365
22	.3932	.3018	.4024	.4641
23	.3277		.3149	
24	.2949	.3149	.3052	.4161
Max	1.2018	1.1633	1.0883	1.3599
Min	.2949	.2984	.3052	.2629
Avg	.6890	.6509	.6961	.6952

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014122 / 33/11 KV MANDAVGAN

Feeder No / Name : 202 / 11 KV KAMTHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2591		.4641
2		.2591		.4696
3		.2753		.6316
4				.6316
5		.5636		.7449
6		.6539	.6706	1.4419
7		.6706	.7042	2.0719
8		.5256		.7545
9		.4475		1.7223
10		.2643	.4481	.3048
11		.2134	.2559	.1486
12		1.9372	1.9966	.1134
13		1.9907	.2591	
14		2.1091	1.8903	
15		1.9204	1.6821	
16	1.7747	1.8138	2.0083	
17	1.5752	1.9372	1.9608	
18	1.5352	1.278	1.8747	
19	1.6204	1.6004	1.7901	.4973
20	.5407	.5571	.5407	
21	.421	.4049	.5898	.4001
22	.2675	.3163	.3401	
23	.25		.2915	
24	.2561	.2561	.2429	.4161
Max	1.7747	2.1091	2.0083	2.0719
Min	.25	.2134	.2429	.1134
Avg	.9156	.9206	1.0321	.7208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014122 / 33/11 KV MANDAVGAN

Feeder No / Name : 203 / 11 KV KHANDGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6554		.3681
2		.6554	.8796	.3521
3		1.1271		.3521
4		1.4918		.4321
5		1.8945		.5761
6		2.1963	.2238	.7701
7		2.5604	.273	.7362
8		2.73	2.9334	
9		2.1051	.6203	
10		.3479	.3041	
11		.2675	.253	
12		.2658	.2294	
13		.2401	.1524	2.4813
14		.1898	.1265	2.2377
15		.2187	.1875	.2437
16	.2056	.2561	.2241	2.5819
17	.25	.2429	.2241	
18	.2563	.2315	.4534	2.6322
19	.5735	.5898	.6554	
20	.664	.6802	.6802	
21	.5182	.5079	.6173	
22	.4049	.4534	.3441	
23	.3521	.3725	.421	
24	.9488	.5668	.8802	.3841
Max	.9488	2.73	2.9334	2.6322
Min	.2056	.1898	.1265	.2437
Avg	.4637	.8686	.5341	1.0883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 201 / 11 KV Kalas Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048		.3048			.3048
2	.2439	.3201		.3201	.3201		.3429
3		.3048	.3506	.3048			.3048
4	.2743	.3506		.3353	.3048		.3353
5		.381		.381			.3658
6	.4115	.3963	.4268	.4115	.4115		.4115
7	.4268	.442		.442	.4115		
8		.4115		.381	.4656		
9			.3048				
10	.4557		.2439		.333		
11						4.9897	5.2469
12	4.8834		4.4582	3.8066	3.4675	5.1612	5.0069
13						4.904	4.9726
14	4.6982		4.4239				
15				3.8409		4.8868	
16						5.1955	
17	4.1152		4.3038	4.1324			
18	4.0638		3.8752				
19	.381	.3506	.4115	.381			
20	.381	.3963	.4268				
21	.3963	.4115	.381	.3963		.3658	
22	.3658		.3353			.3353	.3506
23	.3353		.3048	.3353		.3048	.3201
24	.2591	.3048	.3048	.3048	.3201		.3048
Max	4.8834	.442	4.4582	4.1324	3.4675	5.1955	5.2469
Min	.2439	.3048	.2439	.3048	.3048	.3048	.3048
Avg	1.4461	.3645	1.4680	1.0719	.7543	3.2679	1.5223

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 202 / 11 KV Akole Urban Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1145		.9774			1.2003
2	1.0498	1.0974		.9431	1.1041		1.0974
3		1.0288	1.1584	.8916			1.1317
4	1.1222	1.2346		1.1317	1.1765		1.2174
5		1.4918		1.4575			1.3203
6	1.9004	1.5432	1.8099	1.7147	1.6832		1.7661
7	2.0995	1.8347		1.9204	1.9547		2.0233
8		1.8861		1.8861	2.0237		1.8519
9		1.9185	1.9728			2.1091	1.7147
10	1.8781		1.8642			1.869	1.5089
11						1.7661	1.3717
12	1.7372	1.4118	1.5927		1.5203	1.6461	1.2517
13						1.6118	
14	1.4327		1.448		1.3394	1.4232	1.286
15		1.3394		1.448		1.4403	
16						1.4575	
17	1.5432		1.3937	1.5203			
18	1.6289		1.4575				
19	1.869	1.7556	1.8176	1.9547			
20	1.8519	1.8099	1.8519				
21	1.6632	1.6289	1.6289	1.6832		1.7147	
22	1.5432		1.3375			1.6289	1.6461
23	1.2346		1.1145	1.3394		1.406	1.286
24	1.086	1.1831	1.267	1.0288	1.1765		1.2174
Max	2.0995	1.9185	1.9728	1.9547	2.0237	2.1091	2.0233
Min	1.0498	1.0288	1.1145	.8916	1.1041	1.406	1.0974
Avg	1.5760	1.4852	1.5510	1.4212	1.4973	1.6430	1.4307

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 203 / 11 KV Tambhol Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524		.1524			.1524
2	1.6118	.1524		.1524	.1677		.1524
3		1.8861	1.6461	1.3717			2.4691
4	1.5432	1.7833		2.0576	1.8004		2.6063
5		1.9204		2.1338			2.6749
6	1.6461	2.1948	2.1434	2.8807	2.6063		3.0864
7	2.4006	3.4294		3.5665	3.4979		
8		4.1838		4.0466	4.2524		
9		3.9781	3.9781	3.9438		3.7723	
10	3.3913		3.6351			4.1152	
11						.1524	
12		.1219	.1524	.1524		.1524	
13						.1524	
14	.1753		.1219		.2103	.1524	
15		.1219				.1524	
16						.1524	
17	.1524		.1524	.1524			
18	.1524		.1524				
19	.2286	.2439	.2286	.2439			
20	.1981	.2286	.2286				
21	.1829	.2134	.2286	.2286		.1829	
22	.1829		.1524			.1829	.1829
23	.1524		.1524	.1981		.1829	.1829
24	1.6461	.1524	.1219	.1524	.1829		.1829
Max	3.3913	4.1838	3.9781	4.0466	4.2524	4.1152	3.0864
Min	.1524	.1219	.1219	.1524	.1677	.1524	.1524
Avg	.9760	1.3842	.9353	1.4289	1.8168	.8501	1.2989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 204 / 11 KV Kumbhefal Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743		.3353			.2286
2	2.572	.2896		.3201	.3963		.2286
3		2.6406	2.6063	2.4006			3.0007
4	2.5377	2.7092		2.8292	2.7435		3.0864
5		2.7778		2.915			3.2579
6	2.6235	2.8464	3.7723	3.0864	3.3436		3.5837
7	3.2579	3.8752		3.155	4.0981		4.4239
8		4.4582		4.6982	4.9078		5.0069
9			5.024	2.4348		4.8525	4.5268
10	4.4086		4.6982			4.9383	4.6296
11						.1829	.2439
12	.2454		.3201			.1372	.2134
13						.2286	.1829
14			.3048			.2286	
15				.2286		.2286	
16						.2591	
17			.2591	.1981			
18	.2743		.442				
19	.503	.4572	.4268	.4115			
20	.4572	.4572	.4572				
21	.3353	.381	.4572	.4268		.3963	
22	.3048		.4115			.3353	.3353
23	.3048		.3963	.2896		.3048	.2743
24	2.6406	.2743	.3048	.381	.3353		.2439
Max	4.4086	4.4582	5.024	4.6982	4.9078	4.9383	5.0069
Min	.2454	.2743	.2591	.1981	.3353	.1372	.1829
Avg	1.5742	1.7868	1.4200	1.6073	2.6374	1.0993	2.0917



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 205 / 11 KV Induri Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524		.1524			.1524
2	.1524	.1524		.1524	.1829		.1524
3		.1524	.1524	.1524			.1524
4	.1524	.1524		.1829	.1981		.1524
5		.1829		.2134			.1524
6	.2439	.2286	.1677	.2286	.2439		.2286
7	.2743	.2286		.2286	.2439		.2286
8		.2286		.2286	.1753		.2286
9			.1524			.1829	.1829
10	.1734		.1524		.2126		.1829
11						4.5953	3.8066
12	4.0695		3.7037	3.3608	4.0466	4.1152	3.9095
13						3.9095	3.8409
14	3.9339		3.4979			3.7037	
15				3.7037		3.5665	
16						3.4979	
17	3.858		3.3608	3.7037			
18	3.7037		3.155				
19	.2286	.2591	.2286	.2591			
20	.1981	.2439	.2286				
21	.1829	.2286	.2286	.2439		.1829	
22	.1524		.1981			.1829	.1829
23	.1524		.1524	.2134		.1829	.1524
24	.1524	.1524	.1372	.1524	.1981		.1524
Max	4.0695	.2591	3.7037	3.7037	4.0466	4.5953	3.9095
Min	.1524	.1524	.1372	.1524	.1753	.1829	.1524
Avg	1.1752	.1969	1.1083	.8784	.6877	2.4120	.8661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 206 / 11 KV Karkhana Express      SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder Feeder KV- 11 / OUTGOING      STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2229		.1543			.1715
2	.1991	.2229		.1543	.181		.1715
3		.2229	.181	.1543			.1715
4	.1991	.2229		.1886	.1991		.1886
5		.2401		.1886			.1886
6	.2172	.2401	.1991	.2058	.2172		.2058
7	.2172	.2058		.2058	.2172		.1886
8		.1715		.1715	.1791		.1715
9			.181	.181		.1715	.2058
10	.1753		.181		.1417	.1886	.2229
11						.2058	.2058
12	.1949		.181	.181	.1063	.1715	.1715
13						.1715	.1715
14	.1949		.181			.2572	.1715
15				.181		.1543	
16						.1715	
17	.1715		.181	.181			
18	.1715		.1372				
19	.1886	.181	.1715	.181			
20	.1886	.181	.1715				
21	.1886	.181	.1715	.1991		.1886	
22	.2058		.1715			.1886	.1715
23	.2058		.1715	.181		.1886	.1715
24	.1991	.2401	.181	.1543	.181		.1886
Max	.2172	.2401	.1991	.2058	.2172	.2572	.2229
Min	.1715	.1715	.1372	.1543	.1063	.1543	.1715
Avg	.1945	.2110	.1758	.1789	.1778	.1871	.1846

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 207 / 11 KV Washere Gfss Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171		.0171			.0171
2	.0181	.0171		.0343	.0181		.0171
3		.0171	.0181	.0171			.0171
4	.0181	.0171		.0171	.0181		.0171
5		.0171		.0171			.0343
6	.0362	.0343	.0362	.0343	.0362		.0343
7	.0543	.0343		.0343	.0362		.0343
8		.0343		.0343	.0351		.0171
9			.0362	.0181		.0171	.0171
10	.0354		.0362		.0354	.0171	.0171
11						.0171	.0171
12	.0177		.0181	.0181	.0177	.0171	.0171
13						.0171	.0171
14	.0179		.0181		.0354	.0171	
15				.0181		.0171	
16						.0171	
17	.0171		.0181	.0181			
18	.0171		.0171				
19	.0343	.0362	.0343	.0362			
20	.0305	.0362	.0305				
21	.0305	.0362	.0343	.0362		.0171	
22	.0171		.0171			.0171	.0171
23	.0171		.0171	.0181		.0171	.0171
24	.0181	.0171	.0181	.0171	.0181		.0171
Max	.0543	.0362	.0362	.0362	.0362	.0171	.0343
Min	.0171	.0171	.0171	.0171	.0177	.0171	.0171
Avg	.0253	.0262	.0250	.0241	.0278	.0171	.0203

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 208 / 11 KV Kumbhefal Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372		.1543			.1543
2	.1629	.1372		.1543	.181		.1543
3		.1372	.1448	.1543			.1543
4	.1991	.2058		.2058	.2534		.2058
5		.2743		.3086			.2401
6	.362	.3258	.2896	.3429	.362		.3086
7	.3801	.4115		.3601	.4344		.3601
8		.3772		.3429	.394		.4115
9		.3258	.2896			.3944	.3086
10			.2715		.3045	.2915	
11						.2572	.1715
12	.2149	.181	.181		.2561	.1715	.1715
13						.1886	.1372
14			.181		.1595	.1886	
15		.1267		.2353		.2058	
16						.1715	
17			.2534	.2172			
18	.2572		.2915				.1991
19	.3601	.3077	.3772	.3982			
20	.3429	.3258	.2915				
21	.2572	.2353	.2743	.2896		.2058	
22	.1715		.1715			.1715	.2229
23	.1715		.1543	.1991		.1715	.1715
24	.1629	.1543	.1267	.1543	.181		.1372
Max	.3801	.4115	.3772	.3982	.4344	.3944	.4115
Min	.1629	.1267	.1267	.1543	.1595	.1715	.1372
Avg	.2535	.2442	.2356	.2512	.2807	.2198	.2193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 209 / 11 KV Washere Ag

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5432		1.3717			1.3375
2	.2439	1.4746		1.286	1.3889		1.286
3		.3506	.381	.3506			.3048
4	.2286	.3658		.381	.3048		.3353
5		.3658		.3963			.3353
6	.3658	.3658	.3353	.4115	.381		.4115
7	.442	.4115		.4268			.442
8		.4115		.4115			.3963
9			.3201				.2591
10	.2601		.2439		.3721		.1981
11						.2134	.1829
12	.1928		.1372	.1524	.3544	.1677	.1524
13						.1677	.1524
14	.1753		.1067			.1372	.1372
15				.1524		.0914	
16						.1219	
17	.1524		.1524	.1372			
18	.1524		.1829				
19	3.2065	3.2922	3.3436	3.4637			
20	2.572	2.6749	3.2922				
21	2.2462	2.1948	2.2119	2.3491		2.7435	
22	1.8861		1.8861			2.0576	2.0748
23	1.7833		1.5432	1.6804		1.7147	1.7147
24	.2439	1.5775	1.5432	1.5432	1.4918		1.3717
Max	3.2065	3.2922	3.3436	3.4637	1.4918	2.7435	2.0748
Min	.1524	.3506	.1067	.1372	.3048	.0914	.1372
Avg	.9434	1.2524	1.1200	.9676	.7155	.8239	.6525

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 210 / 11 KV Tambhol GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686		.0686			.0857
2	.0724	.0686		.0686	.0724		.0857
3		.0686	.0905	.0686			.0857
4	.0905	.1029		.1029	.0724		.12
5		.12		.12			.12
6	.1629	.1372	.1448	.1543	.1379		.1543
7	.1629	.1715		.1543	.181		.1543
8		.1543		.1372	.1629		.1543
9		.1267	.1267			.12	.0686
10	.1075		.0905		.128	.0857	.0343
11						.0686	.0343
12		.0362	.0543		.0543	.0686	.0343
13						.0514	
14	.0362		.0181		.0362	.0686	.0343
15		.0543		.0724		.0514	
16						.0514	
17	.0686		.0543	.0905			
18	.0686		.12				
19	.1543	.1629	.1543	.1629			
20	.1372	.1991					
21	.1372	.1448	.12	.1448		.12	
22	.1029		.0857			.1029	.1372
23	.0857		.0686	.0724		.0857	.0857
24	.0905	.0857	.0724	.0686	.0724		.0857
Max	.1629	.1991	.1543	.1629	.181	.12	.1543
Min	.0362	.0362	.0181	.0686	.0362	.0514	.0343
Avg	.1055	.1134	.0923	.1062	.1019	.0795	.0922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014027 / 33 / 11 KV SAMSHERPUR SUB

STAT

Feeder No / Name : 201 / 11 KV Deothan Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334		.1364	.1334		.1334	.1334
2	.1334		.2294	.1334	.0564	.1334	.1349
3	.1334		.1471	.1334		.1334	.1334
4	.1334		.1349	.1334		.1334	.1334
5	.1715		.1883	.1334	.0793	.1334	.1928
6	.2782	.128	.3277	.2995	.1814	.2934	.3133
7	.3079	.1646	.3292	.3407	.3331	.3437	.3399
8	.1364	.1639	.2309	.0198	.2492	.2782	.1989
9	.1517	.1364		.1334		.1334	.1334
10	2.1689	2.0767	2.0668	2.242	2.2542	2.284	2.8022
11	2.9035	5.599	5.426	6.2673	2.8822	5.163	6.214
12	2.9066	6.2361	5.2797	5.9999	2.7023	5.9061	6.1081
13		5.9381	5.1722	5.7544	2.4249	2.9371	6.5379
14		6.0098	5.391	5.679	3.0468	2.9645	5.2317
15	.6203	5.708	6.0128	1.1858	3.2419	2.8852	5.519
16	6.0525	5.8436	6.0426		5.7407	2.9569	5.6409
17	3.1382	5.8902	2.0195	5.3063	5.573	2.9386	5.6157
18	2.3548	5.0877	2.1369	4.9009	2.6086	2.6231	4.5031
19	.0015	.3795		.2843	.3056	.1631	.3163
20	.0107	.3331	.1768	.3163	.3148	.1707	.3331
21		.3209	.2301	.3224	.3087	.1661	.2934
22		.3216	.1783	.3026	.1761	.1387	.2751
23		.2355	.0274	.2904	.1334		.1334
24	.1334	.003	.1334	.1364	.1334	.1334	.1334
Max	6.0525	6.2361	6.0426	6.2673	5.7407	5.9061	6.5379
Min	.0015	.003	.0274	.0198	.0564	.1334	.1334
Avg	1.1510	2.6619	1.9099	1.7586	1.6373	1.4411	2.1404

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014027 / 33 / 11 KV SAMSHERPUR SUB

STAT

Feeder No / Name : 205 / 11 Kv Deothan GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017		.0554	.0549		.056	.1143
2	.0995		.0554	.0549		.056	.0953
3	.0829		.0554	.0549		.056	.0953
4	.0829		.0905	.1097		.0566	.1143
5	.1509		.1448	.1646		.0943	.1334
6	.1865		.1772	.1991		.1509	.2096
7	.2477		.2353	.2353	.2378	.1715	.2641
8	.2254	.2279	.2303		.2402	.1905	.2427
9	.1562	.1823	.1966	.1355		.1848	.2054
10	.1907	.1372	.1457			.2204	
11		.128	.1353	.1543		.1865	.1646
12		.1341	.1486	.1734		.1715	.1463
13		.1107	.1467	.1097			.1075
14		.0937	.1227	.1097			.1006
15		.1027	.1174				.124
16	.1423	.1235	.1524		.168		.1097
17		.1094		.1417	.1463		.1227
18		.1134		.1214	.1463		.116
19		.1865		.1387	.2075		.2033
20		.1734		.2103	.168		.1867
21		.1543		.1928	.112		.1886
22		.1187		.1612	.0953		.1698
23		.0995		.1063	.0572		.132
24	.1097		.1097	.1075	.0537	.0572	.1143
Max	.2477	.2279	.2353	.2353	.2402	.2204	.2641
Min	.0829	.0937	.0554	.0549	.0537	.056	.0953
Avg	.1480	.1372	.1364	.1368	.1484	.1271	.1505



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014027 / 33 / 11 KV SAMSHERPUR SUB

STAT

Feeder No / Name : 206 / 11 KV samsherpur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0926	.0934	.0937	.0941	.1013	.0975	.0956
2	.0914	.0903	.0918	.0933	.1021	.0964	.0945
3	.0914	.0926	.0914	.0926	.0983	.0971	.0945
4	.0994	.0964	.1021	.1013	.1179	.1219	.1009
5	.1271	.1532	.1463	.1539	.1467	.1784	.1273
6	.1623	.1968	.16	.2014	.163	.1955	.1673
7	.2264	.2233	.2021	.2159	.2275	.2328	.1951
8	.2348	.2283	.2128	.1132	.2264	.2119	.2104
9	.2635	.1848	.2397	.2019	.2374	.21	.2161
10	.2199	.2283	.2082	.0751	.2109	.1909	.2039
11	.1659	.1497	.1663	.1916	.1473	.1661	.1486
12	.1396	.1324	.1336	.1378	.1078	.1147	.1219
13	.1438	.1025	.1347	.0971	.101	.0667	.1212
14	.1377	.1181	.1218	.0926	.1275	.0572	.0891
15	.1247	.1021	.1172	.0438	.107	.0541	.1212
16	.1339	.0949	.1042		.1275	.0739	.1109
17	.1392	.113	.0659	.1543	.1301	.08	.1738
18	.1528	.1588	.16	.1737	.1639	.0998	.162
19	.1974	.2195	.2086	.2351	.2679	.1257	.2137
20	.217	.2025	.2279	.2492	.253	.1257	.2439
21	.1817	.1749	.2203	.2462	.2104	.1185	.1833
22	.1423	.1408	.1722	.1691	.1452	.0834	.1608
23	.1278	.1271	.1444	.1211	.1353	.072	.1143
24	.099	.1141	.0979	.1059	.1017	.1154	.0967
Max	.2635	.2283	.2397	.2492	.2679	.2328	.2439
Min	.0914	.0903	.0659	.0438	.0983	.0541	.0891
Avg	.1547	.1474	.1510	.1461	.1565	.1244	.1486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014027 / 33 / 11 KV SAMSHERPUR SUB

STAT

Feeder No / Name : 207 / 11 Kv Khirvire GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0191	.0191		.0191	.0191
2	.0191		.0191	.0191		.0191	.0191
3	.0191		.0191	.0191		.0191	.0191
4	.0191		.0191	.0191		.0191	.0191
5	.0381		.0381	.0572		.0381	.0191
6	.0572		.0572	.0572		.0572	.0572
7	.0762		.0953	.0762	.0762	.0762	.0762
8	.0572	.0762	.0572		.0572	.0572	.0572
9	.0381	.0381	.0191	.0191		.0381	.0381
10		.0191	.0191			.0191	.0191
11		.0191	.0191			.0191	.0381
12		.0191	.0191			.0191	.0191
13		.0191	.0191				.0191
14		.0191	.0191				.0191
15		.0191	.0191				.0191
16	.0191	.0191	.1143		.0191		.0191
17		.0191		.0381	.0191		.0381
18		.0572		.0381	.0572		.0381
19		.0762		.0953	.0762		.0572
20		.0762		.1143	.0953		.0762
21		.0572		.0953	.0762		.0762
22		.0381		.0572	.0381		.0572
23		.0191		.0381	.0191		.0381
24	.0191		.0191	.0191	.0191	.0191	.0191
Max	.0762	.0762	.1143	.1143	.0953	.0762	.0762
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0347	.0369	.0348	.0489	.0503	.0323	.0365

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 201 / 11 KV Virgaon Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372			.1372	
2		.1372	.1372		.1715	
3	1.3748	1.2452			1.2483	1.1584
4					1.3763	
5					2.0317	
6	1.5546					1.9509
7		2.6216	2.6216			
8	2.7435	3.0361		3.0361		3.3532
9			3.2388			
10				3.0803		
11			.0686			
12			.0655			
17	.0686					.0686
18						.0686
19						.2743
20	.2035					.2743
21						.2804
22						.2035
23						.2058
24	1.4022	1.9662	.1372		.1372	.1372
Max	2.7435	3.0361	3.2388	3.0803	2.0317	3.3532
Min	.0686	.1372	.0655	3.0361	.1372	.0686
Avg	1.2245	1.5239	1.0448	3.0582	.8504	.7250

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 203 / 11 KV Ganore Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8192			.8855	
2		.759	.7461		.8192	
3	.12	.1357			.1543	.1372
4					.2058	
5					.3052	
6	.3086					.2743
7		.3052	.3429			
8	.3086	.3086		.3086	.3429	.2439
9			.2743			
10				.2058		
11			.2058			
12			.0686			
16					.1372	
17	.0686					.1357
19						2.4478
20	2.0348					2.146
21						1.5364
22						1.1069
23						.2241
24	.1029	.3086	.8223		.9503	.9145
Max	2.0348	.8192	.8223	.3086	.9503	2.4478
Min	.0686	.1357	.0686	.2058	.1372	.1357
Avg	.4906	.4394	.41	.2572	.4751	.9167

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 204 / 11 KV Ganore Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	15-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.132			.112	
2		.132	.1307		.1307	
3	.1334	.132			.1494	.1334
4					.1886	
5					.2772	
6	.2401	.2829				.2401
7		.2987	.3018			
8	.2401	.2987		.2452	.2401	.2477
9			.2427			
10				.2054		
11			.128			
12			.132			
16					.0953	
17	.1307					.1886
19						.3018
20	.2829					.2987
21						.2427
22						.2096
23						.1886
24	.1334	.132	.1509		.1307	.12
Max	.2829	.2987	.3018	.2452	.2772	.3018
Min	.1307	.132	.128	.2054	.0953	.12
Avg	.1934	.2012	.1810	.2253	.1655	.2171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 205 / 11 KV Gardani GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.056			.0747	
2		.0554	.0549		.0739	
3	.0953	.0747			.0747	.0686
4					.0934	
5					.0914	
6	.1372	.1494				.12
7		.128	.1494			
8	.1334	.1132		.1494	.0953	.12
9			.1494			
10				.1307		
11			.0747			
12			.0747			
16					.0762	
17	.056					.0747
18						.0732
19						.0747
20	.0934					.112
21						.0924
22						.0914
23						.0924
24	.0762	.0747	.0686		.0747	.0762
Max	.1372	.1494	.1494	.1494	.0953	.12
Min	.056	.0554	.0549	.1307	.0739	.0686
Avg	.0986	.0931	.0953	.1401	.0818	.0905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 206 / 11 KV Tambhol Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1768	.2774	.1311	.1791	.3209	.1707
2	.1707	.1776	.2767	.2518	.1821	.3551	.1707
3	.28	.1509	.2233	.1204	.1562	.3102	.3071
4	.1616	.1669	.1242	.1265	.1646	.3208	.1715
5	.1661	.173	.1212	.1326	.173	.3163	.1791
6	.3483	.1791	.2774	.1463	.1745	.2035	.3506
7	.176	.1867	.2904	.2978	.1936	.1981	.1974
8	.338	.1616	.2519	.1341	.3273	.2747	.3026
9	.1265	.1417	.0998	.2482	.1357	.1059	.1219
10	1.7345	1.627	1.8214	1.6103	1.6293	1.5783	2.05
11	2.5545	2.1475	2.3182	4.1373	2.3373	2.2801	2.7298
12	2.7991	2.2451	2.1254	4.2002	2.2161	2.2268	2.6238
13	2.5895	2.2169	2.018	2.0767	1.7894	2.0569	2.3624
14	2.3762	2.1414	1.9082	1.8823	1.5729	1.9715	2.0904
15	2.2184	2.0172	1.8054	1.7917	1.6034	1.7383	1.9082
16	2.1658	1.9532	1.8793	1.7871	1.9037		1.8458
17	3.7256	1.8092	1.8412	1.8564	2.0523		3.5855
18	1.5173	1.4761	1.6034	1.3352	1.5851	.3498	1.7482
19	.1928	.1669	.1692	.1989	.2096	.1959	.3231
20	.3498	.1722	.1684	.2149	.218	.2164	.3513
21	.2042	.1768	.1677	.2134	.221	.2202	.3513
22	.2004	.1715	.1593	.1943	.2065	.2126	.3308
23	.1882	.1539	.1425	.1837	.1951	.1867	.3018
24	.3178	.1501	.2675	.311	.189	.3041	.3018
Max	3.7256	2.2451	2.3182	4.2002	2.3373	2.2801	3.5855
Min	.1265	.1417	.0998	.1204	.1357	.1059	.1219
Avg	1.0441	.8391	.8474	.9826	.8173	.7247	1.0365

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 208 / 11 kv Hivergaon feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029			.1006	
2		.1017	.1029		.1029	
3	.5487	.5571			.6036	.5182
4					.6706	
5					.9717	
6	.7011					1.0059
7		1.3435	1.6095			
8	1.4022	2.2996		2.146	2.1338	1.89
9			2.0317			
10				1.0486		
11			.1638			
12			.1372			
16					.1372	
17	.1017					.1715
19						.3086
20	.3429					.3086
21						.3086
22						.2401
23						.2401
24	.6706	.8855	.1372		.1029	.1372
Max	1.4022	2.2996	2.0317	2.146	2.1338	1.89
Min	.1017	.1017	.1029	1.0486	.1006	.1372
Avg	.6279	.8817	.6971	1.5973	.6029	.5129



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 209 / 11 kv pimpalgaon Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.852			.852	
2		.8097	.7865		.8192	
4					.1311	
5					.1311	
6	.1886	.1638				.1715
7		.1638	.1638			
8	.1715	.1865		.1638	.1372	.1543
9			.1475			
19						2.0972
20	1.2018					1.9595
21						1.6095
22						1.2407
23						1.1984
24	.1372	.9503	.9831		.9175	.945
Max	1.2018	.9503	.9831	.1638	.9175	2.0972
Min	.1372	.1638	.1475	.1638	.1311	.1543
Avg	.4248	.5210	.5202	.1638	.4980	1.1720

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014094 / 33 / 11 KV KELI SANGAVI SUB

ST

Feeder No / Name : 201 / 11 KV Kombhalne Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0914	.0762	.061	.061	.0762	.081
2	.081	.0762	.0762	.061	.0762	.0762	.081
3	.081	.0762	.061	.061	.0762	.0762	.0648
4	.081	.0762	.0762	.061	.0762	.0914	.0648
5	.081	.0762	.0914	.0914	.0914	.0914	.0972
6	.1296	.1219	.1067	.1067	.0914	.1067	.0972
7	.1619	.1219	.1219	.1219	.1219	.1219	.1296
8	.1296	.1067	.1067		.0914	.0914	.081
9	.1296	.0762	.0914	.1067	.1067	.0914	.1134
10	.0762	.0762	.061	.0762	.0914	.0972	.0762
11	1.1279	1.0212	1.1279	1.0974	1.0974	1.2793	1.1431
12	1.1584	1.1888	1.0364	1.2651	1.0364	1.1984	1.2193
13	1.2803	1.1888	1.0364	1.2193	1.0364	1.1336	1.0822
14	1.1736	1.0669	1.0364	1.2498	1.0822	1.1336	1.0212
15		1.0822	1.0364	1.1431	1.0212		1.0364
16	1.2498	1.0364	1.1431	.9907	1.0212		.9297
17	1.0669	.945	.9907	1.0364	1.0059	1.085	1.0212
18	1.0059	.8993	.9755	1.0059	1.0364	1.0202	.9755
19	.0914	.1067	.1067	.1219	.1372	.1781	.1219
20	.1067	.1219	.1372	.1219	1.1126	.1619	
21	.1524	.1067	.1372	.1524	.0914	.1619	.0914
22	.1219	.1067	.0762	.1219	.0914	.1296	.0762
23	.0762	.0914	.0762	.0914	.0762	.0972	.0762
24	.081	.0762	.0762	.061	.0762	.0762	.0762
Max	1.2803	1.1888	1.1431	1.2651	1.1126	1.2793	1.2193
Min	.0762	.0762	.061	.061	.061	.0762	.0648
Avg	.4228	.4141	.4109	.4533	.4502	.3898	.4242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 201 / 11 KV Ambad Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2134	.2134	.2134	.2401	.2134	.2134
2	.2134	.2134	.2134	.2134	.2401	.2134	.2134
3	.2134	.2134	.2439	.2134	.2401	.2134	.1981
4	.2134	.2134	.2743	.2134	.2743	.2134	.1981
5	.2439	.2439	.3048	.2134	.3429	.2439	.2439
6	.2439	.2439	.3353	.2743	.3772	.3048	.2743
7	.2743	.2743	.3658	.2743	.3429	.3963	
8	.3048	.2743	.3353	.2743	.3258	.3048	.3048
9	.3353	.2743	.3086	.2286	.2401	.2743	.2743
10	.2134	.2134	.1715	.1677	.1829	.1524	1.6956
11	2.21	2.2253	2.5434	2.3624	2.3167	1.9966	2.3739
12	2.3167	1.6461	2.3739	2.2862	2.1338	2.0424	1.7126
13	2.2862	1.89	2.2721	1.9814	1.9814	2.0729	2.2382
14	2.2253	1.9204	2.2043	1.829	1.829	1.9509	2.0687
15	2.1643	1.89	2.1195	1.6156	1.6766	1.829	2.0348
16	2.0729	1.9204	2.0348	1.9204	1.9052	1.768	2.0348
17	1.8747		2.1534	1.9509		1.89	2.2043
18	1.5851	1.7985	1.8347	1.8652	1.6461	1.4937	1.6766
19	.3048	.2743	.2896	.3429	.3048	.2743	.3048
20	.2743	.3048	.2743	.3429	.3048	.2743	.3353
21	.2591	.2743	.2743	.3086	.2743	.2439	.3429
22	.2439	.2439	.2591	.3086	.2743	.2439	.2743
23	.2286	.2286	.2439	.2743	.2439	.2286	.2134
24	1.3717	.2134	.2134	.2572		.2286	.2134
Max	2.3167	2.2253	2.5434	2.3624	2.3167	2.0729	2.3739
Min	.2134	.2134	.1715	.1677	.1829	.1524	.1981
Avg	.9120	.7482	.9107	.8305	.8044	.7945	.9410

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 202 / 11 KV Ambad GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0686	.0514	.0514	.0686	.0686
2	.0514	.0514	.0686	.0514	.0514	.0686	.0514
3	.0686	.0514	.0686	.0514	.0514	.0686	.0514
4	.0857	.0686	.0686	.0686	.0686	.1029	.0514
5	.1029	.0857	.1029	.1029	.1029	.1029	.1029
6	.12	.1029	.1029	.1372	.1372	.1372	.1372
7	.1372	.1372	.1372	.1372	.12	.1372	.1372
8	.1543	.1372	.1715	.1372	.0857	.1029	.12
9	.1372	.12	.1372	.12	.0857	.1029	.12
10	.1372	.0857	.12	.1029	.1029	.0686	.0857
11	.1029	.0686	.0857	.0686	.0686	.0686	.0686
12	.0686	.0514	.0514	.0686	.0686	.0686	.0686
13	.0343	.0514	.0514	.0343	.0343	.0343	.0686
14	.0343	.0343	.0343	.0343	.0343	.0343	.0514
15	.0343	.0343	.0343	.0343	.0343	.0343	.0514
16	.0514	.0343	.0343	.0343	.0514	.0686	.0514
17	.0686		.0343	.0343		.0686	.0514
18	.0514	.1029	.0514	.0686	.0686	.0514	.0857
19	.1372	.1372	.12	.1372	.12	.12	.1372
20	.1029	.1715	.1029	.12	.12	.12	.1715
21	.0857	.1372	.0857	.0857	.1029	.1372	.1372
22	.0686	.1029	.0686	.0857	.0857	.1029	.1029
23	.0514	.0686	.0686	.0514	.0857	.0686	.0686
24	.0514	.0514	.0686	.0514		.0686	.0686
Max	.1543	.1715	.1715	.1372	.1372	.1372	.1715
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0514
Avg	.0829	.0842	.0807	.0779	.0787	.0836	.0879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 203 / 11 kv Induri Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	1.1888	1.2498	1.2193	1.56	1.4632	1.6461
2	.1829	1.2193	1.2193	1.2193	1.4243	1.3717	1.5242
3	.1829	.1219	.1829	.1219	.1372	.1219	.1219
4	.1829	.1219	.1829	.1219	.1372	.1219	.1219
5	.1829	.1524	.2134	.1219	.2058	.1524	.1219
6	.2134	.2439	.2439	.1829	.3086	.2134	.2134
7	.2439	.2439	.2743	.2134	.3772	.3048	.2439
8	.2439	.1829	.2439	.2134	.2743	.2439	.1829
9	.1829	.1219	.2401	.2439	.2058	.2439	.1829
10	.1677	.1219	.1715	.3048	.1524	.1829	.1715
11	.1524	.1219	.1372	.1829	.1219	.1524	.1372
12	.1219	.1219	.1372	.1524	.1219	.1219	.1543
13	.1219	.1219	.12	.1219	.1067	.1067	.1543
14	.1067	.1219	.12	.1219	.1067	.1067	.1543
15	.1067	.1219	.12	.1219	.1067	.1067	.1543
16	.1219	.1219	.12	.1219		.1219	.1372
17	.1219	.1219	.1372	.1219		.1219	.1372
18	.2439	.1524	.1219	.1372	.1829	.1829	.1524
19	2.4387	1.9814	2.5911	2.713	2.5911	2.8959	2.1338
20	2.1338	1.829	2.4387	2.5434	2.4387	2.7435	1.9814
21	1.89	1.768	2.0424	2.3061	2.1338	2.4387	1.829
22	1.5242	1.6766	1.768	2.0687	1.829	1.9814	1.6766
23	1.4632	1.3717	1.5242	1.8652	1.6461	1.829	1.5242
24	.2134	1.2193	1.2955	1.6956		1.4937	1.6766
Max	2.4387	1.9814	2.5911	2.713	2.5911	2.8959	2.1338
Min	.1067	.1219	.12	.1219	.1067	.1067	.1219
Avg	.5303	.6071	.7040	.7599	.7699	.7843	.6889

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 204 / 11 KV Induri GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0514	.0686	.0514	.0686	.0686	.0686
2	.0686	.0514	.0686	.0514	.0686	.0686	.0686
3	.0686	.0514	.0686	.0514	.0686	.0686	.0686
4	.0686	.0686	.0686	.0686	.0686	.1029	.0686
5	.12	.12	.1029	.1029	.1029	.1372	.1029
6	.1372	.1715	.1029	.12	.1372	.1715	.1715
7	.1372	.1715	.1372	.1372	.1715	.1715	.1715
8	.1715	.1372	.1715	.1372	.1715	.1715	.1715
9	.1715	.1372	.1372	.1029	.1372	.1372	.1372
10	.1372	.1029	.12	.1029	.1029	.0686	.1029
11	.1029	.0686	.0857	.0686	.0686	.0686	.0857
12	.0686	.0514	.0686	.0686	.0686		.0857
13	.0343	.0514	.0686	.0686	.0343	.0343	.0686
14	.0343	.0514	.0686	.0686	.0343	.0343	.0686
15	.0343	.0514	.0686	.0686	.0343	.0343	.0686
16	.0343	.0686	.0686	.0686		.0686	.0686
17	.0686		.0686	.0686		.0686	.0686
18	.1029	.1029	.0686	.0686	.0069	.1029	.1029
19	.1372	.1372	.1372	.1715	.1715	.1372	.1372
20	.1372	.1715	.12	.1372	.1715	.1372	.1715
21	.1029	.1372	.1029	.1029	.1372	.12	.1219
22	.0686	.1029	.0686	.0857	.1029	.1029	.1029
23	.0686	.0686	.0686	.0686	.0857	.0686	.0686
24	.0857	.061	.0686	.0686		.0857	.0686
Max	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Min	.0343	.0514	.0686	.0514	.0069	.0343	.0686
Avg	.0929	.0951	.0907	.0879	.0959	.0969	.1008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 205 / 11 KV MEHENDURI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	1.6156	1.448	1.3717	1.6956	1.4632	1.6766
2	.1829	1.5699	1.3717	1.3717	.1715	1.3717	1.6156
3	.2134	.1829	.1829	.1524	.1715	.1829	.2134
4	.2134	.1829	.1829	.1524	.1715	.1829	.2134
5	.2439	.2439	.2134	.2134	.2401	.2134	.2134
6	.2743	.2743	.2439	.2439	.3086	.2439	.2743
7	.3658	.3429	.2743	.2743	.4115	.3048	.381
8	.4268	.3048	.2439	.2743	.3086	.2743	.3353
9	.762	.2286	.2401	.1524	.3086	.2134	.3048
10	.1829	.1829	.2058	.1524	.1524	.1524	.2401
11	.1524	.1524	.1715	.1219	.1219	.1829	.1715
12	.1219	.1524	.1372	.1219	.1219	.1219	.1372
13	.1219	.1219	.12	.1219	.1067	.1067	.1372
14	.1067	.1524	.12	.1067	.1067	.1067	.1372
15	.1067	.1524	.12	.1067	.1067		.1372
16	.1219	.1524	.12	.1219	.1219		.1372
17	.1219	.1524	.12	.1219			.1372
18	.1524	.1829	.1524	.1372	.1524	.1219	.1524
19	2.5606	2.2558	2.8349	2.713	2.7587	2.7892	2.2558
20	2.3015	2.0729	2.5911	2.5434	2.4387	2.5911	2.1338
21	2.2558	1.9814	2.2862	2.3739	2.2558	2.1338	1.9509
22	1.8595	1.89	1.9966	2.0576	1.9662	1.9814	1.9204
23	1.7375	1.6766	1.829	1.9669	1.5242	1.8138	1.9052
24	.1829	1.6309	1.5242	3.5604		1.4937	1.768
Max	2.5606	2.2558	2.8349	3.5604	2.7587	2.7892	2.2558
Min	.1067	.1219	.12	.1067	.1067	.1067	.1372
Avg	.6230	.7440	.7804	.8556	.7146	.8593	.7729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014112 / 33/11 KV LINGDEO SUBSTATION

Feeder No / Name : 201 / 11 KV LAHIT FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	.2286	.2286	.3239	.2667	.3239	.3429
2	1.8747	.2286	.2286	.3048	.2286	.3048	.3239
3	1.8442	2.3777	2.0119	2.0576	2.0881	1.6309	1.768
4	1.8595	2.4387	2.0729	2.1033	2.1186	1.6766	1.829
5	1.8747	2.4996	2.1338	2.4348	2.21	1.7375	1.9662
6	1.9052	2.5606	2.2558	2.2558	2.3167	1.8747	1.9662
7	1.9357	3.0483	2.7435	2.3167	2.4387	2.21	2.4539
8	1.9662	3.3532	3.0483	2.8959	2.8045	2.7435	2.7892
9	2.1491	3.1703	2.8045	2.9874	2.8197	2.7435	2.652
10	2.0424	2.6825	2.6558	2.5606	2.4996	2.713	2.4234
11	.2286	.1905	.2286	.2286	.2477	.2286	.1905
12	.2096	.1524	.1905	.2286	.2477	.2286	.1715
13	.1905	.1524	.1715	.1524	.2286	.2096	.1524
14	.1715	.1524	.1524	.1524	.2096	.1905	.1524
15	.1524	.1524	.1524	.1524	.2096	.1715	.1715
16	.1524	.1524	.1524	.1524	.2477	.1715	.1905
17	.1524	.1524	.1524	.1524	.2667	.1715	.1715
18	.1524	.2286		.2286	.2477	.2096	.2286
19	.381	.381	.2477	.381	.4382	.4382	.381
20	.381	.381	.2477	.4572	.4572	.4763	.5525
21	.381	.381	.4954	.4191	.4572	.5335	.5335
22	.3048	.3048	.4382	.381	.4191	.4763	.5335
23	.3048	.3048	.362	.3048	.381	.4191	.4572
24	1.9052	.3048	.2286	.3429	.3048	.3429	.381
Max	2.1491	3.3532	3.0483	2.9874	2.8197	2.7435	2.7892
Min	.1524	.1524	.1524	.1524	.2096	.1715	.1524
Avg	1.0177	1.0825	1.0175	.9989	1.0064	.9261	.9493



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014112 / 33/11 KV LINGDEO SUBSTATION

Feeder No / Name : 202 / 11 KV CHASS FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	2.2405	2.2862	2.5396	2.4387	2.5149	2.5453
2	.4001	2.1948	2.1948	2.2862	2.3777	2.3777	2.4844
3	.381	.381	.4001	.4191	.4191	.4191	.4001
4	.4001	.4001	.4001	.4763	.4191	.4191	.4001
5	.4382	.4191	.4191	.4954	.4382	.4191	.4191
6	.4572	.4572	.4382	.5335	.5335	.4572	.4382
7	.4763	.4763	.4572	.5525	.5525	.5144	.4954
8	.4763	.4382	.4763	.4382	.4763	.4572	.4763
9	.381	.381	.4382	.362	.381	.381	.3429
10	.3048	.3429	.3429	.3048	.3048	.2858	.3429
11	.2286	.3048	.3048	.2667	.2858	.2286	.2667
12	.2286	.2858	.2667	.2286	.2477		.2096
13	.2286	.2858	.2477	.2096	.2286	.2096	.1715
14	.2096	.2858	.2286	.2286	.2096	.2096	.1715
15	.2096	.2858	.2286	.2477	.2096	.2286	.1905
16	.2096	.2667	.2477	.2477	.2096	.2286	.2096
17	.1905	.2858	.2286	.2667	.2477	.2477	.1143
18	.1905	.2858		.2286	.2286	.2477	.2286
19	3.1093	2.4082	.2667	3.3836	3.0636	3.1703	2.8654
20	2.8654	2.8654	3.3448	3.094	3.094	3.2312	3.0636
21	2.7282	2.8349	2.9729	3.0788	2.9569	3.2465	3.2007
22	2.4996	2.4691	2.753	3.0636	2.7435	3.0636	2.9569
23	2.3777	2.3929	2.6235	2.7892	2.7435	2.8654	2.6978
24	.4001	2.2862	2.3777	2.6052	2.5453	2.7282	2.652
Max	3.1093	2.8654	3.3448	3.3836	3.094	3.2465	3.2007
Min	.1905	.2667	.2286	.2096	.2096	.2096	.1143
Avg	.8246	1.0531	1.0411	1.1811	1.1398	1.2240	1.1393

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014112 / 33/11 KV LINGDEO SUBSTATION

Feeder No / Name : 203 / 11 KV LINGDEO GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1029	.1097	.1029	.12	.1029
2	.1029	.1029	.1029	.1029	.1029	.12	.1029
3	.1029	.1029	.12	.0857	.0857	.12	.12
4	.12	.1029	.12	.1029	.0857	.1372	.12
5	.1543	.1372	.1372	.1715	.1543	.1543	.1372
6	.1886	.1715	.1886	.2058	.1715	.2058	.2058
7	.2229	.1886	.2058	.2401	.2229	.2229	.2229
8	.2401	.2229	.2401	.2229	.2915	.2401	.2401
9	.2572	.2229	.2229	.2229	.2743	.2229	.2401
10	.1886	.2058	.1629	.1715	.1715	.1715	.1886
11	.1372	.1715	.1267	.1372	.1543	.1372	.1543
12	.12	.12	.1086	.1029	.1543	.12	.1372
13	.12	.1029	.1086	.0514	.1543	.1029	.1029
14	.1029	.0857	.0905	.0686	.1372	.0857	.1029
15	.1029	.0857	.0762	.0686	.12	.0857	.12
16	.1029	.1029	.0724	.0857	.1029	.0857	.12
17	.1372	.0857	.0732	.1029	.12	.12	.1029
18	.1372	.1372		.12	.1372	.12	.1029
19	.2058	.1715	.1086	.1715	.1886	.1715	.1715
20	.1715	.1886	.2353	.2058	.1886	.2058	.2401
21	.1543	.1715	.181	.1715	.1715	.2058	.2058
22	.1543	.1372	.1448	.1543	.1543	.1715	.1543
23	.1372	.12	.1097	.12	.1372	.1372	.12
24	.12	.1029	.1029	.1097	.12	.1372	.12
Max	.2572	.2229	.2401	.2401	.2915	.2401	.2401
Min	.1029	.0857	.0724	.0514	.0857	.0857	.1029
Avg	.1493	.1393	.1366	.1378	.1543	.1500	.1515

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 201 / 11 Kv Shingve SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.2926		.2743	.2743	
2	.3109	.2926		.2743	.2743	
3	.3109	.2926		.2743	.3086	
4	.3292	.3109		.2401	.3086	
5	.3658	.2926		.2401	.3258	
6	.3658	.2926		.2058	.3258	
7	.3658	.3292		.2058	.3258	
8	.3292	.3292		.1886	.3086	
9	.2743		.2427	.1734		
10	.2572			.1387		
11	.1372		.156	.1214		
12	2.0233		1.8861	1.9719		
13	2.0576			2.1262		
14	2.0576			2.0576		
15	1.8347			1.9719		
16	1.989			1.9204	1.8347	1.869
17			2.1125	1.9791		1.8176
18			2.0936	2.0725		1.8861
19			2.0936	2.1472		1.9033
20			.3772	.3734		.2915
21			.3734	.3547		.2915
22			.3547	.3361		.2572
23			.3174	.3174		.2058
24				.3018	.6104	1.6118
Max	2.0576	.3292	2.1125	2.1472	1.8347	1.9033
Min	.1372	.2926	.156	.1214	.2743	.2058
Avg	.8325	.3040	1.0007	.8445	.4897	1.1260

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 202 / 11 Kv Kanhegaon

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4031		.6344	.583	
2	.4382	.4031		.6344	.6001	
3	.4382	.4382		.6859	.6687	
4	.5258	.5258		.7373	.7373	
5	.7011	.7011		.8059	.8916	
6	.8413	1.0166		.823	1.0288	
7	1.0517	1.4022		1.166	1.0974	
8	1.4022	1.6126		1.6118	1.5432	
9	1.1317		1.2689	1.1488		
10	.1029			.1387		
11	.1029		.104	.1029		
12	.1029		.0867	.104		
13	.1029			.0867		
14	.1029			.1052		
15	.0857			.1052		
16	.0857			.1052	.0857	.12
17			.1029	.1132		
18			.1029	.132		
19			.2229	.2641		.2572
20			.2572	.2641		.3086
21			.2427	.2452		.3086
22			.2075	.2263		.2915
23			.168	.1886		.2572
24				.6979	.6859	.2229
Max	1.4022	1.6126	1.2689	1.6118	1.5432	.3086
Min	.0857	.4031	.0867	.0867	.0857	.12
Avg	.4784	.8128	.2764	.4636	.7922	.2523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 203 / 11 Kv Appegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5959	.6135		.5658	.6001	
2	.5959	.6135		.6001	.6001	
3	.6135	.6661		.6001	.6344	
4	.7011	.7011		.6687	.6859	
5	.7888	.7888		.7373	.823	
6	.8764	.8413		.7716	.9774	
7	.9114			.9431	1.0288	
8	1.0867	1.0517		1.166	1.2174	
9	1.0288		1.0974	1.166	.9431	
10	.1029			.1214	.1214	
11	.1029		.104	.1214	.104	
12	.0857		.0867	.1214	.0693	
13	.0857		.104	.104		
14	.0857			.1214		
15	.1029			.1214		
16	.1029			.104	.1029	.0857
17			.0876	.1052		
18			.1052	.1052		
19			.2406	.2454		.2401
20			.2454			.2572
21			.2454	.1578		.2572
22			.2103	.2103		.2572
23			.1578			.2572
24				.1052	.6516	.2401
Max	1.0867	1.0517	1.0974	1.166	1.2174	.2572
Min	.0857	.6135	.0867	.104	.0693	.0857
Avg	.4917	.7537	.2440	.4074	.6114	.2278

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 204 / 11 Kv Puntamba

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1097		.12	.12	
2	.1097	.1097		.12	.12	
3	.1097	.1097		.1372	.1372	
4	.1463	.1463		.1372	.1372	
5	.1829	.1463		.1543	.1715	
6	.1829	.1463		.1715	.1715	
7	.1829	.1463		.1543	.1715	
8	.1463	.1463		.1372	.1372	
9	.1372		.1387	.1214		
10	.12			.0693		
11	.0343		.0693	.0693		
12	1.8347		1.8176	1.8861		
13	1.9719			1.989		
14	1.989			1.989		
15	1.8176			1.9547		
16	1.9547			1.989	1.989	1.9547
17			2.1502	2.1125		1.9376
18			2.0936	2.037		1.8347
19			2.037	2.0182		1.749
20			.1886	.1886		.1543
21			.1578	.1698		.1543
22			.1402	.1698		.12
23			.132	.132		.0857
24				.1227	.1029	1.5604
Max	1.989	.1463	2.1502	2.1125	1.989	1.9547
Min	.0343	.1097	.0693	.0693	.1029	.0857
Avg	.6894	.1326	.8925	.7563	.3258	1.0612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 205 / Savantsar GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1478		.168	.1867	
2	.1478	.1478		.168	.1867	
3	.1663	.1848		.1867	.2054	
4	.1867	.2614		.2427	.2427	
5	.2614	.2987		.2987	.3174	
6	.3772	.3395		.3361	.3921	
7	.3772	.3772		.3696	.4108	
8	.3772	.3772		.3361	.3921	
9	.3086		.3361	.3361		
10	.2801			.2218		
11	.1646		.208	.1848		
12	.1848		.1867	.1848		
13	.1478			.1848		
14	.1478			.1867		
15	.1307			.1867		
16	.168			.2054	.1848	.2075
17			.2075	.2427		.2263
18			.2218	.2378		.2587
19			.2686			.3841
20			.3696			.3696
21			.3326	.3109		.3734
22			.2743	.2743		.3174
23			.2241	.2075		.2075
24				.2054	.2263	.1698
Max	.3772	.3772	.3696	.3696	.4108	.3841
Min	.1307	.1478	.1867	.168	.1848	.1698
Avg	.2234	.2668	.2629	.2398	.2745	.2794

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 201 / 11 Kv Ukkadgaon

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7476	1.2003	1.3435	1.4255	1.5402	1.6032	
2	.7974	1.2689	1.3763	1.5402	1.5893	1.6518	
3	.8307	1.3375	1.4419	1.5893	1.6385	1.7166	
4	.8971	1.4746	1.5546	1.6712	1.704	1.7652	
5	1.0965	1.5604	1.7004	1.7859	1.8023	1.8138	
6	1.3125	1.7661	1.9109	2.0317	1.917	1.9595	
7	1.7444	2.2634	2.3746	2.6871	2.6379	2.8016	
8	2.1763		2.7044	.5571	2.7362	2.8826	
9	1.8939	2.3148	2.1956	.4752	2.1948	2.3644	
16		.4481	.5144	.5144	.5601		.5144
17		.5601	.5144	.5144	.5601		.5144
18			.5144	.5144	.5601		.5144
19	.5144	.5601	.5144	.5144	.5601		.5258
20	.5144	.5601	.5144	.5144	.5601		.5144
21	.5144	.5601	.5144	.5144	.5601		.5144
22		.5716	.5144	.5144	.5658		.5144
23		.5716	.5144	.4973	.5658		.5144
24	.7327	1.2689	1.3435	1.3272	1.4746	1.587	
Max	2.1763	2.3148	2.7044	2.6871	2.7362	2.8826	.5258
Min	.5144	.4481	.5144	.4752	.5601	1.587	.5144
Avg	1.0594	1.1429	1.2256	1.0660	1.3182	2.0146	.5158



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 202 / 11 Kv Dahgaon Bolka SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3032	.3086	.7209	.9175	.9831	.9175	
2	.3032	.3429	.7537	.9831	1.0486	.9503	
3	.3368	.3772	.7865	1.0486	1.1797	.9831	
4	.4042	.4458	.852	1.1142	1.2452	1.0486	
5	.4384	.5144	.9831	1.1797	1.3108	1.1142	
6	.5396	.6173	1.1142	1.2452	1.4403	1.3108	
7	.7082	1.0288	1.4899	1.4419	1.704	1.6842	
8	.96		1.4419	.4588	1.5729	1.749	
9	.6752		1.3763	.5243	1.6827	1.4899	
16			.4801	.5144	.5601		.3429
17		.4481	.5144	.5144	.5601		.4115
18			.5144	.5144	.5601		
19	.5144	.5601	.5144		.5601	.5144	
20	.4801	.5228	.5144		.5601		
21	.4115	.4527	.4801		.5228		
22		.4572	.4458	.4801	.5281		
23		.4572	.4115	.4801	.4527		
24	.3035	.3429	.7209	.9175	.9831	.9175	
Max	.96	1.0288	1.4899	1.4419	1.704	1.749	.4115
Min	.3032	.3086	.4115	.4588	.4527	.5144	.3429
Avg	.4906	.4911	.7841	.8223	.9697	1.1527	.3772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 203 / 11Kv Padhegaon SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3032	.7716	1.1961	1.2125	1.3599	1.3927	
2	.3368	.823	1.2289	.4115	1.4582	1.4255	
3	.4047	.8916	1.2452	1.3927	1.5238	1.4575	
4	.4379	.9774	1.2616	1.491	1.6057	1.5546	
5	.4716	1.0974	1.2955	1.5238	1.6385	1.6842	
6	.5733	1.3203	1.5074	1.6549	1.9498	1.9919	
7	.9432	1.6461	1.9109	1.6549	2.5069	2.332	
8	1.358		2.2672	.426	2.5396	2.672	
9	1.1789	1.8861	1.8679	.4588	2.2977	1.9757	
16		.2614	.2572	.3429	.3547		.1886
17		.2987	.2949	.3772	.3921		.2915
18			.3429	.4115	.4668		.3601
19	.4115	.5041	.4801	.5144	.5601		.4733
20	.3772	.5041	.463		.5415		.5144
21	.3258	.4481	.4115	.4458	.4294		.5144
22		.4191	.3258	.4287	.3772		.4973
23		.2477	.2058	.2572	.3018		.463
24	.3035	.8402	1.1961	1.2452	1.278	1.3927	
Max	1.358	1.8861	2.2672	1.6549	2.5396	2.672	.5144
Min	.3032	.2477	.2058	.2572	.3018	1.3927	.1886
Avg	.5712	.8086	.9866	.8382	1.1990	1.7879	.4128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 204 / Ukkadgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.104	.1143	.1029	.1097	.1143	
2	.1132	.1214	.1334	.128	.12	.1334	
3	.1334	.1372	.1524	.1646	.1646	.1524	
4	.1524	.1715	.2096	.1829	.1829	.2096	
5	.1905	.1886	.2858	.2195	.2195	.3511	
6	.2328	.2279	.3361	.2743	.2561	.4075	
7	.2452	.2058	.3921	.2195	.2561	.4075	
8	.2263		.3734	.2012	.2378	.3544	
9	.1867	.1543	.2926	.1463	.1753	.3292	
10		.2835	.2926			.2926	.2561
11	.1029	.2481	.2743				.1494
12	.1928	.2303	.2195		.1753	.1753	.0732
13			.2195	.2012	.2481		.0732
14		.0739	.2195	.2195	.2126		.0732
15	.2058		.2195	.2378	.2303		.0732
16		.0739	.0732	.2743	.2481		.1463
17		.0924	.128	.2743	.0924		.1829
18			.1646	.3292	.1478		.2195
19	.2572	.2587	.2195	.3601	.2402	.2279	.2378
20	.2279	.2218	.2195	.3841	.2427		.2561
21	.1715	.1867	.1829	.3292	.168		.1829
22		.168	.1463	.2195	.1698		.1463
23		.1524	.1097	.128	.1509		.12
24	.0914	.1052	.1143	.1097	.128	.1143	
Max	.2572	.2835	.3921	.3841	.2561	.4075	.2561
Min	.0914	.0739	.0732	.1029	.0924	.1143	.0732
Avg	.1765	.1703	.2122	.2241	.1898	.2515	.1564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 205 / Dahegaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0857	.0762	.0686	.0914	.0953	
2	.0943	.1029	.0953	.1097	.12	.1143	
3	.0953	.12	.1143	.1463	.1463	.1334	
4	.1143	.1372	.1524	.1829	.1463	.1524	
5	.1509	.1715	.1905	.1829	.1646	.1905	
6	.2075	.2058	.2477	.2195	.2012	.2477	
7	.1132	.2058	.1715	.2195	.1029	.0762	
8	.132		.1905	.2012	.2012	.2054	
9	.1132	.1372	.1463	.1463	.1372	.2035	
10		.1417	.128			.1109	.1463
11	.12	.0886	.1097				.0934
12	.0857	.0739	.0732		.0686		.0914
13			.0732	.1463	.0924		.0732
14		.0934	.0914	.1097	.0924		.0732
15	.0514		.0732	.128	.0924		.0914
16		.0747	.0914	.1463	.1109		.1097
17		.112	.1097	.1463	.1478		.128
18			.1372	.1463	.1867		.1646
19	.1886	.2241	.2012	.2012	.2033	.1886	.2195
20	.1715	.1867	.2012	.2229	.1867		.2012
21	.1372	.1715	.1646	.2012	.2054		.1646
22		.1524	.128	.1372	.1509		.12
23		.1143	.1029	.12	.1132		.1029
24	.0747	.0857	.0953	.0914	.1097	.1143	
Max	.2075	.2241	.2477	.2229	.2054	.2477	.2195
Min	.0514	.0739	.0732	.0686	.0686	.0762	.0732
Avg	.1203	.1343	.1319	.1559	.1396	.1527	.1271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 206 / 11Kv Kasali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3429	.4572	.4115	.3944	.4572	
2	.4028	.3601	.4763	.4115	.3944	.4763	
3	.4028	.3772	.4954	.4458	.4115	.4954	
4	.4028	.3944	.5144	.463	.4287	.5144	
5	.4028	.4115	.5335	.4801	.463	.5335	
12	1.4586	1.5708	1.6712		2.0405		1.8351
13			1.8842	1.8351	1.7652		1.6712
14		1.3763	1.7532	1.9662	1.4089		1.5729
15	1.2003		1.4091	1.8023	1.4899		1.3435
16		1.5223	1.4582	1.6876			1.4582
17		1.7166	1.5074	1.6712	1.7166		1.5402
18			1.4255	1.704	1.668		1.3435
19	.9774	1.4255	1.278	1.4255	1.2452	1.5432	1.1469
20	.4458	.5228	.4287	.463	.5228		.3772
21	.463	.5041	.4801	.4115	.5228		.3601
22		.4954	.4458	.4115	.5093		.2743
23		.5144	.4287	.3944	.4904		.1715
24	.422	.3601	.4954	.4115	.3772	.4763	
Max	1.4586	1.7166	1.8842	1.9662	2.0405	1.5432	1.8351
Min	.4024	.3429	.4287	.3944	.3772	.4572	.1715
Avg	.6346	.7930	.9524	.9645	.9323	.6423	1.0912

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 207 / 11Kv Talegaon Male

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3429	.381	.3429	.3429	.381	
2	.3705	.3772	.381	.3429	.3429	.381	
3	.4042	.4115	.4191	.3944	.3944	.4191	
4	.4379	.4115	.4572	.4115	.4115	.4572	
5	.4379	.4115	.4572	.4115	.4115	.4572	
12	1.989	1.3603	1.5238		1.5432		1.1797
13			1.5402	1.5074	1.2452		1.1142
14		1.166	1.3435	1.4255	1.0364		1.0486
15	1.5775		1.1633	1.2289	.9175		.9831
16		1.0486	1.2289	1.3763	.9831		1.0486
17		1.1142	1.2616	1.4091	1.1797		1.1797
18			1.1305	1.3599	1.1142		1.0486
19	1.0974	.9175	.9175	1.0814	.9831		.9831
20	.4801	.5228	.4115	.4115	.4481		.4115
21	.4458	.4481	.4115	.4115	.4481		.3658
22		.4572	.3772	.4115	.4527		.2743
23		.4572	.3429	.4115	.4527		.2058
24	.3372	.3429	.381	.3429	.3429	.381	
Max	1.989	1.3603	1.5402	1.5074	1.5432	.4572	1.1797
Min	.3353	.3429	.3429	.3429	.3429	.381	.2058
Avg	.7193	.6526	.7849	.7812	.7250	.4128	.8203

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 201 / 11Kv Ravanda GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	16-FEB-17	17-FEB-17
HR	Load (MW)	Load (MW)
8		.1886
9		.1433
16	.1075	
22	.1509	
23	.1307	
Max	.1509	.1886
Min	.1075	.1433
Avg	.1297	.1660

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 202 / 11Kv Dhamori  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17
HR	Load (MW)	Load (MW)
8		2.5101
9		2.4291
17	.1296	
22	.3239	
23	.3239	
24	.1457	
Max	.3239	2.5101
Min	.1296	2.4291
Avg	.2308	2.4696



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 203 / 11Kv Sangvi Bhusar  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17
HR	Load (MW)	Load (MW)
8		.3048
9		.2667
16	2.1628	
17	2.4813	
22	.3048	
23	.3239	
Max	2.4813	.3048
Min	.3048	.2667
Avg	1.3182	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 204 / 11Kv Sangvi + Dhamori  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	16-FEB-17	17-FEB-17
HR	Load (MW)	Load (MW)
8		.1886
9		.1867
16	.112	
22	.1698	
23	.1509	
24	.112	
Max	.1698	.1886
Min	.112	.1867
Avg	.1362	.1877

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 205 / 11Kv Ravanda AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17
HR	Load (MW)	Load (MW)
8		1.4251
9		1.0753
17	.1905	
22	.3429	
23	.3048	
24	.2286	
Max	.3429	1.4251
Min	.1905	1.0753
Avg	.2667	1.2502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 202 / 11Kv Chas (Karwadi) SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9217	.953	.8749	.8796
2				.9217	.953	.8749	.8796
3				.9217	.953	.8749	.8905
4				1.0155	1.0155	.9804	.9374
5				1.1843	1.0936	1.1363	1.0437
6				1.4413	1.2186	1.3916	1.2334
7				1.6518	1.4883	1.587	1.6842
8				1.9433	1.7166	1.8299	1.9662
9		1.448	1.6049	1.5813			
10		.112	.1109	.0754			
11		.0934	.1109				
12		.0924	.1097				
13		.0747	.0905				
14		.0747					
15		.0934					
16		.0934					
17	.0762	.0943					
18	.0953	.0943					
19	.1524	.2075					
20	.2075	.2075					
21	.2263	.2263					
22	.1886	.1886					
23	.1509	.1698					
24	1.0669	.9877	1.0311		1.0279		
Max	1.0669	1.448	1.6049	1.9433	1.7166	1.8299	1.9662
Min	.0762	.0747	.0905	.0754	.953	.8749	.8796
Avg	.2705	.2661	.5097	1.1658	1.1577	1.1937	1.1893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 203 / 11Kv Suregaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1143	.0953	.1143	.0953
2				.1143	.0953	.1143	.0953
3				.1143	.0953	.1143	.0953
4				.1143	.0953	.1143	.0953
5				.1143	.1143	.1143	.0953
6				.1143	.1143	.1143	.1143
7				.1143	.1143	.1143	.1143
8				.0953	.0953	.0953	.0762
9		.0762					
12		1.6741	1.6032	1.6221			
13		1.6712	1.7368	1.6356			
14		1.6194		1.587			
15		1.5061	1.4883	1.5546			
16		1.4243	1.4575	1.5061			
17	1.6057	1.3765					
18	1.4243	1.3117					
19	1.2654	1.1248					
20	.1509	.132					
21	.1509	.132					
22	.132	.1132					
23	.1143	.1143					
24	.1143	.1143	.1132		.0953		
Max	1.6057	1.6741	1.7368	1.6356	.1143	.1143	.1143
Min	.1143	.0762	.1132	.0953	.0953	.0953	.0762
Avg	.6197	.8850	1.2798	.6770	.1016	.1119	.0977

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 205 / 11 Kv Kolpewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0953	.0953	.1143	.1143
2				.0953	.0953	.1143	.1143
3				.0953	.0953	.1143	.1143
4				.0953	.0953	.1143	.1143
5				.1143	.1143	.1143	.1143
6				.1143	.1334	.1143	.1334
7				.1334	.1334	.1143	.1334
8				.0953	.1143	.1143	.0953
9		.0762		.0762			
12		1.9113	2.0388	1.9281			
13		1.9448	2.1125	1.9784			
14		1.9448	2.0481	1.9559			
15		1.8896	1.9498	1.9951			
16		1.873	2.0388	1.9616			
17	2.0287	1.9784					
18	1.8842	1.8442					
19	1.6385	1.5729					
20	.1334	.1334					
21	.1334	.1334					
22	.1334	.1334					
23	.1143	.1143					
24	.0953	.0953	.0953		.0943		
Max	2.0287	1.9784	2.1125	1.9951	.1334	.1143	.1334
Min	.0953	.0762	.0953	.0762	.0943	.1143	.0953
Avg	.7702	1.1175	1.7139	.7667	.1079	.1143	.1167

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 206 / 11 KV Kolpewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6979	.679	.7545	.7167
2				.6979	.679	.7545	.7167
3				.7922	.7922	.8488	.7922
4				1.094	1.0562	1.1128	1.094
5				1.7918	1.3957	1.4335	1.4146
6				1.7918	1.7353	1.8107	1.7541
7				1.8296	1.8861	1.8296	1.8484
8				1.5089	1.5844	1.6221	1.5466
9		1.134	1.1949	1.2012			
10		.8596	.964				
11		.7209	.8383	.8987			
12		.8131	.8954	.9979			
13		.7762	.8779	1.0059			
14		.7577	.7059	.8686			
15		.7392	.823	.9328			
16		.8131	.8779	.9877			
17	1.0136	.8316					
18	.9492	.9511					
19	1.2936	1.2752					
20	1.2803	1.2803					
21	1.1523	1.1523					
22	.9511	.9955					
23	.7947	.823					
24	.6413	.6602	.7167		.6979		
Max	1.2936	1.2803	1.1949	1.8296	1.8861	1.8296	1.8484
Min	.6413	.6602	.7059	.6979	.679	.7545	.7167
Avg	1.0095	.9114	.8771	1.1398	1.1673	1.2708	1.2354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 207 / 11 Kv Sarthak Agro Express NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0018	.0018	.0018	.0018
2				.0018	.0018	.0018	.0018
3				.0018	.0018	.0018	.0018
4				.0018	.0018	.0018	.0018
5				.0018	.0018	.0018	.0018
6				.0018	.0018	.0018	.0018
7				.0018	.0018	.0018	.0018
8				.0018	.0018	.0018	.0018
9		.0018	.0018	.0018			
10		.0018	.0018	.0018			
11		.0018	.0018	.0018			
12		.0018	.0018	.0018			
13		.0018	.0018	.0018			
14		.0018	.0018	.0018			
15		.0037	.0018	.0018			
16		.011	.0018	.0018			
17	.0018	.0128					
18	.0018	.011					
19	.0037	.011					
20	.0018	.011					
21	.0018	.011					
22	.0018	.011					
23	.0018	.011					
24	.0018	.0018	.0091		.0018		
Max	.0037	.0128	.0091	.0018	.0018	.0018	.0018
Min	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Avg	.0020	.0066	.0026	.0018	.0018	.0018	.0018



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014015 / 33/11 KV CHAS

Feeder No / Name : 203 / Wadgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.6832	
2					1.6289		
8					3.3665	3.2398	
9							1.0867
10							.0566
11							.0754
12							.0943
13							.1132
14							.1132
15							.132
16						.132	.132
17	.0754	.132	.1132	.0943	.132	.1132	
18			.2263			.132	
19	.2829		.2829				
23		.2641	.2641	.2452	.2075		
24		1.4842	1.3756	1.4842	1.7918	1.6289	1.6651
Max	.2829	1.4842	1.3756	1.4842	3.3665	3.2398	1.6651
Min	.0754	.132	.1132	.0943	.132	.1132	.0566
Avg	.1792	.6268	.4524	.6079	1.4253	1.1549	.3854

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014015 / 33/11 KV CHAS

Feeder No / Name : 204 / Wadgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0189	
2					.0377		
8					.0189	.0189	
9							.0189
10							.0189
11							.0189
12							.0189
13							.0189
14							.0189
15							.0189
16						.0189	.0189
17	.0189	.0189	.0189	.0189	.0189	.0189	
18			.0377			.0189	
19			.0377				
23	.0377	.0189	.0377	.0377	.0377		
24		.0377	.0189	.0377	.0377	.0189	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0189	.0377
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0283	.0252	.0302	.0314	.0302	.0189	.0210

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014015 / 33/11 KV CHAS

Feeder No / Name : 205 / 11Kv Baktarpur  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1886	.1509	
8					.1509	.1698	
9							.0953
10							.0754
11							.0754
12							2.8826
13							2.8502
14							2.8826
15							2.915
16						3.7828	2.8837
17	3.8009	2.9502	3.2952	4.0543	3.2036	3.7285	
18			3.2217			3.0769	
19	2.1719	2.4253	2.733	2.7511	2.2805		
23			.1886				
24		.1886	.1886	.1886	.1886	.1886	.1886
Max	3.8009	2.9502	3.2952	4.0543	3.2036	3.7828	2.915
Min	2.1719	.1886	.1886	.1886	.1509	.1509	.0754
Avg	2.9864	1.8547	1.9254	2.3313	1.2024	1.8496	1.6499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 201 / 11Kv Kumbhari  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.12	.12	.1543		
2	.1029	.1029	.12	.12	.1372		
3	.12	.1029	.12	.12	.1372		
4	.12	.12	.1372	.12	.1372		
5	.1372	.1543	.1543	.1372	.1543		
6	.1715	.1886	.1715	.1543	.1886		
7	.1543	.1886	.1715	.1715	.1886		
8	.12	.12	.1543	.12	.1372		
9							.1029
10							.0857
11							.0343
12							2.5377
13					2.5377		2.2805
14					2.4177		2.2977
15					2.2977		2.2291
16					2.2977		2.1776
17		2.2291	2.0508	2.1574		1.6735	1.6735
18		2.1148	1.8138	1.9719		1.6968	1.669
19		1.9067	1.6796	1.761		1.5146	1.4662
20		.2033	.168	.1663		.1867	.1663
21		.2054	.1494	.1867		.1478	.1494
22		.1848	.1494	.1848		.1478	.1294
23		.168	.1307	.1848		.1294	.0934
24		.1494	.1307	.1867		.168	.1494
Max	.1715	2.2291	2.0508	2.1574	2.5377	1.6968	2.5377
Min	.1029	.1029	.12	.12	.1372	.1294	.0343
Avg	.1286	.5151	.4638	.4914	.8988	.7081	1.0776

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 202 / 11Kv Mahegaon Deshmukh  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5604	1.5089	1.5775	1.5775	1.6461		
2	1.8004	1.5432	1.5775	1.5775	1.6461		
3	1.8861	1.5775	1.6461	1.5775	1.6632		
4	1.9719	1.9204	1.7833	1.6461	1.6975		
5	2.0748	2.3663	1.9547	1.749	1.8519		
6	2.2634	2.4177	2.0919	2.1605	2.0919		
7	2.5377	2.6235	2.6578	2.5377	2.5892		
8	2.6749	2.7435	2.7778	2.8464	2.7435		
9							2.3663
10							.12
11							.12
12							.1029
13					.0686		.0686
14					.0857		.12
15					.0857		.12
16					.0857		.1372
17		.056		.056		.0373	.1307
18		.0747		.056		.0934	.1663
19		.0934	.2241	.2218		.1848	.2743
20		.2427	.2241	.2772		.2218	.2926
21		.2241	.2587	.2012		.2218	.3109
22		.2033	.2614	.2054		.1848	.3142
23		.168	.112	.1848		.112	.2427
24		1.4022	1.4022	1.4632		1.3226	1.2342
Max	2.6749	2.7435	2.7778	2.8464	2.7435	1.3226	2.3663
Min	1.5604	.056	.112	.056	.0686	.0373	.0686
Avg	2.0962	1.1978	1.3249	1.1461	1.3546	.2973	.3826

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 203 / Kumbhari GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.12	.0103	.1029	.1029		
2	.12	.12	.1029	.1029	.1029		
3	.1372	.12	.1029	.1029	.12		
4	.1543	.12	.1372	.1372	.1372		
5	.1715	.1543	.1715	.1543	.1715		
6	.2058	.2058	.2058	.1715	.2401		
7	.2229	.2229	.2401	.2058	.2229		
8	.2058	.2058	.2229	.1715	.2401		
9							.1543
10							.1372
11							.1029
12							.0686
13					.1029		.0857
14					.0514		.0857
15					.0686		.0857
16					.0686		.0857
17		.0934	.112	.0924		.112	.0943
18		.0924	.112	.1294		.112	.1132
19		.1848	.1494	.2218		.1494	.1867
20		.1867	.2241	.2587		.2195	.2402
21		.1663	.1848	.2033		.1848	.2241
22		.1463	.1494	.1663		.1478	.168
23		.1294	.112	.1307		.1294	.1307
24		.112	.112	.112		.112	.1109
Max	.2229	.2229	.2401	.2587	.2401	.2195	.2402
Min	.12	.0924	.0103	.0924	.0514	.112	.0686
Avg	.1672	.1488	.1468	.1540	.1358	.1459	.1296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 204 / 11Kv Dharangaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.12	.12	.12		
8	.1886	.2229	.2058	.1715	.1886		
9							.1543
13					.0857		
16					.1029		.1029
17		.112	.0934	.0934		.0924	.1132
24		.1307	.132	.1307		.1307	.112
Max	.1886	.2229	.2058	.1715	.1886	.1307	.1543
Min	.1029	.1029	.0934	.0934	.0857	.0924	.1029
Avg	.1458	.1421	.1378	.1289	.1243	.1116	.1206

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 205 / 11 Kv Dharangaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2743	.2401	.2401		
8	.2572	.2915	.3258	.2572	.3258		
9							.3086
13					2.4006		
16					2.0919		2.0919
17		1.8823	1.7665	1.6537		1.8004	1.6004
24		.2987	.2641	.2614		.168	.1867
Max	.2743	1.8823	1.7665	1.6537	2.4006	1.8004	2.0919
Min	.2572	.2743	.2641	.2401	.2401	.168	.1867
Avg	.2658	.6867	.6577	.6031	1.2646	.9842	1.0469



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014113 / 33/11KV KHIRDI

GANESH(YESGAON)

Feeder No / Name : 201 / 11Kv Yesgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4191	.4191	
2	.381	.381	.4191	.4191	
3	.381	.381	.4191	.4191	
4	.4191	.4191	.4572	.4572	
5	.4572	.4191	.4572	.4954	
6	.4954	.4572	.4954	.4954	
7	.4954	.4572	.5335	.4191	
8	.4572	.4954	.5335	.4954	
9	.4191	.4572	.4954	.4954	
10	.3048	.381	.4572	.381	.4572
11	.3048	.3429	1.7078	.2667	.381
12	1.8564	1.7078		1.9433	1.9292
13	1.8343	1.6324	1.6248	1.8343	1.781
14		1.5181	1.5935	1.6872	1.6248
15	1.5497	1.406	1.5935	1.5623	1.5623
16	1.9814	1.4506	1.4815	1.4373	1.4998
17	1.7185	1.5123	1.3748	1.5497	1.5935
18	1.5546	1.406	1.3435	1.4373	1.3245
19	1.3717	1.2193	1.2963	.0168	1.2944
20	.3429	.381	.381	.4572	
21	.4572	.4954	.4954	.4572	
22	.381	.4954	.4572	.4572	
23	.5144	.4954	.4572	.4572	
24	.4191	.4191	.4572	.4572	
Max	1.9814	1.7078	1.7078	1.9433	1.9292
Min	.3048	.3429	.381	.0168	.381
Avg	.8034	.7796	.8239	.7715	1.3448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014113 / 33/11KV KHIRDI

GANESH(YESGAON)

Feeder No / Name : 202 / 11Kv Nategaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	1.406	1.2342	1.2944			1.4937
2	1.0105	1.2342	1.2342	1.2944			1.4937
3	1.0235	1.2803	1.2643	1.3108			1.5432
4	1.1888	1.3413	1.3717	1.3889			1.6248
5	1.5546	1.3717	1.4998	1.6049			1.7185
6	1.821	1.5432	1.5813	1.7711			1.7711
7	1.5935	1.6975	1.9845	1.7078			2.0622
8	1.8027	1.9444	2.0622	2.0485			2.2222
9	1.5623	1.7459	1.8747	2.0805			1.9814
10	.1905		.3429	.4191	.4572	.381	
11	.1905	.3429	.4191	.2286	.4954	.4191	
12	.1905	.3429		.381	.5335	.4572	
13	.2667	.381	.4191		.5335	.4954	
14	.3048	.3429	.4572		.5335	.4954	
15	.3048	.3048	.4572	.4954	.3429	.5335	
16	.3429	.3048	.4191	.5335	.4572	.5335	
17	.3429	.381	.3429	.5335	.2667	.5335	
18	.3429	.4572	.4191	.4954	.3429	.5335	
19	.3048	.5335	.4954	.5335		.5335	
20	.3429	.5335	.4954	.5335			
21	.0762	.4572	.4572	.4572			
22	.3239	.3429	.3429	.381			
23	.2286	.3048	.3048	.2667			
24	.9633	1.2342	1.2643	1.2643			
Max	1.821	1.9444	2.0622	2.0805	.5335	.5335	2.2222
Min	.0762	.3048	.3048	.2286	.2667	.381	1.4937
Avg	.7189	.8621	.9019	.9556	.4403	.4916	1.7679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014113 / 33/11KV KHIRDI

GANESH(YESGAON)

Feeder No / Name : 203 / 11Kv Yesgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.2858	.2858		.2858
2	.2477	.2477	.2858	.2858		.2477
3	.2477	.2667	.2858	.2858		.2477
4	.2858	.3048	.3429	.362		.3048
5	.362	.381	.4001	.4001		.362
6	.4572	.4572	.4572	.4572		.4191
7	.4954	.4954	.4954	.4763		
8	.4001	.4294	.4572	.381		
9	.4108	.3475	.3429	.3921		
10	.4805		.4108	.4066	.3361	
11		.4251	.4066	.4024	.394	
12	.4024	.3841		.3921	.2896	
13	.3109	.3292	.3292	.3696	.3361	
14	.3658	.3475	.3511	.3658	.3174	
15	.3696	.3475	.3696	.3511	.3475	
16	.3696	.3326	.3696	.3142	.3475	
17	.3841	.2957	.3841	.3475	.3475	
18	.3582	.4066	.4066	.3326	.3582	
19	.4066	.4755	.4066	.4066	.4435	
20	.4481	.5175	.462	.4854		
21	.4481	.4668	.4294	.4527		
22	.3734	.381	.381	.381		
23	.2858	.3239	.3048	.381		
24	.2667	.2667	.3048	.2858		
Max	.4954	.5175	.4954	.4854	.4435	.4191
Min	.2477	.2477	.2858	.2858	.2896	.2477
Avg	.3663	.3694	.3769	.3750	.3517	.3112

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014117 / 33/11Kv Karanji

Feeder No / Name : 201 / 11Kv Karanji  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17
HR	Load (MW)
16	.4191
Max	.4191
Min	.4191
Avg	.4191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 014109 / 33/11 KV INDUSTRIAL ESTATE

Feeder No / Name : 201 / 11 KV Sanjiwani

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3429	.3429
2			.3429	.3429
3			.3429	.3429
4				.3429
5			.3429	.381
6			.381	
7		.3429	.381	.381
8	.4191			.381
14	.4458			
16				.5716
17				.5335
18				.4763
24			.3429	.3429
Max	.4458	.3429	.381	.5716
Min	.4191	.3429	.3429	.3429
Avg	.4325	.3429	.3538	.4035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 014109 / 33/11 KV INDUSTRIAL ESTATE

Feeder No / Name : 202 / 11 KV Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4289	1.3336
2			1.4289	
3			1.4289	1.3336
4			1.3336	
5			1.4289	
6			1.3336	
7		1.1431	1.3336	1.3336
8	1.1812			1.3336
14	1.4403			
16				1.1812
17				1.1431
18				1.2384
24			1.4289	1.3336
Max	1.4403	1.1431	1.4289	1.3336
Min	1.1812	1.1431	1.3336	1.1431
Avg	1.3108	1.1431	1.3932	1.2788

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 017004 / 132/11 KV KOPERGAON

Feeder No / Name : 205 / 11 KV KOPERGAON URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-FEB-17
HR	Load (MW)
2	.1067
3	.0762
4	.0762
5	.0914
6	.1067
7	.1524
10	.2286
11	.1677
12	.1219
13	.1067
14	.0762
15	.0762
16	.0914
17	.1067
18	.1219
19	.1524
20	.1372
21	.1372
22	.1372
23	.1067
24	.0914
Max	.2286
Min	.0762
Avg	.1176

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 201 / Puntamba

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8233	1.9662	2.13		2.079		
2	1.8233	1.9662	2.1628		2.0957		
3	1.9281	2.0287	2.2298		2.1195		
4	2.1605	2.0622	2.2466		2.1534		
5	2.3061	2.0622	2.2634		2.1874		
6	2.2024	1.1622	2.2885		2.4697		
7		1.2449	2.9492		2.9504		
8		3.8058	3.4642		3.4974		
9			3.0445	3.1295	2.8673		2.915
17		.373		.4115		.6767	
18		.39	.5087	.4458		.6602	
19		.7716	.8495	.7442			
20		1.1949	1.2696	1.3203			
21		1.1576	1.1361	1.2323			
22		.9425	.8954	1.0374			
23		.8131	.8402	.8676			
24	1.7695	1.9826	2.1792	1.9559	2.079	1.9616	
Max	2.3061	3.8058	3.4642	3.1295	3.4974	1.9616	2.915
Min	1.7695	.373	.5087	.4115	2.079	.6602	2.915
Avg	2.0019	1.4952	1.9036	1.2383	2.4499	1.0995	2.915



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 203 / Astagaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4413	1.5089	1.2955		1.6956		
2	1.4413	1.5089	1.3717		1.7804		
3	1.5432	1.6956	1.4842		1.8861		
4	1.6289	1.8861	1.5623		2.0576		
5	1.7147	2.0576	1.7185		2.4006		
6	1.7284	.4854	2.0119		2.7664		
7		.4854	2.9492		3.2322		
8		3.315	3.2322		1.6194		
9			2.982	2.7854	1.3717		2.9492
18		.2622	.2652				
19		.3605	.3353	.3353			
20		.4715	.4715	.4715			
21		.4338	.4338	.4338			
22		.415	.3961				
23		.3772	.3772	.3898			
24	1.4413	1.5089	1.2955	1.3565	1.6956	2.0348	
Max	1.7284	3.315	3.2322	2.7854	3.2322	2.0348	2.9492
Min	1.4413	.2622	.2652	.3353	1.3717	2.0348	2.9492
Avg	1.5627	1.1181	1.3864	.9621	2.0506	2.0348	2.9492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 204 / Pimpalas

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6443	.7922	.6602		.7545	
2	.6443	.811	.7167		.811	
3	.6783	.8488	.7733		.9054	
4	.9156	.9431	.9242		1.0185	
5	.9156	.9997				
6		1.0185				
12	2.1026			1.8176	2.3061	
13	2.2291		2.1026	2.2634	2.0576	
14	2.0508		2.0348	2.1152	.0229	
15	1.8427	1.2717		1.97	2.0576	
16			1.933	1.97	2.1384	
17		1.3395	1.8313	1.933		
18		1.3565	1.5939	1.8652		
19		1.065	1.3056	1.3565		
20		.9156	.8648	.9326		
21		.9335	.8478	.8648		
22		.8962	.8962	.9149		
23		.7842	.8029	.8589		
24	.6613	.7922	.679	.7167	.7733	.8676
Max	2.2291	1.3565	2.1026	2.2634	2.3061	.8676
Min	.6443	.7842	.6602	.7167	.0229	.8676
Avg	1.2685	.9845	1.1978	1.5061	1.2845	.8676

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 206 / Saibaba

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.3944	.1429		.543		
2	.4481	.4134	.1429		.5573		
3	.4858	.4464	.1572		.5792		
4	.5121	.5007	.1593		.6081		
5	.5601	.4854	.1593		.5502		
6	.6722	.6602	.2107		.7968		
7		.945	.25		1.1043		
8		1.2631	.6009		1.3123		
9			1.1203	1.0562	1.1873		.7907
16			.2881	.2812	.3125		
17		.3201	.2881	.2881			
18		.3521	.3241	.3361			
19		.5975	.4801	.4161			
20		.6348	.5441	.4961			
21		.5788	.5281	.4801			
22		.4294	.5373	.5228			
23		.4251	.4435	.4294			
24	.4481	.3944	.1572	.4652	.5502	.4793	
Max	.6722	1.2631	1.1203	1.0562	1.3123	.4793	.7907
Min	.4481	.3201	.1429	.2812	.3125	.4793	.7907
Avg	.5106	.5526	.3630	.4771	.7365	.4793	.7907

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 207 / Upasani Baba

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1765	1.1088	1.1088		1.2936		
2	1.1765	1.1088	1.1458		1.2936		
3	1.2127	1.2136	1.1949		1.3443		
4	1.267	1.2883	1.2696		1.4003		
5	1.3756	1.363	1.4003		1.4563		
6	1.9004	1.8298	1.7737		1.8861		
7	2.3529	2.1845	2.2779		2.1313		
8	2.4072	2.3712	2.5766		2.5206		
9	2.1491		1.1203	2.2565	2.4025		2.2262
10	2.0416		2.2624	2.2207	2.2314		
11	2.0774		2.1357	2.0995	2.1719		
12	1.9185		1.7194	1.7558	1.9004		
13	1.7909		1.5746	1.848	1.6879		
14			1.6289	1.7558	1.6476		
15	2.1491	1.448		1.8461	1.6834		
16			1.5364	1.8625			
17		1.6289	1.8823	1.7918			
18		1.7375	2.1176	2.1176	1.7194		
19		2.2862	2.5882	2.5339			
20		2.2218	2.3529	2.2805			
21		1.9418	1.9728	1.9547			
22		1.6651	1.6476	1.6289			
23		1.4175	1.4706	1.5223			
24	1.1765	1.1088	1.1088	1.2382	1.3306	1.3121	
Max	2.4072	2.3712	2.5882	2.5339	2.5206	1.3121	2.2262
Min	1.1765	1.1088	1.1088	1.2382	1.2936	1.3121	2.2262
Avg	1.7448	1.6426	1.7333	1.9196	1.7707	1.3121	2.2262

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014007 / 33/11 KV NIMGAON S/S

Feeder No / Name : 201 / 11 KV MALHAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6302	1.1182	.4466	1.0724	.0015	1.199	
2	.6363	1.1256	.4588	1.1043	.0015	1.1848	
3	.6516	1.1514	.4679	1.0935		1.1906	
4	.6691	1.1421	.4885	1.1313		1.2159	
5	.6775	1.1627	.4915	1.1603		1.252	
6	.6958	1.1615	.4877	1.1949		.7649	
7	.7072	1.1913	.4885	1.1072	.2096	.0107	
8	.6264	1.1408	.413	1.0746			
9	.5533	.3658	.4275	1.0124	.3589	.615	
10	.4954	.5274	.5213	.5091		.4138	
11	2.1117	2.1087	2.0157	1.7513	2.2276	1.717	1.6613
12	2.7191	2.6056	2.4928	2.6985	2.8479	2.6589	2.71
13	2.713	2.5377	2.5057	1.816	2.6048	2.5255	2.5248
14	2.5713	2.3251	1.5767	2.3708	2.3182	1.9799	2.3457
15	2.1658	2.2565	.7484	2.2314	2.1574	2.0081	2.3022
16	4.1114	2.2588	.6996	2.1917	2.1079	2.1696	2.1917
17	4.2311	2.3343	.6874	2.2565	2.1666	2.1026	2.2138
18	4.0108	2.2352	1.5943	2.2504	2.1132	2.1559	2.1956
19	3.8298	2.1224	2.0828	2.1353	2.1102	2.114	2.0203
20	.1959	.7026	1.233	.6912	.109	.7026	.5479
21	1.1312	.7194		.7186	.1128	.7293	.5228
22	1.2559	.0137	1.0854	.5883	.1029	.6196	.5296
23	1.235	.5388	1.25	.0023	.0114	.6798	1.2109
24	2.3426	.9291	.9672	.5138	.5152		1.8228
Max	4.2311	2.6056	2.5057	2.6985	2.8479	2.6589	2.71
Min	.1959	.0137	.413	.0023	.0015	.0107	.5228
Avg	1.7070	1.4073	1.0274	1.3615	1.2265	1.3641	1.7714

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014007 / 33/11 KV NIMGAON S/S

Feeder No / Name : 203 / 11 KV SHRINATH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	2.2952	1.6651	3.5779	3.9173	4.2357	4.3096
2	.9877	2.3188	1.6606	3.613	3.8807	4.177	4.2593
3	1.0105	2.3463	1.6568	3.6519	3.8663	4.1564	4.1246
4	1.028	2.3984	1.685	3.8039	4.2058	4.3679	4.1999
5	1.1736	2.507	1.8168	4.1274	4.537	4.6807	4.3172
6	1.3817	3.0232	2.2085	4.7564	5.2287	5	4.5202
7	2.2619	4.8132	3.0636	5.9295	6.4247	6.382	6.0896
8	2.6528	5.0243	3.4164	6.7362	6.0697	7.0912	6.8599
9	2.4394	2.6048	3.1001	5.5885	3.4042	3.5269	3.315
10	.25	.253	.2378	.2705	.2522	.2507	.298
11	.1715	.2058	.1791	.1959	.2012	.2286	.2515
12	.1715	.1776	.1753	.1928	.1631	.2157	.1829
13	.1638	.1631	.1402	.2035	.173	.1768	.1677
14	.1578	.1539	.1395	.1867	.176	.1776	.1593
15	.16	.1692	.1417	.1844	.1768	.1806	.1829
16	.3226	.1623	.1417	.1776	.1654	.1913	.1806
17	.2703	.173	.1425	.1539	.1745	.1837	.1722
18	.338	.1776	.2119	.2004	.1981	.1669	.2096
19	.5585	.2957	.3125	.3102	.314	.3193	.2797
20	.5702	.3201	.6398	.346	.3368	.3704	.3262
21	.5866	.3094	.633	.3422	.3353	.3643	.3635
22	.5255	.2865	.608	.3086	.3216	.349	.3788
23	.9305	.8352	1.3038	1.1477	1.3839	1.4083	.3597
24	2.0471	2.658	3.2399	3.6945	3.9151	4.2081	2.4123
Max	2.6528	5.0243	3.4164	6.7362	6.4247	7.0912	6.8599
Min	.1578	.1539	.1395	.1539	.1631	.1669	.1593
Avg	.8800	1.4030	1.1883	2.0708	2.0759	2.1837	1.9967

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014007 / 33/11 KV NIMGAON S/S

Feeder No / Name : 206 / 11kv Godavari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2311		.6152	.6469	.5982	.652
2		.2166		.6292	.6337	.5752	.6836
3		.2166		.603		.5752	.6845
4		.2452		.6816	.6957	.6591	.7406
5		.3177		.7088	.89	.8762	.8641
6		.4044		.7482	1.044	.8882	.8865
7		.8087		1.1814	1.2363	1.1021	1.2929
8		1.1279		1.4702	1.4255	.916	1.2771
9				1.1831			
16	.1157						
17	.1012						
18	.1298						
19	.1442						
20	.1298		.1303				
21	.101		.1178				
22	.101		.1178				
23	.1155		.0916				
24	.361	.2166	.4355	.6283	.6337	.5982	.5924
Max	.361	1.1279	.4355	1.4702	1.4255	1.1021	1.2929
Min	.101	.2166	.0916	.603	.6337	.5752	.5924
Avg	.1444	.4205	.1786	.8449	.9007	.7543	.8526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 201 / Rastapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1337	.0829	.0835		.1326
2		.1504	.0829			.1326
3		.1671	.0995	.1003		.1492
4		.169	.116			.1658
5		.169	.1326	.1003		.1658
6		.1521	.1492	.117		.1658
7		.1337				
8		.1014				
9		.1003				
10		.1003				
11		.1003				
12		1.6709	1.8233	2.005		1.7404
13		1.9215	1.9062	2.005		1.8233
14		1.7564	1.5746	2.005		1.7404
15		1.6728	1.6575	2.005		1.7404
16		1.6728	1.7404	1.8379		1.8233
17		1.6728	1.6575	1.6709		1.6575
18		1.6728	1.6409	1.6709		1.7404
19		1.5055	1.5746	1.5038		1.5746
20		.1337	.116	.1337		.0995
21		.1003	.116			.116
22		.0835	.0995	.1168		.1326
23		.0835	.0995	.1003		.116
24	.0845	.1337	.0835	.0835	.1001	.1326
Max	.0845	1.9215	1.9062	2.005	.1001	1.8233
Min	.0845	.0835	.0829	.0835	.1001	.0995
Avg	.0845	.6482	.7765	.9712	.1001	.8078



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 202 / Changdev

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3107	.2401	.2417		.2743
2		.3107	.2401	.2417		.3086
3		.3452	.2401	.2417		.3429
4		.3797	.2401	.2589		.3772
5		.4143	.2572	.2762		.3772
6		.4143	.2572	.3452		.4115
7			.3944	.4488		.4115
8			.4801	.4833		.4458
9			.4287	.4833		.2915
11		.0863				
12		.0862				
13		.069				
14		.0862				
15		.069				
16		.0863	.1029	.0863		.1029
17		.1036	.1029	.1381		.12
18		.1208	.12	.1382		.12
19		.2589	.2401	.2592		.2401
20		.2589	.2572	.2765		.2401
21		.1899	.2401			.2572
22		.1554	.1886	.1728		.2058
23		.1208	.12	.1381		.12
24	.1207	.2589	.2417	.2417	.2076	.2058
Max	.1207	.4143	.4801	.4833	.2076	.4458
Min	.1207	.069	.1029	.0863	.2076	.1029
Avg	.1207	.2063	.2440	.2630	.2076	.2696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 204 / 11 KV PNTB GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2954	.2829	.2415		.2829
2		.2954	.2829	.2601		.3018
3		.3508	.2829	.2601		.3961
4		.4066	.3772	.3715		.415
5		.4444	.4715	.4644		.4527
6		.5196	.547	.5578		.547
7		.5741	.6413	.5818		.5847
8		.5573	.5658	.5072		.5658
9		.5175	.4715	.4687		.4904
10		.3519	.3547	.3742		.3584
11		.3138	.3734	.3361		.3395
12		.3508	.3109	.3323		.3772
13		.3309	.3292			.3018
14		.3116	.2926	.3138		
15		.2914	.2896			
16		.3285	.3258	.3309		
17		.365	.3258	.311		
18		.4211	.4251	.3869		
19			.5359	.5376		
20		.4663	.5544	.5573		
21		.4099	.462	.4277		
22		.3475	.3326	.3719		
23		.2926	.2772	.2975		
24	.2969	.3323	.2778	.2587	.2846	.3395
Max	.2969	.5741	.6413	.5818	.2846	.5847
Min	.2969	.2914	.2772	.2415	.2846	.2829
Avg	.2969	.3859	.3913	.3886	.2846	.4109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 205 / 11KV BAJARANG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0658	.0655	.0658	
2		.0658	.0655	.0658	
3		.0822	.0655	.0822	
4		.0987	.0983	.0987	
5		.1315	.1147	.1315	
6		.1315	.1311	.1644	
7		.1483			
8		.1318			
9		.0824			
10		.0493			
11		.0329			
12		.9043	.9995	1.1016	
13		.9865	1.0322	1.0852	
14		.9865	1.0814	1.0687	
15		.9865	.6882	.9865	
16		.9865	1.0486	1.0194	
17		.9536	1.1305	1.0523	
18		.9207	1.0159	.9865	
19		.9207	.9339	.9865	
20		.1315	.1311	.1315	
21		.0822	.0983	.1003	
22		.0822	.0819	.0822	
23		.0658	.0655	.0658	
24	.0657	.0658	.0658	.0655	.0658
Max	.0657	.9865	1.1305	1.1016	.0658
Min	.0657	.0329	.0655	.0655	.0658
Avg	.0657	.3789	.4691	.4916	.0658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014009 / 33/11 KV POHEGAON

Feeder No / Name : 202 / 11KV MANEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)
12		2.2891
14		2.2539
15		2.1672
17	2.0683	
Max	2.0683	2.2891
Min	2.0683	2.1672
Avg	2.0683	2.2367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014009 / 33/11 KV POHEGAON

Feeder No / Name : 204 / Korhale

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-FEB-17
HR	Load (MW)
9	3.3913
Max	3.3913
Min	3.3913
Avg	3.3913

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014009 / 33/11 KV POHEGAON

Feeder No / Name : 205 / 11 KV Mayureshwar GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
9		.5487	
10		.439	
11		.3696	
12		.2195	
14		.1829	
15		.1663	
17	.2743		.2743
Max	.2743	.5487	.2743
Min	.2743	.1663	.2743
Avg	.2743	.321	.2743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014010 / 33/11 KV RANGANGAON

Feeder No / Name : 201 / Javalka

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429	.3429	.3048	.381	.3429
2	.3429	.362	.3429	.362	.2667	.381	.381
3	.381	.381	.381	.381		.4191	.381
4	.381	.4382	.4191	.3772		.4191	.4191
5	.381	.4572	.4191	.415		.4572	.4572
6	.4191	.4572		.4338		.4572	.4904
8		2.3472					
12	2.4813	2.3739	2.5484	3.0664	2.8837		2.9172
13	2.2475	2.6379	3.0178	2.9005	2.6825		2.8166
14		2.4577	2.7664	2.8837	2.5857		2.5692
15	2.0287	2.3102	2.4531	2.8669	2.7664	2.7496	
16	2.1879	2.7199	2.4034	2.7664	2.8502	3.3234	3.1493
17	2.2969	2.7199	2.6825	2.5652	2.9172	3.1623	2.4531
18	1.8299	2.3472	2.5484	2.5095	2.2801	3.2278	2.8334
19	.3241	1.9784	2.146	2.4587	2.1216	2.5232	1.9919
20	.4001	.5335	.547	.4763	.547	.4954	.2286
21	.4954	.5525	.5335	.5144		.5335	.381
22	.4382	.4954	.5335	.5525	.5144	.4954	.3429
23	.4382	.4954	.4572	.4954	.4763	.4954	.3048
24	.4191	.4001	.4191	.4572	.4191	.4191	.4191
Max	2.4813	2.7199	3.0178	3.0664	2.9172	3.3234	3.1493
Min	.3241	.3429	.3429	.3429	.2667	.381	.2286
Avg	.9908	1.3404	1.3867	1.4118	1.6868	1.2462	1.2710

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014010 / 33/11 KV RANGANGAON

Feeder No / Name : 204 / 11kv Kakadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0572	.0953	.0572	.0762	.0762
2	.0953	.0762	.0762	.0953	.0572	.0762	.0762
3	.0953	.1334	.1143	.0953	.1143	.0953	.0953
4	.0953	.1524	.1143	.1143	.1334	.0953	.1143
5	.1143	.1524	.1334	.1334	.1334	.1334	.1143
6	.1334	.1715	.1524	.1524	.1715	.1334	.1334
7	.1715	.1905	.1524	.1715	.1715	.1524	.1334
8	.1334	.1524	.1524	.1524	.1524	.1715	.1334
9	.1006	.0133	.1143	.1334	.1267	.1143	.1052
10	.0829	.0095	.0762	.0762	.0762	.0953	.0701
11	.0686	.0076	.0762	.0572	.0572	.0469	.0351
12	.0572	.0057	.0572	.0762	.0572	.0381	.0572
13	.0381	.0038	.0572	.0572	.0572	.0381	.0572
14	.0572	.0572	.0381	.0381	.0572	.0572	.0469
15	.0572	.0057	.0572	.0381	.0572	.0381	.0633
16	.0381	.0057	.0572	.0572	.0762	.0381	.0474
17	.0572	.0057	.0572	.0762	.0953	.0572	.0572
18	.0886	.1143	.0876	.0953	.0953	.0762	.0724
19	.1629	.1334	.1524	.1334	.1524	.1524	.1629
20	.1334	.1143	.1524	.1524	.1334	.1143	.1334
21	.1143	.1143	.1334	.1334	.1334	.1143	.1334
22	.0953	.0953	.1334	.1334	.1143	.0762	.0953
23	.0762	.0953	.0953	.0953	.0953	.0762	.0762
24	.0953	.0572	.0762	1.0829	.0762	.0953	.0762
Max	.1715	.1905	.1524	1.0829	.1715	.1715	.1629
Min	.0381	.0038	.0381	.0381	.0572	.0381	.0351
Avg	.0932	.0802	.0989	.1436	.1022	.0901	.0902



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014010 / 33/11 KV RANGANGAON

Feeder No / Name : 205 / 11kv GOPAJIBABA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.2667	.2286	.2286	.2286	.2286
2	.2286	.3048	.2667	.2286	.2667	.2286	.2286
3	.2858	.3239	.3048	.3048	.2858	.2286	.2667
4	.3048	.3239	.3048	.3048	.2858	.2667	.3048
5	.3048	.3429	.3429	.3429		.3048	.3429
6	.381	.362	.381	.3429	.3239	.3239	.3048
12	.8951	.7865	.679	.8288	.7042	.7449	.7125
13		.7537	.7537	.6958	.5868		.5937
14		.6882	.6562	.6562	.5365		.4595
15	.7907	.5719	.5117	.6249	.5868		
16	.8642	.7362	.5117	.6882	.6299	.6478	.6173
17	.8855	.7362	.6874	.7625	.852	.6962	.679
18	.7316	.5401	.6097	.7545	.6249	.6642	.6001
19	.6401	.4428	.7125	.7377	.6958	.7956	.5716
20	.2286	.3429	.4191	.381	.381	.3048	.3001
21	.381	.381	.381	.4191	.381	.381	.3521
22	.3429	.381	.381	.4572	.362	.4001	.4254
23	.3048	.381	.3429	.362	.362	.3429	.4024
24	.3048	.2858	.2667	.2858	.2858	.2858	.2858
Max	.8951	.7865	.7537	.8288	.852	.7956	.7125
Min	.2286	.2858	.2667	.2286	.2286	.2286	.2286
Avg	.4766	.4825	.4621	.4951	.4655	.4278	.4264

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014010 / 33/11 KV RANGANGAON

Feeder No / Name : 206 / 11KV BAJARANG(KAKADI)

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9328	.8718	1.2384	.9339	.9526	.8573
2	.9526	1.0608	.9012	1.2384	.9667	.9526	.9526
3	.9526	1.1949	.8951	1.2696	1.0867	1.0479	1.0479
4	1.1203	1.2696	1.0174	1.2696	1.1568	1.1203	1.1317
5	1.1949	1.2883	1.065	1.3443	1.1919	1.1576	1.1694
6	1.4003	1.307	1.1469	1.4937	1.307	1.4003	1.587
7	1.9044	2.2822	2.4143	2.5149	2.4387	2.5463	1.6956
8	1.8671	2.1098	1.9839	1.6644	2.1529	2.3577	1.9978
14					.1524		
15					.1524		
16					.1524		
17					.1905		
18	.1286	.2667	.0762	.1457	.1905	.1715	.1286
19	.2804	.381	.373	.2294	.2229	.2286	.2258
20	.3144	.4191	.3353	.2932	.3353	.3048	.2709
21	.3858	.4572	.3647	.3227	.3391	.381	.3311
22	.3429	.4191	.2858	.3001	.2778	.4191	.381
23	.3144	.4001	.2572	.2429	.2164	.4572	.3429
24	.7468	.9054	.6173	1.0829	.9012	.8589	.7373
Max	1.9044	2.2822	2.4143	2.5149	2.4387	2.5463	1.9978
Min	.1286	.2667	.0762	.1457	.1524	.1715	.1286
Avg	.8509	.9796	.8403	.9767	.7561	.9571	.8571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 201 / Dwarka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.8484	1.7918	1.5466	1.8861	1.6598	1.8484
2	1.4712	1.6975	1.6598	1.4901	1.7918	1.6598	1.7353
3	1.4712	1.6032	1.5089	1.6032	1.6975	1.6975	1.6598
4	1.5089	1.7353	1.6289	1.6975	1.8484	1.7737	1.8484
5	1.6221	1.8484	1.7194	1.8107	2.0748	1.8861	1.9239
6	1.8861	1.9239	1.9805	1.9805	2.2257	2.1502	2.037
7	2.0936	2.0748	2.2257	2.2068	2.3577	2.3011	2.0936
8	2.2445	2.2068	2.2445	2.2822	2.4143	2.1691	2.2257
9	2.2822	2.0748	2.2405	2.3388	2.7161	2.0748	2.2445
10	2.2257	2.1691	2.2218	2.3011	2.6595	2.037	2.32
11	2.1879	2.2068	2.0351	2.1691	2.6217		2.3954
12	2.2257	1.9616	2.0911	2.3011	2.6972		2.3388
13	2.2445	1.9616	2.1472	2.452	2.7538	2.4143	2.32
14	2.1125	1.9239	2.2779	2.452	2.4897	2.3011	2.2634
15	2.037	1.9427	2.2032	2.6406	2.3011	2.0748	2.3011
16	2.1313	2.1313	2.3152	2.2257	2.452	2.037	2.2634
17	2.2257	2.2445	2.3577	2.2822	2.6029	2.4331	2.2634
18	2.3777	2.2068	2.4331	2.3011	2.6406	2.4331	2.2445
19	2.5274	2.6406	2.8669	3.2065	2.8481	2.6029	2.6783
20	2.452	2.5652	2.7349	2.999	2.5463	2.452	2.6783
21	2.4143	2.4143	2.6217	2.8669	2.5463	2.2257	2.6029
22	2.2634	2.3011	2.3954	2.6406	2.3594	2.2257	2.4331
23	2.1125	1.8484	1.957	2.452	1.8673	2.0748	2.037
24	1.5844	1.8656	1.6032	1.6975	2.0748	1.6598	1.8861
Max	2.5274	2.6406	2.8669	3.2065	2.8481	2.6029	2.6783
Min	1.4712	1.6032	1.5089	1.4901	1.6975	1.6598	1.6598
Avg	2.0504	2.0582	2.1359	2.2477	2.3530	2.1065	2.1934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 202 / Shriram

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.4632	1.1888	1.2136	1.4632	1.1871	1.4632
2	1.0642	1.3717	1.0974	1.1203	1.3717	1.1888	1.4266
3	1.0829	1.3169	1.0425	1.1949	1.2437	1.2136	1.3717
4	1.1949	1.4266	1.1706	1.307	1.4266	1.307	1.4998
5	1.3443	1.6095	1.3169	1.4377	1.6095	1.4377	1.6827
6	1.7177	1.7375	1.6827	1.6991	1.6461	1.7737	1.8656
7	1.9605	1.8656	1.8839	2.0698	1.7375	1.9978	1.9753
8	2.2177	2.1033	2.1582	2.1807	2.1582	2.1992	2.2862
9	2.0513	2.0485	2.0851	1.9589	2.1582	2.1253	2.1582
10	1.957	2.0119	2.0668	1.9404	2.1033		1.957
11	1.8839	1.7375	1.957	1.7556	2.0485	2.1582	2.1216
12	1.8107	1.7558	1.7924	1.848	1.9387	2.1582	1.8107
13	1.701	1.701	1.6827	1.885	1.8473	2.0851	1.8473
14	1.6278	1.5546	1.5546	1.4815	1.701	2.0119	1.701
15	1.4815	1.4632	1.4266	1.6032	1.5364	1.7924	1.6278
16	1.5912	1.6095	1.7558	1.7193	1.6827	1.6827	1.8107
17	1.6278	1.701	1.6827	1.9753	1.9204	1.829	1.6644
18	1.829	1.7375	1.8839	1.8839	1.9204	1.957	1.701
19	1.9204	1.9204	1.9959	2.1879	1.9936	2.0119	2.1582
20	1.848	1.7556	1.848	1.8473	2.7069	1.8656	1.9936
21	1.7556	1.7002	1.8111	1.7924	2.7069	1.7924	1.8473
22	1.6461	1.6095	1.7741	1.6461	1.6827	1.6461	1.7924
23	1.6095	1.5546	1.46	1.6095	1.4632	1.6095	1.5546
24	.9054	1.5546	1.2986	1.2936	1.5546	1.3169	1.5546
Max	2.2177	2.1033	2.1582	2.1879	2.7069	2.1992	2.2862
Min	.9054	1.3169	1.0425	1.1203	1.2437	1.1871	1.3717
Avg	1.6229	1.6796	1.6507	1.6938	1.8176	1.7542	1.7863

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 203 / VIRBHADRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.587	2.0328	1.7187	1.6804	2.0328	1.9044	2.0119
2	1.5497	1.8111	1.5708	1.643	1.9404	1.8298	1.885
3	1.587	1.6632	1.5339	1.643	1.8111	1.8298	1.8111
4	1.6804	1.7556	1.6632	1.7551	2.0698	1.9605	1.9959
5	1.7924	1.848	1.7737	1.9978	2.1807	2.0538	2.1253
6	2.2032	2.1992	2.1807	2.3339	2.3101	2.3899	2.1807
7	2.4646	2.4025	2.5318	2.6886	2.7351	2.7536	2.3228
8	2.5318	2.6427	2.4874	2.7446	2.9569	2.1691	2.4579
9	2.384	2.5873	2.7166	2.652	2.8275	2.0748	2.347
10	2.4025	2.5503	2.5688	2.6886	2.7536		2.4949
11	2.2731	2.1437	2.4579	2.5972	2.5873	2.5873	2.6155
12	2.2177	2.3101	2.1992	2.3411	2.4949	2.5503	2.2546
13	2.2361	2.3285	2.1068	2.2497	2.2177	2.4394	2.1437
14	2.1992	2.1807	2.0698	2.2731	2.2731	2.2546	2.1622
15	2.1992	2.2177	2.0328	2.2731	2.4025	2.1253	2.1437
16	2.3285	2.3285	2.0698	2.1948	2.2916	2.1807	2.0328
17	2.4025	2.2497	2.4691	2.5972	2.4394	2.2546	2.0513
18		2.5057	2.4331	2.8166	2.6242	2.4579	2.4394
19	2.9754	2.8166	2.7984	2.963	2.9569	2.6029	2.9754
20	2.9235	2.5873	2.5606	2.7618	2.7536	2.6797	2.7166
21	2.809	2.4949	2.3777	2.6242	2.4874	2.5873	2.6242
22	2.6242	2.3285	2.3411	2.4394	2.4508	2.4394	2.4025
23	2.4394	2.2177	2.1472	2.2081	1.9978	2.2546	2.0725
24	1.7364	2.1582	1.9404	1.8665	2.1253	1.848	2.1807
Max	2.9754	2.8166	2.7984	2.963	2.9569	2.7536	2.9754
Min	1.5497	1.6632	1.5339	1.643	1.8111	1.8298	1.8111
Avg	2.2412	2.2650	2.1979	2.3347	2.4050	2.2708	2.2687

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 204 / STP Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0181	.0181	.0183	.0181	.0181	.0181
2	.0183	.0181	.0181	.0914	.0181	.0181	.0181
3	.0183	.0181	.0181	.0732	.0181	.0183	.0181
4	.0183	.0181	.0181	.0732	.0181	.0183	.0181
5	.0183	.0181	.0181	.0183	.0181	.0183	.0905
6	.0914	.0914	.1267	.0914	.1267	.0183	.1267
7	.0914	.1267	.1448	.128	.0905	.0549	.0905
8	.0183	.0181	.1086	.0732	.1629	.0914	.1086
9	.0183	.0543	.0905	.0183	.1267	.128	.0724
10	.0732	.0905	.0724	.0732	.0905		.0905
11	.1097	.1267	.0905	.128	.0905		.0724
12	.0905	.0905	.0724	.0914	.0905	.0724	.0905
13	.0724	.0905	.0905	.0732	.0905	.1086	.0905
14	.1086	.0724	.0905	.128	.0905	.0724	.1448
15	.0724	.0905	.0905	.0905	.0543	.0181	.0543
16	.0724	.0905	.0905	.0905	.0905	.1448	.0905
17	.128	.1829	.1097	.1086	.0181	.1629	.0183
18	.0905	.1097	.0183	.181	.1267	.0181	.0914
19	.0905	.0183	.0183	.0181	.1448	.0181	.0914
20	.0724	.0183	.0183	.0181	.0177	.0905	.0183
21	.0181	.0181	.0914	.0181	.0549	.0724	.0181
22	.0905	.0905	.0183	.0905	.0914	.0181	.0905
23	.0724	.0724	.0183	.0724	.0914	.0181	.0905
24	.0914	.0181	.0181	.0183	.0181	.0914	.0905
Max	.128	.1829	.1448	.181	.1629	.1629	.1448
Min	.0181	.0181	.0181	.0181	.0177	.0181	.0181
Avg	.0652	.0650	.0612	.0744	.0732	.0586	.0710

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 401 / Hotel Country Inns  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17
HR	Load (MW)
24	.5093
Max	.5093
Min	.5093
Avg	.5093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014106 / 33/11kv Astagaon S/Stn

Feeder No / Name : 201 / 11kv Renuka

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6133	.6908	.5967	.57	.7167	
2	.6062	.6722	.6036	.5636	.6979	
3	.6062	.6722	.5967	.5801	.7095	
4	.6554	.6908	.6133	.5967	.7282	
5	.663	.7655	.6226	.6062	.7468	
6		.7842				
7		.8029				
8		.6535				
9		.4475				
10		.285				
11		.285				
12	2.0891	1.7328	1.7695	1.7532	1.6876	1.8244
13	1.9109	1.5223	1.7695	1.6057	1.3927	1.5779
14	1.704	1.4091	1.4899	1.5746	1.2452	1.3599
15	1.4089	1.4089	1.3927	1.3094	1.3108	1.1043
16	1.7204	1.4746	1.4746	1.576	1.5384	1.4083
17	1.6712	1.5729	1.5546	1.4251	1.6004	1.4083
18	1.7736	1.5729		1.4922	1.4582	1.5223
19	1.7901	1.5729		1.7238	1.6004	1.6194
20	.7095	.7209		.7282	.7209	.679
21	.8029	.7042		.7842	.7293	.6602
22	.7468			.7468		.547
23	.7282			.7282		.547
24	.6133	.7095	.5967	.6203	.7095	
Max	2.0891	1.7328	1.7695	1.7532	1.6876	1.8244
Min	.6062	.285	.5967	.5636	.6979	.547
Avg	1.1563	.9614	1.0900	1.0547	1.0995	1.1882



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014106 / 33/11kv Astagaon S/Stn

Feeder No / Name : 202 / 11kv Saishakti

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0898	1.3077	1.326	1.3592	2.2119		
2	1.0774	1.358	1.3923	1.3592	2.2721		
3	1.2266	1.4083	1.4255	1.3927	2.3137		
4	1.278	1.6078	1.4586	1.4746	2.42		
5	1.3108	1.8515	1.491	1.5729	2.6355		
6	1.5402	2.17	1.8351	1.8461	2.6707		
7	1.8785	2.2565	2.4413	2.332	2.8018		
8	2.17	2.5911	2.9656	2.3967	3.0476		
9	2.1445	2.4939	2.672	2.4577	2.9473		2.1091
10		.2515					1.6716
11		.218					
12		.1823					
13		.1802					
14		.1802					
15		.1966					
16	.3361	.2155	.2429	.3361	.3277		.5415
17	.3361	.2652	.2915	.3361	.3605		.6722
18	.3921	.2984		.5601	.431		.6979
19	.5041	.4973		.6348			.7842
20	.4854	.4973		.5975	.57		.8215
21	.4668	.4527		.5601	.503		.7842
22	.4668			.5228			.7655
23	.4481			.5041			.6535
24	1.073	1.291	1.2742	1.2431	2.0233	1.4918	
Max	2.17	2.5911	2.9656	2.4577	3.0476	1.4918	2.1091
Min	.3361	.1802	.2429	.3361	.3277	1.4918	.5415
Avg	1.0125	.9896	1.568	1.1937	1.8357	1.4918	.9501

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014106 / 33/11kv Astagaon S/Stn

Feeder No / Name : 204 / 11kv Mothe Baba

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5967	.6783	.663	.663	.7716	
2	.5967	.7291		.663	.7888	
3	.663	.7291	.6962	.7293	.823	
4	.6554	.7969	.7373	.852	.8478	
5	.6882	.9054	.7701	.9175	.8817	
6	.8192	1.0227	.852	1.085	1.2266	
7	.9503	1.094	1.2289	1.2146	1.3592	
8	1.2793	1.3923	1.3765	1.5546	1.5893	
9	1.1797	1.1633	1.2793	1.3435	1.3603	1.6324
10		.1509				1.1469
11		.1509				
12		.1475				
13		.1147				
14		.0983				
15		.0995				
16	.2054	.0995	.1311	.2054	.1802	.2427
17	.2054	.116	.1619	.1867	.1802	.2614
18	.2987	.1326		.2614	.2155	.3361
19	.3547	.2818		.3547	.3149	.3547
20	.3174	.3353		.3547	.3353	.3961
21	.2801	.3018		.3361	.3018	.3961
22	.2427			.2987		.3961
23	.2427			.2614		.3584
24	.5868	.6443	.6036	.5967	.7545	
Max	1.2793	1.3923	1.3765	1.5546	1.5893	1.6324
Min	.2054	.0983	.1311	.1867	.1802	.2427
Avg	.5646	.5084	.7727	.6599	.7457	.5521

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 202 / 11 KV NILWANDE FEEDER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2058		
24	.2743		.2058	.1715
Max	.2743	.2058	.2058	.1715
Min	.2743	.2058	.2058	.1715
Avg	.2743	.2058	.2058	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 203 / 11 KV SHENDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5818	3.4675	3.4675	3.2769	3.315	3.2769	3.0483
2	3.5818	3.4675	3.5437	3.315	3.3532	3.2769	3.0102
3	3.5818	3.5056	3.4675	3.4294	3.4675	3.5056	3.0102
4	3.5437	3.4675	3.3913	3.4294	3.3913	3.3913	3.0102
5	3.5437	3.5056	3.315	3.1626	3.315	3.3532	2.9721
6	3.7342	3.658	3.5437	3.1626	3.4294	3.5056	3.3913
7	4.0771	4.1152	4.0771	3.7342	3.8866	3.8866	3.9247
8	3.8866	3.7342	4.6487	3.2388	3.3913	3.5056	3.3913
9	3.4294	3.0102	2.934	2.7816	2.8578	2.8578	2.7435
10	5.2584	4.2676	4.6106	4.8392	3.2769	4.1533	4.382
11	***	***	***	***	***	9.1831	9.7927
12	5.2965	***	9.8308	***	***	9.0688	***
13	9.5641	***	9.526	***	***	7.2779	9.907
14	***	***	8.6496	***	***	***	***
15	***	***	8.802	***	***	9.907	***
16	***	***	8.6115	***	***	***	***
17	***	***	9.2974	***	***	***	***
18	8.8782	***	***	***	***	***	***
19	4.2676	4.2676	4.0009	3.658	4.1533	3.6199	3.7723
20	4.9154	5.1821	5.144	5.0297	5.6394	4.7249	5.144
21	4.8773	5.0678	5.144	4.9154	4.8011	4.8392	5.144
22	4.763	4.8011	4.9916	4.3439	4.382	4.6106	4.6106
23	4.2676	4.3058	4.4582	3.8104	3.7342	4.2295	4.1533
24	3.5818	4.2372	3.2769	4.0772	3.8599	3.1245	3.2769
Max	12.1552	12.079	11.0883	11.9266	12.079	10.6691	10.8596
Min	3.4294	3.0102	2.934	2.7816	2.8578	2.8578	2.7435
Avg	6.0522	6.3780	5.8569	6.2602	6.3940	5.7156	5.8775

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 204 / 11 KV AMBIT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	***	2.3624	***	***	***	***
2	2.0576	***	2.3624	***	***	***	***
3	2.0576	1.9433	1.9814	3.6961	1.9814	1.9814	2.0195
4	2.0576	1.9052	1.9433	2.0195	2.0195	2.0195	2.0195
5	2.0957	2.0195	2.0195	2.0957	2.0957	2.0576	2.0957
6	2.2481	2.1719	2.3624	2.3243	2.2481	2.21	2.2862
7	2.4768	2.4768	2.553	2.4768	2.2862	2.3243	2.4006
8	2.21	2.1338	1.8671	2.1719	2.2862	2.0576	2.0957
9	1.6766	1.7147		1.9433	1.7147	1.6385	1.9052
10	1.7909	1.6004	.6859	1.8671	1.7147	1.4861	1.6004
11	1.0288	1.2955	1.6004	1.5623	1.5242	1.4098	1.3717
12	1.1812	1.1812	1.5242	1.3336	1.2955	1.1812	1.1812
13	1.1431	1.0288	1.3717	1.3336	1.2193	1.0669	
14	1.105	1.2574	1.2955	1.2574	1.0669	1.0288	.9526
15	1.1812	1.4098	1.3717	1.2193	1.2955	.9907	1.1431
16	1.105	1.3717	1.3717	1.105	1.2193	1.0288	1.105
17	1.0669	1.448	1.2955	1.1431	1.1812	1.105	1.1431
18	3.8866	4.763	5.0678	1.9052	5.1821	4.0771	2.7054
19	***	***	***	***	3.4294	***	***
20	***	***	***	***	4.5344	***	***
21	***	3.8485	***	***	***	***	.0762
22	***	3.0102	***	***	***	***	.3048
23	***	2.7435	***	***	***	***	.2286
24	***	2.995	***	***	***	***	.4954
Max	14.1366	14.7462	13.565	14.3652	14.8224	14.4795	12.3076
Min	1.0288	1.0288	.6859	1.105	1.0669	.9907	.0762
Avg	4.6661	3.8622	4.8707	5.5735	4.7376	5.3187	3.2256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 205 / 11 KV RAJUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4115		
24	.3086		.3429	.4115
Max	.3086	.4115	.3429	.4115
Min	.3086	.4115	.3429	.4115
Avg	.3086	.4115	.3429	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 206 / 11 KV PIMPARKANE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0686		
24	.0686		.0686	.0686
Max	.0686	.0686	.0686	.0686
Min	.0686	.0686	.0686	.0686
Avg	.0686	.0686	.0686	.0686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 207 / Vitha GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2058		
24	.1372		.1372	.1029
Max	.1372	.2058	.1372	.1029
Min	.1372	.2058	.1372	.1029
Avg	.1372	.2058	.1372	.1029



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 209 / 11 KV SANGAMNER EXPRESS NON SHEDDABLE WATER SUPPLY AND  
WATER Feeder KV- 11 / INCOMING UTILITY

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.1029		
24	.1029		.1029	.1029
Max	.1029	.1029	.1029	.1029
Min	.1029	.1029	.1029	.1029
Avg	.1029	.1029	.1029	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 202 / 11 KV DHAMANGAON PAT  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2058		
2				.2401	.1886	
3				1.8861		
4				1.9719		
5		1.8861		1.989		
6		1.9204		2.1605		
7		2.3834		2.5377		
8		2.6578		2.8292	1.3717	
9				2.7606	2.0233	
10		2.8121		2.3834	2.0576	
11				.2401		.1715
12				.1543		
13				.1886	.12	
14				.1715	.1372	
15				.1543	.1372	
16				.1543	.2058	
17			.2058	.1715	.1715	
18					.1886	
22				.2229	.1886	
23	.2401	.2058		.2058	.1886	
24		.1886	.1715	.2058	.1886	.1715
Max	.2401	2.8121	.2058	2.8292	2.0576	.1715
Min	.2401	.1886	.1715	.1543	.12	.1715
Avg	.2401	1.7220	.1887	1.0417	.5513	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 203 / 11 KV KOTUL -R-

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.4006	
2				2.332	2.1948
3				.2229	
4				.2401	.2743
5				.2572	
6				.3258	.3086
7				.2743	
8		.2743		.2743	
9				.2058	
10		.3258		.4287	.2401
11				.1715	
12				.0514	
13				.0514	.1543
14				.0514	.2743
15				.0514	.2572
16				.0514	.2058
17			.1372		.1543
23	2.3491				
24		2.3491		2.4348	
Max	2.3491	2.3491	.1372	2.4348	2.1948
Min	2.3491	.2743	.1372	.0514	.1543
Avg	2.3491	.9831	.1372	.5779	.4515

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 204 / NACHANTHAV

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7373		
2				.6859	.9431	
3				.2572		
4				.2401		
5		.2401			.2572	
6		.2743				
7		.3086		.3086		
8		.2743				
9				.1715	.2401	
10		.1886		.1543	.2229	
11				.1543		
12				.1372		
13				.1029	.1372	
14					.1543	
15					.1372	
16					.1372	
17			.1372		.1372	.12
18					.1543	
22				1.2346	1.3203	
23	.7888	.9088		1.0631	1.1145	
24		.7545	.8059	.7716	1.046	.9945
Max	.7888	.9088	.8059	1.2346	1.3203	.9945
Min	.7888	.1886	.1372	.1029	.1372	.12
Avg	.7888	.4213	.4716	.4630	.4617	.5573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 205 / DHAMANGAONPAT GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.2915	.2401	
3				.2401		
4				.2743		
5		.3429			.3429	
9		.3258			.3429	
10		.2915			.3258	
11					.2058	
12					.1715	
13					.1715	
14					.1372	
15					.2058	
16				.1029	.1543	
17			.1886		.1715	
18					.2229	
22				.2743	.3772	
23	.3086	.2743		.2743	.2743	
24		.2572	.2401	.2058	.2401	.2058
Max	.3086	.3429	.2401	.2915	.3772	.2058
Min	.3086	.2572	.1886	.1029	.1372	.2058
Avg	.3086	.2983	.2144	.2376	.2389	.2058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 206 / AMBHOL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1715		
2				.1715	.2401	
3				.1715		
4				.1886		
5		.2229			.3258	
6		.2401				
7		.2572				
8		.2743			.2915	
10		.2401			.2915	
11				2.6406		
12				2.7949		
13				2.692	2.4691	
14				2.6578	2.4006	
15				2.6578	2.0233	
16				2.6578	2.2805	
17			2.5377		2.3148	
18					2.3148	
22				.2401	.2229	
23	.2572	.2058		.2572	.2229	
24		.1886	.1886	.2058	.2229	.1886
Max	.2572	.2743	2.5377	2.7949	2.4691	.1886
Min	.2572	.1886	.1886	.1715	.2229	.1886
Avg	.2572	.2327	1.3632	1.3467	1.2016	.1886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 207 / ABIT KHIND

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.463		
2				.4115	.4115	
3				.4115		
4				.4115	.4287	
5		.4115				
6		.5487			.5487	
7		.6344				
8		.4801			.4973	
10		.3258			.3258	
13					1.0802	
15					.6173	
16				1.0802	.8745	
17			1.0288		.8745	
18					.9602	
22				.5316	.4973	
23	.4115	.4287		.463	.4458	
24		.3944	.4115	.4115	.4287	.4115
Max	.4115	.6344	1.0288	1.0802	1.0802	.4115
Min	.4115	.3258	.4115	.4115	.3258	.4115
Avg	.4115	.4605	.7202	.5230	.6147	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014093 / 33/11 KV KOHANE

Feeder No / Name : 203 / 11 KV MECHKARWADI AG

SINGLE PHASING

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0566	.0566	.0566	.0377	.0381	.0381
2	.6173	.0566	.0566	.0566	.0377	.0381	.0381
3	.6173	.6001	.6001	.6203	.6874	.6687	.5658
4	.6516	.6001	.6516	.6706	.7545	.7373	.583
5	.6687	.6344	.6859	.8048	.8048	.8402	.6344
6	.6952	.7545	.8402	.8551	.8551	.8916	.6687
7	.7122	.9602	.9602	.9556	1.073		.7888
8	.9221	1.1145	.9602	1.0898	1.1568		1.0004
9	1.0117	1.0631	1.0288	1.2574	1.1736		1.0174
10	.9774	1.0631	1.046	1.1904	1.1233	1.0288	.9259
11	.0189	.0189	.0189	.0189	.0189		.0191
12	.0189	.0189	.0189	.0189	.0191	.0381	.0191
13	.0189	.0189	.0189	.0189	.0381		.0191
14	.0189	.0189	.0189	.0189	.0381	.0191	.0191
15	.0189	.0189	.0189		.0381		.0191
16	.0189	.0189	.0189		.0381	.0191	.0191
17	.0189	.0189	.0189	.0189	.0381		.0191
18	.0189	.0189	.0189	.0189	.0572	.0381	.0191
19	.0754	.0754	.0754	.0189			
20	.0943		.0943	.0189	.0572	.0762	
21	.0943	.0754	.0943	.0189	.0572		.0572
22	.0754	.0754	.0566	.0189	.0572	.0572	.0572
23	.0566	.0566	.0566	.0377	.0572		.0572
24	.7373	.0566	.0566	.0566	.0377	.0381	.0572
Max	1.0117	1.1145	1.046	1.2574	1.1736	1.0288	1.0174
Min	.0189	.0189	.0189	.0189	.0189	.0191	.0191
Avg	.3423	.3215	.3113	.3564	.3590	.3235	.3019



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014097 / 33/11 KV SHENDI

Feeder No / Name : 201 / 11 KV DEVGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3772	.3086	.3601	.3086
2	.3086	.3086	.3601	.3086	.3601	.3258
3	.7716	.823	.8573	.8573	.8059	.7716
4	.8573	.8573	.8573	.9259	.8402	.8573
5	.9945	.9602	.9774	.9945	.9088	.9259
6	1.0288	1.0974	1.2517	1.0631	1.3203	.9945
7	1.0974	1.2003	1.3889	1.0288	1.4575	1.0631
8	1.1145	1.3032	1.3889	1.1145	1.5261	1.1145
9	1.1317	1.2517	1.286	.5487	1.4746	1.2003
10	1.166	1.046	1.2003	.8573	1.4403	1.2003
11	.3086	.3772	.3086	.3601	.3086	.3086
12	.3086	.4115	.3429	.3601	.3086	.2915
13	.2743	.4458		.3429	.2743	.3086
14	.3086	.4458	.2401	.3429	.3086	.3429
15	.3429	.4287		.3772	.3429	.3258
16	.3429	.4115		.4115	.3086	.3086
17	.3772	.3772		.3944	.3429	.3429
18	.4115	.3601	.3429	.3944	.3772	.3429
19	.4458	.4115	.3601	.4287	.4115	.3601
20	.463	.4115	.3772	.463	.4458	.3772
21	.4458	.4458	.3772	.4801	.4458	.3772
22	.4115	.4458	.3429	.4801	.4115	.3429
23	.3772	.4115	.3258	.4458	.3772	.3258
24	.3086	.3429	.3772	.3086	.4115	.2915
Max	1.166	1.3032	1.3889	1.1145	1.5261	1.2003
Min	.2743	.3086	.2401	.3086	.2743	.2915
Avg	.5794	.6201	.667	.5665	.6487	.5587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014097 / 33/11 KV SHENDI

Feeder No / Name : 202 / 11 KV GHATGHAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2743	.2743	.2915	.2915
2	.2915	.2743	.2743	.2915	.2743	.2743
3	.6859	.583	.4458	.7716	.4801	.6859
4	.7888	.6173	.4973	.823	.5144	.7545
5	.8573	.6173	.5487	.8573	.5658	.823
6	.9259	.6859	.7202	.9259	.7202	.7888
7	.9945	.7202	.823	.9431	.8402	.9431
8	1.0288	.6859	.8059	.9602	.8745	.9945
9	.9945	.6687	.8573	.4458	.7888	1.0631
10	.9602	.5487	.823	.5144	.7545	1.0631
11	.2743	.3086	.2743	.2915	.2743	.2915
12	.2743	.2915	.3086	.2915	.2743	.2743
13	.3086	.3086		.2743	.3086	.2743
14	.2743	.3086	.2915	.2743	.2743	.3086
15	.3086	.2915	.2743	.3086	.3086	.2915
16	.3086	.3086	.2915	.3086	.2743	.2743
17	.2743	.2915	.3086	.2915	.3086	.2915
18	.3086	.2915	.3086	.2915	.3429	.3086
19	.3429	.3086	.3429	.2743		.3258
20	.3772	.3258	.3429	.3086	.3772	.3429
21	.4115	.3429	.3601	.3258		.3429
22	.3772	.3258	.3258	.3429		.3258
23	.3086	.3086	.3086	.3258		.3086
24	.2915	.2743	.2915	.2915	.3086	.2572
Max	1.0288	.7202	.8573	.9602	.8745	1.0631
Min	.2743	.2743	.2743	.2743	.2743	.2572
Avg	.5101	.4151	.4391	.4587	.4578	.4958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014097 / 33/11 KV SHENDI

Feeder No / Name : 203 / 11 KV RATANWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3258	.3429	.3429	.3429
2	.3601	.3086	.3086	.3601	.3258	.3086
3	.3429	.3429	.3258	.3429	.3429	.3086
4	.3086	.3086	.3258	.3258	.3429	.3429
5	.3086	.3772	.3086	.3086	.3258	.3601
7		.3772				
8		.3429				
9		.3086				
10	.2743	.3258	.3772	.3429	.3086	.3429
11	1.2003	1.166	1.1145	1.2003	1.166	.9259
12	1.2689	1.3203	1.2003	1.4746	1.2003	1.1145
13	1.3032	1.4746		1.6118	1.2346	1.286
14	1.3032	1.6118	1.166	1.5775	1.2689	1.3032
15	1.3717	1.5089	1.1145	1.4403	1.3375	1.2689
16	1.3375	1.6118	1.0974	1.3717	1.3032	1.2003
17	1.3032	1.6289	1.1145	1.4746	1.3717	1.2003
18	1.3375	1.5432	1.0288	1.4403	1.406	1.1145
19	.3772	.3601	.3772	.3772	.3772	.3772
20	.4458	.3772	.4287	.4115	.4458	.4115
21	.4115	.3944	.4115	.4115	.4115	.4287
22	.3772	.3772	.3772	.4458	.3772	.4115
23	.3772	.3601	.3601	.4115	.3429	.4115
24	.3429	.3429	.3429	.3772	.3944	.3601
Max	1.3717	1.6289	1.2003	1.6118	1.406	1.3032
Min	.2743	.3086	.3086	.3086	.3086	.3086
Avg	.7347	.7425	.6371	.8025	.7313	.6910

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014097 / 33/11 KV SHENDI

Feeder No / Name : 204 / 11 KV S P Valley

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0514	.0514	.0514
2	.0514	.8745	.0514	.0514	.0514	.0514
3	.0514	.0514	.0514	.0514	.0514	.0514
4	.0514	.0514	.0514	.0514	.0514	.0514
5	.0514	.0514	.0514	.0514	.0514	.0514
6	.0514	.0514	.0514	.0514	.0514	.0514
7	.0514	.0343	.0343	.0343	.0514	.0343
8	.0343	.0343	.0343	.0343	.0514	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.0343	.0343	.0343
12	.0343	.0343	.0343	.0343	.0343	.0343
13	.0343	.0343		.0343	.0343	.0343
14	.0343	.0343	.0343	.0343	.0343	.0343
15	.0343	.0343	.0343	.0343	.0343	.0343
16	.0343	.0343	.0343	.0343	.0343	.0343
17	.0343	.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0514	.0343	.0343	.0343
19	.0514	.0514	.0514	.0514	.0343	.0514
20	.0514	.0514	.0514	.0514	.0343	.0514
21	.0514	.0514	.0514	.0514	.0514	.0514
22	.0514	.0514	.0514	.0514	.0514	.0514
23	.0514	.0514	.0514	.0514	.0514	.0514
24	.0514	.0514	.0514	.0514	.0514	.0514
Max	.0514	.8745	.0514	.0514	.0514	.0514
Min	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0436	.0771	.0440	.0429	.0429	.0429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014016 / 33/11 KV PIMPARNE SUB-STATION

Feeder No / Name : 201 / 11 KV Pimparne  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6344	2.6216	1.2056	2.2104	1.3352	1.3359	2.4645
2	2.7184	2.7268	1.2506	2.2325	1.3557	1.3527	2.4767
3	2.7716	2.6444	1.3077	2.308	1.4236	1.403	2.5331
4	3.0742	2.6582	1.3451	2.5613	1.4822	1.4114	2.6448
5	3.3359	3.0178	1.4373	2.806	1.5783	1.5562	3.056
6	3.9674	3.562	1.7535	3.434	1.8496	1.8831	3.6645
7	6.0051	4.4552	2.2573	3.8234	2.2337	2.3541	4.4715
8	5.9016	4.9306	2.9104	5.5799	3.1299	2.9797	5.9579
9	5.1304	5.7156	2.9439	3.0437	4.8103	3.1863	5.2362
10	.5776	.8672	.298	.3216	.6527	.2507	.5837
11		.311	.1898	.1738	.2934		.2134
12		.2592		.0023	.0511		.0069
13		.2316					
14		.2042					
15		.1936					
16		.186					
17		.1828					
18	.2896	.2134		.0396	.1257	.2546	.1059
19	.4786	.4482		.2301	.2111	.447	.1844
20	.5624	.5868	.532	.3109	.2987	.509	.2721
21	.5472	.5822	.5171	.3056	.2858	.5205	.2843
22	.5274	.5044	.4641	.2675	.266	.493	.2782
23	.4542	.442	.4013	.2202	.2256	.3765	.2492
24	3.1862	2.1932	1.1355	2.25	1.2422	1.3626	1.2094
Max	6.0051	5.7156	2.9439	5.5799	4.8103	3.1863	5.9579
Min	.2896	.1828	.1898	.0023	.0511	.2507	.0069
Avg	2.4801	1.6558	1.2468	1.6906	1.2027	1.2751	1.8891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014016 / 33/11 KV PIMPARNE SUB-

STATION

Feeder No / Name : 205 / Digras

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	15-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239		.362			.2743
2	.3239		.362			.2778
3	.3077		.362			.2778
4	.3113		.362			.2778
5	.3277		.3982			.3086
6	.3239		.3814			.3858
7	.4049		.4508			.3704
8	.4049					.2778
9				.3241		
10				.2469		.3086
11						.3086
12				2.3148		2.2531
13		2.6179		2.4383		
14		2.3739		2.284		
15		2.5095		2.4691		
16		2.3303		2.3148		
17		2.1914				
18		2.0833			2.1605	
19		1.8747			2.0062	
20		.724			.6173	
21		.6335			.6173	
22		.6335			.6173	
23		.543			.5401	
24	.3239		.362			.2778
Max	.4049	2.6179	.4508	2.4691	2.1605	2.2531
Min	.3077	.543	.362	.2469	.5401	.2743
Avg	.3391	1.6832	.3801	1.7703	1.0931	.4665

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014016 / 33/11 KV PIMPARNE SUB-STATION

Feeder No / Name : 206 / rayate gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195		.2172			.2195
2	.2195		.2172			.2195
3	.2195		.2172			.2195
4	.2195		.2172			.2715
5	.2743		.2715			.2896
6	.3658		.362			.3292
7	.439		.394			
8	.4344		.394			.4161
9				.4382		.3467
10				.2601		.3467
11				.2601		.2601
12				.2601		.2601
13		.2601		.2401		
14		.2601		.1734		
15		.1734		.1734		
16		.1734		.3467		
17		.208				
18		.3467			.2601	
19		.463			.4334	
20		.394			.4334	
21		.3582			.3506	
22		.2686			.2804	
23		.2149			.2629	
24	.2195		.2172			.2195
Max	.439	.463	.394	.4382	.4334	.4161
Min	.2195	.1734	.2172	.1734	.2601	.2195
Avg	.2901	.2837	.2786	.2690	.3368	.2832

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 201 / Chandanapuri

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.63	6.935	3.3532	3.5437	3.658	4.1496	3.6199
2	6.7826	7.4959	3.2769	3.4675	4.4704	4.2239	3.6961
3	6.7064	6.935	3.4675	3.3913	3.8485	4.2601	3.7342
4	6.8588	7.944	3.658	3.658	4.9009	4.2582	3.7723
5	7.697	8.5352	4.1152	4.1152	4.4201	4.8278	4.2676
6	9.526	***	6.2491	6.9593	6.0204	6.1404	5.7918
7	***	***	9.4117	9.4498	***	9.6403	***
8	***	***	***	***	***	***	***
9	9.2617	***	***	***	***	***	***
10	4.7058	5.0815	2.6535	2.6968	3.0079	2.1338	2.2481
11	4.1152	4.039	2.0195	2.6549	2.1338	1.5242	2.0576
15	2.0576	1.829	1.2574	1.448	1.6004	1.2574	1.3717
16	4.1914	4.1914	2.0576	2.6549	2.1719	2.1338	2.1338
17	4.3438	4.1152	2.0957	2.1338	2.6916	2.1338	2.1719
18	5.1272	4.1914	2.7907	2.8966	2.7297	2.21	2.8319
19	5.4108	5.487	2.7816	2.7435	3.2446	2.8578	2.7054
20	6.2586	5.3346	2.7816	3.7578	3.5559	2.8578	3.6793
21	5.3346	5.1822	2.553	2.7054	3.3856	2.553	2.6292
22	5.6223	4.8774	2.4006	3.1798	3.2008	2.4387	3.1337
23	4.5724	6.1728	2.553	2.6292	2.452	2.7054	2.3243
24	6.7826	7.3923	4.0009	3.8104	4.5153	4.2258	2.3624
Max	21.3891	24.2768	11.2788	13.786	13.9842	13.9479	12.6725
Min	2.0576	1.829	1.2574	1.448	1.6004	1.2574	1.3717
Avg	7.1023	8.0666	4.0824	4.4013	4.7084	4.4228	4.2616



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 202 / hiwargaon pawsa SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.7316	
2		.5182			.5487	.7468	
3						.7621	
4		.5792			.6097	.7773	
5						.7773	
6		.884		.8688	.9907	.9907	
7						1.4022	
8	1.6918	1.6766			1.6918	1.7985	
9	1.448			1.5851	1.7071	1.5089	1.7985
10	.1524	.2743	.2439	.2439	.2591	.2591	
11				.1981			.2286
13				2.9721			
16			.1524	.1524	.1524		.1677
17					.1829		
18	.2134		.1677	.1677	.1677		.2134
19					.2429		
20	.4572			.4115	.4372		.442
21					.4049		
22	.3506			.3353	.3506		.3658
23					.3201		
24		.5487			.6097	.7011	
Max	1.6918	1.6766	.2439	2.9721	1.7071	1.7985	1.7985
Min	.1524	.2743	.1524	.1524	.1524	.2591	.1677
Avg	.7189	.7468	.188	.7705	.5784	.9505	.536

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 203 / shirapur SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.5944	
2		.3963			.4877	.6249	
3						.6706	
4		.442			.5944	.7164	
5						.7621	
6		.8078		1.0059	1.0212	.8078	
7						1.387	
8	1.7071	1.5699			1.7528	1.6461	
9	1.3717			1.5242	1.2041	1.3108	1.7375
10	.1524	.1524	.1372	.2134	.1981	.1981	
11				.1524			.1372
16			.1067		.1219		.1677
17					.1829		
18	.1372		.1677	.1981	.1829		.1524
19					.2105		
20	.3048			.3048	.4372		.2439
21					.2915		
22	.2134			.2439	.2439		.2134
23					.2286		
24		.4268			.5182	.5639	
Max	1.7071	1.5699	.1677	1.5242	1.7528	1.6461	1.7375
Min	.1372	.1524	.1067	.1524	.1219	.1981	.1372
Avg	.6478	.6325	.1372	.5204	.5117	.8438	.4420

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 204 / zole SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.5335	
2		.5182			.4877	.5487	
3						.5792	
4		.5944			.5639	.5944	
5						.6097	
6		.9907		.8993	.945	.9602	
10		.6401	.6554		.7164	.5944	
11							.5639
12			3.0483	2.9264	3.1398	3.155	
13					3.155		3.0483
14			2.7435				
15					2.271		2.5149
16			3.0178		2.6368		2.9721
17					2.9111		
18	3.0483		2.8197	3.3227			2.8654
19					2.5911		
20	.7164			.7773	.7449		.7316
21					.7287		
22	.7011			.6706	.6401		.6706
23					.5944		
24		.5487			.5182	.5182	
Max	3.0483	.9907	3.0483	3.3227	3.155	3.155	3.0483
Min	.7011	.5182	.6554	.6706	.4877	.5182	.5639
Avg	1.4886	.6584	2.4569	1.7193	1.5096	.8993	1.9095

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 205 / channapuri gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1715	
2		.2195			.1524	.1715	
3						.1715	
4		.1334			.1715	.1867	
5						.1867	
6		.1524		.1524		.168	
7						.1524	
8	.2096	.1905				.181	
9	.2096			.1715	.1715	.1524	.2096
10	.1524	.1143	.1372	.1143	.1334		
11				.1334			.1715
12			.1715	.1143	.1524		
13					.0572		.1524
14			.1143				
15					.1524		.1143
16							.1524
17					.1905		
18	.1715		.1715		.2096		.1715
19					.2452		
20	.3239			.2667	.2896		.2667
21					.2263		
22	.2667			.2286	.2286		.1715
23					.2096		
24		.2096			.1715	.0191	
Max	.3239	.2195	.1715	.2667	.2896	.1867	.2667
Min	.1524	.1143	.1143	.1143	.0572	.0191	.1143
Avg	.2223	.1700	.1486	.1687	.1841	.1561	.1762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 207 / Savargaon Tal

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2534	
2					.2241		
3						.2715	
4		.2926			.2987	.3258	
5						.3429	
6		.4755		.4481		.4458	
10	.2172	.2957		.3395	.2835		
11				.3772			.2172
12			2.0576	2.0576	2.0687		
13					1.5384		1.9109
14			1.9765				
15					1.4232		1.3279
16			1.7337				1.8785
17					2.0645		
18	2.1365		1.8442	1.9765	1.7185		1.8861
19					1.5546		
20	.4115			.2743	.3841		.3772
21					.3982		
22	.3258			.2743			.3086
23					.3018		
24		.2401	.2401		.4435	.2534	
Max	2.1365	.4755	2.0576	2.0576	2.0687	.4458	1.9109
Min	.2172	.2401	.2401	.2743	.2241	.2534	.2172
Avg	.7728	.3260	1.5704	.8211	.9771	.3155	1.1295

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 205 / Vadzari Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.061		.0686	.061	
2					.0686	.061	
3					.0686	.0457	
4					.0857	.061	
5			.0914		.1067	.0914	
6			.1219		.1372	.1219	
7			.1829		.1524	.1677	
8			.0914		.1524	.1067	
9	.1524	.1543	.0914			.1219	.1219
10	.1219	.1029	.0857			.1029	
11		.0686	.0686			.0686	
12			.0343			.0343	
13			.0343			.0343	
14			.0343				
15			.0343				
16			.0514				
17				.0343	.061		
18				.0686	.061		
19		.1067			.1372		
20		.1219		.1219	.1219		
21		.0762		.1067	.0914		
22		.0762		.0762	.0762		
23		.061		.0762	.061		
24			.061		.0686	.061	
Max	.1524	.1543	.1829	.1219	.1524	.1677	.1219
Min	.1219	.061	.0343	.0343	.061	.0343	.1219
Avg	.1372	.0960	.0746	.0807	.0949	.0814	.1219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 207 / vadzari 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572		.1219	.2743
2				.1067	.2743
3				.1067	.2572
4				.1219	.2743
5		.3086		.1219	.3086
6		.3601		.1372	.3429
12		.9907			
13		.9431			
14		.7926			
15		.8383			
16		.6097			
17				.9755	
18				.9907	
19	.8688			.9755	
20	.2743		.1829	.3258	
21	.3258		.1677	.3258	
22	.3258		.1829	.3429	
23	.2915		.1829	.2915	
24		.2572		.1677	.2743
Max	.8688	.9907	.1829	.9907	.3429
Min	.2743	.2572	.1677	.1067	.2572
Avg	.4172	.5953	.1791	.3651	.2866

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 208 / CHINCHOLI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4287		.4801	.4458	
2					.4458	.4287	
3					.4458	.4287	
4					.4801	.4458	
5			.5658		.5487	.5487	
6			.7545		.7888	.7373	
7			.9602		.8535	.9088	
8			.8383		.8535	.9088	
9	.8383	.8916	.9755			.9755	.884
10	.823	.6516	.7888				.6859
11	.6001	.6516	.583				
12		.5144	.583				
13			.4801				
14			.4801				
15			.5487				
16			.5144				
17		.4801		.3772	.5487		
18				.4801	.6687		
19		.8573		.7621	.8573		
20		.823		.7621	.7888		
21		.6173		.7202	.6859		
22		.5487		.583	.6173		
23		.4801		.5144	.4801		
24			.4458		.5144	.4458	
Max	.8383	.8916	.9755	.7621	.8573	.9755	.884
Min	.6001	.4801	.4287	.3772	.4458	.4287	.6859
Avg	.7538	.6516	.6391	.5999	.6286	.6274	.7850



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014019 / 33/11 KV JAWALE KADLAG

Feeder No / Name : 203 / Ganore

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953		.0953	.1143	.0953	
2				.0953		.0953	
3		.0953		.0953	.1143	.0953	
4				.0953		.0953	
5		.0953		.0953	.1143	.0953	
6		.1143		.0953	.1143	.1143	.5716
7		.1524		.1334	.1334	.1334	.9145
8				.1143	.1143	.1143	
9	.08	.0953	.0953	.1143	.0953		
10		.0762		.0953	.0762		
11		.0572	.0762	.0953	.0762		.0572
12		1.166	1.2193	1.2003	1.2574		
13		1.0631	1.2384		1.1431		
14		1.0288	1.0669		1.0669		
15		.9945	1.105		1.0288		
16			1.0098		1.0098		
17	1.0669		.9955	1.105	1.105		
18			.905	.9907	.9526		
19	.8954		.7762	.8573	.8764		
20	.1524		.1524	.1524			
21	.1334		.1334	.1334			
22			.1143				
23			.1143				.0953
24		.0953			.1143		
Max	1.0669	1.166	1.2384	1.2003	1.2574	.1334	.9145
Min	.08	.0572	.0762	.0953	.0762	.0953	.0572
Avg	.4656	.3945	.643	.3273	.5282	.1048	.4097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014019 / 33/11 KV JAWALE KADLAG

Feeder No / Name : 204 / JAWALE KADLAG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2477			.2477	.2667	
2						.2667	
3		.2477			.2477	.2667	
4						.2667	
5		.2858			.2667	.3048	
6		.381			.4001	.3048	1.6956
7		.5144			.5144	.4954	2.3815
8					.4572		
9	.3077	.381	.1905		.4191		
10	.2778	.3048			.381		
11	.2778	.3239	.2667				.3239
12	.2623	2.4082	2.915				
13	2.6235	2.4691	3.1245				
14	2.4691	2.4387	3.0102				
15		2.4082	2.9721				
16			2.9912				
17	3.0102		2.332	2.8578			
18			2.3015	2.8006			
19	2.6673		2.0557	2.4387			
20	.381		.381	.4382			
21	.4001		.3429	.362			
22			.3048				
23			.2477				.3048
24		.2667			.2477		
Max	3.0102	2.4691	3.1245	2.8578	.5144	.4954	2.3815
Min	.2623	.2477	.1905	.362	.2477	.2667	.3048
Avg	1.2677	.9752	1.6740	1.7795	.3535	.3103	1.1765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014019 / 33/11 KV JAWALE KADLAG

Feeder No / Name : 205 / JAWALE KADLAG GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953		.0953		.0953	
2						.0953	
3		.0953		.0953	.1143	.0953	
4				.0953		.0953	
5		.1143		.1143	.1334	.1143	
6		.1715		.1524	.1905	.1143	.1524
7		.2477		.2286	.2286	.2286	.1715
8				.1334	.1715	.1524	
9	.1543	.1905	.1905	.1715	.1905		
10		.1334		.1715	.1715		
11		.1143	.1143	.1334	.1524		.1334
12		.0953	.0762		.0953		
13		.0572	.0762		.0953		
14		.0572	.0762		.0953		
15		.0572	.0762		.0953		
16			.0953		.1143		
17	.1143		.0953	.0953	.1143		
18			.1524	.1334	.1524		
19	.1905		.2477	.1905	.1905		
20	.2286		.2096	.2286			
21	.1905		.1715	.1715			
22			.1334				
23			.0953				.1143
24		.0953			.1143		
Max	.2286	.2477	.2477	.2286	.2286	.2286	.1715
Min	.1143	.0572	.0762	.0953	.0953	.0953	.1143
Avg	.1756	.1173	.1293	.1474	.1423	.1239	.1429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014019 / 33/11 KV JAWALE KADLAG

Feeder No / Name : 207 / Chikani Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	1.2384	1.1431	1.0098	1.3336	1.3717	
2	.8383		1.1431	1.0098		1.3717	
3	1.0479	1.2765	1.1431	1.0098	1.3527	1.3717	
4	1.0479		1.1431	1.0098		1.3717	
5	1.105	1.3336	1.1431	1.2384	1.5242	1.5242	
6	1.3336	1.5623	1.5242	1.5432	1.848	1.9433	.3429
7	2.0957	2.572	2.6673	2.5339	2.8769	3.0864	.4191
8	2.7625		2.9721	2.915	2.7816		
9	.2591	1.2963	2.2862				
10	.2286	.3048					
11		.1905	.3429				.2286
12		.1334	.1905				
13		.1334	.1715				
14		.1334	.1715				
15		.1524	.1715				
16			.1905				
17	.1524		.1334	.1905			
18			.1905	.2477			
19	.3239		.381	.3429			
20	.4001		.4191	.4382			
21	.3429		.4001	.4191			
22			.3239				
23			.3048				.362
24	.8764	1.2765			1.2955		
Max	2.7625	2.572	2.9721	2.915	2.8769	3.0864	.4191
Min	.1524	.1334	.1334	.1905	1.2955	1.3717	.2286
Avg	.9241	.8926	.8435	1.0699	1.8589	1.7201	.3382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014096 / 33/11 KV NIMON SUB STATION

Feeder No / Name : 201 / 11 K V Pimpale  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
7	.6249		
16			.2641
23		.3961	
Max	.6249	.3961	.2641
Min	.6249	.3961	.2641
Avg	.6249	.3961	.2641

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014096 / 33/11 KV NIMON SUB STATION

Feeder No / Name : 202 / 11 K V Karhe

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
7	.2743		
16			.8573
23		.2058	
Max	.2743	.2058	.8573
Min	.2743	.2058	.8573
Avg	.2743	.2058	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014096 / 33/11 KV NIMON SUB STATION

Feeder No / Name : 204 / pimpale gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
7	.1715		
16			.0857
23		.0857	
Max	.1715	.0857	.0857
Min	.1715	.0857	.0857
Avg	.1715	.0857	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014096 / 33/11 KV NIMON SUB STATION

Feeder No / Name : 205 / palaskhede gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-FEB-17	17-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
7	.1372		
16			.3429
23		.0857	
Max	.1372	.0857	.3429
Min	.1372	.0857	.3429
Avg	.1372	.0857	.3429



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014105 / 33/11 KV PADMANAGAR

Feeder No / Name : 201 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.9149	.8871		.9335		.9055
12			.7682				.6767
16		.6447					
17	.8131	.7343		.7468			
20	.9709			.9997		1.0059	
24					.5544		
Max	.9709	.9149	.8871	.9997	.9335	1.0059	.9055
Min	.8131	.6447	.7682	.7468	.5544	1.0059	.6767
Avg	.892	.7646	.8277	.8733	.7440	1.0059	.7911

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014105 / 33/11 KV PADMANAGAR

Feeder No / Name : 202 / 11KV PRAVARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.3306	1.5581		1.4083		1.4118
12			1.2851				1.2048
16		.8916					
17	.9536	.8322		.9593			
20	1.2048			1.2986		1.1517	
24					.8775		
Max	1.2048	1.3306	1.5581	1.2986	1.4083	1.1517	1.4118
Min	.9536	.8322	1.2851	.9593	.8775	1.1517	1.2048
Avg	1.0792	1.0181	1.4216	1.1290	1.1429	1.1517	1.3083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014105 / 33/11 KV PADMANAGAR

Feeder No / Name : 401 / 33 KV TALEGAON &amp; HIWARGAON NON SHEDDABLE EHV INDUSTRIAL FEEDERS

SS Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		13.7494	11.0391		13.4259		10.691
12			11.6358				11.6855
16		11.785					
17	11.9342	12.0833		11.4369			
20	4.177			4.3261		4.2764	
24					5.7185		
Max	11.9342	13.7494	11.6358	11.4369	13.4259	4.2764	11.6855
Min	4.177	11.785	11.0391	4.3261	5.7185	4.2764	10.691
Avg	8.0556	12.5392	11.3375	7.8815	9.5722	4.2764	11.1883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014145 / 33/11 KV MIDC GHULEWADI

Feeder No / Name : 201 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115			.4908		.4075	
2	.4191	.3856	.3856	.4908	.2606	.4024	
3	.3688	.3978		.4477		.4024	.4115
4	.3772	.3812	.4144	.4115	.3201	.3467	
5	.4161	.431	.4334	.3772		.3944	
6	.543	.4527	.5731	.4508	.3637	.4525	
7	.6468	.6161	.5853	.4748	.4607	.5487	.5548
8	.7167	.5975	.6584	.3353		.7133	
9	.7922	.7545	.8775	.3052	.9054	.8488	.9431
10	.7922	.7922	1.0562	.2688	1.1694	1.1317	1.1694
11	.9335	1.0374	1.226	.2408	1.2071	1.2071	1.0374
12	1.0374	1.1317	1.2637	.2623	1.094	.5487	1.1317
13			.9242	.23	1.0374	1.1317	.9431
14	.8488	.9808	1.0751	.2092	1.0751		1.2071
15		1.2071	1.1883		1.1317	1.1949	1.2637
16	1.226	1.226	1.094		1.094		1.3014
17	1.1883	1.1883	1.1317	.217	1.094		1.2826
18	1.0751	1.2071	1.0562	.1951	1.0374	1.2449	
19		.9431	1.0185	.2012	1.0562		1.0185
20			.7733	.2462	.8488		.8215
21		.5281	.5544		.4904		.583
22			.5487		.4805		.5487
23	.5014	.4527	.5611	.2622	.4119	.4527	.5304
24	.7922	.4239	1.094	.4477	.2202	.439	.4119
Max	1.226	1.226	1.2637	.4908	1.2071	1.2449	1.3014
Min	.3688	.3812	.3856	.1951	.2202	.3467	.4115
Avg	.7270	.7567	.8406	.3282	.7879	.6981	.8918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014145 / 33/11 KV MIDC GHULEWADI

Feeder No / Name : 202 / 11 KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733			.8488		.8299	
2	.7167	.7545	.6413	.7922	.6979	.7922	
3	.7545			.7545		.7545	.6602
4	.679	.811	.7356	.7356	.7167	.7545	
5	.7282	.695	.7167	.6722		.6722	
6	.9431	.5434	.9431	.8488	.7356	.7545	
7	.9997	.7023	.9431	.6219	.9619	.9242	1.1506
8	.8865	.8215	.9054	.7545		.9054	
9	.9997	.7545	.811	.9808	.9431	.9709	1.0751
10	.9619	.9808	1.094	1.0751	1.1128	1.0498	.9431
11	.811	.9808	.9808	1.094	1.1317	1.1946	1.0374
12	1.1317	.8676	.9997	.7545	.811	1.1888	1.1317
13			.9431	.9431	.8676	1.0498	1.0374
14	.9242	.8299	.8488	.7733	.8676		.9997
15		.8676	1.0751	.9431	1.1317	1.0242	.9431
16	.9808	.7545	.811	.8676	1.0374		1.1883
17	.9997	.7356	.811	.9054	.9431		.9808
18	.8299	.7545	.7356	.6602	.8488		
19			.7545	.8299	.9619		
20			.7356	.7922	.8676	.8676	.9242
21		.6979	.7167		.8488		.8865
22			.7356		.7545		.8865
23	.7356	.6036	.6602	.7545	.7167	.7167	.7545
24	.7922	.7167	.5847	.811	.7545	.7545	.679
Max	1.1317	.9808	1.094	1.094	1.1317	1.1946	1.1883
Min	.679	.5434	.5847	.6219	.6979	.6722	.6602
Avg	.8693	.7707	.8265	.8279	.8855	.8944	.9549

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014145 / 33/11 KV MIDC GHULEWADI

Feeder No / Name : 203 / 11 KV MALDAD GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494			.1494		.1629	
2	.1463	.2054	.1791	.1494	.1991	.1463	
3	.1494			.1494		.1463	
4	.1509	.2054	.2195	.1433	.2195	.1463	
5	.1867	.2614	.2402	.1886		.1867	
6	.2614	.2614	.2957	.2241	.2402	.2218	
7	.3361	.2957	.3174	.2987	.2957	.2987	
8	.2957	.3582	.3142	.2896	.2804	.3077	
9	.2715	.2835	.2883	.2543	.2915	.2865	
10	.2427	.2658	.2683	.2458	.2629	.2915	
11		.2481	.2543	.2204	.2481	.2572	
12	.2149	.2058	.2401	.1949	.2012	.2401	1.1317
13	.2328		.2229	.1658	.2103	.2012	
14			.2035	.1509	.1844		
15	.2347		.2058	.1907	.1753	.2427	
16		.2481	.2427	.1886	.2204		
17	.2713	.2686	.2427		.2572		.2601
18	.2881	.3315	.2883	.1989	.3391		
19			.3641	.2804	.3467		
20			.3012				.3189
21		.2507	.2507		.2507		.2835
22			.2353		.2534		.2328
23	.2328	.1595	.1848	.2149	.2012		.2172
24	.1848	.1848	.1612	.1463	.1791	.181	
Max	.3361	.3582	.3641	.2987	.3467	.3077	1.1317
Min	.1463	.1595	.1612	.1433	.1753	.1463	.2172
Avg	.2264	.2521	.2509	.2022	.2428	.2211	.4074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014145 / 33/11 KV MIDC GHULEWADI

Feeder No / Name : 422 / 33 KV NIMON OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	1.3014		1.0631		.9568	
2	.6722	1.2574	.7888	1.0288	.9134	1.0745	
3	.6722			1.0802		1.0745	1.0402
4	.7356	1.1883	.9671	1.0208	1.0059	1.0517	
5	.8488	1.3014	1.1283	1.1568		1.2357	
6	1.1317	1.6975		1.6644	1.4752	1.5947	
7	1.4563	2.6029	2.5434	2.5434	2.6452	2.3908	2.2885
8	2.7349	3.6214	3.1539	3.3316		3.2322	
9	2.8841	2.9835	2.6852	2.9492	3.6008	2.7206	2.7846
10	.6224	.499	.5601	.6584		.2286	.5702
11		.4527	.679	.6224		.2263	
12	2.037	1.278	1.4403	1.5947	1.3889	1.0682	1.4243
13		1.3272	1.4586	1.2071	1.3735	.1457	1.3923
14	1.6409	1.0562	1.166	1.1523	.8333		.9145
15		1.0562	1.3923	1.2717	1.0682		.9145
16	1.9239	1.0442	1.4752	1.5947	1.3889		1.5729
17	2.037	1.5061	1.4586	.679	1.9033		1.7101
18	1.6975	1.5912	1.5089	1.5769	1.5947		1.5729
19		1.442	1.4712	1.6301	1.5947		
20			.9054	.8596	.9619	1.5604	.5658
21		.7042	.7842		.8402		.5093
22			.6653		.7207		.439
23	.7356	.6173	.5487	.7356	.5973		.2715
24	.7356	.6173	.6241	.9465	.7922	.9134	.9259
Max	2.8841	3.6214	3.1539	3.3316	3.6008	3.2322	2.7846
Min	.6224	.4527	.5487	.6224	.5973	.1457	.2715
Avg	1.3707	1.3879	1.3050	1.3803	1.3721	1.2983	1.1810

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 204 / 11 KV WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0484	3.0484	1.5242	1.5242		1.829
2	3.0484	3.0484	1.5242	1.5242		1.5242
3	3.0484	3.0484	1.5242	1.5242		1.5242
4	3.0484	3.0484	1.5242	1.5242		1.5242
5	3.0484		1.5242	1.5242	2.4387	
6	3.658		1.829	1.829	1.829	
7	4.8774		2.4387	2.4387	2.4387	
8	5.487		3.0483	3.0483	3.0483	
9	5.487		2.7435	3.0483	2.4387	
10	4.8774		2.4387	2.4387	2.4387	
11	4.8774		2.4387	2.4387	2.4387	
12	4.8774		2.4387		2.1338	
13	4.2676		2.1338		2.1338	
14	4.2676		2.1338		2.1338	
15	3.658	3.658	2.1338			
16	3.658	3.658	2.1338		1.5242	
17	3.658	4.2676	2.1338		2.1338	
18	4.2676	4.2676	2.4387		2.4387	
19	4.8774	4.8774	2.7435		2.4387	
20	5.487	5.487	3.0483		2.7435	
21	5.487	5.487	2.7435		2.7435	
22	4.8774	4.8774	2.4387		2.7435	
23	4.2676	4.2676	2.4387		2.4387	
24	3.658	3.658	2.1338		1.829	
Max	5.487	5.487	3.0483	3.0483	3.0483	1.829
Min	3.0484	3.0484	1.5242	1.5242	1.5242	1.5242
Avg	4.2423	4.0499	2.2355	2.0784	2.3424	1.6004



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 205 / MIRZAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.061	.0267	.061	.08	.0762	.08
2	.0762	.0152	.0305	.0762	.08	.0762	.08
3	.08	.0572	.0495	.0762	.0838	.08	.08
4	.08	.0762	.0762	.08	.0876	.0838	.0838
5	.0762	.08	.0305	.0838	.0876	.0838	.08
6	.061	.08	.0152	.0838	.0838	.0838	.08
12	1.1888	1.3832	1.4746	1.2193	1.2612	3.5017	3.5894
13	1.8785	1.8023	1.8557	1.6461	1.8671	1.8595	1.89
14	1.9852	1.829	1.848		1.8633	1.89	1.8976
15	1.989	1.8557	1.8595		1.8176	1.8442	1.8747
16	1.909	1.8747	1.8328	1.7795	1.8061	1.89	1.8557
17	1.8938	1.8747	1.8976	1.89	1.8366	1.9662	1.8823
18	1.8214	1.8595	1.8785	1.9547	1.8557	1.9776	1.8328
19	1.7985	1.8099	1.7756	1.9166	1.7756	1.8785	1.8061
20	1.8138	1.7642	1.8138	1.8633	1.7795	1.8519	1.8404
21	.0953	.0914	.1029	.1029	.0914	.1029	.1067
22	.0914	.0876	.1029	.0953	.0914	.0991	.1067
23	.0953	.0914	.1067	.0991	.0914	.1029	.1105
24	.0914	.0876	.0953	.0953	.0838	.0953	1.0631
Max	1.989	1.8747	1.8976	1.9547	1.8671	3.5017	3.5894
Min	.061	.0152	.0152	.061	.08	.0762	.08
Avg	.9001	.8832	.8880	.7719	.8802	1.0286	1.0705

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 201 / SAKUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1715			.1715
4		2.572			3.9438
6		3.9438			3.9438
8		3.9438			4.1152
9			3.9438		
19	.1715			.1715	
21				.1715	
23	.1715			.1715	
24		.1715			.1715
Max	.1715	3.9438	3.9438	.1715	4.1152
Min	.1715	.1715	3.9438	.1715	.1715
Avg	.1715	2.1605	3.9438	.1715	2.4692

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 202 / MANDAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		2.572		2.572
4		.1715		.1715
6				.1715
19	.1715		.1715	
21			2.7435	
23	.1715		2.7435	
24		.1715		2.7435
Max	.1715	2.572	2.7435	2.7435
Min	.1715	.1715	.1715	.1715
Avg	.1715	.9717	1.8862	1.4146

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 203 / RANKHAMB AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1715			.1715
4		.1715			.1715
6		.1715			.1715
8		.1715			
13			1.2003		
15			1.2003		
16			1.2003		
17	1.2003				
19	1.2003			.1715	
21				.1715	
23	.1715			.1715	
24		.1715			.1715
Max	1.2003	.1715	1.2003	.1715	.1715
Min	.1715	.1715	1.2003	.1715	.1715
Avg	.8574	.1715	1.2003	.1715	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 204 / JAMBUT AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1715			.1715
4		1.8861			3.0864
6		2.915			3.0864
8		.1715			
11			3.6008		
17	.1715				
19	.1715			.1715	
21				.1715	
23	.1715			.1715	
24		.1715			.1715
Max	.1715	2.915	3.6008	.1715	3.0864
Min	.1715	.1715	3.6008	.1715	.1715
Avg	.1715	1.0631	3.6008	.1715	1.6290

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 205 / KAUTHE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.8861		2.0576
4		.1715		.1715
6				.1715
8				.1715
19	.1715		.1715	
21			2.572	
23	.1715		.2572	
24		.1715		2.572
Max	.1715	1.8861	2.572	2.572
Min	.1715	.1715	.1715	.1715
Avg	.1715	.7430	1.0002	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 206 / 11 KV SAKUR G.F.S.S

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1715			.4287
5					.4287
6					.4287
8					.4287
9			.3429		
11			.3429		
13			.1715		
15			.1715		
17	.3429			.1715	
19	.3429			.3429	
21				.3429	
23	.1772			.3429	
24		.1715			.3429
Max	.3429	.1715	.3429	.3429	.4287
Min	.1772	.1715	.1715	.1715	.3429
Avg	.2877	.1715	.2572	.3001	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 208 / Jambut GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0343			.0857
4		.0343			.0857
6					.0857
8					.0857
9			.0857		
11			.0857		
13			.0343		
15			.0343		
16			.0343		
17	.0034			.0343	
19	.0343			.0514	
21				.0514	
23	.0343			.0857	
24		.0343			.0857
<b>Max</b>	<b>.0343</b>	<b>.0343</b>	<b>.0857</b>	<b>.0857</b>	<b>.0857</b>
<b>Min</b>	<b>.0034</b>	<b>.0343</b>	<b>.0343</b>	<b>.0343</b>	<b>.0857</b>
<b>Avg</b>	<b>.024</b>	<b>.0343</b>	<b>.0549</b>	<b>.0557</b>	<b>.0857</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 209 / Rankham GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1715			.1715
4		.1715			.1715
6		.1715			.1715
8		.1715			.1715
9			.1715		
11			.1715		
13			.1715		
15			.1715		
16			.1715		
17	.1715			.1715	
19	.1715			.1715	
21	.1715			.1715	
23	.1715			.1715	
24		.1715	.1715		.1715
Max	.1715	.1715	.1715	.1715	.1715
Min	.1715	.1715	.1715	.1715	.1715
Avg	.1715	.1715	.1715	.1715	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 210 / Jambut AG 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1715			.1715
4		.1715			
5					.1715
6		.1715			.1715
8		.1715			.1715
13			2.572		
15			2.572		
16			2.572		
17	2.7435			2.572	
19	2.7435			2.572	
21				.1715	
23	.1715			.1715	
24		.1715			.1715
Max	2.7435	.1715	2.572	2.572	.1715
Min	.1715	.1715	2.572	.1715	.1715
Avg	1.8862	.1715	2.572	1.3718	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 201 / SANGHVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4577	2.0119	
2		2.5911	2.0814	
3		2.6292	2.1582	
4		2.6101	2.2546	
5		2.8959	2.4025	
6		2.8387	2.4949	
7		2.8387	2.6063	
8		3.1055	2.5606	
17		.1086		.128
18		.1307		.128
19		.128		1.7741
20	.1715	.1848		.2012
21	.2286	.1663		.1829
22	.2096	.1478		.1478
23	.1715	.128		.128
24		.128		.1109
Max	.2286	3.1055	2.6063	1.7741
Min	.1715	.1086	2.0119	.1109
Avg	.1953	1.4431	2.3213	.3501

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 203 / NIMAJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1492		.1296	.2286	.1296	
2		.1457		.1134	.2477	.1147	
3		.1638		.116	.2667	.116	
4		.1966		.1619	.3429	.1311	
5		.2591		.1966	.381	.1619	
6		.3113		.3239	.4382	.2591	
7		.421		.4372	.362	.3725	
8		.3239		.2949	.381	.3401	
9					3.2579		3.7913
10	3.8866	4.1914	3.9057				
11	3.8104		3.9628				
12			3.8485				
14			3.5818				
15			3.3532				
16			3.3913				
17	.1147		.1147	.1334	.1134		.1147
18	.1457		.1296	.1524	.1147		.1134
19	.2753		.2429		.1147		.2915
20	.2429		.2591	.3048	.2429		.2785
21	.2105		.2486	.362			.2486
22	.1966		.2294	.3429	.1781		.2155
23	.1619		.1619	.3239	.1658		.1966
24	.1475		.1296	.1524	.1475		.1619
Max	3.8866	4.1914	3.9628	.4372	3.2579	.3725	3.7913
Min	.1147	.1457	.1147	.1134	.1134	.1147	.1134
Avg	.9192	.6847	1.6828	.2364	.4364	.2031	.6013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 205 / 11 KV SANGHVI G.F.S.S

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1097		.1086	.2477	.1267	
2		.1267		.1267	.2477	.1097	
3		.1294		.128	.2477	.128	
4		.1463		.1448	.2858	.1267	
5		.1848		.2012	.3239	.181	
6		.2561		.2743	.3239	.3292	
7		.3258		.3292	.3429		
8		.3077		.3801	.3239	.3841	
10	.2858	.2286					
14			.0953				
15			.0953				
16			.1334				
17	.128		.1646		.1267		.128
18	.128		.2534		.1829		.1646
19	.3258		.3658		.3292		.3326
20	.2534		.2715	.3429	.3142		.3292
21	.2195		.2218	.3048			.2195
22	.1629		.1663	.2477	.2172		.1478
23	.1448		.128	.2286	.1848		.1267
24	.1267		.1086		.1267		.1109
Max	.3258	.3258	.3658	.3801	.3429	.3841	.3326
Min	.1267	.1097	.0953	.1086	.1267	.1097	.1109
Avg	.1972	.2017	.1822	.2347	.2550	.1979	.1949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 206 / 11KV NIMAJ GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4927	.8749	.4679	.8137	.778	.7268	.3978
2	.4431	.7552	.4538	.7415	.7445	.7015	.3391
3	.3734	.6474	.3643	.6794	.7674	.6285	.2995
4	.3772	.676	.4039	.769	.8756	.6333	.3692
5	.4992	.8737	.5216	1.0054	.9412	.9753	.5445
6	.6927	1.1713	.7213	1.3041	1.1485	1.2491	.7442
7	.7476	1.4726	.8253	1.4889	1.3618	1.5352	.8234
8	.7716	1.6214	.8105	1.5297	1.491	1.4743	.836
9	.7583	.692	.7419	.7084	.7552	.7552	.7606
10	.6943	.6348	1.3953	.7232	.7118	.5746	.636
11	.5815	.4553	1.1565	.5773	.5472	.5117	.4435
12	.4607	.3917	.9751	.5022	.418	.4119	.3227
13	.3951	.3113	.4279	.3894	.4085	.4138	.3064
14	.3841	.3056	.8314	.333	.314	.3243	.322
15	.3639	.3056	.783	.4073	.3102	.3399	.2972
16	.3913	.3235	.7869	.3909	.362	.4203	.33
17	.8208	.3685	.9282	.3849	.7731	.4176	.7678
18	.8726	.4302	1.0002	.9087	1.0035	.4683	.8661
19	1.2125	.615	1.2731	.7213	1.3112	.7366	1.1816
20	1.2083	.6211	1.1961	1.1675	1.2674	.6775	1.2218
21	1.0826	.5605	1.1603	.9518	1.1191	.5685	1.0788
22	.9362	.4641	1.1153	.7952	.9648	.4771	.9547
23	.8991	.3738	.9787	.8097	.883	.4611	.8953
24	.9308	.4374	.9046	.4161	.7888	.4123	.8032
Max	1.2125	1.6214	1.3953	1.5297	1.491	1.5352	1.2218
Min	.3639	.3056	.3643	.333	.3102	.3243	.2972
Avg	.6829	.6410	.8426	.7716	.8352	.6623	.6476

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 204 / UMBARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3685	2.6673	2.2908	2.364	2.6216	2.4859	2.6901
2	2.3853	2.6734	2.2954	2.367	2.6383	2.4874	2.7603
3	2.3716	2.6551	2.3122	2.3777	2.6337	2.4661	2.7633
4	2.3731	2.649	2.3777	2.3838	2.588	2.5042	2.774
5	2.4387	2.7496	2.4326	2.4874	2.6368	2.5987	2.7694
6	2.5743	2.8852	2.6978	2.8243	2.9142	2.9325	3.0361
7	3.1169	3.4339	3.2754	3.4095	3.629	3.7144	3.9217
8	3.248	3.6031	3.3516	3.6961	3.8104	4.0863	3.9643
9	.9617	1.3032	1.1264	1.2361	1.8458	1.448	1.1629
15	.0076						
16				.003			
17	.0198			.0076			
18	.1951	.1661	.1905	.1219	.0457	.192	.0442
19	.4008	.2454	.2606	.2439	.2347	.2591	.2683
20	.2439	.2271	.2576	.2286	.2378	.2591	.2789
21	.2393	.2134	.2454	.2119	.2271	.2393	.2439
22	.218	.192	.2241	.1829	.1936	.2073	.2256
23	2.7039	2.2725	2.303	2.5956	2.4051	2.7237	.1936
24	2.7039	2.303	2.3579	2.6414	2.4646	2.7694	.1829
Max	3.248	3.6031	3.3516	3.6961	3.8104	4.0863	3.9643
Min	.0076	.1661	.1905	.003	.0457	.192	.0442
Avg	1.5872	1.8900	1.7499	1.6324	1.9454	1.9608	1.7050

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 205 / KANOLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1936	.2058	.2393	.2622	.2195	.2286	.2149
2	.1905	.2012	.2408	.2225	.218	.2332	.2134
3	.1981	.2073	.2423	.2134	.221	.2362	.2149
4	.0991	.0457	.2454	.2103	.2225	.2347	.2225
5			.2439	.2042			.2225
6				.2134			.2301
7				.0244			.0686
11	.3673		.0015		.0015	.6828	.2728
12	3.2876	3.3653	3.437	3.0087	2.7572	2.9843	5.0526
13	3.2968	3.3257	3.3425	3.1306	2.7724	3.0895	2.9935
14	3.0498	3.1276	3.3638	3.2053	2.899	1.5623	3.0895
15	3.2282	3.3867	3.2815	3.1093	3.03	2.8669	2.998
16	3.2968	3.5269	3.3943	3.0209	3.2282	3.0224	3.0758
17	3.3013	3.4126	3.2861	3.3623	3.0971	2.9462	3.1413
18	2.0698	3.1596	3.1215	3.1672	2.8548	2.838	2.2268
19	4.3248	2.8913	2.9203	2.9188	1.2437	2.742	2.7191
20	.3185	.3246	.3368	.3445	.3048	.2972	.3018
21	.2942	.3201	.3445	.3353	.3125	.3079	.3018
22	.2911	.3201	.3399	.3246	.3018	.2972	.2774
23	.2561	.2972	.3246	.3033	.2698	.2683	.5472
24	.218	.25	.2667	2.3194	.2301	.2271	1.8564
Max	4.3248	3.5269	3.437	3.3623	3.2282	3.0895	5.0526
Min	.0991	.0457	.0015	.0244	.0015	.2271	.0686
Avg	1.5712	1.6687	1.5249	1.4950	1.3436	1.3925	1.4400



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 206 / NIMGAONJALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1562	.1364	.1242	.1539	.1425	.1646
2	.1616	.1547	.1349	.1318	.1463	.1463	.1555
3	.1631	.1578	.1341	.1318	.1486	.1486	.1616
4	.0983	.0465	.1334	.1387	.1486	.1478	.1699
5			.1425	.1379			.1722
6				.1463			.1821
7				.0351			.0823
11	.0335	.1364	.1562	.2538	.0274	.0945	.003
12	2.3922	1.9502	2.4539	4.4772	2.4196	2.3739	3.3135
13	2.6513	1.9761	2.7168	2.6962	2.4326	2.3282	2.0713
14	2.5194	1.8176	2.6635	2.5918	2.3891	2.4844	2.0119
15	2.4737	1.813	2.3876	2.5636	2.3076	2.3754	1.9601
16	2.508	1.8747	2.5537	2.6612	2.3724	2.4935	1.9075
17	2.5202	1.7208	2.6116	2.6696	2.3952	2.3632	1.8846
18	2.4836	1.5943	2.5019	2.5309	2.3571	2.2725	1.8122
19	3.7833	.5159	2.2893	2.3411	2.0157	2.1803	1.7574
20	.2126	.2012	.1905	.2027	.1989	.1966	.1997
21	.2111	.1943	.1829	.1936	.2035	.1989	.2035
22	.1966	.1859	.1791	.2004	.1837	.1974	.1951
23	.1814	.1738	.1593	.1867	.1684	.1928	.2042
24	.1593	.1433	.128	.1593	.1417	.1684	.9084
Max	3.7833	1.9761	2.7168	4.4772	2.4326	2.4935	3.3135
Min	.0335	.0465	.128	.0351	.0274	.0945	.003
Avg	1.2729	.8229	1.1503	1.1702	1.1228	1.1392	.9296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 207 / PIMPRI LAUKI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
12		1.2803	
19	1.6644		
24			1.3336
Max	1.6644	1.2803	1.3336
Min	1.6644	1.2803	1.3336
Avg	1.6644	1.2803	1.3336

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 209 / 11 KV NIMGAONJALI G.F. S.S

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3216	.3304	.3288	.3243	.3563	.3403	.3643
2	.3113	.3128	.3197	.3117	.3349	.3319	.3422
3	.3109	.3132	.3197	.314	.3346	.3353	.3372
4	.3125	.3231	.3296	.3151	.3406	.3414	.3406
5	.3528	.3719	.3666	.3692	.378	.3845	.3784
6	.498	.4877	.4733	.4816	.4816	.4957	.4885
7	.6642	.6264	.6763	.6973	.652	.6329	.655
8	.6763	.7484	.7205	.7247	.7095	.6302	.652
9	.6238	.6813	.6539	.628	.6946	.6139	.5902
10	.5868	.6032	.562	.5681	.6474	.5544	.5053
11	.4603	.4512	.4988	.4668	.4893	.4934	.4492
12	.4188	.3715	.4298	.692	.455	.4439	.6695
13	.3346	.3422	.4127	.4104	.3582	.4576	.3818
14	.3117	.3014	.3849	.3563	.3589	.3696	.33
15	.2945	.2942	.3022	.3471	.3258	.3448	.3185
16	.3144	.2904	.357	.3818	.3509	.362	.3346
17	.2873	.2942	.3746	.3982	.3567	.4108	.3368
18	.4287	.3589	.4599	.4386	.3887	.423	.405
19	1.0292	.546	.6127	.6112	.5403	.6085	.4142
20	.6672	.6664	.6664	.7327	.6645	.7396	.6752
21	.6382	.6043	.6344	.6539	.6169	.6516	.6196
22	.5068	.4877	.4874	.5171	.5049	.5197	.511
23	.4302	.4176	.4237	.4542	.4546	.4637	.4283
24	.3685	.3509	.3586	.3803	.3528	.3989	.3616
Max	1.0292	.7484	.7205	.7327	.7095	.7396	.6752
Min	.2873	.2904	.3022	.3117	.3258	.3319	.3185
Avg	.4645	.4406	.4647	.4823	.4645	.4728	.4537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 212 / HANGEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
12			2.5873
19	3.7723		
24		2.8006	
Max	3.7723	2.8006	2.5873
Min	3.7723	2.8006	2.5873
Avg	3.7723	2.8006	2.5873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 213 / Chanegaon / Kanoli GFSS

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-FEB-17	18-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
12		.0672	.0806
19	.0562		
Max	.0562	.0672	.0806
Min	.0562	.0672	.0806
Avg	.0562	.0672	.0806

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 214 / 11 KV VARVANDI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17
HR	Load (MW)
19	.1372
Max	.1372
Min	.1372
Avg	.1372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 215 / 11 KV PLA / S PUR (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2526	.2785	.2557	.2412	.229	.2454	.2751
2	.25	.2603	.2549	.2412	.2237	.2458	.2717
3	.2484	.2542	.2553	.2503	.2225	.2454	.2694
4	.258	.2515	.2599	.2389	.2225	.2481	.2827
5	.2858	.2755	.2675	.2709	.2561	.2869	.3018
6	.3913	.3544	.3784	.365	.3471	.3803	.3921
7	.4954	.4946	.4592	.4736	.4252	.4386	.5041
8	.503	.4793	.4881	.479	.4652	.4534	.4908
9	.5072	.4672	.4576	.4778	.474	.4652	.4755
10	.471	.4275	.4915	.4412	.4824	.4694	.4382
11	.4005	.3822	.3791	.3319	.3948	.3151	.3113
12	.2995	.1917	.2702	.3125	.1852	.1947	.4036
13	.2248	.1532	.242	.1528	.1619	.1825	.1959
14	.1791	.1616	.2324	.1711	.1566	.2164	.1936
15	.2111	.1589	.226	.1833	.1562	.1795	.1795
16	.2092	.1658	.2347	.2039	.1555	.1909	.1795
17	.2324	.1776	.2637	.2012	.2191	.2103	.2176
18	.2972	.2843	.3052	.2683	.2961	.2984	.3109
19	.657	.4336	.4729	.3974	.4755	.49	.4386
20	.551	.4843	.5415	.5178	.5902	.5677	.5796
21	.4637	.4283	.4485	.4119	.4992	.5201	.5045
22	.378	.3144	.3452	.3189	.3475	.37	.3677
23	.3132	.3025	.3033	.2991	.3006	.3353	.3258
24	.2839	.2675	.253	.2522	.2603	.2804	.2671
Max	.657	.4946	.5415	.5178	.5902	.5677	.5796
Min	.1791	.1532	.226	.1528	.1555	.1795	.1795
Avg	.3485	.3104	.3369	.3126	.3144	.3262	.3407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014025 / 33/11 KV KARJULEPATHAR

Feeder No / Name : 201 / JAWALE BALESHWAR AG SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.4024
9				.2926
10			.2378	
11			.1829	
24	.7442	.1433	.3582	
Max	.7442	.1433	.3582	.4024
Min	.7442	.1433	.1829	.2926
Avg	.7442	.1433	.2596	.3475



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014025 / 33/11 KV KARJULEPATHAR

Feeder No / Name : 204 / Dolasane GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.0732
9				.0732
10			.0732	
24	.0732	.0701	.0709	
Max	.0732	.0701	.0732	.0732
Min	.0732	.0701	.0709	.0732
Avg	.0732	.0701	.0721	.0732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014025 / 33/11 KV KARJULEPATHAR

Feeder No / Name : 205 / Pimpalgaon depa GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.128
9				.128
10			.128	
24	.1254	.0526	.181	
Max	.1254	.0526	.181	.128
Min	.1254	.0526	.128	.128
Avg	.1254	.0526	.1545	.128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014025 / 33/11 KV KARJULEPATHAR

Feeder No / Name : 206 / JawalaBaleshwar GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.2896
9				.2561
24	.2715	.1086	.3012	
Max	.2715	.1086	.3012	.2896
Min	.2715	.1086	.3012	.2561
Avg	.2715	.1086	.3012	.2729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014100 / 33/11 KV NIMBALA

Feeder No / Name : 201 / Jorwa AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3117	1.3279	1.247	1.2967	1.278	1.247	1.4089
2	1.3441	1.3279	1.2631	1.2651	1.2944	1.247	1.2955
3	1.3927	1.3279	1.2793	1.186	1.278	1.247	1.2955
4	1.4899	1.3927	1.3279	1.166	1.4091	1.3279	1.3603
5		1.5384	1.3765	1.2955	1.5565	1.5061	1.5384
6	1.4899	1.7652	1.4737	1.4737	1.6712	1.6194	1.7004
7	1.6356	1.6194		1.5384	1.5927	1.7004	1.8623
8		1.7166	1.692	1.6762	1.917	2.0165	1.749
9	1.7004	.6668				1.8404	1.8138
10		.362					
11		.3239					
12		.2858					
13	.4001	.3048					
14	.3239	.2858					
15	.3239	.2667					
16	.3429	.2858					
17	.381	.3239					
18	.4191	.381	.5716	.5716	.4954	.5144	.4382
19	.6287	.7621	.7621	.8002	.7621	.8002	.8383
20	.8002	.7621	.8002	.8764	.8192	.8954	.8764
21	.6859	.6859	.7049	.7621	.7811	.724	.8383
22	.5716	.5906	.5525	.6478	.6097	.5716	.724
23	.4763	.5144	.5144	.5525	.4954	.5335	.5716
24	1.2955	1.3279	1.2793	1.2651	1.3108	1.247	1.4737
Max	1.7004	1.7652	1.692	1.6762	1.917	2.0165	1.8623
Min	.3239	.2667	.5144	.5525	.4954	.5144	.4382
Avg	.8954	.8394	1.0603	1.0916	1.1514	1.1899	1.2365

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014100 / 33/11 KV NIMBALA

Feeder No / Name : 202 / NIMBALA AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.1363	1.1043	1.1203	1.1043	1.2163	1.3443
2	1.1363	1.1363	1.1043	1.0883	1.0883	1.2163	1.2323
3	1.1523	1.1363	1.1203	1.0402	1.1043	1.2163	1.1523
4	1.1843	1.2003	1.1843	1.1363	1.1843	1.2643	1.3123
5	1.2483	1.3763	1.2483	1.3123	1.2483	1.3763	1.4403
6	1.3123	1.7764	1.3603	1.4403	1.4723	1.7604	1.7124
7		1.6324		1.5364	1.5203	1.7924	2.0005
8	1.6004	1.6804	1.6964	1.6964	1.8244	1.9204	2.0165
9		.4481	1.6004	1.3603	1.3923		
10	2.0005	2.1445	2.0805	2.0325	2.0805	2.0805	2.1445
11	2.1605	2.0805	2.0485	2.2405	2.0005	2.0165	2.1925
12	2.0965	2.0805	2.0165	2.0645	2.0805	2.0965	2.1765
13	2.0805	2.1125		2.1125	2.0325	2.2085	1.9204
14	2.2565	1.8404		2.0645	1.9845	2.0165	2.0165
15	.16	1.9685	2.0729				
16	.176	.192	2.0567				
17	2.3205	.16	2.0965	2.0485	2.0325	1.9204	2.0805
18	2.3365	2.1605	2.2565	2.2565	2.0805	2.3685	2.2405
19	2.3205	2.2405	2.2725	2.2085	2.2405	2.1605	1.9342
20	.5121	.5281	.571	.5441	.5601	.5761	.5761
21	.4801	.4961	.5601	.5121	.5121	.5121	.5761
22	.4161	.4481	.4801	.4801	.4801	.4481	.4801
23	.3201	.4954	.3704	.4161	.4321	.4321	.4161
24	1.1203	1.1363	1.1043	1.1523	1.1203	1.2163	1.2803
Max	2.3365	2.2405	2.2725	2.2565	2.2405	2.3685	2.2405
Min	.16	.16	.3704	.4161	.4321	.4321	.4161
Avg	1.3414	1.3169	1.4479	1.4483	1.4353	1.5150	1.5355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014100 / 33/11 KV NIMBALA

Feeder No / Name : 203 / TALEGAON WATERWORK  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1372	.096	.096	.1646	.096	.096
2	.1509	.1372	.096	.096	.1646	.096	.096
3	.1509	.1372	.096	.096	.1646	.096	.096
4	.1509	.1372	.096	.096	.1646	.096	.096
5	.1646	.1372	.096	.096	.1646	.096	.1097
6	.1509	.1372	.096	.096	.1646	.096	.1097
7		.096		.0549	.0686	.0137	.1097
8	.0549	.096	.096	.096	.1646	.096	.1235
9	.1646	.1097	.096	.096	.0549	.1235	.1235
10	.1509	.1097	.1097	.1235	.1646	.1235	.1235
11	.1372	.096	.096	.1235	.1646	.1097	.1097
12	.1509	.096	.096	.096	.1646	.1097	.1097
13	.1509	.096	.096	.1509	.1646	.1097	.1097
14	.1509	.0549	.096	.1509	.1646	.1646	.1097
15	.0549	.0549	.096	.1509	.1646	.1646	.1097
16	.1509	.0274	.1097	.1509	.1646	.1646	.1097
17	.1509	.096	.096	.0412	.1509	.1509	.1097
18	.1509	.096	.096	.096	.1509	.1509	.1097
19	.1509	.096	.096	.096	.1372	.1509	.1097
20	.1372	.096	.096	.1646	.1372	.1509	.1097
21	.1372	.096	.096	.1646	.1372	.1372	.1097
22	.1372	.096	.1097	.1646	.1372	.1372	.1097
23	.1372	.1334	.096	.1646	.1509	.1372	.1097
24	.096	.1372	.096	.1097	.1646	.096	.1097
Max	.1646	.1372	.1097	.1646	.1646	.1646	.1235
Min	.0549	.0274	.096	.0412	.0549	.0137	.096
Avg	.1384	.1044	.0978	.1155	.1498	.1195	.1091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014100 / 33/11 KV NIMBALA

Feeder No / Name : 204 / Kolhewadi AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1143	.1143	.1334	.1334
2	.1143	.1143	.1143	.1143	.0823	.1334	.1334
3	.1143	.1143	.1143	.1143	.1334	.1334	.1143
4	.1143	.1334	.1334	.1334	.1334	.1524	.1334
5	.1524	.1524	.1524	.1905	.1715	.1715	.1715
6	.2858	.2858	.2286	.2286	.2477	.2858	.2667
7		.2286		.2667			
8		.1905					
9		.3429					
10	2.1403	2.3434	2.2834	2.3967	2.5126	2.1376	2.5606
11	2.4074	2.3403	2.2348	2.5101	2.6246	2.2834	2.4352
12	2.3765	2.3087	2.2024	2.4129	2.5286	2.3158	2.4669
13		2.2138	2.1862				
14		2.2138	2.1538				
15	2.2653	2.198		2.332	2.4006	2.2672	2.2929
16	2.3746	1.9608		2.2996	2.4806	2.2348	2.3403
17	2.359	2.0557		2.4453	2.5926	2.4291	2.4036
18	2.2653	.0953	2.2929	2.4291	2.5606	2.4939	2.2929
19	2.2184	.1905	2.2771	2.3805	2.5286	2.4291	2.2455
20	.2286	.1905	.2286	.2096	.2477	.2477	.2096
21	.2096	.1715	.2667	.1715	.2096	.2667	.1715
22	.2096	.1334	.2667	.1524	.1715	.2286	.1524
23	.1905	.1334	.2286	.1334	.1334	.1905	.1143
24	.1334	.1143	.1143	.1524	.1143	.1334	.112
Max	2.4074	2.3434	2.2929	2.5101	2.6246	2.4939	2.5606
Min	.1143	.0953	.1143	.1143	.0823	.1334	.112
Avg	1.0670	.8475	.9774	1.0594	1.1573	1.0878	1.0921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014110 / 33/11 KV RAHIMPUR

Feeder No / Name : 201 / Dongre B/F

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1715	.1905	.1715	.1715	.1715
2	.1905	.1905	.1715	.1905	.1715	.1715	.1715
3	.2667	.1715	.1715	.1524	.1715	.1905	.1905
4	.2858	.2096	.1905	.2286	.1905	.2286	.2286
5	.2058	.2286	.2286	.2286	.1905	.2667	.2477
6	.2858	.2477	.2401	.2477	.2667	.2667	.2667
7	.3048	.2858	.2858	.2829	.3048	.3048	.2858
8	.2858	.2667	.2667	.2667	.2667	.2667	.2667
9	.2477	.2096	.2667	.2477	.2477	.2477	.1905
10	.2286	.2286	.2286	.2286	.2286	.2096	.1715
11	.1905	.1905		.1334	.1334	.1524	.1334
12	2.5339	2.7054	2.3388	2.7915	2.5463	2.584	2.572
13	2.8006	2.6972	2.4331	2.7244	2.6029	2.6217	2.452
14	2.6406	2.6783	2.5274	2.7073	2.4143	2.6406	2.4143
15	2.652	2.6406	2.5463	2.6217	2.452	2.5463	2.6029
16	2.6139	2.6029	2.4508	2.3491	2.4331	2.4577	2.6863
17	2.4646	2.6406	2.4143	2.572	2.4086	2.3577	
18	2.4709	2.4143	2.32	2.1262	2.4331	2.4143	
19	2.3954	2.1948	2.0233	2.0062	2.2481	2.3577	1.9993
20	.2667	.2286	.1905	.2667	.2477	.2452	.2286
21	.2477	.2477	.2477	.2096	.2286	.2286	.2286
22	.1905	.2096	.1698	.1905	.1905	.1905	.1715
23	.1905	.1905	.1905	.1905	.1905	.1905	.1715
24	.1524	.1905	.1715	.1715	.1715	.1715	.1715
Max	2.8006	2.7054	2.5463	2.7915	2.6029	2.6406	2.6863
Min	.1524	.1715	.1698	.1334	.1334	.1524	.1334
Avg	1.0126	1.0025	.9672	.9719	.9546	.9785	.8192



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014110 / 33/11 KV RAHIMPUR

Feeder No / Name : 202 / Biroba B/F

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.1143	.1143	.1143	.1143	.1143
2	.0953	.1143	.1143	.1143	.1143	.1143	.0953
3	.1905	.1334	.1524	.1524	.1524	.1143	.0953
4	.2286	.1524	.1905	.1334	.1905	.1715	.1524
5	.2286	.1905	.1905	.1905	.1905	.1905	.1905
6	.2667	.2286	.2477	.2286	.2286	.2286	.2286
7	.2858	.2667	.2286	.2667	.2286	.2477	.2477
8	.2286	.2477	.2286	.2286	.2477	.2286	.2286
9	.2096	.2286	.1905	.2096	.2286	.2096	.2286
10	.1715	.1905	.1143	.1715	.1905	.1334	.1905
11	.1524	.1715	.1143	.1143	.1143	.1334	.1715
12	1.086	1.1317	1.0425	1.0456	.9907	1.0374	.9997
13	1.2346	1.1128	1.1694	1.094	.9907	1.0098	1.0374
14	1.2346	.9619	1.0631	1.1812	.9335	1.0479	1.0185
15	1.1458	.9808	1.1523	1.0374	.9054	1.2955	1.0562
16	1.0288	.9877	1.0974	1.0288	.8589	1.1431	1.0374
17	.9808	1.0608	.9896	1.0456	.8488	.9431	.8764
18	.9526	.9335	.8779	.9694	.8676	.9808	.9619
19	.8962	.7373	.8589	.8002	.7655	.7733	.8676
20	.1886	.1905	.2096	.1905	.1715	.1905	.1524
21	.2096	.1524	.1524	.1524	.1715	.1715	.1905
22	.1334	.1143	.1143	.1524	.1524	.1372	.1524
23	.1143	.1143	.1143	.1334	.1334	.1143	.0953
24	.0953	.1143	.1143	.1143	.1334	.1143	.1143
Max	1.2346	1.1317	1.1694	1.1812	.9907	1.2955	1.0562
Min	.0953	.1143	.1143	.1143	.1143	.1143	.0953
Avg	.4772	.4430	.4518	.4529	.4135	.4519	.4376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014114 / 33/11 KV KHALI S/STN

Feeder No / Name : 201 / 11 KV KHAMBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1549	1.5674		1.7159	1.5179	1.8809
2		.9899	1.4849		1.7489	1.5344	1.8809
3		1.0064	1.4849		1.7489	1.5674	1.9139
4		1.1549	1.5179		1.7819	1.6169	1.9469
5		1.5674	1.5839		1.8149	1.7159	2.0459
6		1.9469	1.9799		2.0129	1.7819	2.3099
7		2.4749	2.3099		2.3759	2.3429	2.4749
8		2.3264	1.8479		.231	2.2439	2.0789
15	.165	.2145		.165	.165	.165	.165
16	.165	.264		.198	.165	.165	.165
17	.165	.264		.264			
18	.198	.231		.231			
19	.2805	.297		.297			
20	.33	.297		.297			
21	.2805	.297		.297			
22	.231	.264		.297			
23		1.8479		1.9139			
24	1.648	1.2869	1.6499		1.8149	1.8149	2.0789
Max	1.648	2.4749	2.3099	1.9139	2.3759	2.3429	2.4749
Min	.165	.2145	1.4849	.165	.165	.165	.165
Avg	.3848	.9936	1.7141	.4400	1.4159	1.4969	1.7219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014114 / 33/11 KV KHALI S/STN

Feeder No / Name : 202 / 11KV ZAREKATHI AG SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1632	1.454		1.2553	1.3331	.4608
2		1.0986	1.2925		1.2711	1.349	.4449
3		.2585	.2908		.2542	.2539	.1589
4		.2908	.307		.2542	.3015	.1589
5		.3231	.3231		.3178	.3333	.1589
12	.1777	.1777		.1902	.1748	.1587	
13	.1616	.1616		.1744	.1589	.1746	
14	.1616	.1616		.1585	.1589	.1428	
15	.1454	.1616		.1585	.1748	.127	
16	.2262	.1616		.1744	.1748	.1111	.2066
17	2.7142			2.663			
18	2.2619	2.5527		2.774			
19	2.1649	2.4557		2.346			
20	2.1003	2.1003		1.9814			
21	1.9387	1.8741		1.8546			
22	1.8256	1.7449		1.7955			
23		1.6318		1.4936			
24	.2423	1.2925	1.5348		1.3506	1.3506	.4767
Max	2.7142	2.5527	1.5348	2.774	1.3506	1.3506	.4767
Min	.1454	.1616	.2908	.1585	.1589	.1111	.1589
Avg	1.1767	1.0359	.8670	1.3137	.5041	.5123	.2951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014114 / 33/11 KV KHALI S/STN

Feeder No / Name : 203 / 11KV PIMPRI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2445	.2445		.2295	.2448	.2448
2		.2445	.2445		.2295	.2601	.2448
3		.2445	.2598		.2448	.2907	.2601
4		.2598	.275		.2754	.306	.2907
5		.275	.2903		.306	.3213	.306
9	1.4974	1.421	1.3752		1.2851	1.331	1.331
10	1.4057	1.3752	1.3141		1.1474	1.2239	1.331
11	1.3446	1.2682	1.1321		1.0862	1.0709	
12	1.2224	1.0543		.9791	.9944	1.0097	.9791
13	.9626	1.0085		.9026	.9638	.9485	.9485
14	1.0085	.9779		.9332	.9332	1.0157	.9179
15	1.0696	1.0085		1.0097	1.0403	.9944	.9332
16	1.0696	1.0543		.9944	1.0862	.6731	.9485
20	.3362	.3056		.3213			
21	.3209	.2903		.3366			
22	.3056	.2598		.306			
23		.2598		.2601			
24	.9168	.2598	.2598		.2448	.2448	.2448
Max	1.4974	1.421	1.3752	1.0097	1.2851	1.331	1.331
Min	.3056	.2445	.2445	.2601	.2295	.2448	.2448
Avg	.9550	.6562	.5995	.6714	.7190	.7096	.6908

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014115 / 33/11 KV PEMGIRI

Feeder No / Name : 201 / PREMGIRI SHIRGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-FEB-17
HR	Load (MW)
8	3.0011
Max	3.0011
Min	3.0011
Avg	3.0011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014115 / 33/11 KV PEMGIRI

Feeder No / Name : 202 / SAVARCHOL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-FEB-17
HR	Load (MW)
8	.4572
Max	.4572
Min	.4572
Avg	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014119 / 33/11 KV ASHWI BK

Feeder No / Name : 201 / Nimgaonjali AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-FEB-17	19-FEB-17
HR	Load (MW)	Load (MW)
8		2.4966
9		2.343
17		.1715
18		.1905
19	.381	.362
20	.4382	
21	.4191	
22	.362	
Max	.4382	2.4966
Min	.362	.1715
Avg	.4001	1.1127

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014119 / 33/11 KV ASHWI BK

Feeder No / Name : 202 / Nimgaonjali GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.2772	
9			.4668	
10			.4508	
11		.4075	.3391	
12		.3721	.4668	
13			.3174	
14			.3921	
15			.4481	
16			.5041	.4251
17			.4706	
19	.3881			
20	.3734			
21	.3547			
22	.3361			
23	.3475			
Max	.3881	.4075	.5041	.4251
Min	.3361	.3721	.2772	.4251
Avg	.3600	.3898	.4133	.4251



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014119 / 33/11 KV ASHWI BK

Feeder No / Name : 203 / Umbri AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
12		3.2065	
13		3.2065	
14		2.9287	
15		2.9254	
16		2.9447	2.9984
17		2.9473	2.9473
18		2.6543	2.7206
19	2.4453	2.4086	
20	.1524		.1524
21	.1524		
22	.1334		
23	.1143		
24			.1524
Max	2.4453	3.2065	2.9984
Min	.1143	2.4086	.1524
Avg	.5996	2.9028	1.7942

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 207 / MANGALAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0168	.0168	.0168	.0183	.0168	.0168
2	.0183	.0168	.0168	.0168	.0191	.0175	.016
3	.0175	.0168	.0183	.0175	.0206	.0183	.0168
4	.0168	.0183	.0183	.0191	.0191	.0191	.0175
5	.0183	.0191	.0206	.0213	.0229	.0221	.0206
6	.0061	.0061	.0069	.0122	.0084	.0069	.0114
12	.3452	.3018	.333	.3117	.3224	.2987	.3269
13	.3597	.3384	.3338	.1303	.3208	.333	.3536
14	.3635	.3422	.3292		.3094	.346	.3422
15	.3635	.3384	.3262	.1204	.3086	.3429	.3285
16	.3749	.3269	.3315	.3246	.3208	.3429	.3353
17	.3666	.3277	.333	.3353	.3414	.3406	.3353
18	.3483	.3346	.3315	.3384	.3422	.3391	.3346
19	.3224	.3147	.2835	.3246	.3315	.3292	.3254
20	.1311	.1212	.1128	.1174	.1296	.1044	.0899
21	.0221	.0206	.0229	.0229	.0229	.0251	.0251
22	.0221	.0213	.0259	.0229	.0229	.0251	.0259
23	.0229	.0221	.0244	.0236	.0229	.0244	.0259
24	.0183	.0183	.0191	.0191	.0175	.0183	.1898
Max	.3749	.3422	.3338	.3384	.3422	.346	.3536
Min	.0061	.0061	.0069	.0122	.0084	.0069	.0114
Avg	.1661	.1538	.1529	.1219	.1538	.1563	.1651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 201 / PMT

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4527	.3983	.4749	.4904	.4939	.4904	
4	.4338	.397	.4939	.4715	.4939	.5093	
6	.4715	.4143	.5129	.5093	.4749	.5658	
7	.5281		.5319	.547	.4749		
8	.679	.433	.5319	.5847	.4939	.5281	
9	.7356	.5509	.6648	.7733	.5509	.6739	.6048
10	.7415	.5514	.7218	.811	.6458		
11	.7415	.4944		.811	.6078		
12			.7978	.8467	.4944	.8548	
13	.7035	.5134	.7598		.547		
14	.6648		.6648	.7408	.5281		
15	.7796	.5134	.6648		.4338		
16	.0721	.4559	.7733	.6648			
17		.4373	.6602		.415		
18	.5184	.5704	.5281	.5698	.4904		
19		.5698	.6413	.6458	.6224		
20	.5715	.6275		.5888	.5658		
21		.6078	.5847	.5698			
22	.5357	.6078	.5658	.5324	.547		
23		.5509	.5281	.5319	.4904		
24	.4715	.4749	.6648	.547	.5129	.5093	.5144
Max	.7796	.6275	.7978	.8467	.6458	.8548	.6048
Min	.0721	.397	.4749	.4715	.415	.4904	.5144
Avg	.5688	.5094	.6192	.6242	.5202	.5902	.5596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 202 / 11 KV Gogalgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.1469	1.0736	1.0425	1.065	1.0291	.2622	
4	1.3108	1.1043	1.0934	1.2289	1.1256	.2785	
6	1.4746	1.3803	1.4633	1.4746	1.4633	.426	
7	2.0809		1.7688	2.0645	1.8653		
8	2.2775	2.2238	2.0421	2.4249	2.2833	.3932	
9	2.0481	2.1176	2.0621	2.0317	2.1065		
10	.3421	.3421	.3273	.3605	.3584		
11	.2606	.3095		.3113	.2769		
12			.2128				
13	.2412	.2118	.2128				
14	.2118		.18	.1629			
15	.2282	.2281	.2291		.2458		
16	.1534	.2281	.1966	.1955			
17		.2281	.2294		.2458		
18	.0275	.3095	.2458	.2573	.2949		
19		.3909	.4588	.3859	.3932		
20	.3988	.4398		.4561	.4588		
21		.402	.4096	.4235			
22	.3685	.3859	.3605	.3909	.3932		
23		.3538	.3277	.3421	.3441		
24	1.065	1.0429	1.0452	.9503	.997	.2785	.3185
Max	2.2775	2.2238	2.0621	2.4249	2.2833	.426	.3185
Min	.0275	.2118	.18	.1629	.2458	.2622	.3185
Avg	.8522	.7096	.7320	.8545	.8676	.3277	.3185

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 203 / 11 kv Sadatpur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1989	.1384	.1629	.1823	.1792	.9116	
4	.2321	.1537	.1792	.2155	.1955	.9945	
6	.2818	.123	.2769	.2984	.2606	1.4089	
7	.3149		.3258	.2984	.2932		
8	.2486	.2767	.2769	.2652	.2606	2.0388	
9	.2321		.2331	.2155	.1955		
10	.1629	.1466	.1665	.1658	.1466		
11	.1303	.1629		.1326	.1466		
12			.1665		1.5149		
13	1.7045	1.6452	.1665		1.5912		
14	1.7593		.8492	1.6289	1.6244		
15	1.6723	1.5149	.5495		1.6575		
16	1.6297	1.5638	.3978	1.6615			
17		1.6127	1.5746		1.7404		
18	1.599	1.5801	1.6575	1.6615	1.8233		
19		1.5638	1.6907	1.5455	1.6741		
20	.246	.2769		.2769	.2818		
21		.2606	.2984	.2769			
22	.2152	.2606	.2818	.2606	.2652		
23		.2118	.2486	.2281	.2155		
24	.2155	.1665	.1955	.2321	.2118	.8619	.8421
Max	1.7593	1.6452	1.6907	1.6615	1.8233	2.0388	.8421
Min	.1303	.123	.1629	.1326	.1466	.8619	.8421
Avg	.6777	.6858	.5104	.5615	.7515	1.2431	.8421

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 204 / 11 kv Engr Collage

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1132	.1212	.114	.1132	.114	.1132	
4	.132	.1212	.114	.1132	.114	.132	
6	.1886	.1212	.152	.1509	.133	.1698	
7	.2263		.171	.1509	.152		
8	.2075	.1559	.2089	.2075	.1899	.2075	
9	.1886	.152	.1711	.2263	.1899	.2075	
10	.1901	.1711	.2092	.2263	.152	.2075	
11	.1711	.152		.1886	.152		
12			.1901	.1559	.114		
13	.1711	.1331	.1901		.1132		
14	.2092		.1901	.152	.132		
15	.2282	.1331	.1141		.132		
16	.1905	.1331	.1886	.171			
17		.1141	.1509		.132		
18	.0866	.1331	.132	.114	.132		
19		.152	.1698	.171	.1698		
20	.1557	.1521		.152	.1509		
21		.1521	.1698	.152			
22	.1384	.1521	.1698	.152	.1509		
23		.1521	.1509	.152	.1509		
24	.132	.1212	.133	.132	.133	.1509	.132
Max	.2282	.1711	.2092	.2263	.1899	.2075	.132
Min	.0866	.1141	.114	.1132	.1132	.1132	.132
Avg	.1706	.1402	.1626	.1600	.1425	.1698	.132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 205 / 11 kv Dudheshwar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.531	.9779	1.1738	1.3279	1.2703	.2343	
4	1.6716	1.1613	1.2372	1.4842	1.2703	.25	
6	1.8903	1.803	1.8323	1.7966	1.8653	.3281	
7	2.1559		2.2082	2.3434	2.2351		
8	2.359	2.3072	1.9733	2.234	2.5406	.3749	
9	2.1559	2.3804	2.5027	2.234	2.0904		
10	.2932	.2662	.2346	.2968	.2894		
11	.2349	.2193		.2343	.209		
12			.1564		.1608		
13	.1955	.1566	.1564		.1718		
14	.1723		.1564	.1566	.1875		
15	.1566	.1409	.1408		.1718		
16	.1375	.1566	.125	.1566			
17			.1562		.1823		
18	.1375	.1723	.2031	.1879	.1875		
19		.2976	.3437	.2894	.2812		
20	.3209	.3258		.3602	.3437		
21		.3055	.3281	.3377			
22	.2972	.2894	.2968	.2734	.2968		
23		.2573	.2656	.2734	.2812		
24	1.5154	.9321	1.1578	1.3279	1.2542	.25	.2949
Max	2.359	2.3804	2.5027	2.3434	2.5406	.3749	.2949
Min	.1375	.1409	.125	.1566	.1608	.2343	.2949
Avg	.9515	.7147	.7710	.9008	.8047	.2875	.2949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 206 / Adgaon Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0377	.052	.057	.0377	.038	.0377	
4	.0566	.052	.057	.0566	.057	.0377	
6	.0943	.052	.095	.0943	.095	.0754	
7	.0943		.114	.0943	.114		
8	.0943	.052	.095	.0754	.114	.0943	
9	.0754	.0761	.0951	.0943	.1141		
10	.057	.038	.057	.1132	.095		
11	.0761	.038		.0754	.057		
12	.057		.019		.038		
13	.057	.1901	.038		.0377		
14	.038			.038	.0377		
15	.038	.057			.0566		
16	.052	.0761		.038			
17		.0761	.0566		.0754		
18	.0519	.1141	.0566	.1141	.0943		
19		.1521	.1509	.171	.132		
20	.1039	.0951		.152	.132		
21		.0951	.0943	.114			
22	.052	.0761	.0754	.0761	.0754		
23		.057	.0566	.057	.0566		
24	.0566	.0056	.057	.0566	.057	.0566	.0566
Max	.1039	.1901	.1509	.171	.132	.0943	.0566
Min	.0377	.0056	.019	.0377	.0377	.0377	.0566
Avg	.0642	.0753	.0734	.0858	.0777	.0603	.0566



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014131 / Wakadi

Feeder No / Name : 202 / Ganeshnagar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
8	.3125
Max	.3125
Min	.3125
Avg	.3125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014131 / Wakadi

Feeder No / Name : 203 / MAHADEO GGSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
8	.2987
Max	.2987
Min	.2987
Avg	.2987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014131 / Wakadi

Feeder No / Name : 204 / KHANDOBA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
8	.3439
Max	.3439
Min	.3439
Avg	.3439

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 201 / 11 kv chinchpur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1334	.0953	.0905	.9957	1.0364
2	.1715		.1334		.0905	.9957	
3	.1715		.1334		.0905	1.0105	1.0364
4	.1715	.1524	.1524	.1143	.1267	1.0402	
5	.1715		.1524		.1629	1.1145	1.3565
6	.1905	.1905	.1524	.1524	.181	1.2492	
7	.2286	.2096	.2286		.1991	1.7071	1.9814
8	.1524	.1715	.1905	.1524	.1715	1.8827	
9	.1143	.1524	.132	.1334	.1267	1.821	1.768
10	.1334	.1715	.1715	.1524	.1334	.1334	
11	.1334	.1334	.0953	.1715	.1143	.1143	.1334
12	1.9599	1.6432	1.7861	1.8673	2.0833	.0572	
13	2.0216		1.7623	1.9753	2.1715	.0572	.0572
14		2.3243	1.7524	2.0525	2.0778	.0572	
15		1.7341	1.7861		2.0309	.0572	
16	1.9753	1.7575	1.7341	1.9599	2.0309	.0572	
17	1.9662	1.7482	1.6861		2.0466	.0762	
18	1.89		1.5146	1.8747	1.9216	.0762	
19	1.6461	1.6129	1.4575	1.7654	1.7497	.1524	.1334
20			.1715	.1905		.1905	
21	.2096	.2477	.1715		.2096	.2096	
22				.1524		.1905	
23	.1524	.2096			.1143	.1905	.1905
24	.1715	.1524	.1334		.1086		1.0364
Max	2.0216	2.3243	1.7861	2.0525	2.1715	1.8827	1.9814
Min	.1143	.1334	.0953	.0953	.0905	.0572	.0572
Avg	.6901	.7508	.7105	.8540	.8196	.5842	.8730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 204 / 11KV Chandrapur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4175	1.3032	1.3094	1.0526	.2286	.1905
2	1.3717	1.4175	1.3032		1.1174	.2286	
3	1.3717	1.4175	1.4266		1.4563	.2286	.1905
4	1.5242		1.4266	1.4327	1.4217	.2477	
5	1.5546	1.829	1.5051		1.5623	.2858	.2286
6	1.6512	1.7337	1.5804	1.6404	1.7747	.3048	
7	2.0083	1.7871	2.0083		2.0988	.3239	.2858
8	2.2996	2.0405	2.2929	2.3878	2.0576	.2667	
9	2.1032	1.8804	2.1348	2.1338	2.2377	.2096	.2477
10	.2096	.2286	.2452	.1715	.2477	.2096	
11	.1905	.2075	.1715	.1524	.2286	.2096	.2667
12	.1715	.1132	.0972	.1334	.1905	2.6235	
13			.1006		.1524	1.6194	1.8364
14		.132	.1017	.132		2.7206	
15		.1132	.1132		.1334	2.6726	
16	.0953		.132	.1132	.1334	2.2005	
17	.1143	.1143	.1132		.1524	2.1338	
18	.1334		.1509		.1905	2.915	
19	.0762	.2477	.2012	.2641	.2667	1.8671	1.7869
20	.3429		.2858	.3395		.362	
21	.3429	.3429	.2858		.3429	.3429	
22	.2858			.2858		.3429	
23	.2477	.3239			.2286	.3239	.3239
24	1.3889	1.387	1.2378		1.0395		.1905
Max	2.2996	2.0405	2.2929	2.3878	2.2377	2.915	1.8364
Min	.0762	.1132	.0972	.1132	.1334	.2096	.1905
Avg	.8979	.9296	.8281	.8074	.8612	.9942	.5548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 205 / 11KV HASNAPUR GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0953	.0953	.0754	.0762	.0572
2	.0762	.0572	.0953		.0754	.0762	
3	.0953		.1143		.0943	.0762	.0572
4	.0953		.1143	.1143	.0762	.0953	
5	.1143	.0953	.1334		.0943	.1143	.0953
6	.1334	.1143	.1334	.1143	.0943	.1334	
7	.1334	.1334	.1524		.1509	.1334	.1334
8	.1143	.1334	.1524	.1524	.1715	.1334	
9	.0953	.1143	.1509	.1334	.1524	.1334	.1524
10	.0953	.1132	.1334	.1143	.1334	.1143	
11	.0953	.1132	.1509	.1143	.1143	.1143	.1143
12	.0762	.0943	.1334	.0953	.1143	.0953	
13			.0943		.1143	.0953	.0953
14		.1143	.0953	.0754		.0953	
15		.0762	.0953		.0762	.0953	
16	.0762		.0762	.0754	.0762	.0953	
17	.0762	.0953	.0953		.0953	.0953	
18	.0762		.1132	.1132	.1143	.0953	
19	.1143	.1334	.1143	.1509	.1143	.1334	.1334
20	.1143		.1143	.1334		.1143	
21	.0953	.1334	.1143		.1143	.1143	
22				.0953		.0953	
23	.0572	.0953			.0762	.0762	.0953
24	.0762	.0572	.0953		.0762		.0572
Max	.1334	.1334	.1524	.1524	.1715	.1334	.1524
Min	.0572	.0572	.0762	.0754	.0754	.0762	.0572
Avg	.0943	.1046	.1167	.1127	.1050	.1044	.0991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 206 / 11KV DURGAPUR GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0572	.0572	.0572	.0381	.0381
2	.0381		.0572		.0572	.0381	
3	.0572		.0572		.0572	.0381	.0381
4	.0572		.0572	.0572	.0572	.0572	
5	.0572	.0762	.0572		.0943	.0953	.0762
6	.0572	.1143	.0572	.0572	.1143	.1143	
7	.0953	.1143	.0953		.1132	.0953	.1143
8	.0953	.0762	.0762	.0572	.1132	.0953	
9	.0953	.1143	.0953	.0762	.1143	.1143	.0953
10	.0762	.0762	.0762	.0572	.0953	.0762	
11	.0572	.0572	.0566	.0381	.0762	.0572	.0381
12	.0381	.0566	.0381	.0191	.0762	.0381	
13	.0381		.0381	.0191	.0572	.0381	.0381
14		.0381	.0377	.0191	.0572	.0572	
15		.0572	.0762		.0572	.0381	
16	.0381	.743	.0762	.0191	.0572	.0381	
17	.0762	.0762	.0762		.0762	.0572	
18	.0953		.0953	.0754	.0953	.0762	
19	.0762	.0762	.0953	.0953	.0953	.0953	.0953
20			.0953	.1143		.0953	
21	.0762	.0762	.0762		.0762	.0762	
22	.0762			.0762		.0572	
23	.0572	.0572			.0572	.0381	.0572
24	.0381	.0381	.0572		.0572		.0381
Max	.0953	.743	.0953	.1143	.1143	.1143	.1143
Min	.0381	.0381	.0377	.0191	.0572	.0381	.0381
Avg	.0635	.1109	.0684	.0559	.0778	.0663	.0629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 201 / 11 kv Satral

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.4523		.1075	
5							.2743
7		2.271			2.5149		
8	2.6783	2.4539		2.6949		.1791	.3201
9					2.9854	.2743	
12			.1297			3.066	
13				.1067			
14					.113		
16			.1135			2.9854	
17	.1219					2.7587	2.711
18							2.6787
19				.2896		2.332	2.5012
20					.188		.3389
21							.3227
22							.2905
23	.1829			.2134		.2439	.2582
24	1.5421	1.4784		1.4523	1.3565	.1075	.1677
Max	2.6783	2.4539	.1297	2.6949	2.9854	3.066	2.711
Min	.1219	1.4784	.1135	.1067	.113	.1075	.1677
Avg	1.1313	2.0678	.1216	1.0349	1.4316	1.3394	.9863



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 202 / Dhanore

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.2246		1.0082	
5							1.7375
7		.4115					
8	.3227	.3048		.3369		1.0402	2.271
9					.3227	2.3742	
12			2.3399			.1604	
13				2.2405			
14					2.4063		
16			2.2915			.1283	
17						.1524	.1604
18							.1765
19				2.3167		.3201	.3208
20					.2321		.4492
21							.4171
22							.369
23	.2439			.2439		.2896	.3208
24	.2421	2.1948		.2406	.2286	.9602	1.4175
Max	.3227	2.1948	2.3399	2.3167	2.4063	2.3742	2.271
Min	.2421	.3048	2.2915	.2246	.2286	.1283	.1604
Avg	.2696	.9704	2.3157	.9339	.7974	.7148	.7640

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 203 / Nimbhere

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.4034		.976	
5							1.829
8						2.9369	3.0331
9						2.7594	
12			2.8535			.1614	
13				2.0881			
14					2.7756		
16			2.2699			.1775	
17	2.4387					.2286	.1604
18							.2582
19				2.4996		.4725	.468
20					.3045		.4841
21							.4841
22							.4518
23	.3506			.3658		.381	.4034
24	.3239	.3353		.3389	.3353	.8507	1.4784
Max	2.4387	.3353	2.8535	2.4996	2.7756	2.9369	3.0331
Min	.3239	.3353	2.2699	.3389	.3045	.1614	.1604
Avg	1.0377	.3353	2.5617	1.1392	1.1385	.9938	.9051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 204 / Kanadgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.773		.1791	
5							.381
7		3.1245			3.1703		
8	3.2925	3.4446		3.3848		.2686	
9					3.2236		
12			.1927			3.3242	
13				.1524			
14					.1612		
16			.1927			3.1629	
17	.1677					2.8807	2.8401
18							2.8078
19				.5182		2.4844	2.6626
20					.298		.4841
21							.5164
22							.4841
23	.3658			.381		.4115	.4518
24	1.7667	1.6004		1.6924	1.5699	.184	.3658
Max	3.2925	3.4446	.1927	3.3848	3.2236	3.3242	2.8401
Min	.1677	1.6004	.1927	.1524	.1612	.1791	.3658
Avg	1.3982	2.7232	.1927	1.3170	1.6846	1.6119	1.2215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 206 / SHERAKHAWALI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.0637		.7476	
5							.1067
7		.1219			.1829		
8	.2105	.1981		.1752		.0686	.1677
9					.2071	.223	
12			.1296			.1274	
13				.1067			
14					.0956		
16			.0956			.1115	
17	.1372					.0914	.1274
18							.1433
19				.2439		.1829	.223
20					.1029		.2389
21							.223
22							.1593
23	.1067			.1067		.1372	.1433
24	.1297	.0914		.0796	.0762	.0412	.0914
Max	.2105	.1981	.1296	.2439	.2071	.7476	.2389
Min	.1067	.0914	.0956	.0637	.0762	.0412	.0914
Avg	.1460	.1371	.1126	.1293	.1329	.1923	.1624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 207 / MHASOBA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.1823		.1629	
5							.2401
7		.3944					
8	.4731	.4287		.4558		.2715	.4458
9					.4736	.4923	
12			.2732			.3282	
13				.1715			
14					.2735		
16			.2368			.2735	
17	.2743					.1715	.2917
18							.3282
19				.4973		.381	.4194
20					.2932		.4741
21							.3464
22							.3282
23	.2058			.2401		.2743	.31
24	.2183	.381		.1823	.1715	.152	.1715
Max	.4731	.4287	.2732	.4973	.4736	.4923	.4741
Min	.2058	.381	.2368	.1715	.1715	.152	.1715
Avg	.2929	.4014	.255	.2882	.3030	.2786	.3355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 201 / 11 KV Papermill Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	21-FEB-17
HR	Load (MW)
9	.2229
10	.1886
11	.2229
12	.2915
13	.2572
14	.2229
15	.2229
16	.0867
17	.1029
18	.0867
19	.1029
20	.12
21	.1214
22	.1214
23	.12
Max	.2915
Min	.0867
Avg	.1661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 202 / 11 KV Morwadi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
9	1.4918
10	.1734
11	.1886
12	.0857
13	.0857
14	.0857
15	.12
16	.0857
17	.12
18	.12
19	.2572
20	.3086
21	.2915
22	.2774
23	.2572
<b>Max</b>	<b>1.4918</b>
<b>Min</b>	<b>.0857</b>
<b>Avg</b>	<b>.2632</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
Station

Feeder No / Name : 203 / 11 KV Kangar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
9	.3086
10	.2572
11	.1715
12	3.3979
13	3.2693
14	3.4808
15	3.3979
16	2.8178
17	2.8509
18	3.437
19	.3988
20	.3944
21	.3944
22	.3429
23	.3086
Max	3.4808
Min	.1715
Avg	1.6819



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 204 / 11 KV Deolali  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	21-FEB-17
HR	Load (MW)
9	1.7436
10	.2743
20	.3086
21	.3258
22	.3086
23	.3294
Max	1.7436
Min	.2743
Avg	.5484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 206 / 11 KV DEOLALI-PRAVARA (G)  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	21-FEB-17
HR	Load (MW)
9	.8383
10	.7293
11	.6274
12	.6706
13	.503
14	.5087
15	.57
16	.5571
17	.5801
18	.57
19	.7042
20	.7293
21	.6859
22	.6068
23	.5144
Max	.8383
Min	.503
Avg	.6263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 207 / 11 KV RAHURY FACTORY (G)  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	21-FEB-17
HR	Load (MW)
9	.8383
10	.779
11	.7545
12	.7545
13	.7202
14	.7459
15	.7545
16	.788
17	.6706
18	.9221
19	.9054
20	.9054
21	.8383
22	.779
23	.57
Max	.9221
Min	.57
Avg	.7817

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 208 / 11 KV AMBIKA(DEOLALI  
BANGALA) Feeder KV- 11 /  
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
9	.2915
12	1.873
13	1.2431
14	1.8842
15	1.9062
16	1.7736
17	1.6575
18	2.1795
19	1.989
20	.2947
21	.3086
22	.2743
23	.3121
Max	2.1795
Min	.2743
Avg	1.2298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014136 / 33 /11 KV Tharabad

Feeder No / Name : 202 / 11 KV Mahisgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16							3.0407
24	2.1872	1.7394	2.0679	2.0062	2.0062	1.5741	
Max	2.1872	1.7394	2.0679	2.0062	2.0062	1.5741	3.0407
Min	2.1872	1.7394	2.0679	2.0062	2.0062	1.5741	3.0407
Avg	2.1872	1.7394	2.0679	2.0062	2.0062	1.5741	3.0407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014136 / 33 /11 KV Tharabad

Feeder No / Name : 203 / 11 KV TAHARABAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.8592	.8592	1.0936	.9061	1.0623	.1265	.1107
Max	.8592	.8592	1.0936	.9061	1.0623	.1265	.1107
Min	.8592	.8592	1.0936	.9061	1.0623	.1265	.1107
Avg	.8592	.8592	1.0936	.9061	1.0623	.1265	.1107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014136 / 33 /11 KV Tharabad

Feeder No / Name : 204 / GFSS TAHARABAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1094	.0617	.0926	.108	.1265	.0937	.125
Max	.1094	.0617	.0926	.108	.1265	.0937	.125
Min	.1094	.0617	.0926	.108	.1265	.0937	.125
Avg	.1094	.0617	.0926	.108	.1265	.0937	.125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014140 / 33 / 11 KV Aradgaon

Feeder No / Name : 202 / 11 KV Manori (AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
19	.2785
Max	.2785
Min	.2785
Avg	.2785



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 201 / 11 KV Ambi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8564	1.7284	1.8404	1.9204	
3	1.8564	1.7284	1.8404	1.8404	
4		1.8564			
5	2.1765		2.0805		
6		2.0965	2.3205		
7	2.4006	2.1605	2.4006		
8	2.4646	1.6964	2.5606		
9	1.9845	2.2885	2.4006		
10	.208	.2561	.208		
11	.192	.2401	.192		
12	.128	.112	.176		
13	.128	.112	.16		
14	.128	.112	.16		
15	.144	.112	.144		
16	.128	.112			
17			.144		
18		.144	.128		
19			.2561		
20		.2241	.2561		
21			.192		
22		.2241			
23		.2241	.16		
24		1.7604	1.9204	1.9204	.176
Max	2.4646	2.2885	2.5606	1.9204	.176
Min	.128	.112	.128	1.8404	.176
Avg	1.0612	.9046	.9770	1.8937	.176

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 202 / 11 KV Ganeshwadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1581	.1423	.1423	.1423	
3	.1739	.1423	.1423	.1423	
4		.1898			
5	.2688		.1581		
6			.253		
7	.3163	.3321	.3321		
8	.3005	.3321			
9	.2372				
10	.1423	.2214	.2214		
11	.1107	.1739	.1898		
12	1.5971	1.7394	1.8343		
13	1.9766	1.7604	1.7078		
14	1.8976	1.8185	1.7236		
15	1.7711	1.8185	1.7553		
16	1.7553	1.8185	1.7236		
17			1.692		
18		1.8976	1.7078		
19			1.5971		
20		.253	.2214		
21			.1898		
22		.208			
23		.1581	.1739		
24		.2688	.1423	.1423	.9172
Max	1.9766	1.8976	1.8343	.1423	.9172
Min	.1107	.1423	.1423	.1423	.9172
Avg	.8235	.7809	.8373	.1423	.9172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 203 / 11 KV Wakanphata

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.176	.144	.176	.1602	
3	.176	.144	.176	.144	
4		.144			
5	.2401		.208		
6		.2721	.3041		
7	.3521	.3681	.3681		
8	.3201	.3361	.3041		
9	.3041	.2721	.2561		
10	.208	.2401	.192		
11	.16	.16	.16		
12	1.9524	1.9204	1.7124		
13	1.8724	1.9204	1.6804		
14	1.7604	1.9204	1.6484		
15	1.6964	1.9204	1.6804		
16	1.6804	1.9204	1.7124		
17			1.7604		
18		1.9204	1.8084		
19			1.7604		
20		.2561	.2721		
21			.208		
22		.2401			
23		.2241	.192		
24		.144	.176	.16	1.1363
Max	1.9524	1.9204	1.8084	.1602	1.1363
Min	.16	.144	.16	.144	1.1363
Avg	.8383	.7614	.7979	.1547	1.1363

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 204 / 11 KV KARANJGAON AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3061	2.8826	2.7978	2.5434	
3	2.3061	2.8178	2.7978	2.5434	
4		2.9504		2.5434	
5	2.4756		2.8826		
6		3.1369	3.1369		
7	2.8826		3.2217		
8	3.12	3.103	3.2217		
9	.5087	2.6282	2.713		
10	.2035	.1865	.2035		
11	.1696	.1865	.1526		
12		.1187	.0848		
13	.0678	.1017	.0678		
14	.0678	.0848	.0678		
15	.0848	.0678	.0678		
16	.0848	.1017	.0848		
17			.1017		
18		.1526	.1187		
19			.2035		
20		.2035	.2543		
21			.1865		
22		.1526			
23		.1526	.1526		
24	.0678	2.8995	2.4587	2.5434	.1696
Max	3.12	3.1369	3.2217	2.5434	.1696
Min	.0678	.0678	.0678	2.5434	.1696
Avg	1.1035	1.2182	1.1894	2.5434	.1696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 205 / Dawangaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0526	.0526	.0526	
3	.0351	.0526	.0526	.0526	
4		.0526			
5	.0701		.0526		
6		.0701	.0701		
7	.0876	.1052	.1052		
8	.1052	.1052	.1052		
9	.1052		.1052		
10	.0701	.1052	.0701		
11	.0526	.0701	.0526		
12	.0526	.0526	.0526		
13	.0351	.0526	.0526		
14	.0351	.0526			
15	.0351	.0526			
16	.0526	.0526			
17			.0526		
18		.0526	.0876		
19			.0876		
20		.0876	.0876		
21			.0526		
22		.0701			
23		.0526	.0351		
24		.0526	.0526	.0526	.0526
Max	.1052	.1052	.1052	.0526	.0526
Min	.0351	.0526	.0351	.0526	.0526
Avg	.0593	.0662	.0682	.0526	.0526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 206 / Karajgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	19-FEB-17	20-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0554	.0739	.0554	
3	.0554	.0554	.0739	.0554	
4		.0739		.0554	
5	.1109		.0739		
6		.1294	.1109		
7	.1478	.1663	.1663		
8	.0924	.1663	.1663		
9	.0924		.1663		
10	.0924	.1478	.1478		
11	.0739	.1109	.1478		
12		.0739	.1075		
13	.0554	.0739	.0924		
14	.0739	.0739	.0739		
15	.0739	.0739	.1109		
16	.0739	.0924	.1294		
17			.1478		
18		.1294	.1478		
19			.1663		
20		.1478	.168		
21			.0934		
22		.0924			
23		.0739	.0739		
24		.0554	.0739	.0554	.0739
Max	.1478	.1663	.168	.0554	.0739
Min	.0554	.0554	.0739	.0554	.0739
Avg	.0831	.0996	.1196	.0554	.0739

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014144 / 33 / 11 KV Talkalimiya

Feeder No / Name : 201 / 11 KV Talkalimiya

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9846	.9587	.9288	.8802	.9682	.0693	.0686
2	.9431	.9587	.9288	.8655	.9682	.0686	.0701
3	.9574	.9717	.9288	.8688	.9701	.0693	.0716
4	1.0002	1.0002	.9717	.8833	.9846	.0867	.0724
5	1.0431	1.0402	1.0425	.9122	1.0402	.1033	.0924
6	1.1439	1.0837	1.1294	.9682	1.1126	.1294	.0934
7	1.3523	1.1591	1.2498	1.2963	1.2811	.1307	.1132
8	1.6598	1.3226	1.4632	1.3565	1.1728	.112	.1132
9	1.386	1.2445	1.363	1.3056	1.2346	.0886	.0686
10	.0781	.0914	.06	.0524	.0457	.0366	.0419
11	.0754	.0686	.0472	.0533	.044	.0332	.0366
12	.0619	.0314	.0452	.0526	.0434	1.4563	1.2346
13	.048	.0286	.048	.044	.0503	1.5813	1.2955
14	.0465	.0291	.0497	.0457	.0509	1.5339	1.6512
15	.0556	.0286	.0326	.0486	.0509	1.142	1.6204
16	.0495	.0291	.0509	.0503	.0509	1.5023	1.6204
17		.0297		.0503	.0503	1.5023	1.5278
18		.0734	.0497	.0503	.0671	1.5242	1.5089
19	.0914	.1067	.0914	.1134	.0671	1.4022	1.4969
20	.1048	.1029	.0972	.096	.0892	.1143	.0846
21	.08	.0972	.0743	.0926	.0892	.1303	.0766
22	.0762	.0789	.0564	.0714	.0914	.0823	.0732
23	.072	.0686	.0526	.0648	.0762	.0667	.061
24	.9846	.9446	.9288	1.3203	.9682	.0693	.0857
Max	1.6598	1.3226	1.4632	1.3565	1.2811	1.5813	1.6512
Min	.0465	.0286	.0326	.044	.0434	.0332	.0366
Avg	.5588	.4812	.5083	.4809	.4820	.5431	.5491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014144 / 33 / 11 KV Talkalimiya

Feeder No / Name : 202 / 11 KV Lakh  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3889	1.3523	1.3717	1.3672	1.595	.1254	.1334
2	1.3565	1.3523	.9145	1.3696	1.6126	1.2489	.1288
3	1.3717	1.3847	1.4217	1.387	1.6126	.1343	.1362
4	1.3696	1.4548	1.4899	1.4217	1.595	.1429	.1486
5	1.3998	1.5424	1.5424	1.491	1.6644	.2105	.1734
6	1.4784	1.7002	1.647	1.595	1.7511	.2401	.2
7	1.8818	2.0508	1.9071	2.1209	2.2786	.2503	.2503
8	2.1605	2.2961	2.0805	2.2192	2.0978	.217	.2012
9	2.0679	2.1434	1.9033	2.1262	2.2119	.1715	.1829
10	.1307	.1143	.1429	.1467	.112	.136	.14
11	.0747	.1067	.1254	.1658	.1227		.088
12	.0381	.0793	.112	.1414	.104	2.9994	2.8086
13	.0191	.0768	.1147	.128	.1015	2.774	2.9664
14	.0191	.0914	.1147	.1142	.0991	2.9127	2.7469
15	.0191	.1094	.1147	.1189	.0941	2.6699	2.7978
16	.0191	.0991	.1147	.1189	.0867	2.5312	2.34
17		.0941		.1189	.0867	2.8121	2.7092
18		.1362	.1174	.1189	.1164	2.1672	2.5434
19	.1734	.16	.16	.1627	.1707	2.2539	2.2291
20	.18	.2105	.1951	.1772	.2073	.1829	.2029
21	.1715	.2058	.1738	.192	.1981	.1886	.2164
22	.1543	.1585	.1486	.1686	.1677	.1684	.2042
23	.12	.1219	.1372	.1457	.1494	.1524	.1772
24	1.4198	1.3523	1.3717	1.3496	1.595	.1254	.128
Max	2.1605	2.2961	2.0805	2.2192	2.2786	2.9994	2.9664
Min	.0191	.0768	.112	.1142	.0867	.1254	.088
Avg	.7734	.7664	.7574	.7694	.8263	1.0789	.9939



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014144 / 33 / 11 KV Talkalimiya

Feeder No / Name : 203 / 11 KV TAKALIMIYA GAVATHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2865	.2715	.3224	.2534	.3189	.298	.298
2	.2865	.2715	.3258	.2534	.3189	.2804	.298
3	.2865	.2896	.3292	.2561	.3155	.3012	.3224
4	.3077	.3475	.3658	.2926	.3155	.3544	.362
5	.4024	.4435	.6468	.3881	.3988	.5304	.4344
6	.6653	.5847	.7842	.7095	.5658	.7095	.6535
7	.8589	.9149	.8589	.9054	.8215	.8029	.8589
8	.8871	.8501	.7947	.8029	.7947	.8402	.8501
9	.7265	.8316	.7655	.7133	.7499	.6733	.7628
10	.578	.6661	.5376	.5335	.5407	.5376	.6325
11	.5182	.5316	.4938	.4715	.4527	.4161	.4816
12	.4382	.5316	.443	.443	.4287	.4477	.3681
13	.4334	.4854	.4382	.4144	.4161	.3582	.4031
14	.3814	.4334	.4334	.3944	.3814	.443	.407
15	.4252	.4115		.4334	.3506	.3467	.3856
16	.4961	.3688	.0069	.4252	.3403	.5028	
17		.4191	.0234	.4557	.3898	.5258	.5596
18		.5426	.6443	.4733	.5316	.5434	.4917
19	.7343	.6154	.724	.6874	.6706	.7455	.6154
20	.6882	.6718	.6133	.5898	.6154	.583	.5121
21	.5601	.583	.4744	.4744	.5571	.5281	.4515
22	.4344	.4784	.3963	.4064	.4534	.4374	.3841
23	.3353	.2743	.3102	.3286	.3401	.3395	.3199
24	.2865	.2715	.3224	.2534	.3189	.298	.2947
Max	.8871	.9149	.8589	.9054	.8215	.8402	.8589
Min	.2865	.2715	.0069	.2534	.3155	.2804	.2947
Avg	.5008	.5037	.4806	.4733	.4745	.4935	.4847

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014144 / 33 / 11 KV Talkalimiya

Feeder No / Name : 204 / 11 KV JATAP AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1097	.1097	.084	.0838	1.2489	1.267
2	.1052	.1132	.1132	.084	.0796	1.2489	1.267
3	.1052	.1267	.12	.088	.0789	1.267	1.267
4	.1052	.1339	.141	.088	.0823	1.267	1.2894
5	.1433	.1339	.1677	.108	.0991	1.3717	1.448
6	.2033	.1524	.1972	.1467	.1174	1.4632	1.5364
7	.2241	.1718	.2149	.2332	.1928	1.6644	1.6827
8	.2054	.184	.1886	.1884	.1718	1.8473	2.0328
9	.1595	.1562	.1334	.1509	.1216	1.7013	1.7909
10	.1143	.1448	.0914	.1166	.112	.1231	.1134
11	.08	.1448	.1115	.0686	.1067	.0823	.0762
12	1.7747	1.9765	2.0119	2.0302	1.8861	.08	.0686
13	1.8278	2.0332	2.1765		1.9004	.0724	.1844
14	1.8278	2.0157	2.0851	2.0814	1.9753	.0724	.061
15	1.8435	1.6827		2.0814	2.0119	.061	
16	1.7236	1.7528		1.957	2.0119	.0686	.088
17		1.8404		1.829	1.7013	.0686	.084
18		1.7337	1.9366	1.6827	1.8267	.104	.088
19	1.5238	1.5432	1.829	1.8099	1.8267	.108	.1665
20	.1286	.1097	.1701	.1701	.1612	.1174	.1783
21	.1172	.12	.1263	.1376	.1475	.1067	.1311
22	.1219	.1086	.1134	.1166	.1158	.1105	.1393
23	.1067	.1014	.1029	.0914	.0869	.105	.1198
24	.1052	.1029	.1029	.084	.0838	1.2489	1.267
Max	1.8435	2.0332	2.1765	2.0814	2.0119	1.8473	2.0328
Min	.08	.1014	.0914	.0686	.0789	.061	.061
Avg	.5751	.6955	.5830	.6708	.7076	.6504	.7107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 201 / 11 KV Khadamba

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.8833	1.0059	1.6095	1.6667	1.39	.3768	.3506
Max	.8833	1.0059	1.6095	1.6667	1.39	.3768	.3506
Min	.8833	1.0059	1.6095	1.6667	1.39	.3768	.3506
Avg	.8833	1.0059	1.6095	1.6667	1.39	.3768	.3506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 204 / 11 KV Gunjale

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5344	.7087	.7865	.6447	.5487	.3467	.3048
Max	.5344	.7087	.7865	.6447	.5487	.3467	.3048
Min	.5344	.7087	.7865	.6447	.5487	.3467	.3048
Avg	.5344	.7087	.7865	.6447	.5487	.3467	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 205 / Gunjale GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4641	.7164	.5788	.4557	.4694	.5304	.6001
Max	.4641	.7164	.5788	.4557	.4694	.5304	.6001
Min	.4641	.7164	.5788	.4557	.4694	.5304	.6001
Avg	.4641	.7164	.5788	.4557	.4694	.5304	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 206 / Kukkadvedhe GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1848	.1928	.2075	.2614	.1638	.2012	.2218
Max	.1848	.1928	.2075	.2614	.1638	.2012	.2218
Min	.1848	.1928	.2075	.2614	.1638	.2012	.2218
Avg	.1848	.1928	.2075	.2614	.1638	.2012	.2218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 207 / Morewadi Ag

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1928	.2374	.2353	.1829	.1783	1.3253	1.0669
Max	.1928	.2374	.2353	.1829	.1783	1.3253	1.0669
Min	.1928	.2374	.2353	.1829	.1783	1.3253	1.0669
Avg	.1928	.2374	.2353	.1829	.1783	1.3253	1.0669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 208 / Katrad Ag

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.9145	1.1641	1.3817	1.0802	.3222	.3429
Max	.9145	1.1641	1.3817	1.0802	.3222	.3429
Min	.9145	1.1641	1.3817	1.0802	.3222	.3429
Avg	.9145	1.1641	1.3817	1.0802	.3222	.3429



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 209 / 11 Kv Gorakshanath LIS PURELY LIS FEEDERS  
Satge Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
24	.0709
Max	.0709
Min	.0709
Avg	.0709

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 201 / Mokalohal

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524		.1949	.1629	
2				.1949	.1629	
3				.1629	.1646	
4		.4108			.1646	
5					.2402	
7						2.3777
8		.4108				2.6871
9			.3734			
10			.2267			
11			.1833			
12		2.5263	2.6882			
13			2.8826			
14			1.8187			
15			2.6882			
16		2.5911			2.7282	.1402
20		.2606				
23	.1619		.1915			.2347
24				.1886	.1595	1.5242
Max	.1619	2.5911	2.8826	.1949	2.7282	2.6871
Min	.1619	.1524	.1833	.1629	.1595	.1402
Avg	.1619	1.0587	1.3816	.1853	.5404	1.3928

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 202 / Umbre

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6289		1.4043	1.4373	
2				1.3935	1.4529	
3					1.5061	
4		1.6804			1.4899	
7						.2743
8		2.584				.2801
9			2.1033			
10			.1799			
11			.1219			
12		.0671	.0829			
13			.108			
14			.0907			
15			.1027			
16		.108				2.0165
20		.257				
23	.1646		.1509			.132
24				1.4043	1.4198	.1067
Max	.1646	2.584	2.1033	1.4043	1.5061	2.0165
Min	.1646	.0671	.0829	1.3935	1.4198	.1067
Avg	.1646	1.0542	.3675	1.4007	1.4612	.5619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 203 / Bramhani

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.2896	.4588	
2			.2881	.4752	
3				.4973	
4	.2286			.5144	
7					2.7606
8	.6043				3.4743
12	3.2057	3.3133			
13		3.1893			
14		2.733			
16	3.1007				.1677
20	.4611				
23		.3041			.2599
24			.3185	.254	1.8861
<b>Max</b>	<b>3.2057</b>	<b>3.3133</b>	<b>.3185</b>	<b>.5144</b>	<b>3.4743</b>
<b>Min</b>	<b>.2286</b>	<b>.3041</b>	<b>.2881</b>	<b>.254</b>	<b>.1677</b>
<b>Avg</b>	<b>1.3048</b>	<b>2.3849</b>	<b>.2987</b>	<b>.4399</b>	<b>1.7097</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 204 / Chedgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4006		2.268	2.3525	
2				2.268	2.3525	
3					2.1773	
4		2.6244			2.4272	
7						.2515
8		3.5639				.2294
9			2.914			
10			.2467			
11			.1263			
12		.152	.136			
13			.1065			
14			.1065			
15			.104			
16		.1557				3.6713
20		.2679				
23	.2058		.1677			.1372
24				2.268	2.2916	.1524
Max	.2058	3.5639	2.914	2.268	2.4272	3.6713
Min	.2058	.152	.104	2.268	2.1773	.1372
Avg	.2058	1.5274	.4885	2.268	2.3202	.8884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 205 / Bramhani GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029		.1132	.1132	
2				.1132	.1132	
3					.112	
4		.1715			.112	
7						.2915
8		.2829				.2829
9			.2218			
10			.1865			
11			.1478			
12		.1494	.1307			
13			.1494			
14			.1494			
15			.1294			
16		.132				.1646
20		.2218				
23	.12		.112			.1307
24				.1132	.1132	.1029
Max	.12	.2829	.2218	.1132	.1132	.2915
Min	.12	.1029	.112	.1132	.112	.1029
Avg	.12	.1768	.1534	.1132	.1127	.1945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 206 / Mokalohal GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715		.1698	.1698	
2				.1698	.1698	
3					.1384	
4		.1886			.1494	
7						.2229
8		.1886				.2452
9			.2829			
10			.2103			
11			.1848			
12		.1646	.1905			
13			.1886			
14			.1478			
15			.1905			
16		.1886				.1886
20		.2195				
23	.1715		.1867			.2218
24				.1905	.1905	.1886
Max	.1715	.2195	.2829	.1905	.1905	.2452
Min	.1715	.1646	.1478	.1698	.1384	.1886
Avg	.1715	.1869	.1978	.1767	.1636	.2134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 201 / Jambhali

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.3472	2.1534	2.0481	.1357	
2			2.3472	2.1795	2.0972	.12	.0867
3			2.3472	2.2801	2.13	.12	.0676
4			2.3807	2.3205	2.3102	.1214	.0829
5			2.6658	2.3807	2.4577	.1227	.0886
6			2.6155	2.3922	2.8182	.124	.1075
7			2.7664	2.967	2.9001	.1357	.0914
8	2.6046		.7202	2.8344	3.2278	.12	.0848
9			.7202	2.8509	2.0645	.0914	.1036
10				.2785		.1734	.1658
11		.08		.1802		.0655	.1475
12				.1147	.0122	3.4808	3.3261
13				.1147	.1174	3.2487	3.2769
14				.1147	.1149	3.3316	3.2278
15				.1147	.0766	3.2322	1.6712
16	.1147			.1147	.0974	3.2023	3.2985
17				.1147	.0894	2.8837	3.2985
18		.0814		.1147	.1067	2.9673	3.1459
19				1.8679	.14	3.0011	2.5396
20				.2458	.1524	.1313	.2949
21			.1219	.2294	.1619		.2785
22		.1212	.0914	.2294	.1787	.1189	.2622
23	.1147	.0823	.0753	.1475	.1738	.093	.1638
24	1.9989	2.0972	2.0119	1.861	1.8842	.12	
Max	2.6046	2.0972	2.7664	2.967	3.2278	3.4808	3.3261
Min	.1147	.08	.0753	.1147	.0122	.0655	.0676
Avg	1.2082	.4924	1.6316	1.1751	1.1527	1.1800	1.1732



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 202 / Kuranwadi

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0629	.044	.0754	.3616	
2			.0638	.044	.0754	.4144	1.0208
3			.0629	.0429	.0754	.3868	1.0848
4			.0629	.0648	.0943	.3894	.9587
5			.0697	.0619	.1132	.4172	.9084
6			.0814	.0732	.1509	.4816	1.086
7			.093	.0354	.1509	.7773	1.3032
8	.1402		.1052	.0619		.7587	2.1338
9			.1402	.0686	.2054	1.6099	1.708
10		.1663		.1698	.1254	.0554	.132
11		.1663		.1132	.0714	.0554	.0876
12			.6325	3.5837	1.9113	.0474	.1132
13			.9981	3.3008	1.39	.0474	
14			.2949	3.2253	1.9071	.0503	
15			1.2308	3.1499	1.5975	.0503	
16	3.4517		.2949	3.4517	1.829		
17			.4725	3.4328	1.9547	.0549	
18		1.391	.0295	3.3951	1.3605	.128	.0943
19			.0869	2.8481	1.8896	.12	.3018
20			.0714	.2075	.0977	.1629	.2641
21			.088	.1698	.1086		.1886
22		.1448	.061	.1698	.1433	.1509	.1698
23	.1132	.0724	.04	.1132	.0983	.0867	.1132
24	.0347	.0943	.0638	.0429	.0754	.5994	
Max	3.4517	1.391	1.2308	3.5837	1.9547	1.6099	2.1338
Min	.0347	.0724	.0295	.0354	.0714	.0474	.0876
Avg	.9350	.3392	.2321	1.1613	.6739	.3275	.6864

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 204 / Chinchale GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0373	.0566	.052	.0549	.0185
2			.0373	.0543	.052	.0549	.0187
3			.0373	.0549	.052	.0549	
4			.056	.0554	.052	.0549	
5			.0377	.0543	.052	.0549	.0181
6			.0377	.0554	.052	.0554	.0187
7			.056	.0732	.0693	.0724	.0183
8	.0747		.0549	.0876		.0886	.0351
9			.0509	.0724	.0937	.088	.044
10		.0655	.052	.0867	.08	.0474	.052
11			.0543	.052	.0526	.0474	.0526
12			.0537	.052	.004	.048	.0566
13			.0543	.052	.052	.0469	.052
14			.0543	.052	.0514	.0497	.052
15				.052	.0514	.0497	.052
16	.052		.0532	.052	.0514		.052
17			.0537	.052	.0655	.0156	.052
18		.0625	.081	.052	.0633	.0316	.104
19			.096	.104	.0974	.0312	.104
20			.0995	.104	.0564	.0162	.104
21			.0754	.0867	.0564		.0693
22		.0549	.056	.0554	.0693	.0168	.0693
23	.052	.056	.056	.052	.0549	.0181	.0693
24	.056		.0377	.0566	.052	.0549	
Max	.0747	.0655	.0995	.104	.0974	.0886	.104
Min	.052	.0549	.0373	.052	.004	.0156	.0181
Avg	.0587	.0597	.0557	.0636	.0580	.0478	.0530

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 205 / Nandur GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2054	.1698	.1698	.2054	
2			.2054	.1698	.1698	.2054	.2054
3			.2054	.2054	.1698	.2054	.2054
4			.2054	.2054	.2263	.2054	.2033
5			.2427	.2801	.2829	.2054	.2641
6			.3206	.3584		.3395	.3395
7			.4481	.4527	.1509	.4338	.4715
8	.4024		.462	.4481	.4904	.4294	.4481
9			.4024	.4251	.3982	.4024	.3511
10			.3506	.2915	.2896	.2772	.2926
11		.2254	.2601	.2229	.2427	.2401	.2401
12			.2774	.2195	.2172	.2427	.2149
13			.2103	.181	.181	.1753	.197
14			.1991	.1829	.2172	.2303	.1949
15			.1991	.1829	.2012	.1949	.2103
16	.2454		.2126	.1829	.1791	.181	.2401
17		.2103	.2279	.197	.2804	.2254	.2401
18		.2427	.394	.2686	.2804	.3189	.298
19			.4656	.4163	.4163	.4344	.4681
20			.4344	.439	.3658	.4435	.5121
21			.3658	.3511	.3658		.3801
22		.2926	.2829	.2743	.3109	.2957	.3292
23	.2241	.2195	.2012	.2218	.2378	.2378	.2402
24	.2195	.2054	.2033	.1698	.1698	.2054	.1848
Max	.4024	.2926	.4656	.4527	.4904	.4435	.5121
Min	.2195	.2054	.1991	.1698	.1509	.1753	.1848
Avg	.2729	.2327	.2909	.2715	.2614	.2754	.2926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 206 / 11 Kv Hanumanwadi Ag

SHEDDABLE RURAL

Feeder KV- 11 / INCOMING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0251	.012	.012	3.7072	
2			.0251	.0131	.0126	3.6752	1.7465
3			.0251	.0177	.0131	3.6774	1.7072
4			.0251	.0171	.0114	3.5528	1.7238
5			.0114	.0177	.0109	3.5768	1.7772
6			.0114	.0177		3.4285	1.8482
7			.0221	.0177	.029	3.7829	2.0748
8	.0572		.0048	.0149	.0137	4.2772	2.2977
9			.0091	.0023	.0754	4.2574	1.9113
10			.0076	.0907	.0629	2.4257	.0572
11		.0671	.0251	.0842	.0472	.2538	.0427
12			2.1704	2.2462		.2395	.013
13			2.2382	2.3908	2.3908	.0551	.0168
14			2.3405	2.4926	2.2977	.0598	.0267
15				2.4756	2.3739	.0612	.0206
16	2.3491		2.0178	2.4348	2.332	.0675	.0248
17			2.2043	2.3061	2.4348	.0653	.0248
18		2.1874	2.0348	2.2043	2.3834	.0657	.0114
19			1.9669	2.0687	2.1874	.061	
20			.0181	.0857	.2915	.2414	.1029
21			.024	.072	.2743	.2393	.1004
22		.0686	.0171	.0886	.0743	.2852	.0914
23	.1475	.0427	.0097	.0686	.0732	.2951	.0768
24	.061	.0377	.0293	.0109	.0267	3.3828	1.5581
Max	2.3491	2.1874	2.3405	2.4926	2.4348	4.2772	2.2977
Min	.0572	.0377	.0048	.0023	.0109	.0551	.0114
Avg	.6537	.4807	.6636	.8021	.7922	1.7389	.7843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014143 / BABHULGAON

Feeder No / Name : 202 / VARVANDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.8185	.2846	.2846
2				1.9608	1.8185	.2846	.2846
3				1.9766	2.625	.3005	.2846
4				2.0399	1.8818	.3163	.3005
5				2.1822	2.1032	.3321	.3163
6				2.2455	2.3245	.3479	.3321
7			.8697	2.5459	2.625		.3479
8				2.6408	2.5934	.3637	.3163
9	1.8976	2.6882		2.198	2.4985	.3479	
10	.2372	.2372	2.1822	.2372	.2688		
11	.1898	.2214	.2688	.2372	.2688		
12	.1107	.0949	.3005	.3005	.3005		
13	.0949	.1107	.3005	.2688	.3005		
14	.0949		.3005	.3005	.3005		
15	.0949	.3163	.2846		.3005		
16	.1107	.3321	.2846	.3584	.3005		2.8464
17							2.9571
18							2.7989
19							2.6566
20					.2688		.2688
21			.2688				.253
22							.2372
23							.2688
24					1.7553	.2846	.3163
Max	1.8976	2.6882	2.1822	2.6408	2.625	.3637	2.9571
Min	.0949	.0949	.2688	.2372	.2688	.2846	.2372
Avg	.3538	.5715	.5622	1.3923	1.3529	.3180	.8865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014143 / BABHULGAON

Feeder No / Name : 203 / Khadakwadi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0566	.0566	.0566
2		.0566	.0566	.0566	.0566
3		.0566	.0566	.0566	.0566
4		.0566	.0566	.0566	.0566
5		.0633	.0754	.0754	.0566
6		.0943	.1132	.0943	.0754
7	.0754	.132	.132		.132
8		.1132	.1132	.132	.132
9			.1132	.1132	
10			.0943	.1509	
11	.0754		.0754		
12			.0566		.0377
16			.0566		.0566
20			.132		
21	.0943				
24			.0566	.0566	
Max	.0943	.132	.132	.1509	.132
Min	.0754	.0566	.0566	.0566	.0377
Avg	.0817	.0818	.0830	.0849	.0717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014143 / BABHULGAON

Feeder No / Name : 204 / 11 Kv Gorakshanath LIS

PURELY LIS FEEDERS

Stage - Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0603	.059	.0592	.059	.1158	.1163	.115
2	.0603	.0588	.059	.1156	.1159	.1164	.1152
3	.0603	.0589	.0589	.1154	.1155	.1161	.1161
4	.0602	.0589	.059	.1156	.1154	.1162	.1165
5	.061	.0597	.0596	.116	.1162	.1163	.1167
6	.0627	.0605	.0603	.1175	.1176	.1167	.1174
7	.0617	.0619	.1183	.1193	.1203	.0607	.1183
8	.0634	.0607	.0618	.1195	.1199	.1186	.1188
9	.062	.0596	.0597	.1173	.1187	.1181	.0619
10	.0581	.0581	.0584	.0588	.1155	.1157	.0594
11	.0582	.0578	.1157	.0585		.0588	.0589
12	.062	.0627	.0612	.0626	.1239	.0651	.1183
13	.0607	.062	.0609	.0607	.0645	.0642	.0615
14	.0605	.061	.0607	.061	.0623	.0618	.06
15			.0602		.0614		
22	.0485		.0536	.0357	.0361	.0515	.0296
23	.0577	.0586	.0588	.0594	.0599	.0593	.0596
24	.0589	.0598	.0597	.0595	.117	.1122	.1182
Max	.0634	.0627	.1183	.1195	.1239	.1186	.1188
Min	.0485	.0578	.0536	.0357	.0361	.0515	.0296
Avg	.0598	.0599	.0658	.0854	.0998	.0932	.0918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014143 / BABHULGAON

Feeder No / Name : 205 / 11 Kv NDDB Dairy

Feeder KV- 11 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	17-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.0754	
7	.0754			
8			.0943	
9			.0754	
10			.1132	
11	.1132			
12		.0754		.0943
Max	.1132	.0754	.1132	.0943
Min	.0754	.0754	.0754	.0943
Avg	.0943	.0754	.0896	.0943



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 201 / VADALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0886	.0886	.0886	.0886	1.4937	1.4632
2		.0886	.0886	.0886	.0886	1.5546	1.4937
3		.0886	.1063	.0886	.0886	1.5546	1.5851
4		.1063	.1063	.1063	.1063	1.6461	1.6766
5		.1417	.124	.1063	.1227	1.7158	1.89
6		.1578	.1578	.1227	.1402	1.9913	2.0119
7		.1753	.1578	.1402	.2103	2.2885	2.774
8		.1578		.1578		2.8235	2.9573
9	.1402					3.4751	3.1367
10	.1227	.1227	.1227	.128	.1646	.1097	.1402
11	.1052	.1052	.12	.128	.1646	.1097	.1052
12	2.9424	2.6825	2.6698	3.457	3.4751	.0732	
13	3.0788	2.8654	2.6216	3.3288	3.5117		
14	3.0316	2.8807	2.9264	3.8043			
15	3.1093	2.7641	2.8959	3.4751			
16	3.1093	2.652	2.9264	3.4019			
17	3.6031	3.1276	3.4751	3.1093	3.2922		
18	3.1093	3.1093	3.2922	3.3653	3.3471		
19	2.5972	2.4326	2.9995	3.1459	2.9447		
20	.1646		.1829	.1928	.1753		.1753
21				.1753	.1753	.1753	.1578
22				.1578	.3506	.1543	.2103
23					.1753	.125	.1402
24		.1227	.1052	.1063	.1063	1.4842	1.4685
Max	3.6031	3.1276	3.4751	3.8043	3.5117	3.4751	3.1367
Min	.1052	.0886	.0886	.0886	.0886	.0732	.1052
Avg	2.0928	1.2563	1.3246	1.3125	.9857	1.2984	1.3366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 202 / GONDEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6221	1.6057	1.7532	1.8187	.1753	.1753
2		1.6712	1.6385	1.8187	1.9498	.1715	.1928
3		1.7859	1.7532	1.8842	2.0809	.1928	.2103
4		1.7652	1.9271	1.9433	2.1052	.3506	.3155
5		1.8947	2.1052	2.0081	2.251	.3429	.3856
6		3.0727	2.4129	2.251	2.5749	.4801	.5959
7			2.7046	2.8988	3.2007	.5487	.583
8		3.6008	3.5528	3.5848	3.7609		
9	2.6673	3.3608		3.658	3.0727	.439	
10	.1715	.2401	.2058	.1829	.2195	.2195	.1772
11	.1715	.2103	.2401	.2195	.2378	.2561	.1578
12	.2743	.2804	.2103	.1829	.2378	3.9872	3.2388
13		.1928	.2058	.2012	.2561	4.0787	3.4008
14		.1886	.1715			3.9872	3.6808
15		.1753	.1715		.2561	3.9323	
16		.2058	.1886	.1829	.2378	4.2433	
17		.2195	.1463		.2926	3.195	3.6008
18	.2195	.2195	.1829	.2195	.3292		3.5627
19	.2743	.1829	.2195	.1463	.4024		3.2226
20	.2926		.2195	.2103	.4287		.2279
21				.2103	.3429	.3155	.2454
22				.1928	.3506	.2804	.2103
23					.2454	.2454	.1928
24		1.5893	4.7572	1.704	1.7859	.1753	.2103
Max	2.6673	3.6008	4.7572	3.658	3.7609	4.2433	3.6808
Min	.1715	.1753	.1463	.1463	.2195	.1715	.1578
Avg	.5816	1.1830	1.2310	1.2726	1.2364	1.3808	1.2293

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 203 / Sutgirani Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8328	.691	.7087	.8238	1.0082	.8962
2		.8859	.7442	.7973	.8859	.9709	.8589
3		.9745	.8328	.8682	.9214	.0747	.9055
4		1.0985	.9745	.9391	1.0454	1.1203	1.2136
5		1.1744	1.0867	1.0631	1.1744	1.2437	1.4998
6		1.3146	1.3146	1.3146	1.3847	1.5364	1.6644
7		1.6297	1.543	1.56	1.7878	1.9004	1.8804
8		2.1209	1.8176	2.0111	2.2018	2.3045	2.2923
9	2.0538	1.9281	1.8446	2.1582	1.9765	2.2497	1.9982
10	1.7924	1.7924	1.7741	1.8473	1.8107	1.9022	1.5777
11	1.7187	1.6461	1.6632	1.6095	1.8656	1.829	1.7002
12	1.8665	1.7187	1.7177	1.6827	1.829	1.7741	1.5775
13	1.7924	1.6632	1.6644	1.4784	1.7741	1.701	1.5775
14	1.643	1.5203	1.5181	1.4784	1.7375	1.6644	
15	1.4632	.2561	1.5364	1.5364	1.6644	1.5729	
16	1.4998	1.4632	1.4449	1.5546	1.7741	1.6095	1.7337
17	1.6095	1.6095	1.7741	1.6461	1.8656	1.829	1.8204
18	1.7558	1.6461	1.4998	1.8107	1.9387	1.829	1.9418
19	1.8473	1.8473	1.8473	2.0668	1.9204		1.9105
20			1.7741	1.7528	1.7187		1.8404
21				1.5777	1.5708	1.6244	1.6461
22				1.4373	1.7364	1.3817	1.5154
23					1.587	1.2696	1.363
24		.8859	.9134	.8859	.9114	1.2136	.9709
Max	2.0538	2.1209	1.8473	2.1582	2.2018	2.3045	2.2923
Min	1.4632	.2561	.691	.7087	.8238	.0747	.8589
Avg	1.7311	1.4004	1.4275	1.4689	1.5794	1.5277	1.5629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 204 / 11 kv DIGHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0701	.0886	.0886	.0886	.0732	.0549
2		.0709	.0886	.0895	.0886	.0549	.0549
3		.0886	.1063	.1063	.1063	.0732	.0732
4		.1063	.1063	.124	.1063	.0914	.0914
5		.124	.1227	.1417	.124	.1463	.1463
6		.1753	.1402	.1578	.1753	.1829	.2012
7		.2254	.1928	.1928	.2279	.2353	.2561
8		.2279	.2279	.2103	.2103	.1829	.2195
9	.1646	.1928		.1829	.1753		.1595
10	.1075	.1463	.128	.128	.1646	.2194	.124
11	.0914	.1254	.128	.128	.1097	.1097	.1063
12		.1097	.0895	.0914	.0914	.0914	
13	.0732	.0914	.0914	.0914	.0732	.1464	
14	.0732	.0716	.0914	.0732	.0732	.0739	
15	.0732	.0716	.0732	.0732	.0732	.0732	
16	.0914	.0732	.0732	.0732	.0914	.0732	.1052
17	.128	.0732	.0732	.0732	.0914	.0914	.0709
18	.128	.0914	.1097	.0732	.1097		.124
19	.1463	.1463	.1646	.1463	.1463		.2126
20	.1646		.1829	.1417	.1463		.1753
21				.124	.1463	.1463	.1463
22				.1063		.1097	.128
23					.0914	.0914	.0914
24		.0701	.2498	.0886	.2349	.0732	.0732
Max	.1646	.2279	.2498	.2103	.2349	.2353	.2561
Min	.0732	.0701	.0732	.0732	.0732	.0549	.0549
Avg	.1129	.1176	.1264	.1176	.1281	.1170	.1307

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 205 / 11KV SUBHEDAR WASTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6024	.691	.6447	.691	.695	.695
2		.6556	.7087	.6984	.7087	.7133	.695
3		.7442	.7442	.7164	.7442	.7682	.7316
4		.8682	.8328	.7701	.8238	.8779	.8779
5		.9745	.929	.8328	.964	.9877	.9412
6		1.0867	1.0985	.9745	1.0692	1.086	1.086
7		1.3672	1.2403	1.0985	1.2971	1.3717	1.4632
8	1.5181	1.3847	1.4373	1.2269	1.5074		1.4685
9	1.4266	1.4022	1.5912	1.2986	1.4899	1.2803	1.3289
10	1.2254	1.1523	1.3352	1.0608	1.2254	1.1706	1.0985
11	1.262	1.1888	1.3717		1.2803	1.1706	.9922
12	.9877	1.0425	1.2254	.9145	1.134	.9145	.9568
13	.8596	.2454	1.1706	.9328	1.0425	.8413	.8682
14	.7316	.7682	.695	.7316	.9511	.7865	
15	.7316	.7499	.6219		.7499	.7133	
16	.7316	.6767	.6401		.7682	.6584	.9214
17	.7682	.7316	1.7741	.7316	.823	.7865	.7973
18	.8962	.8413	.8962	.8413	.9145	3.0316	.8505
19	1.0608	1.0242	1.0425	1.0059	1.0608		.985
20	1.0425		1.0608	1.1104	1.0608		1.1163
21				1.0277	.9694	1.0242	1.0425
22				.9114	1.0608	.9511	.961
23					.9694	.8048	.8131
24		.6556	.6556	.6805	.691	.7207	.7282
Max	1.5181	1.4022	1.7741	1.2986	1.5074	3.0316	1.4685
Min	.7316	.2454	.6219	.6447	.691	.6584	.695
Avg	1.0186	.9081	1.0363	.9105	.9999	1.0169	.9736

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 206 / WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5939	1.6118	1.5939	1.97	1.5089	1.5432
2		1.7013	1.6834	1.6834	1.8446	1.5261	1.5604
3		1.7909	1.8446	1.773	1.9521	1.5432	1.6118
4		1.9879	1.9521	1.9163	2.0376	1.5939	1.6804
5		2.2502	2.0595	2.0376	2.2502	1.8313	1.8519
6		2.392	2.2857	2.2857	2.4806	2.1704	2.1948
7		2.8746	2.516	2.5766	2.7869	2.8147	2.9664
8		2.7641	2.9973	2.8921	2.9973	2.6063	2.9334
9	2.7801		2.7263	2.8349	2.8395	2.6337	2.7168
10	2.4417	2.4348	2.4177	2.3228	2.6155	2.5423	2.1735
11	2.3739	2.3061	2.332	2.3228	2.2862	2.524	2.3137
12	2.1195	2.0008	2.0062	.2012	2.3777	2.1948	2.1262
13	2.0233	2.0302	2.0008	2.1582	1.8656	2.1033	2.0376
14	1.7833	1.7126	1.7465	1.9387		1.9753	
15	1.7661	1.6617	3.2217	1.9204	1.7375	1.829	
16	1.6804	1.6975	1.6617	1.957	1.8107	1.9387	2.3565
17	1.8656	1.9204	1.829	1.9936	1.9204	1.8652	2.1794
18	2.1948	2.0119	2.1948	2.0119	1.9936	.3155	2.2857
19	2.4326	1.8473	2.524	2.4326	2.3594		2.3819
20	2.3777		2.5972	2.3282	2.2805		2.489
21				2.2386	2.0405	2.1776	2.2634
22				2.1794	2.2805	1.8861	2.0348
23					2.0405	1.8004	1.7974
24		1.6476	1.6118	1.5939	1.7372	1.5432	1.5775
Max	2.7801	2.8746	3.2217	2.8921	2.9973	2.8147	2.9664
Min	1.6804	1.5939	1.6118	.2012	1.7372	.3155	1.5432
Avg	2.1533	2.0329	2.1819	2.0519	2.1959	1.9511	2.1398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 207 / 11 KV Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0905	.0724	.0366	.0724	.0747	.0732
2		.0905	.0724	.0366	.0724	.0747	.0739
3		.1254	.1267	.0366	.0905	.0732	.0747
4		.1612	.1267	.0366	.0905	.112	.1463
5		.1791	.1612	.0362	.1267	.2012	.1829
6			.1791	.0362	.1991	.2195	.2195
7		.3045	.2328	.0362	.2865	.2353	.2561
8		.2507	.2149	.0366	.1991	.2172	.2715
9	.2033	.2353	.2195	.0366	.1991	.2195	.2715
10	.2012	.2195	.2012	.0366	.2012	.2195	.2172
11	.2054	.2561	.2033	.0366	.3109	.2743	.2686
12	2.1195	.2561	.1848	.0366	.2926	.1646	.3077
13	.2012	.2402	.1478	.0366	.2743	.2561	.2715
14	.2054	.2378	.1848	.0366	.2195	.2378	
15	.2561	.2561	.2454	.0366	.1829	.2195	
16	.2218	.2561	.1109	.0366	.2012	.2195	.2896
17	.2195	.2378	.2378	.1463	.1829	.2378	.3077
18	.2195	.2012	.2195	.2012		.1463	.3077
19	.2195	.2012	.1829	.2195	.2012		.2561
20	1.0425		.0366	.181	.2054		.2172
21				.181	.2241	.2195	.2195
22				.1063	.2012	.2012	.2195
23					.2241	.1829	.2195
24		.1267	.1267	.0362	.0905	.0934	.0934
Max	2.1195	.3045	.2454	.2195	.3109	.2743	.3077
Min	.2012	.0905	.0366	.0362	.0724	.0732	.0732
Avg	.4429	.2066	.1661	.0720	.1891	.1864	.2166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 208 / SHIRSGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1612	.1595	.1595	.1595	.1646	.181
2		.1612	.1772	.1772	.1595	.1646	.1791
3		.1772	.1949	.1772	.1949	.1829	.2195
4		.1949	.2303	.1949	.2629	.2195	.2507
5		.2481	.3012	.333	.333	.3292	.3506
6		.333	.4031	.4031		.3856	.4031
7		.5258	.4382	.4382	.4207	.4733	.4207
8		.4382	.5083	.4557	.4908	.4733	
9	.4031	2.7995	.4031	.4207	.4207	.4207	.4075
10	.333	.333	.3155	.3658	.1646	.3292	
11	.3506	.3155	.3155	.3109	.2743	.3109	.2835
12	.2629	.2629	.2629	.2561	.2378	.2561	.2481
13	.2454	.2454	.2454	.2378	.2561	.2926	.2303
14	.2454	.2103	.2454	.2561		.2926	.333
15	.2629	.2279	.2454	.2743	.2561	.3109	
16	.2629	.2629	.2804	.2743	.2743	.3292	
17	.2926	.2926	.2926	.3109	.2926	.333	.3155
18	.3658	.3109	.3658	.3292	.3109		.2658
19	.4207	.2012	.4207	.3841	.3658		.3366
20	.3841		.3841	.3582	.333		.3721
21				.3366	.333	.3681	.333
22				.3012	.333	.3224	.2865
23					.333	.2454	.2507
24		.1791	.1772	.1949	.1949	.1829	.2103
Max	.4207	2.7995	.5083	.4557	.4908	.4733	.4207
Min	.2454	.1612	.1595	.1595	.1595	.1646	.1791
Avg	.3191	.3940	.3032	.3022	.2910	.3041	.2939



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 201 / 11 Kv Kesapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1475	.1311	.1311	.1311	.1311		1.3927
2				.1311	.1311		1.3927
3		.1147	.1147	.1475	.1475		1.4255
4			.1147		.1966		
5	.2294	.1638			.2458		
6	.2785		.2622				
8						1.8187	
9						1.7859	1.7368
10			.1802	.1475	.1802	.1147	1.0322
11			.1311	.1311	.1309	.0983	.0819
12	2.13		1.9662	1.9662	1.8842		
13			2.0809	2.0481	1.9334		
14	1.9498		2.0481	2.1956	2.0481		
15			1.9826	1.7695	1.9498		
16	2.0645		1.9989	1.9334	1.9334		
17		1.9334	1.7368		2.0972		
18	1.8023				1.8351		
19	1.8351	1.5565	2.0153	1.6712	1.4582		
20					.1638	.2294	.2294
21		.2785	.1638	.1966	.1802	.2294	.2294
22					.1638	.1802	.2294
23	.1311		.1638	.1475	.1311	.1638	.1638
24	.1475	.1311	.1147	.1311	.1311	1.2289	1.3927
Max	2.13	1.9334	2.0809	2.1956	2.0972	1.8187	1.7368
Min	.1311	.1147	.1147	.1311	.1309	.0983	.0819
Avg	1.0716	.6156	.9503	.9105	.8536	.6499	.8460

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 203 / 11 KV CHANDEGAON AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5402	1.7814	1.7287	1.6842	1.6842		
2				1.7004	1.7166		.1457
3		1.7166	1.6518	1.749	1.7652		.1457
4			1.8138		1.7814		
5	1.6221	1.9433			1.7976		
6	1.6221		1.7004		1.8138		
7					2.2283		
8	2.1792	2.0405			2.2024		
9		2.1628	2.0405		2.0891		
10			.1619	.1619	.184	.1943	.1943
11			.0972	.0972	.1134	.1296	.1134
12						2.5101	2.2024
13						2.4453	2.1538
14						2.2024	
15						2.1214	
16						2.2024	2.2996
17						2.1052	2.2996
18						2.17	2.4453
19						1.9433	2.0081
20					.2591	.2105	.2267
21		.2267	.2591	.2267	.2429	.2031	.2429
22					.2267	.1781	.2267
23	.1638		.1619	.1943	.1943	.1781	.1718
24	1.5074	1.7368	1.6032	1.668	1.668	.1619	.1457
Max	2.1792	2.1628	2.0405	1.749	2.2283	2.5101	2.4453
Min	.1638	.2267	.0972	.0972	.1134	.1296	.1134
Avg	1.4391	1.6583	1.1219	.9352	1.2479	1.2637	1.0014

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 204 / 11 KV MALUNJA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662	1.8343	1.8343	1.9204	1.9989		.1949
2				2.0481	2.0481		.2096
3		1.7711	1.8027	2.0485	2.0972		.2286
4			2.0645		2.1464		
5	2.0405	2.0645			2.2119		
6	2.3158		2.2447		2.2611		
7					3.0312		
8	2.7854	2.8166	2.8346		2.982		
9	2.6707	2.2725	2.8346		2.6216		
10			.2477	.2286	.2286	.2286	
11			.1905	.1905	.1905	.2286	
12						3.0445	3.2388
13						3.1903	3.2874
15						2.753	
16						2.9312	3.0607
17						3.1903	3.0607
18						3.0769	3.2388
19						2.753	2.7854
20					.298	.2804	.3155
21		.2858	.2743	.2858	.2804	.2804	.3366
22					.2667	.2804	.2835
23	.2667		.2401	.2667	.2667	.2454	.2303
24	2.6707	1.7711	1.7869	1.9204	1.9662	.2096	.1928
Max	2.7854	2.8166	2.8346	2.0485	3.0312	3.1903	3.2874
Min	.2667	.2858	.1905	.1905	.1905	.2096	.1928
Avg	2.1023	1.8308	1.4868	1.1136	1.5560	1.6209	1.4760

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 205 / 11 KV BELAPUR TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3761	.394	.394	.4477	.4477		
2				.4477	.4477		.4298
3		.3582	.394	.5014	.5014		.4656
4			.4656		.5552		
5	.4298	.4835			.6268		
6	.6984		.7522		.6805		
7					1.0029		
8	.985	1.0208	1.0924		1.0566	1.0924	
9		.9134	.9671		1.0029	.9313	.985
10			.9313	.7701	.9134	.8238	.8596
11			.7343	.6984	.788	.7522	.7343
12	.7701		.6268	.5731	.6626	.5552	.6089
13			.5373	.591	.6089	.5373	.591
14	.5731		.5014	.5552	.5731	.5552	
15			.5373	.5731	.591	.5731	
16	.6268		.5014	.788	.6626	.5731	.6984
17		.6268	.5552		.6626	.6984	.6805
18	.6984				.6805	.6805	.788
19	.7522	.7701	.8417	.8238	.8596	.8954	.8954
20					.8238	.8059	.788
21		.5075	.6984	.6805	.7522	.788	.788
22					.6447	.5731	.7701
23	.4656		.4835	.5014	.5373	.5373	.5731
24	.394	.3582	.394	.4477	.5014	.4119	.4477
Max	.985	1.0208	1.0924	.8238	1.0566	1.0924	.985
Min	.3761	.3582	.394	.4477	.4477	.4119	.4298
Avg	.6154	.6036	.6338	.5999	.6910	.6932	.6940

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 206 / 11 KV WALADGAON GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1334	.1334	.1334	.1334		.1063
2				.1334	.1334		.1143
3		.1143	.1143	.1334	.1334		.1143
4			.1524		.1524		
5	.1524	.1905			.1905		
6	.1905		.1905		.1905		
7					.2096		
8	.2477	.2286	.2286		.2286	.2686	
9	.2286	.2286	.2286		.2667	.3582	.2096
10			.1715	.2031	.1783	.2315	.2408
11			.1505	.1781	.0791	.2372	.2656
12	.2477		.1334	.2286	.2658	.2835	.1524
13			.1334	.2667	.1905	.2096	2.7401
14	.1905		.1334	.2286	.2835	.2477	
15			.1334	.2477	.2481	.1905	
16	.2667		.1147	.2096	.2686	.1334	.3048
17		.2096	.1334		.2507	.2286	.3048
18	.1715				.1791	.1715	.2477
19	.2477	.2286	.2096	.2096	.2507	.2667	.2477
20					.218	.2328	.2328
21		.1753	.1829	.2347	.1875	.2103	.1581
22					.1829	.1753	.1928
23	.1402		.1658	.1509	.1372	.1578	.1578
24	.128	.1143	.1143	.1334	.1174	.1524	.1227
Max	.2667	.2286	.2286	.2667	.2835	.3582	2.7401
Min	.128	.1143	.1143	.1334	.0791	.1334	.1063
Avg	.1952	.1804	.1569	.1922	.1948	.2209	.3478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 207 / 11 KV UKKALGAON GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2865	.2481	.2858	.2858		.2858
2				.2772	.2858		.2858
3		.2686	.2303		.2858		.2858
4			.3189		.3239		
5	.2858	.3696			.4191		
6	.4191		.4191		.4572		
7					.5716		
8	.5304	.5544	.5335		.5914	.5914	
9	.4024	.462	.4954		.4656	.499	.4066
10			.3547	.333	.3189	.333	.3391
11			.2743	.2915	.3189	.2481	.2572
12	.3012		.2658	.2481	.3258	.2481	.2865
13			.2686	.2481	.2686	.2686	.2353
14	.2481		.3048	.2667	.2507	.2126	
15			.2658	.2686	.2507	.2303	
16	.2865			.2835	.2667	.2865	.2507
17		.3224			.2865	.2303	.2507
18	.4344				.3403	.3366	.3224
19	.5249	.5014	.4938	.4119	.4477	.4784	.4119
20					.4298	.3898	.4344
21		.3658	.4024	.3292	.3544	.4024	.3658
22					.3258	.3292	.3582
23	.2865	.2561	.3224	.2926	.3045	1.7558	.2865
24	.2614	.2149	.2126	.2865	.2858	.2865	1.8099
Max	.5304	.5544	.5335	.4119	.5914	1.7558	1.8099
Min	.2452	.2149	.2126	.2481	.2507	.2126	.2353
Avg	.3522	.3602	.3382	.2941	.3526	.4192	.4043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 208 / 11 KV PADHEGAON GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2667	.2477	.2477	.2477		.2477
2				.2477	.2667		.2477
3		.2286	.2286		.2858		.2477
4			.3048		.3239		
5	.2858	.4001			.381		
6	.4382		.4572		.4382		
7					.5335		
8	.462	.4572	.4763		.5175	.5144	
9	.3658	.3881	.4001		.4477	.439	.4024
10			.3142	.333	.3012	.2915	.3391
11			.2629	.2947	.2835	.2572	.2713
12	.2481		.1791	.2658	.2658	.2572	.2507
13				.2686	.2715	.2149	.2172
14	.2481		.2587	.2427	.2353	.1905	
15			.2835	.3012	.2507	.2126	
16	.2686		.2865	.3012	.2829	.2481	.2896
17		.3224	.3366		.362	.3224	.4163
18	.362				.362	.3761	.3801
19	.4344	.4656	.3841	.4163	.4706	.4298	.4344
20					.362	.394	.4755
21		.3658	.4024	.3841	.3761	.3856	.4251
22					.3077	.3155	.4066
23	.2195	.2743	.2865	.2743	.2667	.3121	.2957
24	.2075	.2286	.2303	.2477	.2477	.2286	.2481
Max	.462	.4656	.4763	.4163	.5335	.5144	.4755
Min	.2075	.2286	.1791	.2427	.2353	.1905	.2172
Avg	.3123	.3397	.3141	.2942	.3370	.3170	.3291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 209 / 11 KV UKKALGAON Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524			.1524	.1524		1.4575
2				.1524	.1524		1.4899
3					.1524		1.5581
4					.1715		
5	.2096				.1905		
6	.2286				.2096		
8						2.0454	
9						1.8107	1.8564
10			.1334	.1524	.1524		
11			.1143	.1334	.1143		
12	2.536		1.8399	2.304	2.2542		
13			2.3371		2.2874		
14	2.4531		1.8399	2.2874	2.1879		
15			2.1628	2.3205	2.2377		
16	2.3868		2.2874	2.3703	2.1714		
17		2.2542	2.3537		2.0622		
18	2.1548				1.9113		
19	2.0553	1.989	.2286	1.9393	1.7101		
21			.2286	.2286			
23			.1715	.2096			
24	.1715			.1715	.1715	1.2163	1.4575
Max	2.536	2.2542	2.3537	2.3703	2.2874	2.0454	1.8564
Min	.1524	1.989	.1143	.1334	.1143	1.2163	1.4575
Avg	1.3720	2.1216	1.2452	1.0352	1.0758	1.6908	1.5639



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 210 / 11 KV RAMGAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.073	.9724	.9221	.9221	.1677	.1677
2				.9221	.9892		.1677
3		1.0395	.9389		1.0059		.1844
4			1.0395		1.1233		
5	1.0562	1.1401			1.1904		
6	1.1401		1.2407		1.2239		
7					1.5424		
8	1.576	1.7772	1.7604		1.6766		
9	1.5927	1.3435	1.5089		1.4754		
10			.1341	.1509	.1341	.1677	.1677
11			.1174	.0838	.1174	.1174	.1509
12						1.5592	1.6598
13						1.6095	1.5257
14						1.4083	
15						1.4251	
16						1.7269	1.7101
17						1.7101	
18						1.643	1.8107
19						.2347	1.5424
20					.2683	.2347	.2012
21		.218	.218	.2347	.2515	.2347	.2347
22					.218	.2012	.218
23	.1677	.1677	.1509	.1677	.1677	.1844	.1677
24	.9724	1.0395	.9389	.9054	.9054		.1677
Max	1.5927	1.7772	1.7604	.9221	1.6766	1.7269	1.8107
Min	.1677	.1677	.1174	.0838	.1174	.1174	.1509
Avg	1.073	.9748	.8200	.4838	.8257	.8416	.6718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 201 / BHOKAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
2	2.1445
3	2.1765
4	2.2085
24	2.1445
Max	2.2085
Min	2.1445
Avg	2.1685

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 202 / KAMALPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
2	.2721
3	.2721
5	2.2565
24	.2721
Max	2.2565
Min	.2721
Avg	.7682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 203 / 11 KV MALWADGAON  
(KHANAPUR) Feeder KV- 11 /  
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
1	.2812
3	.2881
4	.3041
5	.3041
6	1.7604
8	2.4646
9	2.5126
10	2.5606
11	2.5126
12	2.7686
13	.2241
19	.2881
Max	2.7686
Min	.2241
Avg	1.3558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 204 / GHUMANDEV GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	21-FEB-17
HR	Load (MW)
1	.2401
2	.2401
3	.2401
4	.3521
5	.4961
Max	.4961
Min	.2401
Avg	.3137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 206 / VADALA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
1	1.7654
2	1.8084
3	1.7924
4	1.7924
5	1.7924
7	.128
11	1.8084
19	.128
Max	1.8084
Min	.128
Avg	1.3769

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 207 / KHOKAR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
1	.1219
2	.2881
3	.128
4	.128
5	.128
6	1.7604
7	2.4646
8	2.7046
9	2.7686
10	2.7526
11	2.7526
12	2.8006
13	.064
20	.128
Max	2.8006
Min	.064
Avg	1.3564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 208 / KAREGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
1	1.7966
2	1.8404
3	1.8244
5	1.8884
6	.2881
7	.2241
8	.144
19	.128
Max	1.8884
Min	.128
Avg	1.0168



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 209 / WADALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
1	.5921
2	.5601
3	.5601
4	.7522
5	.8802
12	.6882
19	.9282
Max	.9282
Min	.5601
Avg	.7087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 201 / 11 Kv MIDC feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0098	1.1317	.8865	.9431	.5658	1.2071	
2	1.0479	1.1317	.8676	.9054	.5658	1.094	
3	1.105	1.226	.8488	.8676	.5658	1.0374	
4	1.1431	1.226	.8299	.8676	.6602	1.0185	
5	1.2003	1.3203	.811	.7922	.6602	1.0562	
6	1.2384	1.3203	.8299	.7733	.7545	1.0751	
7	1.2765	1.226	.8488	.8299	.8488	1.094	
8	1.3527	1.4146	.9808	.5847	.6602	1.1694	
9	1.4098	1.5089	1.094	.415	1.226	1.3957	
10	1.6032	1.6004	1.6194	.4715	1.2637		
11	1.8861	1.6385	1.6956	.1886	1.9805	2.0576	
12	2.1691	1.7337	1.7528	.4715		2.1529	
13	2.1691	1.5623	1.5051	.2829	1.8861	2.0576	
14	2.2634	1.3908	1.6575	.3772	1.9805	1.9624	
15	2.0748	1.4289	1.7909	.4715	2.0748		
16	2.0748	1.4861	1.7147	.5658	2.32		1.6032
17	2.1691	1.4289	1.7147	.5658	2.1691		1.7918
18	1.8861	1.3527	1.6385	.4715	2.037		1.8861
19	1.4146	1.2574	1.3908	.4715	1.9239		2.2634
20	1.3203	1.2384	1.3527	.5658	1.8484		2.0748
21	1.1317	1.0479	1.3146	.5658	1.7541		1.9805
22	1.226	.9808	1.1506	.5658	1.6221		1.8861
23	1.226	.9431	1.0185	.5658	1.358		1.7918
24	1.0479	1.1317	.9054	.9808	.5658	1.3203	
Max	2.2634	1.7337	1.7909	.9808	2.32	2.1529	2.2634
Min	1.0098	.9431	.811	.1886	.5658	1.0185	1.6032
Avg	1.5186	1.3220	1.2591	.6067	1.3605	1.4070	1.9097

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 202 / 11 KV WAKADI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.037	.0747	.0754	.037	.0754	
2	.1143	.0924	.0747	.0754	.0554	.0754	
3	.1143	.0924	.0747	.0566	.0924	.0754	
4	.1334	.0924	.0747	.0566	.0924		
5	.1334	.0924	.0934	.0754	.0924	.0754	
6	.1524	.0924	.1307	.0943	.0924	.1132	
7	.1715	.0924	.168	.1509	.0924	.1509	
8	.1715		.1509	.132	.0924	.1509	
9	.2096	.0924	.132	.132	.0924	.1698	
10	.1886	.1143	.1905	.0924	.2452		
11	.1886	.1143	.2477	.0924	.2263	.2477	
12	.1886	.1715	.2858	.0924	.2075	.2858	
13	.1886	.2286	.2096	.0924	.1886	.3048	
14	.1886	.2858	.1715	.0924	.2075	.3429	
15	.2263	.2667	.1905	.0924	.2263		
16	.2829	.2286	.1715	.0924	.2452		.2686
17	.2829	.2096	.1715	.0924	.2263		.1886
18	.2772	.1905	.1715	.0924	.2452		.2686
19	.2772	.1334	.1715	.0924	.2452		.2218
20	.2772	.1143	.1715	.0924	.1886		.2218
21	.0924	.1334	.1524	.0924	.132		.2218
22	.0943	.1307	.132	.0924	.1132		.181
23	.0857	.1307	.132	.0924	.1132		.1791
24	.1143	.0924	.0934	.0943	.0554	.0754	.1848
Max	.2829	.2858	.2858	.1509	.2452	.3429	.2686
Min	.0857	.037	.0747	.0566	.037	.0754	.1791
Avg	.1778	.1404	.1515	.0932	.1502	.1648	.2151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 203 / INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3146	1.4784	1.2449	1.3769	1.5708	1.358	
2	1.2765	1.386	1.2071	1.3392	1.5708	1.3203	
3	1.448	1.386	1.1694	1.3203	1.5708	1.2826	
4	1.6575	1.5223	1.1694	1.3014	1.6632	1.2826	
5	1.8671	1.5708	1.226	1.3203	1.7556	1.358	
6	2.1529	1.7556	1.6221	1.5402	1.9404	1.6598	
7	2.4577	2.3101	2.4143	2.1313	2.2177	2.3011	
8	2.4958	2.1253	2.3011	2.3577	2.5873	2.1125	
9	2.1529	1.9404	2.1691	2.1879	2.2177	1.9993	
10	1.97	1.8671	2.0195	2.0328	1.9993		
11	1.9404	1.7147	1.9624	2.0328	1.9805	1.9433	
12	1.97	1.7909	1.9052	1.848	1.9427	1.9814	
13	1.8804	1.7147	1.829	1.8861	1.8861	2.0005	
14	1.7556	1.6956	1.7337	1.8861	1.8484	1.1431	
15	1.7556	1.7337	1.6575	1.7556	1.7918		
16	1.848	1.7528	1.7528	2.0328	1.7541		2.7721
17	1.97	1.8671	1.848	1.1088	1.8484		2.7721
18	2.1253	1.9624	2.0576	2.2177	2.0748		2.7721
19	2.4025	2.2862	2.4196	2.4949	2.3954		3.0493
20	2.4949	2.1719	2.3053	2.5873	2.2068		2.7721
21	1.7556	1.9243	1.9624	2.0328	1.9427		3.0493
22	1.6632	1.6221	1.6787	1.7556	1.7353		2.1253
23	1.5708	1.4712	1.5278	1.7556	1.5278		1.848
24	1.3908	1.5708	1.3203	1.4335	1.6632	1.4712	
Max	2.4958	2.3101	2.4196	2.5873	2.5873	2.3011	3.0493
Min	1.2765	1.386	1.1694	1.1088	1.5278	1.1431	1.848
Avg	1.8882	1.7759	1.7710	1.8223	1.9038	1.6581	2.6450

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 204 / NEW TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.2536	1.1641	1.2894	1.379	1.182	
2	1.2955	1.1641	1.1462	1.2357	1.379	1.1462	
3	1.2384		1.1104	1.182	1.379	1.1104	
4	1.5051	1.1641	1.1104	1.1999	1.4327	1.1104	
5	1.7528	1.3611	1.1999	1.1999	1.7193	1.2178	
6	2.0195	1.5402	1.5223	1.3432	1.7909	1.5402	
7	2.191	2.1491	2.167	1.8088	2.0595	2.0237	
8	2.1338	2.0595	2.0595	2.0595	2.0595	1.8804	
9	1.9052	1.97	1.7551	1.8446	2.0058	1.7372	
10	1.7909	1.9814	1.8861	1.9404	1.773		
11	1.7013	1.9243	1.829	1.7909	1.773		
12	1.7013	1.7528	1.7909	1.8804	1.8484		
13	1.6118	1.5432	1.6766	1.5223	1.6297		
14	1.6118	1.467	1.6194	1.6409	1.7164	2.4006	
15	1.7013	1.4289	1.6956	1.7372	1.5402		
16	1.7013	1.4861	1.7718	1.97	1.4506		2.5968
17	1.7909	1.5623	1.8099	1.8804	1.6476		2.7721
18	2.0595	1.7337	2.0005	2.0953	1.8804		2.6863
19	2.3282	2.3434	2.4196	2.4356	2.0237		2.7759
20	2.2386	2.2291	2.191	2.4177	1.97		2.7721
21	2.0328	1.8861	1.9814	1.97	1.8446		2.1491
22	1.6118	1.4685	1.576	1.7013	1.5939		2.1719
23	1.5708	1.3611	1.4327	1.5402	1.3611		1.5384
24	1.3527	1.3432	1.1999	1.3432	1.5402	1.2715	
Max	2.3282	2.3434	2.4196	2.4356	2.0595	2.4006	2.7759
Min	1.2384	1.1641	1.1104	1.182	1.3611	1.1104	1.5384
Avg	1.7575	1.6597	1.6715	1.7095	1.6999	1.5109	2.4328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 205 / Prabhat

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	1.1317	.7733	.8676	.9431	.7167	
2	.8383	1.0374	.7545	.9054	.9431	.7167	
3	.8954	1.0374	.7356	.8676	1.0374	.7545	
4	.9526	1.0374	.7167	.8488	.9431	.7545	
5	1.0098	1.1317	.7545	.8676	1.0374	.7922	
6	1.0669	1.2449	.7922	.9431	1.1317	.8488	
7	1.1241	1.1317	1.0374	1.0751	1.226	1.0374	
8	1.2003	1.226	1.1694	1.1317	1.3203	1.094	
9	1.2955	1.1317	1.2071	1.1883	1.4146	1.1317	
10	1.226	1.0669		1.226	1.4335		
11	1.226	.9907	1.1812	1.226	1.3957	1.2384	
12	1.226	1.0669	1.1431	1.226	1.358	1.1812	
13	1.226	1.105	1.1622	1.3203	1.3203	1.1622	
14	1.1317	1.0098	1.086	1.226	1.2826	1.1431	
15	1.1317	.9526	1.0288	1.226	1.0562		
16	1.0374	.8954	1.0479	1.1317	.9242		1.0374
17	1.0374	.9717	1.086	1.1317	.9431		1.226
18	.9431	1.0288	1.0669	1.1088	.9808		1.226
19	.924	.9145	1.0479	1.0374	1.0374		1.226
20	.924	.8954	1.0098	1.1317	.9808		2.2634
21	.9431	.9145	.9526	1.1317	.9054		1.0374
22	1.1317	.8676	.8676	1.0374	.8676		1.0374
23	1.0374	.7922	.8299	.9431	.8299		1.0374
24	.8002	.9431	.7545	.8676	.9431	.7922	
Max	1.2955	1.2449	1.2071	1.3203	1.4335	1.2384	2.2634
Min	.8002	.7922	.7167	.8488	.8299	.7167	1.0374
Avg	1.0470	1.0219	.9654	1.0694	1.0940	.9545	1.2614

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 201 / TAKALIBHAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5926		2.5749	1.8884	.1943	
2	2.5926	1.8884	2.5749	1.9204	.1943	.2915
3	2.6246	1.9685	2.6235	2.0485	.1943	.2915
4	2.6566	2.0805	2.7368	2.2085	.1943	.2915
5	2.6882	2.3685	2.9959	2.372	.2105	.2915
6		2.7206	3.255	2.8464	.2267	.2915
7	3.2026	3.4789	3.4008	3.3208		.2753
8		3.4526	3.4818	3.5627		
9	3.0308	3.4057	2.834	2.9959		
10					3.5627	3.6113
11					3.4008	3.7247
12					3.0769	
13					3.0283	3.255
14					3.1255	
15					3.2065	3.4008
16					3.1093	3.6923
17					2.915	3.6761
18	.144		.16	.1781	.1943	.2374
19		.2105	.1943	.1781	.2915	.2883
20		.2753	.2267	.2753	.3563	.3222
21		.2753	.2241	.2915	.3563	.3391
22		.2429		.2591	.3725	.3391
23	.208	.2105	.192	.2267	.3563	.2883
24			2.4615	1.8884	.1943	
Max	3.2026	3.4789	3.4818	3.5627	3.5627	3.7247
Min	.144	.2105	.16	.1781	.1943	.2374
Avg	2.1933	1.7368	1.9957	1.6538	1.3696	1.3837

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 202 / PUNATGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2631		1.2894	1.1203	.0716	
2		1.2631	1.1012	1.2894	1.1523	.0716	.0716
3		1.2631	1.1336	1.3611	1.2003	.0716	.0716
4		1.2955	1.1843	1.4327	1.2803	.0716	.0716
5		1.3443	1.2483	1.6476	1.3603	.0895	.0716
6			1.3603	1.7013		.1075	.0716
7		1.5813	1.7328	1.8088			.0716
8		1.6604	2.0595	2.0953	2.1491		
9		1.656	1.9163	1.773	1.8446		
10	2.0302	.0509	.1075	.0895	.1075	.0716	.1075
11		.0339	.0716	.0537	.0895	.0537	.0895
12						2.2028	2.1132
13							2.3819
14						2.0774	2.5072
15						2.2386	2.2923
16						2.5789	
17						2.4535	2.3282
18						1.8983	2.2213
19			.0895		.0716	2.0416	1.9387
20		.1781	.0895	.081	.0716	.1075	.1187
21		.1781	.0895	.0972	.1075	.1075	.1187
22			.0895		.1075	.1075	.1187
23		.0648	.0716	.0819	.1075	.1075	.1357
24				1.2536	1.2146	.0895	
Max	2.0302	1.6604	2.0595	2.0953	2.1491	2.5789	2.5072
Min	2.0302	.0339	.0716	.0537	.0716	.0537	.0716
Avg	2.0302	.9102	.823	1.0704	.7990	.8310	.8895



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 203 / PACHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7046		2.6246	2.4006	.125	
2		2.6406	2.1125	2.6246	2.5926	.125	.1718
3		2.6886	2.2085	2.6558	2.6886	.125	.1562
4		2.7206	2.2725	2.8433	2.8006	.125	.1406
5		2.8147	2.3205	3.2339	2.878	.1406	.1718
6			2.3685	3.2808		.1562	.1875
7		2.9683	3.2808	3.3901			.1718
8		3.1245		3.4682	3.4682		
9		.9686	3.1402	2.7652	3.0152		
10	.1187		.1094	.1094	.1094	.1094	.1094
11	1.1361		.1094	.1094	.1094	.1094	.1094
12				.1094		3.437	3.3432
13						3.3432	3.3432
14							3.4995
15						3.1245	
16						3.3745	3.312
17						3.3432	3.4057
18						3.187	4.0055
19			.1094		.1562	.2812	3.6031
20		.128	.1406	.16	.1718	.2187	.2158
21		.144	.1406	.16	.1562	.1875	.2204
22			.125		.1562	.1718	.2035
23		.112	.1094	.112	.125	.1718	.1865
24				2.5621	2.4006	.125	
Max	1.1361	3.1245	3.2808	3.4682	3.4682	3.437	4.0055
Min	.1187	.112	.1094	.1094	.1094	.1094	.1094
Avg	.6274	1.9104	1.3248	1.8881	1.5486	1.0991	1.3977

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 204 / 11 KV WANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.144		.2652	.2241	2.4531	
2		.144	.16	.2652	.2241	2.4531	2.0222
3			.16	.2652	.2241	2.5194	2.0719
4		.144		.2652	.2401	2.5692	2.3205
5		.16	.16	.2818	.2721	2.652	2.7846
6			.16			2.9504	3.0664
7						3.315	2.9338
8						3.3316	3.4974
9						2.7183	3.2156
10			.144	.2984	.1989	.1492	.1989
11				.2984	.1823	.0995	.1492
12	3.1642	3.2373	3.0087	3.4145			
13	3.658	3.3288	2.9127	3.315	2.9172		
14			3.0887		2.9338		
15	3.4202	3.4385	3.1527		3.1327		
16	3.0361	3.2922	3.1824	3.3366	3.315		
17	3.219	3.53	3.4476	3.4294	3.0333		
18		2.9127		3.2808	2.7515		
19		2.6882	2.9007	3.2007	2.9007		
20		.176	.3647	.2401	.1989	.2155	.2204
21		.176	.3647	.2561	.1989	.1989	.2035
22			.3481		.1989	.1823	
23		.176	.3149	.2241	.1989	.1823	
24				.2818	.2401	2.42	
Max	3.658	3.53	3.4476	3.4294	3.315	3.3316	3.4974
Min	3.0361	.144	.144	.2241	.1823	.0995	.1492
Avg	3.2995	1.6820	1.4919	1.3481	1.2413	1.7756	1.8904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 205 / KAREGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.128		.2187	.16	1.8122	
2		.128	.128	.2187	.16	1.8122	1.8435
3		.128	.128	.2187	.16	1.8278	2.3122
4		.128	.128	.2187	.16	1.8435	2.4059
5		.144	.144	.2187	.16	1.9685	2.4684
6			.144			2.2809	2.4996
7						2.4684	2.6246
8						2.9214	3.312
9						2.4215	2.8121
10			.0781	.2187	.2187	.2187	.2187
11				.2187	.2187	.2187	.2031
12			3.0464	2.9214			
13	3.6946		3.2651	2.8746	2.8902		
14	3.8958				2.9214		
15			2.9839	3.305	3.2339		
16	3.6214		3.2808	3.1245	3.187		
17	2.9264		3.312	3.7289	3.0777		
18		3.2007		2.9607	2.8121		
19		2.7206	2.5777	2.6566	2.3434		
20		.16	.2656	.2401	.2031	.25	
21		.192	.2656	.2721	.25	.2343	.2883
22			.25		.25	.2343	.2543
23		.128	.2812	.2753	.25	.2187	.2713
24				.25	.1619	1.8747	
Max	3.8958	3.2007	3.312	3.7289	3.2339	2.9214	3.312
Min	2.9264	.128	.0781	.2187	.16	.2187	.2031
Avg	3.5346	.7057	1.2674	1.3411	1.2010	1.4129	1.6549

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 206 / GHOGARGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4207		.4207	.4024	.4207	.4024
2			.3658	.4207	.4024	.4207	.3841
3		.439	.4207	.4572	.439	.4755	.4024
4		.4938	.4572	.5304	.4938	.5853	.5121
5		.7499	.5487	.6767	.5853	.6219	.6584
6			.7682			.6584	.7316
7		.6697				.695	.6767
8		.6516				.6401	
9		.5973				.6036	
10	.3391	.4578	.6401	.5853	.6401	.5487	.4755
11	.3391	.3391	.439		.4938	.4755	.3658
12		.3561	.3475			.4207	
13		.2883	.3292	.5487	.4572	.3658	.2743
14	.4409	.2883		.5068	.4024	.439	
15	.4917	.3222		.4525	.3658	.3841	
16	.39	.3561	.5304	.4887	.3658	.439	
17	.5765	.3391	.5304		.4207	.4572	
18		.4938		.5853	.439	.4938	.6104
19		.5853	.7133	.7316	.6767	.695	.7122
20		.695	.7682	.7682	.7133	.7133	.6783
21		.5853	.6219	.7316	.6401	.6767	.4748
22			.5487		.5487	.5487	.4748
23		.362	.4572	.439	.439	.439	.4239
24				.4207	.4207	.4207	
Max	.5765	.7499	.7682	.7682	.7133	.7133	.7316
Min	.3391	.2883	.3292	.4207	.3658	.3658	.2743
Avg	.4296	.4745	.5304	.5478	.4919	.5266	.5161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 207 / GUJARWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / INCOMING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1578		.1715	.1578	.1715	.1543
2		.1578	.1753	.1715	.1578	.1715	.1543
3		.1753	.1753	.1886	.1753	.1886	.1715
4		.2103	.2279	.2058	.2279	.2058	.2572
5		.2401	.2804	.2229	.2804	.2401	.3258
6			.3506	.3429		.3429	.3772
7		.3944		.3772			.3944
8		.3429					
9		.2743					
10	.3052	.2374	.2883	.3258	.3086	.2915	.2915
11	.2204	.1865	.2204	.1886	.2572	.2401	.2743
12	.2035	.1187	.1526	.1372		.1715	.1886
13	.0848		.1017	.1715	.1372	.1543	.1886
14	.1357		.1017	.1372	.12	.12	.1543
15	.1526		.1017	.12	.12	.1543	.1886
16	.1357		.1526	.12	.1886	.1543	.1886
17	.2035		.1543	.1543	.2058	.1886	.1715
18		.2629		.2454	.2058	.2572	.2035
19		.298	.3258	.3429	.2915	.3601	.3561
20		.2804	.3258	.3155	.3086	.3258	.3391
21		.2629	.2401	.3155	.2743	.2572	.2713
22			.2058		.2401	.2401	
23		.1753	.2058	.2103	.2058	.2058	
24				.1715	.1753	.1715	
Max	.3052	.3944	.3506	.3772	.3086	.3601	.3944
Min	.0848	.1187	.1017	.12	.12	.12	.1543
Avg	.1802	.2359	.2103	.2208	.2125	.2197	.2448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 209 / JAINPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.16		.4144	.4372	2.0885	
2		.16	.192	.4144	.4372	2.0885	1.9559
3		.16	.192	.4144	.4372	2.1216	2.2542
4		.16	.192	.4144	.4372	2.1548	2.3537
5		.176	.192	.431	.4372	2.2542	2.4531
6		.176	.208			2.42	2.536
7						2.5194	2.6189
8						2.7846	3.0333
9						2.7183	2.3868
10	3.6946	3.0178	2.8006	2.7018	2.8012		
11	4.2067	3.8775	3.0887	2.652	2.8344		
12	4.0238	3.8775		3.4145			
13	2.7984	3.3288		2.9835	2.3205		
14	3.4019	3.1459	3.4568	2.8166	2.1051		
15	3.219	3.658		2.7831	2.2211		
16		3.2373	3.1493		1.757		
17	2.8349	3.2739	3.2819	3.2417	1.873		
18		.16		.3201	.4475	.4641	.2374
19		.192	.431	.3201	.431	.431	.5256
20		.2401	.5138	.4694	.5138	.4973	.5426
21		.208	.4973	.503	.5138	.5138	.5256
22			.4973		.4973	.5138	.5256
23		.144	.4973	.5407	.4973	.5304	.5256
24				.4807	.4858	2.0885	
Max	4.2067	3.8775	3.4568	3.4145	2.8344	2.7846	3.0333
Min	2.7984	.144	.192	.3201	.431	.431	.2374
Avg	3.4542	1.5449	1.2793	1.4064	1.1308	1.6368	1.6053

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 201 / MALWADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4458		2.2291	2.1948	
2	.4458	.4458		2.2291	2.1948	
3	.463	.4801		2.2634	2.2291	
4	.463	.4801		2.2634	2.2634	
5	.4973	.5144		2.3148	2.2977	
6	.5144	.5487		2.4006	2.3663	
7	.5316	.5144		2.4863	2.572	
8		.463		2.4863	2.915	
9		.3772		2.4863	2.6235	
10	.3944		.3944	.3772		
11	.3772		.3601	.3601		
12	3.3608		2.9664	.3601		
13	3.2922		3.0007	.3772		
14	3.2065		2.7606	.3772		
15	3.2236		2.5034	.3772		
16	3.2407		2.4348	.3772		.3429
17	3.0864		2.3834	.3601		
18	2.8464		2.3148	.3601		
19	2.4691		2.2977	.4115		
20	.3944		.4458	.4458		.4115
21	.4115		.4287	.4458		.4115
22	.4287		.4115	.4287		.4115
23	.4458		.4115	.4115		.4115
24	.4458	.4458		2.1262	2.1948	2.0233
Max	3.3608	.5487	3.0007	2.4863	2.915	2.0233
Min	.3772	.3772	.3601	.3601	2.1948	.3429
Avg	1.4084	.4715	1.6510	1.1981	2.3851	.6687

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 202 / UNDIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.3717		.2401	.2401		
2	1.4918	1.3717		.2401	.2401		
3	1.5261	1.4403		.2743	.2743		
4	1.6118	1.5089		.2743	.3429		
5	1.6632	1.5775		.3429	.3944		
6	1.869	1.6461		.3601	.3601		
7	2.0576	1.9547		.4801			
8	2.1776	2.2634		.3601			
9	.1886	2.1091		.3258	.3944		
10	.2401		.2058			.2401	
11	.2058		.1715			.2229	
12			.1543			2.3491	
13	.1372					2.3148	
14	.1372					2.332	
15			.12				
16	.1715		.12				2.0576
17	.2229		.12	2.3148			
18	.2572			2.3148			2.1262
19	.2915		.3258	1.989			2.1091
20	.3086		.2743	.3258			1.8519
21	.2915		.2743	.3086			.2743
22	.2572		.2572	.2743			.2572
23	.1886		.2229	.2572			.2401
24	1.3375	1.3717		.2229	.2401		.2229
Max	2.1776	2.2634	.3258	2.3148	.3944	2.3491	2.1262
Min	.1372	1.3717	.12	.2229	.2401	.2229	.2229
Avg	.8231	1.6615	.2042	.6415	.3108	1.4918	1.1424



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 203 / TEXTILE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5775	1.5089		.2229	.2229		
2	1.5775	1.5089		.2229	.2229		
3	1.6289	1.5775		.2572	.2401		
4	1.6632	1.6461		.2572	.2572		
5	1.7661	1.7147		.2743	.2743		
6	1.8004	1.7833		.2743	.2915		
7	2.1605	2.0919		.3086			
8	2.2634	2.332		.2572			
9	1.3375	2.2462		.2229	.2401		
10	.1886		.2058			2.452	
11	.1715		.1715			.2058	
12	.12		.1715			2.4177	
13	.12		.1543				
14	.1029		.12			2.4691	
15	.1029		.12			2.5034	
16	.12		.1372			2.5034	1.8861
17	.1543		.1372	2.3663		2.0919	2.1948
18	.1886		.2058	2.1948		1.869	1.7661
19	.2229		.2229	2.0062		1.5947	
20	.2572		.2915	.3258			1.3032
21	.2743		.2915	.3086			.2743
22	.2401		.2572	.2915			.2743
23	.2229		.2743	.2915			.3086
24	1.5261	1.4746		.2572	.2401		.2572
Max	2.2634	2.332	.2915	2.3663	.2915	2.5034	2.1948
Min	.1029	1.4746	.12	.2229	.2229	.2058	.2572
Avg	.8245	1.7884	.1972	.6082	.2486	2.0119	1.0331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 204 / 11 KV HAREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715		.1886	.1886	
2	.1715	.1715		.2229	.1886	
3	.2229	.2401		.2229	.2229	
4	.2572	.2401		.2572	.2572	
5	.2572	.2743		.2572	.2915	
6	.2915	.3086		.2915	.3086	
7	.4458	.3944		.4115		
8	.3772	.3601		.2915		
9	.2572	.3601		.3258	.3772	
10	.2572		.2915			
11	.2401		.2229			
12	.2229		.2058	.0857		
13	.2058		.1886			
14	.1886		.1886			
15			.1715			
16	.1715		.2058			.3429
17	.2058		.2229	.2572		.3086
18	.2743		.2572	.2572		.2401
19	.3429		.3086	.3601		.3772
20	.3258		.3258	.3258		.3258
21	.2915		.2572	.2915		.3086
22	.2572		.2572	.2572		.2401
23	.1715		.2058	.2058		.2229
24	.1543	.1715		.1886	.1886	.1886
Max	.4458	.3944	.3258	.4115	.3772	.3772
Min	.1543	.1715	.1715	.0857	.1886	.1886
Avg	.2505	.2692	.2364	.2610	.2529	.2839

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 205 / MALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029		.12	.1029	
2	.12	.1029		.12	.1029	
3	.1543	.1372		.1543	.1372	
4	.1715	.2058		.1543	.2058	
5	.2229	.2743		.2401	.2915	
6	.2572	.3601		.2915	.3601	
7	.3429	.4115		.4115		
8		.3601				
9		.2743			.2743	
10	.1372		.1715	.1543		
11	.1372		.1372	.1372		
12	.1543		.1372	.0857		
13	.1029		.12	.0857		
14	.1029		.12	.0857		
15	.0857		.1029	.0857		
16	.12		.12	.0857		.2401
17	.1715		.12	.1372		.1886
18	.2743		.1715	.1715		.2058
19	.3429		.3086	.2915		.3086
20	.3086		.2572	.2743		.2572
21	.2058		.1715	.2058		.2229
22	.1715		.1543	.1372		.1543
23	.12		.12	.1029		.12
24	.1029	.1029		.12	.1029	.12
Max	.3429	.4115	.3086	.4115	.3601	.3086
Min	.0857	.1029	.1029	.0857	.1029	.12
Avg	.1785	.2332	.1580	.1660	.1972	.2019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 201 / MATULTHAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
1	.1581
2	.1423
3	.1423
4	.4428
5	.4586
6	.506
7	.506
8	.6483
9	.7116
19	.1423
20	.2372
21	.2214
22	.1739
23	.1581
24	.1581
Max	.7116
Min	.1423
Avg	.3205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 202 / NAUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
1	.1357
2	.1187
3	.1357
4	.1357
5	.1526
6	.1696
16	2.1704
17	2.4587
18	2.2891
19	.1017
20	.2035
21	.1865
22	.1865
23	.1526
24	.1357
Max	2.4587
Min	.1017
Avg	.5822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 203 / 11KV KHAIRI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-FEB-17
HR	Load (MW)
1	.1204
2	.1054
3	.1054
4	.6321
5	.7074
6	.873
7	1.1439
8	1.4299
9	1.5653
19	.1505
20	.1806
21	.1656
22	.1505
23	.1355
24	.1355
Max	1.5653
Min	.1054
Avg	.5067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 204 / GONDEGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	21-FEB-17
HR	Load (MW)
1	.0554
2	.037
3	.0554
4	.0739
5	.0924
6	.1109
7	.1109
8	.1663
9	.0924
17	.1109
18	.1294
19	.1109
20	.0924
21	.0739
22	.0554
23	.0554
24	.0366
Max	.1663
Min	.0366
Avg	.0859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 205 / 11 KV RAMPUR GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	21-FEB-17
HR	Load (MW)
1	.0549
2	.0732
3	.0732
4	.0914
5	.128
6	.1829
7	.1829
8	.2012
9	.1097
16	.0732
17	.1097
18	.1646
19	.1646
20	.1463
21	.1463
22	.1097
23	.0732
24	.0732
Max	.2012
Min	.0549
Avg	.1199



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 206 / 11 KV NIMGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	21-FEB-17
HR	Load (MW)
1	.0829
2	.0663
3	.0663
4	.0995
5	.1326
6	.2155
7	.2155
8	.2204
9	.1492
16	.0829
17	.1492
18	.1658
19	.1989
20	.1989
21	.1823
22	.1823
23	.1294
24	.0848
Max	.2204
Min	.0663
Avg	.1457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 201 / 11 KV MATAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3887	.3749		.3401	.3921	1.6347	
7						2.0018	
8						2.4777	
9						2.2348	
10	.3052	.3801	.2591	.3658	.3593	.2429	
11	.2401	.3258	.2591	.4835	.4218	.2105	
12	2.4074	2.4006	2.2725	2.4939			
13			2.4006				
14	2.3765		2.4486		2.3967		
15			2.4006		2.4249		
16	2.0833	2.3434		2.4985	2.4741		
17			1.9204	2.4059	2.5652		
18	2.0567	2.2965			2.5692		
19	2.3434	2.3158	2.2885	2.6216	2.3922		
20			.3401		.4557		
21	.3439				.4031		.4557
22		.3012	.2915	.3224	.362		.4239
23	.1928	.2715	.2753	.3012	.333	.2591	.3944
24	.2591	.1638	.2267	2.4528		1.4175	
Max	2.4074	2.4006	2.4486	2.6216	2.5692	2.4777	.4557
Min	.1928	.1638	.2267	.3012	.333	.2105	.3944
Avg	1.1816	1.1174	1.2819	1.4286	1.3499	1.3099	.4247

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 202 / 11 KV BHERDAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	2.7206	2.1643	2.2138	2.5926	2.1376	.2824	
7		2.5436	2.8841		2.9835		
8	2.8487		2.9492		2.9338		
9			2.8006	2.7206	2.3777		
10	.3294	.3841	.2915	.362	.3681	.2915	
11	.208	.2926	.2429	.3841	.3155	.2753	
13						2.8006	
14						2.8807	2.9995
15						2.8006	2.7515
16						2.8807	2.8502
17							2.9312
18							2.7692
19	.3605	.4163	.2591	.3292	.3077		2.7044
20			.3725		.4908		
21	.3561				.4075		.4382
22		.3258	.3239	.3439	.3681		.39
23	.39	.2743	.2915	.2743	.3506	.2429	.3391
24	1.8404	1.9433	1.9204	1.9204		.2561	
Max	2.8487	2.5436	2.9492	2.7206	2.9835	2.8807	2.9995
Min	.208	.2743	.2429	.2743	.3077	.2429	.3391
Avg	1.1317	1.0430	1.3227	1.1159	1.1855	1.4123	2.0193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 203 / 11 KV LADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4049	.3763	.4887	.4372	.4854	1.4074	
7						1.6918	
8						2.2348	
9						1.8299	2.1285
10	.3801	.4163	.3563	.3982	.4031	.3277	.373
11	.3439	.3439	.3239	.443	.4031	.3239	
12	2.1862	2.1293	2.0325	2.2712			
13		2.3137	2.2085	2.146	2.34		
14	2.3594	2.3137	2.2405	1.9334			
15			2.2085	2.0153	2.3205		
16	2.2874	2.1714	2.1285		2.2996		
17			2.1285	1.8842	2.3537		
18	2.2672	2.146			2.1052		
19	2.0567	1.989	1.9204	1.8143	2.0972		
20			.4049		.5249		
21	.4163				.4706		.5083
22		.4075	.3887	.4163	.4344		.4733
23	.3982	.3982	.3725	.3801	.4252	.2429	.4525
24	.3239	.3277	.3563	.3563		1.2039	
Max	2.3594	2.3137	2.2405	2.2712	2.3537	2.2348	2.1285
Min	.3239	.3277	.3239	.3563	.4031	.2429	.373
Avg	1.2204	1.2778	1.2542	1.2080	1.2818	1.1578	.7871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 204 / 11 KV KAREGAON AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	2.332	1.8435		2.21	2.1605	.2818	
7		2.5453	2.4777		2.6871		
8	2.1338	2.6558	2.5775	2.6978	2.915		
9			2.0576	2.4082	2.6397		
10	.4096	.5487	.4218	.4961	.5087	.3906	.4748
11	.3441	.5138	.4062	.5548	.5087	.3086	
12							2.9635
13						2.9264	2.7368
14						3.0483	2.7854
15							2.7854
16						2.1338	
17						3.0483	
18							2.7854
19	.4144	.3174	.2187	.2614	.5784		2.4939
20			.3906		.6661		
21	.4938				.6135		.6878
22		.4706	.4062	.4706	.5611		
23	.4733	.4477	.3906	.4525	.5249	.3858	
24	1.5242	1.6404	1.6049	1.6004		.2031	
Max	2.332	2.6558	2.5775	2.6978	2.915	3.0483	2.9635
Min	.3441	.3174	.2187	.2614	.5087	.2031	.4748
Avg	1.0157	1.2204	1.0952	1.2391	1.3058	1.4141	2.2141

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 205 / 11KV MATAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.1943	.1619		.1619	.1886	.2103	
7		.1875	.218		.2218	.2204	
8		.2031				.1949	.1134
9						.2543	.1619
10	.1738	.1734	.1619	.2254	.1709	.1457	.1303
11	.1303		.1296	.2058	.1334	.1134	
12	.081	.0791	.0972	.1052		.081	.0972
13		.1067	.081	.0937	.0937		.081
14	.0829		.081			.0648	.0625
15			.081		.0937	.0648	.0633
16	.0819	.08	.0972	.0829	.0937	.0648	.0781
17			.0972	.128	.0937		.1134
18	.1147	.1006			.0972	.1296	.1296
19	.1802	.1448	.1457	.1463	.2035		.2031
20			.1619		.2172		
21	.1526				.1991		.1928
22		.1214	.1457	.1214	.1629		.6274
23	.1187	.0867	.1296	.0876	.1086	.1296	.1543
24	.081	.0781	.081	.0791		.0876	
Max	.1943	.2031	.218	.2254	.2218	.2543	.6274
Min	.081	.0781	.081	.0791	.0937	.0648	.0625
Avg	.1265	.1269	.122	.1307	.1484	.1355	.1577

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-FEB-17 and 21-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 206 / 11 KV BHERDAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-FEB-17	16-FEB-17	17-FEB-17	18-FEB-17	19-FEB-17	20-FEB-17	21-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.2683	.2915		.2713	.2601	.2743	
7		.3601	.2683		.2683	.2572	
8		.3258				.2515	
9						.2683	.1844
10	.2743	.2481	.2713	.2658	.2915	.2035	
11	.2401	.1772	.2374	.2658	.2572	.1509	
12	.1715	.1677	.1696	.1677			
13		.1865	.1696	.1844	.2058	1.7269	
14	.2229		.1865	.1341	.1715	.1677	.2058
15			.1696		.1715	.2012	.1357
16	.1886	.2012	.1696	.218	.2058	.1677	.1844
17			.1865			.2347	.2012
18	.2743	.2347			.2572		.218
19	.3258	.285	.2713	.285	.2743		.285
20			.2883		.2915		
21	.2572				.2572		.2572
22		.1949	.1865	.2303	.2229		.218
23	.1886	.1595	.1696	.1772	.1715	.1509	.1844
24	.1509	.1715	.1357	.1341		.1715	
Max	.3258	.3601	.2883	.285	.2915	1.7269	.285
Min	.1509	.1595	.1357	.1341	.1715	.1509	.1357
Avg	.2330	.2311	.2057	.2122	.2362	.3251	.2074