

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 201 / KIRPE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6465	1.5745	.1219	.0945	.0804	.1021	1.0859
2	1.6313	1.5067	.1211	.0934	.0785	.0998	1.1237
3	1.5421	1.4621	.1196	.0926	.0781	.1002	1.0612
4	1.456	1.3737	.1215	.0915	.0777	.0991	1.0425
5	1.5631	1.4918	.1207	.0903	.0827	.0926	1.1644
6	1.6198	1.7307	.1467	.1063	.1173	.0812	1.3428
7	1.8476	2.0721	.1341	.1235	.12	.1375	1.9384
8	1.8671	1.992	.1334	.1261	.1234	.1128	2.0237
9	.9888	2.1768	2.0568	2.0805	2.2546	2.1487	.9477
10	.0473	.0766	2.4078	2.1525	2.3746	2.3247	.0812
11	.0377	.0343	2.3983	2.0622	.8467	2.2881	.0823
12	.0343	.0591	2.3339	1.9223	2.1822	2.1304	.0869
13	.0819	.1166	2.1814	1.7093	2.1593	1.965	.1051
14	.0777	.1108	2.0294	1.7197	2.1128	1.7878	.1051
15	.0819	.1158	1.8953	1.7014	1.9109	1.7169	.0888
16	.096	.1135	1.0029	1.7075	1.731	1.7124	.0663
17	.0987	.093	1.0037	.9042	.9008	.8703	.0671
18	.0953	.0922	.093	.0408	.0777	.045	.107
19	.1227	.107	.0941	.077	.1093	.1131	.115
20	.1399	.1246	.1254	.085	.146	.1082	.1147
21	.1418	.1177	.1288	.0835	.1452	.1116	.1387
22	.1486	.1207	.1147	.1124	.128	.1268	.157
23	1.5733	.123	.1257	.0884	.131	.1345	.1498
24	1.6881	.7926	.1169	.0823	.1105	.1059	.1078
Max	1.8671	2.1768	2.4078	2.1525	2.3746	2.3247	2.0237
Min	.0343	.0343	.093	.0408	.0777	.045	.0663
Avg	.7761	.7324	.7970	.7228	.7533	.7714	.5543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 202 / CHACHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	.0343	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343	.0343	.0343	.0343
8	.0343	.0343	.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.0343		.0343	.0343
12	.0343	.0343	.0343	.0343	.0343	.0343	.0343
13	.0343	.0343	.0343	.0343	.0343	.0343	.0343
14	.0343	.0343	.0343	.0343	.0343	.0343	.0343
15	.0343	.0343	.0343	.0343	.0343	.0343	.0343
16	.0343	.0343		.0343	.0343	.0343	.0343
17	.0343	.0343	.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0514	.0343	.0514	.0343	.0343	.0514
21	.0343	.0457	.0343	.0514	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0514
23	.0343	.0514	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0343	.0514	.0343	.0514	.0343	.0343	.0514
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0343	.0362	.0343	.0357	.0343	.0343	.0357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 203 / DHEBEWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.583	.4973	.5144	.5144	.5316	.5658
2	.6173	.5487	.4801	.4801	.4973	.5316	.5487
3	.5144	.5144	.4973	.4801	.4801	.5144	.5144
4	.5487	.5487	.4801	.4801	.4801	.5487	.583
5	.583	.583	.4801	.5144	.4801	.583	.6516
6	.583	.6173	.6001	.583	.5658	.6344	.6859
7	.7202	.6687	.6344	.6516	.6173	.6859	.6859
8	.6173	.6001	.5487	.5658	.583	.6173	.6001
9	.5487	.583	.6001	.5487	.5144	.583	.6173
10	.6859	.463	.5487	.6344	.5487	.6516	.6859
11	.7545	.463	.6516			.6173	.6859
12	.7888	.6516	.6859		.5487	.7202	.6687
13	.6859	.6001	.6859		.583	.6859	.6516
14	.6344	.6344	.5487		.583	.583	.5316
15	.6001	.6859	.583	.2058	.583	.7545	.6687
16	.5487	.6344		.2401	.5487	.7202	.7202
17	.6173	.6859	.583	.2058	.583	.7545	.6344
18	.5487	.6516	.7545	.583	.6173	.6516	.5658
19	.7716	.8059	.9088	.8059	.823	.823	.7373
20	.9945	.9088	.9259	.9431	.9945	.9774	.9602
21	.9602	.9431	.9088	.8573	.8745	.9088	.8916
22	.823	.8745	.8916	.7716	.7545	.823	.823
23	.6859	.6001	.7202	.6687	.6344	.6859	.6516
24	.6516	.6516	.5316	.5487	.5144	.5658	.6001
Max	.9945	.9431	.9259	.9431	.9945	.9774	.9602
Min	.5144	.463	.4801	.2058	.4801	.5144	.5144
Avg	.6709	.6459	.6411	.5641	.6054	.6730	.6637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 204 / KOLE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2401	.2801	.2743	.2743	.2743	.2572
2	.2743	.2401	.2572	.2743	.2743	.2401	.2401
3	.2743	.2401	.2401	.2401	.2572	.2401	.2401
4	.2743	.2743	.2572	.2743	.2572	.2401	.2401
5	.3086	.2743	.2572	.2915	.2572	.2743	.2743
6	.3086	.3086	.3258	.3429	.3258	.3429	.3258
7	.3086	.3258	.3258	.3944	.3772	.3429	.3429
8	.2743	.3086	.3086	.3258	.3429	.3258	.3429
9	.2743	.2915	.2915	.2915	.2743	.3086	.2743
10	.2743	.2743	.2743	.2572	.2743	.2743	.2572
11	.2743	.2743	.2401	.2401		.2743	.2401
12	.2915	.3086	.3086		.3429	.2743	.2743
13	.2915	.2915	.3086		.3429	.3086	.3429
14	.2743	.3086	.2743		.3086	.3086	.3429
15	.2572	.3086	.3086	.3086	.3086	.3086	.3258
16	.2915	.3429		.3429	.3429	.3086	.3086
17	.2915	.3429	.2743	.3086	.2743	.2743	.2743
18	.2743	.2743	.2743	.3086	.2401	.2743	.2743
19	.3772	.3944	.4458	.3601	.3772	.3772	.3258
20	.4801	.463	.4801	.4458	.463	.4458	.4287
21	.4115	.4115	.4458	.4115	.4287	.4458	.4287
22	.3772	.3601	.4115	.3772	.3944	.3944	.3944
23	.3086	.3086	.3601	.3258	.3429	.3429	.3258
24	.2743	.2743	.2743	.3086	.2915	.3086	.2915
Max	.4801	.463	.4801	.4458	.463	.4458	.4287
Min	.2572	.2401	.2401	.2401	.2401	.2401	.2401
Avg	.3050	.3101	.3141	.3192	.3206	.3129	.3072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 205 / CHACHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.7392	.8733	.7133	.7194	.0343
2	.0343	.0343	.7041	.7963	.6699	.7331	.0343
3	.0343	.0343	.6996	.7902	.6524	.73	.0343
4	.0343	.0343	.6745	.7384	.6637	.7236	.0343
5	.0343	.0343	.6691	.7765	.6676	.7815	.0343
6	.0343	.0343	.7377	.8456	.7819	.8581	.0343
7	.0343	.0343	1.0448	1.1724	1.1195	1.1873	.0343
8	.0343	.0343	1.0342	1.1252	.6851	1.1759	.0343
9	1.0059	.9815	.4748	.4915	.5578	.5327	.977
10	1.2102	1.1035	.0343	.0343	.0343	.0343	1.1126
11	1.0989	1.0455	.0343	.0343		.0343	1.198
12	1.0349	.9861	.0343	.0343	.0343		.9769
13	1.0273	.9054	.0343	.0343	.0343		1.0509
14	.9854	.868	.0343	.0343	.0343		.9815
15	.8985	.9347	.0343	.0343	.0343	.0343	.9481
16	.9168	.9222	.0343	.0343	.0343	.0343	1.1241
17	.4603	.4519	.0343	.0343	.0343	.0343	.6104
18	.0343	.0373	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.74	.8931	.7827	.1235	.0343	.0343
24	.0343	.4641	.8055	.8566	.3383	.0343	.0343
Max	1.2102	1.1035	1.0448	1.1724	1.1195	1.1873	1.198
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.3814	.4105	.3718	.4039	.3211	.3740	.3956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 206 / TALMAVALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.4918	.0343	.0343	.0343	.0343	1.7147
2	1.2346	1.4403	.0343	.0343	.0343	.0343	1.749
3	1.2346	1.406	.0343	.0343	.0343	.0343	1.6975
4	1.2346	1.3717	.0343	.0343	.0343	.0343	1.6804
5	1.2346	1.406	.0343	.0343	.0343	.0343	1.8347
6	1.2346	1.4232	.0343	.0343	.0343	.0343	2.1262
7	1.6461	1.8861	.0343	.0343	.0343	.0343	2.572
8	1.6461	1.6461	.0343	.0343	.0343	.0343	2.6578
9	.0343	.0343	2.332	2.1948	2.1091	2.3834	.0343
10	.0343	.0343	2.4348	2.1605	2.2291	2.2805	.0343
11	.0343	.0343	2.1948	2.0576		2.0576	.0343
12	.0343	.0343	2.0576	1.9204	2.0576	2.0576	.0343
13	.0343	.0343	1.9204		2.0576	2.0576	.0343
14	.0343	.0343	1.9204	.6173	1.7833	1.9204	.0343
15	.0343	.0343	1.749	.6859	1.6461	1.7833	.0343
16	.0343	.0343	1.749	.6859	1.6461	1.7833	.0343
17	.0343	.0343	.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	1.5775	.0343	.0343	.0343	.0343	.0343	.0343
24	1.3717	1.5432	.0343	.0343	.0343	.0343	.0343
Max	1.6461	1.8861	2.4348	2.1948	2.2291	2.3834	2.6578
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.5916	.5887	.7045	.4727	.6121	.7030	.6909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 201 / YELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.787	1.0269	1.0562	1.0456	1.0349	.695
2	.7316	.8124	.9896	1.0185	1.0269	1.0082	.6805
3		.8124	.9335	1.0185	1.0082	.9896	.6602
4		.8333	.8962	.9808	.9709	.9709	.6923
5		.9105	.9335	.9808	1.0082	1.0164	.7676
6	.9998	1.0136	.9979	1.0185	1.0456	1.0317	.8429
7	1.6248	1.419	1.1827	1.0829	1.0642	1.0208	1.1003
8	1.448	1.1431	.9412	.9979	.9694	1.0136	1.0987
9	.9998	.9593	1.6137	2.1765	1.1439	1.4198	.905
10	.8859	.788	1.6507	1.286		1.2498	.9955
11	.9313	.788	1.3213	1.3466		1.0623	.8954
12	.9492	.8596	1.302	1.2445		1.0669	.9955
13	.9568	.9134	1.3329	1.0717	1.0936	.9755	1.0208
14	.8417	.9231	1.2765	1.1145	1.0364	1.0364	1.0208
15	.9671	.9774	1.3672	1.0717	1.0242	1.0364	1.0136
16	.8682	.9313		.7331	.9998	1.0059	.9955
17	.8859	.905	.8322	.3814	.8063	.3982	.3761
18	.8505	.8238	.905	.8842	.8413	.964	.905
19	1.3998	1.2489	1.4415	1.267	1.3321	1.3032	1.3535
20	1.8204	1.9404	1.9978	1.9774	1.858	1.9959	2.0911
21	1.8229	1.9418	1.9418	1.9589	1.8204	1.9774	1.9418
22	1.6655	1.7177	1.6804	1.7372	1.6301	1.8296	1.6804
23	1.0802	1.2323	1.3203	1.2696	1.2851	1.3491	1.3817
24	.823	.8488	1.1203	1.1317	1.0269	1.1088	1.1576
Max	1.8229	1.9418	1.9978	2.1765	1.858	1.9959	2.0911
Min	.7316	.787	.8322	.3814	.8063	.3982	.3761
Avg	1.1111	1.0638	1.2611	1.2003	1.1446	1.1611	1.0528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 202 / YEWATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4715	1.4811	1.3455	1.6461	1.7162	1.5016	1.5716
2	1.4102	1.4007	1.2984	1.4975	1.5956	1.492	1.5352
3	.7964	1.3914	1.2414	1.4399	1.5062	1.4495	1.5064
4		1.3779	1.246	1.4799	1.5615	1.5245	1.5354
5		1.4307	1.4632	1.6918	1.7044	1.7535	1.6415
6	1.8092	1.4945	2.1975	2.4219	2.3914	2.4743	1.7729
7	1.707	1.53	3.0544	3.6405	3.3926	3.1461	1.3348
8	1.3878	1.3422	2.8202	3.2731	3.049	2.8972	1.4274
9	3.3829	3.0921	1.2384	1.1904	1.2072	1.2605	5.005
10	3.2998	2.8867	1.1195	1.0589	.7034	1.1839	5.1071
11	3.135	2.6818	1.1249	.8799	.7072	1.2544	4.8481
12	2.9138	2.4051	1.118	.8575	.8185	1.3702	4.6578
13	2.4236	2.1631	1.1088	.8385	1.326	1.3801	4.7538
14	1.6182	2.1551	1.2414	.8162	1.3283	1.3931	4.7584
15	2.3219	2.3183	1.2566	.9109	1.2993	1.4312	4.7611
16	2.4653	2.3413	.7522	.8747	1.2087	1.4255	4.6573
17	1.1855	1.1736	1.227	1.1701	1.0738	1.3268	1.1976
18	1.1492	1.1263	1.2239	1.1393	1.2888	1.2902	1.2376
19	1.8229	1.7117	1.8915	1.8168	1.8518	2.015	2.1057
20	2.3635	2.4169	2.5888	2.482	2.3703	2.5859	2.5392
21	2.3343	2.4404	2.5286	2.4442	2.4196	2.5987	2.5858
22	2.1285	2.247	2.3252	2.2916	2.2603	2.4052	2.4128
23	1.8637	1.6605	2.0942	2.138	1.9189	2.2992	2.0492
24	1.6164	1.531	1.6682	1.9029	1.737	1.8915	1.7131
Max	3.3829	3.0921	3.0544	3.6405	3.3926	3.1461	5.1071
Min	.7964	1.1263	.7522	.8162	.7034	1.1839	1.1976
Avg	2.0276	1.9083	1.6322	1.6626	1.6848	1.8063	2.7798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 203 / UNDALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8109	.9374	1.0829	1.0562	1.0642	1.1088	.8109
2	.8025	.9217	1.0456	1.0185	1.0456	1.0751	.7819
3		.9105	1.0269	.9808	1.0269	1.0164	.8069
4	.8573	.9061	1.0082	.9808	.9896	.9795	.8429
5		.9362	1.0269	1.0185	1.0456	.9896	.873
6	1.1111	1.0084	1.0534	1.0562	1.0642	1.0719	.9783
7	1.4861	1.3575	1.1088	1.1576	1.1203	1.1041	1.2616
8	1.291	1.2407	1.0498	.9774	1.0242	1.0745	1.1544
9	.8573	.9671	1.423	1.39	1.2643	1.4784	.9412
10	.8328	.8596	1.3611	1.2146		1.1149	1.0317
11	.9134	.8775	1.1961	1.086		1.0433	1.0208
12	.985	.9313	1.0212	.9469		1.0433	1.0566
13	.9391	1.0208	.8551	.9412	1.0292	.9736	1.086
14	1.0387	1.086	.9574	.9412	.9877	.7049	1.086
15	1.0566	1.1222	1.0254	.9717	1.057	1.0002	1.1999
16	1.0631	1.1462		1.0002	1.1203	1.0425	1.2308
17	1.0985	1.1041	1.0402	.9816	.5868	1.0517	1.1462
18	.7442	1.0517	1.262	.6415	.9214	.6661	1.0631
19	1.4548	1.3394	1.7013	1.3937	1.4706	1.5565	1.2803
20	1.6832	1.7741	1.848	1.7372	1.5604	1.8111	1.7741
21	1.595	1.643	1.7551	1.6078	1.6476	1.7002	1.6804
22	1.4373	1.5497	1.6057	1.5708	1.543		1.643
23	1.1092	1.2696	1.358	1.2696		1.4045	1.3443
24	.8573	.9414	1.1389	1.1317	1.0829	1.1827	1.2323
Max	1.6832	1.7741	1.848	1.7372	1.6476	1.8111	1.7741
Min	.7442	.8596	.8551	.6415	.5868	.6661	.7819
Avg	1.0920	1.1209	1.2153	1.1280	1.1326	1.1389	1.1386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 201 / TAMBVE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4548	1.4098	2.905	3.4072	3.4019	3.3417	1.544
2	1.3999	.7331	2.6924	3.2008	3.216	3.2572	1.4967
3	1.3847	.7202	2.6398	3.0849	2.9957	3.1367	1.496
4	1.3047	.7019	2.6269	3.0438	2.921	2.937	1.4899
5	1.3938	.7171	2.6345	3.1679	2.9782	2.937	1.363
6	1.5356	.7621	3.1284	3.4736	3.3707	3.3585	1.4247
7	1.4251	.7484	3.7624	4.0962	3.898	4.1137	1.5356
8	1.1416	1.2277	3.7533	3.8287	4.0261	3.9445	1.2841
9	4.555	4.6494	1.6278	1.4488	1.7093	1.7162	4.614
10	4.7603	4.654	.9587	.9533	.5068	.9122	4.7897
11	4.5596	4.273	.9777	.9952	.3628	.7476	4.5965
12	4.1983	3.991	.9922	1.0631	.4908	.8634	3.9296
13	3.9224	3.6557	1.0639	1.1736	.9975	.7575	.977
14	3.5886	3.4561	1.1172	1.1919	1.0425	.8261	3.6377
15	3.5513	3.4141	1.2133	1.2277	1.0631	1.4502	3.8032
16	3.6436	3.3988	.6127	1.2254	1.2133	1.3511	3.7929
17	1.8404	1.8054	1.1667	1.2018	1.1302	1.2811	1.6613
18	1.1843	1.1187	1.0646	1.1591	1.0394	1.3214	1.1202
19	1.5219	1.6077	1.5165	1.5181	1.5378	1.5219	1.454
20	2.1147	2.1727	1.9951	2.1125	2.1841	2.1666	2.1269
21	1.0921	2.1502	2.1079	2.1292	2.1316	2.1422	2.1185
22	2.1033	2.0715	2.0226	2.0386	2.1339	2.1185	2.1041
23	1.8861	3.4812	3.8813	3.7091	2.2572	1.9639	1.9784
24	1.5691	2.5545	3.5475	3.6603	2.5843	1.627	1.6477
Max	4.7603	4.654	3.8813	4.0962	4.0261	4.1137	4.7897
Min	1.0921	.7019	.6127	.9533	.3628	.7476	.977
Avg	2.3805	2.3114	2.0837	2.2546	2.0497	2.0747	2.3327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 202 / SAJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3784	.3502	1.9246	1.9871	1.88	1.9292	.3845
2	.3494	.3441	1.8549	1.9208	1.7676	1.906	.3776
3	.346	.3418	1.8183	1.8187	1.7059	1.7235	.3768
4	.3338	.3342	1.8305	1.8057	1.7013	1.2357	.3765
5	.3502	.3414	1.8252	1.8294	1.7048	1.1938	.4089
6	.4039	.3822	2.0259	1.9185	1.986	2.0782	.3995
7	.3967	.4264	2.3388	2.3228	2.2378	2.3061	.4199
8	.3281	.3829	2.2116	2.3571	2.3804	2.2459	.3464
9	2.7805	2.3514	.8558	.8379	.98	.889	2.3929
10	2.8098	2.8121	.2831	.301	.1673	.3193	2.7027
11	2.721	2.6753	.2881	.2717	.1901	.3098	2.6162
12	2.6775	2.5293	.2793	.3002	.1989	.3319	.9084
13	1.2887	2.3579	.3041	.3041	.3707	.3349	1.938
14	2.3012	2.2261	.3129	.3105	.3387	.2903	2.3632
15	2.2821	2.2352	.3205	.3357	.3467	.232	2.4931
16	2.0523	2.2897	.1791	.3349	.3509	.2393	2.3884
17	1.1408	.9621	.3559	.3418	.3289	.1958	.085
18	.3277	.3105	.3742	.3006	.3205	.3898	.0198
19	.3822	.4074	.4512	.4535	.4744	.5087	.0244
20	.5631	.5335	.5617	.5521	.5792	.5814	.4614
21	.2839	.5304	.5705	.5419	.5682	.5094	.6611
22	.5438	.5236	.5472	.5175	.5495	.5564	.6481
23	.4794	2.0343	2.236	2.0066	.6817	.4851	.5586
24	.3989	1.2913	2.0504	2.0333	1.1706	.4115	.2477
Max	2.8098	2.8121	2.3388	2.3571	2.3804	2.3061	2.7027
Min	.2839	.3105	.1791	.2717	.1673	.1958	.0198
Avg	1.0800	1.2072	1.0750	1.0710	.9575	.8835	.9833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 203 / AREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3528	.3277	.7171	.9221	.9221	.9206	.3826
2	.346	.3162	.6684	.8436	.8368	.8878	.3582
3	.3429	.3117	.6668	.7605	.8002	.8665	.3498
4	.3063	.3048	.6356	.7674	.775	.7926	.3452
5	.2987	.3071	.6646	.7972	.801	.8131	.3475
6	.3315	.3262	.9609	.9808	.9747	.9084	.3536
7	.2888	.3124	1.2498	1.304	1.3458	1.2422	.3658
8	.2766	.2987	1.1508	1.2841	1.2986	1.2696	.317
9	.9297	1.2261	.5895	.6096	.6855	.6378	1.2624
10	1.3702	1.2913	.2377	.2492	.1341	.3437	1.2533
11	1.2956	1.3181	.2564	.2004		.333	1.3135
12	1.1393	1.1371	.2747	.3033	.1738	.3742	1.2498
13	1.0425	.9259	.3349	.3155	.3418	.3513	1.1176
14	.9419	.8886	.2892	.3269	.3471	.3856	.9518
15	.9853	.8901	.3072	.3544	.3239	.3749	1.0148
16	1.0684	.9205	.1524	.3109	.3524	.4115	1.108
17	.6363	.5616	.2301	.3262	.3384	.3818	.6531
18	.2682	.2995	.3323	.3124	.3479	.4001	.3239
19	.4123	.3589	.4405	.3658	.3879	.474	.3727
20	.5343	.5453	.6112	.5304	.6012	.6287	.5807
21	.2919	.5484	.5826	.5396	.5926	.615	.5165
22	.5411	.5423	.5655	.5335	.543	.5829	.5845
23	.4756	.6992	.9572	.9861	.5259	.4885	.5213
24	.3765	.6051	.8962	.9763	.7155	.4047	.4146
Max	1.3702	1.3181	1.2498	1.304	1.3458	1.2696	1.3135
Min	.2682	.2987	.1524	.2004	.1341	.333	.317
Avg	.6189	.6360	.5738	.6208	.6159	.6204	.6691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 204 / TAMBAVE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2458	.8779	.1543	.4207	.439	.3441
2	.3658	.8779	.1543	.4755	.439	.4752
3	.0328	.8779	.1543	.4755	.439	.4915
4	.1646	.8779	.1543	.4755	.4755	.4915
5	.6882	.8779	.8048	.4755	1.0974	.9012
6	.6882	.9145	.823	.4755	1.134	1.0322
7	.7045	.9145	.823	.5121	1.134	1.0322
8	.7865	.9145	.9511	.5041	1.2071	.9831
9	.8596	.9145	.9709	.1086	1.1797	1.0159
10	.8596	.9145	.9709		1.0978	.9995
11	.8596	.9145	.9709		1.0322	1.0159
12	.8238	.9145	.9709		1.065	
13	.8596	.8596	1.1203	.5228	1.0159	.9667
14	.788	.8596	1.1576	.5228	1.0814	1.0159
15	.8779	.8596	1.1576	.4854	1.0978	.4752
16	.5121	.2743		.4854	.4424	.5898
Max	.8779	.9145	1.1576	.5228	1.2071	1.0322
Min	.0328	.2743	.1543	.1086	.439	.3441
Avg	.6323	.8528	.7559	.4569	.8986	.7887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254056 / 33/11 KV KALE

Feeder No / Name : 202 / PACHWAD

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.186	.8381	.8322	1.1843	1.1227	.8025
2	1.1702	.8381	.8322	1.1843	1.1227	.8025
3	1.1702	.8381	.8322	1.1843	1.1227	.8025
4	1.1702	.8381	.8322	1.1843	1.1227	.8025
5	1.1702	.8381	.8322	1.1843	1.1227	.8025
6	1.1843	.8482	.8322	1.1843	1.1523	.8025
7	.2397	.8381	.8322	1.1843	1.166	.8322
8	.8065	.8482	1.1683	1.2003	1.166	1.0082
9	.7116	.8482	1.1984	1.2003	1.1822	1.2003
10	.7116	.0109	1.1984	1.186		1.2003
11	.6009	.6093	1.2003	1.186		1.2146
12	.3963	.828	.9842	1.1544		
13	.8025	.8436	.9877	.9783	.8381	1.142
14	.8025	.8436	1.1561	1.0279	.8381	1.1702
15	.8124	.8539	1.1405	1.2003	.8381	1.2146
16	.0126	.0168		.1947	.008	.1947
Max	1.186	.8539	1.2003	1.2003	1.1822	1.2146
Min	.0126	.0109	.8322	.1947	.008	.1947
Avg	.8092	.7237	.9906	1.1011	.9848	.9328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254064 / 33/11 KV WING

Feeder No / Name : 201 / 11 KV Wing AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.208	.3366	2.7938	2.8086	2.625	2.5789	.2829
2	.1715	.3439	2.8235	2.7606	2.1872	2.552	.2829
3		.3258	2.7109	2.774	2.3746	2.5606	.2829
4	.1509	.3361	2.894	2.7435	2.3746	2.6242	.2829
5	.1886	.2801	2.8567	2.7778	2.451	2.7073	.3018
6	.2263	.2772	3.006	2.915	2.7041	2.7633	.3206
7	.2829	.2715	3.3634	3.2236	3.0519	2.9199	.3206
8	.3206	.3511	2.6155	2.8292	2.5934	2.5606	.3395
9	2.5446		.2641	.2195	.2641	.2374	2.5775
10	2.8622		.2641	.2103	.2452	.218	2.8306
11	2.8967		.2263	.128			2.8306
12	2.7673	3.1379	.2452	.1097	.2075		
13	2.7041	2.9321	.2829	.128	.2263		
14	2.5621	2.8635	.2641	.128	.2829		2.0399
15	2.5465	2.7778	.1886	.2743	.2452	.2683	2.8327
16	2.6558	2.7606		.3206	.2452	.2515	2.6724
17	.2534		.3206	.3018	.3018	.3018	.2374
18	.2926	.3109	.3018	.2801	.2926	.3018	.3086
19	.3475	.3258	.3206	.3547	.3475	.3772	.3258
20	.3544	.3841	.3584	.3584	.3292	.415	.3403
21	.4024	.3734	.3584	.3506	.3506	.3395	.3439
22	.362	.3658	.3772	.3395	.3475	.3584	.362
23	.3292	2.652	2.722	2.5301	.3109	.3206	.2896
24	.2427	.3109	2.8715	2.915	2.7357	.2561	.2829
Max	2.8967	3.1379	3.3634	3.2236	3.0519	2.9199	2.8327
Min	.1509	.2715	.1886	.1097	.2075	.218	.2374
Avg	1.1162	1.0859	1.4100	1.3242	1.178	1.2456	.9404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254064 / 33/11 KV WING

Feeder No / Name : 202 / 11 KV Wing Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3814	.3814	.4252	.439	.3544	.3898	.4481
2	.3429	.3856	.3898	.4251	.3366	.3506	.4294
3		.4252	.3641	.4024	.3189	.3121	.4108
4	.3898	.4784	.3898	.4066	.3012	.3898	.4108
5	.4252	.4835	.4031	.4435	.3366	.4252	.4481
6	.4557	.5316	.4784	.5175	.4161	.4557	.5041
7	.4801	.567	.5493	.5914	.4973	.5316	.5415
8	.4973	.5014	.5138	.5729	.4359	.4908	.4854
9	.503	.5373	.4694	.5083	.5175	.5256	.4694
10	.4475		.4588	.5316	.5041	.5256	.431
11	.4588		.4424	.4784		.503	.4424
12	.4372	.5373	.426	.443	.499	.4973	.4858
13	.426	.4656	.426	.4607	.499	.4641	.4586
14	.426	.4298	.4144	.4031	.4854	.4024	.427
15	.4144	.4298	.3978	.3898	.4854	.3688	.3795
16	.4588	.4477		.4207	.5228	.4359	.3953
17	.4784		.4656	.3932	.4854	.5175	.4748
18	.4908	.631	.567	.421	.4961	.5175	.5144
19	.5784	.6516	.6838	.5087	.6135	.6653	.5487
20	.6661	.6379	.7023	.5895	.6135	.6653	.6089
21	.5959	.5784	.6283	.5609	.6024	.6283	.5792
22	.5373	.5083	.5544	.4961	.5316	.5544	.5611
23	.4784	.4557	.499	.4252	.4557	.499	.4706
24	.4161	.4252	.4207	.4435	.3898	.4075	.4481
Max	.6661	.6516	.7023	.5914	.6135	.6653	.6089
Min	.3429	.3814	.3641	.3898	.3012	.3121	.3795
Avg	.4689	.4995	.4813	.4697	.4651	.4801	.4739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 201 / 11 KV Kasarshirambe Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.0631	.2058	.1886	.2058	.2033	.9335
2	.9431	1.0288	.2058	.1886	.2058	.2033	.9335
3	.9431	1.0288	.2058	.1867	.2058	.2033	1.1317
4	.9774	1.0802	.2058	.2075	.2058	.2033	1.226
5	1.0631	1.0802	.2058	.2075	.2058	.2033	1.5089
6	1.1488	1.2986	.2058	.2075	.2058	.2033	1.5089
7	1.829	1.7556	.2058	.2263	.2452	.2195	1.7918
8	1.647	1.5729	.2058	.2378	.2263	.2561	1.5089
9	.2075	.1698	1.957	1.8671	2.0452	1.9427	.2075
10	.1698	.1509	1.8473	1.7375		1.9239	.1886
11	.2075	.1886	1.7194			1.7918	.2263
12	.1886	.1886	1.5384		1.6804	1.6975	.1791
13	.1886	.1886	1.4842		2.009	1.3957	.197
14	.1886	.2075	1.448		1.7194	1.358	.1698
15	.2075	.1886	1.39		1.5927	1.307	.1886
16	.1698	.2075			1.5746	1.4712	.1886
17	.1886	.1772	.2054	.2058	.1715	.1949	.1772
18	.12	.1753	.1578	.1886	.208	.2172	.1949
19	.2149	.2378	.2126	.2254	.2279	.2195	.2772
20	.2715	.2587	.2126	.3077	.2402	.2743	.2801
21	.2801	.2641	.2481	.2801	.2743	.2561	.2801
22	.2801	.2641	.2561	.2801	.2801	.2378	.2452
23	1.1317	.2452	.2012	.2427	.2614	.2195	.2075
24	.9602	1.0974	.2263	.2054	.2241	.2054	.2195
Max	1.829	1.7556	1.957	1.8671	2.0452	1.9427	1.7918
Min	.12	.1509	.1578	.1867	.1715	.1949	.1698
Avg	.6036	.5883	.6413	.3995	.6461	.6837	.5821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 202 / 11 KV Malkhed

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406	1.9204	1.8861	1.8861	1.4403	1.3817
2		2.0576	2.0576	2.0538	2.0919	1.6804
3	2.0576	2.0919	2.0576	2.2634	2.1091	1.8861
4	2.1434	2.1091	2.0748	2.2634	2.1091	1.8861
5	2.1434	2.0919	2.0919	2.2779	2.1262	2.2634
6	2.1434	2.268	2.0748	2.32	2.1262	2.3011
7	2.2314	2.2624	1.8519	2.2779	2.32	2.32
8	2.2443	2.3228	2.0919	2.2779	2.3765	2.32
9	2.2634	2.3388	2.2131	2.2779	2.2624	2.3765
10	2.2445	2.32	2.1948	2.1719		2.2445
11	1.9805	2.3011	2.1538			2.3011
12	2.3011	2.2822	2.0995		1.2689	
13	2.0559	2.3011	2.0995		2.19	
14	2.2634	2.3388	1.9909		2.1719	.2075
15	2.3011	2.32	1.9909		2.1538	.3584
16	2.1313	2.1125			2.0633	2.32
24	.0686		.1886		.168	
Max	2.3011	2.3388	2.2131	2.32	2.3765	2.3765
Min	.0686	1.9204	.1886	1.8861	.168	.2075
Avg	1.9987	2.2149	1.9449	2.2070	1.9318	1.8462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 203 / 11KV Kalawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.12	.132	.1543	.1663	.168
2	.1372	.1372	.12	.132	.1372	.1663	.1698
3	.1372	.1372	.12	.1307	.1372	.1478	.1698
4	.1372	.1372	.12	.1509	.1372	.1478	.1886
5	.1372	.1372	.12	.1698	.1372	.1478	.1698
6	.1372	.128	.12	.1509	.1372	.1294	.1886
7	.1463	.1629	.1029	.1509	.1886	.1829	.1698
8	.1629	.1646	.1372	.1307	.1886	.1646	.1867
9	.132	.132	.1463	.1307	.1629	.1509	.132
10	.132	.1132	.1463	.1267		.1698	.1509
11	.132	.132	.0905			.1698	.1509
12	.1132	.1509	.1086		.1715	.1886	.1612
13	.132	.1698	.1448		.1629	.1698	.1612
14	.132	.1509	.1267		.1629	.1494	.1698
15	.1509	.1509	.1448		.181	.132	.1509
16	.1509	.1698			.181	.1509	.1698
17	.1372	.1417	.168	.2058	.1715	.1772	.1595
18	.1372	.1578	.1578	.2058	.1734	.1991	.1595
19	.2149	.2012	.2012	.208	.2279	.2378	.1848
20	.2353	.2772	.2303	.2534	.2402	.2561	.2427
21	.2054	.2263	.2126	.2241	.2378	.2561	.2427
22	.2054	.2075	.2012	.2241	.2241	.2195	.2263
23	.1543	.1698	.168	.1867	.2054	.2054	.1886
24	.1543	.1543	.1509	.1307	.168	.168	.1646
Max	.2353	.2772	.2303	.2534	.2402	.2561	.2427
Min	.1132	.1132	.0905	.1267	.1372	.1294	.132
Avg	.1521	.1603	.1460	.1691	.1767	.1772	.1761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 203 / NANDGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0837	1.2037	.7468	.7095	.7095	.7655	1.034
2	1.0837	1.1279	.6908	.6908	.6908	.7282	1.0753
3	1.0551	1.0837	.6908	.6908	.6908	.7282	.9907
4	1.0551	1.0837	.6722	.6722	.6908	.7095	1.0517
5	1.0551	1.2041	.6908	.6908	.7167	.7545	1.1111
6	1.2654	1.4529	.8316	.8215	.8676	.7947	1.5023
7	2.1605	2.2405	.8686	.8215	.8686	.7947	2.0557
8	1.8827	1.7654	.6219	.5853	.6219	.7316	1.7553
9	.543	.5068	2.0805	1.9509	1.929	1.9685	.567
10	.5731	.5138	2.1506	1.9509		1.8435	.5853
11		.5138	1.8747	1.768		1.6857	.5487
12		.5138	1.5752	1.5653		1.5352	.5973
13		.567	1.423	1.2689	1.6716	1.3426	.6089
14		.5731	1.423	1.2492	1.4815	1.2346	.6036
15	.7186	1.0791	1.4712	1.2955	1.4373	1.1736	.6283
16	.7265	.6661		1.3998	1.4937	1.358	.6335
17	.631	.6447	.5959	.5792	.5973	.6556	.6268
18	.5959	.6468	.6241	.5731	.591	.6135	.5609
19	.7783	.8145	.8145	.823	.8048	.788	.8145
20	1.0349	.9896	.9979	1.0642	1.0719	1.0349	.9795
21	.9979	.9896	.9795	1.0082	1.0269	.9795	1.0082
22	.9896	.9431	.9709	.9522	1.0082	.9709	.9896
23	1.3923	.8402	.811	.811	.8589	.8402	.8215
24	1.1888	1.2963	.7468	.7468	.7468	.7655	.7577
Max	2.1605	2.2405	2.1506	1.9509	1.929	1.9685	2.0557
Min	.543	.5068	.5959	.5731	.591	.6135	.5487
Avg	1.0406	.9692	1.0588	1.0287	.9798	1.0332	.9128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 205 / RETHARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8778	2.1628	.9431	.9431	.9431	.9808	1.945
2	1.7772	2.079	.9431	.9431	.9242	.9431	1.8747
3	1.7604	2.0056	.9242	.9054	.9054	.9431	1.8278
4	1.7238	2.0056	.8865	.9054	.8676	.9619	1.8122
5	1.8233	2.0388	.9054	.9054	.8488	.9431	1.866
6	2.146	2.0622	.9619	.9896	.9619	.9795	2.2245
7	2.4741	2.4863	.8589	.9149	.8962	.9896	2.5526
8	2.4291	2.4863	.7392	.7095	.7207	.8316	2.3087
9	.6878	.7865	3.0178	2.7846	2.7349	2.8664	.6653
10	.4938	.724	2.9172	2.834		2.7686	.7499
11		.7783	2.8675	2.8346		2.8487	.8779
12		.7701	2.8509	2.6871	2.9007	2.5934	.8596
13		.8215	2.7368	2.5286	2.9504	2.5301	.9328
14		.8402	2.6073	2.5069	2.6852	2.4827	.924
15	1.0679	.8596	2.5911	2.5069	2.652	2.2809	.9055
16	.9877	.8238	2.1792	2.4646	2.4939	2.4215	.9055
17	.7783	.7783	.815	.6516	.7865	.9036	.7316
18	.7783	.724	.7522	.7059	.8145	.8775	.788
19	1.0425	1.0349	1.0242	.9979	1.0164	1.0791	1.0608
20	1.3443	1.2883	1.3256	1.2696	1.363	1.3256	1.363
21	1.3443	1.251	1.3256	1.2883	1.3817	1.3443	1.419
22	1.2696	1.3014	1.3256	1.2637		1.363	1.3817
23	2.4417	1.1317	1.1506	1.1128	1.1949	1.2136	1.226
24	1.9616	2.2466	.9808	.9997	.9997	1.0374	1.094
Max	2.4741	2.4863	3.0178	2.8346	2.9504	2.8664	2.5526
Min	.4938	.724	.7392	.6516	.7207	.8316	.6653
Avg	1.5105	1.3953	1.5679	1.5272	1.4782	1.5629	1.3457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 206 / KALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8656	2.5095	1.3014	1.3203	1.3203	1.3256	2.9005
2	2.7469	2.4247	1.2826	1.2826	1.2826	1.3203	2.8012
3	2.6113	2.696	1.226	1.2449	1.2826	1.3014	2.7664
4	2.6282	2.5434	1.2449	1.226	1.2449	1.3014	2.7664
5	2.696	2.3569	1.2826	1.3203	1.2637	1.3392	3.103
6	3.1207	3.0864	1.3769	1.3957	1.3392	1.307	3.5439
7	3.3867	2.9334	1.2323	1.2012	1.2382	1.307	3.8561
8	3.0849		1.0242	.9795	.9511	1.0425	3.5376
9	.9145	1.1765	4.2221	3.8729	4.213	3.9903	.9877
10	.8869	.8688	4.256			4.3088	.8779
11		.9134	4.0741			4.1747	.9511
12		.985	3.6631		4.0314	3.9735	1.0425
13		1.0059	3.5968		4.2476	3.6885	1.0242
14		1.0425	3.5968		4.1436	3.4873	1.0903
15	1.2489	1.0791	3.4476		3.8142	2.4531	1.1088
16	1.1765	.9774	2.915		3.5099	3.0312	1.0974
17	1.0924	.9593	.985	1.3717	.9955	.9671	.9671
18	1.0208	.9955	.9745	1.2178	1.0136	1.0208	.8596
19	1.2986	1.262	1.3352	1.4815	1.423	1.4083	1.3352
20	1.7924	1.7177	1.7924	1.9404	1.8671	1.848	1.8298
21	1.8298	1.7551	1.8111	1.9231	1.9418	1.9044	1.8671
22	1.7551	1.7737	1.7737	1.8111		1.8858	1.8298
23	3.275	1.5497	1.5684	1.587	1.6804	1.6057	1.587
24	3.0352	3.0013	1.363	1.358	1.3817	1.4563	1.4003
Max	3.3867	3.0864	4.256	3.8729	4.2476	4.3088	3.8561
Min	.8869	.8688	.9745	.9795	.9511	.9671	.8596
Avg	2.1233	1.7223	2.1394	1.5608	2.1041	2.1437	1.8805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 201 / 11 KV NAGARPALIKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0973	2.0767	2.0812	2.1026	2.0995	2.2382	2.2436
2	1.938	1.9715	1.9502	1.9632	1.9494	2.0576	2.0972
3	1.8793	1.906	1.8351	1.8979	1.9022	1.9669	2.0386
4	1.8503	1.8809	1.7707	1.7924	1.8427	1.8808	1.9189
5	1.816	1.8488	1.7524	1.7947	1.8381	1.8587	1.8937
6	1.816	1.8785	1.7509	1.7695	1.8404	1.8686	1.9151
7	1.9859	1.9159	1.9083	1.7764	1.8046	1.919	1.9425
8	2.0309	2.0134	2.0577	1.912	2.031	2.1179	2.146
9	1.9936	1.9799	1.9501	1.8797	1.8747	2.0828	2.0196
10	1.9487	2.0256	2.0652	1.9387	1.0303	2.1167	2.1193
11	2.2733	2.2481	2.2275	2.2123	1.3405	2.4377	2.306
12	2.3898	2.3914	2.386	2.2694	2.4257	2.5675	2.4584
13	2.3533	2.4302	2.5423	1.166	2.5393	2.6669	2.4638
14	2.3761	2.3571	2.4058		2.5035	2.5545	2.4546
15	2.2999	2.2694	2.3144		2.5317	2.4886	2.4622
16	2.3975	2.2557	1.2483		2.5271	2.4707	2.5454
17	2.5766	2.3761	2.5431	3.0132	2.4752	2.5934	2.5118
18	2.5095	2.3327	2.5019	2.7595	2.5773	2.5712	2.6742
19	2.9218	2.9302	3.155	2.8181	3.2457	3.0102	3.4149
20	3.4774	3.3719	3.5216	2.9561	3.6557	3.5879	3.687
21	3.024	2.8529	3.1489	2.8171	3.2662	3.1809	3.1885
22	2.5423	2.5717	2.7183	2.5614	2.7305	2.7282	2.8548
23	2.4044	2.4002	2.4344	2.4782	2.5324	2.5956	2.7137
24	2.3015	2.2656	2.2924	2.3091	2.3289	2.4021	2.4722
Max	3.4774	3.3719	3.5216	3.0132	3.6557	3.5879	3.687
Min	1.816	1.8488	1.2483	1.166	1.0303	1.8587	1.8937
Avg	2.3001	2.2729	2.2734	2.1994	2.2872	2.4151	2.4393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 202 / 11 KV KRISHNA GHAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0326	1.0402	.9755	1.0044	.9595	1.1317	1.1088
2	.9519	.9747	.8809	.9762	.9145	1.0041	1.0063
3	.9237	.948	.8905	.8771	.8333	.5144	.9835
4	.8451	.8886	.8661	.8193	.7774	.9259	.9312
5	.8383	.871	.8436	.8063	.7812	.913	.913
6	.8307	.9324	.8859	.8056	.8855	.916	1.0212
7	.9603	.9869	.857	.8375	.8794	.9568	.98
8	.9282	.9808	.9084	.9949	.9046	1.0067	.9747
9	.8741	.9785	.8352	.9068	.9286	.9419	.9366
10	1.0913	1.0112	1.0753	1.0586	.5677	1.126	1.083
11	1.1287	.9884	1.0052	1.0609	.6485	1.2087	1.115
12	1.0326	1.025	.599	1.0464	1.1043	1.1679	1.1089
13	.9899	.9922	1.0189	.5136	1.0738	1.1496	1.099
14	.9831	.9975	1.1013		1.102	1.1428	1.1805
15	.9914	.9991	1.1142		1.1698	1.198	1.1295
16	1.0952	.9693	.5693		1.1896	1.2117	1.2026
17	1.1043	.9823	1.0776	1.2697	1.1073	1.1972	1.2247
18	1.0814	1.0242	1.0505	1.2003	1.1675	1.1347	1.2056
19	1.2834	1.1797	1.3923	1.2894	1.3245	1.4053	1.5089
20	.8208	1.3904	1.4937	1.4358	1.6046	1.5866	1.6065
21	1.4464	1.2811	1.3401	1.3462	1.5036	1.4571	1.4799
22	1.3793	1.2076	1.2696	1.2437	1.4693	1.374	1.3832
23	1.2361	1.1816	1.2582	1.1984	1.3504	1.3062	1.3695
24	1.1187	1.1599	1.1047	1.0845	1.1599	1.2582	1.2239
Max	1.4464	1.3904	1.4937	1.4358	1.6046	1.5866	1.6065
Min	.8208	.871	.5693	.5136	.5677	.5144	.913
Avg	1.0403	1.0413	1.0172	1.0369	1.0586	1.1348	1.1573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 203 / 11 KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4128	2.6101	2.4939	2.4775	2.6367	2.8007	2.697
2	2.3015	2.4546	2.3255	2.3495	2.4733	2.524	2.4661
3	2.1856	2.3625	2.1883	2.2764	2.3491	2.473	2.3472
4	2.1429	2.239	2.1293	2.2089	2.2626	2.3282	2.2482
5	2.1033	2.2253	2.0626	2.1574	2.1944	2.3076	2.2131
6	2.1269	2.2428	2.0809	2.2063	2.2451	2.3793	2.2466
7	2.3427	2.361	2.3663	2.2596	2.503	2.5064	2.4741
8	2.2748	2.2291	2.2954	2.2634	2.5194	2.4913	2.457
9	2.2039	2.2474	2.2238	2.1986	2.3487	2.4683	2.3312
10	2.3632	2.2778	2.4112	2.4371	1.2833	2.6551	2.6566
11	2.4439	2.4584	2.7565	1.2818	1.5958	2.9181	2.8441
12	2.5003	2.5484	2.873		2.9134	2.9729	2.9835
13	2.4759	2.463	2.8265		2.886	2.8552	2.9119
14	2.5621	2.45	2.7633		2.7877	2.7226	2.8517
15	2.598	2.4714	2.8502		2.8776	2.7668	3.0018
16	2.8395	2.4584	1.4975		3.0117	2.8133	3.0193
17	2.5765	2.5576	2.9088	1.829	3.0224	2.9268	3.001
18	2.5667	2.428	2.9424	1.672	3.0323	2.966	2.9843
19	3.0673	2.9934	3.3943	2.678	3.6588	3.482	3.6298
20	3.485	3.2228	3.5041	3.5391	3.6922	3.6245	3.655
21	3.2069	3.0445	3.2502	3.3379	3.4423	3.3752	3.2861
22	3.0056	2.8197	2.9973	3.1192	3.2038	3.1694	3.2159
23	2.9477	2.8255	2.9416	3.0362	3.0544	3.0819	3.2182
24	2.7115	2.7511	2.7279	2.8128	2.843	2.9767	2.9759
Max	3.485	3.2228	3.5041	3.5391	3.6922	3.6245	3.655
Min	2.1033	2.2253	1.4975	1.2818	1.2833	2.3076	2.2131
Avg	2.5602	2.5309	2.6171	2.4285	2.7015	2.8161	2.8215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 204 / 11 KV HIGH WAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7502	.7282	.6893	.7266	.7758	.7697	.7823
2	.6973	.6756	.6485	.7106	.7316	.7122	.7365
3	.6539	.6291	.6055	.6642	.716	.6996	.6909
4	.6486	.6283	.5937	.6245	.6797	.6931	.6474
5	.6421	.6272	.6272	.6539	.6684	.7206	.6504
6	.6772	.6257	.668	.6585	.6649	.7175	.719
7	.692	.6726	.6352	.6695	.7045	.7743	.7396
8	.7384	.7118	.679	.6806	.716	.7884	.7384
9	.6958	.6786	.7072	.6755	.7263	.8257	.7011
10	.7941	.6855	.8585	.7686	.2843	.8753	.8086
11	.9301	.8825	.9957	.8818	.3654	.998	1.0067
12	.942	.9046	1.0082	.8124	1.1221	1.0833	1.041
13	.9317	.9256	1.0197	.2702	1.1263	1.1096	1.0547
14	.9286	.8376	1.0204		1.1233	1.1104	1.0547
15	.9313	.9031	1.0277		1.1286	1.0582	1.1332
16	.924	.8981	.3445		1.0437	1.0944	1.1484
17	.9244	.8341	1.0185	1.0166	1.1092	1.1108	1.1568
18	.8901	.8234	.9926	.9957	1.1028	1.0334	1.1774
19	1.0353	.961	1.0901	.9759	1.2445	1.1039	1.2548
20	1.1104	1.0586	1.1378	1.0155	1.2049	1.1366	1.2483
21	.982	.9538	1.0799	.9953	1.1028	1.0391	1.1237
22	.9355	.8863	.9579	.9407	1.0178	.9564	1.0589
23	.8257	.8318	.8646	.9016	.9221	.9042	1.0044
24	.762	.7926	.772	.8036	.8066	.8673	.8677
Max	1.1104	1.0586	1.1378	1.0166	1.2445	1.1366	1.2548
Min	.6421	.6257	.3445	.2702	.2843	.6931	.6474
Avg	.8351	.7982	.8351	.7829	.8787	.9243	.9394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 205 / 11 KV WAKHAN ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9062	.8894	.9138	.9045	.8966	.9987	.8909
2	.8726	.8219	.8471	.8764	.8246	.9237	.8208
3	.833	.7766	.8311	.8234	.78	.8699	.7636
4	.8238	.7674	.7804	.7797	.7731	.8448	.7476
5	.8124	.7621	.7789	.772	.7804	.8379	.7385
6	.8139	.7613	.7743	.7659	.7766	.8688	.7987
7	1.1027	.825	.7781	.7766	.8733	.9317	.8178
8	1.0189	.9435	.7614	.7118	.7705	.9298	.8482
9	.9998	.7964	.8444	.6241	.7949	.8894	.8436
10	.935	.7948	.9358	.6798	.442	.8425	.7918
11	.9267	1.0144	.9297	.0312	.4283	.7796	.8063
12	.9168	.9411	.9282		.6051	.8364	.8208
13	.9244	1.0449	.9381		.6051	.8463	.8032
14	.9312	.9404	.9381		.5906	.8478	.7933
15	1.0372	1.0228	.9335		.727	.8932	.903
16	1.0403	1.0372	.4938		.8817	.897	.9061
17	1.0464	1.0532	.9343		.9007	.8886	.9305
18	.9964	.9945	1.0151		.8825	.8486	.9439
19	1.0654	1.1553	.9503	1.0776	1.1348	1.0021	1.0993
20	1.2799	1.2959	1.0849	1.0913	1.2171	1.2468	1.2171
21	1.1961	1.1469	1.0608	1.0368	1.2232	1.1888	1.1534
22	1.126	1.1218	1.0258	1.0578	1.2064	1.1438	1.1919
23	1.0311	.9873	.9911	1.0135	1.0692	1.0433	1.0814
24	.9267	.9374	.9457	.993	.9309	1.0418	.9815
Max	1.2799	1.2959	1.0849	1.0913	1.2232	1.2468	1.2171
Min	.8124	.7613	.4938	.0312	.4283	.7796	.7385
Avg	.9818	.9513	.8923	.8244	.8381	.9351	.9039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 206 / 11 KV COTTAGE HOSPITAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3731	2.5186	2.4433	2.4775	2.5522	2.7626	2.527
2	2.1932	2.3754	2.2405	2.2413	2.3015	2.5614	2.3213
3	2.0843	2.2732	2.1342	2.1338	2.1658	2.3808	2.1277
4	2.0409	2.1986	1.9746	2.0058	2.0714	2.348	2.0225
5	1.9997	2.1552	1.8664	1.9433	1.9806	2.3099	1.9821
6	2.034	2.1917	1.8877	1.9723	2.0058	2.3602	2.0935
7	2.1528	2.3289	2.1602	2.1636	2.2413	2.4691	2.1978
8	2.194	2.329	2.1358	2.2801	2.3175	2.4051	2.332
9	2.4265	2.4714	2.3049	2.2268	2.4851	2.5423	2.5271
10	2.7732	2.5499	2.8052	2.4363	1.3954	2.838	3.0148
11	3.0696	2.7595	3.2892	.7567	1.6682	3.2384	3.2358
12	2.9782	2.8685	3.3402		3.2556	3.3462	3.2282
13	3.014	2.8913	3.213		3.3654	3.3081	3.3494
14	2.8989	2.8281	3.1833		3.2335	3.2228	3.3387
15	2.8707	2.7443	3.1848		3.2412	3.2083	3.3989
16	2.7839	2.7404	1.6651		3.2473	3.1466	3.4926
17	3.014	2.7183	3.2366	2.0051	3.309	3.2769	3.3951
18	2.9592	2.6384	3.0799	3.3874	3.1763	3.0605	3.3676
19	3.2761	3.0506	3.3859	3.288	3.6267	3.4484	3.8828
20	3.4804	3.3066	3.5658	3.2838	3.8447	3.7106	3.9598
21	3.2129	2.9797	3.2434	3.1085	3.4918	3.3805	3.6107
22	2.9104	2.8472	2.9981	2.9645	3.2354	3.1588	3.4781
23	2.8319	2.7778	2.8563	3.0019	3.2808	3.1641	3.4918
24	2.6574	2.7085	2.7226	2.7831	2.8456	3.0803	2.9344
Max	3.4804	3.3066	3.5658	3.3874	3.8447	3.7106	3.9598
Min	1.9997	2.1552	1.6651	.7567	1.3954	2.3099	1.9821
Avg	2.6762	2.6355	2.7049	2.4453	2.7641	2.9470	2.9712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 207 / 11 KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4866	.4878	.4839	.4763	.2541	.525	.4805
2	.4496	.2275	.4462	.4397	.1863	.4858	.4443
3	.3064	.2222	.269	.2713	.1886	.4496	.3971
4	.3056	.2115	.2671	.2268	.224	.3102	.2991
5	.4851	.3936	.3357	.3129	.2237	.4092	.3357
6	.5304	.466	.5289	.5213	.4184	.4973	.5274
7	.442	.5304	.5277	.5	.4869	.5327	.5087
8	.5236	.5273	.5209	.495	.4774	.5266	.4912
9	.5312	.5281	.5062	.5012	.4824	.5503	.5156
10	.6245	.5304	.6962	.6333	.2984	.5746	.5297
11	.687	.5285	.6924	.6904	.3506	.5786	.5381
12	.6973	.5285	.6939	.6916	.7057	.5702	.54
13	.6958	.4511	.6946	.3532	.7015	.5748	.5297
14	.5776	.5152	.6969		.7007	.5436	.4508
15	.6139	.516	.7003		.7045	.5117	.274
16	.3754	.599	.3616		.7019	.5129	.5396
17	.2626	.5263	.7015	.5887	.7038	.4599	.5343
18	.2004	.4877	.5003	.5944	.6185	.3779	.4195
19	.2103	.4717	.4014	.5445	.4161	.4481	.4862
20	.3197	.5148	.5027	.4858	.4988	.5074	.5372
21	.5327	.5007	.5285	.5058	.5235	.5178	.508
22	.5334	.5201	.5015	.4877	.527	.5003	.5224
23	.5041	.4893	.4986	.482	.7846	.5171	.5281
24	.49	.5285	.5036	.5053	.4488	.5296	.508
Max	.6973	.599	.7015	.6916	.7846	.5786	.54
Min	.2004	.2115	.2671	.2268	.1863	.3102	.274
Avg	.4744	.4709	.5233	.4908	.4844	.5005	.4769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 208 / 11 KV Chawadi Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3292	.2629	.3189	.2804	.3292	.3155
2	.3109	.3292	.2454	.2835	.2804	.2926	.3012
3	.2195	.2926	.2481	.2481	.2454	.2561	.2804
4	.2195	.2926	.2378	.2103	.2454	.2561	.2629
5	.2195	.2926	.2353	.1928	.2103	.2561	.2629
6	.2195	.2926	.2279	.1928	.2103	.2561	.298
7	.2926	.3292	.2629	.2804	.2629	.2926	.2835
8	.2926	.2743	.3077	.2835	.298	.2926	.3366
9	.2926	.2926	.3077	.2804	.3012	.3109	.3155
10	.3696	.3696	.3881	.3142		.3801	.4066
11	.462	.4805	.4805	.3696		.4887	.4805
12	.462	.4805	.4805	.3696	.5544	.4887	.4805
13	.499	.5175	.5175		.499	.543	.499
14	.499	.499	.4805		.5175	.543	.5359
15	.4251	.499	.499		.4805	.543	.5729
16	.4435	.4805			.5359	.5249	.499
17	.5359	.5175	.499	.4805	.462	.5068	.5544
18	.5121	.4801	.5434	.4572	.5304	.5316	.5487
19	.6219	.6173	.6485	.4252	.6767	.7011	.7682
20		.6687	.6379	.4207	.695	.6733	.7133
21	.5121	.5068	.5434	.3506	.5304	.5258	.5853
22	.4207	.3544	.3898	.3898	.4207	.4252	.4572
23	.3475	.3506	.3721	.3898	.4207	.3856	.439
24	.3841	.3292	.3439	.333	.3155	.3475	.3366
Max	.6219	.6687	.6485	.4805	.695	.7011	.7682
Min	.2195	.2743	.2279	.1928	.2103	.2561	.2629
Avg	.3873	.4115	.3983	.3295	.4079	.4229	.4389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 207 / 11 KV Vadoli AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.8402	.0343	.0343	.0343	.0343	.6687
2	.7716	.7716	.0343	.0343	.0343	.0171	.6173
3	.7716	.7545	.0343	.0343	.0343	.0171	.6173
4	.7716	.7545	.0343	.0343	.0343	.0171	.6173
5	.8059	.8402	.0343	.0343	.0343	.0343	.703
6	.8402	1.0288	.0514	.0343	.0343	.0343	.8402
7	.9602	1.0974	.0514	.0343	.0343	.0343	.9602
8	1.0631	1.0802	.0343	.0343	.0343	.0343	1.046
9			1.3546	1.4232	1.406	1.3717	
10		.0343	1.4575	1.3717		1.406	
11		.0343	1.5604	1.3375		1.4232	
12	.0343	.0343	1.6118	1.3375	1.3717	1.406	
13	.0343	.0514	1.5432	.1337	1.406	1.3717	
14	.0343	.0343	1.5089	1.2003	1.3889	1.2346	
15	.0343	.0514	1.4746	1.1831	1.3375	1.1831	.0343
16	.0343	.0514	1.2346	1.2003	1.1145	1.1145	.0171
17	.0514	.0514	.0343		.0343	.0343	.0514
18	.0514	.0686	.0343	.0514	.0514	.0343	.0343
19	.0514	.0514	.0343	.0514	.0514	.0343	.0343
20	.0514	.0514	.0343	.0514	.0514	.0343	.0514
21	.0514	.0514	.0514	.0514	.0514	.0343	.0514
22	.0343	.0514	.0514	.0514	.0514	.0343	.0514
23	.9259	.0514	.0514	.0343	.0343	.0343	.0514
24	.8573	.8573	.0514	.0343	.0343	.0343	.0343
Max	1.0631	1.0974	1.6118	1.4232	1.406	1.4232	1.046
Min	.0343	.0343	.0343	.0343	.0343	.0171	.0171
Avg	.4319	.3780	.5165	.4255	.3936	.4587	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 258001 / 220/33KV Ogalewadi SS

Feeder No / Name : 204 / Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2964	.3589	.3125	.3022	.3045	.3433	.373
2	.2942	.3281	.3086	.3056	.3045	.3178	.3746
3	.2953	.3281	.3109	.3075	.3075	.3174	.3631
4	.2964	.3296	.3193	.3125	.309	.3185	.3791
5	.3041	.3311	.3174	.3174	.3098	.3277	.3833
6	.314	.3357	.3185	.3174	.3109	.3342	.3909
7	.3166	.3429	.3292	.3056	.3117	.354	.3829
8	.3384	.3521	.3487	.3048	.3296	.3578	.378
9	.4832	.4519	.4466	.2919	.426	.4847	.4557
10	.66	.5658	.6112	.2622	.5376	.6371	.5556
11	.7613	.6409	.6401	.266	.4942	.7129	.631
12	.772	.6962	.6645	.2484	.6539	.732	.6272
13	.4694	.4531	.4058	.2644	.4089	.4854	.4435
14	.6497	.623	.6394	.2743	.6055	.6306	.5887
15	.6104	.615	.5731	.2751	.5693	.6043	.5807
16	.6428	.6005	.5331	.2945	.5811	.6276	.5879
17	.6241	.615	.57	.2759	.583	.6215	.6047
18	.5152	.4976	.4447	.282	.4633	.5552	.4592
19	.4428	.4081	.3574	.2839	.3814	.4485	.3849
20	.3551	.3448	.3414	.2957	.3727	.3871	.3746
21	.3658	.3319	.3338	.306	.3826	.3711	.3967
22	.3795	.3304	.3094	.3071	.3742	.3647	.3913
23	.3849	.3494	.3128	.3121	.3688	.3544	.3742
24	.3788	.3498	.314	.3098	.362	.3616	.3883
Max	.772	.6962	.6645	.3174	.6539	.732	.631
Min	.2942	.3281	.3086	.2484	.3045	.3174	.3631
Avg	.4563	.4408	.4193	.2926	.4188	.4604	.4529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 258001 / 220/33KV Ogalewadi SS

Feeder No / Name : 403 / 33 KV KARAD TOWN

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	23.8957	23.8764	23.7283	24.1084	24.6	25.6242	25.9362
2	21.9068	21.4426	21.9765	22.272	22.1434	23.2054	23.5066
3	20.6721	20.1989	20.4704	20.9928	20.7648	22.045	22.2806
4	19.6845	19.4741	19.3615	19.5428	19.9222	20.7865	20.7648
5	19.3142	18.9403	18.8814	19.2867	19.4393	20.3064	20.3378
6	19.8491	19.6891	19.4844	19.6828	19.9269	20.9774	21.5913
7	20.1646	19.9188	19.8788	20.3069	20.5647	21.3535	21.7233
8	22.5789	22.1434	21.8679	20.439	22.951	23.5094	23.8495
9	21.5227	21.0997	21.0305	20.8334	21.3958	22.5046	22.6527
10	22.3377	21.7307	22.348	21.6067	17.1468	24.1055	23.9049
11	25.3059	24.1792	25.9946	19.6051	21.262	26.569	26.5987
12	26.3901	25.4561	27.2714	12.2108	27.9572	28.5409	27.7938
13	26.5272	25.6882	27.8756	9.0535	27.931	28.7066	28.2608
14	26.2792	25.1657	27.8333		27.8887	28.4609	28.163
15	25.3745	25.1657	27.6698		27.8915	27.775	28.646
16	25.9888	24.9732	21.1934		28.7015	28.1036	29.1684
17	25.5933	25.4007	21.3306	15.9065	28.7277	28.4866	29.6777
18	25.4184	25.2058	28.4374	24.9983	28.3208	28.5208	29.4125
19	26.4484	27.7435	29.3759	26.2192	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	29.3942	28.6163	29.9611	28.9689	***	***	***
23	27.0291	26.6976	27.6869	28.1585	29.129	29.7806	***
24	25.8711	25.3795	26.2552	26.8771	27.7264	28.3323	29.0586
Max	32.0006	33.3163	35.2538	31.9159	36.3055	36.9776	37.06
Min	19.3142	18.9403	18.8814	9.0535	17.1468	20.3064	20.3378
Avg	24.5873	24.2714	24.9502	22.0935	25.7402	26.7392	27.0493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 201 / KRISHNA HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3772	.3429	.3961	.3772	.415	.415
2	.3395	.3395	.3429	.3772	.3772	.3772	.3772
3	.2263	.3395	.3429	.3772	.3395	.3395	.3395
4	.2075	.3395	.3429	.3772	.3395	.3395	.3395
5	.3206	.3772	.415	.3772	.3772	.3772	.3772
6	.3584	.415	.4527	.3961	.415	.415	.415
7	.4904	.415	.5658	.4338	.5093	.5093	.5281
8	.4715	.415	.6413	.4973	.5658	.5658	.5658
9	.679	.4115	.679	.583	.679	.7356	.7167
10	.6979	.4458	.7167		.7733	.8488	.8299
11	.679	.4801	.7095	.6516		.811	.8299
12		.4458	.7468	.6516		.3772	.7545
13	.6413	.4801	.7095	.6927	.3018	.3961	.7733
14	.679	.4801	.6413	.6516	.3206	.3584	.6224
15	.6979	.4458	.6979	.6173	.3584	.3961	.811
16	.6602	.4115	.6979	.6173	.7167	.7733	.7545
17	.6224	.3772	.6413	.6413	.5847	.6979	.5847
18	.5093	.3772	.4715	.6036	.5281	.547	.5144
19	.5281	.4115	.4904	.5658	.5658	.5093	.5144
20	.5281	.4801	.5093	.5093	.547	.5281	.5144
21	.5093	.4801	.5847	.547	.4904	.5658	.4801
22	.4904	.4458	.4904	.4527	.4527	.5658	.4801
23	.4527	.4115	.4904	.4527	.4527	.4904	.4458
24	.3772	.415	.3429	.415	.3961	.4338	.4527
Max	.6979	.4801	.7468	.6927	.7733	.8488	.8299
Min	.2075	.3395	.3429	.3772	.3018	.3395	.3395
Avg	.5035	.4174	.5444	.5167	.4758	.5155	.5598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 202 / MALKAPUR Gaonthan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6263	1.6975	1.4403	1.6263	1.6221	1.6817	1.773
2	1.5524	1.6975	1.4403	1.5893	1.5844	1.5893	1.6975
3		1.6598	1.4403	1.5893	1.5844	1.5684	1.6975
4	1.4937	1.5844	1.4403	1.5893	1.5844	1.531	1.6598
5	1.531	1.5844	1.7551	1.5893	1.6598	1.643	1.6975
6	1.7187	1.6975	1.848	1.6095	1.8107	1.7556	1.8861
7	1.6827	1.9239	1.9387	1.8107	1.9616	1.9022	1.9239
8	1.829	2.037	1.9022	1.5947	1.8861	2.2131	1.8861
9	2.037	1.8861	1.829	1.749	1.8484	2.2634	1.9616
10	2.5652	2.0919	2.2081		2.2634	2.584	2.3954
11	2.3388	2.1262	2.3998	1.2003		2.7161	2.4897
12		2.0576	2.4356	1.2003	2.2634	2.6783	
13	2.7161	1.989	2.2923	1.2346	2.2068	2.5652	1.1694
14	2.4897	2.0233	2.1538	1.2003	2.1313	2.3765	1.1317
15	2.2634	2.0576	2.1491	1.2174	1.9993	.4527	2.9424
16	2.4897	2.0919	2.2805	1.166	2.32	2.999	2.999
17	2.6406	1.989	2.2986	1.2449	2.1719	2.6972	2.584
18	2.4143	2.0233	2.1357	1.8861	2.1176	2.4897	2.1776
19	2.3388	2.0576	2.268	2.3388	2.3594	2.4143	2.1948
20	2.4897	2.1262	2.3411	2.3388	2.4508	2.5652	2.2977
21	2.4143	2.0233	2.2177	2.2634	2.347	2.4143	2.2291
22	2.1879	1.9204	2.1068	2.0748	2.2546	2.3011	2.0576
23	1.9993	1.7147	1.9774	1.8861	2.0698	2.0748	1.8861
24	1.7002	1.8107	1.5775	1.7177	1.7353	1.8111	1.8861
Max	2.7161	2.1262	2.4356	2.3388	2.4508	2.999	2.999
Min	1.4937	1.5844	1.4403	1.166	1.5844	.4527	1.1317
Avg	2.1145	1.9113	1.9948	1.6399	2.0101	2.1370	2.0271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 203 / Goleshwar Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3395	.0655	.0686	.0754	.0709	.415
2	.3086	.3395	.061	.0686	.0754	.0716	.415
3	.2915	.3395	.061	.0686	.0754	.0716	.415
4	.2915	.3395	.061	.0686	.0754	.0716	.415
5	.2915	.3584	.0857	.0857	.0943	.0876	.415
6	.3277	.3961	.0857	.0876	.1132	.0876	.4527
7	.4049	.415	.1029	.0709	.0943	.0686	.4527
8	.421	.415	.1029	.0655	.0754	.0857	.4904
9	.0943	.0686	.5426	.5144	.5847	.6979	.1132
10	.0754	.0655	.5801		.2641	.7356	.0943
11	.0754	.0686	.6226	.5487		.7167	.0943
12		.0648	.6226	.5316	.6979	.679	.0943
13	.0754	.0648	.6316	.5243	.6413	.6413	.0943
14	.0754	.0655	.583	.547	.6224	.6036	.0754
15	.0754	.064	.5636	.503	.6413	.4904	.0754
16	.0754	.0671	.5658	.4428	.6413	.5281	.0754
17	.0754	.064	.0716	.0754	.0886	.0754	.0754
18	.0754	.0678	.0543	.0754	.0716	.0754	.0678
19	.0754	.0857	.1029	.0754	.0716	.0943	.0686
20	.0754	.0857	.1029	.1132	.0876	.0943	.0857
21	.0754	.0686	.0857	.1132	.0895	.0943	.0819
22	.0754	.0857	.0857	.0943	.0886	.0943	.061
23	.3584	.0686	.0857	.0943	.0716	.0754	.061
24	.3258	.3584	.0678	.0686	.0754	.0716	.0754
Max	.421	.415	.6316	.5487	.6979	.7356	.4904
Min	.0754	.064	.0543	.0655	.0716	.0686	.061
Avg	.1882	.1815	.2498	.2133	.2355	.2660	.1985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 204 / Goleshwar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.6036	.5487	.5975	.5658	.6099	.5658
2	.5914	.5658	.5487	.5914	.5281	.5914	.5658
3	.5914	.5658	.5487	.5914	.5281	.5914	.5281
4	.5544	.5281	.5487	.5914	.4904	.5788	.5281
5	.6161	.5658	.6283	.6283	.5281	.6099	.6036
6	.6838	.6413	.7316	.7133	.6413	.7023	.7167
7	.7133	.7167	.7316	.7682	.6413	.7682	.7167
8	.567	.679	.6401	.6001	.6036	.6401	.6413
9	.6036	.6173	.567	.5144	.5658	.6036	.6036
10	.5281	.5658	.5249		.4904	.6036	.5847
11	.5281	.5144	.5014	.4801		.5658	.6036
12		.5316	.4961	.463		.6036	
13	.5281	.5144	.5373	.463	.5658	.5847	
14	.5658	.5487	.5731	.4458	.5658	.5658	
15	.6036	.5144	.567	.4801	.5658	.6036	.7167
16	.6036	.5487	.5373	.463	.5658	.6036	.7356
17	.6036	.583	.5373	.4904	.5731	.6036	.679
18	.5658	.6173	.6024	.5281	.5792	.6036	.6516
19	.6413	.6516	.7316	.5658	.7316	.679	.6859
20	.7545	.7202	.823	.7545	.8779	.7545	.7545
21	.7167	.6859	.8316	.7167	.8501	.7922	.6859
22	.7545	.6859	.8048	.679	.8131	.7545	.6516
23	.679	.6173	.7392	.6413	.7762	.4904	.6173
24	.6468	.6036	.583	.6161	.5658	.6653	.6036
Max	.7545	.7202	.8316	.7682	.8779	.7922	.7545
Min	.5281	.5144	.4961	.4458	.4904	.4904	.5281
Avg	.6188	.5994	.6201	.5819	.6188	.6321	.6400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 205 / AAGASHIVNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1827	1.2071	1.2346	1.4415	1.0185	1.2382	2.5652
2	1.1949	1.2071	1.2346	1.3306	.9808	1.1643	1.2071
3	1.1088	1.1317	1.2346	1.3306	.9431	1.0082	1.2071
4	1.0829	1.094	1.2346	1.3443	.9054	.8962	1.1317
5	1.0829	1.2071	1.3676	1.3676	.9431	1.1949	1.2071
6	1.0829	1.4335	1.4045	1.3717	.9808	1.2323	1.358
7	1.1706	1.5089	1.4784	1.0791	1.0562	1.3676	1.358
8	1.1273	3.0178	1.39	.9602	.9808	1.4083	1.4335
9	1.5089	2.7434	1.5729	1.0288	1.0562	1.5466	1.5844
10	1.5844	2.7434	1.5927		1.6032	1.6221	1.6598
11	1.6598	2.7434	1.6832	.9259		1.6598	1.6975
12		1.406	1.5223	.8916		1.3957	1.5466
13	1.5089	1.3717	1.6289	.9259	1.6975	1.6409	
14		1.3717	1.5927	.8573	1.6975	1.6975	
15	1.6221	1.406	1.7375	.8745	1.6975	1.7353	1.9616
16	3.395	1.3889	1.7013	.8916	1.7353	1.7164	1.8673
17	1.7353	1.3717	1.7013	1.0562	1.7375	1.7353	1.8107
18	1.6598	1.4746	1.6108	1.0562	1.6108	1.6598	1.6975
19	1.8107	1.5432	1.7013	1.1317	1.7375	1.8107	1.7147
20	1.9616	1.6804	1.9022	1.358	1.8656	1.9616	1.7833
21	1.8861	1.5432	1.8111	1.2826	1.7558	1.8861	1.7147
22	1.5089	1.5089	1.7372	1.2826	1.5893	1.6598	1.5775
23	1.4335	1.3717	1.6632	1.2071	1.4784	1.5844	1.4403
24	1.307	1.358	1.3032	1.531	1.094	1.3256	1.4335
Max	3.395	3.0178	1.9022	1.531	1.8656	1.9616	2.5652
Min	1.0829	1.094	1.2346	.8573	.9054	.8962	1.1317
Avg	1.5280	1.6181	1.5434	1.1533	1.3711	1.5062	1.5890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 206 / Koyana Industrial Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2401	.2263	.2263	.2641	.2641
2	.2263	.2452	.2401	.2263	.2263	.2641	.2641
3	.2263	.2263	.2401	.2263	.2263	.2263	.2641
4	.2263	.2263	.2401	.2263	.2263	.2263	.2641
5	.2263	.2263	.2452	.2263	.2263	.2263	.2263
6	.2452	.2452	.2452	.2263	.2263	.2641	.2263
7	.2452	.2641	.2452	.2641	.2452	.2641	.2641
8	.2641	.2641	.2641	.2401	.2829	.3018	.2641
9	.3018	.3086	.3395	.2229	.3206	.3395	.3772
10	.415	.3772	.3772	.2058	.4527	.415	.3772
11	.4527	.4458	.4527	.2058		.4527	.4527
12		.4115	.3772	.2058	.415	.415	.3395
13	.3772	.4287	.3772	.2401	.3772	.415	.3772
14	.3961	.4115	.3772	.2401	.415	.415	.4527
15	.415	.4115	.3772	.2229	.415	.415	.4904
16	.415	.3944	.415	.2401	.4527	.4527	.4527
17	.415	.3772	.415	.2641	.4527	.4527	.4527
18	.3395	.3429	.3772	.2641	.3772	.3772	.3429
19	.3395	.3086	.3395	.2641	.3772	.3395	.3086
20	.3018	.3086	.3018	.2641	.3395	.3206	.3086
21	.3018	.2743	.2641	.2452	.3018	.2641	.3086
22	.2641	.2743	.2641	.2263	.3018	.2641	.2743
23	.2829	.2743	.2641	.2263	.3018	.2641	.2743
24	.2641	.2641	.2572	.2641	.2263	.2641	.2641
Max	.4527	.4458	.4527	.2641	.4527	.4527	.4904
Min	.2263	.2263	.2401	.2058	.2263	.2263	.2263
Avg	.3133	.3156	.3140	.2360	.3223	.3293	.3288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 207 / 11 KV Malkapur water works NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.132	.1543	.1494	.1509	.1494	.1509
2	.1307	.132	.1543	.1494	.1509	.1494	.1509
3	.168	.132	.1372	.1494	.1509	.1494	.1509
4	.0185	.132	.1372	.132	.1509	.1867	.1509
5	.1307	.132	.1663	.1478	.0189	.0185	.0566
6	.1663	.132	.1848	.1663	.1509	.0747	.0189
7	.1478	.1698	.1663	.1848	.1886	.1478	.1698
8	.1294	.2075	.1829	.1372	.1698	.1663	.1509
9	.132	.1543	.1646	.1543	.1509	.1509	.1509
10	.2263	.1372	.1829		.1886	.1886	.2075
11	.1886	.1715	.1663	.1543		.3206	.1886
12		.1715	.1663	.1715		.1698	.132
13	.1698	.1543	.2402	.1715	.1698	.1698	
14	.1698	.1715	.1663	.1715	.1698	.1886	.0754
15	.0943	.1715	.1663	.1543	.3018	.3018	.0754
16	.0754	.1543	.1646	.1715	.132	.1886	.132
17	.0566	.2572	.1663	.1886	.1663	.1698	.1886
18	.0754	.1372	.1646	.2075	.168	.1509	.1543
19	.0189	.1543	.168	.2075	.1867	.1509	.1372
20	.132	.1372	.1494	.1698	.168	.1509	.1372
21	.0566	.1372	.1848	.1509	.1494	.1698	.12
22	.132	.1543	.1494	.1509	.1494	.1509	.12
23	.0754	.1715	.1494	.2075	.1307	.1509	.1372
24	.1307	.132	.1715	.1494	.1509	.1867	.1509
Max	.2263	.2572	.2402	.2075	.3018	.3206	.2075
Min	.0185	.132	.1372	.132	.0189	.0185	.0189
Avg	.1198	.1557	.1668	.1651	.1597	.1667	.1351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 201 / Supane AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3117	.3639	3.642	3.8005	3.8116	3.4166	.2878
2	.3101	.3631	3.4846	3.6397	3.7135	3.3528	.3056
3	.3109	.3601	3.357	3.4945	3.5951	3.2614	.2871
4	.3101	.354	3.312	3.4417	3.4653	3.2339	.2856
5	.3124	.3654	3.3037	3.388	3.517	3.3865	.2871
6	.3201	.3768	3.4406	3.6092	3.7827	3.6883	.2894
7	.3521	.4252	4.0821	3.9093	4.2933	4.6965	.3585
8	.2636	.4123	4.0548	3.7805	4.0886	4.6916	.3223
9	4.9829	5.0809	1.0172	1.3028	1.1149	1.3516	5.3601
10	5.5247	5.146	.3492	.1311	.1242	.081	1.744
11	5.2288	5.1871	.39	.3301	.244		.9501
12	5.001	4.8876	.3824	.3086	.2242		3.2661
13	4.848	4.2363	.3378	.1288	.2518		4.6864
14	4.6411	4.2594	.3324	.3385	.2756		4.7716
15	4.5681	4.2103	.3301	.337	.2564	.2825	5.2524
16	4.5294	4.3213	.3317	.334	.3347	.2671	5.0194
17	1.0791	1.2385	.3717	.377	.3101	.3301	1.2507
18	.3239	.4331	.3582	.3946	.3162	.3831	.0015
19	.3849	.3923	.386	.3877	.4009	.4085	.312
20	.4336	.3984	.3826	.4085	.4324	.4176	.4207
21	.4161	.3892	.3696	.3846	.3719	.39	.4553
22	.4169	.3469	.3418	.3515	.3651	.3553	.3999
23	.3915	3.8048	4.0118	3.7751	.3997	.2932	.3446
24	.3406	1.6564	3.8199	4.0061	2.4914	.2363	.2901
Max	5.5247	5.1871	4.0821	4.0061	4.2933	4.6965	5.3601
Min	.2636	.3469	.3301	.1288	.1242	.081	.0015
Avg	1.9001	2.0421	1.7579	1.7650	1.5909	1.7262	1.5395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 203 / SAHYADRI HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0566	.0754	.0754	.0566	.0754	.1509
2	.0754	.0566	.0754	.0754	.0566	.0754	.0754
3	.0754	.0566	.0566	.0566	.0566	.0754	.0754
4	.0754	.0566	.0566	.0754	.0566	.0754	.0754
5	.0754	.0566	.0754	.0943	.0566	.0754	.0754
6	.2075	.0566	.0754	.0754	.0754	.0754	.0754
7	.0754	.0754	.0943	.1698	.1698	.0943	.1698
8	.0943	.0754	.2075	.1509	.0754	.1886	.0566
9	.0754	.132	.1698	.0943	.1509	.2075	.1698
10	.132		.1698			.1886	.1698
11	.2452		.1698	.1698	.1886	.1886	.2075
12	.1132	.0754	.1886		.1886	.2075	.1698
13	.0943	.1886	.1698		.1698	.1886	.1886
14	.2263	.132	.1886		.1886	.1886	.132
15	.2075	.132	.1509		.1886	.1886	.2263
16	.2263	.1509	.1886	.1132	.1886	.0943	.2263
17	.2075	.1509	.1132	.1132	.1886	.2075	.132
18	.1509	.0754	.0754	.0754	.0943	.1886	.0943
19	.1509	.0566	.1886	.0754	.0754	.0943	.0754
20	.132	.132	.1509	.1509	.2075	.132	.0943
21	.0754	.0754	.0754	.0754	.0754	.0754	.1698
22	.0754	.0754	.0754	.0754	.0754	.0754	.0754
23	.132	.1886	.1886	.1886	.1886	.0754	.0566
24	.132	.0566	.0566	.0754	.0566	.0754	.1698
Max	.2452	.1886	.2075	.1886	.2075	.2075	.2263
Min	.0754	.0566	.0566	.0566	.0566	.0754	.0566
Avg	.1304	.0960	.1265	.1042	.1230	.1297	.1297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 206 / Supane Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.6283	.6722	.6468	.6722	.6584	.6767
2	.6401	.6161	.6413	.6283	.6468	.6219	.6584
3	.6219	.5788	.6161	.6283	.6283	.6036	.6468
4	.6036	.5788	.6161	.6099	.5729	.6036	.6099
5	.6036	.5729	.6161	.5914	.5729	.6036	.7316
6	.6767	.6653	.7282	.6767	.6653	.7421	.7392
7	.695	.7392	.6613	.6697	.6447	.691	.7499
8	.7619	.724	.6464	.7343	.7522	.7265	.7343
9	.7011	.663	.663	.6661	.6962	.7186	.6133
10	.6706	.6962	.6464			.6241	.5967
11	.6203	.6299	.663	.5967	.6133	.6722	.6796
12	.6706	.6133	.663	.6133	.6464	.7042	.6299
13	.6539	.6299	.6464	.547	.5636	.7042	.6464
14	.57	.5967	.6226	.5801	.6133	.6405	.6299
15	.6371	.6226	.6062	.5571	.6299	.6882	.6554
16	.5801	.6299	.639	.5668	.639	.5624	.6718
17	.6104	.6859	.6718	.6478	.6718	.664	
18	.6478	.68	.679	.6478	.7125	.8097	.7274
19	.8478	.8817	.7865	.8402	.9088	.9156	.8381
20	1.0924	1.0985	1.0808	.985	1.0745	1.134	1.0631
21	.9955	.9955	1.0208	.9593	1.0498	.985	1.0317
22	.9694	.9328	.9313	.905	1.0317	1.0059	.9231
23	.8316	.7947	.8316	.6964	.8326	.924	.905
24	.6767	.6838	.7095	.6653	.7095	.7059	.7499
Max	1.0924	1.0985	1.0808	.985	1.0745	1.134	1.0631
Min	.57	.5729	.6062	.547	.5636	.5624	.5967
Avg	.7099	.7057	.7108	.6808	.7195	.7379	.7351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 201 / VAHAGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.0526	2.2634	2.0119	1.8842	3.6884	.0732
2	.0486	.0514	2.13	2.0119	1.8623	1.8652	.0549
3	.0486	.0526	2.2043	1.8842	1.8351	1.8233	.056
4	.0486	.0532	2.1195	1.9109	1.8138	1.8861	.056
5	.0486	.0526	2.1795	1.8351	1.7966	1.9281	.0724
6	.0486	.0532	2.2119	1.9662	1.8747	1.989	.0886
7	.0648	.0532	2.2939	2.2672	2.1872	2.2119	.0543
8		.0701	2.2939	2.2024	2.3482	2.2939	.0543
9	.0549	3.0178	.0709	.0532	.0514	.0701	2.7854
10	6.0585	3.195	.0724		.0671	.0709	3.2065
11	3.3532	3.1824	.0701	.0526		.0701	3.1089
12	3.1855	3.1161	.0701	.0532	.1364		3.0121
13	2.9165	3.0178	.0543	.0701	.0514		2.915
14	2.753	2.8837	.0543		.0514		2.9607
15	2.5911	2.6825	.0526	.0716	.0514	.0526	2.9959
16	2.5911	2.6825	.0532	.0537	.052	.0532	2.915
17	.0701	.0526	.052	.0526	.0701	.0526	.0526
18	.0701	.0886	.0671	.0526	.0701	.0537	
19	.0857	.0701	.0678	.0709	.0701	.0914	
20	.0857	.1752	.2183	.0678	.0876	.0732	
21	.0857	.1052	.181	.0701	.0709	.0732	
22	.0686	.0886	.0914	.0686	.0709	.0732	
23	.0701	2.2377	1.9662	1.9433	.0701	.0732	
24	.0549	.0526	2.2377	2.0081	1.9662	.0709	.0739
Max	6.0585	3.195	2.2939	2.2672	2.3482	3.6884	3.2065
Min	.0486	.0514	.052	.0526	.0514	.0526	.0526
Avg	1.0631	1.1286	.9615	.9445	.8061	.8840	1.3631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 202 / Vahagaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.5359	.4961	.6348	.5175	.4908	.5544
2	.4344	.5228	.463	.6036	.4805	.4961	.5601
3	.4344	.5228	.4733	.5658	.4572	.4607	.5601
4	.4344	.4904	.4961	.5601	.4572	.4557	.5175
5	.4525	.5228	.4784	.5041	.4755	.4908	.499
6	.5121	.5729	.5083	.5175	.4755	.5721	.499
7	.567	.5544	.5201	.5415	.5914	.5601	.5544
8	.5487	.5544	.4557	.5228	.5359	.5415	.5544
9	.567		.5083	.4557	.462	.4854	.5544
10	.5601	.5041	.4805		.4805	.4805	.499
11	.5175	.5415	.5359	.4557		.4805	.499
12	.462	.5228	.499		.462	.499	.4805
13	.5175	.4805	.4805	.4477	.462	.5601	.4805
14	.5175	.499	.499		.4805	.5601	.499
15	.4854	.4805	.4805	.4557	.4805	.4938	.5175
16	.4525	.4805	.4805	.4435	.5175	.4938	.5175
17	.3982	.5041	.4805	.4572	.499	.4572	.5359
18	.4805	.4382	.5601	.5544	.443	.4755	.5028
19	.7392	.5721	.7282	.6401	.5895	.5975	.6068
20	.8413	.6762	.8589	.7392	.6859	.8215	.6241
21	.7392	.6485	.7282	.6838	.6935	.7468	.6241
22	.7023	.631	.7095	.6653	.7011	.7023	.6241
23	.6468	.5609	.6722	.5914	.5784	.7023	.5721
24	.5304	.5544	.4908	.6348	.5359	.5083	.6283
Max	.8413	.6762	.8589	.7392	.7011	.8215	.6283
Min	.3982	.4382	.4557	.4435	.443	.4557	.4805
Avg	.5421	.5379	.5452	.5559	.5244	.5472	.5444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 203 / ALFA-LAVAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0026	.0021		.0026	.0021	.003	.0026
2	.0026	.0025		.0026	.002		.0026
3	.0026	.002	.0032	.0027	.0021		.0026
4	.0025	.0021		.0027	.0021	.0032	.0027
5	.0026	.0019		.0026	.0021		.0026
6	.0025	.0019	.0031	.0026	.0023	.0032	.0027
7	.0648	.0021		.0027	.0023	.0027	.0027
8	.0023	.0021	.003	.0027	.0021	.0026	.0027
9	.0026	.0026		.003	.0026	.0026	.0021
10	.0027	.0026	.0021		.0026	.0026	.0021
11	.0027	.0026	.0021			.0027	.0021
12	.0027	.0026	.0021	.003	.0026	.0026	.0021
13	.0027	.0026	.0021		.0026	.0027	.0021
14	.0021	.0025	.0021		.0026	.0027	.0021
15	.0023	.0026	.0021	.0023	.0026	.0026	.0022
16	.0023	.0026	.0021	.0021	.0026	.0026	.0021
17	.0021	.0026	.0021	.0023	.0026	.0026	.0021
18	.0019	.003	.0026	.0022	.003	.0026	.0025
19	.0021		.0026	.0021		.0027	.0025
20	.0021		.0026	.0021	.0032	.0026	.0025
21	.0021	.003	.0026	.0021		.0027	.0025
22	.0021		.0026	.0021		.0027	.0025
23	.0021	.0032	.0026	.0021	.0032	.0026	.0025
24	.0032	.0021	.003	.0027	.002	.003	.0026
Max	.0648	.0032	.0032	.003	.0032	.0032	.0027
Min	.0019	.0019	.0021	.0021	.002	.0026	.0021
Avg	.0050	.0024	.0025	.0025	.0025	.0027	.0024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 204 / Taswade East

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1677	.1753	.2195	.1143	.1772	.2561
2	.1448	.1509	.1227	.2195	.1219	.0895	.2614
3	.1296	.1738	.124	.181	.1	.0886	.181
4	.1463	.1448	.0886	.1829	.1014	.0886	.1463
5	.1463	.1337	.0895	.1829	.104	.0886	.1463
6	.1463	.0974	.0886	.2172	.1067	.0895	.1448
7	.181	.092	.2804	.181	.1134	.0914	.1448
8	.1829	.0914	.3155	.128	.2715	.181	.2561
9	.5487	.2926	.4161	.1791	.5228	.5228	.415
10	.5853	.4854	.3772		.4755	.5228	.4904
11	.6535	.5228	.415	.1772		.6535	.5658
12	.5975	.4904	.5658	.1772	.5975	.6535	.5281
13	.4904	.4904	.3772	.1791	.3658	.5601	.3772
14	.5335	.439	.3772		.6348	.4805	.4527
15	.3772	.3734	.3772	.1772	.5121	.4481	.3772
16	.3772	.2743	.3772	.1429	.4066	.439	.415
17	.4904	.3361	.3018	.1524	.3772	.5121	.1886
18	.3734	.2658	.2561	.1429	.3189	.3258	.1387
19	.3395	.2658	.2743	.1448	.3155	.3258	.1387
20	.3361	.2658	.3658	.1134	.3189	.2743	.1387
21	.1886	.1772	.2534	.12	.1772	.2587	.1387
22	.3395	.3155	.3658	.1448	.1772	.3292	.1387
23	.3395	.3189	.3292	.1189	.1772	.2957	.1734
24	.1734	.2241	.1772	.2743	.1014	.1772	.2926
Max	.6535	.5228	.5658	.2743	.6348	.6535	.5658
Min	.1296	.0914	.0886	.1134	.1	.0886	.1387
Avg	.3319	.2746	.2871	.1707	.2831	.3197	.2711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 205 / Taswade West

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.8589	.7973	.8962	.3506	.8764	.8962
2	.4024	.9054	.7973	.8962	.3681	.7087	.8215
3	.3658	.7922	.7011	.8402	.3982	.7011	.7468
4	.3658	.724	.7087	.8215	.3944	.7087	.7468
5	.3658	.6805	.7087	.7468	.3944	.7087	.7095
6	.4572	.6584	.7164	.7095	.4207	.6447	.6722
7	.8048	.724	.7442	.6348	.4252	.679	.7842
8	.8779	.7545	.7011	.415	.5658	.679	.8215
9	1.0608	.9335	.7362	.3189	.6036	.8131	.9054
10	1.0829	1.1203			.7468	1.1203	1.0562
11	1.2696	1.2323	1.2071	.2629		1.307	1.2826
12	1.1949	1.358	1.1317	.2658	1.1949	1.2136	1.2826
13	1.2696	1.2071	.9054	.2658	1.0456	1.2136	1.2449
14	1.1317	1.0829	1.1317		1.2696	1.2136	1.2071
15	1.2449	1.1203	1.2071	.2658	1.1203	1.2136	1.1317
16	1.2826	.9709	1.1317	.1619	1.3443	1.2136	1.2071
17	1.226	1.1949	1.1317	.1753	1.419	1.1949	1.226
18	.9808	.9816	.8215	.2012	.8764	.9709	.7975
19	1.1317	.964	.8962	.2987	.8764	.9709	.8669
20	1.1317	.9015	.8215	.2915	.815	.8589	.7802
21	.8299	.7011	.7545	.2896	.7011	.7468	.6935
22	.9808	.7087	.7468	.3429	.7011	.7545	
23	.9054	.7796	.8215	.3772	.8764	.9709	.8669
24	.8669	.9054	.8764	.9335	.3429	.8764	.8962
Max	1.2826	1.358	1.2071	.9335	1.419	1.307	1.2826
Min	.3658	.6584	.7011	.1619	.3429	.6447	.6722
Avg	.9090	.9275	.8781	.4732	.7500	.9316	.9410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 206 / 11 KV Talbid Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3394	1.1961	.0895	.1063	.0686	.0886	1.1469
2	1.267	1.0936	.0895	.1063	.0526	.0886	1.1012
3	1.2986	1.1069	.0886	.1052	.0543	.0876	1.1012
4	1.2986	1.0648	.0886	.1052	.0549	.0895	1.065
5	1.3352	1.0911	.0886	.0905	.0724	.0886	1.1336
6	1.3352	1.1683	.1063	.0905	.0686	.0876	1.2929
7	1.5364	1.3283	.1227	.1063	.0876	.1086	1.4575
8	1.4083	1.2793	.0876	.1227	.0857	.0905	1.4899
9	3.1093	.0905	1.7901	1.7901	1.7814	1.7444	.0876
10	.0895	.0905	1.7532		1.7284	1.749	.0701
11	.0914	.0886	1.6712	1.6907		1.749	.0686
12	.1063	.0905	1.5384	1.5592	1.587	1.4883	.0693
13	.0905	.0905	1.3765	1.4586	1.5384	1.2955	.0876
14	.1086	.1063	1.3441		1.4723	1.2763	.0848
15	.0876	.1063	1.3108	1.2378	1.4575	1.1934	.0838
16	.0686	.0876	1.3599	1.3245	1.442	1.21	.0857
17	.104	.1086	.1006	.0709	.0905	.0876	.0686
18	.0876	.1254	.0886	.0876	.1063	.0876	.0972
19	.1187	.1063	.124	.1227	.1052	.1052	.0972
20	.1341	.1227	.1448	.1214	.1227	.1086	.0972
21	.12	.1402	.1267	.1187	.1063	.124	.081
22	.12	.124	.124	.1017	.0886	.1063	.081
23	1.4089	.1063	.124	.0848	.1063	.0905	.0972
24	.0549	1.2289	1.6301	.1227	.0876	.0886	.0914
Max	3.1093	1.3283	1.7901	1.7901	1.7814	1.749	1.4899
Min	.0549	.0876	.0876	.0709	.0526	.0876	.0686
Avg	.6966	.5059	.6404	.4875	.5376	.5514	.4640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 207 / MIDC-III

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2277	1.2559	1.2841	1.0516	.9322	.9522	1.0063
2	1.0722	1.2445	1.2094	1.0604	.9012	.9145	.979
3	1.0776	1.1907	1.1812	.9932	.9053	.9023	.979
4	1.0273	1.163	1.1972	.9957	.9709	.8779	.9172
5	1.0592	1.1484	1.1704	.9798	1.0075	.8733	.9488
6	1.1172	1.1568	1.1576	1.0207	1.021	.8985	1.0623
7	1.0121	1.1439	1.1446	1.0056	1.0246	1.076	1.2725
8	1.0402	1.0528	1.146	.889	1.0197	1.129	1.214
9	1.3847	1.4716	1.3782	.8349	.9833	1.2792	1.3809
10	1.5115	1.5649	1.3748	.4572	1.2704	1.8038	1.4037
11	1.7848	1.9734	1.7185	.9021	.3757	1.8046	1.9312
12	1.6723	1.9578	1.7204	.8718	1.5657	1.89	1.6499
13	1.6427	1.8207	1.5951	.8349	1.7313	1.73	1.6857
14	1.7193	1.7478	1.5028	.4557	1.7803	1.7482	1.605
15	1.7726	1.5802	1.5973	.9362	1.729	1.76	1.8202
16	1.6827	1.8511	1.6728	.9755	1.7259	1.7593	1.6979
17	1.776	1.9159	1.6415	.9183	1.6896	1.6762	1.8176
18	1.5028	1.5508	1.3794	.8428	1.2041	1.5641	1.4114
19	1.3398	1.3588	.9964	.8375	1.1065	1.4114	1.1744
20	1.384	1.3276	.977	.7884	1.0566	1.2681	1.0269
21	1.3085	1.2624	1.0397	.887	.9343	1.0776	.9858
22	1.2589	1.3611	1.0669	.886	.966	.9707	.9774
23	1.3588	1.3839	1.1549	.9111	.9838	1.0368	1.0524
24	1.1927	1.3725	1.2003	1.009	.9457	.985	1.0103
Max	1.7848	1.9734	1.7204	1.0604	1.7803	1.89	1.9312
Min	1.0121	1.0528	.977	.4557	.3757	.8733	.9172
Avg	1.3719	1.4524	1.3128	.8894	1.1596	1.3079	1.2921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 208 / MIDC- IV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6053	.6112	.5357	.6325	.5506	.5973	.6386
2	.6053	.6059	.542	.628	.534	.6123	.5946
3	.6129	.5834	.5312	.6231	.5206	.6064	.5923
4	.6196	.5279	.5403	.5565	.4984	.5932	.5537
5	.6362	.486	.543	.5354	.49	.5719	.522
6	.6847	.5076	.5754	.5506	.54	.5731	.5705
7	.6257	.4999	.5836	.5854	.556	.671	.6173
8	.333	.4514	.5944	.559	.5567	.6756	.6242
9	.801	.5815	.6691	.5369	.6188	.7916	.6695
10	1.0954	.7312	.8497	.2926	.791	1.0814	.932
11	1.1873	.9107	.9714	.596	.4191	1.1317	.9774
12	1.1298	.884	.9726	.6072	.8774	1.1823	.9724
13	1.0452	.797	.7929	.5639	.8875	1.1099	.8276
14	1.1313	.8783	.8197	.3185	.7933	1.0604	.854
15	1.1256	.8776	.9032	.5851	.913	1.0467	.9615
16	1.008	.8834	.9572	.572	.9126	1.0734	.9343
17	.9526	.9154	.8913	.615	.8738	.9927	.8829
18	.8301	.7961	.8405	.6211	.7964	.8103	.7628
19	.7106	.6775	.691	.5998	.7964	.7282	.6653
20	.6402	.6795	.6969	.572	.7184	.6266	.6001
21	.5877	.5996	.6047	.5415	.644	.5712	.5239
22	.6066	.573	.5755	.5504	.6676	.5542	.4828
23	.6992	.6771	.6506	.5893	.694	.6704	.5967
24	.6475	.647	.5965	.6367	.6139	.6424	.6295
Max	1.1873	.9154	.9726	.6367	.913	1.1823	.9774
Min	.333	.4514	.5312	.2926	.4191	.5542	.4828
Avg	.7884	.6826	.7054	.5612	.6776	.7906	.7077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 401 / HINDUSTAN

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1824	3.7151	3.3265	3.774	2.8006	3.8809	3.8386
2	3.1824	3.5082	3.2487	3.6808	2.6292	3.6037	3.7334
3	3.1824	3.4294	3.2487	3.546	2.6029	3.5288	3.77
4	3.1276	3.3385	3.0493	3.4751	2.572	3.3265	3.5294
5	3.1276	3.2007	3.0493	3.4751	2.5463	3.3265	3.4208
6	3.1276	3.1436	3.1927	3.4019	2.5463	3.2487	3.5294
7	3.1824	3.5437	3.0493	3.4751	2.8578	3.6677	3.5837
8	3.2922	2.9721	2.9938	2.7721	3.1687	3.2156	3.5837
9	3.2373	3.2373	3.5482	2.7166	3.3122	3.2579	4.1152
10	3.1824	3.2922	3.4294		3.1824	2.8275	3.315
11	3.4751	3.1824	3.8295	2.4949	1.3306	3.5837	3.7151
12	3.2373	3.095	3.3722	2.2405	3.1824	3.2373	3.2007
13	3.3665	3.095	3.2579	2.2965	3.4751	3.4751	4.1152
14	3.678	2.9081	3.7723		3.2579	3.6145	3.6008
15	3.7151	3.1493	3.8477	2.4394	3.5665	3.5294	4.0009
16	3.7151	3.2579	3.7346	2.9721	3.8272	3.5294	3.9438
17	3.6008	2.963	3.4294	2.5149	3.4568	3.5757	3.9438
18	3.7151	3.1602	3.2579	2.572	3.5482	3.5294	4.0175
19	3.9438	3.3265	3.8912	2.999	4.1581	3.786	4.1307
20	3.6008	3.3048	3.786	2.7161	3.77	3.5837	4.1307
21	3.5437	3.0493	3.6283	3.1436	3.8649	3.7334	4.0741
22	4.0581	3.0087	3.774	3.0864	4.0472	3.7334	4.0741
23	4.1152	3.3819	3.9963	3.2007	3.9918	3.8803	3.9043
24	4.6291	4.0009	3.4374	3.8912	2.915	3.6591	3.5665
Max	4.6291	4.0009	3.9963	3.8912	4.1581	3.8809	4.1307
Min	3.1276	2.9081	2.9938	2.2405	1.3306	2.8275	3.2007
Avg	3.5091	3.2610	3.4646	3.0402	3.1921	3.5139	3.7849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching

Station

Feeder No / Name : 201 / KARVE Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.379	.2641	.2641	.2641	.3018	1.3245
2	1.2742	1.3203	.2641	.2641	.2452	.2829	1.2929
3	1.2574	1.2887	.2452	.2452	.2452	.3018	1.2944
4	1.3375	1.2887	.2829	.2641	.2641	.3018	1.3245
5	1.3847	1.326	.3018	.3206	.2829	.3772	1.3717
6	1.5242	1.7284	.3584	.3772	.3206	.4338	1.6918
7	1.9052	1.8663	.3395	.3772	.3584	.3961	1.8673
8	1.8778	1.7665	.3018	.3772	.3395	.3395	1.8595
9	.1886	.2263	2.0778	2.0271	2.1605	2.0216	
10	.2075	.2263	2.2809		2.4036	2.1605	
11	.2263	.2641	2.2138	2.1674		2.077	
12		.2452	2.0881	1.9364		1.9616	
13	.2641	.2641		1.8576	1.9841	1.8576	
14	.2641	.2452	1.2431		1.929	1.7604	
15	.2641	.2641	1.9913	1.9204	1.8673	1.8663	.2452
16	.2641	.3018	1.9658	1.8631	1.8595	1.8595	.3395
17	.2829	.2829	.2263	.2263	.2641	.2263	.3584
18	.3018	.3206	.2263	.2263	.2641	.2641	.3395
19	.3395	.3584	.3018	.3018	.3395	.3018	.3961
20	.3584	.415	.3584	.3206	.3772	.3395	.415
21	.3395	.3772	.3584	.3395	.3772	.3584	.415
22	.3206	.3584	.3206	.3018	.3584	.3206	.3961
23	1.4861	.3018	.3018	.2641	.3584	.3018	.3018
24	1.3032	1.448	.2829	.2829	.2641	.3018	.2829
Max	1.9052	1.8663	2.2809	2.1674	2.4036	2.1605	1.8673
Min	.1886	.2263	.2263	.2263	.2452	.2263	.2452
Avg	.7946	.7443	.8085	.7511	.7785	.8631	.8620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching

Station

Feeder No / Name : 202 / TEMBHU LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3546	2.2068	1.7071	1.5242	1.5546	1.25
2	1.3672	2.2809	1.7008	1.5352	1.5352	1.2498
3	1.3969	2.2531	1.7223	1.5352	1.5352	1.2654
4	1.3998	2.1948	1.7284	1.5158	1.5306	1.2193
5	1.387	2.1914	1.6857	1.5051	1.5306	1.2498
6	1.5089	2.2929	1.7223	1.5352	1.4914	1.2037
7	1.6667	2.2558	1.821	1.6667	1.5697	1.2944
8	1.8964	2.3167	2.0466	1.7071	1.6871	1.6049
9	2.372	2.359	2.0778	1.7375	1.781	1.7528
10	2.4827	2.2653	2.0083		1.9997	1.9136
11	2.4684	2.2377	2.234	1.8964		2.2028
12		2.2685	2.1914	1.8576	1.1138	2.1491
13		2.1674	2.1712	1.7718	1.406	
14	2.3015	1.7017	2.1845		1.4685	
15	2.3167	1.6792	2.2125	1.8278	1.656	
16	1.4432			1.0574	.6015	1.1883
Max	2.4827	2.359	2.234	1.8964	1.9997	2.2028
Min	1.3546	1.6792	1.6857	1.0574	.6015	1.1883
Avg	1.8116	2.1781	1.9476	1.6195	1.4974	1.5034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching

Station

Feeder No / Name : 206 / 11 KV Karve Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4481	.4435	.4668	.4527	.462	.4854
2	.4527	.4527	.4435	.4481	.4527	.4481	.4668
3	.4527	.4338	.4481	.4481	.4338	.4435	.4715
4	.4481	.5041	.4668	.4668	.4338	.4715	.4854
5	.6036	.5544	.5914	.5975	.4854	.6979	.6535
6	.7842	.8215	.7682	.7655	.7023	.8316	.8962
7	.695	.7421	.7762	.7392	.7316	.7682	.724
8	.5316	.5784	.6024	.5552	.5784	.6024	.5959
9	.4382	.5201	.5144	.3988	.4908	.4973	.4578
10	.3467	.4287	.4334		.4115	.4458	.4239
11	.2947	.3944	.4458	.407		.4527	.4458
12	.4409	.463	.4409	.4287		.4748	.4527
13	.4287	.4409	.431	.4115	.4252	.4801	
14	.4508	.4508	.4458		.4252	.4578	.4298
15	.4557	.4382	.4287	.4075	.4477	.4458	.4298
16	.4334	.3814	.3898	.3814	.4252	.4409	.4075
17	.4557	.4191	.3688	.3944	.3856	.4908	.4287
18	.4784	.3932	.4024	.3601	.4527	.5316	.4144
19	.5609	.5959	.5609	.5316	.631	.5959	.5316
20	.695	.6805	.7421	.6767	.7499	.724	.724
21	.6584	.695	.7133	.6468	.7392	.7316	.7316
22	.6413	.6535	.6468	.6099	.6908	.6838	.7023
23	.5228	.5544	.5304	.5415	.5729	.5729	.5487
24	.4854	.462	.4805	.462	.4854	.499	.5041
Max	.7842	.8215	.7762	.7655	.7499	.8316	.8962
Min	.2947	.3814	.3688	.3601	.3856	.4409	.4075
Avg	.5092	.5211	.5215	.5066	.5274	.5521	.5396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254073 / 33/11 KV VADGAON H

Feeder No / Name : 201 / 11 KV VADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.3582	.3582		.362	.3761	.362
2	.3403	.3582	.3403	.3077	.3439	.3761	.362
3	.3475	.3475	.3582	.3077	.3475	.3761	.3658
4	.4024	.4024	.394	.3475	.3658	.394	.4207
5	.4572	.439	.4706	.439	.439	.4706	.4938
6	.5304	.5121	.5121	.4755	.5304	.5487	.5304
7	.5014	.4607	.4961	.4607	.4733	.4961	.407
8	.3641	.3814	.3944	.3294	.3988	.3814	.3521
9	.3315	.3277	.3441	.2949	.2984	.3315	.3077
10	.3315	.3239	.3361			.2881	.2949
11	.3277	.2721	.2915	.3077		.3005	.2984
12	.3077	.3113	.3005	.3077		.3041	.3315
13	.3077	.3149	.3041	.3315	.2984	.3113	
14	.2652	.2818	.2883		.2543	.2785	
15	.2622	.2652	.2683	.285	.253	.2622	
16	.2915	.2984		.2622	.2458	.3113	.3561
17	.2753	.2915	.2949	.2753	.3077	.2753	.3239
18	.2915	.3125	.2881	.2785	.3605	.3201	.3321
19	.3353	.4115	.407	.3391	.4458	.3856	.39
20	.4334	.443	.4681	.4557	.4908	.3467	
21	.4733	.5316	.4607	.4607	.5316	.4961	
22	.443	.4835	.4607	.4607	.5014	.4835	.5316
23	.4298	.4298	.4298	.443	.4607	.4252	.443
24	.3582	.3582	.3582	.3582	.3761	.3856	.3761
Max	.5304	.5316	.5121	.4755	.5316	.5487	.5316
Min	.2622	.2652	.2683	.2622	.2458	.2622	.2949
Avg	.3653	.3715	.3750	.3585	.3850	.3719	.3831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254073 / 33/11 KV VADGAON H

Feeder No / Name : 202 / 11 KV VADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.9511	.1886		.132	.1886	.8488
2	.8398	.9511	.1698	.132	.132	.1886	.823
3	.8619	.8916	.1698	.132	.132	.1886	.7977
4	.8398	.9145	.1698	.132	.132	.1886	.7977
5	.8398	.9362	.1698	.1509	.1509	.1886	.7573
6	.8688	.9659	.1905	.1509	.1698	.2263	.8619
7	1.0122	.9701	.2263	.1886	.2075	.2263	.904
8	.9389	.9511	.2075	.1509	.2263	.2075	.9164
9	.1132	.1132	1.1431	.945	1.1584	1.1736	
10	.1509	.132	1.1004			1.0987	
11	.1698	.1478	1.0416	.9556		.9701	
12	.1886	.1663	.9859	.9717		.9002	
13	.1867	.1698	.9446	.9556	.9536	.8716	
14	.168	.1698	.9682		.8859	.8573	
15	.1886	.1698	.8288	.8318	.8716	.8459	.1886
16	.1886	.1478		.8741	.8762	.86	.2075
17	.2075	.1463	.1307	.132	.1698	.1509	.2263
18	.1886	.1646	.168	.1698	.2075	.1867	.2241
19	.1886	.1698	.1698	.2075	.2075	.2075	.2263
20	.1886	.1905	.1886	.2075	.2075	.2241	.2427
21	.1886	.1905	.1886	.2075	.2075	.2263	.2263
22	.1698	.1905	.1698	.1509	.1905	.2075	.2263
23	.9934	.0191	.1698	.1509	.1886	.1886	.2033
24	.8688	.9511	.1886	.1509	.1509	.1886	.1698
Max	1.0122	.9701	1.1431	.9717	1.1584	1.1736	.9164
Min	.1132	.0191	.1307	.132	.132	.1509	.1698
Avg	.4758	.4488	.4295	.3785	.3599	.4484	.4916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256011 / 110 KV TEMBHU

Feeder No / Name : 204 / TEMBHU Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2587	.2402	.2427	.2587	.2587	.2614
2	.2587	.2614	.2402	.2427	.2614	.2402	.2402
3	.2587	.2427	.2427	.2402	.2427	.2378	.2427
4	.2561	.2587	.2587	.2614	.2587	.2402	.2614
5	.2743	.2743	.2715	.2926	.2987	.2987	.2772
6	.3801	.4163	.3841	.3801	.3018	.4344	.3841
7	.3856	.3856	.333	.3681	.3391	.3988	.3429
8	.3688	.3391	.3814	.3222	.3113	.3647	.3113
9	.3391	.3052	.3185	.2949	.3605	.3401	.3077
10	.2622	.2561	.2721		.2279	.3125	.2846
11	.2915	.2561	.2915	.2031		.2896	.3041
12	.2656	.2656	.2846	.2056	.2035	.2932	.3201
13	.2372	.2721	.2372	.1875	.2229	.2753	.2778
14	.2688	.2267	.2241		.208	.2458	.2785
15	.2429	.2561	.2591	.1823	.2229	.2818	.3185
16	.3681	.3563	.3521	.1389	.3018	.3563	.407
17	.3479	.3479	.3563	.2915	.3041	.3768	.3932
18	.3704	.3858	.3281	.3113	.3361	.3858	.4001
19	.4475	.4475	.4191	.3647	.4409	.431	.4024
20	.4161	.4239	.3988	.333	.4557	.5028	.4031
21	.3721	.3681	.3366	.3189	.3721	.3856	.3761
22	.3658	.3292	.3439	.3258	.3801	.3582	.3658
23	.3109	.2926	.2957	.2772	.3077	.2957	.3326
24	.2772	.2957	.2715	.2587	.2587	.2715	.2587
Max	.4475	.4475	.4191	.3801	.4557	.5028	.407
Min	.2372	.2267	.2241	.1389	.2035	.2378	.2402
Avg	.3183	.3134	.3059	.2747	.2989	.3281	.3230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 201 / MUNDHA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0914	1.9814	2.1605	2.0729	2.0576	.1524
2	.061	.0914	1.9814	2.1434	2.0729	.1029	.1524
3	.061	.0914	1.9814	2.1434	2.0729	.1029	.1524
4	.061	.0914	1.9814	2.2291	2.1033	.0857	.1524
5	.061	.0914	1.9814	2.2291	2.1033	.0857	.1524
6	.1067	.0914	1.9966	2.2977	2.1033	.0857	.1524
7	.1219	.0914	2.271	2.4006	2.1033	.12	.1372
8	.1067	.0762	2.271	2.5034	2.2405	2.7092	.1219
9	2.6368	2.7435	.1219	.1067	.12	2.2862	2.271
10	2.774	2.713	.1219		.12	2.2405	2.6978
11	2.6673	2.6825	.12	.1067	.12		2.5911
12	2.5301	2.4691	.12	.1524	.1715		2.3624
13	2.4387	2.332	.12	.1372	.1886		2.4996
14	2.332	2.2253	.12	.1524	.1886		2.4234
15	2.3624	2.2558	.12	.1372	.1543	.061	2.5758
16	2.4234	2.332	.12		.1543	.1067	2.5453
17	.0457	.0762	.12		.1715	.1524	.1219
18	.0914	.0762	.12	.1677	.2229	.1829	
19	.061	.1067	.12	.1677	.1715	.2134	.1524
20	.0914	.1219	.12	.1829	.1715	.1981	.1524
21	.0914	.1219	.12	.1829	.1715	.2134	.1524
22	.0914	.1067	.12	.1829	.1715	.1981	.1524
23	.0914	1.9814	2.0576	1.9966	.1372	.2286	.1524
24	.061	.0914	1.9662	2.1262	2.0729	.1715	.1677
Max	2.774	2.7435	2.271	2.5034	2.2405	2.7092	2.6978
Min	.0457	.0762	.12	.1067	.12	.061	.1219
Avg	.8929	.9647	.9231	1.1384	.8908	.5801	.9648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 202 / LIS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3574	.4466					.4512
2	.4237	.4733					.4816
3	.4267	.4725					.4488
4	.4313	.4793					.4389
5	.4382	.5121					.4992
6	.5784	.6104					.5327
7	.7713	.7423					.7323
8	.8002	.73					.7431
9	.362	.3346	.8451	.6714	.7194	.804	.3521
10			.9785	.4664	.8184	1.0821	
11			1.0722	.833	.6493	1.0357	
12			1.0448	.804	.8916	.9244	
13			.9576	.8459	.8817	.9122	
14			.9705	.7758	.8657	.9671	
15			.9065	.743	.8245	.8711	
16			.7945	.4199	.6893	.836	
17			.3041		.3307	.3704	
23	.4062						
24	.3871	.1829					
Max	.8002	.7423	1.0722	.8459	.8916	1.0821	.7431
Min	.3574	.1829	.3041	.4199	.3307	.3704	.3521
Avg	.4893	.4984	.8749	.6949	.7412	.867	.5200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 204 / MARALI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3772	.3772	.4115	.3772	.4115	.3601
2	.3944	.3772	.3772	.4115	.3772	.4115	.3601
3	.3944	.3772	.3772	.4115	.3772	.4115	.3601
4	.3944	.3772	.3772	.4115	.3772	.4287	.3601
5	.3944	.4115	.3772	.4115	.4115	.4287	.3772
6	.463	.4458	.4115	.4115	.4458	.4287	.4287
7	.4973	.4801	.4287	.4287	.4458	.463	.463
8	.4801	.4287	.4287	.3944	.463	.463	.4458
9	.4458	.463	.4458	.2058	.4458	.4458	.4115
10	.4458	.4458	.3944		.2401	.463	.4287
11	.4287	.4458	.4115	.2401	.2058	.4973	.4287
12	.4287	.4287	.4115	.2572	.2058	.4458	.4801
13	.4458	.4287	.4115	.2401	.2229	.4287	.463
14	.463	.463	.4287	2.6578	.4287	.4287	.463
15	.4801	.463	.4287	.4801	.4973	.4973	.4973
16	.5144	.4801	.4287		.463	.463	.5316
17	.4973	.4287	.4801		.4801	.463	.5487
18	.4973	.4287	.5144	.5144	.4801	.4801	
19	.6001	.583	.583	.583	.5487	.583	.6173
20	.6516	.6001	.6173	.6687	.6516	.6173	.6516
21	.6173	.5487	.6173	.6173	.583	.5658	.5487
22	.5658	.4973	.5144	.5316	.5316	.5316	.5144
23	.463	.4287	.4458	.4287	.4458	.4458	.4801
24	.3944	.4115	.3772	.4115	.3772	.4115	.3944
Max	.6516	.6001	.6173	2.6578	.6516	.6173	.6516
Min	.3944	.3772	.3772	.2058	.2058	.4115	.3601
Avg	.4730	.4508	.4444	.5299	.4201	.4673	.4615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 206 / SOMAIDEVI LIS EXPRESS

PURELY LIS FEEDERS

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2536	1.8359	1.5067		1.2498	2.1232	1.9022
2	1.2848	1.8519	1.5029		1.2627	2.1651	.2233
3	1.2833	1.8465	1.5006		1.2635	2.4524	
4	1.281	1.8458	1.5006		1.262	2.553	
5	1.2978	1.8465	1.5021		1.2635	2.5538	
6	1.3154	1.9845	1.9791		1.409	2.6318	
7	1.8952	2.2466	2.5507		2.2862	2.2188	
8	2.1734	2.5766	2.5477		1.1652	2.6612	.1692
9	2.5606	2.6383	2.6353		1.1568	2.5271	
10	2.5804	2.6048	2.5576			2.3914	
11	2.5842	2.5629	2.6444			2.3449	
12	2.5796	2.5522	2.6475			2.3045	
13	2.5209	2.5202	2.6345			2.3296	
14	2.5049	2.2786	2.5911			2.3068	
15	2.5796	1.951	2.5987		.0221	2.3274	
16	2.5187	1.9395	2.5278		1.4221	2.2237	
24	.1387	.0175		.0686	.189	.1593	.0716
Max	2.5842	2.6383	2.6475	.0686	2.2862	2.6612	1.9022
Min	.1387	.0175	1.5006	.0686	.0221	.1593	.0716
Avg	1.9031	2.0647	2.2142	.0686	1.1627	2.2514	.5916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 201 / 11 KV Kalgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5464	.5316	.58	.538	.5141	.6472	.6744
2	.5327	.5278	.5685	.5483	.5144	.644	.6516
3	.5045	.5388	.5533	.5083	.4855	.6394	.6438
4	.4851	.5335	.5483	.5037	.4748	.6207	.5994
5	.4776	.5608	.5437	.5053	.4699	.6316	.6415
6	.6135	.7164	.767	.6707	.6691	.7716	.8166
7	.7815	.9114	.9358	.9034	.8779	.9812	.9465
8	.8299	.8691	.8474	.8695	.892	.927	.9229
9	.8025	.8726	.7697	.7701	.7393	.8722	.8154
10	.7571	.7503	.735	.3647	.6767	.8372	.754
11	.7342	.6965	.7377	.6274	.3083	.7912	.7224
12	.7	.6973	.6881	.607	.7547	.7469	.6722
13	.7099	.6683	.6778	.3231	.7848	.7253	.6771
14	.6688	.6828	.6744		.7571	.7247	.6539
15	.652	.6619	.6375		.7388	.7323	.6268
16	.743	.7076	.6882		.7838	.8152	.6809
17	.7716	.8015	.7846		.7463	.8612	.6672
18	.8276	.8745	.916		.812	.8332	.7217
19	.9827	1.0366	1.0442	1.1454	1.0048	1.0395	.8625
20	1.2803	1.323	1.294	1.3546	1.3759	1.4356	1.238
21	1.238	1.2479	1.1751	1.2714	1.3139	1.3477	1.214
22	1.097	1.057	1.068	1.0913	1.1492	1.1765	1.1188
23	.8248	.7851	.7958	.8372	.9542	.9625	.8996
24	.6283	.6196	.6169	.6393	.6893	.7556	.731
Max	1.2803	1.323	1.294	1.3546	1.3759	1.4356	1.238
Min	.4776	.5278	.5437	.3231	.3083	.6207	.5994
Avg	.7579	.7780	.7770	.7410	.7703	.8550	.7897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 202 / 11 KV Jinti Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1372	.1341	.104	.12	.124	.1402
2	.12	.1372	.1357	.104	.12	.1227	.1402
3	.12	.1372	.1341	.1017	.12	.1227	.124
4	.12	.1372	.1174	.1187	.12	.1227	.124
5	.1387	.1372	.1372	.12	.12	.124	.1448
6	.1612	.1612	.1595	.1433	.1612	.1629	.1848
7	.2328	.2328	.2328	.1791	.2126	.1991	.2172
8	.1907	.2172	.1417	.1753	.2103	.1772	.2103
9	.1402	.1928	.1387	.1578	.1753	.1578	.1715
10	.1677	.2012	.1526		.1509	.2012	.1715
11	.1696	.1966	.1638	.1326		.1696	.1543
12	.128	.176	.1638	.144	.1619	.1509	.1619
13	.1296	.1475	.1638		.1734	.1638	.1781
14	.144	.1457	.1638		.1543	.1526	.1696
15	.1619	.1509	.1638		.156	.1696	.1715
16	.1875	.1638	.16		.1696	.1865	.1715
17	.1898	.1852	.1718		.1457	.1829	.176
18	.192	.2031	.1898		.2012	.1943	.2056
19	.2374	.2035	.2713	.2804	.2454	.2279	.208
20	.3439	.2896	.3077	.2896	.3109	.3077	.2715
21	.2915	.2534	.3077	.2534	.2743	.2926	.2743
22	.2481	.2353	.2561	.2378	.2587	.2534	.2353
23	.1949	.1595	.1629	.1791	.2103	.1612	.1791
24	.1372	.1595	.1543	.1227	.1402	.1578	.1595
Max	.3439	.2896	.3077	.2896	.3109	.3077	.2743
Min	.12	.1372	.1174	.1017	.12	.1227	.124
Avg	.1778	.1817	.1785	.1673	.1788	.1785	.1810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 203 / SANBUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2915	.2347	.2601	.2743	.3012	.3155
2	.2572	.2915	.2374	.2601	.2743	.298	.298
3	.2572	.2915	.2347	.2543	.2743	.2804	.3012
4	.2572	.2915	.2347	.2543	.2743	.2629	.3189
5	.2601	.3086	.2401	.2572	.12	.2835	.3258
6	.3761	.3761	.3898	.4119	.1254	.4163	.462
7	.4656	.4477	.4298	.4656	.1595	.4887	.5068
8	.4161	.4382	.4075	.4031	.1227	.4607	.4557
9	.4207	.4382	.3467	.3856	.3155	.4207	.3772
10	.3856	.3353	.2883		.3018	.4207	.3772
11	.373	.3113	.3052	.2652		.373	.3772
12	.3521	.2721	.3113	.2561	.4049	.3688	.3563
13	.3401	.2622	.2949		.4161	.3391	.2753
14	.3361	.2591	.2949		.3601	.3561	.2883
15	.3239	.2683	.2949		.3814	.373	.2915
16	.3281	.2949	.3041		.3561	.39	.3086
17	.253	.3281	.3125		.3887	.381	.3041
18	.2881	.2968	.3637		.4359	.4049	.3479
19	.4578	.4409	.4917	.5083	.5434	.5434	.4334
20	.6154	.5973	.6154	.6154	.695	.6697	.5973
21	.5853	.543	.543	.5611	.6584	.6219	.5853
22	.4784	.4525	.4572	.4755	.5359	.543	.4887
23	.3544	.3189	.3439	.3224	.4031	.394	.3761
24	.2915	.3012	.2572	.2804	.2804	.3155	.3366
Max	.6154	.5973	.6154	.6154	.695	.6697	.5973
Min	.2058	.2591	.2347	.2543	.12	.2629	.2753
Avg	.3616	.3524	.3431	.3669	.3522	.4044	.3794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 204 / TALMAVALE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7625	.7209	.7377	.8	.7354	.8333	.8664
2	.7343	.7064	.7086	.7802	.7148	.7872	.8512
3	.7343	.7034	.6904	.757	.7056	.7484	.8457
4	.6977	.6912	.663	.7293	.6805	.7568	.8449
5	.7239	.7244	.6878	.761	.679	.7975	.9113
6	.9034	.8695	.8497	.86	.8676	.9538	1.1561
7	.7929	1.044	1.0402	1.0063	1.0246	1.1639	1.267
8	1.0282	1.0616	1.0402	.9961	.9328	1.0713	1.2064
9	.9336	.9465	.8701	.9579	.8787	1.0273	1.1001
10	.9069	.8825	.9324	.5235	1.0403	1.0772	1.1085
11	.9001	.9953	.977	.9703		1.0985	1.0639
12	.7865	.9076	.8695	.3978	1.1016	.9267	.4748
13	.9394	.8794	.887	.2301	1.0435	.9317	1.0743
14	.9061	.8627	.6698		.8543	1.0179	1.1665
15	.8911	.9503	.676		.8868	.9888	1.1195
16	.9309	.9839	1.041		.8856	.9698	1.0913
17	.8754	.9057	1.1134		.5942	.9862	.9816
18	.8185	.9731	1.0174		1.1591	1.028	.9846
19	1.0136	1.0633	1.2067	1.4777	1.2376	1.2856	1.1121
20	1.2068	1.2989	1.4087	1.6027	1.5158	1.5484	1.322
21	1.2003	1.2952	1.3634	1.395	1.4167	1.4624	1.2963
22	1.0787	1.19	1.2948	1.2712	1.2912	1.2914	1.2024
23	.9461	.9686	1.1043	1.0597	1.0921	1.1149	1.0696
24	.8451	.7693	.86	.8969	.8808	.9275	.9289
Max	1.2068	1.2989	1.4087	1.6027	1.5158	1.5484	1.322
Min	.6977	.6912	.663	.2301	.5942	.7484	.4748
Avg	.8982	.9331	.9462	.9196	.9660	1.0331	1.0436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 205 / Sanbur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3025	.2637					.122
2	.3014	.2645					.213
3	.2595	.2347					.2096
4	.2404	.2172					.1915
5	.2517	.2084					.2538
6	.3247	.2839					.3422
7	.4496	.4351					.5394
8	.5251	.4527					.5746
9	.2896	.2256	.4706	.3642	.4218	.4286	.2724
10			.9877	.3494	.7701	.8345	
11			.8783	.6028	.439	.7582	
12			.7434	.5105	.6752	.6699	
13			.6333	.2568	.6815	.5365	
14			.5537		.6127	.4955	
15			.551		.6007	.5098	
16			.5358		.5704	.5015	
17			.3014		.3071	.2732	
23	.1638						
24	.346	.1417					
Max	.5251	.4527	.9877	.6028	.7701	.8345	.5746
Min	.1638	.1417	.3014	.2568	.3071	.2732	.122
Avg	.3140	.2728	.6284	.4167	.5643	.5564	.3021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 206 / 11 KV Kalgaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2683	.2774	.2915	.3012	
2			.2713	.2774	.2915	.7888	
3			.285	.2713	.2915	.2629	
4			.285	.2883	.2915	.2629	
5			.2915	.3258	.2915	.2658	
6			.4075	.4477	.3582	.362	
7			.5014	.6089	.4961	.4163	
8			.4252	.4908	.4908	.3366	
9	.2454	.631					.6344
10	.285	.6036					.6344
11	.3052	.5735					.583
12	.208	.5761					.4858
13	.2591	.5735					.421
14	.4161	.5344					.4409
15	.6478	.5197					.4458
16	.4062	.5243					.4115
23		.3012	.3439	.3224			
24			.2743	.298	.3506		
Max	.6478	.631	.5014	.6089	.4961	.7888	.6344
Min	.208	.3012	.2683	.2713	.2915	.2629	.4115
Avg	.3466	.5375	.3353	.3608	.3504	.3746	.5071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 201 / 11 KV Mandure Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126		.2294	.2103		.2294	.2103
2	.1772		.1943	.2103		.1943	
3	.2126		.1943	.208		.1943	.2103
4	.2126		.1943	.2103		.1943	.2103
5	.2481		.1943	.2454		.2294	.2103
6	.2835		.2652	.3155		.2622	.2774
7	.3189		.3506	.3506		.3506	.3506
8	.3189		.3086	.3506		.3086	.3544
9	.3189		.3086	.2804		.3086	.2835
10	.3224	.3086	.3189			.3155	.2507
11	.2149	.3506	.3189		.2683	.3155	.2401
12	.3224	.3086	.3155		.3506	.2804	.2507
13	.3224	.3086	.2804		.2683	.2103	.2865
14	.3224	.1989	.2427		.2347	2.7694	.2507
15	.2865	.3086	.1402		.2683	.3506	.2507
16	.2865	.4252	.3467		.3086	.3856	.2865
17	.394	.4252	.3856		.3856	.4557	.3582
18	.4298	.4961	.4557		.4207	.4908	.394
19	.5014	.5373	.5959	.6447	.567	.5609	.5731
20	.6447	.6805			.6805	.6379	.6805
21	.6089	.6089	.5548		.4607	.5959	.6447
22	.5014	.4961	.4908		.4961	.5258	.5014
23	.3582	.3018	.3467		.3856	.4252	.3582
24	.2454		.2294	.2454		.3018	.3155
Max	.6447	.6805	.5959	.6447	.6805	2.7694	.6805
Min	.1772	.1989	.1402	.208	.2347	.1943	.2103
Avg	.3360	.4111	.3157	.2974	.3919	.4539	.3369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 202 / LIS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			5.2652	5.0404	2.4173	3.9666	
2			5.0603	4.8191	2.332	4.3184	
3			4.8594	4.7752	2.2695	4.1815	
4			4.662	4.7127	2.2573	4.1952	
5			4.6437	4.6823	2.2695	4.2257	
6			5.0374	4.792	2.4524	4.4814	
7			5.6104	5.3711	2.6901	5.1045	
8			5.4999	5.6272	2.5652	4.9208	
9	6.2582	3.4202	1.4236	1.6598	1.3077	1.3032	5.8147
10	7.1041	7.1407					6.451
11	6.8122	6.2559					6.7962
12	6.9814	7.0439					6.6369
13	5.9862	6.4785					6.611
14	6.3328	6.3123					6.4273
15	6.409	3.8866					6.4449
16	6.195	5.6646					6.2377
17	1.893	1.5455					1.5867
23		5.2385	4.8728	2.4463	.0701		
24		2.9279	5.2347	4.8956			
Max	7.1041	7.1407	5.6104	5.6272	2.6901	5.1045	6.7962
Min	1.893	1.5455	1.4236	1.6598	.0701	1.3032	1.5867
Avg	5.9969	5.0831	4.7427	4.4383	2.0631	4.0775	5.8896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 203 / ADUL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.821	1.2696	2.1373	2.2596	1.0978	1.7684	2.0603
2	1.781	1.2033	2.0378	2.1106	1.0631	1.7178	1.0532
3	1.7604	1.1908	2.0009	2.0325	1.0418	1.7052	2.0401
4	1.8546	1.1778	2.0626	1.9986	1.0231	1.7616	1.9994
5	1.9993	1.2045	2.2954	2.1292	1.0917	2.0473	2.2039
6	2.3872	1.3923	2.7697	2.4871	1.2601	2.3431	2.4756
7	2.8285	1.515	2.987	2.9668	1.4685	2.9591	2.5762
8	2.9424	1.5299	2.8838	3.0076	1.4552	2.8882	2.8571
9	2.8886	1.5661	2.7644	2.7831	1.4624	2.8331	2.8693
10	2.8776	2.9085	2.591	1.4079	1.3336	2.5899	2.857
11	2.8483	2.9241	2.4604	1.358	1.5329	2.4299	2.8296
12	2.6474	2.6761	2.2633	1.3443	2.023	2.308	2.4588
13	1.9227	2.3545	2.1692	1.102	2.066	2.2961	2.0294
14	1.9921	2.0931	1.9993	.9012	2.1982	2.2996	1.9803
15	2.1746	2.2428	2.1456	.9979	2.3164	2.3625	2.2684
16	2.3194	2.1449	2.2188	1.0848	2.2904	2.3171	2.5007
17	2.3229	2.4619	2.4291	1.1953	2.4863	2.5289	2.7031
18	2.5091	2.4474	2.5027	1.2422	2.7027	2.8471	2.7866
19	2.8719	2.8117	2.8669	2.9645	2.9367	3.147	2.9081
20	3.6043	1.6671	3.2575	1.6773	3.4115	3.1675	3.0876
21	3.5635	3.1269	3.296	1.7151	3.221	1.6404	3.0601
22	3.5353	3.1825	3.2731	1.611	3.0598	3.0133	2.8041
23	3.1577	2.7763	2.8155	1.4521	2.6905	2.7332	2.4882
24	2.3553	1.23	2.4562	2.3239	1.2018	2.0504	2.1864
Max	3.6043	3.1825	3.296	3.0076	3.4115	3.1675	3.0876
Min	1.7604	1.1778	1.9993	.9012	1.0231	1.6404	1.0532
Avg	2.5402	2.0457	2.5285	1.8397	1.9348	2.4064	2.4618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 204 / HELWAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2764	.7217	1.1511	1.0913	.586	1.0128	1.1835
2	1.1832	.6889	1.0745	1.0227	.5533	.9167	.599
3	1.1657	.676	1.0094	1.0013	.5472	.9053	1.1088
4	1.1489	.6409	.9987	1.0021	.551	.8748	1.0966
5	1.1968	.6455	1.0433	1.5356	.5624	.9663	1.1507
6	1.3622	.772	1.2948	1.2593	.7064	1.1424	1.4357
7	1.8359	.8535	1.6926	1.7322	.6798	1.7063	1.7535
8	2.1015	.865	1.8385	1.8137	.8627	2.002	1.8861
9	2.2237	.9534	2.0069	1.9044	.9122	2.1708	1.8199
10	2.2755	1.4937	2.0446	1.0372	.9153	1.9395	1.7992
11	2.1765	1.9841	1.8808	.9869	.8394	.8612	1.7345
12	1.9738	2.082	1.6289	.964	1.8278	1.5993	1.6248
13	1.832	1.8278	1.8824	.9381	1.8359	1.592	1.4122
14	1.7802	1.6385	1.643	.804	1.7478	1.7147	1.4243
15	1.9021	1.7226	1.5935	.8634	1.7516	1.9425	1.5478
16	1.9845	1.7818	1.7493	.9724	1.6834	1.9913	1.6819
17	2.0089	1.9197	1.4434	.948	1.837	2.1155	1.8046
18	2.0409	1.9246	1.8461	.8924	1.8694	2.1765	1.8725
19	2.3015	1.9391	2.0858	2.1018	2.1456	2.2992	2.1613
20	2.7588	2.5385	2.3602	1.31	2.508	2.7233	2.6421
21	2.6375	2.4805	2.223	1.2231	2.3861	2.6189	2.4676
22	2.3182	2.1476	2.0759	1.1401	2.1392	2.303	2.1788
23	1.9036	1.608	1.5989	.932	1.595	1.7436	1.7924
24	1.4998	.6958	1.3371	1.1862	.6889	1.2982	1.4136
Max	2.7588	2.5385	2.3602	2.1018	2.508	2.7233	2.6421
Min	1.1489	.6409	.9987	.804	.5472	.8612	.599
Avg	1.8703	1.4417	1.6459	1.1943	1.3221	1.6923	1.6496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 205 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.258	.5853	.7476	.3768	.564	.6851
2	.4142	.2439	.4881	.695	.3326	.6203	.3201
3	.4066	.2477	.2446	.6066	.3178	.6138	.551
4	.3864	.2241	.176	.517	.3151	.6024	.5381
5	.4184	.2031	.3894	.4854	.2759	.5875	.5533
6	.4549	.2416	.4493	.5136	.3132	.5807	.5666
7	.5312	.2721	.524	.6382	.3586	.7552	.6279
8	.6886	.3022	.6554	.7549	.3616	.7712	.7252
9	.7385	.3826	.6984	.9754	.4249	1.1104	.9343
10	.9652	.9823	.9138	.5891	.5415	1.1499	1.1122
11	1.0849	.9404	.9415	.6055	.2846	1.2052	1.2292
12	1.0783	.9995	.9613	.6238	1.0501	1.177	1.2594
13	.9637	.857	.9252	.6531	1.1992	1.2155	1.0314
14	.9305	.8776	.876	.4999	1.1535	1.1428	1.0452
15	.8897	.8059	.9046	.2976	1.1367	.9914	1.0021
16	.8269	.8135	.8962	.5662	1.0182	.9134	.9126
17	.666	.8192	.8493	.5388	.8295	.7793	.8204
18	.6157	.7339	.7755	.4226	.6889	.6821	.7979
19	.5513	.5659	.7088	.3521	.6893	.6729	.6714
20	.4999	.4794	.6985	.3403	.6283	.6668	.6771
21	.4344	.4721	.695	.341	.5846	.3349	.6237
22	.4942	.4694	.7198	.3841	.6824	.7107	.668
23	.6485	.7049	.8158	.434	.7804	.7511	.7945
24	.6877	.3749	.7857	.8192	.4237	.5605	.732
Max	1.0849	.9995	.9613	.9754	1.1992	1.2155	1.2594
Min	.3864	.2031	.176	.2976	.2759	.3349	.3201
Avg	.6624	.5530	.6949	.5584	.6153	.7983	.7866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 206 / 11 KV Mandure Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4252	.4908		.3189	
2			.3898	.4557		.3189	
3				.4508		.2481	
4			.2149	.4557		.2481	
5			.2865	.4854		.2835	
6			.3582	.5258		.2835	
7			.4607	.5258		.3898	
8			.4607	.5258		.3544	
9	.8505		.0107			.0084	.6661
10	.7888	.6379					.6516
11	.7202	.7442			.0072		.6447
12		.7442			.0099	.6379	.6805
13	.7888	.7087			.0053		.5373
14	.7888	.6733			.0057		.6089
15	.8238	.6733			.0057		.6447
16	.7522	.5316			.0084		.6447
17		.0107			.0053		
18		.0099			.0099		
19		.0072			.0069		
20		.0084			.0053		
21		.0091			.0057		
22		.0095			.0099		
23		.4298	.4908		.0091		
24			.4607	.5258		.0076	
Max	.8505	.7442	.4908	.5258	.0099	.6379	.6805
Min	.7202	.0072	.0107	.4508	.0053	.0076	.5373
Avg	.7876	.3713	.3558	.4935	.0073	.2817	.6348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 207 / 11 KV Helwak Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4947	2.524	.1913	.2629	.2324	.2156	4.5237
2	4.4681	2.4874	.1913	.2629	.2332	.2164	2.444
3	4.2403	2.348	.1928	.2637	.234	.2187	4.5313
4	4.0859	2.2016	.1921	.2644	.2332	.2194	4.4079
5	4.0734	2.1773	.192	.2637	.234	.2187	3.9925
6	4.1717	2.3381	.1912	.2629	.2324	.2195	1.9974
7	4.337	2.2878	.189	.2591	.2317	.2202	3.773
8	4.7074	2.271	.1936	.2637	.2362	.2271	4.6494
9	1.8869	1.7817	2.3678	5.3666	2.6345	5.3696	1.7193
10	.2218	.1795	4.0482	3.0849	2.8578	5.8737	
11	.2187	.2325	5.7297	3.3638	3.8942	5.9168	
12	.2202	.2332	3.6771	3.1253	5.3993	.6295	
13	.2202	.237	5.4458	2.838	5.1791	5.1997	
14	.2164	.2363	5.5799	2.5934	4.9939	5.9938	
15	.2126	.2287	5.5868	2.7915	4.952	5.7659	
16	.2119	.1928	5.3323	2.5187	4.6326	5.3948	.0556
17	.2126	.1928	2.6947	1.8214	1.6359	2.3236	.2507
18	.2126	.1913	.2683	.2317	.2164	.2736	.2492
19	.2134	.1917	.2614	.2317	.2145	.2721	.237
20	.2126	.1924	.2561	.2317	.2141	.2721	.237
21	.2119	.1916	.2606	.2309	.2153	.2721	.2378
22	.2248	.192	.2614	.2317	.2172	.2721	.2378
23	4.4734	.1912	.2591	.2294	.218	.2782	.2576
24	4.5328	.1859	.2682	.2317	.2096	.2858	.2637
Max	4.7074	2.524	5.7297	5.3666	5.3993	5.9938	4.6494
Min	.2119	.1795	.189	.2294	.2096	.2156	.0556
Avg	2.0117	.9786	1.8263	1.3011	1.6480	1.9229	1.8925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 208 / Patan Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567		.5731	.5609		.6089	.5609
2	.5258		.5316	.5258		.5316	.5609
3	.5258			.5258		.5316	.5609
4	.567		.5316	.5258		.567	.5609
5	.6379		.6089	.631		.6447	.5959
6	.7087		.6805	.7202		.7164	.7011
7	.7442		.7964	.7011		.7964	.8063
8	.6733		.6447	.6661		.724	.7362
9	.6379		.6805	.631		.6447	.6733
10	.6447	.6805	.6733			.6241	.6805
11	.6805	.6805	.6733		.8688	.631	.788
12	.6089	.6805	.6733		.7602	.631	.788
13		.6805	.6661		.7602	.631	.7164
14		.6447	.6661		.7602	.6661	.7164
15	.6805	.6089	.7011		.7964	.7362	.7164
16	.7164	.7164	.7442		.7964	.7362	.7164
17	.7522	.6805	.7011		.7964	.7712	.7164
18	.7164	.724	.7442		.724	.8063	.6447
19	.8954	.905	.8764		.905	.8764	.9671
20	.9313	.9412	.9465		.9774	.9214	
21	.8596	.8326	.8764		.905	.8764	
22	.8238	.7964	.8063		.8779	.8764	
23	.7164	.724	.6935		.7602	.7712	
24	.6379		.6089	.631		.6805	.6661
Max	.9313	.9412	.9465	.7202	.9774	.9214	.9671
Min	.5258	.6089	.5316	.5258	.724	.5316	.5609
Avg	.6933	.7354	.6999	.6119	.8222	.7084	.6936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 402 / MARALI

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2035		.2172		.2103	.1829
10	.7202	.3189	.1943		.2812	.2058
11	.7202	.4252	.4115		.3155	.2058
12	.7202	.4252	.4161	.3189	.2915	.2058
13	.7202	.3155	.2915	.4252	.2881	
14	.7202	.3155	.2881	.3189	.2812	.2058
15	.7202	.3155	.2915	.7362	.2812	.2058
16		.2172	.1715		.2778	
Max	.7202	.4252	.4161	.7362	.3155	.2058
Min	.2035	.2172	.1715	.3189	.2103	.1829
Avg	.6464	.3333	.2852	.4498	.2784	.2020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 201 / Rasati Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1473	.2355	.2393	.2405	.2492	.2355	.1555
2	.1435	.2255	.2302	.2309	.2043	.2325	.1493
3	.1296	.189	.1936	.1928	.1997	.226	.1433
4	.1339	.1837	.1913	.1893	.1909	.2275	.1398
5	.1414	.1871	.1894	.1982	.1848	.2237	.1417
6	.1663	.2584	.2889	.3231	.2694	.2706	.1838
7	.2609	.4325	.4531	.4778	.4938	.4755	.2551
8	.3116	.4721	.4801	.4774	.4847	.3051	.3215
9	.3174	.4683	.5194	.3879	.4488	.2789	.321
10	.3259	.506	.498	.4233	.4428	.2923	.2854
11	.5727	.5064	.0351	.3673	.2458	.2773	.2694
12	.5468	.4729	.3806		.4508	.2773	.2709
13	.3422	.4557	.3894		.4957	.2662	.2598
14	.3673	.4599	.3757		.3734	.2678	.2608
15	.407	.4565	.4649		.3727	.271	.2749
16	.4786	.4587	.2987	.1581	.4008	.2923	.2969
17	.485	.5323	.6413	.53	.5011	.3772	.3821
18	.4439	.3825	.634	.6627	.5555	.3687	.3451
19	.4992	.5842	.6268	.7163	.6043	.3975	.3579
20	.6626	.7644	.6264	.6764	.6794	.4597	.4623
21	.6074	.6531	.5814	.6203	.6215	.4035	.4484
22	.4816	.5479	.4931	.5247	.4923	.3045	.3853
23	.3894	.4008	.3974	.3376	.3872	.253	.3101
24	.1707	.269	.2995	.2908	.2679	.3189	.2025
Max	.6626	.7644	.6413	.7163	.6794	.4755	.4623
Min	.1296	.1837	.0351	.1581	.1848	.2237	.1398
Avg	.3555	.4209	.3970	.4013	.4007	.3043	.2760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 202 / KOYANA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1796	.2393	.2443	.2732	.2355	.2332	.2168
2	.1791	.2336	.2359	.2367	.2332	.2248	.2149
3	.1819	.2332	.2442	.2347	.2287	.2233	.206
4	.183	.2363	.2419	.2313	.2267	.2244	.1979
5	.183	.2946	.2477	.2324	.2221	.2203	.1882
6	.1991	.3563	.3026	.3125	.3193	.3124	.201
7	.2391	.4683	.3887	.3868	.442	.399	.298
8	.2521	.4382	.4458	.4497	.3906	.2584	.2962
9	.1998	.3769	.4344	.3955	.3951	.2316	.2461
10	.1821	.3307	.3506	.365	.3788	.2256	.2511
11	.3628	.301	.3387	.3601	.226	.1877	.2248
12	.3806	.319	.3871		.4017	.1946	.221
13	.3384	.3563	.3068		.3255	.2166	.2444
14	.3513	.3715	.29		.3486	.196	.2524
15	.3204	.3189	.3227		.3071	.1895	.2206
16	.3665	.3887	.2202	.1947	.3749	.2769	.2629
17	.5536	.4854	.4691	.4881	.5392	.4329	.3577
18	.5026	.4729	.4919	.5777	.6276	.378	.4134
19	.5868	.5212	.6101	.5994	.5979	.3932	.3967
20	.1033	.6421	.7236	.7232	.7171	.4644	.4619
21	.5951	.6013	.6245	.6329	.674	.426	.4619
22	.5357	.5292	.5231	.5331	.5487	.3909	.4148
23	.3871	.3478	.3552	.3475	.4279	.3273	.3584
24	.169	.2595	.2903	.3018	.3132	.4225	.3057
Max	.5951	.6421	.7236	.7232	.7171	.4644	.4619
Min	.1033	.2332	.2202	.1947	.2221	.1877	.1882
Avg	.3138	.3801	.3787	.3938	.3959	.2937	.2880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 203 / Rasati Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5007	.7903					.3395
2	.4896	.7918		.0278			.3823
3	.4915	.7712		.0385			.4315
4	.4678	.7888		.0389			.4475
5	.4763	.7975		.0385			.4499
6	.5348	.9267		.0076			.5046
7	.7048	1.054		.0137			.6229
8	.7242	1.1595		.0072	.0122		.6322
9	.5106	.4813	.8684	1.0825	1.1984	.5407	.4256
10			1.1739	1.2955	1.6107	.7472	
11			1.4186	1.414	.5003	.7731	
12		.0004	1.3447	.735	1.5779	.788	
13			1.2956		1.5177	.7628	
14			1.3158		1.5535	.7373	
15	.0008		1.4404		1.5364	.7308	.0004
16			1.3977		1.4597	.7529	
17			.6017	.0545	.6714	.5182	
18			.0358	.0755	.0179	.0004	
19			.0396	.0145	.0389		.0004
20			.0469	.0781	.0057	.0042	.0179
21			.045	.0774			
22			.0446	.0758			
23	.7777		.0335	.0328		.0111	.005
24	.4815	.3688				.0057	.0027
Max	.7777	1.1595	1.4404	1.414	1.6107	.788	.6322
Min	.0008	.0004	.0335	.0072	.0057	.0004	.0004
Avg	.5134	.7209	.7401	.2838	.9001	.4902	.3045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 201 / CHAFAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1524	.1372	.1334	.1372	.1029	.1543
2	.12	.1524	.1372	.1334	.12	.1029	.1543
3	.12	.1524	.1372	.1334	.12	.1029	.1543
4	.12	.1524	.1372	.1334	.1029	.1029	.1543
5	.12	.1524	.1372	.1524	.1029	.1029	.1543
6	.1372	.1715	.1715	.1524	.1029	.1029	.1543
7	.1715	.1905	.1715	.1905	.12	.1029	.1715
8	.1715	.1905	.1715		.1543	.1029	.1715
9	.1543	.1905	.1905	.1715	.1715	.1029	.1715
10	.1715	.2058	.1905	.1715	.1715	.1029	.1715
11	.1715	.2058	.1905	.1543	.1372	.1029	.1905
12	.1715	.2058	.1715	.1543	.1715	.2058	.1905
13	.1715	.2058	.1715	.1715	.1715	.1886	.1905
14	.1715	.2058	.1715		.1715	.1886	.1905
15	.1715	.2058	.1715	.1372	.1715	.2058	.1905
16	.1715	.2058	.1715	.1543	.1715	.2058	.1905
17	.1905	.2058	.1715	.1543	.1715	.2058	.1905
18	.2096	.2058	.1905	.1543	.1715	.2058	.1905
19	.2667	.2058	.2477	.1543	.2401	.2229	.2286
20	.2858	.2401	.2667	.2229	.2401	.2743	.2477
21	.2477	.2401	.2096	.2058		.2229	.2286
22	.2286	.2401	.2096	.1886	.1715	.2229	.2286
23	.1905	.1715	.1715	.1543	.1715	.1886	.1905
24	.1372	.1524	.1715	.1524	.1372	.1715	.1715
Max	.2858	.2401	.2667	.2229	.2401	.2743	.2477
Min	.12	.1524	.1372	.1334	.1029	.1029	.1543
Avg	.1747	.1920	.1778	.1605	.1566	.1601	.1846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 202 / MASUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9907	.8573	1.105	.8916	.8573	.9259
2	.8573	.9907	.8573	1.105	.8916	.8573	.9259
3	.8573	.9907	.8573	1.105	.8916	.8573	.9259
4	.8573	.9907	.8573	1.105	.8916	.8573	.9259
5	.8573	.9907	1.0288	1.0288	.8916	.9431	.9602
6	.9602	1.0669	1.0288	1.1431	.9945	1.0288	1.0288
7	1.0288	1.1431	1.1145	1.2193	1.0288	1.1145	1.0288
8	.9602	1.0669	.9431	1.0288	.9602	1.0288	.9259
9	.8916	1.1431	1.0669	.9259	.9259	1.0288	.9259
10	.9945	1.0974	1.0669	.9602	.9431	1.0288	1.0288
11	1.0288	1.0288	1.0669	.9602	.9431	1.0288	1.1431
12	1.0288	1.0288	1.0669	1.1145	1.0288	.9602	1.1431
13	.9907	1.0288	1.0669	1.2003	1.0288	1.0288	1.1431
14	.9526	1.0288	1.0288		1.0288	1.0288	1.1812
15	.9526	1.0288	1.1431	1.0288	1.0288	1.0631	1.1431
16	.9526	1.0288	1.1431	1.0631	1.0288	1.0288	1.0669
17	.7621	1.0288	1.1812	1.0288	1.0288	1.0631	1.1812
18	1.105	1.1145	1.2193	1.0288	1.2003	1.1317	1.2193
19	1.5242	1.2003	1.5242	1.2346	1.286	1.3717	1.448
20	1.5623	1.3717	1.5242	1.3717	1.286	1.4403	1.5242
21	1.448	1.3717	1.3336	1.3032	1.286	1.3717	1.5242
22	1.1812	1.2003	1.3336	1.2003	1.286	1.2689	1.448
23	1.0669	1.2003	1.1431	1.0974	1.0288	1.2003	1.3336
24	.9602	1.0288	1.0288	1.105	.9602	.9431	1.0288
Max	1.5623	1.3717	1.5242	1.3717	1.286	1.4403	1.5242
Min	.7621	.9907	.8573	.9259	.8916	.8573	.9259
Avg	1.0266	1.0900	1.1034	1.1071	1.0317	1.0638	1.1304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 203 / PAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9204	1.9814	1.286	1.5242	1.3375	1.7147	1.9719
2	1.9204	1.9814	1.286	1.5242	1.3375	1.7147	1.8861
3	1.9204	1.9814	1.286	1.5242	1.3375	1.7147	1.8861
4	1.9204	1.9814	1.3717	1.5242	1.3375	1.7147	1.8861
5	1.9204	1.9814	1.5432	1.5242	1.3375	1.7147	1.8861
6	2.0576	2.0957	1.7147	1.829	1.4746	1.7147	2.1262
7	2.1262	2.21	1.7147	1.9052	1.7833	1.8861	2.1605
8	2.1262	2.1719	1.4575	1.7147	1.6804	2.0576	2.1605
9	1.9547	2.2862	2.8578	2.572	2.572	2.572	2.0576
10	2.0576	2.0919	2.8578	2.5377	2.572	2.7435	2.1262
11	2.2862	1.8861	2.8578	2.4348	2.572	2.6578	2.2862
12	2.0957	1.8861	2.8578	2.4348	2.4006	2.4348	2.21
13	2.0957	1.8861	2.8578	2.4348	2.3148	2.4006	2.1338
14	2.0957	1.8861	2.7435		2.2291	2.4006	2.0957
15	2.0957	1.8861	2.7435	2.2977	2.2291	.1029	2.0957
16	2.0957	1.8861	2.4768	2.2291	2.2291	2.1948	2.0195
17						2.0576	
18						2.0233	
19	.1905	.0686	.1143	.0857	.0514	.1029	.0953
20	.0953	.0686	.1143	.0857	.0514	.1029	.0953
21	.0953	.0686	.1143	.0857	.0514	.0857	.0953
22	.0953	.0686	.0953	.0686	.0514	.0686	.0953
23	2.0195	1.286	1.5623	1.4746	.0857		.0381
24	2.0233	1.9814	1.286	1.5242	1.4403	.0857	
Max	2.2862	2.2862	2.8578	2.572	2.572	2.7435	2.2862
Min	.0953	.0686	.0953	.0686	.0514	.0686	.0381
Avg	1.6913	1.6191	1.6909	1.5874	1.4762	1.5768	1.5908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 204 / PERLE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4954	.3429	.4954	.3772	.4287	.4115
2	.3429	.4954	.3429	.4954	.3772	.4287	.4115
3	.3429	.4954	.3429	.4954	.3772	.4287	.4115
4	.3429	.4954	.3429	.4954	.3772	.4287	.4115
5	.4115	.4954	.4287	.4954	.3772	.5144	.4801
6	.5144	.5716	.5144	.5716	.4801	.5144	.6173
7	.583	.6097	.5144	.6478	.5487	.6859	.6173
8	.5487	.6097	.5144	.5716	.5487	.5144	.5144
9	.4801	.4572	.4954	.4458	.3772	.5144	.4115
10	.4801		.4954	.4115	.3429	.4458	.3772
11	.4191	.4115	.4954	.4115	.3429	.4458	.4191
12	.4954	.4287	.4954	.4115	.3429	.4801	.4954
13	.4954	.4287	.4572	.4115	.3429	.4458	.4954
14	.4954	.4287	.4191		.3429	.4458	.4954
15	.4954	.4287	.381	.3772	.4287	.4458	.4954
16	.5335	.4801	.4191	.4115	.4287	.5144	.4954
17	.5335	.4287	.4191	.4115	.5144	.5144	.4954
18	.5716	.4287	.5335	.4458	.5144	.4801	.4954
19	.1524	.5144	.7621	.583	.6859	.6516	.5716
20	.7621	.6859	.7621	.7545	.6859	.7888	.7621
21	.724	.6859	.6859	.6516	.6859	.6859	.7621
22	.6097	.6001	.6478	.583	.6859	.583	.6859
23	.5335	.5144	.5335	.4801	.6001	.5144	.5716
24	.4115	.4954	.4287	.4954	.3772	.4287	.4115
Max	.7621	.6859	.7621	.7545	.6859	.7888	.7621
Min	.1524	.4115	.3429	.3772	.3429	.4287	.3772
Avg	.4842	.5080	.4906	.5023	.4651	.5137	.5131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 205 / VARADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.3336	.0857	.1334	.1372	.0686	1.3717
2	1.2003	1.3336	.0857	.1334	.12	.0686	1.3032
3	1.2003	1.3336	.0857	.1334	.12	.0686	1.3032
4	1.2003	1.3336	.0857	.1334	.12	.0686	1.3032
5	1.2003	1.3336	.0857	.1334	.12	.0686	1.3032
6	1.2346	1.5242	.0857	.1524	.1372	.0686	1.406
7	1.406	1.7147	.0857	.1905	.1372	.0686	1.6118
8	1.4403	1.7147	.0857	.1715	.12	.0686	1.5432
9	.0686	.1334	2.1338	2.0576	2.0919	2.0576	.1372
10	.0857	.1029	2.21	2.1262	2.1262	1.9719	.1372
11	.1334	.1029	2.21	1.9547	2.0576	1.8861	.1524
12	.1334	.1029	2.21	1.9547	2.0576	1.749	.1524
13	.1334	.1029	2.21	1.989	1.8861	1.6804	.1524
14	.1334	.1029	2.1338		1.8861	1.6804	.1715
15	.1334	.1029	2.0576	1.8176	1.8861	1.6804	.1524
16	.1334	.1029	2.0957	1.7833	1.8861	1.7147	.1524
17	.1143	.1029	.1524	.1543	.0686	.1372	.1715
18	.1143	.1029	.1905	.1543	.12	.1372	.1715
19	.1524		.2096	.1543	.0686	.1543	.1905
20	.1905	.1029	.1715	.1372	.0686	.1372	.1715
21	.1715	.1029	.1715	.1372	.0686	.1372	.1715
22	.1524	.1029	.1715	.1372	.0686	.1372	.1334
23	1.4098	.0857	.1524	.1372	.0686		
24	1.3375	1.3336	.0857	.1334	.1372	.0686	
Max	1.4403	1.7147	2.21	2.1262	2.1262	2.0576	1.6118
Min	.0686	.0857	.0857	.1334	.0686	.0686	.1334
Avg	.6117	.6265	.8022	.6961	.7316	.6904	.6074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 206 / CHAFAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1334	.6859	.8383	.6859	.0857	.12
2	.1029	.1334	.6859	.8383	.6859	1.0288	.12
3	.1029	.1334	.6859	.8383	.6859	1.0288	.12
4	.1029	.1334	.8573	.8383	.6859	1.0288	.12
5	.1029	.1334	1.0288	.8383	.6859	1.0288	.1372
6	.12	.1524	1.2003	1.1431	.9602	1.0288	.1372
7	.1715	.1715	1.2003	1.1431	1.3717	1.3717	.1715
8	.1372	.1524	1.0288	1.1431	1.0974	1.3717	.1543
9	1.4746	1.5242	.1143	.0857	.0686	.0857	1.406
10	1.5089	1.5432	.1143	.0857	.0686	.0514	1.4746
11	1.448	1.3717	.1143	.1029	.0686	.0514	1.5242
12	1.4861	1.2003	.1143	.1029	.0686		1.2955
13	1.4098	1.2003	.1143	.1029	.0686		1.2574
14	1.1431	1.0288	.1143		.0686		1.1431
15	1.105	1.0288	.1143	.1029	.0686	.12	1.105
16	1.1431	1.0288	.1143	.1029	.0686	.12	1.0669
17	.0953	.0686	.1334	.1029	.0686		.0953
18	.1334	.0686	.1524	.1372	.0686	.1372	.1334
19	.1715	.0686	.1524	.1543	.0686	.1372	.1524
20	.1715	.0686	.1524	.1372	.0686	.1543	.1524
21	.1524	.0686	.1334	.1372	.0686	.1543	.1334
22	.1524	.0686	.1143	.1372	.0686	.1543	.1334
23	.1524	.6859	.8764	.8916	.0857	.1372	.1334
24	.1029	.1334	.6859	.8383	.7888	.0857	.12
Max	1.5089	1.5432	1.2003	1.1431	1.3717	1.3717	1.5242
Min	.0953	.0686	.1143	.0857	.0686	.0514	.0953
Avg	.5331	.5125	.4453	.4714	.3622	.4681	.5169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 401 / UMESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4269	3.5238	3.2695		2.6529	2.0774	2.4022
2	3.4136	3.5089	3.2561		2.3124	2.2644	2.3772
3	3.3924	3.5528	3.4976		2.2143	2.5238	1.0917
4	3.3681	3.4839	3.7529		2.1057	2.5142	2.0482
5	4.3086	4.2356	4.0159		2.3083	2.6188	2.0499
6	4.3708	3.9972	4.0564		2.3723	2.6489	2.1152
7	4.3912	3.7058	4.0813		2.3795	2.6583	2.1192
8	4.3743	3.7198	4.0773		2.3654	2.6889	2.1115
9	4.423	3.6106	4.3539		2.7843	2.7351	2.1217
10	4.382	3.4813	4.2948		2.608	2.2408	2.4799
11	4.5658	4.0718	4.2754		2.2949	1.6595	2.6256
12	4.5424	4.071	4.2865		2.7527	1.4165	1.7635
13	4.1936	4.025	4.2562		2.7635	1.6164	1.7511
14	4.1901	4.0097	4.2274		2.7362	2.8608	1.7328
15	4.2617	4.0251	4.2459		2.8624	2.8392	1.7328
16	2.6809	2.4592	1.1521		2.4179	1.7623	1.4462
24	.5789	.6924		.3182	.0857	.2913	.1648
Max	4.5658	4.2356	4.3539	.3182	2.8624	2.8608	2.6256
Min	.5789	.6924	1.1521	.3182	.0857	.2913	.1648
Avg	3.8155	3.5396	3.8187	.3182	2.3539	2.2010	1.8902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 201 / shamgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995	.0183	3.5597	3.8182	3.9241	3.2533	.0171
2	.1002	.0179	3.4655	3.7824	2.0149	3.309	
3	.1002	.0179	3.5033	3.7082	3.8591	3.2815	.017
4	.1002	.0183	3.472	3.4644	3.8824	3.28	
5	.1033	.0183	3.4711	3.4629	3.8855	3.3456	
6	.1018	.0185	3.6828	3.4881	1.8976	3.4263	
7	.1	.0202	4.1377	3.6534	4.0878	4.2183	.0008
8	.0818	.0189	4.1529	3.7961	4.2761	4.3806	.0168
9	5.3864	5.4771	2.2106	1.9073	2.059	2.2605	2.6741
10	5.7091	5.8071	.0166	.0709	.0876	.0181	4.9377
11	5.5705	5.7659	.0156	.0915	.0808		5.1574
12	5.0568	5.6329	.0151	.0189	.0343		5.4797
13	5.0774	5.3094	.104	.0265	.0177		5.5834
14	5.0374	5.0655	.1086	.0288	.0181		5.6976
15	4.9093	4.8872	.1059	.0438	.0187		5.5121
16	2.7214	4.7995	.0838	.0185	.0183	.0187	5.2896
17	2.7709	2.6067	.0854		.0644		2.6321
18	.0278	.0776	.1084	.0197	.0995	.0183	.0189
19	.0233	.0517	.1019	.0974	.1018		.0179
20	.0574	.1065	.0861	.0846	.1052		.0181
21	.0189	.0193	.0869	.0838	.1039		.0183
22	.0179	.0452	.0861	.0854	.1069		.0179
23	.0183	3.7181	4.0049	2.7599	.6815		.0179
24	.0187	2.0795	3.6752	4.0236	1.8427	.0187	.0179
Max	5.7091	5.8071	4.1529	4.0236	4.2761	4.3806	5.6976
Min	.0179	.0179	.0151	.0185	.0177	.0181	.0008
Avg	1.8004	2.1499	1.6808	1.6754	1.3862	2.3715	2.1571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 202 / Helgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7476	2.4128	.1539	.0686	.0816	.0693	2.7641
2	2.6463	2.2473	.1494	.1456	.0579	.0709	1.1576
3	2.5548	2.1597	.1387	.1608	.0655	.0724	2.7317
4	2.471	2.1902	.1638	.1563	.1067	.0716	1.0463
5	2.5137	2.2005	.163	.1554	.1425	.0716	1.1538
6	2.6543	2.3685	.1334	.1364	.0107	.0724	1.3809
7	3.5352	3.4862	.1593	.1547	.0739	.0716	2.05
8	3.608	3.3478	.141	.1623	.1349	.0724	3.5829
9	1.1057	.9868	4.6142	4.2583	3.6484	4.1387	1.0555
10	.1768	.1417	4.8459	2.4059	2.444	4.6161	.1379
11	.1624	.1479	4.6655	4.1655	2.0043	4.2575	.1234
12	.1258	.1654	4.238	3.703	4.2936	3.6683	.1333
13	.1524	.1836	3.8554	3.4378	3.988	3.4646	.1395
14	.1532	.1837	3.5841	3.2695	3.597	3.2728	.1067
15	.1692	.1593	3.4238	3.0956	3.4371	1.7391	.1524
16	.1158	.1547	1.9532	2.9401	3.4846	3.3703	.1333
17	.1014	.1509	1.3877	1.0044	1.1797	1.2742	.1722
18	.1616	.1585	.1776	.1615	.1516	.1493	.1707
19	.1554	.1638	.1753	.1014	.1517	.1006	.1867
20	.1448	.163	.1075	.08	.1646	.1097	.1471
21	.1432	.1509	.109	.0937	.0724	.1021	.1532
22	.1417	.1349	.1036	.0884	.0732	.0937	.1563
23	2.6924	.1539	.157	.1158	.069	.1151	.1662
24	2.7537	1.2636	.0686	.109	.0625	.1906	.157
Max	3.608	3.4862	4.8459	4.2583	4.2936	4.6161	3.5829
Min	.1014	.1349	.0686	.0686	.0107	.0693	.1067
Avg	1.2994	1.0365	1.4445	1.2571	1.2290	1.3015	.7983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 203 / KONEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0964	.0972	3.1017	3.5227	3.091	3.1889	.1677
2	.104	.0972	3.0495	1.768	1.6918	3.1246	.1067
3	.104	.0968	3.0419	3.4903	3.2198	3.1291	.1692
4	.1044	.0972	3.0026	3.5223	1.6842	3.1695	.1067
5	.1048	.098	3.1573	3.5671	3.2838	3.2122	.1067
6	.1638	.1204	3.2998	3.6199	1.8214	3.2773	.1296
7	.1715	.1577	3.7761	3.6755	3.738	3.7321	.1296
8	.1661	.1658	3.8134	3.9323	3.7974	3.906	.2372
9	4.7691	4.7575	1.9879	1.8358	1.8244	2.1155	.16
10	5.066	5.2644	.1253	.1067	.0914	.2738	.0229
11	5.0549	5.1033	.1105	.1307	.0914	.16	
12	4.887	4.9002	.1288	.1324	.133		5.2241
13	4.6944	4.8902	.0914	.1282	.1347		5.4508
14	4.5026	4.4555	.1052	.1113	.176		5.5258
15	4.5413	4.26	.0762	.1029	.1459	.1448	5.5296
16	2.431	4.1223	.061	.0762	.1631	.2931	5.173
17	2.2253	2.0683	.0762	.0991	.1206	.1448	2.5882
18	.1639	.1494	.18	.1745	.1014	.2639	.1817
19	.1048	.1345	.1991	.1669	.0949	.16	.0998
20	.1261	.1132	.1143	.0914	.0972	.1524	.0915
21	.1185	.1204	.0914	.0991	.0945	.1296	.1738
22	.1128	.1124	.0914	.0762	.1662	.1296	.1814
23	.112	3.2937	3.2823	2.1255	.4554	.1296	.1662
24	.0887	1.8195	3.3951	3.5593	1.646	.1357	.1675
Max	5.066	5.2644	3.8134	3.9323	3.7974	3.906	5.5296
Min	.0887	.0968	.061	.0762	.0914	.1296	.0229
Avg	1.6672	1.9373	1.5149	1.5048	1.1610	1.4749	1.3865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 204 / Shahapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0154	.0135					.0139
2	.0154	.0137					
3	.0156	.0133					.0139
4	.0156	.0133					
5	.0156	.0137					
6	.0156	.0133					
7	.0149	.0135					
8	.0164	.0137					.0164
9			.0137	.0137	.0145	.0135	
10			.0147			.0143	
11			.0141	.0135		.0137	
12			.0143	.0133	.0152	.0137	
13				.0141	.0147	.0137	
14			.0141	.0139	.0145	.0137	
15				.0139	.0131		
16					.0336	.0151	
23	.0133						
24	.0154	.0135					
Max	.0164	.0137	.0147	.0141	.0336	.0151	.0164
Min	.0133	.0133	.0137	.0133	.0131	.0135	.0139
Avg	.0153	.0135	.0142	.0137	.0176	.0140	.0147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 205 / MASUR VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0452	1.0955	1.118	.9603	.9827	1.2235	1.0075
2	1.0227	1.0082	1.0444	.5293	.5456	1.1107	.5396
3	1.0151	.9968	.9941	.9347	.9431	1.0578	.9061
4	1.0052	.9835	.9789	.9218	.9317	1.0475	.5213
5	1.0082	.9796	1.0242	.9541	.9557	1.0497	.5426
6	1.116	1.0848	1.117	1.057	.5735	1.1538	.6413
7	1.1774	1.1488	1.1835	1.1618	1.1793	1.2578	.6428
8	1.1008	1.1603	1.1477	1.1145	1.1207	1.3085	1.2517
9	1.089	1.1393	1.2624	1.0928	1.1443	1.1963	.6108
10	1.1009	1.0943	1.1092	.5373	.5731	1.1511	1.1801
11	1.0818	1.1626	1.1058	.1905	.5476	1.1972	1.1237
12	1.0707	1.2056	1.2136		1.3017	1.2056	1.0242
13	.9591	1.1667	1.1115		1.2613	1.1881	1.1641
14	.9282	1.1995	1.1584		1.262	1.2254	1.2266
15	1.1389	1.2216	.6371		1.2914	.612	1.1862
16	.6283	1.2125	.6588		1.2872	1.1953	1.2879
17	.6055	1.2087	.6542	.7133	1.2224	.6386	1.3896
18	1.3568	1.2834	1.4998	1.3912	1.4659	1.3359	1.3576
19	1.3637	1.443	1.616	1.5417	1.6153	.8364	1.6358
20	1.6221	1.5966	.8821	.9156	1.5333	.9271	1.7543
21	1.5086	1.4849	.8371	.8482	1.6785	.8897	1.5574
22	1.3737	1.5284	.7983	.8086	1.5912	.8592	1.5359
23	1.3897	1.3394	1.3893	1.4392	1.5415	.7651	1.4245
24	1.1648	1.2247	1.2049	1.1484	1.1923	1.3245	1.2647
Max	1.6221	1.5966	1.616	1.5417	1.6785	1.3359	1.7543
Min	.6055	.9796	.6371	.1905	.5456	.612	.5213
Avg	1.1197	1.2070	1.0728	.9611	1.1559	1.0732	1.1157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 206 / Kalgaon Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.394	.439	.3429	.439	.4508	.3048
2	.362	.362	.3696			.4298	
3	.362	.3658	.3734	.3429	.3506	.3429	.2629
4	.3658	.3696	.3658	.3544		.3467	
5	.3658	.3696	.3658	.3696	.4161	.3582	
6	.3658	.3982	.3982	.3658		.362	
7	.394	.3429	.4115	.362	.4298	.3647	
8	.3814	.373	.3688	.3605	.5373	.4024	.3605
9	.3479	.3521	.3163	.3437	.4115	.3163	
10	.3239	.3437	.3277			.3239	.3395
11	.3163	.3185	.3353	.3384		.3395	.3841
12	.3437	.4359	.3437	.3311	.3647	.3841	.3277
13	.3384	.3567		.5258	.373	.421	.3688
14	.3612	.426	.421	.4744	.373	.3688	.373
15	.3563	.3353		.567	.3429		.3429
16		.3277			.373	.4298	.3688
17		.3772			.3521		.373
18	.3437	.3704	.3704	.4694	.3201	.3856	.3227
19	.5068	.4458	.4801	.7011	.4428		.3978
20	.6089	.5731			.5959		.6089
21	.5792	.5487			.6154		.6154
22	.5144	.5487			.5792		.5609
23	.4755	.5068	.4748	.7468	.5365		.5068
24	.4298	.4344	.4656	.362	.3429	.4973	.4706
Max	.6089	.5731	.4801	.7468	.6154	.4973	.6154
Min	.3163	.3185	.3163	.3311	.3201	.3163	.2629
Avg	.4002	.4032	.3898	.4328	.4314	.3838	.4050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 207 / Satyam Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0693	.0995	.0343	.0343	.0358	.0377
2	.0183	.0701	.0648			.0358	
3	.0187	.0701	.0671	.0343	.0328	.0351	.0189
4	.0187	.0857	.0655	.0173		.0343	
5	.0187	.0867	.0829	.0173	.0332	.0347	
6	.0187	.0857	.1006	.0177		.0351	
7	.0183	.0848	.1341	.0177	.0343	.0339	
8	.0183		.1492	.0366	.0347	.0347	.0332
9	.0185	.0829	.1463	.037	.0332	.0343	
10	.0747	.0358	.0754			.0343	.0354
11	.0063	.0671	.0739	.0183		.0335	.4763
12	.0168	.0678	.037	.0189	.0067	.0678	.2858
13	.017	.0166	.0191	.0187	.0065	.0347	.1017
14	.0175	.0332	.0381	.0191	.0067	.0343	.1143
15	.0686	.0339		.2263	.0065		.0905
16		.0693		.4382	.0061	.0343	.0762
17		.0709			.007		.0724
18	.0335	.0686	.0366	.3688		.0566	.0754
19	.0686	.1494	.0602	.0373	.0122		.1478
20	.0633	.1463			.0133		.056
21	.0732	.1448			.013		.037
22	.0743	.1357			.0335		.0532
23	.0714	.1372	.0377	.0328	.0332		.0537
24	.0183	.0705	.1357	.0526	.0332	.0335	.0343
Max	.0747	.1494	.1492	.4382	.0347	.0678	.4763
Min	.0063	.0166	.0191	.0173	.0061	.0335	.0189
Avg	.035	.0818	.0791	.0802	.0211	.0378	.1

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 208 / kharade ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	2.0553	.0663	.061	.0686	.0772	1.5851
2	1.9113	1.9662	.064			.0762	
3	1.9113	1.9662	.061	.0663	.0716	.061	1.7394
4	1.8896	1.9433	.061	.0655		.061	
5	1.8896	2.0119	.0617	.0663	.0754	.0457	
6	1.8896	2.0222	.0648	.0655		.0457	
7	2.3472	2.2939	.0587	.0663	.0693	.0617	
8	2.2801	2.1052	.0594	.0602	.0716	.061	2.1879
9	.0602	.096	2.9165	2.7831	2.8826	2.5857	
10	.0686	.1017	3.0864			3.0864	
11	.0457	.0511	3.2236	2.6825		2.9504	
12	.0579	.0488	2.8826	2.652	2.8487	2.8826	
13	.0457	.1017		2.6155	2.9165	2.8147	
14	.08	.1029	1.8785	2.6452	2.7808	2.6113	
15	.0533	.08		2.5434	2.713		.0686
16		.088			2.6155	2.3644	.0511
17		.0633			.0518		.0259
18	.0705	.0772	.0572	.0572	.0995	.0602	.0995
19	.0829	.061	.064	.0579	.0983		.0972
20	.0678	.061			.0983		.096
21	.1006	.0617			.0829		.0937
22	.0829	.061			.0905		.0823
23	1.9509	.0655	.0724	.0594	.1075		.0663
24	2.079	1.9444	.0648	.0633	.0739	.1075	.0671
Max	2.3472	2.2939	3.2236	2.7831	2.9165	3.0864	2.1879
Min	.0457	.0488	.0572	.0572	.0518	.0457	.0259
Avg	.9535	.8096	.8672	.9771	.9377	1.1737	.4815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 201 / BAMBAWADE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.5944	.5464	.5601	.5243	.535	.5647
2	.5418	.5639	.5358	.5464	.5091	.5161	.554
3	.5396	.5632	.5152	.538	.5053	.5083	.5525
4	.535	.5768	.5038	.5243	.5015	.535	.5952
5	.6127	.6196	.5884	.5304	.5883	.5852	.6813
6	.7461	.7316	.7773	.6379	.7134	.7072	.8535
7	.9404	.9206	.9847	.9343	.9305	1.0379	.961
8	1.0258	.9869	.996	.9152	.8223	1.0319	.9031
9	.9359	.9755	.8917	.8185	.7712	.9671	.8711
10	.8611	.9137	.9282	.4641	.7499	.9739	.8437
11	.7705	.852	.8215	.8337		.945	.6801
12	.772	.7934	.7819	.7713	.4123	.9138	.362
13	.7758	.7659	.8078	.7362	.7575	.9153	.7123
14	.7515	.7682	.7019	.6912	.7842	.7972	.7958
15	.737	.7621	.6988	.7484	.7377	.7834	.7821
16	.7499	.7895	.3582	.8238	.7247	.8711	.763
17	.7385	.8856	.7377	.8764	.7423	.8565	.7509
18	.7646	.9091	.9701	.8604	.8413	.9953	.7659
19	1.0463	1.0929	1.1782	.9869	.9915	1.2063	.9079
20	1.3244	1.4152	1.4586	1.2239	1.3939	1.5104	1.3067
21	1.2872	1.3618	1.3999	1.2125	1.275	1.4243	1.1837
22	1.1973	1.2285	1.1484	1.0532	1.1591	1.2208	1.1387
23	.9099	.7986	.8414	.7506	.8718	.8818	.8292
24	.6515	.6348	.6386	.5708	.6119	.6409	.6416
Max	1.3244	1.4152	1.4586	1.2239	1.3939	1.5104	1.3067
Min	.535	.5632	.3582	.4641	.4123	.5083	.362
Avg	.8242	.8543	.8254	.7754	.7791	.8900	.7917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 202 / TARALE -VG-

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2279	.2279	.2835	.2507	.2279	.2835	.2507
2	.2103	.2279	.2481	.2328	.2103	.2481	.2507
3	.2103	.2279	.2481	.2328	.2103	.2481	.2507
4	.2454	.2454	.2481	.2507	.2454	.2481	.2686
5	.2804	.2804	.2481	.2686	.2804	.2835	.2865
6	.3506	.3155	.2835	.3045	.3506	.3544	.3224
7	.3856	.3856	.3681	.3761	.3506	.3856	.3582
8	.3506	.3506	.3506	.3224	.3506	.3506	.3045
9	.3506	.3155	.2835	.2686	.2804	.3155	.3045
10	.3506	.3155	.3155		.3155	.3506	.3189
11	.3155	.3012	.3155	.2126		.333	.2835
12	.3155	.3012	.3155	.2835		.333	
13	.3155	.3012	.3155	.2835	.2835	.3155	.2835
14	.333	.3224	.3155	.2835	.2686	.3506	.3544
15	.3506	.2686	.3155	.2835	.3012	.3506	.3544
16	.3506	.3045		.2835	.2804	.3506	.3189
17	.3506	.3721	.333	.3155	.3189	.3544	.3189
18	.3898	.3721	.3582	.3155	.3544	.3898	.3189
19	.3856	.4207	.3761	.3506	.4031	.3721	.3898
20	.4252	.4557	.3856	.3856	.4557	.4252	.4607
21	.3856	.4207	.394	.3856	.4207	.3898	.4252
22	.3856	.3856	.3582	.3856	.3856	.3189	.4252
23	.3155	.3544	.3224	.3155	.3544	.298	.3898
24	.2454	.2454	.2835	.2629	.2454	.2835	.2658
Max	.4252	.4557	.394	.3856	.4557	.4252	.4607
Min	.2103	.2279	.2481	.2126	.2103	.2481	.2507
Avg	.3261	.3216	.3159	.2980	.3134	.3305	.3263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 203 / DUSALE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0701	.0709	.0716	.0701	.1063	.0716
2	.0701	.0701	.0709	.0716	.0701	.1063	.0716
3	.0701	.0701	.0709	.0716	.0701	.1063	.0716
4	.0701	.0701	.0709	.0716	.0701	.1063	.0716
5	.0701	.0701	.0709	.0895	.0701	.1063	.0716
6	.0876	.0701	.0709	.0895	.0876	.1052	.0895
7	.0876	.0701	.1052	.1254	.0701	.1402	.1254
8	.0701	.0701	.1052	.1254	.0701	.1052	.1433
9	.0701	.0701	.1063	.1075	.0701	.1052	.1433
10	.0701	.0876	.0701		.1402	.1052	.1417
11	.0701	.1063	.0701	.1063		.1052	.1417
12	.0701	.0709	.0701	.1063		.1052	
13	.0701	.0709	.0701	.1063	.0709	.1052	.1063
14	.0701	.0895	.0701	.1063	.1075	.1052	.1417
15	.0701	.0716	.0701	.1063	.0886	.1052	.1417
16	.0709	.0537		.1063	.1052	.0701	.0709
17	.0709	.0709	.0701	.0701	.1063	.1063	.1063
18	.0709		.1075	.0701	.1063	.1417	.1063
19	.0876	.1052	.1433	.0876	.1052	.1417	.1063
20	.1052	.1402	.1402	.0876	.1402	.1772	.1772
21	.1052	.1402	.1791	.0701	.1753	.1595	.1417
22	.1052	.1402	.1433	.0701	.1402	.1417	.1417
23	.0876	.1052	.1075	.0701	.1063	.1063	.1063
24	.0701	.0701	.0709	.0716	.0701	.1063	.0709
Max	.1052	.1402	.1791	.1254	.1753	.1772	.1772
Min	.0701	.0537	.0701	.0701	.0701	.0701	.0709
Avg	.0775	.0849	.0924	.0895	.0959	.1154	.1113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 204 / BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.954	3.1369	.0229	.0229	.0229	.0229	2.9165
2	2.954	3.0759	.0229	.0229	.0229	.0229	2.9443
3	3.0369	3.0302	.0229	.0229	.0229	.0229	2.9215
4	2.9235	2.9769	.0229	.0229	.0229	.0229	2.9138
5	2.8559	2.955	.0229	.0229	.0229	.0229	2.9698
6	3.0979	3.0331	.0229	.0229	.0229	.0229	3.1455
7	3.2921	3.4322	.0229	.0229	.0229	.0229	3.6479
8	3.4217	3.4827	.0229	.0229	.0229	.0229	3.4964
9	1.7909	1.768	3.8398	3.9525	3.6999	4.2394	1.7375
10	.0152	.0152	4.8211	2.431	4.4801	4.8041	.0152
11	.0152	.0305	4.8087	4.4323	1.3489	4.6556	.0152
12	.0152	.0305	4.7982	2.3472	2.21	4.5489	
13	.0229	.0305	4.6124	4.3156	4.1431	4.5511	
14	.0152	.0305	4.4868	4.1704	4.3313	4.4399	
15	.0229	.0305	4.3534	4.0581	4.2269	4.3865	.0152
16	.0152	.0229	2.2786	4.1511	4.1736	4.308	.0229
17	.0229	.0229	2.1872	2.1491	2.1795	2.2634	.0229
18	.0229	.0229	.0229	.0229	.0152	.0229	.0229
19	.0229	.0229	.0229	.0229	.0229	.0229	.0229
20	.0229	.0229	.0229	.0229	.0229	.0229	.0229
21	.0229	.0229	.0229	.0229	.0229	.0229	.0229
22	.0229	.0229	.0229	.0229	.0229	.0229	.0229
23	2.9778	.0229	.0229	.0229	.0229	.0229	.0229
24	3.1683	1.3994	.0229	.0229	.0229	.0229	.0229
Max	3.4217	3.4827	4.8211	4.4323	4.4801	4.8041	3.6479
Min	.0152	.0152	.0229	.0229	.0152	.0229	.0152
Avg	1.3638	1.1934	1.5221	1.3480	1.2970	1.6059	1.2831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 205 / TARALE -AG-

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.704	1.8399	1.4899	1.5402	
2			1.704	1.8399	1.4899	1.5565	
3			1.7204	1.8233	1.4899	1.5893	
4			1.7204	1.8233	1.4899	1.5893	
5			1.7368	1.8233	1.4899	1.6057	
6			1.7368	1.7901	1.7878	1.6057	
7			1.8515	1.9725	1.8461	1.6385	
8			1.917	1.9559	1.749	1.7532	
9	1.9433	1.9433					1.6907
10	2.1862	2.2211					1.7976
11	2.2024	2.3663					1.7328
12	2.1862	2.1548					
13	2.17	2.1216					1.8461
14	1.9433	2.2045					1.8785
15	2.1376	2.1879					1.8785
16	2.1052	2.0885					2.0243
23		1.6549	1.5581	1.4575			
24			1.704	1.7404	1.4899		
Max	2.2024	2.3663	1.917	1.9725	1.8461	1.7532	2.0243
Min	1.9433	1.6549	1.5581	1.4575	1.4899	1.5402	1.6907
Avg	2.1093	2.1048	1.7353	1.8066	1.5914	1.6098	1.8355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 201 / 11kv CHORE VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6878	.6516	.6447	.6878	.695	.7468	.7392
2	.6653	.6089	.6089	.6089	.6722	.695	.7023
3	.5544	.6154	.5959	.6447		.6584	.6584
4	.5544	.695	.6805	.7164	.7468	.6653	.7023
5	.5914	.724	.7522	.7522		.7316	.8413
6	.7316	.7522	.8145	.7964	.8779	.7468	.8871
7	.924	.8596	.8238	.7522	.9877	.8215	.8413
8	.8131	.8238	.788	.7164	.7682	.8589	.6584
9	.8131	.9313	.3258	.7164	.724	.7964	.695
10	.7762	.7164	.2926			.9774	.7316
11	.788	.6859	.788	.6859		.8131	.7545
12	.7602	.6516	.8954	.6173		.7762	.7545
13	.7682	.6516	.9412	.583	.9877	.8413	.7545
14	.7964	.6173	.8326	.5487	.9709	.7682	.7716
15	.7682	.6661	.8779	.5144	.9145	.9145	.7716
16	.9774	.6516		.5144	.9568	.8779	.7888
17	.8954	.6859	.8779	.6516	.9335	.924	.823
18	.8326	.6935	.8596	.9602	1.0456	.9979	.9259
19	1.1222	.9259	1.086	1.0631	1.0829	1.0719	.9602
20	1.1462	1.1222	1.1462	1.0288	1.1203	1.0719	.9602
21	1.0242	.9816	1.0745	1.0117	1.094	1.0719	.9602
22	.9979	.9114	.9313	.9945	1.0082	1.0719	.8916
23	.8596	.8238	.8048	.8573	.5658	.7762	.7888
24	.7762	.6805	.6516	.7164	.7842	.7545	.7392
Max	1.1462	1.1222	1.1462	1.0631	1.1203	1.0719	.9602
Min	.5544	.6089	.2926	.5144	.5658	.6584	.6584
Avg	.8177	.7553	.7867	.7452	.8914	.8512	.7959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 202 / 11kv VADGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0366	2.1849	1.7394	1.9006	1.7528	.0324
2	.0328	.037	2.1491	1.656	1.8122	1.7695	.0324
3	.0324	.0373	2.1132	1.6129	1.9109	1.8023	.032
4	.0324	.0373	2.0774	1.6644	1.9433	2.2939	.032
5	.0324	.037	2.1491	1.6964	1.9433	1.749	.0324
6	.0324	.037	2.0774	1.6872	1.9433	1.7814	.0324
7	.0324	.037	2.3282	1.8976	1.9662	1.9109	.0324
8	.0324	.037	2.364	1.9685	1.9989	1.9433	.0324
9	2.2996	2.4985	.0732	.0366	.0354	.0362	2.0405
10	2.4939	2.372	.0724		.0351	.0324	2.5034
11	2.372	2.758	.0732	.037		.0324	2.5034
12	1.3123	2.7938	.0739	.0358			
13	1.2651	2.6863	.0373	.0358	.0362		2.3148
14	2.0873	2.5339	.0362	.0358	.0354		2.3148
15	2.0934	2.4253	.037	.0358	.0362	.0324	2.2977
16	2.1559	2.3282		.0358	.0351	.0324	2.3148
17	.0366	.0716	.0366	.0716		.0324	3.1722
18	.037	.0724	.037	.0716	.0366	.0324	.0686
19	.0366	.0716	.0366	.0716	.0347	.0324	.0686
20	.037	.0716	.0739	.0686	.0354	.0324	.0686
21	.0366	.0716	.0732	.0716	.0351	.0324	.0686
22	.037	.0724	.0366	.0716	.0373	.0324	.0686
23	.0366	2.1719	1.656	1.8861	.0351	.0324	.0686
24	.0324	.0366	2.2805	1.8343	1.781	.0373	.0324
Max	2.4939	2.7938	2.364	1.9685	1.9989	2.2939	3.1722
Min	.0324	.0366	.0362	.0358	.0347	.0324	.032
Avg	.6929	.9722	.9599	.7966	.8394	.7349	.8767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 203 / 11kv SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0729	1.9372	.0724	.1097	.0732	.1052	1.9433
2	2.0405	1.7394	.0716	.0739	.0732	.1063	1.9204
3	1.9109	1.6762					1.9109
4	1.9334	1.6872					1.9109
5	1.8461	1.7604					1.8785
6	1.9109	1.7924					1.9109
7	2.2672	2.0873					2.4291
8	2.17	2.0557					2.2996
9			2.7831	2.5934	2.3967	2.7526	
10			2.8464		2.4291	2.5587	
11			2.7496	2.5934		2.5587	
12			2.6246	2.7435		2.2996	
13			2.5934	2.6063	2.5587	2.3967	
14			2.4352	2.572	2.556	2.2996	
15	.0732	.0686	2.3122	2.4006	2.5232	2.3266	
16	.1109	.0724		2.2291	2.332	2.3967	
17	.1109	.0686	.0739	.0686		.0648	
18	.112	.0724	.1097	.0686	.0709	.0648	
19	.1109	.0724	.1109		.1086	.0972	
20	.1478	.0724	.1097	.1029	.1063	.0972	
21	.1109	.0724	.1109	.1029	.1086	.0972	
22	.112	.0724	.1109	.1029	.112	.0972	
23	2.0557	.0716	.1097	.0686	.1086	.0972	.0686
24	2.13	2.0241	.0686	.112	.0747	.1086	.0972
Max	2.2672	2.0873	2.8464	2.7435	2.5587	2.7526	2.4291
Min	.0732	.0686	.0686	.0686	.0709	.0648	.0686
Avg	1.1792	.9668	1.1349	1.1593	1.0421	1.1403	1.6369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 201 / Charegaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1698	.8139	.8848	.9835	.8745	.0934
2	.1307	.1698	.8048	.8684	.9835	.8745	.0943
3	.1307	.168	.8383	.852	.9945	.8745	.0943
4	.1307	.168	.8288	.8192	.9945	.8916	.0934
5	.1494	.168	.8951	.8619	.9945	.9259	.112
6	.1867	.1867	.9614	.9339	1.0117	.9431	.1509
7	.2054	.1867	.9717	.9012	1.0562	1.1869	.2241
8	.2033	.1867	.8421	.9012	.9221	.9724	.1867
9	1.5238	1.3765	.2241	.1886	.1867	.2012	1.5939
10	1.5074	1.4419	.1509		.1867	.1867	1.3763
11	1.5384	1.2651	.1494	.2378			1.2018
12	1.4575	1.0722	.1494				1.1683
13	1.3108	.9442	.112	.2054	.1307		1.0242
14	1.0159	.8097	.112		.1494		.9878
15	.9717	.8192	.1132	.168	.1494	.1867	.9717
16	.8907	.7865	.1509	.168	.1494	.1886	.9393
17	.1867	.1867	.1509	.1307	.1494	.1867	.1886
18	.1867	.1867	.1698	.1867	.1494	.1867	.2075
19	.1698	.2241	.1698	.1886	.168	.2263	.2241
20	.2075	.2427	.1886	.1886	.2054	.2263	.2241
21	.2263	.2427	.1509	.1698	.2054	.1886	.1867
22	.2075	.2075	.1494	.168	.1867	.1494	.1867
23	.1886	.8848	.8907	1.0802	.168	.132	.1494
24	.132	.1698	.8478	.8907	1.0004	.1494	.112
Max	1.5384	1.4419	.9717	1.0802	1.0562	1.1869	1.5939
Min	.1307	.168	.112	.1307	.1307	.132	.0934
Avg	.5412	.511	.4515	.5235	.5057	.4876	.4913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 202 / charegaon vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.2561	.5487	.567	.5014	.4656	.4961
2	.5014	.2561	.5359	.5544	.4656	.4656	.4607
3	.5014	.2772	.543	.5175	.4656	.4656	.4607
4	.5014	.2772	.5853	.5121	.4656	.4557	.4908
5	.5014	.2772	.6219	.5544	.5194	.5258	.5609
6	.591	.2772	.6516	.7762	.6089	.5609	.6588
7	.6836	.3326	.7087	.724	.7545	.703	.7712
8	.703	.7602	.6485	.7421	.6687	.6516	.6935
9	.6104	.7316	.6089	.6516	.583	.5658	.6241
10	.57	.6335	.5792		.583	.6516	.4508
11	.5853	.591	.5792	.5596		.631	.6447
12	.5611	.6516	.5853			.6379	.6154
13	.567	.6036	.5121	.5434	.4801	.5548	.5487
14	.567	.5487	.4887		.4748	.5895	.5729
15	.5853	.5853	.543	.4973	.5533	.6516	.543
16	.5853	.6516	.6219	.5426	.5658	.6588	.6154
17	.6283	.6878	.7316	.4973	.6613	.6516	.5611
18	.6653	.6984	.7682	.5258	.6613	.6661	.6447
19	.7682	.8682	.7865	.7362	.8238	.8505	.8505
20	.9145	1.0341	.961	.929	.9816	1.0517	.9465
21	.9979	.9816	1.0534	.8413	1.0242	1.0166	.9816
22	.8779	.7796	.823	.788	.8145	.9015	.8063
23	.3326	.7087	.7392	.5731	.6516	.6661	.7164
24	.5373	.2561	.543	.5914	.4908	.5258	.5258
Max	.9979	1.0341	1.0534	.929	1.0242	1.0517	.9816
Min	.3326	.2561	.4887	.4973	.4656	.4557	.4508
Avg	.6197	.5719	.6570	.6297	.6272	.6485	.6350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 203 / Mazgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083	1.5074	.0377	.0373	.0377	.0377	1.1469
2	1.3748	1.491	.0377	.0373	.0377	.0377	1.2346
3	1.3904	1.491	.0377	.0377	.0377	.0377	1.2597
4	1.3717	1.326	.0377	.0377	.0377	.0377	1.3226
5	1.3032	1.326	.0377	.0377	.0377	.0377	1.3226
6	1.2003	1.2944	.0377	.0377	.0377	.0377	1.3592
7	1.5261	1.5565	.0566	.0377	.0377	.0377	1.4746
8	1.4255	1.5893	.0377	.0377	.0377	.0377	1.4586
9	.0373	.0377	2.0778	1.7814	2.1879	1.9281	.0377
10	.0373	.0377	2.0466		2.1548	2.0056	.0377
11	.0377	.0377	2.1052	1.9271		1.7924	.0377
12	.0377	.0377	2.2119				.0377
13	.0377	.0377	1.9662	1.6446	1.8623	1.8084	.0377
14	.0377	.0377	1.9334		1.8679	1.6385	.0377
15	.0377	.0377	1.9062	1.6385	1.6712	1.5684	.0377
16	.0377	.0377	1.8023	1.6194	1.5708	1.5364	.0566
17	.0377	.0377	.0373	.0377	.0377	.0377	.0566
18	.0373	.0377	.0373	.0377	.0377	.0377	.0566
19	.0373	.056	.0377	.0377	.0377	.0377	.056
20	.0377	.056	.0377	.0377	.0566	.0377	.0377
21	.0377	.056	.0377	.0377	.0377	.0377	.0373
22	.0377	.0377	.0373	.0377	.0377	.0377	.0373
23	1.5223	.0377	.0373	.0377	.0754	.0377	.0377
24	1.3443	1.5061	.0377	.0373	.0377	.0377	.0377
Max	1.5261	1.5893	2.2119	1.9271	2.1879	2.0056	1.4746
Min	.0373	.0377	.0373	.0373	.0377	.0377	.0373
Avg	.5997	.5712	.6946	.4387	.5443	.5600	.4690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 201 / Shahapur Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5144	.5144	.5144	.5144	.5716	.5525
2	.5335	.4954	.4954	.4954	.4954	.5525	.5335
3	.5335	.4954	.4954	.4763	.4954	.5716	.5144
4	.5716	.5335	.4763	.5144	.5144	.6287	.4763
5	.6097	.5906	.4191	.6287	.5335	.6668	.4763
6	.6478	.6859	.4001	.6668	.5716	.6602	.4572
7	.5847	.5788	.4338	.6036	.6413	.5415	.679
8	.5359	.5281	.3326		.5415		.5729
9	.5487	.5041	.6767	.6379	.5121	.6468	.591
10	.6036	.4887	.6859	.6602		.6722	.6602
11	.4755	.439	.5914	.5847		.6535	.5415
12	.499	.4706	.5544	.3403		.5175	.5847
13	.4344	.394	.4525	.2507	.4954	.5175	.5847
14	.499	.3077	.5847	.3258	.6859	.5975	.6036
15	.6036	.394	.5658	.3801	.6287	.6036	.6413
16	.6036	.4706	.5228		.5658	.6036	.6097
17	.5729	.4938	.6036	.3258	.5658	.5415	.5729
18	.4854	.5304	.5175	.5729		.6516	.5359
19	.6767	.7577	.7095	.679	.7095	.695	.7577
20	.8402	.8589	.9335	.8402	.924	.7762	.9149
21	.7733	.8029	.8215	.8002	.8589	.8962	.8573
22	.7621	.6602	.7167	.743	.7922	.7922	.8192
23	.6097	.5716	.6478	.6097	.6859	.6668	.6668
24	.5525	.5335	.5335	.5525	.5525	.6097	.5716
Max	.8402	.8589	.9335	.8402	.924	.8962	.9149
Min	.4344	.3077	.3326	.2507	.4954	.5175	.4572
Avg	.5871	.5458	.5702	.5547	.6142	.6363	.6156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 202 / Shahapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	1.0364	1.0648	1.25	1.1888	.0953
2	.0762	.0953	.9332	1.0155	1.2041	1.1584	.0953
3	.0762	.0953	.884	.9877	1.1288	1.142	.0953
4	.0762	.0953	.8905	1.0155	1.0837	1.1111	.0953
5	.0953	.0953	.9259	1.0911	1.1265	1.0936	.0953
6	.0953	.1143	1.0031	1.186	1.2018	1.1405	.0953
7	.1143	.1143	1.3123	1.3923	1.3443	1.3283	.1143
8	.0953	.1143	1.3117		1.3748	1.3279	.1143
9	1.866	1.6872	.0953	.0762	.0762	.1143	1.781
10	1.7924	1.7185	.0762	.0762		.1143	1.7764
11	1.9334	1.7078	.0953	.0953			1.8244
12	1.8842	1.6248	.0953	.0953			1.9334
13	1.7814	1.7236	.1334	.0953	.0762		1.9006
14	1.7124		.1143	.0953	.0762		1.8351
15	1.6248		.1143	.0953	.0762	.0762	1.7652
16	1.5466	1.4998	.1334		.0572	.0953	1.531
17	.1334	.0762	.1143	.0762	.0762	.0762	.0953
18	.1143	.1143	.1143	.0762	.0762	.0762	.1143
19	.1334	.1334	.1143	.0953	.0953	.0762	.1143
20	.1143	.1143	.1143	.0953	.1143	.0953	.1143
21	.1143	.1143	.1143	.0953	.1143	.0953	.1143
22	.1143	.1143	.1143	.0953	.0953	.0953	.1143
23	.1143	1.1279	1.1431	1.2498	.0762	.1143	.1143
24	.0953	.0953	1.0837	1.1584	1.2654	.0572	.0953
Max	1.9334	1.7236	1.3123	1.3923	1.3748	1.3283	1.9334
Min	.0762	.0762	.0762	.0762	.0572	.0572	.0953
Avg	.6583	.5760	.5028	.5147	.5709	.5288	.6677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 203 / Riswad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9804	.9804	.1143	.0953	.1143	.1143	.8278
2	.9217	.9414	.1143	.0953	.0953	.1143	.8078
3	.8642	.9259	.1143	.0762	.0953	.1143	.8025
4	.9374	.884	.1143	.0953	.0953	.1143	
5	.9922	.9602	.1143	.0953	.1143	.1334	.8025
6	1.0364	1.0322	.1143	.0953	.1143	.1334	.7676
7	1.668	1.5424	.1143	.1334	.0953	.1143	1.3108
8	1.3599	1.4419	.1334		.0762		1.1405
9	.0953	.1143	1.7029	1.6762	1.7695	.873	.0953
10	.0762	.1143	1.8724	1.7859		1.8351	.0953
11	.0762	.1143	1.8084	1.5708		1.6876	.1143
12	.0953	.1143	1.6004	1.1405		1.4251	.1143
13	.0953	.1143	1.4548	.9998	1.3916	1.2323	.1143
14	.0953	.0953	1.3763	.9877	1.2334	.9998	.1143
15	.0953	.0953	1.2163	.9877	1.1574	1.0031	.0953
16	.1334	.1143	1.2803		1.1883	1.1717	.1143
17	.1143	.1334	.1143	.1143	.0953	.1334	.1334
18	.1143	.1143	.0953	.1143	.1143	.1334	.1143
19	.1334	.1143	.0953	.1143	.1143	.1334	.0953
20	.1143	.1143	.0953	.0953	.1143	.1143	.1334
21	.1143	.1143	.1143	.1143	.1143	.1143	.1143
22	.1143	.1334	.1143	.1143	.1143	.1143	.1143
23	1.065	.1143	.0953	.1143	.1143	.1143	.0953
24	1.0562	1.0082	.1143	.0953	.1143	.1143	.1143
Max	1.668	1.5424	1.8724	1.7859	1.7695	1.8351	1.3108
Min	.0762	.0953	.0953	.0762	.0762	.1143	.0953
Avg	.5145	.4763	.5868	.4869	.4017	.5234	.3579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 301 / WING

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.439	.4344	.4854	.3662	.5175	.4108
2	.3696	.3658	.3982	.4481	.3658	.4805	.1791
3	.3361	.3658	.3982	.4481	.3658	.4854	.1494
4	.3326	.3658	.3982	.4108	.3982	.4481	.1867
5	.3696	.3292	.3982	.4481	.4108	.4481	.1867
6	.3326	.3292	.4344	.3734	.4435	.4481	.1867
7	.4481	.426	.5792	.4854	.5121	.4805	.1867
8	.4805	.5068	.5914	.4481	.5914	.5601	.1448
9	.5975	.6653	.6722	.5914	.7095	.6348	
10	.6348	.6283	.7842		.7468		
11	.6584	.7392	.7468				
12	.6089	.7023	.6722		.7316	.6283	
13	.6348	.6722	.6348		.6661	.6722	
14	.5975	.6283	.7468			.6722	
15	.6348	.7392	.6348			.5601	
16	.5975	.6283	.6722		.7316	.7468	
17	.6348	.5914	.6348			.7095	
18	.5975	.5914	.5975		.5914	.6722	
19	.5601	.6283	.6348		.5975	.6348	
20	.5975	.6283	.5601	.6348	.6283	.6722	
21	.5228	.5914	.5228	.5914	.6283	.6283	
22	.4854	.5175	.4854	.5175	.5175	.5228	
23	.439	.4066		.3696	.5175	.4481	.4481
24	.3696	.439	.4481	.4854	.3658	.5175	.4066
Max	.6584	.7392	.7842	.6348	.7468	.7468	.4481
Min	.3326	.3292	.3982	.3696	.3658	.4481	.1448
Avg	.5087	.5385	.5687	.4813	.5443	.5722	.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 302 / SHINDEWADI

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2195	.2172	.2241	.2561	.2587	.1867
2	.2241	.1829	.181	.1867	.2218	.2218	.1791
3	.1848	.1829	.181	.1867	.2218	.2241	.1867
4	.1867	.1829	.181	.1867	.2218	.2241	.1494
5	.2241	.1829	.2172	.1867	.2218	.2614	.1867
6	.2218	.2195	.2172	.1867	.2587	.2614	.2241
7	.2241	.1638	.2172	.1867	.2561	.2218	.1867
8	.2218	.2172	.2218	.1867	.2561	.2241	.181
9	.2241	.2218	.2241	.1829	.2241	.2241	.2241
10	.2614	.2218	.2241	.1829	.2241	.2241	.2241
11	.2561	.2587	.2241	.2218		.2241	.2241
12	.2507	.2587	.2241	.2218		.1848	.2241
13	.1494	.2587	.2241		.1753	.1867	.2241
14	.1494		.2241			.1867	.2241
15	.2614	.1867	.2241			.1867	.1867
16	.2241	.2218	.2241		.2195	.1867	.1867
17	.2241	.2218	.2241		.2241	.1494	
18	.2241	.1848	.2241		.2218	.1867	
19	.1867	.2241	.2614		.2614	.2614	
20	.2987	.2587	.2614	.2926	.2957	.2987	
21	.2241	.2587	.2614	.2587	.2957	.2587	
22	.2987	.2587	.2614	.2957	.2957	.2987	
23	.2195	.2218		.2587	.2957	.2241	.2241
24	.2218	.2195	.2172	.2241	.2561	.2587	.2218
Max	.2987	.2587	.2614	.2957	.2957	.2987	.2241
Min	.1494	.1638	.181	.1829	.1753	.1494	.1494
Avg	.2243	.2186	.2234	.2159	.2452	.2266	.2025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 303 / INDUSTRIAL

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6057	1.39	1.3394	1.8671	1.2803	1.7741	3.9209
2	1.5893	1.3169	1.3756	1.9791	1.3169	2.1658	2.0416
3	1.643	1.3169	1.3032	1.4937	1.2936	2.1658	3.5101
4	1.6057	1.0974	1.3394	1.6804	1.3169	2.3525	3.6222
5	1.643	1.0974	1.2894	1.5684	1.2936	2.726	3.6595
6	1.6057	1.0608	1.3253	1.419	1.2437	3.2114	3.5475
7	1.4937	1.1797	1.4118	1.419	1.2437	3.0678	3.2861
8	1.6632	1.3394	1.3306	1.307	1.448	3.5101	2.9683
9		1.4415	2.2405	1.39	2.3152	3.6969	
10	1.9044	1.2936	2.4272		2.726	4.257	
11	2.268	1.2936	2.4272			4.0703	
12	2.2923	1.5154	2.1658		2.4508	2.5873	
13	2.4646	1.4784	2.3152		1.9982	2.4272	
14	2.7633	1.5893	2.2405		2.3777	3.8089	
15	2.2779	1.6057	2.4272		2.1719	3.8836	
16		1.7002	2.1658		2.0851	4.145	
17	2.0165	1.6057	1.9044		1.9044	3.8836	
18	1.7924	1.3676	2.0911		1.6263	4.145	
19	1.531	1.4563	1.6804		1.6804	3.7715	
20	1.531	1.1088	1.7924	1.1706	1.5893	3.3234	
21	1.531	1.2235	1.6804	1.3306	1.8111	3.4743	
22	1.4937	1.3443	1.6057	1.5893	1.7741	3.5475	
23	1.6461	1.4045		1.39	1.7002	3.6969	3.8089
24	1.5524	1.4632	1.2894	1.7924	1.3306	1.7002	3.6591
Max	2.7633	1.7002	2.4272	1.9791	2.726	4.257	3.9209
Min	1.4937	1.0608	1.2894	1.1706	1.2437	1.7002	2.0416
Avg	1.8143	1.3621	1.7899	1.5283	1.7382	3.2247	3.4024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 304 / TUBE

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6759	3.568	2.2043	2.793	3.3527	3.3726	3.456
2	3.706	3.9262	2.1529	3.0019	3.197	3.4412	2.7991
3	3.6793	3.9522	2.1319	3.1512	2.865	3.53	2.7793
4	3.528	3.8851	2.1548	2.9089	2.8639	3.9186	2.652
5	3.0643	3.059	2.0805	3.0171	2.7378	3.9781	2.5971
6	3.7456	3.4537	1.9281	3.7853	2.7443	4.3949	2.7123
7	3.2106	3.5368	1.9281	3.4233	2.4783	3.6897	2.6086
8	3.4617	2.9969	3.2957	3.2579	2.71	4.103	2.5301
9	3.7014	3.6137	3.7784	4.0036	2.7946	4.3782	1.9509
10	4.5808	3.7411	3.7685	3.4202	2.8014	4.7135	2.0424
11	3.9842	3.6988	3.7823	3.5513	2.0652	3.9003	2.7511
12	2.2329	3.6172	3.8942	3.7261	3.3898	3.7532	2.774
13	3.1703	3.3646	3.7167	2.4615	3.1215	4.0101	2.4768
14	3.8104	3.6732	3.6541		2.3853	4.2814	2.8807
15	3.3372	3.7483	3.6138		2.2024	3.8889	2.6139
16	3.2815	3.4016	3.6252		3.2069	3.6161	2.9264
17	3.8774	3.6812	3.2502		3.3886	3.5559	3.0483
18	3.946	3.2578	3.1139		4.1545	3.1322	2.5682
19	2.8654	2.9195	3.011		4.0848	3.9369	2.6901
20	4.5069	2.5781	2.7053	1.0372	3.7185	3.9026	2.332
21	4.2791	2.3666	2.5751	2.8777	2.9012	3.6942	2.0729
22	4.1045	3.4103	2.6879	4.6658	3.022	4.3606	2.2786
23	3.1764	3.1386	1.8061	4.1838	3.3584	3.8767	2.7717
24	3.4636	2.3594	2.572	2.8784	3.6824	3.709	3.0323
Max	4.5808	3.9522	3.8942	4.6658	4.1545	4.7135	3.456
Min	2.2329	2.3594	1.8061	1.0372	2.0652	3.1322	1.9509
Avg	3.5996	3.3728	2.8930	3.2302	3.0511	3.8807	2.6394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 402 / GODREJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1643	1.2071	.2218	1.3443	1.1523	1.3306	1.4003
2	1.2323	1.0974	.2172	1.2883	1.1643	1.3306	1.2357
3	1.1763	1.0974	.3258	1.1203	1.2197	1.3443	1.3443
4	1.1763	1.1523	.543	1.1763	1.3306	1.4563	1.1203
5	1.2197	1.1523	.2772	1.4003	1.3306	1.4563	1.2883
6	1.2323	1.1523	.6653	1.2883	1.3717	1.4563	1.2883
7	1.2752	.639	.9979	1.2323	1.1088	.9425	.3361
8	1.6804	.5973	1.885	1.6804	1.6078	1.6804	.1629
9		.499		1.8296	1.7924	1.7364	.3361
10	1.8484	.499	2.1285	1.7741	.8962	1.9044	.3921
11	1.8107	.499	1.9605	1.9404		1.7924	.3361
12	1.4506	.4435	1.6804	1.6632		1.386	.3361
13	1.4506	.3881	1.6804	1.6461	.6836	1.5684	.3361
14	1.4563	.3881	1.7924	1.6804	.8779	1.5123	.3361
15	1.8484	.3326	1.8484	1.4969		1.5684	.3361
16	1.0082	.2241	1.4003	1.0534	1.2071	1.1203	.3361
17	.9522	.2218	1.0082	.9979	1.0082	.7842	
18	.7842	.1663	.9522	.9425	.9425	.9522	
19	.9522	.1663	1.0082	.8316	1.0082	1.0082	
20	.8402		.8962	.7207	.8871	.8962	
21	.7842	.2241	.9522	.7207	.7207	.7762	
22	.8402	.2218		.8871	1.1088	.9522	
23	1.262	.2218	1.2323	1.2752	1.1088	1.2323	.168
24	1.2197	1.2071	.2172	1.0082	1.0534	1.2197	1.0534
Max	1.8484	1.2071	2.1285	1.9404	1.7924	1.9044	1.4003
Min	.7842	.1663	.2172	.7207	.6836	.7762	.1629
Avg	1.2463	.5999	1.0859	1.2916	1.1229	1.3086	.6746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 403 / SUSSEN ASIA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5123	1.3169	1.3032	1.4003	1.386	1.3306	1.6804
2	1.4563	1.3169	1.2778	1.5684	1.3717	1.4415	1.4506
3	1.4563	1.4266	1.2489	1.5123	1.386	1.4563	1.3443
4	1.5123	1.4266	1.1403	1.4003	1.4118	1.4003	1.4563
5	1.4969	1.4266	1.1643	1.5684	1.3575	1.4003	1.5684
6	1.4415	1.3169	1.1643	1.2883	1.4266	1.4563	1.2883
7	1.4003	1.3272	1.5524	1.5684	1.5364	1.4969	1.5123
8	1.4969	1.3032	1.5524	1.6804	1.4266	1.6804	1.5746
9	1.6244	1.4969	1.6244	1.6632	1.7924	1.8484	1.6804
10	1.7364	1.5524	1.6804	1.7741	1.9044	1.7924	1.7924
11	1.6461	1.2197	1.5123	1.5364		1.3443	1.4563
12	1.6655	1.5524	1.7924	1.7741		1.7741	1.5684
13	1.7924	1.4415	1.5684	1.7187	1.7353	1.6804	1.4003
14	1.7364	1.4415	1.6804	1.6632		1.7924	1.8484
15	1.2323	1.2323	1.6804	1.3306		1.5123	1.6804
16	1.7924	1.6804	1.6804	1.7741	1.701	1.6804	1.5123
17	1.5684	1.4969	1.5123	1.6804	1.5684	1.6244	
18	1.5123	1.5524	1.7924	1.6078	1.4969	1.7924	
19	1.8484	1.5684	1.6804	1.6632	1.5684	1.5684	
20	1.4003	1.386	1.5684	1.3306	1.5524	1.4003	
21	1.5684	1.4969	1.6804	1.6078	1.6632	1.7187	
22	1.5123	1.386		1.4815	1.4415	1.6804	
23	1.4815	1.4563		1.6244	1.4415	1.4003	1.5684
24	1.5123	1.4266	1.3032	1.5684	1.4815	1.3306	1.4969
Max	1.8484	1.6804	1.7924	1.7741	1.9044	1.8484	1.8484
Min	1.2323	1.2197	1.1403	1.2883	1.3575	1.3306	1.2883
Avg	1.5584	1.4270	1.5073	1.5744	1.5325	1.5668	1.5489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 404 / UMICORE

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6007	.5607	.5584	.591	.6104	.6716	.5773
2	.5887	.5762	.5567	.5842	.5762	.6527	.5716
3	.579	.5693	.5533	.6127	.5682	.5756	.5636
4	.5562	.5624	.5378	.6196	.603	.591	.5345
5	.5716	.5487	.5464	.6179	.615	.579	.5619
6	.5688	.5624	.5585	.5636	.6201	.5808	.5773
7	.5476	.543	.563	.579	.5487	.5699	.567
8	.567	.5601	.5613	.5722	.3515	.5962	.5756
9	.5808	.5619	.5996	.7253	.6625	.7122	.6968
10	.6133	.5853	.8076	.703	.8419	.8094	.7293
11	.6687	.6213	.8014	.6951	.4801	.6562	.7139
12	.6367	.5928	.8659	.9557	.5881	.7453	.7688
13	.615	.6116	.9071	.8401	.9477	.7945	.7619
14	.5242	.6133	.8642	.8922	.5521	.7208	.7699
15	.543	.6213	.8745	.8642	.5813	.7328	.8402
16	.4938	.623	.8694	.8871	.9396	.7585	.8711
17	.519	.6613	.8419	.7973	.7882	.7774	.4561
18	.6693	.5688	.6185	.7836	.611	.7585	.4681
19	.5945	.5825	.6385	.7887	.6728	.7225	.4544
20	.6316	.5819	.7208	.6402	.7453	.6951	.4201
21	.5619	.5544	.6968	.7287	.7162	.6385	.3978
22	.567	.5613	.4029	.6104	.7561	.6202	.415
23	.5813	.579	.3909	.6087	.7527	.5945	.6745
24	.5767	.5521	.5859	.5842	.7028	.6287	.6219
Max	.6693	.6613	.9071	.9557	.9477	.8094	.8711
Min	.4938	.543	.3909	.5636	.3515	.5699	.3978
Avg	.5815	.5814	.6634	.7019	.6596	.6742	.6079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 301 / AHIRE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9791	1.9204	.0686		.1132	.0686	
2	2.0538	1.9204	.112		.1132	.0686	
3	2.0538	1.9547	.0686		.1132	.0686	
4	1.9418	1.9547	.0686		.1132	.1029	
5	2.0911	2.0576	.0686		.112	.0686	
6	2.1658	2.1262	.0686		.1132	.1029	
7	2.8006	2.6749	.0686		.112	.0686	
8	2.726	2.5034	1.8176		.112	.0457	
9	.0686	.112	2.9127	1.9791		2.4006	
10	.1029	.112	2.2977			2.5377	.112
11	.0686	.1132	2.0919	3.0994		2.0576	.112
12	.1029	.112				2.0576	.112
13	.0686	.1132	1.8861			2.0919	.112
14	.1029	.1132	1.7147	2.838		1.9204	.112
15	.1029	.1132	1.5432			2.0919	.1132
16	.1029	.1132	1.3032	3.0247		2.2634	
17	.1029	.112	.0686				.112
18	.1029	.112	.0686			.0686	.1132
19	.0686	.1132	.0686	.112		.0686	.1132
20	.1029	.112	.0686			.0686	.1132
21	.1029		.0686			.0686	.1132
22	.0686		.0686	.112		.0686	.1132
23	2.0576		.0686			.0686	
24	2.0538	1.989	.0686		.1132	.0686	
Max	2.8006	2.6749	2.9127	3.0994	.1132	2.5377	.1132
Min	.0686	.112	.0686	.112	.112	.0457	.112
Avg	.9664	.9739	.7235	1.8609	.1128	.8042	.1126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 302 / KHANDALA

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.0288	1.3717		1.1949	1.3032	1.3717
2	1.0082	1.0288	1.3717		1.307	1.3375	1.3032
3	1.1203	1.0974	1.3717		1.3817	1.3032	1.3375
4	1.2323	1.166	1.3032		1.531	1.3717	1.2346
5	1.419	1.4746	1.3717		1.6804	1.2346	1.2346
6	1.5684	1.6804	1.2346		1.1203	1.2346	1.2346
7	1.307	1.0288	1.1317		1.4937	1.2346	1.3032
8	1.5684	1.0631	1.3032		1.1203	1.1317	
9	1.6118	1.0456	1.4937	1.419		1.166	
10	1.8519	1.1203				1.0974	1.4937
11	1.5775	1.6804	1.0974	1.1949		.7545	1.1203
12	1.4403	.9335	1.0974			.823	1.1203
13	1.4746	.7468				1.2346	1.1203
14	.9602	1.2323		1.0829		1.3032	1.307
15	.9945	1.2323				1.3717	1.7551
16	.9945	1.307	.7202	1.0082		1.3717	
17	1.1317	.9335	.9945				1.1203
18	1.3032	1.0456	1.1317			1.5432	1.3443
19	1.3032	1.1576	1.2346	1.2323		1.2346	1.6804
20	1.3032	1.419	1.6461			1.7833	1.7924
21	1.2346		1.7147			1.3375	1.6804
22	1.2003		1.2346	1.307		1.3717	1.4937
23	1.0974		1.5775			1.3032	
24	1.1203	1.2003	1.3717		1.1203	1.406	1.3032
Max	1.8519	1.6804	1.7147	1.419	1.6804	1.7833	1.7924
Min	.9602	.7468	.7202	1.0082	1.1203	.7545	1.1203
Avg	1.2862	1.1725	1.2887	1.2074	1.3277	1.2719	1.3675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 303 / LOHOM

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.3717	1.3717		1.307	.7545	1.2689
2	1.4563	1.3717	1.406		1.1949	.8573	1.3032
3	1.3817	1.3032	1.4403		1.2323	.9602	1.3375
4	1.4563	1.3032	1.3717		1.307	.9602	1.2346
5	1.4937	1.4403	1.406		1.3443	1.1317	1.2003
6	1.4937	1.5089	1.4403		1.4937	1.0974	1.1317
7	1.6804	1.2689	1.5089		1.6804	1.3032	1.0974
8	1.4937	1.2689	1.5089		1.4937	1.3717	1.4403
9	1.4403	1.7177	2.0538	.5975		1.3717	
10	1.5775	1.8671	1.6118			.5144	1.8671
11	1.3717	1.4937		1.4937		.7545	1.8671
12	2.0576	1.6804	1.5775			.6859	1.6804
13	1.6118	1.1203	1.7147			.7202	1.5684
14	1.5775	1.5684	1.7147	1.3443		.6859	1.8671
15	1.7147	1.1203	1.7147			1.6461	1.7924
16	1.749	1.1203	.9602	1.419		1.3717	
17	1.989	1.6804	1.9204				1.8671
18	1.4746	1.4937	1.406			1.7147	1.6804
19	1.3717	1.6804	1.4746	1.4563		1.6461	1.8671
20	1.4403	1.9418				1.6461	2.0538
21	1.5775		1.3032			1.0974	1.9044
22	1.4746		1.5432	1.6804		1.2689	1.7177
23	1.5432		1.3717			1.2346	
24	1.6804	1.4403	1.4403		1.4937	1.0974	1.3032
Max	2.0576	1.9418	2.0538	1.6804	1.6804	1.7147	2.0538
Min	1.3717	1.1203	.9602	.5975	1.1949	.5144	1.0974
Avg	1.5698	1.4648	1.5118	1.3319	1.3941	1.1257	1.5738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 304 / TBK

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1372	.1029		.1494	.1715	.2058
2	.1867	.1372	.1029		.1494	.1715	.2058
3	.1494	.1372	.1029		.1494	.1715	.2058
4	.1494	.1029	.1029		.1494	.1372	.2058
5	.1494	.1029	.1029		.1494	.1372	.1715
6	.1494	.1029	.1372		.1494	.1372	.1372
7	.1494	.1029	.1715		.1494	.1372	.1715
8	.112	.1029	.1715		.1494	.1029	.1372
9	.1372	.112	.2614	.1494	.2743	.1715	
10	.2058	.1132	.2058		.2401	.2401	.2241
11	.2401	.112	.2401	.1867	.2401	.2058	.2614
12	.1372	.112	.2401		.1372	.2058	.2614
13	.2058	.0754	.2401		.1715	.2058	.1867
14	.1715	.112	.2401	.1867	.1715	.2058	.1867
15	.1715	.112	.2058		.1715	.2401	.2241
16	.1372	.112	.1372	.1867	.1715	.1715	
17	.1372	.112	.1372		.1372	.1372	.2241
18	.1029	.112	.1372		.1372	.1715	.2241
19	.1372	.112	.1372	.1494	.1372	.1715	.1867
20	.1372	.112	.1029		.1029	.1372	.1867
21	.1372		.2058		.1372	.1715	.173
22	.1372		.1372	.1867	.1372	.2058	.2263
23	.1372		.1715		.1715	.2058	
24	.1867	.1372	.1029		.1494	.1372	.2058
Max	.2401	.1372	.2614	.1867	.2743	.2401	.2614
Min	.1029	.0754	.1029	.1494	.1029	.1029	.1372
Avg	.1563	.1129	.1624	.1743	.1618	.1729	.2006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 401 / Panache Alluminium

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.4115	.1543		.2801	.2572	.3086
2	.2801	.4115	.1543		.2801	.2572	.3086
3	.3361	.3601	.1543		.2801	.2572	.3086
4	.3921	.3601	.1543		.2241	.2572	
5	.4481	.3601	.1543		.2241	.2572	.0206
6	.4481	.3601	.1543		.3921	.2572	.2572
7	.3361	.3086	.1543		.3921	.3086	.3086
8	.3921	.4115	.2572		.5041	.3086	.463
9	.3601	.5041	.3921	.3361		.3601	
10	.4115	.6161	.3601			.3601	.3921
11	.463	.3921	.3601	.2241		.3601	.5601
12	.463	.5041	.4115			.2572	.5041
13	.3086	.4481	.463			.2572	.5601
14	.3601	.3395	.463	.2801		.2572	.5041
15	.3601	.3921	.463			.2572	.7282
16	.2572	.3361	.3601	.3361		.3601	
17	.3601	.2241	.3601			.3601	.7282
18	.5658	.2801	.3086			.3601	.4481
19	.5144	.3361	.4115	.3921			.5041
20	.5144	.2241	.4115			.4115	.6161
21	.4115		.4115			.3601	.5041
22	.3601		.4115	.5041		.3086	.3921
23	.3601		.2058			.3086	
24	.3361	.4115	.1543		.3921	.4115	.3086
Max	.5658	.6161	.463	.5041	.5041	.4115	.7282
Min	.2572	.2241	.1543	.2241	.2241	.2572	.0206
Avg	.3883	.3806	.3035	.3454	.3299	.3109	.4363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 301 / 22 KV MUKUND EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.7167	.5914	.415	.2561	.4904	.5228
2	.5975	.5658	.5228	.415	.2195	.415	.4481
3	.5975	.6036	.6283	.3772	.2195	.3772	.4108
4	.5228	.6413	.4854	.3772	.2561	.3772	.6348
5	.4854	.7167	.4481	.4527	.2587	.3772	.5975
6	.6722	.7167	.4108	.4904	.2561	.3395	.5601
7	.6722	.679	.4108	.4527	.2481	.3772	.5228
8	.7468	.7167	.5975	.5658	.2481	.5658	.5601
9	.5975	.5601	.5975	.4527	.2126	.5658	.2987
10	.5975	.5658	.679	.4904	.3772	.6413	.0244
11	.5658	.6036	.7167	.4527		.5487	
12	.5281	.6036	.5658	.4904	.5281	.5658	.6413
13	.5975	.4904	.679	.5228	.415	.4527	
14	.5281	.7545	.6413		.4904	.4527	.679
15	.4904	.4527	.4854		.4527	.4481	.1509
16	.6036	.5658			.679	.7545	.4527
17	.4527	.6348	.4904	.3361	.4904	.4904	.6413
18	.415	.5601	.5853	.2614	.415	.5228	.4904
19	.5658	.5228	.4527	.2614	.3018	.4854	.679
20	.5281	.5601	.4527	.2561	.3018	.4481	.5658
21	.5658	.4066	.4527	.2195	.3018	.4108	.6036
22	.7545	.5228	.4527	.3361	.415	.5228	.6413
23	.6036	.5601	.4527	.2561	.4527	.5601	.4527
24	.5975	.5281	.4435	.3772	.2641	.3018	.4854
Max	.7545	.7545	.7167	.5658	.679	.7545	.679
Min	.415	.4066	.4108	.2195	.2126	.3018	.0244
Avg	.5800	.5937	.5323	.3933	.3504	.4788	.5029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 302 / 22 KV ANDHURI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3772	4.8068	5.0793	5.7682	5.6036	.4108
2	.3696	.3772	4.9726	4.923	5.5708	5.3765	.4108
3	.3696	.3772	5.2709	4.7051	5.5053	5.3117	.4108
4	.4481	.415	5.3704	4.6411	5.6356	5.2172	.4108
5	.4854	.4527	5.7019	4.6639	5.8013	5.2812	.4481
6	.4854	.4904	6.2323	5.4725	6.2323	5.8657	.4854
7	.4481	.4904	6.5638		7.0611	6.5969	.4481
8	.4108	.3395	5.8676		6.5969	6.2262	.3696
9	6.6301	7.0127	.3734		.3734	.3696	6.7295
10	7.4387	7.1605	.3361		.3395	.3395	
11	7.537	7.0127	.2987	.0256		.3361	
12	6.8816	5.735	.1867	.034	.3395	.3772	.2896
13	6.5306	6.5386	.2195		.3395	.3395	
14	6.5969	5.7674	.2641		.3361	.2987	7.7991
15	6.6632	5.6691	.2926	.3292	.3361	.2957	6.8953
16	6.7627	6.2323			.2987	.3734	7.5583
17	.3395	.2614	.2195	.2957	.3018	.3292	7.2093
18	.415	.3696	.3772	.4108	.3361	.3734	.5975
19	.4904	.4108	.5281	.4108	.415	.4854	.4527
20	.5658	.5228	.5658	.4481	.5121	.5601	.4904
21	.5281	.4854	.5658	.4481	.4904	.5228	.5281
22	.4904	.4854	.7167	.4481	.4904	.4805	.5281
23	.4527	.4108	5.0465	5.7682	4.7611	.4481	.4904
24	.3696	.415	.4108	5.0465	6.0002	5.7019	.4108
Max	7.537	7.1605	6.5638	5.7682	7.0611	6.5969	7.7991
Min	.3395	.2614	.1867	.0256	.2987	.2957	.2896
Avg	2.5866	2.4087	2.3995	2.5382	2.7757	2.3796	2.0654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 303 / 22 KV LONAND MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.7545	.9335	1.0985	.7842	.6935	.8962
2	.8962	.7202	.9335	1.0402	.8215	.6588	.9335
3	.9709	.6859	.8589	1.0402	.8215	.6516	.8589
4	.8962	.7282	.8962	.9945	.8962	.6173	1.2696
5	.9335	.7628	.9335	1.0749	.8589	.6173	1.307
6	.8962	.7628	1.0456	.9259	.9709	.7442	1.307
7	.8871	.9922	1.0456	.4115	.9335	.6588	1.2323
8	.7842	.6516	1.1576	.7167	.8962	.7442	3.0994
9	.9335	.9808	2.0538	.9431	1.531	.7167	2.0165
10	.9709	1.1317	2.7915	.7922	2.3011	.8676	
11	1.2449	2.6406	1.5466	.7922		2.9047	
12	1.0562	3.131	1.773	.7023	.8299	3.6595	.112
13	1.1203	1.6975	2.8292	.7545	.788	3.2819	
14	1.0185	1.6598	2.6406		2.3388	2.3899	1.9239
15	.9054	2.5652	2.8006	.9431	.9774	3.0933	1.4712
16	1.0185	1.5844			.8954	1.773	3.2442
17	.6036	1.9418	2.0748	.7545	1.086	1.4335	2.5019
18	.8505	1.9791	1.3817	.7023	1.0608	1.7924	1.1827
19	.8505	.8589	1.419	.7095	1.0387	.9335	1.1222
20	.9671	.9335	1.4563	.8215	.8596	.8962	1.1584
21	.8859	.8589	1.1827	.8589	.8505	.9709	1.3535
22	1.0029	.7842	1.1222	.8962	.7796	.8962	1.3032
23	.8413	1.0082	1.2437	.7468	.7628	.9335	1.182
24	1.2696	.7545	1.0082	1.0985	.7095	.7628	.8215
Max	1.2696	3.131	2.8292	1.0985	2.3388	3.6595	3.2442
Min	.6036	.6516	.8589	.4115	.7095	.6173	.112
Avg	.9474	1.2737	1.5273	.8554	1.0344	1.3621	1.4427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 304 / 22 KV KHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.5281	.5228	.4904	.4854	.5281	.5228
2	.5228	.5281	.5228	.4854	.4854	.5281	.5228
3	.6722	.5228	.5228	.4854	.4854	.5228	.5601
4	.6722	.5228	.6348	.4854	.5601	.5601	.5601
5	.7468	.6036	.7468	.5658	.7468	.7167	.5601
6	.8962	.9054	.8215	.8299	.8589	.9054	.9709
7	.9335	1.0185	.9335	.8676	.8962	.9054	.9335
8	.7468	.7545	.7468	.7392	.7468	.7545	.6722
9	.6722	.679	.6348	.5658	.6348	.6036	.6722
10	.6036	.7167	.6413		.6283	.6036	
11	.5601	.6348	.5914	.5658		.5975	
12	.5228	.6036	.6036	.6036	.5228	.5658	.3395
13	.5544	.5281	.5658	.5658	.5228	.5658	
14	.4527	.5281	.5658		.5228	.5487	.6036
15	.5544	.5281	.5658		.5601	.5228	.679
16	.5975	.4904			.5228	.5281	.6413
17	.5544	.5601	.5281	.6036	.6348	.6036	.6348
18	.6413	.4854	.6036	.3734	.5975		.7095
19	.7922	.7468	.7922	.7842	.8299	.8589	.8676
20	1.0185	.9335	.9808	.9335	1.0185	1.0829	.9808
21	.9054	.9335	.9054	.8589	.9431	.9335	.9431
22	.8299	.8215	.7922	.7468	.8299	.7468	.8299
23	.6413	.6348	.5853	.5601	.6413	.7095	.7167
24	.5228	.5658	.5601	.5281	.4854	.5658	.5601
Max	1.0185	1.0185	.9808	.9335	1.0185	1.0829	.9808
Min	.4527	.4854	.5228	.3734	.4854	.5228	.3395
Avg	.6706	.6573	.6682	.6319	.6591	.6721	.6896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 301 / 22 KV PADEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3395	.3772	.3395	.3395	.3395	.3395	.3772
12	.3018	.3018	.2641	.3395	.3772	.3395	
18	.3772	.3395	.3395	.3395	.3395	.3772	.3018
23	.3018	.3395	.3395	.3395	.3395	.3395	.3395
24	.3018	.3018	.3018	.3395	.3395	.3018	.3018
Max	.3772	.3772	.3395	.3395	.3772	.3772	.3772
Min	.3018	.3018	.2641	.3395	.3395	.3018	.3018
Avg	.3244	.3320	.3169	.3395	.3470	.3395	.3301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 302 / 22KV LONAND URBAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.2071	1.2071	1.2071	1.2071	1.2071	1.2826	1.2826
12	1.3203	1.3203	1.3957	1.3203	1.358	1.1694	1.2826
18	1.2826	1.358	1.4712	1.3957	1.4335	1.358	1.5089
23	1.2826	1.3203	1.358	1.3203	1.4335	1.5089	1.4335
24	1.2826	1.2071	1.2071	1.2449	1.2449	1.358	1.358
Max	1.3203	1.358	1.4712	1.3957	1.4335	1.5089	1.5089
Min	1.2071	1.2071	1.2071	1.2071	1.2071	1.1694	1.2826
Avg	1.2750	1.2826	1.3278	1.2977	1.3354	1.3354	1.3731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 303 / 22KV TARADGAON AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	4.9794	4.9794	.2561	.3018	.1132	.1509	5.0549
12	.2263	.0377	4.5268	6.6392	3.2819	6.6392	
18	.0377	.3772	.2263	.0377	.1509	.2263	.1132
23	4.5645	.3772	.2641	.0754	.1132	.1132	.1509
24	4.7154	4.7908	2.7801	.3018	.0754	.1132	.1132
Max	4.9794	4.9794	4.5268	6.6392	3.2819	6.6392	5.0549
Min	.0377	.0377	.2263	.0377	.0754	.1132	.1132
Avg	2.9047	2.1125	1.6107	1.4712	.7469	1.4486	1.3581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 304 / 22 KV TAMBAVE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	5.9225	6.0357	.4527	.4527	.4904	.4904	4.5268
12	.4527	.1509	6.7901	6.4129	5.168	6.4129	.1886
18	.4904	.3772	.3018	.3018	.4527	.1886	.3018
23	5.2812	.3772	.3772	.3395	.3395	.415	.8676
24	5.3567	5.2058	4.225	.3395	.3395	.3395	.415
Max	5.9225	6.0357	6.7901	6.4129	5.168	6.4129	4.5268
Min	.4527	.1509	.3018	.3018	.3395	.1886	.1886
Avg	3.5007	2.4294	2.4294	1.5693	1.3580	1.5693	1.2600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 307 / 22KV TARADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.358	1.4712	1.5089	1.3957	1.3957	1.5844	1.3957
12	1.1694	.8299	1.2449	1.2071	1.3957	1.2449	1.2826
18	1.3203	1.1694	1.3203	.8676	1.1694	1.094	1.1317
23	1.3203	1.3203	1.3957	1.3203	1.358	1.358	1.358
24	1.094	1.094	1.0562	1.2071	1.1317	1.2449	1.2071
Max	1.358	1.4712	1.5089	1.3957	1.3957	1.5844	1.3957
Min	1.094	.8299	1.0562	.8676	1.1317	1.094	1.1317
Avg	1.2524	1.1770	1.3052	1.1996	1.2901	1.3052	1.2750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 204 / 11 KV HERITAGE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1124	.0895	.1143	.1124	.1143	.1143	.12
2	.0895	.0838	.1143	.1181	.1124	.1181	.12
3	.0914	.1181	.1143	.1219	.1143	.1162	.1162
4	.0857	.12	.1105	.12	.0838	.1219	.1124
5	.061	.1181	.0953	.0876	.0838	.12	.1086
6	.0762	.1067	.0362	.0381	.0819	.08	.0857
7	.0686	.0476	.0343	.0438	.0457	.0381	.0819
8	.0762	.0362	.0324	.0648	.0381	.0476	.0381
9	.04	.0876	.0476	.0953	.0533	.1334	.1296
10	.1296	.1029	.1334	.1772	.0857	.1981	.1753
11	.16	.1257	.1391	.1772	.0781	.2153	.1772
12	.1238	.0686	.0572	.0819	.0876	.12	.1696
13	.0362	.0629	.0857	.0324	.0762	.1372	.0953
14	.0191	.0591	.061		.0305	.1315	.0972
15	.0667	.0705	.0457		.0553	.1162	.0724
16	.1029	.0857	.0572		.1467	.1067	.0514
17	.1105	.0762	.0457		.0895	.1181	.0724
18	.0972	.08	.0629		.0591	.0953	.0705
19	.0762	.0533	.0876		.0667	.0934	.04
20	.0895	.0743	.1391		.1219	.12	.1162
21	.1429	.141	.1448	.0591	.141	.1372	.1448
22	.1372	.1886	.1372	.0133	.1962	.1448	.1467
23	.1391	.1943	.1753	.2096	.1981	.1467	.1867
24	.1086	.1372	.1353	.2	.1791	.1791	.1543
Max	.16	.1943	.1753	.2096	.1981	.2153	.1867
Min	.0191	.0362	.0324	.0133	.0305	.0381	.0381
Avg	.0934	.0970	.0919	.1031	.0975	.1229	.1118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 306 / SM Spining

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2934	.3125	.3163	.3048	.301	.282	.2858
2	.2934	.2972	.3201	.2972	.301	.2782	.2858
3	.2934	.301	.3086	.2858	.301	.282	.2858
4	.2934	.301	.3048	.2858	.301	.2743	.2858
5	.301	.3163	.301	.2972	.301	.2705	.2858
6	.301	.3125	.3086	.3048	.2972	.2705	.2858
7	.2934	.3201	.3163	.3086	.2972	.2743	.2743
8	.2972	.3086	.3125	.2934	.2896	.2705	.282
9	.2934	.301	.2972	.2972	.2934	.3429	.282
10	.3086	.2934	.3239	.3048	.282	.4687	.3086
11	.3582	.362	.4725	.3467	.2896	.5144	.3125
12	.5144	.5258	.5373	.4534	.2858	.4344	.4687
13	.5106	.5525	.5716	.4382	.3048	.4725	.4839
14	.4534	.5373	.4954	.4306	.2934	.4954	.4572
15	.3734	.5296	.3163	.4268	.2896	.4915	.4496
16	.4954	.4687	.4649	.4153	.2858	.3734	.3849
17	.4458	.4572	.4915	.3201	.2896	.2858	.4649
18	.4191	.4687	.4534	.2972	.2858	.4649	.4954
19	.4915	.3506	.3048	.301	.2743	.4344	.4344
20	.4877	.2972	.2972	.2896	.2667	.2896	.282
21	.3772	.2972	.2934	.2934	.2782	.2896	.2743
22	.3048	.2972	.2858	.2934	.2782	.2858	.2743
23	.3163	.2972	.2934	.2896	.282	.282	.2743
24	.3163	.3163	.3086	.2972	.282	.2705	.2782
Max	.5144	.5525	.5716	.4534	.3048	.5144	.4954
Min	.2934	.2934	.2858	.2858	.2667	.2705	.2743
Avg	.3680	.3675	.3623	.3280	.2896	.3499	.3415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 301 / 22 KV SOMANTHALI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.7621	.6859	.6859	.6173	.5144	.583
2	.3429	.724	.6173	.6859	.6173	.5144	.583
3	.2401	.6859	.6173	.6516	.5487	.5144	.583
4	.2743	.724	.6173	.6516	.5487	.5144	.583
5	.2743	.7621	.6173	.6516	.583	.5144	.583
6	.4115	.8002	.6516	.7202	.6859	.6173	.583
7	.3772	.7621	.6859	.7545	.5487	.6516	.583
8	.4115	.7621	.583	.6173	.3772	.4801	.6478
9	.3429	.7621	.6173	.6173	.6173	.4115	.6478
10	.7202	.8383	.6859	.7202	.8002	.5487	.6859
11	.6859	.7888	.8002	.7545		.7545	.5144
12	.583	.6173	.8002	.7202		.6173	.4115
13	.583	.6859	.724	.6859	.4954	.583	.4115
14	.5487	.6173	.724	.6859	.4954	.583	.4115
15	.5144	.6173	.724	.6173	.4954	.583	.4458
16	.5487	.6173		.5487	.4954	.583	.3772
17	.5144	.5487	.6478	.6173	.4954	.6173	.3772
18	.6859	.583	.7621	.7545	.5335	.6516	.5487
19	.724	.7545	.823	.6859	.583	.6516	.4801
20	.9526	.823	.9259	.823	.6859	.7545	.5487
21	.8764	.7545	.8916	.7888	.6516	.6859	.583
22	.8002	.7545	.9259	.8916	.6859	.6859	.6859
23	.9526	.7545	.8573	.8916	.6173		.6516
24	.583	.8002	.6859	.7888	.7202	.5144	.6859
Max	.9526	.8383	.9259	.8916	.8002	.7545	.6859
Min	.2401	.5487	.583	.5487	.3772	.4115	.3772
Avg	.5581	.7208	.7248	.7088	.5863	.5890	.5498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 302 / 22 KV KAMBALESHWAR

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.381	1.6118	2.4691	2.1605	2.1948	.2743
2	.1715	.381	1.7147	2.4691	2.1948	2.1948	.2743
3	.1372	.381	1.9204	2.4348	2.2291	2.2291	.2743
4	.1715	.381	2.0576	2.4348	2.2291	2.2291	.2743
5	.1715	.381	2.2634	2.572	2.2977	2.4348	.3086
6	.3772	.4572	2.7092	2.7778	2.5034	2.7092	
7	.3772	.4954	2.9835	2.9492	3.0178	2.9835	.4115
8	.3086	.381	2.6406	2.915	2.572	2.8464	.381
9	2.6406	3.3913	.2743	.2743	.2401	.2743	3.3913
10	3.2579	3.5818	.2743	.2743	.2667	.2743	3.4294
11	3.155	3.2922	.2667	.2401		.3086	3.1893
12	3.0521	2.6406	.1905	.2401		.2743	3.1207
13	3.0178	2.7435	.3048	.2743	.3048	.3086	3.0521
14	2.7778	2.7435	.3429	.2743	.3048	.3086	2.8121
15	2.8121	2.8464	.3048		.3048	.1715	3.0178
16	2.9492	2.8121		.2743	.3048	.1715	2.7435
17	.2743	.3086	.3429	.2743	.3048	.3429	.3086
18	.3086	.3429	.3429	.1372	.3048	.2401	.3086
19	.4191	.3772	.3429	.2058	.3772	.3086	.3772
20	.4572	.4115	.4458	.2743	.4458	.4458	.4458
21	.4572	.3772	.4115	.2058	.4115	.3772	.4458
22	.4191	.3772	.4115	.3772	.4115	.3772	.4115
23	.381	.3429	2.3663	2.2977	.3429	.3772	.3772
24	.1715	.381	.3086	2.6063	2.1605	.3429	.3772
Max	3.2579	3.5818	2.9835	2.9492	3.0178	2.9835	3.4294
Min	.1372	.3086	.1905	.1372	.2401	.1715	.2743
Avg	1.1849	1.2587	1.0796	1.2718	1.1677	1.0302	1.3046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 303 / 22 KV SASTEWADI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	3.1245	.4801	.5487	.6173	.583	2.4006
2	1.3717	3.0483	.4801	.5487	.6173	.583	2.4006
3	1.3717	2.3624	.4801	.5487	.6173	.6173	2.4006
4	1.4403	2.5149	.5144	.5487	.6173	.6173	2.572
5	1.6118	2.7054	.5487	.6173	.6516	.6516	2.7435
6	2.6749	3.2769	.6516	.6859	.7545	.7202	2.7435
7	4.0809	4.3439	.6516	.6516	.5487	.7202	
8	3.9438	4.2676	.5144	.5144	.4801	.5487	4.3058
9	.4801	.4572	3.8409	4.1838	3.6351	4.2181	.4572
10	.4801	.4954	.2743	4.3896	4.9154	4.5268	.4572
11	.4801	.4801	4.763	4.2867		4.1838	.4115
12	.4801		4.6106	2.4691		3.2922	.4115
13	.4801	.4801	4.6106	2.6063	4.382	3.7723	.4115
14	.4458	.4801	4.6106	3.5665	4.2676	3.6351	.4458
15	.4801	.4801	4.5725		4.1152	1.0631	.4801
16	.4458	.4458		3.738	4.3439	1.0631	.4801
17	.4801	.5144	.5716	.4458	.5335	.5144	.5144
18	.5144	.5144	.5716	.4801	.5335	.6516	.583
19	.7621	.6516	.6516	.6173	.6516	.7545	.6173
20		.7202	.7888	.823	.823	.7888	.7202
21	.8383	.7202	.7888	.7545	.7888	.6859	.7545
22	.8383	.6859	.7202	.7888	.7545	.6859	.7202
23	3.2388	2.6406	.6516	.6516	.6516	.6859	.6516
24	1.3717	3.2388	2.5377	.583	.6173	.6173	.6859
Max	4.0809	4.3439	4.763	4.3896	4.9154	4.5268	4.3058
Min	.4458	.4458	.2743	.4458	.4801	.5144	.4115
Avg	1.2906	1.6804	1.6907	1.5238	1.6326	1.5075	1.2334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 304 / 22 KV SANGAVI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.3048	1.3717	1.9204	2.0576	1.5775	.2743
2	.1715	.3429	1.3717	1.8519	1.989	1.6461	.2743
3	.1715	.3429	1.3717	1.9204	2.0576	1.7147	.2743
4	.1715	.3429	1.5775	1.9204	2.0576	1.7833	.3086
5	.2743	.381	1.9204	2.1262	2.1262	1.989	.3429
6	.4801	.5716	2.6063	2.6063	2.6063	2.6063	.4458
7	.2743	.5716	2.9492	3.0864	2.9492	2.8807	.4801
8	.2743	.4954	2.6063	3.0864	2.2634	2.6749	.4191
9	2.332	3.0102	.2743	.2743	.2743	.2743	3.0102
10	.2743	2.553	.2743	.2743	.2286		3.5437
11	2.8807	3.0864	.2667	.2058			3.155
12	2.7435	2.6749	.3048	.2743			2.8807
13	2.4691	2.8121	.2667	.0686	.2667	.3429	2.8807
14	2.4691	2.6749	.2667		.2286	.3429	2.8807
15	2.4691	2.7435	.2667		.2286	.2743	2.9492
16	2.6063	2.6063			.2286	.2743	2.4691
17	.2058	.2743	.381	.3086	.3048	.2743	.3086
18	.2401	.3429	.381	.4115	.3048	.3429	.0343
19	.5335	.4115	.4115	.4115	.4115	.4115	.4115
20	.5335	.4458	.4801	.5487	.4115	.4801	.4458
21	.4954	.4115	.4115	.4801	.4115	.4115	.0343
22	.4191	.4115	.4115	.4115	.3429	.4115	.3429
23	.381	.3086	1.9204	2.0576	.3429	.4115	.3086
24	.2058	.381	.3086	1.9204	2.0576	.3429	.4115
Max	2.8807	3.0864	2.9492	3.0864	2.9492	2.8807	3.5437
Min	.1715	.2743	.2667	.0686	.2286	.2743	.0343
Avg	.9686	1.1876	.9739	1.2460	1.0977	1.0223	1.2036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 305 / 22 KV SOMANTHALI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.829	.4115	.4115	.4801	.4115	1.3032
2	.9945	1.7147	.4115	.4115	.4801	.4115	1.3032
3	.9945	1.6766	.4115	.4115	.4801	.4115	1.3032
4	1.0288	1.7147	.4115	.4115	.4801	.4115	1.4403
5	1.0974	1.7528	.4458	.4801	.5487	.4801	1.5775
6	1.5775	2.21	.5144	.5487	.5487	.5487	2.2634
7	2.1948	2.4387	.4801	.4801	.4801	.5487	2.332
8	2.0576	2.553	.4801	.4801	.4115	.4801	2.5149
9	.3429	.4191	1.0974	2.2634	2.0576	2.2634	.381
10	.3772	.3048	2.332	2.4006	2.2862	2.4691	.381
11	.3772	.3429	2.553	2.2634		2.332	.3772
12		.4115	2.5149	2.2634		2.0576	.0343
13	.4115	.3429	2.2862	2.1262	2.3243	1.9204	.3429
14	.3429	.3429	2.2481		2.2862	1.9204	.3429
15	.3772	.3429	2.2862		2.3243	2.1262	.3772
16	.3772	.4115			2.4387	2.1262	.3429
17	.3772	.4115	.381	.3772	.381	.4115	.4115
18	.4115	.4115	.381	.3772	.4191	.4115	.0343
19	.5716	.4801	.5487	.5487	.5487	.4801	.5144
20	.6859	.583	.5487	.6173	.5487	.5487	.0343
21	.6097	.5487	.5487	.6173	.5487	.6173	.5487
22	.6097	.5487	.5487	.5487	.5487	.5487	.0343
23	1.8671	1.6461	.4801	.4801	.4801	.4801	.5144
24	1.0288	1.8671	1.6461	.4115	.4801	.4115	.4801
Max	2.1948	2.553	2.553	2.4006	2.4387	2.4691	2.5149
Min	.3429	.3048	.381	.3772	.381	.4115	.0343
Avg	.8583	1.0544	1.0421	.9014	.9810	1.0345	.7995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 306 / 22 KV somawar peth

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0381	.0343	.0343	.0343	.0343	.0343
2	.0343	.0381	.0343	.0343	.0343	.0343	.0343
3	.0343	.0381	.0343	.0343	.0343	.0343	.0343
4	.0343	.0381	.0343	.0343	.0343	.0343	.0343
5	.0343	.0381	.0343	.0343	.0343	.0343	.0343
6	.0343	.0381	.0343	.0343	.0343	.0343	.0343
7	.0343	.0381	.0343	.0343	.0343	.0343	.0343
8	.0343	.0381	.0343	.0343	.0343	.0343	.0381
9	.0343	.0381	.0343	.0343	.0343	.0343	.0381
10	.0343	.0381	.0343	.0343	.0381	.0343	.0381
11	.0343	.0343	.0381	.0343		.0343	.0343
12	.0343		.0381	.0343		.0343	.0343
13	.0343	.0343	.0381	.0343	.0381	.0343	.0343
14	.0343	.0343	.0381		.0381	.0343	.0343
15	.0343	.0343	.0381		.0381	.0343	.0343
16	.0343	.0343		.0343	.0381	.0343	.0343
17	.0343	.0343	.0381	.0343	.0381	.0343	.0343
18	.0343	.0343	.0381	.0343	.0381	.0343	.0343
19	.0381	.0343	.0343	.0343	.0343	.0343	.0343
20	.0381	.0343	.0343	.0343	.0343	.0343	.0343
21	.0381	.0343	.0343	.0343	.0343	.0343	.0343
22	.0381	.0343	.0343	.0343	.0343	.0343	.0343
23	.0381	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0381	.0343	.0343	.0343	.0343	.0343
Max	.0381	.0381	.0381	.0343	.0381	.0343	.0381
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0351	.0361	.0355	.0343	.0355	.0343	.0348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114] BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 301 / 22KV PHALTAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0195		1.749		1.8176	
12	1.8176			1.9433		1.8519
20		2.572		2.572		
Max	2.0195	2.572	1.749	2.572	1.8176	1.8519
Min	1.8176	2.572	1.749	1.9433	1.8176	1.8519
Avg	1.9186	2.572	1.749	2.2577	1.8176	1.8519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 302 / 22KV Y. C. HIGHSCHOOL

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3408	4.4353	4.4109	4.3743	4.1518	4.6914	4.6487
2	4.1488	4.1122	4.1427	4.0939	3.9598	4.3286	4.3621
3	3.9842	3.9079	3.9872	3.9598	3.7891	4.1549	4.1488
4	3.914	3.8226	3.9262	3.847	3.725	4.0543	4.0878
5	3.8317	3.7098	3.8531	3.7677	3.6245	4.0634	4.0634
6	3.8531	3.8104	3.8927	3.7982	3.7037	4.0268	4.1457
7	3.7677	3.7525	3.6732	3.6153	3.5879	3.9598	3.9994
8	3.533	5.6333	3.5086	5.4481	3.2739	5.7636	3.6885
9	3.4202	3.2922	3.4111	3.3806	3.2556	3.6001	3.6062
10	3.8409	3.7159	3.9811	3.8104	3.786	4.1945	4.0817
11	4.3591	4.0847	4.5572	4.1274	4.6091	4.7767	4.6609
12	4.4993	6.8518	4.7767	.3353	7.7595	4.9169	7.4371
13	4.5329	4.3621	4.859	.3292	4.8804	4.8926	4.7767
14	4.414	4.3256	4.8072	4.7127	4.7798	4.8499	4.8529
15	4.5237	4.3774	4.6152	4.5481	4.5024	4.7462	4.6609
16	4.6609	4.5329	4.9901	4.8255	5.0053	5.0815	4.9261
17	4.545	4.5329	4.9078	4.7645	4.9474	5.109	5.0267
18	4.4231	4.3195	4.7889	4.7401	4.9139	4.9688	5.0175
19	4.3621	4.6182	4.7889	4.5603	4.7706	4.8834	4.8621
20	5.1029	5.2553	8.4332	5.3955	8.5475	5.5937	5.176
21	4.8072	5.0937	5.1608	5.1669	5.1943	5.301	4.9566
22	4.5969	4.7493	4.7523	4.417	4.7188	4.7615	4.6091
23	4.8346	4.6853	4.9688	4.5572	5.0541	5.0876	5.0907
24	4.7158	4.7005	4.7158	4.4658	4.9962	4.8956	5.112
Max	5.1029	6.8518	8.4332	5.4481	8.5475	5.7636	7.4371
Min	3.4202	3.2922	3.4111	.3292	3.2556	3.6001	3.6062
Avg	4.2922	4.4451	4.5795	4.0434	4.6474	4.6959	4.6666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 303 / 22 KV SAINAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2667		.2401		.2743	
12	.2058					.2058
13				.1905		
20		.2401		.2401		
Max	.2667	.2401	.2401	.2401	.2743	.2058
Min	.2058	.2401	.2401	.1905	.2743	.2058
Avg	.2363	.2401	.2401	.2153	.2743	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 305 / 22 KV MORAYA MILK FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6097		.3772		.4115	
12	1.1317					.6516
13				.8764		
20		.6516		.9945		
Max	1.1317	.6516	.3772	.9945	.4115	.6516
Min	.6097	.6516	.3772	.8764	.4115	.6516
Avg	.8707	.6516	.3772	.9355	.4115	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 301 / SAKHARWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.5144	2.4996	3.4332	3.0483	2.8959	.5335
2	.3429	.5144	2.4996	3.4008	3.0788	2.7435	.4954
3	.3429	.5144	2.4691	3.4008	3.0178	2.713	.4954
4	.3429	.5144	2.4996	3.4332	3.0483	2.5606	.4954
5	.3772	.5487	2.713	3.4008	3.1093	2.5606	.4954
6	.4115	.583	.679	3.4656	3.2922	2.2862	.5335
7	.3963	.583	.7922	4.0486	3.0483	3.8104	.5716
8	.4115	.5487	.3772	4.0486	3.719	3.6885	.5335
9	3.6885	4.3286	2.452	.4268		.4458	4.0238
10	4.3591	5.1821	.4458			.4115	3.1398
11	4.7859	.2195	.4458	.3963		.3429	4.8468
12	4.603	.1943	.4458	.3963	.4191	.3086	4.4505
13	4.2981	.0038	.4458	.3963	.381	.4801	4.3896
14	4.0847	.0038	.4115		.3429	.4801	4.5115
15	3.9933	.0038	.3086	.3963	.4191	.4801	4.1457
16	3.9628	.0038	.4458	.3353	.4191	.4801	4.2981
17	.4268	.5716	.4115	.3963	.381	.5144	.5144
18	.4268	.5335	.4115	.3963	.381	.5487	.3772
19	.4877	.5716	.4458	.4268	.5716	.4801	.4115
20	.6173	.4572	.4954	.583	.4877	.5487	.5144
21	.583	.4572	.6097	.5487	.4877	.583	.4801
22	.6173	.4572	.5716	.5144	.4572	.5487	.4801
23	.4801	.3963	3.4979	3.0178	.5182	.5144	.4458
24	.3429	.5144	.2561	3.4332	3.0483	.4268	.5716
Max	4.7859	5.1821	3.4979	4.0486	3.719	3.8104	4.8468
Min	.3429	.0038	.2561	.3353	.3429	.3086	.3772
Avg	1.6969	.7592	1.1096	1.8316	1.6036	1.2855	1.7398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 303 / NIMBHORE AG FEEDER

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	2.1338	.3048	.4572	.4115	.3963	2.2672
2	2.1338	2.1338	.3048	.4572	.4115	.3963	2.2672
3	2.0729	2.1338	.3048	.4572	.3772	.3658	2.332
4	2.0424	2.1338	.3353	.4191	.3772	.3658	2.4291
5	2.0424	2.1338	.3658	.5335	.4458	.3963	2.5911
6	2.2558	2.2558	.4268	.5716	.4801	.4572	2.8826
7	2.7435	2.7435	.4268	.5335	.4801	.4268	2.1052
8	2.6825	2.6825	.3963	.5335	.4458	.3963	2.753
9	.3658	.4115	2.9264	2.9874		3.1398	.4115
10	.3658	.4115	2.6216			3.3836	.4458
11	.3658	.4115	3.2617	3.3227		3.2312	.4115
12	.3353	.3772	3.1398	3.0483	3.3684	2.9874	.3772
13	.3353	.4191	3.0788	2.9264	3.2065	3.0483	.4115
14	.3353	.4191	3.2922		3.2065	2.9874	.4115
15	.3658	.4191	3.4979	2.8045	3.2712	3.0483	.4801
16	.3353	.381	3.1398	2.8045	3.2388	3.0483	.4115
17	.3658	.4954	.3429	.3658	.4191	.3429	.4458
18	.3658	.4572	.4115	.3658	.4572	.4115	.4458
19	.3963	.5716	.5144	.4268	.5716	.4801	.4801
20	.5144	.4572	.6097	.5487	.5182	.5144	.5487
21	.5144	.4877	.6097	.5487	.4877	.5144	.5487
22	.4801	.4268	.5716	.5144	.4877	.4801	.5487
23	2.2558	1.9814	.5335	.4458	.4268	.4458	.4801
24	2.1948	2.1338	1.9204	.4954	.4115	.4268	.4572
Max	2.7435	2.7435	3.4979	3.3227	3.3684	3.3836	2.8826
Min	.3353	.3772	.3048	.3658	.3772	.3429	.3772
Avg	1.1666	1.1922	1.3891	1.1622	1.1191	1.3205	1.1226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 304 / WATHAR -NIMBLAK- AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1703	3.0483	.1829	.4954	.4801	.3658	2.5263
2	3.0483	2.9874	.1829	.4572	.4801	.3658	2.7206
3	2.9264	2.9264	.1829	.4572	.4458	.3353	2.7206
4	2.9264	2.8654	.1829	.4572	.4458	.3353	2.6558
5	2.9874	2.8654	.2134	.5716	.4801	.3963	3.4979
6	3.4751	3.5361	.2439	.5716	.5144	.4572	3.9514
7	3.7799	4.3286	.3048	.6097	.583	.5487	4.1133
8	4.2067	3.8104	.2439	.6097	.4115	.4877	4.1457
9	.4268	.3429		4.1152		4.1457	.3429
10	.3658	.4191	4.1457			3.8714	.3658
11	.3963	.4191	4.6639	4.4505		4.2676	.4458
12	.3658	.1524	4.6334	4.2372	4.4696	4.2676	.4458
13	.3963	.2286	4.1457	3.3532	4.2105	4.1762	.4458
14	.2439	.4191	3.8104		4.0809	3.9018	.4115
15	.3353	.4191	4.561	3.5361	3.1417	3.719	.4458
16	.3353	.4572	4.1457	3.6885	3.919	3.719	.4458
17	.3658	.4954	.3429	.2743	.2667	.3772	.4458
18	.2439	.4954	.4115	.3658	.3429	.3086	.4458
19	.2439		.3772	.4572	.5716	.5144	.5144
20	.583	.3048	.6478	.583	.4572	.583	.5487
21	.5487		.2667	.5144	.4572	.5144	.5487
22	.5487	.2439	.4191	.5144	.4268	.5144	.5144
23	2.9264	.5487	.4572	.4458	.4268	.4801	.4115
24	3.2312	3.1093	.5182	.4954	.4801	.3963	.4954
Max	4.2067	4.3286	4.6639	4.4505	4.4696	4.2676	4.1457
Min	.2439	.1524	.1829	.2743	.2667	.3086	.3429
Avg	1.5866	1.5647	1.5341	1.4209	1.2901	1.6270	1.4002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 307 / 22 KV SAKHARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.6859	.8002	.6859	.6516	.6859
2	.6859	.7202	.6859	.7621	.6516	.6516	.6859
3	.6859	.7202	.6859	.724	.6516	.4115	.6516
4	.6859	.7545	.7202	.8002	.6859	.6173	.7545
5	.0754	.7545	.7545	.9145	.7545	.7202	.823
6	.8916	.9259	.823	.9907	.8916	.7888	.8916
7	.7545	.7202	.6859	.7621	.7202	.7545	.7202
8	.8916	.7888	.7545	.8002	.7545	.7202	.823
9	.7888	.7202	.7545	.7545		.7202	.6859
10	.583	.7621	.7545			.7888	.6516
11	.583	.724	.7202	.8573		.8573	.6859
12	.6173	.8002	.7202	.7888	.7202	.7888	.6859
13	.6859	.8383	.6859	.823	.7545	.7888	.7202
14	.7202	.7621	.6859		.7888	.7888	.7545
15	.7202	.8002	.7545	.7888	.7888	.7888	.7202
16	.7545	.8383	.823	.7888	.8573	.7888	.7545
17	.7888	.823	.823	.7888	.823	.823	.823
18	.7888	.9145	.8573	.7888	.823	.8573	.7202
19	.8573	.9907	.9259	.8573	.9259	.9602	.8573
20	.9945	1.0288	1.2193	.9602	1.0631	1.0974	.9945
21	.9602	.9602	1.0288	.9259	.9259	.9602	.9602
22	.9602	.8916	1.0288	.8573	.823	.8916	.9602
23	.8573	.7888	.9145	.7545	.7888	.7888	.8573
24	.7888	.7545	.7545	.9145	.7202	.6859	.7545
Max	.9945	1.0288	1.2193	.9907	1.0631	1.0974	.9945
Min	.0754	.7202	.6859	.724	.6516	.4115	.6516
Avg	.7448	.8140	.8019	.8274	.7904	.7788	.7759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 308 / 22 KV NANDAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2058	.2401	.2667	.2401	.2058	.2058
2	.2401	.2058	.2058	.2667	.2401	.2058	.2058
3	.2401	.2058	.2058	.2667	.2401	.2058	.2058
4	.2401	.2058	.2058	.2667	.2401	.2058	.2058
5	.2743	.2401	.2743	.3048	.2401	.2058	.2401
6	.3086	.3086	.3086	.3429	.3086	.2058	.2743
7	.2743	.3086	.2743	.3429	.2743	.3086	.3086
8	.2743	.2401	.2401	.3048	.2401	.2401	.3086
9	.2401	.2401	.2743	.2743		.2058	.2743
10	.2058	.3048	.2743			.2743	.2743
11	.2743	.3048	.2743	.2743		.2058	.3429
12	.2743	.3048	.3429	.2401	.2743	.2743	.2743
13	.2401	.3048	.2743	.2401	.2401	.2401	.3086
14	.2058	.1905	.2058		.2058	.2401	.3086
15	.2743	.2286	.2401	.2058	.2743	.2743	.3086
16	.2743	.2667	.2401	.2058	.3086	.2743	.3086
17	.2743	.3048	.2743	.2401	.2401	.2743	.3429
18	.2401	.2667	.2401	.2401	.3086	.2743	.2743
19	.2743	.3429	.2743	.2401	.2743	.3086	.2743
20	.3429	.3429	.381	.3086	.3429	.3429	.3086
21	.3086	.3086	.3429	.3086	.3086	.3086	.3429
22	.3086	.3086	.3429	.2743	.3086	.3429	.2743
23	.2743	.2743	.3048	.2401	.2401	.2743	.2743
24	.2401	.2401	.2401	.2667	.2401	.2401	.2401
Max	.3429	.3429	.381	.3429	.3429	.3429	.3429
Min	.2058	.1905	.2058	.2058	.2058	.2058	.2058
Avg	.2643	.2689	.2701	.2691	.2662	.2558	.2786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 309 / 22 KV NIMBHORE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2743	.3048	.3086	.2743	.2743
2	.2401	.2743	.2401	.3048	.2743	.2743	.2743
3	.2401	.2743	.2401	.3048	.2743	.2743	.2743
4	.2401	.2743	.2401	.3048	.2743	.2743	.2743
5	.2743	.2743	.2743	.3429	.2743	.2743	.2743
6	.3086	.3086	.3086	.3429	.3086	.3086	.3086
7	.3086	.2743	.2743	.3429	.3086	.2743	.3086
8	.2743	.2401	.2743	.3429	.3086	.3086	.3086
9	.2401	.2401	.2401	.2401		.2743	.2743
10	.2401	.1905	.2058			.2401	.2401
11	.2743	.2286	.2058	.3086		.2743	.2743
12		.2286	.2743	.2743	.3086	.2401	.2401
13	.2743	.2667	.2743	.3086	.2401	.2743	.2743
14	.2743	.2667	.2058		.2401	.3086	.2743
15	.2743	.2667	.2401	.2743	.3086	.3086	.3086
16	.2743	.2667	.2743	.2743	.2743	.3429	.3086
17	.3429	.2667	.3429	.3429	.3086	.3429	.3086
18	.3429	.2667	.3086	.3429	.3086	.3429	.3086
19	.3429	.3048	.4115	.3772	.4115	.3772	.3429
20	.4115	.3772	.4954	.4115	.4115	.4458	.3772
21	.4115	.3772	.4191	.3772	.3772	.4115	.3772
22	.3772	.3429	.4191	.3772	.3772	.3772	.3772
23	.3086	.3086	.381	.3772	.3429	.3429	.3429
24	.2743	.3086	.2743	.3429	.3086	.3086	.3086
Max	.4115	.3772	.4954	.4115	.4115	.4458	.3772
Min	.2401	.1905	.2058	.2401	.2401	.2401	.2401
Avg	.2967	.2792	.2958	.3282	.3119	.3115	.3015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 403 / cummines india limited

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.2858	.3429	.3429	.2858	.3429
2	.3429	.3429	.2858	.3429	.3429	.2858	.3429
3	.3429	.3429	.2858	.2858	.3429	.2858	.3429
4	.3429	.3429	.2858	.2858	.3429	.2858	.2858
5	.3429	.3429	.2858	.2858	.3429	.2858	.3429
6	.4001	.2858	.3429	.3429	.4001	.3429	.4001
7	.4001	.2858	.4001	.4572	.4001	.4572	.4001
8	.4001	.2858	.4572	.5144	.4572	.4572	.4572
9	.5144	.2858	.5144	.5716		.5144	.5716
10	.5716	.4001	.6287			.743	.8002
11	.6287	.4572	.8002	.6859		.743	.8002
12	.5716	.4001	.6859	.6859	.6859	.6859	.8002
13	.6287	.2858	.8002	.6859	.8573	.743	.9145
14	.5716	.2858	.6859		.6859	.8002	.8573
15	.6287	.3429	.6859	.6859	.6859	.743	.743
16	.6287	.2858	.743	.743	.743	.8002	.8002
17	.6287	.2858	.6287	.6287	.743	.8573	.8002
18	.5144	.2858	.5144	.4001	.5144	.5716	.5716
19	.5144	.2858	.5144	.4572	.5144	.5716	.5716
20	.4572	.2858	.4572	.4572	.5144	.5144	.4572
21	.4572	.2858	.4572	.4572	.4572	.5144	.4572
22	.4001	.2858	.4001	.4001	.4001	.3429	.4001
23	.3429	.3429	.3429	.3429	.3429	.2858	.2858
24	.3429	.3429	.2858	.3429	.3429	.2858	.2858
Max	.6287	.4572	.8002	.743	.8573	.8573	.9145
Min	.3429	.2858	.2858	.2858	.3429	.2858	.2858
Avg	.4715	.3215	.4906	.4728	.4981	.5168	.5430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 404 / tata cumines ltd

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7497	4.2695	1.6004	4.5668	4.7954	4.8468	4.8354
2	4.6982	3.1093	1.6004	4.3439	4.8297	4.8468	4.8411
3	4.4753	2.9607	1.6004	3.4294	4.121	4.7211	4.0809
4	4.3896	2.8635	1.5661	3.0921	3.7609	4.2239	4.0409
5	4.3038	2.7778	1.6403	3.0979	3.5837	4.0409	4.0238
6	5.8699	2.715	4.081	5.0983	5.1269	5.8128	5.7156
7	6.933	1.8576	7.2931	6.8759	6.6872	6.9101	6.5844
8	7.2017	1.7204	7.2017	7.1273	6.19	6.4872	6.7787
9	7.0416	1.366	7.316	6.8587	4.784	6.8873	6.2986
10	6.8073	2.5035	7.7389	5.2812	5.4184	7.6246	7.2188
11	7.0131	3.0179	7.1617	6.6416	5.2298	7.4874	7.1045
12	7.1845	3.0179	7.4246	6.7158	7.0302	7.7275	6.693
13	6.8244	2.795	7.3731	6.4129	6.9159	7.3217	6.4587
14	7.253	2.8178	7.2931	4.9726	6.8759	7.0244	6.5958
15	7.1045	2.7721	7.2588	6.813	7.0931	7.0244	6.893
16	6.9845	3.2179	7.1159	6.7844	7.1617	7.1788	7.236
17	7.1159	3.155	7.1045	6.7215	6.8187	7.0587	7.3217
18	7.2759	2.5034	7.1559	6.6815	7.0702	7.1273	7.1159
19	7.3389	1.4346	7.1788	6.9845	7.1674	6.8644	7.3731
20	7.2817	1.4574	7.013	6.6759	7.476	6.8816	7.596
21	7.2302	1.4574	7.1674	6.7273	7.2474	6.8988	7.356
22	6.8587	1.5489	6.7787	6.5444	6.7901	6.8016	6.8702
23	5.4641	1.6347	5.7042	5.5556	5.3155	5.2527	5.9385
24	4.9955	2.3549	4.4125	5.1498	4.9497	4.5497	5.0869
Max	7.3389	4.2695	7.7389	7.1273	7.476	7.7275	7.596
Min	4.3038	1.366	1.5661	3.0921	3.5837	4.0409	4.0238
Avg	6.3498	2.4720	5.7409	5.7980	5.9350	6.3167	6.2524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 301 / 22KV Barad ag
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2641	.3018	.9054	.6036	.6413	.6036
2	.3018	.2641	.3018	.9054		.6413	.6036
3	.3018	.2641	.3018	.7545		.6413	.6036
4	.3018	.3018	.3018	.679		.6413	.5658
5	.3395	.3395	.3395	.5658		.9431	.7545
6	.3772	.415	.3395	.8676		1.2449	.8676
7	.3772	.3772		1.2071		1.358	1.0185
8	.3018	.3018	.3018	1.0562		.9054	.8299
9	.9431	1.2826	.2263	.2263	.2263	.2263	.679
10	1.0562		.1886		.2263	.1886	.8676
11	.9431	1.2071	.1886	.1509		.2263	.6036
12	.9808	1.0562	.3018	.1509		.1509	.8299
13	.8573	.8299	.2263	.1509	.2263	.1509	.679
14	.9054	.7545		.2263	.2263	.1509	.6036
15	.8676	.7545	.2263	.2641	.1886	.2641	.7545
16	1.0185	.9431	.2263	.2263	.1886	.2641	.7167
17	.2263	.2263	.2641	.2263	.1886	.2263	.1886
18	.2641	.2641	.2641	.3018	.2263	.3018	.2263
19	.3395	.3772	.3395	.3018	.3772	.3772	.3018
20	.4527	.3772	.4527	.3772	.4527	.4527	.3772
21	.3772	.3772	.4527	.3772	.415	.3772	.3772
22	.3018	.3395	.4527	.3395	.3395	.3772	.3395
23	.2641	.3018	.8676	.6413	.3018	.3018	.3018
24	.3018	.2641	.3018	.9054	.6413	.3018	.2641
Max	1.0562	1.2826	.8676	1.2071	.6413	1.358	1.0185
Min	.2263	.2263	.1886	.1509	.1886	.1509	.1886
Avg	.5293	.5166	.3258	.5134	.3219	.4731	.5816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 302 / MUNJAWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.5281	.5281	3.9609	3.8477	3.81	3.546
2	.4527	.5281	.5281	3.9609		3.8477	3.546
3	.4527	.5281	.5281	3.9609		3.8855	3.6214
4	.5658	.6036	.6413	3.81		3.9609	3.6214
5	.6413	.679	.7545	4.1118		4.5268	3.9609
6	.7545		.8676	5.0172		5.5076	4.3759
7	.8676	.9431	.9054	6.3375		6.1866	5.3567
8	.7545	.7922	.8676	6.1866		5.8848	5.2058
9	5.3944	6.0357	.6413	.5658	.5281	.5658	4.6776
10	5.9225	6.3752	.4527		.4527	.4904	5.3189
11	6.2243	6.677	.4527	.4904		.4527	5.6207
12	6.1488	6.1866	.3772	.5281		.415	5.583
13	6.0357	6.0734	.415	.4527	.1886	.415	5.583
14	5.7339	5.5076	.4904	.4527	.2263	.3772	5.6962
15	5.6584	5.4698	.4904	.4904	.2263	.415	5.583
16	5.5076	5.168	.1886	.4904	.2263	.1886	
17		.415	.4904	.415	.2263	.1886	.4527
18		.5281	.5281	.5281	.2641	.2641	.2641
19	.8299	.8676	.7545	.7167	.9054	.7922	.7167
20	.9054	.8676		.7545	.8676	.9054	.7922
21	.7922	.7545	.8048	.7545	.7167	.7545	.679
22	.679	.6413	.7167	.679	.679	.679	.6036
23	.5658	.5658	4.2627	4.0364	.5658	.6413	.5658
24	.4527	.5281	.5281	4.0364	3.9609	.4904	.5658
Max	6.2243	6.677	4.2627	6.3375	3.9609	6.1866	5.6962
Min	.4527	.415	.1886	.415	.1886	.1886	.2641
Avg	2.5360	2.4897	.7484	2.2929	.9255	1.9019	3.3016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 303 / ANDHRUD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5082	3.2819	3.0556	.5658	.6036	.6413	.6413
2	3.5082	3.1687	3.0556	.5658		.6413	.6413
3	3.5082	3.1687	3.0933	.5658		.679	.6413
4	3.6591	3.3196	3.0933	.7545		.7545	.7167
5	4.0741	3.5082	3.2819	.9054		.8676	.9054
6	4.3759	4.3381	3.5082	1.1317		1.1317	1.1317
7	4.9794	5.3567	4.3759	1.094		.9808	1.0562
8	4.7908	4.7908	4.3759	.9054		.7922	.7922
9	.5658	.6036	4.2627	4.6776	4.1872	4.8663	.679
10	.3772	.5658	4.0364		4.2627	5.168	.6036
11	.4527	.4904	3.8477	5.0926		4.7908	.6413
12	.415	.4904	4.0364	4.5645		4.8663	.6036
13	.1886	.5281	3.81	4.3004	4.3381	4.5645	.5658
14	.2641	.5281	3.4328	4.1495	3.9986	3.8855	.5658
15	.4527	.5658	3.9232	3.9232	3.9232	4.3004	.4904
16	.5281	.415	3.6591	4.0364	4.0364	4.5645	
17	.2263	.415	3.2065	.4527	.2263	.2263	.5281
18	.2641	.4527	.8676	.5281	.2641	.4904	.6036
19	.9054	.9808	.8676	.7922	.4904	.9054	.8676
20	.9431	.9808		.9054	.9431	.9808	.8676
21	.8676	.7922	.9431	.7922	.8676	.8299	.7922
22	.7545	.7545	.9054	.7545	.7545	.7922	.7545
23	3.2819	3.1687	.7922	.679	.679	.7167	.6413
24	3.5082	3.3951	3.0556	.6413	.6036	.679	.679
Max	4.9794	5.3567	4.3759	5.0926	4.3381	5.168	1.1317
Min	.1886	.415	.7922	.4527	.2263	.2263	.4904
Avg	1.9333	1.9192	3.0211	1.8599	2.0119	2.0465	.7135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 304 / Barad Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6815	1.6689	1.7535	1.9022	1.773	1.9285	1.821
2	1.6689	1.5981	1.7238	1.8507	1.174	1.8485	1.8199
3	1.6529	1.6072	1.6963	1.8507	1.1557	1.8142	1.789
4	1.757	1.6678	1.8347	1.8702	1.1786	1.8119	1.8736
5	2.0244	1.9605	2.1754	2.1422	1.262	2.2039	2.2897
6	2.3663	2.3834	2.5423	2.7344	1.653	2.715	2.6749
7	1.9856	2.5023	2.4897	2.5275	1.6027	2.5035	2.5275
8	1.6152	1.9455	2.0074	2.0645	1.2506	2.1547	2.0074
9	1.4723	1.6118	1.6804	1.6827	1.501	1.6392	1.8462
10	1.8542	1.557	1.6038	1.158	1.4712	1.7546	1.8267
11	1.7546	1.6073	1.7958	1.5912	1.1145	1.8359	1.7524
12	1.7249	1.6004	1.6586	1.6712	1.2323	1.8199	1.8325
13	1.7466	1.5593	1.6918	1.781	1.8255	1.853	1.8473
14	1.7055	1.5947	1.6312	1.6575	1.8118	1.7982	1.7741
15	1.6655	1.4987	1.6312	1.7055	1.6918	1.8862	1.7032
16	1.7341	1.6141	1.8656	1.8084	1.7272	1.9296	1.7261
17	1.6598	1.7055	1.9125	1.6175	1.7798	1.7649	1.6644
18	1.6438	1.6769	1.7696	1.7901	1.7558	1.9685	1.6061
19	2.3457	2.4646	2.7778	2.2988	2.4692	2.5355	2.3194
20	2.5754	2.6383	2.8875	2.4874	2.7447	2.7824	2.6235
21	2.4337	2.4772	2.7367	2.3103	2.6177	2.6417	2.5686
22	2.2393	2.2999	2.5686	2.1593	2.4566	2.4669	2.38
23	1.9033	2.0028	2.2966	1.9764	2.1308	2.189	2.1365
24	1.7409	1.8187	1.9387	1.997	1.8747	1.957	1.989
Max	2.5754	2.6383	2.8875	2.7344	2.7447	2.7824	2.6749
Min	1.4723	1.4987	1.6038	1.158	1.1145	1.6392	1.6061
Avg	1.8730	1.8775	2.0279	1.9431	1.7189	2.0751	2.0166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 305 / 22 KV GUNAWARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4904	.4904	.4904	.4904	.4904	.5281
2	.5281	.4904	.4904	.4904		.4904	.5281
3	.5281	.5281	.4904	.5281		.4904	.5281
4	.6036	.5658	.5658	.5281		.5658	.5658
5	.7167	.6413	.679	.6413		.7167	.7922
6	.8299	.8299	.7922	.8676		.9431	.9431
7	.7922	.8676	.8676	.7922		.9431	.9808
8	.7167	.679	.7167	.7545		.7545	.8299
9	.6036	.679	.5658	.6036	.6413	.6413	.7167
10	.5658	.679	.5658		.6413	.679	.6413
11	.6036	.6413	.3395	.6036		.6036	.7545
12	.6413	.6036	.5658	.6413			.679
13	.5658	.5281	.6036	.4527	.5281	.5658	.5658
14	.5281	.4904	.5658	.4904	.5281	.5281	.4527
15	.5281	.5281	.6413	.4904	.5281	.5658	.5658
16	.5658	.4904	.6413	.5281	.5658	.6036	.5658
17	.6413	.5658	.679	.4904	.6413	.4904	.679
18	.5658	.6036	.7167	.6036	.7167	.7922	.679
19	.8676	.8299	.8299	.8676	.9431	.7922	.8676
20	.8676	.9054	.9431	.8676	.9808	1.0185	.9808
21	.7922	.7922	.8299	.7922	.7922	.8299	.8676
22	.7167	.6413	.7167	.6413	.7167	.7167	.679
23	.5281	.5281	.6413	.5658	.6036	.6413	.6413
24	.5281	.4904	.4904	.4904	.4904	.3772	.5658
Max	.8676	.9054	.9431	.8676	.9808	1.0185	.9808
Min	.5281	.4904	.3395	.4527	.4904	.3772	.4527
Avg	.6397	.6287	.6429	.6183	.6539	.6626	.6916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 306 / 22 KV Rajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4302	.4786	.4257	.4938	.4893	.5803	.6032
2	.3997	.4618	.4013	.4771	.314	.5605	.5197
3	.3799	.4634	.3952	.471	.3231	.5559	.5106
4	.3677	.4694	.3982	.5087	.3307	.559	.4938
5	.4405	.5193	.4847	.6089	.3506	.6226	.6299
6	.647	.6726	.7137	.7911	.4313	.7412	.7153
7	.7384	.7808	.8814	.9583	.6173	.7537	.8372
8	.6657	.7129	.7282	.871	.567	.7022	.7068
9	.538	.6893	.6637	.6504	.5773	.5685	.6439
10	.5956	.5045	.6291	.41	.6485	.6759	.8063
11	.591	.6637	.6744	.6835	.4496	.6531	.8433
12	.65	.4298	.6698	.679	.4298	.5929	.8265
13	.6184	.7201	.7079	.6535	.6424	.5457	.7399
14	.5262	.6661	.5899	.5594	.5731	.4573	.599
15	.4832	.6988	.6424	.5864	.5437	.498	.5757
16	.5742	.6957	.6199	.5849	.5925	.5757	.349
17	.5274	.6367	.5997	.5563	.5925	.4969	.5967
18	.4954	.6683	.6032	.4409	.4836	.5278	.5746
19	.5388	.7697	.6893	.4736	.5026	.5266	.5224
20	.6973	.9195	.5792	.7323	.8082	.8947	.7595
21	.6698	.7704	.7217	.6672	.775	.8951	.7354
22	.6352	.687	.6306	.6108	.6698	.8174	.7064
23	.559	.57	.5864	.5502	.6047	.7552	.6306
24	.4954	.503	.5289	.506	.5639	.6306	.6093
Max	.7384	.9195	.8814	.9583	.8082	.8951	.8433
Min	.3677	.4298	.3952	.41	.314	.4573	.349
Avg	.5527	.6313	.6069	.6052	.5367	.6328	.6473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 307 / 22 KV Nimblak AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.546	3.2819	3.0933	.2641	.2263	.3395	.3018
2	3.546	3.0933	3.0933	.2641		.3395	.3018
3	3.546	3.131	3.0933	.2641		.3018	.3018
4	3.5837	3.2819	3.2065	.2641		.3018	.3018
5	3.6591	3.3951	3.3196	.3018		.3395	.3395
6	3.7723	3.8477	3.4705	.3395		.3772	.3772
7	4.0741	4.225	3.5082	.3395		.3772	.3772
8	3.9609	3.8477	3.6591	.3395		.2641	.3395
9	.2263	.2641	3.131	3.7723	4.0741	3.9609	.1886
10	.2263	.2263	3.6969		4.0364	.5281	.2263
11	.2263	.1886	3.9232	4.225		4.2627	.2263
12	.2641	.1886	3.6591	4.2627		3.131	.2263
13	.2263	.2641	3.2442	3.8855	4.0741	3.7346	.2263
14	.2263	.2263	3.3951	3.9232	3.8855	3.5837	.1886
15	.2263	.2263	3.546	3.8477	3.5082	3.8477	.2263
16	.2641	.2263	3.3951	3.7346	3.81	3.8855	
17	.2263	.2263	3.0933	.2263	.1886	.1886	.2263
18	.3018	.3018	.3018	.2641	.2641	.2641	.2263
19	.415	.3395	.3395	.3395	.3772	.3395	.3395
20	.415	.3395		.3395	.3395	.415	.3018
21	.3772	.3018	.3772	.3395	.415	.3395	.3018
22	.3018	.3395	.3395	.3018	.3772	.3395	.2641
23	3.4328	3.0556	.2641	.2641	.3395	.3395	.2641
24	3.546	3.3951	3.0933	.2641	.2641	.3395	.3018
Max	4.0741	4.225	3.9232	4.2627	4.0741	4.2627	.3772
Min	.2263	.1886	.2641	.2263	.1886	.1886	.1886
Avg	1.6913	1.5922	2.7062	1.4072	1.7453	1.3392	.2772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 301 / ADARKI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.3717	.1029	.1029	.1029	.1029	1.0288
2	1.0974	1.2689	.1029	.1029	.1029	.1029	1.0288
3	1.0288	1.3032	.0686	.1029	.1029	.1029	.9945
4	1.166	1.2689	.0686	.1029	.1029	.1029	.9945
5	1.2346	1.3717	.0686	.0686	.1029	.1029	1.0288
6	1.4403	1.5432	.0686	.1029	.1029	.1029	1.5089
7	1.749	2.1262	.1029	.1029	.1029	.1029	2.1262
8	1.749	1.989	.1029	.1029	.1029	.1372	1.9204
9	.1029	.1029	1.8519	1.7833	1.8176	1.989	.0686
10	.1029	.0686			1.9547	1.8861	.0686
11	.1029	.1029	2.1262	1.8176		1.8519	.1029
12	.1029	.1029	1.9547	1.8519		1.9204	.1029
13	.1029	.0686	1.9547	1.7833	1.0631	1.749	.1029
14	.1029	.1029	1.7833		1.749	1.6804	.1029
15	.1029	.1029	1.8519	1.4746	1.7833	1.749	.1029
16	.1029	.1029	1.989	1.7833	1.989	1.8519	.1029
17	.1372	.0686	.0686	.1029	.0686	.1029	.1029
18	.1029	.1029	.1029	.1029	.1029	.1029	.1029
19	.1372	.1372	.0034	.1029	.1372	.1372	.1372
20	.1372	.1372	.1372	.1372	.1372	.1372	.1715
21	.1372	.1372	.1372	.1372	.1372	.1715	.1372
22	.1372	.1029	.1372	.1372	.1372	.1372	.1372
23	1.4403	1.2346	.1372	.1372	.1029	.1372	.2401
24	1.166	1.5089	1.1317	.1029	.1029	.1029	.1029
Max	1.749	2.1262	2.1262	1.8519	1.989	1.989	2.1262
Min	.1029	.0686	.0034	.0686	.0686	.1029	.0686
Avg	.6159	.6845	.6980	.5565	.5503	.6902	.5216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 302 / BIBI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.0034	.7545	.7888	.8573	.5487	.0034
2	.0034	.0034	.7545	.7888	.823	.6173	.0034
3	.0034	.0034	.7545	.7888	.823	.583	.0034
4	.0034	.0034	.7545	.7888	.823	.6516	.0034
5	.0034	.0034	.7545	.823	.8573	.823	.0034
6	.0034	.0034	1.166	1.166	.9945	1.0974	.0034
7	.0034	.0034	1.3032	1.3717	1.3717	1.406	.0034
8	.0034	.0034	1.2346	1.3375	1.166	1.2003	.0034
9	1.166	1.2689	.0034	.0034	.0034	.0034	1.4746
10	1.5089	1.406	.0034		.0034		1.6118
11	1.3717	1.4403	.0034	.0034		.0034	1.6118
12	1.4403	1.3375	.0034	.0034		.0034	1.5775
13	1.3717	1.166	.0034	.0034	.0034	.0034	1.4746
14	1.3717	1.2003	.0034		.0034	.0034	1.5089
15	1.3717	1.3032	.0034	.0034	.0034		1.6118
16	1.406	1.3032	.0034	.0034	.0034	.0034	1.6461
17	.0034	.0034	.0034	.0034	.0034	.0034	.0034
18	.0034	.0034	.0034	.0034	.0034	.0034	.0034
19	.0034	.0034	.0034	.0034	.0034	.0034	.0034
20	.0034	.0034	.0034	.0034	.0034	.0034	.0034
21	.0034	.0034	.0034	.0034	.0034	.0034	.0034
22	.0034	.0034	.0034	.0034	.0034	.0034	.0034
23	.0034	.0034	.7545	.7888	.0034	.0034	.0034
24	.0034	.0034	.0034	.7888	.8573	.0034	.0034
Max	1.5089	1.4403	1.3032	1.3717	1.3717	1.406	1.6461
Min	.0034	.0034	.0034	.0034	.0034	.0034	.0034
Avg	.4609	.4367	.3451	.4305	.3917	.3170	.5238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 303 / MULIKWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.0034	.4115	.3772	.4458	.5144	.0034
2	.0034	.0034	.3772	.3772	.4115	.5487	.0034
3	.0034	.0034	.3772	.3772	.4115	.5144	.0034
4	.0034	.0034	.3772	.3772	.4115	.583	.0034
5	.0034	.0034	.3772	.4115	.4115	.6516	.0034
6	.0034	.0034	.6173	.6516	.5487	.7888	.0034
7	.0034	.0034	.7888	.7888	.7545	.9259	.0034
8	.0034	.0034	.6173	.6516	.6173	.7888	.0034
9	.6173	.583	.0034	.0034	.0034	.0034	.823
10	.6516	.7202	.0034		.0034		.9602
11	.583	.6173	.0034	.0034			.8916
12	.5487	.6173	.0034	.0034			.8573
13	.583	.1029	.0034	.0034	.0034		.7202
14	.5487	.1029	.0034		.0034		.7888
15	.5144	.3429	.0034	.0034	.0034		.8573
16	.583	.5487		.0034	.0034	.0034	.823
17	.0034	.0034	.0034	.0034	.0034	.0034	.0034
18	.0034	.0034	.0034	.0034	.0034	.0034	.0034
19	.0034	.0034	.0034	.0034	.0034	.0034	.0034
20	.0034	.0034	.0034	.0034	.0034	.0034	.0034
21	.0034	.0034	.0034	.0034	.0034	.0034	.0034
22	.0034	.0034	.0034	.0034	.0034	.0034	.0034
23	.0034	.0034	.3772	.4458	.0034	.0034	.0034
24	.0034	.0034	.0034	.3772	.4801	.0034	.0034
Max	.6516	.7202	.7888	.7888	.7545	.9259	.9602
Min	.0034	.0034	.0034	.0034	.0034	.0034	.0034
Avg	.1952	.1537	.1899	.2216	.2062	.2972	.2823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 304 / ADARKI GOANTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2401	.2401	.2401	.2401	.2058
2	.2058	.2058	.2058	.2058	.2058	.2058	.2058
3	.2058	.2058	.2058	.2058	.2058	.2058	.2058
4	.2058	.2058	.2058	.1715	.2058	.2058	.1715
5	.2058	.2401	.2058	.1372	.2058	.2058	.1715
6	.2058	.2743	.2058	.1372	.2401	.2058	.2401
7	.2058	.2743	.1715	.1715	.2058	.2058	.2058
8	.2743	.2743	.1715	.1715	.1715	.2058	.1715
9	.2401	.2743	.2401	.2401	.2401	.2743	.2743
10	.2401	.2401	.3086		.2401	.3086	.2401
11	.2743	.2743	.2743	.3429		.2743	.3429
12	.3429	.2401	.3086	.3086		.2743	.3429
13	.3429	.2401	.2743	.2743	.1372	.2743	.2401
14	.2743	.2058	.2743		.2743	.2743	.2743
15	.2743	.2401	.2743	.2743	.2743	.3086	.2743
16	.2743	.2401		.2401	.2401	.3086	.2743
17	.2743	.2401	.2401	.3086	.2058	.3086	.2743
18	.2743	.2058	.2743	.2743	.2058	.3086	.3086
19	.2743	.2401	.2401	.2401	.2401	.3086	.2743
20	.3429	.2743	.3429	.3086	.3429	.3086	.3086
21	.3429	.3086	.3086	.2743	.2743	.2743	.2743
22	.3086	.2743	.2743	.2401	.2743	.3086	.2743
23	.2743	.2743	.2401	.2401	.2743	.3086	.2743
24	.2401	.2401	.2401	.2401	.2401	.2401	.2401
Max	.3429	.3086	.3429	.3429	.3429	.3086	.3429
Min	.2058	.2058	.1715	.1372	.1372	.2058	.1715
Avg	.2643	.2472	.2490	.2385	.2338	.2643	.2529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 305 / BIBI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1715	.1372	.2058	.1372	.2058	.2401
2	.1715	.1715	.1372	.1715	.1372	.1715	.2401
3	.1372	.1715	.1372	.1715	.1372	.1715	.2401
4	.1715	.1715	.1372	.1715	.1372	.1715	.2401
5	.1715	.2401	.1372	.1372	.1372	.1715	.2401
6	.2058	.1715	.1715	.2058	.1372	.2058	.3086
7	.2058	.2058	.2401	.2058	.1715	.2743	.3086
8	.2401	.2401	.2058	.2401	.2058	.2743	.3086
9	.3429	.2058	.2401	.3772	.3086	.3772	.3086
10	.4458	.2058	.3772		.4115	.3429	.4115
11	.4458	.1372	.2743	.3086		.4458	.4801
12	.4458	.1372	.2401	.2743		.4458	.5487
13	.1715	.1372	.2058	.2401	.3429	.2401	.3086
14	.2401	.1372	.2401		.3086	.2401	.3772
15	.3429	.1715	.2743	.3772	.4115	.2743	.4115
16	.3429	.1372	.3086	.3086	.3429	.3772	.3772
17	.3772	.1715	.2743	.3429	.3086	.4115	.4801
18	.1715	.1715	.2743	.2058	.3429	.2401	.2058
19	.2058	.2058	.2058	.2058	.2401	.3086	.3086
20	.2743	.2743	.2743	.2401	.2743	.3772	.3429
21	.2401	.2743	.2401	.2058	.2743	.3429	.3429
22	.2401	.2058	.2058	.1715	.2401	.3086	.3429
23	.2058	.1715	.2058	.1715	.2058	.2743	.3086
24	.1715	.1715	.1372	.2058	.1372	.2058	.2401
Max	.4458	.2743	.3772	.3772	.4115	.4458	.5487
Min	.1372	.1372	.1372	.1372	.1372	.1715	.2058
Avg	.2572	.1858	.2201	.2338	.2432	.2858	.3301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 306 / Siddhivinayak Bio-Energy NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.0034	.0034	.0034	.0034	.0034	.0034
2	.0034	.0034	.0034	.0034	.0034	.0034	.0034
3	.0034	.0034	.0034	.0034	.0034	.0034	.0034
4	.0034	.0034	.0034	.0034	.0034	.0034	.0034
5	.0034	.0034	.0034	.0034	.0034	.0034	.0034
6	.0034	.0034	.0034	.0034	.0034	.0034	.0034
7	.0034	.0034	.0034	.0034	.0034	.0034	.0034
8	.0034	.0034	.0034	.0034	.0034	.0034	.0034
9	.0034	.0034	.0034	.0034	.0034	.0034	.0034
10		.0034	.0034		.0034	.0034	.0034
11	.0034	.0034	.0034	.0034		.0034	.0034
12	.0034	.0034	.0034	.0034		.0034	.0034
13	.0034	.0034	.0034	.0034	.0034	.0034	.0034
14	.0034	.0034	.0034		.0034	.0034	.0034
15	.0034	.0034	.0034	.0034	.0034	.0034	.0034
16	.0034	.0034	.0034	.0034	.0034	.0034	.0034
17	.0034	.0034	.0034	.0034	.0034	.0034	.0034
18	.0034	.0034	.0034	.0034	.0034	.0034	.0034
19	.0034	.0034	.0034	.0034	.0034	.0034	.0034
20	.0034	.0034	.0034	.0034	.0034	.0034	.0034
21	.0034	.0034	.0034	.0034	.0034	.0034	.0034
22	.0034	.0034	.0034	.0034	.0034	.0034	.0034
23	.0034	.0034	.0034	.0034	.0034	.0034	.0034
24	.0034	.0034	.0034	.0034	.0034	.0034	.0034
Max	.0034	.0034	.0034	.0034	.0034	.0034	.0034
Min	.0034	.0034	.0034	.0034	.0034	.0034	.0034
Avg	.0034	.0034	.0034	.0034	.0034	.0034	.0034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 302 / ASU AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477		1.669	1.9166	1.8442	.1753	.1867
2	.2401		1.7185	1.9128	1.749	1.7414	.1791
3	.2629		1.8023	1.909	1.768		.1867
4	.2896		1.8861	1.9852	1.7985	1.829	.1905
5	.3201		2.0652	2.3243	2.2901	2.2634	.1981
6	.3582		2.713	2.6711	2.6368	2.7054	.2401
7	.3429		3.2503	2.6673	3.0521	3.0712	.2515
8			2.8387	3.1245		2.8616	.1372
9			.3353	.061		.0495	2.3967
10			.3125	.0381			
11		3.3913	.2934		.0686	.4077	3.4598
12		3.6732	.301			.0419	3.4179
13			.2705				3.3951
14		2.9835					3.1817
15		2.9874			.0953	.0419	3.1017
16		3.0521				.0648	3.0255
17		.1943	.2782	.08	.0991	.08	.1486
18		.2743	.301	.0838		.1219	.1677
19		.3963	.3506	.0914	.1486	.1448	.2172
20		.4115	.4268	.0953	.1753	.1753	.2553
21		.4077	.3849	.0838		.202	.2286
22		.4001	.3696	.0838	.141	.2096	.2096
23		.362	1.7909	1.8633	.061	.1981	.2096
24	.2629		.362	2.0767	2.0005	.1334	.1905
Max	.3582	3.6732	3.2503	3.1245	3.0521	3.0712	3.4598
Min	.2401	.1943	.2705	.0381	.061	.0419	.1372
Avg	.2906	1.5445	1.1295	1.2816	1.1952	.8259	1.0946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 303 / 22 KV GOKHALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1257		.1372	.1334	.141		.141
2	.1219		.1296	.1334	.1334	.1372	.141
3	.1257		.1334	.1296	.1334		.141
4	.1372		.1372	.141	.1372	.1867	.1448
5	.1829		.1829	.1905	.1943	.2096	.1867
6	.2324		.2515	.2401	.2477	.2705	.2401
7	.2172		.221	.2172	.1905	.2362	.2172
8			.1067	.1296	.1334	.1372	.1334
9			.0686	.1067		.1143	.1029
10			.0686				2.3967
11		.1029	.0991		.1105	.0991	.1181
12		.1105	.1067		.1448	.0953	.1143
13		.1257	.1105			.141	.0991
14		.1105			.1372	.1181	.1181
15		.1181				.1029	.1181
16		.141			.141	.0991	.1448
17		.1257	.1448	.1638		.1257	.0991
18		.1257	.1296	.1829	.0991	.1524	
19		.1562	.1753	.1981		.1562	.1524
20		.2248	.2096	.2286	.2172	.2362	.2248
21		.1829	.202			.1867	.1638
22		.1867	.1791	.08	.1791	.1791	.16
23		.1486	.1562	.1524		.16	.1448
24	.1257		.141	.1334	.1448	.1486	.141
Max	.2324	.2248	.2515	.2401	.2477	.2705	2.3967
Min	.1219	.1029	.0686	.08	.0991	.0953	.0991
Avg	.1586	.1430	.1472	.1600	.1553	.1568	.2454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 304 / 22 KV ASU GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2972		.2553	.2667	.2705		.3086
2	.2972		.2439	.2629	.2591	.2629	.3086
3	.2858		.2477	.2591	.2667		
4	.2743		.2591	.2629	.2782	.2743	.3163
5	.3658		.282	.3315	.3429	.3391	.3277
6	.4572		.3887	.3963	.4306	.4915	.4496
7	.4534		.4153	.4039	.2591		.221
8			.3734	.3467	.2096	.362	.4306
9			.3658	.3429		.3772	.3125
10			.3125	.3163			.3125
11			.2591			.2934	.3277
12			.2477			.3277	.3277
13			.2629			.2705	.2972
14		.2934				.2782	.2743
15						.2896	.282
16		.2896				.301	.3163
17		.3239	.3582	.4534		.3429	
18		.423	.381	.3887		.4039	
19		.4306	.423	.4725		.4572	.3887
20		.4649	.503	.4763		.5335	.5296
21		.423	.4877	.4001		.4801	.4382
22		.3925	.423	.3925		.4153	.4153
23		.2858	.3239	.3353		.3582	.3772
24	.301		.2858	.2743		.2858	.3086
Max	.4572	.4649	.503	.4763	.4306	.5335	.5296
Min	.2743	.2858	.2439	.2591	.2096	.2629	.221
Avg	.3415	.3696	.3380	.3546	.2896	.3572	.3462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 301 / Wathar- N Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335	1.5844	.0038	.0038	.0036	.0038	1.0185
2	1.4335	1.5844	.0038	.0038	.0036	.0038	1.1317
3	1.4335	1.5844	.0038	.0038	.0036	.0038	1.1317
4	1.4712	1.5844	.0038	.0038	.0036	.0038	1.3203
5	1.5089	1.6975	.0038	.0038	.0036	.0038	1.5089
6	1.8861	2.2634	.0038	.0038	.0036	.0038	1.9239
7	2.4143	2.7915	.0038	.0038	.0036	.0038	2.6406
8	2.4897	2.4143	.0038	.0038	.0036	.0038	2.5274
9	.0038	.0038	2.452	2.2634	2.0332	2.037	.0038
10	.0038	.0038	2.0748		2.3137	2.3765	.0038
11	.0038	.0038	1.9616	2.3529		2.4143	.0038
12	.0038	.0038	2.1502	1.9909		2.452	.0038
13	.0038	.0038	1.773	1.97	2.0748	2.2634	.0038
14	.0038	.0038	1.9616	2.0058	1.8861	2.1502	.0038
15	.0038	.0038	1.8107	1.8983	1.4712	1.9993	.0038
16	.0038	.0038	1.9993	1.7337	1.5466	1.9239	.0038
17	.0038	.0038	.0038	.0036	.0038		.0038
18	.0038	.0038	.0038	.0036	.0038	.0038	.0038
19	.0038	.0038	.0038	.0036		.0038	.0038
20	.0038	.0038	.0038	.0037	.0038	.0038	.0038
21	.0038	.0038	.0038	.0037	.0038	.0038	.0038
22		.0038	.0038	.0037	.0038	.0038	
23	1.3957	1.3957	.0038	.0036	.0038	.0038	.0038
24	1.4335	1.6598	1.3203	.0038	.0036	.0038	.0038
Max	2.4897	2.7915	2.452	2.3529	2.3137	2.452	2.6406
Min	.0038	.0038	.0038	.0036	.0036	.0038	.0038
Avg	.7369	.7755	.7317	.6206	.5419	.7684	.5765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 302 / Upalwe Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	1.6221	1.8861	1.3969	1.2449	.4527
2	.4527	.4527	1.6975	1.773	1.3611	1.2449	.4527
3	.4527	.4527	1.6975	1.773	1.2536	1.3203	.4527
4	.5281	.4527	1.773	1.773	1.182	1.5089	.4527
5	.6036	.6036	1.9993	1.773	1.3969	1.7353	.5658
6	.7545	.7922	2.5274	2.3765	2.0416	2.4143	.7545
7	.7167	.7167	2.6406	2.7915	2.5431	2.8292	.7167
8	.6036	.4904	2.5274	2.7161	2.1849	2.7915	.7167
9	2.4897	2.5274	.4904	.4527	.3224	.3772	2.8292
10	2.9424	2.6783	.4904		.394	.3395	2.8669
11	1.8107	2.6783	.3395			.3395	2.8669
12	2.5274	2.6406	.3772	.4298		.3772	2.9424
13	2.3765	2.5274	.3772	.4656	.3772	.3772	2.5274
14	2.2634	2.452	.3772	.4298	.415		2.6029
15	1.7353	2.3765	.3395	.4298	.3395	.3772	2.5652
16	2.1125	2.2634	.415	.4298		.3772	2.4897
17	.3395	.415	.415	.4024			.3772
18	.4527	.4904	.4527	.5121	.4527	.4527	.4527
19	.7922	.7545	.679	.695	.679	.7167	.6413
20	.7545	.8299	.7922	.7682	.7167	.7545	.7922
21	.7545	.7922	.7922	.7316	.7167	.7545	.7545
22	.6036	.7545	.7167	.695	.679	.7167	.679
23	.5281	.5658	1.8861	1.4327	.5658	.5281	.4527
24	.4527	.5281	.5281	1.8861	1.4632	.4904	.4904
Max	2.9424	2.6783	2.6406	2.7915	2.5431	2.8292	2.9424
Min	.3395	.415	.3395	.4024	.3224	.3395	.3772
Avg	1.1458	1.237	1.0814	1.2101	1.0241	1.0031	1.2873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 303 / Tathawada Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3957	1.3203	.3772	.3772	.3582	.3395	1.3957
2	1.3957	1.3203	.3395	.3772	.3224	.3395	1.3957
3	1.358	1.3203	.3395	.3772	.3224	.3395	1.4335
4	1.358	1.358	.3395	.3772	.3224	.3772	1.5089
5	1.358	1.5844	.3772	.4527	.394	.415	1.6221
6	1.6975	1.8107	.4527	.4527	.4656	.4904	1.9993
7	1.9993	1.9616	.5281	.5658	.4656	.4527	2.2257
8	1.9239	1.6975	.3772	.415	.394	.3395	2.3765
9	.2641	.2641	2.452	2.452	2.0774	2.037	.3018
10	.2641	.3018	2.452		2.1849	2.2634	.2641
11	.3018	.3018	2.2634	2.2923		2.2634	.2641
12	.3395	.3395	2.2257	2.3282		1.8484	.3018
13	.3395	.3395	2.3011	2.1132	1.9993	1.9993	
14	.3395	.3395	2.2634	1.97	1.9239	2.1502	
15	.3395	.415	2.1125	1.8625	1.9239	2.0748	
16	.3772	.415	2.1879	1.7909	1.9616	1.9993	
17	.3772	.3772	.3395	.3258	.2641		.3395
18	.3772	.4527	.3772	.3658	.3018	.3018	.3772
19	.4527	.5281	.415	.4024	.4527	.415	.4904
20	.5281	.4904		.4755	.5658	.4527	.5281
21	.5281	.4904	.4527	.4755	.415	.4527	.5281
22	.4527	.4527	.415	.439	.4527	.4527	.4904
23	1.4712	1.3957	.415	.394	.3772	.415	.4904
24	1.3957	1.5089	1.2449	.3772	.3582	.3395	.3772
Max	1.9993	1.9616	2.452	2.452	2.1849	2.2634	2.3765
Min	.2641	.2641	.3395	.3258	.2641	.3018	.2641
Avg	.8598	.8661	1.0891	.9330	.8320	.9808	.9355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 304 / Wathar-N Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1509	.1886	.2149	.1886	.2263
2	.1886	.1886	.1509	.1886	.1829	.1886	.1886
3	.1886	.1886	.1509	.1886	.1829	.1886	.1886
4	.1886	.1886	.1509	.1886	.1829	.1886	.1886
5	.1886	.1886	.1509	.1886	.2195	.1886	.1886
6	.2263	.1886	.1886	.1886	.2561	.1886	.2263
7	.1886		.1886	.1886	.1829	.2263	.2263
8	.1132	.2263	.1509	.1886	.1463	.1509	.1886
9	.1886	.2263	.1886	.1886	.1791	.1509	.1886
10	.2641	.1886	.1509		.1791	.1886	.1509
11	.2263	.1886	.1886	.1829		.1886	.1509
12	.2263	.1886	.1509	.1829		.2263	.1509
13	.2263	.1886		.1829	.1509	.2263	.2263
14	.1886	.1886	.1886	.1829	.1886	.2263	.2263
15	.1886	.1886	.1886	.1829	.1886	.2263	.1886
16	.2263	.1886	.1886	.1829	.2263	.2263	.1886
17	.2263	.1886	.1509	.1463	.1886		.2263
18	.1886	.1886	.1886	.1829	.1886	.2641	.1886
19	.3018	.2641	.2641	.2561		.3395	.3018
20	.3772	.3018	.3395	.3292	.3772	.3395	.3018
21	.3395	.3018	.3395	.3292	.3018	.3395	.3018
22	.2641	.2641	.2641	.2561	.3018	.3018	.3018
23	.2263	.2263	.2641	.2561	.2263	.2641	.2641
24	.2263	.2263	.2263	.2263	.2149	.2263	.2263
Max	.3772	.3018	.3395	.3292	.3772	.3395	.3018
Min	.1132	.1886	.1509	.1463	.1463	.1509	.1509
Avg	.2232	.2116	.1985	.2077	.2133	.2280	.2169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 305 / Upalawe Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.1132	.1097	.0754	.0754
2	.0754	.0754	.0754	.1132	.0732	.0754	.0754
3	.0754	.0754	.0754	.1132	.0732	.0754	.0754
4	.0754	.0754	.0754	.1132	.0732	.1132	.0754
5	.1132	.1132	.0754	.1132	.1097	.1509	.1132
6	.1509	.1886	.1132	.1509	.1829	.1509	.1509
7	.2263	.1886	.1509	.1509	.1463	.1132	.1132
8	.1132	.1132	.1509	.1509	.1097	.1132	.1132
9	.1509	.1132	.1132	.1132	.0716	.0754	.1132
10	.1509	.1132	.1132		.0732	.1509	.1132
11	.1509	.0754	.0754	.1097		.1509	.1132
12	.1509	.0754	.1509	.1097		.1132	.1132
13	.1509	.0754	.1132	.1097	.0754	.1132	.1132
14	.1509	.0754	.1132	.1463	.0754	.1132	.1132
15	.0754	.0754	.1509	.0732	.0754	.1132	.0754
16	.0754	.0754	.1132	.0732		.1132	.1132
17	.1132	.0754	.1509	.1097			.1509
18	.1509	.1132	.1509	.1097	.0754	.1132	.1132
19	.1509	.1509	.1132	.1463	.1132	.1509	.1132
20	.1509	.1886	.1886	.1463	.1509	.1509	.1132
21	.1509	.1886	.1509	.1463	.1132	.1509	.1132
22	.1132	.1886	.1509	.1463	.1509	.1509	.1132
23	.1132	.1509	.1132	.1097	.1132	.1509	.1132
24	.0754	.0754	.0754	.1132	.1075	.0754	.0754
Max	.2263	.1886	.1886	.1509	.1829	.1509	.1509
Min	.0754	.0754	.0754	.0732	.0716	.0754	.0754
Avg	.1242	.1132	.1179	.1209	.1037	.1197	.1069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 306 / Tathawada Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1509	.1886	.1463	.1509	.1509
2	.1886	.1886	.1509	.1886	.1463	.1509	.1509
3	.1886	.1886	.1509	.1886	.1463	.1509	.1509
4	.1886	.2263	.1509	.1886	.1463	.1509	.1509
5	.1886	.2263	.1886	.1886	.1829	.1886	.1886
6	.2263	.2641	.2263	.2263	.2926	.1886	.3018
7	.2641	.2263	.2641	.2641	.2561	.2641	.2641
8	.2263	.1509	.1886	.1886	.1829	.1886	.1509
9	.2263	.1509		.1886	.1463	.1509	.2263
10	.1509	.1886	.1509		.1463	.1509	.1886
11	.1509	.1886	.1132	.1463		.1509	.1886
12	.1886	.1886	.1132	.1463		.1886	
13	.1886	.1886		.1463	.1509	.1886	.1509
14	.1509	.1886	.1886	.1463	.1509	.1886	.1509
15	.1509	.1886	.1509	.1097	.0754	.1886	.1509
16	.1509	.1886	.1132	.1097	.1132	.1886	.1509
17	.1509	.1886	.1886	.1463	.1132		.1509
18	.1886	.1886	.1509	.1829	.1509	.1509	.1132
19	.2641	.2263	.2263	.2561	.1886	.2641	.2641
20	.3018	.3018	.3018	.3292	.2641	.2641	.2641
21	.2641	.2641	.2641	.2561	.2263	.3018	.2641
22	.2641	.2641	.2263	.2195	.2263	.2641	.2641
23	.2263	.2263	.1886	.1829	.1886	.2263	.2263
24	.1886	.1886	.1886	.1886	.1433	.1509	.1886
Max	.3018	.3018	.3018	.3292	.2926	.3018	.3018
Min	.1509	.1509	.1132	.1097	.0754	.1509	.1132
Avg	.2028	.2075	.1835	.1903	.172	.1935	.1935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 301 / 22 Kv Giravi Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.829	.3658	.3429	.3292	.4115	1.4937
2	1.5432	1.9022	.362	.3429	.3292	.4115	1.5684
3	1.5432	1.9909	.3658	.3772	.3658	.4115	1.5684
4	1.5432	2.1216	.4481	.4115	.3658	.4458	1.7177
5	1.7833	2.2314	.5228	.4458	.4024	.4458	2.037
6	1.9547	2.3777	.5975	.4801	.439	.5144	2.8292
7	2.7092	3.0361	.6413	.4801		.5975	3.2442
8	2.9874	.4024	.5975	.4801		.4115	3.1367
9	.4115	.2926	2.6783	2.8121	2.6703	2.7092	.3734
10	.4115	.3292	3.2442		3.1459	3.155	.3734
11		.362	3.0864	2.963	3.0178	3.2065	.2926
12	.3658	.3658	2.9835	2.9264	2.8807	3.1367	.2926
13		.4481	2.7092	2.8532	2.7435		.2926
14	.3292	.4854	2.7778	2.8898	2.7778	3.131	
15	.2195	.4481	2.7778	2.7801	3.062	3.0933	.3292
16	.3292	.4481		2.524	2.8807	3.0178	.3292
17	.3292	.439	.4115	.3658	.3772	.3734	.3292
18	.439	.4481	.3772	.439	.3772	.4755	.4024
19	.3658	.5228	.4801	.4024	.3772	.5487	.3658
20	.5121	.5601	.5144	.5121	.4458	.5975	.5121
21	.4755	.5601	.5487	.4755	.5487	.5914	.4755
22	.4024	.5228	.4801	.4755	.5144	.543	.439
23	1.829	1.9239	.3772	.3658		.4298	.3292
24	1.6118	1.7924	1.8861	.3429	.3292	.4115	.439
Max	2.9874	3.0361	3.2442	2.963	3.1459	3.2065	3.2442
Min	.2195	.2926	.362	.3429	.3292	.3734	.2926
Avg	1.0745	1.0767	1.2710	1.1517	1.3514	1.2639	1.0074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 303 / 22 Kv Giravi Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2926	.2195	.2743	.2926	.2401	.2195
2	.2401	.2926	.2241	.2743	.2926	.2401	.2241
3	.2401	.3292	.2614	.2743	.2926	.2743	.2241
4	.3086	.3258		.2743	.2926	.2743	.2587
5	.3086	.3658	.3361	.3086	.2926	.3429	.3292
6	.3429	.3658	.4108	.4108	.2926	.3086	.3734
7	.3772	.3658	.4108	.3429		.3086	.3361
8	.2401	.3658	.2241	.3734		.2401	.2896
9	.1715	.2195	.2195	.2401	.2926	.2401	.2614
10	.2058	.2561	.2241		.2561	.2401	.2926
11			.1715	.2926	.2401	.2561	.2926
12	.2926	.2534	.2058	.2926	.2743	.2614	
13	.2926	.2561	.2058	.2926	.2743	.2534	.2561
14	.3292	.2561	.2058	.2561	.2058	.2561	
15	.3292	.2561	.2058	.2195	.2058	.2172	.2195
16	.2561	.2561		.2561	.2058	.2614	.2561
17	.3292	.2614		.2561	.2058	.2561	.2561
18	.2987	.3018	.2401	.2561	.2743	.2614	.2561
19	.362	.4024	.3361	.3292	.3086	.362	.3658
20	.4024		.3429	.439	.3772	.4481	.4024
21	.439	.4344	.3429	.3982	.3429	.4108	.4024
22	.3982	.3658	.3772	.3658	.3429	.3734	.3658
23		.3292	.3086	.3292		.2987	.3292
24	.2743	.2896	.2561	.3086	.2926	.2401	.2587
Max	.439	.4344	.4108	.439	.3772	.4481	.4024
Min	.1715	.2195	.1715	.2195	.2058	.2172	.2195
Avg	.3051	.3110	.2728	.3072	.2788	.2861	.2941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 304 / 22 KV Wadale AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3658	.8962	.9602	.9145	.823	.2957
2	.3429	.4024	.8048	.9602	.9877	.823	.2561
3	.3429	.4435	.8048	.9602	.9511	.823	.2561
4	.3429	.4755	1.0456	.9602	1.134	.823	.2561
5	.3772	.5487	1.3443	1.0288	1.2071	.9602	.3696
6	.3772	.6219	1.7177	1.0631	1.3169	1.3375	.4854
7	.4458	.5121	1.9993	1.8176		2.1948	.5175
8	.3772	.4024	1.9616	1.8861		1.989	.4481
9	1.8519	1.9387	.3734	.3086	.3658	.3086	2.0165
10	2.0233	1.9387	.2987		.3658	.2743	1.773
11		1.8861	.2401	.3292	.2401	.2926	1.5364
12	1.829	1.7924	.2401		.3086	.0358	
13	1.5729	1.4937	.2401	.2172	.3086		1.4632
14	1.3443	1.307	.2401	.0256	.2743	.362	
15		1.307	.2743	.0293	.2743	.3734	1.3535
16	1.39	1.3817		.0293	.2743	.3361	1.39
17	.4755	.2614		.0293	.3361	.3326	.3658
18	.3658	.2926	.3429	.439	.3734	.4481	.4024
19	.3658	.4108	.3429	.439	.3772	.5228	.4024
20	.5121	.439	.4115	.5121	.4801	.5228	.5121
21	.5228	.439	.4801	.5121	.4115	.4854	.5487
22	.4755	.4108	.4115	.4755	.3772	.3734	.5121
23	.3658	.3734	1.0974	1.0608		.2987	.439
24	.3772	.3658	.3361	.9602	.8326	.3086	.2987
Max	2.0233	1.9387	1.9993	1.8861	1.3169	2.1948	2.0165
Min	.3429	.2614	.2401	.0256	.2401	.0358	.2561
Avg	.7464	.8254	.7229	.6820	.5767	.6543	.7227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 305 / 22 KV Dudhebavi AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.181	.2614	.2401	.3292	.3429	.1463
2	.1494	.1829	.2614	.2987	.3292	.3429	.1448
3	.1372	.2195	.2614	.2743	.3658	.3429	.1463
4	.1715	.2195	.2987	.2743	.4024	.3429	.1478
5	.1715	.2561	.4481	.3429	.439	.3429	.2241
6	.2058	.2926	.6722	.3772	.4755	.3772	.2534
7	.2058	.2926	.7842	.6859		.5487	.2957
8	.2058	.2561	.7468	.4801		.6173	.2241
9	.4801	.5487	.1867		.2195	.0686	.6348
10	.4458	.5121	.1829		.1829	.0686	.5658
11		.5121	.1029	.1829	.0686	.112	.5487
12	.3658	.5228	.1029		.0686	.1097	.5121
13	.4755	.4854	.0686	.1829	.0686		.4755
14	.439	.439	.0686	.1463	.0686		
15	.3658	.4481	.1029	.1463	.1029		.439
16	.4755	.4854		.1463	.1029		.3658
17	.1829	.1494		.1463	.1029		.1829
18	.1829	.1867	.1372	.1463	.1372	.2241	.1829
19	.2195	.2614	.1715	.2561	.1715	.2561	.2195
20	.2561	.2614	.1715	.2561	.1715	.2896	.2561
21	.2561	.2195	.1715	.2561	.2058	.2561	.2561
22	.2561	.2195	.1715	.1829	.2058	.2195	.2195
23	.1829	.2241	.2401	.2926		.1829	.2195
24	.1372	.1829	.181	.2743	.2926	.1029	.1463
Max	.4801	.5487	.7842	.6859	.4755	.6173	.6348
Min	.1372	.1494	.0686	.1463	.0686	.0686	.1448
Avg	.2655	.3150	.2634	.2661	.2148	.2709	.2960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 306 / 22 KV Dudhebbavi Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2561	.2241	.2058	.2561	.2401	.2614
2	.2058	.2561	.1867	.2241	.2561	.2401	.2241
3	.2401	.2926	.1867	.2743	.2926	.2743	.2241
4	.3086	.3292	.1867	.2987	.3292	.2743	.2172
5	.3429	.3658	.2614	.3429	.3658	.3086	.2987
6	.3429	.3658	.3361	.3429		.3734	.4024
7	.3429	.3658	.3772	.3361		.3772	.3734
8	.2743	.3292	.3361	.2401		.3086	.2987
9	.2401	.2926	.2534		.3292	.2401	.2614
10	.2401	.2195	.2926		.2926	.2401	.2218
11		.2195	.2987	.2195	.2743	.2926	.2926
12	.2926	.2195	.2614		.2401	.2614	.2561
13	.2926	.2614	.2743	.2926	.2743		.2926
14	.2561	.2534	.2401	.2926	.2058	.2987	
15	.1829	.2614	.2058	.2896	.2401	.2614	.2561
16	.2926	.2614	.2401	.2195	.2058		.2195
17	.2926	.2987		.2926	.2058		.2195
18	.3292	.3292	.2987	.2926	.2401	.3292	.2195
19	.3658	.3734	.2743	.3292	.3361	.4481	.3292
20	.4755	.4344	.3734	.4024	.4108	.4481	.4024
21	.4024	.4481	.4108	.3658	.3429	.4481	.3658
22	.3292	.3361	.2743	.3292	.3086	.3734	.3292
23	.2926	.2614	.2401	.2926		.2987	.2896
24	.2401	.2561	.2241	.2058	.2561	.2401	.2534
Max	.4755	.4481	.4108	.4024	.4108	.4481	.4024
Min	.1829	.2195	.1867	.2058	.2058	.2401	.2172
Avg	.2951	.3036	.2720	.2899	.2831	.3132	.2830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 301 / JANAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4777	.4361	1.3975	2.5888	2.9241	2.6719	.5356
2	.4769	.4321	1.422	2.5775	2.866	2.6868	.5033
3	.4722	.4289	1.424	2.5632	2.8457	2.7316	.4908
4	.4934	.4265	1.51	2.5407	2.8308	2.7378	.5027
5	.4989	.483	1.9399	2.6068	2.8889	2.8358	.5338
6	.6171	.6138	2.2802	3.423	3.3468	3.5008	.6004
7	.6513	.7563	2.6679	3.8236	4.1849	1.6164	.6868
8	.6405	.6383	2.5708	3.9653	4.0631	4.1276	.5981
9	3.6674	3.5376	.9943	1.3776	1.5594	1.5463	4.1733
10	3.8573	4.3164	.359	.4103	.4229	.4737	4.854
11	4.1102	4.0567	.4036	.1425	.1585	.4253	4.6278
12	4.2163	3.7313	.3768		.1341	.295	4.1032
13	3.8989	3.5188	.4239		.315	.3324	4.0346
14	3.5444	3.1902	.3322		.3377	.3707	3.9048
15	3.3859	3.154	.31		.3442	.4128	3.828
16	3.2828	3.1067	.1265		.3712	.4544	3.595
17	1.2473	1.1303	.3362		.4088	.4206	1.2956
18	.4736	.3059	.1212		.4465	.4315	.4579
19	.5524	.1273		.6682	.5739	.4218	.5432
20	.629	.4014	.5723	.6734	.6743	.6505	.6487
21	.6126	.4123	.5893	.6002	.6438	.6313	.606
22	.56	.3478	.5537	.5313	.5961	.6101	.5734
23	.6497	.2961	2.6204	2.6071	.5368	.5806	.508
24	.4637	.4042	1.1969	2.6892	2.0974	.5041	.5265
Max	4.2163	4.3164	2.6679	3.9653	4.1849	4.1276	4.854
Min	.4637	.1273	.1212	.1425	.1341	.295	.4579
Avg	1.6450	1.5105	1.0665	1.9876	1.4821	1.3112	1.7805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 302 / SATE PHATTA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.871	3.9817	.5186	.1905	.639	.5552	2.9066
2	3.7553	3.9004	.5184	.5571	.3751	.5171	3.2091
3	3.7189	3.8595	.5501	.5963	.645	.5752	3.1316
4	3.7552	3.9333	.5677	.6129	.6552	.6074	3.1585
5	4.0028	4.1816	.6468	.7148	.7386	.7162	3.7833
6	4.7704	4.8928	.7949	.9112	.8367	.8487	4.6544
7	5.3912	5.7041	.9246	1.0044	.8926	.5167	5.3959
8	5.6605	5.6471	.8	.8227	.8561	.7199	5.4344
9	2.5792	2.2824	4.8804	4.4111	2.0525	4.9179	2.4402
10	.7773	.5501	5.4857	5.5722	4.6742	5.4372	.5529
11	.7712	.5224	5.8947	3.3029	2.6597	2.1064	.5781
12	.8554	.5519	5.3902		2.9569	5.214	.57
13	.8261	.5239	5.1791		1.9296	5.387	.5245
14	.8237	.0625	5.3883		5.6638	5.3519	.5167
15	.9447	.0305	5.4036		6.1733	4.9306	.514
16	.9512	.5785	2.8227	1.4769	6.2913	4.8005	.502
17	.9521	.6076	2.1316	.6015	2.8515	1.9833	.5529
18	.9364	.6165	.6282	.7091	.6181	.5427	.6502
19	1.1041	.3826	.7619	.7843	.7459	.4974	.7911
20	1.1399	.8223	.9619	.8264	.8807	.7823	.8483
21	1.1256	.7806	.8842	.7583	.8543	.7518	.8471
22	1.0295	.711	.82	.707	.785	.6979	.7425
23	4.1314	4.0089	.7343	.6731	.7321	.7009	.6304
24	4.0923	3.9806	2.1231	.6531	.6803	.6279	.62
Max	5.6605	5.7041	5.8947	5.5722	6.2913	5.4372	5.4344
Min	.7712	.0305	.5184	.1905	.3751	.4974	.502
Avg	2.4152	2.2130	2.2838	1.2943	1.9245	2.0744	1.8148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 303 / RAJALE GAON

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7974	.9363	.8876	.9123	1.0602	.9918	.9187
2	.7899	.9153	.8636	.8888	1.0263	.985	.8839
3	.7883	.9055	.841	.8826	1.0127	.997	.8783
4	.9128	.9631	.9041	.9433	1.0136	1.0399	.9456
5	1.0955	1.0779	1.0789	1.0981	1.1654	1.1352	1.1396
6	1.4794	1.5159	1.4168	1.4362	1.4912	1.3686	1.4101
7	1.4837	1.4885	1.5164	1.416	1.5171	.6988	1.3959
8	1.3113	1.2255	1.3742	1.1779	1.3753	1.1611	1.1674
9	1.1954	1.1196	1.1217	1.0633	1.1487	1.064	1.0303
10	.947	1.0397	.9553	1.0086	1.1206	1.0745	.9707
11	.9257	.8879	1.0378	.4847	.5632	1.0643	.9253
12	.9779	.8263	.9898		.5838	1.0546	.9235
13	.9731	.7987	.9566		1.0466	1.0292	.8959
14	.8717	.8346	.8525		.8815	.4816	.8388
15	1.0428	.9146	.7923		1.0495	.9824	.7155
16	.9881	.8895	.3887		1.0265	1.0194	.7974
17	1.0069	1.035	.7665	1.126	.9949	1.1389	.4291
18	1.1458	1.0759	.8836	1.321	1.1693	1.2728	
19	1.3647	.6158	1.3162	1.4122	1.3428	1.3574	1.3701
20	1.4707	1.3965	1.5139	1.5943	1.5419	1.4059	1.3617
21	1.3734	1.3426	1.4604	1.5262	1.4834	1.3902	1.4969
22	1.2414	1.2127	1.2745	1.4401	1.363	1.3238	1.4474
23	1.1193	1.1016	1.0782	1.2522	1.1895	1.1565	1.2959
24	.9216	.9881	.9515	1.0521	1.0867	1.0269	1.0695
Max	1.4837	1.5159	1.5164	1.5943	1.5419	1.4059	1.4969
Min	.7883	.6158	.3887	.4847	.5632	.4816	.4291
Avg	1.0927	1.0461	1.0509	1.1598	1.1356	1.0925	1.0568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 201 / KATHAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.1029	4.3103	4.5294	4.5214	3.6519	.1143
2	.0686	.0857	4.1853	4.4071	4.0939	3.7144	.0953
3			4.068	4.2699	3.9407	3.6427	
4			3.9765	4.1717	3.887	3.5756	
5			3.783	4.0809	3.8934	3.4736	
6			3.9933	4.0493	4.0265	3.9765	
7			4.8438	4.7325	4.486	4.2585	
8			4.8026	4.4498	4.0284	4.1137	
9	4.9809	5.9622	2.4615	2.2862	1.6918	2.1506	4.6849
10	6.3939	6.4628					6.5554
11	5.9519	6.4838					5.4938
12	5.8589	6.0452					5.8615
13	5.6302	5.9633					5.8188
14	5.4504	2.8425					5.6063
15	5.4123	5.0518	.1029	.0762		.1029	1.9448
16	5.3132	5.0801	.2541	.0762		.1029	
17	2.9942	2.5621	.2861	.0857	.0914	.1219	5.4744
18	.0857	.0762	.2621	.0857	.1691	.2728	5.4683
19	.0857	.0762	.0953	.1029	.2667	.2713	2.894
20	.1029	.0762	.0953	.0857	.2424	.1746	.1166
21	.1029	.0762	.0953	.0857	.2515	.1669	.1029
22	.1029	.0762	.112	.1029	.16	.1143	.1029
23	.1029	4.196	4.4075	4.3568	.163	.1071	.0857
24	.1029	2.6254	4.4185	4.5631	2.1776	.0914	.0995
Max	6.3939	6.4838	4.8438	4.7325	4.5214	4.2585	6.5554
Min	.0686	.0762	.0953	.0762	.0914	.0914	.0857
Avg	2.7116	2.9914	2.4502	2.4525	2.2406	1.7939	2.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 202 / EKAMBE -SANGVI- AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6016	5.0248	.1524	.295	.2777	.3475	4.8986
2	3.4431	4.8461	.1311	.295	.2777	.346	5.0914
3	3.357	4.7889	.0427	.1616	.1844	.2012	4.7897
4	3.3509	4.6285		.1463			4.9017
5	3.3466	4.6106					4.9078
6	3.874	4.7303					5.2133
7	5.1684	5.4535					5.5811
8	5.0252	6.0692					5.4919
9	2.5941	2.9813	6.3458	5.996	5.6863	6.797	3.03
10			3.0758	6.2856	6.2338	6.7178	
11			1.704	6.656	3.1779	6.7608	
12			5.4023	6.3877	3.5406	7.1232	
13			6.2159	5.9381	6.845	7.0656	
14			6.7703	5.5738	6.9212	6.9223	
15	.0762	.0983	6.7044	5.7522	6.2902	6.6537	.1215
16	.125	.1173	6.6956	5.7278	5.8878	6.7143	.0831
17	.1269	.099	3.5704	3.166	3.2144	3.4964	.0343
18	.1288	.1143	.125	.2732	.2941	.3201	.1044
19	.3201	.2392	.1746	.2732	.3063	.3048	.1745
20	.3075	.1935	.3026	.3193	.3109	.3056	.3171
21	.3044	.2621	.3026	.2915	.32	.2027	.3216
22	.3014	.2545	.3148	.2808	.3216	.3033	.3353
23	4.7585	.2484	.2936	.2606	.3353	.3435	.3323
24	4.4064	2.4318	.2378	.3227	.2805	.3231	.3155
Max	5.1684	6.0692	6.7703	6.656	6.9212	7.1232	5.5811
Min	.0762	.0983	.0427	.1463	.1844	.2012	.0343
Avg	2.3482	2.4838	2.5559	2.7201	2.6687	3.2236	2.4234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 203 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0343	.0343	.0373	.0343	.0343	.0373
2	.0171	.0343	.0343	.0373	.0171	.0343	.0373
3	.0343	.0171	.0343	.0373	.0171	.0343	.0373
4	.0171	.0171	.0343	.0373	.0343	.0343	.0373
5	.0343	.0343		.0373	.0343	.0343	.0373
6	.0171	.0343		.0373	.0171	.0514	.0747
7	.0686	.0343		.0373	.0514	.0343	.0373
8	.0343	.0686	.0514	.0373	.0514	.0514	.056
9	.0686	.056	.0514	.0171	.056	.0686	.0514
10	.0686	.0373	.0857	.0171	.056	.12	.0514
11	.0514	.056	.12	.0171		.1029	.0514
12	.0514	.0747	.12	.0171		.0857	.0343
13	.0343	.056	.0857	.0171	.0934	.0686	.0514
14	.0343	.056	.0686	.0171	.0747	.0686	.0514
15		.056	.0686	.0343	.0747	.0857	.0686
16	.0514	.0934	.1029	.0343	.0747		.0857
17	.0686	.0514	.0343	.0343	.0857	.0747	.0686
18	.0857	.1029	.0747	.0171	.0857	.112	.0514
19	.0857	.0686	.0747	.0343	.0857		.0686
20	.0343	.0514	.056	.0343	.0686	.056	.0857
21	.0514	.0686	.0373	.0343	.0514	.056	.0686
22	.0514	.0514	.056	.0171	.0514	.056	.0514
23	.0343	.0514	.0373	.0343	.0343	.0373	.0686
24	.0343	.0514	.0686	.0373	.0343	.0343	.0373
Max	.0857	.1029	.12	.0373	.0934	.12	.0857
Min	.0171	.0171	.0343	.0171	.0171	.0343	.0343
Avg	.0455	.0524	.0634	.0297	.0538	.0607	.0542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 204 / EKAMBE -SANGVI- VLG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7533	.7697	.7579	.8626	.7552	.823	.8786
2	.7278	.7594	.7289	.8322	.7206	.7742	.8505
3	.6942	.7308	.7198	.7876	.7099	.762	.7609
4	.6839	.7202	.6988	.7465	.7251	.7423	.724
5	.7278	.7872	.7907	.8634	.7549	.8223	.9716
6	.8729	.8936	.9484	1.009	.8897	.9675	1.057
7	1.0395	.9789	1.0741	1.118	1.0997	1.0204	1.1949
8	1.0082	.9454	1.052	1.0615	.9602	1.0379	1.0418
9	.8509	.862	.9378	.9129	.921	.9324	.8776
10	.7899	.8764	.6794	.7381	.8612	.833	.7617
11	.7697	.8376	.5369	.655	.3285	.8513	.7773
12	.679	.3944	.7609	.6176	.4424	.8116	.7808
13	.668	.711	.7823	.6489	.7762	.8189	.7228
14	.6721	.6588	.7529	.6249	.7347	.8154	.6935
15	.7213	.6748	.7171	.6436	.7011	.8585	.711
16	.7263	.7076	.743	.7327	.6092	.8013	.7853
17	.769	.7164	.754	.7899	.8005	.8646	.8101
18	.8211	.8211	.8409	.8101	.8787	.9049	.8173
19	1.0345	1.0128	.9816	.9652	1.0582	1.1039	.8333
20	1.2719	1.1926	1.2578	1.2395	1.3272	1.3184	1.2273
21	1.2261	1.1778	1.3298	1.1767	1.2712	1.3176	1.243
22	1.179	1.1275	1.2018	1.1222	1.2144	1.3012	1.15
23	.9824	.9549	1.0242	.9579	1.0235	1.089	1.0475
24	.828	.8364	.8337	.879	.844	.8795	.9236
Max	1.2719	1.1926	1.3298	1.2395	1.3272	1.3184	1.243
Min	.668	.3944	.5369	.6176	.3285	.7423	.6935
Avg	.8540	.8395	.8710	.8665	.8503	.9355	.9017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 205 / 11KV KATAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2136	1.7071	1.1413	1.1691	1.086	1.1755	1.2826
2	1.1413	1.086	1.0689	1.0555	1.0517	1.1413	1.2072
3	1.086	1.0517	1.0689	.9426	1.0136	1.1241	1.1698
4	1.0689	.9793	.9965	.98	1.0136	1.086	1.2445
5	1.1717	1.0822	1.0479	1.1683	1.1336	1.1546	1.32
6	1.5509	1.4442	1.4785	1.4708	1.4785	1.5337	1.6785
7	1.7375	1.7547	1.6652	1.6046	1.648	1.6652	1.7181
8	1.5794	1.6309	1.5242	1.4925	1.5966	1.5585	1.5478
9	1.9623	1.3222	1.3584	1.1622	1.5276	1.4308	1.3794
10	1.2003	1.1131	1.2517	1.0136	1.3775	1.2517	.6097
11	.9241	1.0369	1.1241	.9412	.6097	1.086	
12	.9622	.9435	1.086	1.0898	.6478	1.1203	
13	.9241	.9995	1.0346	1.0517	1.2453	1.1241	1.0803
14	.9412	1.0555	.9373	1.0308	1.2826	1.0384	1.2651
15	1.0136	1.2258	1.086	1.1413	1.2258	.9241	1.1755
16	1.1584	1.2632	1.086	1.1241	1.2258	1.1374	1.1584
17	1.1927	1.2822	1.1203	1.1203	1.1584	1.2445	1.1584
18	1.4442	1.4099	1.3954	1.2441	1.2689	1.3767	1.3927
19	1.7128	1.6061	1.5276	1.6404	1.5851	1.7718	1.5642
20	2.0995	2.0271	2.1125	1.9376	2.0443	2.1498	1.9204
21	2.0481	1.9719	2.0191	1.8652	1.9757	2.1506	1.9376
22	1.7795	1.669	1.8115	1.7071	1.8861	1.9623	1.7452
23	1.507	1.4175	1.5097	1.4556	1.4213	1.6606	1.5623
24	1.286	1.2136	1.2346	1.2453	1.1584	1.307	1.3588
Max	2.0995	2.0271	2.1125	1.9376	2.0443	2.1506	1.9376
Min	.9241	.9435	.9373	.9412	.6097	.9241	.6097
Avg	1.3627	1.3455	1.3203	1.2772	1.3192	1.3823	1.3853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 206 / Shirambe-Ag

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0686	2.0748	2.5069	2.572	1.829	.0762
2	.0514	.0686	1.7833	2.4577	2.4863	1.8747	.0572
3			1.7528	2.3922	2.3663	1.829	
4			1.7375	2.3266	2.2977	1.8138	
5			1.6766	2.2283	2.2977	1.89	
6			1.9509	2.1792	2.3148	2.3167	
7			2.2862	2.3922	2.692	2.4539	
8			2.2253	2.1792	2.5892	2.4387	
9	2.3777	3.0803					3.1893
10	2.652	3.1459					3.6008
11	2.4082						3.4465
12	2.5606	2.8673					3.5665
13	2.4539	2.7854					3.2236
14	2.3929	2.7854					3.2236
15	2.3624		.0514	.0457	.0572	.0686	3.2407
16	2.2862		.0686	.0457	.0762	.0686	3.1722
17	.0514	2.5453	.0686	.0514	.061	.0762	.0514
18	.0686	2.21	.0762	.0686	.061	.0762	.0343
19	.0686	.061	.0762	.0686	.061	.0762	.0343
20	.0686	.0762	.0762	.0686	.0762	.0762	.0686
21	.0686	.0762	.0762	.0686	.061	.0762	.0686
22	.0686	.0762	.0747	.0686	.061	.0762	.0686
23	.0686	1.9052	2.6052	2.7092	.061	.0655	.0686
24	.0514	.0686	1.9204	2.5069	2.6063	.061	.0655
Max	2.652	3.1459	2.6052	2.7092	2.692	2.4539	3.6008
Min	.0514	.061	.0514	.0457	.0572	.061	.0343
Avg	1.1173	1.4547	1.1434	1.3536	1.2666	.9537	1.5143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 201 / 11KV CHIMANGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9313					1.0631
2		.8417					1.0029
3		.788					.9492
4		.8596					.9492
5		1.134					1.182
6		1.3466					1.5061
7	1.5581	1.3998					1.701
8	1.4529	1.4373					1.382
9	1.4746		1.2048	1.2403	1.3112	1.382	
10			1.0631	1.2536		1.3466	
11			1.0288	1.1488			
12			1.0208	1.0745	1.0924	1.2403	
13			.9774	.9671	1.0387	.9745	
14			.9313	.8954	1.1283	1.0454	
15			.8596	1.0208	1.1999	.9391	
16			.8238	1.1641	1.2003	1.1694	
17			.9313	1.3073	1.2178	1.3073	
18			1.182	1.3432	1.5415	1.3969	
19			1.6301	1.4175	1.6655	1.5238	
20			1.8054	1.825	1.8604	1.9667	
21			1.858	1.7541	1.701	1.8959	
22			1.6655	1.6118	1.5592	1.6655	
23	1.1283					1.5043	
24	1.0985	.9671					1.1222
Max	1.5581	1.4373	1.858	1.825	1.8604	1.9667	1.701
Min	1.0985	.788	.8238	.8954	1.0387	.9391	.9492
Avg	1.3425	1.0784	1.2130	1.2874	1.3764	1.3827	1.2064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 202 / 11 KV CHIMANGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1097	2.2634	2.2634	2.5149	2.5377	.0924
2	.1448	.0914	2.2721	2.1948	2.431	2.431	.0924
3			2.2634	2.1434	2.2298	2.3472	
4			2.2462	2.0062	.0886	2.3491	
5			2.2382	1.9547	.0895	2.2977	
6			2.2466	2.0287	.1063	2.3975	
7			2.5029	2.1795	.124	2.649	
8			2.4531	1.9616		2.8166	
9	2.0748						2.6852
10	2.5034						3.0476
11							3.1184
12		2.7435					
13		2.7949					
14	2.7606	3.035					
15	2.7606	3.0007	.0747	.1494	.1307	.0739	3.1007
16	2.4348	2.8292	.0934	.168	.1543	.0924	3.1893
17	2.4863	2.8121	.112	.168	.1307	.0924	
18	2.2466	2.6825	.128	.1109	.1097	.0924	
19	2.3137	2.5943	.1097	.1097	.1097	.1294	
20	.0914	.1294	.1097	.128	.1097	.1109	2.7694
21	.1097	.1109	.0914	.1294	.1097	.1109	.1086
22	.1097	.0924	.0914	.1294	.1097		.1075
23	.1097	2.2874	2.4981	2.5692	.1097		.1086
24	.1463	.1097	2.2542	2.4006	2.536	.1097	.1109
Max	2.7606	3.035	2.5029	2.5692	2.536	2.8166	3.1893
Min	.0914	.0914	.0747	.1097	.0886	.0739	.0924
Avg	1.3626	1.6949	1.3360	1.2664	.6585	1.2899	1.5443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 203 / 11 KV Khed Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.0062	2.0653	2.0687	2.0622	
2			1.8731	1.9399	1.9411	1.8667	
3			1.8206	1.8633	1.8754	1.7813	
4			1.8023	1.8099	1.8698	1.8265	
5			2.0107	1.9452	2.0637	2.1072	
6			2.4175	2.6376	2.5141	2.6029	
7			3.1746	3.3143	3.248	3.1777	
8			3.0444	3.235	3.0543	2.8898	
9		2.0503	1.4624	1.6011	1.4487	1.4792	1.8377
10	2.9675	3.0784					2.7341
11	2.8951	2.8818					2.8997
12	2.6131	2.6871					2.8315
13	2.5293	2.6597					1.2727
14	2.3346	2.3419					
15	2.4105	2.5541					2.2638
16	2.7126	2.9721					1.608
17	2.5545	2.9698					3.0374
18	3.034	2.9165					3.3532
19	3.3535	3.2045					3.4439
20	3.755	3.7064					3.7454
21	3.7487	3.5801					3.9704
22	3.425	3.3005					3.7479
23	1.6781	2.8268	1.9685	2.2552	1.9239		3.4675
24		1.2513	2.2274	2.2169	2.294	.9922	1.3893
Max	3.755	3.7064	3.1746	3.3143	3.248	3.1777	3.9704
Min	1.6781	1.2513	1.4624	1.6011	1.4487	.9922	1.2727
Avg	2.8580	2.8113	2.1643	2.2622	2.2092	2.0786	2.7735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 204 / 11 KV Khed Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0732	1.073	1.4022	1.358	1.4373	.1294
2	.0732	.0732	1.0343	1.3672	1.2887	1.387	.0554
3			.5658	1.3146	1.1904	1.3672	
4			.5658	1.2269	1.2003	1.3003	
5			.5935	1.2971	1.2378	1.4217	
6			.6203	1.4918	1.3077	1.5432	
7			1.7404	1.6118	1.6741	1.9376	
8			1.6078	1.5939	.8215	1.6598	
9	2.0233	1.9376					.0554
10	2.0748	2.0405					
11	1.5947	2.0576					
12	1.8004						2.3388
13	1.6461						
14	1.6289	1.6461					
15	1.5775	1.6804	.0934	.0934	.0093	.0739	2.4451
16	1.5775	1.7147	.2054	.1494	.112	.1294	2.2386
17	.0934	1.7661	.1494	.1867	.0934	.1663	2.2148
18	.0732	1.5089	.1629	.1848	.0914	.2033	
19	.0732	1.3565	.1448	.1463	.1097	.1663	
20	.0914	.1294	.128	.0549	.0914	.0739	1.7718
21	.0914	.0554	.128	.0739	.0914	.0739	.0895
22	.0732	.0554	.1097	.1109	.0914	.1848	.0905
23	.0732	1.1271	1.5432	1.4255	.0914	.1848	.0905
24	.0724	.0732	1.1065	1.439	1.3923	.0914	.1848
Max	2.0748	2.0576	1.7404	1.6118	1.6741	1.9376	2.4451
Min	.0724	.0554	.0934	.0549	.0093	.0739	.0554
Avg	.8172	1.0810	.6429	.8428	.6807	.7446	.9754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 205 / 11KV Shendurjane AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6476	2.0062	.1663	.0914	.1463	.0914	1.9062
2	1.6118	1.9547	.1663	.0914	.1478	.0914	1.8275
3	1.6118	1.8861					1.7436
4	1.6834	1.6975					1.7635
5	1.7551	1.8482					1.8442
6	2.1085	2.0287					2.1628
7	2.1971	2.1628					2.5857
8	2.268	2.3137					2.3537
9			2.6686	2.7496	2.4531	2.6993	
10			2.8807	.2743		2.7018	
11			2.7606	2.5892		2.7183	
12			2.6046	2.5034	.216	2.5819	
13			2.5072	2.332	2.1605	2.5149	
14			2.3034	2.0919	2.1776	2.4078	
15	.112	.0934	.2229	2.2462	2.2805	2.1216	.1463
16	.1307	.112	2.1948	2.2977	.2349	2.3371	.1448
17	.112	.0934	.0934	.0934	.0747	.1848	.1448
18	.1097	.2195	.0914	.1663	.0914	.1663	.1448
19	.0914	.2378	.1097	.1829	.1097	.1848	.1433
20	.0914	.2218	.1097	.1829	.0732	.1848	.1433
21	.0914	.1829	.1097	.1848	.0732	.1848	.1448
22	.0914	.1663	.128	.1848	.0732	.1663	.1448
23	2.0062	.1646	.1097	.1646	.0732	.1663	.1433
24	1.6834	2.0748	.1463	.1097	.1463	.0914	.1663
Max	2.268	2.3137	2.8807	2.7496	2.4531	2.7183	2.5857
Min	.0914	.0934	.0914	.0914	.0732	.0914	.1433
Avg	1.0779	1.0814	1.0763	1.0298	.6582	1.1997	.9808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 206 / 11KV Bhatamwadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.7796	.1294	.1097	.128	.128	.663
2	.6379	.7265	.1294	.1097	.1294	.1097	.6539
3	.6447	.7087					.6274
4	.6805	.6626					.6274
5	.7343	.6984					.6706
6	.8238	.7442					.7377
7	1.0099	.8322					.9945
8	1.1104	.8842					.9282
9			.9945	1.1871	1.0111	1.1096	
10			1.0924	1.1145		1.0111	
11			1.0745	1.0631		.9614	
12			1.0099	.8573	1.0288	.9448	
13			.9671	.823	.9431	.8551	
14			.9036	.8059	.9431	.8288	
15	.0934	.0934	.9431	.9259	.9431	.7712	
16	.168		1.0288	1.0029		.8288	
17	.2054	.0747	.1494	.1307	.0373	.1294	
18	.2012	.0732	.1829	.1478	.1629	.1663	
19	.2172	.1646	.181	.1463	.1991	.1663	
20	.1829	.1478	.181	.1829	.181	.1663	.1829
21	.1646	.1478	.1646	.1848	.1629	.1478	.1791
22	.1646	.1478	.1646	.1663	.1646	.1478	.181
23	.7522	.1463	.1463	.1463	.1629	.1663	.181
24	.7164	.7442	.128	.1463	.1097	.1629	.1663
Max	1.1104	.8842	1.0924	1.1871	1.0288	1.1096	.9945
Min	.0934	.0732	.128	.1097	.0373	.1097	.1663
Avg	.5104	.4574	.5317	.5139	.4205	.4890	.5225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 201 / TARAGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5971	1.749	.3768	.4527	.4338	.4096	1.668
2	1.5497	1.6164	.3605	.4338	.415	.3932	1.6004
3	1.4864	1.5339	.3605	.4338	.3961	.3768	1.5524
4	1.4685	1.5023	.3441	.415	.3961	.3768	1.5364
5	1.4998	1.4706	.3277	.415	.3772	.3768	1.5844
6	1.7284	1.6964	.3441	.3961	.3772	.3441	1.7924
7	1.9608	1.8818	.2949	.3584	.3395	.3277	1.9997
8	1.8976	1.8244	.3113	.3961	.3206	.3277	1.7869
9	.2785	.3921	2.1628	2.2939	1.9919	2.3967	.3292
10	.2785	.3547	2.3922			2.5232	.2987
11	.1966	.3174	2.3482	2.2119		2.3644	.3547
12	.2294	.3734	2.2085	2.1792	2.332	2.1862	
13		.4066	2.0485	2.13	2.3644	2.0405	.4805
14	.2949	.4251	2.1052		2.2996	2.1214	.4435
15	.2785	.4251	2.0243	1.9989	2.2024	2.2119	
16	.2622	.462		2.0481	2.119	1.9845	.5175
17	.2561	.3441	.4344	.4024	.3441	.4207	.462
18	.2743	.3441	.3982	.3982	.3441	.3761	.3801
19	.5729	.4096	.5658	.5041	.4424	.4854	.5175
20	.7655	.6062	.7356	.679	.639	.7545	.7655
21	.7356	.6226	.6979	.6979	.6718	.7356	.7545
22	.679	.5571	.6602	.6602	.6062	.6979	.679
23	1.7652	.4752	.5658	.5281	.5079	1.8299	.5658
24	1.7124	1.8138	.4096	.5093	.4715	.426	1.7652
Max	1.9608	1.8818	2.3922	2.2939	2.3644	2.5232	1.9997
Min	.1966	.3174	.2949	.3584	.3206	.3277	.2987
Avg	.9464	.9002	.9773	.9337	.9269	1.1037	.9925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 202 / KIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3584	1.8446	2.0058	1.9667	2.1132	.3961
2	.362	.3395	1.773	1.9163	1.8959	2.0416	.3772
3	.3239	.3395	1.7013	1.8446	1.8427	1.97	.3772
4	.3239	.3395	1.6655	1.8088	1.8073	1.97	.3772
5	.3429	.3206	1.7372	1.7909	1.825	1.9521	.3961
6	.381	.4338	2.0058	1.9879	2.0416	2.0774	.4527
7	.3584	.3772	1.7909	2.0908	2.073	2.2565	.3961
8	.3174	.3584	1.8446	2.2386	2.1262	2.1491	.3584
9	3.0407	2.9235		.2865	.2987	.2614	2.64
10	3.0769	2.959				.2957	2.9058
11	2.8778	2.8704		.197		.2926	2.7641
12	2.8778	2.8045		.2865	.0191	.2801	
13	2.6787	2.489	.4435	.3224	.2454	.2987	2.64
14	2.6606	2.5789	.3734		.4207	.3326	3.0266
15	2.6063	2.5431	.3921	.3403	.4207	.3292	
16	2.6063	2.4535		.3224	.4024	.3511	2.6223
17	.3109	.3403	.2896	.3258	.3582		.0191
18	.3155	.2328	.3439	.1612	.3403	.3761	.3761
19	.439	.4298	.4527	.181	.4298	.5041	.462
20	.6161	.5731	.6036	.6161	.6089	.6979	.6161
21	.6036	.5731	.6224	.6036	.6268	.679	.6224
22	.5658	.5194	.5658	.547	.5731	.6224	.6036
23	.4715	1.97	2.1849	2.0774	2.2207	.5281	.4715
24	.3772	.3961	1.97	2.1312	2.0774	2.2207	.4338
Max	3.0769	2.959	2.1849	2.2386	2.2207	2.2565	3.0266
Min	.3109	.2328	.2896	.1612	.0191	.2614	.0191
Avg	1.2040	1.2301	1.1897	1.0946	1.1191	1.0695	1.0607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 203 / WATHAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6852	2.6023	.6878	.7167	.6979	.7545	3.0182
2	2.5692	2.4863	.6697	.679	.679	.7167	2.8837
3	2.3758	2.3922	.6697	.6602	.6602	.6979	2.7349
4	2.3758	2.3594	.6697	.6413	.6413	.6979	2.7183
5	2.4249	2.343	.6516	.679	.6602	.7167	2.7018
6	2.8502	2.4813	.724	.7922	.7922	.811	2.9172
7	2.6852	2.6686	.724	.679	.6413	.7468	2.8841
8	2.8669	2.7831	.6154	.4715	.5847	.6722	2.8675
9	.567	.5544	2.7831	2.5194	2.4413		.6283
10	.567	.5914	2.9675			2.2447	.5544
11	.6036	.567	2.9504	2.8178		2.2283	.6283
12	.6401	.6401	2.7161	2.5857	2.8018	2.1792	
13	.5853	.6584	2.6825	2.4366	2.8018	2.1628	.8131
14	.6401	.6767	2.8147		2.7035	2.2045	.7947
15	.6219	.6767	2.6282	2.4697	2.6355	2.2708	
16	.6401	.6584	2.3472	2.5526	2.4905	2.2708	
17	.6584	.6335	.7207	.6516	.7059	.6767	.7964
18	.5792	.5611	.5544	.5973	.5249	.6219	.6878
19	.8048	.8507	.7545	.7947	.8145	.8676	.924
20	1.1203	1.086	1.094	1.0642	1.086	1.1694	1.1203
21	1.1128	1.1041	1.0751	1.0374	1.0679	1.1694	1.1389
22	1.0185	1.0136	1.0185	.9997	1.0498	1.1128	1.1016
23	2.934	.8507	.8299	.811	.8507	3.0521	.8676
24	2.7664	2.934	.724	.7167	.7356	.703	2.9504
Max	2.934	2.934	2.9675	2.8178	2.8018	3.0521	3.0182
Min	.567	.5544	.5544	.4715	.5249	.6219	.5544
Avg	1.5289	1.4239	1.4197	1.2442	1.2758	1.3369	1.7015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 204 / ARVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5093	1.0059	1.5091	1.326	1.56	.5658
2	.547	.5093	.9724	1.3748	1.2431	1.4752	.5281
3	.4715	.4904	.9054	1.2742	1.1934	1.2717	.5281
4	.4715	.4904	.8718	1.2407	1.1603	1.2616	.5281
5	.4904	.5093	.9221	1.3748	1.1904	1.3395	.6036
6	.547	.5658	1.2742	1.6244	1.4419	1.7465	.6036
7	.5093	.4715	1.576	1.8564	2.0388	1.9161	.4715
8	.3584	.415	1.576	1.6409	1.6741	1.7126	.3961
9	1.9393	1.9113	.3734	.3547	.3734		2.1548
10	2.0553	1.8778	.3547			.3881	2.1795
11	2.0222	1.8564	.3511	.3921		.4251	2.1963
12	1.8233	1.7901	.3326	.4294	.4066	.4481	
13	1.8233	1.6907	.4066	.4668	.4435	.4668	1.9559
14	1.6907	1.5249	.4481		.4066	.5228	2.0454
15	1.7072	1.7901	.4294	.4854	.499	.5228	
16	1.8067	1.6244	.462	.4668	.4572	.5041	2.0885
17	.4024	.4251	.462	.4251	.3921	.4938	.4755
18	.3841	.3881	.462	.3881	.4108	.4572	.4572
19	.5914	.6099	.6036	.5788	.5788	.5658	.6161
20	.7922	.7947	.8299	.7922	.8775	.8865	.811
21	.8299	.7762	.7922	.7733	.8775	.8488	.811
22	.7545	.7392	.7545	.6979	.7842	.7922	.7922
23	.6224	1.3491	1.5091	1.4413	1.7295	.6224	.6413
24	.5658	.5281	1.1736	1.5939	1.4083	1.6787	.5847
Max	2.0553	1.9113	1.576	1.8564	2.0388	1.9161	2.1963
Min	.3584	.3881	.3326	.3547	.3734	.3881	.3961
Avg	.9897	.9849	.7854	.9628	.9506	.9525	1.0016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 205 / PWV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0895	.0907	.0154	.037	.0935	.0901
2	.0191	.089	.0907	.0152	.0514	.0935	.0895
3	.0191	.089	.0907	.0735	.089	.0935	.0895
4	.0191	.089	.0907	.0907	.089	.0935	.0895
5	.0189	.1433	.0907	.0907	.089	.0935	.0895
6	.0189	.1271	.0907	.0895	.0901	.0935	.089
7	.0187	.089	.0907	.0895	.0895	.089	.089
8	.0006	.089	.0901	.0895	.0895	.089	.089
9	.0175	.0907	.0895	.0568	.0895	.0381	.0895
10	.037	.0907	.0895		.0381	.0747	.0895
11		.0747	.089	.0111		.144	.0743
12	.0187	.0747	.0747	.0095	.0568	.0739	
13	.0549	.0747	.0524	.0185	.0187	.0895	.0747
14	.0514	.0747	.0187		.0187	.0492	.0751
15	.0514	.0751	.0187	.0185	.0168	.0739	.0381
16	.0514	.0541	.0152	.009	.0366	.0739	.0751
17	.037	.0084	.0154	.008	.0747	.0739	.0743
18	.0366	.0084	.0177	.0072	.0747	.0154	.0467
19	.0366	.0084	.0154	.0051	.0183	.0156	.0084
20	.0088	.0175	.0156	.0048	.0175	.0154	.0002
21	.0063	.0175	.0048	.0055	.0175	.0152	.0002
22	.005	.0351	.004	.0055	.0175	.0154	.0002
23	.0187	.0907	.0042	.0067	.0751	.0901	.0901
24	.0191	.0895	.0526	.0187	.048	.0381	.0901
Max	.0549	.1433	.0907	.0907	.0901	.144	.0901
Min	.0006	.0084	.004	.0048	.0168	.0152	.0002
Avg	.0254	.0704	.0543	.0336	.0540	.0681	.0670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 201 / PIMPARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9282	1.1469	.0781	.0678	.0655	.0949	.5121
2	.9614	1.1012	.0633	.0693	.0625	.0949	.506
3	1.0174	1.0562					.5121
4	1.065	1.0562			2.2119		.506
5	1.0883	1.1469					.5693
6	1.1797	1.3435					.9922
7	1.1797	1.5083					1.3279
8	1.2651	1.3763					1.1336
9	2.2119		1.7284	1.704	1.4842	1.4232	
10			1.7966		1.4548	1.3923	
11			1.6518		1.2803	1.1961	
12			1.5238		1.1843	1.1568	
13			1.4251		1.0437	1.1336	
14			1.2407		1.0242	1.0774	
15	.1107	.096	1.1271	1.3757	1.0242	.8907	.0772
16	.0791	.1134		1.3441	1.0242	.8539	.0867
17	.0791	.1147	.081	1.012	.1029	.0972	
18	.08	.0972	.081	.8697	.104	.0663	.1029
19	.081	.0995	.0819	.0972	.0949	.1214	.1107
20	.1147	.112	.1147	.1147	.128	.1214	.1107
21	.0983	.1147	.08	.0949	.1265	.1214	.0791
22	.0983	.0937	.0819	.1147	.1107		.1107
23	1.1961	.081	.0983	.081	.0791	.1029	
24	.9374	1.1934	.1147	.0663	.08	.0949	.104
Max	2.2119	1.5083	1.7966	1.704	2.2119	1.4232	1.3279
Min	.0791	.081	.0633	.0663	.0625	.0663	.0772
Avg	.7248	.6584	.6687	.5393	.6677	.5905	.4276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 202 / BRAMHAPURI SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.9709	.8417	.8962	.8859	.924	.9568
2	.8871	.9145	.7973	.8131	.8954	.9055	.9313
3	.8859	.8688	.8145	.8048	.924	.9055	.9313
4	.9511	.8869	.8596	.8145	.9412	.9145	.9214
5	.9671	.8859	.8619	.8238	.9671	.9694	.9313
6	.9922	.9671	.9389	.8688	.9745	1.0349	.9671
7	.9922	1.0974	.9602	.924	1.086	1.0277	1.0498
8	.9745	.9979	.8124	.9694	.8859	.9922	1.0059
9	.9492	.9955	.8583	.9593	.9593	.9816	.8779
10	1.0425	.9774	.8684		.9214	.9568	1.0136
11	.9816	1.0317	.9955	.9745	.9313	1.0679	.9412
12	1.0099		.9231	.9362	.9313	1.0974	1.134
13	.9922	1.0029	.9145	.9536	.9774	1.0808	1.0974
14	.9391	.9214	.8871		1.0059	1.1041	1.0029
15	.9391	.8669	.7682	.8063	.9774	1.0631	1.086
16	.9036	.7442	.6878	.8589	.9774	1.0679	1.0059
17	.8413	.9145	.905	.7537	1.0242	.8764	
18	.8745	.9313		.8573	1.0242	.8859	.9955
19	1.0402	1.1568	.9313	1.0166	1.2269	1.134	1.1641
20	1.3032	1.2894	1.3717	1.2127	1.3032	1.4266	1.3352
21	1.2851	1.2254	1.2936	1.1517	1.2936	1.39	1.3306
22	1.2254	1.1694	1.1576	.0791	1.2197	1.307	1.2567
23	1.1317	1.0608	1.0269	.9214	1.0349	1.1203	
24	.9145	1.0562	.9214	.9335	.9412	.9425	1.094
Max	1.3032	1.2894	1.3717	1.2127	1.3032	1.4266	1.3352
Min	.8413	.7442	.6878	.0791	.8859	.8764	.8779
Avg	.9951	.9971	.9303	.8786	1.0129	1.049	1.0468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 203 / SAP

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.0747	2.0715	2.8502	2.1548	2.5857	.0686
2	.0648	.0754	2.1136	2.7846	2.1704	2.5396	.0693
3			2.1628	2.7526	2.0729	2.5232	
4			2.2245	2.5911	2.2119	2.5069	
5			2.5149	2.6235	2.5434	2.5069	
6			2.6379	2.7854	2.7343	2.8344	
7			2.9058	2.9172	3.6323	3.1161	
8			2.5775	2.5029	3.2036	3.3029	
9	2.2119	3.3316					3.1493
10	2.4194	3.0178					3.1786
11	1.9826	2.8837					2.8178
12	1.7814						2.6871
13	1.6194	2.6216					2.5194
14	1.5655	2.5232					2.6189
15	1.6804	2.2672	.064	.1006	.0686	.0972	2.5069
16	1.6484	2.2996	.0819	.1006	.0686	.0819	2.343
17	.0949	.081	.0819	.1017	.0857	.0972	
18	.096	.0819	.0848	.1006	.104	.1006	.081
19	.0972	.08	.1052	.0983	.1526	.104	.1372
20	.1052	.0983	.1075	.1134	.1372	.104	.1433
21	.0886	.0972	.0886	.0949	.1357	.104	.1433
22	.0895	.0781	.0895	.081	.1341	.1029	.1433
23	.0914	2.4036	2.8509	1.9766	.4024	.104	
24	.0663	.0732	2.3758	2.8837	2.0965	.1341	.0876
Max	2.4194	3.3316	2.9058	2.9172	3.6323	3.3029	3.1786
Min	.064	.0732	.064	.081	.0686	.0819	.0686
Avg	.8759	1.2993	1.3966	1.5255	1.3394	1.2748	1.4184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 204 / SASURVE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9282	1.9334	.0655	.0829	.0625	.0972	1.1203
2	.9724	1.9006	.0648	.0848	.0648	.081	1.1203
3	9.9455	1.8461					1.1203
4	.9717	1.7604					1.1203
5	1.0277	1.7711					1.1523
6	.9922	1.8884					1.2631
7	.9922	2.0317					1.2955
8	1.2003	1.8896					1.2955
9			1.4232	2.1628	1.6385	2.3805	
10			1.8623		1.6766	2.5263	
11			1.9334	2.8166	1.6575	2.4863	
12			1.8679	2.4453	1.6194	2.6825	
13			1.7901	2.2348	1.587	2.3967	
14			1.6766		1.5546	2.0805	
15	.1107	.0937	1.5912	1.8947	1.5402	2.1872	.0867
16	.096	.112	1.5074	1.8461	1.4746	2.2939	.0867
17	.096	.0983	1.4746	1.7814	1.4403	2.1548	
18	.088	.1296		1.8138	1.3443	1.9766	.0857
19	.112	.0995	1.3927	1.8351	1.2146	1.6324	.0532
20	.1147	.0972	1.2146	1.6004	1.1822	1.7695	.0972
21	1.8023	.0983	.0937	.0819	.1134	1.1523	2.0405
22	2.0553	.0791	.0983		.1134	1.1984	2.1376
23	2.0645	.0772	.0983	.0655	.1134	1.2308	
24	.9831	2.0222	.0633	.0983	.0633	.1134	1.1469
Max	9.9455	2.0317	1.9334	2.8166	1.6766	2.6825	2.1376
Min	.088	.0772	.0633	.0655	.0625	.081	.0532
Avg	1.3640	.9960	1.0716	1.3896	1.0256	1.6911	.9514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 205 / VELU

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2658	.2452	.218	.2054	.1943	.2801	.2686
2	.2378	.2075	.1966	.2054	.1658	.2614	.2303
3	.2452	.2075	.192	.1848	.1696	.2614	.2328
4	.2629	.2218	.2105	.2195	.1966	.2614	.2126
5	.3045	.2641	.25	.2033	.2241	.2801	.2328
6	.3277	.3174	.3113	.2987	.2846	.3511	.3012
7	.3277	.3326	.3201	.3361	.2915	.362	.3898
8	.2785	.3292	.2591	.2772	.3113	.2686	.3761
9	.2204	.2534	.2241	.2172	.2652	.2328	.2896
10	.1886	.2195	.2105		.2105	.2149	.2865
11	.1991	.2561	.2427	.181	.1823	.2172	.2865
12	.2328		.2103	.1612	.1928	.2743	.2896
13	.2507	.2353	.2149	.197	.2481	.2658	.2865
14	.2328	.2149	.2378		.2347	.2561	.3077
15	.2534	.2328	.2353	.1629	.2427	.2402	.2896
16	.2328	.2715	.2149	.181	.2658	.2126	.2865
17	.2328	.2534	.2012	.2279	.2865	.2865	
18	.2279	.2926		.2774	.2835	.2629	.3258
19	.3544	.3544	.2353	.3721	.3898	.3801	.3475
20	.5121	.4938	.4435	.4344	.4835	.543	.499
21	.439	.443	.3881	.4024	.4656	.4706	.462
22	.3881	.3801	.3547	.3481	.3921	.4163	.4251
23	.3361	.2835	.2987	.2591	.3174	.362	
24	.2715	.2987	.2401	.2263	.2214	.2801	.3109
Max	.5121	.4938	.4435	.4344	.4835	.543	.499
Min	.1886	.2075	.192	.1612	.1658	.2126	.2126
Avg	.2843	.2873	.2569	.2536	.2717	.3017	.3153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 206 / 11KV Dhamner Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0497	.0335	2.0622	2.1548	2.0165	1.989	.0564
2	.0509	.0339	2.0485	2.0645	2.0645	1.9334	.0714
3			2.0972	1.9989	2.1125	1.9334	
4			2.0165	1.9845	1.9925	1.9227	
5			2.0241	2.0405	1.9997	1.9448	
6			2.1548	2.13	2.0972	2.2721	
7			2.1715	2.3472	2.3061	2.17	
8			2.2024	2.3537	2.4348	2.13	
9	2.6216	2.9172					3.0803
10	2.5484						2.8837
11	2.6322	2.652					2.5194
12	2.6825						2.5232
13	1.9845	2.5888					2.9172
14	1.9433	2.556					2.146
15	2.0645	2.4905	.0549	.0286	.0417	.0655	2.0972
16	1.8842		.0564	.036	.0417	.0492	1.9757
17	.024	.0511	.0697	.0463	.0556	.0486	
18	.0541	.0629	.072	.096	.0834	.0655	.0572
19	.0452	.0389	.0743	.0655	.0772	.0926	.0469
20	.0617	.0394	.0709	.0671	.0617	.0812	.0492
21	.0533	.04	.0777	.0655	.0678	.0834	.0452
22	.0509	.0412	.0667	.064	.0526	.096	.0452
23	.037	2.2184	2.2466	2.0567	.0509	.096	
24	.0389	.0351	2.1956	2.2131	1.9997	.0564	.1134
Max	2.6825	2.9172	2.2466	2.3537	2.4348	2.2721	3.0803
Min	.024	.0335	.0549	.0286	.0417	.0486	.0452
Avg	1.0459	1.0533	1.209	1.2118	1.0865	.9461	1.2892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 301 / 22KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3899	2.4272	2.3152	2.3899	2.2405	2.5393	2.3899
2	2.2405	2.2405	2.2405	2.2405	2.2405	2.3525	2.3899
3	2.2405	2.2405	2.2405	2.2405	2.2405	2.3525	2.3899
4	2.2405	2.3152	2.2405	2.1658	2.2405	2.3525	2.3899
5	2.3152	2.3152	2.3152	2.1658	2.3152	2.4272	2.5393
6	2.4646	2.4646	2.5766	2.3899	2.5393	2.5393	2.7915
7	2.6139	2.5019	2.6886	2.5503	2.5393	2.5766	2.8292
8	2.5393	2.5393	2.5873	2.4764	2.5393	2.5766	2.6139
9	2.4025	2.5393	2.4646	2.5133	2.5019	2.5019	2.6139
10	2.5019	2.4646	2.5766	3.5482		2.5873	2.726
11	2.5766	2.4394	2.6337	3.0308	3.0308	2.7721	2.6981
12	2.6981	2.4143	2.7801	2.5873	2.809	2.8532	2.846
13	2.6337	2.3045	2.7435	2.6612	2.7435	2.8898	2.8829
14	2.5606	2.3777	2.6703	2.5606	2.7435	2.8166	2.6612
15	2.5873	2.4508	2.7435	2.6337	2.6703	2.8166	2.6703
16	2.524	2.4874		2.6337	2.7435	2.809	2.8166
17	2.4143	2.524	2.8532	2.4508	2.809	2.8166	2.8166
18	2.7069	2.7435	3.0361	2.4874	2.9264	2.8959	2.8959
19	3.1824	3.2922	3.6946	3.2156	3.5482	3.5475	3.5475
20	3.5482	3.5113	.3658	3.4374	3.807	3.8809	3.7342
21	3.2895	3.1417	3.2895	3.0308	3.5113	3.5113	3.4728
22	2.9874	2.9569	3.0308	2.95	3.2114	3.2156	3.2114
23	2.838	2.6886	2.838	2.6139	2.9874	2.8006	2.9127
24	2.5019	2.4272	2.3525	2.3899	2.3152	2.6886	2.5393
Max	3.5482	3.5113	3.6946	3.5482	3.807	3.8809	3.7342
Min	2.2405	2.2405	.3658	2.1658	2.2405	2.3525	2.3899
Avg	2.6249	2.5753	2.5773	2.6402	2.7502	2.7967	2.8075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]**SATARA CIRCLE[575]****SATARA DIVISION[516]****SATARA (U)[117]****BU 0914****Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN****Feeder No / Name : 302 / 22KV SANGAM NAGAR****SHEDDABLE URBAN****Feeder KV- 22 / OUTGOING**

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.2071	1.2826	1.358	1.3203	1.4335	1.4335
2	1.2826	1.1317	1.2826	1.358	1.3203	1.4335	1.4335
3	1.2826	1.1317	1.2826	1.2449	1.2071	1.3203	1.2826
4	1.2826	1.1317	1.2071	1.2449	1.2071	1.3203	1.2826
5	1.2826	1.1317	1.2071	1.2449	1.2071	1.3203	1.2826
6	1.358	1.1694	1.2071	1.2071	1.2071	1.3203	1.2826
7	1.2826	1.1694	1.2071	1.2323	1.3203	1.358	1.3203
8	1.3203	1.2449	1.2449	1.3203	1.4335	1.358	1.3957
9	1.4335	1.3203	1.4335	1.3957	1.5844	1.5466	1.5089
10	1.6975	1.358	1.6975	1.8107	2.1125	1.773	1.8484
11	1.9589	1.4335	2.037	1.5524		2.1502	2.1502
12	2.0538	1.3203	1.9993	1.358	2.2634	2.2634	2.1879
13	1.9993	1.358	1.9239	1.3203	2.1502	2.2257	2.0748
14	1.8484	1.358	1.9993	1.3957	2.1125	2.1502	1.4712
15	1.8484	1.4335	2.0748	1.4335	2.1879	2.2634	2.1502
16	1.7924	1.3957		2.2634	2.2634	2.3011	2.1125
17	1.7924	1.5089	2.1125	2.1125	2.1125	2.1125	2.0748
18	1.6057	1.4335	1.8484	1.7924	1.8107	1.5089	1.8861
19	1.7741	1.6057	1.9418	1.7924	1.8484	1.8861	1.8861
20	1.7551	1.6057	1.9044	1.8107	1.9239	1.8861	1.8107
21	1.643	1.5844	1.6975	1.6221	1.773	1.6975	1.7353
22	1.5466	1.5089	1.5844	1.5466	1.773	1.6975	1.6975
23	1.5466	1.5089	1.5466	1.5089	1.6598	1.6975	1.6598
24	1.358	1.3817	1.358	1.3957	1.4335	1.5089	1.5844
Max	2.0538	1.6057	2.1125	2.2634	2.2634	2.3011	2.1879
Min	1.2826	1.1317	1.2071	1.2071	1.2071	1.3203	1.2826
Avg	1.5876	1.3514	1.6122	1.5134	1.7057	1.7305	1.6897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 303 / 22KV PARANGE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.5684	1.4937	1.6804	1.5684	1.6804	1.5684
2	1.5844	1.5684	1.4937	1.5684	1.5684	1.5684	1.5684
3	1.5844	1.4937	1.4937	1.4937	1.4937	1.5684	1.5684
4	1.5844	1.4937	1.4937	1.4937	1.4937	1.5684	1.5684
5	1.5844	1.4937	1.531	1.4937	1.4937	1.5684	1.6057
6	1.6804	1.4937	1.6804	1.6057	1.5684	1.7177	1.8107
7	1.643	1.5684	1.6804	1.7002	1.6804	1.7924	1.8107
8	1.6057	1.6057	1.5684	1.5893	1.6804	1.7177	1.6804
9	1.5154	1.643	1.531	1.5154	1.643	1.6804	1.5684
10	1.5684	1.4937	1.6057	1.5524		1.7551	1.1233
11	1.6263	1.5524	1.7372	1.5524	1.9589	1.7372	1.7002
12	1.7002	1.5893	1.7002	1.5154	1.7741	1.7924	1.6632
13	1.6804	1.6263	1.7002	1.5893	1.7372	1.7193	1.7372
14	1.7372	1.5524	1.9993	1.5893	1.7372	1.7741	1.7002
15	1.6632	1.5729	1.7372	1.7002	1.848	1.848	1.7558
16	1.6263	1.4998		1.6263		1.8111	1.848
17	1.5729	1.4998	1.7193	1.6632	1.7002	1.8111	1.8111
18	1.6461		1.5524	1.5927	1.7558	1.829	2.0271
19	2.0119	1.8656	2.0851	1.9959	2.1068	2.1948	2.2443
20	2.1437	2.2177	2.3285	2.1437	2.4394	2.4025	2.3899
21	2.0698	1.922	1.9959	2.0911	2.2546	2.2405	2.2405
22	2.0911	2.1285	1.9959	2.0538	2.2405	2.0911	2.2032
23	1.9239	1.7353	1.7912	1.8671	2.0538	1.8671	2.0165
24	1.773	1.6057	1.6057	1.6804	1.643	1.6804	1.6804
Max	2.1437	2.2177	1.7912	2.1437	2.4394	2.4025	2.3899
Min	1.5154	1.4937	1.4937	1.4937	1.4937	1.5684	1.1233
Avg	1.7214	1.6430	2.5009	1.6814	1.7927	1.8090	1.7871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 304 / 22KV CIVIL HOSPITAL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2762	.1753	.1715	.2191	.2362	.2534	.2134
2	.2629	.1715	.1696	.2286	.1696	.2191	.2115
3	.2553	.1696	.1715	.2134	.1677	.2172	.2115
4	.2743	.1696	.1696	.2115	.1657	.2153	.1791
5	.2705	.1657	.1696	.2096	.1619	.2134	.1848
6	.2953	.2077	.2191	.2248	.1657	.2172	.1867
7	.2629	.1848	.1791	.1791	.1638	.1962	.1772
8	.2153	.2134	.2153	.2077	.1962	.2248	.2038
9	.2724	.2477	.3086	.322	.3048	.2762	.2858
10	.3353	.2515	.3467	.3486	.2229	.2953	.2896
11	.3734	.2477	.3563	.3753	.3544	.3296	.3563
12	.3239	.1886	.322	.3753	.3448	.3372	.3124
13	.2934	.2229	.3048	.3144	.3105	.3658	.2953
14	.2629	.1829	.2934	.2801	.2934	.3124	.2724
15	.2305	.1638	.2934	.261	.2705	.2991	.242
16	.2134	.1505	.2	.2591	.3372	.3239	.3086
17	.2019	.1448	.2724	.2591	.3105	.3048	.2743
18	.16	.1429	.2858	.2096	.3029	.2496	.3163
19	.1657	.2038	.24	.1753	.2305	.1886	.2915
20	.1848	.2134	.2362	.1715	.2458	.2381	.2667
21	.2248	.2496	.24	.1848	.2324	.2629	.2915
22	.2229	.2572	.2648	.1848	.2801	.2572	.3048
23	.2077	.2039	.2496	.2039	.261	.2343	.2839
24	.221	.1753	.1848	.2477	.2629	.2191	.2496
Max	.3734	.2572	.3563	.3753	.3544	.3658	.3563
Min	.16	.1429	.1696	.1715	.1619	.1886	.1772
Avg	.2503	.1960	.2443	.2444	.2496	.2604	.2587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 301 / 22KV OLD MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.6219	.695	.5175	.4641	.6173	.6516
2	.4908	.5853	.6516	.5014	.4694	.5487	.5959
3	.4801	.5792	.6516	.4557	.431	.503	.5959
4	.5373	.5853	.6584	.4656	.426	.4481	.5487
5	.5487	.5792	.695	.5121	.426	.4481	.5426
6	.5201	.6154	.7023	.4656	.426	.4588	.631
7	.5731	.6878	.6089	.4755	.5121	.5312	.583
8	.5544	.4359	.4588	.4066	.4572	.4374	.5144
9	.6584	.7468	.7762	.3185	.6516	.695	.6653
10	.7922	.8676	.9054	.3978	.631	1.0562	.8962
11	.9054	.8299	.0953	.3605	.9808	1.2193	1.1812
12	1.1431	.8676	.8676	.3086	1.1576	1.2071	1.1317
13	.8676	.8676	.9431	.3018	.8871	1.0562	1.0562
14	1.094	.9054	.8676	.4024	.8871	1.2071	.9054
15	1.2193	.9054	.9054	.5121	1.1694	1.1203	1.1694
16	.9145	.8299	.7922	.5487	1.0185	1.1317	1.094
17	.9054	.8299	.8676	.4344	.9054	.9431	.8676
18	.7545	.7545	.7468	.2972	.7922	.7545	.8589
19	.5975	.7167	.8299	.2743	.695	.679	.8326
20	.5228	.543	.5975	.3521	.631	.6413	.5487
21	.6722	.695	.6413	.5201	.5792	.6413	.5914
22	.6219	.6219	.6348	.426	.5548	.679	.7167
23	.5316	.6283	.5544	.5544	.7316	.7922	.7167
24	.5975	.6219	.695	.5487	.4694	.695	.8131
Max	1.2193	.9054	.9431	.5544	1.1694	1.2193	1.1812
Min	.4801	.4359	.0953	.2743	.426	.4374	.5144
Avg	.7102	.7051	.7017	.4316	.6814	.7713	.7795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 302 / 22 KV KARMVEER NAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.2803	1.307	1.2826	1.2696	1.419	1.307
2	1.2567	1.2567	1.3817	1.2826	1.2323	1.3443	1.2826
3	1.2323	1.2197	1.3817	1.2449	1.2696		1.2826
4	1.2826	1.2696	1.358	1.358	1.307	1.1949	1.3203
5	1.307	1.307	1.3957	1.358	1.358	1.2071	1.307
6	1.3817	1.358	1.3957	1.4335	1.3957	1.4335	1.5684
7	1.5089	1.419	1.5089	1.4712	1.5844	1.6598	1.6057
8	1.2826	1.3443	1.4712	1.358	1.3957	1.4712	1.419
9	1.2449	1.1827	1.2323	1.1694	1.2826	1.2826	1.2197
10	1.1317	1.0719	1.086	1.0456	1.2826	1.2826	1.0608
11	1.1694	1.0349	1.0974		1.2449	1.2449	1.1458
12	1.1694	1.0456	.7164		1.1317	1.2071	1.1458
13	1.1694	1.0829	1.1584		1.1694	1.2449	1.1576
14	1.1694	1.1458	1.1706		1.2449	1.2449	1.2071
15	1.2449	1.1827	1.1458		1.2449	1.2826	1.2826
16	1.2071	1.0974	1.1949		1.1694	1.2826	
17	1.2323	1.2071	1.2071	1.4784	1.2449	1.2696	1.1694
18	1.2696	1.2826	1.1694	1.419	1.3957	1.2696	1.2449
19	1.6221	1.5844	1.6221	1.7741	1.6598	1.7551	1.531
20	1.829	1.8484	1.7924	1.8298	1.9239	1.9418	1.773
21	1.7558	1.773	1.7551	1.8107	1.9239	1.8671	1.8107
22	1.7558	1.6598	1.6598	1.7551	1.8484	1.5684	1.8484
23	1.4998	1.5466	1.5844	1.4937	1.6598	1.5684	1.6221
24	1.3443	1.3169	1.3203	1.3203	1.307	1.4335	1.419
Max	1.829	1.8484	1.7924	1.8298	1.9239	1.9418	1.8484
Min	1.1317	1.0349	.7164	1.0456	1.1317	1.1949	1.0608
Avg	1.3489	1.3132	1.3380	1.4381	1.3978	1.4120	1.3796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 303 / 22KV MAHARASHTRA SCOOTERS SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6057	1.5089	1.4415	.9709	.3155	1.2803	1.6598
2	1.5524	1.5089	1.39	.924	.3475	1.2308	1.6057
3	1.4937	1.5466	1.39	.9335	.362	1.2178	1.5684
4	1.5154	1.531	1.4415	.9511	.3963	1.2536	1.4937
5	1.6057	1.5684	1.4937	1.0456	.4191	1.2936	1.4937
6	1.6461	1.5684	1.531	1.2803	.4561	1.4937	1.531
7	1.4563	1.531	1.6221	1.3676	.5784	1.3817	1.307
8	1.5684	1.5364	1.6057	.8215	.9069	1.4632	1.0829
9	2.0748	1.643	2.0538	.4641	1.8671	2.037	2.037
10	2.1719	1.8107	1.8671	.7122	1.5089	2.1125	2.2257
11	2.1338	1.8484	2.1719		1.8671	2.1502	1.9616
12	2.0957	1.8861	2.0957		2.037	2.1502	1.9993
13	1.8484	1.8861	1.9993		2.1125	1.9239	2.037
14	2.1338	1.9616	2.037		2.1125	2.0698	2.0748
15	2.2481	2.037	2.2257		2.0748	2.0538	2.1125
16	1.8484	2.0748	1.9239		1.9044	2.0538	
17	1.6975	1.8107	1.1694	.2915	1.9814	2.037	1.9239
18	1.6221	1.773	1.2071	.4241	1.829	1.9239	1.9814
19	1.6975	1.8107	1.7551	.5041	1.8107	1.8107	1.8861
20	1.5844	1.4563	1.5089	.4161	1.643	1.6598	1.358
21	1.5466	1.5466	1.6057	.3765	1.6975	1.6598	1.5089
22	1.1317	1.5089	1.6221	.4527	1.8107	1.6804	1.8107
23	1.5844	1.8107	1.643	.4401	1.6975	1.6598	1.773
24	1.643	1.448	1.4415	1.0185	.3185	1.2803	1.5154
Max	2.2481	2.0748	2.2257	1.3676	2.1125	2.1502	2.2257
Min	1.1317	1.448	1.1694	.2915	.3155	1.2178	1.0829
Avg	1.7294	1.6922	1.6768	.7441	1.3356	1.7032	1.7368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 304 / 22KV DOBURG

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.1321	6.4681	7.8266	8.014	5.7511	7.8136	9.4593
2	8.8645	8.3638	8.219	8.1287	5.7213	9.1374	8.8561
3	8.1794	8.5525	8.2038	8.4111	5.4935	8.1771	9.6929
4	8.4088	8.9449	7.5956	7.6017	5.3345	8.5269	9.608
5	8.347	9.2973	8.2125	7.7953	5.4268	8.7533	9.8713
6	8.7022	9.6137	8.0072	7.9809	5.5342	8.5021	9.6842
7	8.565	8.1169	9.0889	6.7905	6.1217	9.2467	9.8278
8	8.1581	7.2124	8.3376	4.6517	7.4055	8.8096	8.9994
9	10.7347	9.1186	9.8502	3.85	7.2931	10.6881	9.8354
10	12.1567	11.3184	11.6698	3.8665	8.8748	12.9081	12.4612
11	12.5515	12.217	12.9165	1.4632	8.0986	13.5025	13.0963
12	12.5362	11.0479	12.3384		11.677	13.5787	12.9173
13	12.2268	10.3331	11.3443		11.3744	12.4771	10.8627
14	12.9173	11.4278	11.7912		12.2253	12.5076	10.5682
15	12.5972	12.5541	12.3949		12.4242	13.4808	12.316
16	13.1935	11.1058	12.9714		11.9418	13.0552	8.5048
17	12.8106	10.2664	12.9344	1.094	11.0079	11.9143	12.0188
18	10.9682	10.7392	11.6819	3.6762	10.2808	11.2982	11.68
19	9.6968	9.7802	11.2479	3.836	10.192	10.0557	8.8652
20	8.8694	9.8606	11.0246	3.9274	9.7619	10.2691	9.1103
21	8.938	7.8079	9.3149	4.2966	9.0752	8.9742	7.4859
22	8.7864	8.8154	9.9512	5.6813	9.2231	7.8323	8.8923
23	7.5225	9.4852	9.5427	5.0778	9.9353	8.45	8.9217
24	6.9121	6.408	7.5712	5.0034	8.517	7.8456	8.5136
Max	13.1935	12.5541	12.9714	8.4111	12.4242	13.5787	13.0963
Min	6.9121	6.408	7.5712	1.094	5.3345	7.8136	7.4859
Avg	10.0323	9.5356	10.1682	5.3235	8.6955	10.3252	10.0854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 301 / 22KV KARANJE MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2765	1.2212	1.2422	1.2307	1.2041	1.2925	1.1355
2	1.2612	1.1888	1.1964	1.2002	1.1736	1.2346	1.1507
3	1.3069	1.2041	1.2117	1.2155	1.2041	1.2879	1.1507
4	1.3069	1.2254	1.2422	1.2155	1.2041	1.2517	1.1659
5	1.3222	1.2212	1.246	1.2307	1.2712	1.2559	1.2002
6	1.2959	1.3078	1.3108	1.2612	1.2559	1.2712	1.2155
7	1.3908	1.3748	1.3412	1.3108	1.2712	1.3474	1.2955
8	1.406	1.5028	1.387	1.3565	1.4052	1.4052	1.3412
9	1.64	1.6042	1.6918	1.3687	1.5585	1.4517	1.323
10	1.8504	1.5661	1.7985	1.2498	1.1888	1.7833	1.5119
11	1.7985	1.6575	1.768	1.1065	1.6347	1.8709	1.5943
12	1.9266	1.5927	1.5889	1.1065	1.8138	1.9014	1.6034
13	1.7566	1.547	1.4441	1.2316	1.7528	1.7337	1.6247
14	1.7589	1.486	1.5051	1.2864	1.8504	1.7985	1.6247
15	1.7776	1.4213	1.7071	1.2407	1.9327	1.7985	1.7071
16	1.8138	1.4365	1.627	1.2559	2.0081	1.7985	1.7009
17	1.7467	1.467	1.6385	1.2407	1.829	1.768	1.6796
18	1.7414	1.4174	1.4746	1.2407	1.7071	1.6042	1.4907
19	1.589	1.4403	1.4822	1.2925	1.5943	1.4479	1.5546
20	1.5212	1.4174	1.4365	1.3535	1.4861	1.3931	1.5364
21	1.246	1.2955	1.3069	1.3383	1.2155	1.2612	1.2712
22	1.2365	1.2917	1.2955	1.2712	1.2407	1.2002	1.2407
23	1.2879	1.3069	1.2765	1.2041	1.185	1.1507	1.2041
24	1.2307	1.3641	1.2765	1.2498	1.1584	1.1755	1.105
Max	1.9266	1.6575	1.7985	1.3687	2.0081	1.9014	1.7071
Min	1.2307	1.1888	1.1964	1.1065	1.1584	1.1507	1.105
Avg	1.5203	1.3982	1.4373	1.2524	1.4644	1.4785	1.3928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 302 / 22KV PRATAPGANJ PETH

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.6775	5.7827	5.6775	5.4755	5.5175	5.9518	5.8376
2	5.4184	5.4526	5.2202	5.2469	5.2584	5.727	5.6775
3	5.4984	5.4809	5.1859	5.1859	5.3773	5.5784	5.5251
4	5.426	5.3707	5.1936	5.2241	5.4199	5.5723	5.4489
5	5.3651	5.346	5.2508	5.2508	5.5052	5.6622	5.5366
6	5.6242	5.5846	5.7194	5.7004	5.929	6.0547	6.0966
7	5.9671	6.121	5.8718	6.169	6.31	6.4624	6.6758
8	6.0129	6.0585	5.7042	6.1348	6.2734	6.1546	6.2643
9	5.5388	5.5708	5.5327	5.6485	5.8071	5.6318	5.8223
10	5.125	5.5251	5.4108	5.2065	3.6885	5.4717	5.4413
11	5.2035	5.1402	5.1974	4.8591	5.7491	5.2736	5.1303
12	5.362	5.0183	5.0145	4.6396	5.3574	5.2126	5.0877
13	5.4565	5.2317	5.2431	4.856	5.1707	5.407	5.3011
14	5.4679	5.2393	5.2888	4.8225	5.2279	5.4374	5.3742
15	5.6603	5.3803	5.4756	4.6639	5.7065	5.5175	5.6546
16	5.6451	5.487	5.4908	4.6639	5.8146	5.6165	5.7004
17	5.7079	5.5213	5.506	4.7829	5.9168	5.6165	5.8803
18	5.9651	5.6318	5.8147	4.6853	6.2125	5.6737	5.6881
19	6.0871	5.8032	5.9366	5.6729	6.5478	6.2376	6.1546
20	7.761	7.518	7.7846	7.5202	8.3181	7.697	7.9714
21	7.6787	7.5027	7.8076	7.6513	8.2	7.7313	7.8006
22	7.5568	7.3655	7.5865	7.4866	7.9591	7.5598	7.6787
23	6.912	7.1292	7.3274	7.1666	7.7122	7.2283	7.5019
24	6.4244	6.3938	6.432	6.2796	6.5691	6.6758	6.592
Max	7.761	7.518	7.8076	7.6513	8.3181	7.7313	7.9714
Min	5.125	5.0183	5.0145	4.6396	3.6885	5.2126	5.0877
Avg	5.9392	5.8606	5.8614	5.6247	6.0645	6.0480	6.0767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 303 / 22KV SUSHAMA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0653	2.0233	1.9395	2.0005	2.0911	2.0911	2.0653
2	1.9738	1.9471	1.8785	1.909	1.9784	1.9761	1.9243
3	1.9128	1.9014	1.8138	1.8633	1.9174	1.8808	1.8785
4	1.9167	1.8709	1.7833	1.8824	1.9601	1.8656	1.9167
5	1.9357	1.85	1.8519	1.9128	1.9814	1.8805	1.9662
6	2.1034	2.09	2.0691	2.2405	2.2162	2.1948	2.2291
7	2.332	2.3453	2.5683	2.6483	2.5515	2.7069	2.6406
8	2.4509	2.3472	2.4577	2.6026	2.7374	2.6033	2.6292
9	2.2634	2.271	2.4311	2.5119	2.6826	2.4959	2.5026
10	2.212	2.271	2.4311	1.6613	1.7833	2.652	2.6154
11	2.0938	2.1719	2.3701		2.6102	2.5758	2.3929
12	2.1243	2.0653	2.2062		2.3929	2.4349	2.2344
13	2.1277	2.1262	2.0348	1.1706	2.3686	2.3168	2.1887
14	2.0843	2.0195	2.0195	2.4325	2.1758	2.2062	2.1368
15	2.2539	2.0691	2.1148	2.2039	2.2024	2.2062	2.2924
16	2.2939	2.13	2.13	2.1582	2.3606	2.2062	2.3381
17	2.3758	2.1262	2.191	2.1277	2.452	2.2329	2.3381
18	2.2634	2.031	2.3015	2.0546	2.4052	2.4387	2.3411
19	2.4177	2.1186	2.2863	2.21	2.4874	2.5148	2.5392
20	2.7435	2.5721	2.7473	2.7008	2.9782	3.0045	2.7983
21	2.6673	2.5568	2.6977	2.7313	2.8593	2.8692	2.7983
22	2.5644	2.5187	2.6178	2.6703	2.7378	2.8007	2.7983
23	2.5362	2.4844	2.5835	2.5606	2.5827	2.5759	2.716
24	2.2024	2.2424	2.2482	2.2062	2.2954	2.3556	2.3282
Max	2.7435	2.5721	2.7473	2.7313	2.9782	3.0045	2.7983
Min	1.9128	1.85	1.7833	1.1706	1.7833	1.8656	1.8785
Avg	2.2464	2.1729	2.2405	2.2027	2.3670	2.3786	2.3587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 304 / 22 KV MANGALWAR TALE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.135	4.0489	3.8844	3.6938	3.882	4.1777	4.0504
2	3.8973	3.876	3.7418	3.5825	3.6976	3.9537	3.8767
3	3.8364	3.8088	3.6245	3.5124	3.6549	3.8005	3.7617
4	3.8416	3.7086	3.6832	3.7753	3.6946	3.6961	3.7647
5	3.8119	3.7128	3.7242	3.7837	3.7662	3.7662	3.8172
6	4.116	4.0699	4.1091	4.0931	4.0497	4.0878	4.2707
7	4.3546	4.065	4.3758	4.2966	4.1198	4.3973	4.4764
8	4.0833	4.2268	4.2287	4.0885	4.2311	4.2875	4.3438
9	4.3713	4.2722	4.1937	4.2722	4.4482	4.3072	4.5146
10	4.2646	4.2813	4.1678	2.3777	2.2085	4.3507	4.4795
11	4.4505	4.4818	4.4357	4.4551	5.4976	4.5862	4.9109
12	4.4326	4.6586	4.6231	4.4139	5.1215	4.7988	4.9002
13	4.5885	4.7059	4.7919	4.4277	4.9844	4.8857	4.8499
14	4.4627	4.4886	4.577	4.5039	4.7104	4.7653	4.7798
15	4.4612	4.4978	4.6147	4.4048	4.7843	4.7257	4.795
16	4.3926	4.587	4.6174	4.4856	4.7691	4.7066	4.9398
17	4.4947	4.6815	4.6174	4.5222	4.854	4.8476	5.0617
18	4.7599	4.8118	4.9947	4.5664	5.1836	4.9353	5.1547
19	5.4561	5.8566	3.1413	5.8391	6.424	6.2749	5.9762
20	5.9991	6.345	6.531	6.3771	6.9818	6.6453	6.7764
21	5.6691	6.0006	5.8787	5.6821	6.6012	6.1805	6.2948
22	5.0263	5.1258	5.1029	5.0831	5.5056	5.3246	5.5007
23	4.843	4.5999	4.7363	4.7371	5.1612	4.9314	5.0922
24	4.4079	4.2649	4.2463	4.1594	4.4018	4.5786	4.4086
Max	5.9991	6.345	6.531	6.3771	6.9818	6.6453	6.7764
Min	3.8119	3.7086	3.1413	2.3777	2.2085	3.6961	3.7617
Avg	4.5065	4.5490	4.4434	4.3806	4.6972	4.7088	4.7832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 305 / 22 KV S. T. STAND

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4362	3.6256	3.3813	3.3676	3.4522	3.5844	3.485
2	3.3249	3.3695	3.2701	3.2564	3.3455	3.3943	3.3234
3	3.2533	3.1908	3.2183	3.1893	3.283	3.2846	3.2609
4	3.2091	3.222	3.2411	3.1481	3.3607	3.248	3.2777
5	3.2922	3.2148	3.3295	3.1901	3.3257	3.3603	3.3867
6	3.4416	3.2426	3.5025	3.3493	3.5772	3.6915	3.674
7	3.6656	3.6926	3.6809	3.5627	3.8028	3.882	3.8714
8	3.6656	3.7018	3.5612	3.5856	3.8775	3.9662	3.7014
9	3.4644	3.5208	3.4194	3.501	3.5886	3.9644	3.6686
10	3.6419	3.5071	3.453	2.1993	1.9174	3.7616	3.7906
11	3.8943	3.6009	3.5642	.98	4.3012	3.8577	4.004
12	3.9563	3.6877	3.4659	4.042	4.2738	3.9955	4.1076
13	3.8275	3.6153	3.815	3.9263	4.1689	4.0946	4.1244
14	3.8561	3.6016	3.7937	3.8104	4.0036	4.0352	4.1198
15	3.8835	3.6108	4.0535	3.8013	4.1304	3.3936	4.257
16	3.8911	3.6108	4.0474	3.9293	4.2268	4.2067	4.2204
17	3.8363	3.6656	4.0672	3.8958	4.2207	4.151	4.2433
18	3.9407	3.6611	4.2021	3.7906	4.4353	4.2676	4.1152
19	4.3983	4.2158	4.4155	4.4414	4.6929	4.8278	4.67
20	5.0891	4.6281	5.0884	4.9139	5.3795	5.2408	5.176
21	4.9181	4.4841	4.8377	4.6441	5.1901	4.933	4.9672
22	4.6361	4.2806	4.4101	4.3713	4.7767	4.5694	4.7112
23	4.3621	4.0513	4.1861	4.1107	4.5724	4.308	4.4628
24	3.9933	3.834	3.6244	3.674	3.94	3.9334	3.8607
Max	5.0891	4.6281	5.0884	4.9139	5.3795	5.2408	5.176
Min	3.2091	3.1908	3.2183	.98	1.9174	3.248	3.2609
Avg	3.8699	3.7015	3.8179	3.6117	3.9935	3.9980	4.0200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR

Feeder No / Name : 301 / 22 KV PIRWADI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.9877	.9511	.9877	.9877	.9877	.9877
2	.9145	.9145	.8779	.9511	1.0242	.9511	.9511
3	.9145	.8779	.8779	.9511	.9145	.9145	.9145
4	.9145	1.0242	.8779	.9511	.9145	.8779	.9511
5	.9511	.8048	.8779	1.0242	.9511	.8779	.9877
6	.9145	.8413	.9511	1.0242	1.0242	.9511	.9877
7	.9145	.9511	.9145	.9877	.9511	1.0242	1.0242
8	.9145	.9511	.9145	.9145	.9511	.9877	.9877
9	.8779	.9511	.9145	.9145	.9511	.9877	.9145
10	.9877	.9145	.9145	.9511	1.0974	.9877	.9877
11	.9511	.9145	.9145	.9511	1.134	1.0242	.9511
12		.8779	.9877	.9145	.9877	1.0608	.9877
13	.2195	.8779	.9511	.9511	.9877	.9877	.9877
14	.8779	.8779	.9145		.9511	.9877	.9877
15	.9145	.9511	.9877		1.0608	.9877	.9877
16		.9145	.9877		1.0608	1.0242	1.0242
17	.9511	.8779	1.0974	1.2071	1.2437	.9877	1.0608
18	.9877	.9145	1.0974	1.0608	1.0608	1.0608	1.0242
19	1.1706	1.0974	1.0974	1.0608	1.2071	1.0974	1.0974
20	1.2803	1.2437	1.2437	1.2803	1.2803	1.3535	1.3169
21	1.2437	1.2071	1.2071	1.2803	1.2803	1.2437	1.2437
22	1.2071	1.2071	1.1706	1.2071	1.3169	1.2803	1.2437
23	1.1706	1.1706	.9511	1.134	1.2803	1.1706	1.2071
24	1.0608	1.0608	1.0242	1.0242	1.0242	1.134	1.0608
Max	1.2803	1.2437	1.2437	1.2803	1.3169	1.3535	1.3169
Min	.2195	.8048	.8779	.9145	.9145	.8779	.9145
Avg	.9677	.9755	.9877	1.0347	1.0684	1.0395	1.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR

Feeder No / Name : 302 / 22 KV SADAR BAZAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.39	1.3535	1.3169	1.134	1.1706	1.39	1.2803
2	1.2071	1.2803	1.3169	1.0974	1.0974	1.3169	1.2437
3	1.0974	1.2071	1.2437	1.0608	1.0974	1.2803	1.2803
4	1.0974	1.2071	1.2437	1.0608	1.0974	1.2071	1.1706
5	1.2071	1.2437	1.1706	1.0974	1.0608	1.2071	1.1706
6	1.2803	1.3169	1.2803	1.1706	1.0974	1.3169	.9511
7	1.3169	1.3535	1.3535	1.2803	1.2803	1.39	1.3169
8	1.3169	1.2437	1.2803	1.2437	1.2071	1.3169	1.3169
9	1.39	1.3169	1.2803	1.2071	1.2437	1.39	1.3169
10	1.1706	1.2437	1.2071	1.0974	1.2437	1.2803	1.2437
11	1.1706	1.2803	1.2437	1.134	1.39	1.2437	1.2437
12		1.2071	1.0974	1.0974	1.1706	1.2071	1.1706
13	1.1706	1.1706	1.134	1.0974	1.134	1.2071	1.2071
14	1.1706	1.134	1.134	1.0974	1.2071	1.2437	1.2071
15	1.3169	1.2071	1.134	1.0974	1.2071	1.2071	1.2437
16	1.2803	1.2071	1.1706	1.134	1.2437	1.2437	1.2437
17	1.2803	.8413	1.2071	1.134	1.2437	1.2803	1.1706
18	1.2803	1.2071	1.2803	1.134	1.5729	1.2437	1.2071
19	1.5364	1.4998	1.4998	1.2803	1.6095	1.4632	1.4632
20	1.7924	1.7193	1.7193	1.5729	1.829	1.7558	1.7193
21	1.7558	1.6461	1.6827	1.6095	1.6827	1.6827	1.7193
22	1.6827	1.6461		1.5364	1.7558	1.7193	1.7193
23	1.6461	1.6095	1.5729	1.4632	1.6827	1.7193	1.7193
24	1.4632	1.4632	1.4632	1.4632	1.3535	1.5364	1.4632
Max	1.7924	1.7193	1.7193	1.6095	1.829	1.7558	1.7193
Min	1.0974	.8413	1.0974	1.0608	1.0608	1.2071	.9511
Avg	1.3487	1.3169	1.3058	1.2209	1.3199	1.3687	1.3245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 302 / 22 KV POWAI NAKA

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 22 / OUTGOING

UTILITY

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	21.3078	20.6905	20.5761	20.5305	20.5304	21.8793	21.765
2	19.936	19.3873	19.4788	19.4559	19.273	20.4618	20.5533
3	19.1587	18.6786	18.7929	18.7243	18.5643	19.7074	19.7531
4	18.7014	18.2213	18.3356	18.2442	18.2213	19.3645	19.273
5	18.6328	18.0384	18.1527	18.2442	18.1984	19.1129	19.2958
6	20.119	19.4788	19.9817	19.776	20.1418	20.6676	21.422
7	21.0334	20.3247	21.1934	20.9877	21.2849	22.0851	22.5652
8	20.9191	20.5533	21.1935	21.1249	21.102	21.8336	22.3594
9	20.7819	20.096	21.0563	20.6676	21.7422	21.8108	21.9022
10	21.5135	20.3704	22.0851	23.8683	22.268	22.8395	22.9995
11	23.5254	20.7133	24.5999	24.5314	24.0742	***	***
12	24.3942	21.0791	***	20.759	***	***	***
13	24.4856	20.7819	***	20.9877	***	***	***
14	24.1427	20.6905	24.7828	20.8962	***	***	***
15	23.5482	21.0334	***	21.6507	***	***	24.92
16	23.251	20.9877	***	24.6914	***	***	***
17	22.6566	21.2849	***	24.6457	***	***	***
18	22.8852	21.8107	***	23.5026	***	***	***
19	***	24.1655	***	23.434	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***	***	***	24.9658	***	***	***
23	***	24.8743	***	24.4171	***	***	***
24	23.3883	23.0681	23.3425	22.7252	24.6	24.4856	24.4399
Max	28.9895	28.1436	30.3155	27.252	30.9786	31.2986	30.3384
Min	18.6328	18.0384	18.1527	18.2442	18.1984	19.1129	19.273
Avg	22.8291	21.5992	23.5111	22.2051	23.9169	24.4580	24.1684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 303 / 22 KV RADHAKRISHNA

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.9849	9.0078	9.0306	8.8706	4.824	8.642	8.5505
2	8.5277	8.9849	9.0764	8.2533	4.8697	8.8477	8.8935
3	9.0764	8.8706	8.8706	8.0247	4.8011	8.482	8.7334
4	8.9392	8.6877	8.7106	7.8875	4.7782	8.2305	8.6648
5	8.3448	8.5048	8.6877	7.7961	4.8697	7.9104	8.6191
6	8.482	8.4362	8.482	7.9333	4.8926	8.0018	8.5277
7	9.0992	8.9392	8.4362	7.5675	6.0585	8.1619	7.6132
8	7.7504	8.2076	8.2305	7.1788	6.5615	8.0018	6.8587
9	10.128	10.4938	9.0992	4.9383	8.2076	10.2195	13.5494
10	11.2712	11.7513	11.0654	4.9611	9.1907	11.5912	11.3398
11	12.1857	11.3855	10.9511	4.8697	6.8587	12.2771	11.4312
12	12.1628	11.2026	10.2881	4.8926	9.5336	11.4769	11.3855
13	10.9054	10.1052	9.8766	4.9383	8.7334	10.8825	10.3567
14	11.797	11.2026	10.4938	4.9154	10.3338	11.0654	10.9054
15	11.957	11.0654	10.9054	4.7782	10.5167	15.5795	10.9968
16	11.4541	11.2712	11.3626	4.8697	10.8596	12.2085	11.4312
17	10.7682	10.7911	10.8596	4.9154	9.9451	11.8427	11.1111
18	13.6934	10.3109	9.8994	4.824	9.7394	10.9511	10.631
19	9.465	9.7394	8.1162	5.0297	9.5108	10.3567	9.6479
20	9.3964	9.3964	7.8189	5.0755	8.8935	9.968	8.6877
21	8.7792	9.2135	8.1619	5.0069	7.6589	8.9849	8.2991
22	9.7851	9.465	8.3448	4.9383	8.2533	9.5336	8.7563
23	9.2821	9.3964	8.1162	4.984	8.5048	9.6708	8.5505
24	9.7622	9.3964	8.9621	5.0297	9.5336	9.7165	8.8477
Max	13.6934	11.7513	11.3626	8.8706	10.8596	15.5795	13.5494
Min	7.7504	8.2076	7.8189	4.7782	4.7782	7.9104	6.8587
Avg	10.0832	9.8261	9.3269	5.9366	7.8304	10.1085	9.6828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 304 / 22KV ARISTOCRAT

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.2669	9.8613	10.2271	8.8706	5.1212	10.2119	10.5929
2	10.2119	10.1052	10.4862	9.5717	5.3193	10.974	11.0197
3	10.0595	10.3643	10.913	9.8308	5.1212	10.3643	10.4557
4	9.6632	9.9375	10.3795	9.4955	4.9383	10.4253	10.2424
5	9.0383	8.0171	9.7546	8.9621	4.8773	9.3583	9.8461
6	9.0078	6.3253	9.6022	8.4438	5.2736	9.2821	10.0137
7	9.8156	9.8766	10.1966	8.6115	5.6699	9.5108	10.4862
8	9.084	7.8189	8.5048	6.4624	7.9561	9.5108	9.6784
9	9.9528	9.6784	10.029	5.2431	9.4193	10.1814	16.5219
10	11.0654	10.6234	10.4405	5.3803	9.4803	10.6844	11.7055
11	11.9951	11.5989	10.8825	5.3803	8.0628	11.7818	11.7055
12	12.1933	11.6598	11.3245	4.8926	10.2271	11.797	11.8275
13	10.5167	10.2576	10.3948	4.8773	9.2212	10.7453	10.1204
14	10.1509	11.4617	9.8918	4.7401	10.4405	11.2788	11.7208
15	10.9435	11.3398	11.5379	4.7554	10.7301	17.4749	11.6446
16	11.3093	10.4405	10.4557	4.7859	10.9587	12.7725	11.3245
17	10.6844	11.0044	10.9282	4.6639	10.41	12.1323	11.5074
18	15.2221	11.2026	10.3033	4.7401	11.5226	11.9951	10.9587
19	9.6632	9.6632	9.7394	4.923	10.2728	10.3033	9.9528
20	10.029	9.7089	10.3033	5.045	10.3186	10.7301	10.1204
21	9.145	8.8554	8.7487	5.1364	9.4955	10.1052	9.8461
22	9.5565	9.968	9.5565	5.3193	10.1204	10.6234	10.3795
23	10.1966	11.2026	9.7394	5.6242	10.3948	10.913	10.8215
24	9.9985	10.2424	8.7182	5.3346	9.968	10.8063	10.5167
Max	15.2221	11.6598	11.5379	9.8308	11.5226	17.4749	16.5219
Min	9.0078	6.3253	8.5048	4.6639	4.8773	9.2821	9.6784
Avg	10.3654	10.0506	10.1274	6.2954	8.5550	10.9984	10.9587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 305 / 22KV OKASA PHARMA

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.1203	.381	1.044	1.105	.9831	1.1888
2	1.2117	1.0212	.381	.9831	1.0669	1.0288	1.1888
3	1.2117	.9831	.3734	.9602	.9907	.9831	1.1507
4	1.1888	.8764	.3887	1.0059	1.0288	1.0059	1.1355
5	1.1507	.8459	.381	.945	1.0212	1.0059	1.1279
6	1.1203	.8154	.3887	.8383	.9602	.9983	1.1126
7	1.2879	.7926	1.0059	1.2041	.9374	1.1203	1.1812
8	1.5927	.381	1.4175	1.448	1.326	1.6766	1.6309
9	2.5606	.3963	2.5072	2.4691	2.4615	2.6292	3.7524
10	2.7206	.4344	2.111	2.652	2.6901	2.7968	2.6597
11	2.7054	.503	2.1262	2.6673	1.1355	2.8654	2.652
12	2.6978	.4954	2.0805	2.6597	2.2939	2.652	2.5758
13	2.6749	.3582	2.0348	2.2329	2.3015	2.7435	2.4996
14	2.8121	.3429	2.05	2.0652	2.431	2.8502	2.5149
15	2.7511	.381	1.989	2.6063	2.3777	3.807	2.5072
16	2.7435	.3429	2.0195	2.7054	2.3777	2.5987	2.4387
17	2.6292	.3429	1.9509	2.652	2.2329	2.5606	2.4082
18	2.8204	.3125	1.5699	2.0652	1.9128	2.0881	1.8214
19	1.5775	.3887	1.4556	1.7756	1.6994	1.7299	1.6232
20	1.7071	.381	1.4784	1.5089	1.4022	1.5394	1.4708
21	1.448	.3734	1.4175	1.2955	1.3717	1.4784	1.3717
22	1.3565	.3734	1.2879	1.3032	1.2955	1.4022	1.3641
23	1.2727	.381	1.2651	1.3108	1.2727	1.3794	1.326
24	1.1888	.3734	1.1736	1.1507	1.044	1.2041	1.1126
Max	2.8204	1.1203	2.5072	2.7054	2.6901	3.807	3.7524
Min	1.1203	.3125	.3734	.8383	.9374	.9831	1.1126
Avg	1.9046	.5423	1.3848	1.7312	1.6140	1.8803	1.8256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 402 / 33KV SIDDHIVINAYAK
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
9			8.4311
15		6.677	
18	10.6945		
Max	10.6945	6.677	8.4311
Min	10.6945	6.677	8.4311
Avg	10.6945	6.677	8.4311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117] BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 406 / 33 KV COOPER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
9			2.999
15		3.3385	
18	3.5082		
Max	3.5082	3.3385	2.999
Min	3.5082	3.3385	2.999
Avg	3.5082	3.3385	2.999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 201 / PARALI-SATARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7027	.6285	.5193	.5655	.6607	.724	.6782
2	.6455	.5502	.5207	.535	.6006	.6822	.658
3	.6219	.5433	.5081	.5216	.5517	.6723	.6078
4	.62	.5529	.5062	.5529	.5605	.5588	.6698
5	.6784	.6041	.6409	.6794	.6405	.5965	.8048
6	.8974	.7628	.8094	.889	.8425	.8612	1.0193
7	.5178	.8591	.5209	1.1572	1.0597	1.0696	1.1012
8		1.0223	1.0145	1.0212	1.0734	1.0932	1.1298
9	.0732	1.0643	.7263	.7925	.5007	1.2186	1.0936
10	.447	1.0063	.9987	.4664	.4466	1.2007	.751
11	.2111	.7453	.8135	.4931		1.1477	.9754
12	.3121	.582	.9998	.471	.8823	1.1244	1.0193
13	.3315	.8	.9664	.4371	.8358	.8631	.9233
14	.3098	.7903	.8253	.141	.751	.8672	.8459
15	.5636	.7944	.4024	.6874	.7396	.8493	.8642
16	1.1075	1.006	.4508	.4024	.7419	1.015	.9599
17	1.1061	.5609		.7861	.7924	1.0863	.4607
18	1.0677	.6817	.8939	.8886	.8697	.9846	.5045
19	1.2509	1.1963	1.3192	1.2534	1.2829	1.2666	.9617
20	1.5954	1.4776	1.535	1.5542	1.4712	1.5516	1.472
21	1.3687	1.3948	1.5333	1.511	.7811	1.5002	1.4531
22	1.2803	1.2441	.7491	1.3245	.7598	.7251	1.3196
23	.9134	.5323	.5963	.9934	.6085	.5594	.976
24	.7377	.724	.7796	.711	.7998	.7807	.7236
Max	1.5954	1.4776	1.535	1.5542	1.4712	1.5516	1.472
Min	.0732	.5323	.4024	.141	.4466	.5588	.4607
Avg	.7548	.8385	.8100	.7848	.7936	.9583	.9155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 202 / THOSEGHAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2075	.2263	.2263	.2263	.2263	.2241
2	.1886	.1886	.1886	.2263	.1886	.2452	.2241
3	.1886	.1886	.1886	.2075	.1698	.2452	.2241
4	.1886	.1886	.2641	.2075	.1886	.2452	.2614
5	.2452	.2263	.2641	.2614	.2263	.2452	.2987
6	.3206	.3206	.3018	.3361	.3206	.2641	.3921
7	.3395	.3734		.3734	.3772		.4294
8	.3921	.3961	.415	.3734	.3772	.3961	.3921
9		.4108	.415	.3921		.4338	.3734
10		.3734	.4066	.3395	.3961	.4668	.3696
11		.3361	.3696	.2641		.4108	.4066
12		.3174	.3326		.3961	.3921	.3881
13		.3174	.3475		.3772	.3174	.3174
14		.3361	.3511		.3584	.3361	.3734
15		.3361	.3696		.3395	.3547	.3696
16		.3361	.3326		.3772	.3174	.3696
17	.3772			.4207	.3772	.3921	.3696
18	.415	.415	.4066	.4024	.4338	.3921	.4066
19	.4481	.4527	.5228	.5121	.5281	.5228	.5175
20	.6161	.5281	.5281	.6401	.547	.5228	.4805
21	.5601	.4715	.5281	.5487		.5041	.4435
22	.4108			.4024			.4108
23	.3174			.3142			.3174
24	.2641	.2641	.2263	.2263	.2641	.2641	.2801
Max	.6161	.5281	.5281	.6401	.547	.5228	.5175
Min	.1886	.1886	.1886	.2075	.1698	.2263	.2241
Avg	.3425	.3326	.3493	.3513	.3405	.3569	.3600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 203 / Nitral Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	.0189	***	***	***	***	***	***
3	.0189	.0189	***	***	***	***	***
4	.0189	.0189	***	***	***	***	***
5	.0377	***	***	***	***	***	***
6	***	***	***	***	***	***	***
7	***	***	***	***	***	***	***
8	***	***	***	***	***	***	***
9	***	***	***	***	***	***	***
10	***	***	***	***	***	***	***
11	***	***	***	***		***	***
12	***	***	***	***	***	***	***
13	***	***	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	***	***	***	***	***	***	***
17	***	***		***	***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	***	***	***	***
Max	114.4427	152.548	152.548	152.548	114.4252	152.5292	114.444
Min	.0189	.0189	38.104	38.104	38.1229	38.1229	38.1413
Avg	54.0276	61.9659	61.3549	66.7188	69.6263	76.2701	68.3408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 204 / PARALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7253	.9724	.0189				.6371
2	.7362	.9724	.0189				.6371
3	.7449	.9724					.6706
4	.7164	1.0059					.7042
5	.7748	1.0059					.8048
6	.8223	1.0277					.9667
7	.9122	1.0774					1.1797
8	.9568	1.0111					1.2452
9			1.5257	1.3599		1.2517	
10			1.6766	1.5089		1.5565	
11			1.6263			1.5779	
12			1.5089		1.3769	1.5813	
13			1.5746		1.3769	1.0031	
14			1.5249		1.4523	1.4074	
15			1.4918		1.5089	1.406	
16			1.442			1.3441	
23	.9614						
24	.7499	.9614	.0189				
Max	.9614	1.0774	1.6766	1.5089	1.5089	1.5813	1.2452
Min	.7164	.9614	.0189	1.3599	1.3769	1.0031	.6371
Avg	.8100	1.0007	1.1298	1.4344	1.4288	1.391	.8557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 201 / 11 KV ANGAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9247	1.8646	.1086	.1294	.1307	.0914	2.0785
2	1.9146	1.8384	.1176	.127	.127	.0905	2.0388
3	1.9079	1.8318					2.0255
4	1.9012	1.8875					1.989
5	1.8811	1.94					2.0857
6	1.8778	2.3189					2.1594
7	2.1192	2.13					2.3807
8	2.0387	2.094					2.357
9			2.0119	2.6155	2.6222	2.8837	
10			2.7362	2.6825	2.7496	2.9038	
11				2.4679		2.763	
12			2.649	2.366		2.6423	
13			2.602	2.2742	2.4664	2.5953	
14			2.4813	2.2087	2.4914	2.4545	
15	.085	.0841	2.3338	2.0873	2.3472	2.4277	.0784
16	.0957	.0924		2.0664	2.2277	2.4746	.1232
17	.127	.0823	2.2466	.0934	.0686	.1035	.1344
18	.1363	.1176	.0914	.0859	.144	.1552	.1195
19	.1531	.1357	.1072	.1568	.163	.1867	.1531
20	.1606	.1902	.1552	.1755	.1262	.1922	.1606
21	.127	.2048	.168	.1755	.0905	.1792	.1232
22	.1438	.1075	.1441	.1344	.0886	.1568	.0971
23	1.8974	.1075	.1294	.1195	.0796	.1368	.1718
24	1.9314	1.8744	.1205	.127	.1307	.0732	.1441
Max	2.1192	2.3189	2.7362	2.6825	2.7496	2.9038	2.3807
Min	.085	.0823	.0914	.0859	.0686	.0732	.0784
Avg	1.1346	1.0501	1.1377	1.1163	1.0033	1.2506	1.0233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 202 / 11 KV ANGAPUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.298	.2769	.2913	.2817	.2743	.2957
2	.289	.2867	.2658	.2809	.278	.2606	.295
3	.2817	.2801	.2534	.2801	.2743	.2507	.2883
4	.3073	.3062	.2353	.2698	.289	.2991	.2987
5	.3365	.3137	.274	.3174	.3146	.3185	.3137
6	.4188	.3286	.4353	.3918	.3585	.4572	.4463
7	.3676	.3641	.4163	.4444	.4024	.4075	.4694
8	.4072	.3846	.4207	.4033	.3731	.3926	.4369
9	.3207	.3454	.3182	.3366	.3286	.3292	.3731
10	.3185	.3211	.289	.3344	.3099	.3402	.3475
11		.3398	.2689	.284		.3201	.3109
12	.2675	.2801	.3365	.2743		.3	.289
13		.267	.278	.2778	.3062	.2963	.2643
14		.268	.2743	.2349	.2577	.3054	
15	.298	.2476	.268	.2587	.2763	.3146	.3059
16	.2941	.3105		.257	.2689	.3292	.2926
17	.3435	.298	.2846	.289	.3086	.2987	.3137
18	.3566	.3167	.377	.331	.3035	.3174	.3043
19	.4649	.3403	.4332	.3765	.4252	.4182	.3809
20	.4621	.439	.4518	.4163	.4764	.4854	.5004
21	.4112	.3898	.4369	.4018	.4525	.4369	.4406
22	.3846	.3801	.3958	.3747	.4243	.3992	.4014
23	.3323	.3201	.3363	.3312	.3164	.3473	.3398
24	.2963	.3025	.2872	.2987	.2926	.2896	.3137
Max	.4649	.439	.4518	.4444	.4764	.4854	.5004
Min	.2675	.2476	.2353	.2349	.2577	.2507	.2643
Avg	.3453	.322	.3310	.3232	.3327	.3412	.3488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 204 / 11 KV JIHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5593	.5774	.518	.4725	.5228	.5174	.5661
2	.552	.5356	.4639	.4676	.481	.4664	.5624
3	.5447	.5356	.4614	.4676	.4737	.4664	.5505
4	.5667	.5087	.4729	.4615	.4993	.4737	.5439
5	.5813	.5423	.4938	.5281	.5249	.5281	.5476
6	.3457	.6409	.738	.7014	.6831	.682	.7544
7	.406	.8336	.7377	.7809	.7651	.7614	.8187
8	.3695	.8019	.7684	.747	.7794	.7468	.7582
9	.3721	.6827	.716	.6237	.6827	.6959	.714
10	.3155	.6866	.6011	.606	.6827	.6739	.6723
11	.3277	.6715	.6176	.6584		.6831	.6121
12	.3189	.5908	.6066	.6168	.381	.6922	.6212
13	.3155	.758	.541	.5972	.7394	.6868	.6048
14	.3277	.6868	.6157	.5255	.7163	.6011	.3048
15	.3366	.7582	.6264	.5325	.6827	.652	.6433
16	.351	.6866	.3429	.5532	.7318	.6959	.6941
17	.3716	.6672	.7691	.6358	.7963	.7358	.7488
18	.3809	.746	.7768	.6157	.6999	.6259	.76
19	.5713	.9278	1.0107	.8045	.9427	.8597	.909
20	.5321	1.0822	1.1056	1.0493	1.274	1.0787	1.0731
21	.4929	1.0273	1.06	.9388	1.1584	1.0264	.9805
22	.4742	.9053	.9024	.8191	.8554	.9053	.8866
23	.3772	.6984	.6678	.6506	.7026	.7851	.7208
24	.3	.5811	.5774	.5281	.5282	.3429	.6116
Max	.5813	1.0822	1.1056	1.0493	1.274	1.0787	1.0731
Min	.3	.5087	.3429	.4615	.381	.3429	.3048
Avg	.4204	.7139	.6746	.6409	.7088	.6826	.6941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 205 / 11 KV VIJAY NAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4754	1.5424	1.4284	1.3468	
2			1.3765	1.5156	1.4251	1.2803	
3			1.3125	1.5091	1.4184	1.2334	
4			1.3443	1.4787	1.4318	1.2452	
5			1.4519	1.4951	1.4452	1.1863	
6			1.4899	1.5961	1.472	1.2485	
7			1.6221	1.6414	1.586	1.4419	
8			1.6095	1.6196	1.5592	1.4287	
9	2.0354	2.146					1.9448
10	2.0466	2.1602					2.0253
11	2.0873	2.0287					2.0222
12	1.9271	1.9784					2.1527
13	2.1628	1.9492					2.079
14	2.0354	2.0253					
15	2.0222	2.089					1.9028
16	1.9669	1.9683					1.8631
23		1.4563	1.6263	1.4486	1.3916		
24			1.4877	1.6095	1.4318	1.4609	
Max	2.1628	2.1602	1.6263	1.6414	1.586	1.4609	2.1527
Min	1.9271	1.4563	1.3125	1.4486	1.3916	1.1863	1.8631
Avg	2.0355	1.9779	1.4796	1.5456	1.4590	1.3191	1.9986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 206 / Tasgaon Ag Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0317	.0411	.7406	.8383	.9422	1.1633	.034
2	.0299	.0411	.6879	.8139	.9355	1.012	.0299
3			.6802	.788	.9288	.9995	
4			.6554	.7902	.9188	.9765	
5			.6478	.7964	.9188	1.0224	
6			.8586	.8718	.8986	1.1595	
7			.9831	1.0127	1.0864	1.2492	
8			.9156	.9657	1.0059	1.3599	
9	1.4419	1.4955					1.8442
10	1.4627	.0537					2.146
11	1.3279	.0671					2.0885
12	1.2398	1.4582					1.8778
13	1.399	1.4188					1.9649
14		1.6799					
15	1.399	1.6296	.0224	.0343	.0373	.0224	1.9559
16	1.326	1.405		.0358	.049	.0224	1.8896
17	.0485	1.1468	.0485	.0392	.0578	.0336	.0485
18	.0485	.1134	.037	.0411	.0478	.0523	.0523
19	.0523	.0982	.0336	.0411	.0358	.0554	.0528
20	.0485	.1086	.0336	.0448	.0366	.0377	.0485
21	.0448	.0443	.0377	.0448	.0351	.0377	.0485
22	.0411	.078	.0336	.0411	.0362	.0411	.0453
23	.0411	.8834	.9255	.9791	1.2138	.0415	.0453
24	.0299	.0411	.8061	.8852	.9523	1.1854	.0336
Max	1.4627	1.6799	.9831	1.0127	1.2138	1.3599	2.146
Min	.0299	.0411	.0224	.0343	.0351	.0224	.0299
Avg	.5890	.6558	.4792	.5035	.5632	.5818	.8356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 201 / 11 KV VALASE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7773	.0343	.0297		.0594	
2	.8059	.7773	.0343	.0297		.0594	
3	.7888	.7362					
4	.8059	.7362					
5	.823	.8097					
6	.8573	.8745					
7	1.0288	1.0159					
8	1.0631	.9555					
9			1.0288				
10			1.1317	1.166	1.5432	2.8807	
11			1.1488			2.6578	
12			1.0974		1.5089	2.572	
13			1.0974		2.3834	2.5034	
14			1.0974		2.8807	2.572	
15		.0514	.8916	.9431	2.6578	2.7092	.0514
16		.0514	.823	1.2174		2.5206	
17			.0514	1.1317	2.6063		.0514
18	.0446	.0514	.0446	1.1145	2.4291	.0686	.0686
19	.0446	.0514	.0297		.0446	.0343	.0514
20	.0446	.0686	.0297		.0594	.0514	.0514
21	.0446	.0686	.0297		.0594	.0514	.0514
22	.0446	.0514	.0297		.0594	.0514	.0514
23	.8097	.0343	.0297		.0594	.0514	.0514
24	.8402	.8097	.0343	.0297		.0594	.0514
Max	1.0631	1.0159	1.1488	1.2174	2.8807	2.8807	.0686
Min	.0446	.0343	.0297	.0297	.0446	.0343	.0514
Avg	.5912	.4659	.4813	.7077	1.3576	1.1814	.0533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 204 / 11 KV SHENDRE-VECHALE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1894	2.3701	4.2181	4.1464	3.844	.1501
2	.1802	.1833	4.4228	4.1282	4.0977	3.7966	.0686
3	.0899	.0899	4.4213	3.9857	4.0451	3.7547	
4	.0991		4.3789	3.9964	3.9971	3.719	
5	.0953		4.4585	3.7571	4.0753	3.7326	
6	.1059		4.5972	3.6237	4.7755	3.9049	
7			4.6502	3.4667	4.7325	4.3072	
8	.3601		2.4348	2.2721	4.8263	4.59	
9	4.6406	4.0985	2.3815	.8543	2.1658	1.8008	3.8881
10	5.9816	5.6005					5.0069
11	3.0483	5.6539					5.6966
12	3.1085	5.7103					5.0766
13	3.0148	5.5373					5.5841
14	2.8913	5.4496					5.6306
15	2.729	5.2675	.0343			.1059	5.5308
16	2.5408	5.349	.0373	.1029		.16	5.4089
17	2.4973	2.7534	.0343	.1052		.1844	2.878
18	.2496	.2233	.0998	.0655	.0877	.189	.1936
19	.2473	.2248	.2008	.0693	.1394	.2119	.1832
20	.269	.2942	.2565	.0008	.2537	.2503	.2286
21	.261	.301	.2588	.0793	.2484	.2549	.2264
22	.2519	.2838	.2431		.2115	.2271	.2203
23	.2443	3.7301	3.8394	3.2983	1.3146	.1977	.2038
24	.2065	2.4482	4.5115	4.2486	3.9876	1.8907	.1924
Max	5.9816	5.7103	4.6502	4.2486	4.8263	4.59	5.6966
Min	.0899	.0899	.0343	.0008	.0877	.1059	.0686
Avg	1.4477	2.8099	2.2964	2.2513	2.6940	1.9538	2.5760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 205 / VALASE (GAONTHAN)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3326	.3258	.3326	.3429	.3511	
2	.3429	.3326	.3086	.2926	.3086	.3326	.3086
3	.3258	.3142	.3086	.2926	.3086	.3292	.3086
4	.3429	.3511	.3429	.3142	.3262	.3292	
5	.3601	.3734	.3944	.3174	.3601	.3696	.3429
6	.3944	.4294	.4458	.3734	.4287	.4108	.3944
7	.4458	.4294	.5144	.4481	.463	.4481	.4458
8	.3772	.3696	.1715	.3921	.4458	.4108	.4458
9	.4287	.3696	.1715				.3601
10	.3944		.2058	.4115	.3772	.4115	.4115
11			.2401	.3944	.4115	.4468	
12		.3944	.2572	.3601	.3944	.4458	.3601
13		.3772	.2401		.3944	.3601	.3601
14		.3429	.2401		.3944	.4115	.3772
15		.3429	.4115		.3429	.3601	.3944
16		.3772	.4115	.3944		.3944	.3772
17		.3772	.3772		.3944		.3429
18	.4668	.4801	.3881		.462	.463	.3772
19	.5041	.5144	.5601		.4294	.5487	.3772
20	.6161	.5487	.6348	.4801	.5975	.6516	.6173
21	.6161	.5144	.6161	.5316	.5601	.6173	.583
22	.4668	.4973	.5788	.4973	.5601	.5658	.5144
23	.4481	.4287	.462	.4115	.4668	.4458	.463
24	.3772	.3696	.3429	.3696	.3601	.3921	.3601
Max	.6161	.5487	.6348	.5316	.5975	.6516	.6173
Min	.3258	.3142	.1715	.2926	.3086	.3292	.3086
Avg	.4275	.4030	.3729	.3890	.4150	.4316	.4058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 302 / LIMB

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3734	.3856	.4108	.415	.3856	.4108
2	.3734	.415	.3467	.3734	.3734	.3898	.3734
3	.3734	.415	.3544	.3734	.3734	.3467	.3734
4	.3734	.4108	.3506	.3734	.3734	.3544	.3734
5	.3734	.4481	.3814	.3734	.415	.3506	.3734
6	.3734	.4435	.3544	.4108	.4481	.3506	.3734
7	.4435	.5121	.4557	.4854	.4854	.3467	.4854
8	.5121	.4706	.4207	.3734	.439	.567	.4854
9	.7712	.7095	.7164	.3506	2.3411	.695	.5792
10	.8505	.8962	.9465	.3155	2.2314	.8048	.905
11	.9922	1.2696	.9816			1.2071	1.0387
12	1.0631	1.1949	.9214	.4252	.8048	1.0974	1.0608
13	.7796	1.1576	.9214	.4607		.8871	.905
14	1.0631	1.0456	1.0387	.4161	.695	.9145	.6219
15	1.1222	1.0082	1.0631	.4252	.7602	1.0974	.8413
16	1.2757	1.1203		.4755	.7682		1.1584
17	.4755	.9816	1.1576	.394	.631	.9335	1.0974
18	.4344	.5316	.7842	.3544	.4607	.8215	.7164
19	.4298	.4207	.5228	.4024	.3506	.5228	.439
20	.439	.4961	.5228	.4066	.3856	.4854	.439
21	.5175	.4252	.4854	.4854	.4207	.4854	.4481
22	.4854	.4252	.4854	.4854	.4207	.4854	.4108
23	.4108	.3898	.4481	.4527	.3856	.4481	.4481
24	.439	.3734	.3898	.4481	.415	.3506	.4108
Max	1.2757	1.2696	1.1576	.4854	2.3411	1.2071	1.1584
Min	.3734	.3734	.3467	.3155	.3506	.3467	.3734
Avg	.6159	.6639	.6276	.4118	.6542	.6229	.6154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 303 / 22 KV VARYE MIX

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.531	1.3169	1.262	1.358	1.4045	1.3321
2	1.39	1.5089	1.2197	1.1218	1.3443	1.3443	1.262
3	1.3676	1.5089	1.1949	1.1218	1.3443	1.3306	1.262
4	1.3535	1.5684	1.1706	1.1218	1.5684	1.3169	1.262
5	1.3817	1.7924	1.2197	1.3321	1.7353	1.3169	1.4022
6	1.643	1.922	1.7741	1.6126	1.9418	1.6632	1.6827
7	2.2546	2.0119	2.1948	2.0683	2.1285	2.1068	1.858
8	2.3411	2.0995	2.4508	2.1033	2.3045	2.3045	2.1033
9	2.4143	2.2436	2.4714	2.2314		2.3411	2.0774
10	2.4764	2.3137	2.3137	1.7372		2.3045	2.0416
11	2.4025	2.2786	2.1033			2.2443	2.0271
12	2.3411	1.9631	2.1262	1.9589	2.1948	2.0119	1.8823
13	2.1948	1.858	1.9845	1.9022	2.3045	2.0119	1.8099
14	2.0908	1.893	2.0416	1.5364	2.1582	1.9753	1.7558
15	2.2443	1.893	2.0199	1.7372	2.0633	1.922	1.7924
16	2.2325	2.2085		1.9022	2.1216		1.8823
17	1.9753	2.3045	2.2436	2.1491	2.4143	1.7528	1.9753
18	2.2443	2.3655	2.0332	2.2325	2.5133	2.1033	2.2207
19	2.364	2.5019	2.2786	2.3045	2.5503	2.3838	2.3411
20	2.524	2.4272	2.2085	2.2177	2.5133	2.4188	2.2314
21	2.3655	2.1582	1.9982	1.9044	2.2916	2.1735	2.1285
22	2.0911	2.0119	1.7878	1.8298	2.0328	1.858	1.9791
23	1.7551	1.6827	1.5424	1.5466	1.7002	1.5424	1.7177
24	1.6057	1.531	1.4415	1.3321	1.358	1.4266	1.3672
Max	2.524	2.5019	2.4714	2.3045	2.5503	2.4188	2.3411
Min	1.3535	1.5089	1.1706	1.1218	1.3443	1.3169	1.262
Avg	2.0228	1.9824	1.8755	1.7507	1.9972	1.8808	1.8081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 304 / 22 KV RAMNAGAR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2702	.2461	2.322	2.6182	2.705	2.2916	.1966
2	.2542	.2435	2.1838	2.5377	2.6757	2.2325	.1852
3	.1387	.0854	2.1358	2.4878	2.6383	2.228	.0724
4			2.0969	2.4261	2.678	2.2165	
5			2.2173	2.5244	2.8563	2.2855	
6			2.7431	2.7142	3.142	2.6105	
7			3.3928	3.2579	3.4903	3.1669	
8			3.4031	3.1573	3.5201	3.3833	
9	4.0299	4.0687	1.057	1.0174	1.0547	.9998	4.0908
10	4.4776	4.2879					4.7646
11	4.7675	4.467					4.7896
12	4.4898	4.4951					4.5771
13	4.2432	4.1823					4.3903
14	4.4711	3.8973					4.1449
15	4.4044	3.8855	.2987	.2473	.2572	.2606	4.3202
16	4.1994	3.7277	.1501	.2667	.269	.16	4.2882
17	1.7589	1.427	.3209	.3239	.2588	.2987	1.579
18	.5148	.2527	.3323	.3208	.3102	.3048	.285
19	.4915	.2995	.3505	.3605	.3125	.3548	.3018
20	.3917	.3262	.3769	.3753	.3109	.3609	.3483
21	.3761	.2809	.3563	.3308	.3033	.3616	.3528
22	.3155	.2611	.3232	.3285	.2679	.3214	.3521
23	.2988	2.479	2.4673	2.5754	.2656	.2977	.3072
24	.2896	1.4281	2.5491	2.6296	1.4689	.2405	.2412
Max	4.7675	4.4951	3.4031	3.2579	3.5201	3.3833	4.7896
Min	.1387	.0854	.1501	.2473	.2572	.16	.0724
Avg	2.1149	2.1232	1.5304	1.6053	1.5150	1.2829	2.0835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 201 / KOPARDE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2637	1.358					1.2071
2	1.2637	1.3203					1.2071
3	1.2826	1.2826					1.2209
4	1.2826	1.2696					1.2209
5	1.2637	1.307					1.2071
6	1.3014	1.358					1.2378
7	1.2826	1.3443					1.4243
8	1.2637	1.4937					1.5424
9			1.3957	1.9605	1.6956	1.8652	
10			1.5089	1.9978	1.8442	2.0119	
11			1.5278	1.9978		2.0517	
12			1.5278	1.9978		1.989	
13			1.5278	2.0165	1.8313	2.0008	
14			1.5466	2.0538	1.8313	2.0622	
15			1.6975	2.0538	1.8991	2.0119	
16					1.8313	1.643	
22						.0189	
23	1.3443					.0189	
24	1.2449	1.3817					.0189
Max	1.3443	1.4937	1.6975	2.0538	1.8991	2.0622	1.5424
Min	1.2449	1.2696	1.3957	1.9605	1.6956	.0189	.0189
Avg	1.2793	1.3461	1.5332	2.0111	1.8221	1.5674	1.1429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 202 / VENEGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.415	.3734	.362	.3395	.3258	.3582
2	.3395	.3772	.3734	.362	.3395	.3224	.3403
3	.3395	.3395	.3361	.3439	.3395	.3258	.3403
4	.3772	.3361	.3361	.3403	.3772	.3224	.333
5	.415	.4481	.3361	.3982	.3772	.4163	.3403
6	.5281	.5281	.4668	.4344	.4527	.6154	.5731
7	.4904	.5975	.5975	.5731	.4904	.6447	.631
8	.4527	.5228	.4668	.5228	.4904	.5373	.5068
9	.3772	.4706	.4527	.4854	.4344	.5121	.4344
10	.4904	.4298	.3961	.4481		.439	.3696
11	.3696	.4163	.3961	.4108		.3582	.3696
12	.415	.3761	.3772			.3582	.4066
13	.3658	.1791	.3772	.3921	.362	.3366	
14	.3547	.3258		.3921	.3582	.3801	.4435
15	.3696	.362	.3772	.3921	.362	.362	.4344
16	.4066	.3734			.3982	.3582	
17	.4298	.4344	.4344	.415		.4163	.415
18	.4298	.4706	.4706	.5281	.3921	.5014	.5658
19	.6154	.631	.5068	.5281	.6348	.5792	.6224
20	.7316	.6805	.7316	.6979	.6722	.7316	.7545
21	.6653	.6584	.6767		.6908	.6878	.7167
22	.5975	.6413	.5792			.5731	.5658
23	.4854	.4904	.5068		.5228	.5373	.4527
24	.4715	.4481	.4108	.3982	.415	.3258	.4298
Max	.7316	.6805	.7316	.6979	.6908	.7316	.7545
Min	.3395	.1791	.3361	.3403	.3395	.3224	.333
Avg	.4555	.4563	.4536	.4434	.4447	.4570	.4729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 203 / NANDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	2.4646	1.8991	2.452	2.0622	.0377
2		.0377	4.3759	1.8564	2.4709	2.0622	.0377
3			2.4646	1.8778	2.452	2.1195	
4			2.452	1.9161	2.452	2.1795	
5			2.6139	1.9669	2.452	2.2043	
6			2.6513	2.1704	2.452	2.2043	
7			2.6886	2.2542	2.4897	2.3472	
8			2.6886	2.2382	2.4709	2.2298	
9	3.0933	2.9843					3.0849
10	3.6969	3.2236					3.8439
11	3.6214	3.1539					3.77
12	3.5101	3.0864					3.77
13	3.3951	2.8509					
14	3.2114	2.4813					3.4004
15	3.1367	2.6452	.0038				3.7647
16	3.0308	2.5774					
17	.0377					.0377	.0038
18	.0377					.0377	.0038
19	.0381	.0377			.0373	.0377	.0038
20	.0381	.0377	.0038	.0038		.0566	
21	.0381	.0377	.0038			.0377	
22	.0381	.0377	.0038			.0377	
23	.0381	2.4897	2.3061		2.2405	.0377	
24		.0377	2.4646	2.2969	2.4143	2.0622	.0377
Max	3.6969	3.2236	4.3759	2.2969	2.4897	2.3472	3.8439
Min	.0377	.0377	.0038	.0038	.0373	.0377	.0038
Avg	1.7974	1.6098	1.9418	1.8480	2.2167	1.2346	1.8132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 201 / 11 KV DEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1012		.056	.0709	.056	.056	1.3413
2	.9717		.056	.0724	.056	.056	1.3889
3	.9717						1.4198
4	.9717						1.4373
5	1.1797						1.5623
6	1.1934						1.692
7	1.4083	.8179					1.9528
8	1.3923	.7811					1.8278
9			1.1203	1.704	1.5684	2.1216	
10			1.6804	1.7695	.1943	2.1925	
11			1.7341	1.7238		2.0715	
12			1.7236	1.5912	2.0153	1.9925	
13			1.6446	1.4091	2.0153	1.8435	
14			1.5813	1.4419	1.8278	1.7341	
15	.0693	.0543	.9686	1.2651	1.8122	1.9134	.0924
16	.0709			1.2955	1.8343	1.9757	.056
17	.1629	.0543	.5761	.0914	.0739	.0732	.0739
18	.1646	.0724	.1097	.0549	.0747	.168	.0924
19	.1463	.0716	.1267	.0739	.0747	.0924	.0943
20	.1463	.0732	.1086	.0716	.0747	.0934	.0943
21	.1646	.0739	.0716	.0732	.0747	.0934	.0943
22	.1494	.0747	.0716	.056	.0739	.168	.1132
23	1.1248	.056	.0724	.0373	.0739	.168	.0943
24	1.1797	1.0936	.056	.0716	.056	.056	.1867
Max	1.4083	1.0936	1.7341	1.7695	2.0153	2.1925	1.9528
Min	.0693	.0543	.056	.0373	.056	.056	.056
Avg	.6983	.293	.6916	.7152	.7033	.9372	.7563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 202 / VARNE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1109	.3315	.4858	.4374	.6554	.168
2	.1267	.1109	.3113	.3201	.4428	.547	.1867
3			.2743	.3361	.427	.5155	
4			.2572	.3401	.4424	.463	
5			.2538	.3681	.4096	.4475	
6			.3475	.4096	.4049	.6249	
7			.6167	.6081	.5851	.823	
8			.6081	.639	.6327	.9069	
9	.7956	.6167					1.3117
10	.8223	.7362					1.3108
11	.6562	.7045					1.2793
12		.5121					1.2323
13	.6062	.5281					1.2003
14	.4938	.4641					1.1385
15	.4428	.4752	.1928	.1578	.1848	.2033	1.1385
16	.4961	.4696		.1867	.1848	.2614	1.0623
17	.2012	.208	.2241	.1307	.1478	.2614	.2218
18	.2195	.1753	.1848	.1848	.1867	.2614	.2218
19	.1829	.1595	.1867	.1663	.2054	.2427	.2402
20	.1267	.1612	.1494	.1494	.1848	.2427	.2614
21	.1478	.1433	.132	.1109	.1848	.2427	.2427
22	.1307	.1448	.112	.1494	.1663	.2054	.2054
23	.1448	.4096	.5121	.463	.7459	.1509	.1848
24	.1646	.128	.3812	.5407	.4687	.128	.168
Max	.8223	.7362	.6167	.639	.7459	.9069	1.3117
Min	.1267	.1109	.112	.1109	.1478	.128	.168
Avg	.3472	.3477	.2986	.3193	.3579	.3991	.6541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 203 / DEGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3641	.8502	.4251	.4119	.4298		.3814
2	.3429	.3881	.4066	.3801	.394	.4066	.3601
3	.3429	.3881	.3658	.362	.394	.4108	.3601
4	.3429	.3881	.3841	.3582	.394	.3696	.3601
5	.3601	.4207	.362	.4119	.4298	.3881	.4115
6	.4207	.4938	.5487	.4784	.4835	.5121	.5201
7	.4458	.5258	.591	.5138	.5973	.543	.543
8	.4287	.4382	.567	.5316	.567	.4656	.4908
9	.3988	.5028	.5194	.5258	.5375	.5068	.5083
10	.4477	.4557	.4694	.4607	.4409	.4334	.4908
11	.4334	.4334	.4917	.4298		.4578	.4973
12		.4748	.5316	.4525	.4287	.4239	.4607
13	.4656	.5138	.208	.4382	.4239	.4024	.9568
14	.463	.5316	.4733	.394	.4382	.4239	.9816
15	.4908	.567	.4607	.5068	.4382	.4287	.9716
16	.4656	.5609		.4706	.9466	.3856	1.1568
17	.4908	.5316	.4908	.4784	1.0028	.4508	1.0402
18	.4908	.5194	.4784	.4607	.5121	.4557	.9362
19	.4334	.5731	.4784	.5316	.6283	.5609	1.1157
20	.7442	.6154	1.2963	.6089	.6838	.6626	.6516
21	.6697	.6335	.6626	.5973	.6535	.6401	.6219
22	.6154	.6335	.6089	.5973	.5973	.5731	.567
23	.5028	.5121	.5316	.5249	.4938	.4887	.4382
24	.3856	.4287	.462	.5014	.4938	.4066	.4163
Max	.7442	.8502	1.2963	.6089	1.0028	.6626	1.1568
Min	.3429	.3881	.208	.3582	.394	.3696	.3601
Avg	.4585	.5158	.5136	.4761	.5395	.4694	.6349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 204 / 11 KV CHINCHNER GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2694	.2753	.2502	.3971	.3955	.3033	.2995
2	.2633	.27	.2438	.3635	.3818	.2946	.2941
3	.2585	.2658	.2349	.3538	.3407	.2942	.2881
4	.2661	.2746	.2453	.3586	.3407	.2728	.2915
5	.3025	.3322	.2945	.4022	.3666	.2835	.3477
6	.4504	.4412	.4058	.5323	.411	.346	.4545
7	.2503	.4923	.4477	.5814	.4878	.3714	.435
8	.4228	.573	.4157	.5475	.4016	.3357	.4052
9	.3649	.4188	.3628	.4715	.4237	.3387	.3346
10	.3007	.2974	.3652	.394	.4367	.4211	.3704
11	.278	.3378	.0989	.3304	.2206	.3765	.3361
12	.1517	.2176	.0941	.322	.4138	.3476	.3189
13	.2518	.2172	.3765	.3151	.3424	.3944	.3109
14	.2583	.2297	.3708	.2985	.3723	.3662	.3401
15	.2669	.1981	.3536	.3223	.4009	.3517	.3332
16	.2894	.1574		.3389	.3868	.3574	.3449
17	.3761	.346		.3795	.3132	.3708	.3647
18	.4569	.4017		.399	.3412	.3605	.3321
19	.5109	.4793	.6325	.5689	.447	.4618	.4352
20	.5567	.4615	.7049	.6335	.5033	.5548	.5513
21	.5131	.463	.6737	.6386	.4879	.5182	.5304
22	.4879	.4287	.6279	.6051	.4359	.4883	.4634
23	.3784	.3327	.5197	.5395	.37	.4161	.4113
24	.3147	.3208	.3254	.4664	.4611	.2937	.3503
Max	.5567	.573	.7049	.6386	.5033	.5548	.5513
Min	.1517	.1574	.0941	.2985	.2206	.2728	.2881
Avg	.3433	.3430	.3830	.4400	.3951	.3716	.3726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 205 / 11KV VARNE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5094	.5069	.5045	.5174	.4793	.5382	.4921
2	.4515	.4688	.4481	.4793	.4639	.4481	.4366
3	.4344	.4664	.4481	.4589	.4412	.4298	.4366
4	.4344	.4664	.4389	.4639	.4435	.4504	.4366
5	.4687	.4664	.4639	.4639	.4435	.4664	.5121
6	.5647	.5439	.5744	.5502	.482	.5712	.6759
7	.3429	.7708	.7453	.7531	.6795	.7929	.743
8	.7068	.762	.7236	.6523	.603	.7056	.6645
9	.7277	.6723	.6325	.5931	.6203	.6306	.6342
10	.6264	.6233	.5761	.5555	.5822	.5677	.6344
11	.5121	.5449	.5422	.4614	.2667	.5791	.562
12	.2667	.5096	.4896	.4277	.3048	.562	.5239
13	.497	.477	.4896	.4277	.4344	.4871	.5268
14	.4995	.4589	.4515	.4256	.4031	.4725	.5239
15	.4435	.5148	.2286	.4096	.4235	.4713	.4871
16	.4664	.5174	.2286	.4614	.4235	.5148	.5094
17	.5121	.497	.2286	.5148	.5532	.5441	.5121
18	.5441	.5174	.4944	.5706	.3048	.6614	.5121
19	.6759	.6272	.6028	.6414	.6306	.6515	.711
20	.8089	.7811	.7531	.7468	.8215	.8691	.7992
21	.743	.8173	.7213	.7468	.8215	.8373	.7468
22	.7285	.7594	.6506	.7136	.6721	.7285	.7102
23	.6203	.6355	.6294	.6294	.2926	.6506	.6264
24	.3048	.5475	.5045	.5382	.2507	.5582	.5609
Max	.8089	.8173	.7531	.7531	.8215	.8691	.7992
Min	.2667	.4589	.2286	.4096	.2507	.4298	.4366
Avg	.5371	.5813	.5238	.5501	.4934	.5912	.5824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 201 / 11 kv BHATMARALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.8048	.8573	.9431	.8259	.0381
2	.0343		.7432	.8916	.9431	.759	.0381
3			.7432	.8916	.9808	.7712	
4			.703	.9431	1.0374	.759	
5			.7537	.9945	1.1317	.8025	
6			.8162	.9945	1.1694	1.0159	
7			1.1984	1.2517	1.2071	1.2967	
8			1.1822			1.2944	
9	1.4575	1.2452					1.4712
10	1.4922	1.56					1.5278
11	1.4548	1.4746					1.5089
12	1.4419	1.4413					1.4146
13	1.2967	1.278					1.4523
14	1.3077	1.2125					1.4523
15	1.1405	1.1142	.0343	.0381	.0316	.0343	1.4523
16	1.2574	1.2289		.0381	.0312	.0381	1.3203
17	.0343	.0335	.0343	.0343	.0316	.0381	.0514
18	.0343	.0335	.0343	.0377	.0324	.0572	.0514
19	.0343	.0474	.0514	.0343	.0469	.0572	.0343
20	.0343	.064	.0514	.0377	.0486	.0572	.0514
21	.0343	.0625	.0343	.0377	.0503	.0572	.0343
22	.0343	.0469	.0343	.0343	.048	.0572	.0343
23	.0343	.8745	.9259	.7356	.9503	.0572	.0343
24	.0343		.8097	.8573	.8676	.8962	.0381
Max	1.4922	1.56	1.1984	1.2517	1.2071	1.2967	1.5278
Min	.0343	.0335	.0343	.0343	.0312	.0343	.0343
Avg	.6218	.7811	.5267	.5123	.5618	.4930	.6670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 202 / 11 KV KUSAVADE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572		.3189	.2572	.2829	.2835	.2858
2	.2058		.2753	.2058	.2263	.2804	.3048
3	.2058		.298	.2058	.2263	.2772	.3429
4	.0206		.2865	.2401	.2641	.2149	.3239
5	.2743		.3155	.2743	.3206	.2835	.3429
6	.3086		.3544	.3772	.3772	.4755	.4763
7	.3944	.4287	.4031	.4458	.4904	.4656	.5335
8	.463	.3944	.3801		.4904	.4525	.4954
9	.4784	.4191	.3258	.381	.4252	.4115	.4527
10	.4477	.4572	.3601	.4191	.3898	.4115	.4338
11	.4706	.4572	.3429	.4191		.4115	.3961
12	.4298	.4763		.4382	.4733	.3429	.3584
13	.4435		.3429	.1905	.4119	.3086	.3206
14	.3734	.3429	.3086	.3429	.3898	.3772	.3961
15	.2658	.3048	.3086	.3429	.3721	.3772	.415
16	.3547	.4252		.3429	.3506	.3048	.2263
17	.3429	.4607	.2915	.3429	.3582	.3048	.3086
18	.3944	.4252	.3086		.3898	.3429	.3258
19	.4287	.5316	.3772	.3601	.543	.4954	.5487
20	.5316	.5258	.4801	.4458	.6089	.5716	.4973
21	.3315	.4733	.5144	.463	.5792	.5716	.463
22	.4458	.4207	.4458	.547	.4755	.4572	.3944
23	.3601	.4207	.3772	.3961	.3681	.381	.3258
24	.2572		.3506	.3086	.3584	.3224	.3048
Max	.5316	.5316	.5144	.547	.6089	.5716	.5487
Min	.0206	.3048	.2753	.1905	.2263	.2149	.2263
Avg	.3536	.4352	.3530	.3521	.3988	.3802	.3864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 203 / 11 kv PADALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289	1.749	.1296	.0343	.1132	.1174	.6316
2	1.5432	.1715	.1311	.0343		.1094	.6226
3	1.5775	1.749					.5765
4	1.5432	1.7661					.5868
5	1.5089	1.8004					.6783
6	1.5089	1.8519					.7969
7	1.8519	1.869					.9431
8	1.8347	1.8004					.9156
9			2.7263	2.6216	2.7328	2.0748	
10				2.7362	2.0119	2.0576	
11			1.6289	2.6216		2.0405	
12				2.7778	1.9281	1.8861	
13			2.0576	2.3537	1.8515	1.8347	
14			2.1262	2.332	1.8299	1.6289	
15	.1509	.1524	2.7949	2.5232	1.7859	1.5432	.132
16	.1406	.1524		2.5774	1.6716	1.7337	.1509
17	.1543	.1475	.1372	.1372	.1006	.1524	.0343
18	.1715	.1457	.1543	.1372	.0937	.1524	.0343
19	.1715	.1457	.1543	.1372	.1006	.1524	.0343
20	.1715	.1619	.1543	.1372	.1311	.1524	.0343
21	.1543	.1619	.1543	.1372	.1174	.1524	.0343
22	.1543	.144	.1372	.0943	.1341	.1143	.1372
23	1.7318	.1543	.0343	.1132	.1341	.1143	.0343
24	1.6804	1.7661	.1457	.0034	.1132	.1296	.0953
Max	1.8519	1.869	2.7949	2.7778	2.7328	2.0748	.9431
Min	.1406	.144	.0343	.0034	.0937	.1094	.0343
Avg	.9821	.8827	.8444	1.1949	.9281	.8970	.3596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 204 / 11 KV NINAM GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2572	.2629	.1715	.1886	.3658	.2858
2	.2058	.2401	.2481	.1543	.1698	.3258	.2858
3	.2058	.2229	.2427	.1543	.1646	.2804	.2858
4	.2572	.2058	.2743	.1715	.1886	.3189	.2667
5	.3429	.2229	.3366	.2572	.2829	.362	.3429
6	.3772	.2743	.3856	.3772	.4527	.4525	.4763
7	.4287	.4115	.4298	.3944	.4338	.4887	.4954
8	.463		.4525		.415	.4706	.381
9	.3982	.5906	.3944	.362	.6335	.3258	.5093
10	.5434	.8954	.5658	.3048	.691	.3086	.4904
11	.5434	.9907	.4115	.3048		.3258	.547
12	.4344	.9145		.381	.5434	.6859	.9431
13	.439	.5716	.5487	.2477	.5959	.9774	.7545
14	.3658	.9145	.6344	.2667	.6661	.8573	.7545
15	.5316	.7621	.6687	.2667	.3544	.8573	.9619
16	.5914	.6668			.6379	.6668	1.0374
17	.5658	.823	.6687	.1715	.5847	.5716	
18	.6001	.7059	.8916	.2572	.6805	.5716	.8916
19	.823	.7362	.6001	.3772	.5784	1.1431	.3944
20	.703	.5068	.7202	.4973	.6089	.9907	.4801
21	.5144	.4887	.6687	.4115	.6154	1.1812	.463
22	.5144	.4344	.703	.415	.5552	.4572	.3944
23	.3429	.3366	.3429	.3395	.4382	.381	.3429
24	.2572	.3258	.2896	.2572	.3395	.3982	.3048
Max	.823	.9907	.8916	.4973	.691	1.1812	1.0374
Min	.2058	.2058	.2427	.1543	.1646	.2804	.2667
Avg	.4439	.5434	.4882	.2973	.4704	.5735	.5256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 301 / PIMPODE Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	.9922	.7682	.1715	.16	.096	.2058
2	1.0288	.8962	.7682	.1715	.128	.096	.2058
3	1.0288	.8322	.7682	.1715	.128	.096	.2058
4	1.0288	.8322	.8322	.2058	.128	.096	
5	1.2003	.8962	1.0242	.2401	.192	.128	.2058
6	1.4746	1.3123	1.0883	.2743	.2881	.192	.2401
7	2.2634	1.9204	1.3443	.3086	.2881	.192	.2401
8	2.1948	1.8244	1.5043	.2743	.2561	.16	.2058
9	.2401	.2561	1.4723	1.7833	1.5684	1.6004	.2058
10	.16	.096	1.4746	1.7284	.096	1.7147	.096
11	.16	.16		1.5043	.096	1.749	.096
12	.16	.096	1.3032	1.3443	1.6004	1.4403	.096
13	.16	.096	1.3375	1.1203	1.3443	1.2689	.096
14	.2241	.096	1.3443	1.0562	1.2163	1.3375	.128
15	.16	.096	1.2003	1.1203	1.2483	1.4403	.128
16	.16	.096	1.5775	1.2803	1.3763	1.7147	.128
17	.16	.16	.2743	.128	.16	.1715	.128
18	.2241	.128	.2743	.2241	.16	.2058	.16
19	.2561	.16	.3086	.2241	.16	.2401	.2241
20	.3201	.2241	.3086	.2561	.192	.2401	.2561
21	.2881	.16	.2743	.2561	.192	.2401	.2561
22	.2881	.16	.2743	.2561	.16	.2401	.192
23	1.1843	.8962	.2058	.2241	.128	.2401	.192
24	1.3375	1.1203	.8002	.1715	.192	.096	.2058
Max	2.2634	1.9204	1.5775	1.7833	1.6004	1.749	.2561
Min	.16	.096	.2058	.128	.096	.096	.096
Avg	.7000	.5628	.8925	.6040	.4774	.6248	.1781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 302 / 22KV PIMPODE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.381	.3361	.3429	.3429	.3361	.3086
2	.3772	.3429	.2987	.3429	.3429	.3361	.3086
3	.3772	.3429	.2987	.3429	.3429	.3361	.3086
4	.3772	.3429	.3361	.3429	.3429	.3734	.3429
5	.4115	.4572	.4108	.3772	.381	.4108	.3772
6	.4115	.4904	.4854	.3772	.5658	.4108	.4115
7	.5144	.4854	.5975	.4115	.5601	.3361	.4458
8	.4801	.5228	.5228	.3772	.5228	.4481	.3772
9	.4458	.5121	.4854	.4458	.4435	.3734	
10	.4755	.4854	.3772	.439	.4481	.3772	.4481
11	.5121	.4481		.4481	.5228	.4115	.4108
12	.5068	.4481	.3429	.4108	.4108	.4458	.4108
13	.3258	.4108	.3772	.4481	.4108	.4458	.4108
14	.362	.4108	.3772	.3658	.3734	.4115	.3734
15	.2896	.3734	.3772	.3658	.3734	.4115	.3734
16	.4706	.3734	.4458	.3696	.4481	.3772	.3734
17	.4024	.4108	.3772	.4607	.4481	.4458	.3734
18	.3814	.4481	.3772	.3544	.4108	.4115	.3734
19	.5792	.5975	.5487	.5068	.5601	.5487	.5228
20	.7023		.6516	.7095	.7468	.6859	.7468
21	.7023	.7468	.6173	.6348	.7095	.6173	.7095
22	.5975	.6348	.5487	.5601	.5975	.5487	.5975
23	.5281	.4481	.4115	.4527	.4481	.4458	.4854
24	.4115	.415	.3734	.3429	.3772	.4108	.3772
Max	.7023	.7468	.6516	.7095	.7468	.6859	.7468
Min	.2896	.3429	.2987	.3429	.3429	.3361	.3086
Avg	.4591	.4578	.4337	.4262	.4638	.4315	.4290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 303 / SONKE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3361	.3086	.3429	.2987	.2743
2	.3429	.3429	.3361	.3086	.3429	.2987	.2743
3	.3429	.3048	.2987	.2743	.3429	.2987	.2743
4	.3772	.3048	.3734	.3086	.3429	.2987	.2743
5	.4115	.3429	.4481	.3429	.3429	.4481	.4115
6	.5487	.5281	.5601	.4458	.5658	.5228	.4801
7	.5487	.6348	.5975	.4801	.4854	.5975	.5144
8	.5144	.6348	.5228	.4801	.5601	.4854	.5144
9	.4458	.4755	.4854	.4801	.4435	.4481	.4458
10	.439	.3734	.4115	.439	.4108	.3772	.3734
11	.4344	.4108	.3772	.3658	.3734	.3429	.2614
12	.3982	.4108	.3086	.4024	.3734	.3086	.2987
13	.3982	.4108	.3086	.3292	.3734	.2743	.3361
14	.3258	.4108	.3086	.2926	.2987	.2743	.3361
15	.362	.3734	.3361		.2987	.2743	.3361
16	.362	.2987	.3429	.2926	.2987		.3361
17	.3544	.3361	.3429	.3258	.2987	.2743	.2987
18	.3544	.3734	.3772	.2835	.2987	.3772	.2987
19	.5068	.4854	.4458	.4344	.4481	.4115	.4481
20	.6722	.6722	.583	.5975	.5975	.5487	.5975
21	.6348	.6348		.5975	.5601	.583	.5975
22	.5658	.5228	.4458	.4904	.4854	.4801	.4854
23	.4904	.3734	.3429	.3772	.3734	.3772	.3734
24	.3772	.3772	.3361	.3086	.3395	.3361	.3086
Max	.6722	.6722	.5975	.5975	.5975	.5975	.5975
Min	.3258	.2987	.2987	.2743	.2987	.2743	.2614
Avg	.4410	.4323	.4011	.3898	.3999	.3885	.3812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 304 / 22 KV SONAKE AG FEEDER
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429	.2949	.6173	.5312	.5898	.4801
2	.2743	.3429	.2949	.5487	.5312	.5243	.4458
3	.2743	.3429	.2949	.5487	.5312	.5243	.4458
4	.2743	.3429	.3277	.5487	.5312	.5243	.4801
5	.2743	.381	.3605	.6173	.5312	.6554	.4801
6	.3086	.381	.3605	.7545	.6249	.7865	.5487
7	.4115	.415	.3932	.9259	.8124	.8848	.583
8	.3429	.3772	.2949	.7545	.7186		.6173
9	.823	.759	.3277	.2743	.2667	.2949	.6859
10	.7682	.8848	.3086	.3395	.3605	.3086	.7537
11	.7011	.8192	.3429	.3772	.2294	.3086	.7537
12		.7209	.3086	.3395	.2949	.2743	.7209
13	.5868	.6882	.2743	.3429	.2622	.2743	.6554
14	.5868	.6554	.2743	.3429	.2294	.2743	.6226
15	.5868	.7209	.2743	.3429	.2294	.2743	.5898
16	.6161	.7209	.2743	.3395	.2622	.3086	.6554
17	.3048	.3277	.3086	.3395	.2622	.3429	.2949
18	.3429	.2949	.3086	.3429	.2622	.3429	.2949
19	.3429	.3605	.3429	.415	.3277	.3772	.2949
20	.4191	.3277	.3429	.3772	.3605	.3772	.3277
21	.3429	.3277	.3429	.3772	.2949	.3429	.2949
22	.381	.2949	.3429	.381	.2949	.3086	
23	.3429	.3605	.7888	.6325	.3605	.3086	.2949
24	.3429	.3429	.2949	.6173	.5556	.2949	.3429
Max	.823	.8848	.7888	.9259	.8124	.8848	.7537
Min	.2743	.2949	.2743	.2743	.2294	.2743	.2949
Avg	.4329	.4805	.3366	.4790	.4027	.4132	.5071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 305 / 22 KV WATHAR (GAOTHAN)

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5914	.5975	.5487	.5544	.4854	.4458
2	.4458	.5544	.5228	.5487	.4435	.4854	.4458
3	.4458	.5544	.4108	.5487	.4435	.5228	.4458
4	.4801	.5914	.5228	.5144	.4066	.5975	.4801
5	.5487	.6653	.5601	.5487	.4066	.6348	.5144
6	.5487	.7023	.5601	.583	.6283	.6722	.5487
7	.583	.6653	.5975	.583	.7023	.7095	.5487
8	.5144	.5914	.6722	.5487	.5914	.6348	.583
9	.4458	.5175	.5975	.4801	.5544	.5975	.4801
10	.5175	.4854	.4458	.4805	.5975	.6173	.4481
11	.6653	.5228	.6173	.5914	.6348	.7545	.4481
12	.4435	.6722	.5487	.3326	.4854	.7545	
13	.6653	.4854	.4458	.4805	.7468	.7202	.5601
14	.5175	.4854	.4458	.6283	.4854	.7545	.5601
15	.4805	.4481	.4458		.7468	.7888	.5601
16	.5544	.5975	.5487	.6653	.6722	.823	.5601
17	.6653	.5228	.4458	.6653	.6722	.7545	.5601
18	.7762	.4108	.7202	.7023	.5601	.7888	.5975
19	.6653	.7468	.7202	.6283	.8215	.6859	.7095
20	.7762	.7842	.7545	.8501	.8589	.7628	.8215
21	.7762	.7468	.583	.7392	.7842	.7545	.8215
22	.6653	.7842	.583	.6653	.7095	.6859	.7468
23	.5175	.5228	.5487	.7392	.6722	.5487	.6722
24	.4801	.6653	.6722	.5487	.6283	.7468	.583
Max	.7762	.7842	.7545	.8501	.8589	.823	.8215
Min	.4435	.4108	.4108	.3326	.4066	.4854	.4458
Avg	.5691	.5964	.5653	.5922	.6170	.6784	.5714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 306 / 22 KV WATHAR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.1523	1.1142	.3429	.3201	.2949	.3086
2	1.2689	1.0883	1.0486	.3429	.3201	.2949	.3086
3	1.2346	1.0562	1.0486	.3429	.3201	.2949	.3086
4	1.2346	1.0562	1.1142	.3429	.3201	.3277	.3086
5	1.2346	1.0883	1.1797	.3772	.3521	.3932	.3429
6	1.3717	1.4083	1.2452	.4458	.3841	.426	.3429
7	2.0576	1.9204	1.4419	.5144	.4161	.426	.3772
8	1.9547	1.7604	1.5729	.4801	.3201	.3277	.3772
9	.2743	.2561		1.989	1.5684	1.704	.3772
10	.2881	.3277		1.8564	1.5729	1.749	.2294
11	.2881	.3277	1.6804	1.7604	1.4419	1.7147	.2294
12	.3201	.2622	1.5432	1.4403	1.3108	1.5775	.1966
13	.2561	.2622	1.406	1.3443	1.3108	1.4403	.2294
14	.2561	.2949	1.5089	1.2163	1.3108	1.5089	.2622
15	.2561	.2622	1.5466	1.2163	1.1797	1.5775	.2949
16	.2881	.3361	1.406	1.3443	1.3108	1.6804	.2622
17	.3201	.2949	.2743		.2622	.2743	.2622
18	.3201	.2622	.3772		.3277	.3429	.2622
19	.3521	.3277	.4115	.2561	.3277	.3772	.3277
20	.3841	.3932	.4458	.3841	.3605	.3772	.3932
21	.3521	.3605	.4115	.3841	.3605	.3772	.3605
22	.3201	.3932	.4115	.3521	.3277	.3772	.3605
23	1.3123	1.278	.3772	.3201	.3277	.3772	.3277
24	1.406	1.2163	1.1797	.3429	.3201	.3277	.3429
Max	2.0576	1.9204	1.6804	1.989	1.5729	1.749	.3932
Min	.2561	.2561	.2743	.2561	.2622	.2743	.1966
Avg	.7787	.7244	1.0339	.7907	.6822	.7737	.3080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 307 / 22 KV Nandwal AG Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4163	1.2894	.9419	.4504	.4405	.375	.3856
2	1.2913	1.1248	.852	.452	.4382	.3643	.3742
3	1.2403	1.0898	.8832	.4154	.4375	.3673	.3719
4	1.132	1.0349	.8634	.4154	.439	.3742	.3849
5	1.1435	1.0745	.9137	.4626	.4436	.6279	.6721
6	1.3972	1.3131	1.0783	.7483	.6527	.8116	.8459
7	2.3727	2.1734	1.5615	1.3123	1.105	1.0722	.9115
8	2.6128	2.3022	1.7741	1.0456	1.0163	.8688	.7697
9	2.5675	2.13	1.7947	1.9071	1.7391	1.7147	.7445
10	.788	.7628	1.8309	2.1125	2.0058	2.1685	.6127
11	.6767	.7293	.6535	1.9875	.1265	2.125	.6744
12	.5533	.7194	1.4735	1.7634	1.9517	1.8164	.6744
13	.4923	.5777	1.5531	1.5051	1.8839	1.5131	.5662
14	.5419	.583	1.4437	1.2978	1.5356	1.3911	.5434
15	.5651	.6294	1.3668	1.2521	1.4434	1.4437	.5738
16	.5441	.7163	1.664	1.4358	1.7063	1.901	.6775
17	.2019	.2721	1.2288	1.2338	1.4502	1.6152	.2286
18	.2545	.2698	.2823	.2599	.285	.2076	.2606
19	.3041	.285	.2854	.2842	.256	.2435	.2995
20	.3452	.3536	.3425	.33	.3056	.2953	.3376
21	.3483	.3452	.3334	.3246	.2721	.2861	.3277
22	.3444	.317	.3204	.3132	.2705	.2854	.3262
23	1.3839	1.0578	.7156	.5404	.2454	.2884	.3414
24	1.4651	1.0425	.266	.5349	.4763	.2591	.3174
Max	2.6128	2.3022	1.8309	2.1125	2.0058	2.1685	.9115
Min	.2019	.2698	.266	.2599	.1265	.2076	.2286
Avg	.9993	.9247	1.0176	.9327	.8719	.9340	.5092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 301 / 22KV Koregaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	24-APR-17
HR	Load (MW)
1	.2439
Max	.2439
Min	.2439
Avg	.2439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 303 / 22 KV DEURGAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2439	.3048	.2743	.2439	.3429	.3429
2	.4115	.2439	.3048	.2743	.2439	.3772	.3772
3	.3772	.2439	.3048	.3086	.2439	.3429	.4115
4	.4115	.2743	.3048	.3086	.3048	.3429	.3772
5	.4115	.3658	.3658	.3429	.3658	.4115	.4115
6	.4458	.4268	.4572	.4801	.3658	.4458	.5144
7	.4801	.5182	.4572	.5144	.4572	.4458	.4801
8	.3772	.4572	.4572	.3429	.3963	.4115	.4458
9	.4268	.4458	.4115	.3963	.3429	.2743	.3772
10	.3658	.3429	.3772		.4115	.3772	.3772
11	.3353	.3429	.3429	.3658	.3429	.3429	.4115
12	.3048	.2743	.3772	.3353	.3429	.3429	.3772
13	.3353	.3772	.3429	.3353	.3772	.2401	.4115
14	.3048	.3772	.3429	.3048	.3429	.2743	.3772
15	.3048	.3772	.3772	.3048	.3429	.2401	.4115
16	.3658	.3429		.3658	.3429	.3429	.4115
17	.3658	.3658	.3772	.3658	.3429	.4115	.3772
18	.4268	.3963	.3772	.2439	.3429	.5144	.3429
19	.5182	.4877	.5487	.4268	.4115	.5487	.5487
20	.6097	.5792	.7202	.5487	.7202	.6859	.6859
21	.5487	.5792	.6173	.5487	.6859	.6173	.583
22	.5487	.5487	.583	.4877	.5144	.4801	.5487
23	.4572	.4877	.4458	.3658	.4115	.4115	.4115
24	.4115	.3658	.3658	.4115	.3353	.3772	.3772
Max	.6097	.5792	.7202	.5487	.7202	.6859	.6859
Min	.3048	.2439	.3048	.2439	.2439	.2401	.3429
Avg	.4134	.3944	.4158	.3762	.3847	.4001	.4329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 304 / 22KV KINHAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3658	.3658	.4115	.3658	.5144	.4801
2	.4801	.3658	.3658	.4458	.3658	.5144	.4458
3	.4115	.3658	.3658	.4458	.3658	.4801	.4115
4	.4458	.4572	.4572	.4458	.4572	.4115	.4115
5	.5144	.5182	.5182	.5144	.5487	.5144	.5487
6	.6173	.6097	.6097	.6859		.6173	.7202
7	.7545	.7316	.6706	.7888		.583	.6859
8	.7202	.6401	.5487	.6516		.6859	.6859
9	.5487	.6516	.5487	.6097		.6173	.5487
10	.4572	.583	.583	.4877		.4458	.5144
11		.583	.5144	.4268	.4115	.4115	.583
12		.4115	.5487	.4268	.5487	.4458	.5144
13	.5487	.5487	.5144	.4572	.5144	.5487	.5487
14	.4877	.5144	.5487	.4877	.6173	.5144	.4115
15	.4877	.4115	.5144	.4572	.6173	.5487	.4115
16	.5182	.4458	.5487	.4877	.6173	.5487	.4458
17	.5487	.4572	.5487	.1219	.6173	.6173	.5487
18	.5792	.5487	.6516	.1219	.6859	.7888	.6516
19	.7316	.5792	.7888	.823	.9259	.823	.823
20	.7926	.7926	.9259	.9145	.9602	1.0288	.9259
21	.7316	.7316	.7545	.7621	.8916	.9602	.7545
22	.6097	.6401	.6516	.6401	.6859	.6859	.7202
23	.5182	.5182	.5487	.4877	.6173	.5144	.5487
24	.5144	.4572	.4572	.4458	.4572	.5487	.4801
Max	.7926	.7926	.9259	.9145	.9602	1.0288	.9259
Min	.4115	.3658	.3658	.1219	.3658	.4115	.4115
Avg	.5650	.5387	.5646	.5228	.5932	.5987	.5758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 301 / WATHAR i.e. 22KV KINHAI SEPARATED AG FEEDERS HAVING SPECIAL
 AG. Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11							6.9273
13		6.31				.2058	
14			.3086				
24	.2743	.2774	5.1181	5.6242	5.9534	.4115	.4115
Max	.2743	6.31	5.1181	5.6242	5.9534	.4115	6.9273
Min	.2743	.2774	.3086	5.6242	5.9534	.2058	.4115
Avg	.2743	3.2937	2.7134	5.6242	5.9534	.3087	3.6694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 303 / 22 KV COOPER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11							1.8176
13		.7545				.4458	
14			.8916				
24	.5487	.6935	1.1568	1.166	1.4175	1.4746	1.7147
Max	.5487	.7545	1.1568	1.166	1.4175	1.4746	1.8176
Min	.5487	.6935	.8916	1.166	1.4175	.4458	1.7147
Avg	.5487	.724	1.0242	1.166	1.4175	.9602	1.7662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 304 / 22KV BHUINJ i.e. 22KV SEPARATED AG FEEDERS HAVING SPECIAL
DEUR AG Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11							.3772
13		.3429				7.8189	
14			7.6818				
24	6.1728	6.1721	.3506	.4115	.3544	.3772	.3429
Max	6.1728	6.1721	7.6818	.4115	.3544	7.8189	.3772
Min	6.1728	.3429	.3506	.4115	.3544	.3772	.3429
Avg	6.1728	3.2575	4.0162	.4115	.3544	4.0981	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 406 / 33KV WANGANA LIS

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	23-APR-17	24-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11				.0514
13	.0514		.0514	
14		.0514		
Max	.0514	.0514	.0514	.0514
Min	.0514	.0514	.0514	.0514
Avg	.0514	.0514	.0514	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 407 / 33KV VASANA

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	23-APR-17	24-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11				.0514
13	.0514		.0514	
14		.0514		
Max	.0514	.0514	.0514	.0514
Min	.0514	.0514	.0514	.0514
Avg	.0514	.0514	.0514	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 201 / 11 KV Aundh Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0732	.0732	.0724	.0724	.0938	.1897
2	.0709	.0732	.0732	.0724	.0724	.0724	.0862
3	.0732	.0732	.0732	.0724	.0701	.0732	.0793
4	.0709	.0732	.0732	.0724	.0724	.0732	.1174
5	.0717	.0914	.0732	.0724	.0762	.112	.1448
6	.1877	.1882	.2179	.1978	.2016	.2187	.2339
7	.2362	.2461	.24	.2336	.2374	.2568	.2385
8	.2313	.2095	.2293	.2079	.229	.2027	.2187
9	.1848	.1639	.1448	.1707	.1387	.1608	.1775
10	.1578	.1464	.1639	.1669	.141	.1509	.192
11	.122	.1433	.1425	.1608	.0983	.1509	.1364
12	.1372	.1646	.1425	.157	.1121	.2072	.1235
13	.157	.1639	.1464	.1654	.1555	.2355	.1113
14	.1662	.1464	.154	.1562	.1608	.2438	.1257
15	.1494	.1631	.154	.1616	.1608	.2438	.1724
16	.1532	.1578	.1578	.1562	.1464	.2416	.1747
17	.1677	.1685	.1646	.1776	.1471	.2377	.1877
18	.1677	.2217	.1858	.1972	.1014	.2233	.2332
19	.2103	.2553	.2288	.2212	.2133	.3132	.256
20	.3216	.3048	.2936	.273	.3208	.3513	.2888
21	.3056	.3147	.274	.2709	.298	.3445	.269
22	.2667	.3018	.2322	.2338	.2644	.2949	.23
23	.2065	.269	.1852	.1814	.224	.2667	.1951
24	.1578	.1159	.189	.1014	.1555	.1836	.2141
Max	.3216	.3147	.2936	.273	.3208	.3513	.2888
Min	.0709	.0732	.0732	.0724	.0701	.0724	.0793
Avg	.1686	.1762	.1672	.1647	.1612	.2064	.1832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 202 / 11 KV Aundh AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2846	.3772	.0362	.0362	.0366	.0366
2	.2915	.2846	.3772	.0362	.0362	.0366	.0366
3	.2915	.2846	.3772	.0362	.0362	.0366	.0366
4	.3772	.3163	.3772	.0362	.0362	.0366	.0366
5	.4287	.3479	.3772	.0362	.0362	.0366	.0366
6	.5144	.3795	.4115	.0543	.0362	.0366	.0366
7	.6001	.4999	.4801	.0543	.0362	.0366	.0366
8	.6001	.5218	.5853	.0543	.0362	.0366	.0366
9	.0366	.0366	.5144	.4344	.3401	.463	.0366
10	.0366	.0366	.4801	.4525	.4374	.5316	.0366
11	.0366	.0366	.4287	.3239	.3906	.4801	.0366
12	.0366	.0366	.4287	.3563	.3953	.463	.0354
13	.0366	.0366	.4287	.4858	.3593	.4801	.0354
14	.0366	.0366	.4287	.4049	.3637	.4801	.0354
15	.0366	.0366	.4755	.421	.3593	.5144	.0354
16	.0366	.0366	.4801	.502	.4218	.5658	.0354
17	.0366	.0366	.0366	.0362	.0366	.0366	.0354
18	.0366	.0366	.0362	.0362	.0366	.0366	.0366
19	.0366	.0366	.0543	.0543	.0366	.0366	.0549
20	.0549	.0366	.0543	.0543	.0366	.0366	.0543
21	.0549	.0366	.0362	.0362	.0549	.0366	.0366
22	.0366	.0366	.0362	.0362	.0549	.0366	.0366
23	.3005	.3772	.0362	.0362	.0366	.0366	.0366
24	.2572	.2812	.3772	.0362	.0362	.0366	.0366
Max	.6001	.5218	.5853	.502	.4374	.5658	.0549
Min	.0366	.0366	.0362	.0362	.0362	.0366	.0354
Avg	.1861	.1704	.3206	.1688	.1536	.1902	.0378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 303 / BHOSARE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.506	.7545	.0724	.0724	.0732	.0732
2	.3429	.506	.7545	.0724	.0724	.0732	.0732
3	.3429	.506	.7545	.0724	.0724	.0732	.0732
4	.3429	.506	.7545	.0724	.0724	.0732	.0732
5	.5144	.5693	.7545	.0724	.0724	.0732	.0732
6	.7087	.5693	.7545	.0724	.0724	.0732	.0732
7	.8573	.9488	1.0288	.0724	.0724	.0732	.0732
8	1.086	.9374	1.0974	.0724	.0724	.0732	.0732
9	.0732	.0732	1.0288	.9717	.9717	.9259	.0732
10	.0732	.0732	.9602	1.1222	.9998	1.0288	.0732
11	.0732	.0732	.8573	.9717	.9374	.9602	.0709
12	.0732	.0732	.8573	.8097	.7907	.8916	.0709
13	.0747	.0732	.7545	.8097	.6958	.823	.0709
14	.0732	.0732	.8573	.8421	.6958	.823	.0709
15	.0732	.0732	.9602	.8097	.6874	.8779	.0709
16	.0732	.0732	1.0288	.9717	.7811	.8916	.0709
17	.0732	.0732	.0732	.0648	.0732	.0732	.0709
18	.0732	.0732	.0724	.0724	.0732	.0732	.0732
19	.0732	.0732	.0724	.0724	.0732	.0732	.0732
20	.0732	.0732	.0724	.0724	.0732	.0732	.0732
21	.0732	.0732	.0724	.0724	.0732	.0732	.0732
22	.0732	.0732	.0724	.0724	.0732	.0732	.0732
23	.6325	.7545	.0724	.0724	.0732	.0732	.0732
24	.3429	.5693	.7545	.0724	.0724	.0732	.0732
Max	1.086	.9488	1.0974	1.1222	.9998	1.0288	.0732
Min	.0732	.0732	.0724	.0648	.0724	.0732	.0709
Avg	.2725	.3082	.6342	.3525	.3218	.3497	.0725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 304 / BHOSARE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.5487	.5121	.2896	.2896	.5487	.5487
2	.2926	.5487	.5121	.2896	.2896	.5487	.5487
3	.2926	.5487	.5121	.2896	.2896	.5487	.5121
4	.2926	.5487	.5853	.2896	.2896	.5487	.5121
5	.4344	.6584	.6584	.362	.362	.6584	.5853
6	.5068	.7316	.8048	.4344	.4344	.7316	.7316
7	.6584	.5487	.5853	.5792	.5792	.6584	.5853
8	.6584	.5487	.5487	.543	.543	.5487	.5487
9	.439	.5487	.5121	.4344	.4344	.362	.5121
10	.439	.439	.5121	.4344	.439	.3658	.3658
11	.3658	.439	.3658	.4344	.3658	.439	.3658
12	.3658	.439	.3658	.4344	.3658	.5121	.3544
13	.3658	.439	.3658	.4706	.3658	.5121	.3544
14	.3658	.439	.3658	.3982	.3658	.5121	.3658
15	.3658	.439	.3658	.4344	.3658	.5121	.3658
16	.439	.439	.3658	.4344	.3658	.5121	.439
17	.3658	.4755	.439	.4344	.3658	.5487	.439
18	.5487	.5853	.4344	.4344	.439	.5487	.5487
19	.6584	.6219	.543	.543	.5487	.7316	.567
20	.8048	.8048	.6516	.6516	.7316	.8048	.6379
21	.8413	.7316	.6516	.6516	.7316	.8048	.5853
22	.7316	.7316	.543	.543	.6584	.7316	.5487
23	.5487	.5853	.4344	.4344	.5487	.5853	.4252
24	.2926	.5487	.5121	.362	.362	.5487	.5487
Max	.8413	.8048	.8048	.6516	.7316	.8048	.7316
Min	.2926	.439	.3658	.2896	.2896	.362	.3544
Avg	.4736	.5579	.5061	.4419	.4388	.5760	.4998

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 305 / KHATAV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3775	1.581	1.6403	1.3382	1.3211	2.297	1.6599
2	1.326	1.5444	1.5318	1.2822	1.2811	2.2509	1.6153
3	1.2917	1.5101	1.5204	1.2662	1.2616	2.2417	1.5924
4	1.3512	1.5021	1.5124	1.2582	1.2262	2.309	1.5558
5	1.4906	1.6221	1.6506	1.3763	1.3466	2.5389	1.6781
6	1.8964	1.869	1.8987	1.7261	1.6084	2.9206	2.1251
7	2.2386	2.0977	2.0462	2.0889	2.0237	3.0429	2.0942
8	2.1376	1.9479	1.9353	1.9113	1.8976	1.9627	1.925
9	1.8793	1.7386	2.2051	1.6198	1.6758	1.7261	1.6427
10	1.6198	1.7192	1.4449	1.523	1.5786	1.7089	1.5627
11	1.5387	1.5318	1.2392	1.4727	1.4357	1.518	.8813
12	1.5364	1.446	.767	1.363	1.3226	1.438	.9008
13	1.5604	1.3591	1.3637	1.411	1.3294	1.5043	.9945
14	1.6118	1.2998	1.4334	1.4659	1.3992	1.5112	1.0048
15	1.7025	1.3546	1.4426	1.5059	1.4129	1.4963	.8871
16	1.6816	1.5169	1.4254	1.5276	1.4586	1.6473	.9968
17	1.6906	1.3855	1.4449	1.5341	1.5867	1.6221	.9214
18	1.7376	1.6416	.9202	1.7158	1.6289	1.6906	.8653
19	1.9833	1.909	2.0923	1.8968	2.0576	2.2314	1.078
20	2.7846	2.7583	2.6582	2.4638	2.8304	2.8269	1.6575
21	2.6521	2.6772	2.4844	2.2969	2.7183	2.6955	1.6232
22	2.316	2.4154	2.196	2.0679	2.5172	2.3697	1.4678
23	2.0142	2.0748	1.8599	1.7799	2.228	2.0988	1.3569
24	1.4735	1.7627	1.7421	1.3965	1.5337	2.4691	1.8187
Max	2.7846	2.7583	2.6582	2.4638	2.8304	3.0429	2.1251
Min	1.2917	1.2998	.767	1.2582	1.2262	1.438	.8653
Avg	1.7872	1.7610	1.6856	1.637	1.6950	2.0882	1.4127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 306 / KHATAV AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0732	.0732	1.4575	1.4899	1.5623	2.0485
2	.0732	.0732	.0732	1.4575	1.4899	1.5242	2.0485
3	.0709	.0732	.0732	1.6194	1.6194	1.5242	1.9204
4	.0732	.0732	.0732	2.1052	2.1052	1.5242	1.9204
5	.0732	.0732	.0732	2.1052	2.1052	1.829	1.9204
6	.0709	.0732	.0732	2.915	2.2672	2.0729	1.9204
7	.0732	.0732	.0732	2.915	2.915	3.1703	2.6063
8	.0732	.0732	.0732	3.4008	3.4979	2.7435	2.4691
9	3.2579	2.6216	.0732	.0724	.0724	.0709	2.5377
10	3.062	2.8746	.0732	.0724	.0732	.0732	2.4006
11	2.8045	2.9492	.0732	.0648	.0732	.0732	2.4006
12	2.7435	2.7435		.0724	.0732	.0732	2.4006
13	2.4996	2.5377	.0732	.0724	.0732	.0732	2.4006
14	2.4996	2.7435	.0724	.0724	.0732	.0732	2.4006
15	2.4996	2.8121	.0732	.0724	.0732	.0732	.2469
16	2.5934	2.9492	.0732	.0724	.0732	.0732	2.572
17	.0732	.0732	.0732	.0724	.0732	.0732	.0732
18	.0732	.0732	.0724	.0724	.0732	.0732	.0732
19	.0732	.0732	.1086	.0724	.0732	.0732	.0709
20	.0732	.0732	.1086	.0724	.0732	.0732	.0709
21	.0732	.0732	.0724	.0724	.0732	.0732	.1063
22	.0732	.0732	.0724	.0724	.0732	.0732	.0709
23	.0732	.0732	1.7166	1.7814	.0732	.0732	.0709
24		.0732	.0732	1.7814	1.8461	.0732	.0732
Max	3.2579	2.9492	1.7166	3.4008	3.4979	3.1703	2.6063
Min	.0709	.0732	.0724	.0648	.0724	.0709	.0709
Avg	1.0023	.9751	.1476	.9394	.8514	.7133	1.4510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 301 / 22 KV R Kurle AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7045	3.4842	3.1778	.5167	.5396	.5152	.5087
2	3.4987	3.3928	3.0635	.4938	.4938	.4923	.5087
3	3.3387	3.2556	2.9721	.4938	.4938	.4923	.5087
4	3.293	3.0727	2.8349	.4938	.5315	.4923	.5087
5	3.4827	3.3242	2.9934	.5544	.5692	.5296	.5544
6	3.898	4.0939	2.1719	.6985	.6756	.6501	.6756
7	5.7271	6.0844	3.1779	.8357	.8276	.9339	.9111
8	6.0567	6.1819	5.5099	.8357	.8734	.7899	.7899
9	3.0155	2.8783	5.8376	5.3818	5.6223	6.7421	.615
10	.5773	.6607	5.4412	6.1538	6.941	6.9471	.5544
11	.5315	.5773	4.7462	5.8547	4.5268	6.7871	.2504
12	.5087	.5544	2.4005	5.4831	5.7704	6.2734	.1143
13	.5544	.5087	2.9142	5.1574	5.4138	5.5251	.2126
14	.5544	.5087	4.3385	4.6849	4.9825	5.1197	.3944
15	.5921	.615	3.8546	4.382	4.593	4.8224	.6001
16	.5773	.615	4.1915	4.4239	4.7996	5.5906	.5773
17	.5773	.5544	2.5823	1.6522	2.5957	3.5117	.6607
18	.6378	.615	.2126	.3567	.567	.5087	.7064
19	.7899	.6985	.319	.615	.7331	.6378	.6835
20	.5716	.7899	.9191	.8734	.8703	.8505	.8128
21	.8962	.8505	.8585	.8128	.7872	.7899	.8128
22	.7899	.7899	.775	.7442	.7644	.7899	.7521
23	3.538	2.9965	.6835	.6835	.6813	.6458	.6835
24	3.8645	3.3417	1.3946	.5773	.5773	.5525	.6001
Max	6.0567	6.1819	5.8376	6.1538	6.941	6.9471	.9111
Min	.5087	.5087	.2126	.3567	.4938	.4923	.1143
Avg	2.1490	2.1018	2.8071	2.1983	2.3013	2.5412	.5832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 302 / 22 KV Pusesavali Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.648	1.6632	1.7162	1.7394	1.6327	1.7032	1.7089
2	1.6022	1.5645	1.6095	1.6255	1.6022	1.6423	1.6784
3	1.4955	1.5188	1.5638	1.595	1.587	1.627	1.648
4	1.5108	1.4578	1.5333	1.5036	1.5333	1.5203	1.648
5	1.624	1.6168	1.624	1.5493	1.5935	1.6103	1.7924
6	1.9661	2.0797	2.0268	1.9441	1.973	1.9966	2.3845
7	2.4371	2.3621	2.5442	2.4985	2.5355	2.7192	2.6887
8	2.127	2.1502	1.9673	2.3171	2.3323	2.4688	2.3549
9	1.8461	2.0355	1.7851	1.8534	2.0507	2.1342	1.9449
10	1.6784	2.1037	1.8156	1.566	2.0203	1.387	1.7772
11	1.6937	1.9745	1.7242	1.4746	1.2041	2.0203	.6706
12	1.6103	1.9064	1.648	1.5813	1.1888	1.9296	1.3439
13	1.595	1.7627	1.7089	1.627	1.7394	1.6937	1.4963
14	1.587	1.5645	1.6407	1.6423	1.6937	1.6632	1.8911
15	1.534	1.7467	1.6632	1.6575	1.656	1.6632	1.9441
16	1.6175	1.7924	1.8149	1.5287	1.7546	1.6712	1.7394
17	1.701	1.8004	2.005	1.5897	1.983	1.8149	1.7851
18	1.6937	1.1126	2.0355	1.7242	1.8001	1.8534	1.8534
19	2.0653	1.5211	1.9818	2.095	1.9677	2.1037	1.8759
20	1.6918	2.9149	2.6661	2.6117	2.732	2.7721	2.6204
21	2.4383	1.768	2.4912	2.559	2.6269	2.7039	2.6051
22	2.3396	2.5964	2.4078	2.3998	2.649	2.6582	2.537
23	2.0965	2.3014	2.2561	2.0283	2.2489	2.2489	2.3171
24	1.8156	1.8687	1.9449	1.762	1.9223	1.9083	1.8839
Max	2.4383	2.9149	2.6661	2.6117	2.732	2.7721	2.6887
Min	1.4955	1.1126	1.5333	1.4746	1.1888	1.387	.6706
Avg	1.8089	1.8826	1.9239	1.8530	1.9178	1.9797	1.9246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 303 / 22 KV Vadgaon AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8265	.8452	.9099	6.1104	5.9309	5.2241	4.7988
2	.8265	.8494	.9099	5.9633	5.8851	5.2603	5.0343
3	.8265	.8494	.9099	5.5449	5.8394	5.2603	5.1684
4	.8037	.8494	.8871	5.3552	5.8394	5.1688	5.2896
5	.8791	.4344	.9328	5.3483	6.0471	5.4032	5.3581
6	1.0985	1.1066	.4115	6.3695	6.9456	6.4853	6.5462
7	1.3191	1.2129		6.7277	9.081	8.9659	8.2861
8	1.1454	1.1602		5.8452	9.1404	8.7723	8.943
9	7.497	7.9789	.0754	2.7241	4.3095	3.9198	8.5741
10	8.8356	9.1716	.144	.8825	.7053	.8951	8.6748
11	8.6062	8.9102	.1589	.2058	.4344	.4344	4.481
12	6.2498	8.0141	.3258	.4108	.8494		7.9942
13	7.252	7.5888	.4092	.8825	.8642		4.0924
14	7.2092	7.2062	1.3054	.8825	.9099		6.9799
15	7.0263	7.1049	1.1523	.8596	.8494	.7796	3.8637
16	6.8168	7.0263	1.1374	.9053	.9476	.5487	7.1666
17	3.6683	3.2807	1.1443	.9343	1.1462		3.5391
18	.9476	.8871	1.2814	1.0688	1.0173		1.1294
19	1.0082	1.0459	1.3191	.9773	1.1462		1.2209
20	1.2209	1.198	1.342	1.342	1.1545	1.3568	1.2059
21	1.2814	1.1374	1.3043	1.342	1.0319	1.3797	1.1752
22	1.1602	1.1145	1.2209	1.2666	1.1919	1.2895	1.2209
23	1.062	1.0162	5.8001	5.5784	1.1088	1.1752	1.0539
24	.8722	.9328	3.8512	6.1401	3.2102	1.0197	1.0688
Max	8.8356	9.1716	5.8001	6.7277	9.1404	8.9659	8.943
Min	.8037	.4344	.0754	.2058	.4344	.4344	1.0539
Avg	3.2683	3.3717	1.2242	3.0695	3.1494	3.5188	4.7027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 304 / 22 KV Pusesavali AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.7389	6.7863	5.8383	1.1035	1.1793	1.1393	1.1793
2	7.3579	6.5577	6.105	1.1035	1.1412	1.1012	1.1793
3	7.2054	6.1385	6.105	1.0273	1.1412	1.1012	1.1793
4	6.9387	6.0242	5.9145	1.0273	1.1027	1.1386	1.2555
5	7.0751	5.8604	5.9091	1.065	1.1024	1.1378	1.4453
6	7.8971	6.8465	6.0402	1.3687	1.4064	1.6316	1.8668
7	11.5303	10.3643	8.9918	2.2059	2.2443	2.4726	2.0542
8	12.1037	10.282	9.5145	2.2828	1.8645	2.2451	1.9022
9	8.9902	8.1138	11.0334	8.2251	7.2474	9.2982	1.7879
10	1.5211	1.6735	11.4037	12.0257	11.1919	11.9921	1.9403
11	1.5977	1.7121	11.4037	11.8313	10.1738	13.5772	1.105
12	1.2936	1.5596	11.0174	11.0159	10.0595	13.3806	
13		1.4834	10.3582	10.2862	10.7179	12.6398	
14	1.2932	1.4079	9.8629	9.9547	9.3949	11.6057	
15	1.2551	1.2551	8.1474	8.1161	10.1898	11.6491	1.1789
16	1.1031	1.3313	8.5125	9.324	10.048	9.6022	1.4449
17	1.3313	1.4456	7.5046	6.512	8.0742	9.2951	2.0923
18	1.2555	1.1812	1.217	1.065	1.1005	1.2551	1.6735
19	1.3313	.3018	1.5215	1.1405	1.1767	1.3694	1.1397
20	1.6735	1.6735	1.4456	1.7498	1.6323	1.3694	1.9403
21	1.6735	1.7498	1.4456	1.6739	1.7848	1.3313	1.6739
22	1.6735	1.5977	1.3313	1.5215	1.6712	1.3313	1.7116
23	4.795	4.859	1.2555	1.4456	1.4434	1.2555	1.4834
24	6.4434	6.1652	1.8374	1.2174	1.2936	1.2155	1.3698
Max	12.1037	10.3643	11.4037	12.0257	11.1919	13.5772	2.0923
Min	1.1031	.3018	1.217	1.0273	1.1005	1.1012	1.105
Avg	4.5686	4.0154	6.4048	4.5120	4.5159	5.1723	1.5525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 306 / 22 KV Vadgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.598	1.5596	1.4456	1.2932	1.4456	1.3672	1.5596
2	1.5218	1.5596	1.3694	1.2555	1.3694	1.3672	1.5596
3	1.4456	1.4834	1.2932	1.2555	1.3694	1.291	1.4834
4	1.4456	1.4072	1.2932	1.2555	1.2932	1.291	1.4072
5	1.3694	1.5588	1.217	1.2932	1.331	1.291	1.4834
6	1.5973	1.635	1.4834	1.5973	1.5973	1.4807	1.9399
7	1.9399	1.8637	1.6735	1.6358	1.7498	1.6735	1.8637
8	1.6358	1.5218	1.4834	1.6358	1.4834	1.4834	1.5218
9	1.3694	1.3694	1.4456	1.2555	.8368	1.4072	1.1031
10	1.2932	1.2932	1.3694	1.025	.7229	1.2932	.9907
11	1.4834	1.3694	1.2932		.8383	1.2932	1.2932
12	1.4072	1.2932	1.4072	.2614	1.0269	1.1408	1.1431
13	1.5218	1.3694	1.4834	1.3672	1.0269	1.0646	1.1431
14	1.1431	1.3694	1.3694	1.291	1.1031	1.217	1.3317
15	1.2193	1.3694	1.217	1.1774	1.1031	1.1408	.9907
16	1.4072	1.2932	1.2932	1.025	1.0269	1.3694	1.1793
17	1.331	1.1031	1.2932	1.025	1.025	1.3694	1.1793
18	1.0646	1.4072	1.3694	.9507	1.2148	1.3694	1.2932
19	1.7112	1.5588	1.4834	1.4449	1.2894	1.5973	1.5973
20	2.244	2.3964	2.2062	2.13	2.2786	2.5865	2.2824
21	2.4726	2.2824	2.13	2.0161	2.316	2.4726	2.3964
22	2.3586	2.2824	2.0923	2.0161	2.2024	2.3586	2.2824
23	1.9784	1.9022	1.7883	1.7498	1.8229	1.9784	1.9022
24	1.7498	1.5973	1.4834	1.4456	1.5596	1.7856	1.6735
Max	2.4726	2.3964	2.2062	2.13	2.316	2.5865	2.3964
Min	1.0646	1.1031	1.217	.2614	.7229	1.0646	.9907
Avg	1.5962	1.5769	1.4993	1.3653	1.3764	1.5287	1.5250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 201 / Ladegaon High School

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2004	.2484	.2499	.2092	.2025	.2077	.2374
2	.1913	.2133	.2246	.1837	.1821	.2031	.213
3	.1928	.2049	.2162	.1844	.1798	.1837	.2138
4	.1875	.2011	.2155	.1829	.1775	.1837	.2085
5	.1875	.2217	.2359	.1822	.1768	.2024	.2069
6	.2053	.2454	.258	.2153	.2225	.213	.2443
7	.2549	.272	.2696	.2519	.2197	.2458	.272
8	.2614	.2271	.2572	.2141	.2401	.1999	.2684
9	.2254	.2461	.2198	.2095	.1936	.2235	.2503
10	.2118	.2636	.2363	.198	.1722	.2255	.229
11	.253	.2336	.2098	.189	.1745	.2269	.2098
12	.2415	.2574	.2103	.1837	.1911	.2088	.203
13	.2316	.2686	.2065	.2094	.2053	.1995	.2152
14	.2415	.2572	.2118	.2086	.1992	.2102	.2423
15	.2461	.2633	.2182	.2033	.197	.2578	.2438
16	.2514	.232	.1212	.2071	.2023	.2572	.2263
17	.2469	.2364	.2381	.2027	.2664	.2313	.1402
18	.2316	.2734	.2915	.2522	.2697	.2351	.2377
19	.2629	.3302	.3148	.2598	.2819	.3121	.2484
20	.3658	.3913	.3809	.3345	.3753	.4016	.3688
21	.3734	.4001	.349	.3322	.3687	.4085	.3361
22	.3353	.365	.3123	.2979	.3277	.3658	.3098
23	.3109	.3093	.2656	.2591	.2682	.304	.2999
24	.2441	.2621	.2412	.212	.2242	.238	.2395
Max	.3734	.4001	.3809	.3345	.3753	.4085	.3688
Min	.1875	.2011	.1212	.1822	.1722	.1837	.1402
Avg	.2481	.2676	.2481	.2243	.2299	.2477	.2444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 202 / 11 KV Yeliv AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9061	.9172	.7459	.0953	.0754	.0934	.0953
2	.9014	.9122	.7459	.0762	.0754	.0953	.0953
3	.9014	.9122	.6299	.0762	.0754	.0762	.0762
4	.9282	.9393	.6299	.0762	.0754	.0762	.0762
5	.9374	.9374	.6299	.0762	.0754	.0762	.0953
6	1.0155	.9488	.7042	.0953	.0914	.0953	.1143
7	1.2018	1.186	1.094	.1143	.0914	.112	.1143
8	1.2643	1.1069	1.0814	.0953	.0924	.112	.168
9	.0905	.0762	1.1233	1.2146	1.1523	1.2407	.132
10	.0732	.0953	1.2574	1.326	1.3599	1.1797	.132
11	.0914	.0754	1.291	1.2955	1.3765	1.4255	.0554
12	.0914	.112	1.2239	1.2003	1.3916	1.4251	.0739
13	.1097	.1132	1.1736	1.2003	1.0688	1.2431	.0739
14	.0914	.0739	1.1233	1.1843	1.0526	1.2266	.0739
15	.0914	.0739	1.1736	1.1843	1.1797	1.4586	.1097
16	.0914	.0739	1.2071	1.0364	1.2616	1.5091	.1097
17	.128	.0876	.0686	.0732	.0709	.0754	
18	.1463	.1254	.0876	.0924	.0905	.0754	.1097
19	.128	.112	.1052	.0924	.1086	.112	.1097
20	.128	.132	.1075	.112	.128	.1307	.1109
21	.128	.1132	.1097	.0934	.1097	.112	.1109
22	.1097	.0953	.1109	.0934	.1109	.1109	.0934
23	.8421	.788	.0934	.0754	.1109	.1097	.0934
24	.9061	1.9524	.788		.0754	.0934	.0953
Max	1.2643	1.9524	1.291	1.326	1.3916	1.5091	.168
Min	.0732	.0739	.0686	.0732	.0709	.0754	.0554
Avg	.4709	.4983	.7211	.4773	.4708	.5110	.1008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 204 / Trimali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2772	.2858	.2858	.2829	.3048	.3048
2	.2614	.2587	.2667	.2667	.2667	.2858	.2858
3	.2614	.2561	.2667	.2667	.2667	.2858	.2858
4	.2614	.2743	.2667	.2667	.2667	.2858	.2858
5	.2801	.2926	.2858	.2858	.2858	.3239	.3239
6	.3174	.3109	.3048	.3239	.3395	.3429	.381
7	.3734	.3658	.3395	.3429	.3361	.381	.3547
8	.3361	.3547	.2801	.2987	.2743	.3429	.3292
9	.2957	.3361	.2614	.2772	.2743	.3142	.3403
10	.2614	.3174	.2743	.2957	.2561	.3292	.4163
11	.2614	.2835	.2715	.3174	.2715	.3189	.2926
12	.2801	.3012	.2686	.3361	.2715	.3258	.2743
13	.2801	.2835	.2865	.2987	.3109	.2957	.3109
14	.2614	.2926	.2865	.2801	.2896	.2957	.3109
15	.2801	.2926	.2896	.3174	.2715	.3439	.3258
16	.2987	.2957	.2896	.2987	.2561	.3292	.3109
17	.2987	.2957	.3109	.3174	.2957	.3366	
18	.3174	.3142	.3258	.3292	.3109	.3366	.3292
19	.4108	.3658	.362	.3841	.3475	.4207	.4066
20	.5041	.4904	.439	.4525	.462	.4854	.5041
21	.4481	.415	.3841	.439	.4435	.5041	.4668
22	.4108	.4001	.3696	.3841	.3734	.4715	.4294
23	.3734	.3239	.3326	.3361	.3361	.3772	.3734
24	.3142	.3174	.2858	.2987	.3018	.3048	.3048
Max	.5041	.4904	.439	.4525	.462	.5041	.5041
Min	.2614	.2561	.2614	.2667	.2561	.2858	.2743
Avg	.3195	.3215	.3056	.3208	.3080	.3476	.3455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 205 / 11 KV Karkhana AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4783	2.1133	2.1172	.3334	.2816	.3128	.3054
2	2.3419	2.0591	2.1178	.3132	.2755	.2797	.2576
3	2.2954	1.9867	2.0835	.3162	.2755	.2812	.2568
4	2.2901	2.0142	2.0515	.3155	.277	.2797	.2537
5	2.3617	2.258	2.108	.3643	.3019	.3285	.2793
6	2.7671	2.5606	2.2897	.4508	.4835	.4188	.4632
7	3.6893	3.4724	2.8277	.5879	.5597	.5673	.5625
8	3.69	3.6621	3.4004	.532	.5045	.516	.5306
9	1.9243	1.8389	3.5543	3.0335	3.1954	3.3882	.4222
10	.33	.3993	3.3585	3.4456	3.2291	3.3406	.3078
11	.2976	.4035	3.4408	3.3976	3.3438	3.6184	.3185
12	.287	.3487	2.5858	3.1344	3.4972	3.5913	.3353
13	.3163	.3704	2.6635	2.9431	3.2441	3.1161	.3582
14	.2969	.3481	2.7305	2.8593	2.8448	2.8542	.3079
15	.3033	.3452	2.8273	2.8742	2.8449	2.8609	.3056
16	.3003	.3708	1.6865	2.8799	2.889	3.0746	.2713
17	.3635	.4161	1.7608	1.7246	1.5783	1.5989	.1433
18	.4351	.4497	.442	.3719	.3883	.361	.2651
19	.4519	.4348	.4817	.4443	.4481	.399	.3454
20	.4793	.4824	.5582	.5297	.4873	.4805	.4558
21	.5205	.5001	.5487	.5206	.4733	.4771	.4031
22	.4801	.49	.5015	.426	.4149	.4239	.3506
23	1.9744	2.1591	.4355	.2362	.3604	.3616	.2919
24	2.3388	2.1978	1.2298	.3254	.3164	.3113	.2872
Max	3.69	3.6621	3.5543	3.4456	3.4972	3.6184	.5625
Min	.287	.3452	.4355	.2362	.2755	.2797	.1433
Avg	1.3755	1.3201	1.9917	1.3483	1.3548	1.3851	.3366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 206 / 11 KV Kharsinge AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0654	1.011	1.0149	.0583	.056	.056	.056
2	1.0417	.9518	1.0263	.056	.056	.056	.0566
3	1.0113	.9263	1.021	.056	.056	.056	.0566
4	.9887	.9814	1.0171	.0568	.056	.056	.0566
5	1.0173	1.106	1.0511	.056	.056	.056	.0754
6	1.118	1.2911	1.134	.0747	.0857	.1143	.1614
7	1.5234	1.7513	1.13	.2044	.1696	.2113	.205
8	1.5871	1.6111	1.0612	.186	.1859	.2273	.1995
9	.7118	.7415	1.0858	1.1972	1.3161	1.2944	.1806
10	.0549	.0709	1.1443	1.3085	1.5158	1.355	.0962
11	.0465	.1593	1.3984	1.2978	1.5044	1.4199	.0688
12	.0549	.1623	1.3702	1.2318	1.4792	1.4495	.1031
13	.1677	.1502	1.3153	1.2643	1.3874	1.421	.1427
14	.173	.1456	1.278	1.4174	1.3045	1.4235	.1578
15	.1616	.1517	1.2879	1.3529	1.3348	1.3327	.1578
16	.1128	.1297	.7506	1.3557	1.3755	1.5157	.1639
17	.1723	.1456	.6832	.7099	.6546	.7533	.1471
18	.1669	.1615	.154	.1623	.1623	.1941	.1105
19	.1973	.1242	.1555	.1893	.176	.1493	.1867
20	.2141	.209	.2239	.2298	.2225	.2263	.2321
21	.2271	.2347	.2292	.211	.2286	.2252	.2136
22	.1867	.197	.1928	.1814	.2019	.2006	.1814
23	.8749	.9652	.1517	.1456	.1621	.1623	.1519
24	1.0756	1.0534	.4702	.0554	.1339	.056	.1049
Max	1.5871	1.7513	1.3984	1.4174	1.5158	1.5157	.2321
Min	.0465	.0709	.1517	.0554	.056	.056	.056
Avg	.5813	.6013	.8478	.5441	.5784	.5838	.1361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 201 / 11 KV VAR-MALAWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	27-APR-17
HR	Load (MW)
12	.0934
13	.0724
Max	.0934
Min	.0724
Avg	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 202 / 11 KV SHENAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.8192	.4344	.4251	.3982	.4435	.8817
2	.8478	.7865	.3982	.4066	.3658	.4251	.9054
3	.8478	.7373	.3982	.4066	.3841	.4435	.9156
4	.8817	.7701	.4525	.462	.4525	.4805	.9389
5	.8817	.8684	.543	.5175	.543	.5304	1.0059
6	1.2742	1.2955	.7059	.7133	.7783	.8048	1.2887
7	1.8519	1.9595	.7602	.6036	.6335	.7023	1.8442
8	1.7635	1.4251	.5068	.4755	.5249	.567	1.643
9	.3658	.4024	1.9433	1.8519	1.5223	1.4899	.3658
10	.2957	.2896	1.6194	1.5261	1.4575	1.4243	.3326
11	.3109	.2896	1.4899	1.4243	.7701	1.3077	.3142
12	.3142	.3258	1.2146	1.3032	1.1498	1.2407	.3109
13	.2957	.2715	1.1498	1.1361	1.166	1.0395	.3326
14	.2772	.3439	1.004		1.085	.8718	.2957
15	.3109	.3077		1.0513	1.1142		.3326
16	.3142	.3258	1.0526	1.2887	.9503	1.1736	.2957
17	.3511	.3982	.9995	.362	.3109	.2926	.3696
18	.3881	.4706	.4024	.4525	.4251	.3658	.3511
19	.6468	.6697	.6401	.6516	.6219	.724	.5729
20	.823	.8145	.8413	.7964	.7865	.8048	.7499
21	.7316	.7602	.7682	.7421	.7499	.724	.567
22	.6219	.6154	.5359	.5194	.6036	.6154	.5914
23	.852	.5068	.462	.4525	.5175	.5068	.4805
24	.9156	.8356	.4706	.4251	.4163	.4805	.4706
Max	1.8519	1.9595	1.9433	1.8519	1.5223	1.4899	1.8442
Min	.2772	.2715	.3982	.362	.3109	.2926	.2957
Avg	.7106	.6787	.8171	.7823	.7386	.7591	.6732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 203 / 11 KV VAR-MALAWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.0943	.1109	.0943	.1109	.1109
2	.0924	.0924	.0943	.0924	.0943	.1109	.1097
3	.0914	.0924	.0943	.0924	.0943	.0924	.1109
4	.0924	.1109	.0934	.1109	.0934	.1109	.128
5	.1097	.1294	.1307	.1294	.112	.1294	.1463
6	.1097	.1663	.1494	.1478	.1494	.1478	.1463
7	.1109	.1478	.1646	.1294	.1494	.1478	.1463
8	.0924	.1294	.1478	.1109	.1109	.1109	.1109
9	.0924	.1109	.0924	.0924	.0924	.1109	.0924
10	.0924	.1109	.0924	.0924	.0924	.0914	.0924
11	.0554	.0924	.0554	.0924	.0739	.1097	.0924
12	.0554	.1109	.0739	.0924	.0924	.1109	.0924
13	.0554	.0554	.0924	.0924	.0739	.1097	.0924
14	.0554	.0924	.0924	.0924	.0739	.0924	.0924
15	.0554	.0924	.0924	.0924	.0924	.1097	.0924
16	.0554	.0924	.0924	.1109	.1109	.1097	.0924
17	.0924	.1109	.0924	.1109	.1109	.1097	.0924
18	.0924	.1109	.1109	.1109	.1109	.1478	.1294
19	.1294	.1663	.1478	.1494	.1663	.1829	.1109
20	.2033	.2033	.1848	.1867	.2033	.2218	.2033
21	.1848	.1848	.1663	.1848	.1848	.1848	.1848
22	.1663	.168	.1663	.1494	.1478	.1663	.1478
23	.1478	.1307	.1294	.1307	.1294	.128	.1294
24	.1109	.1109	.1132	.1075	.0943	.1109	.1294
Max	.2033	.2033	.1848	.1867	.2033	.2218	.2033
Min	.0554	.0554	.0554	.0924	.0739	.0914	.0924
Avg	.1023	.1218	.1152	.1172	.1145	.1274	.1198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 204 / 11 KV SHENAWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0924	.0754	.0924	.0754	.0739	.0924
2	.0732	.0924	.0754	.0924	.0754	.0739	.0739
3	.0739	.0739	.0754	.0739	.0754	.0739	.0739
4	.0739	.0924	.0943	.0739	.0934	.0739	.0924
5	.0732	.1109	.112	.1109	.1494	.0924	.1463
6	.1478	.2012	.1646	.1646	.2033	.1463	.1829
7	.1478	.1646	.1663	.1829	.1848	.1646	.1463
8	.1294	.1463	.1478	.1646	.1294	.128	.1478
9	.128	.128	.1463	.1478	.128	.128	.0914
10	.1097	.1294	.1097	.1294	.128	.1097	.1097
11	.0914	.1478	.128	.1097	.0914	.1097	.0914
12	.0914	.1478	.128	.128	.1097	.128	.0914
13	.0914	.1097	.1294	.128	.0914	.0732	.0914
14	.0914	.112	.1097	.128	.0732	.0732	.0914
15	.0914	.0739	.0914	.128	.0732	.0914	.0914
16	.0914	.0924	.0914	.1109	.0914	.0914	.0914
17	.1097	.0924	.1097	.1294	.1097	.1097	.1097
18	.128	.112	.128	.128	.1097	.0914	.1097
19	.1646	.1848	.1478	.1646	.1097	.1478	.1463
20	.2195	.1663	.1829	.1848	.1829	.2218	.1848
21	.1829	.1663	.1829	.1848	.1663	.1848	.1663
22	.1646	.1494	.1663	.1267	.1478	.1663	.1478
23	.1097	.112	.1294	.0934	.0924	.1097	.1109
24	.0739	.0924	.0754	.1109	.0943	.0739	.0924
Max	.2195	.2012	.1829	.1848	.2033	.2218	.1848
Min	.0732	.0739	.0754	.0739	.0732	.0732	.0739
Avg	.1138	.1246	.1236	.1287	.1161	.1140	.1156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 205 / 11 KV Jambhulni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2772	1.2239	1.3927	1.3032	.7625	.2534
2	.2561	.2587	1.2003	1.3435	1.2346	.6882	.2561
3	.2743	.2587	1.2346	1.3108	1.2003	.7373	.2743
4	.2896	.2772	1.2517	1.2616	1.286	.7701	.2896
5	.2896	.2957	1.2689	1.2944	1.4243	1.0159	.362
6	.362	.3881	1.4922	1.6518	1.6956	1.6518	.3982
7	.362	.2957	2.079	2.2996	2.0454	1.9757	.3258
8	.3258	.2012	1.5775	1.6518	1.6766	1.7652	.2534
9	1.5223	1.6518	.1829	.2534	.2033	.2012	1.6518
10	1.9433	2.079	.2378	.2715	.1478	.1448	1.9595
11	1.8138	2.0119	.2378	.2353	.2033		1.7328
12	1.9271	2.079	.2587	.2715	.2033		2.0081
13	1.6518	1.7974	.2772	.3077	.2218		1.6518
14	1.8299	1.6461	.2772	.3077	.2507		1.6194
15	1.7166	1.7436	.3077	.2896	.2561	.2561	1.587
16	1.7166	1.6278	.3142	.2896	.2772	.2534	1.6518
17	.2561	.2534	.3142	.2896	.2743	.2926	.2743
18	.2587	.2534	.2957	.3258	.3292		.3142
19	.3326	.4344	.3142	.3982	.3841	.362	.3326
20	.4024	.3982	.4435	.4706	.4251	.4706	.4024
21	.4024	.3982	.3881	.3982	.3881	.439	.4066
22	.3511	.3077	.3511	.362	.3658	.3658	.3696
23	.2957	1.2346	1.2125	1.2174	.3696	.2926	.3511
24	.2561	.2772	1.2574	1.3763	1.2689	.3326	.2926
Max	1.9433	2.079	2.079	2.2996	2.0454	1.9757	2.0081
Min	.2534	.2012	.1829	.2353	.1478	.1448	.2534
Avg	.7954	.8519	.7499	.8029	.7264	.6725	.7924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 201 / 11 KV DEVAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.3429		1.5432	1.4232	1.6461
2		.2743	.3429		1.5089	1.3717	1.6804
3		.2743	.3429		1.4746	1.7147	1.7147
4		.3429	.3772		1.4746		1.9204
5		.4458	.4801		1.7147	2.4006	2.2462
6		.5487	.583		2.4691		2.5377
7		.5487			2.9835	2.7435	2.9321
8		.463			2.6063	2.7092	2.9492
9	2.572	2.9664	.3258	1.4918	.2743	.2743	2.7435
10		2.915		1.4232	.2572	.2743	2.8464
11		3.0864	.2572	.2401	.2058		2.0576
12		2.8635	.2743	.2229	.2229		
13		2.3663	.2915	.2743	.2572		
14		2.4006	.2743		.2401		
15		2.3148	.2743	.2572	.2572	.2743	
16			.2743	.1372	.2572	.3086	
17	.3429	.3429		.1543	.2572	.3429	.3086
18	.4115	.2915		.1715	.2743	.3601	.3258
19	1.8519	.3772		.2743	.3601	.463	.463
20	.5487	.3772		.3086	.4801	.5487	.5144
21	.4801	.3772		.4115	.4115	.4801	.4115
22	.3772	.3772		.3086	.3429	.3944	.3944
23	.3258	.3772		1.6289		.3772	.3429
24		.3086	.3772		1.6461	.3258	.3429
Max	2.572	3.0864	.583	1.6289	2.9835	2.7435	2.9492
Min	.3258	.2743	.2572	.1372	.2058	.2743	.3086
Avg	.8638	1.0832	.3441	.5217	.9356	.9326	1.4936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 202 / 11 KV DHULDEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	1.8004	1.9719		.5487	.5487	.4458
2	2.1262	1.8004	1.8861		.5144	.5144	.4458
3	2.0576	1.8861	1.8861		.5144	1.3717	.4801
4	2.0576	2.0576	1.8861		.5144	.5487	.5144
5	2.0576	2.1262	1.8519		.5487	.583	.5144
6	2.6406	2.332	2.1948		.5658		.6173
7	2.7778	2.7949			.5975	.3772	.5658
8	2.6749	2.572			.2915	.3429	.6173
9	.2058	.2743	2.4691	2.4691	2.0919	2.1605	.583
10		.4115		2.6749	2.1434	2.6063	.5487
11			2.332	2.4691	2.4348	2.5377	.5487
12		.4115	2.3148	2.452		2.2977	
13		.4115	2.1948	2.3663	2.332	2.1262	
14		.5144	2.1262		2.4006	2.0919	
15		.5144	2.0919	2.2119	2.4348	2.4006	.6001
16			2.2634	2.332	1.9204	2.5034	
17	.6173	.583		.2572	.3086	.2743	.6516
18		.463		.3086	.3772	.2743	.6173
19	.5487	.5487		.5144	.5144	.5487	.6516
20	.4973	.5144		.5487	.6173	.6516	.6859
21	.463	.4801		.5487	.583	.583	.6516
22	.4287	.4287		.5487	.5487	.6173	.5487
23	1.9719	1.8004		.5487		.5658	.3429
24	2.4006	1.9376	1.9719		.168	.5487	.5144
Max	2.7778	2.7949	2.4691	2.6749	2.4348	2.6063	.6859
Min	.2058	.2743	1.8519	.2572	.168	.2743	.3429
Avg	1.6097	1.2120	2.1029	1.4465	1.0441	1.1772	.5573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 203 / 11 kv Devapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.12	.1029		.1494	.12	.12
2	.1307	.1029	.1029		.1307	.1029	.1029
3	.112	.1029	.1029		.1307	.1029	.1029
4	.112	.1372	.12		.112	.12	.12
5	.112	.1715	.1372		.1494	.1372	.12
6	.1848	.2229	.1715		.168		.1372
7	.1612	.2058			.2218	.2058	.12
8	.1097	.1715			.1494	.1886	.1372
9	.1254	.1543	.1543	.12	.128	.1372	.12
10		.1715		.1029	.12	.1433	.12
11		.12	.1402	.0686	.1029	.1402	.1372
12		.12	.12	.0857	.1372	.0867	
13		.1372	.12	.1029	.1029	.1372	
14		.12	.1029		.1029	.1029	
15		.12	.12	.1372	.12	.1372	.1372
16			.1227	.0343	.0857	.1372	
17		.12	.1715	.0701	.1372	.1372	.1734
18	.1715	.12		.1402	.1715	.1372	.1372
19	.1886	.2103		.1791	.1543	.1543	.1753
20	.2058	.1715		.0187	.2058	.1715	.2149
21	.1886	.1715		.2195	.2058	.1715	.1991
22	.1715	.1372		.1829	.1886	.1372	.1463
23	.1543	.1372		.168		.1372	.1494
24	.1478	.12	.1029		.1494	.1372	.12
Max	.2058	.2229	.1715	.2195	.2218	.2058	.2149
Min	.1097	.1029	.1029	.0187	.0857	.0867	.1029
Avg	.1504	.1463	.1261	.1164	.1445	.1384	.1395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 204 / 11 kv Dhuldeo Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.12	.1029		.1494	.1372	.1029
2	.1307	.1029	.1029		.1307	.12	.1029
3	.112	.1029	.1029		.1307	.12	.1029
4	.112	.12	.1029		.1307	.12	.12
5	.1307	.1372	.1029		.1494	.1543	.1543
6	.2033	.1543	.1715		.1829		.2058
7	.1097	.1372			.168	.1543	.1715
8	.1254	.1029			.1307	.1372	.12
9	.0895	.0686	.12	.1372	.1307	.1372	.12
10		.1029		.12		.1402	.12
11			.1402	.12		.1402	
12		.1029	.1372	.1372		.1214	
13		.12	.1372	.1543	.1372	.1214	
14		.1029	.1214		.1372	.1227	
15		.1029	.1372	.0686	.1372	.0876	.1372
16			.0857	.1029	.1029	.104	
17	.0857	.0857		.1433	.1029	.12	.1029
18	.0857	.1029		.156	.1372	.1029	
19	.1372	.1791		.1433	.1543	.1543	.1753
20	.1543			.2012	.1886	.2058	.2149
21	.1715	.1715		.2054	.1886	.1886	.2195
22	.1886	.1715		.1867	.1886		.2012
23	.1372	.12		.168			.168
24	.1494	.12	.1029		.168	.1372	.1372
Max	.2033	.1791	.1715	.2054	.1886	.2058	.2195
Min	.0857	.0686	.0857	.0686	.1029	.0876	.1029
Avg	.1326	.1204	.1191	.1460	.1473	.1346	.1487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 205 / 11 KV Mhaswad (U) Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.7716	.9088		.9335	.8059	.7888
2	.9335	.7716	.9088		.9335	.7716	.7888
3	.8962	.7716	.9088		.8962	.7716	.823
4	.8962	.7716	.9088		.8775	.7716	.8573
5	.9709		.9259		.9522	.9431	.9602
6	1.134	.9259	1.1831		1.1827		1.166
7	1.0745	1.0117			1.1157	.9945	1.0288
8	.9313	.8059			1.0242	.8916	.9259
9	.8238	.7716	.8402	.7888	.8779	.7888	.8573
10				.823	.8573	.9465	.8916
11		.7888	.8859	.8916	.8916	1.0166	.9259
12		.8916	.8764	.7545	.9431	.9945	
13		.9259	.8322	.823	.9602	1.046	
14		.8573	.9465		.9431	1.0288	
15		.823	.9709	.8745	.9602	1.0288	1.0631
16			.8916	.8916	1.0288	1.0166	
17	.9431			1.0056	.8916	1.0288	1.1568
18	.8916	1.0974		.9816	.9259	.9945	1.1393
19	1.0974	1.3253		1.2489	1.0802	1.2003	1.2757
20	1.2346	1.2689		1.4266	1.3032	1.4746	1.4118
21	1.166	1.2517		1.3256	1.1488	1.3032	1.3535
22	1.0974	1.0974		1.1949	1.0802	1.0631	1.2437
23	.9602	.9088		1.0456		1.0117	1.1389
24	1.0082	.8059	.9088		.9709	.823	.8573
Max	1.2346	1.3253	1.1831	1.4266	1.3032	1.4746	1.4118
Min	.8238	.7716	.8322	.7545	.8573	.7716	.7888
Avg	.9996	.9322	.9212	1.0054	.9904	.9876	1.0327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 201 / 11 KV KUKUDWAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	26-APR-17
HR	Load (MW)	Load (MW)
3	.0716	
8	.0747	
24	.0693	.3765
Max	.0747	.3765
Min	.0693	.3765
Avg	.0719	.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 202 / 11 kv Kukudwad gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	26-APR-17
HR	Load (MW)	Load (MW)
3	.1829	
8	.2126	
24	.2218	.2012
Max	.2218	.2012
Min	.1829	.2012
Avg	.2058	.2012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 203 / 11 kv Diwad gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17
HR	Load (MW)
3	.112
8	.1509
24	.1109
Max	.1509
Min	.1109
Avg	.1246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 204 / 11 KV DIWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	25-APR-17
HR	Load (MW)	Load (MW)
3	.4481	
8	.4902	.2987
9	.2614	.7407
10	.2218	
11	.1829	.5498
12	.1715	.535
13	.1696	.5573
14	.1402	.4934
15	.1629	.5075
16	.1949	.6062
17	.2103	.1158
18	.213	
19	.3403	
20	.3801	
21	.3439	
22	.2715	
24	.4801	.1097
Max	.4902	.7407
Min	.1402	.1097
Avg	.2755	.4514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 205 / 11 kv Naravane Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	25-APR-17
HR	Load (MW)	Load (MW)
8		.7116
9	.6325	.0876
10	.7449	
11	.6009	
12	.5796	
13	.5573	
14	.5247	
15	.5468	
16	.5944	
17	.108	
18	.1265	
19	.1387	
20	.1578	
21	.1715	
22	.1357	
24	.1006	.4458
Max	.7449	.7116
Min	.1006	.0876
Avg	.3813	.415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 206 / 11 KV NARAWANE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1031	1.1126	1.0364	1.0612	1.0383	1.2079	1.1565
2	1.0612	1.0536	1.0117	1.0117	1.0117	1.1222	1.0879
3	1.083	1.0612	.9964	1.0136	.9964	1.0898	1.0364
4	1.0517	1.0707	1.004	1.0193	1.0098	1.0879	1.0402
5	1.0936	1.1946	1.1412	1.1393	1.0688	1.2479	1.1412
6	1.6099	1.5889	1.6728	1.6709	1.6385	1.7642	1.6842
7	2.1643	2.1567	2.1757	2.1967	2.1281	2.3148	2.2539
8	2.0656	2.0024	2.0119	1.8138	1.8404	1.9909	2.01
9	1.4095	1.4632	1.4632	1.448	1.3279	1.3336	1.3679
10	1.1818	1.1222	1.1317	1.0631	1.0402	1.0974	1.1298
11	1.1207	.8916	.9088	1.0269	1.0059	1.0002	.9107
12	.9984	.8726	.8211	.7735	1.0136	.8954	.7868
13	.8288	.8269	.783	.7773	.8192	.8878	
14	.865	.7849	.8383	.825	.8383	.8783	.9831
15	.8954	.7659	.823	.8364	.8478	.9526	1.0212
16	.8497	.804	.7754	.8707	.865	.9145	1.0822
17	.8726	.844	.8364	.8478	.7849	.9126	1.0593
18	.9659	.9526	.9335	.8288	.8288	1.0002	1.0479
19	1.1717	1.1831	1.1603	1.0936	1.0574	1.3203	1.2041
20	1.8595	1.8652	2.0119	1.9281	1.9547	1.97	1.9776
21	2.0024	1.9185	2.0233	2.0157	2.0424	1.9776	2.0157
22	1.9052	1.8252	1.9395	1.8347	1.8461	1.9243	1.8404
23	1.6118	1.5032	1.4842	1.467	1.669	1.6289	1.5794
24	1.323	1.1812	1.2879	1.1698	1.347	1.2936	1.2993
Max	2.1643	2.1567	2.1757	2.1967	2.1281	2.3148	2.2539
Min	.8288	.7659	.7754	.7735	.7849	.8783	.7868
Avg	1.2956	1.2519	1.2613	1.2389	1.2508	1.3255	1.3355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 207 / 11 KV KRUSHNA FERTILIZERS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0118	.0118	.0118	.0114	.0118	.0118	.0118
2	.0118	.0118	.0118	.0114	.0118	.0118	.0122
3	.0126	.0118	.0114	.0114	.0118	.0118	.0122
4	.0118	.0118	.0118	.0114	.0118	.0118	.0122
5	.0114	.0118	.0118	.0114	.0118	.0118	.0122
6	.0118	.0118	.0118	.0114	.0118	.0122	.0118
7	.0114	.0118	.0118	.0114	.0118	.0118	.0114
8	.0813	.0118	.0118	.0118	.0118	.0111	.0141
9	.0541	.0107	.0549	.0111	.0118	.0107	.0556
10	.0575	.0107	.0575	.0118	.0118	.0107	.0594
11	.0549	.0114	.0572	.0137	.0114	.0118	.0594
12	.0564	.0114	.0591	.0114	.0118	.013	.061
13	.0598	.0118	.0583	.0118	.0118	.0114	
14	.0633	.0103	.0602	.0088	.0118	.0095	.0606
15	.0633	.0118	.0617	.0118	.0118	.0118	.0598
16	.064	.0118	.0442	.0114	.0114	.0114	.0587
17	.0671	.0118	.013	.0118	.0114	.0114	.024
18	.0678	.0114	.0114	.0114	.0118	.0114	.0107
19	.0248	.0122	.0114	.0114	.0118	.0118	.0114
20	.0114	.0114	.0114	.0114	.0118	.0118	.0114
21	.0114	.0114	.0114	.0114	.0118	.0118	.0114
22	.0114	.0118	.0114	.0114	.0118	.0118	.0114
23	.0118	.0118	.0114	.0118	.0118	.0118	.0114
24	.0125	.0118	.0114	.0118	.0118	.0118	.0118
Max	.0813	.0122	.0617	.0137	.0118	.013	.061
Min	.0114	.0103	.0114	.0088	.0114	.0095	.0107
Avg	.0356	.0116	.0267	.0115	.0118	.0116	.0268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 301 / 22 KV SHINGANAPUR AG
(SHINGNA Feeder KV- 22 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5762	.5243	.6725	2.5423	2.1155	2.1186	1.7772
2	.5609	.5258	.6878	2.3411	1.9944	2.0378	1.7376
3	.5472	.5288	.6916	2.2367	1.9422	1.9144	1.6918
4	.6204	.5624	.7293	2.2862	2.0104	2.0096	1.7497
5	.3132	.6813	.7976	2.6215	2.1567	2.335	2.0294
6	.7796	1.0936	1.1618	3.698	3.0163	3.3371	3.097
7	.889	1.2155	1.3143	5.615	4.9154	5.1859	4.1579
8	.5335	1.0029	1.0387	5.2248	4.923	4.984	3.9109
9	3.0521	4.4944	.8116	2.0157	2.6425	2.8106	3.5589
10	3.6	4.6411	.6378	.381	.5411	.5243	2.9081
11	3.0605	4.1229	.5563	.3933	.4816	.2286	2.5694
12	2.9568	3.8904	.5849	.1219	.5548		2.4265
13	2.947	3.4476	.5696	.1951	.4054		2.3777
14	2.4417	3.211	.5696	.2896	.4786		2.2786
15	1.8838	3.1444	.5015	.1067	.2515	.4649	2.396
16	2.7084	4.3134	.5544		.4649	.5136	3.1588
17	2.0942	2.8502	.5609		.4831	.4984	2.2511
18	.5899	.5015	.6554	.8154	.5921	.6001	.3612
19	.9754	.7061	.823	.983	.8078	.8882	.6378
20	1.3062	1.124	1.2533	1.1126	1.1583	1.1698	1.0135
21	1.185	1.1168	1.1202	1.0745	1.0212	1.0863	.9602
22	1.105	.9572	.9724	.9602	.9084	.9042	.8459
23	.7591	.8585	3.4933	2.8791	.881	.7598	.7468
24	.6463	.6463	2.3579	2.6692	1.166	.7423	.6531
Max	3.6	4.6411	3.4933	5.615	4.923	5.1859	4.1579
Min	.3132	.5015	.5015	.1067	.2515	.2286	.3612
Avg	1.5055	1.9234	.9632	1.8438	1.4963	1.6721	2.0540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 302 / 22 KV MARDI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3808	1.4213	1.3969	.1494	.442	.6683	.6592
2	1.3344	1.3276	1.3664	.3948	.6066	.6683	.6287
3	1.3397	1.4273	1.3458	.471	.6249	.6835	.6592
4	1.3878	1.4754	1.3763	.4847	.6401	.7559	.6592
5	1.5893	1.6194	1.4803	.6531	.7925	.4695	.8505
6	2.2116	2.2908	2.0042	1.0406	.9602	.8017	.9572
7	3.6816	3.2198	2.9173	.823	1.1507	.9267	1.1473
8	3.5326	2.3624	2.6436	.8664	.9069	.6988	.836
9	1.8381	1.5669	2.1948	2.8418	2.6719	2.0165	.6458
10	.1478	.3323	1.829	2.1948	2.9062	2.9416	.583
11	.2088	.1494	1.568	2.5606	2.5073	2.6825	.5015
12	.3171	.1494	1.518	1.5546	1.9555	2.4897	.2392
13	.2789	.3444	1.6404	1.9509	1.9113	2.2001	.2896
14	.1417	.5182	1.5638	1.4022	1.7864	2.1338	.1799
15	.1417	.503	1.544	1.7902	1.6035	2.1338	.1494
16	.1494	.4557	1.989	2.3929	2.4661	3.03	.1494
17	.1417	.2881	1.5074	1.6918	1.8427	2.1948	.2576
18	.378	.4557	.2225	.6066	.2438	.3734	.3963
19	.5921	.6531	.5624	.6477	.6401	.6531	.602
20	.6988	.881	.7925	.9297	.8505	1.0711	.7925
21	.6988	.8433	.8078	.8154	.775	1.0029	.7068
22	.5929	.6306	.6234	.7316	.6988	.6916	.5944
23	1.7101	1.5912	.5152	.6524	.5152	.7423	.6096
24	1.56	1.5135	.4931	.5746	.471	.6386	.5696
Max	3.6816	3.2198	2.9173	2.8418	2.9062	3.03	1.1473
Min	.1417	.1494	.2225	.1494	.2438	.3734	.1494
Avg	1.0856	1.0842	1.4126	1.1759	1.2487	1.3612	.5693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 303 / 22 KV SHINGANAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0537	.0537	.0537	.0358	.0537	.0537
2	.0358	.0537	.0537	.0537	.0358	.0537	.0358
3	.0537	.0537	.0537	.0537	.0362	.0537	.0358
4	.0543	.0537	.0537	.0537	.0543	.0716	.0537
5	.0732	.0537	.0716	.0716	.0724	.0716	.0537
6	.0724	.0716	.0895	.0895	.0914	.0895	.0716
7	.0914	.0895	.0895	.0895	.0905	.0895	.0895
8	.0914	.0716	.0716	.0716	.0905	.0716	.0895
9	.0732	.0537	.0537	.0716	.0732	.0716	.0716
10	.0549	.0716	.0537		.0724	.0537	.0895
11	.0716	.0716	.0895	.0732	.0716	.0537	.0732
12	.0716	.0716	.0716		.0716	.0716	.0914
13	.0716	.0716	.0537	.0905	.0716	.0895	.0914
14	.0537	.0716	.0537		.0716	.0716	.0724
15	.0537	.0537	.0537		.0716	.0716	
16	.0537	.0716	.0895		.0716	.0716	.0905
17	.0537	.0716	.0716		.0895	.0716	.0724
18	.0537	.1075	.1075	.1086	.0716	.0537	.0543
19	.0895	.0895	.0895	.0914	.0716	.0895	.0914
20	.0895	.0895	.1075	.1097	.0895	.1075	.0914
21	.0895	.0895	.0895	.0905	.0716	.0895	.0905
22	.0716	.0716	.0716	.0724	.0716	.0716	.0732
23	.0537	.0537	.0537	.0549	.0537	.0716	.0543
24	.0549	.0537	.0537	.0537	.0549	.0537	.0537
Max	.0914	.1075	.1075	.1097	.0914	.1075	.0914
Min	.0358	.0537	.0537	.0537	.0358	.0537	.0358
Avg	.0661	.0694	.0709	.0752	.0690	.0716	.0715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 304 / 22 KV MARDI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.2667	.3048	.3048
2	.2667	.3048	.3048	.3048	.2667	.3048	.3048
3	.2667	.3048	.3048	.3048	.3048	.381	.3048
4	.3429	.4572	.381	.381	.3429	.5335	.381
5	.5335	.6097	.5335	.5716	.5335	.6478	.4954
6	.724	.7621	.7621	.8002	.7621	.8002	.6478
7	.724	.6859	.724	.6859	.724	.724	.6478
8	.5335	.4954	.5335	.4572	.5335	.4954	.5716
9	.4191	.4191	.4572	.381	.4191	.381	.381
10	.3429	.381	.3429		.3429	.3429	.381
11	.3048	.4191	.381	.3048	.3429	.3429	.381
12	.3048	.3429	.3048		.2667	.3429	.3048
13	.3429	.3048	.3048	.3048	.2667	.3429	.3429
14	.3429	.3048	.3048		.3048	.3048	.3429
15	.3429	.2667	.3048	.2667	.2667	.3429	.3048
16	.3048	.3048	.3048	.3048	.3429	.3048	.381
17	.381	.3048	.3429	.3048	.3048	.381	.3429
18	.4191	.381	.4191	.3429	.3048	.4572	.3048
19	.6859	.6097	.5716	.5335	.1524	.6097	.6097
20	.6859	.6859	.7621	.6859	.4954	.724	.724
21	.5716	.5716	.6097	.6097	.4954	.6478	.6097
22	.4954	.4954	.4572	.4572	.4572	.4954	.4954
23	.381	.381	.381	.3429	.3429	.381	.381
24	.3429	.3429	.3429	.3048	.3429	.3048	.3429
Max	.724	.7621	.7621	.8002	.7621	.8002	.724
Min	.2667	.2667	.3048	.2667	.1524	.3048	.3048
Avg	.4318	.4350	.4350	.4264	.3826	.4541	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 301 / 22 KV PARKANDI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.828	.8207	.7163	3.6366	3.2419	2.8029	2.4691
2	.8585	.836	.7316	3.28	3.1367	2.9017	2.812
3	.8585	.836	.7925	3.1291	3.0757	2.8407	2.8471
4	.8962	1.0326	.8687	2.9664	2.9736	2.646	2.902
5	1.0974	1.23	1.0624	3.1123	3.1717	2.6765	3.1775
6	1.6614	1.9288	1.483	4.7279	4.1609	4.164	4.1045
7	1.9662	2.082	1.8252	7.0321	5.9351	5.5975	5.266
8	1.4784	1.5356	1.4583	6.8629	5.9778	5.8757	5.1471
9	4.795	5.6104	.9054	4.0786	3.6732	3.7776	4.545
10	5.2233	5.666	.6916	.5335	.6988	.6763	3.8835
11	4.7554	5.2583	.6154	.6683	.6683	.381	3.3684
12	4.1655	4.4323	.5624	.7118	.6378		3.1124
13	3.7616	3.8348		.6509	.6683		3.0239
14	3.4027	3.7373	.5319	.6378	.714		3.0377
15	3.3531	3.9727	.7445	.714	.6988	.6661	2.7184
16	4.6075	4.7951	.503	.6835	.6988	.5419	2.0493
17	3.488	3.6732	.7445	.7366	.6988	.6782	1.7063
18	.8962	.8383	.8626	.7976	.7293	.8002	.6855
19	1.0173	1.0364	1.0593	.9644	1.0776	1.0516	1.044
20	1.3215	1.5242	1.5116	1.3295	1.5044	1.6004	1.3824
21	1.4129	1.4936	1.4586	1.3222	1.5044	1.6614	1.3977
22	1.2765	1.2498	1.2917	1.2345	1.2765	1.4098	1.2765
23	.9427	.9678	3.8912	3.94	1.124	1.0821	1.1168
24	.881	.7598	3.1016	3.7765	1.5928	.9419	.6706
Max	5.2233	5.666	3.8912	7.0321	5.9778	5.8757	5.266
Min	.828	.7598	.503	.5335	.6378	.381	.6706
Avg	2.2894	2.4647	1.1919	2.3970	2.0683	2.1321	2.6560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 302 / 22 KV BHANDAWALI AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0987	2.5888	2.6483	.6763	.74	.714	.7163
2	1.992	2.476	2.4197	.6611	.7225	.6988	.6325
3	1.8922	2.3602	2.329	.6611	.7026	.6835	.6325
4	1.8412	2.3975	2.2832	.6988	.7312	.6835	.7087
5	1.9341	2.5636	2.4501	.7796	.8169	.6988	.873
6	2.2893	3.309	2.8334	1.1314	1.2148	1.0783	1.1949
7	3.3463	4.3644	3.9103	1.2765	1.4784	1.3062	1.2803
8	3.658	5.4107	4.5268	1.0167	1.2845	1.1248	1.049
9	2.3883	3.8531	4.3484	3.3684	3.3326	3.9613	.8947
10	.0701	.9389	3.3745	3.0483	4.0817	4.8986	.6813
11	.0716	.8931	2.5743	3.7982	3.7837	4.2646	.6509
12	.0739	.8315	3.5269	3.5971	3.1947	3.7677	.5849
13	.7956	.6943	2.5606	3.6062	3.1131	3.9506	.6638
14	.801	.7271	2.5644	3.44	3.3608	4.0085	.5773
15	.7293	.6744	3.8798	3.4416	3.3364	3.6869	.5696
16	.7445	.714	3.0178	3.5178	3.9277	4.4917	.6356
17	.881	.7697	3.2826	3.0026	3.2892	3.536	.7011
18	.881	.8154	.8101	.7445	.9267	.7392	.828
19	1.0021	1.0898	1.0288	.9187	1.0029	.9373	.8306
20	1.4731	1.4404	1.4506	1.3412	1.3672	1.3717	1.2955
21	1.4282	1.4479	1.4129	1.2692	1.3824	1.3336	1.299
22	1.246	1.265	1.2506	1.246	1.2307	1.2193	1.246
23	2.127	2.5453	.9625	1.0455	1.0029	.9754	1.0516
24	2.7969	2.9813	1.3869	.788	.7769	.7598	.9145
Max	3.658	5.4107	4.5268	3.7982	4.0817	4.8986	1.299
Min	.0701	.6744	.8101	.6611	.7026	.6835	.5696
Avg	1.5234	1.9646	2.5347	1.8781	1.9500	2.1204	.8547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 303 / 22 KV MALAWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1509	.1524			.1478	.3048
2	.1494	.1509	.1524			.1509	.3048
3	.1494	.1509	.1143			.1494	.3048
4	.1494	.1509	.1132			.1494	.381
5	.1494	.1509	.1494			.1509	.4526
6	.1494	.1886	.1829			.2263	.5282
7	.1494	.1886	.1478			.1509	.4436
8	.1494	.1509	.1494			.112	.4482
9	.1494	.1509	.1494			.1829	.3361
10	.1509	.1867	.1494			.1848	.1097
11	.1509	.1494	.1109			.1867	.1433
12	.1509	.1848	.1494			.1867	.1109
13	.1886	.0185				.1867	.1109
14	.1509	.1867				.2263	.1132
15	.1509	.1886				.1867	.1132
16	.1509	.1494				.1848	.1132
17	.1509	.1524				.1524	.1433
18	.1509	.1524				.1524	.1109
19	.1886	.1905				.2286	.1509
20	.2641	.2286				.3048	.1886
21	.2263	.1905				.2286	.1886
22	.1886	.1905				.2286	.1905
23	.1509	.1524				.1905	.1509
24	.1463	.1509	.1524	.3395	.1463	.2926	.3048
Max	.2641	.2286	.1829	.3395	.1463	.3048	.5282
Min	.1463	.0185	.1109	.3395	.1463	.112	.1097
Avg	.1626	.1627	.1441	.3395	.1463	.1892	.2395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 304 / 22 KV KULAKJAI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1109	.0762	.1109	.0732	.1109	.0762
2	.1494	.1097	.0762	.1109	.0732	.1109	.0762
3	.1494	.1109	.0762	.1109	.0732	.112	.0762
4	.1867	.1109	.1143	.1494	.1109	.112	.1524
5	.1886	.1478	.1524	.1886	.1494	.1494	.1886
6	.5487	.2614	.1886	.2641	.2263	.1867	.2263
7	.5121	.1848	.1867	.1494	.1494	.1848	.1867
8	.4805	.1109	.1509	.1494	.0732	.1463	.112
9	.3018	.1097	.112	.1494	.1494	.1463	.0754
10	.3696	.0739	.0754		.1097	.1109	.0732
11	.3292	.0747	.0739	.1109	.1109	.0747	.0732
12	.0739	.0754	.1109	.1109	.112	.0754	.0351
13	.1494	.0754	.1109	.1109	.112	.0754	.0732
14	.0739	.0754	.0739	.1109	.112	.0754	.1109
15	.0732	.0754	.0732	.1109	.1109	.0747	.0732
16	.0739	.0754		.1109	.1097	.0747	.0732
17	.0747	.0762	.1109	.1494	.1109	.0762	.0732
18	.0754	.1524	.1109	.1494	.112	.0762	.1494
19	.1848		.1886	.1886	.1494	.1524	.1886
20	.2587	.2667	.2641	.2641	.2614	.2667	.2263
21	.2195	.2286	.2263	.2263	.2218	.2667	.2263
22	.1867	.1524	.1886	.1886	.1494	.1905	.1494
23	.1109	.1143	.1109	.0754	.1109	.1143	.1132
24	.1494	.1097	.0762	.1109	.0351	.1097	.0762
Max	.5487	.2667	.2641	.2641	.2614	.2667	.2263
Min	.0732	.0739	.0732	.0754	.0351	.0747	.0351
Avg	.2112	.1253	.1273	.1479	.1253	.1281	.1202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 306 / 22 KV TONDALE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1905	.7042	.5304	.5243	.4801
2	.1886	.1886	.1905	.6859	.503	.4973	.5487
3	.1886	.1867	.1905	.6859	.4694	.4588	.6706
4	.1886	.1848	.2641	.6516	.5967	.4641	.7377
5	.2263	.2561	.3734	.7042	.7377	.5243	.8619
6	.4904	.5175	.5175	1.2125	1.0562	1.0608	.9831
7	.4527	.4755	.5175	1.5729	1.3763	1.6385	1.1934
8	.3018	.3326	.3361	1.4586	1.326	1.4586	1.1065
9	1.2125	1.6095	.1867	.2263	.1494	.1829	.9389
10	1.0608	1.4415	.1509		.1463	.1848	.8192
11	.9503	1.1203	.1509	.1109	.1478		.8048
12	.8951	.8871	.1509	.1109	.1097		.8192
13	.7865	.7293	.1494	.1109	.1848		.5365
14	.7625	.6706	.1509	.1494	.112		.4915
15		.9054	.0377	.1494	.1097	.1867	.6036
16	1.1271	1.1401		.1509	.1478	.1867	.8383
17	.2218	.1905	.1886	.2263	.1463	.1905	.1886
18	.2614	.2286	.2263	.2263	.1848	.2667	.2263
19	.2957	.3429	.3361	.3018	.2987	.381	.3772
20	.4024	.4191	.4904	.3772	.4066	.4572	.4954
21	.3658	.3429	.415	.3018	.3696	.381	.4527
22	.2587	.3048	.3772	.2263	.2926	.3048	.3018
23	.1867	.2667	.8619	.6036	.2195	.2286	.2263
24	.1886	.1886	.1905	.7377	.5243	.1829	.1905
Max	1.2125	1.6095	.8619	1.5729	1.3763	1.6385	1.1934
Min	.1867	.1848	.0377	.1109	.1097	.1829	.1886
Avg	.4870	.5466	.2888	.5081	.4227	.4880	.6205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 201 / 11 KV PALASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2715	.2896	.5735	.5636	.4359	.4359
2		.2172	.2715	.5571	.5304		.431
3		.2534	.2172	.5407	.5304		.4641
4		.2896	.2534	.5571		.5365	.6299
5		.4706	.5068	.5735			.7293
6		.5571	.6516	1.0486	.8848		.8619
7		.5365	.5792	1.4091			1.1142
8	.4207	.4207	.4344	1.065	.9175	.788	1.0159
9	1.0202	.9945			.2743	.1402	
10	.7773	.9614					.6554
11	.5571	.6554					.4973
12	.5898	.5898	.1372				.4973
13	.5898	.5898					.4973
14	.3391	.5304					.431
15	.5182	.6299					
16	.6154	.6962	.1543		.1578		
17	.2126	.1753					
18	.2835	.2454					
19	.2012	.4207					
20	.4908	.5258	.4557				
21	.4252	.4207	.3856				
22	.3224	.3544	.3506		.3467		
23	.2865	.2865					
24	.2507	.2715	.2896	.5898	.57	.2947	.3155
Max	1.0202	.9945	.6516	1.4091	.9175	.788	1.1142
Min	.2012	.1753	.1372	.5407	.1578	.1402	.3155
Avg	.4647	.4735	.3555	.7683	.5306	.4391	.6126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 202 / 11 KV DHAMANI Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8288	.6882	.2279			
2		.823	.6882	.2279			
3		.779	.6554	.2454			
4		.8122	.7045	.2629			
5		1.2266	.7773	.3155			
6		1.3123	.9393	.4908			
7		1.531	1.004	.4557			
8	1.3599	1.3123	1.166	.2804	.2804	.3258	
9	.2058	.2534	1.0364		1.3413	1.3927	
10	.2401	.2534	.9231		1.3108		.2865
11	.2103	.2172	.7611		1.2631		.2507
12	.2103	.181	.7611		.8907		.2149
13	.2103	.181	.8583		.9069		.2507
14	.2103	.181	.8097		.9393		.1791
15	.1753	.1448	.8421				.1791
16	.1753	.2172	.9393		1.1012		.2149
17	.2835	.2172	.1886		.1781		.2507
18	.2926	.2534	.2572				.2534
19	.4607	.3982	.4115				.3582
20	.4607	.4344	.4115		.4287		.394
21	.3582	.362	.5144				.3224
22	.2896	.3258	.2915				.3224
23	.8288	.8192					.2507
24	.8551	.8453	.7209	.2454		.2572	.394
Max	1.3599	1.531	1.166	.4908	1.3413	1.3927	.394
Min	.1753	.1448	.1886	.2279	.1781	.2572	.1791
Avg	.4016	.5796	.7109	.3058	.8641	.6586	.2748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 203 / 11 KV GONDAWALE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.2587	.2686			
2		.2926	.2587	.2686			
3		.3292	.2402	.2686			
4		.3475	.3881	.2865		.3155	
5		.5014	.4887	.3582			
6		.5373	.5258	.5611			
7		.5552	.4908	.4298			
8	.4252	.4024	.4207	.4477	.3721	.4382	
9		.3511	.3681				
10		.3511					.3982
11	.4031	.3511					.3761
12	.3012	.3142	.2629		.2804		.3582
13	.3012	.3326					.3582
14	.3189	.3696					.2534
15	.2835	.3511					.2534
16	.2835	.3142	.3155		.2279		.2328
17	.3506	.3326					.2865
18	.3898	.3326					.3582
19	.5258	.5175					.4784
20	.5959	.5973	.5784		.5609		.5258
21	.4835	.543	.5258				.5083
22	.4298	.462	.4557				.4382
23	.3045	.3142					.3506
24	.2658	.2743	.2587	.2865		.3155	.3544
Max	.5959	.5973	.5784	.5611	.5609	.4382	.5258
Min	.2658	.2743	.2402	.2686	.2279	.3155	.2328
Avg	.3775	.3895	.3891	.3528	.3603	.3564	.3687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 204 / 11 kv Mhaswad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1663	.1109	.6706		.4191	.3978
2		.1294	.1109	.5365			.3978
3		.1294	.1109	.4694			.4973
4		.1294	.1109	.4694		.503	.4973
5		.1478	.1478	.4862			.5243
6		.1463	.1478	.8886			.5243
7		.1294	.1478	1.1401			
8	.1052	.0739	.1109	.8718	.7209	.788	
9	.7537	.9389			.0678		
10	.8421	.9945					.5304
11	.6554	.8048					.4588
12	.5898	.7209	.0671		.0686		.5243
13	.5898	.6554					.4641
14	.407	.5304					.5304
15	.6104	.5967					
16	.7209	.7209	.1341		.0686		
17	.1433	.0739					
18	.0732	.1478					
19	.2195	.2218					
20	.2896	.2957	.1928		.2103		
21	.2172	.2957	.1753				
22	.1478	.1478	.1578				
23	.1478	.1109					
24	.8421	.1663	.1109	.7042		.1227	.1402
Max	.8421	.9945	.1928	1.1401	.7209	.788	.5304
Min	.0732	.0739	.0671	.4694	.0678	.1227	.1402
Avg	.4326	.3531	.1311	.6930	.2272	.4582	.4573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 205 / 11 KV Gondawale Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.7545	.156			
2		.7209	.7045	.1387			
3		.7377	.7293	.1387			
4		.7377	.7293	.1734		.2103	
5		.7209	.8192	.2254			
6		.6882	.9831	.3294			
7		.663	1.1523	.3121			
8	1.278	1.3108	1.1012	.2774	.2454	.2279	
9		.1753	.9717		1.0059	1.1469	
10	.1848	.1772	.9069		.9831		.2126
11	.1848	.1791	.8421		1.0814		.1753
12	.1848	.1448	.7449		.9995		.1753
13	.1848	.1448	.7449		.8684		.2103
14	.1478	.181	.7125		.8718		.1753
15	.1478	.181	.6802		.8356		
16	.1848	.181	.7287		.8684		
17	.1848	.181	.1509		.2458		
18	.2218	.181	.1865		.1677		
19	.2957	.2896	.2374		.2279		
20	.2587	.3258	.2743				
21	.2218	.2534	.2572				
22	.2218	.2172	.2229				
23	.8139	.7712					
24	.7712	.181	.7712	.1734		.1928	
Max	1.278	1.3108	1.1523	.3294	1.0814	1.1469	.2126
Min	.1478	.1448	.1509	.1387	.1677	.1928	.1753
Avg	.3430	.4208	.6698	.2138	.7001	.4445	.1898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 201 / 11 KV PINGALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3674	.3803	.3761	.3929	.2088	.2187	.4149
2	.359	.3704	.3654	.3822	.1981	.1981	.3867
3	.3475	.3605	.3382	.3746	.189	.1951	.3829
4	.3796	.3514	.3405	.4169	.189	.1951	.3829
5	.4717	.4108	.4193	.4192	.2301	.2073	.4614
6	.6383	.6531	.6177	.7042	.3589	.3719	.6832
7	.6614	.6995	.7442	.7594	.4565	.4481	.7415
8	.5978	.5918	.6314	.6508	.4092	.3513	.6436
9	.2926	.5277	.5266	.5266	.2873	.4938	.4855
10	.3928	.4504	.4081	.205	.234	.418	.4215
11	.3773	.4073	.3974	.1852	.2164	.4058	.4009
12	.3871	.3637	.3642	.2141	.1852	.2096	.4329
13	.3849	.3769	.3647	.221	.1859	.4314	.4489
14	.4024	.3891	.3936	.2423	.2004	.4443	.4469
15	.3826	.4052	.4014	.2385	.1997	.3826	.3788
16	.4466	.4197	.2202	.2241	.218	.375	.3849
17	.4626	.4542	.4719	.253	.2256	.4375	.4398
18	.5415	.5401	.5462	.2606	.2469	.546	.5265
19	.7156	.6786	.6664	.346	.3315	.6935	.5796
20	.8207	.8678	.8263	.4077	.442	.7846	.7582
21	.7224	.771	.7702	.41	.4252	.7773	.6977
22	.6462	.6348	.6695	.3582	.3795	.6703	.647
23	.4904	.4685	.5373	.2949	.314	.5742	.5693
24	.4134	.3997	.4279	.4096	.237	.2644	.4855
Max	.8207	.8678	.8263	.7594	.4565	.7846	.7582
Min	.2926	.3514	.2202	.1852	.1852	.1951	.3788
Avg	.4876	.4989	.4927	.3707	.2737	.4206	.5084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 202 / 11 KV KIRAKSAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	.8097	.7773	.1134		.1219
2	.8097	.8097	.7449	.1134		.1219
3	.8097	.8097	.7449	.1134		.1219
4	.8097	.8097	.7449	.1296		.1219
5	.8097	.8907	.7287	.1296		.1524
6	.9717	1.1012	.9282	.192		.1829
7	1.4089	1.4089	1.1843	.16		.1524
8	1.3117	1.1822	1.1043	.112		.0914
9	.1219	.0914	1.1523	.9804	1.2651	.0762
10	.1134	.1067	1.1069		1.3441	.0762
11	.0914	.0914	.9962		1.3927	.0762
12		.1107	.8697			.0762
13	.0914	.0949	.4744			
14	.1134	.1107	.8223		.4534	
15	.1134	.1107	.6009		1.2955	
16		.1107			1.2955	
17		.1107	.1107		.0914	.0914
18	.1296	.1265	.1265		.0914	.1219
19	.1677	.128	.1423		.1372	.1372
20	.1677	.176	.1581		.1524	.1524
21	.1677	.16	.1581		.1524	.1677
22	.1524	.144	.144		.1372	.1524
23	.8097	.7773	.1134		.1372	.1524
24	.8259	.8097	.7773	.1134		.1219
Max	1.4089	1.4089	1.1843	.9804	1.3927	.1829
Min	.0914	.0914	.1107	.112	.0914	.0762
Avg	.5146	.4617	.6396	.2157	.6112	.1234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 401 / 33 KV MANDESHI SOOT GIRNI

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8573	.9619	.9054		.8488
2	.9145	.8573	.9054	.8488		.8488
3	.9145	.8573	.9054	.9054		.8488
4	.9145	.8573	.8488	.9054		.8488
5	.9145	.9145	.9619	.9619		.9054
6	.9145	.9717	.9619	1.0185		1.0185
7	.9145	.9717	.9619	.8488		.9619
8	.9145	.9717	.9054	.9054		.9619
9	.8002	.8002	.8488	.7922	.6687	.9054
10	.8002	.8573	.7922		.7356	.9054
11	.8002	.9145	.8488		.7356	.9054
12	.8002	.679	1.0185		.7922	.9054
13	.8002	.8488	.7922		.7922	.9054
14	.8573	.7356	.9619		.8488	.8488
15	.8573	.8488	.7922		.8488	.8488
16	.9145	.9054			.8488	.9054
17	.9145	.9054	.8488		.7922	.9054
18	.9145	.8488	.8488		.7922	.9619
19	.9145	.7922	.9619		.7922	.9619
20	.9717	.9054	.9054		.7356	.9619
21	.9145	.8488	.9619		.7922	.9054
22	.8573	.9054	.8488		.8488	.9054
23	.9145	.9054	.9619		.8488	.9054
24	1.0288	.9145	1.0185	.9054		.8488
Max	1.0288	.9717	1.0185	1.0185	.8488	1.0185
Min	.8002	.679	.7922	.7922	.6687	.8488
Avg	.8907	.8698	.9054	.8997	.7915	.9054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 301 / 22 KV DAHIWADI

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.6804	1.7558	1.6632	1.6827	1.7909	1.7558
Max	1.6804	1.7558	1.6632	1.6827	1.7909	1.7558
Min	1.6804	1.7558	1.6632	1.6827	1.7909	1.7558
Avg	1.6804	1.7558	1.6632	1.6827	1.7909	1.7558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 302 / 22 KV BIDAL AG (DAHIWADI) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.0486	.9804	.9602	.5658	.4588	.5487
Max	1.0486	.9804	.9602	.5658	.4588	.5487
Min	1.0486	.9804	.9602	.5658	.4588	.5487
Avg	1.0486	.9804	.9602	.5658	.4588	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 303 / 22 KV SHINGANAPUR AG
 (DAHIWADI Feeder KV- 22 /
 OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
 DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.2641	.3395	.3395	.4108	1.1203	.3292
Max	.2641	.3395	.3395	.4108	1.1203	.3292
Min	.2641	.3395	.3395	.4108	1.1203	.3292
Avg	.2641	.3395	.3395	.4108	1.1203	.3292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 305 / 22 KV DEVAPUR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.9602	.9804	.8539	.1132	.1509	.1463
Max	.9602	.9804	.8539	.1132	.1509	.1463
Min	.9602	.9804	.8539	.1132	.1509	.1463
Avg	.9602	.9804	.8539	.1132	.1509	.1463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 201 / 11 KV LALGUN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9488	.9991	.0358	.0366	.0373	.0358	.8596
2	.9602	.9774	.0343	.0351	.0377	.0366	.8413
3	.9555	.9556	.0343	.0343	.037	.0351	.7468
4	.9555	1.0059	.0339	.0351	.0377	.0343	.7811
5	.9105	1.0059	.0335	.0358	.037	.0351	.8785
6	1.166	1.2717	.0339	.0351	.037	.0343	1.0957
7	1.6324	1.3565	.0343	.0343	.0373	.0351	1.7368
8	1.6604	1.3889	.0351	.0351	.037	.0343	1.4883
9	.0366	.0343	1.7147	1.5074	1.4582	1.6164	
10	.0362	.0358	1.8185	1.5394	1.4864	1.491	
11	.0358	.0358	1.5364	1.6032		1.3108	
12	.0358	.0366	1.6221	1.3413		1.3279	
13	.0358	.0366	1.4419	1.3599	1.3245	1.2018	
14	.0358	.0366	1.3546	1.1873	1.1488	1.2193	
15	.0358	.0366	1.2654	1.2186	1.1797	1.3108	.0343
16	.0358	.0366		1.3283	1.2407	1.4091	.0351
17	.0358	.0366	.0328	.0377	.0343	.0366	.0358
18	.0358	.0366	.0335	.0377	.0351	.0366	.0366
19	.0358	.0366	.0343	.0566	.0358	.0549	.0358
20	.0358	.0366	.0351	.0754	.0366	.0739	.0366
21	.0358	.0366	.0343	.056	.0358	.0739	.0373
22	.0358	.0366	.0351	.0373	.0351	.0566	.0366
23	.8059	.0366	.0351	.0366	.0358	.0377	.0358
24	.9488	1.0208	.0358	.0358	.0377	.0351	.0373
Max	1.6604	1.3889	1.8185	1.6032	1.4864	1.6164	1.7368
Min	.0358	.0343	.0328	.0343	.0343	.0343	.0343
Avg	.4769	.4386	.4915	.4892	.3828	.4822	.4883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 202 / 11 KV MANJARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8116	.7945	.7735	.7774	.711	.8174	.799
2	.7811	.7583	.7278	.7449	.7324	.743	.7661
3	.7806	.7278	.7144	.7182	.7099	.7426	.7545
4	.7611	.7278	.7897	.7571	.6902	.7525	.7787
5	.771	.8136	.783	.8428	.7264	.7682	.8442
6	1.0435	.9678	.9284	1.0471	1.062	1.0646	1.0559
7	1.2022	1.1526	1.1603	1.1629	1.1272	1.1755	1.1206
8	1.0917	1.0879	1.142	1.0966	1.0893	1.0913	1.0306
9	.9402	1.0117	.8897	.8559	.913	.9149	.9228
10	.8833	.8879	.8261	.7308	.8021	.8511	.7804
11	.8261	.8215	.8338	.8177	.4153	.7964	.7221
12	.7888	.7888	.8406	.7274	.4382	.8249	.7278
13	.7933	.8635	.841	.7766	.7754	.8752	.7469
14	.8135	.9096	.7869	.7445	.8489	.8436	.924
15	.8501	.8444	.7792	.7735	.8577	.8776	.7506
16	.8894	.8261	.4477	.7343	.8352	.9579	.7583
17	.9087	.8364	.8745	.8697	.8577	1.0147	.7468
18	.8421	.8654	.8642	.8591	.9183	1.0166	.8044
19	.8135	1.0916	.9374	1.0478	1.0685	1.0799	.9103
20	1.164	1.4308	1.4117	1.4386	1.4632	1.4539	1.353
21	1.3317	1.4422	1.5195	1.4872	1.4411	1.5847	1.3813
22	1.2936	1.3119	1.376	1.3393	1.3523	1.4286	1.2658
23	1.2636	1.2193	1.1244	1.0627	1.1789	1.1679	1.1126
24	.916	1.0403	.9849	.8726	.8299	.9656	.977
Max	1.3317	1.4422	1.5195	1.4872	1.4632	1.5847	1.3813
Min	.7611	.7278	.4477	.7182	.4153	.7426	.7221
Avg	.9400	.9676	.9315	.9285	.9102	.9920	.9181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 303 / Budh Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8226	.7331	.7133	.7682	.7271	.7393	.7445
2	.7644	.7026	.6783	.7331	.6835	.7133	.6767
3	.7671	.6874	.6607	.698	.6661	.7026	.6615
4	.7464	.6721	.7315	.759	.6509	.698	.7095
5	.8444	.8657	.7925	.7956	.7339	.7636	.8169
6	1.1903	1.0441	1.0211	1.105	1.0631	1.1584	1.1507
7	1.2689	1.166	1.2574	1.2117	1.1812	1.2049	1.2685
8	1.1545	1.1508	1.1279	1.1218	1.1317	1.0394	1.1622
9	1.0525	1.0029	.9205	1.0303	1.0974	.9846	1.0982
10	.8711	.8444	.8604	1.0303	.8504	.6554	.7225
11	.8139	.753	.8505	1.054	.4725	.9541	.8626
12	.8139	.7377	.7728	.9267	.5944	.8207	.8292
13	.7987	.7225	.714	.8231	.7728	.8596	.7271
14	.8292	.7377	.692	.7491	.7377	.82	.753
15	.8749	.7834	.7118	.8432	.7728	.7491	.7788
16	.8444	.7834	.4572	.7728	.7377	.8657	.7834
17	.9023	.7987	.753	.775	.7788	.8718	.9388
18	1.0364	.8139	.7576	.8253	.7789	.9492	.9347
19	1.1462	.9937	1.0822	1.0783	1.0593	1.0783	1.0593
20	1.4357	1.2955	1.4083	1.4586	1.3992	1.2864	1.4145
21	1.3794	1.326	1.3931	1.3793	1.4357	1.4037	1.3489
22	1.2117	1.2041	1.2574	1.1507	1.2041	1.2803	1.2193
23	.9465	.9785	.9725	.9572	1.0364	1.0639	1.0638
24	.9175	.7788	.7987	.7728	.8338	.8047	.8863
Max	1.4357	1.326	1.4083	1.4586	1.4357	1.4037	1.4145
Min	.7464	.6721	.4572	.698	.4725	.6554	.6615
Avg	.9764	.899	.8910	.9508	.8916	.9361	.9421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 305 / 22 KV KATEWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4255	1.5432	.0732	.0686	.0739	.0686	1.2742
2	1.3763	1.5432	.0716	.0671	.0747	.0701	1.2125
3	1.3283	1.5089	.0686	.0655	.0747	.0686	1.2548
4	1.5261	1.5261	.0686	.0671	.0754	.0701	1.2689
5	1.8031	1.8442	.0686	.0686	.0732	.0686	1.3375
6	1.5813	1.8652	.0686	.0701	.0739	.0686	1.4022
7	2.0317	2.0576	.0686	.0716	.0739	.0701	2.1216
8	1.8343	2.0919	.0686	.0732	.0739	.0716	1.7711
9	.0701	.0686	2.2786	2.0934	2.0553	1.9662	
10	.0701	.0701	2.2996	2.0485	1.9757		
11	.0686	.0732	2.2939	2.0222		1.9334	
12	.0701	.0732	2.1795			1.9109	
13	.0701	.0732	2.0919	1.9292	1.989	1.7185	
14	.0701	.0732	2.0317	1.9109	1.656	1.7497	
15	.0716	.0732	2.0119	1.9109	1.7604	1.6712	.0686
16	.0716	.0732		1.8884	1.7695	1.6766	.0701
17	.0716	.0732	.0701	.0754		.0732	.0716
18	.0716	.0732	.0716	.0754		.0732	.0732
19	.0716	.0732	.0732	.0754	.0701	.1109	.0747
20	.0716	.0732	.0716	.1132	.0716	.112	.0732
21	.0716	.0732	.0701	.112	.0686	.1132	.0747
22	.0716	.0732	.0716	.0754	.0686	.1097	.0732
23	1.2536	.0732	.0732	.0686	.0686	.112	.0747
24	1.4419	1.576	.0732	.0701	.0754	.0701	.0732
Max	2.0317	2.0919	2.2996	2.0934	2.0553	1.9662	2.1216
Min	.0686	.0686	.0686	.0655	.0686	.0686	.0686
Avg	.6914	.6936	.7095	.6531	.6111	.6068	.6872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 201 / 11 KV Pusegaon gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4377	1.4507	1.4532	1.4685	1.4453	1.5109	1.432
2	1.4164	1.3977	1.4171	1.4141	1.4179	1.4682	1.384
3	1.4034	1.3794	1.4049	1.4049	1.4042	1.4628	1.3596
4	1.3889	1.3695	1.3927	1.4113	1.3973	1.4715	1.3565
5	1.4144	1.4548	1.4159	1.5005	1.392	1.5791	1.4178
6	1.6906	1.7787	1.7543	1.7413	1.8179	1.9125	1.8827
7	1.9242	2.1646	1.9234	1.8789	1.8636	2.1083	2.0439
8	1.685	1.9883	1.8362	1.7924	1.7787	1.9197	1.9208
9	1.6427	1.736	1.7882	1.7352	1.6918	1.789	1.752
10	1.6328	1.7021	1.7376	1.6804	1.6564	1.7265	1.7307
11	1.6499	1.5093	1.616	1.6994	1.642	1.7981	1.672
12	1.6156	.1738	1.6636	1.6176	1.5843	1.8004	1.6019
13	1.6347		1.688	1.5962	1.459	1.7608	1.5836
14	1.5993	1.9285	1.6846	1.6091	1.5779	1.6343	1.6252
15	1.6019	.9541	1.696	1.6785	1.632	1.7059	1.7409
16	1.6118	1.8366	1.6862	1.6713	1.776	1.909	1.7643
17	1.7422	1.8062	1.736	1.7772	1.7498	1.9811	1.8031
18	.9122	1.6896	1.7345	1.7303	1.8107	1.7977	1.7833
19		1.8705	2.0912	1.7665	1.9399	2.0371	1.8842
20		2.263	2.2916	2.3038	2.3716	2.4615	2.1624
21	2.3102	2.2455	2.183	2.2314	2.3487	2.3617	2.3076
22	2.4147	1.1515	2.1269	2.082	2.2207	2.1647	2.1673
23	1.989	1.8233	1.8408	1.8218	1.97	1.9436	1.8728
24	1.5916	1.5596	1.5881	1.5939	1.6038	1.632	1.6057
Max	2.4147	2.263	2.2916	2.3038	2.3716	2.4615	2.3076
Min	.9122	.1738	1.3927	1.4049	1.392	1.4628	1.3565
Avg	1.6504	1.6188	1.7396	1.7169	1.7313	1.8307	1.7439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 202 / 11 KV PUSEGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0149	.0151	1.254	1.3818	1.1557	1.1338	.0166
2	.0149	.0151	1.2435	1.3306	1.1336	1.1163	.0151
3	.0149	.0151	1.2193	1.2919	1.1282	1.0774	.0151
4	.0149	.0151	1.214	1.2752	1.1191	1.1115	.0151
5	.0149	.0151	1.2252	1.2597	1.1534	1.1629	.0151
6	.0297	.0151	1.3526	1.2816	1.3058	1.2896	.0151
7	.0149	.0151	2.0193	1.7164	1.9324	1.8648	.0151
8	.0149	.0151	1.9296	1.8751	2.0852	1.8562	.0151
9	2.0022	2.0996	.736	.7109	.89	.6713	2.0345
10	2.167	2.1603	.0151	.0151	.0151	.0159	2.1035
11	2.2052	2.0081	.0151	.0151	.0151	.0151	1.8246
12	2.1896	1.038	.0151	.0151	.0151	.0494	1.7886
13	2.0691	.7209	.0151	.0151	.0151	.0357	1.8165
14	2.0098	1.8113	.022	.025	.0151	.0532	1.8218
15	1.9285	1.0204	.0151	.0159	.0151	.0151	1.8067
16	1.9614	1.8161	.0395	.0151	.0151	.0151	1.8917
17	.7764	.7878	.0166	.0151	.0166	.0151	.7421
18	.0189	.0151	.0806	.0166	.0151	.0151	.0151
19	.0166	.0151	.0598	.0301	.0301	.0151	.0309
20		.0151	.088	.0331	.0151	.0578	.0151
21	.0301	.0151	.117	.0301	.0301	.0151	.0301
22	.0301	.0151	.086	.0309	.0151	.0166	.0301
23	.0151	1.2989	1.5179	1.165	.0166	.0151	.0452
24	.0297	.7254	1.4087	1.3216	.5658	.0959	.0151
Max	2.2052	2.1603	2.0193	1.8751	2.0852	1.8648	2.1035
Min	.0149	.0151	.0151	.0151	.0151	.0151	.0151
Avg	.7645	.6535	.6544	.6201	.5297	.4887	.6722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 203 / 11 KV VARDHANGAD AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8065	1.9396	.1317	.105	.0783	.1317	1.3536
2	1.7844	1.8942	.1301	.1126	.0966	.0989	1.3902
3	1.7784	1.8395	.1324	.1309	.105	.1126	1.3714
4	1.7654	1.8562	.1454	.1332	.1073	.1202	1.3699
5	1.7613	1.9761	.1469	.1347	.105	.1157	1.3885
6	1.9959	2.1635	.121	.1172	.0454	.1149	1.8633
7	2.6595	2.7271	.1088	.1088	.1346	.1187	2.2539
8	2.7778	2.8475	.0989	.0707	.118	.1164	2.2767
9	1.271	1.3495	2.5551	2.485	2.5458	2.6723	1.1294
10	.0166	.0181	3.0535	2.9553	2.9407	2.8182	
11	.0166	.0303	3.0378	2.8869	2.7977	2.7425	
12	.0166	.0015	2.9584	2.531	2.595	2.6071	
13	.0166		2.8835	2.3286	2.6482	2.48	
14	.0997	.0166	2.768	2.4535	2.5301	2.383	
15	.102		2.7642	2.4848	2.5535	2.3222	.0212
16	.0913	.0379	2.4158	2.577	2.4251	2.4551	.0372
17	.1035	.1073	1.0529	1.4204	1.2146	1.3076	.0257
18	.1172	.1279	.0351	.1065	.0423	.0181	.0166
19	.1271	.1317		.1216	.0705	.1126	.1239
20	.1707	.1218	.1201	.0766	.102	.1187	.1488
21	.1677	.1149	.1368	.1178	.1079	.1202	.1549
22	.1593	.1073	.1155	.1254	.1073	.1309	.1346
23	1.9323	.0974	.0905	.1058	.0989	.1324	.1088
24	1.9104	.9413	.0296	.0585	.1286	.1614	.108
Max	2.7778	2.8475	3.0535	2.9553	2.9407	2.8182	2.2767
Min	.0166	.0015	.0296	.0585	.0423	.0181	.0166
Avg	.9437	.9294	1.0883	.9895	.9874	.9796	.8040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 301 / 22 KV Nidhal GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2735	.2735	.2735	.2735	.2735	.2888	.2888
2	.2735	.2583	.2583	.2735	.2735	.2888	.2735
3	.2583	.2583	.1829	.2735	.2735	.2735	.2735
4	.2583	.2583	.2583	.2735	.2735	.2735	.2735
5	.2583	.2431	.2583	.2735	.3113	.3266	.2735
6	.3955	.4252	.418	.4485	.471	.4862	.5015
7	.5015	.2278	.4485	.3875	.1901	.4252	.2583
8	.4333	.471	.3723	.3723	.4028	.4485	.3723
9	.3418	.3571	.2888	.3193	.3571	.3497	.3723
10	.2431	.3193	.2583	.2431	.304	.3266	.3723
11	.3345	.2735	.2888	.2735	.2735	.3723	.304
12	.2735	.2735	.2735	.2735	.2583	.3193	.2888
13	.2735	.2735	.1981	.2735	.2888	.2735	.3418
14	.2888	.2735		.2888	.3418	.2888	.304
15	.2735	.2888		.304	.3418	.304	.304
16	.2735	.2888		.2735	.3266	.304	.3418
17	.2583	.304	.3875	.3418	.3266	.3266	.2888
18	.2735	.3418	.5015	.3571	.3571	.3948	.3266
19	.3266	.5015	.5167	.4028	.4557	.4862	.4405
20	.6154	.5319	.5777	.5472	.5167	.6306	.5319
21	.5167	.479	.5624	.5167	.5015	.5624	.5015
22	.4485	.3353	.5167	.4638	.4485	.4638	.4485
23	.3497	.2591	.3875	.3497	.3875	.3497	.3497
24	.2286	.2888	.304	.2888	.304	.304	.304
Max	.6154	.5319	.5777	.5472	.5167	.6306	.5319
Min	.2286	.2278	.1829	.2431	.1901	.2735	.2583
Avg	.3322	.3252	.3586	.3372	.3441	.3695	.3473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 302 / 22 KV DARUJ AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.881	1.0406	4.6403	4.9543	5.0175	4.0775	.9796
2	.881	1.0029	4.5442	4.7996	4.8956	4.5321	.9796
3	.8505	.9724	4.5904	4.7691	4.8956	4.4406	.9796
4	.8505	.9724	4.5572	4.8651	4.8956	4.4764	.9492
5	.9187	1.0406	4.715	5.0548	4.8956	4.7775	1.0101
6	1.0551	1.1771	5.1394	5.3384	5.2119	5.6989	1.2757
7	1.238	1.4731	6.8381	7.1083	6.0067	7.7946	1.4354
8	1.1088	1.3977	7.3708	7.2226	7.4128	7.896	1.36
9	5.5266	6.2673	4.7146	4.4939	5.0339	4.7146	6.6689
10	7.3266	7.2626	.881	.6835	.9115	.7518	7.7809
11	7.2352	7.2108	.9187	.1509	.9492	.8505	7.2466
12	7.2306	7.1986	.9492	.3948	.9419	.8505	6.7543
13	7.0493	6.5828	.9115	.4557	.881	.82	6.6956
14	6.6773	6.3374	.881	.4557	.9796	.8128	6.9463
15	6.7444	6.2445	.9187	.418	.9796	.8505	6.9791
16	7.1757	6.2475	.9187	.3948	.9796	.7823	7.2002
17	5.2706	4.6537	1.0478	.82	1.0478	.82	5.0267
18	1.0173	.7823	1.0406	.9492	1.2076	.6604	.8882
19	1.222	1.0856	1.2148	1.3511	1.3134	.9564	1.1843
20	1.6327	1.3367	1.4354	1.4659	1.6327	1.4049	1.534
21	1.5573	1.2307	1.4282	1.4354	1.6255	1.4049	1.4659
22	1.4659	.7926	1.3367	1.3672	1.3831	1.2612	1.3977
23	1.2307	4.3095	4.7783	4.3447	1.1553	1.1088	1.2002
24	1.0334	3.6622	5.0061	5.1067	2.3045	.9724	1.0406
Max	7.3266	7.2626	7.3708	7.2226	7.4128	7.896	7.7809
Min	.8505	.7823	.881	.1509	.881	.6604	.8882
Avg	3.2158	3.3451	2.9490	2.8500	2.7732	2.6132	3.2908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 303 / 22 KV Nidhal AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0814	1.073	.0754	.0754	.1132	.1132	.7537
2	1.0814	1.073	.0754	.0754	.1132	.1132	.7537
3	1.0814	1.0159	.0754	.0754	.1132	.1132	.7444
4	1.0814	1.0159	.0754	.0754	.1132	.1132	.7377
5	1.1142	1.0883	.0754	.1132	.1132	.1132	.7293
6	1.3108	1.2163	.1509	.1509	.1509	.1132	1.1142
7	1.7695	1.6324	.1509		.1509	.1509	1.5729
8	1.6057	1.5364	.1132	.1886	.1132	.1509	1.3435
9	.1132	.1132	1.4746	1.6057	1.6712	1.4419	
10	.0754	.0754	1.5729	1.6385	1.8023	1.4746	
11	.0754	.0754	1.4091	1.5402	1.6057	1.5074	
12	.0754	.0377	1.3763	1.4091	1.4746	1.2452	
13	.1132	.1132		1.3108	.426	1.278	
14	.1132	.0754		1.3108	1.3763	1.3435	
15	.1132				1.4091	1.4419	
16	.1132	.0754		.4458	1.4746	1.4419	.0983
17	.0754	.1132	.1132	.1132	.0754	.0754	.1132
18	.0754	.1132	.1509	.1509	.1132	.1132	.1132
19	.1132	.1509	.1509	.1509	.1509	.1509	
20	.1509	.1886	.1886	.1886	.1886	.1886	.1886
21	.1886	.1509	.1886	.1509	.1886	.1886	.1886
22	.1509	.1132	.1886	.1509	.1509	.1509	.1509
23	1.1065	.1132	.1132	.1132	.1132	.1509	.1509
24	1.0814	1.1065	.1132	.1132	.1132	.1132	.1509
Max	1.7695	1.6324	1.5729	1.6385	1.8023	1.5074	1.5729
Min	.0754	.0377	.0754	.0754	.0754	.0754	.0983
Avg	.5775	.5333	.3916	.5067	.5548	.5536	.5565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 201 / GOPUJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2667		1.1961	.9175	.7865	.9503
2	.2507	.2667		1.1469	.9175	.9175	.9175
3	.2149	.2667	.2286	1.0814	.9012	.9175	.9012
4	6.4396	.2667	.2286	1.065	.9012	.9831	.9831
5	.2667	.3048	.2667	1.0322	.9503	1.0486	1.0814
6	.3048	.381	.3048	1.1888	1.3599	1.1142	1.1142
7	.362	.381	.3429	1.8187	1.7859	1.278	1.3763
8	.362	.3429	.4191	1.7368	1.5729	1.118	1.4746
9	.639	1.704	.1905	.2096	.2286	.1715	
10	.2622		.2667		.2667	.2096	1.3763
11	.6226	1.5238	.2286			.1905	1.278
12	1.2944		.2286	.2286	.3048	.2286	1.2125
13	1.4091	1.1142	.2858	.2477	.2286	.2286	1.0486
14	1.3763	1.5074	.3048		.2477	.2667	1.0486
15	1.3763	1.5729	.3048	.2858	.2477	.2096	1.0322
16	1.4582	1.5074		.3239	.2477	.1715	1.0814
17	.1715	.2667	.3429	.3239		.3048	.1905
18	.2667	.2667	.381	.3048		.2667	.2286
19	.3429	.381	.2667	.362			.2667
20	.4191		.3048	.381		.4191	.362
21	.4191	.4191	.3048	.381			.362
22	.4001	.3429	.2477	.3429		.3429	.3429
23	.3429	.3048	1.278	.9831		.2667	.3048
24	.2667	.3048		1.2289	.9503		
Max	6.4396	1.704	1.278	1.8187	1.7859	1.278	1.4746
Min	.1715	.2667	.1905	.2096	.2286	.1715	.1905
Avg	.8134	.6520	.3363	.7557	.7518	.5448	.8606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 202 / VADUJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6112	.5998	.5304	1.3394	1.864	1.4861	1.3748
2	.5708	.5975	.4824	1.2898	1.8004	1.5196	1.4335
3	.5273	.5685	.474	1.2768	1.746	1.5189	1.4427
4	.5647	.5654	.5113	1.2677	1.7383	1.6621	1.5181
5	.5967	.5631	.5494	1.3207	1.7383	1.8313	1.6698
6	.6607	.6767	.6257	1.7326	2.4608	2.313	2.0752
7	.8291	.7552	.6859	3.0182	3.248	2.95	2.8204
8	.8223	.7674	.8939	3.1573	3.1364	2.8212	3.0224
9	2.7199	2.6177	.8177	1.499	1.2345	1.1949	1.4091
10	2.953	2.8544	.49	.2888	.5631	.602	2.6623
11	2.9241	2.7084	.628	.176	.3513	.7156	1.4616
12	2.6116	1.3344	.6485	.5022	.7575	.775	2.098
13	2.3853	2.4493	.6828	.4999	.7255	.7133	1.9307
14	2.3213	2.7328	.6843	.2218	.7415	.6569	1.7883
15	2.2744	2.5369	.6409	.4946	.7141	.6585	2.1392
16	2.5072	2.8616	.3102	.6691	.602	.7034	2.295
17	1.3359	1.1842	.7674	.7697	.3704	.8817	1.3016
18	.7247	.5845	.8588	.775	.413	.6797	.6645
19	.8443	.7719	.9687	.8749	.4252	.3955	.8147
20	.8909	.4435	1.0341	.8947	.4633	.9221	.8497
21	.8977	.8161	.9556	.884	.4763	.5014	.8405
22	.8542	.6538	.8894	.8947	.455	.4801	.7392
23	.7331	.6287	1.2349	1.8881	.362	.6706	.7003
24	.6401	.6539	.7423	1.7185	1.1755	.365	.3368
Max	2.953	2.8616	1.2349	3.1573	3.248	2.95	3.0224
Min	.5273	.4435	.3102	.176	.3513	.365	.3368
Avg	1.3667	1.2886	.7128	1.1439	1.1484	1.1257	1.5579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 203 / WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1105	.0526	.189	.1117	.1166	.1887	.1231
2	.1109	.1117	.1883	.1128	.189	.1875	.1551
3	.186	.1128	.1117	.186	.1536	.1117	.1929
4	.1856	.1395	.0594	.1864	.1788	.1864	.1909
5	.2702	.2538	.1083	.1864	.2549	.2507	.1189
6	.2553	.2564	.2561	.2549	.2568	.2564	.2423
7	.2561	.2561	.2572	.2568	.2572	.2568	.2549
8	.2549	.2557	.2534	.2591	.2584	.2378	.2557
9	.2523	.2561	.2538	.2027	.1761	.2523	.1444
10	.2576	.144	.2549	.1067	.1086	.2561	.2629
11	.1185	.1597	.2526	.0545	.0655	.2564	.2564
12	.1125	.0636	.2519	.1117	.2561	.2507	.2561
13	.2561	.1178	.2511	.0648	.2519	.2507	.2538
14	.2545	.0686	.2488	.0667	.237	.1136	.1178
15	.2545	.2545	.1532	.2538	.2481	.25	.1102
16	.2542	.2538	.0949	.2523	.2515	.2004	.1105
17	.2542	.1875	.2488	.253	.1349	.2515	.253
18	.2507	.1909	.2496	.2538	.1341	.25	.2523
19	.1144	.2538	.2496	.2538	.1341	.1341	.2523
20	.1254	.136	.2469	.2526	.1334	.2279	.2496
21	.2507	.1856	.2481	.1734	.0633	.0602	.2435
22	.2545	.117	.2496	.1208	.064	.1371	.1871
23	.1875	.1897	.1631	.1208	.0876	.1555	.2016
24	.1102	.1925	.0613	.1166	.1864	.0819	.1417
Max	.2702	.2564	.2572	.2591	.2584	.2568	.2629
Min	.1102	.0526	.0594	.0545	.0633	.0602	.1102
Avg	.2057	.1754	.2042	.1755	.1749	.2002	.2011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 204 / VADUJ GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.086	1.0136	.9955	1.1403	1.0498	1.1584
2	1.0498	1.0498	.9412	.9412	1.0791	1.0136	1.1222
3	1.0136	.9955	.9412	.9231	1.0242	1.0136	1.1222
4	.9774	.9955	.9412	.9231	1.0242	1.0498	1.086
5	1.0136	.9955	.9774	.9593	1.0498	1.1584	1.0498
6	1.1584	1.1041	1.134	1.0498	1.1222	1.1946	1.1584
7	1.2308	1.267	1.1946	1.267	1.2851	1.3394	1.3032
8	1.2308	1.2127	1.1041	1.1946	1.2851	1.2308	1.1584
9	1.086	1.1584	1.1222	1.086	1.1222	1.1222	
10	1.086	1.1584	1.1584		1.1946	1.1946	1.1222
11	1.1584	1.1222	1.267			1.267	1.267
12	1.267		1.267			1.3756	1.267
13	1.1584	1.2308	1.1946		1.2308	1.3394	1.267
14	1.086	1.1946	1.2308		1.2308	1.3032	1.2308
15	1.267	1.1946	1.267		1.267	1.3032	1.3032
16	1.1946	1.2308			1.3032	1.3032	1.3394
17	1.2127	1.267	1.3032	1.6289		1.3253	1.1946
18	1.1765	1.2851	1.2308	1.7013		1.1584	1.2308
19	1.448	1.4661	1.3032	1.7556		1.5203	1.4118
20	1.5203		1.7194	1.7737		1.6289	1.4118
21	1.3937	1.4661	1.4842	1.5927			1.3756
22	1.3937	1.1584	1.3575	1.5203			1.3575
23	1.267	1.1222	1.2308	1.3394		1.2308	1.2127
24	1.086	1.1403		1.0498	1.1765		
Max	1.5203	1.4661	1.7194	1.7737	1.3032	1.6289	1.4118
Min	.9774	.9955	.9412	.9231	1.0242	1.0136	1.0498
Avg	1.1901	1.1773	1.1992	1.2765	1.1690	1.2439	1.2341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 205 / GOPUJ GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1646	.1254	.1463	.1829	.1254	
2	.1254	.1646	.1075	.128	.1646	.1254	.1267
3	.1267	.1463	.1086	.128	.1646	.1267	.1086
4	.1448	.1463	.1267	.128	.1646	.1463	.1075
5	.1612	.1646	.1254	.128	.1646	.1448	.1086
6	.181	.2012	.1629	.1646	.2378	.181	.1991
7	.2149	.2378	.1448	.2012	.2378	.181	.1991
8	.1433	.1646	.1612	.1646	.1829	.1612	.1629
9	.1991	.1646	.1417	.128	.1478	.1448	
10	.181		.1063		.1663	.1629	.181
11	.2534	.181	.1612			.1629	.1991
12	.2195		.1612	.2378	.2241	.2012	.181
13	.2218	.181	.197	.2561	.2054	.1829	.2012
14	.1848	.1448	.1448		.1663	.1294	.1463
15	.1663		.1267	.1848	.112	.1294	.1463
16	.1663	.1267		.1848	.112	.1109	.1848
17	.1646	.1254	.128	.2402		.1478	.1829
18	.1646	.1433	.1463	.2561		.1254	.1829
19	.2378	.181	.2195	.2743			.1829
20	.2561		.2561	.2561		.181	.1829
21	.2195	.181	.2561	.2378			.1646
22	.2378	.1612	.2743	.2378			.2195
23	.2378	.1612	.2561	.2561		.1448	.2012
24	.1991	.1829		.1463	.2012		
Max	.2561	.2378	.2743	.2743	.2378	.2012	.2195
Min	.1254	.1254	.1063	.128	.112	.1109	.1075
Avg	.1896	.1662	.1654	.1945	.1772	.1508	.1700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 206 / 11KV KUMTHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1142	1.3435	.852	.2667	.2286	.2667	.2286
2	***	1.3272	.852	.2477	.2096	.2286	.2477
3	1.0486	1.3108	.8192	.2477	.2096	.2286	.2286
4	1.1469	1.278	.8192	.2667	.2096	.3048	.2477
5	1.2125	1.2452	.9831	.3048	.2286	.3429	.2667
6	1.5074	1.4746	1.1797	.4001	.4001	.362	.3048
7	1.8023		1.6057	.4191	.4191	.362	.381
8	1.6385	2.0153	1.6385		.362	.3048	.3429
9	1.5257	.2667	1.9334	1.6712	1.5402	1.6712	
10			1.5729		1.7368	1.7859	.3429
11		.2477	1.5238				.3239
12	.2858		1.4419	1.5893	1.7532	1.704	.3239
13	.2096	.2667	1.4091		1.5238	1.491	
14	.1905	.2286	1.4746		1.4746	1.7368	
15	.2286	.2286	1.5238	1.4746	1.3599	1.5893	
16	.2858	.2667		1.5402	1.4582	1.6057	.362
17	.3048	.2667	.381	.0953		.2477	.3048
18	.3429	.3048	.362			.3048	.3239
19	.4191	.3429	.4001	.3239			.3429
20	.4572		.4572	.4191		.4572	.4001
21	.8764	.4001	.4382	.3429			.4001
22	.4001	.3048	.4001	.3048			.381
23	2.7198	.7865	.3239	.2667		.2286	.3239
24	1.2452	2.7198		.2858	.2477		
Max	10.6665	2.7198	1.9334	1.6712	1.7532	1.7859	.4001
Min	.1905	.2286	.3239	.0953	.2096	.2286	.2286
Avg	1.3467	.8313	1.0178	.5815	.8351	.8012	.3199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 201 / 11 KV BANPURI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2096		2.915		2.915
2	.2667	.2286	.2096	3.2198	2.915	2.3834	2.915
3	.2667	.2286	.2096		2.915		2.915
4	.2667	.2286	.2096		2.915		2.915
5	.3048	.2667	.2667		2.915	2.4006	2.9835
6	.381	.3429	.3048		3.0864	2.7778	3.1893
7	.4382	.362	.381	3.7723	3.4979		2.5034
8	.3429	.381	.381	3.3608	3.4465		2.6406
9	3.3608	3.3265	.362	.2286	.2858	.2572	2.7778
10	3.6866	3.4122	.2858	.3048		.3048	2.915
11	3.9095	3.5837	.2858	.2286		.3048	2.8635
12	3.5151	3.3436		.3239		.2858	2.7435
13	3.5151	3.4637	.3048	.2667		.2858	2.915
14	3.3951	3.3779				.3048	
15	3.3951	3.3093	.2858	.2858	.3048	.2858	
16	3.4294	3.3265				.2858	3.3265
17	.2667	.362		.362		.3048	2.7949
18	.3429	.381		.381		.3429	.4001
19	.362	.362	.2858	.362		.3429	.4191
20	.381	.3429		.2667		.381	.4191
21	.3239	.3429		.2667		.3429	.4001
22	.3429	.3239	.381	.2667		.3048	.3048
23	.2858	.2477		2.9835		.2858	.2858
24	.2667	.2667	.2477	2.8978	2.915	.2058	.2858
Max	3.9095	3.5837	.381	3.7723	3.4979	2.7778	3.3265
Min	.2667	.2286	.2096	.2286	.2858	.2058	.2858
Avg	1.3880	1.3366	.2882	1.1634	2.5556	.6520	2.0831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 203 / 11 KV Palasgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3772	.3772	.1905	.1905	.2286	.1715
2	.3772	.3772	.3772		.1905		.1715
3	.3772	.3772	.3772		.1905	.2667	.1715
4	.3772	.3772	.3772	.2286	.1905		.1715
5	.4458	.4801	.4973		.1905		.1715
6	.6173	.6344	.6687		.381	.381	.4572
7	.8916	.9774	.8059	.3239	.4763		.4572
8	.7545	.7888	.7202		.4191		.4001
9	.2858	.2667	.6516		.7716	.6859	.3429
10	.2286	.2286	.6344	.823		.703	.3239
11	.2286	.1905	.5144	.6859		.6859	.2667
12	.2858	.1334		.5144		.6001	.1905
13	.2286	.1334	.5144	.4801		.5144	.1524
14	.2286	.1334				.4287	
15	.2286	.1334	.362	.4458	.6859	.5144	
16	.2286	.1143		.4973		.6859	.1524
17	.2286	.1715		.1905		.1715	.1905
18	.2286	.2096		.2286		.2096	.2286
19	.3239	.2667	.2858	.3048		.3429	.3048
20	.381	.3239		.4001		.381	.3239
21	.3239	.2477		.3048		.3239	.2858
22	.2286	.2286	.362	.2477		.2477	.2477
23	.4115	.4115		.1905		.1905	.2096
24	.4458	.3772	.3601	.1905	.1905	.2286	.1715
Max	.8916	.9774	.8059	.823	.7716	.703	.4572
Min	.2286	.1143	.2858	.1905	.1905	.1715	.1524
Avg	.3653	.3317	.4929	.3675	.3524	.4100	.2529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 301 / PIMPRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.663	.6477	.663	.6096	.6706	.4572	.6249
2	.6325	.6477	.663	.4268	.6554	.4115	.6096
3	.5411	.5411	.5715	.5182	.5639	.381	.5182
4	.5258	.5411	.5258	.3506	.5487	.5182	.5182
5	.5639	.5411	.5411	.3506	.5487	.3963	.602
6	.7316	.6935	.6706	.7392	.663	.7163	.7849
7	.9145	.8992	.8306	.8078	.8306	.5335	.9526
8	.8687	.8535	.8154	.7621	.8459	.4877	.8306
9	.6782	.5715	.5868	.5182	.602	.6401	.6325
10	.6096	.5944	.4725	.5334	.3658	.6858	.6401
11	.6173	.6401	.503	.5487	.4268	.7163	.6325
12	.602	.6554	.3506	.5715	.4877	.6249	.663
13	.5792	.6325	.5639	.5868	.4572	.6554	.6173
14	.6096	.6249	.4115	.4115	.4115	.6554	.4115
15	.6096	.6782	.5792	.602	.6325	.6706	
16	.6401	.663	.4268	.5563	.3963	.6249	.7011
17	.6706	.6554	.3506	.5639	.381	.6249	.7011
18	.7316	.6096	.442	.5639	.3658	.6401	.6706
19	.8078	.7468	.7011	.5944	.4572	.8459	.6935
20	.9449	.9068	.5944	.8535	.5792	1.0288	.9526
21	.8459	.9068	.6249	.8916	.5639	.9907	.9221
22	.7773	.8459	.823	.8764	.5639	.9221	.8992
23	.6706	.7925	.503	.7621	.5182	.7621	.7773
24	.663	.663	.663	.6554	.7011	.6249	.6935
Max	.9449	.9068	.8306	.8916	.8459	1.0288	.9526
Min	.5258	.5411	.3506	.3506	.3658	.381	.4115
Avg	.6874	.6897	.5782	.6106	.5515	.6506	.6978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 302 / ENKUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524				.1524
2	.1524	.1524	.1143			.1524	.1143
3	.1524	.1524	.1143	.1524			.1143
4	.1524	.1524	.1143				.1143
5	.1524	.1524	.1143				.1524
6	.5182	.3658	.2743	.1219	.1372	.3048	.4725
7	.7011	.6554	.6173	.7087	.4268	.4572	.7011
8	.6249	.6249	.5334	.5258	.4268	.4115	.6554
9	.4648	.3734	.2972	.6173	.2896	.1524	.5487
10	.5944	.2134	.2362	.5563	.1067	.4725	.221
11	.442	.1524	.2667	.6325		.5487	.2438
12	.5639	.1524	.4268	.5411		.4267	.503
13	.6249	.1524	.4801	.4496		.3353	.3201
14	.4267	.1524	.061	.0152		.1524	
15	.4877	.1524	.3963	.1905	.1524	.3353	
16	.5715	.1524	.4572	.2362		.1524	.4877
17	.5792	.1143	.2591	.3353		.3201	.3963
18	.6096	.1143	.442	.4191		.4572	.4496
19	.2896	.4877	.3582	.2057	.1219	.4191	.381
20	.6706	.663	.4268	.602	.4572	.6858	.7087
21	.6706	.6173	.4268	.6173	.4572	.7163	.6782
22	.5715	.5182	.503	.4649	.3506	.602	.6096
23	.1524	.2286	.1067	.1143	.1372	.4039	.1905
24	.1524	.1524	.1524	.1524		.1905	.1524
Max	.7011	.663	.6173	.7087	.4572	.7163	.7087
Min	.1524	.1143	.061	.0152	.1067	.1524	.1143
Avg	.4366	.2835	.3055	.3829	.2785	.3848	.3803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 303 / MANDVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143			.1524	.1524
2	.1143	.1143	.1143				.1143
3	.1143	.1143	.1143				.1143
4	.1143	.1143	.1143				.1143
5	.1143	.1143	.1143	.1143			.1143
6	.1524	.1524	.1143			.1143	.1524
7	.1524	.1524	.4115	.1448		.0457	.2972
8	.1524	.0305	.1143	.1143			.1905
9	.1524	.1524	.1143	.1143		.1143	.1905
10	.1524	.1524	.1143	.1143		.1143	.1524
11	.1524	.1524		.1143		.1143	.1524
12	.1524	.1524		.1524		.1143	.1524
13	.1524	.1524	.1143	.1524		.1143	.1524
14	.1524	.1143				.1524	
15	.1524	.1524	.1905	.1524	.1143	.1524	
16	.1143	.1524		.1143		.1524	.1524
17	.1143	.1143		.1143		.1524	.1524
18	.1524	.1143				.1524	.1524
19	.1524	.1524	.1905	.1143		.1524	.1524
20	.503	.4725	.061	.503	.3506	.5411	.3582
21	.4725	.442	.3048	.4877	.3658	.5411	.5258
22	.3505	.3048	.4344	.3124	.3353	.381	.1981
23	.1524	.4877	.1677	.3277	.0762	.1524	.1524
24	.1524		.1143	.1143		.1143	.1524
Max	.503	.4877	.4344	.503	.3658	.5411	.5258
Min	.1143	.0305	.061	.1143	.0762	.0457	.1143
Avg	.1775	.1816	.1677	.1919	.2484	.1857	.1839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 306 / PEDGOAN AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.9602	.8573				.381
2	.8916	.9602	.8573				.381
3	.8916	.9602	.8573			.3429	.381
4	.8916	.9602	.8573	.6097			.381
5	1.0288	1.2346	.9945				.381
6	1.5089	1.5089	1.0974			.6097	.5335
7	2.0576	1.989	1.406	.6859			.6097
8	1.7833	1.7833	1.5089	.6097			.6097
9	.4572	.381	1.2689	1.4403		1.7833	.6097
10	.5335		1.3375	1.5775		1.7147	.4572
11	.5335	.5335	.9602	1.3717		1.5432	.4572
12	.5716	.4572		1.2003		1.3717	.4191
13	.5335	.4954	.7545	.8916		1.0974	.381
14	.5335	.4954			1.3717	1.0974	
15	.5335	.5335	.8916	.9602	1.448	1.2346	
16	.5335	.5335		1.406		1.7147	.4572
17	.6097	.4954		.3429		.381	.5335
18	.6478	.5335				.381	.4572
19	.8383	.7621	.6097	.5716		.5335	.5335
20	.8383	.8383		.6859		.6859	.6859
21	.8383	.7621		.6097		.6097	.6097
22	.7621	.6859	.6097	.5716		.5335	.6097
23	1.2346	1.1317		.8383		.4191	.5335
24	1.0974	.9602	.9259	.4191		.3429	.381
Max	2.0576	1.989	1.5089	1.5775	1.448	1.7833	.6859
Min	.4572	.381	.6097	.3429	1.3717	.3429	.381
Avg	.8767	.8676	.9871	.8701	1.4099	.9109	.4902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 201 / AMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	2.037	2.5183	1.959	.9221	.4595	.4473
2	.1471	1.925	2.5206	1.9346	.9412	.3913	.4337
3	.157	1.8741	2.2138	1.9029	.9412	.3158	.4351
4	.1669	1.8922	2.2983	1.9677	.9252	.3088	.4351
5	.1699	2.2008	2.4981	2.0121	.9777	.3322	.4549
6	.189	2.87	2.9561	2.7395	1.0974	.4313	.5784
7	.2401	3.7218	3.4652	3.6839	1.6202	.583	.7285
8	.2629	3.8418	3.3935	3.5756	1.7558	.6119	.7377
9	.2538	2.0683	1.6096	1.5327	1.6659	2.7115	2.8503
10	.2401	.4465	.3355	.5018	1.5798	3.5277	3.1123
11	.1875	.4889	.3778	.4982	1.0395	3.3884	3.1039
12	.2225	.4597	.4361	.442	1.406	2.6824	1.5783
13	.2294	.518	.4367	.4685	1.422	2.6208	
14	.1898	.5018	.409	.4798	1.3138	2.5648	
15	.2004	.5157	.3892	.4716	1.2673	2.4099	
16	.2233	.4378	.4791	.433	1.2513	2.6117	3.562
17	.2629	.4528	.6337	.3673	1.0532	1.3704	2.1773
18	.2789	.4551	.6119	.4731	.2294	.5195	.5785
19	.301	.5038	.4683	.5275	.2751	.5984	.6249
20	.2964	.5546	.529	.515	.2721	.551	.6447
21	.2652	.5232	.5316	.5066	.2622	.5378	.6859
22	.2553	.4558	.4649	.5057	.2454	.5393	.6173
23	1.1462	2.8161	1.9471	1.7773	.266	.4588	.5746
24	1.1309	2.021	2.7702	1.9178	1.0555	.4756	.4908
Max	1.1462	3.8418	3.4652	3.6839	1.7558	3.5277	3.562
Min	.1402	.4378	.3355	.3673	.2294	.3088	.4337
Avg	.2982	1.3992	1.4289	1.2997	.9911	1.2917	1.1834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 204 / 11 KV MORALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0145	.1093	.0861	.0899	.0072	.1109	.1151
2		.088	.0701	.0381	.0019	.0964	.0118
3		.0712	.0701	.0991		.0743	.0701
4		.0693	.0754	.1067		.0682	.0766
5		.104	.0914	.1113	.003	.0534	.1052
6	.0476	.1802	.1511	.1269	.0579	.1261	.1334
7	.0739	.2447	.216	.216	.0781	.1806	.202
8	.0716	.1848	.2084	.1723	.0655	.1482	.1932
9	.0499	.1273	.12	.1563	.0427	.1208	.1135
10	.0194	.1246	.0983	.1215	.0065	.0743	.0789
11	.0293	.1078	.0701	.1238	.0412	.0952	.0983
12	.0404	.1135	.0975	.1116	.0293	.1147	.0019
13	.0415	.1147	.1196	.1143	.0248	.1116	
14	.0171	.1025	.1135	.1135	.0057	.0872	
15	.0118	.1173	.1067	.1113		.0739	
16	.0046	.1105	.1013	.1151	.0046	.1006	.1242
17	.048	.117	.1371	.1063	.0255	.1124	.2073
18	.0438	.1412	.1326	.1193	.0427	.1356	.1582
19	.053	.148	.1486	.1448	.0583	.1939	.208
20	.077	.202	.2393	.1736	.0758	.2504	.2244
21	.0793	.4229	.221	.1691	.0777	.2183	.1955
22	.0667	.2229	.1734	.178	.0667	.1882	.1826
23	.0602	.1745	.128	.128	.0564	.1474	.1646
24	.1189	.117	.1147	.1139	.1208	.1189	.1219
Max	.1189	.4229	.2393	.216	.1208	.2504	.2244
Min	.0046	.0693	.0701	.0381	.0019	.0534	.0019
Avg	.0484	.1465	.1288	.1275	.0425	.1251	.1327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 207 / 11 KV Goregaon (N) AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1506	.5671	.4779	.5838	.2522	3.9537	4.1426
2	2.1193	.5649	.4748	.5876	.2561	4.0017	4.3362
3	2.0965	.5468	.439	.5899	.2583	2.8936	4.318
4	2.095	.5495	.4412	.6341	.2652	3.8341	4.377
5	2.1338	.6348	.5041	.6806	.2896	3.8647	4.9215
6	2.3617	.7815	.6333	.8185	.3544	4.6167	5.327
7	2.6703	.9128	.711	.897	.4489	5.1029	5.3319
8	2.6886	.8156	.6823	.8825	.4809	4.8575	5.295
9	2.889	4.3907	5.2185	4.5154	.4351	2.9934	2.3762
10	2.889	4.7168	5.6325	4.9505	.4176	.6943	.6613
11	2.6231	5.237	5.8551	3.9308	.1936	.6638	.2362
12	2.5667	5.8205	5.7217	6.1292	.2622	.5632	
13	2.4524	5.8755	5.2279	6.0673	.2614	.5654	
14	2.4935	5.6966	4.952	5.7643		.4946	
15	2.4737	5.3479	4.9992	5.6455		.5136	
16	2.5735	4.8495	5.0053	5.6154		.5556	.5958
17	2.2016	.6815	2.2595	2.6322		.6098	.555
18	.3612	.6567	.5205	.6927	.3597	.6357	.7185
19	.3948	.6577	.5602	.8209	.4245	.788	.9065
20	.3734	.743	.727	.828	.4641	.909	.9762
21	.3688	.7011	.7027	.8185	.4329	.788	.9286
22	.3193	.6005	.6158	.7377	.3788	.6947	.8779
23	.3201	.5518	.5919	.6621	.9183	.5931	.8232
24	2.0081	.611	.628	.6287	.4755	.5594	.651
Max	2.889	5.8755	5.8551	6.1292	.9183	5.1029	5.3319
Min	.3193	.5468	.439	.5838	.1936	.4946	.2362
Avg	1.901	2.1880	2.2326	2.3381	.3815	1.9061	2.4178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 302 / MHASURNE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	1.3443	1.3923	1.2308		.2641	.1509
2	.1463	1.5364	1.3923	1.2308		.2263	.1509
3		1.2803	1.3108	1.2308		.2263	.1509
4		1.2631	1.2452	1.2803		.1886	.1509
5		1.4575	2.2024	1.2803		.2263	.1509
6		1.704	1.1336	1.6842		.3018	.2263
7		2.2283	1.6004	2.2939		.3772	.2641
8		2.0081	1.6842	1.9608		.3395	.2263
9		.3018	.3772	.3395		2.1704	1.9433
10		.2263	.2263	.1886		2.0119	2.0165
11		.2263	.3018	.3018		2.2043	2.0081
12		.2263	.3772	.2263		2.7435	
13		.2263	.3018	.2263		2.13	
14		.1886	.2641	.2263		2.0885	
15		.2263	.2641	.2263		1.6956	
16		.2263	.2641	.2263		1.6842	2.2405
17		.2263	.3018	.2641		.1886	.415
18		.1509	.3395	.2641		.1886	.4527
19		.2263	.3772	.3018		.2263	.4527
20		.2263	.3772	.3018		.2263	.415
21		.2263	.3395	.2641		.2263	.3772
22		.1886	.3395	.3018		.2263	.3772
23		1.2955	1.2308	1.0486		.2263	.3018
24	.1509	1.3927	1.6095	1.2308	.9717	.2641	.1886
Max	.1509	2.2283	2.2024	2.2939	.9717	2.7435	2.2405
Min	.1463	.1509	.2263	.1886	.9717	.1886	.1509
Avg	.1494	.7751	.8022	.7554	.9717	.8605	.6330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 303 / NIMSOD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.749	.2641	.3018	.3018	.2641		1.7901
2	1.8351	.2641	.3018	.2652	.2263		1.7238
3	1.8785	.2263	.2641	.2652	.2263		1.6766
4	1.8461	.2263	.3772	.2652	.2641		1.6918
5	2.1052	.3018	.4527	.3772	.3018		1.9204
6	2.2672	.3772	.5658	.4527	.3772		2.0081
7	2.6558	.4904	.5658	.4904	.5281		2.6558
8	2.5263	.4527	.415	.415	.415		2.17
9	2.6235	2.2283	2.1052	2.13	.3658	.2263	.3018
10	2.4006	2.5263	2.4006	2.3685		.1886	.3018
11	2.4326	2.3685	2.556	2.5587	.2641		.415
12	2.2672	2.17	2.2725	2.332	.415		
13	2.1956		1.9372	2.4615	.3772	.2641	
14	2.0972	2.0729	2.0729			.3018	
15	2.13	2.1376	1.8023			.3772	
16	1.9433	2.1125	2.0081	2.17		.3772	.3395
17	.3018	.4527	.3395	.2641	.1509	2.1445	.3772
18	.3772	.4527	.3772	.3395	.1886	2.5819	.3772
19	.415	.5281	.3395	.415	.2263	2.4531	.415
20	.4527	.4904	.415	.4527	.2263	2.1795	.5281
21	.415	.4527	.415	.4527	.1886	2.146	.4904
22	.3772	.4904	.3395	.415	.1886	1.989	.3772
23	.3018	.4527	.3018	.2641	.1886	1.989	.3018
24	1.7814	.3018	.3772	.3018	.2641	.1509	1.9662
Max	2.6558	2.5263	2.556	2.5587	.5281	2.5819	2.6558
Min	.3018	.2263	.2641	.2641	.1509	.1509	.3018
Avg	1.6406	.9496	.9710	.8981	.2824	1.2407	1.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 305 / SHIRASWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5392	.1509	.1509	.4862	.2119	.4862	.1509
2	.5087	.1509	.1509	.471	.1509	.4862	.1509
3	.471	.1132	.1509	.1509	.1509	.4862	.1509
4	.4557	.1132	.1886	.1509	.1509	.4333	.1509
5	.471	.1132	.1886	.3338	.1509	.471	.1661
6	.5167	.4934	.6147	.5696	.5167	.6226	.5015
7	.6234	.6756	.6226	1.7094	.6458	.9115	.5777
8	.6378	.5464	.6226	.5849	.6835	.8055	.5319
9	.7671	.5696	.6081	.759	.6611	.7068	.7743
10	.7902	.6539	.6844	.8657	.4725	.4862	.82
11	.5544	.6234	.714	.7902	.2576	.5319	.7976
12	.2881	.6081	.6611	.6683	.5167	.4862	.5182
13	.1509	.5929	.5167	.6306	.41	.4252	
14	.1509	.5015	.5392	.5392	.2809	.4557	
15	.1509	.5015	.4862	.5544	.1509	.2728	
16	.1509	.5015	.4325	.5544	.1509	.1509	.7976
17	.1509	.5392	.5392	.5087	.1886	.2423	.828
18	.2881	.1886	.5849	.2038	.2263	.3948	.8128
19	.4775	.6073	.7438	.41	.0914	.5319	.7823
20	.9347	.775	.8738	.7221	.5639	.7301	.8585
21	.8817	.7678	.889	.7221	.6249	.7453	.7445
22	.7373	.6691	.7293	.6988	.6097	.6844	.7293
23	.5777	.5929	.6081	.6154	.442	.6081	.6378
24	.4934	.4862	.5472	.4862	.5319	.4862	.471
Max	.9347	.775	.889	1.7094	.6835	.9115	.8585
Min	.1509	.1132	.1509	.1509	.0914	.1509	.1509
Avg	.4903	.4806	.5353	.5911	.3684	.5267	.5692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 306 / PUNWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.828	.7823	.775	.5639	.5792	.8207	.9267
2	.7598	.7671	.7221	.5335	.5639	.7902	.8207
3	.7445	.7293	.7221	.5182	.5487	.7902	.8055
4	.82	.7377	.7068	.503	.5335	.7373	.8292
5	.8433	.8207	.8055	.5639	.5944	.8207	.8664
6	1.254	1.254	1.2315	.9297	.9297	1.156	1.2925
7	1.595	1.6712	1.4441	1.0974	1.0822	1.5798	1.5051
8	1.3374	1.5116	1.3222	.9297	.945	1.4354	1.595
9	1.185	1.3062	1.1706	.7011	.7926	1.2148	1.23
10	1.1778	1.2612	1.1706	.7011	.6249	1.2765	1.2757
11	1.0639	1.2002	1.0559	.6706	.6554	1.2468	1.4121
12	1.0944	1.0486	1.246	.5335	.6401	.9884	1.0059
13	.9652	.9579	1.1248	.5639	.6097	1.0036	
14	1.0029	.828	1.0631	.5639	.5792	1.0341	
15	.95	1.0262	1.0944	.5639	.5639	1.0567	
16	1.0486	1.1024	1.1473	.5639	.6249	1.1408	1.4594
17	1.0029	1.0486	.9957	.4877	.7011	1.2315	1.6712
18	1.3069	1.1188	1.1088	.4572	.7468	1.1401	1.6191
19	1.5493	1.1706	1.3367	.7316	.8078	1.3831	1.4434
20	1.6792	1.5051	1.6407	1.1279	1.1431	1.5211	1.7322
21	1.5653	1.4289	1.4362	1.0822	1.0517	1.566	1.6792
22	1.3374	1.3687	1.2692	.9907	.945	1.3687	1.3759
23	1.1168	.9731	1.1096	.7773	.823	1.2163	1.193
24	.9115	.8738	.8664	.9267	.9195	.95	.9877
Max	1.6792	1.6712	1.6407	1.1279	1.1431	1.5798	1.7322
Min	.7445	.7293	.7068	.4572	.5335	.7373	.8055
Avg	1.1308	1.1038	1.1069	.7118	.7502	1.1445	1.2727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 301 / PACHWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1109	.1132	.0747	.0754	.1109	.0754
2		.0754	.0754	.0754		.1132	.0754
3		.0747	.0754	.0754		.1132	.0754
4		.0754	.0754	.0747		.1132	.0754
5		.1132	.0754	.1109		.1143	.0754
6		.1509	.1509	.1509		.1509	.1509
7		.1867	.1886	.2263	.1509	.2587	.1494
8		.1509	.1132	.1132	.1132	.1448	.1478
9	.1494	.1478	.1509	.1132	.1509	.1463	
10	.1494	.1132	.1132			.1086	.1132
11	.112	.1132	.112		.0732	.0747	
12	.112	.1132	.1132		.0747	.0754	
13	.1109	.1132	.0754	.0754	.0754	.0747	
14	.1132	.0754			.0754	.0747	.0754
15	.0739	.0754		.0754	.0754	.0693	.0754
16	.0754	.0754		.0754	.0754	.0739	.0754
17	.112	.1132		.0754	.112	.0754	.0754
18	.1109	.1132		.1132	.1086	.0754	.1132
19	.1848	.1509		.1886	.1448	.1848	.1509
20	.2241	.2263		.1886	.2218	.1886	.1886
21	.2218	.1509			.1867	.1867	.1886
22	.1509	.1509			.1509	.1509	.1509
23	.1509	.1132			.1132	.1132	.1132
24		.1132	.1132	.0747	.0754	.0716	.0754
Max	.2241	.2263	.1886	.2263	.2218	.2587	.1886
Min	.0739	.0747	.0754	.0747	.0732	.0693	.0754
Avg	.1368	.1207	.1104	.1107	.1141	.1193	.1110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 302 / PADAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754	.0754	.0754	.0754	.1132	.0377
2		.0747	.0754	.0754		.1132	.0373
3		.0754	.0754	.0754		.1132	.0377
4		.0754	.0754	.0754		.1132	.0377
5		.1109	.0754	.0754		.1509	.0747
6		.1886	.1509	.1132		.1886	.1509
7		.1509	.1886	.0762	.1509	.1524	.1509
8		.1132	.1132	.1132	.1132	.1143	.1132
9	.0754	.0754	.1132	.1132	.0754	.1132	
10	.1132	.0754	.0754			.0747	.0377
11	.0739	.0754	.0754		.0739	.0377	
12	.0754	.0754	.0754		.0754	.0377	
13	.0381	.0754	.0754	.0754	.037	.0377	
14	.0739	.0754			.0362	.0377	.0754
15	.0762	.0754		.0754	.037	.0373	.0754
16	.0754	.0754		.0754	.0754	.0377	
17	.0754	.0754		.0754	.037	.0377	.0754
18	.1463	.1132		.1509	.0377	.0377	.0754
19	.1867	.1132		.1886	.1494	.1132	.1132
20	.2263	.2263		.1886	.1867	.112	.1509
21	.1524	.1509			.1509	.1132	.1132
22	.1143	.1132			.1143	.0754	.1132
23	.0747	.0754			.1132		.0754
24		.0762	.0754	.0754	.0754	.0754	.0377
Max	.2263	.2263	.1886	.1886	.1867	.1886	.1509
Min	.0381	.0747	.0754	.0754	.0362	.0373	.0373
Avg	.1052	.1005	.0943	.0999	.0897	.0886	.0833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 303 / KALEDHON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.1886	.1886	.1886	.1886	.0754
2		.1886	.1886	.1509		.1848	.1132
3		.1886	.1886	.1886		.1886	.112
4		.1886	.1886	.1886		.2263	.1086
5		.3048	.1886	.2241		.2263	.1509
6			.3018	.3048		.3048	.2926
7		.3395	.3018	.2641	.2641	.3018	.2641
8		.2263	.1886	.1867	.2263	.2241	.1886
9	.1524	.1867	.2263	.1905	.1509	.1524	
10	.1886	.1886	.1509			.1886	.1886
11	.1494	.1886	.1509		.1509	.1494	
12	.1509	.1886	.1494		.1478	.1886	
13	.1886	.1509	.1509	.1886	.1509	.1509	
14	.1848	.1509			.1509	.1509	.1886
15	.1524	.1886		.1886	.1509	.1494	.2263
16	.1509	.1886		.1886	.1524	.1494	
17	.1829	.1509		.1886	.1886	.1509	.2263
18	.2241	.1509		.2263	.2172	.1509	.2263
19	.2641	.2641		.3018	.2987	.2641	.3018
20	.3018	.3395		.3018	.3018	.3018	.3395
21	.2667	.3018			.3018	.2614	.3018
22	.2667	.1886			.3018	.1886	.2641
23	.2263	.1886			.2263	.1886	.2263
24		.1886	.1886	.1886	.1886	.1886	.0754
Max	.3018	.3395	.3018	.3048	.3018	.3048	.3395
Min	.1494	.1509	.1494	.1509	.1478	.1494	.0754
Avg	.2034	.2100	.1966	.2153	.2088	.2008	.2037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 304 / STATIONERY POINT

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4156	1.467	1.4388	1.1603	1.4536	1.2426	1.2368
2	1.3508	1.5219	1.3835	1.0002	1.0174	1.2373	1.2845
3	1.2308	1.4464	1.3035	1.0155	1.1107	1.0886	1.3889
4	1.2117	1.2239	1.4483	.9983	1.0136	1.0529	1.3812
5	1.1736	1.2788	1.4121	.8116	1.0841	1.0258	1.4045
6	1.2193	1.302	1.4495	1.046	1.0117	1.0429	1.3173
7	.985	1.102	1.685	1.0688	1.0079	.9054	1.3607
8	.8993	.9225	1.3565	.8383	1.3672	1.0563	1.286
9	1.4689	1.3901	1.6606	1.0517	1.5554	1.1115	1.3969
10	1.5558	1.4625	1.5272	.9717	1.6053	1.2197	1.5588
11	1.5253	1.7101	1.4841	.9335	1.0482	1.2273	1.1888
12	1.3835	1.6149	1.4574	.6173	1.0067	1.273	1.2574
13	1.1679	1.5539	1.1275	1.0452	1.1763	1.2726	1.0479
14	1.2087	1.2247	.7278	.7373	1.3184	1.3645	1.3831
15	1.5329	1.2666	.823	1.0471	1.4559	1.4765	1.446
16	1.5806	1.3355	.9202	1.07	1.4079	1.4521	1.1831
17	1.675	1.2769	1.004	1.1595	1.5787	1.5489	1.4632
18	1.7235	1.5645	1.0383	1.2159	1.5806	1.4975	1.3226
19	1.6496	1.4369	1.0288	1.3691	1.6377	1.467	1.2521
20	1.7288	1.3569	1.0079	1.4487	1.3268	1.5089	1.2007
21	1.776	1.3622	1.0822	.9335	1.2544	1.4746	1.1458
22	1.9456	1.568	.9678	.9907	1.2277	1.3931	1.0963
23	1.7025	1.5017	1.0631	.9678	1.3112	1.2163	1.0163
24	1.2498	1.5173	1.4331	.9659	1.3146	1.3035	1.0654
Max	1.9456	1.7101	1.685	1.4487	1.6377	1.5489	1.5588
Min	.8993	.9225	.7278	.6173	1.0067	.9054	1.0163
Avg	1.4317	1.3920	1.2429	1.0193	1.2863	1.2691	1.2785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 305 / GHARUDI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3018	.3018	.9774	.9214	.6447	.6379
2		.3018	.2641	.9774	.6024	.6089	.6516
3		.3018	.2641	1.0242		.6154	.6878
4		.3018	.2641	1.0136		.6447	.6805
5		.4527	.3018	1.1218		.8764	.8063
6		.6036	.5658	1.749		1.166	1.0749
7		.6036	.6413	2.332	1.7193	1.6956	1.8519
8		.415	.5281	2.4272	1.6476	2.1216	1.4922
9	1.6617	1.7772	.415	.3018	.9568	.3772	
10	1.6575	1.6244	.3772		.415	.3734	1.1443
11	1.3226	1.4403	.3772		.2263	.3018	
12	1.1919	1.2003	.3395		.3018	.3018	
13	1.0029	1.0288	.3395	.3018	.3018	.3395	
14	.9313	1.0288			.3018	.3395	.9114
15	.5121	1.1317		.2641	.3395	.3018	1.3321
16	1.6461	1.6461		.2263	.3772	.2641	
17	.3395	.3018		.3018	.3395	.3395	.3018
18	.4904	.3395		.3772	.415	.3395	.3395
19	.4904	.4527		.5658	.4527	.5281	.4904
20	.4904	.5281		.5658	.5658	.5281	.5281
21	.4904	.4527			.4904	.4904	.5281
22	.4527	.415			.3395	.415	.415
23	.3772	.3395		.9774		.3772	.3395
24		.3395	.3018	.9774		.2641	.3395
Max	1.6617	1.7772	.6413	2.4272	1.7193	2.1216	1.8519
Min	.3395	.3018	.2641	.2263	.2263	.2641	.3018
Avg	.8705	.7220	.3772	.9157	.5952	.5939	.7659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 306 / KANERWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4961	.4607		.2263	.2263	.2641
2		.4961	.4252			.2263	.2641
3		.5014	.3898			.2263	.2641
4		.4961	.3898			.2641	.3018
5		.5609	.4252			.3772	.3395
6		.823	.7796			.5658	.4527
7		1.153	.9568		.679	.6413	.4904
8		.8764	.7796		.4904	.5281	.4527
9	.3018	.2641	.788		.8954	.788	
10	.2641	.2263	.7087		.7964	.8505	.3018
11		.1886	.7362		.543	.7796	
12	.2263	.1509			.7362	.5959	
13	.1886	.1886	.4706	.5258	.6024	.5258	
14	.1886	.1886			.5731	.4961	.1509
15	.1886	.1886			.631	.631	.1886
16	.2263	.1886		.7011	.7202	.631	
17	.2641	.2641		.1886	.2641	.7362	.2641
18	.3395	.3018		.3395	.3395	.2263	.3772
19	.415	.3772		.4904	.415	.2263	.4527
20	.4527	.4904		.4904	.4527	.4527	.4904
21	.4527	.415			.415	.4108	.4904
22	.415	.3395			.3772	.3734	.3772
23	.4961	.5258			.3018	.3018	.3018
24		.4961	.4961		.3018	.2641	.2641
Max	.4961	1.153	.9568	.7011	.8954	.8505	.4904
Min	.1886	.1509	.3898	.1886	.2263	.2263	.1509
Avg	.3157	.4249	.6005	.4560	.5137	.4727	.3415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 307 / VIKHALE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5959	.631		.2263	.2641	.2241
2		.5959	.5959			.2641	.2263
3		.5959	.5959			.2641	.2286
4		.6241	.5959			.2641	.2286
5		.6859	.631			.3018	.2641
6		.7545	.8063			.3395	.3395
7		1.0631	.9465		.415	.415	.3772
8		.9259	1.0517		.3395	.3772	.3772
9	.2263	.1509	.9114		1.0631	1.0387	.2641
10	.3018	.1886	.815		.9922	1.0402	.3018
11	.3395	.1886	.6935		.7602	.9568	
12	.3018	.1886	.7316		.8764	.7628	
13	.2263	.1886	.6516	.7087	.8916	.7362	
14	.2641	.1886			.7712	.7602	.2641
15	.1886	.2263		.788	.7975	.6935	.2641
16	.2263	.2263		.788	.823	1.1317	
17	.2263	.2641		.2641	.1886	.1867	.2641
18	.1886	.3018		.3018	.2641	.2263	.3018
19	.2641	.2263		.3395	.3395	.3772	.3395
20	.3018	.3018		.3395	.3395	.3361	.3395
21	.2641	.3395			.3395	.3018	.3395
22	.2263	.3018			.3395	.3018	.3395
23	.6661	.7522			.2641	.2641	.3395
24		.6024	.7011		.2263	.2641	.2263
Max	.6661	1.0631	1.0517	.788	1.0631	1.1317	.3772
Min	.1886	.1509	.5959	.2641	.1886	.1867	.2241
Avg	.2808	.4366	.7399	.5042	.5398	.4945	.2925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 301 / MAHABALESHWAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.105	1.1431	.6036	1.105	1.0669	.9907
2	1.0288	1.0288	1.0669	.8676	1.0288	.9907	.9145
3	.9526	.9907	.9526	.8299	.9526	.8383	.8383
4	.9526	1.0288	.9907	.8299	.9907	.8383	.8764
5	1.0669	1.0669	1.0669	.9054	1.0669	.9145	.9526
6	1.3336	1.2193	1.1431	1.1317	1.2193	1.1431	1.2955
7	1.5623	1.6004	1.6385	1.5089	1.6385	1.5242	1.5242
8	1.7528	1.7528	1.7147	1.7528	1.6385	1.5242	1.7147
9	1.7528	1.7147	1.7528		1.6385	1.7528	1.7147
10	1.7147	1.7147	1.6766		1.6385	1.5242	1.6385
11	1.6004	1.5242	1.6004		1.5242	1.3336	1.448
12	1.5242	1.5242	1.2193		1.7528	1.2193	1.4098
13	1.5242	1.448	1.3336		1.448	1.1431	1.4098
14	1.3336	1.3717	1.1812		1.2955	1.2955	1.3336
15	1.829	1.448	1.3336		1.3336	1.3336	1.4098
16	1.4098	1.4098	1.2955		1.3336	1.4098	1.2574
17	1.3717	1.5242	.9526	1.4861	1.3336	.8383	1.2955
18	1.5242	1.4861	1.4098	1.9052	1.5242	1.4861	1.2955
19	1.9052	1.829	1.6766	2.0957	1.7528	1.7909	1.9052
20	1.9814	2.0576	2.0576	2.0957	1.9433	1.9433	2.1719
21	1.9052	2.0195	1.8671	2.0195	1.9052	1.9052	1.9433
22	1.7909	1.7909	1.6004	1.7528	1.7147	1.6766	1.8671
23		1.5242	1.1812	1.4098	1.448	1.4861	1.5623
24	1.2955	1.2193	1.2955	1.1317	1.1431	1.1431	1.1431
Max	1.9814	2.0576	2.0576	2.0957	1.9433	1.9433	2.1719
Min	.9526	.9907	.9526	.6036	.9526	.8383	.8383
Avg	1.4894	1.4750	1.3813	1.3954	1.4321	1.3384	1.4130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 302 / Moleshwar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0762	.0762	.0754	.0762	.0762	.0762
2	.0754	.0762	.0762	.0754	.0762	.0762	.0762
3	.0754	.0762	.0762	.0754	.0762	.0762	.0762
4	.0754	.0762	.0762	.0754	.0762	.0762	.0762
5	.0754	.0762	.0762	.0754	.0762	.0762	.0762
6	.1676	.1524	.1143	.0754	.1143	.0762	.1143
7	.6001	.5868	.6249	.5944	.6401	.5182	.602
8	.7239	.7316	.6173	.6234	.7316	.5411	.6706
9	.7163	.6935	.5563	.4115	.602	.5182	.602
10	.6477	.4725	.4267		.5563	.0914	.4953
11	.4877	.2896	.1219		.4725	.5334	.1524
12	.3353	.1981	.0762		.1372	.4344	.1829
13	.1524	.2743	.1676		.0762	.0762	.1219
14	.1067	.5106	.0762		.0762	.0762	.0762
15	.0762	.3505	.0762		.0762	.0762	.1219
16	.0762	.1067	.0762		.0762	.0762	.0914
17	.0762	.3201	.0914	.0762	.0914	.0762	.0762
18	.503	.2896	.1981	.0762	.4953	.2134	.3124
19	.7163	.6173	.5563	.8611	.6173	.3734	.6401
20	.8383	.7697	.6835	1.0135	.8002	.7773	.7544
21	.7621	.7011	2.2599	.7468	.7316	.7316	.7392
22	.6325	.6325	.5696	.6477	.6325	.6477	.6477
23	.3353	.4039	.3505	.4572	.4115	.4801	.4268
24	.1211	.0762	.0762	.0754	.0762	.0762	.1067
Max	.8383	.7697	2.2599	1.0135	.8002	.7773	.7544
Min	.0754	.0762	.0762	.0754	.0762	.0762	.0762
Avg	.3522	.3566	.3375	.3550	.3248	.2823	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 303 / Metgutad

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.9145	.9526	.7621	.8002	.7621	.6859
2	.7621	.8383	.8383	.6859	.7621	.7621	.6478
3	.6859	.7621	.7621	.6859	.724	.6859	.6478
4	.6859	.7621	.7621	.6859	.724	.6859	.6859
5	.7621	.8002	.8002	.7621	.7621	.724	.7621
6	.9526	1.1431	.8764	.8383	.8764	.7621	.9526
7	1.2574	1.2574	1.2193	1.2574	1.2193	1.1431	1.1431
8	1.3336	1.4861	1.3336	1.3336	1.2574	1.2574	1.2955
9	1.3336	1.3336	1.3336		1.3717	1.3336	1.2955
10	1.2955	1.3336	1.1431		1.1812	1.1431	1.2193
11	1.1431	.9907	.9526		1.1431	.8764	.9145
12	.8383	.9526	.9526		.9526	.7621	.8383
13	.9526	.9526	.8764		.7621	.7621	.8002
14	.8383	.8383	.7621		.8764	.8002	.8764
15	1.0669	.9526	.8383		.9145	.8764	.9526
16	1.0669	.9526	.8383		.9526	.9145	.9526
17	.9907	.9145	.8764	.8002	.8764	.8383	.8383
18	1.1431	.9526	.9526	.9526	.9907	.9526	.8764
19	1.1431	1.1431	1.0669	1.2193	1.1431	.9526	1.0288
20	1.1431	1.1431	1.448	1.1431	.9907	1.0669	.7621
21	1.2193	1.0288	.9431	1.0669	1.0288	.9526	.724
22	1.1431	.9526	1.1317	.9526	.9145	.9526	.7621
23		.8002	.6413	.8002	.7621	.7621	.7621
24	.9526	.9526	.9145	.7922	.8764	.8383	.7621
Max	1.3336	1.4861	1.448	1.3336	1.3717	1.3336	1.2955
Min	.6859	.7621	.6413	.6859	.724	.6859	.6478
Avg	1.0235	1.0066	.9673	.9211	.9526	.8986	.8828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 304 / Venna Lake

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6859	.6478	.5716	.7621	.6859	.4572
2	.6859	.6097	.5716	.4954	.6097	.6097	.5716
3	.6097	.6097	.5716	.4572	.5716	.6097	.6097
4	.6097	.6859	.6097	.4954	.6097	.6097	.5716
5	.6859	.724	.6478	.5335	.6097	.6478	.5716
6	.7621	.8002	.724	.5716	.6478	.7621	.7621
7	.9526	.8764	.8764	.7621	.7621	.8383	.9145
8	1.0669	1.0669	.9526	.8002	.8764	.9526	1.105
9	1.105	.9526	.9526		.9907	.9907	1.0669
10	1.105	1.1431	.9526		1.105	1.1431	1.1431
11	1.1431	1.105	.9526		1.0669	1.0669	1.1431
12	1.2193	1.0669	.8383		1.105	.9526	1.1431
13	1.2193	.9526	.9526		.9526	.9526	1.1431
14	1.2955	.9526	.9526		.9526	.9907	1.105
15	1.5623	1.105	1.0669		1.0669	.9907	1.2193
16	1.1431	.9907	.8383		1.3336	.8764	1.105
17	1.0669	.9907	.9907	1.1812	.8764	.8383	.9526
18	.9526	.9907	.9907	1.2193	.9145	.9526	1.0288
19	1.2193	1.2574	1.2955	1.6004	.9145	1.2574	1.448
20	1.5242	1.8671	1.7909	1.5242	1.448	1.3336	1.4861
21	1.5242	1.3717	1.2449	1.448	1.2193	1.0288	1.448
22	1.3336	1.1812	1.2574	1.3336	1.105	.8383	1.2193
23		.9526	.7545	1.0288	.8383	.724	.9526
24	.9145	.7621	.724	.6859	.7621	.7621	.6859
Max	1.5623	1.8671	1.7909	1.6004	1.448	1.3336	1.4861
Min	.6097	.6097	.5716	.4572	.5716	.6097	.4572
Avg	1.0636	.9875	.9232	.9193	.9209	.8923	.9939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 305 / Bramha Corp Hotels &
Resorts Feeder KV- 22 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.381	.3429	.381	.3429	.381	.381
2	.3772	.381	.3429	.3429	.3048	.3048	.3429
3	.381	.381	.3048	.3048	.3048	.3048	.3429
4	.4191	.381	.3048	.3048	.3048	.3429	.3429
5	.381	.381	.3048	.3048	.3429	.3429	.3429
6	.4191	.381	.3429	.3048	.3429	.3429	.3429
7	.381	.4191	.3429	.3048	.3048	.3429	.4191
8	.4572	.381	.381	.4191	.381	.4191	.4572
9	.4954	.5335	.4572		.4572	.4954	.5335
10	.4954	.4954	.4191		.4954	.4954	.4954
11	.4954	.4954	.4191		.4572	.4191	.4954
12	.4572	.4572	.381		.4191	.4954	.4191
13	.4191	.4191	.415		.4572	.4191	.4191
14	.381	.4191	.415		.4572	.4572	.4954
15	.4572		.381		.4572	.4572	.4954
16	.4954		.415		.4191	.4954	.4572
17	.4954	.4572	.4191	.381	.4191	.3429	.4572
18	.4572	.4572	.3772	.381	.381	.4572	.5335
19	.4954	.5335	.5281	.4572	.4954	.4572	.5335
20	.5335	.4954	.4527	.4954	.5335	.4572	.5335
21	.4572	.4191	.415	.4191	.4572	.4191	.4572
22	.4191	.4572	.3772	.381	.4572	.4191	.4572
23		.3429	.415	.4191	.4191	.4191	.4191
24	.3772	.381	.3429	.381	.381	.381	.4191
Max	.5335	.5335	.5281	.4954	.5335	.4954	.5335
Min	.3772	.3429	.3048	.3048	.3048	.3048	.3429
Avg	.4418	.4295	.3874	.3739	.408	.4112	.4414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 303 / TAPOLA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0754	.0754	.0754	.0754	.0754	.0754
2	.0762	.0754	.0377	.0754	.0747	.0754	.0754
3	.0762	.0747	.0377	.0754	.0754	.0762	.0377
4	.0762	.0747	.0377	.0747	.0754	.0762	.0377
5	.0762	.0754	.0373	.0747	.0762	.0754	.0747
6	.1132	.0739	.0747	.1109	.1143	.112	.1109
7	.112	.0739	.1478	.1109	.112	.1109	.1109
8	.0754	.0747	.1478	.1109	.1132	.1494	.1109
9	.112	.1109	.1478	.1097	.112	.1097	.0732
10	.1494	.1109	.1494	.112		.1097	.1494
11	.1109	.1109	.1478	.1509	.112	.1097	.1132
12	.112	.0739	.0747		.1109	.0732	.112
13	.1109	.0739	.0739	.1143	.112	.0732	.1132
14	.112	.0739	.0747	.112	.0739	.0732	.0754
15	.1109	.0739	.1109	.1109	.0754	.0732	.0747
16	.1109	.0366	.1097	.0747	.0754	.1097	.1143
17	.1132	.037	.1463	.1132	.112	.1097	.1143
18	.1132	.037	.1109	.1509	.112	.1463	.1143
19	.2241	.1848	.1478	.2241	.1848	.1848	.2286
20	.2241	.2241	.2218	.2641	.2241	.2218	.2614
21	.1509	.1867	.1494	.2263	.2263	.1848	.2263
22	.1494	.1494	.1494	.1524	.1509	.1494	.1905
23	.1132	.0754	.112	.1143	.112	.112	.1524
24	.0754	.0754	.1132	.0754	.0762		.0754
Max	.2241	.2241	.2218	.2641	.2263	.2218	.2614
Min	.0754	.0366	.0373	.0747	.0739	.0732	.0377
Avg	.1162	.0930	.1098	.1223	.1125	.1127	.1176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 304 / KELGHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8684	.8931	.7576	.8169	.7553	.9419	.889
2	.8139	.8505	.714	.7518	.6687	.884	.7902
3	.7834	.7895	.6988	.6988	.6573	.8535	.7598
4	.7728	.7118	.6835	.6835	.6401	.8353	.7445
5	.7796	.7682	.7186	.7712	.6744	.8169	.8322
6	.9727	.9526	.9305	1.0135	1.0699	1.0173	1.1187
7	1.2925	1.3778	1.2906	1.2818	1.3397	1.3016	1.3059
8	1.3854	1.5485	1.419	1.4814	1.4967	1.5692	1.395
9	1.3458	1.4388	1.384	1.3717	1.4525	1.5692	1.3565
10	1.2864	1.1622	1.0303	.8269	.9145	1.3756	1.1926
11	1.1926	1.1926	.9358	.6721	1.2864	1.0997	1.2822
12	1.0578	1.1812	1.044	.442	1.246	1.0029	1.1302
13	.9998	1.0974	1.044	.6721	1.1355	.9724	1.02
14	1.0182	.9937	1.049	.7384	1.1202	1.0083	1.0913
15	1.1164	1.0517	.9663	.7049	1.1317	1.0388	1.1164
16	1.3016	1.2163	1.0364	.6874	.8078	1.1355	1.0913
17	1.3626	1.2559	1.1279	.8326		1.2528	1.1469
18	1.5844	1.323	1.3961	.9541	1.1371	1.4616	1.267
19	1.8168	1.7589	1.6309	1.006	2.0897	1.7376	1.4918
20	2.0828	2.0218	2.0149	1.6552	2.2268	2.0606	1.9086
21	1.954	1.8961	1.8957	2.0607	2.2557	1.8652	1.8808
22	1.7169	1.5779	1.5561	1.7368	1.7879	1.659	2.0389
23	1.3679	1.1427	1.2506	1.3413	1.4586	1.3184	1.4125
24	1.0334	.9572	.932	.9846	1.0844	1.0639	1.1287
Max	2.0828	2.0218	2.0149	2.0607	2.2557	2.0606	2.0389
Min	.7728	.7118	.6835	.442	.6401	.8169	.7445
Avg	1.2461	1.2150	1.1461	1.0077	1.2364	1.2434	1.2246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 305 / NIZARE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2987	.2218	.2987	.1867	.3018	.2614
2	.2218	.2957	.2241	.3018	.1867	.2987	.2195
3	.1867	.2614	.2263	.2641	.1848	.3018	.2263
4	.1886	.2614	.2241	.2614	.1848	.2987	.2263
5	.2263	.3018	.2241	.2987	.2218	.2957	.2987
6	.2614	.3395	.2987	.3326	.2561	.3734	.4108
7	.3696	.4108	.4066	.4066	.3326	.4481	.4805
8	.4024	.439	.5121	.5175	.3658	.5121	.5121
9	.4344	.3658	.5121	.5121	.439	.5914	.4755
10	.5175	.5121	.5228	.5544		.5487	.5175
11	.5544	.5544	.4207	.5175	.4108	.5487	.5228
12	.5228	.5175	.4854		.4854	.4024	.439
13	.4805	.4435	.4435	.3361	.4805	.4755	.4435
14	.5228	.4755	.4108	.4024	.4527	.4755	.4108
15	.5228	.5487	.3658	.4066	.4481	.5121	.4435
16	.5175	.5544	.4108	.2587	.4904	.5487	.4854
17	.5544	.5487	.4066	.4066	.5914	.5853	.4805
18	.6348	.5853	.439	.4066	.6348	.5853	.4435
19	.7095	.6219	.5121	.5121	.679	.5853	.4755
20	.7392	.5487	.5487	.4435	.6348	.5853	.5175
21	.5228	.5175	.4805	.4755	.5658	.5487	.4527
22	.4481	.4435	.4066	.3734	.4854	.4435	.415
23	.3772	.2957	.3696	.2641	.415	.3361	.2987
24	.2614	.3395	.2587	.3361	.2286	.3395	.2587
Max	.7392	.6219	.5487	.5544	.679	.5914	.5228
Min	.1867	.2614	.2218	.2587	.1848	.2957	.2195
Avg	.4333	.4367	.3888	.3864	.407	.4559	.4048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 306 / BHANANG

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2987	.3018	.3395	.2587	.3395	.0754
2	.2587	.3018	.2641	.3018	.2241	.3018	.2641
3	.2241	.2614	.2641	.2641	.2218	.3018	.2263
4	.2641	.2641	.2641	.2641	.2218	.2987	.2263
5	.2641	.3395	.2614	.3361	.2195	.2987	.3018
6	.2587	.4108	.3326	.4066	.2172	.3696	.4108
7	.2926	.4024	.4066	.5544	.3696	.439	.4805
8	.3982	.4481	.5121	.5487	.439	.6584	.5121
9	.4298	.4435	.4755	.6219	.5068	.6219	.4755
10	.5014		.5914	.6283		.5853	.4805
11	.4805	.4805	.5975	.6219	.5914	.4755	.5175
12	.4854	.4805	.6584		.6653	.4755	.4344
13	.4805	.4435	.5853	.5544	.6036	.3292	.4024
14	.5228	.2587	.5658	.4706	.5281	.3658	.4066
15	.4854	.4435	.5975	.5487	.4854	.439	.439
16	.5175	.4805	.5914	.4435	.5914	.5121	.4854
17	.5601	.5853	.6219	.5487	.6722	.5853	.5175
18	.6283	.6219	.5487	.5914	.679	.5853	.5121
19	.6722	.5853	.5853	.5068		.6219	.5792
20	.7468	.6653	.6653	.5914	.6584	.5853	.6653
21	.5658	.6283	.6283	.5487	.5853	.5487	.5975
22	.4481	.5601	.5544	.5175	.5175	.4435	.5281
23	.3772	.4481	.4854	.4108	.3734	.3696	.3696
24	.2987	.3018	.3361	.4481	.3395	.3395	.2987
Max	.7468	.6653	.6653	.6283	.679	.6584	.6653
Min	.2241	.2587	.2614	.2641	.2172	.2987	.0754
Avg	.4340	.4415	.4873	.4812	.4531	.4538	.4253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254050 / TAPOLA

Feeder No / Name : 301 / GOGAVE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1029	.0724	.0762	.0724	.1067	.0876
2	.0876	.0991	.0686	.0686	.061	.1029	.0724
3	.08	.0953	.0648	.061	.0686	.08	.0648
4	.08	.0838	.0648	.0724	.0762	.0838	.0648
5	.08	.0914	.0686	.0762	.0876	.1105	.08
6	.0876	.0991	.0914	.0762	.1105	.1181	.0914
7	.141	.1181	.1486	.1067	.1334	.1334	.0953
8	.1753	.1296	.1753	.1448	.1524	.1753	.141
9	.1334	.1486	.1524	.1486	.141	.16	
10	.1867	.1029	.1486	.1524	.1067	.1524	.1524
11	.141	.1257	.1562	.1296		.141	.141
12	.1372	.1181	.1524	.1448	.0991	.1562	.141
13	.1029	.1181	.0914	.1334	.1029	.0876	.0991
14	.08	.1067	.1105	.1029	.1219	.0953	.0953
15	.1181	.0991	.1181	.1181	.1029	.1105	.1219
16	.1105	.1105		.1562	.1219	.1067	.141
17	.1562	.1486	.0381	.1562	.1372	.1486	.1753
18	.16	.1486	.1143	.16	.16	.1829	.1638
19	.1715	.1715	.202	.1867	.2096	.1867	.1943
20	.1829	.2058	.2324	.1981	.2172	.1981	.1943
21	.1829	.1486	.1753	.1791	.2134	.1791	.1867
22	.16	.1257	.1562	.1372	.1562	.1562	.1638
23	.1448	.0914	.1143	.1029	.141	.1181	.1257
24		.0914	.0762	.08	.08	.1105	.1029
Max	.1867	.2058	.2324	.1981	.2172	.1981	.1943
Min	.08	.0838	.0381	.061	.061	.08	.0648
Avg	.1300	.1200	.1214	.1237	.1249	.1334	.1259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254050 / TAPOLA

Feeder No / Name : 302 / SHINDI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.1105	.0762	.0381	.0876	.1029	.0914
2	.0686	.1067	.0724	.0381	.0762	.0991	.0876
3	.0495	.1029	.0648	.0381	.0724	.0838	.0724
4	.08	.0876	.061	.0381	.0724	.0914	.0686
5	.08	.1181	.0648	.0381	.0876	.1029	.0914
6	.08	.1219	.08	.0381	.1181	.1067	.141
7	.1334	.1372	.1334	.0381	.1486	.16	.1638
8	.1448	.1334	.1524	.0381	.2096	.1715	.1753
9	.1296	.1067		.1257	.1753	.1486	.1753
10	.1524	.1219	.0914	.141	.1143	.1486	
11	.1448	.1105	.141	.1296		.1029	.16
12	.1105	.1067	.1486	.141	.1029	.1181	.2134
13	.1334	.0838	.141	.1448	.1067	.1334	.1105
14	.1029	.1067	.141	.1029	.1181	.1296	.1372
15	.0914	.1181	.221	.1029	.141	.1372	.1067
16	.0876	.1181	.1677	.1029	.1219	.1638	.1296
17	.1296	.16	.16	.1181	.141	.1638	.16
18	.1448	.1867	.1181	.16	.1448	.1829	.1562
19	.2248	.2401	.2096	.2553	.2172	.2401	.2591
20	.2858	.1943	.3353	.301	.2286	.3277	.3696
21	.2553	.2058	.2782	.2172	.2248	.2896	.2934
22	.2324	.1867	.2058	.1791	.1753	.1562	.221
23	.202	.1181	.0876	.1219	.1562		.1791
24	.0914	.1067	.0876	.0572	.0991	.1067	.1372
Max	.2858	.2401	.3353	.301	.2286	.3277	.3696
Min	.0495	.0838	.061	.0381	.0724	.0838	.0686
Avg	.1350	.1329	.1408	.1127	.1365	.1508	.1609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 301 / ANEWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4191	.4298	.381	.3658	.4298	.4298
2	.3658	.4191	.394	.381	.3658	.394	.394
3	.3658	.4191	.394	.3429	.3658	.394	.394
4	.3658	.4191	.394	.381	.439	.394	.394
5	.4024	.4572	.3582	.4191	.4755	.394	.4298
6	.439	.4954	.4656	.4954	.5121	.5373	.5373
7	.5121	.6478	.5373	.6097	.5487	.5731	.5373
8	.5121	.6097	.5731	.5335	.5487	.5014	.5373
9	.439	.5335	.5014	.5716	.5487	.4656	.4298
10	.4024	.4298	.5014	.4298	.4656	.394	.4298
11	.4572	.4656		.4298	.4656	.5335	.4298
12	.5335	.394	.3582	.4298	.4656	.4572	.4298
13		.4656	.4298	.4298	.4298	.4954	.4298
14	.4572	.4656	.3582	.394	.394	.4572	.4656
15	.4954	.4298	.4298	.4298	.394	.4572	.4298
16	.4954	.4298	.381	.4066	.4298	.4954	.4656
17	.6097	.5373	.4572	.4435	.4656	.4954	.4298
18	.5716	.5373	.4572	.439	.5014	.5716	.4298
19	.6859	.6447	.7621	.5853	.6447	.6859	.6447
20	.8383	.788	.8764	.439	.7522	.8764	.7522
21	.8002	.7164	.8002	.7316	.7522	.8383	.7164
22	.6478	.6447	.6859	.6219	.6805	.7621	.6805
23	.5716	.5014	.5716	.5121	.5373	.6097	.5373
24	.3658	.4572	.4298	.4572	.439	.4656	.4656
Max	.8383	.788	.8764	.7316	.7522	.8764	.7522
Min	.3658	.394	.3582	.3429	.3658	.394	.394
Avg	.5087	.5136	.5020	.4706	.4995	.5283	.4925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 302 / ANEWADI AGRICULTURE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.6461	1.4327	1.3717	1.4586	.1791	.1791
2	.1829	1.5432	1.4327	1.3375	1.4586	.1791	.1433
3	.1715	1.5089	1.4327	1.2689	1.5249	.1791	.1433
4	.1715	1.5432	1.3969	1.2346	1.6095	.1791	.1791
5	.1715	1.6461	1.3969	1.3032	1.6575	.1791	.2149
6	.2058	1.6804	1.7551	1.5089	1.7368	.2507	.2507
7	.2427	1.6118	2.0058	1.749	1.8023	.2149	.2149
8	.2058	.2058	1.8983	1.6461	1.9662	.2149	.2149
9	.1715	.2058	.1791	.1715	2.1956	2.1849	1.7909
10	.2058	.1791	.1791	.1433	2.2207	2.2923	2.0774
11	.2058	.1791	.1791	.1791		2.2634	2.0774
12	.2058	.1791	.1433	.1433	2.1132	2.0576	1.7193
13		.1433	.1791	.1433	2.1849	1.8861	1.7909
14	.1715	.1433	.1433	.1791	2.0058	1.4403	1.8625
15	.1715	.1433	.1791	.1791	2.0058	1.7147	1.8983
16	.1715	.1791	.1715	.2058	2.0058	1.7833	1.8625
17	.2058	.1791	.1715	.2058	1.7909	.1372	.1433
18	.1715	.1791	.1715	.2058	.1791	.1715	.1791
19	.2058	.2149	.2058	.2058	.2149	.2401	.2149
20	.2743	.2865	.2743	.2401	.2507	.2743	.2507
21	.2743	.2507	.2401	.2401	.2507	.2743	.2507
22	.2401	.2149	.2401	.2058	.2149	.2401	.2149
23	1.6118	1.6476	1.3717	1.4419	.2149	.2058	.2149
24	.1715	1.6804	1.5043	1.3717	1.4419	.1791	.1791
Max	1.6118	1.6804	2.0058	1.749	2.2207	2.2923	2.0774
Min	.1715	.1433	.1433	.1433	.1791	.1372	.1433
Avg	.2601	.7246	.7618	.7034	1.4132	.7884	.7611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 303 / Kudal Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	.9907	.8954	.9526	.8779	.8596	.8596
2	1.0242	.9145	.8954	.9145	.8779	.8238	.8954
3	.9511	.9145	.8596	.8764	.9511	.8596	.8954
4	1.0974	.8764	.8596	.9145	1.0608	.8238	.9313
5	1.1706	.9907	.8954	1.0288	1.1706	.6447	.9671
6	1.2437	1.2955	1.182	1.1431	1.2437	.8238	1.1462
7	1.4266	1.4861	1.3969	1.3717	1.3535	1.2536	1.2894
8	1.5729	1.5242	1.4327	1.448	1.4998	1.3253	1.3253
9	1.4998	1.3336	1.4685	1.5623	1.4998	1.3969	1.3969
10	1.4632	1.2178	1.3969	1.3253	1.2894		1.2178
11	1.448	1.2536	1.2536	1.2536		1.3717	1.2178
12	1.2955	1.1462	1.0745	1.1462	1.3253	1.4098	1.0387
13	1.1812	1.1104	1.182	1.0387	1.2178	1.3336	1.0745
14	1.1431	1.2536	1.1462	1.1462	1.182	1.1431	1.1104
15	1.1431	1.1462	1.2536	1.0745	1.2178	1.2574	1.1462
16	1.2574	1.2536	1.5242	1.0608	1.182	1.3717	1.1104
17	1.5242	1.2894	1.5242	1.134	1.3969	1.5242	1.2178
18	1.4861	1.2894	1.448	1.2071	1.4327	1.3717	1.2178
19	1.7147	1.4327	1.4861	1.39	1.4327	1.5623	1.5043
20	1.9052	1.6118	1.6766	1.5729	1.6476	1.8671	1.6834
21	1.7147	1.5402	1.5242	1.4998	1.5043	1.6385	1.5043
22	1.448	1.3969	1.4098	1.3169	1.3611	1.3717	1.3969
23	1.2955	1.182	1.2955	1.0974	1.1104	1.1812	1.182
24	1.0974	1.105	.9313	1.0669	.9511	.9671	.9313
Max	1.9052	1.6118	1.6766	1.5729	1.6476	1.8671	1.6834
Min	.9511	.8764	.8596	.8764	.8779	.6447	.8596
Avg	1.3417	1.2315	1.2505	1.1893	1.2516	1.2253	1.1775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 304 / KUDAL AGRICULTURE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7101	.1715	.1433	.1372	.1715	1.8625	2.1132
2	1.6766	.1372	.1433	.1372	.1715	1.8267	2.0774
3	1.7436	.1372	.1433	.1372	.1372	1.8625	2.0416
4	1.7901	.1372	.1433	.1372	.1372	1.8267	2.0416
5	1.7901	.1715	.1433	.1372	.1715	1.8267	2.0416
6	2.0485	.2058	.1433	.1372	.1715	2.2207	2.4714
7	1.9448	.2058	.1791	.2058	.1715	2.5072	2.6863
8	1.9662	.2058	.1433	.1372	.1715	2.4356	2.6505
9	1.4754	2.332	1.6118	2.0576	.1715	.1433	.1075
10	2.2131		3.0803	2.6505	.1075	.1433	.1075
11	2.2634	2.6505	2.9371	2.8654		.1715	.1075
12	2.332	2.7938	2.364	2.7221	.1433	.1372	.1433
13	2.2634	2.7221	2.5072	2.6505	.1075	.0686	.1433
14	2.1605	2.6505	2.2923	2.3594	.1433		.1433
15	2.0233	2.4356	2.2923	2.2939	.1433	.1029	.1433
16	2.1262	1.9342	.1029	1.7238	.1433	.1905	.1791
17	.1372	1.576	.1029	.2058	.1433	.1715	.1433
18	.1715	.0716	.1372	.1715		.1715	.1433
19	.1715	.1791	.1715	.1715	.1791	.1715	.1791
20	.2401	.2149	.1715	.2058	.2149	.2058	.2149
21	.2401	.1791	.1715	.2058	.2149	.2058	.1791
22	.2058	.1791	.1715	.2058	.1433	.2058	.1791
23	.2058	.1791	.1715	.1715	.1075	.1715	.1433
24	1.7436	.1715	.1433	.1372	.1715	.1075	.1433
Max	2.332	2.7938	3.0803	2.8654	.2149	2.5072	2.6863
Min	.1372	.0716	.1029	.1372	.1075	.0686	.1075
Avg	1.4435	.9409	.8171	.9152	.1563	.8146	.8552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 305 / KARHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4191	.394	.4191	.439	.394	.4656
2	.3658	.381	.394	.4191	.3658	.394	.4298
3	.3658	.381	.394	.381	.3658	.4298	.4298
4	.439	.4191	.394	.3429	.439	.4298	.4298
5	.5121	.4572	.394	.4191	.5121	.4298	.4298
6	.5853	.4572	.5014	.5335	.5853	.5373	.5014
7	.6584	.6859	.6447	.6097	.6584	.6805	.6447
8	.7316	.6859	.6805	.6478	.7316	.788	.7522
9	.7316	.7621	.8596	.6859	.7316	.7164	.8238
10	.7682	.7522	.6805	.6447	.8238	.7522	.8596
11	.8764	.7164		.6805		.8383	.7522
12	.8383	.6805			.7164	.7621	.6805
13	.724	.6447	.6089		.6447	.5335	.6089
14	.6859	.6805	.6805	.5373	.6447	.4954	.5731
15	.6859	.5731	.6447	.5373	.6089	.5335	.6447
16	.724	.6447	.724	.6584	.6089	.6859	.6447
17	.8383	.788	.8002	.695	.7522	.6859	.6805
18	.8764	.8954	.9907	.7682	.7164	.9145	.8238
19	1.0288	.9313	1.0669	.9511	1.0745	1.0669	.8238
20	1.105	1.0029	1.0669	1.0242	1.0029	1.1431	.8596
21	.9145	.8238	.9145	.9145	.8238	.9907	.7164
22	.1905	.6805	.8002	.695	.7164	.8383	.6089
23	.4572	.5014	.6097	.5487	.5373	.6478	.5014
24	.5121	.4572	.394	.4572	.439	.4656	.5014
Max	1.105	1.0029	1.0669	1.0242	1.0745	1.1431	.8596
Min	.1905	.381	.394	.3429	.3658	.394	.4298
Avg	.6689	.6425	.6654	.6168	.6495	.6731	.6328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 401 / 33 KV PACHGANI

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17
HR	Load (MW)
14	4.9726
Max	4.9726
Min	4.9726
Avg	4.9726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / PACHGANI

Feeder No / Name : 301 / BHILAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7392	.695	.7468	.7316	.7392	.7164
2	.7167	.7316	.6653	.6653	.6584	.7167	.6722
3	.7095	.7316	.6722	.6653	.6584	.679	.6722
4	.7095	.7468	.6722	.6584	.6516	.6722	.6653
5	.7602	.7682	.6722	.724	.724	.7023	.8215
6	1.0029	.961	.9145	.8954	.9412	.9774	.8131
7	1.3611	1.4327	1.2803	1.2403	1.2757	1.3611	1.2757
8	1.5238	1.6301	1.5364	1.4685	1.6651	1.5043	1.3672
9	1.4842	1.5775	1.4022		1.5729	1.4118	1.382
10	.6516	1.5043	1.387		1.3676	1.2483	1.1218
11	.6859	1.4632	1.0288		1.0829	1.0852	1.0631
12	1.0867	1.3306			.9979	1.0974	.9465
13	.9602	.9335	.9602		.9877	1.0402	.9602
14	.8573	.961	.8669		1.0136	.9835	.9465
15	1.134	1.0136	.9259		1.0242	.9362	.9412
16	1.1096	1.1706			1.086	1.0985	1.0745
17	1.4998	1.3032	1.1317		1.2803	1.2136	1.0867
18	1.3321	1.4632	1.2894		1.4784	1.3032	1.1568
19	1.6834	1.5729	1.448	2.3743	1.4998	1.5074	1.5238
20	1.5565	1.4883	1.4632	1.8427	1.4842	1.448	1.4118
21	1.4632	1.3169	1.3676	1.5203	1.39	1.3535	1.2536
22	1.0974	1.0608	1.134	1.3032	1.134	1.1584	1.1462
23	.9979	.9511	.961	.9412	.961	.9313	.9671
24	.8131	.8501	.7316	.7762	.7964	.7762	.8063
Max	1.6834	1.6301	1.5364	2.3743	1.6651	1.5074	1.5238
Min	.6516	.7316	.6653	.6584	.6516	.6722	.6653
Avg	1.0813	1.1543	1.0548	1.1301	1.1026	1.0810	1.0330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / PACHGANI

Feeder No / Name : 302 / PACHGANI CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.1706	1.0242	1.0829	1.0242	1.0456	1.0166
2	1.094	1.1458	.9511	.9979	.924	.961	1.0082
3	1.094	1.0349	.924	.9145	.924	.9335	.9877
4	1.0719	1.0349	.8962	.905	.924	.9335	.9877
5	1.0974	1.0974	.8962	.9877	.9979	1.0242	.961
6	1.1946	1.1203	1.0719	1.086	1.0829	1.1584	.9709
7	1.3394	1.39	1.2894	1.3032	1.3443	1.3394	1.307
8	1.4685	1.4937	1.2971	1.5203	1.4937	1.4842	1.531
9	1.5043	1.5524	1.4998		1.5154	1.4266	1.5893
10	1.4175	1.448	1.4415		1.531	1.4784	1.4784
11	1.5043	1.4118	1.3756		1.4937	1.4118	1.382
12	1.4266	1.39	1.3756		1.3169	1.4118	1.3756
13	1.39	1.3306	1.2403		1.3032	1.3253	1.2269
14	1.2403	1.3032	1.1222		1.2536	1.2178	1.2178
15	1.382	1.2536	1.1946		1.2536	1.2178	1.1706
16	1.4632	1.3253			1.2308	1.2308	1.2308
17	1.4632	1.2894	1.2536	1.4883	1.2308	1.39	1.2536
18	1.3756	1.2803	1.2403	1.406	1.2071	1.3032	1.2894
19	1.5364	1.39	1.4685	1.7193	1.448	1.4118	1.4632
20	1.7375	1.6095	1.6118	1.7737	1.6476	1.4998	1.7002
21	1.6651	1.5043	1.5729	1.7002	1.6289	1.5565	1.5203
22	1.5565	1.4632	1.4784	1.4784	1.5364	1.4118	1.4842
23	1.4266	1.2437	1.2803	1.2437	1.2803	1.3394	1.3611
24	1.2437	1.3169	1.1088	1.1222	1.0745	1.1088	1.0745
Max	1.7375	1.6095	1.6118	1.7737	1.6476	1.5565	1.7002
Min	1.0719	1.0349	.8962	.905	.924	.9335	.961
Avg	1.3693	1.3167	1.2441	1.2956	1.2778	1.2759	1.2745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / PACHGANI

Feeder No / Name : 303 / WATER SUPPLY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1478	.1478	.112	.1097	.1494	.1075
2	.1509	.1494	.112	.1109	.1109	.1109	.1132
3	.1509	.1109	.112	.1097	.1109	.112	.1109
4	.1478	.1109	.112	.1086	.1109	.112	.1109
5	.1829	.1463	.1478	.1463	.1478	.1463	.1494
6	.2172	.2218	.2195	.2172	.2241	.2172	.1848
7	.2534	.3258	.3224	.2534	.2614	.2896	.2561
8	.3224	.362	.3544	.3258	.3361	.2896	.3258
9	.2507	.2481	.2926		.2587	.2926	.2896
10	.2149	.3258	.2835		.2241	.2149	.2218
11	.2149	.2896	.2804		.1867	.2103	.2172
12	.2195	.2561	.2427		.2195	.1791	.181
13	.181	.2218	.2427		.181	.1791	.1753
14	.1463	.2172	.2149		.1433	.1448	.1791
15	.1829	.2149	.1791		.1433	.1772	.1829
16	.2195	.2149			.2172	.2195	.1086
17	.2195	.2865	.1734	.2835	.2534	.2454	.1075
18	.3121	.3658	.2835	.3772	.2926	.3052	.1791
19	.2195	.4024	.2865	.439	.3258	.3155	.2926
20	.2896	.3658	.3582	.362	.3582	.2957	.3326
21	.2507	.3292	.3292	.3326	.3258	.2957	.2896
22	.2957	.2587	.2587	.2957	.2926	.2587	.2534
23	.2263	.2195	.2195	.2195	.2195	.2263	.1791
24	.1829	.1886	.1463	.1448	.1509	.1478	.1494
Max	.3224	.4024	.3582	.439	.3582	.3155	.3326
Min	.1463	.1109	.112	.1086	.1097	.1109	.1075
Avg	.2168	.2492	.2313	.2399	.2169	.2140	.1957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 301 / SURUR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0754	.0762	.6859	.679	.5658	.0381
2	.0762	.0754	.0381	.6859	.679	.4904	.0381
3	.0762	.0754	.0381	.6859	.6036	.4458	.0381
4	.0762	.0754	.0381	.6859	.6036	.4904	.0381
5	.0754	.0754	.0381	.7545	.6036	.5281	.0381
6	.1132	.0754	.0762	.8299	.679	.6036	.0381
7	.0754	.0754	.0762	.9808	1.3203	.9431	.0762
8	.0754	.0754	.0762	1.2826	1.094	1.0185	.0762
9	1.2071	1.2826	.0762	.0754	.0754	1.094	1.1812
10	1.1317	1.4335	.0754		.0754	1.2449	.5716
11	.9431	1.1431	.0754		.0377	1.105	.6413
12	1.2071	1.0288	.0754		.0377	.9907	.9054
13	1.094	.9145	.0754		.0754	.9907	.9808
14	.8676	.9907	.0754		.0754	.8764	1.0562
15	.9054	.9526	.0754		.0754	.9526	1.1317
16	.9431	1.105	.0754	.0754	.0754	.9907	1.1317
17	.0754	.0762	.0754	.0754	.0754	.0762	.0754
18	.0754	.0762	.0754	.0754	.0754	.0762	.0754
19	.0754	.0762	.0754	.0754	.0754	.0762	.0754
20	.0754	.1143	.0754	.0754	.0754	.0762	.1132
21	.0754	.1143	.0754		.0754	.0762	.1132
22	.0754	.1143			.0754	.0762	.0754
23	.0754	.0762	.8299		.0754	.0762	.0754
24	.0754	.0754	.0762	.7545	.679	.0754	.0762
Max	1.2071	1.4335	.8299	1.2826	1.3203	1.2449	1.1812
Min	.0754	.0754	.0381	.0754	.0377	.0754	.0381
Avg	.3978	.4240	.1019	.5199	.3332	.5808	.3609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 302 / NEW KENJAL AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5658	.4572	.0762	.0377	.0377	.0381
2	.6859	.5281	.4191	.0762	.0377	.0377	.0381
3	.6859	.5281	.3429	.0762	.0377	.0377	.0381
4	.6859	.5281	.3048	.0762	.0377	.0377	.0381
5	.7545	.5281	.3048	.0754	.0377	.0377	.0381
6	.7545	.5281	.3429	.0754	.0377	.0377	.0381
7	1.2071	.9431	.6478	.0754	.0377	.0377	.0381
8	1.1317	.9431	.8383	.0377	.0377	.0377	.0381
9	.0754	.0377	.8764	.9808	1.1317	1.358	.0381
10	.0377	.0754	.7545		1.1317	1.2071	.0381
11	.0377	.0381	.7545		1.094	1.0669	.0754
12	.0377	.0381	.7545		1.1317	.6859	.0754
13	.0754	.0381	.679		.9808	.7621	.0754
14	.0754	.0381	.679		.8299	.7621	.0754
15	.0754	.0381	.679		.8299	.7621	.0754
16	.0754	.0381	.7545		.9431	.9145	.0754
17	.0754	.0381	.0754		.6413	.0381	.0754
18	.0754	.0381	.0754		.0377	.0381	.0754
19	.0754	.0381	.0754		.0377	.0381	.0754
20	.0754	.0762	.0754		.0377	.0762	.0754
21	.0754	.0762	.0754		.0754	.0762	.0754
22	.0754	.0762			.0754	.0762	.0754
23	.679	.4572	.0754		.0754	.0381	.0754
24	.7545	.6036	.5335	.0754	.0377	.0754	.0381
Max	1.2071	.9431	.8764	.9808	1.1317	1.358	.0754
Min	.0377	.0377	.0754	.0377	.0377	.0377	.0381
Avg	.3736	.2849	.4598	.1625	.3914	.3449	.0583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 303 / NEW KENJAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3018	.2667	.1905	.2641	.3018	.3048
2	.3048	.3018	.2667	.1905	.2641	.2641	.3048
3	.3048	.3018	.2667	.1905	.2263	.2641	.3048
4	.3048	.3018	.2667	.1905	.2263	.2641	.3048
5	.3395	.3018	.3048	.2263	.2641	.2641	.3048
6	.3395	.3395	.3048	.2641	.3018	.3395	.381
7	.3395	.3772	.3429	.3018	.3395	.3772	.3429
8	.3018	.3395	.3048	.3395	.3018	.3395	.3048
9	.3772	.415	.4191	.2641	.2641	.415	.381
10	.3018	.415	.3772		.2641	.415	.3429
11	.2641	.2286	.3018		.3018	.3429	.3395
12	.3018	.3429	.2263		.415	.3429	.3395
13	.2641	.2667	.2263		.2641	.2667	.3018
14	.2641	.3429	.2263		.3395	.2667	.3018
15	.3395	.3048	.2263		.3395	.3048	.3395
16	.3395	.3429	.1509		.3772	.3429	.2641
17	.3018	.2286	.1509		.3772	.3429	.3395
18	.2641	.2667	.2263		.3018	.3048	.2641
19	.3772	.3429	.3018		.415	.4191	.3395
20	.4527	.4191	.415		.4904	.4572	.415
21	.415	.4191	.3772		.4527	.4191	.415
22	.3772	.381			.415	.381	.3772
23	.3395	.3048	.2641		.3395	.3429	.3395
24	.3018	.3018	.2667	.1886	.2641	.3018	.3048
Max	.4527	.4191	.4191	.3395	.4904	.4572	.415
Min	.2641	.2286	.1509	.1886	.2263	.2641	.2641
Avg	.3259	.3287	.2818	.2346	.3254	.3367	.3316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 304 / SURUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.8641	1.7909	1.829	2.0165	2.0927	2.0576
2	1.7909	1.7121	1.7528	1.6765	1.8641	1.8641	1.9052
3	1.7909	1.6739	1.6765	1.6765	1.7879	1.826	1.829
4	1.7146	1.6358	1.6765	1.6384	1.7879	1.7879	1.8671
5	1.7493	1.6739	1.6765	1.6735	1.7879	1.7879	1.9433
6	1.7875	1.7498	1.7528	1.7879	1.826	1.9018	2.0957
7	2.2059	2.1678	2.3243	1.9395	2.2062	2.2443	2.3243
8	2.5865	2.3956	2.7815	2.2059	2.4722	2.548	2.7054
9	2.5869	2.6246	2.6672	2.3586	2.6627	2.625	2.6291
10	2.5488	2.5488	2.3586	1.5623	2.7008	2.5107	2.5529
11	2.1681	2.3624	2.2824		2.7008	2.3624	2.3964
12	2.3202	2.3624	2.2824		2.6627	2.1719	2.4726
13	2.4729	2.3624	2.3964		2.5869	2.5148	2.3964
14	2.3205	2.4005	2.4345		2.5865	2.5148	2.4348
15	2.3202	2.4005	2.4348		2.5484	2.4767	2.3583
16	2.3205	2.4386	2.2824		2.6623	2.3624	2.4726
17	2.244	2.4005	2.2447	.6859	2.7008	2.4005	2.3202
18	2.3964	2.4767	2.1681	2.2481	2.6246	2.4386	2.3964
19	2.9279	2.8959	2.3575	2.7054	3.0426	2.8578	2.8905
20	3.5757	3.4675	3.3855	3.2388	3.842	3.7342	3.6138
21	3.4995	3.5056	3.3474	3.1626	3.7281	3.5818	3.5379
22	3.3859	3.3913	2.7816	2.934	3.5002	3.4675	3.3478
23	2.8537	2.8959	2.5488	2.7054	2.9676	3.0864	3.0057
24	2.2824	2.2828	2.21	2.5495	2.4733	2.5491	2.4767
Max	3.5757	3.5056	3.3855	3.2388	3.842	3.7342	3.6138
Min	1.7146	1.6358	1.6765	.6859	1.7879	1.7879	1.829
Avg	2.4064	2.4037	2.3173	2.1432	2.5725	2.4878	2.5012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 305 / OZARDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.415	.4191	.4191	.415	.415	.4572
2	.4572	.3772	.4191	.4191	.415	.415	.4572
3	.4572	.3772	.4191	.4191	.415	.415	.4191
4	.4572	.3772	.4191	.4572	.415	.415	.4572
5	.4904	.415	.4572	.4904	.4527	.4527	.4954
6	.5658	.5658	.5335	.5658	.5281	.6036	.6097
7	.7167	.6413	.724	.679	.7167	.7167	.6478
8	.5658	.4527	.6097	.6036	.6413	.6413	.6097
9	.4527	.5658	.5716	.5281	.5281	.6036	.5716
10	.5658	.4904	.4904		.5281	.5281	.4572
11	.4904	.5716	.4904		.5281	.5335	.4527
12	.4904	.4954	.4904		.5281	.4572	.4904
13	.4527	.4572	.4527		.4527	.3429	.4527
14	.4904	.4954	.4527		.4527	.3429	.415
15	.4527	.4572	.4904		.415	.4572	.415
16	.4904	.4954	.4904		.4527	.4954	.4527
17	.5281	.4954	.4904		.4527	.5335	.4904
18	.4904	.4572	.5658		.4904	.6097	.5281
19	.679	.6478	.679		.7167	.6859	.6413
20	.7922	.8383	.7922		.8299	.8002	.7545
21	.7545	.6859	.7167		.679	.724	.7167
22	.679	.6478			.6413	.6097	.6413
23	.5658	.5335	.5658		.5658	.5335	.5658
24	.4904	.4527	.4191	.4527	.4527	.4527	.4572
Max	.7922	.8383	.7922	.679	.8299	.8002	.7545
Min	.4527	.3772	.4191	.4191	.415	.3429	.415
Avg	.5430	.5170	.5286	.5034	.5297	.5327	.5273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 201 / 11 KV WAI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	2.8948	2.8829	3.9742	2.0272	2.5069	2.9698
2	2.886	2.8792	2.5705	3.7227	1.9098	2.4548	2.8571
3	2.7915	2.7652	2.4242	3.2267	1.9197	2.4076	2.6619
4	2.5979	2.6071	2.4227	3.0018	1.9319	2.4026	2.5942
5	2.5857	2.4063	2.5088	3.3768	1.8885	2.4301	2.6139
6	2.5316	2.4716	2.5941	3.3722	1.8138	2.1502	2.4607
7	2.6246	2.7073	2.6833	2.7572	1.1172	2.0397	2.6284
8	3.1931	3.1506	3.0423	2.5164	2.7656	2.6835	2.9432
9	4.0781	3.9567	3.5826	1.1561	4.0678	3.706	3.4339
10	4.2404	4.5389	3.9941		4.4197	4.0626	3.6595
11	4.579	4.7515	4.3941		2.3678	4.3286	3.8318
12	4.6616	4.7561	3.8584		5.6593	4.164	4.042
13	4.1448	5.0351	4.0527		4.414	3.805	3.876
14	3.9384	5.0747	4.2997		4.2322	4.0466	3.9811
15	4.7312	5.4367	4.9954		5.5758	4.475	4.3728
16	4.6007	5.5296	5.3452		4.4614	4.3035	4.2616
17	4.3179	4.6349	5.3742	1.4518	5.4467	3.9917	4.004
18	4.1753	3.9544	5.0031	1.6903	5.0729	3.9384	4.0071
19	3.8592	3.6359	4.9885	1.038	4.4597	3.6138	3.6519
20	3.7538	3.4073	4.6403	2.0485	3.7609	3.1832	3.6283
21	3.035	3.0003	3.6717	1.2986	3.0665	3.0262	3.1147
22	2.8585	2.7579	3.4956	2.1125	3.0534	2.7542	2.9165
23	3.1601	2.9965	4.6989	1.2483	3.082	3.0719	2.9088
24	3.0201	2.8418	3.5703	3.2807	2.3304	2.7991	2.8509
Max	4.7312	5.5296	5.3742	3.9742	5.6593	4.475	4.3728
Min	2.5316	2.4063	2.4227	1.038	1.1172	2.0397	2.4607
Avg	3.5576	3.6746	3.7956	2.4278	3.3685	3.2644	3.3446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 202 / 11 KV MANDHARDEV AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3795	.5228	.381	.0158	.0191	.0187	.0158
2	.3479	.5228	.3048	.0158	.0191	.0187	.0158
3	.3479	.4854	.2667	.0158	.0191	.0185	.0158
4	.3479	.4668	.2667	.0158	.0191	.0187	.0158
5	.3795	.4294	.3048	.0158	.0191	.0187	.0158
6	.4428	.5041	.3429	.0158	.0381	.0187	.0158
7	.5693	.9709	.4191	.0158		.0377	.0151
8	.6958	.8775	.7621	.0316	.0762	.0373	.0158
9	.0373	.0381	.4847		1.0269	.759	.0191
10	.0187	.0381	.6325		1.0082	.7907	.0191
11	.0187	.0381	.5376			.6325	.0381
12	.0187	.0381	.506		.8402	.6325	.0381
13	.0187	.0381	.4744		.811	.5376	.0381
14	.0187	.0381	.4744		.7468	.5376	.0191
15	.0187	.0381	.4744		.6908	.5693	.0191
16	.0187	.0381	.506		.7095	.6958	.0381
17	.0187	.0381	.0158	.8383	.0187	.0158	.0762
18	.0187	.0381	.0158	.7621	.0373	.0158	.0762
19	.0187	.0762	.0316	.7621	.0373	.0316	.0762
20	.0373	.0762	.0316	.0381	.0373	.0316	.0762
21	.0373	.0381	.0158		.0373	.0316	.0762
22	.0316	.381	.0158	.0381	.0373	.0316	.0762
23	.5601	.381	.0158		.0187		.0762
24	.4111	.5601	.5335	.0158	.0381	.0187	.0158
Max	.6958	.9709	.7621	.8383	1.0269	.7907	.0762
Min	.0187	.0381	.0158	.0158	.0187	.0158	.0151
Avg	.2005	.2781	.3256	.1855	.2866	.2399	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 203 / 11 KV WAI NAGARPALIKA PWW NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0753	.0791	.0762	.0753	.0762	.0633	.0753
2	.0602	.0633	.0762	.0602	.0762	.0791	.0602
3	.0602	.0625	.0762	.0602	.0762	.0781	.0602
4	.0753	.0791	.0762	.0753	.0762	.0791	.0753
5	.0753	.0781	.0953	.0753	.0762	.0791	.0753
6	.0753	.0781	.0953	.0753	.0762	.0791	.0753
7	.0753	.0791	.0953	.0753		.0791	.0753
8	.0602	.0791	.0953	.0753	.0953	.0791	.0753
9	.0791	.0953	.0753		.0791	.0753	.0953
10	.0633	.0953	.0753		.0633	.0753	.0953
11	.0791	.0953	.0753			.0753	.0953
12	.0633	.0953	.0753		.0633	.0753	.0953
13	.0791	.0953	.0753		.0791	.0753	.0953
14	.0791	.0953	.0753		.0791	.0753	.0953
15	.0791	.0953	.0753		.0791	.0753	.0953
16	.0633	.0953	.0753		.0316	.0753	.0953
17	.0633	.0953	.0753	.0953		.0753	.0953
18	.0633	.0953	.0753	.0953	.0633	.0602	.0953
19	.0791	.0953	.0753	.0953	.0791	.0602	.0953
20	.0781	.0953	.0753	.0953	.0791	.0753	.0953
21	.0791	.0953	.0753		.0791	.0753	.0953
22	.0791	.0953	.0753	.0762	.0791	.0753	.0953
23	.0791	.0953	.0753		.0791	.0602	.0762
24	.0753	.0791	.0953	.0753	.0762	.0633	.0753
Max	.0791	.0953	.0953	.0953	.0953	.0791	.0953
Min	.0602	.0625	.0753	.0602	.0316	.0602	.0602
Avg	.0725	.0878	.0796	.0789	.0744	.0735	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 204 / 11 KV MAPRO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2075	.1905	.2286	.0762	.2263	.2477
2	.1905	.1886	.1905	.1905	.0762	.2075	.2286
3	.2096	.1886	.1905	.1905	.0762	.2075	.1905
4	.2096	.1886	.1905	.2096	.0953	.2263	.2286
5	.1905	.1886	.2286	.2096	.1143	.2263	.2286
6	.2096	.2075	.2477	.2096	.1334	.2263	.2858
7	.2667	.2641	.3048	.1334		.2452	.2667
8	.3048	.2829	.3239	.0953	.2477	.3206	.2667
9	.3395	.3429	.3048		.4527	.381	.4382
10	.4527	.3429	.3429		.3584	.4191	.381
11	.3772	.362	.4382			.4001	.3429
12	.3961	.3429	.3048		.3018	.3429	.381
13	.3772	.381	.2858		.3206	.3048	.381
14	.3018	.4191	.2858		.2641	.381	.4572
15	.4527	.4382	.381		.4904	.4572	.4954
16	.4715	.4382	.4763		.4904	.4382	.5716
17	.5093	.381	.381	.1334	.4904	.381	.4954
18	.3206	.3048	.3239	.1524	.3961	.3429	.4572
19	.2075	.2667	.2858	.1715	.3018	.3048	.2858
20	.132	.3429	.2096	.1905	.2641	.2858	.3048
21	.1132	.1905	.2096		.2452	.2667	.3048
22	.2263	.1905	.1524	.0572	.2263	.2667	.2667
23	.2263	.1905	.2667		.2075	.2477	.2667
24	.1715	.2075	.1905	.2477	.0762	.2263	.2667
Max	.5093	.4382	.4763	.2477	.4904	.4572	.5716
Min	.1132	.1886	.1524	.0572	.0762	.2075	.1905
Avg	.2845	.2858	.2794	.1728	.2593	.3055	.3350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 205 / 11 KV MANDHARDEV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2743	.3048	.2033	.2667	.2743	.2587
2	.2587	.2561	.2667	.1848	.2667	.2561	.2402
3	.2587	.2561	.2286	.1663	.2667	.2561	.2218
4	.2772	.2587	.2286	.1848	.2858	.2561	.2402
5	.2957	.2743	.2667	.2218	.3048	.2743	.2772
6	.3142	.2378	.3429	.3511	.3239	.2743	.3326
7	.3696	.3841	.381	.4435		.3841	.3326
8	.3881	.3292	.362	.3511	.4001	.3292	.3511
9	.2772	.3048	.3326		.3292	.3326	.3239
10	.2926	.3048	.2957		.2926	.2587	.3048
11	.3326	.2858	.2772			.3696	.3048
12	.2561	.2858	.2587		.2926	.2957	.2858
13	.2743	.3048	.2667		.2926	.2772	.2667
14	.2926	.2858	.2858		.2926	.2772	.2667
15	.3109	.3048	.2402		.2561	.3142	.2858
16	.2926	.3048	.2218		.3109	.2957	.2858
17	.2926	.381	.3142	.4001	.3658	.3326	.3048
18	.3292	.4191	.3696	.4572	.3292	.4435	.3239
19	.4572	.4191	.4066	.5144	.4572	.5175	.4954
20	.5304	.4191	.5175	.4954	.5121	.5544	.4954
21	.4938	.5144	.462		.4938	.499	.4572
22	.4207	.4763	.3881	.4572	.4024	.462	.4191
23	.3658	.4191	.3326		.3475	.3326	.4001
24	.3142	.2743	.381	.2402	.3048	.2926	.2957
Max	.5304	.5144	.5175	.5144	.5121	.5544	.4954
Min	.2561	.2378	.2218	.1663	.2561	.2561	.2218
Avg	.3329	.3323	.3222	.3337	.3361	.3400	.3238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 302 / 22 KV MENAWALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.6584	.6097	.5914	.6097	.6584	.7392
2	.6653	.6584	.5335	.5175	.6097	.6219	.6653
3	.5914	.6584	.5335	.5175	.6097	.6219	.6653
4	.5914	.6219	.5335	.5544	.6859	.6219	.7392
5	.6653	.6219	.6097	.6653	.7621	.6584	.8131
6	.8501	.7682	.7621	.8501	.8764	.8779	.9979
7	1.1827	.8048	1.3717	1.1827		1.1706	1.1088
8	1.1827	1.1706	1.2574	1.2567	1.3717	1.2437	1.2197
9	1.2071	1.1431	1.1827		1.2071	1.2197	1.3336
10	1.0974	1.0669	1.1088		1.2071		1.1431
11	.8779	1.0288	.8501				1.0669
12	1.0242	1.0669	.924		1.0974		.9526
13	.9511	.9907	.8501		.9145		.9145
14	.8779	.9907	.8131		.8779		.8764
15	.9145	.9526	.7762		.8048		.9145
16	.8779	.9526	.7762	.3048	.8779		.9145
17	1.0242	1.1431	.8871	.4572	.9145		.9526
18	1.2071	1.3717	.9979	.7621	1.0974		.9526
19	1.4266	1.448	1.3306	1.5623	1.3169	1.6263	1.3717
20	1.6461	1.7147	1.6632	1.9814	1.7193	1.9589	1.7147
21	1.5364	1.5242	1.2342		1.6095	1.5524	1.3717
22	1.3169	1.1431		1.448	1.2803	1.3306	1.1431
23	.9145	1.0288	.924		1.0242	.9979	.9907
24	.7762	.7316	.7621	.7023	.7621	.7682	.7762
Max	1.6461	1.7147	1.6632	1.9814	1.7193	1.9589	1.7147
Min	.5914	.6219	.5335	.3048	.6097	.6219	.6653
Avg	1.0060	1.0108	.9257	.8902	1.0107	1.0619	1.0141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 303 / 22 KV PASARNI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7765	.5716	.5944	4.6335	4.4048	2.8959	.6142
2	.7411	.5716	.5792	4.4864	3.9933	3.1474	.5788
3	.7411	.5716	.5792	3.8363	3.7799	3.174	.5788
4	.7411	.0762	.5792	3.7296	3.6732	3.2083	.5635
5	.7461		.5792	3.8767	3.9629	3.3912	.6142
6	.7461		.6706	4.8762	4.7707	4.4848	.6497
7	.7461		.6554	7.3224	3.9781	7.2322	.6649
8	.7461		.6554	7.2886	7.1178	8.5505	.6649
9	6.9044	3.5513	.6294	3.7952	3.4865	7.6666	7.2321
10	8.6077	9.0078	.6802		.5411	9.9108	8.9315
11	9.0078	10.8597	.7156		.4572	8.2667	9.1297
12	9.164	11.0807	.6802		.5258	8.8813	7.5064
13	8.9621	10.4558	.6142		.5106	8.8611	7.2397
14	8.7876	9.8613	.6142		.5258	8.0991	6.9044
15	8.2419	9.5717	.5989		.5106	8.4088	7.1483
16	8.6953	9.2516	.5989		.5106	8.8096	7.2169
17	5.6367	3.7494	.6142	.1524	.5258	4.7192	3.3379
18	.5418	.5487	.6497	.1524	.5258	.6497	.6096
19	.5917	.6249	.6649	.6249	.5754	.6497	.6249
20	.6375	.6859	.7107	.6859	.6211	.6802	.6554
21	.6527	.7011	.7816	.5335	.6364	.6802	.6554
22	.6375	.7011	.5182	.6554	.6364	.6802	.6706
23	.5875	.6859	4.6075	2.8959	.6211	.6649	.6554
24	.7308	.5868	3.4751	4.75	2.0272	.5754	.6294
Max	9.164	11.0807	4.6075	7.3224	7.1178	9.9108	9.1297
Min	.5418	.0762	.5182	.1524	.4572	.5754	.5635
Avg	3.5155	4.1857	.9186	3.1938	2.0383	4.7620	3.0865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 402 / 33 KV GARWARE

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	11.4712	12.9836	12.6429	13.4945	13.043	13.6489	13.0315
2	11.8427	13.0624	13.1116	13.8432	13.2774	13.9129	13.4888
3	8.5734	13.0572	12.6086	13.1116	13.4202	13.2322	13.4088
4	8.1104	13.011	13.0315	13.4774	13.5745	13.2219	13.0773
5	10.9854	13.0333	13.2144	13.3345	12.7972	12.9767	13.5574
6	11.1511	13.011	13.5975	14.0661	13.2373	13.6094	13.6146
7	11.3512	12.0542	13.083	13.4774	10.2881	14.0313	13.6431
8	10.6596	12.2651	11.6827	12.0085	13.8146	14.1685	12.8886
9	11.5912	12.9401	12.58	8.3505	14.7325	14.6662	13.1859
10	12.1331	13.5345	14.1633		14.7479	14.6491	13.5917
11	11.9684	14.6319	14.2833		10.0137	13.7517	14.0833
12	11.5827	14.0776	13.2031		10.0652	13.1631	12.5972
13	11.2329	13.7574	10.7225		13.3728	13.5917	10.671
14	12.0062	13.2545	13.1573		14.2147	14.1003	12.3114
15	12.8172	13.8832	14.1175		14.3571	13.8604	13.4431
16	12.5446	13.4374	14.7177		13.8615	13.3231	13.043
17	12.8789	14.0947	15.072	6.9273	13.5716	13.8088	13.5059
18	13.0384	13.6717	14.6034	8.9335	13.7072	13.8317	13.6031
19	12.987	14.4148	14.4605	10.1909	13.3144	14.4205	13.9404
20	13.3094	14.3862	13.1287	11.1969	14.3107	14.4034	13.9347
21	13.7055	13.6317	11.7742	8.7963	14.0604	14.1804	13.5632
22	13.9867	13.9461	9.8766	11.8599	13.6557	14.7005	9.8423
23	14.165	13.8375	10.2881	10.048	13.8152	13.9746	12.8887
24	12.9973	12.3612	13.5174	13.2659	12.8487	12.8618	12.6886
Max	14.165	14.6319	15.072	14.0661	14.7479	14.7005	14.0833
Min	8.1104	12.0542	9.8766	6.9273	10.0137	12.8618	9.8423
Avg	11.9621	13.4308	13.0266	11.5519	13.2542	13.8370	13.0668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 404 / 33 KV ATHARVA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.5563	8.3985	5.2984	8.259	4.3439	6.5741	6.1843
2	8.5106	8.2408	7.5732	6.8073	4.321	5.5145	7.6132
3	8.0476	8.1173	6.2243	7.7904	4.8982	7.7709	7.4132
4	6.4987	7.0079	5.0412	6.1214	5.0926	7.0113	6.9273
5	7.1788	8.8941	6.0871	5.6299	4.8982	7.1588	7.7847
6	7.1331	10.0292	6.8473	6.9216	4.5953	7.5737	7.2131
7	8.8306	7.6817	7.1559	3.0121	1.8519	7.7161	7.7618
8	6.6301	5.6876	5.1669	3.7095	5.7671	6.2894	5.0297
9	7.4366	7.7561	5.4698	1.6461	5.8745	8.0304	4.1609
10	8.0881	9.3164	2.3091		7.404	5.91	8.8077
11	9.0055	8.8134	2.6063		7.8361	8.4877	7.939
12	8.9524	8.362	4.0295		10.0446	8.8021	8.4419
13	8.1345	7.8361	2.0519		8.3899	8.2305	8.1847
14	7.0045	8.6877	6.5272		8.4036	9.608	7.0645
15	7.7418	5.9842	8.7505		8.2133	7.5046	7.7618
16	7.963	10.3338	7.7104		5.3909	8.602	1.2975
17	8.558	8.8363	8.2991	.5087	10.2692	8.2018	6.3101
18	8.1688	9.065	6.11	.5087	9.0998	8.1161	6.5044
19	7.1725	8.7791	8.8421	.5888	7.6886	9.1507	7.4874
20	5.5813	8.642	3.9094	1.4118	6.1831	8.1733	8.3105
21	4.5439	6.2071	7.1331	2.2291	6.2671	5.5784	4.9154
22	7.5446	5.7041	5.024	3.2922	5.9619	7.3274	6.4986
23	5.1286	8.3162	3.7037	4.2353	10.0138	7.8533	6.3044
24	8.6991	8.4174	7.1102	5.1669	7.0588	8.5048	6.2015
Max	9.0055	10.3338	8.8421	8.259	10.2692	9.608	8.8077
Min	4.5439	5.6876	2.0519	.5087	1.8519	5.5145	1.2975
Avg	7.5462	8.1298	5.7909	3.9905	6.6611	7.6537	6.7549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 301 / BHUINJ AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2131	.0762	.1143		.1143	2.5926	3.3913
2	2.0317	.0762	.1143		.1143	2.556	3.2769
3	1.9113	.0762	.0762		.1143	2.4905	3.4294
4	1.9448	.0762	.0762		.1143	2.5232	3.4294
5	1.8778	.1143	.1143		.1143	2.6871	3.5056
6	2.3137	.1905	.1143		.1524	3.2648	4.382
7	2.982	.1905	.1143		.1524	3.7769	3.8104
8	3.0407	.1143	.1143		.1524	3.6168	3.5056
9	3.3097	4.763	4.1914	4.4201	.1524	.1143	.1143
10	3.7723	3.4248	4.5725	4.1533	.1524	.1143	.1143
11	3.9247		4.4963	4.4582	.1524		.1143
12			4.6487	3.7723	.1524		.1143
13	3.2769		4.5725	3.8485	.1143		.1143
14	3.2769		3.4888	3.6961	.1143		.1143
15	3.2388		3.1367	3.658	.1143	.1143	.1143
16	4.0009	4.321	3.2114	3.5056		.1143	.1143
17	.1143	4.225		.1143		.1143	.1143
18	.1143	3.1459		.1524	.1143	.1143	.1524
19	.1905	3.1047		.1524		.1905	.1524
20	.1905	.1143		.1524	.1143	.1905	.1524
21	.1905	.1143		.1524	.1524	.1905	.1524
22	.1905	.1143		.1524	.1524	.1905	.1524
23	.1143	.1143		.1524	.1524	.1905	.1143
24	2.2405	.1143	.1143		.1143	.1524	.1143
Max	4.0009	4.763	4.6487	4.4582	.1524	3.7769	4.382
Min	.1143	.0762	.0762	.1143	.1143	.1143	.1143
Avg	2.0200	1.2879	1.9571	2.1694	.1324	1.2649	1.2812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 302 / JAMB AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5424	.1143	.1143		.0762	1.8351	2.2862
2	1.4083	.0762	.0762		.0762	1.8351	2.3624
3	1.3611	.0762	.0762		.0762	1.7695	2.3624
4	1.3413	.0762	.0762		.0762	1.7101	2.3624
5	1.2407	.0762	.1143		.0762	1.8107	2.3624
6	1.4419	.0762	.1143		.0762	1.9662	2.5149
7	1.7772	.1905	.1143		.1143	2.2405	2.4387
8	1.9784	.1905	.1143		.1143	2.2801	2.2481
9	2.146		2.8197	2.4387	.1143	.1143	.1143
10	2.6292		2.8197	2.553	.1143	.1143	.1143
11	2.6673		2.8197	2.8959	.1143		.0762
12	2.2862		2.8197	2.4768	.1143		.0762
13			2.8197	2.4387	.1143		.1143
14	2.3624		2.1628	1.8671	.1143		.1143
15			2.146	2.2862	.1143	.1143	.1143
16	1.9052	2.7526	2.079	2.1719	.1143	.1143	.1143
17	.1143	2.7846		.0762	.1143	.1143	.1143
18	.1143	2.6566		.0762	.1143	.1143	.1143
19	.1905	2.2405		.1143	.1143	.1143	.1143
20	.1905	1.9784		.1143	.1143	.1905	.1143
21	.1905	1.8351		.1143	.1143	.1905	.1143
22	.1905			.1143	.1143	.1905	
23	.1143	.1143		.1143	.1143	.1905	.1143
24	1.5729	.1143	.1143		.0762	.1143	.1143
Max	2.6673	2.7846	2.8197	2.8959	.1143	2.2801	2.5149
Min	.1143	.0762	.0762	.0762	.0762	.1143	.0762
Avg	1.3075	.9595	1.2589	1.3235	.1032	.8562	.8946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 303 / BHUINJ GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5335	.5335		.7621	.5853	.5335
2		.5335	.4954		.7621	.5487	
3	.5121	.4572	.4572		.7621	.5121	.4572
4	.5853	.4572	.4572		.8002	.4755	.6097
5	.4755	.5335	.4954		.8002	.5487	.724
6	.5853	.6097	.6097		.8383	.6219	.9145
7	.8238	.8383	.8002		.1143	.8596	.6859
8	.788	.7621	.6859		.9145	.8238	.6097
9	.6584	.724	.6859	.6859	.8764	.695	.6097
10	.6097	.6219	.6859	.724	.6219	.6859	.9907
11	.6478	.6584	.724	.6478	.6219	.6859	.9526
12	.6097	.5853	.724	.6478	.6584	.6859	.9907
13	.6097	.5487	.6859	.6478	.5853	.6478	.9526
14	.6097	.5853	.695	.5716	.6584	.6478	.724
15	.6859	.6219	.6584	.6097	.695	.6097	.8383
16	.6859	.6219	.6584	.6478	.7522	.6859	.8764
17	.724	.5853		.6859	.6584	.6097	.724
18	.724	.6219		.9526	.7316	.7621	.9907
19	.8764	.7522		.9526	.8238	.9145	1.105
20	.9145	.8596		1.1812	.9671	1.1431	1.3717
21	.7621			1.105	.9313	.9526	1.2574
22	.6859	.788		1.0288	.788	.8764	
23		.8596		.8764	.695	.6478	1.1431
24	.5853	.6097	.0549		.7621	.6219	.6097
Max	.9145	.8596	.8002	1.1812	.9671	1.1431	1.3717
Min	.4755	.4572	.0549	.5716	.1143	.4755	.4572
Avg	.6685	.6421	.5945	.7977	.7325	.7020	.8487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 304 / JAMB GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5335	.5335		.5716	.5121	.5335
2	.4755	.4572	.4954		.5716	.5121	.5335
3	.5121	.4572	.4572		.5716	.4755	
4	.5487	.381	.4954		.5716	.4755	.6859
5	.5121	.381	.5716		.5716	.5121	.7621
6	.6219	.6859	.6859		.6097	.6584	.7621
7	.7316	.7621	.724		.7621	.7522	.7621
8	.6584	.6859	.6859		.6859	.6584	.6859
9	.5487	.6478	.6859	.4572	.6478	.6584	.6097
10	.4572	.695	.724	.4572	.7316	.724	.724
11	.5335	.7522	.6859	.5716	.695		.8002
12	.5335	.788	.6859	.5716	.7316	.6859	.6097
13		.6584	.6859	.6478	.7316	.4954	.8764
14	.7621	.7316	.6584	.4954	.6584	.4954	.8002
15	.6859	.7522	.6584	.4954	.6584	.6097	.8383
16	.6859	.7522	.6584	.4954	.6584	.724	.8002
17	.6859	.7522		.381	.7164	.5716	.8002
18	.6859	.788		.5335	.788	.7621	.8002
19	.9907	.788		.6478	1.0029	.9145	.9145
20	1.1431	.9313		.8383		1.1812	1.0288
21	1.0669	.8238		.8002	.8596	1.105	.8383
22	.6859	.7522		.7621	.7316	.8002	
23	.6859			.6478	.5853		.6097
24	.5487	.6097	.5487		.5716	.5487	.6097
Max	1.1431	.9313	.724	.8383	1.0029	1.1812	1.0288
Min	.4572	.381	.4572	.381	.5716	.4755	.5335
Avg	.6640	.6768	.6259	.5868	.6819	.6742	.7448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 305 / 22 KV KHADAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	1.9052	1.829		.1524	.1143	.1143
2	.1143	1.8671	1.6766		.1143	.1143	.1143
3	.1143	1.829	1.4861		.1143	.1143	.1143
4	.1143	1.829	1.448		.1143	.1143	.1143
5	.1143	1.9814	1.448		.1524	.1143	.1143
6	.1143	2.0957	.8764		.1524	.1143	.1143
7	.1143	2.5911	2.4006		.1524	.1143	.1143
8	.1143	2.5911	2.21		.1524	.1143	.1143
9	.1143	.0762	.1143	2.5149		2.2611	2.6673
10	.1143	.1143	.0762	2.5911	2.3137	3.0102	3.0483
11	.0762	.1143	.0762	2.2862	2.3472		2.2862
12	.0762	.1143	.0762	2.2481	2.556	2.8197	2.21
13	.0762	.1143	.0762	1.9052	2.3594	2.7435	2.21
14	.0762	.1143	.0762	1.9052	2.1125	2.0576	2.21
15	.0762	.1143	.0762	1.7909	2.079	2.21	1.7528
16	.0762	.1143	.0762	1.6385	1.9113	2.2862	2.1338
17	.0762	.1143		.1143	1.6095	.1143	.1143
18	.0762	.1143		.1143	.1143	.1143	.1524
19	.0762			.1524	.1143	.1143	.1524
20	.1905	.1143		.1524	.1143	.2286	.1524
21	.1905	.1143		.1905	.1143	.2286	.1524
22	.1143			.1905	.1143	.1905	
23	2.1338	.1143		.1905	.1143	.1905	.1524
24	.1143	2.0957			.1524	.1143	.1905
Max	2.1338	2.5911	2.4006	2.5911	2.556	3.0102	3.0483
Min	.0762	.0762	.0762	.1143	.1143	.1143	.1143
Avg	.1905	.9197	.8764	1.199	.8362	.8521	.8913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 302 / 22 KV COLLEGE ROAD

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-APR-17	23-APR-17	24-APR-17	25-APR-17	26-APR-17	27-APR-17	28-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8535	.8383	.823	.7773	.823	.823	.884
2	.7926	.7773	.7773	.7164	.7621	.7468	.7468
3	.7773	.7621	.7468	.7011	.7468	.7621	.7316
4	.7773	.7468	.7011	.7011	.7316	.7773	.7316
5	.7468	.7468	.7011	.6859	.7011	.7621	.7164
6	.7468	.8078	.7468	.7926	.7621	.7926	.7621
7	.9602	1.0364	1.0212	1.1279	1.1126	1.0212	1.0974
8	1.1279	1.1279	1.1584	1.2193	1.2955	1.2346	1.2803
9	1.1736	1.0974	1.2041	1.1888	1.3413	1.2498	1.2498
10	1.3108	1.2498	1.2346	1.2193	1.4022	1.2803	1.2193
11	1.3108	.945	1.2803	.9297	1.2193	1.2498	1.2041
12	1.2955	1.0822	1.2803	2.3472	1.1736	1.2651	1.0669
13	1.2651	.9755	1.2193	1.9052	1.1888	1.0669	.9297
14	1.1736	.9145	1.0669	.4572	1.0822	2.7282	1.0364
15	1.1431	.884	1.0669	.9297	1.0669	3.8409	.9755
16	1.0974	.884	1.0669	.9907	1.1126	3.8561	1.0212
17	1.1888	1.1126	1.2651	.3506	1.1279	3.6123	1.0974
18	1.2955	1.2041	1.2498	.3201	1.1431	4.1457	1.1736
19	1.2346	1.2651	1.2651	1.3108	1.1888	4.1914	1.2041
20	1.2803	1.2803	1.2041	1.4175	1.1888	1.2803	1.2651
21	1.2041	1.1431	1.1888	1.2803	1.1279	1.2498	1.2193
22	1.1279	1.1126	1.1126	1.1431	1.1126	1.2651	1.1736
23	1.1126	1.0669	1.0517	1.1584	1.0517	1.1736	1.1584
24	.945	.9145	.8993	.9145	.945	1.0059	.945
Max	1.3108	1.2803	1.2803	2.3472	1.4022	4.1914	1.2803
Min	.7468	.7468	.7011	.3201	.7011	.7468	.7164
Avg	1.0809	.9990	1.0555	1.0244	1.0586	1.7242	1.0371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-17 and 28-APR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 404 / 33 KV WAI-VELE

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	22-APR-17	23-APR-17
HR	Load (MW)	Load (MW)
1	2.8121	2.5377
2	2.6063	2.332
3	2.5377	2.2634
4	2.4691	1.989
5	2.332	1.989
6	2.6749	2.332
7	3.6351	2.6749
8	3.9781	3.8409
9	10.4938	5.9671
10	12.6886	11.4541
11	13.3745	14.3347
12	12.62	14.4033
13	12.5515	13.8546
14	17.1468	13.0316
15	11.5226	12.62
16	12.0028	12.3457
17	11.9342	9.808
18	3.9095	3.4979
19	4.4582	4.4582
20	5.8299	5.7613
21	5.5556	5.6242
22	5.144	4.9383
23	4.2524	4.1152
24	3.0864	2.8807
Max	17.1468	14.4033
Min	2.332	1.989
Avg	7.0673	6.6272