

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 201 / KIRPE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1238	.1116	.0343
2	.1234	.1105	.0343
3	.1063	.1097	.0343
4	.1075	.1097	.0343
5	.128	.1467	.0343
6	.1585	.152	.0343
7	.1524	.1337	.0514
8	.1219	.12	.0514
9	2.0797	2.1483	.7316
10	2.1929	2.2051	.7773
11	2.1457	2.0942	.7773
12	2.1613	2.0512	.7926
13	1.243	2.0363	.7468
14		1.8656	.6859
15	.0713	1.0642	.7011
16	1.2224	1.5756	.6859
17	.57	.6177	.0343
18	.0793	.0343	.0343
19	.1044	.0918	.0343
20	.1463	.1257	.0686
21	.1452	.1272	.0686
22	.1574	.1291	.0514
23	.1261	.1291	.0514
24	.1154	.1169	.0343
Max	2.1929	2.2051	.7926
Min	.0713	.0343	.0343
Avg	.5905	.7253	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 202 / CHACHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343
2	.0343	.0343	.0343
3	.0343	.0343	.0343
4	.0343	.0343	.0343
5	.0343	.0343	.0343
6	.0343	.0343	.0343
7	.0343	.0343	.0343
8	.0343	.0343	.0343
9	.0343	.0343	.0343
10	.0343	.0343	.0343
11	.0343	.0343	.0343
12	.0343	.0343	.0343
13	.0343	.0343	.0343
14	.0343	.0343	.0343
15	.0343		.0343
16	.0343	.0343	.0343
17	.0343	.0343	.0343
18	.0343	.0343	.0343
19	.0343	.0343	.0343
20	.0343	.0514	.0343
21	.0514	.0514	.0343
22	.0514	.0514	.0343
23	.0343	.0343	.0343
24	.0343	.0343	.0343
Max	.0514	.0514	.0343
Min	.0343	.0343	.0343
Avg	.0357	.0365	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 203 / DHEBEWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6516	.4973
2	.583	.6173	.4801
3	.5658	.6001	.4801
4	.583	.6001	.4973
5	.583	.583	.5144
6	.703	.6859	.583
7	.6859	.6859	.6344
8	.6516	.6516	.583
9	.6173	.6001	.583
10	.6706	.5144	.5487
11	.6344	.583	.5144
12	.6401	.583	.4801
13		.463	.4801
14		.4458	.463
15	.6401		.5144
16	.7773	.3601	.5144
17	.6001	.3429	.5316
18	.6687	.5316	.6173
19	.7202	.6097	.703
20	.8916	.7316	.8745
21	.9088	.7011	.823
22	.823	.6249	.6859
23	.6516	.4973	.6344
24	.6001	.6859	.5144
Max	.9088	.7316	.8745
Min	.5658	.3429	.463
Avg	.6727	.5804	.5730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 204 / KOLE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2743	.2401
2	.2743	.2743	.2401
3	.2743	.2915	.2401
4	.2743	.2743	.2743
5	.2743	.2915	.2915
6	.3429	.3429	.3258
7	.3258	.3086	.3429
8	.2743	.3258	.3086
9	.2572	.2743	.2743
10	.2401	.2572	.2743
11	.2572	.2229	.2401
12	.2915	.1886	.2743
13	.3086	.2058	.2743
14	.3086	.2058	.2743
15	.3086		.2743
16	.3086	.2229	.2743
17	.2572	.1886	.2058
18	.2915	.2572	.2401
19	.2743	.2915	.3429
20	.4458	.3601	.3944
21	.4458	.3772	.3944
22	.4115	.3429	.3429
23	.3429	.2401	.2915
24	.2915	.2915	.2572
Max	.4458	.3772	.3944
Min	.2401	.1886	.2058
Avg	.3072	.2743	.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 205 / CHACHEGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6142	.6957	.1886
2	.6089	.6775	.1715
3	.6508	.6653	.1715
4	.6013	.6942	.1715
5	.6256	.7018	.1886
6	.6836	.7522	.1886
7	1.0052	.9747	.2915
8	1.0341	1.0121	.3601
9	.4855	.5037	.0343
10	.0389	.0587	.0343
11	.0427	.0473	.0343
12	.048	.045	.0343
13	.0549	.0438	.0343
14	.0587	.0351	.0343
15	.0549	.0038	.0343
16	.0503	.0343	.0343
17	.0419	.0343	.0343
18	.0404	.0343	.0343
19	.0572	.0755	.0343
20	.0549	.1166	.0343
21	.0686	.1158	.0343
22	.0983	.1136	.0343
23	.724	.343	.2572
24	.6851	.548	.1886
Max	1.0341	1.0121	.3601
Min	.0389	.0038	.0343
Avg	.3512	.3469	.1107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 206 / TALMAVALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343
2	.0343	.0343	.0343
3	.0343	.0343	.0343
4	.0343	.0343	.0343
5	.0343	.0343	.0343
6	.0343	.0343	.0343
7	.0343	.0343	.0343
8	.0343	.0343	.0343
9	2.1338	2.2462	.6401
10	2.5606	2.2977	1.2041
11	2.5301	2.1605	1.2498
12	2.3929	2.0576	1.2193
13	2.3015	1.9204	1.2955
14	2.1338	1.8176	1.1736
15	1.9966		1.2193
16	2.0576		1.1736
17	.0343		.0343
18	.0343	.0343	.0343
19	.0343	.0343	.0343
20	.0343	.0343	.0343
21	.0343	.0343	.0343
22	.0343	.0343	.0343
23	.0343	.0343	.0343
24	.0343	.0343	.0343
Max	2.5606	2.2977	1.2955
Min	.0343	.0343	.0343
Avg	.7773	.6197	.4052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 201 / YELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0608	.9335
2	1.0425	1.0242	.8962
3	1.0425	1.0059	.9054
4	1.0608	1.0059	.9335
5	1.0425	.9877	.9709
6	1.0425	1.134	1.0829
7	.9694	1.0059	1.0829
8	.9328	.9877	1.0269
9	1.5524	1.4083	1.1401
10	1.7444	1.6297	1.2071
11	1.6324	1.5604	1.1065
12	1.4723	1.4022	1.0395
13	1.4723	1.4175	1.0059
14	1.3283	.7796	.9496
15	1.3283	1.1919	.9602
16	1.2323	1.0288	.8573
17	.7316	.6154	.7783
18	.8596		.7783
19	1.134	.7964	1.1576
20	1.7924	1.2323	1.6804
21	1.7375	1.307	1.6244
22	1.6644	1.2323	1.419
23	1.2986		1.0751
24	1.1157	1.0974	1.0164
Max	1.7924	1.6297	1.6804
Min	.7316	.6154	.7783
Avg	1.2636	1.1323	1.0678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 202 / YEWATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2231	1.6095	.503
2	1.1675	1.5341	.4694
3	1.0844	1.4975	.4641
4	1.0852	1.2787	.4973
5	1.3732	1.4266	.6036
6	2.0073	1.928	.8048
7	2.5148	.3368	1.012
8	2.2679	.1844	.9568
9	1.4868	2.0202	.5921
10	1.4563	1.7696	.543
11	1.3984	1.2521	.5487
12	1.5036	1.0182	.5487
13	1.1988	.9366	.4877
14	1.2491	.6585	.4572
15	1.0722	.9313	.3506
16	1.0387	1.0738	.381
17	.9861	1.137	.381
18	1.1926	1.249	.3658
19	2.0218	1.8228	.7907
20	2.6757	2.2626	1.0595
21	2.7587	2.2207	1.0437
22	2.6307	2.0889	.9646
23	1.778	1.5112	.6001
24	1.4975	1.4244	.5304
Max	2.7587	2.2626	1.0595
Min	.9861	.1844	.3506
Avg	1.6112	1.3822	.6232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 203 / UNDALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.2071	.3982
2	1.1523	1.1706	.9335
3	1.1523	1.1706	.8962
4	1.1523	1.1706	.9431
5	1.1706	1.134	1.0082
6	1.1706	1.1706	1.2071
7	1.0974	1.2254	1.0349
8	1.0059	.9694	1.1088
9	1.4083	1.4723	.8223
10	1.6324	1.2742	1.1728
11	1.5203	1.1888	1.1728
12	1.5203	.9602	1.0669
13	1.2643	.9457	1.0155
14	1.1843	.8573	.9686
15	1.2803	.9023	.9686
16	1.4243	.9267	.953
17	1.1157	.9465	.9568
18	1.1157	.6805	.9568
19	1.262	1.3676	1.2803
20	1.6278	1.531	1.6057
21	1.5729	1.4563	1.531
22	1.5546	1.1576	1.419
23	1.3535		1.2637
24	1.2437	1.2254	.3982
Max	1.6324	1.531	1.6057
Min	1.0059	.6805	.3982
Avg	1.2995	1.1352	1.0451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 201 / TAMBVE

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	3.8843	3.4656	1.0456
2	3.8317	3.4004	1.0082
3	3.8195	3.3859	1.0082
4	3.7997	3.36	1.0136
5	3.7959	3.3989	1.0829
6	4.4018	3.8017	1.1203
7	4.8255	4.2113	1.4937
8	4.7005	4.1526	1.6057
9	2.0164	1.8114	.6535
10	1.1499	1.1179	.5601
11	1.1866	.9892	.5601
12	1.2369	.948	.3734
13	1.2765	.6203	.3734
14	1.2841	.6821	.3734
15	1.2662	.3567	.3734
16	1.2601	.6623	.3361
17	1.23	.695	.3361
18	.9789	.3132	.2987
19	1.5775	1.0463	.7468
20	2.1334	1.8542	1.0642
21	2.171	1.1607	1.0751
22	2.2013	.5929	.9997
23	3.4984	1.6088	1.1934
24	3.8188	2.7671	1.0829
Max	4.8255	4.2113	1.6057
Min	.9789	.3132	.2987
Avg	2.5560	1.9334	.8241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 202 / SAJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.9326	2.0008	.3361
2	1.8941	1.9271	.2987
3	1.8659	1.8829	.2987
4	1.8446	1.8742	.2801
5	1.8598	1.8707	.2801
6	2.082	2.0668	.3361
7	2.4391	2.207	.4294
8	2.4509	2.2016	.5228
9	1.0699	.8814	.2054
10	.3562	.1478	.1867
11	.3193	.319	.1867
12	.3322	.1966	.1494
13	.3379	.1494	.1494
14	.3673	.3121	.1494
15	.3532	.1718	.1494
16	.3452	.1825	.1494
17	.3498	.2572	.1494
18	.3366	.2316	.1867
19	.373	.4699	.2427
20	.567	.5617	.2829
21	.5748	.5819	.2829
22	.5805	.5483	.2641
23	1.9637	.7754	.663
24	2.1037	1.3466	.3734
Max	2.4509	2.207	.663
Min	.3193	.1478	.1494
Avg	1.1125	.9652	.2730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 203 / AREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6157	.775	.2241
2	.5822	.7438	.1867
3	.5715	.6805	.1867
4	.5708	.6897	.1867
5	.5936	.6746	.2241
6	.7431	.8611	.2987
7	1.0631	1.0959	.3734
8	1.1538	1.0692	.4481
9	.5757	.5658	.056
10	.056	.2423	.0373
11	.1494	.2347	.0373
12	.1726	.2316	.0373
13	.3562	.2416	.0373
14	.3471	.3011	.0373
15	.3216	.1578	.0373
16	.2988	.2965	.1494
17	.2896	.2537	.1307
18	.2892	.2423	.1307
19	.3379	.3711	.1867
20	.5418	.4893	.2829
21	.5644	.4824	.2641
22	.54	.442	.2263
23	.7202	.4718	.2321
24	.7537	.6048	.2241
Max	1.1538	1.0959	.4481
Min	.056	.1578	.0373
Avg	.5087	.5091	.1765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 204 / TAMBAVE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
1	.0549	.0373
2	.0549	.0373
3	.0549	.0373
4	.0549	.0373
5	.0549	.0373
6	.0366	.0373
7	.0183	.4668
8	.0366	.5601
9	.0514	.5853
10	.0514	.5853
11	.0514	.5853
12	.0514	.5975
13	.0514	.567
14	.0514	.5853
15	.0514	.5853
16	.0514	.0343
Max	.0549	.5975
Min	.0183	.0343
Avg	.0486	.336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254056 / 33/11 KV KALE

Feeder No / Name : 202 / PACHWAD

Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9804	.9804	.703
2	.9842	.9962	.703
3	.9842	.9962	.703
4	.9962	.9962	.703
5	1.0082	.9962	.703
6	1.0082	.9962	.703
7	1.0082	.9962	.703
8	1.0082	.9962	.703
9	1.0364	1.0242	.703
10	1.0242	.9962	.703
11	1.0242	.9686	.703
12	1.012	.9962	
13	.9842	.9842	.7116
14	.9842	1.0082	1.0242
15	.9962	.9962	1.0242
16	.0191	.0114	.0143
Max	1.0364	1.0242	1.0242
Min	.0191	.0114	.0143
Avg	.9411	.9337	.7005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254064 / 33/11 KV WING

Feeder No / Name : 201 / 11 KV Wing AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.1874	.4321
2	2.079	2.1293	.4374
3	2.13	2.1293	.6327
4	2.2996	2.0972	.6327
5	2.4006	2.2119	.6481
6	2.4966	2.4646	.7099
7	2.5301	2.6216	.8688
8	2.3746	2.5316	.945
9	.2263	.2012	.132
10	.2641	.2012	.1509
11	.2641	.1677	.0943
12	.3206	.1658	.1509
13	.1886	.2058	.1509
14	.2075	.2254	.1698
15	.2452	.2103	.2075
16	.2829		.2075
17	.2829	.2263	.2075
18	.2829	.2452	.2263
19	.3018	.2641	.2774
20	.3584	.3206	
21	.3584	.3018	.3077
22	.3584		.3109
23	2.13	1.0467	1.6804
24	1.6126	2.2721	.3395
Max	2.5301	2.6216	1.6804
Min	.1886	.1658	.0943
Avg	1.0784	1.1103	.4313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254064 / 33/11 KV WING

Feeder No / Name : 202 / 11 KV Wing Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4294	.0324
2	.3688	.4108	.3366
3	.3277	.4108	.3189
4	.3563	.3921	.3189
5	.3841	.4668	.3544
6	.3841	.5415	.4031
7	.3953	.6161	.4801
8	.4062	.5415	.4191
9	.4694	.4681	.4668
10	.4359	.4024	.4294
11	.4527	.3688	.4108
12	.4475	.3315	.3921
13	.4372	.3086	.3921
14	.4001	.3121	.4294
15	.4144	.2774	.4294
16	.4409	.2279	.4294
17	.4294	.285	.4294
18	.4854	.3521	.4854
19	.5228	.4681	.4854
20	.6535	.5434	.591
21	.6348	.5138	.5611
22	.5788		.4938
23	.5041		.4115
24	.4557	.4481	.3437
Max	.6535	.6161	.591
Min	.3277	.2279	.0324
Avg	.4499	.4144	.4102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 201 / 11 KV Kasarshirambe Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886
2	.1886	.1715	.1715
3	.1886	.1715	.1715
4	.1886	.1715	.1715
5	.1886	.1715	.1715
6	.1886	.1715	.1715
7	.2058	.1543	.1543
8	.2229	.1886	.1886
9	1.5655	1.6975	
10	1.6827		1.2883
11			1.2883
12	1.6461		1.307
13	1.749		1.2323
14	1.4746	1.5432	1.1389
15	1.3375	1.6461	1.358
16		1.4045	1.3443
17	.1772	.1715	.1543
18	.1949	.1886	.1715
19	.2172	.2279	.2103
20	.2614	.2686	.2534
21	.2641	.2587	.2587
22	.2641	.2587	.2427
23	.2641	.2218	.2241
24	.2075	.2263	.2033
Max	1.749	1.6975	1.358
Min	.1772	.1543	.1543
Avg	.5848	.4751	.5245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 202 / 11 KV Malkhed

Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.5775	2.0233	.8916
2	2.1091	2.0748	1.5775
3	2.1091	2.0748	1.9204
4	2.0919	2.1091	2.0405
5	2.0748	2.0919	2.0576
6	2.0919	2.1262	2.0405
7	2.1434	2.0748	1.5432
8	2.1091	1.9033	1.5261
9	.6413	2.2862	1.5524
10	2.2131		1.5684
11			1.2883
12	1.5432		1.5684
13	2.0062		1.5497
14	2.0233	1.166	1.475
15	2.0405	1.5364	1.5655
16	2.0022	1.5339	1.5684
24		.1886	.1848
Max	2.2131	2.2862	2.0576
Min	.6413	.1886	.1848
Avg	1.9184	1.7838	1.5246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 203 / 11KV Kalawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	
2	.1543	.1543	
3	.1543	.1543	
4	.1543	.1543	
5	.1543	.1543	
6	.1543	.1715	
7	.1886	.1715	
8	.1715	.1543	.1886
9	.1886	.1646	
10	.1829		.2054
11	.1543		.168
12	.1715		.1867
13	.1886		.1494
14	.1715	.1886	
15	.1715	.2012	.132
16	.1715	.2033	.1867
17	.1595	.1715	.1543
18	.1772	.1715	.1543
19	.2534	.2103	.2103
20	.2614	.2328	.2715
21	.2452	.2218	.2402
22	.2452	.2033	.2054
23	.2452		.1867
24	.1698	.1886	
Max	.2614	.2328	.2715
Min	.1543	.1543	.132
Avg	.1851	.1803	.1885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 203 / NANDGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7356	.7655	.4108
2	.7282	.7468	.3921
3	.7356	.7356	.3772
4	.7356	.7356	.3772
5	.7922	.7545	.3961
6	.8775	.8589	.4481
7	.7922	.7682	.4668
8	.6099	.7059	.4207
9	1.9292	1.9925	.4843
10	2.0083	1.8435	.4755
11	1.7747	1.5202	.9633
12	1.6156	1.3643	1.4529
13	1.39	1.3523	1.5181
14	1.4266	1.1888	1.3435
15	1.5051		1.2654
16	1.4563	.7628	1.326
17	.4887	.567	.4298
18	.5316		.4344
19	.7865	.8688	.7499
20	1.0082	.9979	.9522
21	.9896	.9896	.9149
22	.9709	.9522	.8865
23	.8589		.7922
24	.7655		.4108
Max	2.0083	1.9925	1.5181
Min	.4887	.567	.3772
Avg	1.0630	1.0235	.7370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 205 / RETHARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0751	1.0185	.9054
2	1.0185	.9997	.8865
3	1.0562	.9808	.9242
4	1.0185	.9619	.9054
5	1.0751	.9808	.9242
6	1.0562	.9808	.9808
7	.9522	.9055	.9335
8	.8316	.8131	.8402
9	2.6749	2.6179	2.1845
10	2.6621	2.5095	2.3232
11	2.696	2.4756	.6642
12	2.6282	.6554	2.1735
13	2.4756	.4321	2.0805
14	2.2291	.2656	2.0111
15	2.2977	.4988	1.9982
16	2.3061	2.2539	1.9547
17	.8145	.7973	.7602
18	.7421		.6878
19	.8962	1.0974	.9425
20	1.307	1.3443	1.3256
21	1.2883	1.2883	1.2883
22	1.3443	1.3014	1.2883
23	1.1694		1.1576
24	1.0829		.9619
Max	2.696	2.6179	2.3232
Min	.7421	.2656	.6642
Avg	1.5291	1.1990	1.2959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 206 / KALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.4377	1.4377	1.3014
2	1.4377	1.4335	1.2826
3	1.4146	1.4003	1.2826
4	1.419	1.3957	1.2826
5	1.4901	1.4335	1.358
6	1.5497	1.475	1.4563
7	1.3491	1.3121	1.4563
8	1.0534	1.0608	1.1458
9	3.199	4.0278	2.4086
10	3.0283	3.4248	2.7199
11	3.6599	3.0203	3.0312
12	3.5528	2.8147	2.6052
13	3.3524		2.3594
14		1.1883	2.2996
15			2.9473
16		2.9473	2.9447
17	1.2357	.9214	.9774
18	1.0454		.8682
19	1.1765	.9774	1.262
20	1.7924	1.0456	1.6057
21	1.8484	.9709	1.643
22	1.8111	1.7364	1.6617
23	1.6617		1.5123
24	1.475	1.5123	1.363
Max	3.6599	4.0278	3.0312
Min	1.0454	.9214	.8682
Avg	1.9043	1.7768	1.7823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 201 / 11 KV NAGARPALIKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.2634	2.3244	
2	2.1391	2.1811	.8859
3	2.0797	2.0249	.8413
4	2.0588	2.002	.815
5	2.0245	1.9967	.8505
6	2.0016	2.0279	.8859
7	1.9624	2.0233	.9214
8	2.1338	2.3335	.9114
9	2.0603	2.1422	.9568
10	2.2214	2.0911	1.1088
11	2.4043	2.1155	1.1827
12	2.492	2.0256	1.1827
13	2.5202	2.1712	1.1827
14	2.524	2.0614	1.2567
15	2.5919	1.0692	
16	2.553	2.3403	1.4045
17	2.492	2.0104	1.2567
18	2.6437	1.9044	1.182
19	2.9379	2.4425	1.6834
20	3.4172	1.3748	1.576
21	3.1093	2.5819	1.3611
22	2.7678	2.3754	1.2178
23	2.6383	2.3053	1.1462
24	2.4116	2.2771	.9816
Max	3.4172	2.5819	1.6834
Min	1.9624	1.0692	.815
Avg	2.4353	2.0918	1.1269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 202 / 11 KV KRISHNA GHAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0883	1.0974	
2	1.0441	1.0166	.7087
3	.9914	.9519	.7087
4	.9496	.9465	.7087
5	.9374	.9282	.7087
6	.9899	.9397	.7087
7	.8825	.9507	.7522
8	.9519	1.0295	.7087
9	.9484	.9343	.7087
10	1.083	1.0738	1.0349
11	1.1805	1.0289	1.0349
12	1.0311	.9891	.8871
13	1.1066	1.0235	1.0349
14	1.2064	.9442	1.0349
15	1.1538	.4877	1.0349
16	1.2041	1.0326	.8871
17	1.2034	.8992	.961
18	1.1805	.8779	1.1104
19	1.3115	.8841	1.3611
20	1.5265	.6775	1.3611
21	1.4235	1.2963	1.1462
22	1.3519	1.2178	.9671
23	1.2849	1.0746	.9313
24	1.1705	1.0738	.4557
Max	1.5265	1.2963	1.3611
Min	.8825	.4877	.4557
Avg	1.1334	.9740	.9111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 203 / 11 KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.492	2.5842	
2	2.4067	2.4562	.9922
3	2.314	2.3358	1.0166
4	2.2199	2.3213	.9922
5	2.2054	2.303	1.0029
6	2.2184	2.2756	.9922
7	2.3472	2.3449	1.0985
8	2.3198	2.6116	1.0277
9	2.3388	2.4044	1.134
10	2.7381	2.5408	1.2567
11	2.8761	2.582	1.4045
12	3.1093	2.4051	1.4784
13	3.0551	2.2877	1.3306
14	2.9637	2.3616	1.4045
15	2.9675	1.1934	1.4045
16	3.0056	2.5865	1.3306
17	2.9645	2.3076	1.3306
18	3.0262	1.6293	1.4266
19	3.3029	2.6124	1.6461
20	3.4484	1.4716	1.6827
21	3.3036	2.7214	1.4998
22	3.1497	2.6276	1.4266
23	3.0445	2.5057	1.3535
24	2.6909	2.5316	1.0277
Max	3.4484	2.7214	1.6827
Min	2.2054	1.1934	.9922
Avg	2.7712	2.3334	1.2722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 204 / 11 KV HIGH WAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7781	.7705	
2	.7304	.7103	.4252
3	.7213	.7034	.4252
4	.716	.7011	.4298
5	.6752	.6969	.3898
6	.6714	.7232	.3898
7	.7198	.7777	.4908
8	.7701	.8109	.4961
9	.8185	.7503	.4961
10	.9938	.8905	.5914
11	1.1313	.9983	.6653
12	1.1412	1.0151	.7392
13	1.2376	1.0277	.8131
14	1.2467	.9953	.7392
15	1.3165	.3487	.8131
16	1.2585	.9107	.8131
17	1.1705	.8978	.7392
18	1.121	.8341	.724
19	1.1553	.9122	.8326
20	1.1881	.349	.7964
21	1.0837	.8985	.6516
22	1.0182	.8459	.6154
23	.9576	.2934	.5792
24	.8569	.7427	.4908
Max	1.3165	1.0277	.8326
Min	.6714	.2934	.3898
Avg	.9782	.7752	.6151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 205 / 11 KV WAKHAN ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9404	.9812	
2	.9129	.9237	.3898
3	.8634	.8768	.3856
4	.8254	.8783	.394
5	.8261	.8753	.3982
6	.8178	.8532	.3856
7	1.0067	.8962	.3898
8	1.0478	.8722	.3544
9	1.0178	.7804	.3544
10	1.0784	.7438	.3696
11	1.0738	.7331	.5175
12	1.0601	.7224	
13	1.0616	.7392	.5175
14	1.054	.7438	.4435
15	1.0525	.3536	.5175
16	1.0601	.7148	.4435
17	1.086	.6508	.5175
18	1.0715	.5791	.543
19	1.1751	.7789	.5068
20	.8063	.551	.6154
21	1.3409	.9693	.6154
22	1.1538	.9633	.5792
23	1.1047	.9095	.5068
24	.9922	.977	.3506
Max	1.3409	.9812	.6154
Min	.8063	.3536	.3506
Avg	1.0179	.7945	.4589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 206 / 11 KV COTTAGE HOSPITAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.6749	2.4577	
2	2.4855	2.3297	.9214
3	2.1826	2.1887	.8413
4	2.0836	2.1468	.815
5	2.01	2.1102	.815
6	2.0294	2.1438	.8505
7	2.1422	2.1971	1.0387
8	2.1696	2.2886	1.0631
9	2.4234	2.3312	1.1694
10	2.7709	2.633	1.4784
11	3.2785	2.7252	1.4784
12	3.2899	2.729	1.6263
13	3.4134	2.7267	1.5524
14	3.4233	2.633	1.5524
15	3.2861	1.3161	1.5524
16	3.3318	2.7496	1.4784
17	3.2374	2.4508	1.3306
18	3.104	2.2275	1.3443
19	3.2868	2.4203	1.6057
20	3.5482	1.4274	1.5684
21	3.3235	2.684	1.419
22	3.1459	2.5362	1.3443
23	3.2206	2.3937	1.2323
24	3.0087	2.4737	1.0277
Max	3.5482	2.7496	1.6263
Min	2.01	1.3161	.815
Avg	2.8696	2.3467	1.2655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 207 / 11 KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4732	.5323	
2	.4382	.5292	.2303
3	.4123	.33	.1417
4	.328	.1894	.1753
5	.346	.2614	.2103
6	.5015	.5296	.4031
7	.4996	.5312	.2303
8	.4901	.5038	.2279
9	.5156	.5289	.2303
10	.5301	.5327	.2263
11	.5297	.5304	.2263
12	.5141	.5312	.2263
13	.5301	.5293	.2263
14	.5278	.4919	.2263
15	.5278	.2298	.2263
16	.5297	.3399	.2263
17	.532	.2613	.1478
18	.5289	.1981	.1829
19	.5148	.1916	.2614
20	.5308	.1513	.2587
21	.5304	.527	.2587
22	.5102	.5217	.2378
23	.5016	.4195	.1848
24	.5042	.53	.2481
Max	.532	.5327	.4031
Min	.328	.1513	.1417
Avg	.4936	.4134	.2267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 208 / 11 KV Chawadi Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	.2804	.3292
2	.2454	.2926
3	.2103	.2926
4	.2279	.2926
5	.2303	.2926
6	.2279	.2926
7	.2629	.2926
8	.298	.2743
9	.3224	.2743
10	.4066	.2957
11	.5175	.3696
12	.499	.3326
13	.499	.3326
14	.499	.3326
15	.462	
16	.462	.3142
17	.4805	.2957
18	.5121	.2804
19	.5487	.3506
20	.567	
21	.4755	.333
22	.4024	.333
23	.3841	
24	.3224	.3475
Max	.567	.3696
Min	.2103	.2743
Avg	.3893	.3119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 207 / 11 KV Vadoli AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0017	
2	.0514	.0171	
3	.0343	.0171	
4	.0343	.0171	
5	.0343	.0171	
6	.0514	.0171	
7	.0343	.0017	
8	.0343	.0171	
9	1.2346	1.2517	.12
10	1.2517	1.3032	.1372
11	1.2003	1.286	.1372
12	1.0974	1.2346	.1372
13	1.0631	1.0802	.1372
14	1.0288	1.0288	.1372
15	1.0288	1.0117	.8916
16	.9774	.9774	.7716
17	.0343	.0343	.0343
18	.0171	.0343	.0343
19	.0171	.0343	.0343
20	.0171	.0343	.0343
21	.0171	.0343	.0171
22	.0171	.0343	.0171
23	.0017	.0343	.0171
24	.0514	.0171	
Max	1.2517	1.3032	.8916
Min	.0017	.0017	.0171
Avg	.3909	.3974	.1772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 258001 / 220/33KV Ogalewadi SS

Feeder No / Name : 204 / Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	.3502	.3243
2	.3445	.3269
3	.346	.3361
4	.3445	.3406
5	.3547	.3544
6	.3582	.3555
7	.3746	.3483
8	.3814	.3365
9	.5453	.3387
10	.743	.33
11	.7968	.3372
12	.7457	.3387
13	.4984	.3048
14	.6973	.3014
15	.6706	.2907
16	.6405	.3307
17	.6264	.3578
18	.5567	.3422
19	.4851	.3376
20	.4047	.3429
21	.3913	.3471
22	.349	.3445
23	.3422	.3464
24	.3357	.3414
Max	.7968	.3578
Min	.3357	.2907
Avg	.4868	.3356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 258001 / 220/33KV Ogalewadi SS

Feeder No / Name : 403 / 33 KV KARAD TOWN

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	25.3956	24.9052	
2	23.8294	23.1962	4.8371
3	22.1788	21.7673	4.6273
4	21.0769	21.0128	4.5713
5	20.6128	20.5864	4.4696
6	20.9088	21.2814	4.5713
7	21.1866	21.3295	5.1578
8	23.2968	21.8336	4.8371
9	22.9698	22.7698	5.1029
10	24.6754	22.8178	6.2094
11	27.3823	23.9838	6.7084
12	29.0181	23.9547	6.7638
13	29.6777	23.8597	6.8747
14	29.6354	23.5563	6.8747
15	29.3188	17.5583	5.7105
16	29.3479	24.8303	6.9856
17	29.4559	21.8359	6.653
18	28.9084	20.259	6.4472
19	29.4994	20.1132	7.6829
20	***	19.9589	7.8978
21	***	26.773	6.9845
22	***	25.8688	6.3935
23	28.6786	23.2357	6.1248
24	27.5806	20.6414	4.784
Max	32.38	26.773	7.8978
Min	20.6128	17.5583	4.4696
Avg	26.6604	22.4137	5.9682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 201 / KRISHNA HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3086	.415	.3086
2	.3086	.415	.3086
3	.3086	.415	.3086
4	.3086	.415	.3086
5	.3429	.4527	.3086
6	.4115	.5093	.3601
7	.5144	.5093	.4801
8	.583	.6413	.6516
9	.7922	.7545	.7922
10	.8299	.811	.8676
11	.3961	.811	.7733
12	.3772	.3584	.3961
13	.3395	.3395	.3395
14	.3395	.3206	.6036
15	.3961		.7733
16	.7545	.1509	.6979
17	.6602	.4973	.547
18	.5093	.4801	.5658
19	.5093	.4287	.5093
20	.5658		.4715
21	.5281	.4287	.4715
22	.4715	.4115	.4715
23	.4527	.3429	.3961
24	.3429	.4527	.3258
Max	.8299	.811	.8676
Min	.3086	.1509	.3086
Avg	.4730	.4709	.5015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 202 / MALKAPUR Gaonthan
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.7353	1.0288
2	1.5432	1.6975	1.0288
3	1.5432	1.6975	
4	1.5432	1.6975	1.3717
5	1.6461	1.7353	1.4746
6	1.7147	1.8107	1.749
7	1.749	1.8861	1.7147
8	1.8861	1.8107	1.2346
9	2.2445	2.2634	1.3203
10	2.452	2.2068	1.2826
11	2.4897	.9808	2.6406
12	2.3388		2.4897
13	2.2257		2.3765
14	2.2822		2.3577
15	2.5274		2.3388
16	2.3011		2.5431
17	2.1691		2.1538
18	2.0748	1.2003	2.2314
19	2.1502	2.0062	2.0851
20	2.4897		2.2546
21	2.4143	2.0576	2.0328
22	2.3011	1.8861	1.9959
23	2.1125	1.0974	1.8484
24	1.749	1.8861	1.1145
Max	2.5274	2.2634	2.6406
Min	1.5432	.9808	1.0288
Avg	2.0621	1.7444	1.8551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 203 / Goleshwar Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0943	.0686
2	.0686	.0754	.0686
3	.0686	.0754	.0686
4	.0686	.0943	.0686
5	.0686	.0943	.0686
6	.0857	.1132	.0857
7	.0857	.1132	.1029
8	.0857	.1132	.1029
9	.679	.6036	.3772
10	.5658	.5847	.4904
11	.547	.5093	.5281
12	.679	.3961	.5093
13	.6602	.3961	.4904
14	.6224	.3772	.4715
15	.6036		.4527
16	.5847	.2641	.4115
17	.0754	.0686	.0686
18	.0754	.0686	.0716
19	.0754	.0686	.0895
20	.1132		.0895
21	.1132	.0686	.0895
22	.1132	.0686	.0895
23	.0943	.0686	.0895
24	.0686	.0943	.0686
Max	.679	.6036	.5281
Min	.0686	.0686	.0686
Avg	.2613	.2005	.2092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 204 / Goleshwar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5658	.4801
2	.5144	.5658	.4801
3	.5144	.5658	.4801
4	.5144	.5281	.4801
5	.5487	.5281	.5487
6	.6173	.6413	.6859
7	.6859	.7545	.6516
8	.583	.6413	.6173
9	.6036	.6036	.6413
10	.6413	.5847	.6413
11	.6036		.6413
12	.5658		.6036
13	.6036		.5658
14	.6036	.6036	.5658
15	.6036		.5281
16	.6224	.5281	.5611
17	.5281	.4973	.5792
18	.5658	.4801	.543
19	.6413	.583	.6584
20	.7922		
21	.7545		
22	.7545		
23	.679		
24	.5487	.6413	.5144
Max	.7922	.7545	.6859
Min	.5144	.4801	.4801
Avg	.6085	.5820	.5734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 205 / AAGASHIVNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.2449	.8573
2	1.3032	1.2071	.8573
3	1.3032	1.2071	.8573
4	1.3032	1.1694	.8573
5	1.3032	1.1317	.8573
6	1.3717	1.1317	1.0288
7	1.2689	1.0562	.9945
8	1.2003	1.0562	.8916
9	1.7353	1.1317	1.1694
10	1.6975	1.0562	1.4523
11	1.7164	.8299	1.4712
12	1.5655	.7167	1.0562
13	1.6598	.7545	1.1506
14	1.6975	.7545	1.3203
15	1.6975		1.5089
16	1.6975	.8299	1.5203
17	1.6975	.7545	1.5565
18	1.6598	.8916	1.4661
19	1.6598	1.2003	1.6095
20	1.5844		1.4266
21	1.5844	1.166	1.3306
22	1.5089	1.0974	1.2382
23	1.4335	1.0288	1.1458
24	1.3717	1.358	.8916
Max	1.7353	1.358	1.6095
Min	1.2003	.7167	.8573
Avg	1.5135	1.0352	1.1881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 206 / Koyana Industrial Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2641	.2058
2	.2401	.2641	.2058
3	.2401	.2641	.2058
4	.2229	.2641	.2058
5	.2229	.2263	.2058
6	.2229	.2263	.2229
7	.2229	.2263	.2229
8	.2229	.2263	.2229
9	.3772	.2263	.3395
10	.415	.2263	.3772
11	.415	.1886	.3395
12	.415	.2263	.3772
13	.3395	.2263	.3395
14	.415	.2263	.3395
15	.415		.3772
16	.415	.2263	.415
17	.415	.2058	.3772
18	.3772	.2058	.3772
19	.3018	.2058	.3395
20	.3018		.3018
21	.2829	.2058	.3018
22	.2641	.2058	.3018
23	.2641	.2058	.3018
24	.2401	.2641	.2058
Max	.415	.2641	.415
Min	.2229	.1886	.2058
Avg	.3120	.2276	.2962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 207 / 11 KV Malkapur water works NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1509	.12
2	.1372	.1509	.1372
3	.1543	.1509	.12
4	.1372	.0189	.1543
5	.0514	.0189	.0171
6	.1715	.1698	.1543
7	.1715	.1886	.1543
8	.1543	.1698	.1372
9	.1698	.1509	.1509
10	.1886	.2263	.1698
11	.2641	.2263	.2829
12	.2263	.1886	.3206
13	.1698	.132	.2075
14	.1698	.1886	.2641
15	.1886		.3018
16	.2075	.0943	.2218
17	.1698	.1543	.1848
18	.1886	.2229	.2587
19	.2641	.1543	.2402
20	.2263		.1867
21	.1698	.1372	.1494
22	.1698	.1372	.1494
23	.1698	.1543	.168
24	.1372	.1698	.1372
Max	.2641	.2263	.3206
Min	.0514	.0189	.0171
Avg	.1748	.1525	.1828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 201 / Supane AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.1956	2.0567	1.1469
2	2.13	1.9919	1.1469
3	2.0972	1.9757	1.0978
4	2.0153	1.9271	1.1142
5	2.0317	1.9757	1.1469
6	2.4249	2.2348	1.3272
7	2.5396	2.4291	1.6549
8	2.343	2.4615	1.7368
9	.1781	.2294	.1619
10	.2267	.2294	.1509
11	.0324	.0492	.1457
12	.0324		
13	.0324		
14	.1619		
15	.1781		
16	.1781	.2294	.1457
17	.1943		.1457
18	.2267		
19	.2267	.2458	.1781
20	.2753	.2458	.1781
21	.2591	.213	.2105
22	.2429	.213	.1943
23	2.3644	.8684	1.2308
24	2.2775	2.3482	1.3108
Max	2.5396	2.4615	1.7368
Min	.0324	.0492	.1457
Avg	1.0360	1.2180	.7592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 202 / Khodashi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0534	1.0164	.3881
2	.4024	.9979	.3881
3	.961	.9795	.3881
4	.9795	.9979	.3881
5	.9795	1.0164	.3881
6	1.1088	1.0903	.4805
7	1.1883	1.3121	.5914
8	1.0719	1.2012	1.1088
9	1.1273	1.1458	1.2012
10	1.1088	1.0164	1.1643
11	1.1643	1.1273	1.3169
12	.961	.8131	
13	1.0349		.4887
14	1.0349	.8501	.4115
15	1.0349		.4458
16	1.2012	.924	1.1568
17	1.1273	.9055	1.0692
18	1.2197		
19	1.3306	1.0534	1.4003
20	1.5524	.5544	1.587
21	1.5524	.5544	1.419
22	1.5339		1.4712
23	1.2936	.4805	1.3392
24	1.1643	1.1643	.4251
Max	1.5524	1.3121	1.587
Min	.4024	.4805	.3881
Avg	1.1328	.9600	.8644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 203 / SAHYADRI HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	
2	.1509	.0754	
3	.0754	.0754	
4	.0754	.0754	
5	.0754	.0754	
6	.0754	.0566	
7	.0754	.1886	
8	.132	.0943	
9	.1509	.0943	
10	.1886	.2452	.132
11	.1698	.1886	.1886
12	.1698	.1886	
13	.1886	.0943	.1886
14	.1509	.0943	.1886
15	.1698		.1698
16	.1886	.2075	.1698
17	.1886		.1886
18	.1698		
19	.1509	.0754	.1698
20	.132	.132	.1132
21	.132	.1698	.0754
22	.1509	.1132	.0754
23	.0754		.0754
24	.0566	.0754	
Max	.1886	.2452	.1886
Min	.0566	.0566	.0754
Avg	.1320	.1198	.1446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 205 / Sangam LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
1	.3772	.1509
2	.3772	
3	.3772	
4	.3772	
5	.3772	
6	.3772	
7	.3772	
8	.3734	
10	.2218	
11	.2218	
12	.1478	
13	.3881	
14	.3881	
15	.3881	
Max	.3881	.1509
Min	.1478	.1509
Avg	.3407	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 206 / Supane Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7133	.7023	.5853
2	.695	.6697	.5487
3	.6767	.6516	.5487
4	.6767	.6516	.5487
5	.6767	.6697	.567
6	.7682	.724	.6584
7	.8413	.788	.8048
8	.8326	.7442	.7682
9	.7537	.6984	.7522
10	.7291	.6371	.6661
11	.7209	.6036	.6173
12	.7449	.3353	
13	.6316	.4096	.6173
14	.6464	.3481	.639
15	.7373		.6371
16	.6802	.6539	.6173
17	.7125	.7042	.6173
18	.7287	.7209	
19	.8987	.8764	.8309
20	1.1462	1.0242	.9991
21	1.0974	.9877	1.0059
22	1.0059	.924	.9709
23	.8589	.6584	.8029
24	.7499		.6584
Max	1.1462	1.0242	1.0059
Min	.6316	.3353	.5487
Avg	.7801	.6901	.7028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 201 / VAHAGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.0719	1.8233	1.1717
2	1.989	1.8233	1.1069
3	1.9662	1.7604	1.078
4	2.0119	1.7101	1.1174
5	1.989	1.8023	1.1203
6	2.1548	1.8623	1.2003
7	2.4577	1.9433	1.2631
8	2.431	2.1548	1.2146
9	.0701	.0709	.0724
10	.0716	.0701	.0625
11	.0701	.0701	.0648
12	.0709	.0709	.0497
13	.0537	.0709	.0514
14	.0537	.0701	.0686
15	.0526	.0709	.0686
16	.0537	.0709	.0686
17	.0503	.0709	.0686
18	.0514	.0716	.0709
19	.0686	.0724	.0701
20	.0867	.0724	.0709
21	.0678	.0724	.0876
22	.0678	.0724	.0709
23	1.9006	1.1336	1.1736
24	2.2939	1.8138	1.2631
Max	2.4577	2.1548	1.2631
Min	.0503	.0701	.0497
Avg	.9231	.7843	.5273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 202 / Vahagaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4733	.5175	.4527
2	.4607	.499	.4338
3	.4733	.4805	.4338
4	.4784	.4805	.4904
5	.4207	.462	.4904
6	.5028	.4938	.5175
7	.5201	.5788	.5487
8	.4908	.5175	.462
9	.4607	.4733	.3696
10	.4805	.4075	.4435
11	.5093	.4382	.4854
12	.5093	.4207	.5041
13	.4066	.4382	.4435
14	.4805	.4252	.4251
15	.4805	.4207	.439
16	.5175	.3544	.4854
17	.499	.4207	.4344
18	.5228	.4435	.443
19	.6535	.5359	.5375
20	.7095	.6653	.6516
21	.7468	.5975	.5721
22	.6722	.5359	.5434
23	.6348	.4805	.5375
24	.4908	.5601	.4715
Max	.7468	.6653	.6516
Min	.4066	.3544	.3696
Avg	.5248	.4853	.4840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 203 / ALFA-LAVAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.003	.0027	.0021
2		.0027	.0023
3	.0031	.0027	.0021
4		.0027	.0021
5	.003	.0027	.0021
6	.0032	.0027	.0022
7		.0027	.0021
8	.003	.0027	.0021
9	.0023		.0021
10	.0022	.003	.0027
11	.0021		.0027
12	.0022	.0032	.0027
13	.0023		.0027
14	.0022	.003	.0027
15	.0021		.0027
16	.0023	.0031	.0027
17	.0027	.0025	.0027
18	.0027	.0021	.003
19	.0027	.0021	
20	.0027	.0021	.0032
21	.0027	.0021	.003
22	.0027	.0021	
23	.0027	.0023	.0031
24	.003	.0027	.0021
Max	.0032	.0032	.0032
Min	.0021	.0021	.0021
Avg	.0026	.0026	.0025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 204 / Taswade East

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2629	.1829	.12
2	.0886	.1829	.1006
3	.0886	.1448	.1219
4	.0876	.1448	.1166
5	.0886	.1267	.1286
6	.0895	.1448	.1296
7	.0886	.1097	.1
8	.1753	.1294	.2829
9	.3155	.1772	.4527
10	.3772	.1772	.4108
11	.4527	.2629	.4805
12	.5281	.1772	.5658
13	.3772	.2658	.3361
14	.3772	.2629	.3361
15	.3395	.1772	.3361
16	.2829	.2629	.3395
17	.2241	.1772	.2772
18	.1829	.0787	.0876
19	.2195	.1715	.2629
20	.2195	.1448	
21	.1829	.1158	.1227
22	.1829	.1014	.1227
23	.2195	.1448	.1753
24	.2629	.1829	.1448
Max	.5281	.2658	.5658
Min	.0876	.0787	.0876
Avg	.2381	.1686	.2413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 205 / Taswade West

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0402	.8962	.6859
2	.8764	.7468	.6173
3	.8859	.6413	.6104
4	.8764	.6036	.6859
5	.8764	.679	.7164
6	.8859	.7545	.7545
7	.9816	.8299	.7545
8	1.0402	.7842	.8299
9	.9465	.7712	1.0562
10	1.358	.7011	1.2323
11	1.5089	.8322	1.3443
12	1.2826	.8322	1.307
13	1.2071	.6661	1.1949
14	1.2826	.7087	1.4335
15	1.358		1.4563
16	1.2826	.6935	1.4937
17	1.1949	.7087	1.4563
18	1.1203	.6859	1.166
19	1.2696	.7545	1.1443
20	1.0829	.724	1.1218
21	1.0829	.7545	.9214
22	1.0456	.7545	.9536
23	1.1203	.724	1.0402
24	1.0402	1.1949	.724
Max	1.5089	1.1949	1.4937
Min	.8764	.6036	.6104
Avg	1.1103	.7583	1.0292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 206 / 11 KV Talbid Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0905	
2	.0876	.0905	
3	.0886	.0886	
4	.0876	.0701	
5	.0886	.0886	
6	.0876	.1086	
7	.0886	.0905	
8	.1052		
9	1.5089	1.5746	1.1363
10	1.4089	1.5089	1.2146
11	1.3927	1.442	1.278
12	1.2967		1.1271
13	1.2003	1.2407	.703
14	1.1717	1.1904	.7122
15	1.1544	1.0852	.6706
16	1.078	1.0852	.6706
17	.0549	.0886	.0709
18	.0543	.0857	.1063
19	.0549	.0876	.1052
20	.0709	.1052	.1063
21	.1086		.1227
22	.1097		.1063
23	.0905		.0886
24	.0876	.0914	
Max	1.5089	1.5746	1.278
Min	.0543	.0701	.0709
Avg	.4819	.5375	.5479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 207 / MIDC-III

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4557	.4527	.4763
2	.4207	.415	.4904
3	.3898	.3961	.4904
4	.3721	.415	.4527
5	.394	.3584	.4338
6	.3898	.3395	.4338
7	.5375	.415	.5093
8	.6068	.3772	.5847
9	.5609	.3506	.679
10	.9335	.4207	.7545
11	.9145	.4908	.8676
12	.8573	.4607	.9054
13	.6602	.4607	.7922
14	1.0479	.4908	.7545
15	.8573	.4908	.8676
16	.9526	.4908	.7922
17	.811	.4961	.9054
18	.7167	.4191	.631
19	.6413	.4338	.3898
20	.547	.4527	.5201
21	.4715	.5281	.4908
22	.5281	.4527	.5375
23	.547	.4715	.4908
24	.4557	.4715	.5281
Max	1.0479	.5281	.9054
Min	.3721	.3395	.3898
Avg	.6279	.4396	.6157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 208 / MIDC- IV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3395	.3018
2	.3189	.3206	.2987
3	.3366	.3018	.2772
4	.333	.2829	.2829
5	.3189	.3018	.3018
6	.3189	.3206	.2829
7	.298	.3018	.2452
8	.3506	.2829	.2641
9	.3544	.2481	.3395
10	.5906	.2658	.3772
11	.6036	.2804	.5093
12	.4715	.2303	.4527
13	.4527	.2303	.3772
14	.4715	.2328	.3772
15	.415	.2126	.4338
16	.4715	.2454	.3772
17	.3772	.2303	.3961
18	.3206	.2452	.2658
19	.3018	.2641	.3155
20	.3018	.3018	.298
21	.2829	.2829	.2303
22	.3395	.3206	.3155
23	.3584	.3395	.3467
24	.3681	.3395	.3206
Max	.6036	.3395	.5093
Min	.2829	.2126	.2303
Avg	.3794	.2801	.3328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 401 / HINDUSTAN

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	3.3265	3.2579	2.2634
2	3.3608	3.2579	2.2291
3	3.4168	3.3471	2.1719
4	3.3048	3.1276	2.0936
5	3.271	3.0727	2.0936
6	3.1367	3.2036	2.1719
7	3.1047	3.0727	2.0576
8	3.1602	2.4394	2.0936
9	3.4928	2.6326	3.4294
10	3.3722	2.7166	3.1276
11	3.4294	2.7721	3.4208
12	3.2579	2.2405	2.963
13	2.9424	2.1845	2.7984
14	3.2253	2.6057	2.7984
15	3.8295	2.4949	3.0178
16	3.658	2.6057	3.2036
17	3.3122	2.1845	3.2579
18	3.1276	2.3434	3.1602
19	3.4019	2.5463	3.4928
20	3.3122	2.4577	3.5288
21	3.3122	2.572	3.4374
22	3.3665	2.4577	3.3819
23	3.5082	2.32	3.4728
24	3.4374	3.2956	2.3434
Max	3.8295	3.3471	3.5288
Min	2.9424	2.1845	2.0576
Avg	3.3361	2.7170	2.8337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching

Station

Feeder No / Name : 201 / KARVE Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2641	
2	.2452	.2641	
3	.2263	.2641	
4	.2641	.2641	
5	.3206	.2829	
6	.3584	.3206	
7	.3395	.2829	
8	.2829	.2829	
9	2.1605	2.2809	
10	1.9509	2.0062	
11		2.0168	1.5432
12	1.8814	1.7086	1.7284
13	1.829	1.655	
14	1.829	1.6072	.7468
15			.6327
16	1.8061		1.713
17	.2452		.3018
18	.2641	.2452	.2641
19	.2641	.2452	.2641
20	.3206	.3018	.3772
21	.3206	.3018	.3395
22	.3018	.3018	.3018
23	.2829	.2263	.2829
24	.2641	.2641	
Max	2.1605	2.2809	1.7284
Min	.2263	.2263	.2641
Avg	.7274	.7327	.7080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching

Station

Feeder No / Name : 202 / TEMBHU LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.0062	1.9814	2.2184
2	2.037	2.1296	2.2685
3	2.0466	2.1033	1.1728
4	2.0466	2.0833	1.1431
5	2.0062	2.0833	1.1561
6	2.0466	2.2184	1.1717
7	2.0934	2.2184	1.1683
8	2.1715	2.2222	1.866
9	2.2085	2.3746	2.3434
10	2.0729	2.3028	
11		2.2862	2.372
12	2.0062	2.2298	1.2346
13	2.1548	.3601	1.2483
14	1.7375	1.9403	1.2342
15	1.2003	2.3746	1.2191
16	1.2346	1.1138	.8768
Max	2.2085	2.3746	2.372
Min	1.2003	.3601	.8768
Avg	1.9379	2.0014	1.5129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching

Station

Feeder No / Name : 206 / 11 KV Karve Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4805	.4805	.415
2	.4854	.4668	.4108
3	.4435	.462	.415
4	.4805	.4854	.4338
5	.5975	.5914	.4904
6	.8501	.8402	.7655
7	.7865	.7947	.7762
8	.6268	.6024	.6036
9	.5434	.4733	.4908
10	.463	.4287	
11		.3688	.3898
12	.4161	.3856	.4382
13	.4458	.3601	.4334
14	.4287	.4031	.4161
15	.4334		.443
16	.4115	.333	.3856
17	.4382	.3429	.407
18	.4359	.3856	.4458
19	.5784	.5373	.5784
20	.7602	.6219	.7023
21	.7023	.6348	.6468
22	.6908	.5788	.6468
23	.5544	.4668	.5228
24	.499	.5041	.4108
Max	.8501	.8402	.7762
Min	.4115	.333	.3856
Avg	.5457	.5021	.5073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254073 / 33/11 KV VADGAON H

Feeder No / Name : 201 / 11 KV VADGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4119	.3439	.333
2	.4119	.3475	.3506
3	.4119	.3475	.3582
4	.4477	.4024	.4163
5	.543	.4525	.4887
6	.5973	.543	.5792
7	.5434	.4961	.4961
8	.407	.3988	.3772
9	.373	.3944	.3315
10	.3239	.3647	.3239
11	.3041	.3481	.3077
12		.2883	.3113
13		.2401	.3239
14	.2204	.2321	.2785
15	.2204		.2785
16	.2035	.2486	.2622
17	.2429	.2486	.2915
18	.3277	.2458	.3041
19	.373	.373	.3856
20	.4908	.4382	.4733
21	.4961	.4733	.5083
22	.5014	.4252	.4784
23	.4784	.4031	.443
24	.4298	.3582	.3544
Max	.5973	.543	.5792
Min	.2035	.2321	.2622
Avg	.3982	.3658	.3773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254073 / 33/11 KV VADGAON H

Feeder No / Name : 202 / 11 KV VADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2075	.132	.1698
2	.2263	.132	.1698
3	.2263	.132	.1698
4	.2263	.132	.1698
5	.2075	.132	.1886
6	.2263	.1509	.1886
7	.2241	.1698	.1886
8	.2241	.2075	.1886
9	1.0364	.9145	.9808
10	.9214	.9682	.9389
11	.9682	.9536	.8398
12	.9122	.7287	.8002
13	.8398	.7788	.9242
14	.8288	.7649	.631
15	.7613		.6036
16	.7716	.8573	.6859
17	.1132	.1494	.1509
18	.1509	.1698	.1494
19	.1886	.168	.1509
20	.1886	.1867	.1698
21	.1886	.1698	.1698
22	.1886	.1698	.1509
23	.1886	.1509	.1524
24	.2263	.132	.1509
Max	1.0364	.9682	.9808
Min	.1132	.132	.1494
Avg	.4267	.3674	.3785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256011 / 110 KV TEMBHU

Feeder No / Name : 204 / TEMBHU Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2378	.2587
2	.2587	.2402	.2614
3	.2614	.2427	.2427
4	.2772	.2402	.2587
5	.3292	.2587	.2587
6	.3982	.2743	.4024
7	.3366	.3012	.3582
8	.3467	.2774	.3506
9	.3086	.2743	.3401
10	.2561	.2214	.2429
11		.208	.2713
12	.2812		.2294
13	.2439		.213
14	.2469		.2105
15	.2656		.2713
16	.3315		.2458
17	.2915	.3113	.2623
18	.2932	.3149	.3239
19	.3277	.39	.3978
20	.3814	.443	.4508
21	.3224	.4119	.3721
22	.3292	.3292	.3077
23	.3174	.2957	.2957
24	.2772	.2587	.2772
Max	.3982	.443	.4508
Min	.2439	.208	.2105
Avg	.3018	.2911	.2960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 201 / MUNDHA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.9814	
2	2.0576	1.9814	
3	2.0576	1.9509	
4	2.0576	1.9509	
5	2.0576	1.9814	
6	2.1262	2.0576	
7	2.2977	2.1033	
8	2.1434	1.6766	
9	.0857	.0762	.8402
10	.0914	.0857	.9145
11	.0914	.0857	.9145
12	.1219	.0857	.0762
13	.1677	.0857	.0914
14	.1829	.1372	.0914
15	.1829	.1715	.0914
16	.1829	.1715	.061
17	.1677	.2058	.0762
18	.1219	.2058	.0762
19	.1219	.2229	.0762
20	.1219	.1753	.0762
21	.1372	.1402	.0762
22	.1372	.1052	.0914
23	1.89		1.3108
24	2.0576	1.9814	
Max	2.2977	2.1033	1.3108
Min	.0857	.0762	.061
Avg	.9466	.8530	.3243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 202 / LIS

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.2134		.1886
10	.2439		.1677
11	.2896		.1219
12	.3353		.1219
13	.2896		.1372
14	.2743	.2058	.1372
15	.2743	.2401	.0762
16	.2743	.2401	.0762
Max	.3353	.2401	.1886
Min	.2134	.2058	.0762
Avg	.2743	.2287	.1284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 204 / MARALI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4458	.3506
2	.4287	.4458	.3506
3	.4287	.4458	.3506
4	.4287	.4458	.3506
5	.4458	.4801	.3429
6	.4801	.4801	.4287
7	.4458	.4287	.4458
8	.4287	.4115	.4801
9	.4458	.4115	.463
10	.4458	.4287	.4801
11	.4287	.4287	.4801
12	.5144	.3429	.4801
13	.4801	.1372	.4973
14	.5316	.3429	.4973
15	.5487	.4287	.4973
16	.5487	.4287	.4458
17	.5316	.4458	.463
18	.583	.5144	.5487
19	.6344	.631	.6001
20	.6859	.6661	.6344
21	.6516	.5258	.583
22	.6001	.4801	.5487
23	.4973	.3944	.4287
24	.463	.463	.3681
Max	.6859	.6661	.6344
Min	.4287	.1372	.3429
Avg	.5044	.4439	.4632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 206 / SOMAIDEVI LIS EXPRESS

PURELY LIS FEEDERS

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
1	.6859	.0351
2	.6859	.0351
3	.6859	.0171
4	.6859	.0175
5	.7202	.0171
6	.7716	.0171
7	1.1317	.0171
8	1.0517	
9	1.0669	
10	1.0364	.2572
11	1.0364	.3353
12	1.0517	.3353
13	1.0364	.3353
14	1.0212	.0305
15	1.0059	.0305
16	.7621	.0305
Max	1.1317	.3353
Min	.6859	.0171
Avg	.9022	.1079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 201 / 11 KV Kalgaon Gaothan
Feeder KV- 11 / OUTGOING**GAOTHAN FEEDER**

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3155	.2947	.2507
2	.3155	.2947	.2507
3	.3121	.2915	.2507
4	.3121	.2915	.2507
5	.3155	.3121	.2715
6	.3761	.394	.3361
7	.443	.443	.3696
8	.407	.3944	.3475
9	.1017	.3429	.4252
10	.1174	.2458	.394
11	.3521		.3403
12	.3239		.3403
13	.3125		.3045
14	.1581		.2865
15	.2984		.2774
16	.3401		.2713
17	.192		.3052
18	.3725	.39	.3353
19	.463	.4706	.4527
20	.6516	.499	.5729
21	.6401	.5544	.5544
22	.5487	.4572	.4435
23	.3544	.2896	.3142
24	.3155	.3155	.2454
Max	.6516	.5544	.5729
Min	.1017	.2458	.2454
Avg	.3475	.3695	.3413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 202 / 11 KV Jinti Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1402	.156	
2	.1402	.156	.0716
3	.1387	.1372	.0716
4	.1387	.1372	.0716
5	.1402	.156	.0724
6	.1433	.1791	.0747
7	.1595	.2303	.1478
8	.1696	.2401	.1097
9	.1357	.1715	.0709
10	.1341	.1638	.0716
11	.1341	.1698	.0537
12	.1457	.1635	.1433
13	.1457	.1389	
14	.1265	.1235	
15	.1326		
16	.1619	.08	
17	.144	.0686	.2035
18	.192	.1526	.1677
19	.2401	.2353	.218
20	.3077	.2587	.2218
21	.2926	.2587	.1478
22	.2378	.2195	.1848
23	.1949	.1267	.1478
24	.1402	.1753	.1227
Max	.3077	.2587	.2218
Min	.1265	.0686	.0537
Avg	.1682	.1695	.1249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 203 / SANBUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3155	.2947	.2328
2	.3155	.2774	
3	.3121	.2743	
4	.3121	.2915	
5	.3155	.3121	
6	.394	.394	
7	.443	.4252	
8	.39	.4115	.0914
9	.3391	.3772	.1063
10	.3353	.3441	.394
11	.285	.2315	.2507
12	.3077	.1783	.2507
13	.3077	.1852	
14	.2688	.1389	
15	.2818		.1907
16	.3239		.2374
17	.3361		
18	.4001	.1017	.2012
19	.463	.4344	.3688
20	.6335	.5359	.6653
21	.6584	.5175	.5914
22	.5487	.3658	.499
23	.3721	.2534	.3511
24	.3155	.3155	.2279
Max	.6584	.5359	.6653
Min	.2688	.1017	.0914
Avg	.3739	.3171	.3106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 204 / TALMAVALE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4207	.3988	.3045
2	.4207	.3988	.3045
3	.3814	.3772	.3045
4	.3814	.3772	.3045
5	.3856	.4161	.3258
6	.4835	.5373	.3921
7	.4784	.5316	.4108
8	.4748	.5144	.4207
9	.4239	.463	.443
10	.4527	.426	.4119
11	.4694	.3858	.176
12	.421	.3864	.197
13	.502	.3086	.1612
14	.4428	.2932	.197
15	.3812		.156
16	.4049	.2721	.1357
17	.3841		.4239
18	.4321		.4694
19	.5316	.4344	.5868
20	.724	.4805	.6468
21	.6401	.6283	.5914
22	.5853	.5121	.5175
23	.4784	.3439	.4066
24	.4207	.4207	.298
Max	.724	.6283	.6468
Min	.3812	.2721	.1357
Avg	.4634	.4241	.3577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 205 / Sanbur Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.373	.3258	.0709
10	.3856	.2949	.0537
11	.3521	.1852	.0716
12	.3401	.1337	.0537
13	.2267	.1543	.0537
14	.2688		.0537
15	.2486		.052
16	.2915		.0509
Max	.3856	.3258	.0716
Min	.2267	.1337	.0509
Avg	.3108	.2188	.0575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 206 / 11 KV Kalgaon Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	.2454	.2254
2	.2279	.2254
3	.1907	.2229
4	.1907	.2401
5	.1928	.2254
6	.2507	.2328
7	.3721	
8	.3391	.1543
23	.2303	
24	.2454	.2279
Max	.3721	.2401
Min	.1907	.1543
Avg	.2485	.2193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 201 / 11 KV Mandure Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2454		.2427
2	.2103		.2454
3	.2103		.2454
4	.2103		
5	.2126		.2427
6	.2835	.2622	.3155
7	.3189		.3467
8	.3224	.1943	.3467
9	.3224	.2294	.3814
10	.2683	.3155	
11	.3086		
12	.2683		
13	.2347		
15	.2683		
16	.2683		
17	.3086		
18	.3506	.3544	
19		.5014	.4656
20	.6805	.5731	
21	.6024	.4961	
22	.4961	.4252	
23	.3018	.3506	
24	.2481	.2294	.2804
Max	.6805	.5731	.4656
Min	.2103	.1943	.2427
Avg	.3155	.3574	.3113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112] BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 202 / LIS

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	2.0553	
2	1.949	
3	1.949	
4	1.9281	
5	1.9631	
6	2.0908	1.0395
7	2.2325	
8	2.1384	.1581
23	1.2209	
24	2.1033	1.3565
Max	2.2325	1.3565
Min	1.2209	.1581
Avg	1.9630	.8514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 203 / ADUL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8413		.6661
2	.8063		.6588
3	.8413		.631
4	.7712		.6588
5	.8764		.7712
6	.8764	.9774	.8669
7	.9214	.9412	.8954
8	1.0387	.8238	.8596
9	.9313	.8505	.8596
10	.9214	.7712	
11	.9214		
12	1.134		
13	1.0277		
14	.9568		
15	.9922		
16	.9214		
17	.9568		
18	.9922	1.0277	
19		1.1462	1.3611
20	1.5364	1.2536	
21	1.3169	1.182	
22	1.3169	1.0631	
23	1.134	.8505	
24	.8413	.8688	.7011
Max	1.5364	1.2536	1.3611
Min	.7712	.7712	.631
Avg	.9945	.9797	.8118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 204 / HELWAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4908		.3155
2	.4557		.1052
3	.4607		.104
4	.4557		.1052
5			.1052
6	.4908	.5316	.1063
7	.5959	.6805	.1417
8	.6447	.7164	.3224
9	.5731	.6447	.3582
10		.6024	
11	.567		
12	.5316		
13	.567		
14	.567		
15	.4961		
16	.4607		
17	.6024		
18	.7087		
19		.5959	.6805
20	1.1706	.815	
21	1.0974	.7522	
22	.9774		
23	.6447	.4961	
24	.5258	.5316	.3814
Max	1.1706	.815	.6805
Min	.4557	.4961	.104
Avg	.6230	.6366	.2478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 205 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2481		.2454
2	.2103		.2103
3	.2126		.2103
4	.2126		.208
5	.2126		.2103
6	.2481	.2149	.2103
7	.2835	.2896	.2835
8	.3582	.3258	.3224
9	.4298	.3258	.394
10	.439	.3544	
11	.5121		
12	.5487		
13	.4706		
14	.2896		
15	.362		
16	.3258		
17	.2896		
18	.2534	.2481	
19		.2835	.2149
20	.2149		
21	.1772	.1772	
22	.2534	.2507	
23	.2896	.2804	
24	.2481	.3258	.2774
Max	.5487	.3544	.394
Min	.1772	.1772	.208
Avg	.3083	.2797	.2533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 206 / 11 KV Mandure Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1772		.0701
2	.1402		.0701
3	.1417		.007
4	.1402		.0701
5	.1772		.0701
6	.2103	.1772	.0701
7	.3155	.2126	.0701
8	.2804	.2126	.0709
9		.0122	
10	.0122	.0701	
11	.0122		
12	.0122		
13	.0122		
15	.0122		
16	.0137		
17	.0137		
18	.0137	.9114	
20	.0137		
21	.013		
22	.0122		
23	.0709		
24	.1753	.0709	.0701
Max	.3155	.9114	.0709
Min	.0122	.0122	.007
Avg	.0938	.2381	.0632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 207 / 11 KV Helwak Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.0072	
7		.0072	
8		.0053	
9	1.0277	1.2757	.1052
10		1.262	
11	1.4723		
12	1.5424		
13	1.5424		
14	1.5424		
15	1.4723		
16	1.4022		
17	.0053		
18	.0061		
20	.0069		
21	.0069		
22	.0072		
23	.0065		
24		.0065	
Max	1.5424	1.2757	.1052
Min	.0053	.0053	.1052
Avg	.7724	.4273	.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 208 / Patan Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5959		.567
2	.567		.5609
3	.5609		.5258
4	.5959		.5258
5	.6024		.5959
6		.724	.6661
7	.6379	.7602	.7164
8	.6805	.6805	.6447
9	.6447	.6089	.6447
10	.6447	.5959	
11	.6805		
12	.6805		
13	.6805		
14	.6447		
15	.6447		
16	.6447		
17	.6805		
18	.6805	.9214	
19		.9671	.788
20	.905	.9774	
21	.8326	.8954	
22	.7964	.7796	
23	.724	.5959	
24	.5959	.6089	.5959
Max	.905	.9774	.788
Min	.5609	.5959	.5258
Avg	.6691	.7596	.6210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 402 / MARALI

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-MAY-17
HR	Load (MW)
12	.3121
13	.3086
14	.3086
15	.3086
16	.3086
Max	.3121
Min	.3086
Avg	.3093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 201 / Rasati Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0732	.0709
2	.1097	.0716	.0701
3	.0739	.0701	.0693
4	.0739	.0686	.0686
5	.0747	.0671	.0701
6	.0754	.1029	.1433
7	.1132	.1402	.1829
8	.112	.208	.1791
9	.0366	.1753	.1734
10	.0693	.1006	.1677
11	.2321		
12	.1989		
13	.16		.061
14	.1638		.0926
15	.1296		.1158
16	.1189		.1158
17	.1486		.0857
18	.192	.1966	.1524
19	.2454	.2401	.2427
20	.2561	.2481	.2561
21	.2561	.2149	.2507
22	.1829	.1448	.181
23	.1402	.0709	.1097
24	.1086	.1109	.0701
Max	.2561	.2481	.2561
Min	.0366	.0671	.061
Avg	.1409	.1355	.1331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 202 / KOYANA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1311	.0937	.0937
2	.1296	.0949	.0949
3	.128	.096	.0937
4	.125	.0937	.096
5	.1219	.0914	.0937
6	.1387		.1235
7	.1387		.1875
8	.1696		.16
9	.1372		.16
10	.1296		.1562
11	.1326		
12	.1265		
13	.1235		.144
14	.125		.1372
15	.1265		.1124
16	.1486		.1276
17	.141		.1417
18	.1486	.2187	.1814
19	.2683		.2214
20	.3155	.2241	.3086
21	.2804	.1966	.2374
22		.1677	
23		.1219	.0701
24	.1341	.0949	.0926
Max	.3155	.2241	.3086
Min	.1219	.0914	.0701
Avg	.1555	.1358	.1445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 203 / Rasati Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.2347	.0983	.0309
10	.2949	.0972	.064
11	.3315		
12	.2949		
13	.3277		.0857
14	.3429		.0834
15	.3688		.1097
16	.3647		.1189
Max	.3688	.0983	.1189
Min	.2347	.0972	.0309
Avg	.3200	.0978	.0821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 201 / CHAFAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.12
2	.1715	.1524	.12
3	.1715	.1524	.12
4	.1715	.1524	.12
5	.1715	.1524	.12
6	.1715	.1715	.1372
7	.1715	.1905	.1543
8	.2058	.1905	.1543
9	.2058	.1905	.1372
10	.2058	.1543	.1543
11	.1715		.1524
12	.1715		.1524
13	.1715		.1524
14	.1715		.1524
15	.1715	.1372	.1524
16	.1334	.1543	.1715
17	.1334	.1715	.1524
18	.2096	.1886	.1905
19	.2286	.2058	.2096
20	.2667		.2477
21	.2477	.1543	.2096
22	.2286	.1372	.1905
23	.1715	.12	.1715
24	.1715	.1524	.12
Max	.2667	.2058	.2477
Min	.1334	.12	.12
Avg	.1861	.1621	.1568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 202 / MASUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.105	.7545
2	.8573	1.105	.7545
3	.8573	1.105	.7545
4	.8573	1.105	.7545
5	.9431	1.105	.7545
6	1.0288	1.1431	.823
7	1.0288	1.1431	.8916
8	.9431	1.105	.9259
9	1.0288	.9526	.8916
10	1.0288	1.0631	.6859
11	1.1431	.9259	.9145
12	1.1431	.9945	.9526
13	1.0288	.9602	
14	1.105	.9259	.9907
15	1.1812	.8916	.9526
16	.9526	.8916	.9526
17	.9907	.9602	.9526
18	1.1431	.9945	.9526
19	1.3336	1.0974	
20	1.5242	.8916	1.3336
21	1.3336	1.0631	1.1812
22	1.3336	.9602	1.1812
23	1.2384	.8916	1.0669
24	1.0288	1.1431	.8573
Max	1.5242	1.1431	1.3336
Min	.8573	.8916	.6859
Avg	1.0796	1.0218	.9218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 203 / PAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3336	.6173
2	1.3717	1.3336	.6173
3	1.3717	1.3336	.6173
4	1.4575	1.3336	.6173
5	1.5432	1.3336	.6173
6	1.5432	1.5242	.6859
7	1.5432	1.9052	.7202
8	1.5432	1.7147	.823
9	2.4006	2.2862	1.5432
10	2.4006	2.1605	1.5432
11	2.6673	2.2291	1.6385
12	2.5911	2.2291	1.6385
13	2.4768	1.8861	1.6004
14	2.2862	1.8176	1.5242
15	2.3624	1.749	1.5242
16	2.2862	1.749	1.448
19	.1334	.0857	.0762
20	.1334	.0686	.0762
21	.1334	.0686	.0762
22	.1334	.0686	.0762
23	1.5242	.6516	.9907
24	1.3717	1.3336	.6173
Max	2.6673	2.2862	1.6385
Min	.1334	.0686	.0762
Avg	1.5748	1.3725	.8949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 204 / PERLE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4954	.3772
2	.4287	.4954	.3772
3	.4287	.4954	.3772
4	.5144	.4954	.3772
5	.5144	.4954	.3772
6	.5144	.5716	.5144
7	.5144	.6478	.5487
8	.5144	.5716	.4801
9	.4287	.6097	.3772
10	.4287	.4458	.3772
11	.4954	.4115	.4191
12	.4954	.4115	.4191
13	.4954	.3429	.381
14	.4954		.4191
15	.4954	.3772	.4954
16	.4954	.4115	.4191
17	.4954	.3772	.4191
18	.4954	.3772	.4191
19	.6097	.5144	.5716
20	.6859	.6173	.724
21	.6859	.5144	.6097
22	.6859	.4801	.5716
23	.5716	.4458	.5335
24	.4287	.4954	.3772
Max	.6859	.6478	.724
Min	.4287	.3429	.3772
Avg	.5144	.4826	.4568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 205 / VARADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1524	.0857
2	.0857	.1524	.0857
3	.0857	.1524	.0857
4	.0857	.1524	.0857
5	.0857	.1524	.0857
6	.0857	.1715	.1029
7	.0857	.1905	.1029
8	.0857	.1905	.1029
9	1.6289	1.7528	1.0974
10	1.6289	1.7147	1.1317
11	1.2955		1.2574
12	1.9814		1.3717
13	1.9052		1.448
14	1.7909		1.4861
15	1.829	1.2346	1.3717
16	1.7528	1.2346	1.3717
17	.1715	.1372	.1334
18	.1715	.1543	.1524
19	.1715	.1372	.1524
20	.1715	.1372	.1524
21	.1524	.1029	.1334
22	.1524	.12	.1334
23	.1524	.1029	.1334
24	.0857	.1524	.1029
Max	1.9814	1.7528	1.4861
Min	.0857	.1029	.0857
Avg	.6553	.4148	.5153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 206 / CHAFAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6097	.4458
2	.6859	.6097	.4458
3	.6859	.6097	.4458
4	.6859	.6097	.4458
5	.6859	.6097	.4458
6	.6859	.9907	.5487
7	.8573	1.3717	.6859
8	.8573	1.2955	.7545
9	.0857	.1143	.0857
10	.0857	.1029	.0857
11	.1334		.0953
12	.1334		.0953
13	.1334		.1143
14	.1143		.1143
15	.1143	.1029	.0953
16	.1143	.1029	.0953
17	.1143	.1029	.0953
18	.1334	.12	.1143
19	.1715	.12	.1524
20	.1715	.12	.1334
21	.1905	.12	.1334
22	.1715	.1372	.1334
23	.7621	.583	.6859
24	.6859	.6859	.5144
Max	.8573	1.3717	.7545
Min	.0857	.1029	.0857
Avg	.3811	.4559	.2901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 401 / UMESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
1	1.0288	
2	1.5432	
3	1.8004	
4	2.0576	
5	2.0576	
6	2.0576	
7	2.0576	
8	2.2634	
9	2.2634	
10	2.2634	1.4918
11	2.4577	.8002
12	2.4577	2.4577
13	2.4006	2.4006
14	2.4006	2.4006
15	2.4006	.2286
16	.2286	.2286
Max	2.4577	2.4577
Min	.2286	.2286
Avg	1.9837	1.4297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 201 / shamgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.8652	1.0753
2	1.6385	1.6956	1.0753
3	1.6385	1.7147	1.0595
4	1.6575	1.6956	1.085
5	1.8107	1.8004	1.1012
6	1.933	1.8652	1.1336
7	2.1262	2.0687	1.1363
8	2.1195	1.9448	1.2163
9	.0191	.0189	.0189
10	.0187	.017	
11	.0187	.0189	
12	.0189		
13	.0189	.0191	
14	.0191	.0187	
15	.0187		
16	.0187		
17	.0189		
18	.0189	.0189	
19	.0191	.0189	.0185
20	.0189	.0189	.0191
21	.0189	.0191	.0191
22	.0189	.0191	.0191
23	1.7804	1.1843	1.3426
24	1.7436	1.8652	1.0753
Max	2.1262	2.0687	1.3426
Min	.0187	.017	.0185
Avg	.7654	.8944	.7597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 202 / Helgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0633	.0686	.0533
2	.0617	.0686	.0533
3	.0633	.0663	.0572
4	.0617	.0678	.0594
5	.061	.0678	.0602
6	.0633	.0678	.0602
7	.0732	.0686	.0579
8	.0739	.0533	.0572
9	1.9719	1.6907	1.2763
10	2.0687	1.8351	
11	2.0348	1.6549	
12	1.7804		
13	1.7772		
14	1.6129	1.3283	
15	1.6057		
16	1.5061		
17	.0564		
18	.0617	.0549	.0564
19	.0602	.0587	.0625
20	.061	.0533	.0587
21	.061	.0503	.0556
22	.0587	.0511	.0549
23	.0686	.0556	.0572
24	.0732	.0686	.0518
Max	2.0687	1.8351	1.2763
Min	.0564	.0503	.0518
Avg	.6408	.3911	.1333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 203 / KONEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.4685	1.4706	.9907
2	1.4022	1.4706	.9907
3	1.4198	1.4529	.9907
4	1.406	1.4529	
5	1.5741	1.5023	1.0059
6	1.656	1.5813	1.0059
7	1.8278	1.7236	1.3169
8	2.2546	1.7185	1.2334
9	.0686	.052	.0164
10	.1063	.0701	
11	.1063	.0151	
12	.0838		
13	.0686		
14	.0693	.1052	
16	.0886		
17	.1052		
18	.0732	.0701	
19	.0543	.0701	
20	.0537	.0532	.0339
21	.0543	.0532	.0343
22	.0543	.0532	.017
23	1.4883	1.0494	.9934
24	1.4327	1.4706	.9907
Max	2.2546	1.7236	1.3169
Min	.0537	.0151	.0164
Avg	.7355	.8124	.7400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 204 / Shahapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.0133	.0156	.0181
10	.0149	.0149	
11	.0141	.0149	
12	.0151		
13	.0141		
14	.0143	.0141	
15	.0145		
16	.0139		
Max	.0151	.0156	.0181
Min	.0133	.0141	.0181
Avg	.0143	.0149	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 205 / MASUR VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5853	.4904	.4904
2	.5487	.4904	.4904
3	.5544	.4904	.4854
4	.5487	.4854	.4854
5	.543	.4854	.4854
6	.5853	.5601	.5228
7	.6516	.6653	.5487
8	.6767	.5853	.5853
9	.5729	.5853	.5487
10	.6154	.5373	
11	.6154	.543	
12	.5792		
13	.5853		
14	.543	.5068	
15	.5487		
16	.6089		
17	.6024		
18	.5959	.4961	
19	.6805	.695	.6379
20	.8131	.6468	.7842
21	.7167	.5975	.6722
22	.7545	.5601	.695
23	.679	.6036	.6283
24	.6516	.5281	.4904
Max	.8131	.695	.7842
Min	.543	.4854	.4854
Avg	.6190	.5554	.5700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 206 / Kalgaon Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.362	.4066	.3326
2	.362	.3696	.3326
3	.3658	.362	.3292
4	.3582	.362	.3292
5	.3982	.3582	.3292
6	.4298	.394	.3292
7	.4252	.4344	.3658
8	.407	.3467	.3582
9	.3563	.3506	.3772
10	.3353	.3391	
11	.407	.3052	
12	.3688		
13	.3978		
14	.4024	.3353	
16	.3353		
17	.3052		
18	.373	.3315	
19	.4161	.4706	.4409
20	.6154	.5068	.5792
21	.5853	.5175	.5175
22	.5853	.4435	.5175
23	.4755	.4066	.4435
24	.4435	.4435	.3696
Max	.6154	.5175	.5792
Min	.3052	.3052	.3292
Avg	.4135	.3939	.3968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 207 / Satyam Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0373	.0354
2	.0309	.0377	.0354
3	.0305	.0377	.0362
4	.0309	.4904	.0362
5	.0457	.0377	.037
6	.0457	.0377	.0373
7	.0324	.0309	.0156
8	.0181	.0152	.0135
9	.0347	.0324	.032
10	.0377	.0335	
11	.0377	.0324	
12	.0381		
13	.0149		
14	.0312	.0179	
15	.0566		
16	.0351		
17	.0381		
18	.0373	.0154	
19	.0377	.0358	.0366
20	.056	.0354	.0457
21	.037	.0347	.0526
22	.0354	.0347	.0526
23	.0362	.0351	.0543
24	.0309	.0532	.0354
Max	.0566	.4904	.0543
Min	.0149	.0152	.0135
Avg	.0358	.0571	.0371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 208 / kharade ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0495	.0533	.0495
2	.0541	.0533	.0495
3	.0541	.0533	.0533
4		.0518	.0533
5	.0533	.0518	.0533
6	.0686	.0518	.0812
7	.0812	.0823	.0549
8	.08	.0754	.0572
9	2.4691	2.4756	1.9227
10	2.8487	2.5819	
11	2.7808	2.6113	
12	2.8502		
13	2.713		
14	2.5819	2.3205	
15	2.4417		
16	2.4417		
17	.0686		
18	.0846	.064	
19	.0926	.072	.0686
20	.0937	.0743	.0743
21	.0625	.0754	.08
22	.0594	.0503	.0676
23	.0617	.0518	.0857
24	.0638	.0587	.0488
Max	2.8502	2.6113	1.9227
Min	.0495	.0503	.0488
Avg	.9633	.5741	.1867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 201 / BAMBAWADE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2804	.2804	.2629
2	.2804	.2804	.2454
3	.2804	.2804	.2454
4	.2804	.2804	.2454
5	.2804	.298	.2454
6	.333	.3506	.2629
7	.4031	.4557	.3506
8	.4733	.3856	.298
9	.3856	.4031	.298
10	.3506	.298	.3506
11	.3155	.298	.3506
12	.333	.298	.3506
13	.3681	.2804	.3506
14	.3155	.2629	.3155
15		.2804	.3155
16	.333	.3155	.1753
17	.298	.1402	.3155
18	.4207		.3506
19	.5083		.4733
20	.6135	.2454	.6135
21	.5784	.2454	.5434
22	.4908	.3506	.4908
23	.3681	.3155	.3506
24	.3155	.3155	.2804
Max	.6135	.4557	.6135
Min	.2804	.1402	.1753
Avg	.3742	.3027	.3367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 202 / TARALE -VG-

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3155	.2865	.298
2	.3155	.2686	.298
3	.3155	.2686	.2804
4	.3155	.2686	.2804
5	.3155	.2865	.3155
6	.3506	.3045	.3506
7	.3856	.3582	.3856
8	.3856	.3403	.3856
9	.3155	.3155	.3155
10	.3155	.2804	.3155
11	.3155	.2103	.3155
12	.3506	.3155	.3155
13	.3506	.3155	.3506
14	.3506	.2804	.333
15		.2804	.3155
16	.3045	.2804	.333
17	.3403	.2454	.3155
18	.3403	.2804	.3506
19	.3582	.3155	.3856
20	.4207	.3506	.4207
21	.394	.3506	.4207
22	.3582	.3506	.3856
23	.3224	.3155	.3506
24	.333	.3045	.3155
Max	.4207	.3582	.4207
Min	.3045	.2103	.2804
Avg	.3421	.2989	.3389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 203 / DUSALE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0716	.0701
2	.0701	.0716	.0701
3	.0701	.0716	.0701
4	.0701	.0716	.0701
5	.0701	.0895	.0701
6	.0701	.1075	.0876
7	.1052	.1254	.0876
8	.1052	.1433	.0876
9	.1052	.1052	.1052
10	.1052	.1052	.1402
11	.1052	.1402	.0701
12	.1052	.1052	.1402
13	.1052	.1052	.1052
14	.1052	.1052	.0701
15		.0701	.1052
16	.1075	.0701	.0701
17	.1075	.0701	.0701
18	.1075	.0701	.0701
19	.1254	.0876	.1052
20	.1578	.0876	.1753
21	.1612	.0876	.1227
22	.1433	.0876	.1052
23	.1075	.0701	.1052
24	.0701	.0716	.0701
Max	.1612	.1433	.1753
Min	.0701	.0701	.0701
Avg	.1022	.0913	.0935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 204 / BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
9	1.3117	1.4089	.5992
10	1.6518	1.6827	.5959
11	1.7166	1.587	.4049
12	1.6518	1.587	.4382
13	1.6518	1.5708	.664
14	1.6194	1.5546	.7773
15		1.4575	.9069
16	1.6907	1.004	.7935
Max	1.7166	1.6827	.9069
Min	1.3117	1.004	.4049
Avg	1.6134	1.4816	.6475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 205 / TARALE -AG-

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.4899	1.5249	
2	1.6126	1.442	
3	1.4899	1.442	
4	1.4899	1.442	
5	1.4899	1.442	
6	1.6032	1.442	
7	1.7004	1.4918	
8	1.668	1.6575	.7773
23	1.3923		1.1336
24	1.668	1.5083	
Max	1.7004	1.6575	1.1336
Min	1.3923	1.442	.7773
Avg	1.5604	1.4881	.9555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 201 / 11kv CHORE VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7545	.1867
2	.695	.6859	.1829
3	.695	.6859	.181
4	.695		.181
5	.7316	.7202	.2195
6	.8048	.7545	.2195
7	1.0082	.7888	.2172
8	.8413	.6859	.208
9	.7202	.3429	.2614
10	.9709	.3429	.2195
11	.905	.4854	.7316
12	.823	.5487	.8413
13	.7888	.4481	.7682
14	.7888	.4755	.7316
15	.7888	.3258	.9145
16	.8916	.4024	.7316
17	.9259	.4801	
18	.9602	.5853	.695
19	.9945		1.0242
20	1.0288		1.0242
21	.9602	.2987	.9877
22	.8916	.2614	.8779
23	.8573	.1867	.8048
24	.8215	.7888	.1867
Max	1.0288	.7888	1.0242
Min	.695	.1867	.181
Avg	.8473	.5261	.5390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 202 / 11kv VADGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.7695	2.0576	1.1797
2	1.749	2.0576	1.1336
3	1.757	2.0919	1.1142
4	1.8138	2.0919	1.1142
5	1.9006	2.0919	1.1469
6	1.9334	2.0919	1.1469
7	2.0645	2.0919	1.2452
8	2.0645	1.9547	1.2631
9	.0328	.0343	.0328
10	.0328	.0343	.0328
11	.0328	.0343	.0328
12		.0343	.0328
13		.0373	.0328
14	.0343	.0362	.0328
15	.0686	.0362	.0328
16	.0686	.0366	.0328
17	.0686	.0343	.0328
18	.0686	.0339	.0328
19	.0686	.0373	.0328
20	.0686	.0343	.0328
21	.0686	.0362	.0328
22	.0686	.0343	.0328
23	2.0576	1.2452	1.278
24	1.8023	2.0576	1.2125
Max	2.0645	2.0919	1.278
Min	.0328	.0339	.0328
Avg	.8906	.8469	.5122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 203 / 11kv SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0686	.0686
2	.1029	.0343	.0686
3	.1029	.0343	.0678
4	.1029	.0343	.0724
5	.1029	.0343	.1017
6	.1029	.0686	.1029
7	.1029	.0686	.1052
8	.1029	.0686	.1052
9	2.8837	2.915	.0972
10	2.982	3.0007	.1296
11	3.0476	2.7854	1.6032
12	3.2922	2.6558	1.587
13	3.3265	2.6216	1.6032
14	3.2922	2.556	1.587
15	3.2579	2.332	1.0688
16	2.7435	2.0317	
17	.0686	.0678	.0648
18	.0686	.0686	.0486
19	.0686		.0972
20	.0686	.0373	.0972
21		.0366	.0972
22	.0686	.0343	.0972
23	.0686	.0343	.0972
24	.112	.0686	.0343
Max	3.3265	3.0007	1.6032
Min	.0686	.0343	.0343
Avg	1.1379	.9416	.3914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 201 / Charegaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6588	.8684	.4973
2	.6588	.8848	.4973
3	.6588	.8745	.4973
4	.6588	.9175	.4973
5	.6588	.9503	.5304
6	.8322	.9503	.5506
7	1.1488	.9175	.6154
8	.9156	.8848	.6241
9	.2054	.132	.168
10	.1494	.1307	.1307
11	.1494	.1267	.112
12	.1494	.1307	.1132
13	.1494	.1132	.0934
14	.1494	.1132	.0934
15	.1509	.1307	.1132
16	.1509	.168	.1132
17	.1509	.0754	.132
18	.1698	.1132	.1494
19	.1886	.168	.1698
20	.1886	.1867	.1886
21	.1886	.2054	.1886
22	.1698	.168	
23	.9431	.5636	.7045
24	.6588	.852	.5243
Max	1.1488	.9503	.7045
Min	.1494	.0754	.0934
Avg	.4210	.4427	.3176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 202 / charegaon vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5959	.6584	.5792
2	.6089	.6219	.5731
3	.6089	.5914	.5249
4	.6089	.5914	.543
5	.6447	.6219	.5731
6	.6661	.6838	.6516
7	.7628	.7682	.7973
8	.7545	.8413	.7362
9	.6516	.6219	.7164
10	.6952	.5175	.7164
11	.6584	.567	.5973
12	.6283	.543	.5853
13	.6219	.5121	.5544
14	.5853	.4435	.5359
15	.6401	.462	.5487
16	.6219	.4805	.5729
17	.6219	.5611	.5853
18	.695	.7059	.6036
19	.924	.7619	.8779
20	1.0269		.9145
21	.9877		.9511
22	.8413		.8871
23	.7762		.6219
24	.6984	.695	.543
Max	1.0269	.8413	.9511
Min	.5853	.4435	.5249
Avg	.7052	.6125	.6579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 203 / Mazgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377
2	.0377	.0377	.0377
3	.0377	.0377	.0377
4	.0377	.0377	.0377
5	.0377	.0377	.0377
6	.0377	.0377	.0377
7	.0377	.0377	.0377
8	.0566	.0377	.0566
9	1.2574	1.7204	.8684
10	1.7101	1.7328	.9503
11	1.7204	1.6762	.8745
12	1.7814	1.4232	.9175
13	1.7695		.9393
14	1.6385	1.2003	.9503
15	1.4255	1.1336	.8848
16	1.3108	1.0688	.852
17	.0373	.0566	.0377
18	.0566	.0566	.0373
19	.0566	.056	.0377
20	.0566	.056	.0377
21	.0566	.056	.0373
22	.0377	.0566	.0377
23	.0377	.0377	.0373
24	.0377	.0377	.0377
Max	1.7814	1.7328	.9503
Min	.0373	.0377	.0373
Avg	.5546	.4639	.3274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 201 / Shahapur Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5525	.6097	.5335
2	.5335	.5716	.5144
3	.5335	.5716	.5144
4	.5525	.6097	.5335
5	.5716	.6287	.5716
6	.5906	.6859	.6413
7	.5281	.6413	.5788
8	.5121	.5975	.5487
9	.6468	.6908	.5068
10	.5973	.5014	.5373
11	.5611	.4294	.5611
12	.5973	.4835	.5014
13	.5194	.4163	.4298
14	.543	.5068	.4656
15	.5853		.5068
16	.2667	.5068	.4525
17	.5014	.3982	.4706
18	.5611	.4938	.5487
19	.7682	.7207	.6653
20	.9055	.7207	.7947
21	.8402	.7095	.7468
22	.7922		.7167
23	.7049	.5525	.6097
24	.5906	.6478	.5525
Max	.9055	.7207	.7947
Min	.2667	.3982	.4298
Avg	.5981	.5770	.5626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 202 / Shahapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0648	1.0802	.8993
2	1.0364	1.0364	.873
3	.9783	.9934	.8173
4	1.0059	.9659	.8025
5	1.0957	1.0235	.8322
6	1.2334	1.1111	.888
7	1.2643	1.2654	.9488
8	1.3272		.9877
9	.1143		.0762
10	.0953	.0762	.0762
11	.0953	.0572	.0762
12	.1143	.0762	.0762
13	.1143	.0762	.0572
14	.1143	.1334	.0572
15	.1334		.0572
16	.1334	.1334	
17	.1334	.1524	.0762
18	.1334	.1334	.0953
19		.1524	
20	.1334	.1715	.0953
21	.1143	.1524	.1143
22	.0953		.0762
23	1.1111	.9259	.8749
24	1.1265	1.1111	.9145
Max	1.3272	1.2654	.9877
Min	.0953	.0572	.0572
Avg	.5551	.5414	.4442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 203 / Riswad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0381
2	.0762	.0762	.0381
3	.0762	.0762	.0381
4	.0762	.0762	.0381
5	.0762	.0953	.0381
6	.0953	.0953	.0381
7	.0953	.0953	.0381
8	.0762	.0762	.0381
9	1.2654	1.1683	.8684
10	1.3904	1.1984	.9614
11	1.3272	1.0722	.7773
12	1.0802	.953	.7935
13	1.0031	.5424	.8583
14	.9602	.6716	.7773
15	.9065		.6882
16	.9414	.7876	.6748
17	.0762		.0762
18	.0953	.0572	.0762
19		.0762	.0953
20	.0953		.0953
21	.0953	.0572	
22	.0953	.0572	.1143
23	.0953	.0381	.1143
24	.0953	.0953	.0381
Max	1.3904	1.1984	.9614
Min	.0762	.0381	.0381
Avg	.4422	.3553	.3180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 301 / WING

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4344	.3292	.2957
2	.4344	.3292	.2587
3	.4344	.3292	.2587
4	.3544	.2957	.2587
5	.3544	.2926	.2587
6	.3544	.2957	.2896
7	.3772	.3658	.2865
8	.4435	.3696	.2587
9	.4805	.4435	.2957
10	.4805	.3696	.4066
11	.4805	.2957	.3696
12	.4805	.2957	.4024
13	.4435	.2987	.2926
14	.4435	.2614	.3658
15	.4435	.2987	.3658
16	.4805	.2987	.3696
17	.4066	.2614	.37
18	.3696	.2587	.3696
19	.3326	.2614	.3696
20	.5175	.3361	.4066
21	.4805	.3155	.4066
22	.4108	.3326	.3696
23	.3292	.2957	.3292
24	.4344	.3292	.2614
Max	.5175	.4435	.4066
Min	.3292	.2587	.2587
Avg	.4251	.3150	.3298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 302 / SHINDEWADI

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2195	.1848
2	.2172	.2218	.1478
3	.2172	.1848	.1848
4	.2126	.1848	.1848
5	.2126	.2218	.1848
6	.2481	.2218	.181
7	.2058	.2218	.1791
8	.2218	.2195	.1848
9	.2218	.2218	.1848
10	.2218	.1478	.1848
11	.2218		.1848
12	.2218	.1478	.1848
13	.2218	.112	.1829
14	.2587	.112	.2218
15	.2587	.1494	.2195
16	.2587	.1867	.2195
17	.2587	.1494	.1478
18	.1478	.1478	.1848
19	.1848	.1867	.2218
20	.2957	.2614	.2587
21	.2587	.2454	.2218
22	.2218	.2218	.2218
23	.2218	.1848	.2195
24	.2534	.2195	.1867
Max	.2957	.2614	.2587
Min	.1478	.112	.1478
Avg	.2299	.1909	.1949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 303 / INDUSTRIAL
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.5893	1.2567
2	1.3756	1.6263	1.1827
3	1.3756	1.5893	1.1088
4	1.3466	1.5893	1.2567
5	1.4175	1.5524	1.1827
6	1.4529	1.5524	1.1584
7	1.3375	1.4045	1.3253
8	1.4045	1.3535	1.5154
9	1.6263	1.7002	1.922
10	2.0328	1.1827	2.3285
11	2.1437	1.6263	2.1807
12	2.1948	1.4045	2.2177
13	2.2177	1.643	1.9022
14	1.9589	1.8671	1.9022
15	2.2085	1.5684	2.1948
16	2.2546	1.531	2.3777
17	2.4394	1.419	2.0485
18	1.9589	1.2567	1.7741
19	1.8111	1.1949	1.7002
20	1.8111	1.307	1.8656
21	1.7372	1.1218	1.7372
22	1.8111	1.2567	1.5524
23	1.5729	1.1827	1.5729
24	1.448	1.5524	1.307
Max	2.4394	1.8671	2.3777
Min	1.3375	1.1218	1.1088
Avg	1.7661	1.4613	1.6904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 304 / TUBE

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6516	.9877	1.2936
2	.5792	.961	1.2567
3	.5792	.9145	1.3676
4	.5316	.961	1.1088
5	.5316	.9145	1.4045
6	.5316	.9511	.9774
7	.4801	.6653	.5373
8	1.1827	.9979	1.4045
9	.8413	1.1088	1.1088
10	.924	.6283	1.5893
11	.961	.7762	1.2567
12	.8501	.924	1.1375
13	.9979	1.0082	1.134
14	.9979	.6722	1.2567
15	.924	.6722	.7392
16	.8779	1.0456	.9877
17	1.1458	.7095	1.6057
18	1.2567	.924	1.5524
19	1.2071	1.0829	1.3535
20	.7392	.9709	.7762
21	1.0349	.6661	.7762
22	.9897	1.1827	.7392
23	.8413	.6283	.7316
24	.6516	.9511	1.1576
Max	1.2567	1.1827	1.6057
Min	.4801	.6283	.5373
Avg	.8462	.8877	1.1355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 402 / GODREJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1629	.6036	.6099
2	.1629	.6036	.6653
3	.1629	.6653	.7762
4	.3189	.6584	.7207
5	.3189	.7207	.6653
6	.5316	.7207	.7059
7	.5658	.8316	.7522
8	1.7741	1.262	1.5524
9	1.6078	1.6632	1.4415
10	1.6461		1.9959
11	1.5524	1.4415	1.7187
12	1.4969	1.2197	1.6632
13	1.4969	1.2883	1.5364
14	1.1643	1.4563	1.1523
15	1.6078	1.2883	.9877
16	1.0534	1.0642	.5544
17	1.1643	.7842	.5544
18	.7762	.7762	.499
19	.7682	.7282	.5544
20	.6099	.6161	.439
21	.5544	.5784	.4481
22	.6099	.7207	.4435
23	.6099	.6653	.4938
24	.1629	.5487	.3921
Max	1.7741	1.6632	1.9959
Min	.1629	.5487	.3921
Avg	.8700	.9089	.8884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 403 / SUSSEN ASIA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9774	1.4415	1.6078
2	.9774	1.4815	1.5524
3	.8688	1.386	1.386
4	.8505	1.386	1.4415
5	.7442	1.386	1.5524
6	.7442	1.3306	1.3575
7	1.286	1.4969	1.5581
8	1.3306	1.6078	1.6078
9	1.7187	1.7741	1.6632
10	1.6632		1.8296
11	1.4415	1.4415	1.2357
12	1.4969	1.7187	1.4266
13	1.4969	1.6244	1.6632
14	16.0768	1.7924	1.6078
15	1.386	1.2883	1.6632
16	1.4415	1.7924	1.6078
17	1.7187	1.5684	1.7741
18	1.5524	1.6632	1.5912
19	1.7187	1.6804	1.7741
20	1.5524	1.3443	1.4415
21	1.5524	1.6301	1.5912
22	1.4661	1.7187	1.6632
23	1.4969	1.4969	1.4883
24	.9774	1.4266	1.5684
Max	16.0768	1.7924	1.8296
Min	.7442	1.2883	1.2357
Avg	1.9390	1.5425	1.5689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 301 / AHIRE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0686	.0686
2	.1132	.0686	.0686
3	.1132	.1029	.0686
4	.1132	.1029	.0686
5	.1132	.0686	.0686
6	.1132	.1029	.0686
7	.112	.1372	.0686
8	.112	.1029	.0686
9	2.2405	.168	2.1285
10	2.0919	1.3717	2.1285
11	2.0576	1.5089	2.2779
12	2.1605	1.5089	2.0911
13	1.9547	1.3717	1.8671
14	1.7147	1.3032	1.7551
15	1.7147	1.3032	1.7551
16	1.7147	1.3717	1.8671
17	.1029	.0686	.1132
18	.0686	.0686	.1132
19	.0686	.0686	.1132
20	.1029	.0686	.1132
21	.1029	.0686	.112
22	.1029	.0686	
23	.0686	.0686	
24	1.6804	.1029	.0686
Max	2.2405	1.5089	2.2779
Min	.0686	.0686	.0686
Avg	.7854	.4685	.7751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 302 / KHANDALA

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.2003	1.3032
2	1.0456	1.2003	1.3717
3	1.1203	1.0631	1.3032
4	1.1576	1.0974	1.2689
5	1.2323	1.3032	1.166
6	1.307	1.5089	1.0288
7	1.3817	1.2346	1.406
8	1.1203	1.3032	1.2346
9	1.4937	1.0631	1.2323
10	1.4403	.6859	1.1203
11	1.3717	.9602	1.1203
12	1.4403	1.1317	.9709
13	1.3717	.9259	1.1203
14	1.0288	1.3032	1.307
15	.6859	1.3032	1.2323
16	1.0974	.9945	1.6804
17	1.0288	1.0288	1.0082
18	1.2003	1.1317	1.1203
19	1.2003	1.2003	1.2696
20	2.0576	1.6804	1.7924
21	1.5432	1.5775	1.5684
22	1.406	1.2346	
23	1.0631	1.406	
24	1.0456	1.0631	1.3717
Max	2.0576	1.6804	1.7924
Min	.6859	.6859	.9709
Avg	1.2452	1.1917	1.2726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 303 / LOHOM

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0829	1.3717	1.2346
2	1.0456	1.3717	1.2689
3	1.1576	1.3032	1.2346
4	1.0829	1.2003	1.2346
5	1.0456	1.0631	1.2346
6	1.1576	1.1317	1.3032
7	1.419	1.1317	1.2689
8	1.6804	1.0974	1.166
9	1.7551	1.2346	1.5684
10	1.6461	1.0288	1.7177
11	1.6461	.1372	1.6804
12	1.7147	.5487	2.0911
13	1.3032	.4115	1.8671
14	1.749	.823	1.6804
15	1.3717	.8916	1.9044
16	1.6804	.9945	1.8671
17	1.7147	.823	1.7924
18	1.7147	.823	1.4937
19	1.749	1.1317	1.643
20	1.7147	1.2003	1.5684
21	1.6118	1.2346	1.7924
22	1.749	1.2346	
23	1.6804	1.2003	
24	1.1576	1.5775	1.2346
Max	1.7551	1.5775	2.0911
Min	1.0456	.1372	1.166
Avg	1.4846	1.0402	1.5385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 304 / TBK

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.112	.1372	.2058
2	.112	.1372	.2058
3	.112	.1029	.2058
4	.112	.1029	.2058
5	.112	.1029	.1715
6	.112	.1029	.1715
7	.112	.1029	.1372
8	.112	.1372	.1029
9	.2614	.2401	.2614
10	.2743	.2743	.2241
11	.2058	.2743	.2614
12		.1372	.1867
13	.1372		.2614
14	.2058	.2401	.2241
15	.2401	.2401	.1867
16	.2058	.2058	.2614
17	.2058	.2401	.2241
18	.2058	.2058	.1867
19	.2058	.2401	.2241
20	.1715	.1715	.1867
21	.1715	.2401	.1867
22	.2058	.2401	
23	.1715	.2058	
24	.112	.1372	.2058
Max	.2743	.2743	.2614
Min	.112	.1029	.1029
Avg	.1685	.1834	.2040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 305 / HITECH PLAST

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4854	.583	.6173
2	.4854	.583	.6173
3	.4854	.6173	.6173
4	.5228	.6173	.6173
5	.5228	.583	.5487
6	.5228	.6173	.583
7	.5228	.6173	.583
8	.3361	.5487	.0446
9	.5975	.4458	.3734
10	.6516	.5144	.2987
11	.6173	.4115	.2241
12	.5487	.3772	.4108
13	.5487	.5144	.3734
14	.5144	.4458	.4108
15	.4458		.4854
16	.583	.4458	.4481
17	.5487	.583	.4481
18	.583	.3429	.4108
19	.583	.6173	.5228
20	.6516	.583	.4854
21	.4801	.583	.4854
22	.583	.6173	
23	.583	.6516	
24	.4854	.583	.583
Max	.6516	.6516	.6173
Min	.3361	.3429	.0446
Avg	.5370	.5427	.4631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 401 / Panache Alluminium
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2572	.2058
2	.2241	.2572	.2058
3	.2241	.2572	.2058
4	.2241	.2572	.2058
5	.2241	.2572	.2058
6	.2241	.2572	.3086
7	.168	.2572	.2058
8	.168	.2572	.2058
9	.168	.3086	.3361
10	.2058		.3361
11	.2058	.2572	.5601
12	.3601	.4115	.5041
13	.3086	.3601	.3921
14	.2572	.3086	.3361
15	.3086	.3601	.3361
16	.3601	.4115	.5041
17	.3086	.3601	.3361
18	.3086	.2058	.3361
19	.2572	.2572	.3361
20	.2572	.4115	.3921
21	.3086	.2572	.2801
22	.2572	.2572	
23	.2572	.2572	
24	.2241	.2572	.2058
Max	.3601	.4115	.5601
Min	.168	.2058	.2058
Avg	.2514	.2930	.3155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 301 / 22 KV MUKUND EXPRESS
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4108	.5658
2	.5658	.4854	.6036
3	.4527	.4435	.4904
4	.415	.5228	.415
5	.415	.5175	.4527
6	.5281	.4435	.5281
7	.3772	.4435	.5658
8	.3772	.3696	.4904
9	.3018	.3772	.5975
10	.415	.5658	.7167
11		.2263	.8048
12	.4904	.4904	.679
13	.3361	.6036	.679
14	.6413	.5281	.5281
15	.4904	.4904	.3395
16	.4527	.4527	.5601
17	.4527	.3696	.5601
18	.4108	.4904	.5228
19	.4854	.5658	.5601
20	.4481	.5281	.5228
21	.5601	.5281	.4854
22	.7095	.4527	.4854
23	.2561	.5281	.5175
24	.415	.4481	.6036
Max	.7095	.6036	.8048
Min	.2561	.2263	.3395
Avg	.4543	.4701	.5531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 302 / 22 KV ANDHURI AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	5.2759	5.3704	2.6216
2	5.0465	5.3041	2.6216
3	4.9878	5.1448	2.5263
4	4.9554	5.0793	2.6216
5	5.1776	4.4239	2.7526
6	5.8013	5.4035	3.1459
7	6.4643	5.9339	4.6079
8	6.2986		4.3427
9	.415		.2641
10	.3772	.3734	.2641
11		.3772	.2218
12	.3772	.3772	.2614
13	.3395	.3018	.2614
14	.3772	.2641	.2195
15	.3395	.2641	.2641
16	.3772	.2641	.3326
17	.415	.2957	.4108
18	.4854	.3018	.3734
19	.4108	.3395	.5228
20	.5975	.5281	.5601
21	.5228	.4904	.4854
22	.4481	.4527	.4854
23	5.5693	1.1576	3.408
24	.4527	5.4698	2.4939
Max	6.4643	5.9339	4.6079
Min	.3395	.2641	.2195
Avg	2.4136	2.1781	1.5029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 303 / 22 KV LONAND MIDC
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.1584	1.419	1.7177
2	1.1222	1.3443	1.6804
3	1.086	1.307	1.6057
4	1.1584	1.3817	1.4784
5	1.0974	1.3817	1.531
6	1.1458	1.307	1.4563
7	1.3306	1.3443	1.419
8	1.419	1.3443	1.3443
9	1.4563	1.4335	1.9616
10	1.4712	1.5466	3.0178
11		1.4335	1.3957
12	1.7353	1.3957	1.5844
13	1.5466	1.358	1.6221
14	1.7353	1.3957	1.5089
15	1.6057	1.9239	2.1502
16	1.8107	1.9616	2.2405
17	1.773	1.7353	2.5766
18	1.6804	1.773	3.5848
19	1.7177	1.6598	3.1367
20	1.643	1.773	1.0829
21	1.4937	1.7353	1.1576
22	1.6057	1.8107	1.0082
23	1.6804	1.7177	.9335
24	1.2437	1.4937	1.5684
Max	1.8107	1.9616	3.5848
Min	1.086	1.307	.9335
Avg	1.4659	1.5407	1.7818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 304 / 22 KV KHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4854	.4904
2	.5281	.4854	.4904
3	.5228	.4805	.4904
4	.5601	.4805	.5281
5	.6348	.6348	.6413
6	.9431	.9335	.8676
7	.9431	.8215	.8676
8	.7167	.5975	.7167
9	.6219	.5658	.6036
10	.5601	.5281	.6036
11		.0747	.6036
12	.5281	.5281	.4854
13	.4854		.5658
14		.4904	.5281
15	.4527	.5281	.6036
16	.6036	.4904	.5601
17	.6036	.5281	.4108
18	.5228		.4854
19	.7095	.1509	
20	.9335	.9054	.9335
21	.8962	.8676	.8215
22	.7468	.7545	.7468
23	.6348	.6413	.6348
24	.5658	.5601	.5281
Max	.9431	.9335	.9335
Min	.4527	.0747	.4108
Avg	.6491	.5697	.6177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 301 / 22 KV SOMANTHALI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6859	.823	.6173
2	.6859	.7545	.6173
3	.6173	.7545	.583
4	.583	.5144	.583
5	.5487	.5144	.6516
6	.6173	.5487	.6859
7	.6516	.6516	.6516
8	.6859	.6516	.7202
9	.7545		.8383
10	.823		.8383
11	.7545		.9145
12	.823	.5335	.9907
13	.823	.5716	.8383
14	.6516		.8002
15	.6173	.2286	.7621
16		.2286	
17			.724
18			.7621
19	.4458	.4115	.6859
20	.6173	.6859	.7888
21	.6173		.823
22	.8916	.6173	.8573
23		.7888	.823
24	.7202	2.9492	.7202
Max	.8916	2.9492	.9907
Min	.4458	.2286	.583
Avg	.6807	.7193	.7512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 302 / 22 KV KAMBALESHWAR

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2401	.3429
2	.2058	.2401	.3429
3	.2058	.2401	.3429
4	.2058	.2401	.3429
5	.2401	.2401	.3772
6	.3429	.3429	.4801
7	.4458	.4458	.6516
8	.4115	.4115	.6859
9			.1143
10	.0686		.1143
11	.0686		.0762
12		.1524	.0762
13		.1524	.0762
14			.0762
15	.0686	.2667	.0762
16		.4191	
17	.0686	.1029	.1143
18	.0686	.1029	.1143
19	.0686	.1372	.1905
20	.1029	.2743	.1715
21	.1029	.1029	.1715
22	.1029	.1029	.1715
23	.2401	.3772	.5487
24	.0686	.2401	.3772
Max	.4458	.4458	.6859
Min	.0686	.1029	.0762
Avg	.1733	.2416	.2624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 303 / 22 KV SASTEWADI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4115	.6516	.5487
2	.4115	.6516	.5487
3	.4115	.583	.5487
4	.4801	.583	.5487
5	.5487	.5487	.583
6	.5487	.6859	.6859
7	.583	.6859	.6516
8	.5144	.583	.5487
9	2.4006		3.7723
10	2.1948		4.039
11	2.915		2.8197
12	2.9492	.6478	3.658
13	2.9492	3.4294	3.6961
14	2.4348	3.2007	3.5056
15	.3772	3.2769	3.4294
16	2.4348	3.4294	
17	.4115	.3429	.4954
18	.4458	.0686	.5335
19	.583	.4801	.6097
20	.7545	.7202	.7545
21	.7545	.7202	.7545
22	.6859	.7202	.6859
23	.6516	.6516	
24	1.5089	.6516	.583
Max	2.9492	3.4294	4.039
Min	.3772	.0686	.4954
Avg	1.1817	1.1101	1.5455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 304 / 22 KV SANGAVI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.4403	1.2346
2		1.4403	1.2346
3		1.5089	1.3032
4		1.5775	1.3032
5		1.6461	1.4403
6		2.1262	2.0576
7		2.7435	2.2634
8		2.6749	2.4006
9			.3048
10	.2058		.2667
11	.2058	.2667	.2286
12		.2286	.2667
13		.2286	.2667
14		.1905	.0381
15	.2743	.2286	.2667
16		.2286	
17		.2058	.3048
18		.2743	.3048
19	.4115	.2743	.3429
20		.3429	.3772
21		.3429	.3772
22		.2743	.3086
23	1.3717	1.2346	1.4403
24		1.3717	1.2346
Max	1.3717	2.7435	2.4006
Min	.2058	.1905	.0381
Avg	.4938	.9477	.8507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 305 / 22 KV SOMANTHALI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4115	.4115
2	.3429	.4115	.4115
3	.3429	.4115	.4115
4	.3429	.3429	.4115
5	.3429	.3429	.4115
6	.4115	.4115	.4115
7	.4801	.4115	.4801
8	.3429	.4115	.4115
9			1.5242
10			1.7909
11	.3429	1.7528	1.6385
12	1.166	1.7528	1.3717
13		1.3336	1.6385
14	.823	1.2193	1.4861
15		1.3336	1.7528
16		1.5242	
17		.2058	.381
18	.823	.3429	.381
19	.0686	.4115	.4572
20	.0686	.4801	.5144
21	.4801	.4801	.4801
22	.4801	.4801	.4801
23	.4115	.4115	.4458
24	.823	.4115	.4115
Max	1.166	1.7528	1.7909
Min	.0686	.2058	.381
Avg	.4687	.6952	.7876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 306 / 22 KV somawar peth

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0343	.0343
2		.0343	.0343
3		.0343	.0343
4		.0343	.0343
5		.0343	.0343
6		.0343	.0343
7		.0343	.0343
8		.0343	.0343
9			.0381
10			.0381
11	.0343	.0381	.0381
12	.0343	.0381	.0381
13	.0343	.0381	.0381
14		.0381	.0381
15	.0343	.0381	.0381
16	.0343	.0381	
17	.0343	.0343	.0381
18	.0343	.0343	.0381
19	.0343	.0343	.0381
20	.0343	.0343	
21	.0343	.0343	
22	.0343	.0343	.0343
23	.0343	.0343	.0343
24		.0343	.0343
Max	.0343	.0381	.0381
Min	.0343	.0343	.0343
Avg	.0343	.0353	.0361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114] BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 301 / 22KV PHALTAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
8		1.7147
12		2.1338
20	2.3663	
Max	2.3663	2.1338
Min	2.3663	1.7147
Avg	2.3663	1.9243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114] BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 302 / 22KV Y. C. HIGHSCHOOL
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
8		1.9547
12		2.9721
20	2.6063	
Max	2.6063	2.9721
Min	2.6063	1.9547
Avg	2.6063	2.4634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114] BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 303 / 22 KV SAINAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
8		.2401
12		.2286
20	.2401	
Max	.2401	.2401
Min	.2401	.2286
Avg	.2401	.2344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114] BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 305 / 22 KV MORAYA MILK FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
8		.8916
12		1.0288
20	.9945	
Max	.9945	1.0288
Min	.9945	.8916
Avg	.9945	.9602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 301 / SAKHARWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.4387	2.9797	2.3472
2	2.4387	2.915	2.3167
3	2.5301	3.0864	2.3472
4	2.5911	3.155	2.3777
5	2.6216	3.3265	2.4387
6	2.9569	3.4008	2.8959
7	3.597	4.1495	3.3532
8	3.5665	3.7247	3.1703
9	.3429	.3353	.4801
10	.3086	.2439	.3086
11	.3429	.2743	.3086
12	.3086	.2743	.3429
13	.3772	.3658	
14	.3429	.2439	.3772
15	.3772	.2743	.3429
16	.3429	.2439	.3429
17	.3772	.2743	.3429
18	.3429	.3353	.3429
19	.3772	.3353	.3772
20	.4801	.4801	.3963
21	.5144	.4801	.3963
22	.4458	.4458	.3963
23	2.915	2.3472	2.3777
24	.3963	3.2579	2.3472
Max	3.597	4.1495	3.3532
Min	.3086	.2439	.3086
Avg	1.3055	1.5396	1.3360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 303 / NIMBHORE AG FEEDER

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4115	.3772
2	.3658	.4115	.3429
3	.3353	.4115	.3429
4	.3658	.4458	.3429
5	.3963	.4458	.3772
6	.4572	.5144	.4801
7	.4572	.5144	.4801
8	.4572	.5144	.4458
9	.4801	.1524	2.2672
10		.2134	2.6558
11	2.3777	2.0119	.2743
12	1.89	2.3167	2.3644
13		2.3472	2.5263
14		2.0729	2.5263
15	.2401	1.8595	2.2672
16		1.9509	2.1376
17	.3772	.3353	.4115
18	.1029	.3658	.4458
19	.1029	.3658	.4458
20	.583	.5144	.4877
21	.5144	.4801	.4572
22	.4801	.4801	.4268
23	.4458	.4115	.3963
24	1.2803	.4458	.3772
Max	2.3777	2.3472	2.6558
Min	.1029	.1524	.2743
Avg	.6038	.8330	.9857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 304 / WATHAR -NIMBLAK- AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.003	.0034	.0034
2	.003	.0034	.0034
3	.003	.0034	.0034
4	.003	.0034	.0034
5	.003	.0034	.0034
6	.003	.0034	.0034
7	.003	.0034	.0034
8	.003	.0034	.0034
9	3.5665	3.6275	3.2065
10	4.2372	3.6885	3.8218
11	4.0238	3.5665	3.7247
12	4.0543	3.5361	3.6275
13	3.7494	3.2007	3.1093
14	3.6885	3.0178	3.0121
15	3.6275	2.652	2.753
16	3.3532	2.5606	2.915
17	.0034	.003	.0034
18	.0034	.003	.0034
19	.0034	.003	.0034
20	.0034	.0034	.003
21	.0034	.0034	.003
22	.0034	.0034	.003
23	.0034	.0034	.003
24	2.5606	.0034	.0034
Max	4.2372	3.6885	3.8218
Min	.003	.003	.003
Avg	1.3712	1.0793	1.0926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 307 / 22 KV SAKHARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7202	.7202
2	.7545	.7202	.7202
3	.7202	.7202	.6859
4	.7202	.7545	.6859
5	.823	.8573	.7545
6	.9259	.9945	.8916
7	.7202	.823	.7545
8	.7888	.9259	.7888
9	.6516	.7545	.823
10	.7888	.823	.823
11	.8573	.7545	.7888
12	.7888	.7888	.823
13	.7202	.7202	.823
14	.7888	.6859	.7545
15	.7888	.7545	.7888
16	.823	.7888	.823
17	.9259	.823	.8573
18	.9259	.7888	.8573
19	.9259	.8916	.9259
20	1.0631	1.0288	.945
21	1.0288	.8573	1.0288
22	.9945	.8573	.9602
23	.8573	.7888	.8573
24	.7888	.7888	.7202
Max	1.0631	1.0288	1.0288
Min	.6516	.6859	.6859
Avg	.8302	.8088	.8167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 308 / 22 KV NANDAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715
2	.1715	.1715	.1715
3	.1715	.1715	.1715
4	.1715	.1715	.1715
5	.2058	.2058	.2058
6	.2058	.2401	.2401
7	.2058	.1372	.2058
8	.2058	.1715	.2058
9	.1029	.3086	.2058
10	.2058	.2743	.2058
11	.2401	.2401	.3086
12	.1715	.2401	.2058
13	.2058	.1905	.2401
14	.2058	.1715	.2058
15	.2401	.2401	.2401
16	.2667	.2058	.3086
17	.2058	.1715	.2743
18	.2058	.1372	.1715
19	.2058	.2401	.2058
20	.2743	.2743	.2401
21	.2743	.2401	.2401
22	.2401	.2058	.2401
23	.2401	.2058	.2058
24	.2058	.2058	.1715
Max	.2743	.3086	.3086
Min	.1029	.1372	.1715
Avg	.2083	.2080	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 309 / 22 KV NIMBHORE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2743
2	.2743	.2743	.2743
3	.2743	.2743	.2401
4	.2743	.2401	.2401
5	.2743	.3086	.2401
6	.2743	.3086	.2743
7	.2743	.3086	.3086
8	.2743	.3086	.2743
9	.2401	.2743	.2401
10	.2058	.2401	.2743
11	.2743	.2058	.2401
12	.2743	.2058	.3086
13	.3086	.2401	.2743
14	.3086	.2743	.2743
15	.3086	.2743	.2743
16	.2743	.2743	.2743
17	.2743	.2743	.3086
18	.3086	.2743	.3086
19	.3086	.3086	.3086
20	.4458	.4115	.4115
21	.3772	.3772	.3772
22	.3772	.3772	.3772
23	.3429	.3429	.3772
24	.2743	.3086	.2743
Max	.4458	.4115	.4115
Min	.2058	.2058	.2401
Avg	.2957	.2900	.2929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 403 / cummines india limited
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2858	.4001	.4572
2	.2858	.4001	.4572
3	.2858	.3429	.4001
4	.2858	.3429	.4001
5	.2858	.3429	.4572
6	.2858	.4001	.4001
7	.4001	.4001	.5144
8	.4572	.5144	.5716
9	.5144	.5716	.6287
10	.8573	.8002	.8573
11	.9145	.8002	.8573
12	.743	.8002	.8002
13	.6859	.8573	.8573
14	.8002	.4572	.8573
15	.743	.5716	.8002
16	.743	.8573	.743
17	.8002	.8002	.6287
18	.5144	.5716	.4572
19	.5144	.5716	.5144
20	.5144	.5716	.4572
21	.4572	.5144	.4572
22	.4572	.4572	.4572
23	.4572	.4572	.4001
24	.2858	.4572	.4572
Max	.9145	.8573	.8573
Min	.2858	.3429	.4001
Avg	.5239	.5525	.5787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 404 / tata cumines ltd

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2858	1.0288	1.2574
2	.2858	1.086	1.2574
3	.2858	1.086	1.2574
4	.2858	1.086	1.3146
5	.3429	1.3146	1.3717
6	1.3717	1.6575	1.5432
7	1.829	1.6575	1.7147
8	1.7147	1.6575	1.6575
9	1.7718	1.829	1.6575
10	1.9433	1.6575	1.5432
11	1.6575	1.8861	1.4861
12	1.9433	1.9433	1.829
13	1.7147	1.7718	1.6575
14	1.5432	1.7718	1.7147
15	1.829	1.829	1.6004
16	1.829	1.7147	1.8861
17	2.0005	1.8861	1.7147
18	1.829	1.7718	1.8861
19	2.0005	1.6575	1.7147
20	2.0005	1.7147	1.829
21	1.829	1.6004	1.5432
22	1.6575	1.7147	1.4861
23	1.1431	1.4289	1.3717
24	.2858	1.086	1.2574
Max	2.0005	1.9433	1.8861
Min	.2858	1.0288	1.2574
Avg	1.3908	1.5766	1.5646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 301 / 22KV Barad ag
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3018	.5281	.3018
2	.3018	.5281	.3772
3	.3018	.4527	.3772
4	.3018	.4527	.4527
5	.3395	.6036	.6036
6	.3395	.8676	.7167
7	.3772	1.3203	.8299
8	.3018	1.0562	.7167
9	.2263	.2641	.1886
10	.1886	.1886	.1886
11	.1886	.1886	.1886
12	.1886	.1886	.1886
13	.1886	.1886	.2263
14	.1886	.1886	.2263
15	.1886	.1886	.1886
16	.1886	.1886	.1886
17	.1886	.1886	.1886
18	.1886	.1886	.2263
19	.2641	.2263	.3395
20	.415	.3018	.3772
21	.415	.3018	.3395
22	.3395	.2641	.3395
23	.6413	.3395	.4904
24	.3018	.6036	.3018
Max	.6413	1.3203	.8299
Min	.1886	.1886	.1886
Avg	.2861	.4087	.3568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 302 / MUNJAWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5281	4.2627	3.546
2	.5281	4.1495	3.546
3	.5281	4.1495	3.6969
4	.6413	4.2627	3.9609
5	.7545	4.3759	4.225
6	.8676	4.8663	4.6399
7	.9054	5.5076	5.1303
8	.7545	5.6962	5.168
9	.6413	.5281	.5658
10	.6036	.4904	.4904
11	.4527	.3772	.5281
12	.4527	.3772	.4527
13	.4527	.3772	.3772
14	.4527	.3395	.415
15	.5281	.3772	.4527
16	.5658	.415	.4527
17	.4527	.415	.4904
18	.5658	.4904	.5281
19	.6413	.679	.679
20	.7545	.7922	.8299
21	.7167	.679	.7167
22	.6413	.6036	.6036
23	4.4136	3.4705	3.4328
24	.5281	4.4513	3.6214
Max	4.4136	5.6962	5.168
Min	.4527	.3395	.3772
Avg	.7655	2.1722	2.0229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 303 / ANDHRUD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	3.0178	.6036	.6036
2	3.0178	.6036	.6036
3	3.0178	.6036	.5658
4	3.1687	.679	.679
5	3.4328	.7922	.9054
6	3.6969	.8299	1.0562
7	3.9986	.9054	.8676
8	4.3759	.7545	.3772
9	4.1872	3.8477	3.7723
10	4.225	4.4136	4.3004
11	3.7723	4.3759	4.7908
12	3.8477	4.4136	4.3759
13	3.7723	4.2627	4.1495
14	3.7723	3.3951	3.7723
15	3.81	3.3196	3.6214
16	3.81	3.4705	3.4705
17	.415	.415	.4527
18	.6413	.4527	.5281
19	.7167	.7167	.7167
20	.9431	.7922	.9054
21	.7922	.7545	.7922
22	.7545	.679	.7167
23	.6413	.6413	.679
24	3.0178	.6036	.6413
Max	4.3759	4.4136	4.7908
Min	.415	.415	.3772
Avg	2.7852	1.7636	1.8060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 304 / Barad Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.679	.6036	.6036
2	.679	.6036	.5658
3	.679	.6036	.6036
4	.7545	.679	.679
5	.7922	.7167	.7545
6	.8676	.7922	.9054
7	.7167	.7922	.7922
8	.6413	.679	.679
9	.6036	.6036	.6036
10	.6036	.5658	.6413
11	.6413	.5658	.5281
12	.6036	.5658	.6413
13	.6413	.6036	.6036
14	.679	.5658	.5658
15		.5658	.5658
16	.6413	.4904	.6036
17	.6036	.5658	.6413
18	.679	.6413	.6413
19	.7545	.7167	.7922
20	.8676	.8299	.9431
21	.8676	.7922	.8299
22	.7922	.7167	.7922
23	.7167	.6413	.679
24	.679	.679	.6036
Max	.8676	.8299	.9431
Min	.6036	.4904	.5281
Avg	.7036	.6491	.6775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 305 / 22 KV GUNAWARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4527	.4904
2	.5281	.4527	.4527
3	.5281	.4527	.4527
4	.6413	.4904	.5281
5	.7545	.5658	.6413
6	.8676	.6413	.8676
7	.8299	.7545	.8299
8	.8299	.7545	.7545
9	.7167	.679	.679
10	.7167	.6036	.679
11	.6413	.5658	.6413
12	.5658	.5281	.4527
13	.5658	.5281	.5281
14	.5281	.4527	.5281
15	.5281	.3018	.5658
16	.5281	.3395	.5658
17	.6036	.3395	.6036
18	.6413	.415	.6036
19	.7545	.8676	.8299
20	.9808	.9431	.9808
21	.8299	.7167	.7545
22	.6413	.679	.6413
23	.5281	.5658	.6036
24	.5281	.4904	.5281
Max	.9808	.9431	.9808
Min	.5281	.3018	.4527
Avg	.6586	.5658	.6334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 306 / 22 KV Rajuri Gaothan
Feeder KV- 22 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509
2	.1509	.1509	.1509
3	.1886	.1509	.1509
4	.1886	.1886	.1509
5	.1886	.1886	.1886
6	.2263	.1886	.2263
7	.3018	.2263	.2263
8	.2641	.1886	.2263
9	.2263	.2263	.1886
10	.2641	.1886	.1509
11	.2263	.2263	.1886
12	.2263	.2263	
13	.2263	.2263	.1886
14	.1886	.1509	.1509
15	.1886	.1509	.1886
16	.1509	.1509	.1886
17	.1509	.1509	.1886
18	.1509	.1509	.1886
19	.2641	.2263	.2263
20	.2641	.2641	.3018
21	.2641	.2263	.2641
22	.2641	.2263	.2263
23	.1886	.1509	.1509
24	.1509	.1886	.1509
Max	.3018	.2641	.3018
Min	.1509	.1509	.1509
Avg	.2106	.1902	.1919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 307 / 22 KV Nimblak AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.2634	.2263	.1886
2	2.2634	.2263	.1886
3	2.3388	.2263	.1886
4	2.452	.2263	.1886
5	2.5652	.2641	.2263
6	2.7161	.2641	.2641
7	2.8292	.3018	.2263
8	3.0556	.2263	.1886
9	3.0933	2.4897	2.037
10	3.0178	2.9801	2.4897
11	3.131	2.6783	2.7161
12	2.9047	2.7161	2.6029
13	2.8292	2.7161	2.6406
14	2.8292	2.0748	2.2257
15	2.6783	2.3011	2.3011
16	2.6783	2.1879	2.3388
17	.1886	.1509	.1509
18	.1886	.2263	.1886
19	.2263	.2263	.2641
20	.3018	.2641	.3018
21	.3395	.2263	.2263
22	.2641	.1886	.2263
23	.2263	.1886	.1509
24	2.2634	.2263	.1886
Max	3.131	2.9801	2.7161
Min	.1886	.1509	.1509
Avg	1.9852	.9918	.9462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 301 / ADARKI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1029
2	.1029	.1029	.1029
3	.1029	.1029	.0686
4	.1029	.1029	.0686
5	.0686	.1029	.0686
6	.1029	.1029	.1372
7	.0686	.1029	.1029
8	.1029	.1029	.1029
9	1.6118	1.4746	1.5089
10	1.8176	1.6804	1.6461
11	1.7147	1.5432	1.6118
12	1.6461	1.406	1.4746
13	1.5089		1.3032
14	1.2346	1.0631	1.0974
15	1.2346	1.0631	1.0974
16	1.3375	1.0631	1.1317
17	.0686		.0686
18	.0686	.1029	.0686
19	.1029	.0686	.1029
20	.1715	.1372	.1715
21	.1372	.1029	.1372
22	.1372	.1029	.1372
23	.1029	.1029	.1029
24	.9259	.1029	.1029
Max	1.8176	1.6804	1.6461
Min	.0686	.0686	.0686
Avg	.6073	.4926	.5216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 302 / BIBI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.583	.6859	.5487
2	.6173	.6859	.5144
3	.6516	.6859	.5144
4	.6516	.6859	.5144
5	.6173	.7202	.583
6	.9259	1.166	.9259
7	1.2003	1.406	1.0974
8	1.0631	1.2003	1.0288
9	.0034	.0034	.0034
10	.0034	.0034	.0034
11	.0034	.0034	.0034
12	.0034	.0034	.0034
13	.0034		.0034
14	.0034	.0034	.0034
15	.0034	.0034	.0034
16	.0034	.0034	.0034
17	.0034	.0034	.0034
18	.0034	.0034	.0034
19	.0034	.0034	.0034
20	.0034	.0034	.0034
21	.0034	.0034	
22	.0034	.0034	.0034
23	.7545	.5487	.6173
24	.0034	.7545	.5487
Max	1.2003	1.406	1.0974
Min	.0034	.0034	.0034
Avg	.2965	.3732	.3016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 303 / MULIKWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1029
2	.1029	.1029	.1029
3	.1372	.1029	.1029
4	.1372	.1029	.1029
5	.1372	.1029	.1029
6	.2401	.3086	.2401
7	.4801	.4115	.3772
8	.2401	.3086	.3086
9	.0034	.0034	.0034
10	.0034	.0034	.0034
11	.0034	.0034	.0034
12	.0034	.0034	.0034
13	.0034		.0034
14	.0034	.0034	.0034
15	.0034	.0034	.0034
16	.0034	.0034	.0034
17	.0034	.0034	.0034
18	.0034	.0034	.0034
19	.0034	.0034	.0034
20	.0034	.0034	.0034
21	.0034	.0034	.0034
22	.0034	.0034	
23	.1372	.1372	.1372
24	.0034	.1372	.1372
Max	.4801	.4115	.3772
Min	.0034	.0034	.0034
Avg	.0736	.0809	.0765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 304 / ADARKI GOANTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2058
2	.2401	.2058	.2058
3	.2401	.1715	.1715
4	.2058	.1715	.1715
5	.1715	.1715	.1715
6	.1372	.2058	.2058
7	.2058	.2058	.2401
8	.1715	.2401	.1715
9	.2401	.2743	.2401
10	.3429	.3086	.3086
11	.3086	.2743	.3086
12	.3086	.2743	.3086
13	.2743		.2401
14	.2401	.2743	.2743
15	.2401	.2743	.2743
16	.2401	.2401	.2743
17	.2401	.2743	.2743
18	.2743	.3086	.2743
19	.2743	.2743	.2743
20	.3086	.3086	.3086
21	.3086	.2401	.3086
22	.3086	.2401	.3429
23	.2743	.2401	.2743
24	.2401	.2401	.2401
Max	.3429	.3086	.3429
Min	.1372	.1715	.1715
Avg	.2515	.2460	.2529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 306 / Siddhivinayak Bio-Energy

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0034	.0034
2		.0034	.0034
3		.0034	.0034
4		.0034	.0034
5		.0034	.0034
6		.0034	.0034
7		.0034	.0034
8		.0034	.0034
9		.0034	.0034
10		.0034	.0034
11		.0034	.0034
12		.0034	.0034
13			.0034
14		.0034	.0034
15		.0034	.0034
16		.0034	.0034
17		.0034	.0034
18	.0034	.0034	.0034
19	.0034	.0034	.0034
20	.0034	.0034	.0034
21	.0034	.0034	.0034
22	.0034	.0034	.0034
23	.0034	.0034	.0034
24		.0034	.0034
Max	.0034	.0034	.0034
Min	.0034	.0034	.0034
Avg	.0034	.0034	.0034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 302 / ASU AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2071		1.2917
2	1.2486		1.2917
3	1.275		
4	1.2864		1.3527
5	1.4674		1.4403
6	1.656		2.0043
7	2.0597		2.1491
8	1.8899		
11		.1962	
12		.2037	.1105
13	.1219	.1811	.1181
14	.1067	.1094	
15		.1584	.1067
16	.0991		
17	.1257		
18	.1486		
19	.1677	.1524	.1715
20		.2058	.2134
21		.1867	.2096
22		.1638	.1753
23		1.2574	1.406
24	.1811	1.3032	1.3298
Max	2.0597	1.3032	2.1491
Min	.0991	.1094	.1067
Avg	.8694	.3744	.8914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 303 / 22 KV GOKHALI GAOTHAN
Feeder KV- 22 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.1448
2			.1448
4			.1448
5			.1715
6			.2248
7			.1486
8			.141
11	.1219		.1181
12	.1143		.1257
13	.1219	.1773	.16
14	.1334	.1811	
15	.1067	.1886	.1562
16	.1257		
17	.1372		
19		.2058	.1829
20		.2553	.2324
21		.2172	.2096
22		.221	.1753
23			.1638
24	.1358		.1486
Max	.1372	.2553	.2324
Min	.1067	.1773	.1181
Avg	.1246	.2066	.1643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 304 / 22 KV ASU GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.2705
2			.2705
4			.2782
5			.3239
6			.4039
7			.4268
11	.3353	.3056	.3353
12		.2641	.3163
13	.3048	.2791	.3391
14	.282	.2716	
15	.2934	.2565	.3125
16	.3163		
17	.3239		
18	.381		
19	.3925	.4687	.5335
20		.5144	.5982
21		.4306	.4458
22		.3925	.4115
23		.3506	.362
24	.2867		.2782
Max	.3925	.5144	.5982
Min	.282	.2565	.2705
Avg	.3240	.3534	.3691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 301 / Wathar- N Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0038	.0038	.0038
2	.0038	.0038	.0038
3	.0038	.0038	.0038
4	.0038	.0038	.0038
5	.0038	.0038	.0038
6	.0038	.0038	.0038
7	.0038	.0038	.0038
8	.0038	.0038	.0038
9	1.8107	1.773	1.5844
10	1.9993		1.4335
11	2.1502	1.773	1.8861
12	2.0748	1.6975	1.8861
13	1.9239		1.773
14	1.3203	1.4712	1.4712
15	1.6975	1.4335	1.6221
16	1.8107	1.3957	1.5466
17	.0038		.0038
18	.0038	.0038	.0038
19	.0038	.0038	.0038
20	.0038	.0038	.0038
21	.0038	.0038	.0038
22	.0038	.0038	.0038
23	.0038	.0038	.0038
24	.9054	.0038	.0038
Max	2.1502	1.773	1.8861
Min	.0038	.0038	.0038
Avg	.6562	.4572	.5527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 302 / Upalwe Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9808	1.3957	1.4335
2	.9808	1.3957	1.358
3	.9808	1.3957	1.358
4	1.2071	1.4335	1.0185
5	1.6975	1.5844	1.7353
6	2.3765	2.5274	1.8861
7	2.7161	3.1687	2.7915
8	2.5652	2.7538	2.5274
9	.4527	.415	.415
10	.5281	.3772	.3395
11	.3772	.3018	.3395
12	.415	.3772	.3395
13			.3395
14		.3772	
15	.415	.3395	
16	.4527	.3395	
17	.3772	.3395	
18	.415	.4527	.4904
19	.5281	.5281	.7167
20	.7922	.679	.7922
21	.7545	.6413	.6036
22	.6413	.6036	.7167
23	1.1694	1.358	1.5089
24	.4527	1.3957	1.4335
Max	2.7161	3.1687	2.7915
Min	.3772	.3018	.3395
Avg	.9671	1.0513	1.1072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 303 / Tathawada Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3772	.1886
2	.3018	.3772	.1886
3	.3018	.3772	.1886
4	.3018	.415	.1886
5	.3772	.415	.2263
6	.4904	.5658	.2641
7	.4527	.4904	
8	.415	.4904	
9	1.8107	1.6221	.3018
10	2.1502		
11	2.1125		1.6975
12	2.037		1.8861
13	1.773		2.1502
14	1.773		2.0748
15	1.6975		2.0748
16	1.6975		1.9239
17		.2263	.3395
18		.1509	.3395
19	.3395	.2263	.4527
20	.4527	.2641	.5658
21	.415	.2641	.5281
22	.3772	.2263	.415
23	.3772	.2263	.3772
24	1.2071	.3772	.4904
Max	2.1502	1.6221	2.1502
Min	.3018	.1509	.1886
Avg	.9619	.4172	.8030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 301 / 22 Kv Giravi Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3696	.2561	.3361
2	.3658	.2561	.3361
3	.3658	.2561	.3734
4	.4435	.2926	.2987
5	.5068	.3292	.3734
6	.5487	.3658	.4481
7	.5228	.4024	.4854
8	.4805	.3292	.4854
9	3.2819	2.7801	3.062
10	3.3265	3.1824	3.3608
11	3.3234	2.9874	
12	3.2487	2.9424	2.963
13	3.1367	2.838	2.3777
14	3.1741	2.037	2.4508
15	3.062		2.2314
16	2.9874	2.5274	1.6827
17	.4854	.4024	
18	.5601	.4108	
19	.4024	.4854	
20	.3982	.5228	.439
21	.5121	.4854	.3658
22	.3658	.4481	.3258
23	.2926	.3734	.2218
24	1.8484	.2561	.3361
Max	3.3265	3.1824	3.3608
Min	.2926	.2561	.2218
Avg	1.4171	1.0942	1.1477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 303 / 22 Kv Giravi Gaothan
Feeder KV- 22 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2926	.2241
2	.2534	.2926	.2241
3	.2614	.3292	
4	.2614	.3292	.2241
5	.2957	.3658	.2241
6	.3361	.4024	.3361
7	.2987	.2926	.2987
8	.2614	.2926	.2614
9	.2614	.2561	.2987
10	.2926	.2195	.3361
11	.2987	.2587	
12	.2987	.2614	.2926
13	.2614	.2561	.2561
14	.2614	.2172	.2561
15	.2614		.2926
16	.2614	.2241	.1829
17	.3361	.2926	.2926
18	.2987	.2987	.2926
19	.2926	.3361	
20	.4024	.4481	.439
21	.3292	.3734	.439
22	.3658	.2987	.3658
23	.3292	.2614	.3258
24	.2926	.2926	.2614
Max	.4024	.4481	.439
Min	.2534	.2172	.1829
Avg	.2946	.2996	.2916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 304 / 22 KV Wadale AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8131	1.0242	.8215
2	.8215	1.0974	.8215
3	.7964	1.2071	.7842
4	.8871	1.2803	.8215
5	1.4045	1.3535	.9335
6	1.7177	1.4632	1.3817
7	2.1502	1.7924	1.9418
8	1.8861	1.7558	1.643
9	.4066	.3292	.4108
10	.4066	.3292	.3361
11	.3361	.2561	
12	.3361	.2195	
13	.3361	.2195	
14	.3361	.181	.3658
15	.3734	.2561	.3658
16	.2241	.2957	.4024
17	.3361	.362	.4024
18	.4481	.2614	.3658
19	.3982	.3734	.4706
20	.4755	.5228	.5175
21	.439	.4854	.5121
22	.439	.4854	.439
23	1.0242	.9335	.8326
24	.4755	.9511	.8962
Max	2.1502	1.7924	1.9418
Min	.2241	.181	.3361
Avg	.7195	.7265	.7365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 305 / 22 KV Dudhebavi AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2926	.1867
2	.2195	.3292	.1867
3	.2218	.3292	.1867
4	.2926	.3658	.1494
5	.3658	.439	.1867
6	.6219	.5121	.4481
7	.6653	.695	.6348
8	.6283	.6219	.5975
9	.1848	.2561	.1867
10	.1478	.2195	.1494
11	.112	.1494	
12	.112	.1075	
13	.112	.1097	.1463
14	.0747	.1086	.2195
15	.112		.2172
16	.112	.0732	.1463
17	.1494	.1829	.1463
18	.1867	.1867	
19	.2561	.2241	
20	.3658	.2241	.181
21	.2926	.2241	.181
22	.2926	.1867	.1448
23	.2926	.2241	.2218
24	.2195	.2926	.1867
Max	.6653	.695	.6348
Min	.0747	.0732	.1448
Avg	.2609	.2763	.2352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 306 / 22 KV Dudhebavi Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2561	.2218
2	.2218	.2561	.2241
3	.2218	.2926	.2241
4	.2587	.3292	.2241
5	.3696	.3658	.2614
6	.4435	.4024	.3734
7	.4066	.3658	.3361
8	.2987	.2926	.2614
9	.2587	.2561	.2614
10	.2218	.2926	
11	.2614	.2195	
12	.1715	.2195	
13	.1494	.1848	.1829
14	.2241	.1829	.2561
15	.2241	.1829	.2926
16	.2241	.2172	.2926
17	.2614	.2957	.2561
18	.3361	.2241	.2926
19	.3658	.3734	.362
20	.4755	.4108	.4024
21	.4024	.3734	.3658
22	.3658	.3361	.3292
23	.2926	.2614	.2587
24	.2614	.2641	.2614
Max	.4755	.4108	.4024
Min	.1494	.1829	.1829
Avg	.2891	.2856	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 301 / JANAI AG

Feeder KV- 22 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.3955	1.6068	1.3795
2	1.4243	1.594	1.3763
3	1.4467	1.5524	1.3635
4	1.562	1.6036	1.3827
5	1.6548	1.7124	1.4563
6	2.0101	2.1989	1.9524
7	2.4358	2.567	2.5638
8	2.2917	2.4774	2.4614
9	.2305	.2305	.2689
10	.2529	.2849	.2401
11	.2209	.2433	.2497
12	.2112	.2016	.176
13	.23		.2112
14	.2561		.2465
15	.192	.2497	.2241
16	.2209		
17	.2369	.2849	
18	.2753		
19	.2945	.3393	.2977
20	.3457	.3713	.3649
21	.3265	.3265	.3073
22	.2945	.2753	.2913
23	1.5556	1.4083	1.658
24	.1984	1.5812	1.4307
Max	2.4358	2.567	2.5638
Min	.192	.2016	.176
Avg	.8151	1.0555	.9477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 302 / SATE PHATTA AG

Feeder KV- 22 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1846	.2462	.2688
2	.1879	.2332	.2623
3	.1846	.23	.2591
4	.2008	.2721	.2688
5	.3174	.3142	.285
6	.3304	.434	.4016
7	.366	.3628	.3951
8	.2753	.298	.353
9		2.2834	2.2575
10	1.4121	2.4971	
11	1.4186	2.2737	
12	1.4057	2.2639	2.0405
13	1.4186	2.1538	2.2413
14	1.3376		2.3482
15	1.2599	1.9595	2.2478
16	2.2607		
17	.2267		
18	.2656		
19	.3109	.3174	.3692
20	.3304	.4049	.4049
21	.3174	.3725	.3757
22	.3077	.3368	.3271
23	.285	.2818	.285
24		.2623	.2721
Max	2.2607	2.4971	2.3482
Min	.1846	.23	.2591
Avg	.6638	.8899	.8244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 303 / RAJALE GAON

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3958	.3996	.4518
2	.4033	.3958	.4481
3	.4182	.3809	.4406
4	.4294	.4257	.4556
5	.478	.4705	.5116
6	.5303	.5601	.5937
7	.5415	.5303	.5937
8	.4929	.4444	.4406
9	.4294	.4556	.4332
10	.4294	.4518	.3809
11	.4033		.3884
12	.3921		.4257
13	.4369		.4294
14	.4033		.4406
15	.4108	.168	.407
16	.4257		
17	.4332	.5415	
18	.4406		
19	.4556	.5564	.6199
20	.5303	.6871	.661
21	.5228	.5975	.5937
22	.5191	.5489	.5639
23	.4518	.463	.4929
24	.4294	.4257	.4593
Max	.5415	.6871	.661
Min	.3921	.168	.3809
Avg	.4501	.4724	.4872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 201 / KATHAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	4.9993	5.0743	1.6118
2	4.8103	4.9725	1.5947
3	4.6014	4.885	1.5432
4	4.5252	4.7897	1.4746
5	4.3469	4.7066	1.4746
6	4.7722	4.5447	1.4918
7	4.8209	5.1227	1.6118
8	4.9718	5.026	1.6289
9	2.7267	2.5804	
15	.2309	.0762	.0953
16	.1136	.0918	.0762
17	.1189	.107	.0762
18	.0953	.1372	.0762
19	.0953	.1555	.1067
20	.1143	.1402	.1067
21	.1143	.1372	.0914
22	.1143	.12	.0914
23	4.7714	3.4419	1.7528
24	5.141	4.1749	1.6461
Max	5.141	5.1227	1.7528
Min	.0953	.0762	.0762
Avg	2.7097	2.6465	.9195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 202 / EKAMBE -SANGVI- AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0953	.0686
2	.0914	.0762	.0686
3		.0762	
4		.0762	
5		.0953	
6		.0953	
7		.0572	
9	2.7724	4.2616	2.2447
10	3.4995	5.5189	2.9001
11	3.629	5.7004	2.343
12	7.402	5.5998	2.4249
13	7.1994	2.9995	2.4249
14	6.6789	4.1579	2.3758
15	5.8532	4.7142	2.3758
16	5.2751	4.9795	2.3472
17	2.8677	2.6829	
18	.0655	.0171	
19	.0381	.0171	
20	.1143	.0686	.0914
21	.0953	.0686	.0914
22	.0953	.0686	.0762
23	.0953	.0686	.0762
24	.0914	.0791	.0686
Max	7.402	5.7004	2.9001
Min	.0381	.0171	.0686
Avg	2.5531	1.8076	1.3318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 203 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0373	.0343
2	.0343	.0373	.0343
3	.0343	.0373	.0171
4	.0343	.0373	.0171
5	.0343	.0373	.0343
6	.0343	.0373	.0343
7	.0343	.056	.0514
8	.0514	.0373	.0514
9		.0343	.0747
10		.0343	.0934
11		.0343	.0747
12	.0686	.0171	.1307
13	.0857	.0171	.056
14	.0857	.0171	.0747
15	.0686	.0171	.0934
16	.0857	.0171	.12
17	.0747	.0171	.0514
18	.056	.0171	.0857
19	.056	.0171	.0857
20	.0373		.0686
21	.0373		.0514
22	.0373	.0171	.0343
23	.0373	.0343	.0514
24	.0343	.0373	.0514
Max	.0857	.056	.1307
Min	.0343	.0171	.0171
Avg	.0503	.0293	.0613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 204 / EKAMBE -SANGVI- VLG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8741	.8981	.2915
2	.4713	.8135	.2743
3	.8451	.7716	.2572
4	.8341	.7426	.2572
5	.865	.8211	.2915
6	1.017	1.0368	.4287
7	.9507	1.1291	.4458
8	.977	1.0502	.3944
9	.5125	.8581	.4481
10	.4553	.7892	.3361
11	.4073	.7594	.3361
12	.7727	.7815	.3547
13	.7636	.607	.3547
14	.7224	.5399	.3361
15	.6866	.6047	.3361
16	.6214	.556	.3258
17	.7628	.6176	.3429
18	.7312	.6535	.12
19	.8559	.8082	.4458
20	1.2948	1.0841	.5316
21	1.2758	1.0479	.5144
22	1.2475	1.0315	.4973
23	1.0997	.833	.4115
24	.8947	.7998	.2915
Max	1.2948	1.1291	.5316
Min	.4073	.5399	.12
Avg	.8308	.8181	.3593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 205 / 11KV KATAPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9842	.9396	.5316
2	.8706	.9023	.5144
3	.8706	.8649	.5144
4	.9084	.8276	.5144
5	.9945	.9023	.6516
6	1.1736	1.0913	.8059
7	1.2117	1.0539	.8059
8	1.1221	.9785	.7202
9	.9983	.9259	.6908
10	.9087	.8364	.4854
11	.8706	.7468	.5415
12	.7506	.5239	.5975
13	.6916	.2648	.5601
14	.7259	.2477	.5601
15	.7811	.2305	.5228
16	.7087	.5677	.4287
17	.8082	.943	.4801
18	.9396	1.0459	.6001
19	.9396	1.0974	.703
20	1.2966	1.2079	.9088
21	1.3721	1.1736	.8573
22	1.2033	1.1393	.7716
23	1.0897	.964	.6344
24	.9259	.9583	.5487
Max	1.3721	1.2079	.9088
Min	.6916	.2305	.4287
Avg	.9644	.8514	.6229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 206 / Shirambe-Ag

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.0424	2.3266	1.9204
2	1.9814	2.2939	1.9033
3	1.9357	2.2611	1.8519
4	1.9204	2.2283	1.869
5	1.9509	2.2939	1.9204
6	2.1643	2.3102	1.989
7	2.3624	2.4905	2.2977
8	2.3167	2.1956	2.2291
15	.0686	.0457	.0762
16	.0686	.0514	.061
17	.0762	.0514	.061
18	.0762	.0686	.061
19	.0762	.0686	.061
20	.0762	.0514	.061
21	.0762	.0514	.061
22	.0762	.0514	.061
23	2.13	1.8861	1.768
24	2.1338	2.3266	1.9204
Max	2.3624	2.4905	2.2977
Min	.0686	.0457	.061
Avg	1.1962	1.2807	1.1207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 201 / 11KV CHIMANGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6626	.3921	.4344
2	.6626	.3734	.4344
3	.6805	.3921	.4344
4	.6984	.4481	.4887
5	.6268	.5228	.5138
6	.6089	.6535	.5792
7	.591	.6348	.6447
8	.5552	.5975	
9	.6626	.6348	
10	.5175	.6154	.6805
11	.5544	.5973	.6626
12	.4668	.4887	
13	.3511	.3801	.5552
14	.3696	.543	.4656
15	.3921	.6878	.4656
16	.3921	.6335	.3761
17	.4481	.5792	.0537
18	.4294	.543	.6805
19	.5228	.5304	.7164
20	.8029	.6697	.9492
21	.7207		.9492
22	.6348	.6556	.6626
23	.5228		.394
24	.8059	.4294	.4656
Max	.8059	.6878	.9492
Min	.3511	.3734	.0537
Avg	.5700	.5456	.5527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 202 / 11 KV CHIMANGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.8004	2.4863	
2	1.7318	2.4177	1.9728
3	1.7147	2.3491	1.949
4	1.9204	2.2291	
5	2.0576	2.2634	2.0199
6	2.4691	2.2969	2.1616
7	2.5892	2.3137	2.5692
8	2.6406	2.3304	
10			.1494
11			.1307
12			.0934
13			.112
14			.0093
15	.0934		.0934
16	.0934		.0895
17	.0924		.112
18	.0934		.112
19			.0747
20	.1307		.1494
21	.1307		.1307
22	.1307	.1086	.112
23	2.2291		3.3779
24	1.8519	2.452	2.6063
Max	2.6406	2.4863	3.3779
Min	.0924	.1086	.0093
Avg	1.2806	2.1247	.9013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 203 / 11 KV Khed Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.4933	1.2692	
2	1.3367	1.1858	
3	1.3043	1.1191	
4	1.3271	1.145	
5	1.3767	1.2265	
6	1.5851	1.4693	
7	1.8759	1.7836	
8	1.853	1.9446	
9	1.7151	1.7032	
10	1.6445	1.4306	.0681
11	1.5807	1.3022	.6626
12	1.4758	1.3127	.0274
13	1.3904	1.2335	.6268
14	1.3251	1.1321	.6089
15	1.2905	1.1662	.6268
16	1.2607	.599	.6268
17	1.2788	.519	.6626
18	1.3215	.6592	.7701
19	1.5032	.7057	.8238
20	1.8421	.759	.9134
21	1.7892	.6783	.8596
22	1.7345	1.466	.7522
23	1.562	.7537	.6268
24	1.6019	1.2468	.591
Max	1.8759	1.9446	.9134
Min	1.2607	.519	.0274
Avg	1.5195	1.1588	.6165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 204 / 11 KV Khed Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2689	1.1871	
2	1.3375	1.0985	
3	1.4575	1.0277	
4	1.5775	.9568	
5	1.4746	1.0867	
6	1.3375	1.2656	
7	1.5775	1.4403	
8	1.5947	1.5432	
10			.0934
11			.0934
12			.0747
13			.0747
14			.0747
15	.0934	.0724	.0747
16	.0934		.056
17	.2427		.0747
18	.2054		.056
19	.1867		.0747
20	.0934		.0716
21	.0934		.0747
22	.0934	.0709	.0075
23	1.2971		1.2174
24	1.3375	1.2226	1.286
Max	1.5947	1.5432	1.286
Min	.0934	.0709	.0075
Avg	.8535	.9974	.2269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 205 / 11KV Shendurjane AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.112	.0747	
2	.0747	.0747	
9	2.2462	1.8347	
10	2.649	2.1176	.2281
11	2.4813	2.5158	2.2805
12	2.4646	2.3034	2.1776
13	2.1795	2.19	2.0576
14		2.2081	2.0062
15	2.2119	2.2081	1.989
16	2.2291	2.1033	1.9547
17	.0934	.0905	.1867
18	.0747		.112
19	.0747		.0075
20	.0747		.112
21	.0747		
22	.0747	.0905	.0934
23	.0747		.0747
24	.1307	.0747	.112
Max	2.649	2.5158	2.2805
Min	.0747	.0747	.0075
Avg	1.0189	1.3759	.9566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 206 / 11KV Bhatamwadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1307	
2	.1867	.1307	
9	1.0117	1.0749	
10	1.0576	1.0631	.8573
11		1.0566	.8573
12	.0373	1.0566	.8573
13	.0373	1.0454	.7716
14	.0373	.9671	.8962
15	.0373	.9231	.8962
16	1.1568		.9335
17	1.1694		.1494
18	.1307		.1494
19	.1307		.1307
20	.1494		.1307
21	.168		.1494
22	.168	.128	.1494
23	.1494		.1307
24	.2241	.1494	.1307
Max	1.1694	1.0749	.9335
Min	.0373	.128	.1307
Avg	.3563	.7023	.4793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 201 / TARAGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4424	.5093	.4715
2	.4424	.5093	.4715
3	.426	.4904	.439
4	.426	.4904	.4527
5	.426	.5093	.4527
6	.3932	.4715	.4527
7	.3441	.415	.3961
8	.3113	.4108	.3772
9	2.2405	2.251	2.0325
10	2.5126	2.2725	2.0805
11	2.3045	2.332	2.0153
12	2.0715	2.2348	2.0481
13	1.9997	2.0165	1.9498
14	1.9524	1.9919	1.9006
15	2.0081		1.8351
16	1.9433	.0152	1.8351
17	.3841	.0133	.3605
18	.3658	.0141	.3113
19	.5041	.6908	.3605
20	.7167	.7356	.5571
21	.7356	.679	.5898
22	.679	.6413	.5735
23	.5847	.5281	.4915
24	.4588	.5281	.4904
Max	2.5126	2.332	2.0805
Min	.3113	.0133	.3113
Avg	1.0280	.9022	.9560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 202 / KIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.3611	2.2207	1.647
2	1.3253	2.0774	1.6108
3	1.3213	2.0237	1.5927
4	1.3213	1.9879	1.5746
5	1.3032	1.9521	1.5203
6	1.448	2.1491	1.7556
7	1.7194	2.2028	1.9521
8	2.19	2.0199	1.8983
9	.2587	.3174	.3292
10	.2957	.2957	.3109
11	.2926	.2772	.2743
12	.2926	.3142	.0183
13	.3326	.2772	.3109
14	.3326	.2957	.3142
15	.3511	.3109	.3326
16	.3511	.2926	.3142
17	.3109	.2743	.2715
18	.3475	.3142	.3439
19	.4108	.4481	.3982
20	.6036	.547	.5792
21	.6224	.5658	.5973
22	.6036	.5281	.5611
23	2.2207	1.7556	1.4842
24	1.4327	2.2207	1.7013
Max	2.2207	2.2207	1.9521
Min	.2587	.2743	.0183
Avg	.8770	1.0695	.9039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 203 / WATHAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8299	.8299	.7733
2	.8299	.8299	.7733
3	.811	.811	.7733
4	.8299	.811	.7545
5	.811	.8299	.7922
6	.8676	.8488	.8299
7	.811	.7733	.6979
8	.7356	.6348	.6602
9	3.0498	2.5692	1.8299
10	2.8669	2.6379	2.0405
11	2.9005	2.5029	2.2186
12	2.5857	2.3703	2.5425
13	2.4249	2.4905	2.5425
14	2.4366	2.4366	2.5724
15	2.4981	1.873	2.4577
16	2.4981	1.8679	2.5232
17	.0187	.2172	.5853
18	.0187	.6036	.6584
19	.8962		.7133
20	1.1317	1.1694	1.0425
21	1.1694	1.094	1.0974
22	1.1317	1.0185	1.0608
23	.9619	.8865	.9328
24	.8676	.8676	.7922
Max	3.0498	2.6379	2.5724
Min	.0187	.2172	.5853
Avg	1.4159	1.3467	1.3194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 204 / ARVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2717	1.4582	1.0682
2	1.2803	1.2717	1.0004
3	1.153	1.2039	.9665
4	1.1361	1.1904	.9326
5	1.1361	1.2071	.9496
6	1.3056	1.4922	1.2209
7	1.5769	1.7436	1.291
8	1.4582	1.6766	1.3245
9	.4108	.4108	.3734
10	.4066	.4066	.4108
11	.3881	.3734	.3696
12	.4251	.2801	.3881
13	.4435	.4108	.4435
14	.4435	.4108	.2957
15	.462	.112	.2772
16	.4066	.0934	.0189
17	.3696	.0189	.5658
18	.3511	.0189	.4715
19	.4854		.5658
20	.7167	.0377	.7733
21	.7356	.6413	.7922
22	.7167	.7356	.7733
23	1.3565	1.153	1.406
24	1.3735	1.5261	1.153
Max	1.5769	1.7436	1.406
Min	.3511	.0189	.0189
Avg	.8254	.7771	.7430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 205 / PWV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.052	.0038	.0057
2	.052	.003	.0046
3	.052	.0029	.0036
4	.052	.003	.0048
5	.0173	.003	.0044
6	.0002	.0029	.0044
7	.0006	.003	.0038
8	.1425	.0021	.0048
9	.0107	.0019	.0021
10	.0084	.0111	.0187
11	.008	.0185	.0187
12	.0093	.0183	.0187
13	.0093	.0183	.0187
14	.009	.0128	.0187
15	.0187	.0187	.0187
16	.0112	.013	.0187
17	.0103	.0072	.0086
18	.0097	.0042	.0086
19	.0061		.0002
20	.0042	.0053	.0017
21	.0038	.0048	.0017
22	.0038	.0038	.0017
23	.0038	.0048	.0017
24	.052	.004	.0053
Max	.1425	.0187	.0187
Min	.0002	.0019	.0002
Avg	.0228	.0074	.0083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 201 / PIMPARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0949	.0693	.0648
2	.1107	.0693	.0655
9	1.439	1.1702	1.166
10	1.6484	1.2323	1.3108
11	1.6518	1.2018	1.1984
12	1.4251	1.2334	
13	1.3603	1.1544	.9804
14	1.2955	1.0753	1.0364
15	1.1822	1.012	.9488
16	1.0688	.9014	
17	.0857	.081	
18	.0857	.0972	.104
19	.104		.0949
20	.0857	.128	.128
21	.1029	.1296	.1107
22	.104	.128	.0949
23	.0867	.081	.1107
24	.0949	.0693	.0791
Max	1.6518	1.2334	1.3108
Min	.0857	.0693	.0648
Avg	.6681	.5784	.4996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 202 / BRAMHAPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9795	.9313	.8779
2	.9425	.8596	.8413
3	.9425	.8688	.8326
4	.9694	.905	.8596
5	1.0242	.8954	.8954
6	1.0608	.8764	.9774
7	1.0692	.905	1.0791
8	.9431	.8505	1.0136
9	.9709	.7522	.9231
10	1.0277	.7522	.9671
11	1.0498	.8322	.9774
12	1.0166	.78	1.0136
13	.9745	.78	
14	.985	.7602	
15	.9593	.6584	
16	.8688	.8596	
17	.905	.8775	
18	.905	.788	
19	1.086		
20	1.3756	1.3289	1.3213
21	1.3169	1.3213	1.2254
22	1.267	1.1765	1.1643
23	1.1222	.9671	1.0642
24	1.0349	1.0029	.924
Max	1.3756	1.3289	1.3213
Min	.8688	.6584	.8326
Avg	1.0332	.9013	.9975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 203 / SAP

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.8841	2.7206	.08
2	2.1792	2.753	.112
3	2.1792	2.7206	.0949
4	2.1464	2.6882	.0937
5	2.1956	2.7206	.1265
6	2.7018	2.8502	.16
7	2.8182	2.9656	.1943
8	2.4741	2.9492	.192
15	.0648	.0791	.104
16	.0686	.0949	
17		.096	
18	.0648	.1006	.0686
19	.0867		.0995
20	.1029	.0838	.1311
21	.104	.1017	.1296
22	.1029	.1029	.1134
23	2.7199		2.3205
24	2.9007	2.7206	.0972
Max	2.9007	2.9656	2.3205
Min	.0648	.0791	.0686
Avg	1.5173	1.6092	.2573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 204 / SASURVE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0819	.0686	.0463
2	.0819	.0701	.0457
9	2.2447	1.2967	1.9989
10	2.5396	1.7166	2.13
11	2.4905	1.7695	2.2611
12	2.3922	1.8679	2.4905
13	2.4272	1.8187	2.3266
14	2.2024	1.7532	2.4615
15	2.2725	1.6221	
16	2.2085	1.6244	
17	1.9595	1.5592	
18	1.749	1.3927	1.8138
19	1.6518		1.7532
20	1.4575	.2622	1.704
21	.0857	.0949	.0819
22	.0857	.0949	.0983
23	.0857	.0772	.0655
24	.0655	.0693	.0617
Max	2.5396	1.8679	2.4905
Min	.0655	.0686	.0457
Avg	1.4490	1.0093	1.2893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 205 / VELU

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2481	.2534
2	.2641	.2507	.2353
3	.2641	.2172	.197
4	.2641	.2149	.197
5	.2987	.2126	.2353
6	.3511	.2835	.2743
7	.3012	.2835	.3109
8	.2507	.3258	.3258
9	.2303	.3045	
10	.2303	.2507	.1267
11	.2126	.2254	.3012
12	.1949	.2229	.2865
13	.2328	.2401	
14	.2103	.2401	.2658
15	.2353	.1829	.197
16	.2149	.2254	
17	.2126	.1928	
18	.2126	.2427	.1372
19	.3801		.3012
20	.4835	.4525	.4477
21	.4477	.3761	.4251
22	.3898	.3292	.3547
23	.2865	.2896	.2801
24	.2829	.2835	.2743
Max	.4835	.4525	.4477
Min	.1949	.1829	.1267
Avg	.2798	.2650	.2713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 206 / 11KV Dhamner Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.3807	1.8564	1.5402
2	2.3472	1.9109	1.4746
3	2.3472	1.9109	1.4575
4	2.2874	1.8747	1.4251
5	2.4143	2.1052	1.5074
6	2.6825	2.1052	1.5912
7	2.6707	2.2024	1.6766
8	2.5396	2.2996	1.7269
15	.0303	.0293	.0406
16	.0314	.0309	
17	.0541	.0358	
18	.0533	.0591	.04
19	.0541		.0495
20	.0533	.04	.0343
21	.0541	.0406	.0326
22	.0587	.0314	.0389
23	1.8884		2.0719
24	2.4813	1.8564	1.5912
Max	2.6825	2.2996	2.0719
Min	.0303	.0293	.0326
Avg	1.3571	1.1493	1.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 301 / 22KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.3525	2.4272	2.0698
2	2.2405	2.3525	2.0328
3	2.1658	2.2405	2.0328
4	2.2405	2.2405	2.0328
5	2.2405	2.2405	2.2177
6	2.4272	2.3899	2.4646
7	2.6139	2.5019	2.6139
8	2.3899	2.5766	2.5393
9	2.6139	2.5393	2.5873
10	2.726	2.6612	2.6612
11	3.0247	2.5873	2.8532
12	2.9801		2.963
13	2.9801		2.7801
14	2.8829		2.6703
15	2.9199		2.6703
16	2.8166		2.6337
17	2.9199	3.219	2.7069
18	2.809	2.8959	2.7801
19	3.3653	3.2922	3.3634
20	3.6961	3.4751	3.5482
21	3.3634	3.1093	3.1786
22	3.062	2.8532	2.809
23	2.8006	2.6337	2.6612
24	2.4272	2.5019	2.3655
Max	3.6961	3.4751	3.5482
Min	2.1658	2.2405	2.0328
Avg	2.7524	2.6704	2.6348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 302 / 22KV SANGAM NAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	1.6598	1.6975
2	1.6221	1.5844
3	1.5466	1.5089
4	1.5089	1.5089
5	1.5089	1.4712
6	1.5089	1.5089
7	1.5089	1.6598
8	1.6598	1.6598
9	1.8861	1.6632
10	2.2634	1.9589
11	2.4143	
12	2.4897	
13	2.3011	
14	2.3388	
15	2.4897	
16	2.6029	
17	2.3765	
18	2.2257	
19	2.1502	
20	2.2257	
21	2.1125	
22	1.9616	
23	1.9239	
24	1.7353	1.6975
Max	2.6029	1.9589
Min	1.5089	1.4712
Avg	2.0009	1.629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 303 / 22KV PARANGE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.6804	1.5524
2	1.531	1.5684	1.5524
3	1.4335	1.4937	1.5524
4	1.4712	1.4937	1.5524
5	1.5089	1.4937	1.5524
6	1.5684	1.531	1.5684
7	1.643	1.643	1.5684
8	1.6263	1.5684	1.6632
9	1.5684	1.4937	1.6632
10	1.7002	1.5524	1.6632
11	1.6632		1.7741
12	1.7372		1.7741
13	1.7372		1.7002
14	1.7372		1.6632
15	1.7741		1.6263
16	1.848		1.5729
17	1.7741		1.6827
18	1.8111	2.1491	1.6827
19	1.9959	2.4874	1.885
20	2.2177	2.3411	2.1807
21	2.1068	2.1216	2.0698
22	2.0911	2.0119	1.922
23	1.9044	1.829	1.7177
24	1.643	1.7177	1.6632
Max	2.2177	2.4874	2.1807
Min	1.4335	1.4937	1.5524
Avg	1.7358	1.7751	1.7001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 304 / 22KV CIVIL HOSPITAL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2324	.0762
2	.2077	.2324	.0762
3	.2058	.2458	.0762
4	.2058	.2496	.0381
5	.2038	.2153	.0381
6	.1677	.2153	.0762
7	.1829	.1791	.0762
8	.2267	.2724	.1143
9	.2496	.3105	.0762
10	.3143	.362	.1524
11	.3753	.4077	.1143
12	.3848	.2877	.1143
13	.3582	.2782	.1143
14	.3429		.0762
15	.3315		.1143
16	.3544		.0762
17	.322	.0762	.0762
18	.2896	.2686	.0381
19	.2248	.2515	.0762
20	.2496	.2343	.0762
21	.2972	.2915	.1143
22	.2782	.2972	.0762
23	.2705	.2705	.0762
24	.261	.2248	.0762
Max	.3848	.4077	.1524
Min	.1677	.0762	.0381
Avg	.2714	.2573	.0841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 301 / 22KV OLD MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7095	.4854
2	.7468	.6348	.4805
3	.7095	.6653	.4656
4	.7167	.6653	.5068
5	.7023	.6653	.5914
6	.695	.6154	.6584
7	.6878	.5258	.567
8	.9922	.4359	.5609
9	.7842	.3479	.6722
10	1.2071	.2321	.8676
11	1.1694	.2481	1.0562
12	.9431	.2374	1.094
13	.9054	.2507	1.094
14	1.0562	.2926	1.1317
15	1.094	.2534	1.2071
16	1.094	.2481	1.1317
17	.9054	.3506	
18	.9054	.3429	.9054
19	.7922	.3506	.7545
20	.679	.3582	.5228
21	.7922	.4801	.6653
22	.7922	.4748	.5792
23	.7922	.4458	.6219
24	.7922	.7095	.5175
Max	1.2071	.7095	1.2071
Min	.679	.2321	.4656
Avg	.8626	.4392	.7451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]**SATARA CIRCLE[575]****SATARA DIVISION[516]****SATARA (U)[117]****BU 0914****Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS****Feeder No / Name : 302 / 22 KV KARMVEER NAGAR****SHEDDABLE URBAN****Feeder KV- 22 / OUTGOING**

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.1125	1.8671	1.5466
2	1.9616	1.8298	1.5154
3	1.8861	1.8107	1.4937
4	1.6975	1.8107	1.5364
5	1.7924	1.773	1.6057
6	1.9791	1.9239	1.7924
7	2.0165	2.0748	1.8298
8	1.7924	1.9791	1.8298
9	1.7551	1.6057	1.7177
10	1.6804	1.4563	1.643
11	1.5466	1.3676	1.7002
12	1.643	.8131	1.5893
13	1.6804	.924	1.5524
14	1.6057	.8962	1.4784
15	1.6598	.8871	1.5154
16	1.8107	.8962	
17	1.7551	.9054	1.4563
18	1.643	1.094	1.4937
19	2.0538	1.6975	1.9239
20	2.4764	2.1879	2.3899
21	2.3655	2.2634	2.2779
22	2.2177	2.1502	2.2405
23	2.0911	1.9616	1.9418
24	2.1502	1.9044	1.6804
Max	2.4764	2.2634	2.3899
Min	1.5466	.8131	1.4563
Avg	1.8905	1.5867	1.7283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 303 / 22KV MAHARASHTRA SCOOTERS

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.4335	.3772
2	1.4937	1.4712	.3368
3	1.4937	1.4712	.3174
4	1.4937	1.4937	.3018
5	1.4937	1.4937	.3155
6	1.4563	1.531	.3765
7	1.531	1.3676	.6241
8	1.643	1.182	.6653
9	1.9616	.724	1.9239
10		.7522	1.9239
11		.7282	2.1879
12	2.0748	.6325	1.8861
13	2.1502	.583	1.8861
14	2.037	.6226	1.8861
15	2.1879	.5502	1.9993
16	1.9993	.4793	1.8107
17	1.9993	.3913	1.8671
18	1.8861		3.6222
19	1.8861	.5068	1.8484
20	1.5844	.3658	1.773
21	1.5844	.5357	1.5466
22	1.6221	.6722	1.773
23	1.7353	.7023	1.7353
24	1.5466	1.358	.3174
Max	2.1879	1.531	3.6222
Min	1.4563	.3658	.3018
Avg	1.7441	.9151	1.3876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 304 / 22KV DOBURG

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	8.3555	7.7306	1.2826
2	9.8484	8.658	1.2696
3	9.2235	9.2973	1.2449
4	9.3926	8.8699	1.3203
5	9.1183	9.1137	1.4335
6	9.3888	8.8416	1.6598
7	9.4578	7.6551	2.3388
8	8.2403	5.5583	1.5844
9	10.3399	4.1655	3.0178
10	7.697	4.2417	3.0178
11	8.703	4.1743	3.9609
12	8.642	2.8045	3.4328
13	11.9468		3.3573
14	12.1586		3.0178
15	12.806		3.8855
16	11.7604		2.7915
17	10.5464		3.5082
18	11.4171		2.7161
19	10.3148		3.3951
20	9.0676	3.1489	2.4897
21	8.1219	4.0268	1.6221
22	7.6239	4.0951	2.6406
23	8.8248	4.0505	3.0178
24	7.6422	4.5093	1.2696
Max	12.806	9.2973	3.9609
Min	7.6239	2.8045	1.2449
Avg	9.6099	5.9377	2.4698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 301 / 22KV KARANJE MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0097	1.0608	.2926
2	.9945	1.0456	.2926
3	.9945	1.0151	.2926
4	.9945	.9632	.2957
5	1.0288	.9632	.3292
6	1.044	.948	.3292
7	1.0593	.948	.3292
8	1.1393	.9327	.3658
9	1.3078	.9327	.3429
10	1.5212	.948	.3429
11	1.7193	.9023	.4801
12	1.4998	.8718	.3772
13	1.5455	.8718	.3772
14	1.64	.9023	.3772
15	1.4967	.9175	.3772
16	1.5943	.9632	
17	1.7375	.9632	.4115
18	1.5212	.9572	.3772
19	1.384	.9389	.3086
20	1.2651	1.0303	.2401
21	1.1279	.9998	
22	1.1584	.9693	
23	1.1431	.948	.3086
24	1.0859	.9755	.2926
Max	1.7375	1.0608	.4801
Min	.9945	.8718	.2401
Avg	1.2922	.9570	.3400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 302 / 22KV PRATAPGANJ PETH

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	5.9633	5.8375	1.5729
2	5.7232	5.6303	1.4784
3	5.6928	5.5236	1.39
4	5.6165	5.4474	1.4266
5	5.7042	5.551	1.7558
6	5.9861	5.8223	1.8656
7	6.0509	6.1301	1.9753
8	6.0243	6.0418	1.8656
9	5.871	5.5479	1.7147
10	5.4595	5.2522	1.7147
11	5.0785	4.9444	1.5775
12	4.8864	4.414	1.5089
13	4.9474	4.4201	1.4403
14	4.1	4.2859	1.3717
15	5.0267	4.353	1.3717
16	5.9777	4.3134	
17	5.9777	4.6762	1.5432
18	5.9656	5.173	1.5089
19	6.0479	5.4687	1.7833
20	7.9987	7.1788	2.332
21	7.8266	7.3465	
22	7.7762	7.2794	
23	7.2611	6.7673	1.9204
24	6.4586	6.06	1.7558
Max	7.9987	7.3465	2.332
Min	4.1	4.2859	1.3717
Avg	5.9759	5.5610	1.6606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 303 / 22KV SUSHAMA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.97	2.0394	.5853
2	1.8747	1.9266	.5487
3	1.8138	1.8961	.5487
4	1.8481	1.8961	.5487
5	1.8976	1.9997	.5853
6	2.1339	2.0911	.6219
7	2.4425	2.3625	.695
8	2.492	2.5576	.7316
9	2.4448	2.3777	.6859
10	2.4143	2.1308	.6859
11	2.4814	1.9632	.6859
12	2.3868	1.8961	.6859
13	2.2344	1.8138	.6859
14	2.1216	1.2559	.6859
15	2.2344	.0366	.6859
16	2.2649	.0366	
17	3.4233	.0366	.6516
18	2.0911	.0366	.6173
19	2.0149	2.8197	.6859
20	2.6673	3.0087	.7888
21	2.8136	2.8807	
22	2.7008	2.7679	
23	2.5515	2.521	.7202
24	2.2329	2.1521	.6219
Max	3.4233	3.0087	.7888
Min	1.8138	.0366	.5487
Avg	2.3146	1.8543	.6549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 304 / 22 KV MANGALWAR TALE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	3.956	4.1457	1.829
2	3.7373	3.8363	1.829
3	3.7022	3.7052	1.6461
4	3.7899	3.661	1.6461
5	3.8187	3.7205	1.829
6	4.2082	4.0954	2.0119
7	4.0817	4.3423	2.0851
8	4.0275	4.222	2.0485
9	4.1823	4.3865	
10	4.6852	4.289	2.1262
11	2.524	2.9996	2.4006
12	5.2218	1.5028	2.4006
13	4.9535	1.4235	2.1605
14	4.9032	1.4022	2.0576
15	4.8148	1.4037	2.0576
16	4.8621	1.3641	
17	3.216	1.3458	2.1605
18	1.5638	1.4418	2.2291
19	6.8633	2.3518	2.6406
20	6.7124	7.3373	2.8807
21	6.4625	6.2735	
22	5.5433	5.1196	
23	5.0023	4.9155	1.989
24	4.3164	4.3942	1.9753
Max	6.8633	7.3373	2.8807
Min	1.5638	1.3458	1.6461
Avg	4.4645	3.4866	2.1002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]**SATARA CIRCLE[575]****SATARA DIVISION[516]****SATARA (U)[117]****BU 0914****Substation No/ Name :- 254033 / 33/22 KV KARANJE SS****Feeder No / Name : 305 / 22 KV S. T. STAND****SHEDDABLE URBAN****Feeder KV- 22 / OUTGOING**

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	3.4606	3.5223	1.4632
2	3.3623	3.2236	1.39
3	3.3181	3.184	1.3535
4	3.2678	3.1718	1.3535
5	3.3867	3.3791	1.4632
6	3.5391	3.5802	1.6095
7	3.6824	3.8104	1.8656
8	3.6732	3.658	1.829
9	3.8242	3.5787	1.7147
10	3.9293	3.5696	1.7147
11	2.1552	2.3426	1.9204
12	4.2418	1.0059	1.8861
13	4.2006	.9542	1.7147
14	4.2326	.9481	1.5432
15	4.2433	1.8534	1.5432
16	4.196	3.0026	
17	4.2021	4.1304	1.6461
18	4.0345	1.8229	1.6461
19	4.318		2.1605
20	5.0496	5.3086	2.1262
21	4.7554	4.9901	
22	4.4398	4.5298	
23	4.2478	4.132	1.8519
24	3.6946	3.7677	1.6461
Max	5.0496	5.3086	2.1605
Min	2.1552	.9481	1.3535
Avg	3.8940	3.1942	1.6877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR

Feeder No / Name : 301 / 22 KV PIRWADI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3353	.7316
2	.3353	.3353	.6219
3	.3719	.2987	.5853
4	.3719	.2987	.5121
5	.3719	.2987	.4755
6	.3353	.3353	.5487
7	.3353	.3353	.5853
8	.2987	.3353	.6219
9	.2987	.2621	.5487
10	.2987	.2987	.6219
11	.3353	.2987	.5853
12	.2987		.5853
13	.2987		.5487
14	.2987		.5487
15	.2987		.5853
16	.2621		.5121
17	.3353		.5487
18	.2987		.5121
19	.3353	1.6034	.6219
20	.2987	1.7558	.6584
21	.3719	1.5669	.6584
22	.3719	1.5303	.6219
23	.3719	1.5669	.5487
24	.3719	.6097	.5487
Max	.3719	1.7558	.7316
Min	.2621	.2621	.4755
Avg	.3292	.7097	.5807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR

Feeder No / Name : 302 / 22 KV SADAR BAZAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.6886	2.652	2.7801
2	2.7252	2.652	2.7069
3	2.8349	2.463	2.3045
4	2.6825	2.463	2.3777
5	2.6825	2.463	2.3411
6	2.5728	2.5362	2.3045
7	2.6886	2.7617	2.3411
8	2.6886	2.652	2.4874
9	2.7617	2.4264	2.7069
10	2.652	2.3533	2.8898
11	2.463	4.8712	3.1459
12	2.463	5.7491	3.2556
13	2.463	5.4504	3.1824
14	2.4264	5.676	2.9995
15	2.463	5.7491	2.9995
16	2.463	5.6394	3.1459
17	2.4996	5.487	3.1093
18	2.4264	5.4138	2.8166
19	2.7617	5.2248	3.1459
20	3.3227	5.9747	3.1824
21	3.3959	5.9747	3.1824
22	3.3227	5.7491	2.963
23	3.213	5.7491	2.5606
24	2.9508	2.5911	2.5606
Max	3.3959	5.9747	3.2556
Min	2.4264	2.3533	2.3045
Avg	2.7338	4.1968	2.8121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]**SATARA CIRCLE[575]****SATARA DIVISION[516]****SATARA (U)[117]****BU 0914****Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS****Feeder No / Name : 302 / 22 KV POWAI NAKA****Feeder KV- 22 / OUTGOING****NON SHEDDABLE WATER SUPPLY AND
UTILITY**

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	22.4508	22.1994
2	21.3077	21.0563
3	20.6447	20.3932
4	20.2104	20.0732
5	20.1875	20.1418
6	21.3535	21.0334
7	21.9022	21.5364
8	22.3366	21.8107
9	22.7481	21.6964
10	24.4628	22.7252
11	***	18.5185
12	***	10.6082
13	***	
14	***	
15	***	.3429
16	***	.0229
17	***	10.6538
18	***	20.599
19	***	20.3018
20	***	22.0393
21	***	21.765
22	***	19.9817
23	***	18.6785
24	24.7371	16.781
Max	30.7956	22.7252
Min	20.1875	.0229
Avg	25.1353	17.8618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 303 / 22 KV RADHAKRISHNA

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	8.5963	9.0306
2	9.465	8.8706
3	8.5048	8.5734
4	8.6877	8.3905
5	8.5277	8.3219
6	8.4591	8.6877
7	8.7792	8.5734
8	8.5505	7.1331
9	9.0535	4.2753
10	10.9054	4.2981
11	10.9968	4.161
12	11.3398	4.1381
13	10.5624	4.321
14	10.8368	4.3439
15	11.7284	4.4582
16	11.8427	4.321
17	11.4769	4.3439
18	11.134	4.2524
19	10.1052	.0229
20	9.5336	4.2295
21	9.2364	4.3896
22	9.5336	4.2524
23	9.1678	4.2295
24	9.3507	4.2295
Max	11.8427	9.0306
Min	8.4591	.0229
Avg	9.8489	5.4936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 304 / 22KV ARISTOCRAT

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	9.3583	9.2212
2	9.3279	9.2517
3	9.4498	9.023
4	8.7334	8.8706
5	8.078	8.2762
6	8.2914	8.0171
7	8.5048	7.7427
8	8.5353	7.0111
9	9.6937	5.7308
10	9.7394	5.1212
11	11.3855	1.6156
12	11.5379	1.326
13	10.6234	1.3108
14	10.2728	1.2651
15	10.8825	3.0178
16	11.7055	3.5665
17	10.7453	3.6123
18	10.2424	3.2465
19	9.5412	4.6944
20	9.7851	4.8926
21	8.9163	4.9383
22	9.1297	4.9535
23	9.084	4.7706
24	9.4346	4.7859
Max	11.7055	9.2517
Min	8.078	1.2651
Avg	9.7083	5.2609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 305 / 22KV OKASA PHARMA

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	.3963	1.1279
2	.3887	1.0288
3	.3887	1.044
4	.381	1.0517
5	.4115	1.0364
6	.4039	1.3717
7	1.1355	1.3717
8	1.5623	1.5851
9	2.4082	2.4006
10	2.5835	2.4996
11	2.6368	.7392
12	2.8502	
13	2.7892	
14	2.8273	1.9281
15	2.8883	2.4996
16	2.8502	2.4768
17	2.7587	2.4844
18	2.3243	2.1872
19	1.9966	1.6613
20	1.8061	1.6309
21	1.8214	1.448
22	1.768	1.3413
23	1.5623	1.3946
24	1.4327	1.2117
Max	2.8883	2.4996
Min	.381	.7392
Avg	1.7655	1.6146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 201 / PARALI-SATARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6875	.3624	.3018
2	.6573	.3521	.2829
3	.6455	.3384	.2829
4	.6527	.3513	.2829
5	.6834	.3368	.3018
6	.8861	.4214	.3961
7	1.1216	.4607	.5281
8	1.0774	.0004	.4481
9	.6123	.2122	.5228
10	1.1749	.5083	.2614
11	1.175	.4218	
12	.5235	.4146	.3174
13	.4527	.3475	
14	.4527	.0027	
15		.0046	
16		.2721	
17		.2961	
18	.9436		
19	1.1912	.5865	
20	1.3797	1.0319	.6979
21	1.4202	.57	
22	.6771		.5847
23	.5521	.4462	
24	.8002	.3932	.3395
Max	1.4202	1.0319	.6979
Min	.4527	.0004	.2614
Avg	.8460	.3696	.3963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 202 / THOSEGHAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2452		.2263
2	.2452		.2075
3	.2452		.2075
4	.2452		.2075
5	.2641		.2263
6	.3395		.3206
7	.4338		.3961
8	.4338		.3734
9			.3734
10	.3772		.3547
11	.3961		.3361
12			.2987
13	.3961		
14	.3772		
15	.2829		
16	.3772		
17	.2452	.3018	
18	.3772		.3961
19	.415	.4527	.3961
20	.5041	.5093	.5281
21	.5228	.4527	.4338
22			.4715
24	.2452		.2263
Max	.5228	.5093	.5281
Min	.2452	.3018	.2075
Avg	.3484	.4291	.3322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 203 / Nitral Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	***	***	.0377
2	***	***	.0377
3	***		.0377
4	***		.0377
5	***		.0377
6	***		.0754
7	***		.0943
8	***		.0943
9	***		.0754
10	***		.0943
11	***		.0943
12	***	***	.1132
13	***		
14	***		
15	***		
16	***		
17	***	***	
18	***		.0754
19	***	***	.132
20	***	***	.132
21	***	***	
22	***	***	.132
23	***	***	
24	***	***	.0377
Max	152.548	152.5669	.132
Min	38.1417	38.104	.0377
Avg	81.0362	83.8722	.0788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 204 / PARALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
9		.8192
10	1.1506	.9556
11	.9431	
12	1.2637	.8886
13	1.2637	
16	1.1317	
Max	1.2637	.9556
Min	.9431	.8192
Avg	1.1506	.8878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 201 / 11 KV ANGAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.105	.1008	.1195
2	.1014	.0961	.1475
9		2.3838	2.5953
10	2.7697	2.6281	2.7898
11	2.7965	2.7592	2.6554
12	2.6892	2.6299	2.5526
13	2.6825	2.6674	2.5367
14	2.6758	2.3838	2.3073
15	2.7228	2.481	2.2734
16	2.5752	2.5953	2.1104
17	.161	.1382	.0754
18	.17	.1344	.1772
19	.1792	.1494	.1734
20	.1478	.1531	.2033
21	.1441	.14	.1738
22	.1207	.1531	.1559
23	.1072	.1214	.1402
24	.1086	.0998	.1456
Max	2.7965	2.7592	2.7898
Min	.1014	.0961	.0754
Avg	1.1916	1.2119	1.1852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 202 / 11 KV ANGAPUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3185	.3142	.267
2	.3077	.3031	.2652
3	.3005	.2987	.2561
4	.3005	.2963	.267
5	.3041	.3174	.3182
6	.4115	.4257	.4036
7	.3696	.4472	.4271
8	.3747	.4361	.3765
9		.3383	.3105
10	.2487	.3032	.2614
11	.2561	.2857	.239
12	.2451	.2826	.239
13	.2561	.2717	.2577
14	.2743	.2734	.2166
15	.2597	.2804	.2502
16	.286	.2835	.2339
17	.2661	.2932	.2507
18	.2875	.2707	.2606
19	.4182	.3656	.3256
20	.4657	.4163	.4706
21	.4731	.3982	.4444
22	.4108	.3783	.4097
23	.3547	.3149	.3384
24	.3363	.3323	.278
Max	.4731	.4472	.4706
Min	.2451	.2707	.2166
Avg	.3272	.3303	.3070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 204 / 11 KV JIHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6125	.5961	.2231
2	.5708	.5505	.2414
3	.5563	.5439	.2378
4	.286	.555	.2597
5	.2817	.6005	.3219
6	.3801	.6903	.333
7	.3891	.8037	.409
8	.3294	.7925	.3511
9		.7285	.3547
10	.3439	.6725	
11	.333	.6308	.3174
12	.3185	.6028	.3511
13	.3149	.4767	.3253
14	.2679	.4589	.2624
15	.2597	.5318	.292
16	.2634	.5382	.2804
17	.292	.5118	.3077
18	.2987	.5418	.3439
19	.3323	.6759	.417
20	.5452	.9825	.5175
21	.4854	.8245	.4731
22	.4556	.7538	.4145
23	.3548	.6429	.3435
24	.3131	.5593	.267
Max	.6125	.9825	.5175
Min	.2597	.4589	.2231
Avg	.3732	.6361	.3324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 205 / 11 KV VIJAY NAGAR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6155	1.6343	
2	1.5959	1.6376	.1372
3	1.5991	1.6211	.1367
4	1.6155	1.6057	.1332
5	1.5903	1.6509	.1367
6	1.5795	1.7404	.1402
7	1.6745	1.9592	.2209
8	1.7237	1.7973	.2138
23	1.5912	1.2273	
24	1.6516	1.643	1.2004
Max	1.7237	1.9592	1.2004
Min	1.5795	1.2273	.1332
Avg	1.6237	1.6517	.2899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 206 / Tasgaon Ag Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2988	1.2239	.8852
2	1.3075	.295	.8517
3	1.3304	1.187	.845
4	1.3501	1.1768	.8752
5	1.3698	1.2474	.8953
6	1.5041	1.3849	.9322
7	1.5795	1.529	1.0663
8	1.5533	1.3547	1.0529
15	.0448	.0343	.0373
16	.0448	.0175	.0316
17	.0336	.0261	.0354
18	.0373	.0187	.0343
19	.0299	.0187	.0177
20	.0411	.0224	.0368
21	.0448	.0299	.0322
22	.034	.0299	.0526
23	1.3077	.9255	1.0559
24	1.3173	1.2608	.8919
Max	1.5795	1.529	1.0663
Min	.0299	.0175	.0177
Avg	.7905	.6546	.5350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 201 / 11 KV VALASE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0514	.2743
2	.0343	.0514	.2572
3	.0171		.2572
4	.0171		.2401
5	.0171		.3944
6	.0343		.4458
7	.0343		
8	.0343		
9	1.4746	1.8519	
10	1.4746		
11	1.6118		
12	1.4575		
13	1.6461		2.4348
14			2.5377
15	1.5089		3.1379
16	1.5089		
17	.0514		
18	.0514	.0171	2.4364
19	.0514	.0343	.1578
20	.0514	.0343	.1928
21	.0514	.0514	.1928
22	.0514	.0514	.1928
23	.0514		.1829
24	.0343	.0514	.2743
Max	1.6461	1.8519	3.1379
Min	.0171	.0171	.1578
Avg	.4913	.2438	.8506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 204 / 11 KV SHENDRE-VECHALE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	4.1381	4.007	.5487
2	3.9632	3.7731	.5316
3	3.9998	3.7605	.5316
4	4.0859	3.7639	.5487
5	4.2951	3.7643	.6001
6	4.3271	3.7986	.6516
7	4.4467	4.5294	.6859
8	4.8731	4.544	.703
9	4.9493	2.4044	
15			.0686
16	.152	.016	
17	.1852	.0015	
18	.1707		.0934
19	.1661		.0934
20	.1677	.152	.112
21	.173	.1722	.112
22	.1707	.0968	.0934
23	3.5833	1.0093	1.5729
24	4.1355	2.556	.5487
Max	4.9493	4.544	1.5729
Min	.152	.0015	.0686
Avg	2.6657	2.3968	.4685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 205 / VALASE (GAONTHAN)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1886	.3944	.3944
2	.1715	.3772	.3601
3	.1543	.3601	.3601
4	.1543	.3772	.3601
5	.1715	.3772	.3944
6	.1886	.3944	.4287
7	.1886	.463	.4801
8	.1715	.3944	.4458
9		.3944	
10	.2572		
11	.463		.4458
12	.5658		
13	.4458		.4801
14	.3944		
15	.4115		.4115
16	.4287		
17	.4115		
18	.4801		.4435
19	.5316		.4294
20	.583	.2915	.6161
21	.583	.4801	.5975
22	.5487	.5144	.5601
23	.4801	.4801	.5121
24	.2229	.4287	.4287
Max	.583	.5144	.6161
Min	.1543	.2915	.3601
Avg	.3564	.4091	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 302 / LIMB

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4108	.381
2	.4108	.3734	.3772
3	.4066	.3734	.3772
4	.4066	.3734	.4191
5	.4066	.3734	.415
6	.439	.4108	.5281
7	.4755	.4108	.6036
8	.4706		.3734
9	.8505		.6722
10	.9568		.8589
11	1.0985		1.0456
12	1.0985		1.1203
13	1.134	.4344	1.1203
14	1.3466	.4024	1.0456
15	1.134	.567	1.307
16	1.2696	.3544	.9709
17	1.1203	.3696	.924
18	.7468	.3734	.6722
19	.4481	.3734	.3734
20	.5601	1.7002	.4805
21	.4854	1.7177	.4481
22	.5228	.4191	.3734
23	.4481	.3772	.3734
24	.4481	.4481	.3772
Max	1.3466	1.7177	1.307
Min	.4066	.3544	.3734
Avg	.7138	.5402	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 303 / 22 KV VARYE MIX

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.4022	.9145
2	1.6804	***	.9054
3	1.6263	1.3321	.9054
4	1.6263	1.3321	.9907
5	1.848	1.4022	1.2071
6	2.0485	1.6476	1.358
7	2.268	1.9631	1.5844
8	2.4253	1.7878	1.6804
9	2.3034	1.9136	1.6126
10	2.0908	1.8427	1.5074
11	2.1262	1.7878	1.3321
12	2.0553	1.3112	1.5424
13	2.0553	1.2048	1.6126
14	1.949	1.5238	1.6126
15	1.382	1.4883	1.5424
16	1.8229	1.4998	1.5775
17	2.1033	1.3306	1.6655
18	2.2436	1.419	1.7718
19	2.3838	1.4937	1.8781
20	2.4539	1.4045	1.9418
21	2.1384		1.8427
22	1.9281	.8764	1.5074
23	1.6476	.9054	1.4022
24	1.6804	1.5074	.9808
Max	2.4539	133.2116	1.9418
Min	1.382	.8764	.9054
Avg	1.9820	7.1995	1.4532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 304 / 22 KV RAMNAGAR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.9035	2.5507	.1143
2	2.8563	2.4104	.1132
3	2.822	2.3952	.1132
4	2.886	2.3289	.1143
5	2.9234	2.3853	.1509
6	3.11	2.6898	.1509
7	3.357	3.1303	.1509
8	3.4015	2.8913	.1494
9	1.0463	.9877	
15	.2949	.3078	.0995
16	.41	.1532	.0995
17	.334	.3086	.0995
18	.334	.3087	.0995
19	.3525	.3125	.1326
20	.3761	.3109	.1326
21	.3586	.3018	.1326
22	.327	.3048	.1326
23	2.5831	.2565	.8951
24	2.8524	1.3268	.1132
Max	3.4015	3.1303	.8951
Min	.2949	.1532	.0995
Avg	1.7647	1.3506	.1663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 201 / KOPARDE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
9	1.6975	1.9978	1.4403
10		2.1472	1.5424
11	1.7918	2.0165	1.4403
12	1.6975	1.9791	1.4083
13	1.7164		1.4403
14		1.7737	1.5089
15	1.6787	1.6991	1.5089
16	1.6787	1.6991	
21	.1509		
Max	1.7918	2.1472	1.5424
Min	.1509	1.6991	1.4083
Avg	1.4874	1.9018	1.4699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 202 / VENEGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3506	.415
2	.3734	.3506	.3772
3	.3547	.333	.3584
4	.3547	.333	.3395
5	.4668	.3856	.415
6	.6348	.4961	
7	.5601	.5731	.5281
8		.5014	.5093
9	.4527	.4481	.4031
10	.3772	.4108	.3506
11	.3584	.3921	.3506
12	.3772	.3734	.3403
13	.3961		.3155
14		.3734	.333
15	.3961	.3734	.333
16	.3395	.3734	
17	.4031	.3772	.3734
18	.4119	.5093	.3734
19	.5014	.6036	.5975
20	.7537	.679	.6908
21	.7701	.6036	.7468
22	.6089		
23	.5014		.5228
24	.4294	.4119	.4715
Max	.7701	.679	.7468
Min	.3395	.333	.3155
Avg	.4643	.4406	.4355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 203 / NANDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.894	2.572	1.9993
2	2.894	2.4863	2.0182
3	2.894	2.3472	2.0182
4	2.9874	2.3472	2.0182
5	3.0434	2.431	2.1502
6	3.1181	2.713	2.2634
7	3.1927	2.8807	2.452
8		2.8121	2.4897
15	.0189		.0189
16	.0189	.0187	
17	.0189	.0189	
18	.0189	.0189	.0187
19	.0189	.0189	.0187
20	.0377	.0189	.0187
21	.0377	.0189	.0373
22	.0377		
23	2.4813		2.5206
24	2.894	2.5484	1.9993
Max	3.1927	2.8807	2.5206
Min	.0189	.0187	.0187
Avg	1.5651	1.5501	1.4694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 201 / 11 KV DEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0747	.0566
2	.0566	.0747	.0566
9	1.6712		1.3283
10	1.8244	1.8724	1.4563
11	2.0485	1.5203	1.3283
12	1.9204	1.8461	1.4232
13	1.7711	1.8461	1.3599
14	1.8084	1.704	1.3599
15	1.8244	1.4506	1.2176
16	1.7604	1.4373	1.2651
17	.0934	.112	.0747
18	.0934	.1132	.0754
19	.0739	.112	.0754
20	.0747	.0943	.0754
21	.0739	.0943	.0754
22	.0747	.0943	.0566
23	.0747	.0943	.056
24	.056	.0747	.0566
Max	2.0485	1.8724	1.4563
Min	.056	.0747	.056
Avg	.8532	.7421	.6332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 202 / VARNE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0277	.9804	.7842
2	.9831	.9962	.7682
3	.9831	1.0242	.7682
4	.9945	1.0279	.7449
5	1.0608	1.0279	.7449
6	1.094	1.0722	.7611
7	1.1142	1.1385	.8322
8	1.1305	1.0279	.9014
14	.2401		
15	.2401	.1494	.168
16	.1867	.1294	.1867
17	.168	.1448	.1867
18	.2054	.1494	.1698
19	.2218	.1509	.1698
20	.1867	.1132	.168
21	.1848	.1132	.168
22	.2054	.1509	.168
23	.9804	.8097	.8029
24	1.094	1.0242	.7935
Max	1.1305	1.1385	.9014
Min	.168	.1132	.168
Avg	.6474	.6239	.5159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 203 / DEGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3761	.362
2	.4024	.3582	.3439
3	.4066	.3761	.3475
4	.4207	.362	.3475
5	.4572	.3898	.3841
6	.5175	.4075	.4344
7	.6154	.5258	.4656
8	.4835	.4733	.4298
9	.4508		.4252
10	.4161	.443	.3582
11	.4508	.3982	.3189
12	.4382	.4161	.3641
13	.4908	.3772	.4031
14	.4508	.3506	.3814
15	.4334	.3467	.4075
16	.4607	.298	.3582
17	.4656	.3189	.3018
18	.4887	.3366	.3601
19	.5194	.4119	.3982
20	.6154	.4887	.567
21	.5847	.4755	.5359
22	.543	.462	.499
23	.4382	.4207	.4435
24	.439	.3898	.3841
Max	.6154	.5258	.567
Min	.4024	.298	.3018
Avg	.4746	.4001	.4009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 204 / 11 KV CHINCHNER GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2767	.2905	.1294
2	.274	.2871	.1109
3	.2694	.2864	.1109
4	.2679	.3121	.1109
5	.3464	.3178	.1307
6	.4245	.373	.2054
7	.4054	.4283	.1991
8	.3647	.4083	.197
9	.3235	.1901	.1595
10	.3505	.3155	.1402
11	.3319	.2808	.1402
12	.2776	.2746	.1417
13	.2671	.2618	.1227
14	.264	.2749	.124
15	.2549	.2469	.1227
16	.2367	.2561	.1052
17	.2832	.2843	.1063
18	.3115	.3178	.1052
19	.3868	.3976	.124
20	.4855	.4443	
21	.4466	.4184	.1646
22	.4279	.3625	.1663
23	.3807	.3109	.1494
24	.3066	.2892	.1294
Max	.4855	.4443	.2054
Min	.2367	.1901	.1052
Avg	.3318	.3179	.1389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 205 / 11KV VARNE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4873	.4589	.2012
2	.4688	.4589	.1829
3	.4664	.4614	.1848
4	.4688	.4386	.1848
5	.5029	.4767	.2012
6	.5212	.509	.2561
7	.6487	.6134	.2328
8	.5325	.6134	.2658
9	.4915	.2667	.2254
10	.4344	.5382	.2058
11	.4687	.502	.208
12	.449	.35	.2279
13	.4713	.4031	.2481
14	.1905	.3896	.1949
15	.2286	.4614	.2103
16	.5298	.4031	.1928
17	.5582	.3854	.2686
18	.5852	.4031	.2328
19	.606	.4972	.2507
20	.746	.634	.394
21	.715	.619	.394
22	.663	.5624	.3224
23	.5883	.4862	.2772
24	.4873	.4793	.2012
Max	.746	.634	.394
Min	.1905	.2667	.1829
Avg	.5129	.4755	.2402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 201 / 11 kv BHATMARALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2125	1.2689	.7545
2	1.1385	1.2689	.7356
3	1.166	1.2517	.7167
4	1.0883	1.2346	.7167
5	1.1498		.7545
6	1.3889	1.3032	.7733
7	1.4373	1.5089	.8676
8	1.4706	1.406	.9242
15	.0377	.0335	.0381
16		.0335	.0335
17	.0381		.0316
18	.0381	.0377	.0309
19	.0572	.0377	.0328
20	.0572	.0366	.048
21	.0572	.0377	.0503
22	.0572	.0377	.0324
23	1.2574	.7373	.7274
24	1.2574	1.2574	.7545
Max	1.4706	1.5089	.9242
Min	.0377	.0335	.0309
Avg	.7594	.7182	.4457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 202 / 11 KV KUSAVADE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3045	.4191	.2926
2	.3012	.4191	.3018
3	.2896	.381	.2829
4	.2601	.381	.2829
5	.3155	.4191	.3206
6	.4706	.4763	.3584
7	.5258	.5335	.5093
8	.5258	.4954	.4715
9	.3841		.4191
10	.3429		.4191
11	.3475		.381
12	.3772		.381
13	.3584		.381
14	.3961		.3429
15	.3658	.3721	.3048
16	.3772	.3721	.3898
17	.3429	.2641	.362
18	.3429	.3206	.3814
19	.4954	.1509	.4656
20	.5716	.3772	.5784
21	.6097	.5281	.5083
22	.6097	.5093	.443
23	.4954	.3395	.3681
24	.3258	.4572	.3206
Max	.6097	.5335	.5784
Min	.2601	.1509	.2829
Avg	.4057	.4009	.3861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 203 / 11 kv PADALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1227	.1524	.132
2	.1107	.1524	.128
9	1.773		1.3413
10	1.7918		1.4922
11	1.9239		1.6289
12	1.905		1.6632
13	2.037		1.5089
14	2.0559		1.4251
15	2.0182	1.1736	1.4232
16	1.9993	1.5223	1.3603
17	.1524	.1509	.1006
18	.1715	.0943	.1265
19	.1715	.1509	.1402
20	.1715	.1509	.125
21	.1715	.1509	.125
22	.1524	.1509	.1296
23	.1524	.1463	.1296
24	.1341	.1524	.1509
Max	2.0559	1.5223	1.6632
Min	.1107	.0943	.1006
Avg	.9453	.3457	.7295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 204 / 11 KV NINAM GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3012	.3429	.2641
2	.2804	.3429	.2641
3	.2804	.3048	.2452
4	.298	.3048	.2452
5	.333	.3429	.3206
6	.394	.4572	.3772
7	.3988	.5716	.4527
8	.3506	.5335	.3772
9			.3048
10	.2561		.381
11	.3961		.4572
12	.547		.381
13	.5093		.4191
14	.4715		.381
15	.4338	.3012	.6478
16		.3292	.567
17	.8383	.3206	.5973
18	1.1812	.3584	.4887
19	.4382	.4715	.4075
20	.5335	.547	.5258
21	.5335	.4715	.4607
22	.4954	.5093	.4207
23	.4191	.3584	.3366
24	.3258	.381	.2829
Max	1.1812	.5716	.6478
Min	.2561	.3012	.2452
Avg	.4552	.4027	.4002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 403 / 33 KV KIRLOSKAR EXPRESS

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	1.3546	1.2517
2	1.3546	1.3203
3	1.3546	1.3117
4	1.3546	1.406
5	1.346	1.3375
6	1.346	1.3032
7	1.346	1.3032
8	1.3546	1.3203
9	1.3546	1.3117
10	1.3546	1.3717
11	1.346	1.3632
12	1.3203	1.3546
13	1.3203	1.3289
14	1.3117	1.346
15	1.3203	1.3375
16	1.3975	1.3546
17	1.7918	1.6461
18	1.929	1.7318
19	1.8947	1.689
20	1.809	1.5947
21	1.6975	1.5689
22	1.749	1.6032
23	1.7833	1.5604
24	1.6461	1.3803
Max	1.929	1.7318
Min	1.3117	1.2517
Avg	1.4932	1.4207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 301 / PIMPODE Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5761		
2	.5761		
3	.5761		
8	1.0242		
9	1.4723	1.1869	.78
10	1.4582	1.1191	.8817
11	1.56	1.1869	
12	1.6617	1.0513	1.153
13	1.3904		1.1694
14	1.56	.2713	1.0174
15	1.1869	.8322	1.1191
16	1.2887	.9602	1.2209
17	.1372		
18	.1867		
19	.2058		
20	.2058		
21	.2401		
22	.2401		
23	.2058		
24	.6401	.1715	
Max	1.6617	1.1869	1.2209
Min	.1372	.1715	.78
Avg	.8196	.8474	1.0488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 302 / 22KV PIMPODE GAOTHAN
Feeder KV- 22 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3734		.3361
2	.3734		.3361
3	.3734		.3361
4	.4108		.3734
5	.4481		.4108
6	.4854		.3734
7	.5228		.4854
8	.4108		.4108
9	.4481	.4748	.373
10	.4409	.407	.3052
11	.407		.3391
12	.3052	.373	
13	.3391	.3391	
14	.407	.2713	.3391
15	.4409	.2374	.2713
16		.2987	.3052
17		.2614	
18		.3361	
19		.4481	
20	.7888	.5975	
21		.5228	
22		.4854	
23	.4801	.3734	
24	.3734	.3772	.3361
Max	.7888	.5975	.4854
Min	.3052	.2374	.2713
Avg	.4349	.3869	.3554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 303 / SONKE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3734		.2987
2	.3734		.2987
3	.3734		.3361
4	.3734		.3734
5	.4481		.4108
6	.5601		.5975
7	.5601		.4481
8	.4108		.4108
9	.3734	.4409	.3052
10	.3018	.407	.2713
11	.3052		.2713
12	.3018	.3391	.2035
13	.3052	.3052	.2035
14	.2713	.2374	.2713
15	.2713	.2035	.2743
16	.2713	.3361	.2713
17	.2058	.2614	.2713
18		.3361	
19		.4108	
20		.5601	
21		.4481	
22		.3734	
23	.4854	.3361	
24	.3734	.3772	.2987
Max	.5601	.5601	.5975
Min	.2058	.2035	.2035
Avg	.3652	.3582	.3231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 304 / 22 KV SONAKE AG FEEDER
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2214		.4588
2	.2294		.3605
3	.2622		.3605
4	.2949		.3932
5	.2622		.3605
6	.2622		.5243
7	.2949		.6554
8	.2622		.6226
9	.2949	.5765	
10	.2713	.4748	
11	.2035		
12	.2374	.2035	
13	.2012	.2035	
14	.2713	.2035	
15	.2035	.2035	
16	.1357	.3277	
17	.2058	.1966	
18	.2401	.2622	
19	.2401	.2622	
20	.2743	.2622	
21	.3086	.2949	
22		.2949	
23	.5144	.4915	
24	.2294	.583	.4588
Max	.5144	.583	.6554
Min	.1357	.1966	.3605
Avg	.2574	.3227	.4661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 305 / 22 KV WATHAR (GAOTHAN)

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6722		.3734
2	.5898		.3734
3	.4854		.3734
4	.4854		.4108
5	.5601		.4108
6	.5975		.5601
7	.6348		.6348
8	.5601		.5975
9	.5601	.5426	.4748
10	.6104	.407	.5087
11	.7461	.4409	.5426
12	.7468	.4409	.679
13	.6443	.373	.3391
14	.6104	.3391	.373
15	.5765	.3391	.4748
16	.6443	.4108	.407
17	.6173	.4481	
18	.6859	.4481	
19	.5487	.5975	
20	.7842	.7095	
21	.6859	.5975	
22	.8573	.5601	
23	.7202	.4854	
24	.6722	.5487	.3734
Max	.8573	.7095	.679
Min	.4854	.3391	.3391
Avg	.6373	.4805	.4651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 306 / 22 KV WATHAR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7865		.2622
2	.6882		.2622
3	.6882		.2622
4	.6882		.2622
5	.7865		.2622
6	.9175		.3277
7	1.0814		.3277
8	1.0486		.3277
9	1.1797	1.153	.3052
10	1.0174	1.0174	.2713
11	.9496	1.0852	.2035
12	.9835	.9496	.2012
13	.8139	.8139	
14	.9496	.7461	.2713
15	1.0174	.8817	.3052
16	.8817	.9175	.2713
17	.2743	.2622	
18	.3086	.1966	
19	.3086	.2622	
20	.4108	.3277	
21	.3429	.3277	
22	.3086	.2949	
23	.3086	.2622	
24	.7865	.2743	.2622
Max	1.1797	1.153	.3277
Min	.2743	.1966	.2012
Avg	.7303	.6108	.2741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 307 / 22 KV Nandwal AG Feeder
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7933	.2218	.0983
2	.7377	.2218	.0983
3	.7285	.2187	.0983
4	.7301	.2149	.0983
5	.0038	.2294	.0983
6	.0038	.2705	.3605
7	.1113	.2865	.5571
8	.2118	.2919	.426
9	1.7673	1.3192	.0034
10	1.8865	1.4982	.0034
11	1.8827	1.3649	.0034
12	1.7359	1.8896	.0034
13	1.6091	1.5455	
14	1.4567	.7693	.0034
15	1.2989	1.4255	.0034
16	1.3904	1.4106	.0034
17	1.3081	.0038	
18	.218	.0571	
19	.2301	.0671	
20	.2644	.0038	
21	.2843	.0038	
22	.2728	.0038	
23	.2553	.1311	
24	.2309		.0983
Max	1.8865	1.8896	.5571
Min	.0038	.0038	.0034
Avg	.8088	.5847	.1223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 301 / 22KV Koregaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.749	
2	1.5089	1.166	1.3717
3	1.4403	.9945	1.5089
4	1.5089	1.7833	1.4403
5	1.7833	1.749	1.9204
6	2.2291	2.1948	2.0576
7	2.1948	2.4348	2.1262
8	2.1605	.8916	2.1948
9	1.9547	.9602	1.6461
10	1.8519	1.6461	1.829
11	1.749	1.7147	1.829
12	1.9204	1.7833	1.7985
13	1.7833	1.7833	1.768
14	1.8519	.4115	1.6766
15	1.8176	.6173	1.6461
16	1.9547	.5487	1.7071
17	1.9204	1.3375	1.6766
18	2.0576	1.6461	1.7375
19	2.4348	2.1262	2.0119
20	2.7435	2.332	2.3167
21	2.5377	2.1948	2.1948
22	2.3663	2.1948	2.0424
23	2.0919	1.9204	1.768
24	.5144	1.9204	1.6118
Max	2.7435	2.4348	2.3167
Min	.5144	.4115	1.3717
Avg	1.9119	1.5875	1.8209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 303 / 22 KV DEURGAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429
2	.3429	.3772	.3429
3	.3772	.3772	.3429
4	.3429	.4115	.4115
5	.3772	.3772	
6	.4115	.4458	
7	.4115	.5144	.4115
8	.3772	.1715	.4801
9	.3429	.3429	.3658
10	.3429	.4115	.3353
11	.2743	.3086	.3353
12	.3086	.3429	.3048
13	.2743	.3429	.2134
14		.2743	.3353
15	.1372	.2743	.3048
16	.2058	.3429	.3048
17	.3772	.3429	.3353
18	.4801		.3048
19	.6859	.4115	.3963
20	.7888	.6859	.5487
21	.6859	.6173	.4572
22	.6173	.5487	.4572
23	.5144	.4115	.3658
24	.3772	.4115	.3429
Max	.7888	.6859	.5487
Min	.1372	.1715	.2134
Avg	.4085	.3951	.3654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 304 / 22KV KINHAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4115	.4115
2	.5144	.4458	.4801
3	.4801	.4115	.5144
4	.5144	.4801	.6173
5	.5144	.5487	.5487
6	.6173	.6516	.6173
7	.6859	.7202	.6173
8	.7202	.6173	.6173
9	.6173	.6859	.5182
10	.5144	.4801	.4572
11	.5487	.4801	.4268
12	.5144	.4801	.4268
13	.4458	.4115	.4268
14	.4115	.4115	.4572
15	.4458	.4801	.4572
16	.4458	.4458	.4572
17	.5144	.5281	.4877
18	.5487	.6173	.4877
19	.7202	.823	.6097
20	.8573	1.2346	.7621
21	.7545	.6859	.7316
22	.6859	.6516	.6097
23	.583	.5144	.4877
24	.4801	.4801	.4458
Max	.8573	1.2346	.7621
Min	.4115	.4115	.4115
Avg	.5701	.5707	.5281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 301 / WATHAR i.e. 22KV KINHAI SEPARATED AG FEEDERS HAVING SPECIAL
AG. Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
15	.2058		
24	.4115	4.9383	4.1152
Max	.4115	4.9383	4.1152
Min	.2058	4.9383	4.1152
Avg	.3087	4.9383	4.1152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 303 / 22 KV COOPER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
15	.5144		
24	.7545	1.4403	.6859
Max	.7545	1.4403	.6859
Min	.5144	1.4403	.6859
Avg	.6345	1.4403	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 304 / 22KV BHUINJ i.e. 22KV SEPARATED AG FEEDERS HAVING SPECIAL
DEUR AG Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
15	6.4129		
24	5.7613	.4801	.4801
Max	6.4129	.4801	.4801
Min	5.7613	.4801	.4801
Avg	6.0871	.4801	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 406 / 33KV WANGANA LIS

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	29-MAY-17
HR	Load (MW)
15	.0514
24	.0514
Max	.0514
Min	.0514
Avg	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 407 / 33KV VASANA

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-MAY-17
HR	Load (MW)
15	1.3889
24	.8745
Max	1.3889
Min	.8745
Avg	1.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 201 / 11 KV Aundh Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4344	
2	.4207	.4344	
3	.4207	.4344	
4	.4572	.4344	
5	.5121	.4525	.543
6	.5853	.4887	.543
7	.6401	.543	.543
8	.5487	.5792	.543
9	.5487	.4706	.543
10	.5487	.4525	.543
11	.3475	.4525	.543
12	.4755		.362
13	.5487		.4525
14			.4525
15			.4344
16			.3801
18		.5068	
19		.543	.6154
20	.6767	.543	.6335
21	.1698	.543	.5792
22	.1698	.543	.543
23	.5121		.4344
24	.5121	.4344	
Max	.6767	.5792	.6335
Min	.1698	.4344	.362
Avg	.4751	.4876	.5111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 202 / 11 KV Aundh AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5121	.0362	
2	.5144	.0362	
3	.5144	.0362	
4	.6001	.0362	
5	.6516	.0362	
6	.6859	.0362	
7	.7316	.0362	
8	.7716	.0362	
9	.6325	.7449	
10	.6009	.9393	
11	.7274	.6478	
12	.3749		.3239
13	.4999		.2591
14			.2591
15			.2591
16			.7125
18		.0362	
19		.0362	.6874
20	.506		.6964
21	.4858		.7773
22	.0366		.7287
23	.0366		.0724
24	.5121	.0362	
Max	.7716	.9393	.7773
Min	.0366	.0362	.0724
Avg	.5219	.1950	.4776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 303 / BHOSARE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6584	.0724	.0724
2	.6173	.0724	.0724
3	.5144	.0724	.0724
4	.6173	.0724	.0724
5	.6584	.0724	.0724
6	.7316	.0724	.0724
7	.7316	.0724	.0724
8	.7545	.0724	.0724
9	.6325	.6478	.6478
10	.6325	.7773	.6478
11	.6249	.7125	.6874
12	.5624		.6478
13	.4999	.6478	.6478
14	.4744		.724
15	.3795		.6478
16	.3277	.543	.6478
17	.0732	.0362	.0648
18	.0732	.0724	.0724
19	.0732	.0724	.0724
20	.0732	.0724	.0724
21	.0732	.0724	.0724
22	.0747	.0724	.0724
23	.0747	.0701	.0724
24	.6173	.0724	.0724
Max	.7545	.7773	.724
Min	.0732	.0362	.0648
Avg	.4396	.2118	.2687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 304 / BHOSARE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.439	.4344	.362
2	.3658	.4207	.362
3	.3429	.4344	.362
4	.3658	.543	.362
5	.439	.6516	.362
6	.5487	.724	.5068
7	.6173	.7964	.543
8	.5487	.6516	.5792
9	.439	.543	.4344
10	.3658	.4344	.4344
11	.439	.362	.362
12	.439		.543
13	.439	.362	.543
14	.439	.362	.543
15	.439	.3506	.543
16	.439	.3239	.543
17	.439	.181	.4207
18	.5487	.181	.4207
19	.5487	.181	.5792
20	.8215		.7964
21	.8215		.724
22	.7468		.6516
23	.5601		.5792
24	.439	.4344	
Max	.8215	.7964	.7964
Min	.3429	.181	.362
Avg	.5013	.4406	.5025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 305 / KHATAV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.439	.5792	.4706
2	.439	.5792	.4344
3	.439	.5792	.4344
4	.439	.5792	.4344
5	.439	.6516	.543
6	.6584	.724	.6516
7	.7316	.7964	.724
8	.6584	.724	.543
9	.5487	.6154	.4344
10	.439	.6516	.4344
11	.3292	.543	.4344
12	.5487	.543	.5068
13	.6584	.4344	.5068
14	.6584	.4344	.543
15	.6219	.4344	.5068
16	.5487	.4344	.5068
17	.5487	.4344	.5068
18	.5853		.543
19	.7316	.6516	.724
20	1.0829	.724	.8688
21	1.0456	.7964	.8688
22	.8962	.724	.7964
23	.7095	.6516	.6878
24	.439	.6154	.543
Max	1.0829	.7964	.8688
Min	.3292	.4344	.4344
Avg	.6098	.6044	.5686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 306 / KHATAV AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0732	1.6194	
2	.0732	1.6194	
3	.0732	1.6194	.3239
4	.0732	1.6194	.3239
5	.0732	1.9433	.3239
6	.0732	2.2672	.4858
7	.0732	2.9797	.5506
8	.0732	2.7854	.6478
9	.0732	.0724	.0724
10	.0732	.0724	.0724
11	.0724	.0724	.0724
12	.0732	.0724	.0724
13	.0732	.0724	1.749
14	.0732	.0724	1.749
15	.0732	.0724	.0724
16	.0732	.0724	.0648
17	.0732	.0724	.0724
18	.0732	.0724	.064
19	.0732	.0724	.0724
20	.0747	.0724	.0724
21	.0739	.0724	.0724
22	.0747	.0724	.0724
23	1.5813	.0724	1.5546
24	.0732	1.6194	
Max	1.5813	2.9797	1.749
Min	.0724	.0724	.064
Avg	.1362	.7983	.4077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 301 / 22 KV R Kurle AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1886	.1463
2	.1494	.1886	.1509
3	.1494	.1886	.1509
4	.1867	.1886	.1509
5	.2241	.1886	.1509
6	.2987	.3018	.2263
7	.2641	.2561	.3018
8	.2263	.2263	.2263
9	1.3435	1.6385	1.6975
10	1.4746	1.749	1.5729
11	1.9006	1.6842	1.6712
12	1.9662	1.6518	1.6385
13	1.8679	1.749	1.6385
14	1.5729	1.4575	1.4419
15	1.8351	1.5546	1.4746
16	1.8351	1.5546	1.4251
17	.1509	.1867	.1867
18		.1886	.1494
19	.2641	.2263	.1867
20	.2641	.2263	.2241
21	.2641	.2263	.2241
22	.2641	.1886	.2241
23	.2263	.1509	.2241
24	.1494	.1886	.1509
Max	1.9662	1.749	1.6975
Min	.1494	.1509	.1463
Avg	.7403	.6812	.6514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 302 / 22 KV Pusesavali Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6036	.034
2	.5975	.5853	.3772
3	.5975	.6036	.3772
4	.5975	.6036	.3772
5	.6722	.5853	.3772
6	.7842	.8299	.4904
7	.7167	.8676	.5658
8	.6413	.8299	.5281
9	.7167	.679	.415
10	.5281	.6348	.5281
11	.6036	.5975	.5658
12	.6036	.5601	.5281
13	.6036	.5601	.6413
14	.5658	.5601	.5658
15	.6036	.5975	.6036
16	.6036	.5975	.5975
17			.5601
18		.7167	.5601
19	.6036	.7167	.6722
20	.9431		.8589
21	.8299		.8215
22	.7545	.5281	.7468
23	.679	.5281	.6722
24	.6348	.6036	.3772
Max	.9431	.8676	.8589
Min	.5281	.5281	.034
Avg	.6581	.6376	.5351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 303 / 22 KV Vadgaon AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4108	2.2939	.4359
2	.4108	2.2939	.4359
3	.4108	2.6406	.4359
4	.4108	2.2939	
5	.4481	2.4249	
6	.5228	3.7723	
7		3.7357	
8		3.7723	.0754
9		.4904	.0754
10		.4854	.1132
11		.5228	.1886
12	.3772	.4481	.1509
13	.4527	.3734	.1886
14	.4904	.3361	.2263
15	.5281	.3361	.3395
16		.4481	.4854
17	.415	.4108	.4481
18	.5281	.4527	.4108
19	.6036	.5281	.7888
20	.6036		2.0729
21	.5658	.1509	.5975
22	.5658	.1132	.5975
23	2.4863		2.5263
24	.4108	2.2939	.4359
Max	2.4863	3.7723	2.5263
Min	.3772	.1132	.0754
Avg	.5912	1.3917	.5514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 304 / 22 KV Pusesavali AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6859	.0754	.0754
2	.6859	.0754	.0754
3	.6859	.0754	.0754
4	.6859	.0754	.0754
5	.7202	.0754	.0754
6	.823	.1509	.1509
7		.1132	.1509
8		.1132	.1132
9		1.3108	.8383
10		1.4899	1.1469
11		1.4575	1.1797
12	1.3763	1.4251	1.1797
13	1.1797	1.3927	.9831
14	1.4091	1.2631	.9175
15	1.4419	1.0059	1.1797
16	1.3435	1.0395	1.1012
17	.0754		.112
18	.0754	.0754	.112
19	.0754	.1132	.112
20	.1132	.1132	.1494
21	.1132	.1132	.1494
22	.1132	.1132	.1494
23	.0754	.0754	.112
24	.7202	.0754	.0754
Max	1.4419	1.4899	1.1797
Min	.0754	.0754	.0754
Avg	.6526	.5138	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 306 / 22 KV Vadgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2263	.1132
2	.2241	.1966	.1132
3	.2241	.2263	.1132
4	.2241	.2263	.1132
5	.2241	.2263	.1132
6	.2614	.2641	.1509
7		.2263	.1509
8		.1886	.1509
9	.1886	.1886	.1886
10	.1886	.1494	.1886
11	.1509	.1867	.1509
12	.1509	.1867	.1509
13	.1509	.1867	.1494
14	.1509	.1494	.1494
15		.1494	.1494
16		.1494	.1867
17	.1509	.1494	.112
18	.1886	.1509	.1867
19	.2263	.2641	.2241
20	.3395		.2987
21		.1886	.3361
22		.1886	.2987
23	.2641	.1509	.2614
24	.2241	.2263	.1132
Max	.3395	.2641	.3361
Min	.1509	.1494	.112
Avg	.2087	.1933	.1735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 201 / Ladegaon High School

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0747	.1109
2	.0747	.0747	.0924
3	.0732	.0747	.0924
4	.0732	.0747	.0924
5	.0732	.0732	.0924
6	.1086	.0732	.1109
7	.0895	.1097	.112
8	.0905	.1097	.0924
9	.0895	.0732	.1086
10	.0724	.0366	.1063
11	.1086	.0709	.0886
12	.1086	.0686	.0895
13	.0905	.0633	.0905
14	.1463	.0701	.0905
15			.1097
16			.0914
17			.0732
18	.0732		.0924
19	.1097		.112
20	.1097	.2012	.112
21	.1829	.1991	.112
22	.112	.1463	.112
23	.0943	.1307	.112
24	.0924	.0747	.112
Max	.1829	.2012	.112
Min	.0724	.0366	.0732
Avg	.0984	.0947	.1004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 205 / 11 KV Karkhana AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.096	.1132	.1109
2	.0995	.0903	.1109
3	.0995	.1494	.1109
4	.0995	.1848	.1109
5	.096	.1848	.1478
6	.1067	.2241	.1698
7	.125	.2241	.1886
8	.1372	.2241	.1867
9	.1372	.9804	1.4575
10	.1372	1.1544	1.5043
11	.1562	.1981	1.4074
12	.2006	1.0936	1.4403
13	.0625		1.3765
14	.0633		1.1843
15			1.2163
17			.1267
18	.0377	.1715	.1463
19	.4744	.1715	.1097
20	.168	.1848	.1463
21	.1494	.1848	.1463
22	.1494	.1448	.1463
23	.1509	.1307	.1086
24	.0983	.1494	.1307
Max	.4744	1.1544	1.5043
Min	.0377	.0903	.1086
Avg	.1355	.3136	.5123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 206 / 11 KV Kharsinge AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1619	.0747	.0377
2	.1638	.0747	.0377
3	.1638	.0754	.0377
4	.1638	.0754	.0377
5	.1638	.0754	.0377
6	.192	.0732	.0566
7	.2401	.0732	.0943
8	.2561	.0914	.0934
9	.3637	.2824	.2881
10	.3749	.3269	.3201
11	.3749	.4062	.3201
12	.4111	.381	.3041
13	.3681	.333	.3239
14	.3637	.4161	.3277
15	.3269	.4161	.3239
16	.2968	.3521	.3277
17	.0747		.0537
18	.0754		.0543
19	.0747	.0857	.0549
20	.112	.0943	.0732
21	.112	.0943	.0732
22	.0747	.0747	.0732
23	.0747	.0566	.0549
24	.176	.0754	.0566
Max	.4111	.4161	.3277
Min	.0747	.0566	.0377
Avg	.2150	.1822	.1443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 202 / 11 KV SHENAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4755	.5359
2	.4163	.4344	.499
3	.4344	.439	.499
4	.4706	.4755	.5175
5	.5121	.543	.5729
6	.823	.7964	.7865
7	.6878	.6878	.695
8	.4706	.5068	.5249
9	.8718	1.1736	1.3395
10	.8383	1.2597	1.0395
11	.9156	1.2944	1.073
12	.8817	1.1271	1.0395
13	.8951		.9326
14	.6516	.7377	.8886
15	.6706	.7377	.8383
16	.3772	.6796	.8718
17	.3982	.2378	.2534
18	.4755	.2587	.362
19	.5792	.7392	
20	.8413	.9425	.7783
21	.7682	.8413	.7059
22	.6516	.7207	.5611
23	.5121	.6099	.4572
24	.4706	.4938	.5729
Max	.9156	1.2944	1.3395
Min	.3772	.2378	.2534
Avg	.6277	.7049	.7106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 203 / 11 KV VAR-MALAWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0924	.1109
2	.0754	.0924	.1109
3	.0747	.0934	.0924
4	.0934	.1109	.1109
5	.1109	.1097	.1109
6	.1494	.1448	.1294
7	.112	.128	.1294
8	.1109	.1097	.0924
9	.0914	.1109	.0924
10	.1086	.1109	.0739
11	.0732	.0739	.0914
12	.0732	.0924	.0914
13	.0914	.0739	.0914
14	.0905	.0739	.1109
15	.1097	.0739	.1097
16	.1086	.0924	.0914
17	.1097	.0924	.1097
18	.1109	.0924	.1109
19	.1478	.1478	.1294
20	.1848	.1848	.1663
21	.1848	.1663	.1478
22	.1494	.1478	.112
23	.1109	.1109	.0934
24	.1132	.112	.1109
Max	.1848	.1848	.1663
Min	.0732	.0739	.0739
Avg	.1116	.1099	.1092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 204 / 11 KV SHENAWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0747	.0924
2	.0754	.0739	.0924
3	.0747	.0739	.0739
4	.0747	.0747	.0895
5	.0934	.0739	.0924
6	.168	.1646	.1829
7	.1867	.1646	.1829
8	.1494	.128	.1848
9	.1086	.1097	.128
10	.1097	.1109	.0924
11	.1097	.0924	.0914
12	.128	.0732	.0914
13	.1463	.0732	.1097
14	.1097	.0739	.1097
15	.0905	.0739	.0914
16	.1097	.0924	.0914
17	.1097	.0914	.1097
18	.1097	.0924	.1097
19	.1294	.1294	
20	.1478	.2012	.2218
21	.1294	.1663	.1663
22	.1109	.1478	.1307
23	.0747	.1109	.112
24	.0754	.0747	.0924
Max	.1867	.2012	.2218
Min	.0747	.0732	.0739
Avg	.1124	.1059	.1191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 205 / 11 KV Jambhulni Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7461	.8817	.7287
2	.7373	.8718	.7293
3	.7545	.8383	.7127
4	.8383	.8139	.7545
5	.8718	.8139	.779
6	1.3916	1.2071	1.3272
7	1.5257	1.7772	1.5402
8	1.2239	1.4419	1.2407
9	.1629	.1829	.1991
10	.2195	.2195	.2172
11	.2534	.2561	.2534
12	.2561	.2743	.2534
13	.2896	.1646	.2561
14	.2172	.2378	.2534
15	.2561	.2926	.2715
16	.2561	.2743	.2715
17	.2534	.2743	.2534
18	.2896	.2957	.2896
19	.3292	.1829	.3258
20	.4344	.4435	.3982
21	.3982	.4024	.3696
22	.3658	.3475	.2896
23	.8478	.6539	.6706
24	.78	.9156	.7377
Max	1.5257	1.7772	1.5402
Min	.1629	.1646	.1991
Avg	.5708	.5860	.5468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 201 / 11 KV DEVAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4115	1.7147	1.5432
2	.4115	1.5775	1.5432
3	.4115	1.5775	1.5432
4	.4115	1.6118	1.5432
5	.4287	1.6975	2.2291
6	.5658	2.5377	2.6749
7	.4801	3.2236	2.3663
8	.4287	2.7778	2.1434
9	.3429	.2743	.3258
10	.298	.2743	.3258
11	.3772	.2743	.2401
12	.3856	.3429	.2572
13	.3429	.463	.2743
14		.4287	.2743
15	.3155	.3944	.2572
16	.3772	.2743	
17	.3772	.0343	.2629
18	.3086	.0343	.2743
19	.3772	.4801	.3772
20	.463	.5487	.463
21	.4115	.4801	.4115
22	.3601	.4801	.3601
23	1.5432	1.4575	1.5432
24	.3944	1.7833	1.5261
Max	1.5432	3.2236	2.6749
Min	.298	.0343	.2401
Avg	.4445	1.0309	.9895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 202 / 11 KV DHULDEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8916	.4207	.4115
2	.8573	.3856	.4115
3	.823	.3856	.4115
4	.823	.3582	.4115
5	1.0288	.3582	.4287
6	1.0974	.4681	.4458
7	1.406	.4801	.4287
8	1.6118	.4733	.5487
9	1.5432	1.5089	1.6461
10	1.6289	1.6118	1.7833
11	1.3717	1.6289	1.7147
12	1.406	1.4575	1.5432
13	1.3717	1.2003	1.4746
14		1.2003	1.3717
15	1.3375	1.2346	1.3032
16	1.5775	1.4746	
17	.3086	.2058	.2743
18	.3258	.2229	.3429
19	.3944		.3601
20	.463	.3258	.4458
21	.4115	.3772	.4458
22	.4115	.3772	.4287
23	.4115	.4115	.4207
24	.8573	.4115	.4115
Max	1.6289	1.6289	1.7833
Min	.3086	.2058	.2743
Avg	.9721	.7382	.7593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 203 / 11 kv Devapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1307	.1029
2	.1029	.112	.1029
3	.1029	.112	.1029
4	.0857	.112	.1029
5	.12	.1494	.1372
6	.12	.1829	.1543
7	.12	.1463	.1715
8	.1715	.1791	.1372
9	.1543	.1463	.12
10	.1402	.1372	.1075
11	.1254	.1372	.1075
12	.1227	.12	.0886
13	.1214	.1029	.0876
14			.0895
15	.0876		.1433
16	.0876		
17	.1227	.0857	.1052
18	.1075	.0857	.1433
19	.2103	.0857	.1433
20	.2149	.1715	.1433
21	.1646	.2058	.1829
22	.1494	.1715	.1848
23	.1494	.1372	.168
24	.1029	.1307	.1029
Max	.2149	.2058	.1848
Min	.0857	.0857	.0876
Avg	.1299	.1353	.1274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 204 / 11 kv Dhuldeo Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1543	.0934	.1029
2	.1543	.0934	.1029
3	.1543	.0934	.1029
4	.1543	.0934	.1029
5	.1715	.1294	.12
6	.1886	.168	.1372
7	.1543	.1254	.0857
8	.1543	.1052	.12
9	.12	.1829	.0857
10	.1227	.1715	.1612
11	.1063	.1543	.1227
12	.1075	.1372	.1254
13		.12	.1433
14		.12	.0895
15	.1254	.1372	.1052
16	.1075	.0686	
17	.1075	.1029	.1075
18	.1052	.1029	.1075
19	.1075	.1543	.1612
20	.1646	.1715	.2149
21	.1829	.1715	.2195
22	.1663	.1715	.1829
23	.1494	.1715	.168
24	.1543	.0934	.1543
Max	.1886	.1829	.2195
Min	.1052	.0686	.0857
Avg	.1415	.1305	.1314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 205 / 11 KV Mhaswad (U) Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9709	.8745
2	.9088	.9335	.8745
3	.8916	.9335	.8745
4	.8916	.9149	.9259
5	.9431	.9979	1.0288
6	1.1831	1.1458	1.0974
7	1.1488	1.086	1.0288
8	1.0117	.9671	.9431
9	.9431	1.0387	.8916
10	.9465	.9602	.964
11	1.0166	.9774	.9991
12	1.0867	.9602	.9991
13	1.1269	.9602	1.0166
14		.9602	1.0387
15	1.0749	.9774	1.0208
16	1.1104	.8916	
17	1.0867	.8916	1.0166
18	1.0745	.8916	.1075
19	1.1706	1.046	1.2178
20	1.4118	1.3032	1.3969
21	1.267	1.2346	1.3032
22	1.2696	1.0288	1.1827
23	1.1203	1.0288	1.0642
24	.9259	1.0082	.8745
Max	1.4118	1.3032	1.3969
Min	.8916	.8916	.1075
Avg	1.0668	1.0045	.9887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 201 / 11 KV KUKUDWAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.0549		
4	.0549		
6	.0934		
8	.1086		.6097
16		.0701	
20		.0905	
24	.0732	.3241	.2317
Max	.1086	.3241	.6097
Min	.0549	.0701	.2317
Avg	.077	.1616	.4207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 202 / 11 kv Kukudwad gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.1848		
4	.1848		
6	.4066		
8	.2658		.2507
16		.12	
20		.3582	
24	.2012	.1829	.1463
Max	.4066	.3582	.2507
Min	.1848	.12	.1463
Avg	.2486	.2204	.1985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 203 / 11 kv Diwad gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.1307		
4	.132		
6	.2452		
8	.1307		.1509
16		.0943	
20		.2263	
24	.1307	.1132	.1294
Max	.2452	.2263	.1509
Min	.1307	.0943	.1294
Avg	.1539	.1446	.1402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 204 / 11 KV DIWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
8			.2172
16		.3567	
20		.2865	
24	.4012	.2033	.1848
Max	.4012	.3567	.2172
Min	.4012	.2033	.1848
Avg	.4012	.2822	.201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 205 / 11 kv Naravane Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
8			.7907
20		.1928	
24	.104	.4372	.3749
Max	.104	.4372	.7907
Min	.104	.1928	.3749
Avg	.104	.315	.5828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 206 / 11 KV NARAWANE GAVTHAN

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
8			.0848
20		.1417	
24	.0554	.0732	.0554
Max	.0554	.1417	.0848
Min	.0554	.0732	.0554
Avg	.0554	.1075	.0701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 207 / 11 KV KRUSHNA FERTILIZERS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.0093		
4	.0093		
6	.0151		
8	.0061		.0069
16		.0532	
20		.0018	
24	.0093	.0022	.0018
Max	.0151	.0532	.0069
Min	.0061	.0018	.0018
Avg	.0098	.0191	.0044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 301 / 22 KV SHINGANAPUR AG
(SHINGNA Feeder KV- 22 /
OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1886	.5243	.4024
2	.1886	.3841	.407
3	.1829	.4481	.4801
4	.2218	.5182	.5426
5	.2987	.6554	.6706
6	.415	.8288	
7	.3772	1.1934	1.1142
8	.2987	.9922	1.0364
9	.1867	.1829	.2218
10	.1463	.1478	.1463
11	.1886	.2263	.1478
12	.1478	.2241	.1478
13	.1886	.1509	.1417
14	.1886		.1417
15	.1494	.1417	.1433
16	.1886	.1372	.1494
17	.2286	.1433	.1494
18	.2667	.2241	.1905
19	.3048	.2241	.2667
20	.4191	.3772	.3018
21	.3429	.3018	.3018
22	.2667	.2957	.2641
23	.5967	.5365	.4748
24	.1867	.6706	.4694
Max	.5967	1.1934	1.1142
Min	.1463	.1372	.1417
Avg	.2570	.4143	.3614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 302 / 22 KV MARDI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3277	.1463	.1433
2	.3391	.1448	.1478
3	.2652	.1478	.1494
4	.3201	.1494	.2263
5	.4588	.2263	.3018
6	.6783	.3048	.3772
7	.7274	.3048	.3772
8	.7011	.2286	.2263
9	.4321	.9488	.6478
10	.506	.823	.7529
11	.4458	.3704	.6371
12	.4938	.4512	.5213
13			.5075
14			.4001
15		.3658	.4988
16	.2743	.5418	.2469
17	.1524	.2263	.1509
18	.1524	.2263	.1509
19	.1524	.2263	.2667
20	.1524	.3018	.3018
21	.1524	.2241	.2263
22	.1509	.2241	.1886
23	.1433	.1433	.1509
24	.253	.1478	.1433
Max	.7274	.9488	.7529
Min	.1433	.1433	.1433
Avg	.3466	.3124	.3225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 303 / 22 KV SHINGANAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0537	.0543
2	.0543	.0537	.0543
3	.0543	.0537	.0543
4	.0543	.0537	.0543
5	.0724	.0537	.0724
6	.0724	.0716	.0905
7	.0905	.0724	.0724
8	.0724	.0724	.0905
9	.0543	.0724	.0724
10	.0724	.0724	.0724
11	.0724	.0724	.0724
12	.0724	.0724	.0543
13	.0905	.0543	.0724
14			.0724
15	.0905	.0543	.0724
16	.0724	.0724	.0905
17	.0724	.0724	.0905
18	.0724	.0724	.0724
19	.0905	.0724	.0905
20	.1086	.0905	.0905
21	.0895	.0724	.0905
22	.0724	.0543	.0543
23	.0537	.0543	.0543
24	.0543	.0543	.0543
Max	.1086	.0905	.0905
Min	.0537	.0537	.0543
Avg	.0723	.0652	.0716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 304 / 22 KV MARDI GAONTHAN
Feeder KV- 22 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048
2	.3048	.3048	.3048
3	.3048	.381	.3048
4	.381	.5335	.381
5	.5716	.6097	.5335
6	.724	.7621	.6859
7	.6478	.6478	.5335
8	.5335	.5716	.4191
9	.4572	.4572	.381
10	.381	.381	.3429
11	.381	.3048	.3429
12	.2667	.2667	.3048
13	.2667	.3048	.3429
14	.2286		.3429
15	.3429	.2667	.3429
16	.3429	.3048	
17	.381	.3429	.2667
18	.381	.4191	.3048
19	.6097	.6097	.6097
20	.7621	.6859	.724
21	.6097	.5335	.6097
22	.4572	.4191	.4954
23	.381	.3429	.381
24	.3048	.381	.3048
Max	.7621	.7621	.724
Min	.2286	.2667	.2667
Avg	.4302	.4407	.4158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 301 / 22 KV PARKANDI AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2286	.6036	.6859
2	.2286	.5487	.7545
3	.2667	.5487	.823
4	.3018	.6036	1.2071
5	.3772	.7042	.9175
6	.4298	1.3435	.9602
7	.5121	1.1603	1.4419
8	.3734	1.278	1.4754
9	.3018	.2614	.2263
10	.2263	.1848	.2149
11	.1886	.2241	.2263
12	.1886	.1402	.2263
13	.1886	.2149	.2263
14	.1886	.1829	.2263
15	.2263	.1867	
16	.1886	.1753	.2263
17	.2263	.1905	.2263
18	.2241	.2286	.2263
19	.2987	.381	.3018
20	.4904	.4572	.4527
21	.4527	.381	.4527
22	.3772	.3048	.3772
23	.7625	.7377	.8619
24	.2667	.6706	.6516
Max	.7625	1.3435	1.4754
Min	.1886	.1402	.2149
Avg	.3131	.4880	.5821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 302 / 22 KV BHANDAWALI AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4115	.1886	.1905
2	.4115	.1886	.1905
3	.4694	.1886	.2286
4	.503	.1886	.3048
5	.57	.1886	.3772
6	.7865	.3772	.4298
7	1.0242	.3772	.3658
8	.9175	.2987	.2926
9	.9389	1.0486	1.0059
10	.8951	.9831	1.0242
11	.7293	.8718	.8124
12	.7625	.7209	.7926
13	.7537	.8718	.7407
14	.7293	.7461	.8749
15	.8421	.8916	.8322
16	.9282	.9175	.6554
17	.1886	.2286	.2263
18	.2241	.2667	.2263
19	.2241	.4191	.3018
20	.3772	.4572	.3772
21	.3361	.381	.3018
22	.2614	.2286	.1509
23	.1886	.2263	.2263
24	.4527	.1886	.1886
Max	1.0242	1.0486	1.0242
Min	.1886	.1886	.1509
Avg	.5802	.4768	.4632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 303 / 22 KV MALAWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1494	.1524
2	.1143	.1494	.1524
3	.1143	.1109	.1524
4	.112	.1494	.1524
5	.1478	.1886	.1886
6	.1829	.2263	.1867
7	.1829	.1494	.1463
8	.1867	.1109	.112
9	.1509	.1494	.1463
10	.1494	.1494	.1372
11	.1886	.1848	.1448
12	.1494	.1829	.1463
13	.1886	.1791	.1478
14	.1886	.1463	.1848
15	.1109	.1494	
16	.1494	.1791	.1109
17	.1886	.1905	.1463
18	.1494	.1905	.1478
19	.2263	.2286	.2561
20	.3395	.2667	.2218
21	.2641	.1905	.1829
22	.2641	.2286	.1848
23	.2263	.1886	.2195
24	.1524	.1886	.1524
Max	.3395	.2667	.2561
Min	.1109	.1109	.1109
Avg	.1783	.1761	.1640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 304 / 22 KV KULAKJAI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0754	.0762
2	.0762	.0754	.0762
3	.0762	.0739	.0762
4	.0754	.1109	.1143
5	.112	.1494	.1524
6	.1478	.2263	.2263
7	.1848	.1494	.1463
8	.1494	.1494	.1463
9	.1132	.1109	.0739
10	.112	.0747	.0358
11	.112	.0377	.0732
12	.0739	.037	.0739
13	.1109	.0373	.0732
14	.0739	.037	.112
15	.112	.0373	.1109
16	.0747	.0373	.112
17	.1109	.0373	.112
18	.1109	.0358	.112
19	.1494		.1109
20	.2641	.2667	.2195
21	.2263	.2286	.1867
22	.1494	.1524	.1478
23	.1494	.0754	.1097
24	.4572	.1109	.0762
Max	.4572	.2667	.2263
Min	.0739	.0358	.0358
Avg	.1374	.1011	.1147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 306 / 22 KV TONDALE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2286	.4207	.4115
2	.2286	.394	.4801
3	.2286	.4207	.5487
4	.2641	.4458	.6036
5	.2987	.5144	.6882
6	.4108	1.1271	.7537
7	.5601	1.2631	1.0883
8	.3734	1.2266	.9175
9	.2641	.2614	.2926
10	.2263	.1867	.2195
11	.1886	.1848	.2218
12	.1886	.1829	.0732
13	.2263	.1829	.2957
14	.1886	.2241	.1463
15	.0377	.2641	.2195
16	.0377	.2149	.2218
17	.2614	.2667	.2561
18	.2614	.3429	.2957
19	.3772	.4191	.3658
20	.5281	.5335	.5175
21	.4904	.4191	.439
22	.3772	.3429	.3696
23	.4801	.4458	.4755
24	.2667	.4115	.3772
Max	.5601	1.2631	1.0883
Min	.0377	.1829	.0732
Avg	.2914	.4457	.4283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 201 / 11 KV PALASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3401	.3605
2	.2641	.3239	.3353
3	.2641		.3353
4	.3018	.3563	.3688
5	.4904		.4915
6	.6219	.7935	.8383
7	.6036	1.1822	1.1469
8		1.0526	.9393
9		.3224	.3772
10		.2534	.2641
11			.1646
12			.2012
13			.1463
14			.1463
15			.1646
16			.2195
17			.2378
18			.2926
19			.4024
24	.3018	.4049	.3605
Max	.6219	1.1822	1.1469
Min	.2641	.2534	.1463
Avg	.3937	.5588	.3897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 202 / 11 KV DHAMANI Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4801		.3395
2	.4854		.3018
3	.4557		.3018
4	.439	.3045	
5	.5548		
6	.8413		
7	.8916		
8		.4119	
9			.8383
11			.9724
13			.9012
14			.9012
15			.5898
16			.7712
17			.2686
18			.3224
19			.4477
24	.4854	.2865	.3395
Max	.8916	.4119	.9724
Min	.439	.2865	.2686
Avg	.5792	.3343	.5612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 203 / 11 KV GONDAWALE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
1	.3045	
4	.3045	.3395
8	.4656	.5093
12		.3224
16		.3403
20		.6036
24	.3224	.3395
Max	.4656	.6036
Min	.3045	.3224
Avg	.3493	.4091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 204 / 11 kv Mhaswad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1509		.3605
2	.1509		.3647
3	.1509		.3647
4	.1509	.2622	.4024
5	.1509		.4641
6	.1509		.5898
7	.1509		.7377
8		.7373	.3932
9		.0914	.0754
10			.0754
13			.0747
16			.0747
19			.1463
24	.1494	.2949	.3688
Max	.1509	.7373	.7377
Min	.1494	.0914	.0747
Avg	.1507	.3465	.3209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 205 / 11 KV Gondawale Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)
4	.1791	.1886
8	.197	.2263
9		.6882
12		.7701
16		.6882
17		.1829
20		.3292
23		.1829
24	.1791	.1886
Max	.197	.7701
Min	.1791	.1829
Avg	.1851	.3828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 201 / 11 KV PINGALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2353	.1715	.1715
2	.2353	.1543	.1715
3	.2172	.1543	.1715
4	.2172	.1543	.1715
5	.2172	.1715	.2058
6	.3721	.3086	.3258
7	.3721	.3429	.3429
8	.2835	.2572	.2401
9	.2481	.2401	.2058
10	.2058	.1715	.2126
11	.2058	.1715	.2126
12	.2058	.1715	.1949
13	.2058	.1715	.1772
14	.2058	.1543	.2126
15	.1715	.1543	.1772
16	.1715	.1543	.2126
17	.1715	.2058	.1949
18	.2058	.2401	.2126
19	.2401	.2743	.3012
20	.3429	.3429	.3721
21	.3258	.3429	.3544
22	.3258	.2572	.2835
23	.2572	.2058	.2126
24	.2534	.2058	.2058
Max	.3721	.3429	.3721
Min	.1715	.1543	.1715
Avg	.2455	.2158	.2310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 202 / 11 KV KIRAKSAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4725	.1219	.1067
2	.4725	.1219	.1067
3	.442	.1219	.1067
4	.442	.1219	.1067
5	.4725	.1372	.1524
6	.5944	.1372	.1524
7	.7316	.1372	.1067
8	.7621	.1134	.1067
9	.7621	.9242	.6316
10	.8259	1.0374	.7316
11	.8097	1.0185	.7621
12	.6154	.6478	.6706
13	.583	.6478	.7316
14	.583	.6478	.7468
15	.6478	.6478	.7468
16	.6964	.6478	.7621
17	.0914	.0914	.0914
18	.0914	.0914	.0914
19	.1219	.1219	.1067
20	.1372	.1524	.1524
21	.1372	.1524	.1423
22	.1372	.1219	.1423
23	.1219	.1067	.0949
24	.4725	.1219	.1067
Max	.8259	1.0374	.7621
Min	.0914	.0914	.0914
Avg	.4677	.3413	.3190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 401 / 33 KV MANDESHI SOOT GIRNI
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9619	.9054	.9054
2	.9619	.9054	.9054
3	.9054	.9054	.9054
4	.9054	.9054	.9054
5	1.0751	.9054	.9619
6	1.0185	.9054	.9619
7	1.0185	.8488	.9619
8	.9619	.9054	.9054
9	.9619	.9619	.9619
10	.9619	.8488	.9619
11	.9619	.9619	.9619
12	.679	.7922	.9619
13	.9619	.8488	.9054
14	.9619	.9054	.8488
15	.9619	.9054	.9054
16	.9054	.9619	.9054
17	.9619	.9619	.9054
18	.9054	.9054	.8488
19	.9054	.9054	.8488
20	.9054	.9619	.7922
21	.9054	.9619	.9054
22	.9054	.7922	.8488
23	.9054	.9619	.9619
24	.9619	.9054	.9054
Max	1.0751	.9619	.9619
Min	.679	.7922	.7922
Avg	.9384	.9054	.9101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 201 / 11 KV LALGUN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0358	.0373
2	.0377	.0366	.0366
3	.0373	.0351	.037
4	.0366	.0343	.0366
5	.037	.0335	.0366
6	.037	.0343	.037
7	.0377	.0351	.037
8	.0377	.0343	.0373
9	1.1336	.8356	1.0437
10	1.2803	1.2574	1.0595
11	1.3923	1.1271	.9722
12	1.1401	1.012	.8025
13	1.0978	.9488	.7164
14	.8886	.7712	.8535
15	.9602	.933	.7526
16	.9667	1.0111	.9842
17	.0335	.0358	.0732
18	.0343	.037	.0724
19	.0351	.037	.0747
20	.0358	.0373	.1132
21	.0351	.037	.0754
22	.0358	.0366	.0754
23	.0343	.0373	.0754
24	.0366	.0351	.0377
Max	1.3923	1.2574	1.0595
Min	.0335	.0335	.0366
Avg	.3933	.3528	.3366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 202 / 11 KV MANJARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3841	.4066
2	.3881	.3506	.4024
3	.3881	.3429	.3326
4	.3921	.3353	.3772
5	.4294	.4115	.3841
6	.5041	.4908	.4251
7	.462	.4477	.4805
8	.4108	.4031	.3881
9	.3658	.2229	.3366
10	.3109	.3681	.3688
11	.3982	.3641	.373
12	.4024	.3429	.3403
13	.4031	.3315	.394
14	.4119	.3326	.3681
15	.4024	.3326	.3506
16	.394	.3921	.3506
17	.439	.3439	.3475
18	.4481	.3511	.3185
19	.4755	.4298	.4557
20	.6805	.6283	.6767
21	.7499	.6283	.6767
22	.5788	.5121	.6036
23	.4755	.4435	.4207
24	.4108	.4119	.3547
Max	.7499	.6283	.6767
Min	.3109	.2229	.3185
Avg	.4455	.4001	.4139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 303 / Budh Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2149	.2534
2	.2241	.2103	.2507
3	.2218	.2058	.2587
4	.2614	.2103	.2614
5	.2987	.2865	.2561
6	.4805	.3658	.2957
7	.4435	.3734	.3326
8	.4024	.3658	.3658
9	.3734	.2987	.3326
10	.2926	.3018	
11	.2835	.2587	.3189
12	.2865		.3224
13		.2241	.2865
14	.2743	.2218	.2804
15	.2804	.2218	.2534
16	.2865	.2218	.2534
17	.2926	.2774	.2865
18		.2957	.2481
19	.4298	.3696	.362
20	.4908	.4481	.4805
21	.4298	.4435	.4108
22	.3658	.3326	.3734
23	.2865	.2987	.3018
24	.2587	.2195	.2561
Max	.4908	.4481	.4805
Min	.2218	.2058	.2481
Avg	.3283	.2899	.3061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 305 / 22 KV KATEWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0663	.0671	.0732
2	.0747	.0686	.0747
3	.0739	.0701	.0732
4	.0739	.0716	.0747
5	.0747	.0701	.0747
6	.0754	.0686	.0747
7	.0732	.0671	.0747
8	.0747	.0686	.0747
9	.6802	.7865	.7907
10	.7625	1.0059	.8436
11	.7773	.9389	.7907
12	.7537	.9488	.9282
13		.9054	.9488
14	.8048	.7956	1.012
15	1.9204	.6882	.9488
16	.8718	.8619	.9172
17	.0686	.0724	.061
18	.0701	.0732	.0686
19	.0716	.0724	.0716
20	.0701	.0732	.0732
21	.0686	.0739	.0724
22	.0701	.0739	.0724
23	.0671	.0739	.0686
24	.0655	.0655	.0709
Max	1.9204	1.0059	1.012
Min	.0655	.0655	.061
Avg	.3352	.3359	.3472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 201 / 11 KV Pusegaon gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8402	.7468	.6535
2	.8215	.7468	.6535
3	.8029	.7095	.6535
4	.8029	.7095	.6535
5	.8402	.7095	.6722
6	.9335	.8589	.8215
7	.9896	.9149	.7842
8	.9335	.9709	.8029
9	.9522	.7282	.8029
10	.9149	.7282	.8029
11		.6908	
12			.7842
13	1.0082		.8215
14	.9896	.0934	.8962
15	.7468	.5228	.8775
16	.9335	.5975	.8962
17		.9522	.9149
18		.8775	.9522
19	.6722	.9522	.9522
20	1.2696	1.0082	1.1016
21	1.1576	.8775	1.0642
22	1.0642	.8775	1.0642
23	.9335	.6722	.8215
24	.8775	.8962	.6535
Max	1.2696	1.0082	1.1016
Min	.6722	.0934	.6535
Avg	.9242	.7655	.8305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 202 / 11 KV PUSEGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3311	.2107
2		.2709	.2107
3	.286	.2709	.2107
4	.301	.2709	.2107
5	.3161	.2709	.2258
6	.3462	.3913	.2408
7	.5719	.6923	.3913
8	.6321	.602	.4214
9	.0151	.0151	.0151
10	.0151	.0151	.0151
11		.0151	
12		.0151	.0151
13	.3763	.0151	.0151
14	.0151	.0151	.0151
15	.0151	.0151	.0151
16	.0151	.0151	.0151
17	.0151	.0151	.0151
18	.0151	.0301	.0151
19	.0301	.0452	.0301
20	.0301	.0452	.0301
21	.0151	.0452	.029
22	.0151	.0301	.0301
23	.3763	.1957	.2709
24		.3612	.2107
Max	.6321	.6923	.4214
Min	.0151	.0151	.0151
Avg	.1791	.1662	.1243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 203 / 11 KV VARDHANGAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0166	.0166	.0166
2	.0166	.0166	.0166
3	.0166	.0166	.0166
4	.0166	.0166	.0166
5	.0166	.0166	.0166
6	.0166	.0166	.0166
7	.0166	.0166	.0166
8	.0166	.0166	.0166
9		.6133	.663
10		.9945	.779
11		.8288	.779
12	1.0442	.8288	.8122
13	.8619	.5801	.7459
14	.9282	.6299	.7127
15	.8951	.7459	.7293
16	.779	.7127	.7459
17		.0166	.0166
18	.0166	.0166	.0166
19	.0332	.0332	.0332
20	.0332	.0497	.0497
21	.0166	.0497	.0332
22	.0166	.0332	.0332
23	.0166	.0166	.0166
24	.0166	.0166	.0166
Max	1.0442	.9945	.8122
Min	.0166	.0166	.0166
Avg	.2395	.2625	.2631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 301 / 22 KV Nidhal GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754
2	.0754	.0754	.0754
3	.0754	.0754	.0754
4	.0754	.0754	.0754
5	.0754	.1132	.1132
6	.1509	.1509	.1509
7	.0377	.1509	.0754
8	.1132	.1132	.1509
9		.0377	.1132
10		.0754	.1132
11	.0754		.1132
12	.0754	.0754	.0754
13	.1132	.0754	.0754
14	.0754	.0754	
15		.0754	.1132
16	.1132	.0754	.1132
17	.0377	.1029	
18	.0754	.1132	.1132
19	.1132	.1509	.1132
20		.1509	.1509
21		.1132	.1132
22	.1132	.1132	.1132
23	.0754	.0754	.0754
24	.0754	.0754	.0754
Max	.1509	.1509	.1509
Min	.0377	.0377	.0754
Avg	.0854	.0963	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 302 / 22 KV DARUJ AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.2071	.9503
2	1.0608	1.0059	.9503
3	1.0608	1.0059	.9503
4	1.094	1.0059	.9503
5	1.1603	1.2742	.9831
6	1.5074	1.5729	1.1797
7	2.0645	1.9989	1.5402
8	1.9662	1.9334	1.6057
9	.3018	.3395	.2641
10	.3018	.2641	.2263
11	.3018		.2641
12		.2641	.2263
13		.2641	.2263
14	.2641	.3018	
15		.3018	.3395
16	.0377	.3018	.3395
17	.3018		
18	.3395	.3018	.2641
19	.4527	.415	.415
20	.4904		.4904
21	.4527	.4527	.4527
22	.415	.4527	.3772
23	1.2407	.9831	1.1271
24	1.094	1.2071	.9831
Max	2.0645	1.9989	1.6057
Min	.0377	.2641	.2263
Avg	.8096	.8026	.6866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun

)

Feeder No / Name : 303 / 22 KV Nidhal AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	
2	.1132	.1132	
3	.1132	.1132	
4	.1132	.1132	
5	.1132	.1132	
6	.1509	.1132	
7	.1132	.1509	
8	.1132		
9	.9724		.1132
10	1.073		.1509
11	1.073		.0754
12			.8848
13			.8848
14	.8848		
15			.852
16	.9175		.9503
17	.1132		
18	.1132	.0754	.1132
19	.1132	.0754	.1509
20	.1132		.1509
21	.1509	.0377	.1509
22	.1132	.0377	.1132
23	.1132		.1132
24	.1132	.1132	
Max	1.073	.1509	.9503
Min	.1132	.0377	.0754
Avg	.3242	.0975	.3618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 201 / GOPUJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.1311
8			.1267
9	.3239	.1715	
10	.381	.2096	
11		.2477	
12		.2477	
13		.2286	
14		.2286	
15		.2286	
16		.1715	
21		.1524	
24			.1638
Max	.381	.2477	.1638
Min	.3239	.1524	.1267
Avg	.3525	.2096	.1405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 202 / VADUJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.1638
6			.2622
7			.3277
9	.3239	.2477	.1143
10	.2858	.2858	
11	.2858	.2667	.3277
12	.2477	.2667	
13	.2667	.2286	
14	.2477	.2286	.6554
15	.2286	.1715	.6554
16	.3048	.3048	
19			.2667
21			.4191
23		.3277	.6226
24			.1966
Max	.3239	.3277	.6554
Min	.2286	.1715	.1143
Avg	.2739	.2587	.3647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 203 / WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.0492
6			.1147
7			.1147
8			.1147
9	.1147	.1147	.0492
10	.1147	.1147	.0492
11	.1147	.1147	.0492
12	.0492	.1147	.1147
13	.0492	.1147	.0492
14	.0492		.0492
15		.0492	.1147
16	.1147	.1147	
19	.1147		.1147
21		.0492	.0492
23		.1147	.0492
24			.0492
Max	.1147	.1147	.1147
Min	.0492	.0492	.0492
Avg	.0901	.1001	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 204 / VADUJ GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.9412
6			1.086
7			1.2071
8			1.1584
9	1.2308	1.1584	1.0498
10	1.1946	1.0498	1.1584
11	1.267	1.2308	1.2308
12	1.3394	1.2308	1.3394
13	1.3032	1.2308	1.2308
14	1.3032	1.086	1.1584
15	1.4842		1.1584
16	1.4118	1.0136	
19			1.267
21			1.3394
22		1.2803	
23		1.0498	1.0974
24			.9774
Max	1.4842	1.2803	1.3394
Min	1.1946	1.0136	.9412
Avg	1.3168	1.1478	1.1600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 205 / GOPUJ GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.0724
6			.1097
7			.1097
9	.1629		.181
10	.0934		.1463
11	.1663		.1663
12	.1478		.1848
13	.1448		.1448
14	.1848		.168
15	.0934		.1663
16	.1478		
19			.181
21		.1086	.1991
23		.0724	.1791
24			.0716
Max	.1848	.1086	.1991
Min	.0934	.0724	.0716
Avg	.1427	.0905	.1486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 206 / 11KV KUMTHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.1524
6			.0572
7			.1524
8			.0572
9	.6882		.8848
10	.852	1.0159	.4915
11	.6226	.9175	
12	.8356		
13	.852		
14	.6882	.7316	
15	.7865	.852	
16	.8356	.9667	
19			.2667
21			.3429
22		.1905	
23		.1524	.2286
24			.0953
Max	.852	1.0159	.8848
Min	.6226	.1524	.0572
Avg	.7701	.6895	.2729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 201 / 11 KV BANPURI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3048	3.0864	2.2291
2	.3048	3.0864	2.2634
3	.3239	3.0864	2.5149
4	.3239	3.0864	2.2634
5	.3429	3.0864	2.4348
6	.362	3.3436	2.572
7	.381	3.2579	2.8464
8	.381	3.2579	2.8635
9	.3048	.2477	.2667
10	.3048	.2286	.2477
11	.2858	.2667	.2858
12	.3048	.2667	.2096
13	.3239	.2477	.2858
14	.3239	.2286	.3048
15	.2286	.2477	.362
16	.2477	.2477	.2858
17	.381	.3239	.2858
18	.381	.2286	.3239
19	.381	.2477	.2667
20	.381	.2477	.3048
21	.381	.2477	.2477
22	.3048	.2286	.2858
23	2.9492	2.1434	2.3148
24	.2667	3.0864	2.2291
Max	2.9492	3.3436	2.8635
Min	.2286	.2286	.2096
Avg	.4364	1.4178	1.1873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 202 / 11 KV BARAGAON Water
Supply Feeder KV- 11 /
OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAY-17
HR	Load (MW)
23	.2096
Max	.2096
Min	.2096
Avg	.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 203 / 11 KV Palasgaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4214	.1905	.1524
2	.4214	.1905	.1524
3	.4268	.1905	.1524
4	.4572	.1905	.1715
5	.5335	.2286	.2286
6	.5944	.4001	.362
7	.6706	.4763	.4763
8	.6327	.4191	.4001
9	.5647	.5658	.583
10	.5335	.6001	.5658
11		.5316	.5487
12	.4687	.4973	.4854
13	.427	.3601	.463
14	.3841	.4001	.4681
15	.4049	.3258	.4801
16	.4475	.3772	.2572
17	.1334	.1524	.1524
18	.2096	.2477	.1715
19	.362	.3239	.1715
20	.4191	.4001	.4382
21	.362	.3048	.3429
22	.2667	.2477	.2477
23	.1905	.1715	.2096
24	.3864	.1905	.1524
Max	.6706	.6001	.583
Min	.1334	.1524	.1524
Avg	.4225	.3326	.3264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 301 / PIMPRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1905	.1905
2	.2241	.1524	.1905
3	.2241	.1524	.1905
4	.2241	.1524	.1905
5	.2241	.1524	.2286
6	.2241	.1524	.3696
7	.2241	.2286	.3429
8	.1848	.2667	.2667
9	.1448	.2667	.1905
10	.1772	.2286	.1905
11	.2103	.1905	.2149
12	.2126	.2286	.2172
13	.2103	.2286	.2172
14	.2126	.1905	.2149
15	.2804	.1905	.1478
16	.2804	.1905	.1524
17	.1772	.1905	.1524
18	.2667	.1905	.2286
19	.3048	.1905	.2667
20	.3048	.2667	.3048
21	.3048	.2667	.2667
22	.2286	.2286	.2286
23		.2286	.1905
24	.2241	.1905	.2286
Max	.3048	.2667	.3696
Min	.1448	.1524	.1478
Avg	.2301	.2048	.2243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 302 / ENKUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1524	.1143
2	.1509	.1524	.1143
3		.1524	.1143
4	.1509	.1143	.1143
5	.1509	.1524	.1524
6		.1524	.1905
7	.1509	.1905	.1905
8		.1905	.1905
9	.2195	.1524	.1524
10		.1143	.1524
11		.1143	
12		.1524	.1387
13		.1524	.1417
14		.1524	.1463
15		.1524	.1715
16		.1524	.1143
17	.1463	.1524	.1143
18	.1905	.1524	.1143
19	.2286	.1524	.1905
20	.2667	.1524	.2286
21	.2286	.1905	.1905
22		.1524	.1524
23	.1905	.1524	.1524
24	.1509	.1524	.1143
Max	.2667	.1905	.2286
Min	.1463	.1143	.1143
Avg	.1828	.1524	.1502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 303 / MANDVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1143	.1143
2		.1143	.1143
3		.1143	.1143
4		.1143	.1143
5		.1143	.1143
6		.1524	.1143
7		.1524	.1143
8		.1524	.1143
9		.1524	.1143
10		.1143	.1143
11		.1143	
12		.1143	
13		.1143	
14		.1143	
15		.1143	
16		.1143	.1143
17		.1143	.1143
18	.1905	.1143	.1143
19	.1524	.1143	.1143
20	.1524	.1143	.1143
21	.1524	.1143	.1143
22		.1143	.1143
23	.1524	.1143	.1143
24		.1143	.1143
Max	.1905	.1524	.1143
Min	.1524	.1143	.1143
Avg	.1600	.1207	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 306 / PEDGOAN AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.823	.4191	.3429
2	.823	.4191	.3429
3	.9145	.4191	.3429
4	.9755	.4191	.3429
5	1.0364	.5716	.4191
6	1.0974	.6478	.5716
7	1.1584	.6859	.6478
8	1.1702	.5716	.5335
9	1.0364	1.3375	1.2346
10	.8345	1.3032	1.0974
11	.8977	.6859	1.0749
12	.8855	.7888	.9614
13	.6325	.8916	.9156
14	.5761	.8573	.8916
15	.7125	1.3375	.9496
16	.8619	.8916	1.0288
17	.3048	.2667	.3048
18	.381	.3048	.3048
19	.4954	.6859	.4572
20	.6859	.4572	.6478
21	.6478	.4572	.5716
22		.4572	.5335
23	.6097	.381	.4191
24	.7716	.4191	.3429
Max	1.1702	1.3375	1.2346
Min	.3048	.2667	.3048
Avg	.7970	.6532	.6366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 201 / AMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6642	.6964	.5571
2	.6642	.6802	.5571
3	.6405	.6722	.5571
4	.6718	.7611	.583
5	.9998	.8097	.583
6	1.1385	.9503	.6964
7	1.3283	1.4575	1.0202
8	1.2483	1.2146	1.0364
9	.1658	.1658	1.1012
10	.1823	.1823	.9922
11	.1823	.1989	.9122
12	.1989	.2652	.8642
13		.1823	.8322
14	.1989	.1658	.7748
15	.1823	.1658	.8381
16	.2321	.1492	.8855
17	.2321	.0995	.1658
18	.2155	.0995	.1989
19	.2321	.2321	.2155
20	.2155	.1989	.1802
21	.1989	.1989	.1802
22	.1989	.1658	.1802
23	.7125	.5407	.1658
24	.6958	.6964	.5571
Max	1.3283	1.4575	1.1012
Min	.1658	.0995	.1658
Avg	.4956	.4562	.6098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 204 / 11 KV MORALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0701	.0701
2		.0701	.0701
3		.0701	.0701
4		.0701	.0701
5		.0701	.0701
6		.0876	.1227
7		.1052	.1227
8		.0876	.1052
9		.0701	.0701
10	.0876	.0701	.0701
11	.0701	.0701	.0701
12		.0701	.0701
13	.0701	.0701	.0701
14	.0701	.0701	.0701
15	.0701	.0701	.0701
16	.0701	.0701	.0701
17	.0701	.0701	.0876
18	.0876	.0701	.1052
19	.1052	.1052	.1227
20	.1227	.1402	.1227
21	.1052	.1052	.1227
22	.1052	.1052	.1052
23	.0701	.0701	.0701
24		.0701	.0701
Max	.1227	.1402	.1227
Min	.0701	.0701	.0701
Avg	.0849	.0803	.0862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 207 / 11 KV Goregaon (N) AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4144	.3315	.2949
2	.4144	.2984	.2949
3		.2818	.2949
4		.2652	.2949
5		.2652	.3277
6		.2984	.3277
7		.4475	.3277
8		.3812	.3277
9		2.332	.426
10	2.915	2.2834	.3978
11	2.9312	2.4453	.3647
12	2.9635	2.4939	.3481
13	2.9312	2.3644	.3441
14	3.1903	2.2834	.3277
15	3.2065	2.2348	.3277
16		2.0081	.3277
17	.3978	.3277	.3812
18	.4144	.1802	.3812
19	.431	.3932	.3812
20	.3978	.3932	.3932
21	.4144	.3605	.3441
22	.3978	.3277	.3149
23	.3647	.3658	1.9204
24	.431	.3481	.2949
Max	3.2065	2.4939	1.9204
Min	.3647	.1802	.2949
Avg	1.3885	.9880	.4069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 302 / MHASURNE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7865	.6154	.6478
2	.7537	.6478	.6478
3	.7209	.7773	.6478
4	.7773	.8322	.7125
5	.9069	.9717	.7125
6	1.2803	1.1336	.8421
7	1.8564	1.6842	1.2308
8	1.6644	.9717	1.4899
9	.3018	.2263	1.2308
10	.2641	.3395	1.2308
11	.2263	.3395	1.2163
12	.2263	.3018	1.1523
13	.2263	.3018	1.1069
14	.2263	.3018	1.1203
15	.2641	.2641	1.0242
16	.3018	.3018	.9602
17	.2263	.3018	.2263
18	.2641	.3018	.2263
19	.2641	.3395	.3395
20	.3018	.3772	.3772
21	.2641	.3018	.3395
22	.2263	.3018	.3018
23	.7545	.583	.3018
24	.7773	.6882	.6478
Max	1.8564	1.6842	1.4899
Min	.2263	.2263	.2263
Avg	.5776	.5502	.7806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 303 / NIMSOD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.1886
2	.1886	.1886	.1886
3	.1886	.1886	.1886
4	.1886	.2641	.1886
5	.2641	.2641	.1886
6	.3772	.3395	.3018
7	.4527	.4527	.4527
8	.3395	.3018	.3018
9	1.8785	2.0687	.2641
10	1.8884	2.2138	.2641
11	1.9433	2.2771	.2263
12	2.0081	1.9608	
13	2.17	1.8027	.2263
14	2.2348	2.0241	.1886
15	2.1376	1.8976	.2263
16	2.1376	1.7284	.2263
17	.2263	.2263	.1886
18	.2641	.2263	.2641
19	.3018	.3018	.3395
20	.3395	.3395	.3772
21	.3018	.2641	.3772
22	.3018	.2641	.3395
23	.2263	.2263	1.4243
24	.2263	.2263	.2263
Max	2.2348	2.2771	1.4243
Min	.1886	.1886	.1886
Avg	.8672	.8447	.3112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 305 / SHIRASWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.0754
2	.1509	.1509	.0754
3	.1509	.1509	.0754
4	.1509	.1509	.0754
5	.1509	.1886	.0754
6	.2263	.1886	.1886
7	.3018	.2263	.1886
8	.2641	.1886	.1509
9	.2263	.2263	.0754
10	.1886	.2263	.1132
11	.2263	.2263	.1132
12	.2263	.2263	.1132
13	.0754	.1509	.0754
14	.0754	.1509	.0754
15	.0754	.1886	.1132
16		.1509	.1132
17	.0754	.1509	.1509
18	.1509	.0754	.1509
19	.2263	.1509	.2263
20	.3018	.2263	.3018
21	.2641	.1509	.2641
22	.2263	.1886	.2263
23	.2263	.1509	.1509
24	.1509	.1509	.1509
Max	.3018	.2263	.3018
Min	.0754	.0754	.0754
Avg	.1853	.1745	.1383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 306 / PUNWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3018	.2641
2	.2641	.2641	.2263
3	.2641	.2641	.2263
4	.2641	.2263	.2263
5	.2641	.3018	.3018
6	.3772	.3772	.415
7	.5658	.6036	.4527
8	.4904	.3772	.3395
9	.415	.3772	.3018
10	.3772	.3395	.2641
11	.3772	.2263	.2641
12	.3772		.2641
13		.3018	.3018
14		.2641	.3018
15		.2641	.3018
16	.415	.2641	.2561
17	.415	.2263	.3018
18	.4904	.2641	.3395
19	.5281	.415	.4527
20	.6413	.4527	.5281
21	.5281	.3772	.415
22	.415	.3395	.3395
23	.3395	.2641	.3018
24	.3018	.3018	.2641
Max	.6413	.6036	.5281
Min	.2641	.2263	.2263
Avg	.4006	.3215	.3188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 301 / PACHWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0754	.0754
2	.1132	.0762	
3	.1132	.0762	
4	.112	.0754	
5	.1132	.0754	
6	.1478	.1509	
7	.1509		.1509
8	.1463	.112	.1509
9	.1097	.1132	.1132
10	.1086		.112
11	.0754	.0754	.0747
12	.0762		.0754
13	.0754		.0754
14	.0754		.0747
15	.0754		.0747
16	.0754	.0754	.0754
17	.0747	.1132	.1086
18	.1017	.1509	.1097
19	.1029	.1886	.1791
20	.1867	.1886	.1886
21	.1886		.1867
22	.1132	.1886	.1509
23	.1132	.1132	.1132
24	.1143	.0754	.1132
Max	.1886	.1886	.1886
Min	.0747	.0754	.0747
Avg	.1115	.1132	.1159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 302 / PADAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	
2	.0754	.0754	
3	.0754	.0754	
4	.0754	.0762	
5	.1132	.1132	
6	.1509	.1905	
7	.2286		.1886
8	.1524	.112	.1132
9	.1143	.0754	.1132
10	.0754		.1132
11	.0747	.0754	
12	.0754		.0754
13	.0754		.0754
14	.0747		.0739
15	.0754		.0381
16	.0754	.0754	.0754
17	.0693	.0754	.0652
18	.0754	.1132	.0739
19	.0754	.1886	.1509
20	.1494	.1886	.1886
21	.1509	.1132	.1905
22	.112	.0754	.1132
23	.0754	.0754	.0754
24	.0754	.0754	.0754
Max	.2286	.1905	.1905
Min	.0693	.0754	.0381
Avg	.0988	.1028	.1059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 303 / KALEDHON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1509	
2	.1905	.1509	
3	.1886	.1509	
4	.1848	.1494	
5	.1886	.1494	
6	.2241	.3048	
7	.2667		.2641
8	.2263	.1905	.2263
9	.1867	.1886	.1886
10	.1509		.1886
11	.1509	.0754	.1886
12	.1494		.1509
13	.1509		.1509
14	.1494		
15	.1509		.1886
16	.1509	.1132	.1494
17	.1509	.1132	.1848
18	.1494	.1886	.1886
19	.1886	.3018	.2587
20	.2587	.3018	.3018
21	.2641	.2641	.3018
22	.2263	.2263	.2263
23	.1886	.2263	.1886
24	.1886	.1509	.2263
Max	.2667	.3048	.3018
Min	.1494	.0754	.1494
Avg	.1881	.1887	.2102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 304 / STATIONERY POINT

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0381	
2	.0754	.0381	
3	.0754	.0377	
4	.0754	.0381	
5	.1886	.0381	
6	.0754	.0377	
7	.1132		.0377
8	.0377	.0377	.0377
9	.0377	.0377	.0377
10	.0377		.0754
11	.0377		.0754
12	.0754		.0754
13	.0377		.0754
14	.0377		.0754
15	.0377		.1132
16	.0377	.0377	.0754
17	.0377	.0377	.1132
18	.0377	.0377	.1132
19	.0377	.0377	.1132
20	.0377	.0377	.1132
21	.0381	.0377	.1132
22	.0381	.0377	.0754
23	.0377	.0377	.1132
24	.0754	.0377	.0377
Max	.1886	.0381	.1132
Min	.0377	.0377	.0377
Avg	.0582	.0378	.0817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 305 / GHARUDI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3018	.7164	
2	.2641	.7164	
3	.2641	.6878	
4	.2641	.7087	
5	.3395	.8859	
6	.4527	1.2971	
7	.5658		1.7718
8	.4527	1.4746	1.701
9	.415	.3772	.3395
10	.3734		.3018
11	.2641		.2641
12	.2263		.3018
13	.2614		.3018
15	.3018		.3018
16	.3018	.2641	.2263
17	.3395	.2641	.3018
18	.2987	.3395	
19	.3395	.5658	.415
20	.4904	.5658	.5281
21	.4108	.415	.4904
22	.3018	.3395	.3772
23	.6588	.6036	.6516
24	.3018	.7087	.5731
Max	.6588	1.4746	1.7718
Min	.2263	.2641	.2263
Avg	.3561	.6430	.5529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 306 / KANERWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3658	.2263	
2	.3658	.2263	
3	.3658	.2641	
4	.3982	.3395	
5	.4706	.3395	
6	.6089	.5228	
7	.8859		.5281
8	.6805	.4066	.3772
9	.6447	.7011	.5609
10	.5068		.631
11	.4908		
12	.5121		.5014
13	.3856		.4344
14	.3582		.4344
15	.362		.439
16	.0724	.3155	.3658
17	.2263	.1509	.1886
18	.3018	.2641	.2641
19	.3395	.4527	.4527
20	.4481	.4527	.4527
21	.415	.3772	.4527
22	.3018	.3395	.3772
23	.2614	.3018	.3395
24	.3658	.2263	.2641
Max	.8859	.7011	.631
Min	.0724	.1509	.1886
Avg	.4222	.3475	.4155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 307 / VIKHALE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4024	.2263	
2	.4024	.2241	
3	.4024	.2263	
4	.5121	.2641	
5	.4344	.2641	
6	.6447	.3018	
7	.8413		.2641
8	.8413	.3734	.2641
9	.7087	.7282	.567
10	.6588		.6024
11	.631		.6661
12	.631		.7628
13	.4252		.6379
14	.5201		.4961
15	.5959		.4706
16	.5201	.5316	.567
17	.2614	.1509	.1509
18	.2641	.1886	.2263
19	.3018	.2641	.1886
20	.3395	.3018	.2641
21	.2641	.3018	.2263
22	.2641	.1886	.2263
23	.2263	.1886	.1886
24	.4024	.2263	.1886
Max	.8413	.7282	.7628
Min	.2263	.1509	.1509
Avg	.4790	.2912	.3865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 301 / MAHABALESHWAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8764	.381	1.0288
2	.8002	.4572	.9526
3	.7621	.381	.9145
4	.7621		.9526
5	.7621		1.0288
6	.8002		1.105
7	.7621	.381	1.448
8	1.3336	.4572	1.6004
9	1.5242	.381	1.9814
10	1.5242	.4954	1.7147
11	1.3336	.381	1.6004
12	1.2193	.3429	1.4098
13	1.2574		1.1431
14	1.448	1.0288	1.4861
15	1.7528		1.2955
16	1.6766		
17	1.6004	1.3336	1.2574
18	1.7909		1.2955
19	2.0195	1.5242	1.4098
20	2.0576	1.6766	1.8671
21	2.0576	1.5242	1.6004
22	1.829	1.448	1.6004
23	1.4098	1.105	1.3336
24	.5716		1.105
Max	2.0576	1.6766	1.9814
Min	.5716	.3429	.9145
Avg	1.3305	.8311	1.3535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 302 / Moleshwar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762
2	.0762	.0762	.0762
3	.0762	.0762	.0762
4	.0762	.0762	.0762
5	.0762	.0762	.0762
6	.0762	.0762	.0762
7	.1905	.1905	.0762
8		.1905	.1524
9		.1905	.2286
10		.1905	.1905
11		.0762	.0762
12		.0762	.0762
13		.0762	.0762
14	.1905	.0762	.0762
15	.1905	.0762	.0762
16	.1905	.0762	.0762
17	.1905	.1143	.0762
18	.2286	.1905	.0762
19	.2286	.1905	.1905
20	.2667	.2286	.2286
21	.2286	.2286	.2286
22	.1905	.1524	.1905
23	.1143	.1143	.0762
24		.1143	.0762
Max	.2667	.2286	.2286
Min	.0762	.0762	.0762
Avg	.1569	.1254	.1127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 303 / Metgutad

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.7147	.5716	.6859
2	1.7147	.4954	.724
3	1.7147	.4572	.6859
4	1.7147	.381	.8002
5	1.9052	.381	.8764
6	2.4768	.7621	.9907
7	1.7528	.7621	1.2955
8	2.4768	1.1431	1.4098
9	2.5911	1.1431	1.3336
10		.9526	1.1812
11		.8383	1.1431
12		.8002	1.1431
13		.6097	.9145
14	.8383	.6859	.8383
15	1.1431	.6859	.8383
16	1.2574	.6478	1.2955
17	1.3336	.7621	.8383
18	1.2193	.7621	
19	1.3336	.8383	
20	1.1431	.9907	1.2574
21	1.2193	.9907	1.0669
22	.9907	.9526	1.0288
23	.8383	.9907	.9526
24	1.1431	.7621	.7621
Max	2.5911	1.1431	1.4098
Min	.8383	.381	.6859
Avg	1.5261	.7653	1.0028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 304 / Venna Lake

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9526	.5716	.8002
2	1.1812	.381	.7621
3	1.0669	.381	.724
4	.7621		.724
5	.9526		.8002
6	1.0669		.8383
7	1.2193		.9526
8	1.5242		1.1812
9	1.0669		1.2193
10	1.0669		1.105
11	1.6385	.0762	1.1812
12	2.2862	.0762	1.1431
13	1.1431	.0762	1.2193
14	1.1431	1.1812	1.105
15	1.2955	.5716	1.1431
16	1.2574		1.1431
17	1.1431	1.1431	1.105
18	1.3336	1.4098	.9526
19	1.6766	1.448	1.448
20	1.6385	1.6385	1.5242
21	1.5242	1.6385	1.1431
22	1.5242	1.4861	1.3336
23	1.1431	1.2193	1.1431
24	.6859	.9526	.9907
Max	2.2862	1.6385	1.5242
Min	.6859	.0762	.724
Avg	1.2622	.8907	1.0701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 305 / Bramha Corp Hotels &
Resorts Feeder KV- 22 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3048	.381
2		.1143	.381
3		.0762	.3429
4		.0762	.3429
5		.3048	.381
6		.3429	.4191
7		.0762	.4572
8		.2286	.4572
9		.3048	.4954
10		.3048	.4572
11		.3429	.4572
12		.3429	.4572
13		.3429	.5335
14		.3429	.5335
15		.3429	
16		.381	
17		.381	.5716
18		.4572	.5716
19		.4954	.5335
20		.4954	.5716
21	.4572	.4572	.5335
22	.4191	.4572	.4954
23	.381	.4191	.4954
24		.381	.381
Max	.4572	.4954	.5716
Min	.381	.0762	.3429
Avg	.4191	.3239	.4659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 303 / TAPOLA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3018	.1448
2	.2263	.2614	.1075
3	.2263	.2614	.1075
4	.2263	.2641	.1075
5	.2614	.3395	.1829
6	.3361	.3696	.2195
7	.3734	.4108	.2172
8	.3326	.4481	.2195
9	.2926	.3696	.1829
10	.2561	.2896	.2218
11	.2926	.2195	.1886
12	.2561	.181	.2957
13	.2587	.0724	.2987
14	.3326	.0732	.3018
15	.3361	.2195	.2987
16	.3395	.2195	.3326
17	.3734	.3292	.2957
18	.4527	.362	.3696
19	.4904	.4755	.4854
20	.6722	.5601	.6413
21	.5975	.4435	.5658
22	.5281	.2957	.4108
23	.381	.2926	.3018
24	.3018	.3048	.1791
Max	.6722	.5601	.6413
Min	.2263	.0724	.1075
Avg	.3503	.3069	.2782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 304 / KELGHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9846	.9816	.1463
2	.9042	.9141	.1448
3	.9042	.9015	.1086
4	.9042	.9419	.1448
5	.9236	.0762	.2172
6	1.049		.2896
7	1.2296		.3658
8	1.2041		.4024
9	1.2003	.0152	.3658
10	1.1698	.8322	.362
11	.8345	.7423	.4066
12	1.1241	.6615	.4066
13	1.1355	.753	.3982
14	1.1546	.6493	.3658
15	1.0997	.7354	.3292
16	1.0574	.9023	.2957
17	1.1431	.7754	.3258
18	1.395	1.1622	.3658
19	1.5947	1.8168	.4805
20	2.2405	2	.6283
21	2.0241	1.9631	.5914
22	1.768	1.6217	.4706
23	1.4583	1.2727	.3658
24	1.1134	.9915	.1433
Max	2.2405	2	.6283
Min	.8345	.0152	.1086
Avg	1.2340	.9862	.3384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 305 / NIZARE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2614	.1867	.1448
2	.2241	.1886	.1448
3	.2241	.1509	.1448
4	.2241	.1867	.1448
5	.2241	.2218	.181
6	.2587	.2241	.2195
7	.2957	.2218	.2534
8	.3292	.2926	.2561
9	.3292	.2172	.2561
10	.2926	.2195	.2587
11	.2195	.2172	.2241
12	.2926	.2507	.2218
13	.2957	.1829	.2218
14	.2561	.181	.2241
15	.2561	.2172	.1848
16	.2587	.2195	.1829
17	.2195	.1829	.1848
18	.2218	.2195	.2195
19	.2957	.3326	.2957
20	.439	.3734	.4481
21	.4066	.3658	.3696
22	.3326	.3292	
23	.2587	.2507	.2534
24	.2614	.1867	.1791
Max	.439	.3734	.4481
Min	.2195	.1509	.1448
Avg	.2782	.2341	.2267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 306 / BHANANG

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.415	.3326	.181
2	.3772	.3018	.1448
3	.3395	.2641	.1448
4	.3395	.2987	.181
5	.3361	.3326	.2172
6	.4108	.4108	.2926
7	.5175	.5175	.2926
8	.5121	.1463	.3292
9	.5121	.4706	.3292
10	.5121	.3292	.3326
11	.4755	.3658	.4108
12	.4024	.2896	.3292
13	.4066	.3258	.3326
14	.3982	.2926	.3361
15	.4024	.2896	.3326
16	.5544	.2896	.3658
17	.5121	.2896	.4066
18	.4481	.3292	.4066
19	.5175	.3734	.439
20	.6516	.4481	.5601
21	.4805	.439	.5175
22	.4755	.3658	.4854
23	.4066	.2896	.4066
24	.4108	.3361	.2149
Max	.6516	.5175	.5601
Min	.3361	.1463	.1448
Avg	.4506	.3387	.3329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254050 / TAPOLA

Feeder No / Name : 301 / GOGAVE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.08	.16	.0953
2	.0762	.1257	.0876
3	.0724	.0914	.0762
4	.0648	.0991	.0876
5	.1067	.1219	.0991
6	.1448	.1448	.0876
7	.1562	.16	.1105
8	.16	.202	.0991
9	.1524	.1867	.1219
10	.1448	.1181	.0991
11	.1486	.1296	.1029
12	.1105	.1334	.1143
13	.1105		.1296
14	.1029		.1067
15		.1296	.1257
16		.16	.1143
17		.1791	.1029
18		.1981	.1257
19		.1867	.1715
20		.1867	.1791
21		.1638	.1715
22		.1562	.1334
23		.1067	.1105
24	.1029	.1638	.0914
Max	.16	.202	.1791
Min	.0648	.0914	.0762
Avg	.1156	.1502	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254050 / TAPOLA

Feeder No / Name : 302 / SHINDI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0724	.1638	.1067
2	.0686	.1334	.0991
3	.0648	.0953	.1029
4	.0648	.1029	.0953
5	.1181	.1219	.1105
6	.1105	.1219	.1181
7		.1219	.1448
8	.0953	.1219	.141
9	.08	.1143	.0876
10	.08	.0953	.0991
11	.1067	.1029	.0991
12	.0953	.08	.0838
13	.141	.0724	.0686
14	.1296	.0686	.08
15		.0686	.0762
16		.0838	.0991
17		.0953	.0914
18		.1638	.1067
19		.2096	.16
20		.2629	.2172
21		.1981	.1791
22		.16	.1334
23		.1448	.0991
24	.0991	.1677	.0991
Max	.141	.2629	.2172
Min	.0648	.0686	.0686
Avg	.0947	.1280	.1124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 301 / ANEWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4954	.3582
2	.5335	.4954	.3582
3	.5335	.4954	.3582
4	.5335	.4656	.3582
5	.5716	.4656	.394
6	.6478	.5373	.5014
7	.6478	.5373	.5373
8	.6859	.5014	.4656
9	.6478	.5014	.3582
10	.6089	.4656	.4656
11	.5731	.4656	.3582
12	.5731	.4656	.4656
13	.3224	.394	.4298
14	.4656	.394	.4656
15		.4298	.4298
16		.3982	.4656
17	.5731	.4656	.4656
18	.6478	.4298	.6859
19	.7621	.5731	.6859
20	.9526	.7164	.8002
21	.8383		.8383
22	.6859		.6478
23	.6097	.4656	.4954
24	.5716	.5335	.394
Max	.9526	.7164	.8383
Min	.3224	.394	.3582
Avg	.6145	.4860	.4909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 302 / ANEWADI AGRICULTURE
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.4685	1.2536	
2	1.3611	1.2178	
3	1.3611	1.182	
4	1.3969	1.182	
5	1.5043	1.2536	
6	1.6834	1.4327	
7	1.97	1.7551	
8	1.8983	1.3611	
9			1.2308
10			1.3969
11			1.6834
12			1.6476
13			1.5402
14			1.5402
15		.1433	1.576
16		.1433	1.576
17	.2149	.1433	1.2894
18	.2058	.1433	1.166
19	.2401	.2149	1.1317
20	.2743	.2149	.2401
21	.3086		.2743
22	.2743	.2507	.2743
23	1.3375		.2058
24	1.5043	1.2346	
Max	1.97	1.7551	1.6834
Min	.2058	.1433	.2058
Avg	1.0627	.8204	1.1182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 303 / Kudal Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8596	.8238	.6805
2	.8238	.788	.6805
3	.8238	.788	.6805
4	.8596	.7522	.6805
5	.8954	.788	.6805
6	.9671	1.0029	1.0029
7	.9671	1.0029	1.0745
8	1.0029	.7522	1.0387
9	1.0745	1.1104	1.0745
10	1.2178	1.0745	1.182
11	1.182	1.0029	1.0745
12	1.1462	.9313	1.0745
13	.8596	.7164	1.0745
14	1.1104		.9671
15		.7522	.9671
16		.7522	.9313
17	1.4327		.9313
18	1.6385	.8954	1.0669
19	1.448		1.2574
20	1.6385	.7164	1.5623
21	1.5242	1.2536	1.3717
22	1.2955	1.0745	1.2574
23	1.0288	.8596	.9907
24	.8954	.8596	.7164
Max	1.6385	1.2536	1.5623
Min	.8238	.7164	.6805
Avg	1.1223	.8903	1.0008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 304 / KUDAL AGRICULTURE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1433	.1075
2	.1791	.1433	.1075
3			.1075
4			.1075
5			.1075
6			.1791
7			.1791
8			.1433
9	1.8983	.5014	
10	2.2923	.5014	
11	2.2923	1.7193	
12	2.364	1.9342	
13	1.7193	1.2894	
14	1.576		
15		1.6476	.1791
16		1.7193	.1791
17	2.0058	1.4327	.1433
18	1.7833	1.2178	.1715
19	1.4746	.1433	.1715
20	.1715	.1433	.1715
21	.1715	.1433	.2058
22	.1715	.1075	.2058
23	.1372	.1075	1.166
24	.1791	.1372	.1075
Max	2.364	1.9342	1.166
Min	.1372	.1075	.1075
Avg	1.1622	.7666	.2078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 305 / KARHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4298	.2865
2	.394	.4298	.2507
3	.3582	.394	.2865
4	.394	.4298	.2865
5	.4298	.4298	.2865
6	.4656	.4656	.3224
7	.5014	.6447	.4298
8	.6447		.5014
9	.6805	.6089	.5014
10	.6447	.5014	.4656
11	.7164	.5373	.4656
12	.6805		.394
13	.5014		.4656
14	.5373	.4656	.5014
15		.4656	.5014
16		.4656	.4656
17	.6805	.5373	.5731
18	.8002		.6859
19	.9907	.1791	.8383
20	1.105	.5731	.8764
21	.9145	.5731	.7621
22	.724	.5014	.6478
23	.5335	.3224	.5335
24	.4298	.4298	.3224
Max	1.105	.6447	.8764
Min	.3582	.1791	.2507
Avg	.6162	.4692	.4854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 401 / 33 KV PACHGANI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
11	19.1015	
12	18.8958	
13	18.0384	
14	17.6955	
15	8.059	
16	7.8532	.9602
17		6.1728
18		6.0357
19		7.3731
20		6.2071
21		6.4815
22		7.6818
23		8.2648
24		6.653
Max	19.1015	8.2648
Min	7.8532	.9602
Avg	14.9406	6.2033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / PACHGANI

Feeder No / Name : 301 / BHILAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.9058	.7545	.6348
2		.724	.5975
3		.679	.5975
4	2.9264	.679	.5975
5	2.9058	.7468	.6283
6	3.5818	.8048	.679
7	3.8272	1.182	1.094
8	4.1716	1.2894	1.1694
9	4.9383	1.2308	1.1827
10		1.0974	.8962
11	4.1076	.9709	.8871
12	3.9918	.8413	.8779
13	4.1027	.8413	.8501
14	.8779	.8048	.8589
15	.9671	.7964	.7922
16	.8326	.6516	.8131
17	.9877	.695	.7316
18	1.1827	.8501	.7964
19	1.3394	.9979	1.1706
20	1.3169		1.1458
21	1.307		1.1203
22	1.1203	1.0349	.9145
23	.8962	.8215	.724
24	2.1948	.7922	.6722
Max	4.9383	1.2894	1.1827
Min	.8326	.6516	.5975
Avg	2.4039	.8766	.8513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / PACHGANI

Feeder No / Name : 302 / PACHGANI CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.2071	1.0349
2	1.0974	1.1317	.9313
3	1.086	1.0669	.9511
4	1.086	1.0456	1.0082
5	1.0974	1.1088	.9979
6	1.1462	1.1584	1.1088
7	1.6632		1.419
8	1.5565	1.8461	1.6804
9	1.6289	1.9387	1.6461
10	1.4998	1.6095	1.7002
11	1.6461	1.5364	1.5893
12	1.576	1.2437	1.4842
13	1.4327		1.4266
14	1.3611	1.1584	1.3676
15	1.382	1.1584	1.3535
16	1.2803	1.1222	1.3032
17	1.3394	1.2071	1.2071
18	1.3969	1.2048	1.267
19	1.4998	1.4118	1.6118
20	1.5927		1.6289
21	1.7372	1.5927	1.6651
22	1.6057	1.448	1.3756
23	1.4335	1.2437	1.1946
24	1.3443	1.2323	1.0498
Max	1.7372	1.9387	1.7002
Min	1.086	1.0456	.9313
Avg	1.4040	1.3177	1.3334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / PACHGANI

Feeder No / Name : 303 / WATER SUPPLY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.181	.1509	.112
2	.1478	.1509	.1086
3	.1494	.1524	.1109
4	.1494	.1867	.1509
5	.1494	.2218	.1494
6	.2195	.2896	.1494
7	.2896	.3189	.2957
8	.3224	.3258	.2926
9	.2926	.2561	.2561
10	.1829		.2614
11	.2534	.2218	.2195
12	.1791		.2172
13	.1734	.0739	.2195
14	.1387	.0732	.2218
15	.1753	.0747	.2195
16	.181	.1097	.2172
17	.2126	.1097	.2195
18	.2507	.104	.1829
19	.2926	.1463	.3258
20	.3258	.3292	.2896
21	.3696	.2926	.2896
22	.2987	.2587	.2172
23	.2263	.1867	.181
24	.1867	.1494	.1478
Max	.3696	.3292	.3258
Min	.1387	.0732	.1086
Avg	.2228	.1901	.2106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 301 / SURUR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0754	.5335	.2641
2	.0754	.4954	.2641
3		.4191	.2641
4		.381	.3018
5		.381	.3018
6		.724	
7		1.0288	.9054
8		.9526	.8299
15			.0754
16			.0754
17		.0754	.0754
18	.0381	.0754	.0754
19	.1143	.0754	.0754
20	.1143	.0754	.0754
21	.1143	.0754	.0754
22	.1143		.0754
23	.6859	.0754	.5281
24	.0754	.5716	.2641
Max	.6859	1.0288	.9054
Min	.0381	.0754	.0754
Avg	.1564	.3960	.2663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 302 / NEW KENJAL AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3018	.0381	.0377
2	.2641	.0762	.0377
3	.2641		
4	.2641		
5	.3018		
6	.415		
7	.5487		
8	.5658		
9	.5658	.9145	.8299
10	.5658		.6413
11	.3429		.6036
12	.5716		.6413
13	.5716		.6036
14	.4191		.6036
15	.5716		.6036
16	.6097		.6036
17	.0381		.0754
18	.0381		.0754
19	.0762		.0754
20	.0762		.0754
21	.0762		.0754
22	.0762		.0754
23	.0762		.0754
24	.3395	.0762	.0377
Max	.6097	.9145	.8299
Min	.0381	.0381	.0377
Avg	.3308	.2763	.3206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 303 / NEW KENJAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2286	
2	.2263	.2286	.2263
3	.2263	.2286	.2263
4	.2263	.2286	.2263
5	.2641	.2286	.2263
6	.2641	.2286	.2263
7	.2641	.2286	.2641
8	.2641	.2286	.2263
9	.3395	.2286	.3018
10	.2263		.1886
11	.1905		.3395
12	.1905		.3018
13	.1905		.2263
14	.3048		.1886
15	.3048		.2263
16	.3048		.2263
17	.2667		.3395
18	.1905		.1886
19	.2667		.3018
20	.3429		.3772
21	.3429		.3395
22	.3048		.3018
23	.2667		.2641
24	.2641	.2286	.2263
Max	.3429	.2286	.3772
Min	.1905	.2286	.1886
Avg	.2624	.2286	.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 304 / SURUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.4726	2.3624	.3772
2	2.2824	2.3624	.3772
3	2.2824	2.2862	.3772
4	2.2443	2.2481	.3772
5	2.3205	2.3243	.3772
6	2.5107	2.4386	.3772
7	2.6627	2.5148	.415
8	2.7385	2.7053	.415
9	2.7774	2.6672	.415
10	2.7008	2.0195	.4904
11	2.8578		.415
12	2.7053		.415
13	2.6291	1.2955	.3772
14	2.6672	2.1338	.415
15	2.5529	2.0576	.415
16	2.6291	1.9052	.415
17	2.5529	1.9052	.3772
18	2.4386	2.0195	.3772
19	2.8578	2.21	.5658
20	3.0865	3.1245	.679
21	3.7342	3.0864	.6036
22	3.6199	2.934	.5658
23	3.4294	2.7054	.4904
24	2.8533	2.6672	.415
Max	3.7342	3.1245	.679
Min	2.2443	1.2955	.3772
Avg	2.7336	2.3624	.4385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 305 / OZARDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4954	.4904
2	.4904	.4954	.4904
3	.4904	.4954	.4904
4	.4904	.4954	.4527
5	.5281	.5335	.4527
6	.6413	.6478	.4904
7	.7167	.6478	.5281
8	.7545	.6859	.4527
9	.679	.5335	.4527
10	.6413		.3772
11	.5335		.4904
12	.4954		.4904
13	.5335		.4527
14	.4954		.4904
15	.4191		.4904
16	.381		.4904
17	.4572		
18	.5335		.4527
19	.6097		.679
20	.7621		.7545
21	.6859		.7545
22	.6478		.7167
23	.5716		.5658
24	.5281	.4954	
Max	.7621	.6859	.7545
Min	.381	.4954	.3772
Avg	.5673	.5526	.5230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 201 / 11 KV WAI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	3.388	3.1749	1.0562
2	3.3517	2.9881	1.0185
3	3.2524	2.8166	.9808
4	3.1257	2.7595	.9431
5	2.64	2.758	.9431
6	2.5499	2.9667	.9054
7	2.5962	2.8882	1.1317
8	3.901	2.274	1.5655
9	4.7523	2.2331	2.0957
10	5.2645	2.3974	2.3815
11	5.4824	2.1253	2.2672
12	5.4687	1.8512	2.4958
13	5.3109	1.7529	2.2291
14	5.2736	1.9669	2.191
15	5.3277	2.2199	2.2862
16	5.2066	2.3146	2.1338
17	4.8437	2.1218	2.0005
18	4.4414	1.756	2.0195
19	3.9445	2.3542	2.0005
20	3.424	2.8363	1.9814
21	3.2533	2.1544	1.4098
22	3.1543	2.0024	1.5242
23	3.5087	2.2031	1.8099
24	3.5351	2.825	1.094
Max	5.4824	3.1749	2.4958
Min	2.5499	1.7529	.9054
Avg	4.0415	2.4059	1.6860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 202 / 11 KV MANDHARDEV AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3734	.0158	.0187
2	.3361	.0158	.0187
3	.3361		
4	.3361		
5	.3174		
6	.4294		
7	.4854		
8	.5601		
9	.4428	.5228	.4744
10	.4111	.4294	.4744
11	.3795	.4854	.4428
12	.3479	.5228	.4111
13	.3479	.2241	.253
14	.3479	.3772	.253
15	.3479	.3479	.253
16	.3795	.4108	.2835
17	.0158	.0187	.0158
18	.0158	.0187	.0158
19	.0158	.0187	.0177
20	.0158	.0187	.0316
21	.0158	.0187	.0158
22	.0158	.0187	.0158
23	.0158	.0187	.0158
24	.3734	.0158	.0187
Max	.5601	.5228	.4744
Min	.0158	.0158	.0158
Avg	.2776	.1944	.1683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 203 / 11 KV WAI NAGARPALIKA PWW NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0791	.0602	.0791
2	.0633	.0602	.0633
3	.0633	.0753	.0633
4	.0781	.0753	.0791
5	.0781	.0753	.0791
6	.0781	.0753	.0791
7	.0781	.0753	.0791
8	.0791	.0753	.0781
9	.0753	.0791	.0753
10	.0753	.0791	.0753
11	.0753	.0791	.0753
12	.0602	.0791	.0753
13	.0602	.0791	.0753
14	.0753	.0791	.0753
15	.0753	.0791	.0602
16	.0753	.0791	.0753
17	.0602	.0791	.0753
18	.0753	.0791	.0903
19	.0753	.0791	.0753
20	.0602	.0791	.0753
21	.0602	.0791	.0602
22	.0753	.0791	.0602
23	.0753	.0633	.0753
24	.0791	.0753	.0791
Max	.0791	.0791	.0903
Min	.0602	.0602	.0602
Avg	.0721	.0758	.0741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 204 / 11 KV MAPRO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1524	.132
2	.1886	.1334	.132
3	.1886	.1334	.132
4	.1886	.1524	.1132
5	.1886	.1524	.1132
6	.1886	.1715	.1132
7	.0566	.1334	.1886
8	.2641	.1905	.3018
9	.381	.0754	.5335
10	.381	.1886	.2667
11	.381	.1509	.362
12	.381	.1886	.3048
13	.4572	.0943	.381
14	.5144	.0943	.5716
15	.5144	.132	.6097
16	.5335	.0943	.5335
17	.4382	.1132	.381
18	.3429	.0943	.362
19	.3048	.132	.381
20	.2286	.132	.2286
21	.1905	.1509	.2286
22	.1905	.0943	.2286
23	.2096	.132	.2286
24	.1886	.1715	.132
Max	.5335	.1905	.6097
Min	.0566	.0754	.1132
Avg	.2954	.1358	.2900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 205 / 11 KV MANDHARDEV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2587	.2926
2	.2926	.2402	.2743
3	.2926	.2402	.2743
4	.3292	.2587	.2743
5	.3475	.2772	.2926
6	.4024	.3696	.3292
7	.4207	.3511	.3841
8	.3475	.2957	.3658
9	.3511	.2743	.2587
10	.3326	.2195	.2402
11	.3142	.2378	.2402
12	.3142	.1829	.2402
13	.3142	.2195	.3142
14	.2957	.2012	.3142
15	.2957	.1829	.3326
16	.3142	.2195	.2957
17	.3142	.2926	.2957
18	.4435	.3292	.3142
19	.5175	.4572	.4066
20	.5544	.4938	.5359
21	.499	.439	.4805
22	.4435	.4207	.4066
23	.2957	.2743	.3326
24	.3109	.2957	.2926
Max	.5544	.4938	.5359
Min	.2926	.1829	.2402
Avg	.3598	.2930	.3245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 301 / 22 KV DHAGE ALI (WAI CITY
ALT) Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.724	.6935	.2926
2	.6721	.6858	.2926
3	.6721	.6554	.2926
4	.6645	.7011	.2926
5	.6645	.7316	.2926
6	.7834	.8078	.3292
7	.948	.8306	.3292
8	.9648	1.0593	.4024
9	1.0212	1.1355	.4191
10	.9908	1.0532	.381
11	.9831	.8886	.381
12	.9373	.881	.4066
13	.8535	.7811	.381
14	.884	.7621	.381
15	.8535	.7316	.4191
16	.8001	.7316	.4191
17	.8306	.7255	.4191
18	.8992	.7011	.4191
19	1.0593	.8139	.4572
20	1.1736	.8886	.4954
21	1.0822	.8886	.4191
22	.9984	.8292	.381
23	.884	.7026	
24	.7621	.6858	.2926
Max	1.1736	1.1355	.4954
Min	.6645	.6554	.2926
Avg	.8794	.8069	.3737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 302 / 22 KV MENAWALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.6017	2.5225	.6219
2	2.5103	2.356	.6219
3	2.4052	2.3724	.5853
4	2.3747	.6097	.5853
5	2.3609		.6219
6	2.7953	.9198	.8048
7	3.6077	3.0403	1.0608
8	3.7556	3.0883	1.2071
9	3.7727	3.0437	1.1088
10	3.3886	3.4522	.9979
11	3.4115	3.2541	.6653
12	3.232	2.7831	.8131
13	2.1052	2.5286	.924
14	2.8597	2.2588	.8871
15	2.9435	2.114	.8871
16	2.8726	2.2344	.8501
17	3.2972	2.2801	.8871
18	3.5658	2.5271	.961
19	4.3351	3.5254	
20	5.5898	4.5054	1.6263
21	5.3605	4.3911	1.5154
22	4.7119	3.6275	1.3306
23	3.8481	3.0316	.961
24	2.9736	2.5267	.6584
Max	5.5898	4.5054	1.6263
Min	2.1052	.6097	.5853
Avg	3.3616	2.7388	.9210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 303 / 22 KV PASARNI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4344	3.7403	.5487
2	.4192	3.1969	.5487
3	.4192	3.2731	.5487
4	.4192	1.9966	.5487
5	.4192	1.3565	
6	.4603	.7243	
7	.4839	4.9528	.5487
8	.4496	5.3387	.6859
9	.2591	3.1398	.567
15	.3044		.1417
16	.477		.1063
17	.4618	.1029	.1063
18	.4923	.4382	.1417
19	.5075	.4687	.1417
20	.599	.4839	.1772
21	.5989	.4839	.1063
22	.538	.4839	.1063
23	3.4758	.3658	.7087
24	2.6902	2.3022	.4801
Max	3.4758	5.3387	.7087
Min	.2591	.1029	.1063
Avg	.7321	1.9323	.3655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]**SATARA CIRCLE[575]****WAI DIVISION[700]****WAI[121]****BU 0957****Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN****Feeder No / Name : 402 / 33 KV GARWARE****Feeder KV- 33 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	14.0844	14.1689	3.1121
2	13.9472	13.8832	2.999
3	13.4894	13.7517	2.9424
4	13.7466	13.4945	2.9424
5	13.4037	13.5574	2.8292
6	13.1362	13.1688	2.6595
7	13.4568	13.0373	2.6595
8	13.0915	13.0202	2.8858
9	14.2147	13.5991	3.0293
10	14.3862	13.7483	3.315
11	14.592	13.8546	2.9721
12	14.4205	13.8615	2.915
13	14.3462	12.8756	2.8578
14	14.6033	12.7778	2.7435
15	15.1635	13.3487	2.6292
16	15.0435	13.6317	2.7435
17	14.4205	13.8889	2.7435
18	14.6606	13.9009	2.6292
19	14.369	13.1551	2.6292
20	14.1118	12.4417	2.572
21	13.5173	12.4006	2.572
22	13.7117	11.9993	
23	14.6205	10.9243	2.7435
24	13.8838	12.1342	2.9424
Max	15.1635	14.1689	3.315
Min	13.0915	10.9243	2.572
Avg	14.1009	13.1927	2.8290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 404 / 33 KV ATHARVA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	8.4465	7.9276	1.5278
2	9.2575	7.2302	1.5278
3	8.8306	10.1051	1.4712
4	6.7696	7.516	1.0185
5	7.5737	6.933	1.4146
6	6.0768	5.9956	.9619
7	10.6276	3.6866	2.0936
8	8.2013	3.8295	1.5278
9	9.265	2.5395	.9717
10	7.0245	1.7627	2.0576
11	11.5112	1.5175	.4572
12	9.4193	1.2603	1.7147
13	8.9277	1.1865	2.5149
14	7.8989	1.1522	2.1719
15	9.5508	1.2088	2.2862
16	9.7108	1.226	1.6575
17	7.9047	1.1522	1.3717
18	6.8873	1.2431	2.0576
19	7.5389	1.2774	1.6004
20	7.196	4.844	.9717
21	6.9787	2.8224	1.7147
22	7.9561	2.2205	1.7147
23	7.5846	2.3851	1.9433
24	8.8734	3.8409	.9054
Max	11.5112	10.1051	2.5149
Min	6.0768	1.1522	.4572
Avg	8.3338	3.5359	1.5689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 301 / BHUINJ AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1143	1.6385	.1143
2	.1143	1.5242	.1143
3			.1143
4			.1143
5			.1905
6			.1905
7			.1905
8			.1905
9	3.5208	3.7723	
10	4.5725	3.9247	
11	3.8866	4.3058	
12	3.8866	4.1914	
13	3.8866		
14	2.5911	3.0864	
15	3.2007	1.2955	
16	2.8578	1.2574	
17	.1143	.0762	
18	.1143	.0762	.2286
19	.1143	.1905	.2667
20	.1905	.1905	.2667
21	.2286	.1905	.2286
22	.1524	.1905	.2286
23	.1143	.1143	
24	.1143	1.6385	.1143
Max	4.5725	4.3058	.2667
Min	.1143	.0762	.1143
Avg	1.6541	1.6273	.1823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 302 / JAMB AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0762	.1143
2	.1143	.0762	.1143
3			.1143
4			.1143
5			.1143
6			.1905
7			.1905
8			.1905
9	2.4905		
10	3.2769		
11	2.7054	2.8959	
12	2.4006	2.8197	
13	2.4768		
14	1.829	2.7435	
15	2.1338	2.6673	.0762
16	2.0957		.0762
17	.0762		.0762
18			.0762
19			.0762
20	.0762	.1905	.1143
21	.0762	.1905	.1143
22	.0762	.1905	.1143
23	.0762	.1143	2.3045
24	.1143	.0762	.0762
Max	3.2769	2.8959	2.3045
Min	.0762	.0762	.0762
Avg	1.2583	1.0946	.2360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 303 / BHUINJ GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6219	.6859	.6097
2	.6219	.724	.6097
3	.5853	.6859	.6478
4	.5853	.6859	.6859
5	.6584	.724	.724
6	.7164	.8002	.724
7	.8238	.9145	.8764
8	.7522	.8002	.7621
9	.695	.6478	.6859
10	.6478	.6478	.6584
11	.724	2.8959	.5487
12	.724	.6478	
13	.6097		.5853
14	.6478		.5487
15	.6478	.6097	.695
16	.6478		.6584
17	.724		.6584
18	.6859	.7621	.6584
19	.8002	.8764	.7164
20	.9526	.9526	.8596
21	.9145	.9526	.8238
22	.8764	.8383	.788
23	.8002	.6859	.695
24	.6219	.6859	.6478
Max	.9526	2.8959	.8764
Min	.5853	.6097	.5487
Avg	.7119	.8612	.6899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 304 / JAMB GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6219	.6097	
2	.5853	.6097	
3	.5487	.6097	.6478
4		.6097	.6859
5	.6219	.6478	.6859
6	.695	.7621	.6859
7	.788	.8383	.7621
8	.6584	.724	.724
9	.5853	.5335	.6097
10	.7621	.5716	.5121
11	.8383	.5716	.7164
12	.8383	.5716	
13	.6859		.8063
14	.8002		.5487
15	.724	.5716	
16	.724		.6584
17	.8764	.5716	.6584
18		.5716	.6584
19		.7621	.6584
20	1.2193	.9145	1.0029
21	1.1431	.9145	.9313
22	.9145	.7621	.8596
23	.6097	.6859	.6219
24	.5853	.6097	.6859
Max	1.2193	.9145	1.0029
Min	.5487	.5335	.5121
Avg	.7536	.6678	.706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 305 / 22 KV KHADAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17	31-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.5402		.0762
2	1.5074	1.5242	.0762
3	1.4419	1.5242	
4	1.5074	1.5242	
5	1.5729	1.4861	
6	1.704	1.5242	
7	2.0645	2.0957	
8	1.8023	.6859	
9		1.829	2.2862
10		1.829	1.0395
11		1.6766	1.0867
12		1.6766	
14		1.5242	1.7695
15	.1143	1.5242	1.6712
16	.0762	1.5242	1.6095
17	.0762	.0762	.1143
18	.1524	.0762	.1143
19	.1524	.0762	.1143
20	.1524	.1905	.1143
21	.1143	.1905	.1143
22	.1143	.1905	.1143
23	.6859	.0762	.1143
24	1.704	1.6385	.0762
Max	2.0645	2.0957	2.2862
Min	.0762	.0762	.0762
Avg	.9157	1.1120	.6557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 302 / 22 KV COLLEGE ROAD

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	.8535	.823
2	.7773	.7773
3	.7773	.7468
4	.7621	.7468
5	.7773	.7621
6	.823	.8688
7	1.0059	1.1126
8	1.2041	1.2498
9	1.2193	1.1584
10	1.3413	1.2346
11	1.2803	
12	1.0822	
13	1.0822	
14	1.0974	
15	1.0517	
16	1.1279	1.2193
17	1.1736	1.1431
18	1.1888	.5792
19	1.1279	1.0822
20	1.1888	1.1888
21	1.1736	1.2041
22	1.1736	1.1126
23	1.0669	.9907
24	.945	.884
Max	1.3413	1.2498
Min	.7621	.5792
Avg	1.0542	.9939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 304 / 22 KV WAI CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	4.5877	4.542
2	4.3439	4.2676
3	4.2067	4.1914
4	4.161	4.1
5	4.2524	4.2829
6	4.5572	4.5115
7	4.7249	4.6944
8	4.8163	4.8468
9	4.9688	4.9535
10	5.2431	3.9171
11	5.2279	
12	5.2584	
13	5.2584	
14	5.1974	
15	5.2126	6.0966
16	5.1364	5.4565
17	5.1517	5.0602
18	5.2736	4.923
19	5.5175	5.3498
20	7.2398	6.4472
21	6.874	6.371
22	6.2491	6.1119
23	5.8375	5.6242
24	5.1059	4.9078
Max	7.2398	6.4472
Min	4.161	3.9171
Avg	5.1834	5.0328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAY-17 and 04-JUN-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 404 / 33 KV WAI-VELE

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	29-MAY-17	30-MAY-17
HR	Load (MW)	Load (MW)
1	3.9095	7.6818
2	3.7037	6.653
3	3.5665	6.8587
4	3.4979	5.3498
5	3.4979	3.5665
6	3.9781	.1372
7	5.2126	9.0535
8	5.6927	10.2881
9	5.4184	10.0137
10	5.144	5.2126
11	23.8683	4.9383
12	23.7312	4.2524
13	20.9877	3.9781
14	22.2223	3.6351
15	12.2085	3.3608
16	10.631	4.2524
17	4.6639	9.808
18	4.9383	9.6022
19	5.8985	12.2085
20	7.7504	11.8656
21	7.7504	12.3457
22	6.7901	12.4143
23	7.6132	12.8944
24	7.9561	10.4938
Max	23.8683	12.8944
Min	3.4979	.1372
Avg	8.7763	7.5360