

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 206 / 11 KV Jai Gajanan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9198	.9556	.9938	1.089	1.0296	1.0715	1.0707
2	.8444	.8954	.9099	1.0128	.9617	.9945	.9976
3	.7987	.865	.8596	.9343	.8985	.9381	.929
4	.759	.8002	.8406	.9099	.868	.8886	.8985
5	.7301	.7621	.8002	.8825	.8208	.8619	.8672
6	.6958	.7385	.7766	.8528	.8169	.8558	.8314
7	.7346	.7796	.8368	.8665	.8276	.8131	.8269
8	.7819	.7827	.7773	.8345	.7948	.82	.7743
9	.6851	.7278	.7247	.7293	.7263	.7567	.7263
10	.6325	.7232	.6866	.7217	.6584	.6882	.6874
11		.6622	.6508	.5838	.6401	.679	.6851
12		.6638	.6607	.6668	.6485	.6638	.6493
13	.9282	.7301	.708	.7872	.7034	.7133	.7034
14	.8368	.8017	.7987	.8154	.7514	.8048	.743
15	.8589	.8612	.8558	.8421	.8322	.8589	.8345
16	.8756	.8703	.8657	.9953	.8657	.8726	.8612
17	.8436	.8604	.8421	.9412	.8688	.8383	.8573
18	.7758	.7956	.7491	.8711	.8032	.8093	.7918
19	.7743	.8276	.7827	.8436	.8116	.7994	.7857
20	.8581	.8642	.8741	.9023	.8665	.868	.8985
21	.8512	.8772	.9038	.9183	.8924	.8619	.8863
22	.8962	.929	.9412	.9892	.9686	.9663	.9625
23	.993	1.0044	1.0898	1.0928	1.0722	1.0837	1.0661
24	1.0014	1.028	1.1248	1.0928	1.1058	1.1294	1.1439
Max	1.0014	1.028	1.1248	1.0928	1.1058	1.1294	1.1439
Min	.6325	.6622	.6508	.5838	.6401	.6638	.6493
Avg	.8216	.8252	.8356	.8823	.8430	.8599	.8532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 201 / 11 KV BORGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17
HR	Load (MW)
19	1.7909
Max	1.7909
Min	1.7909
Avg	1.7909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 202 / 11 KV KHAMBORA ,EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6626	.5731	.4835	.591		.6219	.4119
2	.6089	.5731	.499	.591		.6283	.4298
3	.6348	.5731	.5014	.5914		.6283	.4298
4	.6348	.5731	.499	.5729		.6161	.4298
5	.6653	.5731	.4805	.5729		.5601	.4119
6	.6805	.5731	.5552	.5544		.5415	.4835
7	.6984	.5731	.6805	.6089		.5175	.5552
8	.6447	.5731		.788		.5487	.5359
9	.6268	.591	.7343	.788		.5228	.5194
10	.8059	.6516	.7392	.7701	.695	.6722	.499
11	.8029	.6626	.7655	.788	.3224	.6068	.5194
12	.8589	.6838		.788	.3224	.1433	.1791
13	.5601	.1612	.7468		.1433	.1433	.1791
14	.4854	.181	.7682			.1433	.197
15	.7842	.2402	.1646	.2947	.3045	.1433	.197
16	.8589	.3045	.2195	.3224	.3045	.197	.197
17	.8215	.3224	.2195	.0347	.3045	.1791	.2328
18	.2865	.2507	.6697	.4207	.7701	.6268	
19	.2865	.2772	.7207	.9145	.7682	.6838	.6401
20	.2865	.6626	.6516	.7316	.8413	.6283	.6535
21	.5731	.6447	.6268	.7133	.823	.591	.6219
22	.5731	.5552	.6447	.695	.8048	.591	.6584
23	.5731	.5194	.6268	.695	.6219	.5194	.6219
24	.6626	.5731	.5544	.6268	.7095	.6283	.5014
Max	.8589	.6838	.7682	.9145	.8413	.6838	.6584
Min	.2865	.1612	.1646	.0347	.1433	.1433	.1791
Avg	.6282	.4944	.5705	.6115	.5525	.4868	.4393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 203 / 11 KV PALSO

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.5731	.1294	.6099	.6584	.5729	.6099
2	.6099	.5731	.1294	.6283	.5853	.5788	.6099
3	.6099	.5731	.1294	.6099	.5853	.5788	.5914
4	.6099	.5373	.1294	.6099	.5853	.5788	.5914
5	.6099	.5014	.1294	.6099	.5853	.5359	.5544
6	.5544	.5014	.1294	.5544	.567	.5041	.5359
7	.4805	.4477	.1294	.4251	.6401	.462	.4805
8	.499	.4477	.0924	.462	.5487	.462	.462
9	.499	.4477	.0924	.4435	.4755	.4572	.4435
10	.499	.4435	.499	.4251	.4755	.5041	
11	.9335	.4435	.4755	.4298	.5014	.4656	.4656
12	.6908	.5175	.5228	.4298	.5014	.4656	.4477
13	.5487	.4805	.5121		.5014		.5194
14	.4854	.499	.5304	.5548	.5014	.4477	.5373
15	.4854	.499	.5487	.5552	.5014	.5014	.5373
16	.4854	.5175	.5487	.5552	.5373	.5373	.5552
17		.5175	.4938	.5552	.5373	.5194	.5014
18	.5194	.5544	.5175	.5853	.5552	.5359	
19	.591	.6283	.6838	.6584	.6036	.6283	.5853
20	.6447	.6838	.6838		.6767	.6468	.7468
21	.6626	.6653	.6653	.7499	.6584	.6838	.695
22	.6268	.7023	.6838	.7316	.6584	.7207	.7316
23	.5731	.6653	.6653	.7316	.6584	.6653	.695
24	.6283	.5731		.6447	.6584	.6348	.6283
Max	.9335	.7023	.6838	.7499	.6767	.7207	.7468
Min	.4805	.4435	.0924	.4251	.4755	.4477	.4435
Avg	.5851	.5414	.3966	.5709	.5732	.5516	.5693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 204 / 11 KV KANSHIVANI,AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0179	.0189	2.0725	1.8656	1.8671	2.0538
2	.0187	.0179	.0189	2.0538	1.8656	1.8671	1.9978
3	.0187	.0179	.0187	1.9044	1.9044	1.8298	1.9404
4	.0187	.0179	.0187	1.6804	1.8656	1.7177	1.9605
5	.0187	.0179	.0189	1.7737	1.8656	1.8671	1.8088
6	.0187	.0179	.0189	1.8111	1.9204	1.9231	1.6244
7	.0187	.0179	.0189	2.0351	1.9387	1.9978	1.7364
8			.0187	2.1472	2.0851	2.0351	1.7737
9	.0187	.0179	.0187	2.2032	1.9936	2.0538	1.7737
10	2.3339	2.2916	.0187		.0183	.0187	2.0576
11	2.4832	2.5873	.0183	.0179	.0179	.0179	1.9342
12	2.2218	2.3101	.0187	.0179	.0179	.0179	1.8804
13	2.0165	2.1068	.0183		.0179	.0179	1.7013
14		2.0698			.0179	.0179	1.7551
15		1.922		.0179	.0179	.0179	1.7551
16	1.8111	2.0513	.0183	.0179	.0179	.0179	1.8088
17	1.9605	2.3655	.0183	.0179	.0179	.0179	2.0416
18	2.0774	.0185	.0189	.0183	.0179	.0187	
19	1.7909	.0185	.0189	.0183	.0183	.0187	.0183
20	.0179	.0185	.0189	.0183	.0183	.0187	.0183
21	.0179	.0185	.0189	.0183	.0183	.0187	.0183
22	.0179	.0185	.0189	.0183	.0183	.0185	.0183
23	.0179	.0191	.0187	.0183	.0183	.0185	.0187
24	.0187	.0179	.0189	1.9879	2.1216	1.9605	1.9231
Max	2.4832	2.5873	.0189	2.2032	2.1216	2.0538	2.0576
Min	.0179	.0179	.0183	.0179	.0179	.0179	.0183
Avg	.8064	.7816	.0187	.9461	.8200	.8073	1.4617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 206 / 11 KV Rajeshwar Express. NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0029	.0029	.0029	.0029	.0183	.0187	.0029
2	.0029	.0029	.0029	.0029	.0183	.0183	.0029
3	.0029	.0029	.0029	.0029	.0183	.0183	.0029
4	.0029	.0029	.0029	.0185	.0183	.0183	.0029
5	.0029	.0029	.0029	.0029	.0183	.0183	.0029
6	.0029	.0029	.0029	.0029	.0183	.0183	.0029
7	.0029	.0029	.0029	.0029	.0183	.0183	.0029
8	.0029	.0057	.0029	.0029	.0183	.0183	.0029
9	.0029	.0057	.0029	.0029	.0183	.0183	.0029
10	.0029	.0057	.0029	.0029	.0183	.0183	.0029
11	.0187	.0029	.0187	.0057	.0057	.0057	.0057
12	.0187	.0029	.0187	.0057	.0057	.0358	.0057
13	.0183	.0029	.0061	.0057	.0057	.0057	.0057
14	.0183	.0029	.0183	.0029	.0057	.0057	.0057
15	.0187	.0029	.0061	.0029	.0057	.0057	.0358
16	.0187	.0029	.0061	.0029	.0057	.0057	.0057
17	.0183	.0029	.0061	.0029	.0057	.0057	.0057
18	.0029	.0029	.0029	.0069	.0057	.0029	
19	.0029	.0029	.0029	.0067	.0183	.0029	.0183
20	.0029	.0029	.0029	.0183	.0183	.0029	.0183
21	.0029	.0029	.0029	.0183	.0183	.0029	.0183
22	.0029	.0029	.0029	.0061	.0183	.0029	.0183
23	.0029	.0029	.0029	.0067	.0183	.0187	.0183
24	.0029	.0029	.0029	.0029	.0183	1.9605	.0029
Max	.0187	.0057	.0187	.0185	.0183	1.9605	.0358
Min	.0029	.0029	.0029	.0029	.0057	.0029	.0029
Avg	.0075	.0033	.0054	.0058	.0141	.0936	.0084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 207 / 11 KV KANSHIVANI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1273	1.1104	1.1283	.9795	1.4632	1.5546	1.4415
2	1.1458	1.1104	1.0924	.961	1.4632	1.531	1.386
3	.1743	1.0745	1.0745	.9425	1.4632	1.4784	1.3676
4	1.1273	1.0387	1.0745	.9055	1.4632	1.363	1.3491
5	1.1088	.9671	1.0745	.8686	1.4003	1.2936	1.3306
6	.9055	.9313	1.0566	.8131	1.3535	1.2136	1.3121
7	.9055	.8238	.9313	.7023		1.1763	1.1088
8	.9055	.8596	1.0029	.6838		.9896	1.2012
9	.9979	.9134	.985	1.2197	.4024	1.0164	1.2012
10	.961	.8316	.8417	1.2197	1.6095	.9335	1.2012
11	.695	1.1273	1.0974	1.2357	1.4327	1.2894	1.2178
12		1.1088	1.1888	1.2357		1.2894	1.2178
13	.3734	1.2012	1.2136			1.2894	1.2715
14	.6535	1.1827	1.134		1.4685	1.2536	1.2715
15	.7655	1.1643		.9313	1.4685	1.2894	1.2715
16		1.1827	1.0974		1.4685	1.3073	1.1999
17	1.2883		1.2136	.6984	1.4685	1.2894	1.1999
18	.9335	.5729	1.8111		1.1283	1.3676	
19	1.2357	.8501	1.4415	.7682	1.3717	1.7187	1.3717
20	1.2894	1.46	.9795	.9145	1.9387	1.7926	1.5912
21	1.2715	1.3676	1.1088	1.9022	1.7924	1.7372	1.7558
22	1.2715	1.4045	1.1088	1.829	1.7924	1.6632	1.6461
23	1.2178	1.2936	1.0534		1.6644	1.2012	1.5181
24	1.1458	1.1104	1.1641	.9492	1.6244	1.6095	1.46
Max	1.2894	1.46	1.8111	1.9022	1.9387	1.7926	1.7558
Min	.1743	.5729	.8417	.6838	.4024	.9335	1.1088
Avg	.9773	1.0733	1.1249	1.0400	1.4619	1.3603	1.3431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 208 / 11 kv BORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6057	1.3253	1.5893	1.4045	1.3169	1.3717	1.2567
2	1.3817	1.3253	1.5524	1.4784	1.3169	1.3717	1.3306
3	1.363	1.3253	1.5154	1.4045	1.3169	1.4003	1.1458
4	1.3443	1.3253	1.4784	1.2567	1.2803	1.2567	1.1458
5	1.3817	1.3253	1.4784	1.2936	1.2803	1.2437	1.1088
6	1.363	1.3253	1.4045	1.3306	1.1706	1.2696	1.0164
7	1.3443	1.2536	1.4784	1.1088	1.0608	1.2696	.924
8	1.0829		1.3306	1.0719	.9511	.961	.961
9	1.0829	1.1641	1.2197	1.0349	.8413	1.1088	.961
10	.9335	.8871	1.2567	1.2197	1.2071	1.4415	1.2567
11	1.0082	1.0349	1.4937	1.3253	1.2894	1.4685	1.2894
12	1.1203	.9979		1.3611	1.2894	1.4685	1.3611
13	1.1576	1.0719	1.4632	1.3611	1.2894	1.4327	1.2536
14		1.1827	1.4266	1.3611	.8954	1.3611	1.3432
15	1.307	1.2936	.2926	1.4685	1.2178	1.3611	1.4327
16	1.3443	1.2752	1.2437	1.3611	1.2536	1.1694	1.2536
17	1.307	1.2567	1.4998	1.1462	1.2894	1.1104	1.3611
18	1.0745	1.1827	1.1088	1.2803	1.3253	.9979	
19	1.2178	1.2567	1.1643	1.39	1.4266	.961	1.3169
20	1.3611	1.3676	1.3306	1.4266	1.2437	1.4045	1.3443
21	1.3969	1.3306	1.4784	1.4632	1.3169	1.3676	1.2437
22	1.3253	1.4784	1.5893	1.39	1.4632	1.2752	1.4998
23	1.2178	1.4937	1.4415	1.39	1.4998	1.3676	1.419
24	1.4563	1.3253	1.6817	1.4327	1.6095		1.4415
Max	1.6057	1.4937	1.6817	1.4784	1.6095	1.4685	1.4998
Min	.9335	.8871	.2926	1.0349	.8413	.961	.924
Avg	1.2686	1.2524	1.3703	1.3234	1.2563	1.2800	1.2464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 405 / 33 KV AMIBIKA SOLVEX NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2	.4527	.2886	.0572	.0274	.3292	.0343
2	.2	.4527	.2942	.0572	.028	.0329	.0343
3	.2115	.4527	.2942	.0572	.028	.0329	.0343
4	.2229	.4527	.3282	.0572	.028	.0329	.0286
5	.2115	.4527	.3338	.0572	.0274	.0219	.0229
6	.3086	.4583	.5319	.0572	.0168	.0165	.0229
7	.423	.481	.2716	.04	.0168	.0165	.0171
8	.4744	.481	.2546	.04	.0165	.0219	.0171
9	.4687	.4459	.2999	.04	.0219	.0224	.4287
10	.3086	.4744	.2659	.0283	.0219	.0165	.7716
11	.3977	.4744	.2745	.0566	.0226	.0226	.9393
12	.3977	.4858	.2857	.0566	.0226	.017	.9959
13	.4369	.4915	.1232	.0566	.0226	.017	1.1543
14	.4425	.4287	.1701	.0566	.0283	.017	1.1656
15	.4369	.4344	.1232	.0905	.0226	.017	1.177
16	.4313	.4344	.1232	.0566	.017	.0566	1.1175
17	.4537	.4801	.168	.0566	.017	.0453	1.1883
18	.4527	.3772	.0457	.0549	.017	.0229	
19	.4583	.3944	.0629	.0384	.0329	.0286	1.0974
20	.4527	.4001	.0629	.0274	.0329	.0286	1.0919
21	.4527	.4001	.0572	.0274	.0329	.0286	1.0979
22	.4583	.4115	.0572	.0329	.0329	.0286	.9108
23	.4583	.4744	.0629	.0384	.0329	3.4294	
24	.12	.4527	.2886	.0537	.028	.0329	.0343
Max	.4744	.4915	.5319	.0905	.0329	3.4294	1.1883
Min	.12	.3772	.0457	.0274	.0165	.0165	.0171
Avg	.3700	.4477	.2112	.0498	.0248	.1807	.6083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 409 / J.J.Fine Spun

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0468	.9676	.9402	.9877	.9767	1.046
2	.9316	1.0412	.9733	.9336	.9578	.9273	.9774
3	.9316	1.0412	.9846	.9846	.9438	.823	.9259
4	.9488	1.0355	.9902	.8827	.9858	.8121	.9202
5	.9659	1.0355	.9959	.8714	.9822	.823	.9545
6	.9488	1.0298	.9563	.8657	1.0474	.834	.9717
7	1.0345	1.126	.8997	.8374	.9186	.856	.8631
8	.9202	1.2449	.9393	.8318	.9018	.7846	.9431
9	1.2289	1.3524	.9563	1.2901	1.2565	1.0645	1.2003
10	.8573	1.1888	1.0185	1.2392	1.0316	.9986	1.3089
11	.9466	1.1888	1.0474	1.2845	1.2731	1.2675	1.3297
12	1.0474	1.2174	.9298	1.2845	1.2845	1.2845	1.3241
13	.8738	1.4118	1.053	1.182	1.2505	1.2731	1.2335
14	.9018	1.326	1.0923	1.1712	1.1883	1.2562	1.3863
15	1.1371	1.2974	1.025	1.3297	1.2335	1.3297	1.392
16	1.1707	1.3317	1.0362	1.1826	1.2505	1.3114	1.1713
17	1.2491	1.1374	1.1707	1.3637	1.2222	1.3297	1.4316
18	1.4033	1.1317	1.3317	1.1962	1.2788	1.4118	
19	1.2562	1.1488	1.1717	1.3224	1.5199	1.2917	1.3891
20	1.2562	1.2174	1.246	1.2323	1.251	1.2574	1.2181
21	.8657	1.0974	1.1431	1.0586	1.0754	1.2631	1.1468
22	.8657	1.1546	.8688	1.1707	1.0316	1.0345	1.1875
23	1.0185	1.0802	.9488	1.1483	.8999	1.0015	.9746
24	1.0974	1.0468	.9563	.9725	1.0425	1.0645	.9659
Max	1.4033	1.4118	1.3317	1.3637	1.5199	1.4118	1.4316
Min	.8573	1.0298	.8688	.8318	.8999	.7846	.8631
Avg	1.0398	1.1637	1.0293	1.1073	1.1173	1.0949	1.1418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 201 / 11 KV GHUSAR FDR .

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.543	.5175	.5228	.5788	.5601	.5175
2	.5228	.5249	.5175	.5228	.5788	.5415	.4805
3	.5228	.5068	.5175	.5228	.5601	.5415	.4805
4	.5228	.5068	.4805	.5228	.5601	.5228	.4805
5	.5228	.5068	.4435	.5041	.5415	.5228	.4805
6	.4481	.4344	.3696	.4481	.4668	.3658	.3696
7	.3174	.2896	.3142	.2987	.3921	.2743	.3326
8	.2614	.2743	.2957	.2614	.2427	.2743	.2957
9	.3036	.3258	.2987	.2801	.2926	.2926	.2241
10	.2926	.3326	.2801	.2987	.2926	.2957	.2801
11	.2926	.2957	.2801	.2987	.2926	.2772	.3174
12	.3109	.2957	.3174	.3547	.2896	.2587	.3547
13	.3658	.3326	.3547	.3734	.181	.2957	.3734
14	.3475	.3326	.3547	.3921	.3982	.2218	.3921
15	.3439	.3696	.3734	.4108	.3982	.3142	
16	.3475	.3696	.3734	.3921	.3982	.3142	
17	.2896	.3696	.3361	.3174	.3801	.3142	
18	.2715	.3326		.2987	.3077	.2772	
19	.4572	.4805	.4481	.4481	.4706	.4066	.4481
20	.439	.5544	.5601		.5304	.5914	.5788
21	.567	.5914	.5601	.5975	.6219	.5544	.5788
22	.5249	.5544	.5601	.5975	.6154	.5544	.5788
23	.543	.5544	.5788	.6161	.5487	.5544	.5601
24	.5415	.5487	.5544	.5601	.6161	.5487	.5175
Max	.567	.5914	.5788	.6161	.6219	.5914	.5788
Min	.2614	.2743	.2801	.2614	.181	.2218	.2241
Avg	.4116	.4261	.4211	.4278	.4398	.4031	.4321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 202 / 11 KV MHAISANG FDR .

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5304	.5487	.5487	.5975	.6161	.5853
2	.5487	.5304	.5487	.5487	.5975	.5975	.5487
3	.5487	.5304	.5121	.5487	.5788	.5975	.5121
4	.5487	.5304	.5121	.5487	.5788	.5975	.5121
5	.5121	.5304	.4755	.5304	.5788	.5788	.5121
6	.4938	.5304	.439	.4755	.5041	.4572	.4755
7	.3658	.4207	.439	.3658		.4207	.4024
8	.3475	.3658	.3982	.4024	.4294	.4207	.4024
9	.3475	.4024	.4024	.3921	.4668	.3658	.4294
10	.3475	.4024	.4024	.3734	.4755	.3982	.4668
11	.3475	.4024	.4024	.3547	.4755	.362	.4668
12	.3658	.4024	.3841	.4668		.3658	.4668
13		.3982	.3841	.4668		.3658	.4668
14	.4755	.3982	.3841	.4668	.4572	.3658	.4854
15	.4207	.4706	.4572	.4668	.5249		
16	.4207	.4706	.5121	.4668	.5304	.4024	
17	.4024	.4344	.5121	.4294	.439	.3982	
18	.3982	.4344		.3921	.4207	.439	
19	.5853	.5068		.6161	.6036	.543	.5415
20	.6584	.6516	.4207		.6219	.6878	.5975
21	.6401	.6878	.6219	.7655		.6878	.6535
22	.6401	.6516	.6219	.7095	.6219	.695	.6348
23	.4938	.6219	.6036	.6908	.6219	.6516	.6161
24	.5487	.4938	.5853	.567	.6161	.6219	.6154
Max	.6584	.6878	.6219	.7655	.6219	.695	.6535
Min	.3475	.3658	.3841	.3547	.4207	.362	.4024
Avg	.4785	.4916	.4803	.5041	.5370	.5059	.5196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 203 / 11 KV Ghusar W/W Express. NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.0316	.0791	.0819	.0316	.0316	.0158
2	.0819	.0316	.0791	.0819	.0316	.0316	
3	.0819	.0316	.0158	.0819	.0316	.0316	
4	.0819	.0316	.0158	.0819	.0316	.0316	
5	.0819	.0316	.0791	.0819	.0316	.0316	
6	.0819	.0316	.0791	.0819	.0316	.0316	
7	.0819	.0791	.0791	.0819	.0316	.0316	
8	.0791	.0791	.0791	.0819	.0316	.0316	
9	.0791	.0791	.0819	.0791	.0316	.0316	.0158
10	.0316	.0791	.0819	.0316	.0316	.0158	.0158
11	.0316	.0791	.0819	.0791	.0316	.0158	.0158
12	.0316	.0158	.0819	.0373	.0316	.0158	.0158
13		.0791	.0655	.0316	.0316	.0158	.0158
14	.0316	.0924	.0655	.0373	.0316	.0158	.0164
15	.0316	.0554	.0819	.0373	.0316	.0158	.0158
16	.0316	.0474	.0819	.0316	.0316	.0158	.0158
17	.0316	.0791	.0164	.0316	.0316	.0158	.0158
18	.0316	.0924	.0819	.0316	.0316	.0158	.0158
19	.0633	.0474	.0164	.0316	.0316	.0158	.0158
20	.0633	.0554	.0655	.0316	.5376	.0158	.0158
21	.0633	.0158	.0819	.0316	.0316	.0158	.0158
22	.0316	.0158	.0819	.0316	.0316	.0158	.0158
23	.0316	.0791	.0492	.0316	.0316	.0158	.0158
24	.0819	.0316	.0791	.0819	.0316	.0316	.0158
Max	.0819	.0924	.0819	.0819	.5376	.0316	.0164
Min	.0316	.0158	.0158	.0316	.0316	.0158	.0158
Avg	.0574	.0538	.0667	.0551	.0527	.0224	.0158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 204 / 11 KV Jaiguru Express.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	16-APR-17	17-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0934			.0934
2		.0934			.0934
3		.0934			.0934
4		.0189			.0189
5		.0189			.0189
6		.0189			.0189
7		.0189			.0189
8		.0189			.0189
9		.0934			.1698
10		.0934		.0934	.1509
11		.0934		.1307	.1698
12	.0934	.0934		.1307	.1698
13		.0747		.168	.1509
14		.0934		.1494	.1509
15		.0934		.1494	.1509
16		.0934		.1494	.1509
17		.0934		.1494	.1509
18		.0187		.056	.0566
19		.0187		.0189	.0566
20		.056		.0934	.1646
21		.0943		.0934	.2075
22	.0934	.0943		.0924	.1509
23	.0934	.0943		.0934	.1509
24		.0934	.0566		.0934
Max	.0934	.0943	.0566	.168	.2075
Min	.0934	.0187	.0566	.0189	.0189
Avg	.0934	.0694	.0566	.1120	.1113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 201 / 11 KV HINGNA FEED
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.8383		.8002		.7049	.5487
2	.6516	.8383	.7621	.8002	.6859	.6478	.5487
3	.6516	.8002	.6097	.7621	.6859	.6287	.5487
4	.6516	.8002	.6668	.7621	.6859	.6287	.5487
5	.6859	.8002	.724	.724	.6859	.6478	.5487
6	.7888	.8764	.7621	.7621	.6859	.743	.6516
7	.7545	.8383	.8002	.8002	.7545	.7811	.6516
8	.7545	.8383	.0191	.8383	.6173	.7811	.6344
9		.8764	.743	.8383	.6859	.8383	.6859
10	.9717	.8779		.8002	.9907	.9431	.9145
11	1.0669	.9694	.6516	.9717	1.0288	.9431	.9526
12	1.0669		.6516	.9526	.9907	.5144	.8573
13	.8954	.8192	.6859	.9335	.8002	.823	.9145
14	.9717	.8779	.7888	.9526	.8764	.8916	.724
15	.9717	.8413	.7202	1.0098		.7888	.8002
16	.9526	.8048	.823	1.0098	.9907	.9602	.743
17	.9145	.743	.8383	.8573	1.0479	.9945	.8764
18	.9526	.7049	.7621		.9335	.823	.8192
19	1.0479	.724	.9526	1.0117	1.0098	.9431	1.0098
20	1.105	.9145	.9526		.743	.9259	.9717
21	.9907	.8573	.8383	.823	.8192	.7545	.9526
22	.8764	.6668	.8573	.7888	.0191	.6859	.9526
23	.8573	.8383	.8383	.7545	.8002	.6516	.7811
24	.6859	.8383	.8383	.8002	.703	.7049	.6001
Max	1.105	.9694	.9526	1.0117	1.0479	.9945	1.0098
Min	.6516	.6668	.0191	.724	.0191	.5144	.5487
Avg	.8660	.8254	.7403	.8524	.7837	.7812	.7599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 203 / 11 KV RUHATIYA EXP.

FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0191		.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191		.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9		.0191		.0191	.0191	.0191	.0191
10	.0191	.0183		.0191	.0191	.0191	.0191
11	.0191	.0191	.0191	.0191	.0191	.0191	.0191
12	.0191		.0191	.0191	.0191		.0191
13	.0191	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0183	.0191	.0191	.0191	.0191	.0191
15	.0191	.0183	.0191	.0191	.0191	.0191	.0191
16	.0191	.0183	.0191	.0191	.0191	.0191	.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191		.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0171	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191		.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0171	.0183	.0191	.0171	.0191	.0191	.0191
Avg	.0190	.0190	.0191	.0190	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 204 / 11 KV HINGANA-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.381	.2058	.4382	
2			.4001	.381	.2058		
3			.4001	.4191	.2058		
4			.381	.4191	.2572	.0191	
5			.4382	.4572	.3772		
6			.4572	.4954	.4287		
7			.5906	.5335	.5144		
8			.5525	.6097	.2572		
9			.5144	.6668	.2058		
10	.0191	.5121				.2572	.1905
11	.7049	.6401				.6001	.5716
12	.6287					.0191	.724
13	.5716	.6097				.1715	.5716
14		.5853				.1715	.5335
15		.5487				.0191	
16		.567				.0191	
17						.0191	.6478
24			.4001	.381	.1715		
Max	.7049	.6401	.5906	.6668	.5144	.6001	.724
Min	.0191	.5121	.381	.381	.1715	.0191	.1905
Avg	.4811	.5772	.4594	.4744	.2829	.1734	.5398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 207 / 11 K GAJANAN MAHARAJ
GINNING Feeder KV- 11 /
INCOMINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0191		.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0171	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9		.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0183	.0191	.0191	.0191	.0191	.0191
11	.0191	.0183	.0191	.0191	.0191	.0191	.0191
12	.0191		.0191	.0191	.0191	.0191	.0191
13	.0191	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0183	.0191	.0191	.0191	.0191	.0191
15	.0191	.0183	.0191	.0191	.0191	.0191	.0191
16	.0191	.0183	.0191	.0191	.0191	.0191	.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191		.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0171	.0183	.0191	.0191	.0191	.0191	.0191
Avg	.0189	.0189	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 203 / 11 KV RUHATIYA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4504	.5159	.4523	.5148	.4649	.4496	.4611
2	.4706	.5228	.4603	.5159	.4271	.463	.4542
3	.4755	.503	.4412	.4572	.423	.4748	.4351
4	.4843	.5228	.4572	.4893	.434	.471	.4351
5	.479	.5041	.4496	.4851	.4329	.4725	.4416
6	.487	.5331	.4431	.4546	.4317	.471	.458
7	.4858	.5373	.4729	.4477	.4294	.4675	.4371
8	.4702	.4946	.458	.4538	.442	.4534	.4683
9	.4614	.45	.4908	.4508	.4862	.4527	.4679
10	.4744	.4508	.487	.4588	.519	.4592	.4542
11	.4824	.4534	.4793	.4675	.5095	.4565	.4531
12	.4961	.4504	.5441	.471	.5125	.5418	.4546
13	.5418	.4466	.5963	.5075	.4934	.5228	.4572
14	.5529	.4496	.5944	.5361	.5148	.53	.4569
15	.5335	.4538	.5971	.5323	.5091	.5483	.4668
16	.5251	.45	.5959	.5434	.519	.5369	.4733
17	.5361	.4603	.6032	.5449	.5102	.5373	.5144
18	.5373	.4607	.6253	.5392	.5361	.5529	.5144
19	.5388	.5014	.5929	.5483	.5544	.551	.5049
20	.5487	.4691	.5224	.474	.4717	.4691	.4592
21	.5578	.4622	.5235	.4752	.4668	.4519	.4763
22	.5392	.4572	.5133	.4672	.4607	.45	.4656
23	.5369	.4847	.5255	.4721	.4458	.4443	.458
24	.5335	.4694	.527	.4565	.4641	.4523	.4458
Max	.5578	.5373	.6253	.5483	.5544	.5529	.5144
Min	.4504	.4466	.4412	.4477	.423	.4443	.4351
Avg	.5083	.4793	.5189	.4901	.4774	.4867	.4630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 204 / 11 kv shivapur feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.157	.1578	.1562	.1532	.1501	.1478
2	.1471	.1547	.1547	.1555	.1517	.1494	.1456
3	.1456	.1532	.1494	.1547	.1501	.1486	.1448
4	.1509	.1585	.1494	.1532	.1501	.1478	.1425
5	.1486	.157	.1547	.1593	.1547	.1539	.1486
6	.1463	.1578	.1524	.1539	.1539	.1524	.1463
7	.1395	.1616	.1593	.1471	.1456	.1463	.1532
8	.1402	.1783	.1547	.1814	.1646	.2088	.1859
9	.1501	.2042	.1974	.1684	.2279	.2126	.2103
10	.1898	.2698	.1799	.202	.2042	.1974	.1776
11	.1966	.2263	.2317	.2553	.1684	.2317	.1806
12	.2332	.2385	.1768	.2522	.205	.2332	.176
13	.1646	.1296	.1219	.1593	.1212	.1341	.1334
14	.1913	.1585	.1989	.2576	.2256	.1684	.1699
15	.176	.2393	.1097	.1905	.2263	.205	.1943
16	.192	.2484	.1875	.2187	.2149	.2027	.2134
17	.189	.2431		.1844	.2088	.2294	.2401
18	.2157	.1562	.2926	.2416	.2294	.2004	.2614
19	.1646	.1517	.1882	.1913	.1417	.1578	.2263
20	.1623	.16	.1631	.0206	.1379	.1585	.1821
21	.1578	.1616	.1654	.1562	.1494	.16	.1738
22	.1524	.16	.1707	.1699	.1578	.1539	.1661
23	.1707	.1684	.1722	.1738	.1646	.1509	.157
24	.173	.1692	.1684	.1646	.1608	.1585	.1494
Max	.2332	.2698	.2926	.2576	.2294	.2332	.2614
Min	.1395	.1296	.1097	.0206	.1212	.1341	.1334
Avg	.1685	.1818	.1720	.1778	.1737	.1755	.1761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 205 / 11 KV Chandur Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0831	.0815	.237	.2492	.2301	.2027	.0655
2	.0831	.0808	.2393	.2515	.253	.2164	.0693
3	.0838	.0838	.2439	.2683	.2637	.2218	.0808
4		.0815	.2484	.2736	.2698	.2378	.0953
5	.0122	.0945	.3376	.3445	.346	.3391	.0777
6	.013	.0122	.5098	.538	.5091	.5121	.0251
7	.0008		.5357	.7011	.615	.5799	.0183
8		.0343	.6295	.7423	.6622	.5898	.0556
9	.49	.6546	.1867	.2606		.1783	.5396
10	.6874	.7468		.109		.0602	.5891
11	.8322	.7042		.0861	.0008	.1959	.5883
12	.7865	.612		.1097	.0267	.1417	.5197
13	.724	.5807		.1021	.0442	.0366	.6165
14	.7362	.5716		.0709	.032		.5685
15	.6828	.583		.1075	.0914		.66
16	.7186	.6965		.1372	.1006		.6897
17	.2964	.2469		.1372	.0511	.0107	.3315
18	.1021	.0831	.1029	.1097	.1006	.1623	.1966
19	.1029	.0907	.0983	.1143	.1029	.2012	.1943
20	.0975	.096	.1029	.1158	.1036	.1387	.1951
21	.0907	.1036	.1029	.1242	.0793	.1044	.1875
22	.0922	.0975	.0861	.1196	.0785	.0892	.1768
23	.0869	.2332	.2309	.2332	.2134	.0846	.1646
24	.0815	.2385	.2477	.237	.2149	.0793	.1646
Max	.8322	.7468	.6295	.7423	.6622	.5898	.6897
Min	.0008	.0122	.0861	.0709	.0008	.0107	.0183
Avg	.3129	.2960	.2587	.2309	.1995	.2087	.2863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 206 / 11 KV GADGEBABA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.1936	.1768	.1288	.173	.1768	.1791
2	.1905	.1814	.1799	.1303	.1753	.1829	.1821
3	.1829	.1821	.1783	.1311	.1768	.1783	.1768
4	.1844	.1882	.1753	.1311	.1745	.1745	.1814
5	.1852	.1882	.176	.1318	.173	.1799	.1814
6	.1882	.1844	.1722	.1334	.1776	.1791	.1799
7	.1882	.173	.176	.1357	.1745	.1799	.1753
8	.1875	.1829	.1814	.1364	.1776	.1852	.1875
9	.1898	.2035	.1821	.1372	.1867	.202	.1852
10	.2515	.2401	.205	.1341	.2088	.2484	.1989
11	.2622	.1844	.2149	.1357	.2187	.2522	.2012
12	.2172	.1875	.2149	.1341	.2538	.2477	.2538
13	.2119	.2355	.2233	.1334	.237	.2431	.2827
14	.2378	.25	.2187	.1326	.237	.2378	.2561
15	.234	.2408	.2157	.1318	.2309	.2477	.2667
16	.2591	.2355	.128	.1318	.2202	.2347	.2408
17	.2225	.2103	.1357	.1951	.2233	.2111	.2362
18	.1905	.176	.1357	.192	.2088	.1829	.2454
19	.1905	.1738	.1364	.1898	.1768	.1768	.1837
20	.1898	.1768	.1349	.1791	.1753	.176	.176
21	.1867	.1738	.1341	.1753	.173	.1753	.1783
22	.1821	.1738	.1334	.1745	.1692	.1753	.1776
23	.1859	.1738	.1326	.1768	.1722	.1753	.1745
24	.1882	.1745	.1318	.1715	.1722	.173	.1692
Max	.2622	.25	.2233	.1951	.2538	.2522	.2827
Min	.1821	.173	.128	.1288	.1692	.173	.1692
Avg	.2038	.1952	.1705	.1493	.1944	.1998	.2029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 201 / 11 kv Sangvi Mohadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8869	.8779	.8326		.8413	.7602
2	.8048	.8869	.8688	.8145	.8596	.8048	.7421
3	.7865	.8507	.8413	.7964	.8962	.7499	.7164
4	.7682	.8596	.823	.7783	.8779	.7316	.724
5	.7499	.8413	.8048	.7602	.8596	.7133	.6984
6	.7682	.8145	.7602	.7602	.8048	.7499	.6878
7	.7682	.724	.7499	.7602	.8048	.7316	.6335
8	.7499	.7964	.7133	.7602	.7682	.7059	.6154
9	.8413	.9145	.7421	.7602	.7499	.7602	.6878
10	.7964	.8779	.7602		.7701	.7602	.6584
11	.8326	.8596	.8326	.7059	.7602	.6516	.6584
12	.7964	.823	.8507	.8145	.5194	.6516	.695
13	.905	.8962	.8688	.8507	.5249	.5792	.695
14	.8688	.8413	.9328	.8869		.5792	.6584
15	.7964	.7316	.8048	.8326	.6805		.695
16	.7964	.6584	.7602	.7865	.695	.3658	.695
17	.8507	.7059	.7964	.8048	.8048	.3801	.439
18	.9231	.7783	.8688	.823	.7499	.6219	.8413
19	1.0317	.9955	1.0498	1.0791		.8779	1.0608
20	1.0679	.9774	.905	1.1157	1.0059	.9328	1.0974
21	1.0208	.9774	.9412	1.0425	1.1157	.9231	1.0974
22	1.0136	.9593	.905	.9877	1.0425	.9145	1.0608
23	.9774	.9145	.8596	.9328	.9511		.9511
24	.8413	.905	.8869	.8326	.8596	.8779	.7783
Max	1.0679	.9955	1.0498	1.1157	1.1157	.9328	1.0974
Min	.7499	.6584	.7133	.7059	.5194	.3658	.439
Avg	.8574	.8532	.8418	.8486	.8143	.7229	.7645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 202 / 11 kv Ugwa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6697	.7421	.724	.7522	.7421	.7421	.7164
2	.6154	.7059	.724	.7343	.724	.6878	.6984
3	.5611	.7133	.7133	.7164	.7059	.6335	.6805
4	.5068	.695	.695	.6984	.6878	.5792	.6626
5	.4887	.6878	.6697	.6984	.6878	.543	.6447
6	.4706	.6154	.6335	.6268	.6335	.5249	.5552
7	.4525	.5068	.4887	.5552	.5068	.5249	.4835
8	.4706	.4887	.4755	.4656	.4706		.4656
9	.4706	.4706	.4344	.4706	.4525	.4835	.394
10	.4477	.4706	.4525	.5249	.4835	.5194	.4344
11	.4656	.4344	.4938	.5249	.5792	.5014	.5068
12	.4835	.4163	.5304	.567	.5973		.5611
13	.5552	.5249	.567	.5973	.6335	.4298	.5792
14	.5552	.5973		.6516	.6154	.591	.6154
15	.5552	.5792		.6335	.5792	.591	.6516
16	.5194	.5792	.4835	.6154	.6036	.567	.5792
17	.4706	.5792	.5731	.6335		.5853	.543
18	.4887	.5611	.5373	.6516		.567	.5249
19	.6697	.7783	.6447	.7421	.8688	.6767	.7059
20	.7421	.8145	.7343		.8145	.8048	.7964
21	.7522	.7964	.8059	.8326	.7964	.823	.8326
22	.8326	.7964	.8238	.8145	.8145	.8048	.8688
23	.8326	.7682	.8238	.7964	.7783	.7865	.8326
24	.724	.7602	.7421	.7522	.7783	.7964	.7522
Max	.8326	.8145	.8238	.8326	.8688	.823	.8688
Min	.4477	.4163	.4344	.4656	.4525	.4298	.394
Avg	.5750	.6284	.6259	.6546	.6615	.6256	.6285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 203 / 11 kv Gandhigram

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4656	.4525	.4887	.5014	.5014	.5014	.4835
2	.4119	.4755	.4706	.4835	.4835	.4656	.4835
3	.3761	.4572	.4572	.4656	.4656	.4298	.4656
4	.3224	.4572	.4525	.4477	.4477	.3582	.4477
5	.2507	.4525	.4344	.4298	.4477	.3403	.4298
6	.2686	.3982	.4024	.3761	.4119	.3224	.3045
7	.2686	.2896	.3077	.3045		.3224	.2865
8	.3045	.2715	.2896	.3045	.394		.2865
9	.3045	.3045	.2896	.362	.3582	.3224	.3403
10	.2865	.2865	.2715	.362	.362	.3045	.3045
11	.2865	.3403	.2561	.3982	.3439	.3761	.3582
12	.3224	.3224	.2926	.3841	.4163	.3582	.394
13	.3403	.394	.3475	.4344		.3761	.394
14	.394	.4119	.3841	.4024	.4344	.3582	.3582
15	.394	.4298	.4024	.3801	.4163	.3582	.3582
16	.3403	.394	.394	.4119	.4119	.3109	.3403
17	.3292	.3801	.3761	.4119	.4119	.3292	.3403
18	.3077	.3658	.4298	.394	.394	.3475	.3403
19	.4706	.5068	.5552	.591	.4298	.4938	.4835
20	.5068	.5792	.6089		.394	.5487	.5373
21	.5014	.567	.591	.6268	.5373	.567	.5014
22	.5068	.543	.5552	.591	.5373	.5249	.5194
23	.5068	.5304	.5194	.5373	.5373	.5304	.5014
24	.4835	.4525	.5068	.5014	.5194	.5373	.5014
Max	.5068	.5792	.6089	.6268	.5373	.567	.5373
Min	.2507	.2715	.2561	.3045	.3439	.3045	.2865
Avg	.3729	.4193	.4201	.4392	.4389	.4080	.4067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 201 / 11 kv sarawa gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2858	.2858	.2667	.2229	.2401
2	.2858	.2667	.2858	.2858	.2667	.2229	.2401
3	.2858	.2667	.2858	.2858	.2667	.2229	.2401
4	.3048	.2667	.3048	.2858	.2667	.2229	.2401
5	.3048	.3048	.3239	.3048	.3048	.2401	.2401
6	.3048	.3048	.3239	.2667	.3429	.2915	.3429
7	.381	.2667	.2096	.2858		.2229	.3601
8	.4191	.2667	.1905	.2477	.3239	.2915	.3601
9	.4382	.2858	.2477	.3239	.2858	.3772	.4115
10	.4001	.5335	.2286	.3841	.4287	.5335	.5906
11	.4763	.4763	.1905	.5335	.3601	.4382	.4382
12	.381	.5525	.1905	.5611		.381	.5335
13	.362	.4954	.2096	.5525		.3048	.5144
14	.3239	.4572	.2286	.4382	.5487	.3048	.4763
15	.3239	.381	.2477	.4435	.4801	.2477	.4572
16	.381	.5144	.2667	.4251	.4287	.5525	.4763
17	.4382	.381	.2858	.5729	.5525	.4382	.4763
18	.4191	.4001	.2477	.2896	.4115	.3239	.4954
19	.3048	.3429	.2667	.2896	.3086	.362	.3048
20	.3429	.3429	.3239		.2058	.3048	.3048
21	.3048	.3429	.3048	.3048		.2572	.2858
22	.3048	.3239	.3048	.3048		.2572	.2858
23	.3048	.3239	.2858	.2858	.2401	.2401	.2667
24	.3048	.2858	.2858	.2858	.2667	.2401	.2401
Max	.4763	.5525	.3239	.5729	.5525	.5525	.5906
Min	.2858	.2667	.1905	.2477	.2058	.2229	.2401
Avg	.3493	.3612	.2636	.3584	.3450	.3125	.3676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 202 / 11 kv eranda gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2667	.2667	.2858	.2229	.7716
2	.2667	.2858	.2667	.2667	.2858	.2229	.7545
3	.2667	.2667	.2667	.2667	.2858	.2229	.7545
4	.2667	.2667	.2667	.2667	.2858	.2229	.7545
5	.2858	.2858	.2858	.2858	.3048	.2401	.7716
6	.2858	.2667	.3048	.3048	.2858	.2743	.9259
7	.2477	.2477	.2667	.2858	.2858	.2572	1.1279
8	.2286	.2286	.2477	.2477	.2858	.2401	1.3375
9	.2667	.2096	.2096	.2858	.2477	.2058	1.1488
10	.1905	.2667	.2096	.2477	.2096	.2667	.2477
11	.2096	.2667	.1905	.3429	.2572	.2667	.2477
12	.1905	.1715	.1905	.2286	.3086	.3048	.362
13	.1905	.2286	.1905	.2667	.2743	.2477	.2286
14	.1905	.2667	.2286	.3048	.2229	.2858	.2858
15	.2096	.2477	.2286	.2858	.2229	.2477	.3048
16	.2286	.2477	.2667	.2667	.1886	.2477	.2858
17	.2096	.1905	.1905	.1905	.2058	.2286	.2667
18	.2096	.1905	.1905	.2667	.1715	1.5623	.2286
19	.3239	.3239	.3048	.381	.2743	1.467	.2858
20	.362	.362	.3429		.3086	1.2193	.2858
21	.3239	.3239	.3048	.2858	.2915	.9602	.3048
22	.3048	.3239	.2858	.3239	.2572	.9088	.3048
23	.3048	.3048	.2667	.3048	.2401	.8573	.3048
24	.2858	.2858	.2667	.2858	.2858	.2401	.8573
Max	.362	.362	.3429	.381	.3086	1.5623	1.3375
Min	.1905	.1715	.1905	.1905	.1715	.2058	.2286
Avg	.2556	.2643	.2516	.2808	.2613	.4758	.5478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 203 / 11 kv katkeda ag
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.8954	.6668	.7049	.724	.6001	
2	.743	.8764	.6478	.7049	.724	.6097	
3	.724	.8764	.6478	.7049	.743	.5487	
4	.743	.8764					
5	.8002	.9526					
6	.8192	1.0669					
7	1.2765	1.3717					
8	1.467	1.5051					
9	1.2193	1.3527					
10			1.448	.933	1.3336	1.5051	
11			1.4098	1.0479	1.286	1.5813	
12			1.3717	1.2651		1.3717	
13			1.1812	1.086		1.1431	
14			1.0669	.9717	.8573	.9335	
15			1.0669	.8488	.5487	.8192	
16	1.2003	1.086	1.0669	1.0185	.5487	1.0098	.9907
17	1.5242	1.3336	.8573	1.0957	.6859		1.3527
18	1.6004	1.6194	1.4289	1.0364	1.286		1.1812
19	1.2955	1.2955	1.0288	.8535	1.1488		.5525
20	1.105	.8192	.9335	.9526	.9259		.5716
21	.9907	.7811	.8764	.8954			.724
22	.9907	.7621	.8954	.8573			.8192
23	.9335	.724	.9145	.8192	.6687		.7621
24	.7811	.8954	.6859	.8002	.724	.6344	
Max	1.6004	1.6194	1.448	1.2651	1.3336	1.5813	1.3527
Min	.724	.724	.6478	.7049	.5487	.5487	.5525
Avg	1.0531	1.0606	1.0108	.922	.8718	.9779	.8693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 203 / AKOT ROAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7514	.7567	.7057	.7468	.7727	.7362	.8383
2	.7278	.7308	.7034	.7263	.7514	.6866	.7827
3	.7225	.7278	.6943	.7194	.7377	.6737	.7819
4	.7087	.7194	.7278	.7095	.7392	.7034	.7667
5	.7019	.7156	.7308	.7057	.727	.6973	.7606
6	.6988	.7217	.7369	.7148	.7225	.7087	.7392
7	.6714	.6714	.6828	.6379	.0251	.6272	.6485
8	.551	.57	.5838	.5685	.7057	.5998	.6104
9	.5822	.6424	.5472	.5624	.6836	.6104	.5693
10	.5723	.647	.5731	.5838	.6729	.5754	.6417
11	.5906	.3871	.551	.6127	.6653	.6325	.6257
12	.6348	.0076	.5357	.6409	.6706	.663	.6142
13	.6699	.6302	.5738	.6859		.6516	.5838
14	.6783	.6699	.6051	.6699	.7575	.4016	.33
15	.7179	.5632	.5822	.4009	.7415	.5746	.349
16	.7186	.6584	.4428	.6828	.7476	.5716	.6325
17	.6897	.3902	.5563	.6653	.7194	.5578	.644
18		.7232	.5967	.6546	.6699	.551	.5853
19		.7857	.7705	.7926	.8139	.7659	.74
20	.5929	.8314	.8596	.3086	.881	.8772	.7781
21	.8878	.8078	.833	.8718	.2881	.8619	.772
22	.8482	.8436	.8093	.9122	.8825	.8543	.8688
23	.8581	.7941	.8086	.836	.8528	.8543	.8482
24	.8269	.7621	.7834	.8048	.7827	.8589	.8109
Max	.8878	.8436	.8596	.9122	.8825	.8772	.8688
Min	.551	.0076	.4428	.3086	.0251	.4016	.33
Avg	.7001	.6566	.6664	.6756	.6961	.6790	.6801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 201 / 11 KV BALAPUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3385	4.6564	4.8286	2.5149	4.8434	5.0183	3.2922
2	4.3011	4.5061	4.8286	2.5149	4.6933	4.7726	3.2617
3	4.1876	4.5061	4.6029	2.4387	4.617	4.6792	3.2275
4	4.0741	4.393	4.4894	2.3624	4.5801	4.5096	2.9625
5	4.0367	4.3168	4.4894	2.3624	4.5431	4.4162	2.9797
6	3.8409	4.2798	4.5096	2.3624	4.5656	4.4162	2.4387
7	3.9247	4.132	4.3773	2.21	4.2265	4.34	2.2862
8	3.6588	3.8294	3.8127	1.9814	3.8485	1.9814	2.1338
9	3.4705	3.7555	3.5841	1.9052	3.735	3.7723	2.1338
10	3.4332	3.7163	1.829	1.9814	3.7723	1.9052	2.0576
11	1.829	1.9052	3.735	2.0576	1.9814	3.6976	2.1338
12	2.0576	1.9814	3.5856	2.0576	2.0576	3.8112	4.3385
13	2.21	1.9814	3.959	4.3842	2.0576	4.1114	4.3773
14	2.2862	2.1338	4.3385	4.3842	2.1338	4.3758	4.2249
15	2.2862	2.1338	4.5282	2.3624	2.21	4.4147	4.4147
16	4.4299	2.21	4.6029	2.4387	2.2862	4.4147	4.452
17	4.4299	4.2265	2.1338	4.4974	2.21	2.21	4.4132
18	4.2428	4.0741	2.0576	4.5267	4.1503	2.1338	4.4505
19	4.9913	4.7554	2.2862	4.9048	4.8286	2.3624	4.6029
20	5.2568	5.3201	2.5911	5.2828	4.9048	2.5911	4.981
21	5.1806	5.2066	2.5911	5.3574	4.6372	2.5149	5.0183
22	5.1437	5.2454	2.6673	5.4321	5.2641	2.6673	5.0572
23	5.1067	5.2081	2.7435	5.4336	5.3574	2.7435	5.0572
24	4.7569	4.9196	5.0572	2.6673	5.2066	2.6673	2.5911
Max	5.2568	5.3201	5.0572	5.4336	5.3574	5.0183	5.0572
Min	1.829	1.9052	1.829	1.9052	1.9814	1.9052	2.0576
Avg	3.8947	3.8914	3.6762	3.2675	3.8629	3.5219	3.6203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 202 / 11 KV PARAS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2079	1.4601					.6211
2	1.1949	1.4502					.6295
3	1.2528	1.4396					.6295
4	1.2582	1.4342					.618
5	1.1553	1.4045					.618
6	1.1691	1.4098					.6142
7	1.5401	1.5615					.6379
8	1.7078	1.7886					.7552
9	1.8084	1.8427					.8703
10	.8787	.9564	.1608	.0815	.9557	.1135	.791
11			1.7322	1.2864	1.1256	1.8534	
12			1.611	1.0006	1.0875	1.9776	
13			1.5021	2.0157	.2263	1.8312	
14			1.5653	1.6369	.1684	1.4175	
15			1.5226	.8391		1.3923	
16			1.3755	.8657	.7583	1.3839	
17			.8993	1.7353	.8901	.804	
18			.9076	.9625		.6325	
24	.6935	.6249				.0107	.0854
Max	1.8084	1.8427	1.7322	2.0157	1.1256	1.9776	.8703
Min	.6935	.6249	.1608	.0815	.1684	.0107	.0854
Avg	1.2606	1.3975	1.2529	1.1582	.7446	1.1417	.6246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 203 / 11 KV VYALA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9404	1.1149	1.1065	1.1248	1.0456	1.134	1.0951
2	.8741	1.0669	1.0639	1.0921	1.0029	1.1043	1.0722
3	.8672	1.041	1.038	1.0669	.9846	1.0753	1.0387
4	.8269	.9976	1.0189	1.0395	.9534	1.0509	1.0143
5	.804	1.0006	1.0189	1.0151	.9511	1.0113	1.0006
6	.8055	.9717	.9938	1.0174	.9313	.9915	.9755
7	.788	.9617	.8833	1.0151	.9031	.9793	.9015
8	.6622	.7903	.7872	.8909	.7194	.8002	.6622
9	.5502	.6859	.6196	.6783	.6424	.6562	.5876
10	.6272	.6897	.647	.6478	.5418	.6051	.5441
11	.6569	.6645	.66	.6783	.5571	.5952	.5708
12	.6661	.6767	.6394	.6912	.5914	.6257	.5708
13	.7293	.7377	.6813	.7407	.615	.6523	.5891
14	.756	.7918	.7766	.8086	.6859	.7194	.6081
15	.7933	.8612	.8215	.8505	.7529	.7514	.7552
16	.8093	.8855	.8436	.8764	.756	.7697	.7743
17	.7987	.8573	.8284	.8627	.7377	.7827	.7583
18	.772	.8017	.7735	.8078	.7133	.7095	.7598
19	.7865	.7918	.7415	.8063	.6851	.6996	.6988
20	.9732	.9991	.9816	.9831	.9168	.9092	.8993
21	1.086	1.0471	1.0898	1.0166	1.0357	1.012	.7895
22	1.1096	1.1126	1.1485	1.041	1.1218	1.1058	.9808
23	1.1347	1.1507	1.1622	1.0776	1.1782	1.1538	1.044
24	1.1416	1.1561	1.1485	1.0814	1.1584	1.1149	1.0707
Max	1.1416	1.1561	1.1622	1.1248	1.1782	1.1538	1.0951
Min	.5502	.6645	.6196	.6478	.5418	.5952	.5441
Avg	.8316	.9106	.8947	.9129	.8409	.8754	.8234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 204 / 11 KV PALASI GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2075	.2075		.1886	.2452	
2	.2241	.1886	.2012		.1886	.2452	
3	.1867	.1886	.2075		.1886	.2263	
4	.1867	.1886	.2075		.1698	.2263	
5	.1867	.1886	.2075		.1886	.2075	
6	.1867	.2075	.2075		.2075	.2075	
7	.1867	.2075	.2075		.2263	.1886	
8	.1867	.2263	.2075		.2075	.1886	
9	.1867	.2263	.2075		.1886		
10	.1867	.168			.1867		
11			.1886			.1867	
12			.1886			.2241	.1663
13			.1886	.2033		.2241	.1663
14			.1886	.2033			.1663
15			.1867				.1867
16	.1886		.1867				.1867
17	.1509	.1698		.181			.1867
18	.168	.1886		.1086	.1698		.1867
19	.2427	.2263		.1629	.3206		.2241
20	.3174	.2641		.2353	.2818		.2241
21	.2801			.2353	.3018		.2614
22	.2427			.2263	.2829		.2241
23	.2054	.2263		.2263	.2641		.2241
24	.2241	.2075	.2075		.2452		
Max	.3174	.2641	.2075	.2353	.3206	.2452	.2614
Min	.1509	.168	.1867	.1086	.1698	.1867	.1663
Avg	.2085	.2050	.1998	.1980	.2239	.2155	.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 206 / 11 KV MANN EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.017		.0191	.0166	
2	.0191	.0191	.017		.0191	.0166	
3	.0191	.0191	.017		.0191	.0166	
4	.0191	.0191	.017		.0191	.0166	
5	.0191	.0191	.017		.0191	.0166	
6	.0191	.0191	.017		.0191	.0166	
7	.0191	.0191	.017		.0191	.0166	
8	.0191	.0191	.0509		.0381		
9	.048	.0572	.0509		.0572	.0497	
10	.0503	.0497			.0497		
11			.0492			.0492	
12			.0492			.0492	.0497
13			.0492	.0497		.0492	.0497
14			.0164	.0497		.0492	.0497
15			.0189			.0191	.0164
16	.017		.0189			.0191	.0164
17	.0509	.0509		.0497	.0497		.0164
18	.0492	.0509		.0497	.0497		.0492
19	.0492	.0509		.0554	.0166		.0492
20	.0492	.0509		.0554	.0166		.0492
21	.0509			.0191	.0166		.0492
22	.0166			.0191	.0166		.0164
23	.0164	.017		.0191	.0189		.0164
24	.0191	.0191	.017		.0166		
Max	.0509	.0572	.0509	.0554	.0572	.0497	.0497
Min	.0164	.017	.0164	.0191	.0166	.0166	.0164
Avg	.0300	.0312	.0275	.0408	.0267	.0286	.0357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 207 / 11 KV VYALLA AGRICULTURE
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.1943		.2267	.3201	
2	.0191	.0191	.1943		.2591	.3201	
3	.0191	.0191	.2429		.2591	.3521	
4	.0191	.0191	.2429		.2267	.3521	
5	.0191	.0191	.3239		.2267	.3841	
6	.0191	.0191	.3239		.2561	.3841	
7	.0191	.0191	.3239		.3841	.3841	
8	.0191	.0191	.3239		.3841		
9	.0191	.0191	.3239		.3201	.3201	
10	.3932	.2622			.0191		
11			.0191			.0191	
12			.0191			.0191	.3841
13			.0191	.0191		.0191	.3201
14			.0191	.0191		.0191	.3201
15			.0191			.0191	.3841
16	.3277		.0191			.0191	.3841
17	.2622	.3887		.0191	.0189		.3841
18	.0191	.0162		.0191	.0189		.0191
19	.0191	.0162		.0191	.0377		.0191
20	.0191	.0162		.0191	.0377		.0191
21	.0191			.0191	.0377		.0191
22	.0191			.0191	.0377		.0191
23	.0191	.0162		.0191	.0377		.0191
24	.0191	.0191	.1943		.3201		
Max	.3932	.3887	.3239	.0191	.3841	.3841	.3841
Min	.0191	.0162	.0191	.0191	.0189	.0191	.0191
Avg	.0678	.0567	.1752	.0191	.1727	.2094	.1909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 208 / 11 KV PALASI AGRICULTURE
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.4588		.2321		
2	.1524	.1334	.4915		.2652	.3841	
3	.1524	.1334	.4915		.2321	.4801	
4	.1524	.1334	.6554		.2321	.4801	
5	.1524	.1334	.6554		.2652	.6401	
6	.1524	.1524	.852		.2561	.8002	
7	.1905	.0191	.852		.5121	.8962	
8	.1524	.1524	.852		.5121	.3841	
9	.1524	.1524	.852		.5121	.8962	
10	.5182	.9069			.0762		
11			.132			.1524	
12			.132			.1524	.8962
13			.132	.1143		.1524	.8002
14			.132	.0953		.1334	.6401
15			.1509			.1334	
16	.6958		.1509			.1334	
17	.759	.7773			.1132		.5761
18	.1143	.081			.132		.1715
19	.1524	.1296		.1326	.1698		.1905
20	.1524	.1296		.1492	.1698		.1905
21	.1715			.1492	.1698		.2096
22	.1715			.1492	.1698		.1715
23	.1524			.1492	.1698		.1715
24	.1524	.1334	.4374		.3841		
Max	.759	.9069	.852	.1492	.5121	.8962	.8962
Min	.1143	.0191	.132	.0953	.0762	.1334	.1715
Avg	.2342	.2201	.4642	.1341	.2541	.4156	.4018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 209 / 11 KV BALAPUR AGRICULTURE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9285	1.7375	.0678		.0497	.0497	.9198
2	1.8747	1.7383	.0655		.0497	.0497	.9099
3	1.8294	1.707	.0823		.0497	.0332	.8893
4	1.7764	1.6834	.0683			.0332	.8756
5	1.6949	1.6758	.0606			.0332	.8634
6	1.664	1.6534	.0328		.0497	.0332	.8223
7	2.0047	1.9372	.0336		.0332	.0332	.8939
8	2.1552	2.0938	.0492		.0332		1.1187
9	2.247	2.2294	.0492		.0332	.0332	1.1866
10	1.2963	1.2491	.1296	.1905	1.2955	.0937	1.1858
11			2.6795	1.6499	1.6225	2.5381	
12			2.8841	1.7284	1.5729	2.5389	.0332
13			2.8265	2.7149	1.4815	2.4955	.0332
14			2.5834	2.5244	1.4358	1.1096	.0332
15			2.5248	1.3131	1.2536	.3795	.0332
16	.0166		2.5362	1.3405	1.2498	1.3306	.0332
17	.034	.0328	1.4594	1.8668	2.4859	1.1218	.0332
18	.0332	.0328	1.4861	.431	1.3493	1.1553	.0332
19	.0497			.0332	.0497		.0497
20	.0497	.0492		.0497	.0497		.0497
21	.0663	.0766		.0497	.0497		.0505
22	.0663	.0023		.0497	.0497	.061	.0497
23	.0505	.069		.0497	.0497	.08	.0497
24	.974	.8282	.0655		.0497	.1509	.1829
Max	2.247	2.2294	2.8841	2.7149	2.4859	2.5389	1.1866
Min	.0166	.0023	.0328	.0332	.0332	.0332	.0332
Avg	1.0427	1.1056	1.0360	.9994	.6520	.6677	.4491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 401 / 33KV Balapur/Wadegaon
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.048	5.1578	16.4713	9.6022	18.3539	5.487	5.487
2	4.417	4.8354	16.4713	8.2305	17.7504	5.487	5.487
3	4.417	4.8354	17.3869	8.2305	16.3787	5.487	5.487
4	4.7325	4.8354	17.9973	8.2305	16.0769	4.1152	4.1152
5	4.7325	4.8354	18.913	8.2305	15.7751	4.1152	4.1152
6	4.7325	4.8354	19.2182	8.2305	17.1811	4.1152	4.1152
7	4.1461	4.513	22.5721	12.3457	23.9815	4.1152	4.1152
8	3.8272	3.8683	12.3457	12.3457	25.3532	4.1152	4.1152
9	3.5082	3.546	12.3457	13.7174	25.3532	2.7435	2.7435
10	15.6276	12.0988	12.3457	12.3457	16.9993	9.6022	9.6022
11			6.2517	2.7435	2.7435	27.332	15.0892
12			6.2517	2.7435	2.7435	21.0906	15.0892
13			5.2949	6.5707	2.7435	20.679	22.7161
14			5.7099	8.2613	2.7435	21.3306	20.7683
15			3.8272	4.1152		21.1763	21.3444
16	11.8107	10.974	4.784	4.1152	4.1152	21.1763	21.8245
17	12.6749	22.2086	4.1152	7.9424	7.9938	12.3457	19.616
18	3.7449	16.0906	4.1152	7.9424	4.1152	12.3457	15.8025
19	4.9931	8.1961	4.1152	8.642	4.1152	5.487	8.8477
20	5.3052	9.8594	5.487	10.9191	5.487	6.8587	10.535
21	5.3052	5.487	5.487	10.9191	5.487	5.487	10.8505
22	5.3052	5.487	5.487	10.9191	5.487	5.487	11.166
23	5.3052	12.9767	5.487	10.9191	5.487	5.487	11.166
24	5.1578	15.4047	15.4047	6.8587	13.7175	5.487	5.487
Max	15.6276	22.2086	22.5721	13.7174	25.3532	27.332	22.7161
Min	3.5082	3.546	3.8272	2.7435	2.7435	2.7435	2.7435
Avg	6.0416	8.4234	10.3285	8.5467	11.3123	10.0480	10.8202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 201 / 11 KV NIMBA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.0754		.7621	.5487	.0686	.7621
2	.6859	.0754		.7621	.5487	.0652	.7621
3	.6173	.072		.7621	.5144	.0652	.724
4	.6173	.072		.7621	.5144	.0652	.724
5	.5487	.072		.7621	.5144	.0652	.6478
6	.5487	.0549		.6859	.4801	.0617	.6478
7	.5487	.0549		.6859		.0617	.6478
8	.0617	.06		.6097	.5144	.0617	.5906
9	.0686	.0686		.7621	.5144	.0686	.6859
10	.0686	.0686		.7621	.6173	.0686	.9145
11	.0686		.6859	.6859	.0686		.7621
12	.0754		.6859	.6859			.6859
13	.0686		.6859	.6859			.7621
14	.0652			.6859	.0617		.6859
15	.0617			.6859	.0549		.6859
16	.0617			.6859	.0549		.6097
17	.0617		.7621	.823	.0514		.6097
18	.0857		.7621	.8573	.0514		
19	.0892		.9145	.8916	.0566		.6097
20	.0874		.9145		.06		.8573
21	.0857		.8383	.823			.7621
22	.0823		.8383	.823	.0823		.7621
23	.0789		.7621	.6859	.0686		.6859
24	.0874	.0754			.6173	.0686	
Max	.6859	.0754	.9145	.8916	.6173	.0686	.9145
Min	.0617	.0549	.6859	.6097	.0514	.0617	.5906
Avg	.2296	.0681	.7850	.7425	.2997	.0655	.7084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 202 / 11 KV KARANJA RAMJANPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.048		.5716	.5144	.0549	.5716
2	.4801	.0343		.5716	.4801	.0549	.5716
3	.4801	.0343		.5716	.4801	.0514	.5335
4	.4801	.0343		.5716	.4801	.0514	.5335
5	.4801	.0343		.5716	.4801	.0514	.4954
6	.4801	.0343		.381	.4801	.0412	.4954
7	.4801	.0343		.381		.0412	.4954
8	.048	.0343		.4572	.4801	.0412	.5716
9	.048	.0343		.381	.4801	.0446	.5716
10	.048	.0497		.5335	.4801	.048	.5716
11	.0412			.4115	.0412		
12	.0412			.5144			.5716
13	.0412			.5144			.5335
14	.0412			.5144	.0549		.4572
15	.0412			.5144	.0514		.4572
16	.0412			.5144	.048		.5335
17	.0412			.5144	.048		.5335
18	.048		.4572	.5487	.048		.6097
19	.048		.5335	.5487	.0514		.5335
20	.048		.6097		.0514		.724
21	.048		.5335	.583			.6859
22	.048		.6097	.583	.0617		.5716
23	.048		.5335	.5487	.0514		.6859
24	.048	.048		.5716	.5144	.0549	.6097
Max	.4801	.0497	.6097	.583	.5144	.0549	.724
Min	.0412	.0343	.4572	.381	.0412	.0412	.4572
Avg	.1720	.0382	.5462	.5162	.2689	.0486	.5617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 204 / 11 KV ANTARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.0823	.8383		.7202	.0892	.8573
2	.7716	.0754	.8002	.8573	.7202	.0892	.8573
3	.7202	.0754	.7621	.8573	.7202	.0892	.8573
4	.7202	.0754	.6097	.8573	.7202	.0892	
5	.7202	.0703	.6668	.8573	.7202	.0892	.7621
6	.6859	.0703	.6668	.7621	.7373	.0874	.7621
7	.6859	.0703	.7049	.7621		.0874	.8002
8	.072	.0857	.7621	.7621	.7888	.0874	.8002
9	.0789	.0909	.8192	.7811	.4973	.0857	.8002
10	.0789	.0823	.8192	.724	.823	.0857	.8002
11	.0806		.7811	.6859	.0874		.4191
12	.0806		.743	.6859			.8192
13	.0806		.724	.6859			.7811
14	.0789		.8764	.7888	.0857		.7621
15	.0789		.8764	.7888	.0823		.7621
16	.0857		.8002	.7888	.0806		.7621
17	.0874		.8954	.8573	.0943		.0762
18	.0909		.9145	.9259			.8954
19	.0977		.9717	.9602	.096		.7621
20	.096		1.0288		.0857		.5716
21	.0943		.9526	.9602			.9907
22	.0926		.8764	.9088	.0943		.5716
23	.0857		.8764	.8402	.0909		1.0288
24	.8059	.0823		.8573	.7202	.0892	.9145
Max	.8059	.0909	1.0288	.9602	.823	.0892	1.0288
Min	.072	.0703	.6097	.6859	.0806	.0857	.0762
Avg	.3017	.0782	.8159	.8161	.4192	.0881	.7571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 201 / 11 KV NIMKARDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.439				.3155	.3292
2	.4664	.4115				.2881	.3429
3	.4664	.4115				.3018	.3429
4	.4664	.4115				.3018	.3567
5	.4527	.439				.3155	.3429
6	.4664	.4527				.3292	.3429
7	.5624	.5213				.439	.4801
8	.5761	.6036				.5075	.5624
9	.6859	.6173				.4938	.5487
10			.6584	.6859	.5487		
11			.6859	.6996	.5624		
12			.6859	.6447	.5487		
13				.6173	.5487		
14			.631	.5761			
15			.6447	.5487	.4801		
16			.6859	.5624	.4664		
17			.6859	.5487	.5487		
24	.4527	.439				.3018	.3292
Max	.6859	.6173	.6859	.6996	.5624	.5075	.5624
Min	.4527	.4115	.631	.5487	.4664	.2881	.3292
Avg	.5048	.4746	.6682	.6104	.5291	.3594	.3978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 202 / 11 KV IOC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.1886	.1509	.1886	.1715	.1905
2	.1698	.1886	.1886	.0579	.1886	.1715	.1905
3	.1886	.1886	.1886	.1509	.1886	.1905	.1524
4	.1698	.1886	.1698	.1132	.1886	.1905	.1524
5	.1698	.1886	.1698	.1132	.1886	.1905	.1524
6	.0943	.0943	.1132	.0754	.0754	.1143	.1334
7	.0754	.0754	.0754	.0754	.0754	.0762	.0762
8	.0754	.0754	.0762	.0754	.0754	.0762	.0762
9	.0754	.0754	.132	.1698	.2263	.1143	.1334
10	.2641	.1509	.2641	.1715	.2667	.2641	.2641
11	.2641	.1132	.2641	.2641	.2667	.2641	.2667
12	.2641	.0754	.2641	.2477	.2667	.1886	.2641
13	.2452	.0943	.1509	.2096	.2096	.3395	.2286
14	.2452	.0943	.1886	.1905	.2096	.2641	.2667
15	.415	.0943	.2263	.1715	.1905	.2263	.2667
16	.3584	.0754	.2452	.1886	.2286	.1886	.3429
17	.3206	.0754	.2263	.2667	.1905	.2641	.2263
18	.2641	.0754	.2263	.1886	.0762	.1143	.132
19	.2263	.132	.2641	.3206	.2096	.1905	.1509
20	.2641	.1886		.2263	.2096	.2096	.1886
21	.3018	.1886	.1886	.1886	.1905	.2286	.1886
22	.2263	.1886	.1886	.1886	.1715	.1905	.1886
23	.1886	.1698	.1886	.1886	.1905	.1905	.1886
24	.1698	.1886	.1698	.1509	.1886	.1715	.1905
Max	.415	.1886	.2641	.3206	.2667	.3395	.3429
Min	.0754	.0754	.0754	.0579	.0754	.0762	.0762
Avg	.2169	.1320	.1895	.1727	.1859	.1913	.1921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 203 / 11 KV GAIGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0305	.0423	.04		
2			.0366	.0507	.04		
3			.0457	.0507	.04		
4			.0381	.0579	.0419		
5			.0457	.0564	.0503		
6			.0457	.0564	.0503		
7			.061	.0652	.0671		
8			.0732	.0634	.0671		
9			.064	.0705	.0754		
10	.0686	.0806				.0686	.0686
11	.0703	.0754				.0762	.072
12	.0625	.0895				.0838	.0732
13	.061	.0914					.0686
14	.0686	.0806				.0457	.0305
15	.061	.0914				.08	.0381
16	.0937	.0806				.088	.0686
17	.0781	.1075				.088	.064
24			.0305	.0352	.0419		
Max	.0937	.1075	.0732	.0705	.0754	.088	.0732
Min	.061	.0754	.0305	.0352	.04	.0457	.0305
Avg	.0705	.0871	.0471	.0549	.0514	.0758	.0605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 204 / 11 KV HATRUN FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1783	.1486	.2134		
2			.2218	.1486	.2134		
3			.2402	.1783	.1981		
4			.1932	.1783	.1829		
5			.2027	.1932	.1829		
6			.1932	.208	.2134		
7			.208	.1932	.2439		
8			.2494	.2675	.2286		
9			.2031	.2229	.2439		
10	.2201	.2201				.2378	.1806
11	.2526	.2559				.2675	.1337
12	.2439	.2469				.2378	.1783
13	.2286	.2591				.2229	.208
14	.2591	.2591				.1783	.2347
15	.3048	.2675				.1467	.208
16	.2896	.2591				.132	.208
17	.2591	.2591				.1614	.4458
24			.16	.1486	.2107		
Max	.3048	.2675	.2494	.2675	.2439	.2675	.4458
Min	.2201	.2201	.16	.1486	.1829	.132	.1337
Avg	.2572	.2534	.2050	.1887	.2131	.1981	.2246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 205 / 11 KV NIMKARDA G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3491	1.4415	1.386	1.4784	1.4784	1.3306	1.4415
2	1.3306	1.4045	1.386	1.423	1.4415	1.3306	1.423
3	1.3306	1.4045	1.4045	1.386	1.4045	1.2936	1.386
4	1.2567	1.3676	1.4045	1.3491	1.4045	1.2936	1.386
5	1.1643	1.2936	1.2936	1.3306	1.3676	1.3491	1.3306
6	1.1273	1.2382	1.3306	1.3121	1.2936	1.386	1.2936
7	1.0534	1.1088	1.1088	1.1643		1.1088	1.0534
8	.961	1.0534	1.0719	.9979	1.1273	1.0164	1.0164
9	.9795	1.0164	.924	1.0349	1.0164	1.0349	1.0719
10	.9795	1.0534	.924	1.1088	1.0164	1.0164	1.0719
11	.924	.924	.961	1.0719	.9979	.7947	1.0534
12	.924	.9979	.9425	1.0719		.7392	.8686
13	1.0349	.9979	.9979	1.1643			.924
14	1.0719	1.0719	1.0349	1.1458		.8316	1.1088
15	1.1088	1.0719	1.0534	1.1088	1.4415	.6653	1.1088
16	1.0719	1.0719	1.0349	1.2382	.9979	1.0349	1.1088
17	1.0534	.6838	.9979	1.1643	.8501	.924	1.1088
18	1.0719	.7023	1.0164	1.1827	1.1827	1.0349	.924
19	1.2936	1.2936	1.4415	1.5154	1.386	1.2936	1.2936
20	1.5524	1.6448	1.6448		1.5708	1.4784	1.5524
21	1.5708	1.5154	1.6263	1.7002		1.5708	1.5708
22	1.5524	1.4784	1.6263	1.6817	1.6632	1.5524	1.6078
23	1.5524	1.4784	1.5708	1.5893	1.4784	1.5154	1.5524
24	1.3491	1.4784	1.386	1.0349	1.5154	1.386	1.46
Max	1.5708	1.6448	1.6448	1.7002	1.6632	1.5708	1.6078
Min	.924	.6838	.924	.9979	.8501	.6653	.8686
Avg	1.1943	1.1997	1.2320	1.2719	1.2965	1.1731	1.2382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 201 / 11 KV WADEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.373		.373		
2			.373	.4207	.3681		
3			.373	.5258	.3467		
4			.407	.5373	.3658		
5			.407	.5784	.3506		
6			.4409	.5973	.5426		
7			.763	.8413	.8573		
8			.8309	1.0185	.8916		
9			.7969	.8238	.8059		
10	1.0562	.7202				.8764	.9496
11	.8865	.7888				.9214	.9326
12	.9054	.8139				.7865	.8309
13	.6413	.7545				.7865	.4578
14	.5658	.6379					.5765
15	.6584	.5658				.6135	.6274
16		.6001				.7011	.6478
17	.7888	.6783					.7783
24			.3772	.3772	.3772		
Max	1.0562	.8139	.8309	1.0185	.8916	.9214	.9496
Min	.5658	.5658	.373	.3772	.3467	.6135	.4578
Avg	.7861	.6949	.5142	.6356	.5279	.7809	.7251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 202 / 11 KV TAMSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1494	.407	.6468	.5847	.12	.1402
2	.1372	.1227	.407	.6068	.5375	.12	.1417
3	.1402	.132	.407	.5721	.5359	.12	.124
4	.1214	.1214	.407	.6626	.463	.1029	.124
5	.1227	.1448	.4409	.6415	.4161	.12	.124
6	.1052	.1448	.5426	.7059	.6661	.12	.132
7	.1052	.1132	.9156	.9465	.8817	.1052	.1132
8	.0857	.0876	.8987	.9991	.9665	.0857	.0934
9	.0876	.1132	.8478	.9412	.9602	.0781	.0732
10	1.3535	1.2548	.0914	.0895	.0857	1.1789	1.153
11	1.2637	1.1568	.0943	.0905	.1029		1.0343
12	1.1128	1.0117	.0857	.0876	.0686		.7969
13	.8865	.9724	.1029	.1086	.0686	.0183	.6783
14	.7167	.6687	.0943	.0876		.8859	.6443
15		.691	.1029	.0867		.8954	.6104
16	.8676	.7545	.0857		.0848	.905	.7287
17	1.0791	.8309	.0876	.1052	.0857	1.0269	.7602
18		.0857	.0857	.0886	.0857	.7186	.1086
19	.1463	.1372	.1267	.1227	.12	.6036	.1267
20	.1698	.1357	.1543	.1417	.128	.1509	.1629
21	.1698	.1543	.1578	.1578	.128	.1595	.1629
22	.1509	.1372	.1698	.1595	.1402	.1543	.1543
23	.1417	.1543	.1372	.1372	.1265	.1372	.1402
24	.1357	.1267	.407	.6024	.6068	.1107	.12
Max	1.3535	1.2548	.9156	.9991	.9665	1.1789	1.153
Min	.0857	.0857	.0857	.0867	.0686	.0183	.0732
Avg	.4198	.3917	.3024	.3821	.3565	.3599	.3520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 203 / 11KV BELURA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1731	1.2294	1.7834	2.0516	1.9754	1.262	1.262
2	1.1724	1.1986	1.7789	2.0995	1.8983	1.2383	1.2049
3	1.1507	1.1769	1.767	2.0507	1.8137	1.2155	1.2178
4	1.133	1.1602	1.6977	1.9408	1.797	1.1979	1.2109
5	1.1117	1.1362	1.7574	.9777	1.7734	1.1926	1.1888
6	1.0999	1.1324	1.8503	2.1491	2.0447	1.2361	1.1759
7	1.1082	1.1163	2.3724	2.7513	2.5637	1.1416	1.102
8	.973	1.0181	2.7927	2.8988	2.9675	.9374	.9587
9	.8114	.8406	2.7748	3.0224	2.9466	.7375	.7552
10	2.3068	2.0222	1.5257	1.7437	1.6301	2.0211	1.99
11	3.3411	2.9493	.7269	.7926	.8086	3.1443	2.9853
12	3.1895	3.0022	.7149	.7046	.7118	3.0841	2.8054
13	2.6799	2.713	.7947	.7994	.7591	2.5682	2.581
14	2.4817	2.2167	.8718	.9105	.7937	2.3765	2.4006
15	2.1925	1.869	.6904	.9397	.8311	2.0567	2.2657
16	2.3365	1.9204	.9039	.9434	.923	1.9768	2.2138
17	2.678	1.9226	.868	.8994	.9092	2.3247	2.4614
18	1.6741	1.3615	.7865	.8124	.8389	1.5101	1.5322
19	.9819	.6241	.8789	.9027	.9358	.7992	.9307
20	1.2018	1.165	1.2155	1.1768	1.1586	1.1363	1.1889
21	1.3016	1.2868	1.2805	1.2643	1.233	1.2323	1.2633
22	1.3235	1.3366	1.3351	1.3042	1.2999	1.2863	1.3089
23	1.3094	1.3397	1.3422	1.3529	1.3212	1.3096	1.3565
24	1.2656	1.2818	1.7857	2.0202	1.9402	1.2338	1.0395
Max	3.3411	3.0022	2.7927	3.0224	2.9675	3.1443	2.9853
Min	.8114	.6241	.6904	.7046	.7118	.7375	.7552
Avg	1.6666	1.5425	1.4290	1.5212	1.4948	1.5925	1.6000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 204 / 11 KV WADEGAON G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.9431	.8478	.9808	.9465	.9922	.9745
2	.8413	.905	.8478	.9412	.9808	.9602	1.0059
3	.7975	.9145	.8478	.9808	.9431	.9568	.9145
4	.8145	.8775	.8139	.905	.8478	.9259	.9145
5	.7716	.8775	.8139	.9431	.8478	.8764	.9145
6	.7716	.8865	.8309	.8676	.8059	.8859	.8865
7	.7186	.8488	.763	.8676	.78	.7973	.8676
8	.7011	.7922		.8299	.6952	.7442	.8299
9	.6335	.7545	.7122	.7356	.6344	.6325	.7733
10	.724	.6068	.7167	.7087	.7796	.7545	.6952
11	.6979	.6274	.6979	.7522	.7796	.7733	.6952
12	.7545	.7545	.7087	.7973	.7373	.811	.7122
13	.8488	.8817	.7537	.8859	.7291	.823	.6613
14	.8865	.8859	.811	.8507		.9054	.7291
15	.8507	.8402	.2401	.7712	.8987	.9431	.8817
16	.8676	.8573	.9568	.7973	.8648	.8764	.7935
17	.8962	.8478	.8682	.7888	.8682	.9431	.7964
18	.8488	.8063	.7888	.8669	.8328	.8676	.7783
19	1.0751	1.0277	1.0317	1.0277	1.0631	1.0562	.9231
20	1.0562	.9602	.9922	1.0402	.9962	1.094	.9593
21	1.0185	.9431	.9568	1.086	1.0364	1.0317	.9412
22	.9922	.9389	1.094	1.0288	1.0099	.9145	.9431
23	.9602	1.0117	1.0277	1.0517	.9503	1.0288	.9745
24	.8842	.9568	.9326	.9259	.9602	.8855	.9602
Max	1.0751	1.0277	1.094	1.086	1.0631	1.094	1.0059
Min	.6335	.6068	.2401	.7087	.6344	.6325	.6613
Avg	.8453	.8644	.8284	.8930	.8690	.8950	.8552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 201 / 11 KV WAGHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3658	1.4746	1.4746	1.5089	1.406	.4115
2	.2743	.3658	1.4746	1.4746	1.4746	1.406	.3772
3	.2743	.3658	1.4746	1.3717	1.4746	1.406	.3429
4	.2743	.3658	1.5432	1.3717	1.4746	1.406	.3429
5	.2058	.3658	1.5432	1.2346	1.4746	1.4403	.3429
6	.2058	.3658	1.5775	1.3717	1.4746	1.5089	.3086
7	.2058	.2195	1.5775	1.4403	1.5089	1.5775	.2401
8	.1715	.2195	1.6461	1.4403	1.5775	1.5089	.2058
9	.2058	.2195	1.7147	1.3717	1.5089	1.5089	.2058
10	2.0119	1.7147	.2058	.1715	.2058	.1715	2.0485
11	1.9753	1.7833	.2058	.2195	.2058	.2058	2.0485
12	1.9022	1.7833	.2401	.2195	.2743	.2401	1.9022
13	1.7924	1.6461	.2401	.2195	.2743	.2058	1.9022
14	1.6095	1.6118	.2743	.2926	.2743	.2401	1.5364
15	1.829	1.5775	.2743	.2926	.2743	.2743	1.5546
16	1.8656	1.5775	.2401	.2058	.2743	.2401	1.5729
17	1.7558	1.6461	.2058	.2058	.2743	.2058	1.6095
18	.2195	.2058	.2058	.2058	.2058	.2058	.2195
19	.439	.3429	.4115	.4115	.3429		.3658
20	.439	.3772	.4458	.4458	.4115	.3772	.439
21	.5121	.4115	.4458	.4801	.4115	.3772	.5121
22	.439	.4115	.4458	.4801	.4115	.4458	.4755
23	.439	.3772	.4115	.4115	.4115	.4458	.439
24	.3429	.3658	1.4403	1.5089	1.5089	1.3717	.4458
Max	2.0119	1.7833	1.7147	1.5089	1.5775	1.5775	2.0485
Min	.1715	.2058	.2058	.1715	.2058	.1715	.2058
Avg	.8222	.7786	.8216	.7634	.8016	.7902	.8271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 202 / 11 KV KOTHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8779	1.2003	1.3032	1.3032	1.2346	.8573
2	.823	.8779	1.2003	1.2689	1.3375	1.2346	.823
3	.7202	.8779	1.2003	1.2689	1.3375	1.2689	.823
4	.7202	.8779	1.2346	1.2689	1.3375	1.2689	.8059
5	.6859	.8779	1.3032	1.2174	1.3375	1.2689	.7888
6	.6516	.8779	1.3375	1.3375	1.3717	1.286	.7202
7	.6173	.6219	1.406	1.3717	1.5089	1.5432	.6516
8	.583	.5487	1.2174	1.5432	1.4746	1.406	.5487
9	.5316	.5487	1.2346	1.5432	1.2003	1.3203	.5144
10	1.6461	1.5775	.5487	.5316	.4115	.463	1.6827
11	1.6827	1.5775	.5144	.5121	.4973	.4973	1.8656
12	1.6461	1.5604	.5487	.5487	.5658	.5144	1.4998
13	1.5729	1.3889	.5144	.5487	.6173	.4973	
14	1.3169	1.406	.5316	.5853	.6001	.5144	1.4998
15	1.3535	1.3717	.5316	.6219	.6173	.5144	1.4632
16	1.4266	1.3375	.5144	.5487	.6001	.5144	1.4632
17	1.4998	1.4403	.4973	.5144	.5316	.4973	1.4632
18	.6219	.463	.5658	.5144	.583	.5144	1.2071
19	1.0608	.8916	.9431	.9602	.9431	.9259	.9511
20	1.0974	1.0288	1.1488	.9945	1.0288	1.0117	1.134
21	1.0974	1.0631	1.0974	1.0288	1.0288	1.0117	1.0974
22	1.0974	1.046	1.0288	1.0288	.9945	.9602	1.0974
23	1.0242	1.0288	.9431	.9259	.9602	.9602	1.0608
24	.8402	.9145	1.166	1.3375	1.3032	1.2003	.8573
Max	1.6827	1.5775	1.406	1.5432	1.5089	1.5432	1.8656
Min	.5316	.463	.4973	.5121	.4115	.463	.5144
Avg	1.0475	1.0451	.9345	.9719	.9788	.9345	1.0815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 203 / 11 KV MAHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.4632	1.4575	1.406	1.4403	1.4575	.4458
2	1.3717	1.4632	1.4575	1.406	1.4403	1.4575	.4458
3	1.3717	1.4632	1.4575	1.406	1.4403	1.4403	.4458
4	1.4403	1.4632	1.4746	1.406	1.406	1.4403	.9602
5	1.5432	1.4632	1.5089	1.406	1.3717	1.4746	.9945
6	1.6461	1.4998	1.5261	1.406	1.3717	1.6461	1.3717
7	1.7147	1.6461	1.3546	1.4232	1.2346	1.3375	1.5089
8	1.1488	1.8473	1.1831	1.3203	1.2003	1.1488	1.5261
9	1.5947	1.6827	1.2517	1.0974	1.1831	1.2346	1.3889
10	1.3717	1.286	1.9204	1.8004	1.749	1.6804	1.39
11	1.3352	1.2689	2.0405	2.2131	1.8347	1.7147	1.3535
12	1.262	1.1831	1.749	2.0851	1.6118	1.4918	1.3535
13	1.2803	1.2346	1.5089	1.8656	1.4232	1.5432	1.262
14	1.2803	1.3169	1.406	1.7193	1.3717	1.3717	1.2254
15	1.2803	1.2517	1.3546	1.6461	1.3546	1.286	1.2437
16	1.3169	1.2346	1.4746	1.5947	1.406	1.406	1.2437
17	1.3352	1.2003	1.5432	1.5432	1.4746	1.3375	1.2803
18	1.2986	1.3546	1.2517	1.3032	1.2517	1.3717	1.2986
19	1.829	1.5432	1.6461	1.6461	1.6804	1.7833	1.8107
20	1.9387	1.6118	1.7833	1.7147	1.7147	1.8004	1.9753
21	1.7558	1.6461	1.749	1.749	1.7147	1.7147	1.2437
22	1.6827	1.6632	1.6632	1.6975	1.6461		1.2437
23	1.6095	1.5432	1.5604	1.5775	1.5432	1.4746	1.2071
24	1.3375	1.39	1.4403	1.4232	1.4746	1.4575	.4458
Max	1.9387	1.8473	2.0405	2.2131	1.8347	1.8004	1.9753
Min	1.1488	1.1831	1.1831	1.0974	1.1831	1.1488	.4458
Avg	1.4618	1.4467	1.5318	1.5773	1.4725	1.4813	1.1944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 204 / 11 KV Donod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7368	1.8656	.3429	.3429	.3429	.3429	1.4746
2	1.8176	1.8656	.3429	.3429	.3429	.3429	1.5089
3	1.8861	1.8656	.3429	.3429	.3429	.3429	1.5089
4	1.8861	1.9022	.3429	.3429	.3429	.3429	1.5089
5	2.0576	1.9022	.3429	.3429	.3429	.3086	1.5089
6	2.0576	1.9022	.3086	.2743	.3429	.2743	1.4746
7	2.0576	1.9387	.2058	.2401	.3086	.2401	1.8861
8	1.989	1.9753	.2058	.2058	.2743	.2058	1.6804
9	1.9204	1.9753	.2058	.2401	.2401	.1715	1.6804
10	.2195	.2058	2.0576	1.8519	1.8519	2.0576	.2195
11	.2195	.2058	2.2634	2.3045	2.0576	1.9204	.2195
12	.2561	.2401	1.8861	2.0485	1.8861	1.7147	.2195
13	.2561	.2401	1.8176	2.3045	1.7833	1.7147	.2561
14	.2926	.2401	1.8176	2.1948	1.7833	1.5432	.2561
15	.2926	.2401	1.8176	2.0851	1.7833	1.5089	.2561
16	.2926	.2401	1.8861	1.7147	1.749	1.5089	.2561
17	.2195	.2058	1.9547	1.7147	1.7147	1.5775	.2195
18	.2561	.2058	.2229	.3086	.2401	.4458	.2195
19	.3292	.3429	.3772	.3772	.3429	.4458	.3658
20	.439	.4115	.4287	.3772	.4115	.4458	.4755
21	.4755	.4115	.4287	.4458	.4115	.463	.4755
22	.439	.4115	.4115	.4115	.4115	.4458	.439
23	.4024	.3429	.3944	.4115	.3772	.4458	.439
24	1.7974	1.8656	.3429	.3429	.3429	.3429	1.3032
Max	2.0576	1.9753	2.2634	2.3045	2.0576	2.0576	1.8861
Min	.2195	.2058	.2058	.2058	.2401	.1715	.2195
Avg	.9832	.9584	.8645	.8987	.8345	.7980	.8272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 401 / 33 KV W/W

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.7558	.7716	.7202	1.8004	1.5432	1.8519
2	1.6804	1.7558	.7716	.7202	1.8004	1.5432	2.0576
3	1.6804	1.7558	.7716	.7202	1.8004	1.5432	2.0576
4	1.6804	1.8107	.7716	.7202	1.8004	1.5432	1.749
5	1.6804	1.8107	.7716	.7202	1.8004	1.5432	1.749
6	1.5432	1.8107	.7716	.7202	1.8519	1.5432	1.8519
7	1.9605	1.8107	.7716	.7202	1.8519	2.0576	2.1605
8	2.0576	2.3594	.7716	.7202	1.8004	2.0576	2.1091
9	2.2405	2.3045	.7716	.7202	2.1605	2.0576	2.1605
10	2.3045	2.3663	.7716	.7716	2.3148	2.3148	2.3594
11	2.4143	2.3663	.823	.823	2.3148	2.3663	2.6337
12	2.4143	2.3663	.7716	.5487	2.3148	2.1605	
13	2.4143	2.3663	.7716	.5487	1.5432	2.1605	2.4691
14	2.4143	2.5766	.7716	.5487	1.5432	2.1605	2.4143
15	2.1948	2.3663	.7716	.5487	2.0576	2.1091	2.4143
16	1.9753	1.5432	.7716	.5144	2.0576	2.1091	2.4691
17	1.6461	1.5432	.7716	.5144	1.5432	1.6975	2.4691
18	1.6461	1.5432	.7716	.5144	1.5432	1.5947	1.8656
19	1.6461	1.5432	.7716	.5144	1.5432	1.5947	1.6461
20	1.6461	1.5432	.7716	1.5432	1.5432	1.5947	1.6461
21	1.7558	1.5432	.7716	1.5432	1.5432	1.5947	1.6461
22	1.8107	1.5432	.7716	1.749	1.5432	1.5432	1.6461
23	1.8107	1.5432	.7202	1.8004	1.5432	1.5432	1.6461
24	1.6804	1.6461	1.5432	.7202	1.8519	1.5432	1.6461
Max	2.4143	2.5766	1.5432	1.8004	2.3148	2.3663	2.6337
Min	1.5432	1.5432	.7202	.5144	1.5432	1.5432	1.6461
Avg	1.9157	1.8989	.8038	.8202	1.8111	1.8133	2.0312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 201 / 11 KV PATUR-NANDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.8402		.9335		.6379	.6687
2	.7796	.8402		.9335		.6379	.6687
3	.7796	.823		.9335		.6379	.6859
4	.8505	.823		.9335		.6722	.6859
5	.8505	.8871		.9335		.6379	.7545
6	.8859	.823		.9709		.6379	.8573
7	.9214	.8573		1.0456		.9922	1.0288
8	.8962	.8573		.8962		.9922	1.0802
9	.8505	.8745		1.0269		.9214	1.1088
10	.8215	.7762		.7087		.7468	.9979
11	.8131			.7442		1.1203	.961
12	.8131		.8859	.7956	.7796	1.1273	.9335
13	.8501		.9214	.7956	.7796	1.1273	.9335
14	1.0349		.9214	.8619	.8859	1.2012	.9709
15	1.1088		.9214	.8619	.8859	1.2012	.9709
16	1.1088		.8859	.8619	.8859	1.3121	.9709
17	.9425		1.0631	.9282	1.0631	1.2197	
18	1.1088		.8215	.8048	.7468	1.2197	
19	1.3121		1.2696		1.307	1.3121	1.0269
20	1.46		1.1203		1.307	1.5708	1.2136
21	1.5154		1.2323		1.307	1.0164	1.2136
22	1.4045		1.1203		1.307	1.1088	1.2136
23	1.4045		1.1203		1.307	1.2012	1.2136
24	.7796	.7888		.9335		.6379	.8059
Max	1.5154	.8871	1.2696	1.0456	1.307	1.5708	1.2136
Min	.7796	.7762	.8215	.7087	.7468	.6379	.6687
Avg	1.0047	.8355	1.0236	.8897	1.0468	.9954	.9529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 202 / 11 KV PINJAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.8686		.6733		.8589	.7207
2	.8215	.8686		.6733		.8402	.7392
3	.8215	.8501		.6733		.8402	.7392
4	.8215	.8501		.6733		.8402	.7392
5	.8215	.8686		.6733		.8402	.7762
6	.8402	.8871		.6733		.8402	.8871
7	.7468	.8501		.7087		.8402	.8871
8	.7468	.8871		.7087		.9335	.8871
9	.7468	.9795		.6733		.9335	.8916
10	.7973	.8573		.7468		1.0631	.8573
11	.8859	.6859		.6348		.8859	.9945
12	.9431		.6722	.6706	.7095	.8402	.8859
13	.7716		.6722	.7042	.7468	.7202	.7973
14	.7545		.6722	.6371	.6722	.4458	.6733
15	.7373		.6722	.6706	.6722	.4458	.6733
16	.8402		.7095	.7377	.6722		.6379
17	.823		.7095	.7377	.7095		
18	.924		.9335	.8383	.8402	.8402	
19	1.1643		1.1203		1.1203	.8916	1.1203
20	1.2012		1.1203		1.1203	.8573	1.1949
21	1.1273		1.1203		1.1203	.8131	1.1203
22	1.0719		1.1203		1.1203	.7947	1.1203
23	1.0164		1.0829		1.1203	.7947	1.0269
24	.8402	.8871		.6379		.9335	.7392
Max	1.2012	.9795	1.1203	.8383	1.1203	1.0631	1.1949
Min	.7373	.6859	.6722	.6348	.6722	.4458	.6379
Avg	.8786	.8617	.8838	.6919	.8853	.8224	.8686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 203 / 11 KV MAHAN (PINJAR)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6733	.7545		.8029		.6379	.7023
2	.6733	.7545		.8029		.6379	.6859
3	.6556	.7545		.8029		.6379	.6859
4	.6556	.7545		.8029		.6379	.6687
5	.6733	.8131		.7442		.6379	.7202
6	.7087	.7545		.7265		.6379	.7888
7	.8328	.9088		.7282		.8859	.9259
8	.815	.9431		.6348		.8505	.7545
9	.7973	.7888		.6908		.8328	.6173
10	.5601	.5544		.7973		.5041	.2587
11	.6348	.4066		.8859		.5975	.5914
12	.7023		.9391	.7459	.8682	.6099	.3174
13	.6468		.8402	.663	.7796	.5359	.6535
14	.6838		.7087	.663	.691	.5544	.6348
15	.5729		.7265	.6796	.6379	.5359	.6348
16	.5914		.7796	.5801	.691	.5914	.5975
17	.5359		.815	.8383	.7619	.5544	.3921
18	.7207		.6348	.5197	.5788	.6099	.6161
19	.8501		.8962		.8029	.7577	.8215
20	.924		.9896		.8962	.6653	.9149
21	.9425		1.0269		.9709	.8686	.9335
22	.8501		.9149		.9522	.9055	.9149
23	.7762		.8589		.8215	.8131	.8402
24	.6733	.7202		.7842		.6201	.6001
Max	.9425	.9431	1.0269	.8859	.9709	.9055	.9335
Min	.5359	.4066	.6348	.5197	.5788	.5041	.2587
Avg	.7146	.7423	.8442	.7312	.7877	.6717	.6780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 204 / 11 KV MAHAGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5061	.7762		1.7364		1.825	2.0062
2	1.587	.7762		1.8484		1.3643	1.989
3	1.5061	.7762		1.7541		1.3643	1.9719
4	1.5769	.7762		1.7718		1.3643	1.9719
5	1.6655	.8131		1.8781		1.6124	1.989
6	1.7718	.924		2.0199		1.7718	2.3663
7	1.9667	.9979		2.0199		1.8959	2.1434
8	1.6832	.7577		1.9136		1.6655	2.2634
9	1.6124	.7023		.9391		1.3289	1.9376
10	1.4529	1.4746		.6348		.9391	1.2689
11	1.701	1.5604		.7468		1.643	1.5432
12	.4801		.6535	.6203	.6161	1.5604	1.5415
13	.7202		.6722	.6203	.6722	1.5604	1.7187
14	1.749		.5788	.6203	.6535	1.5432	1.5947
15	1.5947		.6535	.6036	.5975	1.3717	.9568
16	1.6461		.6535	.5868	.5788	1.406	1.6832
17	.6859		.5601	.57	.5975	1.4746	1.6832
18	1.423		.6535	1.2597	1.4377	1.0349	1.5415
19	1.7926		2.0538		2.0538	1.5708	2.1472
20	1.7741		2.0538		2.2405	1.7926	2.4272
21	1.8111		1.949		2.0538	1.6817	2.4272
22	1.8111		1.8298		2.0538	1.5154	2.2405
23	1.6632		1.7177		2.0538	1.423	2.2779
24	1.3289	.7947		1.825		1.7718	1.9204
Max	1.9667	1.5604	2.0538	2.0199	2.2405	1.8959	2.4272
Min	.4801	.7023	.5601	.57	.5788	.9391	.9568
Avg	1.5212	.9275	1.1691	1.2615	1.3008	1.5200	1.9005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 205 / 11 KV BAHIRKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-APR-17	17-APR-17	18-APR-17	19-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003			
2	1.2003			
3	1.2174			
4	1.2174			
5	1.3375			
6	1.4403			
7	1.6975			
8	1.6118			
9	.8916			
11			1.3643	
12		1.5061	1.21	1.1871
13		1.4529	1.21	1.1517
14		1.0479	1.1271	.9391
15			1.2266	1.1163
16		.8859	1.1768	1.1163
17			1.4586	1.1871
24	1.0802			
Max	1.6975	1.5061	1.4586	1.1871
Min	.8916	.8859	1.1271	.9391
Avg	1.2894	1.2232	1.2533	1.1163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 206 / 11 KV GHOTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	.961		1.8959		1.9231	2.1253
2	1.7924	.961		1.9313		1.9231	2.0698
3	1.7551	.961		1.9313		1.8671	2.0328
4	1.6617	.961		1.9313		1.8671	2.0328
5	1.6617	.9425		1.9136		1.8484	2.0328
6	1.6244	.7762		2.073		1.8298	2.0144
7	1.6991	.6283		2.3339		1.8298	1.6078
8	1.0829	.7207		2.1971		1.7737	1.922
9	1.5684	.6283		2.0553		1.643	1.6817
10	1.587	1.9376		.7655		2.073	1.9376
11	1.4883	1.8004		.7468		2.1439	2.1776
12	2.0405		.5601	.7545	.7468	1.9376	2.1085
13	2.0576		.5601	.7545	.7655	1.7661	2.0376
14	1.9719		.7282	.6874	.8215	1.5261	1.4175
15	1.9033		.7842	.6874	.7842		1.701
16	2.0062		.7655	.6874	.7282	.6859	1.701
17	1.8296		.7095		.6535	.7373	1.8858
18	1.848		1.587		1.9605		1.6804
19	1.848		2.1845		2.4832		2.2032
20	2.2546		2.3712		2.6699	1.9033	2.2592
21	2.347		2.2032		2.4459	2.1434	2.3339
22	2.2916		2.1285		2.3899	2.4209	2.3712
23	2.0883		1.9231		2.2779	2.4025	2.1098
24	1.9044	.9795		1.6655		1.8298	2.1253
Max	2.347	1.9376	2.3712	2.3339	2.6699	2.4209	2.3712
Min	1.0829	.6283	.5601	.6874	.6535	.6859	1.4175
Avg	1.8377	1.0215	1.3754	1.4713	1.5606	1.8131	1.9820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 201 / 11 KV KANHERI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4668	.4534	.5506	.5304		.3932
2	.3696	.4475	.4372	.6219	.5304		.3932
3	.362	.4475	.421	.6154	.5304		.3887
4	.3982	.4475	.421	.6154	.4973		.4024
5	.543	.4973	.4534	.6584	.5304		.4024
6	.6154	.5304	.4858	.724	.5304		.3605
7	.6335	.5304	.5506	.7499	.5801		.421
8	.6036	.5801	.6316	.6964	.663		.5487
9	.5344	.6464	.6478	.7125	.6299		.5853
10		.779			.7459		.6516
11	.663		.5853	.663	.7202	.5182	
12	.6962		.6516	.6962	.6722	.6478	
13	.663		.695	.1658		.3932	
14	.663		.6878	.1823		.421	
15	.6962		.6554	.663		.426	.6154
16	.7459		.6478	.779		.7537	
17	.8122		.3887	.8453		.9503	.6478
18			.0754			.0566	
19	.0829		.0754	.0663		.0566	.0162
20	.0663		.0754	.0829		.0566	.0162
21	.0663			.0829		.0566	.0162
22	.0663		.0943	.0829		.0566	.0162
23	.0747	.0625	.0943	.0663	.0625	.0566	.0162
24	.3658	.4144	.4534	.6584	.5636		.3887
Max	.8122	.779	.695	.8453	.7459	.9503	.6516
Min	.0663	.0625	.0754	.0663	.0625	.0566	.0162
Avg	.4585	.4875	.4401	.4990	.5562	.3423	.3489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 202 / 11 KV DHABA BT

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.1326				.1646
2	.0732	.1326				.1629
3	.0732	.116				.1463
4	.1097	.116				.1448
5	.1448	.116				.1463
6	.1448	.1326				.1463
7	.1448	.1326				.1463
8	.1629	.1492				.1097
9	.1646	.1492				.0366
10					.0732	
11			.1448	.1307	.125	
12			.1463	.168	.125	
13			.1494	.1326	.125	
14			.1463	.116	.125	
15			.1463	.1326	.1406	
16			.1463	.1326	.125	
17			.1448	.1492	.125	
24	.0366	.1326				.1457
Max	.1646	.1492	.1494	.168	.1406	.1646
Min	.0366	.116	.1448	.116	.0732	.0366
Avg	.1128	.1309	.1463	.1374	.1205	.1350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 203 / 11 KV REDWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	.8619					.8192
2	.8954	.8288					.8192
3	.9145	.8619					.9877
4	1.0136	.9116					.8745
5	.9831	.9116					.9175
6	1.0159	.9116					.9175
7	1.0159	.9448					1.0242
8	1.0486	.9116					1.0242
9	1.0486	.9779					1.0242
10			.6224		1.39		
11			1.0242	1.1934		1.1142	
12			1.086	1.1271		1.1012	
13			1.1222	1.0774		1.2308	
14			1.1706	1.0277		1.0814	
15			1.0688	.9945		1.0364	
16			1.0814	.9945		1.004	
17			1.085	.9945		.9717	
24	1.0349	.8951					.905
Max	1.0486	.9779	1.1706	1.1934	1.39	1.2308	1.0242
Min	.8954	.8288	.6224	.9945	1.39	.9717	.8192
Avg	.9948	.9017	1.0326	1.0584	1.39	1.0771	.9313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 204 / 11 kv Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.9335	.6602	.5281	.6535		.6036
2	.5601	.9335	.6602	.5281	.6535		.6036
3	.5658	.9335	.6413	.5281	.5601		.6413
4	.6036	.8962	.5658	.5281	.5601		.6348
5	.6036	.8775	.6036	.547	.5601		.6283
6	.5658	.8402	.5658	.547	.5975		.6348
7	.5601	.7842	.5658	.547	.5975		.5487
8	.4755	.8402	.4904	.6036	.5975		.4904
9	.5658	.8402	.6602	.6413	.5975		.4527
10	.6653	.8775	.6224		.6161		.5228
11			.6224	.7095	.6224	.6653	.5281
12	.7282		.6099	.5601	.6413	.5975	.5658
13	.7468		.6036	.4668	.6602	.547	.415
14	.724		.6036	.4481	.6413	.5658	.3772
15	.5601		.6219	.5601	.6413	.5601	.3772
16	.5228		.6722	.6535	.6413	.6413	.5281
17	.5415		.6979	.7655	.6413	.6413	.6036
18	.5975		.679	.6722	.7356	.6348	.415
19	.6535		.6413	.5601	.7167	.6348	.3584
20	.7842		.6036	.5041	.547	.6602	.415
21	.8962		.5914	.5228	.6413	.6602	.7922
22	.9522		.5601	.5601	.6413	.6602	.6602
23	.9335	.9335	.5175	.6348	.679	.6602	.5658
24	.5281		.679	.5228	.6722		.6036
Max	.9522	.9335	.6979	.7655	.7356	.6653	.7922
Min	.4755	.7842	.4904	.4481	.547	.547	.3584
Avg	.6478	.8809	.6141	.5713	.6298	.6253	.5403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 205 / 11 kv Dagadparwa Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2054	.2829	.2743	.2614		.2294
2	.2195	.168	.2829	.2743	.2241		.2294
3	.2195	.168	.2641	.2743	.2241		.2561
4	.2195	.2054	.2641	.2715	.2427		.2534
5	.2195	.2241	.2452	.2561	.2801		.2561
6	.1829	.2614	.2263	.2172	.2241		.2561
7	.1646	.2427	.2263	.2012	.1867		.2195
8	.1629	.2241	.1698	.1829	.2054		.1829
9	.1463	.1867	.1509	.1646	.168		.1448
10	.1448	.168	.1698		.1463		.1267
11	.1307		.1829	.168		.1463	.132
12	.1307		.1848	.1867		.1448	.1134
13	.1307		.2012	.1867		.1463	.1296
14	.1307		.1829	.168		.1463	.1296
15	.1494		.1848	.168		.1463	.1509
16	.1494		.1848	.1494		.1463	.1509
17	.1307		.1829	.1307		.1448	.1509
18	.168		.2534	.2241		.1829	.1886
19	.2054		.2896	.2614		.2172	.2641
20	.2801		.2896			.2926	.2829
21	.2987		.2926	.2987		.2926	.3206
22	.2614		.2896	.2801		.2926	.3018
23	.2614	.3018	.2926	.2614	.2641	.2561	.2829
24	.2353	.2241	.2829	.2743	.2801		.2561
Max	.2987	.3018	.2926	.2987	.2801	.2926	.3206
Min	.1307	.168	.1509	.1307	.1463	.1448	.1134
Avg	.1900	.2150	.2324	.2215	.2256	.1965	.2087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 206 / 11 kv Barshitakali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5729	1.8298	1.9805	1.6385	1.9978		2.0119
2	1.7375	1.7177	1.8861	1.6385	1.8671		1.6194
3	1.7741	1.643	1.8861	1.8099	1.7737		1.7375
4	1.7193	1.643	1.8484	1.829	1.6804		1.5364
5	1.4899	1.6804	1.7918	1.829	1.7177		1.6385
6	1.6289	1.7177	1.8484	1.5546	1.8298		1.6712
7	1.4089	1.7737	1.8673	1.6832	1.9231		1.6194
8	1.5384	1.7177	1.7541	1.6832	1.8671		1.5729
9	1.3927	1.7177	1.6409	1.6832	1.8298		1.5074
10	1.6108	1.7551	1.7353		1.6385		1.6385
11	1.7177		1.6651	1.9605	1.773	1.8099	1.8861
12	1.7924		1.6827	2.0351	1.7353	1.7918	1.8484
13	1.6804		1.7013	2.0538	1.7541	1.2793	1.7918
14	1.643		1.7013	2.0911	1.8484	1.448	1.7918
15	1.6804		1.7375	2.1472	1.9239	1.3108	1.773
16	1.6804		1.7193	1.9044	1.9239	1.4575	
17	1.7177		1.6385	1.7177	1.9239	1.5223	1.7353
18	1.9605		1.9433	1.9418	1.8861	1.6575	1.8861
19	2.2779			2.4459	2.2634	1.9662	2.32
20	2.2405		1.9433		2.2634	2.0405	2.3011
21	2.2405		1.8884	2.4646	2.2634	1.9433	2.1125
22	2.1845		1.9006	2.2405	2.2634	1.9595	2.0748
23	2.0538	2.1691	1.7814	2.1472	2.2445	1.9271	2.0559
24	1.7737	1.9978	2.0748	1.7814	2.1098		1.8515
Max	2.2779	2.1691	2.0748	2.4646	2.2634	2.0405	2.32
Min	1.3927	1.643	1.6385	1.5546	1.6385	1.2793	1.5074
Avg	1.7715	1.7802	1.8094	1.9218	1.9292	1.7011	1.8253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 201 / 11 KV DHABA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1494	.1494		.1494
2	.1372	.1372	.1494	.1494		.1494
3	.1372	.12	.1494	.1494		.1494
4	.1372	.12	.1494	.1494		.1494
5	.12	.12	.1494	.1494		.1494
6	.12	.12	.1494	.1433		.1494
7	.1029	.0686	.1463	.1254		.1294
8	.1029	.0686	.0914	.1075		.1109
9	.0857	.0686	.0886	.1075		.1086
10		.0686	.1063	.1075		.0716
11		.0709	.1063	.0686	.1052	.0716
12	.0857	.1063	.1086	.0514	.1052	
13	.0857	.1063	.1086	.0514	.1052	
14	.1029	.1063	.1086	.0514	.1075	
15	.1029	.1063	.1086	.0857	.0895	
16	.1372	.1086	.1086	.12	.0895	
17	.1372	.1086	.1086	.1372		
18	.1543	.1267	.1463	.1372		
19	.1543	.1848	.1829	.1372	.1097	.1829
20	.1543	.2054	.2054	.1886	.1829	.1829
21	.1543	.1867	.1867	.1886	.2012	.1646
22	.1372	.1494	.1867	.1715	.1867	.1478
23	.1372	.1494	.1867	.1543	.1867	.1494
24	.0857	.1372	.1494	.1867		.1494
Max	.1543	.2054	.2054	.1886	.2012	.1829
Min	.0857	.0686	.0886	.0514	.0895	.0716
Avg	.1231	.1201	.1388	.1278	.1336	.1391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 202 / 11 KV Punoti Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2572	.2772	.2772		.2957
2	.2743	.2572	.2772	.2772		.2957
3	.2401	.2401	.2772	.2772		.2957
4	.2401	.2401	.2772	.2772		.2957
5	.2058	.2401	.2772	.2772		.2587
6	.2058	.2572	.2772	.2454		.2402
7	.2058	.2401	.2328	.2149		.2149
8	.1543	.1886	.197	.1791		.1791
9	.1543	.1886	.1928	.1791		.1753
10	.1543	.1715	.1753	.1753		.1753
11	.1543	.1753	.1578	.1715	.1715	.1578
12	.12	.1928	.1753	.1543	.1715	
13	.1543	.1928	.1753	.1543	.1886	
14	.2058	.1928	.1753	.1715	.1886	
15	.2058	.1928	.1791	.1715	.1907	
16	.2058	.1949	.1829	.1715	.1772	
17		.1772	.1629	.2058	.1791	
18	.2572	.2743	.2149	.2572	.1791	
19	.2572	.3292	.3045	.2743	.3077	.2328
20	.3086	.3511	.3547	.3601	.3439	.3045
21	.3086	.3361	.3326	.3429	.3326	.2865
22	.3258	.3174	.3142	.3429	.3142	.2865
23	.3086	.3174	.3142	.3086	.2957	.2865
24	.2743	.2915	.3142	.2772		.2957
Max	.3258	.3511	.3547	.3601	.3439	.3045
Min	.12	.1715	.1578	.1543	.1715	.1578
Avg	.2259	.2423	.2425	.2393	.2339	.2516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 203 / 11KV NIMBI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	18-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0762	.0312		
2	.061	.0762	.0312		
3	.061	.0762	.0316		
4	.061	.0762	.0312		
5	.061	.0762	.0457		
6	.061	.0762	.0655		
7	.061	.0762	.1147		
8		.0762	.108		
9	.061	.0762	.0937		
10	.0914	.061			.0648
11	.1219	.0617	.0914	.0457	.1219
12	.061	.0617	.0914	.0457	
13	.061	.0617	.0914	.0457	
14	.061	.0617	.0914	.061	
15	.061	.0617	.0914	.061	
16	.061	.0648	.0914	.061	
17	.0762	.0972	.0914	.061	
18	.0762		.0914		
19	.0076		.0914		
20	.0762		.0914		
21	.0762		.0914		
22	.0762		.0914		
23	.0762		.0914		
24	.061	.0762	.0312		
Max	.1219	.0972	.1147	.061	.1219
Min	.0076	.061	.0312	.0457	.0648
Avg	.0666	.0719	.0771	.0544	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 201 / 11 KV KOLSARA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6668	.724	.8076	.7842	.7217	.7621
2	.7621	.6668	.6859	.7799	.7842	.669	.7621
3	.7621	.6668	.6478	.784		.682	.6668
4	.724	.6668	.6097	.7209	.7468	.6199	.6668
5	.6859	.6668	.6097	.6632	.6722	.6108	.6668
6	.6478	.6287	.5716	.5932	.6348	.6108	.5716
7	.6478	.5335	.4572	.5527	.4294	.4422	.4572
8	.6097	.5906	.5716	.539	.5105	.5159	.5335
9	.6097	.6287	.5384	.5627	.4553	.4812	.4572
10	.5906	.6478		.5413	.559	.4924	.381
11	.5906	.6097			.1081	.5335	.4954
12	.6097	.6859		.5803		.1524	.5716
13	.6287	.6859	.6849	.5743	.1081	.2286	.6097
14	.6287	.6859	.6575	.596	.5464	.3048	.6097
15	.6478	.6859	.6682	.2633	.547	.2286	.6097
16	.6668	.5716	.6337	.5067	.5275	.2096	.5716
17	.4954	.5335	.6921	.4668	.5453	.4191	.5335
18	.7621	.5335	.5948	.5975	.6863	.4572	.6478
19	.7621	.8383	.7098	.7655	.5453	.7621	.6859
20	.8764	.9145	.8935	.9149	.8212	.8954	.8383
21	.8573	.8383	.8545	.8402	.7721	.8573	.8764
22	.8573	.8383	.8276	.9149	.7586	.7811	.8764
23	.8192	.8002	.7913	.8775	.7179	.7621	.8383
24	.7621	.6668	.724	.8076	.8215	.7209	.7811
Max	.8764	.9145	.8935	.9149	.8215	.8954	.8764
Min	.4954	.5335	.4572	.2633	.1081	.1524	.381
Avg	.6986	.6772	.6737	.6630	.5946	.5483	.6446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 202 / 11 KV BHATORI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.7621	.8002	.8642	.8215	.848	.7621
2	.7621	.7621	.7621	.7807	.7842	.7562	.7621
3	.7621	.7621	.7621	.7832	.7842	.7725	.7621
4	.724	.7621	.724	.7217	.7468	.7369	.7621
5	.724	.7621	.6859	.7324	.7095	.7034	.7621
6	.724	.7049	.6859	.6687	.6908	.5929	.6668
7	.6859	.5716	.6097	.5624	.5975	.5207	.4954
8	.6478	.6097	.5716	.5407	.4775	.5191	.5525
9	.6478	.6287	.5217	.5652	.4825	.5275	.4763
10	.4954	.5335		.5516	.5613	.4796	.6097
11	.5906	.5716			.5573	.6097	.6097
12	.6668	.6097		.5564	.6676	.6478	.6097
13	.6668	.6859	.5591	.5954	.6488	.6097	.6097
14	.6097	.6859	.6687	.578	.5877	.5767	.6097
15	.6097	.6859	.6682	.5816	.6428	.6668	.6478
16	.6097	.6478		.596	.6667	.6478	.6097
17	.6478	.6859	.7179	.6722	.6393	.6287	.5716
18	.6478	.6859	.6193	.5975	.6979	.5716	.724
19	.8383	.7621	.8212	.8775	.682	.7811	.8002
20	1.0098	.9907	.9643	.9709	.9126	1.0288	.9907
21	.9907	.9526	.9144	.9709	.8716	1.0288	.9907
22	.9526	.9145	.9332	.9522	.8788	.9145	.9907
23	.8954	.8383	.8983	.8962	.8792	.8954	.9145
24	.8002	.7621	.8002	.8441	.8402	.8471	.7811
Max	1.0098	.9907	.9643	.9709	.9126	1.0288	.9907
Min	.4954	.5335	.5217	.5407	.4775	.4796	.4763
Avg	.7296	.7224	.7344	.7156	.7012	.7046	.7113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 203 / 11 KV JAMBHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	19-APR-17
HR	Load (MW)
18	.724
Max	.724
Min	.724
Avg	.724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 204 / 11 KV POHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.1524	.1198	.1494	.1183	.1334
2	.1143		.1524	.121	.1494	.1183	.1334
3	.1143		.1334	.1198	.1494	.1196	.1334
4	.1143		.1334	.1195	.1494	.1236	.1334
5	.1143		.1334	.1043	.1307	.1183	.1334
6	.1334		.1334	.1048	.1307	.1195	.1143
7	.1143		.0953	.0855	.0934	.0847	.0953
8	.0953	.0953	.1143	.0854	.1014	.1012	.1143
9	.0953	.0953	.0844	.0898	.1025	.0845	.0953
10	.0953	.0953		.0845	.0847	.0847	.1143
11	.0953	.0953			.1171	.1143	.1143
12	.0953	.1143		.1014	.1183	.0953	.1524
13	.0953	.1143	.1009	.1037	.1183	.1143	.1524
14	.1143	.1143	.1014	.1077	.1176	.1014	.1334
15	.1143	.1143	.1016	.1001	.1183	.1143	.1334
16		.1143	.1032	.1013	.1001	.1143	.1143
17		.1143	.1011	.0934	.1179	.0953	.1143
18	.1143	.1334	.0847	.1494	.1183	.0953	.1524
19	.1524	.1334	.1142	.1494	.1183	.2096	
20	.1524	.1715	.1171	.1867	.1329	.1524	.1524
21	.1715	.1905	.1347	.168	.1352	.1524	.1715
22	.1715	.1715	.1367	.1494	.1186	.1524	.1715
23	.1524	.1524	.1338	.168	.1352	.1334	.1524
24	.1143		.1524	.1338	.1494	.1242	.1334
Max	.1715	.1905	.1524	.1867	.1494	.2096	.1715
Min	.0953	.0953	.0844	.0845	.0847	.0845	.0953
Avg	.1204	.1262	.1197	.1194	.1232	.1184	.1325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 401 / 33 KV Murtizapur Main I/C NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	28.1265	29.7623	***	***	***	***	29.5542
2	27.9636	29.4468	***	***	***	***	29.3416
3		28.2785	***	29.0124	***	***	29.3885
4	27.2577	26.3649	29.6868	28.5826	***	29.9257	29.0124
5	26.8776	25.5202	28.8466	28.2894	***	27.9379	28.2065
6	24.5428	25.7888	28.6226	28.0179	29.7989	27.9379	26.5947
7	23.9455	25.2515	27.7824	13.5746	26.7742	22.7801	21.9908
8	27.6378		27.0405	27.8007		26.4872	21.1797
9	22.0994		24.6091	27.7641	25.0892	28.0064	20.0903
10	28.2899			25.1349	18.2322	28.2305	22.979
11	***			27.9596	24.0793	29.5748	23.6626
12	29.7623			22.4314	19.189	26.9982	24.0833
13	29.3942		27.1622	22.3783	19.4548	27.2223	23.9712
14	26.4495		28.438	21.2757	24.3982	19.6605	***
15	27.1857		27.0279	21.0071	24.1856	19.7165	
16	29.3942			29.8183	25.4081	23.9175	
17	26.0288	24.2536	28.0179	28.2305	27.0405	23.6374	
18	23.6134	22.4612	24.3462	23.3014	26.769	22.1251	
19	27.9836	***	28.4523	***	***	***	27.5023
20	29.3416	***	***	***	***		***
21	28.5494	***	29.8183	***	***	28.9587	***
22		***	29.8149	29.9109	29.281	***	27.7229
23	29.3416	***	29.7137	***	***	29.3416	29.4102
24	28.398	***	***	***	***	***	***
Max	30.6036	34.896	32.2074	33.0225	33.1596	32.7733	32.0954
Min	22.0994	22.4612	24.3462	13.5746	18.2322	19.6605	20.0903
Avg	27.3994	28.8281	28.7896	27.4377	27.7090	27.4695	26.9599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 201 / 11 KV MANA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6001		.6344	.6516	.583	
2	.6173	.6001	.6344	.6173	.6344	.5658	.6344
3	.6001	.6001		.6173	.6173	.5658	
4	.6001	.6001	.6344	.6001	.6001	.5658	.6344
5	.583	.5487		.583	.6344	.5487	
6	.5658	.5487	.6001	.5658	.6001	.5316	.5658
7	.4973	.6001		.5658	.5658	.463	
8	.5144	.6173		.5658	.5316	.463	.4973
9	.5316	.5658	.5144	.6344	.583	.5487	.5788
10	.5975	.5316		.6173	.6516		.4481
11	.5975	.5316		.6001	.6001		.6722
12	.5788	.5316		.5658	.5658	.5316	.6535
13	.6099	.5144	.6687	.5658		.5658	.5415
14	.6099		.6859	.6001	.6687		.5601
15	.5914		.6859	.583	.6687	.6173	.6535
16	.6161		.6859	.6001			.6161
17	.5601		.6516	.6001		.6344	.5729
18	.6348		.6173	.583	.583		.5729
19	.8775	.7888	.7545	.6859	.6001	.6344	.5544
20	.8775	.8573	.7716	.7888	.703		.7947
21	.7468	.823	.7373	.7202	.6516	.7888	.8029
22	.7468	.823	.7202	.7545	.6344		.7655
23	.7282	.7545	.6859	.7202	.6516	.6859	.7842
24	.6344	.6722	.7545	.6516	.6687	.6001	.6687
Max	.8775	.8573	.7716	.7888	.703	.7888	.8029
Min	.4973	.5144	.5144	.5658	.5316	.463	.4481
Avg	.6306	.6373	.6752	.6259	.6222	.5820	.6286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 202 / 11 KV KURUM AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1823	.1543		1.0631	.9945	.7459	.2915
2	.1823	.1543	.1715	.9774	.9116	.7459	.2915
3	.1823	.1543		.9431	.9116	.7127	.2915
4	.1823		.1886	.8745	.8951	.6962	.2572
5	.1823	.1543		.8745	.9116	.7127	.2743
6	.1823	.1543	.1886	.9431	.9282	.7459	.3086
7	.1492	.1372		.9259	1.094	.7625	.3086
8	.1326	.1543	.1886	1.1317	.9448	.7459	.3772
9	.1326	.1715	.1029	1.0974	.7459	.6962	.3944
10	1.1145			.1886	.0995	.1372	.4458
11	1.4918			.12	.0995	.1372	.4458
12	1.3375	.7716		.1543	.116	.1372	.8573
13	1.3676	.7716	.12	.2058	.116	.1372	.7373
14	1.0288		.12	.12	.116		.8573
15	.9431			.1372	.0829	.1372	.7716
16	1.1488			.1543	.0829		.8059
17	1.1145		.0686	.1372	.0663	.12	.8573
18	.168		.0343	.1372	.0686		.1307
19	.1848	.9431	.12	.2058	.1326	.1543	.1867
20	.2054		.12	.2229	.1492	.1886	.1867
21	.2218	1.1145	.1886	.1886	.1326		.168
22	.2241		.1715	.1715	.116		.168
23	.2218	.1715	.1543	.1886	.116	.1543	.1494
24	.1823	.2033	.1715	1.0974	1.0974	.7293	.3086
Max	1.4918	1.1145	.1886	1.1317	1.0974	.7625	.8573
Min	.1326	.1372	.0343	.12	.0663	.12	.1307
Avg	.5193	.3722	.1406	.5108	.4554	.4524	.4113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 203 / 11 KV JAMATHI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4973		.0857	.12	.0686	
2	.4287	.4973	.2915	.0857	.1029	.0686	.0686
3	.3772			.0686	.1029	.0686	
4	.3944	.4973	.2915	.0686	.0857	.0686	.0514
5	.4115	.4973		.0686	.0857	.0686	
6	.4458	.4973	.2743	.0686	.0686	.0343	.0514
7	.5487	.4668		.0686	.0686	.0343	
8	.6001	.6001	.2743	.0514	.0686	.0343	.0514
9	.6344	.4287	.3429	.0686	.0343	.0343	.0343
10	.0686				.463	.4458	.0343
11	.0566	.0514		.463	.5487		.0514
12	.0514	.0514		.583	.5487	.6001	
13		.0514	.463	.6344	.4287		.0343
14	.0686		.5316	.4287		.4458	.0343
15	.0514		.2572	.4458			.0857
16	.0857		.5316	.5144	.4287	.463	.0514
17	.0514		.4458	.6173	.5487		.1372
18	.1307		.4287	.0686		.0514	.112
19	.0739	.0857	.1543	.0857		.0514	.112
20	.0934		.0686	.0686			.1307
21	.0924	.0857	.0857	.0857	.0514	.0514	.168
22	.112		.0686	.1029	.0686		.1307
23	.0924	.0514	.1029	.0857	.0686	.0686	.112
24	.3772	.462	.2743	.0857	.12	.0686	.0686
Max	.6344	.6001	.5316	.6344	.5487	.6001	.168
Min	.0514	.0514	.0686	.0514	.0343	.0343	.0343
Avg	.2467	.3214	.2875	.2132	.2112	.1515	.0800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 204 / 11 KV NAWASAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.6173		.7716	.7888	.9431	
2	.6344	.6173	.6001	.7373	.7888	.8916	.9431
3	.6344	.6173		.7373	.7716	.8916	
4	.6173	.6173	.6001	.703	.7373	.8573	.8573
5	.6001	.5658		.6687	.7373	.823	
6	.6001	.5658	.6173	.6516	.6859	.7888	.7716
7	.5316	.5144		.5658	.5316	.7716	
8	.6173	.5658	.5144	.6001	.6173	.7202	.6001
9	.6001	.5658	.2915	.6687	.6687	.7545	.7202
10	.5144			.6173	.2572	.6344	.6516
11	.6516	.6173		.6173	.7373		.7888
12	.4801	.6516		.583	.6516	.5658	
13	.5658	.5144	.3086	.6344	.7888		.4801
14	.6001		.7716	.583	.7545	.2915	.5144
15	.6344		.703	.7202			.5316
16	.6173		.7716	.703	.2572	.2572	.5144
17	.5487		.6173	.583	.2401		
18	.5658		.703	.6173	.7202	.2058	
19	.823	.703	.823	.8059	.9774		.3086
20	.823		.9259	.8916	1.1145	1.2003	.9774
21	.7716	.8402	.9088	.9431	1.0802		.9945
22	.7373		1.1488	.8573	1.1145	.9774	.9259
23	.7373	.7888	.8059	.8745	.9774	.9774	.8059
24	.6516	.703	.7373	.7888	.8059	.9945	.9774
Max	.823	.8402	1.1488	.9431	1.1145	1.2003	.9945
Min	.4801	.5144	.2915	.5658	.2401	.2058	.3086
Avg	.6330	.6291	.6970	.7052	.7306	.7526	.7272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 205 / 11 KV RAJURA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3734		.3258	.3601	.3601	
2	.3601	.3734	.3258	.3258	.3601	.3601	.2915
3	.3429	.3734		.3258	.3429	.3601	
4	.3429	.3734	.3258	.3258	.3429	.3429	.2915
5	.3258	.2987		.2915	.3258	.3429	
6	.2743	.2987	.2401	.2572	.2743	.2743	.2058
7	.1886	.1867		.2058	.2058	.1886	
8		.1886	.1715	.0686	.1715	.1543	.1372
9	.1372	.1715	.2229	.0343	.1543	.1543	.1698
10	.1698	.1715		.4287		.1543	.1132
11	.2263			.2572	.2058		.1509
12	.2801	.2401		.2401	.2572	.2401	.2452
13	.3361	.2743	.3086	.2915	.2915		.2801
14	.3584			.2915	.3258	.2915	.2801
15	.3547		.2915	.2915	.3086		.2801
16	.3206		.2915	.2915	.2572	.2743	.2801
17	.2641		.2401	.2229	.2058		.1886
18	.2075		.1886	.1886	.1886	.0686	.168
19	.3734	.2743	.2915	.3086	.2743		.2054
20	.4338	.3772	.3772	.3944	.3944	.2572	.3921
21	.4435		.3429	.4115	.4115		.4294
22	.4435	.3772	.3772	.4287	.3944	.3258	.4294
23	.4108	.3601	.3601	.3772	.3601	.2915	.4294
24	.3772	.3921	.3429	.3258	.3601	.3429	.3258
Max	.4435	.3921	.3772	.4287	.4115	.3601	.4294
Min	.1372	.1715	.1715	.0343	.1543	.0686	.1132
Avg	.3188	.3003	.2936	.2879	.2945	.2658	.2647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 201 / 11 KV DAHATONDA AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2721	.2656	.3239		
2			.2721	.2656	.3239		
3			.2721	.2656	.3239		
4			.2688	.2623	.3239		
5			.2721	.3437	.3239		
6			.3201	.3749	.4049		
7			.4321	.4374	.4858		
8			.4801	.4374	.6802		
9				.4012	.4858		
10	.6036		.2721			.6371	.5182
11	.6203	.5138				.6371	.1951
12	.5967	.4973				.5304	.1463
13	.503	.4641				.3315	.0732
14	.3887						.1219
15	.3887	.3391					.2846
16	.421	.4409				.3647	.3795
17	.5182	.4973				.4641	.4191
24			.2721	.2623	.3239		
Max	.6203	.5138	.4801	.4374	.6802	.6371	.5182
Min	.3887	.3391	.2688	.2623	.3239	.3315	.0732
Avg	.5050	.4588	.3134	.3316	.4000	.4942	.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 202 / 11 KV SHIVAN FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3222	.3086	.3052	.2915	.3018	.3353	.2401
2	.3258	.3086	.3052	.2984	.3018	.3391	.2401
3	.3222	.3086	.2883	.2818	.3018	.3353	.2401
4	.3222	.3086	.2883	.285	.3018	.3391	.2401
5	.3258	.3086	.2883	.2543	.3018	.3222	.2401
6	.3391	.2743	.2883	.2401	.2683	.3222	.2401
7	.3561	.3086	.3052	.3086	.3018	.3222	.2401
8	.3601	.3429	.3391	.4115	.3353	.39	.2915
9	.4115	.3772		.431	.3688	.4409	.2915
10	.3772			.3978	.3353	.407	.2267
11	.3258	.2543		.3315	.3315	.4409	.0972
12	.3258	.2713		.3149	.218	.3856	.0914
13	.218	.2374		.3315	.2713	.3647	.0857
14	.2458		.3437	.3018	.3222		.1029
15	.3018	.116	.3239	.3018	.3018		.3086
16	.2785	.3018	.3163	.3149	.3018		.3429
17		.2984	.3201	.3353	.3391		.2652
18	.407	.3978	.3887	.3353	.39		.2321
19	.4239	.3647	.4024	.3688	.4191		.4641
20	.4287	.3149	.373	.4024	.4578	.2572	.4694
21	.3772		.3772	.3772	.4239	.2572	.4115
22		.2984	.3772	.3429	.407	.2401	.4458
23	.3086	.2984	.3401	.3086	.373	.2401	.3772
24	.3391	.3086	.3018	.2915	.3018	.3688	.2401
Max	.4287	.3978	.4024	.431	.4578	.4409	.4694
Min	.218	.116	.2883	.2401	.218	.2401	.0857
Avg	.3383	.3004	.3301	.3274	.3324	.3393	.2677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 203 / 11 KV UMRI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.8573	.9054	.7545		1.0513	1.166
2	.7888	.8573	.9054	.7545		1.0513	1.166
3	.7888	.5601	.9054	.7042		1.0513	1.1317
4	.78	.8402	.8987	.7042		1.1694	1.1317
5	.7888	.823	.8987	.6706		1.1694	1.0974
6	.8139	.823	1.0562	.6036		1.0852	1.0288
7	.7888	.9945	1.0513	.8718		1.2826	1.1145
8	.9156	1.0288	1.0513	1.1065		1.4146	1.2346
9	.8916	1.153		.6249		1.4712	1.2346
10	.8916			1.2308	.6371	1.4335	1.2003
11	.9602	.9602		1.2597	.6706	1.0852	1.0059
12	.8916	.823		1.1603		1.0852	1.0059
13	.9602	.823		.7377	.6783	.9496	1.0059
14	.9054		.6097	1.1065	.6001		.8718
15	.8383	.8478	.6478	1.0898	.6173		.8718
16	.8951	1.0174	.7209	1.1736	1.0631		.2347
17	1.1401	1.1233	.8421	1.3413	1.2346	.8139	1.0174
18	1.2742	1.2209	1.0059	1.3413	1.2346	1.153	1.1949
19	1.2003	1.2887	.9389	1.0974	1.5432	1.166	.9602
20	1.166	1.0059	.8421	1.0974	1.4232	1.166	1.3717
21	1.0288	.9665	.8421	1.166	1.3565	1.166	
22	1.0288	1.0174	.823		1.286	1.2003	
23	.9602	.9054	.7459		1.1488	1.166	.7293
24	.8402	.8573	.9496	.7716		1.2071	1.166
Max	1.2742	1.2887	1.0562	1.3413	1.5432	1.4712	1.3717
Min	.78	.5601	.6097	.6036	.6001	.8139	.2347
Avg	.9303	.9452	.8758	.9713	1.0380	1.1590	1.0428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 204 / 11 KV KHANDALA W/W EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1372	.1698	.1372	.1341	.1357	.1372
2	.132	.1372	.1698	.1372	.1341	.1509	.1372
3	.132	.1372	.1509	.1372	.1341	.1357	.1372
4	.12	.0686	.1509	.1372	.1341	.1509	.1372
5	.132	.0686	.1509	.0526	.1341	.1357	.0686
6	.132	.0686	.1509	.0526	.1341	.1494	.0686
7	.132	.1372	.1509	.1227	.1174	.1494	.1372
8	.0366	.12	.1509	.1227	.1341	.1187	.1372
9	.0686	.0686		.12	.1341	.1187	.1372
10	.0686			.12	.1341	.0678	.1372
11	.0686	.0366		.1341	.1187	.1698	.1372
12	.0686	.1494		.1174	.132	.1372	.0686
13	.1372	.1509		.1174	.132	.12	
14	.1372		.1543	.1174	.1307	.1357	.0514
15	.1372	.1494	.1372	.1174	.132	.0678	.1543
16	.1357	.1109	.1372	.1174	.132	.0848	.1029
17	.1341	.1698	.1543	.0838	.1509	.0678	.0848
18	.0671	.032	.1372	.0671	.0335	.0678	.0678
19	.0686	.0419	.1372	.0686	.0747	.0686	.0678
20	.0686	.0328	.1372	.0686	.0351	.0686	.0747
21	.0686	.0335	.1372	.0686	.1698	.0857	.1372
22	.1372	.1494	.1372	.1372	.1509	.1372	.1372
23	.1372	.1509	.1372	.1372	.1509	.1372	.12
24	.1509	.1372	.1698	.1372	.1341	.1357	.1372
Max	.1509	.1698	.1698	.1372	.1698	.1698	.1543
Min	.0366	.032	.1372	.0526	.0335	.0678	.0514
Avg	.1084	.1040	.1485	.1095	.1251	.1165	.1120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 205 / 11 KV MURAMBA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.775	.7582	.7571	.7211	.8428	.7371	.7411
2	.775	.7411	.7571	.7211	.8428	.7771	.7411
3	.775	.7411	.7571	.7211	.7666	.7371	.7411
4	.775	.7411	.7392	.7211	.7666	.7371	.6477
5	.775	.7239	.7392	.7211	.7498	.7032	.6306
6	.7034	.7068	.7213	.7049	.7331	.7201	.6134
7	.5376	.5791	.5913	.6287	.5731	.6439	.5449
8	.5913	.5029	.6451	.6287	.5731	.6439	.5791
9	.6477	.6134	.3048	.7163	.5304	.6439	.5963
10	.6306	.2286		.6066	.3048	.5761	.6134
11	.7411	.4972		.6066	.5731	.6066	.5866
12	.7582	.6272		.6066	.3048	.5866	.4607
13	.7582	.7392	.381	.6066		.5591	.57
14	.7411	.381	.6725	.6233	.3326	.6032	.57
15	.5868	.6272	.6077	.7163	.6952	.61	.57
16	.4298	.6272	.5963	.6233	.634	.57	.6032
17	.6066	.6093	.6287	.6066	.5974	.2881	.6032
18	.6401	.6988	.6935	.6439	.7136	.5761	.6363
19	.7582	.775	.7559	.7834	.8061	.6477	.7457
20	.9202	1.0349	.8634	.903	.9192	.8687	.9213
21	.903	1.0349	.8459	.903	.9144	.8173	.8882
22	.8687	.9228	.8504	.903	.1524	.7754	.855
23	.8687	.887	.8472	.903	.8268	.7582	.7457
24	.7929	.8344	.775	.826	.7834	.754	.7411
Max	.9202	1.0349	.8634	.903	.9192	.8687	.9213
Min	.4298	.2286	.3048	.6066	.1524	.2881	.4607
Avg	.7233	.6930	.6919	.7144	.6494	.6642	.6644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 206 / 11 KV BIDGAON GF

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1698	.1543	.168	.1658	.1715
2	.1886	.1886	.1698	.1543	.168	.1696	.1886
3	.1886	.1886	.1698	.1543	.168	.1696	.1886
4	.1886	.1886	.1698	.1543	.168	.1658	.1698
5	.1886	.1886	.1698	.1543	.168	.1658	.1509
6	.1698	.1509	.1509	.1372	.168	.1326	.132
7	.1132	.0943	.1132	.0857	.1307	.0995	.0754
8	.0943	.0754	.1132	.1029	.0934	.0829	.0754
9	.056	.0566		.0671	.0934	.0663	.056
10	.0747			.0686	.056	.0663	.056
11	.056	.0566		.0934	.0934		.0503
12	.0747	.0754		.0934		.0678	.0671
13	.0747	.0566		.112		.0663	.0671
14	.0934		.1029	.112	.0754	.1017	.0838
15	.0934	.0943	.0857	.112	.112	.0848	.1006
16	.0747	.0943	.0995	.0934	.1132	.1017	.1006
17	.0934	.0754	.1147	.0943	.112		.1029
18	.1307	.0566	.0829		.112	.0848	.0857
19	.168	.2075	.1619	.132	.1698	.1494	.1715
20	.1867	.132	.1658	.1886	.1867	.1867	.1823
21	.2075	.132	.1715	.1886	.2075	.1886	.1844
22	.2075	.0943		.1886		.1698	.1677
23	.2075	.1886	.1715	.1886	.1886	.1886	.3688
24	.1886	.2075	.1698	.1543	.1867	.1677	.1886
Max	.2075	.2075	.1715	.1886	.2075	.1886	.3688
Min	.056	.0566	.0829	.0671	.056	.0663	.0503
Avg	.1378	.1269	.1418	.1297	.1399	.1292	.1327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 207 / 11 KV DHANORA P GF

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6413	.6602	.5868	.7095	.5801	.6602
2	.6602	.6413	.6602	.6001	.7095	.5801	.6602
3	.6602	.6413	.6602	.5868	.6908	.5868	.6602
4	.6602	.6413	.6413	.5533	.6908	.5868	.6413
5	.6413	.6224	.6413	.5658	.6722	.5596	.6036
6	.5847	.5847	.6036	.503	.6348	.5636	.547
7	.5281	.5281	.4527	.4359	.5041	.4527	.4715
8	.4715	.4338	.4338	.4024	.3921	.4144	.4527
9	.4481	.4338		.4115	.3921	.3812	.415
10	.4294			.3887	.3734	.3856	.4108
11	.4108	.415		.4108	.3547	.3481	.3944
12	.4668	.415		.4294		.3978	.3772
13	.4854	.5093		.4668		.4239	.4973
14	.4854		.4424	.4854	.5601	.4578	.4287
15	.4854	.4527	.4475	.5041	.547	.4409	
16	.4481	.4338	.4359	.4668	.5041	.4239	.4191
17	.3921	.415	.3887	.3921	.4338	.3647	.3353
18	.415	.415	.3906	.4481	.4338	.373	.3185
19	.6602	.7356	.5992	.679	.6602	.6535	.6036
20	.7545	.7167	.6952	.7733	.7167	.7095	.6783
21	.7545	.7167	.6241	.7356	.7356	.7356	.7202
22	.7167	.7356	.6401	.7356		.7356	.7545
23	.6979	.7167	.6299	.7733	.6908	.6979	.6516
24	.679	.6602	.679	.5967	.7095	.5801	.6602
Max	.7545	.7356	.6952	.7733	.7356	.7356	.7545
Min	.3921	.415	.3887	.3887	.3547	.3481	.3185
Avg	.5665	.5684	.5645	.5388	.5769	.5181	.5375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 201 / 11 KV SIRSO AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.061	.0903		
2			.0602	.0452	.0903		
3			.0602	.0452	.0903		
4			.0753	.0452	.0903		
5			.0753	.0753	.0903		
6			.0903	.1054	.0903		
7			.1054	.1656	.1355		
8			.1957	.1806	.1656		
9			.1783	.1806	.1806		
10	.1505	.216				.1524	.1355
11	.1656	.1783				.2134	.1656
12	.1957	.2229				.1543	.1656
13	.1806	.104				.1486	
14	.1067	.104				.1235	.1505
15	.1219	.1054					.1355
16	.1524	.1189				.1337	.1355
17	.1829	.1932				.1486	
23				.0903			
24			.0602	.0762			
Max	.1957	.2229	.1957	.1806	.1806	.2134	.1656
Min	.1067	.104	.0602	.0452	.0903	.1235	.1355
Avg	.1570	.1553	.1001	.0973	.1137	.1535	.1480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 202 / 11 KV HIRPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3734	.4108	.3326	.4108	.3841	.3734
2	.3658	.3734	.4108	.3142	.4108	.3841	.3734
3	.3109	.3734	.3921	.2772	.3734	.3841	.3734
4	.2561	.3734	.3921	.2772	.3734	.3841	.3734
5	.2587	.3734	.3921	.2772	.3734	.3841	.3361
6	.2402	.3174	.3361	.2957	.3174	.3109	.3174
7	.2402	.2402	.2195	.2218	.2801	.2195	.2614
8	.3142	.2353	.2801	.2218	.2614	.1829	.2054
9	.2587	.2507	.1867	.2195	.2241	.2012	.2241
10	.2149	.1612		.2561	.2054	.2195	.2614
11	.2195	.2378		.2378	.2218	.2012	.2195
12	.2195	.2743		.2561	.2378	.2378	.2378
13	.2926	.2926	.3326	.2926	.2561	.2743	.2743
14	.3109	.3292	.7207	.3292	.3292	.2743	.2926
15	.3292	.3292	.3142	.3292	.3109		.2926
16	.2926	.3109	.2957	.2926	.2926	.2926	.2926
17	.2378	.2378	.2561	.2561	.2561	.2195	.2378
18	.2328	.2195	.2378	.2378	.2012	.2195	.2054
19	.3109	.3475	.3475	.3109	.3109	.2743	.3109
20	.3841	.3841	.4207	.4024	.3841	.3658	.3921
21	.3921	.4066	.3841	.4024	.3658	.3734	.4108
22	.4294	.4294	.4024	.4294	.4294	.4108	.4108
23	.4294	.4294	.4207	.4481	.4294	.5228	.4294
24	.4024	.4108	.4108	.4108	.4108	.4108	.4108
Max	.4294	.4294	.7207	.4481	.4294	.5228	.4294
Min	.2149	.1612	.1867	.2195	.2012	.1829	.2054
Avg	.3045	.3213	.3602	.3054	.3194	.3101	.3132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 203 / 11 KV PUNDLIK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.8852	.8722	.8186	.9602	.9058	.9157
2	.2772	.8307	.7861	.7904	.9411	.8852	.857
3	.2402	.8044	.7655	.7418	.9	.4386	.8467
4	.2402	.7213	.7178	.7101	.9049	.4188	.8326
5	.2218	.711	.7068	.6994	.8823	.41	.8299
6	.2218	.7007	.7068	.7447	.8574	.4371	.8235
7	.3326	.8103	.8928	.9408	.813	.9848	1.0121
8	.3326	.9977	1.0354	1.0446	.8549	1.0993	1.0208
9	.4805	1.146	1.0086	1.1298	1.0209	1.196	1.0104
10	.6838	1.23	.495	1.3778	1.1816	1.3557	1.0658
11	.6283	1.2738		1.4975	1.2299	1.2763	1.1042
12	.6653	1.3905		1.5301	1.3071	1.2963	1.0968
13	.6099	1.4024	.7293	1.5282	1.2901	1.3845	.974
14	.499	1.2102	1.4636	1.5308	1.2875	1.3985	.784
15	.5544	1.1357	1.432	1.4059	1.3702	.6001	.7155
16	.5544	1.1458	1.2205	1.2807	1.1183	1.1698	.6203
17	.5544	1.1662	1.2809	1.1971	1.1709	1.1788	.577
18	.5175	1.1631	1.1425	1.1973	1.2633	1.0917	.5323
19	.4805	1.1003	1.1378	1.1612	1.1938	1.1166	.5615
20	.499	1.0302	1.1442	1.157	1.0825	1.0854	.6354
21	.4435	.9518	1.0442	1.12	.9507	.9134	.6736
22	.462	.9425	.9705	1.0624	1.009	1.0027	.7314
23	.4435	.9564	.9671	1.088	1.0271	1.0046	.7542
24	.2957	.9301	.9277	.9631	1.0195	.9989	.8852
Max	.6838	1.4024	1.4636	1.5308	1.3702	1.3985	1.1042
Min	.2218	.7007	.495	.6994	.813	.41	.5323
Avg	.4389	1.0265	.9749	1.1132	1.0682	.9854	.8275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 201 / 11 KV KHADAKA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4031	.407	.4435	.4525	.4239	.4835	.9774
2	.4031	.407	.4435	.4525	.407	.4656	.9774
3	.3982	.407	.4435	.4207	.3944	.4557	.9774
4	.3982	.4239	.4435	.4207	.3944	.4733	.905
5	.4031	.4115	.4298	.4207	.3772	.4382	.8413
6	.4458	.4287	.4191	.4207	.3944	.4031	.8063
7	.3944	.3772	.3932	.3772	.4115	.3506	.6415
8	.3481	.4115	.4111	.4024	.4458	.2915	.5765
9	.3353	.426	.3841	.39	.4527	.2401	.5658
10	.3121			.3601	.4588	.2715	.3601
11	.3688	.373		.3772	.4588	.2715	.3601
12	.3688	.3612		.463		.3681	.3086
13	.3353	.3858	.4917	.2401		.4191	.3429
14	.3353		.4748	.4458		.4239	.3601
15	.431	.2972	.3856	.407	.4458	.4024	.3601
16	.3978	.3222	.373	.4239	.3841	.3441	.3292
17	.4024	.2883	.3772	.3944	.3658	.3441	.3292
18	.4527	.3269	.3953		.3841		
19	.5197	.4557	.583	.5658	.5544	.9189	.4854
20	.4973	.5194	.5895	.503	.6219	.9465	.5434
21	.4973	.5194	.5895	.4862	.567		.5258
22	.4973	.5552	.5548	.4527	.5194	1.1584	.6135
23	.4973	.5194	.5434	.503	.5373	1.1403	.5014
24	.4031	.4287	.4435	.4805	.407	.5014	1.0136
Max	.5197	.5552	.5895	.5658	.6219	1.1584	1.0136
Min	.3121	.2883	.373	.2401	.3658	.2401	.3086
Avg	.4102	.4115	.4577	.4287	.4479	.5051	.5957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 202 / 11KV SONORI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.2881	.2229			.2115
2	.0572	.2915	.2229			.2115
3	.0572	.2753	.2229			.2115
4	.0572	.2915	.2229			.2115
5	.0572	.3239	.2317			.2462
6	.0572	.3605	.2397			.2824
7		.4752	.257			.3658
8		.5243	.3429			.4268
9		.3841	.4064			.3749
10				.4801	.4167	
11				.4641	.4999	
12				.426	.4843	
13			.2824	.3277	.4218	
14			.2675	.2458	.3353	
15			.2896		.2378	
16			.3506		.2408	
17			.4012	.2012	.1372	
21						.5258
24	.0572	.2561	.2229			.2115
Max	.0572	.5243	.4064	.4801	.4999	.5258
Min	.0572	.2561	.2229	.2012	.1372	.2115
Avg	.0572	.3471	.2789	.3575	.3467	.2981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 203 / 11 KV KURANKHED AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4401	.4001	.016	
2			.4572	.4321	.016	
3			.439	.426	.0164	
4			.4572	.3932	.0164	
5				.3932	.0164	
6				.4752	.0164	
7					.0164	
8			.7282		.0164	
9			.6093			
10	.5569			.0714		.5601
11	.5155	.5864		.0572	.4938	.5761
12	.4108	.4172			.5624	.5441
13	.2751	.4365			.5498	.5243
14	.2751				.5418	.4752
15	.2896				.431	.5407
16	.4458				.2976	.5093
17					.5357	.578
18		.0191			.5075	
19	.503				.4054	
24			.415	.3841	.032	
Max	.5569	.5864	.7282	.4752	.5624	.578
Min	.2751	.0191	.415	.0572	.016	.4752
Avg	.4090	.3648	.5066	.3369	.2493	.5385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 201 / 11KV NAGOLI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	1.4861	1.7734	1.816	1.0082	.9145	1.8195
2	1.4571	1.4499	1.7547	1.7833	.9709	1.8004	1.6309
3	1.2613	1.4137	1.6987	1.7741	.9335	1.8359	1.5947
4	1.2613	1.2251	1.6613	1.7471	.9335	1.8004	1.5223
5	1.1889	1.1889	1.5089	1.765	.9709	1.8004	1.4137
6	1.1889	1.195	1.5836	1.7558	1.0082	1.7741	1.3413
7	1.195	1.1584	1.5463	.9145	.9313	1.8099	1.4137
8	.4572	.6097	1.6309	.9145	1.0669	1.7741	.6097
9	1.0002	.9716	1.5771	1.5169	1.9174	1.736	1.2613
10	1.4956	.3048		1.5169	1.4575	1.3253	1.5211
11	1.8713	1.8301		1.3261	1.0364	1.0951	1.7467
12	1.9067	.9145		1.3184	1.0596	1.2072	1.5851
13	2.0614	1.7375	.6097	1.3184	1.2476	1.2819	1.5509
14	1.9067	.9145	1.4137	1.3184	1.2476	1.2445	1.5509
15	1.8713	1.5509	1.2121	1.4708	1.2476	1.2072	.7621
16	.9145	1.7718	1.1927	1.283	1.5063	1.2819	.9145
17	2.1167	1.9227	1.1241	1.0173	1.4282	1.3565	.9145
18	1.4403	1.4746	1.1927	1.2445	1.2407	1.2445	.9145
19	.9953	1.3565	1.3794	1.2819	1.4072	1.4343	2.1872
20	1.4861	1.5836	1.3931	1.5089	1.4743	1.4716	1.736
21	1.7757	1.621	1.5943	1.5836	1.5249	1.4716	1.621
22	1.5509	1.5089	.9145	1.2289	1.5859	1.1965	1.6217
23	1.5585	1.6583	.9145	1.7833	1.6309	1.8458	1.8099
24	1.5223	1.5223	1.8107	1.7757	1.9281	1.8458	1.8195
Max	2.1167	1.9227	1.8107	1.816	1.9281	1.8458	2.1872
Min	.4572	.3048	.6097	.9145	.9313	.9145	.6097
Avg	1.4571	1.3488	1.4041	1.4568	1.2818	1.4898	1.4526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 203 / 11 KV TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.633	5.0259	5.2621	5.1783	5.426	5.2145	4.2524
2	2.4615	4.7839	4.9844	4.856	5.2412	5.0869	4.1362
3	2.3396	4.5458	4.7539	4.6967	4.9916	4.9287	2.0271
4	2.2481	4.3419	4.5801	4.3671	4.8628	4.7458	1.9433
5	2.13	4.1297	4.3576	4.0619	4.5587	4.5869	3.5422
6	2.0424	3.8843	4.1244	3.9407	4.3096	4.2799	3.293
7	1.9395	3.6946	3.8653	2.1148	3.9437	3.8767	4.3058
8	1.9547	1.9052	3.6991	1.9547	1.9852	3.6588	2.5111
9	3.536	1.7375	3.597	3.4998	3.4274	3.5612	1.7993
10	3.5455		1.8023	3.4369	3.5246	3.5193	1.3801
11	3.7579	.9831		3.7189	3.8066	3.7829	.7202
12	3.8988	1.105		2.0652	4.0409	3.9194	2.0386
13	2.069		5.3898	.2782	4.1533	4.1785	3.4751
14	4.3202	2.8273	5.4108		4.4924	4.68	5.3726
15	4.5253	2.6368	5.2869		4.7458	4.862	5.3726
16	2.3472	3.3417	5.2907	3.0407	4.8106	3.0041	5.3269
17	4.2562	4.8201	4.7915	6.1881	4.6144	3.5338	5.0617
18	4.0832	4.6045	4.4506	5.7644	4.4277	3.3608	4.5382
19	4.1952	4.6647	4.4448	5.4511	4.3591	3.3303	4.6114
20	4.5673	4.7802	4.9059	5.426	4.6258	4.2257	5.0023
21	4.6133	4.7805	4.9032	5.3239	4.726	4.1732	5.1974
22	4.7287	4.9253	4.8636	5.4954	4.8697	4.0218	5.1776
23	5.0373	5.2767	5.3422	5.4774	5.1723	4.1285	5.2081
24	2.6635	5.1535	5.4717	5.4291	5.346	4.7439	2.7968
Max	5.0373	5.2767	5.4717	6.1881	5.426	5.2145	5.3726
Min	1.9395	.9831	1.8023	.2782	1.9852	3.0041	.7202
Avg	3.3289	3.8158	4.6172	4.1712	4.4359	4.1418	3.7121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 204 / 11KV Goyanaka fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7697	1.5775	1.4575	1.6004	1.5965	1.6255	1.6736
2	.743	1.4456	1.4159	1.4857	1.4792	1.528	1.6065
3	.7049	1.3497	1.2872	1.3458	1.4343	1.4571	1.5051
4	.6935	1.3093	1.2345	1.2726	1.3969	1.3421	1.4014
5	.6325	1.2521	1.1964	.7164	1.3207	1.2327	1.3241
6	.6363	1.1698	1.2415	1.1386	1.2529	1.1805	1.2788
7	.6059	1.1831	1.2041	.5982	1.1641	1.1576	1.1156
8	.5335	.5906	1.1622	1.086	.6059	1.1755	1.1203
9	.942	.5944	1.0013	.9382	1.2193	1.124	1.0288
10	.8711	.6592	.5258	1.1363	1.2727	1.211	1.0349
11	.9153	1.1934		1.2422	1.8681	1.1477	1.2155
12	1.0479	.6211		1.3394	1.5185	1.1881	1.3375
13	1.1302	1.3794	1.7284	1.368	1.6194	1.4038	1.3527
14	1.1736	.7087	.8535	1.4708	1.5718	1.467	1.3908
15	1.243	1.5131	1.6179	1.5375	1.576	1.6149	1.5165
16	.6478	1.5394	1.6252	1.6255	1.6088	1.5508	1.6377
17	1.1888	1.4991	1.5089	1.6682	1.5547	1.4762	1.5486
18	1.0468	1.4045	1.4899	1.5105	1.4556	1.3893	1.3031
19	1.0277	1.5798	1.4194	1.5988	1.4404	1.4708	1.3047
20	1.2319	1.419	1.4395	1.544	1.467	1.5615	1.2681
21	1.2563	1.3733	1.4442	1.4457	1.4442	1.5188	1.3276
22	1.2833	1.4228	1.5676	1.6248	1.5105	1.4899	1.4061
23	1.5227	1.5204	1.6823	1.7376	1.7166	1.6899	1.5966
24	.8307	1.5829	1.6308	1.6911	1.7147	1.6633	1.666
Max	1.5227	1.5829	1.7284	1.7376	1.8681	1.6899	1.6736
Min	.5335	.5906	.5258	.5982	.6059	1.124	1.0288
Avg	.9449	1.2453	1.3515	1.3634	1.4504	1.4028	1.3734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 205 / 11 KV MIDC IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.1776	.1486	.1585	.1562	.1304
2		.1334	.1776	.1463	.1547	.157	.1304
3		.1143	.1319	.0347	.1204	.1151	.1075
4		.1219	.1661	.0343	.064	.1128	.1158
5		.1219	.1623	.0339	.0564	.1056	.1006
6		.1143	.17	.0343	.0525	.117	.1349
7		.1219	.17		.1173	.1208	.1577
8	.061	.1219	.1524	.0038	.0762	.1044	.1547
9		.1997	.0442	.157	.1848	.1249	.1554
10	.1463	.1257		.2896	.242	.1554	.1334
11	.3277	.1753		.3467	.3277	.2393	.282
12	.362	.1791		.3658	.3368	.2843	.3087
13	.3544	.1791	.1097	.3239	.3178	.3704	.3468
14	.1715	.16	.2138	.1829	.2621	.3776	.3101
15	.2621	.1372	.224	.3201	.2545	.1715	.2942
16	.1677	.1715	.2267	.2934	.2294	.2728	.2942
17	.1677	.2682	.1905	.3094	.2134	.2614	.2682
18	.2401	.253	.1677	.3132	.2172	.2462	.1966
19	.1639	.2717	.16	.3094	.2191	.2424	.0373
20	.2374	.2641	.1638	.2942	.1912	.2424	.0373
21	.2309	.2416	.1562	.2004	.1768	.2271	.0373
22	.2286	.2043	.1524	.1776	.1715	.2066	.0362
23	.2382	.2111	.1562	.2248	.1562	.1554	.0358
24	.1334	.25	.1547	.1554	.1524	.16	.0724
Max	.362	.2717	.2267	.3658	.3368	.3776	.3468
Min	.061	.1143	.0442	.0038	.0525	.1044	.0358
Avg	.2183	.1783	.1632	.2043	.1855	.1969	.1616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 206 / 11 KV Water /W EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.0938	.1596	.1752	.2545	.1692	.1399
2	.2229	.1121	.2358	.1733	.2358	.197	.1962
3	.2229	.1121	.2263	.1839	.2263	.2057	.1962
4	.2229	.1121	.2263	.2029	.2263	.224	.2145
5	.224	.0938	.2263	.2029	.2263	.224	.2062
6	.2229	.0938	.2263	.2124	.2263	.2057	.1877
7	.2229	.0656	.2263	.1048	.2218	.1513	.1323
8	.1143	.0381	.2229	.0857	.1143	.0846	.1667
9	.0923	.0724	.224	.0747	.2423	.0754	.1667
10	.0747	.0381		.0747	.2229	.0754	.1734
11	.0842	.0819		.0747	.2229	.0754	.181
12	.0842	.0732		.0747	.2423	.1501	.1654
13	.0842	.0286	.1781	.0747	.1143	.2263	.181
14	.0747	.0476	.123	.2029	.224	.2263	.1574
15	.1208	.0724	.0747	.2492	.224	.1887	.0667
16	.0572	.0915	.0724	.2492	.224	.1887	.0667
17	.0895	.1882	.2077	.245	.2195	.1326	.1048
18	.1098	.2077	.2172	.1703	.201	.0754	.1608
19	.1098	.1887	.216	.1135	.1402	.0754	.0849
20	.1086	.1506	.2195	.0754	.1018	.0754	.0754
21	.0923	.0945	.2195	.0754	.0724	.0754	.0754
22	.0724	.0754	.216	.0754	.0739	.0743	.0739
23	.0743	.0754	.1896	.0743	.0739	.0743	.1456
24	.1478	.0838	.1977	.1286	.0743	.0838	.141
Max	.224	.2077	.2358	.2492	.2545	.2263	.2145
Min	.0572	.0286	.0724	.0743	.0724	.0743	.0667
Avg	.1314	.0955	.1955	.1406	.1836	.1389	.1442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 207 / 11 KV ANBHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	18-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955				
2	1.2955				
3	1.2955				
4	1.2193				
5	1.2193				
6	1.2193				
7	1.2955				
8	1.0669				
9	2.2771				
10	2.13				
11	1.1431				
12	1.1431	.0762		.7468	
13	1.6232	.4572		1.1431	
14	1.3184		1.7791	.381	
15			.2286		
16		.7888		1.8824	
17		2.6025		2.3022	1.448
18	.2713	2.9417		2.5651	1.5242
19	1.7876	3.1874	.0762	2.7145	1.6004
20	3.3303	3.357		2.9805	3.4332
21	.8383	3.1314		3.0179	3.3196
22				3.1242	2.9927
23				1.6004	1.448
Max	3.3303	3.357	1.7791	3.1242	3.4332
Min	.2713	.0762	.0762	.381	1.448
Avg	1.4316	2.0678	.6946	2.0416	2.2523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 208 / 11KV J.K. GINING

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.482	3.3829	3.245	3.0247	3.4332	3.2713	3.0179
2	.482	3.2713	3.2076	2.9112	3.357	3.2358	2.9062
3	.4096	3.1242	3.0941	2.9264	3.2434	3.1242	2.7946
4	.3334	3.1047	3.0567	2.8152	3.2061	2.9771	2.7733
5	.3334	2.9615	2.9805	2.8152	3.1688	2.9062	2.8091
6	.4096	2.8853	3.0179	2.6399	3.1314	2.7778	2.8449
7	.3334	2.8495	2.716	1.3717	3.1047	2.5225	2.5537
8	.1524	1.448	2.6154	1.3717	1.5242	2.8449	.3353
9	.2896	1.3717	2.5003	2.4901	2.729	2.6787	.2987
10	.2987	1.2955		2.6067	.2972	2.6787	.2896
11	.3353	1.2193		2.6829	.2941	2.6787	.3315
12	.3353	.9907	.9145	2.5411	.2941	1.5211	.4001
13	.4115	.1524	3.2713	2.6474	.2987	.3018	.3582
14	.4481	.1524	2.6883	.8631	1.7281	1.9586	.3277
15	.4481	.1524	2.495	1.648	1.4655	1.2536	.4527
16	.1524	.1524	1.3717	1.9528	3.1189	.1524	.5273
17	.2896	.3018	2.835	.5335	3.3467	.4153	.4153
18	.2896	.3018	2.4059		3.4408	.378	.4153
19	.2372	.3391	2.8853	3.7319	3.6542	.4153	.3391
20	.4321	.4153	3.4568	3.9247	3.6618	.4153	.4153
21	3.6389	.4915	3.4766	3.6961	3.5513	.4153	.4153
22	3.7647	3.4332	3.5665	3.8858	3.6961	.4096	.4458
23	3.7365	3.5079	3.3817	3.6789	3.5841	2.5434	2.1544
24	2.0851	3.4362	3.2823	3.3493	3.4541	3.3417	3.0846
Max	3.7647	3.5079	3.5665	3.9247	3.6961	3.3417	3.0846
Min	.1524	.1524	.9145	.5335	.2941	.1524	.2896
Avg	.8387	1.6975	2.8393	2.6134	2.6160	1.8841	1.2794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 403 / 33 KV O/G -I (To Mana S/S) NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2805	2.6063	2.5206	2.364	3.5848	3.1493	
2	2.1719	2.4977	2.3525	2.2565	3.4728	3.0407	
3	2.2805	2.4691	2.2405	2.2565	3.3608	3.0178	2.2262
4	2.1719	2.4143	2.1285	2.4714	3.3608	3.0178	2.1719
5	2.1719	2.3045	2.2405	2.7938	3.2487	2.963	2.2262
6	2.2805	2.2497	2.2965	2.7692	3.5848	2.8532	2.2805
7	2.1719	2.1948	2.0165	2.7938	3.0807	2.7984	1.9547
8			1.9753	2.9081		2.6337	2.0302
9	2.2262		1.6289	1.6289	1.1403	2.2405	2.1176
10	2.9321			1.6289	2.1176	2.2405	2.0508
11	3.4208			2.3891	2.552	2.3525	
12	3.0407			2.4977	2.552	2.5206	2.6292
13	3.2036			2.5789	2.6046	1.8484	2.2119
14	2.9864		2.0633	2.2805	2.1176	1.2883	2.2085
15	2.9321		2.2805	2.4977	1.4661	1.5684	
16	3.0864			2.4977	.9231	1.9605	
17	2.4966			2.5766	2.1262	1.7924	
18	1.6278			1.8484	2.1262	1.1203	
19	2.1605	4.0889		2.2405	2.4451	2.0165	2.0725
20	2.3137	4.145	2.3891	2.6326	2.2857	2.5766	2.4646
21	2.2891	3.7529	2.2085	2.6326	2.1719	2.7446	2.5766
22	2.1091	2.4646	2.392	2.6326		2.4434	2.3102
23	2.3045	3.0247	2.2565	3.638	2.5252	2.4434	2.3891
24	2.552	2.7149	2.6886	3.4208	3.6763	3.2236	2.3348
Max	3.4208	4.145	2.6886	3.638	3.6763	3.2236	2.6292
Min	1.6278	2.1948	1.6289	1.6289	.9231	1.1203	1.9547
Avg	2.4874	2.8406	2.2299	2.5098	2.5692	2.4106	2.2503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 404 / 33 KV O/G -II (To Kherda S/S) Feeder KV- 33 / OUTGOING NON SHEDDABLE WATER SUPPLY AND UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.3303	7.9201	9.0741		7.2257	8.1327	9.7805
2	7.1674	7.7075	8.9621	8.5963	7.1696	8.0264	9.7782
3	7.0588	7.6292	8.85	8.059	7.0016	7.8138	9.7737
4	6.7158	7.4143	8.682	7.5217	7.0016	7.6012	9.5565
5	6.9502	7.5217	9.0741	6.8039	7.3377	7.4417	9.3393
6	6.9502	7.7904	9.3542	6.7696	4.9291	7.3068	9.1335
7	6.8359	8.1447	9.6902	7.5217		7.0919	9.2307
8			10.1538	10.3155		7.0919	9.6108
9	6.4072		9.8823	8.7289	5.4218	7.8418	9.4376
10	9.2547			9.3073	8.2922	9.4102	9.6754
11	9.8337			9.3021	8.2922	11.2026	9.0969
12	9.3553			8.8769		11.0906	8.2819
13	8.7706			7.867	2.6578	7.5057	7.4949
14	8.239		6.857	7.4417	5.7407	4.9291	8.139
15	8.5048		7.1228	7.3886	6.9633	4.0329	
16	8.9392		7.0919	7.5755	6.9633	4.8731	
17	8.6237	8.514	7.5217	8.514	7.9201	7.7858	
18	9.1564	7.6178	8.1127	6.8336	6.9633	7.0016	
19	7.9218	8.85	6.6787	8.514	8.8769	9.4102	8.9621
20	7.9927	8.1779	8.3076	8.4579	8.7174	7.9538	9.6342
21	7.5617	8.2339	8.059	8.85	9.1958	6.7215	9.4662
22	7.7675	8.4019	8.0053	5.5453	6.3786	9.5022	5.9637
23	7.8189	8.1779	7.6017	9.3021	8.6877	9.5679	7.1994
24	7.3846	8.2533	9.2421	9.3484	6.7873	8.2739	10.0995
Max	9.8337	8.85	10.1538	10.3155	9.1958	11.2026	10.0995
Min	6.4072	7.4143	6.6787	5.5453	2.6578	4.0329	5.9637
Avg	7.9365	8.0236	8.4162	8.1496	7.0726	7.8171	8.9827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 201 / 11 KV PATUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	1.829	1.9753	1.9547	1.9753	1.922	1.9022
2	1.7013	1.7741	1.9387	1.8099	1.9589	1.9022	1.829
3	1.7193	1.7193	1.829	1.829	1.9387	1.7741	1.7558
4	1.6289	1.7193	1.7551	1.7551	1.8461	1.7372	1.7193
5	1.6289	1.7002	1.7551	1.7737	1.848	1.7002	1.7558
6	1.829	1.7741	1.7741	1.7924	1.848	1.7002	1.7741
7	1.7741	1.7741	1.6827	1.7193	1.7558	1.7741	1.7375
8	1.6095	1.6095	1.5927	1.6476	1.5927	1.6632	1.576
9	1.6263	1.6827	1.6651	1.6827	1.6827	1.6289	1.7013
10	1.7375	1.6476	1.6651	1.7375	1.6476	1.4723	1.6827
11	1.6651	1.5592	1.576	1.6651	1.6655	1.5927	1.6301
12	1.6301		1.5592	1.5424		1.5203	1.6827
13	1.6644	1.4883	1.576	1.6476		1.6126	1.701
14	1.7375	1.6301	1.6301	1.6834		1.6126	1.6301
15	1.7375	1.6301	1.6301	1.7375	1.9631	1.6126	1.6476
16	1.7193	1.5592	1.6834	1.6476	1.9136	1.6301	1.6827
17	1.6095	1.6651	1.576	1.6476	1.8625		1.5775
18	1.7909	1.6476	1.6827	1.7718	1.858	1.7833	1.6278
19	1.9547	2.1948	2.0271	1.8983	2.2081	2.1491	2.0633
20	2.1216	2.3045	2.0271		2.1719	2.0995	2.0058
21	2.0485	2.268	2.2443	2.2443	2.1216	2.0271	2.0058
22	2.0485	2.1948	2.2081	2.2443	2.1216	2.0271	2.0058
23	2.0119	2.1948	1.9909	2.1719	2.0851	1.9909	2.0271
24	1.9022	1.9022	2.0485	2.0485	2.0485	2.0328	1.9387
Max	2.1216	2.3045	2.2443	2.2443	2.2081	2.1491	2.0633
Min	1.6095	1.4883	1.5592	1.5424	1.5927	1.4723	1.576
Avg	1.7787	1.8030	1.7955	1.8110	1.9102	1.7811	1.7775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 202 / 11 KV KARLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9503	.7922	.7545	.7922	.9614	.9945
2	1.0059	.9503	.7922	.7545	.7545	.9496	
3	.9945	.9282	.7545	.7167	.7545	.8718	.9945
4	1.0059	.9389	.7545	.7167	.7545	.9054	1.0059
5	1.0852	.9175	.7545	.7167	.7545	.8718	.9945
6	1.1401	1.1271	.7545	.7167	.7545	1.1065	1.0486
7	1.4754	1.4586	.5658	.6036	.5658	1.4586	1.3599
8	1.3108	1.4419	.4904	.5281	.5281	1.3603	1.2498
9	1.1797	1.3108	.4527	.3772	.4527	1.2483	1.2186
10	.3772	.3395	1.5581	1.326	1.4083	.3772	.415
11	.415	.3772	1.6575	1.4918	1.7238	.415	.4527
12	.4481		1.4419	1.2631		.4904	.4854
13		.4854	1.3603	1.1523	1.2018	.4904	.5228
14	.3734	.4854	1.153	1.1271	1.0311	.3734	.5228
15	.5228		1.0562	1.1934	1.0242	.4481	.4481
16	.3326	.4481		1.1984	1.0688	.4108	.4854
17	.4904	.4481	1.2631	1.1934	1.1523	.4108	.4854
18	.5601	.415	.4527	.4435	.4481	.4854	.4527
19	.6413	.7545	.6722	.7167	.679	.679	.7095
20	.8962	.7922	.9054	.8962	.9054	.8962	.8589
21	.9054	.9054	.9054	.9335	.9431	.8676	.7842
22	.8676	.9054		.8962	.9054	.9054	.8215
23	.8299	.8676	.8215	.8299	.8299	.8299	.8215
24	.9945	1.0395	.8299	.7842	.7922	1.0059	1.0562
Max	1.4754	1.4586	1.6575	1.4918	1.7238	1.4586	1.3599
Min	.3326	.3395	.4527	.3772	.4481	.3734	.415
Avg	.8209	.8312	.9177	.8888	.8793	.7841	.7908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 203 / 11 KV SHIRLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7811	.8215	.6722	.7842	.759	.8322
2	.7773	.7907	.7842	.679	.7842	.7362	.8223
3	.759	.7499	.7842	.679	.7468	.7042	.8097
4	.8097	.7186	.7842	.7095	.7468	.6874	.7907
5	.8097	.679	.7842	.6722	.7468	.6874	.8745
6	1.1012	.9374	.7842	.6036	.7545	1.0242	1.1012
7		1.4685	.679	.6413	.6036	1.5364	1.5546
8	1.7695	1.6446	.5281	.5281	.4527	1.6194	1.6842
9	1.5546	1.358	.415	.4527	.4527	1.3413	1.1561
10	.4527	.4481	1.3108	1.6057	1.5223	.4108	.415
11	.3734	.4481	1.8313	1.9006	1.6842	.415	.4527
12	.4481		1.6057	1.2967		.5281	.5228
13	.5228	.5175	1.2163	1.2346	1.2346	.5175	.5601
14	.5975	.5975	1.0623	.9934	.8429	.5544	.5914
15	.5975		1.1069	.9332	.8642	.5544	.5975
16	.4854	.5914		.9877	1.0753	.5975	.5975
17	.3326	.5175	1.3283	1.3599	1.3123	.5975	.5975
18	.4481	.5228	.4805	.4481	.4805		.5175
19	.5975	.7095	.7468	.7468	.7095	.8215	.7095
20	.8962	.7468	.8215	.8962	.8589	.8962	.8589
21	.8962	.8962	.7468	.8962	.8962	.8962	.8589
22	.8962	.8962	.5975	.8962	.8962	.8962	.8589
23	.8215	.8589	.8962	.8962	.8589	.8215	.8215
24	.8097	.8322	.8215	.8215	.8215	.7773	.9114
Max	1.7695	1.6446	1.8313	1.9006	1.6842	1.6194	1.6842
Min	.3326	.4481	.415	.4481	.4527	.4108	.415
Avg	.7619	.8050	.9103	.8979	.8752	.7991	.8124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 204 / 11 KV KHANAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.6263	1.701	2.3472	2.079	1.7177	1.7177
2	1.6598	1.643	1.4403	2.4006	2.0454	1.6804	1.6804
3	1.643	1.6057	1.2266	2.34	2.0008	1.6804	1.6804
4	1.643	1.6057	1.2548	2.4272	1.989	1.643	1.6804
5	1.6598	1.5684	1.491	2.3807	2.079	1.643	1.6804
6	1.643	1.643	1.8625	2.5377	2.4143	1.6804	1.6804
7		1.307	1.9281	3.0864	2.6852	1.3443	1.5684
8		1.0456		3.2861	3.0178	1.0456	1.2323
9	1.1317	.9709	2.8182	2.7846	2.8166	.6722	.8589
10	2.5312	2.4417	1.0456	1.0082	1.0456	2.9843	2.6852
11	2.1605	2.8502	.9709	1.0349	1.0456	3.219	3.219
12	2.2634		1.0719	1.1827		2.7496	2.9508
13	2.2291	2.5484	1.1827	1.2567	1.2437	2.3967	2.7183
14	2.0458	2.1879	1.2696	1.2567	1.2803	2.4531	2.0222
15			1.2197	1.2936	1.2197	1.7695	2.146
16	1.5581			1.2567	1.1827	1.9662	2.3137
17	1.8778	.6661	1.1458	1.1458	1.1088	2.2131	2.6825
18	2.8166	1.3599	1.0719	1.134	1.1088	1.1706	1.1088
19	2.2939	2.0908	1.6263	1.6057	1.5154	1.5524	1.6289
20	2.1152	2.4451	1.7013	1.922	1.9418	1.9044	1.8671
21	2.4006	2.0805	1.885	1.9959	1.9791	1.8671	1.922
22	1.8671	2.1616	1.848	1.885	1.922	1.8671	1.9589
23	1.7741	1.9845	1.7177	1.7372	1.7741	1.848	1.848
24	1.7177	1.6804	1.8073	2.3579	2.1026	1.7177	1.7177
Max	2.8166	2.8502	2.8182	3.2861	3.0178	3.219	3.219
Min	1.1317	.6661	.9709	1.0082	1.0456	.6722	.8589
Avg	1.9395	1.7863	1.5130	1.9026	1.8086	1.8661	1.9404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 205 / ww patur

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.0377	.0377
2	.0377	.0377	.0377	.0377	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.0377	.0377	.0377	.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10		.0377	.0377	.0377	.0377	.0377	.0377
11	.0377	.0377	.0377	.0377	.0377	.0377	.0377
12	.0377		.0377	.0377		.0377	.0377
13	.0377	.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377	.0377	.0377	.0377	.0377
15	.0377		.0377	.0377	.0377	.0377	.0377
16	.0377	.0377		.0377	.0377	.0377	.0377
17	.0377	.0377	.0377		.0377	.0377	.0377
18	.0377	.0377	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	.0377	.0377	.0377	.0377	.0377	.0377
24	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.0377	.0377	.0377	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 201 / 11 KV SASTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2427	.5487	.5426	.6161	.2641	.2614
2	.2427	.2427	.5487	.5426	.5228	.2641	.2614
3	.2427	.2427	.6001	.5426	.5228	.2641	.2614
4	.2427	.2427	.6001	.5087	.5601	.2641	.2427
5	.2427	.2054	.6516	.5087	.5975	.2641	.2427
6	.2427	.2241	.6516	.5087	.7282	.2614	.2241
7	.2054	.2427	.763	.7468	.7282	.2054	.2054
8	.1867	.1867	.5935	.7545	.7059	.1867	.1867
9	.168	.168	.5658	.6348	.6535	.1494	.1494
10	.8775	.7842	.1372	.1543	.1494	.8215	.8029
11	.7282	.7468	.12	.168	.1494	.7095	.6274
12	.6348	.7468	.1372	.168	.1494	.6348	.6104
13	.6535	.7095	.1543	.168	.1867	.6348	.5087
14	.6908	.6535	.1372	.168	.1867	.4481	.4115
15	.4668	.5601	.1372	.1867	.1867	.4115	.4287
16	.5228	.4854	.1543	.1867	.1494	.5601	.4458
17	.6722	.7095	.1543	.1494	.1509	.5975	
18	.1494	.1494	.1372	.1494	.168	.1494	.1372
19	.2054	.2075	.1886	.2054	.2054	.1867	.1886
20	.2241	.2641	.2058	.2054	.2241	.2614	.2058
21	.2427	.2829	.2229	.2427	.2427	.2801	.2229
22	.2427	.2829	.2401	.2614	.2427	.2801	.2401
23	.2614		.2572	.2715	.2801	.2801	.2614
24	.2427	.2427	.5975	.5426	.6161	.2614	.2614
Max	.8775	.7842	.763	.7545	.7282	.8215	.8029
Min	.1494	.1494	.12	.1494	.1494	.1494	.1372
Avg	.3680	.3836	.3543	.3549	.3718	.3600	.3212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 202 / 11 KV CHANNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5601	.1715	.1543	.168	.4904	.5601
2	.5601	.5601	.1715	.1543	.168	.4904	.5601
3	.5601	.6348	.1715	.1543	.1494	.4904	.5601
4	.5601	.6535	.12	.1543	.1307	.4904	.5975
5	.5601	.7842	.12	.1543	.1267	.5281	.6722
6	.5601	.8962	.12	.1543	.1307	.5975	.7468
7	.8215	.9522	.12	.1307	.1267	.8775	.8215
8	.9709	.8589	.12	.1307	.12	.7655	.6908
9	.7842	.6722	.12	.1307	.1307	.6348	.5792
10	.112	.1307	.763	.6697	.7842	.1307	.112
11	.112	.0934	.8139	.8962	.8402	.112	.0857
12	.112	.0934	.8139	.7842	.8402	.112	.0857
13	.1307	.0934	.6443		.4668	.1307	.1029
14	.1494	.1307	.6104	.5975	.4715	.1307	.1029
15	.1307	.1307	.5765	.5228	.3734	.12	.1029
16	.1307	.112	.5765	.5601	.4668	.112	.12
17	.112	.1307	.5426	.6348	.6036	.0934	.0857
18	.1307	.0934	.1543	.1307	.0754	.112	.1543
19	.1867	.2075	.1543	.1886	.1867	.1372	.1715
20	.1867	.1886	.1543	.2054	.2054	.168	.1715
21	.1867	.1886	.1543	.1867	.2054	.1867	.1715
22	.1867		.1715	.181	.1867	.1867	.1867
23	.1867		.1715	.1867	.168	.1867	.1715
24	.5601	.5601	.1867	.6348	.168	.4854	.5601
Max	.9709	.9522	.8139	.8962	.8402	.8775	.8215
Min	.112	.0934	.12	.1307	.0754	.0934	.0857
Avg	.3563	.3966	.3218	.3347	.3039	.3237	.3406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 203 / 11 KV KHETRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.4481	1.7101	1.8778	2.1658	.5281	.5228
2	.5228	.5041	1.7101	1.8778	1.8671	.5281	.3734
3	.5228	.5041	1.7804	1.8778	1.6804	.5281	.5228
4	.5601	.5228	1.8107	1.8442	1.6804	.5281	.5601
5	.5975	.5228	1.8107	1.7772	1.7194	.5658	.5601
6	.6161	.5601	1.8442	1.643	2.0538	.5975	.5601
7	.5975	.5788	1.8778	2.2779	2.2965	.5415	.5601
8	.5601	.5601	2.0957	2.726	2.5206	.4668	.5041
9	.5228	.5228	1.7772	2.4253	2.0911	.3921	.5041
10	3.1181	2.838	.3601	.3921	.4294	2.5393	1.9376
11	2.894	2.7073	.3601	.3921	.4108	2.5393	1.9448
12	2.4086	1.8298	.3429	.3921	.4108	2.4272	1.0898
13		1.8671	.3601	.3921	.4108	2.3525	1.1568
14		1.7737	.3601	.3961	.4668	1.6057	1.7939
15	2.5206	1.7177	.3772		.4668	1.6057	1.7269
16	2.5393	1.9978	.4115	.4294	.5601	2.0538	1.7604
17	2.5393	1.9978	.4287	.4294	.5975	2.1658	
18	1.9791		.4458	.4973	.5093	.3734	2.0957
19	1.8671	.6602	.5487	.5788	.5975	.5601	.4973
20	.5601	.5658	.5487	.5788	.5975	.5228	.5144
21	.5601	.5281	.5487	.5228	.5975	.4668	.5144
22	.5601	.5281	.5144	.5068	.5601	.5601	.5601
23	.5601		.4801	.5041	.5601	.5228	.5415
24	3.0434	.5041	.5487	1.8778	2.1658	.5228	.5228
Max	3.1181	2.838	2.0957	2.726	2.5206	2.5393	2.0957
Min	.5228	.4481	.3429	.3921	.4108	.3734	.3734
Avg	1.3715	1.1018	.9605	1.1399	1.1423	1.0623	.9271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 204 / 11 KV WADEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.4003	.3429	.3429	.3734	1.3203	1.363
2	1.3443	1.4003	.3429	.3429	.3361	1.3203	1.363
3	1.419	1.4563	.2915	.3429	.3361	1.3203	1.363
4	1.4563	1.4937	.2915	.3601	.3174	1.358	1.4937
5	1.531	1.587	.2915	.3601	.2987	1.3957	1.643
6	1.5684	1.7177	.2915	.3601		1.4003	1.643
7	1.7924	1.7551	.2915	.3361	.2801	1.7551	1.7551
8	1.8298	1.9231	.2572	.2427	.2614	1.7177	1.643
9	1.6804	1.6057	.2058	.2054	.2241	1.7551	1.6804
10	.2241	.2241	1.153	1.9605	1.8671	.2241	.2241
11	.2241	.2241	.9496	1.9605	1.7737	.2054	.1886
12	.2058	.2427	1.4243	1.8671	1.6804	.2054	.2229
13	.2801	.2241	1.4582		1.6804	.2241	.2401
14	.2801	.2614	1.4582	1.4937	1.4003	.2614	.2572
15	.2801	.2801	1.4922	1.4661	1.2323	.2572	.2572
16	.2614	.2801	1.4582	1.6804	1.3817	.2614	.2401
17	.2427	.2614	1.4582	1.7364	1.5466	.2427	
18	.2241	.2241	.2058	.2241	.2263	.2241	.2058
19	.3174	.3206	.2572	.3174	.3174	.2614	.2572
20	.3734	.3772	.3086	.3734	.3734	.2987	.3086
21	.3734	.1886	.3601	.4108	.3921	.3921	.3429
22	.3921		.3601	.4108	.3921	.3921	.1867
23	.4108		.3601	.3801	.3921	.3734	.3734
24	1.3443	1.4003	.3734	1.475	.2987	1.307	1.3817
Max	1.8298	1.9231	1.4922	1.9605	1.8671	1.7551	1.7551
Min	.2058	.1886	.2058	.2054	.2241	.2054	.1867
Avg	.8083	.8567	.6535	.8108	.7557	.7697	.8102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 201 / 11 KV CHONDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9342		.9431	.8478	.7888	1.9448	1.7772
2	1.9342		.9619	.8478	.8063	1.9448	1.8778
3	1.9281		.9431	.8139	.7888	2.0119	1.8778
4	1.8861		.9242	.763	.7888	2.0119	2.0008
5	2.0919		.9054	.6783	.8669	2.0454	2.0576
6	2.3059		.9242	.6443	.823	2.079	2.0454
7	2.7618		.7356	.6443	.8048	2.146	2.4078
8	2.6863		.5658	.4917	.7545	1.8945	2.2131
9	.3898		.5281	.373	.763	1.8679	1.9227
10	.3814	2.343	2.5604	2.5316	2.2018	.4656	.4904
11	.4115	2.6189	2.713	2.2801	2.2634	.4207	.4338
12	.439	1.8515	2.6791	2.2291	2.1795	.4294	.4715
13		2.1628	2.3908	2.2291	1.9784	.415	.4338
14		2.13	2.0856	1.7101	1.9113		.4481
15	.4668		2.1195	1.7295	1.8442	.3961	.4854
16	.4854	1.9006	2.1874	1.643	1.8023	.4338	.499
17	.4854	.499	2.2891	1.6244	1.8187	.4338	
18	.6348	.499	.8817	.9054	.4854	.4715	
19	.8779	.8215	.763	.9389	.7316	.7922	.6602
20	.9877	1.0829	.78	.9496	1.0608	1.0751	.9054
21	1.0608	1.0456	.9326	.9362	1.0608	1.0562	1.1128
22	1.0456	1.0642	.9665	.9259	1.0029	1.0374	1.0185
23	.9709	.9431	.8817	.8745	.9492	.9431	.9619
24	1.749		.9242	.8478	.8505	1.7204	1.7804
Max	2.7618	2.6189	2.713	2.5316	2.2634	2.146	2.4078
Min	.3814	.499	.5281	.373	.4854	.3961	.4338
Avg	1.2688	1.4586	1.3578	1.1858	1.2219	1.2190	1.2673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 202 / 11 KV ALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7802	.8596	.7712	1.1128	.7973	.8596	.6405
2	.823	.8596	.7293	1.0374	.7716	.8596	.6964
3	.7973	.8596	.7045	.9431	.7888	.8596	.7459
4	.7802	.8954	.7377	.9808	.7628	.8413	.8139
5	.7712	.9465	.763	.9619	.7282	.8573	.8402
6	.8309	.9465	.779	.9619	.6805	.8916	.8939
7	.9015	.8954	.9339	.9808	.6805	.8573	.8669
8	.8322	.9313	.8259	.9619	.7186	.6882	.7116
9	.823	.8238	.8322	.9431	.7186	.6882	.7701
10		.8573	.6413	.9242	.6859	.9389	.8907
11			.7922	.7545	.6783	.9054	.8065
12			.7922	.695	.6173	.7748	.8223
13			.811	.6805	.6173	.7186	.68
14			.7922	.679	.6447		.6874
15	.8855		.7922	.6588	.6089	.759	.6483
16	.9602		.7733	.6588	.6089	.7811	.6958
17	1.0242		.7922	.6859	.6584	.8025	
18	.9831	.6097	.9054	.6859	.7316	.5001	
19	.9503	.8025	1.0562	.7442	.8596	.6093	.6562
20	.9282	.7186	1.0374	.7716	.9313	.7956	.759
21	.7362	.7562	1.0374	.9214	.9313	.8145	.7716
22	.7682	.7773	1.0562	.8596	.8954	.7947	.7407
23	.7888	.8124	.9054	.8779	.8954	.7468	.6327
24	.8413	.7712	.7545	.9431	.8779	.8413	.6019
Max	1.0242	.9465	1.0562	1.1128	.9313	.9389	.8939
Min	.7362	.6097	.6413	.6588	.6089	.5001	.6019
Avg	.8529	.8308	.8340	.8510	.7454	.7907	.7442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 203 / 11 KV AMBASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8267	1.8861	1.8296	1.6108	1.5432	1.6804	1.9105
2	1.7684	1.989	1.8107	1.6108	1.5432	1.7318	1.8724
3	1.8656	2.0332	1.8296	1.6278	1.5775	1.7318	1.8004
4	1.9044	2.1033	1.8484	1.3904	1.6461	1.8176	1.8204
5	2.0165	2.1033	1.905	1.3565	1.7013	1.9281	1.8229
6	2.0851	2.2291	1.9616	1.4413	1.7193	2.0683	1.825
7	2.364	2.2977	1.6975	1.56	1.5592	2.2786	2.4364
8	2.4539	2.2291	1.4146	1.2378	1.5089	2.1948	2.4539
9	2.4272	2.0233	1.3392	1.2039	1.4403	2.1384	2.1033
10	1.0974	1.2071	2.6116	2.9005	2.7343	1.0791	1.1949
11	1.1145	1.9281	2.6244	2.6155	2.6353	1.1157	1.3392
12	1.2071	1.8821	2.4143	2.5692	2.3487	1.1949	1.3769
13	1.2437	1.7939	2.3411	2.2885	1.858	1.2071	1.2136
14	1.2696	1.8519	1.9387	1.8804	1.7177		1.2136
15	1.2567		1.9204	1.9342	1.5074	1.2826	1.2936
16	1.2696	1.8519	1.9204	1.893	1.6804		1.3306
17	1.1949	1.9033	2.3777	1.9204	2.0405	1.4146	
18	1.3817	1.2567	1.4266	1.5089	1.1883	1.4146	
19	1.531	1.6244	1.6644	1.6126	1.7551	1.7353	1.4146
20	1.8484	1.9418	1.8861	2.0165	1.8858	1.905	1.5466
21	1.8861	1.9231	1.905	2.0165	1.8671	1.8861	1.9616
22	1.8861	1.9044	1.9427	1.885	1.829	1.8673	1.9239
23	1.8484	1.8673	1.8296	1.8296	1.8107	1.7164	1.7353
24	1.7177	1.8519	1.8107	1.7918	1.6476	1.5604	1.9136
Max	2.4539	2.2977	2.6244	2.9005	2.7343	2.2786	2.4539
Min	1.0974	1.2071	1.3392	1.2039	1.1883	1.0791	1.1949
Avg	1.6860	1.8992	1.9271	1.8209	1.7810	1.6795	1.7047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 201 / 11 KV Rajeshwar Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.621	1.7157	1.73	2.8822	2.9484	1.9991	2.966
2	1.5272	1.6295	1.6118	2.7534	2.8075	1.8939	2.7924
3	1.438	1.576	1.5691	2.6589	2.7191	2.7445	2.7328
4	1.4174	1.505	1.5028	2.5895	2.5849	2.6353	2.6787
5	1.393	1.457	1.4769	2.5453	2.5705	3.8464	2.5522
6	1.4007	1.4562	1.4609	2.5347	2.5956	2.6737	2.6322
7	1.4319	1.5059	1.5097	2.6139	2.7351	2.769	2.6719
8	.7674	2.1342	1.5074	2.543	2.7107	2.6552	2.694
9	.6699	1.3127	1.4548	2.4699	1.3611	2.3971	2.5355
10	.6783	1.2544	1.3588	1.2559	2.4142	1.2277	2.5651
11	.6203	1.2079	1.2925	2.3087	2.447	2.2424	2.4775
12	2.9945	1.2415	1.2018	2.3921	2.4082	3.3394	2.3564
13	1.2693	1.2681	1.2422	2.5271	2.4014	3.2053	2.3084
14	1.4098	1.496	1.9509	2.5569	2.447	2.2954	2.3884
15	1.4195	1.5242	2.4691	1.3527	2.5324	2.4561	1.2506
16	.7369	1.5211	2.4653	1.3656	1.3435	2.5552	2.2702
17	.7522	1.4654	2.3838	2.5308	2.4384	2.5385	1.4114
18	1.434	1.3984	2.6375	2.4615	2.4222	2.5834	1.3725
19	1.4923	1.5036	1.3542	2.7983	4.2017	2.7915	2.6901
20	1.7265	1.7101	3.1451	3.1596	3.0979	3.1177	3.0643
21	1.7998	1.7291	5.0686	3.0956	3.1003	3.0315	3.0872
22	1.8464	1.829	4.4787	3.1055	3.1347	2.9935	3.1741
23	1.8814	1.8762	3.1185	3.2678	3.1995	3.1459	4.7271
24	1.8084	1.8149	2.4836	1.7017	3.1543	3.1573	3.1093
Max	2.9945	2.1342	5.0686	3.2678	4.2017	3.8464	4.7271
Min	.6203	1.2079	1.2018	1.2559	1.3435	1.2277	1.2506
Avg	1.3973	1.5472	2.1031	2.4779	2.6573	2.6790	2.6045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 204 / 11 KV Renuka Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	1.73	1.829	1.8107	1.885	1.8627	1.829
2	1.0608	1.6547	1.6827	1.7193	1.7194	1.752	1.7193
3	.9877	1.5595	1.5181	1.6461	1.6095	1.6765	1.7193
4	.9877	1.5611	1.4969	1.5364	1.4784	1.6028	1.6461
5	.9877	1.4923	1.5154	1.4632	1.4842	1.5492	1.4632
6		1.4784	1.5154	1.4632	1.5154	1.537	1.4815
7		1.4326	1.448	1.4449	1.4815	1.4028	1.4266
8		1.3338	1.267	1.2803	1.2803	1.3577	1.3169
9		1.2321	1.1888			1.3129	1.1827
10		1.0924	1.0608	1.2803	1.1523	1.1403	1.1104
11		1.1694	1.0608		1.0425	1.0959	1.086
12	1.7466	1.2715	1.1157		1.2437	1.134	1.182
13	1.1462	1.3969	1.2803	1.3226		1.2803	1.3032
14	1.0104	1.5384	1.4266	1.5133	1.5364	1.4632	1.4118
15	1.0284	1.6108	1.4998	1.5514	1.4632	1.5364	
16	1.0498	1.5746	1.4998	1.5348	1.4632	1.5364	1.448
17	.9881	1.4118	1.4083	1.4299	1.3937	1.39	
18	1.4014	1.2934	1.4266	1.3643	1.4058	1.2757	
19	1.6691	.8059		1.6644	1.6616	1.5364	1.5384
20	1.7482	1.6278	1.6278	1.7194	1.6974	1.5364	1.6108
21	1.8118	1.7375	1.7558	1.7924	1.7723	1.4632	1.7193
22	1.9224	1.8473	1.9204	1.9387	1.916	1.829	1.7193
23	2.004	1.9936	2.0302	2.0851	2.1003	1.9936	1.9753
24	1.1888	1.8956	1.9204	1.9387	2.0144	1.9733	1.9387
Max	2.004	1.9936	2.0302	2.0851	2.1003	1.9936	1.9753
Min	.9877	.8059	1.0608	1.2803	1.0425	1.0959	1.086
Avg	1.3263	1.4892	1.4998	1.5952	1.5598	1.5099	1.5156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 205 / 11 KV Shivsena Vasahat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.8012	.7762	.8596	***	***	.823
2	.695	.7802	.7316	.8596	***	***	.7865
3	.695	.7639	.7762	.8596	***	***	.7865
4	.695	.7624	.7682	.8596	***	***	.7865
5	.7865	.802	.823	.8779	***	***	.8413
6	.823	.8632	.7842	.9877	***	***	1.0425
7	.8962	1.0541	1.1016	1.1157	***	***	1.0242
8		1.0353	1.0642	1.0974	***	***	1.262
9		1.0342	.9511	1.1157	***	***	1.0791
10		1.0082	.8596	.9749	***	.8971	.8871
11		.8775	.8413	.9167	***	.8029	.8871
12	.7858	.8589	.8596	.9167	***	.7499	.8501
13	.6701	.8131	.8413	.8775		.7499	
14	.7415	.7762	.7316	.8012		.7316	
15	.723	.8501	.7499			.7133	
16		.7762	.823			.695	.8501
17	.7826	.7207		.8131		.7133	
18	.913	.7947		.8316	***	.8686	
19	1.1203	1.0082		1.0269	***	1.0608	1.0829
20	1.1424	1.0349	1.0608	1.251	***	1.134	1.1016
21	1.0477	.9709	.9694	1.0903	***	1.0425	1.0425
22	.9886	.9425	.9877	.9979	***	.9877	.9877
23	.8393	.8686	.9877	.961	***	.9145	.9694
24	.823	.8385	.8316	.8779	***	.9297	.8779
Max	1.1424	1.0541	1.1016	1.251	140.1996	127.4988	1.262
Min	.6701	.7207	.7316	.8012	11.5748	.695	.7865
Avg	.8368	.8765	.8724	.9532	103.3990	41.0875	.9457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 241 / 11KV DABKI I/C NO.1

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0851	2.1713		2.6886		2.7188	2.652
2	1.9387			2.5789		2.6244	2.524
3	1.829	1.9636		2.5057		2.6999	2.4691
4	1.829	1.9258		2.4508		2.5866	2.4691
5	1.9204	1.9258	1.9805	2.4508	2.584	2.681	2.4326
6	2.0668	2.0957		2.5789		2.8132	2.7435
7	2.0485	2.3978	2.2822	2.7252		2.9076	2.6155
8	1.8656	2.0391	2.2068	2.6337		2.7566	
9	1.9204		2.0302	2.7252		2.5678	2.652
10	1.7924		1.8473	2.5866	2.5423	2.4733	
11	1.8839	1.9239	1.8473	2.53	2.5057	2.4167	2.5463
12	1.9258			2.6433	1.5364		
13			1.8107	2.681	1.6095	2.2862	
14			2.3045	2.6055	1.6278	2.3594	
15			2.268	2.6055	1.6095	2.4143	
16			1.9204	1.8692	1.5729	2.4326	
17		1.9239	2.2862		1.6426	2.1948	
18			2.3594		2.8887	2.5423	
19			2.9447			2.9264	3.1121
20		2.452	3.219	2.8858	3.3607	3.0361	
21			2.9264		3.1908	2.8715	2.9447
22			2.8715		3.3041	2.8532	3.0544
23	2.3034		2.9995		3.0398	2.7618	1.9387
24	2.2497	2.2468	2.2068	2.7618	2.7046	2.8698	2.8166
Max	2.3034	2.452	3.219	2.8858	3.3607	3.0361	3.1121
Min	1.7924	1.9239	1.8107	1.8692	1.5364	2.1948	1.9387
Avg	1.9756	2.0969	2.3506	2.5837	2.3813	2.6432	2.6408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 242 / 11 KV DABKI I/C NO.2

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8656	2.5714		2.8349			2.7435
2	1.7558	2.4579		2.4874		2.64	2.5606
3	1.6461	2.3005		2.3777		2.5185	2.5606
4	1.6461	2.2963		2.268		2.4099	2.4508
5	1.6461	2.2291	2.2177	2.1948	2.2443	2.3753	2.1971
6	.6584	2.2054		2.2314		2.3458	2.2497
7	.7316		2.2405	2.2131		2.2062	2.1582
8	.6219	2.2009	1.9791	2.0119		2.0655	
9	.5487		1.8107	1.8656		1.9733	
10			1.6461	1.6708	1.7558	1.7449	
11	.6219	1.8111	1.6461	1.568	1.6095	1.6903	1.6832
12	2.641		1.701	1.8701	1.829	1.8298	
13			1.9022		2.0485	1.9936	
14			2.1582	2.2958	2.2862	2.2131	
15			2.2314	1.5433	2.2497	2.3411	
16			2.2314	2.4351	2.2862	2.2862	
17		2.1437	2.0668		2.0931	2.1216	
18			2.0485		2.1765	2.0302	
19			2.3777		2.4926	2.3411	2.3348
20		2.371	2.396	2.5882	2.5266		
21			2.5972		2.6741	2.3411	2.5972
22			2.9264		2.9229	2.8166	2.7069
23	2.9723		3.0178		3.1819	3.0544	
24	1.9936	2.7934	2.7984	2.8898	2.9447	2.9815	2.9264
Max	2.9723	2.7934	3.0178	2.8898	3.1819	3.0544	2.9264
Min	.5487	1.8111	1.6461	1.5433	1.6095	1.6903	1.6832
Avg	1.4884	2.3073	2.2102	2.1968	2.3326	2.2873	2.4308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 401 / 33KV I/C APATAPA TO DABKI SHEDDABLE RURAL
SOUR Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	16.5135	14.0032	13.4888	21.4792	16.2895	21.6927	21.8724
2	15.4916	13.0887	12.8029	20.3476	15.3178	20.4884	20.4619
3	14.808	12.6886	12.2885	19.8948	14.8606	19.8566	19.9566
4	14.6388	16.2989	11.9456	19.2136	14.2318	19.3002	19.2753
5	14.353	11.6027	15.8717	18.3037	18.594	19.3718	18.8775
6	13.5322	12.2314	12.1171	18.6466	13.8889	19.7245	19.1542
7	11.3032	12.5172	17.4011	18.93	10.2881	19.4438	18.6534
8	10.4024	16.8597	16.6649	18.0842	13.8318	18.754	13.4888
9	9.8925	11.2597	15.5533	17.6338	13.203	17.4146	13.3745
10	9.1175	10.9168	4.2021	12.1171	16.9548	16.7948	12.5743
11	7.2337	14.7531		11.5455	16.7902	16.5124	16.9697
12	13.923	11.2597		17.3058	14.3576	16.2163	12.3457
13	12.1742	11.8313		13.2602	14.8034	16.7878	12.6886
14	11.2597	12.5172		19.0828	14.1884	17.7435	13.203
15	11.1454	12.5743	15.1761	16.662	15.711	18.5368	12.5743
16	6.9159	12.6886	16.749	18.8837	15.711	18.5368	13.6603
17	9.888	16.9697	16.5501	12.1742	15.2964	13.4888	13.546
18	12.2885	11.6027	17.0691	13.546	19.0444	17.7023	12.9173
19	14.0032	13.3173	19.7805	15.6036	21.697	20.2309	20.7362
20	14.6891	19.2204	21.8702	21.2483	22.8318	21.5387	16.4609
21	14.4033	14.0604	21.358	16.4609	22.6059	21.4769	21.8176
22	14.8034	14.4033	22.8212	17.4326	23.7312	22.1537	22.9973
23	20.8669	14.4033	22.9424	17.947	24.0146	22.6681	23.5071
24	19.6891	20.0292	22.0165	23.6969	23.3425	23.1143	23.2922
Max	20.8669	20.0292	22.9424	23.6969	24.0146	23.1143	23.5071
Min	6.9159	10.9168	4.2021	11.5455	10.2881	13.4888	12.3457
Avg	13.0557	13.7957	16.4335	17.4792	17.1494	19.1479	17.2669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 403 / 33 KV I/C KHADKI TO DABKI

Feeder KV- 33 / OUTGOING

DATE	17-APR-17
HR	Load (MW)
10	6.4712
11	6.3511
12	6.5672
13	6.9753
14	8.2922
15	3.7551
Max	8.2922
Min	3.7551
Avg	6.4020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 201 / 11KV RPTS Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2883	1.5089	1.6991	1.7177	1.5947	1.7551	1.7177
2	1.2323	1.5089	1.643	1.6804	1.5775	1.6804	1.6617
3	1.2136	1.4746	1.6057	1.6057	1.5432	1.643	1.6244
4	1.1949	1.4746	1.6057	1.587	1.5432	1.6057	1.587
5	1.1949	1.4746	1.643	1.5684	1.5432	1.6057	1.6244
6	1.2323	1.4746	1.6617	1.6244	1.6118	1.6244	1.6804
7	1.307	1.5432	1.6804	1.7924		1.7177	1.7737
8		1.5432	1.7177	1.7551	1.749	1.6991	1.8111
9	1.3443	1.6118	1.6991	1.6804	1.6118	1.6804	1.7364
10	1.2003	1.643	1.531	1.531	1.6804	1.4937	1.6461
11	1.2174	1.6057	1.4937	1.587	1.5497	1.4003	1.4746
12	1.2174	1.6804	1.643	1.5775	1.6804	1.3817	1.5432
13	1.2003	1.587	1.587	1.5432	1.6057	1.419	1.5261
14	1.0974	1.4937	1.5123	1.3889	1.587	1.419	1.3717
15	1.1317	1.4937	1.587	1.3717	1.6057	1.4563	1.4232
16		1.5497		1.3717	1.6057	1.4937	1.4575
17	1.3032	1.5684	1.6617	1.3889	1.6804	1.531	1.4575
18	1.6118	1.643	1.6991	1.5775	1.7364	1.6244	1.9231
19	1.8861	1.9044	2.0538	1.8004	1.7551	1.9231	
20	1.9204	1.8671	1.9605	1.8861	1.7551	1.9605	1.9605
21	1.7147	1.7924	1.8111	1.7147	1.8111	1.8111	1.6632
22	1.6632	1.7924	1.8298	1.6804	1.9044	1.7924	1.7147
23	1.6804	1.7924	1.8298	1.749	1.8671	1.8298	1.749
24	1.3256	1.5432	1.7364	1.7551	1.6461	1.8298	1.7924
Max	1.9204	1.9044	2.0538	1.8861	1.9044	1.9605	1.9605
Min	1.0974	1.4746	1.4937	1.3717	1.5432	1.3817	1.3717
Avg	1.3717	1.6071	1.6909	1.6223	1.6628	1.6407	1.6487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 204 / 11 KV Cotton Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	2.3396	2.9127	3.0179	2.9263	3.0788	2.9432
2	.9335	2.2919	2.8212	2.9009	2.8312	2.9805	2.8822
3	.8962	2.2272	2.772	2.7465	2.7016	2.833	2.8025
4	.8402	2.1967	2.7416	2.6787	2.6711	2.8025	2.6787
5	.9335	2.1662	2.6925	2.6483	2.6063	2.772	2.6787
6	.9335	2.1148	2.6551	2.7111	2.5759	2.7416	2.6787
7	1.0269	2.2329	2.6178	2.6178		2.6787	2.6856
8		2.2977	2.5499	2.6483	1.286	2.7092	2.7397
9	.9335	2.5027	1.4022	2.6158	2.7797	2.8025	2.8635
10	.9602	2.4417	2.772	2.833	3.184	2.9245	3.0635
11	.9602	2.3434	3.0826	3.5722	3.5094	3.6027	3.7037
12	.8916	2.1891	3.4847	3.9838	3.4614	3.7675	4.0542
13	.8573	2.3758	3.6389	4.1057	4.1876	3.9704	4.3134
14	.8573	2.4692	3.5456	3.959	4.1876	4.0943	4.0847
15	.8573	2.4387	3.4522	3.8065	3.9419	3.9209	3.8123
16		1.4937	1.5242	3.837	4.1876	3.9095	3.8733
17	.8573	1.4003	3.6694	1.0288	4.3911	4.0638	4.0199
18	1.9547	2.6521	3.7509	4.3286	4.0638	4.1198	4.1571
19	2.2291	4.1426	3.8238	4.4086	4.2741	4.3115	2.1033
20	1.9719	3.9342	3.5742	4.0562	4.2486	4.0314	3.9724
21	1.7147	3.4446	3.3707	3.4979	3.7571	3.5772	3.5742
22	1.4575	3.2008	3.2518	3.2503	3.2636	3.3688	3.3913
23	2.5377	3.0788	3.2331	3.0902	3.2705	3.2636	3.0597
24	2.6002	2.9606	3.0788	3.1093	3.0521	3.184	3.1093
Max	2.6002	4.1426	3.8238	4.4086	4.3911	4.3115	4.3134
Min	.8402	1.4003	1.4022	1.0288	1.286	2.6787	2.1033
Avg	1.2807	2.5390	3.0174	3.2272	3.3634	3.3962	3.3019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 205 / 11 KV Tajnapeth Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	1.0288	1.0349	1.1389	1.0288	1.1389	1.0719
2	.7392	1.0288	.9979	1.1016	1.0288	1.1203	1.0164
3	.7023	.9945	.961	1.0269	1.0288	1.1203	.961
4	.6653	.9945	.961	1.0269	1.0288	1.0829	.9335
5	.6283	.9602	.961	1.0269	.9945	1.0456	.9335
6	.5914	.9431	1.0164	1.1203	.8916	1.0269	.961
7	.5914	.8916	.961	.9709		1.643	1.0164
8	.6468	1.0288	.924	1.0082	.9774	.9709	1.0164
9	.7023	.9088	.924	.9709	1.0288	.9335	1.0164
10	.6859	.924	1.0269	1.0269	1.1203	.961	.9602
11	.6516	1.0164	1.0269	1.0269	1.1203	1.0164	1.0288
12	.6516	.924	1.0456	.9602	1.1203	1.0719	1.1145
13	.6344	.961	1.0269	.9945	1.1203	1.1088	1.1145
14	.6173	.924	1.0269	1.0288	1.2136	1.1088	1.1145
15	.6173	.924	1.0269	1.1145	1.2136	1.1088	1.1145
16		.924		1.0288	1.2136	1.1088	1.1145
17	.6859	1.0164	1.2136	1.0288	1.2136	1.1088	1.1145
18	1.166	1.0164	1.2323	1.0631	1.2136	1.1458	1.1949
19	1.2003	1.0349	1.3443	1.166	1.1949	1.1458	
20	1.1317	.961	1.1576	1.0974	1.2323	1.1827	1.1949
21	1.1145	.961	1.1203	1.0631	1.1203	1.1458	1.1145
22	1.0288	1.0164	1.1576	1.0288	1.1949	1.1088	1.1145
23	1.0974	.961	1.1203	1.0288	1.2323	1.1088	1.0974
24	.8131	1.0802	1.1088	1.1203	1.0288	1.2323	1.1088
Max	1.2003	1.0802	1.3443	1.166	1.2323	1.643	1.1949
Min	.5914	.8916	.924	.9602	.8916	.9335	.9335
Avg	.7887	.9760	1.0598	1.0487	1.1113	1.1144	1.0621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 241 / 11KV MOHATA I/C NO.1

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.2097	8.2533	8.7635	8.8195	8.602	8.8569	2.894
2	6.8877	8.0247	8.4416	8.5162	8.3219	8.4416	2.8006
3	6.7943	7.9561	8.1756	8.0636	8.2019	8.1009	2.7446
4	6.5097	7.6761	8.1383	8.0076	7.9733	8.0263	2.6699
5	6.4724	7.6761	7.947	7.9889	7.9733	7.7977	2.6886
6	6.5097	7.5904	8.1569	8.0263	8.059	7.8163	2.7446
7	6.5657	7.6932	7.8537	8.213		7.7977	2.8006
8	6.5284	7.8018	7.625	7.7603	8.219	7.7043	2.7446
9	6.435	7.6932	7.5503	7.6856	7.7847	7.247	2.5393
10	6.3672	7.4943	7.1163	7.2702	7.4943	7.0416	2.5034
11	6.1042	7.2283	6.8504	6.9064	7.135	2.1845	2.2805
12	6.1042	7.6063	7.0988	7.2359	7.6063	2.2405	2.3491
13	6.1385	7.5316	7.2283	7.6247	7.4943	2.2965	2.3834
14	6.3501	7.2657	7.2097	7.2759	7.5503	2.3525	2.2977
15	6.3844	7.5876	7.5876	7.3445	7.569	2.3899	2.3663
16	2.0576	7.6063	5.0297	7.3445	7.569	2.4272	2.4006
17	4.9897	7.8537	4.6902	7.2759	7.5876	2.4272	2.2977
18	7.7275	7.835	7.835	7.7275	7.6436	2.4832	
19	9.122	8.7403	8.8337	8.7734	8.2876	3.0247	3.0434
20	9.5793	9.4262	***	9.5622	8.8195	3.1181	3.0994
21	8.9163	9.1602	8.8755	8.9506	8.8755	2.9687	2.95
22	8.6534	9.0855	9.2348	8.8477	9.2722	2.9127	2.8121
23	8.9849	9.1228	9.1228	9.3507	9.2348	2.9874	2.915
24	8.656	8.8134	9.0855	9.1228	8.9506	3.062	3.006
Max	9.5793	9.4262	20.4561	9.5622	9.2722	8.8569	3.0994
Min	2.0576	7.2283	4.6902	6.9064	7.135	2.1845	2.2805
Avg	6.9187	8.0301	8.2878	8.0706	8.0967	4.8211	2.6666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 242 / 11 KV MOHATA I/C NO. 2

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7551	2.332	2.4646	2.6326	2.4006	2.6326	2.5019
2	1.6804	2.3148	2.4272	2.5393	2.3663	2.5766	2.4272
3	1.6057	2.2462	2.3712	2.3712	2.2977	2.5206	2.3712
4	1.5123	2.2462	2.3712	2.3339	2.2977	2.4832	2.2405
5	1.5684	2.2119	2.3525	2.3339	2.2291	2.4459	2.2405
6	1.531	2.1434	2.3712	2.5206	2.1262	2.4272	2.2779
7	1.6244	2.0576	2.2779	2.2779		2.3339	2.3712
8	1.6244	2.2291	2.2032	2.3152	2.2634	2.2779	2.3339
9	1.643	2.1434	2.2405	2.1845	2.3148	2.3339	2.4272
10	1.6461	2.2779	2.4272	2.4272	2.6886	2.3712	2.4691
11	1.6118	2.3339	2.7073	2.8006	2.8006	2.8006	2.8121
12	1.5432	2.1472	2.7606	2.9321	2.5393	2.8567	3.035
13	1.4918	2.3712	3.0807	2.9664	3.1741	2.9874	3.1722
14	1.4746	2.4272	2.9874	2.915	3.2674	3.0807	3.035
15	1.4746	2.4272	2.894	3.0007	3.1741	2.9874	2.915
16		2.4272		2.915	3.2674	2.9874	2.915
17	1.5432	2.4272	3.2674	2.9492	3.3794	3.0807	3.0007
18	3.1207	2.5206	3.3981	2.9835	3.1741	3.1741	3.2487
19	3.4294	2.7446	3.4915	3.2579	3.3048	3.3048	
20	3.1036	2.5579	3.0247	2.8978	3.2861	3.062	3.1554
21	2.8292	2.4646	2.8753	2.6406	2.9874	2.8753	2.8292
22	2.4863	2.5206	2.7633	2.572	2.782	2.782	2.8292
23	2.5377	2.4646	2.7073	2.5034	2.8567	2.7073	2.572
24	1.8671	2.4863	2.6139	2.6139	2.4348	2.8006	2.6139
Max	3.4294	2.7446	3.4915	3.2579	3.3794	3.3048	3.2487
Min	1.4746	2.0576	2.2032	2.1845	2.1262	2.2779	2.2405
Avg	1.9437	2.3551	2.6991	2.6619	2.7571	2.7454	2.6867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 401 / 33KV APATAPA TO MOHATA S/S

I/C Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	***	***	***	***	***	***	***
3	29.8543	***	***	***	***	***	***
4	28.4243	***	***	***	***	***	***
5	27.3663	***	***	***	***	***	***
6	26.6644	***	***	***	***	***	***
7	26.7067	***	***	***	14.1975	***	***
8	26.4033	***	***	***	***	***	***
9	26.5404	***	***	***	***	***	***
10	26.7147	***	***	***	***	***	***
11	27.332	***	***	***	***	***	***
12	27.8635	***	***	***	***	***	***
13	28.1893	***	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	21.5535	***	29.5645	***	***	***	***
17	27.8293	***	***	***	***	***	***
18	***	***	***	***	***	***	29.7668
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	***	***	***	***
Max	42.747	42.6561	44.8606	44.7554	45.0413	44.68	44.0045
Min	21.5535	30.95	29.5645	31.8291	14.1975	31.9845	29.7668
Avg	31.6487	35.7188	36.9860	38.6110	38.3224	38.0588	38.0678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 402 / 33KV MOHATA TO VIDYUT B
S/S O/ Feeder KV- 33 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	17.2428	18.0042	18.9781	19.7509	19.7017	19.6011	19.952
2	15.8162	16.4266	17.6224	17.987	18.1757	18.1893	18.2716
3	14.4239	15.6721	21.4335	16.7901	16.9753	17.1331	17.2291
4	13.4843	14.7462	15.1715	15.6561	15.9808	16.1637	15.8162
5	12.7024	13.8031	14.2525	14.824	15.0892	15.1634	14.6159
6	11.8313	12.4486	13.3059	13.9918	14.2661	13.9826	13.834
7	11.262	11.9685	12.4074	12.9138	14.1975	12.9916	12.9081
8	11.0837	11.6255	11.9067	12.3994	13.2202	12.6829	12.3252
9	10.9328	11.3512	12.0096	12.4554	12.7058	12.6829	12.62
10	11.5055	11.7352	12.5583	13.3871	13.1814	13.4774	13.0315
11	12.6201	12.5034	13.6489	14.2067	14.0135	14.5199	13.5802
12	13.1516	13.299	14.1038	15.0377	15.6619	14.7462	15.0891
13	14.2319	14.609	15.0138	16.6324	16.5718	15.7545	16.3409
14	15.535	15.8643	16.8553	17.7641	18.0613	16.941	17.5412
15	16.7867	16.893	13.5322	18.8272	19.4388	17.6955	18.1413
16	17.1639	16.6392	17.6646	19.0158	19.5668	13.1002	18.33
17	16.0151	16.3375	17.6875	18.0213	18.4203	10.8573	17.5411
18	14.9863	14.7669	17.0519	16.4781	17.0862	18.5392	16.2666
19	15.1406	14.9589	16.8336	16.6324	17.3229	18.155	12.0371
20	15.5865	15.3566	17.1297	16.821	17.7218	18.1344	16.7868
21	15.4321	15.9122	17.2886	16.9068	17.516	17.7229	16.7432
22	16.1523	17.3252	18.8341	18.4843	18.7781	18.4363	16.9239
23	18.4157	19.4308	21.3706	20.6962	21.134	20.5076	20.0103
24	19.026	19.4617	21.0768	21.2403	21.0735	20.9316	20.6448
Max	19.026	19.4617	21.4335	21.2403	21.134	20.9316	20.6448
Min	10.9328	11.3512	11.9067	12.3994	12.7058	10.8573	12.0371
Avg	14.6054	15.0475	16.1557	16.5383	16.9109	16.1712	16.1075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 201 / 11KV Washim NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.2291	2.191	2.2862	2.3815	2.2481	2.3624
2	2.0005	2.191	2.1338	2.2481	2.2862	2.2481	2.3243
3		2.0957	2.0957	2.191	2.2481		2.2862
4	1.9052	2.0576	2.0576	2.1338	2.191	2.2481	1.9814
5	1.8671	2.0195	2.0195	2.0957	2.1529	2.2481	2.0195
6	1.829	2.0005	2.0005	2.0386	2.0957	2.0767	2.0957
7	1.9052	2.1719	2.0767	2.1338		2.1529	2.0767
8	2.0386	2.0576	1.9814	2.21	2.572	2.1719	2.0576
9	1.9433	2.1529		2.0576	2.191	2.0957	2.0767
10	1.9052	2.1148		2.0195	2.1148	1.9814	2.0576
11	2.0957	2.191		1.8099	2.1338	1.8671	2.0005
12	2.1148	2.1719		1.9814	2.191	1.9433	1.9052
13	2.1529	2.1148		1.9624	.5525	2.0005	2.1719
14	2.0767	2.0957		1.9814	2.3053		2.0386
15	2.0957	2.1529	2.4768	2.0767		1.7528	
16		2.0957	2.4387	2.191		2.0576	
17		2.191	2.3815	2.1719		2.0957	
18	2.3815	2.1338	2.3624	2.1529		2.1719	
19	2.7435	2.4006	2.6292	2.6673	2.553	2.5339	2.4768
20	2.7625	2.572	2.5339	2.6482		2.6292	2.553
21	2.3815	2.3434	2.4768	2.3624	2.553	2.2862	2.2672
22	2.4196		2.5149	2.4577	2.4958	2.4006	2.3053
23	2.3815	2.3815	2.553	2.553	2.553	2.5149	2.4958
24	2.191	2.3243	2.2862	2.4387	2.4577	2.4958	2.4768
Max	2.7625	2.572	2.6292	2.6673	2.572	2.6292	2.553
Min	1.829	2.0005	1.9814	1.8099	.5525	1.7528	1.9052
Avg	2.1565	2.1852	2.2894	2.2029	2.2238	2.1918	2.2015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 202 / 11 KV Kholeshwar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.028	1.1554	1.1225	1.2445	1.1721	1.1119	1.1241
2	.9717	1.0525	1.0981	1.1569	1.1096	1.0449	1.0242
3	.4702	1.0228	1.0311	1.0524	1.0814	1.0037	.9831
4	.8825	.9442	.9937	.9884	1.0167	1.0037	.9289
5	.8634	.8756	.932	.9534	.9641	.9831	.8954
6	.7956	.8368	.9053	.8954	.9007	.9084	.9327
7	.7559	.8116	.9122	.9038	1.044	.8962	.8794
8	.8413	.8009	.8382	.9076	1.0776	.9198	.8756
9	.8725	.8421	.4077	.9472	1.0715	.9572	.9617
10	.8558	.849		.9122	.5083	.9617	.9122
11	.9061	.9731		1.0814	1.067	1.0677	1.0891
12	1.0631	1.1005		1.2048	1.1957	1.1485	.1882
13	1.0952	1.1066		1.2102	1.1736	1.2117	
14	1.1157	1.1599		.6569	1.0974	.3765	1.4815
15	1.1774	1.2026	1.6484	1.3352	.6722	1.4099	.8154
16	.4466	1.2262	1.7048	1.4746	.7194	.3582	.791
17	.5228	1.2346	1.6544	1.3702	.6607	.6859	.7118
18	1.3634	1.1767	1.4556	1.2521	.6158	1.4997	.6211
19	1.0272	1.3001	1.4975	1.326	1.3092	1.4861	1.336
20	1.4533	1.3085	1.515	1.4563	.7034	1.4426	1.4061
21	1.3634	1.2201	1.4792	1.3748	1.2963	1.3657	1.2818
22	1.2057	.5952	1.3314	1.2681	1.2018	1.326	1.1782
23	1.2201	1.1858	1.3527	1.2811	1.1934	1.2018	1.1378
24	1.1324	1.2452	1.243	1.2864	1.2346	1.2034	1.1583
Max	1.4533	1.3085	1.7048	1.4746	1.3092	1.4997	1.4815
Min	.4466	.5952	.4077	.6569	.5083	.3582	.1882
Avg	.9762	1.0511	1.2170	1.1475	1.0036	1.0656	.9875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 203 / 11 KV Rajputpura SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1905	.2286	.2286	.2286	.2286
2	.1715	.1905	.1905	.1905	.2286	.2286	.2286
3	.1715	.1905	.1905	.1905	.2286	.2286	.1905
4	.1715	.1905	.1905	.1905	.2286		.1524
5	.1715	.1905	.1905	.1905	.2286	.2286	.1524
6	.1524	.1715	.1715	.1715	.1905	.2286	.1905
7	.1334	.1524	.1715	.1715	.1715	.1715	.1715
8	.1334	.1524		.1905	.1715	.1715	.1524
9	.1715	.1715		.1905	.1905	.1715	.1715
10	.1905	.1715		.1905	.1905	.2096	.2096
11	.2477	.1905		.2477	.2477	.2858	.2667
12	.2096	.1905		.2858	.2667	.2667	.2858
13	.2667	.2286		.2858	.2858	.3048	.3048
14	.2667	.2286		.3048	.2858	.3048	.3048
15	.2477	.2286	.3429	.3048		.3239	
16	.3048	.2286	.362	.3239		.3048	
17		.2286	.3239	.3048		.2858	
18	.2477	.2286	.3048	.2858		.2667	
19	.2477	.2477	.3239	.3239	.3048	.2858	.2477
20	.2477	.2286	.2858	.2858		.2858	.2477
21	.2477	.2286	.2477	.2477	.2667		.2477
22	.2286		.2286	.2667	.2477	.2477	.2477
23	.2286	.2477	.2667	.2858	.2477	.2477	.2286
24	.2096	.2477	.2477	.2477	.2667	.2477	.2667
Max	.3048	.2477	.362	.3239	.3048	.3239	.3048
Min	.1334	.1524	.1715	.1715	.1715	.1715	.1524
Avg	.2104	.2054	.2488	.2461	.2356	.2511	.2248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 204 / 11 KV NEW CLOTH MARKET SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6668	.724	.8002	.7621	.6859	.7621
2	.6668	.6668	.7049	.7621	.724	.6859	.724
3		.6668	.6668	.7621	.6859	.6859	.6859
4		.6287	.6097	.724	.6668	.6859	.5716
5		.6287	.5906	.6859	.6668	.6859	.5716
6	.5525	.5906	.5716	.6478	.6287	.6097	.6097
7	.5525	.5716	.5716	.5906		.5716	.5906
8	.5525	.5906	.5906	.5716	.724	.6287	.6097
9	.5716	.6097		.6097	.743	.6859	.6668
10	.8383	.724		.8383	.8192	.8002	.8002
11	1.1241	.9907		1.2574	1.2574	1.2574	1.2384
12	1.3527	1.2003		1.3527	1.3717	1.3336	1.4861
13	1.467	1.2574		1.448	1.467	1.5623	1.5623
14	1.467	1.2384		1.5813	1.467	1.5623	1.4861
15	1.4098	1.3336	1.7718	1.5623		1.448	
16		1.3336	1.7909	1.5623		1.467	
17		1.2574	1.7528	1.5242		1.467	
18	1.6004	1.2574	1.7718	1.5623		1.467	
19	1.6004	1.3336	1.8099	1.5813	1.3908	1.5623	1.6004
20	1.5432	1.2955	1.6004	1.5242		1.5051	1.5242
21	1.2955	1.1812	1.3336	1.3527	1.1431	1.2765	1.2384
22	.8573		.9526	.9145	.8192	.8954	.8383
23	.7621	.7811	.8383	.8192	.8192	.7811	.7811
24	.7049	.743	.7811	.8764	.8192	.7811	.8002
Max	1.6004	1.3336	1.8099	1.5813	1.467	1.5623	1.6004
Min	.5525	.5716	.5716	.5716	.6287	.5716	.5716
Avg	1.0308	.9368	1.0796	1.0796	.9431	1.0455	.9574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 205 / 11 KV Dana Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6241	1.2209	1.2521	1.3261	1.297	1.2902	1.3215
2	.5883	1.1759	1.2011	1.2468	1.2232	.6455	1.3017
3	1.1317	1.1508	1.182	1.1889	1.1767	1.2308	1.2224
4	1.0814	1.1088	1.1576	1.1607	1.1432	1.2041	1.0959
5	1.0654	1.0822	1.1355	1.1538	1.131	1.1988	1.0974
6	1.0266	1.0845	1.0883	1.1454	1.0891	1.1188	1.1302
7	.9884	1.0578	1.0639	1.1042		1.0608	1.1028
8	.9999	1.1188	1.0943	1.1165	1.323	1.0913	1.1515
9	1.2102	1.1294	.5677	1.1096	1.3069	1.1584	1.2307
10	1.4853	1.3252		1.3633	1.4274	1.339	1.3573
11	1.6605	1.5242		1.5257	1.5531	1.6141	1.7795
12	1.9174	1.7535		1.9624	1.704	1.9197	1.9639
13	2.0073	1.8846		2.0241	1.8975	1.9806	2.1224
14	2.0188	1.9182		2.1209	1.9326	2.0066	2.0271
15	2.0142	1.864	2.649	2.0737	.9617	1.0235	1.0227
16	1.025	1.9037	2.572	2.1285	.9419	2.0515	1.0037
17	.6889	1.8435	2.4661	2.1087	.9526	2.0485	1.0357
18	2.3807	1.8442	2.4737	2.1011	.9335	2.0607	1.057
19	2.4325	2.0013	2.6239	2.476	2.0028	2.2794	2.3129
20	2.3601	2.0409	2.5004	2.2359	1.0059	2.2581	2.2954
21	2.111	1.8716	2.114	2.0309	1.765	2.0042	2.0538
22	1.6454	.8253	1.6986	1.5996	1.4807	1.6149	1.5981
23	1.3816	1.3794	1.4503	1.3809	1.4091	1.4281	1.4152
24	1.2811	1.3298	1.3664	1.3748	1.4015	1.3908	1.3878
Max	2.4325	2.0409	2.649	2.476	2.0028	2.2794	2.3129
Min	.5883	.8253	.5677	1.1042	.9335	.6455	1.0037
Avg	1.4636	1.4766	1.6662	1.6274	1.3504	1.5424	1.4619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 206 / 11 KV COLLECTOR OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1334	.1334	.1334	.1334	.1334	.1334
2	.1334	.1334	.1334	.1334	.1334	.1334	.1334
3	.0953	.1334	.1334	.1334	.1334	.1334	.1334
4	.0953	.1334	.1334	.1334	.1334	.1334	.1334
5	.0953	.1334	.1334	.1334	.1334	.1334	.1334
6	.0953	.0953	.0953	.1334	.0953	.0953	.1334
7	.0572	.0572	.0953	.0953	.0953	.0953	.1334
8	.0953	.0953	.0953	.1334	.0953	.0953	.1334
9	.0572	.0572	.0381	.0953	.0953	.1334	.1334
10	.1524	.0953		.1905	.1524	.1715	.2667
11	.5525	.0953		.6288	.7812	.8193	.5526
12	.5716	.1715		.6669	.8383	.8002	.6669
13	.5907	.1715		.6669	.8955	.9526	.6097
14	.686	.1715	.6478	.6478	.6478	.6859	.6288
15	.5334	.1905	.7431	.5907	.5716	.7812	.5335
16	.5716	.1905	.705	.6288	.6478	.724	.5716
17	.4572	.1905	.7431	.6288	.6859	.724	.6097
18	.4191	.1715	.5907	.5907	.5335	.705	.5716
19	.362	.1715	.3048	.3048	.4001	.362	.3429
20	.2286	.1715	.2858	.2667	.2667	.3048	.4192
21	.2286	.1525	.1715	.2096	.2477	.1715	.1715
22	.1524	.0762	.1334	.1334	.2096	.1334	.1334
23	.1334	.0953	.1334	.1334	.1334	.1334	.1715
24	.0953	.1334	.1334	.1334	.1334	.1334	.1334
Max	.686	.1905	.7431	.6669	.8955	.9526	.6669
Min	.0572	.0572	.0381	.0953	.0953	.0953	.1334
Avg	.2731	.1342	.2792	.3144	.3414	.3620	.3160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 241 / 11 KV COLLECTOR OFFICE I/C

NO. Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.9912	2.934	3.1245	3.1817	2.9721	3.1245
2	2.6482	2.915	2.8769	3.0102	3.0483	2.9721	3.0102
3	2.6101	2.8197	2.8006	2.8959	3.0102	2.9721	2.915
4	2.5149	2.7244	2.7625	2.8006	2.915	2.9721	2.553
5	2.4768	2.6482	2.6863	2.7625	2.8769	2.9721	2.553
6	2.3624	2.572	2.6292	2.6482	2.7435	2.6863	2.5911
7	2.3815	2.7054	2.7054	2.7435	.7621	2.7625	
8	1.0669	2.5911	2.553	2.8578	3.2579	2.8006	2.6482
9	2.5339	2.7244		2.7054	2.915	2.7244	2.7244
10	2.5149	2.6863		2.6482		2.6673	2.7054
11	2.7816	2.8387		2.5911	2.915	2.6863	2.8006
12	2.8387	2.8959		2.8578	3.0483	2.7816	2.191
13	2.9531	2.8769		2.8197	1.4098	2.8769	2.4768
14	2.8769	2.8959		2.2862	3.0674	.3048	3.0864
15	2.8959	2.9721	3.6008	3.1055	3.296	2.7625	
16	.3048	2.915	3.6008	3.2198	3.2198	2.3624	
17		2.9912	3.4865	3.1436		3.0674	
18	2.8578	2.934		3.0483	2.8769	3.1436	
19	3.3341	3.2769	3.315	3.5818	3.1626	3.5437	3.3722
20	3.7532	3.4103	3.5246	3.6389		3.6008	3.4865
21	3.2769	3.1436	3.4103	3.2579	3.4294	3.1817	3.1055
22	3.2198		3.3532	3.315	3.315	3.2769	3.1055
23	3.2198	3.2198	3.315	3.4865	3.3913	3.3722	3.2769
24	2.915	3.2007	3.1055	3.3532	3.3341	3.315	3.3341
Max	3.7532	3.4103	3.6008	3.6389	3.4294	3.6008	3.4865
Min	.3048	2.572	2.553	2.2862	.7621	.3048	2.191
Avg	2.6557	2.9108	3.0976	2.9959	2.9132	2.8657	2.8979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 242 / 11KV COLLECTOR OFFICE I/C
NO.2 Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.2574	1.3527	1.467		1.3146	1.4289
2	1.2574	1.2574	1.2955	1.3908		1.3146	1.3908
3		1.2574	1.2574	1.3527		1.3146	1.3146
4	1.1241	1.2003	1.2003	1.3146		1.3146	1.105
5	1.1241	1.1812	1.1812	1.2765		***	1.1241
6	1.0669	1.1431	1.1241	1.2384		1.1622	1.2003
7	1.0479	1.1241	1.1241	1.1622		1.105	1.1431
8	1.0669	1.1812	1.1622	1.1622	1.4098	1.105	1.2193
9	1.2003	1.1812		1.1812	1.4289	1.2003	1.3146
10	1.6385	1.4098		1.5813	1.5813	1.4861	1.5242
11	2.0386	1.7718		2.1148	2.0957	2.191	2.21
12	2.3815	2.0767		2.4387	2.3053	2.4196	2.572
13	2.553	2.191		2.5339	2.4958	2.6673	2.7054
14	2.5149	2.1719		2.7054	2.4958	2.6673	2.572
15		2.2672	3.1817	2.6673	2.553	2.5911	
16	.0762	2.2862	3.2198	2.7244	2.4958	2.6101	
17		2.191	3.0483	2.6292	2.3815	2.6101	
18	2.8578	2.191	3.0674	2.6673	2.3434	2.6101	
19	2.8769	2.3243	3.0674	2.8578	2.5339	2.7435	2.7816
20	2.7244	2.2862	2.8197	2.6292		2.6292	2.7244
21	2.3434	2.0576	2.3434	2.3243	2.0005	3.1817	2.2481
22	1.6575		1.7528	1.6575	1.5432		1.6004
23	3.2198	1.4861	1.5813	1.5242	1.5432	1.5051	1.5051
24	1.3717	1.4289	1.467	1.5813	1.5242	1.4861	1.5051
Max	3.2198	2.3243	3.2198	2.8578	2.553	10.2881	2.7816
Min	.0762	1.1241	1.1241	1.1622	1.4098	1.105	1.105
Avg	1.7827	1.6923	1.9581	1.9243	2.0457	2.3268	1.7595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 401 / 33KV APATAPA TO COLLECTOR

I/C Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2295	4.3439	4.4582	4.7439	4.7439	4.4582	4.5153
2	4.1152	4.2867	4.3439	4.5725	4.5153	4.4582	4.401
3	3.9438	4.1152	4.2295	4.3439	4.401	4.4582	4.2295
4	3.8866	4.0009	4.1152	4.2295	4.3439	4.4582	3.658
5	3.8866	3.8866	4.0009	4.0581	4.2295	4.4582	3.658
6	3.5437	3.658	3.8295	3.9438	3.9438	4.0009	4.0009
7	3.658	3.7723	3.8866	3.8866	.8002	4.0009	4.0009
8	3.7723	3.8295	3.8866	4.0581	4.5725	4.1724	4.0009
9	3.7723			3.9438	4.4582	4.0581	4.1724
10	4.2295	4.1152		4.1724	4.4582	4.2867	4.4582
11	5.0297	4.6868		4.9154	5.144	4.9726	5.0869
12	5.4298	5.0869		5.5441	5.5441	5.4298	5.2012
13	5.8299	4.0009		5.6013	4.1152	5.7728	5.3727
14	5.8299	5.2584		5.144	5.8299	3.0864	5.9442
15		5.3727			6.0585	5.5441	6.0585
16	.4001	5.3155	6.8016	6.23	5.8871	5.144	5.9442
17		5.3155	6.8016	6.0014		5.7728	
18	6.23	5.144	6.973	5.9442		6.0014	
19	6.23	5.7156	7.1445	6.8016	6.2872	6.4015	6.4586
20	6.5158	5.7728	6.5158	6.4586		6.4586	6.5158
21	5.7156	5.2012	6.0014	5.7728	5.6013	5.7156	5.6584
22	4.9726		5.2584	5.2012	5.0297	5.0297	4.9726
23	4.8011	4.7439	5.2012	5.144	5.487	4.9726	4.9726
24	4.5153	4.5725	4.7439	4.9726	4.9154	4.4582	4.8583
Max	6.5158	5.7728	7.1445	6.8016	6.2872	6.4586	6.5158
Min	.4001	3.658	3.8295	3.8866	.8002	3.0864	3.658
Avg	4.5699	4.6452	5.1878	5.0297	4.7793	4.8988	4.9154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 201 / 11KV Bhim Nagar Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.3772	.3772	.3944	.3772	.3772	.3772
2	.703	.3429	.3772	.3944	.3772	.3772	.3772
3	.703	.3429	.3601	.3772	.3772	.3772	.3601
4	.703	.3429	.3601	.3772	.3772	.3772	.3601
5	.703	.3601	.3601	.3429	.3772	.3772	.3601
6	.7202	.3601	.3429	.3601	.3772	.3772	.3429
7	.7202	.3601	.3429	.3601		.3772	.3429
8	.7373	.3429	.3086	.3086	.4287	.3086	.3429
9	.7202	.3086	.3086	.3086	.3841	.3086	.3086
10	.6173	.2915	.2915	.2743	.3429	.2743	.2915
11	.583	.2743	.2915	.2743	.3086	.2915	.3086
12	.6173	.2915	.2915	.3258	.3086	.2915	.2743
13		.2915	.2743	.3086	.3086	.2915	.2915
14	.5487	.3086	.2915	.2743	.3086	.3258	.3086
15		.3258	.3258	.2915	.3429	.3258	.3292
16	.6516	.3086		.3086	.2401	.3086	.3086
17		.3086	.3429	.3109	.3086	.2915	.3086
18	.3429	.3086	.2915	.2743	.2915	.2743	
19	.3944	.3601	.3601	.3429	.3429	.3429	.3258
20	.4115	.3601	.3944	.3601	.3772	.3429	.3601
21	.3944	.3601	.3772	.3772	.3772	.3772	.3772
22	.4115	.4115	.3944	.3944	.3944	.3944	.3772
23	.4287	.4287	.4287	.4287	.4115	.4287	.4115
24	.7716	.4115	.4115	.3944	.4115	.3772	.3944
Max	.7716	.4287	.4287	.4287	.4287	.4287	.4115
Min	.3429	.2743	.2743	.2743	.2401	.2743	.2743
Avg	.6001	.3408	.3437	.3402	.3544	.3415	.3408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 202 / 11KV Tilak Road Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-APR-17
HR	Load (MW)
1	.6859
2	.6516
3	.6001
4	.5316
5	.5316
6	.5487
7	.5487
8	.5487
9	.6173
10	.7545
11	.6173
12	1.3717
14	1.406
16	1.4403
24	.6859
Max	1.4403
Min	.5316
Avg	.7693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 204 / 11KV Bhandpura Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.7888	.7716	.2229	.2058	.2058	.2058
2	.6859	.7373	.7545	.2229	.2058	.208	.1886
3	.6859	.7202	.7545	.2058	.2058	.2058	.1715
4	.6859	.7202	.7545	.2058	.2058	.2058	.1715
5	.6859	.7202	.7373	.2058	.2058	.2058	.1715
6	.7202	.7202	.7373	.2058	.2058	.2058	.1886
7	.7716	.7716	.7545	.2058		.2058	.1715
8	.7716	.7545	.7888	.1715	.2058	.1715	.1543
9	.7373	.7545		.1715	.1829	.1715	.1715
10	.7716	.7202	.7888	.1372	.1543	.1372	.1372
11	.703	.703	.7373	.1372	.1715	.1372	.1543
12	.7545	.7716	.7202	.1543	.1715	.1372	.1372
13		.7545	.6859	.1372	.1715	.1543	.1543
14	.703	.7373	.1715	.1886	.1715	.1543	.1715
15		.7545	.1715	.1886	.1886	.1715	.1829
16	.7202	.7373		.1715	.1886	.1715	.1715
17		.7545	.1715	.1646	.1715	.1543	.1543
18	.9259	.7545	.1715	.1543	.1543	.1372	
19	.9945	.9431	.1715	.1715	.1715	.1715	.1715
20	.9431	.9088	.1886	.1715	.1715	.1715	.1886
21	.8573	.7888	.1886	.1886	.1715	.1886	.1715
22	.823	.8402	.2058	.2058	.2058	.2058	.2058
23	.8573	.8573	.2058	.2058	.2058	.2058	.2058
24	.7545	.823	.823	.2229	.2229	.2058	.2229
Max	.9945	.9431	.823	.2229	.2229	.208	.2229
Min	.6859	.703	.1715	.1372	.1543	.1372	.1372
Avg	.7749	.7723	.5207	.1841	.1876	.1787	.1750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 205 / 11 KV Ganesh Nagar Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.166	1.166	1.2689	1.2986	1.2174	1.2003
2	1.6289	1.0802	1.0802	1.2003	1.2986	1.2174	1.0631
3	1.5432	1.046	1.0288	1.166	1.2986	1.2174	1.0288
4	1.4575	1.0288	.9945	1.1145	1.2986	1.1145	.9945
5	1.3717	.9945	.9602	1.0288	1.1888	.9259	.9945
6	1.4403	.9431	.9431	.9602	1.0425	.9259	.8916
7	1.3032	.8745	.8916	.9774		.9431	.8916
8	1.3375	.8916	.8916	.9259	1.1523	.8745	.8059
9	1.2689			.9088	1.0425	.8916	.7716
10	1.2346	.7716	.8745	.8916	.9088	.8059	.7373
11	1.2346	.8402	.7888	.823	.823	.823	.8573
12	1.2517	.8573	.7545	.9259	.9088	.8745	.8745
13		.9945	.9259	.9431	1.0288	.9774	.9088
14	1.5432	1.046	1.0288	1.046	1.0974	.9945	1.046
15		1.046	1.0974	1.0802	1.0802	1.046	1.1523
16	1.5947	1.046		1.0631	1.0974	1.0631	1.0631
17		.9774	1.166	1.0791	1.0288	.9774	.9774
18	1.166	.9088	1.0288	.8916	.9774	.8573	
19	1.1831	1.046	1.1145	1.0631	1.0631	.9602	1.0117
20	1.2003	1.046	1.1145	1.1145	1.0974	1.0802	1.0802
21	1.166	1.0802	1.2003	1.1488	1.0974	1.1317	1.1317
22	1.166	1.1488	1.2174	1.2346	1.166	1.1831	1.1488
23	1.2346	1.2517	1.3032	1.286	1.2517	1.2689	1.2346
24	1.8519	1.2346	1.1488	1.3032	1.3352	1.2689	1.3032
Max	1.8519	1.2517	1.3032	1.3032	1.3352	1.2689	1.3032
Min	1.166	.7716	.7545	.823	.823	.8059	.7373
Avg	1.3758	1.0139	1.0327	1.0602	1.1123	1.0267	1.0073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 206 / 11 KV Shivcharan Peth
Feeder Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4801	.4801	.5144	.4938	.4801	.4801
2	.3772	.4458	.4458	.4801	.4938	.4801	.4458
3	.3601	.4287	.4287	.4801	.4938	.4801	.4287
4	.3601	.4115	.4287	.4458	.4938	.4801	.4287
5	.3601	.3944	.4287	.4115	.4938	.4801	.4287
6	.3772	.3772	.4287	.4458	.4572	.4115	.3772
7	.3601	.3601	.3772	.4115		.3772	.3772
8	.3429	.3601	.3601	.3772	.439	.3601	.3429
9	.3258			.3601	.4024	.3601	.3429
10	.3258	.3429	.3601	.3601		.3429	.3601
11	.3772	.3601	.3429	.3944	.4115	.3944	.3772
12	.3258	.3601	.3772	.4115	.3944	.4287	.3601
13		.3944	.4287	.4115	.3944	.3944	.3944
14	.3429	.4458	.4115	.4287	.4115	.4115	.4458
15		.4458	.4287	.4801	.4287	.4458	.439
16	.463	.4458		.4458	.4458	.4287	.4458
17		.4458	.4973		.4458	.4287	.4115
18	.4973	.3944	.4801	.4287	.4115	.3944	
19	.4115	.4801	.4973	.4973	.463	.4458	.4801
20	.5144	.4801	.4801	.5144	.4458	.463	.463
21	.4801	.4458	.4801	.4801	.4458	.4801	.463
22	.4801	.4287	.4973	.4973	.463	.463	.4801
23	.4973	.4973	.5316	.5144	.4973	.5316	.4973
24	.4973	.4973	.5144	.5144	.5487	.0514	.4973
Max	.5144	.4973	.5316	.5144	.5487	.5316	.4973
Min	.3258	.3429	.3429	.3601	.3944	.0514	.3429
Avg	.4058	.4227	.4412	.4481	.4534	.4172	.4246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 201 / 11 KV KHADKI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7417	5.0975	4.7135	5.0286	4.8765	5.49	5.0587
2	4.4772	4.7603	4.446	4.7927	4.7003	5.3445	4.7371
3	4.2383	4.7916	4.2322	4.4642	4.4589	5.0739	4.5131
4	4.0966	4.4818	4.0748	4.2909	4.322	4.8312	4.3925
5	3.8725	4.196	3.9594	4.0638	4.0013	4.497	1.9071
6	3.8016	3.9522	3.8824	3.9822	4.1213	4.2326	1.8821
7	3.7495	3.645	3.8537	3.8295	4.0391	4.0428	1.9105
8	3.5193	3.6164	3.6304	3.6092	3.5915	3.7439	1.6991
9	3.3166	3.3836	3.632	3.3006	3.5147	3.4739	1.8107
10	3.1443	3.2472	3.3429	3.4027	3.3714	3.3966	1.6827
11	3.171	3.2495	3.3364	3.296	3.2785	1.7513	1.7193
12	3.1512	3.3394	3.3768	3.5456	3.3722	3.5372	1.8107
13	3.4551	3.6553	3.5627	3.8486	3.8192	3.6481	1.9805
14	3.6488	3.9601	4.0706	4.2227	4.0885	4.2036	2.1313
15	3.8504	4.1144	4.0778	4.5039	4.3416	4.4906	2.2218
16	3.9131	4.3598	4.3934	2.2878	4.3008	4.5568	2.0748
17	4.0405	4.1812	3.9682	4.0527	2.1948	4.5195	1.9547
18	3.8146	3.894	3.7586	3.9438	2.1338	3.9839	
19	4.3671	4.1198	4.3972	4.3393	2.2702	4.4189	2.0576
20	4.7173	4.5369	4.776	4.9002	2.6795	4.7653	2.2291
21	4.7733	4.7615	4.9402	5.0975	2.7122	5.0078	2.2891
22	5.1696	4.8354	5.3292	5.3296	2.8845	5.401	2.4272
23	5.4078	5.0225	5.4493	5.4085	3.0392	5.5292	
24	5.0773	5.3606	5.0574	5.3433	5.5898	5.6981	2.5486
Max	5.4078	5.3606	5.4493	5.4085	5.5898	5.6981	5.0587
Min	3.1443	3.2472	3.3364	2.2878	2.1338	1.7513	1.6827
Avg	4.0631	4.1901	4.1775	4.2035	3.6542	4.4016	2.5017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 202 / 11 KV MALKAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5045	.5304	.4524	.5483	.5289	.5556	.5061
2	.4863	.49	.4134	.5045	.4923	.5175	.4733
3	.45	.4853	.4004	.4946	.4825	.2545	.426
4	.4363	.4413	.3844	.4691	.4458	.4883	.4047
5	.4131	.423	.3745	.439	.4412	.4759	.4352
6	.4321	.3829	.4243	.4337	.4718	.4643	.4641
7	.41	.3847	.2157	.4073	.4412	.4352	.4029
8	.3753	.3679	.3588	.3883	.3742	.3681	.3892
9	.3433	.3392	.3772	.3928	.362	.2065	.4314
10	.3501	.3346	.3247	.3596	.3829	.386	.3913
11	.3661	.3974	.3201	.3544	.3895	.3814	.205
12	.373	.4027	.3551	.431	.4149	.3883	.3921
13	.4267	.439	.3734	.4374	.4878	.434	.4172
14	.4052	.4675	.3875	.5028	.4683	.4736	.4233
15	.445	.4835	.2279	.4938	.4969	.4984	.4035
16	.4321	.4904	.4142	.253	.487	.4759	.2484
17	.3666	.4458	.3936	.4713	.2271	.4442	.3997
18	.3628	.4488	.4149	.4454	.2058	.4253	.2408
19	.4489	.4734	.503	.4648	.2591	.5517	.442
20	.4496	.442	.5236	.4992	.2774	.5716	.5144
21	.5099	.4709	.6085	.5106	.2957	.5487	.5556
22	.5288	.4881	.6428	.6226	.3323	.5598	.5959
23	.5849	.5085	.6317	.5765	.3338	.5689	.3391
24	.5605	.5854	.5083	.5807	.5657	.5815	.5327
Max	.5849	.5854	.6428	.6226	.5657	.5815	.5959
Min	.3433	.3346	.2157	.253	.2058	.2065	.205
Avg	.4359	.4468	.4179	.4617	.4027	.4606	.4181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 241 / 11 KV INCOMER NO-I

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2977	2.6217		2.572	.823	3.6755	
2	2.1948	2.4356		2.4863	.8535	3.6707	
3	2.0748	2.4709		2.2977	3.1001	3.6353	2.0856
4	2.0405	2.0748		2.2634	.8535	3.4935	
5	1.8861	2.0936		2.1605	2.9507	3.3249	
6	1.8176			2.1776	.8535	3.2455	1.9765
7	1.7661	1.8296		2.2291	.8535	3.1923	
8	1.6289	1.7164	2.0858	2.2291	3.0748	3.0683	1.7337
9	1.5604	1.5604	2.3045	2.1948	3.134	2.1434	
10	1.9113	2.0919	1.5424	1.6787	2.4139	1.6289	2.0858
11		2.1948	1.7164		2.4139	.0686	2.1616
12		2.1776		1.7375	2.4482	1.8347	2.2085
13		2.3663	1.8671	1.9805	2.6882	1.7147	2.392
14		2.4348	2.0182	1.9448	2.8254	2.0576	2.5514
15	2.4417	2.5405	2.0936	2.1209	2.9283	2.1605	2.8669
16		2.572	2.1313		2.9283	2.1948	2.7641
17	2.4006	2.3102	1.8004	1.7652	2.8341	2.1534	2.5034
18	1.7147		1.7661		2.7465		
19	2.0233		2.2291	2.0645	3.086		2.2291
20	2.2018		2.3491		3.3695	2.2552	2.4006
21	2.2634		2.4348		3.3695		
22	2.5393		2.6235		3.5467	2.4777	2.5434
23	2.7161		2.6063		3.5025		
24	2.4006	2.3752	2.4247	2.692	3.4309	2.822	2.6179
Max	2.7161	2.6217	2.6235	2.692	3.5467	3.6755	2.8669
Min	1.5604	1.5604	1.5424	1.6787	.823	.0686	1.7337
Avg	2.0989	2.2274	2.1246	2.1526	2.5429	2.5409	2.3414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 242 / 11 KV INCOMER NO-II

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8404	1.9221	.9602	1.7433	.9145	1.9976	
2	1.8404	1.949	.9145	1.7433	1.7623	1.8685	
3	1.8061	1.8004	.9145	1.6975	.8688	1.8873	
4	1.7776	1.8004	.8688	1.6518	1.6327	1.8496	.8149
5	1.7776	1.8381	.8688	1.6346	.8688	1.8307	
6	1.7776	1.7033	.823	1.6175	1.7239	1.7742	
7	1.7776	1.669	.9145	1.5832	.8688	1.793	
8	1.7146	1.7524	1.6118	1.6003	1.6613	.9808	.8589
9	1.7433	1.749	1.8536	1.6175	1.8518	.8745	.9619
10	1.8833	1.8804	1.8004	1.6175	1.9033	1.0117	.8865
11	.9602	1.8175	1.6445	1.7452	2.0291	.9945	.9242
12	1.0059	1.8175	1.6736	1.7627	2.0062	.9602	.8865
13	.9602	1.8061	1.8147	1.6643	2.0004	1.0288	1.0185
14	1.0974	1.8861	1.9829	1.7863	2.1262	1.046	1.0374
15	2.229	1.9833	2.0273	1.8991	2.1948	1.1145	.9259
16	1.1431	1.9661	1.7147	.9602	2.1491	1.0802	.9389
17	1.9852	1.8991	1.5832	1.9215	1.0517	.9465	.9945
18	2.0234	.9145	2.0861	.9602	1.0517		
19	1.9776	.8688	2.1148	1.9421	.9145		.9431
20	1.9662	.8688	1.829	.9145	.9602	.9882	.9259
21	1.9013	.8688	1.8805	.9602	.9145		
22	1.9208	.9602	1.8919	1.0059	.9602	.9326	.9709
23	1.9666	.9602	1.8576	.9602	1.0059		1.0059
24	2.0291	1.8175	1.7665	1.8404	1.8656	1.0374	1.8589
Max	2.229	1.9833	2.1148	1.9421	2.1948	1.9976	1.8589
Min	.9602	.8688	.823	.9145	.8688	.8745	.8149
Avg	1.7127	1.6041	1.5582	1.5346	1.4703	1.2998	.9971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 401 / 33KV I/C Khadki feeder

Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.6584	6.286		6.7901		6.5729	
2	5.7099	6.4198		6.8416		6.6255	5.3921
3	5.5556	6.1248		6.4815		6.5729	
4	5.5556	6.2809		6.4301	5.3635	6.4849	
5	5.4527	5.9808		6.6358		6.31	5.4613
6	5.5556	5.4527		6.893		6.166	
7	5.5556	6.1677		7.0473		5.8471	
8	5.2984	6.1111	6.1043	7.0473	6.6129	6.0597	5.6173
9	5.1955	5.3498		6.8416	6.6358	5.6584	4.5222
10	7.0919	6.8416	6.0545	5.2584	5.7613	5.8128	6.31
11		5.4527	5.8162	6.1111	6.0185	4.2696	7.2039
12		6.3272	6.1677	4.7851	5.6584	6.07	7.0919
13		6.9959	6.6084	4.9954	5.6584	6.2243	6.3935
14		7.0988	7.3605	6.5072	5.8642	4.0124	6.8039
15	6.941	7.2017	3.1121	5.9945	4.6296	5.0412	7.2257
16		7.4589	2.9424		5.8642	5.5041	7.356
17	7.0919	7.3857	5.8642	5.2395	5.1006	5.0972	7.4589
18	4.9429		4.3724		4.417		
19	4.0832		5.5041	5.5133	5.3109		5.2984
20	5.2984	3.6054	5.5556		5.5281	5.4938	5.607
21	5.8162		5.6584		5.475	4.7851	
22	5.8025		5.8642		5.7842	5.7213	5.8894
23	6.2243		5.8128		5.7939		
24	5.6584		4.3759	7.0473	5.4898	6.7158	5.8253
Max	7.0919	7.4589	7.3605	7.0473	6.6358	6.7158	7.4589
Min	4.0832	3.6054	2.9424	4.7851	4.417	4.0124	4.5222
Avg	5.7099	6.2523	5.4484	6.2478	5.6092	5.7640	6.2161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 402 / 33 KV DABAKI-NIMBI O/G NON SHEDDABLE WATER SUPPLY AND
FEEDER Feeder KV- 33 / INCOMING UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4177	2.7778		3.3436		3.0624	
2	2.572	2.955		3.4979		3.0087	
3	2.572	2.7778		3.2922	2.1365	2.955	
4	2.6235	3.1121		3.2922		2.955	
5	2.6749	3.0087		3.6008		3.0407	
6	2.8292	3.1276		3.858		2.955	
7	2.8807	3.1602		4.0124		2.955	
8	2.7778	3.4517	3.4328	4.0124	3.5208	2.9012	3.0013
9	2.7778	2.8807	3.2373	3.8066	3.4979	2.7263	2.1491
10	4.1289	3.858	3.5665	3.1161	3.2407	3.1893	3.546
11		2.4177	3.4922	3.546	3.4979	3.1893	4.3519
12		3.2922	1.6655	2.5766	3.1379	3.2922	4.513
13		3.7551	3.8146	2.3663	2.8292	3.4979	3.1699
14		3.7551	4.8097	3.0498	2.8807	.9259	3.1161
15	3.5608	3.7037		2.9172	1.4403	1.749	3.3385
16		3.9095			2.6749	2.2119	3.2922
17	3.4922	3.9169	3.2407	3.1093	2.1033	1.9765	3.9609
18	1.8267		1.5432		1.7193		
19	.9671		2.0576	2.3926	2.1491		2.1091
20	2.4177	.7968	2.2634		2.1491	2.2119	2.2634
21	2.1719		2.2119		2.2028	1.3226	
22	2.2131		2.2634		2.2262	2.0856	2.2131
23	2.1605		2.2634		2.1719		
24	2.2634	2.955	1.0688	3.4465	2.3405	3.0624	2.2885
Max	4.1289	3.9169	4.8097	4.0124	3.5208	3.4979	4.513
Min	.9671	.7968	1.0688	2.3663	1.4403	.9259	2.1091
Avg	2.5962	3.1375	2.7287	3.2909	2.5511	2.6321	3.0938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.2538	10.6985	9.1564	11.6427	9.0021	9.3964	11.653
2	9.7222	10.4167	8.6591	11.1282	11.1111	8.882	11.19
3	9.225	9.9605	8.2819	10.631	8.4191	8.5391	10.7922
4	8.9163	7.1502	7.9561	10.2367	10.2635	8.1962	10.0263
5	8.3676	8.8517	7.6475	9.9109	7.7675	7.9561	7.2874
6	8.2133	8.3505	7.6132	9.7565	9.7663	7.8018	9.4478
7	8.1962	7.971	7.9047	9.928	7.7675	7.8704	9.1701
8	7.7504	7.6646	9.7634	9.8937	9.8863	7.8532	8.4225
9	7.1845	7.4246	10.1954	9.9108	10.048	9.8594	7.6852
10	8.6638	9.3108	8.7785	9.1729	7.8189	8.6934	9.1632
11	6.9273	9.6193	7.0302	6.9639	7.0988	5.6927	9.4422
12	7.6646	9.6537	6.3775	7.3914	7.3732	8.0247	7.9647
13	7.9904	10.2367	7.8001	8.1533	8.1962	7.9046	10.0137
14	8.5563	10.8196	8.3962	9.0284	8.7448	8.8992	10.9122
15	11.1694	11.2655	9.1581	9.5851	9.4307	9.5679	11.5741
16	8.522	11.5741	9.2673	7.3045	9.4479	9.7908	11.7205
17	11.1443	11.4518	8.7963	8.9301	7.0473	9.6434	11.4026
18	9.9589	8.3848	8.1448	6.5844	6.8073	6.6358	8.2648
19	9.1633	7.2017	9.465	7.0473	7.1845	7.0988	9.345
20	10.2355	8.0418	10.3567	7.9561	8.4877	10.3247	10.391
21	10.3407	8.2648	10.7339	8.2305	8.5905	8.3848	8.2305
22	10.7682	8.6934	11.5227	8.8649	9.1221	11.5124	11.2597
23	11.4369	9.2421	11.9514	9.4136	9.6365	9.465	9.3964
24	11.2826	11.7027	11.6627	11.9856	12.0656	9.345	12.236
Max	11.4369	11.7027	11.9514	11.9856	12.0656	11.5124	12.236
Min	6.9273	7.1502	6.3775	6.5844	6.8073	5.6927	7.2874
Avg	9.2356	9.3313	9.0258	9.1521	8.7951	8.6391	9.8746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO-II
Feeder KV- 33 / INCOMING

SHEDDABLE RURAL

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9619		.8745		1.0082	
2	.9259	.9054		.8745	.8048	.9619	
3	.8745	.823		.8745		.9877	
4	.9259	.8322		.8745	.8048	.9619	
5	.9259	.9054		.8745		.9522	
6	.9259	5.715		.823	.8551	.8962	
7	.9259	.7545		.823		.8962	
8	.8745	.7202	.7545	.823	.8139	.9522	.8648
9	.8745	.7716	.9328	.823	.8745	.8745	.9619
10	.9231	.8745	.8779	.8413	.9259	1.0288	.8962
11		.8745	.8962	.9054	.9774		.9054
12		.8745		.8939	.9259		
13		.8745	.9259	.8048	.9774	1.0288	1.0185
14		.9259	1.1317	.8939	1.0288	1.0288	1.0185
15	1.0402		1.0751	.9259	1.0802	1.1317	.9568
16		.9774	.7545		1.0802	1.0802	.9259
17	.9054	.9054	.823	.9362		.9156	.9774
18	.8551		1.0802				
19	.9134		1.1831	.9156			.9259
20	.9054		.9774			.9665	.9259
21	.8139		1.0288				
22	.9054		.9774			.9465	.9156
23	.823		.9259				
24	.9774	.8048	.8939	.9259	.8745	.9877	.8648
Max	1.0402	5.715	1.1831	.9362	1.0802	1.1317	1.0185
Min	.8139	.7202	.7545	.8048	.8048	.8745	.8648
Avg	.9074	1.1471	.9524	.8726	.9249	.9781	.9352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 204 / TRANSPORT NAGAR

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381				.0191	
2						.0191	
3						.0191	
4						.0191	
5						.0191	
9						.0191	
10	.0191			.0191		.0191	
11	.0381	.0381		.0381		.0381	.0191
12	.0381	.0381	.0191	.0381		.0381	.0381
13	.0381	.0381	.0191	.0381		.0381	.0381
14	.0381	.0191	.0381	.0381		.0381	.0381
15	.0381		.0381	.0381	.0572	.0381	.0381
16	.0572	.0191	.0381	.0381	.0572	.0381	.0381
17	.0389	.0381	.0381	.0381		.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381		.0381	.0381	.0381	.0381
20	.0381	.0191	.0381	.0381	.0381	.0381	.0381
21		.0191		.0381	.0381	.0381	.0381
22	.0381	.0191	.0191	.0191		.0191	.0381
23	.0381	.0191		.0191	.0191	.0191	.0381
24		.0381				.0381	.0191
Max	.0572	.0381	.0381	.0381	.0572	.0381	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0382	.0300	.0318	.0340	.0408	.0300	.0354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 205 / 11KV NARAYAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6607	.6432	.6417	.6325	.5494	.6173	.6249
2	.6623	.6264	.6508	.6287	.5449	.6157	.6256
3	.66	.3033	.647	.6272	.5494	.618	.6241
4	.6546	.3048	.6447	.6233	.5502	.6119	.6203
5	.6493	.3079	.6501	.6272	.5487	.6066	.615
6	.647	.6127	.6585	.3231	.5685	.6081	.6256
7	.6287	.6104	.6623	.3193	.5693	.6134	.6637
8	.6402	.6614	.6226	.3231	.6287	.6554	.6813
9	.7316	.7209	.6531	.644	.7011	.7704	.8192
10	.9945	1.1713	.6218	.9999	.5037	1.2376	1.374
11	1.3565	1.6263	.6173	1.2887	.7407	1.5401	1.6019
12	1.5379	1.5371	.6364	1.4335	.8169	1.5989	1.6491
13	1.4503	1.3245	.6417	1.3496	1.4487	1.451	1.3924
14	1.3321	1.118	.6508	1.2727	.5761	1.3573	1.272
15	1.6522	1.5135	.6493	1.3428	1.5097	1.4213	1.4297
16	1.6286	1.627	.6356	1.4571	1.5066	1.5546	1.5081
17	1.6918	1.544	.6165	1.5577	.7918	1.5988	1.5744
18	1.6377	1.5074	.6203	1.5683	1.4898	1.5196	1.5279
19	1.4716	1.2109	.3185	1.4525	1.3893	1.3329	1.5219
20	1.1164	.8444	.6089	1.108	.9762	1.0684	1.1751
21	.5014	.6767	.3185	.7842	.7842	.8162	.7949
22	.6965	.6531	.6241	.6539	.6783	.7194	.6371
23	.6515	.647	.3201	.6424	.6432	.7125	.6096
24	.6714	.6417	.6463	.6173	.6074	.6874	.6066
Max	1.6918	1.627	.6623	1.5683	1.5097	1.5989	1.6491
Min	.5014	.3033	.3185	.3193	.5037	.6066	.6066
Avg	1.0135	.9347	.5982	.9282	.8197	1.0139	1.0239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 206 / 11 KV B.K. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.2286	.1905	.2667	.2667	.2477
2	.1905	.2096	.2286	.1905	.2667	.2667	.2477
3	.1905		.2286	.1905	.2667	.2667	.2477
4	.1905		.2286	.1905	.2667	.2667	.2477
5	.1905		.2286	.1905	.2667	.2477	.2477
6	.1905	.1905	.2096		.2477	.2477	.2477
7	.2096	.1905	.2477		.2286	.2667	.2286
8	.2096	.2286	.1905		.2667	.2477	.2667
9	.2667	.1905	.1334	.2477	.2858	.3048	.3239
10	.4382	.381	.1524	.381		.4572	.4001
11	.5335	.5144	.1524	.4001		.4763	.4954
12	.6097	.4954	.1905	.4763		.4572	.4763
13	.5144	.4191	.1524	.4382		.4382	.4763
14	.4572	.4382	.1715	.4001		.4763	.4382
15	.5906	.4763	.1524	.4763	.6097	.4954	.4763
16	.4954	.4763	.1905	.5525	.5335	.5144	.4763
17	.5144	.4572	.1905	.5335		.5716	.4382
18	.5525	.4191	.1905	.5335	.5144	.5335	.5335
19	.4763	.4001		.4572	.5335	.5144	.5144
20	.4001	.2858	.1905	.3048	.4001	.362	.4191
21				.2477	.3239	.5716	.3239
22	.2096	.2286	.2096	.3048	.3048	.2858	.2667
23	.2286	.2286		.2667	.3239	.2858	.2667
24	.2096	.2096	.2286	.1905	.2667	.2667	.2667
Max	.6097	.5144	.2477	.5525	.6097	.5716	.5335
Min	.1905	.1905	.1334	.1905	.2286	.2477	.2286
Avg	.3504	.3325	.1950	.3411	.3429	.3787	.3572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 207 / 11KV DADAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.4382	.2286	.381	.362	.362
2	.362	.3429	.4382	.2286	.381	.362	.362
3	.362		.4382	.2286	.381	.362	.362
4	.362		.4382	.2286	.381	.362	.362
5	.3429		.4382	.2286	.362	.362	.362
6	.3239	.3429	.4382		.4001	.3429	.362
7	.3239	.3239	.3429		.362	.4763	.3239
8	.3429	.3429	.2286		.381	.4001	.362
9	.6287	.5716	.2096	.5716	.9526	.6859	.7811
10	1.0288	.8954	.2096	1.0479		1.2574	.9145
11	1.3527	.8954	.2096	.9907		1.4098	1.0669
12	1.2193	.9526	.2096	1.105		1.467	1.1622
13	.9526	.8002	.2667	1.0098		1.3527	.8954
14	1.105	.9907	.2096	1.1241		1.3908	.9717
15	1.105	1.0288	.2096	1.1812	1.3908	1.4289	1.105
16	1.1431	1.0479	.2096	1.2574	1.4098	1.4861	1.1812
17	1.3146	1.1431	.2096	1.2384		1.3527	.9526
18	1.1241	1.2193	.2096	1.2003	1.2193	1.3717	1.0479
19	1.0288	.9717		1.0669	1.3336	1.2574	1.0098
20	.6478	.8954	.2286	.9145	.7049	.8192	.4954
21		.6859		.5716	.5716	.5525	.3429
22	.381	.743	.2286	.5716	.6097	.5335	.3429
23	.4001	.6478		.5716	.4763	.381	.3239
24	.381	.381	.6859	.2286	.4001	.362	.362
Max	1.3527	1.2193	.6859	1.2574	1.4098	1.4861	1.1812
Min	.3239	.3239	.2096	.2286	.362	.3429	.3239
Avg	.7215	.7421	.3094	.7521	.6721	.8391	.6589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 208 / 11KV YEVATA ROAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1524	.2096	.1524	.1715	.1524	.2286
2	.1334	.1524	.1905		.1905	.1524	.2286
3	.1334		.1715	.0953	.2286	.1524	.2286
4	.1334		.1715		.2667	.1524	.2286
5	.1143		.1715		.2858	.1524	.2286
6	.1715	.2286	.2477		.2667	.1905	.2286
7	.1905		.1905		.2667	.1905	.2286
8	.1905	.1905	.1905		.2096	.1715	.2286
9	.2667	.2477	.1715	.1715	.1905	.1715	.2477
10	.3429	.2858	.1715	.3048		.2667	.3239
11	.4001	.3048	.1143	.3429		.3429	.362
12	.4572	.4001	.0953	.4001		.3429	.4001
13	.2858	.3048	.1143	.381		.362	.3239
14	.381	.3048	.0953	.381		.362	.3239
15	.4001	.362	.0953	.3239	.4001	.381	.381
16	.4382	.4382	.1143	.4191	.381	.381	.362
17	.5144	.5144	.1143	.4572		.4191	.2667
18	.4763	.4191	.1715	.4001	.3429	.4572	.2858
19	.4001	.3429		.381	.3429	.4191	.362
20	.4382	.2858	.1715	.4001	.381	.4763	.3048
21		.2096		.3048	.2858	.381	.2477
22	.2286	.2667	.1524	.3048		.3048	.2096
23	.1905	.3429		.2096	.2096	.3239	.2286
24	.1524	.1524	.3239	.1524	.1905	.1524	.2477
Max	.5144	.5144	.3239	.4572	.4001	.4763	.4001
Min	.1143	.1524	.0953	.0953	.1715	.1524	.2096
Avg	.2858	.2953	.1642	.3101	.2712	.2858	.2794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 241 / 11 KV INCOMER NO-I

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6729	.6828	.3239	.3048		.3239	.3048
2	.6745	.6173	.3239			.3239	.3048
3	.6699		.3239	.3048		.3239	.3048
4	.6577		.3239	.3048		.3239	.3048
5	.6546		.3239			.3239	.3048
6	.6562	.3048	.3239			.3048	.3048
7	.6294	.3048	.3239			.3048	.3429
8	.6592	.3429	.2858		.3239	.3429	.3429
9	.7918	.381	.3239	.3239	.362	.4382	.4572
10	1.1645	.6859	.3048	.5906	.6668	.7049	.743
11	1.4876			.7049		.8192	
12	1.6385			.724		.8002	
13	.8154			.5906		.6287	
14	.6615			.6478		.6859	
15	.9496			.7049	.7811	.7621	
16	1.6971	.8002	.362	.7049	.7621	.7811	.743
17	.9145	.7621	.3429	.7621			.7811
18	1.7116	.7049		.7811	.7811	.724	.743
19	.8535	.4572			.6668	.6097	.7621
20	.6722	.3429			.4001	.4191	.4191
21	.4024	.3239			.362		.362
22	.7453	.3429	.3239		.362	.381	.3429
23	.6813	.3429			.3239	.362	.3429
24	.6935	.362	.3239	.3048		.381	.3239
Max	1.7116	.8002	.362	.7811	.7811	.8192	.7811
Min	.4024	.3048	.2858	.3048	.3239	.3048	.3048
Avg	.8814	.4849	.3239	.5539	.5265	.5031	.4492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 242 / 11 KV INCOMER NO-II

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.724	.8764	.5716		.7811	.8383
2	.6859	.7049	.8573			.7811	.8383
3	.6859		.8383	.5716		.7811	.8383
4	.6859		.8383	.5144		.7811	.8383
5	.6478		.8383			.7621	.8383
6	.6859	.8002	.8954			.7811	.8383
7	.724	.7049	.7811			.9335	.7811
8	.743	.7621	.6097		.8573	.8192	.8573
9	1.1622	1.0098	.5144	1.0098	1.4289	1.1622	1.3527
10	1.8099	1.5623	.5335	1.7337	2.0005	1.9814	1.6385
11	2.2862			1.7337		2.2291	
12	2.2862			1.9814		2.2672	
13				1.829		2.1529	
14				1.9052		2.2291	
15				1.9814	2.4006	2.3053	
16	2.0767	1.9624	.5144	2.2291	1.9433	2.3815	2.0195
17		2.1148	.5144	2.2291		2.3434	1.6575
18	2.1529	2.0576		2.1338	2.0767	2.3624	1.8671
19		1.7147			2.21		1.8861
20		1.467	.5906		1.4861	1.6575	1.2193
21		1.1241			1.1812		.9145
22	.2477	1.2384			1.1241	1.1241	.8192
23	.8192	1.2193			.9907	.9907	.8192
24	.743	.743	1.2193	.5716		.7811	.8764
Max	2.2862	2.1148	1.2193	2.2291	2.4006	2.3815	2.0195
Min	.2477	.7049	.5144	.5144	.8573	.7621	.7811
Avg	1.1252	1.2443	.7444	1.4997	1.6090	1.4722	1.1441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 401 / 33 KV INCOMER NO-I

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER MIDC EQUIVALENT

HAVING WEEKLY STAGGERING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.321	4.3782	5.7956	3.3264	4.7897	4.5839	4.7782
2	4.0466	3.0864	4.6297	3.2579	4.3782	4.3096	4.5039
3	4.1152	3.0178	4.5039	3.2579	4.3667	4.241	4.5039
4	3.9095	3.0178	4.4353	3.2579	4.3553	4.1724	4.4353
5	3.8524	2.9492	4.2981	3.2008	4.3553	4.1724	4.3667
6	3.8409	3.9667	4.4925	2.4006	4.6297	4.1724	4.5039
7	3.978	4.1038	4.4468	3.2579	4.5725	4.5496	4.5039
8	4.0352	3.9667	3.9552	2.4691	4.5039	4.7096	4.5611
9	5.2469	4.5953	3.6008	4.1267	5.7499	5.2355	5.5327
10	7.5446	7.2474	3.0636	7.3503	8.7335	8.5162	8.2533
11	10.8482	9.6365	3.0636	9.4536	8.642	11.054	10.4253
12	11.7399	10.4595	3.8752	10.2995	8.7792	12.0713	11.4884
13	11.6599	10.2881	3.1893	10.4939	9.1221	12.6086	11.3397
14	11.0654	9.4193	3.1322	10.2538	7.9561	11.9685	10.5739
15	11.3397	10.0937	3.2008	10.7796	8.7792	11.6598	10.631
16	12.1171	10.974	3.2579	11.4884	12.2199	12.6086	11.0426
17	12.117	11.2254	3.2579	12.3	9.3964	12.8144	10.9625
18	12.2886	11.3855	3.3151	12.0942	12.2542	12.4828	10.6539
19	11.7627	10.8596	2.4691	11.5569	11.7055	12.1285	10.7225
20	9.8994	8.7563	2.5377	10.4252	10.3909	10.4938	9.8194
21	7.3617	7.5332	3.3836	8.0019	8.3333	7.3388	7.9104
22	5.0412	5.5785	3.395	6.0014	6.0129	6.3558	5.0526
23	4.5039	5.9328	2.6063	5.6927	5.4984	5.8985	4.5039
24	5.6242	5.407	4.0123	5.0411	5.0526	5.7956	4.5611
Max	12.2886	11.3855	5.7956	12.3	12.2542	12.8144	11.4884
Min	3.8409	2.9492	2.4691	2.4006	4.3553	4.1724	4.3667
Avg	7.5941	6.9949	3.6632	7.0745	7.2741	8.0809	7.4846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 403 / 33 KV OUTGOING FEEDER NO-I

Feeder KV- 33 / OUTGOING

DATE	16-APR-17
HR	Load (MW)
21	.9717
Max	.9717
Min	.9717
Avg	.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717		.3429			.3429	.2858
2	.9717		.3429			.3429	.2858
3	.9717		.3429			.3429	.2858
4	.9717		.3429			.3429	.2858
5	.9717		.3429			.3429	.2858
6	.9717		.3429			.2858	.2858
7	.9145		.3429			.2858	.3429
8	.9717		.2858			.3429	.3429
9	1.2003		.3429			.4572	.4572
10	1.7147			.5716		2.1148	.743
11	2.1719			.6859		2.4577	
12	2.2862			.743		2.4006	
13				.5716		1.8861	
14				.6287		2.0576	
15				.6859		2.2862	
16				.6859		2.3434	
17				.743			
18		.6859			.8002		2.2291
19		.4572			.6859		2.2862
20		.3429			.4001		1.2574
21		.3429			.3429		1.086
22		.3429			.3429	.4001	1.0288
23		.3429			.3429	.3429	1.0288
24	1.0288		.3429			.3429	.3429
Max	2.2862	.6859	.3429	.743	.8002	2.4577	2.2862
Min	.9145	.3429	.2858	.5716	.3429	.2858	.2858
Avg	1.2399	.4191	.3372	.6645	.4858	1.0378	.7565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO- SHEDDABLE RURAL
II Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.201	2.2462	3.8923	1.5604	2.7606	3.2522	3.4293
2	4.1838	2.2462	3.4979	1.5432	2.5549	3.1836	3.275
3	4.0809	2.2119	3.4465	1.5261	2.452	3.0807	3.275
4	4.0809	2.2462	3.3779	1.5089	2.4348	3.0464	3.2064
5	3.9666	2.1948	3.395	1.5089	2.572	3.0235	3.2579
6	4.1667	2.2805	3.5723	1.5947	2.7263	3.1493	3.3779
7	4.2981	2.1948	3.3722	1.5947	2.7092	3.658	3.2693
8	4.4753	2.1776	2.8406	1.749	2.692	3.578	3.2693
9	6.693	2.8292	2.0919	2.6578	3.8066	4.4867	4.8182
10	10.6596	5.8928	1.949	6.2586	5.8128	11.1225	6.1157
11	13.1687	5.4184	1.4232	6.9445	6.4301	13.1345	5.8299
12	13.4431	5.7099	1.4575	7.8476	6.7558	13.6946	6.4301
13	6.8587	5.7956	1.2689	7.556	6.6187	13.6088	6.3272
14	5.6927	4.5953	1.4575	7.2188	6.1728	12.8601	5.0926
15	6.31	5.6756	1.4746	8.1048	7.1159	13.6374	5.8471
16	6.5672	5.7956	1.4918	8.8649	6.9273	14.3633	6.0357
17	6.7044	8.2534	1.5089	9.0707	7.1502	6.8416	5.8985
18	8.5277	8.3676	1.5947	8.5849	8.6248	7.0473	11.3626
19	6.2929	7.4703	1.7318	6.31	8.8306	6.5844	11.4026
20	5.2298	6.7673	1.7147	5.7956	7.4189	6.3786	9.4193
21	3.4979	4.8468	1.8004	4.321	5.367	4.5782	6.2757
22	2.4177	4.6696	1.749	3.5322	4.4353	4.7268	5.0983
23	2.4863	4.8526	1.6975	3.5494	4.2467	4.3496	5.0126
24	4.6125	3.8752	2.6978	3.1379	2.915	3.6809	3.3779
Max	13.4431	8.3676	3.8923	9.0707	8.8306	14.3633	11.4026
Min	2.4177	2.1776	1.2689	1.5089	2.4348	3.0235	3.2064
Avg	5.9423	4.5256	2.2710	4.6809	4.9804	6.9611	5.4460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 201 / 11KV TUKARAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4118	1.4998	1.5927	3.4291	3.5048	3.532	3.5208
2	1.3032	1.4083	1.4842	3.1257	3.2899	3.2456	3.2465
3	1.2489	1.3169	1.3575	2.9422	3.0201	3.0537	3.0178
4	1.1222	1.2254	1.2489	2.767	2.8296	2.8163	2.7519
5	1.086	1.1706	1.1946	2.5277	2.6093	2.5995	2.5598
6	1.0317	1.0974	1.1403	2.3549	2.3975	2.3958	2.4471
7	.9412	1.0059	1.0679	2.1617	2.2313	2.1763	2.2161
8	.9593	.9877	.9955	2.1365	2.0409	2.0542	2.0355
9	.9231	.9694	.9955	1.9679	1.9631	1.9555	1.9959
10	.9328	.9774	.905	1.9729	2.0039	1.9746	.905
11	.9412	1.0317	.8869	1.9967	2.0192	2.0865	.9774
12	.9877	1.0498	1.0317	2.0919	2.2335	2.1429	
13	1.0791	1.2308	1.1584	2.399	2.4579	2.3991	1.1584
14	1.2803	1.3756	1.3032	2.841	2.8992	2.7409	1.3575
15	1.3717	1.4299	1.4299	2.9622	3.0829	3.0278	1.4299
16	1.3535	1.448	1.4118	2.9268	3.0377	2.9714	1.4299
17	1.2437	1.3394	1.267	2.8693	2.8144	2.7868	1.3032
18	1.1157	1.1403	1.1041	2.5171	2.5115	2.3234	
19	1.2986	1.3032	1.3394	2.7838	2.743	2.6218	1.2489
20	1.4266	1.4118	1.4299	2.9828	3.0592	2.9699	1.4118
21	1.4449	1.5023	1.5023	3.1139	3.0867	3.1009	1.448
22	1.5912	1.6289	1.6651	3.4301	3.3884	3.3997	1.6108
23	1.5912	1.828	1.8461	3.9353	3.8098	3.9346	1.8461
24	1.5746	1.701	1.7556	3.7643	3.8279	3.8374	1.848
Max	1.5912	1.828	1.8461	3.9353	3.8279	3.9346	3.5208
Min	.9231	.9694	.8869	1.9679	1.9631	1.9555	.905
Avg	1.2192	1.2950	1.2964	2.7500	2.7859	2.7561	1.8985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 202 / 11KV KOTHARI WATIKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7098	1.7824	1.829	1.8986	1.9393	1.8911	1.9319
2	1.6194	1.6788	1.7339	1.8098	1.8023	1.7675	1.8015
3	1.5255	1.6139	1.6461	1.7014	1.6989	1.6795	1.7006
4	1.4238	1.5442	1.5474	1.5876	1.6085	1.6057	1.5802
5	1.3531	1.4563	1.4556	1.5436	1.5427	1.5269	1.4914
6	1.3152	1.4074	1.3617	1.4716	1.4378	1.4291	1.4394
7	1.3001	1.2832	1.339	1.3483	1.3819	1.3622	1.3499
8	1.2279	1.2225	1.2371	1.2144	1.2565	1.2243	1.275
9	1.174	1.1691	1.2062	1.2315	1.2096	1.2039	1.1981
10	1.1471	1.2582	1.0984	1.1391	1.1447	1.1722	1.0968
11	1.1308	1.2422	1.1272	1.1056	1.1999	1.1676	1.0833
12	1.1816	1.2877	1.1755	1.2091	1.2824	1.1897	.6302
13	1.3179	1.4198	1.3123	1.4396	1.4421	1.3177	1.3007
14	1.4967	1.5663	1.5278	1.5735	1.5619	1.5335	1.4941
15	1.5758	1.6362	1.6564	1.6225	1.7012	1.624	1.5844
16	1.594	1.6732	1.6322	1.6625	1.7014	1.6444	1.5711
17	1.4836	1.5825	1.5179	1.5762	1.568	1.5097	1.4866
18	1.339	1.4581	1.3676	1.3744	1.3476	1.4535	.7476
19	1.5613	1.6116	1.5398	1.5945	1.4724	1.4874	1.5086
20	1.6491	1.709	1.7482	1.771	1.6892	1.6816	1.7429
21	1.7717	1.8469	1.8424	1.8269	1.8157	1.8114	1.756
22	2.0201	1.975	1.991	1.9906	1.9721	2.0376	1.9546
23	2.0589	2.0637	2.0958	2.1562	2.1154	2.1824	2.1449
24	1.8989	1.9759	1.9929	2.0287	2.0874	2.039	2.0948
Max	2.0589	2.0637	2.0958	2.1562	2.1154	2.1824	2.1449
Min	1.1308	1.1691	1.0984	1.1056	1.1447	1.1676	.6302
Avg	1.4948	1.5610	1.5409	1.5782	1.5825	1.5642	1.4985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 203 / 11KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.46	2.7297	2.5568	2.1232	2.4882	2.4791	.0191
2	2.4532	2.6497	2.5294	2.159	2.492	2.5179	.0191
3	2.4249	2.662	2.4333	2.1536	2.4943	2.4859	.0191
4	2.4402	2.5979	2.4303	2.1536	2.5209	2.3853	.0191
5	2.4417	2.5697	2.4386	2.1422	2.4676	2.3746	.0191
6	2.4219	2.6109	2.4059	2.1346	2.4455	2.4158	.0191
7	2.4661	2.5324	2.3632	2.1559	2.5316	2.4295	.0191
8	2.4745	2.4684	2.0423	2.1925	2.5011	2.4326	.0191
9	2.7778	2.5598	2.0187	2.082	2.7	1.3115	.2553
10	3.4988	3.2091	1.8297	2.5431	3.4278	3.5284	.3825
11	4.1084	3.8562	1.7977	3.2396	4.1792	4.3004	.2995
12	4.1838	4.0063	1.7833	3.4705	4.132	4.3759	.1555
13	4.0734	3.8469	.8939	3.3943	2.0904	4.1511	.3879
14	4.0718	3.8501	1.7306	3.3752	3.8439	4.1419	.3818
15	4.3103	4.0687	1.7322	3.7236	4.2608	4.5442	.3872
16	4.2418	4.119	1.7581	3.7761	4.4505	4.4871	.2835
17	4.1076	4.0024	1.7284	3.7944	4.4345	4.1145	.1944
18	3.7456	3.6504	1.7268	3.789	3.8904	3.8325	.0815
19	3.5704	3.347	1.7177	3.629	3.5078	3.5246	.112
20	3.0795	2.8845	1.7162	3.1108	2.9873	2.9347	.0267
21	2.5957	2.4623	1.6926	2.5263	2.4745	2.3861	.0191
22	2.2938	2.1887	1.6972	2.159	2.0873	1.0388	.0191
23	2.2261	2.1879	1.7482	2.1003	2.0614	.2766	.0191
24	2.1628	2.1811	2.1407	1.9494	2.1087	1.2003	.0191
Max	4.3103	4.119	2.5568	3.7944	4.4505	4.5442	.3879
Min	2.1628	2.1811	.8939	1.9494	2.0614	.2766	.0191
Avg	3.1096	3.0517	1.9547	2.7449	3.0241	2.9029	.1324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 204 / 11KV CHAITANYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3575	1.5023	1.5023	1.4842	1.5927	1.5927	1.5565
2	1.2851	1.3213	1.4299	1.4661		1.5023	1.5927
3	1.1584	1.1946	1.3394	1.3394	1.4299	1.3213	1.3575
4	1.1041	1.1946	1.2127	1.2489	1.1765	1.267	1.267
5	.9774	.9774	1.0136	1.086	1.1041	1.1584	1.086
6	.8326	.8507	.9412	.9412	.9412	.9774	.9412
7	.8326	.905	.905	.905	.8869	.9593	.9412
8	.8507	.8688	.8507	.8145	.9774	.9231	.8688
9	.8507	.8326	.8326	.8507	.905	.8326	.8688
10	.8326	.8326	.7964	.905	.9412	.8869	.8507
11	.8326	.905	.9231	.905	1.0317	1.0136	.905
12	.8507	.9412	1.0136	.9412	1.1222	.9231	
13	1.0136	1.086	.9955	1.0317	1.2308	1.0136	1.0679
14	1.086	1.1584	1.1584	1.1222	1.267	1.2308	
15	1.1946	1.267	1.267	1.3032	1.3575	1.2489	1.267
16	1.1584	1.2489	1.267	1.2489	1.3032	1.2489	1.2127
17	1.086	1.1584	1.1403	1.1584	1.1765	1.1041	1.086
18	.9412	1.0136	1.0498	1.0498	1.0317	1.086	
19	1.086	1.1946	1.1946	1.1946	1.1403	1.1222	1.086
20		1.2308	1.2127	1.2851	1.2489	1.2127	1.1584
21	1.3575	1.3575	1.3032	1.3394	1.647	1.3394	1.2851
22	1.3937	1.5746	1.5384	1.5565		1.5927	1.5565
23	1.647	1.647	1.7737	1.7918	1.828	1.7375	1.7013
24	1.5203	1.6289	1.647	1.647	1.7013	1.7013	1.7194
Max	1.647	1.647	1.7737	1.7918	1.828	1.7375	1.7194
Min	.8326	.8326	.7964	.8145	.8869	.8326	.8507
Avg	1.0978	1.1622	1.1795	1.1923	1.2291	1.2082	1.2084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 205 / 11 KV FEEDER NO.5

Feeder KV- 11 / OUTGOING

DATE	16-APR-17	20-APR-17
HR	Load (MW)	Load (MW)
8	.6478	
22		.9145
Max	.6478	.9145
Min	.6478	.9145
Avg	.6478	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 206 / 11 KV FEEDER NO-6

Feeder KV- 11 / OUTGOING

DATE	17-APR-17	20-APR-17
HR	Load (MW)	Load (MW)
8	.5716	
22		.9145
Max	.5716	.9145
Min	.5716	.9145
Avg	.5716	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 241 / 11 KV INCOMER NO-I

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9693	3.1392	3.1804	3.224	3.3632	3.416	3.3043
2	2.7632	2.8314	3.0143	3.079	1.6575	3.145	3.2228
3	2.5404	2.5709	2.8015	2.83	2.9422	2.8462	2.8733
4	2.3741	2.4932	1.406	2.6229	2.5117	2.697	2.689
5	2.0611	2.1205	2.2687	2.3114	2.2952	2.4341	2.3137
6	1.7802	1.8612	1.9826	1.9963	2.0203	2.0965	2.0203
7	1.7528	1.8321	1.8698	1.9052	1.9031	1.9847	1.938
8	1.7218	1.8039	1.7846	1.7233	2.0074	1.9016	1.8084
9	1.7561	1.7757	1.7219	1.7526	1.9247	1.7837	1.8016
10	1.7391	1.7334	1.6697	1.8378	1.9094	1.8288	1.7732
11	1.77	1.8847	1.9073	1.8264	2.1462	2.1281	1.8721
12	.9122	1.9266	2.0893	1.9163	2.2996	1.9645	.9671
13	2.0664	2.2211	2.0449	2.1039	2.4997	2.0756	2.3341
14	2.2474	2.417	2.385	2.3122	2.5964	2.5157	2.477
15	2.4385	2.6818	2.5953	2.6692	2.7933	2.5989	2.6296
16	2.417	1.3592	2.6182	2.6366	2.739	2.6264	2.5902
17	2.3069	2.433	2.4286	2.4547	2.5185	2.3798	2.3343
18	2.0352	2.1853	2.2226	2.1941	2.2205	2.1737	1.1763
19	2.2085	2.4177	2.4029	2.4212	2.3634	2.2928	2.2348
20	2.4907	2.5317	2.4953	2.6534	2.5635	2.5044	2.385
21	2.53	2.7658	2.7047	2.8072	2.8489	2.7123	2.6374
22	2.8878	3.183	3.1445	3.206	3.3137	3.1896	3.1546
23	3.3537	3.4143	3.6084	3.6597	3.6924	3.5305	3.4754
24	3.283	3.4236	3.4703	3.564	3.584	3.5874	3.5152
Max	3.3537	3.4236	3.6084	3.6597	3.6924	3.5874	3.5152
Min	.9122	1.3592	1.406	1.7233	1.6575	1.7837	.9671
Avg	2.2669	2.3753	2.4090	2.4878	2.5297	2.5172	2.3970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 242 / 11 KV INCOMER NO-II

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.8507	3.7532	3.7157	3.6025	3.8676	3.9043	2.6673
2	6.4992	3.5246	3.5837	3.4705	3.7151	3.6214	2.4577
3	6.1477	3.4675	3.3573	3.3008	3.5437	3.5082	2.3243
4	5.8945	3.2579	3.2065	3.1687	3.4103	3.3008	2.1148
5	5.703	2.9912	3.0933	2.999	3.2198	3.1687	1.9624
6	5.5545	3.1055	2.999	2.8669	3.0674	3.0178	
7	5.4413	2.8959	2.8669	2.7349	2.9912	2.9047	1.7528
8	5.3173	2.7816	2.7349	2.7538	2.8197	2.7726	1.6385
9	5.7391	2.8006	2.4709	2.4897	2.934	3.0102	1.7147
10	6.6126	3.3762	2.3388	2.9613	3.4139	3.4517	1.6409
11	7.0253	3.6214	2.2443	3.1824	3.6969	3.7346	1.5844
12	7.1754	3.6403	2.5086	3.3913	3.81	3.7346	
13	7.3136	3.7912	1.8107	3.677	3.9232	3.8295	1.9993
14	7.9256	4.1118	2.9047	3.9819	3.9798	4.1872	2.3011
15	8.4854	4.2816	3.131	4.1914	4.5079	4.5456	2.4143
16	8.4343	4.3004	3.1121	4.1724	4.5268	4.3947	2.2822
17	7.8304	4.0741	2.8669	4.039	4.2627	4.0175	2.1125
18	7.1754	3.4705	2.6406	3.7723	3.5271	3.5246	
19	7.5659	3.6591	2.9613	3.9628	3.7723	3.6591	2.0559
20	7.2169	3.7534	3.1687	3.6961	3.6403	3.546	2.32
21	6.8393	3.5271	3.263	3.5246	3.5082	3.3951	2.3388
22	7.2657	3.6969	3.5082	3.7342	3.6214	3.7342	2.6217
23	7.4268	3.9798	3.7723	4.0581	3.9609	3.0864	2.9613
24	7.152	3.7723	3.9798	3.6403	3.9438	4.0552	2.8959
Max	8.4854	4.3004	3.9798	4.1914	4.5268	4.5456	2.9613
Min	5.3173	2.7816	1.8107	2.4897	2.8197	2.7726	1.5844
Avg	6.8580	3.5681	3.0100	3.4738	3.6527	3.5877	2.1981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 402 / 33 KV INCOMER (TUKARAM
SST) Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	19.6205	20.6893	20.9762	19.8949	21.2472	21.3935	18.1928
2	18.131	19.1999	19.2216	18.4362	20.1658	20.0286	16.9959
3	16.9467	17.9813	17.9036	17.2772	18.7666	18.8351	15.7464
4	15.9557	17.1743	17.0279	16.3546	17.4486	17.4703	14.6525
5	14.9177	15.9557	15.8906	15.08	16.0586	16.2643	13.4339
6	13.8615	14.8868	14.5908	13.9084	15.1143	15.1829	12.3217
7	13.5906	13.7712	13.5563	13.1448	14.6251	14.1575	11.262
8	13.0076	13.3505	12.4532	12.1319	13.8055	13.3848	10.5019
9	13.8489	13.4968	11.5215	12.0016	13.9049	13.5654	10.7945
10	15.5539	15.7682	10.2561	13.8237	16.2449	15.9957	10.511
11	16.8553	17.5103	10.4927	15.6528	17.7939	18.3517	10.6699
12	17.2359	17.7378	11.5272	16.9182	18.8157	18.498	8.3333
13	18.0899	18.6694	12.0348	17.987	19.7509	18.386	12.4429
14	19.3301	20.1029	14.1232	19.433	20.1029	20.6264	14.1941
15	21.094	22.1502	15.4881	21.446	22.6395	22.1502	15.207
16	21.4552	22.1537	15.6036	21.5615	22.9138	21.9445	15.1543
17	20.0377	21.278	14.7405	20.9169	21.565	21.0414	13.8797
18	18.5265	19.3404	13.251	19.4456	19.3371	19.0284	9.5336
19	18.5574	18.2957	14.0295	19.3393	18.5323	18.1459	12.9321
20	19.0935	18.7758	15.5316	19.8571	19.1621	18.8661	14.5805
21	18.4671	18.4579	16.4666	18.8787	18.626	17.8532	15.2973
22	19.6388	19.8662	18.386	20.1498	19.7417	18.3391	17.164
23	21.3123	21.5181	20.6082	22.3343	21.9137	19.8377	19.1679
24	21.0826	21.3501	20.8196	21.9581	22.0416	20.0183	14.6434
Max	21.4552	22.1537	20.9762	22.3343	22.9138	22.1502	19.1679
Min	13.0076	13.3505	10.2561	12.0016	13.8055	13.3848	8.3333
Avg	17.7588	18.3117	15.2709	17.8305	18.7632	18.3069	13.6505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I SHEDDABLE RURAL
Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	1.5432	1.6004	1.6004	1.7147		1.6004
2	1.3717	1.3717	1.4861	1.5432	1.6004		1.6575
3	1.2574	1.2574	1.3717	1.3717	1.4289	1.4289	1.4289
4	1.2003	1.2003	1.2574	1.3146	1.2574	1.3717	1.3146
5	1.1431	1.0288	1.0288	1.1431	1.086	1.1431	1.1431
6	.8573	.9145	1.0288	.9717	.9717	1.0288	1.0288
7	.8573	.9145	.9145	.9145	.9717	1.0288	.9717
8	.8002	.9145	.9145	.8573	1.0288	.9145	.9145
9	.9145	.8573	.8573	.8573	.9717	.8573	.9717
10	.8573	.8573	.8573	.9145	.8648	.8551	.7373
11	.9145	.9717	1.0288	.9717	1.0174	1.086	.8356
12		.9717	1.086	.9717		.9717	
13	1.086	1.1431	1.0288	1.0288	1.3146	1.086	.9831
14	1.1431	1.2574	1.2003	1.1431	1.3146	1.2574	1.3146
15	1.2574	1.3717	1.3146	1.3717	1.4289	1.2574	1.3717
16	1.2003	1.2574	1.3717	1.3146	1.3717	1.3146	1.2574
17	1.086	1.1431	1.2003	1.2003	1.2003	1.2003	1.1431
18	1.0288	1.086	1.086	1.086	1.086	1.086	
19	1.1431	1.2003	1.2003	1.2574	1.1431	1.1431	1.2003
20	1.2574	1.2574	1.3146	1.3717	1.3146	1.3146	1.2574
21	1.4289	1.3717	1.3146	1.4289	1.4861	1.3717	1.3146
22	1.4289	1.6004	1.6575	1.7147	1.6575	1.6004	1.6004
23	1.6575	1.7718	1.7147	1.8861	1.8861	1.829	1.7147
24	1.5432	1.6575	1.7718	1.7147	1.829	1.829	1.7718
Max	1.6575	1.7718	1.7718	1.8861	1.8861	1.829	1.7718
Min	.8002	.8573	.8573	.8573	.8648	.8551	.7373
Avg	1.1704	1.2050	1.2336	1.2479	1.302	1.2262	1.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO- SHEDDABLE RURAL
II Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	3.0293	2.9721	2.6863	3.0864	3.2007	2.6292
2	2.572	2.8578	2.8006	2.572	2.915	2.915	2.4577
3	2.4577	2.6863	2.5149	2.3434	2.7435	2.6863	2.2291
4	2.4006	2.5149	2.4006	2.2862	2.572	2.5149	2.1148
5	2.2862	2.4006	2.2862	2.1719	2.5149	2.3434	1.9433
6	2.2291	2.2862	2.1719	2.0576	2.2862	2.2862	1.8861
7	2.0576	2.1719	1.9433	1.9433	2.2291	2.1148	
8	2.1148	1.9433	1.7147	1.8861	2.0005	1.9433	1.5432
9	2.2291	2.1719	1.4289	1.4861	2.2291	2.4006	1.7147
10	2.9721	2.8578	1.3146	2.3434	2.9721	2.8578	1.5415
11	3.0864	3.0864	1.3146	2.8578	3.1436	3.2007	1.5415
12	3.2007	3.1436	1.4861	2.915	3.4294	3.2579	
13	3.2007	3.315	1.8861	3.1436	3.315	3.2579	1.8604
14	3.4294	3.6008	1.9433	3.4294	3.4865	3.7151	2.2291
15	3.7151		2.1148		4.0009	4.0009	2.4006
16	3.8295	3.7723	2.0576	3.6008	4.0009	3.9438	2.2862
17	3.4294	3.7151	1.8861	3.4294	3.6008	3.5437	2.1148
18	3.0864	2.915	1.6575	3.315	3.0293	3.1436	
19	3.315	3.0864	2.0005	3.3722	3.315		2.0576
20	3.1436	3.0293	2.2862	3.1436		3.0293	2.4006
21	2.915	2.8006	2.3434	2.8578	2.8578	2.7435	2.4577
22	3.0864	3.0293	2.6863	3.0293	2.915	2.7435	2.6863
23	3.1436	3.1436	3.0293	3.3722	3.2579	3.0293	2.9721
24	2.8006	3.0864	3.2007	2.8006	3.1436	3.1436	2.8578
Max	3.8295	3.7723	3.2007	3.6008	4.0009	4.0009	2.9721
Min	2.0576	1.9433	1.3146	1.4861	2.0005	1.9433	1.5415
Avg	2.8935	2.8976	2.1433	2.741	3.0019	2.9572	2.1869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 201 / 11 KV GORAKSHAN FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.5242	1.5242	1.5242	1.5242	1.5242	1.5242
2	1.2193	1.5242	1.5242	1.5242	1.5242	1.5242	1.5242
3	1.2193	1.2193	1.2193	1.2193	1.5242	1.5242	1.2193
4	.9145	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
5	.9145	.9145	1.2193	1.2193	1.2193	1.2193	1.2193
6	.9145	.9145	.9145	.9145	.9145	.9145	.9145
7	.6097	.9145	.9145	.9145	.9145	.9145	.9145
8	.9145	.9145	.9145	.9145	.9145	.9145	.9145
9	.9145	.9145	.9145	.9145	.9145	.9145	.9145
10	.9145	.9145	.9145	.9145	.9145	.9145	.9145
11	.9145	.9145	.9145	.9145	.9145	.9145	.9145
12	.9145	.9145	.9145	2.1148	.9145	.9145	.9145
13	.9145	.9145	.9145	1.2193	.9145	.9145	.9145
14	1.2193	.9145	1.2193	.9145	1.2193	1.2193	.9145
15	1.2193	1.2193	1.2193		1.2193	1.2193	1.2193
16	1.2193	1.2193	1.2193		1.5242	1.5242	1.2193
17	1.2193	1.2193	1.2193	1.5242	1.2193	1.2193	1.2193
18	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	.9145
19	.9145	.9145	.9145	1.2193	.9145	.9145	.9145
20	1.2193	.9145	1.2193	1.2193	.9145	1.2193	.9145
21	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
22	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
23	1.5242	1.5242	1.5242	1.5242	1.5242	1.5242	1.5242
24	1.5242	1.5242	1.5242	1.829	1.829	1.5242	1.5242
Max	1.5242	1.5242	1.5242	2.1148	1.829	1.5242	1.5242
Min	.6097	.9145	.9145	.9145	.9145	.9145	.9145
Avg	1.0923	1.1177	1.1558	1.2462	1.1812	1.1812	1.1177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 202 / 11 KV KHADAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-APR-17
HR	Load (MW)
12	2.4577
Max	2.4577
Min	2.4577
Avg	2.4577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 203 / 11 KV INDUSTRIAL FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-APR-17
HR	Load (MW)
18	1.9433
Max	1.9433
Min	1.9433
Avg	1.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 205 / 11 KV BIRLA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.9585	2.0576	2.111	2.1033	2.1186	2.0957
2	1.7604	1.829	1.8747	1.9738	1.9585	1.8976	1.9585
3	1.6385	1.7071	1.7528	1.7985	1.8366	1.7985	1.8061
4	1.4861	1.5775	1.6309	1.6994	1.7147	1.669	1.6994
5	1.3946	1.4556	1.5089	1.5623	1.608	1.5013	1.5623
6	1.3032	1.3565	1.4098	1.4327	1.4784	1.4175	1.4632
7	1.2803	1.2422	1.326	1.387	1.4556	1.3794	1.4022
8	1.2422	1.2651	1.326	1.2879	1.3641	1.3565	1.3489
9	1.1507	1.2422	1.2879	1.2955	1.2879	1.3717	1.3032
10	1.1812	1.1355	1.2574	1.2574	1.3108	1.387	1.3032
11	1.2879	1.2422	1.2803	1.326	1.3641	1.4327	1.3489
12	1.2803	1.3336	1.3641	1.4022	1.4327	1.448	1.4022
13	1.4098	1.5013	1.4556	1.5623	1.5699	1.5242	1.4861
14	1.6613	1.6766	1.669	1.7375	1.7528	1.669	1.6918
15	1.7909	1.7756	1.8519	1.8595	1.8519	1.8138	1.8366
16	1.7756	1.8061	1.829	1.9052	1.9052	1.8138	1.9662
17	1.6918	1.7299	1.7985	1.7909	1.8214	1.7756	1.89
18	1.5242	2.9683	1.6537	1.6994	1.7452	1.5775	1.7223
19	1.7147	1.6766	1.7375	1.8138	1.9052	1.7909	1.829
20	1.8519	1.7223	1.8671	1.9433	2.1186	1.9204	1.8976
21	1.8214	1.768	1.8442	1.9052	2.0271	1.8976	1.8747
22	1.7985	1.8823	1.9585	1.9966	2.0271	1.9433	1.8519
23	2.05	2.0805	2.2024	2.2405	2.2024	2.0957	2.0881
24	2.0729	2.1186	2.2329	2.2939	2.2558	2.1643	2.1414
Max	2.0729	2.9683	2.2329	2.2939	2.2558	2.1643	2.1414
Min	1.1507	1.1355	1.2574	1.2574	1.2879	1.3565	1.3032
Avg	1.5864	1.6688	1.6740	1.7201	1.7541	1.6985	1.7071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 207 / 11 KV KAULKHED

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-APR-17
HR	Load (MW)
12	3.2198
Max	3.2198
Min	3.2198
Avg	3.2198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 208 / 11 KV CHITRA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.1753	.2362					.2515
8	.2362	.3201					.282
9	.1677	.2058	.0914	.1905	.1067		.2058
10			.0838	.2362	.2058		
11			.221	.2286	.2134		
12			.1905	.2134	.1905		
13			.1905	.0914	.16		
14			.16	.0076	.0381		
15			.0152		.1067		
16			.0991		.1753		
17			.1219		.1448		
18		.5335					
24	.0914					.0229	
Max	.2362	.5335	.221	.2362	.2134	.0229	.282
Min	.0914	.2058	.0152	.0076	.0381	.0229	.2058
Avg	.1677	.3239	.1304	.1613	.1490	.0229	.2464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 209 / 11 KV MOHOTA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.326	1.3946	1.4556	1.4784	1.608	1.6156	1.6004
2	1.2346	1.3184	1.326	1.387	1.5013	1.5089	1.5013
3	1.1965	1.2651	1.2803	1.3489	1.4175	1.4403	1.4175
4	1.1279	1.2041	1.2498	1.3032	1.3489	1.3717	1.3489
5	1.0822	1.1888	1.1965	1.2422	1.2803	1.2879	1.2727
6	1.1203	1.2041	1.2041	1.2498	1.2955	1.2879	1.2651
7	1.1812	1.2117	1.2193	1.2651	1.2803	1.2803	1.2727
8	1.1584	1.1965	1.1965	1.2041	1.2727	1.2498	1.2955
9	1.1888	1.1812	1.2574	1.2727	1.326	1.3108	1.3336
10	1.3565	1.1888	1.387	1.4175	1.4632	1.5089	1.5013
11	1.6385	1.2651	1.6309	1.5394	1.6385	1.7147	1.6613
12	1.7452	1.3946	1.8138	1.7909	1.8061	1.8138	1.829
13	1.7985	1.4403	1.89	1.9204	1.9052	1.829	1.8976
14	1.8366	1.5394	1.8671	1.9814	1.9738	1.8747	1.9204
15	1.9052	1.5546	1.9052	2.0729	2.1338	1.9585	2.0576
16	1.9662	1.5623	1.9662	2.05	2.1186	1.9966	2.05
17	1.9052	1.5165	1.9052	2.0043	2.0729	1.9052	2.0043
18	1.7375	2.7511	1.7909	1.8442	1.8671	1.7909	1.8595
19	1.6994	1.5165	1.7604	1.7909	1.768	1.7375	1.7299
20	1.7071	1.5851	1.7756	1.8595	1.8138	1.8747	1.7528
21	1.7071	1.5775	1.7223	1.8138	1.8138	1.7985	1.7375
22	1.5851	1.5927	1.6766	1.7375	1.7223	1.7147	1.6918
23	1.5318	1.6004	1.6994	1.768	1.7223	1.7452	1.7147
24	1.5013	1.547	1.6156	1.7299	1.7375	1.7223	1.6232
Max	1.9662	2.7511	1.9662	2.0729	2.1338	1.9966	2.0576
Min	1.0822	1.1812	1.1965	1.2041	1.2727	1.2498	1.2651
Avg	1.5099	1.4499	1.5747	1.628	1.6620	1.6391	1.6391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 210 / AKOLA TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6994	1.7604	1.7909	1.89	1.9052	1.8823	1.89
2	1.5927	1.6918	1.6994	1.7452	1.7909	1.7833	1.7985
3	1.5013	1.5623	1.5775	1.6461	1.7071	1.7452	1.6918
4	1.4175	1.4556	1.5165	1.547	1.6232	1.5699	1.5699
5	1.3489	1.4022	1.4556	1.4861	1.5242	1.5165	1.5013
6	1.3336	1.3717	1.4098	1.4098	1.448	1.4022	1.4327
7	1.2041	1.3336	1.326	1.3336	1.547	1.3336	1.3336
8	1.2269	1.3108	1.2879	1.3184	1.3565	1.3184	1.3413
9	1.3717	1.3336	1.448	1.4632	1.4556	1.5394	1.4403
10	1.4708	1.3794	1.5775	1.5775	1.669	1.5851	1.6842
11	1.7452	1.4403	1.8671	1.8595	1.8823	1.9052	1.9509
12	1.89	1.5394	2.0195	2.0271	2.0348	2.0271	2.05
13	1.9585	1.6994	2.111	2.1872	2.0729	2.1186	2.1567
14	2.0652	1.8061	2.1948	2.2558	2.271	2.1719	2.0957
15	2.1414	1.829	2.3091	2.3472	2.332	2.271	2.2177
16	1.5699	1.829	2.3243	2.3548	2.3167	2.3472	2.3091
17	2.3624	1.8061	2.2253	2.2939	2.2177	2.2862	2.21
18	2.2024	3.3684	2.1643	2.1186	2.0348	2.1491	2.0729
19	2.0652	1.7375	2.2329	2.0348	2.1567	2.1186	2.2481
20	2.0729	1.8366	2.271	2.1948	2.2177	2.2024	2.2558
21	1.9738	1.8061	2.1567	2.0957	2.0957	2.1186	2.1414
22	1.8061	1.7756	1.9509	1.9509	1.8976	1.9433	1.9509
23	1.7985	1.7985	1.8747	1.9509	1.9052	1.9204	1.8671
24	1.8442	1.8061	1.9204	1.989	1.9052	1.9357	1.8823
Max	2.3624	3.3684	2.3243	2.3548	2.332	2.3472	2.3091
Min	1.2041	1.3108	1.2879	1.3184	1.3565	1.3184	1.3336
Avg	1.7359	1.6950	1.8630	1.8782	1.8903	1.8830	1.8788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 211 / 11 KV UMRI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6309	1.5699	1.6156	1.5242	1.669	1.5775	1.6994
2	1.4632	1.4327	1.4175	1.4327	1.4861	1.4556	1.547
3	1.3413	1.3413	1.3336	1.3641	1.3794	1.3489	1.448
4	1.2727	1.2498	1.2498	1.2727	1.326	1.2879	1.3641
5	1.2269	1.1888	1.166	1.2117	1.2193	1.1888	1.2879
6	1.1965	1.1431	1.1203	1.1507	1.1736	1.1507	1.2422
7	1.1584	1.0745	1.0822	1.0974	1.1507	1.0745	1.1965
8	1.0974	1.044	1.0136	1.0136	1.044	1.0136	1.1203
9	1.0745	1.0288	.9907	.9526	1.1507	1.0745	1.1812
10	1.0745	1.0364	1.044	1.0593	1.1812	1.0669	1.044
11	1.2422	1.044	1.2422	1.2955	1.4251	1.3032	1.2269
12	1.3032	1.2117	1.4556	1.4403	1.4556	1.3794	1.3032
13	1.3794	1.3108	1.4708	1.4098	1.5165	1.4784	1.5623
14	1.448	1.4251	1.5013	1.4937	1.7452	1.5546	1.7223
15	1.5318	1.4861	1.5927	1.7147	1.8366	1.6385	1.7299
16	1.6004	1.5013	1.7452	1.8061	1.9052	1.7985	1.768
17	1.5699	1.4937	1.7452	1.7985	1.8214	1.8061	1.7528
18	1.5242	2.7511	1.6842	1.6918	1.7604	1.7299	1.6461
19	1.4251	1.3108	1.5242	1.5623	1.5394	1.4861	1.4708
20	1.4556	1.3641	1.4937	1.5546	1.5013	1.4861	1.5318
21	1.4098	1.3717	1.4098	1.448	1.5165	1.4556	1.4403
22	1.4251	1.4556	1.4784	1.5013	1.4784	1.4175	1.4937
23	1.5394	1.6994	1.6156	1.6918	1.6156	1.547	1.7223
24	1.608	1.6918	1.6385	1.7223	1.6842	1.7147	1.7299
Max	1.6309	2.7511	1.7452	1.8061	1.9052	1.8061	1.768
Min	1.0745	1.0288	.9907	.9526	1.044	1.0136	1.044
Avg	1.3749	1.3844	1.4013	1.4254	1.4826	1.4181	1.4680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 212 / 11 KV EXPRESS MAIN HOSP. NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	16-APR-17
HR	Load (MW)
18	.2477
Max	.2477
Min	.2477
Avg	.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 241 / 11 KV INCOMER NO-I
GORKSHAN S/ Feeder KV- 11 /
INCOMING

SHEDDABLE RURAL

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.3955	5.6699	5.8528	6.0052	6.1576	6.2186	6.1576
2	5.0297	5.3346	5.3955	5.6089	5.7918	5.7308	5.7918
3	4.7249	4.9688	5.0602	5.2431	5.4565	5.426	5.365
4	4.4201	4.6334	4.8468	4.9688	5.0907	5.0602	5.0602
5	4.1152	4.4201	4.542	4.6639	4.7859	4.7249	4.7249
6	4.0238	4.2676	4.3591	4.4505	4.5725	4.481	4.542
7	3.9628	4.0238	4.1152	4.2981	4.542	4.2676	4.2981
8	3.8714	4.0238	4.1152	4.1457	4.2981	4.2676	4.2067
9	4.0847	4.1152	4.3591	4.3591	4.4201	4.6334	4.4201
10	4.481	4.0847	4.6944	4.7249	4.9078	5.0602	4.9078
11	5.1212	4.4505	5.2431	5.2431	5.4565	5.6089	5.5479
12	5.3955	4.7249	5.7918	5.8223	5.9137	5.8223	5.9442
13	5.6699	5.0907	6.0357	6.371	6.2795	6.0966	6.2795
14	6.1881	5.487	6.4015	6.7978	6.8282	6.4015	6.5234
15	6.4624	5.7004	6.9807	7.1026	7.1636	6.6758	6.9197
16	6.0662	5.8223	6.9502	7.1026	7.1331	6.7063	7.1026
17	6.432	5.5784	6.6453	6.8892	6.9197	6.8282	6.9197
18	6.0662	5.1212	6.31	6.2491	6.3405	6.2491	6.3405
19	5.9747	5.426	6.3405	6.2186	6.6149	5.8528	6.5539
20	6.1576	5.6699	6.4929	6.4624	6.7978	6.6149	6.5539
21	6.0052	5.6699	6.2795	6.3405	6.4624	6.371	6.31
22	5.6699	5.7613	6.0662	6.1271	6.2186	6.0966	5.9747
23	5.9747	6.1271	6.4624	6.5844	6.4624	6.4015	6.2491
24	5.9747	6.0966	6.4015	6.6149	6.5234	6.4015	6.2186
Max	6.4624	6.1271	6.9807	7.1026	7.1636	6.8282	7.1026
Min	3.8714	4.0238	4.1152	4.1457	4.2981	4.2676	4.2067
Avg	5.3028	5.0945	5.6559	5.7664	5.8807	5.7499	5.7880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 242 / 11 KV INCOMER NO-II
GORKSHAN S Feeder KV- 11 /
INCOMING

SHEDDABLE RURAL

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	***	***	***	***	***	***	***
3	***	***	***	***	***	***	***
4	9.6937	***	***	***	***	***	***
5	9.1754	9.6022	9.8156	***	***	***	***
6	8.9621	9.3279	9.5412	9.7241	9.7546	9.8766	9.7851
7	8.9011	9.145	9.3583	9.5108	8.0476	9.6022	9.4498
8	9.0535	9.1754	9.084	9.2364	9.7241	9.2669	9.3279
9	9.023	9.2364	9.2059	9.2974	9.6022	9.5108	9.4193
10	9.084	9.1145	9.1754	9.4498	9.2059	9.5108	
11	9.1754	9.023	9.3583	8.9011	8.3219	9.6632	
12	9.6327	9.2974	9.7851	8.5353	9.968	9.8461	
13	***	9.907	***	***	***	***	
14	***	***	***	***	***	***	
15	***	***	***	***	***	***	
16	***	***	***	***	***	***	
17	***	***	***	***	***	***	
18	***	***	***	***	***	***	
19	***	***	***	***	***	***	
20	***	***	***	***	***	***	
21	***	***	***	***	***	***	
22	***	***	***	***	***	***	
23	***	***	***	***	***	***	
24	***	***	***	***	***	***	
Max	12.4371	12.742	12.9554	13.3821	13.3516	13.1383	12.7115
Min	8.9011	9.023	9.084	8.5353	8.0476	9.2669	9.3279
Avg	10.3770	10.4608	10.7199	10.9181	10.9803	10.9257	10.5540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 027002 / 132 MIDC

Feeder No / Name : 201 / 11 kv Phase II/ OLD MIDC
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097	.7621	.6097	.6097	.6097	1.829
2		.6097	.6097	.6097	.6097	.6097	1.829
3		.6097	.6097	.6097	.6097	.6097	1.6766
4		.6097	.6097	.6097	.6097	.6097	1.6766
5		.6097	.6097	.6097	.6097	.6097	1.829
6		.6097	.6097	.6097	.6097	.6097	1.6766
7		.6097	.6097	.6097	.6097	.6097	1.829
8		.6097	.6097	.6097	.6097	.6097	1.6766
9		.6097	.6097	.6097	.6097	.6097	1.829
10		.7621	.6097	.7621	.6097	.7621	2.2862
11		.9145	.4572	.7621	.7621	.7621	2.8959
12		.9145	.6097	.9145	.7621	.7621	2.8959
13		.9145	.6097	.9145	.7621	.7621	2.8959
14		.7621	.6097	.7621	.7621	.7621	2.7435
15		.9145	.6097	.7621	.9145	.7621	3.0483
16		.9145	.6097	.9145	.9145	.7621	3.0483
17		.9145	.6097	.9145	.9145	.7621	2.8959
18		.9145	.6097	.9145	.9145	.7621	2.7435
19		1.8014	.6097	.9145	.9145	.7621	2.5911
20		.9145	.7621	.9145	.9145	.9145	2.5911
21		.9145	.7621	.9145	.7621	.9145	2.1338
22		.7621	.7621	.7621	.7621	.7621	1.6766
23	.7621	.7621	.7621	.7621	.7621	1.5242	1.6766
24	.7621	.7621	.7621	.7621	.7621	1.5242	1.6766
Max	.7621	1.8014	.7621	.9145	.9145	1.5242	3.0483
Min	.7621	.6097	.4572	.6097	.6097	.6097	1.6766
Avg	.7621	.8054	.6414	.7558	.7367	.7812	2.2354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 027002 / 132 MIDC

Feeder No / Name : 202 / 11 kv Phase IV/Borgaon
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	16-APR-17
HR	Load (MW)
19	1.4118
Max	1.4118
Min	1.4118
Avg	1.4118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 027002 / 132 MIDC

Feeder No / Name : 205 / 11 kv sutgirani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-APR-17
HR	Load (MW)
19	.4525
Max	.4525
Min	.4525
Avg	.4525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 027002 / 132 MIDC

Feeder No / Name : 206 / 11 KV NEW MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.8078	.8078	.381	.9145	2.1795	2.4692
2	.8688	.7926	.8078	.6097	.9602	2.4844	2.4692
3	.8535	.823	.7926	.7773	.9602	2.4997	2.4844
4	.8535	.823	.7926	.7773	.9602	2.4844	2.1643
5	.8383	.8078	.7773	.8078	.945	2.1795	2.1643
6	.8535	.7926	.7926	.7926	.9602	2.1643	2.1338
7	.8535	.8078	.7926	.7926	.945	2.1643	2.1948
8	.884	.823	.7773	.8078	.945	2.4997	2.1643
9	.8535	.8078	.7926	.7773	.9755	2.4844	2.4692
10	.884	.8688	.7926	.8535	.9907	3.1245	2.7892
11	.9602	.8383	.8078	.9602	1.0364	3.0483	3.1397
12	.945	.9297	.823	.9602	3.4751	2.6825	3.155
13	.945	.945	.8688	.9907	3.4599	3.1093	3.1397
14	.9297	.9297	.8383	.9907	3.1093	2.8349	3.155
15	.884	.9145	.8383	.9907	3.4599	3.1397	3.155
16	.9145	.945		.9602	3.4599	2.1338	3.0788
17	.8993	.9145	.3353	.9755	3.4599	2.4082	3.1245
18	.8535	.8993	.6706	.9602	3.4446	2.8197	3.1093
19	.8383	2.7439	.823	.945	3.1397	2.8197	3.1093
20	.8078	.823	.8535	.9755	2.8502	2.8045	3.1397
21	.7926	.7926	.8383	.9297	2.4844	2.7892	2.7892
22	.8078	.823	.8383	.9602	2.4082	2.4387	2.4692
23	.8078	.8078	.3658	.9602	2.4692	2.4844	2.4844
24	.7926	.823	.381	.9297	2.4539	2.4844	2.4997
Max	.9602	2.7439	.8688	.9907	3.4751	3.1397	3.155
Min	.7926	.7926	.3353	.381	.9145	2.1338	2.1338
Avg	.8662	.9285	.7482	.8694	2.0945	2.5943	2.7105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 027002 / 132 MIDC

Feeder No / Name : 208 / 11KV PH III

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2193	1.2193	.9145	1.2193	1.2193	1.2193
2	1.2193	1.2193	1.2193	.9145	1.2193	1.2193	1.2193
3	1.2193	1.2193	1.2193	.9145	1.2193	1.2193	1.2193
4	1.2193	1.2193	1.2193	.9145	1.2193	1.2193	.9145
5	1.2193	1.2193	1.2193	.9145	1.2193	.9145	.9145
6	1.2193	1.2193	1.2193	.9145	1.2193	.9145	.9145
7	1.2193	1.2193	1.2193	.9145	1.2193	1.2193	.9145
8	1.5242	1.5242	1.2193	1.2193	1.2193	1.2193	1.2193
9	1.829	1.829	.9145	1.5242	1.829	1.829	1.5242
10	2.4387	2.4387	.9145	2.4387	2.7435	2.7435	2.4387
11	3.0483	3.0483	.9145	3.0483	2.7435	3.0483	2.7435
12	3.0483	3.0483	.9145	3.3532	3.0483	3.0483	3.0483
13	3.0483	3.3532	.9145	3.3532	3.0483	3.0483	2.7435
14	2.7435	2.7435	.9145	2.7435	2.4387	2.7435	2.4387
15	3.0483	3.0483		3.0483	3.0483	3.0483	2.7435
16	3.0483	3.0483	.9145	3.0483	3.0483	3.0483	3.0483
17	3.0483	3.3532	.9145	3.0483	3.0483	3.0483	3.0483
18	3.0483	3.0483	.9145	3.0483	2.7435	3.0483	2.7435
19	3.0483	5.1507	.9145	2.7435	2.7435	2.7435	2.7435
20	2.7435	2.4387	.9145	2.7435	2.4387	2.4387	2.4387
21	1.5242	1.829	.9145	1.829	1.829	1.5242	1.829
22	1.5242	1.2193	.9145	1.2193	1.2193	1.2193	1.2193
23	1.2193	1.2193	.9145	1.2193	1.2193	1.2193	1.2193
24	1.2193	1.2193	.9145	1.2193	1.2193	1.2193	1.2193
Max	3.0483	5.1507	1.2193	3.3532	3.0483	3.0483	3.0483
Min	1.2193	1.2193	.9145	.9145	1.2193	.9145	.9145
Avg	2.0703	2.1706	1.0205	1.9687	2.0068	2.0068	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 201 / 11 KV PKV FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2926	.3077	.3292	.3258	.3292	.3258
2	.2926	.2896	.3077	.3109	.3258	.3258	.3077
3	.2926	.2715	.2896	.2926	.3109	.3258	.3077
4	.2743	.2534	.2865	.2926	.2926	.3077	.2896
5	.2715	.2378	.2715	.2561	.2715	.3077	.2896
6	.2743	.2378	.2715	.2378	.2561	.2896	.2715
7		.2353	.2507	.2715	.2561	.2896	.2896
8	.2402	.2378	.2353	.2587	.2378	.2561	.2534
9	.3258	.2195	.2378	.2926	.2378	.2743	.3109
10	.3077		.3109	.3109	.2926	.3475	.3841
11		.2195	.439	.439	.3841	.4207	.439
12	.4525	.2561	.4755	.4572	.439	.439	.4207
13	.4344	.2743	.4755	.4755	.4572	.439	.439
14	.4344	.2926	.4572	.4938	.4572	.4024	.4572
15	.4344	.2896	.4938	.4755	.4207	.439	.4755
16	.4572	.2896	.4525	.4706	.4344	.4344	.4525
17	.3658	.2534	.4525	.4344	.4344	.4344	.4344
18	.3292	.2715	.3439	.3077	.2896	.362	.3292
19	.3077	.2896	.3439	.362	.3258	.3439	.3801
20	.3077	.3258	.362	.362	.2896	.362	.3841
21	.2896	.3258	.362	.3439	.3077	.362	.362
22	.3475	.3475	.3658	.3658	.3258	.362	.3658
23	.3439	.3475	.362	.3982	.3658	.362	.3475
24	.2896	.3109	.3292	.3258	.3475	.3258	.3258
Max	.4572	.3475	.4938	.4938	.4572	.439	.4755
Min	.2402	.2195	.2353	.2378	.2378	.2561	.2534
Avg	.3347	.2769	.3535	.3568	.3369	.3559	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 202 / 11 KV PANCHSHIL FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7964	.8145	.8048	.8779	1.0082	.9145
2	.7316	.724	.7865	.7316	.8688	1.0082	.8779
3	.7316	.724	.724	.7316	.7964	.9335	.8413
4	.695	.724	.724	.7316	.7964	.8215	.7316
5	.695	.6878	.6878	.695	.7316	.8215	.695
6	.6401	.6154	.6878	.695	.7133	.7468	.6767
7		.5973	.6401	.5792	.6219		.567
8	.5359	.5304	.5611	.5544	.5487	.5359	.5487
9	.5304	.5121	.5487	.5121	.5304	.5121	.5304
10	.5121		.4938	.5121	.4755	.5304	.5121
11	.5304	.695	.695	.5121	.5121	.5304	.439
12		.5853	.567	.5304	.5487	.567	.4207
13	.6036	.6219	.6219	.6401	.6036	.6219	.567
14	.6401	.7682	.6767	.695	.6036	.6767	.695
15	.6767	.7468	.7316	.7316	.6767	.6767	.7316
16	.7468	.7282	.7316	.6767	.7133	.6401	.6767
17	.6653	.6908	.6401	.6401	.6584	.6219	.6036
18	.6283	.6838	.5304	.6584	.6401	.5853	.6154
19	.7207	.7392	.7316	.695	.7499	.7499	.6878
20	.7842	.7842	.7682	.7499	.7682	.7316	.724
21	.7842	.8215	.8048	.8048	.8215	.7682	.8413
22	.8507	.9145	.9134	.9328	.8962	.9145	.8779
23	.8954	.8962	.9511	.9694	.9896	.9511	.9412
24	.8048	.8413	.8779	.8779	.9145	1.0642	.9145
Max	.8954	.9145	.9511	.9694	.9896	1.0642	.9412
Min	.5121	.5121	.4938	.5121	.4755	.5121	.4207
Avg	.6896	.7143	.7046	.6942	.7107	.7399	.6930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 203 / 11 KV SUDHIR COLONY FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5339	2.5606	2.7759	2.7801	2.9264	2.8753	2.7801
2	2.524	2.4977	2.7149	2.7069	2.8898	2.8753	2.7069
3	2.3529	2.3411	2.5072	2.4874	2.7435	2.8006	2.5789
4	2.2314	2.2805	2.4253	2.2314	2.4508	2.6886	2.3777
5	2.0271	2.2081	2.3777	2.0485	2.2314	2.5393	2.1765
6	1.8473	2.0119	2.1719	1.8839	2.0668	2.0538	2.0119
7	1.829	1.7375	1.828	1.8107	2.0119	2.0165	1.829
8	1.7556	1.7375	1.7558	1.7926	1.7558	1.8484	1.8107
9	1.6095	1.6644	1.6278	1.701	1.6827	1.829	1.6461
10	1.6095	1.6461	1.5364	1.6278	1.6461	1.6827	1.6095
11	1.5546	1.6461	1.5729	1.6644	1.6827	1.6461	1.6278
12	1.6644	1.7375	1.6644	1.8107	1.7558	1.7558	1.7558
13	1.8473	1.9753	1.8839	2.0119	1.9753	2.0668	1.9204
14	2.0485	2.2131	2.1948	2.2497	2.3045	2.2131	2.1582
15	2.2131	2.3152	2.3411	2.3594	2.3228	2.2862	2.3594
16	2.2779	2.3525	2.3228	2.3228	2.3228	2.1582	2.3594
17	2.0538	2.1658	2.0668	2.1582	2.2131	1.9204	2.0851
18	1.8671	1.9418	1.829	1.9753	2.0302	1.8656	1.9022
19	2.2032	2.1658	2.1216	2.3228	2.3045	2.4691	2.2314
20	2.2965	2.3899	2.3411	2.396	2.371	2.396	2.268
21	2.3525	2.4646	2.4326	2.524	2.4832	2.4691	2.4977
22	2.5423	2.7435	2.733	2.8532	2.8858	2.652	2.7984
23	2.9264	2.9995	2.9864	3.1276	3.1687	2.963	2.9813
24	2.6244	2.7149	2.8715	2.8715	2.9683	2.95	2.8715
Max	2.9264	2.9995	2.9864	3.1276	3.1687	2.963	2.9813
Min	1.5546	1.6461	1.5364	1.6278	1.6461	1.6461	1.6095
Avg	2.1163	2.1880	2.2118	2.2382	2.2997	2.2925	2.2227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 204 / 11kv feeder no. 3

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1157	1.1946	1.2986	1.2437	1.2851	1.3443	1.3169
2	1.0974	1.0974	1.2308	1.1706	1.2986	1.307	1.2803
3	1.0608	1.086	1.2071	1.0974	1.2437	1.307	1.2254
4	1.0608	1.0498	1.2071	1.0608	1.1946	1.1946	1.1157
5	.9511	1.0608	1.0974	1.0059	1.0974	1.1949	1.0425
6	.8779	.9774	1.0498	1.0059	1.0608	1.1203	1.0059
7	.8779	.9511	.9774	1.0608	.9511	1.0269	.9328
8	.7762	.9328	.8775	.8779	.9145	.8215	.823
9	.823	.9145	.8413	1.6461	.8686	.8596	.823
10	.7499		.7865	.823	.7682	.823	.823
11	.7499	1.1706	1.0425	.7865	.8048	.7682	.8048
12	.8048	.9328	.8596	.823	.8779	.8779	.8413
13	.9328	1.0059	.9145	.9328	.9145	.9877	.8779
14	.9877	1.0791	1.0242	1.0425	1.0242	1.0242	1.0242
15	1.0425	1.1203	1.0974	1.1157	1.0608	1.0791	1.0974
16	1.1203	1.0829	1.1157	1.0242	1.0608	1.0425	1.134
17	1.0082	1.0642	1.0059	.9877	.9511	1.0059	1.0242
18	.9149	.9231	.9328	.9328	.9328	.9145	.9328
19	1.1203	1.0829	1.1706	1.0974	1.086	1.0791	1.1584
20	1.1949	1.1949	1.2254	1.2803	1.2489	1.2071	1.1765
21	1.2696	1.251	1.2986	1.3169	1.3443	1.2986	1.2803
22	1.2986	1.3535	1.3535	1.39	1.419	1.3717	1.3535
23	1.3535	1.39	1.4118	1.448	1.419	1.39	1.4118
24	1.1888	1.2071	1.3352	1.3032	1.3394	1.363	1.0974
Max	1.3535	1.39	1.4118	1.6461	1.419	1.39	1.4118
Min	.7499	.9145	.7865	.7865	.7682	.7682	.8048
Avg	1.0157	1.0923	1.0984	1.1030	1.0903	1.1004	1.0668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 210 / 11 kv Incomer No.1

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1312	2.2805	2.4072	2.3282	2.4796	2.6886	2.5606
2	2.0553	2.0774	2.3167	2.19	2.4796	2.6513	2.4691
3	2.0199	2.2624	2.2081	2.0995	2.3348	2.5766	2.3777
4	1.9667	2.0271	2.1849	2.0416	2.2565	2.3712	2.1399
5	1.8604	1.9728	2.0022	1.9366	2.0595	2.3339	2.0302
6	1.7364	1.828	1.9879	1.9185	1.9879	2.1658	1.957
7	1.6124	1.7737	1.8446	1.5384		2.0165	1.7924
8	1.5364	1.6655	1.701	1.6651	1.6832	1.6244	1.6278
9	1.6827	1.6461	1.6827	1.6461	1.6278	1.6644	1.6644
10	1.5729		1.5912	1.6461	1.5364	1.701	1.7193
11	1.2803	2.0851	2.1765	1.7375	1.701	1.7193	1.6827
12	1.262	1.7741	1.9022	1.8107	1.8656	1.8839	1.7924
13	1.9753	1.9022	2.0119	2.0485	1.9753	2.0485	1.8839
14	2.0668	2.1399	2.1582	2.2314	2.0851	2.1033	2.1765
15	2.1582	1.5028	2.3228	2.3228	2.1582	2.1948	2.3045
16	2.3339	2.1098	2.3045	2.1765	2.2131	2.1216	2.2443
17	2.0538	2.0165	2.1033	2.0668	2.0485	2.0668	2.0237
18	1.8858	1.9231	1.8107	1.9022	1.8656	1.8656	1.8642
19	2.1658	2.1285	2.2497	2.1582	2.1538	2.1765	2.2262
20	2.2965	2.3152	2.3594	2.396	2.2986	2.3045	2.2805
21	2.3525	2.4086	2.4691	2.4691	2.4832	2.4326	2.4615
22	2.4796	2.6155	2.5968	2.6606	2.8104	2.652	2.5701
23	2.5882	2.6337	2.6787	2.7759	2.7538	2.7069	2.6968
24	2.2148	2.3461	2.5423	2.4714	2.561	2.7633	2.6155
Max	2.5882	2.6337	2.6787	2.7759	2.8104	2.7633	2.6968
Min	1.262	1.5028	1.5912	1.5384	1.5364	1.6244	1.6278
Avg	1.9703	2.0624	2.1505	2.0932	2.1486	2.2014	2.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 211 / Incomer No.2

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4806	2.5072	2.7463	2.7221	2.8654	2.8753	2.7801
2	2.4451	2.4714	2.7149	2.6787	2.8597	2.8753	2.7069
3	2.3034	2.2923	2.5339	2.4615	2.7149	2.8006	2.5789
4	2.1616	2.2565	2.4253	2.2081	2.4253	2.6886	2.3777
5	1.9845	2.2081	2.3282	2.0271	2.2081	2.5393	2.1765
6	1.7896	1.9909	2.1491	1.8642	2.0237	2.0538	2.0119
7	1.7909	1.7375	1.828	1.7918		2.0165	1.829
8	1.7375	1.7194	1.701	1.7741	1.7375	1.8484	1.8107
9	1.6095	1.6644	1.6278	1.701	1.6827	1.829	1.6461
10	1.6095	1.6461	1.5364	1.6278	1.6461	1.6827	1.6095
11	1.5546	1.6461	1.5729	1.6644	1.6827	1.6461	1.6278
12	1.6644	1.7375	1.6644	1.8107	1.7558	1.7558	1.7558
13	1.8473	1.9753	1.8839	2.0119	1.9753	2.0668	1.9204
14	2.0485	2.2131	2.1948	2.2497	2.3045	2.2131	2.1582
15	2.2131	2.3152	2.3411	2.3594	2.3228	2.2862	2.3594
16	2.2779	2.3525	2.3228	2.3228	2.3228	2.1582	2.3348
17	2.0538	2.1658	2.0668	2.1582	2.2131	1.9204	2.0633
18	1.8671	1.9418	1.829	1.9753	2.0302	1.8656	1.8823
19	2.2032	2.1658	2.1216	2.3228	2.2805	2.4691	2.2081
20	2.2965	2.3899	2.3411	2.396	2.371	2.396	2.268
21	2.3525	2.4646	2.4326	2.524	2.4832	2.4691	2.524
22	2.5158	2.9995	2.7042	2.7938	2.8858	2.652	2.7692
23	2.8959	2.9995	2.955	3.0624	3.1687	2.963	2.9502
24	2.6244	2.7149	2.8416	2.8117	2.9683	2.95	2.8715
Max	2.8959	2.9995	2.955	3.0624	3.1687	2.963	2.9502
Min	1.5546	1.6461	1.5364	1.6278	1.6461	1.6461	1.6095
Avg	2.0970	2.1906	2.2026	2.2216	2.3012	2.2925	2.2175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 202 / TAR FILE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.2862	2.2862	2.4387	2.4387	2.4387	2.4387
2	2.1338	2.2862	2.2862	2.2862	2.2862	2.2862	2.2862
3	2.1338	2.1338	2.1338	2.2862	2.2862	2.1338	2.2862
4	2.1338	2.1338	2.1338	2.1338	2.2862	1.9814	2.1338
5	1.9814	2.1338	2.1338	2.1338	2.1338	1.9814	2.1338
6	1.9814	1.9814	2.1338	2.1338	2.1338	1.9814	2.1338
7	1.829	1.9814	1.9814	1.9814	.1524	1.829	1.9814
8	1.829	1.9814	1.829	1.829	1.9814	1.6766	1.829
9	1.829	1.829	1.6766	1.6766	1.829	1.5242	1.829
10	1.6766	1.6766	1.6766	1.5242	1.5242	1.6766	1.829
11		1.6766	1.5242	1.5242	1.5242	1.6766	1.829
12		1.6766	1.6766	1.829	1.829	1.6766	1.829
13		1.829	1.6766	1.829	1.829	1.6766	1.829
14		1.9814	1.6766	1.829	1.829	1.829	1.829
15		1.9814	1.9814	1.9814	1.829	1.829	1.9814
16		2.1338	1.9814	1.9814	1.829	1.9814	1.9814
17		2.1338	.6097	1.9814	1.829	1.829	1.9814
18		1.9814	1.829	1.829	1.6766	1.829	1.829
19		1.9814	1.9814	2.1338	1.9814	1.9814	1.9814
20		2.2862	2.2862	2.2862	2.2862	2.2862	2.2862
21		2.2862	2.2862	2.2862	2.2862	2.2862	2.2862
22		2.4387	2.4387	2.4387	2.4387	2.4387	2.4387
23		2.5911	2.4387	2.5911	2.4387	2.4387	2.5911
24		2.4387	2.4387	2.5911	2.4387	2.4387	2.4387
Max	2.2862	2.5911	2.4387	2.5911	2.4387	2.4387	2.5911
Min	1.6766	1.6766	.6097	1.5242	.1524	1.5242	1.829
Avg	1.9814	2.0767	1.9624	2.0640	1.9624	1.9878	2.0830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 201 / WOMEN HOSPITAL EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.0389	.0777	.0381	.077
2	.0572	.0762	.0762	.077	.058	.0381	.0389
3	.0572	.0762	.0572	.0381	.058	.0381	.0389
4	.0572	.0762	.0572	.0389	.0572	.0389	.0389
5	.0762	.0762	.058	.1059	.0831	.0381	.0381
6	.08	.0869	.077	.1372	.0633	.0572	.0792
7	.0869	.0846	.058	.0381	.0792	.058	.0495
8	.0777	.0777	.0572	.0762		.077	.077
9	.0846	.1158	.0572	.0389	.1471	.0702	.0389
10	.0739	.0831	.128	.1745	.1646	.1661	.1776
11	.1928	.1562	.2103	.1897	.1776	.1921	.1837
12	.1906	.0953	.2019	.1997	.1822	.2012	.1707
13	.1883	.1143	.2042	.2012	.1616	.2004	.1722
14	.1638	.1143	.2019	.093	.1768	.2042	.1867
15	.157	.1029	.2027	.1936	.1898	.205	.1791
16	.1661	.1197	.2088	.1974	.1692	.0495	.1715
17	.1913	.106	.2141	.1959	.1722	.0998	.1737
18	.1555	.0762	.1638	.1898	.1608	.208	.1692
19	.1136	.0953	.0961	.0991	.0785	.1958	.1555
20	.0953	.0953	.0777	.0968	.0572	.1158	.0892
21	.0953	.0961	.0961	.0968	.0572	.0396	.077
22	.0961		.0015	.077	.056	.0762	.1067
23	.0953	.0762	.0587	.0777	.0554	.0389	.1174
24	.0572	.0762	.0777	.077	.0762	.0389	.0427
Max	.1928	.1562	.2141	.2012	.1898	.208	.1867
Min	.0572	.0762	.0015	.0381	.0554	.0381	.0381
Avg	.1111	.0936	.1132	.1145	.1113	.1036	.1104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 202 / RAMDASPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7936	3.8862	4.1078	4.0481	4.3557	4.1739	4.135
2	1.7627	3.6084	3.6439	3.7959	4.0231	3.9662	3.8165
3	1.6095	3.3992	3.4543	3.5193	3.7456	3.8353	3.5094
4	1.4952	3.2152	3.2192	3.2937	3.5685	3.5158	3.2609
5	1.448	2.969	3.0734	3.0826	3.2278	3.1997	3.0331
6	1.3664	2.7858	2.9134	2.8837	3.0361	2.9666	2.8677
7	1.2612	2.6223	2.5614	2.7717	2.8594	2.8009	2.7222
8	1.2582	2.4866	2.5294	2.7153	1.4297	2.6683	2.6803
9	2.3434	2.4539	2.5286	2.5789	2.7283	2.6298	2.7435
10	2.4348	2.4691	2.5781	2.8052	2.7397	2.7772	2.7839
11	2.6676	2.6444	2.7748	2.8826	2.7489	1.5036	2.8193
12	2.8414	2.873	2.9325	3.0192	3.1565	2.8837	3.1283
13	3.1017	3.1226	3.2144	3.4779	3.2807	3.232	3.4153
14	3.4477	3.3847	3.4999	3.6876	3.5962	3.4923	3.5528
15	3.6005	3.5655	3.7929	3.8855	3.9292	3.6236	3.6351
16	3.5421	3.4728	3.8958	3.8649	3.9087	1.973	3.4491
17	3.3105	3.4378	1.9075	3.5389	3.7464		3.296
18	3.1391	3.2282	3.4263	3.405	3.7113	4.4567	3.1283
19	3.2907	3.3673	3.4988	3.4776	3.7479	4.1526	3.158
20	3.4446	3.3108	3.5254	3.5267	3.8403	4.0322	3.2472
21	3.4789	3.3313	3.6054	3.6214	3.6188	3.8119	3.2853
22	3.6183	3.7089	3.9507	4.2013	3.9613	3.9339	3.3593
23	4.0939	4.1665	4.4749	4.6578	4.5637	4.4307	4.3857
24	4.0516	4.2059	4.3126	4.4391	4.5675	4.4925	4.27
Max	4.0939	4.2059	4.4749	4.6578	4.5675	4.4925	4.3857
Min	1.2582	2.4539	1.9075	2.5789	1.4297	1.5036	2.6803
Avg	2.7667	3.2381	3.3092	3.4658	3.5038	3.4153	3.3201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 204 / D. P.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2508	4.4311	4.4073	2.5034	4.9269	4.6934	4.7367
2	3.9765	4.034	4.0802	4.2982	4.5801	4.4431	4.321
3	3.6969	3.7715	3.869	3.9643	4.2562	4.2576	4.0931
4	3.2796	3.4465	3.6467	3.6802	3.9476	3.9027	3.7288
5	3.0185	3.2137	3.4779	3.4305	3.6995	3.5631	3.4564
6	2.7412	2.9634	3.1497	3.185	3.5749	3.1188	3.1873
7	2.6688	2.7496	2.9167	2.9636	3.4118	3.0345	2.9697
8	2.5972	2.6399	2.8461	2.7999	1.6766	2.9161	2.8102
9	2.5705	2.5903	2.7683	2.8704	2.923	2.9099	2.7773
10	2.6783	2.6205	2.7237	2.9276	2.9835	3.0155	2.7397
11	2.8677	2.8006	2.886	3.19	3.1904	3.3097	2.9336
12	3.1345	3.1417	3.0537	3.415	3.5681	3.4078	3.3444
13	3.3809	3.405	3.2853	3.7185	3.8024	3.693	3.7008
14	3.682	3.6968	3.9132	4.2038	4.2882	3.9195	3.9552
15	3.9586	4.0112	1.563	4.4227	4.5635	4.0714	4.2002
16	3.9274	3.911	3.9903	4.3541	4.4802	2.114	4.2059
17	3.6679	3.7401	4.6579	4.1826	4.2299	2.3503	4.0749
18	3.4637	3.5267	2.2009	3.9744	4.0981	3.9102	3.786
19	3.4857	3.5394	4.0832	3.9817	4.4022	3.7365	3.7045
20	3.6976	3.6383	4.167	4.1137	4.4024	4.0626	3.8289
21	3.7266	3.7601	4.1499	4.1553	4.2739	4.0634	4.0223
22	3.8896	4.0398	4.63	4.6502	4.6894	4.3812	4.1998
23	4.401	4.5073	5.228	5.2271	5.0827	4.9827	4.8742
24	4.5325	4.7264	4.9459	5.0699	5.1951	5.058	5.0032
Max	4.5325	4.7264	5.228	5.2271	5.1951	5.058	5.0032
Min	2.5705	2.5903	1.563	2.5034	1.6766	2.114	2.7397
Avg	3.4706	3.5377	3.6100	3.8034	4.0103	3.7048	3.7773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 205 / AKASHWANI

Feeder KV- 11 / OUTGOING

DATE	19-APR-17
HR	Load (MW)
15	.0876
16	.0886
Max	.0886
Min	.0876
Avg	.0881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 207 / 11KV ICON HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1905	.1715	.1715	.1715	.1448	.1715
2	.1524	.1905	.1715	.1715	.1905	.1433	.1905
3	.1334	.1715	.1715	.1715	.1905	.1433	.1715
4	.1334	.1715	.1715	.1524	.1715	.1433	.1715
5	.1524	.1524	.1524	.1524	.1524	.1433	.1524
6	.1334	.1334	.1524	.1334	.1524	.1433	.1524
7	.1524	.1334	.1524	.1524	.1524	.1715	.1524
8	.1524	.1524	.1715	.1524		.1905	.1524
9	.1334	.1715	.1905	.1905	.1905	.1905	.2096
10	.1524	.1715	.2096	.1905	.1905	.1905	.2096
11	.1905	.1715	.2096	.1991	.2286	.2103	.2286
12	.181	.1715	.2096	.2286	.2477	.2477	.2286
13	.1905	.1715	.2286	.2286	.2477	.2477	.2477
14	.1905	.1715	.2286	.2286	.2286	.2477	.2667
15	.1715	.1905	.2286	.2477	.2286	.2286	.2667
16	.2096	.1698	.2096	.2477	.2286		.2667
17	.2096	.1698	.2096	.2012	.2286		.2477
18	.2096	.1715		.2075	.2286	.2286	.2286
19	.2096	.1905	.2096	.2075	.2096	.2286	.2286
20	.2096	.2096	.2286	.2096	.1905	.2096	.2096
21	.2096	.2286	.2477	.2096	.1905	.1905	.1905
22	.1905	.2286	.2096	.2263	.1905	.2096	.1715
23	.1905	.2096	.1905	.1905	.1715	.2096	.1905
24	.1524	.1905	.1715	.1715	.1715	.1478	.1905
Max	.2096	.2286	.2477	.2477	.2477	.2477	.2667
Min	.1334	.1334	.1524	.1334	.1524	.1433	.1524
Avg	.1735	.1785	.1955	.1934	.1980	.1914	.2040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 210 / 11 kvIncommer 1

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8435	3.9251	4.1916	4.0603	4.4166	4.2124	4.1976
2	3.6233	3.677	3.7484	3.8684	4.0632	3.9933	3.9358
3	3.3006	3.5205	3.4388	3.5391	3.8239	3.8626	3.594
4	2.9689	3.2636	3.3093	3.3196	3.604	3.5284	3.3013
5	2.8035	3.0613	3.1624	3.1459	3.3366	3.2207	3.0544
6	2.6795	2.859	2.9601	2.9995	3.18	3.0331	2.9538
7	2.5423	2.7252	2.6838	2.7892	2.9355	2.8601	2.7801
8	2.5555	2.5606	2.5975	2.8258	1.4175	2.7607	2.7617
9	2.4417	2.5555	2.5438	2.6387	2.8207	2.7428	2.8349
10	2.5697	2.5606	2.7023	2.9721	2.8898	2.8862	2.8898
11	2.8492	2.771	2.9355	2.9931	2.8898	1.5546	3.0058
12	1.5089	2.9813	3.091	3.1484	3.2922	1.5546	3.3036
13	3.3191	3.2724	3.3745	3.5751	3.4202	1.6918	3.5501
14	3.6313	3.5116	3.658	3.8485	3.7677	1.829	3.6675
15	3.7412	3.677	3.9963	3.9485	4.2524	1.8747	3.7491
16	3.6122	3.4385	4.0695	3.9485	4.0146	2.0119	3.5322
17	3.4229	1.829	2.0759	3.6488	3.8226	.0914	3.4271
18	3.2739	3.3842	3.6214	3.5759	3.8073	4.5907	3.6855
19	3.4293	3.5214	3.6854	3.5944	3.837	4.2524	3.2739
20	3.5482	3.4474	3.6214	3.677	3.8561	4.0146	3.3654
21	3.5848	3.4931	3.7027	3.7412	3.722	3.8501	3.3814
22	3.8043	3.8882	2.1033	4.3438	4.1274	4.0329	3.5643
23	4.2524	4.3288	4.5451	4.7676	4.5706	4.5268	4.5725
24	4.1282	4.2799	4.4757	4.4627	4.6742	4.6323	4.3256
Max	4.2524	4.3288	4.5451	4.7676	4.6742	4.6323	4.5725
Min	1.5089	1.829	2.0759	2.6387	1.4175	.0914	2.7617
Avg	3.2264	3.2722	3.3456	3.5597	3.6059	3.0670	3.4461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 211 / Incommmer No.2

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2592	2.3285	2.2731	2.3167	2.5953	2.4253	2.3891
2	2.1472	2.1807	2.0633	2.2081	2.5019	2.3285	2.2262
3	2.0165	2.0513	1.9909	2.0633	2.3899	2.2207	2.0995
4	1.7551	1.8665	1.9163	1.8823	2.1992	2.1176	1.9185
5	1.6263	1.7002	1.8625	1.7918	2.0698	1.8983	1.7918
6	1.4784	1.6078	1.6655	1.647	1.957	1.6118	1.6651
7	1.46	1.4815	1.5565	1.5565	1.7924	1.6108	1.5565
8	1.4415	1.4632	1.5223	1.4661		1.576	1.5023
9	1.4415	1.46	1.5746	1.5546	1.6461	1.2308	1.5364
10	.4938	1.4661	.5175	1.6289	.567	1.6655	1.5384
11	1.6651	1.5729	1.6827	1.8656	1.8656		1.7193
12	1.8267	1.7741	1.8107	1.9753	2.0271		1.9728
13	1.97	1.885	1.9753	2.1033	2.1948		2.1357
14	2.1132	2.0328	2.268	2.3891	2.4072		2.2744
15	2.167	2.1622	.3292	2.4356	2.5339		2.3529
16	2.1312	2.0328	2.7252	.6283	2.4326		2.3461
17	1.9936	1.9404	2.2131	2.2731	2.2805		2.2314
18	1.9204	1.9366	2.4253	2.2361	2.3045	2.1357	2.1399
19	2.0119	1.9521	2.4326	2.2731	2.4326	2.1399	2.1399
20	2.1033	1.9879	2.4143	2.3285	2.3348	2.2497	2.1399
21	2.1216	2.0237	2.3712	2.347	2.2986	2.19	2.2546
22	2.1582	2.167	2.6063	2.6612	2.5873	2.3777	2.3388
23	2.3777	2.3282	2.8054	2.838	2.6147	2.6606	2.6242
24	2.3152	2.5057	2.4025	2.6063	2.7446	2.6427	2.6425
Max	2.3777	2.5057	2.8054	2.838	2.7446	2.6606	2.6425
Min	.4938	1.46	.3292	.6283	.567	1.2308	1.5023
Avg	1.8748	1.9128	1.9752	2.0448	2.2077	2.0636	2.0640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 401 / 33KV VIDYUT BHAVAN I/C

Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	17.4726	18.3745	19.0233	19.5062	20.2835	19.4456	19.8766
2	16.1728	16.7627	17.3869	17.9355	18.7564	18.099	18.1413
3	14.864	15.9311	16.3466	16.6324	17.516	17.3251	17.0096
4	13.4403	14.7279	15.2058	15.6173	16.4141	16.1111	15.7064
5	12.5115	13.7648	14.3805	14.6777	15.203	14.9954	14.5062
6	11.8599	12.7201	13.4717	13.7929	14.625	13.8306	13.7586
7	11.3455	12.1468	12.3228	12.9424	14.4507	12.9538	12.8875
8	11.2214	11.6941	11.877	12.3731	10.3224	12.5034	9.3964
9	10.9603	11.4941	12.005	12.3594	12.9287	12.596	12.5652
10	11.6255	11.6255	12.3274	13.1773	13.0042	13.2133	12.8739
11	12.8098	12.3594	13.3814	14.081	13.8546	14.3553	13.9323
12	13.554	13.3745	13.9781	15.0663	15.439	14.6936	15.1029
13	14.7097	14.5542	14.9589	16.6467	16.3238	15.8705	16.3524
14	15.9471	15.7202	16.7352	17.9042	17.8601	16.9839	17.4189
15	16.9971	16.7284	13.7929	18.8701	19.4514	17.464	18.1093
16	17.1399	16.5141	17.1537	18.9758	19.3073	13.6489	18.0796
17	16.0975	16.2106	17.4486	18.2448	18.4226	8.3333	17.5429
18	15.2949	15.0755	17.1468	16.9416	17.2869	18.5254	16.0946
19	15.3429	15.0343	16.8793	16.7913	17.6201	18.0453	15.7134
20	15.9877	15.4115	17.1331	17.1765	17.7412	18.0247	16.2963
21	15.9397	15.8573	17.2451	17.2108	17.3297	17.5035	16.5141
22	16.4198	17.1468	18.6695	18.9735	18.6557	18.2922	16.9125
23	18.6283	19.1222	21.0631	21.246	20.8676	20.4527	20.224
24	19.025	19.7669	20.9042	21.118	21.3307	20.4058	20.5145
Max	19.025	19.7669	21.0631	21.246	21.3307	20.4527	20.5145
Min	10.9603	11.4941	11.877	12.3594	10.3224	8.3333	9.3964
Avg	14.8070	15.0882	15.8682	16.5942	16.8748	15.9864	16.0637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 410 / T/F no.1

Feeder KV- 33 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9605	1.9959		1.9753	2.2405		2.0302
2	1.9044	1.885		1.8656	2.0725		1.9805
3	1.7187	1.7741		1.7558	1.9404		1.701
4	1.4969	1.6632		1.6461	1.8107		***
5	1.386	1.5524		1.5364	1.6461	***	***
6	1.2752	1.4415	1.5123	1.4815	1.5364	***	***
7	1.2752	1.3717		1.3717	4.1701	***	***
8	1.262	1.4815		1.3169	1.4266	***	***
9	1.2197	1.2752	1.2752	1.3169	1.3717	***	***
10	1.4815	1.2071	1.3306	1.4266	1.4266	***	***
11	1.386	1.3717	1.4266	1.773	1.4266	***	***
12		1.5364	1.5364		1.5912	***	1.5364
13		1.6632	1.701		1.701	***	
14		1.7741	1.8656		1.8656		
15	1.773	1.885	1.9753		1.9753		
16	2.1491	1.8296	2.0302	1.9404	1.9753		1.5043
17	1.7147	1.7187	.1097		1.9204	28.8066	1.5203
18	1.6461		5.1029	1.8296		***	1.5364
19	1.7558		1.7558	1.885		2.1399	1.5524
20	1.8107		1.7558	1.885		1.9547	1.5524
21	1.8656		1.8656	1.885		1.9204	
22	1.9204			2.2405	1.9879	2.0302	
23	2.1399		2.3045	2.4577	2.2565	2.2497	
24	2.0165	2.0851	2.1622	2.1948	2.2965	2.2731	2.1399
Max	2.1491	2.0851	5.1029	2.4577	4.1701	552.127	569.5481
Min	1.2197	1.2071	.1097	1.3169	1.3717	1.9204	1.5043
Avg	1.6742	1.6395	1.8569	1.7781	1.9319	292.7615	221.4065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 411 / T./F NO. 2

Feeder KV- 33 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2965	2.3285		2.3045	2.7446		2.3891
2	2.1845	2.2177		2.2262	2.4949		2.2262
3	2.0165	2.0513		1.9004	2.384		2.1399
4	1.7741	1.885		1.9004	2.1948		1.9004
5	1.6632	1.7187		1.7918			1.7918
6	1.4969	1.6078	1.6655	1.6289	1.9753		1.6289
7	1.4969	1.4815		1.5746	1.8656	1.6632	1.5203
8	1.4266	1.4815		1.4661	1.701	1.5581	1.4118
9	1.4415	1.4815	1.5043	1.5912	1.6461	1.5524	1.5364
10	1.4815	1.3717	1.5524	1.701	1.701	1.7187	1.5746
11	1.6655	1.5912	1.701		1.8656		1.4815
12		1.7741	1.8107		2.0302		1.701
13		1.9404	1.9753		2.0851		
14		2.0513	2.3045		2.3594		
15	2.2177	2.1622	.3292		2.4691		
16	2.1491	2.0513	2.7435		2.3348		2.3102
17	2.0302	1.9404	2.1948		2.3045		2.2731
18	1.9204		2.4691	2.2731			2.1399
19	2.0302		2.1399	2.2731		2.0851	2.1622
20	2.1399		2.0302	2.3285		2.1719	2.1399
21	2.1399		2.2565	2.3525		2.1399	
22	2.1948			2.6886	2.552	2.2262	
23	2.4143		2.552	2.8567	2.7166	2.524	
24	2.3525	2.524	2.3102	2.4691	2.7446	2.5789	2.4977
Max	2.4143	2.524	2.7435	2.8567	2.7446	2.5789	2.4977
Min	1.4266	1.3717	.3292	1.4661	1.6461	1.5524	1.4118
Avg	1.9301	1.8700	1.9712	2.0780	2.2194	2.0218	1.9347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 201 / DAMANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5309	.5408	.5607	.5601	.5723	.5765	.5618
2	.5256	.513	.5411	.5322	.5608	.5689	.537
3	.5038	.5061	.5289	.533	.5391	.5281	.5302
4	.4962	.4985	.5281	.5277	.5368	.535	.5286
5	.4684	.4947	.5064	.5269	.5113	.5297	.5046
6	.4474	.4909	.4988	.5013	.5067	.5079	.4897
7	.4253	.4314	.4373	.4529	.438	.4409	.4569
8	.3364	.3929	.3833	.3911	.3843	.3826	.3971
9	.3391	.3536	.3532	.373	.3511	.3532	.37
10	.37	.173	.3652	.3566	.4053	.37	.3566
11	.3205	.3422	.3774	.357	.3602	.3549	.3658
12	.3776	.3807	.3843	.3887	.3789	.3889	.3719
13	.4161	.3959	.4764	.452	.4144	.4251	.4375
14	.4238	.426	.4546	.4619	.456	.4297	.4527
15	.4539	.4283	.4924	.4949	.4682	.4167	.455
16	.4668	.4546	.463	.4756	.4781	.4484	.4866
17	.4035	.447	.4268	.4367	.4026	.4136	.4626
18	.3536	.4241	.4199	.385	.3976	.3904	.2157
19	.4792	.5094	.4823	.493	.4504	.443	.4907
20	.5052	.5599	.5172	.5586	.5327	.5256	.5437
21	.5784	.5716	.5225	.5654	.5327	.5294	.5977
22	.5631	.5714	.5662	.6	.5621	.5569	.5993
23	.5768	.5944	.597	.6115	.5921	.5763	.6
24	.5732	.5755	.5752	.5807	.5791	.5868	.5652
Max	.5784	.5944	.597	.6115	.5921	.5868	.6
Min	.3205	.173	.3532	.3566	.3511	.3532	.2157
Avg	.4556	.4615	.4774	.4840	.4755	.4699	.4740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 202 / GOYANAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7005	2.7904	2.7938	2.8234	2.8671	2.9611	2.8115
2	2.6171	2.6677	2.6803	2.7338	2.7536	2.8368	2.6761
3	2.5719	2.5729	2.6513	2.6877	2.6938	2.7442	2.6229
4	2.546	2.598	2.5928	2.674	2.6702	2.6719	2.5919
5	2.5361	2.5643	2.5998	2.6751	2.655	2.6539	2.5886
6	2.5317	2.6243	2.6518	2.6842	2.6804	2.6818	2.6159
7	2.6268	2.6934	2.6856	2.784	1.2917	2.7865	2.7009
8	2.5955	2.654	2.6884	2.7246	2.0672	2.7037	2.7071
9	2.4041	2.5663	2.5829	2.5505	2.9159	2.5655	2.6018
10	2.2682	2.3927	2.3955	2.4549	2.6094	2.4386	2.5484
11	2.2257	2.4457	2.3897	2.4259	2.4789	2.324	2.5369
12	2.2961	2.5064	2.4034	2.5115	2.6337	2.3543	2.5766
13	2.3625	2.5043	2.4271	2.5682	2.6542	2.3386	2.6043
14	2.3833	2.3707	2.4202	2.5966	2.4444	2.192	2.4812
15	2.3142	2.5445	2.4623	2.5398	2.4407	2.3762	2.3881
16	.8474	2.5486	1.2209	2.5616	.317	2.3909	2.4196
17	1.3175	2.5952	1.4914	2.5569		2.4271	2.4994
18	2.827	2.5815	2.5361	2.6316	3.0019	2.441	1.2704
19	3.1725	2.9385	2.6814	3.0134	3.2952	2.8651	2.7787
20	3.3258	2.7675	3.3718	3.2343	3.4499	3.1358	3.079
21	3.0973	3.0863	3.1881	3.2279	3.3546	3.0254	3.0044
22	2.9866	3.0262	3.0273	3.1058	3.2306	3.0412	2.946
23	2.9988	3.0239	3.0516	3.0699	3.1996	3.0336	2.9881
24	2.9037	2.9497	2.9256	2.9364	3.0508	3.0212	2.9417
Max	3.3258	3.0863	3.3718	3.2343	3.4499	3.1358	3.079
Min	.8474	2.3707	1.2209	2.4259	.317	2.192	1.2704
Avg	2.5190	2.6672	2.5800	2.7405	2.6416	2.6671	2.6241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 204 / PANKAJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3152	1.3392	1.3535	1.3445	1.3737	1.3817	1.3843
2	1.2832	1.2707	1.2928	1.2886	1.3107	1.3581	1.3358
3	1.2388	1.2368	1.2849	1.2503	1.264	1.297	1.2941
4	1.2228	1.2246	1.2471	1.2358	1.2533	1.2646	1.2804
5	1.2019	1.2124	1.2194	1.2327	1.2263	1.2486	1.2306
6	1.1812	1.19	1.1917	1.1865	1.2063	1.2285	1.2026
7	1.1173	1.1618	.5929	1.158	.0168	1.1576	1.1512
8	1.0921	1.1542	1.1054	1.1199	1.2884	1.1858	1.1298
9	1.1145	1.1717	1.0692	1.126	1.1812	1.1734	1.0869
10	1.0691	1.1685	1.0837	1.0672	1.1127	1.1128	1.1428
11	1.0822	1.1034	1.1237	1.0707	1.1446	1.0959	1.1481
12	1.0614	1.1695	1.1232	1.0955	1.1351	1.083	1.1691
13	1.1453	1.1624	1.1321	1.1218	1.1728	1.1051	1.1896
14	1.1522	1.2124	1.1712	1.1355	1.1852	1.1089	1.1721
15	1.1435	1.2088	1.1557	1.1492	1.1859	1.1613	1.1702
16	.426	1.19	.5876	1.1801	1.1943	1.1606	1.2387
17	1.1443	1.2016	.9619	1.1712	1.2035	1.1702	1.2563
18	1.2503	1.1734	1.2332	1.1958	1.1803	1.1062	.5914
19	1.3417	1.339	1.3188	1.3188	1.3468	1.3306	1.3112
20	1.4068	1.4217	1.3699	1.4299	1.4011	1.5013	1.3501
21	1.4238	1.4179	1.3748	1.417	1.3634	1.4427	1.3786
22	1.393	1.3878	1.3908	1.437	1.3896	1.465	1.3854
23	1.4292	1.4141	1.4337	1.4713	1.4373	1.4883	1.4177
24	1.3905	1.4022	1.4133	1.4437	1.4292	1.4254	1.4122
Max	1.4292	1.4217	1.4337	1.4713	1.4373	1.5013	1.4177
Min	.426	1.1034	.5876	1.0672	.0168	1.083	.5914
Avg	1.1928	1.2473	1.1763	1.2353	1.2084	1.2522	1.2262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 205 / NEW TAPADIYA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.216	1.2838	1.3397	1.3006	1.3403	1.3494	1.3471
2	1.1741	1.2061	1.2791	1.2694	1.2862	1.2913	1.2935
3	1.1183	1.1572	1.2224	1.216	1.2236	1.2615	1.2514
4	1.0932	1.1145	1.1549	1.1916	1.1557	1.1854	1.2194
5	1.0489	1.071	1.1075	1.1412	1.1114	1.1688	1.1365
6	.9863	1.0421	1.0823	1.0977	1.0726	1.1435	1.1136
7	.9726	1.0314	1.0629	1.0305	1.2544	1.0891	1.0675
8	.9031	.9802	.9817	.9779	1.0221	1.0008	.9675
9	.8582	.9414	.9205	.9238	.9238	.9	.4717
10	.7949	.8848	.8837	.8696	.8627	.8484	.8321
11	.7888	.8381	.8391	.8185	.8537	.8521	1.0373
12	.6688	.8852	.8903	.8498	.8834	.8552	.8364
13	.8606	.9842	.8964	.9423	.9063	.9101	.9141
14	.9811	1.0528	.9627	.9596	1.0192	.9918	.964
15	1.02	1.1151	1.0268	1.0601	1.0512	1.0162	1.0602
16	.5274	1.0951	1.0497	1.0976	1.0886	1.0489	1.0492
17	.5865	1.0766	1.0314	1.0328	1.0703	1.0176	.9975
18	1.1046	1.0815	.9909	.9932	1.0234	1.0009	.5068
19	1.236	1.1111	1.123	1.1314	1.1614	1.111	1.0972
20	1.2253	1.2279	1.2068	1.2312	.647	1.1755	1.1925
21	1.1689	1.254	1.2367	1.2595	1.2913	1.1887	1.22
22	1.2123	1.2863	1.3595	1.3335	1.303	1.3206	1.2817
23	1.3717	1.4228	1.4289	1.4693	1.4371	1.4257	1.38
24	1.312	1.3929	1.3984	1.4196	1.4143	1.4177	1.3793
Max	1.3717	1.4228	1.4289	1.4693	1.4371	1.4257	1.38
Min	.5274	.8381	.8391	.8185	.647	.8484	.4717
Avg	1.0096	1.1057	1.1031	1.1090	1.1001	1.1071	1.0674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 206 / Ashok nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3302	3.4129	3.4251	3.4657	3.4955	3.5622	3.4165
2	3.1929	3.2562	3.2857	3.3457	3.3296	3.4076	3.2796
3	3.0918	3.1868	3.2032	3.2502	3.2463	3.3204	3.2395
4	3.0362	3.1341	3.1165	3.2114	3.186	3.2638	3.1661
5	3.0141	3.0674	3.0906	3.1456	3.154	3.2072	3.1173
6	3.0423	3.082	3.1104	3.1285	3.1647	3.2	3.1135
7	3.0231	3.0737	3.1345	3.1102	1.595	3.2326	3.0239
8	2.8333	2.8561	3.0521	3.0002	2.1863	3.2275	1.5417
9	2.7342	2.7763	2.885	2.857	3.2794	3.0609	2.8272
10	2.5689	2.7761	2.613	2.6706	2.8927	2.8674	2.7741
11	2.4489	2.7109	2.5093	2.5872	2.6232	2.715	2.7145
12	2.4711	2.69	2.4605	2.6477	2.6717	2.6869	2.7853
13	2.5642	2.7307	2.5907	2.7377	2.7149	2.7888	2.7881
14	2.6078	2.6629	2.6669	2.7831	2.8459	2.7158	1.7246
15	2.5642	2.7734	2.7007	2.7235	2.7369	2.7413	2.6646
16	1.1629	2.6867	1.4114	2.8047	2.8948	2.7305	1.3702
17	1.3251	2.8638	1.8018	2.7746	2.8796	2.7212	2.7458
18	2.7499	2.9096	2.9147	2.8087	2.9118	2.7373	1.3817
19	3.3793	3.2609	3.1828	3.2496	3.2045	3.0608	3.0715
20	3.5379	3.711	3.5446	3.5091	3.6494	3.6079	3.4653
21	3.5307	3.6296	3.5079	3.5909	3.6851	3.6185	3.4819
22	3.5483	3.6603	3.6012	3.6389	3.6069	3.6145	3.4981
23	3.6471	3.6526	3.7005	3.696	3.7129	3.6622	3.6257
24	3.5183	3.5718	3.5696	3.6382	3.6078	3.6702	3.6108
Max	3.6471	3.711	3.7005	3.696	3.7129	3.6702	3.6257
Min	1.1629	2.6629	1.4114	2.5872	1.595	2.6869	1.3702
Avg	2.8718	3.0890	2.9616	3.0990	3.0531	3.1425	2.8511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 210 / 11KV Incommer no.I NTN

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3998	4.5565	4.6182	4.6256	4.7256	4.8255	4.6803
2	4.2613	4.3413	4.4466	4.4821	4.5407	4.6426	4.4218
3	4.1358	4.1786	4.3339	4.3672	4.3935	4.4875	4.3225
4	4.082	4.1384	4.2099	4.3272	4.2958	4.3324	4.2518
5	4.0039	4.0727	4.1446	4.271	4.2154	4.2977	4.1672
6	3.9033	4.0972	4.1573	4.2133	4.1914	4.2768	4.122
7	3.9728	4.0958	4.119	4.1971	2.9389	4.2364	4.1549
8	3.7901	3.9917	4.0154	4.054	3.4116	4.079	4.0438
9	3.5533	3.8068	3.8205	3.804	4.1415	3.783	3.4109
10	3.3697	3.5752	3.5766	3.618	3.8006	3.6109	3.6362
11	3.3206	3.5226	3.5361	3.5597	3.6404	3.4797	3.8919
12	3.4319	3.6776	3.628	3.6644	3.8416	3.5375	3.7289
13	3.5935	3.7914	3.7181	3.8851	3.8766	3.6004	3.9047
14	3.711	3.8472	3.7764	3.9239	3.8031	3.5304	3.8212
15	3.7282	4.0486	3.8848	4.0234	3.8711	3.7419	3.838
16	1.7734	4.0555	2.6874	4.1011	1.8167	3.8372	3.8607
17	2.3372	4.0672	2.9341	3.9657	1.4502	3.8139	3.9054
18	4.2396	4.0287	3.8877	3.957	4.3633	3.7833	1.9502
19	4.7819	4.5125	4.1941	4.5395	4.826	4.3114	4.3011
20	4.9924	4.9546	5.0272	4.893	5.212	4.7503	4.8005
21	4.7424	4.8531	4.8798	4.9831	5.1125	4.6736	4.757
22	4.6852	4.8011	4.8615	4.9581	5.0435	4.7946	4.7314
23	4.8727	4.9844	5	5.0816	5.1653	4.9705	4.8967
24	4.7229	4.8576	4.8274	4.8733	4.9783	4.9779	4.8365
Max	4.9924	4.9844	5.0272	5.0816	5.212	4.9779	4.8967
Min	1.7734	3.5226	2.6874	3.5597	1.4502	3.4797	1.9502
Avg	3.9335	4.2023	4.0952	4.2654	4.0690	4.1823	4.1015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 211 / 11KV Incommer no.2 NTN

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9049	2.9631	2.9447	2.9999	3.0887	3.0994	3.0964
2	2.8497	2.8343	2.8829	2.9263	2.8865	2.9687	2.9414
3	2.7606	2.7974	2.8645	2.8527	2.8497	2.894	2.9651
4	2.7606	3.3496	2.8275	2.8527	2.8313	2.894	2.8687
5	2.7422	2.7606	2.8275	2.8158	2.7945	2.8753	2.7416
6	2.7138	2.7422	2.7905	2.687	2.7762	2.8006	2.8149
7	2.5398	2.6686	2.6797	2.5923		2.7073	2.5393
8	2.3926	2.411	2.4394	2.5582	2.9784	2.6886	2.5782
9	2.411	2.4846	2.4025	2.411	2.7026	2.6057	2.4045
10	2.2637	2.4662	2.2637	2.2821	2.503	2.4579	2.4797
11	2.1165	2.3106	2.2269	2.1807	2.482	2.4268	2.4459
12	2.2269	1.8785	2.2085	2.2361	1.8753	2.482	2.4949
13	2.3005	2.4045	2.4294	2.5393	1.8569	2.5923	2.4949
14	2.3741	2.3963	2.3741	2.4579	2.5923	2.2981	2.2361
15	2.3373	2.4984	2.3557	2.4025	2.4452	2.482	2.2592
16	.5705	1.8201	.4969	2.5688	2.6475	2.4268	2.7536
17	1.9877	2.6228	2.5214	2.4294	2.6475	2.3901	2.4949
18	1.8772	2.7351	2.5923	2.5923	2.6427	2.4085	
19	2.4085	3.2156	3.1103	3.1623	3.2301	3.1806	3.0152
20	3.2909	3.308	3.2023	2.5004	3.345	3.3813	3.1071
21	3.199	3.2526	3.1471	3.3093	2.5019	3.3438	3.0963
22	3.199	3.308		3.3645	3.3234	3.3285	3.2174
23	3.3093	3.271	3.2944	3.2909	3.3234	3.3436	3.2875
24	3.0519	3.1103	3.0678	3.1471	3.1623	3.2301	3.2499
Max	3.3093	3.3496	3.2944	3.3645	3.345	3.3813	3.2875
Min	.5705	1.8201	.4969	2.1807	1.8569	2.2981	2.2361
Avg	2.5245	2.7337	2.6065	2.7150	2.7603	2.8044	2.7645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 401 / 33 kv I/C Appatapa to New
Tapd Feeder KV- 33 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.9879	5.1524		5.2072	5.3716	5.4893	5.262
2	4.9331	4.8783	5.1006	5.0976	5.0976	5.2652	5.276
3	4.7687	4.8235	4.9897	4.9879	4.9879	5.0972	5.027
4	4.7687	4.8235	4.9343	4.9879	4.9331	5.0412	4.9723
5	4.7139	4.7139	4.8788	4.9331	4.8235	5.0412	4.8084
6	4.6043	4.7687	4.8788	4.8783	4.8235	4.9291	4.8084
7	4.4946	4.6591	4.7125	4.6591	.9318	4.8171	4.5899
8	4.1658	4.3302	4.3799	4.4946	5.0976	4.6491	4.5696
9	4.0561	4.3302	4.3244	4.2206	4.6043	4.481	3.7739
10	3.8917	4.1658	3.9465	4.0013	4.2754	4.2135	4.2754
11	3.7273	3.9888	3.9465	3.9363	4.2754	4.0561	4.425
12	3.8369	3.7758	4.0013	4.1027	3.8369	4.2754	4.3799
13	4.0561	4.291	4.2754	4.537	3.7821	4.385	4.4907
14	4.2206	4.3394	4.2206	4.4353	4.6043	4.1658	4.1027
15	4.1658	4.4398	4.2754	4.4907	4.2754	4.3302	4.201
16	.7674	3.8369	1.2059	4.6016	3.3984	4.3302	4.6571
17	4.0013	4.5899	4.385	4.3302	3.3436	4.2206	4.4353
18	3.9465	4.768	4.4946	4.5494	4.8788	4.2754	
19	4.9879	5.5996	5.5361	5.5361	5.9322	5.3716	5.2565
20	5.7005	5.7659	5.6457	4.9879	5.9322	5.6667	5.4208
21	5.4264	5.655	5.4813	5.7005	5.0412	5.5361	5.4208
22	5.5361	5.7659	5.6457	5.8649	5.8253	5.861	5.5851
23	5.7005	5.7659	5.7553	5.7553	5.9374	5.7373	5.6946
24	5.262	5.4264	5.3772	5.4264	5.4813	5.7133	5.6127
Max	5.7005	5.7659	5.7553	5.8649	5.9374	5.861	5.6946
Min	.7674	3.7758	1.2059	3.9363	.9318	4.0561	3.7739
Avg	4.4467	4.7772	4.6257	4.8217	4.6455	4.8729	4.8280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 410 / Transformer no.1

Feeder KV- 33 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0959	2.2062	2.2731	2.2614	2.3165	2.3525	2.3153
2	2.0959	2.0959	2.2177	2.2062	2.2062	2.2965	2.131
3	2.0408	2.0408	2.1622	2.1511	2.1511	2.2405	2.131
4	2.0408	2.0408	2.1068	2.1511	2.0959	1.6804	2.1111
5	1.9856	1.9856	2.0513	2.1511	2.0959	2.1285	2.0154
6	1.8753	2.0408	2.1068	2.0959	2.0959	2.1285	2.0154
7	1.9856	2.0408	2.0513	2.0959	.9376	2.1285	2.0698
8	1.8201	1.9304	1.9404	1.9856	2.1511	1.9605	1.9124
9	1.7098	1.8753	1.885	1.8201	1.9304	1.8296	1.4653
10	1.6547	1.7098	1.7098	1.765	1.8201	1.7741	1.8578
11	1.6547	1.8034	1.765	1.7741	1.8201	1.653	3.6123
12	1.6598	1.9142	1.8201	1.8296	1.9856	1.8182	1.885
13	1.8201	1.9725	1.8753	1.9605	1.9304	1.8182	1.9959
14	1.8753	1.9142	1.8753	1.9404	2.0386	1.8733	1.885
15	1.8753	1.9733	1.9856	2.0513	1.8733	1.8733	1.9404
16	.2206	2.0831	.717	2.0513	.7714	1.9284	1.885
17	2.0408	2.0247	1.9304	1.9304	.717	1.8733	1.9404
18	2.0959	2.0513	1.9304	1.9856	2.2177	1.8733	
19	2.5923	2.384	2.482	2.4268	2.5503	2.3141	2.259
20	2.4268	2.4394	2.482	2.5372	2.6057	2.3669	2.3141
21	2.2614	2.384	2.3717	2.4268	2.5206	2.3165	2.3141
22	2.3717	2.4394	2.482	2.5372	2.5206	2.4771	2.3692
23	2.4268	2.4949	2.482	2.5372	2.6326	2.536	2.4243
24	2.2614	2.3165	2.3045	2.3165	2.3717	2.4949	2.3669
Max	2.5923	2.4949	2.482	2.5372	2.6326	2.536	3.6123
Min	.2206	1.7098	.717	1.765	.717	1.653	1.4653
Avg	1.9536	2.0901	2.0420	2.1245	2.0148	2.0723	2.1398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 411 / Transformer no.2

Feeder KV- 33 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.893	2.9506	2.9938	2.4589	3.0599		3.0996
2	2.8384	2.7867	2.8829	2.896	2.8413	2.9687	2.9506
3	2.7292	2.7867		2.8413	2.8413	2.9127	2.8413
4	2.7321	2.7867	2.8275	2.8413	2.7867	2.9127	2.8413
5	2.7321	2.7321	2.8275	2.7867	2.7867	2.8567	2.7321
6	2.7321	2.7321	2.7721	2.6774	2.7321	2.8006	2.7235
7	2.5135	2.6228	2.6612	2.5681		2.6886	2.5135
8	2.3496	2.4042	2.4394	2.5135	2.9506	2.6886	2.6487
9	2.4042	2.4589	2.384	2.4042	2.6774	2.6057	2.2685
10	2.2403	2.4589	2.2403	2.2403	2.4589	2.4394	2.4042
11	2.0764	2.3106	2.1856	2.1622	2.4589	2.4042	2.4646
12	2.1856	1.822	2.1856	2.2177	1.8578	2.4589	2.4949
13	2.2403	2.3645	2.4042	2.5206	1.8578	2.5681	2.4949
14	2.3496	2.3741	2.3496	2.4394	2.5681	2.2949	2.2177
15	2.3189	2.4294	2.2949	2.4394	2.4042	2.4589	2.2405
16	.5464	1.822	.4918	2.5503	2.6228	2.4268	2.7721
17	1.9671	2.6502	2.5135	2.4042	2.6228	2.3496	2.4949
18	1.8578	2.7166	2.5681	2.5681	2.6612	2.4042	
19	2.4042	3.1824	3.0599	3.1145	3.2156	3.1692	3.0053
20	3.2785	3.3265	3.1692	2.4589	3.3265	3.3813	3.0599
21	3.1692	3.271	3.1145	3.2785	2.5206	3.325	3.1145
22	3.1692	3.3265	3.2238	3.3331	3.3048	3.325	3.1692
23	3.2785	3.271	3.2785	3.2785	3.3048	3.3813	3.2785
24	3.0021	3.0599	3.0178	3.1145	3.1145	3.2487	3.209
Max	3.2785	3.3265	3.2785	3.3331	3.3265	3.3813	3.2785
Min	.5464	1.822	.4918	2.1622	1.8578	2.2949	2.2177
Avg	2.5003	2.6936	2.6037	2.6712	2.7381	2.7856	2.7408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 201 / 11 KV ITI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1643	1.1458	1.2883	1.3256	1.3256	1.2986	1.2012
2	1.1088	1.0349	1.2696	1.2696	1.2883	1.1888	1.1458
3	.9979	.961	1.1576	1.1763	1.251	1.0974	1.0719
4	.924	.924	1.0456	1.1203	1.1763	1.0608	1.0349
5	.8871	.924	.9709	1.0269	1.0269	1.0059	.9979
6	.8871	.8686	.9709	.8962	1.0082	.9328	.9425
7	.8316	.8131	.8962	.8962	.7095	.8962	.924
8	.9055	.8501	1.0269	.9335	.9896	.9694	.9979
9	.9795	.8686	.5975	1.0456	.9425	1.0059	
10	1.0903	.9055		1.1763	1.2382	1.0903	
11	1.2382	1.0534	.5975	1.3817	1.46	1.386	1.4563
12	1.4045	1.2012	1.7926	1.6263			1.4937
13	.4805	1.2567	1.8111	1.7002	1.5524	1.5893	1.3256
14	.7207	1.3121	1.7002	1.2382	1.7556	1.5893	1.643
15	.7577	1.3306	1.9404	1.7926	1.7926	1.7187	1.7364
16	1.6827	1.3121	1.7741	1.8111	1.8665	1.7558	1.8858
17	1.6278	1.3121	1.7741	1.7926	1.7741	1.6278	1.8111
18	1.4815	1.2567	1.6448	1.7002	1.6263	1.4266	
19	1.6278	1.3676		1.6263	1.7187	1.6461	1.6448
20	1.5364	1.5524	1.7372	1.7002	1.6263	1.7375	1.7372
21	1.4632	1.4969	1.5339	1.5893	1.6078	1.5546	1.4784
22	1.2936	1.419	1.419	1.4969	1.3535	1.4563	1.4563
23	1.2752	1.3256	1.3817	1.46	1.4003	1.3717	1.4563
24	1.2197	1.2567	1.3256	1.363	1.3491	1.363	1.262
Max	1.6827	1.5524	1.9404	1.8111	1.8665	1.7558	1.8858
Min	.4805	.8131	.5975	.8962	.7095	.8962	.924
Avg	1.1494	1.1562	1.3480	1.3810	1.3843	1.3378	1.3668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 202 / 11 KV MHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2402	.2587	.2772	.2772	.2743	.2772
2	.2402	.2402	.2402	.2402	.2772	.2641	.2587
3	.2218	.2218	.2402	.2218	.2402	.2587	.2402
4	.1848	.2218	.2218	.1848	.2218	.2218	.2218
5	.1848	.2218	.2218	.1663	.2033	.2033	.2218
6	.1478	.1848	.1848	.1663	.1848	.1848	.2218
7	.1478	.1663	.1663	.1663	.1848	.1663	.2033
8	.1848	.1294	.1663	.1848	.2402	.1829	.2402
9	.1478	.1478	.1478	.1478	.2033	.1663	
10	.1663	.1478		.1478	.2033	.1663	
11	.1848	.1663	.1663	.1848	.1848	.1848	.2378
12	.1848	.1663	.1848	.1848	.2033		.2402
13	.2218	.1848	.2218	.2218	.2402	.2218	.2402
14	.2033	.2402	.2402	.2587	.2587	.2402	.2402
15	.2587	.2587	.2957	.2772	.2587	.2402	.2402
16	.2033	.2587	.2587	.2402	.2402	.2402	.2772
17	.1848	.2218	.2033	.2218	.2402	.2218	.2957
18	.2033	.1848	.1663	.1848	.2033	.2033	
19	.1848	.1663	.1848	.2218	.2402	.2033	.2218
20	.2218	.2033	.1848	.2033	.2033	.1848	.2402
21	.2218	.2033	.2402	.2033	.2218	.2033	.2218
22	.2587	.2402	.2772	.3142	.2772	.2957	.2957
23	.2772	.2957	.3142	.3142	.3326	.2772	.2957
24	.2587	.2957	.2957	.3142	.2957	.3142	.2957
Max	.2772	.2957	.3142	.3142	.3326	.3142	.2957
Min	.1478	.1294	.1478	.1478	.1848	.1663	.2033
Avg	.2064	.2087	.2210	.2187	.2348	.2226	.2489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 203 / 11 KV SHITALA MATA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5121	.5487	.5487	.6036	.5853	.5487
2	.4755	.4572	.5304	.5487	.5487	.5487	.5121
3	.439	.4207	.5121	.5121	.5121	.5121	.4755
4	.3841	.4207	.4755	.4572	.4755	.4572	.4572
5	.3658	.4207	.4207	.4207	.439	.439	.439
6	.3292	.4024	.3841	.3841	.4024	.3658	.3841
7	.2926	.4024	.3292	.3475		.3475	.3475
8	.3292	.3292	.3109	.3475	.4572	.3292	.3475
9	.3475	.3658	.3841	.4207	.4755	.3841	
10	.4207	.3841		.4755	.4755	.4572	
11	.4755	.4024	.5304	.5121	.5121	.5487	.6036
12	.5121	.4572	.567	.6036			.6219
13	.5853	.5304	.6219	.6401	.6584	.6401	.6401
14	.6401	.567	.6767	.6767		.6584	.695
15	.6219	.567	.7133	.7682	.7499	.695	.695
16		.6036		.695	.695	.7316	.7133
17	.6767	.5487	.7316	.4938	.6767	.6584	.695
18	.567	.439	.6219	.5304	.5304	.5853	
19	.6219	.5853	.6401	.6036	.5853	.6584	.7133
20	.5853	.5304	.6036	.5487	.6219	.6036	.6036
21	.5487	.4938	.567	.567	.6036	.567	.567
22	.5487	.4938	.567	.6219	.567	.5853	.5853
23	.5853	.6219	.6584	.6767	.6036	.6584	.5853
24	.5487	.5853	.5853	.5853	.6401	.6219	.6219
Max	.6767	.6219	.7316	.7682	.7499	.7316	.7133
Min	.2926	.3292	.3109	.3475	.4024	.3292	.3475
Avg	.4962	.4809	.5445	.5411	.5635	.5495	.5644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 207 / 11 KV INCOMMER

Feeder KV- 11 / INCOMING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9404	1.9035				2.1807	2.0328
2	1.8296	1.7372				2.0144	1.922
3	1.6632	1.6078				1.885	1.7926
4		1.5708				1.7556	1.7187
5	1.4415	1.5708				1.6632	1.6632
6	1.3676	1.46				1.5893	1.5524
7		1.386				1.423	1.4784
8	1.423	1.3121			1.6817	1.4969	1.5893
9	1.4784	1.386			1.6263	1.5708	
10	1.6817	1.4415			1.8665	1.7187	
11	1.46	1.6263			2.1622	2.1253	2.2916
12	2.1068	1.8296	2.5503	2.4209			2.347
13	1.2936	1.9774	2.6612	2.5688	2.4579	2.4579	2.1992
14	1.5708	2.1253	2.6242	2.1807	2.6427		2.5688
15	1.6448	2.1622	2.9569	2.846	2.809	2.6612	2.6612
16	1.9035	2.1807	2.0328	2.7536	2.809	2.7252	2.8645
17	2.5133	2.0883	2.7166	2.5133	2.6981	2.5318	2.7905
18	2.2731	1.885	2.4394	2.4209	2.3655		
19	2.4579	2.1253	2.6612	2.4579	2.5503	2.5318	2.5873
20	2.3655	2.2916	2.5318	2.4579	2.4579	2.5503	2.5873
21	2.2546	2.1992	2.347	2.3655	2.4394	2.347	2.2731
22	2.1068	1.989	2.2546	2.4394	2.2177	2.3285	2.2546
23	2.1437	2.2131	2.347	2.4579	2.3285	2.3285	2.3285
24	2.0328	2.1437	2.2218	2.2916	2.2916	2.2916	2.1992
Max	2.5133	2.2916	2.9569	2.846	2.809	2.7252	2.8645
Min	1.2936	1.3121	2.0328	2.1807	1.6263	1.423	1.4784
Avg	1.8615	1.8422	2.4881	2.4750	2.3378	2.1037	2.1763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024012 / KUTASA

Feeder No / Name : 201 / 11 KV KUTASA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2218	.2241	.2241	.2587	.2241	.2402
2	.1867	.2218	.2012	.2054	.2402	.2218	.2402
3	.1867	.2218	.1991	.2054	.2402	.2054	.2218
4	.1478	.2218	.1848	.1663	.2402	.1867	.2218
5	.1478	.2033	.1478	.1663	.2218	.1829	.2218
6	.1294	.1848	.124	.1307	.1848	.1867	.1663
7	.112	.1109	.1097	.112		.112	.1109
8	.0934	.0924	.0895	.0934	.1109	.0934	.0739
9	.0924	.0924	.0914	.0934	.0924	.0924	.0924
10	.0924	.0914	.112	.0924	.1097	.1109	.0924
11	.1109	.0905	.112	.1109	.1494	.1109	.0924
12	.1294	.0905	.1307	.1478	.1086	.1294	.1109
13	.1294		.168	.1663	.1417	.1478	.1294
14	.1848	.1829	.1867	.1663	.1463	.1848	.1663
15	.1848	.1772	.1867	.1848	.1578	.1848	.1848
16	.1663	.181	.168	.1663	.1829	.1663	.1663
17	.1294	.128	.168	.1478	.1478	.1294	.1294
18	.1109	.112	.112	.0924	.112	.0924	
19	.1478	.1772	.1494	.0924	.1646	.1848	.1663
20	.2033	.2427	.2054		.1867	.2033	.2033
21	.2218	.2614	.2241		.2054	.2218	.2218
22	.2218	.2561	.2427	.2587	.2241	.2402	.2402
23	.2218	.2587	.2427	.2772	.2378	.2402	.2402
24	.2427	.2218	.2427	.2427	.2587	.2427	.2402
Max	.2427	.2614	.2427	.2772	.2587	.2427	.2402
Min	.0924	.0905	.0895	.0924	.0924	.0924	.0739
Avg	.1591	.1758	.1676	.1610	.1792	.1706	.1727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024012 / KUTASA

Feeder No / Name : 202 / 11KV Dahihanda

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6535	.6348	.6161	.6348	.6161	.5788
2	.5601	.6348	.5853	.6161	.6161	.5914	.5788
3	.5601	.5975	.5792	.5788	.6161	.5853	.5975
4	.5228	.5975	.5544	.5729	.5975	.5788	.5788
5	.4854	.5601	1.1458	.5175	.5601	.5121	.5788
6	.4435	.5041	.443	.5228	.5041	.5041	.4854
7	.3734	.3361	.3841	.4108		.3292	.3174
8	.3361	.3547	.3582	.2987	.3547	.3361	.3174
9	.3361	.3547	.4024	.2987	.2587	.3142	.3174
10	.3547	.3841	.3361	.3921	.3658	.3734	.3547
11	.3734	.362	.4108	.4108	.4481	.3734	.3921
12	.3921	.4344	.4481	.4481	.3982	.4108	.4294
13	.3734	.4572	.5041	.4668	.4075	.4294	.4668
14	.4481	.4607	.4854	.4854	.4252		.4108
15	.5228	.4755	.4668		.4668		.5041
16	.4668	.4344	.4481	.4668		.5041	.4668
17	.3921	.4066	.4294	.3921	.462	.4294	.4066
18	.3361	.4481	.3547	.4108	.4481	.4108	
19	.5041	.6024	.5415	.6348	.5853	.5975	.5788
20	.6348	.6722	.6348		.7095	.5788	.7095
21	.6535	.7095	.6348	.7095	.6348	.6722	.7468
22	.6348	.7133	.7095	.7095	.6722	.6722	.7095
23	.6722	.6468	.6535	.6722	.6219	.6348	.6838
24	.6161	.6535	.6653	.6161	.6535	.6161	.4481
Max	.6722	.7133	1.1458	.7095	.7095	.6722	.7468
Min	.3361	.3361	.3361	.2987	.2587	.3142	.3174
Avg	.4829	.5189	.5338	.5112	.5200	.5032	.5069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 201 / 11 KV TAKLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3658	.3511	.3511	.3658		.3361
2	.3361	.3206	.3366	.3361	.3658	.3584	.3326
3	.3326	.3258	.2298	.3292	.3696		.3109
4	.3326	.3511	.3326	.3326		.3361	.3292
5	.3361	.2743	.3326	.3361	.3142	.3361	.3326
6	.2452	.2241	.2772	.2801	.2926	.2865	.2801
7	.181	.2054	.2012	.2033	.1829	.2279	.1829
8	.181	.1829	.181	.181	.1448	.181	.1646
9	.1663	.197	.1791	.1448	.1463	.1928	.1646
10	.2218	.1791	.1463	.1829	.156	.1663	.1612
11	.2353	.2743	.1829	.181	.1715		.1772
12	.2402	.1928	.2012	.2195		.197	
13	.2328		.1991	.2353	.2507	.2149	.2149
14	.2481	.2303	.2328	.2587	.2658	.2172	.208
15	.2658	.2279	.2378	.2378	.2804	.1991	.2058
16	.2507	.2303	.2378		.2103	.2012	.2172
17	.2378	.2126	.197	.2353	.156	.2172	.1595
18	.1791	.1772	.1772	.2033	.156	.1753	.1772
19	.3439	.3189	.2743	.2715	.3045	.3077	.2481
20	.3658	.4024	.3658		.394	.3326	.3224
21	.3658	.4066	.3547		.4024	.3511	.3658
22	.3761	.4066	.3584	.3582	.3475	.3734	.4163
23	.3582	.4066	.3734	.362	.3696	.3734	.4163
24	.3361	.3582	.3511	.3511	.3658	.3547	.3511
Max	.3761	.4066	.3734	.362	.4024	.3734	.4163
Min	.1663	.1772	.1463	.1448	.1448	.1663	.1595
Avg	.2792	.2813	.2630	.2662	.2733	.2667	.2641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 202 / 11 KV RAIL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.6401	.6767	.6697		.6722	.6722
2	.7023	.6283	.3658	.6653	.6468	.6602	.6653
3	.6979	.6283	.6468	.6401	.6401	.6535	.6468
4	.6908		.6535	.6535	.6335	.6535	.6348
5	.6908	.5601	.6535	.6653	.6584	.6348	.6099
6	.6348	.499	.5601	.6283	.5175	.543	.5415
7	.4668	.462	.4251	.439	.5304	.4075	.3734
8	.4066	.3841	.3696	.4024		.394	.3696
9	.4024	.2218	.3641	.3801	.3881	.3856	.4066
10	.2561	.3841	.3582	.3841	.4163	.3801	.3734
11		.3801	.3841	.4435	.4163	.3841	.2896
12	.4805		.4207		.4119	.4024	.4477
13	.4706	.2926	.4435	.439	.4382	.439	.4656
14	.5249	.3841	.4755	.5487	.4733	.4706	.4287
15	.5249	.4938	.4805	.5544	.5083	.4805	.4334
16	.4706	.4938	.4525	.5359	.4784	.439	.4706
17	.4344	.443	.4024	.4668	.4835	.3801	.4163
18	.4344		.394	.3881		.3856	.5121
19	.6154	.5792	.5853	.462	.5373	.6283	.5914
20	.695	.6697	.695		.6878	.7023	.7207
21	.3982	.695	.7762	.6283	.7468	.7023	.7682
22	.6335	.724	.7499	.695	.7282	.7282	.7421
23	.7316	.724	.7133	.7392	.6722	.7207	.724
24	.7282	.6335	.6767	.6767	.6099	.6908	.7023
Max	.7316	.724	.7762	.7392	.7468	.7282	.7682
Min	.2561	.2218	.3582	.3801	.3881	.3801	.2896
Avg	.5565	.5200	.5301	.5502	.5535	.5391	.5419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 203 / 11 KV CHOHATA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2507	.2957	.2829	.2715		.2987
2	.3018	.2534	.2772	.2587	.2772	.3206	.3018
3	.2987	.2561		.2452	.2743	.3018	.2772
4	.2772	.2353	.2743	.2427	.2715	.2987	.2772
5	.2801	.2353	.2743	.2957	.2957	.2987	.2926
6	.2587	.2263	.2658	.2587	.2743	.2804	.2427
7	.2328	.2054	.2427	.2427		.2103	.2614
8	.2402	.2172	.2303	.2402	.2195	.2204	.2402
9	.2587	.2218	.1907	.2378	.2743	.1989	.2743
10	.2686	.2402	.2743	.3018	.2629	.2374	.2686
11	.2715	.2534	.3109	.3045	.2572	.2715	.2572
12	.2743	.2481	.2686	.2587	.2713	.2957	.2713
13	.2743	.2481	.2926	.2195	.3142	.3077	.3086
14	.2629	.2896	.3077	.2951	.3109	.3142	.2774
15	.2629	.3109	.3109	.2715	.3109	.3109	.2804
16	.2715	.3142	.3439	.3142	.3077	.3045	.3224
17	.2896	.3012	.2772	.3077	.2774	.3077	.2835
18	.2534	.2601	.2865	.2353	.2743	.3045	.2896
19	.3292	.2835	.3142	.3326	.3189	.3511	.3109
20	.3224	.3142	.3326		.3292	.3547	.3361
21	.3045	.3109	.3326		.3292	.3361	.3361
22	.3012	.3292	.3174	.3142	.2926	.3206	.3326
23	.2835	.3077	.2829	.2957	.3174	.2801	.3142
24	.3018	.2715	.2957	.2801	.2896		.2987
Max	.3292	.3292	.3439	.3326	.3292	.3547	.3361
Min	.2328	.2054	.1907	.2195	.2195	.1989	.2402
Avg	.2801	.2660	.2869	.2743	.2879	.2921	.2897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 204 / 11 KV KELIVELI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3801	.4108	.3841	.3801	.3584	.3841
2	.3734	.3658	.3734	.3658	.3841		.3881
3	.3547	.3658	.3696	.362	.3841	.3361	.3658
4	.3696	.3511	.3547	.3475	.4298	.3361	.3734
5	.3772		.3174	.3734	.3658	.3142	.3658
6	.3206	.2772	.2614	.3174	.2926	.2987	.3361
7	.2263		.2587	.2378	.2896	.2402	.2402
8	.1848	.1991	.2481	.2172	.1991	.2229	.2195
9	.1646	.2172	.2686	.2195	.2195	.2543	.2561
10		.2378	.2561	.2587	.2328	.197	.2303
11	.2561	.2743	.2454	.2926	.2229	.2561	.208
12	.3109		.2686			.2172	.1886
13	.3077	.2926	.2865	.3109	.2835	.2743	.2378
14	.2865	.2835	.3292	.3258	.2896	.2926	.2561
15	.2835	.2715	.3475		.3109	.2957	.2561
16	.2507	.2534	.3511	.056	.2896	.2772	.2896
17	.2561	.2328	.2743	.0554	.2715	.2743	.2378
18	.1791	.3944	.2218	.2987	.2401	.2328	.2561
19	.2865	.3801	.3658	.3109	.3258	.3109	.2926
20	.362	.4108	.3881		.3734	.3921	.3696
21	.3982	.4108	.3921		.394	.3921	.3881
22	.394	.4298	.4108	.4207	.3982	.3881	.3801
23	.3982	.3982	.4066	.4024	.3475	.3921	.3841
24	.3772	.3189	.4108	.3841	.3841	.3547	.3841
Max	.3982	.4298	.4108	.4207	.4298	.3921	.3881
Min	.1646	.1991	.2218	.0554	.1991	.197	.1886
Avg	.3085	.3212	.3257	.2970	.3178	.3004	.3037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 201 / 11 KV UMARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3292	1.9204	1.9433	2.5606	2.5194	.3772
2	.2926	.3292	2.5606	1.9433	2.5606	.4572	.3772
3		.3292	2.5606	1.9433	2.524	.4572	.3772
4	.2926	.2926	2.5606	1.9433	2.4874	.4572	.3429
5	.2926	.2561	2.5606	1.9433	2.524	.4572	.3429
6		.2561	2.2672	1.9433	2.5606	.4572	.2743
7	.2195	.2561	2.6337	2.079	2.5606	.3658	.2743
8	.2561	.2195	2.5606	2.2672	2.5972	.2561	.2347
9	.2195	.1715	2.4874	2.332	2.524	.2195	.2058
10	2.5606	2.2291	.1829	.2195	.2743	2.332	2.2024
11	2.7435	2.0576	.1875	.2195		2.2672	2.4874
12	2.7435	2.2291	.25	.1829		2.1214	2.4874
13	2.7801	2.4177	.25	.2195	.3658	2.0729	2.4691
14	2.7801	2.572	.2591	.2195	.3292	2.1214	2.5057
15	2.7984	2.572	.2591	.2195	.3292	2.17	2.5606
16	2.6703	2.4691	.2591	.2378		2.2348	2.5606
17	2.524		.25	.2561	.2743	2.1538	2.5606
18	.3109	.3109	.2591	.2926	.2926		.2926
19	.4755	.439	.421	.2926	.3658	.4481	.439
20	.5487	.5487	.5144	.4938	.5304	.4854	.5304
21	.5853	.5487	.5144	.5487	.5853	.5601	.5853
22	.567	.5853	.5144	.5487	.6036	.6348	.5853
23	.567	.5487	.5144	.567	.6036	.6348	.5853
24	.3658	.3658	2.7801	1.9433	.5487	.5487	.4801
Max	2.7984	2.572	2.7801	2.332	2.5972	2.5194	2.5606
Min	.2195	.1715	.1829	.1829	.2743	.2195	.2058
Avg	1.2221	.9710	1.2303	1.0333	1.3334	1.1492	1.0891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 202 / 11 KV KASOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4024	1.4335	1.2071	1.134		.415
2	.415	.3841	1.4335	1.2071	1.134	.4338	.415
3	.3961	.3658	1.4335	1.1336	1.134	.4338	.415
4	.3961	.3292	1.4335	1.1336	1.1523	.4338	.3772
5	.3961	.2926	1.4335	1.1336	1.1706	.3658	.3018
6	.3395	.2195	1.4146	1.1984	1.7193	.3206	.3018
7	.1886	.1829	1.3392	1.1984	1.1706	.2075	.2263
8	.2075	.1646	1.4523	1.166	1.3352	.2075	.1886
9	.1715	.2012	1.4335	1.166	1.2437	.1886	.1886
10	1.5278	1.166	.1698	.1646	.2012	1.4754	1.1888
11	1.3717	1.2407	.1619	.2058		1.4754	1.4266
12	1.3535	1.406	.2105	.2195		1.4251	1.4449
13	1.3535		.2267	.2561	.3395	1.4251	1.4632
14	1.4632		.2267	.2926	.3772	1.3108	1.4632
15	1.39	1.4232	.2267	.3292	.3395	1.3108	1.5181
16	1.4632	1.406	.2267	.2926	.3206	1.278	1.4998
17	1.4998		.2267	.2561	.2829	1.2125	1.5181
18	.3292	.3395	.1943	.2378	.2452		.2012
19	.3292	.3395	.2915	.3292	.2641	.3206	.2561
20	.3658	.3772		.3658	.3772	.3772	.3658
21	.4207	.4338	.3772	.439	.4338	.3772	.4207
22	.4207	.4338	.3772	.439	.4904	.3772	.4207
23	.4207	.4338	.3772	.439	.4904	.3772	.4207
24	.3961	.4207	1.3957	1.1736	1.0974	.4338	.415
Max	1.5278	1.4232	1.4523	1.2071	1.7193	1.4754	1.5181
Min	.1715	.1646	.1619	.1646	.2012	.1886	.1886
Avg	.7096	.5696	.7607	.6660	.7479	.7167	.7022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 203 / 11 KV BORDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2211	2.2314	.3647	.3772	.3658		2.4249
2	2.1548	2.2314	.0076	.3734	.3292	2.5194	2.4249
3	2.1548	2.268	.3315	.3395	.3292	2.5194	2.7915
4	2.1548	2.3045	.3315	.3395	.2926		2.7915
5	2.1051	2.3045	.3292	.2915	.2561	1.4089	2.4291
6	2.2874	2.3411	.2321	.3018	.2195	2.6023	2.4291
7	2.4863	2.4874	.1492	.1886	.1829	2.5692	2.4615
8	2.5194	2.6337	.1492	.1886	.1463	2.5526	2.5911
9	2.4531	2.6337	.116	.1886	.0732	2.5194	2.7206
10		.1791	2.5194	3.0544	3.0178	.1494	.1867
11		.1991	2.8959	2.963		.1867	.2012
12		.1991	2.7435	2.9264		.2241	.2195
13		.2353	2.7435	2.7801	2.7349	.2241	.2378
14	.1829		2.8959	2.7435	2.6852	.2241	.2195
15	.1829	.2172	2.5911	2.6337		.2241	.2012
16	.1829	.2195	2.5911	2.6337	2.8675	.2241	.1829
17	.1829	.181	2.8959	2.8349	2.4863	.2241	.1829
18			.2172	3.0361	.1658		.1829
19	.2926	.2321	.3563	.1646	.2652	.1886	.2743
20	.3292	.2984	.415	.3109	.2984	.3772	.3292
21	.3658	.3149	.3772	.3292	.3481	.3772	.3841
22	.3658	.3149	.3772	.3658	.3315	.3772	.3658
23	.3475	.2984	.3772	.3658	.3315	.3772	.3292
24	2.2542	.2321	.2984	.3772	.3658	2.5194	2.5377
Max	2.5194	2.6337	2.8959	3.0544	3.0178	2.6023	2.7915
Min	.1829	.1791	.0076	.1646	.0732	.1494	.1829
Avg	1.3276	1.1162	1.0961	1.2545	.8616	1.0757	1.2125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 204 / 11 KV ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.9753	.3292	.3563	3.0361	1.4632	1.3279
2	1.7741	1.9753	.3658	.3563	2.9995	1.5546	1.3603
3	1.7741	1.9753	.3658	.3239	2.9995	1.5546	1.3603
4	.6344	2.0119	.3658	.3125	2.963	1.5546	1.4251
5	1.6461	2.0485	.3658	.3239	2.9264	1.5546	1.4575
6	1.6804	1.9753	.3475	.2591	2.8898	1.3717	1.3603
7	1.5604	1.9022	.2561	.1943	2.7801	1.4632	1.3603
8	1.5775	1.9387	.2561	.1619	2.9264	1.5729	1.3927
9	1.5604	1.7147	.2561	.1677	2.7435	1.6461	1.4251
10	.1715	.2353	2.2862	2.0119	1.7558	.1943	.1943
11	2.9264		1.749	2.0485		.1943	2.6886
12	2.963		1.6194	2.0119		.2267	2.6886
13	2.9995		1.6194	1.9204	1.5729	.1943	2.6703
14	2.9995		1.6194	1.829	1.6827	.2267	2.7069
15	2.9264	.2401	1.6194	1.6827	1.6095	.2267	2.7801
16	2.8532		1.6194	1.6827		.1943	2.7801
17	2.7069	.2058	1.6842	1.7193	1.6644	.1943	2.7801
18	.3109	.3109	.5792	.2926	.2743		.2926
19	.4938	.3658	.4344	.4207	.3292	.3772	.439
20	.5487	.4938	.4694	.4938	.4755	.4481	.5304
21	.5853	.4938	.4801	.5487	.5121	.4854	.5853
22	.567	.4938	.5144	.5487	.567	.5975	.5853
23	.567	.4755	.503	.567	.567	.5975	.5853
24	1.7193	1.9753	.3658	.3239	3.0361	1.4632	1.3413
Max	2.9995	2.0485	2.2862	2.0485	3.0361	1.6461	2.7801
Min	.1715	.2058	.2561	.1619	.2743	.1943	.1943
Avg	1.6383	1.2004	.8363	.8566	1.9196	.8416	1.5049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 201 / 11 KV PANAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.828	1.7703	2.6113	2.6063	2.6292	1.7528	1.8861
2	1.7703	1.7177	2.5434	2.5265	2.5941	1.7002	1.9547
3	1.7878	1.6476	2.5149	2.5206	2.5659	1.6476	1.9004
4	1.7337	1.4899	***	2.452	2.5312	1.5775	1.7918
5	1.6804	1.4548	2.5265	2.489	2.4966	1.56	1.7556
6	1.6461	1.5074	2.6113	2.4272	2.722	1.5249	1.6817
7	1.4575	1.5074	3.0013	2.9843	2.9504	1.4723	1.4784
8	1.2174	1.3496	3.086	3.1369	2.9835	1.1218	1.3756
9	1.2517	1.3321	3.0521	3.1379	2.9492	1.0867	1.3226
10	3.4294		1.2986	1.2689	1.3169	2.8045	3.2217
11		3.1276	1.2003	1.2986	1.2269	3.2579	3.2251
12	2.9797	2.9843	1.3032	1.39	1.4723	3.1708	3.0323
13	3.0323	2.9165	1.3546	1.4842	1.4723	2.8487	3.0498
14	2.9622	2.8656	1.3032	1.5565	1.3672	3.0178	2.9797
15	2.822		1.3203	1.5565	1.2094	2.9492	2.857
16	3.0323	3.155	1.5565	1.5565	1.4899	3.0007	3.0323
17	3.1725	2.9835	1.2986	1.3535	1.262	3.2236	3.1375
18	2.9622	1.2567	1.2803	1.4998	1.1744	1.1765	
19	1.7703	1.848	1.6832	1.7558	1.7703	1.6632	1.6827
20	1.858	1.922	1.8461	2.0328	1.8755	1.9909	1.7703
21	1.8755	2.0328	1.8004	1.9959		1.9959	1.8755
22	1.9105	2.1253	1.869	2.1253	2.9096	2.1253	2.0157
23	1.9105	2.0851	2.0485	2.0883	1.9982	1.9728	2.0157
24	1.8461	1.893	2.6993	2.6578	2.6292	1.9281	2.0271
Max	3.4294	3.155	25.1462	3.1379	2.9835	3.2579	3.2251
Min	1.2174	1.2567	1.2003	1.2689	1.1744	1.0867	1.3226
Avg	2.1711	2.0442	2.9565	2.0792	2.0694	2.1071	2.2204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 202 / 11 KV AKOLI J

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2483	1.1469	.9175	.9602	1.0322	1.1469	.9602
2	1.2003	1.3435	.9175	.9442	1.0159	1.1633	1.0402
3	1.1523		.9175	.9122	1.0159	1.1305	1.0883
4	1.1683	1.3927	.9503	.9442	1.0159	1.1633	1.1203
5	1.1683	1.4255	.9614	.9762	1.0159	1.1797	1.1043
6	1.1843	1.4746	.9339	.9602	.9339	1.1797	1.1363
7	1.5043	1.5074	6.603	.8002	.852	1.1961	1.1683
8	1.5524	1.6057	.6226	.6401	.639	1.4582	1.2003
9	1.5043	1.4091	.5735	.6081	.6718	1.4091	1.1523
10	.6562		1.5402	1.5203	1.5893	.6882	.6401
11	.6882	.6226	1.6164	1.7204	1.5729	.6562	.6718
12		.6226	1.5684	1.7368	1.5402	.6882	.7373
13		.6882	1.5203	1.6876	1.5402	.763	.6882
14		.759	1.4883	1.6385	1.5402	.7042	.7865
15	.8848	.7373	1.5043	1.6057	1.5729	.7682	.7865
16	.8356	.7373	1.4883	1.6549	1.5729	.7842	.7701
17	.5335	.7045	1.5524	1.6221	1.5893	.6882	
18	.5735	.8356	.5601	.7865	.5571	.7202	
19	.8848	.8848	.7842	.9012	.7537	.7522	.8356
20	.9831	1.0159	1.0562	1.0159	.9667	1.0402	1.0978
21	.9667	1.0159	1.0562	1.0159	1.1142	1.0562	1.1469
22	.945	1.0159	1.0722	1.0978	1.1142	1.0722	1.1142
23	.9995	.9995	1.0722	1.0212	1.0814	1.0402	1.0978
24	1.2163	1.0978	.9339	.9762	1.0322	1.1142	.9282
Max	1.5524	1.6057	6.603	1.7368	1.5893	1.4582	1.2003
Min	.5335	.6226	.5601	.6081	.5571	.6562	.6401
Avg	1.0405	1.0474	1.3421	1.1561	1.1387	.9818	.9669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 203 / 11 KV RUIKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.1219	2.0271	2.0424	1.8747	.2439	.2286
2	.2439	.1372	1.9814	2.0965	1.829	.2591	.2286
3	.2286	.1524	1.9814	2.0805	1.7528	.2743	.2439
4	.2134	.1219	1.9509	2.0119	1.7528	.2439	.2591
5	.2286	.1524	1.89	2.0576	1.7223	.2134	.2134
6	.1981	.1677		2.0576	1.829	.2591	.1981
7	.1981	.1677	2.1033	2.0576	1.829	.1677	.1677
8	.1677	.1829	2.1948	1.9357	2.0271	.1524	.1829
9	.1829	.1677	2.1948	2.1948	2.1948	.1372	.1524
10	2.3777		1.0822	.1219	.1372	2.3167	2.1795
11	2.3167	2.1338	.1357	.1524	.1524	2.4985	2.5453
12	2.2558	2.1795	.1524	.1677	.1372	2.363	2.5911
13	2.4234	2.1338	.1524	.1829	.1524	2.3624	2.5758
14	2.2253	2.0881	1.0669	.1966	.1524		2.332
15	2.21	2.1643	.1524	1.4091		1.9509	2.332
16	2.3472	2.2558	.1677	.1829	.1372	1.9662	2.3015
17	2.271	2.3266	.1677		.1372	2.0881	2.4691
18	.1219	.1524	.1219	.1829	.1219	.1219	
19	.2286	.2134	.1981	.2134	.1829	.2591	.1829
20	.2743	.2591	.2591	.2286	.2896	.2591	.2591
21	.2743	.2591	.2591	.2286	.2591	.2591	.2591
22	.2591	.2591	.2591	.2591	.2439	.2743	.2439
23	.2134	.2286	.2591	.2591	.1677	.2591	.2439
24	.2439	.1524	2.0271	2.0576	1.8747	.2743	.2286
Max	2.4234	2.3266	2.1948	2.1948	2.1948	2.4985	2.5911
Min	.1219	.1219	.1219	.1219	.1219	.1219	.1524
Avg	.9145	.7903	.9906	1.0599	.9112	.8349	.9834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 201 / 11 KV BORDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.6722	1.6004	1.5402	1.6385	.7095	.6722
2	.6653	.6722	1.6004	1.4685	1.6385	.695	.5975
3	.6653	.6722	1.6004	1.5402	1.6385	.7095	.5975
4	.6348	.6722	1.6004	1.4685	1.6385	.6722	.5975
5	.6348	.5975	1.6194	1.4864	1.6385	.6722	.5228
6	.6348	.5975	1.6194	1.5043	1.6385	.4481	.4481
7	.5281	.4481	1.5729	1.4175	1.4815	.4481	.4481
8	.3772	.3734	1.6194	1.5242	1.4998	.3734	.3734
9	.3547	.3734	1.5546	1.4815	1.5181	.3734	.3734
10	1.6129	1.6004	.3734	.3921	.5716	1.6964	1.5813
11	1.6712	1.6964	.4435	.4854		1.7604	1.6129
12	1.6385	1.6964	.4435	.4572		1.6975	1.6446
13	1.6004	1.6964	.4805	.5335	.3734	1.7604	1.5813
14		1.6004	.4854	.5975	.5975	1.7604	1.6004
15	1.6004	1.7284	.5228	.5975	.5601	1.4883	1.6762
16	1.6004	1.749	.5121	.5601	.5601	1.6324	1.6446
17	1.3763	1.7284	.4435	.5175	.5228	1.5741	1.5813
18	.4481	.4481	.3658	.4854	.4481		.3734
19	.5975	.5975	.5175	.5228	.5228	.5975	.5228
20	.5975	.6722	.5731	.5601	.5975	.6722	.6722
21	.5975	.6722	.6653	.6722	.6722	.7468	.7023
22	.7468	.6722	.7392	.6722	.6722	.7468	.7545
23	.7468	.6722	.7392	.7468	.6722	.6722	.7207
24	.6653	.6722	1.6004	1.5043	1.6385	.6722	.6173
Max	1.6712	1.749	1.6194	1.5402	1.6385	1.7604	1.6762
Min	.3547	.3734	.3658	.3921	.3734	.3734	.3734
Avg	.8980	.9575	.9705	.9473	1.0336	.9817	.9132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 202 / 11 KV RAMAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1524	2.5911	2.5606	2.3922	.1143	.1132
2	.1524		2.5911	2.4996	2.4249	.1143	.1143
3	.1509	.1524	2.5911		2.4249	.112	.1143
4	.112	.1524	2.5911	2.4996	2.4577	.1143	.1143
5	.112	.0762	2.5911	2.5606	2.4577	.1143	.0762
6	.1109	.0762	2.4006	2.1765	2.6216	.0762	.0572
7	.0732	.0572	2.4291	2.3167	2.4691	.0953	.0572
8	.0358	.0381	2.4291	2.4691	2.5301	.0572	.0572
9	.0509	.0381	2.4006	2.4691	2.5301	.0572	.0381
10	2.8502	2.5606	.0381	.0347	.0762	2.7206	2.878
11	2.753	2.5606	.0572	.0572		2.8166	2.9607
12	2.6216	2.5606	.0572	.0572		2.7496	3.0445
13	2.5606	2.5606	.0572	.0572	.0572	2.7206	3.0045
14		2.5606	.0762	.0572	.0572	2.753	3.0407
15	2.753	2.5911	.0762	.0762		2.2024	2.5301
16	2.7206	2.5911	.0572	.0747	.0572	2.834	2.6406
17	2.5606	2.5606	.0762	.0732	.0572	2.7496	2.6886
18	.0762	.0762	.0762	.0747	.0572		.0572
19	.1143	.1143	.0762	.0747	.0762	.1143	.0762
20	.1524	.1524	.1143	.1494	.1143	.1524	.1143
21	.1509	.1524	.1524	.1307	.1524	.1509	.1524
22	.1524	.1524	.1509	.1524	.1905	.1524	.1509
23	.1524	.1524	.1524	.1494	.1524	.1524	.1494
24	.1524	.1524	2.5911	2.5301	2.3922	.1524	.1143
Max	2.8502	2.5911	2.5911	2.5606	2.6216	2.834	3.0445
Min	.0358	.0381	.0381	.0347	.0572	.0572	.0381
Avg	.9009	.9670	1.1010	1.0131	1.2261	1.0120	1.0144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 203 / 11 KV POPATKHED

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4539	2.2291	1.0288	1.2003	1.2136	2.2291	2.1948
2	2.4006	2.2291	1.0288	1.2269	1.2003	2.2291	2.1948
3	2.4539	2.2291	1.0288	1.2269	1.2269	2.2291	2.1948
4	2.4806	2.2291	1.0288	1.1789	1.2269	2.2291	2.1948
5	2.1948	2.2291	1.0288	1.0402	1.2269	2.2291	2.2192
6	1.9765	2.2291	.8573	1.0387	1.0517	2.4006	2.0805
7	2.0458	2.0576	.8413	.8916	.8764	2.4006	2.0576
8	2.1152	2.0576	.7888	1.1218	.9465	2.2634	2.4272
9	1.8861	2.0576	.6859	1.0631	1.0517	2.2634	2.4006
10	.8916	.8573	1.8861	2.332	2.0805	.9602	.9816
11	.8916	.7888	.5548	2.0576		.8573	.535
12	.8573	.7888	2.2192	2.2291		.8573	.9114
13	.9259	.8573	2.1845	2.2539	2.0576	.8573	.9362
14		.8573	2.1498	2.4006	2.4006	.8573	.9431
15	1.0288	.8063	2.0805	2.4272	2.4348	.8059	1.2136
16		.8063	2.0805	2.4619	2.4348	.823	1.1269
17	.823	.7888	2.0805	2.0805	2.4006	.8402	1.0402
18	.9259		.852	1.0517	.7888		1.1145
19	1.0288		1.166	1.6804	.9602	1.0631	1.166
20	1.0974	1.0288		1.7177	1.0288	1.0631	1.2136
21	1.0974	1.0974	1.2536	1.7147	1.2003	1.0631	1.3003
22	1.2003	1.0288	1.3146	1.7147	1.2003	1.0631	1.4022
23	1.8861	1.0288	1.3717	1.1694	1.2003	1.0631	2.7435
24	2.4539	2.2291	1.0288	1.2757	1.2403	2.2291	2.1948
Max	2.4806	2.2291	2.2192	2.4619	2.4348	2.4006	2.7435
Min	.823	.7888	.5548	.8916	.7888	.8059	.535
Avg	1.5962	1.4778	1.3278	1.6065	1.4295	1.5164	1.6161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 204 / 11 KV MOHADA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.915	2.7435				3.1786	3.1131
2	2.9797	2.7435				3.0308	3.1131
3	2.9473	2.7435					3.1131
4	2.915	2.7435				3.1786	3.1131
5	2.9797	2.7435				3.1131	3.0769
6	2.8086	2.7435				3.1131	3.0769
7	3.0178	2.915				2.9683	3.0769
8	3.2579	2.915				3.2495	3.1131
9	3.1722	2.7778					3.0769
10			3.0933	3.3436	3.5021		
11			3.4328	3.4294			
12			3.5542	3.4808			
13			3.4675	3.5542	3.1245		
14			3.3808	3.6408	3.1245		
15			3.2941	3.7449	3.2808		
16			3.3436	3.751	3.2808		
17			3.2579	3.6755	3.2808		
24	2.915	2.6825				3.1786	3.1131
Max	3.2579	2.915	3.5542	3.751	3.5021	3.2495	3.1131
Min	2.8086	2.6825	3.0933	3.3436	3.1245	2.9683	3.0769
Avg	2.9908	2.7751	3.3530	3.5775	3.2656	3.1263	3.0986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 205 / water supply express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0366	.0366
2						.0381	.0366
3					.0187		.0366
4						.0381	.0362
5						.0366	.0351
6						.0366	.0351
7					.0187	.0366	
8					.0187	.0183	.0181
9					.0373		
10			.0185	.0191	.0187	.0187	.0732
11			.0191	.0187		.0366	.0543
12	.0358		.0191	.0187		.0335	.0343
13			.0191	.0183	.0171	.0183	.0366
14			.0191	.0183	.0183	.0185	.0373
15	.0351	.0181	.0191	.0187	.0183	.0183	.0762
16	.0358	.0181		.0187	.0183	.0183	.0762
17	.0358	.0181		.0187	.0183	.0183	.0762
18	.0351	.0181		.0187	.0183		.0914
19			.0191		.0362	.0191	.0347
20		.0181			.0366	.0187	
21					.0366	.0554	
22					.0362	.0366	
23					.0366	.0351	
24					.0187	.0366	.0366
Max	.0358	.0181	.0191	.0191	.0373	.0554	.0914
Min	.0351	.0181	.0185	.0183	.0171	.0183	.0181
Avg	.0355	.0181	.0190	.0187	.0248	.0297	.0479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 201 / 11 KV RUIKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4854	2.3365	2.1125	2.2672	.4854	.4656
2	.4298	.4904	2.3365	2.1125	2.2405	.4854	.4656
3	.4298	.4481	2.2725	2.1125	2.2405	.4904	.3224
4	.4298	.4527	2.2405	2.1125	2.2725	.4904	.3224
5	.2865	.4481	2.2085	2.0485	2.3644	.4481	.3224
6	.2865	.4481	2.1445	2.0485	2.3365	.4108	.3224
7	.2561	.3734	2.2405	2.0485	2.3685	.3395	.3224
8		.2614	2.2725	2.0165	2.372	.2263	.2507
9	.2865	.2614	.2507	2.0165	2.3087	.2263	.2507
10	2.4646	2.4939	.2507	.2241	.2614	2.5911	2.2725
11	2.4326	2.5606	.2241	.2507	.2614	2.5606	2.7846
12	2.5911	2.4006	.2507	.2507	.2957	2.5606	2.5926
13	2.5606	2.5301	.3224	.2561	.3361	2.5606	2.5286
14	2.5587	2.4646	.3224	.2865	.3734	2.2405	2.3967
15	2.5911	2.5301	.2507	.2865	.3734	2.2405	2.4966
16	2.6406	2.5617	.2507	.3224	.3326	2.2405	2.5926
17	2.6406	2.3685	.2241	.3224	.2587	2.2405	2.6882
18	.2241	.2241	.3224	.3224	.1867	.2241	.3018
19	.3018	.3772	.3224	.2865	.3361	.3224	.3734
20	.4527	.4527	.4298	.2865	.4854	.3224	.5281
21	.4904	.5281	.4298	.4656	.4854	.5014	.5281
22	.4904	.5228	.4298	.4656	.5228	.5014	.5281
23	.4904	.4904	.4298	.4656	.5228	.4656	.5228
24	.3841	.4904	2.3685	2.1125	2.2405	.4854	.4656
Max	2.6406	2.5617	2.3685	2.1125	2.372	2.5911	2.7846
Min	.2241	.2241	.2241	.2241	.1867	.2241	.2507
Avg	1.1369	1.1110	1.0471	1.0514	1.1685	1.0692	1.1102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281] BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 202 / KHIRKUND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17
HR	Load (MW)
6	.197
24	.2507
Max	.2507
Min	.197
Avg	.2239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 203 / 11 KV VASTAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	2.0405	.4298	.394	.4024	2.2085	2.2725
2	2.2405	1.9845	.4298	.394	.3982	2.2085	2.2725
3	2.2405	1.9845	.3582	.394	.4024	2.1765	2.2725
4	2.7526	1.9524	.3582	.394	.3658	2.2348	2.2725
5	2.7526	1.9524	.3224	.3224	.2896	2.2725	2.6505
6	2.7526	1.7604	.3224	.3224	.2926	2.3685	2.3685
7	2.7526		.2507	.3224	.2926	2.3365	2.3685
8			.2507	.2507	.2534	2.5606	2.4646
9	2.7526		2.1849	.2241	.2534	2.4006	2.4646
10	.2507	.3361	2.6246	2.2405	2.4669	.2561	.2195
11	.2587		2.7526	2.8807	2.4966	.1791	.2534
12	.2561	.2896	2.7526	2.8807	2.3482		.2534
13	.2926	.2926	2.5926	2.8807	2.2672		.2561
14	.2957	.2534	2.5926	2.8807	2.2405		.2561
15	.2926		2.5926	2.5606	2.2405		.2534
16	.2957		2.4326	2.5606	2.2405		.2561
17	.2926		2.4326	2.5606	2.2348		.2926
18	.3292		.4298	.394	.3326		.3292
19	.4854		.4298	.394	.4854	.3224	.4706
20	.5228	2.1125	.4298	.394	.5544	.3224	.5487
21	.5144	2.4508	.5373	.5014	.5544	.5014	.5487
22	.5601	2.2211	.394	.4481	.5175	.5014	.5121
23	.5228	.426	.394	.5014	.4805		.4755
24	2.2405	2.0729	.4298	.394	.394	2.2348	2.2725
Max	2.7526	2.4508	2.7526	2.8807	2.4966	2.5606	2.6505
Min	.2507	.2534	.2507	.2241	.2534	.1791	.2195
Avg	1.2128	1.4753	1.1969	1.1454	1.0335	1.5678	1.1919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024034 / 33 kv SAWARA

Feeder No / Name : 201 / 201 -11 kv sawara gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.1603	1.2643	1.0974	1.0911	1.5257	1.166
2	1.2483	1.1469	1.2334	1.0997	1.0595	1.4918	1.166
3	1.2334	1.1797	1.1574	1.086	1.0155	1.4575	1.1227
4	1.0936	1.2003	1.001	1.0433	1.0311	1.1279	1.0974
5	1.0669	1.1248	1.1584	1.0425	.9511	1.0151	1.0002
6	.7773	1.0669	.8792	.9469	.8402	.9875	.8002
7	.7659	.7868	.6043	.7602		.8792	.7276
8	.6996	.6828	.5462	.7644		.6741	.5234
9	.6737		.5811	.6996	.6299	.6624	.5999
10	.7202	.6624	.6043	6.5484	.6744	.616	.6413
11	.6668	.6392	.6192	.7169	.7059	.5857	.6382
12	.8032	.6508	.6893	.5845		.5538	.6765
13	.7796	.8251	.7787	.7082		.5857	.7148
14	.8032	.8792	.8048	.6733	1.142		.6866
15	.7914	.7796	.8173	.7625	1.0957	.6409	.5958
16	.7659	.7659	.7194	.7148	1.0802	.5746	
17	.7735	.616	.6851	.7554	.8792	.5811	
18	.5449	.6687	.5462	.6407	.6741	.5053	.467
19	.7305	.8928	.8413	.9164	1.0957	.7202	
20	1.1105	1.5257	1.1831		1.701	.9859	
21	1.1401	1.6118	1.2003	.7868		1.1904	
22	1.153	1.6476	1.2003	1.1389	1.543		
23	1.1869	1.543	1.1437	.9779	1.6297		
24	1.3108	1.153	1.2191	1.0669	.9779	1.5257	1.1768
Max	1.3108	1.6476	1.2643	6.5484	1.701	1.5257	1.1768
Min	.5449	.616	.5462	.5845	.6299	.5053	.467
Avg	.9216	1.0091	.8949	1.1101	1.0430	.8994	.8118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024034 / 33 kv SAWARA

Feeder No / Name : 202 / 11 kv sawara ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.2291	1.491	1.2597	1.1126		
2	2.1719	2.2291	1.3117	1.278	1.1126		
3	2.1719	2.2291	1.2963	1.3108	1.0837		
4	2.1719	2.2291	1.4737	1.2323	1.0837		
5	2.1719	2.2291	1.491	1.1561	1.0957		
6	2.1719	2.2291	1.6832	1.1069	1.1227		
7	2.1719	2.2291	1.6817	1.2696	1.4803		
8	2.1719	2.1719	1.9163	1.3474	1.454		
9	2.1719		1.6975	1.3658	1.4464		
10	1.4489	1.5912		2.0386		1.8378	1.2176
11	1.5592	1.9765	2.0957			1.448	1.1405
12	.7468	1.6667	2.0957			1.4624	1.0837
13	1.4464	1.3933	2.0957			.643	1.0856
14	1.4403	1.4098	2.0957			.9991	1.0848
15	1.4239	1.4744	2.0957			1.0574	1.0997
16	1.5432	1.4609	2.0957			1.0425	1.1138
17	2.2291	1.6512	2.0957			1.0574	1.07
18	2.2291		2.0957				
19	2.2291		2.0957				
20	2.2291		2.0957				
21	2.2291		2.0957				
22	2.2291		2.0957				
23	2.2291		2.0957				
24	2.1719	2.2291	1.5083	1.2742	1.3176		
Max	2.2291	2.2291	2.0957	2.0386	1.4803	1.8378	1.2176
Min	.7468	1.3933	1.2963	1.1069	1.0837	.643	1.07
Avg	1.9555	1.9193	1.8606	1.3309	1.2309	1.1935	1.1120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 201 / Pimpri(kh)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3649	.3889	2.3205	2.1392	2.2434	.3584	.3513
2	.3513	.3953	2.3205	2.1449	2.2332	.3395	.3237
3	.3639	.3734	2.3205	2.1449	2.1824	.3395	.32
4	.3275	.3753	2.2725	2.135	2.0405	.3395	.2853
5	.3012	.3395	2.2672	2.0607	1.8904	.2641	.2475
6	.2521	.263	2.2405	2.1708	1.9113	.2263	.2202
7	.1856	.1512	2.1125	2.3179	2.2276	.1886	.1839
8	.1757	.1517	2.2405	2.1401	2.1752	.1509	.1453
9		.1509	2.0551	2.1156	2.3087	.1405	.1494
10	2.1536		.139	.2263	.1886	2.5401	2.2462
11	2.2944			.2268		2.6063	2.2445
12	2.1714		.1287	.2277		1.8564	2.3182
13	2.1948		.2459	.2457	.2829	1.925	2.3063
14	2.2241	2.6246	.2942	.2402	.3395	2.1143	2.2234
15	.2425	2.4036	.274	.2662	.3395	2.2309	2.1674
16	.2258	2.372	.2811	.3024	.3018	2.2752	
17	2.1862	2.4006	.2085	.2254	.2641	2.2579	
18	.1896	2.3087	.139	.2282	.1886		
19	.3036	.3772	.3128	.2957	.415	.2963	.3776
20	.3803	.4527	.3475	.3761	.4527	.3601	.378
21	.415	.4527	.3869	.4183	.4527	.444	.4175
22	.4495	.4527	.4243	.4518	.4527	.4307	.4554
23	.4137	.4527	.4211	.415	.4527	.4003	.4108
24		.4066	2.2238		2.2944	.3957	
Max	2.2944	2.6246	2.3205	2.3179	2.3087	2.6063	2.3182
Min	.1757	.1509	.1287	.2254	.1886	.1405	.1453
Avg	.8258	.8647	1.1294	1.0224	1.1654	.9774	.8886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 202 / Shahapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2389	.1886	.139	.1708	1.531	1.7668
2		1.2583	.1698	.141	.1698	1.5466	1.7374
3		1.3066	.1698	.123	.1701	1.5623	1.787
4	1.5777	1.3392	.1698	.1451	.1701	1.5623	1.8086
5	1.5661	1.3546	.1509	.1451	.1663	1.5623	1.7384
6	1.528	1.3379	.1509	.1054	.1314	1.5466	1.77
7	1.5644	1.4148	.132	.0879	.1133	1.531	1.6576
8	1.6941	1.3311	.1132	.0711	.0755	1.5699	1.5993
9		1.4403	.0753	.0758	.0754	1.5553	1.3749
10	.0761	.0566	1.4823	1.4226	1.5655	.0725	.0754
11	.0758	.056	1.4972	1.507		.0718	.0758
12	.0566	.0566	1.5191	1.4452		.0732	.0759
13	.0758	.0566	1.5179	1.46	1.5813	.072	.0948
14		.0566	1.6188	1.4787	1.5813	.0693	.0943
15	.0944		1.4614	1.4601	1.5497	.0695	.0945
16	.0943	.0566		1.4712	1.5813	.0705	.0948
17	.0944	.0754		1.475	1.5741	.0703	
18	.0944	.0754	1.6044	.1478	.0943		
19	.1518	.132	.1221	.1882	.1886	.1439	.1494
20	.1896	.1886	.1392	.1877	.1886	.1581	.1901
21	.1894	.1886	.1758	.1879	.1886	.1819	.1869
22	.188	.1886	.1762	.1877	.1698	.1564	.1879
23	.1882	.1886	.1738	.188	.1698	.1619	.1869
24		1.2264	.1638		.1901	1.9532	
Max	1.6941	1.4403	1.6188	1.507	1.5813	1.9532	1.8086
Min	.0566	.056	.0753	.0711	.0754	.0693	.0754
Avg	.5277	.6358	.5897	.6018	.5394	.7518	.7975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 203 / Shivpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6432	.5792				.68	.7022
2	.6754	.5982				.68	.7124
3	.6578	.599				.6642	.6805
4	.7167	.6321				.6642	.6465
5	.7075	.6209				.6642	.6145
6	.759	.6398				.6483	.559
7	.7493	.6584				.6325	.6118
8	.7361	.6622				.6405	.8077
9		.6958				.6851	.6853
10			.7819	.685	.7274		
11			.7236	.6257			
12			.6516	.7179			
13			.7536	.7142	.6958		
14			.5629	.7133	.6249		
15			.5348	.7179	.5937		
16			.5632	.6704	.6173		
17			.5638	.6533	.6327		
24		.5807				.6508	
Max	.759	.6958	.7819	.7179	.7274	.6851	.8077
Min	.6432	.5792	.5348	.6257	.5937	.6325	.559
Avg	.7056	.6266	.6419	.6872	.6486	.6610	.6689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 201 / M.I.D.C Lohari road
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.192	.1707	.1787	.208	.2229	.1738
2	.2294	.1947	.176	.1814	.1974	.2254	.1806
3	.2294	.1894	.176	.1659	.1882	.2254	.1829
4	.2294	.1974	.176	.1659	.1957	.2058	.1829
5	.2294	.192	.176	.184	.1806	.2035	.1852
6	.176	.1867	.1684	.1814	.1806	.192	.176
7	.1669	.1947	.1734	.1734	.1646	.1619	.1555
8	.1417	.1313	.16	.1894	.1833	.1562	.1425
9	.2629	.1907	.208	.2486	.2926	.2835	.2427
10	.3292	.2572	.2315	.3366	.3361	.3294	.2481
11	.2926	.2683	.2347	.3292	.3361	.3475	.3142
12	.3109	.2515	.2572	.3292	.3361	.3511	.3174
13	.3142	.2629	.2896	.3292	.3361	.3547	.3326
14	.2915	.2629	.3142	.3224	.3475	.3734	.3109
15	.2713	.2507	.2715	.3258	.3403	.3584	.3109
16	.2865	.2107	.2743	.3439	.3921	.3584	.2896
17	.298	.2214	.2601	.3475	.3761	.3511	
18	.3258	.2743	.2601	.3511	.4108	.3395	
19	.3224	.3077	.2401	.3366	.3841	.3142	.3206
20	.3961	.2743	.2229	.3547	.4066	.3142	.2987
21	.2774	.2572	.144	.3018	.2896	.2401	.1867
22	.2054	.2187	.1882	.2439	.208	.192	.1848
23	.1974	.1833	.1882	.1907	.1966	.1738	.1829
24	.2241	.2027	.1707	.1814	.1974	.208	.1738
Max	.3961	.3077	.3142	.3547	.4108	.3734	.3326
Min	.1417	.1313	.144	.1659	.1646	.1562	.1425
Avg	.2598	.2239	.2138	.2622	.2785	.2701	.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 202 / Hiwarkhed Road industry

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4022	2.9807	2.0981	1.145	2.4745	2.1951	2.7762
2	1.4236	2.9097	2.0699	1.1472	2.4592	1.9946	2.7141
3	1.4649	2.8898	2.1369	1.1244	2.4859	1.9418	2.778
4	1.4785	2.8977	2.1064	1.1332	2.5396	1.9163	2.6916
5	1.477	2.8555	2.0927	1.1218	2.4467	1.9479	2.6223
6	1.4441	2.8243	2.1136	1.1012	2.4067	1.8755	2.3413
7	1.4464	2.4067	1.9294	1.0486	2.0721	1.9475	2.1531
8	1.4339	2.0868	1.5824	1.0494	2.0957	1.5539	2.0062
9	1.7993	2.1064	1.1774	1.2304	1.9266	1.8275	1.4883
10	2.4699	2.1217	1.0563	1.5249	2.0957	1.8836	1.4529
11	2.5263	2.0812	.8741	1.749	1.0669	1.9063	1.4773
12	2.2413	2.0591	.8345	1.789	.2134	1.7764	1.5002
13	2.2223	1.9845	.7935	1.829	.9838	1.6728	1.4612
14	2.0797	1.8522	.8604	1.7859	1.557	1.6335	1.4217
15	2.0828	1.8579	.8187	1.6651	1.616	1.526	1.4072
16	2.229	1.9472	.8512	1.7483	1.6816	1.5168	1.4721
17	2.3632	1.8359	.8115	1.7703	1.8857	1.6903	.8223
18	2.3487	1.5813	.8261	1.605	1.8949	1.4843	.8154
19	1.9181	1.2354	.7415	1.5836	1.6896	1.312	1.3893
20	2.2299	1.5558	.7735	1.7901	1.5412	1.813	1.7293
21	2.9178	2.0447	.7927	2.2752	1.8488	2.1691	1.9357
22	3.0128	2.1635	1.1043	2.6471	2.2165	2.5515	2.1437
23	2.95	2.1505	1.1561	2.7107	2.4292	2.8449	2.3076
24	2.1774	2.5284	1.7033	1.8469	2.4551	2.5739	2.5191
Max	3.0128	2.9807	2.1369	2.7107	2.5396	2.8449	2.778
Min	1.4022	1.2354	.7415	1.0486	.2134	1.312	.8154
Avg	2.0475	2.2065	1.3044	1.6009	1.9201	1.8981	1.8928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 203 / 11KV Water supply
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.1867	.1867	.1734	.1886	.1772	.1772
2	.2286	.2075	.1867	.1715	.1907	.1753	.1772
3	.2096	.2075	.1867	.1715	.1928	.1772	.1772
4	.1905	.2054	.1867	.1734	.1928	.197	.1791
5	.1905	.2075	.1867	.1886	.1928	.1949	.1791
6	.1715	.1867	.1867	.1886	.1928	.197	.1772
7	.2667	.1867	.1886	.2195	.1905	.1928	.2012
8	.2667	.1905	.1886	.2172	.2801	.2772	.2012
9	.2858	.2858	.2858	.2218	.2987	.2772	.2172
10	.3018	.3048	.2858	.2452	.2987	.3206	.2452
11	.3395	.3239	.2667	.2477	.3395	.3395	.3429
12	.3395	.3239	.2641	.2477	.3395	.362	.2263
13	.3206	.3429	.2641	.3429	.3395	.3395	.2452
14	.3174	.3429	.2012	.3429	.3395	.2829	.2641
15	.3018	.3048	.2195	.3048	.3239	.2987	.2614
16	.3584	.3239	.2054	.2858	.362	.2452	.3018
17	.2477	.3048	.2241	.2641	.3429	.2378	
18	.2477	.2286	.2195	.2858	.2452	.2667	
19	.2477	.2477	.2172	.2858	.3395	.3429	.3206
20	.2286	.2507	.2218	.2353	.2427	.3174	.2427
21	.2263	.2149	.1886	.2149	.2103	.2058	.1829
22	.1848	.2075	.1734	.2103	.1907	.1907	.1829
23	.2075	.1886	.1772	.1907	.1928	.1772	.1829
24	.2075	.1867	.1886	.1734	.1907	.1753	.1791
Max	.3584	.3429	.2858	.3429	.362	.362	.3429
Min	.1715	.1867	.1734	.1715	.1886	.1753	.1772
Avg	.2539	.2484	.2125	.2335	.2591	.2487	.2211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 204 / 11KV Wadali-S

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.439	.4024	.4572	.439	.4572	.4572
2	.439	.439	.4024	.439	.4207	.4572	.4572
3	.439	.4207	.4024	.439	.4207	.439	.439
4	.439	.4024	.4024	.4024	.4024	.439	.439
5	.439	.4207	.4024	.4207	.439	.439	.4207
6	.4024	.4207	.4024	.439	.439	.4207	.4024
7	.3109	.3658	.3658	.3292		.2561	.3292
8	.2926	.2926	.2561	.2926	.3292	.2561	.2926
9	.3109	.2926	.3292	.2561	.3292	.2743	.2743
10	.3292	.2926	.2926	.2195	.2926	.2561	.2743
11	.2561	.2926	.2743	.2195	.3109	.2561	.2743
12	.2926	.2743	.3109	.2561		.2561	.2743
13	.3109	.3109	.3292	.3292			.2926
14	.3292	.3292	.3475	.2926	.3292	.0732	.3109
15	.3475	.3292	.3292	.3292	.3658	.0732	.3292
16	.3292	.3109	.3292	.3292	.3292	.0732	.3109
17	.2743	.2926	.2926	.2561	.2743	.0732	
18	.2561	.2926	.2743	.2743	.2561	.3109	
19	.3658	.3658	.3475	.3841	.3658	.4024	.3841
20	.439	.4572	.4755		.439	.4755	.439
21	.4572	.4024	.4755			.4755	.4207
22	.4755	.439	.4755	.5121	.4938	.4938	.439
23	.4755	.4755	.4755	.5304	.5121	.4938	.439
24	.439	.4572	.4207	.4572	.4572	.4755	.4572
Max	.4755	.4755	.4755	.5304	.5121	.4938	.4572
Min	.2561	.2743	.2561	.2195	.2561	.0732	.2743
Avg	.3704	.3673	.3673	.3575	.3823	.3316	.3708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 205 / 11KV Mundgoan AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4489	.4458				.1265	.4923
2	.4344	.4254				.1235	.4988
3	.4401	.4161				.1265	.5053
4	.443	.4108				.1235	.4841
5	.4371	.4401				.1235	.4904
6	.5502	.4755				.1581	.543
7	.6836	.6539				.1581	.6895
8	.7926	.7133				.2031	.6516
9	.7011	.7621				.6249	.743
10			.7274	.7133	.6401		
11			.7186	.7316	.6874		
12			.6859	.7011	.6241		
13			.6539	.7407	.6097		
14			.6097	.7716	.5418		
15			.5944	.6401	.5335		
16			.6321	.5487			
17			.6321	.5944	.1852		
24	.4694	.4458				.128	.5135
Max	.7926	.7621	.7274	.7716	.6874	.6249	.743
Min	.4344	.4108	.5944	.5487	.1852	.1235	.4841
Avg	.5400	.5189	.6568	.6802	.5460	.1896	.5612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281] BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 201 / 11 KV POPATKHED

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		2.8837				
13	3.0312		2.8018		2.6052	2.8509
14				2.343		
Max	3.0312	2.8837	2.8018	2.343	2.6052	2.8509
Min	3.0312	2.8837	2.8018	2.343	2.6052	2.8509
Avg	3.0312	2.8837	2.8018	2.343	2.6052	2.8509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 202 / 11 KV SAWARA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		3.2322				
13	3.1131		2.9835		1.6907	2.769
14				3.1161		
Max	3.1131	3.2322	2.9835	3.1161	1.6907	2.769
Min	3.1131	3.2322	2.9835	3.1161	1.6907	2.769
Avg	3.1131	3.2322	2.9835	3.1161	1.6907	2.769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 203 / 11 KV AKOT-I

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6216	2.713	2.6825	2.652	2.7664	2.7587	2.7282
2	2.4996	2.6063	2.5453	2.5911	2.6825	2.6673	2.6139
3	2.431	2.492	2.431	2.4996	2.5072	2.5377	2.5072
4	2.3396	2.4234	2.332	2.3091	2.4082	2.4234	2.4006
5	2.2024	2.3472	2.2786	2.2177	2.3396	2.3167	2.332
6	2.1491	2.2862	2.2024	2.2024	2.2405	2.2329	2.2329
7	2.1033	2.1795	2.1719	2.2405	2.1491	2.2329	2.1262
8	1.9814	2.1186	2.21	2.1948	2.1262	2.2558	2.1186
9	1.9357	2.0195	2.1491	2.05	2.1338	2.1567	2.0576
10	1.9585	2.111	2.1262	2.111	2.1719	2.1872	2.1414
11	2.1567	2.1643	2.3624	2.4006	2.4387	2.2558	2.2862
12	2.4768	2.2939	4.8085	2.492	2.5682	2.332	2.4615
13	5.0599	2.4158	2.5758	4.4576	2.6063	2.2862	5.1915
14	2.6368	2.4844	2.652	2.492	5.5146	2.4615	2.7054
15	2.7206	2.553	2.7282	2.7587	2.8959	2.553	2.7587
16	2.8349	2.5987	2.7892	2.9035	2.9492	2.652	2.8045
17	2.8045	2.553	2.5987	2.713	2.8883	2.5987	2.7054
18	2.6597	2.5453	2.5225	2.6597	2.6978	4.6979	2.5606
19	2.4768	2.4539	2.4234	2.5835	2.5911	2.4006	2.4768
20	2.8959	2.8121	2.7054	2.8426	2.8883	2.6597	2.7892
21	2.8349	2.7968	2.6673	2.8273	2.8578	2.7664	2.7587
22	2.8349	2.7282	2.7206	2.8502	2.8121	2.7206	2.7816
23	2.713	2.6825	2.652	2.873	2.7892	2.7206	2.7587
24	2.7511	2.7435	2.6901	2.8121	2.8045	2.774	2.8349
Max	5.0599	2.8121	4.8085	4.4576	5.5146	4.6979	5.1915
Min	1.9357	2.0195	2.1262	2.05	2.1262	2.1567	2.0576
Avg	2.5866	2.4634	2.5844	2.6139	2.7011	2.5687	2.6305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 204 / 11 KV AKOT -II

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3134	4.3591	4.481	4.5115	4.4505	4.5953	4.6792
2	4.0771	4.1991	4.2448	4.2753	4.2676	4.3591	4.4429
3	3.9781	4.0924	4.1229	4.1686	4.1762	4.2219	4.2905
4	3.9018	4.0085	4.0543	4.1	4.1	4.0924	4.1838
5	3.8637	3.9476	4.0009	4.0162	4.0314	3.9704	4.0847
6	3.8485	3.9704	4.039	4.0695	4.0543	3.94	4.0543
7	3.9095	3.94	4.0847	4.1152	4.0466	3.9476	4.0085
8	3.8637	3.9552	4.039	4.1076	4.1991	3.8866	3.9781
9	3.7494	3.879	3.8333	3.9247	4.039	3.7113	3.7799
10	3.6046	3.8485	3.7571	3.8485	3.8104	3.6123	3.9171
11	3.8485	3.9095	3.7494	4.0314	3.9552	3.7342	4.0162
12	3.8714	3.6961	7.3205	3.9552	4.0314	3.6885	3.9323
13	7.3906	3.6885	3.818	7.5964	3.9552	3.5361	7.4302
14	3.7799	3.8333	3.8104	2.5225	7.7336	7.1819	3.719
15	3.8409	3.8485	3.8485	3.8485	4.0238	3.3684	3.8333
16	4.0314	3.9171	3.879	3.94	4.0619	3.3913	3.9552
17	4.0619	4.0543	3.9704	4.1152	4.2295	3.4294	4.0466
18	3.94	3.9933	4.0009	4.0466	4.161	3.7723	3.9857
19	3.94	3.9018	4.1076	3.9781	4.0466	4.0009	3.7875
20	4.4658	4.4505	4.4505	4.5877	4.4124	4.4201	4.4887
21	4.4582	4.4505	4.4277	.8993	4.4887	4.5115	4.5801
22	4.2981	4.3439	4.4124	4.8163	4.4582	4.4887	4.4582
23	4.4505	4.542	4.6487	4.8011	4.7249	4.6868	4.6716
24	4.4963	4.6106	4.7097	4.8011	4.763	4.7401	4.7401
Max	7.3906	4.6106	7.3205	7.5964	7.7336	7.1819	7.4302
Min	3.6046	3.6885	3.7494	.8993	3.8104	3.3684	3.719
Avg	4.1660	4.0600	4.2421	4.1282	4.3425	4.1370	4.2943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281] BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 205 / 11 KV MUNDGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		1.1283				
13	1.2715		1.1641		1.0566	1.2178
14				1.3073		
Max	1.2715	1.1283	1.1641	1.3073	1.0566	1.2178
Min	1.2715	1.1283	1.1641	1.3073	1.0566	1.2178
Avg	1.2715	1.1283	1.1641	1.3073	1.0566	1.2178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 207 / 11 KV Akot 3

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7756	1.8442	1.89	1.8976	1.9585	1.9204	1.9509
2	1.6766	1.7299	1.7985	1.8061	1.8442	1.829	1.8442
3	1.6232	1.669	1.7528	1.7604	1.7833	1.7604	1.7756
4	1.5623	1.608	1.6918	1.669	1.7299	1.6156	1.669
5	1.5013	1.547	1.6309	1.6004	1.6309	1.5394	1.6004
6	1.4251	1.4708	1.5623	1.547	1.5623	1.5013	1.5394
7	1.3565	1.4403	1.5394	1.5318	1.4937	1.448	1.448
8	1.3336	1.387	1.448	1.4784	1.4327	1.4327	1.387
9	1.2803	1.3413	1.3794	1.4098	1.387	1.3336	1.3184
10	1.2955	1.3946	1.3794	1.4022	1.3946	1.326	1.3565
11	1.3413	1.4022	1.3489	1.448	1.4327	1.3717	1.3336
12	1.4022	1.448	2.6227	1.4784	1.4708	1.4327	1.387
13	2.8551	1.4708	1.3794	2.6526	1.5242	2.7019	2.7885
14	1.5394	1.5242	1.5851	1.5775	3.1656	.8916	1.5013
15	1.5927	1.6537	1.7375	1.6156	1.6918		1.5623
16	1.6232	1.6994	1.7299	1.7147		1.9052	1.669
17	1.6309	1.669	1.6918	1.7299	1.7452	1.989	1.6766
18	1.547	1.5775	1.6156	1.6537	1.9509	1.8671	1.5623
19	1.6156	1.5851	1.5699	1.669	1.7223	1.7604	1.5318
20	1.7756	1.8061	1.7299	1.8671	1.8671	1.8671	1.7985
21	1.7909	1.7985	1.7375	1.8747	1.9052	1.8671	1.8061
22	1.768	1.8138	1.7833	1.9052	1.9052	1.8976	1.829
23	1.8138	1.9204	1.9052	1.9738	1.989	1.9662	1.9052
24	1.8747	1.9357	1.9509	2.0119	2.0043	2.0195	1.9585
Max	2.8551	1.9357	2.6227	2.6526	3.1656	2.7019	2.7885
Min	1.2803	1.3413	1.3489	1.4022	1.387	.8916	1.3184
Avg	1.6250	1.6140	1.6858	1.7198	1.7648	1.7062	1.6750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 209 / SOOTGIRNI 1

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		1.4373				
13	1.3435		1.3123		1.2811	1.4529
14				1.4373		
Max	1.3435	1.4373	1.3123	1.4373	1.2811	1.4529
Min	1.3435	1.4373	1.3123	1.4373	1.2811	1.4529
Avg	1.3435	1.4373	1.3123	1.4373	1.2811	1.4529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 201 / 11 KV GADEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8238	.9061	.8238	.6371	.6371	.583	.7727
2	.788	.9172	.788	.6371	.6516	.5365	.7926
3	.7362	.8642	.7712	.5898	.6173	.5243	.7526
4	.7202	.8436	.7202	.6036	.6443	.5316	.743
5	.6859	.8749	.6401	.5898	.6554	.5079	.7133
6	.6554	.9374	.5792	.5441	.6802	.5144	.6836
7	.6081	.9214	.5075	.5182	.6081	.3201	.6661
8	.5944	.8749	.5182	.5182	.4877	.2561	.743
9	.5792	.8025	.439	.3437	.3749	.25	.724
10	.2401	.2591	.6562	.6642	.5792	.2561	.282
11	.2214	.3048	.7499	.6097	.6081	.2915	
12	.4801	.3277	.7186	.2667	.743	.3277	.3605
13	.3605	.4024	.7907	.7316	.7133	.3887	.4024
14	.3429	.4359	.7499	.7526	.7011	.421	.5087
15	.4752	.4694	.7186	.7316	.6401	.3932	.5144
16	.4458	.4915	.703	.7011	.6859	.4915	.4409
17	.3932	.4588	.6874	.7011	.6805	.3932	.3932
18	.3429	.4115	.3506	.2743	.543	.4207	.439
19	.5121	.4458	.5121	.4207	.5144	.4298	.543
20	.3506	.5487	.503	.5792	.6661	.567	.7011
21	.503	.6584	.503	.6516	.6478	.6219	.7164
22	.4801	.695	.5609	.6653	.6805	.6249	.7316
23	.4694	.6516	.6859	.7011	.7362	.6081	.7011
24	.7274	.9374	.7274	.6516	.7042	.5571	.7621
Max	.8238	.9374	.8238	.7526	.743	.6249	.7926
Min	.2214	.2591	.3506	.2667	.3749	.25	.282
Avg	.5223	.6433	.6419	.5868	.6333	.4507	.6125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 202 / 11 KV BELKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-APR-17	18-APR-17	19-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3688		
2		.3932		
3		.3932		
4		.3688		
5		.3605		
6		.3201		
7		.3048		
8		.2743	.5487	
9		.3125	.4999	
10				.5418
11				.5571
12	.5243			.5182
13	.6036			.5365
14	.6036			.5487
15	.6706			.4694
16	.6226			.4458
17	.6226			.4527
24		.3086		
Max	.6706	.3932	.5487	.5571
Min	.5243	.2743	.4999	.4458
Avg	.6079	.3405	.5243	.5088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 203 / 11 KV TELHARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7193	1.2193	1.7193	1.9448	1.5851	1.7497	1.5158
2	1.6834	1.142	1.6834	1.8679	1.6091	1.6766	1.5242
3	1.5775	1.0974	1.5775	1.8679		1.6156	1.4449
4	1.4746	1.0669	1.4746	1.8778	1.4373	1.5242	1.3969
5	1.3717	1.0059	1.2193	1.6385	1.2811	1.3717	1.278
6	1.2452	.9374	1.0715	1.4723	1.1279	1.1248	1.1584
7	1.1203	.8109	1.0151	1.2193		.9145	1.1294
8	1.0402	.8333	1.1469	1.1888	1.2193	.9686	1.0997
9	1.0425	.7926	.9328	1.1873	1.3435	1.0059	.9869
10	1.0623	1.1012	1.3413	1.1702	1.2803	1.0059	1.0837
11	1.2498	1.3108	1.4632	1.3108	1.448	1.406	1.2163
12	1.3413	1.4746	1.4784	1.307		1.3748	1.1248
13	1.4632	1.643	1.5623	1.5242		1.5242	1.2803
14	1.6248	1.6766	1.5935	1.5653	1.4327	1.406	1.4373
15	1.5242	1.7101	1.6766	1.5546	1.1069	1.4373	1.5813
16	1.531	1.4746	1.6461	1.5242	1.4883	1.2193	1.6324
17	1.5123	1.5729	1.6766	1.5752	1.4998		1.4685
18	1.2483	1.166	1.3123	1.3413	1.0936	1.4419	1.5074
19	1.4083	1.4746	1.2803	1.4419	1.3763	1.4998	1.5623
20	1.5623	1.6827	1.4723		1.6004	1.6644	1.6385
21	1.531	1.829	1.5623	1.8122		1.8435	1.97
22		1.829	1.4373	1.8884	1.7497	1.7185	1.8023
23	1.406	1.6712	1.989	1.781	1.7185	1.6964	1.5364
24	1.6518	1.2967	1.5813	1.989	1.7071	1.7185	1.5242
Max	1.7193	1.829	1.989	1.989	1.7497	1.8435	1.97
Min	1.0402	.7926	.9328	1.1702	1.0936	.9145	.9869
Avg	1.4083	1.3258	1.4547	1.5674	1.4266	1.4308	1.4125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 205 / Tudgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.3155	.3582	.6706	.6443	.4557	.3269
2		.3086	.3582	.6226	.57	.4287	.3048
3	.3856	.2804	.3506	.6226	.57	.4024	.301
4	.3429		.3429	.6036	.5801	.3772	.2675
5	.3772	.2347	.2743	.6226	.5801	.3681	.2675
6	.3932	.2294	.2606	.5761	.5441	.3506	.2675
7	.3201	.1966	.1974	.5487	.5281	.2881	.2027
8	.208	.1677	.1638	.5182	.4877	.2949	
9	.2317	.1677	.1097	.4999	.5312	.3125	.1738
10	.4801	.7449	.1311	.2214		.463	.5639
11	.583	.7316	.1509	.2439	.1738	.6226	.5182
12	.5571	.7537	.1886	1.8671	.1783	.6401	
13	.5624	.6706	.1052	.2439	.208	.5937	.5571
14	.6081	.7042	.2103	.2408	.061	.5898	.57
15	.4999	.6706	.2401	.2134	.0671	.5636	.5959
16	.4915	.6554	.218	.2134	.0549	.4915	.503
17	.506	.6226	.1715	.2294	.0373		.5571
18	.1753	.2058	.2149	.2103	.2149	.2126	.2926
19	.3361	.2743	.2241	.2926	.2561	.2195	.3658
20	.3292	.3658	.3292		.3658	.3045	.4024
21	.3658	.4024	.3696	.4024	.4298	.2987	.4024
22	.3856	.439	.3658	.4024	.439	.3125	.4108
23	.3772	.3932	.3772	.3658	.4024	.3841	.4207
24	.3887	.3429	.3479	.6859	.6554	.4458	.3353
Max	.6081	.7537	.3772	1.8671	.6554	.6401	.5959
Min	.1753	.1677	.1052	.2103	.0373	.2126	.1738
Avg	.4058	.4295	.2525	.4834	.3730	.4096	.3912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 201 / 11 KV HKD feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9904	3.0312	3.0464	3.1905	3.0262	1.9342	3.1988
2	3.0361	2.9854	3.0007	3.0464	3.1329	1.9647	3.5646
3	3.1428	3.2495	3.1683	3.2598	3.0007	3.3532	3.2732
4	3.2274	2.9074	3.0903	2.9142	2.7465	3.5361	3.1683
5	2.8312	3.0903	2.8769	3.1055	2.2131	2.9845	3.6408
6	2.7648	2.9447	2.8464	2.5923	2.1384	2.5053	3.4796
7	2.6833	1.9635	2.4969	1.9787	.7689	2.6109	2.8322
8	1.848	1.9414	2.4729	1.848	1.9064	1.4129	1.8702
9	1.8107	1.9414	1.7615	1.7395	2.0043	1.8889	1.8702
10	1.8107	1.8576	1.7615	1.8328	1.8957	1.8549	.8993
11	1.7802	.9564	1.765	1.8702	1.1336	1.8549	1.9891
12	2.3274	2.0043	2.1445	2.2615	2.1651	1.1126	2.5053
13	1.8415	2.4158	1.0642	2.3769	1.5919	2.1193	2.6798
14	2.6056	2.2516	2.4531	2.7682	2.8498	2.2702	2.6902
15	2.3007	2.5701	2.3872	2.7987	2.4535	2.5853	2.7682
16	2.614	2.4463	2.6006	2.8799	2.5923	2.3194	2.753
17	2.5815	2.3682	2.5663	2.7542	2.614	2.2073	2.5766
18	2.2882	2.3373	2.505	2.7595	2.6036	2.0766	1.5546
19	2.5446	2.4551	2.4989	2.8635	2.8361	2.3007	2.6109
20	.8993	2.6856	.9435	.9518	2.1503	2.0976	2.2996
21	2.4082	2.7711	2.4082	2.5625	.5319	2.2436	2.2436
22	3.4819	3.5056	3.4903	3.6396	3.4362	3.099	3.3532
23	3.4312	3.3908	3.421	3.2381	3.5276	3.5734	3.6108
24	3.0971	3.3075	3.2819	3.3837	3.5124	3.4446	3.4648
Max	3.4819	3.5056	3.4903	3.6396	3.5276	3.5734	3.6408
Min	.8993	.9564	.9435	.9518	.5319	1.1126	.8993
Avg	2.5145	2.5574	2.5021	2.609	2.3680	2.3896	2.7040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 202 / GORDHA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7291	.7969	.7969	1.4413	1.5261	1.4918	.8139
2	.7461	.763	.7202	1.4413	1.5261	1.5261	.8139
3	.7461	.763	.763	1.4413	1.5261	1.5261	.7461
4	.7461	.763	.663	1.5261	1.5261	.0332	.7461
5	.7461	.7969	.6554	1.5261	1.4413	.0332	.7461
6	.78	.8139	.6443	1.4413	1.4413	.0339	.7461
7	.7969	.8139	.6104	1.5261	1.6108	.0339	.8309
8	.7461	.8139		1.6108	1.5261	.0339	.8478
9	.78	.7773	.6478	1.6108	1.6108	.0339	.8478
10	1.7804	1.8023	.7545	.8478	.8478	1.6617	
11	1.95	1.6385	.6478	.8478	.9156	1.6956	1.6108
12	1.95	1.7147	.6783	.8139	.9326		1.6108
13	1.8652	1.6385	.663	.8478	.8478	1.6108	1.6108
14	1.8652	1.6385	.663	.8478	.8139	1.6108	1.6108
15	1.8652	1.6289	.663	.8478	.8139	1.6108	1.6108
16	1.7804	1.5261	.6133	.8139	.78	1.6108	1.5261
17	1.7804	1.6108	.6783	.8478	.7625	1.6108	1.5261
18	.0339	.0339	.0332	.0339		.0332	
19	.0339	.0332	.0332	.0339		.0339	.0339
20	.0339	.0339	.0339	.0339	.032	.0339	.0339
21	.0339	.0339	.0339	.0339	.0332	.0339	.0339
22	.0339	.0339	.0339	.0339	.0332	.0332	.0339
23	.0328	.0339	.0339	.0339	.0339	.0339	.0339
24	.7461	.7969	.7537	1.5261	1.5261	1.4918	.7969
Max	1.95	1.8023	.7969	1.6108	1.6108	1.6956	1.6108
Min	.0328	.0332	.0332	.0339	.032	.0332	.0339
Avg	.9417	.8875	.5138	.9171	1.0049	.7761	.8732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 203 / SAUNDALA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-APR-17	17-APR-17	19-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
19		.1524	
21	.0332		.1524
Max	.0332	.1524	.1524
Min	.0332	.1524	.1524
Avg	.0332	.1524	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 204 / Wari express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.032	.032	.0324	.032	.032	.0267	.032
2	.032	.032	.0328	.032	.032	.0267	.032
3	.032	.032	.0332	.032	.032	.0267	.032
4	.032	.0328	.0328	.032	.032	.0267	.032
5		.0324	.0324	.032	.032	.0248	.032
6	.0324	.0324	.032	.032	.032	.032	.032
7	.032	.032	.0332	.032	.032	.032	.032
8	.032	.032	.032	.032	.032	.032	.032
9	.032	.0305	.0248	.032	.032	.032	.032
10	.032	.0267	.0267	.032	.032	.032	
11	.032	.0267	.0267	.032	.032	.032	.032
12	.032	.0267	.0267	.032	.032		.032
13	.032	.0267	.0251	.032	.032	.032	.032
14	.032	.0267	.0255	.032	.032	.032	.032
15	.032	.0251	.0229	.032	.032	.032	.032
16	.032	.0286	.0229	.032	.032	.032	.032
17	.032	.0267	.032	.032	.0267	.032	.032
18	.032	.0248	.0229	.032	.0248	.032	
19	.032	.0251	.0229	.032	.0267	.032	.032
20	.032	.032	.032	.032	.0267	.032	.032
21	.032	.0267	.032	.032	.0248	.032	.032
22	.032	.0251	.1989	.032	.0248	.032	.032
23	.032	.0251	.032	.032	.0324	.032	.032
24	.032	.032	.0324	.032	.032	.0229	.032
Max	.0324	.0328	.1989	.032	.0324	.032	.032
Min	.032	.0248	.0229	.032	.0248	.0229	.032
Avg	.0320	.0289	.0361	.032	.0305	.0304	.032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 205 / DIWANZARI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1989	.1823	.1865	3.3065	3.1493	3.2579	.1989
2	.1658	.1823	.2054	3.2322	3.1161	3.0864	.1989
3	.1658	.1823	.1865	3.2322	3.0664	3.0521	.1989
4	.1658	.1619	.1658	3.1493	2.9835	.2075	.1658
5	.1658	.1696	.1696	3.1493	2.9835	.1867	.1658
6	.1326	.1696	.1357	3.1493	2.9835	.1886	.1658
7	.1326	.1067		3.2322	3.1493	.116	.1326
8	.0829	.0995		3.315	3.2322	.0995	.0995
9	.0829	.0914		3.315	3.2322	.0829	.0995
10	3.315	3.2579			.0995	.1326	
11	3.4476	3.2579			.1326	3.4808	3.3979
12	3.315	3.3436			.1326		3.1824
13	3.315	3.6866			.0995	3.4476	3.2819
14	3.1493	3.3913			.0995	2.7349	2.9835
15	3.3648	3.8275			.0995	3.0664	3.0664
16	3.4808	3.476			.0995	2.9835	2.9835
17	2.9835	3.9819			.1017	3.315	3.1493
18	.0995	.0819	.1509		.1132	.0995	
19	.1492	.1509	.1698	.1658	.1698	.1492	.1326
20	.1989	.1658		.1823	.2263	.1989	.1823
21	.1989	.1886	.1989	.1989	.2075	.1823	.1823
22	.1989	.2263	.1989	.1989	.2075	.1989	.1989
23	.2035	.2263	.1823	.1823	.1823	.1989	.1989
24	.1823	.1823	.1989	3.2217	3.1493	3.2579	.1989
Max	3.4808	3.9819	.2054	3.315	3.2322	3.4808	3.3979
Min	.0829	.0819	.1357	.1658	.0995	.0829	.0995
Avg	1.2040	1.2829	.1791	2.2154	1.3757	1.4663	1.1166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 206 / KHANDALA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.915	2.4291	2.5911			2.753
2	2.915	2.4291	2.5911			2.753
3	2.915	2.3482	2.5911			2.753
4	2.834	2.3482	2.5911			2.753
5	2.834	2.3967	2.5911			2.5911
6	2.672	2.4291	2.5911			2.5911
7	2.5911	2.3482	2.5911			2.753
8	2.4291	2.4291	2.5911			2.753
9	2.4291	3.0864	2.7435			2.672
10			2.7435		2.1052	
11			2.7435		2.1052	
12			2.915		2.753	
13			2.7435		2.753	
14			2.915	1.7814	2.5911	
15			2.7435	1.8623	2.2672	
16			2.8178		2.4291	
17				2.8826	2.5434	
18				2.834		
19				2.753		
20				2.753		
21				1.9433		
22				1.9433		
24	2.915	2.4291	2.5911			2.753
Max	2.915	3.0864	2.915	2.8826	2.753	2.753
Min	2.4291	2.3482	2.5911	1.7814	2.1052	2.5911
Avg	2.7449	2.4673	2.6874	2.3441	2.4434	2.7125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 201 / 11 KV KHARKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.2743						
7	.2401						
8	.2058	.2743					
9	.2058						
10		1.7147		1.5432	2.3663		
11	2.1605	1.7147		1.749	2.6406		1.1317
12	2.2634	1.989		1.8176	2.7092		2.572
13				2.0576	2.4348		2.6063
14	2.2291	1.7833			2.7092		
15	2.572	1.7147		1.7833	2.5034		2.6406
16	2.7092	2.0919		1.749	2.572		2.7778
17	2.7435	1.7147			2.4006		2.5034
18				1.7147	2.3663		2.5034
19	2.4006						2.5377
20		1.9204		1.8176			
21				1.7833			
22		1.7833		1.749			
23				1.8519			
24	1.749	2.0576	.1372		1.8519	.6859	2.6063
Max	2.7435	2.0919	.1372	2.0576	2.7092	.6859	2.7778
Min	.2058	.2743	.1372	1.5432	1.8519	.6859	1.1317
Avg	1.6461	1.7053	.1372	1.7833	2.4554	.6859	2.4310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 202 / 11 KV UMARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 203 / 11KV ADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.8004						
7	1.5432					1.749	
8	1.3717	1.749					
9	1.3717						
10				1.3717	1.3203		
11	.3772	.4287		1.5432	1.6804		.3601
12	.4115	.3429		1.5432	1.749		.4115
13				1.4575	1.5775		.3429
14	.4287	.3429			1.5432		
15	.4115	.3429		1.5432	1.4575		.3258
16	.3601	.3429		1.5432	1.4575		.3429
17	.3772	.3429			1.406		.3086
18				.3429	.3772		.3429
19	.3772						.3601
20		.3772		.3772			
21				.4287			
22				.3772			
23				.3429			
24	.3772	1.6804	.3086		.3429	.7716	
Max	1.8004	1.749	.3086	1.5432	1.749	1.749	.4115
Min	.3601	.3429	.3086	.3429	.3429	.7716	.3086
Avg	.7673	.6611	.3086	.9883	1.2912	1.2603	.3494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 204 / 11 KV CHITTALWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.6001						
7	.4572					.9259	
8	.5144	.9259					
9	.5144						
10				.6001	.9259		
11	1.8004	1.8004		.5144	.9431		1.6804
12	2.0576	1.7147		.5144	.9259		1.749
13				.5144	.9431		1.749
14	1.989	1.7147			1.0288		
15	2.0233	1.7147		.5144	1.046		
16	2.0233	1.8861		.5144	1.046		1.6804
17	1.9547	1.7147			.6287		1.749
18				.6001	.9602		1.0631
19	.9259						1.0288
20		.6001		.6859			
21				.7716			
22				.7716			
23				.6859			
24	.5144	1.0631	1.0631		1.4146	.7888	
Max	2.0576	1.8861	1.0631	.7716	1.4146	.9259	1.749
Min	.4572	.6001	1.0631	.5144	.6287	.7888	1.0288
Avg	1.2812	1.4594	1.0631	.6079	.9862	.8574	1.5285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 205 / 11 KV Water Supply Express NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0171						
7	.0514					.0857	
8	.0857	.1029					
9	.0857						
10		.0857			.0857		
11	.0857	.0686		.0686	.0686		.0857
12	.1029	.0514		.0857	.0857		.0857
13				.0686	.0857		.0857
14	.0857	.0857			.0857		
15	.0686	.0857		.0686	.0857		.0857
16	.0514	.0857		.0686	.0686		.0857
17	.0343	.0686			.0514		.0686
18				.0343	.0514		.0171
19	.0171						.0171
20		.0343					
22				.0171			
24	.0171		.0857			.0857	
Max	.1029	.1029	.0857	.0857	.0857	.0857	.0857
Min	.0171	.0343	.0857	.0171	.0514	.0857	.0171
Avg	.0586	.0743	.0857	.0588	.0743	.0857	.0664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 201 / 11 KV PANCHAGAVHAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3889	1.1145	1.5775	1.0117	1.0802	1.4403	1.3375
2	1.3889	1.2003	1.5775	1.0117	1.0288	1.4403	1.286
3	1.3717	1.1145	1.6461	.9945	1.0288	1.406	1.2689
4	1.3375	1.0631	1.6461	.9774	1.0288	1.406	1.2003
5	1.3203	1.0631	1.6804	1.0117	1.046	1.406	1.2003
6	1.2003	1.0288	1.6804	1.0288	1.0288	1.1488	1.0631
7	.9774	.9945	1.3889	.9088	.8745	.8745	.8916
8	.7545	.8573	1.3546	.9602	.8916		.7888
9	.463	.7202	1.3889	1.0117	.9088	.7888	
10	1.5604	1.6461	.8916	.9088	.9088	1.166	.8402
11	1.6289	1.5947	.9088	.8916	.9259	.9259	.8402
12	1.6804	1.6461	.9259	.9431	.9259		.8402
13	1.6975	1.6461	.9774	.9945	.9259	.9259	.8402
14	1.6804	1.6118	.9945	1.0288	.9259	.9774	.8402
15	1.6804	1.6118	1.0288	1.0802	.9259	.7373	
16	1.6804	1.5775	.9602	.9774	.9945	.9259	.8745
17	1.6804	1.6461	.9259	.8745	.9774	.8573	.8573
18	.8745	.5144	.9602	.823	1.0117	.7716	.823
19	1.1145	1.2346	1.3717	1.3717	1.2689	1.3375	1.0802
20	1.3546	1.3717	1.4403	1.4746	1.4232	1.3717	1.4575
21	1.4403	1.4746	1.4918	1.4746	1.4575	1.3717	1.4918
22	1.4403	1.4746	1.5432	1.4575	1.4575	1.4575	1.5089
23	1.4403	1.5089	1.5261	1.4575	1.4575	1.4575	1.4918
24	1.3889	1.406	1.5775	.9774	1.1145	1.4403	1.3717
Max	1.6975	1.6461	1.6804	1.4746	1.4575	1.4575	1.5089
Min	.463	.5144	.8916	.823	.8745	.7373	.7888
Avg	1.3560	1.2967	1.3110	1.0688	1.0674	1.1652	1.0997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 202 / 11 KV WANGESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-APR-17
HR	Load (MW)
8	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 203 / 11 KV DAHIGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288		.9602	1.5432	1.0288	1.4403	1.5089
2	1.0288	1.0974	.9602	1.5261	.9945	1.4403	1.4403
3	1.0288	1.0631	.9602	1.4575	.9945	1.4403	1.3375
4	1.0117	1.0288	.9602		.9945	1.4403	1.3375
5	1.0117	1.0288	.9259	1.406	.9259	1.4403	1.1831
6	.9774	.9774	.8916	1.3375	.9259	1.4232	1.1831
7	.9774	.9088	.5487	.8745	.8573	1.2003	1.1488
8	.9602	.9431	.4801	.9431		1.1488	1.1145
9	1.0288	.9602	.4801	.9774	.9088	1.0974	
10	.4287	.5144	1.1488	1.3717	1.2346	1.0631	.8916
11	.5144	.5144	1.1145	1.3717	1.3032	1.0974	
12	.583	.7202	1.1317	1.3717	1.3032		1.2346
13	.6173	.7888	1.1145	1.4232	1.2346	1.0288	1.2003
14	.6173	.823	1.0802	1.4746	1.2346	.6859	1.2689
15	.6344	.7888	1.4232	1.4575	1.2346	1.0117	.7202
16	.6344	.7202	1.4575	1.4232	1.3375	1.0631	.7202
17	.4973	.6173	1.4918	1.406	1.2346		1.2346
18	.5316	.5316	.5144	.5658	.823		1.1317
19	.8402	.7888	.823	1.0288	.823	.9431	1.3032
20	1.0117	.9602	.9602	1.1145	.8573	.9259	1.3375
21	1.046	1.0288	1.0631	1.1317	.9945	1.1317	1.166
22	1.0631	1.0631	1.1488	1.1145	1.0974	1.166	
23	1.0631	1.0631	1.0974	1.0288	1.1145	1.1488	1.1145
24	1.0288	1.166	1.0288	1.5775	1.0288	1.4403	1.5432
Max	1.0631	1.166	1.4918	1.5775	1.3375	1.4403	1.5432
Min	.4287	.5144	.4801	.5658	.823	.6859	.7202
Avg	.8402	.8738	.9902	1.2577	1.0646	1.1799	1.1962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 201 / 11 KV Danapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.6668	.6173	1.0517	.9907	.9945	.6344
2	.583	.6001	.6173	1.0364	.9602	.884	.6001
3	.5658	.5658	.6478	1.0364	.945	.8535	.6001
4	.5658	.5658	.6097	1.0212	.945	.6516	.5144
5	.5144	.5144	.5716	1.0212	.9145	.6859	.4801
6	.3429	.4572	.5335	1.0059	.9145	.5716	.4287
7	.2572	.3429	.2667	.9907	.8688	.3239	.3429
8	.2058	.2858	.2667	.9145	.884	.2667	.2915
9	.2286	.2667	.2572	.9145		.2572	.2572
10	1.0822	1.1488	.2572	.3086	.3429	.945	1.1431
11	1.0974	1.2003	.3429	.3429	.5335	1.0059	1.0974
12	1.1126	1.1431		.4191	.4801	1.0212	1.0669
13	1.1126	1.1584	.3772	.4954	.5487	.9907	1.0669
14	1.1126	1.1584	.4458	.4954	.5144	.9297	1.0974
15	1.1431	1.1888	.4801	.5716	.5335	.8002	1.0822
16	1.1888	1.1736	.463	.5144	.4954	.8993	1.0517
17		1.0974	.3429	.4001	.4001	.8688	.9755
18		.4191	.2572		.362	.3429	
19	1.046	.4954	.4973			.4763	
20	.6097	.6478	.6097	.6097		.6097	.6478
21	.6478	.724	.6859	.6859	.6859	.6344	.724
22	.724	.583	.743	.743	.724	.6859	.7621
23	.724	.6859	.7621	.743	.724	.703	.7621
24	.5658	.7049	.724	1.0822	.9755	.8688	.6687
Max	1.1888	1.2003	.7621	1.0822	.9907	1.0212	1.1431
Min	.2058	.2667	.2572	.3086	.3429	.2572	.2572
Avg	.7279	.7414	.4946	.7456	.7020	.7196	.7407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 202 / 11 KV Warkhed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8747	2.1948	1.8595	.2229	.2477	.2667	1.9052
2	1.9052	1.89	1.89	.2229	.2477	.2667	1.89
3	1.9052	1.9204	1.829	.2229	.2229	.2286	1.9052
4	1.89	1.8595	.2058	.2229	.2229	.2286	1.9357
5	1.8595	1.829	.2286	.2229	.2058	.1905	1.9357
6	1.829	1.829	.1905	.1715	.1372	.1524	1.9662
7	1.7985	1.7985	.1143	.12	.1029	.1334	1.9509
8	1.9509	1.9509	.0953	.1029	.0857	.1143	1.9357
9	1.829	1.89	.0953	.1029	.0857	.0953	1.9204
10	.0953	.1143	2.0881	2.1033	2.1643	.1143	.1029
11	.1029	.1029	2.0729	2.1338	2.2405	.1334	.0857
12	.12	.1029	2.1338	2.0881	2.1795	.1334	.0686
13	.12	.1372	2.1338	2.0576	2.1643	.1524	.0686
14	.1372	.1543	2.1338	2.1033	2.2253	.1524	.0686
15	.1543	.1543	2.1338	2.0729	2.2862	.1543	.0686
16	.1524	.1543	2.1795	2.1033	1.9662	.1715	.0686
17	.1524	.1372	2.1338		1.9204	.1524	.0572
18	.1334	.1524	.1524	1.9662	.1334	.1334	.1334
19	.2286	.2096	.2096	.1715	.2667	.1905	.1715
20	.2667	.2286	.2858	.2477	.2858	.3048	.2667
21	.2858	.2286	.2667	.2858	.2858	.2572	.2858
22	.2667	.2667	.2858	.2858	.2667	.2401	.2667
23	.2667	.2667	.2667	.2667	.2667	.2401	.2667
24	1.7071	2.1434	1.9357	.2477	.2229	.2477	1.8747
Max	1.9509	2.1948	2.1795	2.1338	2.2862	.3048	1.9662
Min	.0953	.1029	.0953	.1029	.0857	.0953	.0572
Avg	.8763	.9048	1.1217	.8585	.8514	.1856	.8833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 203 / 11 KV Hingani

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2572	.3086	.2657	.2286	.2743	.2401
2	.2401	.2401	.2743	.2401	.2572	.2743	.2401
3	.2401	.2401	.2743	.2401	.2572	.2572	.2401
4	.2401	.2401	.2401	.2401	.2572	.2229	.2058
5	.2401	.1543	.2058	.2229	.2229	.1715	.2058
6	.1543	.1372	.1543	.1543	.1543	.1715	.1715
7	.0857	.1029	.0686	.1029	.1029	.0953	.1029
8	.0686	.0514	.0686	.0686	.0686	.0762	.0857
9	.0686	.1029	.0686	.0686	.0686	.0686	.0857
10	.0857	.0857	.0686	.1029	.0762	.0686	
11	.0762	.1029	.0953	.1029		.0857	
12	.1029	.12	.1334	.1029	.12	.1029	
13	.1029		.1524	.1372	.1372	.1029	.1029
14	.1029	.12	.1715	.1372	.1372		.1372
15	.1372	.12	.1905	.1543	.1543	.0171	.1372
16	.1543	.1372	.1715	.1543	.1543	.0191	.1372
17	1.8595	1.6766	1.829	1.7985	1.7375	1.627	1.7375
18	1.9547	1.7375	.5487	1.768	1.7375	1.6537	1.7375
19	2.0576	1.7375	1.6156	1.89	1.768	1.7204	1.768
20	1.89	1.7071	.1715	1.6766	1.7375	1.8442	1.5851
21	1.89	1.6461	1.5851	1.7375	1.6766	1.7985	1.6156
22	1.8747	1.5546	1.5546	1.7375	1.6766	1.7985	1.5851
23	1.89	1.5546	1.5394	1.7071	1.7071	1.7985	1.5546
24	1.6613	1.8595	1.5851	1.5394	1.6918	1.7071	1.768
Max	2.0576	1.8595	1.829	1.89	1.768	1.8442	1.768
Min	.0686	.0514	.0686	.0686	.0686	.0171	.0857
Avg	.7257	.6820	.5448	.6812	.7013	.6937	.7354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 204 / balhadi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.0364	1.3413	1.0864	.884	1.0517	1.0059
2	1.1584	1.0669	1.3108	1.0974	.945	1.0974	1.0059
3	1.1584	1.0669	1.3565	1.0974	.945	1.0669	1.0364
4	1.1584	1.0364	1.3413	1.0974	.945	1.0669	1.0059
5	1.1584	.9755	1.2803	1.0974	.9145	1.0364	1.0364
6	1.1279	1.0059	1.2651	1.0974	.8993	.9907	1.0364
7	1.0974	1.0059	1.2498	1.0974	.9145	1.0059	1.0364
8	1.1888	.9755	1.2193	1.1888	.945	.9755	1.0364
9	1.4327	1.448	1.4022	1.326	1.2193	1.3413	1.3717
10	1.5546	1.5851	1.4022	1.2803	1.3413	1.1469	1.4937
11	1.5242	1.4022	1.4327	1.2498	1.2193	1.1203	1.4327
12	1.4937	1.2803	1.3413	1.2193	1.2803	1.0936	1.4022
13	1.4327	1.4022	1.2955	1.2498	1.2803		1.3717
14	1.4022	1.4022	1.326	1.2803	1.2498	1.0002	1.3717
15	1.3717	1.4022	1.3565	1.2193	1.4632	1.1469	1.3565
16	1.3413	1.4022	1.3717	1.2193	1.3717	.6097	1.3413
17	.1543	.2058	.1372	.0686	.1715	.1715	.1715
18	.1372	.1886	.1372	.0686	.1543	.2058	.2058
19	.3086	.2915	.2743	.1029	.2915	.2743	.2401
20	.3772	.3429	.3429	.1543	.3086	.3429	.3258
21	.4458	.3772	.3772	.3772	.3429	.4115	.3601
22	.4458	.3772	.4572	.4287	.3429	.4115	.3772
23	.4115	.4115	.4287	.4115	.3944	.4115	.4115
24	.4115	.4115	.4115	.4287	.4287	.4115	.4115
Max	1.5546	1.5851	1.4327	1.326	1.4632	1.3413	1.4937
Min	.1372	.1886	.1372	.0686	.1543	.1715	.1715
Avg	.9784	.9208	.9941	.8727	.8438	.7996	.9102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 201 / Talegaon Bz

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	1.95	1.7497	1.8482	.7049	.724
2	.6668	.6478	1.8945	1.7185	1.8067	.6859	.7049
3	.6478	.6478	1.8652	1.7185	1.7532	.6859	.7049
4	.6097	.6478	1.7736	1.7497	1.7532	.6478	.6859
5	.5716	.6097	1.7532	1.7497	1.7901	.6097	.6859
6	.5525	.5716	1.7204	1.7341	1.8482	.5716	.6097
7	.362	.381	1.933	1.7341	1.9204		.3429
8	.3429	.3239	2.0233	1.906	2.0233	.3239	.2667
9		.3429	2.1434	1.8435	2.1091	.3048	.362
10		2.1704	.2667	.2667	.3239	1.7966	1.8122
11		2.4006	.2286	.3048	.3239	2.1262	2.1262
12		2.1548	.3239	.4001	.4572	2.0576	2.1262
13	1.9559	1.989	.381	.4191	.4763	2.0576	2.0856
14	1.9841	2.0178	.4763	.4954	.4954	1.9765	2.0008
15	1.9997	2.0517	.4763	.4191	.4954	1.8991	2.1605
16	2.0309	2.1434	.4572	.381	.4763	1.8519	2.0687
17	2.1091	2.1026	.362	.362	.4382	1.866	2.1434
18	1.9841	.3048	.3239	.362	.362	.2858	
19	1.8903	.5335	.5335	.5525	.5525	.4954	.4954
20	.6478	.5525	.6478	.6478	.6097	.6287	.6287
21	.6859	.7049	.6859	.7049	.6668	.6859	.6859
22	.743	.724	.6859	.743	.6668	.743	.743
23	.724	.724	.743	.724	.7049	.743	.5716
24	.6859	.6859	1.8842	1.7497	1.8233	.7049	.724
Max	2.1091	2.4006	2.1434	1.906	2.1091	2.1262	2.1605
Min	.3429	.3048	.2286	.2667	.3239	.2858	.2667
Avg	1.0940	1.0883	1.0639	1.0182	1.0719	1.0632	1.1069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 202 / industrial feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1905	.1334	.1905	.2286	.2286
2	.1334	.1334	.1715	.1334	.1715	.1524	.2096
3	.1334	.1334	.1715	.1334	.1715	.2286	.2096
4	.1334	.1334	.1715	.1334	.1715	.2286	.2096
5	.1334	.1334	.1715	.1334	.1715	.2286	.2286
6	.2096	.1334	.1715	.1334	.1715	.2477	.2286
7	.2096	.1334	.1334	.1143	.1524	.2477	.1905
8	.1905	.1143	.1143	.1334	.1524	.1524	.1524
9	.0381	.1143	.1143	.1334	.1143	.1334	.1334
10	.0572	.1334	.1334	.1334	.1334	.1334	.1334
11	.1334	.1334	.1334	.1334	.1334	.1334	
12	.1334	.1334	.1334	.1334	.1334	.1334	.1334
13	.1334	.1334	.1334	.1334	.1334	.1334	.1334
14	.1334	.1334	.1334	.1334	.1334	.1334	.1334
15	.1334	.1334	.1334	.1334	.1334	.1334	.1334
16	.4191	.1334	.1334	.1334	.1334	.1334	.1334
17	.1334	.1334	.1334	.1334	.1334	.1334	.1334
18	.1334	.1334	.1334	.1334	.1334	.1334	
19	.1334	.1334	.1334	.1334	.1334	.1334	.1334
20	.1334	.1334	.1334	.1334	.1334	.1334	.1334
21	.1334	.2286	.1334	.1524	.1143	.2286	.1143
22	.1524	.3048	.1334	.2096	.1905	.2096	.1143
23	.1524	.3429	.1334	.2286	.2667	.2286	.0572
24	.2858	.1334	.2477	.1334	.2096	.2477	.2286
Max	.4191	.3429	.2477	.2286	.2667	.2477	.2286
Min	.0381	.1143	.1143	.1143	.1143	.1334	.0572
Avg	.1548	.1516	.1469	.1405	.1548	.1762	.1594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 203 / Borwa

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8807	2.9058	.7049	.724	.724	.7049	3.0464
2	2.8978	2.8746	.6668	.6859	.7049	.7049	3.3432
3	2.8656	2.8746	.6668	.6859	.7049	.7049	3.2808
4	2.8656	2.8433	.6478	.6478	.6859	3.5307	3.1558
5	2.9321	2.8121	.6287	.6478	.6668	3.4214	3.0308
6	3.0521	2.5465	.6097	.5716	.6668	3.3276	2.9683
7	3.1554	3.0152	.4572	.4382	.4954	3.0152	2.8433
8	3.3808	3.0464	.381	.4191	.4001	3.0933	3.5113
9	3.2065	3.0777	.381	.3429		2.9527	3.2941
10	.3239	.2858	3.1727	2.9527		.4001	.362
11		.3429	3.1901	2.5934	3.2421	.4001	
12	.4191		3.3461	2.5777	3.2407	.4382	.4191
13	.4954		3.2407	2.4215	3.2047	.4763	.4954
14	.4191		3.2421	2.9683	3.0769	.5335	.4954
15	.4191		3.3808	2.9995	3.0967	.5335	.4954
16			3.3288	3.062	2.9729	.4954	.4572
17	.4191	.5906	3.0693	3.2495	2.8464	.4572	.4001
18	.4001	.4382	.4001		2.609	.4001	
19	.5335	.6478			.4763	.5144	.4763
20	.6668	.743	.5525	.7621	.5716	2.6871	.6668
21	.6859	.743	.724	.7811	.724	2.6235	.743
22	.743	.7811	.724	.8002	.724	2.9527	.7621
23	.724	.6668	.743	.7621	.724	2.9312	.743
24	2.8487	2.9058	.7049	.724	.724	.7049	2.9214
Max	3.3808	3.0777	3.3808	3.2495	3.2421	3.5307	3.5113
Min	.3239	.2858	.381	.3429	.4001	.4001	.362
Avg	1.6516	1.7969	1.5201	1.4462	1.5128	1.5835	1.7232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 201 / 11 KV KODRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1143	.108	.1046		
2			.1	.1063	.1046		
3			.0987	.1063	.1046		
4			.0987	.108	.1046		
5			.0987	.108	.1046		
6			.0987	.108	.1046		.1524
7			.1128	.108	.1046		
8			.1143	.0943	.093		
9			.0572	.1021	.093		
10	.0337	.1115				.1149	.0838
11	.0854	.1097				.1097	.1012
12		.1097				.0857	.1012
13	.0884	.1115				.096	.1012
14	.1149	.1115				.0737	.1012
15	.0674	.1149				.1149	.1012
16	.0995	.1149				.0737	.1012
17	.0995	.1149				.0926	.1012
24			.1286	.072	.1046		
Max	.1149	.1149	.1286	.108	.1046	.1149	.1524
Min	.0337	.1097	.0572	.072	.093	.0737	.0838
Avg	.0841	.1123	.1022	.1021	.1023	.0952	.1050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 202 / Wadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6944	.7164	.9907	.9145	.9526		.5601
2	.6944	.7164	.9717	.8954	.9145		.5468
3	.639	.7164	.9526	.8383	.9145		.5312
4	.6241	.7164	.9145	.8383	.8764		.5155
5	.6161	.7011	.8954	.8192	.8383		.5093
6	.5937	.7011	.6859	.8192	.6859		.5093
7	.5357	.6097	.4572		.4572		.4512
8	.6676	.7316	.3239	.3048	.3429		.4868
9	.6899	.7164	.3239	.3429	.3239		.4801
10	.381	.3429	.6859	.7042	.7773		.381
11	.4001	.4191	.7287	.7287	.7573	.4763	.4382
12	.4001	.4572	.643	.7316	.631	.5335	.4763
13	.5906	.5716	.6015	.7621	.5468	.4954	.6287
14	.6478	.6287	.6001	.7316	.5735	.6287	.6478
15	.6859	.6668		.7621	.6173	.6478	.7049
16	.4382	.6287	.6602	.7621	.5841	.4572	.6097
17	.4382	.4763		.7926	.5921	.5335	.5525
18	.381	.4572	.5335	.4191	.4382	.4572	.4382
19	.6859	.7621	.7049	.7621	.6859	.7049	.6668
20	.8954	.9335	.9145	.9145	.8764	.7049	1.0098
21	.9335	.9717	1.0098	1.0098	.9145	.8192	.9907
22	.9717	1.0479	1.0479	1.0098	.9526	.9145	.9907
23	.9717	.9717	1.0098	1.0098	.9907	.9145	.9717
24	.7343	.7164	.9717	.9526	.9526	.7316	.5921
Max	.9717	1.0479	1.0479	1.0098	.9907	.9145	1.0098
Min	.381	.3429	.3239	.3048	.3239	.4572	.381
Avg	.6379	.6824	.7558	.7750	.7165	.6442	.6121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-APR-17 and 21-APR-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 203 / Warud SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-APR-17	16-APR-17	17-APR-17	18-APR-17	19-APR-17	20-APR-17	21-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4191	.4694	.442	.5121	.4572	.362
2	.362	.4191	.4607	.4161	.5121	.4572	.3429
3	.362	.381	.4401	.4161	.5121	.4191	.3429
4	.3239	.381	.4108	.3961	.5121	.381	.3048
5	.2858	.381	.3814	.3715	.5441	.381	.2858
6	.2858	.3048	.3715	.3715	.5761	.3429	.2858
7	.1905	.1715	.5075	.4001	.5921	.3048	.1715
8	.1334	.0953	.5146	.5213	.6081	.3048	.1715
9	.1143	.0953	.4652	.6308	.5441	.2286	.1143
10	.5944	.6562	.1715	.2477	.1905	.1715	.5075
11	.5502	.6554	.1905	.2858	.1905	.6001	.6371
12	.6241	.5944	.2477	.2858	.2477	.3906	.6401
13	.6401	.5944	.3048	.2858	.3048	.3906	.6401
14	.5441	.5721	.3048	.3239	.2286	.5639	
15	.5761	.6093	.2858	.3239	.2286	.6241	
16	.6081	.5335	.2858	.3048	.2286	.5428	.5921
17	.6882	.5639		.2096	.1905	.5796	.5921
18	.1905	.2286	.1905	.2096	.2667	.2477	.2096
19	.381	.381	.3239	.4191	.381	.362	.3239
20	.4572	.4763	.4382	.4763	.5335	.4382	.4954
21	.4572	.4954	.5144	.5144	.5525	.5144	.6097
22	.4572	.4954	.5144	.4954	.5335	.4763	.4763
23	.4572	.4572	.4382	.4572	.4954	.4382	.4382
24	.4191	.4191	.4755	.463	.5121	.4572	.4191
Max	.6882	.6562	.5146	.6308	.6081	.6241	.6401
Min	.1143	.0953	.1715	.2096	.1905	.1715	.1143
Avg	.4209	.4325	.3786	.3862	.4166	.4197	.4074