

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 020519 / 132 KV KARANJA SUB STATION

Feeder No / Name : 403 / 33 KV DARWHA ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4774		.4475	.4615		.463	.4298
2	1.2071	.823	.9516	.4615	.439	.4527	.4083
3	1.262		1.0391	.4561		.4475	.4029
4	1.3169	.8779	1.0802	.4344	.3841	.4527	.3721
5	1.262		1.106	.417		.3858	.3721
6	1.3169	.9877	1.106	.4072	.3292	.3447	.3492
7	1.262			.3365		.3189	.3224
8	1.2126	1.1797		.3296	.2908	.2829	.2901
9	1.2181		1.0545	.3224		.2829	.2524
10	.3896	.3457	.2984		1.2455	1.1574	1.0937
11	.3951	.3292	.3447		1.1574	1.2912	1.2332
12	.3951	.4167	.3909	1.3169	1.214	1.1535	1.251
13	.3951	.4372	3.9638		1.214	1.2411	
14	.3841	.4475	.3922	1.3169	1.1831	1.1163	1.3608
15	.417	.4475	.4459		1.1831	1.2757	
16	.3841	.4321	.3976	1.3004	1.1831	1.1095	1.2181
17	.4115	.4218	.4083		1.1831	1.1163	
18	.439	.3961	.3761	.2963	.3138	.3944	.3073
19		.3498	.3922		.4012	.3827	
20	.4938	.3704	.4567	.3841	.4167	.3189	
21		.4372	.4567		.4475	.4518	
22	.4938	.4887	.467	.4664	.4733	.4674	
23	.4938	.4887	.4995	.439	.4835	.4459	
24	.4774	.4938	.4887	.4778	.4664	.463	.4465
Max	1.3169	1.1797	3.9638	1.3169	1.2455	1.2912	1.3608
Min	.3841	.3292	.2984	.2963	.2908	.2829	.2524
Avg	.7320	.5353	.7529	.5661	.7373	.6590	.6319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344019 / 33 KV KARMARGAON SUB STATION

Feeder No / Name : 201 / 11 KV KAMARGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9061				.5937		
2	.8905				.6249		
3	.9374				.6093		
4	.828				.5937		
5	.8436				.4999		
6	.8436				.5155		
7	.9061				.4687		
8	1.0155				.6405		.5937
9	.9061				.6405		.6405
10	.9686				.6405		.5937
11	.9374		.3963		.6562		.5468
12	.953		.4218	.9998			.3906
13	.9061		.4374				.3906
14	.8749	.4725	.4374				.3281
15	.6562		.6562			.3201	.5312
16	.7499		.6718				.5312
17	.7655		.8124	.5312			.6718
18	.7811		.6562				.6718
19	.7811		.703				.7343
20			.6874				.703
21			.5937				.6718
22			.6874				.6562
23			.9374				.9686
24	.9217		.442		.6249		
Max	1.0155	.4725	.9374	.9998	.6562	.3201	.9686
Min	.6562	.4725	.3963	.5312	.4687	.3201	.3281
Avg	.8686	.4725	.6100	.7655	.5924	.3201	.6015

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344019 / 33 KV KARMARGAON SUB STATION

Feeder No / Name : 202 / 11 KV KAMARGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717				1.406		
2	1.3546				1.3032		
3	1.1831				1.2689		
4	1.1145				1.2003		
5	1.2003				1.1145		
6	1.2517				1.0288		
7	1.1831				1.0802		
8	1.0974				.9945		.9945
9	1.046				.9774		1.0117
10	1.0802				.9774		1.0117
11	1.0631		1.166				1.0117
12	1.0631		1.1831	1.0974			1.046
13	1.166		1.2174				.953
14	1.2003	1.2003	1.2174			1.2003	1.0467
15	1.166		1.2174				1.0974
16	1.1488		1.0117				1.0974
17	1.1317		1.0117	1.0288			.9259
18	1.1145		1.0631				
19	1.286		1.3717				1.3032
20			1.5604				1.5432
21			1.5089				1.4918
22			1.5775				1.4918
23							1.406
24	1.4403		1.4746		1.3717		
Max	1.4403	1.2003	1.5775	1.0974	1.406	1.2003	1.5432
Min	1.046	1.2003	1.0117	1.0288	.9774	1.2003	.9259
Avg	1.1831	1.2003	1.2755	1.0631	1.1566	1.2003	1.1621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344019 / 33 KV KARMARGAON SUB STATION

Feeder No / Name : 204 / 11 KV KAMARGAON INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0133				.0137	
2	.0133				.0137	
3	.0133				.0137	
4	.0133				.0137	
5	.0133				.0137	
6					.0137	
7	.0133				.0137	
8	.0133				.0137	.0133
9	.0133				.0137	.0133
10	.0133				.0137	.0133
11	.0133		.0133			.0133
12			.0137	.0137		.0133
13	.0133		.0137			.0133
14	.0133	.0152	.0137			.0133
15	.0133		.0137			.0133
16	.0133		.0137			.0133
17	.0133		.0137	.0137		.0133
18	.0133		.0137			.0133
19	.0133		.0137			
20	.0133		.0137			.0133
21						.0133
22						.0133
23						.0133
24	.0133		.0133		.0137	
Max	.0133	.0152	.0137	.0137	.0137	.0133
Min	.0133	.0152	.0133	.0137	.0137	.0133
Avg	.0133	.0152	.0136	.0137	.0137	.0133

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344019 / 33 KV KARMARGAON SUB STATION

Feeder No / Name : 205 / 11 KV KHERDA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715				.1886		
2	.1715				.1715		
3	.1715				.1372		
4	.1715				.0857		
5	.1715				.12		
6	.1715				.0857		
7	.1543				.12		
8	.1372				.1029		.12
9	.1372				.1029		.12
10	.1372				.1029		.12
11	.1372		.1372				.12
12	.1543		.1372				.1372
13	.1715		.1372				.1372
14	.1715	.1715	.1372			.1715	.1543
15	.1715		.1372				.1029
16				.4687			.1029
17			.1097	.1372			.1372
18			.1097				.1372
19			.1886				.1372
20							.2058
21							.0133
22							.2058
23							.1886
24	.1715		.2058		.1886		
Max	.1715	.1715	.2058	.4687	.1886	.1715	.2058
Min	.1372	.1715	.1097	.1372	.0857	.1715	.0133
Avg	.1608	.1715	.1444	.3030	.1278	.1715	.1337

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344020 / 33 KV UMBARDA BAZAR SUB

STAT

Feeder No / Name : 201 / 11 KV SOMTHANA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1612
2				.4477	.381	.4268	.1612
3				.4477	.381	.4268	.6184
4				.4477	.381	.4268	.6489
5				.4477	.381	.4268	.6489
6				.4835	.4115	.4268	.7278
7				.6984	.6249	.5796	.9591
8				.7701	.3506		1.0254
9				.1433	.2439	.1858	.7453
10	.6859	.788	.7343				.061
11	.6859	.8417	.788				
12	.7042	.7164	.7343				
13	.6722	.6447	.5731				
14	.6401	.6447	.6089				
15	.5601	.6001	.6089				
16	.6081	.6626	.6089				
17	.7042	.7701	.6626				
24						.1524	.1791
Max	.7042	.8417	.788	.7701	.6249	.5796	1.0254
Min	.5601	.6001	.5731	.1433	.2439	.1524	.061
Avg	.6576	.7085	.6649	.4858	.3944	.3815	.5397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344020 / 33 KV UMBARDA BAZAR SUB

STAT

Feeder No / Name : 202 / 11 KV UMBARDA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5544	.5014	.7164				
3	.5544	.5014	.7164				
4	.5544	.5552	.7164				
5	.5544	.6447	.7164				
6	.6283	.7522	.7522				
7	.8316	.8596	.8596				
8	.9425	.9671	1.0924				
9	.9795	.9671	1.0208				
10				1.1946	1.3213	2.1758	2.3834
11				1.3213	1.1946	1.1888	2.9169
12				1.1584	1.2127	2.353	2.6064
13				1.086	1.0745	1.0679	2.4616
14				1.0498	1.0498	2.0424	2.4806
15				1.0317	.9593	1.9643	2.372
16				1.0136	1.1041	2.1396	2.4625
17				1.1946	1.1765	2.4006	2.6807
18						.4572	1.2498
Max	.9795	.9671	1.0924	1.3213	1.3213	2.4006	2.9169
Min	.5544	.5014	.7164	1.0136	.9593	.4572	1.2498
Avg	.6999	.7186	.8238	1.1313	1.1366	1.7544	2.4015

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344020 / 33 KV UMBARDA BAZAR SUB

STAT

Feeder No / Name : 203 / 11 KV UMBARDA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.9335	.9896	.9335	.9522	.8962	.8962
2	.9522	.9149	.9335	.8962	.9335	.8402	.8962
3	.9335	.9149	.9709	.8962	.9335	.8215	.8962
4	.9335	.8775	.9335	.8962	.9335	.7468	.8962
5	.9335	.8215	.9149	.8402	.9335	.6535	.8589
6	.8402	.7468	.8215	.7842	.8402	.6908	.7655
7	.5975	.6348	.6535	.6535	.6348	.5914	.6535
8	.6348	.5601	.5975	.5975	.5788	.5359	.6348
9	.5975		.5544	.6348	.6161	.499	
10	.6161	.5975	.5975	.5601	.5975	.462	.5975
11	.5788	.5788	.5788	.5788	.5975	.6283	.5975
12	.6722	.6535	.6535	.6535	.6722	.6722	.6908
13	.6722	.7095	.7468	.7095	.7282	.7095	.7468
14	.8029	.7282	.7655	.7468	.7468	.7468	
15	.8215	.7468	.7468	.8029	.7655	.7655	
16	.7468	.7468	.6722	.7468	.7468	.6908	.7842
17	.6348	.6535	.6535	.5601	.7095	.5975	.6722
18	.6161	.7468	.6722	.5788	.7095	.6161	.6161
19	.7842	.7842	.8962	.7468	.6722	.6535	.6535
20	1.0269	1.0269	.9896	.9335	.9335	.9522	.9149
21	1.0642	1.0456	1.0269	1.0456	.9709	.9896	1.0082
22	1.0269	1.0269	1.0642	1.0456	1.0269	.9896	1.0269
23	.9709	1.0269	.9896	1.0269	.9709	.9335	.9896
24	1.0082	.9709	1.0082	.9522	.9709	.8962	.9149
Max	1.0642	1.0456	1.0642	1.0456	1.0269	.9896	1.0269
Min	.5788	.5601	.5544	.5601	.5788	.462	.5975
Avg	.8098	.8020	.8096	.7842	.7990	.7324	.7957



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 201 / 11 KV DHANAJ AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4554	.4934	.4554			
3	.4554	.4934	.4554			
4	.4554	.4934	.4554			
5	.4744	.4934	.4554			
6	.5882	.4934	.4554			
7	.6831	.5313	.6072			
8	.7211	.5693	.6072			
9	.6831	.6072	.5693			
10			.5693	.7401	.5693	.5123
11			.4175	.6072	.7021	.5503
12			.3795	.5313		.6831
13			.3416	.4175	.4364	.4744
14			.3036	.3036	.3795	.4934
15			.3416	.3416	.3416	.4554
16			.4364	.4554	.2467	.5503
17			.5693	.4934	.0949	.6262
Max	.7211	.6072	.6072	.7401	.7021	.6831
Min	.4554	.4934	.3036	.3036	.0949	.4554
Avg	.5645	.5219	.4637	.4863	.3958	.5432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 202 / 11 KV RAHATI AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.517	.517
2	.4784			.6786	.517	.517
3	.4784			.6786	.517	.517
4	.4784			.6786	.517	.517
5	.5422			.8078	.5493	.5493
6	.7654			.8078	.6462	.6462
7	.4784			.8724	.6786	.517
8	.6857	.1648		.8401	.7755	.5978
9	.6698			.7109	.6462	.4847
10	.7016	1.0123	.8164			
11	.6427	.8817	.8164			
12	.607	.8164	.8164			
13	.5103		.6531			
14	.5103	.6531	.5878			
15	.607	.6204	.5816			
16	.606	.6531	.6139			
17	.8205	.6531	.6786			
24						.5008
Max	.8205	1.0123	.8164	.8724	.7755	.6462
Min	.4784	.1648	.5816	.6786	.517	.4847
Avg	.5989	.6819	.6955	.7594	.5960	.5364

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 203 / 11 KV GAS PLANT EXP.

NON SHEDDABLE EXPRESS HV FEEDERS

FEEDER Feeder KV- 11 /

(CONTINUOUS PROCESS)(NO STAGGERING)

OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.057	.0761	.0761	.0761	.0761	.0761	.0761
2	.057	.0761	.0761	.0761	.0761	.0761	.0761
3	.057	.0761	.0761	.0761	.0761	.0761	.0761
4	.0761	.0761	.0761	.0761	.0761	.0761	.0761
5	.0761	.0761	.057	.0761	.0761	.0761	.0761
6	.0951	.0951	.057	.1141	.0761	.0951	.0951
7	.1901	.1901	.1711	.1711	.1901	.1901	.0951
8	.2092	.1901		.1901	.1901	.1711	.0951
9	.1711	.1901	.038	.1708	.1521	.1711	.1141
10	.1901	.1901	.1901	.171	.1521	.2092	.0951
11	.1521	.1521	.171	.1901	.1521	.2092	.0761
12	.1711	.1711	.152	.1901	.1711	.1711	
13	.1521		.1331	.057	.1711	.1521	.057
14	.1521	.1331	.1521	.1521	.1521	.1331	.057
15	.1521	.1711	.1521	.2746	.1521	.1331	
16	.1711	.1711	.1521	.1711		.1331	
17	.1901	.1901	.1711	.1711	.1521	.0761	.057
18	.1901	.1899	.1898	.1901	.1711	.038	.057
19	.2282	.2282	.2469	.2282	.2092	.038	.0761
20	.2282	.2282	.2092	.2282	.2092		.0759
21	.1901	.1901	.2092	.2282	.1711	.057	.0761
22	.0951	.0951	.0761	.0761	.057		.0951
23	.0761	.0761	.0761	.0761	.0761	.0951	.0951
24	.0761	.0761	.0761	.0761	.0761	.0761	.0761
Max	.2282	.2282	.2469	.2746	.2092	.2092	.1141
Min	.057	.0761	.038	.057	.057	.038	.057
Avg	.1418	.1438	.1298	.1461	.1331	.1150	.0797

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 204 / 11 KV DHANAJ GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0062	1.0545	.9649	.9649	1.073	.999	.999
2	1.0062	1.0175	.9689	.9649	1.0577	1.0041	1.0041
3	1.0051	1.0185	.9689	.964	1.0392	1.0051	1.0051
4	.9669	1.0185	.9307	.963	1.0185	.9689	.9689
5	.925	1.0185	.9297	.925	1	.9297	.9307
6	.5782	.9649	.8925	.8861	.8519	.8935	.8843
7	.6852	.793	.7052	.6817	.8333	.7423	.6852
8	.6653	.7008	.5332	.618	.7407	.5895	.6381
9	.5481	.6011	.5847	.6564	.703	.6774	.618
10	.6199	.7278	.5889	.6753	.7407	.7331	.6134
11	.7007	.7538	.681	.6943	.5556		.7293
12	.6388	.7285	.7331	.8039	.695		.7278
13		.817	.5504	.6943	.7308	.9531	.765
14		.8022	.5841	.6578	.7507	.9318	.7832
15	.9078	.8378	.6225	.4539	.7666	.9318	.6746
16	.8897	.8056	.6238	.5804	.7674	.8779	.7848
17	.8196	.7468	.7155	.5079	.7324	.7642	.7126
18	.7538	.6543	.7088	.7906	.6899	.7118	.6212
19	.9299	.8098	.8431	.9135	.8073	.8265	.8325
20	1.1851	1.073	1.1088	1.1655	1.1088	1.0915	1.184
21	1.2034	1.1157	1.1145	1.2285	1.1088	1.1285	1.1493
22	1.1487	1.0402	1.0796	1.1667	1.1123	1.1111	1.1134
23	1.1296	1.036	1.0413	1.1296	1.073	1.0741	1.0752
24	.6845	1.073	.999	.999	1.1111	1.0349	1.0196
Max	1.2034	1.1157	1.1145	1.2285	1.1123	1.1285	1.184
Min	.5481	.6011	.5332	.4539	.5556	.5895	.6134
Avg	.8635	.8837	.8114	.8369	.8778	.9082	.8550

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344021 / 33 KV DHANAJ SUB STATION

Feeder No / Name : 205 / 11 KV RAHATHI GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3479	.3551	.354	.3479	.354	.354
2	.3522	.3479	.3558	.354	.3296	.3551	.3551
3	.3515	.3479	.3558	.3537	.3296	.3558	.3547
4	.3306	.3296	.3368	.3347	.3296	.3368	.3368
5	.3109	.3296	.3174	.3151	.3113	.3177	.3177
6	.2752	.2929	.2795	.2595	.2014	.2609	.2609
7	.2033	.1831	.242	.2405	.2014	.2029	.1651
8	.2225	.1648	.2029	.2033	.2014	.202	.1831
9	.2236	.2014	.239	.2574	.2197	.2202	.1808
10	.1856	.2014	.202	.2385	.2197	.2016	.1825
11	.2197	.2197	.2202	.2388	.238		.2012
12	.238	.2385	.239	.2571	.2569	.2772	.238
13	.2929		.2571	.2204	.2746	.296	.2746
14	.2929	.2929	.2746	.2755	.2926	.2781	.3113
15	.2746	.3116	.2752	.1743	.2936	.2951	.2746
16	.2746	.2936	.2571	.2929	.2755	.2571	.2746
17	.2197	.2749	.2385	.2746	.2752	.1831	.238
18	.2014	.2388	.2014	.2746	.2204	.1653	.2197
19	.238	.2942	.2926	.2563	.2929	.2398	.238
20	.3662	.3696	.3881	.3482	.3861	.3511	.3113
21	.3845	.3696	.3337	.35	.3688	.37	
22	.3845	.3719	.3711	.3479	.3696	.3504	.3662
23	.3662	.3526	.3719	.3685	.37	.3482	.3845
24	.3515	.3669	.3522	.3533	.35	.3522	.3326
Max	.3845	.3719	.3881	.3685	.3861	.37	.3845
Min	.1856	.1648	.2014	.1743	.2014	.1653	.1651
Avg	.2880	.2931	.2900	.2893	.2898	.2857	.2763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 201 / 11 KV POHA INDUSTRIAL

SHEDDABLE FEEDER HAVING WEEKLY

FEEDER Feeder KV- 11 /

STAGGERING (MIDC, EQUIVALENT)

OUTGOING

DATE	15-MAY-17	16-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.2987		.2614	.2402
2	.3547	.2987		.2614	.2218
3	.3734	.3174		.2801	.2033
4	.3734	.2987		.2614	.2218
5	.3734	.2801		.2614	.2402
6	.2241	.3547		.2801	.2561
7	.2614	.4481		.3734	.2561
8	.1867	.4066		.3734	.2743
9	.2241	.3921		.3921	.3326
10		.5041		.3547	.3658
11		.5788		.3547	.3772
12	.2075	.6161	.3361	.3696	.3961
13	.2241		.3174	.3841	.3734
14	.2427		.3361		.2987
15	.2427		.2801		.2614
16	.2614		.3174	.2926	.2614
17	.2801		.3361	.3109	.2452
18	.2801		.3174	.3224	.2075
19	.2427		.3174	.3224	.2241
20	.2054		.3174	.3142	.2263
21	.1886		.2427	.2957	.2241
22			.2987	.2926	.2241
23	.2427			.2801	.2452
24	.3361	.2987		.2801	.2402
Max	.3734	.6161	.3361	.3921	.3961
Min	.1867	.2801	.2427	.2614	.2033
Avg	.2705	.3918	.3106	.3145	.2674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 202 / 11 KV POHA GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.6024		.4908	.6219
2	.5792	.6089		.4908	.6219
3	.5792	.6089		.4908	.6219
4	.567	.6089		.4908	.5853
5	.543	.5731		.4908	.5853
6	.3982	.5316		.4908	.5792
7	.4344	.4607		.4908	.4706
8	.3506	.4344		.4207	.362
9	.3734	.394		.4207	.3982
10		.3582		.4207	.4344
11		.394		.4207	.4344
12	.3224	.4252	.3982	.394	.439
13	.3544		.4706	.3898	.439
14			.362		.4344
15	.3856		.362		.4656
16	.4298		.362	.4961	.4656
17	.4656		.2896	.4252	.5121
18	.4557		.3856	.3856	
19	.6447		.5258	.5731	.6516
20	.7164		.7011	.6154	.724
21	.7164		.6661	.6516	.7164
22			.6661	.6584	.6154
23	.6516			.6516	.5853
24	.6154	.6024		.4908	.6154
Max	.7164	.6089	.7011	.6584	.724
Min	.3224	.3582	.2896	.3856	.362
Avg	.5081	.5079	.4717	.4932	.5382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 203 / 11 KV SOOTGIRNI EXPRESS      NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 11 / OUTGOING      (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0366
2		.0381	.0366
3		.0381	.037
4		.0381	.0362
5		.0381	.0362
6		.0381	.0358
7		.0381	
8		.0381	
9		.1143	.1075
10		.362	.1097
11		.1143	.112
12	.0953	.1387	.0943
13	.0953	.1174	.1143
14	.0953		.1143
15	.0953		.1143
16	.0953	.0678	.1143
17	.0953	.0678	.0953
18	.0953	.0678	.1143
19	.0953	.0867	.1524
20	.0953	.0373	.1509
21	.0381	.037	.1524
22	.0381	.037	.1524
23			.1143
24		.0381	
Max	.0953	.362	.1524
Min	.0381	.037	.0358
Avg	.0849	.0758	.0967



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 204 / 11 KV KINHI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1578		.1494	.1646
2	.1494	.1595		.1494	.1629
3	.1307	.1595		.1307	.1629
4	.1307	.1417		.1307	.1646
5	.1307	.1417		.1307	.1629
6	.1307	.1227		.112	.124
7	.112	.1052		.0934	.1063
8	.0934	.0886		.0747	.0886
9	.056	.0886		.0747	.0886
10		.0886		.0747	.0709
11		.0886			.0886
12	.1097	.0876		.0886	.0886
13	.1254		.112	.0886	.1075
14	.1254		.112		.1433
15	.1417		.112		.1463
16	.1433		.0934	.1063	.1267
17	.1254			.0867	.1086
18	.1063		.0934	.1052	.0724
19	.1612		.112	.1402	
20	.1791		.1494	.1829	.197
21	.1991		.168	.1829	.1991
22			.168	.1829	.1772
23	.1629			.181	.1629
24	.168	.1595		.1494	.181
Max	.1991	.1595	.168	.1829	.1991
Min	.056	.0876	.0934	.0747	.0709
Avg	.1348	.1223	.1245	.1245	.1346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 205 / 11 KV WAI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	19-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3688		
2	.4108			
3	.4108	.3688		
4	.4294	.3688		
5	.4294	.3978		
6	.4108	.3978		
7	.4481	.3812		
8	.4108	.3978		
9	.4481	.3812		
10		.3812		.4294
11		.3481		.4294
12	.4207			.3812
13	.4508		.4108	.3647
14	.4334		.4108	
15	.4508		.4294	
16	.4508		.4108	.3563
17	.4784		.4108	.3481
18	.4508			.407
19	.4382			.4239
20	.4252			
21	.4298			
23	.4115			
24	.4481	.4024		
Max	.4784	.4024	.4294	.4294
Min	.4108	.3481	.4108	.3481
Avg	.4332	.3813	.4145	.3925

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 206 / 11 KV WAI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4607		.5228	.5068
2	.4481	.4656		.4854	.5068
3	.4481	.4607		.4854	.5068
4	.4481	.4607		.4854	.5014
5	.4481	.4557		.5228	.5068
6	.4108	.4207		.5228	.4961
7	.4108	.3506		.4481	.3856
8	.2987	.3224		.4108	.3189
9	.2987	.2865		.3734	.3506
10		.2865		.3361	.5258
11		.2804		.3361	.3506
12	.2835			.3506	.362
13	.3121		.3734	.3506	.3224
14	.3121		.3361		.3189
15	.3506		.3734		.3045
16	.3544		.3734	.3856	.2865
17	.3155		.2987	.3506	.2835
18	.2835		.3361	.3189	.2835
19	.4252		.4481	.5014	.4607
20	.5014		.5975	.5731	.5731
21	.5014		.5975	.5731	.5792
22				.5792	.543
23	.5014			.5487	.5068
24	.4481	.4607		.5228	.5373
Max	.5014	.4656	.5975	.5792	.5792
Min	.2835	.2804	.2987	.3189	.2835
Avg	.3928	.3926	.4149	.4538	.4299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344022 / 33 KV POHA SUB STATION

Feeder No / Name : 207 / 11 KV KINHI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.6722	.4161
3			.6722	.4161
4			.6348	.4508
5			.6348	.5201
6			.6722	.5375
7			.7282	.6068
8			.7095	.6241
9			.6722	.6241
10		.6783		.6415
11		.6783		.631
12	.7442	.6613		.5895
13	.6859			.5609
14	.6588			.5201
15	.5028			.5895
16	.7537			.5895
17	.7888			.6516
Max	.7888	.6783	.7282	.6516
Min	.5028	.6613	.6348	.4161
Avg	.6890	.6726	.6745	.5606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344026 / 33 KV DHANORA SUB STATION

Feeder No / Name : 201 / 11 KV DHANORA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4499	.5233	.4545	.4701	.4476	.4476
2		.4481	.5233	.4527	.4513	.4476	
3	.4696	.4486	.5041	.4527	.4513		.4476
4	.4513		.5046	.4527	.4513	.4294	.429
5		.4504	.5062				
6	.4531	.4508	.4673	.4338	.4137	.3921	.4108
7		.4154	.4312		.3949		
8	.3142	.3925	.4112	.3395	.5265	.3917	.299
9	.2911	.3765	.3738	.3584	.3388		.3925
10	.2993	.3765	.3738	.3893	.3388	.3761	
11		.299		.4658			.3551
12	.3021	.3177	.3402	.3354	.3388	.3388	.5233
13	.3398		.378				
14	.4303	.3551	.4158	.3925	.3761	.4141	.3925
15	.4522	.3734	.4158	.4112	.526		
16	.4692	.3551	.3591	.4312	.3569	.4518	.3551
17	.3587			.4312	.3381		.3381
18	.3587	.3177	.3598	.3937	.3569	.3949	.3206
19	.4003	.4124	.5108	.3941	.429		.4677
20	.472	.5046	.5297	.5453	.5217	.5426	.5239
21	.5221	.5464	.5297	.5265	.5217	.5442	.5303
22	.5221	.5276	.5297	.5265	.5031		
23	.4676	.5233	.473	.4701	.4658	.4692	.4924
24	.4874	.5041	.5249	.473	.4701	.4658	.4692
Max	.5221	.5464	.5297	.5453	.5265	.5442	.5303
Min	.2911	.299	.3402	.3354	.3381	.3388	.299
Avg	.4173	.4212	.4539	.4348	.4305	.4361	.4232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344026 / 33 KV DHANORA SUB STATION

Feeder No / Name : 202 / 11 KV DHANORA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.669					.7935	.7945
3	.669					.7935	.7945
4	.7008					.8262	.8262
5	.7008					.858	.8898
6	.7964					.8898	.8898
7	.9556					.9851	.984
8	1.0831					1.0805	1.0779
9	1.0194					1.0157	1.1096
10	1.0764	.9875	.9534	.9545			
11	1.0364	1.1399	1.0805	1.034			
12	1.023	1.1772	.9851	1.0328			
13	1.0194	1.0766	1.001	1.001			
14	.8745	1.0818	.9534	.9216			
15	1.0194	1.1083	.9057	.9057			
16	1.055	1.1123	1.001	1.001			
17	.8909	1.144		.9693			
18			.9057				
23					.9851		
Max	1.0831	1.1772	1.0805	1.034	.9851	1.0805	1.1096
Min	.669	.9875	.9057	.9057	.9851	.7935	.7945
Avg	.9118	1.1035	.9732	.9775	.9851	.9053	.9208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344026 / 33 KV DHANORA SUB STATION

Feeder No / Name : 203 / 11 KV LONI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.3029	1.2605	.737	.8781		
3		1.3379	1.292	.737	.8781		
4		1.3187	1.2967	.737	.8781		
5		1.3235	1.2967	.7526			
6		1.3347	1.2605	1.0505	.9408		
7		1.3363	1.2605	1.0976			
8		1.3501	1.292	1.0035	1.2701		
9		1.2711	1.2635	1.1917	1.176		
10					.9721	1.0011	.9061
11					.9094	1.0324	.9061
12					.9408	.9396	.9061
13					.8144	.9083	.8749
14					.7204	.8457	
15					.7517	.8457	.7655
16					.783	.783	.8749
17					.8144	.7821	.9998
23							.7499
24	1.1902	1.1902					
Max	1.1902	1.3501	1.2967	1.1917	1.2701	1.0324	.9998
Min	1.1902	1.1902	1.2605	.737	.7204	.7821	.7499
Avg	1.1902	1.3073	1.2778	.9134	.9091	.8922	.8729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344027 / 33 KV KAKADSHIVANI SUB

STATION

Feeder No / Name : 201 / 11 KV SHAHA AG FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	18-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
2			.884
3			.9145
4			.9145
5			.9259
6			.9568
7			.9568
8			.9877
9			.9755
10	1.1584	1.3272	
11	1.1584	1.2498	
12		1.2346	
13		1.0974	
14		.9145	
15		.823	
16		.823	
17		.823	
Max	1.1584	1.3272	.9877
Min	1.1584	.823	.884
Avg	1.1584	1.0366	.9395



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344027 / 33 KV KAKADSHIVANI SUB

STATION

Feeder No / Name : 202 / 11 KV KAKADSHIVANI AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	17-MAY-17	18-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2972	.3814	
3		.3567		
4		.3567	.4108	
5		.3567		
6		.3864	1.2003	
7		.4161	1.2136	
8		.3658	.3814	
9		.3567	.3814	
10				.4108
11			1.0631	
12			.9709	.3913
13	.1806		1.0402	
14	.208		.9709	.3612
15	.2972			.3658
16	.4161			.1219
17	.5053			.4268
18	.5053			.3612
19	.3864			.301
Max	.5053	.4161	1.2136	.4268
Min	.1806	.2972	.3814	.1219
Avg	.3570	.3615	.8014	.3425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344027 / 33 KV KAKADSHIVANI SUB

STATION

Feeder No / Name : 203 / 11 KV KAJLESHWAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-MAY-17	18-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1218		1.134
2		1.1218	1.1443	1.1218
3		.7712		1.1218
4		1.0517	1.1443	1.1218
5		1.0517		1.0974
6		1.0517		1.1218
7		.8764		1.1218
8		.9465		1.0288
9		1.0517	1.0402	.9945
10		1.0056	1.0749	1.0174
11		1.0056		.9496
12	.9835			.9156
13	.9496			.9259
14	.9496			.8669
15	.9945			.9015
16	1.0056			.823
17	.9835			.8322
18	.9835			.9945
19	1.3466			1.0288
20	1.262		1.0517	1.2003
21	1.2269		1.1218	1.2483
22	1.1568		1.1919	1.3375
23			1.2048	1.0288
24		1.1568	1.2048	1.1191
Max	1.3466	1.1568	1.2048	1.3375
Min	.9496	.7712	1.0402	.823
Avg	1.0766	1.0177	1.1310	1.0439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344027 / 33 KV KAKADSHIVANI SUB

STATION

Feeder No / Name : 401 / 33 KV KAMARGAON FEEDER

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	17-MAY-17	18-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.8292		2.696
2		2.7469	2.4862	2.5206
3		2.696		2.2634
4		2.6235	2.3613	2.1091
5		2.5206		2.1091
6		2.4691	2.2989	1.9547
7		2.3663	2.2781	1.8519
8		2.3663	2.0389	1.9033
9		2.4691	2.2313	2.2119
10		2.3148	2.1117	
11		2.1605	1.8158	2.0319
12	2.0856		2.0576	1.8621
13	1.8519		1.857	1.9907
14	1.4403		1.8982	1.5278
15	2.3148		1.4752	1.965
16	2.3663		1.3226	1.9856
17	2.3908		1.2717	2.0833
18	1.286		1.2346	2.1759
19	2.7343		2.5206	2.6389
20	2.6749		2.6235	2.9784
21	2.7778		2.6749	2.8652
22	2.7778		2.7263	2.608
23	2.7778		2.8292	2.8601
24		2.8292	2.507	2.7469
Max	2.7778	2.8292	2.8292	2.9784
Min	1.286	2.1605	1.2346	1.5278
Avg	2.2899	2.5326	2.1248	2.2583

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 201 / 11 KV MANORA ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.2957	.2587	.1848	.2195	.2402
2		.2743	.2957	.2587	.1848	.2218	.2402
3		.2587	.2926	.2587	.1848	.2218	.2402
4		.2561	.2218	.2587	.1848	.2195	.2402
5		.2378	.2195	.2587	.2033	.2195	.2218
6		.2195	.1848	.2587	.2033	.2195	.2218
7		.2012	.2218	.2587	.1991	.2378	.2195
8		.2378	.2218	.2218	.2033	.2012	.2218
9		.2218	.2012	.2195	.1848	.2012	.2195
10		.2033	.2012	.181	.1848	.2012	.2149
11		.2033	.2012	.1829	.2218	.2033	.197
12		.1848	.2012	.1848	.2218	.2012	.2149
13	.181	.1848	.2561	.1848	.2378	.2012	.2353
14	.181	.1848	.2561	.1848	.2587	.2012	.2534
15	.1991	.1848	.2534	.2033	.2587	.2012	.2534
16	.2353	.1848	.2353	.2033	.2587	.2012	.2534
17	.2378	.1848	.2587	.2033	.2402	.2033	.2402
18	.2378	.2033	.2218	.1848	.2587	.2218	.2353
19	.2172	.2402	.2218	.1848	.2772	.2378	.2378
20	.2743	.2561	.2587	.1848	.2772	.2587	.2402
21	.2743	.2743	.2587	.2033	.2772	.2772	.2353
22	.2926	.2957	.3142	.2033	.2772	.2587	.2353
23	.2926	.2926	.2587	.2033	.2957	.2772	.2172
24	.2743	.2743	.2957	.2587	.1991	.2195	.2587
Max	.2926	.2957	.3142	.2587	.2957	.2772	.2587
Min	.181	.1848	.1848	.181	.1848	.2012	.197
Avg	.2414	.2306	.2437	.2168	.2282	.2219	.2328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 202 / 11 KV OLD TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.5873	2.5873	2.2177	2.4025	2.2862	2.4025
2		2.5503	2.5873	2.0328	2.1068	2.1948	2.3777
3		2.5133	2.5133	2.0328	2.0328	2.0119	2.4025
4		2.4253	2.4025	1.9959	2.0328	2.0328	2.2177
5		2.4025	2.2546	1.9959	1.9959	1.829	2.0883
6		2.1068	2.1253	1.9959	1.8099	1.829	1.9959
7		1.9959	1.8665	1.9035	1.8111	1.848	1.8296
8		1.8642	1.8107	1.7741	1.7737	1.8296	1.7556
9		1.885	1.9022	1.7924	1.9774	1.8656	1.7375
10		2.0328	1.9753	1.9753	2.0513	1.8656	1.7551
11		2.0328	2.1582	2.1033	2.2546	1.9387	1.7551
12		2.1807	2.1948	2.1582	2.3101	1.9387	1.8983
13	2.268	2.2177	2.2862	2.2177	2.3411	2.0271	2.0995
14	2.4253	2.3101	2.3411	2.4025	2.4209	2.1033	2.0995
15	2.4072	2.4025	2.4072	2.3101	2.4209	2.1948	2.1582
16	2.4949	2.4394	2.4326	2.3101	2.4209	2.2262	2.1176
17	2.2805	2.4394	2.347	2.3285	2.4764	2.2916	2.0851
18	2.2497	2.1399	2.2177	2.3655	2.2546	2.2916	2.2314
19	2.3348	2.3655	2.4025	2.4949	2.3285	2.2916	2.3777
20	2.4508	2.4394	2.4394	2.5503	2.4025	2.4025	2.4874
21	2.4874	2.4508	2.5503	2.5503	2.4394	2.4691	2.5503
22	2.5606	2.5133	2.5503	2.4949	2.5503	2.4764	2.4691
23	2.7069	2.5606	2.5133	2.4434	2.5503	2.4874	2.3777
24	2.6155	2.6427	2.5873	2.5133	2.4949	2.4691	2.4394
Max	2.7069	2.6427	2.5873	2.5503	2.5503	2.4874	2.5503
Min	2.2497	1.8642	1.8107	1.7741	1.7737	1.829	1.7375
Avg	2.4401	2.3124	2.3105	2.2066	2.2358	2.1334	2.1545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 203 / 11 KV GAWALIPURA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2177	2.2546	2.1253	2.1719	2.0328	2.1992
2		2.2177	2.2314	2.1253	2.1253	2.0119	2.1992
3		2.1807	2.2177	2.0328	2.1253	1.9204	2.1807
4		2.1472	2.1437	2.0328	2.0328	1.9204	2.1068
5		2.1068	2.0328	2.0328	1.9959	1.8656	1.9204
6		2.0144	1.9774	2.0328	1.848	1.8656	1.885
7		1.922	1.848	1.9035	1.829	1.885	1.8111
8		1.8671	1.7926	1.8296	1.8296	1.8107	1.7741
9		1.7002	1.7558	1.7375	1.7741	1.7924	1.7741
10		1.7556	1.8111	1.7737	1.7924	1.8461	1.7372
11		1.848	1.7556	1.7194	1.848	1.8656	1.7013
12		1.885	1.6644	1.7194	1.885	1.922	1.7556
13	1.8858	1.9404	1.7558	1.848	1.922	1.9204	1.7741
14	1.8665	1.9404	1.6827	1.9404	1.922	1.9366	1.8298
15	1.9589	1.9404	1.8839	1.9404	1.922	1.957	1.9231
16	1.9404	1.9404	1.9204	1.9404	1.9022	1.957	1.885
17	1.8296	1.9404	1.7741	2.0328	1.922	1.9936	1.8839
18	1.885	1.7926	1.7926	2.1068	1.885	2.0144	2.0119
19	2.0538	2.1437	1.9404	2.1582	1.9959	2.0144	2.1582
20	2.2032	2.1622	2.1253	2.2916	2.0328	2.1033	2.2862
21	2.2405	2.2177	2.2177	2.2546	2.1622	2.1216	2.2314
22	2.3339	2.2314	2.2546	2.2546	2.2546	2.2314	2.1582
23	2.3712	2.2916	2.2361	2.1719	2.2546	2.2497	2.1033
24	2.2862	2.2965	2.2546	2.2361	2.2177	2.1948	2.1992
Max	2.3712	2.2965	2.2546	2.2916	2.2546	2.2497	2.2862
Min	1.8296	1.7002	1.6644	1.7194	1.7741	1.7924	1.7013
Avg	2.0713	2.0292	1.9718	2.0100	1.9854	1.9764	1.9787

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 204 / 11 KV KARANJA INDUSTRIAL

FEEDER Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6099	.6283	.5544	.5544	.6219	.7207
2		.5914	.6283	.5544	.5544	.6283	.7207
3		.5601	.6283	.5544	.5175	.6219	.7207
4		.5788	.6283	.5544	.5175	.6219	.6468
5		.5544	.6283	.5544	.5175	.6283	.5914
6		.5544	.6036	.5729	.5304	.6653	.5175
7		.5415	.5853	.6283	.5359	.6653	.6099
8		.5175	.5121	.6099	.5175	.5544	.5729
9		.5359	.5914	.6219	.6283	.543	.5975
10		.5144	.6099	.6283	.6653	.6219	.6348
11		.5914	.695	.6401	.7023	.6154	.5973
12		.6468	.7499	.6401	.7133	.695	.6348
13	.5544	.6468	.7865	.7023	.7316	.6878	.6161
14	.5544	.6468	.5853	.6653	.7499	.7316	.6099
15	.4481	.6838	.6468	.6468	.7499	.7316	.6161
16	.5544	.6838	.7947	.6468	.7577	.7602	.6535
17	.5975	.6838	.6653	.6468	.7392	.6219	.5973
18	.5975	.6722	.7207	.6401	.7023	.6219	.6401
19	.5544	.6838	.6653	.6584	.7577	.6036	.6401
20	.6653	.6838	.6283	.7023	.7577	.5853	.695
21	.5975	.6653	.7023	.6401	.7577	.5487	.6516
22	.6722	.6099	.7023	.6283	.7392	.4938	.6516
23	.5914	.5914	.5914	.5914	.7023	.4755	.6584
24	.6653	.5914	.6219	.5359	.5544	.6219	.7133
Max	.6722	.6838	.7947	.7023	.7577	.7602	.7207
Min	.4481	.5144	.5121	.5359	.5175	.4755	.5175
Avg	.5877	.6100	.6500	.6174	.6522	.6236	.6378

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 205 / 11 KV BYPASS TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2936	1.2197	1.2382	1.0498	1.1888	1.2567
2		1.2567	1.2071	1.0719	1.0719	1.0974	1.2382
3		1.2567	1.1706	1.0719	.961	1.0164	1.2382
4		1.1888	1.1458	1.0719	.961	1.0164	1.1088
5		1.1088	1.0719	1.0164	.924	1.0059	.9979
6		1.0059	1.0164	1.0164	.8871	.9328	.9425
7		.8779	.8779	.8686	.8316	.9328	.924
8		.7682	.8048	.7947	.7947	.8131	.8316
9		.7762	.7762	.7865	.8131	.8048	.7682
10		.8316	.7762	.7865	.8131	.9511	.7343
11		.8316	.8131	.823	.8048	.9511	.7522
12		.8686	.8048	.7865	.9055	1.0059	.8417
13	.9593	.924	.9694	.8316	.9877	1.0059	.9412
14	1.0498	.961	1.0164	1.0349	1.1088	1.0608	.9955
15	1.0498	.961	1.0317	1.0349	1.1088	1.0608	1.0317
16	.9774	1.0349	1.0136	1.0164	1.0903	1.0719	.9955
17	.9955	1.0349	.924	1.0719	.924	.924	1.0498
18	.9145	.924	.9055	1.1088	.8316	.924	1.0498
19	.9955	1.0349	1.0164	1.1458	1.0164	.8686	1.086
20	1.1088	1.1088	1.0534	1.2567	1.1088	1.0059	1.1888
21	1.0974	1.1827	1.2012	1.2567	1.1273	1.0534	1.2437
22	1.2254	1.2197	1.2382	1.2382	1.3306	1.2197	1.2197
23	1.3169	1.3169	1.2382	1.2382	1.3306	1.3121	1.2071
24	1.3169	1.2936	1.2197	1.2752	1.2382	1.2803	1.262
Max	1.3169	1.3169	1.2382	1.2752	1.3306	1.3121	1.262
Min	.9145	.7682	.7762	.7865	.7947	.8048	.7343
Avg	1.0839	1.0442	1.0213	1.0351	1.0009	1.0210	1.0377



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 206 / 11 KV BHILKHEDA INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY

FEE Feeder KV- 11 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.056	.0554	.037	.0554	.0366	.0554
2		.056	.0554	.037	.0554	.0366	.0554
3		.056	.0549	.037	.0362	.0366	.0554
4		.0554	.0554	.037	.037	.0366	.0554
5		.056	.0739	.037	.037	.0366	.056
6		.0554	.0739	.037	.037	.037	.0554
7		.056	.0739	.037	.0543	.0366	.0549
8		.056	.0739	.037	.0554	.0366	.0549
9		.0554	.0914	.0366	.0914	.0366	.056
10		.1848	.0905	.0366	.0924	.0366	.0747
11		.1848	.0905	.0366	.1294	.0366	.0739
12		.1848	.0905	.0366	.1294	.0366	.0747
13	.2957	.1848	.0914	.037	.0924	.0366	.0739
14	.2772	.1848	.0914	.037	.0914	.0366	.0747
15	.2772	.1848	.0905	.0924	.0924	.0362	.0739
16	.2957	.1848	.0914	.0924	.0914	.0366	.0747
17	.2987	.1848	.0924	.0924	.0924	.037	.0724
18	.2987	.1829	.0924	.0724	.0924	.0549	.0724
19	.2801	.1829	.0924	.0739	.0924	.0549	.0543
20	.2054	.1848	.0924		.0924	.0549	.0549
21	.056	.0924	.0924	.0739	.0857	.0549	.0549
22	.0554	1.7741	.0924	.0543	.0924	.0549	.0549
23	.056	.0914	.0739	.0554	.0924	.0549	.0549
24	.0549	.056	.0554	.0739	.0554	.0934	.0554
Max	.2987	1.7741	.0924	.0924	.1294	.0934	.0747
Min	.0549	.0554	.0549	.0366	.0362	.0362	.0543
Avg	.2043	.1894	.0803	.0521	.0781	.0436	.0622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 401 / 33 KV POHA FEEDER

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7558	1.885	1.6632	1.5524	1.5524	1.4415
2		1.6461	1.885	1.6632	1.7741	1.5524	1.4415
3		1.6461	1.885	1.6632	1.7375	1.5524	1.4415
4		1.6289	1.8656	1.6632	1.885	1.5524	1.4415
5		1.6461	1.8656	1.6632	1.885	1.5524	1.6632
6		1.5364	1.9044	1.6632	1.9959	2.2177	1.9753
7		1.5364	1.885	1.4415	1.9547	2.2177	1.9753
8		1.4266	.8871	1.3306	1.9959	1.9959	1.7741
9		1.3306	1.4266	1.3032	1.5524	1.9753	1.9753
10		1.6632		1.3032	1.4415	2.0851	1.8656
11		1.7741	2.1068	1.3032	1.9959	2.0851	1.9959
12		1.885	2.2177	1.3032	2.1068	1.9004	1.885
13	1.6461	1.885	2.0851	1.4415	1.4415	1.5364	1.7741
14	1.7558	1.6632	2.1068	1.4415	1.5524		1.7741
15	1.0974	.8871	2.0633	1.4415	1.5524		1.6461
16	2.3045	.8871	1.2197	1.4415	1.5524	1.5364	1.7558
17	2.4143	1.4415	2.1068	1.4118	1.3306	1.6632	1.3032
18	1.4415	1.3306	2.1068	1.4266	1.2197	1.6461	1.3169
19	1.5524	1.7741	2.1068	1.6461	1.4415	1.6632	1.3169
20	1.7741	2.1948	2.1068	1.6461	1.5524	1.5524	1.3169
21	1.7558	2.1948	1.6632	1.6461	1.6632	1.5524	1.5364
22	1.9753	2.1948	1.3306	1.6461	1.6632	1.7741	1.5364
23	1.8656	2.1068	1.3306	1.5364	1.6632	1.6632	1.4118
24	1.6461	1.7558	1.8656	.4435	1.5524	1.5364	1.5364
Max	2.4143	2.1948	2.2177	1.6632	2.1068	2.2177	1.9959
Min	1.0974	.8871	.8871	.4435	1.2197	1.5364	1.3032
Avg	1.7691	1.6580	1.8220	1.4639	1.6693	1.7438	1.6292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 402 / 33 KV MANORA KARANJA

SHEDDABLE URBAN

FEEDER Feeder KV- 33 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7558	1.885	1.6632	1.5524	1.5524	1.4266
2		1.6461	1.8656	1.6632	1.7741	1.5524	1.4415
3		1.6461	1.885	1.6632	1.7741	1.5524	1.4266
4		1.6289	1.885	1.6632	1.885	1.5524	1.4266
5		1.885	1.885	1.6632	1.885	1.5524	1.6632
6		1.5364	1.885	1.6632	1.9959	2.2177	1.9959
7		1.5364	1.885	1.4415	1.9547	2.2177	1.9959
8		1.4266	.8871	1.3306	1.9753	1.9753	1.7741
9		1.3306	1.4266	1.3169	1.5524	1.9753	1.9753
10		1.6632		1.3032	1.4266	2.0851	1.8656
11		1.7741	2.1068	1.3169	1.9959	2.0851	1.9959
12		1.749	2.2177	1.3306	2.0851	1.9204	1.885
13	1.6461	1.885	2.1068	1.6632	1.4415	1.5364	1.7741
14	1.7558	1.6632	2.1719	1.4415	1.5524		1.7741
15	1.0974	.8871	2.0851	1.4415	1.5524		1.6461
16	2.3045	.8871	1.2071	1.4415	1.5524	1.5364	1.7558
17	2.4143	1.4415	2.1068	1.4266	1.3306	1.6632	1.3169
18	1.4415	1.3306	2.1068	1.4266	1.2197	1.6632	1.3032
19	1.5524	1.7741	2.1068	1.6461	1.4415	1.6632	1.3169
20	1.7741	2.1948	2.1068	1.6461	1.5524	1.5364	1.5364
21	1.7558	2.2177	1.6632	1.6461	1.6632	1.5364	1.5203
22	1.9959	2.2177	1.3306	1.6461	1.6632	1.7558	1.5203
23	1.8656	2.1068	1.3306	1.5364	1.6632	1.6632	1.4118
24	1.6461	1.7558	1.8656	.4435	1.5524	1.5364	1.5364
Max	2.4143	2.2177	2.2177	1.6632	2.0851	2.2177	1.9959
Min	1.0974	.8871	.8871	.4435	1.2197	1.5364	1.3032
Avg	1.7708	1.6642	1.8262	1.4760	1.6684	1.7422	1.6369

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344029 / 33 KV KARANJA LAD SUB

STATION

Feeder No / Name : 403 / 33 KV KARANJA FEEDER

SHEDDABLE URBAN

Feeder KV- 33 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		6.9136	7.041	6.4312	6.4866	6.4312	6.8747
2		6.8587	7.041	6.0985	6.0431	6.2003	6.8039
3		6.6244	6.8747	5.9877	5.8213	5.8768	6.749
4		6.6392	6.5975	5.9322	5.5927	5.8768	6.31
5		6.3649	6.2649	5.8768	5.655	5.655	5.8711
6		5.8099	5.9877	5.9322	5.3224	5.655	5.5996
7		6.0905	5.4887	5.5996	5.2669	5.655	5.4887
8		5.3224	5.2669	5.5441	5.156	5.2669	5.2115
9		5.156	5.2126	5.1578	5.4321	5.2126	5.1578
10		5.5441	5.3772	5.2669	5.5418	5.5418	5.104
11		5.655	5.6516	5.655	5.9322	5.5967	5.104
12		5.4012	5.6516	5.4841	6.0905	5.7013	5.3755
13	6.0905	6.0985	6.2003	5.7659	6.31	5.8711	5.7065
14	6.31	6.2094	6.5421	6.2649	6.5421	5.9728	5.8711
15	6.2443	6.3758	6.3758	6.2094	6.5421	6.0814	6.0357
16	6.4198	6.4866	6.5421	6.2094	6.5421	6.19	6.0357
17	6.19	6.4866	6.0985	6.3758	5.9671	6.0985	5.8711
18	6.0357	5.8711	5.9322	6.4866	5.9877	6.0357	6.2003
19	6.4072	6.6392	6.3758	6.7084	6.4312	5.9808	6.5295
20	6.8587	6.8039	6.5975	7.041	6.653	6.3649	6.9136
21	6.6941	6.9302	6.9856	6.9302	6.8747	6.5295	6.9136
22	7.0782	6.9136	6.7638	6.733	7.2628	6.6941	6.749
23	7.2977	7.2074	6.8747	6.9856	7.2074	6.8587	6.5844
24	7.1331	7.0782	7.1331	6.8747	6.7638	6.8587	6.9136
Max	7.2977	7.2074	7.1331	7.041	7.2628	6.8587	6.9136
Min	6.0357	5.156	5.2126	5.1578	5.156	5.2126	5.104
Avg	6.5633	6.3117	6.2865	6.1480	6.1427	6.0086	6.0822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344030 / 33 KV DARWHA ROAD SUB

STATION

Feeder No / Name : 201 / 11 KV DARWHA INDUSTRIAL

SHEDDABLE FEEDER HAVING WEEKLY

FEEDER Feeder KV- 11 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716		.0716	.0532		.1629	.0354
2	.0716	.0716	.0716		.0537	.1439	.0354
3	.0716		.0716	.0532		.1332	.0354
4	.0716	.0537	.0716	.0354	.0537	.1111	.0354
5	.0716		.0716	.0709		.0867	.0354
6	.0716	.0716	.0716	.0709	.0537	.1673	.0354
7	.0716		.0716	.0709		.1287	.0354
8	.0537	.0895	.0358	.0354	.0537	.1044	.0358
9	.1075					.1143	.0354
10	.1433	.1075	.1254	.1063	.0895	.2088	.0354
11	.1433	.1075	.1433		.0895	.2462	.0731
12	.1433	.1791	.1791	.1075	.1075	.2248	.0769
13	.1433	.1612	.1075		.1075	.2298	.0221
14	.1612	.1433	.1075	.1075	.0537	.1737	.0739
15	.1612	.1433	.1772		.0537	.232	.0008
16	.197	.1254	.1417	.1075	.0716	.1898	.0552
17	.197	.1372	.1433		.0716	.2084	.0145
18	.197	.1433	.1075	.0895	.0895	.2473	.0689
19		.1387	.0716		.1075	.205	.0015
20	.1433	.1433	.0709	.0716	.0895	.2081	
21		.1433	.0358		.0895	.0953	
22	.1075	.1433	.0358	.0716	.0716	.1219	
23	.1075	.0716	.0709	.0537	.0716	.0354	
24	.0716	.0716	.0716	.0709	.0537	.0739	.0354
Max	.197	.1791	.1791	.1075	.1075	.2473	.0769
Min	.0537	.0537	.0358	.0354	.0537	.0354	.0008
Avg	.1172	.1182	.0924	.0735	.0754	.1605	.0388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344030 / 33 KV DARWHA ROAD SUB

STATION

Feeder No / Name : 202 / 11 KV DADGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6859	.5144	.8688				
3	1.4213	.5906	1.1995				
4	1.4762	1.2399	1.2452				
5	1.4968	.7156	1.307				
6	1.5965	1.3977	1.3497				
7	1.5875	.8238	1.4495				
8	1.6721	1.6255	1.5889				
9	1.6728	.8253	1.4998				
10	.8863	.836	.8284	.7125	.8059	1.0738	.7125
11			.0145		.7701	1.6835	.7865
12				.7888	.7865	1.5951	.8573
13					.7537	1.6077	
14				.7888	.7209	1.4716	.8573
15					.7373	1.5157	
16				.7545	.7373	1.4259	.823
17					.7373	1.3897	
18						.8794	
19						.0671	
Max	1.6728	1.6255	1.5889	.7888	.8059	1.6835	.8573
Min	.6859	.5144	.0145	.7125	.7209	.0671	.7125
Avg	1.3884	.9521	1.1351	.7612	.7561	1.2710	.8073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344030 / 33 KV DARWHA ROAD SUB

STATION

Feeder No / Name : 203 / 11 KV DARWHAWESH FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668		.4298	.462		.4435	.4119
2	.4668	.4108	.394	.4668	.4108	.4435	.4119
3	.4481		.4066	.4435		.4435	.4119
4	.4481	.3224	.4066	.4435	.3734	.4435	.3898
5	.4481		.4066	.4066		.4066	.3189
6	.3361	.2865	.3511	.3881	.3361	.3511	.3366
7	.3174		.3142	.3224		.3142	.2686
8	.2987	.2614	.2587	.2865	.2801	.2587	.2481
9	.2614		.2401	.2715		.2587	.2507
10	.2801	.2801	.2572	.2926	.2801	.2772	.2865
11	.2987	.2801	.2772		.2772	.2957	.3012
12	.2987	.3174	.2926	.2987	.3326	.3142	.3174
13	.2987	.3734	.3292		.3696	.3403	
14	.2801	.3734	.3258	.2987	.3696	.362	.2987
15	.2801	.3582	.3658		.3696	.3721	
16	.2801	.1715	.3658	.2801	.3696	.3582	.2987
17	.2801	.3734	.3475		.3326	.3403	
18		.2587	.2743	.2427	.2772	.2865	.2801
19		.2241	.3475		.3696	.3366	
20	.4108	.3734	.439	.3734	.3696	.2481	
21		.4481	.4525		.4066	.4298	
22	.4481	.4481	.4572	.4481	.4435	.443	
23	.4481	.4854	.4572	.4481	.462	.443	
24	.4668	.4481	.4854	.4525	.4481	4.768	.4477
Max	.4668	.4854	.4854	.4668	.462	4.768	.4477
Min	.2614	.1715	.2401	.2427	.2772	.2481	.2481
Avg	.3601	.3418	.3617	.3681	.3620	.5408	.3299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344035 / 33 KV MANORA ROAD SUB

STATION

Feeder No / Name : 201 / 11 KV KRUSHNA COLONY

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3374	.3294	.3742	.3224	.3429	.3155
2	.3121	.3405	.3121	.3566	.3224	.3086	.298
3	.2774	.3555	.2947	.3558	.3121	.3086	.2804
4	.2601	.3587	.2947	.3371	.3012	.2915	.3294
5	.2629	.3027	.2774	.3381	.2804	.2915	.2629
6	.2427	.303	.2601	.32	.2835	.2743	.2601
7	.2454	.2654	.2601	.3012	.2774	.2743	.2629
8	.2713	.2263	.2427	.2635	.2454	.2229	.2328
9	.208	.2273	.2254	.2432	.2427	.2229	.2454
10	.2427	.2261	.2427	.263	.2401	.2572	.2353
11	.2627		.2649	.2601	.2401	.2865	.2401
12	.3024	.2427	.2809	.2883	.2401		.2401
13	.3015	.2774	.3206	.2774	.2743	.3155	.2743
14	.3223	.2774	.3033	.2774	.2743	.3439	.2401
15	.3388	.2947	.3405	.333	.2915	.3506	.2401
16	.3402	.3121	.3206	.2774	.3121	.3506	.2401
17	.2821	.3121	.2826	.2713	.3086	.362	.1715
18	.3203	.2774	.3021	.2279	.2915	.3439	.1715
19	.3232	.2804	.3181	.2279	.2915	.2883	.2915
20	.3381	.2774	.3405	.4031	.3086	.2835	.2915
21	.3388	.3121	.3381	.3294	.2401	.3077	.3429
22	.3768	.3641	.3957	.3561	.3086	.3475	.3429
23	.3795	.3641	.3969		.3258	.0339	.3429
24	.3294	.3595	.3294	.3746	.3391	.3258	.3222
Max	.3795	.3641	.3969	.4031	.3391	.362	.3429
Min	.208	.2261	.2254	.2279	.2401	.0339	.1715
Avg	.3017	.2998	.3031	.3068	.2864	.2928	.2698



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344035 / 33 KV MANORA ROAD SUB

STATION

Feeder No / Name : 202 / 11 KV WATER SUPPLY FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0347	.0378	.0351	.0379	.0351	.0343	.0339
2	.0347	.0376	.0351	.0377	.0537	.0343	.0347
3	.0343	.0379	.0351	.0373	.0526	.0343	.0347
4	.0343	.0569	.0351	.0565	.0358	.0343	.0351
5	.0347	.0568	.0526	.0561	.0347	.0343	.0351
6	.0351	.0566	.0526	.0376	.0514	.0343	.0351
7	.0358	.0568	.0526	.0563	.052	.0343	.0351
8	.0339	.0566	.0526	.0565	.0526	.0514	.0347
9	.0358	.0566	.052	.0562	.0351	.0514	.0351
10	.0339	.0566	.0351	.0561	.052	.0343	.0351
11	.0563		.0379	.0343	.0514	.0351	.0343
12	.0378	.052	.038		.0514		.0343
13	.0564	.0526	.0379	.052	.0514	.0351	.0343
14	.0562	.0526	.0566	.052	.0514	.0351	.0343
15	.0567	.0526	.0567	.052	.0514	.0362	.0514
16	.0568	.0526	.0565	.0526	.0514	.0351	.0514
17	.0568	.0526	.0566	.0526	.052	.0351	.0514
18	.0566	.0526	.0566	.0509	.0514	.0543	.0514
19	.0563	.0526	.056	.0526	.0514	.0532	.0514
20	.0562	.0526	.0562	.0514	.0343	.0526	.0514
21	.0564	.0526	.0378	.0509		.0543	.0343
22	.0375	.0347	.0564	.0343	.0514	.0343	.0343
23	.0569	.0351	.0565		.0343	.0509	.0343
24	.0343	.0373	.0351	.0378	.0351	.0343	.0354
Max	.0569	.0569	.0567	.0565	.0537	.0543	.0514
Min	.0339	.0347	.0351	.0343	.0343	.0343	.0339
Avg	.0449	.0497	.0472	.0483	.0467	.0401	.0389

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344035 / 33 KV MANORA ROAD SUB

STATION

Feeder No / Name : 203 / 11 KV GIRDA GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.4508	.3641	.4141	.3467	.3772	.1928
2	.4031	.4536	.3641	.3933	.3467	.3429	.1949
3	.3814	.4307	.3467	.3795	.3439	.3429	.2103
4	.3772	.4154	.3467	.3761	.3403	.3258	.2149
5	.3467	.3765	.3294	.3368	.3224	.3258	.2103
6	.3294	.3795	.3294	.3555	.3121	.3086	.2149
7	.3121	.3398	.2774	.32	.3121	.2229	.208
8	.3121	.3223	.2427	.3003	.2629	.2229	.2149
9	.3121	.2635	.2427	.3177	.2454	.3086	.2303
10	.2713	.2259	.2947	.2821	.2774	.2915	
11	.2259		.3223	.2835	.2401	.2835	.2401
12	.2826	.2254	.3024	.3725	.2229	.298	.2401
13	.3184	.2947	.303	.3155	.2915	.3801	.2743
14	.3595	.2947	.2635	.3224	.2915	.362	.2401
15	.3374	.2947	.2844	.3658	.2743	.362	.2401
16	.3184	.2774	.2835	.2774	.2401		.2401
17	.2806	.2774	.2824	.2774	.3601	.1753	.1715
18	.3033	.2774	.3012	.298	.2572	.181	.1715
19	.4158	.3641	.358	.3429	.3944	.2035	.3086
20	.4894	.4161	.449	.407	.4115		.3086
21	.4909	.4508	.4715	.4119	.3086		.3944
22	.4696	.4161	.4518	.4031	.3429	.1949	.4287
23	.472	.3988	.436		.3086	.2103	.3772
24	.4161	.455	.3814	.4158	.373	.3086	.1928
Max	.4909	.455	.4715	.4158	.4115	.3801	.4287
Min	.2259	.2254	.2427	.2774	.2229	.1753	.1715
Avg	.3603	.3522	.3345	.3465	.3094	.2871	.2487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

KARANJA[279]

BU 1546

Substation No/ Name :- 344035 / 33 KV MANORA ROAD SUB

STATION

Feeder No / Name : 402 / 33 KV MANORA KARANJA

SHEDDABLE URBAN

FEEDER Feeder KV- 33 /  
INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.893	2.1393	1.6644	1.6992	1.5947	1.3889	1.6289
2	1.9765	2.0432	1.6301	1.5684	1.6124	1.5432	1.6827
3	1.6644	2.0268	1.6644	1.7942	1.7193	1.5947	1.7164
4	1.749	1.8107	1.6124	1.8052	1.6118	1.6461	1.6832
5	1.6461	1.701		1.5796	1.6827	1.5432	1.7878
6	1.3889	1.5908	1.6124	1.5764	1.8404	1.6461	1.8404
7	1.4352	1.594	1.7164	1.4682	1.4661	1.8004	1.7164
8	1.2094	1.4712	1.5083	1.3539	1.8604	1.8519	1.6289
9	1.3146	1.4742	1.4563	1.3512	1.8656	1.8519	1.9004
10	2.4417	2.2794		1.4593	1.4506	1.5432	1.7878
11	1.4786		2.2588	.7802	1.3375	1.5775	1.6975
12	2.1611	1.7164	2.3813	1.3375	1.6975	1.5746	1.4403
13	2.2542	1.6124	2.0432	2.6886	1.5947	1.6289	1.2346
14	1.8016	1.6124	2.268	1.2894	1.5947		1.6975
15	1.4757	1.4043	2.2771	1.3003	1.3889		1.4403
16	2.3909	.8939	1.807	1.4043	1.3889	1.4752	1.3375
17	2.3717	1.4043	2.1611	.9831	1.3889	1.0682	1.5432
18	1.4638	1.3672	2.1589	.6836	1.1317	1.4723	1.5432
19	1.1374	1.6827	2.3669	1.4243	1.1317	1.7684	1.3375
20	1.8016	2.0285	2.2588	1.6278	1.4403	1.6289	1.3375
21	1.9355	1.9765	2.4947	1.5604	1.0288	.431	1.5432
22	2.0473	1.9244	1.1317	1.5249	1.0288	1.5261	1.4918
23	2.0268	1.8724	1.6975		1.4403	1.5083	1.4403
24	1.7804	2.1611	1.7164	1.6907	1.4043	1.4403	
Max	2.4417	2.2794	2.4947	2.6886	1.8656	1.8519	1.9004
Min	1.1374	.8939	1.1317	.6836	1.0288	.431	1.2346
Avg	1.7852	1.7299	1.9039	1.4761	1.4875	1.5232	1.5851

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344014 / 33 KV MEDSHI

Feeder No / Name : 201 / 11 KV MEDSHI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.9831	.9831	.8192	.8192	.8192	.8192
3	.9831	.9831	.8192	.8192	.8192	.8192
4	.9831	.9831	.8192	.8192	.8192	.8192
5	.9831	.9831	.8192	.8192	.8192	.8192
6	.9831	.9831	.8192	.8192	.8192	.8192
14		.9831	.9831	.9831	.9831	1.065
15		.9831	.9831	.9831	.9831	1.065
16		.9831	.9831	.9831	.9831	1.065
17		.9831	.9831	.9831	.9831	1.065
18		.9012	.9831	.9831	.9831	1.065
Max	.9831	.9831	.9831	.9831	.9831	1.065
Min	.9831	.9012	.8192	.8192	.8192	.8192
Avg	.9831	.9749	.9012	.9012	.9012	.9421

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344014 / 33 KV MEDSHI

Feeder No / Name : 202 / 11 KV RIDHORA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8951	1.1096	.7865	.7373	.852	.3605	.4424
9	1.2125	1.3108	1.1797	1.0852	1.1469	.6554	.6554
10	1.1797	.8848	1.065	1.0486	.6882	.6718	.6554
11	1.1961	1.6244	.9831	1.0486	.5243		.5898
12	1.3763	1.2597	.9831	1.0486	.5079		
13	1.3927	1.0277	.9012	1.1797	.4588		.4915
21	1.0486	.7865	.9175	.852	.4096	.5735	.4096
22	1.0486	.7865	.9012	.852	.4096	.5571	.4096
23	1.0486	.7865	.8192	.852	.3932	.5571	.4096
24	.9945	.9175	.7865	.8192	.852	.3932	.5571
Max	1.3927	1.6244	1.1797	1.1797	1.1469	.6718	.6554
Min	.8951	.7865	.7865	.7373	.3932	.3605	.4096
Avg	1.1393	1.0494	.9323	.9523	.6243	.5384	.5134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344014 / 33 KV MEDSHI

Feeder No / Name : 203 / Medshi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2947	.2896	.3439	.3142	.3258	.3224	.3077
2	.2947	.2896	.3439	.3142	.3258	.3224	.3077
3	.2947	.2896	.3439	.3142	.3258	.3224	.3077
4	.2947	.2896	.3439	.3142	.3258	.3224	.3077
5	.3294	.2896	.3439	.3326	.3258	.3224	.3258
6	.3467	.2353	.3439	.3511	.3258	.3582	.3761
8		.2896					
9	.2294	.2353	.2715	.2561	.2896	.2658	.2328
10	.2601	.1928	.2534	.2353	.2507	.2481	.2149
11	.2254	.2328	.2534	.2353	.2686		.2481
12	.208		.2481	.2172	.2507		
13	.2254	.2328	.2534	.2353	.2507		.2481
14	.2427	.2195	.2507	.2353	.2507	.2353	.2481
15	.2254	.2353	.2328	.2353	.2507	.2353	.2481
16	.2427	.2172	.2328	.2172	.2507	.2353	.2481
17	.2454	.2353	.2658	.2534	.2481	.2534	.2481
18	.2601	.2534	.2658	.2534	.2507	.2715	.2481
19	.2957	.3403	.3109	.3258	.3582	.3582	.3077
20	.3696	.362	.3696	.362	.3761	.3761	.3511
21	.3881	.3258	.3142	.362	.3761	.3582	.3361
22	.3801	.3439	.3142	.362	.3582	.3403	.3174
23	.3467	.3439	.3142	.3258	.3403	.3403	.3142
24	.3121	.3077	.3439	.3142	.3258	.3403	.3258
Max	.3881	.362	.3696	.362	.3761	.3761	.3761
Min	.208	.1928	.2328	.2172	.2481	.2353	.2149
Avg	.2869	.2750	.2981	.2894	.3023	.3068	.2890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344014 / 33 KV MEDSHI

Feeder No / Name : 204 / Ridhora Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6838	1.7337	1.5257	1.4175	1.387	1.7353	1.7177
2	.7023	1.7337	1.5257	1.4327	1.387	1.7353	1.7528
3	.7023	1.7337	1.5257	1.4327	1.387	1.7353	1.7528
4	.7023	1.7337	1.5257	1.5223	1.387	1.7353	1.7528
5	.7392	1.7337	1.5257	1.5947	1.387	1.7528	1.7684
6	.7947	1.7337	1.5257	1.8604	1.387	1.7878	1.8204
11	.8316	1.595	1.0517	1.2136	1.2483		1.7002
12	.924		1.0631	1.2136	1.2136		
13	.924	.7802	1.0631	1.387	1.1789		1.6827
14	.7577	.5375	1.0631	1.387	1.2483	1.9071	1.6651
15	.7392	.8764	1.2269	1.387	1.2309		1.6651
16	.8316	.7186	1.262	1.387	1.2656	1.8204	1.6651
17	.8686	.8764	1.3146	1.387	1.2483	1.7337	1.7177
18	.8871	1.1393	1.262	1.387	1.283	1.5775	1.8404
19	.9536	1.7337	1.8604	1.7337	1.8724	2.0805	2.0683
20	1.7337	1.5257	1.8604	1.7337	1.9071	2.1845	
21	1.7337	1.5257	1.7718	1.7337	1.9071	.8596	1.2269
22	1.7337	1.5257	1.6118	1.5257	1.8204	1.7528	.9745
23	1.7337	1.5257	1.6118	1.387	1.7684	1.7878	.9745
24	.6838	1.2136	1.5257	1.4022	1.387	1.7337	1.7528
Max	1.7337	1.7337	1.8604	1.8604	1.9071	2.1845	2.0683
Min	.6838	.5375	1.0517	1.2136	1.1789	.8596	.9745
Avg	.9830	1.3671	1.4351	1.4763	1.4451	1.7450	1.6388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344023 / SHIRPUR

Feeder No / Name : 201 / dudhala ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.282	.535	.4934				
3	.3525	.535	.4934				
4	.423	.535	.5075				
5	.4793	.5498	.5075				
6	.6908	.8471	.7895				
7	.7895	1.0254	.9305				
8	.8459	.8768	.8459				
9	.86	.8173	.7613				
10				.8345	.9446	.639	.8882
11				.8623	.6516	.6767	.8459
12				.7754	.6371	.7754	.8802
13				.7093	.5357	.7754	.6626
14				.6259	.5068	.7049	.6203
15				.6259	.4923	.6485	
16				.612	.5357	.719	
17				.7093	.5213	.7613	
Max	.86	1.0254	.9305	.8623	.9446	.7754	.8882
Min	.282	.535	.4934	.612	.4923	.639	.6203
Avg	.5904	.7152	.6661	.7193	.6031	.7125	.7794



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344023 / SHIRPUR

Feeder No / Name : 202 / shirpur town SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0269	.8871	.9795	1.0164	1.0164	.9795	1.0829
2	1.0269	.9709	.9795	1.0164	1.0164	.8871	1.0456
3	1.0269	.9709	.9795	1.0164	1.0164	.8779	1.0456
4	1.0269	.9709	.9979	1.0164	1.0164	.8779	1.0456
5	1.0829	.9896	.9979	1.0164	1.0164	.9709	1.1203
6	1.1389	1.0642	1.0719	1.1088	1.0349	1.1203	1.0829
7	1.0829	1.0829	.9979	1.0349	1.0349	.9896	1.0456
8	1.0269	1.0903		.924	.8871	.8215	.8215
9	.9709	.8871	.961	.961	.8871	.8871	.8402
10	.9335	.9055	.961	.924	.7947	.8871	.8775
11	.8316	.8686	.8501	.8316	.6908	.8501	.6908
12	.7392	.924	.8686	.823	.8215	.8131	.8215
13	.8131	.8131	.8871	.8131	.8215	.7023	.7468
14	.8316	.8316	.8779	.8871	.8402	.9055	.8402
15	.8501	.8871	.961	.8871	.8215	.9149	.8402
16	.8316	.924	.924	.9055	.8775	.8962	.7468
17	.8131	.8871	.924	.8871	.8589	.8775	.6908
18	.8131	.8316	.8501	.8501	.8131	.9149	.7316
19	1.0349	.9795	1.0164	.9425	.9425	.9709	.7316
20	1.1088	1.1273	1.1827	1.0719	.961		1.0425
21		1.1088	1.1088	.9795	1.0349	.8775	1.0242
22	1.0349	1.1273	1.1088	1.0903		1.1203	1.134
23	.9795	1.0719	1.0349	1.0534		1.1949	1.1523
24	1.0269	.9979	1.0164	1.0349	.8871	.8131	1.0456
Max	1.1389	1.1273	1.1827	1.1088	1.0349	1.1949	1.1523
Min	.7392	.8131	.8501	.8131	.6908	.7023	.6908
Avg	.9588	.9666	.9799	.9622	.9132	.9196	.9269

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344023 / SHIRPUR

Feeder No / Name : 203 / karanji ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.2086	.1692	.2538
3				.2029	.2115	.1738	.2538
4				.2058	.2115	.1738	.2538
5				.2058	.282	.2606	.282
6				.2976	.3525	.362	.4934
7				.4801	.4934	.2751	.6908
8				.4329	.5216		.5357
9				.3841	.4652	.2317	.5216
10	.2538	.1669	.3841				
11	.2256	.1669	.3429				
12	.5639	.192	.3841	.2086			
13	.5075	.192	.2743	.2086			
14	.4694	.3429	.3018				
15	.2643	.3429					
16	.2256	.3018	.1372				
17	.1669	.2058	.1372				
18		.1646					
19		.2058					
20		.1372					
21		.1097					
Max	.5639	.3429	.3841	.4801	.5216	.362	.6908
Min	.1669	.1097	.1372	.2029	.2086	.1692	.2538
Avg	.3346	.2107	.2802	.2918	.3433	.2352	.4106

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344023 / SHIRPUR

Feeder No / Name : 204 / dudhala gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9522	.9709	.924	.9511	.8871	.9055	.8962
2	.9522	.8589	.924	.9511	.8871	.9055	.8962
3	.9522	.8589	.924	.9511	.8871	.9055	.8962
4	1.1203	.8775	1.1088	1.0242	.924	.9055	.9709
5	1.307	1.1203	1.3306	1.1888	1.1088	1.0349	1.1203
6	1.6617	1.6057	1.6632	1.7193	1.7002	1.6448	1.7177
7	1.419	1.4003	1.3306	1.2803	1.386	1.4415	1.307
8	1.1949	1.2197	.7392	1.0974	1.2012	1.0349	1.0829
9	.8962	1.0349	.5544	.9877	.961	.7842	.7842
10	.8402	.8686	.4066	.7316	.8501	.7282	.6722
11	.7023	.7023	.6653	.695	.2241	.6908	.5975
12	.7207	.7392	.7023	.6767	.7842	.6535	.5788
13	.5914	.7023	.8131	.6584	.8029	.7468	.6535
14	.6653	.7023	.7762	.7133	.7468	.7655	
15	.5914	.7392		.6767	.7282	.7842	.6401
16		.7023	.6283	.6401	.7655	.7282	.7133
17	.8131	.7023	.7023	.6653	.7842	.7468	.695
18	.924	.8316	.8048	.7762	.8686	.7655	.7499
19	.9335	1.0164	1.0608	.9979	1.1763	1.1763	1.0425
20	1.251	1.1088	1.1706	.961	1.1643	1.1389	1.1157
21		1.0719	1.0974	1.0534	1.0349	1.1203	1.0425
22		1.0164	1.0719	.9979		1.0269	1.0059
23	.9335	.9979	.9979	.961		.8589	.9511
24	.9522	.9709	.961	.9511	.924	.924	.8775
Max	1.6617	1.6057	1.6632	1.7193	1.7002	1.6448	1.7177
Min	.5914	.7023	.4066	.6401	.2241	.6535	.5788
Avg	.9702	.9508	.9286	.9294	.9453	.9340	.9134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344023 / SHIRPUR

Feeder No / Name : 205 / karanji gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3841	.4066	.4024	.4066	.4251	.4108
2	.4108	.3841	.4066	.4024	.4066	.4066	.4108
3	.4108	.3881	.4066	.4024	.4066	1.7741	.4108
4	.4854	.3881	.4435	.439	.4435	.4066	.4854
5	.5601	.5729	.5544	.5487	.5175	.6584	.5228
6	.7468	.8501	.7762	.8048	.5914	.8048	.5601
7	.8029	.7023	.6283	.6584	.6468	.7316	.5601
8	.5601	.6767	.5175	.5487	.5914	.567	.5228
9	.5601	.4755	.5544	.439	.5175	.5121	.4854
10	.9335	.4024	.4066	.439	.4435	.4024	.4481
11	.3142	.3292	.3326	.439	.3292	.3734	.3547
12	.3511	.3142	.2957	.4024	.3292	.3734	.3361
13	.3142	.2957	.3658	.3658	.3292	.3361	.3547
14	.3696	.3326	.2926	.3292	.3658	.3361	
15	.4066	.3326	.3658	.3292	.3475	.2987	.3658
16	.4251	.3326	.3292	.3292	.3292	.3734	.2195
17	.3881	.3326	.3292	.3326	.3475	.3734	.3841
18	.4066	.3326	.3658	.3696	.3185	.3734	.4207
19	.5487	.5544	.3658	.4805	.4344	.4481	.5304
20	.5853	.4805	.5853	.5175	.4489	.5228	.5487
21		.462	.5544	.5175	.4054	.5601	.5121
22	.4755	.462	.4755	.4805		.5228	.5487
23	.4207	.4435	.4024	.4066		.4481	.5853
24	.4108	.4024	.4251	.4024	.4066	.4294	.4108
Max	.9335	.8501	.7762	.8048	.6468	1.7741	.5853
Min	.3142	.2957	.2926	.3292	.3185	.2987	.2195
Avg	.4912	.4430	.4411	.4495	.4256	.5191	.4517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344024 / KINHIRAJA

Feeder No / Name : 201 / YERANDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5261	1.2548	1.5565		1.491	.6859
2	1.5261	1.2407	1.4403		1.5074	.7011
3	1.5432	1.1869	1.4022		1.3717	.6783
4	1.5261	1.1736	1.3717		1.4022	.6783
5	1.5261	1.1736	1.3717		1.4022	.6859
6	1.5432	1.2887	1.5775		1.4723	.7545
7	1.7147	1.7147	1.7147		1.7147	.8764
8	1.7147	2.1033	1.7528		1.8861	.8383
9	1.7147	2.1262	1.8861	1.8054		
10	1.4582	2.0576	1.9281			
11		2.0576	1.7147			
12	1.4091	1.8652	1.8652			
13		1.7147	1.7147			
14		1.6827	1.6956			
15		1.5432	1.5775			
17		1.7528	1.749			
18		1.9105	1.6956			
19		1.9631	1.6956			
20		2.1033	1.9033	2.2291		.8383
21		1.9456			.8916	.7202
22		1.6956		1.8347	.8718	.6062
23		1.6297		1.7147	.6952	.6036
24	1.6095		1.4582		1.5432	.6859
Max	1.7147	2.1262	1.9281	2.2291	1.8861	.8764
Min	1.4091	1.1736	1.3717	1.7147	.6952	.6036
Avg	1.5676	1.6902	1.6536	1.8960	1.3541	.7195

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344024 / KINHIRAJA

Feeder No / Name : 202 / kinhiraja SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	.9945	1.2269		1.2003	1.0174
2	1.4746	.9945	1.2003		1.2269	.9259
3	1.4582	1.0059	1.2269		1.2269	.9259
4	1.4083	1.0174	1.2003		1.2003	.8573
5	1.4083	1.0174	1.2003		1.3032	.8573
6	1.4419	1.0974	1.4723		1.3321	.9496
7	1.5261	1.2403	1.5432		1.3321	1.2003
8	1.576	1.2269	1.5775		1.3717	1.4243
9	1.6766	1.2407	1.5604	1.5261		
10	1.5581	.8478	1.5261			
11	1.5089	1.0974	1.5432			
12	1.5089		1.6118			
13		1.7147	1.4746			
14		1.7147				
15		1.6461	1.5432			
16		1.7147				
17		1.6991	1.4922			
18		1.4403	1.5089			
19		1.5775	1.5432			
20		1.5432	1.4937	1.4582		1.3748
21		1.5089			1.2407	1.2689
22		1.3565		1.2742	1.2003	1.1065
23		1.3375		1.1736	1.073	1.0513
24	1.5775		1.3226		1.2136	1.0288
Max	1.6766	1.7147	1.6118	1.5261	1.3717	1.4243
Min	1.4083	.8478	1.2003	1.1736	1.073	.8573
Avg	1.5102	1.3197	1.4351	1.3580	1.2434	1.0760

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344024 / KINHIRAJA

Feeder No / Name : 203 / kawardari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1791		.1753	.1715
2	.2035	.1715	.1753		.1715	.1715
3	.1715	.2035	.1696		.1715	.1696
4	.1696	.1696	.1753		.1715	.1696
5	.1696	.2058	.1715		.1753	.1696
6	.1696	.2058	.2058		.2103	.1696
7	.2374	.1753	.2374		.2401	.2454
8	.2713	.2103	.2743		.2454	.2622
9	.2683	.208	.2743	.1943		
10	.2743	.2058	.2454			
11	.2374	.1715	.2401			
12	.2374	.2035	.2774			
13		.2058	.2347			
14		.2427	.2401			
15		.2401	.2804			
16		1.7528				
17		.1781	.1886			
18		.1943	.1715			
19		.1898	.2229			
20		.1943	.2229	.2515		.2229
21		.176			.2229	.218
22		.2846		.1844	.2035	.1802
23		.1581		.1886	.1715	.1886
24	.0848		.1619		.1677	.1715
Max	.2743	1.7528	.2804	.2515	.2454	.2622
Min	.0848	.1581	.1619	.1844	.1677	.1696
Avg	.2051	.2660	.2174	.2047	.1939	.1931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344032 / 33 KV AMANI

Feeder No / Name : 201 / amani gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9425			.7207	.5487	.5487	
2				.7207	.5487	.5487	
3		.3395		.7095		.5853	
4		.3772		.8402		.6653	
5		.4954		1.0269	.8048	.8501	1.1088
6	1.423	.5144	1.0349	1.1128		.9709	
10	.9231	.6283	.6283		.695	.6099	.4938
11	.7499	.4435	.5729	.7316	.567	.6283	.5487
12	.6767	.4435	.5304	.7133	.6036	.6283	.5487
13	.7316	.4435	.5487	.6335	.5487	.6283	.4755
14	.5853	.2218	.5487	.6036	.5487	.6468	.6584
15	.5914	.5544	.2715	.5407	.5487	.6283	.6584
16	.6335	.5359	.5792	.6154	.5853	.6283	.6653
17	.6335	.5729	.6036	.8779	.6838	.6653	.6468
18	.439	.6099	.7133	.8779	.4251	.7392	.6838
19	.5121	.7762	.8413	.9511	.7392	.961	.7468
20	1.1888	.9055	1.0719	1.0498	.7947		
21	1.1016	.7865	.9709	.6154	.7655	1.1088	.8779
22	1.0082	.7701	.8962	.6036	.7577	.9795	.7316
23	.9335		.7842	.6584	.6653	.8501	.4207
24		.8402		.7468	.5487	.6219	
Max	1.423	.9055	1.0719	1.1128	.8048	1.1088	1.1088
Min	.439	.2218	.2715	.5407	.4251	.5487	.4207
Avg	.8171	.5699	.7064	.7675	.6322	.7247	.6618



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344032 / 33 KV AMANI

Feeder No / Name : 202 / karanji ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-MAY-17
HR	Load (MW)
10	.0191
Max	.0191
Min	.0191
Avg	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MALEGAON S DN.[575] BU 1562

Substation No/ Name :- 344032 / 33 KV AMANI

Feeder No / Name : 203 / amani ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3067		.1174	.0229	.0655	
2		.3067		.1966	.0671	.1134	
3		.3199		.218		.1134	
4		.3572		.1966	.695	.1134	
5		.4458		.218	.1457	.1492	.1947
6	.3856	.4681	.5121	.2601		.218	.1947
7	.3688	.5525	.5487	.1189	.218	.16	.1029
8		.591	.4915	.1429	.2294	.16	.16
9	.3856	.6268		.1572	.2294	.16	.1143
10	.2462	.0838	.2286		.4752	.2881	
11	.2202	.0943	.1	.503	.3688	.3521	.2294
12	.1814	.0943	.1158	.5197	.3768	.3353	.1134
13	.1052	.0943	.1158	.4534	.3521	.3353	.4424
14	.1734	.1257	.2134	.4475	.3521	.3353	.5079
15	.1808	.1669	.2715	.4424	.3841	.3521	.3725
16	.1669	.1669	.2606	.4527	.3725	.3521	.4115
17	.1715	.1947	.2721	.4527	.2105	.3688	.4607
21	.4001		.1187	.1311	.0829	.1341	.3932
22	.3887	.439	.1174	.0983	.0829	.1509	.2766
23	.3749		.1006	.0819	.0663	.0838	.2936
24		.3067		.1174		.0663	
Max	.4001	.6268	.5487	.5197	.695	.3688	.5079
Min	.1052	.0838	.1	.0819	.0229	.0655	.1029
Avg	.2678	.3022	.2476	.2663	.2629	.2099	.2845

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 201 / Town-1 feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2894	1.3394	1.267	1.267	1.3611
2		1.3032	1.2803			1.3969
3		1.267	1.2803			1.3466
4		1.3032	1.2803	1.2437	1.3394	1.3394
5		1.3535	1.3169			1.3253
6		1.3535	1.3717	1.3535	1.3253	1.3394
7		1.3535	1.4632	1.39	1.3535	1.3535
8		1.2071			1.2803	1.2803
9	1.2308	1.1523		1.2269	1.3169	1.267
10		1.0745		1.3169		
11	1.086	1.134	1.2437	1.2437		1.267
12	1.1222	1.2254	1.1584		1.1584	1.1946
13	1.2178	1.1765	1.0517	1.1222	1.0974	1.1462
14	1.2269	1.182	1.0745	1.1765	1.182	1.0867
15	1.2403	1.182	1.3253	1.0745	1.182	1.1517
16	1.2178	1.0745	1.1462	1.0745	1.1584	1.1641
17	1.182	1.1104	1.2308		1.2071	1.1999
18	1.4266	1.5384	1.2178	1.267	1.2936	1.2403
19			1.39		1.3535	1.3394
20	1.4266	1.5546	1.4266	1.4998	1.4632	1.4784
21		1.5364			1.448	1.4266
22		1.448	1.39	1.3756		1.4083
23		1.4266		1.3756	1.448	1.4266
24		1.3394	1.39	1.3756	1.3394	1.3756
Max	1.4266	1.5546	1.4632	1.4998	1.4632	1.4784
Min	1.086	1.0745	1.0517	1.0745	1.0974	1.0867
Avg	1.2377	1.2863	1.2830	1.2739	1.2896	1.3006

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 202 / Town-2 feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4356		2.4253	2.2923	2.3891	2.3167	2.2565
2			2.364	2.1948			2.2081
3			2.364	2.1033			2.0953
4	2.2624			2.0119	2.1719	2.1491	1.9667
5			2.2131	2.0119			1.8959
6	2.1357		2.0814	2.0452	1.9909	1.9456	1.7718
7			1.8267	1.8781	1.7909	1.7551	1.7187
8			2.3045			1.6478	1.5257
9	1.7002	1.6461	1.7909		1.6651	1.6126	1.5604
10	1.7528	1.7337	1.7337		1.6827		
11		1.7528	1.8404	1.858	1.7353		1.6297
12		1.8229	1.8724	1.949		1.7878	1.6651
13		1.9456	1.97	1.949	1.949	1.9845	1.8804
14		2.0376	2.0595	2.0376	1.949	2.0416	1.9136
15		2.0199	2.0908	2.073	2.0553	2.0553	1.949
16		2.0376	2.0908	2.1616	2.0553	1.9982	2.0452
17		2.0376	1.9136	2.0553		1.8378	1.9631
18		2.167	1.8724	1.9591	1.8781	1.9982	1.8088
19			2.1132	2.0553		2.0508	2.0452
20		2.3348	2.3529	2.3891	2.2805	2.3348	2.2262
21			2.4072	2.3529		2.3282	2.19
22		2.4508	2.5339	2.3529	2.3167	2.371	2.3529
23			2.4874		2.3348	2.4253	2.3167
24	2.4714		2.371	2.4143	2.3282	2.3348	2.2986
Max	2.4714	2.4508	2.5339	2.4143	2.3891	2.4253	2.3529
Min	1.7002	1.6461	1.7337	1.858	1.6651	1.6126	1.5257
Avg	2.1264	1.9989	2.1339	2.1072	2.0358	2.0513	1.9689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 203 / manora

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.724		.8688	.2629
3				.7602			.2835
4				.7964	1.0974	.9412	.2835
5				.8688			.2658
6				.9145	1.0974	.9955	.3012
7				1.1888		.905	
8						1.2803	
9					1.2437	1.3575	
10	1.7558	1.5384	.8413				
11		1.5203	.8238				
12		1.4842	.8059				
13			.8326				
16		.439	.8779				
17		.439	.8413				
Max	1.7558	1.5384	.8779	1.1888	1.2437	1.3575	.3012
Min	1.7558	.439	.8059	.724	1.0974	.8688	.2629
Avg	1.7558	1.0842	.8371	.8755	1.1462	1.0581	.2794

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 204 / shelu

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.8229	1.7551		1.8804	2.0271
2			1.949	1.7909			2.0633
3			2.1262	1.8804			2.0633
4	.197		2.1491	1.8804	1.8099	1.949	1.97
5			2.0908	1.9342			2.1719
6	.2507		2.1971	1.9909	1.7375	1.97	2.2986
7			1.9879			1.97	2.4434
8	.4298		1.7353			1.5384	1.6651
9	.4119		2.1033			1.267	1.6832
10		1.5947			.5068		.3982
11		1.3112		.6154	.4706		.4344
12		1.2403		.4344		.2481	.362
13		1.2269		.3258	.362	.2149	.362
14		1.2308		.2896	.362	.2172	
15		.3582		.2353	.362	.2172	
16		1.4118		.1928	.181	2.1399	.362
17		1.448		.1991		2.0953	.362
18		2.0237			1.5043	1.9163	
19						1.9547	
20		2.2207		2.2624	2.3167	2.4177	2.5882
21			2.2386	2.1357		2.3282	2.4434
22		2.0633	2.0774	2.1176	2.3348	2.2986	2.4434
23			1.97		2.2624	2.1357	2.3529
24	1.0924		1.9185	1.9342	1.9185	2.0058	1.9909
Max	1.0924	2.2207	2.2386	2.2624	2.3348	2.4177	2.5882
Min	.197	.3582	1.7353	.1928	.181	.2149	.362
Avg	.4764	1.4663	2.0282	1.2926	1.2407	1.6192	1.6243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 205 / INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3169			
4	1.2936			
6	1.3969			
8	1.3306			
9	1.2197			
10	1.1827			
12			.0229	
13		.0187	.0152	
14		.0206		
15		.0457		
16		.0465	.0229	
17		.088	.0114	
18			.0057	
19			.0114	
20			.0038	
21			.0038	.0191
22				.061
23				.0152
24	1.3717			
Max	1.3969	.088	.0229	.061
Min	1.1827	.0187	.0038	.0152
Avg	1.3017	.0439	.0121	.0318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344010 / 33 KV MAGALURPIR SUB STATION

Feeder No / Name : 206 / 11kv gavthan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.8131				
6	.788				
9	1.1269		.4012		
10	1.0923		.4049		1.166
11		1.4373	1.4022		1.1317
12		1.5074		1.3176	1.2971
13		1.4899	1.4022	.4115	1.1919
14		1.3998		.3772	1.1393
15		1.3466	1.3672	1.7364	1.1517
16		1.3112	1.3496		1.1517
17		1.262	1.4022		1.1517
18		1.3889	1.2757		1.1744
19		1.7541			1.0288
Max	1.1269	1.7541	1.4022	1.7364	1.2971
Min	.788	1.262	.4012	.3772	1.0288
Avg	.9551	1.4330	1.1257	.9607	1.1584



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344011 / 33/11 KV SHIVANI ROAD SUB

STAT

Feeder No / Name : 201 / GHOTA GAVTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2561	.3277	.2743	.2561	.3277	.2743
2	.2743	.2561	.3277	.2439	.2561	.3277	.2743
3	.2743	.2561	.3277	.2439	.2591	.3315	.2743
4	.2743	.1943	.3277	.2439	.2591	.3277	.2439
5	.2134	.1943	.3125	.2134	.2622	.3201	.2439
6	.2134	.1943	.3048	.2134	.2652	.2881	.2439
7	.1829	.1219	.2054	.1829	.1829	.1898	.1829
8	.1829	.1174		.1524	.1189	.1829	.1524
9	.1524	.1189	.176	.1524	.1235		.1524
10	.1524	.1219	.176	.1524	.1189	.1829	.1524
11	.1852	.1852	.1524	.1829	.1852	.1829	.1562
12	.1852	.1852	.1524	.1806	.1852	.1829	.125
13	.1852	.1852	.1524	.1829	.1852	.1829	.1265
14	.1852	.216	.1524	.1852	.1852	.1829	.16
15	.1852	.2134	.1524	.1875	.2134		.192
16	.1524	.216	.1524	.1852	.216	.1524	.1562
17	.1204	.1852	.1524	.1235	.1852	.1524	.1219
18		.2469	.1829	.1852	.1486	.1829	.1852
19	.2561	.2469	.2134	.25	.2743	.2439	.25
20	.3239	.3086	.2743	.2915	.3277	.3048	.25
21	.3239	.3086	.3048	.3277	.3239	.3048	.253
22	.3239	.3086	.3048	.3277	.3277	.3048	.2561
23	.3239	.3239	.2743	.2949	.3277	.3048	.2622
24	.2743	.2561	.3277	.2743	.2949	.3277	.2743
Max	.3239	.3239	.3277	.3277	.3277	.3315	.2743
Min	.1204	.1174	.1524	.1235	.1189	.1524	.1219
Avg	.2269	.2174	.2363	.2188	.2284	.2495	.2068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344011 / 33/11 KV SHIVANI ROAD SUB

STAT

Feeder No / Name : 202 / Poghat -ag feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.016	.064	.6154	.016	.064	.0648
2	.3563	.016	.064	.0648	.4641	.4801	
3	.3563	.016	.064	.0648	.5441	.4801	
4	.3563	.016	.064	.0648	.6241	.4801	
5	.583	.016	.064	.0648	.7042	.4801	
6	.664	.016	.064	.0648	.7042	.5601	
7	.6964				.7682	.6401	
8	.6964				.8962	.6401	
9	.8097				.7522		
10	.6478	.7522					
11	.6882	.7682					
12	.6882	.7682					
13	.6081	.7682					
14	.6081						.6401
15	.6081						.7682
16	.6401						.8002
17	.6722		.7287				
18			.6964				
19		.3201		.016			
20	.016	.4001		.016	.064	.0648	.016
21	.016	.064	.5668	.016	.064	.0648	.016
22	.016	.064	.5668	.016	.064	.3239	.016
23	.016	.064	.6154	.016	.064	.0648	.016
24	.0648	.016	.064	.6154	.016	.064	.0648
Max	.8097	.7682	.7287	.6154	.8962	.6401	.8002
Min	.016	.016	.064	.016	.016	.064	.016
Avg	.4488	.2551	.3018	.1362	.4104	.339	.2669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344011 / 33/11 KV SHIVANI ROAD SUB

STAT

Feeder No / Name : 203 / DHAMANI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.0655	.5571	.0655	.1311	.0983	.0648
2	.0655	.0655	.5571	.5243	.1311	.0983	.0648
3	.0655	.0655	.5571	.5243	.0983	.0983	.0648
4	.0655	.0655	.5571	.5243	.0983	.0983	.0648
5	.0655	.0655		.5243	.0983	.0983	.0648
6	.0655	.0655		.5243	.0983	.0983	.0648
7				.5571			
8				.5571			
9				.5571			
10				.5243	.6554	.7362	.5506
11				.5571	.6401	.7042	.5506
12				.5898	.5761	.6722	.5506
13				.5898	.6401	.5761	.5571
14				.5243	.6401	.6081	.5243
15				.5243	.5441	.5441	.5243
16				.5571	.5441	.5121	.4915
17			.6226	.5898		.5121	.426
18			.6226			.064	
19	.1638			.0983		.064	.0655
20	.1638	.5441	.6226	.1311	.1311	.064	
21	.1311	.5121	.0655	.1311	.0983	.064	
22	.1311	.5441	.0648	.1311	.0983	.064	
23	.0983	.5441	.0648	.1311	.0983	.064	
24	.0655	.0983	.5571	.0655	.1311	.0983	.064
Max	.1638	.5441	.6226	.5898	.6554	.7362	.5571
Min	.0655	.0655	.0648	.0655	.0983	.064	.064
Avg	.0956	.2396	.4408	.4132	.3029	.2827	.2933

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344011 / 33/11 KV SHIVANI ROAD SUB

STAT

Feeder No / Name : 204 / PARWA GAVTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6089	.6089	.3582	.5373	.5373	.5792	.543
2	.6089	.6447	.3582	.5373	.5373	.543	.543
3	.6089	.6447	.3582	.5373	.5373	.543	.543
4	.6089	.6447	.3582	.5373	.5373	.543	.543
5	.5731	.6447	.3582	.5373	.5014	.543	.543
6	.5373	.6447	.3582	.5014	.5014	.4706	.4706
7	.5014	.5731	.3582	.4298	.4656	.3982	.3982
8	.4298	.394		.4835	.394	.3982	.3982
9	.4298	.4298	.3224	.5014	.394		.3258
10		.394	.3224	.4298	.5014	.5068	.362
11	.5373	.3582	.394	.4298	.4298		.4298
12	.5373	.3582	.5014	.4298	.4344	.4706	.4298
13	.5373	.4298	.5373		.5068	.4344	.4298
14	.5014	.4656	.6447	.4298	.5068	.4344	.394
15	.394	.5373	.6447	.4298	.4706	.4344	.394
16	.394	.5373	.5731	.4298	.4706	.4344	.394
17	.394	.5014	.5731	.4298	.394	.4344	.4298
18		.5731	.6447	.5373	.5068	.4706	.5373
19	.6805	.6447		.6089	.543	.6154	.3224
20	.6805	.5731	.7164	.6089	.6516	.6878	.5731
21	.6805	.1433	.7164	.6089	.6089	.6878	.6447
22	.6447	.1433	.6447	.6089	.6154	.6516	.6447
23	.6447	.1433	.5731	.6089	.6154	.5792	.6447
24	.6089	.6447	.3582	.5731	.6089	.6154	.543
Max	.6805	.6447	.7164	.6089	.6516	.6878	.6447
Min	.394	.1433	.3224	.4298	.394	.3982	.3224
Avg	.5519	.4865	.4852	.5116	.5113	.5216	.4784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344012 / 33/11 KV ASEGAON SUB-STATION

Feeder No / Name : 201 / dhanora

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5247	.4401	.4572	.5117	.423	.4923	.463
2	.5247	.4108	.4268	.5247	.423	.4572	.463
3	.5312	.4108	.4374	.5182	.4172	.4572	.4572
4	.5487	.4161	.4687	.5693	.4252	.4512	.4755
5	.5647	.4254	.5624	.5944	.439	.4512	.4923
6	.5944	.5068	.6882	.6161	.4534	.4793	.5075
7	.4401	.4054		.5502	.5182	.439	.4001
8	.4344	.3018	.4374	.4512	.2332	.4329	.3155
9	.4054	.298	.4161	.4115	.212	.4058	.2766
10	.3948	.2892	.4058	.3841	.1627	.487	.2724
11	.3841	.301	.3096	.3517		.3681	.285
12	.3368	.2538	.2926	.3018		.3467	.3246
13	.3467	2.7073	.2934			.3384	.3246
14	.3382	.2134	.3185	.2936		.3666	.3155
15	.3111	.192	.3185	.2881	.1486	.3715	.3199
16	.3018	.2195	.3429	.298	.1486	.4054	.3102
17	.3477	.2538	.3944	.3001	.2683	.3715	.2705
18	.4287	.3658	.4115	.4268		.4054	.3704
19	.5068	.4687	.4694	.5489		.4054	.535
20	.5944	.6401	.5864	.5681	.4995	.5068	.5647
21	.5502	.6097	.5944	.5411		.535	.535
22	.5144		.5944	.5075		.5268	.4988
23	.4778	.4572	.5719	.4934		.5053	.4755
24	.4344		.4572	.535	.4572	.4923	.5182
Max	.5944	2.7073	.6882	.6161	.5182	.535	.5647
Min	.3018	.192	.2926	.2881	.1486	.3384	.2705
Avg	.4515	.4812	.4459	.4602	.3486	.4374	.4071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344012 / 33/11 KV ASEGAON SUB-STATION

Feeder No / Name : 202 / Wara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7514	.7888	.7545	.7888	.7276	.6287	.8291
2	.7514	.7868		.8002	.7276	.5959	.8413
3	.7735	.7868	.7255	.8002	.7385	.5959	.8269
4	.8002	.7868		.8657	.7385	.6935	.8928
5	.8002	.7888	.7202	.9069	.7404	.7735	.9335
6	.7888	.9069	.7888	.9202	.7545	.9069	1.0254
7	.6893	.6893	.7255	.868	.7796	.7404	.9164
8	.6539	.7316	.5761	.756	.7554	.7183	.7202
9	.6287	.7087	.6481	.7087	.6508	.6722	.6973
10	.6097	.663		.6973	.6182	.6276	.663
11	.567	.663	.5239	.663		.6722	.6188
12	.5958		.442	.6182		.6615	.6078
13	.5944	.6188	.5304	.3111		.6508	.5958
14	.6024	.5975	.5304	.4572		.6401	.5845
15	.4915	.6409	.5746	.3719	.5746	.6173	.5716
16	.3597	.5525	.6295	.4572	.5761	.567	.5346
17	.4881	.6173	.6973	.5716	.5975	.6097	.5373
18	.6584	.7087	.7682	.6842	.6481	.8421	.6508
19	.9318	.7087	.8173	.8173	.9556	.9556	.8169
20	.9069	.8299	.8935	.8935	.9069	1.0364	.8676
21	.8808	.881	.8048	.8551		1.0105	.8291
22	.8551	.6859	.8291	.8048		.9701	.7659
23	.8169	.7087	.8032	.743		.9069	.7293
24	.7903		.743	.8032	.7293	.6287	.8425
Max	.9318	.9069	.8935	.9202	.9556	1.0364	1.0254
Min	.3597	.5525	.442	.3111	.5746	.567	.5346
Avg	.6994	.7205	.6917	.7151	.7188	.7384	.7458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 202 / tarala-ag feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1402	.1402	.1417				
3	.1402	.1402	.1417				
4	.1753	.1402	.1417				
5	.1734	.1753	.1417				
6	.208	.1753	.1417				
7	.208	.1753	.2126				
8	.2427	.208	.2481				
9	.2743	.2601	.2303				
10				.2774	.2454	.2572	.2774
11				.208	.208	.208	.208
12				.2058	.1715	.2058	.1734
13				.1715	.1715	.1715	.1387
14				.1372	.1715	.1372	
15				.104	.1715	.1372	.1372
16				.1753	.1715	.1372	.1029
17				.2103	.2058	.1372	.1715
Max	.2743	.2601	.2481	.2774	.2454	.2572	.2774
Min	.1402	.1402	.1417	.104	.1715	.1372	.1029
Avg	.1953	.1768	.1749	.1862	.1896	.1739	.1727

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 204 / 11kv kanzara gavthan

GAOTHAN FEEDER

feeder Feeder KV- 11 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.298	.2439	.3012	.1219	.1753	.0648
2	.1753	.2629	.25	.2835	.1219	.1753	.2804
3	.1753	.2629	.2429	.2835	.1219	.1753	.3012
4	.1753	.2629	.2343	.3012	.1219	.1753	.3012
5	.1907	.2629	.2591	.3189	.1219	.1753	.3189
6	.1907	.3506	.3201	.3544	.1219	.1753	.3544
7	.208	.3506	.3048	.4382	.0762	.1387	.3681
8	.2947	.3467	.2774	.4334		.1387	.3814
9	.2915	.3429	.3294	.3814	.2591	.2572	
10	.3086	.3086	.3429	.3121	.2656	.4287	
11		.2462		.2601	.2427	.3467	
12		.2709	.298	.1981	.1886	.3429	
13	.3429	.1981	.1753	.1806	.2058	.3944	
14	.2743	.2258	.2454	.1829	.2572	.3258	.2743
15	.2915	.2258	.2835	.1734	.1886	.3258	.2439
16	.3429	.286	.2629	.1981	.2058	.2915	.3048
17	.4287	.301	.3681	.2439	.2572	.3258	.5182
18	.4801	.301	.3856	.3506	.0857	.3856	.4167
19	.3086	.3353	.4031		.4287	.4031	.3704
20	.3429	.2932	.3721		.4287	.3898	.3906
21	.2947	.2656	.3544		.3429	.3544	.3437
22	.2947	.2656	.3366	.1417	.3429	.3189	.394
23	.2774	.25	.3189	.1219	.2601		.3403
24	.1928		.2591	.3012	.125	.1734	.3012
Max	.4801	.3506	.4031	.4382	.4287	.4287	.5182
Min	.0876	.1981	.1753	.1219	.0762	.1387	.0648
Avg	.2713	.2832	.2986	.2743	.2127	.2780	.3299



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 205 / 11kv Tarhala Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8063	.7011	.815	.7442	1.0387	.7888	.7712
2	.7712	.7011	.815	.7796	1.0387	.7888	.7362
3	.7712	.7011	.815	.7796	.9313	.7888	.7087
4	.7011	.7011	.7087	.8505	.9313	.7888	
5	.6935	.7011	.7087	.8859	.7442	.7888	.7442
6	.7628	.7011	.7442	.9114	.815	.7011	.7442
7	.7975	.7716	.7442	.8413	.6379	.7802	.7282
8	.9015	.7011	.8505	.9015	.7796	.8669	.5895
9	.9602	.6935	.7975	.8322	.7011		.6935
10	.7888	.6859	.7545	.6935	.6661	.6859	.6588
11	.6859	.6001	.6859	.6241	.5895	.6935	.6935
12	.6859	.6173	.6661	.6173	.6859	.6859	.5548
13	.6859	.6173	.7011	.5895	.6859	.583	.5895
14	.6859	.5487	.6661	.5895	.6859	.6173	.583
15	.6859	.583	.6733	.5895	.6859	.583	.6173
16		.5201	.7011	.6661	.6859	.5144	
17	.0686	.6935	.7011	.631	.6001	.5144	
18	.8573	.8063	1.0166	.7087	.6859	.8413	.6935
19	.9431	.4908	1.0517	.8859	1.0288	.8764	.7975
20	1.0288	1.0277	1.0631	.9922	1.0288	1.0631	.9214
21	.9015	.9568	1.0277	.9922	.9431	.8859	.9214
22	.8669	.9568	.8859	1.0029	.9431	.8505	.9313
23	.8669	.8859	.815	.8954	.8669		.8238
24	.8063		.8505	.7796	1.0387	.7802	.7796
Max	1.0288	1.0277	1.0631	1.0029	1.0387	1.0631	.9313
Min	.0686	.4908	.6661	.5895	.5895	.5144	.5548
Avg	.7706	.7114	.8024	.7827	.8099	.7485	.7277

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 206 / 11kv Hirangi ww Feeder

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0351	.0354	.0354	.0709	.0351	.0351
2	.0351	.0351	.0354	.0354	.0358	.0351	.0351
3	.0351	.0351	.0532	.0532	.0532	.0351	.0354
4	.0351	.0351	.0709	.0532	.0532	.0351	.0532
5	.052	.0351	.0354	.0532	.0532	.0351	.0532
6	.052	.0351	.0354	.0526	.0351	.0526	.0532
7	.052	.0526	.0709	.0701	.0876	.052	.0509
8	.0693	.052	.0693	.0867	.0886	.052	.052
9	.0686	.0693	.0693	.0867	.0701	.0514	.0347
10	.0686	.0686	.0686	.0876	.0876	.0514	.0351
11	.0686	.0686	.0514	.0693	.0173	.0693	.052
12	.0686	.0686	.0701	.0857	.0514	.0686	.052
13	.0686	.0171	.0701	.0693	.0514	.0171	.0867
14	.0686	.0686	.0686	.0693	.0514	.0686	
15	.0686	.0686	.0709	.052	.0514	.0686	.0514
16	.0514	.0343	.0701	.0686	.0514	.0686	.0514
17	.0514	.0514	.0701	.0351	.0343	.0686	.0686
18	.0514	.052	.0526	.0354	.0343	.0526	.0693
19	.0514	.0351	.0351	.0886		.0526	.0173
20	.0514	.0354	.0532	.0886	.0343	.0532	.0354
21	.0514	.0354	.0532	.0179	.0343	.0354	.0532
22	.052	.0532	.0532	.0895		.0354	.0358
23	.0347	.0532	.0354	.0358	.0347		.0358
24	.0351		.0532	.0354	.0537	.0347	.0354
Max	.0693	.0693	.0709	.0895	.0886	.0693	.0867
Min	.0347	.0171	.0351	.0179	.0173	.0171	.0173
Avg	.0532	.0476	.0563	.0606	.0516	.0491	.0471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344013 / 33/11 KV SHELU BAZAR SUB

STATI

Feeder No / Name : 207 / Shelu AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3321	1.4022	1.382	1.4175	1.2894	1.3146	1.4022
2	1.2971	1.4022	1.382	1.382	1.2894	1.3146	1.3672
3	1.2269	1.4022	1.4175	1.2403	1.2403	1.3146	1.3466
4	1.1919	1.4022	1.5061	1.4175	1.2403	1.3146	1.3112
5	1.3176	1.4899	1.5592	1.4175	1.2757	1.3146	1.2403
6	1.4217	1.7528	1.701	1.4373	1.2757	1.4022	1.2757
7	1.6991	1.7528	1.5947	1.6827	1.2048	1.387	1.2971
8	1.7337	1.7337	1.5238	1.283	1.134	1.387	1.283
9	1.7147	1.6289	1.5257	1.387	1.1919	1.3717	1.387
10	1.2689	1.2003	1.1317	1.7337	1.5424	1.7147	1.6991
11	1.286	1.286	1.2003	1.7337	1.4563	1.7337	1.6644
12		1.3032	1.1568	1.5089	1.5432		1.491
13	1.3717	1.2689	1.2269	1.491	1.5432	1.2003	1.387
14	1.3717	1.2136	1.2269	1.5604	1.6289	1.2346	1.3717
15	1.0288		1.0631	1.5257	1.5432	1.5089	1.387
16	1.3717	1.3375	.9114	1.1919	1.3717	1.4403	1.5089
17	1.4575	1.3176	1.0867	1.5775	1.7147	1.5089	1.5089
18	1.5432	1.4217	1.4022	1.2403	1.3717	1.3672	1.5604
19	1.7147	1.5775	1.7177	1.3466	1.5432	1.5074	1.5604
20	1.7147	1.701	1.7718	1.4529	1.7147	1.7718	
21	1.6289	1.5592	1.5947	1.4175	1.6289	1.5947	1.5947
22	1.5604	1.5238	1.5592	1.3969	1.5432	1.5238	1.5947
23	1.4737	1.4883	1.5238	1.3969	1.4737		1.5402
24	1.4022		1.4175	1.4883	1.2894	1.387	1.4175
Max	1.7337	1.7528	1.7718	1.7337	1.7147	1.7718	1.6991
Min	1.0288	1.2003	.9114	1.1919	1.134	1.2003	1.2403
Avg	1.4404	1.4621	1.3993	1.4470	1.4187	1.4370	1.4433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344034 / 33/11 KV DASTAPUR SUB

STATION

Feeder No / Name : 201 / 11 KV DASTAPUR FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5243	.5144	.5967		.1143		.5801
2	.5243	.5144	.5868		.1143		.5533
3	.5243	.5144	.9116		.1143		.5365
4	.5079	.4807	.5868	.0629	.1143	.5201	.5426
5	.2743	.431	.4588		.1334		.3944
6	.3077	.431	.4748	.4049	.1334		.39
7	.3077	.3812	.3772	.4096	.1143	.5087	.2774
8	.5601	.6783	.5967	.7461	.1334	.6344	.663
9	.5851	.6706	.7127	.8478	.1143	.6104	.6344
10	.5335	.5426	.6062	.6104	.0381	.5365	.6443
11	.3647	.5316		.5868	.6859	.6962	.5636
12	.3647	.3429		.5304	.6274	.5636	.4409
13	.1907	.1387	.2458	.3315	.6104	.2515	.1492
14	.1907	.1387	.2713		.6104	.2683	.1989
15		.1402	.2561		.4024	.2713	.2321
16	.1907	.1734	.2458		.3932	.2947	.1658
17	.2804	.2401	.2267		.3315	.2454	.1658
18	.2804	.2947	.2561		.3688	.2601	.1658
19	.4207	.3944	.3113		.5801	.3506	.2652
20	.9431	.8288	.743		.7373	.6068	.663
21	.9431	.823	.7293	.0354		.8122	.5801
22	.8288	.7625		.1595	.78	.7293	.4973
23	.663	.6133	.639	.1595	.78	.6464	.4475
24	.5571	.6001	.6062	.6539	.116		.6203
Max	.9431	.8288	.9116	.8478	.78	.8122	.663
Min	.1907	.1387	.2267	.0354	.0381	.2454	.1492
Avg	.4725	.4659	.4971	.4261	.3542	.4893	.4321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344034 / 33/11 KV DASTAPUR SUB

STATION

Feeder No / Name : 202 / 11 KV KASOLA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.583	.6882		.7122		.6882
2	.3944	.583	.663		.7122		.6882
3	.3944	.583	.6554		.7122		.663
4	.3944	.5765	.6554	.7045	.7122	.6859	.6882
5	.2286	.5087	.4973		.4239		.407
6	.2286	.4917	.503	.4239	.4748		.4287
7	.1715	.373	.39	.3856	.4144	.39	.4115
8	.4588	.5596	.5967	.7459	.8309		.7209
9	.4321	.5868	.5735	.8551	.8309	.7888	.6796
10	.3749	.5596	.5801	.7625	.8309	.7461	.6882
11	.6274	.5487		.7461		.663	.6464
12	.5801	.4973		.6962	.6539	.6718	.5801
13	.3561	.3641	.3052	.2818	.2883	.4024	.3149
14	.3561	.4161	.3018	.2818	.2713	.3391	.3315
15	.3561	.4207		.3012	.2713	.3561	.3315
16	.3561	.3506	.2683	.3012	.2683	.3258	.2818
17	.3582	.3121	.2458	.3012	.2486	.3222	.3315
18	.2686	.2774	.2652	.3012	.3222	.3258	.3149
19	.0895		.2683	.3772	.6783	.3772	.3437
20	.7164	.6796	.8619	.6859	.9116	.9339	.8785
21	.7164	.6464	.8029	.7888		.8619	.8122
22	.6613	.779		.7888	.8648	.8356	.779
23	.6613	.7625	.8192	.78	.788	.7956	.7459
24	.4359	.6001	.7537	.8551	.7461		.7293
Max	.7164	.779	.8619	.8551	.9116	.9339	.8785
Min	.0895	.2774	.2458	.2818	.2486	.3222	.2818
Avg	.4172	.5243	.5347	.5682	.5894	.5777	.5619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANGRULPEER[278]

BU 1538

Substation No/ Name :- 344034 / 33/11 KV DASTAPUR SUB

STATION

Feeder No / Name : 203 / 11 KV DAM FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	1.3763	1.1561	1.1523		.9374		
6	1.3763	1.1561	1.1984	1.0322	.9231		
7	1.3599	1.1717	1.1797	1.0608		.3353	
8	1.3763						
13	1.3435	1.2803	1.1843	.9998			1.078
14	1.3435	1.3279	1.2452	.9998		.3391	1.078
15	1.3435	1.3123	1.166	.9998	.285	.3391	1.078
16	1.3435	1.2803	1.0883	.9998	.3052	.3641	.9842
17	1.3123	1.3117	1.1633	.9998	.3429	1.1469	1.0155
18	1.2967	1.2803	1.1233	.953	.3018	1.1203	1.0623
19	1.4506	1.2308	1.1568	.9374		1.166	1.0467
Max	1.4506	1.3279	1.2452	1.0608	.9374	1.166	1.078
Min	1.2967	1.1561	1.0883	.9374	.285	.3353	.9842
Avg	1.3566	1.2508	1.1658	.9980	.5159	.6873	1.0490

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 201 / 11 kv amgavan feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764		.8573	.8669			1.1568
2	.8764		.8573	.8669	.8417		1.1317
3	.8764		1.0631	.8669	.8238		1.1694
4	.8764		1.0867	.8669	.8764		1.1568
5	.8764		1.2048	.8669	.9745		1.1568
6	1.0517		1.1919	1.0059	1.0056		1.1919
7	1.2431		1.2048	1.0059	1.0923		1.2269
8	1.2431		1.1919	1.1869	1.0852		1.2269
9	1.2431		1.166	1.1869	1.0774		1.1469
10	1.2431		1.166	1.1869	1.0526		1.1603
11		1.0753	.8097	.9831		.9282	.9686
12			.8097			1.0166	1.004
13		.0995	.7287	.8288		.9503	.8097
14		1.2887	.7287	.8383		.8848	.8097
15		1.2548	.8907	.7865		.8383	.8097
16		1.2136	.8907	.779		.8097	1.0802
17		1.0936	.9686	.9831			1.0802
18		1.1469	.9686	1.0059		1.2803	1.0802
19		1.2136	1.0517	1.0174		1.3413	1.0402
20			1.0517	1.0517		1.3413	1.0402
21		1.0288	.8669	1.0166		1.3717	1.0402
22		.9922	.8669	.9745		1.4022	1.0402
23		.8764	.8669	.8859		1.2003	1.0402
24	.8764	.8573		.8669	.8859		1.2269
Max	1.2431	1.2887	1.2048	1.1869	1.0923	1.4022	1.2269
Min	.8764	.0995	.7287	.779	.8238	.8097	.8097
Avg	1.0257	1.0117	.9778	.9532	.9715	1.1138	1.0748

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 202 / 11 KV GAWHA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.0857	.1063	.1267	.1086	.1029	.1029
2	.1612	.0857	.1063	.1294	.0905	.0857	.1052
3	.1612	.0857	.1052	.1307		.0857	.1063
4	.1612		.1063	.1267	.0905	.0857	.1063
5	.1612	.0857	.1063	.1267	.0905	.0857	.1052
6	.1612	.1029	.1063	.0914	.1109	.1029	.1063
7	.1052	.1372	.1029	.0572	.1086	.1357	.1417
8	.1052	.1357	.1463	.1357	.1254	.1372	.1417
9	.1052	.1357	.1417	.1357	.1029	.1326	.1326
10	.1052	.1372	.1417	.1357	.1029	.1326	.1341
11	.1187	.0995	.1372	.0857	.12	.1235	.0983
12	.116		.1372		.12	.1372	.0983
13	.1174	.1372	.104	.12	.12	.1326	.1029
14	.1187	.1372	.104	.0867	.12	.1357	.1187
15	.1134	.1372	.1357	.1187	.1372	.1341	.1187
16	.1187	.1357	.1357	.1372	.1357	.1357	.0937
17	.116	.1029	.1296	.1357	.1341	.1372	.0937
18	.1174	.0995	.1296	.12	.1357	.1341	.0937
19	.1372	.1075	.1463	.1595	.1372	.1417	.1075
20	.1372	.1029	.1463	.1612	.1372	.1402	.1075
21	.1187	.1063	.1267	.1463	.1372	.1417	.1075
22	.12	.1063	.1267	.128	.12	.1402	.1075
23	.1029	.1052	.1267	.1267	.12	.1052	.1075
24	.1433	.1063		.1267	.1267	.1029	.1052
Max	.1612	.1372	.1463	.1612	.1372	.1417	.1417
Min	.1029	.0857	.1029	.0572	.0905	.0857	.0937
Avg	.1285	.1125	.1241	.1238	.1188	.1220	.1101



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 203 / 11 KV KONDOLI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4327	1.286	1.4175	1.4175	1.6118	1.286	1.387
2	1.4327	1.2346	1.3717	1.4022	1.5223	1.2003	1.4175
3	1.4327	1.2003	1.4175	1.4022	1.4022	1.2003	1.4175
4	1.4327	1.2003	1.4175	1.4022	1.4175	1.2003	1.387
5	1.4327	1.2717	1.4022	1.4022	1.387	1.286	1.5947
6	1.6118	1.4251	1.4175	1.4899	1.4327	1.3717	1.5947
7	1.5089	1.3748	1.4175	1.4899	1.4737	1.4586	1.5947
8	1.5089	1.5089	1.5074	1.4251	1.4918	1.3592	1.5775
9	1.5089	1.4089	1.5424	1.4251	1.5746	1.326	1.4918
10	1.5089		1.5257	1.4251			1.5432
11	1.442		1.4746	1.3413	.8192	1.3717	1.3717
12	1.3108		1.4746		.8288	.9835	1.3717
13	1.2431	1.5432	1.3108	1.3565	.8288	1.3904	1.3565
14	1.1105	1.5432	1.2193	1.3413	1.1869	1.2955	1.3565
15	1.1934	1.5432	1.3108	1.2431	1.2574	1.1869	1.3565
16	1.326	1.4746		1.1736	1.291	1.1336	
17	1.3927	1.326	1.4899	1.3413	1.326	1.2269	.0937
18	1.4918	1.4255	1.4899	1.326	1.5927	1.5432	.9374
19	1.6956	1.3717	1.4899	1.8861	1.8652	1.8004	1.7718
20	1.8004	1.5775	1.4899	1.8404	1.8861	1.8861	1.7718
21	1.6956	1.7718	1.5947	1.7909	1.8347	1.9281	1.7718
22	1.5089	1.7528	1.5947	1.7718	1.6289	1.7909	1.7718
23	1.4575	1.5947	1.5947	1.6118	1.4575	1.5947	1.5947
24	1.4327	1.5432		1.5947	1.6118	1.3717	1.5947
Max	1.8004	1.7718	1.5947	1.8861	1.8861	1.9281	1.7718
Min	1.1105	1.2003	1.2193	1.1736	.8192	.9835	.0937
Avg	1.4547	1.4466	1.4532	1.4739	1.4230	1.3997	1.4403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 204 / 11 kv Manora Town Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	.9431	1.0517	.9955	.9694	.9431	.6859
2	1.086	.8573	.8573	.9955	.924	.8573	.6859
3	1.086	.8573	.8573	.8954	.9145	.7716	.6935
4	1.086	.7716	.8573	.8954	.924	.7716	.6859
5	.9145	.7716	.8573	.8954	.9145	.8059	.6935
6	.9145	.8573	.8573	.9145	.924	.8573	.8764
7	.823	.8669	.8573	.9145	.905	.8573	.8764
8	.823	.823	.9362		.9313	.823	.8669
9	.823	.8059	.9259	.8954	.8954	.8573	.905
10	.823	.8573	.8573	.8954	.9745	.8916	.8764
11	.8573	.9313	.985	.8059	.9431	.8954	.8417
12	.8573		.985		.9431	.8764	.8417
13	1.0288	.8916	1.0387	.8954	.9431	.8573	.9774
14	1.0288	.9015	1.0387	.9745	.9774	.8573	.9774
15	1.0631	.8573	1.0745	.985	1.0288	.823	.9671
16	1.0288	.823	1.0745	.9955	1.0288	1.0029	.9465
17	.9431	1.0029	1.0631	.9671		.905	.9465
18	.9774	1.0029	1.0631	.9955	.9774	.964	.9465
19	1.0288	1.086	1.134	1.0745	1.0288	.985	1.0745
20	1.1145	1.0174	1.134	1.086	1.0288	1.0136	1.0745
21	1.1361	1.0513	1.134	1.0974	.9945	1.0029	1.0745
22	.0486	1.0631	1.134	1.0059	1.0631		1.0745
23	1.0631	1.0517	1.134	1.0059	1.0288	.8326	.985
24	1.086	1.0517		1.134	1.0059	1.0288	.7975
Max	1.1361	1.086	1.134	1.134	1.0631	1.0288	1.0745
Min	.0486	.7716	.8573	.8059	.8954	.7716	.6859
Avg	.9469	.9193	.9960	.9691	.9682	.8904	.8905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344015 / 33 KV MANORA

Feeder No / Name : 205 / 11kv manora industrial

feeder Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267	.0351	.0339	.0335	.0328	.0335	.0343
2	.0267	.0351	.0339	.0335	.0324	.0339	.0343
3	.0267	.0347	.0343	.0335	.0328	.0343	.0351
4	.0267	.0347	.0343	.0335	.0324	.0343	.0351
5	.0354	.0312	.0343	.0335	.0328	.0343	.0351
6	.0354	.0305	.0343	.0335	.0335	.0328	.0343
7	.0305	.0343		.0335	.0486	.0316	.0343
8	.0305	.044	.0678	.0267	.064	.0474	.0678
9	.0305	.0743	.0693	.0267	.081	.0714	.0648
10	.0743		.0678	.0267	.0474	.0714	.0648
11	.0848	.1219	.0657	.1094	.0791	.0838	.0734
12	.0772		.0657		.08	.0762	.0734
13	.081	.1357	.0324	.1094	.081	.0724	.081
14	.0876	.1357	.0324	.081	.0791	.0714	.081
15	.0724	.1372	.029	.1147	.08	.0762	.081
16	.0686	.1372	.029	.1296	.0762	.0743	.0734
17	.0667	.1128	.0236	.096	.0667	.0724	.0293
18	.0714	.1097	.0236	.081	.0819	.0743	.0293
19	.0724	.0857	.0347	.0633	.0829	.081	.0332
20	.0514	.0914	.0347	.0686	.0829	.0619	.0332
21	.0509	.061	.0335	.052	.0503	.0667	.0332
22		.0343	.0335	.0514	.0457	.0762	.0332
23	.0526	.0339		.0335	.048	.0343	.0332
24	.0248	.0335		.0335	.0324	.0497	.0343
Max	.0876	.1372	.0693	.1296	.0829	.0838	.081
Min	.0248	.0305	.0236	.0267	.0324	.0316	.0293
Avg	.0524	.0720	.0404	.0582	.0585	.0582	.0484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344016 / 33 KV POHARADEVI

Feeder No / Name : 201 / umari

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0259	.0754	.0568			
2	.1985	.3269	.3582	.4938			
3	.1947	.3989	.4378	.5071			
4	.1901	.4177	.4637	.4687			
5	.2206	.5056	.4904	.5719			
6	.4546	.8231	.8249	.8717			
7	.7319	1.2121	1.0852	1.0539			
8	.8616	1.0606	1.1153	1.0288			
9	.8234	.7803	.4766	.9015	.0221	.085	.1406
10				.783	.9793	1.0249	1.0021
11				.623	1.0106	1.2239	1.012
12				.5621	1.0155	1.0784	.94
13				.3642	.9545	.9313	.8497
14				.3494	.8048	.7921	.6924
15				.5274	.7392	.8032	.7301
16				.6074	.9747	.7415	.7571
17				.5346	1.0041	.6767	.7914
24							.0758
Max	.8616	1.2121	1.1153	1.0539	1.0155	1.2239	1.012
Min	.0358	.0259	.0754	.0568	.0221	.085	.0758
Avg	.4124	.6168	.5919	.6062	.8339	.8174	.6991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344016 / 33 KV POHARADEVI

Feeder No / Name : 202 / poharadevi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.218	.1265	.4123	.1555			
2	.322	.4431	.4546	.2465			
3	.3151	.482	.4988	.3018			
4	.3391	.4988	.5296	.3045			
5	.3795	.5818	.5807	.3406			
6	.5666	.8276	.9084	.4927			
7	.5582	.9385	.9396	.5064			
8	.7674	.905	.8848	.4854			
9	.7621	.8032	.1985	.4607	.0774	.2583	.3311
10				.415	.7743	.7735	.7788
11				.3445	.9065	.964	.8631
12				.3879	.9701	.9503	.8577
13				.482	.8425	.7865	.783
14				.5312	.7194	.6291	.5586
15				.6215	.2984	.5026	.6329
16				.7148	.6177	.644	.6847
17				.7423	.6836	.6268	.7339
18				.2808			
19				.2484			
20				.1829			
21				.1623			
24							.3185
Max	.7674	.9385	.9396	.7423	.9701	.964	.8631
Min	.218	.1265	.1985	.1555	.0774	.2583	.3185
Avg	.4698	.6229	.6008	.4004	.6544	.6817	.6542

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344016 / 33 KV POHARADEVI

Feeder No / Name : 203 / 11 kv s/stn wai

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5761	.5121	.506	.583			
3	.4481	.7362	.6325	.6722			
4	.4481	.7042	.6958	.6401			
5	.5693	.8539	.8855	.6478			
6	.6325	1.2651	1.3123	.7611			
7	.8962	1.5546	1.5364	.8642			
8	1.2334	1.4723	1.4083	.8745			
9	1.2498	1.2967	.4458	.7682			
10				.6958	1.358	1.3283	1.6194
11				.7407	1.4373	1.6004	1.4403
12				.7621	1.5181	1.4548	1.4548
13				1.0235	1.3123	1.0802	1.3916
14				1.0288	1.2163	1.0185	1.0437
15				1.1584	1.1385	1.0185	1.2018
16				1.1888	1.1385	1.0623	1.0311
17				1.2654	1.1385		.9998
18				.3734			
19				.3814			
20				.2972		.9842	
21				.2709			
Max	1.2498	1.5546	1.5364	1.2654	1.5181	1.6004	1.6194
Min	.4481	.5121	.4458	.2709	1.1385	.9842	.9998
Avg	.7567	1.0494	.9278	.7499	1.2822	1.1934	1.2728

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344016 / 33 KV POHARADEVI

Feeder No / Name : 204 / COE ZP WAI EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1418	.0286	.2557	.2934	.2934	.2557
2	.2263	.104	.0286	.2177	.2934	.2934	.2542
3	.1886	.104	.0286	.2463	.2366	.2743	.2256
4	.1886	.104	.0286	.2463	.2271	.3029	.2176
5	.1886	.1418	.0286	.2652	.2271	.3029	.2365
6	.1886	.1418	.0286	.2652	.1894	.2366	.246
7	.1886	.104	.0286	.2177	.1705	.2271	.2082
8	.1509	.0663	.0286	.2082	.1705	.1516	.1989
9		.0663	.0286	.1799	.1516	.1421	.1799
10		.0286	.0286	.1139	.1421	.1421	.1799
11		.0286	.0286	.1516	.1421	.0286	.1421
12		.0286	.0286	.0754	.104	.0286	.0286
13		.0286	.0286	.0754	.0286	.0286	.0286
14		.0286	.104	.104	.0286	.0286	.0286
15		.0286	.2275	.104	.0286	.0286	.0191
16		.0286	.1897	.104	.0191	.0286	.0286
17		.0286	.1709	.104	.0286	.0286	.0286
18		.0286	.1989	.104	.0286	.0286	.0286
19	.0754	.0663	.0663	.104	.0286	.0286	.104
20	.1132	.0663	.1796	.1418	.1992	.2086	.1894
21	.1509	.0663	.2271	.1704	.3124	.2086	.2652
22	.1132	.0663	.2463	.2652	.3029	.218	.2934
23	.1132	.0663	.2368	.3029	.2934	.218	.2934
24	.2263	.1418	.1048	.2368	.2934	.2934	.218
Max	.2263	.1418	.2463	.3029	.3124	.3029	.2934
Min	.0754	.0286	.0286	.0754	.0191	.0286	.0191
Avg	.1671	.0710	.0968	.1775	.1642	.1571	.1624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344016 / 33 KV POHARADEVI

Feeder No / Name : 205 / WAI GOATHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4003	1.531	1.5123	1.587	1.4937	1.4563	1.6244
2	1.419	1.4937	1.4937	1.5497	1.4563	1.419	1.6057
3	1.4003	1.4937	1.4937	1.531	1.419	1.419	1.6057
4	1.363	1.4937	1.4937	1.531	1.3817	1.4937	1.643
5	1.419	1.5684	1.4937	1.6057	1.419	1.531	1.7177
6	1.4937	1.7551	1.531	1.6804	1.5364	1.6991	1.8298
7	1.587	1.7551	1.4377	1.7551	1.7924	1.6804	1.6057
8	1.643	1.7177	1.3443	1.6804	1.6804	1.643	1.4563
9	1.5497	1.4937	1.3443	1.531	1.4937	.5601	1.307
10	1.3256	1.307	1.2883	1.3817	1.307	1.251	1.1949
11	1.251	1.1389	1.0456	1.3817	1.1389	1.1016	1.0456
12	1.1949	1.1203	1.1389	.3361	1.0829	1.1203	1.0456
13	1.1576	1.0082	1.1576	1.0829	1.1203	1.1203	1.0829
14	1.1203	1.0082	1.1576	1.1203	1.1203	1.1203	1.1203
15	1.1203	1.0456	1.1949	1.1203	1.1576	1.1389	1.1576
16	1.1949	1.0082	1.2323	1.2136	1.1949	1.1576	1.1576
17	1.3443	1.0456	1.251	1.2696	1.2696	1.2696	1.1949
18	1.3443	1.3256	1.5684	1.5497	1.4563	1.7364	1.3443
19	1.8671	1.8298	1.7737	1.9044	1.9418	1.8671	1.9791
20	1.8298	1.8111	1.8111	1.8671	1.8671	1.8298	2.0165
21	1.7737	1.7737	1.7364	1.7924	1.7737	1.7924	1.643
22	1.6057		1.6617	1.6617	1.643	1.7364	1.5684
23	1.5684	1.643	1.6244	1.5684	1.5497	1.6804	1.531
24	1.587	1.5497	1.5684	1.587	1.531	1.5123	1.6244
Max	1.8671	1.8298	1.8111	1.9044	1.9418	1.8671	2.0165
Min	1.1203	1.0082	1.0456	.3361	1.0829	.5601	1.0456
Avg	1.4400	1.4312	1.4314	1.4703	1.4511	1.4307	1.4626



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344017 / 33 KV DAPORA

Feeder No / Name : 201 / 11 kv DAPURA AG FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	19-MAY-17
HR	Load (MW)
8	.8573
9	.9259
11	.9259
12	.6859
14	.6344
Max	.9259
Min	.6344
Avg	.8059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344017 / 33 KV DAPORA

Feeder No / Name : 203 / COE ZP MASNI EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	16-MAY-17
HR	Load (MW)
3	.2058
Max	.2058
Min	.2058
Avg	.2058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344018 / 33 KV SAKHARDOH S/STN

Feeder No / Name : 201 / 11 kv s/stn sakhardoh

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.695	.6081	.6097	.6097
3				.6455	.6001	.6706	.6097
4				.5502	.6371	.6622	.7407
5				.5502	.6371	.6923	.7407
6				.5281	.7042	.7133	.7407
7				.5792	.7628	.884	.7407
8				.7727	.7628	.7827	.7407
9				.5716	.6539	.6081	.6859
10	.9031	.8322	.8802				
11	1.0494	.9568	.8322				
12	1.0623	.873	.8322				
13		.6539	.7628				
14		.6622	.724				
15		.5944	.695				
16		.6923	.724				
17	.9145	.7225	.6622				
19	.7621						
20	.7316						
Max	1.0623	.9568	.8802	.7727	.7628	.884	.7407
Min	.7316	.5944	.6622	.5281	.6001	.6081	.6097
Avg	.9038	.7484	.7641	.6116	.6708	.7029	.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344018 / 33 KV SAKHARDOH S/STN

Feeder No / Name : 202 / 11kv shendurjana

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.7913	1.6469	1.7665				
3	1.7368	1.7909	1.8275				
4	1.765	1.8374	1.848				
5	1.6949	1.8016	1.8853				
6	1.7178	2.2916	2.1323				
7	1.8191	2.4532	2.0371				
8	1.88	2.3411	1.9479				
9	1.7193	2.1796	1.9601				
10	.3376	.2865	.25	2.4882	2.6246	2.4101	1.8183
11				2.7115	2.9866	2.2558	1.9662
12				2.6253	2.7687	2.2055	1.8884
13				1.8511	2.4539	2.0309	1.9288
14				2.3091	2.3384	1.8854	1.7459
15				2.223	2.3296	1.7589	1.7093
16				2.322	2.2893	1.0349	1.9631
17				2.3952	2.3922	2.1551	1.0928
18				.3506	.3948	.4611	.2873
24							.6523
Max	1.88	2.4532	2.1323	2.7115	2.9866	2.4101	1.9662
Min	.3376	.2865	.25	.3506	.3948	.4611	.2873
Avg	1.6069	1.8476	1.7394	2.1418	2.2865	1.7997	1.5052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344018 / 33 KV SAKHARDOH S/STN

Feeder No / Name : 203 / SAKHARDOH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0498	1.0974	1.0719	1.0242	1.0349	1.0242
2	1.086	1.0136	1.0498	.9877	1.0242	.9877	.9979
3	1.0974	1.0029	.9877	1.0349	.9774	.9511	1.0349
4	1.1706	1.0631	1.0136	1.0498	.9774	.9979	.961
5	1.1827	1.0517	1.0498	1.0974	.9774	.961	.9979
6	1.1088	1.1827	1.0974	1.1088	1.0349	.961	1.0349
7	.9214	1.0745	1.0136	1.0242	.8871	.9511	.6653
8	.9313	1.0136	.9671	1.0498	.8871	.8688	.6653
9	.8596	.9412	.8954	.9412	.8048	.788	.6516
10	.7164	.8779	.8063	.9313	.7164	.8238	.7796
11	.7164	.8505	.7522	.8596	.788	.9922	.7087
12	.724	.815	.7796	.788	.7164	.7796	
13		.815	.7796	.7964	.7796	.7164	.788
14		.815	.7522	.8779	.7164	.7964	.7164
15		.7796	.7796		.7164		.7164
16		.7796	.7712	.7087	.7442	.788	.7164
17	.9114	.815	.8505	.7087	.7164	.788	.7164
18	1.0745	.8669	.7796	.8505	.8413	.8505	.7964
19	1.1462	1.1584	1.2178	1.0029	1.086	1.2178	1.0136
20	1.2308	1.3169	1.4118	1.3169	1.2567	1.39	1.2437
21	1.3169	1.2437	1.3169	1.2803	1.2567	1.2437	1.0608
22	1.0974	1.1827	1.2536	1.1827	1.2567	1.2437	1.1088
23	1.0974	1.1458	1.2071	1.1706	1.1827	1.0974	1.1088
24	1.134	1.086	1.0974	1.134	1.0349	1.0349	1.0242
Max	1.3169	1.3169	1.4118	1.3169	1.2567	1.39	1.2437
Min	.7164	.7796	.7522	.7087	.7164	.7164	.6516
Avg	1.0310	.9975	.9886	.9989	.9335	.9680	.8927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344031 / 33 KV SHENDURJANA

Feeder No / Name : 201 / SHENDURJANA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.0305	.3239	.3048	.2667	.3239	.2858
2	.3239	.0305	.3239	.2858	.2667	.3239	.2858
3	.3239	.0286	.3239	.2858	.2667	.3239	.2858
4	.3239	.0286	.3239	.2858	.2858	.3239	.2858
5	.3429	.0286	.3429	.2858	.2858	.3239	.2667
6	.3429	.0248	.3429	.3048	.2667	.3239	.3239
7	.3239	.0248	.2286	.2667	.1905	.2667	.2667
8	.2858	.021	.2477	.2286	.1905	.2667	.2667
9	.2286	.0229	.2286	.2477	.1905	.2286	.1905
10	.0229	.021	.2096	.1905	.1524		.0229
11	.0229	.1905	.2096	.1905	.1905	.1715	.021
12	.0248		.1905	.1905	.1905	.1905	.0191
13	.0248	.1905	.1905	.2286	.1905	.1905	.0229
14	.021	.1905	.1905	.1905	.1905	.2096	.0229
15	.021	.2096	.1905	.2286	.1905	.1905	.0191
16	.0229	.2096	.2096	.2096	.1905	.2286	.0229
17	.0248	.2096	.2667	.1905	.2096	.2286	.0248
18	.0286	.2477	.2667	.2477	.2858	.2858	.0324
19	.0362	.362	.4001	.3429	.362	.4001	.0381
20	.0381	.362	.3429	.3429	.4001	.4191	.0419
21	.0381	.381	.3429	.362	.381	.3429	.0381
22	.0362	.3239	.3429	.3239	.362	.3429	.0362
23	.0324	.3239	.3239	.3239	.3239	.3239	.0343
24	.3239	.3239	.3239	.2858		.3239	.3048
Max	.3429	.381	.4001	.362	.4001	.4191	.3239
Min	.021	.021	.1905	.1905	.1524	.1715	.0191
Avg	.1474	.1646	.2786	.2643	.2535	.2849	.1316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

MANORA DN.[552]

BU 1554

Substation No/ Name :- 344031 / 33 KV SHENDURJANA

Feeder No / Name : 202 / 11 KV PALODI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0553	.1143	.1143			
3	.0114	.1334	.1524			
4	.0152	.1524	.1524			
5	.0191	.1905	.1524			
6	.0171	.2477	.2477			
7	.0171	.2477	.1334			
8	.0286	.2286	.1715			
9	.021	.1905	.2096			
10			.1715	.2858		.0305
11			.1715	.1905	.2286	.0286
12			.1143	.1905	.0762	.0248
13			.0762	.1524	.1715	.0286
14			.0762	.1524	.1334	.0267
15			.0762	.1334	.1334	.0133
16			.0762	.1334	.1334	.0152
17			.0762	.1334	.0381	.0191
Max	.0553	.2477	.2477	.2858	.2286	.0305
Min	.0114	.1143	.0762	.1334	.0381	.0133
Avg	.0231	.1881	.1358	.1715	.1307	.0234

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344005 / 33 KV MOP

Feeder No / Name : 201 / 11 KV LONI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.439		.4706	.4344	.4755	.4755
2	.4755	.439		.439	.4163	.4755	.4755
3	.5121	.4435		.439	.4207	.4755	.5121
4	.6348	.4805		.4805	.439	.5121	.6283
5	.7468	.5415		.5415	.5544	.7316	.7023
6	.9149	1.0082		1.0082	.9335	.9134	.9149
7	.9896	.8501		.8501	.8501	.8596	.8686
8	.8871	.7577	.7468	.7682	.7316	.8063	.7762
9	.7762	.6468		.7316	.6767	.6836	.7133
10	.6401	.4706		.5792	.5487	.4887	.5121
11	.4298	.394	.5959	.4477	.4298	.4572	.439
12	.4075	.3582	.5258	.3898	.4024	.3801	.3582
13		.3582	.4908	.362	.4024	.3366	.3582
14	.4458	.3403	.4557	.3898	.4207	.3898	.3544
15	.4334	.3429	.4557	.4252	.439	.4252	.3544
16	.443	.3856	.4557	.4075	.439	.4557	.3814
17	.4784	.4207	.5258	.5373	.4755	.5083	.4557
18	.695	.5014	.7164	.5731	.695	.6805	.5316
19	.7865	.567	.7682	.7392	.7316	.8316	.7023
20	.7023	.7023	.7023	.7207	.7164	.7207	.6516
21	.5487	.5304	.6722	.5359	.5373	.5544	.5853
22	.5121	.5121	.5544	.4938	.5121	.5121	.5121
23	.4755	.4572	.5121	.4755	.5121	.4755	.4755
24	.439	.4525		.5121	.4525	.4755	.4755
Max	.9896	1.0082	.7682	1.0082	.9335	.9134	.9149
Min	.4075	.3403	.4557	.362	.4024	.3366	.3544
Avg	.6006	.5167	.5841	.5549	.5488	.5677	.5506



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344005 / 33 KV MOP

Feeder No / Name : 202 / 11 KV BORKHEDI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1595	.1543	.1433	.1578	.1646	.1543
2	.1029	.1612	.1543	.1433	.1417	.1646	.1543
3	.1372	.1629	.1715	.1448	.1417	.1646	.1543
4	.2103	.1663	.2454	.2218	.1595	.2149	.2629
5	.2454	.2033	.3506	.4066	.2328	.3224	.3856
6	.3155	.439	.7712	.4805	.4656	.4908	.6024
7	.3856	.4477	.4557	.394	.3292	.4207	.4207
8	.3155	.4706	.5258	.4656	.3982	.3856	.4458
9	.2804	.3898	.3856	.4298	.3366	.3506	
10	.2035	.2915	.2229	.2401	.1791	.2279	
11	.1658	.2683	.1372	.1677	.1753	.1715	.2454
12	.1492	.2012	.1753	.1658	.1791	.1715	.1772
13	.1823	.1844	.1753	.1844	.1791	.1715	.1772
14	.1658	.1677	.1753	.1658	.1829	.1677	.1753
15	.1658	.1509	.1715	.1658	.1829	.1677	.1772
16	.1823	.1696	.2103	.1341	.1829	.2058	.1417
17	.2743	.2058	.2865	.1715	.1829	.2572	.1753
18	.333	.2103	.3506	.2629	.2926	.3155	.2481
19	.362	.2279	.3856	.2303	.2926	.4557	.3506
20	.362	.298	.3155	.2896	.2865	.3681	.3544
21	.2328	.1907	.2804	.1928	.2149	.2229	.2507
22	.197	.1715	.2454	.1772	.1791	.1715	.1791
23	.1772	.1543	.12	.1595	.1791	.1543	.1372
24	.1029	.1753	.1543	.1791	.1578	.1646	.1543
Max	.3856	.4706	.7712	.4805	.4656	.4908	.6024
Min	.1029	.1509	.12	.1341	.1417	.1543	.1372
Avg	.2230	.2362	.2759	.2382	.2254	.2530	.2511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344005 / 33 KV MOP

Feeder No / Name : 203 / 11 KV RISOD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3189	.3429	.3155		.439	.4115
2	.4207	.3224	.3772	.3189		.439	.4115
3	.4656	.3258	.4115	.3224		.4298	.4458
4	.5487	.3696	.5144	.362		.4656	.5144
5	.5853	.4805	.583	.6653		.631	.6379
6	.7023	.6516	.6516	.5914		.7362	.7783
7	.5853	.5731	.6556	.6516		.5959	.7265
8	.5731	.4119	.6379	.6447		.5959	.6516
9	.5375		.567	.6089		.5258	.5765
10	.39		.3801	.4239		.4334	.503
11	.3277		.3688	.3185		.3429	.4024
12	.3277		.3563	.3113	.1402	.3086	.3201
13	.3441		.3688	.2984	.1402	.3086	.3201
14	.3441		.3429	.3277	.2507		
15	.3277	.3239	.3429	.2984			
16	.3277	.3688	.3086	.3185			
17	.39	.4024	.4557	.407	.439		
18	.4207	.4801	.4557	.4382	.5121		.4458
19	.4344	.5201	.5014	.567	.439		.5201
20	.4706	.5014	.5014	.5014	.4656	.6201	.4557
21	.4075	.4557	.4656		.4656	.5201	.4207
22	.394	.4115	.3856		.439	.4458	.4161
23	.3544	.3429	.3856		.439	.4115	.4161
24	.3772	.333	.3429	.3429		.439	.4115
Max	.7023	.6516	.6556	.6653	.5121	.7362	.7783
Min	.3277	.3189	.3086	.2984	.1402	.3086	.3201
Avg	.4347	.4219	.4460	.4302	.3730	.4827	.4893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 201 / 11 KV AASEGAON AGP FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.5647	.743	.8471			
4		.5944	.695	.8655			
6	.5053	.8145	.888	1.0551			
7	.743						
8	.7819	1.0997	.8768	1.1439			
9	.8509	.9991					
10				1.0848	.8109	1.2308	1.2597
11				.9633	.7964		1.1888
12				.86	.7529	1.267	1.1145
13				.8398			.9991
14				.8471	.6773	1.0848	.9511
15				.9031			
16					.8509	1.0136	
17							.9065
18						1.07	
Max	.8509	1.0997	.888	1.1439	.8509	1.267	1.2597
Min	.5053	.5647	.695	.8398	.6773	1.0136	.9065
Avg	.7203	.8145	.8007	.9410	.7777	1.1332	1.0700

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 202 / 11 KV SAWARGAON AGP

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2538	.1334	.1372			
4		.2538	.141	.1738			
6	.3292	.282	.141	.1715			
7	.3868						
8	.4652	.5639	.3429	.4058			
9	.447	.4058					
10				.2115	.3467	.2629	.3144
11				.2	.4033		.4458
12				.2591	.4371	.3109	.2858
13				.0754			.285
14				.0894	.2743	.2263	.1467
15				.0812			
16					.2366	.2538	
17							.2667
Max	.4652	.5639	.3429	.4058	.4371	.3109	.4458
Min	.3292	.2538	.1334	.0754	.2366	.2263	.1467
Avg	.4071	.3519	.1896	.1805	.3396	.2635	.2907

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 203 / 11 KV SIRSALA AGP FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0274	.0305	.0343			
4		.0244	.029	.0381			
6	.0263	.0488	.04	.0457			
7	.0476						
8	.0476	.0732	.0823	.0617			
9	.1029	.0587					
10				.0613	.056	.0438	.0732
11				.064	.0652		.1269
12				.0613	.0732	.0823	.0827
13				.0533	.0732		
14				.064	.0495	.064	.1463
15				.0503			
16					.0457	.6895	
17							.1063
18						.7827	
20						1.0433	
Max	.1029	.0732	.0823	.064	.0732	1.0433	.1463
Min	.0263	.0244	.029	.0343	.0457	.0438	.0732
Avg	.0561	.0465	.0455	.0534	.0605	.4509	.1071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 205 / SAWARGAON&amp; SIRSALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.8322	.7628	.7727	.7002		.7335
4		.8802	.7145	.8025	.7385	.9389	.8535
5						.9267	
6	1.4377	1.3937	1.379	1.2742	1.3094	1.2616	1.2289
7	1.2176					1.0551	
8	1.0402	1.028	1.028	.9633	.9783	.9095	.9511
9	.8916	.8215					
10	.7579			.6805	.6706		.6516
11		.5792	.6895	.6923	.6241		.5268
12	.6687	.4458	.6687	.639	.6161	.6093	.4694
13		.5068	.6836	.6371			.1054
14	.6836	.5944	.7095	.5868	.6687	.6371	.6539
15			.7133	.6001			
16	.6687		.6573		.7042		
17			.7002				.6687
18	.8128	.8278					
19			.945		.8768		
20	1.1584		.9783		1.1003		
21					.9065		
22	.9682				.8949	.945	
23	.945				.8579	.8322	.8802
24	.8916	.8619	.8916	.8322	.6836		.7775
Max	1.4377	1.3937	1.379	1.2742	1.3094	1.2616	1.2289
Min	.6687	.4458	.6573	.5868	.6161	.6093	.1054
Avg	.934	.7974	.8230	.7710	.8220	.9017	.7084

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344006 / 33 KV RITHAD

Feeder No / Name : 206 / 11 kv BORALA EXPRESS

FEEDER Feeder KV- 11 /  
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.2936	1.267	1.2178	1.262		1.1871
4		1.267	1.2489	1.2803	1.1946	1.4118	1.3394
5						1.6834	
6	2.1807	2.268	2.1849	2.2546	2.1582	2.1498	2.2731
7	2.0119					1.9547	
8	1.7556	1.8107	1.7918	1.7737	1.8656	1.8099	1.8267
9	1.7193	1.6095					
10	1.6278			1.3575	1.4415		1.4299
11		1.0608	1.2489	1.1694	1.1999		1.2308
12	.7888	1.0608	1.134	1.1462	1.2127	1.267	1.1157
13		1.1222	1.1273	1.134			1.0059
14	.724	.985	1.1222	1.1104	1.086	1.2254	1.1157
15			1.0534	1.1163			
16	1.0242		1.2127		1.086	1.1946	
17			1.2696				1.1765
18	1.4969	1.0679				1.3213	
19			1.5364		1.5061		
20	1.7924		1.6834		1.7551	1.7187	
21					1.4685		
22	1.3756					1.4327	
23	1.3676				1.3535	1.3352	1.3169
24	1.3352	1.2986	1.3352	1.3717	1.2536		1.2489
Max	2.1807	2.268	2.1849	2.2546	2.1582	2.1498	2.2731
Min	.724	.985	1.0534	1.1104	1.086	1.1946	1.0059
Avg	1.4769	1.3495	1.3726	1.3574	1.4174	1.5420	1.3556

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 202 / 11 KV KARD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.394	.3258	.3506	.3292	.362	.362
2	.362	.394	.3258	.3544	.3292	.3982	.362
3	.3982	.394	.3439	.3801	.3292	.4344	.3475
4	.439	.5068	.3841	.3982	.3696	.4706	.3696
5	.5121	.5487	.4805	.4938	.5914	.5487	.462
6	.695	.6036	.6348	.6348	.7947	.7964	.7842
7		.6219	.5544	.5914	.6219	.7023	.8686
8		.6516	.5121	.6401	.8048	.6219	.7316
9	.5973	.543	.4755	.4938	.567	.5853	.6036
10	.5373	.724	.4163	.4706	.4706	.543	.4344
11	.3582	.3641	.3366	.3544	.3681	.4207	.4656
12		.3561	.333	.3856		.3856	
13		.3258	.333	.3467		.3467	.394
14		.3681	.298	.3467		.3429	.3544
15		.3475	.2804	.3467	.394	.3898	.3189
16		.3121	.3052	.3898	.4207	.3544	.3898
17		.3224	.4075		.4607	.4706	.3856
18		.4119	.5014		.5014	.5973	.4207
19		.5175			.5487	.7392	.4656
20		.499	.567		.543	.6283	.5175
21		.4435	.5121		.5487	.5487	.4706
22		.3982	.4706		.4755	.439	.4344
23		.3801	.3982		.439	.3982	.3982
24	.362	.4298	.362	.3801	.3292	.3982	.3801
Max	.695	.724	.6348	.6401	.8048	.7964	.8686
Min	.3582	.3121	.2804	.3467	.3292	.3429	.3189
Avg	.4659	.4524	.4156	.4328	.4875	.4968	.4661



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 203 / 11 KV WAKAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774	.208	.208	.2103	.2149	.2195	.1772
2	.2454	.2103	.2103	.2103	.2149	.2561	.1772
3	.2774	.2103	.2103	.2103	.2534	.2195	.1772
4	.3224	.2454	.2481	.2126	.2926	.2561	.2126
5	.3582	.3429	.3224	.2865	.4024	.3292	.2896
6	.5068	.4908	.5792	.5487	.5487	.5121	.5544
7	.5373	.4656	.4298	.4706	.5068	.4706	.4024
8	.5373	.4784	.4298	.3982	.4252	.439	.4557
9	.4207	.3155	.4207	.3544	.2804	.3856	.4161
10	.3086	.3155	.2622	.2915	.2743	.3086	.3315
11	.2401	.2267	.2267	.2321	.2347	.2347	.2591
12		.1966	.2267	.2229	.1696	.2683	
13		.1966	.2294	.2401	.1677	.2347	.2458
14		.2012	.2241		.1341	.2652	.2321
15		.2035	.2347		.2012	.2374	.2401
16		.2035	.1875		.2012	.2058	.2743
17		.2012	.2804		.2683	.2743	.2743
18		.3086	.3544		.3086	.3121	.3086
19		.3506			.3856	.4607	.3121
20		.3506	.3258		.3544	.3582	.3506
21		.2804	.2835		.2507	.3189	.3155
22		.2774	.2454		.2454	.2835	.2835
23		.2427	.2454		.2427	.2126	.2481
24	.2454	.2427	.2427	.2454	.2195	.2195	.2126
Max	.5373	.4908	.5792	.5487	.5487	.5121	.5544
Min	.2401	.1966	.1875	.2103	.1341	.2058	.1772
Avg	.3564	.2819	.2882	.2953	.2832	.3034	.2935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 204 / 11 KV RISOD TOWN 1 FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5524	1.5729	1.5524	1.5708	1.4998	1.5524	1.5893
2	1.5893	1.5893	1.5154	1.4784	1.4998	1.5893	1.5708
3	1.5524	1.6095	1.5154	1.4784	1.5546	1.5524	1.4969
4	1.5893	1.6263	1.5339	1.4003	1.6263	1.5893	1.5154
5	1.643	1.6263	1.6057	1.4563	1.643	1.6263	1.5497
6	1.643	1.6263	1.7364	1.6244	1.643	1.6804	1.6617
7	1.531	1.4842	1.6263	1.6263	1.6078	1.6263	1.5893
8	1.531	1.4969	1.5154	1.4784	1.5154	1.4784	1.4969
9	1.423	1.3676	1.4632	1.3676	1.4266	1.4266	1.267
10	1.4449	1.4266	1.5023	1.4266	1.3535	1.39	1.267
11	1.3535	1.4266	1.3032	1.448	1.3717	1.4118	1.3394
12		1.3032	1.262		1.3575	1.448	
13		1.3032	1.4842	1.448	1.4266	1.4842	1.3535
14		1.4632	1.4449		1.4449	1.4998	1.267
15		1.448	1.4118		1.4632	1.5203	1.267
16		1.4661	1.5203		1.4632	1.4998	1.448
17		1.5364	1.5203		1.4842	1.7375	1.3394
18		1.6095	1.5203		1.448	1.6651	1.3394
19		1.7187			1.6095	1.7558	1.4632
20		1.7187	1.7556		1.5089	1.7741	1.6632
21		1.6632	1.7002		1.6263	1.7375	1.6095
22		1.6448	1.6632		1.6632	1.701	1.6461
23		1.6263	1.6448		1.6263	1.7187	1.6632
24	1.5893	1.5893	1.5893	1.6078	1.5203	1.5893	1.6632
Max	1.643	1.7187	1.7556	1.6263	1.6632	1.7741	1.6632
Min	1.3535	1.3032	1.262	1.3676	1.3535	1.39	1.267
Avg	1.5368	1.5393	1.5385	1.4932	1.5160	1.5856	1.4811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277] BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 205 / 11 KV RISOD TOWN 2 FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17
HR	Load (MW)
9	1.448
Max	1.448
Min	1.448
Avg	1.448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 206 / WATWR WOKR EXPRESS FEEDER NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1578	.1372	.1227	.1402	.1214	.1578
2	.1372	.1595	.1372	.1227	.1772	.12	.1578
3	.1715	.1772	.1372	.1227	.1417	.1578	.1578
4	.1734	.1433	.1402	.124	.1595	.1734	.1578
5	.1753	.1463	.1629	.1417	.1417	.12	.1612
6	.1578	.124	.1629	.1417	.1402	.0857	.1646
7	.1214	.1227	.1402	.12	.1791	.1478	.1791
8	.12	.1595	.12	.1029	.1753	.1715	.1543
9	.1227	.0316	.0732	.1372	.1029	.1677	.1715
10	.12	.0324	.1029	.1402	.0857	.12	.1372
11	.1372	.0328	.1734	.1578	.1372	.1227	.1387
12		.0328	.1029	.1227	.0514	.104	
13		.0328	.156	.0526	.0343	.104	.0686
14		.0328	.0857		.0343	.0914	.0343
15		.0332	.0343		.0857	.1715	.1715
16		.0332	.104		.0514	.0686	.1907
17		.0171	.112		.081	.1543	.1715
18		.0171	.0373		.0509	.1372	.1387
19		.0175			.0503	.1372	.0514
20		.0351	.0171		.0339	.0171	.0678
21		.0175	.0343		.0514	.0857	.0514
22		.0876	.0343		.1174	.1029	.0686
23		.1029	.1753		.1543	.0857	.0686
24	.104	.1417	.1029	.1402	.1227	.1734	.1052
Max	.1753	.1772	.1753	.1578	.1791	.1734	.1907
Min	.0857	.0171	.0171	.0526	.0339	.0171	.0343
Avg	.1355	.0787	.1080	.1249	.1042	.1225	.1272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344007 / 33 KV RISOD

Feeder No / Name : 207 / GHONSOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.1086	.1097	.0876	.1086		.1052
2	.0732	.1075	.1097	.0876	.1075		.1052
3	.0914	.124	.1097	.0886	.1254		.1052
4	.1075	.1402	.128	.1063	.1417		.1227
5	.1433	.1772	.1463	.1448	.1753		.1433
6	.1848	.2279	.2378	.2195	.2103		.2012
7	.2279	.2103	.2454	.2427	.2328		.2865
8	.2279	.2743	.2254	.2204	.2652		.2401
9	.2229	.1677	.16	.1715	.2204		
10	.1562	.1696	.156	.1578	.1696		.1619
11	.0914	.1475	.1227	.1715	.1475		.1619
12		.1341		.1214	.1658	.1341	
13		.1387	.116	.1341	.1341	.1357	.1966
14		.104	.1017		.116	.1187	.0328
15		.1006	.1109		.1341	.1326	.128
16		.1017	.1294		.12	.1187	.125
17		.1341	.1227		.1715	.1357	.1311
18		.1341	.1357		.2012	.1543	.1235
19		.1402			.2303	.156	.1715
20		.1433	.1267		.2641	.156	.1772
21		.1267	.1227		.2481	.1357	.1402
22		.1097	.1052		.1086	.1296	.1417
23		.1097	.0876		.1086	.12	.1097
24	.0914	.1086	.1097	.0876	.1086		.104
Max	.2279	.2743	.2454	.2427	.2652	.156	.2865
Min	.0732	.1006	.0876	.0876	.1075	.1187	.0328
Avg	.1409	.1433	.1372	.1458	.1673	.1356	.1461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277] BU 1520

Substation No/ Name :- 344008 / 33 KV MANGULZANAK

Feeder No / Name : 202 / 11 kv mangulzanak

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	19-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.1429	.1429		.1867
8	.141	.2		.2
9	.1692	.2286		.1814
10	.2115	.1669		.2591
11	.2961	.1391	.1858	.2229
12	.2667	.1867	.1981	
13	.1867		.1858	
14	.1532		.2105	
15	.161		.1362	
16	.1486		.1734	
17	.1238		.1734	
18	.1858		.1858	
19	.2		.1486	
20	.1429		.1238	
21	.1		.1115	
22			.0867	
Max	.2961	.2286	.2105	.2591
Min	.1	.1391	.0867	.1814
Avg	.1753	.1774	.1600	.2100

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344008 / 33 KV MANGULZANAK

Feeder No / Name : 203 / MANGUL ZANAK GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	19-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2567	1.2254		1.423
2	1.2197	1.2437		1.4415
3	1.2012	1.2567		1.4299
4	1.5927	1.4632		1.4045
5	1.6289	1.7558		1.5154
6	2.2624	2.4177		2.2546
10	1.4352	1.4506		1.423
11	1.3432	1.3432	1.2012	1.3253
12		1.182	1.1643	
13			1.1403	
14	1.3253		1.0608	
15	1.2536		1.0349	
16	1.2178		1.0387	
17	1.2048		1.1041	
18	1.3575		1.1458	
19	1.5912		1.5927	
20	1.7375		2.1033	
21	1.5565		1.7372	
22			1.4842	
23	1.2567		1.4045	
24	1.2382	1.2936		1.4118
Max	2.2624	2.4177	2.1033	2.2546
Min	1.2012	1.182	1.0349	1.3253
Avg	1.4266	1.4632	1.324	1.5143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344009 / 33 KV MASALA PEN

Feeder No / Name : 201 / 11 KV Karkhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0191	.0191	.0191
2					.0191	.0191	.0191
3					.0191	.0191	
4					.0191	.0191	.0191
5					.0191	.0191	.0191
6					.0191	.0191	.0191
7					.0191	.0191	
8				.0191	.0191	.0191	
9				.0191		.0191	
10			.0191	.0191	.0191		.0191
11	.0191			.0191	.0191		.0191
12			.0191		.0191		.0191
13		.0191		.0191	.0191	.0191	.0191
14			.0191		.0191		.0191
15		.0191					.0191
16			.0191		.0191		.0191
17			.0191	.0191	.0191		.0191
18			.0191	.0191	.0191		.0191
19				.0191	.0191		.0191
20			.0191	.0191	.0191	.0191	.0191
21			.0191	.0191	.0191	.0191	.0191
22			.0191	.0191	.0191		.0191
23			.6859	.0191	.0191		.0191
24					.0191	.0191	.0191
Max	.0191	.0191	.6859	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0858	.0191	.0191	.0191	.0191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344009 / 33 KV MASALA PEN

Feeder No / Name : 202 / chinchambapen ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.1905			
3	.3048	.3048	.5715			
4	.3048	.381	.5715			
5	.3048	.3048	.6096			
6	.3048	.3048	.6096			
7	.4572	.4572	.6858			
8	.5335	.5335	.9145			
9	.6859	.6097	.9907			
10	.6097	.5335	.9907	.2058		.4287
11			.6668	.6211	.381	1.0974
12			.381	1.448	.5335	.9945
13			.6858	.7736	.9907	.8155
14			.2286	.6973	.6097	.663
15			.2286	.4572	.4572	.663
16			.1524	.5182	.4572	.5868
17			.4382	.5868	.5335	.663
18			.3048	.381	.5335	.4572
Max	.6859	.6097	.9907	1.448	.9907	1.0974
Min	.3048	.3048	.1524	.2058	.381	.4287
Avg	.4382	.4287	.5424	.6321	.5620	.7077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344009 / 33 KV MASALA PEN

Feeder No / Name : 203 / MASALA PEN GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	.2401	.2058	.2286
2			.1372	.2401	.2058	.2286
3			.1715	.2401	.2058	.3429
4			.2401	.2401	.2058	.381
5			.2743	.2743	.3086	.4572
6			.5144	.4458	.4801	.4572
7			.4458	.4801	.4458	
8			.4572	.3944	.4115	
9			.381		.3772	
10			.3048	.3239		.2572
11			.2401	.2401		.1886
12				.2401		.1715
13			.2286	.2401		.1715
14		.1372		.2058		.1715
15	.2058					.1715
16		.2058		.2058		.1886
17		.2401	.2667	.2229		.2058
18		.2743	.2743	.2572		.2229
19			.3772	.3944		.3429
20		.3429	.3429	.4115	.381	.3772
21		.2401	.3086	.2401	.2667	.3086
22			.2401	.2401		.2058
23			.2401	.2058		.2058
24			.1715	.2401	.2058	.2286
Max	.2058	.3429	.5144	.4801	.4801	.4572
Min	.2058	.1372	.1372	.2058	.2058	.1715
Avg	.2058	.2401	.2894	.2829	.3083	.2625

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344009 / 33 KV MASALA PEN

Feeder No / Name : 204 / 11 kv Mangulzanak

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6859	1.3337	1.3337	1.2956	1.3718
2	.6097	.6859	.6859	1.6766	1.2689	1.2956	1.3718
3	.6097	.8383	.7621	1.7147	1.2575	1.2956	1.3718
4	.6859	.8383	.7621	1.7147	1.2689	1.6004	1.6385
5	.7621	.9145	.8383	1.829	1.5089	1.6004	1.7909
6	.9907	2.4386	1.0669	2.2862	1.8747	2.21	2.1338
7	1.1431	1.448	1.2193	2.591	2.0576	2.1338	1.0669
8	1.0669	1.3717	1.1431	2.4386	1.829	2.0195	.9907
9	.9145	1.2955	1.1431	2.2862	.9145	1.829	.9907
10	.8383	.7621	.9145	1.9814	1.9814	.9145	1.9052
11		.6859	.6097	1.829	1.8671	.3048	1.9052
12		.6859	.5335	.8383	1.6766	.6477	1.7909
13		.6097	.4572	.9907	.8383	.3048	1.7147
14	.0762	.6097	1.1432	.5335	1.6004	.3048	1.6385
15	.6097	1.2194	.5335	.5335	.8383	.3048	1.5242
16	.6097	.6097	.8002	.381	1.6766	.9907	1.3337
17	.6859	.6859	1.067	1.9052	1.6766	1.0669	1.6385
18	.6859	.6097	1.3718	1.7528	1.4861	1.0669	1.4861
19	.6859	.6097	.6859	1.7528	1.5242	.9145	1.5623
20	.9145	.9907	1.9052	1.9814	1.829	2.21	1.7718
21	.9907	.9907	1.829	1.829	1.6766	1.9052	1.6766
22	.7621	.8383	.8383	1.4556	1.4861	.8383	1.6004
23	.7621	.8383	1.448	1.448	1.448	.7621	1.448
24	.6859	.7621	.6859	1.3337	1.3337	1.3718	1.3718
Max	1.1431	2.4386	1.9052	2.591	2.0576	2.21	2.1338
Min	.0762	.6097	.4572	.381	.8383	.3048	.9907
Avg	.7512	.9177	.9637	1.6007	1.5105	1.2162	1.5456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344033 / 33 kv CHIKHALI SUB STATION

Feeder No / Name : 201 / 11KV Chikhali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2947	.3045	.2804	.3224	.3189	.3086	.3086
2	.2743	.3077	.2658	.3045	.3045	.3086	.3185
3	.2804	.2926	.2865	.2896	.2865	.3086	.3582
4	.3224	.3292	.362	.3292	.3258	.3391	.3856
5	.3982	.3658	.439	.3658	.4024	.4024	.4075
6	.5121	.5121	.3982	.4938	.4706	.4641	.4252
7	.4706	.4607	.3841	.439	.4298	.4144	.443
8	.3544	.4287	.3155	.4031	.4252	.3856	.443
9	.3641	.3467	.3052	.3641	.3506	.3601	.3856
10	.3429		.2515	.2915	.3688	.3121	.3721
11	.3429	.3149	.2258	.2713	.3086	.2629	.3294
12	.3467	.3277	.2591	.3018	.3429	.2818	.3429
13	.3086	.2818	.218	.2785	.3121	.2347	.3294
14	.2883	.3018	.213	.3077	.3121	.2818	.3155
15	.3149	.2515	.2883	.2818	.298	.3052	.3429
16	.2683	.2713	.2881	.3185	.2804	.3582	.3429
17	.2949	.3086	.2683	.3277	.2804	.3258	.3561
18	.3239	.3944	.3258	.3978	.3121	.3582	.3561
19	.3258	.3641	.3641	.4409	.3601	.4075	.3856
20	.3982	.3898	.4207	.3944	.3772	.4477	.39
21	.3601	.3681	.3841	.3814	.4024	.4075	.3601
22	.3258	.3544	.3403	.4031	.3944	.3856	.3294
23	.3224	.333	.3224	.3544	.3391	.3856	.3121
24	.3222	.3045	.2947	.3224	.3403	.3222	.3582
Max	.5121	.5121	.439	.4938	.4706	.4641	.443
Min	.2683	.2515	.213	.2713	.2804	.2347	.3086
Avg	.3399	.3441	.3125	.3494	.3476	.3487	.3624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344033 / 33 kv CHIKHALI SUB STATION

Feeder No / Name : 203 / 11 KV Kawatha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2686	.2947	.3077	.3012	.2774	.3086
2	.2774	.2715	.2835	.2896	.2865	.2804	.2818
3	.3012	.2715	.2865	.2896	.3045	.2804	.3185
4	.3439	.2896	.3439	.2926	.3475	.3121	.3582
5	.4755	.3801	.4435	.3475	.4163	.3429	.3856
6	.5359	.5068	.5121		.4755	.4024	.4477
7	.5121	.3258	.4435	.4207	.443	.3561	.3721
8	.4477	.3582	.3721	.3681	.3856	.2947	.3856
9	.4031	.3045	.2774	.3258	.3721	.2774	.2818
10	.2601	.208	.2374	.2481	.3052	.2279	.2622
11	.2915	.2515	.1526	.2774	.2279	.2126	.2458
12	.3052	.2204	.2515	.2515	.2279		.2622
13	.3222	.213	.2543	.2294	.2454	.2347	.2347
14	.3185	.2515	.2374	.2652	.2601	.2347	.2229
15	.2785	.2374	.2401	.2347	.2774		.2401
16	.3018	.2743	.2515	.2374	.2915	.2622	.2601
17	.3391	.3988	.3052	.2543	.3086	.2126	.2743
18	.373		.3391	.3086		.2818	.2915
19	.407	.3898	.3772	.4161	.1791	.4075	.3185
20	.4207	.4119	.3898	.3898	.3772	.4477	.3222
21	.3814	.3801	.3801	.3801	.3467	.3601	.3222
22	.3721	.3582	.362	.3403	.3086	.3258	.3086
23	.2865	.3366	.3439	.3258	.2947	.3086	.2743
24	.3086	.2686	.3155	.3258	.3224	.2947	.3185
Max	.5359	.5068	.5121	.4207	.4755	.4477	.4477
Min	.2601	.208	.1526	.2294	.1791	.2126	.2229
Avg	.3564	.3120	.3206	.3098	.3176	.3016	.3041

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344036 / 33 KV KENWAD

Feeder No / Name : 201 / 11 KV KENWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8467	.8002	.7948	.7644	.8063	1.6073	.8055
2	.8322	.7888	1.5486	.7446	1.5432	1.5775	1.5577
3	.8337	.7903	.788	.7346	.7446	1.589	.8048
4	.8764	.8147	1.608	.7545	1.515	1.6149	1.6423
5	1.0212	.9328	.9328	.8733	.8695	1.8282	1.8717
6	1.0814	1.0852	2.0965	1.9585	2.1194	2.2176	2.1392
7	.9869	.9092	1.9814	1.7254	2.0256	2.0934	1.8015
8	1.7124	.8528	1.7809	1.7581	.9884	1.8221	1.7414
9	1.7428	1.5493	1.5851	1.6972	.9861	1.6995	1.5516
10	1.5988	.7125	1.4784	1.6453	1.6202	1.531	1.4807
11	.7796	1.5219	1.2323	1.4342	.7857	1.3755	.7362
12	.7278	1.2788	1.2277	1.393	1.4304	1.3862	1.3793
13	.8695	1.3443	.6699	1.4472	1.528	1.3831	1.2986
14	.8299	1.4556	1.3055	1.4533	1.5318	1.4525	1.4281
15	1.3687	.6904	1.217	1.499	1.5074	1.4563	1.3581
16	1.4312	1.2948	1.2742	1.4197	1.3656	1.4159	1.3801
17	.7293	.6607	1.2994	1.5089	1.4533	1.3802	1.3101
18	.8223	1.3946	1.0905	1.6461	1.5356	1.5135	1.3519
19	.932	1.6941	1.1485	1.9212	1.8496	1.8038	1.6789
20	1.1325	1.9029	2.031	1.0799	2.0706	1.0562	.977
21	1.9913	1.8023	1.9845	.2583	2.0675	1.8146	1.8595
22	1.0044	1.8389	.9678		.9884	.9343	.9214
23	.9099	1.7178	1.1393	1.5829	.9366	1.6659	.823
24	.8558	.8261	1.5501	1.5897	1.6217	1.5958	1.563
Max	1.9913	1.9029	2.0965	1.9585	2.1194	2.2176	2.1392
Min	.7278	.6607	.6699	.2583	.7446	.9343	.7362
Avg	1.0799	1.1941	1.3638	1.3430	1.4121	1.5756	1.3942

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344036 / 33 KV KENWAD

Feeder No / Name : 202 / 11 KV SAKHRAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4412	.4595	.4321	.4473	.4816	.8962	.439
2	.4336	.4542	.8055	.4351	.9495	.8908	.8848
3	.4351	.4405	.4146	.4275	.4893	.8848	.4275
4	.4733	.4519	.8025	.4382	1.0455	.9145	.9
5	.5434	.5197	.4793	.4908	.6036	1.0006	.9724
6	.791	.7766	1.3679	1.3969	1.4731	1.1682	1.1743
7	.7689	.6737	1.3252	1.1439	1.1066	1.1789	1.2506
8	1.2665	.6249	1.3176	1.1043	.6249	1.2254	.8863
9	1.1835	1.0852	1.1447	1.0821	.5746	1.2147	.7186
10	1.1812	.5388	1.0242	.8886	.8992	.6744	.6119
11	.5396	.9572	1.0067	.7544	.5014	1.1934	.4275
12	.5365	.7872	.8665	.8162	.9754	.5601	.5815
13	.5205	.7652	.8215	.8924	.9213	.5472	.7331
14	.4969	.8093	.8193	.8825	.7827	.9442	.6745
15	.9023	.4443	.8719	.7705	.8056	.9351	.7369
16	.3071	.7652	.9358	.8086	.6981	.4466	.7743
17		.3841	.7834	.8345	.7948	.9861	.2926
18	.0724	.9297	1.0303	.9785	.3337	1.0707	1.0677
19	.5784	.7865	1.2498	1.0669	1.0433	1.1522	1.1553
20	.5898	.8528	1.0875	.6302	.5387	.66	.6424
21	1.1278	.9823	.8604	.6158	.6447	1.102	.9557
22	.5761	.9138	.5098	.554	.3856	.5944	.551
23	.5274	.8642	.9313	1.1431	.4832	.9686	.5114
24	.4717	.4504	.8581	.9221	.9229	.9152	.9389
Max	1.2665	1.0852	1.3679	1.3969	1.4731	1.2254	1.2506
Min	.0724	.3841	.4146	.4275	.3337	.4466	.2926
Avg	.6419	.6966	.9061	.8135	.7533	.9218	.7628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344036 / 33 KV KENWAD

Feeder No / Name : 203 / 11 KV JAIYKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3147	.4001	.3452	.3445	.3201	.6523	.3871
2	.3117	.3963	.5903	.3376	.5555	.6417	.6634
3	.3056	.3887	.3132	.3262	.301	.6371	.3826
4	.3064	.3917	.5956	.3193	.5525	.6363	.6466
5	.3079	.3833	.3155	.3155	.3208	.716	.6451
6	.3788	.4801	.6904	.735	.7758	.8272	.8898
7	.4893	.5937	.8836	.9278	.9957	1.0463	1.0791
8	1.1423	.6501	.9991	.8391	.5868	1.1964	1.2228
9	1.0075	1.2582	1.1233	.9514	.5898	.7152	1.1245
10	.9396	.6798	1.1408	.9671	.5967	.4435	1.0341
11	1.0623	1.0589	1.1001	.9518	.6234	.5598	.5601
12	1.0913	1.0951	1.1092	.9892	1.0056	.8669	1.2159
13	.5929	1.028	.9755	.9613	1.0803	.5792	1.1469
14	.9945	.924	.9385	.7994	1.0589	.5304	.9949
15	.9583	.365	.8764	.8798	1.0231	.5449	.876
16	1.0829	.7171	.5251	.8909	.9438	.8981	.863
17	.6234	.4161	.9156	.9034	1.049	1.0178	.82
18	.7446	.8866	1.065	.9938	1.0818	1.1329	.927
19	.727	.9602	1.014	.8996	1.054	1.1831	.8516
20	.6318	.8741	.8245	.458	.956	.6158	.4275
21	.8394	.762	.7224	.3635	.8505	.996	.4039
22	.4397	.7049	.3986	.2888	.4786	.5319	.4024
23	.4351	.6428	.6596	.5411	.4542	.8429	.3856
24	.4298	.3506	.6306	.5632	.6897	.6985	.6424
Max	1.1423	1.2582	1.1408	.9938	1.0818	1.1964	1.2228
Min	.3056	.3506	.3132	.2888	.301	.4435	.3826
Avg	.6732	.6836	.7813	.6895	.7477	.7713	.7747



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344037 / 33 KV WAKAD SUB STATION

Feeder No / Name : 201 / 11 KV WAKAD,WAKAD S/S

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5201	.5548	.5201	.5201	.4854
2		.4854	.5548	.5201	.5201	.4854
3		.4854	.5548	.5201	.5201	.4854
4		.5895	.6935	.6588	.5201	.4854
5		.8669	.7975	.7628	.5201	.4854
6		1.0402	.9015	.9362	.9709	.9015
7		.9709	.9015	.6241	.8669	.8322
8		.8322	.8322	.5895	.7282	.7628
9		.7975	.7282	.5201	.7628	.6762
10		.6588	.5548	.4854	.5548	.6588
11		.5895	.5201	.3467	.4681	.4854
12		.5201		.5548	.4508	
13		.4854	.4854	.4854		.4161
14		.5201	.4854	.4854	.4681	.4161
15		.5201	.5201	.5201	.4854	
16	.6241	.5201	.4854	.4854	.5201	.3814
17	.6241	.5548	.5548	.5201	.6241	.4508
18	.7628	.6588	.6588	.5895	.6588	.5201
19	.8322	.7628	.7628	.6935	.7459	.5548
20	.7975	.7628	.7282	.8322	.7127	.6588
21	.6935	.6935	.6241	.6588	.5967	.5895
22	.6241	.6241	.6241	.5895	.5895	.5895
23	.5548	.5895	.5895	.5548	.5548	.5201
24		.5201	.5548	.5548	.5201	.5201
Max	.8322	1.0402	.9015	.9362	.9709	.9015
Min	.5548	.4854	.4854	.3467	.4508	.3814
Avg	.6891	.6487	.6377	.5837	.6034	.5619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

RISOD S/DN.[277]

BU 1520

Substation No/ Name :- 344037 / 33 KV WAKAD SUB STATION

Feeder No / Name : 202 / 11 KV GOHGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3053	2.2824	1.1771	1.2182	1.0087	.9622	.9789
2	2.2778	2.2474	1.0971	1.1977	.9843	.9385	.9606
3	2.2527	2.258	1.0872	1.1893	.9591	.9446	.9705
4	2.2771	2.255	1.1218	1.2624	1.0768	.9477	.9545
5	2.9789	3.0041	1.2292	1.3275	1.1942	1.0407	1.0277
6	3.6381	3.5246	1.5798	1.4743	1.6369	1.5711	1.6122
7	3.3818	3.3876	1.6293	1.408	1.68	1.5314	1.6825
8	3.3437	3.3879	1.7852	1.3146	1.6263	1.3839	1.5695
9	2.7846	2.9811	1.7269	1.3493	1.5673	1.3542	1.5181
10	2.8631	1.1126	1.6461	1.3062	1.4194	1.2786	1.2445
11	2.4583		1.5208	1.1995	1.2262	1.1018	1.1169
12	1.3131		.0678	.6927	1.0722	.9942	.5853
13	2.395		.7453	1.2094	.9987	.9429	.9408
14	2.0385	2.6746	.74	1.1306	.9907	.9143	1.0097
15	1.9608	2.6585	.7529	1.0277	.9835	.9107	.5152
16	2.1731	1.2579	1.2529	.9884	.9873	1.0635	.9229
17	2.3964	1.3592	1.3745	1.0311	1.0463	1.1324	1.1645
18	2.8788	1.4773	1.5162	1.2312	.9998	1.2628	1.2925
19	3.1001	1.6141	1.5752	1.3092	1.2948	1.4923	1.4136
20	3.0689	1.5912	1.5421	1.3466	1.3352	1.5438	1.4784
21	2.5598	1.4453	1.371	1.1995	1.217	1.3382	1.2998
22	2.5359	1.3882	1.283	1.1439	1.0986	1.2216	1.0524
23	2.3891	1.3138	1.2419	1.1009	.5838	1.1169	1.028
24	2.3327	1.7528	1.2243	1.1504	1.0536	1.0334	1.0371
Max	3.6381	3.5246	1.7852	1.4743	1.68	1.5711	1.6825
Min	1.3131	1.1126	.0678	.6927	.5838	.9107	.5152
Avg	2.5710	2.1416	1.2620	1.2004	1.1684	1.1676	1.1407

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344001 / 33KV S/S WASHIM

Feeder No / Name : 201 / RAILWAY STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4533	1.4997	1.4487	1.4087	1.9781	1.4156	1.4006
2	1.4609	1.4586	1.4506	1.4198	1.9825	1.3819	1.4013
3	1.4354	1.4826	1.4537	1.3919	1.9983	1.3645	1.384
4	1.4083	1.3601	1.3993	1.3699	2.1077	1.3295	1.404
5	1.4037	1.4184	1.4089	1.4017	2.3009	1.3318	1.3849
6	1.5157	1.5855	1.4849	1.435	2.028	1.5333	1.472
7	1.5699	1.5855	1.5466	1.4224	2.0801	1.5253	1.4444
8	1.499	1.4434	1.3009	1.3535	2.0648	1.4929	1.395
9	1.2556	1.3161	1.1664	1.3032	1.2226	1.4072	1.2722
10	1.2826	1.2077	1.1382	1.1649	.1924	1.3912	1.22
11	1.2649	1.2348	1.0841	1.0074	1.2194	1.3588	1.1968
12	.1604	1.2319	1.1231	.1536	1.2125	1.312	1.1536
13	1.2068	1.1919	1.1277	1.1336	1.169	1.2673	1.2098
14	1.2151	1.1723	1.1788	1.1016	1.1892	1.2167	1.2136
15	1.2323	1.1782	.1951	1.094	1.209	1.3443	1.2449
16	1.1652	1.1517	1.1742	1.1483	1.1428	1.3323	1.1637
17	1.2422	1.1487	.8585	1.1131	1.1393	1.2182	1.1589
18	1.299	1.2605	1.0971	1.2925	1.2384	1.2658	1.1583
19	1.4314	1.2895	1.2528	.266	1.3908	1.4864	1.1809
20	1.5124	.1989	1.4175	1.4173	1.4413	1.5292	1.2068
21	1.515	1.4872	1.4123	1.4331	1.5059	1.4937	1.3764
22	1.5562	1.5413	1.3417	1.3421	1.5652	1.5349	1.3485
23	1.547	1.4994	1.3611	.9886	1.4798	1.5692	1.4465
24	1.4986	1.459	1.4438	1.456	1.905	1.4667	1.4049
Max	1.5699	1.5855	1.5466	1.456	2.3009	1.5692	1.472
Min	.1604	.1989	.1951	.1536	.1924	1.2167	1.1536
Avg	1.3388	1.3085	1.2444	1.1924	1.5318	1.3987	1.3018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344001 / 33KV S/S WASHIM

Feeder No / Name : 202 / TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	1.7737	1.848	1.7002	1.6651	1.828	1.7918
2	1.7556	1.7556	1.7737	1.7177	1.647	1.8099	1.7737
3	1.7375	1.6832	1.7737	1.6632	1.6289	1.7556	1.7737
4	1.6118	1.6476	1.6632	1.6632	1.5927	1.7013	1.7556
5	1.6118	1.6118	1.6804	1.6632	1.5384	1.6651	1.6289
6	1.6632	1.6632	1.6632	1.5154	1.5384	1.647	1.6289
7	1.6804	1.6476	.0187	1.5893	1.5402	1.6289	1.4842
8	1.7002	1.6118	1.4784	1.5708	1.4937	1.6804	1.5708
9	1.7556	1.5565	1.4784	1.6804	1.5154	1.5708	1.5708
10	1.448	1.5565	1.4784	1.4415		1.6263	1.6632
11	1.647	1.7375	1.8099	1.7551	1.7924	1.7002	1.7375
12	1.6476	1.7551	1.8099	1.8111	1.7924	1.922	1.8099
13	1.6832	1.7909	1.8099	1.8296	1.8296	1.9404	1.8099
14	1.8298	1.828	1.8099	1.8111	1.6827	1.9022	1.8099
15	1.7372	1.8099		1.7741	1.7193	1.9753	1.8099
16	1.8099	1.9004	1.7924	1.7194	1.829	1.7909	1.848
17	1.8099	1.9004	1.8107	1.8099	1.829	1.8823	1.829
18	1.8461	1.9547	1.829	1.8099	1.8099	1.8804	1.848
19	2.0814	2.1948	2.0328		1.9204	2.0119	2.0328
20	2.1719		2.2546	2.0119	2.0328	2.2862	2.2177
21	2.1948	2.0119	1.9404	2.0119	2.0328	2.1033	2.1437
22	2.0119	2.0119	1.9044	1.9909	1.9909	1.97	2.0328
23	1.9342	1.9589	1.848	1.8099	1.9547	1.828	2.0538
24	1.829	1.848	1.848	1.7558	1.7556	1.8823	1.8099
Max	2.1948	2.1948	2.2546	2.0119	2.0328	2.2862	2.2177
Min	1.448	1.5565	.0187	1.4415	1.4937	1.5708	1.4842
Avg	1.7913	1.7917	1.7111	1.7437	1.7448	1.8329	1.8098

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344001 / 33KV S/S WASHIM

Feeder No / Name : 203 / NARAYANBABA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1458	1.2012	1.1088	1.1088	1.2489	1.2308	1.2308
2	1.1458	1.1088	1.1088	1.1088	1.2308	1.1765	1.1946
3	1.0974	1.0974	1.1088	1.1203	1.2127	1.1584	1.1462
4	1.1088	1.1088	1.1088	1.1203	1.1946	1.1222	1.1104
5	1.1203	1.1088	1.0974	1.1088	1.1765	1.1222	1.1222
6	1.1088	1.0974	1.1088	1.1088	1.1765	1.1041	1.1946
7	1.0974	1.1088	1.0745	1.1088	1.2696	1.1576	1.1222
8	1.1088	1.0719	1.0082	1.1088	1.1203	1.1389	1.1088
9	1.0679	.9774	.9335	1.0719	1.1203	1.0082	1.1088
10	1.086	1.0136	.9335	.905		.9335	1.1088
11	.9774	1.0679	.905	.961	1.0719	.924	1.0974
12	.9313	1.0745	.9412	.9979	1.0719	1.0242	1.086
13	.9593	1.0387	.9412	.9979	1.0349	.9795	1.0498
14	.9709	1.1041	.9412	.9511	1.0242	.9979	1.0498
15	.9313	1.0136		.961	1.0242	1.0164	1.0498
16	.9955	.9412	.9877	.905	1.0059	.9145	1.0608
17	.9412	.9412	1.0608	.905	1.0608	.985	1.0719
18	.9412	1.0974	1.0719	.8145	1.0608	1.0719	1.0829
19	1.086	1.0974	1.1088		1.2567	1.267	1.1641
20	1.1222		1.3306	1.2803	1.2936	1.2803	1.2936
21	1.1088	1.0974	1.1203	1.2803	1.307	1.1888	1.2536
22	1.1458	1.1222	1.1576	1.2803	1.267	1.1946	1.307
23	1.2437	1.1827	1.2012	1.267	1.267	1.267	1.307
24	1.1458	1.1888	1.1458	1.1273	1.267	1.267	1.267
Max	1.2437	1.2012	1.3306	1.2803	1.307	1.2803	1.307
Min	.9313	.9412	.905	.8145	1.0059	.9145	1.0498
Avg	1.0661	1.0809	1.0654	1.0695	1.1636	1.1054	1.1495

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344001 / 33KV S/S WASHIM

Feeder No / Name : 204 / IUDP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7468	.7842	.6908	.7059	.7059	.7059
2	.7468	.7468	.7842	.6908	.7059	.7059	.6878
3	.7392	.7392	.7392	.6908	.6878	.6878	.6697
4	.7095	.7023	.7023	.6722	.6697	.6878	.6516
5	.6653	.6283	.6283	.6838	.6516	.6878	.6335
6	.6099	.6099	.6535	.5975	.6335	.5792	.5792
7	.5914	.6099	.6535	.5544	.6348	.5601	.5068
8	.5544	.0187	.5359	.5175	.5975	.4854	.462
9	.4706	.4706	.4435	.4805	.5068	.4344	.462
10	.4525	.4706	.4435	.4706		.4435	.462
11	.4163	.4706	.4344	.4805	.4755	.4706	.439
12	.4656	.4835	.4525	.5121	.5121	.4435	.4298
13	.4706	.5373	.4706	.5121	.5487	.5121	.5731
14	.5729	.5973	.5731	.4755	.5853	.5487	.5731
15	.6089	.6154		.4805	.6219	.5914	.543
16	.6154	.5731	.5792	.6335	.6219	.5914	.5853
17	.7059	.5373	.5853	.567	.5487	.5175	.5853
18	.7059	.5121	.5175	.5316	.4961	.5544	.6099
19	.543	.5121	.5853		.5121	.5792	.5914
20	.6154		.6584	.6584	.6283	.5853	.6468
21	.7023	.7316	.6468	.6516	.7095	.5487	.7023
22	.7392	.6584	.6722	.6584	.7059	.543	.6838
23	.7468	.7682	.6653	.724	.724	.7783	.7468
24	.7762	.7947	.8215	.7392	.724	.724	.724
Max	.7842	.7947	.8215	.7392	.724	.7783	.7468
Min	.4163	.0187	.4344	.4706	.4755	.4344	.4298
Avg	.6253	.5885	.6100	.5945	.6177	.5819	.5939

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344001 / 33KV S/S WASHIM

Feeder No / Name : 205 / CIVIL LINE EXPRESS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0187	.0189	.0181	.0181	.0181
2	.0187	.0187	.0187	.0187	.0181	.0181	.0181
3	.0185	.0185	.0183	.0187	.0181	.0181	.0181
4	.0187	.0185	.0189	.0189	.0181	.0181	.0181
5	.0187	.0185	.0187	.0189	.0181	.0181	.0181
6	.0187	.0187	.0189	.0187	.0181	.0181	.0181
7	.0187	.0185	.0187	.0189	.0181	.0189	.0181
8	.0187	.0185	.0187	.0187	.0189		.0189
9	.0181	.0181	.0189	.0189	.0189	.0191	.0189
10	.0181	.0181	.0189	.0189		.0189	.0189
11	.0181	.0181	.0189	.0189	.0189	.0189	.0189
12	.0179	.0179	.0189	.0189	.0189	.0189	.0189
13	.0181	.0179	.0189	.0189	.0189	.0189	.0189
14	.0189	.0181	.0189	.0189	.0189	.0189	.0189
15	.0181	.0181		.0189	.0189	.0185	.0189
16	.0189	.0189	.0189	.0189	.0189	.0187	.0187
17	.0189	.0189	.0189	.0189	.0189	.0185	.0187
18	.0189	.0189	.0189	.0189	.0189	.0185	.0187
19	.0189	.0189	.0189		.0189	.0189	.0189
20	.0189		.0189	.0189	.0189	.0189	.0185
21	.0189	.0189	.0189	.0189	.0189	.0189	.0187
22	.0189	.0189	.0189	.0189	.0181	.0181	.0189
23	.0189	.0185	.0187	.0181	.0181	.0181	.0189
24	.0185	.0187	.0189	.0187	.0181	.0181	.0181
Max	.0189	.0189	.0189	.0189	.0189	.0191	.0189
Min	.0179	.0179	.0183	.0181	.0181	.0181	.0181
Avg	.0186	.0185	.0188	.0188	.0186	.0185	.0186

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / PIMPALGAON SUB-STATION

Feeder No / Name : 202 / ANSING GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4969	1.4784	1.4784	1.5154	1.6804	1.6263	1.643
2	1.7926	1.4784	1.531		1.7737	1.6632	1.5893
3	1.4784	1.5154	1.643		1.848	1.8111	1.6632
4	1.5893	1.643	1.6804		1.9774	1.922	1.7551
5	1.8111	1.7924	1.7737		2.1098	2.0485	1.8671
6	1.9035	1.9805	1.9978	1.7002	2.0883	2.0883	2.1658
9	1.531	1.5524	1.4937	1.5524	1.7177	1.7177	1.6057
10	1.4415	1.2752	1.4045	1.3121	1.5497	1.6078	1.5123
11	1.3306	1.182	1.423	1.2197	1.419	1.4083	1.4377
12	1.2197	1.2752	1.386			1.4266	1.3256
13	1.2752	1.2567	1.3817		1.6057	1.4045	1.2536
14	1.2986	1.2936	1.3443	1.4266	1.4784	1.3676	1.2752
15	1.4045	1.3121	1.4377	1.4266	1.5339	1.4563	1.3306
16	1.3491	1.3306	1.3817	1.3306	1.5123	1.4377	1.3306
17	1.3306	1.3352	1.4784	1.386	1.6244	1.5684	1.4563
18	1.5729	1.4118	1.5524	1.3717	1.6263	1.6244	1.5497
19	1.7177	1.6617	1.643	1.7924	1.8671	1.8111	1.8111
20	1.8484	1.8298	1.8665	1.8298	1.9044	1.9791	1.9418
21	1.7737	1.7737	1.6263	1.9231	1.8298	1.9418	1.9239
22	1.7364	1.7177	1.7187	1.9231	1.885	1.9044	1.8858
23	1.5893	1.6057	1.7926	1.7924	1.7551	1.7737	1.7737
24	1.5154	1.5339	1.5339	1.5154	1.6817	1.6632	1.6804
Max	1.9035	1.9805	1.9978	1.9231	2.1098	2.0883	2.1658
Min	1.2197	1.182	1.3443	1.2197	1.419	1.3676	1.2536
Avg	1.5457	1.5107	1.5713	1.5636	1.7366	1.6933	1.6263



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / PIMPALGAON SUB-STATION

Feeder No / Name : 203 / 11 KV ANSING AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.1204		.0781
3					.1204		.0937
4					.1372		.1067
5					.1372		.1219
6					.1219	.1189	.1486
7					.1219	.1337	.1715
8					.1219		.2
9					.1067	.1524	.1143
10	.2787	.2134	.25	.2378			
11	.2286	.2591	.25	.2031			
12	.2591	.1738	.25	.2134			
13	.2	.141		.208			
14	.1808	.1509		.1593			
15	.1132	.1429		.1715			
16	.1334	.1448		.176			
17	.1189	.1429		.1509			
Max	.2787	.2591	.25	.2378	.1372	.1524	.2
Min	.1132	.141	.25	.1509	.1067	.1189	.0781
Avg	.1891	.1711	.25	.19	.1235	.135	.1294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / PIMPALGAON SUB-STATION

Feeder No / Name : 204 / 11 KV PARDI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2896	.3086		.216			
3	.2896	.2743		.2623			
4	.2743	.2743		.216			
5	.2591	.3048		.216			
6	.3353	.3913		.216			
7	.3963	.3612		.3906			
8	.442	.4917		.3395			
9	.442	.4917		.3125			
10					.4161	.3814	
11					.4877	.381	.3963
12					.442	.3567	
13					.442	.2972	.2972
14					.3658	.3048	.2572
15			.2286		.3048	.2743	.3048
16			.5093		.2972	.2591	.4588
17			.4012		.3269	.2439	.4572
Max	.442	.4917	.5093	.3906	.4877	.3814	.4588
Min	.2591	.2743	.2286	.216	.2972	.2439	.2572
Avg	.3410	.3622	.3797	.2711	.3853	.3123	.3619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / PIMPALGAON SUB-STATION

Feeder No / Name : 205 / HB OIL INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0189	.0191	.0191
2		.0191	.0191	.0191		.0191	.0191
3		.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191		.0191	.0191
5		.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0381	.0381	.0381	.0191
10		.0381	.0381	.0381	.0572	.0381	.0381
11	.0191	.0572	.0572	.0381	.0572	.0381	.0381
12	.0191	.0572	.0572	.0572	.0572	.0381	
13	.0191	.0572	.0572	.0572		.0381	.0572
14	.0191	.0572	.0572	.0572	.0572	.0381	.0572
15	.0191	.0572	.0572	.0572	.0572	.0381	.0572
16	.0191	.0572	.0572	.0572	.0381	.0381	.0572
17	.0191	.0572	.0381	.0572	.0381	.0381	.0572
18	.0191	.0381	.0572	.0572	.0381	.0572	.0381
19	.0191	.0381	.0572	.0572	.0381	.0754	.0191
20	.0191	.0191	.0381	.0381	.0381	.0566	.0191
21	.0191	.0191	.0191	.0191	.0191	.0377	.0191
22	.0191	.0191	.0191		.0191	.0189	.0191
23	.0191	.0191	.0191	.0191	.0191	.0189	.0191
24	.0191	.0191	.0191	.0191	.0191	.0189	.0191
Max	.0191	.0572	.0572	.0572	.0572	.0754	.0572
Min	.0191	.0191	.0191	.0191	.0189	.0189	.0191
Avg	.0191	.0326	.0342	.0357	.0336	.0325	.0299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344002 / PIMPALGAON SUB-STATION

Feeder No / Name : 206 / WARLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.2241	.2218	.3174	.3142	.2987	.3206
2	.3547	.2054	.2452	.3547	.3734	.3361	.2987
3	.3547	.2054	.2641	.4108	.4481	.3772	.3734
4	.3734	.2641	.3018	.4481	.4854	.4527	.4715
5	.5228	.3395	.3206	.5228	.5975	.5281	.5658
6	.7095	.3206	.3772	.4481	.5975	.6161	.6224
9		.1698	.2614	.3734	.3772	.3206	.3734
10	.2772	.1307	.1867	.2801	.2452	.2452	.2614
11	.2054	.1494	.168	.2427	.2427	.2033	.2054
12	.1867	.1109	.1494	.2957	.2075	.2033	.2054
13	.1867	.1109		.2957	.2427	1.4045	.2054
14	.168	.2033		.2801	.2263	.2427	.2561
15	.2058	.168	.1509	.2614	.2427	.3361	.2957
16	.2328	.1663	.1509	.3258	.2641	.3174	.2987
17	.2218	.2303	.1867	.3475	.3206	.3921	.2801
18	.2241	.2481	.2054	.3326	.3361	.3547	.3174
19	.3174	.2801		.4294	.4904	.4668	.3547
20	.3174	.2641	.3361	.4294	.4904	.4481	.4294
21	.3018	.2614	.2987	.3921	.415	.3921	.3961
22	.2829	.2614	.3547	.3547	.3734	.3361	.3547
23	.2614	1.5565	.3361	.3361	.3395	.3395	.3395
24	.3547	.2241	.2241	.3174	.3206	.2987	.3174
Max	.7095	1.5565	.3772	.5228	.5975	1.4045	.6224
Min	.168	.1109	.1494	.2427	.2075	.2033	.2054
Avg	.3054	.2770	.2495	.3544	.3614	.4050	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344003 / 33 KV RAJGAON S/S

Feeder No / Name : 201 / 11 KV RAJGAON TONDGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.823		.7522
2	.7011	.6878		.5487	.7392		.7164
3	.7164	.6733		.5914	.7762		.7316
4	.7164	.7087	.663	.5914	.8048		.7316
5	.7087	.7087	.663	.6584	.7964		.7602
6	.7087	.7087	.7316	.6447	.7712	.7459	.8859
7	.7377	.7461	.7293	.8048	.7956	.8288	1.0974
8	.7377	.663	.663	.6554	.7209	.663	1.0608
9	.6783	.6554	.663	.6554	.7125		
10	.1753	.1017	.3315	.3658	.3391	.1658	.2149
11	.2743	.1658	.3277	.3772	.373	.1658	.1791
12	.1658	.1658	.3315		.3315	.2865	.0678
13	.1638	.1677	.3315	.3605	.3605	.2629	.0686
14	.1638	.1658	.3315		.3315	.2743	.0686
15	.1619	.1658	.3391	.3277	.3315	.2774	.0678
16	.1619	.1658	.3391	.3277	.1658	.3189	.0678
17	.1658	.1658	.3429	.3315	.1696	.3224	.0686
18	.1562					.2865	
20					1.0608		
22					.9145		
23						.7602	
24							.7602
Max	.7377	.7461	.7316	.8048	1.0608	.8288	1.0974
Min	.1562	.1017	.3277	.3277	.1658	.1658	.0678
Avg	.4290	.4260	.4848	.5172	.5957	.4122	.4882

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344003 / 33 KV RAJGAON S/S

Feeder No / Name : 202 / RAJGAON TONDGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7468		.7316	.7865	.695	.7343
2	.7011	.724		.7316	.7762		.7343
3	.6805	.7442		.7762	.7392		.7316
4	.7522	.8505	.7316	.8871	.8779		.7316
5	.9922	.8859	.9745	.9145	.9412		.7964
6	1.0631	.9214	1.0059	.985	.964	1.0059	.9214
7	.503	.4578	.4024	.4572	.4144	.4755	.439
8	.4191	.4144	.3658	.3605	.4096	.439	.3326
9	.4239	.2949	.695	.3277	.3563	.7499	.2896
10	.7888	.6274	.695	.7316	.763	.823	.6268
11		.4973		.6001	.6783	.4572	.6268
12	.6962		.5801			.6089	.5935
13	.6062	.6401	.547	.4915	.5735	.6135	.5658
14	.5571	.6401	.5801	.4973	.5801	.6173	.5658
15	.5992	.6401	.6783	.4915	.663	.6241	.5765
16	.6154	.7316	.6783	.4915	.695	.6379	.5596
17	.6133	.5487	.6001	.5304	.6401	.6626	.6001
18	.3125	.3658	.3814	.362	.2743	.362	.4572
19	.4163	.8596	.3582	.4525	.823	.4435	
20	.9979	.9145	.985	1.0059		1.0164	1.0534
21	.961	.9145	.823	1.0059	.9877	.9511	1.0269
22	.961	.9511	.9145	.9145		.9145	.8871
23	.8402	.823	.823	.8688	.8048	.8413	.8316
24	.7842	.7468	.823		.8871	.7316	.7964
Max	1.0631	.9511	1.0059	1.0059	.9877	1.0164	1.0534
Min	.3125	.2949	.3582	.3277	.2743	.362	.2896
Avg	.6944	.6931	.6821	.6643	.6969	.6835	.6730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 201 / 11 KV LALDEO AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0373	.0343	.0747	.0934			
3	.0373	.0343	.0747	.0934			
4	.0343	.0343	.0747	.0934			
5	.0343	.0343	.0747	.112			
6	.0343	.0343	.1494	.112			
7	.0686	.0343	.1478	.1494			
8	.0686	.0343	.2772	.1494			
9	.0686	.0514	.2743	.1494			
10					.0549		.0514
11				.0857	.0914	.0514	.0554
12				.0514			.0924
13				.0857	.037		
14				.0686	.0554	.0343	.0924
15				.0857	.037	.0343	.0924
16				.0857	.037	.0343	.0924
17				.0857	.0554	.0343	.0924
18						.0343	
Max	.0686	.0514	.2772	.1494	.0914	.0514	.0924
Min	.0343	.0343	.0747	.0514	.037	.0343	.0514
Avg	.0479	.0364	.1434	.1001	.0526	.0372	.0813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 202 / 11 KV TAMSIA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0343	.0377	.1509	.0514		.0343
2	.0171	.0343	.0377	.0566	.0514		.0343
3	.0171	.0343	.0377	.0566	.0514		.0343
4	.0171	.0343	.0377	.0566	.0514		.0343
5	.0171	.0857	.1132	.0566	.0514		.0343
6	.0171	.1715	.1886	.0566	.0857		.0857
7	.1372	.2743	.3018	.3018	.2572		.2401
8	.1478	.2058	.4527	.3772	.2401		.2743
9	.2572	.2401	.3395	.415	.2743		.2743
10	.2401	.2229	.3772	.3429	.1132		.2401
11	.3086	.3018	.3961	.2743	.3395	.2743	.2641
12	.2743	.3018	.3772	.2572	.3395	.2743	.2641
13	.2915	.2263	.3395	.3258	.3395	.2743	.2641
14	.3772	.2641	.3772	.3429	.3018	.2743	.2641
15	.2743	.2452	.3395	.2743	.3018	.3086	.2641
16	.2229	.2641	.3018	.2915	.2829	.2743	.3395
17	.2058	.2452	.3018	.2401	.2641	.2401	.2641
18	.2058	.2641	.2641	.2572	.2641	.2743	.3395
19	.2058	.2452	.2452	.2401	.3395	.2572	.3395
20	.2058	.2452	.2641	.2401	.2263	.2229	.3395
21	.1715	.2452	.2263	.2572		.2058	
22	.1886	.2452	.2075	.2572		.2401	
23	.1715	.2452	.1886	.2401		.2058	
24	.1478	.1715	.2452	.1886			.2058
Max	.3772	.3018	.4527	.415	.3395	.3086	.3395
Min	.0171	.0343	.0377	.0566	.0514	.2058	.0343
Avg	.1723	.2020	.2499	.2316	.2113	.2559	.2112



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 203 / 11 KV KALAMBA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.362	.3734	.1715		.1715
2		.0857	.362	.3734	.1715		.1372
3		.0857	.362	.3734	.1715		.1372
4		.0857	.362	.3734	.1715		.1372
5		.0857	.3582	.3734	.3429		.1715
6		.0857	.4477	.3734	.3429		.3429
7					.1715		
13	.3429						
14		.1791					
19		.964	.4668	.1715	.8669	.4287	.5658
20	.1715	.7973	.3547	.1715	.6201	.3429	.4477
21	.1715	.5316	.4108	.1715		.1715	
22	.1715	.443	.3361	.1715		.1715	
23	.0857	.4382	.2987			.1715	
24		.0857	.362	.2987	.1715		.1372
Max	.3429	.964	.4668	.3734	.8669	.4287	.5658
Min	.0857	.0857	.2987	.1715	.1715	.1715	.1372
Avg	.1886	.3080	.3736	.2932	.3202	.2572	.2498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 204 / SEPR. WW-EK BHURJI DAM-

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND

UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0343	.0514	.0373	.0514		.0343
2	.0343	.0343	.056	.0373	.2572		.2058
3	.0373	.0343	.0566	.0373	.2401		.2058
4	.0373	.0514	.0566	.0373	.2401		.2572
5	.0343	.0857	.0566	.0373	.2229		.2229
6	.0358	.0343	.0566	.0373	.2229		.2229
7	.0514	.0514	.0566	.0373	.5658		.3429
8	.0514	.0343	.0566	.0373	.5144		.3429
9	.0514	.0343	.0566	.0373	.5316		.2058
10	.3086	.3429	.4344	.0343	.0377		.0514
11	.4287	.3189	.4294	.0343	.0377	.0343	.0377
12	.5316	.4031	.4481	.0514		.0343	.0377
13	.2229	.3681	.4108	.0514	.0343	.0343	.0377
14	.2401	.2865	.3361	.0343	.0343	.0343	.0377
15	.2743	.3155	.3547	.0514		.0343	.0377
16	.3429	.4207	.3921	.0343		.0343	.0377
17	.3086	.3155	.3734	.0514		.0229	.0377
18	.0343	.0373	.0373	.0343		.0343	.0377
19	.0343	.0377	.0377	.0514		.0343	.0377
20	.0343	.0566	.0373	.0343		.0343	.0566
21	.0343	.0566	.0373	.0514		.0343	
22	.0343	.0566	.0373	.1029		.0514	
23	.0343	.0566	.0373	.0514		.0343	
24	.0514	.0343	.056	.0373			.0343
Max	.5316	.4207	.4481	.1029	.5658	.0514	.3429
Min	.0343	.0343	.0373	.0343	.0343	.0229	.0343
Avg	.1369	.1459	.1651	.0434	.2300	.0347	.1201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 205 / TAMSALA GAOTHAN FDR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.3429	.3142	.3361	.2915		.3772
2	.2572	.3258	.3142	.3361	.2743		.2401
3	.2572	.3429	.3142	.3361	.2915		.1886
4	.2401	.3086	.3142	.3361	.3086		.2058
5	.2743	.2743	.3326	.3361	.3258		.2401
6	.2572	.3086	.3326	.3361	.3429		.2401
7	.3258	.3429	.4066	.3547	.3772		.1029
8	.3601	.3601	.4066	.3734	.3429		.0686
9	.3601	.3429	.3326	.4854	.3601		.0686
10	.3258	.3086	.3361		.4435		.0857
11	.4458	.6653	.4108	.3429	.4066	.1372	.1307
12	.3258	.5544	.5415	.3772			.1307
13	.5316	.5914	.5975	.7202	.4251		
14	.5487	.3326	.3547	.8059	.4066	.12	.0934
15	.5658	.4805	.4481	.7888	.3696	.1372	.112
16	.3944	.4435	.4668	.9088	.3881	.1715	.0934
17	.463	.6283	.3921	.4458	.3696	.1543	.1494
18	.4115	.3696	.5415	.4458	.4066	.12	.1494
19	.3601	.3142	.3361	.4115	.4066	.12	.1494
20	.463	.3696	.3734	.4458	.3696	.1543	.1867
21	.4115	.4251	.4481	.3258		.3086	
22	.3429	.3881	.4108	.2743		.2172	
23	.3258	.3696	.3921	.3086		.12	
24	.3258	.3086	.3142	.3734			.2058
Max	.5658	.6653	.5975	.9088	.4435	.3086	.3772
Min	.2401	.2743	.3142	.2743	.2743	.12	.0686
Avg	.3672	.3958	.3930	.4437	.3635	.1600	.1609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344004 / 33 KV MIDC WASHIM SUB-

STATION

Feeder No / Name : 209 / 11 KV ANANT SAHAKARI SUT

SHEDDABLE RURAL

GIRNI Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.463	.4715	.5281	.3258		.4287
2	.3258	.4115	.4527	.4904	.3429		.3772
3	.3086	.3429	.4715	.4715	.3086		.4115
4	.2915	.3772	.4904	.4715	.3258		.3601
5	.3429	.3601	.4904	.4715	.3772		.3429
6	.3772	.4287	.4527	.4527	.3429		.4458
7	.462	.3944	.415	.5093	.4115		.3944
8	.463	.3601	.415	.4527	.3601		.3086
9	.3429	.3086	.3584	.3772	.3772		.1886
10	.2915	.4287	.3547	.3601	.3584		.3258
11	.3772	.4527	.3395	.3944	.415	.3601	.4338
12	.4115	.415	.3395	.3772	.2641	.3772	.5093
13	.3772	.3772	.3018	.4115	.3395	.3944	.4527
14	.4801	.4527	.3584	.4287	.3206	.3601	.4715
15	.4287	.4904	.4715	.4458	.4527	.3772	.4715
16	.3772	.3961	.4904	.4973	.4338	.3601	.3961
17	.3258	.4338	.5281	.4287	.3772	.3429	.3961
18	.3429	.4338	.5093	.463	.3772	.4115	.4715
19	.3086	.4904	.5093	.4287	.415	.4287	.4715
20	.3258	.5281	.4527	.4115	.4715	.3601	.5281
21	.3601	.3772	.4527	.4287		.3772	
22	.4458	.415	.4338	.4973		.3944	
23	.4115	.4527	.4338	.4287		.3601	
24	.3429	.3429	.4715	.4715			.4458
Max	.4801	.5281	.5281	.5281	.4715	.4287	.5281
Min	.2915	.3086	.3018	.3601	.2641	.3429	.1886
Avg	.3697	.4139	.4360	.4458	.3699	.3772	.4110

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344025 / KALAMBA SUBSTATION

Feeder No / Name : 201 / KAJALAMBA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	1.1885						
15				.1952	.2699	.6281	.6281
16	.7078	.4666	.2255	.298	.7497	.7627	.6581
17	.9042	.602	.3457	.2999	.8696	.7777	.8375
18	.8579	.6923	.8407	.2849	1.0183	.8525	.8514
19	.7827	.6472	.8708	.4498	.9284	.8674	.8365
20		.5562	.8858	.4948	.6289	.673	.6871
21	.6001		.8858	.6017	.5398	.6132	.6572
22	.5417	.5261	.6756	.4792	.5683	.6132	.6722
Max	1.1885	.6923	.8858	.6017	1.0183	.8674	.8514
Min	.5417	.4666	.2255	.1952	.2699	.6132	.6281
Avg	.7976	.5817	.6757	.3879	.6966	.7235	.7285

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344025 / KALAMBA SUBSTATION

Feeder No / Name : 202 / 11 KV PARDI TAKMOR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.2412		1.1229	1.378	.16		1.0365
8	.3401			1.378	.16	1.1495	1.0046
9	.3059		.4813	1.2818	.16	1.1203	.893
10	.4508		.4492	1.2338	.9111	.9271	.8601
11		.2085	.4025	1.1857		.926	.876
12			.4166	1.1683	.8322	.9568	.876
13	1.2235		.4006	.8642	.9659	.9887	.8442
14	1.2235	.9625	1.2017	.9015	.9659	.9249	.8282
15			1.2017				
16		1.0748					
17		1.155					
Max	1.2235	1.155	1.2017	1.378	.9659	1.1495	1.0365
Min	.2412	.2085	.4006	.8642	.16	.9249	.8282
Avg	.6308	.8502	.7096	1.1739	.5936	.9990	.9023

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344025 / KALAMBA SUBSTATION

Feeder No / Name : 203 / KALAMBA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6735	1.5893	1.6347	1.5975	1.6161	1.6718	1.5741
2	1.6177	1.5959	1.6161	1.5604	1.5975	1.6718	1.5556
3	1.631	1.5588	1.6161	1.5232	1.5806	1.6701	1.6111
4	1.7129	1.4161	1.7833	1.7461	1.7778	1.8186	1.7037
5	2.0062	1.9418	1.8576	1.8576	1.9504	2.0062	1.7778
6	2.0852	2.0538	1.9504	1.9504	2.0619	2.0805	1.8889
8		1.6598					
9	1.3553		1.1145	.8333	.9649	1.0802	1.1888
10	1.0328		.7802	1.0402	.8907	1.1104	.9815
11		.8889	.9288	.9659		1.1517	.963
12	1.0402	.8359	.9474		.985	1.1331	.963
13	1.0456	.9102	1.096	.5338		1.1888	1
14	1.0884	1.1331	1.096	.7316	.9288	1.2074	.9815
15	1.0974	1.2074	1.226	1.1134	.8916	1.1703	1
16	1.1065	1.1517	.9102	1.0477	.8907	1.2074	.9074
20		1.8947	1.8576	1.9504	1.1145	2.0619	2
21	2.2131		1.3211	1.3189	2.0062	1.9444	1.7407
22	1.6598	1.8204	1.8018	1.709		1.6667	1.7593
23	1.6598	1.8018	1.7461	1.5789	1.6667	1.6667	1.6296
24	1.6783		1.6161		1.5789	1.6718	1.5556
Max	2.2131	2.0538	1.9504	1.9504	2.0619	2.0805	2
Min	1.0328	.8359	.7802	.5338	.8907	1.0802	.9074
Avg	1.5120	1.4662	1.4158	1.3564	1.4064	1.5358	1.4096

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 201 / COLLECTOR OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9269	.9435	.9046	.9269	.8871	.9805	.8907
2	.8871	.8722	.8668	.8722	.851	.9805	.8722
3	.8536	.8519	.8308	.8907	.7947	.9444	.8527
4	.8182	.8131	.7947	.8165	.8148	.8148	.8157
5	.7663	.7522	.7593	.7778	.7794	.76	.7037
6	.7274	.7245	.7245	.6715	.6894	.703	.6475
7	.6495	.6468	.608	.6455	.6674	.6639	.5902
8	.595		.5902	.6251	.6475	.6232	.5676
9	.666		.5705	.5634	.5538	.5693	.5424
10	.6283		.5516	.6199	.5332	.564	.4887
11	.6817	.8291	.6017	.6633	.5877	.6219	.5265
12	.6918	.7272	.6509	.7301	.6509		.5816
13	.7474	.7642	.7714	.6957	.7906	.7103	.6368
14	.7846	.8078	.8325	.7906	.773	.793	.7285
15	.8068	.8333	.8256	.829	.7561	.8325	.7634
16	.8299	.8668	.8131	.8115	.7722	.7746	.7491
17	.7578	.8131	.7554	.7546	.7163	.7369	.6564
18	.6856	.7308	.7339	.7546	.7546	.6711	.6321
19	.7758	.7746	.7118	.7354	.7561	.7178	.695
20	.9562	.8501	.8695	.793	.8632	.7786	.7762
21	.9202	.8677	.8722	.814	.8668	.7955	.7794
22	.9454	.9102	.9297	.925	.9164	.8898	.8545
23	1.0306	.9649	.9659	.9269	.9714	.9083	.9288
24	.9805	.9649	.9805	.964	.96	.999	.9093
Max	1.0306	.9649	.9805	.964	.9714	.999	.9288
Min	.595	.6468	.5516	.5634	.5332	.564	.4887
Avg	.7964	.8242	.7715	.7749	.7647	.7753	.7162



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 202 / KATA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0793					
2	.3071	.2724	.1314			
3	.3115	.2831	.1314			
4	.3371	.1715	.1657			
5	.4055	.3375	.2906			
6	.5859	.5374	.4053			
7	.7053	.578	.5214			
8	.381	.5792	.4685			
9		.5442	.3687	.0335	.1143	.0975
10			.3475	.4953	.5615	.4952
11			.3024	.4969	.5643	.4936
12			.3007	.3961	.486	.4537
13			.3111	.4015	.4373	.3472
14			.2732	.3532	.3153	.332
15			.1562	.3578	.3573	.3242
16			.1849	.3731	.3958	.4087
17			.3318	.4349	.3923	.4027
Max	.7053	.5792	.5214	.4969	.5643	.4952
Min	.0793	.1715	.1314	.0335	.1143	.0975
Avg	.3891	.4129	.2932	.3714	.4027	.3728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 203 / URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3094	1.3463	1.2883	1.287	1.2197	1.3081	1.291
2	1.2936	1.2936	1.2172	1.1988	1.147	1.2896	1.2896
3	1.2619	1.2778	1.2	1.1815	1.1296	1.291	1.2515
4	1.2484	1.2619	1.2012	1.1273	1.11	1.2541	1.221
5	1.2323	1.2471	1.1852	1.11	1.1134	1.1815	1.1727
6	1.2087	1.2398	1.1691	1.2074	1.1157	1.1238	1.11
7	1.1343	1.1225	.9764	1.0317	1	.9938	1.0296
8	.9835		.954	.9279	.962	.9347	.9552
9	.9521		.9059	.9402	.8981	.8816	.8516
10	.9318		.3781	.9712	.7674	.8551	.7981
11	.9299	1.2321	.4294	.9562	.899	.9107	.817
12	.9182	1.121	1.1068	.9965	.9451		.8361
13	.985	1.1233	1.082	.9623	1.007	.9825	.8915
14	1.1092	1.1087	1.0905	1.0376	1.1215	1.0985	.9653
15	1.1474	1.1631	1.118	1.1122	1.0963	1.1145	.9856
16	1.2021	1.1487	1.0242	1.0974	1.087	1.0757	.9501
17	1.1839	1.1499	.9694	1.0575	1.0328	1.049	.9481
18	1.1839	1.0295	1.036	.9839	1.0154	1.0431	.811
19	1.2932	1.1245	1.1087	1.0232	1.0763	1.0414	1.0189
20	1.3478	1.3463	1.2686	1.1779	1.2407	1.2159	1.1316
21	1.3842	1.3817	1.291	1.2395	1.3094	1.2356	1.2752
22	1.4615	1.4215	1.44	1.3505	1.3407	1.2752	1.3094
23	1.443	1.4769	1.4002	1.3477	.9835	1.3292	1.3237
24	1.4171	1.4031	1.3619	1.3605	1.2738	1.3251	1.2923
Max	1.4615	1.4769	1.44	1.3605	1.3407	1.3292	1.3237
Min	.9182	1.0295	.3781	.9279	.7674	.8551	.7981
Avg	1.1901	1.2390	1.0918	1.1119	1.0788	1.1222	1.0636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 204 / 11 KV CIVIL HOSPITAL  
EXPRESS. Feeder KV- 11 /  
OUTGOING

SHEDDABLE RURAL

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0286	.0434	.0267	.021	.0229	.0248	.0229
2	.0286	.0404	.0275	.0248	.0229	.0229	.0218
3	.0286	.0347	.0297	.021	.0229	.0229	.0214
4	.0286	.0347	.0301	.0237	.0229	.0229	.0229
5	.0286	.0366	.0305	.0218	.0229	.0229	.0218
6	.0286	.0324	.0286	.021	.0229	.0229	.0221
7	.0324	.0343	.0309	.0248	.0229	.021	.0214
8	.0286		.0305	.021	.021	.0214	.0229
9	.0381		.0404	.0343	.0362	.0332	.0214
10	.0602		.0907	.0834	.0785	.074	.0237
11	.1246	.1181	.1204	.1185	.1067	.1201	.0286
12	.1417	.1326	.1243	.1242	.125	.1217	
13	.1288	.1269	.1127	.1143	.1131	.1193	.0267
14	.1192	.1216	.088	.0895	.1082	.0892	.0229
15	.1063	.1067	.0587	.0884	.107	.0652	.0233
16	.1078	.0956	.0305	.0743	.0789	.0404	.0199
17	.099	.0773	.0469	.0518	.0899	.0294	.0229
18	.0899	.099	.0572	.0736	.0865	.0309	.0214
19	.0918	.0804	.0218	.0545	.0694	.0233	.0221
20	.0491	.0305	.0233	.0286	.0248	.0229	.0229
21	.0487	.0286	.0233	.0286	.0248	.0237	.0229
22	.0453	.0313	.0229	.0248	.0305	.0229	.0248
23	.0393	.0305	.021	.0248	.0248	.0267	.0237
24	.0328	.0343	.0324	.021	.0229	.0256	.0313
Max	.1417	.1326	.1243	.1242	.125	.1217	.0313
Min	.0286	.0286	.021	.021	.021	.021	.0199
Avg	.0648	.0652	.0479	.0506	.0545	.0438	.0233

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344028 / 33 KV CIVIL LINE SUBSTATION

Feeder No / Name : 205 / 11KV JAVAHAR NAVODAY

SHEDDABLE RURAL

VIDYALAYA Feeder KV- 11 /  
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0243	.0243	.0205	.0187	.0242	.0242
2	.0168	.0243	.0224	.0168	.0187	.0224	.0224
3	.0149	.0224	.0224	.0149	.0187	.0224	.0205
4	.0168	.0243	.0205	.0149	.0168	.0205	.0186
5	.0205			.0149			.0149
6	.0168						.0149
9			.0168				
10			.0168				
11				.0149			.0149
12	.015		.0149				
13	.015		.0149	.0149			.0149
14	.015			.0149			
15	.0149			.0168			
16	.0149			.0149			
17	.0149						
18	.0149			.0149			.0149
19	.0149	.0149	.0168	.0168			
20	.0149	.0187	.0168	.0224		.0205	.0168
21	.0149	.015	.0149	.0205	.0168	.0149	.0261
22	.0149	.0168	.0224	.0224	.0223	.0186	.0205
23	.0168	.0187	.0243	.0205	.0224	.0279	.0224
24	.0205	.0168	.0205	.0261	.0243	.0242	.0242
Max	.0205	.0243	.0243	.0261	.0243	.0279	.0261
Min	.0149	.0149	.0149	.0149	.0168	.0149	.0149
Avg	.0160	.0196	.0192	.0178	.0198	.0217	.0193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344041 / 33/11 KV POLE FACTORY S/STN

Feeder No / Name : 201 / LAKHALA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	***	***	***		***	3.8104	
12	***	***	***	***	***	***	
13	***	***	***	***	***	***	
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	***	***	***	***	***	***	***
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	4.5725
19	***	***	***	***	***	***	
20	***	***	***	***	***	***	
21	***	1.5242	9.907	***	***	***	
Max	101.3566	99.0704	96.0221	99.8325	106.6912	102.8808	48.011
Min	25.1486	1.5242	9.907	67.063	22.8624	3.8104	4.5725
Avg	81.6118	75.4459	74.8224	88.0965	84.6602	78.4250	19.052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344041 / 33/11 KV POLE FACTORY S/STN

Feeder No / Name : 202 / 11 KV TAMSHI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.072	.9492	.9774	.8954	.9979	.9511	.924
2		1.0317	.9593	.9593	.9694	.9511	.9145
3		1.0136	.9671	.9593	.9511	.9511	.9328
4		1.0608	1.0317	1.0425	.9694	.9694	.9694
5		1.2071	1.1706	1.1888	1.0974	1.086	1.0974
6		1.7375	1.4998	1.5546	1.5729	1.4842	1.4969
7		1.4327	1.2894	1.3352	1.3717	1.386	1.2071
8		1.2757	1.2127	1.1641	1.2489	1.0791	1.0317
9		1.1744	1.0277		1.086	1.0425	.9593
10		.8745	.8328		.788	.7973	.7133
11		.7716		.3403	.815	.7164	.6984
12		.6935		.2949	.7796	.7087	.6733
13		.7343	.7716	.3239	.7712	.7537	.6661
14		.7164	.7537	.7455	.7186	.7343	.7011
15		.6805	.6201	.7186	.0754	.7164	.7186
16		.6661	.5258	.7282	.6068	.788	.7202
17		.7011	.8669	.7455	.7186	.788	.7712
18		.7888	.8745	.7373	.7701	.8328	.7619
19		.9036	1.134	.8682	.8871	1.0745	.9492
20	1.4661	1.1765	1.1706	1.134		1.2071	1.1222
21		1.1523	1.1706	1.1523	1.0974	1.1157	1.0974
22	1.2715	1.1157	1.1041	1.0974		1.0608	1.0425
23	1.0679	1.0498	.9877	1.0136	.9955	1.0059	.9877
24	.0823	1.0745	.9774	.9774	1.0425	.9979	.9511
Max	1.4661	1.7375	1.4998	1.5546	1.5729	1.4842	1.4969
Min	.072	.6661	.5258	.2949	.0754	.7087	.6661
Avg	.7920	.9992	.9966	.9080	.9241	.9666	.9211

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344041 / 33/11 KV POLE FACTORY S/STN

Feeder No / Name : 203 / 11 KV WANGI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1299				.1932	.112
3	.1271				.0553	.1
4	.1383				.0545	.1181
5	.1551				.0656	.128
6	.2934				.1572	.1981
7	.2761			.212	.153	.2681
8	.2248			.2681	.1276	.2439
9	.21			.2473	.1271	.208
10	.1867	.2	.2521	.172		
11	.1829	.1905	.2534	.0964		
12	.16	.1067		.088		
13	.1524	.1006	.152	.076		
14	.1486	.088	.1629	.0587		
15	.1524	.088	.1562			
16	.1638		.1677			
17	.1829		.2248			
Max	.2934	.2	.2534	.2681	.1932	.2681
Min	.1271	.088	.152	.0587	.0545	.1
Avg	.1803	.1290	.1956	.1523	.1167	.1720

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344041 / 33/11 KV POLE FACTORY S/STN

Feeder No / Name : 204 / 11 KV SONKHAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17
HR	Load (MW)
1	.8871
2	.8686
3	.8871
4	.9425
5	1.0534
6	1.386
7	1.3306
8	1.1458
9	.8048
10	.7602
11	.7265
12	.7522
13	.7392
14	.7023
24	.8779
Max	1.386
Min	.7023
Avg	.9243



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344042 / 33/11 KV WAI SUB-STATION

Feeder No / Name : 201 / 11 KV H. T. BARRAGES FROM SHEDDABLE HV(AGRICULTURE)  
WAI Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0463	.0941	.0995				
3	.0312	.061	.1006				
4	.0309	.0564	.1174				
5	.0309	.0533	.0995				
6	.0617	.0701	.1677				
7	.0937	.0926	.1492				
8	.1406	.093	.1341				
9	.0937	.0686	.1526				
10				.2267	.0991	.1091	.1372
11				.1943	.0741	.192	.2031
12				.1943	.0625	.096	.1524
13				.1943	.0686	.0972	.1543
14				.1107	.061	.16	.0914
15				.1107	.0686	.1296	.1406
16				.112	.0488	.1448	.1562
17				.112	.054	.0648	.1389
Max	.1406	.0941	.1677	.2267	.0991	.192	.2031
Min	.0309	.0533	.0995	.1107	.0488	.0648	.0914
Avg	.0661	.0736	.1276	.1569	.0671	.1242	.1468

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

WASHIM CIRCLE[611]

WASHIM DIVISION[151]

WASHIM[276]

BU 1511

Substation No/ Name :- 344043 / 33/11 KV ADOLI SUB-STATION

Feeder No / Name : 201 / 11 KV H. T. BARRAGES FROM SHEDDABLE HV(AGRICULTURE)  
ADOL Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3382			.4236	.3429
3	.423			.4415	.4572
4	.5853			.4761	.5647
5	.4365			.5101	.6401
6	.4599			.5769	.5716
7	.4938			.6073	.5761
8	.4938			.6329	.514
9	.5146			.5386	.5853
10	.3628	.3788	.2256		
11		.3978	.24		
12	.1372	.2667	.1907		
13	.1067	.2317	.1697		
14	.0754	.1395	.3037		
15	.1067	.1219			
16	.9145	.1555	.3849		
17	.1646	.1486	.5171		
Max	.9145	.3978	.5171	.6329	.6401
Min	.0754	.1219	.1697	.4236	.3429
Avg	.3742	.2301	.2902	.5259	.5315