

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 201 / 11 KV GANGKHED TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961	.4755	.5373	.4854	.5228	.5373	.5175
2	.4961	.4755	.567	.5228	.5601	.567	.5544
3	.567	.4755	.6661	.5601	.6348	.6379	.5914
4	.6733	.6154		.5601	.7468	.8505	.6283
5	.8063	.724		.6722	.9335	1.0277	.7865
6	.9922	1.0631	1.134	1.0456	1.3443	1.134	1.2437
7		1.4529	1.4022	1.4937	1.5684	1.4175	1.5181
8	1.5592	1.6804	1.5592	1.7177	1.4937	1.5424	1.701
9	1.4723	1.4937	1.4883	1.4373	1.3321	1.6461	1.4175
10	1.4175	1.419	1.2971	1.2757	1.2971	1.4632	1.2403
11	1.3253	1.1203	1.2269	1.182	1.1694	1.1222	1.0985
12	1.1104	1.0829	1.0029	1.0631	1.0867	1.0974	1.0029
13	1.0029	1.0082	.9214	.8954	.9922	1.0534	.9671
14	.905	.9335	.8505	.8954	.8859	1.0349	.8954
15	.905	.8962	.815	.8688	.8596	.8962	.8859
16	.905	.9335	.8505	.8688	.8954	.961	.8505
17	.9114	.9114	1.0082	1.2323	.9671	1.0242	1.0425
18	.9214	.9568	1.1203	1.307	1.0631	1.0974	1.2308
19	.8859	1.0631	1.0829	1.3443	1.182	1.2752	1.3169
20	.8505	1.134	1.0082	1.2323	1.0745	1.1088	1.1523
21	.7964	.8859	.9335	.9709	.8688	.9055	.9145
22	.724	.6733	.7392	.8589	.6024	.8316	.7577
23	.6219	.6154	.6348	.5601	.567	.6283	.5853
24	.5014	.5316		.4854	.5316		.5487
Max	1.5592	1.6804	1.5592	1.7177	1.5684	1.6461	1.701
Min	.4961	.4755	.5373	.4854	.5228	.5373	.5175
Avg	.9064	.9425	.9926	.9806	.9658	1.0374	.9770

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 202 / 11 KV GANGKHED TOWN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.4024	.394	.3734	.4108	.3898	.4251
2	.3898	.4024	.4252	.3734	.4481	.4252	.4435
3	.4607	.4024	.4961	.4108	.4481	.4961	.4805
4	.5959	.4024	.5316	.4108	.6348	.6733	.5175
5	.7011	.5792	.6733	.4481	.7468	.7796	.6468
6	.7712	.788	.7796	.8215	1.0082	.8505	1.0242
7		1.1694	.8413	1.1949	1.1203	1.0631	1.2071
8	.9214	1.2323	1.0631	1.1576	1.0456	1.134	1.2254
9	.9568	1.1203	1.134	.9568	.8764	1.1888	.9922
10	.8505	1.0456	.8505	.8859	.8413	.9955	.7796
11	.788	.9709	.7796	.788	.7796	.9511	.7796
12	.7522	.7842	.788	.7164	.7011	.8413	.7164
13	.7164	.7468	.2454	.6878	.6024	.7682	.6089
14	.6154	.5975	.2835	.6154	.6024	.7316	.6089
15	.6154	.5601	.2481	.5792	.6089	.6283	.567
16	.6878	.5601	.2103	.5731	.7087	.695	.5316
17	.7362	.631	.3734	.7468	.7796	.7947	.724
18	.7087	.7087	.9709	.7842	.8505	.9328	.7964
19	.7442	.7442	.7468	.8215	.7796	.8686	.8779
20	.6379	.7011	.7468	.7842	.7164	.7762	.695
21	.5068	.6024	.7095	.6722	.5731	.6468	.6219
22	.4024	.4961	.5601	.5601	.5014	.5544	.5304
23	.4024	.4344	.4668	.4481	.4252	.4805	.439
24	.3658	.394		.3734	.4108		.4163
Max	.9568	1.2323	1.134	1.1949	1.1203	1.1888	1.2254
Min	.3544	.394	.2103	.3734	.4108	.3898	.4163
Avg	.6383	.6865	.6225	.6743	.6925	.7681	.6940

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 203 / 11 KV MOSICAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6655	1.6644	1.7718	1.7909	1.7909	1.701	1.9376
2	2.2325	2.0111	2.1971	1.97	2.1491	2.0553	2.1033
3	2.3743	2.0111	2.4188	2.3282	2.3282	2.2436	2.2148
4	2.6223	2.1152	2.4539	2.4356	2.4356	2.3034	2.3487
5	2.7343	2.7778	2.5869	2.4806	2.4806	2.4188	2.4792
6	2.7343	3.0521	2.5941	2.8349	3.0803	2.4539	3.0521
7		3.3482	3.5437	3.5056	1.3253	3.1893	3.4979
8	3.5437	2.5431	3.7209	3.1893	1.5043	3.5437	
9	3.7209	1.6118	3.5056	3.4202	1.262	3.6694	
10	3.12	1.6263	3.5082	3.12	1.1218	2.9797	
11					1.0517		
12					.9015		
13					.7628		
14					.7975		
15					.7712		
16					.9465		
17	1.4175	1.1218	1.4632	1.1694	1.0517	1.2403	
18	1.2757	1.3466	1.448	1.448	1.1443	1.3643	1.2934
19	1.2403	1.2403	1.3611	1.5684	1.2483	1.5592	1.5775
20	1.134	1.134	1.2536	1.4327	1.0517	1.382	1.382
21	1.0277	1.0631	1.182	1.3032	.9922	1.182	1.1694
22	.9214	.9568	1.0745	1.1584	.8859	1.0387	1.0498
23	.8505	.9214	.8954	1.086	.8596	1.0387	2.1794
24	.8413	.9431		.7964	.788		.9492
Max	3.7209	3.3482	3.7209	3.5056	3.0803	3.6694	3.4979
Min	.8413	.9214	.8954	.7964	.7628	1.0387	.9492
Avg	1.9680	1.7493	2.1752	2.0577	1.3638	2.0802	1.9453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 204 / 11 KV KODRI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961	.4607	.4961	.5014	.543	.567	.4908
2	.6024	.4607	.5316	.5373	.543	.6379	.5853
3	.6733	.4607	.6024	.6516	.543	.6733	.6089
4	.7087	.7011	.6733	.7087	.724	.7087	.7011
5					1.0136		
6					1.182		
7					1.1765		
8					1.1706		
9					.8764		
10					.7011		
11	1.8229	2.1719	2.0683	1.5074	1.3321	2.4013	
12	2.7808	2.6612	2.7092	2.6749	1.9204	2.4348	2.4691
13	1.1218	2.5882	2.5941	2.4691	2.2043	2.332	2.6406
14	2.6406	2.5606	2.5514	2.6406	2.3137	2.452	2.6113
15	2.8121	2.5339	2.516	2.6749	2.3739	2.1948	2.4539
16	2.6063	2.4356	2.4539	2.6452	2.2043	2.1735	2.2325
17	2.6578	2.5514	2.3282	2.5072	2.1605	2.2634	2.1384
18	2.4539	2.4539	2.2923	2.3282	2.2043	2.0919	1.7878
19	.8505	.7442	1.0745	1.1462	.9465	1.0631	1.949
20	.7087	.7087	1.0029	.9313	.8063	.8063	.8505
21	.5959	.6379	.6805	.7164	.6024	.691	.7087
22	.5316	.5258	.6447	.6154	.567	.6379	.6697
23	.4252	.4961	.5373	.5792	.5316	.567	.5373
24	.5068	.5228		.5014	.5316		.543
Max	2.8121	2.6612	2.7092	2.6749	2.3739	2.452	2.6406
Min	.4252	.4607	.4961	.5014	.5316	.567	.4908
Avg	1.3886	1.4264	1.5151	1.4631	1.2155	1.4527	1.4105

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 206 / 11 KV RAILWAY STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4252	.5121	.5068	.5228	.5601	.4961	.5359
2	.4607	.5121	.5316	.5228	.5975	.5316	.5544
3	.4908	.5121	.6024	.5228	.6348	.631	.5914
4	.6733	.5121	.7796	.5601	.7468	.815	.6283
5	.7712	.6878	.9465	.5601	.8962	.9922	.7865
6	.9816	1.1694	1.0631	.9335	1.1576	1.134	1.2071
7		1.4723	1.3672	1.4937	1.5684	1.4883	1.4815
8	1.3672	1.5684	1.4723	1.5684	1.531	1.5238	1.6461
9	1.4175	1.4563	1.4022	1.3321	1.387	1.4998	1.2971
10	1.2757	1.3443	1.2048	1.2403	1.262	1.267	1.1694
11	1.182	1.1203	1.1218	1.182	1.1568	1.2437	1.1694
12	1.0387	1.0456	1.0029	1.0631	1.0517	1.086	1.0631
13	.8954	.9149	.8859	.9313	.9922	.9511	.8238
14	.8238	.8962	.7796	.8238	.815	.9145	.8238
15	.8326	.8029	.7442	.8238	.8238	.8501	.815
16	.7602	.8589	.7087	.8596	.8954	.8596	.7796
17	.7362	.9214	1.1203	1.0456	.9922	.9877	
18	.7087	1.134	1.1949	1.1203	1.0985	1.1888	1.4842
19	.7442	1.134	1.1203	1.2323	1.1694	1.262	1.4449
20	.8505	1.0985	1.0082	1.1576	1.0745	1.0903	1.1157
21	.7602	.9214	.8962	1.0082	.8596	.9055	.9145
22	.6878	.8505	.7842	.7842	.6024	.8501	.7682
23	.6878	.5316	.6161	.6722	.5316	.6283	.6219
24	.4344	.5014		.5228	.5014		.543
Max	1.4175	1.5684	1.4723	1.5684	1.5684	1.5238	1.6461
Min	.4252	.5014	.5068	.5228	.5014	.4961	.5359
Avg	.8263	.9366	.9504	.9368	.9544	1.0085	.9680

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 207 / 11 kv Prasd Fiber

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1463	.1063	.1109	.1663	.1417	.1052
2	.1448	.1463	.1433	.1663	.1663	.1433	.1063
3	.1629	.1463	.1433	.1663	.1663	.1417	.1063
4	.1612	.1463	.1417	.1663	.1478	.1417	.1063
5	.1612	.1463	.1063	.1663	.0924	.1417	.1052
6	.1417	.1829	.1063	.1646	.1663	.1417	.1075
7		.1448	.1417	.1791	.1663	.1772	.1086
8	.0886	.1463	.1063	.1294	.1663	.1063	.0686
9	.0886	.1478	.0895	.1097	.1463	.1029	.1109
10	.1097	.0924	.0886	.1097	.1097	.1029	.1109
11	.1097	.0924	.0701	.0732	.0732	.1029	.1109
12	.1097	.0924	.0366	.1097	.1097	.1715	.1097
13	.1097	.0924	.0354	.1097	.1097	.1715	.1097
14	.1097	.0924	.0354	.1097	.1097	.1543	.1097
15	.1097	.0554	.0709	.0732	.1097	.1715	.1063
16	.1463	.0554	.0709	.0732	.1097	.0857	.1063
17	.1063	.0537	.1109	.1294	.0732	.0686	.1029
18	.1063	.0532	.1109	.1478	.0732	.1029	.1063
19	.1417	.1075	.1029	.1478	.0732	.1029	.0701
20	.1595	.1063	.1663	.1646	.0732	.1029	.1052
21	.1463	.1086	.1663	.1663	.1829	.1772	.1052
22	.1463	.1063	.1829	.0924	.1448	.1753	.1829
23	.1463	.1063	.1829	.0924	.1417	.104	.1646
24	.1463	.1052		.1109	.1494		.1063
Max	.1629	.1829	.1829	.1791	.1829	.1772	.1829
Min	.0886	.0532	.0354	.0732	.0732	.0686	.0686
Avg	.1303	.1114	.1094	.1279	.1261	.1318	.1097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204011 / 33 KV GANGKHED S/S

Feeder No / Name : 208 / 11KV Water works Express NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.037	.1448	.1463	.1478	.1448	.0343
2	.0181	.037	.0362	.1463	.1478	.1417	.0366
3	.0181	.037	.0362	.0185	.0185	.1063	.1063
4	.0362	.037	.0354	.0185	.0185	.1063	.0354
5	.0354	.0366	.0354	.0185	.0183	.1063	.0362
6	.0354	.1463	.1063	.1109	.1294	.1063	.0354
7		.1448	.1402	.1463	.1478	.1402	.1254
8	.0354	.1478	.0351	.1478	.1478	.4607	.1646
9	.0354	.1663	.0354	.5068	.4706	.4784	.4706
10	.0366	.1663	.1052	.4706	.4706	.1578	.4706
11	.0366	.1478	.1052	.1463	.1463	.1578	.1463
12	.0366	.1478	.1463	.1829	.1097	.1578	.1463
13	.0366	.1478	.1417	.1463	.1829	.1595	.1463
14	.1097	.1478	.1417	.1463	.1463	.1578	.1463
15	.1097	.1478	.1417	.1097	.1463	.1595	.1417
16	.1829	.1109	.1417	.1097	.1463	.1595	.1417
17	.1417	.1433	.1463	.1448	.037	.1753	.1578
18	.1417	.1417	.1463	.1478	.1097	.1578	.1227
19	.1417	.1417	.1478	.1478	.1463	.1595	.1595
20	.0354	.0354	.1433	.1463	.1463	.1595	.1578
21	.0366	.0354	.1478	.1478	.1463	.1595	.1595
22	.0366	.1063	.1463	.1478	.1417	.1595	.1595
23		.1448	.1629	.1448	.1417	.1595	.0351
24	.0351	.1227	.0354	.1848	.1448		.1543
Max	.1829	.1663	.1629	.5068	.4706	.4784	.4706
Min	.0181	.0354	.0351	.0185	.0183	.1063	.0343
Avg	.0613	.1116	.1085	.1577	.1504	.1753	.1454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204035 / 33 KV PIMPALDARI S/S

Feeder No / Name : 204 / 11 KV BORDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-JAN-17	25-JAN-17	26-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2738		.2993	.2806
2	.2738		.2993	.3184
3	.3125		.3765	.3757
4	.3715		.5087	.415
5	.5057		.5687	.5481
6	.7764		.778	
7			.816	
10			.2245	
11			.358	
12			2.2989	
13			.32	.3378
14		.3576		.3566
19		.8539		.8341
20		.6066		.6628
21		.4518		.5103
22		.3765		.4338
23		.2993		.3576
24	.2896		.2993	.2619
<b>Max</b>	<b>.7764</b>	<b>.8539</b>	<b>2.2989</b>	<b>.8341</b>
<b>Min</b>	<b>.2738</b>	<b>.2993</b>	<b>.2245</b>	<b>.2619</b>
<b>Avg</b>	<b>.4005</b>	<b>.4910</b>	<b>.5956</b>	<b>.4379</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204095 / 33 KV ISSAD S/S

Feeder No / Name : 201 / Issad

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.8505	.9149	.8802	1.0242	.9122	.8907
2	.8402	.9709	1.0608	.9995	1.258	1.0364	.9614
3	.9335	1.0802	1.1694	1.1568	1.379	1.1603	1.1191
4	1.0269	1.2548	1.2656	1.3032	1.56	1.3056	1.3523
5		1.3245	1.3998	1.4563	1.6118	1.4737	1.543
6		1.4922	1.5769	1.7177	1.7269	1.8724	1.8378
7		1.8724	1.97	2.3282	1.8299	2.1735	2.2085
8		2.1971	2.4356		2.0485	2.5591	2.4539
9		2.2436	2.3743		2.0965		2.5869
10		1.9244	2.1325	2.0508	2.0517	2.2885	2.5139
11	1.8519			1.8347	.6838		
12	1.9951				.5658		
13	1.8679				.5041		
14	1.6907				.499		
15	1.8442				.4572		
16	1.8564				.5304		
17	1.8107	.6653	.8871	.6838	.8048	.6838	1.0534
18	1.2407	1.0903	.9328	.9055	.961	.8501	1.0534
19	1.1317	1.3256	1.2567	.9335	1.2323	1.2136	1.2936
20	.9431	1.0751	.9335	.9149	.9242	.9242	1.0751
21	.7922	.7922	.7922	.8215	.811	.811	.8488
22	.679	.7167	.7167	.7922	.7733	.7167	.7733
23	.6413	.6413	.6602	.6979	.7356	.6602	.6979
24	.6036	.6036	.5658	.5847	.6413	.6979	.6224
Max	1.9951	2.2436	2.4356	2.3282	2.0965	2.5591	2.5869
Min	.6036	.6036	.5658	.5847	.4572	.6602	.6224
Avg	1.2460	1.2289	1.2803	1.1801	1.1129	1.2552	1.3825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204095 / 33 KV ISSAD S/S

Feeder No / Name : 202 / limbewadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.3144	.3612	.4481	.3763	.3462
2	.7754		.3506	.4012	.5175	.4012	.3593
3	.8573		.4161	.4374	.6099	.427	.3841
4	.9267		.5304	.5571	.695	.4696	.3978
5	.9976				.7316		
6	1.1888				.8048		
7	1.8278				.8501		
8	2.2045				.8048		
9	2.2969				.7377		
10	2.2447				.5506		
11					.6081		
12						1.5384	1.5203
13		2.4129	2.1765	2.4939	2.3967	2.2775	2.4453
14		2.3967	2.2996	2.7206	2.3205	2.5425	2.3045
15		2.4166	2.7526	2.3845	1.6762	2.4486	2.3365
16		2.5425	2.7692	2.6246	2.1125	2.251	2.3967
17	.4687	2.1125	1.9292	2.6558	2.0557	1.4043	2.3967
18	.4668	2.1862	2.1247	2.0873	1.9814	1.7985	2.0833
19	.7074	1.7833	1.7158	1.9216	1.7158	.9701	1.7008
20	.5716	1.5257	1.4718	1.8652	.5075	.4923	.4793
21	.4534	.4527	.439	.567	.4115	.4652	.4778
22	.3344	.4134	.3887	.4755	.3628	.3868	.3734
23		.3467	.3734	.4108	.3601	.3755	.3616
24	.4001		.3338	.3477	.4338	.3429	.3572
Max	2.2969	2.5425	2.7692	2.7206	2.3967	2.5425	2.4453
Min	.3344	.3467	.3144	.3477	.3601	.3429	.3462
Avg	1.024	1.6899	1.2741	1.3945	1.0301	1.1157	1.2189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204097 / 33 KV MIDC S/S GANGAKHED

Feeder No / Name : 201 / 11 KV NEW TOWN GANGAKHED SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5658	.6001	.5487	.6173	.6001
2	.5144	.5144	.5658	.6001	.5487	.6173	.6001
3	.5144	.5144	.5658	.6001	.5487	.6344	.6001
4	.3887	.5144	.6001	.8573	.9259	.6859	.6001
5	.9088	.6001	.9774	1.286	1.406	.9431	1.3717
6	1.4746	1.4575	1.4746	1.5775	2.1776	1.7147	1.8004
7	2.0233	1.8861	2.0062	1.8861	2.2634	2.1948	1.8861
8	1.9719	1.9719	2.3148	2.0233	2.2291	2.2805	1.9719
9	1.8861	1.8861	1.9376	1.8519	1.9719	2.0919	1.9719
10	1.8861	1.9204	1.6289	1.6461	1.7318	1.7661	1.6289
11	1.4575	1.5432	1.4575	1.4232	1.286	1.4575	1.3375
12	1.2003	1.2003	1.166	1.0974	1.1145	1.1145	1.0631
13	1.0288	.9602	.9088	.9088	.8916	.9431	.9431
14	.9431	.8402	.8573	.823	.8573	.8573	.7888
15	.8573	.823	.7888	.7888	.8573	.8573	.8059
16	.8573	.9259	.9088		1.1145	.8573	.9945
17	.9431	1.046	1.0802		1.1145	.9431	1.1488
18	1.2003	1.3032	1.286		1.3032	1.286	1.3546
19	1.286	1.4403	1.4575	1.7318	1.3717	1.3717	1.4918
20	1.1145	1.1488	1.2689	1.406	1.2003	1.2003	1.2174
21	1.0288	.9774	1.0288	1.1488	.9088	.9431	.9945
22	.7716	.823	.8402	.8059	.7888	.7716	.8745
23	.6001	.6687	.6859	.6859	.6516	.6859	.6859
24	.583	.5487	.6173	.6173	.6173	.6173	.6001
Max	2.0233	1.9719	2.3148	2.0233	2.2634	2.2805	1.9719
Min	.3887	.5144	.5658	.6001	.5487	.6173	.6001
Avg	1.0814	1.0845	1.1245	1.1603	1.1846	1.1438	1.1388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204097 / 33 KV MIDC S/S GANGAKHED

Feeder No / Name : 202 / 11 KV MARGALWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3772	.4287	.4458	.5658	.5144	.5144
2	.3944	.3772	.4287	.4458	.5658	.5144	.5144
3	.3944	.3772	.4287	.4458	.583	.5144	.5144
4	.3944	.3772	.4287	.4801	.6173	.5487	.5144
5	.3944	.4801	.4973	.5144	.6516	.5658	.6001
6	.5487	.5144	.5487	.6001	.7202	.6001	.6001
7	.6001	.6001	.6344	.7716	.7888	.6516	.6516
8	.6859	.6859	.7716	.8573	.8573	.7202	.6859
9	.6859	.6859	.823	.9088	.8402	.7373	.7716
10	.7373	.703	.7888	.8916	.823	.8059	.8573
11	.6859	.6687	.7888	.9088		.7716	1.0117
12	.6001	.7202	.7716	.823	.8573	.7716	.9945
13	.6001	.6173	.703	.9088	.6173	.8573	.9431
14	.6001	.6516	.7202	.9431	.6687	.8573	.8916
15	.6001	.6859	.8059	.9602	.703	.8573	.5658
16	.6001	.703	.8573	.9602	.7888	.8573	.7716
17	.6001	.7202	.8745	1.046	.8745	.8573	.8402
18	.6001	.7202	.8745	1.0117	.8916	.7716	.8059
19	.6001	.6687	.7545	.9774	.8745	.7716	.7716
20	.5144	.583	.703	.8916	.7716	.6859	
21	.5144	.5144	.5658	.7373	.6344	.6001	.6687
22	.4287	.4801	.4801	.6344	.6344	.6001	.5487
23	.4287	.463	.4458	.6001	.583	.5144	.5144
24	.4115	.3772	.4458	.4458	.583	.583	.5144
Max	.7373	.7202	.8745	1.046	.8916	.8573	1.0117
Min	.3944	.3772	.4287	.4458	.5658	.5144	.5144
Avg	.5423	.5730	.6487	.7587	.7172	.6887	.6985

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

GANGAKHED (R) S/DN[440] BU 2330

Substation No/ Name :- 204097 / 33 KV MIDC S/S GANGAKHED

Feeder No / Name : 203 / 11 KV MIDC FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	26-JAN-17
HR	Load (MW)
11	.8573
Max	.8573
Min	.8573
Avg	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204022 / 33/11 KV BORI S/STN

Feeder No / Name : 201 / Kausadi AG Feeder  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	24-JAN-17
HR	Load (MW)
18	.0206
Max	.0206
Min	.0206
Avg	.0206

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204022 / 33/11 KV BORI S/STN

Feeder No / Name : 202 / Muda-Bordi Mix feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	24-JAN-17
HR	Load (MW)
18	.4294
Max	.4294
Min	.4294
Avg	.4294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204022 / 33/11 KV BORI S/STN

Feeder No / Name : 204 / Bori Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	24-JAN-17
HR	Load (MW)
18	.9214
Max	.9214
Min	.9214
Avg	.9214



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204053 / 33 /11 KV JINTUR

Feeder No / Name : 201 / 11KV Nimgiri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-JAN-17	26-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0059		
2	1.0059		
3	1.0059		
4	1.0974		
5	1.4632		
6	2.0119		
7	2.7435		
8	2.652		
9	2.652	2.3777	2.3777
10		2.3777	
11		1.7375	1.6461
12		1.4632	1.6461
13		1.4632	1.7375
14		1.4632	1.7375
15		1.4632	1.6461
16		1.5546	1.6461
17			1.829
18			2.2862
19			1.829
20			1.4632
24	1.0974		
Max	2.7435	2.3777	2.3777
Min	1.0059	1.4632	1.4632
Avg	1.6735	1.7375	1.8040

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204053 / 33 /11 KV JINTUR

Feeder No / Name : 202 / 11KV Shevadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	23-JAN-17	26-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6516		
2	.6516		
3	.6516		
4	.6516		
5	.7202		
6	.8745		
7	1.0288		
8	1.0631		
9	1.0974	1.4746	.9602
10		1.4575	.8916
11		1.4575	.8573
12		1.2003	.9431
13		.9431	.9945
14		1.286	.9602
15		1.3717	.8059
16		1.4575	.8745
17			.8573
18			.823
19			.7545
20			.7545
24	.6859		
Max	1.0974	1.4746	.9945
Min	.6516	.9431	.7545
Avg	.8076	1.3310	.8731

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204053 / 33 /11 KV JINTUR

Feeder No / Name : 203 / 11 KV CHANDRAGIRI FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	23-JAN-17	26-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0943		
2	.0943		
3	.0943		
4	.0943		
5	.1132		
6	.1509		
7	.2263		
8	.2075		
9	.2075	.2263	.2263
10		.1886	.2075
11		.1886	.2075
12		.1698	.2075
13		.1698	.2075
14		.1886	.1509
15		.1886	.132
16		.1886	.1698
17			.1698
19			.1509
20			.132
24	.0943		
Max	.2263	.2263	.2263
Min	.0943	.1698	.132
Avg	.1377	.1886	.1783

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204053 / 33 /11 KV JINTUR

Feeder No / Name : 204 / Warud Mix Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	23-JAN-17	26-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2003		
2	1.2003		
3	1.2003		
4	1.2003		
5	1.2174		
6	1.3546		
7	1.6975		
8	2.0748		
9	1.3032	2.2119	2.0062
10		2.1434	2.2119
11		2.0919	2.2805
12		2.2291	
13		2.3663	2.572
14		2.2291	2.5034
15		2.2291	2.5892
16		2.1434	2.6578
17			2.2291
18			2.1434
19			1.8004
20			1.5432
24	1.2346		
Max	2.0748	2.3663	2.6578
Min	1.2003	2.0919	1.5432
Avg	1.3683	2.2055	2.2306

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204055 / 33/11 Kv Adgaon S/s.

Feeder No / Name : 201 / Adgaon feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.2003	1.2003		1.7147		1.286
2	.9431	1.3717	1.3717		2.0576		1.3717
3	.9431	1.5432	1.5089		2.1434		1.406
4	.9808	1.7147	1.9281		2.2291		1.4575
5		2.0576	2.0348		2.2291		1.7147
6		2.4006	2.5415		2.5377		2.4006
7		2.7092	3.0521		2.8502		2.7435
8		2.5377	3.2579		3.0178		3.4122
9		2.8292	3.5582	3.858	2.9492	3.858	2.4863
10		2.6235	2.8045	3.6008	2.4863	3.6008	2.8292
11	2.7092						
12	3.6351						
13	3.738						
15	3.0864						
16	2.9664						
17	2.6063	.9431		.9808		.905	.9431
18	2.4006	1.0374		1.0374		.9955	1.0374
19	1.0269	1.094		.9808		.9955	1.094
20	1.0269			1.0185		.9955	1.094
21	.9896	1.0082		.9808		.9955	1.0374
22	.9335	.9808		.9808			.9808
23	.9335	.9431		.9431		.905	.9431
24	.9431	.9335	.9431		.9431		.905
Max	3.738	2.8292	3.5582	3.858	3.0178	3.858	3.4122
Min	.9335	.9335	.9431	.9431	.9431	.905	.905
Avg	1.8121	1.6428	2.2001	1.5979	2.2871	1.6564	1.6190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204055 / 33/11 Kv Adgaon S/s.

Feeder No / Name : 202 / Takalkhopa feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.132	.1715		.1715		.1886
2	.2286	.12	.1715		.1715		.1886
3	.2286	.1509	.1905		.1905		.1886
4	.2286	.1886	.2667	.1886	.1905	.1886	.2263
5	.2286						
6	.2286						
7	.2286						
8	.2286						
11		.0934		1.2003		1.8004	
12		.0934		2.2466		2.2634	1.9919
13				2.2466		2.2977	2.0729
14		.8192		2.34		2.3148	2.13
15		1.1633		2.3148		2.3491	2.2119
16		1.9662		2.2291		2.3663	2.13
17	.0754	2.146		2.1434		2.4863	2.5652
18	.132	2.1125		2.1672		2.4863	2.2298
19		.3239		.1905		.3395	.3048
20		.2858		.1905		.2829	.2667
21	.1509	.2286		.1905		.2452	.2096
22	.1509	.1905		.1905			.1905
23	.132	.1905		.1905		.1886	.1905
24	.1905	.132	.1715		.1905		.1886
Max	.2286	2.146	.2667	2.34	.1905	2.4863	2.5652
Min	.0754	.0934	.1715	.1886	.1715	.1886	.1886
Avg	.1900	.6080	.1943	1.2878	.1829	1.5084	1.0279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204080 / 33 KV S/s Bhogaon

Feeder No / Name : 201 / 11kv LIMBALA FEEDER ( SINGLE PHASING  
 Single P Feeder KV- 11 /  
 OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.9431	.9149	1.1506	.9242	.7922	.8962
2	.679	1.5466	1.3443	1.4146	1.0562	.9431	.9522
3	.7545	1.773	1.4377	1.5655	1.1203	1.094	1.0642
4	.8488	1.8861	1.5123	1.5708	1.2323	1.226	1.1949
5		2.0748	1.6057	1.828	1.4377	1.2637	1.2136
6		2.2257	1.7364	2.4434	1.6617	1.8861	1.5123
7		2.32	2.6699	2.692	2.2361	2.0936	2.2405
8		2.6326	3.2674	2.7606	2.3777	2.6406	2.8753
9		2.7633	3.2487	2.8292	2.5503	2.9127	2.9687
10		2.3712	3.1602	2.3663	2.2218	2.5579	2.5579
11	2.5393						
12	3.2114						
13	3.0434						
14	2.8753						
15	2.838						
16	2.726						
17	2.4832				.8488	.6099	.7577
18	2.1472	.8871		.9431	.9054	.8316	.7947
19	.8299	1.1273	1.1883	1.0185	.9242	.924	.8488
20	.7167	.961	1.0374	.9619	.7922	1.0164	.8488
21	.7356	.9055	.8865	.9431	.811	.8686	.811
22	.7167	.7577	.7733	.7922	.7545	.7762	.811
23	.679	.7207	.6979	.7167	.7167	.7023	.8488
24	.6602	.6602	.7023	.6602	.6602	.679	.7947
Max	3.2114	2.7633	3.2674	2.8292	2.5503	2.9127	2.9687
Min	.6413	.6602	.6979	.6602	.6602	.6099	.7577
Avg	1.6181	1.5621	1.6365	1.5680	1.2906	1.3232	1.3329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204080 / 33 KV S/s Bhogaon

Feeder No / Name : 202 / 11KV PUNGALA FEEDER SINGLE PHASING  
 (single Ph Feeder KV- 11 /  
 OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.4715	.4805	.4715	.4904	.415	.4251
2	.8299	.5093	.5175	.547	.5281	.4904	.499
3	.9054	.6602	.6838	.7356	.6413	.7167	.7392
4	.9709	.9054	.8131	.8316	.8488	.8488	.7947
5	1.0269						
6	1.1576						
7	1.5684				1.0562		
8	2.0144				.7545		
9	2.0698				.811		
10	1.9791						
11		1.8298	1.6108	1.5402	1.3443	1.5684	1.2489
12		2.1472	1.5604	2.0683	1.4937	1.8484	1.6289
13		2.0911	1.5947	1.9163	1.6244	1.531	1.5947
14		2.0538		1.7013	1.4937	1.643	1.5604
15		1.9231	1.4918	1.4998	1.531	1.5497	1.5432
16		1.8484	1.8004	1.4998	1.5123	1.531	1.5432
17		1.7177	1.7661	1.3306		1.5123	1.4918
18		1.5684	1.6632	1.5364	1.475	1.5123	1.3032
19	.8488	.961	.9619	.7922	.8865	.8316	.8488
20	.7545	.8501	.9242	.8299	.6224	.7207	.7733
21	.7922	.6468	.8865	.7733	.5847	.5914	.6602
22	.5658	.5729	.5847	.5847	.5281	.5359	.5093
23	.5281	.5359	.5093	.4904	.4715	.4805	.4715
24	.4338	.4715	.499	.4338	1.4937	.415	.4251
Max	2.0698	2.1472	1.8004	2.0683	1.6244	1.8484	1.6289
Min	.4338	.4715	.4805	.4338	.4715	.415	.4251
Avg	1.0774	1.2091	1.0793	1.0879	1.0096	1.0412	1.0034



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 204080 / 33 KV S/s Bhogaon

Feeder No / Name : 203 / 11KV BHOGAON FEEDER SINGLE PHASING  
 (Single Ph Feeder KV- 11 /  
 OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.415	.4251	.4338	.3395	.3772	.3696
2	.3772	.4715	.4805	.4715	.3772	.415	.4066
3	.415	.5658	.5359	.5093	.4904	.5281	.6099
4	.4527	.6602	.5729	.6468	.6413	.7167	.6838
5	.547						
6	.6602						
7	1.0269				.8299		
8	1.0719				.7733		
9	1.1203				.6413		
10	1.1016						
11		.8775	.7783	.7468	.7095	.7095	.6697
12		.9149	.7716	.8215	.6722	.6722	.703
13		.8589	.7373	.8215	.6535	.6722	.6859
14		.8775		.7282	.6535	.6535	.6516
15		.8589	.6516	.6602	.6161	.5788	.6344
16		.8215	.6687	.7468	.6535	.5788	.6001
17		.7655	.6859	.7468		.6161	.583
18		.7468	.6859	.7655	.7468	.5228	.6335
19	.7167	.7023	.7733	.6413	.679	.6468	.6602
20	.5847	.5729	.7545	.5281	.5658	.5359	.6224
21	.5658	.462	.6979	.4715	.5281	.4066	.5093
22	.4715	.4066	.4338	.3961	.4904	.3881	.3584
23	.4527	.3696	.3961	.3772	.4527	.3326	.3206
24	.3395	.415	.3142	.3395	.6161	.3772	.3142
Max	1.1203	.9149	.7783	.8215	.8299	.7167	.703
Min	.3395	.3696	.3142	.3395	.3395	.3326	.3142
Avg	.6414	.6535	.6096	.6029	.6065	.5405	.5565

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 207010 / 33/11 Kv MIDC Jintur S/s.

Feeder No / Name : 201 / 11 Kv Industrial Feeder SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	28-JAN-17
HR	Load (MW)
14	.8596
23	.4024
Max	.8596
Min	.4024
Avg	.631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 207010 / 33/11 Kv MIDC Jintur S/s.

Feeder No / Name : 202 / 11 Kv Paghari Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	28-JAN-17
HR	Load (MW)
14	.567
23	.3292
Max	.567
Min	.3292
Avg	.4481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

JINTUR (R) S/DN[452] BU 2372

Substation No/ Name :- 207010 / 33/11 Kv MIDC Jintur S/s.

Feeder No / Name : 203 / Town -Shivaji nagar

SHEDDABLE URBAN

Feeder Feeder KV- 11 /  
OUTGOING

DATE	28-JAN-17
HR	Load (MW)
14	.7865
23	.6219
Max	.7865
Min	.6219
Avg	.7042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 201 / MANWAT TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859		.7164
3			.724	
4		.6859	.8688	
5			.905	
6		1.3717	1.086	
7			1.448	1.448
8			1.6289	
12			1.166	
13				7.7675
15			.6859	
16				7.7675
17	.7973			
19			1.2003	
23			.8573	
24			.724	
Max	.7973	1.3717	1.6289	7.7675
Min	.7973	.6859	.6859	.7164
Avg	.7973	.9145	1.0267	4.4249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 202 / Ambegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			1.0059
7			1.6766
17	2.2862	.8688	
23		.6706	
Max	2.2862	.8688	1.6766
Min	2.2862	.6706	1.0059
Avg	2.2862	.7697	1.3413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 203 / Ratnapur

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3413		1.3413
2		1.2803		
3		1.3108		
4		1.2955		1.3717
16			2.2291	
17	1.8442			
20			1.6956	
23			1.3717	
24		1.2955		
Max	1.8442	1.3413	2.2291	1.3717
Min	1.8442	1.2803	1.3717	1.3413
Avg	1.8442	1.3047	1.7655	1.3565

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 204 / Manoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		5.2934	1.0517
4		.5258	
7			1.6766
8		.8764	
17	2.1338		
18		.5144	
23		.6859	
Max	2.1338	5.2934	1.6766
Min	2.1338	.5144	1.0517
Avg	2.1338	1.5792	1.3642



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 205 / Katruwar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0857
7			.1029
12		.0876	
16		.1402	
17	.1143		
23		.1052	
Max	.1143	.1402	.1029
Min	.1143	.0876	.0857
Avg	.1143	.111	.0943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 206 / Sant Bhagatram  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0895	.12
2		.0895	
4		.0895	
6		.1791	
7			.1372
8		.1791	
9		.3761	
11		.3429	
17	.2401		
18		.3429	
23		.1753	
Max	.2401	.3761	.1372
Min	.2401	.0895	.12
Avg	.2401	.2071	.1286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 207 / Bhagwati

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		.1052
2	.0934	
6	.1867	
7		.0526
8	.3361	
12	.7362	
18	.7011	
23	.1753	
Max	.7362	.1052
Min	.0934	.0526
Avg	.3715	.0789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

MANWAT SUB-DIVISION[801] BU 4801

Substation No/ Name :- 204009 / 33 KV Sub. Manwath

Feeder No / Name : 208 / Town-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.4287
7			1.0288
12		.5258	
16		.4382	
17	.6135		
23		.5144	
Max	.6135	.5258	1.0288
Min	.6135	.4382	.4287
Avg	.6135	.4928	.7288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204024 / 33KV BANWAS

Feeder No / Name : 201 / 11KV BANWAS

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.4001	.2667	.1905	.1905	.1905	.2667
2	.2096	.4954	.2667	.1905	.2286	.2286	.2667
3	.1905	.6478	.2858	.2286	.2667	.2667	.2858
4		.743	.2858	.2286	.381	.3239	.3429
5			.381	.381	.4763	.5144	.4572
6		.9145	.5335	.4763	.743	.6859	.6097
7		.9717	.7621	.6287	.8002	.9145	.9335
8		1.0098	1.0479	.8573	1.0098	1.1622	1.1431
9		.9907	.8573	.9526	.9526	1.086	1.0669
10	.362				.4001		
11	.5525				.2286		
12	.5335				.2096		
13	.5716				.2096		
14	.4954				.1905		
15	.5144				.1905		
16	.5906	.2286		.3048	.2096		.1905
17		.3048		.3048	.1905	.362	.381
18		.381	.4382	.4572	.381	.381	.4382
19		.5144	.5335	.6097	.5144	.5144	.4954
20		.4191	.4191	.4954	.6668	.4572	.2477
21	.4572	.3429	.3239	.4001	.5144	.3239	.4763
22	.3429	.3048	.3048	.3429	.2477	.2858	.381
23	.2667	.2667	.2477	.2667	.2286	.2286	.2667
24	.2096	.3239	.2667	.1905	.1905	.2096	.2477
Max	.5906	1.0098	1.0479	.9526	1.0098	1.1622	1.1431
Min	.1905	.2286	.2477	.1905	.1905	.1905	.1905
Avg	.3919	.5447	.4513	.4170	.4009	.4785	.4721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204024 / 33KV BANWAS

Feeder No / Name : 202 / 11KV TANDULWADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.2667	.1715	.1715		.1524	.2286
2	.7811	.3048	.1715	.1715	.1905	.1715	.2667
3	.8573	.2286	.2286	.2286	.1905	.1715	.2858
4					.2096		
5	1.0288				.2286		
6	1.2384				.2667		
7	1.2574				.2858		
8	1.2955				.3048		
9	1.2193				.2477		
10		.2858		.5335	.6668	.4191	.4572
11		.9717		.743	.8954	1.0098	
12		1.0098		.9717	1.0098	1.1431	.9526
13		1.0288		.9907	.9526	1.086	.9907
14		1.0288	1.0669		.9717	.9907	.9526
15			1.0288	1.0669	.8383	.9526	.9717
16	.1334	.7621		1.0479	.9717	.8002	.9526
17	.2667	.9526		1.0669	.9526	1.0098	.9717
18	.362	.2477	.2286	.2286	.1524	.1905	.1905
19	.4382	.381	.4001		.2667	.2477	.2286
20	.4763	.3239	.362	.2096	.2286	.2096	.2477
21	.4763	.2667	.2667	.2096	.2096	.1524	.2096
22	.2667	.2096	.2477	.1905	.1905	.1334	.1905
23	.2286	.1905	.2096	.1715	.1905	.1524	.1905
24	.4763	.2096	.1905	.3048	.1715	.1715	.1715
Max	1.2955	1.0288	1.0669	1.0669	1.0098	1.1431	.9907
Min	.1334	.1905	.1715	.1715	.1524	.1334	.1715
Avg	.6713	.5099	.3810	.5192	.4606	.5091	.4976

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204024 / 33KV BANWAS

Feeder No / Name : 203 / 11KV CHORWAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.4001	.4191	.4763	.4382	.5144	.6097
2	1.0669	.4191	.4191	.4763	.4763	.6097	.6478
3	1.1622		.5335	.4763	.5335	.6287	.6859
4	1.5242			.5716	.6668		
5	1.6004			.6097	.8002		
6	1.7147			.6668	.9907		
7	2.21				1.0098		
8	2.2862				1.0098		
9	2.1148				.9145		
10		.5716	.9526	.7811	.9335	.6097	.743
11		1.5432	1.7147	1.7147	1.5051	1.4098	
12		1.9814	1.7528	1.7337	1.5432	1.8099	1.7147
13		1.9814	1.5623	1.6766	1.4861	1.7528	1.7909
14		1.9624		1.6004	1.448	1.6956	1.7718
15			1.5813	1.5623	1.2765	1.3717	1.7147
16	.4763	1.1812		1.6194	1.3336	1.2193	1.5242
17	.6478	1.9052			1.3717	1.5813	1.4289
18	.724	.743	.6097	.5906	.6478	.6668	.5716
19	.5335	.8764	.8954	.9335	.8002	.9907	.724
20	.7811	.7621	.7621	.7811	.7621	.7621	.7621
21	.6859	.6668	.6287		.6287	.6287	.6859
22	.6097	.5716	.6287	.5716	.6097	.5906	.6287
23	.4572	.4763	.5716	.5716	.5525	.2286	.4763
24	.7049	.4382	.4763	.4763	.4001	.4191	.5144
Max	2.2862	1.9814	1.7528	1.7337	1.5432	1.8099	1.7909
Min	.4572	.4001	.4191	.4763	.4001	.2286	.4763
Avg	1.1146	1.03	.9005	.9416	.9224	.9716	.9997

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204077 / 33KV PETHSHIVANI

Feeder No / Name : 201 / 11KV PETHSHIVANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	26-JAN-17
HR	Load (MW)
11	.8573
12	.743
Max	.8573
Min	.743
Avg	.8002



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204077 / 33KV PETHSHIVANI

Feeder No / Name : 202 / 11KV PARWA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	26-JAN-17
HR	Load (MW)
11	.1905
12	.2286
Max	.2286
Min	.1905
Avg	.2096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

PALAM SUB-DIVISION[800] BU 4800

Substation No/ Name :- 204077 / 33KV PETHSHIVANI

Feeder No / Name : 203 / 11KV GODAVARI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	26-JAN-17
HR	Load (MW)
11	2.4768
12	2.8578
Max	2.8578
Min	2.4768
Avg	2.6673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 202 / 11KV Town-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0309		
9	.0274	.0257	.6859	
10			.4801	
11			.5487	
12			.5487	
13	.0189			
14	.0171		.4801	
15	.0171		.4801	
16	.0154			
17	.0171			.0137
18				.0154
19				.0189
20				.0171
21				.0154
22				.0154
Max	.0274	.0309	.6859	.0189
Min	.0154	.0257	.4801	.0137
Avg	.0188	.0283	.5373	.0160

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 203 / 11KV Rajwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0429	.0514	2.2634	
10	.0377	.0514	2.2634	
11		.0514	2.0576	
17				.0086
18				.0103
19				.0154
20				.0137
21				.0137
22				.012
Max	.0429	.0514	2.2634	.0154
Min	.0377	.0514	2.0576	.0086
Avg	.0403	.0514	2.1948	.0123

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 204 / 11Kv Waki  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	22-JAN-17	23-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.0291	
11	.0457		
12	.0442		
13	.0412		
14	.048		
15	.0463		
16	.0257		
19			.0171
20			.0137
21			.0154
22			.0137
Max	.048	.0291	.0171
Min	.0257	.0291	.0137
Avg	.0419	.0291	.0150

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 205 / 11KV Moregaon (KHUPSA)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
10	.0381		
11		.012	
17			.0549
18			.0566
19			.0189
20			.0171
21			.0171
22			.0154
Max	.0381	.012	.0566
Min	.0381	.012	.0154
Avg	.0381	.012	.03

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 206 / 11 KV Industrial -I  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JAN-17	23-JAN-17	24-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0206		
9	.0198	.0171	.823	
10	.0206	.0206	.823	
11	.0206	.0206	.7545	
12	.0183		.8916	
13	.0183			
14	.0198		.9602	
15	.0223		.9602	
16	.0223			
17	.0198			.0189
18				.0189
19				.0189
20				.0152
21				.0137
22				.0137
Max	.0223	.0206	.9602	.0189
Min	.0183	.0171	.7545	.0137
Avg	.0202	.0197	.8688	.0166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204008 / 33 KV SAILU

Feeder No / Name : 208 / 11 KV Industrial -II  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JAN-17	23-JAN-17	24-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0206		
9	.0343	.0274	1.5089	
10	.0343	.0291	1.5089	
11	.0309	.0259	1.0974	
12	.0326		1.5775	
13	.0274			
14	.0274		1.5089	
15	.0257		1.5089	
16	.0257			
17	.0257			.0309
18				.0309
19				.0291
20				.0223
21				.0183
22				.0183
Max	.0343	.0291	1.5775	.0309
Min	.0257	.0206	1.0974	.0183
Avg	.0293	.0258	1.4518	.0250



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 201 / 11KV WALUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1578			.3201	.3277
2		.1623			.3201	.3201
3		.1715			.3201	.3201
4		.1715			.3201	.3201
5		.1783				.3163
6						.3163
7						.3906
8						.3906
11	.7865					
12	.6722					
13	.8124	1.4251	1.3757	1.0669		
14	.8223	1.4899	1.2289	1.2193	.9374	
15	.8539	1.3603	1.3272	1.2193	.9374	
16	.679	1.2963	1.326	1.0669	.9686	
17	.5719	1.3283			.9831	
18	.4108	1.2176			.8848	
19		.9686			.8192	
20	.216	.884			.8192	
23	.144	.2782			.3048	
24		.1578			.9831	.3201
Max	.8539	1.4899	1.3757	1.2193	.9831	.3906
Min	.144	.1578	1.2289	1.0669	.3048	.3163
Avg	.5969	.7498	1.3145	1.1431	.686	.3358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 202 / 11KV HATNUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4252	.5578				.4973
2	.4134	.5346				.4973
3	.4134	.5114				.442
4	.4134	.4801				.442
5	.3658	.4649				.442
6	.5304					.5304
7	.6409					.5525
8	.5967					.5746
10			.7183	.7727		
11	.8905		.7956	.9214		
12	.9724	.7735	.884	1.1888		
13	.8318		.884	1.1888		
14	.873	.9061	.8619	1.1145	.8398	
15	.7735	.9061	.8288	1.0402	.8398	
16	.5304	.9061	.8288	1.0402	.7735	
17	.5944	.8067			.7514	
23	.5906	.6142			.4801	
24	.4561	.5906				.5058
Max	.9724	.9061	.884	1.1888	.8398	.5746
Min	.3658	.4649	.7183	.7727	.4801	.442
Avg	.6066	.6710	.8288	1.0381	.7369	.4982

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 203 / 11KV WALUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228					.5601
2	.5041					.5601
3	.5041					.5601
4	.6535					.5601
5	.8962					.8131
9				.7783		
10	1.0456		.924	.6335		
11	.8686		.7842	.5792		
12	.6722	1.0164	.7468	.5792		
13		.7023		.543		
14				.543		
15				.543		
16				.543		
17	.8688	.9328			.7682	
18	.905	.9774			.9145	
19	.924	.9694			.9877	
20	.7762	.924			.961	
21	.6653	.7499			.7392	
22	.6099	.6653			.6468	
23	.5415	.5228			.5544	
24	.5228					.5544
Max	1.0456	1.0164	.924	.7783	.9877	.8131
Min	.5041	.5228	.7468	.543	.5544	.5544
Avg	.7175	.8289	.8183	.5928	.7960	.6013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 204 / 11KV HATNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	.4207				.462
2	.3658	.3982				.4477
3	.3658	.3841				.462
4	.4755	.4706				.4572
5	.5853	.6154				.5487
9				.5434		
10			.4382	.5258		
11	.6733		.4382	.4382		
12	.6401	.6379	.4382			
14				.5258		
15				.6135		
16		.5609		.7011		
17	.6661	.7362			.4607	
18	.7087	.6859			.5609	
19	.631	.7164			.7011	
20	.5609	.6089			.7522	
21	.5014	.5144			.5487	
22	.4908	.4508			.5487	
23	.4298	.3898			.4572	
24	.3761	.4119				.4572
Max	.7087	.7362	.4382	.7011	.7522	.5487
Min	.3658	.3841	.4382	.4382	.4572	.4477
Avg	.5236	.5335	.4382	.5580	.5756	.4725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 205 / 11KV TIRUPATI EXPRESS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-JAN-17	23-JAN-17	25-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029			.0533
2	.104	.1029			.0541
3	.1052				.0541
4	.1063	.081			.0533
5	.1086	.0926			.0533
6	.1086				.0526
7	.1063				.0526
8	.0914				.0229
9	.104		.0061		
14				.0617	
15				.0762	
16				.0762	
17		.116		.0657	
18		.096		.0789	
19		.0983		.0777	
20		.0983		.0541	
21	.0297	.1214		.0533	
22	.0983	.1052		.0533	
23	.0867	.1052		.0533	
24	.1029	.104			.0533
Max	.1086	.1214	.0061	.0789	.0541
Min	.0297	.081	.0061	.0533	.0229
Avg	.0965	.1020	.0061	.0650	.0499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204046 / 33KV WALOOR

Feeder No / Name : 206 / 11KV RAWA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.5213				.759
2	.5792	.5335				.759
3	.571	.5201				.703
4	.5937	.5647				.703
5	.6249	.6706				.6944
6	.7042					.6859
7	.8002					.7621
8	.7042					.823
9	.9922		.8002	1.2003		
10	1.2163		.8097	.9602		
11	1.4419		.8097	.8916		
12	1.0486	.6478	.8192	.9602		
13	.9995	.852	.8097	.9431		
14	1.278	.6882	.8259	.9431	.7811	
15	1.278	.7499	.8583	.9431	.7811	
16	.9998	.9069	.8002	.9431	.7907	
19	.2629	.333			.2705	
20	.2629	.2881			.2705	
21	.2362	.2481			.2667	
22	.2126	.2553			.2667	
23	.5144	.724			.7716	
24	.5792	.5001				.7907
Max	1.4419	.9069	.8583	1.2003	.7907	.823
Min	.2126	.2481	.8002	.8916	.2667	.6859
Avg	.7491	.5627	.8166	.9731	.5249	.7422

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204048 / CHIKHALTHAN

Feeder No / Name : 201 / 11KV CHIKALTHANA BK

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7122	.381			.4435	.4066	.4252
2	.7956	.4191			.4572	.3921	.4298
3	.8478	.5335			.5041	.4294	.5144
4	.8886	.6287			.5658	.5906	.5895
5	1.1934				.724		
6	1.3565				.7621		
7	1.5775				.8002		
8	1.9765				.6668		
9	2.3137				.5375		
10	2.1439				.4001		
11			.6283	2.2862		1.7909	1.6385
12		2.3624		2.3624	1.9839	2.1719	2.0957
13		2.4446		2.3815	1.419	2.1719	2.21
14		2.1879		2.0576	1.7436	2.0767	1.8671
15		1.9784		1.9814	1.8313	1.9052	1.8099
16		2.0719		1.9433	1.8004	1.8671	1.848
17	.724	1.9839		1.7661	1.595	1.7604	1.6263
18	.9145			1.5777	1.3125	1.5074	1.3565
19	.8573			.5544		.8316	.7762
20	.8002			.6805	.5493	.7023	.7095
21	.7621			.5434	.5258	.6219	.5359
22	.6478			.5249	.5304	.5121	.443
23	.5716			.4344	.4525	.5194	.3641
24	.4733	.4954			.3982	.439	.4854
Max	2.3137	2.4446	.6283	2.3815	1.9839	2.1719	2.21
Min	.4733	.381	.6283	.4344	.3982	.3921	.3641
Avg	1.0865	1.4079	.6283	1.4688	.9092	1.1498	1.0958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204048 / CHIKHALTHAN

Feeder No / Name : 202 / 11KV MOREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.25	.3239			.2812	.3277	.373
2	.2753	.381			.3048	.3647	.3814
3	.3041	.5335			.3281	.421	.4115
4	.4527	.724			.4111	.6882	.4748
5		.7621			.5155	.759	.5487
6		.381			.7811	.759	.6316
7					.8697	.9156	.7125
8					1.1265	1.142	1.0513
9				1.4289	1.4243		1.2384
10			.9779	1.3336	.9014	1.3527	1.0098
11	.9555				.1981		
12	1.2431				.2315		
13	1.2384				.1219		
14	1.1812						
15	1.1431				.1829		
16	1.2765				.181		
17		.2774		.2572	.1915	.3481	.3517
18	.9907			.5335	.2667	.3652	.4214
19	.6478			.4755		.5596	.4858
20	.5525			.5765	.285	.4694	.4752
21	.4954			.4607	.2543	.3681	.4144
22	.4001			.3658	.1898	.3605	.3605
23	.381			.2896	.192	.3239	.3163
24	.25	.362			.3086	.1943	.3391
Max	1.2765	.7621	.9779	1.4289	1.4243	1.3527	1.2384
Min	.25	.2774	.9779	.2572	.1219	.1943	.3163
Avg	.7081	.4681	.9779	.6357	.4340	.5717	.5554



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204048 / CHIKHALTHAN

Feeder No / Name : 203 / 11KV JAWALA J

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143			.1143	.1143	.1097
2	.1143	.1524			.1143	.1143	.1075
3	.1334	.1905			.1334	.1334	.1254
4	.2096	.2096			.1715	.1524	.1267
5		.2286			.2096	.2286	.2481
6		.1143			.3429	.2667	.3734
7					.4191	.381	.4572
8					.5525	.6468	.6219
9				.7049	.5316		.724
10			.5853	.5335	.4344	.5335	.4954
11	.3467				.1143		
12	.5083				.1334		
13	.381				.1715		
14	.4382				.1334		
15	.3429				.0953		
16	.4191				.1715		
17	.362	.381		.2286	.1905	.2149	.2477
18	.2286			.2286	.2477	.2477	.2858
19	.1524			.2286		.2286	.2286
20	.1524			.1715	.1715	.1905	.1715
21	.1524			.1334	.1524	.1715	.1524
22	.1334			.1143	.1143	.1143	.1143
23	.1334			.1143	.1143	.1143	.1143
24	.1143	.1143			.1143	.1143	.1143
Max	.5083	.381	.5853	.7049	.5525	.6468	.724
Min	.1143	.1143	.5853	.1143	.0953	.1143	.1075
Avg	.2465	.1881	.5853	.2731	.2151	.2334	.2677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204049 / 33KV NANDGAON

Feeder No / Name : 201 / 11WAGHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.1029	.1494	.112	.112
2	.4207	.1372	.1494	.112	.112
3	.3658	.1715	.168	.1307	.112
4	.3292	.1715	.1867	.168	.1307
5	.3292				.1307
6	.2743				.1307
7	.2743				.1494
8	.5853				.1494
9	.5853				.1494
10	.5144				.1307
11		.823	1.0059	.9511	
12		.7316	1.2986	1.1523	
13		1.3169	1.2437	1.1523	
14		1.3717	1.2803	1.0974	
15		1.1888	.9694	.9145	
16		1.0974	.9145	.823	
17	.1715	1.0974	.9511	1.0059	
18	.1715	.9877	.823	.9511	
19	.1372				
22	.1372	.168	.1307	.1307	
23	.1372	.168	.1307	.1307	
24	.1494	.1029	.168	.1307	.1307
Max	.5853	1.3717	1.2986	1.1523	.1494
Min	.1372	.1029	.1307	.112	.112
Avg	.3051	.6424	.6380	.5975	.1307

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204049 / 33KV NANDGAON

Feeder No / Name : 202 / 11 GANESHPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.12	.168	.1867	.168
2	.5121	.12	.168	.1867	.168
3	.5487	.1372	.1867	.2241	.168
4	.5853	.1715	.2054	.2241	.1867
5	.6401		.2614	.2614	.1867
6					.1867
7					.1867
8					.1494
9	.3658	.6535	1.1523	1.0829	.8402
10	.3086	1.0269	1.1888	.7682	.8402
11	.1886	.7499	.8779	.7499	
15		.823	.823	.7499	
16			.4572	.5853	
17			.5487	.6401	
18			.4572	.5853	
19	.2229	.7316	.6401	.7842	
20	.2401	.6348	.2054	.2422	
21	.1886	.6161	.2054	.1867	
22	.1715	.1867	.2054	.1867	
23	.1715	.1867	.2054	.1867	
24	.5121	.12	.168	.1867	.1867
Max	.6401	1.0269	1.1888	1.0829	.8402
Min	.1715	.12	.168	.1867	.1494
Avg	.3691	.4484	.4514	.4454	.2970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204049 / 33KV NANDGAON

Feeder No / Name : 203 / 11 KV DEVGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366			
2	.0366			
3	.0366			
4	.0549			
5	.0549			
6	.0732			
7	.0732			
8	.1097			
9	.128			
10	.1029			
11		.1097	.1463	.1463
12		.2012	.2195	.2561
13		.1829	.2012	.2195
14		.1829	.2195	.1829
15		.1646	.1829	.2195
16		.2012	.2195	.1646
17		.2012	.1829	.1829
18		.1463	.1829	.1646
Max	.128	.2012	.2195	.2561
Min	.0366	.1097	.1463	.1463
Avg	.0707	.1738	.1943	.1921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204049 / 33KV NANDGAON

Feeder No / Name : 204 / 11 KV SUPRIYA COTEX EXP. SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / INCOMING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0171	.0373	.0373	.0373
2	.0373	.0171	.0373	.0373	.0373
3		.0171	.0373	.0373	.0373
4	.0373	.0171	.0373	.0373	.0373
5	.0362	.0171	.0373	.0373	.0373
6	.0373	.0171	.0373	.0373	.0373
7	.0373	.0171	.0373	.0373	.0373
8	.0373	.0171	.0373	.0373	.0373
9	.1307	.0857	.0934	.1307	.1307
10	.12	.128	.0934	.1307	.1307
11	.1029	.1097		.1307	
12	.1029	.128	.0914	.1307	
13	.1029		.0914	.128	
14	.0857	.128	.0914	.112	
15	.1029	.1097	.0914	.0934	
16	.0857	.128	.0914	.0934	
17	.0857	.128	.0914	.112	
18	.0857	.1463	.0914	.112	
19	.0171	.0366	.0914	.112	
20	.0171	.0373	.0914	.1307	
21	.0171	.0373	.0934	.0373	
22		.0377	.0373	.0373	
23		.0373	.0373	.0373	
24	.0373	.0171	.0373	.0373	.0373
Max	.1307	.1463	.0934	.1307	.1307
Min	.0171	.0171	.0373	.0373	.0373
Avg	.0645	.0622	.0658	.0777	.0543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 204086 / 33/11 KV MIDC SUB-STATION

Feeder No / Name : 203 / 11KV MIDC EXPRESS FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JAN-17
HR	Load (MW)
3	.0377
5	.0358
7	.0396
9	.0472
10	.0448
11	.0453
12	.0453
13	.0472
14	.0472
24	.0373
Max	.0472
Min	.0358
Avg	.0427

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SAILU (R) S/DN[441] BU 2356

Substation No/ Name :- 207009 / 132 KV PATHRI

Feeder No / Name : 401 / 33 KV SAILU

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-JAN-17	23-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.0137	
9	.0206	.0154	
10	.0154	.0103	
11	.0154	.0103	
12	.0137		
13	.0206		
14	.0206		
15	.0183		
16	.0154		
17			.0154
18			.0154
19			.0206
20			.0154
21			.0154
22			.0154
Max	.0206	.0154	.0206
Min	.0137	.0103	.0154
Avg	.0175	.0124	.0163

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204041 / 33 KV KHADKA S/S

Feeder No / Name : 202 / 11 KV KANHEGAON MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)
1		.6001
2		.5144
3		.5144
4		.463
5		.463
6		.4973
15	2.3834	
16	2.3148	
17	2.1948	
18	2.0748	
19	1.9376	
20	1.6632	
21	1.5604	
22	1.4918	
23	1.4575	
24		1.3375
Max	2.3834	1.3375
Min	1.4575	.463
Avg	1.8976	.6271



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204041 / 33 KV KHADKA S/S

Feeder No / Name : 203 / 11 KV SAYKHEDA AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)
1		.0686
2		.0514
3		.0514
4		.0514
5		.0343
6		.0686
7		.8059
8		.9602
9		1.0974
10		1.046
11	1.2517	
12	1.3375	
13	1.2517	
16	1.1831	
21	.0857	
22	.0857	
23	.0857	
24		.0857
Max	1.3375	1.0974
Min	.0857	.0343
Avg	.7544	.3928

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204041 / 33 KV KHADKA S/S

Feeder No / Name : 204 / 11 KV KHADKA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)
1		.2572
2		.2572
3		.3086
4		.3086
5		.3429
6		.3944
7		1.3375
8		1.5604
9		1.4575
10		1.7318
11	1.8861	
12	1.9719	
13	2.0062	
14	1.8519	
21	.3944	
22	.3944	
23	.3772	
24		.3429
Max	2.0062	1.7318
Min	.3772	.2572
Avg	1.2689	.7545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204041 / 33 KV KHADKA S/S

Feeder No / Name : 206 / 11 KV SAYKHEDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)
1		.463
2		.5144
3		.6173
4		.6687
5		.8059
6		.9602
7		1.1145
8		1.2003
9		1.1145
10		.7888
11	.6859	
12	.6516	
13	.4287	
14	.5487	
15	.6859	
16	.703	
17	.7373	
18	.8573	
19	.9774	
20	.6516	
21	.5658	
22	.5144	
23	.463	
24		.4115
Max	.9774	1.2003
Min	.4287	.4115
Avg	.6516	.7872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 201 / 11 KV SONPETH TOWN-I  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	25-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
8	.788	.7468
16		.4382
24		.3584
Max	.788	.7468
Min	.788	.3584
Avg	.788	.5145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 203 / 11 KV LASINA-I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
8	.5975	1.1203
24		.1905
Max	.5975	1.1203
Min	.5975	.1905
Avg	.5975	.6554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 204 / 11 KV SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
16	1.587	1.4022
24		.2858
Max	1.587	1.4022
Min	1.587	.2858
Avg	1.587	.844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 205 / 11 KV SONPETH TOWN-II  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	25-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
8	1.2323		1.1203
16		.5658	.4656
24			.415
Max	1.2323	.5658	1.1203
Min	1.2323	.5658	.415
Avg	1.2323	.5658	.6670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 206 / 11 KV LASINA-II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
8	.9335	1.587
24		.2829
Max	.9335	1.587
Min	.9335	.2829
Avg	.9335	.9350



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - II[232]

SONPETH SUB-DIVISION[799] BU 4799

Substation No/ Name :- 204042 / 33 KV SONPETH S/S

Feeder No / Name : 207 / 11 KVKAUDGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
8	1.307	1.386
24		.1886
Max	1.307	1.386
Min	1.307	.1886
Avg	1.307	.7873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204002 / 33KV POKHARANI

Feeder No / Name : 201 / 11 KV Singanapur AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.0924	.1715	.1791	.0857		.108
2	.7125	.0914	.1715	.1829	.0857		.128
3	.7649	.0914	.1715	.1829	.0857		.128
4	.7649	.0924	.1715		.0857		.128
5	.7649			.1829			
6	.8916						
7	1.6518						
8	1.8204						
9	2.0157						
10	1.8267						
11		1.8861		1.3717	1.2136	1.4175	1.4175
12		2.2291	2.2786	1.6289	1.949	1.5604	2.1491
13		2.572	2.1672	1.8861	2.0595	2.3405	2.3529
14		2.1434	2.4539	2.3148	2.1491	2.3663	2.4434
15			2.3663	2.3148		2.2786	2.3663
16		2.4006	2.4539	2.3148	2.2148	2.3282	2.4539
17		2.3148	2.2786	2.4006	2.2386	2.3034	1.949
18		1.9719	.3506	2.4006	1.8604	1.8604	1.949
19	.1402	.1715	.1991	.1715			
20	.2126	.1715	.1629	.1715		.1417	.12
21	.1772	.1715	.1387	.1372		.1417	.1387
22	.1791	.1715	.1387	.12		.1265	.1214
23	.1372	.1372	.1402	.1029		.1296	.1063
24	.1372	.1294	.1715	.1715	.1029		.108
Max	2.0157	2.572	2.4539	2.4006	2.2386	2.3663	2.4539
Min	.1372	.0914	.1387	.1029	.0857	.1265	.1063
Avg	.8016	.9905	.9404	1.0130	1.1776	1.4162	1.0687

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204002 / 33KV POKHARANI

Feeder No / Name : 202 / 11KV POKHARNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.7545	.7545	.6535	.5601	.5601	.7392
2	.0566	.8316	.8488	.8402	.7468	.6468	.7392
3	.0566	.8316	.9431	.8402	.7468	.6468	.7392
4	.5658	.9335	.9431	.8402	.7468	.8402	.7468
5		1.1317	.9431	.8402	.7468	.9335	.8402
6		1.1317	1.0374	1.0269	.9335	1.0164	.9335
7		1.1765	1.5089	1.4937	1.307	1.4937	1.5089
8		1.2936		1.8671	1.6804	1.9605	1.6975
9		1.7737	1.9805	2.1472	.7468	1.8671	1.6804
10		1.6804	1.8861	2.2405		1.8671	1.6975
11	.7468						
12	1.9404						
13	2.1253						
14	1.8671						
15	1.7737						
16	1.6975						
17	1.8861						
18	1.386						
19	.0747	.0566	.0572	.056	.056	.0381	.0566
20	.0554	.0566	.0572	.056	.056	.0572	.0747
21	.0554	.0566	.0572	.056	.037	.0549	.056
22	.0377	.0566	.0572	.056	.037	.0572	.056
23	.0377	.0566	.0566	.056	.0373	.0572	.0377
24	.0566	.0377	.0566	.0566	.056	.0373	.0572
Max	2.1253	1.7737	1.9805	2.2405	1.6804	1.9605	1.6975
Min	.0377	.0377	.0566	.056	.037	.0373	.0377
Avg	.8042	.7412	.7458	.8204	.5663	.7584	.7288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204002 / 33KV POKHARANI

Feeder No / Name : 203 / 11KV SINGNAPUR GT  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		.0377
2		.0377
3		.0377
4		.0377
5		.0377
9		.0754
10		.0566
11		.0566
12		.0566
13		.0377
14		.0377
15		.0377
16	.0377	.0377
17	.0377	.0377
20	.0732	.0754
21	.0549	.0566
22	.0377	.0377
23	.0377	.0377
24		.0377
Max	.0732	.0754
Min	.0377	.0377
Avg	.0465	.0456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204002 / 33KV POKHARANI

Feeder No / Name : 204 / 11KV POKHARNI GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2686	.3734		.4477	.3734	.3772	.4572
2	.2715	.3734		.4572	.3734	.5658	.4572
3	.2801	.3734		.4668	.3734	.8488	.462
4		.6535		.7468	.5601	.9335	.7392
5	.9431	1.1203		1.226	1.1203	1.0269	1.2012
6					1.1203		
7					1.2136		
8					1.307		
9	1.226	1.4937	1.4937	1.386	1.1203	1.4003	1.386
10	1.0164	1.0269	1.1203	1.1088	.9335	1.1203	1.1203
11	.7468	.7468	.7316	.7468	.5601		.7545
12	.7468	.3734	.4024	.5716	.5658	.5487	.5658
13			.3658	.3734	.5658	.4477	.2829
14	.6602	.3734	.3696	.3734	.5658	.4477	.5658
15	.5658	.3734	.462	.3734		.4572	.5658
16	.5658	.3734	.5544	.4668	.5658	.5544	.3772
17	.6602	.7468	.6468	.8402	.8402	.7392	.6602
18			.6468				.8402
19			1.1203		1.1203	1.1203	.7468
20	.9431	1.1203	.9335	1.0269	.9431	.8488	.9335
21	.7545	.7468	.6468	.8402	.7545	.5658	.7545
22	.5658	.5601	.5544	.6535	.7545	.543	.5658
23	.5658	.3734	.4477	.3734	.5658	.4477	.4715
24	.2686	.3734		.4477	.3734	.3772	.4477
Max	1.226	1.4937	1.4937	1.386	1.307	1.4003	1.386
Min	.2686	.3734	.3658	.3734	.3734	.3772	.2829
Avg	.6499	.6431	.6997	.6803	.7577	.7037	.6836

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204003 / 33KV DAITHANA

Feeder No / Name : 201 / 11KV Dhondi-Malsonna AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-JAN-17	23-JAN-17	24-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	.0895	.0914		.0914	.0914
2	1.0288	.0895	.0914		.0914	.0914
3	1.0288	.0857	.0914		.0914	.0914
4	1.0974	.0905	.0914		.0914	.0914
5	1.1641					
6	1.3003					
7	1.4899					
8	1.8099					
9	1.829					
10	1.7909					
11		1.6651	1.7194	1.8099	1.7909	1.5775
12		2.0576	1.7718	1.9281	1.8099	2.1434
13		2.2291	2.5415	2.3034		
14		2.4863	2.5072	2.1262		2.1434
15		2.4006	2.392	2.0595	1.8861	1.7147
16		2.4006	2.3663	2.0376	2.0576	2.1719
17		2.3148	2.2386	1.8099	1.9719	2.1948
18		2.0576		1.97	1.8861	1.97
20	.0876	.0914		.0886	.0914	.0905
21	.0914	.0914		.0886	.0914	.0857
22	.0895	.0914		.0876	.0366	.0905
23		.0914		.0886	.0914	.0857
24	.0934	.0857	.0914		.0914	.0914
Max	1.829	2.4863	2.5415	2.3034	2.0576	2.1948
Min	.0876	.0857	.0914	.0876	.0366	.0857
Avg	.9974	1.0834	1.3328	1.3665	.8114	.9203

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204003 / 33KV DAITHANA

Feeder No / Name : 202 / 11KV Daithana AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	1.0288	.5373	.7316	.3506	.3658
2	.0914	1.0402	.5373	.724		.3658
3	.0857	1.086	.7164	.8859	.4382	.5373
4	.0876	1.267	.8954	1.4937	.5258	.7164
5		1.2803	1.0517	1.0517	.7011	.7164
6		1.4327	1.2269	1.0631	.8573	.8954
7		1.4022	1.5775	1.387	1.0288	1.0517
8		1.5947		1.7528	1.7147	1.4022
9		1.5432	1.7528	1.7909	1.8861	1.5432
10		1.829	1.7147	1.7718	1.7147	1.7147
11	1.4632					
12	1.3717					
13	1.8099					
14	1.7718					
15	1.8861					
16	2.1491					
17	2.1948					
18	1.829					
20	.0886	.0914		.0886	.0914	.0895
21	.0857	.0914		.0886	.0914	.0886
22	.0886	.0914		.0886	.0914	.0905
23		.0914		.0905	.0914	.0857
24	.0895	.0914	.0914	.0934	.0886	.0914
Max	2.1948	1.829	1.7528	1.7909	1.8861	1.7147
Min	.0857	.0914	.0914	.0886	.0886	.0857
Avg	.9490	.9307	1.0101	.8735	.6908	.6503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204003 / 33KV DAITHANA

Feeder No / Name : 203 / 11KV DAITHNA Gauthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-JAN-17	23-JAN-17	24-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.2743	.1829	.2715	.2743	.1829
2	.181	.1829	.1829	.2658	.2743	.1829
3	.2658	.1829	.2743	.362	.2686	.2686
4	.2572	.3658	.3582	.443	.2686	.2686
5	.3582	.3658	.3582	.5373	.3582	.3582
6				.5373	.4477	
7				.4382	.5373	
8				.443	.6268	
9	1.1765	.5373	.5373	.4572	.5373	.5373
10	.4287	.4477	.4477	.3544	.4477	.4477
11	.4287	.3658	.2743	.2658	.3582	.4477
12	.4287	.2686	.2686	.2772	.2686	.2686
13		.2743	.2715	.2801	.2686	
14		.2743	.1886	.2801	.2743	.2686
15	.3429	.2686	.2715	.2772	.2743	.3467
16	.3544	.3582	.2629	.3582	.3582	.3467
17	.362	.3582		.3696	.3582	.362
18				.3734		
19				.4334		.3658
20	.4382	.3582		.3506	.4477	.3506
21	.3658	.2686		.2686	.3658	.2743
22	.3429	.2743		.2715	.2743	.2686
23		.1829		.2658	.1829	.1829
24	.1867	.2743	.1829	.2743	.2743	.1829
Max	1.1765	.5373	.5373	.5373	.6268	.5373
Min	.181	.1829	.1829	.2658	.1829	.1829
Avg	.3814	.3096	.2901	.3523	.3521	.3111



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204005 / 33KV SINGANAPUR

Feeder No / Name : 202 / 11 KV LOHGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17
HR	Load (MW)
11	1.9909
12	2.5339
13	2.8959
Max	2.8959
Min	1.9909
Avg	2.4736

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204005 / 33KV SINGANAPUR

Feeder No / Name : 203 / 11 KV KARKHANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17
HR	Load (MW)
11	1.8823
12	1.9909
13	2.2443
Max	2.2443
Min	1.8823
Avg	2.0392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204005 / 33KV SINGANAPUR

Feeder No / Name : 206 / 11KV Express Ginning-  
Rajrajesh Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-JAN-17
HR	Load (MW)
11	.1086
12	.1267
13	.1448
Max	.1448
Min	.1086
Avg	.1267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204071 / 33KV JAMB

Feeder No / Name : 201 / 11KV Jamb

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.25	.2006	.2429	.2134	.1875	.1829
2	.1219	.253	.2591	.2591	.2134	.1898	.2623
3	.1829	.3163	.3201	.2591	.2591	.2846	.2932
4	.2591	.3841	.442	.3725	.381	.3521	.3281
5		.4534	.6241	.4049	.5335	.4161	.4531
6		.5182	.8322	.8421	.7011	.5668	.5921
7		.7125	.9602	.9231	1.0425	.9069	.7287
8		.7045	1.1233	1.1174	1.0867		.5992
9			.8745	.9907	1.0517	1.1984	.8848
10		.7202	.6722	.8383	.8421	.9496	
11	.8223						
12	.8848						
13	.8259						
14	.8421						
15	.8583						
16	.8421						
17	.8097	.2785	.3361	.2591	.3201	.3241	.3125
18	.7522	.2785	.4049		.3658	.2778	.2896
19		.3932	.4049	.2896	.381	.3395	.0259
20	.2743	.2881	.3077	.2286	.2591	.2743	.2286
21	.2286	.2315	.2429	.2439	.2134	.2286	.1829
22	.1677	.1852	.1943	.1829	.1677	.1829	.1524
23	.1524	.1698	.1619	.1372	.1524	.1677	.1219
24	.3658	.1524	.1698	.1619	.1219	.1562	.1524
Max	.8848	.7202	1.1233	1.1174	1.0867	1.1984	.8848
Min	.1219	.1524	.1619	.1372	.1219	.1562	.0259
Avg	.5007	.3700	.4739	.4561	.4614	.4119	.3406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204071 / 33KV JAMB

Feeder No / Name : 202 / 11KV Sonna

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.3437	.4167	.3725	.3506	.3658	.3963
2	.4268	.3437	.442	.3887	.3658	.3658	.4321
3	.5335	.4428	.5182	.426	.4268	.4268	.4475
4	.6325	.5535	.5639	.5243	.4877	.5792	.4687
5	.7682						
6	1.1336						
7	1.3283						
8	1.7394						
9	1.8461						
10	1.7078						
11		1.4563	1.4737	1.4937	1.278	1.3123	1.4746
12		1.9845	1.9271	1.9204	1.3765	1.6842	1.9757
13		1.9919	2.0891	1.8084	2.0153	1.8404	2.0317
14		1.9989	2.0081	1.6324	1.9595	1.7444	1.9826
15		1.9662	1.8947	1.6288	1.7814	1.6804	1.8785
16		1.9989	1.749	1.7078	1.668	1.3889	1.7394
17	.3963	1.9826	1.7976	1.5546	1.6194	1.5278	1.7497
18	.4801	1.6712	1.5061		1.3765	1.3889	1.6004
19	.6097	.6882	.664	.6097	.6706	.6019	.7164
20	.5792	.5761	.5506	.5335	.5792	.5792	.4877
21		.4475	.4858	.4725	.4115	.442	.4725
22	.4374	.4321	.421	.3963		.442	.3963
23	.3963	.4167	.4049	.3658	.3963	.4268	.381
24	.3506	.3658	.4167	.3887	.3506	.3749	.4115
Max	1.8461	1.9989	2.0891	1.9204	2.0153	1.8404	2.0317
Min	.3506	.3437	.4049	.3658	.3506	.3658	.381
Avg	.8113	1.0923	1.0738	.9544	1.0067	.9540	1.0579

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204071 / 33KV JAMB

Feeder No / Name : 203 / 11KV Parawa

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.125	.1235	.144	.1067	.1265	.1219
2	.1219	.125	.1372	.144	.1067	.1265	.1389
3	.1524	.125	.1677	.1457	.1372	.128	.1698
4	.1829	.125	.1829	.1619	.1677	.1619	.2006
5		.1581	.2721	.1943	.2134	.1943	.2656
6		.2241	.3201	.3077	.2743	.2267	.3361
7		.3201	.3681	.4049	.3475	.2591	.3887
8		.3441	.4862	.4752	.4557	.3768	.2753
9			.4801	.4115	.4031	.3277	.426
10		.3841	.3681	.3506	.3725	.3391	.7865
11	.3563						
12	.4096						
13	.3887						
14	.3887						
15	.3401						
16	.3563						
17	.3563	.1311	.128	.1372	.1219	.0926	.0937
18	.3521	.1638	.176		.1524	.2006	.1372
19	.2134	.2458	.2561	.2286	.2286	.2469	.2591
20	.1981	.2241	.2241	.2134	.1829	.1219	.2286
21	.1875	.1852	.192	.1829	.1677	.1524	.1829
22	.1562	.1698	.16	.1524		.1677	.1524
23	.1524	.1698	.144	.1372	.1219	.1524	.1372
24	.1219	.1372	.1235	.128	.1219	.1219	.1372
Max	.4096	.3841	.4862	.4752	.4557	.3768	.7865
Min	.1219	.125	.1235	.128	.1067	.0926	.0937
Avg	.2532	.1975	.2394	.2306	.2166	.1957	.2465

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204082 / 33KV Takali Kumbhkarn

Feeder No / Name : 201 / 11KV Aarvi SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.8383	.905	.9503	.6964	.823	.823
2	.9054	.8619	.9412	.9831	.7045	.7716	.823
3		.8619	.8192	.9831	.7209	.7373	.8145
4	1.3769	.8848	.9012	1.2146	.7611	.8288	.8688
5		.9503	.9831	1.2631	.9717	1.0174	.1006
6		.9945	1.2289	1.3765	1.166	1.326	1.1934
7		1.0486	1.4089	1.3603	1.3923	1.4918	1.326
8		1.0364	1.8404	1.7924	1.6549	1.8842	1.8842
9		1.21	1.7924	2.0481	1.7368	1.989	1.9989
10		1.1904	1.8623	1.9662	1.7004	1.9204	1.9559
11	1.5083				.6602		
12	1.9334				.7167		
13	2.0056				.5093		
14	2.0222				.4715		
15	2.0454				.2641		
16	1.989				.415		
17	1.6907	.7733	.7356	.8059	.7167	.8299	.7087
18	1.4419	.905	.9054	.9431	.8505	.9054	.9431
19	1.0751	1.2803	1.226	1.3392	.9145	1.2826	1.0374
20	1.0374	1.0974	1.0562	1.226	1.0534	1.1317	1.1128
21	1.0374	1.0317	.9431	1.0562	.9145	1.0185	.9242
22	.9242	.9145	.9054	.9431	.8145	.9431	.8488
23	.8676	.8145	.8676	.9054	.724	.8676	.7922
24	.8299	.7922	.7682	.8299	.811	.8145	.8299
Max	2.0454	1.2803	1.8623	2.0481	1.7368	1.989	1.9989
Min	.8299	.7733	.7356	.8059	.2641	.7373	.1006
Avg	1.3847	.9714	1.1161	1.2215	.8892	1.1435	1.0547

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204082 / 33KV Takali Kumbhkarn

Feeder No / Name : 202 / 11KV Takali SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0277	.9054	.823		.9431	.9335	.905
2	1.1271	.9431	.7888		1.0374	1.1088	.9145
3	1.1603	.9808	.8413		1.226		.9145
4	1.2266	1.1317			1.5089	1.4632	1.3032
5	1.326	1.358			1.8861		
6	1.6575	1.6787			1.9239		
7	1.7814	2.037			2.0748		
8	2.2611	1.8861			1.8861		
9	2.3537	1.6598			1.6787		
10	2.2834	1.3769					
11	1.1694	1.8299		1.7404			1.8652
12	1.094	2.1605		2.34			2.3205
13	1.0269	2.1033		2.2211			2.3537
14	.9431	2.0018		2.2542			2.2542
15	.9054	2.1033		2.3537			2.2447
16	.7922	2.1491		2.42			2.0222
17	.6979			2.3703			2.3205
18	1.0562	2.13		1.5089	1.989		2.0891
19	1.4901	1.6095		1.8107	1.6095		1.8671
20	1.3957	1.4377		1.5466	1.4415		1.6032
21	1.2826	1.1888		1.4146	1.1888		1.3014
22	1.0374	.9955		1.1317	1.1088		1.226
23	.2829	.905		1.094	1.0059	.9431	1.1203
24	.8676	.9054	.8145		.9431	.905	.9431
Max	2.3537	2.1605	.8413	2.42	2.0748	1.4632	2.3537
Min	.2829	.905	.7888	1.094	.9431	.905	.905
Avg	1.2603	1.5425	.8169	1.8620	1.4657	1.0707	1.6427



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204082 / 33KV Takali Kumbhkarn

Feeder No / Name : 203 / AKASHAWANI EXP.

SHEDDABLE RURAL

Feeder KV- 11 / INCOMING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.9808						
5						.0343	
6	.056	.0526	.0526	.0526	.0526	.0514	.0514
7	.0526	.0526	.0526	.0526	.0526	.0514	.0514
8	.0526	.0526	.0526		.0526	.0514	.0514
9	.0526	.0526	.0526	.0526	.0526	.0514	.0514
10	.0526	.0526	.0526	.0514	.0526	.0526	.0514
11	.052	.0526	.0526	.0514	.0526	.0526	.0514
12	.0526	.0526	.0526	.0514	.0526	.0526	.0514
13	.0526	.0526	.0526	.0514	.0526	.0526	.0514
14	.052	.0526		.0514	.0351	.0526	.0514
18	.0526	.0514	.0526	.0526	.0514	.0526	.0526
19	.0526	.0514	.0526	.0526	.0514	.0526	.0526
20	.0526	.0514	.0526	.0526	.0514	.0526	.0526
21	.0526	.0514	.0526	.0526	.0514	.0526	.0526
22	.0526	.0526	.0526	.0526		.0526	.0526
23	.0526	.0514	.0526	.0053	.0514	.0351	.0526
Max	.9808	.0526	.0526	.0526	.0526	.0526	.0526
Min	.052	.0514	.0526	.0053	.0351	.0343	.0514
Avg	.1108	.0522	.0526	.0488	.0509	.0501	.0519

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204082 / 33KV Takali Kumbhkarn

Feeder No / Name : 204 / 11KV Express-Success Cotton NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.2614	.2279	.2241	.2801	.2481	.2481
2	.1307	.2614	.2454	.2614	.2801	.2229	.2454
3	.1307	.2614	.2126	.2427	.2801	.2229	.2401
4	.1307	.1867	.2218	.2614	.2614	.2229	.2454
5	.1307	.2614	.2587	.2614	.2801	.2229	.2454
6	.112	.2614	.2614	.2614	.2801	.2279	.2401
7	.112	.2772	.2241	.2427	.2801	.2229	.2401
8	.2614	.2801	.132	.2427	.2801	.12	.1029
9	.2614	.2614	.2241	.2241	.1886	.2401	.2454
10	.2427	.2614	.2587	.2454	.2241	.2587	.2401
11	.2054		.2241	.2804	.2241	.2614	.2229
12	.2241	.2957	.2614	.3155	.2427	.3511	.2103
13	.2241	.3326	.2614	.2804	.2241	.3511	.2454
14	.2241	.3292	.2614	.2454	.2614	.3326	.12
15	.2241	.2896	.2614	.2454	.2241	.3326	.12
16	.2427	.2896	.2614	.2454	.2614	.2614	.12
17	.2614	.2658	.2614	.3189	.2614	.3361	.1372
18	.2614	.2835	.2587	.2263	.2279	.2614	.1494
19	.2614	.3086	.2614	.2987	.2229	.2614	.1494
20	.2614	.12	.2614	.2957	.124	.2614	.2427
21	.2614	.1949	.2587	.2987	.2481	.2614	.2427
22	.2587	.2481	.2614	.2987	.2481	.2614	.2427
23	.2801	.2454	.2614	.2801	.2126	.2427	.2427
24	.2241	.2614	.2279	.2614	.2801	.2481	.2614
Max	.2801	.3326	.2614	.3189	.2801	.3511	.2614
Min	.112	.12	.132	.2241	.124	.12	.1029
Avg	.2115	.2625	.2438	.2649	.2457	.2597	.2083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204083 / 33KV Tradhara (Rahati)

Feeder No / Name : 201 / 11KV Aasola AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.844	1.0405		1.1803	.9818	1.1328
2	.8431	.944		1.1549	.944	.944
3	.8402	.9838		1.1803	.9459	1.0384
4	.9263	1.0384		1.3474	.9818	.944
5	.9242	.945		1.3489	.9838	1.1305
6					.945	
7					.944	
8					1.0395	
9					1.0395	
10					1.134	
11					1.1351	
12	1.1328		1.5211	1.5513	1.3216	1.3504
13	1.5513		1.5089	1.5876	1.4175	1.3413
14	1.512		1.3489	1.5482	1.0405	1.3489
18			1.5192			
19	1.2865			1.4	1.134	
20	1.1351		1.3413	1.323	1.126	
21	1.0195			1.173	.944	
22	.9838			1.1328	.9459	
23	.945			1.0973	.942	
24	.8431	.9818		1.1843	1.0395	1.1271
Max	1.5513	1.0405	1.5211	1.5876	1.4175	1.3504
Min	.8402	.944	1.3413	1.0973	.942	.944
Avg	1.0562	.9889	1.4479	1.3007	1.0493	1.1508

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204083 / 33KV Tradhara (Rahati)

Feeder No / Name : 202 / 11KV Tridhara AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.095	.0756		.0951	.0756	.0935
2	.0951	.0568		.095	.0946	.0751
3	.0951	.0758		.0951	.0947	.0754
4	.1141	.0567		.095	.0946	.0944
5	.1141	.0567		.1141	.0947	.0939
7	1.0059	1.0405		1.0139		1.323
8	1.2574	1.3446				1.4089
9	1.3504					1.5104
10	1.7423			1.2499	.8535	1.3504
11	1.701		1.1803	1.5135	.7552	1.4316
12	1.7801		1.438	1.6065	.5664	1.4348
13	1.8144			1.6286	.567	1.3489
14	1.6286			1.6648	1.2272	
15	1.7766			1.6097	1.5967	1.3413
16	1.8351			1.7405	1.6113	1.4348
17	1.7612			1.7405	1.3136	1.3413
18	1.7027			1.701	1.4089	1.4251
19	.0947			.1136	.1495	
20	.0947		.0838	.0757	.0944	
21	.0568			.0945	.0945	
22	.0567			.0756	.0944	
23	.0568			.1326	.0944	
24	.0951	.0758		.0761	.0946	.0944
Max	1.8351	1.3446	1.438	1.7405	1.6113	1.5104
Min	.0567	.0567	.0838	.0756	.0756	.0751
Avg	.8836	.3478	.9007	.7872	.5488	.9340

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204083 / 33KV Tradhara (Rahati)

Feeder No / Name : 203 / 11KV Express-Omkar Ginning NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2277	.1901		.1899	.0381	.019
2	.2282	.1899		.1899	.076	.0189
3	.2279	.2284		.1898	.0759	.019
4	.2662	.1898		.1518	.038	.019
5	.2662	.1521		.2275	.0381	.0189
6	.2659	.1899		.1886	.076	.019
7	.1899	.1898		.2277	.0759	.019
8		.1903		.2659	.038	.019
9			.057	.114	.019	.019
10	.076		.057	.0759	.0189	.038
11	.0759		.0761	.0761	.0189	.0381
12	.0761		.0761	.0761	.0189	.038
13	.076		.038	.076	.0189	.038
14	.0759		.038	.038	.019	.038
15	.019		.038	.0381	.019	.038
16	.0761		.038	.038	.0189	.038
17	.076		.0381	.076	.019	.0951
18	.076		.0761	.0759	.019	.0761
19	.0761			.1142	.0189	
20	.1899		.0761	.038	.019	
21	.1903			.0381	.019	
22	.1898			.038	.019	
23	.1899			.038	.019	
24	.1899	.1898		.1899	.038	.019
Max	.2662	.2284	.0761	.2659	.076	.0951
Min	.019	.1521	.038	.038	.0189	.0189
Avg	.1511	.1900	.0553	.1155	.0324	.0330

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (R) S/DN[439] BU 2321

Substation No/ Name :- 204083 / 33KV Tradhara (Rahati)

Feeder No / Name : 204 / 11KV Tridhara Gauthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9274	.8496		.844	.8496	.7522
2	.9221	.945		.9221	.8135	.7491
3	1.0128	.9459		.9284	.944	.6608
4	1.0082	1.0384		.9305	1.1351	
5	1.0128	1.1351		1.0139	1.2474	.945
6	1.0395	1.323			1.0973	.9828
7					1.1328	
8					.9081	
9					.9459	
10	1.2285		1.1789	1.2839	.944	1.0162
11	.8324		1.1763	.8883	.7552	1.0128
12					.5664	
13					.5624	
14					.5036	
15					.5664	
16					.5636	
17					.756	
18					.6851	
19	1.2096			1.134	.756	
20	1.0773		.9221	1.0384	.7552	
21	.8119			.8883	.6595	.8383
22	.8324			.8496	.603	
23	.7371			.8505	.7552	
24	.979	.7552		1.134	.7938	.793
Max	1.2285	1.323	1.1789	1.2839	1.2474	1.0162
Min	.7371	.7552	.9221	.844	.5036	.6608
Avg	.9736	.9989	1.0924	.9774	.8041	.8611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204029 / 33 KV VIDYANAGAR

Feeder No / Name : 201 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2937	.66	1.3969	1.3214	.6584	1.3374	1.2952
2	1.2576	.631	1.3091	1.2848	.6287	1.31	1.254
3	1.231	.6188	1.2765	1.2665	.6264	1.2993	1.2643
4	1.2414	.6264	1.2281	1.3016	.6302	1.2909	1.302
5	1.254	.6767	1.4236	1.4007	.7179	1.4419	1.3984
6	1.4969	.9153	1.7953	1.8176	1.0372	2.0164	1.7319
7	1.9024	1.1667	2.2007	2.2702	1.2071	1.2414	2.311
8	2.4657	1.3542	2.5166	2.46	1.1446	1.2125	2.3396
9	2.6271	1.3634	2.5589	2.5148	1.1942	3.4523	2.2687
10	1.3359	1.2605	1.2856	2.4738	1.1827	3.2999	2.2817
11	1.3375	1.2437	1.2811	2.3168	1.1706	2.6366	2.1765
12	1.2376	1.2475	1.2369	2.3354	1.2056	2.8074	1.9763
13	1.2178	1.1622	1.1408	2.2283	1.1096	2.6075	1.8652
14	1.1477	1.0997	.9861	2.1064	.9907	2.0938	1.724
15	1.0021	1.0684	1.0585	2.0146	.9198	1.7835	1.6326
16	.9328	1.057	.9899	2.0705	.9214	1.769	1.656
17	1.0067	2.2691	1.0982	2.144	2.0271	.9724	1.7743
18	1.2071	2.681	1.2932	2.4537	2.2665	1.0928	1.9841
19	1.4327	3.0693	1.5402	2.8689	2.6795	1.3093	2.5574
20	1.3763	2.8508	1.5013	2.8815	2.3853	1.2612	2.6498
21	1.2247	2.5292	1.3817	2.5778	2.1415	1.1424	1.2955
22	1.0623	2.0567	1.1302	2.0813	1.8709	1.0433	2.0916
23	.9259	.8993	.9122	1.6829	1.7475	.9038	1.8035
24	.7529	1.4287	.743	1.4266	.7598	1.4998	.7948
Max	2.6271	3.0693	2.5589	2.8815	2.6795	3.4523	2.6498
Min	.7529	.6188	.743	1.2665	.6264	.9038	.7948
Avg	1.3321	1.4140	1.3869	2.0542	1.3010	1.7010	1.8095

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204029 / 33 KV VIDYANAGAR

Feeder No / Name : 202 / 11 KV PARDESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3231	.192	.3376	.3795	.1959	.3414	.3607
2	.3272	.1768	.3409	.3445	.3254	.3307	.3307
3	.3025	.1738	.3355	.3384	.1783	.3277	.3254
4	.3195	.1715	.3494	.3582	.1829	.3246	.3578
5	.3416	.1783	.3801	.346	.208	.365	.4024
6	.4321	.2385	.4643	.4718	.2774	.5776	.4504
7	.5868	.3445	.6788	.6683	.3688	.7507	.6981
8	.724	.3887	.7522	.8055	.3803	.3879	.7461
9	.8013	.4047	.7283	.788	.3765	1.1226	.719
10	.4184	.3643	.378	.6912	.3559	.9913	.6861
11	.3269	.2835	.314	.5731	.2995	.7091	.5679
12	.2911	.2759	.3033	.474	.2873	.6156	.4685
13	.2728	.2256	.2317	.4077	.2568	.5202	.4212
14	.2172	.208	.2111	.3742	.2141	.4365	.3883
15	.1989	.176	.1692	.3681	.2004	.3607	.3715
16	.1928	.1837	.1852	.3567	.202	.3424	.3831
17	.2301	.4988	.2088	.4054	.4367	.2195	.4151
18	.2522	.5186	.2469	.5226	.4855	.2629	.5104
19	.3292	.6772	.3475	.6049	.6394	.4222	.6281
20	.3201	.6487	.349	.6693	.6188	.4313	.6304
21	.2949	.5874	.3163	.5621	.5959	.3948	.33
22	.2827	.5267	.3018	.5354	.5121	.3628	.559
23	.2721	.2522	.2774	.4632	.439	.2843	.4801
24	.2248	.3883	.2126	.4062	.2195	.3742	.2271
Max	.8013	.6772	.7522	.8055	.6394	1.1226	.7461
Min	.1928	.1715	.1692	.3384	.1783	.2195	.2271
Avg	.3451	.3368	.3508	.4964	.3440	.469	.4774



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204029 / 33 KV VIDYANAGAR

Feeder No / Name : 203 / 11 KV POLICE QUARTER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5672	.3079	.6097	.6569	.3163	.6233	.5674
2	.5323	.2964	.6291	.6378	.5579	.5724	.5506
3	.5066	.2957	.6072	.6356	.3102	.5724	.5899
4	.542	.2987	.5559	.6493	.3239	.5928	.6245
5	.6179	.3544	.7434	.7118	.4313	.7705	.7758
6	.7733	.5685	1.0818	1.0387	.7712	1.2658	1.0456
7	1.2352	.7446	1.4588	1.531	.8497	2.0309	1.2068
8	1.7179	.8733	1.8182	1.832	.7743	.8863	1.7326
9	1.7479	.9114	1.7517	1.7353	.8215	2.3327	.9054
10	.9015	.8025	.8749	1.608	.7644	2.0152	1.4537
11	.8116	.6805	.7034	1.3923	.6882	1.4786	1.2837
12	.6859	.5761	.6097	1.118	.5761	1.3091	1.1018
13	.5754	.4778	.4763	.8978	.5144	1.155	.8737
14	.4763	.4199	.41	.7849	.423	.8713	.7697
15	.4138	.3749	.3826	.7621	.3597	.7486	.6964
16	.3871	.3605	.3757	.7339	.3849	.7779	.7036
17	.4382	.8423	.4085	.8892	.9167	.397	.8341
18	.5426	1.1275	.6059	1.0919	1.0463	.5426	1.0866
19	.6302	1.2443	.6866	1.2689	1.2331	.7453	1.3116
20	.6043	1.1921	.6508	1.2695	1.1667	.6866	1.1671
21	.5563	1.0557	.5998	1.0648	1.0821	.6081	.5617
22	.5136	.9911	.5243	.9715	.8657	.5159	.9473
23	.4153	.4443	.4252	.813	.8002	.4374	.7638
24	.3528	.6659	.3749	.6676	.9168	.6531	.3567
Max	1.7479	1.2443	1.8182	1.832	1.2331	2.3327	1.7326
Min	.3528	.2957	.3749	.6356	.3102	.397	.3567
Avg	.6894	.6628	.7235	1.0317	.7039	.9412	.9129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204030 / 33KV MIDC

Feeder No / Name : 201 / 11 KV Super Market Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	24-JAN-17
HR	Load (MW)
1	.4329
2	.4047
3	.3963
4	.397
5	.4184
6	.5929
7	.9328
8	1.0837
9	.9877
10	.9358
11	.7743
12	.5807
13	.474
14	.4085
15	.3993
16	.3749
17	.4077
18	.4824
19	.7019
20	.8208
21	.8093
22	.711
23	.6348
24	.5175
Max	1.0837
Min	.3749
Avg	.6116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204057 / 33 KV MKV -1

Feeder No / Name : 201 / 11KV SAKHALA PLOT  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-JAN-17	25-JAN-17
HR	Load (MW)	Load (MW)
1	.362	
2	.362	
3	.3439	
4	.3439	
5	.5068	
6	.6335	
7	1.0317	
8	1.1403	
9	1.086	.905
10	.8779	.8688
11	.7499	.8326
12	.5304	.6878
13	.4207	.543
14	.4024	.4344
15	.4024	.4344
16	.4572	
17	.5304	
18	.724	
19	.724	
20	.6516	
21	.543	
22	.4706	
24	.362	
Max	1.1403	.905
Min	.3439	.4344
Avg	.5938	.6723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204057 / 33 KV MKV -1

Feeder No / Name : 203 / 11 KV S.T. WORKSHOP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	25-JAN-17
HR	Load (MW)	Load (MW)
1	1.4118	
2	1.4118	
3	1.4118	
4	1.4118	
5	1.828	
6	2.6787	
7	3.2941	
8	3.4751	
9	3.2036	2.8959
10	3.2373	2.5339
11	2.7984	2.3167
12	2.5423	1.9909
13	2.4874	1.7375
14	2.3388	1.7375
15	2.1216	1.7375
16	2.1948	
17	2.3529	
18	2.3529	
19	2.3529	
20	2.2443	
21	2.1719	
22	1.8823	
24	2.268	
Max	3.4751	2.8959
Min	1.4118	1.7375
Avg	2.3249	2.1357

### Feederwise Load Information for All Feeders

Feeder No / Name : 205 / 11KV G & P EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-JAN-17	25-JAN-17
HR	Load (MW)	Load (MW)
1	.4525	
2	.4525	
3	.362	
4	.362	
5	.362	
6	.4525	
7	.2715	
8	.2715	
9	.543	.9955
10	.6036	.9231
11	.7316	.8688
12	.7316	.9412
13	.7316	.9412
14	.8048	.9412
15	.8048	.905
16	.8048	
17	.7316	
18	.8688	
19	.6516	
20	.6154	
21	.5792	
22	.543	
24	.4525	
Max	.8688	.9955
Min	.2715	.8688
Avg	.5732	.9309

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204057 / 33 KV MKV -1

Feeder No / Name : 402 / 33KV O/G MKV-MIDC Link

SHEDDABLE RURAL

Line Feeder KV- 33 / INCOMING

DATE	22-JAN-17	25-JAN-17
HR	Load (MW)	Load (MW)
1	1.8461	
2	1.8461	
3	1.9547	
4	1.9547	
5	2.1176	
6	2.2805	
7	2.4434	
8	2.7149	
9	2.7149	2.6337
10	2.0851	2.6337
11	1.2071	2.524
12	1.6461	2.4143
13	1.9753	2.3045
14	1.8656	2.1948
15	1.7558	2.0851
16	1.8107	
17	1.8656	
18	2.1948	
19	2.1948	
20	2.1948	
21	2.0851	
22	1.9753	
24	2.0633	
Max	2.7149	2.6337
Min	1.2071	2.0851
Avg	2.0344	2.3986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 201 / 11 KV NATRAJ FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9335	.905	.7392		.8954	.7392
2		.9335	.905	.7392		.8764	.7392
3	.9145	.9335	.905	.7392		.8859	.7392
4		.9335	.9955	.8316		.9745	.8316
5	.924	1.0269	1.086	.924	1.0974	1.0745	.924
6	1.1888	1.6461	1.267	1.2936	1.5546	1.3575	1.2936
7	1.4784	1.7375	1.7194	1.7556	1.7375	1.7013	1.6632
8	1.848	1.829	2.0119	1.848		1.9004	1.8671
9	1.7556	1.829	1.9404	1.6289	1.6632	1.829	1.6289
10	1.848		1.848	1.448	1.5708	1.7375	1.6289
11	1.6632		1.6632	1.3575	1.386	1.6461	1.267
12	1.4784		1.2936	1.1765	1.2936	1.5546	1.1765
13	1.2012		1.2012	1.086	1.1088	1.2803	1.086
14	1.1088		1.0059	.9955	1.0164	1.2136	.9955
15	.924		.9145	.9955	.905	1.0059	.905
16	1.0164	1.086	1.0059		.924		.9145
17	1.2803	1.267	1.0974	1.1888	1.1088		1.1888
18	1.4632	1.448	1.386	1.5546	1.4784		1.4632
19	1.4632	1.6289	1.6632	1.6461	1.6632		1.5546
20	1.4937	1.6289	1.4784	1.6461	1.3575	1.4784	1.5061
21	1.307	1.5384	1.2936		1.1765	1.2936	1.2803
22	1.1203	1.448	1.1088		1.086	1.1088	1.0974
23	1.0059	1.0288	.924		.8859	.924	
24		.9335	.9745	.7392		.8764	.8316
Max	1.848	1.829	2.0119	1.848	1.7375	1.9004	1.8671
Min	.9145	.9335	.905	.7392	.8859	.8764	.7392
Avg	1.3046	1.3228	1.2747	1.2167	1.2785	1.2807	1.1879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 202 / 11 KV LOKMANYA NAGAR  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3658	.3506	.3658		.3506	.3658
2		.3658	.3429	.3658		.3582	.3658
3	.3658	.3658	.3429	.3658		.3582	.3658
4		.3658	.443	.3658		.4477	.3658
5	.3658	.4572	.543	.3658	.5487	.543	.3696
6	.5487	.4572	.6335	.5487	.7316	.6335	.6401
7	.7316	.4572	.8145	.823	.7316	.8145	.823
8		.5487	.8145	.7087		.8145	.823
9	.7316	.4572	.823	.724		.7392	
10	.5487		.823	.543	.5487	.7316	.6335
11	.4572		.6401	.4525	.5487	.5487	
12	.4572		.5487	.4525	.4572	.4572	
13	.3658		.3658	.4525	.3658	.3658	
14	.3658		.3658	.362	.3658	.3734	
15	.3658		.2743	.9955	.362	.3658	
16	.3658	.4525	.2743	.3658	.3658		.4572
17	.4525	.4525	.3658	.4572	.362		.4572
18	.5487	.543	.5487	.7316	.5487		.3429
19	.6401	.6335	.5487	.823	.6401		.6401
20	.6859	.6335	.5487	.823	.6335	.5487	.6401
21	.6535	.543	.4572		.543	.5487	.5487
22	.5601	.543	.4572		.543	.4572	.5487
23	.4668	.4287	.3658		.3544	.3658	
24	.823	.3658	.3506	.3658		.3544	.3658
Max	.823	.6335	.823	.9955	.7316	.8145	.823
Min	.3658	.3658	.2743	.362	.3544	.3506	.3429
Avg	.5174	.4687	.5018	.5456	.5089	.5088	.5149



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 203 / 11KV DHAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.267	1.2403	1.2136		.7973	1.1203
2		1.267	1.2536	1.2136		.7973	1.1203
3	1.0059	1.267	1.267	1.307		.8145	1.1203
4		1.267	1.267	1.4003	1.1888	.8859	1.1203
5	1.1888	1.267	1.3575	1.4937	1.2803	.905	1.1203
6					1.3717		
7					1.3717		
9					1.4003		
10					1.307		
11					1.307		
12					1.4937		
13					1.6804		
14					1.8671		
15	2.5463		2.4691	2.4434	1.8099		2.1948
16	2.6406	2.5339	2.5606	2.4691	1.6804		2.2862
17	2.4691	2.3529	2.4272	2.652	2.4272		2.4691
18	2.2862	2.4434	2.4272	2.3777	1.7737		2.1948
23	1.0974	1.2003	1.307		.7973	1.307	
24	1.0059	1.267	1.2003	1.307			1.1203
Max	2.6406	2.5339	2.5606	2.652	2.4272	1.307	2.4691
Min	1.0059	1.2003	1.2003	1.2136	.7973	.7973	1.1203
Avg	1.6940	1.6133	1.7070	1.7877	1.5171	.9178	1.5867

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 204 / 11 KV Sarnath Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3658	.4382	.3658		.3544	.3658
2		.3658	.443	.3658		.3544	.3658
3	.4572	.3658	.4525	.3658		.3582	.3658
4		.3658	.4525	.3658		.443	.3658
5	.462	.4572	.543	.4572	.6401	.543	.3658
6	.5487	.4572	.6335	.5487	.7316	.724	.5487
7	.7316	.5487	.905	.823	.8316	.905	.823
8	.9145	.7316	.905	.823		.905	.823
9	.823	.7316	.905	.724	.823	.9145	.724
10	.823		.823	.6335	.7316	.823	.6335
11	.7316		.5487	.6335	.6401	.7316	.6335
12	.6401			.543	.5487	.6401	.6335
13	.5487		.5487	.543	.5487	.5544	.543
14	.4572			.4525	.5487	.5487	.4525
15	.4572		.5487	.4525	.4525	.4572	.4525
16	.5487	.543	.5487	.4572	.4572		.4572
17	.7316	.724	.5487	.6401	.5487		.5487
18	.823	.8145	.7316	.9145	.7316		
19	.7316	.8145	.9145		.7316		
20	.5487	.6335	.7316	.9431	.8145	.6335	.6401
21	.543	.543	.6401		.543	.543	.3429
22	.543	.4525	.5487		.4525	.4525	.5316
23	.4525	.4287	.4572		.3582	.362	
24	.4572	.3658	.4382	.3658		.3544	.3658
Max	.9145	.8145	.9145	.9431	.8316	.9145	.823
Min	.4525	.3658	.4382	.3658	.3582	.3544	.3429
Avg	.6105	.5394	.6230	.5709	.6186	.5801	.5230

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 205 / 11KV RAJARANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.2936	1.2403	1.0269		1.3289	1.1203
2		1.2936	1.2403	.9335		1.3289	1.1203
3	1.2803	1.2803	1.2403	1.1203		1.3432	1.1203
4		1.2803	1.3575	1.4003		1.4327	1.2136
5	1.4632	1.6632	1.8099	1.6804	1.9204	1.7013	1.4003
6	2.0119	1.6804	2.2624	2.2405	2.2862	2.3529	2.1472
7	2.4949	1.9605	2.8054	2.894	2.8349	2.9864	2.8006
8	2.9569	2.894	2.8054	2.8006		3.2579	2.8006
9	2.7721	2.894	2.7435	2.5339	2.7073	3.2007	2.4434
10	2.6797		2.4691	2.3529	2.4272	2.8349	1.9004
11	2.1948		2.1948	2.2624	2.0538	2.2862	
12	2.0328		1.9204	2.0814	1.8671	1.9204	1.5384
13	1.6632		.823	1.8099	1.6804	1.7375	1.448
14	1.4784		1.4632	1.6289	1.4937	1.7375	1.267
15	1.4784		1.3717	1.5384	1.3575	1.5546	1.267
16	1.5708	1.7194	1.3717		1.587		1.1888
17	2.1948	2.0814	1.4937	2.0119	1.8671		1.5546
18	2.8006	2.7149	2.6139	2.5606	2.5206		
19	2.4691	2.8959	2.8006		2.4272		
20	2.0119	2.0814	2.4272	2.1948	2.1719	2.2405	2.1948
21	1.829	1.7194	2.0538		1.8099	1.8671	1.829
22	1.4632	1.5384	1.6804		1.5384	1.4937	1.5546
23	1.2803	1.2003	1.4937		1.4175	1.307	
24	1.2803	1.2936	1.2003	1.1203		1.3289	1.2136
Max	2.9569	2.8959	2.8054	2.894	2.8349	3.2579	2.8006
Min	1.2803	1.2003	.823	.9335	1.3575	1.307	1.1203
Avg	1.9403	1.8603	1.8701	1.9048	1.9982	1.9621	1.6561

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 206 / 11 KV HUDCO FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3658	.3544	.3658		.362	.362
2		.3658	.362	.3658		.3544	.362
3	.3658	.3658	.362	.3658		.3544	.362
4		.3658	.4525	.3658		.4477	.362
5	.3658	.4572	.543	.4572		.543	.4525
6	.5487	.4525	.6335	.6401	.7316	.6335	.5487
7	.7316	.543	.8145	.9145	.823	.8145	.7316
8	.8145	.6335	.905	.823		.905	.9145
9	.724	.543	.9145	.8145	.7316	.924	.724
10	.6335		.9145	.724	.7316	.8316	.724
11	.6401		.823	.6335	.6401	.7392	.724
12	.6401		.5487	.543	.5487	.6401	.6335
13	.5487		.5487	.543	.5487	.462	.543
14	.4572		.5487	.4525	.4572	.462	.4525
15	.4572		.5487	.362	.4525	.3658	.362
16	.4572	.4525	.3658	.3658	.362		.3658
17	.5487	.543	.5487	.5487	.543		.5487
18	.7316	.724	.7316	.7316	.6335		.6401
19	.7316	.724	.7316		.724		.6401
20	.6401	.6335	.6401	.7316	.6335	.6401	.6401
21	.6535	.6335	.5487		.543	.5487	.6401
22	.5601	.543	.5487		.4525	.4572	.5487
23	.4572	.4287	.4572		.362	.3658	
24	.5544	.3734	.3506	.3658		.3544	.3658
Max	.8145	.724	.9145	.9145	.823	.924	.9145
Min	.3658	.3658	.3506	.362	.362	.3544	.362
Avg	.5740	.5082	.5915	.5557	.5834	.5603	.5499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204061 / 33KV KHANDOBA

Feeder No / Name : 207 / DESHMUKH Ag

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.1753	.1715	.1619		.1772	.2429
2		.1753	.1715	.1619		.181	.2429
3		.1753	.1772	.1619		.1791	.2429
4	.2743	.1753	.2658	.1619	.1829	.2715	.2429
5	.2743	.1753	.2715	.1619	.1829	.2715	.2429
6					.1829		
7					.1829		
9					.1619		
10					.1619		
12					.1619		
13					.3239		
14					.3239		
15	.4049		.4572	.181	.362	.2715	.2743
16	.4858	.362			.3239		.2743
17	.543	.362	.4049	.3658	.4049		.4572
18	.4287	.4525	.3239	.4572	.3239		.4572
23	.1829	.2658	.1619		.1772	.1619	
24	.2743	.1753	.1715	.1619		.1772	.2429
Max	.543	.4525	.4572	.4572	.4049	.2715	.4572
Min	.1829	.1753	.1619	.1619	.1619	.1619	.2429
Avg	.3492	.2494	.2577	.2195	.2469	.2114	.2920

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204069 / 33 KV MKV II

Feeder No / Name : 201 / 11KV RAILAY STATION  
EXPRESS Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0747	.0747	.0747	.056	.0747
2	.0747	.0747	.0747	.0747	.0518	.056	.0747
3	.0747	.0747	.0747	.0747	.0747	.056	.0747
4	.0747	.0747	.0747	.0747	.0747	.084	.0747
5	.0747	.0934	.0934	.0934	.0934	.0878	.0747
6	.0747	.112	.0934	.0934	.0934	.0934	.0747
7		.0934	.0747	.0934	.0934	.0796	.0747
8	.0934	.112	.0934	.0905	.0747	.0878	.0747
9	.1307	.112	.0934	.0934	.0934	.0822	.0934
10	.112	.112	.1307	.0934	.0747	.1307	.0905
11	.1494	.112	.0934	.0934	.0934	.112	.1307
12	.112	.0934	.0934	.0747	.1307	.0934	.1307
13	.0934	.0747	.0934	.056	.0934	.0934	.0934
14	.0747	.0747	.0934	.056	.056	.0747	.112
15	.056	.0747	.0934	.0747	.056	.0747	.0747
16	.0747	.0747	.0747	.0747	.056	.0747	.0747
17	.0784	.0747	.056	.0747	.0691	.0747	.0747
18	.0971	.0747	.0747	.0075	.084	.056	.7468
19		.0934	.112	.0075	.1027	.0747	.1307
20	.1046	.0934	.112	.0934	.1064	.112	.112
21	.0934	.0747	.0934	.0934	.0934	.0934	.0093
22	.0822	.0934	.0747	.0866	.0934	.0934	.0934
23	.0784	.0934	.0747	.0747	.0822	.0934	.0075
24	.0747	.0747	.0747	.0747	.0747	.0747	.0934
Max	.1494	.112	.1307	.0934	.1307	.1307	.7468
Min	.056	.0747	.056	.0075	.0518	.056	.0075
Avg	.0888	.0879	.0872	.0749	.0829	.0837	.1111

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204069 / 33 KV MKV II

Feeder No / Name : 202 / 11KV RAM KRISHNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.5068	.4706	.5249	.543	.5121	.4525
2	.4344	.4706	.4706	.5068	.5068	.4938	.4163
3	.4706	.4525	.4887	.5068	.5792	.4755	.4344
4	.543	.543	.543	.5068	.6878	.5853	.5792
5	.6516	.6697	.6335	.5611	.724	.7316	.7059
6	.8507	.8688	.7783	.7421	.8688	.823	.905
7	.8507	.9955	.8869	.8688	.9774	1.0242	.9231
8	.9593	.9955	.9955	.9412	.8688	.8779	.9412
9	.9877	.905	.9231	.905	.8326	.823	.0814
10	.9511	.8688	.7783	.6335	.7421	.7783	.6878
11	.823	.6335	.8145	.724	.7059	.5973	.695
12	.695	.5792	.8688	.5792	.5792	.7059	.6219
13	.6401	.5611	.905	.543	.543	.6335	.5611
14	.5487	.5068	.8145	.5249	.5068	.5249	.4887
15	.567	.5249	.7602	.5249	.4706	.4887	.5792
16	.5853	.543	.4887	.5792	.5121	.5249	.5792
17	.5853	.5068	.6516	.6878	.6036	.5611	.6154
18	.7316	.7421	.7964	.0724	.7133	.7602	.724
19	.8596	.9412	.9231	.7964	.8779	.7783	.905
20	.823	.8688	.905	.0796	.7865	.8507	.8507
21	.7682	.7964	.8145	.724	.7682	.7964	.076
22	.695	.6878	.724	.7059	.7133	.6878	.6516
23	.5853	.5792	.5973	.6335	.5853	.6154	.0543
24	.543	.543	.5068	.5611	.543	.5487	.543
Max	.9877	.9955	.9955	.9412	.9774	1.0242	.9412
Min	.4344	.4525	.4706	.0724	.4706	.4755	.0543
Avg	.6917	.6788	.7308	.6014	.6766	.6749	.5863

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204069 / 33 KV MKV II

Feeder No / Name : 203 / 11 KV MKV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.3109	.2743	.2804	.2103	.3077	.2629
2	.2454	.3109	.2743	.2804	.2103	.3077	.2279
3	.2629	.2926	.2926	.2804	.2629	.2896	.2454
4	.3506	.3658	.3658	.2804	.3856	.362	.2629
5	.4557	.4938	.4572	.333	.6135	.4525	.4031
6	.5258	.6219	.5853	.5609	.6661	.5611	.4908
7	.5784	.695	.7316	.7186	.631	.6878	.6661
8	.6485	.7316	.7499	.6661	.4908	.6697	.6661
9	.5973	.8048	.7133	.631	.6036	.5973	.6697
10	.5611	.7682	.8238	.7537	.567	.7712	.631
11	.5068	.7316	.7011	.6485	.5304	.6661	.5959
12	.6335	.6401	.6485	.5959	.4938	.6661	.5258
13	.5611	.6219	.6135	.5083	.4572	.631	.4733
14	.4525	.543	.4733	.4557	.4207	.4382	.4031
15	.3982	.5304	.4207	.4031	.4024	.4557	.3681
16	.3982	.5121	.5258	.3856	.362	.4908	.3856
17	.4525	.4938	.4908	.4207	.5249	.4557	.4207
18	.543	.5304	.4908	.4557	.5068	.7362	.4557
19	.5068	.567	.5609	.5258	.4706	.5258	.5434
20	.4344	.4938	.5258	.4908	.4344	.4207	.4557
21	.3982	.439	.4557	.4207	.3801	.4031	.0403
22	.3801	.3475	.4031	.3856	.362	.4031	.3681
23	.3258	.3292	.333	.3506	.3439	.3506	.3506
24	.3155	.3292	.2926	.298	.3155	.3258	.298
Max	.6485	.8048	.8238	.7537	.6661	.7712	.6697
Min	.2454	.2926	.2743	.2804	.2103	.2896	.0403
Avg	.4505	.5210	.5085	.4637	.4436	.4990	.4254



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204070 / 33 KV DARGA

Feeder No / Name : 201 / 11KV DARGA ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.086	1.9806	2.1163	2.0155	2.1346	.8764
2	.8145	1.086	1.9134	1.9496	1.918	2.0493	.8859
3	.8145	1.086	1.8485	2.0096	1.9025	2.0371	.964
4	.905	1.086	1.8875	2.0879	2.0769	1.086	1.1393
5	1.086	1.267	1.9256	2.2272	2.8953	1.448	1.4327
6	1.448	1.6289	2.71	2.7359	3.3909	1.9909	1.6832
7	1.7194	2.1719	3.812	3.9144	4.0188	2.1719	1.949
8	2.1719	2.2624	4.5603	4.5526	4.1958	2.1719	1.9281
9	2.1719	2.2624	4.3101	4.5694	4.0399	2.1719	1.9004
10	2.1719	1.8099	3.8304	3.8873	3.9333	1.9909	1.8099
11	1.9909	1.3575	3.2938	3.3903	3.4967	1.8099	1.5384
12	1.5384	1.3575	2.8613	3.088	3.0619		1.3575
13	1.267	1.3575	2.6738	2.7089	2.714		1.3575
14	1.3575	1.1765	2.412	2.4074	2.4562		1.086
15		1.1765	2.163	2.437	2.2318		1.086
16	1.2308	1.086	2.1651	2.3532	2.2306		1.1765
17	1.3289	1.3575	2.6622	2.5808	2.7618	1.7718	1.3575
18	1.6108	1.5947	3.3838	1.9547	3.4331	1.97	1.8099
19	1.6651	1.7147	4.0531	2.0814	3.8584	1.8604	1.9909
20	1.4175	1.2651	3.6036	1.6289	3.5411	1.5947	1.8099
21	1.3003	1.2003	3.1947	1.448	3.1337	1.4175	1.6289
22	1.267	1.1517	2.8277	1.3575	2.8155	1.2536	1.3575
23	1.267	1.1145	2.6448	1.1765	2.473	1.1517	1.086
24	1.1765	1.1765	2.2413	1.086	2.2809	.905	.8859
Max	2.1719	2.2624	4.5603	4.5694	4.1958	2.1719	1.9909
Min	.8145	1.086	1.8485	1.086	1.9025	.905	.8764
Avg	1.4264	1.4097	2.8733	2.4895	2.9532	1.7362	1.4207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204070 / 33 KV DARGA

Feeder No / Name : 202 / 11KV ITI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.543	.8787	.9936	.976	.9608	.9364
2	.362	.543	.849	.8726	.8383	.9341	.8315
3	.362	.543	.9073	.9471	.8192	.9242	.8185
4	.362	.543	.9076	1.0345	.9018	.9235	.9762
5	.4525	.543	1.0193	1.1334	1.0353	1.2315	1.1919
6	.724	.724	1.3153	1.3603	1.5763	1.5497	1.4433
7	.9955	.9955	1.7444	2.0013	1.9477	2.0561	1.8555
8	.9955	1.086	2.2024	2.3821	2.0816	2.3958	2.178
9	1.086	.9955	2.1022	2.4004	2.1016	2.44	2.058
10	1.086	.905	2.0298	2.0009	2.098	2.3396	1.9948
11	.905	.8145	1.7901	1.7703	1.8271	2.2939	1.7109
12	.8145	.8145	1.5996	1.5996	1.5836	2.0784	1.4901
13	.724	.6335	1.5059	1.5631	1.3936	1.9605	.7537
14	.6335	.6335	1.3826	1.2853	1.3083	1.6135	.4237
15	.543	.6335	1.1969	1.3293	1.2698	1.2677	
16	.543	.724	1.2569	1.3247	1.3649	1.2615	1.4746
17	.6859	.8145	1.5461	.7133	1.5653	1.523	1.6536
18	.8764	.8859	1.8727	1.086	1.7349	.8573	1.8157
19	.8764	.7888	1.9902	1.086	1.933	.905	2.0357
20	.7087	.6201	1.8829	.8145	1.7299	.7087	1.7978
21	.5258	.6001	1.6172	.724	1.4832	.6001	1.5358
22	.543	.6093	1.3127	.6335	1.2776	.5316	1.4017
23	.543	.5258	1.1178	.543	1.203	.443	1.1521
24	.543	.6201	1.0075	.4525	1.0309	.4525	1.0071
Max	1.086	1.086	2.2024	2.4004	2.1016	2.44	2.178
Min	.362	.5258	.849	.4525	.8192	.443	.4237
Avg	.6772	.7141	1.4598	1.2521	1.4617	1.3438	1.4146

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 204070 / 33 KV DARGA

Feeder No / Name : 203 / 11KV CIVIL HOSPITAL  
EXPRESS Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0362	.0854	.0839	.0876	.0884	.0343
2		.0362	.0804	.0804	.0846	.0857	.0343
3		.0362	.0781	.0808	.0838	.0846	.0351
4		.0362	.0785	.0789	.0843	.0362	.0347
5		.0362	.0766	.0938	.0857	.0362	.0343
6		.0362	.0792	.0984	.1059	.0362	.0343
7		.0362	.0819	.1003	.1284	.0362	.0343
8		.0543	.0876	.1103	.1227	.0543	.0514
9		.0724	.1421	.1553	.1383	.0905	.0655
10		.0819	.1779	.1631	.1161	.0819	.0655
11		.0655	.1524	.1585	.1089	.0724	.0819
12		.0655	.1444	.1336	.1134	.0819	.0819
13		.0655	.1227	.1267	.0911	.0492	.0543
14		.0543	.1166	.1153	.0796	.0724	.0362
15		.0492	.093	.1168	.0838	.0492	.0362
16	.0328	.0492	.1075	.113	.1046	.0492	.0328
17	.0351	.0492	.1041	.0964	.1111	.0514	.0328
18	.0343	.0532	.1115	.109	.0533	.0514	.0328
19	.0701	.0514	.1079	.0995	.1198	.0514	.0492
20	.0514	.0351	.117	.1153	.1134	.0526	.0328
21	.0343	.0343	.114	.1094	.1156	.0514	.0328
22	.0362	.0343	.101	.1067	.1115	.0514	.0492
23	.0362	.0354	.1033	.1064	.0903	.052	.0328
24	.0362	.0328	.0861	.0884	.0907		.0362
Max	.0701	.0819	.1779	.1631	.1383	.0905	.0819
Min	.0328	.0328	.0766	.0789	.0533	.0362	.0328
Avg	.0407	.0474	.1062	.1100	.1010	.0594	.0436

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PARBHANI (U) S/D[438] BU 2313

Substation No/ Name :- 207002 / 132 KV Parbhani

Feeder No / Name : 406 / 33 KV DARGA

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	4.8868	4.904	4.9383
2	4.4067	4.4925	4.561
3	4.2524	4.441	4.3896
4	4.2867		4.321
5	4.6296		4.4925
6	6.2929		5.4698
7	9.2421		8.1104
8	9.9966		10.0823
9	9.9623		10.1681
10	9.8251		9.6536
11	9.1564		9.3279
12	8.059		8.0247
13	7.0816		7.0302
14	6.3272		5.4012
15	5.8128		3.9266
16	5.5384		5.7785
17	5.9499		6.4129
18	7.3731		7.7161
19	9.225		9.2764
20	9.2936		9.7565
21	7.8361		8.2819
22	7.0473		7.1502
23	6.3786		6.31
24	5.5384		5.5041
Max	9.9966	4.904	10.1681
Min	4.2524	4.441	3.9266
Avg	7.0166	4.6125	6.9202

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 201 / 11KV PATHRI 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		.9145
2		.9145
3		.8573
4		1.1888
6		1.1145
7		1.7147
13	1.3717	
16	1.2193	
17	1.4575	
18	2.0119	
19	2.1948	
20	2.4691	
21	2.0119	
22	1.4632	
23	1.2003	
24		.9145
Max	2.4691	1.7147
Min	1.2003	.8573
Avg	1.7111	1.0884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 202 / 11 KV WADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		.8573
2		.8573
3		.8573
4		1.0288
5		1.0288
6		1.0288
7		1.286
20	.5144	
21	.5316	
22	.5144	
23	.3429	
24		.3429
Max	.5316	1.286
Min	.3429	.3429
Avg	.4758	.9109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 203 / 11KV PATHRI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		.0848
2		.0857
3		.0848
13	1.4575	
16	1.2193	
17	1.3565	
20	.0857	
21	.0857	
22	.5144	
23	.0857	
24		.0857
Max	1.4575	.0857
Min	.0857	.0848
Avg	.6864	.0853

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 204 / 11 KV RENAPUR

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		.3429
2		.3429
3		.3429
13	2.9864	
16	3.0864	
17	2.6578	
18	.8573	
19	.8573	
20	.8573	
21	.6859	
22	.6859	
24		.3429
Max	3.0864	.3429
Min	.6859	.3429
Avg	1.5843	.3429



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 205 / 11 KV DEVNANDRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		1.3717
2		1.3717
3		1.3717
4		1.3717
5		1.3717
6		1.3717
7		2.0576
18	.6859	
19	.6859	
20	.6859	
21	.7316	
22	.3429	
23	.3429	
24		.3429
Max	.7316	2.0576
Min	.3429	.3429
Avg	.5792	1.3288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 206 / 11 KV PATHRI-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		.6859
2		.6859
3		.8859
4		1.1145
5		1.1145
6		1.1145
7		1.8861
13	1.0288	
16	.9145	
17	1.0288	
18	1.5432	
19	1.7147	
20	1.8861	
21	1.3717	
22	1.0288	
23	.9145	
24		.6783
Max	1.8861	1.8861
Min	.9145	.6783
Avg	1.2701	1.0207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 207 / 11KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		.0857
2		.0857
3		.0857
4		.0857
5		.0857
6		.0857
7		.12
13	.1067	
16	.1067	
17	.1372	
18	.1372	
19	.1372	
20	.1372	
21	.1357	
22	.1715	
23	.1715	
24		.1372
Max	.1715	.1372
Min	.1067	.0857
Avg	.1379	.0964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204012 / 33/11 KV PATHRI

Feeder No / Name : 208 / 11KV DHALEGAON  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)
1		.5316
2		.5316
3		.6859
4		.6859
5		.6859
6		.6859
7		.7716
13	.8573	
16	.7621	
17	.6859	
18	.7716	
19	.7716	
20	.7888	
21	.6783	
22	.5144	
23	.5487	
24		.5144
Max	.8573	.7716
Min	.5144	.5144
Avg	.7087	.6366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204025 / 33/11 KV HADGAON

Feeder No / Name : 201 / 11KV HADGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.547						
8	.7733						
9	.9808						
10	.9259						
12	1.0288						
13	.9602			1.286			
14	.9259			1.286			
15		1.2689	1.2826	1.3032	1.3203	1.1317	1.4146
16		1.286	1.4146	1.2517		1.1317	1.3769
17		1.2346	1.3203			1.2826	
18		1.1317	1.2637	1.1145	1.094	1.1128	
19		.8402	.8676	.823	.811	.9054	.9619
20		.8865	.811	.6859	.7545	.9054	.9242
21		.8676	.7922	.6516	.811	.8676	.8865
22		.8488	.703		.7922	.8676	.811
23				.6001			
Max	1.0288	1.286	1.4146	1.3032	1.3203	1.2826	1.4146
Min	.547	.8402	.703	.6001	.7545	.8676	.811
Avg	.8774	1.0455	1.0569	1.0002	.9305	1.0256	1.0625

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204025 / 33/11 KV HADGAON

Feeder No / Name : 202 / 11 KVA NATHRA AG FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.4001	.7621	.583	.4641	.583	
8			.8993	.8059	.7701		.7011
9			1.0364	1.0117	.8848	1.1145	.9297
10		.9922	1.1126		1.0288	1.2689	1.0974
11		.7621	1.3375	.8322	1.3889	1.4575	.8383
12			1.4403	1.4563	1.4918	1.4251	1.4232
13		1.2498	1.3203	1.2963	1.0802	1.4251	1.4746
14		1.2041	1.2003		1.2174	1.3245	1.406
16	1.2963						
17	1.3203						
18	1.1488						
19	.7373						
20	.6401						
21	.5601						
22	.5121						
23	.6401						
24		1.1736					
Max	1.3203	1.2498	1.4403	1.4563	1.4918	1.4575	1.4746
Min	.5121	.4001	.7621	.583	.4641	.583	.7011
Avg	.8569	.9637	1.1386	.9976	1.0408	1.2284	1.1243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204025 / 33/11 KV HADGAON

Feeder No / Name : 203 / 11KV Gopegaon 1 PH SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3429	.3772	.3429	.3772	.3429
2	.3772	.3429	.3429	.3772	.3429	.381	.3429
3	.3772	.3429	.5144	.3772		.381	.3429
4	.5658	.3429	.5144	.3772	.5144	.5716	.5144
5	.5658	.5144	.6859	.5658	.5144	.5716	.6859
6	.5658		.8573	.5658	.6859	.7621	.6859
7	1.8861	1.3717	1.3717	1.5089	1.2003	.9526	1.1317
8	2.0748		1.7147	1.5089	1.3717	1.3336	1.1317
9	2.2634		1.8861	1.6975	1.5432	1.3336	1.3203
10	2.0748	1.3717	1.5432	1.6975	1.7147	1.5242	1.5089
11	2.0576	1.2003	1.8861		1.6975	1.7147	1.6975
12	2.0576	1.8861	1.8861	.1715	1.8861	1.8861	1.8861
13	2.0576	1.8861	1.6975	.1715	1.5089	1.8861	1.8861
14	1.8861	1.7147	1.6975	1.2003	1.5432	1.6975	1.6975
15	1.7147	1.8861	2.2634		1.8861		2.2634
16	1.8861	2.0576	2.452	2.2291		2.2634	2.0748
17	1.7147	1.8861	2.2634	2.2291		2.2634	
18	1.7147	1.7147	1.8861	2.0576	2.0748	2.0748	
19	1.2003	1.7147	1.8861	1.8861	2.0748	1.8861	2.0748
20	1.2003	1.6975	1.8861	1.5432	1.6975	1.6975	1.6975
21	1.2003	1.5089	1.6975	1.5432	1.6975	1.5089	1.5089
22		1.5089	1.3717	1.3717	1.6975	1.5089	1.5089
23	.3429		.3772		.3772	.3429	.3772
24	.3772	.3429		.3772	.3429	.3772	.3429
Max	2.2634	2.0576	2.452	2.2291	2.0748	2.2634	2.2634
Min	.3429	.3429	.3429	.1715	.3429	.3429	.3429
Avg	1.3277	1.2817	1.4358	1.1349	1.2721	1.2737	1.2283

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204074 / 33/11 KV KASAPURI

Feeder No / Name : 201 / 11KV NATHRA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.6379	.7442	.7362	.6173	.7455	.6485
2	.7537	.6447	.7522	.9671	.8939	.7619	.6661
3	1.0208	.691	.9134	1.086	1.1999	.8682	.691
4	1.262	1.0631	1.4118	1.1999	1.3169	1.2178	.9134
5	1.4266	1.3672	1.448	1.39	1.5154	1.448	1.2803
6					1.3717		
7					1.386		
8					1.4506		
9	1.9342	1.8099	1.8461	1.9342	1.5249	1.8099	
10	1.8404	1.4118	1.6289	1.7684	1.4043	1.7177	1.2308
11	1.439	1.3321	1.166	1.5424	1.2239	1.3003	.8954
19		1.5061	1.4118	1.5581	1.5384	1.5203	1.576
20		1.1694	1.1218	1.1616	1.2403	1.2094	1.1568
21	1.0631	1.0517	.9465	1.0166	.9362	1.0229	1.0288
22	.9745	.7716	.7282	.9114	.8402	.567	.9088
23	.6984	.7802	.7011	.8413	.7802	.6626	.8478
24	.7362	.6447	.7362	.6173	.7362	.7455	.6485
Max	1.9342	1.8099	1.8461	1.9342	1.5384	1.8099	1.576
Min	.6344	.6379	.7011	.6173	.6173	.567	.6485
Avg	1.1486	1.0630	1.1112	1.1950	1.1751	1.1141	.9609



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204074 / 33/11 KV KASAPURI

Feeder No / Name : 202 / 11KV PATHARGAVAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10					.9783		
11	.8951	.7811	.9998	.9686	.9783	1.1385	1.1248
12	1.186	1.1043	1.2654	1.1248		1.3279	1.1248
13	1.2963	1.3123	1.1431	1.1888	1.2334	1.439	1.4864
14	1.2483	1.3123	1.2186	1.3123		1.439	1.4175
15	1.2186	1.3125	1.1431	1.3123	1.2037	1.4548	1.4074
16	1.2651	1.3125	1.1248	1.3123		1.3904	1.3717
17	1.1405	1.0517	1.2037	1.1248		1.3279	1.2346
18	.9031	.9031	.8579	.8688	.8688	1.0235	1.1279
Max	1.2963	1.3125	1.2654	1.3123	1.2334	1.4548	1.4864
Min	.8951	.7811	.8579	.8688	.8688	1.0235	1.1248
Avg	1.1441	1.1362	1.1196	1.1516	1.0525	1.3176	1.2869

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204075 / 33/11 KV GUNJ

Feeder No / Name : 201 / 11KV GUNJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3391	.3429	.2858	.3258	.4191	.3429
2	.5144	.3391	.4191	.2858	.362	.4191	.362
3	.5487	.3601	.4763	.3239	.3439	.4572	.4001
4	.5144	.373	.5335	.4382	.3258	.4954	.4763
5	.6687				.4525		
6	.823				.543		
7	.8573				.5068		
8	.8916				.4525		
9	.8573				.4115		
10	.8916				.2374		
11		.8383	.8356	.7373	.7122		.7274
12		.9172	.9393	.7716		.884	.7811
13		.9442	.8907	.7545	.8309	.8688	.8223
14		.8124	.8745	.823	.8139	.8383	.8124
15		.6642	.8907	.8573		.8259	.8907
16		.8592	.9393	.8745	.8817	.8745	.9172
17	.407	.8749		.823			
18	.2515	.6944	.7202	.7716	.7373	.823	.9069
19	.4239	.4382	.3429	.4525	.4191	.4572	.4763
20	.3772	.2858	.5335	.5792	.4191	.4001	.4191
21	.3481	.2858	.4382	.4887	.3978	.4001	.4954
22	.3353	.381		.3601	.39	.381	.4191
23	1.4922	.3048	.3239	.362	.3353	.381	.381
24	.2572	.3052	.3048	.3048	.3801	.3391	.3429
Max	1.4922	.9442	.9393	.8745	.8817	.884	.9172
Min	.2515	.2858	.3048	.2858	.2374	.3391	.3429
Avg	.6049	.5565	.6128	.5719	.4895	.5790	.5867

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204075 / 33/11 KV GUNJ

Feeder No / Name : 202 / 11KV UMRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3681	.2058	.2858	.1905	.3258		.2286
2	.4287	.208	.3239	.1905	.2715		.2667
3	.4115	.2058	.4191	.2858	.2896		.3048
4	.4287	.2543	.5144	.5335	.4525		.4954
5	.5144		.5716		.6335		
6	.5487		.7621		.6335		
7	.6001		.8002		.6001		
8	.5658		.743		.543		
9	.6173		.5906		.4115		
10	.6001		.3429		.2883		
11		.6443	.4744	.583	.5087		.4641
12		.6009	.5487	.5144		.5506	.506
13		.6019	.5658	.5316	.5533	.6001	.4666
14		.5247	.5144	.5487	.5426	.583	.4111
15		.3864	.4801	.5144		.5487	.4096
16		.4755	.5316	.4973	.1875	.5658	.427
17	.2374	.5624	.5487	.4287			.426
18	.4409	.5601	.6516	.5658	.5155	.6344	.4515
19	.4239	.5716	.6287	.3077	.5344	.6097	.6097
20	.3944	.4001	.381	.4287	.4239	.5144	.4763
21	.3052	.4382	.3429	.3258	.2543	.4191	.2858
22	.2204	.2667	.2667	.2715	.2155	.3048	.2667
23	.1865	.2286	.2286	.2896	.1989	.2477	.2096
24	.2534	.1886	.1905	.1905	.5596	.1844	.2286
Max	.6173	.6443	.8002	.583	.6335	.6344	.6097
Min	.1865	.1886	.1905	.1905	.1875	.1844	.2096
Avg	.4192	.4069	.4878	.3999	.4259	.4802	.3852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204075 / 33/11 KV GUNJ

Feeder No / Name : 203 / 11KV ANDHAPURI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572						.0572
2	.2915						.0572
3	.2743						.0572
4	.2572						.0572
5	.2743						
6	.3086						
7	.3429						
8	.3086						
9	.3258						
10	.2915						
11		.3391	.3144	.463	.4287		.3018
12		.3961	.4287	.4801		.3944	.306
13		.4214	.4287	.4801	.4409	.3944	.2881
14		.3311	.3982	.5144	.4527	.3772	.2976
15		.3311	.4163	.4801		.4287	.3286
16		.4064	.4115	.4458	.4161	.4115	.3477
17		.4054	.4287	.4287			.3668
18		.4064	.4344	.3944	.407	.4525	.3429
19						.0572	.0381
20						.0572	.0381
21						.0762	.0381
22						.0762	.0381
23						.0762	.0191
24					.4409		.0762
Max	.3429	.4214	.4344	.5144	.4527	.4525	.3668
Min	.2572	.3311	.3144	.3944	.407	.0572	.0191
Avg	.2932	.3796	.4076	.4608	.4311	.2547	.1698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204090 / 33/11 KV BABHALGAON

Feeder No / Name : 201 / 11 KV BABHALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5373		.4287	.543
2			.5373		.4287	.543
3			.5373		.4287	.543
4			1.2536			1.2536
5			1.4327			1.4327
6			1.8804			1.97
7			2.0595		2.0576	2.1491
8			2.5072		2.4006	2.6244
9			2.8654		2.572	2.7938
10			2.8654		2.4006	2.8959
11	2.1052		2.7759	2.3482	2.4006	2.6244
18		.5487			.724	
19	.5144	.8145		.5144	.905	
20	.5144	.8954		.5144	.8954	
21	.5144	.8954		.5144	.8954	
22	.5144	.7164		.5144	.724	
23	.4287	.5373		.5144	.6335	
24	.4858		.5373	.4858	.4287	.6335
Max	2.1052	.8954	2.8654	2.3482	2.572	2.8959
Min	.4287	.5373	.5373	.4858	.4287	.543
Avg	.7253	.7346	1.6491	.7723	1.2216	1.6672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204090 / 33/11 KV BABHALGAON

Feeder No / Name : 202 / 11 KV GUNJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2686		.2572	.2715
2			.2686		.2572	.2715
3			.2686		.2572	.2715
4			.2686			.2686
5	.3239		.3582			.3582
7					.2572	
12	1.1336	.8059	1.2269		1.3432	
13	1.3717	1.2308	1.2136		1.4685	
14	1.286	1.2178	1.1269	1.1336	1.4327	
15	1.1336	1.1641	1.1145		1.3432	
16		1.2536			1.2894	
17		1.3253	1.2003	1.2003	1.2536	
18		1.2894			1.1765	
19	.9717	1.2536		1.2003	1.086	
20	.2572	.3582		.2572	.3582	
21	.2572	.3582		.2572	.362	
22	.2572	.3582		.2572	.2743	
23	.2572	.2686		.2572	.2743	
24	.3239	.2572	.2715	.3239	.2572	.2715
Max	1.3717	1.3253	1.2269	1.2003	1.4685	.3582
Min	.2572	.2572	.2686	.2572	.2572	.2686
Avg	.6885	.8570	.6897	.6109	.7616	.2855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204090 / 33/11 KV BABHALGAON

Feeder No / Name : 203 / 11 KV LIMBA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858		.7164		.4287	.6335
2	.4858		.7164		.4287	.6268
3	.5087		.7164		.4287	.6335
4	.4858		.7164			.724
5	.5668		.7164		.4287	.724
7					.4287	
12	2.5911	2.8654	2.572		2.7149	
13	2.572	3.1341	2.7435	2.5101		
14	2.572	3.0445	2.6825	2.2672	.6401	
15		2.7759	2.7978		.695	
16		2.7759	2.713		.6401	
17		2.7401	2.5149	2.7435	.6401	
18		2.6863			.7164	
19	1.4575	2.5072		2.2291	.8954	
20	.9431	1.0745			.905	
21	.6859	1.0745		.5144	.905	
22	.5144	.8954		.5144	.724	
23	.4287	.7164		.5144	.6335	
24	.4858		.7164	.4858	.4287	.6335
Max	2.5911	3.1341	2.7978	2.7435	2.7149	.724
Min	.4287	.7164	.7164	.4858	.4287	.6268
Avg	1.0560	2.1909	1.6935	1.4724	.7460	.6626

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PATHRI (R) S-DN[557] BU 2348

Substation No/ Name :- 204090 / 33/11 KV BABHALGAON

Feeder No / Name : 204 / 11 KV TURA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2686		.2572	.2715
2			.2686		.2572	.2715
3			.2686		.2572	.2715
4			.3582			1.0745
5			.3582			1.2403
6			.5373			1.4175
7			.8059		1.4575	1.6832
8			.8059		1.8861	1.97
9			.8954		1.8861	2.0416
10			.8954		1.7147	2.0814
11	1.5384		.7164	1.2146	1.7147	1.9004
18		.2715			.2715	
19	.2572	.362		.2572	.362	
20	.2572	.3582		.2572	.362	
21	.2572	.3582		.2572	.3658	
22	.2572	.362		.2572	.3658	
23	.2572	.2686		.2572	.2743	
24	.3239	.2572	.2686	.3239	.2572	.2715
Max	1.5384	.362	.8954	1.2146	1.8861	2.0814
Min	.2572	.2572	.2686	.2572	.2572	.2715
Avg	.4498	.3197	.5373	.4035	.7793	1.2079



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204014 / 33KV WAZOOR

Feeder No / Name : 201 / 11KV WAZOOR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17
HR	Load (MW)
1	.3142
2	.3881
3	.4251
4	.4805
11	.4435
12	.4805
13	.462
14	.4805
17	.5359
18	.5544
19	.462
20	.4805
21	.4066
22	.3696
23	.2957
24	.2587
Max	.5544
Min	.2587
Avg	.4274

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204014 / 33KV WAZOOR

Feeder No / Name : 202 / 11KV LIMLA FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-JAN-17	24-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6632		.3429
2	1.8519		.3048
3	2.0062		.3048
4	2.1948		.2667
5	2.3148		
6	2.4863		
7	2.8292		
8	2.6749		
9	2.4348		
10	2.3663		
17	.3429	2.934	
18	.3601		
19	.3772		
20	.2915		
21	.2572		
22	.2229		
23	.2058		
24	.1886		.4191
Max	2.8292	2.934	.4191
Min	.1886	2.934	.2667
Avg	1.3927	2.934	.3277

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204014 / 33KV WAZOOR

Feeder No / Name : 203 / 11KV DEOULGAON FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-JAN-17
HR	Load (MW)
1	.2279
2	.333
3	.4207
4	.4382
14	2.2786
15	2.3487
16	2.2436
17	2.3137
18	2.489
19	.4382
20	.4733
21	.3506
22	.2629
23	.2454
24	.2103
Max	2.489
Min	.2103
Avg	1.0049

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204015 / 33KV CHUDAWA

Feeder No / Name : 201 / 11KV CHUDAWA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	2.2043	1.989	2.0348	2.2043	1.7147	1.8652
2	1.7528	2.2891	1.8442	2.0348	2.2891	1.7147	1.8861
3	1.9281	2.2043	1.8442	2.0348	2.2891	1.8861	1.8861
4	2.1033	2.2043	1.989	2.0348	2.2043	1.8861	1.8652
5					2.2043		
6					2.2043		
7					1.6956		
8					1.6956		
9					.8478		
10					.8573		
11					.8573		
12					.6859		
14	3.0521	2.9492		2.713		2.8178	2.8502
15	3.0521	2.9835		2.8826	1.3717	2.6825	2.7978
16	2.713	2.5149		2.713	2.572	2.5149	2.713
17					2.572		
20		2.4863				2.3739	
21	2.5434	2.1548		2.5434	2.0576	2.2043	
22	2.3739	2.0957		2.5434		2.1195	
23	2.2939	2.0119		2.4587		2.0348	
24	1.8861	2.2043	1.989	1.989	2.2043	1.8861	2.0348
Max	3.0521	2.9835	1.989	2.8826	2.572	2.8178	2.8502
Min	1.7528	2.0119	1.8442	1.989	.6859	1.7147	1.8652
Avg	2.3138	2.3586	1.9311	2.3620	1.8125	2.1530	2.2373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204015 / 33KV CHUDAWA

Feeder No / Name : 202 / 11KV GOUR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.1869	1.0059	1.0059	1.0174	1.2136	1.0174
2	1.1393	1.1869	.9945	1.0059	1.1022	1.2136	1.0174
3	1.1393	1.1022	***	1.0174	1.0174	1.1269	1.0174
4	1.2269	1.1022	1.0059	1.0059	1.0174	1.1269	1.0898
5					.4239		
6					.4239		
7					.5087		
8					.5087		
9	1.5089	1.6108		1.5261	1.5261	1.8004	1.9052
10	1.5261	1.5746		1.5261	1.5432	1.6766	1.829
11	1.4413	1.4918		1.3927	1.4575	1.5089	1.6766
12	1.4413	1.3413		1.4413	1.286	1.4251	1.3904
13	1.3565	1.1736		1.3565		1.2717	1.3565
20	.4239	.4477		.5087	.4334	.4382	
21	.4239	.4477		.5087	.4334	.3544	
22	.4239	.3582		.5087		.3544	
23	.4239	.3582		.5087		.3544	
24		1.2717	1.0059	1.0059	1.0174	1.1269	1.0174
Max	1.5261	1.6108	16.0951	1.5261	1.5432	1.8004	1.9052
Min	.4239	.3582	.9945	.5087	.4239	.3544	1.0174
Avg	1.0520	1.0467	4.0215	1.0228	.9144	1.0709	1.3317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204015 / 33KV CHUDAWA

Feeder No / Name : 204 / 11KV SONNA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.1869	1.0774	.7011	1.1022	1.1269	.9221
2	1.0517	1.1022	1.0774	.6935	1.1022	1.0402	.9326
3	1.1393	1.1022	1.0898	.6935	1.0174	1.0402	.9326
4	1.2269	1.1022	1.1736	.8139	1.0174	1.1269	1.0174
5					.4239		
6					.4239		
7					.5087		
8					.5087		
9	1.6956	1.6956		1.6956	1.5261	1.5432	1.6766
10	1.5261	1.6575		1.6956	1.4575	1.5089	1.3889
11	1.3565	1.4918		1.6956	1.3717	1.3565	1.3565
12	1.3565	1.3413		1.6956	1.286	1.3413	1.1869
13	1.3565	1.1736		1.5261		1.3565	1.1869
20	.4239	.3582		.5087	.4334	.3506	
21	.4239	.3582		.5087	.4334	.2658	
22	.4239	.362		.5087		.2658	
23	.4239			.5087		.2658	
24	1.1145	1.1869	1.1736	.8669	1.0174	1.1269	1.0059
Max	1.6956	1.6956	1.1736	1.6956	1.5261	1.5432	1.6766
Min	.4239	.3582	1.0774	.5087	.4239	.2658	.9221
Avg	1.0453	1.0860	1.1184	1.0080	.9087	.9797	1.1606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204016 / 33KV KATNESHWAR

Feeder No / Name : 201 / 11KV KATNESHWAR FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0669	1.4289	1.0402	1.0669	1.186	1.5242
2	1.0669	1.0669	1.4289	1.0774	1.1574	1.2431	1.5242
3	1.0669	1.0669	1.4289	1.0155	1.1111	1.2431	1.5242
4	1.1717	1.1717	1.4289	1.0155	1.2334	1.3108	1.6194
5					.1867		
6					.2195		
7					.1867		
8					.1867		
9					.1867		
10					.1867		
13		1.5242	1.6604	1.7204	1.5813	1.6004	1.7394
14		1.3717	1.5203	1.6385	1.6575	1.5242	
17	1.5927						
20	1.3441	1.3717	1.0936	1.4403	1.2193	1.3717	1.5813
21	1.2651	1.3717	1.2003	1.406	1.3717	1.3717	1.5023
22	1.1736	1.2193	1.0936	1.2955	1.2955	1.2955	1.4232
23	1.1717	1.1431	1.0279	1.2193	1.2803	1.2955	1.406
24	1.1431	1.1717	1.1431	.9907		1.2498	1.6194
Max	1.5927	1.5242	1.6604	1.7204	1.6575	1.6004	1.7394
Min	1.0669	1.0669	1.0279	.9907	.1867	1.186	1.406
Avg	1.2063	1.2314	1.3141	1.2599	.8830	1.3356	1.5464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204016 / 33KV KATNESHWAR

Feeder No / Name : 202 / 11KV ERRANDESHWAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	25-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2651	1.3927	1.6194	1.3765	1.2651	1.4575	1.7147
2	1.2651	1.3927	1.6194	1.3603	1.3441	1.4746	1.7147
3	1.2498	1.4089	1.6194	1.3765	1.3441	1.406	1.7147
4	1.3603	1.4918	1.6194	1.3279	1.4403	1.5203	1.9052
5					.1867		
6					.2195		
7					.1867		
8					.1867		
9					.1867		
10					.1867		
13		1.6766	2.0719	1.9281	1.7204	1.7528	2.0719
14		1.5242	1.7604	1.7204	1.6004	1.6766	1.8842
17	1.8652						
20	1.8442	1.5242	1.6804	1.8442	1.7004	1.6004	1.7404
21	1.7604	1.5242	1.6385	1.6004	1.5546	1.7004	1.7404
22	1.5565	1.3717	1.6004	1.5242	1.5546	1.6004	1.6575
23	1.4746	1.2955	1.6194	1.448	1.5746	1.5242	1.6575
24	1.3603	1.4746	1.2955	1.4842	1.4403	1.5746	1.9052
Max	1.8652	1.6766	2.0719	1.9281	1.7204	1.7528	2.0719
Min	1.2498	1.2955	1.2955	1.3279	.1867	1.406	1.6575
Avg	1.5002	1.4616	1.6495	1.5446	1.0407	1.5716	1.7915



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 203 / 11 KV D. TAKALI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	27-JAN-17
HR	Load (MW)
1	1.3717
2	1.5089
3	1.6461
4	1.7147
5	1.8861
6	1.7147
7	1.989
8	2.0576
Max	2.0576
Min	1.3717
Avg	1.7361

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 204 / 11KV NEELA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)
9		2.4863
11	2.8292	
12	2.915	
Max	2.915	2.4863
Min	2.8292	2.4863
Avg	2.8721	2.4863

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 206 / 11KV D.TAKLI GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)
1		.1715
11	.2401	
12	.2058	
24		.823
Max	.2401	.823
Min	.2058	.1715
Avg	.2230	.4973

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 207 / 11KV NEELA GFSS Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)
1		.2572
2		.2572
3		.2572
4		.4287
5		.5658
11	.2743	
12	.2229	
24		.4801
Max	.2743	.5658
Min	.2229	.2572
Avg	.2486	.3744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 208 / 11KV BARBADI GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)
1		.0857
2		.0857
3		.0857
4		.1029
5		.1372
11	.0857	
12	.0686	
24		.2401
Max	.0857	.2401
Min	.0686	.0857
Avg	.0772	.1229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 209 / 11KV RAILWAY EXPRESS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	24-JAN-17	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0857
2			.0857
3			.0857
4			.0857
5			.1029
6			.1372
7			.1372
8			.1715
9			.1543
11		.1372	
12	.1372	.1372	
24			.0857
Max	.1372	.1372	.1715
Min	.1372	.1372	.0857
Avg	.1372	.1372	.1132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204019 / PURNA URBAN

Feeder No / Name : 211 / 11KV ALLIED FEED EXPRESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	24-JAN-17	26-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0857
2			.0857
3			.0857
4			.0857
5			.0686
6			.12
7			.0343
8			.0343
9			.1029
12	.0857	.0343	
24			.0857
Max	.0857	.0343	.12
Min	.0857	.0343	.0343
Avg	.0857	.0343	.0789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204040 / MATEGAON

Feeder No / Name : 201 / 11KV MATEGAON GFSS Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	23-JAN-17	27-JAN-17
HR	Load (MW)	Load (MW)
9		1.0631
16		.6001
24	.703	.7373
Max	.703	1.0631
Min	.703	.6001
Avg	.703	.8002



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204040 / MATEGAON

Feeder No / Name : 203 / 11KV AHERWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	27-JAN-17
HR	Load (MW)
5	.0686
17	1.5947
24	1.0288
Max	1.5947
Min	.0686
Avg	.8974

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204040 / MATEGAON

Feeder No / Name : 204 / 11KV NAWAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	27-JAN-17
HR	Load (MW)
8	1.8347
20	.0514
24	.0343
Max	1.8347
Min	.0343
Avg	.6401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204052 / TADKALAS

Feeder No / Name : 201 / 11KV TADKALAS GFSS Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	26-JAN-17
HR	Load (MW)
24	1.7833
Max	1.7833
Min	1.7833
Avg	1.7833

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204052 / TADKALAS

Feeder No / Name : 202 / 11KV DHANORA KALE GFSS

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	24-JAN-17	26-JAN-17
HR	Load (MW)	Load (MW)
1	.8745	
24		.9945
Max	.8745	.9945
Min	.8745	.9945
Avg	.8745	.9945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204052 / TADKALAS

Feeder No / Name : 203 / 11KV TADKALAS AG Feeder  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	25-JAN-17
HR	Load (MW)
15	1.8861
16	2.0576
17	1.9547
Max	2.0576
Min	1.8861
Avg	1.9661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204052 / TADKALAS

Feeder No / Name : 205 / 11KV J.R.COTTON IND  
EXPRESS Fe Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	25-JAN-17	26-JAN-17
HR	Load (MW)	Load (MW)
17	.0171	
24		.0171
Max	.0171	.0171
Min	.0171	.0171
Avg	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204078 / 33KV PIMPLA (L)

Feeder No / Name : 201 / 11KV PIMPLA(L)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715					
2	.1715					
3	.1715					
4	.1715					
9		1.0974				
10		1.2689				
11		1.2003		1.1145		
12		1.1145		1.0288		
13	1.0288			.9259		.964
14			.964			
19					.8573	
20					.7716	
21					.823	
22					.8573	
23					.823	
24	.8573	1.2971			.7716	
Max	1.0288	1.2971	.964	1.1145	.8573	.964
Min	.1715	1.0974	.964	.9259	.7716	.964
Avg	.4287	1.1956	.964	1.0231	.8173	.964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204078 / 33KV PIMPLA (L)

Feeder No / Name : 202 / 11KV WAI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	23-JAN-17	24-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115					
2	.4115					
3	.4287					
4	.4287					
10		1.0631				
11		1.286		.8916		
12				.9259		
13				.9431		
14	.8573		.8764	.9431		.8764
19					.8573	
20					.823	
21					.823	
22					.7716	
23					.7202	
24	.7716				.6859	
Max	.8573	1.286	.8764	.9431	.8573	.8764
Min	.4115	1.0631	.8764	.8916	.6859	.8764
Avg	.5516	1.1746	.8764	.9259	.7802	.8764



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204078 / 33KV PIMPLA (L)

Feeder No / Name : 203 / 11KV PANGRA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-JAN-17	24-JAN-17	26-JAN-17	27-JAN-17	28-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431				
2	.9088				
3	.8573				
4	.7888				
5	.7373				
14	1.6461		1.5604		
15			1.4918		
16	1.6118		1.4232		
17			1.3717		
18	1.406	1.4899	1.3375		1.4548
19				.4287	
20				.3772	
21				.3772	
22				.3772	
23				.3772	
24	.2229			.3772	
Max	1.6461	1.4899	1.5604	.4287	1.4548
Min	.2229	1.4899	1.3375	.3772	1.4548
Avg	1.0136	1.4899	1.4369	.3858	1.4548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204079 / PURNA URBAN-2

Feeder No / Name : 201 / 11KV Koliwada Feeder  
(Purna To Feeder KV- 11 /  
OUTGOING

SHEDDABLE URBAN

DATE	23-JAN-17	24-JAN-17
HR	Load (MW)	Load (MW)
1	.2033	.2402
2	.1848	.2033
3	.1848	.1848
4	.4066	.3326
5	.5729	.5359
6	.6653	.7577
12	.5544	
13	.5175	
14	.462	
15	.4066	
17	.3511	
18	.3881	
19	.5544	
20	.462	
21	.3881	
22	.3326	
23	.3142	
24	.2772	
Max	.6653	.7577
Min	.1848	.1848
Avg	.4014	.3758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204079 / PURNA URBAN-2

Feeder No / Name : 202 / 11 KV Anand Nagar (Purna  
Town) Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	23-JAN-17	24-JAN-17
HR	Load (MW)	Load (MW)
1	.8596	.8954
2	.8596	.8596
3	.9134	.7522
4	1.5043	1.0566
5	1.6476	1.4148
6	1.8983	1.9521
12	1.7193	
13	1.6297	
14	1.3253	
15	1.0566	
17	.9134	
18	1.0208	
19	1.4506	
20	1.3611	
21	1.1999	
22	1.0924	
23	1.0745	
24	.9671	
<b>Max</b>	<b>1.8983</b>	<b>1.9521</b>
<b>Min</b>	<b>.8596</b>	<b>.7522</b>
<b>Avg</b>	<b>1.2496</b>	<b>1.1551</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204079 / PURNA URBAN-2

Feeder No / Name : 203 / 11 KV Suki Ag.Feeder  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	23-JAN-17	24-JAN-17
HR	Load (MW)	Load (MW)
7	.9962	1.1227
8	1.2967	1.2492
9	1.3283	
10	1.3283	
11	1.3283	
17	1.3283	
18	1.2492	
Max	1.3283	1.2492
Min	.9962	1.1227
Avg	1.2650	1.1860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JAN-17 and 28-JAN-17

NANDED ZONE[066]

PARBHANI CIRCLE[635]

PARBHANI DIVSION - I[231]

PURNA (R) S/DN[558] BU 7323

Substation No/ Name :- 204079 / PURNA URBAN-2

Feeder No / Name : 204 / 11KV Express Vaibhav  
Jinning Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	23-JAN-17	24-JAN-17
HR	Load (MW)	Load (MW)
1	.0497	.0497
2	.0497	.0497
3	.0497	1.3757
4	.0497	.0497
5	.0497	.0497
6	.0497	.0497
7	.0497	.0497
8	.0497	.0497
9	.0497	
10	.0497	
11	.0497	
12	.0497	
13	.0497	
14	.0497	
15	.0497	
17	.0497	
18	.0497	
19	.0497	
20	.0497	
21	.0497	
22	.0497	
23	.0497	
24	.0497	
Max	.0497	1.3757
Min	.0497	.0497
Avg	.0497	.2155