

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 201 / 11 KV Lakhani
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9802	.9802	.9802	.9497	.9497	.9497	.4572
2	.9497	.9192	.9192	.9192	.9497	.9192	.2772
3	.8268	.8888	.8888	.8888	.9192	.8268	.6735
4	.7964	.8583	.8888	.7659	.8888	.823	.704
5	.7659	.7659	.7583	.7659	.7964	.7926	.6735
6	.6401	.643	.6287	.6401	.6706	.7621	.643
7	.6125	.4934	.5982	.5791	.6096	.6182	.582
8	.582	.5544	.4934	.5486	.582	.5515	.4572
9	.582	.5849	.582	.6401	.6125	.5763	.5429
10	.6125	.7583	.5763	.6373	.7354	.6373	.7011
11	.6735	.7583	.3658	.7583	.8268	.7621	.7316
12	.7659	.7964	.0316	.823	.8535	.7926	.7354
13	.8268	.9192	.1901	.9192	.8573	.9497	.7621
14	.8306	.9192	.7125	.9497	.8573	.9497	.7926
15	.8611	.9192	.9564	.9497	.8878	.9802	.823
16	.8306	.9144	.7964	.9497	.8573	.9497	.8268
17	.7964	.7926	.7926	.8268	.8268	.7401	.7926
18	.7926	.7011	.7926	.7926	.7964	.7049	.7926
19	.7659	.7354	.7926	.5849	.8002	.8268	.3658
20	.7964	.7659	.8268	.7354	.8002	.7964	.1658
21	.8306	.7964	.8306	.8002	.8306	.8268	
22	.8306	.8306	.9802	.924	.9545	.9497	.9145
23	.9497	.9802	.9802	.985	.9802	.8878	1.8385
24	.9802	.9802	.9802	.9497	.9802	.9802	1.3146
Max	.9802	.9802	.9802	.985	.9802	.9802	1.8385
Min	.582	.4934	.0316	.5486	.582	.5515	.1658
Avg	.7866	.8023	.7226	.8035	.8260	.8147	.7203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 202 / 11 KV Salebhata

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.7811	.4877				.5944
2	.8916	.7811	.4877				.5639
3	.8916	.7735	.4877				.5639
4	.8964	.7735	.4877				.5639
5	.8964	.7735	.4877				.5639
6	.9659	.8659					.1486
7	.8964	.8707					.3925
8	.9469	.9012					.3277
9	.8659	.8754					.3201
10	.8945	.8802					.3163
11	.885	.8545					.3468
12	.5182	.4877	.3668	.2972	.2934	.2934	.2134
13		.4877	.885	.8287	.7202	.7202	
14			.885	.8287	.7544	.724	
15			.8545	.824	.724	.6935	
16			.8802	.8287	.724	.6935	
17			.9526	.8192	.824	.1829	
18			1.0079	.4877	.8497	.2229	
19			1.0193	.8097	.8335	.5525	
20			.9774	.8097	.7354	.5106	
21			.8754	.8097	.7164	.522	
22			.8754	.784	.7202	.5944	
23			.885	.7126	.7697	.5944	
24	.3429	.5068	.8611	.4268	.4268	.3048	.2896
Max	.9659	.9012	1.0193	.8287	.8497	.724	.5944
Min	.3429	.4877	.3668	.2972	.2934	.1829	.1486
Avg	.8295	.7581	.7647	.7128	.6994	.5084	.4004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 203 / 11 KV Pohara

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3003	1.2059	1.3308	1.1508	1.1145	1.1145	1.3717
2	1.3003	1.1755	1.3003	1.1508	1.084	1.1145	
3	1.3003	1.1755	1.3003	1.1508	1.084	1.0202	2.2606
4	1.3003	1.1755	1.3003	1.1508	1.084	1.0202	2.2062
5	1.3003	1.1755	1.3003	1.1508	1.084	.9897	1.1279
6	1.3003	1.0812	1.1698	1.1203	.9897	.9592	
7	1.2699	1.145	1.1088	1.1755	.3353	.9592	
8	1.3241	1.145	1.3003	1.3003	.0343	1.084	.5277
9	1.4784	1.2059	1.3613	1.3003	.4697	1.1145	.7707
10	1.5166	1.3003	1.3613	1.3308	.4248	1.145	.8716
11	1.5166	1.3003	.6602	1.3308	.8335	1.1508	.9936
12	.8535	1.4556	1.2802	1.3613	1.1088	1.2699	1.7528
13	1.2002	1.4861	1.3003	1.3613	1.1031	1.3069	1.8671
14	1.2374	1.4861	1.2699	1.3308	1.145	1.3069	1.9186
15	1.4861	1.3613	1.2699	1.3308	1.1145	1.3003	1.9186
16	1.4223	1.3613	1.1755	1.3308	1.1145	1.1755	1.9186
17	1.3613	1.3613	1.2059	1.3308	1.1145	1.0202	1.7633
18	1.3308	1.3613	1.2059	1.3308	1.145	.9497	1.7328
19	1.3308	1.3613	1.1755	1.1813	1.145	.9497	.823
20	1.3308	1.3374	1.145	.5487	1.1088	.9192	
21	1.3069	1.3308	1.145	1.145	1.145	.9192	
22	1.3003	1.3308	1.145	1.145	1.145	.924	
23	1.2059	1.3374	1.1508	1.145	1.145	.924	
24	1.2699	1.2364	1.2394	1.1203	1.1145	1.2364	1.5166
Max	1.5166	1.4861	1.3613	1.3613	1.145	1.3069	2.2606
Min	.8535	1.0812	.6602	.5487	.0343	.9192	.5277
Avg	1.3143	1.2872	1.2168	1.2072	.9661	1.0781	1.4907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 204 / 11 KV Dhargaon Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.647	1.647	1.6108	1.6289	1.5432	1.4737	1.2003
2	1.5604	1.647	1.6108	1.6289	1.5432	1.4899	1.2003
3	1.5604	1.5432	1.6108	1.5432	1.5432	1.4022	1.2003
4	1.4575	1.5432	1.6108	1.5432	1.5089	1.4022	1.1869
5	1.4575	1.4575	1.4575	1.5261	1.3413	1.3146	1.0898
6	1.2289	1.3108	1.2498	1.2146	1.1336	1.3146	1.0774
7	1.1203	1.1069	1.1288	1.1717	1.1069	1.065	.8592
8	1.2003	1.1336	1.0936	1.186	1.1717	1.0155	.9116
9	1.2146	1.2289	1.2146	1.1203	1.1069	1.186	.8697
10	1.2289	1.2146	1.2803	1.1203	1.186	1.2003	.9717
11	1.326	1.2289	1.1869	1.2146	1.3108	1.3108	.9717
12	1.4413	1.3108	1.2289	1.2955	1.4251	1.2955	.9831
13	1.5261	1.3108	1.326	1.3565	1.4413	1.5261	1.1022
14	1.4575	1.4413	1.326		1.4413	1.4413	1.1022
15	1.4413	1.3565	1.326	1.3413	1.326	1.3413	1.1022
16	1.2574	1.2574	1.2289	1.2574	1.2955	1.2431	1.0059
17	1.2289	1.2574	1.1203	1.2146	1.2146		1.065
18	1.2003	1.2574	1.1717	1.1069	1.2003	1.1336	1.0155
19	1.5261	1.4251	1.4918	1.3413	.4973	1.2574	
20	1.7528	1.6651	1.7337	1.6651	1.7718	1.387	
21	1.8404	1.7528	1.7528	1.7528	1.848	1.3765	
22	1.7337	1.7528	1.7337	1.6651	1.7528	1.4737	
23	1.647	1.6651	1.7737	1.5604	1.647	1.4022	
24	1.647	1.647	1.6108	1.6289	1.5432	1.5604	1.3146
Max	1.8404	1.7528	1.7737	1.7528	1.848	1.5604	1.3146
Min	1.1203	1.1069	1.0936	1.1069	.4973	1.0155	.8592
Avg	1.4459	1.4234	1.4116	1.3949	1.3708	1.3310	1.0647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 205 / 11 KV MIDC II feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.9431	.9431	.5373	.9431	.6859	.8402
2	.8145	.8488	.8488	.4287	.9431	.7545	.8402
3	.7973	.8488	.8488	.4287	.9335	.7545	.8402
4	.7011	.8316	.724	.3125	.8402	.7468	.8402
5	.6859	.8316	.7164	.3125	.8316	.8316	.8402
6	.6935	.7392	.6268	.5935	.823	.8316	.7392
7	.4858	.6068	.4858	.6335	.6554	.5087	.6268
8	.8488	.8488	.6602	.9431	.9431	.9431	.8488
9	.8488	.8402	.543	1.0374		.8488	.7468
10	1.3203	.8488	.5544	1.307	1.386	1.4003	1.0374
11	1.0059	.9335	.5144	.9335	1.0374	.9335	1.1317
12	1.1888	1.226	.4287	1.4146	1.307	1.4937	1.226
13	1.0374	1.0374	.4973	1.0374	1.226	.9431	1.0374
14	1.226	1.1317	.4973	1.1317	1.3203	.9431	1.0374
15	.905	.8316	.3315	.7087	1.1317	1.1317	1.0374
16	1.226	1.0374	.3201	1.1317	1.1317	1.226	1.0374
17	1.1317	1.226	.3048	1.0374	1.0374	.0305	1.226
18	1.0374	1.1317	.2896	1.1203	1.0374	.7373	1.0374
19	.9335	.7392	.2058	.7011	.443	.763	
20	.924	.8954	.2086	.6335	.362	.8316	.5316
21	.924	.8059	.4572	.6201	.7316	1.0374	.7545
22	.924	.9145	.4191	.7164	.9145	.9431	.7545
23	.823	.905	.5316	.8059	.7392	.8488	.7392
24	.9335	1.0374	.9431	.5373	1.0374	.7545	.8488
Max	1.3203	1.226	.9431	1.4146	1.386	1.4937	1.226
Min	.4858	.6068	.2058	.3125	.362	.0305	.5316
Avg	.9270	.9184	.5375	.7943	.9459	.8718	.8956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 206 / 11 KV GADEGAON GAOTHAN

SEPARATED GAOTHAN FEEDERS

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9617	.9586	.9827	.9608	.9562	1.0749	.3285
2	.9456	.9495	.9667	.9517	.9578	.9728	.7347
3	.8406	.9341	.9598	.9433	.9494	.9659	.8193
4	.8314	.9258	.949	.9357	.9479	.8726	.8033
5	.8246	.8528	.9149	.9197	.8429	.7749	.6341
6	.6455	.6849	.6367	.6455	.6775	.6828	.6274
7	.5468	.4786	.5651	.5572	.5834	.5563	.4557
8	.4329	.2808	.4614	.2317	.5312	.5412	.412
9	.546	.2235	.56	.1699	.2934	.5439	.4161
10	.3033	.592	.5916	.1211	.5921	.5605	.5433
11	.5906	.5981	.615	.3384	.7248	.7026	.5555
12	.7469	.7293	.7278	.6148	.7575	.7697	.5898
13	.7636	.7682	.7469	.8093	.8033	.88	.737
14	.7971	.7652	.7857	.8246	.8109	.9194	.7537
15	.7933	.7629	.7789	.4382	.8055	.9086	.7743
16	.756	.74	.7163	.74	.7652	.7873	.7652
17	.5993	.5975	.6752	.6442	.6378	.3811	.607
18	.5969	.5355	.5563	.5721	.5834	.4813	.5727
19	.711	.6882	.7217	.7286	.5849	.7034	.1562
20	.9465	.9541	.9571	.9373	.9782	.919	
21	.9625	1.0814	.9863	.9894	1.1233	.9663	.0015
22	.9787	1.0997	1.0936	1.0928	1.1225	1.0841	.1974
23	.9655	.9936	.986	.9913	1.1069	.9833	.3826
24	.9701	.983	.9598	.9654	.9913	1.065	.7347
Max	.9787	1.0997	1.0936	1.0928	1.1233	1.0841	.8193
Min	.3033	.2235	.4614	.1211	.2934	.3811	.0015
Avg	.7524	.7574	.7873	.7135	.7970	.7957	.5479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 401 / 33 KV Ashok Leyland Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1839	6.0842	5.7442	5.7727	6.0842	5.7928	5.8013
2	4.161	6.0842	5.5156	5.1869	5.5727	4.9725	5.3441
3	3.9323	5.5441	5.0098	5.1869	5.5441	5.1441	6.0299
4	3.9323	5.287	5.0098	4.5268	5.3155	4.0695	5.2898
5	3.8866	4.601	4.5725	4.2981	4.8297	4.2752	5.2898
6	3.8866	4.2066	3.7865	4.4125	4.1152	4.1152	5.0612
7	5.3983	5.8556	5.3983	5.3983	5.6813	4.8325	4.7783
8	6.5415	5.747	6.2586	6.5415	6.4329	6.0299	5.1212
9	6.7902	6.0842	7.0531	6.5615	6.3128	6.0013	5.0868
10	3.4294	5.5727	6.3128	6.3128	3.658	6.2814	4.4581
11	5.4641	5.0069	4.984	4.7554	4.4954	5.0069	3.115
12	4.7783	5.627	4.5496	5.5727	5.2898	5.5727	4.0438
13	5.4641	6.0299	5.2898	5.8013	5.2898	5.747	3.6694
14	6.2586	5.8013	5.3441	5.7156	5.8556	5.0612	3.858
15	4.9612	5.1898	5.0612	4.7554	6.0842	4.7326	4.0866
16	5.2126	5.8013	5.5727	6.0842	6.3128	5.8556	3.858
17	5.95	6.8787	5.8013	6.5958	6.0842	5.7213	3.5779
18	6.4872	6.5958	6.2586	7.5646	6.8245		4.321
19	6.3128	6.8245	6.3128	6.5101	7.0531	2.2634	3.6408
20	5.8013	6.0299	6.3672	6.0842	6.5958	5.0612	3.4808
21	6.8245	7.1074	6.8245	6.3128	6.8245	6.5958	4.2524
22	6.7701	7.2817	6.23	6.3128	7.0531	6.3672	3.6351
23	5.9757	6.3128	5.8242	6.0299	6.8245	6.1386	3.6008
24	4.6411	6.3128	5.7442	6.0013	6.0842	5.8556	1.829
Max	6.8245	7.2817	7.0531	7.5646	7.0531	6.5958	6.0299
Min	3.4294	4.2066	3.7865	4.2981	3.658	2.2634	1.829
Avg	5.2935	5.9111	5.6177	5.7623	5.8424	5.2823	4.3012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064020 / 33 KV MUJABI S/STN

Feeder No / Name : 201 / 11 KV SHAHAPUR AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.1981	.2134	.2134	.1829	.1829	.1219
2	.2134	.1981	.2134	.2134	.1829	.1829	
3	.2134	.1981	.2134	.2134	.1829	.1981	
4	.2134	.2134	.2286	.2134		.1829	
5	.2134	.2439	.2286	.2286		.1981	
6	.2439	.2591	.2286	.2439		.1981	
7	.2743	.2591	.2743	.3048	.2591	.2286	
8	.2743	.2896	.2743	.3048	.2858	.1981	.2286
9	.2743	.3048	.2743	.2743	.2591	.2229	.1829
10	.1543	.12	.3048	.2591	.2591	.2286	
11	.1715	.1715	.3048	.1981	.2134	.2105	.1981
12	.1372	.1372	.1219	.0857	.1219	.1029	.1677
13	.1372	.12	.1219	.0857	.1219	.1029	.1905
14	.1372	.1372		.1029	.1372	.1029	.1524
15	.1372	.1372		.0857	.1372	.1029	.1067
16	.1372	.1372	.1524	.0857	.1372		.1219
17	.1524	.1543	.1781	.0914	.1543		.1372
18	.1677	.1715	.1943	.1372	.1543		.1543
19	.1524	.1715	.1619	.1219	.1372		
20	.1372	.1543	.1457	.1219	.12	.1715	
21	.1219	.1372	.1296	.1219	.12	.1372	
22	.1067	.1372	.12	.1219	.12	.1372	
23	.0914	.12		.1219	.12	.1524	
24	.1372	.1829	.2134	.2429	.1677	.1829	.1219
Max	.2743	.3048	.3048	.3048	.2858	.2286	.2286
Min	.0914	.12	.12	.0857	.12	.1029	.1067
Avg	.1749	.1814	.2047	.1747	.1702	.1712	.1570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064020 / 33 KV MUJABI S/STN

Feeder No / Name : 202 / 11 KV MUJABI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3815	2.4768	2.4768	2.4958	1.7528	1.7528	1.7147
2	2.2862	2.3815	2.3624	2.3815	1.7337	1.6956	
3	2.2862	2.2672	2.21	2.2862	1.7337	1.6194	
4	2.21	2.0767	2.1148	2.2481	1.6575	1.4098	1.8099
5	2.0767	1.9433	1.7147	2.1338	1.6385	1.3717	1.848
6	1.5623	1.7147	1.6004	1.7718	1.5432	1.3527	1.8671
7	1.448	1.5242	1.2193	1.4098		1.1622	1.5623
8	1.4289	1.5051	1.2765	1.4861	1.0479	1.105	1.3908
9	1.6194	1.448	1.5242	1.6194	1.0669	1.1241	1.5051
10	1.5813	1.6194	1.6194	1.8099	1.3336	1.1241	1.5623
11	1.7718	1.6575	1.7337	1.6575	1.448	1.1622	1.6766
12	2.0386	1.9052	1.9433	1.8099	1.4861	.8954	1.848
13	2.2291	2.0767	1.9814	2.0576	1.5623	1.3146	1.9814
14	2.2481	2.1719	2.0386	2.0576	1.6385	1.5623	2.0767
15	2.1338	2.2291	2.0957	2.0005	1.5623	1.6766	2.0957
16	2.0767	1.9814	2.0767	1.9624	1.5051		2.1529
17	1.848	1.7147	1.7337	1.6004	1.2955		1.8099
18	1.5242	1.448	1.467	1.0288	1.105		1.7147
19	1.829	1.6575	1.6575	1.2193	1.2955		
20	2.0576	2.0386	2.0957	1.5051	1.5623	1.6385	
21	2.2481	2.2672	2.2862	1.6194	1.7147	1.6766	
22	2.3815	2.553	2.4387	1.848	1.7718	1.7718	1.467
23	2.4958	2.2481		1.848	1.7718	1.5242	1.5051
24	2.4768	2.5339	2.6673		1.7909	1.829	1.7718
Max	2.4958	2.553	2.6673	2.4958	1.7909	1.829	2.1529
Min	1.4289	1.448	1.2193	1.0288	1.0479	.8954	1.3908
Avg	2.0100	1.9767	1.9276	1.8199	1.5225	1.4384	1.7558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064020 / 33 KV MUJABI S/STN

Feeder No / Name : 203 / 11KV SATONA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6668	.5335	.6287	1.5051	1.4098	1.3336
2	.6478	.6668	.4954	.6287	1.467	1.3527	
3	.6478	.6097	.4572	.6287	1.3717	1.2955	
4	.6478	.5906	.4191	.6287	1.2384	1.086	
5	.5906	.5144	.381	.6097	1.1622	.9335	
6	.4001	.4191	.362	.362	1.0669	.9145	
7	.3048	.3048	.2096	.3429	.7621	.7811	
8	.3429	.4382	.4572	.4572	.6668	.9145	
9	.381	.5716	.5144	.4763	.9526	1.1241	
10	.381	.5716	.0953	.381	1.1622	1.2574	
11	.4763	.5906	.0953	.4572	1.448	1.3527	.0572
12	.6097	.6287		.6287	1.5051	1.3146	.5525
13	.7049	.6668		.724	.8002	1.6004	.6097
14	.5525	.6668		.8954	.743	1.5242	.6287
15	.6097	.5716		.8573	.9526	1.3717	.6478
16	.4572	.6287		.8954	1.2384		.6478
17	.4382	.6097	.0762	.7621	1.1812		.5906
18	.4763	.6478	.2096	.9907	1.105		.5716
19	.5144	.4954	.5716	1.1812	1.2384		
20	.6287	.5906	.6859	1.3146	1.3717	.381	
21	.7049	.6478	.6859	1.467	1.5432	1.0479	.5335
22	.7049	.6859	.724	1.5813	1.6004	1.4861	.6478
23	.7049	.5906		1.5432	1.5813	1.5242	.6287
24	.6859	.6859	.5716	.6478	1.5242	1.4861	1.4098
Max	.7049	.6859	.724	1.5813	1.6004	1.6004	1.4098
Min	.3048	.3048	.0762	.3429	.6668	.381	.0572
Avg	.5525	.5859	.4192	.7954	1.2162	1.2079	.6815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 202 / 11 KV Rajola Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.122	.2233					
11	.4344	.4305					
12	.4763	.4458	.3734	.314	.221	.1219	
13	.4763	.5121	.583	.5272	.3296	.2743	
14	.4763	.4725	.555	.5083	.2964	.3144	
15	.4725	.5076	.6165	.5045	.1417	.3449	
16	.5067	.6044	.6144	.5849	.4267	.2553	
17	.7316	.719	.8002	.6188	.5471		
18	.4382	.4344	.8383	.5806	.5457		
19			.8231	.5693	.5273		.0762
20			.7468	.4572	.442		
21			.7545	.4515	.3837		
22			.7278	.4138	.3863		
23			.7202	.4382	.3604		
24			.4153	.2858	.2629		
Max	.7316	.719	.8383	.6188	.5471	.3449	.0762
Min	.122	.2233	.3734	.2858	.1417	.1219	.0762
Avg	.4594	.4833	.6591	.4811	.3747	.2622	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 203 / 11 KV Shahapur Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.857	3.8668	3.8828	3.9784	3.9255	3.9876	3.7875
2	3.7551	3.7174	3.7433	3.9174	3.817	3.8672	3.6732
3	3.6599	3.5712	3.5597	3.8679	3.6906	3.7723	3.3859
4	3.5379	3.4156	3.4993	3.8113	3.633	3.6077	3.2236
5	3.2027	3.2747	3.2651	3.3425	3.4438	3.4461	3.0376
6	2.8296	2.8967	2.8521	3.0651	3.1526	3.0555	2.7717
7	2.3418	2.413	2.2405	2.7003	2.6147	2.7502	2.3502
8	2.1223	2.2063	1.2963	2.4473	2.3514	2.4866	2.1071
9	2.1254	2.3087	.8139	2.1258	2.3464	2.3716	2.1681
10	2.1216	2.335	.5213	1.1317	2.5017	2.5316	1.3452
11	2.5377	2.6192	.5693	2.5148	2.7643	2.7907	1.5672
12	2.7236	2.87	.6354	3.0582	3.0719	3.142	2.7285
13	2.9661	3.1375	2.9272	3.2426	3.2952	3.2632	2.8181
14	3.2731	3.2487	2.9436	3.3173	3.4705	3.4241	2.9241
15	3.3234	3.2991	3.6054	3.4454	3.4366	3.5566	3.0559
16	3.3211	3.2817	3.5787	3.36	3.2529	1.8099	3.3242
17	3.1001	3.0696	3.2693	2.9713	2.9647	.8063	3.1947
18	2.7381	2.8205	2.9711	2.6101	2.8144	1.2414	2.9805
19	2.6521	3.0369	3.0525	2.5248	2.7149	2.473	1.4137
20	3.3074	3.4023	3.4957	3.1971	3.413	2.9508	2.149
21	3.6094	3.5951	3.7579	3.5052	3.8288	3.2205	2.7473
22	3.8265	3.7081	1.9966	3.8981	4.1297	3.434	3.6763
23	4.0032	3.935	2.0843	4.0619	4.0916	3.8408	4.3713
24	3.9415	3.9751	3.9739	4.0725	3.9773	3.9754	4.0611
Max	4.0032	3.9751	3.9739	4.0725	4.1297	3.9876	4.3713
Min	2.1216	2.2063	.5213	1.1317	2.3464	.8063	1.3452
Avg	3.1199	3.1668	2.6890	3.1736	3.2793	2.9919	2.8693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 205 / 11 KV Explosive - I Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.9996	3.1931	3.0896		3.6579
2		2.8319	2.9645	2.945		3.3471
3		2.8144	2.8806	3.0974		2.9827
4		2.9797	3.2072	3.155		3.0102
5		3.1836	3.1405	3.0388		3.2754
6		2.9169	2.9257	2.8555		2.9234
7		2.3739	2.2491	2.172		2.0332
8		2.1739	1.0517	2.1304		1.1873
9		3.166	2.9832	2.8471		1.27
10		3.1203	3.1626	2.9493		1.4156
11		3.1663	2.9493	1.829		1.2681
12	1.9776	3.1813	2.2424			1.0707
13	2.4539	3.1584	2.8441			1.012
14	2.6444	3.6972	2.9843			.9495
15	3.0121	3.5067	3.1291			1.23
16	3.4179	3.6004	3.2779			1.8153
17	3.3645	3.5522	3.5163		1.5527	2.5941
18	3.1188	3.3989	3.7186		2.3911	2.6341
19	2.7987	3.0567	3.0758		2.9569	1.5318
20	2.7664	2.6881	2.6413		3.4713	.6249
21	2.6958	2.6498	2.5056		3.6903	
22	2.7046	2.5795	1.387		3.6865	
23	2.8296	2.7339	1.4403		3.674	
24	1.5927	3.0891	2.9728	1.4969	1.8976	1.8473
Max	3.4179	3.6972	3.7186	3.155	3.6903	3.6579
Min	1.5927	2.1739	1.0517	1.4969	1.5527	.6249
Avg	2.7213	3.0258	2.7685	2.6338	2.9151	1.9848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 206 / 11 KV Bhandara Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0914	.1524	.2324	.0838
10	.2896	.6097					
11	.8497	1.4365					
12	1.5356	1.4769	.7164	.7186	.6718	.3506	.0152
13	1.6194	1.7227	1.1786	1.8191	1.5996	.8802	.1028
14	1.1736	1.6796	.7131	1.9223	1.6491	1.1279	.2057
15	1.2232	1.6872	.8634	1.9223	1.6732	1.5013	.3429
16	.8306	1.672	.9376	1.7231	1.7403	.8497	.4534
17	1.2308	1.7071	1.0269	2.0119	1.7688	.2972	.5335
18	.8993	1.0136	1.0419	1.9509	1.7985	.6134	.3582
19	.2782	.1829	1.0593	1.7795	1.7383	.6821	.3544
20			.9592	1.5051	1.6111	.6592	
21			.885	1.4632	1.5455	.6173	
22			.8821	1.4518	1.5535	.5525	
23			.8687	1.4404	1.5219	.4839	
24			.4801	.8116	.8497	.2972	
Max	1.6194	1.7227	1.1786	2.0119	1.7985	1.5013	.5335
Min	.2782	.1829	.4801	.0914	.1524	.2324	.0152
Avg	.993	1.3188	.8933	1.4722	1.4196	.6532	.2722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 207 / 11 KV Awarmara Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	28-MAY-17
HR	Load (MW)
22	.381
23	.4877
Max	.4877
Min	.381
Avg	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 208 / 11 KV Explosive - II NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder Feeder KV- 11 / (CONTINOUS PROCESS)(NO STAGGERING)
 INCOMING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323		.5601	.6161	2.0957	1.9044	
2	1.2071		.5093	.6161	1.9052	2.1285	
3	1.1765		.4854	.5601	2.1529	2.2405	
4	1.1706		.4805	.4668		2.1285	
5	1.1584		.6979	.0747	1.9052	2.0144	
6	1.2071		.4066	.0747	1.7147	1.2012	
7	.7499		.2801		1.2193	1.307	
8	.4706	.0377	.112		1.4098	1.4901	
9	.7733	.0747	.1097		1.4003	1.3203	
10	1.226	.0373	.0739		1.1506	1.4146	
11	.2452	.2641	.0366	1.1431	2.0725	1.8107	
12	.0377	.3206	.1086	.9717	1.0642	1.4146	
13	.2829	.0739	.1097	.8383	.7167	1.1317	
14	.2452	.0739	.0366	1.0479	1.0562	1.0374	
15	.0377		.2033	1.3146	2.2032	1.4712	
16	.0754	.2427	.3142	1.848	1.9427	1.7353	
17		.4481	.6584	1.829	2.1658		
18	.2829	.3174	.6161	1.3908	2.0538		
19	.2075	.3174	.8048	1.2955	1.6804		1.0185
20	.0377	.6722	.7499	1.6766	1.6632		1.094
21		.6722	.7682	1.7718	1.6991		1.2637
22		.6722		1.7337	1.7551		1.1888
23		.6413		1.8671	2.0538		1.2696
24	1.1946		.5975	.6161	2.0576	1.7924	
Max	1.2323	.6722	.8048	1.8671	2.2032	2.2405	1.2696
Min	.0377	.0373	.0366	.0747	.7167	1.0374	1.0185
Avg	.6509	.3244	.3963	1.0876	1.7017	1.6202	1.1669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 209 / 11 KV Awarmara Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3191	1.2829	1.2186	1.3397	1.3485	1.3241	.2313
2	1.3146	1.2715	1.1864	1.3428	1.3162	1.3241	.2275
3	1.2851	1.2639	1.166	1.3283	1.2879	1.2978	.2275
4	1.1927	1.2601	1.1583	1.32	1.1984	1.2875	.2046
5	1.0981	1.2151	1.1096	1.1481	1.1682	1.2529	.1635
6	1.0273	1.0505	.9713	1.0581	1.1248	1.025	.1635
7	.8154	.82	.7293	.8162	.9351	.7331	.1254
8	.6394	.7743	.3582	.7506	.7682	.6969	.072
9	.8448	.7624	.7247	.3887	.3993	.7327	.0038
10	.8002	.8036	.7545		.1821	.8143	.0419
11	.8964	.8303	.8398		.4736	.9149	.061
12	1.0058	.935	.9343		1.0033	1.0172	.6157
13	1.0884	.9583	1.0096		.9411	1.1107	1.0783
14	1.1075	.9808	1.0158		1.1545	1.1036	1.1203
15	1.0891	.9473	.9838	1.0224	1.145	1.1058	1.0603
16	.9335	.8535	.8753	1.2761	.908	.5639	.9821
17	.8078	.7817	.7747	.921	.7038	.2549	1.0075
18	.7849	.6946	.7735	.7835	.7441	.1178	.7849
19	.7175	.9088	.9396	.868	.9648	.0934	.3925
20	1.2342	1.1025	1.185	1.225	1.1664	.9084	
21	1.2843	1.1679	1.3268	1.3866	1.4443	1.3626	
22	1.3702	1.2679	1.3637	1.4049	1.4637	1.3172	
23	1.366	1.3165	1.379	1.3948	1.3889	.663	
24	1.3268	1.2749	1.302	1.3664	1.3344	.7516	.056
Max	1.3702	1.3165	1.379	1.4049	1.4637	1.3626	1.1203
Min	.6394	.6946	.3582	.3887	.1821	.0934	.0038
Avg	1.0562	1.0218	1.0033	1.1127	1.0235	.9072	.4310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 401 / 33 KV SAINATH

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0792	.0448	.0448	.0448	.0566	.0566
2	.0604	.0792	.0336	.0444	.056	.0504	.0566
3	.0604	.0792	.0336	.0448	.0952	.0444	.0566
4	.0652	.0792	.0336	.0504	.084	.0509	.0566
5	.0706	.0849	.0448	.056	.0784	.0509	.0566
6	.076	.0905	.0504	.0672	.0336	.0509	.0283
7	.0329	.0396	.0554	.056		.056	.0566
8	.0165	.0453	.0504	.0448		.056	.0566
9	.0728	.0392	.0384	.028		.0962	.0549
10	.056	.0616	.0329	.0224		.0509	.056
11	.0616	.0622	.0329	.028		.0622	.056
12	.0448	.0448	.0384	.0672		.0453	.0543
13	.028	.0499	.0388	.0672	.0616	.0453	.0616
14	.028	.061	.0554	.0616	.0504	.0396	.0543
15	.0504	.0616	.056	.0952	.0504	.0962	.056
16	.0448	.0616	.0549	.112	.0896	.056	.0554
17	.0336	.0952	.0597	.0896	.0952		.0566
18	.0336	.084	.0597	.084	.0736		.0554
19	.0336	.0283	.0543	.084	.0672		.0792
20	.0336	.0396	.0494	.0952	.0672		.0962
21	.0336	.0504	.0597	.0952	.0616		.0962
22	.0566	.0504	.0504	.084	.056		.0494
23	.0792	.0448	.0444	.056	.056	.0309	.0384
24	.0494	.0736	.0444	.0448	.0336	.056	.0962
Max	.0792	.0952	.0597	.112	.0952	.0962	.0962
Min	.0165	.0283	.0329	.0224	.0336	.0309	.0283
Avg	.0490	.0619	.0465	.0635	.0641	.0553	.0600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 201 / 11kv korambhi (GAOTHAON)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5568	2.5339	2.5339	2.5606	2.5873	2.5644	2.5758
2	2.5072	2.4691	2.4691	2.6216	2.5758	2.5377	2.5034
3	2.4234	2.431	2.431	2.4958	2.5415	2.5911	1.2117
4	2.3701	2.3777	2.3891	2.4501	2.5111	2.4691	1.1812
5	2.3053	2.3205	2.3243	2.4006	2.5225	2.4387	1.9357
6	2.1757	2.2138	2.21	2.2939	2.3815	2.3815	2.0919
7	1.5966	1.6461	1.6499	1.6994	1.768	1.7795	1.6537
8	1.3451	1.3565	1.4251	1.4975	1.5013	1.5051	1.3603
9	1.3756	1.3756	1.3794	1.4022	1.4899	1.5318	1.4403
10	1.3603	1.4289	1.4175	1.4403	1.627	1.6423	1.4289
11	1.4632	1.448	1.4213	1.5661	1.8138	1.7718	1.3832
12	1.688	1.6194	1.6042	1.7871	1.9166	1.89	1.6651
13	1.9547	1.8366	1.8252	2.0538	2.1186	2.0233	1.8671
14	2.0462	1.9738	1.9928	2.1186	2.1757	2.2024	2.1567
15	2.0843	2.0233	2.1033	2.0957	2.191	2.2558	2.3053
16	2.0348	1.9966	1.9547	2.0538	2.1719	2.2253	2.3396
17	1.8404	1.7756	1.749	1.8404	1.9357	1.1088	1.9166
18	1.6309	1.4975	1.5356	1.5927	1.7337	.644	1.8557
19	1.5889	1.5356	1.5203	1.3756	1.5927	1.4022	1.7109
20	2.1948	2.2405	2.2329	2.0995	2.271	2.0652	.0876
21	2.4577	2.4844	2.5568	2.4501	2.5644	2.3282	.3353
22	2.5835	2.5758	2.6787	2.6863	2.694	2.6025	.6478
23	2.6292	2.6825	2.7206	2.7282	2.7206	2.7206	1.0174
24	2.5987	2.6406	2.6597	2.6673	2.652	2.694	1.8061
Max	2.6292	2.6825	2.7206	2.7282	2.7206	2.7206	2.5758
Min	1.3451	1.3565	1.3794	1.3756	1.4899	.644	.0876
Avg	2.0338	2.0201	2.0327	2.0824	2.1691	2.0573	1.6032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 204 / 11 KV MIDC Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6325	.7049	.1562	.6249	.6097	.644
2	.644	.6173	.5411	.1562	.5982	.6135	.6478
3	.6059	.6059	.6744	.1562	.5868	.5639	.644
4	.6325	.5373	.6783	.1562	.5144	.583	.0076
5	.5868	.5487	.6744	.1448	.522	.5487	.4915
6	.5296	.583	.5868	.1372	.5296	.5411	.5716
7	.5906	.602	.4001	.1715	.6211	.6173	.6363
8	.583	.5144	.2782	.1905	.5868	.5525	.5525
9	.5906	.5754	.2515	.2096	.5906	.5525	.5525
10	.7392	.7354	.2439	.4725	.6783	.7926	.6935
11	.8154	.804	.2934	.6744	.7888	.884	.7087
12	.8078	.8573	.2134	.7506	.8192	.8269	.6935
13	.7583	.8116	.2324	.8307	.8269	.8535	.7964
14	.6554	.7659	.202	.7583	.7583	.7583	.7011
15	.7164	.7506	.1829	.7811	.8269	.8535	.743
16	.8002	.8383	.1943	.8269	.823	.8421	.8421
17	.7849	.8154	.2248	.8421	.8612	.7468	.8497
18	.7545	.8078	.2058	.8497	.865	.8154	.7964
19	.6744	.663	.1753	.6363	.5906	.7202	.7468
20	.6706	.7125	.1829	.6249	.6478	.6935	.522
21	.6211	.5677	.1791	.5525	.5411	.6211	.5068
22	.6173	.5563	.1486	.5525	.5868	.6287	.5373
23	.6059	.5792	.1486	.6706	.6401	.6135	.5754
24	.6173	.6783	.1524	.6097	.6592	.6363	.5868
Max	.8154	.8573	.7049	.8497	.865	.884	.8497
Min	.5296	.5144	.1486	.1372	.5144	.5411	.0076
Avg	.6703	.6733	.3237	.4963	.6703	.6862	.6270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 402 / 33 KV Gadegaon Feeder

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	7.8732	7.5172	1.7541	.9991	1.3757	.9054	2.7366
16	9.3696	9.2181	.6916	.4275	.5247	.7122	1.3443
24	9.1101	10.0903	5.0972	.4801	.9145	.0686	.2058
Max	9.3696	10.0903	5.0972	.9991	1.3757	.9054	2.7366
Min	7.8732	7.5172	.6916	.4275	.5247	.0686	.2058
Avg	8.7843	8.9419	2.5143	.6356	.9383	.5621	1.4289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 403 / 33 KV Pahela Feeder

SHEDDABLE RURAL

INCOMER Feeder KV- 33 /
INCOMING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.166	1.2431	1.2963	1.17	1.3443	1.1437
16	2.1845	2.364	2.4143	2.1091	2.4143	2.0885	2.1325
24		1.8656	1.8656	1.9004	1.8656	1.8267	1.7558
Max	2.1845	2.364	2.4143	2.1091	2.4143	2.0885	2.1325
Min	2.1845	1.166	1.2431	1.2963	1.17	1.3443	1.1437
Avg	2.1845	1.7985	1.841	1.7686	1.8166	1.7532	1.6773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 404 / 33 KV KarachKheda Feeder PURELY LIS FEEDERS
Feeder KV- 33 / INCOMING

DATE	22-MAY-17	23-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.001	.0004	.0065	.0005	.0051
16	.0114	.0114	.0114	.0114	.0065	
Max	.0114	.0114	.0114	.0114	.0065	.0051
Min	.0114	.001	.0004	.0065	.0005	.0051
Avg	.0114	.0062	.0059	.0090	.0035	.0051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 406 / 33 KV TAKALI NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	14.4719	14.4033	14.4033	14.6777	14.8148	14.8834	14.4719
2	13.8546	14.0604	13.9232	14.0604	14.3347	14.5405	14.0604
3	13.3745	13.5117	13.5803	13.6489	14.0604	13.9918	13.4431
4	12.963	13.2373	13.1002	13.2373	13.5803	13.8546	9.7394
5	12.3457	12.62	12.62	12.7572	13.1687	13.5117	11.9342
6	11.5226	11.797	11.797	12.0028	12.4829	12.963	11.2483
7	10.0823	10.2195	10.0823	10.3567	10.974	11.3855	10.0823
8	8.5734	8.5093	8.5792	8.5309	11.581	9.4698	8.0981
9	8.2305	8.4362	8.5048	8.5734	9.0535	9.1907	7.8189
10	8.3676	8.2991	8.4362	8.9163	9.2593	8.8477	8.0933
11	8.8477	8.7792	8.4362	9.1907	9.808	9.2593	7.476
12	9.6708	9.6022	9.465	10.1509	10.631	9.9451	8.4362
13	10.4253	10.2195	10.4938	10.7682	11.3169	10.6996	9.3964
14	11.5226	11.2483	11.797	12.1399	12.0713	11.797	10.8368
15	12.2771	11.8656	12.1399	12.8944	12.8944	12.7572	12.0028
16	16.4198	13.1773	15.6408	16.9954	16.709	13.5071	12.2085
17	12.3457	10.2881	11.8656	12.7572	12.5515	7.7504	16.0094
18	11.3855	10.5624	10.7682	11.4541	10.7682	8.7106	11.2483
19	9.808	9.3964	9.3964	8.3676	10.2195	8.8477	9.465
20	10.974	10.6996	10.1509	10.2195	11.3855	10.0823	6.5158
21	12.0028	11.5226	12.0713	11.5912	12.2771	11.1111	11.3855
22	12.4829	12.2085	12.6886	13.1002	13.0316	12.0713	8.5734
23	13.2373	13.5803	13.8546	14.1976	14.129	13.786	10.2881
24	14.4033	18.8478	19.1987	19.4588	19.3758	19.1701	16.3324
Max	16.4198	18.8478	19.1987	19.4588	19.3758	19.1701	16.3324
Min	8.2305	8.2991	8.4362	8.3676	9.0535	7.7504	6.5158
Avg	11.6495	11.5455	11.7914	12.0853	12.5199	11.7556	10.7985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 202 / 11 KV Sunflag Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.5316	.7373					
11	.8059	.8402					
12	.9088	.8745	.8916	.703	.3601	.5316	.3944
13	.9431	.7888	.9774	.7888	.4115	.679	.4801
14	.9602	.823	.9774	.7888	.4287	.679	.5144
15	.9259	.8402	.9602	.7888	.3944	.679	.5658
16	.9945	.8745	.9774	.7373	.4287		.6173
17	.9431	.8916	1.0117	.7716	.6687		.6516
18			.9602	.6687	.6859	.5658	.6173
19			.8745	.583	.6344	.4904	
20			.8402	.3772	.5658	.4527	
21			.8059	.3772	.5658	.4527	
22			.7888	.3601	.5853	.4527	
23			.7716	.3429	.4973	.4527	
24	.583						
Max	.9945	.8916	1.0117	.7888	.6859	.679	.6516
Min	.5316	.7373	.7716	.3429	.3601	.4527	.3944
Avg	.8440	.8338	.9031	.6073	.5189	.5436	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 203 / 11 KV DABHA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5847	.6602	.6979
2		.547	.6036	
3		.547	.5658	.679
4		.5281	.5658	.6224
5		.5093	.5281	.5658
6		.415	.4715	.4338
7		.415	.415	.3961
8		.3772	.3961	.3584
9		.3584	.3584	.3584
10		.3961	.3961	.3584
11		.4338	.3961	.3584
12		.547	.4527	.4715
13		.6036	.5281	.4904
14		.6036	.5281	.547
15		.547	.5093	.5093
16		.415		.4338
17			.2829	.3772
18	.2829		.4338	.4338
19	.3961		.4904	
20	.5658	.7733	.6413	
21	.6036	.7922	.7167	
22	.679	.7733	.7545	
23	.6602	.7545	.7167	
24		.6224	.7167	.6979
Max	.679	.7922	.7545	.6979
Min	.2829	.3584	.2829	.3584
Avg	.5313	.5497	.5273	.4883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 205 / Sahakar Nagar Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8865	.811	.8676	.8676	.2829	.2263	.2452
2	.8865	.7922	.8299	.8299	.2641	.2075	
3	.8676	.7545	.7733	.7545	.2641	.2075	.2263
4	.8299	.7356	.7545	.6979	.2452	.2263	.2263
5	.7733	.7167	.679	.6413	.2263	.2263	.2263
6	.5847	.679	.547	.547	.2263	.2075	.1698
7	.4715	.5847	.5281	.4904	.1886	.1698	.1509
8	.415	.6602	.5281	.5093	.1886	.2075	.1509
9	.5093	.6602	.679	.6602	.3395	.2641	.2452
10	.7356	.7167	.6979	.7356	.4527	.3961	.3584
11	.4904	.7356	.7922	.7545	.4904	.415	.4338
12	.8299	.8488	.8488	.811	.4338	.0754	.415
13	.9619	.8865	.9431	.9054	.4527	.3961	.4527
14	.9431	.9054	.9619	.9808	.4527	.4527	.5093
15	.8676	.9431	.8676	.9997	.4338	.152	.4338
16	.8488	.7922	.8488	.8488	.3961		.415
17	.679	.679	.7356	.811	.3961	.3961	.3584
18	.6413	.679	.7356	.0566	.3395	.3395	.3206
19	.6602	.811	.8299	.2829	.3018	.3395	
20	.7545	.9054	.9808	.3206	.3206	.3018	
21	.7545	.8865	.9997	.3395	.3018	.2829	
22	.9431	.9997	.9808	.3395	.2641	.2641	
23	.8865	.9431	1.094	.3395	.2641	.2641	
24	.9054	.8676	.8865	.9242	.3206	.2452	.2452
Max	.9619	.9997	1.094	.9997	.4904	.4527	.5093
Min	.415	.5847	.5281	.0566	.1886	.0754	.1509
Avg	.7553	.7914	.8079	.6437	.3269	.2723	.3102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 206 / 11 KV MMKD Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6221	1.7541	1.8484	1.8484	1.9427	1.6975	1.8484
2	1.6598	1.6409	1.9239	1.8296	1.9993	1.6787	
3	1.5844	1.5844	1.9616	1.8107	1.8296	1.6787	
4	1.5466	1.6221	1.8484	1.7353	1.8107	1.6975	
5	1.3957	1.6032	1.773	.1698	1.8484	1.6975	
6	1.5089	1.6221	1.6032	1.6032	1.7918	1.6975	
7	1.5089	1.6032	1.6975	1.7353	1.5844	1.6221	
8	1.5844	1.5278	1.5466	1.8296	1.5844	1.6787	
9	1.6598	1.5844	1.406	1.7353	1.5844	1.6975	
10	1.5089	1.3392	1.5089	1.8107	1.7164	1.5844	1.5655
11	1.6787	1.7353	1.6461	1.7918	1.6598	1.7164	1.6221
12	1.6032	1.6221	1.5604	1.8296	1.773	1.7353	1.7164
13	1.6221	1.7353	1.5261	1.6598	1.8673	1.6975	1.4335
14	1.6032	1.6598	1.5261	1.7164	1.8484	1.2071	1.5844
15	1.6221	1.5655	1.4918	1.6598	1.773	1.6598	1.6598
16	1.6787	1.3957	1.2003	1.5089	1.773		1.6221
17	1.6975	1.905	1.4746	1.6409	1.7353	1.4901	1.6975
18	1.5089	1.5466	1.3203	1.6975	1.6032	1.5844	1.5089
19	1.6975	1.773	1.5775	1.6409	1.6975	1.7164	
20	1.6409	1.5844	1.4746	1.773	1.7918	1.6975	
21	1.6409	1.5278	1.5261	1.6975	1.773	1.7164	
22	1.6787	1.773	1.773	2.0559	1.949	1.773	
23	1.6221	1.9427	2.0936	2.0936	1.8861	1.9427	
24	1.5466	1.6598	1.6598	1.8861	1.8484	1.6975	1.905
Max	1.6975	1.9427	2.0936	2.0936	1.9993	1.9427	1.905
Min	1.3957	1.3392	1.2003	.1698	1.5844	1.2071	1.4335
Avg	1.6009	1.6378	1.6237	1.6983	1.7780	1.6680	1.6512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 401 / 33KV Incomer sunflag NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 33 / INCOMING UTILITY

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	19.8869	19.3896	19.3776	19.6846	19.8663	20.4476	20.0927
2	19.1118	19.0586	18.99	19.0347	19.1838	19.1633	19.1924
3	18.131	18.2031	18.2031	18.1345	18.5785	18.5014	18.0864
4	17.2188	17.2908	17.2222	17.2222	17.8601	17.6337	16.8107
5	16.0803	16.2654	16.2861	16.3786	17.1296	17.3149	15.7167
6	14.736	15.0789	14.9417	15.2607	15.8539	16.4712	14.429
7	12.879	12.6286	10.2195	10.4819	13.7792	11.4421	9.7394
8	8.0247	10.0497	6.31	9.9588	7.8875	11.7096	7.0645
9	12.4194	11.0031	12.1931	12.1811	13.5494	13.1053	12.8275
10	11.9273	11.6769	11.2774	11.4026	12.3508	12.0525	13.6591
11	12.0405	11.7096	12.6664	11.3906	11.9839	12.4966	14.0141
12	13.1225	12.6783	14.6039	12.2222	12.8721	13.5219	14.1067
13	13.7518	13.9541	16.202	13.7157	13.4568	14.8902	13.8409
14	16.1094	15.5761	17.5823	15.6087	13.6591	16.5775	15.9156
15	17.0576	16.545	18.0625	16.6136	15.3738	17.9699	17.1502
16	17.2668	16.6495	17.8121	16.6495	15.866	13.786	17.6629
17	16.2295	15.878	17.1536	15.6156	15.3859	7.236	17.0611
18	14.2713	14.0415	14.832	12.8258	13.8238	13.239	15.6396
19	12.8601	12.6783	13.0333	10.4064	13.167	13.4654	9.9451
20	14.8783	14.297	14.4908	13.6591	15.0274	14.0467	1.0751
21	15.7013	15.4269	15.8025	15.1406	16.3837	15.0274	6.4558
22	16.6907	16.4849	17.1468	17.3405	17.9784	16.2792	10.3549
23	17.9099	18.0659	19.5765	19.976	20.1698	19.4273	15.5967
24	19.5885	15.8316	19.7771	20.4115	20.7545	20.4561	17.4623
Max	19.8869	19.3896	19.7771	20.4115	20.7545	20.4561	20.0927
Min	8.0247	10.0497	6.31	9.9588	7.8875	7.236	1.0751
Avg	15.3289	15.0192	15.5734	15.0548	15.4976	15.2609	13.9125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 802 / 220 KV SUNFLAG

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 220 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	18.7472	24.9848	18.9644	19.5092	17.8327	18.7777	19.9513
2	18.9758	23.0872	21.3725	19.8141	19.3187	18.4843	18.0041
3	19.9246	23.4035	21.9746	19.8674	19.3187	20.8505	17.2001
4	20.9343	23.0872	18.7243	25.9107	19.8141	17.604	15.1235
5	22.5576	23.7197	17.7603	18.5948	19.2044	21.7117	20.0198
6	21.3992	15.8055	17.7641	19.7531	19.9132	18.3585	17.1011
7	16.7962	18.61	23.3196	14.8072	18.328	17.3145	17.5926
8	17.8022	18.107	15.8055	18.6367	18.0803	18.107	21.9479
9	20.2904	18.892	18.671	26.8176	17.2459	16.8267	22.0851
10	17.665	16.5752	13.7174	19.7531	18.2442	16.7734	24.8895
11	22.2527	18.5338	17.0096	20.3018	19.2654	17.7641	25.5144
12	20.3704	16.6438	18.3585	21.1477	21.4183	18.8234	21.6164
13	18.5185	15.1578	18.0803	18.892	23.1482	18.7777	31.1615
14	19.4445	15.8436	18.5338	20.2713	23.4721	18.4843	39.4567
15	18.8272	16.7238	20.2713	17.9546	22.0051	22.8853	21.262
16	19.997	15.9275	18.0041	20.0046	19.7531	14.7424	24.097
17	20.0618	20.5609	17.1468	17.2001	17.8022	22.5576	22.0851
18	18.9644	17.7641	18.5757	26.4251	17.5583	12.6886	24.3485
19	20.9343	18.7243	18.5757	17.3106	18.8234	27.8007	19.0444
20	23.3654	18.9644	23.1672	19.8141	19.6921	22.2908	18.5643
21	23.3654	19.8141	28.6542	20.3171	21.3992	20.1684	20.4847
22	24.3523	18.9644	22.8776	18.8996	18.7777	17.8327	27.5378
23	20.8734	18.6633	19.5664	21.6964	26.6995	19.4026	29.0467
24	19.6083	23.7464	22.5576	20.7705	19.2654	18.8234	18.7777
Max	24.3523	24.9848	28.6542	26.8176	26.6995	27.8007	39.4567
Min	16.7962	15.1578	13.7174	14.8072	17.2459	12.6886	15.1235
Avg	20.2512	19.2627	19.5605	20.1862	19.8492	19.0771	22.3713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 201 / 11 KV Ambedkar ward

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3222	1.3017	1.1294	1.3497	1.3451	1.3504	1.3474
2	1.294	1.3001	1.3558	1.3466	1.3398	1.3489	1.3115
3	1.2513	1.2095	1.3161	1.3092	1.8786	1.3153	1.2788
4	1.2201	1.1942	1.2704	1.2727	1.2598	1.2864	1.23
5	1.1926	1.1599	1.2186	1.2148	1.2514	1.2338	1.1927
6	1.147	1.1271	1.1629	1.1774	1.1927	1.2072	1.169
7	1.1119	1.0639	1.0951	1.0882	1.1119	1.1484	1.1264
8	.5365	.9595	.5578	.5426	.5479	.5563	.5533
9	.817	.8406	.8832	.8635	.8498	.8841	.8818
10	1.0334	1.0243	1.0289	1.06	1.0723	1.0593	1.0517
11	1.0167	1.0045	1.0258	1.0402	1.0578	1.0463	1.0326
12	1.0158	1.0083	1.0242	1.0296	1.0395	1.0379	1.0288
13	1.0379	1.0525	1.025	1.0433	1.0525	1.0647	1.0525
14	1.0624	1.0708	1.07	1.0586	1.0898	1.0761	1.0921
15	1.0944	1.1256	1.1348	1.1218	1.099	1.1188	1.1325
16	1.1332	1.1332	1.1554	1.1531	1.1271	.6142	1.1599
17	1.1042	1.1066	1.1431	1.102	1.1271	1.1256	1.166
18	1.0597	1.0821	1.0882	.5586	1.1218	1.0532	1.1492
19	1.0025	1.0289	1.0121	.8505	1.0319	1.0243	.5479
20	.8962	1.0494	1.0311	1.0341	1.0479	1.0555	.4954
21	1.0578	1.1035	1.1035	1.0799	1.0799	1.0966	1.0197
22	1.1639	1.166	1.1698	1.1554	1.198	1.1515	1.1005
23	1.2422	.6127	1.2209	1.3085	1.2994	1.2658	1.1607
24	1.3047	1.2342	1.326	1.339	1.3511	1.3489	1.2628
Max	1.3222	1.3017	1.3558	1.3497	1.8786	1.3504	1.3474
Min	.5365	.6127	.5578	.5426	.5479	.5563	.4954
Avg	1.0882	1.0816	1.1062	1.0875	1.1488	1.1029	1.0643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 202 / 11KV Sahakar Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.2269	6.2978	6.2953	6.467	6.4352	6.6659	6.2742
2	5.9476	6.0952	6.1499	6.1759	6.1397	6.4525	5.9583
3	5.6411	5.8657	5.8326	5.8558	5.9448	6.1995	5.5708
4	5.3515	5.3445	5.5022	5.6051	5.7331	5.9175	5.1932
5	4.9846	5.1868	5.0585	5.1868	5.4218	5.7202	4.8354
6	4.539	4.6068	4.6077	4.6182	4.8351	5.1234	4.4142
7	3.995	3.7197	3.8765	3.9819	4.1423	4.5252	3.9162
8	2.0378	3.4751	1.9547	2.0881	1.9029	2.2474	1.9685
9	3.8744	3.6462	3.6515	3.5469	3.943	4.0231	4.0185
10	4.0798	3.8534	3.7542	3.8554	4.1311	4.1206	4.2928
11	4.3024	4.0826	3.6304	3.7294	4.1123	4.2684	4.3415
12	4.667	4.3372	3.9305	4.0958	4.4044	4.6213	4.5503
13	5.0364	4.7072	4.3769	4.6195	4.7463	5.0755	5.048
14	5.683	5.4183	4.8708	5.2444	5.2037	5.6371	5.663
15	5.952	5.547	5.0816	5.5323	5.5666	5.6721	6.0616
16	5.7748	5.4969	5.0118	5.5104	5.4548	3.1062	6.0585
17	5.516	4.8533	4.7828	5.0399	5.1098	5.4079	5.7141
18	4.6007	4.4048	4.497	4.1465	4.718	4.6902	5.035
19	4.4254	4.2246	4.26	3.7904	4.5268	4.5208	2.2146
20	4.8643	4.5576	4.696	4.457	4.7981	4.7136	.1143
21	5.0633	4.8527	5.1258	4.9556	5.3651	4.9175	1.5638
22	5.2424	5.261	5.4526	5.6495	5.9991	5.3772	3.7365
23	5.567	6.1166	6.3108	6.4291	6.624	6.2348	4.8941
24	6.2727	6.1713	6.4421	6.5699	6.4956	6.6255	5.8969
Max	6.2727	6.2978	6.4421	6.5699	6.624	6.6659	6.2742
Min	2.0378	3.4751	1.9547	2.0881	1.9029	2.2474	.1143
Avg	4.9852	4.9218	4.7980	4.8813	5.0731	5.0776	4.4723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 203 / 11 KV KHAT ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4753	2.5667	2.4241	2.5972	2.6086	2.6734	2.5995
2	2.3563	2.4273	2.3647	2.4577	2.4951	2.5979	2.4852
3	2.2383	2.319	2.2527	2.3464	2.8075	2.4806	2.3639
4	2.175	2.2817	2.1354	2.1514	2.3373	2.3838	2.2238
5	2.0447	2.005	2.0569	2.0347	2.1537	2.2443	2.0851
6	1.8275	1.6446	1.8998	1.8862	2.0836	2.1056	1.8442
7	1.6469	1.4235	1.6637	1.6865	1.8724	1.9303	1.6195
8	.8162	1.2879	.7362	.9145	.9206	.9412	.7575
9	1.5158	1.0387	1.5295	1.5523	1.7581	1.6477	1.8267
10	1.3908	1.3328	1.4967	1.4808	1.6415	1.6103	2.1514
11	1.3809	1.4266	2.2794	1.5143	1.6293	1.6415	2.2649
12	1.5707	1.592	2.9401	1.72	1.7192	1.7482	1.8694
13	1.8344	1.7726	3.2617	1.8923	1.5059	1.9753	1.6057
14	2.0233	1.9616	3.2983	2.0912	1.2315	2.194	1.8313
15	2.0135	2.0035	3.1664	2.1011	1.5608	2.1217	1.9501
16	2.0264	1.9174	2.9874	2.0508	2.1514	1.1774	1.9616
17	1.9464	1.8298	2.7572	1.944	1.9562	1.9174	1.8763
18	1.7909	1.7109	2.1879	1.5196	1.8252	1.7215	1.7978
19	1.7917	1.7314	1.9242	1.4084	1.7977	1.6552	.9488
20	1.9875	1.9776	1.9388	1.8206	1.925	1.8313	1.2971
21	2.1056	2.0744	2.2764	2.0462	2.178	2.037	1.6301
22	2.338	2.2901	2.4387	2.4409	2.5598	2.3061	1.8161
23	2.5735	2.4425	2.6459	2.6901	2.7504	2.6192	2.1437
24	2.5621	2.6582	2.556	2.6475	2.7404	2.6893	2.4523
Max	2.5735	2.6582	3.2983	2.6901	2.8075	2.6893	2.5995
Min	.8162	1.0387	.7362	.9145	.9206	.9412	.7575
Avg	1.9347	1.9048	2.3008	1.9581	2.0087	2.0104	1.8918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 204 / 11 KV Kham Talao (Takiya SHEDDABLE URBAN
Ward) Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1327	2.2097	2.1121	2.2542	2.2576	2.2717	2.1948
2	***	***	2.0184	2.1841	2.2009	2.2093	2.1258
3	***	***	1.9589	2.082	2.1209	2.098	1.9776
4	1.9181	1.978	1.8572	1.9776	2.0268	2.0019	1.8195
5	***	***	1.7585	1.8206	1.8968	1.8503	1.653
6	***	***	1.6461	1.6911	1.7665	1.7406	1.5706
7	1.4483	1.4099	1.4293	1.4616	1.5043	1.5295	1.3954
8	***	***	.7133	.7179	.743	.772	.7049
9	***	***	1.2353	1.2437	1.3888	1.2708	1.2033
10	1.3051	1.2452	1.3028	1.3595	1.4258	1.3047	1.206
11	***	1.3832	1.4385	1.385	1.5295	1.4091	1.1561
12	***	1.5333	1.597	1.5843	1.6865	1.5882	1.2681
13	1.6583	1.723	1.7843	1.7791	1.8553	1.8187	1.4366
14	***	1.8854	1.9212	1.9448	1.989	1.9924	1.6655
15	***	.9579	1.8873	2.0218	2.0409	1.0181	1.7878
16	1.9338	.5954	1.9462	2.0047	1.9795	1.0349	1.8568
17	***	1.4979	1.8579	1.8789	1.8991	1.4235	1.7581
18	***	1.8484	1.781	1.592	1.6941	1.4338	1.6115
19	1.6091	1.6419	1.616	1.5249	1.7268	1.4868	.7827
20	***	1.7002	1.787	1.7284	1.8091	1.6579	1.1702
21	***	1.7695	1.8831	1.8068	1.9129	1.7421	1.2662
22	1.9382	1.8888	1.9586	2.0157	2.0439	1.901	1.1705
23	***	2.0938	2.0976	2.22	2.2268	2.1452	1.5504
24	***	2.2505	2.2172	2.2782	2.2805	2.2375	2.0648
Max	51.0332	50.9593	2.2172	2.2782	2.2805	2.2717	2.1948
Min	1.3051	.5954	.7133	.7179	.743	.772	.7049
Avg	34.4195	13.9160	1.7419	1.7732	1.8336	1.6641	1.5165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 205 / 11 KV Nashik Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.6218	5.7267	5.7933	5.708	5.9198	6.0128	5.9496
2	***	***	5.6051	5.4839	5.7073	5.8444	5.6463
3	***	***	5.3483	5.3216	5.567	5.6196	5.3407
4	5.1836	5.2216	5.0625	4.9619	5.3353	5.4161	3.9834
5	***	***	4.8125	4.603	5.141	5.0023	4.6853
6	***	***	4.2753	4.2692	4.7173	4.7036	4.1732
7	3.7723	3.6458	3.7037	3.7754	3.9285	4.167	3.6557
8	***	***	1.7513	1.7124	1.7261	1.9685	1.7566
9	***	***	3.3692	3.4568	3.5657	3.5155	3.2053
10	3.5063	3.459	3.3829	3.6938	3.8759	3.6839	3.3082
11	***	3.719	3.5216	3.9804	4.1708	3.895	3.3737
12	***	3.9895	3.9666	4.3485	4.5412	4.1472	3.8927
13	4.6129	4.2776	4.4673	4.6274	4.8149	4.6232	4.2433
14	***	4.6548	4.8469	5.141	5.1715	5.096	4.7988
15	***	4.8126	4.8598	5.288	5.2645	5.1349	4.9718
16	5.0937	4.8072	4.8285	5.2508	5.1524	2.6848	5.0442
17	***	4.3423	4.5818	4.7792	4.8491	3.443	4.7592
18	***	3.8104	4.2097	4.0163	4.5321	3.6214	4.2318
19	4.1367	3.8912	4.0306	3.7198	4.4049	3.9217	1.9395
20	***	4.5176	4.3835	4.4978	4.8719	4.3256	2.9576
21	***	4.8271	5.032	5.0206	5.1441	4.7142	3.9453
22	5.2241	5.1974	5.2522	5.3833	5.5693	5.3528	4.1343
23	***	5.6783	5.727	5.8916	5.8154	5.8719	4.6258
24	***	5.8684	5.8581	5.9259	5.9107	6.0273	5.4298
Max	52.8742	52.6226	5.8581	5.9259	5.9198	6.0273	5.9496
Min	3.5063	3.459	1.7513	1.7124	1.7261	1.9685	1.7566
Avg	36.3269	16.4508	4.5279	4.6190	4.8207	4.5330	4.1688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 206 / 11KV Station Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.278	1.228	1.259	1.3756	1.3009	1.3649	1.2979
2	***	***	1.2117	1.3092	1.2498	1.2963	1.2666
3	***	***	1.1675	1.2445	1.2392	1.2505	1.2376
4	1.0856	1.1218	1.1111	1.1865	1.1751	1.1884	1.1408
5	***	***	.9991	1.054	1.118	1.1164	1.0403
6	***	***	.8939	.948	.9839	1.0223	.9526
7	.7255	.712	.756	.8414	.8017	.8935	.8055
8	***	***	.2957	.3102	.3285	.3628	.298
9	***	***	.6969	.78	.7994	.8086	.7457
10	.7545	.7905	.6801	.7644	.8955	.8909	.8178
11	***	.7804	.743	.8832	.9709	.9347	.8292
12	***	.8448	.7884	.8894	.9548	1.0101	.8463
13	.8795	.8638	.8841	.9138	.9145	1.0631	.9381
14	***	1.0014	.9657	1.0357	1.1111	1.1054	1.0703
15	***	1.0837	1.0013	1.0997	1.1599	1.1481	1.2072
16	1.0021	1.0814	.9702	1.0654	1.1286	.6066	1.1413
17	***	.9824	.8409	.9831	1.0326	.6165	1.0585
18	***	.9023	.7884	.7088	.8718	.7392	.9145
19	.7248	.8002	.7675	.547	.8208	.7255	.426
20	***	.9358	.9747	.7669	.9952	.8924	.7991
21	***	1.0101	1.1393	1.0242	1.1317	.9998	.8581
22	1.156	1.1218	1.2608	1.2636	1.1778	1.1515	.9782
23	***	1.2674	1.3713	1.2765	1.3344	1.272	1.0993
24	***	.6729	1.3238	1.3626	1.3694	1.3417	1.2377
Max	50.5842	50.5087	1.3713	1.3756	1.3694	1.3649	1.2979
Min	.7248	.6729	.2957	.3102	.3285	.3628	.298
Avg	33.9052	13.3105	.9538	.9847	1.0361	.9917	.9586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 202 / 11 KV Civil Line Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	2.0195	2.0233	2.0386	2.1148	2.0919	2.0081
2	1.9357	1.9166	1.9624	2.0119	2.0424	1.989	1.9624
3	1.8633	1.8671	1.9052	1.9509	1.9547	1.9319	.0114
4	1.8061	1.8023	1.8328	1.8938	1.8976	1.89	1.8366
5	1.768	1.7452	1.7718	1.8595	1.8671	1.8519	1.8252
6	1.6766	1.7071	1.6918	1.7795	1.8138	1.8099	1.7032
7	1.5203	1.5203	1.5585	1.6156	1.6461	1.6613	1.5661
8	1.044	1.1279	1.1088	1.1355	1.4441	1.1584	1.086
9	1.4327	1.4746	1.467	1.528	1.4175	1.5508	1.4137
10	1.4822	1.4365	1.4822	1.4822	1.5623	1.5051	1.3413
11	1.7566	1.6347	1.7223	1.6918	1.7909	1.6537	1.4213
12	1.9585	1.8328	2.0005	1.9966	2.0957	1.8176	1.5508
13	2.1529	1.989	2.1605	2.13	2.2824	2.0386	1.688
14	2.2672	2.0424	2.2672	2.1453	2.3586	2.1376	1.7795
15	2.3396	2.1643	2.3472	2.2519	2.4425	2.1834	1.9776
16	2.3282	2.4272	2.2862	2.351	2.4501	2.1986	2.0195
17	2.2939	2.5492	2.2672	2.3358	2.431	1.9052	1.9357
18	2.1681	2.0271	2.1376	2.1757	2.2329	1.6461	1.8328
19	1.9433	1.7985	1.89	1.7223	1.9319	1.6728	1.5927
20	2.0348	1.8823	2.0119	1.9204	2.0995	1.8823	
21	1.9966	1.8823	1.9738	1.9547	2.0652	1.9166	1.6004
22	1.909	1.8023	1.9433	1.9738	1.9966	1.8442	1.5623
23	1.8747	1.9243	2.0157	2.0729	2.0043	1.9509	1.7071
24	1.9319	2.0043	2.0119	2.1224	2.1033	2.0195	1.7985
Max	2.3396	2.5492	2.3472	2.351	2.4501	2.1986	2.0195
Min	1.044	1.1279	1.1088	1.1355	1.4175	1.1584	.0114
Avg	1.8947	1.8574	1.9100	1.9225	2.0019	1.8461	1.6183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 205 / 11 KV Shastri Nagar Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4518	1.4784	1.4251	1.5089	1.528	1.5432	1.4861
2	1.3908	1.3946	1.4098	1.4556	1.4822	1.4861	1.4556
3	1.3451	1.3641	1.3565	1.4175	1.448	1.4594	1.3641
4	1.2879	1.3184	1.3146	1.3832	1.4022	1.4175	1.3489
5	1.2384	1.2879	1.2765	1.3375	1.3717	1.3832	1.2879
6	1.1927	1.2231	1.2117	1.2689	1.3108	1.3298	1.2117
7	1.0783	1.1088	1.1088	1.1317	1.1698	1.2193	1.1279
8	.7735	.8269	.8269	.8345	.9526	.8954	.823
9	1.044	.9755	1.0479	1.0517	1.1469	1.1088	1.025
10	.9831	.9107	.9755	1.0098	1.0555	1.0326	.9145
11	1.0517	.9869	1.0669	1.0631	1.1088	1.1012	.9526
12	1.2155	1.1317	1.2765	1.2803	1.3336	1.2765	1.1241
13	1.3832	1.2917	1.4556	1.4746	1.4632	1.4098	1.2727
14	1.4861	1.4251	1.5813	1.5508	1.547	1.5356	1.3984
15	1.5889	1.4632	1.627	1.6537	1.627	1.608	1.5165
16	1.608	1.3984	1.6651	1.669	1.6309	1.627	1.5356
17	1.5737	1.3908	1.6004	1.6309	1.5775	.7011	1.4975
18	1.4022	1.2879	1.4632	1.448	1.4746	1.3032	1.4022
19	1.3298	1.1622	1.3679	1.3184	1.4213	1.2879	1.3375
20	1.4822	1.2917	1.528	1.5089	1.5661	1.5089	.8688
21	1.5242	1.2841	1.5661	1.5394	1.608	1.5242	1.326
22	1.4937	1.307	1.5165	1.547	1.5813	1.4327	1.2155
23	1.4213	1.4022	1.448	1.5356	1.4899	1.4746	1.2727
24	1.4937	1.4365	1.528	1.5737	1.5432	1.5318	1.326
Max	1.608	1.4784	1.6651	1.669	1.6309	1.627	1.5356
Min	.7735	.8269	.8269	.8345	.9526	.7011	.823
Avg	1.3267	1.2562	1.3602	1.3830	1.4100	1.3416	1.2538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 206 / 11 KV Vidya Nagar Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9531	2.995	2.9607	3.075	3.0979	3.2427	3.0445
2	2.8006	2.8692	2.8311	2.9607	3.0369	3.1283	2.9264
3	2.6635	2.7435	2.7282	2.8235	2.9302	3.0026	2.7206
4	2.5149	2.6216	2.572	2.7016	2.8235	2.8883	2.5682
5	2.3777	2.4387	2.4082	2.5644	2.7282	2.7968	2.4158
6	2.21	2.271	2.2481	2.4234	2.5835	2.6901	2.2405
7	1.9204	1.9509	1.9166	2.0157	2.1529	2.2367	1.8938
8	.9717	1.0707	1.0174	1.0517	1.2841	1.1888	.9983
9	1.7604	1.7337	1.8557	1.7985	2.1224	1.4556	1.6918
10	1.6842	1.6347	1.7071	1.7261	1.9776	1.768	1.5889
11	1.8938	1.8557	1.9395	1.8976	2.1605	1.909	1.5966
12	2.1033	2.0881	2.1224	2.0995	2.3167	2.0957	1.7109
13	2.3129	2.3739	2.4006	2.4501	2.5758	2.3586	1.89
14	2.5758	2.5987	2.6635	2.713	2.8616	2.5835	2.2253
15	2.6673	2.6901	2.774	2.8235	2.9645	2.7168	2.3929
16	2.7206	2.6901	2.7587	2.8616	2.9531	2.7587	2.4463
17	2.6444	2.5835	2.6368	2.7702	2.8578	.8916	2.4006
18	2.3929	2.4348	2.4006	2.4196	2.5835	2.0119	2.1948
19	2.0386	2.0881	2.05	1.8747	2.2367	1.9662	1.9395
20	2.332	2.3396	2.3624	2.2405	2.5758	2.2596	.5677
21	2.4272	2.4272	2.5377	2.4425	2.7168	2.3548	2.05
22	2.5758	2.5453	2.7282	2.7549	2.8997	2.4958	2.0119
23	2.9531	2.9073	3.0902	3.0902	3.1398	3.0483	2.2481
24	3.0407	2.995	3.1626	3.1398	3.2731	3.1055	2.5149
Max	3.0407	2.995	3.1626	3.1398	3.2731	3.2427	3.0445
Min	.9717	1.0707	1.0174	1.0517	1.2841	.8916	.5677
Avg	2.3556	2.3728	2.4113	2.4466	2.6189	2.3731	2.0949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 208 / 11 KV Hospital Feeder NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.2477	.2591	.1905	.2629	.2591
2	.2362	.2591	.2439	.2515	.2477	.2515	.2477
3	.2324	.2591	.2439	.2515	.2401	.2477	.2439
4	.2324	.2553	.2439	.2515	.2362	.2324	.2401
5	.2286	.2515	.2439	.2667	.2324	.2286	.2401
6	.2286	.2553	.2439	.2896	.1905	.2286	.2401
7	.2782	.2972	.2858	.1715	.2743	.2172	.221
8	.2782	.2934	.2896	.2896	.2782	.2782	.282
9	.2782	.2896	.2934	.2896	.2667	.2553	.2477
10	.2782	.1753	.2439	.1981	.202	.202	.1867
11	.2477	.1638	.1753	.2896	.3734	.3048	.3086
12	.2058	.1829	.2782	.3086	.3963	.3163	.3086
13	.202	.1905	.3506	.2172	.3925	.3658	.2782
14	.3315	.1715	.3391	.2553	.381	.3582	.1943
15	.3125	.2477	.2743	.2591	.3201	.301	.2972
16	.3239	.3163	.3048	.3315	.3506	.2553	.2972
17	.3163	.3086	.2972	.3429	.3506	.301	.282
18	.3391	.3086	.2439	.3277	.2324	.3086	.2858
19	.3086	.2896	.3163	.2286	.3201	.2972	.2934
20	.3163	.2896	.301	.2286	.3125	.2096	.2248
21	.3086	.2972	.1943	.2591	.301	.2934	.2591
22	.2972	.2743	.2553	.2972	.3086	.2896	.2096
23	.1981	.2553	.2705	.3048	.3048	.282	.1486
24	.2705	.2515	.2705	.2248	.202	.1905	.2362
Max	.3391	.3163	.3506	.3429	.3963	.3658	.3086
Min	.1981	.1638	.1753	.1715	.1905	.1905	.1486
Avg	.2707	.2562	.2688	.2664	.2877	.2699	.2513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 201 / 11 KV Jamb Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8063	.8328	.7619	.8505	.7975	.7973	.8501
2	.8063	.8238	.7701	.8505	.8063	.7973	.8413
3	.8063	.8238	.7442	.8505	.7888	.7973	.8413
4	.7712	.8059	.7362	.8059	.7796	.7796	.8048
5	.7186	.7343	.7186	.7421	.7796	.7796	.724
6	.5083	.5373	.5373	.5316	.5373	.5847	.4706
7	.3856	.4835	.4887	.4656	.5014	.4784	.4706
8	.2629	.4252	.4344	.4656	.5068	.5138	.4119
9	.443	.4344	.4382	.4706	.5068	.4784	.5014
10	.4298	.4344	.5138	.5068	.5316	.5316	.4784
11	.5373	.5731	.5068	.5731	.5847	.5847	.4607
12	.6201	.5731	.591	.6556	.6556	.591	.4607
13	.691	.591	.6089	.6733	.7442	.6984	.5959
14	.7087	.6201	.6089	.691	.7087	.7059	.6588
15	.6556	.6379	.6201	.6268	.6733	.6805	.6733
16	.5316	.5373	.591	.543	.5847		.6733
17	.443	.4525	.5083	.4525	.4961		.591
18	.4607	.4525	.4287	.4706	.443	.5316	
19	.5316	.5552	.6268	.591	.567	.6024	
20	.691	.7087	.7421	.7186	.7265	.7499	.5611
21	.7619	.7537	.8048	.7975	.815	.8316	.691
22	.815	.8238	.9055	.8322	.8328	.9055	.7455
23	.8505	.7975	.8686	.8149	.8328	.9055	.7455
24	.8238	.8328	.7619	.8505	.8149	.8328	.8871
Max	.8505	.8328	.9055	.8505	.8328	.9055	.8871
Min	.2629	.4252	.4287	.4525	.443	.4784	.4119
Avg	.6275	.6352	.6382	.6596	.6673	.6890	.6427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 202 / 11 KV Andhalgaon Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8505	.8507	.924	.8402	.8573	.8954	.924
2	.8505	.8507	.9055	.8402	.8573	.905	.924
3	.8505	.8059	.9055	.8402	.8322	.8688	.924
4	.8505	.8145	.8316	.7975	.8322	.8688	.8501
5	.724	.724	.7499	.7186	.7888	.8507	.7682
6	.4755	.4887	.4961	.5316	.5493	.6154	.5194
7	.4163	.4119	.4525	.394	.4706	.5121	.4163
8	.4344	.4344	.4477	.394	.4557	.4706	.4298
9	.439	.4252	.4298	.4887	.5028	.5068	.4119
10	.4938	.4733	.5194	.5373	.5611	.5249	.3439
11	.567	.5434	.6036	.591	.6516	.6268	.4656
12	.695	.6485	.7316	.6556	.7164	.7421	.5731
13	.7701	.6588	.7682	.7537	.8059	.7783	.7087
14	.7602	.6588	.7316	.7537	.7343	.8048	.6201
15	.7442	.6859	.6878	.7186	.7164	.7682	.7087
16	.5731	.567	.5731	.6268	.6089		.6268
17	.5249	.5068	.4784	.4706	.543		.5373
18	.4607	.4706	.3772	.4344	.394	.4784	
19	.6036	.5784	.5973	.6556	.6516	.6447	
20	.7602	.7455	.8048	.7455	.8059	.7865	.0543
21	.8326	.8059	.9335	.8573	.9313	.9335	.6447
22	.8596	.8573	.9709	.8764	.9774	.9425	.6661
23	.8962	.8745	.9335	.8669	.9492	.924	.7628
24	.8775	.8688	.924	.9055	.8573	.9231	.924
Max	.8962	.8745	.9709	.9055	.9774	.9425	.924
Min	.4163	.4119	.3772	.394	.394	.4706	.0543
Avg	.6796	.6562	.6991	.6789	.7104	.7442	.6274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 203 / 11 KV Dhop Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2743	.2801	.2601	.2774	.2896	.2614
2	.2587	.2686	.2614	.2601	.2774	.2896	.2587
3	.2587	.2715	.2587	.2601	.2774	.2896	.2614
4	.2587	.2715	.2772	1.0749	.2804	.3077	.2218
5	.2587	.2715	.2587	.2427	.2804	.3077	.2033
6	.1663	.181	.1829	.1595	.1772	.2012	.181
7	.0924	.1646	.1448	.1772	.1417	.1097	.1075
8	.1294	.1267	.1254	.124	.1214	.1448	.1448
9	.128	.124	.1254	.124	.2058	.1829	.1448
10	.1463	.1086	.1254	.124	.1629	.1448	.124
11	.1463	.1734	.1254	.124	.1646	.1463	.124
12	.1829	.1734	.181	.1753	.1991	.2012	.1753
13	.2172	.1753	.1991	.208	.1991	.2172	.2254
14	.2195	.1753	.1629	.1907	.2195	.2172	.2254
15	.2012	.1734	.1991	.1753	.2195	.2172	.2229
16	.1463	.1267	.181	.1417	.1629		.1595
17	.1267	.1134	.1448	.1267	.1663		.1595
18	.2012	.1134	.1075	.1267	.1086	.1629	
19	.2012	.1581	.181	.2103	.1791	.1629	
20	.2743	.2454	.2772	.2427	.2686	.2957	.1753
21	.3109	.2469	.3174	.2774	.3077	.2801	.2254
22	.3077	.2343	.3174	.298	.3012	.2801	.2401
23	.2926	.2343	.2772	.2774	.3077	.2987	.2254
24	.2587	.2926	.2801	.2601	.2774	.2896	.2772
Max	.3109	.2926	.3174	1.0749	.3077	.3077	.2772
Min	.0924	.1086	.1075	.124	.1086	.1097	.1075
Avg	.2101	.1958	.2080	.2350	.2201	.2289	.1975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 204 / JAMB AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0122						
10	1.2117	1.2428					
11	1.6133	1.7669					.0709
12	1.7726	1.7437	1.4144	1.2723	1.3131	1.374	.8164
13	1.7337	1.7178	1.9031	1.7131	1.6606	1.7733	1.2589
14	1.6446	1.7223	1.8576	1.7162	1.7314	1.7044	1.2426
15	1.5363	1.7078	1.7547	1.6356	1.669	8.5528	1.2788
16	1.6453	1.7909	1.8665	1.6762	1.8099	.2462	1.2772
17	1.7695	1.8549	1.9277	1.4568	1.8838		1.387
18	.9823	.9938	1.8332	1.7133	1.8389	.9111	.7705
19			1.711	1.5707	1.6598	1.1382	
20			1.6427	1.4914	1.5028	1.0174	.0008
21			1.6102	1.4708	1.4814	1.028	
22			1.5958	1.4563	1.4586	.9874	
23			1.5789	1.442	1.4396	.979	
24	.6371		.8756	.7926	.8147	.5388	
Max	1.7726	1.8549	1.9277	1.7162	1.8838	8.5528	1.387
Min	.0122	.9938	.8756	.7926	.8147	.2462	.0008
Avg	1.3235	1.6157	1.6593	1.4929	1.5587	1.6876	.9003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 205 / Andhalgaon AG Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4008	3.2769	3.3246	2.9552	2.7387	2.3548	
2	3.3627	3.2007	3.2865	2.8975	2.7387	2.3167	
3	3.3189	3.2007	3.2865	2.912	2.6779	2.3167	
4	3.3627	3.2007	3.2484	2.8563	2.6779	2.3167	
5	3.3246	3.1626	3.2865	2.8944	2.7206	2.3167	
6	3.5452	3.2084	3.4189	3.3074	2.668	2.3777	
7	3.8275	3.8637	3.6075	3.5886	3.011	2.1719	
8	3.5631	3.9476	3.7448	3.8767	3.1049	2.1719	
9	3.5894	3.7827	3.9734	3.8589	3.283	1.6385	2.5625
10	2.3243	2.4387	3.9551	3.7854	2.9417	2.652	2.2853
11			3.5955	2.745	2.9417	2.7434	2.4177
12			2.3243	1.829	1.829	1.6766	2.5457
13							2.5457
14							2.6017
15							2.5369
16							2.4945
17							1.7147
24	2.7816	3.2922	3.0198	2.7492	2.472	.3514	
Max	3.8275	3.9476	3.9734	3.8767	3.283	2.7434	2.6017
Min	2.3243	2.4387	2.3243	1.829	1.829	.3514	1.7147
Avg	3.3092	3.3250	3.3901	3.0966	2.7542	2.1081	2.4116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 207 / Dhop Agp

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.7468	.7907					
11	.7621	.8065					
12	.823	.828	.8916	.8065	.7164	.6859	.5693
13	.8078	.8223	.8745	.8065	.7011	.823	.5693
14	.7926	.828	.8916	.8124	.6859	.8059	.5535
15	.7773	.8436	.8573	.8065	.7011	.823	.5693
16	.7773	.8179	.8745	.8333	.7164		.6009
17	.7926	.8078	.8916	.8065	.7011		.6167
18			.823	.7907	.7011		
19			.823	.7125	.7011	.6516	
20			.7716	.7287	.6859	.6173	.4641
21			.8402	.7287	.6706	.6001	.4049
22			.7716	.6882	.6554	.6001	.4049
23			.7545	.7125	.6554	.6001	.4049
24	.7712						
Max	.823	.8436	.8916	.8333	.7164	.823	.6167
Min	.7468	.7907	.7545	.6882	.6554	.6001	.4049
Avg	.7834	.8181	.8388	.7694	.6910	.6897	.5158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 206 / 11 KV Chichkheda Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9929	2.9458	2.8848	2.9721	2.9746	3.023	2.4795
2	3.0396	2.5667	2.8322	2.9344	2.9439	3.023	2.3441
3	3.0079	2.8433	2.7549	2.8879	2.9516	3.0184	2.335
4	2.9607	2.9592	2.6741	2.8349	2.9378	3.0011	2.3285
5	2.9273	2.9988	2.6113	2.7587	2.9836	3.0133	2.3392
6	2.726	2.7179	2.2927	2.3476	2.5465	2.6719	1.9928
7	2.403	2.6562	1.4045	1.4442	1.5813	1.7474	1.27
8	2.4996	2.7256	1.2932	.7842	.8621	1.318	.865
9	2.6765	2.8513	1.3462	.8025	1.0007	1.129	1.5202
10	1.7801	1.7192	1.5154	1.2048	1.0117	1.5725	1.7467
11	1.5584	1.6099	1.701	1.7886	1.1366	1.7989	2.099
12	1.9957	1.9913	3.2652	3.2636	1.7444	2.8814	1.4709
13	2.2066	2.2672	3.7386	3.6732	1.9516	3.1664	2.1282
14	2.2786	2.3187	3.6054	3.4839	3.0353	3.0956	2.2634
15	2.2192	2.2405	3.5572	3.2522	3.3417	3.1363	2.2664
16	1.893	1.9154	3.2783	3.1463	3.0666	1.5767	2.0679
17	1.5066	1.443	3.0826	2.7607	2.8327		1.6042
18	1.2741	1.2906	3.0106	2.6244	2.865		1.2041
19	1.6854	1.7745	3.1811	2.7146	2.8686		.6805
20	2.7583	2.7347	3.4145	2.9234	3.0254	1.0199	1.8132
21	3.0948	3.0666	3.4157	3.1784	3.1036	2.7118	2.582
22	3.1638	3.0967	3.5433	3.2426	3.2602	2.7423	2.7191
23	3.0795	3.0384	3.6451	3.0849	3.1595	2.5968	2.7563
24	3.6832	3.6877	2.7538	2.5804	2.5913	2.0688	3.2918
Max	3.6832	3.6877	3.7386	3.6732	3.3417	3.1664	3.2918
Min	1.2741	1.2906	1.2932	.7842	.8621	1.0199	.6805
Avg	2.4755	2.4775	2.7834	2.6120	2.4907	2.3958	2.007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 207 / 11 KV Pardi Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.815	.7796	.4801	.4458	.4854	.4854	.7164
2	.815	.7011	.4287	.4287	.4733	.4854	.6984
3	.7888	.7011	.3772	.3429	.4733	.4681	.6984
4	.7888	.7186	.3258	.2572	.4557	.4681	.6626
5	.7628	.7186	.3086	.2401	.4733	.4681	.6154
6	.5365	.6173	.2915	.2229	.2481	.333	.4161
7	.5596	.6173	.2058	.2229	.1772	.1886	.3239
8	.4862	.6344	.2058	.2401	.2486	.1029	.3353
9	.5596	.6344	.2058	.2229	.2572	.2229	.3978
10	.2035	.1886	.2229	.2572	.2543	.2294	.4409
11	.2543	.2543	.2683	.3018	.1543	.1475	.4854
12	.2883	.3391	.6935	.5375	.6173	.6661	.2543
13	.373	.3601	.7628	.6859	.6173	.7362	.3429
14	.3258	.3772	.7455	.6859	.703	.7888	.3601
15	.3601	.3429	.6241	.6173	.6859	.6935	.3601
16	.1372	.2713	.6613	.583	.6722		.2743
17	.2401	.1966	.5365	.4475	.4801	.4167	.2374
18	.1715	.1543	.5935	.3978	1.2003	.4588	.1715
19	.1715	.2229	.5935	.5658	.6241	.5895	
20	.4508	.4287	.6443	.6661	.6687	.6379	.3294
21	.4477	.463	.763			.7164	.4252
22	.5316	.5144	.7461	.7619	.7796	.7343	.4681
23	.5138	.4801	.7842	.7265	.8328	.7164	.4508
24	.815	.815	.4801	.463	.4854	.4854	.7164
Max	.815	.815	.7842	.7619	1.2003	.7888	.7164
Min	.1372	.1543	.2058	.2229	.1543	.1029	.1715
Avg	.4749	.4805	.4979	.4487	.5247	.4887	.4427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 208 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5407	.6862	1.2761	.8413	.6984	.8729	.7956
2	.5213	.6725	1.219	.8135	.6691	.8821	.7591
3	.5407	.6535	1.1561	.751	.6741	.8383	.7948
4	.5258	.6573	.9713	.7065	.615	.852	.7971
5	.5281	.6565	.9469	.7106	.6321	.8772	.8475
6	.5033	.6036	.967	.7121	.5739	.8764	.735
7	.4645	.5106	1.1256	.5864	.527	.7506	.6333
8	.557	.5056	.9743	.7712	.4934	.652	.6169
9	.5384	.4824	.9408	.7266	.6352	.6218	.6542
10	.6451	.847	.8706	.6664	.5822	.5662	.582
11	.7335	1.0102	.8562	.6527	.6245	.5849	.6104
12	.6889	1.3447	.9149	.5541	.6576	.5735	.6112
13	.7182	1.3539	.9419	.5197	.6794	.5437	.5956
14	.5967	1.1545	.7728	.5826	.7449	.6131	.6246
15	.53	1.0288	.5312	.5437	.7639	.7495	.6086
16	.6314	.9792	.5731	.5163	.6973	.3887	.6086
17	.6207	.8974	.6455	.5289	.7194	.6268	.6317
18	.8044	.7324	.7198	.5453	.6181	.7217	.6378
19	.8574	1.0158	.6169	.551	.6308	.7968	.2896
20	.7724	.9042	.5167	.551	.6828	.7796	.3921
21	.7392	.7571	.572	.5464	.695	.7666	.7545
22	.5452	.6953	.5804	.6257	.6546	.7727	1.6533
23	.6135	.9213	.9038	.6287	.6996	.82	2.9169
24	.6451	.8779	1.0761	.7026	.7213	.8703	1.8976
Max	.8574	1.3539	1.2761	.8413	.7639	.8821	2.9169
Min	.4645	.4824	.5167	.5163	.4934	.3887	.2896
Avg	.6192	.8312	.8612	.6389	.6537	.7249	.8353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 209 / 11 KV Mohadi Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4668	.4668	.4294	.4854	.4854	.4854
2	.4108	.4294	.4294	.4108	.5041	.4481	.4294
3	.4294	.4108	.3734	.3734	.4854	.4481	.4294
4	.3921	.4108	.3547	.3734	.4668	.4294	.4108
5	.3734	.3734	.3361	.3547	.4294	.4294	.4108
6	.2987	.3361	.3174	.3174	.3547	.3734	.3174
8	.2987	.2987	.2801	.2987	.2987	.3174	.2987
9	.2801	.2801	.2801	.3174	.3547	.2987	.2614
10	.2801	.2614	.2987	.2987	.3547	.3361	.2543
11	.3174	.3174	.3361	.3174	.3361	.3547	.2774
12	.3174	.3921	.3734	.3547	.3921	.3921	.3052
13	.3921	.3921	.3921	.3921	.4294	.4108	.3601
14	.4108	.3921	.3921	.4294	.4294	.4294	.3921
15	.3734	.4108	.3734	.4108	.4294	.4294	.4108
16	.3361	.3361	.3734	.3361	.3361		.3734
17	.2987	.2987	.2987	.2987	.3174	.2427	.3361
18	.2614	.2801	.2614	.2241	.2743	.3174	.2801
19	.3174	.3361	.3361	.2987	.3467	.3361	
20	.4108	.3921	.3921	.3547	.4668	.3734	.2987
21	.4108	.4294	.4481	.4481	.3361	.4481	.3361
22	.4668	.4854	.4668	.4854	.5041	.5041	.4108
23	.4668	.4668	.4481	.4854	.4854	.5041	.4294
24	.4481	.4668	.4668	.4481	.4854	.4854	.5041
Max	.4668	.4854	.4668	.4854	.5041	.5041	.5041
Min	.2614	.2614	.2614	.2241	.2743	.2427	.2543
Avg	.3653	.3767	.3694	.3677	.4045	.3997	.3642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 210 / Kanhalgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8908	.8404	.8394	.8688	.8969	.8779	.6722
2	.8693	.8131	.8155	.847	.8992	.8763	.6238
3	.8413	.8108	.7944	.8254	.8924	.8537	.5864
4	.8565	.7888	.7838	.7952	.887	.8484	.6028
5	.865	.7888	.7629	.7579	.8733	.8718	.6421
6	.7986	.7648	.6176	.6226	.6262	.6851	.5323
7	.7506	.6901	.3951	.4111	.4607	.4443	.4452
8	.676	.7053	.3562	.3578	.3521	.346	.4443
9	.6583	.7072	.3509	.3578	.4085	.2835	.4222
10	.4247	.434	.3692	.3669	.4202	.3559	.4022
11	.3767	.3599	.4138	.4237	.6241	.3978	.3896
12	.4735	.5112	.7512	.7701	.7404	.6866	.3661
13	.5352	.615	.8604	.8558	.8047	.8444	.5239
14	.6028	.6527	.8507	.8284	.9008	.865	.5601
15	.5823	.6173	.7727	.8395	.7701	.8097	.6005
16	.4778	.5163	.7554	.7808	.735	.4435	.543
17	.3821	.3673	.74	.711	.7217	.4208	.4629
18	.3186	.3395	.7629	.6777	.6752	.4584	.4225
19	.4298	.4344	.7807	.7018	.698	.5609	
20	.7259	.7423	.9486	.7971	.7933	.6413	.603
21	.815	.8566	.9355	.8465	.8358	.7225	.7236
22	.884	.9077	.9393	.9277	.805	.7385	.8133
23	.9099	.8829	.9439	.9061	.7867	.7091	.8339
24	1.1004	1.069	.8143	.8208	.7757	.5601	.966
Max	1.1004	1.069	.9486	.9277	.9008	.8779	.966
Min	.3186	.3395	.3509	.3578	.3521	.2835	.3661
Avg	.6769	.6756	.7231	.7124	.7243	.6376	.5731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 212 / Dongargaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1763	1.0456	.2801	.2614	.2614	.2614	.7468
2	1.1389	1.0456	.2614	.2427	.2614	.2241	.7282
3	1.1203	1.0456	.2241	.2241	.2427	.2241	.7095
4	1.1203	1.0082	.1867	.1867	.2614	.2427	.7282
5	1.0456	1.0082	.168	.168	.2614	.2614	.7095
6	1.0456	.9896	.1494	.1494	.1494	.168	.5975
7	.9709	.9709	.0934	.112	.1307	.1307	.5041
8	.9522	1.0269	.0934	.0747	.1307	.0934	.5601
9	1.0269	.9335	.3361	.112	.1307	.112	.5415
10	.1307	.0934	.1307	.1307	.1307	.1307	.5426
11	.1494	.1307	.1494	.1494	.8962	.1494	.5895
12	.1867	.168	.9522	.8215	.8589	.8589	.2241
13	.2054	.1867	.9335	.8962	.8775	.8589	.168
14	.2054	.2054	.9522	.8962	.8775	.8402	.1867
15	.1867	.2054	.8775	.8402	.8402	.7842	.2054
16	.1307	.1494	.8775	.8029	.8029		.1494
17	.112	.112	.9522	.7655	.8215		.1307
18	.0934	.0934	.8962	.7842	.703	.4294	.0747
19	.1494	.112	.9149	.8029	.7628	.7282	
20	.2614	.2427	.9709	.8402	.8589	.7842	.1867
21	.2614	.2614	1.0269	.8962	.9149	.7842	.2427
22	.2801	.2801	1.0456	.9149	.9149	.7842	.2614
23	.2801	.2801	1.0082	.8962	.9149	.7842	.2427
24	1.1389	1.0829	.2801	.2614	.2614	.2614	.7842
Max	1.1763	1.0829	1.0456	.9149	.9149	.8589	.7842
Min	.0934	.0934	.0934	.0747	.1307	.0934	.0747
Avg	.5570	.5282	.5734	.5096	.5528	.4498	.4267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064033 / 33 KV Kardi

Feeder No / Name : 201 / Kardi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.0562	1.543					
11	1.5261	1.7101					
12	1.6118	1.6575	1.5769	1.4754	1.543	1.3904	1.3413
13	1.6095	1.7238	1.046	1.6617	1.5257	1.4419	1.4255
14	1.6598	1.5927	1.56	1.6095	1.5261	1.5769	1.3592
15	1.6617	1.6244	1.5927	1.6598	1.5604	1.1934	1.4251
16	1.6787	1.5592	1.6766	1.7126	1.6108	1.1401	1.4074
17	1.6817	1.5893	1.7126	1.6933	1.6278	1.1361	1.4413
18			1.6108	1.7126	1.6263	1.2517	
19			1.5089	1.5927	1.56		
20			1.4413	1.6108	1.5091	1.3735	
21			1.4413	1.5939	1.4922	1.3375	
22			1.4575	1.5424	1.4582	1.3226	.7202
23			1.3735	1.5261	1.4582	1.3077	.78
24	1.0004						
Max	1.6817	1.7238	1.7126	1.7126	1.6278	1.5769	1.4413
Min	1.0004	1.543	1.046	1.4754	1.4582	1.1361	.7202
Avg	1.4984	1.625	1.4998	1.6159	1.5415	1.3156	1.2375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064033 / 33 KV Kardi

Feeder No / Name : 202 / Koka Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	2.0062	1.5746	1.7465	1.7318	1.8143	1.7635
2	2.0178	2.0111	1.6244	1.6956	1.6956	1.7939	1.6933
3	1.9839	1.989	1.6263	1.7147	1.6933	1.7804	1.6956
4	1.95	1.8945	1.4746	1.7318	1.6787	1.7147	1.6975
5	1.8652	1.8652	1.5091	1.647	1.6448	1.6448	1.56
6	1.8143	1.7511	1.4089	1.6124	1.6289	1.6289	1.4251
7	1.7436	1.6632	1.4752	1.5604	1.543	1.5261	1.4403
8	1.7661	1.6933	1.5261	1.439	1.4922	1.543	1.4243
9	1.8755	1.6278	1.5091	1.5604	1.5769	1.56	1.4413
10	1.8724	1.5912	1.4922	1.647	1.6461	1.4243	1.406
11	1.8004	1.6575	1.4752	1.6632	1.6461	1.6118	1.4083
12	1.8519	1.6712	1.6598	1.7337	1.5592	1.7147	1.4243
13	1.8004	1.7404	1.6598	1.6804	1.6263	1.7465	1.5415
14	1.6766	1.6766	1.6787	1.6598	1.7126	1.7604	1.5746
15	1.5261	1.6263	1.6263	1.6448	.3077	1.56	1.4918
16	1.3413	1.5581	1.6448	1.3748	.929	1.4922	1.4754
17	1.335	1.4918	1.6278	1.543	1.4575	1.2378	1.3413
18	1.6124	1.5729	1.6598	1.543	1.6461	1.2407	
19	1.9719	1.6385	1.7318	1.6263	1.7147	1.4413	
20	2.0978	1.8067	1.8275	1.7804	1.9281	1.5074	
21	1.9719	1.7295	1.95	1.7939	1.7604	1.8067	
22	2.2192	1.7436	1.9839	1.7804	1.8778	1.7939	
23	1.9982	1.6575	1.6975	1.6263	1.8313	1.7604	
24	2.0687	1.989	1.643	1.7635	1.7974	1.8519	1.7604
Max	2.2192	2.0111	1.9839	1.7939	1.9281	1.8519	1.7635
Min	1.335	1.4918	1.4089	1.3748	.3077	1.2378	1.3413
Avg	1.8405	1.7355	1.6286	1.6487	1.5886	1.6232	1.5314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064033 / 33 KV Kardi

Feeder No / Name : 203 / Kardi Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6613	.6706	.6687	.7011	.6344	.6516
2	.6415	.6344	.6443	.6588	.6733	.6344	.6588
3	.6068	.6068	.6613	.6135	.6626	.6068	.6173
4	.5609	.5658	.5868	.6135	.5973	.5895	.5548
5	.5258	.5087	.4115	.5373	.4706	.5609	.4908
6	.4252	.3944	.3772	.4477	.4207	.5258	.4298
7	.3258	.3601	.333	.3439	.3814	.3366	.1629
8	.333	.3601	.3258	.3841	.3429	.2865	.3155
9	.3721	.3222	.333	.3881	.3601	.3582	.2947
10	.3544	.3391	.3544	.3982	.3814	.3258	.3121
11	.4477	.407	.3155	.4938	.4207	.3155	.3258
12	.4961	.463	.4681	.462	.4508	.3814	
13	.4733	.4917	.4973	.4854	.5144	.4607	.4115
14	.4334	.4748	.5144	.462	.583	.5487	.3772
15	.4287	.463	.5028	.4706	.5201	.4031	.39
16	.4161	.4458	.4854	.4477	.4334	.3601	.3601
17	.394	.3641	.3681	.3721	.3681	.3155	.3641
18	.4525	.1829	.394	.394	.3721	.3366	
19	.5258	.3772	.2715	.2534	.4854	.4334	
20	.6241	.5765	.583	.6089	.6001	.5316	
21	.6415	.5935	.6935	.6878	.6344	.6036	
22	.6859	.6613	.6687	.7265	.6859	.6203	.503
23	.7282	.6613	.6859	.7011	.6516	.6443	.57
24	.6687	.6836	.6539	.6859	.7087	.6516	.6687
Max	.7282	.6836	.6935	.7265	.7087	.6516	.6687
Min	.3258	.1829	.2715	.2534	.3429	.2865	.1629
Avg	.5089	.4833	.4917	.5127	.5175	.4777	.4452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 201 / 11 KV BHAVAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5093	.547	.547	
2				.5281	.547	.547	
3				.5281	.547	.547	
4				.5093	.547	.5281	
5				.4715	.5093	.4715	
6				.2452	.2829	.2829	
7				.1886	.2829	.2263	
8				.1509	.2263	.2263	
9				.2075	.2075	.2452	
10	.2452	.2263		.2829	.3018	.2829	
11	.3206	.3018		.3206	.3206	.3395	
12	.3206	.3584	.3584				.3395
13	.415	.415	.415				.415
14	.4338	.415	.415				.3961
15	.3772	.3772	.3772				.3772
16	.3018	.2829	.2641				.3018
17	.2263	.2075	.2263				.2075
18	.1886	.1886	.1886				.2263
19	.3395	.2829	.3206				.2263
20	.4904	.4904	.4904				.2263
21	.547	.547	.6036				.2263
22	.547	.5658	.5847				.3772
23	.5281	.5281	.5281				.4715
24				.4904	.547		
Max	.547	.5658	.6036	.5281	.547	.547	.4715
Min	.1886	.1886	.1886	.1509	.2075	.2263	.2075
Avg	.3772	.3705	.3977	.3694	.4055	.3858	.3159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 202 / 11 KV GOSE FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5431	3.5757	3.5841	3.5553	2.9607	2.657	3.3292
2	3.4952	3.5567	3.5446	3.4901	2.9507	2.6605	3.352
3	3.4731	3.5052	3.5143	3.5029	2.9325	2.6681	3.3535
4	3.3914	3.4446	3.496	3.4446	2.918	2.6471	1.9677
5	3.2215	3.3924	3.3283	3.4217	2.9287	2.6135	1.9121
6	2.5303	2.6275	2.6492	3.1405	2.7471	2.4443	.9084
7	1.6431	1.6488	1.4973	2.9123	2.5836	2.2794	1.1273
8	1.1877	1.5522	1.2216	3.2046	2.8163	.969	1.7235
9	1.154	1.3428	1.6871	3.0986	2.9197	2.4817	1.756
10	2.7564	2.1119	2.3285	3.0708	2.9786	2.5381	1.9518
11	3.7938	3.404	2.5509	3.1021	3.0167	2.5541	2.339
12	3.8943	3.5486	2.9706	3.1291	3.0565	2.8445	2.2635
13	4.01	3.6896	3.4728	3.1413	3.1409	3.1794	2.3996
14	3.9975	3.661	3.5223	3.188	3.2916	3.2185	2.5105
15	3.9545	3.5722	3.456	3.0678	3.0215	3.1744	2.4798
16	3.731	3.5048	3.3432	2.6875	2.6105	2.7984	2.4486
17	3.5433	3.3749	3.3081	2.2409	2.1459	1.8511	2.3502
18	2.5505	2.4903	3.3768	1.8786	1.8307	1.4773	2.2858
19	2.4412	2.2828	3.405	2.5507	2.5996	2.2001	2.154
20	3.5728	3.5774	3.7734	3.7242	3.7603	3.4271	1.0802
21	3.8559	3.8878	3.9331	3.9561	4.2206	3.8574	1.0802
22	3.9154	4.0093	3.8146	3.9449	4.042	3.838	1.2605
23	3.7397	3.8792	3.6481	3.8632	3.8195	3.594	1.4419
24	3.6296	3.6677	3.6852	3.6062	3.2152	2.9496	2.4533
Max	4.01	4.0093	3.9331	3.9561	4.2206	3.8574	3.3535
Min	1.154	1.3428	1.2216	1.8786	1.8307	.969	.9084
Avg	3.2094	3.1378	3.1296	3.2051	3.0211	2.7051	2.0804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 203 / 11 KV KONDHA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8778	1.8187	1.7126	2.3577	2.3577	2.452	1.153
2	1.9113	1.8652	1.7126	2.32	2.32	2.3011	1.153
3	1.933	1.8652	1.7126	2.3011	2.32	2.2634	1.1191
4	1.8652	1.8482	1.6956	2.2634	2.2257	2.2068	1.0682
5	1.7974	1.8313	1.6448	2.1313	2.1691	2.037	.9835
6	1.6766	1.6164	1.543	1.5844	1.5655	1.5278	
7	1.5927	1.5364	1.5089	1.1128	1.2071	1.1694	.8478
8	1.6263	1.531	1.5261	.8676	1.094	1.0185	.8139
9	1.6244	1.4998	1.5089	1.1694	1.2826	1.1317	1.0343
10	1.3203	1.3392	1.5775	1.5844	1.0562	1.5844	1.0174
11	1.5844	1.6032	1.5927	1.7541	1.8296	1.7541	1.0174
12	1.8861	1.8861	1.8107	1.4419	1.5257	1.3904	1.7541
13	1.9993	1.9993	2.0182	1.6057	1.6095	1.4413	1.9993
14	2.0559	2.037	2.1125	1.6221	1.5927	1.4582	2.037
15	1.9239	1.773	2.0748	1.6385	1.5091	1.4922	2.037
16	1.6409	1.6975	1.6975	1.5402	1.4582	1.3904	1.8861
17	1.3769	1.3392	1.4335	1.4746	1.3904	1.0682	1.6032
18	.9431	1.2637	1.2449	1.358	1.2378		1.3203
19	1.7541	1.4901	1.6409	1.406	1.4413	.6718	1.3203
20	2.1879	2.2257	2.2822	1.6057		1.0159	1.3203
21	2.4331	2.3954	2.3388	1.6712	1.5939	1.1022	1.3203
22	2.5463	2.5274	2.5652	1.6876	1.56	1.1361	1.1694
23	2.3954	2.452	2.4709	1.6385	1.5261	1.1305	2.1313
24	1.7772	1.8143	1.6448	2.4143	2.3954		1.153
Max	2.5463	2.5274	2.5652	2.4143	2.3954	2.452	2.1313
Min	.9431	1.2637	1.2449	.8676	1.0562	.6718	.8139
Avg	1.8221	1.8023	1.7946	1.6896	1.6638	1.4883	1.3591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 204 / 11 KV Virlee Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6191	3.4109	3.2161	1.7547	1.7199	1.6819	1.5078
2	3.645	3.4343	3.24	1.716	1.7168	1.6804	1.5009
3	3.6161	3.3798	3.2181	1.7168	1.6895	1.6834	1.5139
4	3.5898	3.3547	3.127	1.6941	1.6918	1.6607	1.4746
5	3.5167	3.3251	3.0856	1.6503	1.6775	1.6223	1.4449
6	3.3467	3.0582	2.9576	1.2605	1.3106	1.2832	.7766
7	3.2179	3.1825	2.8525	.8966	.9452	.8695	1.1915
8	3.4106	3.2057	3.0476	.856	.8296	.7672	.7194
9	3.4255	3.2392	3.1109	.8433	.9077	.9265	1.2368
10	2.3143	2.2493	3.1383	.994	1.0073	1.0138	1.6099
11	1.0047	1.0047	3.1573	1.1448	1.1973	1.1845	1.832
12	1.1707	1.2072	2.3965	2.1791	2.0971	1.9643	1.5358
13	1.286	1.3278	1.4186	3.0133	2.8066	2.656	1.2828
14	1.3687	1.3112	1.4262	3.0453	3.0504	2.7023	1.4254
15	1.3407	1.2557	1.3854	3.0757	2.6414	2.6827	1.4106
16	1.1772	1.1605	1.1704	3.0952	2.5478	2.5743	1.2675
17	.9446	.9497	.9317	3.1165	2.3234	2.483	.9877
18	.7948	.7057	.7297	2.8727	2.4066	2.1344	.7803
19	1.1959	.8533	1.1505	2.9149	2.3973	2.2719	.8405
20	1.9425	1.8094	1.9003	3.1154	2.6911	2.4549	.3772
21	2.0384	1.9989	1.9944	3.1742	2.7942	2.5743	.8451
22	1.9635	1.9408	1.9867	3.139	2.761	1.8533	1.6152
23	1.8376	1.7981	1.9027	3.0685	2.7147	1.4312	1.6412
24	2.7146	2.7062	2.2495	2.6234	2.373	1.624	1.451
Max	3.645	3.4343	3.24	3.1742	3.0504	2.7023	1.832
Min	.7948	.7057	.7297	.8433	.8296	.7672	.3772
Avg	2.2701	2.1612	2.2831	2.2067	2.0124	1.8242	1.2612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 205 / 11 KV Palora Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8562	1.8692	1.86	2.9144	1.9483	1.9692	1.8146
2	1.8417	1.8359	1.8313	2.9065	1.9454	1.9753	1.8656
3	1.8326	1.8298	1.8191	2.8845	1.9737	1.9738	1.8044
4	1.7789	1.8048	1.7896	2.8228	2.0069	1.9845	1.7282
5	1.5626	1.7707	1.6922	2.8205	2.0446	1.9571	1.6134
6	1.1715	1.2826	1.2136	2.8096	2.0207	1.9349	.6676
7	.8428	.9116	.9017	2.5095	2.0248	1.9654	.5149
8	.7756	.816	.8387	2.4289	2.1041	1.9273	.7951
9	.8296	.7521	.9016	2.3792	2.0659	2.0104	.8197
10	1.7508	1.8648	1.0584	2.32	2.0814	2.1483	.8354
11	2.7945	2.5713	1.2458	2.3533	1.5731	2.133	.9871
12	2.8298	2.9656	2.1748	2.0228	1.3443	1.8787	1.355
13	2.9228	3.0056	2.8525	1.6036	1.5532	1.6142	1.419
14	2.5389	3.0952	3.043	1.6104	1.6165	1.6023	1.6541
15	2.8217	3.1211	3.0071	1.532	1.4642	1.5509	1.6773
16	2.7549	3.0403	2.8929	1.2851	1.1801	1.2675	1.6865
17	2.7176	2.9881	2.8434	.9417	.8928	.8489	1.7261
18	1.8233	1.9605	2.7877	.8678	.6799	.6869	1.7649
19	1.2437	1.0713	2.8904	1.2112	1.1208	1.0842	1.8007
20	1.672	1.7379	2.873	1.8634	1.7734	1.5855	.823
21	1.6985	1.9494	2.9523	1.9988	1.957	1.8486	.823
22	1.9046	2.0275	3.0171	1.9928	1.9384	1.785	
23	1.9547	1.9663	2.9995	1.9148	1.8882	1.8229	.6399
24	1.9239	1.9003	2.4985	2.2999	1.757	1.8351	1.3908
Max	2.9228	3.1211	3.043	2.9144	2.1041	2.1483	1.8656
Min	.7756	.7521	.8387	.8678	.6799	.6869	.5149
Avg	1.9101	2.0057	2.1660	2.0956	1.7064	1.7246	1.3133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 206 / 11 KV Pimpalgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8619	.8785	.8122	.8676	.8865	.8865	.7377
2	.8886	.8619	.7956	.8676	.8676	.8676	.7377
3	.8718	.8421	.7956	.8676	.8865	.8676	.6874
4	.8886	.8097	.779	.8299	.8676	.8488	.6706
5	.8215	.8097	.7459	.7733	.8488	.7356	.57
6	.8215	.7186	.663	.4904	.4338	.5093	
7	.8048	.7186	.7127	.3395	.3961	.415	.5533
8	.8383	.7186	.7293	.2641	.3395	.415	.4862
9	.8453	.6874	.7127	.3961	.4527	.4527	.503
10	.4527	.4527	.7459	.5093	.5281	.5281	.5533
11	.5658	.5658	.7459	.6036	.6413	.6413	.5533
12	.6979	.679	.6224	.6718	.6802	.7293	.547
13	.7545	.7167	.6979	.7701	.7125	.7956	.5658
14	.7167	.679	.6979	.7865	.7611	.8288	.6979
15	.6224	.6036	.6979	.7373	.7287	.8122	.6413
16	.5093	.4904	.4715	.6882	.6964	.7293	.4715
17	.415	.3772	.3961	.7045	.6478	.6299	.3961
18	.3772	.3206	.2829	.5944	.6802	.5765	.3584
19	.5847	.4904	.5281	.6093	.7287		.3584
20	.8488	.811	.8676	.7865	.7935	.6802	.3584
21	.9431	.9054	.9313	.8356	.8421	.7545	.3584
22	.9242	.9431	.9619	.7865	.8097	.7377	
23	.8865	.8865	.9054	.7865	.8097	.6802	
24	.8288	.8065	.8865	.8865	.8865		.7209
Max	.9431	.9431	.9619	.8865	.8865	.8865	.7377
Min	.3772	.3206	.2829	.2641	.3395	.415	.3584
Avg	.7404	.6989	.7161	.6855	.7052	.6874	.5489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 201 / 11 KV ADYAL FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4762	1.5288	1.5112	.7362	.7537	1.5463	1.4937
2	1.4762	1.4632	1.5112	.7011	.7186	1.5592	1.4937
3	1.4457	1.4632	1.4807	.7011	.7186	1.4937	1.4282
4	1.3931	1.4327	1.4327	.6661	.7186	1.4937	
5	1.3321	1.3321	1.3847	.6485	.6836	1.4106	
6	1.083	1.1355	1.0174	.4733	.5434	1.1964	.5434
7	.9084	.8603	.8428	.4031	.4557	.9434	1.0311
8	.8603	.8299	.4207	.3856	.4207	.8779	.8871
9	.8299	.9129		.4382	.4908	.9915	1.044
10	1.009	.961		.4733	.5609	1.022	1.0791
11	1.1767	1.105		.5083	.5959	1.1706	1.1927
12	1.2841	1.1881	.6135	.6485	.6661	1.3191	1.2886
13	1.3016	1.3016	.6485	.7011	.7362	1.3847	1.3847
14	1.4282	1.3672	.7011	.7011	.7011	1.4282	1.3977
15	1.3496	1.3321	.7011	.7011	.631	1.3801	1.3801
16	1.3451	1.2315	.5959	.6135	.631	1.3451	1.3451
17	1.236	1.1706	.4908	.5609	.5609	.4908	1.1614
18	1.1271	1.105	.4908	.6135	.5258	.9915	1.0525
19	1.1401	1.2232	.6135	.5784	.6135	.9305	.5792
20	1.3672	1.4327	.7011	.6836	.7011	1.3321	
21	1.5333	1.4152	.7362	.7186	.7537	1.4983	
22	1.5767	1.5288	.7537	.7888	.7888	1.5942	.4557
23	1.5592	1.5767	.7712	.7537	.7888	1.5592	1.3367
24	1.5814	1.5288	.7362	.7362	.7537	1.5463	.7186
Max	1.5814	1.5767	1.5112	.7888	.7888	1.5942	1.4937
Min	.8299	.8299	.4207	.3856	.4207	.4908	.4557
Avg	1.2842	1.2678	.8645	.6222	.6463	1.2711	1.1147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 203 / 11 KV Nerala Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5064	.4898	.4235	.57	.4912	.5548	.4603
2	.5064	.4898	.4594	.57	.476	.5217	.4603
3	.5064	.4746	.4594	.57	.476	.5217	.4451
4	.5064	.4732	.4594	.5534	.476	.5051	.4146
5	.4912	.4732	.4594	.5217	.4594	.4898	.3658
6	.4746	.4746	.4262	.4746	.4594	.458	.3963
7	.4428	.4275	.3957	.4275	.3957	.4275	.349
8	.4109	.4123	.4123	.4275	.4123	.4123	.3338
9	.4262	.397	.4594	.4441	.4123	.4275	.3338
10	.4275	.3487	.4428	.4275	.4594	.4441	.3322
11	.4428	.3957	.4428	.4594	.4594	.4428	.3825
12	.4097	.4123	.4594	.4912	.4898	.4912	.4283
13	.4123	.4275	.4746	.4912	.4898	.4912	.4451
14	.4594	.4428	.5064	.5064	.4898	.4912	.4116
15	.4428	.4428	.4898	.5064	.5064	.4746	.4451
16	.4275	.4594	.4594	.4428	.458	.4428	.3811
17	.4275	.4275	.4275	.4109	.476	.128	.3825
18	.4123	.4109	.3765	.4275	.3957	.3109	.3658
19	.4123	.4607	.1989	.4275	.4123	.3261	.1981
20	.6005	.5051	.57	.5217	.5548	.4912	
21	.5548	.57	.5548	.57	.57	.5243	
22	.5866	.57	.5866	.5382	.5853	.5228	
23	.5866	.5229	.6019	.4912	.57	.4732	.3673
24	.5229	.4898	.5534	.5243	.5369	.5243	.4302
Max	.6005	.57	.6019	.57	.5853	.5548	.4603
Min	.4097	.3487	.1989	.4109	.3957	.128	.1981
Avg	.4749	.4583	.4625	.4915	.4797	.4540	.3871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 204 / 11 KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2964	.2964	.1288	.1128	.1326	.1128	.1288
2	.2964	.2964	.1288	.1166	.1326	.0968	.1448
3	.2964	.2964	.1288	.1288	.1326	.1128	.1448
4	.3124	.2964	.1326	.1288	.1288	.1128	.1448
5	.3825	.144	.2287	.1006	.1288	.1326	.1448
6	.5289	.144	.221	.1128	.0846	.1006	.1486
7	.4267	.208	.1249	.2089	.0884	.2767	.1524
8	.3505	.2241	.2127	.2569	.1044	.2492	.1646
9	.3345	.16	.1851	.1531	.1524	.1089	.1364
10	.4146	.144	.1608	.2287	.3087	.1166	.1204
11	.3947	.2401	.0929	.1531	.2812	.1166	.1204
12	.2484	.192	.1166	.2287	.1211	.1006	.1326
13	.2964	.144	.1006	.1768	.1364	.0846	.1166
14	.2644	.128	.1166	.1326	.1166	.0846	.1128
15	.2644	.16	.1966	.1288	.1486	.1166	.1608
16	.2263	.2561	.1964	.1448	.2089	.1326	.1691
17	.2263	.2241	.0808	.1006	.253	.1524	.1128
18	.2042	.144	.1806	.1364	.0853	.1006	.1288
19	.1722	.2241	.0846	.0846	.1166	.1044	-.0152
20	.2583	.128	.1364	.1204	.1288	.1486	
21	.2964	.144	.1326	.1288	.1326	.1448	.112
22	.2964	.144	.1288	.1288	.1128	.1288	.144
23	.2964	.144	.1128	.1288	.1288	.1288	.1288
24	.2964	.144	.1326	.1326	.1288	.1128	.1288
Max	.5289	.2964	.2287	.2569	.3087	.2767	.1691
Min	.1722	.128	.0808	.0846	.0846	.0846	-.0152
Avg	.3075	.1928	.1442	.1447	.1456	.1282	.1297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 206 / 11 KV Tirri Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.0953	.0953	.0953	.0953
2	.1143	.0953	.1143	.1143	.0953	.0953	.0953
3	.1143	.0953	.1143	.0953	.0953	.0953	.0953
4	.1143	.0953	.1143	.0953	.0953	.0953	.0762
5	.1143	.0953	.0953	.0953	.0953	.0762	.0762
6	.0572	.0572	.0762	.0762	.0762	.0762	.0762
7	.0572	.0572	.0572	.0572	.0572	.0572	.0572
8	.0572	.0572	.0572	.0572	.0762	.0572	.0572
9	.0572	.0572	.1143	.0762	.0762	.0572	.0572
10	.0572	.0762	.0762	.0572	.0762	.0572	.0572
11	.0572	.0572	.0762	.0762	.0572	.0572	.0762
12	.0953	.0762	.0762	.0953	.0762	.0762	.0572
13	.0762	.0762	.0762	.0953	.0762	.0762	.0572
14	.0762	.0762	.0572	.0953	.0762	.0953	.0762
15	.0762	.0953	.0762	.0953	.0762	.0953	.0572
16	.0572	.0762	.0762	.0762	.0572	.0953	.0572
17	.0572	.0762	.0762	.0572	.0762	.0381	.0572
18	.0953	.0572	.0762	.0762	.0572	.0572	.0762
19	.1143	.0953	.0762	.0953	.0762	.0762	
20	.1143	.0953	.1143	.1143	.1143	.0762	
21	.1143	.1334	.1143	.0953	.1143	.0953	
22	.1334	.1143	.1143	.1143	.1143	.0953	.0381
23	.1334	.0953	.1143	.0953	.0953	.0953	.0381
24	.1143	.1143	.1143	.0953	.0953	.0953	.0953
Max	.1334	.1334	.1143	.1143	.1143	.0953	.0953
Min	.0572	.0572	.0572	.0572	.0572	.0381	.0381
Avg	.0905	.0850	.0905	.0873	.0834	.0786	.0681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 201 / 11 KV Paoni Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	.8501	.8501	.8686	.9055	1.0903	.961
2	.8316	.8316	.8501	.8686	.8501	1.1088	.8501
3	.8131	.7762	.8316	.8501	.8501	1.0534	.8316
4	.7392	.7762	.7762	.8316	.8316	.924	.8316
5	.7023	.7392	.6838	.7392	.7947	.8131	.7392
6	.5544	.5544	.5175	.6468	.6653	.6283	.5914
7	.4805	.5359	.462	.5014	.5359	.5544	.5175
8	.5175	.4435	.4805	.5544	.5552	.5175	.5175
9	.6653	.5914	.6099	.6468	.5729	.6838	.6283
10	.7392	.7023	.5544	.8131	.8131	.7577	.6838
11	.7762	.7762	.6468	.7947	.9795	.8686	.6099
12		.7207	.7392	.7762	.9425	.7947	.6653
13	.7762	.961	.8686	.8316	.8686	.8316	.7577
14	.961	.8316	.8316	.8316	.8686	.9055	.8316
15	.9425	.9795	.7947	.8501	.8316	.961	.8131
16	.8871	.7392	.7392	.8131	.7947	.961	.7577
17	.6838	.6653	.6653	.924	.7207	.5914	.7392
18	.6468	.6283	.5914	.8316	.6099	.5729	.7947
19	.6099	.7023	.7023	.8686	.7207	.6468	
20	.7207	.8131	.8316	1.0349	.8316	.8871	
21	.7947	.8316	.8686	.9979	.8871	.9425	
22	.8501	.8871	.9055	.924	.9425	1.0719	
23	.8871	.9149	.9425	.9425	1.1088	1.1088	
24	.8686	.8316	.8686	.9425	.9425	1.1273	.9979
Max	.961	.9795	.9425	1.0349	1.1088	1.1273	.9979
Min	.4805	.4435	.462	.5014	.5359	.5175	.5175
Avg	.7521	.7535	.7338	.8202	.8093	.8501	.7431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 202 / 11 KV Sawarla Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1777	2.1967	2.1818	2.4241	1.2403	1.2403	1.7299
2	2.1777	2.1967	2.1818	2.2519	1.2403	1.2403	1.7299
3	2.1472	2.1052	2.0903	1.0631	1.2403	1.2403	1.6994
4	2.1167	2.0747	2.0599	1.0631	1.2403	1.1517	1.6994
5	2.1167	2.0747	2.0253	1.0631	1.2403	1.1517	1.6994
6	2.1335	1.9883	1.9254	.7442	.7087	.691	1.4298
7	1.9338	1.9883	1.9948	.443	.4961	.567	1.3384
8	1.9989	2.0188	2.0294	.1772	.3544	.443	1.4514
9	2.0557	1.0669	.8859	.443	.3544	.6201	1.5602
10	1.5702	1.7353	1.1298	.6733	.7087	.8505	1.6385
11	.7442	.7628	.8859	.815	.8505	.6935	1.6587
12	.7619	.8322	.7442	.8859	.7442	.7802	1.6892
13	.8859	.8669	.9745	2.5312	2.4044	2.2644	.9214
14	.8328	.9015	1.0631	2.5312	2.4653	2.2034	.9214
15	.8859	.8669	.8859	2.4958	2.3158	2.1382	1.0277
16	.8505	.7282	.7442	2.4044	1.9833	1.9338	1.0277
17	.443	.5201	.5316	2.242	1.9528	1.7992	.7087
18	.443	.4854	.443	2.1329	1.8869	.6935	.7973
19	.691	.7282	.7442	2.0038	2.0443	1.5817	
20	1.2403	1.1789	1.2048	2.1081	2.3462	1.8387	
21	1.382	1.2483	1.3289	2.4604	2.4958	2.021	
22	1.3289	1.2136	1.4175	2.4072	2.4958	1.1584	
23	1.2757	1.2136	1.2403	2.3462	2.4299	.2774	
24	.9015	.9214	.8322	2.5511	2.5816	2.2767	.7108
Max	2.1777	2.1967	2.1818	2.5511	2.5816	2.2767	1.7299
Min	.443	.4854	.443	.1772	.3544	.2774	.7087
Avg	1.3789	1.3297	1.3144	1.6776	1.5759	1.2857	1.3389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 203 / 11 KV Amgaon Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1419	2.2266	2.1419	1.4232	1.4413	1.4403	1.9351
2	2.1419	2.2266	2.1419	1.3717	1.4413	1.4232	1.9825
3	2.2295	2.257	2.1114	1.3717	1.3904	1.3565	1.9181
4	2.0809	2.1961	2.1114	1.286	1.3904	1.2717	1.9181
5	2.1114	2.1961	2.1114	1.2003	1.3904	1.1869	1.8842
6	2.0639	2.1656	1.9825	.9945	1.1022	1.0004	1.8064
7	2.2606	2.2875	2.1148	.823	.8139	.8478	1.8403
8	2.335	2.3723	2.2875	.823	.8478	.7461	1.8537
9	2.3689	2.5247	2.3825	.7373	.8478	.7122	2.1114
10	2.0264	2.0433	2.4028	.823	1.0174	.9835	2.0639
11	.9835	1.0174	2.4638	1.153	1.17	.8817	2.1148
12	1.0174	1.1191	2.1453	1.0174	.9156	.8987	2.1996
13	1.2548	1.2209	1.1869	2.7146	2.6196	2.5282	1.2548
14	1.2209	1.3226	1.2616	2.6976	2.64	2.5756	1.2717
15	1.2039	1.1869	1.1869	2.6536	2.64	2.4808	1.2717
16	1.1869	1.0513	1.0513	2.6061	2.5586	2.5417	1.2717
17	.9156	1.0174	.9496	2.7485	2.5113	2.2977	.9665
18	.8139	.9835	.8478	2.5586	2.5113	.763	1.0174
19	1.1022	1.153	1.2039	2.3178	2.4469	1.7047	
20	1.6278	1.6108	1.6448	2.1824	2.6196	2.1114	
21	1.6787	1.6956	1.5261	2.4638	2.5655	2.1588	
22	1.6108	1.6278	1.5769	2.4638	2.5586	2.0944	
23	1.5091	1.5261	1.56	2.2706	2.4469	1.9995	
24	.9835	1.0682	.8139	2.6634	2.6911	2.4743	.8987
Max	2.3689	2.5247	2.4638	2.7485	2.6911	2.5756	2.1996
Min	.8139	.9835	.8139	.7373	.8139	.7122	.8987
Avg	1.6196	1.6707	1.7170	1.8069	1.8574	1.6033	1.6621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 204 / 11 KV Gose Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6829	.6783	.6844	.1562	.3125	.1562	.5914
2	.6829	.6783	.6844	.1562	.3125	.1562	.5754
3	.6509	.7088	.6844	.1562	.2343	.1562	.5754
4	.6509	.6306	.6539	.1562	.2343	.1562	.5896
5	.6509	.6306	.6844	.1562	.2343	.1562	.5754
6	.6973	.7697	.6219	.1562	.2343	.1562	.5449
7	.8573	.8002	.6859	.1562	.1875	.1562	.5609
8	.7773	.8002	.7469	.1562	.1562	.1562	.6059
9	.7773	.8002	.7689	.1562	.1562	.1562	.6364
10	.6172	.6752	.7689	.1562	.1562	.1562	.6364
11	.1562	.2241	.7994	.1875	.1562	.16	.6001
12	.1562	.2241	.522	.3125	.1875	.2241	.5525
13	.1562	.2241	.1562	.6611	.6915	.6669	.1562
14	.1696	.2241	.1562	.6915	.722	.6973	.1562
15	.1562	.2241	.1562	.8314	.8009	.6973	.1562
16	.1562	.2241	.1562	.7697	.7697	.6973	.2812
17	.1562	.2241	.1562	.7697	.7697	.6829	.1562
18	.1562	.192	.1562	.8307	.7393	.192	.1562
19	.1562	.2561	.1562	.7384	.7393	.5449	
20	.3125	.2561	.1562	.7689	.6915	.6859	
21	.3125	.3201	.1562	.7697	.6915	.6524	
22	.3125	.2881	.1562	.722	.6915	.7164	
23	.2343	.2561	.1562	.7384	.6611	.6219	
24	.2713	.3125	.2241	.6134	.6455	.4915	.2561
Max	.8573	.8002	.7994	.8314	.8009	.7164	.6364
Min	.1562	.192	.1562	.1562	.1562	.1562	.1562
Avg	.4128	.4426	.4270	.4570	.4656	.3872	.4401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 205 / 11 kv Pauni - II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0029	1.0029	1.0387	1.0387	1.0566	1.0745	1.0029
2	1.0029	1.0029	1.0029	.9671	1.0387	1.0387	1.0029
3	.985	.985	1.0029	.8669	1.0387	1.0387	.9671
4	.8954	.9492	.9671	.8417	1.0387	1.0208	.9492
5	.8059	.8954	.8954	.8059	.985	1.0029	.9134
6	.7164	.7164	.6447	.7701	.8059	.8059	.7522
7	.6089	.6805	.5731	.6089	.6984	.7164	.6089
8	.6447	.2328	.2507	.5552	.6805	.6838	.5373
9	.591	.2507	.2686	.591	.6268	.6626	.567
10	.7164	.6805	.7701	.5373	.7522	.7343	.6447
11	.788	.9492	.8596	.7522	.8954	.788	.6805
12	.8596	.8775	.8596	.9134	.9134	.8775	.7701
13	.8954	.9671	.9671	1.0029	.9671	.6089	.9313
14	.961	.9671	.985	1.0208	1.0387	1.0029	1.0208
15	.9313	.9671	.9313	.985	.985	.9671	.9671
16	.8954	.8417	.8596	.9313	.9134	.8954	.9313
17	.8775	.9134	.8238	.8596	.8417	.788	.8954
18	.7343	.8059	.7522	.8596	.7701	.6089	.7522
19	.8417	.924	.8596	.8417	.8238	.6626	
20	.9134	.985	.985	.9671	.985	.8238	
21	.9671	.9671	1.0208	1.0208	1.0387	.9134	
22	1.0387	1.0387	1.0745	1.1104	1.1283	1.0387	
23	1.0566	1.0745	1.0029	1.1104	1.1104	1.0566	
24	1.0208	1.0208	1.0745	1.0745	1.1104	1.1104	1.0208
Max	1.0566	1.0745	1.0745	1.1104	1.1283	1.1104	1.0208
Min	.591	.2328	.2507	.5373	.6268	.6089	.5373
Avg	.8646	.8623	.8529	.8764	.9268	.8717	.8376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 206 / 11 KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2016	.1859	.2957	.2042	.317	.2804	.2957
2	.2016	.1859	.2195	.2042	.2042	.2042	.2957
3	.1837	.1859	.2016	.2042	.2042	.2042	.2374
4	.1657	.2042	.2195	.2042	.2042	.2042	.2374
5	.1657	.2225	.2195	.2042	.1676	.2042	.2374
6	.1657	.2042	.2195	.1859	.1494	.1859	.1478
7	.0716	.2042	.2195	.1676	.1676	.2042	.1478
8	.1075	.2225	.2016	.1494	.1494	.2804	.2195
9	.1657	.2042	.1494	.0732	.2225	.2225	.2195
10	.2732	.3353	.317	.2225	.3353	.2225	.3136
11	.3353	.3315	.3536	.3719	.3536	.2419	.3536
12	.2804	.3315	.3353	.3353	.3353	.3494	.317
13	.2408	.3136	.317	.317	.2804	.3136	.3353
14	.2987	.3136	.2987	.3353	.317	.3136	.3353
15	.2987	.3136	.317	.3353	.2987	.3315	.3536
16	.2987	.2957	.2987	.317	.317	.3136	.3536
17	.2987	.3136	.2987	.317	.3536	.2957	.2987
18	.317	.2778	.317	.317	.317	.2778	.2987
19	.2804	.1657	.2042	.2987	.2804	.1837	.0762
20	.2408	1.0612	.2408	.2987	.2804	.2957	
21	.2408	.2778	.2225	.2804	.2987	.2957	
22	.2225	.2195	.2408	.2804	.2225	.2957	
23	.317	.2957	.2987	.2987	.2987	.3136	
24	.2778	.2804	.2195	.2804	.2987	.2987	.1612
Max	.3353	1.0612	.3536	.3719	.3536	.3494	.3536
Min	.0716	.1657	.1494	.0732	.1494	.1837	.0762
Avg	.2354	.2894	.2594	.2584	.2656	.2639	.2618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 207 / 11 KV SHINDHPURI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161						
2	.6161						
3	.6161						
4	.6722						
5	.6722						
6	.7095						
7	.8589						
8	.9335						
9	.9694						
10		.6767					
11		.9896					
12		1.0456	.823	.8048	.5853	.5201	.4024
13		1.0642	.9694	.8962	.6401	.6348	.5121
14		1.0829	1.0059	.9145	.7133	.6722	
15		1.0642	.9877	.7682	.695	.6535	.3658
16		1.0642	.9694	.8596	.695	.6722	.439
17		1.0642	1.0242	.9145	.7499	.591	.4755
18			1.0608	.9328	.7316		.5121
19			1.0608	.8309	.695	.3921	
20			1.0425	.9145	.6767	.4108	
21			1.0242	.8596	.695	.3921	
22			.9877	.8413	.6584	.3921	
23			.9328	.8413	.6767	.3921	
24	.5975						
Max	.9694	1.0829	1.0608	.9328	.7499	.6722	.5121
Min	.5975	.6767	.823	.7682	.5853	.3921	.3658
Avg	.7262	1.0065	.9907	.8649	.6843	.5203	.4512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 201 / 11 KV Pahela-P FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.775	.7792	.7624	.7582	.7754	.7754	.7582
2	.775	.7792	.7491	.7582	.7582	.7582	.7582
3	.775	.743	.7491	.7239	.7411	.7582	.7582
4	.7571	.743	.7491	.7068	.7411	.7411	.7491
5	.7213	.7068	.7213	.6725	.7411	.7411	.7491
6	.6451	.5582	.5635	.562	.6553	.562	.5266
7	.5689	.4481	.4688	.4344	.4515	.4344	.4153
8	.4972	.4639	.4515	.4515	.4858	.4515	.3742
9	.4972	.583	.5372	.5372	.4172	.5182	.4687
10	.6203	.6414	.562	.562	.4344	.7316	.4687
11	.6203	.6093	.5277	.4858	.4858	.6999	.4858
12	.6306	.627	.6477	.5791	.4687	.6569	.4858
13	.7068	.7032	.7068	.6553	.5372	.7163	.5791
14	.7068	.6134	.6134	.6725	.682	.7032	.5963
15	.6306	.6134	.5963	.5791	.7239	.7371	.6134
16	.6306	.5852	.6553	.5963	.6134	.6896	.6134
17	.6093	.5913	.562	.5791	.5963	.3557	.6134
18	.6093	.6272	.5791	.5449	.562	.5331	.6477
19	.6306	.6649	.6649	.6134	.5963	.6689	.1524
20	.743	.7666	.7582	.7411	.7411	.7239	
21	.7792	.7582	.7925	.7582	.7754	.7411	.562
22	.7792	.771	.8687	.8516	.8687	.7498	.6134
23	.7792	.771	.7754	.7754	.8516	.7582	.6134
24	.775	.7792	.7666	.7582	.7754	.7754	.682
Max	.7792	.7792	.8687	.8516	.8687	.7754	.7582
Min	.4972	.4481	.4515	.4344	.4172	.3557	.1524
Avg	.6776	.6636	.6595	.6399	.6450	.6659	.5776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 202 / 11 KV Wakeshwar Gaothan
feeder Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7163	.7468	.7491	.7239	.7239	.7582	.7624
2	.7163	.7468	.7491	.7239	.7239	.7582	.7624
3	.7163	.7834	.7491	.7068	.7411	.7411	.7624
4	.7163	.7834	.7354	.6896	.7239	.7411	.7354
5	.6828	.7102	.7034	.6553	.7068	.7411	.7392
6	.5974	.5609	.582	.5449	.6134	.6553	.5791
7	.4847	.4664	.4688	.4687	.5963	.4515	.4504
8	.4847	.4664	.4344	.4344	.5277	.4515	.4527
9	.4847	.4664	.4172	.4344	.4858	.4664	.3582
10	.454	.4481	.4515	.4344	.5372	.4639	.4515
11	.4565	.5582	.4858	.5106	.6306	.5182	.4515
12	.6706	.4767	.6306	.5277	.6896	.6134	.562
13	.6005	.6134	.6306	.7068	.6477	.6477	.6553
14	.6005	.7331	.6896	.7411	.6649	.7201	.6896
15	.5243	.6757	.6134	.7239	.6134	.6306	.7239
16	.5243	.5706	.5963	.5449	.5449	.5883	.6134
17	.4298	.482	.562	.4687	.2286	.298	.562
18	.4847	.4847	.4687	.4515	.4687	.4504	.4687
19	.5612	.5266	.5201	.5887	.5372	.551	.2286
20	.7506	.771	.7582	.7754	.7925	.7498	
21	.9007	.7754	.7582	.7754	.8687	.7666	
22	.8823	.7754	.8344	.7582	.8687	.8302	.3334
23	.7876	.7624	.7411	.7411	.7582	.8344	.4858
24	.7506	.7506	.7491	.7239	.7239	.7582	.682
Max	.9007	.7834	.8344	.7754	.8687	.8344	.7624
Min	.4298	.4481	.4172	.4344	.2286	.298	.2286
Avg	.6241	.6306	.6283	.6189	.6424	.6327	.5686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 203 / 11 kv Nimgaon Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2698	.2698	.2671	.1962	.1962	.1791	.1591
2	.2698	.2865	.2671	.1962	.1962	.1791	.1591
3	.2698	.2865	.2671	.1962	.1791	.1791	.1591
4	.2698	.2698	.2671	.1962	.1791	.1619	.1591
5	.2698	.253	.2684	.1791	.1791	.1791	.1591
6	.16	.16	.1591	.1791	.1791	.1619	.1433
7	.16	.0838	.1581	.1791	.1791	.1448	.0503
8	.16	.16	.1791	.1791	.1619	.1448	.0335
9	.1768	.1581	.1791	.1791	.1791	.1581	.0514
10	.1455	.1581	.1791	.1619	.1962	.1581	.0514
11	.1455	.1581	.1791	.1619	.1962	.1581	.0514
12	.16	.0762	.1448	.1619	.1791	.1572	.0686
13	.16	.1562	.1619	.1791	.1791	.1734	.0686
14	.16	.1722	.1619	.1791	.1791	.1734	.1448
15	.16	.1572	.1619	.1619	.1619	.1722	.1448
16	.16	.1722	.1791	.1619	.1619	.1734	.1448
17	.1768	.1734	.1791	.1619	.1448	.0972	.1619
18	.1657	.1581	.1791	.1448	.1448	.0335	.1619
19	.2016	.1734	.1619	.1619	.1619	.0663	.0762
20	.2957	.2644	.1791	.1791	.1791	.1581	
21	.2957	.2804	.2553	.1962	.2724	.1591	.1962
22	.2865	.2804	.2724	.1962	.2724	.1591	.2896
23	.2865	.2658	.2724	.1791	.2553	.1591	.2305
24	.2698	.2698	.1909	.1962	.1791	.1791	.1591
Max	.2957	.2865	.2724	.1962	.2724	.1791	.2896
Min	.1455	.0762	.1448	.1448	.1448	.0335	.0335
Avg	.2115	.2018	.2029	.1776	.1872	.1527	.1315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 204 / 11 kv WAKESHWAR-AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.3163	.2458					
11	.4915	.5769					
12	.4629	.586	.3505	.0857	.2991	.24	.12
13	.4629	.5736	.5791	.4858	.4687	.3604	.3067
14	.4629	.5736	.4858	.4687	.4687	.4366	.3239
15	.4473	.5736	.4858	.4858	.4687	.4088	.341
16	.4473	.6053	.5791	.5029	.4687	.4553	.3582
17	.5548	.6173	.5963	.5791	.4687	.2564	.4515
18	.3048	.3048	.5963	.5963	.4687	.4252	.4515
19			.5449	.5963	.4687	.3778	.1524
20			.4515	.5791	.4344	.2999	
21			.4515	.5791	.4344	.3016	
22			.4515	.4687	.341	.3162	.0171
23			.4515	.4687	.341	.285	.0933
24			.2286	.2286	.1524	.1524	.0762
Max	.5548	.6173	.5963	.5963	.4687	.4553	.4515
Min	.3048	.2458	.2286	.0857	.1524	.1524	.0171
Avg	.4390	.5174	.4810	.4711	.4064	.3320	.2447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 205 / 11 KV PAHELA-P-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.0514	.0486					
11	.0514	.0486					
12	.0492	.0324	.0171	.0343		.0497	.0171
13	.0492	.048	.0343	.0343		.0633	.0171
14	.0492	.0474	.0343	.0343		.0633	.0343
15	.0492	.048	.0343	.0343	.0343	.0633	.0343
16	.0492	.048	.0343	.0343	.0514	.0633	.0343
17	.0492	.0633	.0343	.0343	.0686	.0335	.0343
18			.0343	.0343	.0686		.0343
19			.0343	.0343	.0686	.0175	
20			.0343	.0343	.0686	.0171	
21			.0343	.0343	.0686	.0171	
22			.0343	.0343	.0686	.0171	.0171
23			.0343	.0343	.0686	.0171	.0171
Max	.0514	.0633	.0343	.0343	.0686	.0633	.0343
Min	.0492	.0324	.0171	.0343	.0343	.0171	.0171
Avg	.0498	.0480	.0329	.0343	.0629	.0384	.0267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 401 / 33 KV Adyal feeder INCOMER

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	1.1643	1.1643	1.0802	.9774	1.1317	1.0317
2	1.1568	1.1643	1.1643	1.0802	.9774	1.1317	.9877
3	1.1568	1.1643	1.1643	1.0288	.9774	1.0802	1.0082
4	1.1065	1.1088	1.1088	1.0288	.9259	1.0802	1.0082
5	1.1568	.9979	1.1088	.9774	.823	1.0802	.9054
6	1.0562	.8316	1.0082	.9774	.7716	1.0288	.8688
7	1.1523	.9328	.759	.9259	.7716	1.0288	.8688
8	1.0974	.9328	.8745	.9774	.7716	1.0288	.823
9	.8779	.8436	.5144	.9774	.7716	.7522	.7716
10	1.6832	1.2289	.5144	1.0288	1.1317	.823	.7202
11	1.5746	1.4403	.4115	.9774	1.2346	.9774	.8745
12	1.6461	1.4706	.823	1.0288	1.3375	1.286	1.1317
13	1.6461	1.4403	.823	1.0802	1.3889	1.2431	1.1831
14	1.5364	1.4403	1.4403	1.0802	1.4403	1.2574	1.286
15	1.5364	1.442	1.4403	1.1317	1.4918	1.3226	1.3375
16	1.5364	1.5415	1.3889	1.1831	1.4918	1.286	1.3375
17	1.5524	1.4752	1.3889	1.1831	1.4403	.4527	1.286
18	.9877	.9036	1.3889	1.1831	1.3889	1.0099	1.0288
19	1.0534	1.1317	1.4403	1.2346	1.3889	1.0402	
20	1.1643	1.1088	1.4403	1.3375	1.4403	1.262	
21	1.1643	1.0974	1.3889	1.3889	1.4918	1.286	
22	1.1643	1.0974	1.3889	1.4918	1.4403	1.3735	.0514
23	1.1643	1.1523	1.3375	1.286	1.4918	1.086	.0514
24	1.2071	1.1643	1.1643	1.0802	1.0288	1.1317	1.0425
Max	1.6832	1.5415	1.4403	1.4918	1.4918	1.3735	1.3375
Min	.8779	.8316	.4115	.9259	.7716	.4527	.0514
Avg	1.2681	1.1781	1.1103	1.1145	1.1831	1.0908	.9335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 200 / Station T/F

Feeder KV- 11 / INCOMING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.2715	
24	.0943	.1448	.2561	.0732	.1619	.3258	.0732
Max	.0943	.1448	.2561	.0732	.1619	.3258	.0732
Min	.0943	.1448	.2561	.0732	.1619	.2715	.0732
Avg	.0943	.1448	.2561	.0732	.1619	.2987	.0732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 201 / 11 KV MANGLI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.9755						
10	1.0987	1.3889					
11	1.4969	1.5935					
12	1.5813	1.6804	1.3279	1.3443	1.0936	.884	.4001
13	1.6644	1.6404	1.5699	1.4723	1.2492	1.0822	.4755
14	1.6091	1.656	1.6004	1.4373	1.2029	1.0957	.4988
15	1.6091	1.656	1.5503	1.4529	1.2492	1.0974	.4694
16	1.6091	1.6512	1.5503	1.4685	1.2342	1.0856	.4778
17	1.6204	1.387	1.3226	1.4352	1.2346	.8288	.4144
18			1.5575	1.3998	1.2498	.8543	.4512
19			1.5653	1.2971	1.2346	.8345	
20			1.5394	1.3998	1.2346	.631	
21			1.5741	1.387	1.2346	.6628	
22			1.5242	1.3696	1.2346		.2328
23			1.5242	1.3696	1.2191		.4961
24	.9755						
Max	1.6644	1.6804	1.6004	1.4723	1.2498	1.0974	.4988
Min	.9755	1.387	1.3226	1.2971	1.0936	.631	.2328
Avg	1.424	1.5817	1.5172	1.4028	1.2226	.9056	.4351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 202 / 11 KV LAKHANDUR FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.3715	.6274					
11	.5693	.6783					
12	.6062	.6443	.5243	.5344	.3856	.2229	.1326
13	.6299	.6173	.5898	.506	.4239	.3944	.1844
14	.6062	.4694	.5735	.506	.4239	.373	.1865
15	.6154	.431	.5735	.4458	.4115	.3521	.1677
16	.6325	.4409	.5898	.5182	.39	.3856	.1492
17	.5335	.6036	.6299	.4938	.4239	.3561	.0995
18			.6783	.4967	.4167	.3688	.1265
19			.5935	.4687	.3864	.3561	
20			.583	.4973	.3858	.3353	
21			.5765	.4807	.3715	.2683	
22			.5765	.4807	.3715		
23			.583	.4973	.3715	.1989	
24	.2286						
Max	.6325	.6783	.6783	.5344	.4239	.3944	.1865
Min	.2286	.431	.5243	.4458	.3715	.1989	.0995
Avg	.5326	.5640	.5893	.4938	.3969	.3283	.1495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 203 / 11 Kv Dholsar Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.2124	.2401					
11	.3639	.3403					
12	.3858	.3382	.2196	.18	.1334	.1277	.0377
13	.3841	.3313	.383	.2904	.2165	.246	.1326
14	.3875	5.7415	.3544	.2858	.2153	.2332	.1394
15	.4131	.3563	.4075	.2805	.2372	.246	.1402
16	.4234	.3563	.3673	.2735	.2435	.1953	.1318
17	.41	.3601	.3766	.2797	.2664	.1336	.1364
18	.2439	.2172	.3879	.2649	.2866	.0474	.16
19			.3885	.2729	.2574	.0817	.1067
20			.3715	.2382	.2536	.1648	
21			.3774	.242	.2498	.1724	
22			.2286	.2382	.2484	.1067	
23			.362	.2382	.2446	.1387	
24	.1174		.2248	.1448	.1448	.0953	
Max	.4234	5.7415	.4075	.2904	.2866	.246	.16
Min	.1174	.2172	.2196	.1448	.1334	.0474	.0377
Avg	.3342	.9201	.3422	.2484	.2306	.1530	.1231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 204 / 11 KV KONDHA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.5373	.591	.5658	.6201	.6268	.3086
2	.5611	.5316	.591	.5596	.6201	.6268	.5375
3	.543	.5316	.5731	.5596	.6201	.6089	.5201
4	.543	.5316	.5373	.5144	.5316	.6089	.5083
5	.4835	.5316	.5138	.4917	.4961	.5373	.443
6	.3467	.3898	.3506	.3521	.3814	.3856	.3506
7	.2486	.285	.3077	.2883	.3258	.2713	.208
8	.3467	.2949	.2947	.2743	.2713	.285	.1907
9	.4207	.3018	.3721	.2883	.333	.3544	.1907
10	.4477	.4115	.4119	.3772		.3544	.3258
11	.3506	.4508	.4835	.4119	.4163	.4344	.3429
12	.4961		.591	.5373	.4887	.3921	.4161
13	.5316	.5895	.5373	.5731	.6036	.4024	.4161
14	.5609	.5548	.591	.5316	.5792	.6036	.5258
15	.4908	.6859	.5194	.5014	.5853	.5175	.5201
16	.4854	.4854	.39	.4557	.4961	.4298	.4508
17	.4681	.3429	.2713	.3641	.3898	.2947	.462
18	.3121	.2818	.3052	.3772	.3898		.3475
19		.4207	.4409	.443	.5014	.3681	
20	.567	.5792	.4973	.5138	.6036	.5201	
21	.5373	.6335	.5426	.5847	.6154	.5434	
22	.6089	.6335	.5765	.6201	.6767		.2328
23	.6268	.6089	.5935	.5847	.5853	.3467	.4961
24	.591	.6089	.591	.6001	.6379	.6335	.3155
Max	.6268	.6859	.5935	.6201	.6767	.6335	.5375
Min	.2486	.2818	.2713	.2743	.2713	.2713	.1907
Avg	.4846	.4879	.4781	.4738	.5117	.4612	.3861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 205 / 11 KV KHAIRY FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.6447	.9181					
11	.9242	1.0254					
12	.9332	.9701	.7716	.7876	.5944	.4311	.3185
13	1.0212	.9934	.9095	.8768	.7011	.5721	.3185
14	.9957	.4458	.9242	.8916	.7164	.5721	.3765
15	.9808	.8916	.9389	.8768	.7074	.5868	.3814
16	.9659	.9362	.9633	.8802	.7074	.5498	.333
17	.9846	.9808	.9682	.8688	.7133		.3155
18			.9267	.8484	.6859	.0297	.3467
19			.9214	.8206	.7188	.0297	
20			.9181	.8318	.7133	.3269	
21			.8916	.8318	.7042	.3418	
22			.9031	.8177	.7407		
23			.8916	.8177	.6895	.2972	
24	.5841						
Max	1.0212	1.0254	.9682	.8916	.7407	.5868	.3814
Min	.5841	.4458	.7716	.7876	.5944	.0297	.3155
Avg	.8927	.8952	.9107	.8458	.6994	.3737	.3414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 207 / 11 KV KONDHA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286						
10	.9496	1.1191					
11	3.0588	2.9739					
12	3.2705	2.8296	1.073	1.0513		.6539	.4694
13	3.3297	2.6689	2.4935	1.2548	.9496	.8383	.5426
14	3.3297	2.8807	2.7725	1.2548	1.0174	.8383	.5596
15	3.2952	2.7451	2.7725	1.2209	1.0004	.6539	.5765
16	3.3128	2.9569	2.899	1.2209	1.0004	.7377	.5935
17	3.2366	3.0926	2.9325	1.2209	1.0513	.7461	.5596
18	1.7528	1.6766	2.923	1.2209	1.0174		.5596
19		.0762	2.7367	1.153	1.0174	.6104	
20			2.7536	1.153	1.0174	.6203	
21			2.7367	1.1361	1.0004	.6104	
22			2.6911	1.153	.7461		
23			2.5983	1.153	.7461	.4694	
24	.6443		1.3717				
Max	3.3297	3.0926	2.9325	1.2548	1.0513	.8383	.5935
Min	.2286	.0762	1.073	1.0513	.7461	.4694	.4694
Avg	2.4008	2.3020	2.5195	1.1827	.9604	.6779	.5515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 208 / 11 kv Lakhandur - G
feeder Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.5611	.5611	.5611	.5611	.567	.5792
2	.543	.5792	.5611	.5731	.5611	.567	.5611
3	.5611	.5792	.5611	.5731	.5611	.5487	.543
4	.5373	.5792	.5611	.5611	.5068	.5611	.5014
5	.3982	.5792	.4477	.4477	.4525	.5014	.4119
6	.2601	.2715	.2686	.2715	.3155	.3012	.2507
7	.2155	.2534	.2774	.2715	.1006	.2572	.2328
8	.1823	.2896	.2204	.2149	.1134	.2374	
9	.1989	.3077	.2715	.2534	.081	.3189	.2149
10	.2172	.6274	.3224	.2279	.3366	.3189	.2149
11	.3258	.362	.3721	.3582	.4119	.3761	.2865
12	.4163	.4477	.4344	.3801	.4344	.4477	.3077
13	.4344	.4656	.4525	.4706	.4706	.4334	.3439
14	.4477	.4656	.4706	.4706	.4706	.4477	.3582
15	.3982	.4706	.4163	.4706	.4075	.4298	.3582
16	.2896	.4656	.3439	.3801	.2865	.3224	.3582
17	.3258	.2507	.2353	.3045	.2865	.2328	.2686
18	.2896	.2591	.2507	.3224	.2686	.2686	.3045
19	.3982	.3856	.3761	.3761	.3403	.3403	
20	.5068	.5121	.4298	.5014	.5611	.4656	
21	.5611	.567	.5731	.591	.591	.4344	
22	.5973	.5853	.5973	.6089	.591		.0914
23	.5973	.5973	.5731	.591	.591	.543	.2561
24	.5611	.5792	.5792	.5792	.5792	.567	.5611
Max	.5973	.6274	.5973	.6089	.591	.567	.5792
Min	.1823	.2507	.2204	.2149	.081	.2328	.0914
Avg	.4086	.4600	.4232	.4317	.4117	.4125	.3502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 209 / 11 KV KHAIRY-GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***
2	***	***	***	***	***	***
3	***	***	***	***	***	***
4	***	***	***	***	***	***
5	***	***	***	***	***	***
6	***	***	***	***	***	***
7	***	***	***	***	***	***
8	***	***		***	***	***
9	***	***		***	***	***
10	***	***		***	***	***
11	***	***		***	***	***
12	***		***	***	***	***
13	***		***	***	***	***
14	***		***	***	***	***
15	***		***	***	***	***
16	***		***	***	***	***
17	***		***	***	***	***
18	***		***	***	***	***
19	***		***	***	***	***
20	***		***	***	***	***
21	***		***	***	***	***
22	***		***	***	***	***
23	***		***	***	***	***
24	***		***	***	***	***
Max	65.5389	59.4422	64.0147	67.063	62.4906	57.9181
Min	35.0557	38.104	38.104	42.6765	44.2006	36.5798
Avg	50.2973	48.6345	55.8605	54.2982	53.6631	47.8840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 006813 / 220 KV KAWLEWADA SUBSTN

Feeder No / Name : 404 / 33 KV SondyaTola feeder

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.6006	2.6235	1.9033	2.3137	2.5766	2.4714
2	2.572	2.5434	2.5206	1.8821	2.3137	2.5766	
3	2.572	2.5434	2.5206	1.9033	2.3137	2.4691	2.3663
4	2.6006	2.5434	2.6006	1.9244	2.3137	2.4691	2.3663
5	2.5486	2.4926	2.6006	1.8519	2.3137	2.4691	2.3405
6	2.4691	2.4417	2.5206	1.8004	2.2611	2.3663	2.1874
7	2.5206	2.4417	2.3663	1.749	2.1325	2.2634	2.2119
8	1.8519	2.4177	2.0062	1.933	2.3405	2.3148	2.2634
9	1.9547	2.4966	2.6749	.4115	2.3926	2.4446	2.3926
10	.4681	.5721	2.7778	2.1559	2.4446	2.5486	2.3148
11	.5658	.5201	2.6749	2.3137	2.4691	2.5486	2.3148
12	.6173	.6241	.6173	.5658	.6173	.7202	.6687
13	.6762	.6762	.6687	.6687	.6687	.7716	.7202
14	.7282	.6762	.6687	.6687	.7202	.7716	.7282
15	.6762	.6687	.6173	.6762	.7202	.6984	.7282
16	.5721	.463	.5144	.4681	.6173	.4161	.6241
17	.5144	.5144	.463	.463	.6104		.5144
18	.463	.4681	.5144	.4681	.5144		
19	.6687	.6173	.5658	.7282	.6173		
20	.8745	.9362		.8842	.9259	.9882	.5373
21	.823	.9156	.7802	.9362	.9877	.8745	.7442
22	.8648	.9156	.8139	.8842	.8939	.8939	.7442
23	.8648	.8648	.823	.823	.8413	.8842	.7282
24	2.5434	2.5206	2.5206	1.8519	2.2885	2.524	2.4714
Max	2.6006	2.6006	2.7778	2.3137	2.4691	2.5766	2.4714
Min	.463	.463	.463	.4115	.5144	.4161	.5144
Avg	1.3993	1.4364	1.6284	1.2465	1.5263	1.7424	1.5447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 207 / 11 KV Bagheda

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	1.2346	1.2003	1.1831	1.0802	1.0802	.9088
2	1.2517	1.2174	1.1831	1.1831	1.0288	1.0802	1.0117
3	1.2346	1.1317	1.1488	1.166	.9945	1.0802	.9602
4	1.2174	1.1317	1.1145	1.1145	.9602	1.1145	.8745
5	1.2003	1.0802	1.0631	1.0288	.9088	1.0974	.7888
6	1.0117	.9945	.9945	.9431	.8745	.9088	.7202
7	.9259	.9602	.9945	.8402	.8916	.8916	.6516
8	1.0288	.9431	.9945	.8745	.9431	.8916	.6516
9	1.0288	1.0288	1.0631	.9602	1.0117	.8916	.6344
10	1.0974	.9945	1.0802	1.0802			.6859
11	1.0974	1.0974	1.1317	1.1145	1.1488	.9945	.7373
12	1.2003	1.166	1.1317	1.0974	1.1831		.7888
13	1.2346	1.2174	1.166	1.1488	1.166	1.1317	.9088
14	1.2003	1.2346	1.166	1.1145	1.1317	1.0974	.8916
15	1.1831	1.2174	1.1488	1.0631	1.1831	.9431	.9602
16	1.1317	1.1317	1.0974	1.1317	.9602	.9602	.8745
17	1.0802	1.0974	1.1317	.9431	1.0631	.7716	.8059
18	1.0802	1.0974	1.0631	.9088	1.0117	.8402	
19	1.2174	1.1488	1.0974	1.0117	1.0117	.9774	
20	1.3375	1.2689	1.2689	1.166	1.2003	1.0631	
21	1.3203	1.3032	1.3032	1.2174	1.2517	1.0974	.3944
22	1.3032	1.3032	1.2689	1.1831	1.2174	1.046	.6516
23	1.2517	1.2346	1.2174	1.1145	1.1145	1.0288	.6001
24	1.286	1.2517	1.2346	1.2003	1.0974	1.0974	1.0288
Max	1.3375	1.3032	1.3032	1.2174	1.2517	1.1317	1.0288
Min	.9259	.9431	.9945	.8402	.8745	.7716	.3944
Avg	1.1753	1.1453	1.1360	1.0745	1.0624	1.0039	.7871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 209 / 11 KV Dongri bz

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5338	3.4414	3.5522	2.7347	3.2105	3.513	3.1019
2	3.5153	3.3604	3.573	2.7924	3.2312	3.4945	3.1304
3	3.4968	3.349	3.536	2.7739	3.1758	3.4945	3.0117
4	3.4598	3.275	3.4806	2.6815	3.1388	3.4945	2.8431
5	3.4414	3.2011	3.3882	2.5891	3.0072	3.4945	2.7877
6	3.2588	3.2611	3.4112	2.6123	3.0302	3.4044	2.8847
7	3.3765	3.3026	3.3927	2.5776	1.9052	2.8315	2.85
8	2.8685	3.3396	2.7323	2.73	3.2034	3.2958	2.8707
9	1.9908	2.7877	3.5451	2.8801	3.3927	3.5036	3.0393
10	2.268	1.9841	3.6584	3.0879	2.1338	2.21	2.9262
11	1.2197	1.1643	3.6745	3.275	3.4644	3.4482	3.155
12	1.3121	1.2752	3.4274	3.4044	3.6122	2.1338	3.1226
13	1.4045	1.423	1.423	1.4784	1.6448	1.4045	1.3491
14	1.423	1.4415	1.3676	1.4415	1.5339	1.5524	1.4045
15	1.4045	1.4784	1.2752	1.4969	1.6632	1.3491	1.4415
16	1.2567	1.4415	1.2752	1.3676	1.5708	1.2382	1.4045
17	1.2382	1.386	1.2752	1.1827	1.1458	1.0349	1.386
18	1.1827	1.2752	1.2936	1.1458	1.1831	1.0349	
19	1.423	1.5524	1.3676	1.4415	1.4403	1.2567	
20	1.6263	1.7926	1.7187	1.7002	1.922	1.386	1.0164
21	1.6448	1.7741	1.8111	1.6817	1.9404	1.386	1.0903
22	1.5893	1.7556	1.7187	1.7187	1.885	1.4045	.924
23	1.5339	1.6632	1.6263	1.6263	1.8111	1.386	1.1643
24	2.9795	2.8501	2.58	2.8294	3.0766	2.6724	1.7301
Max	3.5338	3.4414	3.6745	3.4044	3.6122	3.513	3.155
Min	1.1827	1.1643	1.2752	1.1458	1.1458	1.0349	.924
Avg	2.1853	2.2323	2.5043	2.2187	2.3884	2.3093	2.2106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 210 / 11 KV Chikhala

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4556	1.4055	1.3843	1.4299	1.4215	.9938	1.3552
2	1.5498	1.6783	1.5389	1.6259	1.4225	.9945	1.6354
3	1.4367	1.6581	1.5117	1.6486	1.3717	.9907	1.543
4	1.3982	1.4413	1.5076	1.5002	1.4002	.9938	1.4352
5	1.1525	1.2443	1.1705	1.1469	1.1534	1.0149	1.1871
6	1.0801	1.1709	1.1102	1.1113	1.1404	.9573	1.1704
7	1.2586	1.1483	1.2228	1.2269	1.1583	.9463	1.2062
8	1.1524	1.1746	1.2295	1.262	1.1769	1.0964	1.123
9	1.1446	1.3817	1.4307	1.424	1.3689	1.2959	1.2573
10	2.4253	2.7614	2.4081	2.1889	.7506	1.3504	2.4617
11	2.6909	3.1125	2.9826	2.3335	1.3333	2.6924	2.6461
12	2.5284	3.0092	3.0877	2.9037	1.218	2.7925	2.9508
13	1.9286	2.4973	2.4532	2.6161	1.0094	2.1859	2.2756
14	2.5101	2.7635	2.5147	2.4105	.7948	2.2567	2.6095
15	2.0488	2.2561	2.1563	2.1952	.8651	1.8865	2.2331
16	1.0923	1.1172	1.0589	1.1153	.8922	.9326	1.1167
17	1.6402	1.588	1.6257	1.4946	.8705	1.6978	1.7505
18	2.5114	2.4713	2.7723	2.0094	.9844	2.2615	1.8961
19	2.4922	2.5216	2.7205	2.3805	.8913	2.327	.3224
20	2.6023	2.065	1.9203	2.1194	.8604	2.1176	1.8652
21	1.8297	2.2771	2.1573	1.7604	.9336	2.2916	3.4259
22	1.7426	1.9098	2.0178	1.7355	.9842	1.953	2.576
23	1.4927	1.3944	1.4424	1.1858	1.0741	1.5121	1.3238
24	1.2832	1.2391	1.218	1.2335	1.1126	1.134	1.1822
Max	2.6909	3.1125	3.0877	2.9037	1.4225	2.7925	3.4259
Min	1.0801	1.1172	1.0589	1.1113	.7506	.9326	.3224
Avg	1.7686	1.8869	1.8601	1.7524	1.0912	1.6115	1.7729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 211 / 11 KV Nakadongari AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0143	.0141	.0141	.0141	.0139	.0139	.0139
2	.0143	.0141	.0141	.0141	.0139	.0139	.0139
3	.0143	.0141	.0141	.0141	.0139	.0139	.0139
4	.0143	.0141	.0141	.0141	.0139	.0139	
5	.0143	.0141	.0141	.0141	.0139	.0139	.0139
6	.0143	.0141	.0141	.0141	.0139	.0139	.0139
7	.0143	.0282	.0282	.0141	.0139	.0139	.0278
8	.0286	.0282	.0423	.0278	.0278	.0278	.0139
9	.0143	.0282	.0141	.0139	.0139	.0139	.0278
10			.0141	.0139			.0278
11			.0141	.0139	.0139	.0139	.0139
24	.0143	.0141	.0141	.0141	.0139	.0139	.0139
Max	.0286	.0282	.0423	.0278	.0278	.0278	.0278
Min	.0143	.0141	.0141	.0139	.0139	.0139	.0139
Avg	.0157	.0183	.0176	.0152	.0152	.0152	.0177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)

Feeder No / Name : 201 / 11 KV EMD

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1079	.3504	1.105	.0566	.068	.1211	.0581
2	1.1087	1.033	1.0482	.0566	.0604	.1051	.0574
3	1.0595	.9938	1.0513	.0566	.0566	.1082	.0566
4	1.0307	.7387	1.0293	.0377	.0566	.0795	.0566
5	1.0315	.5365	1.0498	.0377	.0377	.0642	.0566
6	.2835	.4311	1.0029	.1928	.0189	.0415	.0189
7	.0975	.1888	.4849	.1865	.0189	.0377	.0189
8	.142	.1707	.0757	.1713	.0392	.0385	.0574
9	.1775	.1949	.2155	.0764	.0446	.084	.1008
10	.2768	.2109	.8815	.0757	.0377	.0385	.0499
11	.6386	.2306	1.0588	.1031	.0627	.1013	.0757
12	.9966	.4378	1.0649	.1623	.0886	.0937	.2806
13	1.0511	.2184	1.0664	.1008	.04	.2715	.1747
14	1.0338	.1008	1.0505	.0566	.0574	.1442	.0566
15	1.0042	.1705	1.0943	.0377	.0635	.0636	.0754
16	.3978	.1768	.9682	.269	.065	.0894	.0604
17	.992	.1941	1.1556	.2943	.2231	.19	.0377
18	.9459	.1722	.8587	.1063	.1452	.1375	.0377
19	.9783	.3079	.9981	.0415	.0574	.0589	
20	.5197	1.0458	.9642	.0438	.0566	.0566	.0377
21	.1865	.9851	1.0443	.0377	.0566	.0566	.0377
22	.9488	.9775	.9989	.0377	.1638	.0612	.0377
23	.9798	1.0626	.9823	.2661	.142	.1046	.0377
24	1.0306	.662	.6267	.1907	.1953	.0754	.0566
Max	1.1087	1.0626	1.1556	.2943	.2231	.2715	.2806
Min	.0975	.1008	.0757	.0377	.0189	.0377	.0189
Avg	.7508	.4830	.9115	.1123	.0773	.0926	.0668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)

Feeder No / Name : 202 / 11kv Balapur

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6897	.5828	.5858	.6777	.6799	.6685	.6662
2	.5258	.5586	.5692	.6043	.6474	.6429	.5798
3	.5056	.5327	.5676	.5926	.5828	.6185	.5624
4	.5155	.5418	.557	.5382	.6093	.5866	.5448
5	.5094	.4618	.5207	.5253	.604	.5912	.5087
6	.2279	.3949	.4016	.383	.4239	.4307	.4109
7	.1661	.2642	.262	.2984	.6082	.3098	.2862
8	.2725	.3693	.3117	.349	.403	.7087	.6131
9	.2984	.3673	.2763	.7864	.3961	.5051	.3595
10	.2961	.3426	.3347	.3472	.6239	.3191	.3248
11	.2984	.3292	.3589	.71	.5958	.4043	.5944
12	.3931	.5059	.4369	.6526	.4765	.2728	.3174
13	.434	.4643	.4736	.5045	.5432	.4864	.4157
14	.4834	.4138	.4765	.4462	.4735	.4264	.4294
15	.4431	.3605	.4569	.4454	.4546	.4115	.4401
16	.5151	.375	.5116	.4645	.5098	.3971	.5327
17	.4553	.3083	.4872	.7509	.7398	.5297	.5211
18	.3916	.3106	.6912	.3088	.4544	.4205	.39
19	.4264	.5703	.5218	.8169	.4938	.2652	.1478
20	.3254	.5388	.6095	.5517	.8093	.681	.5858
21		.5881	.6981	.6638	.7011	.6314	.5573
22		.5889	.6383	.7556	.67	.5897	.5578
23	.607	.6276	.7237	.6921	.6905	.608	.557
24	.6585	.6238	.6792	.7103	.748	.7042	.6045
Max	.6897	.6276	.7237	.8169	.8093	.7087	.6662
Min	.1661	.2642	.262	.2984	.3961	.2652	.1478
Avg	.4290	.4592	.5063	.5656	.5808	.5087	.4795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 211 / 11 KV Sihora Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4373	1.4083	1.4232	2.758	2.7168	2.7263	1.5223
2	1.4373	1.4083	1.4232	2.7221	2.6578	2.7263	
3	1.4022	1.4083	1.4232	2.7042	2.6235	2.7263	.8775
4	1.3672	1.4083	1.4232	2.6505	2.6292	2.7263	.8059
5	1.3496	1.3108	1.3717	2.5431	2.5941	2.5549	.788
6	1.2269	1.1961	1.2689	1.9879	1.8755	2.0576	.7164
7	.7011	1.1768	1.1831	1.5043	1.4548	1.4918	.6268
8	1.1744	1.1934	1.1831	1.4685	1.5775	1.4918	.5731
9	1.2971	1.2003	1.2689	1.5043	1.6301	1.4918	1.0341
10	1.6118	1.5089	1.2346	1.6651	1.7147	1.5947	1.1043
11	1.6118	1.8004	1.3253	1.893	2.0062	1.9342	1.1744
12	2.2291	2.0576	2.1312	1.1043	1.2003	1.4506	1.8755
13	2.3491	2.3491	2.3998	1.6301	1.406	1.5939	1.7353
14	2.3148	2.3491	2.3998	1.6301	1.5089	1.6476	2.0508
15	2.2634	2.3663	2.3282	1.5424	1.5089	1.6297	1.9456
16	2.0062	2.2291	2.0595	1.3496	1.3889	1.3969	1.9456
17	1.6975	1.8004	1.8267	1.2971	1.3375	1.1462	1.4403
18	1.7556	1.5775	1.7551		1.3203	1.0745	
19	2.3594	2.0233	2.0416		1.406	1.4327	
20	2.5606	2.6749	2.9371	1.4548	1.6118	1.576	
21	3.0308	2.8464	3.0624	1.5775	1.6289	1.7372	1.1043
22	3.0123	2.915	3.0445	1.6476	1.6804	1.5939	1.1744
23	2.8753	2.7435	2.7938	1.56	1.6632	1.5581	1.1744
24	1.4373	1.3413	1.406	2.7221	2.7519	3.0007	1.5402
Max	3.0308	2.915	3.0624	2.758	2.7519	3.0007	2.0508
Min	.7011	1.1768	1.1831	1.1043	1.2003	1.0745	.5731
Avg	1.8545	1.8456	1.8631	1.8598	1.8289	1.8483	1.2605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 212 / 11 KV Bapera Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4271	2.3767	2.3356	1.8446	1.8229	1.7364	.9313
2	2.3846	2.3462	2.3051	1.8267	1.7878	1.7364	
3	2.3541	2.3462	2.3051	1.7909	1.7878	1.7364	
4	2.332	2.3462	2.3051	1.7909	1.7528	1.7364	
5	2.2268	2.229	2.2215	1.7551	1.6476	1.6832	
6	2.14	2.0378	2.0414	1.1104	.9991	1.0808	
7	2.1704	2.0856	2.0414	.9492	.8413	.8859	
8	2.319	2.1813	2.1201	.9313	.8063	.8682	.5373
9	2.2276	2.0768	2.2392	.9671	.8589	.9391	.5258
10	2.1466	1.9607	2.1653	.964	.9036	1.0277	.5609
11	1.1694	1.0099	2.1255	1.2094	1.1163	.8775	.5434
12	1.258	1.1871	2.2383	.5959	.9214	.8775	.964
13	1.4706	1.382	1.3073	2.4021	1.0985	.985	1.3672
14	1.4529	1.382	1.5074	2.4326	1.0985	.9671	1.6301
15	1.3466	1.3289	1.4198	2.271	1.0454	.8238	1.6126
16	1.1871	1.1517	1.0867	2.1925	1.0099	.788	1.5775
17	1.0277	.9568	1.0341	.7537	.9214	.6626	1.1043
18	.8842	.8859	.8764	1.5317	.8505	.6626	
19	1.4563	1.3466	1.2445	1.7033	.9214	.788	
20	1.7857	1.825	1.9342	2.066	1.0631	.9492	
21	1.9244	1.9313	2.1312	2.127	1.1163	.9671	.6135
22	1.8551	1.8781	2.0953	2.1491	1.0631	.9492	.7011
23	1.6817	1.7896	1.9342	2.2101	1.0277	.9313	.5847
24	1.1043	1.1443	1.1517	3.0083	1.8229	1.7718	.9134
Max	2.4271	2.3767	2.3356	3.0083	1.8229	1.7718	1.6301
Min	.8842	.8859	.8764	.5959	.8063	.6626	.5258
Avg	1.7638	1.7161	1.8403	1.6910	1.1785	1.1013	.9445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 213 / 11 KV Chandpur Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9804	1.792	1.9652	1.3432	1.6478	1.2851	.8417
2	2.0109	1.792	1.9652	1.3432	1.6301	1.267	.8059
3	1.9804	1.792	1.9652	1.3253	1.6478	1.267	.7522
4	2.0109	1.792	1.9348	1.3073	1.5947	1.267	.7343
5	1.9804	1.7204	1.8805	1.2894	1.5947	1.3032	.6984
6	1.7423	1.6057	1.6985	.9671	.8505	.9774	.6268
7	1.6508	1.6236	1.668	.8059	.6201	.7964	.5373
8	1.6026	1.6415	1.6985	.788	.7619	.7602	.5373
9	1.5545	1.6499	1.6318	.8596	.8869	.7964	.567
10	1.5463	1.4565	1.672	.8328	.905	.905	.6024
11	.9774	.8145	1.7558	.9568	.9593	1.1104	.6379
12	1.0679	.7964	1.9746	.7796	.7783	.8059	.7442
13	1.1584	.7602	1.1568	1.8209	.8869	.9313	.7442
14	1.1403	.7602	1.2094	1.8209	.9231	.9313	.7973
15	1.0679	.724	1.1744	1.5013	.8326	.9313	.8859
16	.9774	.724	.964	1.451	.8145	.7164	.8859
17	.7964	.7602	.8939	1.4708	.2534	.7343	.6201
18	.8238	.7421	.815	1.5368	.5611	.6984	
19	1.2357	1.1765	1.0808	1.8564	.6697	.8238	
20	1.5223	1.5384	1.4723	1.9932	1.086	.9313	
21	1.5043	1.5023	1.56	2.0768	1.0136	.8954	.8505
22	1.4506	1.3756	1.5074	2.0591	.9955	.8417	.7011
23	1.379	1.3937	1.3672	1.9932	.9955	.7701	.6836
24	.9745	.8954	.9412	2.367	1.6832	1.3394	2.0305
Max	2.0109	1.792	1.9746	2.367	1.6832	1.3394	2.0305
Min	.7964	.724	.815	.7796	.2534	.6984	.5373
Avg	1.4223	1.2845	1.4980	1.4394	1.0247	.9619	.7755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064026 / 33/11 Nakadongari

Feeder No / Name : 201 / 11KV Pathari G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8054	1.8023	1.7721	1.736	1.6575	1.7985	1.869
2	1.7398	1.744	.9054	1.7314	1.7276	1.7901	.9556
3	1.7093	1.716	1.6415	1.7009	1.7146	1.7749	1.7951
4	1.6971	1.6993	1.6204	1.6606	1.7014	1.7477	1.8446
5	1.6395	1.6629	1.5813	1.6252	1.6878	1.7576	1.7652
6	1.3519	1.3596	1.2982	1.323	1.4013	1.444	1.5301
7	1.0738	1.0801	1.0301	1.0353	1.0808	1.1255	1.1515
8	.9499	1.0349	.365	.9494	1.0296	1.0517	1.0843
9	1.0486	1.1408	1.2254	.9968	1.053	1.1405	1.2274
10	1.0701	1.2729	.9778	1.154	1.2339	1.2953	1.2064
11	1.2602	1.3285	1.3557	1.2706	1.3054	1.3702	1.2251
12	1.4439	1.4642	1.4449	1.3784	1.4411	1.5821	1.4438
13	1.5368	1.6057	1.5072	1.5733	1.592	1.7257	1.6088
14	1.5983	1.6665	1.4815	1.6012	1.6385	1.7741	1.7378
15	1.494	1.6053	1.4514	1.5303	1.5932	1.6446	1.7515
16	1.4033	1.3039	1.267	1.2556	1.3957	1.1767	1.539
17	1.2292	1.142	1.0745	.9606	1.2807	.237	1.3139
18	1.1355	1.1762	1.0452	1.0334	1.2645		.4557
19	1.4554	1.2919	1.3138	1.584	1.3504		
20	1.8915	1.9753	.8916	1.9388	2.0084	2.1472	.8139
21	1.8675	2.0618	1.6225	2.0434	2.1178	1.9098	1.7044
22	1.8866	2.0154	1.8789	2.0125	2.061	1.9715	1.7861
23	1.8862	1.8919	1.8305	1.8746	1.8985	1.957	1.72
24	1.8589	1.8281	1.7917	1.7977	1.8023	1.8748	1.7596
Max	1.8915	2.0618	1.8789	2.0434	2.1178	2.1472	1.869
Min	.9499	1.0349	.365	.9494	1.0296	.237	.4557
Avg	1.5014	1.5362	1.3489	1.4903	1.5432	1.5589	1.4473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064026 / 33/11 Nakadongari

Feeder No / Name : 203 / 11KV KAWALEWADA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7465	1.7404	1.065	1.4746	1.6409	1.5546
2	1.7604	1.7269	1.7404	1.0364	1.4746	1.5623	
3	1.7436	1.7269	1.7604	1.0526	1.4918	1.6575	1.4737
4	1.7072	1.7238	1.757	1.0688	1.4918	1.6741	1.4575
5	1.7238	1.7404	1.7939	1.0814	1.5083	1.6741	1.5238
6	1.7901	1.861	1.95	1.2125	1.6078	1.6385	1.7238
7	1.9281	1.9784	2.0008	1.2289	1.6575	1.7404	1.8143
8	1.4419	1.7939	.8139	1.4575	1.7901	1.7404	1.8275
9	1.4752	1.6762	2.1195		1.9281	1.9113	1.8233
10			2.0485	1.7295	1.8778	1.8896	1.8233
11			1.9595	1.6766	1.8778	1.8896	1.7772
24	1.6741	1.6244	1.6575	1.065	1.4091	1.5912	1.5746
Max	1.9281	1.9784	2.1195	1.7295	1.9281	1.9113	1.8275
Min	1.4419	1.6244	.8139	1.0364	1.4091	1.5623	1.4575
Avg	1.6938	1.7598	1.7785	1.2431	1.6324	1.7175	1.6703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 201 / 11 KV SIHORA G

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.7282	.7282	.7207	.7392	.7468	.6722
2	.7207	.7023	.7282	.7023	.7316	.7282	.6722
3	.7023	.7095	.7095	.6908	.7468	.7095	.6722
4	.6767	.7095	.6908	.6908	.7133	.7095	.6722
5	.6584	.6838	.6535	.5788	.695	.6908	.6348
6	.4435	.4251	.3734	.4294	.439	.462	.4481
7	.3366	.3292	.2865	.2614	.3403	.3326	.2561
8	.333	.3475	.3258	.2481	.3366	.3326	.2743
9	.3582	.3511	.3475	.3224	.3696	.3696	.2534
10	.3658	.3734	.439		.3801	.362	
11	.4572	.4024	.462	.4835	.4251	.4755	.3475
12	.499	.4435	.5175	.5359	.4755	.5304	.4207
13	.5914	.5487	.5729	.6154	.6036	.5914	.4938
14	.5304	.5729	.5975	.5914	.6036	.6099	.5601
15	.5304	.3696	.5544	.5487	.5544	.5729	.5544
16	.4024	.4572	.4525	.4207	.4251	.3582	.499
17	.3658	.3801	.3544	.3155	.3734	.197	.3841
18	.3142	.3121	.3881	.3429		.2507	
19	.5487	.499	.5068	.5359	.567	.5729	
20	.6722	.6908	.7392	.6653	.7468	.6722	.5658
21	.7133		.7655	.7655	.7842	.7095	.6036
22	.7682	.7842	.7842	.7762	.7655	.7282	.6348
23	.7655	.7762	.7655	.7655	.7499	.7392	.6099
24	.7392	.7468	.7392	.7655	.7392	.7207	.7655
Max	.7682	.7842	.7842	.7762	.7842	.7468	.7655
Min	.3142	.3121	.2865	.2481	.3366	.197	.2534
Avg	.5513	.5367	.5618	.5553	.5785	.5488	.5236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 202 / 11 KV MOHADI G

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7299	1.7337	1.7728	1.7023	1.7589	1.7893	1.6907
2	1.6947	1.685	1.7958	1.6956	1.7242	1.7806	1.6221
3	1.669	1.6736	1.7395	1.666	1.707	1.7318	1.5996
4	1.6332	1.675	1.7017	1.6621	1.6956	1.728	1.5887
5	1.5889	1.6417	1.653	1.5242	1.6591	1.6895	1.4339
6	1.3565	1.3883	1.4323	1.4243	1.4184	1.4548	1.2525
7	1.0679	1.1301	1.3278	1.0717	1.1165	1.0925	.9446
8	1.031	.9764	1.133	.9442	.989	.9574	.8833
9	1.0387	.9427	1.0852	.9785	1.0639	.9411	.9745
10	1.057	.996	1.0822	.5068	1.1379	.9449	.5296
11	1.1445	1.1069	1.1335	1.0147	1.0902	1.1046	1.0183
12	1.3251	1.3794	1.2702	1.2129	1.3799	1.3573	1.0445
13	1.5154	1.4331	1.3992	1.3916	1.4987	1.5116	1.2851
14	1.5966	1.5733	1.4186	1.483	1.5203	1.596	1.4254
15	1.5074	1.5963	1.3855	1.4491	1.5209	1.4838	1.3965
16	1.3263	1.5849	1.3123	1.4533	1.3611	.7506	1.2761
17	1.1309	1.4293	1.3131	1.1461	1.2571	.7287	1.191
18	1.2704	1.3274	1.3913	1.0526	1.2174	1.1835	.5906
19	1.2744	1.3016	1.3555	1.121	1.3443	1.4293	.301
20	1.512	1.576	1.6438	1.4332	1.7238	1.5729	.5723
21	1.6301	.8764	1.7101	1.6585	1.7924	1.6154	.9934
22	1.7747	1.867	1.7924	1.7878	1.8728	1.6377	1.0624
23	1.8206	1.8471	1.811	1.8076	1.8755	1.6941	1.3892
24	1.7855	1.8198	1.7985	1.7596	1.8122	1.7589	1.568
Max	1.8206	1.867	1.811	1.8076	1.8755	1.7893	1.6907
Min	1.031	.8764	1.0822	.5068	.989	.7287	.301
Avg	1.4367	1.4400	1.4774	1.3728	1.4807	1.3973	1.1514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 203 / 11 KV TUMSAR town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6911	1.6834	1.7204	1.7204	1.8084	1.8572	1.7215
2	1.5838	1.6252	1.672	1.656	1.7333	1.8084	1.6183
3	1.5432	1.5699	1.5916	1.6293	1.6612	1.7404	1.5268
4	1.4346	1.5432	1.5356	1.5825	1.6168	1.7052	1.4901
5	1.3832	1.4274	1.4444	1.4853	1.5939	1.688	1.4317
6	1.291	1.3189	1.3024	1.363	1.4617	1.5199	1.3017
7	1.1279	1.2213	1.173	1.2079	1.2849	1.338	1.1767
8	.0305		.0876			.0076	.0953
9	1.2555	1.2727	1.3024	1.3508	1.4361	1.4099	1.2429
10	1.3763	1.4517	1.4569	.7621	1.5288	1.5211	.6211
11	1.6926	1.7054	1.6979	1.6751	1.7082	1.7359	1.3153
12	1.85	1.8524	1.8606	1.8969	1.9052	1.9426	1.4921
13	1.982	2.0302	1.9868	1.9856	2.0136	2.0557	1.6408
14	2.0959	2.1003	2.1372	2.0889	2.0972	2.1003	1.7817
15	2.1232	2.1818	2.122	2.1193	2.0873	2.1225	1.8475
16	2.0942	2.1391	2.122	2.1403	2.0591	1.9913	1.8475
17	2.0098	2.0462	1.9781	2.0112	1.9318	1.8229	1.7437
18	1.8511	1.8347	1.8374	1.7768	1.7633	1.7825	1.5814
19	1.8861	1.9031	1.8385	1.9399	1.8617	1.8812	.1029
20	2.0085	2.0253	1.9449	1.9677	1.8823	1.8873	1.5188
21	1.848	1.025	1.8655	1.9033	1.8157	1.7661	1.4936
22	1.6453	1.6617	1.7497	1.8263	.9374	1.6598	1.4975
23	1.7138	1.7242	1.7535	1.816	1.8725	1.7676	1.6052
24	1.7459	1.7328	1.7623	1.7943	1.8694	1.8001	1.6673
Max	2.1232	2.1818	2.1372	2.1403	2.0972	2.1225	1.8475
Min	.0305	1.025	.0876	.7621	.9374	.0076	.0953
Avg	1.6360	1.6990	1.6643	1.7260	1.7361	1.7046	1.3901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 204 / 11 KV JAMB town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.8339	4.8023	4.8823	4.946	4.9899	5.0648	4.3803
2	4.6169	4.5565	4.6576	4.804	4.9186	4.965	4.897
3	4.374	4.3737	4.5151	4.636	4.7775	4.9013	4.6418
4	4.1002	4.1716	4.3172	4.4559	4.6639	4.6659	4.3776
5	3.8837	3.9384	4.0132	4.0085	4.4146	4.5571	4.0904
6	3.5102	3.5056	3.5183	3.7319	3.9758	4.1444	3.6866
7	2.8532	3.4351	2.926	3.2589	3.4637	1.8252	3.1067
8	.1753	.1105	.6363	.1372	.1257	.16	.7049
9	3.0416	2.8597	2.9377	3.1771	3.4921	3.2651	2.7715
10	2.8886	2.7301	1.1926	1.4365	3.2439	3.1753	1.345
11	3.1763	2.9871		3.2857	3.4735	3.4363	2.7777
12	3.3684	3.4287		3.703	3.8647	3.827	3.0557
13	3.8619	3.8629		4.149	4.2865	4.1822	3.6883
14	4.1963	4.1273		4.5112	4.4666	4.4727	4.1947
15	4.2589	4.2736	5.3338	4.6293	4.385	4.5402	4.1964
16	4.1286	4.1544	5.058	4.3689	4.3477	3.9285	4.1111
17	3.7618	3.6548	4.5359	3.8379	3.9163	3.0399	3.8234
18	3.2673	3.1831	3.8813	3.2464	3.5582	2.9283	3.2831
19	3.3501	3.3678	3.7334	3.3091	3.6869	3.4798	.7201
20	3.8792	3.9391	4.2144	3.8104	4.3606	3.9309	2.8666
21	4.0892	1.97	4.626	4.4053	4.6784	4.369	3.5552
22	4.6075	4.7413	5.0486	5.0557	5.1492	4.8533	4.0344
23	5.0079	5.1732	5.1999	5.2778	5.2386	5.2629	4.3727
24	4.997	5.013	5.0776	5.1532	5.2309	5.2119	4.7737
Max	5.0079	5.1732	5.3338	5.2778	5.2386	5.2629	4.897
Min	.1753	.1105	.6363	.1372	.1257	.16	.7049
Avg	3.7595	3.6817	4.0153	3.8890	4.1129	3.9245	3.4773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 205 / 11kv Sihora AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4489	.5281	.5569	.5639	.4967	.5312	.4214
2	.4287	.5281	.5639	.5639	.4967	.5344	.4054
3	.4172	.5218	.5921	.5418	.4967	.5441	.4001
4	.4801	.5121	.5639	.535	.4816	.5468	.4054
5	.4744	.5376	.5502	.602	.4877	.583	.4001
6	.5898	.6481	.7074	.6321	.602	.6882	.4458
7	.6161	.7499	.7253	.6539	.6327	.6874	.4816
8	.6015	.7716	.7655	.6984	.6481	.6944	.503
9	.6472	.7499	.7407	.7343	.7099	.7116	.4816
10			.6401		.6874	.7116	
11			.6249	.6874	.578	.4111	.5344
24		.5121	.578	.5335	.4967	.5182	
Max	.6472	.7716	.7655	.7343	.7099	.7116	.5344
Min	.4172	.5121	.5502	.5335	.4816	.4111	.4001
Avg	.5227	.6059	.6341	.6133	.5679	.5968	.4479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 207 / 11kv HASARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7364	1.8347	1.5913	1.6412	1.629	1.6073	1.5033
2	1.6103	1.6785	1.5882	1.6412	1.6294	1.5326	1.5376
3	1.5639	1.6343	1.5828	1.6465	1.7262	1.5375	1.5376
4	1.5524	1.632	1.544	1.5977	1.738	1.4865	1.4366
5	1.5478	1.5856	1.3916	1.5184	1.6465	1.5851	1.456
6	1.3341	1.3337	1.1759	1.3417	1.4704	1.3866	1.3463
7	1.1557	1.052	.959	1.1838	1.252	1.1846	1.1301
8	1.0822	1.076	.9331	1.0802	1.2654	1.0943	1.0143
9	1.0852	1.0741	1.0676	1.0798	1.2105	1.1344	1.0177
10	1.0623	1.0638	1.1008	.7011	1.1488	1.2006	.6771
11	1.1229	1.2041	1.198	1.1275	1.0463	1.2341	1.0444
12	1.1332	1.068	.8028	.8177	1.4359	1.4511	1.1004
13	1.4046	1.2483	1.3946	1.4541	1.4541	1.4766	1.3001
14	1.3931	1.1983	1.4365	1.4606	1.3996	1.5555	1.4343
15	1.4007	1.2162	1.3478	1.4171	1.3352	1.416	1.2383
16	1.3154	1.1423	1.2018	1.3482	1.1953	.8154	1.2109
17	1.2083	1.1636	1.0543	1.166	1.1484	.2793	1.1892
18	1.2163	1.0711	1.0497	1.0639	1.0806	.4816	.6782
19	1.3145	1.1945	1.2459	1.3214	1.2544	.9747	
20	1.6381	1.5894	1.6126	1.4861	1.6218	1.4815	1.1157
21	1.6381	1.0681	1.6679	1.6259	1.56	1.6443	1.2943
22	1.7806	1.6713	1.7589	1.6298	1.773	1.7158	1.4442
23	1.8473	1.6503	1.754	1.6366	1.754	1.7456	1.3832
24	1.834	1.6682	1.6134	1.6446	1.7418	1.6591	.9652
Max	1.8473	1.8347	1.7589	1.6465	1.773	1.7456	1.5376
Min	1.0623	1.052	.8028	.7011	1.0463	.2793	.6771
Avg	1.4157	1.3383	1.3364	1.3596	1.4382	1.3200	1.2198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 208 / 11 kv GANDHINAGAR town

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7738	3.735	3.8104	3.8687	4.0367	4.1503	3.581
2	3.5879	3.6054	3.7925	3.7925	3.9426	3.962	3.8294
3	3.4751	3.472	3.6424	3.6424	3.8485	3.9247	3.6793
4	3.3052	3.3585	3.5094	3.4922	3.7536	3.8112	3.5292
5	3.1181	3.1181	3.2838	3.1573	3.6603	3.6229	3.3585
6	2.7069	2.8201	2.8571	2.87	3.1573	3.248	3.0583
7	2.2367	2.2565	2.2565	2.3674	2.5454	2.5938	2.4805
8	.2286	.1524	.1524	.2286	.2286	.3048	.4572
9	2.0546	2.0279	2.178	2.2912	2.5152	2.3396	2.0279
10	1.9418	1.9517	2.0546	1.0669	2.4005	2.215	.9907
11	2.0648	1.9886	2.1338	2.215	2.476	2.2889	2.1125
12	2.2889	2.2496	2.9729	2.4889	2.7023	2.476	2.3125
13	2.7762	2.7023	2.6787	2.9043	3.1246	2.8132	2.6398
14	2.8746	2.8895	2.9112	3.2061	3.1848	3.2434	3.0926
15	2.9805	3.0026	3.024	3.2061	3.3029	3.3398	3.2061
16	2.8548	2.8918	2.9657	3.0636	3.192	2.8963	3.1688
17	2.5411	2.6186	2.6307	2.6464	2.8445	2.2801	2.8685
18	2.1803	2.2912	2.2172	2.1818	2.4043	2.1388	2.3799
19	2.2127	2.2127	2.2127	2.4127	2.601	2.4367	.2286
20	2.716	2.7762	2.8525	2.7252	3.0708	2.7393	2.5651
21	2.9657	1.5242	3.1158	3.1299	3.357	3.0552	2.6398
22	3.3768	3.453	3.6031	3.7151	1.7528	3.6588	3.0179
23	3.735	3.7708	3.9232	3.9994	4.2463	3.9773	3.357
24	3.8675	3.735	3.8866	3.9796	4.1708	4.1503	3.6572
Max	3.8675	3.7708	3.9232	3.9994	4.2463	4.1503	3.8294
Min	.2286	.1524	.1524	.2286	.2286	.3048	.2286
Avg	2.7443	2.6918	2.8611	2.8605	3.0216	2.9861	2.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 401 / 33 KV GOBARWAHI Feeder
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.1816	7.756	8.8415	7.6566	7.1697	7.0954	6.5661
2	8.9712	7.8167	8.8969	7.7743	7.2417	6.9022	6.5101
3	8.578	7.7047	8.786	7.5457	7.1148	6.7902	6.5101
4	8.2802	7.5274	8.3911	7.0954	6.9702	6.7113	6.2814
5	7.9961	7.4154	7.9241	6.4232	6.6667	6.7902	5.8288
6	5.8728	6.2015	6.9113	5.8619	5.807	5.3899	4.872
7	4.8497	5.072	5.5224	4.6994	5.0938	4.1089	3.906
8	4.8497	5.0652	5.0915	5.0915	5.0401	5.6819	4.2981
9	4.0455	5.1761	5.8482	5.9362	5.5127	6.2208	4.4101
10	6.6312	7.2034	8.2665	3.658	6.3374	6.9582	2.7435
11	7.4903	7.8075	8.7306	7.9012	6.8113	7.2131	6.0574
12	8.0515	7.7532	9.1741	7.6566	6.7004	7.6012	6.5826
13	8.4951	7.947	9.0427	7.8229	6.9022	7.7121	6.9776
14	8.8415	8.514	9.3473	7.6395	6.4232	7.6566	7.5835
15	7.7743	7.1788	7.8921	6.7307	6.4717	6.3746	6.7627
16	6.8953	6.8313	7.2245	6.438	6.3609	4.6639	6.4163
17	8.1624	7.7121	8.6009	6.5787	6.7342	5.9259	7.0399
18	8.4328	8.011	8.993	6.1871	5.9105	6.1391	2.3868
19	8.8855	8.0676	8.6569	7.4989	6.8044	6.07	
20	7.5789	9.465	9.6788	8.2041	7.7515	7.5457	4.1815
21	8.1207	5.2584	10.7522	8.7689	7.9961	7.6012	5.7167
22	8.1528	9.3541	9.4165	7.7189	7.6395	7.0233	3.9078
23	8.0921	8.7306	8.0968	7.0599	7.2062	6.2814	4.2524
24	8.5402	8.2694	8.2762	7.6349	7.2245	7.0142	5.647
Max	9.1816	9.465	10.7522	8.7689	7.9961	7.7121	7.5835
Min	4.0455	5.0652	5.0915	3.658	5.0401	4.1089	2.3868
Avg	7.6154	7.4099	8.2651	6.8993	6.6621	6.5613	5.4538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 203 / 11 KV Betala G Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6271	1.2946	1.2576	2.3767	1.8458	2.0995	1.3192
2	1.2555	1.2643	1.2406	1.1789	1.2574	1.2026	.3544
3	1.1743	1.2702	1.2041	1.1743	1.2552	1.1987	.7057
4	1.0745	1.2801	1.214	1.0885	1.2311	1.1927	.7232
5	.9778	1.234	1.153	.9762	1.2117	1.1911	.6118
6	.9358	.9803	.9579	.9793	1.0494	1.1031	.6049
7	.7055	.756	.7944	.7467	.8367	.8832	.5577
8	.6062	.5975	.6851	.631	.7533	.6478	.4211
9	.6874	.5921	1.049	.7156	.7289	.7239	.479
10	1.8295	1.8168	.7224	.7693	.7361	.7743	.5868
11	3.3686	3.1421	.7819	.8219	.8547	.8616	.7735
12	3.683	3.6477	2.021	2.0146	1.6903	1.9696	***
13	3.9076	3.7014	3.7168	3.5768	2.585	3.3554	***
14	4.0049	3.7833	3.8679	3.8092	3.0624	3.6374	3.0609
15	3.9792	3.8321	3.7937	3.8882	3.5288	3.6105	***
16	3.8717	3.7444	3.7068	3.4069	3.4408	1.9212	***
17	3.6833	3.5243	3.6015	2.6897	3.515	3.0597	2.9336
18	2.2441	2.1795	3.5554	2.6361	3.4929	3.0613	***
19	1.7535	1.7223	3.6458	2.6147	3.4876	3.088	***
20	1.0875	1.0692	3.7807	2.7279	3.4922	2.9344	.7468
21	1.1995	1.2418	3.8904	2.8974	3.6618	3.1956	***
22	1.3169	1.306	3.9536	3.0068	3.8291	3.3284	***
23	1.3689	1.2765	3.9742	3.0452	3.7685	3.2581	1.2555
24	2.2862	1.3067	2.6947	2.236	2.5785	2.3658	***
Max	4.0049	3.8321	3.9742	3.8882	3.8291	3.6374	51.3832
Min	.6062	.5921	.6851	.631	.7289	.6478	.3544
Avg	2.0262	1.9401	2.3859	2.0837	2.2456	2.1110	19.6800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 205 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2403	1.226	1.134	1.1393	.9602	.6001	.6201
2	1.2403	1.2637	1.1218	1.1765	.9431	.6001	.6201
3	1.1517	1.2826	1.1163	1.0517	.9431	.6001	.6135
4	1.0631	1.094	1.1393	1.0517	.8916	.6001	.6335
5	1.0517	.9431	1.1517	.964	.8573	.6001	.6201
6	1.1393	.9054	.9568	.7011	.823	.6001	.6201
7	.8764	1.1694	.8413	.8764	.5658	.6001	.6201
8	.9745	.964	.8589	.964	.5487	.6201	.6201
9	.964	1.0517	1.0099	.9955	.5487	.543	.6135
10	1.0751	.6859	.7011	1.1831	.6001	.6135	.5258
11	1.226	.9945	1.0479	.8916	.6001	.5258	.6001
12	1.1694	.9774	1.0269	1.1488	.5144	.6335	.6001
13	1.1506	.9259	1.2384	1.046	.6001	.6201	.583
14	1.4146	.9431	.9955	1.1317	.6001	.6201	.583
15	1.4712	1.0974	.964	1.0802	.6001	.6135	.583
16	1.5089	1.0288	1.0517	1.1317	.6001	.5316	.5658
17	1.2071	1.1831	1.267	1.0631	.6001	.6335	.583
18	1.4146	.8916	.8764	1.1831	.6001	.6201	.583
19	1.1744	.8916	.964	1.1317	.6001	.6135	.5316
20	.8589	.8573	.964	1.1145	.6001	.6335	.5316
21	1.0808		.964	.9259	.6001	.6201	.5144
22	1.1744		1.0631	1.0288	.6001	.6201	.5316
23	.9431		1.0517	.9602	.6001	.6201	.5144
24	1.2403	1.226	1.1765	1.0517	.9602	.6001	.6201
Max	1.5089	1.2826	1.267	1.1831	.9602	.6335	.6335
Min	.8589	.6859	.7011	.7011	.5144	.5258	.5144
Avg	1.1588	1.0287	1.0284	1.0413	.6816	.6035	.5847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 206 / 11 KV UFIL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6135	1.1883	.9745	.5258	1.0288	.7716	.9745
2	.6135	.7733	.7712	.6201	1.0288	.7716	.443
3	.6201	.7356	.7619	.7011	.8573	.6001	.4382
4	.8145	.547	.6836	.7888	.7373	.6001	.443
5	.7011	.7356	.6135	.964	.6516	.6001	.5258
6	.6135	.811	.5959	1.0631	.5144	.5144	.5316
7	.9745	.9808	.4207	1.1393	.8402	.7716	.5316
8	1.0631	1.0517	.4031	1.0517	.8059	.7087	.443
9	1.3146	1.1517	.2658	1.1517	.8402	.7087	.7087
10	1.2449	.6173	.3506	1.2003	.7716	.9745	.724
11	1.0185	1.0974	.2658	1.1145	.6859	.9745	.5658
12	.9619	.9259	.4382	.8916	.6859	.7011	.6859
13	1.0751	.9602	.3544	1.166	.7716	.443	.703
14	1.1694	.5487	.3544	.703	.5144	.6335	.3944
15	1.1317	1.0802	.443	.8745	.6859	.8764	.7202
16	1.1694	1.2094	.3544	1.0117	.9431	1.2269	.8059
17	1.226	1.2403	.4525	.9774	.3429	.6201	.6687
18	1.2826	1.1043	.4382	1.2174	.6859	.7087	.6687
19	1.0808	.9465	.443	1.2346	.6859	.6135	.5144
20	1.2094	.8505	.362	1.0288	.3429	.4382	.3944
21	.9816	.9568	.5258	.9602	.4287	.5258	.4801
22	.8238	.6024	.2629	.6344	.3429	.4382	.4287
23	1.0374	.7537	.4382	.8916	.3429	.5258	.823
24	.7011	1.1694	1.0867	.6135	1.0288	.6859	.5316
Max	1.3146	1.2403	1.0867	1.2346	1.0288	1.2269	.9745
Min	.6135	.547	.2629	.5258	.3429	.4382	.3944
Avg	.9768	.9183	.5025	.9385	.6902	.6847	.5895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 401 / 33 kv tumsar

Feeder KV- 33 / INCOMING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.1276	11.8747	12.5297	12.8069	12.2788	12.0988	11.2026
2	12.0862	11.7627	12.308	12.5297	11.9307	12.2668	10.9225
3	11.5775	11.3655	12.2108	12.3228	11.5387	11.9868	10.4744
4	11.1466	10.9785	11.8747	11.2026	10.9191	11.8827	10.0263
5	10.5864	10.3064	10.5304	10.3064	10.6996	10.9785	9.2421
6	8.0659	8.85	8.794	8.794	8.7963	8.4019	7.5057
7	7.0782	7.4291	7.3937	7.3377	7.6818	7.4846	6.3295
8	4.0832	4.5462	4.481	4.481	4.3519	4.7125	3.5848
9	7.1879	7.8172	8.4579	8.4579	8.5791	8.794	6.9456
10	8.3162	8.9986	8.0944		8.7597	9.1861	
11	8.538	8.6694	8.1499	9.6571	9.3542	9.4805	7.6509
12	9.8583	9.4805	8.2053	9.8131	9.6468	9.8131	8.2899
13	11.0345	10.4784	8.6008	10.7545	10.4184	10.5893	
14	11.3146	10.8111	8.7597	10.9785	10.0349	11.0328	10.0903
15	10.5304	10.0903	10.9774	10.1458	10.0903	9.924	9.7462
16	9.4805	9.5359	10.3155	9.8686	9.6902	6.3203	9.2181
17	9.6468	9.3696	10.4184	8.4499	8.794	7.4291	9.1301
18	9.2421	8.7043	9.9703	7.9836	7.6509	7.4291	4.4353
19	10.0903	9.8131	10.4184	9.6468	10.0349	9.0924	
20	10.4744	11.2026	11.5387	10.3624	11.0328	10.1458	7.8978
21	10.8665		12.6589	11.8261	11.4266	10.5339	
22	11.31	12.0428	12.3228	11.7696	9.0181	10.6424	7.0782
23	11.8747	12.2108	11.9868	11.6507	11.9868	10.9785	8.738
24	12.6183	11.9868	12.8624	12.6589	12.5052	12.3788	11.9868
Max	13.1276	12.2108	12.8624	12.8069	12.5052	12.3788	11.9868
Min	4.0832	4.5462	4.481	4.481	4.3519	4.7125	3.5848
Avg	10.0056	9.9272	10.1608	10.1654	9.8842	9.7326	8.5248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 402 / 33kv Jamb

Feeder KV- 33 / INCOMING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3137	2.8235	2.6046	2.0508	2.6818	2.6292	2.2611
2	2.4451	2.7692	2.524	2.0508	2.6818	2.6292	2.0508
3	2.0508	2.7149	2.3663	1.701	2.6818	2.3663	1.7878
4	1.8604	2.7149	2.4188	1.7353	2.6292	2.1033	1.8073
5	1.8604	2.6063	2.5766	1.7541	2.6292	1.8404	1.701
6	1.9667	2.4977	2.073	1.7878	1.9982	1.5775	1.382
7	1.7353	1.9004	1.6827	1.8404	1.7878	1.262	1.2094
8	1.3146	1.8404	1.8073	2.0199	1.7878	1.2226	1.1568
9	1.7353	1.7541	1.6827	1.9136	1.8404	1.3672	1.262
10	3.2579		1.8073	1.9547	1.8004	1.8073	1.4661
11	3.5837	2.8807	2.1262	1.5249	1.9982	1.9456	1.5249
12	4.0181	3.1379	1.7541	3.6808	3.786	3.4705	2.2611
13	4.1267	3.5231	1.7353	3.9438	4.1015	3.9438	3.3653
14	4.0724	3.6677	4.0398		3.9963		3.155
15	3.4208	3.4705	4.0489		3.8386		3.2602
16	3.2036	3.1893	3.9335		3.7334		2.9767
17	3.1493	2.9973	3.774	3.3653	3.7334		2.6292
18	1.3575	1.2094	3.8803	3.4179	3.3128	2.0508	.2058
19	1.5203	1.5415	3.8272	3.786	3.4705	2.7343	.3601
20	2.0633	1.9982	3.9866	3.9963	3.9963	3.1361	.9259
21	2.2262	2.5514	4.1993	3.9963	4.1541	3.2602	1.9547
22	2.3891	2.7109	4.3056	4.1541	4.2593	3.4019	2.0576
23	2.3891	2.6292	4.1015	4.0489	4.2067	3.5231	2.1605
24	4.0398	2.8778	2.5766	2.3663	2.7343	2.6818	2.2857
Max	4.1267	3.6677	4.3056	4.1541	4.2593	3.9438	3.3653
Min	1.3146	1.2094	1.6827	1.5249	1.7878	1.2226	.2058
Avg	2.5875	2.6090	2.9097	2.7185	3.0767	2.4477	1.8836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 201 / 11 KV LAKHANDUR FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.567	.6161	.6478	.6036	.5788
2	.4954	.5716	.5121	.6161	.6478	.5853	.4668
3	.4954	.5716	.5121	.6161	.6478	.5487	.4763
4	.4954	.5716	.5121	.5281	.6287	.5487	.4668
5	.4954	.5144	.4755	.5228	.5716	.5487	.4668
8	.415	.4001	.3841	.4108	.4382	.4024	.3547
9	.3772	.362	.4024	.4108	.4024	.3658	.3361
10	.4191	.3658	.3734	.4854	.4572	.4294	.4001
11	.5525	.5121	.5041	.5525	.567	.4668	.4191
12	.5716	.5304	.5415	.6668	.5853	.5415	.4572
13	.6287	.5853	.5601	.6287	.6219	.5601	.5335
14	.6287	.567	.5975	.6668	.6401	.5601	.5716
15	.6287	.567	.5975	.6668	.6401	.5788	.5335
16	.5335	.5121	.5601	.6668	.5304	.5415	.5335
17	.4954	.4572		.4763	.5121	.4572	.6668
18	.4572	.4024		.5144	.4572	.4382	.4763
19	.5335	.4938		.5906	.5304	.4954	
20	.5906	.567	.5975	.6097	.6036	.5525	
21	.6097	.567	.6287	.6287	.6036	.5788	.4382
22	.6287	.6036	.6287	.6668	.6219	.6036	.4572
23	.6287	.6219	.6478	.6478	.6219	.5975	.5847
24	.5847		.6036	.6224	.6478	.6036	.5788
Max	.6287	.6219	.6478	.6668	.6478	.6036	.6668
Min	.3772	.362	.3734	.4108	.4024	.3658	.3361
Avg	.5380	.5198	.5371	.5823	.5739	.5276	.4898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 202 / 11 KV TEMBHARI AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.363		1.8347	2.1464	1.9204	1.7375	
2			1.8652	2.1616	1.9357	1.7204	
3			1.8652	2.1616	1.9357	1.7338	
4			1.85	2.1464	1.9167	1.6251	
5			2.0024	2.1573	1.9281	1.6251	
6			2.1414	2.2436	2.0881	1.7547	
7			2.4463	2.316	2.1682	1.9452	
8			2.5911	2.4204	1.8823	2.0767	
9			2.6082	2.4142	2.09	2.0767	
10			2.833	2.1563	2.0919	2.1734	
11			2.5697	2.1186	1.9185	1.9901	
12	1.3146	1.0802	1.326	1.0822	.9145	.8993	.8002
13	2.8044	2.6559					1.7489
14	2.8769	2.7512					1.9128
15	2.8616	2.7855					1.9509
16	2.8655	2.7492					1.6803
17	2.896	2.7664					1.848
18	1.448	2.6692					1.8937
19	2.6444	2.734					.945
20	2.694	2.6864					
21	2.6749	2.6234					.1905
22	2.6749	2.6387					.1905
23	2.6559	2.6559					.762
24	1.3108	1.3565		.9896	.7811	.6687	.8444
Max	2.896	2.7855	2.833	2.4204	2.1682	2.1734	1.9509
Min	1.3108	1.0802	1.326	.9896	.7811	.6687	.1905
Avg	2.3632	2.4733	2.1611	2.0396	1.8132	1.6944	1.2306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 203 / 11 KV PERSODI AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2229	.2987	.2286	.2058	
2			.2401	.2987	.2286	.2058	
3			.2401	.2987	.2286	.2058	
4			.2401	.2987	.2477	.2401	
5			.2401	.2987	.2667	.2401	
6			.3086	.3734	.3429	.2743	
7			.3772	.3734	.3429	.3086	
8			.3772	.3239	.381	.3258	
9			.3944	.3734	.2743	.3429	
10			.4481	.3361	.3086	.3361	
11			.4481	.3429	.3086	.3174	
12	.2286	.3086					.2667
13	.5335	.4458					.3048
14	.5716	.4458					.3048
15	.5906	.4115					.3048
16	.5716	.4115					.3048
17	.5716	.4115					.3239
18	.6097	.4115					.3429
19	.5716	.4115					
20	.5716	.4115					
21	.5335	.4115					.1905
22	.5335	.3944					.1143
23	.5335	.3944					.1143
24				.2987	.2286	.2058	.1524
Max	.6097	.4458	.4481	.3734	.381	.3429	.3429
Min	.2286	.3086	.2229	.2987	.2286	.2058	.1143
Avg	.5351	.4058	.3215	.3263	.2823	.2674	.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 204 / 11 KV BARWA AG FEEDER (FEEDER SEPERATION/PURE AG
CHICHO Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2286					.6535
2	.2427	.2286					.0191
3	.2427	.2286					.0189
4	.2427	.2286					.0187
5	.2241	.2286					.0187
6	.2987	.2286					.0191
7	.2801	.2667					.0187
8	.2987	.3048					.0373
9	.2987	.3048					.0373
10	.3048	.4801					
11	.2096	.4801					
12			.2075	.2286	.1715	.1494	
13			.2452	.2286	.1829	.1494	
14			.2263	.2286	.1715		
15			.2286	.2286	.1715		
16			.2286	.2286	.1715	.1307	
17			.2241	.2286	.1715	.1524	
18			.3018	.2286	.1715	.1509	
19			.2427	.2286	.1715	.1524	
20			.2241	.2096	.1715	.1509	
21			.2241	.2286	.1715	.1509	
22			.2427	.2286	.1543	.1494	
23			.2241	.2286	.1543		
24	.2243	.2286	.1543				
Max	.3048	.4801	.3018	.2286	.1829	.1524	.6535
Min	.2096	.2286	.1543	.2096	.1543	.1307	.0187
Avg	.2592	.2864	.2288	.2270	.1696	.1485	.0935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 205 / 11 KV REST HOUSE Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.3239	.2743	.3206	.3429	.3292	
2	.2801	.3239	.2743	.3206	.3429	.3292	
3	.2801	.3239	.2743	.3018	.3429	.2926	
4	.2427	.3048	.2743	.3018	.3239	.2926	
5	.2241	.2667	.2743	.3018	.3048	.2743	
6	.2054	.2096	.1829	.2054	.2286	.2378	
7	.1867	.1905	.1829	.2054	.2096	.1829	
8	.1698	.1905	.1646	.2075	.1905	.1829	
9	.1867	.1905	.2012	.2263	.1646	.2378	
10	.2096	.1829	.2286	.2286	.2378	.2241	.2096
11	.2286	.1646	.1867	.1905	.2012	.1886	.2286
12	.2286	.2012	.2075	.2286	.2378	.2427	.1905
13	.2477	.2195	.1886	.2286	.2561	.2614	.1905
14	.2477	.2561	.2452	.2667	.2561	.2427	.2667
15	.2667	.2195	.2263	.2286	.2378	.2427	.3048
16	.1905	.1829	.1867	.1905	.2012	.2075	.2096
17	.2286	.1646	.1715	.1715	.1829	.168	.1905
18	.1715	.1463	.1524	.1715	.1646	.1509	.1905
19	.2667	.1829	.2286	.2286	.2195	.2286	
20	.2858	.2743	.3048	.2858	.3109	.2801	
21	.3239	.2926	.3395	.3429	.3109	.3361	.1524
22	.3239	.3109	.3395	.3429	.3292	.3361	.1524
23	.3239	.2926	.3018	.3429	.3109	.3048	.1524
24	.3239	.3239	.2926	.3239	.3429	.3292	
Max	.3239	.3239	.3395	.3429	.3429	.3361	.3048
Min	.1698	.1463	.1524	.1715	.1646	.1509	.1524
Avg	.2470	.2391	.2376	.2568	.2604	.2543	.2032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 206 / 11 KV SONI AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3048					.168
2	.4481	.3048					.168
3	.4481	.3048					.1494
4	.4481	.3429					.1494
5	.4481	.4191					.1494
6	.5601	.5144					.1494
7	.4668	.5716					.0934
8	.6161	.5716					.0747
9	.6348	.5716					.1494
10	.6478	.5144					.1524
11	.5335	.4458					.1143
12			.3361	.381	.3086	.2987	
13			.4108	.381	.3429	.2957	
14			.4668	.4191	.3772	.2987	
15			.4481	.381	.4115	.3174	
16			.3921	.381	.4115	.3734	
17				.5335	.4115	.3734	
18				.5335	.4115	.3734	
19				.4763	.3772	.3429	
20			.3841	.4572	.3601	.3206	
21			.3961	.4572	.3429	.3174	
22			.3961	.4572	.3429	.3239	
23			.3772	.4572	.3429	.1698	
24	.4294	.3048	.2058				
Max	.6478	.5716	.4668	.5335	.4115	.3734	.168
Min	.4294	.3048	.2058	.381	.3086	.1698	.0747
Avg	.5115	.4309	.3813	.4429	.3701	.3171	.1380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 207 / 11 KV Parsodi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1334	.12	.0747	.0953	.128	.132
2	.1132	.1334	.1097	.0747	.0953	.1097	.1307
3	.1132	.1334	.1097	.0747	.0953	.1097	.1307
4	.1132	.1334	.1097	.0747	.0953	.1097	.1307
5	.1143	.1143	.1097	.0747	.0953	.1097	.1307
6	.056	.0572	.0549	.056	.0572	.0732	.1307
7	.0566	.0572	.0549	.0373	.0572	.0366	.0377
8	.0754	.0381	.0366	.0373	.0572	.0549	.0377
9	.056	.0762	.0366	.0762	.0549	.0366	.0566
10	.0572	.0549	.0373	.0572	.0549	.0566	.0762
11	.0381	.0732	.0373	.0572	.0732	.0566	.0762
12	.0381	.0914	.1307	.0762	.0905	.056	.0953
13	.0762	.0914	.132	.0762	.0914	.0747	.0953
14	.0953	.1097	.0754	.0762	.1097	.0747	.0953
15	.1143	.0914	.0754	.0762	.0914	.0754	.0953
16	.0762	.0732	.0566	.0762	.0732	.0572	.0953
17	.0762	.0549		.0381	.0549	.0762	.0762
18	.0381	.0366	.0373	.0762	.0549	.0381	.0953
19	.1143	.0914	.0747	.0953	.0914	.0953	
20	.1334	.128	.1524	.0953	.128	.1143	
21	.1715	.1646	.1494	.1143	.1097	.1132	
22	.1715	.1463	.1307	.1143	.128	.1132	
23	.1524	.128	.1307	.0953	.1463	.1494	
24	.1334	.1334	.128	.1334	.0953	.128	.112
Max	.1715	.1646	.1524	.1334	.1463	.1494	.132
Min	.0381	.0366	.0366	.0373	.0549	.0366	.0377
Avg	.0957	.0977	.0909	.0766	.0873	.0853	.0963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 208 / 11 KV Barwha Gaothan
(CHICHOLI Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4191	.4298	.4527	.4572	.4298	1.5493
2	.3603	.4191	.4115	.2286	.4572	.4298	1.2498
3	.3585	.4191	.3734	.4191	.4572	.3917	1.0212
4	.3585	.4001	.3734	.4172	.4382	.3917	.8688
5	.3585	.381	.3734	.3603	.4001	.3917	.8119
6	.2644	.3048	.3185	.3037	.3239	.3368	.6432
7	.2263	.2096	.2057	.2086	.2286	.2057	.3966
8	.1882	.1715	.1859	.1703	.2286	.2057	.3204
9	.1509	.1715	.2057	.1705	.2423	.1859	.2084
10	.1715	.1676	.1715	.1696	.224	.2086	.1905
11	.1905	.1676	.245	.2096	.2606	.245	.1143
12	.2477	.2423	.245	.2667	.2606	.2637	.1905
13	.2477	.2606	.2858	.3048	.2987	.3204	.2286
14	.3048	.317	.3048	.3048	.3353	.3204	.2667
15	.3048	.2804	.2844	.3048	.3551	.3204	.2477
16	.2858	.224	.2667	.2667	.2621	.1882	.2477
17	.2286	.224	.2263	.2096	.2423	.2096	.2096
18	.1905	.1448	.1905	.1905	.224	.1905	.2477
19	.3048	.2225	.2841	.3048	.2789	.2637	.1143
20	.4191	.41	.4191	.4382	.41	.3222	
21	.4763	.5014	.4527	.4953	.4847	.3772	.1143
22	.4763	.4481	.4713	.4572	.4664	.3772	
23	.4572	.4664	.4572	.4763	.4481	.5087	
24	.4382	.4572	.4344	.4549	.4572	.4481	.8215
Max	.4763	.5014	.4713	.4953	.4847	.5087	1.5493
Min	.1509	.1448	.1715	.1696	.224	.1859	.1143
Avg	.3087	.3096	.3173	.3160	.3434	.3139	.4792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 209 / 11 KV Soni Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9144	.9144	.8962	.8306	.9144	.8962	.2286
2	.9426	.9144	.823	.8306	.9144	.8779	.1143
3	.9426	.9144	.823	.8306	.9144	.8596	.0762
4	.9426	.8954	.823	.8344	.9144	.8596	
5	.868	.8001	.7849	.8306	.9144	.8596	
6	.6432	.7239	.6386	.6287	.6858	.695	
7	.4721	.5525	.3932	.4365	.4763	.4496	
8	.3391	.5334	.341	.3018	.381	.3551	
9	.3959	.4572	.317	.4146	.3734	.3353	.1334
10	.5144	.5776	.4332	.4382	.5395	.4146	.2667
11	.6096	.6721	.6409	.5334	.7453	.49	.3048
12	.6287	.6172	.6976	.7239	.9327	.8283	.4001
13	.6858	.7468	.7544	.8001	1.009	.9808	.6096
14	.762	.7651	.8299	.762	.9587	.9808	.7239
15	.743	.9861	.8112	.7811	.8581	.9062	.8763
16	.6477	.7102	.6984	.6858	.823	.868	.8763
17	.4953	.599	.3429	.6287	.7102	.6832	.8001
18	.4953	.4679	.2667	.5525	.6721	.6635	.762
19	.7239	.4831	.3048	.6477	.82	.8001	.381
20	.8763	.8565	.9808	.9907	1.1554	.9099	
21	1.0289	1.0075	.9816	1.1051	1.2316	.9622	.4191
22	1.0289	1.009	1.0003	1.067	1.1599	.9808	.0762
23	.9526	.9907	.9816	1.0289	1.009	.4954	.0762
24	.9099	.9144	.439	.8726	.9526	.439	.2477
Max	1.0289	1.009	1.0003	1.1051	1.2316	.9808	.8763
Min	.3391	.4572	.2667	.3018	.3734	.3353	.0762
Avg	.7318	.7545	.6668	.7315	.8361	.7329	.4096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 210 / TEMBHERI GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0191	.0183	.0189	.0191	.0183	.0191
2	.0747	.0191	.0183	.0189	.0191	.0183	.0187
3	.0747	.0191	.0183	.0191	.0191	.0183	.0187
4	.0747	.0191	.0183	.0189	.0191	.0183	.0189
5	.0762	.0191	.0183	.0189	.0191	.0183	.0191
6	.056	.0191	.0183	.0189	.0191	.0183	.0187
7	.0187	.0191	.0183	.0189	.0191	.0183	.0189
8		.0191	.0183	.0187	.0191	.0183	.0187
9	.0187	.0191	.0183	.0191	.0183	.0183	.0187
10	.0191	.0183	.0187	.0187	.0183	.0187	.0191
11	.0191	.0366	.0187	.0381	.0549	.0189	.0191
12	.0381	.0914	.1524	.1334	.0549	.0377	.0381
13	.0191	.0732	.1494	.1334	.1097	.0377	.0572
14	.0191	.0732	.0747	.0953	.1463	.0373	.0762
15	.0191	.0732	.0754	.0762	.1097	.0187	.0762
16	.0191	.0549	.0747	.0762	.0914	.0191	.0572
17	.0191	.0549		.0572	.0732	.0191	.0572
18	.0191	.0183	.1143	.0762	.0366	.0191	.0572
19	.0191	.0183		.0191	.0191	.0191	
20	.0191	.0183	.0953	.0191	.0183	.0189	
21	.0191	.0183	.0187	.0191	.0183	.0187	.0191
22	.0191	.0183	.0191	.0191	.0183	.0189	.0191
23	.0191	.0183	.0187	.0191	.0183	.0187	.0191
24	.0572	.0191	.0183	.0191	.0191	.0183	.0191
Max	.0762	.0914	.1524	.1334	.1463	.0377	.0762
Min	.0187	.0183	.0183	.0187	.0183	.0183	.0187
Avg	.0354	.0324	.0461	.0412	.0407	.0210	.0320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 201 / 11 KV VIRLEE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.3696					.8192
2	1.4575	1.3696					.8192
3	1.4575	1.3696					.8192
4	1.4575	1.3696					.8192
5	1.5384	1.4118					.8684
6	1.5893	1.4712					.8192
7	1.6712	1.3321					.6882
8	1.704	1.4266					.7373
9		1.419					.7373
10		1.5844					.7701
11	1.4575	1.5844					.7701
12			1.2597	1.3283	1.1717	1.1984	
13			1.6446	1.6712	1.3748	1.3603	
14			1.6446	1.6604	1.3904	1.3927	
15			1.6762	1.6446	1.4403	1.4091	
16			1.6762	1.6604	1.4563	1.4091	
17			1.7284	1.5971	1.4746	1.4091	
18			1.7444	1.6604	1.4419	1.3763	
19			1.7284	1.5971	1.4737	1.1469	
20			1.7284	1.6549	1.4746	.9831	
21			1.6804	1.6385	1.4737	1.0322	
22			1.6804	1.587	1.4746	.9831	
23			1.6644	1.5893	1.4746	.9175	
24	1.3927	1.2193	1.1203				
Max	1.704	1.5844	1.7444	1.6712	1.4746	1.4091	.8684
Min	1.3927	1.2193	1.1203	1.3283	1.1717	.9175	.6882
Avg	1.5183	1.4106	1.6136	1.6074	1.4268	1.2182	.7879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 202 / 11 KV GOURALA AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0358	2.299	2.2361	2.2161	1.9601	.3292
2			2.3621	2.275	2.2611	1.9852	
3			2.402	2.3403	2.2657	1.9643	
4			2.4005	2.4335	2.2619	1.8488	
5			2.4299	2.532	2.2672	1.9717	
6			2.5318	2.6056	2.5255	2.0629	
7			2.6417	2.8466	2.7108	2.2741	
8			2.5266	2.8629	2.508	2.4379	
9			2.9913	2.8367	2.5339	2.5324	
10			3.1535	2.8098	2.6528	2.4874	
11			3.1066	2.8151	2.6864	2.2931	
12	1.6208	1.5076	1.5165	1.4464	1.3839	1.1195	.775
13	3.4472	3.2057					1.8233
14	3.3475	3.3395					1.8288
15	3.545	3.3588					1.7938
16	3.5449	3.3588					1.8871
17	3.5551	3.2846					1.9795
18	3.4423	3.2796					1.8115
19	3.405	3.2793					.913
20	3.3859	3.2141					.7019
21	3.3745	3.2301					
22	3.3722	3.2346					.0038
23	3.3608	3.1886					
24	1.6857	1.6072		1.1071	1.03	.9374	.5975
Max	3.5551	3.3588	3.1535	2.8629	2.7108	2.5324	1.9795
Min	1.6208	.0358	1.5165	1.1071	1.03	.9374	.0038
Avg	3.1605	2.7946	2.5301	2.3959	2.2541	1.9904	1.2037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 203 / 11 KV Kiramati AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1002	.1475	1.0683	.8412	.8362	.7952	.2462
2			1.0862	.8469	.8325	.8093	
3			1.0824	.8857	.8522	.804	
4			1.1163	.8834	.8484	.8021	
5			1.1316	.8985	.8301	.7994	
6			1.1252	.9019	.8456	.8128	
7			1.1742	.9371	.9058	.8697	
8			1.1248	.9562	.9157	.8244	
9			1.1195	.9569	.8818	.8414	
10			1.1795	.9364	.9023	.8326	
11			1.1502	.9042	.9138	.9058	
12	.5847	.415	.5704	.4752	.4572	.4641	.2286
13	1.3919	.8267	.0888	.0518	.0537	.0591	.8238
14	1.4718	1.1396					.8219
15	1.484	1.2007					.8196
16	1.459	1.2385					.8223
17	1.4794	1.2039					.7624
18	1.4579	1.2296					.7949
19	1.4108	1.2271					.4214
20	1.4289	1.2625					.3277
21	1.4106	1.2702					
22	1.4021	1.2652					
23	1.4013	1.2557					
24	.6965	.6268		.3961	.3961	.378	.3584
Max	1.484	1.2702	1.1795	.9569	.9157	.9058	.8238
Min	.1002	.1475	.0888	.0518	.0537	.0591	.2286
Avg	1.2271	1.0221	1.0013	.7765	.7480	.7141	.5843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 204 / 11 KV Kiramti Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2463	.2463	.2463	.2463	.2463	.2652	.2463
2	.2463	.2463	.2463	.2463	.2463	.2637	.2463
3	.2275	.2463	.2463	.2463	.2463	.245	.2275
4	.2275	.2463	.2275	.2463	.2463	.245	.2263
5	.2275	.245	.2275	.2275	.2463	.2263	.2275
6	.1705	.1703	.2086	.2086	.189	.189	.1897
7	.0941	.0941	.0947	.0947	.1509	.1322	.1328
8	.0758	.0754	.0758	.0758	.0947	.0947	.0947
9	.0381	.0758	.0947	.0947	.0754	.0947	.0947
10		.0947	.0947	.0947	.0947	.0947	.0947
11	.1328	.1135	.1509	.1128	.1516	.1516	.0381
12	.1705	.1516	.1705	.1696	.1705	.1705	.1705
13	.1705	.1705	.1705	.1882	.2275	.2086	.1705
14	.1705	.1705	.1705	.1894	.2275	.2275	.1696
15	.1705	.1516	.1516	.1696	.2086	.1516	.1696
16	.1328	.1328	.1328	.1509	.1516	.1328	.1516
17	.0758	.0947	.0947	.0947	.0941	.0758	.0947
18	.0941	.0947	.0947	.0947	.1128	.0947	.0947
19	.1128	.1324	.1324	.1705	.1315	.1135	.0381
20	.1894	.2463	.2463	.245	.245	.1882	
21	.245	.2463	.2463	.2637	.2637	.2463	.1135
22	.2652	.2652	.2652	.3033	.2637	.2463	.2082
23	.245	.2463	.2463	.2637	.2637	.2652	.2463
24	.2463	.2463	.2463	.2463	.2652	.2637	.2463
Max	.2652	.2652	.2652	.3033	.2652	.2652	.2463
Min	.0381	.0754	.0758	.0758	.0754	.0758	.0381
Avg	.1728	.1751	.1784	.1852	.1922	.1828	.1605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 205 / 11kv virli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9426	.9426	.924	1.0003	1.0563	.9426	1.1123
2	.9426	.9426	.924	1.0003	.9613	.9426	1.0936
3	.924	.9426	.868	.9443	.9613	.9287	1.0936
4	.924	.9426	.3734	.9069	.9613	.924	1.075
5	.8866	.924	.3734	.8696	.9053	.8866	1.0189
6	.6797	.7186	.3174	.7559	.7933	.7559	.5335
7	.3406	.3406	.1494	.4542	.5289	.4168	.2614
8	.3578	.3376	.2241	.4527	.5087	.4138	.4511
9	.1524	.4713	.2614	.49	.5647	.5273	.4527
10		.6035	.3361	.6409	.6782	.6409	.7156
11	.6595	.6969	.4108	.7918	.7918	.6969	.6237
12	.7918	.7731	.4481	.8664	.7918	.8291	.7529
13	.7918	.8493	.4481	.868	.868	.8104	.8104
14	.7918	.7918	.4481	.7918	.868	.868	.8866
15	.7544	.8493	.4108	.7918	.7731	.8306	.7918
16	.7171	.7731	.3734	.7544	.6984	.7357	.7544
17	.6035	.7731	.3547	.7731	.6409	.6984	.7357
18	.49	.7544	.3734	.6797	.6409	.5662	.6051
19	.5647	.7918	.4481	.7156	.7342	.6782	.3048
20	.8291	.924	.4854	.8903	.98	.8276	
21	.9426	.9613	.5601	1.0173	1.0936	1.131	.6409
22	.9426	1.0563	.5601	1.075	1.075	1.1885	.8664
23	.9426	1.0376	.5415	1.0563	1.0376	1.1885	.9426
24	.9426	.9426	.5041	1.0189	.98	1.0376	1.036
Max	.9426	1.0563	.924	1.075	1.0936	1.1885	1.1123
Min	.1524	.3376	.1494	.4527	.5087	.4138	.2614
Avg	.7354	.7975	.4632	.8169	.8289	.8111	.7634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 206 / GAWARADA GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3547	.3547	.3361	.3734	.3742	.3361
2	.3734	.3547	.3547	.3361	.3547	.3734	.3361
3	.3734	.3547	.3547	.3361	.3547	.3547	.3361
4	.3547	.3547	.3361	.3174	.3547	.3547	.3174
5	.3361	.3361	.2987	.2614	.3174	.3547	.2801
6	.2427	.2241	.2241	.2241	.2241	.2241	.2054
7	.168	.168	.1307	.168	.1867	.168	.168
8	.1494	.1494	.1494	.168	.1494		.168
9		.1307	.1494	.1494	.1494		.1867
10		.1867	.168	.1867	.2054		.1867
11	.2427	.2241	.168	.2241	.2427		.2241
12	.2801	.2614	.2054	.2801	.2801	.0934	.2614
13	.2801	.2987	.2427	.2614	.2987	.2801	.2801
14	.2801	.2614	.2427	.3174	.2987	.3547	.2987
15	.2801	.2427	.2614	.2614	.2801	.3174	.2987
16	.2241	.2241	.2054	.2054	.1867	.2427	.2241
17	.2054	.1867	.1867	.2054	.1307	.168	.1867
18	.2054	.168	.168	.1886	.1494	.2054	.1494
19	.2427	.2614	.2614	.2614	.2614	.2427	
20	.3734	.3547	.3174	.3734	.3734	.3174	
21	.3921	.3734	.3734	.3921	.3734	.3734	
22	.3921	.4108	.4108	.3734	.4108	.3361	.056
23	.3734	.3734	.3734	.3734	.3921	.3174	.1494
24	.3734	.3547	.3547	.3547	.3734	.3734	.3547
Max	.3921	.4108	.4108	.3921	.4108	.3742	.3547
Min	.1494	.1307	.1307	.1494	.1307	.0934	.056
Avg	.2962	.2754	.2622	.2731	.2801	.2913	.2383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 201 / 11 KV Barwha Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2972	.2896	.2896	.2787	
2			.2972	.2896	.2896	.2787	
3			.3121	.282	.2751	.2787	
4			.3081	.2679	.2896	.2787	
5			.3227	.2643	.2679	.2787	
6			.3227	.2782	.3384	.3081	
7			.3086	.3227	.1806	.2429	
8			.3353	.3704	.3506	.2858	
9			.4012	.6173		.3374	
10			.4481	.5312		.3374	
11			.4254	.4218		.3269	
12	.216	.2214					.1593
13	.2315	.4586					.2317
14	.3963	.506					
15	.4115	.503					
16	.4268	.503					
17	.4725	.4755					
18	.463	.4607					
19	.4365	.4268					
20	.4161	.3963					
21	.4161	.3963					
22	.4515	.4115		.2054			
23	.4268	.4268					
24				.2606	.2143	.2317	
Max	.4725	.506	.4481	.6173	.3506	.3374	.2317
Min	.216	.2214	.2972	.2054	.1806	.2317	.1593
Avg	.3971	.4322	.3435	.3385	.2773	.2886	.1955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 203 / 11 KV Chikana AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5721	.4401	.1467	.1614	.1448	.1158	
2	.6015	.5287	.1467	.1614	.1429	.1158	.3384
3	.6062	.5716	.1303	.1572	.141	.1158	.3384
4	.6344	.5639	.1303	.1572	.141	.1158	.3429
5	.6222	.578	.1448	.1551	.141	.1143	.3018
6	.6358	.5858	.1429	.1551	.1646	.1286	.2801
7	.6222	.5858	.1467	.1614	.3418	.1128	.2705
8	.6573	.6081	.1646	.1783	.1355	.1355	.2643
9	.6093	.6226	.1593	.1806	.132	.132	.2643
10	.6249	.6171	.1524	.1718	.1467	.1635	.2896
11	.6097	.5944	.1488	.1562	.132	.1486	.2934
12	.1524	.1677	.5639	.4841	.4841	.3814	
13	.1524	.1635	.5944	.5944	.4923	.4666	.0301
14	.1614	.1635	.6171	.5647	.4934	.4607	
15	.1656	.1551	.6241	.5868	.5001	.4199	
16	.1806	.1692	.6161	.543	.5216	.4451	
17	.1692	.1646	.6371	.5639	.5424	.4694	
18	.1692	.1646	.6537	.5487	.487	.4694	
19	.1833	.1551	.6398	.5647	.487	.4515	
20	.1882	.1429	.6161	.4923	.4938		
21	.208	.1429	.6161	.5135	.487		
22	.1635	.1572	.6161	.4778	.4652		
23	.1593	.1572	.6161	.5144	.4778		
24	.5428	.3429	.4715	.1635	.1486	.1174	
Max	.6573	.6226	.6537	.5944	.5424	.4694	.3429
Min	.1524	.1429	.1303	.1551	.132	.1128	.0301
Avg	.3913	.3559	.3957	.3503	.3268	.2540	.2740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 204 / 11KVCHIKANA (GAOTHAN)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3002	.3018	.3002	.3222	.3187	
2	.3002	.3002	.3018	.3002	.3222	.3187	.1524
3	.2818	.3002	.2804	.2987	.3222	.3187	.3002
4	.2423	.2818	.2621	.2804	.3222	.3187	.2606
5	.224	.2633	.2048	.261	.2858	.3002	.2263
6	.2057	.2067	.2048	.2229	.2048	.224	.1696
7	.1478	.1501	.1311	.1486	.1516	.1471	.1501
8	.1097	.1486	.1311	.1486	.1516	.1316	.0947
9	.1478	.1299	.1478	.1494	.1676	.1657	.1105
10	.1501	.1311	.1501	.0886	.1494	.1989	.1676
11	.1882	.1305	.1657	.124	.1859	.2275	.1667
12	.1882	.1676	.241	.1267	.2397	.2463	.2229
13	.2067	.2423	.2591	.1448	.3002	.3033	.2591
14	.2067	.2423	.2972	.1433	.2972	.2987	.1524
15	.1882	.241	.2764	.128	.2987	.3187	.1524
16	.1882	.2229	.2029	.1063	.224	.2831	.1143
17	.1316	.1657	.1478	.0848	.1478	.2019	.0762
18	.1315	.1478	.1448	.0754	.1501	.1638	.0762
19	.1686	.2082	.1962	.132	.2423	.1882	.0762
20	.2831	.3222	.3222	.1698	.341	.1524	
21	.3018	.3222	.3222	.1905	.708	.1524	
22	.3002	.3033	.3204	.1698	.3517	.1524	.0762
23	.2818	.3033	.3018	.1698	.317		.1143
24	.3018	.3187	.1524	.1494	.3222	.1663	.1143
Max	.3018	.3222	.3222	.3002	.708	.3187	.3002
Min	.1097	.1299	.1311	.0754	.1478	.1316	.0762
Avg	.2157	.2313	.2277	.1714	.2719	.2303	.1540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 205 / BARWHA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.8413	.8603	.8823	.9007	.9192	
2	.7811	.8596	.8078	.8072	.9007	.9007	
3	.7449	.7864	.7346	.7666	.9007	.9007	
4	.7056	.7344	.7056	.73	.8626	.8442	
5	.6698	.6778	.6698	.6906	.7811	.8072	
6	.5555	.6016	.5376	.5782	.6525	.6144	
7	.3677	.4319	.3854	.4256	.4277	.4096	
8	.1959	.4031	.3715	.3875	.41	.3959	
9	.4589	.4565	.4389	.4713	.4664	.398	
10	.497	.5174	.5439	.5441	.5201	.4614	.1991
11	.5555	.5913	.4277	.6272	.5974	.6451	.2987
12	.7277	.6653	.5395	.9049	.7249	.7832	.3511
13	.7594	.7392	.7973	.8824	.7834	.9097	.3544
14	.7468	.7611	.7992	.8131	.8257	.8485	
15	.7034	.8516	.7213	.8089	.7702	.7773	
16	.6325	.839	.6474	.7316	.6474	.6965	
17	.5266	.6565	.5296	.6447	.5677	.5972	
18	.541	.5121	.5014	.5506	.4176	.4871	
19	.6523	.6554	.7163	.6559	.6687	.6451	
20	.823	.8859	.924	.9426	1.0313	.4191	
21	1.0129	.9241	1.0129	1.0182	1.051	.4572	
22	.9759	.9574	.9808	1.0376	1.0325	.4572	
23	.9759	.9574	.8835	.9192	.9574		
24	.9344	.8268	.9144	.9007	.9007	.462	
Max	1.0129	.9574	1.0129	1.0376	1.051	.9192	.3544
Min	.1959	.4031	.3715	.3875	.41	.3959	.1991
Avg	.6835	.7139	.6854	.7384	.7416	.6451	.3008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 206 / Murmadi Gaothaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3753	.3753	.3772	.3753	.3938	.3938	
2	.3734	.3753	.3772	.3753	.3753	.3938	.3578
3	.3551	.3568	.3204	.3568	.3753	.3753	.3938
4	.3353	.3368	.3018	.3383	.3753	.3753	.2033
5	.3172	.3002	.2831	.3185	.3568	.3753	.1829
6	.2587	.2804	.2644	.2621	.2791	.3014	.0924
7	.1648	.1686	.1676	.1859	.224	.1501	.0747
8	.1486	.1494	.1509	.1676	.2077	.1667	.0924
9	.1478	.1676	.1509	.1494	.1859	.1676	.0924
10	.1501	.1501	.1696	.0747	.2423	.1871	.0924
11	.1686	.1871	.224	.0941	.2252	.2252	.2241
12	.2252	.2252	.2423	.1509	.3187	.3187	.112
13	.2633	.2067	.2818	.2789	.3187	.3391	.1294
14	.2818	.2252	.3002	.2957	.3187	.3585	
15	.2633	.2252	.2818	.3368	.3187	.1905	
16	.2067	.224	.2252	.2791	.2987	.3002	
17	.1867	.1859	.1494	.2206	.2206	.237	
18	.1848	.2229	.1667	.2206	.2195	.1638	
19	.2437	.2789	.1448	.2841	.2637	.256	
20	.3368	.41	.2263	.3791	.4738	.1905	
21	.3932	.4319	.2075	.4738	.4504	.2286	
22	.3932	.434	.2263	.434	.4319	.1905	
23	.3753	.3772	.1867	.3938	.4319		
24	.3753	.3753	.1848	.3753	.3938	.2033	
Max	.3932	.434	.3772	.4738	.4738	.3938	.3938
Min	.1478	.1494	.1448	.0747	.1859	.1501	.0747
Avg	.2718	.2779	.2338	.2842	.3208	.2647	.1706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 201 / kudegaon

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2954	1.917	.0762				1.2681
2	2.2771	1.917					1.2681
3	2.2771	1.917					1.2681
4	2.2771	1.917					1.2681
5	2.2771	2.0279					1.3047
6	2.4264	2.1757					1.2316
7	2.463	2.3258					1.4175
8	2.5941	2.4575					1.512
9	2.5941	2.402					1.5486
10		2.402					1.5486
11	2.1643	2.439					1.1371
12	1.0669	1.2193	1.4631		1.1278	1.1278	.6097
13			2.2771	2.4264	2.1277	2.0149	
14			2.4081	2.5392	2.1643	2.0911	
15			2.4081	2.5575	2.1643	2.0911	
16			2.4447	2.5392	2.1643	2.0911	
17			1.2437	2.5941	2.1643	1.9966	
18			1.2437	2.5941	2.2771	1.9418	
19			1.2803	2.4447	2.2222	1.9418	
20			1.2803	2.4447	2.2405	2.0149	
21			1.2986	2.4264	2.2405	1.9418	
22			1.2803	2.4264	2.146	1.9235	
23			1.2437	2.4264	2.146	.8139	
24	1.2559	1.1461	.7682	1.2193	1.0669	.381	
Max	2.5941	2.4575	2.4447	2.5941	2.2771	2.0911	1.5486
Min	1.0669	1.1461	.0762	1.2193	1.0669	.381	.6097
Avg	2.1640	2.0203	1.4797	2.3865	2.0194	1.7209	1.2819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 202 / 11 KV PAHUNGAON(AGP)+11 KV FEEDER SEPERATION/PURE AG
BHA Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		1.6065	1.6667	1.5547	1.4605	
2			1.6065	1.6667	1.5547	1.4605	
3			1.6065	1.6084	1.5905	1.4785	
4			1.6065	1.6846	1.6263	1.4785	
5			1.6796	1.7204	1.6621	1.4785	
6			1.7162	1.7741	1.8099	1.6621	
7			1.8656	1.9757	1.9399	1.68	
8			1.9784	2.0698	1.9578	1.7158	
9			2.0728	1.2544	1.9399	1.792	
10			2.1277	1.3843	1.9399	1.8279	
11			2.1094	1.5501	1.9578	1.7741	
12	1.5637	1.329	1.0669	.7621	.9907	.6859	.6135
13	2.5891	2.3899					1.2365
14	2.5891	2.3899					.9228
15	2.5891	2.4081					.9228
16	2.5891	2.3899					.9049
17	2.5891	2.3137					.9228
18	2.5522	1.9875					.9228
19	1.813	1.4937					.4572
20	2.5152	1.3992					
21	1.894	1.5851					
22	1.9702	1.7162					
23	1.9702	1.829					
24	.9907	.9145		.9046	.8688	.6268	
Max	2.5891	2.4081	2.1277	2.0698	1.9578	1.8279	1.2365
Min	.381	.9145	1.0669	.7621	.8688	.6268	.4572
Avg	2.0426	1.8574	1.7536	1.5401	1.6456	1.4709	.8629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 203 / 11 KV KUDEGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9716	.9907	.9526	.9526	.9526	1.067	.8001
2	.9716	.9907	.9526	.9526	.9526	1.067	.8001
3	.9716	.9907	.9526	.9526	.9526	.9907	.8001
4	.9716	.9907	.9526	.9144	.9526	.9526	.8001
5	.8763	.8382	.8382	.9144	.9335	.9144	.762
6	.6668	.762	.6858	.762	1.4098	.7049	.6287
7	.4382	.4953	.4763	.4763	.5715	.5715	.4191
8	.4382	.4953	.4763	.4572	.4953	.4953	.2096
9	.4953	.4763	.5144	.5334	.5144	.4763	.2096
10		.6287	.6668	.6668	.5715	.6668	.2286
11	.6477	.6477	.6287	.8001	.7811	.8001	.3239
12	.381	.7049	.8192	.4572	.8382	.9335	.3429
13	.8001	.762	.9526	.8954	.9526	.9335	.381
14	.8192	.8382	.8954	.8954	.9526	.8954	.362
15	.8001	.8001	.762	.8192	.8954	.7811	.3239
16	.7049	.7239	.6096	.743	.7239	.6096	.2667
17	.6096	.5715	.4763	.6096	.6287	.3048	.2477
18	.6477	.5715	.4953	.5334	.6096	.4191	.2096
19	.8383	.7239	.7239	.7049	.8192	.5715	
20	1.086	.9716	1.1051	1.1051	1.1051	.8764	
21	1.1241	1.1051	1.2003	1.2194	1.2194	.9716	
22	1.1051	1.067	1.067	1.1813	1.1813	.8954	.0762
23	1.067	.9716	1.0479	1.0289	1.067	.743	.0953
24	1.067	.9907	.9526	.9526	.9526	.9335	.4191
Max	1.1241	1.1051	1.2003	1.2194	1.4098	1.067	.8001
Min	.381	.4763	.4763	.4572	.4953	.3048	.0762
Avg	.8043	.7962	.8002	.8137	.8764	.7740	.4146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 201 / 11 KV DHOLSAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3612	.3353	.3269	.3121	.2641	.2107	
2	.3521	.3311	.3227	.3081	.2641	.2107	.0732
3	.3521	.3269	.3227	.3081	.2606	.208	.0754
4	.3475	.3227	.3185	.3041	.2572	.208	.0754
5	.3429	.3185	.3144	.3041	.2572	.208	.0754
6	.3018	.3144	.2462	.257	.2195	.1833	
7	.3155	.2961	.2606		.2286	.1036	
8	.2347	.3001	.2606	.2705	.2115	.1235	.0594
9	.2397	.3001	.2606	.184	.2115	.1551	.0753
10	.2606	.2972	.2641	.2364	.2115	.1593	.0903
11	.2027	.3048	.282	.2572	.2347	.1635	.1054
12	.2408	.3161	.282	.2462	.2526	.1614	
13	.2439	.3121	.3001	.2751	.2286	.1806	.081
14	.2675	.3227	.3001	.2751	.2526	.1783	.112
15	.2675	.3081	.2782	.2572	.2462	.1806	.1107
16	.2526	.3081	.2705	.2503	.2256	.1783	
17	.2462	.3081	.2667	.2435	.1947	.0947	
18	.3041	.2462	.2721	.2498	.1623	.1391	
19	.301	.2961	.3001	.2572	.1882	.1486	
20	.3506	.3041	.3121	.2824	.2134	.1677	
21	.3506	.3269	.301	.2709	.216	.1718	.108
22	.3549	.3121	.3121	.2538	.2134		
23	.3549	.3269	.3161	.2675	.216		.0514
24	.3612	.3353	.3227	.3121	.2641	.2134	
Max	.3612	.3353	.3269	.3121	.2641	.2134	.112
Min	.2027	.2462	.2462	.184	.1623	.0947	.0514
Avg	.3003	.3113	.2922	.2688	.2289	.1704	.0841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 202 / 11 KV MASAL FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632	1.5684	1.3676	1.4415	1.2323	1.1883	
2	1.6461	1.531	1.3676	1.4377	1.2136	1.1883	.7922
3	1.6078	1.4969	1.3676	1.419	1.1949	1.1883	.7545
4	1.5912	1.4784	1.2752	1.3676	1.1949	1.1016	.7545
5	1.4998	1.3169	1.2437	1.3306	1.0829	1.1016	.7545
6	1.3032	1.1706	.9335	1.0425	.924	.8215	.4904
7	1.3073	1.1706	1.0534		.9522	.5658	.4477
8	1.3394	1.2254	1.1273	.9425	.8775	.7733	.5028
9	1.2567	1.3121	1.1643	.924	.5228		.5014
10	1.0642	1.3676	1.2197	1.0719	.5415		.4681
11	1.2696	1.4045	1.262	1.1643	.6099		.6161
12	.7545	1.4415	1.3352	1.2696	.9808	.9335	.6722
13	1.3256	1.3937	1.4045	1.2197	1.094	1.0185	.6908
14	1.386	1.3169	1.3676	1.1203	1.0829	1.0185	.6468
15	1.4003	1.2803	1.3169	1.1389	1.0751	.9997	.6283
16	1.3306	1.262	1.2437	1.0534	.6602	.9242	.6348
17	1.2437	1.2851	1.1584	1.1157	.679		.5601
18	1.262	1.0924	1.1694	1.0059	.7356	.7545	.6036
19	1.3676	1.1706	1.2752	1.0829	.9619	.8299	
20	1.5123	1.2752	1.4003	1.2136	1.1694	.9619	
21	1.587	1.3306	1.46	1.251	1.226	1.0098	.5788
22	1.6244	1.4045	1.531	1.2696	1.2071		
23	1.5893	1.386	1.4937	1.2323	1.1883		.4858
24	1.6817	1.5708	1.386	1.46	1.2323	1.1694	
Max	1.6817	1.5708	1.531	1.46	1.2323	1.1883	.7922
Min	.7545	1.0924	.9335	.924	.5228	.5658	.4477
Avg	1.4006	1.3438	1.2885	1.1989	.9850	.9749	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 203 / 11 KV BELATHI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1252	.1448	.1429	.1174	
2			.1217	.141	.1429	.1174	
3			.1235	.141	.1429	.1158	
4			.1217	.1509	.1269	.1158	
5			.1183	.1509	.141	.1303	
6			.1286	.1509	.1429	.1448	
7			.1448		.1467	.1391	
8			.1448	.1509	.1448	.1572	
9			.1467	.1509	.1614	.1429	
10			.1467	.1692	.1486	.1593	
11			.0846	.141	.1505	.1429	
12	.1656	.1448					.1337
13	.2006	.1715					.1355
14	.1635	.1715					.1355
15	.1806	.0564					.1372
16	.1783	.0572					.132
17	.1907	.1429					.132
18	.1738	.1467					.1303
19	.1738	.1509					
20	.176	.1572					
21	.176	.1593					
22	.1783	.1593					
23	.1783	.1551					
24				.1448	.1429	.1174	
Max	.2006	.1715	.1467	.1692	.1614	.1593	.1372
Min	.1635	.0564	.0846	.141	.1269	.1158	.1303
Avg	.1780	.1394	.1279	.1488	.1445	.1334	.1337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 204 / 11 KV Tai Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2587	.2561	.2587	.2427	.2402	
2	.2378	.2587	.2587	.2402	.2427	.2402	.2033
3	.2378	.2587	.2587	.2402	.2427	.2402	.112
4	.2378	.2402	.2402	.2241	.2402	.2218	.1132
5	.2378	.1829	.2241	.2241	.1829	.2218	
6	.1417	.1433	.1267	.1307	.1448	.1448	.056
7	.1463	.1433	.1254		.1227	.104	.0373
8	.1387	.1417	.1402	.1402	.124	.1341	.0905
9	.1402	.1402	.1063	.1029	.1417	.124	.1494
10	.1612	.1612	.124	.1063	.1791	.1267	.1307
11	.181	.1629	.1595	.1578	.2172	.1612	.1433
12	.2012	.2149	.2149	.124	.2452	.2172	.181
13	.2195	.2715	.2507	.128	.2926	.2378	.2507
14	.181	.2686	.2353	.2926	.2926	.2378	.2195
15	.2149	.1991	.2328	.2218	.2075	.2033	.2353
16	.1949	.1612	.1052	.1463	.1578	.1478	.181
17	.1267	.1097		.1696	.1543	.1254	.1267
18	.1341	.144		.1638	.1174	.168	.1214
19	.2054	.2218	.2353	.2561	.2241	.2241	
20	.2641	.2801	.3174	.2987	.3174	.3018	
21	.3018	.2987	.3018	.2987	.2987	.3018	.1227
22	.2801	.2772	.2801	.2801	.2587		
23	.2801	.2561	.2587	.2614	.2402		.1886
24	.2587	.2587	.2561	.2587	.2427	.2402	
Max	.3018	.2987	.3174	.2987	.3174	.3018	.2507
Min	.1267	.1097	.1052	.1029	.1174	.104	.0373
Avg	.2076	.2106	.2140	.2054	.2137	.1984	.1479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
StationFeeder No / Name : 402 / 33 KV Parsodi Feeder
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1724	4.1724	4.0581	3.9438	3.8295	3.658	3.4294
2	4.1724	4.1724	4.0581	3.9438	3.7723	3.6008	3.4294
3	4.2295	4.1152	4.0581	3.8866	3.7723	3.4294	3.4294
4	4.1152	4.1724	4.0009	3.9438	3.7723	1.6004	2.8578
5	4.0581	4.0581	4.0009	3.8866	3.7723	3.315	2.8006
6	3.8295	3.7723	3.6008	3.3722	3.5437	3.1436	1.8861
7	3.658	3.4865	1.2003	3.4865	3.658	3.0293	1.7718
8	3.8295	3.7151	3.5437	3.7723	3.2007	3.0293	2.0005
9	1.086	3.8295	3.8295	3.2007	3.4865	3.0864	2.1719
10		3.8866	4.2867	3.4294	3.658	3.1367	2.1719
11	5.7728	4.1152	4.0581	3.7723	3.8866	3.2487	2.2862
12	4.401	4.1724	3.7151	3.7723	3.4865	3.2007	2.4577
13	5.144	4.5725	4.3439	4.3439	2.4577	3.7529	3.1436
14	5.0869	4.6868	4.0581	4.1724	4.1152	3.9438	2.6863
15	5.0297	4.6296	3.9438	4.1152	4.0009	3.7723	2.8006
16	4.7439	4.3439	3.8866	3.8295	3.658	3.4294	2.6292
17	4.6868	4.2295	3.658	3.7723	3.7151	3.0864	2.6292
18	4.5725	2.8578	3.7151	3.7151	3.5437	3.2579	2.6292
19	4.8583	3.9438	4.0009	4.2295	4.0009	2.8006	
20	4.7439	4.2867	4.401	4.6296	4.2867	3.4294	
21	4.8583	4.5725	4.4582	4.6868	4.401	3.4865	.4572
22	4.8583	4.6296	4.401	4.5153	4.3439	3.5437	.6287
23	4.8583	4.6296	4.3439	4.3439	4.1724	2.0576	.9717
24	4.1724	3.7151	4.6296	3.8866	3.4865	3.4865	2.0576
Max	5.7728	4.6868	4.6296	4.6868	4.401	3.9438	3.4294
Min	1.086	2.8578	1.2003	3.2007	2.4577	1.6004	.4572
Avg	4.3886	4.1152	3.9271	3.9438	3.7509	3.2302	2.333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
StationFeeder No / Name : 403 / 33 KV Lakhandur Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Incomer Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5149	2.4006	2.915	3.2007	2.9721	2.9721	2.4577
2	2.4006	2.4006	2.915	3.2007	2.9721	2.915	1.8861
3	2.4577	2.2862	2.915	3.1436	2.9721	2.915	1.7147
4	2.4006	2.2862	2.8578	3.1436	2.9721	2.8006	1.6575
5	2.2862	2.2291	2.7435	3.0293	2.8578	2.6863	1.6004
6	1.6575	1.6004	2.1148	2.2862	2.2291	2.0576	.9717
7	1.6575	1.7147	2.3434	2.2291	2.1719	2.1148	.8002
8	2.1148	1.2003	2.7435	2.6292	2.4577	2.572	.8573
9	2.1148	1.9433	2.8006	2.6863	2.4577	2.5206	1.1431
10	2.1719	2.0576	2.8578	2.5149	2.8006	2.6292	1.2003
11		2.1148	3.1436	2.8006	2.8006	2.4577	1.2003
12	2.9721	2.8578	2.1719	2.2291	2.2291	2.0005	1.8861
13	3.4294	3.4865	2.3434	1.5432	2.5149	2.0725	2.4006
14	3.4865	3.4865	2.4006	1.4861	2.4577	2.0005	2.6863
15	3.4865	3.4294	2.3434	2.2291	2.4006	1.7718	2.6292
16	3.315	2.8578	2.1148	1.5432	2.1148	1.9433	2.6292
17	3.0864	3.0864	2.0005	2.0005	2.1148	1.7147	2.572
18	3.1436	2.8578	2.1148	2.0005	2.0005	1.829	2.2291
19	3.2579	3.2579	2.2291	2.2291	2.2291	1.9433	
20	3.6008	3.5437	2.5149	2.572	2.5149	2.1148	
21	3.8295	3.6008	2.572	2.3434	2.6292	2.3434	.6859
22	3.658	3.6008	2.6292	2.6292	2.6292	2.3434	.8002
23	3.658	3.658	2.572	2.5149	2.4006	1.7147	1.2574
24	2.5149	2.4006	3.5437	3.2007	2.8006	2.915	2.1148
Max	3.8295	3.658	3.5437	3.2007	2.9721	2.9721	2.6863
Min	1.6575	1.2003	2.0005	1.4861	2.0005	1.7147	.6859
Avg	2.8354	2.6816	2.5792	2.4744	2.5292	2.3062	1.6991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
StationFeeder No / Name : 404 / 33 KV BARWA FEEDER-- 02 NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289		1.2574	1.2574	1.2574	
2	1.4289		1.2574	1.2574	1.2003	
3	1.4289		1.2574	1.2574	1.2003	
4	1.3717		1.2003	1.2574	1.2003	
5	1.3146		1.2003	1.2574	1.1431	
6	1.2003		1.0288	1.086	.9717	
7	1.2003		.9145	.9717	.743	
8	1.086	.8573	.9717	.9145	.8573	
9		1.0288	1.0288	.5144	.743	
10		1.1431	1.086	.6287	1.0288	
11		1.1431	1.086	.6859	1.086	
12		1.2003	1.2003	1.1431	1.2003	
13		1.3146	1.4861	1.3146	1.2003	1.0288
14		1.3146	1.4861	1.4289	1.2574	1.0288
15		1.3146	1.4289	1.3146	1.2003	1.0288
16		1.2574	1.3717	1.2003	1.1431	.8573
17		1.1431	1.3146	1.2003	.8573	.8002
18		1.2003	1.2574	1.1431	.9717	.8573
19		1.3717	1.2574	1.3146	1.086	
20		1.1431	1.4289	1.5432	1.2574	
21		1.4861	1.4861	1.5432	1.2003	
22		1.5432	1.4289	1.4289	1.2003	
23		1.4289	1.3146	1.3717		
24	1.3717		1.4289	1.2003	1.2574	
Max	1.4289	1.5432	1.4861	1.5432	1.2574	1.0288
Min	1.086	.8573	.9145	.5144	.743	.8002
Avg	1.3146	1.2431	1.2574	1.1765	1.0984	.9335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / PALANDUR SUB STATION

Feeder No / Name : 201 / 11 KV Palandur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	.9882	.9979	.8501	.7975	.7796	.8063
2	1.0056	.9709	.9795	.8316	.7628	.7442	.7186
3	.9602	.9362	.9425	.8131	.7455	.7087	.6661
4	.9259	.8842	.9055	.7392	.7282	.7087	.5959
5	.9088	.8842	.9055	.7023	.6762	.5959	.5083
6	.9088	.8495	.8686	.6653	.6415	.5959	.4733
7	.9088	.7975	.8501	.6468	.5895	.631	.4207
8	.9088	.8322	.8871	.6283	.6241	.6135	.4207
9	.9431	.8495	.9055	.6283	.6068	.6135	.4031
10	.9088	.8322	.9979	.6653	.6068	.6836	.4031
11	.9431	.8495	.9979	.7392	.6588	.7011	.5083
12	.3258	.3696	.4031	.3881	.3353	.333	.2858
13	.3601	.4251	.4031	.3988	.3018	.3506	.381
14	.3772	.4251	.4207	.4161	.3353	.3681	.415
15	.3772	.4066	.4031	.3814	.285	.3506	.3961
16	.3086	.3326	.3155	.3467	.2515	.333	.3395
17	.2743	.2957	.2629	.2947	.2515	.2279	.3048
18	.2058	.2587	.333	.2601	.2347	.2454	.2477
19	.3641	.3696	.3155	.3121	.333	.3155	
20	.4334	.462	.4031	.3988	.4557	.4031	
21	.4681	.4805	.4382	.4508	.4733	.4557	.3224
22	.4681	.499	.4382	.4681	.4733		.3761
23	.4681	.499	.4557	.4334	.4382		.3761
24	1.0576	1.0056	1.0349	.8501	.8149	.7973	
Max	1.0576	1.0056	1.0349	.8501	.8149	.7973	.8063
Min	.2058	.2587	.2629	.2601	.2347	.2279	.2477
Avg	.6604	.6460	.6610	.5545	.5176	.5253	.4461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / PALANDUR SUB STATION

Feeder No / Name : 202 / 11 KV Maregaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1844	.1677	.2012	.2347	.218	.218
2	.1509	.1844	.1677	.218	.218	.2012	.1174
3	.1509	.1677	.1509	.218	.2012	.2012	.1006
4	.1341	.1341	.1174	.1677	.1844	.1844	.0838
5	.1341	.1174	.1174	.1509	.1509	.1844	.0671
6	.1006	.1006	.1006	.1174	.1341	.1174	.0503
7	.0838	.0838	.0838	.1006	.1174	.0838	.1006
8	.0838	.0838	.0838	.1006	.1006	.1006	.0838
9	.0838	.0838	.1006	.1341	.1174	.1006	.1006
10	.1174	.1006	.1006	.1341	.1341	.1174	.1006
11	.1341	.1341	.1341	.1509	.1677	.1677	.1174
12	.6371	.6203	.3856	.6874	.6203	.6706	.503
13	.6874	.6371	.5868	.7712	.6706	.6874	.6036
14	.7209	.6371	.6036	.788	.788	.7042	.6371
15	.7377	.6371	.6036	.788	.7545	.7209	.6036
16	.6706	.6371	.5868	.7712	.6874	.7209	.5868
17	.7209	.6371	.5868	.7545	.6874	.6371	.5533
18	.6371	.6203	.3688	.7712	.6539	.6203	.5533
19	.6371	.6371	.7042	.7545	.7042	.6539	
20	.6874	.6539	.7377	.8048	.7545	.7209	
21	.6539	.6539	.7545	.8215	.7712	.6036	
22	.6539	.6539	.7712	.788	.7545		.3185
23	.6874	.6371	.7377	.788	.7377		.3353
24	.2012	.2012	.1844	.2012	.2347	.218	
Max	.7377	.6539	.7712	.8215	.788	.7209	.6371
Min	.0838	.0838	.0838	.1006	.1006	.0838	.0503
Avg	.4031	.3849	.3723	.4660	.4408	.3925	.2917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / PALANDUR SUB STATION

Feeder No / Name : 203 / 11 KV Gondegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3395	.3395	.3547	.3547	.3921	.3921
2	.2987	.3206	.2829	.3395	.3361	.3921	.3547
3	.3018	.2829	.2641	.3395	.3174	.3772	.3174
4	.2829	.2263	.2075	.2829	.2801	.3584	.2801
5	.2452	.2075	.1886	.2641	.2427	.3584	.2054
6	.1867	.1698	.1698	.1886	.2054	.2075	.1867
7	.112	.132	.132	.1509	.1494	.1698	.1307
8	.1307	.132	.1509	.1494	.1494	.1509	.112
9	.1307	.132	.1509	.168	.1494	.1509	.1307
10	.1867	.2075	.1886	.1867	.1867	.1886	.168
11	.2241	.2263	.2263	.2427	.2241	.2263	.2054
12	1.0814	1.1768	1.153	.9667	.9665	.9774	.8383
13	1.0978	1.2597	1.1934	1.0486	1.0174	.9945	.8718
14	1.1142	1.2431	1.21	1.065	1.0852	1.0117	.9221
15	1.1142	1.2431	1.1603	1.0486	1.0174	1.0288	.8718
16	.7537	1.21	1.0774	1.0322	.9282	1.0288	.8048
17	1.1305	1.1437	1.1105	.9995	.8802	.9088	.7712
18	1.0159	1.1768	1.085	.9831	.9503	.9259	.7712
19	1.2407	1.2266	1.1498	1.065	1.0486	.9774	
20	1.358	1.3056	1.2289	1.1305	1.1633	1.0974	
21	1.3916	1.3395	1.2289	1.1469	1.1934	1.1145	
22	1.1568	1.3226	1.2548	1.0978	1.1768		.4527
23	1.3245	1.3056	1.2378	1.065	1.1437		.6203
24	.3547	.3584	.3584	.3547	.3734	.3921	
Max	1.3916	1.3395	1.2548	1.1469	1.1934	1.1145	.9221
Min	.112	.132	.132	.1494	.1494	.1509	.112
Avg	.6896	.7370	.6979	.6529	.6475	.6104	.4704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / PALANDUR SUB STATION

Feeder No / Name : 205 / 11 KV MURMADI GAOTHON

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1283	1.1462	1.1462	1.1641	1.1104	1.1283	
2	1.0924	1.0924	1.1104	1.1283		1.0745	
3	1.0029	1.0387	1.0924	1.1104	.6805	.9313	
4	.9313	1.0029	1.0566	1.0208	.7701	.6984	
5	.8775	.8596	.9313	.8059	.6268		
6	.7701	.6268	.7164	.6984	.5731	.6984	
7	.7164	.5373	.6805	.6089	.4477	.6626	
8	.6805	.6089	.7522	.6805	.1791	.6805	.2686
9		.6268	.6984	.6984	.2149	.6984	.2149
10	.394	.8596	.8238	.8059	.9492	.7522	.2507
11	.8059	.8775	.8775	.8775	1.0387	.8775	.3224
12	1.0745	1.0745	1.0387	1.0387	1.0745	1.0208	.2507
13	.7701	1.1283	1.1104	1.0924	1.0924	1.0387	.4477
14	.7343	1.0924	1.1104	1.1283	1.1283	1.0029	.4298
15	.394	1.0387	1.0745	1.0924	1.0387	.9671	.4119
16	.3224	.9134	.8775	1.0387	.9313	.9313	.3403
17	.8775	.8238	.7701	.8596	.8417	.6805	.2865
18	.8417	.7701	.7522	.6984	.7701	.6805	.3045
19	1.182	1.0566	1.0566	.9671	.985	.9313	
20	1.2536	1.3073	1.2536	1.1999	1.2715	1.1462	
21	1.3073	1.3611	1.2894	1.2894	1.3432	1.182	
22	1.3073	1.2894	1.2715	1.2178	1.2536		
23	1.2178	1.2178	1.1999	1.1641	1.182		
24	1.1999	1.182	1.182	1.1641	1.1283	1.1462	
Max	1.3073	1.3611	1.2894	1.2894	1.3432	1.182	.4477
Min	.3224	.5373	.6805	.6089	.1791	.6626	.2149
Avg	.9079	.9805	.9947	.9813	.8970	.9014	.3207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / PALANDUR SUB STATION

Feeder No / Name : 403 / 33 KV PALANDUR

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.6578	2.4691	2.4983	2.4983	2.4983	1.4352
2	2.4691	2.5514	2.3663	2.4451	1.3289	2.3388	1.1694
3	2.3148	2.4451	2.3148	2.392	1.9667	2.1794	1.0631
4	2.2119	2.2325	2.1605	2.1262	1.9667	1.9136	.9568
5	2.1091	2.073	2.0062	1.8604	1.701	1.2226	.7973
6	1.9033	1.7541	1.749	1.5947	1.5415	1.5947	.691
7	1.749	1.5415	1.6461	1.4352	1.3289	1.5415	.6379
8	1.749	1.6478	1.749	1.4883	1.0631	1.5415	.9036
9	1.1694	1.701	1.6975	1.5947	1.1163	1.5415	.8505
10	1.5947	2.0199	2.0199	1.7541	1.8604	1.701	.9036
11		2.073	2.1794	1.9667	2.073	1.9667	1.0802
12	3.2425	3.1379	3.1361	3.1893	3.0298	3.083	1.749
13	3.0298	3.1893	3.3488	3.4551	3.1361	3.1361	2.2634
14	3.083	3.0864	3.3488	3.5082	3.3488	3.1361	2.3148
15	2.7641	3.035	3.2956	3.4551	2.9235	3.1361	2.2119
16	2.1794	2.7778	2.9767	3.2956	2.7109	3.0298	2.0062
17	3.1361	2.4691	2.7641	3.0298	2.4983	2.4983	1.8519
18	2.8172	2.4177	2.4983	2.8172	2.392	2.5514	1.8519
19	3.5082	2.9835	3.1361	3.2425	2.8704	2.9235	
20	3.8272	3.3951	3.6677	3.6677	3.5614	3.4551	
21	3.9335	3.4979	3.774	3.8272	3.6677	3.4019	.3086
22	3.6677	3.3951	3.774	3.7209	3.5082		1.0802
23	3.8272	3.2922	3.6677	3.5614	3.3488		1.2346
24	2.7263	2.7641	2.572	2.4983	2.5514	2.4983	
Max	3.9335	3.4979	3.774	3.8272	3.6677	3.4551	2.3148
Min	1.1694	1.5415	1.6461	1.4352	1.0631	1.2226	.3086
Avg	2.6776	2.5891	2.6799	2.6843	2.4163	2.4041	1.3029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 201 / 11 KV SINDHIPAR AGP FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2735	.2962	.2905	.2806	
2			.2795	.3017	.2928	.2791	
3			.2868	.3003	.2801	.2777	
4			.2817	.3084	.2712	.2614	
5			.2684	.2922	.2759	.2667	
6			.2782	.3278	.3183	.2615	
7			.2893	.3192	.3171	.2684	
8			.2947	.3257	.3179	.2485	
9				.3341	.3251	.2614	
10				.3244	.3116	.2689	
11				.3506	.2707	.2801	
12	.2948	.3003					.2288
13	.2957	.3091					.2362
14	.298	.3032					.2348
15	.2881	.3081					.2243
16	.2721	.3125					
17	.2862	.3059					.2259
18	.2975	.3329					.234
19	.2961	.3084					
20	.2886	.2928					
21	.282	.2905					
22	.2749	.2957					
23	.2758	.2749					
24				.318	.2919	.2972	.2497
Max	.298	.3329	.2947	.3506	.3251	.2972	.2497
Min	.2721	.2749	.2684	.2922	.2707	.2485	.2243
Avg	.2875	.3029	.2815	.3166	.2969	.2710	.2334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 202 / 11 KV RENGEPAR FEEDER AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9032	.8041					
2	.8593	.8005					
3	.8579	.7969					
4	.7737	.7964					
5	.7307	.8109					
6	.7123	.8417					
7	.9538	.8923					
8	.9116	.7403					.1276
9	.9922	.9116					.1252
10	.9737	.9044					.2743
11	1.0023	.7271					.3005
12			.981	.9986	.8962	.8187	
13			.9991	1.0009	.7429	.8224	
14			.9719	.9725	.7334	.8168	
15			.9785	.981	.7481	.8176	
16			.9832	.951	.9086	.838	
17			.9674	.9586	.9313	.733	
18			.9395	.9462	.7271	.788	
19			.9588	.8157	.8525	.7444	
20			.9391	.627	.8253	.5633	
21			.9492	.6397	.8253	.6487	
22			.9062	.7743	.7934	.6376	
23			.905	.7725	.7909	.6394	
24	.9328	.8326	.7353				
Max	1.0023	.9116	.9991	1.0009	.9313	.838	.3005
Min	.7123	.7271	.7353	.627	.7271	.5633	.1252
Avg	.8836	.8216	.9396	.8698	.8146	.7390	.2069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 203 / 11 kv lakhori AG feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.739	.7429	.7469	.5229	
2			.749	.7487	.7206	.5287	
3			.7507	.7448	.7077	.5259	
4			.7472	.7485	.7189	.5146	
5			.749	.754	.717	.5341	
6			.7351	.754	.7167	.5258	
7			.7842	.8131	.7461	.7164	
8			.7655	.7503	1.1088	.5311	
9				.7362	.8141	.5441	
10				.573	.7901	.5887	
11				.8066	.7559	.7767	
12	.7938	.7255					.7318
13	.8887	.6836					.5563
14	.8203	.6955					.4154
15	.8221	.669					.3973
16	.6924	.6807					.6941
17	.7042	.6859					.7016
18	.8162	.5639					.679
19	.6429	.643					
20	.7682	.6203					
21	.7836	.6344					
22	.763	.64					
23	.7799	.6287					
24				.7468	.8299	.5231	.8299
Max	.8887	.7255	.7842	.8131	1.1088	.7767	.8299
Min	.6429	.5639	.7351	.573	.7077	.5146	.3973
Avg	.7729	.6559	.7525	.7432	.7811	.5693	.6257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 204 / 11 KV LAKHORI GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1275	.1226	.1023	.1134	.1195	.1249	
2	.1213	.1195	.1029	.1146	.1152	.12	.1092
3	.1152	.112	.1023	.1127	.1092	.1164	.1068
4	.1171	.1102	.1017	.1072	.1068	.114	.0786
5	.1176	.1019	.0999	.1016	.1083	.1104	.0717
6	.0878	.0717	.0645	.0615	.0721	.0778	.0509
7	.0567	.0698	.0627	.0739	.0597	.0645	.053
8	.0617	.0609	.0667	.0676	.0663	.0663	.0526
9	.064	.0633		.0589	.0251	.0597	.0476
10	.0768	.0652		.0695	.0269	.0627	.0602
11	.0721	.0652		.0806	.0358	.0732	.0615
12	.0813		.1063	.0923	.1113	.0959	.0721
13	.0943		.112	.1014	.1169	.1032	.0832
14	.1019	.109	.1128	.0969	.1122	.1068	.0941
15	.0924	.1053	.1099	.1097	.1086	.1094	.0988
16	.0849	.0878	.0878	.0762	.0806	.0806	.0841
17	.0695	.0824	.0823	.0567	.0734	.0492	.0677
18	.0744	.0624	.0923	.0719	.0638	.0658	.0647
19	.1109	.1146	.1232	.0971	.1122	.0869	
20	.1547	.1288	.1606	.1301	.1515	.1415	
21	.1471	.1251	.1438	.1294	.1515	.1755	
22	.1433	.127	.1312	.1326	.1427	.1238	
23	.1245	.1244	.1189	.1195	.1299	.1225	.0476
24	.1363	.1245	.1152	.1152	.1158	.1244	.114
Max	.1547	.1288	.1606	.1326	.1515	.1755	.114
Min	.0567	.0609	.0627	.0567	.0251	.0492	.0476
Avg	.1014	.0979	.1047	.0954	.0965	.0990	.0747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 205 / 11 KV RENGEPAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3558	.3492	.3365	.3439	.3457	.3421	
2	.4075	.3258	.3225	.3421	.3349	.3385	.3065
3	.3415	.3167	.3172	.3366	.3101	.3243	.298
4	.3418	.295	.3155	.3294	.3041	.3067	.2924
5	.3259	.2758	.3172	.3113	.2717	.291	.2167
6	.2226	.2046	.2191	.2384	.2349	.2156	.1886
7	.2209	.1938	.1875	.1848	.2173	.1994	.156
8		.1851	.1858	.1746	.2244	.1611	.1595
9		.1827		.1818	.2068	.1595	.1662
10		.1995		.1869	.2237	.17	.1613
11		.1899		.2279	.2323	.1898	.1878
12	.1244	.2704	.2794	.2507	.2506	.3819	.1943
13	.3243	.2848	.3295	.3062	.324	.3278	.2901
14	.3295	.2955	.3116	.2977	.2955	.3045	.2945
15	.3083	.2794	.3113	.2941	.2675	.2704	.2798
16	.2489	.2303	.2549	.2358	.2016	.2068	.2299
17	.2296	.1989	.2459	.2163	.1984	.1557	.179
18	.2349	.2146	.1884	.2349	.1884	.2072	.2321
19	.2924	.2865	.351	.2769	.283	.2579	
20	.3526	.377	.3585	.3681	.3786	.3457	
21	.3862	.3921	.3823	.3751	.406	.3713	.2551
22	.3909	.381	.3747	.3698	.3747	.371	.2693
23	.3656	.3602	.3493	.3418	.3547	.3725	.2587
24	.3593	.3492	.3529	.3475	.3313	.3421	.3564
Max	.4075	.3921	.3823	.3751	.406	.3819	.3564
Min	.1244	.1827	.1858	.1746	.1884	.1557	.156
Avg	.3081	.2766	.2996	.2822	.2817	.2755	.2368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 202 / 11 KV MANEGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6183	.6189	.6104	.5799	.6016	.605	.5161
2	.6359	.6053	.6019	.568	.5808	.5967	.5144
3	.6376	.6036	.5867	.5629	.5562	.5951	.4929
4	.6359	.5864	.5511	.5596	.5315	.5884	.4686
5	.5714	.5332	.5155	.5545	.5264	.5387	.3932
6	.5046	.4996	.4833	.4917	.4702	.3945	.3336
7	.4745	.4801	.4748	.4801	.4539	.3763	.332
8	.4963	.485	.49	.4458	.4522	.3945	.321
9	.5751	.4817		.1372	.4475	.426	.3352
10	.5505	.4965		.1372	.5117	.4525	.3318
11	.5669	.5935		.1674	.5304	.4793	.3949
12	.5878	.5684	.5528	.1774	.5636	.5231	.4227
13	.5992	.5985	.5307	.6431	.5967	.57	.4883
14	.612	.5784	.624	.5768	.5967	.5636	.4985
15	.5788	.5617	.5901	.5801	.6133	.5136	.4748
16	.5619	.5298	.5646	.5453	.5636	.4649	.4409
17	.5117	.5566	.4476	.1587	.5768	.3917	.4239
18	.5702	.5415	.5087	.1619	.5437	.4475	.4748
19	.5964	.5344	.6138	.5506	.5834	.4518	
20	.6193	.6203	.6664	.6275	.6381	.5243	
21	.6606	.6206	.6316	.6464	.663	.5432	.2374
22		.6325	.6274	.6216	.6464	.5613	.2374
23	.6223	.6257	.6274	.6223	.6282	.5646	.4239
24	.6199	.624	.6206	.6138	.6001	.6133	.511
Max	.6606	.6325	.6664	.6464	.663	.6133	.5161
Min	.4745	.4801	.4476	.1372	.4475	.3763	.2374
Avg	.5829	.5657	.5676	.4671	.5615	.5075	.4122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 203 / 11 KV PATACHI TOLI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2733	.3035	.3332	.3309	.3103	.2751	.2999
2	.2699	.3035	.3232	.3189	.3103	.2652	.2898
3	.2683	.3052	.3083	.3138	.3086	.2635	.2747
4	.2649	.3035	.2702	.3121	.3001	.2569	.2713
5	.2666	.2916	.2635	.3121	.3018	.2486	.2458
6	.2381	.256	.2486	.2709	.247	.242	.2202
7	.2481	.2635	.2403	.2743	.2586	.2188	.2056
8	.2582	.2519	.2718	.2229	.2188	.2155	.1803
9	.2884	.2445		.2572	.2429	.2171	.1879
10	.2783	.2413		.2622	.2486	.2536	.1824
11	.275	.2526		.2818	.2764	.2356	.1792
12	.2984	.2947	.3017	.3116	.3017	.2704	.1943
13	.3135	.3061	.3017	.3116	.2984	.2767	.2543
14	.3353	.2996	.2934	.3083	.2984	.2815	.2764
15	.3202	.298	.2901	.2934	.2818	.2751	.2713
16	.2917	.2866	.305	.2619	.2652	.2498	.2713
17	.3031	.2769	.2735	.2783	.2437	.2348	.2241
18	.3129	.305	.245	.2973	.2553	.2526	.2187
19	.3332	.3663	.3281	.2672	.2685	.2785	
20	.3779	.3845	.3773	.3563	.3365	.3113	
21	.3866	.3945	.3822	.3605	.3431	.3309	
22		.3812	.3772	.337	.3232	.3346	
23	.3309	.3448	.3429	.3329	.2967	.319	.0547
24	.2884	.3069	.3514	.3344	.3259	.2901	.2947
Max	.3866	.3945	.3822	.3605	.3431	.3346	.2999
Min	.2381	.2413	.2403	.2229	.2188	.2155	.0547
Avg	.2966	.3026	.3061	.3003	.2859	.2666	.2298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 204 / 11 KV NILAGONDI GAOTHAN

SEPARATED GAOTHAN FEEDERS

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2817	.2938	.2835	.3073	.2901	.3384	.3345
2	.2798	.2883	.278	.3	.2883	.3219	.2883
3	.2762	.2857	.2725	.289	.2864	.3018	.2857
4	.2689	.2577	.2561	.2817	.2835	.3	.2725
5	.2579	.2329	.2195	.2597	.2872	.278	.2451
6	.1975	.329	.1829	.1884	.2006	.2103	.1955
7	.15	.1793	.1701	.1774	.1612	.2213	.1719
8	.1481	.1903	.192	.1829	.2081	.2012	.1518
9	.1664	.1628		.1886		.1262	.1774
10	.1774	.1663		.2169		.1097	.161
11	.2048	.2587		.2103		.1975	.1939
12	.2378	.255	.2506	.2981	.2542	.2051	.2414
13	.2396	.2532	.2743	.3274	.3073	.3105	.2579
14	.2414	.2532	.2743	.3329	.2926	.3128	.2743
15	.225	.2661	.2414	.3164	.3475	.3197	.2872
16	.192	.231	.2195	.2689	.3292	.2864	.2286
17	.17	.2218	.1994	.2292	.2762	.1975	.2054
18	.1626	.1441	.1957	.2743	.2579	.1829	.168
19	.2772	.2439	.2506	.2569	.2652	.268	
20	.3179	.3086	.3475	.3326	.3567	.3216	
21	.3382	.3216	.3475	.3456	.3585	.3696	.168
22		.3256	.3475	.3271	.3658	.3511	.2103
23	.3123	.3049	.3164	.3049	.3567	.3308	.2195
24	.2853	.3031	.2945	.3109	.292	.353	.3142
Max	.3382	.329	.3475	.3456	.3658	.3696	.3345
Min	.1481	.1441	.1701	.1774	.1612	.1097	.1518
Avg	.2351	.2532	.2578	.2720	.2888	.2673	.2297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 205 / MANEGAON AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0988	.394	.759	.3081	.9222	.8633	.4574
2	.0969	.4014	.7316	.3099	.9148	.8578	.4518
3	.0951	.4089	.7316	.3043	.9018	.8505	.45
4	.0896	.4164	.7133	.3062	.8908	.8413	.4398
5	.0786	.4195	.7115	.3118	.8871	.8322	.4417
6	.0933	.4361	.7005	.9335	.9127	.8249	.439
7	.0951	.4583	.6676	.8688	.931	.8432	.4326
8	.1024	.4602	.6987	.905	.9346	.823	.4217
9	.1079	.4546		.9412	.9346	.8212	.429
10	.1152	.4565		.905	.9145	.8048	.4182
11	.1225	.4121		.9328	.9273	.7873	.4182
12	.9364	.9	.3969	.4682	.4536	.4686	.7978
13	.9492	.8432	.4097	.4627	.4572	.4668	.7468
14	.8816	.8487	.4115	.4682	.4536	.4676	.7543
15	.8706	.8267	.364	.4755	.4627	.4668	.7655
16	.8834	.8505	.3676	.4682	.4646	.4742	.8402
17	.8871		.3896	.4719	.4591	.478	.7133
18	.9108		.3841	.4817	.4664	.4873	.7865
19	.9014	.3951	.3457	.4668	.4591	.4948	
20	.8761	.7609	.3292	.4668	.4591	.4761	
21	.8686	.7334	.3206	.4612	.4536	.4742	.5121
22		.7316	.3109	.4509	.4536	.4686	.439
23	.8464	.7316	.3018	.4472	.4554	.4705	.439
24	.1006	.3865	.4024	.3137	.9444	.8724	.8021
Max	.9492	.9	.759	.9412	.9444	.8724	.8402
Min	.0786	.3865	.3018	.3043	.4536	.4668	.4182
Avg	.4786	.5785	.4975	.5387	.6881	.6548	.5635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 201 / 11 KV SASRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655	.7922	.7127	.7377	.6516	.5596	.8215
2	.7655	.3395	.7127	.7377	.6516	.5596	.7842
3	.7655	.3206	.6802	.7377	.6036	.5596	.7842
4	.7167	.3018	.6802	.7045	.5868	.5533	.7842
5	.5525	.3395	.6562	.6882	.5868	.547	.5658
6	.3018	.3206	.5487	.6554	.4687	.4696	.3772
7	.2286	.2452	.5624	.6554	.4531	.4531	.2667
8	.2641	.2641	.6093	.6718	.4784	.4744	.2667
9	.3018	.3018	.6802	.6642	.4687	.5281	.2641
10	.3395	.3395	.6802	.7042	.5441	.5121	.362
11	.4715	.415		.7449	.5571	.5967	
12	.7373	.7625		.5975	.5788	.4904	.5407
13	.7956	.779		.6722	.6908	.6161	.6036
14	.8048	.3544	.0616	.6722	.7167	.7095	.6371
15	.779	.6796	.5847	.6348	.6348	.6535	.6203
16	.7537	.6802	.4854	.4527	.5093	.5041	.4321
17	.7362	.6958	.3361	.3547	.3395	.6535	.5281
18	.7655	.6944	.3395	.3326	.2829	.3018	.571
19	.7522	.6964	.7356	1.4861	.5335	.5093	
20	.8383	.7712	.7282	.7811	.8676	.7811	
21	.8122	.78	.8488	.9054	.9242	.8299	
22	.8453	.788	.8775	.8676	.9149	.9335	
23	.8215	.788	.8402	.811	.8402	.8589	
24	.7842	.7922	.8215	.7377	.6687	.6036	.5935
Max	.8453	.7922	.8775	1.4861	.9242	.9335	.8215
Min	.2286	.2452	.0616	.3326	.2829	.3018	.2641
Avg	.6541	.5517	.6277	.7086	.6064	.5941	.5446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 202 / 11KV SANGADI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.194	3.3074	1.8599	2.0015	2.0332	2.0492	3.6456
2	3.159	2.3815	1.8274	1.9673	1.9405	2.0023	3.4921
3	3.0571	2.3899	1.8179	1.9521	1.7646	1.9825	3.4349
4	2.8707	2.3364	1.7681	1.8754	1.7089	1.9445	3.3306
5	2.5477	2.1704	1.7086	1.8073	1.6876	1.8137	2.6783
6	1.6442	1.7836	1.5063	1.6091	1.5108	1.5691	2.0062
7	1.4179	1.5066	1.438	1.4518	1.528	.8368	1.589
8	1.4476	1.5485	1.4789	1.541	1.3176		1.4129
9	1.5998	1.595	.8291	1.6701	1.4121	1.5851	1.4502
10	1.8791	1.929	1.536	1.8503	1.62	1.7756	1.6537
11	2.1727	2.279	.5243	1.8528	1.8819	1.9178	
12	1.6606	1.9224	2.8477	3.019	2.9812	2.7759	1.7025
13	1.9395	2.0065	3.0624	3.1909	3.2503	3.275	1.7703
14	1.9852	1.8603	3.0815	3.2867	3.3786	3.3128	1.8486
15	1.9749	1.9315	2.9146	3.2387	3.207	3.3029	1.8387
16	1.8004	1.769	2.4678	2.6109	2.8273	2.7052	1.595
17	1.7913	1.7482	2.1302	2.2382	2.1944	2.0173	1.4773
18	1.6529	1.6516	2.0366	2.0432	2.0106	1.933	1.732
19	1.8557	1.8435	2.7336	2.7035	3.0049	2.6444	.282
20	1.9938	1.9787	3.509	3.6374	3.796	3.3219	
21	2.0164	2.0508	3.7419	3.8344	3.8713	3.5536	
22	2.0995	2.0634	3.777	3.7999	3.8521	3.6774	
23	2.0649	1.9879	3.5532	3.5563	3.6881	3.5273	
24	3.2834	2.9366	2.7172	1.9963	2.0591	2.6147	.9602
Max	3.2834	3.3074	3.777	3.8344	3.8713	3.6774	3.6456
Min	1.4179	1.5066	.5243	1.4518	1.3176	.8368	.282
Avg	2.1295	2.0407	2.2861	2.4473	2.4386	2.4408	1.9947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 203 / 11KV DIGHORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.8299	.6443	.5935	.5144	.5144	.8589
2	.7922	.4527	.6443	.5765	.4801	.5144	.8676
3	.7922	.4382	.6203	.57	.4801	.4801	.8676
4	.7167	.415	.6036	.5765	.4801	.4801	.8488
5	.6224	.4108	.5868	.5658	.4801	.4748	.7167
6	.415	.415	.5197	.4752	.4287	.407	.4338
7	.3395	.3018	.4843	.4641	.3944	.3481	.3395
8	.3584	.3584	.4843	.4744	.4458	.3978	.3048
9	.3961	.415	.5155	.4858	.4801	.4475	.3584
10	.4527	.4715	.5506	.5304	.4973	.4475	.415
11	.547	.5281		.4917	.4801	.4694	
12	.7356	.5801	.6602	.679	.6722	.6224	.4115
13	.7545	.6464	.7545	.7545	.7577	.7842	.4801
14	.6859	.6783	.7468	.7733	.8215	.8215	.6344
15	.703	.6783	.7167	.7356	.7655	.7842	.4973
16	.6516	.6274	.5847	.5658	.5975	.6161	.4801
17	.6344	.6104	.4527	.4763	.4904	.4481	.4287
18	.6001	.583	.3921	.3772	.415	.3734	.3772
19	.6859	.6516	.5281	.4904	.5487	.5093	.3772
20	.7122	.6859	.7373	.8299	.8029	.8573	
21	.7202	.6874	.8962	.9242	.8871	.8488	.3772
22	.7373	.6796	.9149	.9054	.8779	.8775	
23	.7202	.6952	.8589	.8676	.8589	.8402	
24	.811	.7545	.811	.5765	.463	.4973	.4115
Max	.811	.8299	.9149	.9242	.8871	.8775	.8676
Min	.3395	.3018	.3921	.3772	.3944	.3481	.3048
Avg	.6415	.5664	.6395	.6150	.5883	.5776	.5243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 202 / 11 KV SATALWADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1728	.1272					.1344
2	.1494	.1272					.1312
3	.1466	.144					.1392
4	.1579	.1504					.1376
5	.1551	.1536					.1344
6	.1543	.1241					.128
7	.1558	.1227					.1231
8	.148	.1551					.115
9	.1396	.1142					.1166
10	.1396	.1029					.0947
11	.1353	.1015					.096
12			.1086	.1472	.107	.1029	
13			.1139	.152	.1174	.1272	
14			.1159	.1632	.1129	.1186	
15			.1055	.16	.1115	.1115	
16			.1687	.1652	.1082	.136	
17			.1686	.1733	.1214	.1312	
18			.1321	.1668	.1276	.1312	
19			.144	.149	.1306	.1306	
20			.1399	.1425	.1196	.1272	
21			.1399	.1392	.1182	.1247	
22			.1399	.1376	.115	.1231	
23			.1399	.136	.1168	.1215	
24	.144	.1172	.1339				
Max	.1728	.1551	.1687	.1733	.1306	.136	.1392
Min	.1353	.1015	.1055	.136	.107	.1029	.0947
Avg	.1499	.1283	.1347	.1527	.1172	.1238	.1227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 204 / 11 KV KINHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0399	1.0332	1.0638	1.0451	1.0529	1.0214
2	1.0638	1.0029	1.0296	1.0245	1.0227	1.0109	1.0177
3	1.0511	.9598	1.0261	.9891	1.0227	.9199	.9118
4	1.0113	.9183	1.0119	.9835	.9891	.9432	.8626
5	.9389	.9063	1.0048	.948	.9555	.9103	.8554
6	.83	.8082	.7727	.8306	.8379	.8011	.8192
7	.7104	.7141	.5999	.6523	.7136	.7032	.5763
8	.62	.6487	.6066	.6121	.6596	.6308	.5618
9	.6147	.62	.5865	.6344	.6596	.6554	.4892
10	.7283	.5997	.6063	.6523	.7466	.6168	.4873
11	.9853	.6032	.7059	.7466	.7386	.6203	.5777
12	.7611	.7163	.7324	.79	.381	.7421	.5972
13	.8843	.8219	.8517	.9097	.8831	.8779	.7281
14	.8843	.8417	.8663	.8988	.873	.8779	.7377
15	.8626	.7925	.8596	.8691	.8451	.8584	.7239
16	.7358	.7096	.8026	.7394	.6995	.7105	.7029
17	.7077	.7163	.7473	.7357	.6304	.6021	.6032
18	.7765	.6546	.7719	.7683	.7685	.6379	.6473
19	.9081	.9002	.8192	.8988	.9199	.8681	
20	1.1613	1.0421	1.1877	1.0862	1.207	1.0488	.6237
21	1.1613	1.0676	1.184	1.1848	1.1877	1.0899	.2286
22	1.1828	1.1621	1.173	1.1275	1.1694	1.0787	.1859
23	1.1641	1.1474	1.1512	1.0787	1.0785	1.0675	.2621
24	1.181	1.0583	1.0473	1.0787	1.0675	1.0639	.59
Max	1.1828	1.1621	1.1877	1.1848	1.207	1.0899	1.0214
Min	.6147	.5997	.5865	.6121	.381	.6021	.1859
Avg	.9176	.8522	.8824	.8876	.8792	.8495	.6440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 205 / 11 KV SATALWADA GT.

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1092	2.0411	2.1231	1.9828	1.8075	1.9753	1.7897
2	2.1129	2.0053	2.1194	1.9602	1.811	1.9413	1.7859
3	2.0453	2.002	2.1156	1.9338	1.8243	1.9262	1.7897
4	2.0415	1.9295	2.0319	1.9093	1.7813	1.8904	1.7519
5	2.0266	1.9602	1.9828	1.8696	1.7526	1.8451	1.7482
6	1.9489	1.9602	1.8925	1.7784	1.6048	1.7406	1.555
7	1.8727	1.8463	1.8312	1.7121	1.5475	1.6116	1.4137
8	1.8518	1.7059	1.6847	1.7158	1.5467	1.5128	1.286
9	1.8348	1.7135	1.6533	1.6822	1.5581	1.5128	1.3512
10	1.8667	1.7032	1.6516	1.727	1.621	1.5995	1.4983
11	1.8667	1.7831	1.7874	1.8331	1.7084	1.721	1.5203
12	1.8854	1.8829	1.8435	1.8368	1.8217	1.8199	1.5656
13	1.9915	1.9857	1.9191	1.9517	1.807	1.6757	1.6486
14	2.0243	1.9564	1.8957	1.8311	1.818	1.7172	1.6699
15	1.9451	1.8861	1.7944	1.7979	1.7522	1.6984	1.633
16	1.7934	1.7558	1.7769	1.6406	1.5845	1.5775	1.4974
17	1.7474	1.8119	1.0584	1.6048	1.501	1.4496	1.4388
18	1.8576	1.7898	1.9092	1.6227	1.654	1.3512	1.5198
19	2.0064	2.1073	2.0694	1.6621	1.9131	1.7993	
20	2.2932	2.2786	2.353	1.852	2.2783	1.9898	
21	2.297	2.2786	2.3623	1.9862	2.2522	1.9608	.9474
22	2.2559	2.2786	2.2899	1.9427	2.1118	1.9065	.951
23	2.1128	2.142	2.1231	1.921	2.0054	1.7978	.9401
24	2.1203	2.0555	2.1269	1.933	1.8908	1.9179	1.3663
Max	2.297	2.2786	2.3623	1.9862	2.2783	1.9898	1.7897
Min	1.7474	1.7032	1.0584	1.6048	1.501	1.3512	.9401
Avg	1.9961	1.9525	1.9331	1.8203	1.7897	1.7474	1.4849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 201 / 11 KV CHANDORI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	1.0974	1.0751	1.0669	.8954	.9335	.7842
2	.7167	1.0608	1.0562	1.0479	.8764	.8596	.7842
3	.6979	1.0534	1.0374	1.0479	.8383	.8417	.7655
4	.679	1.0269	1.0374	1.0288	.8192	.8145	.7468
5	.6413	.9896	1.0185	1.0098	.7621	.7602	.7095
6	.5847	.924	.8865	.8192	.6859	.7059	.5975
7	.5847	.7865	.8589	.8002	.6859	.6908	.5788
8	.5847	.7947	.8215	.8002	.6478	.6584	.5788
9	.5847	.7865	.8775	.8002	.6859	.6401	.5975
10	.8299			.8192	.7049	.7356	.5975
11	.8402	.5716		.8402	.7621	.7522	.6348
12	.7947	.6097	.9526	.8764	.4191	.7522	.6859
13	.8589	.9896	1.0288	.9526	.8573	.8417	.7621
14	.8589	.9709	1.0288	.9335	.8573	.8596	.7621
15	.8402	.9709	.9526	.8764	.8192	.788	.7049
16	.8215	.8589	.9145	.8383	.6859	.6984	.6478
17	.8589	.5525	.9526	.8192	.6859	.6447	.6668
18	.9896	.743	.9335	.8002	.8002	.6447	.6859
19	1.0829	1.1128	1.0288	.8573	.8962	.8238	
20	1.1949	1.1694	1.2003	.9717	.9979	.8775	
21	1.1949	1.1506	1.1622	.9907	1.0082	.8775	
22	1.1763	1.1506	1.1241	.9526	.9709	.8596	
23	1.1576	1.1128	1.086	.9335	.9717	.8059	.4572
24	.7356	1.1157	1.1128	1.086	.9145	.9231	.7842
Max	1.1949	1.1694	1.2003	1.086	1.0082	.9335	.7842
Min	.5847	.5525	.8215	.8002	.4191	.6401	.4572
Avg	.8352	.9391	1.0067	.9154	.8020	.7829	.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 202 / 11 KV PITEZARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8962	.8916	.884	.8383	.8029	.7773
2	.8887	.8813	.884	.884	.8307	.796	.7697
3	.8887	.8663	.8764	.865	.823	.8002	.7773
4	.8775	.8514	.8764	.8573	.8078	.7846	.7621
5	.8738	.8253	.8535	.8535	.8002	.7771	.7545
6	.7468	.7692	.8612	.8535	.7697	.7468	.7164
7	.5153		.8002	.8154	.7468	.7095	.7087
8	.5228			.7697	.7316	.7394	.663
9	.5004			.8002	.7697	.7543	.6935
10	.5079			.8078		.8078	.7087
11	.6124	.8993	.8612	.8073		.8066	.7087
12	.8439	.9069	.8916	.8612		.8383	.7316
13	.8589	.8764	.8688	.884	.8573	.8383	.7697
14	.8663	.8688	.8307	.8764	.8764	.823	.7773
15	.8514	.8535	.8154	.5639	.8383	.8154	.7621
16	.7842	.823		.5487	.442		.7468
17	.7767	.7916	.7773	.5582	.4382	.6859	.724
18	.7767	.8215	.7773	.8078	.8002	.7468	.7087
19	.8962	.8701	.8688	.7849	.9145	.8459	
20	.9186	.9634	.9297	.8459	.9374	.8688	
21	.9335	.9634	.9297	.8612	.9145	.8612	
22	.9335	.941	.9145	.8535	.8954	.8307	
23	.9037	.9335	.8993	.8383	.8535	.823	.503
24	.9037	.9111	.8993	.8993	.8383	.8215	.8192
Max	.9335	.9634	.9297	.8993	.9374	.8688	.8192
Min	.5004	.7692	.7773	.5487	.4382	.6859	.503
Avg	.7949	.8757	.8653	.8075	.7964	.7967	.7291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 203 / 11 KV BODRA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)
11	.3414	
12	.3531	
13	.3564	
14	.3514	
15	.3497	
16	.3232	
17	.3249	
22		.1943
23		.3048
Max	.3564	.3048
Min	.3232	.1943
Avg	.3429	.2496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 201 / 11 KV GONDUMRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.4435		.4435			.3801
2	.4251	.4435		.4435			.362
3	.4207	.4251		.4435			.362
4	.4207	.4251		.4251			.362
5	.4207	.4251		.4251			.362
6	.439	.4435		.462			.362
7	.439	.4435					.3982
8	.4572	.4805					.4163
9	.439	.4755					.3801
10	.4755	.4755					.3982
11	.4755	.4755					
12				.462	.462	.4656	
13				.4805	.499		
14				.4755	.499	.4938	
15				.4755	.462	.4938	
16				.4755	.4805	.4938	
17				.4805	.5175	.4755	
18				.5175	.5359	.5121	
19			.4805	.4435	.5175	.5121	
20			.4525	.462	.5175	.4938	
21			.462	.4435	.5175	.4572	
22			.462	.439	.499	.4572	
23			.4435	.4251	.499	.439	
24	.4435	.4435	.4207	.4435			
Max	.4755	.4805	.4805	.5175	.5359	.5121	.4163
Min	.4207	.4251	.4207	.4251	.462	.439	.362
Avg	.4416	.4500	.4535	.4561	.5005	.4813	.3783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 202 / 11 KV WADAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086		.3403			.362
2		.3086		.3403			.362
3		.3429		.3403			.362
4		.3429		.3224			.362
5		.3772		.3224			.3801
6		.4115		.3224			.3801
7	.3222	.4115					.362
8	.3222	.3429					.362
9	.3222	.3561					.362
10	.3391	.3561					.4163
11	.3561	.3561					
12				.362	.3439	.3801	
13				.394	.4163		
14				.3982	.4163	.4525	
15				.394	.3982	.4207	
16				.3982	.3982	.4207	
17				.4251	.4163	.4024	
18				.4207	.3801	.4024	
19			.3292	.3658	.3801	.3841	
20			.3475	.3658	.3801	.3658	
21			.3439	.3439	.3801	.3475	
22			.3224	.3439	.362	.3292	
23			.3403	.3439	.362	.3292	
24	.3258	.3086	.3189	.3403			
Max	.3561	.4115	.3475	.4251	.4163	.4525	.4163
Min	.3222	.3086	.3189	.3224	.3439	.3292	.362
Avg	.3313	.3519	.3337	.3623	.3861	.3850	.3711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 203 / 11 KV KHANDALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5721	.5083	.4908	.4557	
2			.5721	.5083	.4961	.4557	
3			.5895	.5083	.4961	.4557	
4			.5895	.5083	.4961	.4557	
5			.5895	.5258	.4961	.4733	
6			.5895	.5434	.5138	.4733	
7			.5895	.583	.5493	.4733	
8			.5895	.4973	.5138		
9			.5895	.5316	.567		
10			.5895	.5316	.5138	.4733	
11				.4973	.5316	.4733	
12	.5281	.5895					.3801
13	.5575	.6068					.4344
14	.5135	.6241					.4706
15	.5967	.6241					.4706
16	.5281	.6241					.4784
17	.5281	.6241					.4784
18	.5868	.6762					.4961
19	.5563	.6762					
20	.5424	.6415					
21	.5424	.6697					
22	.5146	.6697					
23	.4729	.6697					
24				.5083	.4908	.4557	.4382
Max	.5967	.6762	.5895	.583	.567	.4733	.4961
Min	.4729	.5895	.5721	.4973	.4908	.4557	.3801
Avg	.5390	.6413	.5860	.5210	.5129	.4645	.4559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 204 / PALASGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAY-17	23-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048
2	.3048	.3048	.3048	.3048	.2286
3	.3048	.3048	.3048	.3048	.2286
4	.3048	.3048	.3048	.2286	.2286
5	.3048	.3048	.3048	.3048	.2286
6	.2286	.3048	.3048	.2286	.1524
7	.2286	.2286	.2286	.1524	.1524
8	.2286	.2286	.1524	.2286	.1524
9	.1524	.2286	.1524	.1524	.1524
10	.2286	.1524	.2286	.2286	.1524
11	.2286	.2286	.2286	.2286	.1524
12	.3048	.2286	.3048	.2286	.2286
13	.3048	.2286	.3048	.3048	.381
14	.3048	.2286	.3048	.3048	.381
15	.2286	.2286	.3048	.3048	.3048
16	.3048	.2286	.3048	.3048	.3048
17	.2286	.1524	.2286	.2286	.2286
18	.2286	.1524	.2286	.3048	.2286
19	.3048	.2286	.2286	.3048	.2286
20	.381	.3048	.381	.381	
21	.3048	.3048	.381	.381	
22	.3048	.3048	.3048	.3048	
23	.3048	.3048	.3048	.3048	
24	.3048	.3048	.3048	.3048	
Max	.381	.3048	.381	.381	.381
Min	.1524	.1524	.1524	.1524	.1524
Avg	.2762	.254	.2794	.2762	.2326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 205 / SUKALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6169	.562	.5609	.4589	.5883	.4793	.4096
2	.3048	.562	.5426	.4435	.5883	.4793	.3334
3		.5449	.5426	.4435	.5883	.4614	.3153
4		.5449	.4877	.4077	.5883	.4614	.3153
5		.5277	.4877	.4366	.4944	.4435	.3153
6		.4172	.4115	.3136	.4589	.4435	.1848
7	.208	.3239	.3536	.3315	.3473	.3296	.1667
8	.4193	.2896	.4298	.3315	.3277	.3296	.1667
9	.4366	.3067	.4481	.3334	.3627	.3119	.221
10	.4366	.3239	.4481	.3696	.4214	.3296	.2029
11	.4607	.3559		.4793	.4389	.3296	.0762
12	.4607	.449		.4915	.4515	.365	.3334
13	.5534	.466	.3353	.3084	.4687	.4767	.454
14	.4772	.466	.3353	.3102	.4858	.4767	.4713
15	.4607	.449	.3353	.2941	.4344	.4639	.454
16	.4275	.4321	.2987	.2587	.4172	.4277	.4389
17	.3944	.2286	.3002	.1648	.341	.3334	.3258
18	.3513		.3002	.4767	.341	.3696	.3431
19	.4858	.509	.3877	.474	.4515	.4458	.1524
20	.562	.6306	.482	.5852	.4972	.4639	
21	.562	.6306	.4887	.606	.5913	.482	
22	.5791	.6306	.5822	.5883	.5913	.5029	
23	.5791	.6125	.4887	.5883	.5913	.4664	
24	.6169	.5791	.5363	.5529	.5121	.4972	.2195
Max	.6169	.6306	.5822	.606	.5913	.5029	.4713
Min	.208	.2286	.2987	.1648	.3277	.3119	.0762
Avg	.4697	.4714	.4356	.4187	.4741	.4237	.2950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 206 / SAWARBANDH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7506	.7468	.6525	.6487	.7468	.7544	.6487
2	.6523	.7102	.5401	.6157	.7468	.7102	.5944
3	.6523	.7102	.5401	.5974	.7468	.7102	.5944
4	.634	.6919	.522	.5582	.7468	.6553	.5763
5	.6157	.5974	.522	.5706	.7102	.6188	.5582
6	.4481	.5426	.4115	.4458	.5791	.5243	.4115
7	.3536	.4298	.3353	.4458	.4481	.4115	.4298
8	.3536	.4298	.4664	.4458	.5212	.4847	.3353
9	.4847	.5001	.4481	.4458	.5974	.4664	.3353
10	.4481	.5001	.4664	.4614	.5212	.4847	.3353
11	.5001	.4972		.4972	.5791	.4847	.2286
12	.6306	.5734		.6487	.6157	.634	.6487
13	.6668	.6451	.6374	.7249	.634	.6523	.6237
14	.7249	.6451	.6374	.743	.7834	.7285	.7176
15	.6306	.7034	.6374	.7249	.7285	.7249	.7176
16	.5763	.5913	.5662	.5763	.6919	.5944	.5791
17	.4458	.5555	.4944	.5029	.5609	.6125	.5706
18	.4458	.4793	.4944	.5212	.4847	.4639	.4944
19	.5578	.6668	.6689	.5212	.6523	.5182	.2286
20	.8017	.7973	.8779	.8017	.9144	.7792	
21	.7651	.7792	.8647	.8779	.9053	.7792	
22	.7651	.7792	.7885	.7834	.8866	.7468	
23	.7468	.743	.7354	.7651	.7918	.7285	
24	.7506	.7468	.743	.7249	.7468	.6969	.3475
Max	.8017	.7973	.8779	.8779	.9144	.7792	.7176
Min	.3536	.4298	.3353	.4458	.4481	.4115	.2286
Avg	.6000	.6276	.5932	.6104	.6808	.6235	.4988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 201 / 11 KV S'Wafa AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.2408	3.0508	2.9264	3.1876	
2			3.1931	3.0178	2.9264	3.1863	
3			3.1931	3.0026	2.8959	3.1558	
4			3.1931	3.0241	2.8654	3.0925	
5			3.176	3.0068	2.9033	2.7063	
6			3.1544	3.2848	3.1275	2.6822	
7			3.2846	3.3325	3.3501	3.2979	
8			3.3676	3.4156	3.2495	3.2979	
9			3.4812	3.4156	3.123	3.3152	
10			3.6136	3.4156	3.171	3.3806	
11			2.4044	3.4461	3.2535	3.315	
12	1.7372	1.7193	.9755	1.7985	1.6461	1.7071	.3269
13	3.5959	3.7227					2.2664
14	3.5122	3.7582					2.9085
15	3.4766	3.7532					2.9569
16	3.4335	3.6136					2.982
17	3.5654	3.7936					3.4335
18	3.5891	3.7913					3.4812
19	3.5422	3.6336					1.0669
20	3.363	3.3981					
21	3.3325	3.3981					
22	3.3021	3.3499					
23	3.3021	3.315					
24	1.6766	1.7375	1.6301	1.4706	1.4327	1.5415	
Max	3.5959	3.7936	3.6136	3.4461	3.3501	3.3806	3.4812
Min	1.6766	1.7193	.9755	1.4706	1.4327	1.5415	.3269
Avg	3.1868	3.3065	2.9160	2.9755	2.8362	2.9128	2.4278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 202 / 11KV SOUNDAD FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8973	.7126	.7126	.7663	.6466	.4268	.6821
2	.8973	.7126	.7126	.7705	.6466	.3963	.7126
3	.8973	.7126	.7126	.7316	.6466	.3658	.7088
4	.8809	.7088	.7126	.7358	.6268	.3658	.7088
5	.8177	.7011	.7126	.7358	.6234	.3658	.7011
6	.7389	.6973	.7705	.7274	.5704	.3658	.6592
7	.6554	.7124	.7905	.6895	.6249	.6321	.6068
8	.6554	.6668	.7905	.6213	.6213	.6285	.5639
9	.7358	.688	.8269	.6518	.7442	.659	.6287
10	.7905	.6706	.8832	.6744	.7949	.659	.7972
11	.7905	.6663	.8988	.6783	.7204	.7688	.8063
12	.7126	.7956	.9137	.6821	.6973	.8621	.8155
13	.7284	.8428	.9038	1.7415	.7164	.8093	.7831
14	.7324	.8124	.8996	.6663	.7364	.7669	.7202
15	.7284	.834	.9137	.6663	.759	.7526	.6897
16	.7049	.7873	.8878	.3658	.7949	.7364	.761
17	.6554	.6895	.9038	.6363	.7861	.7044	.6912
18	.6739	.6668	.8146	.6897	.724	.6445	.5801
19	.6859	.7644	.7817	.6504	.9065	.7358	.3048
20	.7526	.7873	.8621	.6807	.7568	.7831	.1781
21	.7629	.7831	.8459	.6807	.82	.7789	.3673
22	.7284	.7831	.9099	.6607	.834	.7284	.3957
23	.7284	.7324	.8367	.6302	.8036	.7244	.3978
24	.8173	.7126	.7431	.7034	.7381	.3963	.5602
Max	.8973	.8428	.9137	1.7415	.9065	.8621	.8155
Min	.6554	.6663	.7126	.3658	.5704	.3658	.1781
Avg	.7570	.7350	.8225	.7182	.7225	.6274	.6175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 203 / 11KV SAKOLI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3493	3.3189	3.1684	3.3325	3.3969	3.3798	3.0198
2	3.2309	3.2526	3.0178	3.2328	3.294	3.3144	2.7705
3	3.0331	3.1916	2.8978	3.0659	3.1969	3.2132	2.5339
4	2.9462	3.0769	2.7473	2.9416	3.0941	3.1009	2.6454
5	2.673	2.8502	2.5362	2.9992	2.8521	3.0373	2.4958
6	2.3916	2.3611	2.2775	2.4584	2.681	2.6149	2.2619
7	2.0965	2.2192	1.9578	2.0815	2.2952	2.2249	1.9511
8	1.99	1.699	1.9173	2.0378	2.2451	2.103	1.8465
9	2.0443	1.6948	1.9524	2.2322	2.3937	2.1841	1.8424
10	2.2627	2.1674	2.1251	2.5334	2.617	2.3582	1.9464
11	2.7311	2.5518	1.1795	2.955	2.9748	2.5511	1.7728
12	2.9569	2.7938	1.1165	3.0769	3.1684	2.7665	2.3533
13	3.2221	3.0026	1.1828	3.3851	3.403	3.1074	2.6092
14	3.4443	3.1789	1.3332	3.4819	3.5122	3.1684	2.9569
15	3.3672	3.0967	3.4084	3.4819	3.4282	3.1863	3.0589
16	3.2473	3.0788	3.2613	3.3322	3.3322	3.0685	2.9999
17	3.0049	2.8472	3.038	3.0941	3.1069	2.7416	2.8495
18	2.7969	2.5985	2.8896	2.794	2.8418	2.4425	2.5811
19	2.8349	2.6702	2.6947	2.6602	2.9855	2.4767	1.2803
20	3.0734	3.0285	3.0715	3.0769	3.2221	2.8807	.061
21	3.1199	3.0589	3.2526	3.275	3.3851	3.041	
22	3.3189	3.2569	3.4209	3.4874	2.8193	3.3726	
23	3.4103	3.3722	3.5483	3.5665	3.597	3.3977	
24	3.4819	3.3547	3.3745	3.464	3.5122	3.4084	1.6118
Max	3.4819	3.3722	3.5483	3.5665	3.597	3.4084	3.0589
Min	1.99	1.6948	1.1165	2.0378	2.2451	2.103	.061
Avg	2.9178	2.8217	2.5571	3.0019	3.0564	2.8808	2.2594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 204 / 11 KV LAKHANDUR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1733	.1909	.1265	.1562	.0829	.0655	.1605
2	.1429	.1605	.1265	.1554	.0829	.0655	.1273
3	.1429	.1605	.1265	.1265	.0829	.0663	.1273
4	.1429	.1605	.1265	.1569	.0829	.0655	.1273
5	.0819	.1605	.1265	.1258	.0829	.0663	.1439
6	.0819	.1107	.1265	.1265	.0829	.0655	.1439
7	.0819	.1605	.0797	.1265	.0829	.0663	.0652
8	.0838	.0837	.0797	.1265	.0829	.0663	.0652
9	.0671	.1605	.1265	.1265	.0829	.0663	.165
10	.0492	.1107	.1265	.1273	.0829	.0995	.1989
11	.0492	.0802	.1429	.1107	.0829	.0995	.1989
12	.0492	.0802	.1265	.1605	.0829	.1605	.1303
13	.0492	.1288	.1265	.1605	.0829	.1605	.165
14	.0497	.13	.1265	.1909	.0829	.1605	.113
15	.0497	.0802	.1265	.1909	.0829	.1605	.113
16	.0995	.0802	.1569	.1909	.0829	.1273	.165
17	.0497	.0797	.1569	.1605	.0829	.1577	.1147
18	.0497	.0797	.1569	.1273	.0819	.1605	.1136
19	.0497	.1102	.1569	.0829	.1311	.1605	.0305
20	.0995	.1102	.1569	.0829	.1147	.224	.2804
21	.0497	.1265	.1569	.0829	.0819	.1605	1.8119
22	.0995	.1265	.1569	.0829	.0819	.1605	2.5244
23	.0995	.1102	.1569	.0332	.0819	.1605	3.7342
24	.1593	.1605	.1569	.0655	.0829	.1439	2.2333
Max	.1733	.1909	.1569	.1909	.1311	.224	3.7342
Min	.0492	.0797	.0797	.0332	.0819	.0655	.0305
Avg	.0855	.1226	.1347	.1282	.0861	.1204	.5439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 205 / 11 KV EKODI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0035	2.0641	1.9785	1.9951	2.0165	2.111	1.8884
2	1.9951	2.0805	1.8884	1.9844	1.9753	2.0893	1.8556
3	1.948	2.0172	1.8556	1.9376	1.9315	2.0605	1.8461
4	1.8903	1.9867	1.8156	1.9315	1.9418	1.9925	1.8061
5	1.8381	1.8623	1.7662	1.901	1.8884	1.9566	1.7345
6	1.7345	1.7503	1.7098	1.7597	1.8156	1.8623	1.6488
7	1.5809	1.6707	1.564	1.6187	1.6042	1.7198	1.5241
8	1.5565	1.732	1.5592	1.5592	1.6217	1.7198	1.4866
9	1.6735	1.7625	1.6362	1.6613	1.5737	1.7292	1.48
10	1.6507	1.7261	1.7642	1.6918	1.6937	1.1256	1.5651
11	1.7204	1.7437	1.8176	1.8603	1.7479	.6234	1.5984
12	1.854	1.8111	1.9071	1.928	1.9175	.6897	1.64
13	1.8844	1.8945	1.9646	1.9646	1.928	.9599	1.7174
14	1.901	1.9753	1.9315	1.9006	1.9113	1.2101	1.8306
15	1.901	1.9723	1.9212	1.9646	1.9376	1.2269	1.8138
16	1.7947	1.8884	1.848	1.0364	1.9109	1.1682	1.7406
17	1.7292	1.7357	1.8294	1.7452	2.1758	1.0881	1.6918
18	1.7475	1.7475	1.7978	1.778	1.8238	1.6308	1.6114
19	1.8136	1.8767	1.8701	1.7223	2.0054	1.7806	.7316
20	2.0866	2.0504	2.0698	1.9966	2.274	2.0334	
21	2.1338	2.0809	2.1453	2.1262	2.4148	2.0165	.3105
22	2.1811	2.0978	2.1643	2.1283	2.3215	2.0809	.7484
23	2.1643	2.0698	2.2512	2.0809	2.2515	2.0256	.7789
24	2.1058	2.0641	2.0422	2.0225	2.108	2.0591	1.3384
Max	2.1811	2.0978	2.2512	2.1283	2.4148	2.111	1.8884
Min	1.5565	1.6707	1.5592	1.0364	1.5737	.6234	.3105
Avg	1.8704	1.9025	1.8791	1.8456	1.9496	1.6233	1.4951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 206 / 11 KV SHENDURWAFI GT.

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7025	1.7939	1.6507	1.6247	1.5655	1.6032	1.6032
2	1.746	1.7762	1.6137	1.5935	1.5089	1.4937	1.5655
3	1.6724	1.7766	1.5573	1.5384	1.4335	1.4712	1.5089
4	1.6019	1.6849	1.4495	1.4792	1.4335	1.4003	1.4146
5	1.4803	1.591	1.3575	1.4606	1.358	1.307	1.2826
6	1.2128	1.2469	1.2052	1.2605	1.1694	1.1317	1.0562
7	1.2386	1.1576	1.0776	.1528	1.0374	.9431	.9619
8	1.0877	1.1386	1.0934	1.1005	1.0374	.9431	.8488
9	1.0932	1.129	1.1172	1.1336	1.0479	1.0562	.9054
10	1.183	1.1866	1.1968	1.2218	1.2003	1.094	.9054
11	1.2689	1.3584	1.3196	1.2645	1.3527	1.2449	1.105
12	1.3805	1.4811	1.4445	1.1128	1.4523	1.4146	1.2193
13	1.558	1.5568	1.5653	1.4712	1.5655	1.5655	1.3336
14	1.599	1.6514	1.6027	1.4712	1.5844	1.5655	1.4289
15	1.3172	1.384	1.5637	1.4712	1.5089	1.5655	1.448
16	1.4037	1.4712	1.434	1.3014	1.3769	1.4335	1.2765
17	1.3078	1.3405	1.3287	1.0669	1.1883	1.1317	1.1241
18	1.2689	1.2327	1.2984	1.1694	1.1883	1.1317	1.0669
19	1.5202	1.4769	1.548	1.226	1.5278	1.358	
20	1.765	1.6246	1.8175	1.6004	1.7164	1.4098	
21	1.8427	1.7345	1.8738	1.7337	1.7541	1.6032	.5611
22	1.7601	1.8042	1.8719	1.7541	1.773	1.7164	.9979
23	1.757	1.765	1.8103	1.6975	1.7353	1.5844	1.3203
24	1.8498	1.7494	1.7124	1.5729	1.6221	1.6787	1.6221
Max	1.8498	1.8042	1.8738	1.7541	1.773	1.7164	1.6221
Min	1.0877	1.129	1.0776	.1528	1.0374	.9431	.5611
Avg	1.4841	1.5047	1.4796	1.3533	1.4224	1.3686	1.2071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 401 / SAKOLI I

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.2963	2.7978	3.1367	2.6235	2.8669	1.2146
2	1.2963	1.2334	2.7664	2.7664	2.5943	2.8166	1.2003
3	1.2963	1.2334	2.7161	2.7161	2.5434	2.7349	1.2003
4	1.2334	1.2186	2.7161	2.7161	2.5434	2.6852	1.2003
5	1.2037	1.1574	2.6852	2.7349	2.5434	2.6852	1.1385
6	1.0974	1.0974	2.7161	2.7349	2.5857	2.6852	1.0059
7	.9934	1.0837	2.6852	2.7526	2.6355	2.6355	.9808
8	.9934	1.0837	2.7161	2.6852	2.5857	2.6543	.9362
9	1.0974	1.0837	2.7846	2.6852	2.5857	2.6852	.9362
10	1.2186	1.5089	2.9675	2.8166	2.7161	2.2131	1.0648
11	1.2483	1.1248	2.1879	2.7349	2.7161	2.2891	1.1248
12	2.9172	2.9835	1.3117	1.2146	1.2483	.7682	1.9216
13	2.9504	3.1539	1.3117	1.2146	1.2146	.7202	2.572
14	2.9504	3.1893	1.3117	1.166	1.2289	.9231	2.6235
15	2.8995	3.0864	1.2929	1.2146	1.3117	.9231	1.166
16	2.8487	2.8509	1.2334	1.1174	1.2334	.8796	2.6452
17	2.8669	2.9675	1.2809	1.1111	1.1574	.7579	2.7161
18	2.8178	2.9001	1.3077	1.0837	1.1591	1.0122	2.6355
19	2.9338	2.8669	1.2186	1.1523	1.2809	1.1717	
20	2.9172	2.9835	1.4255	1.2574	1.442	1.3272	.1806
21	2.9675	3.0013	1.3923	1.3077	1.442	1.278	.2486
22	2.9675	3.0013	1.3763	1.2929	1.4746	1.3272	.5344
23	2.9504	2.9504	1.3117	1.2431	1.4255	1.2483	.5898
24	1.3603	1.2963	1.2929	2.7978	2.6749	2.9504	1.2146
Max	2.9675	3.1893	2.9675	3.1367	2.7161	2.9504	2.7161
Min	.9934	1.0837	1.2186	1.0837	1.1574	.7202	.1806
Avg	2.0571	2.0980	1.9503	1.9855	1.9569	1.8433	1.3500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 402 / 33 KV WADAD

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.1492	5.2058	3.7792	6.0597	5.8099	5.4298	
2	4.6965	5.0926	3.6866	6.0597	5.8099	5.4298	
3	4.5833	5.036	3.6374	5.9534	3.3316	5.3212	
4	4.357	4.9228	3.5951	5.8471	5.3224	5.2669	
5	4.1872	3.9369	3.4008	5.6344	5.2675	5.1583	
6	3.315	3.8866	2.9412	4.9383	4.4056	4.4907	
7	3.658	3.4865	2.8349	3.8409	4.1015	2.5143	
8	3.4751	1.9605	2.963	3.9323	4.161	3.6969	
9	3.7346	2.1622	3.1579	4.3724	4.5182	3.7357	
10	4.3004	2.2068	3.1207	4.4753	4.8891	4.473	
11	4.6399	2.4897		5.2126	5.104	5.0297	
12	5.8025	3.5803		1.829	4.9228	4.8663	2.8841
13	6.3397	2.9172		5.4321	5.4321	4.425	3.2819
14	6.286	3.5208		5.2624	5.5453	5.3189	3.4705
15	6.1248	3.6866		4.8011	5.3189	5.2624	3.3699
16	5.7939	3.4008		4.5833	4.8097	4.6965	2.9001
17	5.4161	3.131		4.357	4.357	4.1872	2.7846
18	3.2922	3.0178		4.313	4.1872	4.257	2.8589
19	5.8471	3.6923	2.5463	4.5542	4.425	4.8663	.0171
20	6.5547	4.1244	4.481	5.5996	5.8282	5.5453	
21	6.5009	4.1747	4.9851	5.9414	5.8848	4.201	
22	6.5009	4.1747	5.0972	5.715	5.7716	5.3755	
23	6.286	3.9781	4.8234	5.4321	5.4887	4.8663	
24	5.4887	5.2058	2.2805	6.0711	5.8642	5.5418	4.1152
Max	6.5547	5.2058	5.0972	6.0711	5.8848	5.5453	4.1152
Min	3.2922	1.9605	2.2805	1.829	3.3316	2.5143	.0171
Avg	5.0971	3.7080	3.5831	5.0091	5.0232	4.7482	2.8536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 403 / SAKOLI II

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1824	3.1824	3.0493	3.1927	3.271	3.3471	2.6063
2	3.0727	3.1276	3.1602	3.0727	3.2156	3.2922	2.4977
3	2.963	2.963	2.8829	2.963	3.1047	3.1824	2.8778
4	2.8532	2.7984	2.7721	2.8532	3.0493	3.1276	2.8235
5	2.6886	2.6886	2.6057	2.7721	2.8829	2.963	2.6063
6	2.1622	2.1068	2.0725	2.2497	2.384	2.384	2.1399
7	1.8656	1.9204	1.885	2.009	2.1622	2.0851	1.9004
8	1.8656	1.8107	1.885	1.9753	2.0851	1.9753	1.9753
9	1.9204	1.8107	1.9404	1.9753	2.1948	2.0851	1.7558
10	2.1622	2.2731	2.0513	2.2119	2.524	2.2497	1.8656
11	2.4949	2.3594	1.6244	2.4143	2.7984	2.4691	1.885
12	2.7435	2.6057	1.7924	2.6612	3.0727	2.7984	2.384
13	2.963	2.9384	2.0165	3.1824	3.271	3.0493	2.6057
14	3.1047	2.9938	2.0725	3.2373	3.3265	3.1602	2.8275
15	3.0178	2.9384	3.1276	3.1276	3.1824	3.1276	2.9384
16	2.7984	3.0493	2.7984	2.963	3.0178	2.8532	2.7166
17	2.5789	2.524	2.6337	2.5789	2.6606	2.364	2.4691
18	2.392	2.3348	2.4714	2.552	2.5789	2.3102	2.2497
19	2.7149	2.6337	2.7692	2.5503	2.8532	2.6337	.0154
20	3.1047	2.9938	3.1602	3.1047	3.3265	3.0493	.4858
21	3.1602	3.1047	3.271	3.3265	3.4374	3.1047	1.6278
22	3.2922	3.271	3.4019	3.6037	3.5482	3.3471	2.4394
23	3.3819	3.271	3.3471	3.4374	3.5482	1.6124	3.0493
24	3.2922	3.2373	3.1602	3.3048	3.3265	3.4374	3.1824
Max	3.3819	3.271	3.4019	3.6037	3.5482	3.4374	3.1824
Min	1.8656	1.8107	1.6244	1.9753	2.0851	1.6124	.0154
Avg	2.7406	2.7057	2.5813	2.8050	2.9509	2.7503	2.2469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 404 / 33 KV PARASTOLA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7188	4.9383	6.3626	5.6264	5.9099	5.7939	2.6029
2	4.6639	4.8325	6.3626	5.5739	5.3212	5.7407	3.2253
3	4.5068	4.8325	6.1894	5.5213	5.6413	5.6876	3.1687
4	4.3982	4.6696	6.1374	5.4161	5.6413	5.6876	3.1121
5	4.3982	4.6153	6.0854	5.3635	5.6413	5.5813	2.8858
6	3.8009	4.1267	5.695	4.784	5.1532	4.8903	2.4331
7	3.5117	3.8152	5.2469	5.3412	5.0972	4.7331	2.2497
8	3.2922	3.0498	.6859	5.4092	4.9931	4.7851	2.5149
9	3.4019	3.1361	.8402	5.048	4.8891	4.6291	
10	3.6591	2.3663	.0543	5.3155	4.2181	4.8903	2.6595
11	3.9918	3.8272	.7922	5.7693	4.265	5.475	2.7435
12	6.0597	6.0174	4.8285	4.257	2.7446	4.5542	4.6091
13	6.4318	6.5729	4.1267	4.8285	4.6016	4.8285	4.9931
14	6.4152	6.5729	4.8285	4.7737	4.5462	4.8834	5.048
15	6.2574	5.4527	4.7188	4.4353	4.5462	4.7737	4.9434
16	6.0334	6.1894	3.4922	4.0472	3.77	3.546	4.7782
17	5.9156	4.784	4.2444	3.5665	3.7311	3.7466	3.786
18	5.8848	4.8285	4.3056	3.8552	3.9638	3.638	4.6776
19	6.5329	5.9945	4.8325	4.2135	4.4993	3.9506	
20	6.941	6.9102	5.487	4.8171	5.1006	4.537	
21	6.9936	6.9102	5.3772	4.9291	4.9343	4.537	.2829
22	4.5748	6.8039	5.2675	4.7611	4.9343	4.4907	.9145
23	6.7833	6.6255	5.3189	4.5462	4.8234	4.3244	2.3765
24	4.7737	5.048	5.3212	5.4687	6.0174	5.9637	5.2126
Max	6.9936	6.9102	6.3626	5.7693	6.0174	5.9637	5.2126
Min	3.2922	2.3663	.0543	3.5665	2.7446	3.546	.2829
Avg	5.1642	5.1217	4.4417	4.9028	4.7910	4.8195	3.2961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAY-17 and 28-MAY-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 410 / 33 KV SATALWADA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAY-17	23-MAY-17	24-MAY-17	25-MAY-17	26-MAY-17	27-MAY-17	28-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5463	2.3663	2.4897	2.2965	2.1622	2.1622	2.1068
2	2.5463	2.5463	2.2119	2.2965	2.0851	2.0953	2.1068
3	2.4897	2.5463	2.3765	2.2965	2.0302	2.073	2.0302
4	2.4331	2.4897	2.3765	2.2405	2.0302	2.073	2.0302
5	2.4331	2.4897	2.2965	2.1845	2.0851	2.073	2.0302
6	2.2068	2.2068	2.0165	1.9044	1.7918	1.773	1.7375
7	2.0936	2.1502	1.9605	1.8296	1.7375	1.6478	1.5249
8	2.1502	2.1502	1.885	1.7375	1.7375	1.0751	1.4563
9	2.1502	1.9605	1.8296	1.7741	1.7375	1.6827	1.5249
10	2.2634	1.6004	1.885	1.885	1.9204	1.7541	1.5775
11	2.2634	2.0165	1.9605	1.9959	1.9204	1.8267	1.5947
12	2.1285	2.0513	2.2068	2.1845	2.0513	2.0302	1.5947
13	2.1845	2.2405	2.32	2.32	2.1845	2.1068	1.7164
14	2.2634	2.2405	2.32	2.2634	2.1845	2.1068	1.8073
15	2.1285	2.2405	2.2068	2.1285	2.0513	2.0302	1.7353
16	2.0165	2.0725	2.2068	2.0165	1.8107	1.5844	1.5947
17	2.0165	2.0725	1.6324	1.9605	1.8296	1.6289	1.4752
18	2.0936	2.037	2.4331	2.0936	1.9605	1.6289	1.6478
19	2.32	2.4331	2.4331	2.1068	2.3765	2.0513	
20	2.6595	2.6595	2.7726	2.2177	2.6595	2.3285	.3326
21	2.6595	2.6029	2.6595	2.4646	2.5463	2.3285	.0514
22	2.6029	2.6029	2.6595	2.4086	2.4331	2.2731	.5944
23	2.5463	2.5463	2.4897	2.2965	2.3525	2.1622	.5498
24	2.6029	2.4714	2.5503	2.3525	2.1622	2.2177	2.009
Max	2.6595	2.6595	2.7726	2.4646	2.6595	2.3285	2.1068
Min	2.0165	1.6004	1.6324	1.7375	1.7375	1.0751	.0514
Avg	2.3249	2.2831	2.2575	2.1356	2.0767	1.9464	1.5143