Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154073 / 33/11 KV MIDC
Feeder No / Name : 201 / 11 KV CHAITANYA SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.5716	.724	.9145	.6478		.9145
2	.4572	.5335	.724	.8383	.5716	.5525	.8383
3	.4572	.5716	.724	.7621	.5335	.5525	.7621
4	.4954	.6097	.6859	.6859	.5335	.5335	.7621
5	.5335	.5335	.6859	.6478	.5716	.5716	.6859
6	.5716	.5716	.7621	.6097	.6097	.5906	.6668
7	.6097	.6668	.8002	.5716	.6859	.6287	.6478
8	.6097	.8002	.8764	.8954	.6478	1.0288	.9145
9	.6478	1.0669	.9526	1.105	.724		.9907
10	.6859	1.0669	1.0479	1.1431	.8002	1.0288	1.0669
11	.7621	1.1431	.9907	1.1812		1.105	
12	.8002	1.105	.9526	1.2193	1.0098	1.1431	
13	.9335	.7811	.9145	1.1431	.9907	1.1431	
14	.9907	1.0669	.8764	1.1812	.9526	1.1812	
15	1.105	.9907	.8573	1.1431		1.2193	
16	1.3336	1.1431	.8383	1.2003	.8002	1.1812	
17	1.2955	1.105	.7621	.9145	.6478	1.1431	
18	.9907	.9907	.7049	.8764		1.0669	
19	.362	1.0288	.724	.8002	.5335	1.0669	
20	.9145	.9907	.7621		.5716	.9907	.8002
21	.8764	.9526	.8002		.6287	.9907	.7621
22	.8002	.9526	.8573	.7621	.6287	.9907	.7621
23	.724	.9145	.9145		.6287	.9145	.8002
24	.4954	.5716	.7621	.9526	.6097	.5716	.9907
Max	**1.3336**	**1.1431**	**1.0479**	**1.2193**	**1.0098**	**1.2193**	**1.0669**
Min	**.362**	**.5335**	**.6859**	**.5716**	**.5335**	**.5335**	**.6478**
Avg	**.7478**	**.8637**	**.8208**	**.9308**	**.6823**	**.9180**	**.8243**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154073 / 33/11 KV MIDC
Feeder No / Name : 202 / 11 KV N. DATTA SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.6097	.4572	.4572	.5335	.4572	.4191
2	.4191	.5335	.4572	.4572	.5716	.4572	.4191
3	.381	.5335	.4572	.4191	.5335	.4572	.381
4	.381	.4191	.4572	.381	.4572	.4572	.381
5	.4191	.4572	.4572	.381	.4954	.4572	.381
6	.4191	.4191	.4572	.4191	.4572	.4572	.4191
7	.4572	.4572	.4572	.4191	.4191	.4572	.4191
8	.4572	.5335	.5716	.5335	.5335	.5716	.5335
9	.5335	.5335	.724	.6097	.5716	.6097	.6097
10	.5716	.8383	.8383	.9145	.6478	.7621	.6859
11	.6097	1.105	.9145	.9145	.6478	.9526	
12	.8002	1.1431	.9907		.6478	.9907	
13	.8383	.9907	1.0669	.9907	.5716	.9907	
14	.8383	1.1431	1.0669	.9526	.5335	.9907	
15	.9145	1.1431	.9907	.9145	.4954	.9907	
16	.8764	1.1431	.9907	1.105	.5335	.9907	
17	.8002	1.105	.9145	.7621	.4572	.9526	
18	.8764	.8383	.8383	.8383	.4572	.8383	
19	.8764	.7621	.7621	.8002	.4572	.7621	
20	.7621	.6859	.6859		.4572	.6859	.5716
21	.8002	.5335	.6097		.4572	.5716	.5335
22	.7621	.5335	.5335		.4572	.4572	.4572
23	.724	.4954	.5335	.5716	.4572	.4572	.5335
24	.4572	.5716	.4954	.4954	.6097	.4572	.4572
Max	**.9145**	**1.1431**	**1.0669**	**1.105**	**.6478**	**.9907**	**.6859**
Min	**.381**	**.4191**	**.4572**	**.381**	**.4191**	**.4572**	**.381**
Avg	**.6414**	**.7303**	**.6970**	**.6668**	**.5192**	**.6763**	**.4801**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154073 / 33/11 KV MIDC
Feeder No / Name : 203 / 11 KV OLD SHASHAKIYA SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5716	.4954	.4572	.4572	.4954	.4954
2	.4191	.5335	.4954	.4191	.4191	.5335	.4954
3	.4191	.5335	.4954	.4191	.381	.5335	.4572
4	.381	.5716	.4954	.381	.4572	.5335	.4572
5	.4572	.5335	.5335	.4572	.4954	.5716	.5335
6	.5335	.5335	.5335	.5335	.4572	.6097	.5335
7	.6097	.5335	.5335	.5335	.5335	.6097	.5335
8	.6097	.7621	.6097	.8383	.5335	.7621	.9145
9	.6859	.9907	.9145	.9907	.4572	.9145	.9907
10	.7621	1.0669	1.448	1.1431	.5335	1.1431	1.0669
11	.8002		1.2193	1.1812	.6097	1.4098	
12	.8383	.6097	.9907	1.2955	.6097	1.5242	
13	.9145	1.1431	.9907	1.2955	.5716	1.5242	
14	.8002	1.2193	.9907		.5335	1.3717	
15	.8764	1.2384	1.105	1.3336	.6097	1.2193	
16	1.0669	1.2193	1.105	1.3717	.5716	1.0669	
17	.9907	1.2193	1.1431	1.105	.5335	1.1431	
18		.9907	1.1431	.9145	.5335	1.1431	
19	.7621	.9526	.9907	.7621	.4954	1.1431	
20	.724	.9145	.9145		.4572	.9907	.9526
21	.6478	.6859	.6097		.4572	.8383	.7621
22	.6478	.5335	.5335	.5335	.4572	.6097	
23	.6097	.5335	.4954	.5335	.4572	.6097	
24	.4572	.5716	.4954	.4572	.4954	.4572	.5335
Max	**1.0669**	**1.2384**	**1.448**	**1.3717**	**.6097**	**1.5242**	**1.0669**
Min	**.381**	**.5335**	**.4954**	**.381**	**.381**	**.4572**	**.4572**
Avg	**.6726**	**.8027**	**.8034**	**.8074**	**.5049**	**.9066**	**.6712**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154073 / 33/11 KV MIDC
Feeder No / Name : 204 / 11 KV NEW SHASHAKIYA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2667	.2667	.2667	.3429	.3429	.3239
2	.2286	.3048	.2667	.2477	.3429	.3048	.3048
3	.2286	.3048	.2667	.2286	.3048	.3048	.2858
4	.2667	.3239	.2667	.2667	.2667	.3048	.2858
5	.2858	.3048	.2286	.2858	.2667		.2667
6	.2858	.3048	.2096	.3048	.3429	.3048	.2858
7	.3048	.3429	.2096	.3048	.3429	.381	.3048
8	.3048	.3048	.2667	.3239	.3429	.3048	.2858
9	.2858	.3048	.3048	.2858	.3429	.2667	.2667
10	.3048	.3048	.3239	.3429	.3048	.3048	.2667
11	.3048		.3429	.3429	.2858	.362	
12	.3429	.2286	.362	.362	.2858	.362	
13	.3239	.362	.362	.381	.2667	.362	
14	.3429	.381	.362		.2286	.381	
15	.3429	.381	.3429	.3429		.4001	
16	.3429	.381	.3429	.3429	.2286	.4001	
17	.2667	.381	.3239	.3429	.2667	.381	
18	.2667	.381	.3239	.3048	.2858	.3429	
19	.2667	.381	.3239		.3429	.3429	
20	.3048	.4191	.362		.381	.362	.3048
21	.3048	.381	.3429		.381	.362	.9907
22	.2858	.3429	.3429	.3239	.3429	.3429	.3429
23	.2667	.3048	.3048	.3429	.3429	.3239	.3048
24	.2477	.2667	.2667	.2858	.3429	.3429	.3239
Max	**.3429**	**.4191**	**.362**	**.381**	**.381**	**.4001**	**.9907**
Min	**.2286**	**.2286**	**.2096**	**.2286**	**.2286**	**.2667**	**.2667**
Avg	**.2889**	**.3330**	**.3048**	**.3115**	**.3123**	**.3429**	**.3429**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154073 / 33/11 KV MIDC
Feeder No / Name : 205 / 11 KV TEXTILE SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.1812	1.105	.9907	.9145		1.0669
2	.8383	1.2574	1.105	.9145	.8764	.9145	1.0669
3	.8383	.9526	1.0669	.9145	.8002	.9145	.9145
4	.8383	1.1431	1.0669	.8383	.7621	.9145	.9145
5	.9145	1.1812	1.105	.9145	.9145	.9145	1.0669
6	.9907	1.2193	1.1431	.9907	.9526	.9145	1.0669
7	1.0669	1.2193	1.2193	1.2193	.9145	.9145	1.0669
8	1.0669	1.3146	1.2955	1.3717	1.0669	.9907	1.2955
9	1.1431	1.4098	1.448	1.3717	1.1431	1.2193	1.3717
10	1.2574	.6097	1.829	1.1241	1.1812	1.3336	1.5242
11	1.3336	1.829	1.9814	1.6766	1.2193	1.6194	
12	1.3717	1.2193	2.1338	1.829	1.2193	1.829	
13	1.5242	1.6766	2.1338	1.7147	1.1431	1.9814	
14	1.5623	1.829	1.9814	1.7147	1.105	1.9433	
15	1.6766	2.1338	1.9814	1.8671	.9526	1.829	
16	1.829	2.0195	1.6766		.9145	1.829	
17	1.5242	1.829	1.6766	1.5623	.9145	1.7909	
18	1.3717	1.6766	1.6766	1.6766	.9145	1.5242	
19	1.2955	1.5242	1.3717	1.7528	.9526	1.5242	
20	1.3336	1.448	1.2955		.9526	1.3717	1.3336
21	1.105	1.2955	1.2193		.9526	1.3717	.9907
22	.9526	1.2193	1.2193	1.0669	1.0288	1.3717	.9907
23	.9907	1.1812	.9907	.9907	1.0669	1.2193	.9526
24	.9145	.9526	1.1812	.9907	.9526	.9907	1.2193
Max	**1.829**	**2.1338**	**2.1338**	**1.8671**	**1.2193**	**1.9814**	**1.5242**
Min	**.8383**	**.6097**	**.9907**	**.8383**	**.7621**	**.9145**	**.9145**
Avg	**1.1939**	**1.3884**	**1.4543**	**1.3091**	**.9923**	**1.3577**	**1.1228**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154073 / 33/11 KV MIDC
Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2481	2.2481	2.2481	2.6673	2.6673	2.2862	1.9052
2	2.191	1.7528	2.0957	2.5911	2.5911	2.2481	1.9052
3	2.1338	2.2481	2.0957	2.5149	2.8197	2.0957	1.8671
4	2.0957	2.3434	2.1338	2.4768	2.5149	2.1338	1.829
5	2.0576	2.3434	2.21	2.553	2.8197	2.0957	1.8671
6	2.0005	2.3243	2.2481	2.572	2.6292	2.0957	
7	1.9433	2.0957	2.21	2.3243	2.3243	2.0957	1.9052
8	1.9052	1.9052	1.1431	2.2862	2.2862	2.0576	1.8671
9	1.8671	1.9433	1.0288	2.2291	2.2481	2.0005	1.848
10	1.9433	2.2862	.8192	2.3815	2.3624	1.9052	1.829
11	2.3243		2.8959	2.7054	2.5911	1.848	
12	2.5911	2.2672	3.2769	2.4387	2.6673	1.848	
13	2.6673	3.0864	3.2007	2.5149	2.553	3.7342	
14	2.8959	3.1245	3.2388		2.4768	1.9052	
15	2.8959	3.1436	.0191	3.2388	2.4387	1.9433	
16	3.0102	3.0483	3.315	3.2007	2.4387	1.9814	
17	3.0864	3.2007	3.2388	3.315	2.3624	1.9052	
18	3.2579	3.1626	3.0864	3.4294	2.3624	1.8671	
19	3.2769		3.4294		2.7816	2.2862	
20	3.4294	3.3532	3.5056		2.8959	2.4006	3.4675
21	3.0483	3.1245	3.4865		2.8578	2.4768	
22	2.8959	3.0102	3.3722	2.7816	2.8197	1.9624	3.2769
23	2.6673	2.7816	3.1436	2.7816	2.6673	1.9433	2.7244
24	2.2862	2.1338	2.2862	2.7054	2.7054	2.5149	3.5818
Max	**3.4294**	**3.3532**	**3.5056**	**3.4294**	**2.8959**	**3.7342**	**3.5818**
Min	**1.8671**	**1.7528**	**.0191**	**2.2291**	**2.2481**	**1.848**	**1.829**
Avg	**2.5299**	**2.5876**	**2.4887**	**2.6854**	**2.5784**	**2.1513**	**2.2980**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154075 / 33/11 KV ARVI
Feeder No / Name : 201 / 11 KV MEDICAL **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0074		.0074				
8	.0074	.0092					.0074
9							.0074
16	.0091		.0073				
18	.0089					.0074	
20			.011				
21						.0092	
23	.0092					.0093	
24	.0074	.0075	.0092	.0093	.0092	.0092	.0093
Max	**.0092**	**.0092**	**.011**	**.0093**	**.0092**	**.0093**	**.0093**
Min	**.0074**	**.0075**	**.0073**	**.0093**	**.0092**	**.0074**	**.0074**
Avg	**.0082**	**.0084**	**.0087**	**.0093**	**.0092**	**.0088**	**.0080**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154075 / 33/11 KV ARVI
Feeder No / Name : 202 / 11 KV DWARAKA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0259		.0277				
8	.0259	.0259					.024
9							.024
16	.0296		.0333				
18	.029					.0296	
20			.0366				
21						.0351	
23	.0333					.0355	
24	.0296	.0317	.0333	.0355	.0351	.0351	.0355
Max	**.0333**	**.0317**	**.0366**	**.0355**	**.0351**	**.0355**	**.0355**
Min	**.0259**	**.0259**	**.0277**	**.0355**	**.0351**	**.0296**	**.024**
Avg	**.0289**	**.0288**	**.0327**	**.0355**	**.0351**	**.0338**	**.0278**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154075 / 33/11 KV ARVI
Feeder No / Name : 204 / 11 KV SWAMI SAMARTH SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.924		.9055				
8	.924	.7762					.7947
9							.7762
16	.7499		.8501				
18	.8145					.8131	
19		1.1088					
20			1.1157				
21						1.1763	
23	1.0811					1.1203	
24	.924	1.0456	1.0719	1.0642	1.0903		1.1016
Max	**1.0811**	**1.1088**	**1.1157**	**1.0642**	**1.0903**	**1.1763**	**1.1016**
Min	**.7499**	**.7762**	**.8501**	**1.0642**	**1.0903**	**.8131**	**.7762**
Avg	**.9029**	**.9769**	**.9858**	**1.0642**	**1.0903**	**1.0366**	**.8908**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154075 / 33/11 KV ARVI
Feeder No / Name : 205 / 11 KV SIDDESHWAR MANDIR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.3795		.3673	.41	.455	.4268
2	.3772	.2683		.3643	.3704	.4222	.4031
3	.3788	.2568		.3094	.3597	.413	.3795
4	.3963	.2583		.2782	.3582	.4047	.3948
5	.3925	.2644		.2812	.3513	.4031	.3605
6	.3711	.2774		.2751	.3513	.407	.3643
7	.4329	.3628	.0069	.3963	.4291	.4854	.4268
8	.5101	.3987		.4687	.4603	.554	.5571
9	.5235	.4123		.4603	.4451	.5449	.4344
10	.57	.4633		.5235	.5517	.5136	.5114
11	.5738	.5456		.5708	.5548	.5632	.5959
12	.5754	.4557		.5769	.5891	.5548	.6318
13	.5746	.4786		.6417	.5944	.6089	.5243
14	.5807	.5365		.5891	.6859	.6066	.5929
15	.5373	.5098		.5769	.6828	.5998	.6554
16	.5767	.5205	.012	.6683	.6546	.6097	.6653
17	.6676	.6409		.6752	.6904	.6478	.6142
18	.6568	.6752		.7072	.7133	.6997	.5662
19	.6036	.631		.7392	.6981	.6683	.6097
20	.4954	.5807	.0072	.6028	.6196	.4786	.5868
21	.4252	.4313		.4664	.5807	.4159	.4954
22	.4611	.4557		.487	.5304	.4801	.5075
23	.4253	.4268		.4687	.5388	.5019	.4854
24	.4005	.3858	.0072	.432	.4876	.4659	.4957
Max	**.6676**	**.6752**	**.012**	**.7392**	**.7133**	**.6997**	**.6653**
Min	**.3711**	**.2568**	**.0069**	**.2751**	**.3513**	**.4031**	**.3605**
Avg	**.4958**	**.4423**	**.0083**	**.4969**	**.5295**	**.5210**	**.5119**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154077 / 33/11 KV KOLPA
Feeder No / Name : 204 / 11 KV URBAN/SOS SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2606	.2911	.2881	.2957	.3163	.3147
2	.2515	.2759	.2766	.2888	.3064	.3025
3	.2492	.2713	.266	.285	.3109	.2865
4	.2378	.2644	.2606	.2827	.3094	.2835
5	.2423	.2629	.2606	.282	.3117	.2919
6	.2736	.2972	.2728	.3033	.3521	.3125
7	.3719	.3551	.3589	.3986	.3719	.365
8	.3589	.4283	.3765	.3932	.4039	.407
9	.3666	.407	.381	.3864	.3727	.3628
10	.3452	.4763	.4618	.3704	.3574	.365
11	.1128	.4984	.4618	.3963	.4191	.4512
12	.4893	.4778	.4656	.3719	.5304	.4542
13	.4405	.4816	.5167	.3795	.5152	.426
14	.4222	.4405	.4778	.3544	.4351	.3612
15	.4123	.4382	.4283	.3277	.4321	.3521
16	.4649	.4641	.4489	.3559	.4351	.4176
17	.5258	.4755	.4976	.3833	.4557	.442
18	.6036	.4931	.4748	.4054	.4252	.4725
19	.365	.4771	.4367	.4039	.4542	.4435
20	.4367	.4649	.4298	.4252	.4435	.4298
21	.4138	.4214	.4001	.4237	.4207	.4199
22	.3483	.3948	.3894	.3887	.3955	.3871
23	.3429	.3803	.3521	.3772	.3749	.3833
24	.3323	.3498	.3285	.3406	.3452	.3384
Max	**.6036**	**.4984**	**.5167**	**.4252**	**.5304**	**.4725**
Min	**.1128**	**.2629**	**.2606**	**.282**	**.3064**	**.2835**
Avg	**.3612**	**.3995**	**.3880**	**.3592**	**.3956**	**.3779**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154116 / 33/11 KV OPH S/S
Feeder No / Name : 201 / 11 KV Vivekanand Chowk SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.166	1.1317		1.1145	1.2003
2			1.1317	1.1317		1.0974	1.2003
3			1.1317	1.1317		1.0974	1.2003
4			1.0974	1.0974		1.0631	1.166
5			1.0974	1.0974		1.0802	1.0974
6			1.0631	1.0631		1.0631	
7		1.1317	1.0631	1.0631		1.0631	1.0288
8	1.0117	***	.9945	1.0974		1.0117	1.0456
9	.9431	.9602		1.1222	.9259	1.0082	1.0456
10	.8573	.8916		1.0288	.9259	.8962	
11	.823	.8916		.9431	.8573	.8962	
12	.8573	.8573		.8916	.823	.9335	
13	.8573	.8916		.9259	.7716	.9709	
14	.8745			.9088	.823		
15	.8916			.9774	.823		
16	.9709	.8916		.9593	.9259	.9709	1.0269
17		.9602			.9945	.9259	
18		.9259			1.0117	.1029	
19		1.0631			1.1145	1.2003	
20		1.3375			1.2346	1.3375	
21		1.3375			1.2003	1.2689	
22		1.3032			1.2003	1.2003	
23	1.1203	1.2689			1.1831	1.166	1.4003
24	1.0317	1.1203	1.166	1.2437	1.2127	1.2127	1.0288
Max	**1.1203**	**10.3224**	**1.166**	**1.2437**	**1.2346**	**1.3375**	**1.4003**
Min	**.823**	**.8573**	**.9945**	**.8916**	**.7716**	**.1029**	**1.0269**
Avg	**.9308**	**1.6347**	**1.1012**	**1.0479**	**1.0017**	**1.0310**	**1.1309**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154116 / 33/11 KV OPH S/S
Feeder No / Name : 203 / 11 KV Gandhi Chowk SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2003			1.1488	1.1317
2			1.1317	1.1317		1.1145	1.1317
3			1.1317	1.1317		1.0288	1.0288
4			1.1317	1.0631		1.0288	1.0288
5			1.0974	.7835		1.046	.9945
6			1.0288			1.0117	.9945
7		1.1203	1.0288	.9945		1.0117	.9602
8	1.0802		1.0631	1.0288		1.046	1.1317
9	1.1145			1.4918	1.0117	1.4563	1.2696
10	1.5432			1.7194	1.0631	1.4563	
11	1.9204			1.8861	1.4918		
12	1.9719			2.0233	1.6289		
13	1.9719			2.0233	1.6632	2.2405	
14	2.0576			2.0576	1.6289	2.2405	
15	2.0576			2.0919	1.5089	2.2405	
16	2.2405	2.1948		2.1605	1.5089	2.2405	2.2779
17		2.2977			1.406	1.989	
18		2.2634			1.3546	2.2634	
19		2.4006			1.4575	2.5377	
20		2.6749			1.5775	2.3663	
21		2.2634			1.4918	2.1605	
22		1.8004			1.3032	2.0576	
23	1.3717	1.3032			1.1831	1.749	1.4563
24	1.086	1.307	1.2003	1.2003	1.2489	1.2127	1.2003
Max	**2.2405**	**2.6749**	**1.2003**	**2.1605**	**1.6632**	**2.5377**	**2.2779**
Min	**1.0802**	**1.1203**	**1.0288**	**.7835**	**1.0117**	**1.0117**	**.9602**
Avg	**1.6741**	**1.9626**	**1.1126**	**1.5192**	**1.408**	**1.6658**	**1.2172**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154116 / 33/11 KV OPH S/S
Feeder No / Name : 204 / 11 kV Subhash Chowk SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859			.6687	.6859
2			.6516	.6859		.5487	.6859
3			.6516	.583		.5487	.6516
4			.6173	.5487		.5144	.6516
5			.6173	.5144		.5144	.583
6			.5487	.5144		.4973	.5487
7		.5601	.5487	.5487		.4973	.5487
8	.5316		.5487	.583		.5316	.583
9	.6859			.7716	.6859	.7095	.7095
10	.8573			.9088	.7202		
11	1.1145			1.0802	.823	.8962	
12	1.1145			1.286	.9088	1.0456	
13	1.2003			1.3375	.9945	1.3817	
14	1.286			1.3889	.9945	1.3817	
15	1.286			1.3889	.9774	1.3443	
16	1.4003	1.3032		1.4232	1.0117	1.4937	1.4003
17		1.4746			1.0117	1.406	
18		1.406			1.0117	1.4746	
19		1.5432			1.0288	1.6118	
20		1.5775			1.046	1.4746	
21		1.4403			.9945	1.4746	
22		1.0288			.823	1.3717	
23	1.307	.7888			.7373	1.3032	.8029
24	.6335	1.1203	.6859	.7202	.7421	.7059	.7545
Max	**1.4003**	**1.5775**	**.6859**	**1.4232**	**1.046**	**1.6118**	**1.4003**
Min	**.5316**	**.5601**	**.5487**	**.5144**	**.6859**	**.4973**	**.5487**
Avg	**1.0379**	**1.2243**	**.6173**	**.8927**	**.9069**	**1.0172**	**.7171**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154116 / 33/11 KV OPH S/S
Feeder No / Name : 205 / 11 KV Hattenagar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9259	.9774		.9602	.9259
2			.9259	.8916		.9431	.9259
3			.9259	.9774		.9431	.9259
4			.8916	.9602		.8745	.8573
5			.8916	.9602		.8916	.8573
6			.8916	.9602		.823	.8573
7		.9335	.8916	.9602		.7716	.8916
8	.7716		.7202	.9431		.7716	.7545
9	.7202			.8573	.823		.7468
10	.6859			.7202	.823		
11	.6859			.703	.8059	.8215	
12	.6859			.7202	.7716	.8215	
13	.6859			.7202	.7716	.8215	
14	.703			.7545	.7716	.8215	
15	1.286			.7716	.7716	.7842	
16	.7842	.7202		.8059	.823		.8402
17		.823			.8059	.7545	
18		.7888			.8059	.8573	
19		.9602			.9431	.9602	
20		1.0631			.9774	1.0631	
21		1.0631			.9774	.9945	
22		1.0288			.9602	.8916	
23	.8402	.9945			.9602	.7545	
24	.8869	.8402	.9259	1.0425	1.0317	1.0136	.8402
Max	**1.286**	**1.0631**	**.9259**	**1.0425**	**1.0317**	**1.0631**	**.9259**
Min	**.6859**	**.7202**	**.7202**	**.703**	**.7716**	**.7545**	**.7468**
Avg	**.7942**	**.9215**	**.8878**	**.8662**	**.8639**	**.8732**	**.8566**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 154116 / 33/11 KV OPH S/S
Feeder No / Name : 206 / 11 KV SALE GALLI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7545	.7202		.7716	.7888
2			.7545	.7202		.7373	.7888
3			.7202	.7202		.7373	.7888
4			.7202	.6859		.7716	.7545
5			.7545	.6859		.7545	.7545
6			.823	.6859		.7373	.7545
7		.9335	.8573	.703		.7373	.7202
8	.6001		.8916	.7202		.7373	.7888
9	.6001			.6859	.7545	.7468	.8589
10	.5658			.6687	.6859		
11	.5658			.6344	.6859	.7468	
12	.6001			.6516	.6516	.7468	
13	.6001			.6516	.6344	.7468	
14	.6001			.6344	.6687	.7468	
15	.6001			.6173	.6687		
16	.6535			.6344	.6859		.7468
17		.7202			.703	.6173	
18		.6859			.703	.6859	
19		.8573			.8402	.8916	
20		.9259			.8916	.9602	
21		.9259			.8573	.9431	
22		.8573			.823	.8573	
23		.823			.7888	.7888	.8402
24	.703	.5487	.7545	.8413	.8326	.8145	.7468
Max	**.703**	**.9335**	**.8916**	**.8413**	**.8916**	**.9602**	**.8589**
Min	**.5658**	**.5487**	**.7202**	**.6173**	**.6344**	**.6173**	**.7202**
Avg	**.6089**	**.8086**	**.7811**	**.6859**	**.7422**	**.7751**	**.7776**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 157004 / 132 KV S/S MIDC
Feeder No / Name : 201 / 11 KV MAROTI FERTOCHEM SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17
HR	Load (MW)
9	.8764
12	.9526
15	.9717
Max	.9717
Min	.8764
Avg	.9336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 157004 / 132 KV S/S MIDC
Feeder No / Name : 206 / 11 KV KIRTI GOLD **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.804	1.2041	1.5356	1.5508	1.4746	1.1546
2	.8269	1.2422	1.5356	1.5585	1.5585	1.1431
3	.945	1.2536	1.5318	1.5927	1.5242	1.1241
4	.9374	1.2231	1.5508	1.6004	1.5165	1.0974
5	.9107	1.1888	1.608	1.608	1.528	1.0822
6	.7888	1.1965	1.5775	1.6156	1.5432	1.1469
7	.7888	1.2079	1.6651	1.5889	1.5775	1.166
8	.8116	1.246	1.749	1.5737	1.5813	1.2117
9	1.7489	1.1774	1.6766	1.5623	1.5737	1.1431
10	.9183	1.2003	1.6918	1.6537	1.2574	1.3641
11	.9297	1.2689	1.688	1.6804	1.185	1.3679
12	2.1567	1.3108	1.7414	1.7909	1.2117	1.4441
13	1.1698	1.307	1.8671	1.7909	1.166	1.4784
14	1.2117	1.3375	1.8595	1.8404	1.2498	1.4213
15	2.3777	1.2803	1.8138	1.5242	1.4822	1.4137
16	1.3489	1.2651	1.8633	1.7566	1.5089	1.4098
17	1.2727	1.2727	1.848	1.7528	1.5699	1.4556
18	1.2079	1.3451	1.7642	1.749	1.6613	1.4175
19	1.166	1.1279	1.5623	1.5585	1.4746	1.3375
20	.8116	.8154	1.3298	1.2955	.945	1.2917
21	.7888	.8078	1.2917	1.2155	.8802	1.2765
22	.7583	.7811	1.2993	1.1774	.8383	1.3032
23	1.0669	1.0136	1.467	1.2879	.9678	1.326
24	1.1622	1.0631	1.528	1.3794	1.0707	1.307
Max	**2.3777**	**1.3451**	**1.8671**	**1.8404**	**1.6613**	**1.4784**
Min	**.7583**	**.7811**	**1.2917**	**1.1774**	**.8383**	**1.0822**
Avg	**1.1212**	**1.1723**	**1.6269**	**1.571**	**1.3478**	**1.2868**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 157004 / 132 KV S/S MIDC
Feeder No / Name : 401 / 33 KV MIDC FEEDER SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.4321	18.2442	18.7929	19.273	16.1866	18.9301
2	14.8834	17.5583	17.6269	17.7641	15.6379	16.5981
3	14.4719	17.0096	16.7353	16.3923	14.952	16.2552
4	14.129	16.0494	15.6379	15.8436	14.6091	15.8436
5	13.9232	15.3635	15.1578	15.5007	14.4033	15.5007
6	14.129	14.7462	15.5693	15.5693	14.3347	15.4321
7	14.3347	15.1578	15.7751	15.3635	15.2264	15.3635
8	14.3347	15.9808	16.1866	15.0892	14.8834	15.2264
9	22.2451	16.3923	17.4897	15.0206	14.7462	16.5981
10	20.6447	21.0563	21.6736	16.7353	20.7133	21.605
11	23.8683	24.0055	25.7202	17.6955	24.9657	23.7312
12	***	13.9232	26.9548	18.7243	26.8176	25.0343
13	27.0234	26.5432	28.6694	20.1646	27.7092	26.3375
14	25.4459	27.5721	26.9548	19.6845	27.7778	25.4459
15	***	27.2977	13.2373	19.4102	26.6804	26.0631
16	27.4349	28.8752	28.3951	19.5474	28.3951	27.3663
17	28.0522	29.2867	29.3553	18.8615	28.8066	27.4349
18	27.0919	27.4349	25.4459	17.4897	28.5323	26.6118
19	25.4459	26.0631	26.2003	16.7353	26.0631	25.7202
20	24.4856	25.3773	26.4061	18.6557	26.2689	26.2689
21	24.1427	24.417	25.2401	18.5185	24.2799	25.0343
22	22.771	22.8395	23.0453	18.3128	22.8395	22.2908
23	20.7133	20.7819	21.5364	17.4211	21.262	11.3855
24	19.273	19.6159	20.1646	17.0782	20.3704	17.284
Max	**30.7842**	**29.2867**	**29.3553**	**20.1646**	**28.8066**	**27.4349**
Min	**13.9232**	**13.9232**	**13.2373**	**15.0206**	**14.3347**	**11.3855**
Avg	**21.4816**	**21.3163**	**21.5821**	**17.5355**	**21.5192**	**20.9734**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 157004 / 132 KV S/S MIDC
Feeder No / Name : 402 / 33 KV MEDICAL COLLEGE FEEDER Feeder KV- 33 / INCOMING **SHEDDABLE URBAN**

DATE	29-MAR-17
HR	Load (MW)
9	5.8871
12	5.8299
15	5.6584
Max	**5.8871**
Min	**5.6584**
Avg	**5.7918**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D[419] BU 5118
Substation No/ Name :- 157004 / 132 KV S/S MIDC
Feeder No / Name : 404 / 33 KV ADM AGRO. INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17
HR	Load (MW)
9	2.0576
12	1.9433
15	2.2862
Max	**2.2862**
Min	**1.9433**
Avg	**2.0957**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154013 / 33/11 KV HARANGUL
Feeder No / Name : 202 / 11KV MIDC SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3561	.4409	.4641	.3856	.6097	.6036
2	.3856	.373	.5087	.503	.4527	.5716	.5847
3	.4694	.3856	.57	.57	.5365	.6478	.6413
4	.503	.4024	.6706	.6299	.5868	.7167	.7167
5	.5801	.4862	.7625	.6706	.6203	.7545	.811
6	.6464	.663	.8288	.7291	.6464	.8676	.9054
7	.8288	.852	.852	.8478	.8288	.9431	.9242
8	.7625	.8619	.9175	.8551	.7209	.6979	.6979
9	.7712	.8048	.8215	.788	.788	.5847	.6224
10	.547	.5093	.5847	.5093	.6224	.5365	.503
11	.4904	.5281	.6413	.5093	.6224		.5801
12	.4904	.5281	.5658	.5281	.5093	.6874	.6464
13	.4527	.5093	.5847	.4527	.5658	.7625	.5868
14	.4715		.4527		.6036	.7459	.5868
15	.4527		.4904	.5658	.5847	.8048	.5967
16	.4904		.4715	.6036	.5847	.8951	.663
17	.4527		.6036	.5658	.5658	.8619	
18	.5281	.6036	.6413	.5847	.547	.5281	
19	.7922	.7922	.8488	.811	.7167	.7922	
20	.9054	1.0374	.8488	.9242	.9242	.9242	.8488
21	.8676	.9431	.8676	.811	.8299	.8676	.8865
22	.811	.8764	.811	.811	.7621	.8299	.8299
23	.7621	.7621	.7167	.7167	.7049	.7922	.7356
24	.3052	.3429	.3772	.4144	.3521	.6668	.6602
Max	**.9054**	**1.0374**	**.9175**	**.9242**	**.9242**	**.9431**	**.9242**
Min	**.3052**	**.3429**	**.3772**	**.4144**	**.3521**	**.5281**	**.503**
Avg	**.5876**	**.6309**	**.6616**	**.6463**	**.6276**	**.7430**	**.6967**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] **BU 5126**
Substation No/ Name :- 154013 / 33/11 KV HARANGUL
Feeder No / Name : 203 / 11KV NANDGAON FEEDER **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6859	.6859	.7167	.679	1.0608	1.0059
2	.679	.6859	.6859	.7545	.7167	1.1603	1.073
3	.7922	.7049	.7621	.8676	.7545	1.2597	1.1768
4	.8676	.724	.8299	.9431	.8299	1.3763	1.2431
5	.9431	.9054	.8676	.9808	.9431	1.4746	1.3592
6	1.0751	1.094	.9431	1.1128	.9997	1.5729	1.5083
7	.8865	.9431	.9808	1.0185	.9431	1.6549	1.7901
8	.8676	.811	.811	.7733	.811	1.6876	1.8679
9	.5658	.547	.6036	.547	.679	1.5746	1.7695
10	1.1065	1.1568	1.1568	1.2071	1.326	.4527	.4904
11	1.1105	1.5746	1.5074	1.4754	1.704	.5281	.4527
12	1.6078		1.5074	1.6409	1.6385	.5281	.4527
13	1.5581	1.3592	1.5415		1.6575	.415	.415
14	1.4918	1.1736	1.4918	1.4918	1.5912	.4338	.4527
15	1.4255	1.326	1.4586	1.5912	1.5592	.415	.4715
16	1.5893	1.5238	1.5729	1.7532	1.7204	.4527	.4338
17	1.1736	1.6549	1.6575	1.7939	1.7859	.415	
18	.4854	.4715	.4338	.4904	.415	.4904	
19	.8676	.7545	.8488	.9054	.7167	.7922	
20	.9808	.9808	.9054	.9431	.9997	.9997	.9808
21	.8865	.9054	.9242	.9242	.9431	.9619	.9431
22	.8299	.8383	.8488	.8676	.8764	.8488	.7733
23	.7621	.7621	.7545	.7922	.8192	.7545	1.0185
24	.6979	.6859	.724	.7167	.7356	.9389	.8886
Max	**1.6078**	**1.6549**	**1.6575**	**1.7939**	**1.7859**	**1.6876**	**1.8679**
Min	**.4854**	**.4715**	**.4338**	**.4904**	**.415**	**.415**	**.415**
Avg	**.9963**	**.9682**	**1.0210**	**1.0568**	**1.0769**	**.9270**	**.9794**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154013 / 33/11 KV HARANGUL
Feeder No / Name : 204 / 11KV NAGZARI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6962	.7042	.8048	.8848	.8718	.1905	.2263
2	.6962	.7293	.8951	.9116	.9221	.1905	.2263
3	.7459	.7625	.9945	.9448	.9724	.2286	.2641
4	.7956	.7865	1.0486	.9503	.9945	.2263	.2641
5	.8192	.8192	1.1797	.9945	1.0277	.2641	.3018
6	.9012	.9393	1.2955	1.1271	1.0774	.2641	.3395
7	1.3272	1.3765	1.3765	1.576	1.3923	.2641	.3206
8	1.4746	1.4746	.5243	1.5746	1.4586	.2641	.2829
9	1.4255	1.4746	1.3923	1.4918	1.491	.1886	.1886
10	.1698	.1698	.1886	.2263	.1867	1.0227	1.0322
11	.1698	.1509	.1886	.2263	.1886		1.4746
12	.1698	.2075	.1886	.2263	.1886	1.2597	1.5249
13	.1698	.1886	.1132	.2263	.1886	1.5238	1.4918
14	.1886	.1886	.2263	.2075	.2075	1.5238	1.4091
15	.1886	.1886	.1698	.2075	.2075	1.4586	1.4586
16	.1886	.1886	.2075		.1886	1.6385	1.4918
17	.1886	.1698	.1886	.2641	.2263	1.6244	
18	.1886	.1886	.1886	.2452	.2263	.2263	
19	.3395	.2641	.3584	.3206	.2641	.3018	
20	.3584	.3395	.3395	.3772	.3395	.3772	
21	.3395	.3395	.3206	.3395	.3395	.3772	
22	.3395	.3048	.3772	.3584	.3239	.3395	
23	.3239	.3048	.3206	.3206	.3239	.3018	
24	.6706	.6706	.7545	.8192	.8215	.2858	.2829
Max	**1.4746**	**1.4746**	**1.3923**	**1.576**	**1.491**	**1.6385**	**1.5249**
Min	**.1698**	**.1509**	**.1132**	**.2075**	**.1867**	**.1886**	**.1886**
Avg	**.5365**	**.5388**	**.5684**	**.6444**	**.6012**	**.6236**	**.7400**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] **BU 5126**
Substation No/ Name :- 154013 / 33/11 KV HARANGUL
Feeder No / Name : 205 / Rajeshwari Feeder **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(NON-CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0018	.0018	.0018	.0018	.0018	.0018	.0018
2	.0018	.0018	.0018	.0018	.0018	.0018	.0018
3	.0018	.0018	.0018	.0018	.0018	.0018	.0018
4	.0018	.0018	.0018	.0018	.0018	.0018	.0018
5	.0018	.0018	.0018	.0018	.0018	.0018	.0018
6	.0018	.0018	.0018	.0018	.0018	.0018	.0018
7	.0018	.0018	.0018	.0018	.0018	.0018	.0018
8	.0018	.0018	.0018	.0018	.0018	.0018	.0018
9	.0018	.0018	.0018	.0018	.0018	.0018	.0018
10	.0018	.0018	.0018	.0018	.0018	.0018	.0018
11	.0018	.0018	.0018	.0018	.0018		.0018
12	.0018	.0018	.0018	.0018	.0018	.0018	.0018
13	.0018	.0018	.0018	.0018	.0018	.0018	.0018
14	.0018	.0018	.0018	.0018	.0018	.0018	.0018
15	.0018	.0018	.0018	.0018	.0018	.0018	.0018
16	.0018	.0018	.0018	.0018	.0018	.0018	.0018
17	.0018	.0018	.0018	.0018	.0018	.0018	
18	.0018	.0018	.0018	.0018	.0018	.0018	
19	.0018	.0018	.0018	.0018	.0018	.0018	
20	.0018	.0018	.0018	.0018	.0018	.0018	
21	.0018	.0018	.0018	.0018	.0018	.0018	
22	.0018	.0018	.0018	.0018	.0018	.0018	
23	.0018	.0018	.0018	.0018	.0018	.0018	
24	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Max	**.0018**	**.0018**	**.0018**	**.0018**	**.0018**	**.0018**	**.0018**
Min	**.0018**	**.0018**	**.0018**	**.0018**	**.0018**	**.0018**	**.0018**
Avg	**.0018**	**.0018**	**.0018**	**.0018**	**.0018**	**.0018**	**.0018**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154013 / 33/11 KV HARANGUL
Feeder No / Name : 206 / harangul SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.5087	.6173	.6371	.6371	.4954	.4763
2	.7545	.5365	.6859	.6706	.7042	.5716	.5335
3	.8048	.5868	.8139	.7459	.8048	.6478	.6668
4	.8718	.6299	1.0174	.8383	.8288	.7621	.7621
5	1.0111	.788	1.1065	.8987	.9614	.9145	.9145
6	1.1105	1.0174	1.2071	1.0117	1.0774	1.0288	.9717
7	1.3426	1.286	1.2717	1.3546	1.3763	1.086	.9907
8	1.326	1.2209	1.2548	1.3413	1.4255	.9526	.9907
9	1.21	1.1401	1.1768	1.1568	1.291	.7811	.724
10	.5716	.6097	.5716	.5335	.5716	.4748	.8288
11	.5716	.4954	.4191	.4191	.4763		1.094
12	.4001	.4572	.381	.3429	.4191	.8383	1.0814
13	.381	.4191	.381	.381	.4191	.9389	.2515
14	.381	.4001	.381	.4191	.4191	.788	.9282
15	.362	.381	.4001	.4191	.4001	.9389	1.0774
16	.4001	.4382	.362	.4001	.4382	1.1105	1.1797
17	.381	.4001	.362		.4572	1.2431	
18	.5335	.4572	.4954	.5906	.4954	.5335	
19	.724	.6859	.7621	.743	.6478	.7811	
20	.7621	.7811	.724	.8573	.8954	.8192	
21	.7049	.6859	.7049	.743	.7621	.724	.743
22	.6287	.6097	.6097	.6287	.6478	.6478	.6287
23	.5716	.5335	.5335	.5335	.5335	.5906	.5525
24	.5365	.5087	.5426	.5304	.5868	.5144	.5144
Max	**1.3426**	**1.286**	**1.2717**	**1.3546**	**1.4255**	**1.2431**	**1.1797**
Min	**.362**	**.381**	**.362**	**.3429**	**.4001**	**.4748**	**.2515**
Avg	**.7088**	**.6490**	**.6992**	**.7042**	**.7198**	**.7906**	**.7955**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] **BU 5126**
Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR
Feeder No / Name : 201 / 11KV BHADI **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1962	.1524		.1619	.1619	.3048	.381
2	.1962	.1791		.1619	.2381	.3048	.381
3	.2134	.0762		.1962	.2553	.3048	.381
4	.3067	.0762		.1962	.2724	.3048	.7411
5	.3239	.1524		.2134	.3067	.381	.4572
6	.4687	.2286	.3086	.5544	.5201	.4572	.5335
7	.5963	.6896		.381	.5791	.6097	.6859
8	.5449	.3048		.6134	.5449	.6097	1.2517
9	.5277	.2286		.4001	.4001	.6097	.6097
10	.5887	.2286	.4973	.6325	.1524	.7126	.7297
11	.8859	.6097	.583	1.0993	.5335	.0762	.2724
12	.8687	.5335	.5487	1.1927	.705	.1619	.0762
13	.8859	.5335	.5144	1.1413	.4572	.0762	.0762
14	.8687	.5335	.4801	1.0308	.5335	.0857	.0762
15	.8954	.5335	.4115	1.0136	.4572		.0762
16	1.0993	1.1336	.6001	1.2441	.5335	.1448	.0762
17	.6097	.6097	.6173	1.286	.6097	.0762	.0762
18	.6783	.6707	.0857	.6783	.6097	.1619	.0762
19	.1524	.1524	.1715	.2648	.0762	.1524	.0762
20	.4515	.4344	.2058	.3239	.2286	.4344	.2286
21	.2286	.2286	.1886	.3067	.2286	.2286	.2286
22	.1524	.1524	.12	.2724	.1524	.3067	.2286
23	.1524	.1524	.1029	.2724	.1524	.1524	.1524
24	.2724	.2724	.12	.2381	.1791	.4096	.3582
Max	**1.0993**	**1.1336**	**.6173**	**1.286**	**.705**	**.7126**	**1.2517**
Min	**.1524**	**.0762**	**.0857**	**.1619**	**.0762**	**.0762**	**.0762**
Avg	**.5068**	**.3695**	**.3472**	**.5781**	**.3703**	**.3072**	**.3429**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR
Feeder No / Name : 202 / 11KV MAMDAPUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401			.2058	.1886		
2	.2401	.2401		.2058	.2058		
3	.2572			.2743	.2229		
4	.2915		.2743	.3086	.2401		.1543
5	.3086			.3429	.2743		
6	.3772		.4115	.463	.4287		
7	.4287	.4458			.4115		
8	.3601			.3429			.2058
9	.3429			.2915			
10	.1543		.1715	.1715		.2401	.2572
11	.1543		.1886	.1715			.2229
12	.1543		.1715	.1543	.2058	.1886	
13	.1543		.1372	.1543			
14	.1372		.1372	.1372		.1715	
15	.1715		.1715	.1543			
16		.1715	.1715	.1886		.1715	
17			.1715	.1886			
18	.2058	.2572	.1886	.2058		.2229	
19			.3086	.3258			
20	.3772		.3601	.3944		.3601	
21			.2743	.3258			
22			.2401	.2915		.3258	
23			.4115	.2401			
24	.1886	.2401	.2401	.2058	.2229	.12	.0686
Max	**.4287**	**.4458**	**.4115**	**.463**	**.4287**	**.3601**	**.2572**
Min	**.1372**	**.1715**	**.1372**	**.1372**	**.1886**	**.12**	**.0686**
Avg	**.2524**	**.2709**	**.2370**	**.2498**	**.2667**	**.2251**	**.1818**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR
Feeder No / Name : 203 / 11KV BHADGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287			.4801	.583		
2	.4287	.583		.4801	.583	.7545	
3	.5144			.5144	.6001		
4	.5487		.7545	.5658	.6687		.2915
5	.6173			.6001	.7716		
6	.9945		1.1488	.9259	.9602		
7	1.2346	1.286			1.2689		
8	1.3889			1.2346			.4287
9	1.2517			1.1488			
10	.3601		.3086	.2915			.7716
11	.2229		.2229	.2229			1.1145
12	.2058		.2229	.1715	.2572	1.166	
13	.2229		.2229	.1886			
14			.2229	.2401		1.0802	
15	.1715		.2058	.2572			
16	.2058	.2401	.2058	.2229		1.0631	
17			.2058	.2572			
18	.2915	.3086	.2401	.2743		.2915	
19			.463	.4458			
20	.583	.5144	.5316	.5316		.583	
21			.5144	.5144			
22			.463	.4287		.4973	
23			.3772	.3772			
24	.4287	.3601	.4115	.4801	.5144	.3258	.4287
Max	**1.3889**	**1.286**	**1.1488**	**1.2346**	**1.2689**	**1.166**	**1.1145**
Min	**.1715**	**.2401**	**.2058**	**.1715**	**.2572**	**.2915**	**.2915**
Avg	**.5611**	**.5487**	**.3954**	**.4719**	**.6897**	**.7202**	**.607**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] **BU 5126**
Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR
Feeder No / Name : 204 / 11KV SOLVANT **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944			.4287	.4287		.4115
2	.4115	.3772		.4115	.3944		.4115
3	.4115			.4115	.3429		.4287
4	.3944			.4287	.2915		.4458
5	.4287			.4287	.1886		.463
6	.4115			.3944	.1715		.4458
7	.3601	.2743			.1886		.4458
8	.3429			.3258			.4458
9	.3944			.3944			.4458
10	.3944		.4115	.3944			.463
11	.4115		.4287	.463			.5316
12	.4115		.3944	.4458	.1715		
13	.4115		.5144	.3944			
14	.4115		.4973	.4287			
15	.4115		.4973	.4115			
16	.4115		.4458	.4287			
17			.463	.4115			
18	.3772			.3429			
19				.3944			
20	.3086		.4115	.3429			
21			.3944	.3601			
22			.3944	.3601			
23			.4115	.3944		.4115	
24	.4115	.3086	.3772	.4801	.4115	.1543	.4115
Max	**.4287**	**.3772**	**.5144**	**.4801**	**.4287**	**.4115**	**.5316**
Min	**.3086**	**.2743**	**.3772**	**.3258**	**.1715**	**.1543**	**.4115**
Avg	**.3953**	**.3200**	**.4340**	**.4033**	**.2877**	**.2829**	**.4458**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] **BU 5126**
Substation No/ Name :- 154033 / 33/11 KV BABHALGAON
Feeder No / Name : 204 / PTS **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(NON-CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0724		.0377	.0305	.0305	.0686
2	.0377	.0724		.0377	.0305	.0305	.0686
3	.0377	.0724		.0377	.0305	.0305	.0305
4	.0377	.0724		.0377	.0305	.0305	.0305
5	.0377	.0724		.0377	.0305	.0305	.0686
6	.0377	.0724	.0305	.0758	.0305	.0305	.0686
7	.0377	.0343	.0305	.0377		.0343	.0305
8						.0343	
9		.0758	.0343	.0343	.0377	.0343	
10		.0758	.0343	.0724	.0377	.0724	
11	.0381	.0758	.0343	.0724	.0758	.0724	
12	.0381	.0758	.0343	.0381	.0377		
13	.0381	.0758	.0343	.0724	.0377		
14	.0381	.0381	.0343	.0724	.0377		
15	.0686	.0381	.0343	.0724	.0377	.0724	
16	.0381	.0758	.0343	.0381		.0381	
17	.0724	.0686	.0377		.0686	.0381	
18	.0724	.0686	.0377		.0305	.0381	.0381
19	.0724	.0686	.0377	.0381	.0381	.0381	.0381
20	.0724	.0686	.0377	.0381	.0381	.0381	.0381
21	.0724	.0686	.0377		.0381	.0381	.0381
22	.0724	.0686	.0377		.0381	.0381	.0381
23	.0724	.0381	.0377	.0381	.0381	.0381	.0381
24	.0758	.0724		.0758	.0305	.0686	.0686
Max	**.0758**	**.0758**	**.0377**	**.0758**	**.0758**	**.0724**	**.0686**
Min	**.0377**	**.0343**	**.0305**	**.0343**	**.0305**	**.0305**	**.0305**
Avg	**.0526**	**.0662**	**.0353**	**.0508**	**.0383**	**.0417**	**.0474**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154033 / 33/11 KV BABHALGAON
Feeder No / Name : 205 / 11KV BABHALGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829	.7716		1.1203	.6859	.4115	
2	1.1949	.7716		1.2136	.6859	.4115	.381
3	1.2323	.7716		1.307	.6859	.4115	.3963
4	1.307	.8059		1.3676	.7926	.4877	.4877
5	1.307	.8916		1.4784	.8535	.5792	.5487
6	1.3256	1.286	1.0974	1.4998	.9907	.7316	.5792
7	1.531	1.4575	1.2193	1.5546		.9945	.9755
8						1.0117	
9		1.1389	1.166	.9945	1.2883	1.0631	
10		.583	.6687	.5658	.7373	.823	
11		.8259	1.0802	.7716	1.004	.7545	
12		.7611	.8402	.9088	.9069		
13		.7611	.8573	.6859	.8421		
14			.8059	.6516	.8097		
15	.6401		.7545	.7545	.7655	.7888	
16		.4696	.823				
17	.9945	.884	.7287				
18	.6516	.7316	.7842				
19	1.166	1.0974	1.0642				
20	1.2174	1.1584	1.0829				
21	1.2003	1.0364	1.1203				
22	1.046	.9602	1.1763				
23	.9431		1.0456				
24	.9522	.8573		.9522	.7621	.9145	.381
Max	**1.531**	**1.4575**	**1.2193**	**1.5546**	**1.2883**	**1.0631**	**.9755**
Min	**.6401**	**.4696**	**.6687**	**.5658**	**.6859**	**.4115**	**.381**
Avg	**1.1120**	**.9010**	**.9597**	**1.0551**	**.8436**	**.7218**	**.5356**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154033 / 33/11 KV BABHALGAON
Feeder No / Name : 206 / 11KV DHANEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.5487		.7468	.6401	1.2193	1.0974
2	.7842	.5487		.8215	.6401	1.2498	1.1431
3	.8962	.5487		.9335	.6859	1.2498	1.1431
4	.9335	.6001		1.0269	.7621	1.2498	1.1431
5	1.0082	.7202		1.0829	.8535	1.4022	1.2193
6	1.0829	1.0117	1.0212	1.1203	.9145	1.7223	1.3108
7	.9709	.5316		.8962		2.2405	1.768
8						1.1584	
9		.4668	.583	.5658	.6722	1.0517	
10		.5487	1.0364	1.0669	1.1498	.1715	
11		1.6248	1.6004	1.6156	1.6091	.1715	
12		1.4685	1.6613		1.531		
13		1.3748	1.8138	1.7375	1.4998		
14			1.5546	1.6004	1.7029		
15	1.4937		1.6461	1.448	1.7654	.3944	
16		1.829	1.6461				
17	1.2498	1.9052	1.8122		1.7528		
18	.0686	.4268	.4854		.381		
19	.6859	.6859	.7842				
20	.9088	.8383	1.0082				
21	.8573	.6859	1.0829				
22	.7202	.5792	.7468				
23	.6344		.6908				
24	.5975	.5487		.6161	.6401	.4115	.8993
Max	**1.4937**	**1.9052**	**1.8138**	**1.7375**	**1.7654**	**2.2405**	**1.768**
Min	**.0686**	**.4268**	**.4854**	**.5658**	**.381**	**.1715**	**.8993**
Avg	**.8501**	**.8746**	**1.1983**	**1.0913**	**1.0750**	**1.0533**	**1.2155**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] **BU 5126**
Substation No/ Name :- 154033 / 33/11 KV BABHALGAON
Feeder No / Name : 207 / 11KV SHELU **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7125	.6706		.8421	.8993	.1524	.1524
2	.7655	.7011		.9717	.9145	.1524	.1524
3	.9061	.7164		.9998	.9145	.1524	.1524
4	.9686	.7468		1.1248	.9907	.1524	.1524
5	1.0155	.8383		1.1717	1.0669	.1829	.1829
6	1.1092	1.0669	1.2193	1.2342	1.1431	.2286	.1981
7	1.0997	1.448		1.3279		.2401	.1829
8						.2058	
9		1.4217	1.2955	1.387	1.4217	.1372	
10		.132	.0857	.1029	.132	1.0974	
11		.0943		.2572	.132	1.2955	
12		.1509	.1372	.2915	.2263		
13		.1886	.1886	.2229	.2829		
14			.1886	.2229	.2829		
15			.3429	.2229	.3018	1.0212	
16		.9054	.2229				
17	.1372	.0762	.1886		.2896		
18	.1372	.0762	.1509		.1829		
19	.1886	.1524	.1509				
20	.2401	.1829	.1886				
21	.2229	.1524	.1886				
22	.2058	.1829	.2263				
23	.1886		.2075				
24	.6154	.6097		.7611	.7316	.1524	.1524
Max	**1.1092**	**1.448**	**1.2955**	**1.387**	**1.4217**	**1.2955**	**.1981**
Min	**.1372**	**.0762**	**.0857**	**.1029**	**.132**	**.1372**	**.1524**
Avg	**.5675**	**.5257**	**.3321**	**.7427**	**.6195**	**.3977**	**.1657**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154040 / 33/11 KV TAKALI
Feeder No / Name : 201 / TAKLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.9831				
8						.5487
10		.1677	.3018			
11		.1341				
12	.0977	.1372		.0977		
13	.0977			.0972		
14					.1629	
15	.0972				.1543	
16	.0972	.1372			.1509	
17		.1029			.1372	
18	.1631	.2229	.1619		.2012	.2561
19		.463		.4072	.4115	
20		.5788		.4887	.3978	
21	.2667			.4072	.3601	
22	.2949			.2443		
Max	**.2949**	**.9831**	**.3018**	**.4887**	**.4115**	**.5487**
Min	**.0972**	**.1029**	**.1619**	**.0972**	**.1372**	**.2561**
Avg	**.1592**	**.3252**	**.2319**	**.2904**	**.2470**	**.4024**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154040 / 33/11 KV TAKALI
Feeder No / Name : 202 / KATGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.6668				
8						1.9784
10		1.1736	1.3108			
11		2.0481				
12	2.0005	1.9524		1.8338		
13	2.0005	1.9334		1.8338		
14		1.8623			1.6617	
15	2.0005	1.917			1.8233	
16	1.9171	1.8442			1.9662	
17		1.9662			1.9334	
18	.2792	.2949	.1658		.3149	.1989
19		.6274		.5835	.5636	
20		.8029		.5835	.5596	
21	.2501			.5001	.5533	
22	.2501			.3315		
Max	**2.0005**	**2.0481**	**1.3108**	**1.8338**	**1.9662**	**1.9784**
Min	**.2501**	**.2949**	**.1658**	**.3315**	**.3149**	**.1989**
Avg	**1.2426**	**1.4241**	**.7383**	**.9444**	**1.172**	**1.0887**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154040 / 33/11 KV TAKALI
Feeder No / Name : 203 / RAMESHWAR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.3222
10		.0876	.2713			
11		.1543				
12	.0652	.1357		.0663		
13	.0652	.1296		.0663		
14		.1357			.1311	
15	.0652	.1715			.1475	
16	.0652	.1296			.1526	
17		.1457				
18	.0913	.1357	.0648		.1526	.0819
19		.3475		.2984	.2683	
20		.3944		.2984	.3239	
21	.2446			.2501	.3277	
22	.1631			.1966		
Max	**.2446**	**.3944**	**.2713**	**.2984**	**.3277**	**.3222**
Min	**.0652**	**.0876**	**.0648**	**.0663**	**.1311**	**.0819**
Avg	**.1085**	**.1788**	**.1681**	**.1960**	**.2148**	**.2021**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154040 / 33/11 KV TAKALI
Feeder No / Name : 204 / 11 KV BHOISAMUDRA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.3429
10		.2241	.2058			
12	.1572	.2103		.1715		
13		.2195		.1429		
14		.2286			.2427	
15	.1572	.1886			.2172	
16	.1715	.1886			.2172	
17		.1463			.2012	
18	.1532	.2241	.2372		.2629	.3258
19		.415		.3353	.3734	
20		.4527		.381	.4668	
21	.2667			.3048	.4668	
22	.2801			.2143		
Max	**.2801**	**.4527**	**.2372**	**.381**	**.4668**	**.3429**
Min	**.1532**	**.1463**	**.2058**	**.1429**	**.2012**	**.3258**
Avg	**.1977**	**.2498**	**.2215**	**.2583**	**.3060**	**.3344**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154040 / 33/11 KV TAKALI
Feeder No / Name : 205 / 11 KV GANJUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.7865
10		.7316	.5083			
11		.8413				
12		.6859				
13		.4458				
14					.6001	
15					.5544	
16		.6733			.6036	
17		.6878			.5898	
18	.1334	.0943	.0953		.112	.1429
19		.1991		.2858	.2279	
20		.2896		.2858	.2477	
21	.1905			.2286	.1966	
22	.1715			.1905		
Max	**.1905**	**.8413**	**.5083**	**.2858**	**.6036**	**.7865**
Min	**.1334**	**.0943**	**.0953**	**.1905**	**.112**	**.1429**
Avg	**.1651**	**.5165**	**.3018**	**.2477**	**.3915**	**.4647**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154040 / 33/11 KV TAKALI
Feeder No / Name : 206 / 11 KV JEWALI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.0566
10		.0754	.0366			
11		.0373				
12		.0381		.0572		
13		.0381		.0572		
14		.0566			.0381	
15	.0572	.0572			.0514	
16	.0572	.0381			.0543	
17		.0377			.0343	
18	.0762	.0381	.0572		.0381	
19		.0943		.1143	.0754	
20		.132		.1143	.1143	
21	.1143			.0953	.1132	
22	.0572			.0762		
Max	**.1143**	**.132**	**.0572**	**.1143**	**.1143**	**.0566**
Min	**.0572**	**.0373**	**.0366**	**.0572**	**.0343**	**.0566**
Avg	**.0724**	**.0584**	**.0469**	**.0858**	**.0649**	**.0566**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154050 / 33/11 KV BORI
Feeder No / Name : 201 / 11KV BORI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.825		.8764	.5335	.9907	1.0669
2	.2743	.8421		.8764	.5335	1.0669	1.0669
3	.2743	.8344		.945	.5335	1.0669	1.0669
4	.3772	.9793		1.0136	.5335	1.0669	1.0669
5	.5144	1.1927		1.1584	.6097	1.1431	1.1431
6	.7888	1.6956		1.5928	.8383	1.2955	1.2955
7	.7545	1.8137		1.7452	.9145	1.829	1.6766
8		1.608	.823	1.669	1.9433	2.0767	1.9052
9		.6859		.6097	.6859	3.3379	1.6004
10		.8916	.8916	.6097	.6097	2.1719	1.448
11		3.1017	1.5089	1.6004	1.5242	.7315	.4572
12		3.4751	1.5089	1.7528	1.6004	.6553	.381
13		3.4065	1.5775	1.829	1.6766	.5868	.381
14		3.3379	1.6461	1.829	1.6766	.5868	.381
15	1.5775	3.3303	1.5775	1.7528	1.6766	.5525	.381
16	1.5775	3.2617	1.5089	1.829	.8383	.381	.381
17	1.5432	1.7528	1.7147	1.9052		.381	.381
18	.2743	1.7528	.3086	1.829	1.1431	.381	.381
19	.6516	.5335	.5487	.6097	.6097	.5335	.5335
20	.7545	.8383	.6173	.9145	.8383	.8383	1.4556
21	.583	.8383	.0062	.9145	.8383	.8383	1.3794
22	.5144	1.0288	.4801	.6859	.6859	.6859	1.3108
23	.4458	.6097	.4115	.6859	.6097	.6859	.9602
24	.3086	.8593	.3429	1.0212	.9526	1.227	.6097
Max	**1.5775**	**3.4751**	**1.7147**	**1.9052**	**1.9433**	**3.3379**	**1.9052**
Min	**.2743**	**.5335**	**.0062**	**.6097**	**.5335**	**.381**	**.381**
Avg	**.6758**	**1.6456**	**.9670**	**1.2606**	**.9742**	**1.0463**	**.9462**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154050 / 33/11 KV BORI
Feeder No / Name : 202 / 11KV MUSHIRABAD SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715		.2058			
2	.1715	.1715		.1715			
3	.1715	.2058		.1715			
4	.2058	.2401		.2058			
5	.2572	.2743		.2743			
6	.6173	.5144		.5487			
7	.583	.5487	.6173	.6173		.9145	
8	.5487	.4973			.6173		
9		.4115				.6859	
10		.4801	.5658			.2743	
11		.6173	.7545			.2058	
12		.6859	.6859			.2058	
13		.6859	.7545			.1715	
14			.6859			.1715	
15	.7545	.7545	.6859			.1372	
16	.7545	.823	.823				
17	.7888		.8916				
18	.2058		.2058				
19	.3429		.3086				
20	.4115		.0041				
21	.3086		.3086				.3429
22	.2401		.2743				.3086
23	.2058		.2058				.2058
24	.1715	.1715	.2058	.2058	.2058	.4115	.4115
Max	**.7888**	**.823**	**.8916**	**.6173**	**.6173**	**.9145**	**.4115**
Min	**.1715**	**.1715**	**.0041**	**.1715**	**.2058**	**.1372**	**.2058**
Avg	**.3839**	**.4533**	**.4986**	**.3001**	**.4116**	**.3531**	**.3172**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154050 / 33/11 KV BORI
Feeder No / Name : 203 / 11KV SALGARA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
2		.5487	
7		.0857	
10			.1029
18	.0857		
23	.0686		
24		.3772	
Max	.0857	.5487	.1029
Min	.0686	.0857	.1029
Avg	.0772	.3372	.1029

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154050 / 33/11 KV BORI
Feeder No / Name : 204 / 11 KV SALGARA II SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	1.6118		1.6461			
2	1.4746	1.6461		1.5089			
3	1.7833	1.4403		1.5775			
4	1.8861	1.6461		1.6461			
5	2.0576	2.0233		1.8519			
6	2.3663	2.4863		2.5377			
7	2.4691	2.8121					
8	2.915	2.7778	2.8121	2.4006		.823	
9		2.6063	2.6749				
10		.6173	.583			.6173	
11						2.332	
12		.3429				2.7435	
13		.2743				2.6749	
14		.2743	.2058			2.7435	
15	.2058	.2058				2.6749	
16	.2058	.2058	.2743				
17	.2401		.2743				
18	.4115		.3429				
19	.9259		.6859				
20	1.0288		.823				.823
21	.8916		.7545				.823
22	.823		.6859				.6173
23	.7888		.5487				.6173
24	1.3375	1.4746	.2743	1.3717	1.4403	.2743	
Max	**2.915**	**2.8121**	**2.8121**	**2.5377**	**1.4403**	**2.7435**	**.823**
Min	**.2058**	**.2058**	**.2058**	**1.3717**	**1.4403**	**.2743**	**.6173**
Avg	**1.2917**	**1.4028**	**.8415**	**1.8176**	**1.4403**	**1.8604**	**.7202**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154052 / 33/11 KV KAWA
Feeder No / Name : 201 / 11KV KAWA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.1905	.2096	.2096	.4999	.6167
2	.1905	.2096	.1905	.2286	.2096	.5401	.6642
3	.2286	.2477	.1905	.2286	.2096	.571	.6642
4	.2286	.2858	.1905	.2667	.2286	.6093	.6964
5	.3048	.2667	.2286	.2667	.2477	.6562	.7125
6	.2858	.3239	.2858	.2858	.3048	.7042	.7773
7	.3239	.3239	.2858	.2858	.3048	.7611	1.0322
8	.2477	.2477	.2477		.2286	.9878	1.065
9	.2286	.2286	.1715	.0191	.2286	.9717	.9503
10		.583	.5761	.3521	.5992	.1334	.1143
11	.8907	.7287	.9717	1.0526	.6802	.0953	
12	.9393	1.0526	1.0202		.7773	.0953	
13	.9717	1.0202	1.0526	1.1012	1.004	.1334	
14	.7449	.9878	.9878	1.0082	1.0202	.1334	
15	.8482		1.0202	1.0202	1.004	.1143	
16	.9393	.9555	1.0688	1.085	1.1012	.0953	
17		1.0526	1.0526	1.0688	1.1012	.0953	
18		.1334	.1143	.1524	.1334	.1334	
19	.2477	.2096	.2096	.2477	.2286	.2096	
20	.3048	.2286	.2286	.2667	.2667	.2858	
21	.2667	.2858	.2477	.2286		.2477	
22	.2477	.2286		.2286	.2286	.2477	
23	.2096	.1905		.2096	.2096	.2286	
24	.1905	.2286	.1905	.2096	.2096	.4725	.5218
Max	**.9717**	**1.0526**	**1.0688**	**1.1012**	**1.1012**	**.9878**	**1.065**
Min	**.1905**	**.1334**	**.1143**	**.0191**	**.1334**	**.0953**	**.1143**
Avg	**.4300**	**.4447**	**.4874**	**.4556**	**.4668**	**.3759**	**.7104**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154052 / 33/11 KV KAWA
Feeder No / Name : 202 / 11KV KHOPEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2947	.2743	.3224	.2947	.2601	.1991	.1907
2	.3121		.3121	.3121	.2601	.1991	.1907
3	.3121	.3258	.3294	.3641	.2601	.1991	.1907
4	.3294	.3601	.3467	.3814	.2774	.1991	.1907
5	.3641	.3944	.3814	.4161	.2947	.2172	.1907
6	.3467	.3772	.4508	.4681	.3121	.2534	.2427
7	.3988	.1543	.5028	.4508	.3988	.2715	.2254
8	.5028	.463	.5375		.4854	.2103	.208
9	.5201	.4458	.4854	.3814	.4681	.1227	.1734
10	.0867	.104	.12	.0693	.1387	.4508	.333
11	.1214	.0867	.12	.0867	.1387	.4508	.4115
12	.104	.0867	.1029	.0867	.1214	.4334	.3856
13	.104	.0867	.0857	.0867	.1214	.4681	.4096
14	.104	.0867	.1029	.104	.1214	.3641	
15	.1214	.104	.1029	.0895	.1214		
16	.1214	.0867	.12	.0867	.104	.3641	
17	.104	.1387	.104	.0867	.104	.3988	
18	.1214	.104	.1387	.0867	.0867	.104	
19	.208	.2427	.2601	.2254	.1734	.2254	
20	.2427	.2601	.2601	.2427	.2534	.2427	
21	.2601	.2601	.2427	.2427		.2427	
22	.2401	.2427		.2254	.2534	.2427	
23	.2058	.208		.208	.2172	.2254	
24	.2947	.2743	.2947	.2947	.2601	.1991	.208
Max	**.5201**	**.463**	**.5375**	**.4681**	**.4854**	**.4681**	**.4115**
Min	**.0867**	**.0867**	**.0857**	**.0693**	**.0867**	**.104**	**.1734**
Avg	**.2425**	**.2247**	**.2601**	**.2300**	**.2275**	**.2732**	**.2536**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154052 / 33/11 KV KAWA
Feeder No / Name : 203 / 11KV RAJIV NAGAR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2194	1.3259	.3795	1.5669	1.363	.3277	.3277
2	1.243	1.3241	.3795	1.5968	1.3637	.3269	.3193
3	1.2784	1.4032	.3637	1.5892	1.3614	.3254	.3246
4	1.2954	1.4569	.4049	1.6516	1.4576	.3193	.3384
5	1.3713	1.5159	.421	1.7345	1.5079	.3947	.3666
6	1.5245	1.7543	.426	1.7419	1.7246	.6295	.5357
7	1.7851	1.9978	.5636	2.1392	2.0125	.5776	.5388
8	2.0001	2.2131	.5967	1.5623	2.2115	.439	.4443
9	2.1356	2.0854	.639	2.1737	2.2809	.3467	.4024
10	1.4967	1.3515	.0486	1.6149	1.5318	1.5982	1.7084
11	.1913	.1883	.0162	.2157	.295	1.9866	2.1485
12	.1807	.1852	.0162	.1746	.1852	2.0178	2.1822
13	.1509	.1715	.0162	.1647	.176	2.0079	1.6423
14	.1426	.1608	.0162	.1631	.208	2.0237	1.5455
15	.1502	.1639	.0162	.1662	.1936	2.0239	1.5623
16	.1479	.1479	.0162	.1563	.17	2.065	1.643
17	.1357	.141	.0191	.1479	.1517	2.1721	1.7452
18	.1821	.1372	.0191	.1816	.1624	1.5341	1.6644
19	.3292	.3429	.1143	.3508	.3734	.3284	.285
20	.4923	.4862	.1143	.3965	.5243	.5197	.3437
21	.4748	.3986	.0953	.3889	.3292	.4542	.3231
22	.3582	.3498		.3688	.3681	.4047	.2972
23	.3285	.3452		.3483	.3597	.3544	.2804
24	1.211	1.3114	.3281	1.2437	.5819	.3376	.3445
Max	**2.1356**	**2.2131**	**.639**	**2.1737**	**2.2809**	**2.1721**	**2.1822**
Min	**.1357**	**.1372**	**.0162**	**.1479**	**.1517**	**.3193**	**.2804**
Avg	**.8260**	**.8733**	**.2277**	**.9099**	**.8706**	**.9798**	**.8881**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154071 / 33/11 KV GANGAPUR
Feeder No / Name : 201 / 11KV WASANGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2833	1.4018	.6859	1.1221	1.4567	.4062	.2522
2	1.3458	1.4662	.7202	1.2559	1.5104	.397	.2454
3	1.4403	1.5059	.7716	1.3588	1.5264	.394	.2416
4	1.4921	1.5386	.8573	1.4228	1.5188	.3947	.2477
5	1.5424	1.6301	.8916	1.5463	1.5874	.4066	.2492
6	1.7493	1.7234	.9945	1.6358	1.7032	.4138	.2545
7	2.1217	2.0054	1.0974	2.229	2.0576	.3852	.2347
8	2.489	2.2123	1.2689	2.1414	2.401	.3048	.2096
9	2.2504	2.1735	1.0848	1.8839	2.2778	.2717	.1799
10	1.392	1.3523	.104	1.4232	1.4594	1.3188	.3757
11	.2191	.2172	.0892	.2359	.2645	2.4733	1.0616
12	.2298	.2404	.0892	.1897	.1501	2.5823	1.2887
13	.2138	.2576	.0892	.1814	.2351	2.5617	1.3306
14	.2332	.2572	.0892	.2103	.2153	2.4798	1.3847
15	.226	.2526	.104	.2096	.2298	2.4638	1.3428
16	.2347	.2302	.104	.237	.2222	2.6719	1.3382
17	.1905	.2374	.1189	.1737	.2073	2.7884	1.4556
18	.1894	.2381	.1337	.2031	.1097	1.558	1.435
19	.3094	.3448	.1783	.3231		.3651	.1532
20	.4446	.4561	.208	.4656	.3905	.5133	.2362
21	.4656	.5239	.2229	.4569	.4652	.5525	.2591
22	.4534	.5106	.208	.45	.4789	.2964	.2675
23	.4702	.5547	.1932	.4667	.4812	.2766	.2881
24	.9366	.9431	.6173	.7346	.8299	.4508	.2759
Max	**2.489**	**2.2123**	**1.2689**	**2.229**	**2.401**	**2.7884**	**1.4556**
Min	**.1894**	**.2172**	**.0892**	**.1737**	**.1097**	**.2717**	**.1532**
Avg	**.9134**	**.9281**	**.4551**	**.8565**	**.9469**	**1.1136**	**.6087**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154071 / 33/11 KV GANGAPUR
Feeder No / Name : 202 / 11KV GANGAPUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7994	.7373	.7716	.7994	.7716	.9945
2	.8755	.7202	.7716	.8755	.7716	1.0288
3	.9516	.6859	.7888	.9516	.823	1.1145
4	1.18	.7716	.8916	1.18	.8573	1.2174
5	1.2942	.8573	1.046	1.3323	1.046	1.3203
6	1.3133	1.2003	1.1145	1.4084	1.1145	1.5089
7	1.161	1.1831	1.2003	1.2942	1.2003	1.9376
8	.9136	.9431	.9431	1.0849	.9602	1.8519
9	.6344	.6859	.7042	.8059	.7888	1.7147
10	1.1831	1.2174	1.2181	1.1317	1.406	.5316
11	1.5775	1.7833	1.751	1.6461	1.6975	.3601
12	1.6289	1.6975	1.7891	1.6975	1.7147	.3944
13	1.2003	1.6632	1.6749	1.6632	1.5947	.4115
14	1.406	1.5947	1.6749	1.6804	1.5089	.4458
15	1.5432	1.6461	1.6559	1.6632	1.4575	.4115
16	1.8519	1.7661	1.713	1.749	1.6804	.4115
17	1.8347	1.869	1.9604	1.7147	1.8861	.4115
18		.4458	.5139	.5144	.4801	.4973
19	.5316	.9431	1.0658	.8916	.8916	.9259
20	1.046	1.0802	1.1991	1.046	1.166	1.0974
21	.9945	1.0288	1.161	1.0288	.9602	1.0802
22	.9088	.9431	.9516	.9259	.9088	
23	.8573	.8402	.9516	.8402	.8745	
24	.8565	.7373	.7716	.8374	.7716	.8745
Max	**1.8519**	**1.869**	**1.9604**	**1.749**	**1.8861**	**1.9376**
Min	**.5316**	**.4458**	**.5139**	**.5144**	**.4801**	**.3601**
Avg	**1.1541**	**1.1267**	**1.1785**	**1.1984**	**1.1388**	**.9337**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154071 / 33/11 KV GANGAPUR
Feeder No / Name : 203 / 11KV PETH SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1851	1.166	.6173	1.2367	1.0265	.9069	.5197
2	1.2725	1.246	.6859	1.3517	1.1019	.8847	.5106
3	1.3497	1.3031	.7202	1.3598	1.1446	.8977	.5167
4	1.3967	1.4281	.7545	1.4271	1.2651	.9953	.5578
5	1.6977	1.5699	.8916	1.5523	1.4601	1.2445	.6965
6	1.6834	1.7596	.9945	1.7546	1.8183	1.5653	.8505
7	1.962	1.938	1.166	2.4342	2.2946	1.5005	.8512
8	2.449	2.348	1.2174	2.3401	1.8115	1.2559	.7697
9	2.3426	2.3594	1.1975	2.0279	1.8664	1.009	.6447
10	1.4221	1.5416	.3825	1.2102	1.3985	.237	.7674
11	.8901	.7087	.3326	.7155	.7202	.3841	1.2399
12	.7697	.6032	.2828	.5975	.6036	2.0332	1.0783
13	.6882	.5857	.2994	.4229	.6051	2.0942	1.1363
14	.6227	.6111		.3208	.5906	1.9478	1.1774
15	.6173	.5658	.2661	.4176	.5692	1.8644	1.2102
16	.5753	.5784	.2994	.6706	.5357	2.1396	1.2437
17	.5792	.5701	.2828	.6447	.5982	1.2033	1.278
18	.679	.695	.4158	.7408	.6699	1.3161	1.15
19	1.0113	1.1344	.5988	1.1462	1.1942	1.3287	.618
20	1.3139	1.4144	.632	1.339	1.8335	1.451	.8009
21	1.259	1.3268	.5988	1.2567	1.3169	1.3896	.7766
22	1.0775	1.171	.499	1.1858	1.1896	.7004	.7103
23	.9297	1.062	.499	1.0829	1.0707	.5838	.6211
24	.9887	1.044	.5658	1.0222	.9373	.9648	.5784
Max	**2.449**	**2.3594**	**1.2174**	**2.4342**	**2.2946**	**2.1396**	**1.278**
Min	**.5753**	**.5658**	**.2661**	**.3208**	**.5357**	**.237**	**.5106**
Avg	**1.1984**	**1.1971**	**.6174**	**1.1774**	**1.1509**	**1.2457**	**.8460**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154071 / 33/11 KV GANGAPUR
Feeder No / Name : 204 / K R REFINARY **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0171		.0191	.0191
2	.0191	.0191	.0171	.0191	.0191	.0191
3	.0191	.0191	.0171	.0191	.0191	.0191
4	.0191	.0191	.0171	.0191	.0191	.0191
5	.0191	.0191	.0171	.0191	.0191	.0191
6	.0191	.0191	.0171	.0191	.0191	.0191
7	.0191	.0191	.0171	.0191	.0191	.0191
8	.0191	.0191	.0171	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0171	.0191		.0191	.0171
11	.0191	.0171	.0191	.0191	.0191	.0171
12	.0191	.0171	.0191	.0191	.0191	.0171
13	.0191	.0171	.0191	.0191	.0191	.0171
14	.0191	.0171	.0191	.0191	.0191	.0171
15	.0191	.0171	.0191	.0191	.0191	.0171
16	.0191	.0171	.0191	.0191	.0191	.0171
17	.0191	.0171	.0191	.0191	.0191	.0171
18	.0191	.0171	.0191	.0191	.0191	.0171
19	.0191	.0171	.0191	.0191	.0191	
20	.0191	.0171	.0191	.0191	.0191	
21	.0191	.0171		.0191	.0191	
22	.0191	.0171	.0191	.0191	.0191	
23	.0191	.0171	.0191	.0191	.0191	
24	.0191	.0191	.0171	.0191	.0191	.0191
Max	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**
Min	**.0191**	**.0171**	**.0171**	**.0191**	**.0191**	**.0171**
Avg	**.0191**	**.0179**	**.0183**	**.0191**	**.0191**	**.0182**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA
Feeder No / Name : 201 / 11KV CHINCHOLIRAOWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3605	.463	.3658	.3944	.4458		.6687
2	.373	.4801	.3506	.4458	.463		.7202
3		.5316	.3658	.5144	.463		.7716
4	.4973	.703	.463	.5487	.4801		.8745
5	.583	.9431	.6001		.5144		.9431
6	.7362	1.046	.7373	.7716	.583		.9945
7	.8642	1.0288	.7716	.0514	.6001		1.1317
8	.6802	.5144	.6859	.6516	.6516		1.286
9	.583		.5487				1.2517
10	.5792	.8916			.8619	.1619	.3944
11	.9907	1.2174	1.2517	.945	1.166	.3315	.3429
12	1.0212	1.286	1.2003		1.085	.2374	
13	1.0669	1.3375	1.166	.8383	1.1271	.2984	
14	1.0974	1.3203	1.166	.9602	1.1105	.2652	
15	1.1126	1.3546	1.1831	1.0364	1.065	.2267	
16	1.1584	1.3717	1.166	1.0974	1.0322	.2622	
17	1.3889	1.3565	1.2174			.2915	
18	.5144	.442	.5658	.4458		.4287	
19	.7202	.4877	.7716	.6516	.4458	.703	
20	.7373	.5487	.8916	.6001	.583	.6859	
21	.7202	.5335	.8059	.5658	.5658	.6173	
22	.6859	.4401	.6859	.5316	.5658	.5487	
23	.5658	.4134	.5144	.5144		.5144	
24	.4409	.4801	.3963	.4287	.4287	.4134	
Max	**1.3889**	**1.3717**	**1.2517**	**1.0974**	**1.166**	**.703**	**1.286**
Min	**.3605**	**.4134**	**.3506**	**.0514**	**.4287**	**.1619**	**.3429**
Avg	**.7599**	**.8344**	**.7770**	**.6312**	**.7119**	**.3991**	**.8527**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA
Feeder No / Name : 202 / 11KV KHANDAPUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.1831	1.286	1.2346	1.1488		1.2003
2	1.3375	1.286	1.6289	1.3375	1.2003		1.1145
3		1.5089	1.8861	1.6289	1.286		1.1145
4	1.647	1.7318	2.3148	1.8004	1.7318		1.2003
5	2.0576	2.3491	2.8292	1.9204	2.0919		1.3375
6	2.4006	2.6749	2.9492	2.0748	2.4863		1.4575
7	2.8121	2.8807	2.915	2.692	2.8807		1.5604
8	2.7949	2.9492	3.1207	2.7606	3.0521		1.4232
9	2.7263		2.9492			.0173	1.4918
10	1.0802	.9774			1.1789	1.7337	1.6289
11	.8916	.9431	.9774	1.0117	1.1269	2.5206	1.3889
12	.7888	.8573			1.0117	2.774	1.2003
13	.8573	.7373	.9774	.9602	1.046	2.6749	
14	.823	.8573	.9602	.9259	1.0631	2.6006	
15	.8745	.9088	.9259	.9431	1.1145	2.5312	
16	.8916	.9088	.9088	.9602		2.722	
17	.9431	1.0117	.7716			2.9835	
18	1.0631	1.166	1.0802	1.0974		1.0974	
19	1.3889	1.5261	1.3375	1.5089	1.4918	1.4575	
20	1.3717	1.6118	1.6975	1.4918	1.6975	1.7147	
21	1.2174	1.5775	1.6289	1.4575	1.6804	1.6632	
22	1.166	1.4575	1.5089	1.4232	1.6461	1.5604	
23	1.0974	1.3203	1.3717	1.3717		1.4746	
24	1.046	1.0288	1.166	1.166	1.0117	1.286	
Max	**2.8121**	**2.9492**	**3.1207**	**2.7606**	**3.0521**	**2.9835**	**1.6289**
Min	**.7888**	**.7373**	**.7716**	**.9259**	**1.0117**	**.0173**	**1.1145**
Avg	**1.4120**	**1.4545**	**1.6905**	**1.4883**	**1.5761**	**1.9257**	**1.3432**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA
Feeder No / Name : 203 / 11KV AGRAWAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1949	.1715	.1715	.1543	.1543		.1543
2	.197	.1543	.1543	.1372	.1543		.1543
3		.1543	.1372	.1372	.1543		.1372
4	.2149	.1715	.1543	.1372	.1372		.1372
5	.2033	.1886	.1543	.1543	.1372		.1372
6	.2149	.2058	.1715	.1715	.1372		.1372
7	.2149	.2058	.1715	.1543	.1543		.1543
8	.1991	.1886	.1886	.1715	.1372		.1715
9	.1886		.1715				.1886
10	.2058	.2401			.181	.1848	.2229
11	.2229	.2401	.2743	.2572	.1791	.2402	.2229
12	.2401	.2572	.2915			.2328	.2229
13	.2743	.2572	.2915	.2058	.1928	.2427	
14	.3258	.2915	.2915	.2229	.1991	.2328	
15	.3429	.3086	.3086	.2915	.173	.2534	
16	.3258	.3258	.2915	.3258	.1791	.2195	
17	.3086	.2401	.2401			.1886	
18	.2401	.2058	.2229	.2572		.1543	
19	.2572	.2058	.2401	.1886	.1372	.1715	
20	.2401	.1886	.2229	.1886	.1543	.1715	
21	.2229	.1886	.2058	.1715	.1543	.1715	
22	.2058	.1886	.1886	.1543	.1372	.1543	
23	.1886	.1715	.1715	.1543		.1543	
24	.2353	.1715	.1715	.1543	.1543	.1372	
Max	**.3429**	**.3258**	**.3086**	**.3258**	**.1991**	**.2534**	**.2229**
Min	**.1886**	**.1543**	**.1372**	**.1372**	**.1372**	**.1372**	**.1372**
Avg	**.2376**	**.2140**	**.2125**	**.1895**	**.1583**	**.1940**	**.1700**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA
Feeder No / Name : 204 / PANAN MAHASANGH NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171		.0171
2		.0171	.0171	.0171	.0171		.0171
3		.0171	.0171	.0171	.0171		.0171
4		.0171	.0171	.0171	.0171		.0171
5	.0171	.0171	.0171	.0171	.0171		.0171
6	.0171	.0171	.0171	.0171	.0171		.0171
7	.0171	.0171	.0171	.0343	.0171		.0171
8	.0171	.0171	.0171	.0171	.0171		.0171
9	.0171	.0171	.0171			.0173	.0171
10	.0171	.0171			.0173	.0173	.0171
11	.0171	.0171	.0171	.0171	.0173	.0173	.0171
12	.0171	.0171	.0171		.0171	.0173	.0171
13	.0171	.0171	.0171	.0171	.0171	.0173	
14	.0171	.0171	.0171	.0171	.0171	.0173	
15	.0171	.0171	.0171	.0171	.0171	.0173	
16	.0171	.0171	.0171	.0171	.0171	.0173	
17	.0171	.0171	.0171	.0171		.0171	
18	.0171	.0171	.0171	.0171		.0171	
19	.0171	.0171	.0171	.0171	.0171	.0171	
20		.0171	.0171	.0171	.0171	.0171	
21	.0171	.0171	.0171	.0171	.0171	.0171	
22	.0171	.0171	.0171	.0171	.0171	.0171	
23	.0171	.0171	.0171	.0171		.0171	
24	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Max	**.0171**	**.0171**	**.0171**	**.0343**	**.0173**	**.0173**	**.0171**
Min	**.0171**	**.0171**	**.0171**	**.0171**	**.0171**	**.0171**	**.0171**
Avg	**.0171**	**.0171**	**.0171**	**.0179**	**.0171**	**.0172**	**.0171**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154077 / 33/11 KV KOLPA
Feeder No / Name : 201 / 11KV MALVATI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.4801				
5		.3982		1.0288	
7	.4572				1.5851
8		.4344			
9	.3048			1.8099	1.768
10		.4062		.4344	
16				.2439	
21				.5487	
23			.6161		
24				.823	
Max	**.4801**	**.4344**	**.6161**	**1.8099**	**1.768**
Min	**.3048**	**.3982**	**.6161**	**.2439**	**1.5851**
Avg	**.4140**	**.4129**	**.6161**	**.8148**	**1.6766**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154077 / 33/11 KV KOLPA
Feeder No / Name : 202 / 11KV KOLPA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.5487				
5		.905		.3429	
7	1.2193				.3658
8		1.448			
9	1.2193			.4298	.2743
10		.3437		.724	
16				.8535	
21				.5144	
23			.547		
24				.3086	
Max	**1.2193**	**1.448**	**.547**	**.8535**	**.3658**
Min	**.5487**	**.3437**	**.547**	**.3086**	**.2743**
Avg	**.9958**	**.8989**	**.547**	**.5289**	**.3201**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154077 / 33/11 KV KOLPA
Feeder No / Name : 203 / 11KV BHATKHEDA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	1.0288				
5		1.086		.3772	
7	1.2193				.3048
8		1.6289			
9	1.3413			.4344	.1829
10		.3239		.6516	
16				1.5242	
21				.3429	
23			.3961		
24				.3429	
Max	**1.3413**	**1.6289**	**.3961**	**1.5242**	**.3048**
Min	**1.0288**	**.3239**	**.3961**	**.3429**	**.1829**
Avg	**1.1965**	**1.0129**	**.3961**	**.6122**	**.2439**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154094 / 33/11 KV BHATANGALI
Feeder No / Name : 201 / 11KV BHATANGALI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0366	.0343	.0373	.037	.4748	.381
2	.0377	.0362	.0343	.0373	.037	.4748	.4115
3	.0377	.0362	.0343	.0373	.037	.5548	.442
4	.0377	.0358	.0343	.0373	.037	.583	.4572
5	.0373	.0358	.0343	.0366	.037	.6173	.4877
6	.0373	.0358	.0343	.0366	.037	.6783	.5335
7	.0373	.0358	.0343	.0373	.0362	.7202	.6401
8	.0377	.0358	.0343	.0373		.6859	.6554
9	.0343	.0373	.0373	.0373	.0343	.6097	
10	.3048	.4268	.4401	.6104	.3658	.0366	
11	.503	.5792	.6249	.6097	.5182	.0377	
12	.5792	.4877	.6015	.6952	.5487	.0377	
13	.5944		.5502	.703	.6706	.0377	
14	.5639	.5792	.5573	.6952	.6706	.0377	
15	.5335	.6249	.5428	.6104	.6554	.0377	
16	.5792	.6874	.5721	.6706	.6706		.0377
17	.6706	.6554	.6706	.6573	.78	.0343	
18	.0381	.0343	.0366	.0377	.0347	.0343	
19	.0381	.0343	.0366	.037	.0347	.0343	
20	.0373	.0343	.0373	.0377	.0351	.0343	
21	.0373	.0343	.0373	.0373	.0351	.0343	
22	.0373	.0343	.0373	.0373	.0351	.0343	
23	.0373	.0343	.0373	.037	.0343	.0343	
24	.0377	.0373	.0343	.037	.037	.4334	.3048
Max	**.6706**	**.6874**	**.6706**	**.703**	**.78**	**.7202**	**.6554**
Min	**.0343**	**.0343**	**.0343**	**.0366**	**.0343**	**.0343**	**.0377**
Avg	**.2053**	**.2004**	**.2137**	**.2436**	**.2356**	**.2738**	**.4351**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154094 / 33/11 KV BHATANGALI
Feeder No / Name : 202 / 11KV CHIKHALTHANA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4534	.4586	.4115	.5121	.4374		
2	.4801	.4744	.4268	.5281	.4374		
3	.5121	.4572	.442	.5441	.4744		
4	.5441	.4572	.4725	.5312	.4902		
5	.6081	.506	.4877	.5601	.4902		
6	.6325	.5851	.503	.5761	.5376		
7	.6562	.7042	.5335	.6081	.6554		
8	.5535	.5624	.5182	.6722			
9	.5792	.6249	.4877	.6562	.6554	.0152	
10		.0152				.4843	
11						.5624	
12						.5937	
13						.5639	
14		.0152				.5487	
15		.0152				.5335	
16		.0152					.6642
17			.0152				
18			.0152				
19			.0152				
20			.0152				
21			.0152				
22			.0152				
23			.0152				
24	.3749	.4531	.3658	.4801	.4374		
Max	**.6562**	**.7042**	**.5335**	**.6722**	**.6554**	**.5937**	**.6642**
Min	**.3749**	**.0152**	**.0152**	**.4801**	**.4374**	**.0152**	**.6642**
Avg	**.5394**	**.3817**	**.2797**	**.5668**	**.5128**	**.4717**	**.6642**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154094 / 33/11 KV BHATANGALI
Feeder No / Name : 203 / 11KV BAMNI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3841	.3353	.3563	.3749	.1029	.1029
2	.3841	.4049	.3506	.4534	.4062	.104	.1029
3	.4481	.4001	.381	.4858	.4321	.1029	.1372
4	.4744	.4588	.3963	.5441	.4321	.1029	.1372
5	.5441	.4588	.503	.583	.4915		.1715
6	.5761	.5571	.5487	.6226	.663	.1907	.1886
7	.6081	.7127	.6706	.6478	.6802	.1907	.2058
8	.5992	.5182	.6706	.7449		.1715	.2229
9	.5487	.5792	.7011	.6478	.5944	.1578	
10	.1029	.0876	.0886	.052	.1029	.4801	
11	.1029	.0701	.0537	.052	.1029	.5441	
12	.1029	.0526	.0549	.0678	.0857	.5121	
13	.0686		.056	.0693	.0686	.6081	
14	.0514	.0532	.056	.0686	.0857	.4572	
15	.0514	.0532	.0543	.052		.5182	
16	.0686	.0543	.0554		.0686		.5921
17	.0366	.0857	.0549	.0549	.052	.5944	
18	.0747	.1029	.0886	.0754	.0693	.1029	
19	.124	.1543	.1417	.1612	.1214	.1372	
20	.1595	.1715	.1595	.1433	.12	.1715	
21	.1463	.1543	.1417	.1433	.1387	.1543	
22	.1097	.1543	.124	.1267	.1387	.1543	
23	.0914	.1372	.1063	.0914	.1214	.1372	
24	.2591	.3321	.2743	.0514	.3353	.104	.1372
Max	**.6081**	**.7127**	**.7011**	**.7449**	**.6802**	**.6081**	**.5921**
Min	**.0366**	**.0526**	**.0537**	**.0514**	**.052**	**.1029**	**.1029**
Avg	**.2493**	**.2668**	**.2528**	**.2737**	**.2584**	**.2636**	**.1998**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154095 / 33/11 KV ADD MIDC
Feeder No / Name : 201 / 11KV DOOT SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2785				
2		.2401	.2543		.2915		
3			.2458				
4		.2572	.2743		.2915		
5			.2713		.2915		
6	.2195		.2926	.3109			
7	.2926		.362	.3658		.1829	
8	.3292		.362			.1829	
9	.4294		.3944	.3768			
10	.6478			.4424	.4572		
11	.6287		.6001	.5906	.4024		.6219
12	.6287	.5853		.6287			
13	.6287		.6173	.6859			
14	.5304	.5487		.7049	.4207		
15	.5087		.5144	.743	.3658		
16	.5716	.5487	.5487				
17	.5144	.6478		.4973			
18		.5525	.4024		.3658		
19	.4973	.6097		.5144	.2926		
20		.5906	.439		.3475		
21	.3086	.3768		.3601			
22		.3277	.3841				
23			.3292		.2926		
24	.2561	.2401	.2785	.2926	.2915		
Max	**.6478**	**.6478**	**.6173**	**.743**	**.4572**	**.1829**	**.6219**
Min	**.2195**	**.2401**	**.2458**	**.2926**	**.2915**	**.1829**	**.6219**
Avg	**.4661**	**.4604**	**.3805**	**.5010**	**.3426**	**.1829**	**.6219**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154095 / 33/11 KV ADD MIDC
Feeder No / Name : 202 / 11KV AIRPORT SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4915				
2		.463	.5087		.6859		
3			.4917				
4		.5487	.5087		.7202		
5			.5847				
6			.9526	.9313			
7			.9145	.197		.9313	
8	.7522		.7316			.9134	
9	.8413			1.2765			1.2178
10	.8413			1.2384	.9134		
11	.9526			1.2193	1.0029		1.0745
12	.7973	.8417		1.1622			
13	.7499		.5487	1.1812			
14	.7499	.6626		1.1812	.7522		
15	.6952			1.2193	.788		
16	.8048		.5658				
17	1.0288	1.0288		1.2689			
18		1.2574	1.0745		.8059		
19	.7888	.8764		1.2346	.8417		
20		.815	.9313		.9134		
21	.7202	.6859		.7545			
22		.6201	.7164				
23			.7522		.4477		
24	.5731	4.7497	.5426	.6447	.6859		
Max	**1.0288**	**4.7497**	**1.0745**	**1.2765**	**1.0029**	**.9313**	**1.2178**
Min	**.5731**	**.463**	**.4915**	**.197**	**.4477**	**.9134**	**1.0745**
Avg	**.7920**	**1.1408**	**.6877**	**1.0392**	**.7779**	**.9224**	**1.1462**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154095 / 33/11 KV ADD MIDC
Feeder No / Name : 203 / 11KV KALANTRI SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1581				
2		.2058	.1638		.6859		
3			.1696				
4		.2058	.1696		.7202		
5			.1696				
6	.2641		.1696	.2641			
7	.3395		.1638	.2263		.1905	
8	.2641		.1357			.1905	
9	.4954		.2058	.381			.2286
10	.724	.6036		.5716	.3018		
11	.724		.3258	.6097	.3018		.4763
12	.724	.8299		.5716			
13	.724		.3086	.2543			
14	.5716	.5658		.5716	.3018		
15	.724		.5144	.6478	.3018		
16		.6036	.3772				
17	.7545	.5716		.583			
18		.3605	.3772		.2286		
19	.4801	.3658		.3429	.1905		
20		.2374	.2641		.1905		
21	.4115	.1966		.3772			
22		.1581	.2263				
23			.2263		.1905		
24	.3395	.2058	.1638	.2263	.3429		
Max	**.7545**	**.8299**	**.5144**	**.6478**	**.7202**	**.1905**	**.4763**
Min	**.2641**	**.1581**	**.1357**	**.2263**	**.1905**	**.1905**	**.2286**
Avg	**.5386**	**.3931**	**.2383**	**.4329**	**.3415**	**.1905**	**.3525**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154095 / 33/11 KV ADD MIDC
Feeder No / Name : 204 / SHANKARSHETH POLYMERS Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0492				
2		.0171	.0492				
3			.0655				
4		.0171	.0655				
5			.0509				
6	.0171		.0492	.0171			
7	.0171		.0492	.0171		.0164	
8	.0171		.0655			.0164	
9	.0492		.0171	.0492			.4024
10	.0819	.0171		.0492	.0171		
11	.0474		.0343	.0492	.0171		.0819
12	.0474	.0171		.0492			
13	.0474		.0343	.0492			
14	.0492	.0171		.0492	.0171		
15	.0492		.0343	.0492	.0171		
16	.0316	.0171	.0343				
17	.0171	.0492		.0171			
18		.0509	.0171		.0164		
19	.0343	.0655		.0343	.0164		
20		.1147	.0171		.0164		
21	.0171	.0492		.0171			
22		.0509	.0171				
23			.0171		.0164		
24	.0171	.0171	.0474	.0171	.0171		.0492
Max	**.0819**	**.1147**	**.0655**	**.0492**	**.0171**	**.0164**	**.4024**
Min	**.0171**	**.0171**	**.0171**	**.0171**	**.0164**	**.0164**	**.0492**
Avg	**.0360**	**.0385**	**.0397**	**.0357**	**.0168**	**.0164**	**.1778**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154095 / 33/11 KV ADD MIDC
Feeder No / Name : 205 / KANHAIYA SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1581				
2		.1886	.1638		.1715		
3			.1865				
4		.1886	.1865		.1715		
5			.1966				
6	.1829		.2035	.2012			
7	.2012		.1696	.2012		.128	
8	.1646		.1526			.1463	
9	.1311		.1715	.213			.1829
10	.1966	.4938		.2458	.0914		
11	.2949		.2915	.3391	.0732		.4572
12	.3277			.4075			
13	.4001		.3086	.4607			
14	.2713			.3277	.1097		
15	.3475		.2743	.3052			
16		.3658	.2915				
17	.3772	.3113		.4801			
18		.3052	1.0974		.0732		
19	.2572	.2543		.4287	.0732		
20		.2294	.2561		.1097		
21	.1886	.1696		.1715			
22		.1265	.2012				
23			.3841		.1097		
24	.1646	.2229	.1802	.3841	.1886		
Max	**.4001**	**.4938**	**1.0974**	**.4801**	**.1886**	**.1463**	**.4572**
Min	**.1311**	**.1265**	**.1526**	**.1715**	**.0732**	**.128**	**.1829**
Avg	**.2504**	**.2596**	**.2708**	**.3204**	**.1172**	**.1372**	**.3201**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (R) S/D[420] BU 5126
Substation No/ Name :- 154095 / 33/11 KV ADD MIDC
Feeder No / Name : 206 / Gajraj **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9717				
2		.8573	.9526				
3			.9526				
4		.8402	.8779				
5			.9717				
6	.9896		1.0669	1.0082			
7	.9149		1.105	1.0082		.9149	
8	1.0269		.9335			.8962	
9	.9907		.9431	.5868			
10	.3441	.9522		.763	.7468		
11	.2688		.9945	1.105	.3395		.9709
12	.2688	1.0269		1.0288			
13	.2846		.9259	1.0479			
14	.3277	.9149		.8596	.2987		
15	.2949		.8402	.9145			
16	.2949	.9522	.9259				
17	.3601	.8779		.823			
18		.763	.9149		.1494		
19	.2915	.9526		.7545	.1494		
20		.8215	.8402				
21	.2915	.763		.9088			
22		.8505	.9896				
23			.9896				
24	.8589	.7545	.9717	1.0082	.8573		.9522
Max	**1.0269**	**1.0269**	**1.105**	**1.105**	**.8573**	**.9149**	**.9709**
Min	**.2688**	**.7545**	**.8402**	**.5868**	**.1494**	**.8962**	**.9522**
Avg	**.5205**	**.8713**	**.9538**	**.9090**	**.4235**	**.9056**	**.9616**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 154113 / MEDICAL COLLEGE
Feeder No / Name : 201 / 11KV MEDICAL COLLEGE **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.181	.2033	.1949	.1907	.2149	.2126
2	.1791	.1772	.1829	.1949	.1886	.1907	.2126
3	.1772	.1595	.2054	.1949	.1886	.1907	.2103
4	.1772	.1612	.2033	.1949	.1886	.1907	.2103
5	.1791	.1629	.2012	.1949	.1886	.1907	.1928
6	.2012	.1829	.2033	.197	.1886	.1928	.1928
7	.1991	.1848	.2402	.2218	.1772	.2149	.1949
8	.2263	.1867	.2195	.2218	.1949	.1991	.1772
9	.2263	.2452	.2641	.2218	.2054	.2801	.1991
10	.2801	.3048	.3048	.2987	.2012	.3206	.1991
11	.2957	.3239	.3018	.2772	.2218	.3395	
12	.2772	.3239	.2829	.2772	.2587	.3206	.1991
13	.2801	.3048	.3018	.2926	.2427	.2641	
14	.2218	.2263	.2452	.2772	.2241	.2353	
15	.2218	.2263	.2641	.2353	.2218	.2241	
16	.2378	.2452	.2263	.2241	.2218	.2058	
17	.2241	.2241	.2452	.2241	.2012	.1848	
18	.2033	.2218	.2452	.2195	.2012	.2172	
19	.2218	.2402	.2561	.2561	.2241	.2195	
20	.2033	.2427	.2353	.2353	.2218	.2507	
21	.2033	.2378	.2378	.2172	.2241	.2353	
22	.2218	.2402	.2378	.2126	.2378	.2172	
23	.2012	.2241	.2353	.2126	.2172	.2172	
24	.2012	.181	.2241	.2353	.1907	.2378	.2149
Max	**.2957**	**.3239**	**.3048**	**.2987**	**.2587**	**.3395**	**.2149**
Min	**.1772**	**.1595**	**.1829**	**.1949**	**.1772**	**.1848**	**.1772**
Avg	**.2184**	**.2254**	**.2403**	**.2305**	**.2092**	**.2314**	**.2013**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 154113 / MEDICAL COLLEGE
Feeder No / Name : 202 / 11KV MARKET YARD SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.531	1.5089	1.4815	1.643	1.6598	1.6617	1.643
2	1.4563	1.4146	1.4449	1.643	1.5844	1.587	1.587
3	1.307	1.3769	1.423	1.4937	1.5466	1.531	1.587
4	1.307	1.3392	1.3756	1.419	1.5089	1.419	1.531
5	1.3256	1.3256	1.3969	1.3817	1.4712	1.2883	1.4937
6	1.3443	1.3256	1.267	1.4937	1.4523	1.3443	1.4563
7	1.3306	1.3676	1.3169	1.386	1.2936	1.2012	1.2567
8	1.2127	1.2567	1.1946	1.267	1.2071	1.086	1.2071
9	1.0791	1.2178	1.2536	1.2986	1.086	1.2357	1.1949
10	1.2489	1.3112	1.2795	1.3394	1.1888	1.2048	1.2197
11	1.3717	1.5203	1.4175	1.3717	1.0679	1.379	1.2936
12	1.3611	1.5043	1.4883	1.4842	1.386	1.4632	1.3121
13	1.3394	1.5402	1.5384	1.5729	1.4266	1.5203	
14	1.4998	1.5203	1.4842	1.5384	1.448	1.5223	
15	1.448	1.5364	1.4998	1.5746	1.3253	1.5708	
16	1.5364	1.6289	1.5546	1.5223	1.3535	1.6278	
17	1.4842	1.4998	1.5565	1.5729	1.4118	1.5364	
18	1.3937	1.4266	1.4723	1.5893	1.39	1.4706	
19	1.848	1.8099	1.828	1.885	1.3756	1.8446	
20	1.848	1.8656	1.9204	1.9404	1.6095	1.922	
21	1.7002	1.8099	1.7741	1.7556	1.6118	1.848	
22	1.8107	1.7375	1.7924	1.7551	1.7375	1.848	
23	1.773	1.7741	1.848	1.8671	1.7002	1.6991	
24	1.587	1.6221	1.5746	1.7551	1.8107	1.7193	1.7177
Max	**1.848**	**1.8656**	**1.9204**	**1.9404**	**1.8107**	**1.922**	**1.7177**
Min	**1.0791**	**1.2178**	**1.1946**	**1.267**	**1.0679**	**1.086**	**1.1949**
Avg	**1.4643**	**1.51**	**1.5076**	**1.5646**	**1.4439**	**1.5221**	**1.4231**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 154113 / MEDICAL COLLEGE
Feeder No / Name : 203 / 11KV KANHERI ROAD SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7922	.8501	.8488	.9242	.8676	.8865
2	.7167	.7922	.8501	.8488	.8488	.8488	.8299
3	.6979	.7545	.7865	.8299	.8299	.7922	.8299
4	.6979	.7167	.724	.7922	.8299	.7922	.8299
5	.7356	.7167	.7133	.8299	.8299	.7545	.8299
6	.811	.7733	.7577	.8865	.8488	.811	.9242
7	.811	.811	.823	.9054	.8676	.7545	.8299
8	.7167	.7167	.8688	.7655	.7842	.7468	.7655
9	.6838	.679	.823	.7023	.7577	.679	.7282
10	.6838	.7207	.7865	.7865	.7577	.7023	.8779
11	.8048	.8413	.8779	.8316	.7865	.8501	.8779
12	.7577	.8413	.8779	.7865	.8326	.8215	.8048
13	.7865	.8316	.9335	.8316	.8131	.9149	
14	.7421	.7922	.9335	.823	.7865	.8589	
15	.7392	.8402	1.0456	.8962	.7947	.9795	
16	.7701	.924	.9335	.8962	.8145	.9709	
17	.7762	.924	.8871	.9055	.8048	.9795	
18	.8131	.8779	.9593	.9335	.7577	.9955	
19	.9425	1.1706	1.134	1.1203	1.0059	1.1222	
20	1.0719	1.1222	1.2012	1.1576	1.0534	1.1576	
21	.924	1.0974	1.0456	1.0829	.9877	1.0374	
22	.9997	1.0349	1.0082	1.0082	1.0185	1.1128	
23	.9431	.9877	1.0374	1.0456	.9808	1.0562	
24	.7922	.811	.8779	.9054	.9808	.8865	.9242
Max	**1.0719**	**1.1706**	**1.2012**	**1.1576**	**1.0534**	**1.1576**	**.9242**
Min	**.6838**	**.679**	**.7133**	**.7023**	**.7577**	**.679**	**.7282**
Avg	**.7988**	**.8571**	**.9057**	**.8925**	**.8623**	**.8955**	**.8414**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157001 / 132 KV KOYANA
Feeder No / Name : 201 / 11 KV BABHALGAON SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0137
Max	.0137
Min	.0137
Avg	.0137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157001 / 132 KV KOYANA
Feeder No / Name : 203 / 11 KV TOWN **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-APR-17	04-APR-17
HR	Load (MW)	Load (MW)
1		1.0745
2		1.0059
3		.9755
4		.9526
5		.945
6		.9602
7		1.0212
8		1.0136
9		.9983
10		.9526
11		.9297
12		.9145
13		.8993
14		.9145
15		.945
16		.945
17		.8764
18		.9297
19		.9831
20		1.2498
21		1.2422
22		1.2193
23		1.1965
24	.0171	1.1736
Max	**.0171**	**1.2498**
Min	**.0171**	**.8764**
Avg	**.0171**	**1.0133**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157001 / 132 KV KOYANA
Feeder No / Name : 204 / 11 KV SHIDDHESHWAR **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7659	.7392	.6744	.7087
2	.6135	.7202	.7087	.6478	.6592
3	.602	.6554	.6783	.6287	.6211
4	.5982	.6211	.6668	.6173	.6173
5	.5944	.6592	.6668	.644	.6249
6	.6363	.7202	.7125	.6935	.6668
7	.743	.7888	.7888	.7964	.7659
8	.7888	.8726	.8688	.8154	.8383
9	.8116	.8573	.9069	.8154	.8459
10	.8954	.8612	.9145	.823	.8269
11	.8612	.8726	.884	.8878	.8612
12	.8192	.9221	.7125	.8916	.9031
13	.8421	.9488	.7049	.8878	.9335
14	.8497	.9374	.7202	.8383	.8688
15	.7735	.865	.7125	.8688	.8345
16	.743	.823	.7316	.9145	.7888
17	.8307	.8764	.7278	.9145	.884
18	.8802	.8383	.7316	.7049	.8688
19	.6744	.8192	.6821	.7773	.7849
20	.7926	.8345	.6859	.9335	.8154
21	.7849	.9031	.6859	.9221	.8307
22	.724	.9069	.7125	.9297	.7773
23	.743	.8878	.7202	.8269	.8078
24	.6401	.7868	.7011	.7926	.7773
Max	**.8954**	**.9488**	**.9145**	**.9335**	**.9335**
Min	**.5944**	**.6211**	**.6668**	**.6173**	**.6173**
Avg	**.7456**	**.8227**	**.7402**	**.8019**	**.7880**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157001 / 132 KV KOYANA
Feeder No / Name : 205 / 11 KV INDUSTRIAL SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0137
Max	.0137
Min	.0137
Avg	.0137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157001 / 132 KV KOYANA
Feeder No / Name : 206 / 11 KV SOOT MILL SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0154
Max	.0154
Min	.0154
Avg	.0154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157001 / 132 KV KOYANA
Feeder No / Name : 207 / 11 KV SAI **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.6059	.6211	.6287	.6211	.6363
2	.5525	.5639	.5792	.5906	.5906	.5906
3	.5411	.5449	.5639	.5792	.5868	.5716
4	.5335	.5373	.5601	.5754	.583	.5639
5	.5449	.5373	.5563	.5716	.5754	.5639
6	.5754	.5639	.583	.602	.5982	.583
7	.6287	.644	.6401	.6478	.6592	.6325
8	.6554	.6325	.6287	.6401	.644	.6287
9	.6401	.5906	.6097	.6097	.5982	.6173
10	.5982	.5525	.5944	.644	.583	.5754
11	.5182	.5182	.5296	.6135	.522	.5411
12	.522	.4611	.4763	.5335	.4763	.503
13	.5182	.4649	.4572	.4763	.4649	.4839
14	.4649	.4496	.4496	.4992	.4687	.4801
15	.4763	.4534	.4306	.4954	.4725	.4572
16	.4725	.4687	.4687	.4877	.4725	.4496
17	.4801	.4572	.4611	.4801	.4649	.4572
18	.5106	.4496	.4915	.5106	.4763	.4572
19	.5525	.5449	.5601	.5639	.5449	.522
20	.724	.6859	.7392	.724	.6783	.724
21	.7164	.6783	.7202	.7278	.7049	.7278
22	.6935	.7011	.6973	.7011	.6973	.7011
23	.7011	.6783	.7011	.7278	.6935	.7164
24	.6668	.6516	.6817	.6821	.6744	.6859
Max	**.724**	**.7011**	**.7392**	**.7278**	**.7049**	**.7278**
Min	**.4649**	**.4496**	**.4306**	**.4763**	**.4649**	**.4496**
Avg	**.5782**	**.5598**	**.5750**	**.5963**	**.5771**	**.5779**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157001 / 132 KV KOYANA
Feeder No / Name : 208 / 11 KV AUSA ROAD SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0257
Max	.0257
Min	.0257
Avg	.0257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157001 / 132 KV KOYANA
Feeder No / Name : 209 / 11 KV SINHGAD SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0181
Max	.0181
Min	.0181
Avg	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157001 / 132 KV KOYANA
Feeder No / Name : 404 / 33 KV MEDICAL COLLEGE SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	01-APR-17
HR	Load (MW)
24	.0514
Max	.0514
Min	.0514
Avg	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
LATUR (U) S/D(SOUTH)[640] BU 4640
Substation No/ Name :- 157004 / 132 KV S/S MIDC
Feeder No / Name : 204 / 11 KV DAYANAND SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8333	4.0085	4.26	4.3439	4.2753	4.2981
2	3.6199	3.7418	4.0314	4.1076	4.0085	4.1
3	3.4675	3.6275	3.9018	3.9247	3.8637	3.9552
4	3.376	3.5132	3.7342	3.8104	3.7647	3.8028
5	3.2998	3.4522	3.658	3.7342	3.6732	3.7037
6	3.4217	3.5818	3.6885	3.6732	3.6961	3.7418
7	3.7266	4.0695	4.0085	3.7723	4.0009	3.94
8	3.6656	3.9857	3.9552	3.879	3.9933	3.9323
9	3.2998	3.6046	3.6046	3.6275	3.5361	3.7494
10	3.0407	3.3684	3.5056	3.3684	3.2465	3.4065
11	2.934	3.3074	3.3379	3.2922	3.0636	3.5665
12	2.9645	2.5377	3.3532	3.3227	3.0712	3.4598
13	3.0102	2.5225	3.3836	3.4294	3.1017	3.5208
14	3.1779	2.5758	3.6275	3.5665	3.3608	3.5818
15	3.2769	2.5911	3.7342	3.719	3.5132	3.7342
16	3.4522	3.7037	3.8866	3.8104	3.658	3.818
17	3.437	3.6275	3.7647	3.8104	3.6961	3.8333
18	3.3608	3.5437	3.6656	3.6046	3.5589	3.719
19	3.4446	3.8485	3.9171	3.7571	3.818	3.7875
20	4.4963	4.481	4.7097	4.4505	4.7478	4.5191
21	4.5268	4.6411	4.7173	4.542	4.7249	4.5801
22	4.5877	4.6639	4.763	4.6563	4.7325	4.6868
23	4.5725	4.6639	4.7554	4.7782	4.7554	4.8163
24	4.4201	4.5572	4.6639	4.6411	4.6716	4.7173
Max	**4.5877**	**4.6639**	**4.763**	**4.7782**	**4.7554**	**4.8163**
Min	**2.934**	**2.5225**	**3.3379**	**3.2922**	**3.0636**	**3.4065**
Avg	**3.6005**	**3.6758**	**3.9428**	**3.9009**	**3.8555**	**3.9571**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154001 / 33/11 KV MURUD
Feeder No / Name : 201 / 11 KV MURUD URBAN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.0212
2						1.0669
3						1.1126
4						1.1431
5	1.2651			1.6461	1.3394	1.2041
6	1.448			1.7147		1.6613
7	1.6004			1.8004		1.6766
8	1.3413			1.5775	1.6655	1.326
9	1.4327	1.3889	1.2041			
10	1.3643	1.1888	1.0974			1.3321
11			1.2041			
12	1.3146		1.1888			
13			1.1431			1.3032
14	1.3321		1.0974			
15		1.3203	1.1584			
16	1.2048	1.3546	1.5261			
17	1.2127		1.1736			
18	1.2269					
20	2.0351					
22	1.4022					
23	1.1888				1.2193	
24	1.8088		1.3169	1.2003	1.3306	1.0974
Max	**2.0351**	**1.3889**	**1.5261**	**1.8004**	**1.6655**	**1.6766**
Min	**1.1888**	**1.1888**	**1.0974**	**1.2003**	**1.2193**	**1.0212**
Avg	**1.4119**	**1.3132**	**1.2110**	**1.5878**	**1.3887**	**1.2677**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154001 / 33/11 KV MURUD
Feeder No / Name : 202 / 11 KV MURUD RURAL FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7316
2					.7468
3					.8383
5					1.1888
7					1.2803
8					1.2498
10	.8383	.8688	.8535		
11			1.1431		
12	1.0669		1.2803		
13			1.2955		
14	1.1736		1.2803		
15		1.1584	1.2193		
16	1.3108	1.2498	1.2346		
17	1.4723				
24				1.8309	.6401
Max	**1.4723**	**1.2498**	**1.2955**	**1.8309**	**1.2803**
Min	**.8383**	**.8688**	**.8535**	**1.8309**	**.6401**
Avg	**1.1724**	**1.0923**	**1.1867**	**1.8309**	**.9537**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154001 / 33/11 KV MURUD
Feeder No / Name : 203 / 11 KV DHORALA FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6249
2						.6097
3						.6859
4						.7621
5	.6097					.8993
6	.6401					.9145
7	.7926					.884
8	.8383				.9774	.8535
9	.8124	.823	.6097			
10	.68	.6706	.6859			.5487
11			.6706			
12	.9374		.6401			
13			.6097			.8993
14	.9755		.6249			
15		.945	.9602			
16	.9755	.945	.9145			
17	1.1462					
24			.5243	.6859	.4887	.381
Max	**1.1462**	**.945**	**.9602**	**.6859**	**.9774**	**.9145**
Min	**.6097**	**.6706**	**.5243**	**.6859**	**.4887**	**.381**
Avg	**.8408**	**.8459**	**.6933**	**.6859**	**.7331**	**.7330**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154001 / 33/11 KV MURUD
Feeder No / Name : 204 / 11 KV Gumphwadi FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0914
2						.0762
3						.0762
4						.0914
5	.0914			.1067		.1219
6	.1067			.1067		.1067
7	.1067			.1067		.1067
8	.1372			.1524	.1052	.1524
9	.1463	.0914	.1219			
10	.0924	.0762	.1219			.1715
11			.1829			
12	.181		.1524			
13			.1372			.2229
14	.1463		.0914			
15		.1219	.2134			
16	.1494	.1677	.1981			
17	.1254					
18	.0905					
19	***					
20	.1294					
21	.1086					
22	.0914					
23	.0914			.0943	.1219	
24	.1086		.0924	1.5946	.0943	.1067
Max	**62.2239**	**.1677**	**.2134**	**1.5946**	**.1219**	**.2229**
Min	**.0905**	**.0762**	**.0914**	**.0943**	**.0943**	**.0762**
Avg	**3.7722**	**.1143**	**.1457**	**.3602**	**.1071**	**.1204**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154001 / 33/11 KV MURUD
Feeder No / Name : 205 / 11 KV WATAWADA FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.4877
Max	.4877
Min	.4877
Avg	.4877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154001 / 33/11 KV MURUD
Feeder No / Name : 206 / 11 KV KARKATTA GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1067
2						.1067
3						.1219
4						.1677
5	.1829			.1981		.2134
6	.1981			.2134		.2134
7	.2439			.2134		.1981
8	.2286			.1981	.2328	.1829
9	.2614	.1372	.1677			
10	.1663	.0457	.1219			
11			.0914			
12	.1463		.0762			
13			.0914			
14	.1463		.0914			
15		.0914	.0914			
16	.1109	.061	.1067			
17	.1052					
18	.0724					
19	.2353					
20	.2427					
21	.2149					
22	.1372					
23	.0914				.1524	
24	.2353		.1109	.1029	.1294	.1372
Max	**.2614**	**.1372**	**.1677**	**.2134**	**.2328**	**.2134**
Min	**.0724**	**.0457**	**.0762**	**.1029**	**.1294**	**.1067**
Avg	**.1776**	**.0838**	**.1054**	**.1852**	**.1715**	**.1609**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154001 / 33/11 KV MURUD
Feeder No / Name : 207 / 11 KV KARKATTA-AG-FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0762
2						.0762
3						.0762
4						.0762
5				1.326		.0762
6	1.0822			1.4937		.0762
7	1.3413			1.5242		
8	1.3565			1.4632		
9	1.1431	1.3108				
22	.0914					
23	.0914				.0762	
24			.7926	.7926	1.8088	.0762
Max	**1.3565**	**1.3108**	**.7926**	**1.5242**	**1.8088**	**.0762**
Min	**.0914**	**1.3108**	**.7926**	**.7926**	**.0762**	**.0762**
Avg	**.8510**	**1.3108**	**.7926**	**1.3199**	**.9425**	**.0762**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154001 / 33/11 KV MURUD
Feeder No / Name : 208 / 11 KV GUMPHAWADI -AG- FEEDER Feeder KV- 11 / OUTGOING **FEEDER SEPERATION/PURE AG**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3048
2					.3201
3					.3201
4					.3353
5					.381
6					.4115
7					.4877
8					.4572
10	.4858	.503	.5487		
12	.503				
13			.6097		
14	.5335				
15		.503	.442		
16	.5944	.6249	.5639		
17	.7164				
24				1.2498	.2743
Max	**.7164**	**.6249**	**.6097**	**1.2498**	**.4877**
Min	**.4858**	**.503**	**.442**	**1.2498**	**.2743**
Avg	**.5666**	**.5436**	**.5411**	**1.2498**	**.3658**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154001 / 33/11 KV MURUD
Feeder No / Name : 209 / 11 KV HOSPITAL (SEPERATE) Feeder KV- 11 / OUTGOING
NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-APR-17
HR	Load (MW)
24	.3201
Max	.3201
Min	.3201
Avg	.3201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA
Feeder No / Name : 201 / 11 KV MURUD AKOLA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	1.5432	.823			.4908	
2	1.0364	1.5432	.8916			.4908	
3	1.1012	1.6278	1.0288			.5144	
4	1.166	1.9784				.6516	
5	1.2955	2.2801				.7716	
6	1.749	2.2542				.8916	
7	1.8138	2.2874				.9945	
8	1.8138	2.2874				.8573	
9	1.6842	2.3205				.2012	.6413
10	1.6842	1.9227	2.0119		.426		.4715
11		.3429			.426	2.1052	
12		.3086			.3647	2.2672	
13		.2915			.3315	2.2672	
14		.3086			.3018	1.9919	
15		.2915			.3018	2.0567	
16	.3018	.2915			.3429	2.1376	
17		.3086			.373	2.1862	
18					.4115		
19					.5487		
20					.6859		
21					.6001		
22					.5487		
23		.4908	.4858		.5144		
24	.4715			.4858	.5658		
Max	**1.8138**	**2.3205**	**2.0119**	**.4858**	**.6859**	**2.2672**	**.6413**
Min	**.3018**	**.2915**	**.4858**	**.4858**	**.3018**	**.2012**	**.4715**
Avg	**1.2574**	**1.2599**	**1.0482**	**.4858**	**.4495**	**1.3047**	**.5564**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA
Feeder No / Name : 202 / 11 KV BHOYRA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.6173	.583			.2103	
2	.5967	.6173				.2103	
3	.663	.5487				.2229	
4	.7293	.583				.2401	
5	.7956					.2743	
6	.8619	.9724				.2915	
7	1.0608	1.0395				.2915	
8	.9282	1.0898				.2401	
9	.9945	1.0395				.1715	.2829
10	.9282	.8718	.8718		.9393		.1698
11		.1029			.1543	.6478	
12		.0686			.1187	.8421	
13		.0857			.1187	.8421	
14		.0857			.1006	.8097	
15		.1029			.12	.8583	
16	.1132	.1029			.1029	.8907	
17		.1029			.12	.9717	
18					.1372		
19					.2058		
20					.2572		
21					.2058		
22					.2058		
23		.2103	.1543		.2058		
24	2.3765		.8718	.1658	.2641		
Max	**2.3765**	**1.0898**	**.8718**	**.1658**	**.9393**	**.9717**	**.2829**
Min	**.1132**	**.0686**	**.1543**	**.1658**	**.1006**	**.1715**	**.1698**
Avg	**.8815**	**.4848**	**.6202**	**.1658**	**.2171**	**.5009**	**.2264**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA
Feeder No / Name : 203 / 11 KV RAMEGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2401	
2		.1372		.2572	
3				.2572	
4				.3086	
5				.3429	
6				.3772	
7				.3772	
8				.4694	
9				.503	.5506
10			.3688		.4534
11		.4287	.3688		
12		.4458	.4694		
13		.4287	.4641		
14		.4287	.4641		
15		.3772	.431		
16	.5761	.4748	.4694		
17		.5765	.5365		
18			.5087		
Max	**.5761**	**.5765**	**.5365**	**.503**	**.5506**
Min	**.5761**	**.1372**	**.3688**	**.2401**	**.4534**
Avg	**.5761**	**.4122**	**.4534**	**.3481**	**.502**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA
Feeder No / Name : 204 / HT Chaitanya STEEL Feeder KV- 11 / OUTGOING
NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	03-APR-17
HR	Load (MW)
17	.168
Max	.168
Min	.168
Avg	.168

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S
Feeder No / Name : 201 / 11 KV GADWAD SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1765			1.1203	.905	.4525	.4477
2	1.6289				.9955	.4525	.4477
3	1.8099			1.2803	1.086	.4525	.4477
4	1.8099			1.6575	1.1641	.543	.5373
5	1.8099			1.8861	1.2536	.543	.5373
6	1.8099		1.7909	1.8861	1.4327	.4858	.5373
7	1.8099		1.97	1.8861	1.4327	.543	.6268
8	1.949		1.97	1.8861	1.6118	.6335	
9			1.7909	1.8861	1.6118	.6335	.6268
10			.3125	.362	.362	.7164	.4999
11			.3125	.362	.362	1.2536	1.3108
12		.4477	.3125	.362	.362	1.6118	1.4746
13		.4477		.362	.362	1.6118	1.1469
14		.4477		.362	.362	1.6118	
15			.2343	.362		1.6118	
16		.4477	.1543	.4525	.362	1.6118	
17		.4477	.3125	.4525	.4525		
18		.4477			.543		
19		.5373	.3125	.543	.6335		
20		.5373		.543	.6335		
21		.5373	.4687	.6335	.543		
22		.5373		.543	.543		
23		.4477	.2315	.4525	.543		
24	.724		.7164	.4687	.543	.4525	.4477
Max	**1.949**	**.5373**	**1.97**	**1.8861**	**1.6118**	**1.6118**	**1.4746**
Min	**.724**	**.4477**	**.1543**	**.362**	**.362**	**.4525**	**.4477**
Avg	**1.6142**	**.4803**	**.7778**	**.8977**	**.7869**	**.8953**	**.6991**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] **BU 5134**
Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S
Feeder No / Name : 202 / 11 KV JAWALA **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081		.08		.081	.1619	.16
2	.081		.08	.0772	.081	.1619	.16
3	.081		.08	.0772	.081	.2429	.2401
4	.081		.08	.0772	.081	.2429	.3201
5	.081		.08	.0772	.081	.3239	.3201
6	.081		.08	.0772	.081	.3239	.3201
7	.081		.08	.0772	.081	.3239	.3201
8	.081		.08	.0772	.081	.3239	.3201
9			.08	.0772	.081	.3239	.3201
10		.2401		.1619	.081	.08	.0772
11		.4001	.5468	.2429	.4001	.08	.0781
12		.4001	.6325	.4049	.4001	.08	.0781
13		.4001		.4049	.3201	.08	.0781
14		.4001		.4049	.3239	.08	
15		.4001	.6325	.4049		.08	
16		.4001	.6325	.4049	.4001	.08	
17		.4001	.6325	.4001	.3239		
18		.08		.081	.081		
19		.08	.0772	.081	.0324		
20		.08	.0772	.081	.081		
21		.08	.0772	.081	.081		
22		.08		.081	.081		
23		.08	.0772	.081	.0324		
24	.081		.08	.0772	.081	.081	.16
Max	**.081**	**.4001**	**.6325**	**.4049**	**.4001**	**.3239**	**.3201**
Min	**.081**	**.08**	**.0772**	**.0772**	**.0324**	**.08**	**.0772**
Avg	**.081**	**.2515**	**.2203**	**.1744**	**.1499**	**.1806**	**.2109**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S
Feeder No / Name : 203 / 11 KV MASLA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955			.9488	1.0402	.1619	.16
2	1.5384			.9602	1.1203	.1619	.16
3	1.6194			1.0802	1.1203	.1619	.16
4	1.7814			1.1336	1.2651	.1619	.16
5	1.7814		1.4403	1.2955	1.2803	.1619	.16
6	1.6194		1.6004	1.3108	1.3603	.1619	.16
7	.8097		1.6004	1.4918	1.3927	.1619	.16
8	1.4403			.4687	1.2803	.1619	.16
9			1.7604	1.3108	1.2803	.1619	
10		.16		.1619	.1619	.6401	.3125
11		.16	.1562	.1619	.1619	1.1203	1.3108
12		.16	.1562	.1619	.1619	1.2803	1.4746
13		.16	.1562	.1619	.1619	1.4403	1.3108
14		.16		.1619	.1619		
15		.16	.1562	.1619			
16		.16	.1562	.1619	.1619	1.4403	
17		.16	.1562	.1619	.1619		
18		.1543			.1619		
19		.16	.1543	.1619	.1619		
20		.16	.1543	.1619	.1619		
21		.16	.1543	.1619	.1619		
22		.16		.1619	.1619		
23		.16	.1543	.1619	.1619		
24	.8097		.6401	.3086	.4001	.1048	.16
Max	**1.7814**	**.16**	**1.7604**	**1.4918**	**1.3927**	**1.4403**	**1.4746**
Min	**.8097**	**.1543**	**.1543**	**.1619**	**.1619**	**.1048**	**.16**
Avg	**1.4106**	**.1596**	**.5731**	**.5397**	**.5932**	**.4989**	**.4499**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S
Feeder No / Name : 204 / 11 KV WANJARKHEDA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619		.16	.1543	.1619	.8097	.8002
2	.1619		.16	.1543	.1619	.8802	.9602
3	.1619		.16	.1543	.1619	.9602	1.2803
4	.1619		.16	.1543	.1619	1.2955	1.2803
5	.1619		.16	.1543	.1619	1.4403	1.2803
6	.1619		.16	.1543	.1619	1.4403	1.2803
7	.1619		.16	.1543	.1619	1.6004	1.2803
8	.1619			.1543	.1619	1.4403	1.4403
9				.1543		1.4403	
10		1.4403	.3125	.3239	.4049	.16	.1543
11		1.6004	1.4918	1.2955	1.4403	.16	.1562
12		1.7604	1.8861	1.4575	1.4403	.16	.1562
13		1.7604	1.8861	1.6194	1.4575		.1562
14		1.7604		1.6004	1.4403	.16	
15		1.7604	1.4918	1.6004		.16	
16		1.6004	1.4918	1.6004	1.3603	.16	
17		1.6004	1.4918	1.4403	1.2803		
18		.16		.16	.1619		
19		.16	.1543	.1619	.1619		
20		.16		.1619	.1619		
21		.16	.1543	.1619			
22		.16		.1619			
23		.1543	.1543	.1562	.1619		
24	.1619	.16	.16	.1543	.1619	.4858	.4801
Max	**.1619**	**1.7604**	**1.8861**	**1.6194**	**1.4575**	**1.6004**	**1.4403**
Min	**.1619**	**.1543**	**.1543**	**.1543**	**.1619**	**.16**	**.1543**
Avg	**.1619**	**.9598**	**.6553**	**.5602**	**.5464**	**.7971**	**.8235**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154028 / 33 KV S/S BOPLA
Feeder No / Name : 201 / 11 KV BOPLA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.1619	.1619		1.0526
10					1.1336
12		.1619			
14		.1457			
16		.1619			
18	.1943				
23	.1619				
24		.6478		1.1431	
Max	**.1943**	**.6478**	**.1619**	**1.1431**	**1.1336**
Min	**.1619**	**.1457**	**.1619**	**1.1431**	**1.0526**
Avg	**.1781**	**.2558**	**.1619**	**1.1431**	**1.0931**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154028 / 33 KV S/S BOPLA
Feeder No / Name : 202 / 11 KC CHATA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			1.2146			.1943
10			1.3765			.1943
12		1.3765				
14		1.2955				
16		1.1012				
18	1.2955					
23	.1943					
24				.5335	.5796	
Max	**1.2955**	**1.3765**	**1.3765**	**.5335**	**.5796**	**.1943**
Min	**.1943**	**1.1012**	**1.2146**	**.5335**	**.5796**	**.1943**
Avg	**.7449**	**1.2577**	**1.2956**	**.5335**	**.5796**	**.1943**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154028 / 33 KV S/S BOPLA
Feeder No / Name : 203 / 11 KV EKURGA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.2591	.2915			.2591
10			.2429			.2591
14		.2429				
16		.2591				
18	1.2955					
23	1.1336					
24		.2267		.6859	.7964	
Max	**1.2955**	**.2591**	**.2915**	**.6859**	**.7964**	**.2591**
Min	**1.1336**	**.2267**	**.2429**	**.6859**	**.7964**	**.2591**
Avg	**1.2146**	**.2470**	**.2672**	**.6859**	**.7964**	**.2591**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154028 / 33 KV S/S BOPLA
Feeder No / Name : 204 / 11kv MBF Express **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			.0324		.0324
10			.0324		.0324
12		.0972			
14		.0324			
16		.0324			
18	.0324				
23	.0324				
24				.381	
Max	**.0324**	**.0972**	**.0324**	**.381**	**.0324**
Min	**.0324**	**.0324**	**.0324**	**.381**	**.0324**
Avg	**.0324**	**.054**	**.0324**	**.381**	**.0324**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S
Feeder No / Name : 201 / 11 KV Shirala Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3987	.4818	.3987		.4486		1.0633
2	.3987	.4652	.3987				1.0799
3	.4153	.5649	.4984		.4984		1.1297
4	.5981		.731				1.2626
5	.8473		.7974			1.2626	1.4121
6	.9968		.9303				1.5284
7	.8805		.9137			1.8773	2.0434
8	.8141		.8307				2.0434
9			.5944			1.8441	
10	1.3457		1.0364				
11	1.7776	1.761		1.5783	1.5949		
12	1.5284	1.7112		1.8275	1.7776	.2824	
13	1.6281	1.6613		1.7112	1.5949		
14	1.5783	1.5783	.442	1.6779	1.6613	.2492	
15	1.5783	1.5284	1.4937	1.4121	1.5949	.2492	
16	1.6613	1.4287	1.5851	1.6613	1.6946	.2824	
17	1.6613	1.6613	1.8275	1.5949	.2824	.2492	
18		.3323	1.326		.2824	.299	
19	.5944	.6645	1.0059	.6811	.6313	.6313	
20	.5792	.6645	.6249	.8639	.7808	.8639	
21	.5487	.6147	.5792	.6313	.6811	.6147	
22	.503	.5316	.503	.5482	.5316	.5316	
23	.4572	.4652		.4486	.4153	.4319	
24		.4319		.9602	.9802		1.0466
Max	**1.7776**	**1.761**	**1.8275**	**1.8275**	**1.7776**	**1.8773**	**2.0434**
Min	**.3987**	**.3323**	**.3987**	**.4486**	**.2824**	**.2492**	**1.0466**
Avg	**.9900**	**.9733**	**.8693**	**1.1997**	**.9656**	**.6906**	**1.4010**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S
Feeder No / Name : 202 / 11 KV Chincholi B Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.307	.2986	.3393	1.8595	1.9333		.1257
2	.2908	.2986	.3554	1.89	1.9962		
3	.307	.2829	.3231	1.9509	2.0748		
4	.3231	.3144	.3554	1.9509	2.0905		.1886
5	.3554	.3772	.4039	2.1643			.2829
6	.4201		.727		2.672		.3144
7		.6287	.727	.9145	2.6249	.4039	.3301
8	.6624	.613	.6624	2.774	2.6406		.2515
9	.5493	.5658		2.4557	2.8292		
10	.0048		.0076				
11	.0048	.0047			.1257	2.9081	
12	.0065	.0063	.0762		.0786	2.5204	
13	.0065	.0063	1.6766	.0969	.0943		
14	.0065	.0063	.0762	.0808	.0786	2.2295	
15	.0065	.0063	.0914	.0969	.0786	2.585	
16	.0081	.0063	.0914	.0969	.0786		
17	.0076	.0081	.1067	.0786	.0646	2.5306	
18	.0076	.0081	.0914	.1257	.0969	.0943	
19	.0076	.0081	.3048	.2358		.2043	
20	.0076	.0081	.3201	.3144	.2908	.2829	
21	.0061	.0065	.2896	.2043	.1616	.2201	
22	.0061	.0065	.2134	.1886	.1454	.1572	
23	.0061	.0081	.1372	.1729	.1454	.1415	
24		.3231		1.6461	1.6818		.1415
Max	**.6624**	**.6287**	**1.6766**	**2.774**	**2.8292**	**2.9081**	**.3301**
Min	**.0048**	**.0047**	**.0076**	**.0786**	**.0646**	**.0943**	**.1257**
Avg	**.1503**	**.1724**	**.3512**	**.9649**	**1.0468**	**1.1898**	**.2335**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S
Feeder No / Name : 203 / 11 KV Wadiwagholi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2631	1.247	1.6356
2	1.2631	1.2631	1.6194
3	1.2308	1.2308	1.3603
4	1.3603	1.3765	
5	1.6518	1.7166	
6	2.0243	2.0729	
7	2.2024	2.2186	
8	2.17	2.1214	
9	1.6518	1.8785	
10	.1781		
11		.0972	
12		.0972	
13		.081	
16		.081	
17		.0648	
18		.0972	
19		.2429	
20	.1981	.2915	
21	.1829	.2267	
22	.1677	.1943	
23	.1372	.1619	
24		1.3765	
Max	**2.2024**	**2.2186**	**1.6356**
Min	**.1372**	**.0648**	**1.3603**
Avg	**1.1201**	**.8637**	**1.5384**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S
Feeder No / Name : 204 / 11 KV WATER WORKS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)
1		.6097
2		.5716
3		.5335
4		.5716
5		.6097
6		.7049
7		.8764
8		.8573
14	.7049	
15	.8954	
16	.9907	
17	1.2955	
18	1.1812	
20	.7049	
21	.743	
22	.8383	
23	.7811	
24		.7049
Max	**1.2955**	**.8764**
Min	**.7049**	**.5335**
Avg	**.9039**	**.6711**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S
Feeder No / Name : 205 / 11kv AADI AGRO Exp Fed NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0803	.0802	.0928	.0671	.0855		.0802
2	.0821	.0784	.0893	.064	.0891		.0819
3	.0785	.0819	.0857	.0671	.0855	.075	.0802
4	.0857	.0819	.0143	.0732	.0873	.0714	.0784
5	.0857	.0855	.0857	.0732	.0819	.0803	.0784
6	.0946	.0855	.0875	.0762	.0802	.0357	.0766
7	.0964	.0926	.0678	.1097	.0784	.0607	.0784
8	.0946	.0926	.0785	.1128	.0784	.0785	.0784
9	.1125	.0926	.0762	.1392	.0855	.0839	
10	.1321		.0701	.1321		.0821	
11	.15	.1283		.1392	.1158	.1285	
12	.1607	.1674	.1341	.1589	.1568	.1375	
13	.1642	.1657	.1311	.1607	.1603		
14	.1696	.1603	.1616	.1642	.1461		
15	.1767	.1568	.1585	.15	.1427		
16	.1553	.1639	.1494	.1428	.1444	.1821	
17	.1341	.1571	.1433	.1461	.1464	.1728	
18	.125	.1607	.1158	.1354	.0821	.1283	
19	.1006	.1625	.0884	.1318	.0714	.1033	
20	.0914	.1196	.0995	.1283		.0748	
21	.0869	.0857	.0869	.0837	.0821	.0784	
22	.0701	.1089	.0854	.0855		.0784	
23	.0701	.0928	.0854	.0855		.0748	
24		.0946		.0671	.0803		.0748
Max	**.1767**	**.1674**	**.1616**	**.1642**	**.1603**	**.1821**	**.0819**
Min	**.0701**	**.0784**	**.0143**	**.064**	**.0714**	**.0357**	**.0748**
Avg	**.1129**	**.1172**	**.0994**	**.1122**	**.1040**	**.0959**	**.0786**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S
Feeder No / Name : 201 / 11 KV Takalgaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8573	.4572	.4144		.5716
16		1.4403		.2486	
24		.4572	.4239		1.2803
Max	**.8573**	**1.4403**	**.4239**	**.2486**	**1.2803**
Min	**.8573**	**.4572**	**.4144**	**.2486**	**.5716**
Avg	**.8573**	**.7849**	**.4192**	**.2486**	**.9260**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S
Feeder No / Name : 202 / 11 KV Pimpalgaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3108	.0848	1.8842		.1677
16	.1905	.0953		1.406	
24		.7316	.1905		.2858
Max	**1.3108**	**.7316**	**1.8842**	**1.406**	**.2858**
Min	**.1905**	**.0848**	**.1905**	**1.406**	**.1677**
Avg	**.7507**	**.3039**	**1.0374**	**1.406**	**.2268**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S
Feeder No / Name : 203 / 11 KV Tandulja Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8573	2.9959	.9526		2.6578
16		.7621		.7621	
24		.9431	2.1548		.8573
Max	**.8573**	**2.9959**	**2.1548**	**.7621**	**2.6578**
Min	**.8573**	**.7621**	**.9526**	**.7621**	**.8573**
Avg	**.8573**	**1.5670**	**1.5537**	**.7621**	**1.7576**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S
Feeder No / Name : 202 / 11 KV Chikurda Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.4915	.4801	.4752	.5243	.1696	
2	.4588	.5243	.5121		.6554	.1311	
3	.5898	.6554	.6401		.7537	.1311	
4	.6882	.6882	.7449		.7865	.1311	
5	.8029	1.0486	.8421		.8192	.1638	
6	.8848	1.1142	1.0526		.852	.1966	
7	.9831	1.1797	1.1043		1.2125	.2294	
8	1.0978	1.1797			1.2944	.2012	
9	1.1469	1.1469	1.1822		1.3435	.1638	
10	.0983	.6478	.1107	.1638			
11	.0819	.081		.112	.0983		
12	.0819	.08	.0633	.112	.0983		
13	.0819	.064	.0791	.08	.0983		
14	.0819	.081	.0949	.064	.0983		
15	.0819	.081		.064	.1311		
16		.081	.0316	.08	.0983		
17	.0819	.081	.0949	.0983	.0983		
18	.0983	.0972	.1107	.096	.1475		
19	.1311	.1457	.2372		.1638		.2294
20	.1966	.208	.2688		.2294		.1966
21	.2294	.2105	.2214		.2294		.1638
22	.2294	.1943	.1739		.1966		.1638
23	.1966	.16	.1423		.1966		.128
24	.2949	.426	1.1683	.3521	.3605	.1638	
Max	**1.1469**	**1.1797**	**1.1822**	**.4752**	**1.3435**	**.2294**	**.2294**
Min	**.0819**	**.064**	**.0316**	**.064**	**.0983**	**.1311**	**.128**
Avg	**.3918**	**.4445**	**.4455**	**.1543**	**.4559**	**.1682**	**.1763**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S
Feeder No / Name : 203 / 11 Kv Samangaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S
Feeder No / Name : 204 / 11 KV Natural FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	31-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)
10		.0191
11		.0191
12		.0191
13	.0191	.0191
14	.0191	.0191
15	.0191	.0191
16	.0191	.0191
17	.0191	.0191
18	.0191	.0191
20	.0191	
21	.0191	
22	.0191	
23	.0191	
24		.0191
Max	**.0191**	**.0191**
Min	**.0191**	**.0191**
Avg	**.0191**	**.0191**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S
Feeder No / Name : 201 / 11 KV Ankoli Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5						1.073	
6	2.2634	2.1195					
7			2.6825	2.5604			
8				2.5774		.5533	.78
9			2.5095		2.2891	.6706	.6274
12	.1677						
14		.1844					
16						2.1874	
17					.2347		2.3739
18		.3521					
20		.8048					
22					.6036		
23	.5365						
24			1.3077	.5087	.6687		.4409
Max	**2.2634**	**2.1195**	**2.6825**	**2.5774**	**2.2891**	**2.1874**	**2.3739**
Min	**.1677**	**.1844**	**1.3077**	**.5087**	**.2347**	**.5533**	**.4409**
Avg	**.9892**	**.8652**	**2.1666**	**1.8822**	**.9490**	**1.1211**	**1.0556**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S
Feeder No / Name : 202 / 11 KV Utti Tawarja Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6859
2							.7621
3							.6859
4							.6859
5						.7545	.7621
6	.3353	.3353				.8048	.8383
7			.3521	.3391			.9907
8				.3052		1.2407	2.6011
9			.2035		.2204	1.1401	2.4655
10							1.2193
11							.7621
12	.9496						.0762
13							.0762
14		.8551					.0762
16			.763			.1017	
17					.9389		.1949
18		.0838					.0762
19							.0762
20		.2515					.1524
21							.2286
22					.1677		
23	.1677						.2035
24			.1509	.1696			.5765
Max	**.9496**	**.8551**	**.763**	**.3391**	**.9389**	**1.2407**	**2.6011**
Min	**.1677**	**.0838**	**.1509**	**.1696**	**.1677**	**.1017**	**.0762**
Avg	**.4842**	**.3814**	**.3674**	**.2713**	**.4423**	**.8084**	**.6760**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S
Feeder No / Name : 203 / 11 KV SAWARGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5						1.9784	
6	.5365	.6706				1.9784	
7			.57	.6274			
8				.5935		2.2634	2.4247
9					.39	2.2634	2.2382
12	2.431						
14		2.146					
16			2.2891			.1187	
17					2.1293		
18		.1677					
20		.4694					
22					.3185		
23	.2515						.3391
24			.2515	.2035			1.2209
Max	**2.431**	**2.146**	**2.2891**	**.6274**	**2.1293**	**2.2634**	**2.4247**
Min	**.2515**	**.1677**	**.2515**	**.2035**	**.3185**	**.1187**	**.3391**
Avg	**1.073**	**.8634**	**1.0369**	**.4748**	**.9459**	**1.7205**	**1.5557**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] **BU 5134**
Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S
Feeder No / Name : 204 / 11 KV WATER WORKS EXP **NON SHEDDABLE WATER SUPPLY AND**
Feeder KV- 11 / OUTGOING **UTILITY**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5						.0168	
6	.0168	.0168				.0168	
7			.0168	.017	.017		
8				.017		.0168	.017
9			.017		.017	.0168	.017
12	.0168						
14		.0168					
16			.017			.017	
17					.0168		.017
18		.0168					
20		.0168					
22					.0168		
23	.0168						.017
24			.0168	.017	.017		.017
Max	**.0168**	**.0168**	**.017**	**.017**	**.017**	**.017**	**.017**
Min	**.0168**	**.0168**	**.0168**	**.017**	**.0168**	**.0168**	**.017**
Avg	**.0168**	**.0168**	**.0169**	**.017**	**.0169**	**.0168**	**.017**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154086 / 33 KV S/S NIVALI
Feeder No / Name : 201 / 11 KV KARKHANA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1469		1.7394	1.5089	1.7394		.3734
2	1.6385		1.7966	1.6385	1.7966		.3696
3	1.7204		1.8747	2.1548	1.8747		3.7902
4	1.8842		2.0557	2.3205	1.8519		.4066
5	2.13		2.2377	2.4577	2.0062		.4668
6	2.3758		2.2862	2.6216	2.1338		.6908
7	2.4577		2.5911	2.915	2.5149		.7468
8	2.5396		.503		2.372		
9	2.3758	2.4806		2.5149	2.1862		.5975
10	.3772	.5249	.4715	.4715		2.1548	1.1022
11		.4572	.3772	.3696		2.5911	2.7035
12	.3109	.3658	.2829	.3109		2.652	
13		.3326	.3206	.2743		2.7854	
14		.2772	.3206	.2715		2.3758	
15		.3326	.2829	.2715		2.4291	
16	.362	.3326	.2715	.3658		2.5396	
17		.2743	.2829	.2772		2.7183	
18		.3696	.4115	.3658		.2374	
19	.6767	.6535	.6859	.7392		.4525	
20		.7762	.7202	.6468		.7316	
21		.6468	.4287	.6401		.7468	
22	.6099	.5601	.3772	.5975		.5975	
23		.5601	1.4918	.5601		.4854	
24	.8288	1.7857	1.6604	1.4918	1.6604	.3772	.4108
Max	**2.5396**	**2.4806**	**2.5911**	**2.915**	**2.5149**	**2.7854**	**3.7902**
Min	**.3109**	**.2743**	**.2715**	**.2715**	**1.6604**	**.2374**	**.3696**
Avg	**1.4290**	**.6706**	**1.0204**	**1.1211**	**2.0136**	**1.5916**	**1.0598**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154086 / 33 KV S/S NIVALI
Feeder No / Name : 202 / 11 KV NIVALI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.3772	.3772	.3772		1.1869
2	.3772		.3772	.3772	.3772		1.1736
3	.3772		.3772	.3772	.415		1.1603
4	.4382		.4715	.4715	.4668		1.2763
5	.5658		.6535	.5658	.5601		1.4918
6	.7545		.8402	.7545	.8402		1.8233
7	.8488		.8402	.811	.8402		2.13
8	.7545		.5601		.8402		
9	.5658	.5201		.5658	.6401	1.5565	1.873
10	1.2289	.8478	1.286	1.0059		.2743	.3391
11		.9945	1.4746	1.6804		.1829	.2263
12	1.7187	1.6004	1.6575	1.7814	1.0802	.1629	
13		1.5203	1.5089	1.6804		.1448	
14		1.4403	1.4746	1.5813		.1829	
15		1.3765	1.6385	1.0774		.1991	
16	1.5775	1.4746	1.7204	1.7204		.1829	
17		1.5684	1.7404	1.7695		.1991	
18		.2241	.2743	.2801			
19	.5068	.4715	.6859				
20		.7545	.703	.7468		.8048	
21		.6036	.6602	.6602		.6348	
22	.4572	.4715	.5144	.4715		.5544	
23		.3772	.3772	.3772		.3734	
24	.3584	.3391	.3772	.3772	.3772	.9326	1.1488
Max	**1.7187**	**1.6004**	**1.7404**	**1.7814**	**1.0802**	**1.5565**	**2.13**
Min	**.3584**	**.2241**	**.2743**	**.2801**	**.3772**	**.1448**	**.2263**
Avg	**.7271**	**.9115**	**.8952**	**.8868**	**.6195**	**.4561**	**1.2572**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154086 / 33 KV S/S NIVALI
Feeder No / Name : 203 / 11 KV DHAKNI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566		.0754	.0943	.0943		.6516
2	.0566		.0754	.0943	.0943		.6371
3	.0566		.0754	.0943	.0943		.6706
4	.0701		.1132	.1132	.112		.663
5	.1509		.1867	.1509	.1848		.6962
6	.2829		.2987	.2263	.2772		.8288
7	.3206		.3326	.2829	.2987		1.065
8	.2641		.2801		.2614		
9	.1886	.1753		.1698	.2614	.8907	.9945
10	.6706	.6554	.8288	.6706			.1029
11		.8097	.9831	.9831			
12	1.0341	.9488	1.0059	.8802	1.0749	.0532	
13		.9488	1.0059	.9374		.0543	
14		.9374	.9339	.8592		.0554	
15		.8592	1.0059	.8697		.0543	
16	1.0277	.9488	1.0059	.9717		.0549	
17		1.0155	.9945	1.0402		.0532	
18		.0934	.0686	.1109		.0543	
19	.1595	.1886	.1372	.1867		.1463	
20		.2427	.1715	.2614		.2172	
21		.1867	.1372	.1867		.1848	
22	.1417	.1494	.1029	.132		.168	
23		.132	.1029	.0943		.112	
24	.0566	.1029	.0943	.1132	.0943	.39	.5935
Max	**1.0341**	**1.0155**	**1.0059**	**1.0402**	**1.0749**	**.8907**	**1.065**
Min	**.0566**	**.0934**	**.0686**	**.0943**	**.0943**	**.0532**	**.1029**
Avg	**.3025**	**.5247**	**.4355**	**.4141**	**.2589**	**.1778**	**.6903**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154102 / 33/11 KV RAMEGAON
Feeder No / Name : 201 / 11 KV RAMEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4							.2134
7	.9934			.9179	1.0265	.4554	
8	.9592		1.0169	.6112	1.0596	.3416	.3048
9				.9168			
10		.7983	.7353		.8332	.1524	.1372
11		.1132	.1225	.1711	.1141		.8557
12		.1136		.1521	.1903		.7955
13		.1133	.0919		.1132	.9259	
14		.1135			.1134		
15		.1132				.0857	
16			.1072	.1328		.823	
17			.0919	.1328	.1134	.9259	
18			.1225	.1708	.1523	.9602	
19			.2604		.2665		
20		.4187	.3056				
21			.2445				
24	.2134	1.0631		.1836			.1829
Max	**.9934**	**1.0631**	**1.0169**	**.9179**	**1.0596**	**.9602**	**.8557**
Min	**.2134**	**.1132**	**.0919**	**.1328**	**.1132**	**.0857**	**.1372**
Avg	**.722**	**.3559**	**.3099**	**.3766**	**.3983**	**.5838**	**.4149**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154102 / 33/11 KV RAMEGAON
Feeder No / Name : 202 / 11 KV CHINCHOLI (B) SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4							1.5089
7	.5704			.2604	.5503	1.6961	
8	.4378		.4183	.3362	.3795	1.7531	1.7833
9				.275			
10		.0188	.0919		.3027	1.5432	1.3905
11		1.5665	1.4399	1.5563	1.5294		.2139
12		1.6683		1.755	1.6404		.2139
13		1.6363	1.348		1.5187	.061	
14		1.7945			1.4592		
15		1.5473				.1829	
16			1.5318	1.6556		.2058	
17			1.5318	1.7384	1.6309	.1219	
18			1.3786	1.6225	1.6994	.2058	
19			.3973		.3803		
20		.5704	.4902				
21			.4126				
22						.4801	
24	.0335	.4268		.3366			.3772
Max	**.5704**	**1.7945**	**1.5318**	**1.755**	**1.6994**	**1.7531**	**1.7833**
Min	**.0335**	**.0188**	**.0919**	**.2604**	**.3027**	**.061**	**.2139**
Avg	**.3472**	**1.1536**	**.9040**	**1.0596**	**1.1091**	**.6944**	**.9146**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] **BU 5134**
Substation No/ Name :- 154102 / 33/11 KV RAMEGAON
Feeder No / Name : 203 / 11 KV GONDEGAN **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4							.2401
7	2.3344			1.6349	2.3013	.3613	
8	2.4669		1.5008	1.528	2.6821	.1513	.3429
9				1.2682			
10		1.3857	1.302		1.4954	.061	.0765
11		.0945	.0153	.0759	.1143		1.5146
12		.0756		.0759	.1142		1.6044
13		.0757			.1134		
14		.0566			.0754		
15		.0568				1.5432	
16				.0569		1.6804	
17			.0613	.0759	.0758	1.749	
18			.0919	.1708	.1332	1.6804	
19			.2139		.2094		
20		.2852	.2598				
21			.1836				
22						.1715	
24	.1219	1.5775		.1683			.1372
Max	**2.4669**	**1.5775**	**1.5008**	**1.6349**	**2.6821**	**1.749**	**1.6044**
Min	**.1219**	**.0566**	**.0153**	**.0569**	**.0754**	**.061**	**.0765**
Avg	**1.6411**	**.4510**	**.4536**	**.5616**	**.7315**	**.9248**	**.6526**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154109 / 33/11 KV JAWALA
Feeder No / Name : 201 / 11 KV JAWALA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.5944
Max	.5944
Min	.5944
Avg	.5944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154109 / 33/11 KV JAWALA
Feeder No / Name : 202 / 11 KV BODKA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
MURURD (R) S/DN[421] BU 5134
Substation No/ Name :- 154109 / 33/11 KV JAWALA
Feeder No / Name : 203 / 11 KV DHOKI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S
Feeder No / Name : 201 / 11 Kv Renapur-I SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8573		.6859	
16	.7716	.7716	.6859	.8573
24		.4287		.4287
Max	.8573	.7716	.6859	.8573
Min	.7716	.4287	.6859	.4287
Avg	.8145	.6002	.6859	.643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S
Feeder No / Name : 202 / 11 Kv Mahapur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0288		.5144	
16	1.6289	1.6289	1.8861	1.6289
24		.5144		.4287
Max	**1.6289**	**1.6289**	**1.8861**	**1.6289**
Min	**1.0288**	**.5144**	**.5144**	**.4287**
Avg	**1.3289**	**1.0717**	**1.2003**	**1.0288**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S
Feeder No / Name : 203 / 11 KV HANMANTWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.4006		1.6289		
16	.6001	.5144	.7716	.6859	2.3148
24		.8573		.8573	
Max	**2.4006**	**.8573**	**1.6289**	**.8573**	**2.3148**
Min	**.6001**	**.5144**	**.7716**	**.6859**	**2.3148**
Avg	**1.5004**	**.6859**	**1.2003**	**.7716**	**2.3148**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S
Feeder No / Name : 204 / 11 Kv Samsapur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1145		.6001		
16	1.8004	1.7147	1.5432	1.3717	.6001
24		.5144		.4287	
Max	**1.8004**	**1.7147**	**1.5432**	**1.3717**	**.6001**
Min	**1.1145**	**.5144**	**.6001**	**.4287**	**.6001**
Avg	**1.4575**	**1.1146**	**1.0717**	**.9002**	**.6001**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S
Feeder No / Name : 205 / 11 Kv Phata SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4287		.4287			
16	.3429	.3429	.2572			.2572
24		.2572		.2572	.0257	
Max	.4287	.3429	.4287	.2572	.0257	.2572
Min	.3429	.2572	.2572	.2572	.0257	.2572
Avg	.3858	.3001	.3430	.2572	.0257	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S
Feeder No / Name : 206 / 11 Kv Renapur-II SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9431		.9431	
16	.3429		.3429	.4287
24		.7716		.9431
Max	.9431	.7716	.9431	.9431
Min	.3429	.7716	.3429	.4287
Avg	.643	.7716	.643	.6859

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN
Feeder No / Name : 201 / 11 Kv Poharegaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.3772			
5		.5228					
6			.5182			1.1203	1.406
7						1.4243	1.5586
8						1.3441	1.7071
10				1.3108	1.1001		.2353
12		1.6156	1.5394		1.5797		.2075
15				1.5891			
16	1.7004		1.7375				
17				1.6502	1.0722		
18				.2139			
19	.5228						
20			.4938		.5601	.4115	
21		.5316					
23				.275			
24	.2139	.3018	.2915	.3361	.2139	.8907	.7773
Max	**1.7004**	**1.6156**	**1.7375**	**1.6502**	**1.5797**	**1.4243**	**1.7071**
Min	**.2139**	**.3018**	**.2915**	**.2139**	**.2139**	**.4115**	**.2075**
Avg	**.8124**	**.7430**	**.9161**	**.8218**	**.9052**	**1.0382**	**.9820**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN
Feeder No / Name : 202 / 11 Kv Shera SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.2641			
5		.3018					
6			.4409			.4534	.57
7						.7287	.8453
8						.7935	.8288
10				.6173	.5221		.2353
12		.4049	.3906		.7773	.1086	.132
15				.6142			
16	.6882	.7621	.7011				
17				.6449	.8745		
18				.1536			
19	.2896						
20			.3734		.3361	.3772	
21		.333					
23				.215			
24	.1382	.1698	.1886	.1886	.1382		.3052
Max	**.6882**	**.7621**	**.7011**	**.6449**	**.8745**	**.7935**	**.8453**
Min	**.1382**	**.1698**	**.1886**	**.1536**	**.1382**	**.1086**	**.132**
Avg	**.372**	**.3943**	**.4189**	**.3854**	**.5296**	**.4923**	**.4861**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN
Feeder No / Name : 203 / 11 Kv Bhokaramba SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				2.0302			
5		1.8023					
6			2.2405			1.8484	1.7635
8			1.7394				
9	2.4112						
10				.8316	.93		2.0081
12			.462		.4338	2.4939	2.5149
15				.2756			
16	.4904						
17				.31	.4904		
18				.775			
19	1.307						
20			1.6461		1.6221	1.4575	
21		1.2517					
23				.8612			
24	1.3606	1.4083	1.3916	1.5261	.1827	.7922	.7602
Max	**2.4112**	**1.8023**	**2.2405**	**2.0302**	**1.6221**	**2.4939**	**2.5149**
Min	**.4904**	**1.2517**	**.462**	**.2756**	**.1827**	**.7922**	**.7602**
Avg	**1.3923**	**1.4874**	**1.4959**	**.9442**	**.7318**	**1.648**	**1.7617**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN
Feeder No / Name : 201 / 11kv Khalangri SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)
16	.1879	
24		.9393
Max	.1879	.9393
Min	.1879	.9393
Avg	.1879	.9393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN
Feeder No / Name : 202 / 11 Kv Karepur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)
16	2.8435	
24		.3981
Max	2.8435	.3981
Min	2.8435	.3981
Avg	2.8435	.3981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN
Feeder No / Name : 203 / 11 Kv Ghodala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)
16	.0871	
24		.1915
Max	.0871	.1915
Min	.0871	.1915
Avg	.0871	.1915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN
Feeder No / Name : 204 / 11KV W/W NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	31-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)
16	.0472	
24		.0314
Max	.0472	.0314
Min	.0472	.0314
Avg	.0472	.0314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN
Feeder No / Name : 201 / 11 Kv Sindhgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5775		1.5432	.1475			
10							.9431
16	.1543		.1543	.1715			
24		.7888	.6859		.7716	.2572	
Max	**1.5775**	**.7888**	**1.5432**	**.1715**	**.7716**	**.2572**	**.9431**
Min	**.1543**	**.7888**	**.1543**	**.1475**	**.7716**	**.2572**	**.9431**
Avg	**.8659**	**.7888**	**.7945**	**.1595**	**.7716**	**.2572**	**.9431**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN
Feeder No / Name : 202 / 11 Kv Niwada SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6173		.6516	.6001		
16	1.5089	1.4575	1.2346	1.5089		
24		.3601	.3772		.2743	.6516
Max	**1.5089**	**1.4575**	**1.2346**	**1.5089**	**.2743**	**.6516**
Min	**.6173**	**.3601**	**.3772**	**.6001**	**.2743**	**.6516**
Avg	**1.0631**	**.9088**	**.7545**	**1.0545**	**.2743**	**.6516**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN
Feeder No / Name : 203 / 11 KV Express Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.0343	.0857		.0686	
24		.0514	.0857		.12
Max	.0343	.0857	.0857	.0686	.12
Min	.0343	.0514	.0857	.0686	.12
Avg	.0343	.0686	.0857	.0686	.12

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154057 / 33/11 KV PALSI S/S
Feeder No / Name : 201 / 11 Kv Palsi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7034	.6363	.6142	.6889	.4024	.397
2	.7301	.6889	.6211	.708	.3894	.3856
3	.74	.6927	.6325	.708	.4077	.4077
4	.7545	.7034	.6554	.727	.4572	.455
5	.8147	.8634	.727	.7758	.583	.6104
6	1.1294	1.1469	1.0044	.9549	1.0082	.8192
7	1.669	1.6819	1.5988	1.531	.6272	
8	1.5524	1.6857	1.5813	1.6088		
9	1.5592	1.5455	1.4883	1.5516		
10	.9922	1.4076	1.3916	1.3596	.6981	.4275
11	.5022	.5251	.4351	.551	1.1385	1.2087
12	.3155	.3506	.3368	.3582	.9236	1.1637
13	.2522	.3727	.2926	.2911	1.0014	1.1195
14	.2926	.3163	.3201	.2995	1.0517	1.0943
15	.2812	.3254	.3376	.2987	.9534	1.0395
16	.2911	.3208	.317	.3307	1.1431	1.1248
17	.2759	.3285	.3231	.3506	1.246	1.2216
18	.1928	.3582	.3498	.0815	1.278	1.1972
19	.6394	.6752	.6813	.5761	.5975	.5083
20	1.0227	1.0639	.9976	1.0486	.9092	.9054
21	.9534	.9145	.9061	.9656	.8223	.8551
22	.6927	.6843	.6592	.6821	.6554	.6661
23	.5152	.5182	.5121	.5205	.5495	.5159
24	.4374	.4435	.5708	.4504	.4473	.4504
Max	**1.669**	**1.6857**	**1.5988**	**1.6088**	**1.278**	**1.2216**
Min	**.1928**	**.3163**	**.2926**	**.0815**	**.3894**	**.3856**
Avg	**.7212**	**.7604**	**.7231**	**.7258**	**.7859**	**.7892**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154057 / 33/11 KV PALSI S/S
Feeder No / Name : 203 / 11 Kv Garsoli SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4824	.5327	.6059	.1825	.1768
2	.5102	.5034	.4877	.5597	.181	.1802
3	.5495	.511	.5068	.5811	.1966	.1882
4	.5578	.5171	.5365	.5662	.221	.234
5	.6055	.583	.5929	.6386	.2797	.3254
6	.7034	.687	.6954	.8055	.338	.3631
7	.8893	.9328	.9922	.988		
8	.6771	.9675	.9579	.9949		
9	.7994	.8703	.8794	.8631		
10	.5456	.439	.8493	.7308		.3281
11	.0987	.1821	.1395	.1558	.3688	.82
12	.1219	.0903	.1166	.117	.7983	.8345
13	.0918		.1063	.1174	.8371	.7971
14	.0975		.0968	.1162	.8379	.767
15	.0964	.0183	.1109	.0412	.7731	.7468
16		.1155	.1097		.8451	.7876
17		.1341	.1147		.841	.8379
18		.1814	.1623	.0236	.7853	.8215
19		.2382	.2435	.0747	.2256	.2572
20	.3704	.3536	.3643	.3841	.3768	.3666
21	.3506	.3483	.3292	.3677	.354	.3601
22	.2858	.2698	.2667	.2865	.2812	.2599
23	.2332	.2362	.2221	.2492	.2401	.2191
24	.2069	.3746	.5464	.2141	.1978	.1947
Max	**.8893**	**.9675**	**.9922**	**.9949**	**.8451**	**.8379**
Min	**.0918**	**.0183**	**.0968**	**.0236**	**.181**	**.1768**
Avg	**.4143**	**.4107**	**.4150**	**.4310**	**.4580**	**.4698**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S
Feeder No / Name : 201 / 11 Kv Kharola SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6401		.3807		
16		1.1736	1.3717		1.2003
24	.5639	.2462	.6001	.6001	.2389
Max	**.6401**	**1.1736**	**1.3717**	**.6001**	**1.2003**
Min	**.5639**	**.2462**	**.3807**	**.6001**	**.2389**
Avg	**.602**	**.7099**	**.7842**	**.6001**	**.7196**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S
Feeder No / Name : 202 / 11 Kv Kumbharwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9297		1.0105		
16		.0762	.1372		.1543
24	.3201	.2808	.0377	.3772	.189
Max	.9297	.2808	1.0105	.3772	.189
Min	.3201	.0762	.0377	.3772	.1543
Avg	.6249	.1785	.3951	.3772	.1717

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S
Feeder No / Name : 203 / 11 Kv Selu (J) SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4725					1.2193
16		1.1385	1.2003		1.1145	
24	.3506	.4338	.3772	.3772	.4338	
Max	.4725	1.1385	1.2003	.3772	1.1145	1.2193
Min	.3506	.4338	.3772	.3772	.4338	1.2193
Avg	.4116	.7862	.7888	.3772	.7742	1.2193

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154084 / 33/11 KV BITTERGAON
Feeder No / Name : 202 / Wala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5959			
9		.1551		
16	.0554	1.9719	1.5775	
24	.3224	.1412	.3429	.0705
Max	**.5959**	**1.9719**	**1.5775**	**.0705**
Min	**.0554**	**.1412**	**.3429**	**.0705**
Avg	**.3246**	**.7561**	**.9602**	**.0705**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154084 / 33/11 KV BITTERGAON
Feeder No / Name : 203 / 11 Kv W/W NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	02-APR-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S
Feeder No / Name : 201 / 11 KV DARJI BORGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.16		.1715	
2		.1715			.1715	
3		.1715			.1715	
4		.2058			.2058	
5		.2058			.2401	
6		.2401			.2572	
7		.2401			.3086	
8	.2743	.2058		.2401	.2572	.4801
9				.1372		
10				.3944	.3041	
16	.3772		.4115	.3086		.0857
17				.3601		.0857
18				.12		.0857
19				.0257		.2058
20				.2572		.2572
21				.2401		.2058
22				.2058		.1715
23				.1886		.1715
24		.1715		.1715	.1886	.2743
Max	**.3772**	**.2401**	**.4115**	**.3944**	**.3086**	**.4801**
Min	**.2743**	**.1715**	**.16**	**.0257**	**.1715**	**.0857**
Avg	**.3258**	**.1982**	**.2858**	**.2208**	**.2276**	**.2023**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S
Feeder No / Name : 202 / 11 KV BHRAMWADI -Ghavan SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.1578		.1543	
2		.2058			.1543	
3		.2058			.1543	
4		.2058			.2058	
5		.2572			.2058	
6		.2572			.2058	
7		.2572			.2572	
8	.2058	.1543		.1543	.2058	1.1317
9				.0514		
10				.8745	.9614	
16	1.1831		1.1317	1.0802		.0514
17				1.1317		.0514
18				.1029		.0514
19				.2058		.1543
20				.2572		.2572
21				.2058		.2572
22				.2058		.2058
23				.1543		.1543
24		.2058		.1543	.2058	.4115
Max	**1.1831**	**.2572**	**1.1317**	**1.1317**	**.9614**	**1.1317**
Min	**.2058**	**.1543**	**.1578**	**.0514**	**.1543**	**.0514**
Avg	**.6945**	**.2172**	**.6448**	**.3815**	**.2711**	**.2726**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
LATUR DIVISION[518]
RENAPUR (R) S/DN[564] BU 5649
Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S
Feeder No / Name : 203 / 11 KV INDARTHANA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2915	.2713		.3429	
2		.2915			.3944	
3		.3086			.3944	
4		.3429			.4287	
5		.3772			.5144	
6		.4287			.6516	
7		.5144			.7716	
8	.8745	.5144		.7373	.7373	.4115
9				.7373		
10				.1543	.1619	
16	.1372		.1372	.1372		.6859
17				.12		.6859
18				.1543		.1886
19				.4458		.3429
20				.4973		.3944
21				.4115		.3429
22				.3086		.3086
23				.2572		.2572
24		.2915		.3086	.3429	.2743
Max	**.8745**	**.5144**	**.2713**	**.7373**	**.7716**	**.6859**
Min	**.1372**	**.2915**	**.1372**	**.12**	**.1619**	**.1886**
Avg	**.5059**	**.3734**	**.2043**	**.3558**	**.4740**	**.3892**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154002 / 33KV Ausa
Feeder No / Name : 203 / 11KV Khanapur(AG) **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.0829		1.4937	1.2197	1.1827	.2241
4	1.3817		1.7924	1.3306	1.3676	
6	.7468			1.6263	1.643	
8			2.6139			
18		.2241		.2241	.1867	
19					.2241	
20		.2987		.2172		
21					.2241	
22				.2241		
24	.9335			1.0082		
Max	**1.3817**	**.2987**	**2.6139**	**1.6263**	**1.643**	**.2241**
Min	**.7468**	**.2241**	**1.4937**	**.2172**	**.1867**	**.2241**
Avg	**1.0362**	**.2614**	**1.9667**	**.8357**	**.8047**	**.2241**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154002 / 33KV Ausa
Feeder No / Name : 204 / 11kv Borphal AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0373			.0373	1.4937
4					1.7924
6					2.0538
8					2.3152
10				.7468	
12	2.2405		2.2405	2.2405	
14	2.4272		2.3152	2.2779	
16	2.5019			2.3525	
17		1.6804			
18	.0373	.0373	.0373	.0373	
19				.0373	
20	.0373		.0373		
21	.0373			.0373	
22			.0373		
24	1.4937				
Max	**2.5019**	**1.6804**	**2.3152**	**2.3525**	**2.3152**
Min	**.0373**	**.0373**	**.0373**	**.0373**	**1.4937**
Avg	**1.1016**	**.8589**	**.9335**	**.9709**	**1.9138**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154002 / 33KV Ausa
Feeder No / Name : 205 / 11kv Utti w/w express feeder Feeder KV- 11 / OUTGOING **NON SHEDDABLE WATER SUPPLY AND UTILITY**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0373		.0373	.112	.1494	.0373
4	.0373		.0373	.112	.1494	.0373
6	.1494			.1494	.1494	.0373
8						.1867
10	.1867				.1494	
12	.1867			.1867	.1867	
14	.1867			.1867	.1867	
16	.1867				.1867	
17		.1494				
18	.112	.1867		.1494		
19					.112	
20	.112	.0373		.1494		
21	.1494				.112	
22				.1494		
24	.0373				.1867	
Max	**.1867**	**.1867**	**.0373**	**.1867**	**.1867**	**.1867**
Min	**.0373**	**.0373**	**.0373**	**.112**	**.112**	**.0373**
Avg	**.1256**	**.1245**	**.0373**	**.1494**	**.1568**	**.0747**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154002 / 33KV Ausa
Feeder No / Name : 206 / 11kv MIDC Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1494		.112	.1848	.1867	.3361
4	.168		.1494	.1663	.2054	.2987
6	.1294			.1294	.2218	.3734
8			.1867			.168
10	.3361				.2987	
12	.3921				.2987	
13				.6161		
14	.3921			.3921	.4481	
16	.3734				.0747	
17		.2987				
18	.3361	.2241		.4066	.2241	
19					.168	
20	.2241	.1867		.2427		
21	.168				.2614	
22				.2241		
24	.1867			.112		
Max	**.3921**	**.2987**	**.1867**	**.6161**	**.4481**	**.3734**
Min	**.1294**	**.1867**	**.112**	**.112**	**.0747**	**.168**
Avg	**.2596**	**.2365**	**.1494**	**.2749**	**.2388**	**.2941**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154002 / 33KV Ausa
Feeder No / Name : 207 / 11kv Khanapur(ALMALA) GAOTHAN FEEDER
gaothan Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.168		.2614	.168	.2241	.2987
4	.2241		.2614	.2241	.2614	.2614
6	.2614			.2987	.2987	.3361
8						.3361
10	.1307				.2241	
12	.112			.1494	.2614	
14	.1307			.4481	.2241	
16	.1307				.2241	
17		.1307				
18	.112	.168		.1867	.2614	
19					.2987	
20	.1867	.2241		.3361		
21	.2801				.2987	
22				.2614		
24	.1867			.1867		
Max	**.2801**	**.2241**	**.2614**	**.4481**	**.2987**	**.3361**
Min	**.112**	**.1307**	**.2614**	**.1494**	**.2241**	**.2614**
Avg	**.1748**	**.1743**	**.2614**	**.2510**	**.2577**	**.3081**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154002 / 33KV Ausa
Feeder No / Name : 208 / 11 KV KARAJGAON GAOTHAN FEEDER Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3361		.4481	.3361	.2987	.5228
4	.3361		.4481	.4108	.4108	.5228
6	.5415			.5601	.5415	.4481
8						.4854
10	.3174				.3547	
12	.2427				.3361	
14	.3361			.3361	.2801	
16	.2614				.3734	
17		.3361				
18	.2987	.3734		.3921	.2987	
19					.2427	
20	.4108	.4294		.4294		
21	.4668				.4481	
22				.4108		
24	.3734			.3734		
Max	**.5415**	**.4294**	**.4481**	**.5601**	**.5415**	**.5228**
Min	**.2427**	**.3361**	**.4481**	**.3361**	**.2427**	**.4481**
Avg	**.3565**	**.3796**	**.4481**	**.4061**	**.3585**	**.4948**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154021 / 33KV Bhada S/S
Feeder No / Name : 201 / 11KV Bhada Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3722				
9	.3412				
10	.3412				
24	.3542	.3412	.322	.583	.5152
Max	.3722	.3412	.322	.583	.5152
Min	.3412	.3412	.322	.583	.5152
Avg	.3522	.3412	.322	.583	.5152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154021 / 33KV Bhada S/S
Feeder No / Name : 202 / 11KV Warwada Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	01-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.2302		
24	.1646	.1315	.296
Max	.2302	.1315	.296
Min	.1646	.1315	.296
Avg	.1974	.1315	.296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154021 / 33KV Bhada S/S
Feeder No / Name : 203 / 11KV Baranpur Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	01-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
8	2.2747		
24	.7122	1.0513	.2377
Max	2.2747	1.0513	.2377
Min	.7122	1.0513	.2377
Avg	1.4935	1.0513	.2377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154021 / 33KV Bhada S/S
Feeder No / Name : 204 / korangala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	01-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.2012	.2012	.4706
Max	.2012	.2012	.4706
Min	.2012	.2012	.4706
Avg	.2012	.2012	.4706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154021 / 33KV Bhada S/S
Feeder No / Name : 206 / kalmatha SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	01-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.788	.3582	.1086
Max	.788	.3582	.1086
Min	.788	.3582	.1086
Avg	.788	.3582	.1086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154030 / 33KV YERANDI S/S
Feeder No / Name : 201 / 11KV Yerandi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.2439					
8					.6097	
9			.1372	.1372		.7621
13					.061	
16	.5792			.6859		
17		.6249				
18			.0914			
19					.1981	
20	.2743					
23				.1219		
24	.1219	.1219	1.7147	.1372	.2134	.3429
Max	**.5792**	**.6249**	**1.7147**	**.6859**	**.6097**	**.7621**
Min	**.1219**	**.1219**	**.0914**	**.1219**	**.061**	**.3429**
Avg	**.3048**	**.3734**	**.6478**	**.2706**	**.2706**	**.5525**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154030 / 33KV YERANDI S/S
Feeder No / Name : 202 / 11KV Kaneri Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.2346					
8					.2134	
9			1.0974	1.0669		.1372
13					1.0364	
16	.061			.061		
17		.0914				
18			.1524			
19					.2134	
20	.2743					
23				.1829		
24	.5182	.2286	1.7147	.5335	.1829	.1829
Max	**1.2346**	**.2286**	**1.7147**	**1.0669**	**1.0364**	**.1829**
Min	**.061**	**.0914**	**.1524**	**.061**	**.1829**	**.1372**
Avg	**.5220**	**.16**	**.9882**	**.4611**	**.4115**	**.1601**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154032 / 33kv Matola
Feeder No / Name : 201 / 11KV Matola **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1694	1.1317			1.4146
2			1.226	1.226			1.5089
3			1.3203	1.3203			1.6409
4			1.4712	1.5466			1.7918
5			1.6032	1.8861			1.8861
6			1.8861	1.9805			2.1313
7			2.1125	2.3011			2.2634
8		1.7528	2.1879	2.2634	.9431		2.3388
9			2.037	2.2634			2.3577
10			1.0374		.9431		.5658
11		1.8861	1.226		1.5089	.3772	
12		2.037	1.6975			.3206	
13		2.0748	1.8484			.2641	
14		2.1125	1.8861		1.5089	.2829	
15		2.1691	1.9239		1.5089	.3206	
16		2.1502	1.9805			.3018	
17		1.8107	2.1879			.3206	
18		.5281	.6602			.6602	
19		.7922	.9431			.9431	
20		.9808	.9431			.8488	
21		.8676	.8488			.8676	
22		.7545	.7545			.5658	
23		.5658	.6036			.4715	
24	.8383	.7545	1.1317	.9808			1.1317
Max	**.8383**	**2.1691**	**2.1879**	**2.3011**	**1.5089**	**.9431**	**2.3577**
Min	**.8383**	**.5281**	**.6036**	**.9808**	**.9431**	**.2641**	**.5658**
Avg	**.8383**	**1.4158**	**1.4453**	**1.6900**	**1.2826**	**.5034**	**1.7301**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154032 / 33kv Matola
Feeder No / Name : 202 / 11kv water works express feede Feeder KV- 11 / OUTGOING **NON SHEDDABLE WATER SUPPLY AND UTILITY**

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754	.0189			.0754
2		.0754	.0189			.0189
3		.0754	.0189			.0189
4		.0754	.0189			.0189
5		.0754	.0189			.0189
6		.0754	.0189			.0189
7		.0754	.0189			.0189
8	.0638	.0754	.0189	.0189		.0943
9		.0189	.0189			.0189
10		.0189		.0943	.0754	.0754
11	.0754	.0189		.0189	.0754	.0943
12	.0754	.0189			.0943	.0754
13	.0754	.0189			.0943	
14	.0754	.0189		.1886	.0943	
15	.0754	.0189		.1886	.0943	
16	.0189	.0189			.0943	
17	.0189	.0189			.0943	
18	.0189	.0189			.0943	
19	.0754	.0189			.0943	
20	.0943	.0189			.0943	
21	.0754	.0189			.0943	
22	.0754	.0189			.0943	
23	.0754	.0189			.0943	
24	.0591	.0754	.0189			.0943
Max	**.0943**	**.0754**	**.0189**	**.1886**	**.0943**	**.0943**
Min	**.0189**	**.0189**	**.0189**	**.0189**	**.0754**	**.0189**
Avg	**.0635**	**.0401**	**.0189**	**.1019**	**.0916**	**.0493**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154032 / 33kv Matola
Feeder No / Name : 204 / Devtala Feeder **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.226	1.226			1.3203
2		1.3203	1.2826			1.4335
3		1.3769	1.4146			1.5089
4		1.4146	1.6221			1.6598
5		1.6409	1.6975			1.7918
6		1.7918	1.9427			1.9616
7		2.1691	2.3577			2.0748
8	1.467	1.4146	2.3765	1.6975		1.8861
9		1.5655	.2829			1.3203
10		.2829		1.5089	1.2449	1.4712
11	1.5466	1.3203		1.4146	1.6975	1.9805
12	1.6032	.1132			2.0748	1.9805
13	1.5844	1.5089			1.8861	
14	1.5466	1.6032		1.4146	2.037	
15	1.5089	1.6409		1.4146	2.0748	
16	1.5278	1.6975		1.4146	2.1125	
17	.9431	1.7918			2.1691	
18	.4338	.4715			.4715	
19	.5658	.5658			.6224	
20	.6036	.4715			.5093	
21	.5658	.5658			.4904	
22	.4715	.4904			.4715	
23	.4338	.4715			.3772	
24	.2543	1.0374	.9431			.9431
Max	**1.6032**	**2.1691**	**2.3765**	**1.6975**	**2.1691**	**2.0748**
Min	**.2543**	**.1132**	**.2829**	**1.4146**	**.3772**	**.9431**
Avg	**1.0037**	**1.1647**	**1.5146**	**1.4775**	**1.3028**	**1.6410**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154032 / 33kv Matola
Feeder No / Name : 205 / Kavli Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.1509
2			.1509
3			.1886
4			.1886
5			.1886
6			.1886
7			.2263
8	1.1317		.1886
9			.1886
10	1.1317	1.0374	.9431
11	1.6975	1.4146	1.3203
12		1.7353	1.2826
13		1.5844	
14	.0943	1.6975	
15	.0943	1.7541	
16	.1886	1.7918	
17		1.8107	
18		.1886	
19		.1886	
20		.2263	
21		.1886	
22		.1886	
23		.1886	
24			.1509
Max	**1.6975**	**1.8107**	**1.3203**
Min	**.0943**	**.1886**	**.1509**
Avg	**.7230**	**.9997**	**.4120**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S
Feeder No / Name : 201 / 11kv Belkund **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2617	.2617	.2858	.2858	.3429		.6158
2	.2617	.2617	.2858	.2858	.3429		.6927
3	.2771	.2463	.2858	.2858	.3429		.7697
4	.2617	.2309	.2858	.2858	.381		.9236
5	.2463	.2463	.4763	.3429	.381		1.0006
6	.2155	.2617	.7621	.381	.4191		1.0776
7	.2309	.2771	.8573	.4191	.4763		1.2315
8	.2309	.2925	.8573	.381	.4191		1.3855
9	.2155	.2771	.8002	.3429	.381		1.3085
10	.6927	.6158		.4763	.4763	.2309	.2309
11		.7697		.5335			
12		.7697					
13	.7697	.7678		.6401			
14	.8467			.6706			
15	.9236	.0838		.6097			
16	1.0006	.7389		.6401			
17	1.0776	.7389	1.1279	.7621			
18	.9236	.3048	.1905				
19	.2309		.381	.3429			
20	.2463		.3429	.381			
21	.2617		.3429	.381			
22	.2771		.3429	.3429			
23	.2771		.3429	.3429			
24	.2463	.2309	.2309	.3429	.3429		.4618
Max	**1.0776**	**.7697**	**1.1279**	**.7621**	**.4763**	**.2309**	**1.3855**
Min	**.2155**	**.0838**	**.1905**	**.2858**	**.3429**	**.2309**	**.2309**
Avg	**.4534**	**.4098**	**.4823**	**.4307**	**.3914**	**.2309**	**.8817**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S
Feeder No / Name : 203 / 11 kv Karkhana Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0095	.0191	.0191	.0183	.0183		.0191
2	.0191	.0191	.0191	.0183	.0183		.0191
3	.0191		.0191	.0183	.0183		.0191
4	.0191	.0191	.0191	.0183	.0183		.0191
5	.0191	.0191	.001	.0183	.0183		.0191
6	.0191	.0191	.0095	.0091	.0183		.0095
7	.0191	.0095	.0095	.0091	.0091		.0095
8	.0191	.0095	.0095	.0091	.0091		.0095
9	.0095	.0095	.0095	.0091	.0076		.0095
10	.0095	.0095		.0091	.0091	.0095	.0095
11	.0095	.0095		.0091			
12	.0095	.0095		.0091			
13	.0095	.0095		.0091			
14	.0095	.0095		.0091			
15	.0095	.0095		.0091			
16	.0095	.0095		.0091			
17	.0095	.0095	.0091	.0091			
18	.0095	.0095		.0091			
19	.0191		.0163	.0091			
20	.0286		.0091	.0091			
21	.0191		.0152	.0183			
22	.0191		.0111	.0183			
23	.0191		.0183	.0183			
24	.0095	.0191	.0191	.0183	.0183		.0191
Max	**.0286**	**.0191**	**.0191**	**.0183**	**.0183**	**.0095**	**.0191**
Min	**.0095**	**.0095**	**.001**	**.0091**	**.0076**	**.0095**	**.0095**
Avg	**.0147**	**.0127**	**.0134**	**.0126**	**.0148**	**.0095**	**.0147**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S
Feeder No / Name : 204 / Gukheda Feeder **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6884	.612	.7649	.9717	.9717		.2448
2	.7649	.6884	.7649	1.2955	.9717		.2601
3	.8414	.7649	.7649	1.4575	1.1336		.2754
4	.9179	.9179	.7649	1.6194	1.1336		.2601
5	.9179	1.0709	1.0709	1.9433	1.3765		.2448
6	1.0709	1.2239	1.3769	2.1052	1.7814		.2295
7	1.1015	1.3769	1.5299	2.1052	1.9433		.2295
8	1.1474	1.5299	1.8359	1.9662	2.0243		.7037
9	1.2239	1.5299	1.7594	1.7814	2.0243		.2601
10	.2295	.2295		.1619	.1619	.459	.612
11	.2754	.2295		.1619		.7649	
12		.2295		.1619			
13		.2295		.1619			
14	.2142	.2295		.1619			
15	.2295	.2295					
16	.2448	.2295					
17	.2601	.2295	.2429	.1619			
18	.2295	.2295	.2429	.2458			
19	.2295		.2915	.2915			
20	.2754		.2915	.3239			
21	.2601		.2753	.3239			
22	.2295		.2753	.2915			
23	.2448		.2753	.2915			
24	.612	.5355	.459	.7287	.6478		.2295
Max	**1.2239**	**1.5299**	**1.8359**	**2.1052**	**2.0243**	**.7649**	**.7037**
Min	**.2142**	**.2295**	**.2429**	**.1619**	**.1619**	**.459**	**.2295**
Avg	**.5549**	**.6482**	**.7639**	**.8506**	**1.2882**	**.6120**	**.3227**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S
Feeder No / Name : 205 / Malumbra Feeder **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2301	.2454	.2301	.2949	.2949		.6884
2	.2301	.2607	.2301	.2949	.2949		.7668
3	.2607	.2761	.2301	.2949	.2949		.8435
4	.2761	.2761	.2301	.3277	.3277		.9202
5	.2607	.2601	.3067	.3277	.3277		.9969
6	.2454	.2454	.4601	.3605	.3277		1.2269
7	.2301	.2301	.4601	.3605	.3605		1.3803
8	.2454	.2454	.4601	.3277	.3277		1.5337
9	.2607	.2301	.3067	.2949	.3277		
10	.7668	.6135		.3277	.4096	.2301	.2301
11	1.0736	1.0736		2.0481			
12	1.3803	.1134		2.2939			
13	1.6871	1.0736		2.2939			
14	1.8404	.9202		2.2119			
15	1.9938	1.2269		2.4577			
16	1.8404	1.6871					
17	1.6871	1.8404	2.13				
18	1.3803	.2301	.2458				
19	.2454		.3277	1.1469			
20	.2761		.3277	1.2289			
21	.2454		.2949	1.1469			
22	.2301		.2949	.3277			
23	.2454		.2915	.2949			
24	.1534	.2301	.2301	.2949	.2949		.6135
Max	**1.9938**	**1.8404**	**2.13**	**2.4577**	**.4096**	**.2301**	**1.5337**
Min	**.1534**	**.1134**	**.2301**	**.2949**	**.2949**	**.2301**	**.2301**
Avg	**.7202**	**.5936**	**.4151**	**.9027**	**.3262**	**.2301**	**.9200**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154041 / 33KV Jawalga S/S
Feeder No / Name : 201 / 11 KV Jawalga Feeder **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.0669	1.2631	1.2803	1.0526	
2	1.2955	1.1431	1.4575		1.1336	.2743
3	1.4746	1.5242	1.6004	1.4403		
4	1.6194	1.9814	1.9204		1.2803	.3658
5	2.2138	2.2862	2.1338	1.6004	1.2803	
6	2.372	2.4387	2.2862	1.8185		.5182
7	2.372	2.21	1.0974	2.0557	2.3434	
8	2.0557	2.2862	2.2558	2.3434	2.3434	.4877
9		1.829	2.2405	2.1872	2.3434	.4572
10	.3163	.3048	.3605	.2949	.3277	.9145
11	.2439	.2743	.2984	.2458	.2743	1.5813
12	.2439	.2591	.2652	.2294	.2439	1.7394
13	.2439	.2743	.2652	.2294	.2134	1.8747
14	.2743	.2743	.2591	.2294	.2134	1.8747
15	.2743	.2743		.2294		2.2653
16	.2743	.2743	.2591		.1829	2.3434
17	.2743	.2743	.2622			2.372
18		.2743		.3277	.2439	
19	.4572	.4572		.5571		.4915
20	.5335	.5182	.6478	.6478	.5182	.4744
21	.4572	.4877		.4915		.4858
22	.4268	.4572	.4049	.3932	.3658	.4096
23	.2743	.3353	.3605	.3277		.4049
24	.905	.9145		.9831		.3048
Max	**2.372**	**2.4387**	**2.2862**	**2.3434**	**2.3434**	**2.372**
Min	**.2439**	**.2591**	**.2591**	**.2294**	**.1829**	**.2743**
Avg	**.8939**	**.9342**	**1.0336**	**.8956**	**.8975**	**1.0337**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154041 / 33KV Jawalga S/S
Feeder No / Name : 203 / 11 KV Haregaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0754	.0739	.0739	
2	.0953	.0762	.0754		.0739	.5658
3	.0953	.0762	.0747	.0739		
4	.0953	.1524	.1448			.7545
5	.0953	.1905	.181	.1478	.1848	
6	.1905	.2286	.2172	.1848		1.0374
7	.1905	.2286	.2229	.2218	.3292	
8	.1905	.1886	.2058	.2772	.3292	1.1317
9	.1509	.1509	.0739	.2772	.2218	1.1317
10	.3772	.362	.6653	.695	.6584	.1143
11	.9431	.6805	.6584	.8326	.8573	.0943
12	1.0185	.7164	.695	.8413	.9431	.037
13	.9907	.6516	.695	.8596	.9431	.0373
14	.9526	.8326	.7316	.8413	.9431	.0373
15	.9526	.8688	.823	.8316		
16	1.0479	.8688	.823	.7316	.9808	.0373
17	.9526	.905	.8413	.8413		.0381
18	.0381	.056	.0924	.0924	.0381	
19	.1905	.1494		.1478		.1905
20	.1905	.1494	.1829	.2772	.2286	.1905
21	.1905	.1509		.2772		.1905
22	.1143	.1132	.1829	.2218	.1143	.1334
23	.0762	.1132	.1829	.1848		.0953
24	.0953	.0762	1.1584	.0924	.0924	.381
Max	**1.0479**	**.905**	**1.1584**	**.8596**	**.9808**	**1.1317**
Min	**.0381**	**.056**	**.0739**	**.0739**	**.0381**	**.037**
Avg	**.3887**	**.3359**	**.4092**	**.4102**	**.4383**	**.3443**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154054 / 33KV BUDHODA
Feeder No / Name : 201 / 11kv budhoda SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.233			1.905		
5		2.0576	1.8004			
7			2.0576			
8	1.5413	2.6578	2.0576	2.6073	.6859	
9	1.5356	2.7435	1.7147			
10	.5195		.6001	.6165		
12				.4624		
13				.4624		
14		.3429	.3429			
16		.3429		.4624	.0857	
18		.5144		.6927		
20		.8573			.8573	
22		.8573				.7793
23		.6859				
24	.8659	.6859	.6859	1.3855		
Max	**1.5413**	**2.7435**	**2.0576**	**2.6073**	**.8573**	**.7793**
Min	**.5195**	**.3429**	**.3429**	**.4624**	**.0857**	**.7793**
Avg	**1.1391**	**1.1746**	**1.3227**	**1.0743**	**.5430**	**.7793**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154054 / 33KV BUDHODA
Feeder No / Name : 202 / 11kv Selu **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1079			.1385		
5			.0857			
7		.1372	.12			
8	.0925		.0857	.0009	1.2003	
9	.0925	.1372				
10	.6927		.8573	1.0391		
11		1.2003				
12				1.156		
13				1.156		
14		1.3717	1.7147			
16		1.3717		1.3855	.0686	
18		.0514		.1039		
20					.12	
21		.12				
22						.1039
23		.12				
24	.0866	.1372	.0857	.1732		
Max	**.6927**	**1.3717**	**1.7147**	**1.3855**	**1.2003**	**.1039**
Min	**.0866**	**.0514**	**.0857**	**.0009**	**.0686**	**.1039**
Avg	**.2144**	**.5163**	**.4915**	**.6441**	**.4630**	**.1039**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154054 / 33KV BUDHODA
Feeder No / Name : 203 / 11kv Almala **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0771			.0866		
5			.0857			
7		.0857	.0857			
8	.0771		.0857	.0768	2.0576	
9	.0771	.0857	.0857			
10	1.1257		.6859	.9248		
11		.8573				
13				1.9266		
14		2.2291	2.2291			
16		2.2291		2.1578	.0857	
18		.0857		.0866		
20					.0857	
21		.0857				
22						.0866
23		.0857				
24	.0866	.0857	.0857	.0866		
Max	**1.1257**	**2.2291**	**2.2291**	**2.1578**	**2.0576**	**.0866**
Min	**.0771**	**.0857**	**.0857**	**.0768**	**.0857**	**.0866**
Avg	**.2887**	**.6477**	**.4776**	**.7637**	**.743**	**.0866**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S
Feeder No / Name : 201 / 11KV Tungi Feeder **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2622	.2543	.3018	.2374	.2683	2.1548	1.989
4		.3391	.5765	.4239	.4024	1.9662	2.0957
5	.4024						
6	.5895	.6783				2.1862	2.0119
8	.5765	.4807				2.2045	1.9281
10	.2915	.3315					
12	.2683		.2321	.2652	.2347		
14	.2652		.213	.2267	.2012		
16	.3018		.1943	.1898	.1844	.1677	
17		2.4531					
18	2.4143	2.3975	2.431		2.5149	.2012	
20	2.3205			1.9989	2.3472	.3688	
22	2.3304			1.7166	2.2131	.3353	
24	1.949		1.5257	1.5927	1.4243	2.2634	.2347
Max	**2.4143**	**2.4531**	**2.431**	**1.9989**	**2.5149**	**2.2634**	**2.0957**
Min	**.2622**	**.2543**	**.1943**	**.1898**	**.1844**	**.1677**	**.2347**
Avg	**.9976**	**.9906**	**.7821**	**.8314**	**1.0878**	**1.3165**	**1.6519**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S
Feeder No / Name : 202 / 11 KV Nagarsoga Feeder **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.4255	1.3565	1.4582	1.5261	1.6095	.3647	.4144
4	1.6095	1.6956	1.6278	2.0348	1.6766	.5243	.5868
6	2.0805	1.7436	1.9113	2.1795	1.8233		
8	1.7974	1.6766	1.8233	1.989	1.6975		
10	.3563	.431				1.643	1.6766
12	.3353	.2652				1.757	
14	.2984	.2155				1.6385	
16	.2012	.2652	.3239	.3479	.3521	1.4754	
18	.2683	.2818	.3185		.3521		
20	.4973			.5898	.6371	.5868	
22	.503			.4858	.57	.5868	.6299
24	.4252	1.3565	.4024	.4359	.4409	.4359	.503
Max	**2.0805**	**1.7436**	**1.9113**	**2.1795**	**1.8233**	**1.757**	**1.6766**
Min	**.2012**	**.2155**	**.3185**	**.3479**	**.3521**	**.3647**	**.4144**
Avg	**.8165**	**.9288**	**1.1236**	**1.1986**	**1.0177**	**1.0014**	**.7621**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S
Feeder No / Name : 203 / 11KV Gadavewadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2652	.2543	.3391	.763	.2683	.2486	.2486
4	.3353	.3391	.4409	.373	.3688	.3605	.3688
6	.4854	.4641					
8	.5087	.3481					
10	2.4615	2.5194	2.3472	2.6852	2.4577	.2984	
12	2.649	2.6189	2.6852	2.7846	2.4813	.2652	
14	2.5194	2.5194	2.6216	2.5911	2.3807	.1638	
16	2.4143	2.5857	2.7854	2.1506	2.5987	.1509	
18	.0838	.1509				2.7496	
20	.4144			.426	.503	2.6825	
22	.3353			.3239	.4191	2.3472	2.3868
24	.3189		.2515	.285	.2713	.285	2.2131
Max	**2.649**	**2.6189**	**2.7854**	**2.7846**	**2.5987**	**2.7496**	**2.3868**
Min	**.0838**	**.1509**	**.2515**	**.285**	**.2683**	**.1509**	**.2486**
Avg	**1.0659**	**1.3111**	**1.6387**	**1.3758**	**1.3054**	**.9552**	**1.3043**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154065 / 33KV Bheta S/S
Feeder No / Name : 201 / 11 KV Andhora feeder **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3684	.4412	.3588	.3554	.4158	.3751
2		.3852	.4417	.3722	.3915	.4162	.3808
3		.4019	.4431	.4272	.411	.4154	.4063
4		.4187	.4426	.4796	.4305	.5653	.4556
5		.4187	.4904	.4893	.5261	.6212	.5795
6		.5359	.6804	.7167	.7305	.6763	.644
7		.6029	.7946	.7013	.6759	.756	.7835
8		.5861		.6962	.7399	.7007	.7037
9	.9043	.8038		1.8747	1.8192	.4934	.5798
10	1.0048	.7636	1.7284	1.873	2.0293	.3795	.2512
11	1.0383	.7636	2.2646	1.6872		.2373	.2345
12	.9713	.8124	2.2634	2.3445		.1987	.201
13	1.0048	.8589	2.2466	2.198		.2142	
14	.9881	.857	2.2685	2.198		.1971	
15	.9713		2.0719	2.262		.1631	
16	.9043	2.0695	2.0388	1.7238		.1648	
17	.3014	.2963	.2204	.2472	.263	2.7726	
18	.3349	.3785	.4268	.3756	.4045	2.3376	
19	.5024		.6501	.5325	.5938	2.1455	
20	.4689	.7514	.5127	.5778	.6149	2.0276	2.0766
21	.4187	.5774	.4893	.495	.4884	1.8861	1.9259
22	.3978		.4893	.526	.4504	1.9502	1.8756
23	.3684	.4966	.4737	.4263	.4508	1.8992	1.7584
24		.3684	.4785	.4553	.3634	1.9479	1.8233
Max	**1.0383**	**2.0695**	**2.2685**	**2.3445**	**2.0293**	**2.7726**	**2.0766**
Min	**.3014**	**.2963**	**.2204**	**.2472**	**.263**	**.1631**	**.201**
Avg	**.7053**	**.6436**	**1.0162**	**1.0016**	**.6521**	**.9826**	**.8856**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154065 / 33KV Bheta S/S
Feeder No / Name : 202 / 11 KV Bheta Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.257	.2412	.2254	.3076	.2922	.8722	.9459
2	.2891	.2573	.2254	.3076	.298	.8756	1.0607
3	.3212	.2894	.2261	.3513	.3643	.8756	1.1297
4	.3533	.3216	.3036	.3445	.3144	.9328	1.1229
5	.4015	.3538	.3761	.4879	.3617	1.0011	1.2857
6	.4818	.4181	.5687	.5801	.5168	1.2925	1.4798
7	.5655	.5467	.4734	.4263	.5298	1.3763	1.607
8	.4818	.4502		.0855	.3891	1.2757	1.4918
9	.3538			.0759	.2908	.3402	.2984
10	.2412		.2277	.1973		.227	.209
11			.0922	1.1248		.1691	.1608
12			.0758	.1471		.1093	.1126
13			.0757	.0761		.0991	
14			.0945	.1137		.0991	
15	.1286	.0751	.1315	.1141		.0941	
16	.1286	.0751	.1581	.1424		.0974	
17	1.5418	.2076	.7127	1.5912		.1159	
18	1.5097	1.1294		1.455		.1711	
19	1.4472			1.3536	1.3854	.3262	.4824
20	1.3829		.7444	1.326	1.2067	.495	.5467
21	1.3186	.4334	.7293	1.2558	1.1355	.4534	.4502
22	1.2864		.6523	1.2721	1.1492	.3588	.402
23	1.2221	.4295	.6331	1.2096	1.1033	.3349	.3216
24	1.2367	1.1899	.7087	.5801	1.1105	.9872	.2899
Max	**1.5418**	**1.1899**	**.7444**	**1.5912**	**1.3854**	**1.3763**	**1.607**
Min	**.1286**	**.0751**	**.0757**	**.0759**	**.2908**	**.0941**	**.1126**
Avg	**.7474**	**.4279**	**.3717**	**.6219**	**.6965**	**.5408**	**.7443**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154065 / 33KV Bheta S/S
Feeder No / Name : 203 / 11Kv Borgaon feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	1.3413	1.3184	1.1934		.3985	.3218
2	2.1795	1.5089	1.3047			.3795	.3751
3	2.3472	1.6766	1.3514			.3757	.3743
4	2.5149	1.8442	1.6442			.4133	.4277
5	2.6825	2.0119	1.6309			.4785	.4785
6	2.8502	2.1795	2.4865			.526	.4898
7	2.9675	2.3975	2.399			.563	.3642
8	2.7664	2.1125		2.0453		.2277	.368
9	.4024	.4024		.332	.3073	1.6888	1.6232
10	.2683	.0759	.2635			1.7798	1.8107
11	.2515	.0759	.1518			1.801	1.8442
12	.2347	.0761		.1901		1.9631	1.9616
13	.1677	.1507	.0949	.1518		1.9393	
14	.1677	.1521					
15	.1677	.1507	.1757	.1901		1.7697	
16	.1509	.1899	.2277	.1816			
17	.2012	.2076	.2472	.2561		.1694	
18	.2012	.5636	.2732			.2032	
19	.503		.5902	.4189		.3756	.503
20	.5365			.5137	.6072	.4077	.5861
21	.3353		.3795	.4133	.526	.3714	.4191
22	.2683		.4158	.4036	.1882	.298	.4187
23	.2515		.3402	.3809	.2261		.3349
24	.5365	.2347	.2209	.3669	.308	.3069	.2963
Max	**2.9675**	**2.3975**	**2.4865**	**2.0453**	**.6072**	**1.9631**	**1.9616**
Min	**.1509**	**.0759**	**.0949**	**.1518**	**.1882**	**.1694**	**.2963**
Avg	**1.0402**	**.9133**	**.8166**	**.5027**	**.3605**	**.7827**	**.7221**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154067 / 33KV SHIVALI S/S
Feeder No / Name : 201 / 11KV Shivali Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2672	1.7814		1.3108	2.1176	.3277	.3277
2	2.4291	2.1052		1.4746	2.1052	.3277	.3277
3	2.4291	2.2672	1.8842	1.8023	2.1052	.3277	.3277
4	2.4291	2.4291			2.1052	.3277	.3277
5		2.4291		2.13	2.2672		.4096
6				2.2939	2.2672		.4915
7		.8145			2.2672		.4915
8		.9774			2.2672		.4915
9					.4096	2.1991	2.1052
10		.2229		.4096	.3277	2.1862	1.4575
11	.3277	.2201	.4915		.3277	2.2672	1.9433
12	1.8623		.3277		.2458	2.2672	1.9433
13	.3277		.3277		.1638	2.2672	1.7814
14	.2458		.3277		.1638	2.3482	1.7814
15	.2458		.2458		.1638	2.3482	2.1052
16			.2458		.1638	2.3482	2.1052
17	.3277	.0734			.1638	.1629	
18	.3277				.1638	.1638	.3277
19	.4915		.4915		.4096	.4096	.4096
20	.5735		.4915		.4915	.4915	.4915
21	.4915		.4915		.4915	.3277	.4915
22	.4096		.4096		.4096	.3277	.4096
23	.3277	.3277	.3277		.3277	.3277	.3277
24	.3277	.3277		.3277	.3277	.3277	.3277
Max	**2.4291**	**2.4291**	**1.8842**	**2.2939**	**2.2672**	**2.3482**	**2.1052**
Min	**.2458**	**.0734**	**.2458**	**.3277**	**.1638**	**.1629**	**.3277**
Avg	**.9318**	**1.1646**	**.5052**	**1.3927**	**.9272**	**1.1040**	**.9219**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154067 / 33KV SHIVALI S/S
Feeder No / Name : 202 / 11KV Jaifal Feeder **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3277	.3277	.3277	.3277	.2458	.2458
2	.3277	.3277	.0229		.3277	.2458	.3277
3	.3277	.3277			.3277	.2458	.3277
4	.3277	.3277			.3277	.2458	.3277
5	.3277	.3277			.3277	.3277	.3277
6	.3277	.4096			.3277	.3277	.3277
7	.3277	.4096	.2934		.3277	.3277	.3277
8	.3277	.3277			.3277	.4096	.4096
9	2.1991	1.7833	2.0481		1.9547		.2458
10	2.1862	2.1072	2.0481	2.2119	2.1052		.1638
11	2.3482	2.1548	2.13		2.1862		.1638
12	1.9433	2.1824	2.13		2.1862	.1638	.1638
13	2.1052	1.4299	2.13		2.2672	.1638	.1638
14	2.2672		2.2939		2.2672	.1638	.2458
15	2.4291		2.13		2.1862	.1638	.2458
16	1.6194		2.2119		2.1052	.1638	.2458
17	.1638	.0734	.2458		.1629	1.9547	2.2672
18	.1638	.1638	.2458		.1638	2.0243	2.2672
19	.4096	.1638	.3277		.3277	2.1052	2.2672
20	.3277	.4096	.3277		.4096	2.1862	2.1862
21	.3277	.3277	.4096		.4096	2.1862	2.1052
22	.3277	.3277	.4096		.3277	2.2672	2.0243
23	.3277	.3277	.3277		.3277	2.2672	1.9433
24	.3277	.3277	1.1469	.3277	.3277	.3277	2.2672
Max	**2.4291**	**2.1824**	**2.2939**	**2.2119**	**2.2672**	**2.2672**	**2.2672**
Min	**.1638**	**.0734**	**.0229**	**.3277**	**.1629**	**.1638**	**.1638**
Avg	**.9206**	**.6935**	**1.1161**	**.9558**	**.9307**	**.8816**	**.8995**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] **BU 5185**
Substation No/ Name :- 154067 / 33KV SHIVALI S/S
Feeder No / Name : 203 / 11KV Warwada Feeder **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.1638		.1638	.3277	1.0588	1.0588
2	.3277	.1638	.1638	.1638	.3277	.9717	1.1336
3	.3277	.1638		.1638	.3277	.9717	1.2146
4	.3277	.1638			.3277	.9717	1.1336
5	.3277	.2458	.3277	.3277	.3277	1.0526	1.2955
6	.3277	.4915		.4915	.3277	1.1336	1.3765
7	.3277	.4096	.3668		.3277	1.2955	1.4575
8	.3277	.3277			.3277	1.2955	1.4575
9	.3277	.2201	.1638		.1638		.1638
10	.3277	.1467	.1638	.2458	.1638		
11	.0819	.1467	.1638		.1638		
12	.0819	.1467			.1638		
13	.0819	.1467	.1638				
14	.0819		.1638		.0819		
15	.0819	.1638	.1638		.0819		
16	.0819		.1638		.0819		
17	1.3846	1.3375	1.3927		1.4661		
18	1.3765	1.4746	.2458		1.3765	.1638	
19	1.2955	1.3927	.3277		1.4575	.3277	.1638
20	1.2217		.3277		1.4575	.4096	.3277
21	1.2217		1.4746		1.3765	.3277	.4096
22	1.1403		1.3927		1.2217	.3277	.3277
23	1.1403		1.3108		1.1403	.2458	.2458
24	1.1336			1.3108	1.1403	1.1403	.1638
Max	**1.3846**	**1.4746**	**1.4746**	**1.3108**	**1.4661**	**1.2955**	**1.4575**
Min	**.0819**	**.1467**	**.1638**	**.1638**	**.0819**	**.1638**	**.1638**
Avg	**.5701**	**.4297**	**.4986**	**.4096**	**.6156**	**.7796**	**.7953**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154074 / 33KV DHANORA
Feeder No / Name : 201 / 11KV Gondri SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6097	.7621	.6706	.9054	1.0517	1.2803
2	.6859	.6706	.7468	.7164	.8676	1.4022	1.387
3	.6097	.7316	.7316	.7621	.8676	1.5242	1.6004
4	.6097	.8078	.7164	.8078	.9242	1.9204	1.7223
5	.6097	.8383	.6706	.8383	1.0185	2.1643	2.0881
6		.884	.7468	.884	1.0562	2.4082	2.3472
7		.8383	.8078	.8383	.9619	2.4387	2.8197
8		.7621	.6401	.7621	.8676	2.2558	2.7587
9		.6097	.6173	.5792	.8488	1.3717	
10	1.4022	1.2803	1.829	1.2803	1.6766		
11	2.21	1.7985	2.3624	2.5987	2.2558	.381	
12	2.4082		2.4844	2.6155	2.3015	.3353	
13	2.3472		2.4082	2.5987		.3048	
14	2.2862	2.4387	2.3167	2.5652	2.3167	.3353	
15	2.2405	2.3167	2.2558	2.5652	2.4082	.3048	
16	2.4082	2.6063	2.332	2.6825	2.4387	.3048	
17	2.3167	2.3624		2.3304	2.4844	.3353	
18	.4572	.3658	.3963	.5093		.381	
19	.7164	.5335	.6554	.8865		.7621	.5601
20	.884	.5182	.884	1.094		.884	.9335
21	.884	.503	.8535	.9556		.8383	.9335
22	.8383	.5792	.8383	1.0751		.7468	.8402
23	.7621	.6554	.8535	1.0374		.6706	.7468
24	.7621	.6401	.8916	.7621	.9431	.823	1.2041
Max	**2.4082**	**2.6063**	**2.4844**	**2.6825**	**2.4844**	**2.4387**	**2.8197**
Min	**.4572**	**.3658**	**.3963**	**.5093**	**.8488**	**.3048**	**.5601**
Avg	**1.3062**	**1.0614**	**1.2087**	**1.3506**	**1.4790**	**1.0411**	**1.5159**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154074 / 33KV DHANORA
Feeder No / Name : 202 / 11KV Dhanora SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1431	1.1888	1.2041	.8859	.4572	.381
2	1.2193	1.2498	1.4022	1.2803	1.2445	.5182	.4115
3	1.3717	1.448	1.6004	1.3565	1.5257	.5487	.4268
4	1.5242	1.5699	1.8138	1.4327	1.8347	.5792	.4572
5	1.6766	1.7833	1.5242	1.6004	2.3304	.5182	.503
6	1.7528	1.89	1.6766	1.8442	2.6155	.4877	.5335
7	2.2862	2.1033	2.3624	2.6825	2.8837	.4725	.5944
8	2.2862	2.3167	2.3472	2.4082	2.8166	.4115	.503
9	2.332	1.2955	2.4082	2.3167	2.6322	.4268	
10	.381	.2439	.3658	.3963	.3772		
11	.2286	.2743	.2743	.2641	.2743	2.2558	
12	.2591	.2134	.2286	.2641	.2896	2.3777	
13	.2286	.2286	.2591	.2641	.2896	2.3472	
14	.2743	.1981	.2286	.2829	.2439	2.271	
15	.2134	.2134	.1981	.2829	.2743	2.332	
16	.2286	.2439	.2286	.2829	.2591	2.4539	
17	.2286	.1981	.2743	.2641	.2439	2.4082	
18	.3353	.3201	.3048	.2641		.3048	
19	.503	.4877	.5335	.5281		.503	.5228
20	.6706	.5182	.5944	.6602		.5792	.6722
21	.6097	.4572	.503	.6413		.5182	.6535
22	.5335	.4268	.4115	.6036		.4572	.5601
23	.503	.3963	.381	.5658		.4115	.5228
24	.6859	1.0364	.7773	1.1431	.6878	.4268	.381
Max	**2.332**	**2.3167**	**2.4082**	**2.6825**	**2.8837**	**2.4539**	**.6722**
Min	**.2134**	**.1981**	**.1981**	**.2641**	**.2439**	**.3048**	**.381**
Avg	**.8840**	**.844**	**.9119**	**.9514**	**1.2061**	**1.0464**	**.5088**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154092 / 33KV Wanwada S/S
Feeder No / Name : 201 / 11KVBorfal Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.639		.7625
2	.3932		.9503
3	1.0978		1.065
4	1.1797		1.1142
5	1.3603		1.2631
6	1.6518		1.5729
7	1.749		1.7695
8	.3481		.3932
9	.1989	.2652	.2785
10	.1492		
11		.116	
12		.1326	
13		.1326	
14		.1492	
15		.116	
16		.1326	
17		.1492	
18		.1658	
19		.3277	
20		.4144	
21		.3481	
24	.4641		.5304
Max	**1.749**	**.4144**	**1.7695**
Min	**.1492**	**.116**	**.2785**
Avg	**.8392**	**.2041**	**.9700**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.
Feeder No / Name : 201 / 11 KV NEW MIDC FEEDER. SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2641	.3206	.3206	.3018	.2452	.4338
2	.2075	.2641	.3206	.3206	.3018	.2452	.4338
3	.2075	.2641	.3206	.3018	.2829	.2641	.4338
4	.2263	.2829	.3206	.3018	.2829	.2641	.4338
5	.2263	.2641	.3206	.3018	.2829	.2829	.415
6	.2263	.2829	.3206	.2829	.3018	.2641	.3395
7	.2641	.2829	.3584	.3206	.3018	.2452	.2829
8	.2641	.2829	.3206	.3395	.3018	.2641	.2829
9	.2829	.3018	.3395	.3772	.2641	.3206	.3206
10	.6602	.6602	.679	.5658	.5281	.4715	.4338
11	.6979	.7733	.9242	.7167	.5847	.6036	.5281
12	.6602	.5847	.7733	.7167	.547	.547	.5281
13	.6224	.547	.7733	.7167	.4904	.6979	.5281
14	.6413	.5847	.7356	.6979	.5658	.6036	
15	.6413	.9054	.6602	.679	.6602	.5281	
16	.6602	.6979	.7356	.7167	.5281	.547	
17	.7167	.8865	.8299	.7167	.4904	.547	
18	.5281	.6413	.5658	.6602	.4904	.5093	
19	.4904	.679	.4715	.5847	.3206	.5093	
20	.3772	.547	.6036	.4715	.2829	.4715	
21	.3395	.3584	.3206	.3395	.3018	.3961	
22	.2829	.3584	.3206	.2829	.2641	.4338	
23	.2829	.3395	.3206	.3018	.3018	.4338	
24	.2263	.2641	.3206	.3206	.3018	.6036	.4338
Max	**.7167**	**.9054**	**.9242**	**.7167**	**.6602**	**.6979**	**.5281**
Min	**.2075**	**.2641**	**.3206**	**.2829**	**.2641**	**.2452**	**.2829**
Avg	**.4150**	**.4716**	**.4990**	**.4731**	**.3867**	**.4291**	**.4163**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.
Feeder No / Name : 202 / 11 KV CHOWRASTA FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3105	1.3738	.7087	1.5804	1.5739	1.5424	1.539
2	1.2831	1.3424	.691	1.5183	1.502	1.5165	1.4693
3	1.257	1.3157	.6733	1.4807	1.4883	1.5074	1.4247
4	1.2326	1.2761	.691	1.4593	1.4754	1.5206	1.4171
5	1.2456	1.3296	.691	1.5291	1.4822	1.5758	1.4462
6	1.3383	1.4997	.7619	1.6371	1.513	1.648	1.5375
7	1.5766	1.6263	.7973	1.6093	1.5833	1.7475	1.4967
8	1.5657	1.5546	.8859	1.5871	1.5762	1.7757	1.6985
9	1.4504	1.483	.7442	1.5573	1.4476	1.565	1.5777
10	1.5069	1.5005	.7973	1.5726	1.5444	1.4697	1.5157
11	1.4621	1.6164	.7973	1.6295	1.6247	1.683	1.5508
12	1.5322	1.6955	.8505	1.5941	1.5657	1.6705	1.5941
13	1.6424	1.7183	.9036	1.62	1.7284	1.6722	.9206
14	1.6269	1.6815	.7973	1.7202	1.7796	1.7324	.9358
15	1.5855	1.6379	.8505	1.82	1.7751	1.7648	.9137
16	1.5622	1.8349	.9036	1.8037	1.676	1.8278	.8932
17	1.5599	1.7131	.9036	1.7663	1.6807	1.7435	.9587
18	1.5767	1.6988	.9036	1.7618	1.6767	1.8067	.929
19	1.9757	2.1038	1.0985	1.9978	1.9536	2.0524	1.0555
20	2.0306	2.2209	1.134	2.0909	2.162	2.0902	1.0555
21	1.9437	2.0649	.9745	2.0589	2.0007	1.9557	1.0677
22	1.7717	1.9964	.9745	1.9595	1.9527	1.9357	1.0334
23	1.6668	1.7915	.8859	1.809	1.8022	1.8138	.964
24	1.435	1.3783	.7442	1.6981	1.6935	1.6779	1.6964
Max	**2.0306**	**2.2209**	**1.134**	**2.0909**	**2.162**	**2.0902**	**1.6985**
Min	**1.2326**	**1.2761**	**.6733**	**1.4593**	**1.4476**	**1.4697**	**.8932**
Avg	**1.5474**	**1.6439**	**.8401**	**1.7025**	**1.6774**	**1.7206**	**1.2788**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.
Feeder No / Name : 203 / 11 KV SAMTA NAGER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1824	2.2084	1.0498	2.344	2.357	2.236	2.3667
2	2.1375	2.1802	1.0317	2.2733	2.2924	2.1624	2.2855
3	2.0904	2.1603	1.0679	2.2112	2.268	2.1554	2.228
4	2.0775	2.1392	1.086	2.172	2.2482	2.1664	2.2135
5	2.1224	2.215	1.1041	2.2954	2.2914	2.2285	2.2878
6	2.6008	2.4722	1.2489	2.6708	2.4802	2.6151	2.5683
7	2.7433	2.7532	1.3937	2.7906	2.6182	2.7205	2.6115
8	2.5694	2.677	1.2851	2.6155	2.558	2.5797	2.6184
9	2.4046	2.5019	1.2308	2.405	2.4728	2.2482	2.4873
10	2.2116	2.3263	1.1765	2.3343	2.4364	2.2579	2.3017
11	1.9277	2.2301	1.267	1.408	2.3543	2.3511	2.2836
12	2.2428	2.3741	1.2127	1.4344	2.4076	1.7799	2.3396
13	2.392	2.4621	1.2489	2.3726	2.5441	2.4515	1.3146
14	2.3823	2.3632	1.2489	2.5543	2.4858	2.5517	1.3009
15	2.3185	2.3634	1.086	2.425	2.3554	2.4553	1.294
16	2.2924	2.4764	1.1584	2.3587	2.3227	2.5187	.6988
17	2.332	2.4821	1.2127	2.3966	2.3217	2.5029	
18	2.3023	2.5475	1.1584	2.3745	2.3551	2.4863	
19	2.9043	3.0871	1.4661	2.9398	2.9506	3.1409	.6386
20	3.112	3.1814	1.6651	3.0708	3.2014	3.2634	1.4922
21	3.1013	3.0676	1.5384	3.0541	3.0617	3.1412	1.9006
22	2.8584	2.8607	1.3937	2.8679	2.8416	2.9116	1.7535
23	2.6105	2.6159	1.267	2.7376	2.6586	2.7052	1.6095
24	2.343	2.3853	1.086	2.4922	2.4821	2.492	2.6307
Max	**3.112**	**3.1814**	**1.6651**	**3.0708**	**3.2014**	**3.2634**	**2.6307**
Min	**1.9277**	**2.1392**	**1.0317**	**1.408**	**2.2482**	**1.7799**	**.6386**
Avg	**2.4275**	**2.5054**	**1.2368**	**2.4416**	**2.5152**	**2.5051**	**1.9648**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
AUSA (R) S/DN[418] BU 5185
Substation No/ Name :- 157009 / 132 KV AUSA S/S
Feeder No / Name : 403 / 33 KV BHADA SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	29-MAR-17	30-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5384	5.9499	6.5158	6.8073	6.5158	6.7387
2	5.2126	5.7613	6.3272	6.3786	6.07	6.4815
3	5.1783	5.6413	6.0357	6.1386	5.8128	6.3786
4	5.1612	5.5384	5.7956	6.19	5.9842	6.2757
5	5.2641	5.6242	6.0185	6.3272	6.1214	6.3443
6	6.0528	6.5501	6.6187	6.5672	6.6701	6.5501
7	6.9787	7.2874	6.9445	7.0816	7.0645	6.4129
8	6.8759	7.3903	7.0816	7.1159	7.2874	6.9445
9	6.5329	6.9959	6.7044	6.7558	6.653	6.7387
10	7.7675	7.9561	7.9904	7.4074	6.6187	7.4246
11	7.2359	8.1619	6.8073	7.5617	7.6475	7.7332
12	8.0076	8.5048	6.8244	7.7332	6.0528	8.1276
13	8.642	8.1962	8.1619	8.1276	8.0933	8.522
14	8.4362	8.1447	9.0878	8.2305	8.4705	8.3848
15	8.4705	8.4019	8.8649	8.0761	8.2991	8.2648
16	8.3848	8.8649	8.9506	7.9904	8.1276	7.0816
17	8.3676	8.8992	8.882	7.7332	8.059	4.561
18	8.0761	8.6934	8.8649	7.4932	8.1276	4.5268
19	8.8477	9.6194	9.6708	7.9047	9.2593	6.6187
20	9.6194	10.0823	9.8251	8.7106	9.7565	8.8992
21	9.6022	9.6022	9.2593	8.3505	9.0535	9.9966
22	8.0247	8.1104	8.2305	8.059	8.4705	8.8477
23	7.356	7.5274	7.8532	7.5789	7.9733	8.2133
24	6.7044	6.9273	7.2702	7.0988	7.4417	7.5446
Max	**9.6194**	**10.0823**	**9.8251**	**8.7106**	**9.7565**	**9.9966**
Min	**5.1612**	**5.5384**	**5.7956**	**6.1386**	**5.8128**	**4.5268**
Avg	**7.3474**	**7.6846**	**7.6911**	**7.3924**	**7.4846**	**7.2338**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154008 / 33 kv s/s killari
Feeder No / Name : 202 / 11 kv Yelawat AG feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4287	.3772
2						.3772	.4287
3						.5144	.4801
4						.6001	.5144
5						.5658	.6001
6						.5487	.6859
7						.6001	.7716
8						.8573	.8916
9						.7716	.4801
10	.3772		.3086		.2915		
11	.6001		.3772	.5144	.3429		
12	.583	.5144	.4458	.5487	.3086		
13	.6001	.5144	.4801	.583	.2743		
14	.6173		.5316	.583			
15	.6516	.4973	.6001	.6516	.4287		
16	.6173		.6173	.4115	.5144		
17	.6516	.4801	.6516	.4287	.5487		
24						.3772	.8916
Max	**.6516**	**.5144**	**.6516**	**.6516**	**.5487**	**.8573**	**.8916**
Min	**.3772**	**.4801**	**.3086**	**.4115**	**.2743**	**.3772**	**.3772**
Avg	**.5873**	**.5016**	**.5015**	**.5316**	**.3870**	**.5641**	**.6121**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154008 / 33 kv s/s killari
Feeder No / Name : 203 / 11 kv Old KIllari Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3772	.3429	.4287	.2058	.6001	.583
2	.3258	.4287	.3772	.5144	.2572	.6859	.6516
3	.3086	.4801	.5144	.6001	.3086	.9431	.7545
4	.3429	.5144	.5487	.5658		1.1145	.8402
5	.3772	.6001	.6516	.7202		1.2003	.9259
6	.4115	.7202	.6001	.6687		1.166	.8916
7	.4801	.6687	.5658	.6859		1.1488	.8573
8	.5144	.6516	.6001	.6344			.8402
9	.6001	.6516	.6687	.6516			.8573
10	.5144		.583	.6859	.4115	.6001	.823
11	.6001	.4801	1.166	.7545	1.5604	.6859	
12	.9774	.6173	.823	.7888	1.6461	.8573	.6516
13	.9431	.6859	.823	.823	.9431	.8402	
14	.9259	.7202		.8573	1.046	.7888	.823
15	.9088	.7545	.6687	.9259	1.1145	.823	
16	1.0631		.8573	.9259	.8916	.8745	
17	1.1831		.7716	.9431	1.1145	.9259	1.0974
18	.2058		.8745	.3086	.2915	.2743	
19	.4115		.3086	.3429	.3601	.3086	.1715
20	.4458	.3086	.3429	.3601	.3944	.3601	
21	.3772		.3772		.4458	.4287	
22	.3429		.3429	.2572	.4115	.4115	.2058
23	.3086	.4115	.3258	.2401	.3429	.3601	.1715
24	.2572	.3429	.2743	.3601	.1715	.4287	.4115
Max	**1.1831**	**.7545**	**1.166**	**.9431**	**1.6461**	**1.2003**	**1.0974**
Min	**.2058**	**.3086**	**.2743**	**.2401**	**.1715**	**.2743**	**.1715**
Avg	**.5465**	**.5537**	**.5830**	**.6106**	**.6621**	**.7194**	**.6798**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154008 / 33 kv s/s killari
Feeder No / Name : 204 / 11 KV Talani Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.4287	.4287	.4287		.6859	.583
2	.2743	.463	.5144	.5144		.7202	.6173
3	.2743	.5144	.5487	.6001		.8573	.6859
4						1.1145	.7716
5						1.166	.8573
6						1.2346	.9431
7						1.1145	1.2174
8							1.286
9							1.3717
10	.7545		.9431	1.0631	.6001		
11	1.0288		1.2003	1.0974	.8573		
12	1.166	.9259	1.2346	1.0288	.9259		
13	1.0288		1.2174	.9945	.9774		
14	.9431		.8916	1.4403	1.0288		
15	.8916	1.2003	1.1317	.9259	1.0631		
16	.8573			.8573	1.0974	.2743	.3429
17	1.3032			.9431	1.0631	.3429	
18	.3772		.3601	.6001	.3772	.3772	.2743
19	.6859		.4115	.6516	.4287	.4115	
20	.7202	.4115	.4458	.7202	.4973	.4801	.3429
21	.6516		.4801		.5487	.5487	.3086
22	.6001		.4458		.5144	.4973	.2743
23	.4801	.3772	.4115		.463	.463	.3086
24	.3086	.4115	.3944	.3772		.4801	.5144
Max	**1.3032**	**1.2003**	**1.2346**	**1.4403**	**1.0974**	**1.2346**	**1.3717**
Min	**.2743**	**.3772**	**.3601**	**.3772**	**.3772**	**.2743**	**.2743**
Avg	**.7021**	**.5916**	**.6912**	**.8162**	**.7459**	**.6730**	**.6687**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION
Feeder No / Name : 201 / 11 KV Jawali Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373		.6401	.6783	.6554		.2629
2	.7202		.6554	.8383	.8383		.2572
3	.8097		.7459	.8383	.8383		.3429
4	.8192		.8002	.9945	1.0059		
5	.9602		.9831	1.0774	1.1469		
6	1.1469		1.1603	1.2289	1.2803		
7	1.2803		1.5746	1.5384	1.3889		
8	1.5203		1.5565	1.6404	1.3889		
9	1.4089		1.4918	1.3717	1.3927		
10						.9431	.5144
11						1.4251	1.4232
12						1.5384	
13						1.4403	
14		.8002				1.4403	
15		.9831				1.4403	
16		1.1469		.1829	.1867	1.406	
17	.1867	.9831		.2658	.1867	1.4842	
18	.1867		.1715	.2629	.2801	.3429	
19	.2801	.4049	.5144	.5201	.2801	.4239	
20	.2801	.4915	.6335	.5144	.3734	.5258	
21	.1867	.4049	.5258	.4287	.5601	.5144	
22		.3239	.443	.3429	.4668	.4287	
23		.3239	.3506	.3429	.3734	.3429	
24	.663	.3315	.5735	.6859		.3734	
Max	**1.5203**	**1.1469**	**1.5746**	**1.6404**	**1.3927**	**1.5384**	**1.4232**
Min	**.1867**	**.3239**	**.1715**	**.1829**	**.1867**	**.3429**	**.2572**
Avg	**.7458**	**.6194**	**.8013**	**.7640**	**.7437**	**.9380**	**.5601**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION
Feeder No / Name : 203 / 11 KV Kharosa Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515		.2515	.2629	.2572		.3429
2	.2515		.2515	.2572	.2572		.503
3	.3353		.3353	.3391	.3429		.6478
4							.7287
5							.7621
6							.7621
7							.9145
8							.9145
9						.8573	.8573
10	.4973	.3315	.503	.5144	.4287		
11	.8288	.6706	.6706	.6554	.8288		
12	.8288	.6706	.703	.6554	.9116		
13	.8288	.5868	.3353	.7545	.7459		
14	.9145	.7545	.6097	.7545	.5801		
15	.9945	.8192	.6097	.7716	.663		
16	.8288	.7545	.6859	.8383		.0867	
17	.8288	.9221	.7811	.8383	.8288	.0848	
18	.1867	.0838	.1715	.1886	.1867	.1715	
19	.3734	.503	.5201	.5487		.5087	
20	.4668	.5868	.6201			.5868	
21	.5601	.503	.4382			.3544	
22		.4191	.4382	.3429		.2658	
23		.3353	.3391	.2572		.1753	
24	.2515	.3734	.2515	.2715	.2629	.3315	.2572
Max	**.9945**	**.9221**	**.7811**	**.8383**	**.9116**	**.8573**	**.9145**
Min	**.1867**	**.0838**	**.1715**	**.1886**	**.1867**	**.0848**	**.2572**
Avg	**.5767**	**.5543**	**.4731**	**.5157**	**.5245**	**.3423**	**.6690**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION
Feeder No / Name : 204 / 11 KV Lamjana II SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.6001	.7087	.5935		.3506
2	.6859		.6001	.7011	.6783		.3506
3	.6859		.6859	.7716	.6706		.4287
4	.7716		.7716	.8478	.8288		
5	.8573		.8573	1.0898	.9945		
6	1.0288		1.0402	1.0898	1.1203		
7	1.2003		1.387	1.2146	1.186		
8	1.3927		1.3565	1.3603	1.1717		
9	1.326		1.2717	1.1431	1.1717		
10						.8383	.5935
11						1.0526	1.1717
12						1.1431	
13						1.0936	
14		1.0898				1.0802	
15		.9012				1.1469	
16		1.0898	.381	.3506		1.1603	
17	.3734	1.0774	.5144	.5201	.4668	1.2003	
18	.5601	.5144	.5144	.6001	.5601	.3429	
19	.6535	.8192	.763	.8478	.6535	.7545	
20	.7468	.9116	.8573	.8478	.7468	.8192	
21	.6535	.7716	.6935	.6706	.7468	.5935	
22		.6001	.6135	.503	.5601	.5258	
23		.4287	.4525	.5087	.4668	.4334	
24	.6068	.4973	.5144	.6001	.5087		.3429
Max	**1.3927**	**1.0898**	**1.387**	**1.3603**	**1.186**	**1.2003**	**1.1717**
Min	**.3734**	**.4287**	**.381**	**.3506**	**.4668**	**.3429**	**.3429**
Avg	**.8152**	**.7910**	**.7708**	**.7986**	**.7721**	**.8703**	**.5397**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION
Feeder No / Name : 206 / 11 KV Chalburga SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.2429	.2629	.2629		.7716
2	.1619		.2458	.2629	.3544		.8383
3	.2429		.2372	.2572	.3429		.8192
4							.9374
5							.9907
6							1.1431
7							1.2193
8							1.2955
9						1.0669	1.2955
10		.4973	.8697	.8573	.8288		
11		1.2289	1.2193	1.2193	1.4089		
12			1.2955	1.2955	1.326		
13	1.0774		1.2955	1.2193	1.2431		
14	1.1603	1.2955	1.2955	1.2193	1.1603		
15	1.326	1.3108	1.2955	1.2193	.9945		
16	1.326	1.2146	1.2955	1.2803		.0876	
17	1.326	1.4918	1.2193	1.2803	.663	.0886	
18	.1658	.2286	.2572		.2801	.3506	
19	.2801	.2286	.3506		.3734	.4287	
20	.2801	.2286	.4191		.3734	.4287	
21	.3734	.2372	.4382	.5087	.3734	.3506	
22		.2372	.3544	.4382	.2801	.3429	
23		.2401	.3506	.2601	.2801	.2686	
24	.0953	.2801	.2515	.2629	.2515		.6554
Max	**1.326**	**1.4918**	**1.2955**	**1.2955**	**1.4089**	**1.0669**	**1.2955**
Min	**.0762**	**.2286**	**.2372**	**.2572**	**.2515**	**.0876**	**.6554**
Avg	**.6070**	**.6707**	**.7185**	**.7896**	**.6351**	**.3792**	**.9966**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA
Feeder No / Name : 201 / 11 KV Tambarwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9588	.9431	.9431		.6097	.3429	.3048
2	1.046	.9431	.8383	1.0288	.6097	.0343	.3429
3	1.046	1.0288	.9145	1.0288	.7621	.4287	.381
4	1.1331	1.1145	.9907	1.3717	.8383		
5	1.6561	1.7147	1.5242	1.3717	.1524		
6	1.9176	1.9719	1.9719	1.6766	1.6766		
7	2.0047	2.0576	2.0576	2.0576	1.7528		
8	2.0919		2.21	2.0576	1.829		
9	2.0919	1.6766	2.8292	2.0576	1.7528		
10						.8573	.6001
11						.9145	1.3717
12						1.5242	1.5432
13						2.0576	1.829
14						1.829	
15						2.1434	
16	.3487	.3429			.3048	1.829	
17	.3487	.3048	.3487	.3048	.3048	1.829	
18	.2615	.3429	.3487	.2286		.3048	
19	.523	.5144	.4358	.3048	.381	.0343	
20	.523	.5144	.523	.3048	.4572	.4572	
21	.4358	.5144	.4358	.381	.381	.5144	
22	.381	.5144	.3429	.3429	.4287		.3429
23	.3048	.381	.3048	.6859	.0429	.3048	.3429
24	.8716	.6097	.6097	.6097		.381	.3048
Max	**2.0919**	**2.0576**	**2.8292**	**2.0576**	**1.829**	**2.1434**	**1.829**
Min	**.2615**	**.3048**	**.3048**	**.2286**	**.0429**	**.0343**	**.3048**
Avg	**.9969**	**.9111**	**1.0370**	**.9883**	**.7677**	**.9286**	**.7363**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA
Feeder No / Name : 202 / 11 KV Shivani-Luc SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1524	.1524		.1524	.1524	.4572
2	.1543	.1524	.1524	.1524	.1524	.1524	.3048
3	.1543	.1524	.1524	.1524	.1524	.2286	.5335
4						.2286	.6097
5						.381	.6859
6						.5335	.6859
7						.7621	.7621
8						.9145	
9						.7621	.9145
10	.3086	.3048	.3048	.6097	.3048		
11	.6944	.6097	.463	.6097	.3048		
12	.6944	.6859	.5401	.7621	.4572		
13	.6944	.7621	.6173	.6859	.4572		
14	.6173	.7621	.5401	.6859	.4572		
15	.6173	.9145	.5401	.7621	.4572		
16	.6944	.9145	.6173	.9145	.4572	.0762	
17	.6944	.9907	.6173	.9145	.5335	.0762	
18	.0772	.0762	.0772	.0762	.0762	.7621	
19	.1543	.1524	.1543	.1524	.1524	.0762	
20	***	.1524	.2315	.1524	.2286	.0762	
21	.1543	.1524	.1543		.1524	.1715	
22	.1524	.1524	.1524	.1524	.1524		.1524
23	.1524	.1715	.1524	.1524	.1524	.1524	.3048
24	.1543	.1524	.1524	.1524		.1524	.2286
Max	**24.1204**	**.9907**	**.6173**	**.9145**	**.5335**	**.9145**	**.9145**
Min	**.0772**	**.0762**	**.0772**	**.0762**	**.0762**	**.0762**	**.1524**
Avg	**1.6913**	**.4117**	**.3207**	**.4430**	**.2824**	**.3328**	**.5127**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA
Feeder No / Name : 203 / 11 KV Kharosa SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5641	.5335	.5335		.5335	.5335	.8383
2	.5641	.5335	.5335	.5335	.5335	.5335	.9145
3	.7253	.6097	.5335	.6097	.6097	.6097	.9907
4						.7621	1.2193
5						.0838	1.2193
6						.9145	1.3717
7						1.0669	1.6766
8						1.2193	
9						1.3717	1.9814
10	.8059	.7621	.7621	.7621	.9907		
11	1.4506	1.1431	.9671	1.3717	.9907		
12	1.1283	1.2193	.9671	1.6766	1.0669		
13	.8865	1.3717	.9671	1.3717	1.0669		
14		1.6766	.8865	1.448	1.0669		
15	1.0477	1.6766	.9671	1.448	.9145		
16	1.1283	1.829	1.1283	1.5242	1.1431	.4572	
17	1.2894	1.9814	1.1283	1.5242	1.2955	.5335	
18	.3224	.7621	.4029	.6097	.3048	.7621	
19	.7253	.7621	.6447	.6097	.6097	.7621	
20	.6447	.6859	.6447	.6859	.6097	.6859	
21	.7253	.6859	.6447	.6859	.6097	.6859	
22	.6859	.6097	.6097	.6097	.6097		.6097
23	.6097	.6097	.5335	.5335	.6097	.6097	.6859
24	.6447	.6097	.5335	.5335		.6097	.7621
Max	**1.4506**	**1.9814**	**1.1283**	**1.6766**	**1.2955**	**1.3717**	**1.9814**
Min	**.3224**	**.5335**	**.4029**	**.5335**	**.3048**	**.0838**	**.6097**
Avg	**.8205**	**1.0034**	**.7438**	**.9728**	**.7980**	**.7177**	**1.1154**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA
Feeder No / Name : 204 / express feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1869	.3429	.3429		.3429	.3429	.3429
2	.1869	.3429	.3429	.3429	.3429	.3429	.3429
3	.1869	.3429	.3429	.3429	.3429	.3429	.3429
4	.1869	.3429	.3429	.3429	.3429	.3429	.3429
5	.1869	.3429	.3429	.3429	.3429	.3429	.3429
6	.1869	.3429	.3429	.3429	.3429	.3429	.3429
7	.1869	.3429	.3429	.1715	.3429	.3429	.3429
8	.2804		.3429	.1715	.3429	.3429	
9	.3738	.3429	.3429	.1715	.3429	.3429	.3429
10	.3738	.3429	.3429	.3429	.3429	.3429	.3429
11	.3738	.2572	.2804	.3429	.3429	.3429	.2286
12	.3738	.2572	.2804	.3429	.3429	.3429	.2572
13	.3738	.3429	.2804	.3429	.3429	.3429	.3429
14	.3738	.3429	.3738	.3429	.3429	.3429	
15	.3738	.3429	.3738	.3429	.3429	.3429	
16	.3738	.3429	.3738	.3429	.3429	.3429	
17	.3738	.3429	.3738	.0343	.3429	.3429	
18	.3738	.3429	.2804	.3429	.0857	.3429	
19	.3738	.3429	.1869	.2572	.0857	.2572	
20	.1869	.1715	.1869	.2572	.0857	.0857	
21	.1869	.1715	.1869	.3429	.0857	.0857	
22	.1715	.1715	.3429	.3429	.1715		.2572
23	.1715	.3429	.3429	.3429	.1715	.2572	.2572
24	.2804	.1524	.3429	.3429		.0857	.3429
Max	**.3738**	**.3429**	**.3738**	**.3429**	**.3429**	**.3429**	**.3429**
Min	**.1715**	**.1524**	**.1869**	**.0343**	**.0857**	**.0857**	**.2286**
Avg	**.2791**	**.3048**	**.3181**	**.2997**	**.2833**	**.3019**	**.3181**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI
Feeder No / Name : 201 / 11 KV Yelli SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4876		1.5013	1.5223	2.0412	.9669	.6228
2	1.4876	1.8557	1.689	1.7299	2.0736	1.1157	.6228
3	1.8595	2.3777	1.6838	1.9029	2.4124	.9669	.6574
4	2.2314	2.4148	1.8766	2.1451	2.6006		
5	2.3801	2.4495	2.0643	2.2489	2.6907		
6	2.4545	2.4495	2.2519	2.4192	2.7464		
7	2.8264	2.6722	2.4421	2.592	2.7492		
8	2.6776	2.6749	2.2451	2.6957	2.3753		
9	2.4545	2.7464	2.2519	2.4192	2.3034		
10						1.728	
11						2.0736	
12						2.3501	
13						2.2464	
14		.3753				1.728	
15		.3753				1.9354	2.0643
16	.4087	.3753	.3456		.4091	2.0045	
17	.4458	.3753	.4147	.4087	.4649	2.0045	1.689
18	.483	.4504	.5542	.668	.4463	.5542	.2252
19	.7776	.898	.762	.8907	.8925	.8659	.9758
20	.8359	1.126	1.0391	.864	.9669	1.1776	1.2198
21	.8359	1.0884	.8659	1.0031	1.1157	1.0391	1.126
22	.8173	.9758	.762	.9288	1.1529	.8659	.9383
23	.8173	.8471	.6927	1.2619	.9669	.7274	.7882
24		1.5013	1.3839	1.3839	.8925		.7506
Max	**2.8264**	**2.7464**	**2.4421**	**2.6957**	**2.7492**	**2.3501**	**2.0643**
Min	**.4087**	**.3753**	**.3456**	**.4087**	**.4091**	**.5542**	**.2252**
Avg	**1.4871**	**1.4752**	**1.3792**	**1.5932**	**1.6278**	**1.4324**	**.9734**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI
Feeder No / Name : 202 / 11 KV Kinnithot SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2975	.2601	.3753	.173	.2227	.6701	.346
2	.3719	.3715	.3742	.2768	.1856	.6694	.3806
3	.3347	.4454	.3753	.3114	.1856	.7438	.4844
4						.8182	.5536
5						.9669	.8294
6						1.1157	1.038
7						1.2657	1.1417
8						1.1901	1.1751
9						1.1157	.9331
10	.7423	.7694	.7266	.6912	.8182		
11	1.0031	.9383	.864	.8916	1.0413		
12	1.0402	.9758	.864	.9278	.9669		
13	1.0031	.8632	.8294	.9288	1.0072		
14	.956	.8531	.8294	.8907	.9297		
15	.956	.8445	.7949	.8916	.8925		
16	1.0392	.9383	.7603		.9297	.1382	
17	1.0031	.9758	.864	.8359	.8925	.1728	
18	.1115	.1501	.2425	.2601	.2975	.2425	.2252
19	.3344	.3742	.3117	.2972	.4091	.3464	.3753
20	.3711	.4677	.381	.3344	.4091	.4849	.4504
21	.3711	.4677	.3464	.3715	.3719	.4156	.4504
22	.334	.4677	.3117	.4087	.3347	.3464	
23	.2419	.3753	.2771	.3715	.3723	.3117	.3753
24	.2227	.3753		.3711	.5207		.3753
Max	**1.0402**	**.9758**	**.864**	**.9288**	**1.0413**	**1.2657**	**1.1751**
Min	**.1115**	**.1501**	**.2425**	**.173**	**.1856**	**.1382**	**.2252**
Avg	**.5963**	**.6063**	**.5605**	**.5431**	**.5993**	**.6479**	**.6089**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI
Feeder No / Name : 203 / 11 KV Tupadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2231	.1856	.2252	.173	.2227	.6694	.4152
2	.2603	.2229	.2627	.2076	.2601	.7438	.5882
3	.1859	.2601	.3003	.2422	.2972	.8182	.6574
4						.8182	.6574
5						.8925	.7612
6						.9669	.865
7						.9669	1.038
8						.9297	1.0022
9						.8925	.9677
10	.8916	.8445		.8907	.8925		
11	.9649	1.0509	.7603	.9649	.9669		
12	.9659	.9698	.8294	1.0021	1.0041		
13	.9928	.9383	.8294	.9928	1.0041		
14	1.0296	.9758	.864	1.02	.9669		
15	.9346	.9758	.8986	.9331	.9669		
16	1.1145	1.0134	.9331	1.0031	1.0413	.0866	.0938
17	1.1505	1.0509	.9331	1.0402	.9669	.1039	.0938
18	.0928	.1126	.1732	.1728	.1488	.1732	.1126
19	.2969	.244	.2771	.2229	.2231	.2771	.1877
20	.334	.3753	.3117	.2601	.2603	.3117	.3003
21	.3344	.3378	.3117	.3715	.2789	.2771	.3003
22	.2765	.3003	.2078	.3711	.2603	.2425	.2627
23	.4152	.3003		.2074	.2234	.2078	.1877
24	.1858	.2252		.173	.6701		.4129
Max	**1.1505**	**1.0509**	**.9331**	**1.0402**	**1.0413**	**.9669**	**1.038**
Min	**.0928**	**.1126**	**.1732**	**.1728**	**.1488**	**.0866**	**.0938**
Avg	**.5916**	**.5769**	**.5412**	**.5694**	**.5919**	**.5516**	**.4947**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL
Feeder No / Name : 201 / 11 KV Limbala Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3094		.2629	.3658	.3506	.7011	.7707
2	.3094		.2658	.3658	.3506	.7011	.7707
3	.3094		.2658	.362	.3506	.7011	.7707
4						.8764	.9248
5						.8573	.9259
6						1.0288	.9259
7						1.0898	1.0802
8						1.0898	1.2346
9						1.0059	
10	.6706	.6859	.6068	.6201	.6001		
11	.9945	1.0288	1.0402		.8573		
12	.9945	1.0155	1.1269		1.0898		
13		.9945	1.2003		1.0898		
14	.9945	1.0402	1.1022		1.065		
15	1.0059	1.1022	1.1022		1.0774		
16	1.0898	1.1022	1.2003		1.1603		
17	1.1736	1.1603	1.2136		1.1603		
18	.1753	.2629	.4477		.2629	.2315	
19	.3582	.4382	.4477			.3858	
20		.3506	.543			.463	
21		.3506	.5487			.463	
22		.3544	.362			.3858	
23		.2601	.3658			.3086	
24	.3094		.2629	.3658	.3506	.5258	.4624
Max	**1.1736**	**1.1603**	**1.2136**	**.6201**	**1.1603**	**1.0898**	**1.2346**
Min	**.1753**	**.2601**	**.2629**	**.362**	**.2629**	**.2315**	**.4624**
Avg	**.6688**	**.7247**	**.6869**	**.4159**	**.7512**	**.6759**	**.8740**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL
Feeder No / Name : 202 / 11 KV Mangrool SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802	.8954	.9745	1.086	1.0631	.3506	.309
2	1.0802	1.0745	1.1393	1.1888	1.1517	.3506	.309
3	1.2346	1.0745	1.1393	1.1765	1.1393	.3506	.309
4	1.2346	1.2003	1.2136	1.3575	1.3146		
5	1.2346	1.2003	1.3146	1.5947			
6	1.3889	1.3717	1.4737	1.9281	1.4575		
7		1.5261	1.4413	1.9281	1.5432		
8	1.5432	1.3413	1.3413	1.8204	1.5089		
9	1.5432	1.5089	1.2717	1.7404	1.5089		
10						.9431	
11						1.3889	
12						1.5432	
13						1.5432	
14						.7716	
15						1.3133	
17						1.5451	
18	.2715	.2658	.3544		.2629	.2318	
19	.4477	.4572	.6135			.3863	
20		.8954	.8859			.5408	
21		.7011	.8059			.5408	
22		.6268	.7164			.5408	
23		.5316	.5544			.3863	
24	.6173	.7316	.7164	.7392	.7011	.4382	.3863
Max	**1.5432**	**1.5261**	**1.4737**	**1.9281**	**1.5432**	**1.5451**	**.3863**
Min	**.2715**	**.2658**	**.3544**	**.7392**	**.2629**	**.2318**	**.309**
Avg	**1.0615**	**.9627**	**.9973**	**1.4560**	**1.1651**	**.7744**	**.3283**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA
Feeder No / Name : 201 / 11 KV Karla SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638			.0762		.5601
2	.1966			.0762		.5601
3	.1966			.1219		.6401
4	.1966			.1219		.6554
5	.2622			.1524		.7373
6	.2622			.1524		.7373
7	.3277			.1524		.7202
8	.2622			.1524		.7373
9	.1966					
10	.1943		.1524			
14					.3201	
15					.6554	
16					.8192	
17	1.117		.9831	.9945	.9012	
18	1.2029		.9831	.9945	.9012	
19	1.0357		.9012	.7373	.8192	
20	.8592		.7202	.7373	.8192	
21			.7202			
22			.6401		.7373	
23			.6401		.7373	
24	.6554	.6015		.5601		.6554
Max	**1.2029**	**.6015**	**.9831**	**.9945**	**.9012**	**.7373**
Min	**.1638**	**.6015**	**.1524**	**.0762**	**.3201**	**.5601**
Avg	**.4753**	**.6015**	**.7176**	**.3869**	**.7456**	**.6670**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA
Feeder No / Name : 202 / 11 KV Kumtha SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201			.4001		.1524
2	.3887			.4801		.2286
3	.4858			.5601		.3048
4	.5182			.5601		
5	.583			.6554		
6	.6478			.6554		
7	.9717			.8192		
8	.8421			.6554		
9						.5601
10						.6874
11					.16	.7733
12					.2401	.6035
13					.4001	
15	.0307		.0762	.1524	.0762	
16	.0306		.0762	.1524	.0762	
17	.046		.0762	.1696	.0762	
18	.0764		.1524	.1989	.1524	
19	.2586		.2286	.192	.3048	
20	.3056		.3048	.3315	.3048	
21			.2286			
22			.2286		.1524	
23			.1524		.1524	
24	.192	.0156		.1524		.6874
Max	**.9717**	**.0156**	**.3048**	**.8192**	**.4001**	**.7733**
Min	**.0306**	**.0156**	**.0762**	**.1524**	**.0762**	**.1524**
Avg	**.3798**	**.0156**	**.1693**	**.409**	**.1905**	**.4997**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA
Feeder No / Name : 203 / 11 KV Sirsal SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1989			.1524	.1989	.0762
2	.1989			.2286	.1989	.1524
3	.1989			.2286	.1989	.1524
4						.2286
5						.3048
6						.3048
7						.381
8						.3048
9	.663				.5967	.2286
10	.8288		.6554		.5636	.0859
11	.8592		.6554		.2401	
12	.6876		.5601	.7459	.3277	
13	.6882		.5601	.7956	.4915	
14	.4607		.5121	.7956	.4915	
15	.7759		.5735	.7459	.6554	
16	.6897		.5735	.7459	.6554	
18	.0764		.0762	.2713	.0762	
19			.3048	.4096	.2286	
20	.4914		.381	.4144	.381	
21			.2286			
22			.2286	.2622	.1524	
23			.0762	.2035	.0762	
24	.1989	.0917		.0762	.1989	.0762
Max	**.8592**	**.0917**	**.6554**	**.7956**	**.6554**	**.381**
Min	**.0764**	**.0917**	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**.5012**	**.0917**	**.4143**	**.4340**	**.3372**	**.2087**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi
Feeder No / Name : 201 / 11 KV Chincholi (T) SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0395			.1753	.3048
2			1.5261			.2103	.2743
3			1.6385			.208	.2743
4			1.7284				
5			1.7924				
6			1.8027				
7			1.8435				
8	1.2517		1.917				
9	1.3032		1.3717	1.7604			
10						1.1584	
11						1.2803	
12						1.4937	
13						1.448	
14						1.3717	
15						1.326	
16	.2667		.2143		.3429	1.4784	
17	.3715	.1715	.2629		.3944	1.5546	
18	.5335	.3155	.2915		.4334	.5335	
19	.6668	.3467			.5784	.6097	
20	.7145	.8215			.5426	.6249	
21	.5716	.4748			.3315	.5792	
22		.3366			.333	.503	
23		.3086			.2947	.4572	.5487
24	.1905	.4001	.6481	.4001	.4001	.2134	.4572
Max	**1.3032**	**.8215**	**1.917**	**1.7604**	**.5784**	**1.5546**	**.5487**
Min	**.1905**	**.1715**	**.2143**	**.4001**	**.2947**	**.1753**	**.2743**
Avg	**.6522**	**.3969**	**1.2367**	**1.0803**	**.4057**	**.8459**	**.3719**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
KILLARI S/DN.[718] BU 4718
Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi
Feeder No / Name : 202 / 11 KV Utka SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1829			1.56	.6097
2			.2195			1.7901	.7926
3			.1905			2.0809	.9907
4						2.1538	1.1431
5						2.2085	1.2193
6						2.2455	1.6004
7						2.2222	2.1186
8						1.6129	2.0119
9						1.9372	
10	1.3108		1.3413	1.3717			
11	1.829		1.9204	1.829			
12	1.9357		1.8747	1.9052			
13	2.0576		1.9052	1.9052			
14	2.1338			1.9052			
15	2.2405						
16	2.0005	1.781	2.0576		1.9204	.0762	
17		2.2405	2.2497		2.0309	.0762	
18	1.929	.2896			.2658	.1829	
19	.2858	.3353			.4801	.2286	
20		.4973			.4191	.2591	
21	.381	.4287			.2629	.2286	
22		.3086			.3601	.1981	
23		.2454			.3052	.1829	.1981
24	.0762	.0762	.1524	.0762	.0762	.535	.5335
Max	**2.2405**	**2.2405**	**2.2497**	**1.9052**	**2.0309**	**2.2455**	**2.1186**
Min	**.0762**	**.0762**	**.1524**	**.0762**	**.0762**	**.0762**	**.1981**
Avg	**1.4709**	**.6892**	**1.2094**	**1.4988**	**.6801**	**1.0988**	**1.1218**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154003 / 33/11 KV NILANGA
Feeder No / Name : 201 / 11 KV SHINDKHED GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4096	.5144	.3277	.3315	.2515	.4191	.4001
7						.6859	.7621
8						.703	.7373
9						.6097	
10						.5335	.4144
12			.5801	.5468			
14				.5601			
16	.5335	.4801	.5801	.663	.5601		
18					.7287	.8192	
20		.4144	.4973		.5668	.5601	
22						.4049	
24	.4382	.3734	.3315	.3582	.1677	.3277	.4096
Max	**.5335**	**.5144**	**.5801**	**.663**	**.7287**	**.8192**	**.7621**
Min	**.4096**	**.3734**	**.3277**	**.3315**	**.1677**	**.3277**	**.4001**
Avg	**.4604**	**.4456**	**.4633**	**.4919**	**.4550**	**.5626**	**.5447**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154003 / 33/11 KV NILANGA
Feeder No / Name : 204 / 11 KV HADGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.7124	1.1919	.5175	.5022
2				1.8625	1.2338	.5175	.5152
3				1.906	1.2887	.5594	.5609
4	1.6604	1.4918	2.5911	3.5955	2.5652	1.2479	1.1548
5				1.7017	1.5013	.6417	.6234
6				2.0523	1.6781		.1212
7				2.9813	2.2763		
8	2.7778	2.8826	2.2862	5.482	4.6769		
9				2.9668	4.6311		
10				4.8431	2.4554		
11				.8878	1.5104	2.633	2.6825
12						2.9271	5.5738
13						5.2004	2.9302
14						5.0061	2.8227
15						2.6589	2.6787
16						5.0327	2.87
17			.2801	.269	.2058	2.982	3.1215
18				.3201	.6295	5.4135	2.995
19				.0975	.3948	.6196	.9358
20		.663	.5601	.6348	1.2917	1.2329	.612
21				.724	.6783	.6821	.6714
22				.1555	.644	1.0989	.6241
23					.6127	.5754	.5761
24	.4191	.4287	.4915	.9984	.8132	1.0616	.9521
Max	**2.7778**	**2.8826**	**2.5911**	**5.482**	**4.6769**	**5.4135**	**5.5738**
Min	**.4191**	**.4287**	**.2801**	**.0975**	**.2058**	**.5175**	**.1212**
Avg	**1.6191**	**1.3665**	**1.2418**	**1.8439**	**1.5936**	**2.1373**	**1.6762**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] **BU 5177**
Substation No/ Name :- 154003 / 33/11 KV NILANGA
Feeder No / Name : 206 / 11 KV DHANORA **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.9326	.9335	.8802	1.7185	1.0936
7						2.21	2.3624
8			.8288			2.2405	2.3205
9						2.1091	
10						1.9204	2.0805
12			1.989	1.9766			
14				1.929			
16	2.3739	2.2405	1.989	1.9766	1.8814		
18					2.0309	.4973	
20		.9326			.8288	.9116	
22						.6554	
24		.663	.6535	.6135	.6401	.5087	.5801
Max	**2.3739**	**2.2405**	**1.989**	**1.9766**	**2.0309**	**2.2405**	**2.3624**
Min	**2.3739**	**.663**	**.6535**	**.6135**	**.6401**	**.4973**	**.5801**
Avg	**2.3739**	**1.2787**	**1.2786**	**1.4858**	**1.2523**	**1.4191**	**1.6874**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154003 / 33/11 KV NILANGA
Feeder No / Name : 207 / 11 KV SHINDKHED AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	31-MAR-17
HR	Load (MW)
24	1.065
Max	1.065
Min	1.065
Avg	1.065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI
Feeder No / Name : 201 / 11 KV KASAR SHIRSHI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.7716	.6859	.9031	.9783
6					1.4861
8				1.8061	2.1548
10				1.4299	.8002
12		1.8814	1.6347		
14	1.8061	1.7833	1.7833		
16	2.0062				
18				.2229	
19			.4515		
20	.9054	.9431			
22	.8299		.602		
23		.7545			
24	.423	1.7833	.7468	.602	.7526
Max	**2.0062**	**1.8814**	**1.7833**	**1.8061**	**2.1548**
Min	**.423**	**.7545**	**.4515**	**.2229**	**.7526**
Avg	**1.1941**	**1.3195**	**.9840**	**.9928**	**1.2344**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI
Feeder No / Name : 202 / 11 KV HASORI GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17
HR	Load (MW)
24	1.065
Max	1.065
Min	1.065
Avg	1.065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI
Feeder No / Name : 204 / 11 KV RAMLING MUDGAD SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3429		.823	.7716	.9659	.9659
6						1.4861
7	.4191					
8					1.7309	1.7833
10					1.5804	.8002
12			1.6857	1.5604		.1677
14		1.6049	1.7238	1.5604		
16		1.7238				
19				.602		
20		1.0562	1.0562			
22		.8676		.602		
23			.9054			
24	.4287	.5144	.7842	.8962	.7526	.743
Max	**.4287**	**1.7238**	**1.7238**	**1.5604**	**1.7309**	**1.7833**
Min	**.3429**	**.5144**	**.7842**	**.602**	**.7526**	**.1677**
Avg	**.3969**	**1.1534**	**1.1631**	**.9988**	**1.2575**	**.9910**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI
Feeder No / Name : 205 / 11 KV HASORI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.381		.3052	.3772		
6			.5487			
7	.4954					
8		.8459				
10						.0381
11					.743	
12					.8916	.6554
18					.8916	
19				.0753		
20		.0754	.0377			
22		.0377				
24	.0476	.0572	.0373	.0373		
Max	**.4954**	**.8459**	**.5487**	**.3772**	**.8916**	**.6554**
Min	**.0476**	**.0377**	**.0373**	**.0373**	**.743**	**.0381**
Avg	**.308**	**.2541**	**.2322**	**.1633**	**.8421**	**.3468**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154016 / 33/11 KV HALGARA
Feeder No / Name : 202 / 11 KV HALGARA GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8573	.9431	.6859	.7716	.7716		.7716
16	.2572	.3429	.1715	.3429	.2572	.2572	
24	.3429	.3429	.3429		.3429	.3429	.3429
Max	.8573	.9431	.6859	.7716	.7716	.3429	.7716
Min	.2572	.3429	.1715	.3429	.2572	.2572	.3429
Avg	.4858	.5430	.4001	.5573	.4572	.3001	.5573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154016 / 33/11 KV HALGARA
Feeder No / Name : 203 / 11 KV SAWARI GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.6001	.6859	.7716	.7716	.6859	.7716
16	.2572	.2572	.2572	.2572	.0857	.2572	
24	.2572	.2572	.2572		.2572	.3429	.2572
Max	.2572	.6001	.6859	.7716	.7716	.6859	.7716
Min	.2572	.2572	.2572	.2572	.0857	.2572	.2572
Avg	.2572	.3715	.4001	.5144	.3715	.4287	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154016 / 33/11 KV HALGARA
Feeder No / Name : 204 / 11 KV SHIRSHI HANGARGA GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6001	.5144	.5144	.5144	.5144	.4287	.5144
16	.1715	.2572	.2572	.1715	.1715	.1715	
24		.2572	.2572		.2572	.2572	.2572
Max	.6001	.5144	.5144	.5144	.5144	.4287	.5144
Min	.1715	.2572	.2572	.1715	.1715	.1715	.2572
Avg	.3858	.3429	.3429	.3430	.3144	.2858	.3858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154016 / 33/11 KV HALGARA
Feeder No / Name : 205 / 11 KV SAWARI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						2.2291	2.1434
16	2.1434	2.3148	2.4006	2.4006	2.0576		
24	.0086	.0857	.0857		.0857	1.2003	1.0288
Max	**2.1434**	**2.3148**	**2.4006**	**2.4006**	**2.0576**	**2.2291**	**2.1434**
Min	**.0086**	**.0857**	**.0857**	**2.4006**	**.0857**	**1.2003**	**1.0288**
Avg	**1.076**	**1.2003**	**1.2432**	**2.4006**	**1.0717**	**1.7147**	**1.5861**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154016 / 33/11 KV HALGARA
Feeder No / Name : 206 / 11 KV HALGARA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.4863	2.2291	2.7435	2.4006	2.4006		
16	.0857	.0857	.0086	.0857	.0857	2.7435	
24	.8573	.8573	1.0288		2.4006	.0857	.0857
Max	**2.4863**	**2.2291**	**2.7435**	**2.4006**	**2.4006**	**2.7435**	**.0857**
Min	**.0857**	**.0857**	**.0086**	**.0857**	**.0857**	**.0857**	**.0857**
Avg	**1.1431**	**1.0574**	**1.2603**	**1.2432**	**1.6290**	**1.4146**	**.0857**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154016 / 33/11 KV HALGARA
Feeder No / Name : 207 / 11 KV TAGARKHEDA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3717	1.2003	1.3717	1.286	1.286		
16	.0857	.0857	.0086	.0857	.0857	1.286	
24	.4287	.5144	.6001		.6001	.0857	.0857
Max	**1.3717**	**1.2003**	**1.3717**	**1.286**	**1.286**	**1.286**	**.0857**
Min	**.0857**	**.0857**	**.0086**	**.0857**	**.0857**	**.0857**	**.0857**
Avg	**.6287**	**.6001**	**.6601**	**.6859**	**.6573**	**.6859**	**.0857**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154016 / 33/11 KV HALGARA
Feeder No / Name : 209 / 11 KV SHIRSHI HANGARGA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						2.0576	2.572
16	1.8004	1.8861	1.7147	1.8861	1.8861		
24						.6859	.7716
Max	**1.8004**	**1.8861**	**1.7147**	**1.8861**	**1.8861**	**2.0576**	**2.572**
Min	**1.8004**	**1.8861**	**1.7147**	**1.8861**	**1.8861**	**.6859**	**.7716**
Avg	**1.8004**	**1.8861**	**1.7147**	**1.8861**	**1.8861**	**1.3718**	**1.6718**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI
Feeder No / Name : 201 / 11 KV PANCHINCHOLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17
HR	Load (MW)
1	.9503
Max	.9503
Min	.9503
Avg	.9503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI
Feeder No / Name : 202 / 11 KV TUPADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.0351	.0343		.0175		
7						2.0348	2.3908
8							1.7804
9							1.9313
10		.3944		1.4373			
12					1.989		
14	1.9669	1.8991					
15	2.0008			1.9456	2.0348		
16		1.9719					
17					2.1262		
18						.0177	
20		.0347					
21					.0343		
22	.0354			.0343			
23				.0171			
24			.0177			1.0852	
Max	**2.0008**	**1.9719**	**.0343**	**1.9456**	**2.1262**	**2.0348**	**2.3908**
Min	**.0354**	**.0347**	**.0177**	**.0171**	**.0175**	**.0177**	**1.7804**
Avg	**1.3344**	**.8670**	**.026**	**.8586**	**1.2404**	**1.0459**	**2.0342**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI
Feeder No / Name : 204 / 11 KV GOUR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			1.2309			.7545	
7			1.7974				
8		2.2502			1.8054		
9		1.8551		1.8229	1.8143		
10							1.2934
11						1.6476	
13						1.7878	
14						1.3672	
15					.3052		
16		.2774					
17					.3294		
21					.7628		
22				.6554			
23				.6104			
24	1.858		.8589	1.9806		.6661	
Max	**1.858**	**2.2502**	**1.7974**	**1.9806**	**1.8143**	**1.7878**	**1.2934**
Min	**1.858**	**.2774**	**.8589**	**.6104**	**.3052**	**.6661**	**1.2934**
Avg	**1.858**	**1.4609**	**1.2957**	**1.2673**	**1.0034**	**1.2446**	**1.2934**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] **BU 5177**
Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI
Feeder No / Name : 205 / 11KV SHARADA CON.EXPRESS FDR Feeder KV- 11 / OUTGOING
NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.1577				
7			.0107			.039	
8		.0762			.0266		
9							.0177
10		.0904		.0496			.0159
12					.2746		
14	.0543	.0939					
15	.305			.0372	.1134		
16		.0248					
17					.2561		
21					.043		
22				.0177			
23				.0177			
24			.208	.026		.2202	.0104
Max	**.305**	**.0939**	**.208**	**.0496**	**.2746**	**.2202**	**.0177**
Min	**.0543**	**.0248**	**.0107**	**.0177**	**.0266**	**.039**	**.0104**
Avg	**.1797**	**.0713**	**.1255**	**.0296**	**.1427**	**.1296**	**.0147**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154029 / 33/11 KV MADANSURI
Feeder No / Name : 202 / 11 KV MADANSURI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.8309	.6874	.6702	
9					.8421
16	.8309	.8421		.7733	
24		.4409	1.4883	.4889	
Max	**.8309**	**.8421**	**1.4883**	**.7733**	**.8421**
Min	**.8309**	**.4409**	**.6874**	**.4889**	**.8421**
Avg	**.8309**	**.7046**	**1.0879**	**.6441**	**.8421**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154029 / 33/11 KV MADANSURI
Feeder No / Name : 203 / 11 KV RAMTIRTH SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.3102	.1959		.3755	
9						.7511
16	.9143	.9797		1.0123	.7674	
24		.1959	2.0849		.1652	
Max	.9143	.9797	2.0849	1.0123	.7674	.7511
Min	.9143	.1959	.1959	1.0123	.1652	.7511
Avg	.9143	.4953	1.1404	1.0123	.4360	.7511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154029 / 33/11 KV MADANSURI
Feeder No / Name : 204 / 11 KV DONGARGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17
HR	Load (MW)
24	1.065
Max	1.065
Min	1.065
Avg	1.065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA
Feeder No / Name : 201 / 11 KV KASAR BALKUNDA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.7373	.6882	.9156
Max	.7373	.6882	.9156
Min	.7373	.6882	.9156
Avg	.7373	.6882	.9156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA
Feeder No / Name : 202 / 11 KV TAMBALA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16			1.528		
24	.3052	.3056		.3056	.5328
Max	.3052	.3056	1.528	.3056	.5328
Min	.3052	.3056	1.528	.3056	.5328
Avg	.3052	.3056	1.528	.3056	.5328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA
Feeder No / Name : 203 / 11 KV TAKLI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16			1.454		
24	1.0501	.9694	1.2117	.9694	.6485
Max	1.0501	.9694	1.454	.9694	.6485
Min	1.0501	.9694	1.2117	.9694	.6485
Avg	1.0501	.9694	1.3329	.9694	.6485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154046 / 33/11 KV ZARI
Feeder No / Name : 201 / 11 KV LAMBOTA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5223	1.6289	1.4998	1.5242	.543	.8059	1.2717
2	1.4327	1.6289	1.4967	1.5242	.5373	.8145	1.1869
3	1.2536	1.5432	1.5773	1.5242	.5373	.8954	1.1869
4						.8954	1.1022
5						1.1517	1.2717
6						1.2403	1.5261
7						1.5947	2.0348
8						1.949	2.0348
9							1.8652
12		1.1641	1.4146	1.6872	.5373		
13	1.7147	1.5935	1.6804	2.005	1.2536		
14	2.0576	1.3176	2.2405	2.0005	1.4175		
15	1.8861	1.8633	2.2405	2.0767	1.5947		
16	1.8861	1.6842	2.1472	2.1746	1.5947		
17	2.2291	1.9982	2.2405	2.2557	1.5775		
18	2.0576	2.0838		2.1672	1.7528		
19	1.7147	1.8359	1.9052	1.5891	1.7528		
20	1.3717	1.7564	1.9052	1.3535	1.5775	1.3927	
21	1.5432	1.6842	1.9052	1.2703	1.4175	1.3108	
22	1.5432	1.6842	1.8099		1.2536	1.4413	
23	1.3717	1.5226	1.7147	.7499	1.2536	1.4413	
24	1.5223	1.3717	1.4397	1.6194	.5641	1.1641	1.3565
Max	**2.2291**	**2.0838**	**2.2405**	**2.2557**	**1.7528**	**1.949**	**2.0348**
Min	**1.2536**	**1.1641**	**1.4146**	**.7499**	**.5373**	**.8059**	**1.1022**
Avg	**1.6738**	**1.6475**	**1.8145**	**1.7014**	**1.1978**	**1.2382**	**1.4837**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154046 / 33/11 KV ZARI
Feeder No / Name : 204 / 11 KV KATE JAWALGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	1.0288	1.1869	1.4289	.9097	.4477	.4239
2	1.1641	1.286	1.3565	1.6194	.905	.5373	.4239
3	1.3289	1.3717	1.438	1.6194	.8954	.5373	.4239
4	1.4022	1.4575	1.1022	1.8099	.8859		
5	1.6289	1.8861	1.3489	2.2862	1.3289		
6	1.95	2.1434	2.005	2.6139	1.7147		
7		2.0576	1.5935	2.2405	2.2043		
8	2.4034	2.4348	1.6804		1.9062		
9	2.4863	2.3445	2.3339		2.1548		
10						1.3927	
11						2.2119	
12						2.2939	
13						2.3266	
14						2.2939	
15						2.2119	
16	.0857	.1899	.1867	.189	.1772	2.2939	
17	.2572	.1901	.2801	.2832	.1772		
18	.3429	.2849	.2858	.2835	.2686	.1715	
19	.3429	.4734	.381	.4715	.3582	.4096	
20	.4287	.5658	.6668	.5647	.5373	.4915	
21	.4287	.4725	.5716	.5647	.5373	.4915	
22	.4287	.3788	.4763		.4477	.4915	
23	.4287	.3788	.4763	.3772	.4525	.5087	
24	.6335	.3429	.5664	.7621	.378	.4477	.4239
Max	**2.4863**	**2.4348**	**2.3339**	**2.6139**	**2.2043**	**2.3266**	**.4239**
Min	**.0857**	**.1899**	**.1867**	**.189**	**.1772**	**.1715**	**.4239**
Avg	**.9786**	**1.0715**	**.9965**	**1.1409**	**.9022**	**1.1505**	**.4239**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154046 / 33/11 KV ZARI
Feeder No / Name : 205 / 11KV KELGAON SPP SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0745	1.2003	1.2186	1.5242	1.086	.7164	.5087
2	1.4327	1.5432	1.307	1.5242	1.0745	.7164	.5087
3	1.4327	1.5432	1.307	1.5242	1.1641	.7164	.4572
4	1.3289	1.6289	1.5822	1.7147	1.2536		
5	1.949	1.7147	1.9982	2.0005	1.5223		
6	2.3663	1.8861	2.3312	2.6673	1.6832		
7	2.6282	2.0576	2.492	2.9874	2.3034		
8	2.572	2.0576	2.492	2.894	2.4272		
9	1.7147	2.3312	2.492	2.9874	2.4272		
10						.9831	
12						1.8023	
14						1.8023	
15					.3506	1.9662	
16	.1715	.1901	.5601	.5664	.5316	2.13	
17	.3429	.5658	.6535	.6588	.7973	1.6385	
18	.4287	.8488	.8573	.7537	1.2403	.2458	
19	1.0288	1.319	1.2384	1.2223	1.2403	.6554	
20	1.1145	1.5074	1.5242	1.406	1.3289	1.1469	
21	.8573	1.1305	1.3336	1.3123	1.2403	1.1469	
22	.6859	1.0374	1.2384		1.1641	1.3108	
23	.5144	.944	.9907	.9412	1.0745	.8478	
24	.7716	.5144	1.1294	1.3336	.7537	.985	.6783
Max	**2.6282**	**2.3312**	**2.492**	**2.9874**	**2.4272**	**2.13**	**.6783**
Min	**.1715**	**.1901**	**.5601**	**.5664**	**.3506**	**.2458**	**.4572**
Avg	**1.2453**	**1.3345**	**1.4859**	**1.6481**	**1.2981**	**1.1756**	**.5382**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] **BU 5177**
Substation No/ Name :- 154056 / 33/11 KV AURAD
Feeder No / Name : 201 / 11 KV AURAD **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4668						
8	.7468	.8192	.9335	.6859	.7716		
10						.7468	.7545
16	.0943	.0943	.0905		.0934	.9335	
18	.0943						
20	.0943						
24	.3734	.3772	.0905	.2572	.2829	.0934	
Max	**.7468**	**.8192**	**.9335**	**.6859**	**.7716**	**.9335**	**.7545**
Min	**.0943**	**.0943**	**.0905**	**.2572**	**.0934**	**.0934**	**.7545**
Avg	**.3117**	**.4302**	**.3715**	**.4716**	**.3826**	**.5912**	**.7545**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154056 / 33/11 KV AURAD
Feeder No / Name : 202 / 11 KV SHELGI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0514				
8			.0328		1.8861
16		1.8861		1.8861	
17					.0514
24	.0686		1.326		.3429
Max	**.0686**	**1.8861**	**1.326**	**1.8861**	**1.8861**
Min	**.0514**	**1.8861**	**.0328**	**1.8861**	**.0514**
Avg	**.06**	**1.8861**	**.6794**	**1.8861**	**.7601**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154056 / 33/11 KV AURAD
Feeder No / Name : 203 / 11 KV SHELGI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4904						
8	.7545	.7842	.7468	.905	.8215	.8299	.7167
10						.5281	.5281
12	.3174			.3361			
14	.3395			.2987			
16	.2987	.3018	.2715		.3734	.3395	
18	.4668						
20	.7468						
24	.3772	.4294		.4525	.415	.4108	
Max	**.7545**	**.7842**	**.7468**	**.905**	**.8215**	**.8299**	**.7167**
Min	**.2987**	**.3018**	**.2715**	**.2987**	**.3734**	**.3395**	**.5281**
Avg	**.4739**	**.5051**	**.5092**	**.4981**	**.5366**	**.5271**	**.6224**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] **BU 5177**
Substation No/ Name :- 154056 / 33/11 KV AURAD
Feeder No / Name : 204 / 11 KV AURAD GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5487						
8	.7392	.8145	.924	.8145	.8316	.9145	.924
10						.9145	.924
12	.6335			.7392			
14	.6468			.6468			
16	.6401	.7316	.8145		.7392	.7392	
18	.7392				.8316		
20	.8402						
24	.4572	.4715		.543	.4668	.5544	
Max	**.8402**	**.8145**	**.924**	**.8145**	**.8316**	**.9145**	**.924**
Min	**.4572**	**.4715**	**.8145**	**.543**	**.4668**	**.5544**	**.924**
Avg	**.6556**	**.6725**	**.8693**	**.6859**	**.7173**	**.7807**	**.924**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] **BU 5177**
Substation No/ Name :- 154056 / 33/11 KV AURAD
Feeder No / Name : 205 / 11KV GRAM PANCHYAT AURAD **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.462						
8	.905	.905	.9955	.905	.8316	.7392	.823
10						.5544	.6335
12	.4572			.462			
14	.3734			.3696			
16	.3696	.3696	.4525		.3658	.362	
18	.4668						
20	.6535						
24	.3696	.2801		.6335	.3772	.3658	
Max	**.905**	**.905**	**.9955**	**.905**	**.8316**	**.7392**	**.823**
Min	**.3696**	**.2801**	**.4525**	**.3696**	**.3658**	**.362**	**.6335**
Avg	**.5071**	**.5182**	**.724**	**.5925**	**.5249**	**.5054**	**.7283**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154063 / 33/11 KV MASALGA
Feeder No / Name : 201 / 11 KV MUGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3						.1638	.1715
4			.7716	.7296			
6		.6554	.9431				
7	.905	1.065			.9326		
8	1.0974	1.065	1.1145	.9728			
9	.9221	.9831		1.0745	.8478		
11							.8917
16		.1715	.1621		.1638	1.1145	
18			.1621	.1696		.1715	
19					.2458		
21			.2432		.2458		
24	.5316	.4915	.4053		.3429	1.1145	.1621
Max	**1.0974**	**1.065**	**1.1145**	**1.0745**	**.9326**	**1.1145**	**.8917**
Min	**.5316**	**.1715**	**.1621**	**.1696**	**.1638**	**.1638**	**.1621**
Avg	**.8640**	**.7386**	**.5431**	**.7366**	**.4631**	**.6411**	**.4084**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154063 / 33/11 KV MASALGA
Feeder No / Name : 202 / 11 KV KOTAL SHIVANI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17
HR	Load (MW)
24	1.278
Max	1.278
Min	1.278
Avg	1.278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154063 / 33/11 KV MASALGA
Feeder No / Name : 203 / 11 KV MASALGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3						.1905	.1715
4			.8573	.9526			
6		1.0479	1.0288				
7	1.1145	1.3336			1.2269		
8	1.267	1.3336	1.1145	1.2384			
9	1.1393	1.3336		1.1888	1.2803		
11							1.1431
16		.1715	.1905		.1905	1.1145	
17	.1905						
18			.1905	.1772		.1715	
19					.1905		
21			.2858		.2858		
22	.2858						
24	.6783	.5716	.381		.5258	1.1145	.1905
Max	**1.267**	**1.3336**	**1.1145**	**1.2384**	**1.2803**	**1.1145**	**1.1431**
Min	**.1905**	**.1715**	**.1905**	**.1772**	**.1905**	**.1715**	**.1715**
Avg	**.7792**	**.9653**	**.5783**	**.8893**	**.6166**	**.6478**	**.5017**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] **BU 5177**
Substation No/ Name :- 154072 / 33/11 KV BORSURI
Feeder No / Name : 201 / 11 KV SONKHED **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573		.078	.8573		.0693	.7716
2	.8573		.0867	.9431		.0693	.8573
3	.8573		.0867	.9431		.0867	.8573
10	.8573	1.387	1.2003	1.2003	.104	.104	
11	1.8861	.6935	1.7147	1.9719		1.9719	
12		.1387	1.8861	1.9938	.1387	1.1145	
13		.1734	1.7147	1.9938	.1647	1.4575	
14		.1734	1.5432	1.9071	.1647	1.3717	
15		.1734	1.5432	1.8204	.1647	1.5432	
16	1.8204	.1907	1.9719	1.9938	.1907	1.2003	
17		.208	2.0576		.208	1.8861	
18		.0347	.3429	.5201	.0433	.2572	
19		.0069	.6859		.0954	.6859	
20		.0954	.9431		.0954	.8573	
21		.0954	.9431		.0867	.8573	
22		.8583	.8573		.0867	.8573	
23		.078	.8573	.9536	.0693	.7716	
24	.7716	.7802	.078	.8573	.7802	.0693	.7716
Max	**1.8861**	**1.387**	**2.0576**	**1.9938**	**.7802**	**1.9719**	**.8573**
Min	**.7716**	**.0069**	**.078**	**.5201**	**.0433**	**.0693**	**.7716**
Avg	**1.1296**	**.3391**	**1.0328**	**1.3812**	**.1709**	**.8461**	**.8145**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154072 / 33/11 KV BORSURI
Feeder No / Name : 202 / 11 KV BORSURI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17
HR	Load (MW)
24	1.4091
Max	1.4091
Min	1.4091
Avg	1.4091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154072 / 33/11 KV BORSURI
Feeder No / Name : 203 / 11 KV CHANDORI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17
HR	Load (MW)
24	1.1142
Max	1.1142
Min	1.1142
Avg	1.1142

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] **BU 5177**
Substation No/ Name :- 154078 / 33/11 KV NITUR
Feeder No / Name : 201 / 11 KV NITUR **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		1.5684	1.8671			.9556	.9054
7				3.5848			
8	2.8178	2.9835	3.3234				
9				3.3234			
12						2.6139	
13					.5571		
14						2.7633	
16		.3696	.5853			2.838	
17					.5914		
20	1.3717	1.3203					
21					1.2449		
24	1.419	.9602	1.0242	1.0722		.8551	.9145
Max	**2.8178**	**2.9835**	**3.3234**	**3.5848**	**1.2449**	**2.838**	**.9145**
Min	**1.3717**	**.3696**	**.5853**	**1.0722**	**.5571**	**.8551**	**.9054**
Avg	**1.8695**	**1.4404**	**1.7**	**2.6601**	**.7978**	**2.0052**	**.9100**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154078 / 33/11 KV NITUR
Feeder No / Name : 202 / 11 KV SHEND FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.5121	1.8671			.8886	1.4712
6						1.2793	
8							1.9022
9						1.9753	
10		1.3435					
11			1.7528				
12		1.829					
13					1.491		
14	1.1279		1.6632				
16		1.7741	1.7193			.4108	
17					1.7002		
20	1.1241	.9054					
21					.7545		
24	.5228	.5281	.5853	.5121		.6036	.6478
Max	**1.1279**	**1.829**	**1.8671**	**.5121**	**1.7002**	**1.9753**	**1.9022**
Min	**.5228**	**.5121**	**.5853**	**.5121**	**.7545**	**.4108**	**.6478**
Avg	**.9249**	**1.1487**	**1.5175**	**.5121**	**1.3152**	**1.0315**	**1.3404**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154078 / 33/11 KV NITUR
Feeder No / Name : 203 / 11 KV BASPUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.3521	.6348			1.643	1.6598
6						1.5384	
8							2.4143
9						2.1216	
10		1.2498					
11			2.0767				
12		2.0119					
13					1.7695		
14	1.6309		1.9387				
16		2.0328	2.0668			.2241	
17					2.1437		
20	.9145	.7922					
21					.679		
24	.3734	.3841	.4024	.3521		.6706	.724
Max	**1.6309**	**2.0328**	**2.0767**	**.3521**	**2.1437**	**2.1216**	**2.4143**
Min	**.3734**	**.3521**	**.4024**	**.3521**	**.679**	**.2241**	**.724**
Avg	**.9729**	**1.1372**	**1.4239**	**.3521**	**1.5307**	**1.2395**	**1.5994**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154104 / 33/11 KV NANAND
Feeder No / Name : 201 / 11 KV NANAND SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4062	.3963	.5544	.381	.2134	1.0164	.8322
2	.4687	.4572		.4458	.2134	1.086	.8802
3	.4999	.4572	.5853	.5201	.3048	1.2003	1.0136
4	.5624	.5487	.6935	.5944	.4268	1.3565	1.1584
5	.6249	.6097	.78	.743	.4572	1.5432	1.2971
6	.9374	.7316	.9503	.8688	.6097	2.0576	1.6411
7	.9374	.7926	.6097	.8398	.6401	2.1879	2.0576
8	.4687				.6401	1.6644	2.1072
9	.4999					1.7604	1.9479
10		1.0059	1.1888				.3437
11	1.829	1.0574	1.6507	1.0669			
12	1.829	1.5927	1.6289	1.3717	1.3169		
13	1.9509	1.6133	1.6507	1.829	1.6072	.2591	
14	1.9204	1.7535	1.6507	1.829	1.5716	.2622	
15	1.9204	1.7246	1.7086	1.829		.2622	
16	1.9204	1.8359	1.7764	1.829	1.813	.2622	
17	1.9509	1.7861	1.6217	1.829	1.7147	.2949	
18	.3048	.2675	.2743	.3353	.3353	.3437	
19	.4572	.5441	.4755	.5792	.6401	.5182	
20	.5792	.6944	.5792	.6401	.5548	.6539	
21	.6097	.6401	.5792		.5548	.5944	
22	.4877	.4961	.4458	.2134	.4572	.5117	
23	.3353	.4763	.3864	.1829	.381	.4268	
24	.4062	1.0574	.381	.3749	1.5931	1.6644	.724
Max	**1.9509**	**1.8359**	**1.7764**	**1.829**	**1.813**	**2.1879**	**2.1072**
Min	**.3048**	**.2675**	**.2743**	**.1829**	**.2134**	**.2591**	**.3437**
Avg	**.9525**	**.9336**	**.9605**	**.9151**	**.8023**	**.9489**	**1.273**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154104 / 33/11 KV NANAND
Feeder No / Name : 202 / 11 KV JEWRI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3749	.4268	.5853	.3125	.3353	.2957	.2622
2	.3749	.4572		.3963	.3963	.3544	.3277
3	.4374	.4572	.6468	.4572	.4572	.4287	.4001
4	.4687	.4877	.6859	.5053	.4572	.503	.4801
5	.4999	.6097	.7545	.5944	.7621	.7011	.6249
6	.8124	.823	.7773	.743	.884	.8383	.7407
7	.9998	.9145	1.0059	.8977	.9145	1.0277	.8619
8	.9061	1.0669	.9482	.9305	.9145	.8356	.724
9	.8749	1.0974	.8471	.945	.945	.7287	.5647
10	.3048		.1638		.3963	.5937	.5792
11	.2134		.1638	.0914	.2058	.6539	
12	.2134	.0743	.1372	.1524	.1448	.743	
13		.0714	.1448	.1524	.1143	.7145	
14	.1524	.1189	.2012	.1524	.1128	.695	
15	.1524	.1448	.1715	.1524	.1158	.6859	
16	.1524	.1158	.1715	.1829	.1204	.724	
17	.1524	.1429	.1715	.2134	.1355	.724	
18	.1829	.2258	.2439	.3658	.0781	.1966	
19	.3658	.5735	.6081	.6097	.5079	.4687	
20	.4572	.5624	.5792	.6401	.763	.4999	
21	.4268	.4096	.4755	.4572	.4733	.4062	
22	.2743	.3224	.3048	.2134	.4066	.3201	
23	.2286	.3048	.2134	.1829	.2858	.2294	
24	.3125	.3048	.4763	.2812	.3048	.2641	.1966
Max	**.9998**	**1.0974**	**1.0059**	**.945**	**.945**	**1.0277**	**.8619**
Min	**.1524**	**.0714**	**.1372**	**.0914**	**.0781**	**.1966**	**.1966**
Avg	**.4060**	**.4414**	**.4555**	**.4187**	**.4263**	**.5680**	**.5238**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154104 / 33/11 KV NANAND
Feeder No / Name : 203 / 11 KV MALEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5624	.5487	.7468	.4816	.4572	.3292	.2949
2	.6249	.6097		.5647	.6097	.3467	.3563
3	.6874	.6097	.7888	.6241	.6097	.5935	.4744
4	.7499	.7316	.8573	.743	.7621	.6783	.6081
5	.8124	.823	1.0277	.7716	.9145	.8478	.7407
6	1.1248	1.0669	1.1843	.9145	1.2193		
7	1.4998	1.3717	1.5051	1.1717	1.2498		
8	1.1873	1.2193		1.2407	1.3413		
9	1.0623	1.2803	1.1294	1.2193	1.3717		
10			.1943		.3353	.9259	.8573
11			.1943	.1829	.1669	.9431	
12	.1524	.1204	.1372	.1829	.1174	1.0433	
13	.1524	.1467	.1372	.1524		1.0997	
14	.1524	.1204	.1372	.2134		1.086	
15	.1829	.1486	.1372	.2134		1.0433	
16	.1829	.1448	.1372	.1524		1.1279	
17	.1829	.1738	.1715	.1829	.1783	1.2125	
18	.2743		.2134	.2743	.253	.2267	
19	.3658		.4755	.4572	.5087	.5624	
20	.5182	.6009	.5053	.4877	.6859	.6173	
21	.4572	.3978	.3567	.3658	.567	.4938	
22	.3353	.3982	.2812	.2439	.4481	.3521	
23	.2439	.381	.2134	.2134	.3429	.2622	
24	.4999	.4572	.6097	.3963	.3048	.2801	.2561
Max	**1.4998**	**1.3717**	**1.5051**	**1.2407**	**1.3717**	**1.2125**	**.8573**
Min	**.1524**	**.1204**	**.1372**	**.1524**	**.1174**	**.2267**	**.2561**
Avg	**.5460**	**.5675**	**.5064**	**.4978**	**.6222**	**.7036**	**.5125**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI
Feeder No / Name : 201 / 11 KV SARWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2096	.2667	.2286	.463	.5312
2	.2286	.2286	.1905	.3048	.2667	.5401	.6241
3	.2477		.1905	.3048	.2858	.6401	.7042
4	.3239	.2477	.2667	.3429	.381	.7373	.7773
5	.4001	.3239	.362	.4191	.5335	.8192	.9069
6	.743	.5335	.4954	.4954	.5716	.9221	1.094
7	.7621	.6478	.6668	.4954	.6478	1.0682	1.2071
8	.5716	.6097	.5716	.4954	.4572	.9389	1.2574
9	.381	.3429	.4572		.2286	.9945	
10	.2785	.3858	.4268	.7621	.2286	.2286	
11	.9014	.6249	.7209	.8124	.2743	.1905	
12	.9172	.7116	.9556	.8124	.3906	.1524	.1905
13		.8162	1.073	.8642	.4481	.1524	
14	.8539	.9122	1.0395	.8962	.5735	.1143	
15	.9069	1.004	1.0174	.9503	.8192	.1143	
16	.9393	1.0364	1.0682	.9556	.8718	.1143	
17	.9069	1.065	.9835	.9389	.8886	.1715	
18	.2096	.1905	.2286	.1715	.1524	.1905	
19	.362	.3048	.362	.2858	.1905	.3429	
20	.5906	.4572	.4191	.4763	.2858	.4954	
21	.4191	.4001	.3429		.3239	.381	
22	.3048	.3429	.3429	.1905	.3429	.3048	
23	.2286	.2667	.2667	.2286	.381	.2477	
24	.2667	.2286	.2096	.2667	.2096	.3506	.3125
Max	**.9393**	**1.065**	**1.073**	**.9556**	**.8886**	**1.0682**	**1.2574**
Min	**.2096**	**.1905**	**.1905**	**.1715**	**.1524**	**.1143**	**.1905**
Avg	**.5205**	**.5178**	**.5361**	**.5335**	**.4159**	**.4448**	**.7605**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI
Feeder No / Name : 202 / 11 KV MUDGAD EKOJI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4268	.4012
2						.4687	.463
3						.5535	.5312
4						.6081	.578
5						.6401	.6562
6						.6882	.7449
7						.7209	.8097
8						.7209	.9012
9						.7125	
10	.2401	.4572	.3048	.2743	.1829		
11	.6405	.5864	.6325	.2343			
12	.6706	.7099	.7712	.2812	.6249		
13	.6173	.7811	.8048	.3201	.6802		
14	.6718	.7186	.7865	.4001	.6299		
15	.7042	.679	.8097	.5601	.583		
16	.7202	.6944	.8383	.6554	.6874		
17	.7274	.7186	.8192	.7127	.6097		
18	.2858						
19	.4001						
20	.6478						
24						.2134	.2743
Max	**.7274**	**.7811**	**.8383**	**.7127**	**.6874**	**.7209**	**.9012**
Min	**.2401**	**.4572**	**.3048**	**.2343**	**.1829**	**.2134**	**.2743**
Avg	**.5751**	**.6682**	**.7209**	**.4298**	**.5711**	**.5753**	**.5955**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI
Feeder No / Name : 203 / 11 KV KOKALGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4641	.4531	.4843	.3963		.3429	.2667
2	.5401	.5281	.5937	.3963	.703	.381	.3429
3	.5864	.6081	.6722	.4428	.8192	.4763	.4191
4	.6325	.6722	.7449	.506	.9221	.5716	.4572
5	.7701	.9231	.8848	.6554	.9724	.6668	.5335
6	.9945	1.1431	1.1401	1.2071	1.0174	.7621	.6668
7	1.0774	1.1401	1.3056	1.2378	1.166	.8573	.7621
8	1.1568	1.1568	1.3565	1.2887	1.2689	.6287	.6478
9	1.065	.9831	1.2717	1.0059	1.2146	.4763	
10	.2858	.3429	.3239	.2858		.4268	
11	.1715	.2667	.2286	.2096		.703	
12	.1715	.2286	.1905	.2286	.2858	.9282	.9217
13	.1715	.2096	.1524	.1905	.2286	1.0402	
14	.1905	.1905	.1524	.1715		.9922	
15	.1905	.1905	.0953	.1715		.9602	
16	.1905	.1524	.1334	.1334	.1905	1.0202	
17	.1905	.1524	.2286	.1524		1.0688	
18	.2858	.1905	.3239	.1905	.2286	.1905	
19	.4001	.3429	.4572	.3429	.2667	.4382	
20	.6478	.5335	.4954	.6859	.381	.5906	
21	.4572	.5716	.362		.4382	.4191	
22	.3239	.4001	.362	.381	.381	.3429	
23	.2858	.3048	.3239	.3239	.3429	.2858	
24	.2949	.2968	.2858	.2824	.2286	.2858	.2286
Max	**1.1568**	**1.1568**	**1.3565**	**1.2887**	**1.2689**	**1.0688**	**.9217**
Min	**.1715**	**.1524**	**.0953**	**.1334**	**.1905**	**.1905**	**.2286**
Avg	**.4810**	**.4992**	**.5237**	**.4733**	**.6142**	**.6190**	**.5246**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA
Feeder No / Name : 201 / 11 KV HARIJAWALGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1088	.0503			.7621	.7621
2	.2477	.128	.0533			.7811	.8002
3	.2858	.1174	.0613			.9145	.8002
4	.3239	.1286	.08			1.0288	.8573
5	.362	.1406	.081			1.3717	1.1431
6	.381	.1829	.0857			1.6766	1.6194
7	.5335	.176	.1067			1.7147	
8	.381	.176	.1303		.1372	1.8861	
9	.2667	.16	.1067		.1143	1.6575	
10	.724	.4763			.1905	.0503	.0914
11	.723	1.3908	1.5242		1.105		.048
12	.9374	1.3717	1.6004	.8552	1.448		.0384
13	.9846	1.4289	1.5623		1.3717		
14	1.2003	1.5051	1.5623		1.2003		
15	1.3146	1.6766	1.5813		1.2955		
16	1.3717	1.7337	1.6575	.7936	1.6004		
17		1.7909	1.6766		1.829		
18	.1334	.0314	.1143			.1715	
19	.1372	.0421	.3429		.0356		
20	.1677	.0876	.381		.0789		
21	.1524	.0398	.3429		.0377		
22	.1524	.0356	.3048		.0305		
23		.04	.2667				
24	.1372	.0457		.1253	.108	.724	.724
Max	**1.3717**	**1.7909**	**1.6766**	**.8552**	**1.829**	**1.8861**	**1.6194**
Min	**.1334**	**.0314**	**.0503**	**.1253**	**.0305**	**.0503**	**.0384**
Avg	**.5075**	**.5423**	**.6215**	**.5914**	**.7055**	**1.0616**	**.6884**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA
Feeder No / Name : 202 / 11 KV BHOOTMUGLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2425	.2286	.2667		.2858	.381
2	.2286	.2401	.2667	.2667		.3429	.4191
3	.2858	.2987	.2667	.3048		.4755	.4191
4	.3048	.2743	.3048	.3429		.5944	.3772
5	.3429	.3086	.3048	.381		.7468	.6154
6	.4001	.3734	.3429	.4954		.7926	.884
7	.4763	.3429	.381			.8421	.7926
8	.3429		.362	.4572	.3395	1.0159	.6401
9	.2858	.0026	.362	.3239		.9175	.8322
10	.4287	.2972	.4058	.3772	.3429	.2858	.1494
11	.6516	.6097	.6401		.5792	.1905	.1132
12	.7716	.6173	.7011	.5144	.703	.1334	.1029
13	.8573	.6327	.6706		.703	.1143	
14	.8048	.68	.6802		.68	.0953	
15	.6927	.7432	.6097		.759	.1143	
16	.6859	.7907	.8002	.7122	.8097	.1143	
17		.8381	.7926		.8259	.1334	
18	.1524	.2667	.1334		.1334	.1715	
19	.2743	.3048	.3048		.3429		
20	.3395	.4001	.362		.4572		
21	.3772	.3429	.3048		.362		
22	.3086	.3048	.2667		.3239		
23	.2743	.2858	.2667		.2667		
24	.2743	.2667		.2667	.2401	.2503	.381
Max	**.8573**	**.8381**	**.8002**	**.7122**	**.8259**	**1.0159**	**.884**
Min	**.1524**	**.0026**	**.1334**	**.2667**	**.1334**	**.0953**	**.1029**
Avg	**.4256**	**.4115**	**.4243**	**.3924**	**.4918**	**.4009**	**.4698**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA
Feeder No / Name : 203 / 11 KV USTURI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
10		.4382	.9145
24	.6859	.5525	.2858
Max	.6859	.5525	.9145
Min	.6859	.4382	.2858
Avg	.6859	.4954	.6002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154108 / 33/11 KV AMBULAGA
Feeder No / Name : 201 / 11KV AMBULGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4586		1.8023	1.004	1.8442	1.7924
2		1.4586		1.7695	1.0082	1.8778	1.8244
3		1.4586		1.7604	1.0155	1.8778	1.8884
4		1.4586		2.0317		1.9113	
5		1.7177				1.9669	
9		2.0348		2.1216	2.079	2.079	
10				1.5249	2.0885		
11	1.4723			1.5249	1.576		1.9662
12	1.5384			1.6766	1.7101		
13	1.8138				2.0119	2.0454	
14	1.7814	2.146			1.8778	2.1795	
15	2.0972				1.8107	2.2801	
16					1.7436	2.2801	
17	2.3758				1.8778	2.4813	
18	2.1605	2.0972			1.9448	2.5484	
19	.4733	.3284			.2606	.2987	
20	.5005				.271	.3414	
21	.4923				.3536	.3982	
22	1.2146		1.643		1.2742		
23	1.2955				1.5424		
24	2.0729	1.4586	2.0119	1.9113	1.7436		1.8244
Max	**2.3758**	**2.146**	**2.0119**	**2.1216**	**2.0885**	**2.5484**	**1.9662**
Min	**.4733**	**.3284**	**1.643**	**1.5249**	**.2606**	**.2987**	**1.7924**
Avg	**1.4837**	**1.5617**	**1.8275**	**1.7915**	**1.4312**	**1.7607**	**1.8592**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA
Feeder No / Name : 201 / NEW BANK COLONY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			1.2803		1.1043		
8	1.1393	1.1043	1.1462	1.1218		1.0341	
16	1.1043		1.1218	1.1393	1.1043		
18	1.2795	1.166	1.2094		1.0517		
20			1.3321				
22	1.2795						
24		1.0692	1.1706	.929	.9114	1.1043	1.0692
Max	**1.2795**	**1.166**	**1.3321**	**1.1393**	**1.1043**	**1.1043**	**1.0692**
Min	**1.1043**	**1.0692**	**1.1218**	**.929**	**.9114**	**1.0341**	**1.0692**
Avg	**1.2007**	**1.1132**	**1.2101**	**1.0634**	**1.0429**	**1.0692**	**1.0692**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA
Feeder No / Name : 202 / ASHOK NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.7762		.6468		
8	.6535	.6838	.695	.5914		.7762	
16	.2033		.2033	.1663	.1848		
18	.2957	.3258	.2402		.3696		
20			.5914				
22	.4066						
24		.2218	.2587	.2772	.2587	.2772	.208
Max	**.6535**	**.6838**	**.7762**	**.5914**	**.6468**	**.7762**	**.208**
Min	**.2033**	**.2218**	**.2033**	**.1663**	**.1848**	**.2772**	**.208**
Avg	**.3898**	**.4105**	**.4608**	**.3450**	**.3650**	**.5267**	**.208**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
NILANGA (R) S/DN[417] BU 5177
Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA
Feeder No / Name : 203 / NEW COURT FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	31-MAR-17
HR	Load (MW)
24	1.065
Max	1.065
Min	1.065
Avg	1.065

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154014 / 33/11 KV UJED
Feeder No / Name : 201 / 11KV SYED ANKULGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.5335		.6706	.6706		.381
2	.6668	.5335		.7545			.381
3	.5868	.6097		.8383	.7545		.381
4	.8048	.6859		.8383			
5	.9221	.7621		1.0059	1.0395		
6	.9724	.7621		1.0059			
7	.9221	.8383		1.0059	1.0898		
8	.8718	.9724	1.1401	1.1736			
9	.8718		1.1401	1.1736	1.0395		
10						.9145	.4572
11						.7621	.503
12						.8383	.5868
13						.9145	
14						.9907	
15						.9907	
16	.1905	.1524	.0191	.1905	.1524	.9145	
17	.2858	.1524	.0191	.1905		1.0898	
18	.3429		.0191			.2858	
19	.381		.0286	.3429		.3429	
20	.381		.0286	.381	.2667	.3429	
21	.381		.0286			.381	
22	.381		.0286			.381	
23	.381		.0286			.381	
24	.3353	.4572	.7716	.503	.3018		.381
Max	**.9724**	**.9724**	**1.1401**	**1.1736**	**1.0898**	**1.0898**	**.5868**
Min	**.1905**	**.1524**	**.0191**	**.1905**	**.1524**	**.2858**	**.381**
Avg	**.5656**	**.5872**	**.2956**	**.7196**	**.6644**	**.6807**	**.4387**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154014 / 33/11 KV UJED
Feeder No / Name : 202 / 11 KV BIBRAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5927	1.5089		1.5089	.8383		.7621
2	1.6766	1.8442		1.6956			.6859
3	1.9281	2.1795		2.0119	.8718		.8573
4	2.1795	2.5149		2.0348			
5	2.3807	2.5149		2.2043			
6	2.431	2.6825		2.3739			
7	2.5095	2.6825		2.3739			
8	2.5149	2.5987	2.7161	2.5149			
9	2.431		2.7469	2.5434			
10						1.7528	1.448
11							1.6766
12						2.21	1.6956
13						2.5149	
14						2.1338	
15						2.431	
16	.381	.3048	.0381	.381		2.3472	
17	.4763	.381	.0381	.4191		2.7664	
18	.5716		.0476			.4763	
19	.6668		.0572	.6097		.5716	
20	.7621		.0057	.6097	1.4403	.6668	
21	.7621		.0572			.6668	
22	.7621		.0572			.6668	
23	.7621		.0572			.6668	
24	1.1431	1.1736	1.6289	1.5432	.7042		.7621
Max	**2.5149**	**2.6825**	**2.7469**	**2.5434**	**1.4403**	**2.7664**	**1.6956**
Min	**.381**	**.3048**	**.0057**	**.381**	**.7042**	**.4763**	**.6859**
Avg	**1.4406**	**1.8532**	**.6773**	**1.6303**	**.9637**	**1.5286**	**1.1268**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154014 / 33/11 KV UJED
Feeder No / Name : 203 / 11 KV Ujed SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381		.0343	.3429		.5335
2	.381	.381		.0381			.5335
3	.381	.381		.0381	.3429		.6097
4						.6173	.6859
5							.6859
6							.7545
7							.6097
8						.6371	.6097
9						.6371	.6097
10	.4191		.4191	.3353			
11			.4191	.3688			
12	.5335	.57	.503	.4191			
13	.6097		.5868	.3688			
14	.7545		.5868	.3353			
15	.6097		.5868	.3018			
16	.6097	.503	.6706	.3353	.5487	.2858	
17	.5335	.503	.6706	.4191		.3429	
18	.2858		.0381			.381	
19	.381		.0381	.381		.4763	
20	.4763		.0381	.4572	.3429	.4763	
21	.4763		.0381			.381	
22	.381		.0381			.381	
23	.381		.0343			.381	
24	.381	.381	.3429	.3429	.3429	.4801	.4572
Max	**.7545**	**.57**	**.6706**	**.4572**	**.5487**	**.6371**	**.7545**
Min	**.2858**	**.381**	**.0343**	**.0343**	**.3429**	**.2858**	**.4572**
Avg	**.4691**	**.4429**	**.3340**	**.2982**	**.3841**	**.4564**	**.6089**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154024 / 33/11 KV YEROL
Feeder No / Name : 201 / 11 KV DIGOL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4715	.462	.3429	.4527	1.0288	1.587
2	.4668	.5281	.462	.3772	.4527	1.2003	1.5775
3	.5601	.6036	.5544	.4525	.6036	1.286	1.6289
4	.5601	.6602	.5544	.6001	.679	1.3717	1.7147
5	.7468	.7131	.7392	.6443	.7131	1.4575	1.7814
6	.8402	.7882	.8316	.724	.8962	1.5432	1.8842
7						1.9757	2.3148
8						2.2291	2.1434
9						1.829	
10	1.3279		1.286	1.4632	1.2742		
11	1.4899	1.7004	1.6194	1.6766			
12	1.4632	1.7004	1.7004	1.6156			
13	1.4632	1.6194	1.587	1.5851			
14	.5487	1.6194	1.5242	1.4632			
15	.5487	1.4575	1.6518	1.4632	1.2193		
16	1.5242	1.6194	1.7004	1.6461	1.7071		.3086
17	1.829	1.9433	1.9719	1.1279	2.0233	.3239	.3696
18	.4527	.462	.3429	.2263	.3086	.3391	.462
19	.5281	.5175	.5182	.7545	.4287	.6173	.5544
20	.6763	.6468	.6516	.8257	.5144	.5487	.6468
21	.5658	.5544	.6859	.7506	.5487	.5487	.6468
22	.4904	.5544	.6516	.6413	.4801	.4534	.462
23	.4904	.462	.5144	.5658	.4287	.4287	.462
24	.4108	.4527	.462	.4287	.4527	.8573	.8573
Max	**1.829**	**1.9433**	**1.9719**	**1.6766**	**2.0233**	**2.2291**	**2.3148**
Min	**.4108**	**.4527**	**.3429**	**.2263**	**.3086**	**.3239**	**.3086**
Avg	**.8283**	**.9537**	**.9748**	**.9226**	**.7755**	**1.0611**	**1.1413**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154024 / 33/11 KV YEROL
Feeder No / Name : 202 / 11 KV YEROL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049	.4115	.3239	.4801	.362	.3429	.3429
2	.4049	.5487	.3239	.6001	.4344	.3429	.3429
3	.4858	.5487	.4858	.6516	.5068	.3772	.3772
4	.4858	.6173	.4858	.6001	.5068	.4287	.4049
5	.6478	.6173	.6478	.6859	.5249	.4801	.4801
6	.6478	.7716	.7287	.8573	.6859		.5144
7	.8907	.8573	.8907	.8573	.823		
8	.8097	.9602	.8907	.8573	.7888		
9	.8573	.7773	.8573		.7865		
10						.5487	
11						.5487	
12						.5792	
13						.5639	
14						.5639	
15						.503	.5792
16	.3018		.2058	.2641	.2058		.6249
17	.3018	.2957	.1943	.2641	.2572	.5144	.5668
18	.2641	.2957	.2401	.2452	.2058	.5792	.1848
19	.5093	.462	.4801		.3772	.5228	.462
20	.6413	.6401	.5144		.4287	.5487	.5544
21	.5658	.5544		.5281	.4801	.5601	.5175
22	.4338	.462	.4801	.4527	.4287	.4801	.462
23	.3772	.3696	.4287	.4527	.3772	.4287	.3696
24	.4049	.2987	.3239	1.3717	.2614	.3734	.3429
Max	**.8907**	**.9602**	**.8907**	**1.3717**	**.823**	**.5792**	**.6249**
Min	**.2641**	**.2957**	**.1943**	**.2452**	**.2058**	**.3429**	**.1848**
Avg	**.5242**	**.5581**	**.5001**	**.6112**	**.4690**	**.4888**	**.4454**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154024 / 33/11 KV YEROL
Feeder No / Name : 203 / 11 KV SAKOL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.5658	.543	.3772	.5658	1.8004	1.8004
2	.543	.6036	.543	.4287	.7131	1.8519	1.8519
3	.724	.679	.724	.6516	.7506	1.7147	2.2291
4	.724	.7882	.724	.7716	.7842		2.3663
5	.8145	.9195	.8145	.823	.8962	2.3148	2.4006
6	.905	1.0509	.905	.8573	.8775	1.7147	2.4863
7						2.4863	2.7435
8						2.5377	2.4863
9						2.3624	
10	1.6461	1.7004	1.8107	1.6766	1.5242		
11	2.1948	2.1052	2.1862	2.1186	1.829		
12		2.2672	2.3482	2.1338	2.0576		
13	2.1948	2.3482	2.3482	2.2253	2.1338		
14	2.1338	2.2672	2.2996	2.1338	2.1643		
15	2.2558	1.9433	2.4863	2.1033	2.0424		
16	2.2558	2.0243	2.6578	2.1948	2.1338		.2058
17	2.1491	2.2672	2.4863	2.0881	2.5377	.3086	.2172
18	.3018	.3077	.3086	.3018	.2401	.2572	.2172
19	.4904	.543	.6001	.7356	.4115	.4344	.543
20	.7882	.724	.6516	.7733	.4287	.5487	.6335
21	.679	.6335	.6859	.6979	.3772	.6001	.6335
22	.5847	.543	.6516	.6602	.4287	.5792	.543
23	.5658	.543	.6001	.6036	.4801	.5228	.543
24	.543	.5144	.543	1.2003	.5658	.8573	1.5384
Max	**2.2558**	**2.3482**	**2.6578**	**2.2253**	**2.5377**	**2.5377**	**2.7435**
Min	**.3018**	**.3077**	**.3086**	**.3018**	**.2401**	**.2572**	**.2058**
Avg	**1.1518**	**1.2066**	**1.2818**	**1.2170**	**1.1401**	**1.3057**	**1.3788**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154024 / 33/11 KV YEROL
Feeder No / Name : 204 / 11 KV DHAMANGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.989	2.0576	1.0288	2.2291	.2401	.1372
2	1.8861	2.13	2.0576	1.1145	2.332	.2058	.1372
3	2.4006	2.1862	2.4006	1.3375	2.3205	.1886	.1457
4	2.6578	2.2348	2.572	1.286	2.3537	.1715	.1296
5	2.7435		2.572	1.4575	2.4291	.2058	.1086
6			2.7435	1.5432	2.5911	.2374	.1372
7			2.915	1.8004	2.3929		
8	2.915	2.2611	2.9673	2.572	2.2862		
9	2.7435	2.4006	2.753		2.2862		
10		1.9719				1.5565	
11						2.21	
12						2.21	
13						2.21	
14						2.2253	
15						2.3472	2.1338
16	.0377	.0377	.0972	.0943	.0686		2.3624
17	.0377	.0566	.1296	.1132	.0857	2.5425	2.7978
18	.0566	.0943	.1543	.1509	.0857	.1677	.1509
19	.2263	.0943	.3086	.2641	.1372	.1886	.2075
20	.2075	.1886	.3429	.2641	.1715	.2172	.2641
21	.2075	.132	.3086		.2058	.1372	.2452
22	.2075	.132	.2743	.2263	.2058	.1448	.2452
23	.1886	.132		.2263	.181	.12	.1886
24	1.5432	1.086	1.7147	1.0288	1.4232	.1715	.1543
Max	**2.915**	**2.4006**	**2.9673**	**2.572**	**2.5911**	**2.5425**	**2.7978**
Min	**.0377**	**.0377**	**.0972**	**.0943**	**.0686**	**.12**	**.1086**
Avg	**1.2359**	**1.0704**	**1.5511**	**.9067**	**1.3214**	**.8849**	**.5966**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL
Feeder No / Name : 201 / 11KV SHIRUR ANANTPAL GAOTHAN FEEDER
GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4287			.5144			.5144
3		.6001			.6001		
4							.6001
5						.7716	
7		1.1145					
8	.8573		.9431	.9431	.8573		.9431
9	.6859	.7716				.8573	
10		.6859		.7716			.7716
11	.6859				.6859		
12		.5144					
13						.5144	
14	.6001						.5144
16	.5144	.5144			.5144	.6001	
17		.6001	.6001	.5144		.5144	.6001
18		.6859					
19							.6859
20	.8573		.7716			.6859	
21				.8573			
22	.6859					.6001	.6859
23					.6859		
24	.4287	.5144	.5144	.5144	.5144	.5144	.5144
Max	**.8573**	**1.1145**	**.9431**	**.9431**	**.8573**	**.8573**	**.9431**
Min	**.4287**	**.5144**	**.5144**	**.5144**	**.5144**	**.5144**	**.5144**
Avg	**.6382**	**.6668**	**.7073**	**.6859**	**.643**	**.6323**	**.6478**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL
Feeder No / Name : 202 / 11KV BHINGOLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1715			.2572			.6001
3		.3429			.3429		
4							.6859
5						.8573	
8							1.0288
9						.8573	
10		.8573		.9431			
11	.9431				.8573		
12		1.286					
14	.9431						
16	1.1145	1.286			1.0288	.1715	
17		1.3717	1.286	1.0288		.1715	.1715
18		.1715					
19							.3429
20	.4287		.3429			.4287	
21				.3429			
22	.3429					.3429	.3429
23					.2572		
24	.1715	.2572	.2572	.2572	.2572	.5144	.6001
Max	**1.1145**	**1.3717**	**1.286**	**1.0288**	**1.0288**	**.8573**	**1.0288**
Min	**.1715**	**.1715**	**.2572**	**.2572**	**.2572**	**.1715**	**.1715**
Avg	**.5879**	**.7961**	**.6287**	**.5658**	**.5487**	**.4777**	**.5389**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL
Feeder No / Name : 203 / 11KV ARI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.0288			.9431			.6001
3		1.286			1.286		
7		2.1434					
8	2.2291		2.3148	2.3148	2.1434		
9	2.3148	2.1434					
10							1.7147
13						2.0576	
14							2.0576
16	.2572	.4287			.3429	2.0576	
17		.5144	.4287	.5144		2.1434	1.8861
18		.6001					
19							.5161
20	.7716		.8573			.8573	
21				.7716			
22	.6001					.7716	.9431
23					.5144		
24	1.0288	1.1145	1.2003	1.1145	1.1145	.4287	.6859
Max	**2.3148**	**2.1434**	**2.3148**	**2.3148**	**2.1434**	**2.1434**	**2.0576**
Min	**.2572**	**.4287**	**.4287**	**.5144**	**.3429**	**.4287**	**.5161**
Avg	**1.1758**	**1.1758**	**1.2003**	**1.1317**	**1.0802**	**1.3860**	**1.2005**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL
Feeder No / Name : 204 / 11KV WATER WORKS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0343			.0343
3			.0343		
4					.0343
5				.0343	
8		.0343	.0343		.0343
9				.0343	
10		.2572			.0343
11			.0857		
13				.2572	
14					.0343
16			.1715		
17	.2572	.0857			.0343
19					.0343
20	.1715			.0343	
21		.0857			
22				.0343	.0857
23			.0343		
24		.0343	.0343	.0343	.0343
Max	**.2572**	**.2572**	**.1715**	**.2572**	**.0857**
Min	**.1715**	**.0343**	**.0343**	**.0343**	**.0343**
Avg	**.2144**	**.0886**	**.0657**	**.0715**	**.0400**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL
Feeder No / Name : 205 / 11KV SHIRUR ANANTPAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6859			1.0288			.3429
3		.8573			1.286		
7		1.2003					
8				1.9719	2.1434		
9	1.5432	1.3717					
10							1.0288
13						2.572	
14							1.5432
16	.0343	.0343			.1715	2.3148	
17		.0343	.0343	.2572			1.5432
18		.0343					
19							.0857
20	.0343		.2572			.4287	
21				.3429			
22	.0343					.3429	.0343
23					.3429		
24	.6859	.7716		1.2003	1.1145	.3429	.3429
Max	**1.5432**	**1.3717**	**.2572**	**1.9719**	**2.1434**	**2.572**	**1.5432**
Min	**.0343**	**.0343**	**.0343**	**.2572**	**.1715**	**.3429**	**.0343**
Avg	**.5030**	**.6148**	**.1458**	**.9602**	**1.0117**	**1.2003**	**.703**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL
Feeder No / Name : 206 / 11 KV LAKKAD JAWALGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2572			.2572			1.1145
3		.4287			.4287		
4							1.286
5						1.5432	
8							2.0576
9						1.8861	
10		1.4575		1.3717			
11	1.7147				1.3717		
12		1.8861					
14	1.9719						
16	2.0576	2.0576			1.7147	.1715	
17		2.1434	1.9719	2.0576		.2572	.2572
18		.1715					
19							.3429
20	.5144		.6001			.5144	
21				.4287			
22	.4287					.4287	.3429
23					.2572		
24	.2572	.3429	.3429	.3429	.3429	1.0288	1.1145
Max	**2.0576**	**2.1434**	**1.9719**	**2.0576**	**1.7147**	**1.8861**	**2.0576**
Min	**.2572**	**.1715**	**.3429**	**.2572**	**.2572**	**.1715**	**.2572**
Avg	**1.0288**	**1.2125**	**.9716**	**.8916**	**.8230**	**.8328**	**.9308**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154066 / 33/11 KV SAKOL
Feeder No / Name : 201 / 11 KV TALEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3658	.4024			.6706	
2	.4973	.5121	.439			.7186	
3	.5487		.4706			.7042	
4		.5853				.7682	
5						.8745	
6						1.1797	
7						1.2452	
8						1.2803	
9						1.3032	1.1888
10	1.4998	1.893	1.1728				
11	1.7185	2.1262	2.1125		1.1096		
12	2.3205	2.2436	2.0241	.7468	1.2483		
13	2.1605	2.3137	2.1765	1.1584	1.387		
14	2.3967	2.2786	2.2996	1.2498	1.387		
15	2.4577	2.3137		1.3717	1.387		
16	2.4905	2.4272	2.4249	1.4937	1.4403		
17	2.5232	2.5941		1.3413	1.4403		
18	.2561	.1753					
19	.3734	.3982					
20	.5175	.5853					
21	.4854	.5175					
22	.5228	.4805					
23	.4805	.4435					
24	.4287	.439	.3982	2.2291		.6401	
Max	**2.5232**	**2.5941**	**2.4249**	**2.2291**	**1.4403**	**1.3032**	**1.1888**
Min	**.2561**	**.1753**	**.3982**	**.7468**	**1.1096**	**.6401**	**1.1888**
Avg	**1.2291**	**1.2607**	**1.3921**	**1.3701**	**1.3428**	**.9385**	**1.1888**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154066 / 33/11 KV SAKOL
Feeder No / Name : 202 / 11 KV SAKOL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.5487	
2						.5144	
3						.6173	
4						.6935	
5						.8322	
6						.8916	
7						.9602	
8						.9503	
9						.823	.8535
10	.7712	.815	.759	.7316	.6661		
11	.8413	.8063		.7621	.7362		
12	.9568	.8063	.8436	.7316	.7011		
13	.9214	.8413	.7811	.7011	.6661		
14	.8413	.7712	.759	.6706	.6523		
15	.8063	.7712		.6706	.6859		
16	.7712	.7975		.6706	.6859		
17	.7888	.8322	.6401	.5792	.6516		
24				2.0576		.583	
Max	**.9568**	**.8413**	**.8436**	**2.0576**	**.7362**	**.9602**	**.8535**
Min	**.7712**	**.7712**	**.6401**	**.5792**	**.6516**	**.5144**	**.8535**
Avg	**.8373**	**.8051**	**.7566**	**.8417**	**.6807**	**.7414**	**.8535**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154066 / 33/11 KV SAKOL
Feeder No / Name : 203 / 11 KV GHUGI SANGVI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.7087	.7796	.7186	.3048	.1372	
2	.7926	.8413	.8063	.7499	.3353	.1372	
3	.8078	.9114	.9114	.0829	.3353		
4	.8383	.9465	.9816	.7682	.3506		
5	.9145	1.0517	1.0517	.9282	.381		
6	.9907	1.1218	1.1218	.9614	.4268		
7	1.0364	1.1789	1.1789	1.073	.5944		
8	.5487	.6935	1.0974	1.073	.6554		
9	.9602	.9709	1.1096	1.1401	.381		
10						.7293	.5487
11						.7865	.945
12						.8097	1.0669
13						.9175	
14						1.0159	
16		.0701			.0709	1.0486	
17		.0709			.0716	1.1271	
18					.0716		
19	.1086	.1417			.1448		
20	.1086	.1791			.2012		
21	.1463	.1991					
22		.1848					
23	.1829	.1478			.1372		
24	.3353	.3982	.7087	1.2003	.2591		
Max	**1.0364**	**1.1789**	**1.1789**	**1.2003**	**.6554**	**1.1271**	**1.0669**
Min	**.1086**	**.0701**	**.7087**	**.0829**	**.0709**	**.1372**	**.5487**
Avg	**.6008**	**.5774**	**.9747**	**.8696**	**.2951**	**.7454**	**.8535**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154066 / 33/11 KV SAKOL
Feeder No / Name : 204 / 11 KV NEW TALEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON
Feeder No / Name : 201 / 11 KV SHIVPUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8413	1.3717			
2				1.4403			.2195
3			1.0288	1.5432			.2195
4			1.166	1.5432			
5			1.3032	1.7147			
6			1.3717	1.7147			
7			1.5432	2.0119			
8			1.5432				
9			1.6118				
10							.6859
11							.8402
12							.8573
13							.9259
14							1.0288
15							1.4403
16		.2572	.3475				1.5432
17		.3658	.3475			1.5242	1.7558
18		.3658	.4024			.2572	.3658
19		.3658	.4024			.2743	.3658
20		.4024	.439			.2195	.4024
21		.4024	.439			.2561	.439
22		.4024	.439			.2561	.439
23		.439	.4024			.2926	.439
24	.7716	.9145	.7468	1.2003	.7716	.2572	.2561
Max	**.7716**	**.9145**	**1.6118**	**2.0119**	**.7716**	**1.5242**	**1.7558**
Min	**.7716**	**.2572**	**.3475**	**1.2003**	**.7716**	**.2195**	**.2195**
Avg	**.7716**	**.4350**	**.8456**	**1.5675**	**.7716**	**.4172**	**.7190**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON
Feeder No / Name : 202 / 11 KV HIPPALGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2195	.3292			
2				.3292			.5853
3			.2195	.3395			.9145
4							1.0974
5							1.2346
6							1.3717
7							1.4403
8							1.5432
9							1.5432
10			.5487				
11		.6142	.6401				
12		.6859	.439				
13		.6859	.439				
14		.6859					
15		.5144					
16		.5144					.2195
17		.2926					.2195
18		.2926	.3292			.3429	.2195
19		.2926	.3658			.3292	.2561
20		.3292	.3658			.3292	.2926
21		.3361	.3658			.3658	.2926
22		.3658	.439			.3658	.2743
23		.3658	.4024			.3658	.2926
24	.3429	.3429	.2561	1.0288	.2572	.6001	.3658
Max	**.3429**	**.6859**	**.6401**	**1.0288**	**.2572**	**.6001**	**1.5432**
Min	**.3429**	**.2926**	**.2195**	**.3292**	**.2572**	**.3292**	**.2195**
Avg	**.3429**	**.4513**	**.3869**	**.5067**	**.2572**	**.3855**	**.7155**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
NILANGA DIVSION[517]
SHIRUR ANANTPAL S/DN[823] BU 4823
Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON
Feeder No / Name : 203 / 11 KV GANESHWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0914	.1097			
2				.1029			.2743
3			.0914	.1097			.2743
4							.2572
5							.3258
6							.3429
7							.3429
8							.4024
9							.3772
10			.2195				
11		.3429	.2195				
12		.3429	.1829				
13		.3429	.1829				
14		.3429	.2195				
15		.3429	.3475				
16		.3429	.3475				.0914
17		.0943	.3475				.0914
18		.0914	.1463			.0857	.1097
19		.0914	.1646			.1097	.1097
20		.1097	.1646			.1097	.1097
21		.112	.1646			.1097	.1097
22		.1097	.1646			.1097	.1097
23		.1097	.1646			.1097	.1097
24	.0857	.0857	.1097	.6859	.0857	.1715	.2743
Max	**.0857**	**.3429**	**.3475**	**.6859**	**.0857**	**.1715**	**.4024**
Min	**.0857**	**.0857**	**.0914**	**.1029**	**.0857**	**.0857**	**.0914**
Avg	**.0857**	**.2044**	**.1958**	**.2521**	**.0857**	**.1151**	**.2184**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR
Feeder No / Name : 202 / 11 KV Nandura AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.3739		2.2405		
2			2.5434		2.6139		
3			2.5434		2.8006		
4			2.713		2.8006		
5			2.713		2.9874		
6			2.8178		3.1741		
7			2.9835		3.3608		
8	3.0807		2.8178	3.0864	3.3608		
9	3.0807				3.3608		
16						2.9874	3.6408
17						2.6139	
18						2.6139	
19						2.6139	
24	1.8671	1.8671	2.2405	1.4937	1.4937		
Max	**3.0807**	**1.8671**	**2.9835**	**3.0864**	**3.3608**	**2.9874**	**3.6408**
Min	**1.8671**	**1.8671**	**2.2405**	**1.4937**	**1.4937**	**2.6139**	**3.6408**
Avg	**2.6762**	**1.8671**	**2.6385**	**2.2901**	**2.8193**	**2.7073**	**3.6408**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR
Feeder No / Name : 203 / 11 KV THODAGA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1696		.1867		.7468
2			.1696		.1867		.9335
3			.1696		.1867		.9335
4			.1696		.1867		1.1203
5			.1829		.1867		1.1203
6			.1658		.1867		1.1203
7			.1658		.1867		1.1203
8	.1867	.1867	.1696	.1715	.1867	.9335	1.1203
9	.1867		.1867		.1867		
10	.7468		.5601		.5601		
11	.7468		1.1203		1.1203		
12	1.1203		1.1203				
13			1.1203				
14	1.1203		1.1203				
15	1.1203		1.1203				
16	1.1203		1.307	.9945	1.1203	.1867	.1867
17		1.0174	1.307	.1638		.1867	
18		.1658	.1867			.1867	
19		.1658	.1867	.2801		.1867	
20		.2543	.1867	.2801		.1715	
21		.2515	.1867	.1867		.1867	
22		.2801	.1867	.1867		.1867	
23		.1696	.1867	.1867		.1867	
24	.1867	.1886	.1696	.1867	.1867	.3734	.7468
Max	**1.1203**	**1.0174**	**1.307**	**.9945**	**1.1203**	**.9335**	**1.1203**
Min	**.1867**	**.1658**	**.1658**	**.1638**	**.1867**	**.1715**	**.1867**
Avg	**.7261**	**.2978**	**.4839**	**.2930**	**.3591**	**.2785**	**.9149**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] **BU 5151**
Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR
Feeder No / Name : 204 / 11 KV NANDURA GFSS **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2801		.1867		.1867
2			.2543		.1867		.1867
3			.2801		.1867		.1867
4			.2801		.1867		.1867
5			.3772		.2801		.2801
6			.4239		.3734		.4668
7			.4668		.5601		.4668
8	.4668		.3391	.4287	.3734	.5228	.3734
9	.3734		.3734		.2801		
10	.2801		.2801		.2801		
11	.2801		.1867		.1867		
12	.1867		.1867				
13	.1867		.1867				
14	.1867		.1867				
15			.1867				
16			.1867		.1867	.1867	.1867
17		.1658	.1867	.1696		.1867	
18		.1696	.1867	.2486		.1867	
19		.3391	.1867	.3734		.2801	
20		.5228	.1867	.4668		.3734	
21		.4668	.1867	.3734		.3734	
22		.3734	.1867	.2801		.3361	
23		.2801	.1867			.2801	
24	.1867	.1867	.2543	.1867	.1867	.1867	.1867
Max	**.4668**	**.5228**	**.4668**	**.4668**	**.5601**	**.5228**	**.4668**
Min	**.1867**	**.1658**	**.1867**	**.1696**	**.1867**	**.1867**	**.1867**
Avg	**.2684**	**.3130**	**.2515**	**.3159**	**.2657**	**.2913**	**.2707**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] **BU 5151**
Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR
Feeder No / Name : 205 / 11 kv Kalegaon **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2543		.3734		.9335
2					.3734		1.1203
3			.2543		.3734		1.1203
4			.1696		.3734		1.307
5			.4144		.3734		1.4937
6			.4973		.4668		1.4937
7			.4973		.5601		1.4937
8	.4668		.4144	.4287	.4668	1.4937	1.4937
9	.4668		.3734		.3734		
10	.7468		.7468		.7468		
11	.9335		1.4937		1.307		
12	1.4937		1.4937				
13			1.4937				
14			1.307				
15	1.4937		1.307				
16	1.4937		1.307	.1638	1.307	.3734	.3734
17		1.326	1.307	.2458		.3734	
18		.2486	.3734			.3734	
19		.5935	.3734	.4668		.3734	
20		.6535	.3734	.5601		.4668	
21		.5601	.3734			.4668	
22		.5228	.3734			.3734	
23		.3734	.3734			.3734	
24	.3734	.3734	.3734	.3734	.3734	.3734	.7468
Max	**1.4937**	**1.326**	**1.4937**	**.5601**	**1.307**	**1.4937**	**1.4937**
Min	**.3734**	**.2486**	**.1696**	**.1638**	**.3734**	**.3734**	**.3734**
Avg	**.9336**	**.5814**	**.6932**	**.3731**	**.5745**	**.5041**	**1.1576**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154018 / 33/11 KV KINGAON
Feeder No / Name : 201 / 11 KV KINGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9097		.7642	.6361		.7964	
2	1.0917		.7285	.5453		.8326	.9097
3	1.1888	.7316	.7634	.6907		.9877	.7278
4	1.0974		.8188	.727			
5	1.2736		1.1827	1.0917	.9633		
6	1.3646		1.3966	1.2736	1.2723		
7	1.2736		1.4177	1.366	1.454		
8	1.4556			1.4571	1.6176		
9			1.4192	1.454			
10						.9097	
11							1.454
14						1.0917	
15						1.0007	
16			.7278	.5453		.8188	
17			.7278	.5816		.9116	
18		1.2723	.6368	.6361		.6375	
19		1.3632	.7278	1.1087			1.0905
20		1.454		1.3995			1.4177
21		1.3995	.8196	.8543			1.2723
22		.727	.9107	.7088			1.1996
23		.6914	.7285	.618		.8188	1.0178
24	.7316	.9997	1.5449	.6361	1.423		1.1996
Max	**1.4556**	**1.454**	**1.5449**	**1.4571**	**1.6176**	**1.0917**	**1.454**
Min	**.7316**	**.6914**	**.6368**	**.5453**	**.9633**	**.6375**	**.7278**
Avg	**1.1541**	**1.0798**	**.9572**	**.9072**	**1.3460**	**.8806**	**1.1432**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] **BU 5151**
Substation No/ Name :- 154018 / 33/11 KV KINGAON
Feeder No / Name : 203 / 11 KV KOPARA **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9307	.8359		2.7149	2.3777
2			.8925	.835		2.9264	2.7435
3		1.0136	1.1145	.9288		3.0178	3.1093
4							3.658
5							3.8689
6							4.0573
7							4.1495
8							4.1495
9							3.4118
10			1.4632	2.7864			
11			2.8349				
12			3.1093				
13			3.0178	3.7151			
14		3.3471	2.9447	3.7151			
15		3.626	3.0727	3.5258			
16			3.1872	3.4365		.5487	
17			3.1255	2.4148		.6375	
18		.5573	.5521	.6124		.4572	
19		1.0217		.8179			.7802
20		.9835	.7346	.9278			.8359
21		.9288	.8273	.8953			.5015
22		.8359	.9193	.927			.4458
23		.7802	.9193	.9111		.823	.3901
24	.8048	3.719	.8376	.7438	.9593	3.786	1.6461
Max	**.8048**	**3.719**	**3.1872**	**3.7151**	**.9593**	**3.786**	**4.1495**
Min	**.8048**	**.5573**	**.5521**	**.6124**	**.9593**	**.4572**	**.3901**
Avg	**.8048**	**1.6813**	**1.7931**	**1.7518**	**.9593**	**1.8639**	**2.4083**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154018 / 33/11 KV KINGAON
Feeder No / Name : 204 / 11 KV KINGAON EXPRESS FEEDER Feeder KV- 11 / OUTGOING NON SHEDDABLE WATER SUPPLY AND UTILITY

DATE	29-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)
1		.7278
24	.0183	
Max	.0183	.7278
Min	.0183	.7278
Avg	.0183	.7278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154043 / 33/11 KV UJANA
Feeder No / Name : 201 / 11 KV UJANA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5432				.8238
2		1.8861				.8596
3		2.0233				.8596
4		2.1948				
5		2.3148				
6		2.3663				
7		2.4006				
8	2.1807	2.4006	2.6063			
9	2.268	2.4691	2.4691	2.4006		
10						1.2308
13					2.4006	
14					2.5377	
15					2.3148	
16	.5144		.6516	.2743	2.1262	
17	.5144		.6859		1.9204	
18	.5144		.823		1.8099	
19	.823		.9602			
20	.9259		1.0288			
21	.8916		1.0974			
22	.7888		1.0974			
23	1.2346	.7522	.9259			
24		1.406	1.3535		.8596	.7602
Max	**2.268**	**2.4691**	**2.6063**	**2.4006**	**2.5377**	**1.2308**
Min	**.5144**	**.7522**	**.6516**	**.2743**	**.8596**	**.7602**
Avg	**1.0656**	**1.9779**	**1.2454**	**1.3375**	**1.9956**	**.9068**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154043 / 33/11 KV UJANA
Feeder No / Name : 202 / 11 KV SANGHAVI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4006				.7164
2		2.5377				.6447
3		.2709				.5731
4		2.8121				
5		3.0521				
6		3.2407				
7		3.4294				
8	3.2895		3.3634			
9	3.4004		3.4004	3.0178		
10					2.5377	1.7013
11					3.2236	
12					3.4979	
13					3.6145	
14					3.4294	
15					3.4979	
16				.3429	3.4979	
17	.5144				3.4294	
18	.5144				.724	
19	.823					
20	.9259					
21	.8916					
22	.8573					
23	.7888	.8596				
24		2.0233	1.9959		.8596	.7522
Max	**3.4004**	**3.4294**	**3.4004**	**3.0178**	**3.6145**	**1.7013**
Min	**.5144**	**.2709**	**1.9959**	**.3429**	**.724**	**.5731**
Avg	**1.3339**	**2.2918**	**2.9199**	**1.6804**	**2.8312**	**.8775**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] **BU 5151**
Substation No/ Name :- 154043 / 33/11 KV UJANA
Feeder No / Name : 203 / 11 KV GANGA HIPPARGA **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.5364
2		.3086				1.7558
3		.3429				1.922
4						2.0119
5						2.1948
6						2.4394
7						2.5873
8					2.5972	2.6337
9					2.6242	2.6612
10	1.6651			1.5592		
11	1.97			1.7147		
12	2.1491			2.0576		
13	2.0576			2.2977		
14	2.0576			2.4691		
15	2.0576			2.7511		
16	2.0576			2.8235	.1372	
17	1.8861				.2195	
18	.2572				.2987	
19	.2743					
20	.3086					
21	.3086					
22	.3429					
23	.3429	.2835				
24		.2572	.2835		1.1706	1.3394
Max	**2.1491**	**.3429**	**.2835**	**2.8235**	**2.6242**	**2.6612**
Min	**.2572**	**.2572**	**.2835**	**1.5592**	**.1372**	**1.3394**
Avg	**1.2668**	**.2981**	**.2835**	**2.2390**	**1.1746**	**2.1082**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154043 / 33/11 KV UJANA
Feeder No / Name : 204 / 11 KV UJANA EXPRESS FEEDER NON SHEDDABLE WATER SUPPLY AND UTILITY
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867				.1433
2		.1867				.1433
3		.181				.1433
4		.181				.1612
5		.1829				.1612
6		.1848				.1612
7		.1791				.1629
8	.1791	.181	.1772		.1791	.1595
9	.0171		.197	.12	.181	.1612
10	.0171		.1886	.128	.1595	.1791
11	.0179			.12	.1543	
12	.1791			.12	.1578	
13	.1715			.12	.1629	
14	.1715			.124	.1595	
15	.1715			.124	.1372	
16	.1715			.128	.1372	
17	.1715				.1478	
18	.1715				.0895	
19	.1715					
20	.1886					
21	.1886					
22	.1886					
23	.1886	.1772				
24		.1867	.1791		.1772	.1448
Max	**.1886**	**.1867**	**.197**	**.128**	**.181**	**.1791**
Min	**.0171**	**.1772**	**.1772**	**.12**	**.0895**	**.1433**
Avg	**.1478**	**.1827**	**.1855**	**.123**	**.1536**	**.1565**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154043 / 33/11 KV UJANA
Feeder No / Name : 205 / 11KV BALGHAT KARKHANA FEEDER Feeder KV- 11 / OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343				.0347
2		.0343				.0343
3		.0343				.0343
4		.0343				.0347
5		.0343				.0347
6		.0343				.0347
7		.0514				.0343
8	.0526	.0514	.0347		.0526	.0347
9	.0351	.0514	.0347	.0343		.0351
10	.0347	.0362	.0343	.0354	.0343	.0351
11	.0358		.0343	.0362	.0343	
12	.0358		.0343	.0362		
13	.0366		.0343	.0354	.0343	
14	.0343			.0354	.0354	
15	.0343			.0343	.0362	
16	.0343			.0343	.0343	
17	.0343				.0354	
18	.0343				.0343	
19	.0343					
20	.0343					
21	.0343					
22	.0343					
23	.0343	.0343				
24		.0343	.0347		.0347	.0347
Max	**.0526**	**.0514**	**.0347**	**.0362**	**.0526**	**.0351**
Min	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**
Avg	**.0359**	**.0387**	**.0345**	**.0352**	**.0366**	**.0347**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] **BU 5151**
Substation No/ Name :- 154081 / 33/11 KV ANDHORI
Feeder No / Name : 201 / 11 KV DHALEGAON **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2291	2.1434	2.3148	.7888	2.4006	1.9719
2	2.2786	2.2291	2.2291	2.3148	.7888	2.4863	
3	2.9797	2.4006	2.3148	2.4006	.8764	2.572	
4	2.4539	2.6578	2.572	2.4863	.964	2.7435	
5	2.6292	2.8292	2.6578	2.8292	.964	2.915	
6	2.7435	3.0864	2.7435	3.1722		3.0007	
7	3.0007	3.1722	2.7435	3.0007			
8	2.7435	2.7435	2.7435	2.6578		2.7435	
10					1.8004		
11					2.0576		
12					1.7147		
13					1.8004		
14					1.7147		
15		.8573	.6859	1.1393	1.7147	.7716	
16	1.2003	1.1393	.6859	1.4022	1.7147	.7716	
17	1.1145	1.2003	.7716	1.3717	.6001		
18	.9431	1.3717	.9431	1.5432		1.0288	1.5432
19	1.0288	1.4575	1.1145	1.5432	1.3717	1.2003	
20	1.0288	1.2003	1.1145	1.5432	1.5432	1.286	
21	1.0288	1.2003	1.1145	1.5432	1.3717	1.3717	
22	1.0288	1.2003	1.2003	.8573	1.3717	1.4575	
23	1.4575	1.4575	1.286	.8573	1.5432	1.286	
24	1.4899	1.3717	1.5432	1.3717	.8764	1.7147	1.2003
Max	**3.0007**	**3.1722**	**2.7435**	**3.1722**	**2.0576**	**3.0007**	**1.9719**
Min	**.9431**	**.8573**	**.6859**	**.8573**	**.6001**	**.7716**	**1.2003**
Avg	**1.8219**	**1.8780**	**1.7004**	**1.9083**	**1.3462**	**1.8594**	**1.5718**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154081 / 33/11 KV ANDHORI
Feeder No / Name : 202 / 11 KV ANDHORI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.6859	.6859	.6859	.7011	.8573	.6001
2	.7011	.7716	.7716	.7716	.8413	.8573	.6001
3	.8764	.8573	.7716	.8573	.7888	.9431	.6001
4						1.0288	.6859
5						1.2003	.7716
6						1.3717	.8573
7							.9431
8							.9431
9	1.9719	1.8861		2.0576		.9431	.8573
10	1.8004	1.7147		1.8861	1.2269	.6859	.6859
11	1.8004	1.5432	1.6651	1.9281	1.0288		
12	1.6289	1.5432	1.4575	1.8404	.8573		
13	1.6289	1.4899	1.4575	1.7528	.6859		
14	1.5432	1.4899	1.4575	1.5432			
15	1.5432	1.4022	1.4575	1.5775	1.2003		
16	1.4575	1.4022	1.3717		1.286		
17							1.8861
18	1.1145	1.0288	.9431	.6859	.9431		1.8004
19	1.2003	1.1145	1.286	1.2003	.9431		1.7147
20	1.1145	1.1145	1.2003		.9431	1.8004	1.6289
21	1.0288	1.0288	1.0288		.9431	1.7147	1.5432
22	.9431	.9431	.8573		.9431		
23	.7716	.8573	.7716	.7716	.8573	1.4575	1.3717
24	.7011	.7716	.6859	.7716	.7011	.6859	1.3717
Max	**1.9719**	**1.8861**	**1.6651**	**2.0576**	**1.286**	**1.8004**	**1.8861**
Min	**.7011**	**.6859**	**.6859**	**.6859**	**.6859**	**.6859**	**.6001**
Avg	**1.2515**	**1.2025**	**1.1168**	**1.3093**	**.9306**	**1.1288**	**1.1095**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154081 / 33/11 KV ANDHORI
Feeder No / Name : 203 / 11 KV KENDREWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5144	.5144	.5144	.5258	.5144	.6001
2	.5258	.5144	.5144	.5144	.5258		.6001
3	.5258	.6001	.6001	.5144	.6135		.6001
4	.5258	.6859	.6001	.5144	.7011		
5		.7716	.6859	.6859	.7888		
6	.7716	.8573	.6859	.8573	.8764		
7	.8573	.8573	.7716	.8573	.964		
8	.6859	.8573		.8573	.8764		
9	.6859	.6859		.6859	.7011		1.3717
10	.6859	.5144		.5144	.6001	1.5432	1.3717
12						1.6289	
13						1.5432	
14						1.5432	
17	1.9719	2.0576	1.8861	1.8861	1.8861		
18	1.9719	2.0576	1.8004	1.9719	1.8004	.6001	.6859
19	1.6289	2.0576	1.8861	2.0576	1.8861	.6859	.7716
20	1.6289	1.8861	1.7147	.1886	1.7147		.8573
21	1.5432	1.6289	1.6289		1.7147	.7716	.7716
22	1.5432	1.5432	1.6289		1.5432	.6859	
23	1.4575	.8573	1.5432	1.6651	1.5432	.6001	.6001
24	1.4022	1.4575	1.4575	1.5432	1.5775	1.4575	.6001
Max	**1.9719**	**2.0576**	**1.8861**	**2.0576**	**1.8861**	**1.6289**	**1.3717**
Min	**.5258**	**.5144**	**.5144**	**.1886**	**.5258**	**.5144**	**.6001**
Avg	**1.1140**	**1.1336**	**1.1945**	**.9893**	**1.1577**	**1.0522**	**.8028**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON
Feeder No / Name : 201 / 11 KV ROKADA SAWARGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2572	.2572	.2572	.5144	.5144
2	.3086	.2572	.2572	.2572	.2572	.5144	.6859
3	.3086	.3429	.2572	.2572	.2572	.6859	.7716
4						.7716	.9431
5						.9431	1.1145
6						1.2003	1.2003
7						1.3717	1.286
8						1.4575	1.286
9						1.3717	1.286
10	1.5432	1.6289	1.5432	1.7147	1.5432		
11	2.0576	2.0576	1.9719	1.7147	2.0576		
12	2.2291	.2058	1.9719	1.7147	2.0576		
13	2.0576	2.0576	1.749	2.0576	2.0576		
14	1.9719	2.0576	1.8861	2.1434	2.0576		
15	2.0576	2.0576	1.8861	1.9719	2.0576		
16	2.0576	2.0576	2.0576	1.9719	2.0576	.1372	
17	2.0576	1.7318	2.1434	1.9719	1.8861	.1715	
18	.3429	.2572	.3429	.2572	.1715	.1715	
19	.4287	.3429	.3429	.2572	.3429	.3772	.2572
20	.5144	.4287	.3429	.3429	.4287	.3429	.2572
21	.4287	.4287	.3429	.3429	.4287	.3429	.2572
22	.4287	.3429	.3429	.2572	.3429	.3086	.2572
23	.3429	.3429	.3429	.2572	.2572	.2572	.1715
24	.2572	.2572	.2572	1.0802	.2572	.3429	.4287
Max	**2.2291**	**2.0576**	**2.1434**	**2.1434**	**2.0576**	**1.4575**	**1.286**
Min	**.2572**	**.2058**	**.2572**	**.2572**	**.1715**	**.1372**	**.1715**
Avg	**1.0917**	**.9507**	**1.0164**	**1.0460**	**1.0431**	**.6268**	**.7145**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON
Feeder No / Name : 202 / 11 KV TAKALGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.1715	.2572	.2572	.5144	.3429
2	.2743	.2572	.1715	.2572	.2572	.5144	.5144
3	.3086	.3429	.1715	.2572	.3429	.6001	.6859
4						.6859	.9431
5						.7716	1.1145
6						.9431	1.2003
7						1.0288	1.2003
8						1.2003	1.2003
9						1.1145	1.0288
10	.5144	.8573	.8573	.9431	.6859		
11	1.2003	1.1145	.9431	1.0288	1.0288		
12	1.286	1.1145	1.0288	1.1145	1.1145		
13	1.2003	1.0288	1.0288	1.1145	1.1145		
14	.3429	.8573		1.1145	1.1145		
15	1.0288	1.1145	1.0288	1.2003	1.0288		
16	1.2003	1.1145	1.1145	1.1145	1.0288	.0857	
17	1.2003	.8573	1.2003	1.2003	.9431	.1715	
18	.2572	.1715	.2572	.1715	.1715	.2058	
19	.3429	.3429	.3429	.3429	.3429	.3772	.2572
20	.4287	.4287	.3429	.3429	.4287	.4287	.3429
21	.5144	.4287	.3429	.3429	.4287	.3772	.2286
22	.4287	.3429	.3429	.2572	.3429	.3429	.3429
23	.3429	.3429	.3429	.2572	.2572	.3086	.2572
24	.3086	.2572	.3429	.2572	.2572	.3429	.3429
Max	**1.286**	**1.1145**	**1.2003**	**1.2003**	**1.1145**	**1.2003**	**1.2003**
Min	**.2572**	**.1715**	**.1715**	**.1715**	**.1715**	**.0857**	**.2286**
Avg	**.6354**	**.6239**	**.5900**	**.6430**	**.6192**	**.5563**	**.6668**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON
Feeder No / Name : 203 / 11 KV KAJAL HIPPARGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	.8573	.6859	.8573	1.0288	.5144	.6001
2	1.3717	.8573	1.0288	1.0288	1.2003	.5144	.6516
3	1.6289	1.0288	1.2003	1.0288	1.2003	.6859	.6859
4	2.4006	1.3717	1.2003	1.2003	1.3717		
5	2.7435	1.8861	2.0576	1.7147	1.3717		
6	2.915	2.7435	3.0864	2.4006	1.3717		
7	3.0864	2.915	2.915	3.0864	3.0864		
8	3.0864	3.0864	3.0007		2.915		
9	2.915	2.7435	3.0007	2.8292	2.915		
10						2.1434	1.7147
11						2.7435	
12						2.7435	
13						2.7435	
14						2.7435	
15						2.7435	
16	.3429	.2572	.3429	.3429	.3429	2.7435	
17	.3429	.3429	.3429	.4287	.3429	2.7435	
18	.4287		.4287	.5144	.4287	.4115	
19	.6001	.8573	.7716	.6001	.6001	.7545	.6001
20	.7716	.8573	.8573	.7716	.7716	.823	.6859
21	.6859	.7716	.7716	.6859	.7716	.7202	.7716
22	.6001	.6859	.6859	.6001	.6859	.6516	.6859
23	.6001	.6859	.6001	.6001	.6001	.6173	.6001
24	.6859	.6859	.6001	1.6289	.6859	.6001	.6001
Max	**3.0864**	**3.0864**	**3.0864**	**3.0864**	**3.0864**	**2.7435**	**1.7147**
Min	**.3429**	**.2572**	**.3429**	**.3429**	**.3429**	**.4115**	**.6001**
Avg	**1.4622**	**1.3314**	**1.3098**	**1.1952**	**1.2050**	**1.5356**	**.7596**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154106 / 33/11KV THODAGA
Feeder No / Name : 201 / 11KV Thodga GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.4305	.5975	.5601	.5228	.4305	
2	.5544	.4612	.5975	.5601	.5415	.4612	
3	.5914	.492	.6348	.5975	.5228	.5381	.6468
4	.7023	.5381	.7282	.6722	.6722	.5234	
5	.7947	.6457	.9149	.8589	.8962	.615	.8501
6	.9979	.7995	1.0456	1.0082	1.0269	.6919	
11	.519	.5601	.5175		.4618		.5415
12			.462	.5228	.431	.4805	
13	.3806		.4805	.4481	.4325		
14	.346			.4294	.4152		
15	.346	.5228	.4435	.4668	.4152	.3696	
16		.5788	.4805	.4108	.3844		
17		.4668	.4066	.4294	.3997		
18	.4844	.5228	.6283	.5041	.4612	.3881	
19	.692	.6722	.7762	.7468	.5842		
20	.063	.8402	.8686	.8962	.692	.8316	
21	.5689	.7468	.7207	.7468	.5842		
22	.5388	.6722	.6653	.6722	.5381		
23	.4612	.5975	.6099	.5975			
24	.5544	.4305	.5601	.5544	.5601	.4612	.499
Max	**.9979**	**.8402**	**1.0456**	**1.0082**	**1.0269**	**.8316**	**.8501**
Min	**.063**	**.4305**	**.4066**	**.4108**	**.3844**	**.3696**	**.499**
Avg	**.5382**	**.5869**	**.6389**	**.6149**	**.5548**	**.5265**	**.6344**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] **BU 5151**
Substation No/ Name :- 154106 / 33/11KV THODAGA
Feeder No / Name : 202 / 11KV MOGHA AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5301	2.1525	2.0243	2.5587			
2	2.5301	2.214	2.1052	2.6882			
3	2.6566	2.3062	2.4291	2.7854	.7125		
4	2.7199	2.46	2.5911	2.8502			
5	2.8147	2.6137	2.8664	2.915			
6	2.7199	2.7675	2.9959	3.0121	.7449		
7	2.9986	3.0447	2.5911	3.1741	2.5911		
8	3.131	2.9212	2.672	3.1741	2.753		
9	3.0994	2.7675	2.915	3.0769	2.7854		
10							1.8519
11							3.2065
12						1.4842	3.2065
15						2.9683	
24	2.2771	2.0295	1.9433	2.4036			
Max	**3.131**	**3.0447**	**2.9959**	**3.1741**	**2.7854**	**2.9683**	**3.2065**
Min	**2.2771**	**2.0295**	**1.9433**	**2.4036**	**.7125**	**1.4842**	**1.8519**
Avg	**2.7477**	**2.5277**	**2.5133**	**2.8638**	**1.9174**	**2.2263**	**2.7550**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] **BU 5151**
Substation No/ Name :- 154106 / 33/11KV THODAGA
Feeder No / Name : 203 / 11KV TEMBHURNI AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						2.1525	
2						2.214	
3						2.3062	2.4684
4						.2586	
5						2.46	2.5777
6						2.6137	
7						2.7435	2.5621
8						2.7675	
9							2.7183
10	2.4036	2.1525	2.2672	2.332	2.1862		
11	3.1139	2.753	2.6566	2.915	2.9212		
12	2.8544	2.1052	3.131	2.834	2.5149		
13	2.46	2.753	2.3403	3.1579	2.9409		
14	2.3062			2.9959	2.694		
15		2.4291	2.6566	2.915	2.7675		
16		2.672	2.4985	2.672	2.8444		
17	2.46	2.753	***	2.915	2.7709		
24						1.9987	1.7185
Max	**3.1139**	**2.753**	**23.7356**	**3.1579**	**2.9409**	**2.7675**	**2.7183**
Min	**2.3062**	**2.1052**	**2.2672**	**2.332**	**2.1862**	**.2586**	**1.7185**
Avg	**2.5997**	**2.5168**	**5.6123**	**2.8421**	**2.705**	**2.1683**	**2.409**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB ST
Feeder No / Name : 201 / 11KV BUSTAND FEEDER. SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9993	1.9909	1.7924	1.9342	2.1719	2.0814	2.0774
2	1.9993	1.9342	1.7193	1.8267	2.0995	2.1357	
3	2.037	1.8983	1.7924	1.7909	1.97	1.9909	
4	2.037	1.9547	1.6126	1.7909	1.9547	1.9909	
5	2.0748	1.9909	1.7193	1.7551	2.0271	1.9547	
6	2.0748	2.0271	1.8861	1.7551	2.0416	1.9185	
7	2.037	2.1719	1.9616	1.7193		1.9909	
8	1.9239	2.0271	1.9239	1.7909	1.9909	2.0271	1.8519
9	1.7924		2.037	1.6834	1.7737	1.9547	
10	1.6476		2.037	1.9547		1.8099	
11	1.7013		1.9993	1.9909		1.7193	
12	1.7375		2.0748	2.0271		1.7551	
13	1.8099		2.0748	2.0271		1.7909	
14			2.037	1.9909			
15			2.0748	2.0271			
16	1.9185		2.1125	1.9547			
17	2.0995		2.2257	2.1719			
18	2.1719		2.2634	2.2805			
19	2.3891		2.6783	2.5339			
20	2.4977		2.6783	2.5339			
21			2.6029	2.4615			
22			2.5463	2.4253			
23	2.0633		2.4143	2.3529			
24	2.037	2.0271	1.8671	1.9204	2.2805	2.1719	2.0576
Max	**2.4977**	**2.1719**	**2.6783**	**2.5339**	**2.2805**	**2.1719**	**2.0774**
Min	**1.6476**	**1.8983**	**1.6126**	**1.6834**	**1.7737**	**1.7193**	**1.8519**
Avg	**2.0024**	**2.0025**	**2.0888**	**2.0291**	**2.0344**	**1.9494**	**1.9956**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB ST
Feeder No / Name : 202 / 11KV TELEPHONE FEEDER SHEDDABLE URBAN Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1022	1.2178	1.0059	1.2178	1.3394	1.2894	
2	1.1022	1.182	.9503	1.1104	1.2894	1.2536	
3	1.0852	1.1584	.9503	1.1104	1.2536	1.2178	
4	1.0852	1.1462	.9175	1.0745	1.2308	1.1946	
5	1.0852	1.1946	.852	1.0745	1.182	1.1222	
6	1.0852	1.1946	.852	1.0387	1.182	1.0745	
7	1.0174	1.1946	.8642	1.0387	1.182	1.0745	
8	.8907	1.0745	.9614	1.0387	1.0387	1.0029	.884
9	.8907		1.0174	1.0387	1.0387	.9313	
10	.9671		1.0631	1.086		1.0029	
11	1.0029		1.0631	1.1584		1.0029	
12	1.0498		1.0974	1.1946		1.0745	
13	1.086		1.1145	1.182		1.1462	
14	1.1584		1.1568	1.2308			
15	1.1946		1.1568	1.267			
16	1.2308		1.1568	1.3032			
17	1.3756		1.286	1.3394			
18	1.4118		1.4327	1.3756			
19			1.5043	1.3756			
20	1.6651		1.5043	1.5203			
21			1.3717	1.448			
22			1.3717	1.448			
23	1.3394		1.3032				
24	1.1191	1.267	1.0513	1.2003	1.3756	1.3611	1.2346
Max	**1.6651**	**1.267**	**1.5043**	**1.5203**	**1.3756**	**1.3611**	**1.2346**
Min	**.8907**	**1.0745**	**.852**	**1.0387**	**1.0387**	**.9313**	**.884**
Avg	**1.1402**	**1.1811**	**1.1252**	**1.2118**	**1.2112**	**1.1249**	**1.0593**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
AHMEDPUR[432] BU 5151
Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB ST
Feeder No / Name : 203 / 11KV EXPRESS FEEDER NON SHEDDABLE WATER SUPPLY AND Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.2012	.1067	.1677	.2012	.1341	
2	.1067	.1677	.1067	.1677	.2012	.1677	
3	.1067	.1677	.1429	.1006	.1677	.1677	
4	.1067	.1677	.1429	.1006		.1677	
5	.1067	.1341	.1429	.1341		.1677	
6	.08	.0335	.08	.1677	.2012	.1341	
7	.1067	.2012	.1067	.1677	.2012	.2012	
8	.1067	.2012	.1715	.1677	.2012	.2012	.1829
9	.0533		.1715	.1677	.2713	.1677	
10	.0671		.1715	.1677		.1677	
11	.1341		.1715	.2012		.2374	
12	.1341		.1715	.2012		.1341	
13	.1677		.1715	.1677		.1677	
14			.1143	.1341			
15	.2012		.1429	.1006			
16	.2012		.1715	.1006			
17	.2012		.1715				
18	.2374		.2134	.1341			
19	.2012		.1783	.2374			
20	.1341		.1783	.2012			
21			.1715	.2374			
22			.1715	.2012			
23	.2012		.1715	.2012			
24	.1067	.2347	.1067	.1524	.2012	.1341	.1524
Max	**.2374**	**.2347**	**.2134**	**.2374**	**.2713**	**.2374**	**.1829**
Min	**.0533**	**.0335**	**.08**	**.1006**	**.1677**	**.1341**	**.1524**
Avg	**.1365**	**.1677**	**.1521**	**.1643**	**.2058**	**.1679**	**.1677**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON
Feeder No / Name : 201 / 11KV Khandsari SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.061	.061		.0648		.061
2	.061	.061	.061		.0648		.061
3	.061	.061	.061		.0648		.061
4	.1219	.1219	.061	.0686	.1219	.1219	.061
5	.1219	.1219	.061		.1296		.061
6	.1219	.1219	.1219	.0686	.1219		.1219
7	.1219	.1219	.1219		.1219		.1219
8	.1219	.1219	.1219		.1219	.1219	.1219
9	.1219		.1219	.061	.1219		.1219
16						.0648	
20						.0305	
24		.061	.061	.0686	.0648	.061	.061
Max	**.1219**	**.1219**	**.1219**	**.0686**	**.1296**	**.1219**	**.1219**
Min	**.061**	**.061**	**.061**	**.061**	**.0648**	**.0305**	**.061**
Avg	**.1016**	**.0948**	**.0854**	**.0667**	**.0998**	**.0800**	**.0854**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON
Feeder No / Name : 202 / 11KV Sugaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.2193	1.1584		1.1336		1.0364
2	1.0974	1.3717	1.1888		1.2955		1.1888
3	1.0974	1.5851	1.1203		1.3603		1.4327
4	1.3413	1.6766	1.3717	1.5089	1.4022	.6706	1.5242
5	1.3413	1.9509	1.6461		1.6766		1.6766
6	1.829	2.0424	1.829	1.9204	1.829		1.7985
7	2.1338	2.1338	2.0119		2.1338		1.8595
8	2.1338	2.1338	2.1338		2.1338	2.1948	2.1338
9	2.1338		1.0059	2.0729			2.1033
10	.0972	.0914	.0914	.0972		.0914	.0914
11	.0972			.0972		.0914	
12	.0972	.0914	.0914	.0983		.0914	
13	.0972	.0914	.0914	.0914	.0914	.0914	.0914
14	.0972	.0914			.0914	.0914	
15	.0972	.0914	.0914		.0914	.0914	
16	.0972	.0914	.0914		.0914	.0914	
17	.1006	.0914	.0914	.0972	.0914	.0914	
18	.1006	.0914	.0914	.0972	.0914	.0914	
19	.1006	.0914	.0914	.1006	.1029	.0914	
20	.1006	.0914		.1006		.0914	
21	.1006	.0914		.1006		.0914	
22	.1006	.0914		.1006		.0914	
23	.0972	.0914		.0972		.0914	
24	.9717	.9717	.945	1.0288	.0914	.6859	.7926
Max	**2.1338**	**2.1338**	**2.1338**	**2.0729**	**2.1338**	**2.1948**	**2.1338**
Min	**.0972**	**.0914**	**.0914**	**.0914**	**.0914**	**.0914**	**.0914**
Avg	**.6899**	**.7397**	**.8412**	**.5073**	**.8567**	**.2842**	**1.3108**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON
Feeder No / Name : 203 / 11KV Chakur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.0972	.0914		.1006		.6706
2	.1006	.0972	.0914		.1017		.7316
3	.0972	.0972	.0914		.1006		.7316
4	.0972	.0972	.0914	.1029	.0972	.7316	.7621
5	.0914	.0972	.0914		.0972		.823
6	.0972	.0972	.0914	.1029	.0972		1.0974
7	.0914	.0972	.0914		.0972		1.2193
8	.0972	.0972	.0914		.0972	1.2003	1.2498
9	.0972		.0914	.0972			1.2193
10	.5182	.7621	.7926	.6478		.0914	.0914
11	.8535	.945		1.0364		.0914	
12	1.0059	1.0059	1.0669	.945		.0914	
13	1.0669	.8535	.945	.945		.0914	.0914
14	1.1279	.9145		.884	1.0059	.0914	
15	1.0669	.945	.9145	.945	.9145	.0914	
16	.9755	.9755	1.0669	.9755	1.0669	.0914	
17	.9145	.9145	1.1888	.9755	1.0669	.0914	
18	.1006	.0914	.0914	.1006	.0914	.0914	
19	.1006	.0914	.0914	.1006	.1029	.0914	
20	.1006	.0914		.1006		.0914	
21	.1006	.0914		.0983		.0914	
22	.1006	.0914		.1006		.0914	
23	.1006	.0914		.1006		.0914	
24	.0972	.0972	.0914	.1029	.0972	.6097	.6706
Max	**1.1279**	**1.0059**	**1.1888**	**1.0364**	**1.0669**	**1.2003**	**1.2498**
Min	**.0914**	**.0914**	**.0914**	**.0972**	**.0914**	**.0914**	**.0914**
Avg	**.3790**	**.3800**	**.3929**	**.4645**	**.3423**	**.2248**	**.7798**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON
Feeder No / Name : 204 / 11KV Lohara SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.0972	.0914		
2	.0972	.0972	.0914		
3	.0972	.0972	.0914		
4	.0972	.0972	.0914	.1029	
5	.0983	.0972	.0914		
6	.0914	.0972	.0914	.1029	
7	.0972	.0972	.0914		
8	.0983	.0972	.0914		
9	.0972		.0914	.1006	
10	.3239	.8535	.7621	.4858	
11	.6097	1.1279	1.0669	1.0059	
12	1.0059	1.1279	1.0974		
13	1.0364	.9335	1.1584		
14	1.0669	1.0974	1.1584		
15	1.1279	1.1279	.9755		
16	1.1584	1.0669	1.0682		
17	1.0669	1.0974	1.2193		
18	.1006	.0914	.1006		
19	.1006	.0914	.1029		
20	.1006	.0914	.1006		
21	.0972	.0914	.0983		
22	.0972	.0914	.1006		
23	.1006	.0914	.0914		
24	.0972	.1006	1.0669	.1029	.0914
Max	**1.1584**	**1.1279**	**1.2193**	**1.0059**	**.0914**
Min	**.0914**	**.0914**	**.0914**	**.1006**	**.0914**
Avg	**.3734**	**.4287**	**.4579**	**.3168**	**.0914**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON
Feeder No / Name : 205 / 11KV Nalegaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.6154	.6097		.583		.5487
2	.5182	.5182	.5792		.5506		.5182
3	.5182	.4858	.5792		.5182		.5182
4	.5182	.4572	.6097	.6859	.5792	.6097	.5487
5	.6097	.5487	.6401		.6097		.5792
6	.6706	.6097	.6706	.7545	.6401		.6401
7	.6706	.6706	.7316		.6097		.6401
8	.6706	.6706	.6097		.5792	.6859	.6097
9	.6097		.4877	.6478	.5487		.5182
10	.6097	.4877	.4572	.5792		.5487	.4877
11	.4572			.6154		.4572	
12	.4268	.5182	.5182	.6154	.6097	.4877	
13	.4534	.4877	.4877	.5487		.4572	.5487
14	.4572	.5182		.5182	.4877	.4877	
15	.5182	.4877	.4572	.5182	.4877	.5182	
16	.4877	.4572	.4572	.5182	.5182	.4572	
17	.4858	.4877	.5182	.4687	.4877	.4268	
18		.5182	.5182	.5182	.5182	.5487	
19	.8421	.6097	.5792	.8048	.7545	.6401	
20	.8097	.7926		.823		.7316	
21	.6478	.7621		.6478		.7316	
22	.6154	.6706		.6478		.6401	
23	.6154	.6401		.5506		.6097	
24	.6478	.6478	.6097	.6173	.6154	.5487	.5487
Max	**.8421**	**.7926**	**.7316**	**.823**	**.7545**	**.7316**	**.6401**
Min	**.4268**	**.4572**	**.4572**	**.4687**	**.4877**	**.4268**	**.4877**
Avg	**.5845**	**.5755**	**.5622**	**.6155**	**.5704**	**.5639**	**.5589**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON
Feeder No / Name : 206 / 11KV Atola SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1012	.8421	.7316		.7449		.0914
2	1.0364	.9145	.823		.9393		.0914
3	1.0364	1.2193	.8535		1.1336		.0914
4	1.0364	1.3717	.9145	1.0288	1.2955	.0914	.0914
5	1.1336	1.5242	1.0974		1.2803		.0914
6	1.4022	1.6461	1.1888	1.3717	1.3108		.0914
7	1.6766	1.7375	1.6766		1.5851		.0914
8	1.6766	1.5851	1.4937		1.5546	.1029	.0914
9	1.5242		1.0669	.9145			.0914
10	.1029	.0914	.0914	.1006		1.0669	
11	.0972	.0914		.0972		1.2803	
12	.0914	.0914	.0914	.0972	.0914	1.4022	
13	.0914	.0914	.0914	.1006	.0914	1.4327	1.3413
14	.0972	.0914		.0972	.0914	1.3717	
15	.0972	.0914	.0914	.0972	.0914	1.2803	
16	.0972	.0914	.0914	.0972	.0914	1.3717	
17	.0972	.0914	.0914	.0972	.0914	1.5242	
18	.1006	.0914	.0914	.1006	.0914	.0914	
19	.1006	.0914	.0914	.1017	.1029	.0914	
20	.1006	.0914		.1006		.0914	
21	.1006	.0914		.1006		.0914	
22	.1006	.0914		.1006		.0914	
23	.1006	.0914		.1006		.0914	
24	.9717	.6478	.7011	.7888	.4858	.0914	.0914
Max	**1.6766**	**1.7375**	**1.6766**	**1.3717**	**1.5851**	**1.5242**	**1.3413**
Min	**.0914**	**.0914**	**.0914**	**.0972**	**.0914**	**.0914**	**.0914**
Avg	**.5821**	**.5551**	**.6266**	**.3052**	**.6513**	**.6802**	**.2050**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON
Feeder No / Name : 207 / 11 KV GILDA SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0229	.0229	.0305		.0229		.0305
2	.0229	.0229	.0305		.0229		.0305
3	.0229	.0229	.0305		.0229		.0305
4	.0229	.0229	.0305	.0343	.0229	.0305	.0305
5	.0229	.0229	.0305		.0229		.0305
6	.0229	.0229	.0305	.0343	.0229		.0305
7	.0229	.0229	.0305		.0229		
8	.0229	.0229	.0305		.0229	.0305	
9	.0229		.0305	.0229	.0229		
10	.0229	.0305	.0305	.0229		.0305	
11	.0229	.0305		.0229		.0305	
12	.0229	.0305	.0305	.0229	.0305	.0305	
13	.0229	.0305	.0305	.0229		.0305	
14	.0229	.0305		.0229	.0305	.061	
15	.0229	.0305	.0305	.0229	.0305	.0305	
16	.0229	.0305	.0305	.0229	.0305	.0305	
17	.0229	.0305	.0305	.0229			
18	.0267	.0305	.0305	.0229	.0305	.0305	
19	.0229	.0305	.0305	.0229	.0343	.0305	
20	.0229	.0305		.0267		.0305	
21	.0229	.0305		.0229		.0305	
22	.0229	.0305		.0229		.0305	
23	.0229	.0305		.0229		.0305	
24	.0229	.0229	.0305	.0343	.0305	.0343	.0305
Max	**.0267**	**.0305**	**.0305**	**.0343**	**.0343**	**.061**	**.0305**
Min	**.0229**	**.0229**	**.0305**	**.0229**	**.0229**	**.0305**	**.0305**
Avg	**.0231**	**.0275**	**.0305**	**.0250**	**.0265**	**.0326**	**.0305**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154011 / 33KV ZARI S/N
Feeder No / Name : 201 / 11KV Chapoli SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1145	1.286		
16	.1715	.1715	.1715	1.0288
24		.2572		
Max	1.1145	1.286	.1715	1.0288
Min	.1715	.1715	.1715	1.0288
Avg	.643	.5716	.1715	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154011 / 33KV ZARI S/N
Feeder No / Name : 202 / 11KV Jadhala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1145	1.2003		
16	1.7147	1.0288	1.7147	1.6289
24	.8573	.9431		
Max	**1.7147**	**1.2003**	**1.7147**	**1.6289**
Min	**.8573**	**.9431**	**1.7147**	**1.6289**
Avg	**1.2288**	**1.0574**	**1.7147**	**1.6289**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154011 / 33KV ZARI S/N
Feeder No / Name : 203 / 11 KV MAHALANGI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.1434		2.2291	1.9719
24	.3429	.3429		
Max	**2.1434**	**.3429**	**2.2291**	**1.9719**
Min	**.3429**	**.3429**	**2.2291**	**1.9719**
Avg	**1.2432**	**.3429**	**2.2291**	**1.9719**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S
Feeder No / Name : 201 / 11KV Chakur GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		1.3336		
8	1.5242	1.3336		
9		1.331		
10		1.5165		
11		1.5165		
16	1.5242		1.5242	
24		1.3336		1.1431
Max	**1.5242**	**1.5165**	**1.5242**	**1.1431**
Min	**1.5242**	**1.331**	**1.5242**	**1.1431**
Avg	**1.5242**	**1.3941**	**1.5242**	**1.1431**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S
Feeder No / Name : 204 / 11KV Tivghal SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.8573		
9		3.3208		
10		3.4225		
11		2.3767		
16	2.4768		2.6673	
24		2.7625		2.4768
Max	**2.4768**	**3.4225**	**2.6673**	**2.4768**
Min	**2.4768**	**.8573**	**2.6673**	**2.4768**
Avg	**2.4768**	**2.5480**	**2.6673**	**2.4768**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S
Feeder No / Name : 205 / 11KV Bothi Express Feeder KV- 11 / OUTGOING **NON SHEDDABLE WATER SUPPLY AND UTILITY**

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.0953		
8	.0953	.0953		
9		.0948		
10		.0948		
16	.0953		.0953	
24		.0953		.0953
Max	**.0953**	**.0953**	**.0953**	**.0953**
Min	**.0953**	**.0948**	**.0953**	**.0953**
Avg	**.0953**	**.0951**	**.0953**	**.0953**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] **BU 5169**
Substation No/ Name :- 154038 / 33/11 KV WADWAL
Feeder No / Name : 201 / 11KV Wadwal **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6077	.6752	.6077	.696	.7266		
2	.6752	.7596	.6414	.7469	.7785		
3	.709	.5739	.709	.7978	.8304		
4	.7596	.6752	.7978	.8488	.865		
5	.844	.8778	.8657	.9336	.9169		
6	1.131	1.2322	1.2731	1.1543	1.1763		
7	1.4348	1.4179	1.392	1.4769	1.5569		
8	.6752		.7978	.7299	.8131		
9			.713	.713			
10			.5602	.5432			1.2455
11			.5432	.5262		1.1763	
12			.5262	.4923		1.2455	
13			.5941	.5536		1.3147	
14			.5602	.5536		1.3839	
15			.5262	.5536		1.2801	
16			.5093			.6055	
17	.5233	.5402	.5262				
18	.5908		.5602				
19	.8609		.9336				
20	.9453		.9336				
21	.9284		.9336				
22	.8778		.8657				
23	.7934		.7978				
24	.6077	.6752	.6077	.696			
Max	**1.4348**	**1.4179**	**1.392**	**1.4769**	**1.5569**	**1.3839**	**1.2455**
Min	**.5233**	**.5402**	**.5093**	**.4923**	**.7266**	**.6055**	**1.2455**
Avg	**.8103**	**.8252**	**.7406**	**.7510**	**.9580**	**1.1677**	**1.2455**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154048 / 33/11kv chapoli
Feeder No / Name : 201 / 11KV Chapoli SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							1.5432
16		1.1469	1.4022		1.1736		
24	.6135		.4915	.7011	.6001	.6554	.8669
Max	.6135	1.1469	1.4022	.7011	1.1736	.6554	1.5432
Min	.6135	1.1469	.4915	.7011	.6001	.6554	.8669
Avg	.6135	1.1469	.9469	.7011	.8869	.6554	1.2051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154048 / 33/11kv chapoli
Feeder No / Name : 202 / 11KV Ajansonda SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4239						
16		2.0576	2.0348		2.1434	.4239	
24	.5935		.5144	.5935	.6001	.8573	.8383
Max	.5935	2.0576	2.0348	.5935	2.1434	.8573	.8383
Min	.4239	2.0576	.5144	.5935	.6001	.4239	.8383
Avg	.5087	2.0576	1.2746	.5935	1.3718	.6406	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154048 / 33/11kv chapoli
Feeder No / Name : 203 / 11KV Naigaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.8442		1.7604	1.6766	1.6766		
16		.2515	.3353		.2486	1.6766	
24	.8383		.8383	.8383	.663	.503	.503
Max	**1.8442**	**.2515**	**1.7604**	**1.6766**	**1.6766**	**1.6766**	**.503**
Min	**.8383**	**.2515**	**.3353**	**.8383**	**.2486**	**.503**	**.503**
Avg	**1.3413**	**.2515**	**.978**	**1.2575**	**.8627**	**1.0898**	**.503**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154048 / 33/11kv chapoli
Feeder No / Name : 204 / 11KV BSF **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.04		.04	.04	.04		
16		.0429	.04		.04	.0391	
24	.04		.0429	.04	.04	.0429	.0391
Max	.04	.0429	.0429	.04	.04	.0429	.0391
Min	.04	.0429	.04	.04	.04	.0391	.0391
Avg	.04	.0429	.0410	.04	.04	.041	.0391

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] **BU 5169**
Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED
Feeder No / Name : 201 / 11KV Ganjur **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.8573	.8573	1.0288	.8573	.2572	.181
2	.8573	.8573	.8573	1.1145	.8573	.2572	.181
3	.8573	.8573	.9431	1.1145	1.0288	.2572	.181
4	.9431	1.0288	1.0288	1.2003	1.1145	.2572	.181
5	1.0288	1.0288	1.2003	1.2003	1.2003	.3429	.2715
6	1.1145	1.1145	1.3717	1.3717	1.2003	.3429	.2715
7	1.286	1.3717	1.4575	1.3717	1.286	.3429	.362
8	1.286	1.4575	1.3717	1.4575	1.3717	.2572	.362
9	1.286	1.3717	1.3717	1.3717	1.286	.2715	.1715
10	.1715	.1715	.1715	.1715	.1715	.8573	.9431
11	.1715	.1715	.181	.1715	.1715	1.1145	1.1145
12	.1715	.1715	.181	.1715	.1715	1.286	1.286
13	.1715		.181	.1715	.1715	1.2003	1.286
14	.1715	.1715	.181	.1715	.1715	1.2003	1.3717
15	.1715	.1715	.181	.1715	.1715	1.286	1.3717
16	.1715	.1715	.181	.1715	.1715	1.3717	1.3717
17	.1715	.1715	.181	.1715	.1715	1.3717	1.3717
18	.1715	.1715	.181	.1715	.1715	.181	.1715
19	.1715	.1715	.181	.2572	.1715	.181	.1715
20	.1715	.2572	.2715	.2572	.2572	.2715	.3429
21	.2572	.1715	.2715	.1715	.2572	.2715	.1715
22	.2572	.1715	.181	.1715	.2572	.2715	.2572
23	.2572	.1715	.181	.1715	.1715	.2715	.1715
24	.1715	.8573	.5144	.9955	.5144	.1715	.181
Max	**1.286**	**1.4575**	**1.4575**	**1.4575**	**1.3717**	**1.3717**	**1.3717**
Min	**.1715**	**.1715**	**.1715**	**.1715**	**.1715**	**.1715**	**.1715**
Avg	**.5108**	**.5703**	**.5700**	**.6166**	**.5573**	**.5789**	**.5728**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED
Feeder No / Name : 202 / 11KV Shivankhed SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	.8573	.8573	.8573	.4287	.362
2	.6859	.8573	.8573	.9431	.8573	.4287	.362
3	.7716	.8573	.9431	.9431	.8573	.4287	.4525
4	.8573	1.0288	1.0288	1.0288	.8573	.5144	.4525
5	.9431	1.0288	1.0288	1.0288	1.0288	.5144	.543
6	1.1145	1.1145	1.2003	1.1145	1.0288	.6859	.543
7	1.2003	1.3717	1.3717	1.4575	1.2003	.6859	.6335
8	1.3717	1.4575	1.3717	1.3717	1.286	.6001	.6335
9	1.2003	1.3717	1.3717	1.3717	1.286	.543	.5144
10	.3429	.3429		.3429	.3429	.8573	.8573
11		.2572		.3429	.3429	1.0288	1.0288
12				.2572	.3429	1.1145	1.1145
13			.181	.2572	.3429	1.0288	1.2003
14			.181		.3429	1.0288	1.286
15			.181	.2572	.3429	1.1145	1.286
16			.181	.2572	.3429	1.2003	1.286
17			.181	.2572	.3429	1.286	1.2003
18		.2572	.2715	.2572	.3429	.5068	.3429
19	.3429	.5144	.4525	.5144	.4287	.6335	.3429
20	.5144	.5144	.6335	.5144	.5144	.6335	.6001
21	.5144	.4287	.6335	.4287	.5144	.6335	.6001
22	.5144	.3429	.543	.3429	.5144	.543	.5144
23	.5144	.3429	.4525	.3429	.4287	.4525	.5144
24	.5144	.8573	.6001	.724	.5144	.4287	.4525
Max	**1.3717**	**1.4575**	**1.3717**	**1.4575**	**1.286**	**1.286**	**1.286**
Min	**.3429**	**.2572**	**.181**	**.2572**	**.3429**	**.4287**	**.3429**
Avg	**.7555**	**.7668**	**.6915**	**.6614**	**.6358**	**.7217**	**.7135**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] **BU 5169**
Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED
Feeder No / Name : 203 / 11KV Dhaveli **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	1.2003	1.2003
2	.1715	.1715	.1715	.1715	.1715	1.3717	1.2003
3	.1715	.1715	.1715	.1715	.1715	1.5432	1.5432
4	.1715	.1715	.1715	.1715	.1715	1.7147	1.7147
5	.1715	.2572	.1715	.1715	.1715	2.0576	2.1434
6	.2572	.3429	.1715	.1715	.1715	2.2291	2.2291
7	.2572	.3429	.2572	.2572	.2572	2.3148	2.2291
8	.2572	.2572	.2572	.2572	.2572	2.2291	2.1434
9	.1715	.2572	.1715	.1715	.1715	2.2291	2.1434
10	1.2003	1.1145	.6859	1.0288	.8573	.181	.1715
11	1.7147	2.0576	.8573	2.0576	1.7147	.181	.1715
12	1.8861	2.1434	.9431	2.0576	2.0576		.1715
13	1.9719		1.286	1.9719	2.2291		.1715
14	2.0576	2.1434	1.5432	1.8861	2.0576	.181	.1715
15	2.0576	2.1434	1.6289	1.8861	2.1434	.181	.1715
16	2.0576	2.1434	1.6289	1.8861	2.2291	.181	.1715
17	2.0576	2.2291	1.6289	2.0576	2.0576	.181	.1715
18	.1715	.1715	.1715	.1715	.1715	.181	.1715
19	.1715	.1715	.1715	.2572	.1715	.181	.1715
20	.1715	.2572	.1715	.2572	.1715	.181	.1715
21	.2572	.1715	.1715	.1715	.1715	.181	.1715
22	.2572	.1715	.1715	.1715	.1715	.181	.1715
23	.2572	.1715	.1715	.1715	.1715	.181	.1715
24	.1715	.1715	.1715	.1715	.1715	.8573	
Max	**2.0576**	**2.2291**	**1.6289**	**2.0576**	**2.2291**	**2.3148**	**2.2291**
Min	**.1715**	**.1715**	**.1715**	**.1715**	**.1715**	**.181**	**.1715**
Avg	**.7609**	**.7567**	**.5466**	**.7466**	**.7609**	**.9054**	**.8238**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON
Feeder No / Name : 201 / 11KV Sugaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8535	.7316	.4108	
2	.7926	.6455		.8535	.823	.4108	
3	.884		.9976	.9145	.945	.4108	.4108
4	.9755	.8802		.9145	1.0364	.4694	
5	1.0974			.9145	1.0974	.5281	
6	1.1888	1.0856	1.1149	.9145	1.1584	.7042	.4694
7	1.2193			.9755	1.2193	.5868	
8	1.2803	1.1736	1.1149	.9755	.7926	.5281	.4694
9		.8802		.9755	.8802	.4694	.4877
10		.2934	.3227	.2439	.2347	.4694	.6706
11			.2347		.2641		
12					.2347		
13				.2134	.2347	1.0562	
14				.2439	.2347		
15			.2347	.3048			
16				.3658		1.1736	
17				.3048		1.1736	
18		.3521		.3658		.2934	
19				.4268			
20				.4877		.5281	
21		.6161		.4877	.5868		
22				.5487			.5487
23		.5868		.5487	.4694	.4694	.6097
24		.5868	.4694	.6706		.4694	.6097
Max	**1.2803**	**1.1736**	**1.1149**	**.9755**	**1.2193**	**1.1736**	**.6706**
Min	**.7926**	**.2934**	**.2347**	**.2134**	**.2347**	**.2934**	**.4108**
Avg	**1.0626**	**.7100**	**.6413**	**.6138**	**.6839**	**.5971**	**.5345**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON
Feeder No / Name : 202 / 11KV Devangra SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061			.0914	.061	.0147	
2	.0914	.088		.0914	.0914	.0147	
3	.0914		.088	.0914	.0914	.0147	.0147
4	.0914	.088		.0914	.0914	.0147	
5	.1219			.1067	.0914	.0147	
6	.1219	.1174	.1174	.1219	.1219	.0147	.0147
7	.1219			.1372	.1219	.0147	
8	.1219	.1174	.132	.1372	.0914	.0147	.0147
9		.0587		.1219	.088	.0147	.0152
10		.0147		.0152	.0147	.044	.061
11	.0147			.0152	.0147		.061
12				.0152	.0147		
13	.0147	.0147		.0152	.0147	.088	
14			.0147	.0152	.0147		
15			.0147	.0152			
16	.0147	.0147		.0152		.088	
17	.0147			.0152		.088	
18		.0147		.0152		.0147	
19				.0152	.0147		
20				.0152		.0147	
21	.0147	.0147		.0152	.0147		
22				.0152			.0152
23	.0147	.0147		.0152	.0147	.0147	.0152
24		.0587	.0147	.061		.0147	.0152
Max	**.1219**	**.1174**	**.132**	**.1372**	**.1219**	**.088**	**.061**
Min	**.0147**	**.0147**	**.0147**	**.0152**	**.0147**	**.0147**	**.0147**
Avg	**.0651**	**.0514**	**.0636**	**.0527**	**.0569**	**.0294**	**.0252**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON
Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829			.2743	.1829		
2	.2134	.2347		.3658	.2743		
3	.2743		.4108	.3658	.3353		
4	.3353	.2934		.4268	.3658		
5	.3658			.4268	.4268		
6	.4268	.4694	.5281	.4877	.4268		
7	.4877			.5487	.4877		
8	.5182	.5868	.5281	.4877	.2439		
9		.1174		.4877	.2934		
10						.1027	.2439
11							.4268
13						.4694	
16						.4694	
17						.4694	
24		.088	.1467	.1524			
Max	**.5182**	**.5868**	**.5281**	**.5487**	**.4877**	**.4694**	**.4268**
Min	**.1829**	**.088**	**.1467**	**.1524**	**.1829**	**.1027**	**.2439**
Avg	**.3506**	**.2983**	**.4034**	**.4024**	**.3374**	**.3777**	**.3354**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154096 / 33KV Ujalamb S/n
Feeder No / Name : 201 / 11KV Ujalamb SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154096 / 33KV Ujalamb S/n
Feeder No / Name : 203 / 11KV Thivghal SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.4191
Max	.4191
Min	.4191
Avg	.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154097 / 33 KV ASHTA S/S
Feeder No / Name : 201 / 11KV Mahalangra SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	03-APR-17
HR	Load (MW)
10	1.7528
11	2.1338
12	2.4577
15	1.9433
Max	**2.4577**
Min	**1.7528**
Avg	**2.0719**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154097 / 33 KV ASHTA S/S
Feeder No / Name : 202 / 11KV Ganjur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17
HR	Load (MW)
9	1.448
Max	1.448
Min	1.448
Avg	1.448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
CHAKUR (R) S/DN[433] BU 5169
Substation No/ Name :- 154097 / 33 KV ASHTA S/S
Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-APR-17
HR	Load (MW)
13	1.3108
Max	1.3108
Min	1.3108
Avg	1.3108

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] BU 4822
Substation No/ Name :- 154010 / 33/11 DEVANI
Feeder No / Name : 201 / 11KV TOGARI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8718	.6859	.9145	.8048		.8413
2	.9511	.8718	.6859	.9511	.8383		.8779
3	.9877	.9054	.6859	.9877	.8383	.7461	.9145
10	.6104	.6706	.407	.5765	.6516	.5144	.7377
11	.8139	.6516	.78	.6706	.583	.7461	.7712
12	.6706	.7202	.6443	.6104	.5487	.78	.6706
13	.7042	.6859	.6104	.8048	.5487	.7461	
14	.7377	.6516		.6706		.7122	
15	.7042	.583	.6104	.6443		.7122	
16	.6443		.6783	.6104		.7122	
17	.6443		.6104	.6706		.6783	
18	.7712		.8048	.8383		.9145	
19	1.1736		1.3169	1.1065		1.2071	
20	1.2407		1.4266	1.2742		1.3535	
21	1.1401		1.3169	1.1065		1.2071	
22	1.0059		1.1706	1.0059		1.0974	
23	.9389		1.0608	.7712		.9511	
24	.9145	.8383	.6859	.9511	.8048	.6859	.8413
Max	**1.2407**	**.9054**	**1.4266**	**1.2742**	**.8383**	**1.3535**	**.9145**
Min	**.6104**	**.583**	**.407**	**.5765**	**.5487**	**.5144**	**.6706**
Avg	**.8649**	**.7450**	**.8342**	**.8425**	**.7023**	**.8603**	**.8078**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] BU 4822
Substation No/ Name :- 154010 / 33/11 DEVANI
Feeder No / Name : 202 / 11KV LASONA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4243	1.8442	1.166	1.6278			2.0348
2	1.4922	2.0119	1.286	1.8313			2.1704
3	2.0348	2.1548	1.5432	1.8991			2.3061
4	2.2382	2.3205	1.9204	2.0687			1.9669
5	2.3739	2.4531	2.8807	2.3061			2.7808
6	2.4417	2.5857	2.8807	2.8487			3.1878
7	2.5774	3.3916	3.3436	3.1369	.6706		3.5269
8	2.9165	3.2769	3.5665	2.5774	.8383	3.5665	3.7982
9	3.1539	3.1131	3.5269	2.8487	1.0059	3.6351	3.6456
10					2.7092		
11					2.2977		
16	.4917		.5487	.4409			
17	.5596		.5853	.5765		.5853	
18	.5935		.6219	.5765		.695	
19	.9054		1.134	1.0395		.9145	
20	1.291		1.3717	1.2239		1.3535	
21	1.1736		1.2071	1.0395		1.3352	
22	.9724		1.0974	.9724		1.0974	
23	.8048		.9145	.7545		.9145	
24	1.3565	1.643	.8573	1.4922		1.1145	1.6278
Max	**3.1539**	**3.3916**	**3.5665**	**3.1369**	**2.7092**	**3.6351**	**3.7982**
Min	**.4917**	**1.643**	**.5487**	**.4409**	**.6706**	**.5853**	**1.6278**
Avg	**1.6001**	**2.4795**	**1.6918**	**1.6256**	**1.5043**	**1.5212**	**2.7045**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] **BU 4822**
Substation No/ Name :- 154010 / 33/11 DEVANI
Feeder No / Name : 203 / 11KV WALANDI **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.6443	.4458	.7316	.6706		.407
2	.8048	.7377	.4458	.8048	.7042		.4409
3	.9145	.8048	.5144	.8779	.7377		.4748
4							.5087
5							.8048
6							.9496
7							1.0174
8						1.2346	1.0852
9						1.2003	1.0852
10	.3391	.6706	.2374	.3391	.5487		
11	.7122	.6516	.78	.8383	.5144		
12	.7377	.7202	.7461	.7377	.6516		
13	.7712	.6859	.6783	.8048	.7202		
14	.8048	.6859	.6783	.7377			
15	.8048	.6859	.6783	.7377			
16	1.1736		.78	.7377			
17	.8383		.8478	.8383		.439	
18	.2713		.4755	.4748		.5121	
19	.7377		.9145	.5765		.8413	
20	.8718		.9511	.6706		.9877	
21	.7712		.6219	.8718		.8779	
22	.7377		.8779	.7377		.7316	
23	.7042		.7316	.7377		.6584	
24	.6584	.6104	.4458	.695	.6104	.4115	.3391
Max	**1.1736**	**.8048**	**.9511**	**.8779**	**.7377**	**1.2346**	**1.0852**
Min	**.2713**	**.6104**	**.2374**	**.3391**	**.5144**	**.4115**	**.3391**
Avg	**.7436**	**.6897**	**.6584**	**.7194**	**.6447**	**.7894**	**.7113**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] **BU 4822**
Substation No/ Name :- 154010 / 33/11 DEVANI
Feeder No / Name : 205 / 11KV BORUL **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8139	.7712	.5144	.6783	.7042		.5853
2	.8817	.8383	.7202	.7461	.7377		.6584
3	.9496	.8718	.9945	.78	.7377	1.8313	.695
4	1.153	.9054	1.0631	.8139	.7712		
5	1.2209	1.0059	1.1145	1.0852	.9389		
6	1.4243	1.0395	1.2346	1.2209	1.1065		
7	1.56	1.576	1.4403	1.3565	1.4419		
8	1.7974	1.576	1.3717	1.4922	1.6095		
9	1.7295	.407	1.3565	1.4582	1.576		
10						.4115	1.643
11						.407	1.643
12						1.6956	1.5089
13						1.56	
14		.4115				1.4582	
15		.2058				1.6278	
16	.3391		.407	.3391		1.6278	
17	.3052		.3658	.3391		1.56	
18	.3052		.3658	.3391		.3292	
19	.4748		.6219	.6104		.5121	
20	.7377		.8048	.7377		.8048	
21	.6443		.695	.6443		.695	
22	.5087		.5487	.5087		.6584	
23	.4409		.5121	.4409		.5853	
24	.8048	.7042	.4115	.6443	.6706	.463	.5487
Max	**1.7974**	**1.576**	**1.4403**	**1.4922**	**1.6095**	**1.8313**	**1.643**
Min	**.3052**	**.2058**	**.3658**	**.3391**	**.6706**	**.3292**	**.5487**
Avg	**.8939**	**.8594**	**.8079**	**.7908**	**1.0294**	**1.0142**	**1.0403**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] BU 4822
Substation No/ Name :- 154010 / 33/11 DEVANI
Feeder No / Name : 206 / AMBEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5087	.5144	.5121	.5426		.5121
2	.5853	.5426	.5144	.5853	.5765		.5487
3	.6036	.5765	.5144	.6584		1.2548	.6219
10	.8817	1.1065	.3052	1.0174	.8916	.3429	1.073
11	1.3226	1.0288	1.4922	1.4754	.8573	1.2548	1.5927
12	1.3413	1.5775	1.4582	1.4586	.8916	1.4922	1.5592
13	1.3413	1.5432	1.2209	1.2742	.8573	1.4922	
14		1.4575		2.6826		1.4922	
15	1.4083	1.3717	1.4922	1.4419		1.6448	
16	1.6095		1.4582	1.576		1.6448	
17	1.643		1.56	1.6598		1.6278	
18	.2713		.3658	.2883		.2926	
19	.5426		.5487	.5765		.5487	
20	.6706		.7682	.7209		.7499	
21	.6613		.7316	.6104		.695	
22	.5765		.6219	.5935		.6401	
23	.5087		.5487	.5087		.5853	
24	.4938	.4578	.5144	.4755	.5087	.3429	.4938
Max	**1.643**	**1.5775**	**1.56**	**2.6826**	**.8916**	**1.6448**	**1.5927**
Min	**.2713**	**.4578**	**.3052**	**.2883**	**.5087**	**.2926**	**.4938**
Avg	**.8808**	**1.0171**	**.8606**	**1.0064**	**.7322**	**1.0063**	**.9145**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] BU 4822
Substation No/ Name :- 154098 / 33 KV SUB STATION TOGRI
Feeder No / Name : 203 / 11 KV WAGDRI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.7922	.5853	.6413	.6224	1.2071	.57
2	.7922	1.0185	.499	.6036	.7167	1.6221	
3	.8402	1.0185	.4805	.6224	.7842	1.7353	1.0395
4						1.8484	1.3748
5						1.9239	1.4083
6						2.037	1.5424
7						2.0165	1.8107
8						2.0538	1.8778
9							2.2405
10	1.3748	1.4419	1.3969	.7468	.9145		
11	1.6766	1.6766	1.5384	1.9418	1.4632		
12	1.5927	1.643	1.3123	1.9753	1.4937		
13	1.576	1.576	1.4899	2.0165	1.4899		
14	1.6095	1.5424	1.4251	1.9418	1.4582		
15	1.576	1.576	1.5061	1.9044	1.3748		
16	1.576	1.576	1.4899	1.8298	1.5912	.3547	
17	1.8298	1.4784	1.5424	1.6032	1.7177	.9431	
18	.4904	.2987	.415	.462	.4904	.6036	
19	.7545	.3921	.6036	.7842	.9808	.7545	
20	1.0562	.5914	1.0185	1.0374		.7545	
21	1.0185	.7947	.8488	.9431	.9054	.7167	
22	.9808	.8779	.7167	.7356	.7922	.679	
23	.8676	.7392	.679	.6602	.7545	.6036	.6036
24	.6413	.7167	.5487	.6036	.6224	.8676	.4694
Max	**1.8298**	**1.6766**	**1.5424**	**2.0165**	**1.7177**	**2.0538**	**2.2405**
Min	**.4904**	**.2987**	**.415**	**.462**	**.4904**	**.3547**	**.4694**
Avg	**1.1650**	**1.0972**	**1.0053**	**1.1696**	**1.0690**	**1.2189**	**1.2937**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] **BU 4822**
Substation No/ Name :- 154101 / 33/11 KV JAWALGA
Feeder No / Name : 201 / JAWALGA **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.6097	.6859	.0076	.5868	.8326
2	.7621		.6859	.7621	.7621		1.0166
3	.8764	.9335	.8764	.7621	.9526	.8048	1.2003
4							1.406
5							1.6095
6							1.749
7						1.7532	2.2024
8						1.9433	2.0165
9						2.0972	1.8435
10	1.2041	1.3763	1.3279	1.1138			
11	.1076	1.6518	1.768	1.8343	1.7204		
12	2.0405	1.829	1.89	1.9845	1.3927		
13	2.2611	1.7071	1.7985	1.8564	1.5565		
14		1.2955	1.6004	1.8564			
15	1.4582	1.4861	1.547	1.9006			
16	.8383	1.3413	1.7147	1.4899	1.3603	.381	
17	1.6194	1.7238	1.547	1.9006	1.6842	.4572	
18	.3048	.4001	.3429	.381	.4572	.4572	
19		.7811	.6097	.7621		.724	
20	.9526	.8383	.7621	.9526	.8573	1.105	
21	.8383	.7049	.6859		.8192	.6478	
22	.7621		.5716		.7621		
23	.7049		.5335	.5716			.5716
24	.6097	.6478	1.547	.5335		.5935	.543
Max	**2.2611**	**1.829**	**1.89**	**1.9845**	**1.7204**	**2.0972**	**2.2024**
Min	**.1076**	**.4001**	**.3429**	**.381**	**.0076**	**.381**	**.543**
Avg	**1.0016**	**1.1940**	**1.1343**	**1.2092**	**1.0277**	**.9626**	**1.3628**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] BU 4822
Substation No/ Name :- 154101 / 33/11 KV JAWALGA
Feeder No / Name : 202 / 11 KV KAUTHALA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0075		.012	.0076	.0062	.0095	.0057
2	.009		.0137	.0089	.0078		.0076
3	.0107	.0153	.0151	.0107	.0082	.0133	.0095
4	.0122		.0168	.0129	.0102		
5	.0156		.0218	.0197	.0113		
6	.0201		.0251	.0173	.0144		
7	.0246	.0311	.0291	.0213	.0174		
8	.0268	.0311	.0291	.0213	.0187		
9	.0213	.0246	.0232	.0198	.0164		
10						.0164	.0162
11						.0213	.0178
12						.0201	.0198
13						.0229	.0213
14						.0199	
15						.0218	
16	.0038	.0038	.0038	.0057	.0038	.0237	
17	.0038	.0038	.0057	.0057	.0038	.0259	
18	.0038	.0057	.0076	.0057	.0076	.0038	
19		.0076	.0095	.0095		.0076	
20	.0133	.0114	.0114	.0133	.0133	.0133	
21	.0114	.0095	.0076		.0133	.0133	
22	.0095		.0057		.0133		
23	.0076		.0038	.0057			
24	.0062	.011	.0069	.003	.0046	.0114	.0076
Max	**.0268**	**.0311**	**.0291**	**.0213**	**.0187**	**.0259**	**.0213**
Min	**.0038**	**.0038**	**.0038**	**.003**	**.0038**	**.0038**	**.0057**
Avg	**.0122**	**.0141**	**.0138**	**.0118**	**.0106**	**.0163**	**.0132**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] **BU 4822**
Substation No/ Name :- 154101 / 33/11 KV JAWALGA
Feeder No / Name : 203 / 11 KV MATEGADI **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0107		.012	.0061	.0038	.0057	.0038
2	.0127		.0137	.0067	.0038		.0057
3	.0144	.017	.0151	.0086	.0038	.0076	.0057
4	.0178		.0184	.0107	.0038		.0057
5	.0194		.0201	.0146	.0038		.0076
6	.0218		.0235	.0163	.0057		.0076
7	.0251	.0279	.0262	.0217	.0057		.0057
8	.0251	.0279	.0275	.0193	.0038		.0057
9	.0235	.0259	.0019	.0193	.0164		
10					.0168		.0073
11						.0232	
12						.0153	.0107
13						.0218	
14						.0201	
15						.0203	
16	.0019	.0019	.0191	.0038		.0251	
17	.0019	.0019	.0038	.0038	.0019	.0232	
18	.0019	.0038	.0057	.0038	.0019	.0019	
19		.0057	.0076	.0057		.0038	
20	.0076	.0057	.0076	.0076	.0076	.0076	
21	.0057	.0057	.0057		.0076	.0057	
22	.0057		.0038		.0076		
23	.0057		.0038	.0038			
24	.0098	.017	.0069	.0017	.0168	.0057	.0038
Max	**.0251**	**.0279**	**.0275**	**.0217**	**.0168**	**.0251**	**.0107**
Min	**.0019**	**.0019**	**.0019**	**.0017**	**.0019**	**.0019**	**.0038**
Avg	**.0124**	**.0128**	**.0124**	**.0096**	**.0069**	**.0134**	**.0063**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
DEVANI S/DN.[822] BU 4822
Substation No/ Name :- 154101 / 33/11 KV JAWALGA
Feeder No / Name : 204 / Morge Express Feeder
Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0627				
8		.0806			.0271	
9		.0358		.0543	.0452	
10		.0438				.0716
11		.0613		.0633	.0627	.0351
12		.0526	.0544		.0537	.0613
13				.0632	.0448	
15			.0544			
16		.0351	.0452	.0542		
17		.0526	.0543	.0543		
18	.0806	.0701	.0905	.0903	.009	
19	.0627	.0526				
20	.009					
Max	**.0806**	**.0806**	**.0905**	**.0903**	**.0627**	**.0716**
Min	**.009**	**.0351**	**.0452**	**.0542**	**.009**	**.0351**
Avg	**.0508**	**.0547**	**.0598**	**.0633**	**.0404**	**.056**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154012 / 33 kv s/s hali
Feeder No / Name : 201 / mortalwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287		.4287	.3429
2		.4287		.8573	.3429
3		.6859		.8573	.3429
4		.6859			.6859
5		.8573			.8573
9		.8573			.8573
10		.8573		.3429	.8573
11		.8573		.3429	
12	.3429	.3429			
13		.3429		.2572	
14		.2572		.2572	
15	.4287	.2572		.2572	
16	.4287	.4287		.2572	
17		.4287		.2572	
18	.3429	.3429		.2572	
19				.8573	
20				.8573	
21				.6859	
22				.5144	
23				.2572	
24		.3429	.3429	.3429	.1715
Max	**.4287**	**.8573**	**.3429**	**.8573**	**.8573**
Min	**.3429**	**.2572**	**.3429**	**.2572**	**.1715**
Avg	**.3858**	**.5251**	**.3429**	**.4640**	**.5573**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154012 / 33 kv s/s hali
Feeder No / Name : 202 / khandsari SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573		1.0288	.0857
2		1.0288		1.2003	.0857
3		1.2003		1.2003	.0857
4		1.2003		1.286	
5		1.2003		1.286	
9		2.0576		1.7147	
10		2.0576		1.8861	1.2003
11		1.8004		1.8004	
12	1.8004	1.8004		1.8004	
13		.0857			
14		.0857			
15	.0857	.0857			
16	.0857	.0857		.0857	
17		.0857		.0857	
18	.0857	.0857		.0857	
19				.0857	
20				.0857	
21				.0857	
22				.0857	
23				.0857	
24		.8573	.8573	.8573	.0857
Max	**1.8004**	**2.0576**	**.8573**	**1.8861**	**1.2003**
Min	**.0857**	**.0857**	**.8573**	**.0857**	**.0857**
Avg	**.5144**	**.9109**	**.8573**	**.8192**	**.3086**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154012 / 33 kv s/s hali
Feeder No / Name : 203 / wadhona SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	02-APR-17	03-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717		1.3717	.6859
2		1.7147		1.5432	.6859
3		1.7147		1.8861	.8573
4		1.8861		2.0576	.9431
5		2.0576		2.2291	1.0288
6		1.7147		1.8861	
7		1.8861		1.8861	
8		2.0576		1.7147	
9		2.2291		1.7147	1.2003
10		1.2003		.8573	1.2003
11		1.2003		1.1145	
12	1.5432	1.2003			
13		1.286		.8573	
14		1.286		.8573	
15	1.4575	1.286		.8573	
16	1.5432	1.2003		.8573	
17		1.3717		.9431	
18	.3429	.3429		.1715	
19				.5144	
20				.5144	
21				.5144	
22				.3429	
23				.2572	
24		1.2003	1.2003	1.2003	.4287
Max	**1.5432**	**2.2291**	**1.2003**	**2.2291**	**1.2003**
Min	**.3429**	**.3429**	**1.2003**	**.1715**	**.4287**
Avg	**1.2217**	**1.4845**	**1.2003**	**1.1369**	**.8788**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154012 / 33 kv s/s hali
Feeder No / Name : 205 / mortalwadi-ww NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	30-MAR-17	02-APR-17
HR	Load (MW)	Load (MW)
13		.2572
14		.2572
15		.2572
16	.2401	.2572
17		.2572
Max	**.2401**	**.2572**
Min	**.2401**	**.2572**
Avg	**.2401**	**.2572**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154020 / shirur taj.
Feeder No / Name : 201 / telgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0137	.0103	.0142	.0137	.0124	.0652	.0532
2	.0309	.0137	.0159	.0137	.0142	.0686	.062
3	.0154	.0154	.0177	.0154	.0142	.072	.0638
4	.0154	.0189	.0213	.0154	.0158	.0754	.0638
5	.0206	.0206	.023	.0208	.0193	.084	.0673
6	.0274	.0274	.0283	.0257	.0263	.0909	.0868
7		.036	.0354	.0309	.0381	.0926	.0213
8	.036	.036	.0354		.0377	.0909	.0177
9	.0377	.0309	.0343	.0326	.0463	.0566	.0154
10	.0326	.0532	.048	.0319	.0343		
11	.0291	.0549	.0497	.0301	.0326		
12	.0291	.0532	.0737	.0283	.0309		
13	.024	.039	.0532	.0585	.0532		
14	.0566	.0461	.0532	.0567	.0532		
15	.06	.0549	.0309	.0549	.0532		
16	.0583	.0638	.0549			.0142	
17		.0656	.0583	.0549	.0549	.0142	
18		.0549	.0514		.0532	.0142	
19	.0291	.023	.0566	.0163	.0137	.0213	
20	.0549	.0266	.0206	.0217	.0206	.0248	
21	.0566	.0213	.0171		.0171	.0213	
22	.0154	.0195	.0154	.0163	.0154	.0213	
23	.0137	.0177	.0137	.0145	.0137	.0177	
24	.0137	.012	.0159	.012	.0124	.06	.0478
Max	**.06**	**.0656**	**.0737**	**.0585**	**.0549**	**.0926**	**.0868**
Min	**.0137**	**.0103**	**.0137**	**.012**	**.0124**	**.0142**	**.0154**
Avg	**.0319**	**.0340**	**.0349**	**.0282**	**.0297**	**.0503**	**.0499**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154020 / shirur taj.
Feeder No / Name : 202 / shirur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0223	.0223	.0248	.024	.0266	.024	.0283
2	.0223	.024	.0266	.024	.0266	.0257	.0283
3	.024	.0257	.0266	.0257	.0283	.0274	.0301
4	.024	.0274	.0283	.0274	.028		
5	.0291	.0274	.0283	.0326	.0298		
6	.0326	.0343	.0354	.0377	.0316		
7	.036	.036	.0408	.0412	.0399		
8	.036	.0291	.0461		.0429		
9	.0309	.036	.0412	.0394	.0394		
10						.0372	.036
11						.0408	
12						.0425	.0377
13						.039	
14					.024	.039	
15					.0274	.0354	
16	.0394	.0354	.0343		.0274	.039	
17	.036	.0354	.0377	.0291	.0291	.0372	
18	.036	.0354	.036	.0362	.0274	.0266	
19	.0412	.039	.0394	.0416	.0326	.0372	
20	.0412	.0408	.0394	.0416	.036	.0372	
21	.0377	.0408	.036	.038	.036	.0354	
22	.036	.0372	.0343	.0362	.0326	.0354	
23	.0343	.0319	.0309	.0326	.0309	.0319	
24	.0206		.036	.0223	.0248	.0274	.0275
Max	**.0412**	**.0408**	**.0461**	**.0416**	**.0429**	**.0425**	**.0377**
Min	**.0206**	**.0223**	**.0248**	**.0223**	**.024**	**.024**	**.0275**
Avg	**.0322**	**.0328**	**.0346**	**.0331**	**.0311**	**.0344**	**.0313**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154020 / shirur taj.
Feeder No / Name : 203 / belur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0274	.0326	.0337	.0343	.039	.0086	.0106
2	.0137	.0343	.0372	.036	.039	.0103	.0106
3	.0326	.036	.039	.0377	.0408	.0103	.0106
4	.036	.0377	.0408	.0394	.0421		
5	.0394	.0377	.0425	.0412	.0456		
6	.0429	.0394	.0408	.0412	.0473		
7	.0429	.0429	.0461	.0532	.0503		
8	.0463	.0463	.0408		.0514		
9	.0377	.0412	.0446	.0497	.0463		
10						.0337	.0274
11						.0478	
12						.0461	.036
13						.0461	
14						.0461	
15						.0443	
16	.0069	.0071			.0069	.0443	
17	.0086	.0089	.0086	.0086	.0069	.0443	
18	.0103	.0089	.0069	.0072	.0086	.0071	
19	.0137	.0124	.0137	.0145	.012	.0106	
20	.0137	.0159	.0154	.0163	.0137	.0124	
21	.0137	.0142	.0137	.0145	.012	.0124	
22	.0103	.0124	.0103	.0109	.0103	.0124	
23	.0086	.0106	.0154	.0109	.0103	.0106	
24	.024	.0309	.0337	.0326	.0354	.0086	.0089
Max	**.0463**	**.0463**	**.0461**	**.0532**	**.0514**	**.0478**	**.036**
Min	**.0069**	**.0071**	**.0069**	**.0072**	**.0069**	**.0071**	**.0089**
Avg	**.0238**	**.0261**	**.0284**	**.0280**	**.0288**	**.0253**	**.0174**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154037 / kolnoor
Feeder No / Name : 201 / kolnoor SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		1.0288		1.9814	1.0288	.6001	.6859
6	1.9814	1.7147		2.2862	2.0576		1.6289
8	2.5911			2.8959			
9	2.2862	3.0007			2.915		
10				.5144		1.8861	
11							3.0864
12				.3429			3.2579
13						3.0007	
15				.6001			
16	.5144	.3658			.5144	2.915	
18	.7716	.5144		.6859	.6001	.5144	
21	.8573	.7716		.9431	.5144	.7716	
23	.6859		.7621	.7716	.3429	.6001	
24		.6859		1.5242	.5144	.3429	.5144
Max	**2.5911**	**3.0007**	**.7621**	**2.8959**	**2.915**	**3.0007**	**3.2579**
Min	**.5144**	**.3658**	**.7621**	**.3429**	**.3429**	**.3429**	**.5144**
Avg	**1.3840**	**1.1546**	**.7621**	**1.2546**	**1.0610**	**1.3289**	**1.8347**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] **BU 5193**
Substation No/ Name :- 154037 / kolnoor
Feeder No / Name : 202 / sonwala **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.5144		.4572	.5144	1.2003	1.0288
6							1.6289
7						1.3717	
8							1.749
10		1.2193		1.3717			
11	1.6118	.6097					
12				1.7147	1.5242		
13		1.5242					
14	1.6118						
15		1.3717		1.7147			
16	1.4746	1.3717			1.3717	.3429	
18	.6859	.6001		1.6804	.4287	.6001	
19						.7716	
21	.8573	.6859		.9945	.5144	.6173	
23	.7716		.4572	.7716	.4287	.5144	
24		.6859		.4572	.6859	1.3717	.6001
Max	**1.6118**	**1.5242**	**.4572**	**1.7147**	**1.5242**	**1.3717**	**1.749**
Min	**.6859**	**.5144**	**.4572**	**.4572**	**.4287**	**.3429**	**.6001**
Avg	**1.1688**	**.9537**	**.4572**	**1.1453**	**.7811**	**.8488**	**1.2517**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154044 / wadhona bk.
Feeder No / Name : 201 / wadhona SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	04-APR-17
HR	Load (MW)	Load (MW)
4	.0655	
6	.6706	
8	.6401	.7716
24	.061	.6859
Max	.6706	.7716
Min	.061	.6859
Avg	.3593	.7288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154044 / wadhona bk.
Feeder No / Name : 202 / ekurka SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	04-APR-17
HR	Load (MW)	Load (MW)
2	.0671	
4	.0762	
6	.064	
8	.6554	.6859
24	.0594	.7716
Max	.6554	.7716
Min	.0594	.6859
Avg	.1844	.7288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154044 / wadhona bk.
Feeder No / Name : 203 / gudsur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	04-APR-17
HR	Load (MW)	Load (MW)
4	.064	
6	.5792	
8	.6401	.7888
24	.0503	.7373
Max	**.6401**	**.7888**
Min	**.0503**	**.7373**
Avg	**.3334**	**.7631**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154044 / wadhona bk.
Feeder No / Name : 204 / wadhona w/w exp.feeder NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / INCOMING UTILITY

DATE	30-MAR-17	04-APR-17
HR	Load (MW)	Load (MW)
2	.0732	
4	.0381	
6	.061	
8	.6706	
9	.0678	
11		.1187
24	.0412	.0366
Max	**.6706**	**.1187**
Min	**.0381**	**.0366**
Avg	**.1587**	**.0777**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154044 / wadhona bk.
Feeder No / Name : 205 / 11 KV SUKNI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17	04-APR-17
HR	Load (MW)	Load (MW)
2	.072	
4	.041	
6	.6097	
8	.7621	
24	.04	.6859
Max	.7621	.6859
Min	.04	.6859
Avg	.3050	.6859

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] **BU 5193**
Substation No/ Name :- 154079 / kumtha
Feeder No / Name : 201 / kumtha **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0073	.8215	.0057	.009	.0075	.0198	.0213
2	.0091	.9431	.0075	.0091	.0075	.0198	.0211
3	.009	.9997	.0075	.0112	.0057	.0213	.0229
4			.0094	.0148	.0075	.0226	.0227
5			.0094	.011	.0075	.0241	.0256
6			.0113	.0112	.0094	.0267	.0324
7			.0112		.0093	.0282	
8			.0113		.0182	.0253	
9			.0577	.0308	.0274	1.1763	
10	.0502	.0534		.0384	.0381	.7655	
11	.0672	.0594	.0458	.038	.0324		
12	.0632		.048	.038			
13	.0615	.0396	.0437	.038	.0331		
14	.0599		.0426		.0351		
15	.0623		.0442	.0389	.0372	.7282	
16	.0599	.0381	.0405	.0368	.0376	.8215	
17	.0615	.0244	.0427	.0176	.0259	.0551	
18	.7842	.0259	.0271	.0215	.0229	.0524	
19	1.1389	.0259	.0254	.0227	.0259	.0508	
20	1.4003	.0259	.0213	.0246	.0274	.0502	
21	1.094	.0229		.0227		.0508	
22	.9896	.0213		.0268		.0486	
23	.9335	.0198		.0243	.0213	.0464	.041
24	.0068	.8589	1.9509	.0073	.0235	.0197	.0453
Max	**1.4003**	**.9997**	**1.9509**	**.0389**	**.0381**	**1.1763**	**.0453**
Min	**.0068**	**.0198**	**.0057**	**.0073**	**.0057**	**.0197**	**.0211**
Avg	**.3810**	**.2653**	**.1232**	**.0235**	**.0219**	**.2027**	**.0290**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154079 / kumtha
Feeder No / Name : 202 / chimachi wadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0268	.034	.0331	.0279	.0168	.0075	.9896
2	.0275	.036	.0335	.0332	.0168	.0094	.9335
3	.0332	.0377	.0366	.0577	.018	.0113	1.2637
4	.0344	.0389	.0381	.0442	.0246		
5	.0373	.0426	.0427	.0437	.0308		
6	.034	.0518	.0512	.0407	.0308		
7	.0386		.0602		.0339		
8	.0441	.0678	.0587				
9	.0424					.0623	
10						.0648	
11						.0518	
12						.0639	
13					.0461	.0606	
14					.0446	.0524	
15			.0055		.0461	.0524	
16		.0056	.0055		.0075	.0492	
17		.0056	.0075		.0075		
18		.0075	.0074		.0075	.7468	
19		.0131	.0072	.0074	.0113	1.358	
20	1.7924	.0168	.0093	.0094	.017	1.8484	
21	1.5497	.0132		.0113		1.4377	
22	1.3121	.0113		.0094		1.2883	
23	1.1763	.0094		.0075	.0094	1.0269	.0112
24	.0266	.0344	.0093	.0254	.0075	.0094	.9709
Max	**1.7924**	**.0678**	**.0602**	**.0577**	**.0461**	**1.8484**	**1.2637**
Min	**.0266**	**.0056**	**.0055**	**.0074**	**.0075**	**.0075**	**.0112**
Avg	**.4411**	**.0266**	**.0271**	**.0265**	**.0221**	**.4556**	**.8338**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154082 / Hadolti
Feeder No / Name : 201 / hadolti SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	.5087	.6535		.5201	.7468	.7011
2	.5201	.5087	.5601	.6135	.5201	.7468	.7011
3	.5144	.5087	.5601	.6135	.5201	.8402	.7011
4						.9335	.8573
5						1.1203	1.0288
6						1.2136	1.2003
7						1.307	1.1603
8						1.4003	1.2431
9			.6001			1.2136	1.1603
10	1.4003	1.2717	.9945	1.1145	1.1203		
11	1.4937	1.4413	1.2431	1.2003	1.4003		
12	1.4937	1.4413	1.2431	1.2717	1.4937		
13	1.4937	1.4937	1.3413	1.2717	1.4937		
14	1.4937	1.4003	1.2574	1.1869	1.4937		
15	1.4937	1.4003	1.1736	1.1869	1.3565		
16	1.4937	1.1869	1.2574	1.1869	1.4003	.503	
17	1.4937	1.307	1.286	1.1869	1.4003	.503	
18	.4239		.5258	.3734	.3391	.5144	
19	.5087	.5935		.5258	.5935	.7011	
20	.6783	.6783	.7011	.6935	.6783	.8764	
21	.6783	.6783	.7011	.6935	.6783		
22	.5935	.6535	.6135	.6135	.6783	.7011	
23	.5087	.6535	.6135	.5258	.5087	.6135	.7468
24	.5258	.5087	.6535	.6135	.5201	.6535	.7011
Max	**1.4937**	**1.4937**	**1.3413**	**1.2717**	**1.4937**	**1.4003**	**1.2431**
Min	**.4239**	**.5087**	**.5258**	**.3734**	**.3391**	**.503**	**.7011**
Avg	**.9627**	**.9550**	**.8877**	**.8748**	**.9286**	**.8581**	**.9274**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] **BU 5193**
Substation No/ Name :- 154082 / Hadolti
Feeder No / Name : 202 / jagalpur **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.3391	.3734	.3506	.3467	.5601	.7011
2	.3467	.3391	.3734	.3506	.3467	.6535	.7011
3	.3429	.3391	.3734	.3467	.3467	.6535	.7011
4						.7468	.6859
5						.9335	.8573
6						1.0269	1.2003
7						1.1203	1.1603
8						1.1203	1.1603
9				.4191		1.1203	.663
10	.8402		.663		1.1203		
11		.5087	1.1603	1.2003	1.4003		
12	.5601	1.1022	1.1603	1.2717	1.307		
13	1.4003	1.1203	1.2574	1.286	1.307		
14	1.4937	1.1203		1.2717	1.307		
15	1.4937	1.307	1.1736	1.2717	1.2003		
16	1.4937	1.1869	1.1736	1.1869	1.307	.3353	
17	1.4937	1.2136	1.2003	1.1869	1.307		
18	.3391		.3506	.2801	.2543	.3429	
19	.4239	.8478		.3506	.4239	.4382	
20	.4239	.4239	.4382	.4334	.4239	.5258	
21	.4239	.4239	.4382	.4334	.4239	.5258	
22	.3391	.4668	.3506	.3506	.3391	.4382	
23	.3391	.4668	.3506	.3506	.3391	.4382	.4668
24	.3506	.3391	.4668	.3506	.3467	.4668	.7011
Max	**1.4937**	**1.307**	**1.2574**	**1.286**	**1.4003**	**1.1203**	**1.2003**
Min	**.3391**	**.3391**	**.3506**	**.2801**	**.2543**	**.3353**	**.4668**
Avg	**.7324**	**.7215**	**.7065**	**.7051**	**.7693**	**.6733**	**.8180**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] **BU 5193**
Substation No/ Name :- 154082 / Hadolti
Feeder No / Name : 203 / walsangi **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.6535	.6535	.8764	.6935	.3391	.4382
2	.3467		.6535	.8764	.7802	.3391	.4382
3	.3429	.6535	.7468	.8669	.8669	.3391	.4382
4	.3429	.9335	.8402	.8669	.8573		
5	.4287	1.0269	.9335	.8573	1.0288		
6	.5087	1.1203	1.1203	1.0402	.8478		
7	.5935	1.4937	1.4003	1.286	1.1869		
8		1.4937	1.4003	1.4251	1.1145		
9	1.2717	1.307	1.1869	1.4251			
10	1.307	1.1869					1.587
11	1.307					1.1603	1.587
12	1.307					1.4251	1.4937
13						1.4251	1.307
14						1.4251	
15						1.1603	
16	.2543	.2801	.2515	.1696	.2543		
17	.2543	.2543	.3429	.2543	.2543		
18	.3391		.3506	.2801	.3391	1.2003	
19	.4239	.4239		.3506		.4382	
20	.4239	.4239	.4382	.4334	.4239	.5258	
21	.3391	.4239	.4382	.4334	.3391	.5258	
22	.3391	.4668	.3506	.3506	.3391	.4382	
23	.3391	.3734	.3506	.3506	.3391	.4382	.4668
24		.5601	.3734	.7011	.4239	.3391	.4382
Max	**1.307**	**1.4937**	**1.4003**	**1.4251**	**1.1869**	**1.4251**	**1.587**
Min	**.2543**	**.2543**	**.2515**	**.1696**	**.2543**	**.3391**	**.4382**
Avg	**.5692**	**.7691**	**.6960**	**.7136**	**.6305**	**.7679**	**.9105**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154088 / Jalkot
Feeder No / Name : 201 / jalkot GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316		.724	.9431	.7468	.924	.9431
2	.724		.724	.9431	.823	.8954	.9431
3	.6935		.724	.9431	.823	.8954	
4	.6935		.6935	.9431	.6706	.905	.9431
5	.6935		.6935	.9431	.924	.8954	
6	.6935		.7545	.9431	.924	.9745	.9431
9	.8059		.7545	.9431	.7459	.8954	.7545
10	.7545		.9431	.7459	.7459	.8954	
11	.6706	.7545	.9431	.924	.7888	.8954	
12	.8145	.724	.9431	.9145	.8764	.8954	
13	.7888	.8145	.9431	.7545	.8764	.9431	
14	.7888	.8145	.9431	.8316	.7973	.9431	
15	.7888	.8145	.9431	.6706	.7973	.9431	
16	.7888	.724	.9431	.6706	.7888	.9431	
17	.8859	.724	.9431	.6706	.7888	.9431	
18	.9335	.7545	.9431	.7459	.8488	.9431	
19	1.0269	.9431	.9431	.7459	.9431	.9431	
20	1.0269	.9431	.9431	.6706	1.0374	.9431	
21	.9431	.9431	.9431	.8145	1.0374	.9431	
22	.9431	.9431	.9431	.6706	1.0374	.9431	
23	.9431	.9431	.9431	.6706	.9335	.9431	
24	.6706	.9335	.7545	.9431	.663	.9335	.9431
Max	**1.0269**	**.9431**	**.9431**	**.9431**	**1.0374**	**.9745**	**.9431**
Min	**.6706**	**.724**	**.6935**	**.6706**	**.663**	**.8954**	**.7545**
Avg	**.8092**	**.8410**	**.8648**	**.8202**	**.8463**	**.9263**	**.9117**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] **BU 5193**
Substation No/ Name :- 154088 / Jalkot
Feeder No / Name : 202 / kunki **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2686		.1677	.2801	.1677	.4477	.543
2	.2629		.1677	.2801	.2486	.5258	.6135
3	.2629		.1677	.2801	.2486	.5144	.724
4						.6859	.6859
5						.8573	.7716
6						1.0174	
7						1.326	.8573
8						1.326	.8573
9						1.326	.6706
10	.2486		.8383	.4668	.3696		
11	.4525	.5801	.8383	.8764	1.0288		
12	.6468	.7459	.8383	.7888	1.3565		
13	1.0288	.8383	.8383	.8573	1.326		
14	.8573	.8383	.8383	1.0059	1.1736		
15	.8573	.8383	.8383	1.0517	1.1736		
16	.8573	.6706	.8097	1.0517	1.1736	.1658	
17	.8573	.6706	.8383	.9945	1.1736	.2486	
18	.1886	.1677	.1867	.1677	.1848	.2486	
19	.2829	.2515	.2801	.1677	.2801	.2486	
20	.2829	.2515	.2801	.1677	.2801	.2486	
21	.2801	.1677	.2801	.2429	.2801	.2515	
22	.2829	.1677	.2801	.1848	.2801	.2515	
23	.2829	.1677	.2801	.1867	.2801	.2515	
24	.1677	.2829	.1677	.2801	.1677	.2686	.3506
Max	**1.0288**	**.8383**	**.8383**	**1.0517**	**1.3565**	**1.326**	**.8573**
Min	**.1677**	**.1677**	**.1677**	**.1677**	**.1677**	**.1658**	**.3506**
Avg	**.4649**	**.4742**	**.4964**	**.5184**	**.6218**	**.5672**	**.6749**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] **BU 5193**
Substation No/ Name :- 154088 / Jalkot
Feeder No / Name : 203 / ravankola **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5261		1.5089	1.6575	1.4784	.3734	.2515
2	1.6766		1.6766	1.6575	1.5384	.3696	
3	1.8233		1.989	1.6575	1.7604	.3658	.2515
4	1.8233		1.989	1.989	1.9062		
5	2.1548		2.2672	1.989	2.5206		
6	2.3472		2.5149	1.989	2.915		
7	2.4863		2.5149	1.989	2.9959		
8	2.4863		2.5149	.3315	2.9683		
9	2.4863		2.6825	.3315	2.6216		
10				.3315		1.1088	
11						1.848	
12						2.9569	
13						2.9569	
14						2.8959	
15						2.7149	
16	.1753	.2486	.1867	.2486	.1715	2.7149	
17	.1753	.2486	.1867	.1658	.1715	2.7149	
18	.1848	.2486	.1867	.2486	.2801	.2715	
19	.2772	.2515	.2515	.2486	.2801	.2829	
20	.3696	.2515	.2515	.1677	.3734	.2686	
21	.3734	.3239	.2801	.2572	.3734	.2515	
22	.3772	.3353	.2801	.2486	.3734	.2515	
23	.3734	.2515	.2801	.2486	.3696	.2515	
24	1.2003	.7011	.6706	.9945	.9717	.3734	.2515
Max	**2.4863**	**.7011**	**2.6825**	**1.989**	**2.9959**	**2.9569**	**.2515**
Min	**.1753**	**.2486**	**.1867**	**.1658**	**.1715**	**.2515**	**.2515**
Avg	**1.2398**	**.3178**	**1.2351**	**.8816**	**1.3372**	**1.2762**	**.2515**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154089 / Dongraj
Feeder No / Name : 202 / sandol SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7147		
8		2.1491		
15			2.2862	2.1338
16	.1715	.1715		
23				.1715
24			.1524	
Max	**.1715**	**2.1491**	**2.2862**	**2.1338**
Min	**.1715**	**.1715**	**.1524**	**.1715**
Avg	**.1715**	**1.3451**	**1.2193**	**1.1527**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
SHIRUR (R) S/DN[434] BU 5193
Substation No/ Name :- 154089 / Dongraj
Feeder No / Name : 203 / jaybhachi wadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429		2.4006
4	2.6578			
8			2.4006	2.572
16		2.6578		
23		2.7435		
24			.8573	
Max	**2.6578**	**2.7435**	**2.4006**	**2.572**
Min	**2.6578**	**.3429**	**.8573**	**2.4006**
Avg	**2.6578**	**1.9147**	**1.6290**	**2.4863**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154042 / 33/11 KV Udgir
Feeder No / Name : 201 / 11 KV TOWN SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3904	1.3904	1.4074	1.4243	1.358	1.3413	1.4582
2	1.3565	1.3904	1.4074	1.3413	1.3413	1.3077	1.4243
3	1.3565	1.4243	1.3565	1.3413	1.3413	1.3077	1.4083
4	1.3904	1.4243	1.4083	1.4419		1.3748	1.5089
5	1.4243	1.4243	1.4083	1.5089	1.5261	1.4419	1.4251
6	1.4243	1.4582	1.5089	1.543	1.56	1.4754	1.4752
7	1.5939	1.5261	1.7101	1.543	1.543	1.56	1.5089
8	1.56	1.56	1.6933	1.56	1.56	1.5769	1.6766
9	1.5089	1.6933	1.7101	1.56	1.5261	1.56	1.5091
10	1.4083	1.643	1.7436	1.4922	1.4922	1.4922	1.56
11	1.4083	1.6095	1.6766	1.4922	1.4582	1.4243	1.4922
12	1.4251	1.5089	1.6095	1.4582	1.3904	1.4243	1.4922
13	1.3916	1.4754	1.5592	1.4243	1.3735	1.4243	1.5261
14	1.4083	1.4413	1.3413	1.3904	1.3565	1.3904	1.5091
15	1.4419	1.4243	.2012	1.4243	1.3565	1.4243	1.4413
16	1.358	1.4243	1.3565	1.4582	1.3395	1.3904	
17	1.3245	1.2378	1.3904	1.3735	1.3395	1.3735	
18	1.4586	1.4922	1.5091	1.4582	1.4922	1.4582	
19	1.6766	1.9161	1.933	1.8652	1.95	1.7974	
20	1.9113	1.9161	2.0008	1.95	1.8821	1.8652	
21	1.8991	1.8652	1.8143	1.8482	1.8313	1.8143	
22	1.7465	1.7465	1.7465		1.7635		
23	1.5939						
24	1.4922	1.4922	1.5261	1.4922	1.4754	1.4243	1.543
Max	**1.9113**	**1.9161**	**2.0008**	**1.95**	**1.95**	**1.8652**	**1.6766**
Min	**1.3245**	**1.2378**	**.2012**	**1.3413**	**1.3395**	**1.3077**	**1.4083**
Avg	**1.4979**	**1.5428**	**1.5225**	**1.5178**	**1.5117**	**1.4840**	**1.4974**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154042 / 33/11 KV Udgir
Feeder No / Name : 202 / 11 KV NAGARPALIKA(Nalgir) SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.0848	.1017	.1006	.1174	.1174	.1187
2	.1017	.0848	.1017	.1006	.0838	.1006	.1017
3	.1017	.0848	.0848	.1006	.0838	.1006	.1006
4	.1017	.1017	.0838	.1174		.1174	.1341
5	.1017	.1017	.1006	.1341	.1017	.1174	.1341
6	.1017	.1017	.1006	.1357	.1017	.1174	.1017
7	.1017	.1187	.1006	.1174	.0848	.1187	.1006
8	.0848	.1187	.1006	.1357	.1017	.1187	.1006
9	.1006	.1174	.1174	.1677	.1341	.1341	.1696
10	.1509	.1677	.1509	.2012	.1677	.1677	.2035
11	.1677	.1677	.1844	.2012	.1677	.1677	.2035
12	.2012	.1677	.2012	.2012	.1677	.1677	.2035
13	.2012	.1844	.2012	.2012	.1677	.1844	.2035
14	.2012	.1844	.2012	.2012	.1677	.1844	.2035
15	.2012	.1865	.2012	.2012	.1677	.1844	.1865
16	.1844	.2035	.2012	.2012	.1677	.1844	
17	.1844	.2035	.2035	.2012	.1677	.1844	
18	.1677	.1865	.2012	.1844	.1677	.1844	
19	.2012	.218	.2374	.218	.2204	.1865	
20	.2012	.2204	.2012	.2012	.218	.1844	
21	.1696	.1844	.2035	.1677	.1844	.1677	
22	.1526	.1526	.1509		.1677		
23	.1357						
24	.1017	.1017	.1357	.1341	.1341	.1357	.1357
Max	**.2012**	**.2204**	**.2374**	**.218**	**.2204**	**.1865**	**.2035**
Min	**.0848**	**.0848**	**.0838**	**.1006**	**.0838**	**.1006**	**.1006**
Avg	**.1466**	**.1497**	**.1551**	**.1648**	**.1474**	**.1512**	**.1501**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154042 / 33/11 KV Udgir
Feeder No / Name : 203 / 11 KV TELEPHONE Express NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.0848	.0678	.0671	.0671	.0678	.0678
2	.0848	.0848	.0678	.0671	.0671	.0671	.0678
3	.0848	.0848	.0678	.0671	.0671	.0671	.0838
4	.0848	.0848	.1006	.0838		.0838	.0838
5	.0848	.0848	.1006	.0838	.0848	.0838	.0838
6	.0848	.0848	.0838	.0848	.0848	.0838	.0848
7	.0848	.0848	.0671	.0848	.0678	.0838	.0848
8	.0838	.0848	.0671	.0848	.0848	.0678	.0838
9	.0838	.1006	.0838	.1341	.1341	.1341	.1017
10	.0838	.1006	.0838	.1509	.1341	.1509	.1357
11	.1006	.1509	.1677	.1509	.1677	.1509	.1526
12	.1509	.1677	.1677	.1509	.1677	.1509	.1526
13	.1696	.1677	.1844	.1509	.1677	.1509	.1526
14	.1677	.1677	.1844	.2012	.1677	.1844	.1526
15	.1677	.1677	.1509	.2012	.1006	.1844	.1696
16	.1844	.1844	.1844	.2012	.1174	.1006	
17	.1006	.1006	.1187	.1006	.1174	.1174	
18	.0838	.0838	.0838	.0838	.0838	.0838	
19	.0838	.0838	.0838	.0838	.0838	.0838	
20	.0838	.0838	.0838	.0838	.0838	.0838	
21	.0848	.0838	.0838	.1006	.0838	.0838	
22	.0848	.0848	.0838		.0838		
23	.0848						
24	.0848	.0848	.0678	.0838	.0838	.0848	.0848
Max	**.1844**	**.1844**	**.1844**	**.2012**	**.1677**	**.1844**	**.1696**
Min	**.0838**	**.0838**	**.0671**	**.0671**	**.0671**	**.0671**	**.0678**
Avg	**.1032**	**.1083**	**.1059**	**.1137**	**.1046**	**.1068**	**.1089**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154042 / 33/11 KV Udgir
Feeder No / Name : 204 / 11KV AMBEDKAR CHOWK SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8139	.8817	.8478	.8048	.7377		.7461
2	.8139	.9496	.8478	.8048	.7377	.6706	.6783
3	.8139	.9496	.9156	.8048	.7042	.6706	.6783
4	.8817	.9835	.9892	.9054		.8048	.8383
5	.8817	1.0174	1.073	.9724	.9156	.8718	.8383
6	.9835	1.0174	1.073	1.0059	1.0174	1.0227	.9496
7	1.1191	.9496	1.1233	1.0852	1.0852	1.1065	1.0174
8	1.1065	.8817	1.2071	1.0513	1.0852	1.1191	1.073
9	1.073	.9054	1.1568	1.0513	1.0513	1.0513	1.0513
10	1.0227	.9556	1.1065	1.0513	.9496	1.0174	1.0174
11	1.073	1.0059	1.1065	1.1191	1.0852	1.0174	1.0174
12	1.1401	1.0395	1.073	1.0852	1.0852	.9496	1.0513
13	1.1401	1.1022	1.0562	1.0174	1.1022	.8817	.9496
14	1.1065	1.1401	1.073	1.0174	1.1191	.9156	.9496
15	1.1233	1.1361	1.1065	1.0513	1.0682	.9496	.9835
16	1.073	1.1191	1.0852	1.1191	1.0852	.9665	
17	1.0898	1.1022	1.0513	1.0513	1.0852	.9835	
18	1.1401	1.1869	1.153	1.0174	1.2209	1.0174	
19	1.3077	1.5261	1.4922	1.4243	1.4413	1.2887	
20	1.4419	1.4413	1.4074	1.3226	1.4413	1.2548	
21	1.2209	1.2378	1.2209	1.17	1.2039	1.0852	
22	1.0852	1.1022	1.0852		1.0513		
23	.8478						
24	.8478	.8817	.8478	.8551	.788	.8309	.8309
Max	**1.4419**	**1.5261**	**1.4922**	**1.4243**	**1.4413**	**1.2887**	**1.073**
Min	**.8139**	**.8817**	**.8478**	**.8048**	**.7042**	**.6706**	**.6783**
Avg	**1.0478**	**1.0658**	**1.0912**	**1.0358**	**1.0482**	**.9750**	**.9169**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154053 / 33/11 KV LONI
Feeder No / Name : 201 / 11 KV SUGER FACTORY **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0543	.1079	.0739	.054	.1079	.0724
2	.0366	.0549	.1079	.0732	.054	.1079	.0724
3	.0362	.1097	.054	.0366	.054	.054	.0543
4	.0366	.1097	.054	.0362	.054	.054	.0543
5	.0366	.1097	.054	.037	.054	.054	.0543
6	.0724	.1097	.054	.0362	.054	.054	.0543
7	.0366	.0549	.054	.0366	.1079	.054	.0543
8	.0366	.0549	.054	.0366	.036	.054	.0543
9	.036	.0549	.054	.036	.054	.054	.0543
10	.036	.1086	.0543	.036	.054	.054	.0362
11	.036		.0543	.054	.036	.0366	
12	.036	.0362	.1086	.054	.036	.0366	
13	.054	.037	.1086	.054	.054	.0724	
14	.054	.0366	.0543	.054	.054	.0732	
15	.054	.037	.0543	.054	.036	.0362	
16	.054	.0732	.0543	.054	.036	.0739	
17	.0543	.1079	.0739	.1079	.054	.0724	
18	.0543	.1079	.037	.054	.054	.0366	
19	.0543	.1079	.0366	.054	.054	.0362	
20	.1086	.054	.0732	.054	.1079	.0739	
21	.1086	.1079	.037	.1079	.1079	.0732	
22	.1086	.0565	.0362	.1079	.054	.0724	.0739
23	.0543	.054	.0732	.1079	.1079	.0362	.0732
24	.0732	.0543	.1079	.0191	.054	.054	.0724
Max	**.1086**	**.1097**	**.1086**	**.1079**	**.1079**	**.1079**	**.0739**
Min	**.036**	**.0362**	**.0362**	**.0191**	**.036**	**.0362**	**.0362**
Avg	**.0558**	**.0736**	**.0649**	**.0573**	**.0592**	**.0597**	**.0600**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154053 / 33/11 KV LONI
Feeder No / Name : 202 / 11 KV TALWES SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.8573	.9488	.7964	.9488	.9488	.905
2	.7682	.7888	.8729	.8413	.9488	.9488	.905
3	.7964	.7888	.8349	.7964	.8539	.8539	.9145
4	.8413	.823	.9108	.7762	.8539	.8539	.924
5	.8048	.823	.9488	.8048	.9488	.9488	.9088
6	.8916	.9431	1.0437	.905	1.0437	1.0437	1.0288
7	1.086	1.1145	1.0437	1.086	1.1385	1.1385	1.1145
8	.9877	1.1145	1.1385	1.0974	1.1385	1.1385	1.1145
9	1.0247	1.0288	1.1385	1.0626	1.1385	1.0437	1.0288
10	.9867	.8573	.9431	.9488	1.0437	.9488	.8916
11	.9488		.8573		1.0437	.905	
12	.8539	.9145	.8573		.9488	.905	
13	.9488	.905	.8573		.9488	.924	
14	.9488	.905	.8573	1.0437	.9488	.924	
15	.9488	.9145	.8573	1.0437	.9488	.9145	
16	.9488	.8688	.8573	1.0437	.9488	.8326	
17	.8573	1.0437	.8326	1.0437	.9488	.8779	
18	.9431	1.1385	.9145	1.0437	.9488	.9145	
19	1.0288	1.1385	1.134	1.2334	1.1385	1.086	
20	1.0288	1.1385	1.086	1.1385	1.1385	1.0974	
21	1.0288	1.142	1.086	1.1385	1.1385	1.086	
22	.9431	1.0437	1.0974	1.1385	1.1385	1.0288	1.1706
23	.9431	1.0437	1.0136	1.1385	1.0437	.9431	1.086
24	.8413	.8573	.9679	.0191	1.0437	1.0437	.8573
Max	**1.086**	**1.142**	**1.1385**	**1.2334**	**1.1385**	**1.1385**	**1.1706**
Min	**.7682**	**.7888**	**.8326**	**.0191**	**.8539**	**.8326**	**.8573**
Avg	**.9240**	**.9649**	**.9625**	**.9590**	**1.0160**	**.9729**	**.9884**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154053 / 33/11 KV LONI
Feeder No / Name : 205 / 11KV MIDC **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.7167	.7196	.5658	.6628	.7196	.7545
2	.5281	.6413	.7196	.4904	.6439	.6818	.7167
3	.5228	.6036	.7575	.4904	.606	.6818	.7167
4	.5281	.6036	.8711	.5228	.606	.6818	.7545
5	.5658	.7545	1.0416	.6413	.7575	.7954	.8488
6	.8589	.9431	1.1363	1.0562	.9848	1.1363	.9431
7	1.0185	1.094	1.212	1.094	1.1741	1.2145	.9431
8	1.1317	1.1694	1.1741	1.1694	1.2499	1.2878	1.1317
9	1.2878	.9431	1.1363	1.1363	1.3256	1.0605	.9431
10	1.2878	1.226	1.2449	1.1741	1.3256	1.3635	1.226
11	1.2499		1.226	1.4771	1.4582	1.0185	
12	1.1741	1.2826	.9431	1.5529	.7575	1.0562	
13	1.0416	1.2826	1.0374	1.4203	.9469	1.1203	
14	.909	1.2449	1.0374	1.1363	.6628	1.1694	
15	1.1363	1.2323	1.1317	1.3256		1.2071	
16	.9469	1.358	1.1317	1.2499	1.515	1.3443	
17	1.0374	1.515	1.5089	1.3635	1.515	1.3203	
18	1.1317	1.5529	1.358	1.3635	1.4582	1.3203	
19	1.0374	1.4771	1.358	1.2878	1.3256	1.2449	
20	.9431	1.2499	1.2449	1.212	1.212	1.1317	
21	.8488	1.1741	1.0185	1.1363	.9469	1.0185	
22	.7922	1.0984	.8299	.8333		.8488	.679
23	.7922	.7575	.7922	.7575	.7575	.7356	.6722
24	.6036	.7545	.6818	.0191	.7575	.7575	.7545
Max	**1.2878**	**1.5529**	**1.5089**	**1.5529**	**1.515**	**1.3635**	**1.226**
Min	**.5228**	**.6036**	**.6818**	**.0191**	**.606**	**.6818**	**.6722**
Avg	**.9139**	**1.0728**	**1.0547**	**1.0198**	**1.0295**	**1.0382**	**.8526**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154053 / 33/11 KV LONI
Feeder No / Name : 206 / 11 KV LONI SPARE1 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	30-MAR-17
HR	Load (MW)
17	.2577
Max	.2577
Min	.2577
Avg	.2577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154053 / 33/11 KV LONI
Feeder No / Name : 207 / 11 KV LONI SPARE2 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1753	.1472	.1448	.184	.1472	.1753
2	.1791	.1753	.1472	.1463	.184	.1472	.1753
3	.181	.1753	.1472	.181	.184	.1472	.1753
4	.1829	.2804	.184	.1848	.184	.1472	.2103
5	.2149	.3506	.2577	.2195	.2577	.184	.2629
6	.2896	.3506	.4049	.2896	.3313	.2577	.3506
7	.4344	.4382	.4049	.4656	.4049	.3681	.4382
8	.4344	.4031	.4049	.3544	.4049	.4417	.4733
9	.4049	.3506	.4049	.3681	.4417	.3313	.3856
10	.3681	.3506	.3506	.4049	.4417	.4049	.3506
11	.2945		.2629	.3313	.4417	.3258	
12	.2577	.181	.1753	.2945	.184	.2534	
13	.2209	.181	.1753	.2577	.2209	.2149	
14	.2209	.181	.1753	.2209	.2577	.2172	
15	.2577	.1829	.2103	.2209	.2577	.2195	
16	.2577	.2534	.2103	.2945	.2577	.2507	
17	.3155	.2577	.2896	.2945	.2945	.3258	
18	.3506	.2577	.2896	.4049	.3681	.3544	
19	.4908	.2945	.3292	.3681	.3681	.3258	
20	.3155	.2945	.3189	.2945	.3313	.2835	
21	.3155	.2577		.2577	.2577	.1791	
22	.2804	.2273	.2896	.2209	.2209	.2103	.2507
23	.2804	.184	.181	.184	.184	.2103	.2172
24	.2534	.2454	.1472	.0191	.184	.1656	.2103
Max	**.4908**	**.4382**	**.4049**	**.4656**	**.4417**	**.4417**	**.4733**
Min	**.1791**	**.1753**	**.1472**	**.0191**	**.184**	**.1472**	**.1753**
Avg	**.2925**	**.2630**	**.2569**	**.2676**	**.2853**	**.2547**	**.2827**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154053 / 33/11 KV LONI
Feeder No / Name : 208 / VAISHALI AGRO EXPRESS FEEDER Feeder KV- 11 / OUTGOING **SHEDDABLE RURAL**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0366	.0364	.3696	.3457	.3639	.3292
2	.0366	.0366	.0364	.3658	.3639	.3639	.3475
3	.0362	.0366	.0364	.3258	.3639	.3639	.3292
4	.0362	.0366	.0364	.3292	.3639	.3457	.3475
5	.0366	.0366	.0364	.3292	.3457	.3457	.3475
6	.0362	.3109	.0364	.3326	.3457	.3457	.2561
7	.0362	.0366	.0364	.3189	.2911	.3639	.3292
8		.0366	.0364	.3292	.3457	.3275	.3475
9	.0364	.0366	.0368	.2911	.3275	.3093	.3292
10	.0364	.0366	.0366	.2911	.3275	.2911	.2926
11	.0364		.0366	.3639	.3275	.362	
12	.0364	.0362	.0366	.3639	.3093	.3292	
13	.0364	.0366	.0549	.3275	.3275	.2984	
14	.0364	.037	.0549	.3275	.3457	.3658	
15		.037	.1097	.3275	.3275	.3696	
16		.0366	.2561	.3457	.3275	.3658	
17	.0366	.0364	.2561	.3275	.3639	.362	
18	.0366	.0364	.2926	.3457	.3639	.3292	
19	.0366	.0364	.3258	.3457	.3639	.2896	
20	.0366	.0364	.3658	.3457	.3275	.2926	
21	.0366	.0368	.3658	.3457	.3457	.3292	
22	.0366	.0364	.362	.3275	.3275	.3109	.3292
23	.0366		.3658	.3457	.3457	.2926	.3258
24	.0366	.0362	.0364	.0191	.3457	.3457	.3475
Max	**.037**	**.3109**	**.3658**	**.3696**	**.3639**	**.3696**	**.3475**
Min	**.0362**	**.0362**	**.0364**	**.0191**	**.2911**	**.2896**	**.2561**
Avg	**.0365**	**.0490**	**.1368**	**.3225**	**.3404**	**.3360**	**.3275**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154053 / 33/11 KV LONI
Feeder No / Name : 403 / 33 KV O/G Wadhavana SHEDDABLE RURAL
Feeder KV- 33 / INCOMING

DATE	31-MAR-17
HR	Load (MW)
24	.0572
Max	.0572
Min	.0572
Avg	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154100 / 33/11 KV MAHADA
Feeder No / Name : 201 / 11KV BODHAN NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772		.3429	.3395	.3429	.4115
2	.3772	.3772		.3429	.3206	.3429	.4115
3	.3395	.3584		.3429	.3395	.3429	.3944
4	.3584	.3584		.3429	.3395	.3429	.3429
5	.3584	.3584		.3429	.3772	.3601	.3429
6	.415	.415		.3601	.4338	.3772	.3429
7	.4715	.4338		.3772	.4338	.4287	.3944
8	.4715	.3772		.3772	.3961	.4287	.4287
9	.3944	.4115	.3772	.4338	.4287	.4527	.4527
10	.3772	.3601	.3772	.4904	.4973	.4527	.4715
11	.3772	.4287	.9945	.4715	.3429	.4527	.4904
12	.3772	.4973	.4973	.4527	.3772	.4715	
13	.3772	.4287	.4973	.4527	.4115	.4527	
14	.3772	.4115	.4973	.4715	.4115	.415	
15	.4115	.3772	.4115	.5658	.4287	.4338	
16	.4115	.3772	.3772	.4458	.4458	.415	
17	.4458		.4801	.4115	.415	.3961	
18	.3944		.4115	.4115	.4715	.415	
19	.4458		.4801	.4801	.5281	.4904	
20	.4801		.4801	.4801	.5281	.4904	
21	.463		.4287	.4801	.4973		
22			.4287		.4801	.4458	
23			.4287		.9431	.4287	
24	.4715	.415		.3601	.3961	.3772	.4287
Max	**.4801**	**.4973**	**.9945**	**.5658**	**.9431**	**.4904**	**.4904**
Min	**.3395**	**.3584**	**.3772**	**.3429**	**.3206**	**.3429**	**.3429**
Avg	**.4079**	**.3978**	**.4778**	**.4198**	**.4410**	**.4155**	**.4094**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154100 / 33/11 KV MAHADA
Feeder No / Name : 202 / 11KV PIMPRI NAKA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0191
Max	.0191
Min	.0191
Avg	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154100 / 33/11 KV MAHADA
Feeder No / Name : 204 / 11 KV MAHADA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.1006		.0514	.1341	.0857	.12
2	.0671	.1174		.0514	.1174	.0857	.1029
3	.0838	.1174		.0686	.1341	.0857	.1029
4	.1006	.1341		.1029	.1341	.1029	.12
5	.1006	.1341		.1029	.1341	.1029	.12
6	.0838	.1174		.1029	.1509	.1029	.12
7	.0838	.0671		.1029	.1509	.1029	.0857
8	.0838	.0838		.1029	.1006	.1029	.0857
9	.0857	.1029	.0857	.1174	.12	.0838	.0671
10	.1029	.0686	.0857	.0838	.12	.0671	.0503
11	.12	.0686	.1029	.1006	.1029	.0838	.0503
12	.12	.1029	.1029	.1006	.1029	.1006	
13	.12	.0857	.1029	.1006	.12	.1174	
14	.12	.0857	.12	.0838	.1372	.1006	
15	.1029	.0857	.12	.0838	.1372	.1174	
16	.1029	.0857	.12	.0857	.1509	.0838	
17	.1372		.12	.1029	.1174	.1006	
18	.1029		.1372	.0857	.0838	.1006	
19	.0857		.1029	.1029	.0503	.0503	
20	.0686		.1029	.1029	.0503	.0335	
21	.0686		.1029	.1372	.0514		
22			.2572		.0686	.1029	
23			.12		.1029	.12	
24	.1174	.1006		.0514	.1341	.1029	.12
Max	**.1372**	**.1341**	**.2572**	**.1372**	**.1509**	**.12**	**.12**
Min	**.0671**	**.0671**	**.0857**	**.0514**	**.0503**	**.0335**	**.0503**
Avg	**.0974**	**.0975**	**.1189**	**.0921**	**.1128**	**.0929**	**.0954**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154100 / 33/11 KV MAHADA
Feeder No / Name : 205 / 11 KV VETERNARY COLLEGE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499	.5175		.4801	.5544	.4287	.3772
2	.4805	.499		.4801	.5175	.4287	.3429
3	.4251	.4805		.4801	.5359	.4115	.3429
4	.4435	.4805		.463	.5359	.4458	.3772
5	.4435	.4805		.4801	.6283	.463	.4115
6	.4805	.5175		.5144	.5359	.463	.463
7	.5359			.5144	.5729	.5487	.4973
8	.6099	.6468		.5487	.5729	.5658	.5658
9	.5658	.6173	.6859	.6838	.6001	.7023	.6653
10	.6344	.6516	.703	.6653	.6859	.7577	.7095
11	.6344	.5658	.6859	.6653	.6516	.6838	.7392
12	.6344	.6516	.6859	.6468	.6173	.7207	
13	.6173	.6344	.6859	.5175	.6173	.7023	
14	.6001	.6344	.6859	.5544	.6001	.7023	
15	.6516	.6344	.6516	.6653	.6859	.7207	
16	.6859	.6859	.6344	.6173	.703	.8131	
17	.6516		.583	.5658	.7207	.7577	
18	.6344		.6173	.583	.7392	.7392	
19	.6001		.6516	.6687	.7207	.7545	
20	.583		.6516	.6687	.6653	.7023	
21	.6173		.6173	.6173	.6344		
22			.583		.6001	.5144	
23			.5658		.583	.4801	
24	.5175	.5544		.5144	.5729	.5144	.4306
Max	**.6859**	**.6859**	**.703**	**.6838**	**.7392**	**.8131**	**.7392**
Min	**.4251**	**.4805**	**.5658**	**.463**	**.5175**	**.4115**	**.3429**
Avg	**.5703**	**.5783**	**.6459**	**.5725**	**.6188**	**.6096**	**.4935**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154100 / 33/11 KV MAHADA
Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.6401		.6173	.695	.6173	.6001
2	.6219	.583		.6001	.6584	.6001	.6001
3	.5853	.5853		.583	.6401	.583	.583
4	.567	.6219		.583	.6401	.6001	.5144
5	.5853	.6401		.6001	.695	.6001	.5144
6	.5853	.6219		.6344	.6401	.6001	.5487
7	.6036	.6001		.6344	.6401	.5487	.583
8	.6036	.6584		.6001	.6401	.5316	.5658
9	.5658	.6001	.6516	.6219	.6344	.6036	.6219
10	.703	.7545	.6687	.7133	.6173	.6767	.695
11	.703	.7545	.7716	.695	.7888	.7682	.7865
12	.7202	.8402	.823	.8596	.7716	.7682	
13	.7716	.8573	.823	.9328	.7716	.8413	
14	.8059	.8573	.823	.9145	.7716	.8779	
15	.823	.8573	.823	.8413	.7545	.8596	
16	.8573	.823	.823	.8745	.7202	.8779	
17	.7716		.7888	.8059	.8048	.8413	
18	.823		.8059	.7888	.8779	.823	
19	.9602		1.0288	.9945	1.0242	.9877	
20	.9945		.9945	.9945	1.0059	.9694	
21	.9259		.8916	.8402	.8573		
22			.8573		.823	.823	
23			.7716		.7545	.7545	
24	.6401	.6584		.6344	.7655	.6344	.6001
Max	**.9945**	**.8573**	**1.0288**	**.9945**	**1.0242**	**.9877**	**.7865**
Min	**.5658**	**.583**	**.6516**	**.583**	**.6173**	**.5316**	**.5144**
Avg	**.7200**	**.7031**	**.8230**	**.7438**	**.7497**	**.7299**	**.6011**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 154100 / 33/11 KV MAHADA
Feeder No / Name : 207 / 11KV EXPRESS RUDRANI HEALTHCAR Feeder KV- 11 / OUTGOING **SHEDDABLE RURAL**

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063	.1595		.1372	.1595	.1029	.12
2	.1063	.1417		.1372	.1417	.1029	.1029
3	.1063	.124		.1372	.1417	.1029	.1029
4	.1063	.1417		.12	.1595	.1029	.12
5	.1063	.1417		.12	.1949	.1029	.12
6	.2126	.1595		.12	.2126	.12	.12
7	.2303	.1949		.12	.1595	.0857	.12
8	.1417	.1063		.0857	.1063	.0857	.12
9	.0857	.0857	.0857	.1063	.0686	.0886	.1063
10	.0686	.0857	.0686	.1063	.0686	.1063	.0886
11	.0857	.0857	.0857	.1063	.1029	.1063	.124
12	.1029	.1029	.1029	.124	.1029	.124	
13	.1029	.1029	.1029	.1063	.1029	.1063	
14	.1029	.1372	.12	.1063	.12	.124	
15	.1029	.1372	.12	.124	.12	.124	
16	.12	.12	.12	.1543	.12	.124	
17	.1715		.1372	.1372	.1949	.1417	
18	.1372		.1372	.1372	.2126		
19	.12		.12	.12	.1463	.1595	
20	.12		.12	.0857		.1772	
21	.1029		.12	.1029	.1543		
22			.12		.1372	.1372	
23			.12		.1029	.1372	
24	.1595	.1772		.1372	.1772	.12	.1372
Max	**.2303**	**.1949**	**.1372**	**.1543**	**.2126**	**.1772**	**.1372**
Min	**.0686**	**.0857**	**.0686**	**.0857**	**.0686**	**.0857**	**.0886**
Avg	**.1227**	**.1296**	**.1120**	**.1196**	**.1394**	**.1174**	**.1152**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 157003 / 132 KV UDGIR
Feeder No / Name : 201 / 11 KV Bus Stand SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0191
Max	.0191
Min	.0191
Avg	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 157003 / 132 KV UDGIR
Feeder No / Name : 202 / 11 KV RAILWAY STATION SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-APR-17
HR	Load (MW)
24	.0191
Max	.0191
Min	.0191
Avg	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 157003 / 132 KV UDGIR
Feeder No / Name : 401 / 33 KV UDGIR SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	31-MAR-17	01-APR-17
HR	Load (MW)	Load (MW)
24	.1144	.0572
Max	.1144	.0572
Min	.1144	.0572
Avg	.1144	.0572

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR URBAN S/DN.[742] BU 4742
Substation No/ Name :- 157003 / 132 KV UDGIR
Feeder No / Name : 402 / 33 KV NALGIR **SHEDDABLE URBAN**
Feeder KV- 33 / INCOMING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.6358	6.7387		6.6358	7.0988	6.5329	6.3786
2	6.8416	6.7901		6.6358	6.893	6.5329	6.3786
3	6.6873	6.9445		6.6873	7.2017	6.5844	6.3786
4	5.0412	5.1955		6.7387	6.6873	6.7901	6.6358
5	6.3786	7.1502		8.1276	8.0247	6.893	6.8416
6	7.4589	8.2819		9.0021	8.8992	6.8416	6.893
7	8.8992	9.7222		9.105	9.465	7.3045	7.8189
8	9.1564	8.6934		9.0021	9.5165	8.2819	8.179
9	8.1276	9.4136	6.1214	9.6708	9.5679	7.9218	7.356
10	7.6646	6.893	7.3045	7.6646	7.0473	8.2819	7.9218
11	7.7161	6.0185	8.642	8.0247	8.0761	10.0309	10.1852
12	7.8704	7.4074	8.8477	8.2819	8.0761	9.7222	
13	7.9733	7.0988	9.0021	8.3848	7.9733	9.6708	
14	8.0247	6.8416	9.0021	7.0988	7.7161	9.2078	
15	8.4877	8.3848	9.0021	8.179	7.9218	9.5165	
16	8.5391	8.3848	8.7449	9.0535	7.9733	10.1338	
17	9.2078		9.0021	9.2593	9.105	10.1338	
18	3.7037		3.858	5.2469	3.9095	4.0638	
19	4.0638		4.6811	5.4527	4.7325	4.8354	
20	4.9897		4.6296	5.2469	5.2984	5.2469	
21	4.6811		4.5268	4.9897	4.8868		
22			4.1152		4.6296	1.1317	
23			3.8066		3.9609	4.0124	
24	6.4815	6.6873		6.6416	6.9959	6.4815	6.4815
Max	**9.2078**	**9.7222**	**9.0021**	**9.6708**	**9.5679**	**10.1338**	**10.1852**
Min	**3.7037**	**5.1955**	**3.8066**	**4.9897**	**3.9095**	**1.1317**	**6.3786**
Avg	**7.0286**	**7.4498**	**6.7524**	**7.5059**	**7.1524**	**7.2240**	**7.2874**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] **BU 5142**
Substation No/ Name :- 154025 / 33 KV NALGIR
Feeder No / Name : 201 / 11 KV ATNOOR **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.788		.7712		.6874	.3353	.3856
2	.7712		.8048		.7545	.3521	.3856
3	.7712		.788		.8383	.3688	.4527
4	.6036		.6539		.8383		
5	.8383		.8048		1.0059		
6	1.1401		1.1401		1.073		
7	1.2742		1.3245		1.2146		
8	1.2574		1.3077		1.2574		
9	1.0898		1.3413		1.3413		
10						1.2574	1.0562
11						1.5592	1.3748
12						1.6766	
13						1.6095	
14						1.5927	
15						1.5089	
16		.285		.218	.3185	1.4754	
17		.3018		.3018	.3353	1.5089	
18		.3018		.3353	.3353	.2347	
19		.4694		.503	.503	.503	
20		.5868		.57	.57	.57	
21		.503		.503	.5365	.5365	
22		.4359		.4359	.4694	.503	
23		.3521		.3688	.4024	.4527	
24	.7209		.6371		.6874	.3521	.3521
Max	**1.2742**	**.5868**	**1.3413**	**.57**	**1.3413**	**1.6766**	**1.3748**
Min	**.6036**	**.285**	**.6371**	**.218**	**.3185**	**.2347**	**.3521**
Avg	**.9255**	**.4045**	**.9573**	**.4045**	**.7316**	**.9109**	**.6678**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154025 / 33 KV NALGIR
Feeder No / Name : 202 / 11 KV AWALKONDA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5533		.4694		.503
2	.5344		.503		.503
3	.6203		.503		.5365
10			1.2071	1.1904	.8215
11			1.358	1.5257	1.3077
12		1.3916		1.5089	1.4251
13		1.3748		1.5089	1.4419
14		1.3916		1.5089	1.4251
15				1.1401	
16		1.4586	1.6095	1.4586	
17		1.6095		1.5592	
18		.3353		.2683	
19		.6036		.4862	
20		.7712		.788	
21		.7545		.7209	
22		.6706		.6203	
23		.503		.57	
24	.5365		.503		.503
Max	**.6203**	**1.6095**	**1.6095**	**1.5592**	**1.4419**
Min	**.5344**	**.3353**	**.4694**	**.2683**	**.503**
Avg	**.5611**	**.9877**	**.879**	**1.0610**	**.9408**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL
Feeder No / Name : 201 / 11 KV KARADKHEL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6783	.763	.6135	.6001	.2543	.3429
2	.6859	.763	.8383	.7011	.6706	.2543	.3429
3	.8573	.8478	1.0174	.8764	.8669	.2543	.3429
4	.9431	1.0174	1.0174	.964	1.0402		
5	.9431	1.0174	1.0059	1.0517	1.0402		
6	1.286	1.1022		1.2269	1.2136		
7	1.3717	1.3565	1.1869	1.4022	1.3003		
8	1.3717	1.3565	1.3413	1.3146	1.387		
9	1.3717		1.3413	1.2269	1.3565		
10						.8573	1.0517
11						1.286	1.4022
12						1.286	1.4022
13						1.286	1.3146
14						1.2003	
15						1.286	
16	.2543	.1696	.2629	.1696	.1696	1.286	
17	.1696	.1696	.2629	.1696	.1696	1.286	
18	.2543	.2543	.2629		.2543	.2572	
19		.3506	.4382		.3391	.4287	
20	.3391	.3391	.4382	.3391	.4239	.4287	
21	.3391	.3391	.4382	.3391	.4239	.4287	
22	.3429	.3391	.4382	.2543	.3391		
23	.3391	.3391	.3506	.2543	.3391	.3429	.3506
24	.5144	.6783	.5087	.503	.5087	.2543	.3429
Max	**1.3717**	**1.3565**	**1.3413**	**1.4022**	**1.387**	**1.286**	**1.4022**
Min	**.1696**	**.1696**	**.2629**	**.1696**	**.1696**	**.2543**	**.3429**
Avg	**.7049**	**.6540**	**.7007**	**.7129**	**.6913**	**.7457**	**.7659**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] **BU 5142**
Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL
Feeder No / Name : 202 / 11 KV HER **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3467	.3506	.3544	.3506	.5201	.7011
2	.4382	.3467	.3544	.443	.3506	.6068	.7888
3		.3467	.3467	.5316	.5258	.6068	.7888
4						.6935	.7888
5						.6935	.964
6						.9536	1.0517
7						1.0402	
8						1.0402	1.1393
9						.9536	1.1393
10	.8669	.7011	.7011	.7011	.7802		
11	.9536	.8764	1.0631	.964	1.0402		
12	1.0402	.8859	1.0631	1.0517	1.0288		
13	.9536	.964	1.0631	.964	.9536		
14	.8669	.8859	.9745		.9536		
15	.8669	.8764	.8859		.8669		
16	.8669	.7888	1.1517	.7888	.9536	.2629	
17	.9536	.7888	1.0631	.7888	.9536	.3506	
18	.2601	.3506	.3544		.2601	.2629	
19	.4334	.5258	.5316		.4334	.5258	
20	.5201	.5258	.6201	.4382	.5201	.6135	
21	.5201	.5258	.5316	.5316	.5201	.5258	.5316
22	.5201	.4382		.5258	.4334		.443
23	.3467	.4382	.443	.4382	.4334	.3506	.7087
24	.443	.3467	.3506	.3544	.3506	.5201	.5258
Max	**1.0402**	**.964**	**1.1517**	**1.0517**	**1.0402**	**1.0402**	**1.1393**
Min	**.2601**	**.3467**	**.3467**	**.3544**	**.2601**	**.2629**	**.443**
Avg	**.6589**	**.6088**	**.6970**	**.6340**	**.6505**	**.6189**	**.7976**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] **BU 5142**
Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL
Feeder No / Name : 203 / 11 KV DIGRESS **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.7087	.7802
2						.7973	.8669
3						.8859	.9536
4						1.0631	.9536
5						.8859	1.0402
6						.9745	1.387
7						1.3289	
8						1.5947	1.647
9						1.4175	1.387
10	1.1517	1.0402	1.1269	1.0402	1.2403		
11	1.4175	1.3717	1.5604	1.286	1.4175		
12	1.4175		1.5604		1.4175		
13	1.4175		1.3003	1.286	1.4175		
14	.9745		1.3003		1.2403		
15	1.0631		1.3003		1.2403		
16	1.2403	1.2136	1.4737	1.0402	1.3289		
17	1.3289		1.5604		1.4175		
19			.5316				
24						.7087	.6935
Max	**1.4175**	**1.3717**	**1.5604**	**1.286**	**1.4175**	**1.5947**	**1.647**
Min	**.9745**	**1.0402**	**.5316**	**1.0402**	**1.2403**	**.7087**	**.6935**
Avg	**1.2514**	**1.2085**	**1.3016**	**1.1631**	**1.3400**	**1.0365**	**1.0788**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] **BU 5142**
Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN
Feeder No / Name : 201 / 11 KV DEVARJAN (AG) **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.8962	.7209
2						.8916	.7956
3						.8916	.8288
4						.823	.8421
5						1.0288	1.0814
6						1.1145	1.1568
7						1.286	1.3441
8						1.3717	1.3108
9							1.2323
10	.884		1.0159	.9503			
11	1.286		1.2041	1.1584	1.1431		
12	1.5432	1.3279		1.3108	1.286		
13	1.4575		1.1584		1.3213		
14	1.4575	.9998	1.3245		1.307		
15	1.3717		1.2498	1.2498	1.3937		
16	1.4575	1.4632	1.2346	1.2651	1.4632		
17			1.4251	1.2803			
24				.9503		.6802	
Max	**1.5432**	**1.4632**	**1.4251**	**1.3108**	**1.4632**	**1.3717**	**1.3441**
Min	**.884**	**.9998**	**1.0159**	**.9503**	**1.1431**	**.6802**	**.7209**
Avg	**1.3511**	**1.2636**	**1.2303**	**1.1664**	**1.3191**	**.9982**	**1.0348**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN
Feeder No / Name : 202 / 11 KV SHEKAPUR (AG) FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3565	1.2289	1.3032	1.2944	1.6004		
2	1.3108	1.1469	1.358	1.3435	1.6766		
3	1.5089	1.5432	1.4586		1.9204		
4	1.4632		1.5565	1.7532	1.829		
5	1.4632	1.9281	1.7124	1.9662	1.9814		
6	2.4387	2.1091	1.8724	2.0317	2.0576		
7	2.3777	2.6787	2.3278	2.4577	2.21		
8	2.2862	2.3167	2.1338		2.332		
9	1.8747		2.2862	2.3594	2.1338		
10						2.0645	2.0809
13						2.5194	
14						2.3537	
15						2.3371	
16						2.652	
17						2.5857	
24	.9907	1.1431	1.2452		1.0669		
Max	**2.4387**	**2.6787**	**2.3278**	**2.4577**	**2.332**	**2.652**	**2.0809**
Min	**.9907**	**1.1431**	**1.2452**	**1.2944**	**1.0669**	**2.0645**	**2.0809**
Avg	**1.7071**	**1.7618**	**1.7254**	**1.8866**	**1.8808**	**2.4187**	**2.0809**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN
Feeder No / Name : 205 / 11 KV DEVARJAN GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1867	.2054	.1753	.1524	.1715	.1753
2	.1219	.2054	.2054		.1524	.1715	.1772
3	.1372	.2241	.2241		.1524		.2126
4	.2286	.2374	.2587		.1829	.2614	.2454
5	.3048	.2987	.3658		.2439	.3361	.3189
6	.381	.5281	.5487		.3048		.5083
7	.4572	.5601			.3658		.4961
8	.3201		.4066		.3048		.4607
9	.2743		.3547	.3155			.2835
10	.1677		.2454	.2103	.2439	.2126	.2481
11	.1867		.1753	.1524	.2134		
12	.168			.1524	.2054		
13	.112		.1052		.168		
14		.0943	.1227		.1494	.1402	
15	.112			.1372	.168	.1402	
16	.0373	.1494	.1052	.1372	.1867	.1402	
17			.1402	.1524	.1867		
18	.2054	.2241		.2134	.2054		
19	.2241	.2957			.2614		
20	.2614		.2804	.2439	.2987		
21	.2801	.2957	.3155	.2439	.2241		
22	.2241			.2134	.2241		
23	.1867	.2241			.2054		
24	.1524	.1715	.2103		.1219	.1753	
Max	**.4572**	**.5601**	**.5487**	**.3155**	**.3658**	**.3361**	**.5083**
Min	**.0373**	**.0943**	**.1052**	**.1372**	**.1219**	**.1402**	**.1753**
Avg	**.2127**	**.2640**	**.2512**	**.1956**	**.2140**	**.1943**	**.3126**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN
Feeder No / Name : 207 / 11 KV ARASNAL AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4801	.4858
2						.5487	.5243
3						.5487	.5571
4						.6859	.663
5						.6859	.7373
6						.9431	.9503
7						1.1145	1.3077
8						1.2003	1.2071
9							.9878
10	.7621		.8848	.8192	.6859		
11	.945		.9012	.8383	.8535		
12	1.2003	1.166		1.1736	.8383		
13	1.2346		1.0978	1.0669	1.0317		
14	1.2003	.9145	1.0486	.9145	1.0288		
15	1.3717		1.1271	.9907	1.0288		
16	1.3717	.9998	1.0814	.9907	1.1145		
17	1.2346		1.0159	.9907			
24						.4973	
Max	**1.3717**	**1.166**	**1.1271**	**1.1736**	**1.1145**	**1.2003**	**1.3077**
Min	**.7621**	**.9145**	**.8848**	**.8192**	**.6859**	**.4801**	**.4858**
Avg	**1.1650**	**1.0268**	**1.0224**	**.9731**	**.9402**	**.7449**	**.8245**

 Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN
Feeder No / Name : 208 / 11 KV Water Works Feeder NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0508	.0491	.0508	.0457		.0508
2	.0381	.0438	.0491	.0526	.0514		.0508
3	.0438	.0497	.0508	.0549	.0457		.0532
4	.0396	.0343	.0508				.0491
5	.0412	.0532	.0508	.0526	.0457	.0086	.0514
6	.0427	.0549	.0508	.0526	.0442		.0526
7	.0508	.0597	.0526	.0514	.0427	.0497	.0503
8	.0457		.0491		.0514	.0526	.0503
9	.0491		.0526	.0508	.0514		.0526
10	.0457		.0491	.0508	.0457	.0508	.0508
11	.0497		.0508	.0526	.0497		
12	.0497	.0508		.0526	.0508		
13	.0497		.0508	.1372	.0438	.0508	
14	.0549	.0508	.0508	.0457	.0438	.0491	
15	.0497		.0508	.0526	.0491	.0508	
16	.0497	.0508	.0508	.0457	.0351	.0526	
17	.0508			.0457		.0532	
18	.0526	.0491	.0508	.0457	.0412		
19	.0514	.0491			.0497		
20	.0497		.0473	.0457	.048		
21	.0508	.0491	.0478	.0457	.0497		
22	.0508			.0457	.0497	.0508	
23	.0497	.0491			.0508	.0526	
24	.0526	.0497	.0508		.0343	.0532	
Max	**.0549**	**.0597**	**.0526**	**.1372**	**.0514**	**.0532**	**.0532**
Min	**.0381**	**.0343**	**.0473**	**.0457**	**.0343**	**.0086**	**.0491**
Avg	**.0478**	**.0497**	**.0503**	**.0543**	**.0463**	**.0479**	**.0512**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154085 / 33 KV LOHARA S/S
Feeder No / Name : 201 / 11 KV L0HARA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2294	.2439	.1943	.2743		.5487
2	.2743	.2267	.2439	.2187	.2743	.5792	.6097
3	.3086	.25	.2743	.2286	.3429	.6554	.6706
4						.7316	.7316
5						.8535	.8535
6						.9145	.9755
7						1.0669	1.0974
8						1.1584	1.2193
9						1.1584	1.3717
10	.6173	.4572	.5487	.7545	.7011		
11	.9145		.9145	1.1317	1.0364		
12	1.0136	1.1584	1.0235	1.2003	1.0669		
13	1.0364	1.0669	1.0425	1.2346	1.0974		
14	1.0105	1.0669	1.0288	1.2003	1.1584		
15	1.086		1.0402	1.2003	1.2193		
16	1.07	1.0059	.9267	1.2689	1.1584	.1829	
17	1.0669	1.0974	.9145	1.2689	1.0669	.1829	
18	.1524	.2134	.1562	.2401	.2134	.2134	
19	.2134	.2743	.2134	.2743		.3048	
20	.2915	.3353	.2915	.4115		.3963	
21	.2622	.3353	.2949	.4458	.3963	.3963	
22	.2429		.2458	.3429	.3658	.3658	
23	.2267	.2743	.2267	.3086	.3658	.3048	
24	.2743	1.0364	.2439	.1829	.3658	.4268	.4268
Max	**1.086**	**1.1584**	**1.0425**	**1.2689**	**1.2193**	**1.1584**	**1.3717**
Min	**.1524**	**.2134**	**.1562**	**.1829**	**.2134**	**.1829**	**.4268**
Avg	**.5919**	**.6019**	**.5486**	**.6726**	**.6940**	**.5819**	**.8505**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154085 / 33 KV LOHARA S/S
Feeder No / Name : 202 / 11 KV BHAKASKHEDA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5898	.5792	.583		.2134	.2439
2	.6516	.6478	.6706	.7499			.2743
3	.6859	.6874	.7621	.8535		.2743	.3048
4	.8573	.7621	.8535	.9145			
5	.9431	.9145	.9907	.9755			
6	1.1145	.9633	1.0364	1.0536			
7	1.2003	1.1145	1.0974	1.1004			
8	1.286	1.1584	1.1431	1.1145			
9	1.3032	.9907	1.1888				
10							.4877
11						1.0669	.9145
12						1.1279	1.1145
13						1.1584	
14					.6097	1.0669	
15					1.0364	.9755	
16	.1189	.1829	.1158	.1715	.1524	.945	
17	.1524	.2134	.1219	.1715	.1524	.9755	
18	.1524	.2439	.1562	.2058	.1829	.1829	
19	.1829	.2439	.1829	.2401	.2134	.2743	
20	.2591	.2439	.2591	.2401	.3048	.3048	
21	.2458	.2743	.2622	.2743	.2743	.3658	
22	.2267	.2439	.2294		.2439		
23	.1943	.2134	.1943		.2439	.2743	
24	.6001	.3932	.5335	.4268		.1829	.2439
Max	**1.3032**	**1.1584**	**1.1888**	**1.1145**	**1.0364**	**1.1584**	**1.1145**
Min	**.1189**	**.1829**	**.1158**	**.1715**	**.1524**	**.1829**	**.2439**
Avg	**.5985**	**.5601**	**.5765**	**.605**	**.3414**	**.6259**	**.5119**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154085 / 33 KV LOHARA S/S
Feeder No / Name : 203 / 11 KV KUMTHA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5898	.4877	.6478	.4458	.2439	.3048
2	.3429	.6802	.5487	.7499	.4801	.2439	.3658
3	.4287	.7499	.6401	.7926	.6001	.3048	.3658
4	.4801	.8535	.7011	.8535	.8573		
5	.6001	.9145	.7621	.9145	.9431		
6	.8573	.9934	.823	1.0837	1.2689		
7	1.3717	1.0402	1.1584	1.1584	1.5432		
8	1.3717	.9145	1.2193	1.3575	1.7147		
9	1.3032	.9145	1.1584	.602	1.5432		
10						.6706	.5487
11						.9755	.9755
12						1.0364	1.1888
13						1.0669	
14						1.0059	
15						.945	
16	.1486	.2134		.2058	.1829	.9145	
17	.1524	.2439	.1524	.2058	.1829	.9145	
18		.2439	.1875	.2401	.2134	.1829	
19	.2286	.2743	.2286	.2743	.2439	.3048	
20	.3239	.3353	.3239	.3429	.3658	.3658	
21	.2949	.3658	.3277	.4287	.381	.3963	
22	.2591	.3353	.2622	.3429	.3048	.3658	
23	.2267	.3048	.2429	.2743	.3048	.3048	
24	.3429	.2134	.4268	.4877	.4115	.2134	.2743
Max	**1.3717**	**1.0402**	**1.2193**	**1.3575**	**1.7147**	**1.0669**	**1.1888**
Min	**.1486**	**.2134**	**.1524**	**.2058**	**.1829**	**.1829**	**.2743**
Avg	**.5458**	**.5656**	**.5677**	**.6090**	**.6660**	**.5809**	**.5748**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] **BU 5142**
Substation No/ Name :- 154087 / 33/11 KV S. OMARGA
Feeder No / Name : 202 / 11 KV S.OMARGA **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.2987	.2804	.2957	.3772	.8764	1.1641
2	.373	.2987	.2629	.3696	.415	.8764	1.262
3	.4239	.2926	.2804	.3696	.4715	.8764	1.4022
4						.8764	1.5089
5						1.2269	1.5432
6						1.8861	1.8004
7						2.1434	1.8861
8						2.6578	2.5095
9						2.4863	2.652
10	2.0348		1.0745	1.0174	2.1033		
11	2.1628		2.1026	2.3739	2.3148		
12	2.0805	2.0683	2.1879	2.2891	2.2119		
13	2.1052	2.2977	1.989	2.1195	2.2939		
14	2.1125	2.1434	1.989	2.1195	2.2939		
15	2.1862	2.1434	1.9227	2.1195	2.13		
16	2.1605	2.2977	1.989	2.1195	1.5927	.1433	
17	2.2672	2.572	2.2382	2.2043	2.13	.1791	
18	.1829	.1753	.2172	.2035	.1867	.2103	
19	.3734	.3506	.3696	.3391	.3734	.3155	
20	.4481	.4115	.5175	.373	.4527	.3506	.4435
21	.4108	.4801	.4435	.4239	.4527	.3856	.3696
22	.3395	.3506	.3696	.373	.3772	.3506	.2957
23	.3018	.3506	.2957			.2804	.2957
24	.3391	.2987	.3155	.2957	.3361	.5601	1.0288
Max	**2.2672**	**2.572**	**2.2382**	**2.3739**	**2.3148**	**2.6578**	**2.652**
Min	**.1829**	**.1753**	**.2172**	**.2035**	**.1867**	**.1433**	**.2957**
Avg	**1.1467**	**1.0519**	**1.0470**	**1.1415**	**1.2066**	**.9268**	**1.2973**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] BU 5142
Substation No/ Name :- 154087 / 33/11 KV S. OMARGA
Feeder No / Name : 203 / 11 KV KARWANDI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3734	.4908	.4344		.3582	.2218
2	.4096	.5487	.5144	.5014		.3582	.2218
3	.4915	.5544	.6001	.5258		.3582	.2772
4	.4915	.5544	.6516	.6661			
5	.7373	.5601	.6859	.7545			
6	.9326	.78	.6859	.823			
7	1.0159	1.0288	.9259	.9945			
8		1.0288	.7888	.9282			
9	.8383	.9945	.7716	.8619	.2241		
10						.1791	.5792
11						.7362	.9259
12						.7712	.5144
13						.6661	.8817
14						.3856	
15						.6859	
16	.0934	.0895	.0724	.0819	.0914	.7202	
17	.1463	.1227	.1086	.1311	.1494	.7888	
18		.1578	.181	.1638		.1433	
19	.2987	.2629	.3326	.2458		.2804	.3326
20	.4108	.3506	.4066	.2949	.3734	.3155	.4066
21	.3734	.3155	.3696	.2458		.3506	.3696
22	.2641	.2804	.2957			.3155	.2957
23	.2641	.2629	.2587			.2454	.2957
24	.3277	.3361	.3506			.3734	.2149
Max	**1.0159**	**1.0288**	**.9259**	**.9945**	**.3734**	**.7888**	**.9259**
Min	**.0934**	**.0895**	**.0724**	**.0819**	**.0914**	**.1433**	**.2149**
Avg	**.4639**	**.4779**	**.4717**	**.5102**	**.2096**	**.4462**	**.4259**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] **BU 5142**
Substation No/ Name :- 154103 / 33 KV S/S GUTTI
Feeder No / Name : 201 / 11 KV GUTTI **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4001	.362	.362		.4748	.463
2	.4191	.381		.381	.362	.503	.5316
3	.4382	.4001	.4001	.381		.5533	.583
4						.463	.5335
5						.5087	.9602
6						.7373	
7						.9054	
8						.9614	.9602
9						.8288	.9088
10	.6274	.5906	.6516	.6687	.5658		
11	.7432	.5944	.6859	.9145	.7935		
12	.8322	.7316	.8573	.8954	.7611		
13	.8097	.8745	.7716	.9145	.5365		
14	.7968	.7316	.7888	.9145	.7701		
15	.8322	.7773	.7373	.9335	.6882		
16	.6401	.5944	.7888	.8402	.5304	.2477	
17	.7611	.6516	.7716	.8402	.7537	.2915	
18	.2286	.4572	.2858	.2477	.3239	.2591	
19	.5716	.6344	.5906	.743	.6859	.3429	
20	.5906	.6516	.724	.724	.6668	.362	
21	.5716	.4973	.5906	.5716	.5716	.3601	
22	.4763	.4954	.4763	.5716	.4763	.3944	
23			.4382	.4382	.4191	.463	
24	.4191			.381	.4001	.4458	
Max	**.8322**	**.8745**	**.8573**	**.9335**	**.7935**	**.9614**	**.9602**
Min	**.2286**	**.381**	**.2858**	**.2477**	**.3239**	**.2477**	**.463**
Avg	**.5986**	**.5914**	**.6200**	**.6513**	**.5816**	**.5057**	**.7058**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] **BU 5142**
Substation No/ Name :- 154103 / 33 KV S/S GUTTI
Feeder No / Name : 202 / 11 kv CHINCHOLI FEEDER **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.362	.4115	.4458		.6097	.5658
2	.3048	.3544	.4801	.463	.5144	.5716	.5487
3	.3239	.3898	.4973	.463		.5335	.5144
4	.3239	.4207	.5316	.4973	.3113		
5	.4191	.431	.583	.5316	.3772		
6	.5335	.5895	.6173	.6516	.4382		
7	.6001	.6984	.6516	.703	.6588		
8	.703	.6935	.6516	.7202	.6173		
9	.7811		.6344	.6687	.6274		
10						.4382	.4115
11						.7293	.6554
12						.6859	.6344
13						.6249	
14						.7202	
15						.5944	
16	.4763	.3944	.4763	.5335	.5525	.5316	
17	.5716	.4973	.5716	.5525	.5525	.6097	
18	.6097	.5906	.5906	.6478	.6287	.5658	
19	.9526	1.0288	.8192	.8573	.8383	.6478	
20	.9907	.7716	.8383	.8383	.9145	.8002	
21	.8192	.703	.8002	.724	.724	.8002	
22	.724		.724	.6859	.6859	.6687	
23			.6478	.6478	.6287	.6478	
24	.2743	.3086		.3086	.2743	.6097	
Max	**.9907**	**1.0288**	**.8383**	**.8573**	**.9145**	**.8002**	**.6554**
Min	**.2743**	**.3086**	**.4115**	**.3086**	**.2743**	**.4382**	**.4115**
Avg	**.5713**	**.5489**	**.6192**	**.6078**	**.584**	**.6327**	**.5550**

Date:- 02-07-17

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-17 and 04-APR-17

LATUR ZONE, LATUR[068]
LATUR CIRCLE[680]
UDGIR DIVISION[685]
UDGIR(R) S/DN[431] **BU 5142**
Substation No/ Name :- 154103 / 33 KV S/S GUTTI
Feeder No / Name : 203 / 11 KV SULLALI **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	29-MAR-17	30-MAR-17	31-MAR-17	01-APR-17	02-APR-17	03-APR-17	04-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3315	.3601	.3772		.2286	.2058
2	.3429	.3441	.3944	.3944	.4382	.2477	.2667
3	.3429	.3521	.4458	.4115		.2667	.2858
4	.362	.3315	.4973	.463	.4096		
5	.4191	.3988	.5658	.5144	.5144		
6	.5906	.4801	.583	.5316	.6001		
7	.7373	.6104	.6001	.5487	.6613		
8	.7202	.5868	.6173	.5658	.5596		
9	.6287			.5487	.57		
10						.4973	.6173
11						.6371	.6687
12						.7011	.6173
13						.6516	
14						.6516	
15						.6097	
16	.1524	.1524		.1905	.1524	.5182	
17	.1524	.2286		.2096	.1715	.2743	
18	.1715	.2401		.4382	.2667		
19	.3239	.2915	.0953	.362	.3429	.3086	
20	.3429	.3239	.1334	.3429	.3048	.3239	
21	.3048	.2743	.1334	.3239	.3048	.3086	
22	.3048	.3048	.1143	.3048	.3048	.3086	
23		.2667	.0953	.2667	.3048	.2743	
24	.2915	.3258		.3944	.3258	.2286	
Max	**.7373**	**.6104**	**.6173**	**.5658**	**.6613**	**.7011**	**.6687**
Min	**.1524**	**.1524**	**.0953**	**.1905**	**.1524**	**.2286**	**.2058**
Avg	**.3842**	**.3437**	**.3566**	**.3994**	**.3895**	**.4139**	**.4436**