

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 201 / BHOKAR TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001		.6001	.7316		.6859	.6859
2	.6001		.6001	.7316		.6859	.6859
3	.6001		.6001	.6401		.6859	.6859
4	.6001	.5144	.6001	.6401	.6135	.6001	.6859
5	.6001	.5144	.6001	.6401	.6001	.6001	.6001
6	.5144	.5144	.6001	.6401	.6135	.6001	.6001
7	.5144	.5144	.6001	.6401		.6001	.6001
8	.6001	.5144	.6001	.6401	.5935	.0514	.6859
9	.6001	.5144	.6001	.6401	.6001	.5144	.6001
10	.6135	.7316	1.848	.6001	.6401	.6001	.5144
11	.6135	.6401	.6001	.6001	.5487	.6001	.5087
12	.6135	.6401	.6001	.6001	.5487	.6001	.5935
13		.5487	.6001	.6001	.5487	.5144	
14		.5487	.6001	.6001	.5487	.5144	
15		.5487	.6001	.6001	.5487	.5144	
16	.6001	.5487	.6001	.6001	.5487	.5144	
17	.6135	.5144	.5487	.6001	.5144	.6001	.5087
18	.6859	.6001	.5487	.6001	.6859	.6001	.5087
19	.7011	.6001	.7316	.6859	.6859	.6859	.5935
20	.6859	.6001	.7316	.6859	.6859	.6859	.5868
21		.6001	.823	.7011	.6859	.6859	.5935
22		.6001	.823			.6859	
23		.6001	.7316	.6859		.6859	
24	.6001	.6859	.6001	.7316	.6859	.6859	.6859
Max	.7011	.7316	1.848	.7316	.6859	.6859	.6859
Min	.5144	.5144	.5487	.6001	.5144	.0514	.5087
Avg	.6087	.5759	.6828	.6450	.6054	.5916	.6069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 202 / BHOKAR TOWN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575		1.5432	1.6461		1.6289	1.5432
2	1.4575		1.5432	1.6461		1.6289	1.5432
3	1.4575		1.5432	1.5546		1.6289	1.5432
4	1.4575	1.3717	1.5432	1.5546	1.3717	1.6289	1.5432
5	1.4575	1.3717	1.3717	1.5546	1.3717	1.3717	1.5432
6	1.3717	1.3717	1.3717	1.4632	1.3717	1.3717	1.4575
7	1.3717	1.3717	1.3717	1.3717		1.3717	1.4575
8	1.286	1.3717	1.3717	1.4632	1.3565	1.3717	1.4575
9	1.286	1.3717	1.286	1.3717	1.2717	1.2003	1.4575
10	1.3146	1.4632	1.3717	1.286	1.4632	1.3717	1.4413
11	1.3146	1.3717	1.4575	1.3717	1.4632	1.4575	1.4251
12	1.4022	1.3717	1.4575	1.4575	1.6461	1.4575	1.4413
13		1.4632	1.4575	1.4575	1.6461	1.4575	
14		1.4632	1.4575	1.4575	1.6461	1.4575	
15		1.4632	1.4575	1.4575	1.6461	1.4575	
16	1.3717	1.4632	1.4575	1.4575	1.6461	1.3717	
17	1.3717	1.3717	1.4632	1.4022	1.5432	1.5432	1.5261
18	1.4899	1.286	1.5546	1.4022	1.6289	1.5432	1.5261
19	1.5432	1.3717	1.7375	1.5432	1.7147	1.7147	1.5089
20	1.5775	1.5432	1.829	1.5775	1.7147	1.7147	1.6956
21		1.5432	1.829	1.5775	1.7147	1.8004	1.6956
22		.6001	1.7375			1.8004	
23		1.5432	1.6461	1.5432		1.7147	
24	1.4575	1.4575	1.5432	1.6461	1.5432	1.6289	1.6289
Max	1.5775	1.5432	1.829	1.6461	1.7147	1.8004	1.6956
Min	1.286	.6001	1.286	1.286	1.2717	1.2003	1.4251
Avg	1.4137	1.3812	1.5168	1.4897	1.5422	1.5289	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 203 / BATALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.4572	1.0974		.6097	.5144
2	.5144		.6097	1.0974		.7621	.5144
3	.5144		.9145	1.3717		.7621	.6859
4	.5144	.5144	.9145	1.5546		1.2193	.6859
5	.5144	.4287	1.2193	1.5546		1.5242	1.0288
6	.5144	.5144	1.3717	1.6461		1.5242	1.3717
7	.4287	.5144	1.6766	1.7375		1.2193	1.7147
8	.3429	.5144	1.6766	2.1948	2.1795	1.5242	1.4575
9	.2572	.3429	1.6766	2.1033	1.8442	1.2193	1.5261
10	.2629	.3658	1.7147	1.7528	1.829	1.3717	1.7147
11	1.4022		.2572	.3048	.3658	.3429	.3391
12	1.7147		.3429	.3048	.3658	.3429	.3391
13		1.3717	.3429	.3048	.3658	.3429	
14		2.0119	.4287	.3429	.3658	.3429	
15		2.0119	.3429	.3048	.3658	.3429	
16	1.7528	2.0119	.3429	.3048	.3658	.3429	
17	1.8861	1.6766	.3658	.3506	.3048	.3429	
18	1.9281	1.6004	.4572		.381	.4287	.3353
19	.543	.4572	.5487	.6001	.4572	.4287	.503
20	.6135	.5144	.5487	.6001	.4572	.5144	.5868
21		.4287	.5487	.6001	.4572	.5144	.5935
22		.381	.5487			.5144	
23		.381	.5487	.5144		.5144	
24	.5144	.5258	.381	.4572	.5144	.4572	.5144
Max	1.9281	2.0119	1.7147	2.1948	2.1795	1.5242	1.7147
Min	.2572	.3429	.2572	.3048	.3048	.3429	.3353
Avg	.8185	.8720	.7599	.9591	.7080	.7295	.8485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 204 / NARWAT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	.7316		.6097	.6859
2	.8573		.6859	.7316		.6097	.6859
3	.8573		.6097	.7316		.5335	.6859
4	.8573	1.3717	.6097	.7316	.6001	.5335	.6001
5	1.2003	1.3717	.6097	.7316	.6001	.5335	.6001
6	1.4575	1.5432	.4572	.7316	.6001	.5335	.6001
7	2.0576	2.1434	.381	.5487		.5335	.5144
8	2.2291	1.8861	.3048	.5487	.4239	.381	.5144
9	1.5432	1.3717	.381	.4572	.4382	.381	.3391
10	2.1033	2.2862	.4287	.381	.4572	.4287	.3391
11	.3506	.3658	1.9719	1.2193	2.0119	1.5432	1.3565
12	.3506	.4572	2.1434	1.829	2.1033	1.5432	1.7804
13		.4572	1.9719	2.0576	2.0119	1.5432	
14		.4572	1.9719	1.6766	1.7375	1.3717	
15		.4572	1.8861	1.5242	1.9204	1.3717	
16	.3506	.4572	1.9719		2.0119		
17	.3429	.381	2.2862		1.6766		
18	.3429	.381	2.0119	2.2786	1.5242	2.2291	1.6956
19	.6135	.6097	.7316	.6859	.7621	.6859	.6783
20	.7888	.6859	.9145	.7716	.7621	.8573	.8478
21		.6859	.9145	.7716	.7621	.8573	.7545
22		.6859	.9145			.8573	
23		.6859	.823	.7716		.7716	
24	.7716	.7716	.6859	.7316	.6859	.6097	.6859
Max	2.2291	2.2862	2.2862	2.2786	2.1033	2.2291	1.7804
Min	.3429	.3658	.3048	.381	.4239	.381	.3391
Avg	1.0044	.9292	1.0980	.9830	1.1716	.8781	.7861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 205 / MANJIT COTTON EXP. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287		.4287	.4572		.3429	.1715
2	.4287		.4287	.4572		.3429	.1715
3			.4287	.4572		.3429	.1715
4		.4287	.4287	.4572	.4287	.3429	.1715
5		.4287	.4287	.4572	.4287	.2572	.1715
6	.0857	.4287	.4287	.4572	.4287	.2572	.1715
7	.0857	.4287	.4287	.4572		.2572	.1715
8	.3429	.4287	.4287	.4572	.1696	.1715	.0857
9	.3429	.4287	.4287	.4572	.0838	.1715	.0848
10	.1753	.4572	.4287	.4287	.0914	.0857	.0848
11	.1715	.4572	.4287	.4287	.2743	.0857	.0857
12	.1753	.4572	.4287	.4287	.0914	.0857	.0848
13		.4572		.4287	.0914	.0857	
14		.4572	.4287	.4287	.0914		
15		.4572	.4287	.381	.0914		
16	.1753	.4572	.1715	.4287	.0914		
17	.1715	.4287	.4572	.4382	.0857		
18	.4287	.4287	.4572	.4382	.0857		.3391
19	.4382	.4287	.4572	.4287	.3429		.3391
20	.5258	.4287	.4572	.4287	.4287	.0857	.3391
21		.3429	.4572	.4287	.4287	.1715	.4191
22		.3429	.4572			.0857	
23		.381	.4572	.4287		.0857	
24	.4287	.4287	.4287	.4572	.4287	.3429	.1715
Max	.5258	.4572	.4572	.4572	.4287	.3429	.4191
Min	.0857	.3429	.1715	.381	.0838	.0857	.0848
Avg	.2937	.4278	.4262	.4398	.2313	.2000	.1902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 206 / EXP. FEEDER W/S BKR(SUDHA) NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857		.0857	.1829		.0857	.0857
2	.1715		.0857	.1829		.0857	.0857
3	.1715		.0857	.1829		.1715	.0857
4	.0857	.0857	.1715	.1829	.1715	.1715	.0857
5	.1715	.0857	.1715	.1829	.1715	.1715	.1715
6	.1715	.1715	.1715	.1829	.1715	.1715	.1715
7	.1715	.1715	.1715	.1829		.1715	.1715
8	.1715	.1715	.1715	.1829	.1696	.1715	.1715
9	.1715	.1715	.1715	.1829	.1696	.1715	.1696
10	.1753	.1829	.1715	.1715	.1829	.1715	.1696
11	.1753	.1829	.1715	.1715	.1829	.1715	.1715
12	.1753	.1829	.1715	.0857	.1829	.1715	.0848
13		.1829	.1715	.0857	.0914	.1715	
14		.0914	.0857	.0857	.0914	.1715	
15		.0914	.0857	.0857	.0914	.0857	
16	.1715	.0914	.0857	.0857	.0914		
17	.1715	.0857	.0914	.0876	.0857	.0857	
18	.0857	.0857	.0914	.0857	.0857	.0857	.0848
19	.0876	.0857	.0914	.0857	.0857	.0857	.0838
20	.0876	.0857	.0914	.0857	.0857	.0857	.0848
21		.0857	.0914	.0857	.0857	.0857	.0848
22		.0762	.0914			.0857	
23		.0857	.0914	.0857		.0857	
24	.0857	.0857	.0762	.0914	.0857	.0857	.0857
Max	.1753	.1829	.1715	.1829	.1829	.1715	.1715
Min	.0857	.0762	.0762	.0857	.0857	.0857	.0838
Avg	.1437	.1209	.1227	.1315	.1268	.1305	.1205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 201 / MATUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.4458	.0427	.0396	.4024	.4458	.426
2	.0427		.0457	.0488		.4458	.421
3	.0446	.4801	.0457	.0488	.5365	.4458	.421
4	.0396		.0518	.0533		.4409	.4858
5	.0396	.4801	.0518	.0549		.4409	.6401
6	.0427	.5144	.0518	.0549		.8139	.7449
7	.0457		.0549	.0732	.5365	1.0174	.9717
8		.4115	.061	.0884		1.0174	1.166
9			.0671	.0914	.503	.9614	
10		.3772	.0823	.0914	.6036	.9282	
11				.2915	.57	.3563	.4858
12	1.326	.8048	.0335	.3932		.3239	.4858
13	1.3279		.0335	.3978	.3688		.4801
14	1.3279	1.0059	.0335	.3647		.3353	.4801
15	1.2955		.0335	.3315	.4115		.4801
16	1.2631	1.0974	.0335	.3978		.3688	.4534
17	1.2955	1.1065	.0412	.4024	.503		.4801
18	1.3279		.0412	.503		.4359	.5121
19	.5426	.5365	.0457	.5426	.583	.6036	.5761
20	.583		.0549	.6104		.6104	.6401
21	.4748	.4801	.0518	.6104	.57	.5087	.6154
22	.4409	.4801	.0488	.6104	.5144	.5087	.6081
23	.4409	.4801	.0488	.5765	.5144	.4534	.583
24	.0488	.4801	.4801	.0457		.4534	.4588
Max	1.3279	1.1065	.4801	.6104	.6036	1.0174	1.166
Min	.0396	.3772	.0335	.0396	.3688	.3239	.421
Avg	.5998	.6120	.0667	.2801	.5090	.5674	.5734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 202 / BENDRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377		.0412	.0274	.3772		.385
2	.0305		.0396	.0274	.2401	.4458	.3841
3	.0305	.3963	.0396	.0274	.2347		.3841
4	.0274		.0396	.0305		.4458	.3887
5	.0309	.4458	.0427	.0229		.5144	.4161
6	.0343	.4024	.0427	.0427			.4161
7	.0309		.0427	.0457	.4801	.5144	.4161
8	.0309	.3018	.0457	.0488	.4359		.4161
9	.0274		.0457	.0488		.5144	.2915
10	.0244	.2683	.0427	.0396	.4458	.4458	.4161
11	.4641				.2683	.3429	.2561
12	.5967		.0274	.3315	.2683		.2561
13	.5898		.0274	.2984		.3086	.2881
14	.5243	.5365	.0244	.2984	.3018	.3086	.2881
15	.5243		.0274	.2984	.3018		.2881
16	.4641	.5365	.0274	.2984	.3353	.3429	.2881
17	.4973		.0274	.2984			.3201
18	.4973	.2012	.1097	.3429	.4024	.3429	.3521
19	.5087		.0377		.4694	.4458	.4161
20	.4973	.4801	.0396	.4115	.503		.4858
21			.0396				.4801
22		.4458	.0366		.4694	.4858	.4801
23		.4115	.0366	.4115	.4694	.4534	.4534
24	.0377	.4115	.4115	.0377	.3772	.4694	.4161
Max	.5967	.5365	.4115	.4115	.503	.5144	.4858
Min	.0244	.2012	.0244	.0229	.2347	.3086	.2561
Avg	.2622	.4031	.0563	.1694	.3753	.4254	.3743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 203 / SONARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1241	.6859		.0762	.9054	.8718	.852
2	1.2208		.0793	.0762	.8718		.8322
3	1.3146	.823	.0793	.0732	.8718	.8718	.8421
4	1.406		.0793	.061	.8718		.7773
5	1.4792	.8916	.0793	.061		.8048	.7865
6	1.9562		.0854	.0686	.9054	.823	.7865
7	2.0964	1.6461	.0579	.0732	.8573	.6371	.7125
8	2.1163		.0549	.064			.6478
9	2.2573	1.5089	.0488	.0518		.5487	.583
10	2.2283		.0427	.0533	.6859	.4801	.5243
11	2.4562				1.3717		1.3108
12	1.1492		.1296			.823	1.5223
13	1.2087	.5487	.1372			1.7833	1.5729
14	1.2483		.1219		1.4754	1.073	1.4899
15	1.2955	.6173	.1143			1.0974	1.5402
16	1.2994		.1341		1.7147		1.5546
17	1.339		.1448			1.6461	1.5223
18	1.147	.6859	.1448		1.8442	1.5775	1.4899
19	1.0997		.061			.8916	.9175
20	1.2102	.6173	.0854		.9389	1.0288	1.0364
21	1.2239		.0945		.9389	.9945	1.004
22	1.1477	.9389	.0945		.9389		.9922
23	.9137	.8916	.0914		.8718	.852	.9717
24	1.1416	.8916	.8916	.0823	.9602	.8718	.852
Max	2.4562	1.6461	.8916	.0823	1.8442	1.7833	1.5729
Min	.9137	.5487	.0427	.0518	.6859	.4801	.5243
Avg	1.4616	.8956	.1296	.0673	1.0640	.9820	1.0467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 201 / MASALGA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.5144		.5144	.4115
2			.5144	.5144		.6859	.4115
3			.6859	.5144		.6859	.4115
4			.6859	.5144		.6859	.4115
5			.8573	.6859		.6859	.5316
6			.6859	.6859			.5144
7			.6859	.6859			.6859
8			.8573	.8573			.6859
9			.8573	.8573	.7716		.6859
10			.8573	.6859	.7716	.3429	.6859
11	.6859	.6859					
12	.6859						
13	.6859						
14	.6859						
15	.6859			.2743			
16	.6859						
17	.6859	.8573					
18	.6859	.6859					
Max	.6859	.8573	.8573	.8573	.7716	.6859	.6859
Min	.6859	.6859	.5144	.2743	.7716	.3429	.4115
Avg	.6859	.7430	.7202	.6173	.7716	.6002	.5436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 202 / PALAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145				.5144		
2	.9145				.5144		
3	1.2193				.5144		
4	1.2193				.5144		
5	1.5242				.6859		
6	1.5242	1.6385			.6859		
7	1.6766	1.8023			.6859		
8	1.5242	1.8023			.6859		
9	1.829	1.9662					
10	1.9662	1.9662					
11			1.5242	1.6385	.1638	1.2193	1.3108
12			1.829	1.6385	1.7147	1.7147	1.3108
13			1.829	1.8023	1.7147	1.6766	1.3108
14			1.829	1.8023		1.6766	1.2289
15			1.829	1.6385	1.7147		
16			1.829	1.6385	1.5432		1.2289
17			1.6766	1.4746			
18			1.6766	1.3927	1.5432	.7621	1.3108
21							1.3108
Max	1.9662	1.9662	1.829	1.8023	1.7147	1.7147	1.3108
Min	.9145	1.6385	1.5242	1.3927	.1638	.7621	1.2289
Avg	1.4312	1.8351	1.7528	1.6282	.9425	1.4099	1.2874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 203 / KINI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.2126	.2401	.2126		.2401	.1772
2	.2126	.2126	.2401	.2126	.2126	.2481	.2126
3	.2481	.2481	.2401	.2481	.2126	.2481	.2126
4	.2481	.2481	.2401	.2481	.2481	.2481	.2481
5	.2835	.2835	.2743	.2481	.2481	.2835	.2481
6	.2835	.2835	.2743	.2835	.2835	.3189	.2835
7	.2835	.2835	.2401	.2835	.2835	.2835	.2835
8	.2481	.2481	.2058	.2481	.2481	.2835	.2481
12	.2126		.2126	.2195	.2058	.2126	.2126
13	.2481		.2126	.2126	.2058	.1772	.1772
14	.2126		.2126	.2126	.2058	.1772	.1772
15	.2126		.2126	.2126	.2058	.2126	.2126
16	.2481		.2126	.2126	.2058	.2481	.2561
17	.2835		.2481	.2481	.2058	.2835	.2481
18	.2835	.2401	.2481	.2835	.2058	.2835	.2835
19	.2835		.2835	.2835	.2743	.2835	.2835
20	.2835		.2835		.3086	.2835	.2835
21	.2481		.2481	.2835		.2481	.2481
22	.2481		.2481	.2481		.2126	
23	.2126		.2126	.2481		.2126	.2126
24	.2126	.2126	.2401	.2126	.2481	.2743	.1772
Max	.2835	.2835	.2835	.2835	.3086	.3189	.2835
Min	.2126	.2126	.2058	.2126	.2058	.1772	.1772
Avg	.2481	.2473	.2395	.2431	.2358	.2506	.2343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 204 / PALAJ GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2378	.2743	.2561	.2561	.2743	.2561
2	.2561	.2561	.2743	.2561	.2561	.2926	.2561
3	.2926	.2561	.3258	.2926	.2926	.2926	.2926
4	.2926	.2926	.2743	.2926	.2926	.2926	.2926
5	.2926	.2926	.3086	.2926	.2926	.3292	.2926
6	.3292	.3292	.3258	.3292	.3292	.3658	.3292
7	.3292	.3292	.3086	.3292	.3292	.3475	.3292
8	.2926	.2926	.2743	.2926	.2561	.3292	.2926
12	.2561		.2561	.2743	.2401	.2926	.2926
13	.2926		.2561	.2743	.2743	.2561	.2561
14	.2743		.2561	.2743	.2743	.2195	.2195
15	.2926		.2561	.2743	.2401	.2561	.2561
16	.2926		.2561	.2926	.2401	.2926	.2561
17	.3292		.2926	.3292	.2401	.2926	.2926
18	.3658	.3429	.3292	.3292	.2401	.3292	.3292
19	.3658	.3429	.1829	.2926	.3429	.3658	.3658
20	.3292		.3292	.3292	.3772	.3658	.3658
21	.3292		.2926	.3292		.3292	.3658
22	.3292		.2926	.3658		.2926	.2926
23	.2926		.2561	.3292		.2561	.2561
24	.2561	.2561	.2743	.2561	.3292	.3086	.2561
Max	.3658	.3429	.3292	.3658	.3772	.3658	.3658
Min	.2561	.2378	.1829	.2561	.2401	.2195	.2195
Avg	.3022	.2935	.2808	.2996	.2835	.3038	.2926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174090 / MOGHALI

Feeder No / Name : 201 / MOGHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)
17		1.2193
24	.5304	
Max	.5304	1.2193
Min	.5304	1.2193
Avg	.5304	1.2193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174090 / MOGHALI

Feeder No / Name : 202 / SHIRUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)
17		.1334
24	.2683	
Max	.2683	.1334
Min	.2683	.1334
Avg	.2683	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174090 / MOGHALI

Feeder No / Name : 203 / KAMANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)
17		.3048
24	.3315	
Max	.3315	.3048
Min	.3315	.3048
Avg	.3315	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 201 / SINGARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3481	.2984	.1658	.2321	.2458	.3277	.2949
2	.2984	.2984	.1658	.2321	.2458	.3277	.2949
3	.2984	.2984	.1658	.2321	.2458	.3277	.2949
4	.2984	.2984	.1658	.2486		.3277	.1638
5	.3481	.2984	.1989	.2652		.3277	.1966
6	.3481	.2984	.1989	.2818		.2622	.2622
7	.1989	.2321	.3315	.3315	.3277	.2949	.3277
8	.1492	.1989	.3315	.3481	.426	.2949	.3932
9	.1492	.1658	.3315	.2984	.3932	.2622	.3277
10	.1492	.1326	.3315	.2984	.3932	.2622	.3277
11	.4144	.3315	.1492	.1492	.1638	.0983	.0983
12	.431		.1492	.1989	.1638	.1475	.1966
13	.3978	.2321	.1492	.1989	.1638	.1475	.1966
14	.3315	.2652	.1492	.1966	.1638	.1475	.2294
15	.3149	.2984	.1492	.1966	.1638	.1475	.1966
16	.3315	.2984	.1492	.1966	.1638	.1475	.1475
17	.3647	.2321	.1492	.1475	.1638	.1475	.1475
18	.4144	.2652	.1492	.1966	.1966	.1475	.1966
19	.2486	.2984	.2984	.2949	.2949	.2949	.2949
20	.3481	.3647	.3481	.3441	.3277	.2949	.3932
21	.3481	.3978	.3481	.3441	.3605	.1966	.1475
22	.3481	.3978	.3481	.3441	.3605	.2458	.3441
23	.3481	.3647	.3481	.3441	.3605	.2949	.2949
24	.3481	.3481	.3315	.3481	.3441	.3277	.2949
Max	.431	.3978	.3481	.3481	.426	.3277	.3932
Min	.1492	.1326	.1492	.1475	.1638	.0983	.0983
Avg	.3156	.2876	.2335	.2612	.2699	.2417	.2526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 202 / SAWARGAON MAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.3563	.0648	.0648	.0648	.0648	.0486
2	.421	.3563	.0648	.0648	.0648	.0648	.0486
3	.4534	.4049	.0648	.0648	.0648	.0648	.0486
4	.4858	.4372	.0648	.0648	.0648	.0648	.0486
5	.583	.4696	.0648	.0648	.0648	.0648	.0486
6	.6154	.4858	.0648	.0324	.0648	.0648	.0486
7	.6802	.4858	.0324	.0324	.0648	.0648	.0486
8	.6478	.6154	.0324	.0324	.0324	.0324	.0486
9	.7449	.583	.0497	.0324	.0324	.0486	.0486
10	.7125	.5506	.0486	.0324	.0324	.0486	.0486
11	.0486	.0324	.2915	.3887	.3563	.2915	.3563
12	.0486	.0324	.4534	.4534	.3887	.3887	.4858
13	.0486	.0324	.421	.4858	.421	.4049	.421
14	.0486	.0324	.421	.5182	.4534	.2267	.3887
15	.0486	.0324	.4858	.5182	.4534	.3563	.4049
16	.0486	.0324	.4858		.4858	.0486	.421
17	.0486	.0324	.5304		.4858	.0486	.5506
18	.0486	.0324	.5506	.4534	.4858	.1296	.583
19	.0486	.0648	.0486	.0486	.0648	.0486	.0486
20	.0486	.0648	.0486	.0648	.0648	.0972	.0486
21	.0486	.0648	.0486	.0648	.0648	.0972	.0486
22	.0486	.0648	.0486	.0648	.0648	.0486	.0489
23	.0486	.0648	.0486	.0648	.0648	.0486	.0486
24	.0648	.0486	.0648	.0486	.0648	.0648	.0486
Max	.7449	.6154	.5506	.5182	.4858	.4049	.583
Min	.0486	.0324	.0324	.0324	.0324	.0324	.0486
Avg	.2679	.2240	.1875	.1664	.1862	.1201	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 203 / DEWTHANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1326	.1326	.1989	.1989	.1989	.1989	.1989
2	.1326	.1326	.1989	.1989	.1989	.1989	.1989
3	.1326	.1492	.1989	.1989	.1989	.1989	.1989
4	.1658	.1658	.1989	.2486	.1989	.1989	.1989
5	.1658	.1989	.1989	.2984	.1989	.1989	.1989
6	.1658	.1989	.1658	.2984	.1989	.0995	.1492
7	.2321	.2321	.1658	.1492	.1492	.0663	.1492
8	.2321	.2652	.1326	.0995	.0995	.0663	.1492
9	.2321	.2652	.0995	.0995	.0995	.0497	.0995
10	.1989	.2321	.0995	.0995	.0995	.0497	.0995
11	.0995	.0995	.1989	.0332	.1989	.1326	.1326
12	.0995	.0995	.1989	.1658	.1658	.1658	.116
13	.0995	.0995	.1989	.1658	.1658	.1658	.0995
14	.0995	.0995	.1989	.1326	.1658	.1326	.0829
15	.0995	.0995	.1658	.1326	.1658	.1326	.0829
16	.0995	.0995	.1326		.1658	.0497	.0663
17	.0995	.0995	.2321		.1989	.0497	.0995
18	.1492	.0995	.1989	.1658	.2321	.1658	.0995
19	.1989	.1658	.1989	.1989	.1989	.1989	.1989
20	.1989	.1989	.1989	.1989	.1989	.2486	.1989
21	.1989	.1989	.1989	.1989	.1989	.2486	.1989
22	.1989	.1989	.1989	.1989	.1943	.2486	.1492
23	.1989	.1989	.1989	.1989	.1989	.1989	.0995
24	.1989	.1989	.1989	.1989	.1989	.1989	.1989
Max	.2321	.2652	.2321	.2984	.2321	.2486	.1989
Min	.0995	.0995	.0995	.0332	.0995	.0497	.0663
Avg	.1596	.1637	.1823	.1763	.1787	.1526	.1444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 201 / BHOSI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576				1.848		
2	.3658				1.8861		
3	.381				1.9814		
4	.4268				2.1529		
5					2.3053	2.7054	
6		.5316		2.572	2.6101		
7	.5335		2.1559		2.7244	2.8959	
8	.3658				2.5149	2.5911	2.2965
9			.2401		.3963		
10			.2743		.3506		.2286
11		.2286	.2134		.3201		
12	.2572		.2591		.3201		
13		.2058	.3048		.3201		.3048
14			.3048		.3048		.3048
15					.3201		
16		.2058	.3086		.3353	.2172	.3353
17					.3048		.3048
18	2.572	2.5621	.3772		.3658	.3071	.4268
19					.4268		.4877
20			.5658				.5182
21		2.1872					
22			.5144			.3429	
23	2.4006						
24	2.0957	2.3148	1.906	.463	.4268	.4572	.3201
Max	2.572	2.5621	2.1559	2.572	2.7244	2.8959	2.2965
Min	.2572	.2058	.2134	.463	.3048	.2172	.2286
Avg	1.1456	1.1766	.6187	1.5175	1.1107	1.3595	.5528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 202 / WAKAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.2955						
3	1.448						
4	1.6575						
5	2.0576						
6	2.1338	1.8004		.2229		.2286	
7	2.2672		.1486		.1829	.2134	
8	1.2384				.1677		.1143
9	.1715		1.448		2.0957		
10			1.848		2.0195		1.4022
11		.1143	1.8861				
12	.1029		1.8099				
13		.0572	1.7718		1.6194		1.6575
14			1.7909		1.6004		1.5623
15					1.5623		1.5432
16		.1143	1.5775		1.5242	1.0669	1.5623
17					.1677		.1524
18	.1715		.1372		.2134	.1143	.1829
19					.2439		.2134
20			.3429				.3201
21		.2172					
22			.3086			.2401	
23	.3086						
24	.2439	.3086	.2058	.2572	.2439	.2896	.2058
Max	2.2672	1.8004	1.8861	.2572	2.0957	1.0669	1.6575
Min	.1029	.0572	.1372	.2229	.1677	.1143	.1143
Avg	1.0914	.4353	1.1063	.2401	.9701	.3588	.8106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 203 / CHITGIRI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.442				.4877	.4572	
2	.442				.4725	.4572	
3					.4877	.4572	
4	.4877				.5182	.4725	
5	.5182				.5335	.5335	
6	.5335	.7202		.6859	.6097	.5487	
7	.5487		.4001		.5639	.5792	
8	.4268				.4877	.503	.3658
9	3.8923		.3201		.3048		
10			.381		.3048		.3201
11		3.5151	.3506		.3201		
12	3.9438		.3506		.3201		
13		2.713	.3353		.3353		.3658
14			.3201		.3506		.3658
15					.381		.3506
16		3.2026	.3429		.3658	.2972	.3506
17					3.9247		3.7342
18	.4287		3.9438		3.9247	3.2808	3.6389
19					3.9057		3.5437
20			***				3.2579
21		.4344					
22			3.4294			2.7183	
23	.5658						
24	.4877	.5658	.3429	3.1722	3.3532	3.0864	2.4691
Max	3.9438	3.5151	37.8944	3.1722	3.9247	3.2808	3.7342
Min	.4268	.4344	.3201	.6859	.3048	.2972	.3201
Avg	1.0598	1.8585	4.0343	1.9291	1.0976	1.1159	1.7057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 201 / AMBALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365		.8048		.8684	.7712
2	.5533		.8048		.9282	.8215
3	.5365		.8215			.8383
4	.5365		.8383		1.0159	.8383
5	.5365		.8383			.8383
6	.5365		1.1401			1.1065
7	.4359	.4115	1.3413			1.4083
8	.4359	.4115	1.3077	1.5402	1.3757	1.2574
9	.3856	.4287	1.4251			1.2407
10	.3018	.4287	1.3748		1.1203	.3353
11	1.3413	1.5927			.3018	.3688
12	1.3717				.3353	
13	1.4327				.3018	
14	1.3413	1.5089			.3521	
15	1.0364	1.5257			.3688	
16	1.1888	1.1065		.3921	.3688	
17	1.3108	.2683				
18	1.2803	1.1233			.3856	
19	.5144	.5533		.5914	.503	
20	.6001	.6036			.5868	
21	.6001	.6203			.6371	
22	.6001	.6203			.6203	
23	.6173	.5868		.7095	.6036	
24	.5533	.583	.57		.6653	.57
Max	1.4327	1.5927	1.4251	1.5402	1.3757	1.4083
Min	.3018	.2683	.57	.3921	.3018	.3353
Avg	.7743	.7733	1.0242	.8083	.6299	.8662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 202 / HADGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.656	1.7318	1.7737			1.9004
2	3.6315	1.6804	1.7194			1.8099
3	3.5754	1.6804	1.6651			1.7918
4	3.5821		1.7737			1.8099
5	3.628	1.6461	1.828			1.8099
6	3.7738	1.6461	1.8099			1.9004
7	3.7711		1.7194			1.8642
8	3.5091		1.5927	1.6476	1.7194	1.8823
9	3.1647		1.5746			1.7375
10	3.2472		1.5384		1.5223	1.7737
11	3.1321	1.448			1.4842	1.7194
12	3.1074				1.3748	
13	3.1402				1.4754	
14	3.1527	1.5384			1.6651	
15	3.0845	1.4842			1.7013	
16	3.2316	1.6289		1.5775	1.6651	
17	3.3376	1.7013			1.9185	
18	3.5966	1.7737			1.7737	
19	3.7685	1.9366			1.9004	
20	4.0093	1.9185			2.0271	
21	2.1468	1.9366			2.0271	
22	1.9151	1.9728			2.0995	
23	2.649	1.9185		1.97	2.009	
24	3.8915		1.7737		1.8804	1.9185
Max	4.0093	1.9728	1.828	1.97	2.0995	1.9185
Min	1.9151	1.448	1.5384	1.5775	1.3748	1.7194
Avg	3.3209	1.7276	1.7062	1.7317	1.7652	1.8265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 203 / BELMANDAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6872	1.0669	.7842		.5601
2	1.6461	1.0669	.7842		.5601
3	1.7185	1.2193	.7842		.5601
4	1.7185	1.4327	.7842		.5975
5	1.7497	1.4937	.8215		.5975
6	1.9608	1.5242	.7655		.5975
7	1.9925	1.5242	.6535		.4854
8	1.9685	1.5242	.6535	.5415	.4481
9	1.9372	1.5546	.4294		.3734
10	1.7375	1.6156		.4668	1.6324
11	.3429			1.7497	2.0005
12	.3429			1.8435	
13	.3772			1.7185	
14	.4115	.5228		1.7497	
15	.4115	.5601		1.7654	
16	.3772	.4481		1.6461	
17	.3772	.4668		1.6766	
18	.4115	.5228		1.7985	
19	.6516	.7095		.7095	
20	.7202	.7842		.7095	
21	.6859	.8589		.7842	
22	.6859	.8402		.6722	
23	.6859	.8029		.7095	
24	.7842	.6859	.7842	.7392	.6535
Max	1.9925	1.6156	.8215	1.8435	2.0005
Min	.3429	.4481	.4294	.4668	.3734
Avg	1.0576	1.0107	.7244	1.2050	.7555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 204 / WATEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2498	1.2193	.4904		.4904
2	1.2498	1.2193	.4904		.4904
3	1.2955	1.2193	.4904		.4715
4	1.326	1.3413	.5281		.5093
5	1.4022	1.3717	.5658		.5658
6	1.5741	1.4632	.6602		.6602
7	1.781	1.5242	.547		.5658
8	1.7966	1.5242	.3353	.4481	.4527
9	1.7593	1.5242	.3395		.3772
10	1.7071	1.5242	.2829	.3361	
11	.3086	.3206		1.4632	1.6644
12	.3086			1.6358	
13	.3086			1.448	
14	.3086	.3395		1.4937	
15	.2743	.3961		1.4632	
16	.2401	.3018		1.5851	
17	.3086	.3018		1.6309	
18	.3429	.415		1.448	
19	.4801	.5281		.4904	
20	.4801	.547		.5281	
21	.3429	.547		.5658	
22	.3429	.5281		.5658	
23	.4458	.4904		.5228	
24	.4904	.4458	.4904	.4854	.4854
Max	1.7966	1.5242	.6602	1.6358	1.6644
Min	.2401	.3018	.2829	.3361	.3772
Avg	.8385	.8678	.4746	1.0069	.6121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 205 / KOTHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8865	.8573	1.7695		1.8351
2	.8676	.8573	1.9662		1.8785
3	.8865	.8573	1.9989		1.8461
4	.9054	.8573	1.9989		1.8461
5	.9619	.8916	2.0153		1.8299
6	.9431	.8916	2.13		2.0317
7	.7167	.8573	2.4249		2.2119
8	.5658	.8573	2.0481	2.2138	2.2874
9	.5281		2.0972		2.42
10	.415				.4904
11	2.3167	2.6852			.5281
12	2.6673			.5658	
13	2.7435			.5847	
14	2.4387	2.7515		.6036	
15	2.5301	2.7515		.6413	
16	2.3472	2.7846		.5658	
17	2.4387	2.556		.5281	
18	2.0729	2.3266		.5281	
19	.7202	.7922		.7167	
20	.823	.8676		.9054	
21	.823	.9431		.9808	
22	.7888	.9431		.9619	
23	.7888	.9054		.9242	
24	.9054	.7888	.9054	.8962	.9054
Max	2.7435	2.7846	2.4249	2.2138	2.42
Min	.415	.7888	.9054	.5281	.4904
Avg	1.3367	1.4011	1.9354	.8297	1.6759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 206 / KOTHALA WW EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-APR-17	30-APR-17	01-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0488		
2	.0488		.0472		.0335
3	.0518	.0427	.0472		.0335
4	.0518	.0427	.0457		
5		.0412	.0457		
6	.0427	.0427	.0412		.0442
7	.0427				.0305
8	.0427		.0442	.0343	.0274
9	.0442				.029
10	.0442		.0442	.0316	.0396
11	.048			.0335	.0381
12				.0335	
13				.0381	
14		.0412			
15	.048	.0396			
16	.0463				
17	.0446				
18	.0463				
20				.0335	
21		.064			
22				.064	
23				.0427	
24	.0518			.0381	
Max	.0518	.064	.0488	.064	.0442
Min	.0427	.0396	.0412	.0316	.0274
Avg	.0467	.0449	.0455	.0388	.0345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 207 / DAVAKHANA EXPRESS

Feeder KV- 11 / OUTGOING

DATE	04-MAY-17
HR	Load (MW)
20	.0293
Max	.0293
Min	.0293
Avg	.0293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 201 / WAIPANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.1949	.9335	.6097	.9431	1.1203	.6668
2	1.294		.9149	.7621	.9431	1.0288	.6668
3	1.7307		.9149	.7621	.9431	1.1317	.7621
4	2.156	1.5497	.9335	.8573	1.0374	1.1949	.8002
5	2.6116	1.7924	.9335	.9526	1.1317	1.2449	.9526
6	3.0369	1.7295	1.0374	1.1431	1.0374	1.3443	.9907
7	3.2624	1.7364	1.1203	1.1812	.9431	1.1763	1.0479
8	3.0529	1.5123	1.1203	.9526	.9431	.9709	.7621
9	3.2106	1.6804		.9526	.8488	.6535	
10	3.1661	1.7177			.7545	.5716	1.3413
11	1.6341	.5658	1.7147		2.0748	1.5242	
12	.3338	.5847	2.2862		2.2257	1.9052	.0838
13		.5658	1.9052		2.2131	1.7147	2.0119
14	1.0146	.5658	1.7147		2.3152	1.5242	1.8652
15	.9964	.6602	1.5242		2.268	1.5242	1.8442
16	.9625	.7733	1.7147		2.1399	.7621	1.8652
17	1.2208	.7733	1.9052		2.0119	.7621	1.6766
18	1.2801	.7733	2.2862		1.7924	1.5242	.9326
19	1.4561	1.0562	.7621		1.1694	.7621	1.0059
20	1.6826	1.1694	.7621		1.226	.9526	1.0174
21	1.8221		.9526		1.2071	.9907	1.0059
22	1.7989	.9431	1.0479		1.1523	.9526	1.0059
23	1.7646	.9808	1.105		1.1694	.7621	.9221
24	1.4731	1.1576	.9808	1.0479	1.0374	1.1317	.6668
Max	3.2624	1.7924	2.2862	1.1812	2.3152	1.9052	2.0119
Min	.3338	.5658	.7621	.6097	.7545	.5716	.0838
Avg	1.8376	1.1182	1.2986	.9221	1.3970	1.1346	1.0861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 202 / DORLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2864	.7716	.6516	.5716	.7522	.5716
2	1.2735	.763	.6722	.6097	.7682	.5716
3	1.7352	.7888	.6173	.6097	.7682	.6097
4	1.9989	.8402	.6173	.6668	.7682	.6097
5	2.566	.9259	.6173	.6668	.8048	.6287
6	3.2022	1.0288	.6344	.724	.8048	.6668
7	3.7334	1.1317	.6001	.7621	.6584	.5716
8	3.9956	1.2346	.5487	.6668	.5304	.4763
9	3.8889	1.4918	.4801	.3429	.415	.3429
10	3.2152	1.5947	.5716		.5716	1.0174
11	1.7658	.3429	1.9052		1.0479	1.3565
12	.8518	.3772	2.0005		1.4289	1.3565
13	.8442	.3944	1.9052		1.1431	1.3565
14	.8779	.3944	1.8099		1.0479	1.2717
15	.9431	.4239	1.4289		1.0479	1.3565
16	.9976	.4458	1.5623		.5716	1.3565
17	1.0113	.5658	1.7147		.381	1.3565
18	1.0448	.5426	1.5242		1.0479	.5087
19	1.0692	.703	.6668		.381	.6783
20	1.5074	.7122	.5716		.4763	.6783
21	1.6		.5716		.6668	.6783
22	1.5676	.7922	.5716		.5716	.6783
23	1.528	.6859	.5335		.5716	.5935
24	1.3253	.7373	.7468	.5716	.7712	.5716
Max	3.9956	1.5947	2.0005	.7621	1.4289	1.3565
Min	.8442	.3429	.4801	.3429	.381	.3429
Avg	1.8262	.7691	.9801	.6192	.7499	.8277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 203 / TAMSA TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.7316	.6584	.5716	.6401	.7682	.5716
2	.5716	.7133	.6584	.5716	.6401	.7682	.6097
3	.6668	.7133	.6584	.6097	.6001	.7682	.6668
4	.6668	.6516	.6584	.6668	.7316	.7682	
5	.724	.695	.695	.7049	.7316	.7316	.724
6	.8573	.6767	.7316	.7621	.7316	.7316	.7621
7	.8002	.695	.7316	.8573	.823	.823	.7621
8	.7621	.7316	.7499	.7621	.823	.7316	.7049
9	.7621	.7023	.7133		.7316	.6584	.724
10	.695	.6908	.7621	.6668	.7316	.6668	.724
11	.7167	.6401	.7049		.7316	.7049	.6335
12	.7316	.6535	.6668		.7133	.724	.724
13	.7316	.6535	.7049		.7316	.724	.724
14	.7316	.679	.6097		.7316	.7049	.6335
15	.7316	.695	.5716		.7316	.6668	.724
16	.7316	.7316	.6097		.7682	.6668	.6335
17	.7716	.7682	.6668		.7682	.724	.724
18	.823	.823	.7621		.823	.7621	.724
19	.823	.8413	.8002		.8962	.8002	.724
20	.8048	.8402	.7621		.8596	.7621	.724
21	.7842		.724		.8238	.724	.724
22	.7655	.7842	.6668		.8145	.6668	.724
23	.7468	.7468	.6097		.8048	.5716	.724
24	.5716	.7316	.7316	.5716	.6602	.8048	.5716
Max	.8573	.8413	.8002	.8573	.8962	.823	.7621
Min	.5716	.6401	.5716	.5716	.6001	.5716	.5716
Avg	.7309	.7213	.692	.6745	.7518	.7260	.6940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 204 / JAMBHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4344	.5853	.7621	1.0974	.439	.4191
2	.4572	.4481	.8048	.9526	1.0974	.439	.4382
3	.4191	.439	.8048	1.1431	1.4632	.4527	.7621
4	.4191	.4527	1.6278	1.4289	1.4632	.439	.9526
5	.4382	.4481	1.7924	1.7147	1.829	.4938	1.1431
6	.4191	.439	1.8473	2.191	1.829	1.9427	1.2384
7	.362	.3658	1.8656	2.3815	2.1948	2.0668	1.3336
8	.2858	.3109	1.9022	2.3815	2.0119	2.0119	1.5242
9	.2286	.2926	2.1948	2.4768	1.829	.6219	1.6194
10	.1886	.2195	2.0957		1.4632	1.5242	.2486
11	1.6991	1.829	.4572		.2195	.381	.2486
12	.1543	.1886	.381		.2378	.2286	.2486
13	.1543	.2263	.3429		.2561	.2286	.2486
14	.1715	1.5604	.3429		.2743	.2286	.2486
15	.2058	1.4632	.3048		.2743	.2286	.2486
16	2.0919	.8962	.3048		.2743	.2667	.2486
17	2.3525	2.0119	.3048		.2561	.2286	.2486
18	2.3228	1.9376	.2667		.3841	.2096	.3315
19	.3185	.4207	.4572		.439	.381	.3315
20	.5415	.439	.4191		.5121	.4572	.4144
21	.5281		.4191		.5121	.4191	.3315
22	.4854		.381		.4755	.4572	.3315
23	.4572	.2926	.4382		.4572	.4763	.3315
24	.4763	.4572	.2715	.4572	.362	.4572	.4191
Max	2.3525	2.0119	2.1948	2.4768	2.1948	2.0668	1.6194
Min	.1543	.1886	.2667	.4572	.2195	.2096	.2486
Avg	.6514	.7079	.8588	1.5889	.8839	.6283	.5796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 206 / Natraj Exp

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0732	.2149	.0762	.0895	.2561	.1905
2	.1143	.0732	.2195	.0762	.0914	.2561	.1905
3	.0762	.0732		.0762	.0914	.2561	.2286
4	.0762	.0732	.1829	.1143	.0876	.2561	.2477
5	.0572	.0732	.1463	.1524	.0857	.2561	.2667
6	.0572	.0732	.0549	.1524	.0857	.2561	.1905
7	.0572	.0732	.0549	.1334	.0857	.128	.1905
8	.0572	.0732	.0549	.1143	.0857	.1097	.0572
9	.0572	.1052	.0732	.0572	.0857	.1097	.0572
10	.0526	.1075	.0572		.0857	.1143	.0848
11	.0754	.1578	.0572		.1029	.1143	.0848
12	.0732	.1052	.0572		.1029	.1334	.0848
13	.0716	.1075	.0572		.0876	.1524	.0848
14	.0732	.1075	.0953		.0857	.1715	.0848
15	.0732	.0701	.1334		.0914	.1715	.0848
16	.0732	.0686	.1143		.0905	.1334	.0848
17	.0934	.0857	.1143		.0905	.1334	.0848
18	.0857	.12	.1334		.1463	.0381	
19	.0857	.1829	.1143		.1829	.0762	.0848
20	.0934	.2401	.1143		.2195	.1143	.0848
21	.0914		.1143		.2743	.1524	.0848
22	.0934		.0762		.2743	.1524	.0848
23	.0876	.1097	.0762		.2629	.1524	.0848
24	.1715	.0914	.2103	.0762	.0876	.2743	.1715
Max	.1715	.2401	.2195	.1524	.2743	.2743	.2667
Min	.0526	.0686	.0549	.0572	.0857	.0381	.0572
Avg	.0817	.1020	.1099	.1029	.1239	.1653	.1258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 201 / KOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5175	.5144	.5487	.5914	.9602	.9602
2	.5487	.5175	.4801	.5487	.5914	.9602	.9602
3	.5487	.5175	.4801	.5487	.5914	.9602	1.0288
4	.583	.5487	.5144	.583	.6219	1.0288	1.1317
5	.6516	.5853	.5144	.6516	.695	1.2689	1.2003
6	.7545	.6219	.5487	.7202	.7682	1.3717	1.3032
7	.583	.5487	.6516	.6516	.6878	.8573	1.0631
8	.583	.439	.5487	.5144	.5792	1.0631	1.0288
9	.4801	.4706		.4458	.5068	.8916	.5144
10	.4458	.4706	.5144	.3772	.5121	.7888	.583
11	.4344	.4115	.4115	.3982	.4801	.7202	.5487
12	.4344	.4115	.4458	.3982	.4801	.6859	.4755
13	.4344	.4801	.4458	.439	.4458	.6859	.4435
14	.5068	.4458	.4458	.4755	.4458		.4435
15	.5068	.4458	.4458	.4755	.4458		.4435
16	.5068	.4458	.4458	.5121	.4458		
17	.5121	.4458	.4801	.5121	.5144	.8916	
18	.5121	.4801	.5487	.5792	.583	.9945	.6516
19	.695	.583	.7202	.7602	.6859	1.3375	.7964
20	.8048	.583	.6859	.7602	.6859	1.2346	.8048
21	.7316	.6173	.6516	.695	.6516	1.1317	.7392
22	.6653	.6173	.6173	.6653	1.0288	1.0631	.7023
23	.5544	.583	.583	.6283	1.0288	.9259	.6653
24	.583	.5175	.583	.583	.5914	.9602	.9945
Max	.8048	.6219	.7202	.7602	1.0288	1.3717	1.3032
Min	.4344	.4115	.4115	.3772	.4458	.6859	.4435
Avg	.5670	.5127	.5338	.5613	.6108	.9896	.7947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 202 / DHANORA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4632	1.0745	1.5912		1.5242
2			1.4632	1.0745	1.5912		1.5242
3			1.4937	1.1203	1.5912		1.5242
4			1.4937	1.1431	1.6575	1.6461	1.6156
5			1.5242	1.2346	1.9662	1.7147	1.6766
6			1.6766	1.2574	2.2939	1.7375	1.7375
7			1.6766	1.5775	2.3594	1.7833	1.9814
8			1.6461	1.5546		1.7833	2.1338
17	2.7854	1.5546					
18	2.7854	1.6766					
19	2.4577	1.8595					
20	2.2939	1.7071					
21		1.6156					
22		1.5242					
23		1.5242					
24	1.3717		1.5242				
Max	2.7854	1.8595	1.6766	1.5775	2.3594	1.7833	2.1338
Min	1.3717	1.5242	1.4632	1.0745	1.5912	1.6461	1.5242
Avg	2.3388	1.6374	1.5513	1.2546	1.8644	1.7330	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 203 / VARULA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.4918					
2	1.0059						
3	1.0517						
4	1.0974						
5	1.1431						
6	1.2574						
7	1.3717						
8	1.3717						
9			1.7375	1.2574	1.6385	1.3717	1.829
10			1.829	1.2803	1.8023	1.2574	1.7985
11				1.8023	1.2117	1.5242	1.989
12		1.0669	1.2574	1.8023	1.2117	1.4632	1.9662
13			1.3032	1.8351	1.1888	1.4327	1.9334
14			1.3032	1.8679	1.1888		1.8023
15			1.3032	1.8351	1.2574		1.8023
16			1.3032		1.2803		1.8023
24			1.3717				
Max	1.3717	1.4918	1.829	1.8679	1.8023	1.5242	1.989
Min	1.0059	1.0669	1.2574	1.2574	1.1888	1.2574	1.7985
Avg	1.1631	1.2794	1.4261	1.6686	1.3474	1.4098	1.8654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 204 / Yelamb

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.6401	1.1469					
10	.6173	1.2452					
11	1.5223	1.2193					
12		1.2498					
13		1.2803					
14		1.3108					
15	1.4575	1.3108					
16	1.3603	1.3413					
17			1.3717	.8848	.9602	1.0669	1.6194
18			1.3717	1.8023	.9374	1.4632	1.6461
19			.2286	1.7814	1.0745	1.2498	1.4746
20			.2286	1.6385	1.0059	1.2193	1.3763
21			.2743	1.4918	.9602	1.1584	1.3923
22			.3429	1.326	.9374	1.2193	1.3592
23			.4344	1.2266	.9145	1.2193	1.326
24				.3658	1.2266	.8002	1.2193
Max	1.5223	1.3413	1.3717	1.8023	1.2266	1.4632	1.6461
Min	.6173	1.1469	.2286	.3658	.9145	.8002	1.2193
Avg	1.1195	1.2631	.6075	1.3147	1.0021	1.1746	1.4267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 205 / NIWGHA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4066	.3429	.3086	.3696	.3429	.3429
2	.3086	.3696	.3429	.3086	.3696	.3429	.3429
3	.3086	.3696	.3429	.3086	.3696	.3429	.3429
4	.3429	.4024	.3429	.3429	.4066	.3772	.3772
5	.3772	.4024	.3772	.3772	.439	.4115	.3772
6	.4115	.4024	.4115	.4115	.4755	.4115	.4115
7	.3772	.3658	.4115	.4458	.4344	.4115	.3772
8	.3772	.3658	.3429	.3772	.3982	.3772	.4115
9	.3086	.3258	.3772	.3429	.3982	.3429	.3772
10	.2743	.2896	.3772	.3086	.439	.3429	.3772
11	.2896	.2743	.3772	.3258	.4115	.3429	.4024
12	.2896	.3429	.3086	.3292	.4115	.3429	.439
13	.3258	.3429	.3429	.3658	.3772	.3429	.4024
14	.362	.3429	.3429	.439	.3772		.4435
15	.362	.3429	.3086	.4024	.3772		.4435
16	.3982	.3772	.3086	.3658	.3772		
17	.4024	.3429	.3429	.4024	.3772	.4115	
18	.4024	.3772	.3772	.4344	.3772	.5144	.543
19	.439	.4115	.4115	.4706	.4115	.5144	.5487
20	.439	.4458	.4458	.4706	.4458	.5144	.5487
21	.439	.4115	.4115	.4435	.4115	.4801	.5175
22	.4066	.4115	.3772	.4435	.4115	.4458	.4805
23	.4066	.3772	.3772	.4435	.3772	.4115	.4435
24	.3429	.4066	.3772	.3086	.3696	.3429	.3772
Max	.439	.4458	.4458	.4706	.4755	.5144	.5487
Min	.2743	.2743	.3086	.3086	.3696	.3429	.3429
Avg	.3639	.3711	.3658	.3824	.4005	.3984	.4240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 206 / KOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5175	.4458	.4458	.5175	.4458	.4458
2	.4115	.5175	.4458	.4458	.5175	.4458	.4458
3	.4115	.5175	.4801	.4458	.5175	.4801	.5144
4	.4458	.5487	.5144	.4801	.5487	.5144	.583
5	.4801	.6219	.583	.5487	.6219	.5487	.6173
6	.583	.695	.6516	.5487	.695	.5487	.6516
7	.5144	.6219	.5487	.583	.6154	.5144	.5487
8	.4458	.5487	.5144	.4801	.543	.4801	.4115
9	.4115	.4706	.4115	.4115	.5068	.3772	.4801
10	.3772	.362	.4801	.3772	.4755	.3086	.3772
11	.362	.3429	.3086	.3982	.4115	.3429	.4024
12	.362	.3429	.3772	.3982	.4115	.3429	.439
13	.362	.3772	.3772	.4024	.3772	.3429	.4066
14	.3982	.3772	.3429	.439	.3429		.4435
15	.3982	.3772	.3429	.439	.3429		.4435
16	.3982	.3772	.3429	.439	.3429		
17	.439	.4458	.3772	.439	.3772	.4115	
18	.4755	.4801	.4115	.5792	.4115	.5144	.5792
19	.5853	.5144	.6173	.6516	.583	.583	.7316
20	.6219	.5144	.583	.6516	.6173	.583	.7316
21	.5487	.4458	.5487	.6283	.5487	.5487	.7023
22	.5175	.4801	.5144	.5914	.4801	.4801	.5544
23	.5175	.3772	.4801	.5544	.4458	.4458	.5175
24	.4801	.5175	.4458	.4458	.5175	.4458	.4458
Max	.6219	.695	.6516	.6516	.695	.583	.7316
Min	.362	.3429	.3086	.3772	.3429	.3086	.3772
Avg	.4580	.4746	.4644	.4927	.4904	.4621	.5215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 201 / LINGAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.139	1.2723	.114	.1274	.1567	.1249	.1171
2	.139	1.3632	.1115	.1288	.1567	.155	.1174
3	1.3203	1.3632	.1238	.136	.155	.1281	.1174
4	1.4232	1.3984	.141	.1433	.1484	.1349	.1171
5	1.4967	1.4177	.161	.1576	.1686	.1628	.1303
6	1.6414	1.4623	.1786	.1679	.2105	.1886	.1564
7	1.781	1.4708	.1536	.163	.1551	.1538	.1433
8	1.6804	1.5449	.1275	.1589	.1433	.1043	.1189
9	1.6804	1.3632	.1147	.1288	.1186	.1238	.1083
10	1.5951	1.2723	.124		.1155	.1786	.0768
11	.1119	.0928	1.5638	1.6804	1.7382	1.3863	1.5089
12		.2148	1.5668	1.751	1.6391	1.6065	1.2771
13	.1031	.0963	1.5513	1.4118	1.5346	1.4296	1.3303
14	.0926	.0867	1.4377	1.1216	1.5257	1.4311	1.316
15	.0889	.0951	1.4391	1.1229	1.4918	1.4157	.9346
16	.0981	.0932	1.5181	.2181	1.6193	.0682	1.2514
17	.1082	.0937	1.5513	.0966	1.6512	.1006	1.2572
18	.2455	.1128	1.5498	1.8652	1.5475	1.2294	1.278
19	.1749	.1322	.1454	.1424	.1289	.1143	.1113
20	.1734	.1738	.1018	.1511	.1115	.1353	.1626
21	.1337	.1618	.141	.1421	.1281	.1215	.1543
22	.136	.1472	.1144	.1396	.1397	.1218	.1446
23	.1208	.1482	.1292	.1658	.1315	.1221	.134
24	.144	.1619	.1482	.1288	.1339	.1281	.1221
Max	1.781	1.5449	1.5668	1.8652	1.7382	1.6065	1.5089
Min	.0889	.0867	.1018	.0966	.1115	.0682	.0768
Avg	.6360	.6558	.5962	.4978	.6271	.4527	.5077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 202 / ASHTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1956	.7322	1.0265	1.0488	1.0542	1.1192	1.1134
2	2.2073	.721	1.0607	1.0741	1.0442	1.1375	1.1145
3	2.6608	.7322	1.1279	1.1145	1.1283	1.0746	1.1145
4	2.727	.737	1.1666	1.2124	1.1623	1.1742	1.1123
5	3.1064	.7629	1.1463	1.2423	1.1814	1.1996	1.2099
6	3.6984	.7531	1.2489	1.3817	1.3539	1.1996	1.319
7	4.4337	.7691	.9923	1.3216	1.167	.727	1.1088
8	4.2414	.7956	1.0265	1.0424	1.0123	.6361	1.03
9	3.7915	.6363	.787	.925		.7186	.8385
10	3.7321	.8431	.8376	.7438		.7699	
11	2.0788	.7423	1.9479	1.7814	1.7709	1.7366	1.9989
12	1.3821	.7052	1.985	1.9204	1.7433	1.8375	1.8862
13	1.4467	.7034	1.941	1.9528	1.9033	1.8331	1.5432
14	1.5112	.6843	1.5642	1.7745	1.8564	1.6404	1.5261
15	1.6057	.7186	1.6704	1.3337	1.8785	1.6444	1.4914
16	1.4299	1.1634	1.7415	.6972	1.9675	.6481	1.2514
17	1.487	1.4542	1.9457	.7438	2.1386	.8188	1.8976
18	1.73	1.3687	1.9695	2.0147	1.9319	1.8592	1.8701
19	2.3278	1.0265	1.2173	1.2722	1.1678	1.2124	1.1248
20	2.6055	1.0436	1.2909	1.2446	1.2736	1.2657	1.3402
21	2.4917	1.095	1.2696	1.226	1.3086	1.2593	1.1901
22	2.3472	1.1121	1.2111	1.1763	1.2723	1.1888	1.1529
23	2.3296	1.1647	1.1157	1.0542	1.1451	1.1481	1.5432
24	2.3107	1.0542	1.1494	1.1145	1.036	1.0409	1.1123
Max	4.4337	1.4542	1.985	2.0147	2.1386	1.8592	1.9989
Min	1.3821	.6363	.787	.6972	1.0123	.6361	.8385
Avg	2.4949	.8966	1.3516	1.2672	1.4317	1.2037	1.3430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 204 / YEOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7839	.8724	1.0031	.8207	1.204	.527	1.0288
2	1.7923	.8761	1.0869	.8376	1.3636	.4549	1.2346
3	1.7992	.856	1.1003	.8207	1.442	.4362	1.2513
4	1.7566	.8435	1.1454	.8376	1.6461	.5453	1.2026
5	1.8985	.9031	1.1564	.8462	1.9319	.727	1.5813
6	2.0655	.9887	1.5656	.8624	1.9409	2.2128	1.801
7	1.9689	.9012	1.8564	1.5016	2.0705	2.3533	2.1811
8	1.6394	.7807	1.9443	1.5404	2.2401	2.1811	1.7284
9	1.4013	.7259	2.1712	1.9528	2.3405	2.0409	1.8409
10	1.1987	.5944	2.0418	1.9913	2.2862	2.1226	1.5764
11	4.5463	2.1271	.4859	1.9802	.4435	2.0338	1.4643
12	1.2301	.5981	.526		.4918	.4234	.3254
13	1.2688	.5828	.5613	.4281	.494	.4488	.4329
14	1.2543	.9459	.5255	.482	.526		.3743
15	4.5332	1.1416	.5613		.518	.5319	.4077
16	5.1176	1.3062	.6335		.5201	.4572	.4211
17	5.3776	2.0246			.5228	.4047	.4547
18	5.3376	2.0899		.5774	.5453	.503	.4835
19	3.8927	1.6309	1.6684	.6798	.5816	.6321	.6108
20	1.9357	.9133	1.0402	.7103	.6375	.7049	.6762
21	1.8808	.9459	1.0413	.6057	.616	.6303	.737
22	1.8961	.9785	.8944	.5356	.5816	.7234	.7695
23	1.9331	.957	.8198	.618	.618	.6935	.6289
24	1.8437	.9088	.9035	.7818	.5948	.5998	.6675
Max	5.3776	2.1271	2.1712	1.9913	2.3405	2.3533	2.1811
Min	1.1987	.5828	.4859	.4281	.4435	.4047	.3254
Avg	2.4730	1.0622	1.1242	.9705	1.0899	.9734	.9950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 201 / BARADSHEWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.142		1.5508	1.9208	2.0576	1.1843	1.1498
2	1.142	1.0974	1.6213		2.0576	1.1702	1.1498
3	1.1279	1.0974	1.6213	1.989	2.1262	2.1148	1.488
4	1.2548		1.6636		2.4006	2.1148	1.6909
5	1.3112	1.2346	1.9315	2.1674	2.6063	2.1289	1.8667
6	1.4944	1.3717	2.5377	2.6377	1.3717	2.6928	2.2184
7	1.3112	1.358	2.7633	.9334	2.7161	2.8197	
8	1.1561	1.166	2.5941	1.0822	2.6749	2.862	
9	1.0574	.9602	2.6364	1.4609	2.7435	2.5941	2.2539
10	.9023	.8459	2.7774		2.8807		1.0425
11	.7545	2.7069	.8116		.0846	.7305	.8505
12	.823	.8882	.7846	.6173	.86		.8916
13	.7545	.8882	.7846	.823	.8882	.744	.8916
14	.7545	2.9184	.771	.6173	.86	.8116	.8916
15	2.8121	3.0171	.8387	.8505	.8459	.8387	.8916
16	3.0178	3.0876	.8792	.8505	.8459	.8387	.9602
17	3.0864	3.0876	.9334	.9602	.8459	.8251	.9877
18	2.9492		1.3321	1.0288	.9164	.8792	.9602
19		1.4803	1.7177	1.2346	1.283	1.258	1.2346
20	1.5089	1.3112	1.2986	1.3032	1.3253	.6493	1.2346
21	1.166	1.2548		1.2894	1.2689	1.2851	1.2346
22	1.2346			1.262	1.2971	1.2174	.1097
23	1.1248	1.0292			1.2125	1.1633	1.0974
24	1.1843	1.0974	1.7147		1.0974	1.1843	
Max	3.0864	3.0876	2.7774	2.6377	2.8807	2.862	2.2539
Min	.7545	.8459	.771	.6173	.0846	.6493	.1097
Avg	1.4378	1.5949	1.5983	1.2793	1.5528	1.4594	1.1950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 202 / PALSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 203 / SIBDARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9114		.9114	.9114	.8764	.9114	.6661
2	.9114	.5258	.9114		.8764	.964	.6661
3	.7712	.5258	.9114	.9114	.8764	.9114	.6661
4	.9114		.9114		.8764	.9114	.6661
5	.9816	.5258	.9816	1.0166	.8764	.9114	.6661
6	1.1218	.6135	.8413	1.0517	1.0517		.7011
7	1.3321	.8764	.7712	.9114	.8764		.7712
8	1.3321	.964	.8413	.5411	.7888		.7011
9	.9816	.8764	.631	.7011	.7011		.4908
10	1.1218	.7011	.7011		.5258		.3856
11	.8764	.5609	.9816	1.0867	.9114		.964
12	.5258	.5609	.964	1.2269	.8413		.964
13	.7011	.631	.9816	1.0517	.8413	.7011	.8764
14	.7011	.631	1.0517	.964	.8413	.8322	.8764
15	.5258	.631	.9816	1.0517	.8413	.8413	.8764
16	.6935	.631	1.0517	.7011	.9114		.964
17	.7011	.631	1.1218	.7011	.9816	.8413	1.0517
18	.7011		1.2955	1.2269	1.0517	.8413	.7011
19		.9816	.9816	.964	.9114	.9816	.8764
20	1.0867			1.0517	.9114	.8413	.8764
21	1.0517	.8413		1.0517	.8413	.8413	.7011
22	1.0517	.9114		1.0517	.9816	.8413	.7011
23	.8764	.9114			.9114	.7011	.7011
24	.9816	.964	.9114		.8764	.9114	
Max	1.3321	.9816	1.2955	1.2269	1.0517	.9816	1.0517
Min	.5258	.5258	.631	.5411	.5258	.7011	.3856
Avg	.9065	.7248	.9368	.9565	.8742	.8616	.7613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 204 / GOPAL COTTON EXPRESS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572		.0381
2		.0572		.0381
3		.0572		.0381
4		.0572		.0381
5		.0572		.0381
6		.0572		.0381
7		.0572		
8		.0572		
9		.0572		
11	.0572			
12	.0572			
13	.0381		.0572	
14	.0572		.0572	
15	.0572		.0572	
16	.0572		.0572	
17	.0572		.0572	
18	.0572		.0572	
19	.0762		.0572	
20			.0762	
21			.0381	
22			.0381	
23			.0381	
Max	.0762	.0572	.0762	.0381
Min	.0381	.0572	.0381	.0381
Avg	.0572	.0572	.0537	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 201 / TALNI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0301	.0301	.3921	.3612	.3161	.3612	.3161
2		.0301	.3921	.3612	.3161	.3612	.3161
3		.0301	.3921	.3612	.4064	.3612	.4064
4		.0301	.4481	.4064	.4064	.4064	.4064
5	.0301	.0301	.4481	.4064	.4515	.4064	.4064
6			.5601	.4967	.4515	.4064	.4515
7			.5601	.4967	.4515	.4515	.4515
8			.5601	.4967	.4515	.4515	.4515
9			.5418	.4515	.4515	.4515	.5601
10			.5418	.4515			.4515
11	.5371	.4967					
12	.7004	.4967					
13	.4923	.4515					
14		.4515					
15	1.0177	.4515					
16	1.0292	.4515					
17	1.1092	.4515					
18	.7232	.4064					
19	.7164						
20	.3121						
23	.0339						
24	.0301		.0187		.0151	.0151	.0151
Max	1.1092	.4967	.5601	.4967	.4515	.4515	.5601
Min	.0301	.0301	.0187	.3612	.0151	.0151	.0151
Avg	.5201	.2929	.4414	.4290	.3718	.3672	.3848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 202 / SHIVOOR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037		1.2323	1.2197	1.3306	1.3306	1.2197
2			1.2323	1.2197	1.3306	1.3306	1.2197
3			1.2197	1.2197	1.4415	1.3306	1.3306
4			1.3306	1.4415	1.4415	1.3306	1.3306
5	.037		1.3306	1.4415	1.4969	1.2197	1.3306
6			1.4415	1.6632	1.7187	1.2752	1.3306
7			1.4415	1.6632	1.7187	1.8296	1.3306
8			1.4415	1.6632	1.9404	1.8296	1.3306
9			1.386		1.885	1.6632	1.4003
10			1.386	1.4415			1.4415
11	1.5708						
15		1.386					
16	1.6632	1.386					
17	1.9404	1.386					
18	.037	1.4415					
22	.037						
24			.0187	.037	.037	.037	.037
Max	1.9404	1.4415	1.4415	1.6632	1.9404	1.8296	1.4415
Min	.037	1.386	.0187	.037	.037	.037	.037
Avg	.7603	1.3999	1.2237	1.3010	1.4341	1.3177	1.2093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 203 / TALNI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.2801	.8402	.8402	1.0082	.9522	.9522
2	.8402	.3734	.8402	.8402	1.0082	.9522	.9522
3	.8402		.8402	.8402	.9522	.9522	.8962
4	1.307	.4668	.9522	.9522	.9522	1.0642	.8962
5	1.4937	.5601	.9522	.9522	1.0082	1.2323	1.0642
6	1.307	.5601	1.0642	1.0642	1.0642		1.2323
7	1.2136	.5601	1.0642	1.0642	1.0642		1.2323
8	1.1203	.5601	1.0642	1.0642	1.0642		1.1203
9	.9335	.5601	.8402	1.0082	1.0642		.9522
10	.8402		.8402	.8962	.7282		.8962
11	.8402	.7842	.0728	.8962	.7282		.8402
12	.7468	.7282	.7282	.8402	.7282		.8402
13		.7282	.7282	.8962	.7842	.8402	.7842
14	.6535	.084	.8402	.8402	.7842		.7842
15	.5601	.8402	.8402	.8402	.7842		.7842
16	.5601	.8402	.8402	.8402	.7842		.7842
17	.8402		.8962	.8962		.8962	.7842
18	1.2136	.9522	1.0082		.8962	.8962	.8962
19	1.307	1.2883		1.2323	1.2883	1.2883	1.2323
20	1.1203	1.1763	1.2323	1.4003	1.2323	1.2883	1.2323
21		1.1763	1.2323		1.2323	1.1763	1.2323
22	.9335	1.1203	1.1763		1.1203	1.1763	1.1763
23		1.1203	1.1203	1.0642	1.0642	1.1203	1.1203
24	.5601		1.0642	1.0642	1.0642	1.0082	1.0642
Max	1.4937	1.2883	1.2323	1.4003	1.2883	1.2883	1.2323
Min	.5601	.084	.0728	.8402	.7282	.8402	.7842
Avg	.9513	.7380	.9164	.9682	.9741	1.0602	.9896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 204 / MATALA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17	02-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
10			1.7147
11			1.7147
12			1.7147
18		1.0082	
21		1.2883	
22		1.1763	
24	1.7147		
Max	1.7147	1.2883	1.7147
Min	1.7147	1.0082	1.7147
Avg	1.7147	1.1576	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 201 / Lyhari

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4854	1.3603	1.5223	1.5546	.5601	1.4091
2	.4904	.4854	1.3927	1.5546	1.5684	.5601	1.4746
3	.4904	.4854	1.4575	1.587	1.5684	.5601	1.5402
4	.4904	.5228	1.5223	1.6518	1.6004	.5544	1.6385
5	.4904	.547	1.587	1.7695	1.7394	1.5043	1.7368
6	.5281	.5847	1.9757	2.0972	1.8976	2.0729	2.0972
7	.4904	.4715	1.9524	2.1376	2.0557	2.0805	2.13
8	.3395	.4715	1.9524	2.17	2.0805	2.0729	1.9662
9	.3772	.3584	1.9845	2.1052	2.0005	2.1125	1.9662
10	.3772	.3395	2.0165	1.9757	1.9204	1.9662	.3395
11	2.2672	1.7764	.3395	.3052	.3326	.2713	.3584
12	2.2348	.3772	.3206	.3052	.2987	.3052	.3206
13	2.1376	.3734	.3206	.3052	.3361	.3052	.3395
14	2.17	1.9109	.3206	.3391	.3547	.3052	.3584
15	2.0729	2.1052	.3395	.3052	.3547	.3052	.3395
16	2.0165	2.1376	.3511	.3391	.3696	.3052	.3547
17	2.1376		.3696	.3391	.3734	.3391	.3547
18	2.1376		.4668	.373	.3734	.373	.4294
19	.4668	.4854	.5041	.407	.499	.5087	.4854
20	.5544	.5788	.5415	.5601	.5601	.5087	.5788
21	.5544	.5975	.5487	.5087	.5975	.5087	.5914
22	.5544	.6036	.5487	.5087	.5975	.5087	.5975
23	.5415	.2743	.5544	.5087	.5975	.5087	.5601
24	.5281	.5228	.5415	.5544	.5175	.5788	
Max	2.2672	2.1376	2.0165	2.17	2.0805	2.1125	2.13
Min	.3395	.2743	.3206	.3052	.2987	.2713	.3206
Avg	1.0407	.7498	.9695	1.0096	1.0062	.8198	.9551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 202 / HARDAP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.3435	.4668	.4715	.4527	.4904	.4409
2	1.3765	1.3603	.4481	.4715	.4715	.4904	.407
3	1.4575	1.3603	.4481	.4715	.4715	.4904	
4	1.5223	1.3927	.4668	.4904	.4854	.5281	.407
5	1.5546	1.4575	.499	.4904	.4527	.547	.4748
6	1.6194	1.6842	.4715	.4904	.3772	.5093	.4917
7	1.6842	1.6842	.4108	.3772	.3395	.415	.3052
8	1.7166	1.6842	.2829	.3206	.2614	.2829	.2713
9	1.6194	1.6446	.2241	.2641	.2641	.2641	.2035
10	1.6194	1.7078	.2614	.2452	.2641	.2452	1.2955
11	.2429	.2987	1.9109	1.7368	1.6804		1.4899
12	.3018	.2561	2.0081	1.6385	1.6004		1.6518
13	.3206	.2987	1.8138	1.6385	1.8138		1.5223
14	.3206	.2987	1.6446	1.6385	1.6518		1.5223
15	.3361	.2614	1.4864	1.4746	1.6194		1.5061
16	.2801	.2218	1.5181		1.6194		1.5061
17	.2614	.2614	1.5181		.0914		1.4089
18	.2641		1.531	1.704	1.5223		.3511
19	.415	.4294	.4668	.3932	.415		.415
20	.4904	.4715	.5093	.426	.4668		.5175
21	.4904	.4854	.5041	.426	.5041		.5415
22	.5281	.4904	.4854	.4409	.5093		.5415
23	.5093	.4706	.4854	.4409	.4904		.5228
24	.4904	.4904	.2427	.4854	.4527	.4904	
Max	1.7166	1.7078	2.0081	1.7368	1.8138	.547	1.6518
Min	.2429	.2218	.2241	.2452	.0914	.2452	.2035
Avg	.8632	.8719	.8377	.7516	.7616	.4321	.8088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 203 / PINGALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.4161	.5487	.4641	.4586	.4801	.4586
2	.5441	.4161	.5175	.4641	.4641	.4801	.4586
3	.6081	.4481	.5228	.4481	.4428	.4801	.4586
4	.6401	.4801	.5228	.4481	.4161	.4801	.4428
5	.8642	.5121	.5601	.4641	.4001	.4801	.4744
6	1.1523	.7362	.5975	.4161	.4161	.4961	.4744
7	.7682	1.0242	.4854	.3681	.3201	.4481	.4111
8	1.1683	1.1683	.3734	.3521	.3201	.3041	.3163
9	1.1843	.8322	.3361	.3201	.2881	.2561	.3163
10	1.1203	1.0562	.3174	.2721	.2881		.6401
11	.2241	.208	1.2696	1.1385	1.2003		1.1363
12	.2561	.2241	1.1843	1.1069	1.2651		1.0883
13	.2721	.2561	1.1523	1.1385	1.0753		1.0562
14	.2561	.2561	1.1203	1.1069	1.012		1.0562
15	.2561	.2561	1.0402	.8223	1.012		1.0402
16	.2561	.2561	1.1203		1.012		1.0402
17	.2721	.2881	1.1203		1.1043		1.1203
18	.3041		1.2003	1.3125	1.1043		.3201
19	.4161	.4481	.4161	.4111	.4321		.4902
20	.5121	.5121	.4641	.5218	.5121		.506
21	.5441	.5441	.4801	.5376	.5281		.5441
22	.5121	.5441	.4961	.506	.5121		.5218
23	.4961	.5121	.4961	.4744	.5121		.5218
24	.4801	.4801	.5121	.4801	.4744	.4961	
Max	1.1843	1.1683	1.2696	1.3125	1.2651	.4961	1.1363
Min	.2241	.208	.3174	.2721	.2881	.2561	.3163
Avg	.5675	.5163	.7022	.6170	.6488	.4401	.6475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 201 / JAWALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 202 / VIRSANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5118	.4545	.5892	.6196	.5975	.5228	.4854
2	.5308	.4919	.6176	.5973	.7095	.5041	.4668
3	.4934	.4914	.6161	.598	.7468	.5041	.6161
4	.455	.5297	.6478	.6295	.7468	.5601	.6535
5	.4739	.5481	.6462	.7013	.7655	.6161	.6535
6		.5464	.6447	.7352	.8029	.7655	.7095
7	.4739	.472	.6923	.6807	.8029	.7655	.7842
8	.3981	.3965	.7388	.6718	.7468	.7468	.7095
9	.4175	.3969	.7379	.7772	.5601	.6535	
10	.3223	.2832	.7219	.6287	.7468	.6908	.2987
11	.7665	.7837	.3024	.2987	.3547	.5788	.3174
12	.3012	.3402	.3021	.3361	.3174	.5601	.3791
13	.3772	.3021	.3036	.3361	.3361	.3734	.3784
14	.3398	.6168		.3734		.3547	.3595
15	.681	.6826		.3921	.3547		.3412
16	.7458	.7458			.3547	.3547	.3412
17	.7764	.7458		.3921	.3734	.3551	.3602
18	.8391	.762		.3921	.3734	.3734	.3981
19	.5108	.3587	.5118	.5041	.4854	.5228	.5308
20	.5481	.5292		.5415	.5228	.5788	.5687
21	.5475	.5281			.5228	.5228	.5693
22	.5297	.4899			.4854	.5041	.5687
23	.5292	.3957		.5228	.4668	.4854	.5497
24		.5113	.3768	.5228	.4108	.4854	.5308
Max	.8391	.7837	.7388	.7772	.8029	.7655	.7842
Min	.3012	.2832	.3021	.2987	.3174	.3547	.2987
Avg	.5259	.5168	.5633	.5358	.5471	.5382	.5031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 203 / KAMARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7962	1.1783	.7914	.7938	.7842	.8029	.8402
2	.8341	1.2676	.8307	.816	.7655	.8029	.8215
3	1.2394	1.3001	.8316	.7962	.7655	.8029	.8215
4	1.3001	1.3781	.8119	.759	.7842	.8029	.8215
5	1.3489	1.4592	.8676	.8151	.7655	.8402	.8402
6	1.4351	1.5079	.8488	.891	.8029	.9149	.8402
7	1.4951	1.5382	.6797	.6445	.6348	.6722	.6908
8	1.568	1.5004	.6054	.6445	.5975	.5601	.5601
9	1.7876	1.6557	.5108		.5601	.5228	
10	1.7832	1.3295	.5297	.6445	.4481	.5228	1.6804
11	1.9146	.5108	1.9456	2.2405	2.0165	1.9044	2.2405
12	.4904		1.7988	1.9978		1.8671	1.8884
13	.5287		1.7876	1.9791	1.9418	1.7737	1.6996
14	.5292	.5287	1.6934		1.7177	1.6804	1.69
15	.567	.5281	1.7311	1.2136	1.9231	1.587	1.656
16	.5287	.6212	1.7783	2.0911	1.9805	.4481	1.6681
17	.5658	.603	1.6661	2.2032	2.2032	.4668	1.8144
18	.6036	.5475	1.7101	2.2032	2.0538	2.0538	.7014
19	.8874	.9459	.872	2.1658	.7842	2.0165	.8151
20	.9035	.9063		.9149	.8402		.872
21	.9063	.9223		.8962	.8215	.9149	.8531
22	.8874	.8659		.8589	.8215	.8962	.7352
23	.8676	.8479		.8215	.8215	.8775	.7962
24	.7962	.8496	.8291	.8215	.8029	.8589	.759
Max	1.9146	1.6557	1.9456	2.2405	2.2032	2.0538	2.2405
Min	.4904	.5108	.5108	.6445	.4481	.4481	.5601
Avg	1.0235	1.0360	1.1560	1.2369	1.1146	1.0691	1.1350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 201 / MANATHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 202 / KEDARGUDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.3239	.3239	.4715	.4954	.4572	.5093
2	.4527		.3239	.4715	.4954	.4763	.4904
3	.3944		.3239	.4904	.4763	.4763	.4904
4	.407		.3429	.4904	.4763	.4572	.4904
5	.4748		.3429	.4904	.4954	.4572	.4904
6	.6783		.381	.5093	.5335	.4572	.4904
7	.8122		.2667	.381	.4001	.3429	.381
8	.6882		.2286	.2667	.2858	.2477	.2858
9	.6241		.2096	.2096	.2286	.2096	.2477
10	.5761		.1905	.1905	.1905	.1905	.3048
11	.2096		.1629	.5571	.6539	.3887	.4572
12	.1715		.6464	.5761	.7377	.3563	.506
13	.1715	.1524	.7127	.4843	.6036	.3125	.4218
14	.1905	.1905	.5898	.427	.4862	.2932	.3549
15	.2096	.1715	.506	.4744	.4694	.2972	.2896
16	.1905	.1715	.5535	.2054	.503	.1886	.3593
17	.1905	.3429	.6802	.2096	.7049	.1886	.4534
18	.2286		.6154	.6882	.6203	.3239	.2075
19		.5144	.4715	.4382	.4191	.3584	.4382
20	.5144	.5525	.547	.5525	.5525	.547	.5335
21	.5716	.5716	.547	.5716	.5525	.5658	.5525
22	.5525	.362	.5658	.5525	.5525	.547	.5335
23	.5335	.4191	.547	.5335	.5335	.5281	.5144
24	.5144	.5144	.3239	.5093	.5144	.5144	.5093
Max	.8122	.5716	.7127	.6882	.7377	.5658	.5525
Min	.1715	.1524	.1629	.1905	.1905	.1886	.2075
Avg	.4283	.3572	.4335	.4480	.4992	.3826	.4297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 203 / MALZARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.1543	.2667	.2829	.2858	.2858	.3018
2	.2829		.2667	.2829	.2858	.2858	.3018
3	.197	.1372	.2667	.2829	.2667	.2829	.2829
4	.2126		.2667	.3018	.2858	.2829	.3018
5	.2629		.3048	.3206	.3429	.3395	.3206
6	.3772		.3239	.3584	.4001	.3429	.3395
7	.4372	.25	.3048	.3584	.3239	.2829	.3206
8	.4096		.2477	.2641	.2641	.2263	.2641
9	.4001	.2591	.2096	.2075	.2477	.1886	.2263
10	.4001	.2229	.1886	.1715	.1905	.1886	.2452
11	.1715	.1334	.3521	.2343	.3521	.2241	.4572
12	.1715	.1334	.3605	.3161	.3521	.2401	.3321
13	.1524	.1334	.3077	.2743	.3688	.2846	.3005
14	.1524	.1334	.2343	.2286	.3018	.1981	.2846
15	.1524	.1334	.2881	.216	.2883	.1783	.2561
16	.1715	.1334	.3281	.168	.285	.168	.2968
17	.1715	.1524	.3437	.1715	.3521	.2263	.3593
18	.2286		.4012	.3041	.3018	.2785	.2477
19		.2858	.3206	.3429	.3429	.3018	.362
20	.4001	.381	.3772	.362	.381	.3772	.4001
21	.362	.3239	.3174	.3239	.3429	.3584	.381
22	.3239	.2858	.3395	.3048	.3429	.3395	.362
23	.3048	.2858	.3206	.3048	.3239	.3206	.3429
24	.3018	.3048	.2667	.3018	.3048	.3048	.3018
Max	.4372	.381	.4012	.362	.4001	.3772	.4572
Min	.1524	.1334	.1886	.168	.1905	.168	.2263
Avg	.2751	.2135	.3002	.2785	.3139	.2711	.3162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 201 / LOHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1863	.2829	.2172	.3506	.3708	.4668	
2	.1859	.3658	.282	.3353	.3605	.5544	
3	.3669	.3391	.2858	.3201	.3605	.543	
4	.4501	.3353	.2896	.3125	.4634	.5487	
5	.5407	.3239	.3572	.3125	.5218	.6135	
6	.7202	.4858	.4344	.381	.6308	.6783	
7	.7209	.6249		.4458	.7301	.8097	
8	.5944	.6097	.5716	.6516		.7811	
9	.5944		.5639	.643	.7209	.6097	
10	.6097	.4344	.4344	.8213	.5258	.602	
11	.1848		.1886	.1644	.1867	.1696	
12	.1677	.2543	.1886	.1642	.1867	.2743	
13	.1696		.1886	.1644	.1848	.1829	.5335
14	.1715	.1829	.1886	.1707	.1867	.1867	.5563
15	.1848		.1886	.1701	.1867	.1886	.5487
16	.1867	.1867	.1886	.1701	.1829	.1867	.1867
17	.1848		.1886		.2801		.1886
18	.1867		.1886		.2772		.2801
19	.3772	.2801	.2801	.2758	.3734		.1886
20	.1867		.2829	.2789	.3734		.2801
21	.2801		.2829	.2703	.3696		.3734
22	.2829		.2829	.2795			.3772
23		.2801	.2829	.2758	.3772		.3772
24	.1835	.2829	.2801	.2829	.2838	.3734	
Max	.7209	.6249	.5716	.8213	.7301	.8097	.5563
Min	.1677	.1829	.1886	.1642	.1829	.1696	.1867
Avg	.3355	.3513	.2886	.3291	.3697	.4570	.3537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 202 / CHIKALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9316	.5658	.9335	.7545	.8085	.8488	
2	.811	.5658	.924	.7545	.7453	.8488	
3	.793	.5658	.924	.7545	.7209	.8488	
4	.8359	.5658	1.0269	.7545	.7186	.8488	
5	.7354	.7545	1.0269	.7545	.7438	.7468	
6	.7202	.7545	1.1203	.5658	.8085	.5544	
7	.559	.7545	1.1469	.5658	.5327	.7468	
8	.4668	1.1317	1.326	.5658	.5516	.5601	
9			1.5089	.5658	.539	.5544	
10		.3734	.503	.563	.4715	.462	
11			.4191	1.8694	2.1719	1.6461	
12		1.8671	.9831	1.7013	2.0576	2.0119	
13	.9488		1.2289	1.6495	2.0805	1.7394	.7392
14	1.6194	1.3108	1.1469	1.689	1.8442	1.7814	.7468
15	1.5813		1.1469	1.6512	1.8023	1.7604	.724
16	1.9662	1.4575	1.1469			2.1052	2.8006
17	1.9662		1.4575				2.5911
18			1.9433	2.3792			2.4577
19	1.5813	.9602	1.6194	2.2519	1.4251		.9602
20	1.6385		1.3108	1.0248	1.6766		.9717
21	1.6766		1.3108	1.0248			1.1336
22	1.0174		1.3108	1.0248	.9431		.9335
23		1.0164	.7545	.9002	.9431		.9431
24	.9012	.4715	.9335	.7545	.9031	.9431	
Max	1.9662	1.8671	1.9433	2.3792	2.1719	2.1052	2.8006
Min	.4668	.3734	.4191	.563	.4715	.462	.724
Avg	1.1528	.8744	1.1314	1.1145	1.1244	1.1181	1.3638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 203 / WANWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4692	.5601	.4515	.7011	.9012	.9335	
2	.4744	.5487	.5868	.6783	.8993	.9335	
3	1.1385	.5487	.5868	.6783	1.1157	.905	
4	1.2616	.5601	.602	.6859	1.2087	.905	
5	1.3975	.6554	.724	.8573	1.3932	1.3565	
6	1.6162	.7545	1.1431	1.3413	1.6735	1.3413	
7	1.7078	.9717		1.6766	1.8252	1.6575	
8	1.5261		1.1584	1.6766	1.8576	1.6575	
9	1.3565	1.6385	1.1431	1.6385	1.6169	1.4918	
10	1.2003	1.6004	1.3108	1.8252	1.8652	1.4746	
11	.2601	.2801	.3772	.3643	.2801	.2772	
12	.2601	.2801	.3772	.365	.2801	.2772	
13	.2658		.3772	.3403	.2801	.2801	1.3413
14	.2743	.2801	.3772	.365	.2801	.2772	1.3108
15	.2801		.3772	.365	.2772	.2829	1.3108
16	.2801	.2801	.3772	.3628	.2801	.2829	.2772
17	.2801		.3772	.365	.2801		.3696
18	.2801		.3772	.3628	.462		.3696
19	.5658	.4668	.4715	.5516	.5601		.5658
20	.5658		.4715	.5418	.6535		.6535
21	.5658		.4715	.5607	.6535		.6602
22	.6602		.4715	.5516	.6602		.6602
23		.5601	.4715	.559	.6602		.6602
24	.2586	.5658	.4668	.4715	.4439	.6535	
Max	1.7078	1.6385	1.3108	1.8252	1.8652	1.6575	1.3413
Min	.2586	.2801	.3772	.3403	.2772	.2772	.2772
Avg	.7367	.6595	.5891	.7452	.8503	.8816	.7436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 201 / HIMAYATNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4045	1.39		
2	1.39	1.3676		
3	1.2803	1.3535		
4	1.2936	1.3817		
5	1.2936	1.3535		
6	1.2696			
7	1.2178	1.4118		
8	1.2071	1.2803		
9	1.1584			
10	1.0974			
11	1.2437			
12	1.3306			
13	1.3306			
14	1.2803			
15	1.3352			
16	1.3394			
17	1.2803			
18	1.267			
19	1.448			
20	1.531			
21	1.5364	1.419		
22	1.4632			
23	1.4415			
24	1.4632	1.4415	.0336	.0373
Max	1.5364	1.4415	.0336	.0373
Min	1.0974	1.2803	.0336	.0373
Avg	1.3293	1.3777	.0336	.0373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 202 / SAWANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
23	.9431
Max	.9431
Min	.9431
Avg	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 203 / MANGROOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.9602
Max	.9602
Min	.9602
Avg	.9602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 204 / KHADKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.4877		
2	.3772	.4801		
3	.3307	.4744		
4	.2347	.4687		
5	.2401	.5312		
6	.2622	.6201		
7	.1593			
8	.1509			
9	.1372			
10	.1303			
11	.1296			
12	.1303			
13	.362			
14	.2679			
15	.1783			
16	.2134			
17	.2743			
18	.4687			
19	.4954			
20	.2743			
21	.2896			
22	.2606			
23	.3041			
24	.2858	.2751	.0136	.0136
Max	.4954	.6201	.0136	.0136
Min	.1296	.2751	.0136	.0136
Avg	.2615	.4768	.0136	.0136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 205 / SIRANGINI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174027 / ISLAPUR

Feeder No / Name : 201 / KOSMETH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			1.286	1.1206	1.4746	1.0608	1.0288
9			1.3811		1.3891	1.0288	1.065
10	1.3927						
12		1.3717					
13					1.2237		1.1469
14			1.1852				
15				1.3108	1.323		
18	1.1469	1.3717					
19			1.3811		1.323		
20	1.3108		1.2568		1.3123		
21				1.3108		1.2003	1.2289
22			1.2597		1.1483		
23	1.1469						
24			1.3717				
Max	1.3927	1.3717	1.3811	1.3108	1.4746	1.2003	1.2289
Min	1.1469	1.3717	1.1852	1.1206	1.1483	1.0288	1.0288
Avg	1.2493	1.3717	1.3031	1.2474	1.3134	1.0966	1.1174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174027 / ISLAPUR

Feeder No / Name : 202 / SAHARTRAKUND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.7049	.7049	.8316	.7049	.7011
7		.6468					
8	.6653						
9		.6135	.5992				
10			.6344	.7392	.793		
11					.7049		
12		.7011	.6344				
13					.5287		.6468
14			.6168				
15		.7011		.5544	.5992	.7011	
17			.6344		.5992		
18	.6468	.7011	.5992		.5287	.7011	
19			.6344		.7049		
20	.6468		.7402		.6859		
21				.7392		.7888	.7468
22			.7754		.6859		
23	.7392						
24			.7011				
Max	.7392	.7011	.7754	.7392	.8316	.7888	.7468
Min	.6468	.6135	.5992	.5544	.5287	.7011	.6468
Avg	.6745	.6727	.6613	.6844	.6662	.7240	.6982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174044 / JALDHARA

Feeder No / Name : 201 / JALDHARA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0377	.0686	.0572	.0693	.0566	
2	.0381	.0377	.0686	.0572	.0701	.0566	
3	.0381	.0377	.0686	.0572	.0693	.0566	
4	.0191	.0566	.0686	.0381	.0701	.0566	
5	.0191	.0377	.0686	.0381	.0701	.0566	
6	.0191	.0566	.0686	.0381	.0709		
13	.6036	.6173	.301	.583	.4338	.2469	
14	.5658	.6173	.4161	.6173	.4338	.2743	.0686
15	.5658	.6516	.4214	.6516	.4527	.2824	.0686
16	.6036	.6859	.3864		.4715		.12
17	.6036	.6173	.4458	.583	.4715	.3227	.124
18	.6224	.5144	.4458	.5144	.4527	.2378	.1214
19	.547		.4254	.5144	.4715	.2538	.2279
20	.4904	.4458	.3429	.5144	.4527	.2235	.4607
21	.0377	.0686	.0572	.0686	.0754	.0381	.0701
22	.0377	.0686	.0572	.0686	.0754	.0381	.0709
23	.0377	.0686	.0572	.0686	.0566		.0351
24	.0381	.0377	.0686	.0572	.0701	.0566	
Max	.6224	.6859	.4458	.6516	.4715	.3227	.4607
Min	.0191	.0377	.0572	.0381	.0566	.0381	.0351
Avg	.2736	.2739	.2131	.2663	.2410	.1505	.1367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174044 / JALDHARA

Feeder No / Name : 202 / NANDGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.4904	.4458	.5228	.4557	.4904	.4805
2	.5228	.4904	.4458	.5228	.4508	.4904	.4435
3	.5228	.4904	.4458	.5041	.4557	.4904	.4805
4	.5228	.4904	.4458	.5041	.4557	.5093	.439
5	.5601	.5093	.4801	.5228	.4908	.5093	.4854
6	.5975	.5093	.4801	5.4519	.5258		.4854
10	.3582						
11	.3772	.3429	.3841	.3086	.3961	.3439	
12	.3961	.3429	.4344	.2743	.4338	.3403	.2835
13	.3772	.3429	.3326	.2743	.415	.3582	.2804
14	.3772	.3429	.3658	.3086	.415	.3224	.2804
15	.3772	.3086	.3841	.2743	.415	.3439	.2804
16	.3584	.3086	.3982	.3086	.3395	.2715	.3189
17	.3772	.3429	.439	.3086	.3395	.3801	.3544
18	.415	.4115	.4344	.4458	.415	.439	.0876
19	.6224	.4801	.6099	.5144	.5847	.5975	.4961
20	.6036	.5144	.6468	.5144	.6036	.6161	.5316
21	.6036	.5144	.6161	.5144	.6036	.5975	.5316
22	.5658	.4458	.5544	.4458	.5658	.5914	.4557
23	.5281		.5415	.4458	.5658		.4557
24	.5228	.5281	.4458	.5228	.4557	.5281	.4854
Max	.6224	.5281	.6468	5.4519	.6036	.6161	.5316
Min	.3582	.3086	.3326	.2743	.3395	.2715	.0876
Avg	.4814	.4319	.4665	.6745	.4691	.4567	.4029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 201 / SARSAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9877	.7716	.8573			.9602
2	.8573	.9511	.8573			1.0288	
3	.8573	.9511	.9431			1.1145	
4	.8573	.9511	1.0288			1.2003	
5	.9088	.9877	1.0802			1.3032	
6	.8573	.9877	1.3375	1.4746	1.5775	1.6461	
7	.7716		1.1145	1.7147		1.749	1.7147
8	.6173						
9	.6219	.6173	1.7147	1.6461			
10	.5487	.5487			1.6804		1.5947
11		1.9376			.6516		
12		1.9204			.6344		
13	1.5947				.6344		
14	1.701	1.8176			.6859		.6219
15	1.6301	1.7147			.6859		.5853
16		1.6461			.6516		
17	1.9845	1.5775			.5316		
18	1.701	1.5775	.6859				.8413
19	.9877	.8573	.8916		.8573		
20	.9511						1.1706
21		1.046			1.0288		
22		1.0288					
23	1.0242	.9945			.9945	.9945	
24	.8916	1.0242	.9259		.9945	.9945	.9945
Max	1.9845	1.9376	1.7147	1.7147	1.6804	1.749	1.7147
Min	.5487	.5487	.6859	.8573	.5316	.9945	.5853
Avg	1.0642	1.2062	1.0319	1.4232	.8930	1.2539	1.0604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 202 / TEMBHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2195	.1029	.1029		.1372	.1029
2	.2229	.2378	.1029			.12	
3	.2229	.2561	.1029			.12	
4	.2572	.2561	.12			.12	
5	.2743	.2926	.12			.12	
6	.3429	.3658	.12	.12	.12	.12	
7	.3772		.1029	.0857		.1029	.0857
8	.4458		.0686		.0514		
9	.3658	.3944	.0686	.0514			
10		.4115			.0514		.0732
11					.3772		
12		.0686			.4115		
13	.0549				.3772		
14	.0732	.0686			.3772		.4755
15	.0732	.0686			.2743		.439
16	.0732	.0857		.4115			
17	.0732	.0686			.4801		.439
18	.0732	.0857	.4801				.439
19	.1463	.1029	.12		.12		
20	.1463	.1372					.128
21		.12			.1372		
22		.12					
23	.1463	.12			.1372	.1029	
24	.12	.128	.1029		.1029	.1372	.1029
Max	.4458	.4115	.4801	.4115	.4801	.1372	.4755
Min	.0549	.0686	.0686	.0514	.0514	.1029	.0732
Avg	.1945	.1804	.1343	.1543	.2321	.1200	.2539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 203 / TAKARALA (OLD POTA)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.8779	.6001	.7202		1.0288	.823
2	.8916	.8779	.6516			1.0288	
3	.8916	.8779	.6859			1.0288	
4	.9431	.9145	.7373			1.0631	
5	.9945	1.0242	.823			1.0974	
6	1.0288	1.1523	.9945	1.0288	1.0288	1.286	
7	.9431		1.046	1.3717		1.3717	1.5432
8	.6001		1.2003				
9	.567	.6173	1.5432	1.7147			
10	.2743				1.5432		1.5947
11				.4287	.6001		
12		1.8861			.6859		
13	1.8604				.6516		
14	1.7718	1.5432			.6859		.7316
15	1.829	1.3717			.7202		.7316
16	1.5384	1.5432		.6001			.7133
17	2.1262				.6344		
18	2.1262	.9602	.7716		.3772		.823
19	.9328	.6859	.8059		.9088		
20	1.0059	.9774					.9694
21		.9602			.9945		
22		.9431					
23	.9511	.8916			.8916	.8573	
24	.9431	.9145	.823	.7888	.7888	.8573	.8573
Max	2.1262	1.8861	1.5432	1.7147	1.5432	1.3717	1.5947
Min	.2743	.6173	.6001	.4287	.3772	.8573	.7133
Avg	1.1555	1.0566	.8902	.9504	.8085	1.0688	.9763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 204 / POTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	1.1145
Max	1.1145
Min	1.1145
Avg	1.1145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174063 / APPARAOPETH

Feeder No / Name : 201 / APPARAOPETH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				.7926	
6		.7042	.6573		.7529
12		.5335	.639	.5213	.535
16	.4572				
18			.7876		
19		.7727		.6836	.7011
24	.7202	.4572	.7188	.7482	.7579
Max	.7202	.7727	.7876	.7926	.7579
Min	.4572	.4572	.639	.5213	.535
Avg	.5887	.6169	.7007	.6864	.6867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174063 / APPARAOPETH

Feeder No / Name : 203 / GODJEWALI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.9808	.9362		
10				.5287	.5498
12		1.2483	1.0517		
14	.9808		.9214	1.0145	1.0416
19				.4458	.4287
24	.9602				
Max	.9808	1.2483	1.0517	1.0145	1.0416
Min	.9602	.9808	.9214	.4458	.4287
Avg	.9705	1.1146	.9698	.663	.6734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174095 / Shiwani

Feeder No / Name : 201 / KANCHALI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17
HR	Load (MW)
24	1.1145
Max	1.1145
Min	1.1145
Avg	1.1145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174095 / Shiwani

Feeder No / Name : 203 / DAYAL DHANORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7335	.5792	.6859	.703	.5647
2			.7335	.5647	.6687	.6539	.5647
3			.7335	.5487	.6539	.6706	.5937
4		.5281	.7335	.5487	.6706	.6874	.5792
5		.5868	.7335	.5624	.6539	.6539	.5792
6		.6455	.7922	.5792	.6602		.5647
7			.381				
8			.6562				
9			.7133				
10			.7145				
11	1.0562	.8802	.7716	.7335	.8619	.7727	.8916
12	1.0856	.8949	.7819	.7727	.7716		.8916
13	.9682	.4401	.8025	.7621	.7628	.7922	.8619
14	.9682	.7042	.7727	.7133	.7926	.7529	.8509
15	.9976	.7335	.7621	.7621	.743	.743	.535
16	.9682	.7628	.7529	.7621	.743	.4458	.724
17	.9682	.7628	.823	.743	.7133	.6706	.7628
18		.7628	.8322	.7133	.7727	.5944	.7529
19	.8215	.7922	.7727	.7316	.7133	.7316	.743
20	.8509	.7922	.7926	.7133	.7335	.7727	.7621
21	.8509	.7922	.823	.7621	.7133	.7727	.7499
22	.8802	.7922		.7133	.7133	.7926	.6401
23	.8069		.7133	.7133	.6836	.7727	.5487
24	.6895	.5281	.7335	.6097	.7011	.7011	.6097
Max	1.0856	.8949	.8322	.7727	.8619	.7926	.8916
Min	.6895	.4401	.381	.5487	.6539	.4458	.535
Avg	.9163	.7124	.7417	.6794	.7206	.7047	.6885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 201 / Andegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5144	.8764	.7956	1.2003	1.1336	.8573
2	.5258	.4694	.8573	.8383	1.2003	1.1843	.8573
3	.5201	.4973	.8573	.9724	1.2003	1.2308	.8573
4	.5201	.4694	.8383	.9503	1.2742	1.3108	.8573
5	.5201	.5087	.8383	.9831	1.3435	1.2717	.8573
6	.5201	.5144	1.1469	1.0814	1.3603	1.094	1.1203
7	.3353	.3401	1.3283	1.3927	1.4723	1.0898	1.4232
8	.2652		1.2346	1.4563	1.5203	1.1843	1.4232
9	.2294		1.3889		1.3077	1.186	1.3889
10	.2429		1.4815		1.406	1.186	1.2654
11	1.3748		.2572		.2572	.2321	.2591
12	1.2498		.2572		.2713	.2343	.2591
13	1.3717		.2572		.2883	.2429	.2949
14	1.4022		.2572		.3018	.2785	.2915
15	1.5935		.2543		.3353	.2818	.2486
16	1.6156		.2543	.2984	.3077	.2818	.2515
17	1.5779		.2515		.2753	.3641	.2915
18	1.6956		.3018		.3113	.3641	.3163
19	.5258		.5601		.5601	.5601	.5281
20	.5041		.5601		.5975	.5601	.5658
21	.4854		.5601		.6535	.5601	.5658
22	.5228		.5601		.6722	.5601	.5658
23	.5041		.5601		.6535	.5601	.5658
24	.5601	.5228	.5601	.5601	.6348		.5601
Max	1.6956	.5228	1.4815	1.4563	1.5203	1.3108	1.4232
Min	.2294	.3401	.2515	.2984	.2572	.2321	.2486
Avg	.7995	.4796	.6791	.9329	.8085	.7370	.6863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 202 / TEMBHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3086	.1227	.116	.0343	.0648	.12
2	.3155	.3353	.12	.1174	.0686	.064	.12
3	.3467	.2984	.12	.1174	.0686		.12
4	.4161	.3688	.1174	.1147	.1006		.12
5	.4334	.5087	.1174	.1147	.0983		.12
6	.4681	.4287	.1147	.0983	.112	.1698	.112
7	.503	.4534	.112	.0648	.08	.1341	.0949
8	.4475		.0772		.032	.096	.0949
9	.4915		.0617		.0335	.0633	.0617
10	.4858		.0617		.0343	.0633	.0617
11	.0625		.3772		.5144	.1658	.3239
12	.061		.4287		.4748	.2343	.3887
13	.0762		.4287		.373	.2429	.4096
14	.061		.4287		.4191	.2458	.4372
15	.0781		.39		.4359	.2486	.4807
16	.061		.39		.3887	.2486	.503
17	.0781		.4024		.421	.3467	.4858
18			.4191		.4588	.3467	.4902
19	.1052		.112		.0373	.1307	.132
20	.1307		.1307		.0373	.1307	.132
21	.1494		.1307		.0373	.1307	.132
22	.1307		.1307		.0373	.1307	.132
23	.1307		.1307		.0373	.1267	.132
24	.1307	.1307	.112	.1307		.0373	.1307
Max	.503	.5087	.4287	.1307	.5144	.3467	.503
Min	.061	.1307	.0617	.0648	.032	.0373	.0617
Avg	.2382	.3541	.2099	.1093	.1885	.1629	.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 203 / PARDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.4115	.1753	.2155	.2743	.2591	.12
2	.3856	.4359	.1715	.218	.2743	.2561	.1886
3	.3814	.4641	.1715	.2012	.2401	.2429	.1886
4	.4334	.503	.1677	.1966	.2347	.2294	.1886
5	.4854	.4239	.1677	.1966	.1966	.2374	.1886
6	.5201	.4801	.1638	.1966	.16	.2263	.176
7	.7209	.4858	.16	.1296		.1677	.1581
8	.7293		.108	.096		.128	.1423
9	.7537		.0926			.1107	.1235
10	.7611		.0926			.1107	.1235
11	.125		.5487			.4475	.4858
12	.1372		.6173			.4858	.4858
13	.1219		.6173			.4858	.4915
14	.1219		.6001		.6874	.4915	.4858
15	.1406		.5935		.6706	.4973	
16	.1067		.5935	.6796	.6802	.4973	
17	.1094		.6036		.6154	.6935	
18			.6036		.6554	.6935	.2372
19	.1402		.2241		.7095	.2427	.132
20	.168		.2427		.2241	.2241	.2452
21	.2054		.2427		.2987	.2241	.2452
22	.2241		.2427		.2801	.2241	.2452
23	.2427		.2427		.2987	.2241	.2452
24	.2427	.2427	.1867	.2427	.2987		.2241
Max	.7611	.503	.6173	.6796	.7095	.6935	.4915
Min	.1067	.2427	.0926	.096	.16	.1107	.12
Avg	.3323	.4309	.3179	.2372	.3999	.3217	.2438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 201 / 11 KV MANDVI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAY-17	02-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.2126	.2172	
11	.6935		
12			.5144
13		.7716	
14	.7628		
17		.8817	
20		.3086	
24	.5144	.2126	
Max	.7628	.8817	.5144
Min	.2126	.2126	.5144
Avg	.5458	.4783	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 202 / 11 KV PALSHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
8		1.6301	
11	.2303		
12			.2126
13		.2374	
14	.2303		
17		.2374	
20		.3391	
24	.5144	.2572	
Max	.5144	1.6301	.2126
Min	.2303	.2374	.2126
Avg	.325	.5402	.2126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 203 / 11 KV UMRI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAY-17	02-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.0995	.0995	
11	.6962		
12			.6962
13		.8573	
14	.7293		
17		.7545	
20		.1696	
24	.5144	.1326	
Max	.7293	.8573	.6962
Min	.0995	.0995	.6962
Avg	.5099	.4027	.6962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 204 / 11KV MANDAVI RH FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 201 / 11KV WAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.3734	.3506	.4572	.4854	.3544	.3734
4	.4854	.3696	.3506	.462	.4854	.3544	.3696
8	.362	.3734	.5258	.9412	.8238	.5258	.8059
12	.3292	.3506	.7023	.7682	.3506	.3772	.7522
16	.9877	.7202	.3982	.3696	.3506	.7164	.3696
19	.9313		.6878	.4805	.5258	.7316	.6653
20		.7202					
22	.8048	.6859	.6401	.5175	.5258	.695	.5601
23			.6401				
24			.5144				
Max	.9877	.7202	.7023	.9412	.8238	.7316	.8059
Min	.3292	.3506	.3506	.3696	.3506	.3544	.3696
Avg	.6239	.5133	.5344	.5709	.5068	.5364	.5566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 202 / 11KV SINDAKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7468	.7362	.7392	.7023	.7087	.8316
4	.7842	.7468	.8413	.7762	.7023	.7087	.8316
8	.8145	.8779	.7011	.7602	.7392	.7888	.9145
12	.6805	.5258	.8145	.7762	.7011	.7164	.9877
16	.7316	.7362	.7682	.8596	.7888	.8048	.788
19	.9145		.7602	.8048	.7011		.8413
20		.964					
22	1.0456	1.0517	.7392	.7392	.7362	.695	.7316
24			.5144				
Max	1.0456	1.0517	.8413	.8596	.7888	.8048	.9877
Min	.6805	.5258	.5144	.7392	.7011	.695	.7316
Avg	.8222	.8070	.7344	.7793	.7244	.7371	.8466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 203 / 11KV DAHELI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.6283	.5609	.5853	.6283	.567	.7095
4	.6535	.6283	.5609	.5853	.6283	.567	.7023
8	.5552	.6401	.6485	.5792	.6219	.631	.6401
12	.6089	.5658	.5792	.5853	.1402	.5487	.6268
16	.5487	.6485	.5792	.5731	.6135	.6584	.6219
19	.7865		.7421	.7316	.8413		.9877
20		.6859					
22	.9145	.7202	.7682	.7762	.8413	.7392	.9795
24			.6859				
Max	.9145	.7202	.7682	.7762	.8413	.7392	.9877
Min	.5487	.5658	.5609	.5731	.1402	.5487	.6219
Avg	.6744	.6453	.6406	.6309	.6164	.6186	.7525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 201 / 11 KV BODHADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0387	1.0166	1.0056		1.0631	1.0749	1.0413
2		.9816	.9536		1.0631	1.0402	.9979
3		.9816	.9015	1.1493	1.0277	1.0749	1.0164
4	1.0745	.9816	.9536	1.1864	1.0277	1.1269	.9979
5		1.0692	1.0749	1.2235	1.1517	1.2136	1.0534
6		1.1393	1.1616	1.242	1.2403	1.1616	1.1643
7		1.1919	1.1616	1.2936	1.1694	1.0923	1.2567
8	1.0924	1.0692	1.0402	1.2382	1.0985	1.0402	1.1096
9	.9816	.964	.9709	.8871	1.0631	.8149	.9709
10	.9114		.961		1.0349	.7087	.8322
11	.9114	.9114	.9111		.924	.8505	.7802
12	.8939		.8925		.9111	.8505	.9189
13	.8589		.9055		.9111	.815	.8322
14	.8238		.874	.9709		.8505	
15	.8939	.9991	.8925	.9882		.8859	
16	.8939	.9991	.924	.9816	.924	.9391	.9745
17	.929	1.0056	1.0349	.9816		1.0903	1.0808
18		1.0402	1.0697	1.0631	1.0576	1.1088	1.1517
19	1.2971	1.1443	1.3169	1.0631	1.2309	1.2071	1.2757
20	1.2445	1.1269	1.3306	1.2403	1.1789	1.2254	1.258
21	1.1919	1.1096	1.2382	1.2048	1.0402	1.1827	1.1694
22	1.1393	1.1269	1.1458	1.1694	1.1616	1.2012	1.0985
23	1.0517	1.0749		1.1163	1.1269		1.0985
24	1.0566	1.0166	.5144		1.0631	1.0576	1.1088
Max	1.2971	1.1919	1.3306	1.2936	1.2403	1.2254	1.2757
Min	.8238	.9114	.5144	.8871	.9111	.7087	.7802
Avg	1.0158	1.0475	1.0102	1.1176	1.0699	1.0266	1.0540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 202 / 11 KV SAWRI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.6661	.6068		.7087	.6241	.3189
2		.6878	.5548		.6733	.6241	.3189
3		.4207	.5201	.7164	.6379	.6588	.3388
4	.5373	.4207	.6068	.7164	.6201	.6588	.3366
5		.4557	.6935	.7701	.7265	.6935	.3544
6		.4908	.7282	.788	.7888		.3544
7		.4557	.4334	.6447	.7087	.6241	.3012
8	.4656	.4557	.2254	.4248	.6024	.6241	.4334
9	.4908	.3856	.2427	.6447	.443	.4854	.5201
10	.5083	.5201	.2293		.4294	.5316	.5201
11	.4733	.4908	.2293		.2865	.3898	.4854
12	.3856	.5959	.2298		.6175	.5493	.6068
13	.4031		.3881		.6447	.4961	.6241
14	.4207	.5784	.4234	.5895		.4961	
15	.3856	.631	.4058	.6415		.4961	
16	.4382	.6836	.4058	.7362	.6598	.4961	.567
17	.4908	.5201	.4234	.7186		.6024	.6733
18	.5258	.6762	.5258	.5609	.7802	.5316	.6379
19	.7888	.4854	.8596	.8859	.8842	.8292	.8859
20	.8238	.5548	.8596	.8328	.8322	.7973	.8859
21	.8063	.6241	.8775	.815	.7802	.7796	.8505
22	.6836	.6935	.6626	.7973	.7975	.7796	.815
23	1.0692	.7282		.7619	.7282		.7973
24	.6805	.7011	.5144		.7442	.6241	.567
Max	1.0692	.7282	.8775	.8859	.8842	.8292	.8859
Min	.3856	.3856	.2254	.4248	.2865	.3898	.3012
Avg	.5820	.5618	.5064	.7085	.6711	.6087	.5542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 204 / 11 KV BODHADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8023					
2		1.8023					
3		1.7695					
4		1.7204					
5		1.7204					
6		1.8351					
7		2.2119					
8	2.3703	2.4086					
9	2.4615	1.917					
10	2.3805						
11			2.4177		3.0521	2.2283	2.1672
12			2.4006			2.3102	2.4619
13			2.3491		2.6406	2.2939	2.2885
14			2.3148	1.7511	2.8292	2.2939	1.9662
15			2.1434	2.3926		2.3102	1.7368
16			2.2291	2.13	2.572	2.3594	1.9826
17			2.2805	2.343		2.4006	1.8842
18			2.1948	2.3371	2.5659	2.332	2.0317
19	2.4615		2.0576	2.1714		2.1605	1.8187
20	2.3758			2.0719			
21	2.3758			2.0119			
22				1.9448			
23	2.1052						
24		2.0317	.5144				
Max	2.4615	2.4086	2.4177	2.3926	3.0521	2.4006	2.4619
Min	2.1052	1.7204	.5144	1.7511	2.5659	2.1605	1.7368
Avg	2.3615	1.9219	2.0902	2.1282	2.7320	2.2988	2.0375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 205 / 11 KV SAWRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0749		1.073		
2			1.0402		1.0277	1.0402	
3			1.0402	1.0288	1.0277		
4			1.0749	1.0974	1.0227	1.0749	
5			1.1269	1.2003	1.0814	1.1616	
6			1.1789	1.2689	1.2452		.9431
7			1.3523	1.4746	1.2289	1.2136	1.286
8			1.3003	1.5432	1.2763	1.3003	1.387
10		.1524					
11	1.6385	1.4746					
12	1.7368	1.5074					
13	1.491						
14	1.6057	1.3435					
15	1.6712	1.4746					
16	1.6549	1.3765					
17	1.6876	1.5777					
18	1.7532	1.543					
19						.1524	
20	.1524						
23		.9536		1.0562	1.1616		
24			.5144		1.0898		.8573
Max	1.7532	1.5777	1.3523	1.5432	1.2763	1.3003	1.387
Min	.1524	.1524	.5144	1.0288	1.0227	.1524	.8573
Avg	1.4879	1.2670	1.0781	1.2385	1.1234	.9905	1.1184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 202 / Town Feeder II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 203 / CHIKHALI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 204 / CHIKHLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 206 / MANDVA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)
14		.5144
24	.5144	
Max	.5144	.5144
Min	.5144	.5144
Avg	.5144	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 207 / RH-GOKUNDA FEEDER
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-ST

Feeder No / Name : 201 / 11 KV BELLORI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9875	.8059	.703		.8916		.8573
2	1.8587	.7716	.7373		.8916		.8059
3	.9785	.7716	.7888	.9088	.8573		.8059
4	1.7661	.7373	.7716	.9259	.8059		.7716
5	1.6846	.6001	.8059	.9088	.8059		.7716
6	1.6503	.5487	.7545	.8573	.7373		.7888
7	1.7262	.5487	.6859	.9431	.7202		.7716
8	.3574	.583	.5658	.703	.6859		.6859
12					.7716		
14				.8402			
15				.8402			
16				.8573	.7373		
17			.8573	.8059			
18	.0175		.8402	.8059			
19	.4893	.6859	.823	.8059		.9431	.8745
20	2.0584		.8402	.8916		1.0631	
21	2.0614		.9088	.9602		1.0974	1.046
22	2.0347		.8745	.9431			1.0802
23	1.0646		.9088	.9259			1.0631
24	2.0279	.9259	.5144	.9259	.9259		1.0288
Max	2.0614	.9259	.9088	.9602	.9259	1.0974	1.0802
Min	.0175	.5487	.5144	.703	.6859	.9431	.6859
Avg	1.4509	.6979	.7738	.8735	.8028	1.0345	.8732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-ST

Feeder No / Name : 202 / 11 KV TOWN 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17
HR	Load (MW)	Load (MW)
3		1.406
4		1.3889
5		1.3546
6		1.2174
7		1.1488
8		1.166
9		1.1488
24	.5144	1.3717
Max	.5144	1.406
Min	.5144	1.1488
Avg	.5144	1.2753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-ST

Feeder No / Name : 203 / 11 KV GHOTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.0288	.9431		1.0802	1.0117	1.2003
2	1.2003	.9602	.9602		1.0288		
3	1.2003		.9259		1.0802	.8745	.8573
4	1.2003		.8745		1.0631	1.0117	.6001
5	1.1145	.9602	.8916		1.0802	1.0117	.6001
6	1.0288		.9088		1.0974		.5487
7	.8916	.9088	.7202		.9259		
8	.9259	.8288	.7202		.8916		.463
9	.9602		.9945			.7373	
10	.9259		.9774		.8573	.8916	.5487
11	.9259	.8745	.823	.9945		.9945	
12	1.0631	.8573	.7888		.9088		
13	1.0288		.8059	1.0288	.9259	.7373	.7202
14		.7373	.8402			.7545	
15	.9945	.9088	.8059	1.2003	.9774		
16	.9945	.8573	.8402		.8916	.8402	
17	.9602	.7888	.8059	1.2003	.9259	.8573	.8916
18	1.0288	.8402	.8059	1.2689	1.0288	.9088	
19		1.286	.8402	1.3032		1.2003	1.0631
20	1.2689		.8745	1.2689		1.2689	
21	1.2346		.7545	1.2689		1.3203	1.2689
22	1.2003		.8059	1.2346		.8402	1.2003
23			.8059	1.166			1.166
24	1.2003	1.1145	.5144		1.1145	1.0631	1.0288
Max	1.2689	1.286	.9945	1.3032	1.1145	1.3203	1.2689
Min	.8916	.7373	.5144	.9945	.8573	.7373	.463
Avg	1.0737	.9251	.8345	1.1934	.9924	.9602	.8684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-ST

Feeder No / Name : 205 / 11KV SIRMITI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2058	.2058		.1715	1.2174	.1715
2	.2401	.2058	.2229		.1715		.1372
3			.2401	.1715	.1715	1.9547	.1372
4	.12		.2058	.2058	.1715		.1372
5	.1543		.2058	.2058	.1715		.1372
6	.1543		.1715	.703	.1715		.1372
7				.1715			
8				.703	1.7147		
9	1.7833	.9259	1.7833	1.0288	1.8861		
10	1.7661		1.7833	1.1145			1.8004
11	1.7833		1.9204	2.0576			
12			1.7147	1.8004		1.2689	
13			1.8861	1.8004		1.0288	1.0974
14			1.6975			.9431	
15	1.9547		1.6975				
16	1.9719	1.8176	1.9719				
17	1.8861	1.5947	1.8861		1.869		1.7318
18					2.0233		
19		.1372	.1715				.2058
20	.2058		.1715	.1715		.1715	
21	.2058		.2058	.1715		.1715	.1715
22	.2058		.2229	.1715			.1715
23	.2058		.2401	.1715			.1886
24	.2572	.2058	.5144		.1715	2.1434	.1715
Max	1.9719	1.8176	1.9719	2.0576	2.0233	2.1434	1.8004
Min	.12	.1372	.1715	.1715	.1715	.1715	.1372
Avg	.8209	.7275	.9104	.7099	.7903	1.1124	.4569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-
ST

Feeder No / Name : 206 / 11KV GHOTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-ST

Feeder No / Name : 207 / 11KV SIRMITI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)
14		.5144
24	.5144	
Max	.5144	.5144
Min	.5144	.5144
Avg	.5144	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / Umri Bazar

Feeder No / Name : 201 / 11KV Chinchkhed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.2103
Max	.2103
Min	.2103
Avg	.2103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / Umri Bazar

Feeder No / Name : 202 / 11KV Umri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / Umri Bazar

Feeder No / Name : 203 / 11KV Wazara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.0154
Max	.0154
Min	.0154
Avg	.0154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 202 / 11KV SHIKHAR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	2.6658
Max	2.6658
Min	2.6658
Avg	2.6658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 203 / 11KV HADSANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5959	.6478	.0509	.7011	.583	.6135	.6783
2	.5959	.6287	.6443	.7888	.6173	.6135	.6952
3	.5959	.5716	.6613	.7888	.6859	.6135	.6952
4	.5959	.6287	.6613	.8063	.7373	.6661	.7122
5	.5959	.6097	.6613	.8413	.8059	.8063	.7377
6	.5959	.6287	.7545	.8589	.823	.8764	.7209
7	.4733	.4954	.7209	.9114	.9259	.9465	.7377
8	.4031	.4763	.9054	.9991	.9259	.9991	1.0227
9	.3361	.3506	.8745	.9326	.3506	1.0341	.9816
10	.3361	.333	.8059	.9221	.3856	.8413	.929
11			.5144	.3734	.3856	.333	.3155
12			.381	.3921	.3856	.3506	.3155
13			.381	.3921	.7011	.3856	.3506
14			.4001	.4294	.7537	.3856	.3506
15			.4001	.4108	.7362	.3856	.3506
16			.362	.3921	.3856	.3506	.3506
17	1.3717	.9665	.3506	.381	.3856	.4108	.3856
18	1.3672	.8817	.4382	.381	.3856	.4668	.4382
19		.6161	.6135	.6287	.7011	.6535	.5258
20	.6668	.7282	.7011	.7049	.7011	.7468	.5609
21	.7049	.7282	.7011	.7049	.7011	.7655	.5609
22	.724	.7095	.6661	.724	.7011	.7468	.5609
23	.7049	.6722	.6485	.724	.631	.7095	.5258
24	.631	.6859	.6535	.631	.6859	.5609	.6908
Max	1.3717	.9665	.9054	.9991	.9259	1.0341	1.0227
Min	.3361	.333	.0509	.3734	.3506	.333	.3155
Avg	.6644	.6310	.5813	.6592	.6284	.6359	.5914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 204 / 11KV ASTHA(SARKHANI) SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5434	.7373	.8962	.8764	.9526	.8939	.9335
2	.5609	.7716	.8962	.8764	.9145	.8764	.9335
3	.5609	.7888	.8962	.8764	.9335	.8764	.9335
4	.5959	.8573	.8962	.8764	.9145	.8764	.9335
5	.7011	.8573	.8962	.8413	.9526	.8413	.9335
6	.7712	.9259	.8402	.8413	.9335	.8063	.8775
7	.9465	1.0117	.7095	.8764	.8764	.7186	.6348
8	1.0692	1.0802	.5788	.5784	.6287	.5434	.6161
9	.9054	1.1393	.3239	.5415	.3506	.4207	.5258
10	.9054	.9816	.3048		.5258	.4382	.4908
11			.7716		.5434	.8939	.8764
12			.8573	.9556	.5434	.9991	.9114
13			.9431	1.073	1.0517	.9465	.964
14			.9602	.9724	1.1744	.8764	.9816
15			.9774	.9054	1.1393	.8589	1.0166
16			.9259	.9556	1.1218	.8413	1.0341
17	.5716	.3547	1.0517	.9431	1.2094	.9389	1.0341
18	.5525	.3734	1.0517	.9431	1.0867	.9054	1.0166
19	1.0098	.5228	.8764	.7621	.9114	.9335	.7011
20	1.0098	1.0456	.929	.9526	.9114	1.0642	.7011
21	1.0098	1.0269	.964	1.0098	.9465	1.0456	.7011
22	.9717	1.0082	.9465	1.0288	.9465	1.0456	.7011
23	.9526	.9522	.9114	1.0288	.9114	.9896	.7011
24	.8764	.9335	.9335	.8939	.9335	.8939	.9522
Max	1.0692	1.1393	1.0517	1.073	1.2094	1.0642	1.0341
Min	.5434	.3547	.3048	.5415	.3506	.4207	.4908
Avg	.8063	.8538	.8474	.8913	.8922	.8552	.8377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 205 / 11KV MAHUR FEEDER NEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9816	1.1203	1.1088	.9114	1.0974	1.0166	1.0719
2	.9816	1.0829	1.0719	.8764	1.0425	.9816	1.0534
3	.9465	1.0829	1.0349	.8764	1.0242	.9816	1.0349
4	.9465	1.0456	1.0349	.8764	1.0059	.9465	1.0164
5	.8764	.9896	1.0349	.8939	.9511	.9114	1.0164
6	.7712	.9425	.924	.8939	.9145	.8764	.8686
7	.7362	.7655	.7207	.8764	.8048	.7712	.7023
8	.6135	.7095	.6908	.7186	.6584	.6836	.6838
9	.7023	.6135	.6468	.6838	.6135	.6836	.6836
10	.7207	.7712	.6283	.7023	.8063	.6836	.7011
11			.6468	.7023	.8413	.7712	.7011
12			.695	.8316	.8589	.8063	.7537
13			.7316	.8501	.8589	.8063	.7888
14			.823	.924	.8764	.8764	.7888
15			.8413	.924	.8764	.8764	.8063
16			.8779	.9425	.8589	.8413	.8063
17	1.0608	.8501	.8764	.823	.7888	.8501	.8238
18	1.0534	.7947	.8589	.7316	.7712	.7947	.7888
19	1.0719	.9795	.964	.8596	.9465	.961	1.0166
20	1.1088	1.0164	1.0517	1.0608	1.0341	1.0534	1.0166
21	1.1273	1.1273	1.1218	1.134	1.0517	1.1273	.9991
22	1.1827	1.2197	1.1568	1.1523	1.1043	1.2012	.9991
23	1.2012	1.2197	1.1393	1.1523	1.0867	1.1643	.964
24	1.0692	1.1827	1.1827	1.1043	1.0974	1.0517	1.1458
Max	1.2012	1.2197	1.1827	1.1523	1.1043	1.2012	1.1458
Min	.6135	.6135	.6283	.6838	.6135	.6836	.6836
Avg	.9529	.9730	.9110	.8959	.9154	.9049	.8846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 206 / 11KV RENUKADEVI PHC NON SHEDDABLE WATER SUPPLY AND
EXPRESS FE Feeder KV- 11 / UTILITY
OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0905	.0724	.0526	.0886	.0724	.0724
2	.0905	.0905	.0724	.0526	.0886	.0905	.0724
3	.0905	.0543	.0724	.0053	.0886	.0905	.0724
4	.0905	.0724	.0724	.0526	.0709	.0905	.0724
5	.0724	.0724	.0724	.0526	.0354	.0724	.0724
6	.0362	.0362	.037	.0351	.0177	.0724	.0362
7	.0362	.0362	.0366	.0351	.0177	.0362	.0362
8	.0362	.0362	.0362	.0351	.0354	.0362	.0362
9	.0358	.0351	.0362	.0362	.0175	.0362	.0351
10	.0358	.0526	.0362		.0175	.0362	.0351
11			.0362	.1109	.0175	.0362	.0351
12			.0724	.1109	.0175	.0905	.0351
13			.0724	.1294	.0701	.0905	.0351
14			.0905	.1478	.0876	.0905	.0876
15			.0905	.1463	.0905	.0905	.1227
16			.0905	.1646	.0905	.0905	.1402
17	.0532	.0905	.0876	.0709	.0905	.0181	.1402
18	.0532	.0543	.0526	.0886	.0543	.0181	.0876
19	.0354	.0543	.1052	.0532	.0543	.0543	.1052
20	.0709	.0905	.1052	.0532	.0543	.0543	.1052
21	.0886	.0905	.1227	.0886	.0362	.0362	.0876
22	.0886	.0724	.0526	.0886	.0362	.0905	.0526
23	.0886	.0724	.0351	.0886	.0724	.0905	.0526
24	.0905	.0886	.0724	.0351	.0886	.0905	.0724
Max	.0905	.0905	.1227	.1646	.0905	.0905	.1402
Min	.0354	.0351	.0351	.0053	.0175	.0181	.0351
Avg	.0658	.0661	.0679	.0754	.0558	.0656	.0708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 201 / 11 KV WAI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6401	.5729
2			.6401	.5729
3			.5729	.5729
4			.5729	.5729
5			.6099	.6099
6			.6401	.6161
7			.6099	.4733
8	.6495		.6099	
9		.5729	.6468	
10		.6036	.6468	.5359
11		.5729	.6099	.5788
12		.5487	.5175	.5729
13		.543	.5175	.462
14		.5304	.5729	.5729
15		.5359	.5729	
16		.5729	.5729	
17	.6099	1.4083		
18	.6099	1.4419		
19	.7207	1.3717		
20	.7947	1.283		
21	.7947	1.2483		
22	.7947	1.3226		
24		.7207	.9709	1.1401
Max	.7947	1.4419	.9709	1.1401
Min	.6099	.5304	.5175	.462
Avg	.7106	.8851	.6191	.6041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 202 / 11 KV HIWALANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4294	.462
2			.4294	.462
3			.4294	.4251
4			.4294	.3881
5			.4294	.4294
6			.4668	.4294
7			.3921	.3921
8	1.1258		.3174	.3174
9		1.4083	1.3077	
10		1.3592	1.3413	.3142
11		1.3108	.9389	.3142
12		1.1401	.9389	.3142
13		1.0059	.8718	.6706
14		.8848	.7956	1.2407
15		.9389	.7956	
16		.9724	.8288	
17	.3174	.2801		
18	.3547	.2801		
19	.3921	.5041		
20	.4294	.5359		
21	.4294	.5359		
22	.4294	.5415		
23			.5041	
24		.4668	.4668	
Max	1.1258	1.4083	1.3413	1.2407
Min	.3174	.2801	.3174	.3142
Avg	.4969	.8110	.6729	.4738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 203 / 11 KV ANJANKHED FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9362	1.2742
2			.9362	1.3748
3			.9362	1.4586
4			.9362	1.576
5			.9945	1.643
6			1.166	1.6766
7			1.9204	1.643
8	.5392		1.2346	1.1065
9		.462	.462	
10		.499	.5359	.6468
11		.499	.5359	.6468
12		.5359	.6099	.6838
13			.5914	.6468
14		.6468	.5729	.6283
15		.6099	.5729	
16		.6099	.5729	
17	1.5424	.5729	.5729	
18	1.576	.5729	.5729	
19	1.4746	.7947	.6161	
20	1.406	.7499	.6099	
21	1.1096	.7133	.6468	
22	1.0749	.7133	.6468	
23			1.6095	
24		.9709	1.576	
Max	1.576	.9709	1.9204	1.6766
Min	.5392	.462	.462	.6283
Avg	1.2461	.6393	.8485	1.1542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 201 / UMRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
2			1.8861
4			1.8861
6			2.0576
10		2.0576	2.0576
11		1.0288	
12			1.0288
13		1.0288	
14		1.0288	2.0576
16		2.0576	
18		2.2291	1.8861
20		2.0576	
21		1.8861	
23		1.8861	
24	1.8861		1.8861
Max	1.8861	2.2291	2.0576
Min	1.8861	1.0288	1.0288
Avg	1.8861	1.6956	1.8433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 202 / TALEGAON

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
2			2.0576
4			2.572
6			3.0864
10		3.0864	3.0864
11		.8573	
12			1.2003
13		1.2003	
14			1.2003
15		1.2003	
16			1.2003
17		1.2003	
18			1.2003
19		1.2003	
21		1.2003	
23		1.2003	
24	1.7147		1.2003
Max	1.7147	3.0864	3.0864
Min	1.7147	.8573	1.2003
Avg	1.7147	1.3932	1.8671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 203 / BOTHI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
2			1.3717
4			1.3717
6			1.5432
10		1.3717	1.5432
11		.8573	
12		.8573	.6859
13		.8573	
14		.8573	.6859
16		.6859	.6859
17			.6859
18		.6859	.6859
19		.6859	
21		.8573	
22		.8573	
23		.8573	
24	.8573		.8573
Max	.8573	1.3717	1.5432
Min	.8573	.6859	.6859
Avg	.8573	.8573	1.0117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 204 / JAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8587			
2	2.1224			.5144
3	2.2649			
4	2.3564			.5144
5	2.3914			
6	2.4897			.5144
7	2.5774			
8	2.9393			
9	3.0156			
10	2.8608		.5144	.3429
11	.9313		1.8861	
12	.2987			2.0576
13	.2964		2.2291	
14	.2926			1.8861
15	.2561		2.2291	
16	.2827			1.8861
17	.3315		2.2291	
18	.3399			1.8861
19	.4367		.5144	
20	.4969			
21	.4854		.5144	
22	.4412			
23	.4329		.5144	
24	.4123	.5144		.5144
Max	3.0156	.5144	2.2291	2.0576
Min	.2561	.5144	.5144	.3429
Avg	1.2755	.5144	1.3289	1.1240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 206 / CIVIL HOSPITAL EXPRESS NON SHEDDABLE WATER SUPPLY AND
FEEDER Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
2			.0171
4			.0171
6			.0171
10		.0171	.0171
12		.0171	.0171
14		.0171	.0171
16		.0171	.0171
18		.0171	.0171
20		.0171	
21		.0171	
23		.0171	
24	.0171		.0171
Max	.0171	.0171	.0171
Min	.0171	.0171	.0171
Avg	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 201 / SHINDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5338	.2572	.2572	.2572	.3429	.3429	
2	.5544	.2572	.2572	.2572	.3429	.3429	
3	.559	.2572	.2572	.2572	.3429	.3429	
4	.5521	.2572	.2572	.2572	.3429	.3429	
5	.5879	.2572	.2572	.2572	.3429	.2572	
6	.6253	.2572		.2572	.3429	.2572	
7	.5971	.2572		.2572	.2572	.2572	
8	.6253	.2572		.2572	.2572	.2572	.2572
9	.5978			.2572	.2572	.2572	.1715
10	.5651			.2572	.2572	.2572	.1715
11	.482		.3429	.3429	.1715		.2572
12	.4889			.3429	.1715		
13	.4805		.2572	.2572	.1715		.2572
14	.4995			.2572	.1715		.2572
15	.5087			.2572	.1715		.2572
16	.5094	.1715	.2572	.1715	.1715		.2572
17	.5232	.1715			.1715		.2572
18	.543	.1715	.2572	.3429	.1715		.2572
19	.695	.3429	.3429	.3429	.3429		.2572
20	.7377	.3429	.3429	.3429	.3429		.2572
21	.7354	.3429	.3429	.3429	.3429		.2572
22	.7148	.3429	.3429	.3429	.3429	.2572	.2572
23	.7156	.2572	.3429	.3429	.3429	.2572	.2572
24	.6146	.2572		.2572	.3429	.2572	.2572
Max	.7377	.3429	.3429	.3429	.3429	.3429	.2572
Min	.4805	.1715	.2572	.1715	.1715	.2572	.1715
Avg	.5853	.2622	.2939	.2833	.2715	.2836	.2465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 202 / HUNDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.5144		1.3717	1.2003	.3429	
2	.3429	.5144	1.5432	1.3717	1.286	.3429	
3	.3429	.5144	1.5432	1.3717	1.286	.3429	
4	.3429	.5144	1.7147	1.3717	.4287	1.3717	
5	.3429	.5144	2.0576	1.5432	.4287	1.5432	
6	.3429	.5144		1.9719	.4287	1.5432	
7	.3429	.5144		2.0576	1.3717	1.5432	
8	.3429	.4287	2.0576	1.9719	1.4575	1.5432	1.7147
9	.3429			1.6289	1.4575	1.5432	1.7147
10	.3429		1.8861	1.7147	1.4575	1.5432	1.5432
11	2.1434			.2572	.3429		.2572
12	2.1434			.2572	.3429		
13	2.1434			.2572	.3429		.2572
14	2.2291			.2572	.3429		.2572
15	2.2291			.2572	.3429		.2572
16	2.3148	2.2291	.2572	.3429	.3429		.2572
17	2.3148	2.2291		.3429	.3429		.2572
18	2.0576	2.0576	.3429	.4287	.3429		.2572
19	.5144	.3429	.5144	.5144	.5144		.4287
20	.6001	.5144	.5144	.5144	.5144		.4287
21	.6001	.5144	.5144	.3429	.4287		.4287
22	.6001	.5144	.5144	.5144	.4287	.5144	.4287
23	.5144	.5144	.4287	.5144	.4287	.5144	.4287
24	.4287	.4287		.4287	.4287	1.5432	.4287
Max	2.3148	2.2291	2.0576	2.0576	1.4575	1.5432	1.7147
Min	.3429	.3429	.2572	.2572	.3429	.3429	.2572
Avg	1.0109	.7867	1.0684	.9002	.6787	1.0947	.5841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 203 / SHIVANGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9633	.6001	1.5432	.0857	.0838	.0857	
2	1.1808	.6001	.0857	.0857	.0857	.0857	
3	1.2006	.6001	.0857	.0857	.0838	.0857	
4	1.2326	.6001	.0857	.0857	.0838	.0857	
5	1.2387	.6001	.0857	.0857	.0857	.0857	
6	1.2585	.6001		.0857	.0829	.0857	
7	1.2822	.6001		.0857	.0829	.0857	
8	1.2639	.0857		.0857	.0838	.0857	.0857
9	1.2003			.0857	.0857	.0857	.0857
10	.9759		.0857	.0857	.0857	.0857	.0857
11	.2435			.3315	.1715		.2572
12	.0857			.4144			
13			.6001	.3315	.1715		.2572
14				.2515	.1715		.2572
15	.0857			.2515	.1715		.2572
16	.0857	.0857	.6001	.0838	.1715		.2572
17	.0857	.0857			.1715		.2572
18	.0857	.0857	.6001	.1677	.1715		.2572
19	.0857	.0857		.1677	.0857		.0857
20	.0857	.0857		.0838	.0857		.0857
21	.0857	.0857		.0838	.0857		.0857
22	.0857	.0857	.0857	.0838	.0857	.0857	.0857
23	.0857	.0857	.0857	.0838	.0857	.0857	.0857
24	.0857	.0857		.0857	.0829	.0857	.0857
Max	1.2822	.6001	1.5432	.4144	.1715	.0857	.2572
Min	.0857	.0857	.0857	.0838	.0829	.0857	.0857
Avg	.5901	.2975	.3585	.1425	.1111	.0857	.1607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 204 / 11 kv Dairy feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.1715	.2572	.2572	.0857	.1715	
2	.2572	.1715	.2572	.2572	.0857	.1715	
3	.2572	.1715	.2572	.2572	.0857	.2572	
4	.2572	.1715	.2572	.2572	.0857	.2572	
5	.2572	.1715	.2572	.2572	.0857	.2572	
6	.2572	.1715		.2572	.0857	.2572	
7	.2572	.2572		.2572	.0857	.2572	
8	.2572	.2572		.2572	.0857	.2572	.1715
9	.2572			.2572	.0857	.2572	.1715
10	.2572		.2572	.2572	.0857	.2572	.1715
11	.2572			.0857	.1715		.1715
12	.2572			.0857	.1715		
13	.2572			.0857	.1715		.1715
14	.2572			.0857	.1715		.1715
15	.2572			.0857	.1715		.1715
16	.2572	.2572	.2572	.0857	.1715		.1715
17	.2572	.2572		.0857	.2572		.1715
18	.2572	.2572	.2572	.0857	.2572		.1715
19	.2572	.2572	.2572	.0857	.2572		.1715
20	.2572	.2572		.0857	.2572		.1715
21	.2572	.2572	.2572	.0857	.2572		.1715
22	.2572	.2572		.0857	.1715	.0857	.1715
23	.2572	.2572	.2572	.0857	.1715	.1715	.1715
24	.2572	.2572		.2572	.0857	.2572	.2572
Max	.2572	.2572	.2572	.2572	.2572	.2572	.2572
Min	.2572	.1715	.2572	.0857	.0857	.0857	.1715
Avg	.2572	.2270	.2572	.1643	.1500	.2242	.1769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174018 / 33 KV ARJAPUR(BILOLI)

Feeder No / Name : 201 / 11 KV ARJAPUR FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	05-MAY-17
HR	Load (MW)
24	.447
Max	.447
Min	.447
Avg	.447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174018 / 33 KV ARJAPUR(BILOLI)

Feeder No / Name : 202 / 11 KV AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-APR-17
HR	Load (MW)
24	.5668
Max	.5668
Min	.5668
Avg	.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174018 / 33 KV ARJAPUR(BILOLI)

Feeder No / Name : 203 / BILOLI URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0349	.924	.924	1.0479	1.0479	1.0719	.961
16	.8871	.7947		.9907	.9979	.924	
19	.9979						
23				1.0288			
24	.9979	.8779	.7762	.8745	.8764	.961	.924
Max	1.0349	.924	.924	1.0479	1.0479	1.0719	.961
Min	.8871	.7947	.7762	.8745	.8764	.924	.924
Avg	.9795	.8655	.8501	.9855	.9741	.9856	.9425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174018 / 33 KV ARJAPUR(BILOLI)

Feeder No / Name : 204 / Govt. Hospital Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0183	.0171	.0185	.0191	.0191	.0183	.0181
16	.0181	.0185		.0191	.0183	.0179	
19	.0173						
23				.0191			
24	.0183	.0177	.0185	.0171	.0191	.0183	.0183
Max	.0183	.0185	.0185	.0191	.0191	.0183	.0183
Min	.0173	.0171	.0185	.0171	.0183	.0179	.0181
Avg	.018	.0178	.0185	.0186	.0188	.0182	.0182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 201 / 11 KV LOHGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.4746	1.3032	1.4403	1.387	1.491	1.1706	1.5844
16	1.2193	1.0669	1.0098	.9907	1.0185		1.1361
24	1.358	1.5089	1.1812	1.2449	1.3146		1.4712
Max	1.4746	1.5089	1.4403	1.387	1.491	1.1706	1.5844
Min	1.2193	1.0669	1.0098	.9907	1.0185	1.1706	1.1361
Avg	1.3506	1.293	1.2104	1.2075	1.2747	1.1706	1.3972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 202 / 11 KV RAHER FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3361	.3395		.2641	.3018	.3018	.2439
16	.3201	.3441	.3401	.4012	.3048	.3755	
17							.2641
24	.2641	.2614	.2241	.2427	.2801	.2801	.3018
Max	.3361	.3441	.3401	.4012	.3048	.3755	.3018
Min	.2641	.2614	.2241	.2427	.2801	.2801	.2439
Avg	.3068	.315	.2821	.3027	.2956	.3191	.2699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 203 / 11 KV HARNAL FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7468	.7922		.7922	.7167	.7545	.5792
16	.5609	.5548	.4508	.5028	.5201	.426	.6413
24	.7545	.7468	.7095	.6722	.7468	.7468	.7095
Max	.7545	.7922	.7095	.7922	.7468	.7545	.7095
Min	.5609	.5548	.4508	.5028	.5201	.426	.5792
Avg	.6874	.6979	.5802	.6557	.6612	.6424	.6433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 201 / 11 KV BELKONI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982					.447	
2	.4141					.4311	
3	.4141					.4311	
4	.4141					.4311	
5	.4141					.4311	
6	.4316					.447	
7						.3353	
8	.3345	.3189	.3827	.3189	.2714	.2714	.6386
9		.303				.2395	.6227
10		.2711			.2874	.2395	.2714
11		.6538			.5748	.447	.2874
12					.6386		.3193
13		.6538			.6227		.2874
14		.7176			.5588		.2874
15		.6857			.5588		.2714
16	.6538	.6538	.6538	.6219	.5588		.2874
17		.7176	.5741		.6067		.2714
18		.6538	.6538		.5907		.2714
19			.3987		.3353		.3832
20					.3832		.3832
21					.447		.4151
22					.447		.4151
23					.447		.4311
24		.4306	.4943	.3827	.447		.4311
Max	.6538	.7176	.6538	.6219	.6386	.447	.6386
Min	.3345	.2711	.3827	.3189	.2714	.2395	.2714
Avg	.4343	.5509	.5262	.4412	.4860	.3774	.3691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 202 / 11 KV CHINCHALA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9393					.8175	
2	.8697					.8001	
3	1.0089					.9741	
4	1.1132					1.0089	
5	1.2176					1.0437	
6	1.2524					1.0785	
7	1.2524					.9741	
8	1.0437	1.2524	1.0959	1.1306	1.0785	1.1132	
9		1.2524				1.0785	
10		1.1132			.8349	1.0437	.9045
11		.574			.5218	.5566	1.148
12		.5392			.5566		.9915
13		.5044			.574		1.1132
14		.5566			.5566		1.0785
15					.574		1.1132
16		.5566	.5566	.5218	.5914		1.1132
17		.574	.6436		.5566		1.148
18		.6958	.661		.6436		.6262
19			.9045		.9393		.9045
20					.9393		.9045
21					.9393		.8697
22					.9045		.8697
23					.8697		.8349
24		.8523	.8349	.8001	.8349		.8001
Max	1.2524	1.2524	1.0959	1.1306	1.0785	1.1132	1.148
Min	.8697	.5044	.5566	.5218	.5218	.5566	.6262
Avg	1.0872	.7701	.7828	.8175	.7447	.9535	.9613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 203 / 11 KV SAVALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1163					.1163	
2	.1163					.1163	
3	.1163					.1163	
4	.1163					.1163	
5	.1163					.1163	
6	.1163					.1329	
7						.0997	
8	.1329	.1163	.1163	.0831	.0997	.0997	.2824
9		.1163				.0997	.2824
10		.1163			.0997	.0997	.1163
11		.0665			.2658	.1994	.1163
12					.2824		.1163
13		.3157			.2326		.1163
14		.2326			.2492		.1163
15		.2658			.2492		.1163
16	.299	.2658	.2824	.2824	.2326		.0831
17		.299	.299		.2326		.1163
18		.2824	.3323		.2492		.1163
19			.1163		.0997		.1329
20					.1495		.1329
21					.1495		.1329
22					.1329		.1661
23					.1163		.1329
24		.1163	.1163	.1163	.0665		.1163
Max	.299	.3157	.3323	.2824	.2824	.1994	.2824
Min	.1163	.0665	.1163	.0831	.0665	.0997	.0831
Avg	.1412	.1994	.2104	.1606	.1817	.1193	.1407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 204 / 11 KV TALNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.478					.5173	
2	.478					.519	
3	.478					.5167	
4	.478					.5178	
5	.478					.5357	
6	.495					.5363	
7						.4849	
8	.4438	.3776	.4396		.4518	.433	.5856
9		.3768				.3467	.5333
10		.3395			.3305	.3086	.3957
11		.5556			.4349	.4681	.3441
12					.4513		.3272
13		.5464			.4503		.3617
14		.6549			.5184		.3961
15		.6088			.5006		.3793
16	.6145	.6028	.4838	.5696	.4989	.1489	
17		.6145	.3793		.5671		
18		.4928	.4645		.5321		
19			.4812		.464		.6207
20					.5155		.5862
21					.5836		.5517
22					.5493		.5173
23					.515		.5173
24		.5525	.5011	.3287	.5167		.5173
Max	.6145	.6549	.5011	.5696	.5836	.5363	.6207
Min	.4438	.3395	.3793	.3287	.3305	.1489	.3272
Avg	.4929	.5202	.4583	.4492	.4925	.4444	.4738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 205 / 11 KV KASRALI FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1863					.2048	
2	.205					.2048	
3	.1863					.2048	
4	.1863					.2048	
5	.1491					.2048	
6	.1491					.1861	
7	.1491					.1675	
8	.1304	.1303	.1303	.1117	.1117	.1675	.1489
9		.1489				.1675	.1489
10		.1303			.1117	.1489	.1489
11		.1303			.1489		.1489
12		.1303			.1489		.1675
13		.1489			.1489		.1675
14		.1489			.1489		.1675
15		.1489			.1489		.1675
16	.1489	.1489	.1489	.1117	.1489	.1489	.1861
17		.1489	.1489		.1675		.1675
18		.1861	.1489		.1675		.1489
19			.1861		.1861		.1861
20					.2234		.2048
21					.2234		.2048
22					.2234		.2048
23					.2234		.1861
24		.1861	.1675	.1489	.2048		.1861
Max	.205	.1861	.1861	.1489	.2234	.2048	.2048
Min	.1304	.1303	.1303	.1117	.1117	.1489	.1489
Avg	.1656	.1489	.1551	.1241	.1710	.1828	.1730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 206 / 11 KV RUDRAPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2301					.061	
2	.1994					.0611	
3	.2147					.2439	
4	.2454					.2743	
5	.2607					.2896	
6	.2604					.3045	
7	.2604					.3653	
8	.3067	.2359	.3462	.3492	.3796	.3649	.0766
9		.2644				.3497	.0613
10		.2784			.3185	.3345	.2907
11		.044			.0454	.0456	.3519
12		.0441			.0607		.382
13		.0442			.0607		.382
14		.0442			.0455		.351
15		.0444			.0607		.3506
16		.0445	.0602	.0607	.0456	.0456	.3353
17		.0445	.0452		.0456		.3201
18		.0446	.0452		.0608		.0609
19			.0754		.0912		.0762
20					.0912		.0762
21					.0912		.0762
22					.0761		.0762
23					.061		.061
24			.0607	.0608	.061		.061
Max	.3067	.2784	.3462	.3492	.3796	.3653	.382
Min	.1994	.044	.0452	.0607	.0454	.0456	.0609
Avg	.2472	.1030	.1055	.1569	.0997	.2283	.1994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 201 / 11 KV DAULATAPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3375	.6173	.3048	.3429	.3086	.2915	.3601
16	.2229	.1886	1.166	1.2689	1.3375		1.286
24	.2743	.2572	.2743	.3429	.2743	.2743	.2915
Max	1.3375	.6173	1.166	1.2689	1.3375	.2915	1.286
Min	.2229	.1886	.2743	.3429	.2743	.2743	.2915
Avg	.6116	.3544	.5817	.6516	.6401	.2829	.6459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 202 / 11 KV SAGROLI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.4287	.463	.3772	.5144	.4801	.4458	.4801
24	.4801	.5144	.4801	.4115	.4115	.463	.4458
Max	.4801	.5144	.4801	.5144	.4801	.463	.4801
Min	.4287	.463	.3772	.4115	.4115	.4458	.4458
Avg	.4544	.4887	.4287	.4630	.4458	.4544	.4630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 203 / 11 KV BOLEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381						
2	.3818						
3	.3772						
4	.3833						
5	.3993						
6	.4161						
8	.2241	.2134	.6687	.6859	.6516	.6344	.5316
9	.5068						
10	.378						
11	.7933						
12	.8627						
13	.8512						
14	.8459						
15	.8208						
16	1.4518	.6687	.2401	.2743	.1715	.2572	.2401
17	.7888						
18	.7872						
19	.5746						
20	.3841						
21	.3902						
22	.3948						
23	.3185						
24	.6561	.2572	.3086	.2439	.3086	.3086	.3601
Max	1.4518	.6687	.6687	.6859	.6516	.6344	.5316
Min	.2241	.2134	.2401	.2439	.1715	.2572	.2401
Avg	.5812	.3798	.4058	.4014	.3772	.4001	.3773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 201 / 11 KV TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
2	1.1431		1.1431	1.1431	1.1431	1.2193
3	1.1431		1.0669	1.1431	1.1431	1.1431
4	1.0669		1.0669	1.0669	1.0669	1.0669
5	1.0669		1.0669	1.0669	1.0669	1.0669
6	1.0669		.9907	1.0669	1.0669	1.0669
7	.9907		.9907	.9907	1.0669	1.0669
8	.9907	.6447	.9145	.9907	.9907	.9907
9	.9907		.9907	1.0669	.9907	1.1431
10	1.1431		1.0669	1.0669	.9907	1.1431
11	1.0669		1.1431	1.2193	1.0669	1.2193
12	1.0669		1.2193	1.2193	1.1431	1.2955
13	1.2955		2.1014	1.2955	2.0073	1.2955
14	1.2955		1.3717	1.3717	1.2955	1.3717
15	1.3717		1.3717	2.1597	1.3717	1.3717
16	1.3717	.7522	1.3717	1.3717	1.2955	1.3717
17	1.2955		1.2955	1.3717	1.2193	1.3717
18	1.2193		2.0073	1.2193	1.9357	1.2955
19	1.2955		1.2955	1.3717	1.2955	1.3717
20	1.448		1.448	1.448	1.448	1.448
21	1.448		1.448	2.2406	1.448	1.448
22	1.2955		1.3717	1.448	1.3717	1.448
23	.8383	.7164	1.2955	1.3717	1.3717	1.3717
24			1.2955	1.9402	2.0119	1.9402
Max	1.448	1.2193	2.1014	2.2406	2.0119	1.9402
Min	.8383	.6447	.9145	.9907	.9907	.9907
Avg	1.1796	.8332	1.2730	1.3279	1.2928	1.2811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 202 / 11 KV TOWN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8269	.8337	.8253	.8512	.8421	.868
2	.8086	.7979	.7948	.8307	.8223	.8497
3	.8032	.7849	.7865	.8078	.8139	.8208
4	.8017	.7804	.7773	.7926	.8078	.8086
5	.7933	.7849	.7598	.7865	.8154	.8032
6	.7956	.7918	.7628	.7796	.8322	.7941
7	.7712	.7667	.7956	.7407	.8566	.7842
8	.7697	1.3717	.8078	.7819	.8566	.8063
9	.7674	.7346	.8147	.8048	.8726	.7971
10	.7781	.788	.7727	.8162	.7788	.8703
11	.7308	.7316	.5975	.7491	.7225	.7705
12	.7164	.7186	.7087	.7369	.7026	.7392
13	.6805	.7042	1.3976	.756	1.3718	.7857
14	.7339	.7164	.7308	.743	.6767	.7453
15	.7438	.724	.711	1.3999	.7125	.7225
16	.7186	1.4014	.7118	.7064	.7377	.6851
17	.6965	.7301	.6798	.6981	.692	.6767
18	.6889	.612	1.3214	.6737	1.2879	.6897
19	.8078	.7842	.7499	.7788	.7423	.7811
20	.9046	.8962	.8566	.8977	.9046	.9168
21	.9	.884	.8817	1.6149	.9038	.9275
22	.8794	.8962	.8749	.9054	.9122	.932
23	.5479	1.5485	.8939	.916	.9275	.9511
24		.8604	.8916	1.4937	1.4541	1.6011
Max	.9046	1.5485	1.3976	1.6149	1.4541	1.6011
Min	.5479	.612	.5975	.6737	.6767	.6767
Avg	.7680	.8601	.8294	.8776	.8769	.8386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 203 / 11 KV TOWN 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.9907	.9526	.9526		
2	.9526	.9526	.9145	.9526		
3	.9145	.9145	.8764	.9145		
4	.9145	.8764	.8383	.8764		
5	.8764	.8764	.8383	.8002		
6	.8383	.9145	.8002	.8383		
7	.8383	.8383	.7621	.7621		
8	.8002	1.371	.8383	.8002		
9	.8002	.724	.8002	.7621		
10	.6859	.6859	.7621	.724		
11	.724	.724	.7621	.7621		
12	.724	.724	.7621	.7621		
13	.8002	.8002	1.3375	.8002	.6805	
14	.8002	.8764	.8383	.8002		
15	.8764	.8764	.8764	1.6263		
16	.9145	1.5211	.8764	.8002		
17	.9145	.9145	.8002	.8002		
18	.8383	.8764	1.4426	.7621	.6805	
19	.9145	.9145	.8383	.8383		
20	.9907	.9526	.9526	.9526		
21	.9907	1.0288	.9907	1.6712		
22	.9907	1.0288	1.0288	1.0288		
23		1.5661	1.0288	1.0669		
24		.9907	1.0288	1.6556	.6268	.6447
Max	.9907	1.5661	1.4426	1.6712	.6805	.6447
Min	.6859	.6859	.7621	.724	.6268	.6447
Avg	.8677	.9558	.9144	.9462	.6626	.6447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 204 / 11 KV INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2149				
13		.2507		.2507	
15			.2507		
16	.2149				
18		.2149		.2149	
21			.2149		
23	.1791				
24			.1433	.1791	.1791
Max	.2149	.2507	.2507	.2507	.1791
Min	.1791	.2149	.1433	.1791	.1791
Avg	.2030	.2328	.2030	.2149	.1791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 205 / 11 KV TOWN 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.833	.8604	.8558	.8741
2	.7979	.7857	.8223	.8048	.807
3	.7392	.7674	.7994	.7888	.7918
4	.7225	.7346	.7903	.7918	.7644
5	.7095	.7133	.7667	.7392	.7285
6	.7202	.7186	.7186	.7484	.7194
7	.695	.7209	.7232	.7575	.7164
8	1.2369	.6607	.6859	.7285	.6943
9	.6729	.7057	.6935	.7346	.6843
10	1.0334	.6965	1.0044	.6744	.9968
11	.7819	.7552	.74	.7042	.7552
12	.6866	.8436	.8284	.6897	.7621
13	.7682	1.5234	.8634	1.4236	.881
14	.7781	.8726	.852	.7644	.8551
15	.8185	.8718	1.5432	.8855	.9343
16	1.5157	.8833	.8711	.8848	.9534
17	.8505	.8794	.8444	.8314	.9366
18	.8474	1.4769	.8345	1.4403	.8032
19	.7773	.7865	.8802	.7194	.7636
20	.8733	.8787	.9534	.8505	.8893
21	.9465	.8779	1.6042	.9054	.913
22	.9663	.8855	.9838	.8932	.9236
23	1.5752	.8794	.9305	.9137	.913
24	.9305	.8703	1.5489	1.5177	1.4594
Max	1.5752	1.5234	1.6042	1.5177	1.4594
Min	.6729	.6607	.6859	.6744	.6843
Avg	.8875	.8592	.9226	.8770	.8550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 206 / 11 KV BHAKTAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5731				
13		.6089		.3582	
15			.7164		
16	.6089				
18		.7164		.6805	
21			.6447		
23	.5731				
24			.5373	.5731	.6447
Max	.6089	.7164	.7164	.6805	.6447
Min	.5731	.6089	.5373	.3582	.6447
Avg	.5850	.6627	.6328	.5373	.6447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 207 / GOVT. HOSPITAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
FEEDER Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0179				
13		.0179		.0179	
15			.0179		
16	.0179				
18		.0179		.0179	
21			.0179		
23	.0179				
24			.0179	.0179	.0179
Max	.0179	.0179	.0179	.0179	.0179
Min	.0179	.0179	.0179	.0179	.0179
Avg	.0179	.0179	.0179	.0179	.0179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 201 / 11 KV MUKRAMABAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734		.3772		.415	.4066	.4024
2	.4066		.3395		.3772	.3734	.4435
3	.4435		.3395		.415	.4066	.4108
4	.4854		.4527		.4481	.4481	.4108
5	.4481						
6	.4481						
7	.4805						
8	.4527						
9	.5975						
10	.5175						
11	.4805	.4854	.6722		.6283	.6516	.4805
12	.4435		.6348		.6653	.5373	.5121
13	.4108		.5975		.6219	.4908	.5014
14	.3734		.5601		.5853	.4908	.543
15	.4108		.5228	.4854	.5175	.4344	.5014
16	.4481	.3658	.4854	.4481	.4805	.4656	.4557
17		.3292	.4481	.4854	.4656	.4344	.5014
18		.4854	.4854	.4854	.5487	.4706	.5487
19		.5601	.5228	.5658	.5601	.4805	.5914
20		.4854	.5975	.6036	.5228	.4805	.5601
21		.5228	.5601	.5601	.4904	.5175	.3628
22		.4854		.5228	.4854	.5121	.5228
23		.4527		.4904	.4481	.4805	.4854
24	.4108		.415		.4904	.4344	.4435
Max	.5975	.5601	.6722	.6036	.6653	.6516	.5914
Min	.3734	.3292	.3395	.4481	.3772	.3734	.3628
Avg	.4489	.4636	.5007	.5163	.5092	.4731	.4821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 202 / 11 KV GOJEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709		.9431		.9709	1.1203	.8573
2	.9979		.9054		.9054	1.0456	.8916
3	1.0456		.7922		.9431	1.0082	.8916
4	1.1203		1.0185		1.0562	1.0719	.9602
5	1.1946						
6					1.1317		
7	1.419						
8	1.307						
9	1.3817					.9259	
10	1.2567					1.1317	
11			1.1949		1.3676	1.1317	.9979
12			1.4937		1.4415	1.0631	1.0608
13			1.3817		1.4632	1.0288	1.1104
14			1.2696		1.4266	1.0631	1.1946
15			1.3443		1.4045	1.0288	1.2536
16			1.307	1.2696	1.3306	1.1317	1.2269
17			1.3443	1.2696	1.0387	1.2346	1.182
18				1.2323	1.1706	1.2689	1.134
19		1.0829		1.3817	1.307	1.1317	1.1088
20		1.1949		1.2696	1.3443	1.2003	1.1203
21		1.1203		1.1949	1.2826	1.0974	1.0456
22		1.0082		1.1694	1.2696	1.0631	1.0456
23		.9808		1.1317	1.2449	.9945	1.0082
24	.9335		1.0185		1.1317	1.1462	.9259
Max	1.419	1.1949	1.4937	1.3817	1.4632	1.2689	1.2536
Min	.9335	.9808	.7922	1.1317	.9054	.9259	.8573
Avg	1.1627	1.0774	1.1678	1.2399	1.2227	1.0944	1.0564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 203 / 11 KV RAVANKOLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392		.5281		.679	.7545	.5853
2	.7842		.5281		.679	.7468	.5487
3	.8299		.6036		.7167	.8029	.5487
4	.8299		.7167		.7922	.9808	.5792
5			.7468		.8589	1.0185	.6154
6			.7842		1.0829	1.0829	.8596
7					1.2696	1.1949	.3856
8			1.3443		1.307	1.1827	.9816
9			1.1827		1.2197	1.0631	1.0387
10			1.1203		.9979	.9259	1.0631
11	1.2197	1.0456					
12	1.4045						
13	1.1203						
14	1.0829				.8871		
15	1.0456				.9979	.5487	
16	1.0829	.9511			.924	.8238	
17				.8962	.8954	.8916	.7164
18		1.1088		1.2323	.9335	.583	.8413
19		1.0829		1.1949	1.0829	.6859	.961
20		1.0082		1.0456	1.0456	.8063	.9335
21		.9709		.9335	1.0562	.7545	.9335
22		.8962		.9054	1.0082	.6859	.8589
23		.8676		.8676	.9431	.5959	.8589
24	.7468		.5658		.7922	.8501	.5792
Max	1.4045	1.1088	1.3443	1.2323	1.307	1.1949	1.0631
Min	.7392	.8676	.5281	.8676	.679	.5487	.3856
Avg	.9896	.9914	.8121	1.0108	.9604	.8489	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 204 / 11 KV SAWARMAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361		.3395		.415	.3696	.2614
2	.3734		.3772		.3772	.3361	.2987
3	.1753		.415		.4527	.3361	.2614
4	.2987		.4481		.4904	.4108	.3547
5			.4854		.5281	.5228	.3326
6			.5228		.5975	.5914	.4938
7					.6722	.6348	.5609
8			.5601		.7095	.7392	.5609
9			.4805		.7392	.6516	.5373
10			.5975		.5175	.5731	.4607
11	.7392	.4854					
12	.6722						
13	.6722						
14	.6348						
15	.5975						
16	.5601	.5487					
17		.4066		.4854	.2149	.543	.4656
18		.5914		.5228	.439	.6154	.439
19		.5601		.5975	.5601	.439	.5175
20		.3734		.6348	.5228	.4435	.5601
21		.3734		.4854	.4527	.3326	.5228
22		.3734		.4854	.4108	.3326	.5228
23		.3772		.4527	.4527	.3326	.5228
24	.3734		.3395		.4527	.4108	.0299
Max	.7392	.5914	.5975	.6348	.7392	.7392	.5609
Min	.1753	.3734	.3395	.4527	.2149	.3326	.0299
Avg	.4939	.4544	.4566	.5234	.5003	.4786	.4279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 201 / 11 KV TAMLOOR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4481	.3174
2				.4481	.3174
3		.4481	.3734	.4481	.3174
4			.4481	.4481	.3174
10					.3734
11				.3174	
12		.4481	.4668	.3361	.3547
13			.4481	.3361	.4294
14			.4108	.3361	.4108
15		.3921	.4294	.3361	.3921
16			.4294	.4108	.4108
17			.4294	.4108	.4294
18	.3921		.4481	.2987	
19			.5415	.3547	.2427
20			.5228	.3921	.2427
21			.4854	.3734	.2241
22			.4854	.3547	.2054
23			.4668	.3361	.1867
24		.4668	.4481	.4481	.3174
Max	.3921	.4668	.5415	.4481	.4294
Min	.3921	.3921	.3734	.2987	.1867
Avg	.3921	.4388	.4556	.3796	.3229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 202 / 11KV NARANGAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-APR-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2614	.2987
2				.2801	.2987
3		.2801	.3361	.2801	.2987
4				.2987	.3174
5				.3174	.3361
6		.2801	.3921	.3547	.4294
8				.3921	.3734
9		.2987	.3734	.2801	.3921
10			.4108	.3174	
16					.2241
17			.2241	.2241	.2614
18	.2241		.2427	.2241	.2614
19			.3361	.3361	.3361
20			.3361	.3921	.2241
21			.3174	.3734	.2054
22			.2987	.3361	.1867
23			.2801	.3174	.168
24		.2241	.2427	.2614	.2987
Max	.2241	.2987	.4108	.3921	.4294
Min	.2241	.2241	.2241	.2241	.168
Avg	.2241	.2708	.3159	.3086	.2888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 203 / 11 KV SANGVI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1867	.1494
2				.1867	.6535
3		.1307	.9335	.2241	.6535
4				.2241	.7468
5				.9335	.7468
6		.2054	1.1203	1.0829	.8215
7				1.1576	.9896
8				1.1949	1.0829
9		1.1576		1.2323	1.0082
10			1.0269	.7468	
12		1.0829			
16					.1494
17			.1867	.1494	.2054
18	.2241		.2241	.168	.1867
19			.2427	.2241	.2614
20			.2427	.2241	.2054
21			.2241	.2054	.2054
22			.1867	.1867	.1867
23			.168	.168	.168
24		.1307	.112	.1494	.1494
Max	.2241	1.1576	1.1203	1.2323	1.0829
Min	.2241	.1307	.112	.1494	.1494
Avg	.2241	.5415	.4243	.4803	.4761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 201 / 11 KV KARADKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.8573		
2					.8573		
3					.8573		
4					.8573		
11	1.9784		.2172	1.6289	1.8861		
12			.2012	2.1795	1.9281		
13			1.8004	2.3148			
14			2.1434	2.2634			
15			2.1434	2.1125			
16			2.0919	2.0119	1.7814		
17			2.0576	2.0454	1.8623		
18	2.0454	1.1633	1.9547	2.0233	1.9433		
19			1.0288	1.0288	1.086		
20			1.2003	1.2003			
21			1.1145	1.2003			
22			1.0288	1.1145			
23			1.0059	1.0288	.9955	.9955	1.086
24	1.0498	.2172	.5792		.9431	.9955	.9955
Max	2.0454	1.1633	2.1434	2.3148	1.9433	.9955	1.086
Min	1.0498	.2172	.2012	1.0288	.8573	.9955	.9955
Avg	1.6912	.6903	1.3262	1.7040	1.3213	.9955	1.0408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 202 / 11 KV MARKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5655	1.2772	1.2772	1.0075	1.0425
2			.5571	1.2499	1.2521	1.012	.9854
3			.5662	1.2369	1.2696	.9983	1.0258
4			.602	1.2475	1.3412	1.057	1.0517
5			.6158	.9442		.0297	.4146
6			.0229	.2279			
9			.7293				
10			.8787	.2324	.1829	.2096	.4374
11	.6762		1.7392	1.803	1.717	.9564	1.0326
12			1.8945	2.0302	2.0149	1.0037	1.0463
13			1.9059	2.0698	.9869	1.0052	1.025
14			1.8229	2.0484	.9328	.8299	.9229
15			1.768	1.7627	.8817	.7926	.9602
16			1.65	1.7223	1.8648	.9351	.9648
17			1.6	1.7596	1.8408	.9122	.8924
18	.9054	.5426	1.608	1.5439	1.7936	.881	.7758
19			1.5874	1.5897	1.6453	1.2422	1.2102
20			1.6434	1.7055	1.3405	1.2818	1.1965
21			1.6316	1.6178	1.2711	1.2422	1.278
22			1.5634	1.5539	1.2224	1.2048	1.1744
23			1.4777	1.451	1.4609	1.4998	1.4178
24	.362	.3077	1.5731	1.3611	1.3839	1.4079	1.3881
Max	.9054	.5426	1.9059	2.0698	2.0149	1.4998	1.4178
Min	.362	.3077	.0229	.2279	.1829	.0297	.4146
Avg	.6479	.4252	1.2728	1.4493	1.3516	.9754	1.0121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 203 / 11 KV KINI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5769	1.049	1.0563	.8223	.8406
2			.5639	1.0406	1.0273	.8215	.8391
3			.57	1.0406	1.0235	.8238	.8269
4			.5754	1.0852	1.108	.8551	.8551
5			.5822	.8314	.4679	.8779	.8459
6			.602	.8657			
7				.2572			
11	.8048		1.3481	1.5227	1.6643	.8154	.8322
12			1.3761	1.9349	1.8885	.9854	1.0059
13			.8733	1.8793	.9831	.9069	.9831
14			.7727	1.8625	.9579	.8977	.9694
15			.8551	1.8343	.8733	.9191	.9747
16			.9206	1.864	1.6343	.9389	.9785
17			1.8267	2.1079	1.7429	.9717	.9922
18	.8478	.7377	1.8579	1.8991	1.7798	1.0151	.9899
19			1.2673	1.0734	1.2797	.9092	.8787
20			1.3497	1.3344	.9518	1.0136	1.0098
21			1.3333	1.3188	.9717	1.0128	.9762
22			1.246	1.2597	.9305	.9869	.9503
23		.1463	1.1389	1.1679	1.1904	1.1871	1.15
24	.3258		1.2965	1.0985	1.0883	1.1387	1.1037
Max	.8478	.7377	1.8579	2.1079	1.8885	1.1871	1.15
Min	.3258	.1463	.5639	.2572	.4679	.8154	.8269
Avg	.6595	.442	1.0466	1.3489	1.1905	.9421	.9475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 204 / 11 KV DEGLOOR WATER SUPPLY NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.264		
2					.2526		
3					.2503	.1097	
4			.1334		.2526	.1311	.1364
5			.1463	.2408	.2511	.128	.1303
6			.1265	.2355	.2488	.1357	.128
7			.1219	.2317	.2488	.1448	.1318
8			.128	.2702	.2496	.1318	.1326
9			.1257	.2648	.2358	.1288	.1303
10		.1094	.0564	.2595	.2203	.1265	.1311
11	.0926		.2164	.1029	.2286		
12			.2398	.0008	.2564		
13			.2518		.1372		.1204
14			.2663	.0198	.1379		.1539
15			.2686		.1372	.0084	.1372
16			.2663		.2332	.1433	.1425
17			.2625		.2355	.1379	.1417
18	.1134		.2633		.245	.1349	.1608
19			.2881		.2378	.1357	.1532
20			.295	.1547		.1372	.1486
21			.1318	.2873		.1364	.1517
22				.2896		.1425	.1387
23		.0926		.282		.1395	.1052
24			.1109	.1448	.12		
Max	.1134	.1094	.295	.2896	.264	.1448	.1608
Min	.0926	.0926	.0564	.0008	.12	.0084	.1052
Avg	.103	.101	.1947	.1989	.2221	.1266	.1375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 205 / 11 KV CHAKUR EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

FEEDER Feeder KV- 11 /

(CONTINOUS PROCESS)(NO STAGGERING)

OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0747	.112		
2				.0747	.112		
3				.0747	.112		
4				.0747	.112		
5				.0747	.112		
6				.0747	.112		
7				.0747	.112		
8				.0934	.112		
9				.112	.112		
10				.1494	.112		
11	.156		.208	.1791	.2149		
12			.2374	.2103	.2012		
13			.2401	.2328			
14			.2229	.2229			
15			.2229	.2229			
16			.2204	.2229	.2172		
17			.2229	.2229	.2172		
18	.2254	.0895	.2229	.2279	.2172		
19			.1715	.1254	.1478		
20			.1372	.1254			
21			.1307	.128			
22			.1307	.128			
23			.0934	.1307	.1109		.0924
24	.0934	.0934	.0934	.0747	.112	.0924	.0905
Max	.2254	.0934	.2401	.2328	.2172	.0924	.0924
Min	.0934	.0895	.0934	.0747	.1109	.0924	.0905
Avg	.1583	.0915	.1825	.1388	.1421	.0924	.0915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174103 / 33 KV S/S KHANAPUR MIDC

Feeder No / Name : 201 / 11 KV MIDC-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2801	.2829	.2801	.2801	.1715
2	.1715	.1715	.2829	.2801	.2801	.2829	.1715
3	.1715	.1715	.2801	.2829	.2829	.2801	.1715
4	.1715	.1715	.1867	.2829	.2801	.2801	.1715
5	.2058	.2058	.1867	.2829	.2801	.2801	.1886
6	.2058	.2058	.2829	.2829	.2829	.2801	.1886
7	.2401	.2058	.2829	.3734	.2801	.2829	.2572
8	.2401	.1886	.2829	.3734	.3772	.2829	.2915
9	.2572	.3734	.2801	.3734	.3772	.2829	.3429
10	.4115	.3429	.4715	.3734	.3734	.2743	.3772
11	.4458	.4287	.4715	.3772	.3772	.2743	.3772
12	.463	.4715	.4715	.4715	.4715	.2915	.3772
13	.4458	.4715	.4715	.4668	.4715		.3772
14	.4458	.4715	.4715	.4715	.4715		.3772
15	.4458	.4715	.4715	.4668	.4715	.2058	.3772
16	.4458	.4715	.4715	.4668	.4715	.2401	.3772
17	.4115	.4668	.3772	.3772	.4715	.2401	.3601
18	.3772	.4668	.3772	.3734	.4715	.2401	.3429
19	.3429	.3734	.3772	.3772	.3772	.2401	.3086
20	.3086	.3772	.3734	.3772	.3772	.2229	.3086
21	.2743	.3772	.3734	.3772	.3772	.2229	.2743
22	.2229	.2829	.2801	.362	.3734	.2229	.2058
23	.2058	.2829	.2801	.2801	.3772	.2058	
24	.2401	.2058	.2829	.2829	.2829	.2801	.2058
Max	.463	.4715	.4715	.4715	.4715	.2915	.3772
Min	.1715	.1715	.1867	.2801	.2801	.2058	.1715
Avg	.3051	.3261	.3486	.3632	.3724	.2588	.2870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174103 / 33 KV S/S KHANAPUR MIDC

Feeder No / Name : 202 / 11 KV TADKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.6001	.4715	.7545	.9431	.9335	.6001
2	.7716	.6001	.7545	.9431	.9335	.9335	.6001
3	.7716	.6001	.7545	.9431	.9335	.9335	.6859
4	.8573	.6001	.7545	.9431	1.1317	1.1317	.7716
5	.8916	.6516	.9431	.9431	1.1317	1.1203	.8573
6	.9259	.7888	1.0374	1.1317	1.2136	.9335	.9259
7	.9945	.8916		1.2136	1.226	1.1317	1.0631
8	1.046	1.0117	.8488	1.1203	1.2136	1.1317	1.0974
9	1.0288	.9145	.9335	1.226		1.1317	1.0974
10	1.0288	1.1203	.9431	1.226			
11	.3086		1.0374				.7202
12	.3429					.2743	.7202
13	.3429					.2743	.7545
14	.3429					.3086	
15	.3429	.4668			.9145	.3086	
16	.3429	.4668			.9431	.3086	.4287
17	.3601	.4668	.5658	.9431	.9431	.3086	.4115
18	.3772	.3734	.5658	.9431	1.1317		.4115
19	.3772	.5601	.6602	.9431	1.1317		.4801
20	.3772	.6602	.7545	.9431	1.1317	.4287	.5144
21	.3772	.6602	.7545	.9431	1.1317	.4801	.5144
22		.6602	.7468	.8488	1.1317	.5144	.5316
23	.3772	.5658	.7468	.8488	.9431		.4801
24	.5144	.3772	.4715	.5601	.7468	.7545	.4287
Max	1.046	1.1203	1.0374	1.226	1.226	1.1317	1.0974
Min	.3086	.3734	.4715	.5601	.7468	.2743	.4115
Avg	.6031	.6518	.7636	.9677	1.0487	.7022	.6712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174110 / 33 KV S/S DAPKA

Feeder No / Name : 201 / 11 KV DAPKA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1187	.1509	.1677	.1696	.1543	.1372
2	.1696	.1187	.1677	.1844	.1715	.1543	.1372
3	.1865	.1341	.1677	.1844	.1696	.1715	.1543
4		.1341	.1989	.2155	.1865	.2058	.1715
10							.2572
11	.1696	.2458	.2785	.2374	.1696	.1886	.2058
12	.2622	.2622	.2294	.2204	.1715	.1886	.2458
13	.2622	.2155	.2458	.2204	.2572	.1718	.2622
14	.2294	.1989	.213	.1865	.1886	.1715	.2294
15	.213	.1823	.1823	.1865	.1715	.1722	.2622
16	.1989	.1989	.1989	.2035	.1715	.1715	.2458
17	.2458	.2294	.1989	.1966	.1886	.1886	.2622
18		.2458	.2294	.1865	.1717	.2229	.1677
19	.1823	.2155	.1989	.2035	.1865	.2229	.1677
20	.2294	.1989	.1989	.213	.2229	.2229	.2458
21		.1844	.1989	.2204	.2058	.1715	.2622
22		.1823	.1823		.1696	.1886	.2294
23		.1844	.1677	.1865	.1715	.1715	.2321
24	.1526		.1509	.1677	.1715	.1715	.1543
Max	.2622	.2622	.2785	.2374	.2572	.2229	.2622
Min	.1526	.1187	.1509	.1677	.1696	.1543	.1372
Avg	.2043	.1912	.1977	.1989	.1842	.1839	.2121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174110 / 33 KV S/S DAPKA

Feeder No / Name : 202 / 11 KV BAMNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.2622	.3277	.4588	.6173	.5144	.5144
2	.6443	.2785	.3605	.4915	.6255	.5487	.5144
3	.6783	.2622	.3932	.5243	.6443	.583	.5487
4	.6718	.2949	.426	.5506	.6783	.6173	.583
7					.6588		
11		.5506	.7125	.78	.7202	.7923	.823
12	.8002	.8002	.8642	.8817	.8402	.8402	.8002
13	.8162	.7125	.8322	.8817	.823	.7716	.8802
14	.7682	.7287	.8002	.8309	.7545	.7888	.8002
15	.7287	.6802	.7842	.8817	.6783	.7888	.7773
16	.6802	.7125	.8322	.9156	.5935	.7733	.7287
17	.7842	.8322	.8482	.9156		.8573	.7287
18	.5407		.8002	.9088	.7888	.9259	.8002
19	.7125	.6964	.7611	.8059	.7373	.6889	.6478
20	.6478	.6478	.5243	.7461	.6783	.6516	.7287
21		.5992	.5506	.6783	.6516	.6344	.6478
22		.5506	.5182	.6783	.6104	.6001	.6154
23		.5182	.4858	.6516	.5487	.5487	.583
24	.6104		.2949	.4915	.6443	.5505	.5144
Max	.8162	.8322	.8642	.9156	.8402	.9259	.8802
Min	.5407	.2622	.2949	.4588	.5487	.5144	.5144
Avg	.6924	.5704	.6176	.7263	.6830	.6931	.6798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174110 / 33 KV S/S DAPKA

Feeder No / Name : 203 / 11 KV HATRAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1475	.1341	.1844	.1989	.2058	.1543	.1715
2	.1526	.1509	.1677	.1989	.1886	.1543	.1543
3	.1715	.1509	.1989	.2155	.1886	.1715	.1543
4	.1865	.1677	.2294	.2458	.2229	.1886	.1715
11	.2204	.2622	.2458	.2374	.2229	.2058	.2743
12	.3077	.2622	.2949	.3052	.2883	.1718	.2622
13	.3239	.2949	.3077	.3052	.2743	.2062	.2458
14	.2949	.2785	.2622	.2713	.2743	.2062	.2294
15	.2622	.2622	.2622	.2713	.2229	.2572	.2622
16	.3077	.2949		.2713	.2058	.2921	.2458
17	.3401	.2622	.2458	.2543		.3258	.2622
18	.3239	.2785	.2915	.3391	.2058	.3086	.2622
19	.2949	.2622	.2785	.2883	.1696	.2915	.1677
20	.2622	.2294	.2785	.2204	.2229	.2915	.2458
21		.2458	.2622	.2374	.2229	.2915	.2622
22		.2294	.2458	.2204	.2204	.2229	.2458
23		.1989	.2294	.2035	.1715	.2058	.2294
24	.1475		.1844	.1989	.206	.1715	.1886
Max	.3401	.2949	.3077	.3391	.2883	.3258	.2743
Min	.1475	.1341	.1677	.1989	.1696	.1543	.1543
Avg	.2496	.2332	.2453	.2491	.2184	.2287	.2242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174117 / 33 KV DEGLOOR-II

Feeder No / Name : 201 / 11 KV SAI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				.543	
20				.724	
24	.724	.7011	.724	.543	.724
Max	.724	.7011	.724	.724	.724
Min	.724	.7011	.724	.543	.724
Avg	.724	.7011	.724	.6033	.724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174117 / 33 KV DEGLOOR-II

Feeder No / Name : 203 / 11 KV HOTTAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				.905	
20				.905	
24	.724	.7362	.724	.905	.724
Max	.724	.7362	.724	.905	.724
Min	.724	.7362	.724	.905	.724
Avg	.724	.7362	.724	.905	.724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 201 / 11 KV DHARMABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.8046	1.8313	3.2914	2.0721	1.938
2		1.4146	3.4408	1.7795	2.0241	1.9677	3.4741
3			1.7353	1.7482	1.9563	1.8968	1.8389
4	1.7177		3.1733	1.6834	3.2411	3.5124	1.8
5			1.6583	1.6606	1.845	1.8069	1.7665
6		1.4146	3.0403	1.5988	1.8145	3.2511	3.2
7			1.5988	1.448	2.9988	1.5623	1.6187
8	1.2136	1.307	2.609	1.464	1.6476	2.628	2.7953
9			1.4114	1.4853	1.6469	1.3123	1.5264
10	1.307	1.2696	2.9836	1.7292	2.9226	2.6234	3.4416
11			1.7124	1.8991	1.8099	1.6651	2.0005
12		1.587	1.9044	2.0469	3.9445	3.3634	2.1018
13			1.9799	1.9677	2.0995	1.9372	2.1346
14	1.4784	1.587	1.9974	1.9883	2.0355	3.7065	1.9265
15			1.9624	1.9006	2.0157	2.0332	1.8877
16	1.5708	1.587	1.8648	1.8877	3.9095	3.6783	1.9753
17			1.8008	1.8991	1.9547	1.8206	2.0149
18	1.386	1.4003	1.8473	1.8381	3.8516	3.4812	3.7528
19			1.9944	2.1102	2.2413	2.0127	2.0469
20	1.6975	1.6804	2.0332	2.1254	2.1971	4.2033	2.1369
21			2.0279	2.1285	2.21	2.1049	4.0516
22	1.8861	1.8671	2.0995	2.0988	4.4037	4.1128	2.1193
23			2.0858	3.557	2.2466	2.1437	2.1834
24	1.7177	1.8861	3.7536	2.0683	2.1696	4.0634	3.8699
Max	1.8861	1.8861	3.7536	3.557	4.4037	4.2033	4.0516
Min	1.2136	1.2696	1.4114	1.448	1.6469	1.3123	1.5264
Avg	1.5528	1.5455	2.1883	1.9143	2.5199	2.6233	2.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 202 / 11 KV DIGRAS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2241		
2		.2641	.1867			.1886
4	.1867		.1867	.2987	.2241	
6		.2641	.1867		.2801	.1886
7				.2987		
8	.1494	.2241	.2801		.2801	.1867
10	.2427	.1867	.2801	.2614	.2801	.2241
12	.2241	.112		.112	.2241	
14	.2241	.2801			.1848	
16	.2402	.3361		.112	.2033	
18	.2772	.3734		.112	.2054	.1867
20	.2452	.3734			.2075	
21						.1867
22	.2829	.1494		.1494	.2075	
24	.1867	.2263	.1494		.2829	.1867
Max	.2829	.3734	.2801	.2987	.2829	.2241
Min	.1494	.112	.1494	.112	.1848	.1867
Avg	.2259	.2536	.2116	.1960	.2345	.1926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 203 / 11 KV BABHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7095		
2		.5658	.4668				.6036
4	.2987		.4668		1.0269	.5601	
6		.5658	.4668			.5601	.6602
7					1.2696		
8	.3361	.3921	.7468			.5601	.7468
10	1.1203	.3734	.7468		1.1765	.5601	.0934
12	.4108	.1494			.112	.4668	
14	.4108	1.1203				.0924	
16	1.2012	1.1203			.0934	.0924	
18	1.2936	1.1203			.0934	.0934	.112
20	1.1317	1.0269				.1698	
21							.1494
22	.6036	.2801			.112	.1698	
23				.112			
24	.2987	.6036	.1307			.112	.3361
Max	1.2936	1.1203	.7468	.112	1.2696	.5601	.7468
Min	.2987	.1494	.1307	.112	.0934	.0924	.0934
Avg	.7106	.6653	.5041	.112	.5742	.3125	.3859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 205 / 11 KV RATNALI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6348		
2		.9431	.9335				1.1317
4	.5228		.8402		.5975	1.1203	
6		9.5628	.7468			.9335	1.0562
7					.6348		
8	.4481	.5228	.5601			.5601	.5601
10	.3174	.5914	.4668		.5601	.5601	.5228
12	.3174	.5601			.4668	.4668	
14	.2033	.1867				.4435	.5228
16	.4066	.3734			.4668	.5914	
18	.4435	.4668			.4668	.6535	.4481
20	.9054	.5601				.8488	
21							.5975
22	.7545	.9335			1.1203	1.0562	
23				.6535			
24	.5228	.7545	.9335			1.1203	1.0562
Max	.9054	9.5628	.9335	.6535	1.1203	1.1203	1.1317
Min	.2033	.1867	.4668	.6535	.4668	.4435	.4481
Avg	.4842	1.4050	.7468	.6535	.6185	.7595	.7369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 206 / 11 KV PIONEER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2241		
2		.4527	.3734				.0754
4	.7095				.1494	.2801	
6		.4527	.2801			.1867	.0943
7					.2801		
8	.7468	.4668	.1867			.1867	.0934
10	.6722	.4294	.3734		.0934	.1867	.1494
12	.6348	.5601			.0934	.0373	
14	.6283	.6535				1.1088	.5601
16	.8316	.3734			1.2136	.0554	
18	.8316	.3734			.2801	.0747	.5975
20	.679	.4668				.0754	
21							.2614
22	.7545	.4668			.1867	.0754	
23				.3734			
24	.6722	.0943	.3734			.1867	.0754
Max	.8316	.6535	.3734	.3734	1.2136	1.1088	.5975
Min	.6283	.0943	.1867	.3734	.0934	.0373	.0754
Avg	.7161	.4354	.3174	.3734	.3151	.2231	.2384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 209 / 33 KV PIONEER

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	02-MAY-17
HR	Load (MW)
14	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 211 / RURAL HOSPITAL EXP
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1494		
2		.1698	.1017				.1698
4	.1494		.1017		.112	.1357	
6		.1886	.1187			.1357	.1509
7					.1867		
8	.056	.1478	.1017			.1357	.1663
10	.1478	.1294	.1017		.1494	.1357	.0373
12	.1646	.1017			.1017	.1494	
14	.1629	.1017				.0362	.112
16	.0362	.112			.1017	.0362	
18	.1267	.1017			.1017	.037	.112
20	.132	.1017				.0373	
21							.112
22	.1698	.1017			.168	.1509	
23				.112			
24	.1494	.1886	.1696			.1526	.1698
Max	.1698	.1886	.1696	.112	.1867	.1526	.1698
Min	.0362	.1017	.1017	.112	.1017	.0362	.0373
Avg	.1295	.1313	.1159	.112	.1338	.1039	.1288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 201 / 11 KV KUNDALWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.6584						
7		.5731		.6348	.567		
8			.5975			.6154	.6653
10		.5601					
11	.567			.5373			
13							.5975
15					.5373	.5487	
17			.5601				
18	.6024			.5316			
19							.6348
22					.695	.7392	
23			.6348				
Max	.6584	.5731	.6348	.6348	.695	.7392	.6653
Min	.567	.5601	.5601	.5316	.5373	.5487	.5975
Avg	.6093	.5666	.5975	.5679	.5998	.6344	.6325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 203 / 11 KV GUJARI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.3142						
7		.2658		.2614	.2774		
8						.2218	.2402
10		.2241					
11	.2126			.1907			
15					.1848	.2033	
16			.1494				
18	.2279			.1928			
19							.1867
22					.3326	.3696	
23			.2241				
Max	.3142	.2658	.2241	.2614	.3326	.3696	.2402
Min	.2126	.2241	.1494	.1907	.1848	.2033	.1867
Avg	.2516	.2450	.1868	.2150	.2649	.2649	.2135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 204 / 11 KV KONDALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.5228						
7		.4917					
10		.5788					
11				.3932			
13							.4108
15					.439	.3582	
16			.6722				
18				.3481			
Max	.5228	.5788	.6722	.3932	.439	.3582	.4108
Min	.5228	.4917	.6722	.3481	.439	.3582	.4108
Avg	.5228	.5353	.6722	.3707	.439	.3582	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 205 / 11 KV GUJARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.6722	.4915		
8					.7167	.439
11	.763					
13						.3734
16		.4668				
18	.8817					
Max	.8817	.4668	.6722	.4915	.7167	.439
Min	.763	.4668	.6722	.4915	.7167	.3734
Avg	.8224	.4668	.6722	.4915	.7167	.4062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 206 / 11 KV SHELGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.2801						
7		.2229		.2987	.2743		
8			.2614			.168	.2801
10		.1478					
11	.2103			.1402			
15					.2218	.168	
18	.2279			.2149			
19							.3142
22					.1867	.2987	
23			.2801				
Max	.2801	.2229	.2801	.2987	.2743	.2987	.3142
Min	.2103	.1478	.2614	.1402	.1867	.168	.2801
Avg	.2394	.1854	.2708	.2179	.2276	.2116	.2972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 208 / 11 KV MACHNOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.4854						
7		.3641		.3734	.3506		
8			.3734			.2801	.3547
10		.3361					
11	.3189			.2303			
15					.2427	.3174	
16			.2614				
18	.3721			.2804			
19							.3734
22					.4294	.4668	
23			.5228				
Max	.4854	.3641	.5228	.3734	.4294	.4668	.3734
Min	.3189	.3361	.2614	.2303	.2427	.2801	.3547
Avg	.3921	.3501	.3859	.2947	.3409	.3548	.3641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 201 / 11 KV KARKHELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.8676		.6104	1.0174	.9431	.9739
2	.9054	.9054	.8507	.6104	1.0288	.964	.9739
3	.9431	.9431		.6443	1.1022	1.1145	1.0563
4	.9808	.9431	.7896	.6443	1.1022	1.1145	1.1496
5	1.0374	.9431		.7545	1.1022	1.1145	1.1496
6	1.0562	1.0374	.7896	.8383	1.2209	1.2209	1.2317
7	.8402	.9431	.7733	.8383	1.2209	1.2717	1.2435
8	.9054	.9054		.9221	1.2929	1.2431	1.2231
9	.8488	.8488		.8383	1.1869	1.1603	1.2986
10	.7545	.811	.7019	.7545	1.326	.9945	1.2788
11	.663		.6608	.679	1.1203	.9774	.9326
12	.7122	.8278	.7167	.7545	1.0269		1.0269
13	.763	.7305	.7356	.7545	1.0082	1.0552	1.0269
14	.8478	.6493	.7545	1.1203	1.1203	1.0704	1.0269
15	.763	.7313	.9054	1.0829	.9259	1.029	1.0829
16	.763		.7545	1.0829	.9259	1.0384	1.0829
17	.8139	.8116	.8488	.9709	1.0517	1.0584	1.1203
18	.9431	.8021	.8299	.924	1.286	1.319	1.0719
19	.9431	.9459	.8488	.9335	1.4022	1.512	1.1088
20	.9431	1.0384	.9431	1.0164	.964	1.2474	.8817
21	1.0374	1.0584	.9431	.9431	1.1145	1.2348	.8478
22	1.0374	.945	.9431	.9116	1.1145	1.134	.8288
23	.9431	.9459	.9431	.9116	1.1145	1.134	.8288
24	1.0374	.8488	.9808	.9431	.9116	1.1145	1.1328
Max	1.0562	1.0584	.9808	1.1203	1.4022	1.512	1.2986
Min	.663	.6493	.6608	.6104	.9116	.9431	.8288
Avg	.8912	.8856	.8270	.8535	1.1120	1.1333	1.0658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 202 / 11 KV YETALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0883	1.1869		.8488	.8488	.9774	.8505
2	1.1203	1.3957	.8505	.8299	.8488	.9412	.8505
3	1.1203	1.4146		.8488	.8676	.8779	
4	1.3603	1.4335	.756	.9054	.9054	.8779	.7552
5	1.4575	1.4712		.9054	.9431	.8688	.793
6	1.4403	1.326	.756	.9431	.9808	.9412	.7946
7	1.6194	1.3927	.7938	.9054	.9431	.7682	.793
8	1.5364	1.4746		.8676	.8488	.7602	.7552
9	1.5223	1.4746		.811	.7922	.724	.756
10	1.3765	1.3927	.7938	.7545	.7545	.6584	.6615
11	.7545		1.1363	1.166	1.2146	1.0517	
12	.679	.6615	1.2071	1.4403	1.3765		1.3765
13	.6602	.6615	1.2574	1.4575	1.4575	1.0713	1.4575
14	.6602	.6615	1.278	1.2631	1.3765	1.1687	
15	.5658		1.5089	1.2146	1.3765	1.1289	
16	.6036	.7182	1.3927	1.2146	1.2955	1.176	
17	.6413	.7567	1.3765	1.2003	1.3765	1.1946	
18	.679	.7552	1.3927	1.1523	1.3765	.8765	1.2955
19	.7167	.9858	.9431	.9431	.9774	1.0206	.8907
20	.9054	1.0395	.9431	.9808	.9671	1.0395	1.1827
21	.9431	1.0584	.9431	1.0185		1.0929	1.0374
22	.9431	.9828	1.0374	.9431	1.086	.945	1.0374
23	.9431	.9828	.9431	.9431	1.0242	.945	.9431
24	.9054	.9431	.945	.9431	.9431	1.0242	.9355
Max	1.6194	1.4746	1.5089	1.4575	1.4575	1.1946	1.4575
Min	.5658	.6615	.756	.7545	.7545	.6584	.6615
Avg	1.0101	1.0986	1.0660	1.0208	1.0687	.9622	.9537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 203 / 11 KV ELEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7167		.6706	.8097	.8764	1.0217
2	.7545	.7545		.6706	.8907	.8764	1.1096
3	.7545	.7922		.7545	.8802	.964	1.1096
4	.7545	.8299	.6141	.7545	.9488	.964	1.1888
5	.8488	.8488		.8383	.9488	.964	1.1888
6	.8488	.8488	.579	1.0898	1.012	1.0288	1.2681
7	.8488	.7545	.579	1.1603	1.012		1.2635
8	.7922	.7167	.5948	1.1603	1.0753	1.0174	1.262
9	.7545	.679		1.065	.7287	.9945	1.1056
10	.7545	.6036	.4758	1.0322	.8697	.763	1.0949
11	1.0402		.5213	.6036	.5658	.543	.5658
12	1.1022	1.1106	.5658	.6413	.679		.5658
13	1.0395	1.1376	.5658	.6413	.679	.5103	.6413
14	1.0608	1.1248	.6602	.5658	.6413	.6972	.679
15	1.1603		.6602	.5281	.583	.6615	.679
16	1.1603	1.2513	.7545	.5281	.5959	.6054	.679
17	1.0774	1.2513	.8488	.5281	.6173	.6231	.679
18	1.1317	1.176	.811	.5658	.631	.756	.679
19	.679	.7583	.8299	.9054	.8413	.8316	.7545
20	.7545	.7938	.8488	.9431	.8688	.8419	.9054
21	.8488	.8513	.8488	.8488	.8145	.9072	.8676
22	.8488	.8341	.8676	.8488	.8145	.8513	.8488
23	.7922	.8349	.8488	.8299	.7362	.8505	.8299
24	.8488	.7545	.6892	.7922	.8299	.7682	.8428
Max	1.1603	1.2513	.8676	1.1603	1.0753	1.0288	1.2681
Min	.679	.6036	.4758	.5281	.5658	.5103	.5658
Avg	.8921	.8829	.6928	.7903	.7947	.8134	.9096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174109 / 33 KV JARIKOT

Feeder No / Name : 202 / 11 KV KAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.6516	.8573	.8573	.8573	.9431	.9088
2	1.0288	.6516	.8573	.8573	.8573	.9431	.9088
3	.9431	.6516	.8573	.8573	.8573	.9431	.9088
4	.9431	.6859	.8573	.9088	.8573	.9431	.9259
5	.9431	.7545	.8573	.9431	.8573	.9431	.9259
6	.9431	.8573	.6859	1.0288	1.0288	.9431	.9431
7	.9431	.9602	.6859	.8573	.9431	.8573	.9602
8	.9431	1.046	.6859	.8573		.7716	.9602
9	.9431	1.046	.6859	.8402	.8573	.7716	.9088
10	.9431	.8745	.6859	.7202	.8573	.7716	.8573
11	.6859	.8573	.9602	.7716	.8573	.8573	.9431
12	.7716	.6859	.9774	.8573	1.0288	.8573	.9431
13	.8402	.6859	.9431	.8573	1.0288	.8573	.9431
14	.7202	.6859	.8916	.8573	.8573		.9259
15	.7373	.6859	.9431	.9431	.8573		.9259
16	.7545	.6859	.9259	.6859	.8573		.9088
17	.7716	.6859	.9602	.9431	.7716		.9945
18	.7888	.6859	.9774	.9431	.8573		1.0288
19	.8916	1.0288	.9945	1.0288	1.0288		1.0288
20	1.046	1.0288	1.046	1.0288	1.1145		1.0288
21	1.046	.9431	.9431	1.0288	1.0288		1.0288
22	1.0288	.9431	.8916	1.0288	.9431		
23	.9945	.9431	.8745	.9431	.9431		1.0288
24	1.0288	.9259	.8573	.8573	.9431	.9431	.9259
Max	1.046	1.046	1.046	1.0288	1.1145	.9431	1.0288
Min	.6859	.6516	.6859	.6859	.7716	.7716	.8573
Avg	.9045	.8188	.8709	.8959	.9170	.8818	.9505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174109 / 33 KV JARIKOT

Feeder No / Name : 203 / 11 KV JARIKOT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6001	.7716	.6687	.6001	.6001	.5487
2	.6001	.583	.5144	.6516	.6001	.6001	.5487
3	.6001	.583	.5144	.6516	.6001	.6001	.5487
4	.6001	.583	.5144	.6687	.6001	.6001	.6859
5	.6001	.5658	.5144	.6859	.6001	.6001	.6859
6	.6001	.5487	.6001	.703	.6001	.6859	.7202
7	.6001	.5487	.6001	.7888	.6001	.7716	.7545
8	.6001	.5144	.6001	.7545	.6859	.7716	.7545
9	.6001	.5144	.6001	.7373	.7716	.7716	.7716
10	.5144	.5144	.6001	.3772	.6001	.6859	.7545
11	.7716	.5144	.3944		.6859		.703
12	.7888	.5144	.4458		.6001	.6859	.703
13		.7716	.4801	.5144	.6001	.6001	.6859
14		.7716	.5144	.5144	.5144	.4287	.4801
15		.7716	.4801	.5144	.5144	.4287	.463
16	.7888	.8573	.3944	.5144	.4287		.463
17	.7888	.7716	.4458	.5144	.4287		.463
18	.8059	.7716	.5144	.5144	.5144		.5144
19	.7716	.6001	.6173	.6859	.6859		.6859
20	.6859	.6001	.6859	.6859	.7716		.6859
21	.6687	.6001	.6687	.6859	.6859		.6859
22		.6001	.6687	.6859	.6001		.6859
23	.6344	.6001	.6687	.6001	.6001		.6859
24	.6859	.6173	.6859	.6687	.6001	.6001	.5658
Max	.8059	.8573	.7716	.7888	.7716	.7716	.7716
Min	.5144	.5144	.3944	.3772	.4287	.4287	.463
Avg	.6653	.6216	.5623	.6266	.6037	.6287	.6352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 201 / 11 KV MUKHED TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516		.7545			.6516	.6344
2	.583			.6516		.6173	
3	.583		.6859			.583	
4	.5487			.6173		.5487	
5	.5487	.0514	.6173		.0549	.5144	
6	.583		.583			.5144	
7	.583	.0532		.6516	.0514	.5487	.0514
8	.5487	.0566		.583		.5144	
9			.583			.5144	.5487
10		.6173	.6516		.5487		.583
11	.5316	.6173		.6001		.5316	.6173
12			.6859		.6173		.6516
13	.0549	.6516		.06	.6516		.6516
14		.6859	.6859		.6516	.0532	.6173
15	.0549	.6516		.06	.6173		.6516
16	.0583	.6859	.7202		.5144		.6516
17		.6173		.0617	.583		.6859
18	.0549	.6516	.6516		.6173	.6001	.7202
19	.0943	.7545				.6516	.823
20		.823	.7888		.823		.8573
21	.0652			.0652	.8573		.8573
22		.8916	.7545		.8573	.0617	.823
23	.6327				.7888		.7888
24	.7202		.5144	.6859	.0634	.7202	
Max	.7202	.8916	.7888	.6859	.8573	.7202	.8573
Min	.0549	.0514	.5144	.06	.0514	.0532	.0514
Avg	.4057	.5578	.6674	.4036	.5532	.5084	.6596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 202 / 11 KV CHANDOLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
23	.5144
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 203 / 11 KV PFC

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 206 / 11 MUKHED TOWN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317		1.0631			1.0288	1.0802
2	1.0974			.9945		.9945	
3	1.0288		1.0974			.9602	
4	.9602			.9945		.8916	
5	.9602	.0892	1.0974		.0995	.8573	
6	.9259		1.0631	.8916		.9259	
7	.8916	.9259			.9431	.9602	.8916
8	.8916	.0874		.9259		.9945	
9			.9945			.8573	.9431
10		.9259	1.0631		.9259		.9259
11	.0926	.9602		.096	.9945	.0909	.9602
12			1.0288		.9945		.9945
13	.0892	1.0631		.1029	1.0288		1.0288
14		1.166	.9945		1.0288		1.0288
15	.0926	1.1317		1.0288	.9602		
16	.0943	1.0974	1.0631		.8573		1.0631
17		1.6804		.0995	.9259		1.0974
18	.0892	1.0288	.9602		.9945	.9945	1.166
19		1.166			1.0974	.1115	1.2346
20		1.2346	1.2689		1.2003		1.3032
21	.1063			.1063	1.2689		1.3032
22		1.2346	1.2346		1.3032	.1063	1.3032
23	1.0288				1.2346		1.2346
24	1.2003			1.0288	.1115	1.166	
Max	1.2003	1.6804	1.2689	1.0288	1.3032	1.166	1.3032
Min	.0892	.0874	.9602	.096	.0995	.0909	.8916
Avg	.6675	.9851	1.0774	.6269	.9393	.7814	1.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 207 / Govt.Hospital Express

Feeder Feeder KV- 11 /

INCOMING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174038 / 33 KV AMBULGA

Feeder No / Name : 201 / 11 KV RAJURA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
23	.4801
Max	.4801
Min	.4801
Avg	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174038 / 33 KV AMBULGA

Feeder No / Name : 202 / 11 KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3048	.2439	.1134	.3077	.2458	.1829	.2915
4	.3201	.3048	.1006	.3113	.2984	.2286	.3239
5	.3353						
6			.1475	.3647	.3481	.3658	.3401
8			.1475	.3605	.3812	.16	.4572
10			.1147	.3239	.3353	.2896	
11		.2743					
14	.3048	.1867					
16	.3658	.3481					
18	.3963	.4807	.5093				
20	.381	.2812	.3605	.3018	.3048	.2286	.3048
22	.3048	.2458	.3149	.2818	.3077	.2439	.3048
24			.1147	.3277	.2321	.2743	.2134
Max	.3963	.4807	.5093	.3647	.3812	.3658	.4572
Min	.3048	.1867	.1006	.2818	.2321	.16	.2134
Avg	.3391	.2957	.2137	.3224	.3067	.2467	.3194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174038 / 33 KV AMBULGA

Feeder No / Name : 203 / 11 KV JAHOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0051		.0572	.1294	.0914	.0762	.1372
4	.0069	.0137	.132	.1463	.1294	.2105	.1524
5	.0069						
6			.168	.1475	.1646	.1677	.1677
8			.2427	.2155	.2402	.1219	.1829
9						.061	
10			.1698	.1267	.1524	.1219	
14		.0754					
16	.2743	.1886					
18	.2401	.2427					
19	.2058						
20	.2058	.168	.0934	.0724	.061	.061	.0457
22		.0747	.0754	.0914	.061	.061	.0457
24	.0034	.0137	.056	.0509	.0724	.061	.061
Max	.2743	.2427	.2427	.2155	.2402	.2105	.1829
Min	.0034	.0137	.056	.0509	.061	.061	.0457
Avg	.1185	.1110	.1243	.1225	.1216	.1047	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 201 / 11 KV BARHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 202 / 11 KV DORNALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 203 / 11 KV PAISMAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
23	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 204 / Public Water Work Sugaon NON SHEDDABLE EXPRESS HV FEEDERS
Camp Feeder KV- 11 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 201 / 11 KV YEOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6379	.3544	.4031	.6241	.463		.4681
4	.6733	.4075	.5548	.6173		.5201	.5144
6			.6556	.7108		.6173	.583
8					.8916	.7455	.8402
10				.7202	.8402	.7108	.8589
12	.8916						
14	.7373	.7202					
16	.6516	.8063					
17		.8149					
18	.8573	.9465		.9362	.7628	.7545	.8842
19			.8413				
20	.7716	.3898		.7373	.7282	.6859	.6173
22		.4908	.7701	.6935	.5895	.6001	.583
24	.6201	.3761	.3544	.7087	.5316		.5201
Max	.8916	.9465	.8413	.9362	.8916	.7545	.8842
Min	.6201	.3544	.3544	.6173	.463	.5201	.4681
Avg	.7301	.5896	.5966	.7185	.6867	.6620	.6521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 202 / 11 KV HONWADAJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.7973	.7442	.6836	.8322	1.387		.7011
4	.9214	.8505	.9189	1.406		1.1963	1.3003
6			1.258	2.1498		1.3546	2.1325
8			1.4899		2.1384	2.0805	2.2885
10			1.3321	1.9719	2.1559	2.1605	2.0978
12	2.2291	2.1325					
14	2.2634	1.9719					2.0978
16	2.2291						
17		1.3176					
18	2.1948	1.4373		.7108	.8322	.8402	1.5257
19			1.1744				
20	1.1317	1.0985		1.0749	1.2003	1.2269	1.9418
22		.8589	.9671	.9362	.9259	.9114	1.9456
24	.8859	.8238	.7442	.7973	.7628		.8063
Max	2.2634	2.1325	1.4899	2.1498	2.1559	2.1605	2.2885
Min	.7973	.7442	.6836	.7108	.7628	.8402	.7011
Avg	1.5816	1.2484	1.0710	1.2349	1.3432	1.3958	1.6837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 203 / 11 KV METHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0532	.0532	.0876	.052	.0701		.0514
4	.0532	.0709	.0693	.0857		.0693	.0686
6			.0886	.104		.1387	.1029
8			.1578		.1907	.1372	.156
10			.1227	.1387	.1387	.1372	.156
12	.12	.1387					
14	.1372	.1372					
16	.1029	.1052					
17		.1387					
18	.12	.1227		.052	.052	.052	.052
19			.1052				
20	.1029	.0709		.1052	.0857	.1029	.0693
22		.0526		.0701	.0701	.0686	.0693
23			.0716				
24	.0709	.0537	.0532	.0532	.052		.052
Max	.1372	.1387	.1578	.1387	.1907	.1387	.156
Min	.0532	.0526	.0532	.052	.052	.052	.0514
Avg	.0950	.0944	.0945	.0826	.0942	.1008	.0864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174076 / 33 KV SAWARGAON

Feeder No / Name : 201 / 11 KV JAMB

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174076 / 33 KV SAWARGAON

Feeder No / Name : 202 / 11 KV SAWARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174076 / 33 KV SAWARGAON

Feeder No / Name : 203 / 11 KV KAMJALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174078 / 33 KV SUB-STATION BETMOGRA

Feeder No / Name : 201 / 11kv BETMOGRA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772		.3395	.3395	.3018	
2		.3772		.3395	.3395	.3018	
3		.3772		.3395	.3395	.3018	
4	.3292	.3772		.3395	.3584	.3018	
5		.3772	.3439	.3395	.3395	.3395	.3395
6	.3511	.3772		.3772	.3584	.3395	
7	.3696	.3772	.3921	.3772	.3395	.3361	.3961
8	.3696	.3584	.3961	.3734	.3395	.2987	.415
9		.3772		.3772	.3395		
10	.3326	.3395		.3772	.3584		.3772
11	.3395				.3772	.3292	
12		.3696	.2957				
13			.3018	.3772	.3734		
14	.3206			.3772	.4668		
15	.3206	.3658	.2801	.3584	.3361	.3395	
16	.3086	.3881	.3018		.3734	.3395	
17	.3395		.3395	.3772	.2987	.3206	.3395
18	.3395		.3395	.3772			.3395
19	.3772	.3292	.4715	.415	.4715		.3772
20	.415	.3658	.5658	.4527	.4715		.3395
21	.415	.3734	.4715	.4715	.4715	.3921	.3395
22				.4338	.3772		.3772
23	.3772		.3772	.415	.3772		.3772
24	.3511	.3772	.3475	.3772	.415	.3395	.3395
Max	.415	.3881	.5658	.4715	.4715	.3921	.415
Min	.3086	.3292	.2801	.3395	.2987	.2987	.3395
Avg	.3535	.3697	.3731	.3815	.3755	.3272	.3631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174078 / 33 KV SUB-STATION BETMOGRA

Feeder No / Name : 202 / 11KV KHATGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0374	1.1317	.6602	
2		.7922		1.1317	1.1317	.7545	
3		.7922		1.3203	1.226		
4	.7316	.7922		1.3203	1.2826	.7545	
5		.811	1.2437	1.5089	1.3203	1.1317	1.1317
6	.905	.8299		1.6598	1.3957		
7	.9055	.9054	1.5524	1.6975	1.6975		1.4146
8	.9328	.8676	1.7918	1.8671	1.8107		1.7002
9		.8488		1.6975	1.7918	1.1203	
10	.695	.7545		1.6975	1.8107	1.307	1.4146
11	1.4523				.1867	.5611	
12		.5914					
13					.2801		
14					.4668		
15	1.7353	1.6095			.3361	.6413	
16	1.6975	1.6632			.5601	.6036	
17	1.773		.7545	.4715	.5601	.6413	.7545
18	1.8107		.9431	.7545			.8488
19	1.6221	1.0534	1.1694	.7545	.9431		.8676
20	.9054	1.1088	1.2071	.7733	1.1317		.8488
21	.8676	1.0349	1.094	.7922		1.0456	.8488
22				.7545	.9431		.7545
23	.8488		.7545	.7167	.7545		.7545
24	.8131	.7716	.7947	.7545	.6602	.7545	.7733
Max	1.8107	1.6632	1.7918	1.8671	1.8107	1.307	1.7002
Min	.695	.5914	.7545	.4715	.1867	.5611	.7545
Avg	1.1797	.9517	1.1305	1.1505	1.0201	.8313	1.0093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174078 / 33 KV SUB-STATION BETMOGRA

Feeder No / Name : 203 / 11KV EKLARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431		.9431	.9808	.9808	
2		.9808		.9431	.9431	.9808	
3		.9808		.9431	.9997		
4	1.0719	1.0185		.9808	1.0185	1.0185	
5		1.1694	.9795			1.0374	
6	1.3352	1.226					
7	1.5339	1.2826	1.0974		.8676		
8	1.2752	1.3957	1.0185		.7922		
9		1.4146			.7922		
10	1.1827	1.3203			.8676		
11	.7545			1.4712	1.307		1.358
12		.1663	1.386				1.358
13			1.4146	1.4146	1.4003		1.3203
14	.7733		1.307	1.3203	1.4563		1.094
15	.7545	.8869	1.2696	1.226	1.1949	1.0185	1.1317
16	.7922	.7682	1.3203		1.1949	1.2323	1.2826
17	.7922		1.3203	1.2449	1.1949	1.2449	1.3769
18	.8299		1.4146	1.4146			1.3769
19	1.226	1.2136	1.1694	1.4523	1.226		1.226
20	1.3957	1.3169	1.358	1.4712	1.1317		1.2637
21	1.094	1.2803	1.2071	1.2637	1.2826	1.3203	1.2826
22				1.094	1.1317		1.1128
23	.9054		.9431	1.0374	1.0374		1.1317
24	.9795	.8676	.9979	.9431	1.0185	1.0374	1.0374
Max	1.5339	1.4146	1.4146	1.4712	1.4563	1.3203	1.3769
Min	.7545	.1663	.9431	.9431	.7922	.9808	1.0374
Avg	1.0435	1.0724	1.2136	1.1977	1.0919	1.0968	1.2395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174113 / 33 KV VASANT NAGAR

Feeder No / Name : 201 / 11 KV BOMNALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174113 / 33 KV VASANT NAGAR

Feeder No / Name : 202 / 11 KV SHIRUR D

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174113 / 33 KV VASANT NAGAR

Feeder No / Name : 203 / 11 KV JUNNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 201 / 11 KV NARSI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0951		1.3536	1.3786	1.366	1.483	1.4304
2	1.0761	.6742	1.3086	1.3679	1.3456	1.4617	1.3966
3	1.0913	.6368	1.3024	1.3443	1.3262	1.4518	1.3832
4	1.0967	.6361	1.3083	1.3825	1.3093	1.4396	1.4289
5	1.1637	.6206	1.3265	1.4023	1.3629	1.4974	1.4433
6	1.3245	.6646	1.4309	1.4112	1.5013	1.5689	1.4853
7	1.4259	.7001	1.442	1.527	1.5729	1.6008	1.5509
8	1.4091	.7377	1.547	1.6445	1.6486	1.6478	1.5684
9	1.32	.7491	1.3803	1.7025	1.702	1.4337	1.6438
10	1.2239	.7522	1.6297	1.595	1.8837	1.3939	1.5805
11	2.5278	.7491	1.6674	1.4016	1.6918	1.3877	1.5539
12	2.5826	.7714	1.624	.8368	1.5538	1.3985	.8246
13	2.4996	.7529	1.6872	1.4942	1.8321	1.4151	1.6948
14	2.6303	.6605	1.643	1.6049	1.7139	1.3386	1.5754
15	2.668		1.6198	1.6664	1.5935	1.5375	1.5822
16	2.7432	.6687	1.546	1.6083	1.5737	1.5379	1.5188
17	2.6398	.6361	.7606	1.4967	1.3388	1.5096	1.4381
18	2.5792	.5527	1.4581	1.4934	1.3922	1.4179	1.3841
19	1.2689	.7015	1.5653	1.4601	1.6642	1.5203	1.6187
20	1.361	.7499	1.6202	1.7023	1.71	1.6642	1.7846
21	1.3383	.7506	1.5661	1.6676	1.7017	1.6785	1.7326
22	1.2849	.7476	1.5791	1.6548	1.68	1.5935	1.7298
23	1.2277	.6972	1.5219	1.5752	1.6019	.8063	1.6638
24	1.1835	.7138	1.4005	1.563	1.5309	.9522	1.5958
Max	2.7432	.7714	1.6872	1.7025	1.8837	1.6785	1.7846
Min	1.0761	.5527	.7606	.8368	1.3093	.8063	.8246
Avg	1.6984	.6965	1.4704	1.4992	1.5665	1.4474	1.5254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 202 / 11 KV NAIGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.643	1.609	1.609	1.6804	1.6179	1.643	1.643
2	1.643	1.586	1.5732	1.6804	1.6229	1.643	1.5497
3	1.643	1.5975	1.5412	1.6975	1.5926		1.643
4	1.8107	1.5764	1.5716	1.7353	1.609		1.6975
5	1.8861	1.586	1.6615	1.773	1.6667		1.7737
6	1.9239	1.7723	1.8728	1.8861	1.8709		1.9753
7	1.8861	1.8316	1.8442	1.9243	1.969		2.0119
8	1.9814	1.9064	1.9103	2.1338	1.7778	1.9805	1.7558
9	1.8671	1.8148	1.6397	2.0195	1.8034	1.6221	1.6057
10	1.6385	1.6514	1.5089	1.9433	1.6975		1.7979
11		1.6838	1.6409	1.73	1.8484	1.5466	1.7613
12		1.6512	.5658		1.8861	1.6032	
13	1.9933		.6036	1.8372	1.9243	1.6975	1.7778
14	1.8709		.6287	1.7961	1.7337	1.6032	1.7705
15	1.73		.6413	1.5412	1.8671	1.5089	1.8034
16	1.7282	1.7705	1.8484	1.5975	1.9616	1.6032	1.9121
17	1.7407	1.6229	1.9616	1.7942	2.0195	1.7918	1.8442
18	1.7723	.6619	1.9239	1.765	1.9624	1.8861	1.8889
19	1.8576	1.9811	2.0005	1.9161	2.0936	1.9805	1.918
20	1.8578	2.058	2.2481	1.9448	2.2445	2.0748	1.9938
21	1.7705	2.0288	2.0936	1.9596	2.1125	2.0748	2
22	1.7961	1.8962	1.9427	1.918	1.9239	1.9427	1.9933
23	1.6581	1.7796	1.7924	1.7247	1.773		1.9616
24	1.6975	1.6145	1.6447	1.6804	1.6397	1.6975	1.6632
Max	1.9933	2.058	2.2481	2.1338	2.2445	2.0748	2.0119
Min	1.6385	.6619	.5658	1.5412	1.5926	1.5089	1.5497
Avg	1.7907	1.6990	1.5945	1.8121	1.8424	1.7588	1.8149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 203 / 11 KV CANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0987	.0974	.1299	.2267	.1329	.1113	.1021
2	.1014	.0987	.1661	.2294	.1623	.1143	.1276
3	.0987	.0997	.1978	.2294	.2003	.1943	.1509
4	.1143	.0974	.2329	.2622	.2273	.2294	.1972
5	.1158	.0999	.2646	.3277	.2667	.2984	.3163
6	.1143	.1315	.3254	.426	.3262	.39	.3563
7	.1448	.1292	.3923	.57	.4657	.4862	.4588
8	.1656	.1305	.4566	.5571	.3992	.5197	.4744
9	.1505	.1329	.4657	.2785	.3349	.4359	.4915
10	.1486	.1289	.502	.5571	.4144		.1331
11		.4668	.1429	.1329	.0846	.1718	.0974
12		.5335	.1715		.096	.16	
13	.455	.5219	.1572	.0997	.1097	.1097	.1001
14	.4609		.1551	.13	.1128	.1128	.0997
15	.455	.4106	.1593	.098	.1113	.0812	.0974
16	.4668	.4806	.1448	.0997	.1097	.0823	.0967
17	.4604	.4245	.141	.0979	.1391	.0857	.1305
18	.424	.5024	.1858	.126	.1269	.1097	.1305
19	.3919	.1321	.1692	.1329	.1269	.1113	.1306
20	.1317	.0974	.1269	.1299	.1269	.1286	.13
21	.1315	.1306	.1286	.1299	.1235	.1269	.1329
22	.1306	.1309	.1128	.0979	.1113	.0975	.1001
23	.1302	.1306	.1128	.0979	.1128		.0997
24	.1	.1317	.0979	.1158	.0979	.1158	.1021
Max	.4668	.5335	.502	.57	.4657	.5197	.4915
Min	.0987	.0974	.0979	.0979	.0846	.0812	.0967
Avg	.2269	.2278	.2141	.2240	.1883	.1942	.1850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 201 / 11 KV RUI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4995	1.1203	1.7444	1.853	.7979	1.9376	1.2662
2	.5003	1.1203	2.5598	2.2473	.8543	2.2162	1.2273
3	.4889	1.1203	2.825	2.4764	.8924	2.2282	1.2235
4	.4965	1.1203	2.8692	2.4905	.9099	2.3686	1.326
5	.5437	1.2136	2.7835	1.6053	.9732	2.7344	1.3877
6	.6843	1.307	2.9096	2.9111	1.1976	3.3536	1.7949
7	.6859	1.307	3.1485	3.4412	.9656	3.5349	1.8835
8	.6047	1.2136	3.413	3.6435	.2279	3.5273	2.2268
9	1.7208	1.1203	3.3143	1.2795	3.0361	2.3651	2.2355
10	1.4856	1.1203	3.3448	1.323	3.0849	2.5587	.5148
11	.4725	1.0517	1.5169	.4462	1.7913	1.4757	.4191
12	.5061	1.7528	1.3957	.4664	.4957	1.4109	.3986
13	1.6704	2.1262	1.4079	.4881	1.1317	.4355	.386
14	2.6075	2.2148	1.3782	.4877	.5144	1.3546	.3696
15	2.9737	1.949	1.3565	.4565	1.4414	1.3793	.3685
16	3.4126	1.949	1.3992	.4813	1.7117	1.3969	.3757
17	3.2442	2.1262	1.4578	.5422	1.7002	1.4689	.4256
18	3.5086	1.949	1.4578	.5826	1.7509	1.4635	
19	2.4447	1.1088	1.9589	.7461	2.4169	1.7276	.6165
20	2.3887	1.2936	2.0761	.772	2.3228	.5601	.6562
21	2.3575	1.1088	1.925	.7602	2.1599	.2503	.6478
22	2.1494	1.1088	1.8439	.6977	2.1925	1.574	.5956
23	1.9993	.9335	1.7372	.6379	1.9539	1.5226	.5331
24	.6569	1.307	1.5679	1.6853	.5868	1.8248	1.4487
Max	3.5086	2.2148	3.413	3.6435	3.0849	3.5349	2.2355
Min	.4725	.9335	1.3565	.4462	.2279	.2503	.3685
Avg	1.5876	1.4059	2.1413	1.3550	1.4629	1.8612	.9707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 202 / 11 KV DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3506	.6535	.4668		.7545	.5601
2		.3506	.5601	.4668		.7545	.543
3		.3506	.7468	.4668		.7545	.7468
4		.3582	.8402	.5601		.7468	.7468
5		.5373	.9335	.5601		.8402	.9335
6		.6268	.9335	.7468		.9335	.9335
7		.4477	.9335	.9335		.9335	.9335
8			.9335	.7468			.9335
9	.5201	.5201	.7468		.6535	.8402	.9335
10	.1734	.5258	.8402		.6535	.8402	
11	.5601	.7468	.5201		1.1203	.3429	
12	.5601	.7468	.5144			.4382	
13	.5658	.7468	.4239		.5144		
14	.6268	.6535	.4287		.4334	.3467	
15	.5601	.6535	.4287		.5258	.3506	
16	.5601	.5601			.5258	.3353	
17	.5601	.5601	.4287		.5258	.4287	
18	.7545	.7468	.5144		.5258	.5201	
19	.9431	.9335	.9335		.9335	.9335	
20	.9431	.9335	.9335		.9335	1.1203	
21	.9431	.9335	.7468		.9335	.9335	
22	.9431	.9335	.7468		.8402	.9431	
23	.7468	.9335	.6001		.7545	.7468	
24		.7468	.7468	.5601		.7545	.7468
Max	.9431	.9335	.9335	.9335	1.1203	1.1203	.9335
Min	.1734	.3506	.4239	.4668	.4334	.3353	.543
Avg	.6640	.6477	.6995	.6120	.7053	.7087	.8011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 203 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6161	.6607	.6847		.6984
2		.6139	.6516	.6722		.7133
3		.6116	.6539	.6687		.6904
4		.6562	.6539	.687		.7133
5		.7545	.8288	.831	.8322	.8779
6		.8356	.7808	.9294	.8711	.9396
7		1.0517	.9556	1.086	.9328	1.0014
8		.7968	.8322	1.0928	.9877	.9031
9		.9682	1.0494	2.1617	1.1237	.7236
10		.9168	.9637	.9614	1.2311	.1463
11	1.1214		.0937	.1395	.3338	
12	1.0162					
13	1.1031					
14	.8859					
15	.6596					
16	.6904					
17	.6596					
18	.6401					
19	.048			1.2136		
Max	1.1214	1.0517	1.0494	2.1617	1.2311	1.0014
Min	.048	.6116	.0937	.1395	.3338	.1463
Avg	.7583	.7821	.7386	.9273	.9018	.7407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 204 / 11 KV KAHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5258	.7545	.7468		.8676	.7545
2		.3506	.9431	.7468		.8488	.7545
3		.5258	.9431	.7545		.8488	.9431
4		.6068	.9431	.8488		.9335	.9431
5		.8764	1.0374	.9431		.9431	.9431
6		.8764	1.1317	1.1317		1.1317	.9431
7		.9536	1.4146	1.1317		1.226	.9431
8		.9536	.9431	1.1317		1.0269	.8859
9		1.0402	.9431			.9335	1.3203
10	.8669	.8478	.9431		.9431	.8402	
11	.8402	.8402	.6859		.8669	.7468	
12	.7468	.9335	.6783			.6783	
13	.7468	.9335	.8573		.8573		
14	.7468	.7468	.6859		.7802	.503	
15	.7468	.7468	.8573		.7888	.503	
16	.8402	.8488			.8669	.8097	
17	.8402	.8488	1.0288		.8573	.6859	
18	1.1203	.9335	.8573		8.6248	.6859	
19	1.2136	1.1203	1.1203		1.2136	1.1088	
20	1.2136	1.1203	1.2136		1.0269	1.3203	
21	1.1317	1.1203	1.2136		1.0269	1.3203	
22	.9431	1.0269	1.1203		.9431	1.1317	
23	.7545	.9335	.9335		.9431	.9431	
24		.7468	.7468	.7468		.8488	.9431
Max	1.2136	1.1203	1.4146	1.1317	8.6248	1.3203	1.3203
Min	.7468	.3506	.6783	.7468	.7802	.503	.7545
Avg	.9108	.8524	.9563	.9091	1.5184	.9081	.9374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 205 / TATA Chemicals

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0181		.0179		.0189	
2		.0179		.0179		.0189	
3		.0179		.0181		.0189	
4		.0181		.0179		.0187	
5		.0179	.0181	.0179		.0181	
6		.0179		.0175		.0173	
7		.0179	.0187	.0177			.0173
8		.0179	.0181	.0164		.0173	.0173
9		.0175	.0181		.0189	.0111	.0173
10		.0175	.0189		.0189		
11	.0173		.0185		.008		
12	.0173		.0185				
13	.0175	.0181	.0185		.0091		
14	.0177		.0185		.009	.0173	
15	.0175		.0185		.0088	.0173	
16	.0179		.0187		.0078	.0173	
17	.0177	.0181	.0185		.0175		
18	1.1203		.0185		.0171		
19	.0078		.0189		.0189		
20	.0185		.0185		.0187		
21	.0189	.0179	.0187		.0187	.0173	
22	.0185		.0181		.0189		
23	.0187	.0179	.0181		.0189	.0173	
24		.0187	.0185	.0181		.0189	
Max	1.1203	.0187	.0189	.0181	.0189	.0189	.0173
Min	.0078	.0175	.0181	.0164	.0078	.0111	.0173
Avg	.1020	.0180	.0185	.0177	.0149	.0175	.0173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 201 / 11 KV GADGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.4715	.4715	.3734	.3734	.3734
2	.4287	.4287	.4715	.4715	.3734	.3734	.3734
3	.4287	.5144	.5658	.5658	.4668	.4668	.4108
4	.5144	.5144	.7545	.6602	.6535	.5601	.4668
5	.8573	.8573	.9335	.7468	.8402	.6535	.4668
6	1.2003	1.0288	1.1203	.9335	.9335	.6535	.5228
7	1.3717	1.2003	1.2136	1.2136	1.1203	.7842	.5601
8	1.3717	1.0288	1.2136	1.307	1.2136	.8402	.5601
9	1.2003	1.1145	1.2136		1.2136	.7468	.4668
10	.9431	1.1145	1.1203		.9335	.7468	.3734
11	.3429	.4715	.415		.3734	.3361	.6859
12	.3429	.3961	.3961		.3361	.3361	.823
13	.3429	.3961	.3584		.3361	.2987	.823
14	.3429	.3772	.3584	.5601	.3361	.2987	.7716
15	.3429	.3772	.3584	.3734	.3361		.7716
16	.3429	.3772	.3584		.3734	.3361	.7716
17	.3086	.3961	.3584	.4108	.3734	.3734	.7716
18	.3429	.415	.3584	.4668	.4668	.4108	.7716
19	.5144	.5093	.5658	.5601	.5228	.4668	.5144
20	.5144	.5281	.5281	.5601	.5601	.5601	.5144
21	.5144	.4715	.4904	.5228	.5228	.4668	.4287
22	.4287	.4527	.4715	.5228	.4668	.4108	.3429
23	.3429	.415	.4715	.4668	.3734	.4108	.3429
24	.3429	.3429	.415	.4715	.4108	.3361	.3734
Max	1.3717	1.2003	1.2136	1.307	1.2136	.8402	.823
Min	.3086	.3429	.3584	.3734	.3361	.2987	.3429
Avg	.5880	.5898	.6243	.6270	.5796	.4887	.5534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 202 / 11 KV KOLAMBI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1509	.1509	.1494	.1307	.0187
2	.1372	.1543	.1509	.1509	.1494	.1307	.3734
3	.1372	.1543	.1509	.1509	.1494	.1494	.4668
4	.1372	.1543	.1509	.1509	.1509		.6535
5	.1543	.1543	.1509	.1509	.168	.1494	.7468
6	.1715	.1543	.1698	.1698	.168	.1494	.8402
7	.1715	.1715	.1698	.1698	.1867	.168	1.1203
8	.1372	.1543	.1509	.1698	.1867	.168	1.2136
9	.12	.1543	.1509		.168	.1494	1.2136
10	.1372	.12	.132		.1307	.1494	1.1576
11	1.0288	1.1203	1.0269		1.0269	.8402	.1543
12	1.0288	1.251	1.1203		1.1203	.8402	
13	1.0288	1.251	1.1203		1.1203	.7842	
14	1.0288	1.251	1.1317	.9335	1.2136	.7468	
15	1.0288	1.251	1.1203	1.0269	1.2136	.7468	
16	1.0288	1.251	1.1317	1.0269	1.1203	.1494	
17	1.2003	1.251	1.1203	1.2136	1.1203	.1494	.1372
18	1.0288	1.1203	1.1203	1.2136	1.2136	.7842	.1372
19	.1715	.2075	.1886	.2241	.1867	.2241	.1715
20	.1715	.2263	.2075	.2241	.2241	.2241	.2058
21	.1715	.2075	.1886	.1867	.1698	.1867	.1715
22	.1715	.1886	.1698	.168	.168	.168	.1715
23	.1715	.1698	.1698	.168	.1494	.168	.1543
24	.1372	.1543	.1698	.1509	.1494	.1307	.1494
Max	1.2003	1.251	1.1317	1.2136	1.2136	.8402	1.2136
Min	.12	.12	.132	.1509	.1307	.1307	.0187
Avg	.4515	.5178	.4797	.4105	.4918	.3255	.4872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 203 / 11 KV MANJRAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.6602	.6602	.4668	.4668	.4668
2	.5144	.5144	.6602	.7545	.4668	.4668	.4668
3	.8573	.6859	.8488	.8402	.5601	.5601	.5228
4	.8573	.8573	1.0269	.9431	.7468	.6535	.5601
5	1.2003	1.3717	1.307	1.307	1.0269	.8402	.5601
6	1.7147	1.7147	1.8671	1.6804	1.307	1.0269	.6535
7	2.0576	2.0576	2.2405	1.8671	1.4937	1.2136	.5975
8	2.0576	2.1434	2.2405	1.8861	1.587	1.307	.5601
9	2.0576	2.0576	1.8861		1.4937	1.2136	.5601
10	1.8861	1.9719			1.1203	1.1203	.4668
11		.415	.5093		.5601	.3734	.8573
12	.5144	.3961	.4715		.5228	.4668	1.2003
13	.4287	.3961	.4715		.4668	.4668	1.2003
14	.4287	.3961	.4715	.6535	.4668	.4668	.8573
15	.4287	.3961	.4715	.5601	.4668	.4668	.8573
16	.4287	.3961	.4715	.4108	.4668	.4668	.9431
17	.4287	.4715	.4715	.4668	.5228	.5601	.9431
18	.5144	.5658	.5093	.5601	.5601	.5601	.9431
19	.6001	.7167	.7167	.6535	.6535	.6535	.6001
20	.6001	.7545	.7545	.5601	.6535	.7468	.6001
21	.5144	.6602	.6602	.5601	.5601	.6535	.5144
22	.5144	.5658	.5658	.5228	.4668	.5601	.5144
23	.4287	.5281	.5281	.5228	.415	.4668	.5144
24	.4287	.4287	.5281	.5281	.4668	.3734	.4668
Max	2.0576	2.1434	2.2405	1.8861	1.587	1.307	1.2003
Min	.4287	.3961	.4715	.4108	.415	.3734	.4668
Avg	.8685	.8740	.8843	.8388	.7299	.6729	.6844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 201 / 11 KV KUNTOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	.8131	.8131	.7392	.7947	.8131	.8215
2	.8316	.8131	.8131	.7207	.8316	.7947	.8402
3	.8589	.8501	.7947	.7023	.8316	.8316	.8402
4	.8589	.8686	.8131	.7023	.8686	.8686	
5	.8871	.9055	.8501	.7207	.9425	.9795	
6	1.1088	1.1458	1.0164	1.0164	1.0719	1.2012	1.1949
7		.9425	.8501	.8686	1.0164		1.0642
8	.9055	.9795	.8316	.7762	.8686	1.0164	
9	.8316		.7762	.5729	.6468	.7095	
10	.8131	.7392	.8501	.7207	.8131	.7655	.5914
11	.7392	.7207	.7023	.7207	.8131	.6348	.924
12	.7577	.7023	.7392	.7207	.7947	.6535	.8686
13	.6838	.7577	.7392	.7023	.7577	.5975	.8131
14	.7207	.7207	.7207	.7023	.8316	.5601	.7947
15	.7023	.7023	.7207	.6838	.7577	.6161	.7762
17	.8686		.7207		.6468	.8215	
18	.9795	.7207	.7392	.8131	.8501	.8775	1.0164
19	1.0903	1.1088	1.0164	.8871	.9979	1.0456	1.1458
20	.9795	1.1273	1.1088	.8871	1.0534	1.1576	1.0903
21	.9425	1.0903	.9979	.8501	.9979	1.1203	1.0719
22	.8871	1.0164	.9425	.8316	.961	.9149	1.0164
23		.8131	.8501	.8131	.8501	.8962	
24	.8501	.8316	.7947	.7762	.7947	.8316	.8402
Max	1.1088	1.1458	1.1088	1.0164	1.0719	1.2012	1.1949
Min	.6838	.7023	.7023	.5729	.6468	.5601	.5914
Avg	.8641	.8747	.8348	.7695	.8605	.8503	.9241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 202 / 11 KV KUNTUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6535					
2	.7577	.7762					
3	.8131	.8131					
4	.8501	.8316					
5	.8686	.8871					
6	1.1088	1.1088					
7		1.0534					
8	1.1088	1.0719					
9	1.3121	.7577					
10	1.3491						.4481
11			1.0903	1.3306	1.0719	.9335	1.3121
12			1.3306	1.4784	1.0719	1.1016	1.4045
13			1.1088	1.423	.9425	1.0269	1.4045
14			1.1088	1.4045	.924	1.0269	1.3676
15			1.1088	1.386	.8501	1.0829	1.2936
16			1.2752	1.4415			1.2197
17			1.3491	1.4784	1.0164		1.3676
18			1.2567	1.4784	1.1458	1.0829	
19						.9149	
Max	1.3491	1.1088	1.3491	1.4784	1.1458	1.1016	1.4045
Min	.6722	.6535	1.0903	1.3306	.8501	.9149	.4481
Avg	.9823	.8837	1.2035	1.4276	1.0032	1.0242	1.2272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 203 / Koklegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7023	.3734	.2241		.3174
2			.7762	.4481	.2772		.3547
3			.7762	.4668	.2772	.4481	.3734
4			.7947	.5228	.2957	.5601	.4108
5			.8871	.4481	.3511	.6283	.4294
6			.8871	.8501	.7762	.8501	.7095
7			.8686	1.1827	1.2012	.9425	
8			.8501	1.1827	1.2197	.7762	
9			.8871	1.0719	.8686		1.0349
10			1.0349	.9979	1.0903	.7842	
11	1.3121						
12	1.4045						
13		1.0534					
14		1.1827					
15	1.2936	1.2197					
16	1.2567	1.2382					
17	1.4415	1.2936					
18	1.46	1.3203					
19	1.2197	1.3121					
Max	1.46	1.3203	1.0349	1.1827	1.2197	.9425	1.0349
Min	1.2197	1.0534	.7023	.3734	.2241	.4481	.3174
Avg	1.3412	1.2314	.8464	.7545	.6581	.7128	.5186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 204 / 11 kv New Ambika EX
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.1494	.0189	.1494	.1478	.0189	.0187
2	.0189	.1494	.0189	.1494	.1478	.0189	.0187
3	.0189	.1494	.0754	.1494	.1478	.1494	.0187
4	.0189	.168	.0189	.168	.1478	.1494	.0187
5	.0189	.168	.0189	.168	.1478	.168	.0187
6	.0189	.168	.0189	.1494	.1848	.1494	.0187
7	.0189	.1494	.0189	.1867	.1478	.168	.0187
8	.0189	.1494	.0189	.056	.1478	.0189	.0187
9	.0189	.0189	.0189	.0189	.0189	.0187	.0189
10	.0189	.0189	.0189	.0189	.0189		.0189
11	.0189	.0189	.0189	.0189	.0189	.0187	.0189
12	.0189	.0189	.0189	.0189	.0189	.0187	.0189
13	.0189	.0189	.0189	.0189	.0189	.0187	.0189
14	.0189	.0189	.0189	.0189	.0189	.0187	.0189
15	.0189	.0189	.0189	.0189	.0189	.0187	.0189
16	.0189	.0189	.0189	.0189	.0189	.0187	.0189
17	.0189	.0189	.0189	.0189	.0189	.0187	.0189
18	.0189	.0189	.0189	.0189	.0189	.0187	.0189
19	.0189	.0189	.0189	.0189	.0189	.0187	.0189
20	.0189	.0189	.0189	.0554	.0189	.0187	.0189
21	.168	.0189	.0189	.1109	.168	.0187	.168
22	.168	.0189	.168	.0554	.168	.0187	.168
23		.0189	.168	.1478	.168	.0187	
24	.0189	.1494	.0189	.1494	.1478	.1494	.0187
Max	.168	.168	.168	.1867	.1848	.168	.168
Min	.0189	.0189	.0189	.0189	.0189	.0187	.0187
Avg	.0319	.0702	.0337	.0793	.0874	.0544	.0318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 205 / 11 KV KOKLEGAON GAOUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2772	.3881	.2427	.3326	.2427	.3292
2	.2614	.2587	.3696	.2241	.3142	.2427	.3361
3	.2614	.2587	.3696	.2241	.2957	.2614	.3292
4	.2772	.2772	.3511	.2427	.3142	.2614	.3292
5	.2957	.3142	.3696	.2772	.3142	.2957	.3475
6	.4066	.3326	.3696	.3326	.3696	.3326	.3841
7		.2772	.2033	.3142	.3142		.3292
8	.2402	.2241	.2033	.3142	.2772	.2772	.3658
9	.168		.2241	.2402	.2427	.2012	.3326
10	.1494		.2427	.2402	.2241	.1829	.2957
11	.1867		.2614	.168	.2427	.1646	.2772
12	.168		.2427	.168	.2241		.2587
13	.1867	.2218	.1494	.2427	.2241		.2402
14	.1867	.2218	.2054	.2241	.2241	.1307	.2587
15	.1867	.2402	.1867	.2241	.2241	.1646	.2772
16		.2772					
17	.1867	.2957	.1867		.2054	.1646	
18	.2054	.3326	.2241	.3142	.2957	.2012	.2427
19	.2801	.3881	.2957	.3696	.3511	.2561	.3696
20	.2957	.4066	.3326	.3881	.3881		.4066
21	.3326	.4066	.3511	.3511	.3326	.2926	.3696
22	.3142	.4066	.3511	.3326	.3326	.2195	.3511
23		.415	.3326	.3326	.2218	.2743	
24	.2427	.2957	.3881		.3142	.2427	.2926
Max	.4066	.415	.3881	.3881	.3881	.3326	.4066
Min	.1494	.2218	.1494	.168	.2054	.1307	.2402
Avg	.2425	.3064	.2869	.2746	.2861	.2320	.3201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 201 / 11 KV VAZIRGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6013	.4024	1.6727	.6096	1.4022	1.2231	1.3317
2	.6013	.4024	1.9738	1.7719	1.7471	1.6995	1.5928
3	.6295	.3658	2.1834	2.0672	1.8405	1.871	1.7757
4	.6386	.3734	2.2558	2.1529	1.9719	1.871	1.8024
5	.7133	.439	2.2939	2.2767	2.01	1.9433	1.9052
6	.8261	.5487	2.4463	2.4387	2.2177	2.0195	2.0729
7	.9023	.5975	2.553	2.4844	2.3872	2.0576	2.0957
8	.7895	.5487	2.4882	2.5434	2.5568	2.0272	2.1872
9	.7057	.4481	2.1948	2.5815	2.5568	1.9891	2.1125
10	.714	.439	2.21	2.4196	2.6688	1.9243	1.0041
11	1.909	1.3169	1.3051	1.1336	1.1751	.8574	.1524
12	2.4977	1.4937	.4953	.4096	.1524	.2858	.0762
13	2.4844	1.6095	.5258	.4096		.2858	
14	2.612	1.6827	.4915	.3715		.2858	
15	2.7435	1.8671	.4953	.3715	.2622	.2858	
16	2.7816	1.829	.5334	.4096	.41	.3201	
17	2.7435	1.9044	.5334	.5334	.5197	.3544	
18	2.7263	1.7558	.5334	.5334	.5929	.3582	
19	1.3999	.5601	.5715	.6192	.6295	.602	.6363
20	.7521	.5228	.6782	.7335	.6767	.6439	.8649
21	.7148	.4854	.6058	.6096	.631	.6096	.8649
22	.7148	.439	.6439	.5715	.6394	.6096	.8649
23	.6394	.4481	.6096	.5715	.631	.5372	.6954
24	.6394	.4024	.5677	.5334	.5639	.6058	.5029
Max	2.7816	1.9044	2.553	2.5815	2.6688	2.0576	2.1872
Min	.6013	.3658	.4915	.3715	.1524	.2858	.0762
Avg	1.3533	.8701	1.2859	1.2149	1.2838	1.0528	1.2521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 202 / 11 KV ANTERGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.6804	2.0614	1.8671	2.2405	2.2062	1.1431
2	1.7528	1.829	1.9852	1.8576	2.0938	1.0669	1.0669
3	1.7528	1.9204	2.0195	1.9338	2.0938	2.1643	1.0669
4	1.829	2.0119	2.0881	2.0195	2.2557	2.1643	1.0669
5	4.1084	2.1948	2.1643	2.0957	2.5148	2.3853	1.1431
6	4.5267	2.4272	2.5377	2.41	2.3986	2.6063	1.448
7	4.7767	2.5606	2.1567	1.2003	2.1643	2.5301	.1524
8	4.1884	2.6139	2.1986	2.572	2.0176	1.4289	.6859
9	5.4321	2.4691	1.9433	1.5051	1.829	2.1986	1.3717
10	4.8659	2.4874	1.8862	2.0957	2.114	2.0195	1.448
11	3.3551	.7316	1.6004	3.8104	2.6475	2.7434	1.9814
12	1.6613	.7682	3.7341	4.6583	4.0055	3.7818	2.2862
13	1.6023	.8413	3.2103	4.744	4.1114	3.9437	2.4387
14	1.6023	.8413	1.2003	4.9059	4.3758	3.8675	2.3624
15	1.8625	.8962	1.286	4.7535	4.4048	3.7818	2.2862
16	1.6956	.8962	1.3717	4.6772	4.5206	4.0199	2.2862
17	1.9204	.9335	1.4575	4.7535	4.7097	3.8675	2.5149
18	2.1643	1.0608	1.4575	4.8964	4.6776	4.3248	2.5911
19	2.5392	1.2696	1.3717	3.7914	3.6793	3.6047	1.2955
20	2.4843		1.2003	2.7434	2.652	2.4862	1.2955
21	2.1643	1.1203	1.0288	2.7434	2.5026	2.0195	1.7528
22	2.3929	1.1203	1.0288	2.4958	2.3533	2.3148	1.2193
23	2.3243	1.0829	1.0288	2.3243	2.3769	2.1624	1.2193
24	1.2193	1.0974	.9945	2.0862	2.2634	2.2062	1.1431
Max	5.4321	2.6139	3.7341	4.9059	4.7097	4.3248	2.5911
Min	1.2193	.7316	.9945	1.2003	1.829	1.0669	.1524
Avg	2.6529	1.5154	1.7922	3.0392	2.9584	2.7456	1.5527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 203 / 11 KV BARBADA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.5144	.6859	.6535	.6516
2	.9145	.6516	.6001	.7468	.6516
3	.9335	.6516	.6001	.7468	.6516
4	.8402	.6516	.6859	.7468	.6859
5	.9145	.6859	.6859	.7468	.6859
6	1.0974	.6859	.7716	.8402	.6859
7	1.2803	.6859	.6859	.9335	.6859
8	1.1706	.7202	.6859	.8402	.7202
9	1.1888	.7202	.6859	.9335	.7202
10	.9877	.6859	.6001	.7842	.6859
11	.7468	.8573	.8573	.7842	.6859
12	.7316	1.0288	.7716	.7468	.6173
13	.695	1.0288	.7716	.6722	.6001
14	.7316	.9431	.7716	.6722	.6859
15	.7682	.8573	.8573	.7316	.7716
16	.7682	.7716	.8573	.7468	.8573
17	.8215	1.0288	1.0288	1.0608	.9945
18	.7842	1.3717	1.2003	1.307	.9431
19	1.5684	1.3717	1.286	1.4266	1.2346
20	1.4937	1.2003	1.3717	1.531	1.3032
21	1.2437	1.2003	1.1145	1.2803	1.2003
22	1.0829	1.1145	1.0288	1.0242	1.0288
23	1.0456	1.0288	.9431	.9877	.9431
24	.9896	.8916	.9431	1.0269	.9259
Max	1.5684	1.3717	1.3717	1.531	1.3032
Min	.695	.5144	.6001	.6535	.6001
Avg	.9880	.8895	.8538	.9154	.8173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 201 / 11 kv kirti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4842	1.6651	2.0005	1.7013	1.1431	1.9052	2.2314
2	1.4632	1.5927	2.0005	1.7013	1.1431	2.0957	2.1948
3	1.5565	1.8099	1.9814	1.6832	1.1431	2.0957	2.1948
4	1.6651	1.9547	1.9814	1.6832	1.1431	2.191	2.1216
5	1.7737	1.9004	1.9814	1.6832	1.1431	2.191	2.1216
6	1.8461	1.8823	1.9433	1.8823	1.0479	2.2481	2.0668
7	1.7737	1.828	1.6766	1.647	.9907	1.8099	2.1033
8	1.7556	1.4266	1.8671	1.6108	.9907	1.5242	1.5729
9	1.6651	1.4449	1.9814	1.6289	.6478	1.7718	1.5912
10	1.5746	1.5242	1.9185	1.7147	1.1812	1.701	1.6289
11	1.6289	1.5242	1.7737	1.7337	1.1431	1.9753	1.8099
12	1.9366	1.6766	1.7556	1.9433	1.1241	1.4998	1.9366
13	1.8461	1.6004	1.8099	1.6766	1.086	2.0485	1.9547
14	1.7375	2.0386	1.7737	1.7147	1.0669	2.0851	1.9909
15	1.7737	2.0005	1.4118	1.7147	1.1431	2.0485	1.8823
16	1.828	2.0005	1.5384	1.7718	1.3336	1.7193	1.7556
17	1.9366	2.0005	1.9185	1.9243	1.3908	1.9753	1.9004
18	2.0452	1.9814	1.7193	1.9052	1.3336	1.9185	2.009
19	1.9185	1.9052	1.7375	1.848	1.2384	2.0302	1.8099
20	1.7918	1.829	1.7375	1.9433	1.2384	1.9387	1.5729
21	1.828	1.7147	1.7558	1.7147	1.2193	2.2862	1.5023
22	1.8099	1.6194	1.7375	1.5623	1.2193	2.3228	1.448
23	1.7556	1.9433	1.7375	1.5432	1.2955	2.3777	1.4266
24	1.5384	1.7194	2.0195	1.7013	1.5242	1.3336	2.3777
Max	2.0452	2.0386	2.0195	1.9433	1.5242	2.3777	2.3777
Min	1.4632	1.4266	1.4118	1.5432	.6478	1.3336	1.4266
Avg	1.7472	1.7743	1.8233	1.7347	1.1638	1.9622	1.8835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 202 / 11 kv flemingo
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1905	.2172	.2858	.1905	.0914
2	.2241	.2054	.1905	.2172	.2858	.1905	.0914
3	.2614	.2614	.1905	.2172	.2858	.1905	.0732
4	.2801	.2801	.1905	.2172	.2858	.1905	.0732
5	.2614	.2427	.0953	.2172	.2858	.1905	.0732
6	.2427	.2241	.0953	.1991	.2096	.0762	.0732
7	.1867	.0934	.0762	.1448	.1143	.0572	.0549
8	.1307	.0762	.0953	.0724	.4191	.0572	.0732
9	.2054	.2427	.2096	.1448	.6668	.0572	.0914
10	.2801	.1905	.5068	.1715	.6859	.0549	.1494
11	.2987	.1905	.4344	.2667	.5716	.0549	.1867
12	.3174	.2286	.4344	.6859	.4382	.0549	.2427
13	.2987	.1905	.4344	.5525	.1524		.2614
14	.2801	.1524	.362	.381	.1524		.2241
15	.2614	.1524	.181	.381	.2858	.0914	.2427
16	.2801	.1524	.1991	.381	.2858	.0549	.2614
17	.3174	.1905	.2353	.381	.3429	.0549	.2614
18	.3547	.2667	.3109	.381	.1905	.0549	.2427
19	.3696	.1905	.2561		.2096	.0732	.2427
20	.3696	.2096	.2195	.2667	.1524	.0914	.2241
21	.3174	.2858	.2195	.1905	.1905	.0914	.2801
22	.2614	.381	.2195	.1905	.1905	.0914	.3361
23	.2427	.2667	.2012	.4763	.2858	.0914	.3696
24	.1867	.2241	.2858	.2172	.381	.2858	.0914
Max	.3696	.381	.5068	.6859	.6859	.2858	.3696
Min	.1307	.0762	.0762	.0724	.1143	.0549	.0549
Avg	.2673	.2119	.2431	.2856	.3064	.1066	.1797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 203 / 11 kv advance steel
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0762	.1143	.1086	.0762	.0953	.0914
2	.112	.0762	.1143	.1086	.0762	.0953	.0914
3	.0934	.0762	.1143	.1086	.0762	.0953	.0914
4	.0934	.0934	.1143	.1086	.0762	.0953	.0914
5	.0934	.0934	.1143	.1267	.0762	.0953	.0914
6	.0934	.0934	.1334	.1267	.0762	.0953	.0914
7	.0934	.0934	.1143	.1448	.0953	.0953	.1097
8	.0934	.112	.1334	.1448	.1143	.0572	.0914
9	.0762	.1143	.1143	.1448	.1143	.1143	.0732
10	.0762	.1143	.1086	.1334	.0953		.0762
11	.0762	.1143	.1086	.1334	.0953	.0549	.0762
12	.0762	.1143	.1448	.1143	.0953	.0732	.0762
13	.0762	.1143	.1086	.1334	.0953	.0914	.0934
14	.0762	.0953	.1086	.1334	.0572	.0914	.112
15	.0762	.0953	.1086	.1334	.0762	.0732	.112
16	.0762	.0953	.1086	.1334	.0762	.0732	.0762
17	.0934	.0953	.1086	.0762	.0762		.0762
18	.0934	.0953	.1097	.0762	.0762	.0914	.0572
19	.0934	.1143	.1097	.0572	.0762	.0914	.0572
20	.0934	.1143	.1097	.0572	.0762	.0914	.0572
21	.0934	.1143	.1097	.0762	.0762	.0914	.0572
22	.0934	.1143	.1097	.0762	.0762	.0914	.0762
23	.0934	.1143	.1097	.0762	.0953	.0914	.0762
24	.112	.0934	.1143	.1086	.0762	.0953	.0914
Max	.112	.1143	.1448	.1448	.1143	.1143	.112
Min	.0762	.0762	.1086	.0572	.0572	.0549	.0572
Avg	.0900	.1011	.1144	.1100	.0834	.0882	.0831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 205 / 33 KV Venkys Express

Feeder Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6214		3.4294				3.7311
2	3.5665		3.4294				3.9506
3	3.6763		3.4294				3.9506
4	3.786		.2858				4.1152
5	3.8409		2.8578				4.1152
6	3.786		2.1719				4.1701
7	3.7311						3.2922
8	3.5665						
9	3.4019						
10	3.271						2.2177
11	3.2922						3.7311
12	3.4019				1.829		4.4993
13	2.7435				2.0005		4.4445
14	1.7741	2.0576			2.0576		4.3896
15	1.885	2.8578	1.9547		2.0005	2.0851	4.4445
16	1.9959	2.8578		2.2862	2.0005	2.3045	4.4993
17	1.9404	4.0009	2.009	2.1719	2.1148	2.1948	4.3896
18	1.9959	4.401	2.1399	2.1148	2.1148	2.1948	4.2798
19	2.0513	4.0009	2.1948	2.2291	2.1719	2.3045	4.2798
20	2.1068	3.8295	2.1948	2.1719	2.1148	3.1276	4.225
21	1.9404	3.7151	2.1399	2.0005	2.0576	2.1399	4.0055
22	1.8296	3.658	2.1399	2.0005	2.0005	3.0178	3.7311
23	1.7741	3.8866	1.9204	1.829	1.829	2.963	3.5665
24	3.6763	1.6632	3.7723	1.6289	1.829		3.4019
Max	3.8409	4.401	3.7723	2.2862	2.1719	3.1276	4.4993
Min	1.7741	1.6632	.2858	1.6289	1.829	2.0851	2.2177
Avg	2.8606	3.3571	2.4046	2.0481	2.0093	2.4813	3.9741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 206 / 33 KV Citrus Exp Feeder
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-APR-17
HR	Load (MW)
3	.4481
4	.4481
5	.5041
6	.5601
7	.5041
8	.5601
9	.4481
11	.4481
12	.5601
24	.4344
Max	.5601
Min	.4344
Avg	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 201 / 11 KV SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	02-MAY-17
HR	Load (MW)	Load (MW)
11		.6859
23	.6859	
Max	.6859	.6859
Min	.6859	.6859
Avg	.6859	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 202 / 11 KV MUGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-APR-17
HR	Load (MW)
23	1.2174
Max	1.2174
Min	1.2174
Avg	1.2174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 203 / 11 KV JAWAHAR NAVODAY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	30-APR-17
HR	Load (MW)
23	.0381
Max	.0381
Min	.0381
Avg	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 204 / 11 KV SHANKARNAGAR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	30-APR-17
HR	Load (MW)
23	1.3546
Max	1.3546
Min	1.3546
Avg	1.3546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 205 / 11 KV MAFCO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3624	2.364	2.3868	2.3929	2.4127	2.4737
2	2.2283	2.2375	2.2481	2.2954	2.3304	2.3533
3	2.1628	2.1963	2.2024	2.2237	2.2801	2.2847
4	2.1323	2.1582	2.1536	2.1735	2.2375	2.2329
5	2.1049	2.1293	2.1216	2.1689	2.2055	2.207
6	2.1445	2.2923	2.1658	2.2344	2.396	2.2634
7	2.1033	2.2878	2.1064	2.2207	2.3624	2.2359
8	2.1887	2.271	2.175	2.242	.3841	2.3701
9	2.3045	2.3442	2.3518	2.3564	2.6078	2.585
10	2.4432	2.4829	2.4798	2.5286	2.6337	2.6475
11	2.3792	2.4859	2.4783	2.4661	2.5804	2.6414
12	2.2481	2.3868	2.4021	2.428	2.3426	***
13	2.1933	2.3381	2.2954	2.3122	2.3243	***
14	2.175	2.268	2.2314	2.271	2.21	2.4844
15	2.0957	2.1247	2.1506	2.1826	2.1887	***
16	1.9281	2.0683	2.0942	2.1293	2.1125	***
17	2.1033	2.0896	2.0591	2.1171	.9084	
18	2.1293	2.1475	2.1216	2.1125	2.3015	***
19	2.3624	2.4585	2.4615	2.431	2.4615	***
20	2.8578	2.8944	2.8517	2.7389	2.8639	3.0559
21	2.8106	2.8868	2.8258	2.7938	2.9432	***
22	2.4615	2.5819	2.5377	2.5835	2.684	***
23	2.4066	2.4859	2.4935	2.5286	2.5575	2.6383
24	2.3807	2.4813	2.4646	2.5042	2.521	***
Max	2.8578	2.8944	2.8517	2.7938	2.9432	99.8858
Min	1.9281	2.0683	2.0591	2.1125	.3841	2.207
Avg	2.2794	2.3526	2.3275	2.3515	2.2854	40.5846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 201 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5258	.8669	.5601		.543	.1886
2	.1867	.5258	.8669	.5601	.3734	.4477	.1886
3		.5258	.8669	.5601		.4477	.1848
4	.1867	.5258	.8669	.3734	.3734	.4477	
5		.5258	.8669	.3734			
6	.1867	.5373	.8669	.5601	.3734	.543	
7	.3734	.543	.8669	.5601	.3734	.5487	
8	.3734	.5487	.8764	.5601	.3734	.5487	.3772
9	.5201	.5487	.8764	.5601	.1734	.3734	.1829
10	.5201	.5487	.6401	.5544	.1715	.3734	.5601
11	.5258	.5487	.8859	.5487	.3467		.1867
12	.5201	.5487	.8859	.5544	.1715		.1867
13	.5201	.5487	.8859	.5544	.6401	.1867	.1848
14	.5201	.5487	.6401	.5544	.6468	.1867	.1848
15	.5201	.5487	.8859	.5544	.6401	.3734	.2772
16	.5201	.5487	.8859	.5544	.3772	.1867	.2772
17	.5544	.8859	.8859	.3734	.3658	.6468	.1867
18	.5544	.8859	.8859	.3734	.5601	.3772	.1867
19	.5544	.8764	.8764	.3734	.5544	.6468	.1867
20	.7316	.8764	.6401	.7468	.5544	.6468	.5601
21	.543	.8764	.6535	.5601	.5487	.1886	.1867
22	.5373	.8669	.5601	.3734	.543	.1886	.1867
23	.5316	.8669	.5601	.3734	.5373	.1886	.1867
24	.1867	.5258	.8669	.5601	.3734	.5316	.1886
Max	.7316	.8859	.8859	.7468	.6468	.6468	.5601
Min	.1867	.5258	.5601	.3734	.1715	.1867	.1829
Avg	.4603	.6378	.8108	.5115	.4320	.4106	.2424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 202 / 11 KV GURUDWARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8764	1.0974	.9145		1.0387	1.0974
2	.823	.8764	.9955	.823	.823	.985	1.0059
3		.7888	.9145	.823		.8954	
4	.823	.7888	.9145	.7316	.823	.8954	
5		.7888	.9145	.7316			
6	.8402	.7522	.9145	.8048	.823		
7	.7316	.724	.823	.823	.823	1.0974	
8	.9145	.7865	.9145	.823	.823	1.0059	1.1088
9	.823	.7316	.823	.8501	.924	.9145	1.0608
10	.7316	.7316	.823	.8048	.9145	.9145	.9145
11	.823	.7682	.823	.8413	.9145		.9511
12	.823	.7682	.9145	.924	1.0608		.9709
13	.7316	.7316	.823	.9425	.9145	1.0974	1.0164
14	.823	.823	.9145	.9979	1.0974	1.0974	1.0164
15	.823	.823	.924	.9979	1.0974	1.0974	1.0534
16	1.0059	.9145	1.0164	1.0164	1.0974	1.0974	1.0719
17	.9979	.9145	1.0164	1.0974	1.1088	1.1888	.6401
18	.961	.9145	1.0164	1.0059	1.1088	1.0974	1.0059
19	1.1088	1.0974	1.1888	1.0974	1.1088	1.0974	1.0974
20	1.0974	1.086	1.1888	1.1888	1.0974	1.1888	1.1888
21	.9412	.985	1.0974	1.0059	1.0974	1.0974	1.0974
22	.8954	.9955	1.0608	1.0974	1.0029	1.0974	1.0974
23	.9745	1.086	1.0974	1.0974	1.1104	1.1888	1.1888
24	.8402	.9145	1.0974	1.0974	1.0059	1.0985	1.1888
Max	1.1088	1.0974	1.1888	1.1888	1.1104	1.1888	1.1888
Min	.7316	.724	.823	.7316	.823	.8954	.6401
Avg	.8825	.8611	.9714	.9390	.9893	1.0595	1.0406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 203 / 11 KV SOMESH COLONEY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7528	1.7909	1.6118		1.7909	2.0328
2	1.6118	1.6651	1.7909	1.4327	1.6118	1.7909	1.848
3		1.6651	1.7013	1.4327		1.7909	1.7375
4	1.6118	1.5775	1.7013	1.4327	1.6118	1.7909	
5		1.5775	1.8099	1.4327			
6	1.4327	1.6118	1.9004	1.4327	1.4327	2.1719	
7	1.4327	1.4632	1.829	1.4327	1.4937	2.0119	
8	1.6118	1.6461	1.7556	1.4327	1.6118	1.9404	2.3339
9	1.829	1.7375	1.7556	1.829	1.9204	1.8804	2.1948
10	2.0119	1.7375	1.848	2.0328	2.1033		
11	2.1948	1.829	2.1033	2.3777	2.3777		2.7073
12	2.2862	1.9204	2.1948	2.5873	2.5606		2.7721
13	2.3529	1.9204	2.1948	2.4949	2.652	2.5968	2.8006
14	2.4691	1.829	2.1719	2.4949	2.7435	2.5072	2.6244
15	2.2862	2.0119	2.4691	2.5873	2.4691	2.5072	2.7721
16	2.2862	1.9204	2.1033	2.4949	2.3529	2.5072	2.5873
17	2.4025	1.9204	2.2862	2.3282	2.5873	2.6244	2.5072
18	2.2177	1.9204	2.4434	2.5072	2.5873	2.5873	2.5072
19	2.6797	2.1491	2.5339	2.5968	2.809	2.5873	2.6863
20	2.4691	2.0595	2.4691	2.5072	2.6797	2.5606	2.5968
21	2.1719	1.8604	2.2386	2.2386	2.3777	2.3101	2.3282
22	1.97	1.8604	1.97	1.97	1.9909	2.2177	2.1491
23	1.8604	1.8804	1.8804	1.7909	1.97	2.1253	2.0595
24	1.4327	1.9204	1.7909	1.7909	1.7909	1.8604	2.0328
Max	2.6797	2.1491	2.5339	2.5968	2.809	2.6244	2.8006
Min	1.4327	1.4632	1.7013	1.4327	1.4327	1.7909	1.7375
Avg	2.0296	1.8098	2.0305	2.0112	2.1778	2.2080	2.3830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 204 / 11 KV VAZIRABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3146	1.448	1.2803		1.3969	1.5708
2	1.3717	1.3146	1.4632	1.2803	1.2803	1.3432	1.4784
3		1.2269	1.3717	1.0974		1.386	1.3717
4	1.2803	1.2269	1.2803	1.0974	1.2803	1.3432	
5		1.0867	1.2803	1.0974			
6	1.1203	1.0745	1.386	1.1888	1.0974	1.5384	
7	1.0974	1.0974	1.2803	1.134	1.1888	1.5546	
8	1.0974	1.1888	1.2936	1.1888	1.2803	1.386	1.587
9	1.2803	1.2437	1.2803	1.3306	1.3717	1.3717	1.6095
10	1.3717	1.2803	1.386	1.3717	1.4632	1.4632	1.6095
11	1.6632	1.4632	1.6461	1.7375	1.9404		2.1472
12	1.9204	1.4632	1.848	2.0328	2.1253		2.1253
13	2.0119	1.7375	2.0328	2.0328	2.2177	2.3777	2.1807
14	2.2177	1.7375	2.0328	2.0698	2.2177	2.2862	2.2177
15	2.2177	1.829	2.1253	2.2731	2.3101	2.2862	2.3285
16	2.2177	1.829	2.1253	2.2177	2.3101	2.2862	2.2916
17	2.1253	1.848	2.1253	2.2862	2.2177	2.3101	2.1948
18	2.2177	1.829	2.2177	2.0119	2.4025	2.3101	2.1948
19	2.4949	2.0119	2.2862	2.4691	2.6057	2.4949	2.4691
20	2.3777	1.9909	2.2862	2.4691	2.4949	2.3101	2.4691
21	1.9004	1.8099	1.9204	2.2862	2.0485	2.0119	2.1033
22	1.4864	1.5546	1.7193	1.7375	1.7193	1.829	1.7375
23	1.4022	1.448	1.4632	1.5546	1.5223	1.829	1.6461
24	1.4937	1.848	1.4632	1.4632	1.4632	1.4529	1.6632
Max	2.4949	2.0119	2.2862	2.4691	2.6057	2.4949	2.4691
Min	1.0974	1.0745	1.2803	1.0974	1.0974	1.3432	1.3717
Avg	1.7317	1.5189	1.6984	1.6962	1.8361	1.8365	1.9498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 205 / 11 KV Khadakpura

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2269	1.4632	1.2012		1.3432	1.5708
2	1.307	1.2269	1.3717	1.2012	1.307	1.3432	1.4784
3		1.2269	1.3717	1.2012		1.3432	1.4784
4	1.307	1.2269	1.4632	1.2012	1.2136	1.3432	
5		1.3146	1.5546	1.3306			
6	1.4937	1.5223	1.6632	1.5708	1.4937	1.7194	
7		1.6289	1.8671	1.7002	1.7737		
8	2.0538	1.9204	1.9605	1.9774	2.1472	2.1033	2.2405
9	1.9605	1.829	1.8671	1.957	2.0538	1.9605	
10		1.7375	1.6804	1.6095			1.9753
11	1.5708	1.4632	1.5546	1.5524	1.848		1.7924
12	1.4784	1.4632	1.4784	1.386	1.6632		1.6804
13	1.386	1.3717	1.5708	1.386	1.4784	1.7737	1.4937
14	1.2936	1.2803	1.4784	1.3306	1.4784	1.587	1.2936
15	1.2936	1.2803	1.386	1.3306	1.4784	1.4937	1.386
17	1.6632			1.6804	1.5154	1.6632	
18	2.1253	2.1253	2.0328	2.0538	2.1472	1.9404	2.0538
19	2.2177	2.4025	2.2177	2.1472	2.1253	1.9404	2.2405
20	1.7375	2.0328	1.9404	1.9605	1.9404	1.6632	1.8671
21	1.5384	1.5546	1.6804	1.6804	1.4632		1.7737
22	1.4327	1.5546	1.5684	1.587	1.6118		1.6804
23	1.4175	1.4632	1.4815	1.4937	1.5223		1.587
24	1.4003	1.3146	1.4632	1.4045	1.307	1.4175	1.5708
Max	2.2177	2.4025	2.2177	2.1472	2.1472	2.1033	2.2405
Min	1.2936	1.2269	1.3717	1.2012	1.2136	1.3432	1.2936
Avg	1.5932	1.5530	1.6416	1.5628	1.6615	1.6423	1.7155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 201 / 11 KV COLLECTOR OFFICE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINOUS PROCESS)(NO
STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8311	.4024	.8387	.7644	.7666	.4672	.455
2	.7743	.394	.434	.7431	.7575	.4466	.4443
3	.7644	.3658	.4344	.716	.713	.4332	.4249
4	.7945	.3658	.4172	.6973	.6996	.415	.4241
5	.7442	.3582	.4054	.6847	.6828	.4142	.4161
6	.7354	.3224	.3883	.6801	.6756	.4142	.405
7	.7324	.3155	.3628	.6774	.6512	.3978	.3955
8	.727	.3292	.3437	.6634	.65	.3818	.3803
9	.74	.3326	.6344	.6901	.7133	.7339	.3887
10	.8722	.3258	.7064	.3871	.9656	.9686	.4645
11	.5662	3.3133	.8364	1.1652	1.2232	1.2833	1.3771
12	1.3356		.41	.6741	.6695	1.3885	.7152
13	1.3988	.3224	.7533	1.3081	1.3718	1.408	1.4624
14	1.3592	.3601	.7518	.6657	.7179	1.3854	.7217
15	1.3657	.3521	.8135	.6546	.7289	1.3203	.7068
16	1.3679	.3544	.4138	.6508	.7297	1.3028	1.4407
17	1.2632		.4279	.6318	1.2841	1.2143	1.4098
18	1.1286	.3258	.4195	1.161	1.1275	.6318	1.2524
19	.9358	.362	.7518	.578	.9301	.5045	1.0859
20	.8455	.3292	.7194	.7807	.7911	.4157	.9038
21	.7453	.3326	.7423	.4024	.7129	.3909	.8044
22	.7583	.3326	.7808	.3852	.7308	.4096	.8005
23	.8493		.809	.7819	.4279	.4374	.8329
24	.8707	.4024	.8223	.775	.8032	.4576	.5213
Max	1.3988	3.3133	.8387	1.3081	1.3718	1.408	1.4624
Min	.5662	.3155	.3437	.3852	.4279	.3818	.3803
Avg	.9377	.4904	.6007	.7216	.8135	.7343	.7597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 202 / 11 KV CHIKHALWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.476	1.1706	2.8593	2.7915	2.7954	1.467	1.4053
2	2.3594	1.1104	1.4327	2.6642	2.6726	1.3954	1.3717
3	2.2916	1.0608	1.3291	2.5255	2.5964	1.3443	1.3275
4	2.2485	.9465	1.2544	2.3548	2.3884	1.3298	1.2833
5	2.1662	.9313	1.2109	2.2405	2.1727	1.2361	1.2132
6	2.0027	.8954	1.2125	2.0911	2.0705	1.2346	1.1797
7	1.9266	.8413	1.2117	1.9562	1.9091	1.2323	1.1553
8	1.7543	.8048	1.041	1.8236	1.8168	1.166	1.0357
9	1.7513	.8131	1.762	1.8888	1.9338	1.9837	.9823
10	1.893	.905	1.8343	.9396	1.9563	2.0408	1.0319
11	1.1347	1.0277	2.1049	2.2466	2.505	2.3898	2.5583
12	2.5712		.7827	1.3298	2.9131	2.7477	1.4373
13	2.79	1.2178	2.9279	2.9851	3.1237	3.1839	3.3013
14	3.0194	1.2003	3.1909	1.6095	1.685	3.1108	1.7642
15	1.7193	1.3077	3.3295	1.6453	1.7871	3.0582	1.8534
16	3.1839	1.2757	1.7284	1.1073	1.8077	3.7853	3.6336
17	2.9721		1.6682	1.8008	3.4042	1.9265	3.6861
18	2.8449		1.6164	3.2061	3.4221	3.4278	3.4721
19	3.0003	1.4842	3.3097	1.7048	3.6191	1.7673	3.6786
20	3.2266	1.4632	3.5513	3.6854	2.3434	1.8046	3.7449
21	3.1512	1.2936	3.4515	1.8717	2.3007	1.8419	3.6652
22	2.7777		3.0986	1.6865	3.2167	1.6491	3.2587
23	2.5858		2.8783	2.9477	1.4982	1.4952	2.7739
24	2.6079	1.1706	2.8456	2.8799	2.8821	1.4716	1.5455
Max	3.2266	1.4842	3.5513	3.6854	3.6191	3.7853	3.7449
Min	1.1347	.8048	.7827	.9396	1.4982	1.166	.9823
Avg	2.4356	1.1011	2.1513	2.1659	2.4508	2.0037	2.1816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 203 / 11 KV GRANTH BHAVAN

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1286	.0549	.1121	.1134	.1087	.0528	.0596
2	.1178	.0537	.0545	.1105	.1065	.0579	.0568
3	.1141	.0366	.0526	.1147	.1034	.056	.0553
4	.1118	.0351	.0512	.108	.1032	.0549	.0518
5	.1124	.0358	.0627	.0836	.0843	.052	.0528
6	.0909	.0358	.0608	.0835	.0855	.053	.0518
7	.0812	.0351	.048	.0806	.0769	.0495	.0476
8	.0754	.0366	.0381	.0785	.0713	.0408	.0415
9	.0751	.037	.0689	.0621	.0716	.0782	.0436
10	.0633	.0362	.0686	.0312	.0669	.0732	.0392
11	.0351	.0354	.0724	.0461	.0688	.0667	.1676
12	.0731	.0362	.0368	.0265	.0741	.0661	.0413
13	.0739	.0895	.0728	.0587	.0709	.0655	.0549
14	.0731	.0343	.0699	.0314	.0337	.0649	.0406
15	.0852	.0335	.0673	.0351	.0309	.068	.0514
16	.0861	.0354	.0282	.0381	.0354	.0694	.0971
17	.0696		.0389	.0372	.0543	.0446	.1197
18	.0465	.0362	.0385	.0664	.0646	.0808	.0905
19	.0471	.0362	.0629	.0255	.0651	.0341	.1453
20	.077	.0366	.076	.097	.0892	.0512	.1922
21	.1029	.037	.082	.0551	.08	.0476	.1703
22	.1063	.0554	.1063	.0488	.0819	.0585	.1942
23	.1147		.1124	.0875	.048	.0526	.196
24	.1242	.0549	.113	.1092	.1086	.0575	.1231
Max	.1286	.0895	.113	.1147	.1087	.0808	.196
Min	.0351	.0335	.0282	.0255	.0309	.0341	.0392
Avg	.0869	.0417	.0665	.0679	.0743	.0582	.0910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 205 / 11 KV OLD MONDHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2146	1.9387	4.1374	3.5262	4.071	2.3114	2.1559
2	3.9254		2.1262	3.2869	4.0535	2.1895	2.0226
3	3.7616	1.7924	2.0431	3.1915	3.8836	1.9502	1.893
4	3.5501	1.7177	1.9829	2.9644	3.5315	1.8656	1.8419
5	3.2084	1.6476	1.7124	2.9576	3.2975	1.7932	1.8183
6	2.9843	1.4327	1.6469	2.7504	2.9702	1.7193	1.7535
7	2.8034	1.262	1.5752	2.6528	2.7808	1.6987	1.6949
8	2.6337	1.2803	1.499	2.4692	2.5987	1.5585	1.5752
9	2.486	1.2567	2.5256	2.4607	2.6817	2.6703	1.3245
10	2.2298		2.4615	1.2574	2.7077	2.6055	1.4632
11	1.1759	1.2048	2.6067	2.761	2.6368	2.6577	2.8791
12	2.7725	1.2308	1.3938	1.4472	2.9184	2.8281	1.464
13	2.9218	1.1462	2.8555	2.9828	3.0034	3.1383	3.2998
14	3.0197	1.1317	3.0651	1.5874	1.6392	3.1283	1.736
15	3.1969	1.2071	1.704	1.6522	1.7756	3.1665	1.8656
16	3.1939	1.2757	1.7025	1.858	1.8442	3.5658	3.5551
17	3.0864		1.7284	1.7886	3.203	1.8381	3.6008
18	2.9378	1.3756	1.6118	3.0758	3.1059	1.7322	3.2586
19	3.1786	1.6651	3.3577	1.5524	3.3677	1.6514	3.5025
20	3.6694	1.7558	3.6649	3.5924	3.7288	1.906	3.8111
21	3.613	1.7372	3.8317	1.9342	3.7617	2.1399	3.9201
22	3.7556	1.848	3.9773	1.848	3.8843	2.1201	4.0307
23	4.1076		4.3598	4.0116	1.957	2.0492	3.6062
24	4.3492	2.0119	4.2783	3.8577	2.54	2.1407	2.1079
Max	4.3492	2.0119	4.3598	4.0116	4.071	3.5658	4.0307
Min	1.1759	1.1317	1.3938	1.2574	1.6392	1.5585	1.3245
Avg	3.1990	1.4959	2.5770	2.5611	2.9976	2.2677	2.5075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 206 / 11 KV SACHKHAND

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.504	.6219	1.3512	1.6034	.7453	.7583	.8924
2	1.4353		.7526	1.5093	1.331	.7468	.8688
3	1.4102	.5853	.7019	1.4152	1.2502	.6714	.7929
4	1.3127	.5258	.6836	1.1252	1.2117	.6691	.7773
5	1.0951	.4656	.4793	.8794	.892	.4889	.5098
6	.788	.2865	.4428	.8459	.828	.5026	.4393
7	.6615	.2454	.3437	.8344	.7583	.4538	.3368
8	.5868	.2561	.37	.8413	.8174	.5045	.4207
9	.7709	.2957	.6219	.8452	.8105	.8109	.5373
10	.8791		.6104	.4233	.8577	.8451	.4047
11	.5163	.4607	.6748	.8627	.4736	.9698	.8219
12	.4184	.5068	.3833	.4553	.8192	1.1123	.4146
13	.727	.5731	.6542	.852	.8562	1.0638	.7179
14	.7316	.6173	.6684	.4706	.4683	.9225	.37
15	.8597	.6036	.4512	.5098	.5658	.924	.474
16	.9366	.567	.4874	.5415	.5719	.9972	.9496
17	.9339		.4942	.5255	.9004	.5117	.498
18	.9419	.4344	.5064	.913	.892	.4523	.8577
19	.8946	.4706	.8006	.4706	.9511	.3951	.8402
20	.9705	.4755	.8394	.9937	.9637	.4645	.8406
21	.884	.4435	.9107	.5464	.9865	.4325	.9149
22	1.2262	.7392	1.1854	.6664	1.3031	.6904	1.2822
23	1.4346		1.4231	1.3382	.7697	.9092	1.4133
24	1.5337	.6584	1.5288	1.5158	1.499	.7152	.6695
Max	1.5337	.7392	1.5288	1.6034	1.499	1.1123	1.4133
Min	.4184	.2454	.3437	.4233	.4683	.3951	.3368
Avg	.9772	.4916	.7236	.8743	.8968	.7088	.7102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 207 / 11 KV RAILWAY HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	.128	***	***	***	***	***
2	***		***	***	***	***	***
3	***	.128	***	***	***	***	***
4	***	.1402	***	***	***	***	***
5	***	.1433	***	***	***	***	***
6	***	.1433	***	***	***	***	***
7	***	.1402	***	***	***	***	***
8	***	.1463	***	***	***	***	***
9	***	.1109	***	***	***	***	***
10	***	.1086	***	***	***	***	***
11	***	.1063	***	***	***	***	***
12	***	.1086	***	***	***	***	***
13	***	.1075	***	***	***	***	***
14	***	.12	***	***	***	***	***
15	***	.1341	***	***	***	***	***
16	***	.1063	***	***	***	***	***
17	***		***	***	***	***	***
18	***	.1086	***	***	.1372	***	***
19	***	.1086	***	***	.1075	***	***
20	***	.1097	***	***		***	***
21	***	.1294	***	***	.1433	***	***
22	***	.1294	***	***	.1646	***	***
23	***		***	***		***	***
24	***	.128	***	***	.2195	***	
Max	123.0312	.1463	148.8685	135.612	131.4063	118.4409	120.6558
Min	76.1138	.1063	81.3989	80.626	.1075	85.8422	89.2276
Avg	100.4668	.1231	107.6919	101.7250	83.7586	101.6318	104.7189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 201 / 11 KV BILAL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6875	1.4632	2.9203	2.6406	2.6673	2.8868	2.8867
2	2.6311	1.4632	2.8814	2.4942	2.6109	2.8464	2.8471
3	2.6128	1.2803	2.6806	2.4767	2.5957	2.8296	2.8212
4	2.5984	1.3717	2.6669	2.466	2.5995	2.8136	2.8136
5	2.6045	1.4632	2.6775	2.4371	2.604	1.3573	2.8387
6	2.8174	1.4632	2.9195	2.6082	2.7442	.202	2.9264
7	1.3359	1.4784	3.017	2.7324	2.9233	.0274	3.2598
8	1.6972	1.4784	3.0902	1.4998	2.5247	2.8341	3.3314
9	3.104		3.0574	3.0483	2.9315	2.8067	3.078
10	1.4891	1.2803	2.7343	2.8048	1.3321	.6158	2.886
11	1.9585	1.4632	2.8052	2.5914	1.6377	1.7894	2.6932
12	2.8375	1.448	2.8418	2.6874	2.8573	2.8273	3.0049
13	2.8845	1.3575	1.4091	2.6394	2.8245	2.8082	2.8045
14	2.7948		1.3938	2.58	2.8123	2.6807	2.6924
15	1.3435		1.3314	1.2849	1.4015	1.4083	1.3146
16			1.3093				
17	2.348		2.2466	1.1088	1.609	2.0649	
18	3.0407	1.6632	2.8228	3.1104	2.9858	2.9271	2.9764
19	3.4697	1.848	3.0142	3.5291	3.4804	3.3954	3.3203
20	3.5939	1.6632	3.2213	3.4838	3.5399	3.2761	3.4789
21	3.1215	1.6632	2.9949	3.2045	3.3402	3.1314	3.1391
22	2.9866	1.4784	2.979	3.0201	3.0102	3.059	3.0483
23	2.9805	1.4784	2.8776	2.9973	2.9851	2.982	2.9858
24	2.7538	1.4632	2.9584	2.7325	2.7458	2.9355	2.9706
Max	3.5939	1.848	3.2213	3.5291	3.5399	3.3954	3.4789
Min	1.3359	1.2803	1.3093	1.1088	1.3321	.0274	1.3146
Avg	2.5953	1.4878	2.6188	2.6164	2.6419	2.3698	2.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 202 / 11 KV RLY TRACK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1221	1.829	4.3419	4.2776	4.3172	4.4544	4.6061
2	4.0794	1.829	4.1121	4.0329	4.26	4.0931	4.5596
3	3.991	1.829	4.0253	3.9735	4.1549	4.0154	4.2794
4	3.8965	1.829	3.9742	3.9141	4.1267	3.9522	4.2009
5	3.8972	1.829	3.9201	3.8226	4.0268	4.097	4.1902
6	4.1297	1.829	4.111	3.917	3.9544	2.1132	4.2855
7	2.1262	1.848	4.1239	3.8132	3.9331	1.4319	4.319
8	2.2626	1.9404	4.1346	2.0134	3.7025	3.9209	4.4925
9	4.0352		4.13	3.9209	4.3952	4.5824	4.6617
10	2.1056	2.1033	3.9605	4.1011	2.2405	2.3198	4.462
11	2.2177	1.9204	3.8813	3.9178	2.2862	2.1948	4.356
12	4.207	1.9909	3.8378	3.8759	2.4882	4.5694	4.2189
13	3.9742	1.9004	1.9509	3.8713	4.377	4.587	4.2494
14	3.9079	1.9404	1.9547	3.8728	4.1994	4.4509	4.0459
15	2.0546		1.9441	2.0012	2.1529	2.114	2.0523
16	.0693		1.8656				
17	2.6429		2.6756	2.0328	1.9909	2.2637	
18	4.4079	2.4025	4.0657	4.4834	4.4376	4.4643	3.8163
19	4.7051	2.7721	4.3828	4.771	5.045	4.8457	4.7492
20	4.9284	2.5873	4.654	5.0279	5.3818	5.0111	5.1501
21	4.5694	2.4025	4.5572	4.763	5.2058	4.7623	4.8756
22	4.4887	2.2177	4.3987	4.5809	4.9002	4.6213	4.6997
23	4.2844	2.2177	4.3583	4.4963	4.606	4.5801	4.5687
24	4.2619	1.829	4.5245	4.4841	4.4475	4.5885	4.5611
Max	4.9284	2.7721	4.654	5.0279	5.3818	5.0111	5.1501
Min	.0693	1.829	1.8656	2.0012	1.9909	1.4319	2.0523
Avg	3.5569	2.0523	3.7452	3.9115	3.9404	3.8275	4.3364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 203 / 11 KV DEGLOOR NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0314	2.5606	4.2582	4.2097	4.2288	4.3766	4.2825
2	3.962	2.5606	4.1926	3.9636	3.959	4.1899	4.2147
3	3.9056	2.9264	3.9598	3.9217	3.9339	4.1549	3.9712
4	3.866	2.5606	3.9354	3.9064	3.9064	4.1252	3.9568
5	3.8706	2.5606	3.9225	3.892	3.9102	3.9483	4.0162
6	3.9689	2.5606	3.9179	3.9789	3.8897	1.3847	4.2742
7	.7636	2.5873	3.9141	3.94	3.8691		4.2406
8	1.4533	2.7721	3.9522	1.3778	4.2536	4.491	4.462
9	3.9171		3.9461	4.1842	4.2345	4.4445	4.5176
10	.74	2.9264	3.9049	4.0513	.6302	.6859	3.9194
11	3.7411	2.7435	3.9087	4.02	3.9445	4.5237	4.4208
12	4.0139	2.7149	3.6572	3.9339	3.9841	4.1671	4.4551
13	4.2139	2.5339	1.2498	3.5559	4.1141	3.9567	4.5169
14	4.1918		1.2788	3.9194	3.866	3.9125	4.0284
15	1.0067		1.2681	.8711	1.3314	1.3603	.7529
16			.5281				
17	4.4056		3.943	3.253	3.6416	4.2109	.0122
18	4.4826	3.3265	4.1587	4.7581	4.696	4.4864	4.6986
19	4.9878	3.3265	4.7131	5.077	5.0168	4.9734	5.3552
20	4.965	3.3265	4.539	5.122	5.0435	4.9985	5.5289
21	4.5047	3.3265	4.4658	4.5656	4.9078	4.5306	5.0282
22	4.4391	3.1417	4.4856	4.5481	4.7013	4.5329	4.9787
23	4.4353	2.9569	4.4757	4.526	4.5336	4.5291	4.9703
24	4.4162	2.9264	4.4811	4.4574	4.4932	4.5016	4.5839
Max	4.9878	3.3265	4.7131	5.122	5.0435	4.9985	5.5289
Min	.74	2.5339	.5281	.8711	.6302	.6859	.0122
Avg	3.6644	2.8599	3.6274	3.9145	3.9604	3.9311	4.1385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 204 / 11 KV KHUDWAI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.6461	3.4678	3.3409	3.379	3.4217	3.5714
2	1.448	1.6461	3.4244	3.3005	3.331	3.3737	3.5196
3	1.448	1.6461	3.3969	3.2891	3.3005	3.3546	3.2937
4	1.448	1.6461	3.3908	3.2464	3.3127	3.3257	3.3013
5	1.448	1.6461	3.4236	3.2921	3.3607	3.4614	3.4042
6	1.4632	1.6461	3.4983	3.4891	3.5216	1.8404	3.6964
7		1.6632	3.6164	3.5722	3.5714	.1448	4.0336
8		1.7556	3.73	2.0584	3.8894	4.0002	4.2535
9	1.6461		3.6799	3.8744	3.8376	3.8812	4.1939
10		1.7375	3.6572	3.6042	.1547		3.8142
11	1.6632	1.5546	3.3577	3.1237	3.2792	3.6527	3.6039
12	1.448	1.448	3.1024	3.0224	3.4194	3.6633	3.5254
13	1.448	1.448	1.5882	3.0346	3.1238	3.2823	3.4507
14	1.448		1.5364	2.8482	3.0926	3.1833	3.0765
15			1.5097	.7964	.7514	.6729	.6821
16			.4214				
17	1.5546		3.1238	2.7217	3.4876	3.1932	.2705
18	1.829	1.848	3.5566	4.0016	4.1381	3.9712	4.0426
19	2.0119	2.1253	2.2047	4.4021	4.4506	4.1914	4.2113
20	1.829	2.0328	3.9956	4.0847	4.2509	4.1236	4.2212
21	1.6461	2.0328	3.5818	3.6557	3.9354	3.9231	3.7046
22	1.6461	1.848	3.6427	3.6504	3.7463	3.9041	3.8409
23	1.6461	1.848	3.5528	3.6153	3.6435	3.7155	3.8561
24	1.7194	1.6461	3.5219	3.5341	3.5803	3.6321	3.6225
Max	2.0119	2.1253	3.9956	4.4021	4.4506	4.1914	4.2535
Min	1.448	1.448	.4214	.7964	.1547	.1448	.2705
Avg	1.5915	1.7297	3.0825	3.2851	3.3286	3.2687	3.4430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 206 / 11 KV TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	2.2253	2.2405	2.3243	2.3777	2.3624
2	2.1186	2.1567	2.1643	2.2177	2.2939	2.2558
3	2.0729	2.1033	2.0957	2.1491	2.2253	2.1795
4	2.0119	2.05	2.0348	2.1033	2.1643	2.111
5	1.989	2.0348	2.0043	2.0729	2.1262	2.0957
6	1.989	2.0424	1.9966	2.0424	2.0805	2.0881
7	1.9509	1.9509	1.8823	1.9738	1.989	2.0805
8	2.05	2.1033	2.1186	2.1567	2.2558	2.2862
9	2.1567	2.2862	2.2558	2.2481	2.3701	2.3396
10	2.111	2.2481	2.2481	2.3091	2.3548	2.5149
11		2.2558	2.1643	2.3243		2.4615
12		2.3015	2.2024	2.4082		2.271
13		2.2939				
14	2.7054	2.3472	2.5301		2.7435	
15	2.7816	2.3091	2.4615	.0152	2.7587	
16	1.448	2.3396	.282	2.7816	.8078	2.8883
17	2.6292	2.3929	2.5072	2.7359	2.713	2.713
18	2.7435	2.5072	2.6368	2.873	2.6978	2.7054
19	3.0636	2.8654	2.8883	3.1703	2.9569	3.0788
20	3.1626	2.934	2.9874	3.3989	3.155	3.1779
21	2.9645	2.8121	2.7359	3.2388	3.0483	3.1474
22	2.5835	2.6673	2.4996	2.8045	2.8349	2.8502
23	2.3548	2.4463	2.431	2.5301	2.5911	2.6216
24	2.2939	2.3472	2.3853	2.4463	2.4539	2.5606
Max	3.1626	2.934	2.9874	3.3989	3.155	3.1779
Min	1.448	1.9509	.282	.0152	.8078	2.0805
Avg	2.3534	2.3342	2.2501	2.3784	2.4285	2.5138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 201 / 11 KV VISHNUPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1866						
2	1.0326						
3	.9877						
4	.9602	.9877			1.0242		.9412
5	1.0166						
6	1.9829	1.0349	1.1203	.8962	1.0349	1.1458	
7	1.9996			.9335			
8	1.0844	1.0719	1.0349	.9709	1.1088	.9979	1.0349
9	1.9708						
10	1.0166		.905	1.0349			1.0349
11	1.0883		.8688			.9774	.8131
12	2.0397		1.0136	1.1827			.924
13	1.0722						1.0242
14	2.0135			1.086		.9214	1.0136
15	.9968						1.0029
16	2.0378		.9145	.9114		.9568	.9602
17	.9869		1.0974				.9602
18	2.1266			1.1462		1.0498	1.0974
19	2.207						
20	1.2948		1.0974	1.2071		1.0745	1.1946
21	1.2856						
22	1.1225		.9877	1.0974			
23	1.137		.9877				1.1706
24	2.1049	1.086	.8299	.9979	1.0136	.9808	1.1462
Max	2.207	1.086	1.1203	1.2071	1.1088	1.1458	1.1946
Min	.9602	.9877	.8299	.8962	1.0136	.9214	.8131
Avg	1.4480	1.0451	.9870	1.0422	1.0454	1.0131	1.0227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 202 / 11 KV WAJEGAON (OLD
TUPPA) Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1177						
2	.0869						
3	.0812						
4	.1155	.1791			.1848		.1448
5	.1189						
6	.2809	.1848	.2218	.1494	.2218	.1848	
7	.2831			.1494			
8	.1372	.2033	.1478	.1494	.1848	.1848	.1478
9	.2492						
10	.0823		.181	.1478			.1109
11	.1452		.181			.1448	.1109
12	.338		.181	.1294			.1478
13	.1658						.1478
14	.29			.1276		.1417	.1086
15	.1372						.1075
16	.257		.1463	.1402			
17	.1429		.1097				
18	.3254					.1448	.1463
19	.3277						
20	.1658		.1463			.1791	.1463
21	.1566						
22	.1463		.1097	.1646			
23	.144		.1097				.1463
24	.2503	.181	.1509	.1109	.1629	.1509	.1791
Max	.338	.2033	.2218	.1646	.2218	.1848	.1791
Min	.0812	.1791	.1097	.1109	.1629	.1417	.1075
Avg	.1894	.1871	.1532	.1410	.1886	.1616	.1370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 203 / 11 KV BHAGYLAXMI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.0358			.037		.0362
6	.0373	.037	.056	.056	.037	.037	
7	.0373			.0373			
8		.037	.056	.0373	.037	.037	.037
9	.037						
10			.0905	.037			.037
11			.0362			.0362	.0554
12	.037		.0724	.037			.0554
13							.0554
14	.0362			.0543		.0354	.0362
15							.0358
16			.0914	.0526		.0354	.0514
17			.0549				.0343
18	.0358			.0537		.0362	.037
19	.0358						
20			.0549	.0366		.0537	.0549
22			.0549	.0366			
23			.0366				.0549
24	.0549	.0543	.0377	.0554	.0362	.0377	.0358
Max	.0549	.0543	.0914	.056	.037	.0537	.0554
Min	.0358	.0358	.0362	.0366	.0362	.0354	.0343
Avg	.0389	.0410	.0583	.0449	.0368	.0386	.0441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 204 / 11 KV CHOUPHALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4297						
2	1.4083						
3	1.3992						
4	1.419	1.7909			1.848		1.6289
5	1.4876						
6	3.7205	1.9404	1.7924	1.1203	1.9959	1.922	
7	3.9857			1.307			
8	2.0576	1.386	2.0698	1.307	2.0328	1.7741	1.9404
9	3.7974						
10	1.7574		1.5565	1.0164			1.5893
11	1.5653		1.3756			1.448	1.4784
12	2.9748		1.448	1.4784			1.4784
13	1.387						1.4045
14	2.6757			1.448		1.3289	1.267
15	1.3519						1.2894
16			1.39	1.3146			
17			1.4632				
18	3.7437			1.97		1.5384	
19	4.2974						
20	2.3548		1.9753	1.9753		1.6118	2.0119
21	2.0165						
22	1.6964		1.6095	1.829			
23	1.6248		1.4998				1.5729
24	3.0346	1.5384	1.358	1.5524	1.3575	1.358	1.576
Max	4.2974	1.9404	2.0698	1.9753	2.0328	1.922	2.0119
Min	1.3519	1.386	1.358	1.0164	1.3575	1.3289	1.267
Avg	2.3266	1.6639	1.5944	1.4835	1.8086	1.5687	1.5670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 206 / 11 KV SHRINIWASA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5122						
2	.5046						
3	.5034						
4	.4996	.3982			.439		.181
5	.5057						
6	.9555	.4066	.3395	.4481	.462	.4435	
7	.946			.4294			
8	.5014	.4066	.2957	.2987	.462	.4066	.1848
9	.9389						
10	.4917		.3982	.4435			.1478
11	.4865		.4344			.4344	.1478
12	.9382		.0326	.4435			.1478
13	.485						.1478
14	.8744			.4344		.3898	.1267
15	.476						.1254
16	.8278		.4024	.4031		.4252	.1433
17	.4486		.4024				.1372
18	.9059			.4298		.4163	.128
19	.8985						
20	.4698		.4024	.4024		.394	.128
21	.4712						
22	.4445		.4024	.4024			
23	.4375		.4024				.1646
24	.8944	.3801	.4527	.4108	.3982	.4527	.1612
Max	.9555	.4066	.4527	.4481	.462	.4527	.1848
Min	.4375	.3801	.0326	.2987	.3982	.3898	.1254
Avg	.6424	.3979	.3605	.4133	.4403	.4203	.1480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 207 / 11 Kv Water works

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.7522			.8501		.6878
5						.8299	
6	.8215	.8501	.7842	.8215	.8501	.8501	
7	.8215			.8589			
8		.8501	.8686	.7842	.9979	.8131	.7392
9	.7392						
10			1.1222	1.1088			1.1458
11			1.1946			.8326	1.4415
12	1.4045		1.1946	1.7741			1.4415
13							1.4118
14	1.3394			1.7013		.7796	1.3969
15							1.5432
16	1.267		1.3169	1.6126		.7796	1.4403
17			1.2071				1.4403
18	1.4685			1.4327		.724	1.4045
19	1.4685						
20			.8413	.9877		.7164	1.1946
22			.8413	.9145			
23			.8413				.9145
24	.9145	.8145	.8299	.8501	.8688	.8299	.6447
Max	1.4685	.8501	1.3169	1.7741	.9979	.8501	1.5432
Min	.7392	.7522	.7842	.7842	.8501	.7164	.6447
Avg	1.1383	.8167	1.0038	1.1679	.8917	.7950	1.2033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 201 / 11 KV NANAKSAR GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1799			.2241	.1875
2	.1867				.2241	.1819
3	.2241	.1819				.2577
4	.2614	.2282				.2978
5	.2987	.2545			.3734	.3275
6	.2332	.3241				.3275
7	.3361	.3765				.3275
8	.2987	.3326		.3639	.3361	.335
9			.2872			
10						.2241
14			.1819			
15			.275			.2614
19						.3361
20						.2987
22	.2126					
23	.2273	.2218				
24	.303		.1663	.1821		.1839
Max	.3361	.3765	.2872	.3639	.3734	.3361
Min	.1867	.1799	.1663	.1821	.2241	.1819
Avg	.2517	.2624	.2276	.273	.2894	.2728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 202 / 11 KV VIDYAPEETH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.3241			.4481	.4124
2	.5228	.2881			.4481	.4045
3	.5228	.2547				.3765
4	.5228	.3313				.4049
5	.5228	.3172			.4668	.4045
6	.5228	.3749				.3999
7	.4481	.3601				.4141
8	.4481	.4124		.4367		.4003
9			.3677			
10						.6722
14			.4399			
15			.4828			.8962
19						.5601
20						.5601
22	.4257					
23	.4499	.4481				
24	.4499	.3601	.3921	.4412	.362	.4563
Max	.5228	.4481	.4828	.4412	.4668	.8962
Min	.4257	.2547	.3677	.4367	.362	.3765
Avg	.4871	.3471	.4206	.4390	.4313	.4894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 203 / 11 KV GANGABET

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.3723			.5601	.3723
2	.3109	.3237			.5601	.3639
3	.3734	.3275				.4412
4	.5975	.3605				.4503
5	.6348	.3999			.5601	.4849
6	.6722	.3961				.4858
7	.7095	.4141				.478
8	.5601	.5046		.6375	.5228	.4785
9			.5453			
10						.5041
14			.4412			
15			.5516			.4108
19						.5975
20						.5228
22	.3544					
23	.4299	.3547				
24	.5441	.4281	.2957	.3681		.3589
Max	.7095	.5046	.5516	.6375	.5601	.5975
Min	.3109	.3237	.2957	.3681	.5228	.3589
Avg	.5123	.3882	.4585	.5028	.5508	.4576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 204 / 11 KV PIMPALGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0082	
2			1.1203	
3				.6927
4				.7697
5				.9064
6				1.0018
7				1.093
8		1.195	.3734	1.3365
9	.9659			
Max	.9659	1.195	1.1203	1.3365
Min	.9659	1.195	.3734	.6927
Avg	.9659	1.195	.8340	.9667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 205 / 11 KV KALESHWAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2587	
2				.3142	
3					.2307
4					.2299
5				.3361	.2707
6					.2963
7					.3449
8	.017		.3527	.4481	.3461
9		.0805			
Max	.017	.0805	.3527	.4481	.3461
Min	.017	.0805	.3527	.2587	.2299
Avg	.017	.0805	.3527	.3393	.2864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 206 / 11 KV PANGRA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-APR-17	30-APR-17	01-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.4618	
2		.5864	
4		.5104	
5		.6516	
6		.824	
7		.4116	
8		.8342	
9	.8899		
14			.8663
15			.9946
24			.1372
Max	.8899	.8342	.9946
Min	.8899	.4116	.1372
Avg	.8899	.6114	.6660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 208 / 11 KV GODAWARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4805	
2			.4805	
3				.2846
4				.317
5			.4805	.3461
6				.3626
8		.445	.4805	
9	.4458			
24				.3193
Max	.4458	.445	.4805	.3626
Min	.4458	.445	.4805	.2846
Avg	.4458	.445	.4805	.3259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 209 / 11 KV VISHNUPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	.6914			.6722	.7124
2	***	.6543			.6722	.6329
3	***	.6193				.6756
4	***	.6557				.7153
5	***	.7153			.7468	.7285
6	***	.7499				.7818
7	***	.7499				.7706
8	***	.7202		.74	.7468	.7354
9	***		.6481			
10	***					.7282
11	***					
12	***					
13	***					
14	***		.5883			
15	***		.6374			.6348
16	***					
17	***					
18	***					
19	***					.7468
20	***					
21	***					.8215
22	***					
23	***	.7468				
24	***	.7225	.8962	.6557		.7202
Max	97.1652	.7499	.8962	.74	.7468	.8215
Min	62.7954	.6193	.5883	.6557	.6722	.6329
Avg	79.2450	.7025	.6925	.6979	.7095	.7234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 201 / 11 kV NAGAPUR G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6722	.708	.6653		.6348
2			.6653	.7453	.6283		.7095
3			.6653	.7453	.6283		.7858
4			.6653	.8215	.8589		.898
5			.8215	.8962	.8962		.9709
6			1.0829	1.0456			1.0851
7			1.0829	.9709	.9431		.8419
8	.8519	.9355		.9335	.9431	.8527	.8589
9		.9431	.9335	.8962			
10		.7545	.8962	.7545	.5908		.6244
11		.6036	.898	.7545	.6199		.5889
12			.7468		.6495		
13			.6722		.4651		
14			.5975		.5014		
15			.5975	.7545	.6584		.7301
16		.5658	.6722	.7545	.7308		.7362
17		.8676	.7468	.8676	.8475	.7506	.9183
18		.8676	.7842	.9431	.9231	.7882	.8752
19		.8676	.7882	.9431	.8413	.8632	.8466
20		.8676	.9729		.7331	.8632	.844
21		.924	.9383	.8589	.7754	.7506	.7362
22		.9145	.7842		.7331	.6722	.6626
23		.5487	.7453	.6653	.655	.5975	
24	.5164	.5975	.5487	.6708	.6653		.5975
Max	.8519	.9431	1.0829	1.0456	.9431	.8632	1.0851
Min	.5164	.5487	.5487	.6653	.4651	.5975	.5889
Avg	.6842	.7890	.7816	.8279	.7251	.7673	.7866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 202 / 11 kV PUNEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4124	1.6194		1.8929
2		1.3603	1.5766	1.6518		1.9064
3		1.5546	1.6868	1.8138		1.9943
4		1.7814	2.0175			2.0693
5		1.8785	2.193			2.1829
6		1.9662	2.198			2.3179
7		2.2939	2.2594	2.2939		2.3392
8			2.3419	2.6825		2.3591
9	2.5484	1.8394	2.3807			
10	2.3472	2.4963	2.2131	2.3419		2.2211
19					2.5948	
20					2.4834	
21					2.4588	
22					2.2594	
23				1.7654	2.135	
24	1.4781					2.1387
Max	2.5484	2.4963	2.3807	2.6825	2.5948	2.3591
Min	1.4781	1.3603	1.4124	1.6194	2.135	1.8929
Avg	2.1246	1.8963	2.0279	2.0241	2.3863	2.1422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 203 / 11 kV TUPPA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.6465						
11			1.9631	2.5232	2.6142		2.356
12			2.5997	2.7831	2.6173		2.6626
13		1.9227	2.0046	2.7161	2.4851		2.6142
14		2.6155	2.6187	2.9172	2.5497		
15			2.5606	2.4006	2.5174		2.5174
16		2.7435	2.5667	2.4006	2.4528		2.0333
17			2.5988	2.6825	2.5497	2.4763	
18			2.5988	2.8837	2.4206	2.447	2.3883
19		2.572	2.571				
20		2.3472	2.0508				
21		2.2939					
22		2.2939	1.9631				
24	1.7105						
Max	2.6465	2.7435	2.6187	2.9172	2.6173	2.4763	2.6626
Min	1.7105	1.9227	1.9631	2.4006	2.4206	2.447	2.0333
Avg	2.1785	2.3984	2.3724	2.6634	2.5259	2.4617	2.4286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 204 / 11 kv New Wajegaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8215	.9335	.7545		.9335
2			.8299	.9335	.7545		.9335
3			.8676	1.0477	.8676		.9729
4			.9431	1.126	.9054		1.0477
5			1.0562	1.1647	1.1317		1.16
6			1.1317	1.1635	1.2449		1.1974
7			1.4335	1.2761	1.3203		1.2761
8	1.2398	1.2696		1.3553	1.2826	1.3525	1.307
9		1.2826	1.1576	1.358		1.2047	
10		1.2449	1.1576	1.0185		1.126	1.315
11		1.1694	1.1203	.9808	1.315	1.0851	1.2398
12		1.1694	1.0829	.9808	1.052	1.0884	
13		.9808	.9335	.9431	1.052	1.1225	
14		.9431	.7842	.9808	.9768	1.1225	
15			.8589	.9808	.9778	1.1635	1.1271
16		.9054	.8962		1.052	1.2323	1.0144
17		.9431	.9335	1.2449	1.1659	1.2761	1.2787
18		1.1317	1.0082	1.2826	1.3525	1.2722	
19		1.2449	1.2696	1.5089	1.5043	1.3096	1.4291
20		1.2826	1.1576		1.315	1.2761	1.3525
21		1.0456	1.1225	1.1317	1.0895	1.1576	1.0895
22		1.0456	.9709		1.052	1.1225	1.1283
23		.9335	.9335	.9709	.9778	1.0477	
24	.9393		.9335	.9335	.9709	.9393	.9709
Max	1.2398	1.2826	1.4335	1.5089	1.5043	1.3525	1.4291
Min	.9393	.9054	.7842	.9335	.7545	.9393	.9335
Avg	1.0896	1.1061	1.0176	1.1103	1.0961	1.1705	1.1541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 205 / 11 kv Injegaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8861	1.6838	1.5089		1.689
2		1.4937	1.689	1.5089		1.689
3		1.6804	1.9142	1.5466		1.7265
4		1.6975	1.9142			1.8016
5		1.6221	1.9161			1.8016
6		1.5466	1.92			1.8016
7			2.0329	1.8107		1.8016
8	1.8671		2.0706	2.1502		1.841
9	1.8861	1.6464	2.0748			
10	1.9993	1.9161	2.0748	2.0517		1.8671
11			2.0748			
19					1.8709	
20					1.9142	
21					1.8709	
22					1.8391	
23				1.4922	1.689	
24	1.5059					1.6804
Max	1.9993	1.9161	2.0748	2.1502	1.9142	1.8671
Min	1.5059	1.4937	1.6838	1.4922	1.689	1.6804
Avg	1.8146	1.6861	1.9423	1.7242	1.8368	1.7699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 206 / 11Kv MARATHWADA EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1158	.1377	.1738		.1395
2			.1448	.1387	.1738		.1395
3				.1387	.1448		.1391
4			.1448	.1387	.1448		.1387
5			.1448	.1395	.1738		.1397
6			.1448	.11	.176		.111
7			.208	.1097	.176		.1376
8	.1856	.1376		.11	.208	.1553	.1669
9		.1505	.1926	.1189		.1926	
10		.2107	.1926	.2408	.2484	.1926	.2487
11		.2134	.1934	.2709	.3105	.2219	.2795
12		.2134	.2201	.3048	.3105	.2219	.342
13		.2134	.2476	.3772	.3105	.2497	.3265
14		.2134	.2763	.3353	.2791	.2497	
15			.2486	.2743	.2791	.2497	.3109
16		.1806	.2497	.2743	.3105	.2751	.2795
17		.1806	.2476	.2439	.3105	.2497	.3109
18		.1806	.2497	.2439	.3416	.2789	.3261
19		.1783	.2789	.2408	.2481	.251	.2795
20		.1486	.2476		.2166	.251	.2487
21		.1448	.1664	.1738	.1861	.2225	.2179
22		.1372	.1376		.1547	.1942	.1863
23		.1372	.1387	.1692	.1553	.1658	
24	.1547	.11	.1448	.1387	.1738	.1553	.1381
Max	.1856	.2134	.2789	.3772	.3416	.2789	.342
Min	.1547	.11	.1158	.1097	.1448	.1553	.111
Avg	.1702	.1719	.1971	.2014	.2264	.2222	.2194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 201 / 11 KV R.T.O.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5335	.6859	.7049	.8299	.8002	.5335
2	.6036	.5144	.6859	.6859	.8299	.7621	.5335
3	.679	.5144	.6859	.6859	.8299	.7049	.5335
4	.5281	.4954	.6859	.6859	.7167	.7049	.5335
5	.5281	.5144	.6859	.7049	.6413	.7049	.5335
6	.5281	.4954	.7621	.724	.6036	.7621	.5906
7	.5281	.4763	.7621	.724	.6036	.5525	.5525
8	.5281	.4954	.7049	.724	.6036	.5906	.5525
9	.7811	.8764	.9335	1.0479	.9526	.5335	.8764
10	1.1431	1.2449	1.5089	1.2765	1.3957	.5335	1.4003
11	1.3146	1.4901	1.8861	1.3336	1.5466	.5335	1.5844
12	1.3146	1.4523	1.9239	1.2384	1.4146	.4572	1.643
13	1.086	1.2384	1.3717	1.1812	1.2574	.5335	1.8861
14	1.6956	1.4861	1.1812	1.1431	1.4098	.4572	1.2574
15	1.7337	1.7924	1.4098	1.1812	1.6409	.4572	1.3957
16	1.3527	1.8839	1.6409	1.2955	1.7164	.4572	1.7924
17	1.358	1.7528	1.5844	1.2826	1.7353		1.6598
18	1.2826	1.6956	1.6221	1.4335	1.5655	.5144	1.4335
19	1.1506	1.5432	1.3769	1.358	1.5089	.5144	1.2826
20	.8192	1.3146	1.086	1.1317	1.1622	.5144	.9431
21	.4763	.8954	.9526	.9808	.8764	.5335	.679
22	.4382	.8002	.9145	.9054	.8383	.5335	.679
23	.5335	.8002	.8383	.9054	.8764	.5335	.7545
24	.679	.5335		.7049	.8299	.8383	.5335
Max	1.7337	1.8839	1.9239	1.4335	1.7353	.8383	1.8861
Min	.4382	.4763	.6859	.6859	.6036	.4572	.5335
Avg	.9036	1.0350	1.1256	1.0016	1.0994	.5881	1.0068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 202 / 11 KV NANDED FLOOR MILL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4191	.362	.3429	.381	.6287	.2858
2	.3772	.4191	.362	.3429	.381	.6287	.2858
3	.3772	.4191	.381	.3429	.381	.6287	.2858
4	.3772	.4191	.381	.362	.381	.6097	.2858
5	.3772	.4191	.381	.4191	.381	.6097	.2858
6	.679	.4954	.6287	.5716	.381	.6097	.4191
7	.7545	.6668	.6287	.6668	.6036	.8192	.4954
8	.6036	.6668	.6287	.6668	.6036	.724	.5144
9	.724	.8764	.724	.6668	.7621	.7545	.8192
10	1.1431	1.2765	.9145	.8764	1.1431	.679	1.1694
11	1.2193	1.2955	1.0374	1.0098	1.3203	.7545	1.2449
12	1.2765	1.2765	.6287	.9907	1.3336	.9808	1.2449
13	.8002	1.2955	.6668	.8954	1.1812	.9808	1.2071
14	.7621	1.2384	.6097	.8764	1.1431	.8299	1.1883
15	.7621	1.1431	.6668	.9526	.9907	.2263	1.2449
16	.8002	1.0479	.6097	.8764	.8383	.2263	.6668
17	.7621	.8002	.4191	.679	.8002	.2858	.6036
18	.4763	.4001	.381	.5975	.6668	.2858	.4527
19	.4763	.4191	.4191	.3772	.6287	.2858	.3772
20	.4572	.4001	.3429	.3772	.5906	.2858	.3772
21	.4191	.4001	.362	.3772	.5906	.2667	.3772
22	.4382	.381	.362	.3772	.5716	.2667	.3772
23	.4191	.362	.3429	.3772	.6097	.2667	.3018
24	.3772	.4191	.362	.3429	.3772	.6097	.2667
Max	1.2765	1.2955	1.0374	1.0098	1.3336	.9808	1.2449
Min	.3772	.362	.3429	.3429	.3772	.2263	.2667
Avg	.6348	.7065	.5251	.5985	.7100	.5518	.6157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 203 / 11 KV GODAWARI DRUG

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1042	.7842	.6859	.4557	.6097	.679	.724
2	1.1652	.7842	.6859	.4557	.6097	.6036	.724
3	1.0448	.7842	.6668	.4458	.6097	.5658	.724
4	1.1362	.8029	.6668	.4359	.6097	.5601	.724
5	1.1972	.7922	.6097	.4424	.6097	.5601	.724
6	1.2277	.7167	.5335	.4481	.6097	.4024	.724
7	1.3191	.679	.4191	.4481	.679	.2865	.743
8	1.4716	.6413	.4572	.4801	.679	.6036	.7049
9	1.547	.6979	.4706	.5716	.6859	.6036	.679
10	1.7071	.6668	.4805	.6097	.7922	.679	.679
11	1.8137	.6224	.4525	.6097	.6859	.679	.7167
12	1.9433	.7167	.4656	.6859	.7049	.3772	.7922
13	2.1033	.7922	.4344	.724	.724	.679	.8002
14	1.9966	.7356	.4477	.7049	.679	.6036	.7545
15	1.8175	.7356	.4252	.6097	.6224	.679	.6979
16	1.7452	.7922	.443	.6859	.6979	.679	.7356
17	1.8358	.7621	.5847	.679	.7049	.724	.7621
18	1.8412	.724	.6767	.679	.7167	.7621	.679
19	1.7527	.6478	.7023	.679	.679	.724	.6036
20	1.608	.7049	.4527	.6859	.6722	.724	.6036
21	1.6495	.743	.5441	.6859	.6668	.724	.6036
22	.8535	.724	.4428	.6413	.6602	.724	.6036
23	1.5748	.6859	.4481	.6036	.6979	.724	.6036
24	1.7139	.7468		.4458	.6036	.6979	.724
Max	2.1033	.8029	.7023	.724	.7922	.7621	.8002
Min	.8535	.6224	.4191	.4359	.6036	.2865	.6036
Avg	1.5487	.7284	.5303	.5797	.6671	.6269	.7013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 201 / 11 kv ASARJAN GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058				.3109	
2	.2035				.3109	
3					.3109	
4	.2543				.3077	
5	.2743	.2926		.2957	.3045	
6					.3403	.3052
7					.3403	.3222
8				.333	.3189	.3429
9		.2561		.2374	.3012	.2774
10		.2481		.2374	.2835	.3109
11		.2012			.2686	.2804
13	.2374	.2561				
14		.2601			.2835	
15		.2481				
16		.2561		.2915		
17	.2454	.2713			.2915	
18	.2926	.1029			.2883	
19					.3561	
20					.3561	
21					.3222	
23			.3142			
24	.2543	.2926		.3142	.3292	
Max	.2926	.2926	.3142	.333	.3561	.3429
Min	.2035	.1029	.3142	.2374	.2686	.2774
Avg	.2460	.2441	.3142	.2849	.3125	.3065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 202 / 11 KV KOUTH GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003				1.5364	
2	1.2346				1.4632	
3					1.4632	
4	1.1191				1.3756	
5	1.0288			1.2803	1.2894	
6					1.4327	1.2209
7					1.3466	1.2548
8				1.3756	1.2757	1.2971
9		1.1706		1.2209	1.2269	1.3112
10		1.0608		1.0974	1.2048	1.3466
11		1.0974				1.3112
12				1.0852		1.3535
13	1.0174	1.134			1.2403	
14		1.1694			1.3112	
15		1.2071				
16		1.1706		1.3717		
17	1.0242	1.1191			1.0174	
18	1.134	1.0974			1.2696	
19					1.4582	
20					1.5261	
21					1.4582	
23			1.5364			
24	1.2003	1.3535		1.4937	1.6095	
Max	1.2346	1.3535	1.5364	1.4937	1.6095	1.3535
Min	1.0174	1.0608	1.5364	1.0852	1.0174	1.2209
Avg	1.1198	1.1580	1.5364	1.2750	1.3614	1.2993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 203 / 11 KV AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0339				.128	
2	.0339				.1463	
3	.0339				.1463	
4	.0509				.181	
5				.2218	.197	
6					.2328	.2374
7					.3012	.2035
8				.4161	.3366	.2543
9		.3841		.4578	.3544	.3814
10		.2926		.4409	.3721	
13	.4578					
17	.4334	.0339			.0747	
18	.4938	.1029			.0678	
19					.0848	
20					.0848	
21					.0848	
22					.0678	
23			.0914			
24	.0509	.0532		.0914	.0914	
Max	.4938	.3841	.0914	.4578	.3721	.3814
Min	.0339	.0339	.0914	.0914	.0678	.2035
Avg	.1986	.1733	.0914	.3256	.1736	.2692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 202 / 11 KV HUDCO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632					
2	1.387					
3	1.387					
4	1.4022					
5	1.4632					
6	1.6156					
7	1.6537					
8	1.6537					
9	1.5318					
10	1.2879					
11	1.2193					
12	1.1279					
13	1.3032					
14	1.2498					
15	1.3565					
16	1.3946					
17	1.3641					
18	1.4022					
19	1.8366					
20	1.8747					
21	1.6842					
22	1.4861					
23	1.4708					
24	1.4327	1.1218	1.3321	1.3321	1.262	1.4022
Max	1.8747	1.1218	1.3321	1.3321	1.262	1.4022
Min	1.1279	1.1218	1.3321	1.3321	1.262	1.4022
Avg	1.4603	1.1218	1.3321	1.3321	1.262	1.4022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 204 / 11 KV OSMANNAGAR(Kiwala)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1848	.1848	.1848	.1848	.1848
Max	.1848	.1848	.1848	.1848	.1848
Min	.1848	.1848	.1848	.1848	.1848
Avg	.1848	.1848	.1848	.1848	.1848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 205 / 11 KV KOHINOOR Exp
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582					
2	.3353					
3	.3582					
4	.3658					
5	.3734					
6	.3734					
7	.3582					
8	.3658					
9	.381					
10	.3734					
11	.3658					
12	.381					
13	.2439					
14	.3506					
15	.3506					
16	.381					
17	.3734					
18	.381					
19	.3734					
20	.3658					
21	.3277					
22	.3582					
23	.3429					
24	.3506	.0438	.0457	.0152	.0191	.0171
Max	.381	.0438	.0457	.0152	.0191	.0171
Min	.2439	.0438	.0457	.0152	.0191	.0171
Avg	.3579	.0438	.0457	.0152	.0191	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 207 / 11 KV GOPALCHAWDI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5121	.6584	.6584	.7316	.7316
Max	.5121	.6584	.6584	.7316	.7316
Min	.5121	.6584	.6584	.7316	.7316
Avg	.5121	.6584	.6584	.7316	.7316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 208 / 11 KV SHIVA PARVATI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.7718	1.5604	1.7718	1.643	1.4575
Max	1.7718	1.5604	1.7718	1.643	1.4575
Min	1.7718	1.5604	1.7718	1.643	1.4575
Avg	1.7718	1.5604	1.7718	1.643	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 209 / 11 KV CIDCO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957					
2	1.989					
3	1.9509					
4	1.9052					
5	1.9052					
6	1.9052					
7	1.9204					
8	1.8595					
9	1.768					
10	1.7604					
11	1.768					
12	1.6994					
13	1.7071					
14	1.7604					
15	1.7985					
16	1.8366					
17	1.8061					
18	1.7833					
19	2.1414					
20	2.3472					
21	2.2862					
22	2.2253					
23	2.2786					
24	2.2481	1.949	1.949	2.0376	2.1262	2.0376
Max	2.3472	1.949	1.949	2.0376	2.1262	2.0376
Min	1.6994	1.949	1.949	2.0376	2.1262	2.0376
Avg	1.9477	1.949	1.949	2.0376	2.1262	2.0376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 403 / 33 KV MIDC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	5.9877	6.154	6.3758	6.394	5.9877
Max	5.9877	6.154	6.3758	6.394	5.9877
Min	5.9877	6.154	6.3758	6.394	5.9877
Avg	5.9877	6.154	6.3758	6.394	5.9877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 404 / 33 KV COMET SIPTA
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0772	.0714	.1029	.1086	.1772
Max	.0772	.0714	.1029	.1086	.1772
Min	.0772	.0714	.1029	.1086	.1772
Avg	.0772	.0714	.1029	.1086	.1772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 406 / 33 KV RTO FEEDER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.8292	2.8578	2.8578	2.8578	2.8578
Max	2.8292	2.8578	2.8578	2.8578	2.8578
Min	2.8292	2.8578	2.8578	2.8578	2.8578
Avg	2.8292	2.8578	2.8578	2.8578	2.8578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 702 / 132KV VISHNUPURI 2 FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 132 / OUTGOING (NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)
24	.0037	.0037
Max	.0037	.0037
Min	.0037	.0037
Avg	.0037	.0037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 201 / 11 KV REST HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0538	2.2177	2.0538	2.1253	2.1472	2.3339	2.1472
2	2.0538	1.848	2.0538	2.0328	1.9605	2.1472	2.0538
3	1.9605	1.848	1.9605	2.0328	1.8671	2.1472	1.9805
4	1.7737	1.848	1.8671	1.848	1.8671	2.0538	1.8671
5	1.6804	1.7556	1.7737	1.7556	1.7737	2.1472	1.7737
6	1.6804	1.6632	1.7556	1.7556	1.7737	1.9605	1.6804
7	1.6804	1.5708	1.7737	1.7556	1.7737	1.6804	
8	1.587	1.5708	1.7737	1.6632	1.6804	1.6804	
9	1.587	1.6632	1.6804	1.6632	1.7737	1.6804	
10	1.7758	1.6632	1.6632	1.6632	1.8606	1.8652	2.6261
11	1.997	1.848	1.5708	1.7556	2.0366	1.9997	2.6547
12	2.1107	1.9404	1.6804		2.2569	1.8735	2.638
13	2.2207	1.848	2.122		2.375	1.8842	3.1489
14	2.2757	1.848	2.3118	2.2177	2.3464	1.3817	3.581
15	3.1096	1.848	2.4051	2.2177	2.5537	1.5093	3.2792
16	3.2666	1.848	2.3734	2.1472	2.3613	.9175	2.6635
17	3.2338	1.8671	2.2138	2.0538	2.3713	3.2065	2.3433
18	3.2338	1.6632	2.2146	2.0538	2.3998	2.3286	2.2917
19	2.8531	1.848	2.3811	2.1472	2.4947	2.5107	2.4829
20	2.4919	2.0748	2.5705	2.2405	2.2531	2.4234	2.3777
21	2.3986	2.0538	2.4089	2.3101	2.2405	2.2405	2.3101
22	2.2177	2.2405	2.3339	2.4272	2.4272	2.3339	2.5873
23	2.2177	2.3339	2.3101	2.3339	2.6139	2.4272	2.5873
24	2.1472	2.2177	2.2634	2.2177	2.2405	2.4272	2.3339
Max	3.2666	2.3339	2.5705	2.4272	2.6139	3.2065	3.581
Min	1.587	1.5708	1.5708	1.6632	1.6804	.9175	1.6804
Avg	2.2336	1.8803	2.0631	2.0190	2.1437	2.0483	2.4480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 202 / 11 KV STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2136	1.1088	1.2136	1.1088	1.1317	1.307	1.2136
2	1.2136	1.0164	1.2136	1.1088	1.1203	1.2136	1.2136
3	1.1203	1.0164	1.1203	.924	1.1203	1.2136	1.1203
4	1.0164	1.0164	1.0269	.924	1.1203	1.1203	1.1203
5	1.1203	.924	.9335	.8316	1.0269	1.1203	1.0269
6	1.1203	.924	1.0269	.8316	.9335	1.2136	.9335
7	1.0269	.924	1.0269	.924	.9335	1.0269	
8	1.2136	.8316	1.0269	1.1088	.9335	1.0269	
9	1.2136	.924	1.1088	1.2012	.9335	1.0269	1.307
10	1.1088	1.0164	1.1088	1.1088	1.1203	1.0269	
11	1.0164	1.1088	1.0269	1.1088	1.1203	1.1203	1.307
12	.985	1.1088	1.0269	1.1088	1.2136	1.1203	1.307
13		1.1088	1.1203	1.1088	1.2136	1.0269	1.307
14		1.1088	1.2136		1.307	1.1203	1.2936
15		1.1088	1.2012	1.2936	1.307		1.307
16	1.386	1.1088	1.2012	1.307	1.307	.9335	1.2936
17	1.386	1.1203	1.2012		1.307	1.2136	1.386
18	1.4784	1.2136	1.2936	1.4003	1.386	1.307	1.386
19	1.4784	1.4003	1.4003	1.4003	1.587	1.4003	1.4784
20	1.4327	1.4003	1.4784	1.307	1.587	1.4937	1.4632
21	1.4784	1.307	1.4937	1.307	1.4937	1.4003	1.386
22	1.2012	1.4003	1.4937	1.307	1.4937	1.307	1.386
23	1.1088	1.4003	1.2012	1.307	1.4937	1.307	1.2936
24	1.307	1.1088	1.307	1.2012	1.2136	1.307	1.307
Max	1.4784	1.4003	1.4937	1.4003	1.587	1.4937	1.4784
Min	.985	.8316	.9335	.8316	.9335	.9335	.9335
Avg	1.2203	1.1127	1.1861	1.1467	1.2252	1.1893	1.2779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 203 / 11 KV NAGARJUNA HOTEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5587	1.5708	3.5785	1.4784	3.4541	3.5353	3.597
2	3.4221	1.4784	3.5493	1.4784	3.3908	3.5094	3.5406
3	3.3581	1.4784	3.4294	1.4784	3.3672	3.3962	3.3901
4	3.2849	1.4784	3.4065	1.4784	3.3428	3.4736	3.3588
5	3.3634	1.4784	3.5143	1.4784	3.4439	3.5463	3.403
6	3.5213	1.5708	3.6778	1.5708	3.5025	3.6915	3.5429
7	2.0915	1.4784	3.592	1.5708	3.517		1.9166
8	3.5155	1.4784	3.4157	1.4784	3.4919	3.6595	1.5394
9	3.4149		3.1001	1.4784	3.2864	3.5673	
10	1.2879	1.848	2.8848	1.4784	1.0555	.4138	
11	2.5781	1.4784	2.5874	1.386	3.2895	3.1066	2.8536
12	2.6469	1.2012	2.7168	1.1088	3.0102	2.9519	3.3779
13	2.5072	1.2012	2.7069	1.1088	2.9546	2.8246	3.293
14	2.5148	1.2012	2.8071	1.1088	2.9439	2.5545	3.1797
15	2.6941	1.2012	2.9417	1.2012	2.8582	2.6288	3.1254
16	1.4601		1.4319	1.307	1.4716	1.2269	1.6019
17	3.0755			1.4003	2.7603	2.7778	
18	3.7463	1.6804	3.1287	1.7737	3.2933	3.1988	3.7164
19	4.3206	2.0538	1.848	1.7556	3.8378	3.6606	4.3046
20	4.3678	2.0538	1.9605	1.7737	3.9773	3.8146	4.3972
21	4.0066	2.0538	2.0538	1.8671	3.9461	3.8283	4.0687
22	3.347	2.0748	2.0538	1.8671	3.927	3.8351	3.5505
23	3.5301	1.9605	1.7556	1.8671	3.8008	3.7993	3.605
24	3.7997	1.5708	1.8671	1.5708	3.7322	3.6603	3.517
Max	4.3678	2.0748	3.6778	1.8671	3.9773	3.8351	4.3972
Min	1.2879	1.2012	1.4319	1.1088	1.0555	.4138	1.5394
Avg	3.1422	1.5996	2.7829	1.5027	3.2356	3.1592	3.2800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 204 / 11 KV DATTA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7349	2.8645	2.7349	2.5873	2.7349	2.894	2.894
2	2.6139	2.6797	2.6406	2.5873	2.6406	2.7073	2.6139
3	2.5206	2.4949	2.452	2.4949	2.6139	2.5206	1.587
4	2.4272	2.4949	2.3577	2.4025	2.6139	2.6139	2.5206
5	2.4272	2.3101	2.3899	2.4025	2.5206		2.3339
6	2.5463	2.3101	2.3339	2.4025	2.4272	2.894	2.0538
7	2.3577	2.2177	2.1472	2.3101	2.2405	2.4272	
8	2.3577	2.1253	2.0538	2.2177	2.1472	2.3339	
9	2.3339	2.0328	2.0538	2.2177	2.2634	2.2405	
10	2.2177	1.9404	2.0538	2.3101	2.3339	2.3339	
11	2.3101	2.0328	1.9605	2.3101	2.4272	2.4272	2.894
12	2.3101	2.2177	2.0538	2.3101	2.5206	2.4272	2.8006
13	2.4949	2.2177	2.1472	2.3101	2.6139	2.4272	2.7073
14	2.5873	2.2177	2.2405	2.4025	2.6139	2.6139	2.6406
15	2.5873	2.3101	2.3339	2.5873	2.7073	2.8006	2.5206
16	2.5873	2.2177	2.3339	2.6139	2.7073	2.8006	2.1472
17	2.4949	2.0748	2.4272	2.6139	2.6139	2.5206	2.1253
18	2.7721	2.2405	2.3339	2.6139	2.5206	2.5206	2.1253
19	3.1417	2.6406	2.7073	2.7073	2.8006	2.9874	2.4691
20	2.9569	2.8006	2.8006	2.8006	2.894	2.894	3.0178
21	2.7721	2.8006	2.894	2.894	3.0807	2.9874	3.1417
22	2.9569	2.9235	2.894	3.0807	3.1741	3.1741	3.4751
23	2.8645	2.9235	2.9569	2.9874	3.1741	3.1741	3.4751
24	2.9235	2.8645	2.8292	2.7721	2.9235	3.0807	2.9874
Max	3.1417	2.9235	2.9569	3.0807	3.1741	3.1741	3.4751
Min	2.2177	1.9404	1.9605	2.2177	2.1472	2.2405	1.587
Avg	2.5957	2.4147	2.4221	2.5390	2.6378	2.6870	2.6265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 201 / 11 KV RLY DIVISION

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	.1509	.1097	.112	.1698	.1509
2	.1097	.1509	.1509	.0914	.0934	.1698	.1509
3	.1097	.132	.1509	.0914	.0934	.1509	.1509
4	.1097	.1132	.132	.0914	.0934	.132	.1509
5	.1097	.1132	.1132	.0914	.0934	.132	
6	.1097	.0943	.1132	.0934	.0934	.1132	.132
7	.112	.0943	.1132	.1132	.0934	.132	.132
8	.1097	.0943	.1132	.132	.1097	.132	
9	.1097	.1132	.132	.1509	.1097	.1509	
10	.1132	.1132	.1698	.1698	.1829	.1463	
11	.132	.1132	.1886	.1886	.1829	.1463	.2263
12	.132	.1132	.1886	.2263	.1829	.1463	.2263
13	.132	.1132	.2263	.2263	.1829	.1829	.2263
14	.1509	.1509	.2263	.2452	.1829	.1829	.2263
15	.1509	.1509	.2829	.2263	.1829	.1829	.2452
16	.1698	.1509	.2829	.2263	.1829	.1829	.2452
17	.1509	.1509	.2743	.2263	.2075	.2263	.2378
18	.1509	.132	.1829	.1886	.2075	.2075	.1829
19	.1509	.1132	.1829	.1698	.1886	.1886	.1463
20	.1509	.1509	.1829	.1698	.1886	.1886	.1463
21	.1509	.1509	.1829	.1886	.1698	.1886	.1494
22	.1509	.132	.1829	.1509	.1698	.1886	.1494
23	.1509	.132	.1463	.1463	.1698	.1509	.1463
24	.1494	.1509	.1509	.1463	.1494	.1698	.1509
Max	.1698	.1509	.2829	.2452	.2075	.2263	.2452
Min	.1097	.0943	.1132	.0914	.0934	.1132	.132
Avg	.1340	.1281	.1759	.1608	.1510	.1651	.1786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 202 / 11 KV CHAITNYA NAGAR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	2.1052	***	***	6.6759	6.8202	5.535
2	4.8933	1.9433	6.0398	6.1614	6.4465	6.48	5.3037
3	***	1.7814	***	***	6.1249	6.0612	5.0831
4	***	1.7004	***	***	5.5293	5.8151	2.5598
5	4.1404	1.7004	5.4542	5.2941	5.4287	3.0963	4.7832
6	***	1.6842	***	***	5.3555	2.2729	4.6053
7	***	1.7166	***	***	5.4641	5.2256	4.5283
8	4.2729	1.7166	4.7569	4.8308	5.4923	5.4184	4.7687
9	***	1.9433	***	***	5.5175	5.2298	
10	***	1.6518	***	***	5.0694	5.3521	
11	3.5437	1.749	4.5134	4.5394	5.016	4.4208	2.6882
12	***	1.6194	***	***	4.891	3.6534	5.1631
13	***	1.6194	***	***	5.2218	4.0733	4.7992
14	3.7673	1.7814	4.8122	4.7478	5.455	4.1503	4.3949
15	***	1.7814	***	***	5.4466	4.244	4.3751
16	***	1.8461	***	5.0313	5.551	4.4788	4.233
17	3.9243	1.8004	5.362	4.9955	2.806	4.1243	4.5184
18	***	2.4006	***	4.9978	3.9034	4.087	4.5458
19	***	2.7778	***	5.8973	5.37	4.2211	4.875
20	4.8491	2.8292	6.1401	6.1683	6.2597	4.8015	5.17
21	***	2.8292	***	6.3885	6.5886	5.1566	5.8734
22	***	2.8807	***	6.4723	6.5653	5.3422	5.9085
23	5.0937	2.915	7.0226	6.7673	3.642	5.5441	6.1028
24	***	2.3482	***	6.7581	6.4785	6.1275	5.6973
Max	52.6502	2.915	53.418	53.2103	6.6759	6.8202	6.1028
Min	3.5437	1.6194	4.5134	4.5394	2.806	2.2729	2.5598
Avg	36.0986	2.0467	36.8618	25.1042	5.4291	4.8415	4.7960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 203 / 11 KV MAHALAJ - SANGVI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2276	1.0608	2.1193	1.0974	1.1203	1.134	1.0608
2	2.1925	1.0242	2.1041	1.0974	1.1203	1.0974	1.0242
3	2.175	1.0242	2.0987	1.0974	1.1203	.9877	1.0059
4	2.1689	1.0242	2.1369	1.0974	1.1203	.9877	1.0059
5	2.2017	1.0608	2.4402	1.0974	1.1203	1.134	1.0608
6	2.6893	1.134	2.4531	1.2803	1.4003	1.3717	1.0974
7	2.8936	1.2437	2.7343	1.2803	1.4003		1.2437
8	2.8379	1.2437	2.6292	1.2803	1.3717		
9	2.6315	1.1706	2.4447	1.2437	1.3717		
10	2.3838	1.1706	2.1841	1.1888	1.2803	1.3717	
11	2.0683	1.134	1.8686	1.0974	1.0059	1.1888	1.3535
12	2.1665	1.0974	1.9113	1.0242	1.0059	1.0059	1.2631
13	2.2603	1.0608	1.9677	.9877			
14	2.0088	1.0608	1.8587	.9145		1.4632	
15	2.1208	.9877	1.8801	1.0059			
16	2.1346	.9877	1.8884	1.0608	1.3717	1.3432	1.4266
17	2.178	1.0974	2.1437	1.1706	1.2803	1.2803	1.4632
18	2.3671	1.134	2.3845	1.2437	1.3169	1.2071	1.4632
19	2.7786	1.2437	1.3717	1.2803	1.4632	1.3717	1.5546
20	3.0117	1.3717	1.3717	1.3717	1.6095	1.4266	1.5546
21	2.7656	1.2437	1.3717	1.3169	1.5729	1.4998	1.5546
22	2.6071	1.0974	1.1888	1.2071	1.3169	1.2071	1.2803
23	2.2596	1.0974	1.1888	1.2071	1.2071	1.134	1.2803
24	2.2962	1.0608	1.0974	1.0974	1.1203	1.134	1.0608
Max	3.0117	1.3717	2.7343	1.3717	1.6095	1.4998	1.5546
Min	2.0088	.9877	1.0974	.9145	1.0059	.9877	1.0059
Avg	2.3927	1.1180	1.9516	1.1561	1.2713	1.2287	1.2641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 205 / 11 KV AIRPORT

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0141	.0514	.0095	.0141	.0211	.0514	.0107
2	.0141	.0514		.0141	.0211	.0514	.0107
3	.0141	.0514	.0095	.0141	.0211	.0514	.0107
4	.0141	.0514	.0095	.0141	.0211	.0514	.0107
5	.0141	.0514	.0095	.0141	.0211	.0514	.0107
6	.0141	.0514	.0095	.0141	.0211	.0514	.0107
7	.0141	.0514	.0095	.0107	.0211	.0514	.0107
8	.0141	.0514	.0095	.0095	.0141	.0514	
9	.0141	.0514	.0171	.0107	.0141	.0514	
10	.016	.0514	.0514	.0107	.0211	.0211	
11	.016	.0514	.0514	.016	.0211	.0211	.0514
12	.0286	.0514	.0514	.016	.0211	.0211	.0686
13	.0286	.0514	.0514	.016	.0211	.0417	.0514
14	.0171	.0514	.0514	.016	.0211	.0417	.0514
15	.0107	.0514	.0514	.016	.0211	.0417	.0514
16	.016	.0514	.0514	.0107	.0211	.0417	.0514
17	.0514	.0171	.0211	.0107	.0514	.0107	.0211
18	.0514	.0171	.0141	.0107	.0514	.0107	.0211
19	.0514	.0107	.0141	.0095	.0514	.0107	.0141
20	.0514	.0107	.0141	.0095	.0514	.0107	.0141
21	.0514	.0107	.0141	.0107	.0514	.0107	.0141
22	.0514	.0107	.0141	.0095	.0514	.0107	.0141
23	.0514	.0095	.0141	.0141	.0514	.0107	.0141
24	.0141	.0514	.0107	.0366	.0141	.0514	.0107
Max	.0514	.0514	.0514	.0366	.0514	.0514	.0686
Min	.0107	.0095	.0095	.0095	.0141	.0107	.0107
Avg	.0264	.0400	.0243	.0137	.0291	.0341	.0249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 206 / 11KV GADEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***		***	***	.2735		.0282
2	***		***	***	.2762		
3			.2819	.2701	.2774	.1494	.2793
4	***		***	***	.2762	.2988	.3025
5	***		***	***	.2755	.2291	.3383
6			.3406	.3993	.3109	.1704	.3559
7	***		***	***	.3239		.3623
8	***		***	***	.4946		
9			.3799	.5225	.5396		
10	***		***	***	.5434		
11	***	.2241	***	***	.2119		.1444
13	***	.112		***			
14	***	.1307		***			
15	.394	.2241					
16	***	.2241					
17	***	.208					
18	.5887	.16					
19	***						
20	***						
22	***						
23	***						
Max	25.2702	.2241	25.2142	25.2116	.5434	.2988	.3623
Min	.394	.112	.2819	.2701	.2119	.1494	.0282
Avg	22.2903	.1833	18.3441	19.3932	.3457	.2119	.2587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 207 / 11Kv Asana River Express NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201		.2793	.3201	.3216	.527	.527
2	.317		.2763	.3178	.3201	.5277	.5277
3	.317		.3132	.317	.3147	.5285	.5316
4	.3162		.3178	.317	.317	.53	.5316
5	.3162		.317	.3162	.3201	.53	.3929
6	.3147		.314	.314	.3201	.5399	.3967
7	.3178		.3163	.3147	.3201	.5361	.5194
8	.2431		.3163	.317	.3178	.3894	
9	.2439		.314	.173	.5373	.317	
10	.3193	.1448	.285	.3147	.535	.2896	
11	.3178	.1448	.3734	.3125	.5365	.5373	.4226
12	.3155	.1448	.3079	.3086	.5358	.5365	.5399
13	.3178	.1494	.3041	.3102	.535	.4611	.5338
14	.317	.1448	.3056	.3109	.5335	.3971	.5331
15	.3003	.1448	.3033	.2522	.5388	.535	.5354
16	.2987	.1448	.3018	.3109	.5373	.5327	.5384
17	.1532	.1448	.3063	.3102	.5308	.5293	.5388
18	.1578	.1448	.3109	.3064	.5346	.5361	.5373
19	.1669	.1448	.3155	.314	.5331	.5361	.5365
20	.1715	.1448	.3201	.317	.5262	.5293	.5342
21	.0983	.1448	.3239	.3216	.5323	.5262	.5319
22	.0762	.1448	.3269	.3247	.5247	.5277	.5632
23	.0732	.1448	.3262	.3231	.5247	.53	.5586
24	.1723		.3216	.3208	.4199	.5239	.5567
Max	.3201	.1494	.3734	.3247	.5388	.5399	.5632
Min	.0732	.1448	.2763	.173	.3147	.2896	.3929
Avg	.2484	.1451	.3124	.3069	.4570	.4981	.5184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 201 / 11 KV MAHAVEER SOCIETY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	.3696	***	***	.7674	.7575	.7476
2	.727	.3696	.639	.6374	.7346	.7308	.727
3	***	.3696	***	***	.7224	.7224	.7202
4	***	.3696	***	***	.7141	.7156	.708
5	.708	.3696	.6238	.6129	.3498	.711	.7019
6	***	.3696	***	***	.3742	.7148	.7179
7	***	.3696	***	***	.788	.3589	.8687
8	.8974	.4668	.933	1.0078	.8768	.7171	1.0589
9	***	.3734	***	***	1.3405	1.1499	.57
10	***	.5601	***	***	.6257	.9587	
11	1.0623	.5601	.913	1.4879	1.0673	1.0437	
12	***	.5601	***	***	1.0947	1.0163	.7621
13	***	.5601	***	***	1.0616	.9599	1.1618
14	.8154	.5601	.8291	.8238	1.0364	.9614	.9671
15	***	.5601	***	***	.9311	.9301	.8489
16	***		***	.4512	.4763	.4687	.4161
17	.7203		.7945	.2522	.8714	.7979	.25
18	***	.5544	***	.9126	1.1122	1.1241	.6744
19	***	.5544	***	1.6672	1.308	1.153	1.2254
20	1.233	.6468	1.2075	1.3578	1.142	1.1972	1.265
21	***	.3734	***	1.189	1.0727	1.1424	1.0174
22	***	.2801	***	.8939	.8832	.9929	.9152
23	.82	.2801	.8101	.8566	.823	.8147	.8543
24	***	.3696	***	.7144	.7842	.7704	.8177
Max	50.503	.6468	50.503	50.503	1.3405	1.1972	1.265
Min	.708	.2801	.6238	.2522	.3498	.3589	.25
Avg	33.8061	.4476	33.8194	21.5029	.8732	.8712	.8180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 202 / 11 KV SHIVAJI NAGAR ROAD SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8154	1.2936	2.6223	2.8216	2.8731	2.9117	3.049
2	2.7399	1.2936	2.4844	2.7141	2.7588	2.8391	2.9523
3	2.6447	1.2012	2.4409	2.6631	2.6631	2.7476	2.7852
4	2.4779	1.0974	2.3479	2.5496	2.5907	2.4912	2.6905
5	2.4428	1.0164	2.2052	2.3487	2.351	1.3032	2.3594
6	2.1511	1.0164	2.1367	2.1412	2.1624	1.7257	2.3145
7	2.0123	1.0164	2.0993	2.1275	2.1944	2.021	2.2519
8	2.0355	1.0269	2.1115	2.1106	2.2775	2.3479	2.3857
9	2.0728	1.1203	2.0378	2.2055	2.3401	2.4081	2.4451
10	2.2321	1.0269	2.1517	2.2459	2.3649	2.2538	2.3412
11	2.4306	1.0269	2.2665	2.3847	2.5221	2.5149	2.5881
12	2.5137	1.0269	2.4566	2.5705	2.6661	2.8048	1.307
13	2.7181	1.307	2.614	2.644	2.8119	2.8412	1.4003
14	2.773	1.307	2.6742	2.825	2.8058	2.9045	1.4003
15	2.7172	1.307	2.6894	2.914	2.4805	2.9191	1.4003
16	2.9302	1.307	2.7466	2.8951	3.214	3.123	1.4937
17	2.8825	1.2803	2.7786	2.93	3.1314	3.11	1.4937
18	2.8444	1.3575	2.8079	2.9102	3.0788	2.9656	1.4937
19	2.9455	1.386	2.9218	2.8984	3.1576	3.184	1.4937
20	3.0804	1.2803	3.1169	3.2015	3.1322	3.3882	1.4937
21	3.003	1.267	2.965	3.2251	3.1497	3.3451	1.4937
22	2.9374	1.267	2.8981	3.126	3.1131	3.1931	1.587
23	2.8658	1.267	3.0041	3.0483	3.2411	3.2765	1.4937
24	2.8794	1.4003	2.8331	2.8917	3.2236	3.1314	1.4784
Max	3.0804	1.4003	3.1169	3.2251	3.2411	3.3882	3.049
Min	2.0123	1.0164	2.0378	2.1106	2.1624	1.3032	1.307
Avg	2.6311	1.2040	2.5588	2.6830	2.7627	2.7396	1.9663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 203 / 11 KV INDUSTRIAL AREA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1244	.543	1.0761	1.1107	1.1343	1.1721	1.089
2	1.1465	.5258	1.1127	1.1374	1.1671	1.1645	1.1378
3	1.1557	.5144	1.1043	1.0974	1.1679	1.1454	1.126
4	1.1488	.5144	1.1005	1.0966	1.1633	1.1355	1.1207
5	1.1191	.5087	1.041	1.0567	1.1221	1.1043	1.0711
6	1.126	.5144	1.0394	1.0498	1.1057	1.0685	1.0681
7	1.1282	.5258	1.0525	1.0772	1.1507	1.0978	1.1374
8	1.1507	.5316	1.1149	1.1172	1.1885	1.1416	1.2442
9	1.1873	.6535	1.1595	1.3072	1.6239	1.1858	1.3012
10	1.4587	.5601	1.1877	1.3479	1.3941	1.6019	1.486
11	1.8164	.9335	1.3318	1.7837	1.941	1.7798	2.1125
12	1.9833	.7468	1.6541	1.8888	2.1857	2.0809	2.2299
13	1.9727	.8402	1.6034	1.9323	2.2238	2.1312	1.962
14	1.9391	.8402	1.6088	1.9353	1.0722	2.1365	2.1918
15	2.1178	.8402	1.5554	1.9216	.6602	2.119	2.2344
16	2.1218	.8402	1.7237	1.962	2.3059	2.1807	2.2611
17	2.1074	.6535	1.7061	2.1295	2.3	2.1723	.8932
18	2.0906	.6602	1.6856	2.1363	2.2413	2.0405	.8595
19	1.9658	.7545	1.7176	2.1356	2.0504	1.9887	1.9948
20	1.8197	.6535	1.7404	2.0207	1.8576	1.9483	1.9005
21	1.6871	.6468	1.5889	1.656	1.6834	1.7532	1.7086
22	1.4141	.6401	1.3944	1.7509	1.5775	1.5371	1.5782
23	1.225	.5373	1.2262	1.2841	1.4974	1.3311	1.3626
24	1.2022	.5544	1.1305	1.1946	1.2749	1.1778	1.3311
Max	2.1218	.9335	1.7404	2.1363	2.3059	2.1807	2.2611
Min	1.1191	.5087	1.0394	1.0498	.6602	1.0685	.8595
Avg	1.5504	.6472	1.3606	1.5471	1.5454	1.5914	1.5167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 204 / I.T.M. Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.9335	.6468	.905	.9335	.9335	.9145
2	.924	.924	.6468	.905	.924	.8316	.924
3	.924	.8316	.6468	.905	.924	.7392	.924
4	.924	.7392	.6468	.823	.7392	.7392	.7392
5	.924	.6468	.6468	.7316	.5544	.7392	.6468
6	.5544	.5544	.6468	.5487	.5544	.6468	.6468
7	.5544	.5544	.5487	.5544	.5544	.6468	.6401
8	.6535	.5601	.5487	.5544	.5544	.6468	.6468
9	.6535	.6535	.5601	.6535	.5544	.6535	.6535
10	.724	.7468	.6535	.7468	.7316	.7468	
11	.905	.8402	.7468	.924	.924	.9335	1.1203
12	.905	.8402	.7468	.924	.924	.9335	1.1203
13	1.086	.9335	.7468	.9955	1.0164	.9335	1.1203
14	1.086	.9335	.7468	1.086	1.0164	.9335	1.1203
15	1.0974	.9335	.9335	1.086	1.1088	1.0269	1.1203
16	1.0974	.9335	.9335	1.0745	1.0974	1.1203	1.2136
17	1.1088	.8316	.9145	1.1088	1.1088	1.1203	1.1203
18	.9335	.8145	.9145	1.0164	1.1203	1.0164	1.0269
19	1.1203	.9955	1.0059	1.0164	1.1203	1.0164	1.1203
20	1.1203	.905	1.0059	1.0269	1.1203	1.0164	1.1203
21	.9335	.905	.9145	.9335	1.0269	1.0164	1.1203
22	.8402	.9145	.9145	.9335	.9335	.924	1.0269
23	.9335	.924	1.0059	.9335	.9335	.9145	1.0269
24	.9335	.9335	.8316	.905	.9335	.9335	.9145
Max	1.1203	.9955	1.0059	1.1088	1.1203	1.1203	1.2136
Min	.5544	.5544	.5487	.5487	.5544	.6468	.6401
Avg	.9108	.8243	.7731	.8871	.8920	.8818	.9577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 202 / 11 KV NASARADPURA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3658	.3547	.362	.4435	.4344	.439
2	.3439	.3658	.3547	.3511	.4435	.3403	.439
3	.3292	.3658	.3547	.3475	.3696	.3258	.439
4	.3109	.4024	.3547	.3258	.3326	.3077	.4755
5	.3292	.439	.3734	.3439	.3696		.4755
6	.3475	.4755	.4481	.362	.4066	.3077	.5121
7	.2926	.5121	.4854	.4706	.5121		
8	.4938	.5121	.5041	.4525	.5487	.5373	
9	.4024		.4481	.4163	.4755	.4656	
10		.4755	.3734	.4024			
11	.3658	.4854	.4163	.4066	.3439	.439	.5853
12	.3658	.4481	.3982	.4435	.4525		.5487
13	.439	.4481	.3982	.4066	.3801	.439	.4755
14	.4755	.4481	.4163	.4066	.4344	.439	.439
15	.4755		.4344	.4435	.3982	.5121	.439
16	.5121			.4066			
17	.5121		.4706	.4066	.2534	.5487	
18	.5853	.3734	.4887	.439	.3982	.5853	.5853
19	.6219	.4481	.5487	.4755	.6335	.6219	.6219
20	.6219	.4854	.5792	.5121	.5792	.5487	.6219
21	.5487	.4481	.4887	.5121	.5068	.5121	.5853
22	.4024	.4108	.4706	.5487	.5068	.5121	.5487
23	.3658	.4108	.3982	.4755	.5121	.4755	.5121
24	.3982	.3658	.3734	.3801	.4805	.4887	.4755
Max	.6219	.5121	.5792	.5487	.6335	.6219	.6219
Min	.2926	.3658	.3547	.3258	.2534	.3077	.439
Avg	.4323	.4343	.4319	.4207	.4446	.4653	.5121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 203 / 11 KV Dnyaneshwar Wadi
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6404	1.6461	3.5483	3.7273	3.6108	3.853	3.6572
2	3.475	1.6461	3.4392	3.6389	3.4393	3.7246	3.52
3	3.3432	1.6827	3.3288	3.5511	3.3554	3.5711	3.4682
4	3.3327	1.7558	3.2632	3.4613	3.2937	3.4739	3.453
5	3.327	1.8656	3.3996	3.4743	3.3356	1.7528	3.5597
6	3.5978	1.9204	3.6207	3.5215	3.5215	3.8469	2.0119
7	3.9815	1.9753	3.5139	3.8287	3.7586	3.8006	
8	4.0794	1.9022	3.8256	4.1592	3.8569	3.6703	
9	3.8089	1.7375	3.7586	3.8401	3.7296	3.3693	
10	3.4202	1.5729	3.4773	3.4576	3.416	3.2215	
11	3.3234	1.5684	3.1793	3.1755	1.6552	3.1459	2.1262
12	3.3143	1.531	1.7646	2.87			1.8781
13	3.2068	1.5684	3.1294	3.0049	1.2984	2.9706	1.8267
14	3.2373	1.6057	3.2394	3.1158	3.059	3.2054	1.8983
15	3.1969	1.643	3.3539	3.2087	3.1329	3.1954	1.8267
16	3.2762	1.6804	3.5417	3.3059	3.2477	3.6107	1.8267
17	3.3897	1.8671	3.6427	3.3554	3.6686	3.866	1.7909
18	3.6023	1.8858	3.73	3.5612	3.6065	3.9781	1.9136
19	4.0428	2.0165	4.0929	3.7631	3.8437	4.2028	1.949
20	4.0375	1.9791	4.0337	3.9239	4.0615	4.1511	2.0199
21	3.5627	1.9044	3.954	3.8218	3.9736	3.8661	1.8781
22	3.4035	1.8671	3.9622	3.9209	4.0895	3.8706	2.0553
23	3.5041	2.0165	4.1038	3.9289	4.2055	3.9522	2.0199
24	3.6961	1.6461	3.8783	3.8729	3.9041	4.0281	1.829
Max	4.0794	2.0165	4.1038	4.1592	4.2055	4.2028	3.6572
Min	3.1969	1.531	1.7646	2.87	1.2984	1.7528	1.7909
Avg	3.5333	1.7702	3.5325	3.5620	3.4375	3.5794	2.3254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 204 / 11 KV FARANDE NAGAR - II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.8779	.8962	.8779	.9774	.8779	.9877
2	.8507	.8779	.8962	.8507	.905	.8048	.9877
3	.8507	.9145	.8962	.8688	.8326	.439	1.0242
4	.7964	.9145	.8962	.8326	.8326	.7316	1.0608
5	.7602	.9511	.9335	.7964	.8048		1.0974
6	.8145	.9511	.9709	.8131	.8048	.4755	1.0974
7	.9231	.9511	.8962	.924	.8779	.6219	
8	.9145	.9145	.8215	.905	.8413	.6878	
9	.8413	.823	.7842	.7783	.7316	.9492	
10	.724	.8048	.7468	.6584	.7316	.724	
11	.7316	.7842	.7059	.6584	.7059	.7316	1.0498
12	.7682	.8589	.6878	.6219	.695	.7682	.9412
13	.8413	.8962	.7133	.695	.6878	.7682	.8326
14	.8505	.8589	.7316	.7316	.7682	.8048	.8688
15	.8779	.8215	.7421	.7682	.7964	.8413	.905
16	.8779	.7468	.7602	.7316	.7964	.8779	.8326
17	.8779	.7842	.7964	.7316	.8145	.9145	.8326
18	.9145	.8029	.8326	.8048	.7964	.9877	.905
19	.9511	.8589	.9412	.8413	.8688	1.0974	1.1584
20	.9145	1.0456	.9231	.8688	.8869	1.0974	1.086
21	.9145	1.0829	.9774	.9412	.9134	1.0608	1.0498
22	.9145	1.0082	1.0498	.9774	1.0136	1.0242	1.0498
23	.9145	1.0082	1.0679	1.086	1.1222	.9877	1.1584
24	.8688	.8779	.9335	.8688	1.0498	1.0679	.9877
Max	.9511	1.0829	1.0679	1.086	1.1222	1.0974	1.1584
Min	.724	.7468	.6878	.6219	.6878	.439	.8326
Avg	.8567	.8923	.8584	.8180	.8440	.8409	.9956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 205 / 11 KV Vijay Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3394	1.4266	1.419	1.3394	1.3394	1.5203	1.4632
2	1.3032	1.4266	1.419	1.262	1.3394	1.3032	1.4266
3	1.2127	1.4266	1.419	1.1584	1.2308	1.2489	1.39
4	1.2127	1.39	1.419	1.1584	1.2308	1.2127	1.4632
5	1.1946	1.39	1.3817	1.1222	1.1584		1.4998
6	1.2489	1.4632	1.307	1.134	1.267	1.5746	1.5729
7	1.2489	1.4632	1.307	1.4118	1.5203	1.4842	
8	1.3535	1.6095	1.307	1.3213	1.4842	1.4118	
9	1.2803	1.4632	1.307	1.3032	1.3756	1.448	
10	1.267	1.4266	1.307	1.2489	1.3394	1.3756	
11	1.2803	1.419	1.134	1.086	1.1946	1.3535	1.6118
12	1.2803	1.3443	1.1041	1.1946	1.1765		1.3575
13	1.2803	1.307	1.086	1.0974	1.2308	1.2803	1.3032
14	1.2437	1.2696	1.1041	1.0974	1.1946	1.2803	1.3611
15	1.2071	1.2696	1.1946	1.1706	1.3756	1.2803	1.3394
16	1.2437	1.307	1.2127	1.2308	1.2894	1.2803	1.3756
17	1.2437	1.307	1.2489	1.2308	1.2986	1.3169	1.3394
18	1.4266	1.307	1.2489	1.3032	1.3394	1.4266	1.3969
19	1.5729	1.5684	1.4842	1.448	1.5565	1.5729	1.6118
20	1.5729	1.6057	1.5565	1.4327	1.7918	1.5729	1.6118
21	1.4998	1.643	1.5203	1.5203	1.7013	1.4998	1.5043
22	1.4632	1.6057	1.5181	1.5565	1.6289	1.4998	1.6118
23	1.4632	1.587	1.5203	1.5203	1.6289	1.4632	1.6476
24	1.4449	1.4632	1.4563	1.4118	1.4118	1.6644	1.4632
Max	1.5729	1.643	1.5565	1.5565	1.7918	1.6644	1.6476
Min	1.1946	1.2696	1.086	1.086	1.1584	1.2127	1.3032
Avg	1.3285	1.4370	1.3326	1.2817	1.3793	1.4123	1.4676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 202 / 11 KV ANAND NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.1948	1.9909	1.9071	2.2634	2.0814	1.9909	2.5606
16	2.5606	2.0851	2.5606	2.6244	2.6244	2.6797	2.8349
24	3.0769	3.0769	3.2007	3.1093	3.2007	3.4027	3.2007
Max	3.0769	3.0769	3.2007	3.1093	3.2007	3.4027	3.2007
Min	2.1948	1.9909	1.9071	2.2634	2.0814	1.9909	2.5606
Avg	2.6108	2.3843	2.5561	2.6657	2.6355	2.6911	2.8654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 203 / 11 KV GAJANAN MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.2862	2.1719	2.3282	2.3777	2.3529	2.5072	2.5606
16	2.5072	2.4177	2.5339	2.5692	2.652	2.6244	2.6244
24	3.0178	3.0769	2.9864	3.0769	3.0769	3.3484	3.1674
Max	3.0178	3.0769	2.9864	3.0769	3.0769	3.3484	3.1674
Min	2.2862	2.1719	2.3282	2.3777	2.3529	2.5072	2.5606
Avg	2.6037	2.5555	2.6162	2.6746	2.6939	2.8267	2.7841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 204 / 11 KV WAMAN NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0119	1.9204	2.5072	2.1033	1.829	2.0119	2.0119
16	2.3777	2.4025	2.4691	2.4434	2.5606	2.5606	2.652
24	2.0851	2.7435	2.5606	2.5606	2.652	2.8006	2.7435
Max	2.3777	2.7435	2.5606	2.5606	2.652	2.8006	2.7435
Min	2.0119	1.9204	2.4691	2.1033	1.829	2.0119	2.0119
Avg	2.1582	2.3555	2.5123	2.3691	2.3472	2.4577	2.4691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 205 / 11 KV GANESH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1203	1.4632	1.0974	1.2012	1.2936	1.6461	1.2012
16	1.2269	1.2936	1.1888	1.1888	.4525	1.448	1.2936
23		1.4632					
24	1.6289	1.4632	1.6461	1.6461	1.6461	1.6461	1.6461
Max	1.6289	1.4632	1.6461	1.6461	1.6461	1.6461	1.6461
Min	1.1203	1.2936	1.0974	1.1888	.4525	1.448	1.2012
Avg	1.3254	1.4208	1.3108	1.3454	1.1307	1.5801	1.3803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 206 / 11 KV PAWDEWADI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.3575				
11				2.5339		
12	1.7924					
17					1.5546	.8669
19			1.7375			
24		1.7924				
Max	1.7924	1.7924	1.7375	2.5339	1.5546	.8669
Min	1.7924	1.3575	1.7375	2.5339	1.5546	.8669
Avg	1.7924	1.5750	1.7375	2.5339	1.5546	.8669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 207 / 11 KV VIVEK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.6406	2.4272	2.4272	2.6406	2.7073		2.0538
16					1.1765		
24	1.2803	1.2803	1.267	1.2803	1.2803	1.1765	1.1765
Max	2.6406	2.4272	2.4272	2.6406	2.7073	1.1765	2.0538
Min	1.2803	1.2803	1.267	1.2803	1.1765	1.1765	1.1765
Avg	1.9605	1.8538	1.8471	1.9605	1.7214	1.1765	1.6152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 208 / 11 KV POLICE COLONY`

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.086	1.0745	.985	1.086	1.267	1.0631	1.1641
16	1.387	1.2803	1.3717	1.4327	1.4327	1.1641	1.5384
23		1.2803					
24	1.3289	1.2403	1.2403	1.3289	1.448	1.5089	1.4175
Max	1.387	1.2803	1.3717	1.4327	1.448	1.5089	1.5384
Min	1.086	1.0745	.985	1.086	1.267	1.0631	1.1641
Avg	1.2673	1.2189	1.199	1.2825	1.3826	1.2454	1.3733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 209 / 11 KV SAHAYOG NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.1253	1.9909	1.6289	1.829	1.6461	1.6461	2.2862
16	2.2624	2.3282	1.7194	1.7909	1.7909	2.3529	2.4434
24	2.7149	2.5072	2.1491	2.1491	2.0814	2.1719	2.7759
Max	2.7149	2.5072	2.1491	2.1491	2.0814	2.3529	2.7759
Min	2.1253	1.9909	1.6289	1.7909	1.6461	1.6461	2.2862
Avg	2.3675	2.2754	1.8325	1.923	1.8395	2.0570	2.5018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 400 / Auxiliary Supply

Feeder KV- 33 / INCOMING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	10.3167						
24		6.1728	8.7449	2.4434	10.974	10.0823	7.2017
Max	10.3167	6.1728	8.7449	2.4434	10.974	10.0823	7.2017
Min	10.3167	6.1728	8.7449	2.4434	10.974	10.0823	7.2017
Avg	10.3167	6.1728	8.7449	2.4434	10.974	10.0823	7.2017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 401 / 33 KV Pawdewadi (Old NTC) NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			10.8968				
24	10.631	6.5158		4.3239	8.1219	8.7792	10.8968
Max	10.631	6.5158	10.8968	4.3239	8.1219	8.7792	10.8968
Min	10.631	6.5158	10.8968	4.3239	8.1219	8.7792	10.8968
Avg	10.631	6.5158	10.8968	4.3239	8.1219	8.7792	10.8968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 402 / 33 KV LIMBGAON FEEDER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.1948	2.6863	2.6863	7.9561	2.672	4.9383	2.2177
Max	2.1948	2.6863	2.6863	7.9561	2.672	4.9383	2.2177
Min	2.1948	2.6863	2.6863	7.9561	2.672	4.9383	2.2177
Avg	2.1948	2.6863	2.6863	7.9561	2.672	4.9383	2.2177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 403 / 33 KV DEGAON FEEDER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23			8.259			7.8418	
24	2.1862	2.1948	1.4003	7.6818	1.7147		1.9004
Max	2.1862	2.1948	8.259	7.6818	1.7147	7.8418	1.9004
Min	2.1862	2.1948	1.4003	7.6818	1.7147	7.8418	1.9004
Avg	2.1862	2.1948	4.8297	7.6818	1.7147	7.8418	1.9004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 404 / 33 KV VIDHUT BHAVAN FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
18							12.0713
24	12.2525	12.1971	12.1971	9.7165	6.8016	9.0364	
Max	12.2525	12.1971	12.1971	9.7165	6.8016	9.0364	12.0713
Min	12.2525	12.1971	12.1971	9.7165	6.8016	9.0364	12.0713
Avg	12.2525	12.1971	12.1971	9.7165	6.8016	9.0364	12.0713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 405 / 33 KV NEELA FEEDER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			2.1628				
23					7.3303		
24	2.2119	2.2377		7.7732		5.5453	1.989
Max	2.2119	2.2377	2.1628	7.7732	7.3303	5.5453	1.989
Min	2.2119	2.2377	2.1628	7.7732	7.3303	5.5453	1.989
Avg	2.2119	2.2377	2.1628	7.7732	7.3303	5.5453	1.989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 201 / 11 KV LIMBGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0747		.2258	.1833		.0373
2		.0747	.2086	.2258	.2115		.0373
3	.0417	.0934	.2086		.2858		.2286
4	.0549	.0934	.2782	.301	.2961	.2896	.2572
5			.2896	.3734	.3567		.3144
6			.4344	.5268	.4515	.362	.4344
7			.5868	.6944	.5719	.5068	.5418
8			.4344	.6773	.5281	.5268	
9			.5868	.6773	.5575	.5268	
10			.5068	.4108	.5716	.535	
11	.7316	.5001					.2286
12		.4287					.6249
13		.4344					
14		.4344					
15	.6173	.4344					
16	.6944	.4572					
17	.6706						
18	.6455	.5068					
19	.112		.112	.0943	.056	.0373	
20	.112	.0554		.132	.056	.0373	.0934
21	.0934	.0554	.0617	.112	.056	.0373	.0934
22	.112			.112	.056	.037	.0886
23	.0934	.037	.0594		.056		.0709
24	.0373	.0732	.037		.112		.037
Max	.7316	.5068	.5868	.6944	.5719	.535	.6249
Min	.0373	.037	.037	.0943	.056	.037	.037
Avg	.2909	.2502	.2926	.3510	.2754	.2896	.2206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 202 / 11 KV CHUDAWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.1294	.3681		.5868		.1878
2		.1294	.5053		.6939		.1878
3	.0747	.1294	.5163		.7313		.5368
4	.0709	.1478	.6523		.6969	.4096	.8701
5			.7091		.8433	.274	1.0117
6			.8748		1.0265	.7808	.9439
7			1.0951		1.1858	1.113	1.0715
8			1.1729		1.038	1.1397	.471
9			1.1782	.7043	1.209	.9593	
10			1.2319	1.2807	1.1865	.9853	
11	.6716	.7049	.4954	1.3192	.4809	.4153	.6687
12		.7049		1.2582			.4119
13		.7049		1.1774			.466
14		.2743		1.1286			
15	.7042	.5563		.1726			
16	.7819	.7145					
17	.8253						
18	.7928	.6763					
19	.1848	.0739	.1646	.312	.0855	.1303	.0636
20	.1109	.0739	.1326	.4134	.1316	.1974	.2854
21	.112	.0739	.0983	.4058	.1373	.2008	.2831
22	.1494	.0739		.2823	.1427	.1886	.2598
23	.1494	.0739		.0861	.1457	.1158	.0876
24	.0747	.1463	.0554	.0804	.2246	.1143	.1593
Max	.8253	.7145	1.2319	1.3192	1.209	1.1397	1.0715
Min	.0709	.0739	.0554	.0804	.0855	.1143	.0636
Avg	.3412	.3169	.6167	.6632	.6204	.5017	.4686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 203 / 11 KV NALESHWAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0286					
7		.0434					
8		.0412					
9	.0293	.0274					
10		.029					
11				.0282	.0305		.0332
12			.0293	.0286	.0305		.0297
13			.0286	.0301	.0305		
14			.0282	.0259	.0259		
15			.0267	.0267			
16			.0286	.0248			
17			.0271	.0271		.0282	
18			.0267			.0282	
Max	.0293	.0434	.0293	.0301	.0305	.0282	.0332
Min	.0293	.0274	.0267	.0248	.0259	.0282	.0297
Avg	.0293	.0339	.0279	.0273	.0294	.0282	.0315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 204 / 11 KV TALNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.0556	.0564				
6		.0846				
7		.0947				
8	.1235	.1143				
9	.0724	.1158				
10	.1286	.141				
11			.0762			
12			.1467	.1014	.1448	.0772
13			.1174	.0686	.1448	.0772
14			.0714	.0549	.1448	
15			.0734	.0549	.0705	.0743
16			.0734	.0667	.1353	.0446
17			.0724	.0846		.0714
18			.0714	.08	.0676	
Max	.1286	.141	.1467	.1014	.1448	.0772
Min	.0556	.0564	.0714	.0549	.0676	.0446
Avg	.0950	.1011	.0878	.0730	.1180	.0689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 205 / 11 KV LIMBGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8246	.4163	.8253	.804	.8825	.919	.4755
2	.807	.4163	.8116	.7941	.8658	.9114	.4611
3	.9027	.4119	.8086	.7872	.865	.9015	.458
4	.9134	.439	.8025	.788	.8818	.9	.4451
5	1.1405	.6036	.8429	.9378	1.0197	.4801	.4694
6	1.4918	.695	.6843	1.3257	1.3527	1.4052	.6752
7	1.1203	.7392	1.5935	1.4567	1.5615	1.5055	.7948
8	.8291	.8048	1.4782	1.3595	1.4727	1.4836	.8063
9	.9975	.6584	1.273	1.0791	1.3047	1.2142	
10	1.236	.5373	.9877	.8676	1.0829	.9518	
11	1.0022	.2658	.8467	.7392	.9137	.807	.4525
12	.5868		.772	.7583	.2507	.2195	.9707
13	.4558		.5291	.2713			.5441
14	.4512		.6371				
15	.7823	.362	.7377	.8234	.8132	.8612	.8535
16	.9286	.4525	.8017	.9	.9143	.9336	.9617
17	1.025		.8398	.9743	1.0711	1.1014	.9779
18	1.2643	.543	.9952	1.1614	1.193	1.1736	1.0006
19	1.4663	.6401	1.1352	1.4182	1.1772	1.4426	.6783
20	1.3078	.5487	.6996	1.4487	1.3184	1.409	1.3001
21	1.0211	.5487	1.166	.5479	.6836	1.1919	1.1582
22	.9981	.4572	1.0008	1.0227	.57	1.0723	.5952
23	.9099	.4572	.9556	.5213	.5075	.5479	.9107
24	.9279	.4344	.9181	.8497	.9153	.8497	.6285
Max	1.4918	.8048	1.5935	1.4567	1.5615	1.5055	1.3001
Min	.4512	.2658	.5291	.2713	.2507	.2195	.4451
Avg	.9746	.5216	.9226	.9407	.9826	1.0128	.7437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174048 / 33 KV DEGAON

Feeder No / Name : 202 / 11 KV SUGAR FACTORY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372		.12	.1372	.1372	.1372
2	.1372	.1372		.12	.1372	.1372	.1372
3	.1372	.1372		.12	.1372	.1372	
4	.1372	.1372		.12	.1372	.1372	.1372
5	.1372	.1372		.12	.1372	.0686	.1372
6	.1372	.1372		.12	.1372	.0686	.1372
7	.12	.1372		.12	.1372	.0686	.1372
8	.12			.12	.1372	.12	
9	.1372		.1372	.12	.1372	.1372	
10	.1372		.12	.1372	.12	.1372	
11	.1372		.12	.1372	.12	.1372	.12
12	.1372		.12	.1372	.12		.12
13	.1372		.12	.1372	.12	.1372	.12
14	.1372		.12	.1372	.12		.1372
15	.1372		.12	.1372	.1372		.1372
16	.1372		.12	.1372	.1372		.1372
17	.1372		.12	.1372	.12	.1372	.12
18	.1372		.12	.1372	.12	.1372	.12
19	.1372		.12	.1372	.12	.1372	.1372
20	.1372		.1372	.1372	.1372	.1372	.1372
21	.1372		.1372	.1372	.1372	.1372	.1372
22	.1372		.1372	.1372	.1372	.1372	.1372
23	.1372		.1372	.1372	.1372	.1372	.1372
24	.1372	.1372		.1372	.1372	.1372	.1372
Max	.1372	.1372	.1372	.1372	.1372	.1372	.1372
Min	.12	.1372	.12	.12	.12	.0686	.12
Avg	.1358	.1372	.1257	.1308	.1315	.1261	.1329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174048 / 33 KV DEGAON

Feeder No / Name : 203 / 11 KV SHELGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAY-17	03-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
11	3.0007	3.0864	3.0007
12	3.1722	3.2579	3.1722
13	3.0864	3.1722	3.0864
14	3.0007	3.0864	3.1722
15	3.0007	3.0007	3.0864
16	3.0007	3.0007	3.0864
17	3.0007	3.0007	3.0864
18	2.8292	2.915	2.915
Max	3.1722	3.2579	3.1722
Min	2.8292	2.915	2.915
Avg	3.0114	3.065	3.0757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174048 / 33 KV DEGAON

Feeder No / Name : 205 / 11KV PIMPALGAON GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859		.6859	.6859	.6859	.6859
2	.6859	.6859		.6859	.7202	.6859	.7888
3	.6859	.7202		.6859	.7202	.6859	.8573
4	.8573	.823		.8573	.823	.9945	1.1317
5	.9431	.8573		.9945	1.0631	1.2003	1.1317
6	1.1488	.9259		1.1145	1.2003	1.2346	1.2346
8					.1029		
9			.7716				
10	1.0288		.7716	1.0288	.8916	.7888	
11	.8573		.7716	.8573	.8059	.7888	.9431
12	.8573		.703	.7888	.7716		.9088
13	.7888		.6859	.7888	.703	.7888	.8402
14	.7202		.6344	.7888	.7202		.823
15	.7888		.6859	.7888	.7716		.823
16	.8573		.8059	.7888	.8573		.8573
17	.0229		.823	.7888	.8916	.8573	.9431
18	.8573		.823	.8573	.9945	.8573	.0686
19	.9602		1.0288	.8573	1.1145	.8573	1.1145
20	.8573		.9431	.8573	1.0288	.8573	1.0288
21	.823		.8745	.8573	.9431	.823	.9945
22	.7888		.823	.8573	.8573	.7888	.9088
23	.7888		.7716	.8573	.823	.6859	.823
24	.7373	.6859		.7545	.6859	.7716	.6859
Max	1.1488	.9259	1.0288	1.1145	1.2003	1.2346	1.2346
Min	.0229	.6859	.6344	.6859	.1029	.6859	.0686
Avg	.7972	.7692	.7945	.8353	.8262	.8442	.8796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 202 / 11 KV JAITAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0373			.0373	
2		.3772	.0373		.0754	.0373	
3	.381		.0373	.0381		.0373	.0381
4		.4527	.0373		.0377	.0373	
6	.4763	.5093					
8	.6668	.5658				.0373	
9	.6668	.6602					
10	.6097	.5601					
11			.381	.4715	.4668	.4191	.3734
12				.6602	.5601		.4668
13				.6602	.5975		.4668
14			.381	.6602	.5975	.4763	.5228
15					.5975		.5228
16			.4191	.9054	.5601		.5228
17		.0362	.4191		.5601		.5601
18	.0377	.0373	.381	.8488	.5228	.4763	.5601
19		.0373			.0373	.381	.0373
20	.0377	.0373		.0377	.0373	.381	
21		.0373	.0381		.0373	.0381	
22	.0377	.0373		.0377	.0373		.0373
23		.0373	.0381		.0373	.0381	.0373
24	.0381	.0377	.0373	.0381	.0377	.0377	.0381
Max	.6668	.6602	.4191	.9054	.5975	.4763	.5601
Min	.0377	.0362	.0373	.0377	.0373	.0373	.0373
Avg	.3280	.2445	.1870	.4358	.3000	.1872	.3218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 203 / 11 KV PIMPALGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0373			.0373	
2		1.226	.0373		.0754	.0373	
3	1.2384		.0377	.0381		.0373	.0381
4		1.358	.0373		.0754	.0373	
6	1.7147	1.6975					
8	2.0957	1.8861					
9	2.0957	1.8861					.0381
10	2.0005	1.8671					
11			1.7147	1.7918	1.6804		
12				2.0748	1.9605		
13				1.9805	1.9605		1.587
14			1.9052	1.829	1.8671	1.5242	1.7335
15					1.9605		1.7737
16			1.9052		2.0538		1.8671
17		.0373	1.9052				1.8671
18	.0377	.0373	1.9052	1.5089	.0373	1.7147	1.8671
19		.0373				1.7147	1.7737
20	.0754	.0373		1.5089	.0373	1.2384	1.4937
21		.0373	.0381		.0373	.9526	
22	.0754	.0373		.0754	.0373		.0373
23		.0373	.0381		.0373	.0381	.0373
24	.0381	.0754	.0373	.0381	.0754	.0373	.0381
Max	2.0957	1.8861	1.9052	2.0748	2.0538	1.7147	1.8671
Min	.0377	.0373	.0373	.0381	.0373	.0373	.0373
Avg	1.0413	.7327	.7999	1.2051	.8497	.6699	1.0886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 204 / 11 KV SUGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6535			.0373	
2		.0377	.7468		.9431	.0373	
3	.0381		.8402	1.2384		.0373	1.1431
4		.0377	.9709				
5			1.1203				
6			1.4003	1.5242			1.6194
7			1.4003			1.6804	
8			1.7737	1.2384	1.6032	1.8671	
9			1.8671		1.6975		
10			1.8671	1.6194	1.7737		
11		1.7737			1.7737	1.9052	1.4563
12		1.9605					1.6804
13		2.0538					1.587
14		1.7737				1.5242	
15		1.6804					
16	2.0748	2.0538					
17		1.9605	.0381				.0373
18	1.8861	1.9605	.0381	.0377		.0381	.0373
19		.0373			.0373	.0381	.0373
20	1.8861	.0373		.0377	.0373	.0381	.0373
21		.0373	.0381		.0373	.0381	
22	.0377	.0373		.0377	.0373		.0373
23		.0373	.0381		.0377	.0381	.0373
24	.0381	.0377	.0373	.0381	.0377	.0373	.0381
Max	2.0748	2.0538	1.8671	1.6194	1.7737	1.9052	1.6804
Min	.0377	.0373	.0373	.0377	.0373	.0373	.0373
Avg	.9935	.9698	.8553	.7215	.7287	.5628	.6457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 205 / 11 KV NALESHWAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8402			.7468	
2		.7545	.9335		.8488	.8402	
3	.9526		.9709	.9526		.9335	.8002
4		.8865	1.0269		1.0374	1.0269	
5			1.1203				
6	1.3717	1.226	1.4003	1.3717	1.3203		1.1622
7			1.4377			1.4003	
8	1.467	1.3203	1.2696	1.4289	1.3203	1.2136	
9	1.3717	1.1317	1.0269		1.1317		
10	1.1812	1.0269	.9335	1.2384	1.0269		
11		.8962	.8573	.8865	.8402	.8573	.8402
12	.6413	.7545		.7356	.7468		.7468
13							.6535
14	.5093		.7621				
16	.6413	.7842	.8002	.6979	1.0829	.8002	1.0269
17		.8962	.9717		1.1203	.8192	1.1203
18	1.226	1.2136	.9907	1.226	1.2136	1.0669	1.2136
19		1.307			1.307	1.1622	.7468
20	1.1317	1.2136		1.0374	1.307	1.1431	
21		1.0269	1.1431		1.0829	.8954	
22	.8865	.9335		.8865	.9335		
23		.8962	.9717		.8402	.8002	
24	.7811	.7356	.8402	.9145	.8488	.8402	.7621
Max	1.467	1.3203	1.4377	1.4289	1.3203	1.4003	1.2136
Min	.5093	.7356	.7621	.6979	.7468	.7468	.6535
Avg	1.0135	1.0002	1.0165	1.0342	1.0593	.9697	.9073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 201 / 11KV MUGAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7964		.4973	.6335	.543	.7545	.724
2	.7922		.4973	.5668	.6268	.7545	.6859
3	.7842		.5868	.5668	.7164	.7545	.7716
4	.8316		.8383	.7545	.8954	.9431	.8573
5	.961		1.0174	.8573	1.0745	1.0374	.8478
6				.8573	1.2536		1.1869
7	1.2803			1.0174	1.1603		1.073
8	1.5565			1.0059	.6783	1.226	1.1022
9	1.3535	1.3203	.9116	.9945	.9431	.9431	.9945
10	1.0059		.8192	.7459	.9431	.7316	.8573
11	.905	.9054	.6602	.6401	.8488	.6401	.763
12			.2263				.6859
13			.5658				
14			.5658				
15	.6554	.5658	.2829	.7316	.7545	.5487	.7392
16	.8192	.7545	.2829	.724	.8488	.724	.7392
17		.7287	.2829	.9145	.9054	.7316	.9145
18		.8097	1.086	.9145	.9808	.7392	1.1706
19		1.267	1.2803	1.0974	1.226	1.2936	1.2803
20		1.0059	1.086	.924	1.0374	1.0164	1.1765
21		.8145	.8954	.7316	.8488	.905	.9955
22		.724	.724	.7392	.7545	.6859	.8048
23			.6335	.543	.6602	.6859	
24	.8059		.2534	.6335	.543	.6602	.724
Max	1.5565	1.3203	1.2803	1.0974	1.2536	1.2936	1.2803
Min	.6554	.5658	.2263	.543	.543	.5487	.6859
Avg	.9652	.8896	.6663	.7902	.8687	.8303	.9092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 202 / 11 KV MATASAB AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.6722						
4	.7023						
5	.7392						
6	.7392						
7	.8501						
8	.4344						
9	.8413	.7621					
10	.8048	.7621					.8288
11			.6859	1.0974	.8383		.9326
12			.8383	1.086	.9145	1.1088	1.0288
13			.7621	1.0974	.8383	.961	1.086
14			.7621	1.086	.8383	.9511	.9145
15			.7621	1.0974	.7621	.9511	.6283
16			.7621	1.086	.8383		.924
17			.8383	1.0974	.8383		.9145
18			.9955	1.0974	.8383	1.0242	
Max	.8501	.7621	.9955	1.0974	.9145	1.1088	1.086
Min	.4344	.7621	.6859	1.086	.7621	.9511	.6283
Avg	.7229	.7621	.8008	1.0931	.8383	.9992	.9072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 203 / 11 KV AMDURA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677		.8619	.9831	1.086	.1524	.181
2	.1677		.9945	1.1336	1.2536	.1524	.1715
3	.1696		1.073		1.2536	.7621	.9602
4	.1886		1.1401	1.2574	1.2536	.7621	1.3413
5	.1886		1.56	1.3717	1.4327	.9907	1.4083
6	.1865			1.7147	1.4327		1.7635
7			1.5851	1.8652	1.5261		1.8107
8			1.6644	1.8442	1.8652		1.8991
9			1.8564	1.8233	1.7528		1.8861
10			1.8351	1.7901	1.6004		
11		1.448					
13		.7621					
14		1.5242					
15	1.7695	1.7071					
16	1.9006	1.6461					
17		1.8785					
18		1.9433					.1677
19		.2172	.1829	.1829	.1524	.2058	.2035
20		.2195	.181	.1848	.1524	.2058	.2012
21		.2172	.1791	.1829	.1524	.2172	.2035
22		.2172	.181	.1848	.1524	.2058	.2012
23		.2172	.181	.181	.1524	.2058	
24	.1696		.2172		.181	.1524	.181
Max	1.9006	1.9433	1.8564	1.8652	1.8652	.9907	1.8991
Min	.1677	.2172	.1791	.181	.1524	.1524	.1677
Avg	.5454	.9998	.9128	1.0500	.9625	.3648	.8387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 201 / 11 KV TRIKUT AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.6903	1.1706	1.2231		
2			2.0589	1.4594	1.4198		
3			2.0234	1.4716	.5685	1.2209	1.0921
4			2.0653	1.6146	.314	1.3405	1.4632
5			2.1749	1.7398		1.7086	1.6217
6			2.2237	1.8358		1.7841	1.9511
7			2.2794	2.1174	1.326	.1898	2.0568
8			2.3198	2.2459	2.0987		2.0607
9			2.332	2.2504	2.1772		2.194
10			2.335	2.191	2.2108		.7948
11			.8467	.775	.804		
12						.852	
13		1.2136				.5258	
14		1.1869					
15	1.406	1.5261					
16	1.5729	1.5432					
17	1.5729						
18	1.5729	1.5432					
23				.124			
Max	1.5729	1.5432	2.335	2.2504	2.2108	1.7841	2.194
Min	1.406	1.1869	.8467	.124	.314	.1898	.7948
Avg	1.5312	1.4026	2.0318	1.5830	1.3491	1.0888	1.6543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 202 / 11 KV MATASAB GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.2987	.3292	.2926	.2629	.2987	.2957
2	.3506	.2987	.2896	.3292	.3734	.2987	.2987
3	.3734	.2987	.2713	.3658	.4287	.2987	.2957
4	.4525	.3734	.3506	.5544	.5258	.3292	.3429
5	.724	.4854	.4755	.7392	.7011	.4481	.5544
6	.8402	.7468	.724	.7468	.7011	.7095	.7095
7	.8145	.8215	.724	.7468	.7468	.7095	.7468
8	.724	.7468		.6535	.6783	.5144	.6535
9		.5601	.5258	.462	.4938	.3429	.3963
10	.3772	.4481	.543	.4287	.4031	.2957	.3734
11	.3114	.362	.3258	.2804	.3361	.2957	.362
12			.2686				
13			.2865				
14			.2686				
15	.346	.2629	.2686	.3077	.3361	.3109	.3658
16	.3806	.3429	.362	.3506	.439	.4066	.4572
17	.4854	.4557	.3982	.3856	.4755	.4481	.5487
18	.5601	.4801	.462	.4382	.5487	.4534	.6335
19	.7095	.6135	.6468	.6661	.6722	.6099	.724
20	.5601	.5487	.5487	.4908		.4066	.6335
21	.4481	.3506	.4525	.4382	.4481	.3772	.543
22	.3734	.3506	.4024	.3506	.3734	.3326	.4525
23	.3361	.3361	.3658		.3361	.3142	.3696
24	.3582	.3361	.2629	.3658	.3506	.5175	.2439
Max	.8402	.8215	.724	.7468	.7468	.7095	.7468
Min	.3114	.2629	.2629	.2804	.2629	.2957	.2439
Avg	.4938	.4532	.4153	.4697	.4815	.4151	.4762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 203 / 11 KV MUGHAT RLY STN
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848		.0549	.0914	.0876	.0857	.081
2	.0886		.0362	.0914	.0876	.0857	.0762
3	1.6289		.0543	.0914	.0876	.0857	.0762
4	1.6956		.0509	.0924	.0876	.0857	.0762
5	1.7147		.0486	.0924	.0701	.0857	.0772
6	1.829		.0543	.0934	.0526	.0857	.0781
7	1.8099		.0543				
8	1.8099						
9	1.7528						
10	1.7528						.6882
11			1.0288	1.1145	1.3169		1.8472
12			2.5354	2.4851	2.9401	1.6177	2.896
13			2.6391	2.6223	2.7725	2.5857	2.822
14			2.5933	2.6519	2.7892	2.5057	2.7157
15		1.1488	2.5453	2.5149	2.662	2.6433	2.8285
16		1.1393	2.5572	2.5392	2.5301	1.3039	1.9104
17		1.1393	2.6426	2.5789	2.5339		2.0519
18		1.1393	2.544	2.4127	2.6711	1.2506	1.5585
19		1.1568	1.3193	1.4687	1.4262	1.4407	.16
20		1.1694	.5235	.0876		.0015	.0914
21		1.1888	.0905	.0905	.0857	.0762	.0914
22		1.1393	.0914	.0876	.0857	.0762	.0914
23		.0905	.0914	.0876	.0857	.0762	.0924
24	.0905			.0914	.0857	.0762	.0762
Max	1.829	1.1888	2.6426	2.6519	2.9401	2.6433	2.896
Min	.0848	.0905	.0362	.0876	.0526	.0015	.0762
Avg	1.2961	1.0346	1.0778	1.0693	1.1820	.7871	.9708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174083 / 33 kV NEELA

Feeder No / Name : 201 / 11 KV NEELA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0349	1.2197	1.1827		1.1827	1.2567	1.1827
2	1.0349	1.2197	1.1827	1.0719	1.2197	1.2936	1.2567
3	1.0719	1.2936	1.2567	1.1088	1.2567	1.3676	1.2936
4	1.2437	1.4045	1.3306	1.2567	1.386	1.4784	1.386
5	1.7002	1.7372	1.5524	1.7002	1.8296	1.6632	1.8111
6			1.3676				
7			1.2936				
8			1.1827				
9			1.1088				
10	1.3306	1.2936	.9979	1.2936	1.2197		
11	1.1827	1.1827	.961	1.1088	1.1827	.924	1.4415
12	.9979	.9979	.961	1.0719	1.1458	.961	1.2567
13	.924	.924	.8501	1.0349	1.1088	.924	1.1827
14		.924	.9979	.961	1.0719	.924	
15	1.1088	.8871	1.0349	1.1088	1.0719	1.0164	1.1458
16	1.1458	.961	1.1088	1.1273	1.1827	1.1088	1.2197
17	1.1827	1.1088	1.2567	1.1643	1.2197	1.2012	1.2567
18	1.2936	1.3676	1.4045	1.386	1.4784	1.3676	1.2567
19	1.5154	1.5524	1.5524	1.6632	1.6632	1.7556	1.5893
20	1.4045	1.4784	1.5154	1.6263	1.5893	1.6263	1.5893
21	1.2936	1.3676	1.4784	1.4784	1.4784	1.386	1.4415
22	1.2197	1.2936	1.4045	1.2936	1.2936	1.2936	1.3306
23	1.1827	1.2197	1.3306	1.2567	1.2197	1.2197	1.2567
24	1.0719	1.1827	1.1827	1.1827	1.1827	1.2197	1.1827
Max	1.7002	1.7372	1.5524	1.7002	1.8296	1.7556	1.8111
Min	.924	.8871	.8501	.961	1.0719	.924	1.1458
Avg	1.2073	1.2308	1.2289	1.2576	1.2992	1.2625	1.3378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174083 / 33 kV NEELA

Feeder No / Name : 203 / 11 KV NEELA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0431	.7537	1.2125	1.4815	1.5752	1.5043	1.4632
2	1.0431	.9831	1.278	1.4815	1.709	1.7284	1.6156
3	1.0715	1.2452	1.5729	1.5779	1.8576	1.7284	1.6156
4	1.1145	1.3108	1.7368	1.6872	2.0062	1.9845	1.7966
5	1.1873	1.4091	1.8023	1.9292	2.0953	1.0288	1.8903
6	1.6918	1.4746	1.9662	2.0873	2.0805	1.9662	1.8747
7		1.4746	1.9989	2.0622	2.2405	2.0805	1.5623
8	1.9662		2.0153	1.5699	1.7071	2.1605	
9			1.9662	1.7223	1.7375	2.1605	
11	2.2611	2.0972	1.6613	1.6309	1.6404	1.5708	1.3998
12	2.2283	2.2119	1.821	1.6156	1.8747	1.6324	1.3496
13	2.2939	2.0972	1.768	1.5432	1.7604	1.5181	1.2308
14	2.0317	2.0645	1.6406	1.2654	1.7604	1.439	
15	2.0317	2.0645	1.6105	1.4661	1.7284	1.4373	1.379
16	2.1628	2.0972	1.6406		1.6644		1.6248
17	2.13	2.13	1.382		1.6004		1.4718
18	2.0809	1.9989	1.419	1.7966	1.5364	1.7438	1.4575
19						1.4198	
20			.2614	.2801		.2801	.3109
21			.2614	.2801		.2987	.3109
22			.2614	.2801		.2987	.2926
23	.1848	.1638	.2614	.2801	.2772	.2614	.2743
24	1.0153	.663	1.0159	1.3696	1.5009	1.278	1.3108
Max	2.2939	2.2119	2.0153	2.0873	2.2405	2.1605	1.8903
Min	.1848	.1638	.2614	.2801	.2772	.2614	.2743
Avg	1.6199	1.5435	1.3888	1.3703	1.7028	1.4057	1.2753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 201 / 11 KV KANDHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6651	1.4737	1.7147	1.7147	1.8099	1.491	1.7147
2	1.5604	1.3717	1.7147	1.5242	1.7194	1.4899	1.5432
3	1.5775	1.387	1.5242	1.5242	1.5384	1.491	1.6289
4	1.5775	1.3003	1.5242	1.6004	1.5384	1.491	1.5432
5	1.5432	1.4022	1.7147	1.7147	1.5384	1.4575	1.5432
6	1.5604	1.406	1.829	1.829	1.6289	1.4746	1.5775
7		1.6632	1.9052	1.9052	1.6289	1.5604	1.7147
8	1.6644	1.6289		2.0957	1.8099	1.869	1.8861
9	1.6827	1.829		2.0957	1.6289		1.9004
10	1.6651	1.829	2.0957	1.97	1.5432		1.8099
11	1.5604	1.8671	2.0957	1.9004	1.4899	1.5604	1.8099
12	1.5432	2.2862	2.0957	1.8099	1.4899	1.8204	
13	1.6461		1.9052	1.8099	1.7528	1.893	.1719
14	1.6289	2.0957	1.9052	1.7013	1.8004	1.893	1.7194
15	1.7528	2.0957	2.0957		1.8861	1.893	1.6289
16		2.0957	2.0957	1.6289	1.8861		1.6289
17	1.7177	2.0957	2.0957	1.6289	1.9204		1.7909
18	1.9204	2.2862	2.0957	1.7909	1.9204	2.0157	1.8099
19	1.9204	2.2862		1.9004	1.8861	2.0285	1.8804
20	1.8004	2.4768	2.4768	1.9909	1.8861	2.0062	1.9909
21	1.8004	2.4768	2.4768	1.9909	1.8861	2.0157	1.9909
22	1.8229	2.2862	2.0957	1.9004	1.8861	1.9938	1.9909
23	1.6827	2.0957		1.9004	1.6289	1.9719	1.8099
24	1.7528	1.6289	1.9052	1.7909	1.8099	1.5432	1.8861
Max	1.9204	2.4768	2.4768	2.0957	1.9204	2.0285	1.9909
Min	1.5432	1.3003	1.5242	1.5242	1.4899	1.4575	.1719
Avg	1.6839	1.8854	1.9681	1.8138	1.7297	1.7480	1.6944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 202 / 11 KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4715	1.5729	1.4632	1.7194	1.5432	1.3717
2	.5658	.5658	1.4632	1.4632	1.8099	1.3717	1.3717
3	.3772	.4668	1.4632	1.4632	1.8099	1.7147	1.2003
4		.4668	1.6461	1.6827	1.9004		1.2003
5		.4715	1.9022	1.922	1.9909		1.286
6	.6602	.5658	2.0538	2.2405	2.3529		1.286
7	.5658	.6535	1.5729	.5144	.543		.5658
8	.5658	.6602	.5144	.5144	.543		.5658
9	.5658	.3429		.5144	.5658	.1715	.5373
10	.5658	.3429	.5144	.4525	.5601	.1886	.543
11	.4715	.3429	.5144	.4525	.3734	.2829	.543
12		.3429	.4115	.4525	.4668	.2829	
13	.4715	.1715	.3429	.4525	.3734	.2829	.543
14	.4715	.1715	.3429	.4525	.3734	1.0288	.543
15	1.7147	1.6461	.1715		.5658	.8573	.4525
16	1.8861	1.8671	.1715	.362	.4715	.5658	.362
17	2.0576	1.848	.1715	.362	.5658	.5658	.362
18	1.7147	2.0538	.2743	.362	.5658	.5658	.362
19	1.7147	2.0538	.3429	.362	.5658	.5658	.543
20	1.7318	1.8671	.5144	.362	.5658	.4715	.543
21	1.6804	1.8671	.5144	.4525	.4715	.4715	.543
22	1.6804	1.6804	.5144	1.1765	.4715	.4715	.543
23	.5658	1.6804			1.2003	1.286	1.267
24	.5658	.5658	1.6804	1.6632	1.5384	1.3717	1.286
Max	2.0576	2.0538	2.0538	2.2405	2.3529	1.7147	1.3717
Min	.3772	.1715	.1715	.362	.3734	.1715	.362
Avg	1.0076	.9653	.8486	.8701	.9319	.7400	.7748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 203 / 11 KV PANBHOSI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.387	1.286	.1715	.1715	.2715	.2829	.2829
2	1.3717	1.3717	.1715	.1715	.181	.2829	.2829
3	1.3717	1.3717	.1715	.1715	.181	.1886	.2829
4	1.286	1.3717	.2743	.2058	.181	.1886	.2829
5	1.2003	1.3717	.3429	.2401	.2715	.3772	.2829
6	.3772	1.286	.3429	.2743	.2715	.3734	.3772
7	.2829	.3734	.1715	1.4632	1.3575	1.5432	
8	.2829	.3734	2.0119	1.5364	1.448	1.4575	1.5432
9	.2829	.1715		1.6461	1.1145	1.5432	1.8099
10	.2829	.1715	1.8671	1.8099	1.0288	1.5432	1.8099
11	.1886	.1715	2.0538	1.8099	.8573	1.5432	1.8099
12		.1715	2.2405	1.9004	.9431	1.3717	
13	.1886	.1715	2.2405	1.6289	1.0288	1.1145	1.7194
14	.1886	.1715	2.2405	1.5384	1.0288	1.0288	1.8099
15	.1886	.1715	.1715		.1886	.2829	.362
16	.1886	.1715	.1715	.362	.2829		.362
17	.1886	.1715	.1715	.362	.1886		.2715
18	.1886	.2058	.1715		.2829		.2715
19	.2829	.2743	.2743		.3772	.2572	.2715
20	.1886	.3429	.3429	.4525	.3772	.2829	.362
21	.1886	.3429	.3429	.362	.3772	.1886	.362
22	.1886	.3429	.3429	.362	.2829	.1886	.362
23	1.3717	.3429		.2715	.3772	.2572	
24	1.2003	1.4575	.3429	.1715	.2715	.3772	.1886
Max	1.387	1.4575	2.2405	1.9004	1.448	1.5432	1.8099
Min	.1886	.1715	.1715	.1715	.181	.1886	.1886
Avg	.5594	.5691	.7560	.8053	.5488	.6987	.7194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 204 / 11 KV KURULA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2801	.1715	.1715	.2715	.2829	.1886
2	.1886	.2829	.1715	.1715	.362	.2829	.2263
3	.1886	.2829	.1715	.1715	.362	.1886	.1886
4	.1886	.1867	.2743	.2058	.362	.1867	.1886
5	.2829	.1886	.3429	.2058	.4525	.1867	.2829
6	.2829	.2829	.3429	.2743	.4525	.2801	.2829
7	1.7147	1.4575	.3429	.3429	.4525	.3734	.3772
8	1.6289	1.5432		.3429		.3734	.3772
9	1.6289	1.8671		.3429	.3772	.3734	.362
10	1.6289	1.8671	.2743	.362	.3772	.2829	.362
11	1.5432	2.0538	.1715	.362	.3772	.2829	.362
12	1.4575	2.2405	.1715	.362	.3772	.2829	
13	1.4146	2.2405	.1715	.362	.4668	.1886	.362
14	1.286	2.2405	.1715	.362	.4668	.1886	.362
15		2.2405	1.8671		1.6804	1.3717	1.3575
16		.1715	1.8671	1.8099	1.7147	1.5432	1.5384
17	.1886	.1715	2.0538	1.8099	1.7147	1.5432	1.6289
18	.2829	.1715	2.2405	1.9909	1.7147	1.4575	1.8099
19	.2829	.1715	2.2405	2.1719	1.8861	1.5432	1.6289
20	.2829	.2743	2.2405	2.1719	1.8004	1.5432	1.448
21	.3772	.3429	2.2405	1.9909	1.8861	1.4575	1.448
22	.2829	.3429	2.0538	1.97	1.8861	1.4575	1.3575
23	.2829	.3429		1.9909	.3772	.1886	.362
24	.3772	.2829	.3429	.1715	.362	.3772	.1886
Max	1.7147	2.2405	2.2405	2.1719	1.8861	1.5432	1.8099
Min	.1886	.1715	.1715	.1715	.2715	.1867	.1886
Avg	.7307	.8969	.9488	.8746	.8774	.6765	.7257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174033 / 33 KV BARUL

Feeder No / Name : 201 / 11 KV BARUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAY-17
HR	Load (MW)
1	.381
23	.7621
Max	.7621
Min	.381
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174033 / 33 KV BARUL

Feeder No / Name : 202 / 11 KV PETHWADAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	1.0269	.7842	.8573	1.5623	
2	.0953	.0953	1.2323	.8962	.9145	1.3336	.9709
3	.0953	.0953	1.3443	.9709	.9907	1.2955	1.0269
4	.1143	.1143	1.3817	1.0456	1.0479	1.2955	1.1203
5	.1334	.132	1.531		1.1431	1.2955	1.2136
6	.1715	.1509	1.587	1.3443	1.4712	1.2955	1.251
7	.1509	.1509	1.4563	1.531	1.6221	1.4335	1.531
8	.1509	.1494	1.419	1.531	1.6804	1.531	1.531
9	.132	.1307	1.4377	1.5684	1.5684		1.475
10	.1132	.112	1.4563	1.5684	1.4937	1.531	.1307
11	1.2449	1.2136	1.3443	.0934	.0934	.0747	.0747
12	1.531	1.587	.0747	.0747	.0934	.056	.0747
13	1.5684		.0747	.0747	.0934	.0747	.0934
14	1.6057	1.7177	.0747	.0747	.0747	.0747	.112
15	1.587	1.6244	.0747	.0747	.0747	.0747	.112
16	1.5684	1.587	.0747	.0747	.0934	.0747	.112
17	1.587	1.6244	.0934	.0747	.0934	.0934	.0747
18	1.4003	.1307	.112	.0934	.112	.0934	.0934
19	.1494	.1307	.1494	.132	.1307	.1307	.1307
20	.168	.1494	.1867	.1698	.1867	.1886	.168
21	.1494	.168	.1307	.1509		.132	.1867
22	.132	.1494	.1307	.132	.112	.1132	.168
23	.1132	.1307	.112	.1143	.1132	.1132	.1307
24	.1143	.112	.112		.0112	.1143	.1307
Max	1.6057	1.7177	1.587	1.5684	1.6804	1.5623	1.531
Min	.0953	.0953	.0747	.0747	.0112	.056	.0747
Avg	.5913	.5030	.6924	.5715	.6118	.6079	.5179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174033 / 33 KV BARUL

Feeder No / Name : 203 / 11 KV KAWTHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-APR-17	01-MAY-17
HR	Load (MW)	Load (MW)
12	.7621	
23		.7621
Max	.7621	.7621
Min	.7621	.7621
Avg	.7621	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 201 / 11 KV KURULA AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.7545					
2	1.9997	.7545					
3	2.0942	.7545					
4	2.1277	.8383					
5	2.2252	.9221					
6	2.4814	1.0059					
7	2.6901	1.1065					
8	2.4852	1.2407					
9	2.495	1.2407					
10	2.4814	1.073					.8951
11	1.2498		.78		.9724	.9389	1.0513
12			2.3384	2.3563	1.8442	1.0059	2.2945
13			2.4164	1.2193	1.9753	2.0759	2.2786
14			1.3108	1.3413	1.6888	1.9235	2.2177
15			1.4022	1.3413	2.5118	2.4112	2.2344
16			2.492	1.3717	1.4022	2.4584	2.4775
17			1.1888	1.3413	2.5423	2.4417	2.4605
18			1.4022	2.5758	2.3533	2.3198	1.1584
19			1.3413	1.3717	1.2193	1.2193	
Max	2.6901	1.2407	2.492	2.5758	2.5423	2.4584	2.4775
Min	.8383	.7545	.78	1.2193	.9724	.9389	.8951
Avg	2.1062	.9691	1.6302	1.6148	1.8344	1.8661	1.8964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 202 / 11 KV KURULA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6908	.6348	.2987			.2614	.7468
2	.6908	.6348	.2987			.2614	.6722
3	.6908	.6348	.3361			.2614	.6722
4	.7842	.7095	.3734			.2987	.7842
5	.9335	.8402	.3734			.3361	.9335
6	1.0642	.9335	.4108			.4481	1.0642
7	.9335	1.0349	.4066			.5228	
8	1.1458	1.0164	.4108	1.0829		1.0456	
9	1.1157	.9511	.3361			1.1576	1.2323
10	.8686	.6584	.2686			1.0829	.9877
11	.7499	.7602	.7947		1.0829	.8215	.7964
12	.7023	.6584	.8779	.7095	1.1949		.8145
13		.7316	.7602		1.1203	.6984	
14		.7602				.6805	
15		.7316					
16	.8048	.6099	.7468	.8589	.8215	.6626	.8326
17	.7964	.7602			.8589	.7701	.9145
18	.7392	.6722			.8589	.8048	.9313
19	1.0903					1.0903	1.1458
20	.7468				1.2323	1.1763	1.0082
21	.6908				1.0082	.9795	.924
22	.6348				.8215	.8501	.8596
23	.6348					.7762	.7947
24	.6908	.6348	.7095	.7095	.7095	.2987	.7392
Max	1.1458	1.0349	.8779	1.0829	1.2323	1.1763	1.2323
Min	.6348	.6099	.2686	.7095	.7095	.2614	.6722
Avg	.8190	.7562	.4935	.8402	.9709	.6948	.8870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 203 / 11 KV DIGRAS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8192			.6706	
2			.9012			.6706	
3			.9831			.7377	.8288
4			1.1469			.8048	.9116
5			1.3108			.9724	.9945
6			1.4586			1.1401	1.2597
7			1.6057			1.5424	1.2944
8			1.5074	1.6057	1.4419	1.5089	1.6078
9			1.5074			1.4419	1.5581
10			1.4575			1.4419	
11	.5801	1.0526					
12	.7209	1.6057					
13	.7209	1.6057					
14	1.442						
15	1.3077	1.5565					
16	1.2574	1.3077					
17	1.2071	.9339					
18	1.291	1.0526					
Max	1.442	1.6057	1.6057	1.6057	1.4419	1.5424	1.6078
Min	.5801	.9339	.8192	1.6057	1.4419	.6706	.8288
Avg	1.0659	1.3021	1.2698	1.6057	1.4419	1.0931	1.2078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 201 / 11 KV JANGAMWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0898	1.1191	.1848	.2401	.2401	.2402	.2012
2	1.2548	1.2209	.1867	.2401	.2454	.2507	.2126
3	1.3565	1.3717	.1715	.2427	.2279	.2254	.2454
4	1.4746	1.4403	.1543	.2601	.2279	.2454	.2629
5	1.6289	1.6297	.1715	.2629	.2454	.2543	.2279
6	1.8378	1.8519	.208	.2629	.2658	.2347	.208
7	1.8898	1.286	.2658	.2835	.2658	.2155	.2204
8	1.9204	2.0062	.2804	.2629	.2454	.2601	.2507
9	1.989	1.9281	.2279	.2427	.2401	.2103	
10	1.8991	1.5927	.2254	.1886	.2204	.1753	
11	.1907	.1715	1.9784	1.6766	2.0119	1.4251	.663
12	.1715	.1715	2.1195	1.989		1.7604	.9945
13	.1886	.1715	2.0119	1.8233	2.2634	1.6575	
14	.1865	.1526	1.8778	1.7404	1.989	1.5746	1.8233
15	.1865	.1696	1.8442	1.4251	.2012	1.6766	1.9062
16	.1715	.1715	1.8313	1.6766	1.9662	1.7804	1.9062
17	.1886	.1886	2.0687	1.6766	1.8442	1.8652	2.0719
18	.2058	.2058	2.0454	1.7404	1.9062	1.7528	.1848
19	.3142	.2987	.2987	.3174	.3326	.2835	
20	.3326	.3174	.3584	.3361	.3174	.3224	
21	.2926	.3086	.3174	.3361	.2957	.3142	.3361
22	.2772	.3395	.2829	.3142	.2801	.3326	.2987
23	.2587	.3018	.2829	.2829		.3109	.2801
24	.2378	.2402	.2801	.2614	.2614	.2587	
Max	1.989	2.0062	2.1195	1.989	2.2634	1.8652	2.0719
Min	.1715	.1526	.1543	.1886	.2012	.1753	.1848
Avg	.8143	.7773	.8197	.7534	.7315	.7345	.6830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 202 / 11 KV HARBAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.2543	1.0164	.9602	.9431	1.0745	.3292
2	.2543	.2713	1.1203	.9945	1.0517	1.0288	.2835
3	.2543	.2743	1.2003	1.1443	1.2269	1.3003	.964
4	.2743	.2915	1.3717	1.283	1.2269	1.3146	1.1393
5	.2743	.2947	1.6804	1.4022	1.3146	1.4413	1.4175
6	.2947	.3086	1.8204	1.4723	1.3289	.2515	1.387
7	.3121	.1715	1.0631	1.701	1.5061	.2984	1.6651
8	.2743	.12	1.4022	1.7177	1.5424	.3814	.985
9	.2572	.0838	1.3146	1.6644	1.5432	.8764	1.56
10	.2204	.0671	1.2483	1.2003	1.5261	1.1919	.218
11	1.3523	.1029	.1844	.2012	.2012	.1844	.1989
12	1.3717	1.5432	.1696	.1823		.2012	.2155
13	1.4746	1.6289	.1677	.116	.2012	.1658	
14	1.4413	1.6278	.1677	.116	.2155	.1823	.1989
15	1.3565	1.6108	.1844	.1174	.2012		.1823
16	1.2003	1.6289	.1865	.1341	.1638		.1823
17	1.3717	1.6289	.1526	.1844	.1677	.2204	.1989
18	1.5089	1.5432	.2012	.1823	.1989	.2454	.2402
19	.3696	.3174	.3174	.3361	.3326	.3012	
20	.4066	.3734	.3961	.4294	.4108	.394	
21	.3475	.4108	.3734	.4294	.4251	.4251	.4108
22	.3326	.3772	.3395	.4108	.3734	.4066	
23	.2957		.3206	.3772		.3658	.3734
24	.2926	.2957	.2801	.2987	.2801	.2957	
Max	1.5089	1.6289	1.8204	1.7177	1.5432	1.4413	1.6651
Min	.2204	.0671	.1526	.116	.1638	.1658	.1823
Avg	.6579	.6620	.6950	.7106	.7446	.5703	.6395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 203 / 11 KV PANSHEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.1017	.2772	.3772	.3429	.4477	.128
2	.1017	.1017	.3361	.4801	.3856	.3772	.1417
3	.1017	.1029	.3429	.5201	.4382	.6068	.3506
4	.1029	.12	.4287	.5548	.5258	.6135	.4382
5	.12	.1214	.4801	.6135	.5258	.6783	.443
6	.1214	.1372	.6068	.6661	.7087	.1174	.5201
7	.1387	.1372	.5316	.7973	.7087	.1326	.5784
8	.1372	.1372	.631	.7011	.6661	.1387	.3582
9	.12	.1341	.4908	.6415	.6001	.298	.5087
10	.1017	.5868	.5375	.4287	.5596	.333	.0838
11		.6001	.0838	.0838	.0838	.0838	.0838
12	.583	.703	.0848	.0829		.0671	.0829
13	.6516	.6859	.0838	.0829	.0671	.0663	
14	.6443	.6443	.0838	.0829	.0663	.0829	.0829
15	.6104	.5935	.0838	.0838	.0838		.0829
16	.6001	.6001	.0848	.0838	.0819		.0332
17	.6516	.6001	.1017	.1006	.0838	.1187	.0829
18	.7373	.6001	.1006	.0995	.0995	.1402	.0924
19	.1663	.1307	.1307	.1494	.1478	.1417	
20	.1478	.1494	.1509	.1494	.1494	.1254	
21	.128	.1494	.1494	.1494	.1294	.1294	.1494
22	.1294	.132	.132	.1307	.1307	.1294	.132
23	.1109	.132	.132	.1132		.1097	
24	.1097	.1109	.112	.112	.112	.1294	
Max	.7373	.703	.631	.7973	.7087	.6783	.5784
Min	.1006	.1017	.0838	.0829	.0663	.0663	.0332
Avg	.2790	.3130	.2574	.3035	.3044	.2303	.2302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174085 / 33 KV PETHWADAJ

Feeder No / Name : 201 / 11 KV PETHWADAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.226	.9335	.9145	1.0374	.9145	.7545	.924
2	1.3717	1.0269	.9145	1.0374	.9145	.7468	.9145
3	1.5546	1.0269	.9145	1.0374	.8145	.7468	.924
4	1.5546	1.1203	1.0059	1.0374	.8145	.8402	.8316
5	1.6461	1.1203	1.0059	1.1317	.9145	.8402	.8316
6	1.7375	1.3717	1.0059	1.1576	.9145	.9335	.9145
7	1.7375	1.4632	1.0059	1.0164	.905	.9145	.9145
8	1.7375	1.5546	.9145	.7316	.823	.9145	.8316
9	1.6461	1.6461	.924	.9145	.7316	.823	.9145
10	1.4632	1.5546	1.0164	.8145	.7316	.7316	1.0059
11	.6401	.7316	1.6461	1.3717		1.3717	1.3717
12	.7316	.7316	1.9204	1.4632	1.2803	1.5708	1.3717
13	.7316	.7316	1.829	1.448	1.6461	1.5546	
14	.7316	.7316	1.829	1.3575	1.5546	1.4632	1.4632
15	.6401	.7316	1.6461	1.3717	1.5546	1.3717	1.4632
16	.6401	.7316	1.4632	1.4632	1.5546	1.4784	1.5546
17	.6401	.7316	1.5708	1.5546	1.6461	1.587	1.5546
18	.7316	1.0059	1.5708	1.386	1.7375	1.5546	.823
19	.9431	1.1317	1.1203	1.1203	1.5546	1.2136	
20	1.1317	1.226	1.3203	1.2136	1.226	1.307	
21	1.1317	1.226	1.2826	1.2136	1.226	1.2136	1.226
22	1.1317	1.1317		1.0269	1.226	1.1203	1.226
23	1.1317	1.1317		1.0164	.7545	1.0269	1.1317
24	1.0374	1.0374	1.0374	1.1317	.924	.7545	1.0269
Max	1.7375	1.6461	1.9204	1.5546	1.7375	1.587	1.5546
Min	.6401	.7316	.9145	.7316	.7316	.7316	.823
Avg	1.1529	1.0762	1.2663	1.1689	1.1462	1.1181	1.1057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174085 / 33 KV PETHWADAJ

Feeder No / Name : 202 / 11 KV WARWANT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.8402	1.0059	1.0374	1.0059	1.0374	.7468
2	.823	.8402	1.0974	1.1317	1.0974	1.2136	1.0059
3	.823	.8402	1.1888	1.1317	1.086	1.2136	1.1088
4	.823	.8402	1.1888		1.267	1.4003	1.2936
5	1.0059	.8402	1.2803	1.4146	1.3717	1.4937	1.386
6	1.0059	.9145	1.2803	1.6032	1.4632	1.587	1.4632
7	1.0059	.9145	1.5546	1.6632	1.6289	1.6461	1.5546
8	.9145	.823	1.6461	1.7375	1.829	1.6461	1.6632
9	.9145	.823	1.6632	1.7375	1.6461	1.6461	1.5546
10	.823	.823	1.4784	1.6289	1.6461	1.4632	.5487
11	1.1888	1.4632	.5487	.6401		.5487	.5487
12	1.5546	1.6461	.5487	.6401	.5487	.5544	.5487
13	1.7375	1.6461	.5487	.6335	.5487	.5487	
14	1.7375	1.6461	.5487	.6335	.6401	.5487	.6401
15	1.7375	1.5546	.6401	.6401	.6401	.5487	.6401
16	1.6461	1.4632	.6401	.6401	.6401		.6401
17	1.6461	1.5546	.6468	.6401	.6401	.7468	.6401
18	1.6461	1.6461	.7392	.7392	.6401	.7316	.6401
19	.9431	1.1317	.9335	1.0269	.9145	1.0269	
20	1.0374	1.1317	1.1317	1.1203	1.1317	1.1203	
21	1.0374	1.1317	1.0374	1.0269	1.1317	1.1203	1.0374
22	1.0374	1.1317	1.0374	.9335	1.0374	1.0269	.9431
23	.9431	1.0374	1.0374	.8316	.9431	.9335	.9431
24	.8488	.8402	.9431	.9431	.7392	.9431	.8402
Max	1.7375	1.6461	1.6632	1.7375	1.829	1.6461	1.6632
Min	.823	.823	.5487	.6335	.5487	.5487	.5487
Avg	1.1554	1.1468	1.0152	1.0511	1.0538	1.0759	.9708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 201 / 11 KV BACHOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0448	1.0517	.8764	.8764	.9773	1.0745	1.0387
2	1.1319	1.1393	.9214	.9114	.9065	1.0387	.9671
3	1.1331	1.1393	.9214	.9114	.9065	1.0029	1.0029
4	1.1854	1.1919	.9465	.9465	.9773	1.0387	1.0387
5	1.1854	1.2269	1.0517	1.0517	1.046	1.0745	1.0631
6	1.5324	1.5424	1.0985	1.0867	1.0808	1.1283	1.1641
7	1.7433	1.7177	1.134	1.1568	1.1518	1.2178	1.2894
8	1.9524	1.7528	1.0867	1.0517	1.1157	1.2894	1.3253
9	1.893	1.7528	1.0867	1.0517	.7522	1.0745	.7164
10	1.8229	1.7528	1.1218	.9465	.8859	1.0029	.7619
11	.8954		1.4022	1.7084	1.5061	1.2403	1.5123
12	.9313	.9114	1.5775	1.6717	1.5947	1.3466	1.5475
13	.9313	.9465	1.6651	1.0448	1.3998	1.5238	1.5826
14		.9465	1.6827	1.4627	1.4706	1.5947	1.6196
15	.9671	1.0517	1.7528	1.4992	1.382	1.6301	1.7252
16	.9816	1.0517	1.7878	1.6038	1.1163	1.701	1.7604
17	1.086	1.0517	1.8229	1.7084	1.4883	1.7364	1.7956
18	1.1043	1.0517	1.8229	1.7433	1.7718	1.7718	.9858
19	1.0867	1.0867	1.0867	1.1506	1.2536	1.1104	1.2675
20	1.1218	1.1218	1.1218	1.3234	1.3611	1.3432	1.3027
21	1.1919	1.1919	1.1919	1.2203	1.2894	1.2894	1.2336
22	1.1919	1.1919	1.1919	1.1331	1.2536	1.2178	1.1631
23	1.1393	1.1393	1.1393	1.0808	1.1999	1.1641	1.0574
24	1.0808	1.0867	1.0867	1.0867	.9762	1.1104	1.0745
Max	1.9524	1.7528	1.8229	1.7433	1.7718	1.7718	1.7956
Min	.8954	.9114	.8764	.8764	.7522	1.0029	.7164
Avg	1.2319	1.2216	1.2741	1.2262	1.2026	1.2801	1.2498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 202 / 11 KV CHINCHOLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5921	.5959	.7011	.7011	.6632	.6733	.5731
2	.5746	.5784	.7362	.7362	.6973	.8859	.6379
3	.5927	.5959	.8063	.8063	.9588	.9745	.7973
4	.6101	.6135	.8764	.8764	1.0808	1.0631	.9922
5	.645	.6485	1.0517	1.0517	1.1331	1.1517	1.0808
6	.9065	.8764	1.262	1.1393	1.3074	1.2403	1.2403
7	.9065	.9114	1.3672	1.1919	1.4136	1.3466	1.3643
8	.8891	.8764	1.3672	1.2269	1.6212	1.4883	1.3112
9	.8063		1.3672	1.262	1.5947	1.4706	1.4706
10	.6485	.7712	1.3321	1.4022	1.4883	1.4529	.7164
11	1.1393	1.1393	.5258	.4881	.5731	.6089	.5275
12	1.2269	1.2269	.5258	.4353	.5373	.5373	.4924
13	1.262	1.262	.5609	.4353	.5194	.5014	.4572
14	1.262	1.2971	.5609	.4179	.5731	.4477	.4577
15	1.2971	1.2971	.5959	.4358	.5194	.4656	.4929
16	1.262	1.3146	.6135	.4532	.5014	.4835	.5281
17	1.262	1.3146	.6135	.4707	.5373	.5373	.5809
18	1.262	1.3146	1.3146	.6101	.5731	.5731	.6337
19	.8764	.8764	.8764	.7322	.8954	.788	.7922
20	.7011	.7011	.7011	.8707	.8417	.8238	.7746
21	.7011	.7011	.7011	.7845	.7164	.8238	.7049
22	.631	.631	.631	.6973	.6447	.7164	.6697
23	.6135	.5959	.5959	.5753	.6268	.6805	.6168
24	.6101	.6135	.5959	.5959	.5578	.591	.6089
Max	1.2971	1.3146	1.3672	1.4022	1.6212	1.4883	1.4706
Min	.5746	.5784	.5258	.4179	.5014	.4477	.4572
Avg	.8866	.9023	.8450	.7665	.8573	.8469	.7717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 203 / 11 KV BAMNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6617	.6661	.6661	.6661	.6981	.6241	.6485
2	.6269	.631	.7011	.7011	.6624	.6935	.5959
3	.6101	.5959	.7888	.7888	.6799	.7802	.7888
4	.6624	.6661	.8764	.8764	.6624	.8669	.9114
5	.6973	.7011	1.0166	.964	.6973	.9536	.9816
6	.8542	.7362	1.0867	1.1393	.9588	1.0056	1.0517
7	.8193	.7712	1.1393	1.2269	1.2565	1.0749	1.1393
8	.6624	.7712	1.1393	1.2269	1.4818	1.1616	1.2445
9	.7362	.6661	1.1568	1.2269	1.2309	1.0402	.7011
10	.6485	.5959	1.1568	1.2269	1.3003	.9536	.5083
11	1.2269	1.2269	.5258	.6101	.5201	.6935	.4748
12	1.2971	1.262	.5609	.5572	.5375	.6588	.4748
13	1.262	1.262	.5609	.5224	.4681	.5375	.4924
14	1.262	1.2795	.5959	.4528	.4854	.4681	.4924
15	1.2269	1.2795	.5959	.4532	.5375	.4854	.5281
16	1.1919	1.2971	.6135	.4881	.5201	.5201	.5633
17	1.1218	1.262	.631	.4881	.5721	.5375	.5633
18	1.1218	1.2269	.631	.645	.6415	.5375	.6513
19	.8764	.8764	.8764	.9065	.9189	.8495	.8274
20	.8063	.8063	.8063	.9403	.9015	.8669	.7922
21	.7712	.7712	.7712	.8716	.7802	.8149	.7578
22	.7362	.7362	.7362	.6973	.7108	.7455	.7225
23	.7011	.7011	.7011	.6624	.6935	.6935	.7049
24	.6973	.7011	.7011	.7011	.645	.6935	.6588
Max	1.2971	1.2971	1.1568	1.2269	1.4818	1.1616	1.2445
Min	.6101	.5959	.5258	.4528	.4681	.4681	.4748
Avg	.8866	.8954	.7931	.7933	.7734	.7607	.7198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174101 / 33 KV DIGRAS

Feeder No / Name : 201 / 11 KV DIGRAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3361	.3361	.3395	.3018	.3734
2	.3395	.3395	.2987	.3361	.3018	.2641	.3734
3	.3395	.3395	.3018	.3361	.3018	.2641	.3734
4	.3772	.3395	.3395	.3734	.3018	.2641	.4108
5	.415	.3772	.3772	.4481	.3395	.3772	.4481
6	.4527	.415	.4904	.4668	.4527	.4715	.5228
7	.5093	.4481	.4854	.5041	.4904	.4715	.5228
8	.4854	.4527	.4108	.5041	.4715	.4715	.4481
9	.4527	.415	.3772	.3921	.2987	.4338	.4294
10	.3772	.4108	.3961	.3734	.2801	.3734	.3734
11	.3395	.2987	.3174	.3174	.3361	.3361	.3361
12	.2987	.2987	.2801	.3174	.2987	.3142	.2801
13	.2614	.2957	.2957	.2987	.2987	.2743	
14	.2957	.2987	.2772	.2614	.2801	.2743	.2957
15	.2614	.2987	.2957	.2614	.2801	.2587	.2587
16	.2957	.3018	.3361	.2427		.3326	.2587
17	.2957	.2641	.2614	.2427	.3174	.3326	.2957
18	.3326	.3395	.3174	.2801	.3361	.3361	.2561
19	.5544	.5658	.4294	.3361	.4481	.4481	
20	.4805	.5544	.5975	.4481	.5601	.5975	
21	.4108	.5853	.4854	.4854	.4854	.5041	.5121
22	.3361	.4435	.4294	.4481	.4108	.4481	.4435
23		.3734	.3734	.4481		.3734	.4066
24	.3734	.3395	.3734	.3734	.3734	.3734	.3734
Max	.5544	.5853	.5975	.5041	.5601	.5975	.5228
Min	.2614	.2641	.2614	.2427	.2801	.2587	.2561
Avg	.3750	.3806	.3701	.3680	.3638	.3707	.3806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174101 / 33 KV DIGRAS

Feeder No / Name : 202 / 11 KV DIGRAS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6802	.9831	1.0159	.8097	
2			.7773	1.1142	1.0486	1.0364	.8907
3			.8421	1.2431	1.1469	1.0364	.9717
4			.9175	1.3592	1.278	1.0688	1.004
5			1.1142	1.4918	1.3108	1.085	1.1012
6			1.3108	1.6078	1.3435	1.1012	1.1336
7			1.2452	1.7238	1.5402	1.2955	1.247
8			1.3763	1.668	1.6057	1.3927	1.3763
9			1.4091	1.704	1.4746	1.3603	1.2289
10			1.4091	1.5223	1.3435	1.3603	
11	1.5402	1.4746					
12	1.7368	1.6057					
13	1.8351	1.6712					
14	1.7368	1.6575					
15	1.8896	1.6907					
16	1.8233	1.6575					
17	1.7814	1.6385					
18	1.4899	1.6057					
Max	1.8896	1.6907	1.4091	1.7238	1.6057	1.3927	1.3763
Min	1.4899	1.4746	.6802	.9831	1.0159	.8097	.8907
Avg	1.7291	1.6252	1.1082	1.4417	1.3108	1.1546	1.1192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 201 / SAWARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2829	1.1203	1.1203	1.0288	1.0288	1.1203
2	.3429	.2829	1.1203	1.1203	1.0288	1.0288	1.1203
3	.3429	.2801	1.1203	1.1203	1.2003	1.2003	1.1203
4	.3429	.2829	1.1203	1.1203	1.286	1.2003	1.1203
5	.3429	.3772	1.1203	1.307	1.3717	1.3717	1.1203
6	.3429	.3734	1.1203	1.307	1.3717	1.3717	1.307
7	.3429	.4715	1.1203	.4251	1.3717	1.5432	1.4937
8	.3429	.3772	1.1203	.4294	1.3717	1.3717	1.4937
9	.2915	.3734	.3734	.3734	.2572	.2915	.3734
10	.2915	.2858	.3734	.3734	.2572	.2915	.3734
11	.2915	.2829	.3734	.3429	.2915	.2801	.2801
12	.2915	.3772	.3734	.3429	.2915		.2801
13	.3174	.2829	.3734	.2915	.2915		
14	.2801	.2829	.3734	.2915	.2915		.2801
15	.2801	.2829	.3734	.2915	.2915		.1905
16	.2801	.3772	.3174	.2915	.2915		.2801
17	1.3203	1.6804	.3174	.2915	.2915		.2801
18	1.4003	1.6804	.3734	.3429	.2915		.3734
19	1.5089	1.4937	.3734	.3429	.3429		.4668
20	1.307	1.4937	.4294	.3429	.3429		.4668
21	1.1203	1.4937		.3429	.3429		.3734
22	1.1203	1.307	.3734	.3429	.3429		.3734
23	1.1317	1.307	.3734	.2915	.3429		.3734
24	1.0288	.2801		.3734	.2915	.2915	
Max	1.5089	1.6804	1.1203	1.307	1.3717	1.5432	1.4937
Min	.2801	.2801	.3174	.2915	.2572	.2801	.1905
Avg	.6252	.6671	.6425	.5508	.6201	.9393	.6664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 202 / SUNEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9335	1.1641	1.1903	.972	1.0856	1.0826
2	.8573	.9335	1.1397	1.8801	.9553	1.1168	1.0658
3	.9431	.9335	1.1313	1.1362	.9842	1.1138	1.0475
4	1.0288	.9335	1.1595	1.1561	1.0018	1.2041	1.0498
5	1.0288	1.1203	1.2567	1.2864	1.1146	1.278	1.1751
6	.9431	1.1203	1.5165	1.5951	1.3424	1.5516	1.4773
7	1.0288	1.0269	1.4133	1.1302	1.3348	1.5264	1.4674
8	1.0288	1.1203	1.1504	.9793	1.2472	1.424	.9145
9	.2572	.2801	2.1025	1.9996	1.8229	1.7436	1.9105
10	.1715	.2801	2.101	1.9768	1.8286	1.6579	.9137
11	.2572	.2801	2.1182	1.8587	1.8309	1.6655	.9274
12	.2572	.3734	1.9516	1.7954	1.6693	1.5546	.6081
13	.1867	.3734	1.9158	1.6312	1.5326	1.5279	.3307
14	.1867	.2801	1.3531	1.4823	1.3881	1.5234	.0732
15	.1867	.2801	1.6803	1.5196	1.4704	1.6823	1.0577
16	.2801	.1867	1.7863	1.7021	.8996	1.7284	.7201
17	.2801	.1867	.9217	.849	.9145	.5891	.3068
18	.2801	.1867	.988	.9995	.9839	.8672	.7854
19	.2801	.2801	1.2239	1.283	1.2871	1.23	1.3953
20	.3734	.2801	1.5958	1.5302	1.5485	1.5086	1.6659
21	.3734	.3174	1.1111	1.4041	1.3988	1.4666	1.6027
22	.3734	.3174	1.3218	1.3127	1.2662	1.3054	1.4152
23	.2801	.3174	1.2464	1.2475	1.2433	1.2559	1.249
24	.2801	.9335	1.2277	1.1183	1.2162	1.0795	1.1919
Max	1.0288	1.1203	2.1182	1.9996	1.8309	1.7436	1.9105
Min	.1715	.1867	.9217	.849	.8996	.5891	.0732
Avg	.5008	.5531	1.4407	1.4193	1.3022	1.3619	1.0597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 203 / KAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3734	.9602	.8947	.9251	.9495	.9175
2	.3429	.3734	.945	.8672	.8703	.9282	.8809
3	.3429	.3734	.9617	.8505	.8687	.9129	.852
4	.3429	.3734	.9632	.9308	.8825	.9053	.799
5	.3429	.4668	1.0436	.9217	.8657	.951	.8021
6	.3429	.4294	1.2372	1.1412	1.0669	1.0852	.9572
7	.3429	.3734	1.2326	1.1317	1.1004	1.1446	.9754
8	.3429	.3772	1.1381	1.0821	1.0212	1.7253	.7694
9	1.2003	1.307	.9892	1.0436	.8737	.8722	.7541
10	1.3717	1.5089	.9023	.8977	.8326	.8204	.5834
11	1.3717	1.587	.8413	.8032	.7381	.7373	.8185
12	.2915	1.5089	.8032	.8017	.732	.7008	.756
13	.3174	.2801	.7864	.7106	.7457	.7228	.3963
14	.3206	1.1203	.7335	.7183	.7457	.7986	.7145
15	1.1317	1.1203	.7289	.6969	.7625	.7069	.7834
16	1.3203	1.1203	.7167	.652	.7442	.4615	.7682
17	.2829	.3174	3.2267	2.6581	2.0454	1.8434	2.7595
18	.2801	.3174	3.6412	3.1573	2.1346	2.6551	2.9592
19	.3772	.3734	3.4164	3.2213	2.7541	2.7283	3.0849
20	.3734	.3734	2.7519	3.0354	2.4836	2.4539	2.7278
21	.3734	.3734	2.6254	2.7663	2.4074	1.9616	2.7176
22	.3772	.3734	2.678	2.5111	2.1155	1.8991	2.6719
23	.3734	.3734	2.6307	2.2161	2.0043	1.8122	2.3465
24	.3429	.3206	1.1004	2.175	1.8839	2.0652	1.7726
Max	1.3717	1.587	3.6412	3.2213	2.7541	2.7283	3.0849
Min	.2801	.2801	.7167	.652	.732	.4615	.3963
Avg	.5354	.6465	1.5439	1.4952	1.3168	1.3267	1.3987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 204 / LOHA URBAN SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.0538	4.7866	4.8491	3.94	3.8843	4.4787
2	1.8861	2.0538	4.7203	4.7775	3.911	3.8417	4.382
3	2.0576	2.0538	4.4399	4.7642	3.9822	3.9666	4.1419
4	2.2291	2.0538	4.5134	4.707	4.0649	4.116	4.1282
5	2.4006	2.2405	4.6877	4.8148	4.3172	4.4422	4.5923
6	2.4006	2.6139	4.9924	5.2389	4.8949	4.8126	5.1086
7	2.4863	2.8006	5.5857	5.5083	5.6744	4.9764	5.5258
8	2.572	2.6139	5.53	5.0362	5.8878	5.6516	5.6698
9	2.4863	2.9874	5.3658	5.5487	5.7412	5.3365	5.7312
10	2.4006	2.8006	5.4062	5.4973	5.62	5.1136	5.4458
11	2.2291	2.6139	5.5468	5.3171	5.6116	5.256	5.3658
12	2.2291	2.2405	5.6306	5.1898	5.4229	5.4107	5.3139
13	2.6139	2.2405	5.5819	5.0138	5.2123	5.3985	2.4943
14	2.6139	2.4272	5.3742	4.9863	5.1167	5.2103	5.2179
15	2.6139	2.4272	5.4775	5.1681	4.9177	5.2057	5.261
16	2.4272	2.894	5.5308	5.2527	4.7817	5.1501	5.5083
17	2.4272	2.894	5.6261	5.3167	4.8049	5.2659	5.5898
18	2.8006	2.8578	5.788	5.7191	5.4519	5.5052	5.615
19	2.9874	2.8006	6.062	6.0871	5.7994	5.8482	6.1256
20	2.8006	2.8006	6.1729	6.0204	5.4992	5.9343	6.1127
21	2.6139	2.7073	5.8288	5.5773	5.2607	5.3932	5.7769
22	2.4272	2.7073	5.4775	5.2991	1.9243	5.2538	5.6363
23	2.4272	2.5206	5.4409	4.9368	4.579	5.0792	5.3543
24	2.2291	2.2405	5.048	4.9181	4.2684	4.4116	5.0305
Max	2.9874	2.9874	6.1729	6.0871	5.8878	5.9343	6.1256
Min	1.8861	2.0538	4.4399	4.707	1.9243	3.8417	2.4943
Avg	2.4269	2.5268	5.3589	5.2310	4.8618	5.0193	5.1503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 201 / KALAMBAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168		.2096	.2054	.1886	.2286	.2054
2	.168		.2096	.2054	.1886	.2286	.2054
3	.3429		.2286	.1991	.1886	.2286	.2054
4	.4287		.2286	.2241	.2075	.2477	.2054
5	.5144		.2858	.2241	.2263	.2667	.2241
6	.5487		.3048	.2614	.2614	.2858	.2614
7	.823	.7842	.2667	.2987	.2614	.3048	.2801
8	.8916		.2667	.2614	.2587	.2667	.2614
9	.8916	.9979	.2286	.2241	.2286	.2477	
10	.8775	.6668	.1867	.2033	.2286	.2054	.2286
11	.168	.1905	.6859	.8316	.8573	.5487	.7621
12	.1509		.7716	.9335	.8573	.6173	.8002
13	.1509	.1905		.7922	.8383	.6173	.8002
14	.1494	.1715	.6859	.7655	.8002	.5487	.7621
15	.1494	.1715	.6859	.7655	.724		.8573
16		.1905	.6859	.7842	.724		.8573
17		.1905	.6859	.8402	.8002		
18		.2286	.5144	.8775	.8002		.5716
19		.2477	.2614	.2241	.2477		.2477
20		.2477	.2801	.2241	.2858	.5144	.2858
21		.2286	.2241	.2263	.2858	.2614	.2858
22	.2096	.2096	.2054	.2075	.2286	.2054	.2667
23	.1867	.1905	.2054	.2075	.2096	.2054	.2096
24	.1867	.1905	.1905	.2054	.1886	.2096	.2054
Max	.8916	.9979	.7716	.9335	.8573	.6173	.8573
Min	.1494	.1715	.1867	.1991	.1886	.2054	.2054
Avg	.3892	.3186	.3695	.4247	.4202	.3284	.4086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 202 / PANGRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307		.1143	.1307	.1143	.1334	.1307
2	.1307		.1143	.1307	.1143	.0953	.1307
3	.5487		.1143	.1307	.1132	.0953	.1307
4	.6859		.1334	.1307	.1307	.1143	.1307
5	.8573		.1524	.1307	.1307	.1143	.1307
6	1.0288		.1524	.1494	.1307	.1524	.1494
7	1.166	1.3443	.1524	.1494	.1109	.1524	.1494
8	1.2346	1.448	.1334	.1307	.1109	.1524	.1494
9	1.166	1.5051	.1334	.0924	.1143	.1334	
10	1.1949	1.2384	.1307	.0924	.1334	.0747	.1334
11	.112	.0953	1.0288	1.1088	1.2384	.4287	.9526
12	.0943		1.1145	1.2449	1.3336	.8573	1.1431
13	.0943	.1143	1.0974	1.1643	1.3336	.8573	1.2384
14	.0934	.1143	1.0288	1.1576	1.2384	.8573	1.2384
15	.0934	.1143	1.0288	1.1576	1.1431		1.2384
16			1.1145	1.1203	1.1431		1.2384
17		.1143	1.1145	1.307	1.4098		1.2574
18		.1334	1.166	1.3817	1.3717		1.2574
19		.1334	.1307	.1132	.1524		.1524
20		.1524	.1494	.132	.1715	.6001	.1715
21		.1524	.1494	.1509	.1715	.1307	.1715
22	.132	.1524	.1307	.132	.1524	.1307	.1524
23	.1334	.1334	.1307	.1132	.1334	.1307	.1334
24	.1307	.1334	.1334	.1307	.1143	.1334	.1307
Max	1.2346	1.5051	1.166	1.3817	1.4098	.8573	1.2574
Min	.0934	.0953	.1143	.0924	.1109	.0747	.1307
Avg	.5015	.4424	.4520	.4868	.5129	.2813	.5092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 203 / TELKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8897		1.0539	1.1092	1.246	1.2918	.9199
2	.8821		1.1896	1.1576	1.2988	1.4182	.8543
3	.8776		1.2269	1.2788	1.3904	1.3177	1.0193
4	.8745		1.4868	1.3637	1.4747	1.7391	1.1965
5	1.0628		1.6728	1.5394	1.7138	2.2908	1.6598
6	1.3211	.3326	2.3129	2.2542	.7468	2.9638	2.2359
7	1.3458	.2957	2.9103	2.162	2.1034	3.3783	2.4966
8	1.3386		1.8069	2.8334	3.2221	3.0536	2.9576
9	1.2518	.3048	.9434	3.0323	3.2998	3.1939	1.6034
10	1.0307	.2858	.7736	2.2958	3.3516	2.8418	3.0827
11	2.2485	1.2955	2.3102	1.4404	1.8366	1.6004	1.6026
12	1.0269		1.5158	.6717	.7849	.5327	.6356
13	.7182	1.3336	1.0684	.6286	.6836	.594	.4725
14	.7167	1.3336	.6295	.4969	.66	.5643	
15	2.4966	1.6194	.6066	.6055	.7331	.4412	
16	2.9767	1.6194	.7686	.74	.7377		
17	3.3437	1.7147	.799	.881	.8703		.5456
18	1.8	1.7147	1.1024	1.0826	1.0334		1.0288
19	1.7124	.3048	1.2612	1.2955	1.1835		1.2528
20	1.0128	.3429	1.3706	1.4022	1.39	1.2795	1.4075
21	.9648	.3239	1.2213	1.2325	1.2948	1.3717	1.3222
22	1.0417	.2858	1.0951	1.0608	1.1241	1.206	1.1096
23	.932	.2667	.9862	.9679	1.0235	1.0757	.9633
24	.9168	.2096	.9213	.913	.9328	1.0006	.9725
Max	3.3437	1.7147	2.9103	3.0323	3.3516	3.3783	3.0827
Min	.7167	.2096	.6066	.4969	.66	.4412	.4725
Avg	1.3659	.7990	1.2931	1.3519	1.4223	1.6578	1.3971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 204 / ALEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6638		.5289	.6585	.6584	.772	.719
2	.6547		.7255	.6486	.6409	.7369	.6954
3	1.1439		.708	.644	.6363	.7323	.6885
4	1.2978		.7179	.6618	.6583	.8184	.6862
5	1.5748		.7712	.7167	.6728	.8337	.7144
6	2.178		1.0143	1.0319	1.0078	.9739	1.0052
7	2.8524	1.4784	1.0997	1.0677	1.0256	1.0783	1.0585
8	2.7073		.9716	.9618	.956	.964	.9309
9	2.8463	1.4415	.8672	.8776	.8649	.8962	.695
10	2.8449	1.3336	.6897	.703	.7316	.6798	.567
11	1.3413	.1334	2.0386	2.2729	2.3343	1.723	2.6017
12	.5877		2.1273	2.633	2.5698	2.3856	2.9706
13	.5331	.1524	2.1041	2.4764	2.4645	2.0123	2.2694
14	.5496	.1715	1.8038	2.4047	2.4554	2.3376	2.1422
15	.4321	.1524	2.1536	2.3667	1.9791		2.7793
16	.559	.1524	2.1925	2.3898	2.1948		2.8319
17	.4588	.1524	2.3091	2.5442	2.2809		2.7542
18	.5197	.1715	2.5564	2.564	2.3106		2.8151
19	.6241	.2096	1.4468	.6798	1.2787		1.2948
20	.8177	.2286	1.1184	1.1023	1.1157	1.8777	.9526
21	.7263	.2286	.961	.9899	1.0173	.9816	.7666
22	.7788	.1905	.7655	.8158	.8513	.8814	.7323
23	.724	.1715	.6943	.7461	.8147	.7979	.6127
24	.703	.1715	.6996	.6745	.7529	.7629	.6234
Max	2.8524	1.4784	2.5564	2.633	2.5698	2.3856	2.9706
Min	.4321	.1334	.5289	.644	.6363	.6798	.567
Avg	1.1716	.4087	1.2944	1.3597	1.3447	1.1708	1.4128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 201 / KAPSI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6735	.759	1.8633	1.547	1.8	1.468	2.0157
2	1.6735	.759	1.8633	1.3946	1.8	1.3156	1.5585
3	1.6735	.759	1.8633	1.7741	1.8107	1.3314	1.5585
4	1.6735	.7907	1.9424	1.7741	1.8	1.3946	1.79
5	2.053	.8855	2.0214	2.1005	2.2054	1.7052	1.9481
6	1.1385	1.012	2.5577	2.2529	2.524	2.332	2.4901
7	2.5102	1.1385	2.8626		3.0682	3.0049	3.2579
8	2.3837	1.012	2.6311		2.5362	3.0682	3.5684
9	2.1048	.8855	2.3262		2.2572	2.9417	3.2579
10	1.5729		2.0157		1.8259	2.6944	3.0998
11	1.9006	1.1069	1.9006	.3795	.9145	1.3717	2.0302
12	2.9474	1.1069	2.2572	.759		.6325	1.2422
13	2.7893	1.4232	2.2572	.6325		1.1157	1.3946
14	2.6627	1.5813	1.8259	.6325	1.8748	1.1157	1.2681
15	2.5102	1.5813	1.6994	.6325	2.9417	1.2422	1.2422
16	1.3717	1.5813	1.7741		2.9417	1.3946	1.3946
17	1.5699	1.2651	2.4844		3.0682	1.5211	.7621
18	3.0998	1.2651	3.0682	1.3916	2.9417	1.7052	
19	2.7835	1.1069	2.6886	1.1523	2.6627	2.1738	
20	2.7893	1.1069	2.6627	1.2651	2.5102	2.6311	2.7835
21	2.5362	.9488	2.3837	.8855	2.3837	2.5521	2.6311
22	2.1681	.9488	2.1048	.8855	2.1048	2.1681	2.4786
23	1.9683	.9488	1.9524	.9014	1.8259	2.089	2.0948
24	1.9524	.759	2.0157	.8855	1.8259	1.8259	1.9366
Max	3.0998	1.5813	3.0682	2.2529	3.0682	3.0682	3.5684
Min	1.1385	.759	1.6994	.3795	.9145	.6325	.7621
Avg	2.1461	1.0753	2.2092	1.1803	2.2556	1.8664	2.0820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 202 / MARTALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6231	2.2405	3.6969	4.167	4.2607	2.5888	2.7237
2	2.6177	2.2405	3.9849	4.3127	4.3789	2.5811	2.6879
3	4.7363	2.2405	4.3865	4.7108	4.4292	2.5743	2.7659
4	4.8766	2.3899	4.6738	4.7613	4.4246	2.6734	2.8967
5	6.4221	2.5206	5.2354	5.4161	5.2904	3.0895	3.1607
6	7.29	2.9874	5.7841	6.4419	6.0837	1.7703	1.8069
7	6.925		6.1234	6.5158	6.448		
8	7.3479		5.9289	6.515	6.6103		
9	3.8066		3.6626	3.4644	3.7372	2.8266	3.0499
10	2.5819	2.6139	2.6254	2.7039	2.3967	2.5012	2.8776
11	2.5872	1.307	1.8679	2.2291	2.2024	2.095	2.207
12	2.4668	1.307	1.7528	2.0447	2.0363	1.8137	1.9906
13	1.9829	1.4003	.2538	2.0302		5.2179	5.945
14	.807	1.4003	2.0355	2.0256		5.7644	6.1676
15	2.1278	1.4003	2.2909	2.0462	2.377	5.9831	6.5836
16	2.3837	1.307	2.4447	2.1178	2.5629	5.3087	6.8854
17	2.4897	1.1203	2.745	2.4676	2.7831	6.6095	6.9883
18	2.7267		2.7633	2.7039	1.2582	6.7201	6.73
19	6.5798	2.9874	6.2338	5.9366	3.4301	6.6553	6.7193
20	6.4503	2.9874	6.4037	6.2788	5.6912	6.5273	6.5516
21	2.8258	1.6804	4.0055	3.924	4.1625	4.1137	4.5755
22	3.0612	1.4937	3.078	3.2564	3.1314	3.2274	3.2579
23	2.8319	1.307	2.966	2.9515	2.8441	2.8647	2.8693
24	2.8281	1.3443	2.6064	2.8776	2.7671	2.7595	2.7984
Max	7.3479	2.9874	6.4037	6.5158	6.6103	6.7201	6.9883
Min	.807	1.1203	.2538	2.0256	1.2582	1.7703	1.8069
Avg	3.8073	1.9138	3.6479	3.8291	3.7866	3.9212	4.1927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 203 / Sai Stone Crusher (Express SHEDDABLE FEEDER HAVING WEEKLY
 Fee Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT))

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0732	.0914	.0732	.0549	.0914	.0914
2	.0549	.0732	.0914	.0732	.0543	.0914	.0914
3	.0549	.0732	.0914	.0732	.0549	.0914	.0914
4	.0549	.0732	.0914	.0732	.0549	.0914	.0914
5	.0549	.0732	.0914	.0732	.0549	.0914	.0914
6	.0732	.0732	.0914	.0549	.0549	.0914	.0914
7	.0732	.0914	.0914	.0549	.0549	.0914	.0914
8	.128	.0914	.0914	.0732	.0732	.0914	.0914
9	.0732	.1097	.1829	.0549	.0732	.1097	.0914
10	.2378	.2012	.1829	.0549	.439	.1097	.2743
11	.128	.3658	.1829	.128	.4207	.128	.3658
12	.128	.3658	.1463	.0914	.1463	.0914	.4207
13	.0732	.3658	.128	.0732	.1646	.128	.128
14	.2378	.1829	.1463	.1097	.1463	.128	.3292
15	.2012	.1829	.2561	.1097	.3658	.128	.128
16	.2561	.1829	.1646	.0732	.2195	.2561	.1829
17	.2378	.1829	.2195	.0914	.1463	.2195	.2195
18	.2926	.1829	.2926	.0549	.0914	.2743	.3658
19	.2926	.1829	.2926	.0633	.128	.1829	.1829
20	.2378	.0914	.0732	.0633	.0732	.0914	.1829
21	.0732	.0914	.0732	.0633	.0914	.0914	.0914
22	.0732	.0914	.0732	.0474	.0914	.0914	.0914
23	.0366	.0914	.0732	.0732	.0914	.0914	.0914
24	.0732	.0732	.0914	.0732	.0732	.0914	.0914
Max	.2926	.3658	.2926	.128	.439	.2743	.4207
Min	.0366	.0732	.0732	.0474	.0543	.0914	.0914
Avg	.1334	.1486	.1379	.0739	.1341	.1227	.1653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 204 / Golegaon New

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	.679	1.226	.7922	.7922	1.1317	1.1317
2	1.1317	.9054	1.226	1.226	.9054	1.1317	1.1317
3	.9054	.9054	1.226	1.358	.9054	1.1317	1.1317
4	.9054	.9054	1.4146	1.358	.9054	1.1317	1.226
5	1.8107	1.1317	1.5089	1.5089	1.5844	1.358	1.3203
6	1.8107	1.5844	1.6975	1.9239	1.8107	1.5844	1.3203
7	2.037	1.8107	2.0748	1.9239	1.8107	1.358	1.1317
8	2.037	1.7353	2.2634	1.9239	1.8107	1.2449	1.1317
9	1.9239	1.8296	2.2634	1.8107	1.8107	1.0185	1.1317
10	1.6975	1.6975	2.0748	1.8107	1.6975	.7922	.9431
11	.7922	1.1317	.7922	.9054		1.2449	1.4712
12	.7922	1.1317	.7922	.7922		1.5089	1.5089
13	.679	1.1317	.7922	.7922		1.358	1.2449
14	.7922	1.226	.7922	.679	.9054	1.358	1.2449
15	.679	1.3203	.7922	.679	.9054	1.4146	1.358
16		1.1317			.9054	.7922	1.2449
17	1.0185	1.1317	.9054		1.0185	1.0374	
18	1.2449	1.226	1.1317	1.2449	1.2449		
19	1.5844	1.3203	1.5089	1.4712	1.5844	1.3203	
20	1.4712	1.4146	1.358	1.4712	1.4712	1.3203	1.3203
21	1.358	1.3203	1.358	1.358	1.358	1.226	1.3203
22	1.2826	1.3203	1.1317	1.2449	1.358	1.1317	1.226
23	1.2449	1.3203	1.1317	1.1317	1.2449	1.1317	1.226
24	1.2449	1.1317	1.1317	1.1317	1.1317	1.1317	1.1317
Max	2.037	1.8296	2.2634	1.9239	1.8107	1.5844	1.5089
Min	.679	.679	.7922	.679	.7922	.7922	.9431
Avg	1.2859	1.2684	1.3302	1.2972	1.2934	1.2112	1.2332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 201 / GOLEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4458	.1199	.1199	.12	.1372	.1155
2	.5144	.4458	.1199	.1199	.12	.1372	.1199
3	.5144	.5144	.1199	.1199	.1372	.1372	.1199
4	.5487	.5144	.1199	.137	.1372	.1543	.1199
5	.6173		.137	.137	.1543	.1543	.137
6	.6173	.583	.137	.1541	.1543	.1543	.137
7	.6516	.6173	.1199	.1713	.1543	.1715	.137
8	.7202	.6687	.1195	.137	.1715	.1713	.137
9	.7202	.6851	.1028	.1547	.1715	.1028	
10	.6859	.8221	.1028	.1543	.1543	.1028	.3426
11	.12	.0856	.5481	.5144	.4973	.4065	.5481
12	.12	.0856	.6166	.5487	.5487	.5138	.5481
13	.1029	.0856		.6687	.3772	.4796	.5481
14	.1029	.0856	.4453	.6859	.3429	.4624	.5138
15	.1029	.0856	.4796	.6859	.4115	.4967	.5138
16	.12	.0856	.5481	.6859	.4458	.5138	.5138
17	.12	.0856	.5481	.6687	.4801		.5463
18	.1543		.5481	.7202	.5144	.5995	.1028
19	.1715		.1199	.1543	.1543	.1199	.137
20	.1715		.1541	.1543	.1715	.137	
21	.1543		.137	.1372	.1543		
22	.1543		.137	.1372	.1543		
23	.1372			.1372	.1372	.1199	
24	.12	.1372	.1199	.1199	.1372	.1372	.1199
Max	.7202	.8221	.6166	.7202	.5487	.5995	.5481
Min	.1029	.0856	.1028	.1199	.12	.1028	.1028
Avg	.3308	.3549	.2546	.3093	.2501	.2576	.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 202 / SHIRADHON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8649	.4115	.7159	.6131	.7925	.8344	.834
2	.8268	.4115	.7159	.6474	.7925	.8344	.834
3	.8611	.4801	.7159	.7501	.8611	.7544	.7959
4	.8954	.5144	.7159	.8529	.8954	.7887	.7578
5	.9335	.5487	.7882	.3429	.4191	.8268	.8644
6	1.1203		.971		.4954	.9373	.9407
7	1.3108		1.2263		.0381	1.086	1.0512
8	1.1889	.6687	1.2349			1.192	.7638
9	1.1927	.6851	1.3025			1.1235	.6495
10	1.1203	.6851	1.3406		.1524	.9446	.9065
11	1.1241	.5138	1.1959	.5906	1.0898	.8722	.9065
12	1.0479	.4111	1.0854	1.2346	1.0631	.4572	.9065
13	.9373	.4111	.5335	1.286	.4954	.7236	.9236
14	.8611	.3768	.6131	1.1584	.4229	.7959	.8854
15	.9335	.3768	.6131	1.1203	.8687	.9158	.9368
16	.9678	.4111	.6855	1.0098	1.0479	.4954	.975
17	1.0441	.4111	.8302	1.0308	1.1241	.9955	1.1578
18	1.1927		.9446	1.1546	1.227	1.1235	.8019
19	1.1165		1.0473	1.2346	1.3756	1.1616	.5351
20	1.1203		1.2301	1.1622	1.2689	1.1749	.5335
21	1.086		1.0893	1.0517	1.1622	1.1235	.4954
22	.9755		.9407	.945	1.0898	.9065	.4954
23	.8306		.4954	.8344	.9793	.4954	.4572
24	.8478	.3772	.4191	.7274	.8726	.8859	.8076
Max	1.3108	.6851	1.3406	1.286	1.3756	1.192	1.1578
Min	.8268	.3768	.4191	.3429	.0381	.4572	.4572
Avg	1.0167	.4809	.8938	.9340	.8424	.8937	.8006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 203 / JOSHI SANGVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.4796	.4796	.703	.7202	.1713
2	.1543	.1543	.4796	.4796	.7545	.7202	.462
3	.1543	.1543	.462	.4796	.7545	.823	.4796
4	.1715	.1715	.6262	.4796	.8573	1.0288	.4796
5	.1715	.1715	.7879	.9592	1.0631	1.1831	.4796
6	.2058	.2058	1.2332	1.3702	1.2003	1.3717	.9592
7	.2058	.2058	1.5193	1.5415	1.4918	1.5089	1.1304
8	.2229	.2058	1.5929	1.7984	1.6804	1.6614	1.4045
9	.2058	.2055	1.61	1.749	1.7147	1.3529	1.473
10	.2058		1.61	1.7147	1.6804	1.1304	.1541
11	1.0288	1.4387	.1199	.1372	.2058		.137
12	1.3717	1.4559	.1199	.1372	.1715	.1199	.137
13	1.4232	1.4559		.12	.1543		.1199
14	1.4746	1.3702	.137	.12	.1543		.1199
15	1.5432	1.3017	.1541	.12	.1715	.137	.1541
16	1.5775	1.473	.137	.12	.1715	.1541	.1541
17	1.6118	1.5415	.1541	.12	.1886	.1541	.1541
18	1.6804		.1713	.1715	.1886	.2055	
19	.2058		.2227	.2058	.2058	.2227	.2227
20	.2229		.2227	.2058	.2229	.2227	
21	.2058		.2227	.1715	.2058		
22	.1715		.1713	.1715	.2058	.1884	.1713
23	.1715			.1715	.1715	.1884	
24	.1543	.1543	.1541	.1541	.1543	.1543	.1713
Max	1.6804	1.5415	1.61	1.7984	1.7147	1.6614	1.473
Min	.1543	.1543	.1199	.12	.1543	.1199	.1199
Avg	.6123	.6953	.5631	.5491	.6030	.6624	.4367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 204 / 11 KV Express - LIS
Shiradhon Feeder KV- 11 /
OUTGOING

PURELY LIS FEEDERS

DATE	05-MAY-17
HR	Load (MW)
15	.1541
16	.1541
Max	.1541
Min	.1541
Avg	.1541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 205 / Osmannagar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.3086	.5213	.6166	.6173	.6173	.3254
2	.6173	.3086	.5481	.6166	.6859	.6173	.5481
3	.6859	.3258	.5481	.6166	.823	.6687	.5481
4	.7545	.3429	.5481	.6509	1.0288	.7545	.5481
5	.8402	.3429	.7879	.8221	1.0631	.9431	.6851
6	1.0288	.3429	.9934	1.2332	1.0974	1.1488	.7879
7	.3772	.3772		1.5072	1.2003	1.3717	.9934
8	.3429	.3772	1.1133	1.6443	1.4403	1.5758	1.2869
9	.3086	.3768	1.0277	1.5775	1.5089	1.3702	1.4045
10	.3086	.3768	1.0277	1.5432	1.5432	1.2675	.8564
11	1.0974	1.0619	.2569	.2915	.3086	.137	.2569
12	1.2346	1.1304		.2743	.2743	.2398	.2569
13	1.4232	1.1647		.2401	.2572	.2227	.274
14	1.4403	1.1476	.2569	.2572	.2572	.2398	.274
15	1.4403	1.1437	.2569	.2572	.2743		.2569
16	1.5432	1.4045	.2569	.2743	.3086	.274	.2569
17	1.5432	1.5415	.3083	.2743	.3086	.264	.2912
18	1.6118		.3083	.3086	.3258	.33	.3083
19	.3429		.3426	.3429	.3429	.33	.3768
20	.3772		.3768	.3772	.3772	.3939	
21	.3429		.3768	.3772	.3429		
22	.3086		.3254	.3601	.3086	.3426	
23	.3086			.3429	.3086	.3426	
24	.583	.3086	.3083	.3083	.3429	.3086	.3254
Max	1.6118	1.5415	1.1133	1.6443	1.5432	1.5758	1.4045
Min	.3086	.3086	.2569	.2401	.2572	.137	.2569
Avg	.8116	.6879	.5245	.6298	.6394	.6255	.5431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 201 / SONKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8497	.381	.8162	.9374	.8139	.9004	.9045
2	.8443	.381	.8162	.9259	.8139	.8943	.8924
3	.8444	.381	.8482	.9236	.8375	.8966	.887
4	.9114	.4572	.8959	1.0075	.9042	.9884	.9594
5	1.0212	.4572	.9576	1.1538	1.0357	1.1442	1.0051
6	1.1272	.5335	1.1957	1.3756	1.2399	1.3687	1.2384
7		.5335	1.2323	1.355	1.2966	1.3741	1.3603
8	.3201	.5335	1.3271	1.3732	1.3939	1.302	1.2948
9	1.2795	.5335	1.2242	1.2463	1.2936	1.2395	1.2453
10	1.1636	.5144	1.2186	1.094	1.1355	.3963	1.1339
11	1.0874	.5144	.8299	.8527	.8855	.8337	.9385
12	.9853	.4287	.9274	.7773	.9446	.7521	1.0235
13	.9106	.4801	.99	.8215	.9701	.7377	1.001
14	.9129	.4287	.9732	.8162	.9899	.7339	.9484
15	.176	.4287	.9503	.0046	.8032		.4641
16		.4287	.9823				
17		.4287	1.1073	.1943			.1006
18	.5655	.463	1.1393	1.1332	1.1805		1.2829
19	1.3962	.6344	1.3252	1.3073	1.3969	.439	1.4244
20	1.1988	.5658	1.2712	1.3256	1.2712	1.4427	1.3977
21	.7026	.5144	1.1637	1.1096	1.1012	1.2963	1.1607
22	.9587	.5144	1.0692	1.0224	.9957	1.1057	1.0247
23	.9305		1.0258	.9594	.9522	1.0577	.95
24	.9945	.381	.8863	.9625	.9122	.9964	.8893
Max	1.3962	.6344	1.3271	1.3756	1.3969	1.4427	1.4244
Min	.176	.381	.8162	.0046	.8032	.3963	.1006
Avg	.9134	.4746	1.0489	.9860	1.0531	.9950	1.0229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 203 / Dagadgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.0762	.3429	.5716	.4287	.4287	.3048
2	.3048	.0762	.3429	.5716	.4572	.5144	.3048
3	.3048	.0762	.3772	.7621	.5335	.7716	.4572
4	.3048	.0762	.4287	.9526	.6097	.9774	.6097
5	.3048	.0076	.5144	1.105	.7621	1.0974	.8383
6	.3048	.0762	.6001	1.2384	.9145	1.166	1.0669
7	.3048	.0762	.6097	1.3336	.8669	1.2517	1.0669
8		.0762	.7202	1.3336	.9335	1.2346	1.0669
9			.9145	1.2003	.9335	1.0288	.9145
10			1.105	1.1145	.9907	.9145	.8383
11		.4287	.2667	.2915	.3429	.2286	.3048
12	.9907	.4287	.2286	.2896	.4287	.2286	.3353
13	1.0669	.6001	.3239	.3086	.3944		
14	1.0669	.3429	.3239	.3258	.3429		.3429
15		.3429	.3429	.3429			.3429
16		.3772	.4191	.4287			.3429
17		.3429	.4763	.4973	.3429		.3429
18		.5335	.4763	.3429	.5144		.4287
19	.8383	.2286	.2858	.3429	.3772		.4572
20	.7621	.2058	.1905	.2572	.3429	.2286	.2743
21	.3048	.1715	.2858	.2572	.3429	.2286	.1715
22	.3048	.2058	.2858	.3086	.3429	.3048	.2401
23	.1524		.3429	.2743	.3429	.3048	.2058
24	.381	.1524	.12	.3429	.2591	.3429	.3048
Max	1.0669	.6001	1.105	1.3336	.9907	1.2517	1.0669
Min	.1524	.0076	.12	.2572	.2591	.2286	.1715
Avg	.5001	.2334	.4302	.6164	.5366	.6619	.5027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 204 / Dapshed Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3048	.3429	.4763	.4287	.4287	.3048
2	.3506	.3048	.3429	.5335	.4287	.4801	.3048
3	.3963	.3048	.4287	.5335	.4801	.4801	.381
4	.4268	.381	.5144	.6097	.5144	.6173	.4572
5	.4572	.4572	.6001	.8002	.6001	.7202	.5335
6	.4572	.5335	.6859	.8573	.6001	.823	.6097
7	.4572	.381	.7716	.9526	.6516	.8573	.6097
8	.4572	.381	.8573	.9526	.6859	.8059	.6097
9	.4115	.3048	.6859	.7716	.6859	.7202	.6097
10	.381	.4287	.724	.6859	.7716	.6097	.6097
11	.4572	.4287	.3048	.2229	.3429	.2286	.3429
12	.3048	.4287	.3048	.2915	.3086	.2286	.3086
13	.381	.3944	.3239	.2572	.3086	.2286	.3086
14	.381	.3429	.2858	.2915	.3086	.2286	.2572
15		.4287	.3048	.2572	.3086		.3086
16		.463	.3429	.3086	.3086		.3429
17		.6001	.4001	.3429	.3601		.3429
18	.4572	.6344	.4191	.3944	.4287		.4287
19	.4572	.5144	.4572	.4287	.4801		.463
20	.4572	.5144	.5335	.5144	.4458	.4572	.463
21	.381	.4287	.4572	.4287	.4287	.381	.4287
22	.3048	.3944	.4191	.3944	.4115	.381	.3772
23	.3048		.4191	.3772	.3772	.3048	.3429
24	.4191	.3048	.3429	.4191	.3429	.3601	.3048
Max	.4572	.6344	.8573	.9526	.7716	.8573	.6097
Min	.3048	.3048	.2858	.2229	.3086	.2286	.2572
Avg	.4024	.4200	.4695	.5042	.4587	.4916	.4187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 201 / MALAKOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4623	1.2709	1.0473	2.5918	1.5973	1.2193	2.4732
2	2.6025		1.0453	2.4234	1.5033	1.2193	2.5958
3	2.7549	1.7979	1.045	2.3933	1.4573	1.2193	2.5143
4	3.014		1.0827	2.4908	1.4621	1.2193	2.5316
5	3.0212	2.3077	1.1593	2.6076	1.5108	1.2955	2.6339
6	4.0238	2.4563	1.2342	3.2046	1.9105	1.448	3.0316
7	2.5911	2.5393	1.3055	3.2555	2.0819	1.6766	3.369
8	4.8201	2.4486	1.2238	3.0655	1.9886	1.6766	3.1891
9	2.5149	2.3653	1.1971	3.0072	1.9316	1.5242	2.9288
10	3.8961	1.9084	1.5423	3.1236	1.7413	2.604	2.4782
11	2.2965		1.9403	3.5316	3.4439	1.4026	3.0701
12	1.3994		3.3917	4.151	3.9142	.548	3.387
13	1.0669	.4028	1.9814	4.2319	2.0257	1.2514	3.4415
14	1.4737	.4255	1.2955	4.1756	3.2186	1.7649	3.465
15	1.0669	.3135	1.6071	3.9095	3.7228	2.7435	3.4668
16	1.5459	.3381	1.437	1.9814	3.9915	3.1531	3.4722
17	1.1431	.3696	1.5175	3.6183	4.1676	3.2848	3.2173
18	1.6037	.3734	1.4362	4.2612	4.0451	3.0621	2.9809
19	1.921	.6011	2.8654	4.132	2.2633	2.9945	2.7922
20	1.6004	.6268	3.4665	3.8087	2.36	3.6332	3.6942
21	2.0206	.5129	3.3766	2.168	2.1814	3.4913	3.368
22	1.448	.4744	3.0947	2.0316	2.0116	3.0804	3.1308
23	1.7623	.3232	2.8807	1.8818	1.5588	2.7397	2.7769
24	1.2193	.4687	1.6949	2.6244	1.1937	1.3717	2.5853
Max	4.8201	2.5393	3.4665	4.2612	4.1676	3.6332	3.6942
Min	1.0669	.3135	1.045	1.8818	1.1937	.548	2.4732
Avg	2.2195	1.1162	1.8278	3.1113	2.3868	2.0676	3.0247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 202 / MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1872	.0374	.1903	.2022	.0762	.0762	.203
2	.1869	.0378	.1895	.2042	.0762	.0762	.1505
3	.1869		.2271	.2233	.0762	.0762	.1687
4	.1867	.0379	.2271	.2239	.0762	.0762	.1699
5	.2228		.2272	.243	.0762	.0762	.1894
6	.317	.0728	.3404	.3391	.0762	.1524	.322
7	.2286		.3376	.3567	.1524	.1524	.3592
8	.4096	.0726	.3525	.3953	.1524	.1524	.4529
9	.2286	.0546	.3597	.2822	.1524	.1524	.4159
10	.1886		.301	.2639	.1524	.3578	.2815
11	.3192	.1137	.2056	.1124	.0762	.0916	.2024
12	.262	.1474	.2995	.1124	.0762	.0908	.2022
13	.0762	.1282	.1861	.1122	.0762	.1077	.1829
14	.2415	.1295	.1864	.1122	.0762	.0718	.1843
15	.0762	.1107	.1867	.1105	.0762	.0905	.1664
16	.2227	.0939	.1865	.0932	.0762		.1848
17	.1524	.0924	.1871	.1113	.0762	.1802	.202
18	.3366	.0934	.2048	.1314	.0762	.1827	.2066
19	.1524	.0376	.2957	.1504	.1524	.1819	.3582
20	.2259	.057	.3343	.2272	.2286	.1985	.4433
21	.1524	.057	.3148	.228	.1524	.1586	.4081
22	.2079	.0569	.3144	.2092	.1524	.1579	.2964
23	.1135	.057	.2957	.1899	.1524	.1378	.2587
24	.165	.0375	.1904	.2179	.0762		.2738
Max	.4096	.1474	.3597	.3953	.2286	.3578	.4529
Min	.0762	.0374	.1861	.0932	.0762	.0718	.1505
Avg	.2103	.0763	.2559	.2022	.1080	.1363	.2618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 203 / ASHTUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6105	.299	.8366	.9362	.9072		.453
2	.6455	.2835	.9063	1.0059	1.0426		.4087
3	.7377		1.0374	1.1031	.961		.444
4	.8475	.2844	1.0374	1.1631	.9383		.4499
5	.9164		1.0951	1.2049	1.1031		.5281
6	1.1523	.4003	1.1659	1.307	1.332		.8479
7	.7377	.3809		1.2074	1.4259		1.0718
8	.8688	.3265		1.0556	1.356		.9158
9		.3275	.8479	.8157	1.2778		.8989
10	.2172		1.1145	.5944	1.2012	1.0082	.5902
11	.964	.8151	.6099	.1631	.2022	.5498	.3424
12	1.1888	1.087	.6435	.1627	.181	.4358	.3421
13	1.1031	.9154	.6042	.162	.1456	.3948	.3377
14		.9435	.6612	.1619	.0182	.3464	.3244
15	1.1645	.9221	.6448	.1543	.1254	.3982	.3067
16		.526	.6435	.1865	.1259		.4163
17	1.2673	.5914	.6468		.1991	.5046	.4132
18	1.2712	.6535	.7163	.0368	.217	.6395	.6521
19	.4028	.4321	.9511		.2917	.7824	.5613
20		.5129	.9097	.299	.3662	.6315	.6798
21	.3677	.3799	.8841		.708		.664
22		.1898	.8462	.2641	.6355	.5264	.6481
23	.3361	.2282	.7522	.2437	.5908	.4822	.6733
24	.586	.3374	.2282	.6379	.2252		.4508
Max	1.2712	1.087	1.1659	1.307	1.4259	1.0082	1.0718
Min	.2172	.1898	.2282	.0368	.0182	.3464	.3067
Avg	.8097	.5160	.8083	.6126	.6490	.5583	.5592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 204 / Limboti Dam (Old Express) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0187	.019	.018		.0181
2	.0184		.0189	.0183		.0186
3	.0184	.0187	.0189	.0184		.0185
4	.0184		.0189	.0185		.0187
5	.0183	.0185	.0189	.0185		.0377
6	.0183	.1274	.0188	.0187		.0377
7		.1451	.0185	.0186		.0564
8	.1448	.1451	.0182	.0185		.0374
9		.1274	.0188	.0185		.0562
10	.0181	.0182	.0186	.0186	.0187	.0369
11	.0185	.019	.0185	.0181	.0183	.0541
12		.0184	.0184	.0181	.0182	.036
13	.0184	.0183	.0183	.0181	.0179	.0356
14		.0185	.0184	.018	.0182	.018
15	.0182	.0184	.0184	.0171	.0181	.0361
16		.0188	.0184	.017	.0171	.0362
17	.0184	.0185	.0185	.0175	.036	.0359
18		.0187	.0184	.0184	.0365	.0186
19	.0183		.0183	.0186	.0364	.0187
20		.019	.0182	.0187	.0361	.0358
21	.0184	.019	.018	.0189	.0176	.0179
22		.019	.018	.0189	.0175	.018
23	.0187	.019	.0179	.0187	.0172	.0177
24	.0178	.0187	.019	.0177		.0173
Max	.1448	.1451	.019	.0189	.0365	.0564
Min	.0178	.0182	.0179	.017	.0171	.0173
Avg	.0262	.0411	.0185	.0183	.0231	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 201 / PENUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6859	.8383	.6859	.7621	.8573
2	.7621	.6859	.6668	.8383	.6859	.7621	.9431
3	.8383	.6859		.8383	.6859	.7621	
4	.9145	.6859	.8002	.823	.6859	.7621	.9431
5	.9145	.6859		.823	.6859	.8383	
6	.9907	.6859	.8002	.823	.6859	.8383	.9431
7	.9907	.6859		.823	.9145	.8535	
8	.8383	.6859	.9335	.7621	.9145	.823	.9431
9	.7621		.7011	.7621	.8078		.8535
10	.7621	.823	.5639	.7621	.6706	.9431	.6097
11	.9145		.7011		.7926		.5792
12	.9145	1.0288	.7316		.823	.8573	.5335
13	.9145		.7316	.6097	.7011	.6001	
14	.8383	1.0288	.7164	.6097	.7011	.6668	.4877
15	.8383		.6859	.6097	.7164		.5639
16	.8383	1.0288	.7164	.4287	.7468	.381	
17	.8383	1.0288	.8535	.6859	.8535		
18	.7621	1.0288	.9145	.6859	.7621	.6668	.7011
19	.6097	.7716	.9602	.6859	.6401		.7621
20	.6097		.9602	.6859	.7926	.6668	.8383
21	.6859	.8383	.8535	.6859	.8535		.8383
22	.6859	.7621	.8535	.6859	.7621	.6668	.7773
23	.6859	.8383	.8535		.7621	.7335	.7621
24	.6859	.6859	.7621	.8383	.6859	.7621	.6668
Max	.9907	1.0288	.9602	.8383	.9145	.9431	.9431
Min	.6097	.6859	.5639	.4287	.6401	.381	.4877
Avg	.8034	.8079	.7831	.7288	.7507	.7414	.7557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 202 / ANTESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.16	.1524	.1524	.3048	.2667
2	.2286	.1524	.2	.1524	.1524	.381	.5144
3	.2286	.1524		.1524	.1524	.381	
4	.3048	.1524	.16	.1524	.1524	.381	.5144
5	.3048	.1524	.1524	.1524	.1524	.381	
6	.381	.1524	.3334	.1524	.1524	.381	.4287
7	.381	.1524	.2667	.1524	.1524	.381	
8	.1524	.1524	.3334	.1524	.1524	.4572	.5144
9	.1524		.3048	.1524	.1524		.4572
10	.1524		.3048	.1524	.1524	.5144	.1524
11	.4572		.4572		.4572		.1524
12	.4572	.5144	.6097		.6097	.16	.1524
13	.4572		.6097	.381	.6097	.1334	
14	.4572	.5144	.5335	.381	.6097	.16	.1524
15	.381		.5335	.381	.4572		.1524
16	.381	.5144	.4572	.381	.4572	.1334	
17	.381	.5144	.4572	.381	.4572		
18	.381	.5144	.4572	.381	.381	.1334	.3048
19	.1524	.2572	.1524	.381			.381
20	.1524		.1524	.1524	.1524	.2	.381
21	.1524	.2286	.1524	.1524	.1524		.2286
22	.1524	.3048	.1524	.1524	.1524		.2286
23	.1524	.2286	.1524		.1524	.2667	.2286
24	.1524	.1524	.1334	.1524	.1524	.1524	.2
Max	.4572	.5144	.6097	.381	.6097	.5144	.5144
Min	.1524	.1524	.1334	.1524	.1524	.1334	.1524
Avg	.2794	.2757	.3142	.2286	.2750	.2883	.3006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 203 / Godawari Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.0669	
2						1.2193	1.5432
3						1.2193	1.3717
4						1.2193	1.5432
5							1.7147
6						1.2193	1.5432
7						1.3717	1.7147
8						1.5546	1.7147
9							1.3717
10						1.749	
11	1.7528	1.7147	1.5546		1.5242		
12	1.829	1.7147	1.7375		1.5851		
13	1.829		1.7528	1.5242	1.6766	1.8004	
14	1.1908	2.0576	1.7985	1.5242	1.7071		
15	1.9052		1.829	1.6766	1.7071		
16	1.9052	2.1434	1.8442	1.829	1.7375		
17	1.9052	2.1434	1.8442	1.829	1.7071		
18		2.1434	1.8138	1.829	1.7528		
19				1.829			
Max	1.9052	2.1434	1.8442	1.829	1.7528	1.8004	1.7147
Min	1.1908	1.7147	1.5546	1.5242	1.5242	1.0669	1.3717
Avg	1.7596	1.9862	1.7718	1.7201	1.6747	1.3800	1.5646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 201 / Mohanpura Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.3429	.3658	.4668	.4481	.4458	.4458
2	.4668	.3429	.3734	.4668	.415	.4287	.4458
3	.4668	.3601	.4066	.4668	.415	.4287	.4458
4	.4854	.4458	.4755	.5041	.4904	.4973	.5144
5	.5601	.4801	.695	.5544	.7023	.5487	.583
6	.8215		.8589	.8131	.8131	.6173	.6516
7		.583	.7762	.7468	.7762	.7716	.7545
8		.6344	.6348	.7282	.7316	.7373	.7373
9	.7842	.4801	.5487	.6908	.7392	.5487	.5487
10	.6001	.5914	.4706	.4435	.583	.4801	.4854
11	.4458	.5544	.3511	.4066	.3772	.3601	.4251
12		.4805	.3511	.415		.3601	
13		.415	.3658	.4066		.3429	
14			.4066	.4066			
15	.4115	.4435	.4066	.4435	.4458		.5041
16	.4458	.4805	.4251	.4854	.4801		.5041
17	.5144	.5601	.4435	.5175	.5144		.5041
18	.5487	.6036	.4805	.5914	.6516		.5601
19	.6687	.6838	.7392	.6722			.7095
20	.5658	.6348	.7468	.7095	.6859	.7545	.7282
21	.4801	.5544	.6908	.6036	.6001	.6173	.6908
22	.3601	.4854	.5975	.5281	.5487	.583	.5601
23	.3429	.4481	.5601	.4904		.4973	.5041
24	.4668	.3429	.4066	.5041	.4904	.4458	.6859
Max	.8215	.6838	.8589	.8131	.8131	.7716	.7545
Min	.3429	.3429	.3511	.4066	.3772	.3429	.4251
Avg	.5212	.4976	.5240	.5442	.5741	.5258	.5709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 203 / Betsangavi Agri

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566		.0686	.0566	.0678	.0686	.0686
2	.0566		.0686	.0566	.0678	.0686	.0686
3	1.7635		.0686	.0566	.0686	.0686	.0686
4	1.9062		.0686	.0566	.1017	.0686	.0686
5	2.0645		.1029	.0754	.1017	.0857	.0857
6	2.2672		.1029	.1132	.1017	.0857	.0857
7	2.332		.1017	.1132	.1017	.1029	.1029
8	2.3482		.0686	.0754	.0671	.0857	.1029
9	2.2996		.0754	.0566	.0671	.0686	.0857
10	2.21		.056	.0509	.0686	.0686	.0943
11	.0857		1.989	2.0919	1.6766	1.3717	2.1051
12	.0686		2.42	2.4078	1.9509	1.768	2.2283
13	.0686		2.3922	2.4417	1.9814	1.829	2.2672
14	.0686		2.3758	2.4078	2.0119		2.2939
15	.0686		2.3482	2.3739	1.9814		2.2672
16	.0686		2.332	2.3061	1.9814		2.251
17	.0857	.0693	2.3158	2.1948	1.8595		2.2024
18	.1029	.0686	2.0885	2.2977	1.9509		2.2119
19	.1029	.1006	.0754	.104	.0857		.0754
20	.1029	.1029	.0943	.0686	.1029	1.5546	.0943
21	.1029	1.7833	.0943	.0678	.1029	1.5699	.0943
22		1.7147	.0754	.0686	.1029	1.6004	.0754
23		1.7337	.0754	.0686		1.5089	.0566
24	.0566		1.5939	.0566	.0686	.0686	1.4022
Max	2.3482	1.7833	2.42	2.4417	2.0119	1.829	2.2939
Min	.0566	.0686	.056	.0509	.0671	.0686	.0566
Avg	.8312	.7962	.8772	.8195	.7248	.6690	.8524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 204 / Jawala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2572	.3395	.4973	.4755	.2743	.2572
2	.2987	.2572	.3772	.5087	.4805	.2743	.2572
3	.2987	.2572	.439	.5087	.5914	.2896	.3658
4	.3174	.2915	.439	.5426	.6283	.2896	.4268
5	.3547	.3086	.5544	.6104	.6722	.3048	.4268
6	.4668		.6468	.6874	.695	.3048	.4572
7	.4668	.3944	.7023	.8029	.7762	.3353	.5182
8	.4108	.3772	.8316	.7865	.7762	.4572	.503
9	.3361	.3086	.7716	.7125	.7655	.4268	.4572
10	.2743	.3018	.7461	.7023	.6706	.4572	.5087
11	.5487	.4805	.2427	.2957	.1372	.2229	.2241
12		.6036	.2427	.1867	.1372	.1543	.1867
13		.7167	.2614	.1867	.1715	.1715	.1867
14		.7545	.2614	.1886	.1886		.168
15	.6097	.7922	.2614	.2195	.1886		.168
16	.6097	.7682	.2614	.2614	.1715		.168
17	.6097	.7762	.2614	.2743	.1715		.168
18	.5487	.7762	.2614	.2743			.1867
19	.5335	.4024	.3921	.3696			.2241
20	.2439	.4755	.4108	.4207	.3086	.3944	.2987
21	.2743	.4527	.3734	.4024	.2743	.3429	.2987
22	.2572	.415	.3174	.3658	.2915	.2915	.3361
23	.2401	.3772	.2987	.3326		.2743	.3174
24	.3174	.2572	.3395	.2801	.2957	.2572	.2572
Max	.6097	.7922	.8316	.8029	.7762	.4572	.5182
Min	.2401	.2572	.2427	.1867	.1372	.1543	.168
Avg	.3960	.4696	.4181	.4341	.4223	.3068	.3069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 201 / Janapuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2622	.2054	.2263	.2241	.2263	.2241
2	.2427	.2949	.2054	.2263	.2241	.2263	.2263
3	.2321	.3277	.2241	.2263	.2263	.2641	.2263
4	.2984	.3605	.2641	.2829	.2641	.3018	.2452
5	.3647	.3887	.2829	.3018	.2829	.3206	.2263
6	.5898	.4696	.3206	.3395	.3018	.3584	.3018
7	.8192	.8322	.3018	.2987	.3018	.3174	.3395
8	.9503	.9122	.2427	.2641	.2614	.2987	.3174
9	.8421	.9282	.2641	.2641	.2614		.3018
10	.8223	.7655	.2075	.2614	.2641		.2641
11	.1698	.1867	.7537	.6478	.6964	.4641	.5992
12		.1867	.7865		.7287	.506	.7209
13		.2195	.7773	.2241	.9442	.5312	.7209
14		.1829	.7287	.4687	.4111	.5312	.6642
15		.1848	.7125	.6401	.506		.6081
16		.2054	.7537	.6874	.6009		.502
17	.2829	.2241	.8288	.8642	.6642		.6478
18	.2987	.2772	.8745	.8421	.7116		.7432
19	.3584	.2987	.3018	.2987	.3206		.3584
20	.3361	.3018	.3395	.3772	.3206	.4915	.3206
21	.2987	.3018	.2829	.3018	.3018	.4428	.3018
22	.2801	.2829	.2641	.2452	.2641	.2801	.3018
23	.2801	.2614	.2452	.2263	.2263	.2402	.2829
24	.2614	.2614	.2054	.2241	.2241	.2263	.2218
Max	.9503	.9282	.8745	.8642	.9442	.5312	.7432
Min	.1698	.1829	.2054	.2241	.2241	.2263	.2218
Avg	.4195	.3715	.4322	.3800	.3972	.3545	.4028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 202 / Wadepuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.3086	.4527	.4527	.4527	.4527	.4481
2	.4338	.3429	.4527	.4527	.4527	.4527	.4527
3	.2804	.4115	.4904	.4527	.4527	.5281	.4527
4	.3155	.4801	.5281	.5281	.4904	.5658	.4527
5	.3814	.5426	.6036	.5658	.5281	.6036	.4904
6	.5487	.6104	.6979	.6224	.6036	.679	.6036
7	.7956	.4807	.6979	.6602	.7167	.6979	.7167
8	.7545	.7935	.6224	.6602	.6602	.6224	.6602
9	.7042	.7274	.547		.6036		.6602
10	.663	.6642	.4715		.4904		.4904
11	.4338	.3361	.6554	.4973	.583	.547	.6554
12		.2987	.6478	.5693	.5601	.4801	.6478
13		.3734	.5121	.4572	.4999	.4428	.5668
14		.3395	.5535	.503	.4586	.4374	.4641
15		.3584	.4843	.4687	.506		.4858
16		.3772	.5761	.5937	.5761		.4534
17	.5914	.415	.7373	.6722	.6154		.5121
18	.5658	.4904	.5365	.6882	.6478		.6009
19	.6979	.679	.6602	.6413	.6602		.6413
20	.6224	.6036	.6413	.7167	.6224	.5144	.6036
21	.5601	.547	.5975	.6224	.5658	.4588	.6036
22	.5228	.5093	.5041	.5281	.5281	.5601	.5658
23	.4854	.4715	.415	.4904	.4904	.5041	.5281
24	.4527	.4715	.4527	.4527	.4527	.4715	.4668
Max	.7956	.7935	.7373	.7167	.7167	.6979	.7167
Min	.2804	.2987	.415	.4527	.4527	.4374	.4481
Avg	.5391	.4847	.5641	.5589	.5507	.5305	.5510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 203 / Ratneshwari Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4108	.3921	.3734	.3734	.4481	.3734
2	.3734	.4481	.4108	.3734	.3361	.4481	.3734
3	.3772	.4481	.4481	.3734	.3734	.4854	.3734
4	.4527	.4854	.4854	.4481	.4108	.5228	.4108
5	.4904	.5601	.5601	.5228	.5228	.6348	.4904
6	.6722	.6908		.6348	.6722	.7095	.6722
7		.7468	.6722	.6348	.6722	.6348	.7392
8	.5281	.6908	.6908	.6653	.4854	.4904	.695
9	.7392	.6653	.5228	.6283	.5914	.5228	.5914
10	.6283	.5175	.3142	.543	.499	.499	.5121
11	.4805	.4435	.439	.3696	.4024	.4024	.5359
12		.2957	.3696			.3658	
13			.2801				
14			.3206				
15	.499	.3881	.3395	.4066	.4435		.4108
16	.4805	.4251	.4481	.439	.499		.4668
17	.6099	.462	.5228	.5121	.5601		.5041
18	.6838	.5601	.5975	.6283	.5975		.5788
19	.7095	.6468	.415	.6099	.5975		.6722
20	.5975	.5544	.6036	.4854	.5228	.7095	.5975
21	.4854	.4854	.4904	.4481	.4854	.5975	.5228
22	.4481	.4481	.4481		.4854	.5228	.4854
23	.4108	.4108	.4108	.4108	.4481	.4435	.4481
24	.4108	.4108	.3921	.3734	.3696	.4481	.4108
Max	.7392	.7468	.6908	.6653	.6722	.7095	.7392
Min	.3734	.2957	.2801	.3696	.3361	.3658	.3734
Avg	.5244	.5088	.4597	.4940	.4928	.5227	.5174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 201 / 11KV MUDKHED (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3717	1.3146	1.2003	1.3575		1.4022
2	1.286	1.286	1.2269	1.2003	1.3575		1.3146
3	1.286	1.286	1.2269	1.2003	1.3575		1.3146
4	1.286	1.286	1.2269	1.2003	1.3575		1.3146
5	1.2003	1.286	1.2269	1.2003	1.3575		1.3146
6	1.2003	1.3717	1.2269	1.286	1.3575		1.4022
7	1.2003	1.3717	1.2269	1.4575	1.2003		1.3146
8		.6859	1.2003	1.286	1.2003		1.3146
9		1.1393	1.2003	1.2003			1.286
10		1.0517	1.2003	1.2003		1.1393	1.2003
11	1.1145	1.1393	1.2003	1.2003		1.1393	1.2003
12		1.0517	1.1145	.0857			1.286
13	1.2003	1.2269	1.1145	1.2003			1.1431
14	1.2003	1.1393	1.1145	1.1145			1.286
15	1.2003	1.1393	1.0288	1.1145			1.286
16	1.2003	1.1393	1.0288	1.1145		1.4022	1.2003
17	1.286	1.2269	1.1145	1.1145		1.2269	
18	1.286	1.1393	1.286	1.286		1.3146	1.3717
19	1.4575	1.3146	1.4575	1.3717		1.5775	1.6289
20		1.4022	1.4575	1.4575		1.5775	1.6289
21	1.2003	1.4022	1.3717	1.4575		1.4899	1.5432
22	.6516	1.4022	1.4575	1.3717		1.4899	1.4575
23	1.8347	1.3146	1.286	1.3717		1.4022	1.3717
24	1.989	1.3717	1.3146	1.2003	1.3575		1.2955
Max	1.989	1.4022	1.4575	1.4575	1.3575	1.5775	1.6289
Min	.6516	.6859	1.0288	.0857	1.2003	1.1393	1.1431
Avg	1.2869	1.2311	1.2343	1.2038	1.3226	1.3759	1.3425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 202 / 11KV MENDAKA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.5242	1.5623	2.0576	1.2955		.5468
2	1.448	1.6766	1.7185	1.9814	1.3717		.5468
3	1.5242	1.6766	1.7966	2.1338	1.448		.5468
4	1.9052	1.829	1.7966	2.2862			1.7185
5	2.1338	1.9814	2.1091	2.2862			1.9528
6	2.21	2.2862	2.5777	2.4387			2.1872
7	2.2862	2.4387	2.4215	2.5911	1.9814		2.1872
8	2.2862	.1524	2.5149	2.5911	2.21		2.5777
9	2.21		1.6766	2.2862			2.2862
10	2.21		1.9052	2.1338		1.8747	.1524
11	.1524		.1524	.3048		1.1717	.1524
12			.1524	.3048		.2343	.1524
13	.2572		.1524	.3048		.2343	.1524
14	.2286	.3125	.1524	.3048		.2343	.1524
15	.2286	.3125	.1524	.3048		.2343	.1524
16	.2286	.3125	.1524	.3048		.2343	.1524
17	.3048	.3906	.1524	.3048		.2343	.1524
18	.381	.3906	.3048	.381		.3906	.1524
19	.6097	.5468	.6859	.5335		.5468	.6859
20	.6097	.6249	.7621	.5335		.703	.6859
21	.6097	.703	.7621	.5335		.703	.6859
22	.6097	.703	.6859	.4572		.703	.6859
23	.5335	.6249	.6859	.4572		.6249	.6859
24	.6097	.6142	.6249	.6097	.4572		.6249
Max	2.2862	2.4387	2.5777	2.5911	2.21	1.8747	2.5777
Min	.1524	.1524	.1524	.3048	.4572	.2343	.1524
Avg	1.0847	1.0053	1.0691	1.1844	1.4606	.5803	.8323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 203 / 11KV IZALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.6097	.6249	.6097	.4572		.5468
2	.5335	.6097	.6249	.6097	.4572		.5468
3	.5335	.6097	.6249	.6097	.4572		.5468
4	.5335	.6097	.6249	.6097	.4572		.5468
5	.5335	.6097	.6249	.6097	.4572		.6249
6	.6097	.6859	.703	.6097	.4572		.6249
7	.6859	.6859	.6249	.4572	.4572		.5468
8	.6097	.2286	.4572	.3048	.381		.4687
9	.4572		.4572	.3048			
10	.381		.3048			.3125	.7621
11	1.9814		1.829	1.9814		1.8747	2.2862
12		2.0309	1.829	1.9814		2.0309	2.1338
13	.381	2.1872	1.829	1.9814		2.0309	2.1338
14	.381	2.1091	1.6766	1.829		1.7185	1.829
15	2.0576	2.0309	1.6766	1.829		1.7185	1.829
16	2.1338	2.0309	1.6766	1.829		.3125	1.829
17	2.1338	1.9528	1.6766	1.829		.3125	
18	2.1338	2.0309	1.5242	1.7528		2.0309	.3048
19	.7621	.703	.6097	.4572		.6249	.6859
20	.6859	.703	.6097	.4572		.703	.6859
21	.6859	.6249	.6097	.4572		.703	.6859
22	.6097	.6249	.6097	.4572		.703	.6859
23	.6097	.6249	.6097	.4572		.6249	.6859
24	.5335	.6097	.6249	.6097	.4572		.6249
Max	2.1338	2.1872	1.829	1.9814	.4572	2.0309	2.2862
Min	.381	.2286	.3048	.3048	.381	.3125	.3048
Avg	.8913	1.0910	.9609	.9841	.4487	1.1215	.9825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 204 / 11KV DONGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.6766	1.3279	1.829	.6097		.5468
2	1.3717	1.829	1.3279	1.829	.7011		.5468
3	1.6766	1.829	1.406	1.829	1.3717		.5468
4	1.7528	1.829	1.4842	1.829			1.1717
5	1.829	1.9814	1.6404	1.9052			1.406
6	1.829	1.9814	1.7966	1.9052			1.6404
7	1.9052	1.9052	1.9528	2.0576	1.448		1.7185
8	1.9814	.3048	1.9052	2.1338	1.6004		1.7966
9	1.9814		1.9052	1.9052			1.6004
10	1.7528		1.829	1.448			.3048
11	.3048		.3048	.3048		.3125	
12		.3125	.3048	.3048		.3125	.3048
13	.2286		.3048	.3048			.3048
14	.2286	.3125	.3048	.3048			.3048
15	.2286	.3125	.3048	.3048			.3048
16	.2286	.3125	.3048	.3048			.3048
17	.3048	.3125	.3048	.3048		.3125	
18	.3048	.3906	.3048	.5335		.3906	.3048
19	.4572	.5468	.4572	.6097		.5468	.6097
20	.5335	.6249	.4572	.6097		.6249	.6097
21	.5335	.6249	.381	.6859		.6249	.6097
22	.5335	.5468	.4572	.6859		.6249	.6097
23	.4572	.5468	.5335	.6097		.5468	.6097
24	.5335	.381	.5668	.5335	.5335		.5468
Max	1.9814	1.9814	1.9528	2.1338	1.6004	.6249	1.7966
Min	.2286	.3048	.3048	.3048	.5335	.3125	.3048
Avg	.9675	.9280	.9111	1.0447	1.0441	.4774	.7592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 205 / 11KV CRPF EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0857	.0905	.0857	.0905		.0905
2	.0905	.0857	.0905	.0857	.0905		.0905
3	.0905	.0857	.0905	.0857	.0905		.0905
4	.0905	.0857	.0905	.0857	.0905		.0905
5	.0905	.0857	.0905	.0857	.0905		.0905
6	.0905	.0857	.0905	.0857	.0905		.0905
7	.0905	.0857	.0905	.0857	.0905		.0905
8	.0857	.0857	.0762	.0857	.0905		.0905
9	.0857	.0905	.0857	.0905			.0857
10	.0857	.0905	.0857	.0905		.0905	.0857
11	.0857	.0905	.0857	.0895		.0905	.0857
12		.0905	.0857	.0876		.0905	.0857
13	.0857	.0905	.0857	.0895		.0905	.0857
14	.0762	.0905	.0857	.0895		.0905	.0857
15	.0857	.0905	.0857	.0895		.0905	.0857
16	.0857	.0905	.0857	.0895		.0905	.0857
17	.0857	.0905	.0857	.0905		.0905	
18	.0857	.0905	.0857	.0905		.0905	.0857
19	.0857	.0905	.0857	.0895		.0905	.0857
20	.0857	.0905	.0857	.0895		.0905	.0857
21	.0857	.0905	.0857	.0895		.0905	.0857
22	.0857	.0905	.0857	.0905		.0905	.0857
23	.0857	.0905	.0857	.0905		.0905	.0857
24	.0905	.0857	.0905	.0857	.0857		.0905
Max	.0905	.0905	.0905	.0905	.0905	.0905	.0905
Min	.0762	.0857	.0762	.0857	.0857	.0905	.0857
Avg	.0870	.0887	.0869	.0882	.0900	.0905	.0876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 201 / CHAINAPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291		.4287	.3963	.4268	.3658
2	2.4006		.4287	.3963	.3963	.3658
3	2.572		.4287	.3963	.381	.4268
4	2.572		.4287	.3658	.381	.4572
5	2.7435		.4458	.3658	.381	.4268
6	2.8292		.4458	.3658	.381	.3963
7	2.8292		.3944	.3201	.3963	.3048
8	2.8292		.2743	.1981	.3048	.2743
9	2.6578		.2058	.2134	.2286	.2134
10		.2401	.2286	.2439	.1677	1.89
11		2.6578	2.3167	2.4387	2.1338	2.3472
12			2.4387	2.4387	2.3167	2.5301
13		2.8292	2.3624	2.2862	1.9204	2.4691
14		2.8292	2.3167	2.2862	2.0729	2.4082
15		2.8292	2.3167	2.2862	2.1643	2.332
16		2.7778		2.2862	.2439	2.1643
17		2.7435		2.2862	.2591	1.9052
18		2.3148	2.4996	2.2862	2.1338	.3963
19		.3429	.4877	.4572	.3658	.4268
20		.4458	.5182	.4572	.4268	.4268
21		.4458	.4572	.4572	.442	.4115
22		.4656	.4268	.4572	.4572	.3963
23		.4458	.4268	.4572	.4572	.3963
24	.4287		.4268	.4572	.4572	.4268
Max	2.8292	2.8292	2.4996	2.4387	2.3167	2.5301
Min	.4287	.2401	.2058	.1981	.1677	.2134
Avg	2.4091	1.6437	.9411	1.0250	.8040	1.0066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 202 / 11KV BARASGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		2.915	2.4387	.7011	2.1338
2	.6859		3.0864	2.4691	.7011	2.1338
3	.6859		3.0864	2.4996	.6706	2.2862
4	.6859		3.0864	2.5606	2.2862	2.4387
5	.6859		3.1722	2.4996	2.4387	2.4387
6	.6859		3.1722	2.3167	2.5911	2.4387
7	.5144		3.1722	2.7435	2.7435	2.5149
8	.5144		3.1722	2.9569	2.7435	2.5149
9	.5144		3.0864	3.0483	2.7435	2.774
10		2.7435	2.5606	2.8197	2.0576	.4877
11		.4287	.4572	.5487	.381	.4877
12		.4287	.4115	.5487	.3963	.4572
13		.4287	.3963	.5487	.3963	.4572
14		.4287	.4268	.5182	.381	.4877
15		.4287	.442	.4877	.3658	.4877
16		.4287	.4572	.4877	.4572	.4877
17		.4287	.503	.5182	.5487	.4877
18		.5144	.5639	.5487	.5182	.6097
19		.8573	.7926	.8383	.7316	.7316
20		.8916	.7621	.8383	.823	.7926
21		.8916	.7316	.823	.823	.8078
22		.8916	.7316	.7926	.7926	.7773
23		.8916	.7164	.7621	.7621	.7621
24	.7716		.6554	.7316	.7316	.7316
Max	.7716	2.7435	3.1722	3.0483	2.7435	2.774
Min	.5144	.4287	.3963	.4877	.3658	.4572
Avg	.6430	.7630	1.6066	1.4727	1.1577	1.2803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 203 / BARAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583		.5658	.6344	.5639	.5182
2	.6089		.591	.6344	.5335	.5182
3	.6268		.591	.6173	.5335	.4877
4	.6268		.5731	.6173	.5335	.4572
5	.6268		.5731		.5182	.4572
6	.6268		.5487	.6516	.5182	.442
7	.5731		.5316	.5487	.503	.4877
8	.5731		.5731	.5658	.503	.4725
9	.5487		.5373	.5487	.4877	.4268
10	.5316	.5014	.3658	.4801	.442	.442
11	.5144	.5194	.4268	.5144	.4115	.4877
12	.5144	.5373	.4115	.5316	.3963	.4877
13	.5144	.5373	.3963	.5316	.4268	.4572
14	.5144	.5144	.4115	.5487	.442	.4725
15	.5144	.5373	.3963	.5487	.4725	.4877
16	.5316	.5373	.3963	.5487	.4572	.4877
17	.5316	.5144	.4268	.5658	.4572	.4877
18	.5487	.5373	.4115		.4877	.5182
19	.6859	.6268	.5487	.6859	.5487	.5487
20	.6859	.6268	.5487	.6859	.6401	.5792
21	.6687	.6268	.6097	.6859	.6554	.6097
22		.6268	.5944	.6687	.6401	.6097
23		.6001	.5792	.6687	.6097	.5792
24	.6001		.6344	.6516	.5792	.5792
Max	.6859	.6268	.6344	.6859	.6554	.6097
Min	.5144	.5014	.3658	.4801	.3963	.4268
Avg	.5796	.5602	.5101	.5970	.5150	.5042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 204 / SHEMBOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572		.6859	.5792	.5487	.5182
2	2.572		.6859	.5487	.5182	.4877
3	2.7435		.6859	.5487	.5182	.5487
4	2.915		.6859	.5487	.5182	.6097
5	2.915		.6859	.5792	.5487	.5792
6	3.0864		.6516	.6097	.5792	.5792
7	3.0864		.6001	.5792	.6097	.5487
8	3.0864		.5144	.4877	.5792	.5487
9	3.0007		.4801	.4572	.5182	.4572
10	3.0007	.4801	.4268	.4268	.381	2.2862
11		3.0864	2.8959	2.5911	2.5149	2.6673
12		3.5151	2.774	2.8959	2.7435	2.774
13		3.5151	2.6825	2.7435	2.5911	2.774
14		3.5151	2.5911	2.7435	2.5149	2.8045
15		3.4294	2.5911	2.7435	2.4387	2.8045
16		3.4294		2.7435	.4268	2.8959
17		3.3436		2.7435	.4268	2.9874
18		3.2579	2.8197	2.7435	2.5149	.5182
19		.8573	.7621	.6097	.5487	.5487
20		.8573	.7926	.6097	.5792	.5792
21		.8573	.823	.6097	.6097	.5944
22		.823	.7011	.6097	.6097	.5792
23		.7716	.5792	.5792	.5792	.5792
24	.7202		.7716	.5792	.5792	.5487
Max	3.0864	3.5151	2.8959	2.8959	2.7435	2.9874
Min	.7202	.4801	.4268	.4268	.381	.4572
Avg	2.6998	2.2670	1.2221	1.2879	1.0415	1.2841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 205 / Barad AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2003	1.0974		
2			1.286	1.1279		
3			1.3717	1.1888	1.2193	1.0669
4			1.5432	1.2498	1.3717	1.0669
5			1.5432	1.2803	1.3717	1.2193
6			1.5432	1.3413	1.3717	1.2955
7			1.5432	1.4022	1.448	1.3717
8			1.6289	1.4327	1.448	1.448
9			1.6289	1.4632	1.3717	1.3108
10		1.3717	1.2041	1.4022	1.2955	
11	1.5242					
12	1.7147					
13	1.5242					
14	1.5242					
Max	1.7147	1.3717	1.6289	1.4632	1.448	1.448
Min	1.5242	1.3717	1.2003	1.0974	1.2193	1.0669
Avg	1.5718	1.3717	1.4493	1.2986	1.3622	1.2542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 201 / 11 Kv Niwgha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2753	.2915	.2915	.2591	.2915	.2753	.2591
2	.2753	.2915	.2915	.2591	.2915	.2753	.2591
3	.2753	.2915	.2915	.2591	.2915	.2753	.2915
4	.2915	.2915	.2915	.2591	.2915	.2915	.2915
5	.3077	.3239	.3239	.3077	.3239	.3077	.2915
6	.3401	.3887	.3401	.3401	.3563	.3563	.2915
7	.3401	.3887	.3401	.3401	.3239	.3239	.2753
8	.3077	.3239	.3239	.3239	.3239	.2915	.3401
9	1.9757	1.9433	.2753	.2591	.2915	.2267	.2753
10	1.9757	1.9433	.2429	.2429	.2429	.1943	.2105
11	1.9109	1.8785	.1619	.1943	.1781		.1781
12	1.8138	1.8461	.1619	.1619	.1619	.1781	.1943
13	1.8138	1.749	.1619	.1619	.1619	.1457	.1943
14	1.6842	1.4899	.1781	.1619	.1619	.1619	.1781
15	1.749	1.5223	.1943	.1619	.1781	.1781	.2105
16	1.749	1.5223	.2105	.1943	.2267		.2105
17	.2591	.1781	2.251	.2429	2.2348	.1781	.2105
18	.2591	.2105	2.2672	2.4291	2.0081	2.3644	2.4291
19	.3239	.3239	2.1376	2.2672	2.2186	2.4291	2.2996
20	.3239	.3239	1.8138	2.2672	2.2186	2.0405	2.1052
21	.3239	.3239	1.7814	1.9433	1.9433	2.1376	2.1052
22	.2915	.3239	1.7004	1.6194	1.9433	2.2348	2.0729
23	.2915	.3077	1.7004	1.6194	1.9433	2.1052	2.0081
24	.2753	.3239	.2915	1.5546	1.6194	.2753	1.9433
Max	1.9757	1.9433	2.2672	2.4291	2.2348	2.4291	2.4291
Min	.2591	.1781	.1619	.1619	.1619	.1457	.1781
Avg	.8097	.7834	.7510	.7429	.8428	.7839	.7969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 202 / 11 kv Pardi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134	.0972	2.0729	2.1376	2.1052	.1134	.1134
2	.1134	.0972	2.0729	2.0729	2.1862	.0972	.1134
3	.1134	.0972	2.0405	2.1052	2.2672	.0972	2.4615
4	.1134	.0972	2.0891	2.1052	.0972	.1134	2.5587
5	.1296	.0972	2.1376	2.2348	.0972	.1296	2.5587
6	.1296	.1296	2.2348	2.3967	.1457	2.7854	2.5587
7	.1296	.1296	2.3482	2.5911	2.6558	2.8664	2.8826
8	.1296	.0972	2.3967	2.5101	.0972	2.8826	2.753
9	.1134	.0972	.1134	.081	.0972	.0972	2.6882
10	.0972	.0486	.0972	.081	.0972	.0972	.1134
11	.081	.0486	.081	.081			.0972
12	.081	.081	.0648				.081
13		.081	.081				.081
14	.081	.081	.081	.0648		.081	.081
15	.081	.081	.081	.0648		.0972	.081
16	.081	.081	.081				.081
17	2.753	2.6882	.0972	.0972	.1134	.0972	.081
18	2.753	2.753	.0972	.0972		.0972	.081
19	2.6558	2.6558	.1134	.0972	.1296	.1134	.1134
20	2.5911	2.4939	.1134	.0972	.1296	.1134	.1134
21		2.2672	.1134	.0972	.1296	.1134	.1296
22		2.17	.1134	.0972	.1296	.1134	.1134
23		2.1052	.1134	.0972	.1296	.1134	.1134
24	2.17	1.6194	2.0243	.1134	.0972	.1134	.1134
Max	2.753	2.753	2.3967	2.5911	2.6558	2.8826	2.8826
Min	.081	.0486	.0648	.0648	.0972	.081	.081
Avg	.7255	.8414	.8691	.92	.6297	.5166	.8401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 203 / 11 KV Khambal feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9757	2.1052	.0324	.0324	.0324	.0324	.0324
2	2.1052	2.1052	.0324	.0324	.0324	.0324	.0324
3	2.2996	2.2672	.0324	.0324	.0324	.0324	.0324
4	2.3967	2.2672	.0324	.0324	.0324	.0324	.0324
5	2.4615	2.5911	.0324	.0324	.0324	.0324	.0324
6	2.5911	2.6558	.0324	.0324	.0324		.0324
7	2.8178	2.6558	.0324	.0324	.0324		.0324
8	2.753	2.6558	.0324	.0324	.0324	.0324	.0324
9	.0324	.0324	2.8178	2.8664	2.915	2.7044	.0324
10	.0162	.0324	2.6235	3.1093	2.915		2.753
11		.0324	2.834	2.753	2.672	2.332	2.3967
12		.0324	2.8502	2.753	2.6235	2.2996	2.5911
13		.0324	2.753	2.4291	2.5587	2.2024	2.6235
14		.0324	2.5911	2.332	2.2672	2.2348	2.5587
15		.0324	2.5587	2.332	2.4291	2.17	2.4291
16		.0324	2.4939		2.3482		2.5911
17	.0324	.0324	.0324			.0162	2.2672
18	.0324	.0324	.0324	.0324		.0162	.0324
19	.0324	.0324	.0324	.0324	.0324	.0324	.0324
20	.0324	.0324	.0324	.0324	.0324	.0324	.0324
21	.0324	.0324	.0324	.0324	.0324	.0324	.0324
22	.0324	.0324	.0324	.0324	.0324	.0324	.0324
23	.0324	.0324	.0324	.0324	.0324	.0324	.0324
24	.0324	.0324	.0324	.0324	.0324	.0324	.0324
Max	2.8178	2.6558	2.8502	3.1093	2.915	2.7044	2.753
Min	.0162	.0324	.0324	.0324	.0324	.0162	.0324
Avg	1.0949	.8259	.9184	.8664	.9628	.7182	.8637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 201 / 11 KV Mahati

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3473	1.333		.2689		.2904	
2	.3467	1.4403		.2465	.312	.317	
3	1.1243	1.559		.2473	.311		
4	1.5133	1.6802			.322	.317	
5	1.6099	1.7869		.2469	.3698	.3597	
6	1.8997	1.8345		.2652	.4438	.3835	.2401
7	1.9319	1.8861		.2923	.3459		
8	2.0165		.2967	.3315	.3102		.2324
9	1.9159		.2347	.3561	.2734	2.6764	.1872
10	1.8763		.2058	.4204	.2309	.2136	1.6479
11			1.4746	1.9479	1.6901	1.704	2.0261
12		.3133	1.6518	2.0429	1.9524	1.7756	2.0549
13		.3071	1.7856	2.0704	1.9641		2.0317
14	.21	.2798	1.8675	2.0694	2.0405	1.7756	1.8984
15		.2872	1.9064	1.985	1.9892		1.8287
16	.3387	.291	1.9757		1.9986		1.7307
17		.3131	2.0165				1.7674
18	.389	.3058		2.0141	1.9227		
19	.3845		2.0607	.3871			.2053
20	.4986		.3802	.3945	.3896		.3704
21	.4514		.3506	.4097	.3658	.2561	.3864
22	.4152		.3315	.4158	.3419		.3972
23	.3904		.3094	.3387	.3195		.3499
24	.3441	.3824	.2904	.2898	.2821	.2936	.2123
Max	2.0165	1.8861	2.0607	2.0704	2.0405	2.6764	2.0549
Min	.21	.2798	.2058	.2465	.2309	.2136	.1872
Avg	.9476	.9333	1.0711	.8114	.8655	.8635	1.0334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 202 / 11 KV Malkautha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4698	.5963		2.2138		.5807	
2	.4995	.5898		2.372	2.5006	.631	
3	.6744	.5898		2.5118	2.512	.5258	
4	.5521	.6116		2.631	2.5878	2.2361	
5	.6722	.6574			2.6917	2.6038	
6	.5201	.6907	3.1365	2.7697	2.7878	2.652	2.9218
7	.5201	.6473		2.8147	2.9239	2.6368	
8	.4458			2.521	2.694	2.6038	2.7526
9			2.982	2.4255	2.5484	2.6764	3.2065
10			3.0417	2.5455	2.5441	2.5687	.5032
11			.412	.3542		.3284	.4341
12		2.7494	.3314	.3565		.3101	.4275
13		2.6241	.3319	.3595			.4206
14	2.5694	2.9057	.3579	.3579	.3905	.3606	
15		2.9029	.3574	.4006	.5365		
16	2.743	2.8016	.3824	.3577	.5335		.4702
17		2.769	.4079	.4814	.4974		.5513
18	2.8275	3.0089	.4468	.4011	.5258		
19	.7522						.7385
20	.7234			.6968	.8913		.7569
21	.7099		.6687	.6975	.815	.8487	.7625
22	.6654		.6411	.6957	.7888		.7515
23	.6638		.6145	.6563	.7099		.7251
24		.6027	.6646	.5642	.6301	.6573	.6228
Max	2.8275	3.0089	3.1365	2.8147	2.9239	2.6764	3.2065
Min	.4458	.5898	.3314	.3542	.3905	.3101	.4206
Avg	1.0005	1.6498	.9851	1.3266	1.5847	1.4813	1.0697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 203 / 11 KV Rohipimpalgaon
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9209		.2123		.2641	
2	.286	1.0391		.2119	.2801	.2647	
3	1.0174	1.0584		.2362	.2812	.2953	
4	1.0913	1.1216		.2378	.3097	.2949	
5	1.1191	1.1896		.2378	.3384	.3086	
6	1.2618	1.2829			.31	.3319	.2924
7	1.3641	1.3413		.3722	.3073		
8	1.3641		.2888	.2393	.2108		.2357
9	1.2942		.2042	.217	.2247	.2287	.227
10	1.5664		.2235	.2132	.2326	.2203	1.6003
11				1.5687	1.6804	1.574	1.6673
12		.1667	1.4643	1.5058		1.7184	1.6598
13		.1774	1.4217	1.4595	1.581		1.6735
14	.1964	.1755	1.387	1.4279	1.5604	1.5274	1.6351
15		.2	1.3992	1.5008	1.5123		1.5968
16	.2072	.2125			1.4779		1.5863
17		.2582	1.3394		1.581		1.6084
18	.2356	.2181	1.3672	1.5415	1.5518		
19	.3713		1.3672	.3639			.3529
20	.4027			.3589	.3507		.3658
21	.3567		.2599	.3362	.3219	.3269	.3635
22	.3265		.2607	.3245	.2926		.3378
23	.306		.2366	.3181	.2934		.3357
24	.2864	.3018	.2805	.2126	.3153	.2644	.3145
Max	1.5664	1.3413	1.4643	1.5687	1.6804	1.7184	1.6735
Min	.1964	.1667	.2042	.2119	.2108	.2203	.227
Avg	.7252	.6443	.8214	.6236	.7149	.5861	.9325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 201 / ARDHAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.5546	1.5223	1.5432	1.4327	1.7013	1.5432
2	1.5432	1.5384	1.4327	1.5432	1.4327	1.6118	1.5432
3	1.4575	1.5223	1.4327	1.3717	1.3432	1.5775	1.5432
4	1.4575	1.5223	1.5223	1.4575	1.5223	1.6651	1.5432
5	1.4575	1.5775	1.6118	1.6289	1.6118	1.6289	1.6289
6	1.6289	1.6651	1.7013	1.6289	1.6118	1.7147	1.6289
7	1.6289	1.7147	1.7551	1.6289	1.773	1.7147	1.6289
8	1.6289	1.6289	1.7013	1.6289	1.6832	1.5927	1.6289
9	1.5432	1.4575	1.5432	1.5432	1.7013	1.5089	1.6289
10	1.4575	1.4575	1.5432	1.6118	1.5432		1.7013
11	1.3717	1.4575	1.3717	1.6118	1.4575	1.5432	1.6118
12	1.3717	1.286	1.286	1.5223	1.3717		1.5947
13	1.3717	1.286	1.286	1.5223	1.4575	1.1145	1.5061
14	1.3717	1.286	1.286	1.4327	1.4575	1.286	1.5223
15	1.3717	1.1736	1.3717	1.4327	1.4575	1.3146	1.5061
16	1.3717	1.2003	1.3413	1.5061	1.4575	1.4022	1.5238
17	1.4251	1.5223	1.3717	1.5947	1.4575		.5281
18	1.5432	1.6118	1.6289	1.7013	1.5432	1.6289	.6036
19	1.9204	1.6118	1.7147	1.7013	1.9204	1.6289	1.8861
20	1.8099	1.7013	1.7147	1.7909	1.9004	1.6289	.679
21	1.848	1.7013	1.6289	1.7909	1.7909	1.6289	1.8004
22	1.7556	1.6118	1.6289	1.7909	1.7909	1.6289	1.8004
23	1.7375	1.6118	1.6289	1.6118	1.7909	1.6289	1.8004
24	1.6289	1.6461	1.5223	1.6289	1.5223	1.7013	1.6289
Max	1.9204	1.7147	1.7551	1.7909	1.9204	1.7147	1.8861
Min	1.3717	1.1736	1.286	1.3717	1.3432	1.1145	.5281
Avg	1.5519	1.5144	1.5228	1.5927	1.5846	1.5643	1.5004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 202 / DABHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4525	.3734	1.3717	1.5432	.4477	.4287
2	.3429	.3582	.3734	1.5432	1.8861	.4572	.4287
3	.3429	.3582	.3734	1.8861	2.0719	.4477	1.5432
4	.3429	.5144	.3734	2.0576	2.0481	1.5775	2.0576
5	.4287	.5258	.4668	.5144	2.2405	1.7528	2.2291
6	.4287	.4287	.4668	2.4006	2.4006	2.1033	2.2291
7	.4287	.3429	.3734	2.4006	2.4006	2.4863	2.4006
8	.4287	.3353	.3734	2.4006	2.5606	2.5987	2.8292
9	.3429	.3429	.3429	2.572	2.4291	2.7664	2.8292
10	.2572	.3429	.3429	2.4006	2.572	2.7435	.4668
11	1.7147	2.3148	2.4006	.3734	.5144		.4668
12	3.0007		2.4006	.3734	.5144		.4668
13	2.915	1.8861	2.8292	.3734	.3429	.3429	.3734
14	2.8292	2.572		.3734	.3429	.3429	.3734
15	2.7435	2.8292		.3734	.3429	.5258	.4668
16	2.4006	2.915	2.5149	.3734	.3429	.5144	.4668
17	2.2634	2.8807	2.915	.4668	.3429	.4287	.3429
18	2.3148	2.8807	2.572	.4668	.4287	.4287	.3429
19	.5487	.5601	2.572	.5601	.5487	.4287	.5144
20	.543	.5601	2.4006	.5601	.5487	.4287	.5144
21	.5544	.5601	.4287	.5601	.543	.4287	.5144
22	.5487	.5601	.5144	.5601	.5373	.4287	.5144
23	.4572	.4668	.4287	.4668	.4477	.4287	.5144
24	.5144	.4572	.3734	.4287	.3734	.4477	.4287
Max	3.0007	2.915	2.915	2.572	2.572	2.7664	2.8292
Min	.2572	.3353	.3429	.3734	.3429	.3429	.3429
Avg	1.1265	1.1063	1.1914	1.0774	1.1801	1.0253	.9893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 203 / Dabhad-II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7164	.8402	1.8861	1.8861	.7164	.6001
2	.7716	.7164	.7468	2.2291	1.989	.724	.6001
3	.7716	.7888	.7468	2.2291	2.1548	.7164	2.2291
4	.7716	.8573	.9335	2.4006	2.4577	1.7528	2.7435
5	.7716	.9431	.9335	2.572	2.4006	1.7528	2.7435
6	.8573	.8573	.9896	2.915	2.5606	2.3663	3.0864
7	.8573	.8573	.8402	3.0007	2.652	2.572	3.2579
8	.6001	.6706	.7468	3.0007	3.1131	2.6825	3.5151
9	.5144	.6001	.6001	3.0864	3.0407	3.0178	3.6008
10	.5144	.6001	.5144	2.915	3.2579	3.0864	.5601
11	2.0576	2.4863	2.7435	.5601	.5144	.4287	.6535
12	3.1722			.5601	.5144	.4287	.5935
13	2.915	2.4006	3.0864	.5601	.4287	.3429	.6535
14	2.8292	2.6578	2.8292	.5601	.4287	.4287	.5601
15	2.572	2.7435	2.8292	.5601	.5144	.5144	.5601
16	2.6578	2.8292	2.915	.6535	.5144	.5144	.5601
17	2.5987	2.8807	2.915	.6535	.5144	.5144	.5144
18	2.572	2.8807	2.572	.7468	.6001	.6001	.6001
19	.9145	.7468	.8573	.8402	.823	.6859	.7716
20	.9955	.8402	.8573	.9335	1.0059	.6859	.7716
21	1.0164	.8402	.7716	.9335	.905	.8573	.6859
22	.9145	.9335	.7716	.9335	.8954	.8573	.6859
23	.823	.9335	.7716	.8402	.8059	.6859	.6859
24	.7716	.823	.8402	.6859	.8402	.7164	.6859
Max	3.1722	2.8807	3.0864	3.0864	3.2579	3.0864	3.6008
Min	.5144	.6001	.5144	.5601	.4287	.3429	.5144
Avg	1.4171	1.3741	1.4196	1.5107	1.4507	1.1520	1.3299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 204 / MENDHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.6289	1.4575	.5144	.6535	.4477	.5144
2	2.0576	1.7013	1.5432	.5144	.7468	.4477	.5144
3	2.2291	1.9281	1.7147	.6859	.7468	.7164	.5144
4	2.3148	2.0576	1.8233				
5	2.3148	2.3148	1.9662				
6	2.4006	2.3148	1.9204				
7	2.4863	2.2291	2.0805				
8	2.4863	2.431	2.2405				
9	2.4006	2.4006	2.3148				
10	2.3148	2.3148	2.1434				2.0576
11				2.0576	2.4006	1.8861	2.2291
12				2.2291	2.7435	2.4006	2.2119
13				2.2119	2.572	2.2291	2.2119
14				2.2119	2.572	2.4863	2.13
15				2.13	2.4863		2.13
16					2.572		2.13
17	.503	.7468			2.572		2.4006
18	.8573	.9335	.9431	2.3205	2.572	2.7435	.7716
19	.9145	.9335	.8573	.5601	1.0059	.6859	.7716
20	.724	.9335	.7716	.5601	.9145	.6859	.7716
21	.7392	.8402	.5144	.6535	.6335	.8573	.6859
22	.6401	.8402	.5144	.6535	.5373	.6859	.5144
23	.5487	.7468	.5144	.5601	.4477	.6859	.5144
24	.5144	.7316	.7468	.5144	.5601	.4477	.5144
Max	2.4863	2.431	2.3148	2.3205	2.7435	2.7435	2.4006
Min	.503	.7316	.5144	.5144	.4477	.4477	.5144
Avg	1.5550	1.5571	1.4157	1.2252	1.5727	1.2433	1.3105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 205 / NIRML COTTON & GINNING
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0362	.0343	.0343	.0171	.0366	.0343
2	.0343	.0358	.0171	.0343	.0171	.0358	.0343
3	.0343	.0351	.0171	.0171	.0171	.0358	.0343
4	.0343	.0343	.0171	.0171	.0171	.0351	.0171
5	.0171	.0171	.0133	.0171	.0171	.0347	.0171
6	.0171	.0171	.0133	.0171	.0171	.0171	.0171
7	.0171	.0343	.0133	.0171	.0171	.0171	.0171
8	.0171	.0343	.0133	.0171	.0171	.0168	.0171
9	.0171	.0343	.0171	.0171	.0171	.0168	.0171
10	.0171	.0171	.0171	.0171	.0171	.0171	.0171
11	.0171	.0171	.0171	.0171	.0171	.0171	.0171
12	.0171	.0171		.0171	.0171	.0171	.0171
13	.0171	.0171	.0171	.0171	.0171	.0171	.0171
14	.0171	.0171	.0171	.0171	.0171	.0171	.0171
15	.0171		.0171	.0171	.0171	.0171	.0171
16	.0171		.0168	.0171	.0171	.0175	.0171
17	.0171	.0171	.0171	.0171	.0171	.0171	.0171
18	.0171	.0171	.0171	.0171	.0171	.0171	.0171
19	.0183	.0343	.0171	.0171	.0171	.0171	.0171
20	.0181	.0343	.0171	.0171	.0366	.0171	.0171
21	.037	.0343	.0171	.0171	.0366	.0171	.0343
22	.0366	.0343	.0171	.0171	.0358	.0343	.0343
23	.0366	.0343	.0171	.0171	.0358	.0343	.0343
24	.0171	.0366	.0343	.0171	.0171	.0358	.0343
Max	.037	.0366	.0343	.0343	.0366	.0366	.0343
Min	.0171	.0171	.0133	.0171	.0171	.0168	.0171
Avg	.0225	.0276	.0179	.0185	.0203	.0232	.0221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 201 / MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	.9602	1.4937	1.2696	1.2936	1.5339	1.3032
2	.8745	1.0562	1.4003	1.2323	1.2567	1.4784	1.2696
3	.9175	1.166	1.4003	1.2323	1.2197	1.4784	1.2323
4	.9503	1.2955	1.4003	1.307	1.2936	1.4784	1.2696
5	.9945	1.4746	1.4937	1.326	1.4415	1.4937	1.2936
6	1.4754	1.5249	1.6244	1.5684	1.7924	1.8671	1.4937
7	1.9448	1.6575	1.6804	1.7002	1.7177	1.8671	1.6263
8	1.8778	1.7695	1.6804		1.5844	1.7737	1.5684
9	1.5249	1.6842	1.587	1.5684	1.5466	1.587	1.419
10	1.5546	1.8023	1.1088	1.1458	1.587	1.1827	1.1984
11	1.1088	1.307	1.6644	1.5729	1.6194	1.2955	1.6518
12	1.1203	1.3203	1.6842	1.4548	1.7604	1.4083	1.7284
13	1.1088	1.4003	1.6446	1.5684	1.8185	1.4083	1.7078
14	1.1088	.4294	1.5623	1.5181	1.7394	1.358	1.5813
15	1.1827	1.3443	1.6324	1.5364	1.7185	1.358	1.4899
16	1.2567	1.307	1.6842	1.2536	1.6604		1.4899
17	1.3306	1.419	1.749	1.2125	1.6404	1.1088	1.6194
18	1.4784	1.4937	1.7695	1.7901	1.7394	1.7741	1.4266
19	1.7924	1.7737	1.7177	1.8111	1.7737	1.7741	1.7002
20	1.643	1.6632	1.643	1.7372	1.7364	1.7002	1.7002
21	1.448	1.6263	1.4784	1.5729	1.7002	1.4632	1.5524
22	1.4327	1.587	1.4045	1.4998	1.6461	1.39	1.4415
23	1.3611	1.587	1.3169	1.4266	1.5708	1.3306	1.39
24	1.3676	1.3443	1.587	1.2696	1.3535	1.587	1.39
Max	1.9448	1.8023	1.7695	1.8111	1.8185	1.8671	1.7284
Min	.8745	.4294	1.1088	1.1458	1.2197	1.1088	1.1984
Avg	1.3220	1.4164	1.5586	1.4597	1.5921	1.5085	1.4810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 202 / UMRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9069	.9602		.415	.415	.4294	.4163
2	.9717	1.0562		.415	.415	.4294	.4294
3	1.0486	1.166		.3772	.415	.4435	.3734
4	1.0814	1.2955		.3772	.4527	.499	.3772
5	1.1603	1.3763		.5228	.4904	.5544	.4668
6	1.4754	1.4918		.6348	.7095	.6722	.5601
7	1.643	1.6575		.7023	.6722		.6468
8	1.643	1.6385	.5281	.5041	.5281		.4715
9	1.6244	1.5708	.2623	.415	.3772	.3772	.415
10	1.587	1.4255	.3734	.3018	.2801	.3174	1.0688
11	.3361	.2614		1.5729	1.2793	1.2146	1.5546
12	.3734	.2263	1.3927	1.5497	1.2803	1.2803	1.5043
13	.3772	.2427	.3163	1.5684	1.3599	1.3763	1.3916
14	.3734	.2829	1.1717	1.3916	1.2967	1.2346	1.2651
15	.3734	.2987	1.2803	1.4403	1.3279	1.2346	1.2631
16	.3547	.3174	1.6194	.3361	1.2651	.3511	1.2308
17	.3734	.3734	1.5384	.852	1.3283	.3696	1.2955
18	.4294	.4338	1.2616	1.6244	1.3916		.415
19	.4854	.5281	.4668	.4904	.5228	.5373	.4904
20	.5601	.4854	.4668	.4904	.4854	.4668	.4904
21	.4668	.4715	.462	.4527	.462	.4572	.4527
22	.4481		.462	.4527	.4207	.4572	.4527
23	.4294		.4075	.4108	.4108	.462	.4527
24	.3772	.4294		.4294	.415	.4294	.4572
Max	1.643	1.6575	1.6194	1.6244	1.3916	1.3763	1.5546
Min	.3361	.2263	.2623	.3018	.2801	.3174	.3734
Avg	.7875	.8177	.8006	.7386	.7500	.6473	.7476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 203 / DEGAON (KD.)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.7095	.4687	.5601	.7209	.5975	.543
2	.7167	.7167	.6249	.7202	.7682	.5914	.5601
3	.7922		.7116	.7373	.8539	.6283	.6249
4	.8299	.8299	.8002	.9831	.9431	.7392	.9061
5	.9054	.9431	.9717	1.1934	.9709	.8871	1.1523
6	1.0185	1.0562	1.0364	1.4586	1.1576	.5975	1.4403
7	.8676	.9054	1.406	1.4918	1.5729	1.2498	1.5364
8	.7922	.811	1.1248	1.5364	1.6057	1.3117	1.3916
9	.6413	.679	1.1111	1.2651	1.4083	1.2498	1.1561
10	.6036	.4668	1.07	1.2037	1.2498	1.326	.5658
11	1.2498	1.307	.3018		.3749		.4108
12	1.358	1.307	.3018	.5658	.3749	.3429	.415
13	1.2498	1.1336	.2829	.5281	.4481	.3734	.4527
14	1.0974	1.0974	.3772	.5281	.4854		.4527
15	1.1111	1.1248	.4481	.5658	.5601		.4527
16	1.1111	1.1248	.4481	.5601	.5975	.5914	.4527
17	1.1728	1.2186	.6036	.679	.6535	.5914	.6036
18	1.2346	1.2193		.7468	.7468	.6653	.7167
19	.8029	.7468	.8962	.8676	.8962	.5914	.7922
20	.6722	.6535	.8215	.8299	.8402	.8871	.8299
21	.7468	.6161	.7762	.7545	.7023	.7316	.7545
22	.6908	.6224	.7392	.7468	.5853	.6584	.7167
23	.6908	.591	.7316	.7468	.5304	.6838	.7167
24	.679	.679	.6161	.7468	.7545	.5975	.5853
Max	1.358	1.307	1.406	1.5364	1.6057	1.326	1.5364
Min	.6036	.4668	.2829	.5281	.3749	.3429	.4108
Avg	.9047	.8939	.7248	.8703	.8251	.7568	.7595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 204 / KASARKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5228	.4687	.4801	.7537	.5601	.4887
2	.4904	.5281	.6249	.5601	.8002	.5544	.5228
3	.5281	.5601	.7116	.5735	.8539	.5544	.6249
4	.5658	.6413	.8002	.9503	.5658	.5544	.9061
5	.6036	.7095	.9717	1.2431	.6036	.5729	1.0242
6	.8299	.8215	1.2146	1.4918	.6348	.7655	1.1203
7	.7922	.8402	1.0623	1.5746	1.4091		1.1203
8		.7655	1.3592	1.3123	1.5402		1.4232
9	.679	.6602	1.25	1.012	1.3763	.7655	1.3435
10	.4527	.5041	1.1888	1.2346	1.2967	.5228	.4527
11	1.2498	.3734	.3395	.2641	.3401	1.1717	.3361
12	1.3117	.4715	.3584	.2641	.3734	1.1523	.3395
13	1.2193	1.2651	.3772	.2641	.3361	1.1523	.415
14	1.1584	1.2651	.3018		.3547		.4527
15	1.1883	1.3441	.3361	.3018	.3734		.3772
16	1.1883	1.3441	.3921	.4108	.3921	.462	.415
17	1.2346	1.3435	.4108	.5281	.5601	.462	.4904
18	1.2654	1.326	.6161	.6036	.6908	.5914	.6036
19	.7468	.7282	.7468	.7545	.5788	.6653	.6413
20	.6535	.5601	.6535	.7167	.5788	.6535	.5658
21	.5601	.5228	.5544	.6036	.5729	.5487	.6413
22	.5415	.5041	.462	.5658	.567	.5121	.5281
23	.5601	.4854	.4024	.5601	.4973	.5544	.5281
24	.4904	.5228	.4854	.4108	.5658	.5415	.5487
Max	1.3117	1.3441	1.3592	1.5746	1.5402	1.1717	1.4232
Min	.4527	.3734	.3018	.2641	.3361	.462	.3361
Avg	.8174	.7754	.6704	.7252	.6923	.6659	.6629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 201 / LAHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.3176	1.1145	.5487	.4801	.4908	.5716
2	1.3908	1.387	1.3889	.4801	.5144	.4854	.5335
3	1.5242	1.4403	1.7147	.4115	.5144		.4572
4	1.7909	1.491	1.7147	.4115	.5487		.4572
5	2.0957	1.5604	2.0233	.4801	.583		.5335
6	2.2862	1.6461	2.1091	.4801	.6001		.5335
7	1.9814	2.1948	2.332	.4801	.5144		
8	2.0576	1.5546	2.0576	.4641	.4801	.4854	
9	2.21	2.1548	2.2805	.4115	.4115	.4854	
10	1.9669	2.1376	2.3624	.3601	.3506	.381	1.6827
11	.3467	.3772	.381	2.1051	1.3717	2.3624	2.2885
12	.4161	.3429	.381	2.3482	2.4966	2.5149	2.4006
13	.4854	.3601	.381	2.2672	2.3739	2.4387	2.3739
14	.4854	.3647		2.2348	2.3061	2.3624	2.4006
15	.4854	.3315	.4572	2.0405	2.3061	.6478	2.3739
16	.4161	.3315	.4572	1.7976	2.332	.381	2.2192
17	.4161	.3647	.381	2.0405	2.332	2.5149	2.2634
18	.4207	.4144	.381		2.2382	2.5149	.4854
19	.4854	.4807	.5335	.5316	.4908	.4572	.5201
20	.5609	.5316	.6097	.583	.4908	.6097	.5609
21	.4908	.5144	.6097	.5658	.4854	.6097	.5548
22	.4207	.5487	.6097	.5487	.5609	.6097	.5609
23	.5609	.5144	.6097	.5144	.5548	.6097	.5609
24	.5716	.5609	.4801	.6097	.4801	.5548	.5716
Max	2.2862	2.1948	2.3624	2.3482	2.4966	2.5149	2.4006
Min	.3467	.3315	.381	.3601	.3506	.381	.4572
Avg	1.0500	.9551	1.1030	.9876	1.0757	1.1324	1.1859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 202 / CHABHARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4382	.4801	1.5432	1.286	.3898	.5716
2	.4954	.4382	.4801	1.6118	1.5432	.3814	1.829
3	.4763	.4382	.6001	1.7147	1.9204		1.9052
4	.5335	.4382	.6001	1.8861	.4115		2.2862
5	.5335	.5258	.6516	2.4006	1.7147		3.0483
6	.4572	.6935	.703	2.7435	2.7435		2.934
7	.4572	.5201	.5144	2.8121	2.915		3.0483
8	.4572		.4115	2.9172	3.0864	2.2291	3.2007
9	.0381		.2743	2.8509	2.8292	2.572	3.2388
10	.0347		.0381	2.2874		2.2862	
11	2.3739	.6001	.5716	.2058	.2427	.2667	
12	3.1722	.0343	3.1626		.2401	.2286	
13	3.0521	.6687	3.3913		.2601	.2667	
14	3.0007	.663	3.3913		.2572	.2667	
15	2.8826	1.4918	3.296		.2774	.3048	
16	2.8292	2.9835	3.4294		.2427	.3048	
17	2.7978	3.2322	3.4294		.2743	.4191	.3467
18		2.9835	3.6199		.2427	.4572	.4382
19	.5258	2.4034	.5716	.5316	.3506	.5335	.5201
20	.5258	2.0919	.4954	.5487	.3506	.5335	.4287
21	.4382	.4458	.5335	.463	.3506	.5335	.4334
22	.4382	.4801	.5335	.4458	.5144	.5335	.4382
23	.4382	.4287	.381	.4287	.5258	.5716	.4334
24	.4954	.4382	.4287	.4954	.4287	.5201	.5716
Max	3.1722	3.2322	3.6199	2.9172	3.0864	2.572	3.2388
Min	.0347	.0343	.0381	.2058	.2401	.2286	.3467
Avg	1.1717	1.0684	1.3329	1.5227	1.0003	.7157	1.5101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 203 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				1.5432		
11			2.8292			
24	.9526	.7802	.9526	.9431	.8764	.9526
Max	.9526	.7802	2.8292	1.5432	.8764	.9526
Min	.9526	.7802	.9526	.9431	.8764	.9526
Avg	.9526	.7802	1.8909	1.2432	.8764	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 204 / 11KV SONALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5959	.583	1.4403	.7716	.6379	.724
2	.6478	.5895	.583	1.4403	.9431	.631	1.2193
3	.5716	.5959	.6173	1.7147	1.1145		1.3336
4	.724	.631	.6859	1.8176	.6001		1.6004
5	.724	.7011	.7716	1.7833	1.286		1.9052
6	.6478	.7888	.8573	1.4746	1.8004		2.0195
7	.6478	.7888	.7373	1.4746	1.7147		2.0957
8	.6859	.663	.583	.3086	1.7147	1.7337	1.9814
9	.5716	.4858	.4801	.0343	1.3717	1.6289	1.3336
10	.5144	.4049	.5335		1.3565	1.7528	
11	1.6108	1.3717	1.6004	.4458	.4115	.4572	
12	1.95	.4115	1.9814		.4458	.381	
13	.5201	1.406	2.0195		.4508	.4572	
14	.5087	1.7404	1.8671		.4458	.4572	
15	1.8004	1.7328	1.8671		.4508	.4191	
16	1.8004	1.8067	1.9052		.4382	.381	
17	1.8404	1.8233	1.8671		.4854	.5335	.5548
18	1.7337	1.7404	1.8671		.5201	.4954	.5548
19	.7011	.6516	.8383	.7716	.6588	.6097	.6935
20	.7011	.7373	.8002	.7545	.631	.8002	.7011
21	.7087	.6859	.8002	.7373	.5895	.8002	.7011
22	.7011	.6516	.7621	.6859	.7011		.7011
23	.6173	.6173	.724	.6516	.6935	.724	.6935
24	.6859	.6241	.6001	.724	.6001	.6935	.724
Max	1.95	1.8233	2.0195	1.8176	1.8004	1.7528	2.0957
Min	.5087	.4049	.4801	.0343	.4115	.381	.5548
Avg	.9292	.9269	1.0805	1.0162	.8415	.7552	1.1492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 201 / PARDI (M) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	1.5364	1.109	1.0584	1.1328	1.1271	1.1317
2	1.7284	1.6964	1.1591	1.0594	1.1317	1.126	1.1317
3	1.8353	1.8564	1.2721	1.0616	1.1328	1.134	1.1317
4	1.8675	1.8976	1.4167	1.1753	1.1294	1.2411	1.2826
5	2.0333	2.0873	1.5821	1.3649	1.2787	1.3525	1.3957
6	2.5587	2.1872	1.9338	1.4378	1.4291	1.5013	1.5089
7	3.0911	2.7496	2.2005	1.3621	1.3512	1.3525	1.4335
8	3.0803	2.8121	2.1895	1.2132	1.1974	1.2787	1.1317
9	2.9012	2.284	2.3826	1.0509	1.052	.9808	.8124
10	2.6543	2.1251	2.8051	.8676	.7522	.7545	.6874
11	.4527	.6005	.6048	2.5667	2.769	.6036	2.4215
12	.4527	.6804	.7545	2.9271	3.1554	2.7831	2.1091
13	.5281	.6011	.5676	2.9061	3.2198	2.7831	2.1091
14	.6036		.5676	2.878	3.091	2.7831	2.9235
15	.7545	.6011	.5664	2.8601	3.0159	2.7496	3.0178
16	.8299	.6763	.9072	.7369	3.091		2.7673
17	.9808	.8266	.9828	2.1713	3.091		2.7673
18	.9808	1.0498	1.1694	2.9482	2.6402	2.8464	3.2065
19	1.2826	1.4291	1.4335	1.4364	1.4291	1.5089	1.4146
20	1.2696	1.2774	1.323	1.3901	1.3539	1.2826	1.4146
21	1.2071	1.2035	1.2839	1.2774	1.2774	1.2449	1.3203
22	1.1694	1.1271	1.2108	1.2398	1.2035	1.2071	1.3203
23	1.1694	1.1283	1.1718	1.2423	1.2035	1.1694	1.226
24	1.1317	1.1317	1.1271	1.1328	1.1271	1.126	1.1694
Max	3.0911	2.8121	2.8051	2.9482	3.2198	2.8464	3.2065
Min	.4527	.6005	.5664	.7369	.7522	.6036	.6874
Avg	1.5066	1.4593	1.3217	1.6402	1.8023	1.5426	1.7014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 202 / CHORAMBA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3027	.2987	.3006	.5802	.6023	.2633	.2614
2	.3024	.2614	.2633	.647	.6052	.263	.2614
3	.3024	.2614	.2633	.6401	.6363	.2627	.7095
4	.3018	.2614	.3006	.7025	.6241	.7131	.7274
5	.3402	.2987	.3009	.7432	.7973	.7176	.8539
6	.2635	.2427	.2646	.8116	.9015	.2633	.9061
7	.2254	.2427	.2257	.9863	1.0133	.2633	1.0974
8	.1886	.1867	.1504	1.1189	1.096	.2633	1.1279
9	.1132	.168	.1503	1.1029	1.1269	.6009	.7274
10	.1132	.1503	.1503	1.0462	1.1591	.759	.9804
11	1.0802	.9459	.8203	.1124	.1128	.7811	.1886
12	1.142	.1503	1.1702	.1126	.1503		.1886
13	1.142	1.0947	1.1772	.1503	.1504	.1509	.1886
14	1.1111	1.1416	1.1495	.1509	.1504		.1886
15	1.1111	.9337	1.1069	.1474	.1504		.1886
16	1.0494	1.0947	1.0818	.1474	.1504		.1509
17	1.0802	1.0625	1.0753	.1503	.1503	.2263	.1509
18	1.1248	1.0625	.9172	.1506	.1503	.2263	.1886
19	.2829	.3006	.189	.2646	.263	.2987	.2263
20	.3395	.3009	.3021	.3006	.3006	.3361	.2641
21	.3361	.3006	.3021	.3381	.3006	.3361	.2641
22	.3361	.3003	.3027	.3006	.263	.2987	.2641
23	.2987	.3003	.3024	.3012	.263	.2987	.2641
24	.3018	.2987	.3006	.3021	.3006	.2633	.2614
Max	1.142	1.1416	1.1772	1.1189	1.1591	.7811	1.1279
Min	.1132	.1503	.1503	.1124	.1128	.1509	.1509
Avg	.5496	.4858	.5236	.4712	.4758	.3793	.4429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 203 / Delub Bk SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6432	.679	.6017	1.1605	1.2681	.6017	.6036
2	.6993	.6348	.6017	1.2602	1.2742	.6017	.6036
3	.6419	.6348	.6017	1.3763	1.2727	.6011	1.2651
4	.679	.6348	.6763	1.0537	.5617	1.2879	1.3748
5	.7552	.7842	.7522	1.454	.6387	1.5455	1.4998
6	.9054	.9619	.7522	1.6232	.8299	.8266	1.5394
7	.7529	.7545	.7354	2.0141	2.0929	.8274	1.7833
8	.6763	.6413	.5883	2.1113	2.0582	.7537	1.7985
9	.6036	.6036	.5265	1.9537	2.0929	1.5181	1.8185
10	.4527	.4508	.3757	1.9022	2.0607	1.7711	2.119
11	1.7284	1.6961	1.5775	.1873	.3761	1.781	.3772
12	1.9136	.0376	1.8976	.1877	.3009		.3772
13	1.9372	1.8266	1.909	.3757	.3009		.3772
14	1.9685	1.8031	1.9159	.3685	.3009		.415
15	1.8827	1.8675	1.8704	.3685	.3753		.4527
16	1.7901	1.8675	1.9432	.4053	.3757		.4904
17	1.8519	1.9319	1.9159	.4508	.3761	.679	
18	1.8519	2.0607	1.8884	.64	.6017	.679	
19	.7545	.8274	.8316	.8694	.8274	.7545	
20	.7545	.7514	.7567	.7514	.7522	.7167	.7545
21	.679	.677	.6797	.6763	.6763	.7167	.7167
22	.679	.6804	.6811	.6763	.6763	.679	.679
23	.679	.677	.6804	.6776	.677	.6413	.6413
24		.679	.677	.6419	.6387	.6017	.6413
Max	1.9685	2.0607	1.9432	2.1113	2.0929	1.781	2.119
Min	.4527	.0376	.3757	.1873	.3009	.6011	.3772
Avg	1.0991	1.0068	1.0598	.9661	.8919	.9255	.9680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 201 / KAMTHA (BK.)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.679	.1886	.1509	.1829	.1886	.1698
2	.5658	.7356	.1886	.1509	.2054	.1886	.1698
3	.6602	.8488	.2075	.1509	.2241	.2075	.1886
4	.7545	.8488	.2263	.1698	.2427	.2263	.2075
5	.7545	.9054	.2452	.1886	.2801	.2452	.2075
6	.8488	.9619	.2829	.2075	.2801	.2641	.2263
7	.9431	.9619	.2452	.2075	.2427	.2452	.2263
8	.9619	.9054	.2075	.2075	.2427	.2263	.2263
9	.9619	.9054	.1886	.1886	.2218		.2075
10	.9054	.9054	.1698	.1886	.1886		.7356
11		.1509	.8299	.7316	.7545	.679	.9054
12	.1698	.132	.8676	.8402	.8299	.7922	.8488
13	.1509	.132	.8676	.8402	.8488	.7922	.8488
14	.1698	.1509	.8488	.8402	.8299	.7922	.8488
15	.1698	.1509	.8488	.8402	.7545	.7922	.8488
16	.1698	.1509	.8488	.1086	.7167	.1698	.8865
17	.1886	.1886	.9808	.7316	.8299	.1698	.8865
18	.2075	.2075	.9808	.8402	.8488	.8488	.1886
19	.2263	.2263	.2263	.2353	.2075	.1886	.2452
20	.2263	.2452	.2452	.2743	.2452	.2075	.2452
21	.2075	.2452	.2452	.2378	.2452	.2075	.2452
22	.2075	.2263	.2452	.2195	.2452	.1886	.2452
23	.1886	.2075	.2263	.2195	.2263	.1698	.2263
24		.1698	.2263		.2012	.1886	.2263
Max	.9619	.9619	.9808	.8402	.8488	.8488	.9054
Min	.1509	.132	.1698	.1086	.1829	.1698	.1698
Avg	.4638	.4684	.4432	.3813	.4206	.3627	.4275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 202 / GANPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.7356	.1509	.9431	.9335	.1698	.1509
2	.132	.7922	.4527	1.1317	1.0269	.1698	.1509
3	.132	.7922	.5093	1.226	1.0642	.1698	1.1317
4	.1509	.8488	.5093	1.3203	.1494	1.0374	1.4146
5	.1509	.9054	.5658	1.4146	.2241	1.226	1.5278
6	.1886	.2263	.5658	1.5089	.2427	.2829	1.6975
7	.1886	.2263	.3961	1.6975	1.4003	.2829	1.6975
8	.2263	.2263	1.4146	1.7918	1.1012	1.6032	1.5844
9	.1698	.2075	1.6032	1.6598	1.5497	1.5844	1.5089
10	.1698	.1886	1.3392	1.5089	1.3203	1.358	.132
11	1.4146	.0943	.0943	.1097	.132	.1132	.1132
12	1.5844	.0943	.0943	.1267	.132	.1132	.1132
13	1.5844	1.1317	.0943	.128	.132	.1132	
14	1.6409	1.0374	.132	.128		.1132	
15	1.6409	1.4146		.1097		.132	
16	1.6975	1.6032		.128		.1132	
17	1.6975	1.7353	.1509	.128	.2075	.132	
18	1.7541	1.6598	.2263	.1463	.2263	.1509	.2452
19	.2641	.2452	.2452	.2195	.2452	.1886	
20	.2263	.2075	.1886	.2195	.2452	.2263	.2452
21	.2263	.1886	.1698	.1829	.2263	.2263	.1886
22	.1886	.1509	.1509	.1829	.1698	.2075	.1509
23		.1509	.1509	.1646	.1698	.1886	.1509
24			.1509		.1478	.1698	.1509
Max	1.7541	1.7353	1.6032	1.7918	1.5497	1.6032	1.6975
Min	.132	.0943	.0943	.1097	.132	.1132	.1132
Avg	.7073	.6462	.4252	.7033	.5260	.4197	.6864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 203 / NANDUSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-APR-17	30-APR-17	01-MAY-17	02-MAY-17	03-MAY-17	04-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9054	.1132	.1132	.1109	.1132	.0943
2	.9431	1.0185	.0943	.1132	.0934	.1132	.0943
3	1.1317	1.1317	.0943	.0943	.0934	.132	.1132
4	1.226	1.1317	.1132	.0943	.0934	.132	.1132
5	1.3203	1.2449	.1132	.0943	.112	.1509	.1132
6	1.4146	1.4146	.1132	.0943	.112	.1509	.132
7	1.5089	1.4146	.1132	.1132	.1097	.132	.132
8	1.5089	1.358	.1132	.1132	.1097	.1132	.1132
9	1.4523	1.4146	.0943	.0943	.1109		.0943
10	1.4712	1.358	.0754	.0943	.0754		.9054
11			1.2637	1.1088	1.2826	.9054	1.2826
12	.0754		1.3957	1.1458	1.3014	1.1317	1.2449
13	.0754			1.2136	1.3203	1.1317	1.226
14	.0754	.0943		1.2936	1.2826	1.1317	1.226
15	.0754	.0943	1.3957	1.2696	1.1317	1.1883	1.3203
16	.0754	.0943	1.3957	.0914	1.0562	.0943	1.3392
17	.0754	.0943	1.3957	.8402	1.2449	.0943	1.3392
18	.0943	.1132	1.3769	1.2696	1.1317	1.2449	.0943
19	.1132	.1132	.132	.128	.1132	.132	.132
20	.132	.132	.132	.1463	.1509	.132	.132
21	.132	.132	.132	.1463	.132	.132	.132
22	.1132	.132		.128	.132	.1132	.3961
23	.1132	.132	.132	.128	.1132	.1132	.132
24		.0943	.132		.1097	.1132	.132
Max	1.5089	1.4146	1.3957	1.2936	1.3203	1.2449	1.3392
Min	.0754	.0943	.0754	.0914	.0754	.0943	.0943
Avg	.6396	.6485	.4724	.4316	.4801	.3952	.5014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-17 and 05-MAY-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 324085 / 33/11 KV DONGARKADA

Feeder No / Name : 205 / 11KV EXPRESS GANESH STONE NON SHEDDABLE EXPRESS HV FEEDERS
 CRUS Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAY-17	02-MAY-17	03-MAY-17	05-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1143	.1524		.1143
9	.1143	.1524	.1524	.1524
10	.1143	.1524	.1905	.1143
11	.0381	.0762	.1143	.0381
12	.1905	.1524	.1524	.1143
13	.1524	.1524	.1524	.1524
14	.1524	.1524	.1524	
15	.0381	.0381		.1524
16	.1143		.1143	.1524
17	.1905		.1524	.1524
18	.1524	.1524	.1524	.1905
19	.0762	.1524	.0381	
Max	.1905	.1524	.1905	.1905
Min	.0381	.0381	.0381	.0381
Avg	.1207	.1334	.1372	.1334