

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 202 / 11 KV KHAMBORA ,EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.197	.2058	.2195		.1543	.2096
2	.1905	.197	.2058	.2195		.1715	.2096
3	.1905	.197	.2058	.2195		.1867	.2286
4	.1905	.197	.2241	.2195		.168	.2286
5	.2096	.197	.2058	.2263		.1543	.2286
6	.2477	.2507	.2743	.2378		.2572	.2286
7	.2286	.2507	.2743	.2378		.2572	.2286
8	.2477	.2865	.2572	.1463		.2401	.2477
9	.2477	.2149	.2229			.2614	.1905
10	.2477	.2865	.3206			.2229	.2667
11	.4116	.2926	.3206	.1372	.1433		.2667
12	.2058	.2561	.3403	.1372	.1433	.2667	.2858
13		.3292	.3403	.1372	.1433	.2667	.3048
14	.2058	.3109	.3224	.1543	.1433		.2667
15	.2058	.3109	.2686	.1867	.1433		
16	.2058	.3109	.3224	.168	.1433		.3048
17	.2401	.3206	.3224	.1372	.1372		
18	.3045	.2926	.1829	.1433	.1372		.2858
19	.2865	.2572		.1433	.1543	.2641	.1905
20	.2865	.2572		.1791	.1543	.2641	.2286
21	.2865	.2572		.1791	.3086	.2561	.2286
22	.2507	.2572		.1433	.2572	.2641	.1524
23	.2149	.2572	.2263	.1509	.2572	.2012	.2096
24	.1905	.197	.2572	.2263		.1372	.2096
Max	.4116	.3292	.3403	.2378	.3086	.2667	.3048
Min	.1905	.197	.1829	.1372	.1372	.1372	.1524
Avg	.2385	.2575	.265	.1795	.1743	.2219	.2364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 203 / 11 KV PALSO

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.5194	.7202	.7316	1.105	1.4937	1.2197
2	.6099	.5014	.7202	.7316	1.086	1.5123	1.2382
3	.6099	.5014	.7468	.695	1.105	1.4937	1.2567
4	.6099	.5014	.7468	.695	1.0669		.4435
5	.6099	.5014	.6516	.7133		.6287	.4066
6	.6099	.5373	.6516	.6767	.8383	.5335	.4251
7	.6653	.5731	.6516	.6401	.8573	.4954	.4066
8	.499	.6089	.6859	.6767		.4801	1.1389
9	.5544	.6268	.6859			.8589	.462
10		.1254	.6908			.5144	1.4089
11	.4805	.7499		.1029	.5731		1.6057
12	.5975	.8413	.6805	.6859	.6089	.462	1.587
13	.6161	.823	.7164	.7373	.591	.5175	1.5684
14	.6348	.695	.7343	.7545			1.5497
15	.6535	.7682	.8059	.7888			
16	.6001	.823	.7701	.7373	.5373	.5175	
17	.6516	.7499	.7701	.6859	.6173	.4854	
18	.6805	.823	.7682	.6268	.1372	.3734	.5359
19	.7164	.8962		.8238	.6687	.5487	.5906
20	.8954	.8402		.8238	.8029	.695	.6838
21	.8954	.8402		.8238	.7373	.7133	.6653
22	.8238	.8402		.8059	1.286	.7316	.6348
23	.6805	.8059	.7682	.7682	1.3717	.6584	.5914
24	.6099	.6984	.7545	.7316	1.0098	1.3717	1.1827
Max	.8954	.8962	.8059	.8238	1.3717	1.5123	1.6057
Min	.4805	.1254	.6516	.1029	.1372	.3734	.4066
Avg	.6484	.6746	.7221	.7026	.8333	.7543	.9334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 204 / 11 KV KANSHIVANI,AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0179		.7716	1.105	
2		.0179		.7545	1.086	
3		.0179		.7373	1.105	
4		.0179		.7716	1.0669	
5		.0179		.7316	1.0288	
6		.0179	.0171	.6401		
7		.0179		.7682	.8383	
8	.0191	.0179		.7682	.8383	
9		.0179			.8573	
10		1.0924	.0191		.0191	
11	1.1203		.0191	.0171	.0179	
12	1.0349		.0179		.0179	
13		1.5089	.0179		.0179	
14	1.4003	1.2174	.0179			
15	1.3256	1.2346	.0179			
16	1.2003	1.2517	.0179			
17	1.1488	1.3717	.0179			
18	.0179	.0183	.0189	.0179		
19	.0179	.0149				.0191
20	.0179	.0149		.0179		.0191
21	.0179	.0171		.0179		.0191
22	.0179	.0171		.0179		.0191
23	.0179	.0067	.0189	.0189		.0191
24		.0179	.0067	.823	1.0098	
Max	1.4003	1.5089	.0191	.823	1.105	.0191
Min	.0179	.0067	.0067	.0171	.0179	.0191
Avg	.5659	.3611	.0173	.4582	.6929	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 206 / 11 KV Rajeshwar Express. HV Non-Express Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0038	.0029		.0057	.0381	.0191	.0061
2	.0038	.0029		.0029	.0381	.0191	.0061
3	.0038	.0029		.0029	.0381	.0191	.0122
4	.0038	.0179		.0029		.0191	.0122
5	.0038	.0029		.0029	.0381	.0191	.0122
6	.0038	.0179	.0067	.0057	.0381	.0191	.0122
7	.0038	.0179	.0067	.0057	.0381	.0191	.0122
8	.0038	.0179		.0029	.0381		.0061
9	.0038	.0029			.0381		.0061
10		.0057	.0061		.0381		.0061
11	.007	.0029	.0171	.0067	.0057		.0061
12	.0038	.0029	.0179	.0067	.0057	.0061	.0061
13		.0057	.0057	.0067	.0057	.0061	.0185
14		.0057	.0057	.0067	.0057		.0061
15		.0057	.0057	.0067			
16		.0057	.0057	.0067	.0057	.0038	
17	.0046	.0029	.0057	.0061	.0067	.0038	
18	.0029	.0057	.0057	.0029	.0067	.0061	.0061
19	.0029	.0067		.0029		.0029	.0061
20	.0029	.0067		.0029		.0029	.0061
21	.0029	.0067		.0029		.0029	.0061
22	.0029	.0067		.0029		.0029	.0061
23	.0029	.0067	.0029	.0029		.0029	.0061
24	.0038	.0029	.0067	.0029	.0381		.0061
Max	.007	.0179	.0179	.0067	.0381	.0191	.0185
Min	.0029	.0029	.0029	.0029	.0057	.0029	.0061
Avg	.0037	.0069	.0076	.0045	.0249	.0102	.0081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 207 / 11 KV KANSHIVANI GAVTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4477	.4287	.695	.5335	.2896	
2	.4294	.4477	.4287	.695	.5335	.2972	
3	.4294	.4477	.4287	.6584	.4954	.2629	
4	.4294	.4477	.4115	.6219	.4954	.2134	
5	.4294	.4477	.4115	.5853	.5335	.181	
6	.3921	.4477	.4115	.5487	.4763	.1848	
7	.3734	.4477	.4115	.6036	.381		
8	.3696	.4477	.4287	.7133	.362	.2401	
9		.4477	.4287		.3239	.2614	
10	.4066	.4298	.4108		.2858		
11	.4435		.4108	.0171	.2686		
12	.4435		.4656		.3224	.2402	
13		.6219	.394		.3761	.2587	
14	.4805	.5121	.3761				
15	.4805	.5487	.6805	.4287			
16	.4458	.567	.8059	.4668	.394	.3734	
17	.4458	.567	.8059	.3734	.4108	.3734	
18	.5194	.6413	.8596	.2149	.4108	.3881	.4435
19	.4835	.0187			.4801		.5228
20	.5373	.6173		.591	.5144		.7095
21	.5552	.5658		.591	.4801		.5415
22	.5194	.5144		.591	.3772		.4668
23	.5014	.5228	.7499	.5487	.3734		.4481
24	.4435	.4656	.4668	.7316	.5335	.3658	
Max	.5552	.6413	.8596	.7316	.5335	.3881	.7095
Min	.3696	.0187	.3761	.0171	.2686	.181	.4435
Avg	.4549	.4828	.5108	.5375	.4255	.2807	.5220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 208 / 11 kv BORGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.2894	1.3443	1.2071	1.3527	1.1576	1.1203
2	1.307	1.2894	1.3443	1.2254	1.3336	1.1576	1.0829
3	1.307	1.2894	1.307	1.2071	1.3336	1.1203	1.0829
4	1.307	1.2894	1.307	1.2071	1.2955	1.0829	1.0269
5	1.2883	1.2894	1.307	1.1888	1.2003	.9709	1.0269
6	1.2323	1.2894	1.2696	1.1706	1.1812	.9149	1.0456
7	1.1203	1.2536	1.2136	.9328	1.086	.8402	.9896
8	.9335	1.2178	1.3443	.823	1.0288	.8962	.9335
9	1.4937	1.2894	1.419		1.086	.8962	.9335
10	1.1088	1.1462	1.531		1.448	.8962	.9335
11	1.1203	1.1706	1.6057	1.8671	1.3611		.9335
12	.9335	1.1157	1.6476	1.6057	1.5402	1.419	1.0269
13	1.0829	1.2254	1.6476	1.6804	1.576	1.307	1.2323
14	1.2696	1.0974	1.5402	1.643	1.5043		1.0456
15	.0747	1.134	1.7193	1.7177	1.5402		1.1203
16	.0686	1.1888	1.8625	1.531	1.576	1.307	
17	1.307	1.0791	1.5043	1.3375	1.6057	1.1827	
18	1.1641	1.2986	1.1523	.8238	1.1203	1.0456	.9335
19	1.0745	1.307		1.1462	1.2136	1.0974	1.0269
20	1.2894	1.2136		1.182	1.363	1.0974	1.0642
21	1.2536	1.307		1.2178	1.2003	1.0974	1.1203
22	1.2536	1.3817			1.2136	1.0974	1.2323
23	1.2178	1.3443	1.2803	1.2803	1.1576	1.1157	1.1812
24	1.363	1.3253	1.419	1.2437	1.3717	1.0974	1.1088
Max	1.4937	1.3817	1.8625	1.8671	1.6057	1.419	1.2323
Min	.0686	1.0791	1.1523	.823	1.0288	.8402	.9335
Avg	1.1199	1.2430	1.4383	1.2971	1.3204	1.0856	1.0546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 405 / 33 KV AMIBIKA EXPRESS

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0453	.0784	.4527	.8688	.8514	.8631
2	.0554	.0679	.056	.5093	.8459	.8738	.8459
3	.0554	.0679	.056	.5093	.8631	.773	.8688
4	.0554	.0679	.056	.5093	.8688	.6273	.8802
5	.0554	.0679	.0672	.5093	.8802	.5321	.9031
6	.0554	.0679	.056	.5093	.8345	.5433	.8427
7	.0554	.0679	.0616	.5093	.5258	.4145	.8631
8	.0554	.0679	.0504	.4527	.7259	.2969	.9145
9	.0499	.0537	.056		.8002	.1344	.423
10	.0514	.0566	.0629		.8116	.1064	1.0345
11	.056	.0566	.08	.801	.8035		1.046
12	.056	.0566	.0792	.8738	.8035	.0572	1.0288
13	.056	.0566	.0679	.8402	.481	.0572	1.0745
14	.056	.0566	.0622	.829	.8092		1.0288
15	.056	.0566	.0849	.7394			1.1317
16	.0504	.0566	.0849	.7898	.8035		
17	.0504	.0566	.0905	.8346	.8402	.6973	
18	.0509	.0566	.1188	.7299	.9074	.8059	.9717
19	.0622	.056		.8261	.9074		.9717
20	.0679	.056		.8261	.9634		.9431
21	.0679	.056			.8402		.8573
22	.0679	.0566		.8148	.8066		.8631
23	.0679	.0672	.3452	.8261	.745		.8573
24	.0686	.0622	.0784	.3961	.8459	.8402	.823
Max	.0686	.0679	.3452	.8738	.9634	.8738	1.1317
Min	.0499	.0453	.0504	.3961	.481	.0572	.423
Avg	.0574	.0599	.0846	.6709	.8079	.5074	.9107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 409 / J.J.Fine Express

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2883	1.3411	1.2	1.358	1.4289	1.2883	1.4861
2	1.2883	1.3807	1.4563		1.4289	1.4003	1.4289
3	1.2883	1.3863	1.4003		1.4289	1.2883	1.4003
4	1.2883	1.3863	1.4395		1.3717	1.2883	1.4563
5	1.2883	1.3863	1.4563		1.4289	1.3611	1.3717
6	1.2883	1.3863	1.3331		1.4861	1.2883	1.5432
7	1.2323	1.3163	1.4115		1.0288	1.4003	1.3717
8	1.3443	1.3863	1.4283		1.3146	1.4003	1.3146
9	1.3443	1.3241	1.4115		1.1883	1.4003	.8002
10	1.3306	1.0751	1.166		1.1883	1.3443	1.2574
11	1.3306	1.1317	1.3832	1.2043	1.182		1.3146
12	1.2752	1.2449	1.4825	1.1819	1.2449	1.1373	1.2574
13	1.2197	1.2449	1.4429	1.3387	1.2279	1.2003	1.2574
14	1.2197	1.1883	1.3128	1.1203	1.3863		1.1431
15	1.2752	1.2449	1.9408	1.3891	1.2675		1.2003
16	1.1763	1.3014	1.3354	1.2435	1.4316	1.4227	
17	1.2323	1.4146	1.3863	1.3107	1.4003	1.2917	
18	1.4599	1.2449	1.4146	.3225	1.3443	1.3203	1.286
19	1.3524	1.3331		1.3071	1.2995		1.2574
20	1.3524	1.214		1.4769	1.3331		1.2574
21	1.3241	1.1875	1.0751	1.4429	1.5011		1.2574
22	1.3863	1.1371	1.4146	1.3637	1.2547		1.2231
23	1.4655	1.4955	1.4146	1.3014	1.5292		1.2574
24	1.3546	1.3354	1.3947	1.358	1.4289	1.4003	1.4861
Max	1.4655	1.4955	1.9408	1.4769	1.5292	1.4227	1.5432
Min	1.1763	1.0751	1.0751	.3225	1.0288	1.1373	.8002
Avg	1.3086	1.2953	1.3955	1.2479	1.3385	1.3270	1.3013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 201 / 11 KV GHUSAR FDR .

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5914	.6348	.7023	.5975	.5228	.4668
2	.5601	.5544	.5601	.7095	.5975	.4854	.4668
3	.5601	.5601	.5601	.7095	.5975	.4854	.4668
4	.5601	.5544	.5601	.6535	.5788		.4668
5	.5601	.5544	.5601	.6468	.5788		.4668
6	.5041	.499	.5415	.5975	.5601		.4668
7	.5788	.6468	.4854	.5228	.4481		.4108
8	.6348	.7392	.5228	.7392	.5601		.5041
9	.5973	.724	.5415			.2241	.4854
10		.724	.5973		.2126		.3921
11	.6335	.724	.5973	.724	.2686		.4668
12	.4887	.7602	.724	.7164	.4344	.2172	.4854
13	.4938	.7602	.7783	.4835	.5068		.4668
14	.7682	.8145	.7602	.5194		.4119	.4481
15	.7421	.7602	.6335	.5194			
16	.724	.8145	.7964	.5194			.3921
17	.7421	.8145	.7095			.4108	
18	.7207	.7468	.7947		.7282		.4706
19	.7762	.7655	.9149	.8402	.8215	.5975	.6335
20	.9425	.9896	.924	.8962	.8962	.7282	.788
21	.924	.9522	.9055	.9149	.7842	.6535	.7522
22	.8316		.7577	.8589	.7095	.5788	.4477
23	.7392		.7577	.7468	.6348	.5228	.4298
24	.6348	.6653	.6908	.7392	.6161	.5601	.4854
Max	.9425	.9896	.924	.9149	.8962	.7282	.788
Min	.4887	.499	.4854	.4835	.2126	.2172	.3921
Avg	.6642	.7143	.6795	.6880	.5859	.4922	.4936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 202 / 11 KV MHAISANG FDR . Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.6733	.8589	.7602	.7842	.6535	.5975
2	.6722	.6878	.8589	.7602	.7842	.6535	.5975
3	.6722	.7023	.8589	.7602	.7842	.6348	.5788
4	.6722	.6878	.8589	.7602	.7468	.6161	.5788
5	.6722	.724	.8589	.724	.7468	.5975	.5788
6	.6348	.724	.8402	.6697	.6722	.5601	.5601
7	.6348	.6516	.7468	.7421	.6161	.4668	.5415
8	.7282	.6154	.8589	.7421	.5975	.3921	.5601
9	.724	.8869	.9335		.5788	.4481	.5041
10		.905	.905		.5552		.5788
11	.8145	.905	.905	.8145	.543		.5041
12	.8507	.905	.9412		.6335		.4854
13	.8145	.9362	.8413	.5249	.5552	.3582	.4668
14	1.0136	.9536	.8688	.5068		.394	.4481
15	.9412		.8962				.5228
16	.905	1.0576	.9231	.6154		.4119	.4668
17	.905	.9955	.8145		.591		
18	.9114	1.0642	.7783		.8215	.5975	.4706
19	.9465	1.1016	.9231	1.0829	.9149	.6161	.6516
20	1.1218	1.2323	.9979	1.363	.9709	.6908	.7522
21	1.0985	1.1576	.9979	1.2883	.9335	.7095	.7164
22	.9816	.9522	.9795	1.0456	.8962	.6535	.6805
23	.9114	.8775	.8059	.9335	.8029	.6161	.6626
24	.7468	.8505	.8775	.7964	.8215	.6908	.5975
Max	1.1218	1.2323	.9979	1.363	.9709	.7095	.7522
Min	.6348	.6154	.7468	.5068	.543	.3582	.4481
Avg	.8297	.8803	.8804	.8272	.7310	.5664	.5696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 203 / 11 KV Ghusar W/W Express. Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0474	.0492	.0474	.0164	.0158	.0158	.0158
2	.0474	.0492	.0474	.0164	.0158	.0158	.0158
3	.0474	.0492	.0474	.0164	.0158	.0158	.0158
4	.0474	.0492	.0474	.0164	.0158	.0158	.0158
5	.0474	.0492	.0474	.0164	.0158	.0158	.0158
6	.0474	.0492	.0474	.0164	.0158	.0158	.0158
7	.0474	.0492	.0158	.0164	.0158	.0158	.0158
8	.0474	.0492	.0158	.0164	.0158	.0158	.0158
9	.0474	.0474	.0158		.0158	.0158	.0187
10		.0474	.0158				.0158
11	.0474	.0474	.0158	.0158	.0158		.0158
12	.0474		.0158	.0158	.0158	.0158	.0158
13	.0474	.0316	.0158	.0158	.0158	.0158	.0158
14	.0474	.0316	.0158	.0158		.0158	.0158
15	.0474	.0316	.0158	.0158			.0158
16	.0474	.0316	.0158	.0158	.0158	.0158	.0158
17	.0474	.0316	.0164		.0158	.0158	
18	.0492	.0316	.0164		.0158	.0158	.0158
19	.0492	.0316	.0164	.0158	.0158	.0158	.0158
20	.0492	.0316	.0164	.0158	.0158	.0158	.0158
21	.0328	.0316	.0164	.0158	.0158	.0158	.0158
22	.0492	.0474	.0164	.0158	.0158	.0158	.0158
23	.0492	.0474	.0164	.0158	.0158	.0158	.0158
24	.0474	.0492	.0474	.0164	.0158	.0158	.0158
Max	.0492	.0492	.0474	.0164	.0158	.0158	.0187
Min	.0328	.0316	.0158	.0158	.0158	.0158	.0158
Avg	.0472	.0419	.0252	.0161	.0158	.0158	.0159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 204 / 11 KV Jaiguru Express.

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189		.0189		.0189	.0189
2	.0189		.0189		.0189	.0189
3	.0189		.0189		.0189	.0189
4	.0189		.0189		.0189	.0189
5	.0189		.0189		.0187	.0189
6	.0189		.0189		.0189	.0189
7	.0189		.0189		.0189	.0189
8	.0189				.0189	.0189
9	.0187				.0189	.0189
10			.0187			.1132
11	.0187					.0754
12					.0187	.0189
13	.0187				.0187	.0189
14	.0187				.0179	.0189
15	.0187					.0189
16	.0187				.0187	.0189
17	.0181				.0189	
18	.0185			.0189	.0189	.0187
19	.0187			.0189	.0189	.0187
20	.0187			.0189	.0189	.0187
21	.0187			.0189	.0189	
22		.0189		.0189	.0189	.0187
23		.0189		.0189	.0189	.0187
24	.0189		.0189		.0189	.0189
Max	.0189	.0189	.0189	.0189	.0189	.1132
Min	.0181	.0189	.0187	.0189	.0179	.0187
Avg	.0188	.0189	.0189	.0189	.0188	.0257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 205 / RAMGAON 11 KV FEEDER
Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3696	.4481	.4066	.4108	.3921	.3734
2	.4108	.3696	.4481	.4108	.4108	.3921	.3734
3	.3734	.3734	.4481	.4108	.4108	.3734	.3734
4	.3734	.3696	.4481	.4108	.4108	.3734	.3734
5	.3734	.3734	.4481	.4108	.4108	.3734	.3734
6	.3734	.3696	.4481	.4108	.4108	.3547	.3921
7	.3547	.3696	.3921	.3361	.3547	.3547	.3547
8	.3734	.3734	.3734	.2957	.3547	.3361	.3174
9	.3801	.362	.3734		.3174	.3734	.3361
10		.362	.3258				.2801
11	.2896	.362	.3258	.2896	.2172		.2614
12	.2534	.3258	.2534	.2534	.2149		.2054
13	.2534	.3258	.2896	.2896	.2534	.2172	.2054
14	.2896	.362	.2896	.2896		.181	.2054
15	.3258	.362	.2896	.2896			.2241
16	.3258	.362	.2896	.2896	.2507	.2149	.2241
17	.2896	.2896	.2218		.2507	.2241	
18	.3734	.3734	.2957		.2987	.3174	.2507
19	.3734	.4108	.3696	.3921	.3547	.3174	.2865
20	.4435	.4668	.4435	.4854	.4294	.3921	.4298
21	.4435	.5041	.4481	.4481	.4108	.3921	.4298
22	.4435	.5041	.4435	.4294	.4108	.3734	.3582
23	.4481	.4668	.4066	.4294	.4108	.3734	.3224
24	.4108	.3696	.4481	.4066	.4108	.3921	.3734
Max	.4481	.5041	.4481	.4854	.4294	.3921	.4298
Min	.2534	.2896	.2218	.2534	.2149	.181	.2054
Avg	.3646	.3824	.3737	.3692	.3526	.3359	.3184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 201 / 11 KV HINGNA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4572	.4904	.4191	.4115	.4294	.4715
2	.3429	.4572	.4715	.4191	.4115	.415	.4527
3	.3429	.4191	.4715	.4191	.4115	.4108	.4527
4	.3429	.4191	.4527	.4191	.4115	.415	.415
5	.3429	.4572	.4527	.4191	.4115	.4715	.4338
6	.3429	.4572	.4527	.4191	.4115	.4904	.415
7	.3772	.5335	.5281	.4763	.5144	.4715	.4904
8	.3944	.5335	.4715	.4572	.4287	.4904	.4527
9	.4763	.4763	.4904	.5716	.4115	.4338	.415
10	.5716	.5281	.4115	.5281		.4572	
11	.4191	.4527	.4287	.5093			
12	.4191	.4904	.4115		.4191	.4572	
13	.4191	.4715	.3429	.5175	.4572	.4954	
14	.4572	.4904	.4115	.5093	.4572	.4572	
15	.5716	.4904	.5716	.6161	.4954	.4763	
16	.5716	.5658	.5335	.6036	.5716	.5658	
17	.5716	.5281	.5335	.5487	.5093	.5658	
18	.5716	.5281	.5335	.4115	.5093	.5281	.3772
19	.4191	.4715	.4191	.4115	.415	.5281	.4287
20	.5716	.5281	.4954	.3944	.4715	.4904	.3944
21	.4191	.5093	.4572		.5093	.4904	.4458
22	.4954	.5093	.4572		.4904	.4904	.4287
23	.4572	.4904	.4572		.4527	.4904	
24	.3258	.4572	.4904	.4191	.4458	.4338	.4715
Max	.5716	.5658	.5716	.6161	.5716	.5658	.4904
Min	.3258	.4191	.3429	.3944	.4115	.4108	.3772
Avg	.4403	.4884	.4682	.4744	.4558	.4763	.4363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 203 / 11 KV RUHATIYA EXP.

HV Express Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0189	.0191	.0191	.0191	.0191
8		.0191	.0191	.0191	.0171	.0191	.0191
9	.0191		.0189	.0191	.0191	.0191	.0189
10	.0191	.0191	.0191	.0191		.0191	.0191
11	.0191	.0191	.0191	.0191			.0191
12	.0191	.0191	.0191		.0191	.0191	.0191
13	.0191	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191	.0191	.0191		.0191
16	.0191	.0191	.0191	.0191	.0191	.0191	.0191
17	.0191	.0189	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191		.0191	.0191	.0191
22	.0191	.0191	.0191		.0191	.0191	.0191
23	.0191	.0191	.0191		.0191	.0191	
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0189	.0189	.0191	.0171	.0191	.0189
Avg	.0191	.0191	.0191	.0191	.0190	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 204 / 11 KV HINGANA-AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3018	.724	.5144		
2			.3018	.724	.5144		.0191
3			.2829	.724	.5144		
4			.2829	.724	.5144		
5			.2829	.724	.5144		
6			.3018	.8383	.6001		
7			.9808	1.0288	.6687		
8			1.0562	.9526	.7202		
9			1.094	.8383	.6859		
10	.8764	.4904					
11	.8764	.9431					
12	.9145	.9808				.2667	
13	.8383	.8676				.1905	
14	.8764	.8299		.0191		.3048	
15	.5335	.8676					
16	.4191	.8865				.3018	
17	.4572	1.0185				.3018	
24			.3018	.724	.5487		
Max	.9145	1.0185	1.094	1.0288	.7202	.3048	.0191
Min	.4191	.4904	.2829	.0191	.5144	.1905	.0191
Avg	.7240	.8606	.5187	.7292	.5796	.2731	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 201 / 11 kv Sangvi Mohadi

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.8145	.9774	.905	.985	.5792	.5068
2	.8869	.8145	.8145	.8954	1.0566	.543	.5068
3	.8688	.8048	.8145	.8688	1.0566		.5068
4	.8507	.7865	.8145	.8596	1.0745		.4835
5	.8869	.7602	.8145	.8238	1.0387		.5068
6	1.086	.7602	1.086		1.0208		.543
7	1.2127	.9412	1.1584		1.0029		.5068
8	1.2308	1.1403	1.2308		1.1462		.5068
9	1.3575	1.3213			1.1462		.4706
10	1.0136	1.379			1.2308		.4706
11	.9412	1.4327	1.5565				.4706
12	1.086		1.5927	1.086	1.1222		.4656
13	1.267		1.5927	.9412	1.2308	.0179	.5014
14	1.2308		1.5203	.9412	1.267	.0358	.5068
15	1.2308	1.4842		.7602	1.0498		.5014
16	1.2308	1.4661	1.448		1.0136		.5014
17	1.2986	1.448	1.3394		1.0498	.724	.5014
18	1.2071	1.448		1.5043	.7964	.6878	.5194
19	1.3032			1.3253	.905	.6878	.5373
20	1.267		1.5927	1.3969	.7964	.6154	.6626
21	1.1946	1.267	1.448	1.1462	.724	.5792	.7522
22	1.0498	1.2308		1.1104	.6516	.5792	.6805
23	.8869	1.086	.9774	.985	.6154	.543	.4835
24	.905	.8326	1.0136	.905	.9313	.5792	.5068
Max	1.3575	1.4842	1.5927	1.5043	1.267	.724	.7522
Min	.8507	.7602	.8145	.7602	.6154	.0179	.4656
Avg	1.0999	1.1167	1.2107	1.0284	.9962	.5143	.5250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 202 / 11 kv Ugwa

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0317	1.0317	1.1946	1.182	1.086	.9774	.7701
2	.9774	1.0317	1.1765	1.1462	1.0498	.9955	.7522
3	.9231	1.0242	1.1765	1.0924	1.0317	.9231	.7522
4	.8869	1.0242	1.0498	1.0745	1.0136		.7164
5	.9231	.9955	1.0498	1.0387	.9955		.7343
6		.9593	1.0136	.9671	1.0136		.6805
7	.905	.905	1.0136	.9492	.9955		.591
8	.905	.9955	.8507	.9671	.9774	.1448	.6268
9	.9955	1.0679	.8326	.9671	.8688	.2172	.6447
10	.9412	1.086	.8145		.8059	.2534	.6516
11	.7964	1.267	.8326			.1991	.724
12	1.086	1.1403	.8145	.905	.591	.543	.724
13	1.0317	.9231	.3439	1.0136	.6089		.7421
14	1.1222	.9412	1.086		.6626	.6335	.724
15	1.1222						.724
16	1.267		1.1641	.7602			.5068
17	1.134	1.2127	1.0208	.9313	.905	.6626	.2896
18	1.0974	1.1584	1.0566	.9955	.905	.6268	.8779
19	1.1041	1.267	1.2357	.7964	1.0136	.788	.8326
20	1.3756	1.4118		.9774	1.086	.8596	1.086
21	1.3213			1.2127	1.086	.8775	
22	1.2851			1.2127	1.0498	.8596	.2534
23	1.1584	1.3032	1.3073	1.2127	.9774	.8059	.2353
24	1.0679	1.0679	1.2851	1.182	1.1946	.9774	.7701
Max	1.3756	1.4118	1.3073	1.2127	1.1946	.9955	1.086
Min	.7964	.905	.3439	.7602	.591	.1448	.2353
Avg	1.0634	1.0907	1.0159	1.0292	.9485	.6673	.6700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 203 / 11 kv Gandhigram

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0029	.543	1.3575	1.3969	1.4449	.724	.7164
2	1.0136	.5121	1.3032	1.3611	1.0974	.6878	.6805
3	.9955	.5121	1.3032	1.2715	1.0974	.6878	.6447
4	.9955	.4938	1.1765	1.1999			.6268
5	1.0679	.4706	1.1765	1.1462	1.0608		.6089
6	1.0498	.362	1.1765	1.0387	1.0425		.5731
7	1.0317	.4163	1.267	1.0387	1.0242		.5373
8	1.0136	.6516	1.5927	1.0745	1.0974	.2561	.788
9		.724	1.7924	1.3611	1.0242	.5121	.7522
10	1.5023	1.6461	1.8107		1.0387	.5853	.7964
11	1.448					.6401	.8326
12					1.0029	.5304	.8413
13	1.4118	1.8473	1.8473		1.1104	.6036	.695
14	1.5565	1.8473	1.4632	1.6651		.6401	.8413
15	1.6289	1.828	1.4148	1.7375	1.2536		.8413
16		1.828	1.2536	1.4842	1.086		.8048
17			1.7193	1.39		.7164	.8596
18			1.8267	1.3169	1.086	.788	.7865
19		1.6651	1.8983	.695	1.1946	.9313	.8417
20	.9231	1.8823	2.0058	.6584	1.086	.8954	.8779
21	.7783	1.8099	1.7193	1.5364	1.086	.8238	.9145
22	.6697	1.7194		1.5181	.9412		.6401
23	.6154			1.4815	.4344	.7522	.6219
24	1.0136	.543		1.3969	1.4449	.7964	.7164
Max	1.6289	1.8823	2.0058	1.7375	1.4449	.9313	.9145
Min	.6154	.362	1.1765	.6584	.4344	.2561	.5373
Avg	1.0955	1.1212	1.5318	1.2884	1.0827	.6806	.7433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 201 / 11 kv sarawa gavthan
Feeder KV- 11 / OUTGOING

Gaathan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3239	.2858	.3109	.362	.3239	.3239
2	.3077	.3239	.2858	.3109	.362	.3239	.3239
3	.2896	.3239	.2858	.3109	.3429	.3239	.3239
4	.2896	.3239	.2858	.2926	.3429	.3429	.3239
5	.3258	.3429	.2858	.2926	.362	.3429	.3239
6	.3801	.381	.381	.3475	.381	.3429	.362
7	.4207	.362	.2858	.3109	.4382	.4382	.362
8	.3898	.4001	.2667	.3841	.3239	.4763	.4954
9	.4163	.5335	.2858	.4887	.4382	.5906	.4572
10	.4382	.5792		.6859		.2477	
11	.5335	.5731	.3048	.6097		.5144	.362
12	.6668	.5731	.3048	.6097	.543	.6287	.5525
13	.5335	.6516	.2667	.7049	.4344		.6859
14		.5973		.5716	.3801		.5144
15	.6097	.6516		.5525	.5792		.724
16	.7621	.5544	.362	.7621	.6097	.7049	.6478
17	.7621	.724		.5906	.6287	.6859	.7621
18	.6478	.4954	.3696	.5335	.5335	.724	.6668
19	.4954	.4572	.3696	.4763	.4382	.381	.4382
20	.4191	.381	.3696	.362	.362	.381	.381
21	.4001	.3429	.3841		.3429		.3429
22	.3429	.362	.3658	.381	.3429	.3429	.3429
23	.3429	.3429	.3109	.381	.3239	.3429	.3429
24	.3077	.3239	.3239	.3109	.381	.3239	.3429
Max	.7621	.724	.3841	.7621	.6287	.724	.7621
Min	.2896	.3239	.2667	.2926	.3239	.2477	.3239
Avg	.4517	.4552	.3190	.4600	.4206	.4391	.4523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 202 / 11 kv eranda gavthan
Feeder KV- 11 / OUTGOING

Gaathan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.2477	.2286	.2477	.2286	.2096
2	.2477	.2667	.2477	.2286	.2477	.2286	.2096
3	.2477	.2667	.2477	.2286	.2286	.2286	.2096
4	.2667	.2667	.2477	.2286	.2286	.2286	.2096
5	.2667	.2858	.2477	.2477	.2477	.2477	.2096
6	.2858	.2858	.2667	.2477	.2667	.2477	.2477
7	.2858	.3429	.2477	.2286	.3048	.2096	.2286
8	.1143	.3048	.2096	.1905	.2096	.1905	.2096
9	.1143	.2477	.2477	.2286	.2667	.1905	.1905
10	.2667	.2667	.1715	.2096		.1905	
11		.2896	.1524	.2096		.1524	.1715
12	.2858	.1829	.1715	.2096	.2149	.2286	.2667
13	.2858	.1715	.1715	.1905	.2149		
14	.3239	.2743	.1715	.2477	.2477		.2858
15	.3048	.2378	.1524	.1905	.3258		.381
16	.3429	.2667	.1715	.2286	.2096	.2286	.362
17	.4001	.1905		.2286	.1715	.2286	.3048
18	.3048	.2477	.1905	.2477	.2286	.1524	.2477
19	.3239	.2286	.2477	.2667	.2667	.2667	.3048
20	.362	.2477	.2858	.2858	.3048	.2858	.2858
21	.3048	.2667	.2667	.2858	.2667		.2667
22	.3239	.2667	.2667	.2667	.2477	.2286	.2477
23	.2858	.2477	.2477	.2667	.2286	.2286	.2477
24	.2477	.2667	.2477	.2286	.2667	.2286	.2286
Max	.4001	.3429	.2858	.2858	.3258	.2858	.381
Min	.1143	.1715	.1524	.1905	.1715	.1524	.1715
Avg	.2800	.2577	.2228	.2342	.2474	.2210	.2511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 203 / 11 kv katkeda ag
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4725	.6478	.6668	.5428	.6478	.4572	.2286
2	.4725	.6287	.6668	.5428	.6097	.4572	.2286
3	.4725	.6287	.6287	.5428	.6097	.4572	.2286
4	.4572	.6478					.2286
5	.4877	.6859					.2286
6	.4725	.7811					.3048
7	1.0479	1.2003					.3048
8	.9907	1.7147					.381
9	.9907	1.5623					.3429
10			1.4289	1.6194		.4382	
11			1.4861	1.8671		.4001	
12			1.7147	1.6766	1.2498	.5144	
13			1.7718	1.6956	1.0974		
14			1.6575	1.5432	1.0212		
15			1.5242	1.448	1.0669		
16	1.2955	1.4083	1.5813	1.5051	1.3717	.5906	.7621
17	1.5242	1.5432	1.5813	1.086		.5716	.7811
18	1.7337	1.6385	1.0669	1.0479	.724	.4191	.7811
19	1.4861	1.4098	1.0517	.9907	.743	.3048	.7621
20	1.2574	1.1812	.945	.8192	.6668	.2858	.5906
21	1.0288	1.0098	.8215	.724	.6287		.4954
22	.8192	.7811	.7482	.6859	.5906	.2667	.4572
23	.7049	.743	.5573	.6668	.4954	.2667	.4572
24	.4725	.6478	.6859	.5287	.6668	.4572	.3429
Max	1.7337	1.7147	1.7718	1.8671	1.3717	.5906	.7811
Min	.4572	.6287	.5573	.5287	.4954	.2667	.2286
Avg	.8993	1.0478	1.1436	1.0851	.8126	.4205	.4392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024051 / 33/11kv kanshivani

Feeder No / Name : 201 / 11kv Rahit Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9816	1.0288	.9602	.9922		.7545
2	1.166	.964	.8688	.9602	.9922		.7545
3	1.0288	.964	.8383	.9602	.9745		.7545
4	1.0288	.9568	.9431	.9602	.9214		.4287
5	1.0288	.929	.9259	.9602	.8859		.7202
6	.9602	.929	.8916		.8505		.6859
7	.8573	.9114	.8402		.8238		.6001
8	.7716	.9214	.8745		.7164		.7373
9	1.0288	.9816	.9431		.788		.6001
10	1.0117	.9536	.9189		.8238		.5316
11	1.0117	.6588	.9709	.9259	.7716		.5658
12	1.0802	.6415	.9816	.9088	.7716		.4973
13		.8322	.964	.9602	.823		.5487
14	1.1145	.8402	.8764	.9431	.7545	.5609	.6001
15	1.1145	1.1317	.9536	.2915	.8573		.6173
16	.6344	1.1317		.3086	.8745	.7011	.6687
17	.9882	.6344	1.0288	1.0229		.6516	.6344
18	.9709	1.046	.8573	.964		.6173	.6687
19	1.0117	1.1145	.9945	.7362		.7373	.7545
20	1.1488	1.3375	1.1831	1.2269		.8059	.8322
21	1.1831	1.2689	1.1831	1.2048		.8745	1.0454
22	1.0802	1.166	1.0974	1.1568		.823	.964
23	1.0402	1.0974	.9945			.7716	.9036
24	1.0288	.9709	1.0288	.9602	1.0208		.7545
Max	1.1831	1.3375	1.1831	1.2269	1.0208	.8745	1.0454
Min	.6344	.6344	.8383	.2915	.7164	.5609	.4287
Avg	1.0138	.9735	.9647	.9117	.8613	.7270	.6926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024051 / 33/11kv kanshivani

Feeder No / Name : 202 / 11kv Rahit Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9145	.9145	.3658
2			.9145	.945	.3658
3			.9145	.945	.3658
4			.9145	.9568	
5			.9145	.9877	
6			.8993	.9907	
7			.9755	.9907	
8			1.0364	1.0031	
9			1.0212	.9602	.2286
10	.6036	.9686			.3048
11	.7956	1.1111			.3353
12	.7287	.9877			
13		.9374			.2896
14	.823	.945			.3048
15	.7926	.9602			.7164
16	.7926	.8383			.6706
17	.9221	1.0669			.7011
18	.8718				.788
19					.6706
24			.9145	.884	.4115
Max	.9221	1.1111	1.0364	1.0031	.788
Min	.6036	.8383	.8993	.884	.2286
Avg	.7913	.9769	.9419	.9578	.4656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024051 / 33/11kv kanshivani

Feeder No / Name : 203 / 11kv Deoli AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9145	.9686	.4725
2			1.0288	.953	.4725
3			.9145	.9686	.4725
4			.9145	.9962	.3048
5			.9145	.9722	.4725
6			.9145	.9686	.4268
7			.9755	.9568	.4115
8			1.0212	1.0311	.6554
9			1.0212	.9374	.7373
10	1.0014	1.1265			.7011
11	1.286	1.2967			.7468
12	1.028	1.2967			.5944
13	1.0364	1.0467			.6401
14	1.0517	.9755			.6249
15	1.0059	1.0669			.5487
16	1.0974	1.1584			.6554
17	1.2071	1.1126			.6706
24			.9602	.9686	.4725
Max	1.286	1.2967	1.0288	1.0311	.7468
Min	1.0014	.9755	.9145	.9374	.3048
Avg	1.0892	1.135	.9579	.9721	.5600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 201 / 11 KV BALAPUR

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1807	2.1948	2.3152		2.268	2.1216	1.9589
2	2.1437	2.1948	2.2405		2.2314	2.0119	1.9589
3	2.1068	2.1948	2.2405		2.2314	2.0119	1.9959
4	2.0698	2.1948	2.2405		2.1948	1.9387	1.9959
5	2.0328	2.1948	2.2405		2.1948	1.9022	1.9959
6	2.0328	2.1216	2.2405		2.1948	1.8656	1.9959
7	1.885	1.9387	2.1658		2.1216	1.9387	2.0698
8	1.7924	1.8656	2.0328	2.0328	2.0485	1.829	
9	1.7924	1.7558	1.9044	1.885	1.9753	1.829	2.0698
10	1.7924	1.7558	1.885	1.922	1.9022	1.9387	
11	1.8656		1.885	1.829		1.6827	2.2177
12	1.9387		1.9044	1.7924	1.7372	1.6827	1.922
13	1.9022		1.9044	1.829	1.885	1.5729	1.922
14	1.9022		1.9044	1.9387	1.1827	1.5364	1.5893
15	1.9022		1.9418	1.9753	1.7372	1.5364	1.5524
16	1.9022		1.9418		1.7002	1.5364	1.7002
17	1.9387			2.0119	1.7558	1.7558	1.6827
18	1.9022			1.3535	2.0485	1.829	1.885
19	2.0851			2.2314	2.1948	1.9753	2.1068
20	2.3777	2.5019		2.4508	2.2314	2.0119	2.3285
21	2.3777	2.4646		2.4508	2.1948	2.1948	2.2546
22	2.3777	2.5393		2.4143	2.1216		2.1437
23	2.3411	2.5393		2.3777	2.1216	2.0485	2.1068
24	2.2177	2.268	2.3899	2.3899	2.3045	2.0119	1.9387
Max	2.3777	2.5393	2.3899	2.4508	2.3045	2.1948	2.3285
Min	1.7924	1.7558	1.885	1.3535	1.1827	1.5364	1.5524
Avg	2.0358	2.1816	2.0810	2.0553	2.0251	1.8592	1.9723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 202 / 11 KV PARAS

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.4161					
2	.5121	.4214					
3	.4481	.3913					
4	.5121	.3913					
5	.5121	.3913					
6	.5121	.3612					
7	.8322	.4816					
8	.7316	.8429					
9	.8535	1.0235					.0152
10			1.1584	1.1584	.8642		
11			1.3245	1.2193			
12			1.2041	1.3413	1.1111		
13			1.2342	1.2803	1.0494	.3048	
14			1.2643	1.2193	.9755	.3048	
15			1.3108	1.0974	.8535	.3048	
16			1.3413		.7621	.3658	
17				.3048	.5556	.1829	
21						.2439	
23						.2439	
24	.5121	.4161					
Max	.8535	1.0235	1.3413	1.3413	1.1111	.3658	.0152
Min	.4481	.3612	1.1584	.3048	.5556	.1829	.0152
Avg	.5938	.5137	1.2625	1.0887	.8816	.2787	.0152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 204 / 11 KV PALASI GAUTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2263	.2218		.2263	.2054	.2218
2	.1848	.2263	.2218		.2263	.2054	.2218
3	.1848	.2263	.2218		.2263	.2054	.2218
4	.1848	.2263	.2218		.2263	.2054	.2218
5	.1848	.2263	.2218		.2263	.2054	.2218
6	.1848	.2263	.2614		.2263	.2054	.2218
7	.1848	.2263	.1867		.2075	.1867	.1848
8	.1848	.2263	.1867	.2054	.1698	.2241	.1848
9	.1848	.1886	.1867	.2054	.132	.1886	.1478
10	.1478	.1848	.1494	.168	.1132	.1886	.1109
11	.1478		.1494	.168		.1886	.1132
12	.1886		.168	.1663	.1509	.1509	.112
13	.1698			.1663	.1509	.1509	.1494
14	.1698			.1848	.1509	.1509	.1494
15	.1698			.2033	.132	.1509	.1494
16	.1886		.2054	.1663	.132	.1509	.1494
17	.1509			.2033	.168	.1494	.1829
18	.1848			.2012	.2241	.1715	.1829
19	.2033			.2195		.1867	.2195
20	.2641	.2587		.2561	.2614	.2241	.2743
21	.2641	.2587		.2561	.2427	.2241	.2743
22	.2641	.2587		.2195	.2427	.2241	.2743
23	.2452	.2587		.2195	.1867	.2241	.2641
24	.2218	.2263	.2241		.2263	.2054	.2241
Max	.2641	.2587	.2614	.2561	.2614	.2241	.2743
Min	.1478	.1848	.1494	.1663	.1132	.1494	.1109
Avg	.1950	.2297	.2019	.2006	.1931	.1905	.1949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 206 / 11 KV MANN EXPRESS

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191		.0191	.0191	.0191
2	.0191	.0191	.0191		.0191	.0191	.0191
3	.0191	.0191	.0191		.0191	.0191	.0191
4	.0191	.0191	.0191		.0191	.0191	.0191
5	.0191	.0191	.0191		.0191	.0191	
6	.0191	.0191	.0191		.0191	.0191	.0191
7	.0191	.0191	.0191		.0191	.0191	.0191
8	.0164	.0191	.0191	.0492	.0191	.0191	.0191
9	.0492	.0497	.0492	.0492	.0503	.0492	.0492
10	.0492	.0497	.0469	.0509	.0492	.0492	
11	.0492		.0497	.0509		.0492	.0497
12	.0503		.0497	.0497	.0497	.0492	.0486
13	.0497		.0469		.0497	.0492	.0486
14	.0503		.0497		.0497	.0492	.0486
15	.0503		.0497		.0497	.0492	.0486
16	.0497		.0497	.0497	.0497	.0492	.0486
17	.0503			.0497	.0503	.0492	.0492
18	.0497			.0486	.0503	.0492	.0492
19	.0497			.0486	.0503	.0492	.0492
20	.0497	.0486		.0486	.0503	.0492	.0492
21	.0497	.0486		.0486	.0503	.0191	.0492
22	.0497	.0486		.0486	.0503	.0191	.0492
23	.0497	.0486		.0486	.0168	.0191	.0492
24	.0492	.0191	.0492		.0503	.0191	
Max	.0503	.0497	.0497	.0509	.0503	.0492	.0497
Min	.0164	.0191	.0191	.0486	.0168	.0191	.0191
Avg	.0394	.0310	.0349	.0493	.0378	.0342	.0390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 207 / 11 KV VYALLA AGRICULTURE
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.2561		.3239	.1875	.0191
2	.0191	.0191	.2561		.3239	.1875	.0191
3	.0191	.0191	.2561		.2591	.1875	.0191
4	.0191	.0191	.2561		.2591	.1875	.0191
5	.0191	.0191	.2561		.2591	.1875	.0191
6	.0191	.0191	.2561		.2591	.1875	.0191
7	.0191	.0191	.2561		.3239	.1875	.0191
8	.0191	.0191	.3201	.3563	.3887	.1562	
9	.0191	.0191	.3841	.3887	.3887	.1875	.0191
10	.2286	.2561	.0191	.0162	.0191	.0191	.128
11	.16		.0191	.0191		.0191	.16
12	.16		.0191	.0191	.0191	.0191	.1829
13	.192		.0191	.0191	.0191	.0191	.1829
14	.2241		.0191	.0191	.0191		.1829
15	.2561		.0191	.0191	.0191		.2134
16	.3201		.0191	.0191	.0191	.0191	.1829
17	.3201			.0191	.0191	.0191	
18	.0191			.0191	.0191	.0191	
19	.0191			.0191	.0191	.0191	.0191
20	.0191	.0191		.0191	.0191	.0191	.0191
21	.0191	.0191		.0191	.0191	.0191	.0191
22	.0191	.0191		.0191	.0191	.0191	.0191
23	.0191	.0191		.0191	.0191	.0191	.0191
24	.0191	.0191	.3239		.3239	.1875	.0191
Max	.3201	.2561	.3841	.3887	.3887	.1875	.2134
Min	.0191	.0191	.0191	.0162	.0191	.0191	.0191
Avg	.0903	.0349	.1738	.0631	.1460	.0942	.0714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 208 / 11 KV PALASI AGRICULTURE

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.583		.5761	.096	.0572
2	.0953	.0953	.583		.5761	.096	.0572
3	.0953	.0953	.583		.5761	.096	.0572
4	.1143	.0953	.583		.6401	.096	.0762
5	.1143	.0953	.583		.6401	.096	.0762
6	.1143	.0953	.583		.6173	.096	.0762
7	.0953	.0762	.9069		.8642	.08	.0762
8	.0953	.1334	.9717	1.1203	.8025		.0572
9	.0953	.1334	1.0364	1.2803			.0381
10	.759	.9488	.0572	.2286	.0572		
11	.8539		.1143	.1905			
12	.8855		.1143	.1524	.0953		.2469
13	.8539			.1334	.0762		.5556
14	.7907		.0191	.1334	.0762		.5556
15	.6958		.0762	.1143	.0762	.0381	.5556
16	.759		.0762	.0572	.0762	.0381	.5556
17	.759						.6173
18	.0762			.0381			.0762
19	.1143			.0953		.0572	.0762
20	.1143	.1524		.1143	.1143	.0762	.0953
21	.1143	.1334		.1143	.1334	.0762	.0953
22	.1143	.1334		.1334	.1524	.0762	.1143
23	.0953	.1334	.5121	.1334	.1143	.0572	.1143
24	.0953	.0953	.5182		.5121	.0926	.0572
Max	.8855	.9488	1.0364	1.2803	.8642	.096	.6173
Min	.0762	.0762	.0191	.0381	.0572	.0381	.0381
Avg	.3331	.1674	.4647	.2693	.3566	.0779	.1949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 209 / 11 KV BALAPUR AGRICULTURE

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6167	.0316		.0324	.0324	.176
2	.6401	.6009	.0316		.0324	.0324	.192
3	.6401	.6009	.0316		.0324	.0324	.192
4	.6401	.6009	.0316		.0324	.0324	.192
5	.6722	.6009	.0316		.0324	.0324	.192
6	.6722	.5693	.0316		.0324	.0324	.192
7	.9122		.0316		.0324	.0324	.192
8	.9602	.5376	.0316	.032	.0324	.0324	.176
9	.9922	1.0437	.0316	.032	.0324	.0324	.2241
10	.016	.0158	.0474	1.1843	.7611	.3563	
11	.0191		.4744	1.4083		.3239	.016
12	.0158		1.5023	1.5203	.9717	.2753	.016
13	.0158		1.4232	1.4723	.8907	.3239	.016
14	.0158		1.2334	1.4403	.9717	.3563	
15	.0158		1.2651	1.3763	.9717	.3563	.016
16	.0158		1.4232	.8802	.5668	.3563	.016
17	.0158			1.2003	.7773		.048
18	.0316			.0324	.0162		.048
19	.0158			.0324	.0324	.0324	.048
20	.0316	.0316		.0324	.0324	.0312	.032
21	.0316	.0316		.0324	.0324	.0312	.032
22	.0316	.0316		.0324	.0324	.0312	.032
23	.0316	.0316		.0324	.0324	.0312	.032
24	.6722	.6325	.048		.0324	.0324	
Max	.9922	1.0437	1.5023	1.5203	.9717	.3563	.2241
Min	.0158	.0158	.0316	.032	.0162	.0312	.016
Avg	.3227	.4247	.4530	.6713	.2788	.1286	.0991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 401 / 33KV Balapur/Wadegaon
Feeder KV- 33 / INCOMING

DIVISION FEEDER

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.048	5.1578	7.4897		7.4074	4.9931	4.784
2	5.048	5.1578	7.4897		7.4074	4.9931	4.784
3	4.7325	5.1578	7.4897		7.4074	4.9931	5.1029
4	4.7325	5.1578	7.1777		7.4074	4.9931	5.1029
5	5.048	5.1578	7.1777		7.4074	4.9931	5.1029
6	5.3635	5.1578	7.1777		7.4074	4.9931	5.1029
7	4.417	4.513	8.738		9.465	4.9931	4.465
8	3.786	4.513	9.9863	9.8457	9.465	4.513	3.8272
9	3.4705	3.8683	9.3622	9.8457	9.1495	3.2236	3.8272
10	7.4589	8.0556	3.2236	3.7449	3.546	4.8354	5.4218
11	7.1605		3.546	3.1207	.695	4.8354	5.1852
12	6.7044		3.2236	2.9321	2.3457	4.8354	4.8971
13	6.9959		3.2236	3.2579	3.1893	4.8354	4.8971
14	7.2874		3.8683	3.5837	3.1893	4.8354	5.1852
15	7.8704		3.8683	3.9095	3.5082	4.8354	5.4733
16	7.8704		3.8683	4.2353	3.5082	5.5876	5.8299
17	6.9959			3.9095	3.4328	5.3635	6.2414
18	3.7449			3.9529	4.0569	5.2675	3.7449
19	4.0569			4.6811	4.9931	4.7325	4.6811
20	5.6173	5.8025		5.6173	5.3052	4.784	5.3635
21	5.7407	6.1248		5.6173	5.3052	5.1029	5.3635
22	5.7407	6.1248		5.6173	5.3052	5.4218	5.3635
23	5.4218	5.8025		5.5556	4.9931		5.1029
24	5.3635	5.4801	7.8018	7.7161	7.4074	4.9931	4.784
Max	7.8704	8.0556	9.9863	9.8457	9.465	5.5876	6.2414
Min	3.4705	3.8683	3.2236	2.9321	.695	3.2236	3.7449
Avg	5.6532	5.4154	6.1595	5.1260	5.5544	4.9110	4.9847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 201 / 11 KV NIMBA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916		1.7147	1.6461		.4801
2	.8916		1.7147	1.5775		
3	.8916		1.7147	1.5775		
4	.8916		1.7147	1.0288		
5	.8916		1.7147	1.0288		
6	.8916		1.7147	.9088		
7	.8916		1.7147	.9088		
8			2.0576	.9602		
9			2.2291	.9602		
10			2.4006	1.0288		
11	2.0233	2.0576	2.6063		.3086	.4801
12	1.989	2.4691	2.6749		.2743	.4801
13	1.8861	2.6063				.3772
14	1.9204	2.4691			.2743	.4115
15	1.9719	2.4691	2.5377		.3086	.4115
16	1.989	2.7435			.3429	.4115
17	1.989	2.8121	1.3717		.3429	.4801
18	1.989		2.1262		.3086	.4801
19	2.0233		3.0864		.4801	.4801
20		2.6063	2.7435		.4801	.4801
21		2.1262	2.4006		.4801	.4801
22		1.7147	1.7147	1.6461	.4801	.4801
23		1.7147	1.6804		.4801	.4801
24	.8916		1.7147	1.6461		.4801
Max	2.0233	2.8121	3.0864	1.6461	.4801	.4801
Min	.8916	1.7147	1.3717	.9088	.2743	.3772
Avg	1.4655	2.3444	2.0642	1.2431	.3801	.4595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 202 / 11 KV KARANJA RAMJANPUR Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487		.8916	.7545		.4115
2	.5487		.8916	.7545		.4115
3	.5487		.8916	.823		.3772
4	.5487		.8916	.6859		.3772
5	.5487		.8916	.6859		.3772
6	.5487		.8916	.6859		.3429
7	.5487		1.0288	.6173		.3429
8			1.3717	.6173		.2572
9				.6173		.4801
10				.6859		.4115
11		1.2003	1.3375		.2743	.5144
12		1.3717	1.3717		.2743	.5487
13		1.4403	1.2003		.3086	.5487
14		1.406	1.166		.3429	.6173
15					.3429	.7545
16					.3429	.7545
17					.3429	.6516
18		1.5432			.4287	.6516
19		1.6118	1.4403		.463	.5144
20		1.6461	1.4575		.4801	.4801
21		1.5432	1.4575		.4458	.4801
22		1.2346	.8573		.4287	.4801
23		.8916	.7716		.4115	.4801
24	.5487		.8916	.7545		.4115
Max	.5487	1.6461	1.4575	.823	.4801	.7545
Min	.5487	.8916	.7716	.6173	.2743	.2572
Avg	.5487	1.3889	1.0945	.6984	.3759	.4865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 204 / 11 KV ANTARI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916		1.0974	1.0288		.5316
2	.8916		1.0974	1.166		.5316
3	.8916		1.0974	1.0631		.5144
4	.8916		1.0974	1.0631		.5144
5	.8916		1.0974	1.0631		.3429
6	.6173		1.0974	1.1145		.3429
7	.8916		1.1317	1.1145		
8			1.2346	1.1145		.2743
9				.9259		.3086
10						.2915
11		1.5775	1.4575	1.4575	.4115	.3772
12		1.5775	1.4232	1.4232	.4115	.4115
13		1.5089	1.5261	1.5261	.4801	.3772
14		1.5432	1.5604	1.5604	.5144	.4115
15		1.5775	1.5775	1.5775	.5316	.4115
16		1.6461	1.0802	1.0802	.5658	.4115
17		1.7833	1.2517	1.2517	.5658	.4801
18		1.7833			.6001	.4801
19		1.749	1.1145	1.1145	.6173	.4801
20		1.6461	1.286	1.286	.6344	.4801
21		1.4403	1.3889	1.3889	.6516	.4115
22		1.3375	1.3717	1.3717	.6001	.4115
23		1.0974	1.286		.5658	.4115
24	.8916		1.0974	1.0288		.5316
Max	.8916	1.7833	1.5775	1.5775	.6516	.5316
Min	.6173	1.0974	1.0802	.9259	.4115	.2743
Avg	.8573	1.5590	1.2558	1.2248	.55	.4234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 201 / 11 KV NIMKARDA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.4858				.3841	
2	.5068	.4934				.3704	
3	.4778	.5068				.3841	
4	.4778	.5144					
5	.4633	.5144					
6	.4778	.5144					
7	.5792	.5213					
8	.724	.6371					
9	.7827	.6516					
10			.7407		.8368		
11			.8505		.9002		
12			.8345	.7956	.8573		
13			.7956	.7819	.8288		
14			.6859	.8802	.7716		.2858
15			.7133		.7573		
16			.7819	.7682	.5858		
17			.8093	.8779	.5716		
18						.2195	
24	.5213	.4923				.3704	
Max	.7827	.6516	.8505	.8802	.9002	.3841	.2858
Min	.4633	.4858	.6859	.7682	.5716	.2195	.2858
Avg	.5518	.5332	.7765	.8208	.7637	.3457	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 202 / 11 KV IOC

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1698	.1509		.1698	.2263	
2	.1698	.1698	.1509		.1698	.2641	
3	.1698	.1509	.1698		.1698	.3018	
4	.1509	.1509			.1698		
5	.1509	.1698	.1509		.1509	.2263	
6	.132	.0943	.132	.1132	.0754	.1509	
7	.0943	.0943	.0754	.0943	.0566	.0754	.0943
8	.0754	.1132	.0754	.0754	.0754	.0754	.0754
9	.3018	.1509	.1543	.1509	.1132	.1698	.1132
10	.2829	.0943	.1886		.1509	.1886	.1886
11	.1698	.0943	.1509		.1886	.2263	
12	.1132		.1509	.2452	.2075	.2263	
13	.1886	.1132	.1132	.1886	.3206	.0754	.0566
14	.2263	.0943	.2075	.1886	.2829	.132	.1132
15	.1886	.0943	.2829		.2641	.1509	.1132
16	.1294	.0754	.2263	.3206	.2075	.1509	.1509
17	.1698	.0754	.0754	.1698	.0943	.0754	.0943
18	.1132	.0943		.1509		.0754	.0943
19	.1509	.0739	.0943	.1698	.1132	.132	.132
20	.1886	.1698	.132	.1698	.1698	.2829	.1698
21	.1886	.1509	.2075	.1509	.1698	.2075	.1698
22	.1698	.1509	.2263	.1698	.1698	.2263	.1698
23	.1698	.1698	.1886	.1698	.1698	.2641	.1698
24	.1886	.0943	.1698	.132	.1509	.1698	.2263
Max	.3018	.1698	.2829	.3206	.3206	.3018	.2263
Min	.0754	.0739	.0754	.0754	.0566	.0754	.0566
Avg	.1697	.1221	.1579	.1662	.1657	.1771	.1332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 203 / 11 KV GAIGAON

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0716		.0701		
2			.061		.0701		
3			.0772		.0701		
4			1.3306		.0701		
5			.0732		.0701		
6			.0701	.0838	.0789		
7			.0772	.1006	.1052		
8			.0701	.1097	.1052		
9			.1029	.1097	.1052		
10	.0876	.0876				.048	.0351
11	.1343	.1052				.048	
12	.1075	.1052				.048	
13	.1075	.0964				.048	.0282
14		.1189				.064	.0328
15	.1254					.064	.0985
16	.1075	.1164				.048	.0343
17	.1227	.1164				.048	.0351
24		.1052	.0701	.0857	.0876		
Max	.1343	.1189	1.3306	.1097	.1052	.064	.0985
Min	.0876	.0876	.061	.0838	.0701	.048	.0282
Avg	.1132	.1064	.2004	.0979	.0833	.052	.044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 204 / 11 KV HATRUN FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2186		.9214		
2			1.1873				
3			1.1385				
4			1.1203				
5			1.0936				
6			1.0212	1.0242			
7			1.2193	1.2793			
8			1.1584	1.2616			
9			1.2346	1.3435			
10	1.2803	1.4586					.6249
11	1.2811	1.2631					
12	1.2654						
13	1.2186	1.491				.1486	.8796
14	1.2498	1.4413			.2439	.1783	.8802
15	1.2186				.301	.1932	.7343
16	1.2498				.6097	.1635	.703
17	2.2862	1.6078				.1783	.7907
18						.2667	
19						.4001	
24		1.4918	1.247	1.0526	.9214		
Max	2.2862	1.6078	1.247	1.3435	.9214	.4001	.8802
Min	1.2186	1.2631	1.0212	1.0242	.2439	.1486	.6249
Avg	1.3812	1.4589	1.1639	1.1922	.5995	.2184	.7688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 205 / 11 KV NIMKARDA G

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.4415	1.386		1.5154	1.3306	
2	1.3121	1.386	1.386		1.4415	1.2936	
3	1.3121	1.3676	1.3676		1.4415	.6838	
4	1.2936	1.3306	1.3306		1.423	.6838	
5	1.3121	1.3306	1.3306		1.3676	.6468	
6	1.2567	1.2936	1.3676	1.2936	1.4045	.5729	
7	1.0164	1.2936	1.1506	1.0719	1.3306	.4805	.961
8	.924	1.2197	1.0719	.961	1.1458	.462	.8686
9	.9795	1.2197	1.0719	1.1088	1.0349	.4435	.8316
10	.9979	1.1643	.9979		1.0349	.924	.8871
11	.9979	.9979	1.0349		.924	.924	
12	1.0164	.9795	1.0349	.961	.8871	.7392	
13	1.0349	.9425	.961	.924	.9795	.7762	.8501
14	1.1088	1.0534	1.1088	1.1088	.9795	.7947	.7392
15	1.2382	1.0719	1.0534		.961	.7762	.7392
16	1.0349	1.1088	.5544	.4435	.924	.7392	.7577
17	1.0164	1.1643	.961	.462	.924	.8871	.8316
18	1.0534	1.0719		.6283		1.1088	.9055
19	1.2936	1.2197	1.4045	.8131	1.3491	1.2382	1.2197
20	1.6817	1.7926	1.7741	1.9404	1.4784	1.2936	1.4415
21	1.7002	1.5893	1.7187	1.848	1.5893	1.3121	.6838
22	1.6632	1.5339	1.7002	1.7556	1.423	1.2012	1.2936
23	1.5708	1.4784	1.6263	1.6263	1.3306	1.1643	1.2936
24	1.2936	1.4415	1.386	1.5339	1.5893	1.386	1.1458
Max	1.7002	1.7926	1.7741	1.9404	1.5893	1.386	1.4415
Min	.924	.9425	.5544	.4435	.8871	.4435	.6838
Avg	1.2251	1.2705	1.2513	1.1550	1.2382	.9109	.9656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 201 / 11 KV WADEGAON Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1829	.1715	.1715		
2			.1829	.1867	.1715		
3			.1829	.1753	.1715		
4			.1829	.1829	.1715		
5			.1829	.1772	.1543		
6			.181	.2033	.1543		
7			.2241	.3429	.2058		
8			.362	.3429	.2572		
9			.362	.373	.1543		
10		.2926				.0724	.1372
11	.2286	.3582					.12
12	.2286	.3658					.1357
13	.2439	.362				.1402	.1865
14	.1981	.3658				.1267	
15	.1981	.3475					
16	.2134	.3292				.1227	
17	.1829	.3658				.1494	
24			.1829	.1715	.1715		
Max	.2439	.3658	.362	.373	.2572	.1494	.1865
Min	.1829	.2926	.181	.1715	.1543	.0724	.12
Avg	.2134	.3484	.2227	.2327	.1783	.1223	.1449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 202 / 11 KV TAMSHI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1219	.7316	.8402	.7373	.3601	.362
2	.12	.1067	.7316	.7783	.7202	.3841	.362
3	.12	.1219	.7316	.703	.7202	.3561	.3361
4	.1029	.1219	.724	.6836	.703	.3772	.3077
5	.12	.1067	.7922	.6379	.7373	.4075	.3258
6	.1372	.1067	.7682	.8869	.823	.4024	.3439
7	.12	.1067	1.1222	1.1317	.9431	.373	.3658
8	.0857	.0762	1.2803	1.3394	.8573	.373	.3801
9		.0914	1.2357	1.1869	.7888	.3155	.3258
10	.945	1.0974	.0819	.0514	.1029	.4572	.5658
11	1.0059	1.3575	.0678	.0514	.1526		.6802
12	.9907	.2715	.0686		.1696		.6783
13	.945		.0686	.0857	.1865	.4207	.5721
14	.9297		.0848	.1029	.1865	.4031	
15	.9297	.6767	.0848	.1029	.1865		
16	.945	1.0608	.0848	.0857	.2374	.5853	
17	.9602	1.3717	.0934	.0857	.2134	.6036	
18	.0762	1.2127	.0905	.0857	.3052	.2804	.1086
19	.1067	1.0166	.1187	.12	.3561	.3506	.3856
20	.1372	.1831	.1696	.1715	.4409	.4298	.407
21	.1372	.181	.1696	.1715	.4409	.4733	.4887
22	.1372	.1829	.181	.1715	.381	.4755	.5068
23	.1372	.1372	.1629	.1543	.381	.4252	.4706
24	.1372	.1219	.7865	.8507	.7202	.3201	.333
Max	1.0059	1.3717	1.2803	1.3394	.9431	.6036	.6802
Min	.0762	.0762	.0678	.0514	.1029	.2804	.1086
Avg	.4114	.4469	.4346	.4556	.4788	.4083	.4153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 203 / 11KV BELURA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2591	.6584	.5784	.6173	.6783	.7087
2	.2743	.2439	.6584	.6036	.6173	.6783	.724
3	.2572	.2591	.6584	.591	.6173	.6783	.724
4	.2743	.1829	.6516	.591	.6344	.7545	.7602
5	.2743	.2743	.6584	.6154	.6516	.8413	.7522
6	.2915	.2439	.631	.7316	.7202	.8505	.7602
7	.2401	.2439	.724	.7969	.8059	.7888	.724
8	.1886	.2286	.8962	.905	.9431	.724	.5792
9		.1981	.8413	.8139	.823	.4917	.5249
10		.724	.1357	.1029	.4409	.7783	
11	.6554	.8322	.1526	.1372	.4748		
12	.7316	.8779	.1715	.1372	.3052		
13	.6401	.8779	.1844	.1372	.407	.3077	
14	.6401	.724	.1865	.1886	.4748	.2957	
15	.6401	.7316	.2035	.2058	.4748		
16	.5792	.7316	.2035	.2058	.5365	.3681	
17	.6097	.7316	.1991	.2058	.4877	.3841	
18	.0762	.1829	.1991	.1886	.5765	.5014	.1629
19	.1829	.1753	.1981	.2401	.6783	.7059	.7499
20	.2591	.3109	.2883	.2915	.8478	.7973	.8402
21	.1981	.3292	.3222	.2915	1.0082	.8413	.9412
22	.2743	.3475	.3439	.3258	.823	.8764	.8869
23	.2896	.3048	.3258	.3086	.8078	.7712	.8145
24	.2915	.2743	.6584	.5973	.7202	.6097	.7087
Max	.7316	.8779	.8962	.905	1.0082	.8764	.9412
Min	.0762	.1753	.1357	.1029	.3052	.2957	.1629
Avg	.3701	.4287	.4229	.4079	.6456	.6535	.7101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 204 / 11 KV WADEGAON Gaothan
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8842	.7164	.9709	.8745	.9015	.823	.8764
2	.8842	.6859	.9511	.8939	.8842	.8596	.905
3	.8669	.6859	.7316	.9036	.8842	.815	.9145
4	.8669	.7316	.724	.9036	.9015	.823	.9149
5	.9015	.7164	.9328	.8648	.9189	.8145	.8869
6	.9362	.6859	.9328	.9259	.9709	.9149	.8507
7	.8149	.7011	.905	.7202	.9709	.8478	.8145
8	.7282	.6249	.7011	.6952	.7888	.7865	.7655
9		.5639	.6767	.6613	.7373	.6706	.7164
10		.724	.5935	.7455	.7291	.8029	
11	.5792	.7316	.6104	.5721	.6443		
12	.5792	.6661	.5935	.6068	.6443	.5792	
13	.5944	.7421	.6274	.5895	.6783	.6485	
14	.6706	.8048	.6783	.6935	.7291	.6697	
15	.6401	.6584	.6613	.6241	.7468		
16	.5944	.7783	.6104	.7282	.7095	.6135	
17	.5639	.7468	.6443	.6068	.5639	.6836	
18	.5944	.7602	.7421	.7455	.5765	.8413	.7461
19	.7164	.8764	.8139	.9536	.8745	.9511	.8745
20	.8078	1.0136	.9326	1.0749	.9665	.9671	.9665
21	.7926	1.0242	.8817	1.0402	.9156	.9231	.8987
22	.823	1.0242	.9156	1.0229	.7926	.9134	.8817
23	.7773	.823	.8987	.9709	.7926	.905	.8478
24	.9189	.7316	.9511	.8648	.9189	.7316	.9145
Max	.9362	1.0242	.9709	1.0749	.9709	.9671	.9665
Min	.5639	.5639	.5935	.5721	.5639	.5792	.7164
Avg	.7516	.7591	.7784	.8034	.8017	.7993	.8609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024057 / 33 KV KANHERI GAWALI

Feeder No / Name : 201 / 11 KV VYALA G

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8682	.7975	.8402	.8413	.788	.7701
2	.8059	.8505	.7712	.823	.8501	.7186	.7619
3	.8059	.8596	.7602	.7969	.823	.7186	.7701
4	.7522	.8413	.7362	.7969	.7316	.7602	.7619
5	.7164	.7442	.7619	.763	.7133	.7602	.788
6	.7164	.7087	.7802	.6783	.7023	.7537	.7796
7	.7164	.6733	.631	.5935	.6767	.6379	.6201
8	.5121	.5316	.4961	.5087	.6468	.5895	.5375
9	.5487	.5847	.5493	.4748	.5304	.6173	.4938
10	.5304	.5487		.5083	.5175	.5258	.499
11	.5249	.5197	.5087	.5121	.4938	.4784	.462
12	.5373	.5658	.4917	.5121	.5014		.4024
13	.5611	.5426	.5087	.5853		.4656	.439
14	.5548	.6001	.5087	.6036	.5316	.4784	.4755
15	.6001	.5765	.5426		.5028	.4207	.5121
16	.5895	.6036	.5426		.4733	.4252	.5121
17	.5487	.6274	.5765	.5853	.5028	.4557	
18	.591	.583	.6274	.6219	.5658	.4961	.591
19	.5847	.6516	.7291	.8048	.7973	.7783	.7421
20	.9114	.9536	.8478	.9694	.8939	.8505	.8779
21	.9431	.9259	.9326	1.0059	.8764	.8417	.9328
22	.9259	.9465	.9156	.9774	.8682	.815	.9145
23	.8669	.9036	.8309	.924	.8328	.8059	.8413
24	.823	.8402	.8589	.8402	.8871	.8059	.7783
Max	.9431	.9536	.9326	1.0059	.8939	.8505	.9328
Min	.5121	.5197	.4917	.4748	.4733	.4207	.4024
Avg	.6871	.7105	.6828	.7148	.6852	.6516	.6636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024057 / 33 KV KANHERI GAWALI

Feeder No / Name : 203 / 11 KV DEGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2601	.1753	.8063	.763	.8669	.1097	.2303
2	.2774	.2279	.8059	.7969	.8573	.0886	.2328
3	.2774	.3012	.8238	.7969	.7975	.0876	.2303
4	.2774	.3544	.8328	.8478	.823	.1063	.208
5	.298	.3506	.8322	.8478	.8573	.1086	.2103
6	.3155	.3506	.8745	.9326	.9362	.1227	.208
7	.3856	.4607	1.0229	.9665	.9602	.0709	.2103
8	.4382	.5434	.9922	.9835	1.0056	.0701	.2454
9	.4207	.5721	1.1393	1.0004	.9114	.0857	.2896
10	.583	.1387		.7362	.5182	.0351	.439
11	.8859	.8745	.7202	.6344			.463
12	.9745	.8402	.6443	.6415			.4365
13	1.0924	.7377	.6443	.7202		.124	.4214
14	1.0576	.78	.6783	.6762		.124	.301
15	1.0229	.9556	.6783			.1949	.4967
16	.929	1.0111	.6443				.503
17	.9709	1.0562	.5935	.7011		.3467	
18	.1595	.2229	.1372	.12		.0905	.0701
19	.1433	.1928	.1357	.1907		.1097	.1029
20	.1578	.2229	.1357	.1734		.1075	.12
21	.156	.208	.1372	.1753		.1086	.0937
22	.1543	.2126	.12	.1772		.1254	.0914
23	.1387	.1772	.1372	.1734		.124	.1054
24	.2601	.12	.8149	.763	.7975	.1063	.2328
Max	1.0924	1.0562	1.1393	1.0004	1.0056	.3467	.503
Min	.1387	.12	.12	.12	.5182	.0351	.0701
Avg	.4848	.4619	.6240	.6281	.8483	.1165	.2583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 201 / 11 KV WAGHA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4115			.5487	.4115	.4115
2	.4115	.4115			.583	.4115	.4115
3	.4115	.3772			.583	.4115	.4115
4	.3772	.3772			.6859	.4115	.4115
5	.3772	.3429			.6859	.4115	.4115
6	.3772	.3429			.7888	.4115	.3772
7	.2743	.2743	.4527		.8916	.4115	.3429
8	.2058	.2058			.9602	.4115	.0686
9	.1715	.2058				.4801	.2058
10	.6173					.1372	.5487
11	.6859				.1372	.1372	.7316
12	.7545			.1372	.1372	.1372	.7316
13	.823			.1372	.1372		.7316
14	.7545			.1372	.1372	.1715	.7316
15	.7545			.1715	.1372	.2058	.6584
16	.8573			.1715	.1372	.1715	.6584
17	.8916			.1372	.1372	.1715	.8048
18	.1372				.2743	.2743	.2926
19	.2743			.2743	.3429	.3772	.2926
20	.4801			.4801	.4801	.4801	.439
21	.4801			.4801	.4801	.4801	.5121
22	.4801			.4801	.4801	.4801	.5121
23	.4115			.4115	.4115	.463	.5121
24	.4115	.4115			.5487	.4115	.4115
Max	.8916	.4115	.4527	.4801	.9602	.4801	.8048
Min	.1372	.2058	.4527	.1372	.1372	.1372	.0686
Avg	.4930	.3361	.4527	.2744	.4411	.3422	.4842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 202 / 11 KV KOTHALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9945		1.046	.7716	1.0631
2	1.0288	.9945		1.0288	.7716	1.0288
3	1.0288	.9602		1.0288	.7716	
4	1.0288	.9602		***	.7716	
5	1.0288	.9602		***	.7716	
6	.9945	.9602		1.2003	.7545	
7	.7373	.703		1.2346	.7716	
8	.5487	.6344		1.2346	.7716	.703
9	.4973	.5316			.6859	.583
10	.6859				.4458	.6516
11	1.0631			.3601	.3601	.8048
12	1.1145		.4287	.3944	.3429	.695
13	1.2003		.4458	.4115	.3429	.7682
14	1.1317		.4458	.4458	.3772	.6219
15	1.046		.463	.463	.3944	.7316
16	1.1145		.463	.4801	.4801	.8048
17	1.2003		.4801	.5316	.4115	.7682
18	.5487			.7202	.6001	.6401
19	.7373		1.0288	.9088	.8916	.9145
20	1.1488		1.166	1.2517	1.0802	.5121
21	1.2174		1.166	1.2346	1.2003	.4755
22	1.166		1.1488	1.2003	1.2003	1.2071
23	1.1145		1.0974	1.0631	1.2003	1.1706
24	1.046	1.0117		1.046	.7716	1.0631
Max	1.2174	1.0117	1.166	11.7799	1.2003	1.2071
Min	.4973	.5316	.4287	.3601	.3429	.4755
Avg	.9774	.8711	.7576	1.8098	.7059	.8004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 203 / 11 KV MAHAN

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5144		1.5089	1.5432	.4801
2	.5487	.5144		1.5089	1.5432	.4801
3	.5487	.4973		1.4403	1.5432	.4458
4	.5487	.4801		1.3717	1.5432	.4458
5	.5487	.5144		1.4746	1.5604	.463
6	.6001	.5487		1.5432	1.5775	.6859
7	.7202	.8573		1.6118	1.5775	.703
8	.7202	.8573		1.3375	1.2003	.823
9	.7545	.8573			1.0802	.8402
10	1.1831				.5144	1.1317
11	1.166			.6687	.463	1.0608
12	1.166		.8573	.7202	.463	1.134
13				.6859	.4801	1.0608
14			.8573	.6516	.4458	1.0059
15	1.3032		.8573	.6516	.5144	1.0608
16	1.3375		.8402	.703	.5316	1.0974
17	1.3717		.823	.6001	.6516	1.1706
18	.5487			1.286	.4801	1.3352
19	1.5604		1.5432	1.5604	.5487	1.6461
20	1.8519		1.7833	1.6632	1.5432	1.6461
21	1.7147		1.749	1.6461	1.5775	1.7193
22	1.6804			1.5432	1.5432	1.7193
23	1.5775		1.6289	1.5089	1.5432	1.6827
24	.5316	.5144		1.5261	1.406	.4973
Max	1.8519	.8573	1.7833	1.6632	1.5775	1.7193
Min	.5316	.4801	.823	.6001	.4458	.4458
Avg	1.0241	.6156	1.2155	1.2369	1.0781	1.0140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 204 / 11 KV Donod

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.4115		.4115	.3772	.2572
2	.3086	.4115		.3772	.3772	.2572
3	.3086	.4115		.3429	.3772	.2401
4	.3086	.4115		.3429	.3772	.2572
5	.3086	.4115		.3086	.3772	.2743
6	.3258	.4115		.3086	.3429	.3429
7	.3429	.6173		.3086	.2743	.3772
8	.4801	.583		.2058	.2401	.4458
9	.4458	.583			.1715	.3772
10	.1886				.2058	.2058
11	.1715			.9259	.2401	.1463
12	.1372		.9259	.8916	.2401	
13	.1372		.9602	.8573	.2572	.1097
14	.1372		1.0631	.8573	.2572	.2195
15	.1372		1.0631	.8573	.2743	.2195
16	.1372		1.0631	.823	.3429	.2195
17	.1372		1.0288	.6859	.3429	.1829
18	.1372			.583	.2401	.2195
19	.2743		.3429	.4801	.3429	.2926
20	.4458		.4458	.4801	.4115	.3658
21	.4801		.4458	.4458	.4115	.439
22	.4458		1.7147	.4458	.4115	.439
23	.4458		.4115	.4115	.4115	.439
24	.3086	.4115		.4115	.3772	.2572
Max	.4801	.6173	1.7147	.9259	.4115	.4458
Min	.1372	.4115	.3429	.2058	.1715	.1097
Avg	.2858	.4664	.8604	.5346	.3201	.2863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 401 / 33 KV Mahan Water Work Only one consumer of WW with HT-IV
Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1605	1.5432		1.5432	1.5432	2.0576
2	2.0576	1.5432		1.5432	1.5432	2.0576
3	1.8519	1.5432		1.5432	1.5432	.9259
4	1.6461	1.5432		1.5432	1.5432	.9259
5	1.6461	1.5432		1.5432	1.5432	.9259
6	1.6975	1.5432		1.5432	1.5432	1.9547
7	1.8004	2.0576		1.8519	1.5432	2.1605
8	2.1091	2.0576		1.8519	2.0576	2.1605
9	2.0062	2.0576			2.0576	2.0576
10	1.9547				2.0576	1.9033
11	2.0576			2.0576	1.9547	1.9204
12	2.0576		.5144	2.0576	1.9547	1.9204
13	2.0576		.5144	2.0576	1.9547	1.9204
14	2.0576		.5144	2.0576	2.0576	1.9204
15	2.0576		.5144	2.0576	1.8519	1.9204
16	2.0576		.5144	2.0576	2.0576	1.9204
17	4.1152		1.5432	2.0576	2.0576	1.9204
18	2.0576			2.0576	2.0576	1.9204
19	2.0576		2.0576	2.0576	2.0576	1.9204
20	2.0576		2.0576	2.0576	2.0576	1.6461
21	1.5432		1.8519	2.0576	1.749	1.6461
22	2.0576		1.8519	2.0576	1.8519	1.9204
23	2.0576		1.8519	1.5432	1.8519	1.9204
24	2.2634	2.0576		1.8519	1.5432	2.0576
Max	4.1152	2.0576	2.0576	2.0576	2.0576	2.1605
Min	1.5432	1.5432	.5144	1.5432	1.5432	.9259
Avg	2.0619	1.7490	1.2533	1.8659	1.8347	1.8168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 201 / 11 KV PATUR-NANDAPUR
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6516	.7392	1.0719	.7762	.5544
2		.6859	.7392	1.0349	.7762	.5544
3		.6859	.7392	.961	.7392	.5601
4		.6859	.7023	.961	.7468	.5175
5		.6859	.7023	.961	.7392	.5359
6		.6859	.7023	.961	.7392	.5175
7		.8402		1.1088	.5175	.5914
8		.9088		1.1827	.5914	.6653
9		.8916		1.3676	.5914	.7392
10	1.0349	.9425	.823	.7202	.5175	.6283
11	1.1458	.8131	.8573		.5914	.8131
12	1.2567	.8131	.8745		.5914	.7762
13	1.2012	.924	.7716		.6653	.7392
14	1.2012	.961	1.0288		.7392	
15	1.2012	.9335	1.0117		.7392	
16	1.2197	.961			.7762	
17	1.2197	1.0164	1.046		.7392	
18	1.1827	1.0456	.7202		.8871	.4435
19	1.2752	1.6263	.8916		.7392	.9979
20	1.4969	1.386	1.2003		.7392	1.1827
21	1.4045	1.2012	1.2936		.8871	1.1088
22	1.386	.9335	1.2936		.9055	.8131
23	1.2936	.9709	1.2012		.8501	.8131
24		.583	.7392	1.0903	.8131	.5544
Max	1.4969	1.6263	1.2936	1.3676	.9055	1.1827
Min	1.0349	.583	.7023	.7202	.5175	.4435
Avg	1.2514	.9097	.9039	1.0382	.7249	.7053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 202 / 11 KV PINJAR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8871	.7202	.7373	.8131	.8316
2		.823	.7202	.7373	.7392	.8316
3		.8871	.6859	.7373	.7392	.7947
4		.8871	.6859	.7373	.7023	.7947
5		.8871	.7202	.7373	.7023	.7947
6		.8871		.7373	.8501	.8501
7		.8131		.7716	.8501	.7577
8		.8131		.7373	.7392	.7762
9		.7947		.7202	.7392	.8131
10	.6687	.7373	.7392	.6859	.4805	.5544
11	.7373	.823	.8316		.4805	.5487
12	.6516	.7468	.6099		.4435	.5544
13	.6516	.5792	.7023		.4435	.4435
14	.6516	.6036			.4435	
15	.7716	.6401	.6653		.4805	
16		.6161	.7023		.4938	
17	.6687	.6535	.6099		.4435	
18	.6687	.6535	.7392		.695	.7023
19	.6516	.9425	.8131		.8413	.5175
20	1.0164	1.1016	.7947		.924	.961
21	1.0164	1.1203	.7577		.924	.924
22	.9795	.6535	.924		.8686	
23	.961	.7392	.9979		.823	.8501
24		.8871	.7202	.7373	.8131	.7865
Max	1.0164	1.1203	.9979	.7716	.924	.961
Min	.6516	.5792	.6099	.6859	.4435	.4435
Avg	.7765	.7990	.7442	.7342	.6864	.7414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 203 / 11 KV MAHAN (PINJAR)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.6283	.6468	.3326	.3361
2		.4287	.6283	.6468	.3326	.3511
3		.4287	.6283	.6283	.3511	.3475
4		.4287	.6099	.6283	.3511	.3109
5		.4287	.6099	.6468	.3696	.3109
6		.4458		.7023	.3696	.3475
7		.5487		.6283	.3326	.3881
8		.5144		.6099	.3326	.2957
9		.5658		.4805	.3696	.4024
10	.499	.4805	.5316	.5487	.2957	.4024
11	.499	.5729	.6516		.3142	.2926
12	.4435	.5914	.6516			.2926
13		.543	.4801		.2587	.3326
14	.4435	.5194	.5487		.3511	
15	.4805	.5914	.583			
16	.4435	.5601	.5487		.3326	
17	.5359	.5068	.5658		.3142	
18	.5544	.5792	.4115		.4108	.4755
19	.6653	.6838	.6653		.5914	.5304
20	.6099	.7762	.7947		.6468	.6838
21	.7023	.7762			.6653	.6584
22	.6838	.7468	.7392		.6099	.567
23	.6653	.6697	.6838		.5914	.567
24		.3772	.6283	.6468	.3292	.3292
Max	.7023	.7762	.7947	.7023	.6653	.6838
Min	.4435	.3772	.4115	.4805	.2587	.2926
Avg	.5558	.5490	.6099	.6194	.4024	.4111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 204 / 11 KV MAHAGAON

SPARE FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8871	.6001	.583	.5658	.6219
2		.8871	.6001	.583	.5487	.6173
3		.8686	.6516	.5658	.5316	.6173
4		.8686	.6516	.5658	.5658	.6173
5		.8686	.6516	.5658	.583	.6584
6		.9795		.5658	.6344	.724
7		.9795		.583	.6344	.7133
8		.8316		.6001		.5658
9		.7577		.5487	.4801	.4938
10		.5658	.6283	.4805		.463
11	.4287	.6173	.6653		.2915	.4572
12	.4973	.6668	.6653			.4435
13	.4458	.6859	.5359		.2572	.4973
14	.463	.381	.6468		.3772	
15	.5487	.724			.3772	
16		.7621	.6099		.4115	
17	.5316	.743			.4287	
18	.6173	.9335	.8501		.463	.5853
19	.703	1.0669	.6099			.583
20	1.0719	1.1431	1.0719		.6687	.4115
21	1.0349	1.1431			.6516	.4115
22	1.0164	1.1241			.6173	.3944
23	.961	.8192	.9055		.6001	.5144
24		.8871	.5906	.4458	.5658	.6283
Max	1.0719	1.1431	1.0719	.6001	.6687	.724
Min	.4287	.381	.5359	.4458	.2572	.3944
Avg	.6933	.8413	.6834	.5534	.5127	.5509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 205 / 11 KV BAHIRKHED

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3889	1.7147	1.406
2		1.5154	1.7147	1.3717
3		1.5154	1.8004	1.406
4		1.406	1.8004	
5		1.406	1.8861	1.3032
6		1.5261		1.4403
7		1.6804		1.7661
8		1.7318		1.8176
9		1.7318	2.1605	1.7147
10		1.5947	1.3375	1.0288
11	1.6289	2.1605	.7716	
12	1.1488	2.21	.8916	
13	1.6118	1.848	.7373	
14	1.8176	1.086	.7202	
15	1.8004	1.086	.9055	
16	1.7833	1.5623	1.3717	
17	1.4403	2.1338	1.6461	
18	1.3889	1.848	1.4045	
19	2.0328	2.2862	1.7002	
20	2.2546	2.4006	1.885	
21	1.8111	2.4006		
22	1.848			
23	1.7556	1.2193	1.2567	
24		1.3203	1.8671	1.3203
Max	2.2546	2.4006	2.1605	1.8176
Min	1.1488	1.086	.7202	1.0288
Avg	1.7171	1.6982	1.4511	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 201 / 11 KV KANHERI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.421		.3887			.2195
2		.426		.415			.2195
3		.426		.3563			.1943
4		.426		.3563			
5		.5121		.3563			
6		.5898		.3563			
7		.6554		.3239			.4024
8		.8097		.3887			.426
9		.8802		.5281			.4915
11	.3239	.5182	.5668		.8097	.5243	.1966
12	.3932	.4534	.7287		.9717	.5182	
13	.4096	.4534	.9717		1.0688	.5344	
14	.4096	.421	1.1012		1.1336	.5571	
15	.426	.421	1.0526		1.2955	.5735	
16	.426	.4372	1.1336		1.2146	.5735	
17	.426	.421	1.0526		.8097	.6154	
18	.0366	.0162	1.1336			.0189	
19	.0377	.0162	1.166			.0189	
20	.0377	.0162	.0162		.0324	.0189	
21	.0377	.0162	.0162		.0324	.0189	
22	.0377	.0162	.0162		.0324	.0189	
23	.0377	.0162	.0162		.0324	.0189	
24		.4588					.2561
Max	.426	.8802	1.166	.5281	1.2955	.6154	.4915
Min	.0366	.0162	.0162	.3239	.0324	.0189	.1943
Avg	.2338	.3838	.6901	.3855	.6757	.3084	.3007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 202 / 11 KV DHABA BT

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189					.0189
2	.0189					.0189
3	.0189					.0189
4	.0189					.0189
5	.0189					.0187
6	.0189					.0185
7	.0189					.0187
8	.0189					.0187
9	.0189					.0189
10			.1619			
11		.1619	.1619	.125		
12		.1886		.125		
13		.1619		.125		
14		.1619		.1094		
15		.1619		.125		
16		.1619		.0781		
17		.1619		.0625		
23					.0189	
24	.0189					.0189
Max	.0189	.1886	.1619	.125	.0189	.0189
Min	.0189	.1619	.1619	.0625	.0189	.0185
Avg	.0189	.1657	.1619	.1071	.0189	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 203 / 11 KV REDWA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2267				.0162
2		.2294				.0162
3		.2267				
4		.2294				
5		.3277				
6		.3277				
7		.3277				
8		.3605				
9		.3605				
10						.6802
11			.7545	.4801	.362	.7611
12			.7922	.5601	.3239	
13			.7922	.6401	.3239	
14			.8488	.6401	.3605	
15			.8488	.6401	.3605	
16		.016	.7287		.3605	
17		.016	.7611			
18		.016	.0324	.016		
19		.016	.0324	.016		
20		.016	.0324	.016		
21		.016	.0324	.016		
22		.016	.0162	.016		
23	.0189	.016	.0162	.016		
24		.2267				.1802
Max	.0189	.3605	.8488	.6401	.362	.7611
Min	.0189	.016	.0162	.016	.3239	.0162
Avg	.0189	.1651	.4376	.2779	.3486	.3308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 204 / 11 kv Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4338	.4715	.415			.3206
2		.4338	.4715	.415			.3206
3		.4527	.4715	.415			.3206
4		.4481	.415	.415			.3584
5		.4481	.4338	.4338			.3584
6		.4715	.4527	.4527			.3772
7		.4715	.4527	.4527			.3772
8		.4904	.4904	.5658			.415
9		.4854	.4338	.6036			.415
10		.4854	.4338	.5658			.4338
11	.439	.4904	.4338	.547	.4904	.5487	.4338
12	.4527	.4904	.415		.4527	.5487	.415
13	.4755	.4904	.4527		.415	.5487	.415
14	.4904		.4527		.4338	.5853	.4338
15	.4527	.5281	.4715		.4904	.5853	.415
16	.4527	.5281	.4715		.4904	.5975	.4338
17	.4527	.4527	.4904		.4527	.5853	.415
18	.4435	.4527	.4904		.4527	.5853	.415
19	.4481	.4338	.4904		.4715	.5487	.4338
20	.4527	.4715	.5093		.3772	.5487	.4527
21	.4527	.4715	.4904		.3018	.4854	.415
22	.4527	.4715	.4715		.3018	.439	.4715
23	.4338	.4527	.4715		.3018	.3658	.4715
24		.4338	.4715				.3206
Max	.4904	.5281	.5093	.6036	.4904	.5975	.4715
Min	.4338	.4338	.415	.415	.3018	.3658	.3206
Avg	.4538	.4691	.4629	.4801	.4179	.5363	.4016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 205 / 11 kv Dagadparwa Gaothan Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2172				.1475
2		.2195				.1646
3		.2195				.1475
4		.1966				.1475
5		.1829				.1646
6		.1829				.1147
7		.1646				.1147
8		.1646				.1097
9		.1448				.081
10		.1463				.1132
11	.128	.1463	.132	.0943		.0943
12	.128	.1509	.132	.0943		
13	.128	.1509	.1132	.0943		
14	.128	.1698	.1132	.0943		
15	.1267	.1698	.1132	.0943		
16	.1267	.1509	.132	.132	.1097	
17	.128	.1509	.132	.1886	.1086	
18		.1698	.1509	.2263	.1097	
19		.2263	.2263	.2075	.1829	.2075
20		.2641	.2829	.2641	.2534	.2263
21	.3109	.2829	.2829	.2641	.2267	.2452
22	.2561	.2829	.2829	.2641	.192	.2452
23	.2534	.2641	.2641	.2263	.1943	.2452
24		.2378				.1646
Max	.3109	.2829	.2829	.2641	.2534	.2452
Min	.1267	.1448	.1132	.0943	.1086	.081
Avg	.1714	.1940	.1814	.1727	.1722	.1608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 206 / 11 kv Barshitakali Gaothan Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6004	2.037	1.9805			1.9805
2		1.6194	1.9616	1.8861			1.8861
3		1.6004	1.8861	1.8861			1.8861
4		1.6004	1.8673	1.9805			1.8861
5		1.6004	1.6975	1.9239			1.9805
6		1.5684	1.6409	1.8673			1.8673
7		1.587	1.8861	1.8484			1.6057
8		1.587	2.0182	1.6194			1.8484
9		1.5364	1.9805	1.7918			1.5546
10		1.5223		1.8861			1.5402
11	1.5402	1.5061	1.7918	1.8296	1.6975	1.4746	1.5074
12	1.4899	1.7353	1.773		1.5466	1.4746	1.6032
13	1.4403	1.6975	1.7353		1.4146	1.4746	1.5844
14	.9231	1.6598	1.6975		1.6032	1.4746	1.5089
15	.9831	1.6975	1.6975		1.4712		1.5089
16	.9717	1.7541	1.6409		1.5466		1.4523
17	1.2803	1.7164	1.8861		1.5089		1.5466
18	1.5074	1.773	2.0182		1.8296	1.6385	1.7541
19	1.6194	2.0182	2.0182		1.9805	1.6194	2.1125
20	1.9433	2.2257	1.9805		1.9993	1.6004	2.1125
21	1.9433	2.3011	2.0182		2.0182	1.4403	1.9616
22	1.8679	2.2634	1.9805		1.9805	1.4746	1.9616
23	1.7814	2.1502	1.8673		1.9427	1.4575	1.8861
24		1.7532	2.0748				1.4746
Max	1.9433	2.3011	2.0748	1.9805	2.0182	1.6385	2.1125
Min	.9231	1.5061	1.6409	1.6194	1.4146	1.4403	1.4523
Avg	1.4839	1.7531	1.8763	1.8636	1.7338	1.5129	1.7504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 201 / 11 KV DHABA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1867	.1646	.1543	.1543	.1829	.1372
2	.1715	.1867	.1646	.1543	.1543	.1829	.1372
3	.1543	.1867	.1646	.1543	.1543	.1829	.1372
4	.1543	.1867	.1646	.1543	.1543	.1646	.1372
5	.1886	.1867	.1646	.1543	.1715	.1646	.1372
6	.2058	.168	.1646	.1543	.1715	.1646	.1543
7		.1463	.0914	.1372	.1372	.1463	.12
8	.0686	.1097	.0549	.12	.0686	.128	.1372
9	.0857	.1097	.128	.0857	.0857	.1097	.0857
10	.0686	.1097	.0914	.0857	.0857	.0732	.0686
11	.0716	.1029	.0686			.0686	.0686
12	.0716	.0857	.0686		.0857	.0686	.0686
13	.0895	.0857	.0857			.0686	.0686
14	.0895	.1029	.0686		.0857	.0686	.0686
15	.0895	.1029	.0857		.0857		.0857
16	.0895			.0914		.0857	.0857
17	.1075	.0905		.0857		.0857	.0686
18	.1075	.1267	.1372	.1372	.1097	.1029	.1029
19	.1433	.1448	.1372	.1715	.1646	.12	.1715
20	.2033	.1991	.1886	.2058	.1829	.1715	.2058
21	.2033	.181	.1715	.2058	.1829	.2058	.2058
22	.1848	.181	.1715	.1715	.1829	.1886	
23	.1848	.181	.1715	.1715	.1829	.1715	.2058
24	.1715	.1867	.1646	.1715	.1543	.1829	.1543
Max	.2058	.1991	.1886	.2058	.1829	.2058	.2058
Min	.0686	.0857	.0549	.0857	.0686	.0686	.0686
Avg	.1337	.1456	.1306	.1456	.1377	.1343	.1223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 202 / 11 KV PUNOTI GAOTHAN NEW

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3292	.2987	.2743	.2915	.3174	.2572
2	.2743	.3292	.2987	.2743	.2743	.3174	.2572
3	.2743	.3109	.2987	.2572	.2743	.3174	.2572
4	.2572	.3109	.2987	.2572	.2743	.3174	.2572
5	.2743	.3109	.2987	.2572	.2572	.2987	.2401
6	.2743	.2926	.2926	.2572	.2572	.2987	.2401
7	.1886	.2629	.2614	.1886	.1543	.2614	
8	.1543	.2279	.2054	.1543	.12	.2427	.1372
9	.1715	.1928	.1829	.1372	.12	.1867	.1372
10	.1543	.1928	.1629	.1372	.1543	.1494	.1372
11	.1578	.1715	.1372			.12	.1029
12	.1578	.1886	.1543		.1372	.1029	.12
13		.1886	.1372		.1372		.12
14	.1753	.1886	.1372				.12
15	.1928	.2058	.1543		.1372	.1543	.1372
16	.1928			.1307	.1372	.1029	.12
17	.2103	.1753		.1372	.1494	.1372	.12
18	.2279	.1753	.1715	.2058	.168	.2058	.1543
19	.2629	.2454	.2915	.2743	.2241	.2572	.2058
20	.3841	.3506	.3429	.3086	.3174	.2572	.2743
21	.3696	.333	.3429	.3086	.3174	.2743	.3086
22	.3511	.3155	.3086	.3086	.3174	.2743	
23	.3326	.3155	.2915	.3086	.3174	.2743	.2915
24	.2915	.3292	.2987	.2743	.2915	.3174	.2572
Max	.3841	.3506	.3429	.3086	.3174	.3174	.3086
Min	.1543	.1715	.1372	.1307	.12	.1029	.1029
Avg	.2444	.2584	.2439	.2343	.2195	.2357	.1933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 203 / 11KV NIMBI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0343	.0381	
2				.0343	.0381	
3			.0343	.0343	.0381	
4			.0324	.0343	.0381	
5			.0343	.0343	.0381	
6			.0324	.0343	.0381	
7			.0972	.0686	.0381	
8			.0972	.0857	.0381	
9			.0972	.0686	.0381	
10	.0514				.0381	.0324
11	.0572	.0972				.0514
12	.0857	.0648				.0343
13		.0648				.0343
14	.0572	.0486				.0343
15	.0714	.081				.0343
16	.0714				.0343	.0343
17	.0714	.0429			.0324	.0343
24				.0343	.0381	
Max	.0857	.0972	.0972	.0857	.0381	.0514
Min	.0514	.0429	.0324	.0343	.0324	.0324
Avg	.0665	.0666	.0607	.0463	.0374	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 204 / 11 KV DHABA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3048	.3086			
2	.4287	.2896	.3241			
3	.4458	.2743	.3241			
4	.463	.3048	.3241			
5	.4458	.2896	.3241			
6	.4801	.3963	.3549			
7	.7373	.5487	.6706			
8	.7373	.5335	.5182			
9	.7716	.5639	.5182			
10			.5182	.3401		.2591
11			.5144			
12			.5658		.421	
13			.4115			
14			.5487		.5182	
15			.6516		.5344	
16				.4572		.3429
17				.3601		.3401
18						.3401
19					.2591	
20					.2439	
21					.2286	
24	.4287	.3048	.2932			
Max	.7716	.5639	.6706	.4572	.5344	.3429
Min	.4287	.2743	.2932	.3401	.2286	.2591
Avg	.5384	.3810	.4481	.3858	.3675	.3206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 201 / 11 KV KOLSARA FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	2.2862	1.9139	1.587		.9653	.9709
2	1.531	2.2862	1.8631	1.5684		.9297	.9709
3	1.4937	2.2862	1.8778	1.4937		.9393	.9335
4	1.419	2.2862	1.7071	1.4937		.9017	.9335
5	1.3443	2.2862	1.688	1.4377		.8378	.8962
6	1.2696	2.0195	1.553	1.2323		.6921	.8589
7	1.643	2.1148	2.0256	1.307		.8078	1.1949
8	1.9418	2.5766		1.6244		.9017	1.2696
9	2.086	1.9044	2.9721			.9522	1.3411
10	2.0279	1.9605	2.9721			1.1498	1.5004
11	2.153	1.9231	2.9531	2.0485			1.4179
12	.2875	.682		2.0485			1.5192
13	1.4798	2.7008				1.0349	.9107
14	2.0256	2.8696	3.1245		1.307	1.0551	.8014
15	2.1046		3.2007		1.5684		.8014
16	2.0997		2.9127	1.7813	1.643	1.2291	1.1786
17		.7725	1.6057			1.419	
18		.8196	1.8298		.4553	1.4003	1.2491
19	3.1436	3.0045	2.0911		.775	1.643	1.4517
20	3.2198	2.1269	2.1658		1.3652	1.6617	1.5192
21	.7811	2.1944	1.9418		1.2322	1.531	1.3673
22	.7621	2.3676	1.8671		1.1657	1.2696	1.3047
23	2.0195	2.1944	1.643		1.1065	1.0829	.9865
24	1.6991	2.3053	2.0256	1.6057		1.0881	1.0082
Max	3.2198	3.0045	3.2007	2.0485	1.643	1.6617	1.5192
Min	.2875	.682	1.553	1.2323	.4553	.6921	.8014
Avg	1.7318	2.0894	2.1873	1.6024	1.1798	1.1187	1.1472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 202 / 11 KV BHATORI FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	1.3336	1.3178			1.5451	
2	1.1576	1.3336	1.5386			1.5451	
3	1.1203	1.3336	1.3378			1.3458	
4	1.1203	1.3336	1.3805			1.31	
5	1.0829	1.3336	1.3154			1.2163	
6	1.0456	1.4289	1.3018			.8983	
7	1.419	1.7337				.9297	
8	1.5684	2.1285				.7366	
9	1.5698	1.8671		1.901			1.355
10	1.5021	1.2136		1.7651		.7382	1.521
11	1.3169	2.1285		1.7651		.8266	1.3196
12	1.401			1.6651		.8803	1.1241
13	1.401			1.7651		1.0061	1.0254
14	1.3154			1.8082			1.3656
15	1.4633			1.7651			1.3241
16	1.4832			2.0669			1.1535
17	2.1148				1.9982		1.0972
18	2.3434	2.7244			2.0695		1.0903
19		2.6673			2.1314		1.2383
20		2.8578			1.9982		1.3449
21	2.8578	.8002			2.1969		1.2154
22	2.7816	.8002			1.5209		1.0742
23	2.191	1.5242			1.5364		.9192
24	1.2323	1.8671	1.4687			1.5451	
Max	2.8578	2.8578	1.5386	2.0669	2.1969	1.5451	1.521
Min	1.0456	.8002	1.3018	1.6651	1.5209	.7366	.9192
Avg	1.5748	1.6894	1.3801	1.8127	1.9216	1.1172	1.2112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 203 / 11 KV JAMBHA Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6348		.5636	.3734
2		.5975		.4918	.3734
3		.5975		.4736	.3361
4		.5601		.3643	.3361
5		.5601		.3643	.3361
6		.4668		.3302	.3174
7		.5415		.3244	.4668
8		.6908		.3278	.5228
9			.5228	.3965	.5121
10			.5975	.4736	.6077
11		.7562	.6161		.53
12		.8212	.6722		.52
13			.6722	.3756	.581
14			.6908		.5441
15			.6908		.5384
16		.7861	.4108	.5121	.5261
17				.6535	
18	.8029			.2987	.0364
19	.9335		.6752	.5788	.4389
20	.8589		.6921	.6161	.6577
21	.8402		.5081	.5415	.5975
22	.8029		.5292	.4481	.5121
23	.6908		.5121	.3921	.3376
24		.6535		.5464	.3921
Max	.9335	.8212	.6921	.6535	.6577
Min	.6908	.4668	.4108	.2987	.0364
Avg	.8215	.6388	.5992	.4537	.4519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 204 / 11 KV POHI Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2286	.217			.2026	
2	.2241	.2286	.217			.2026	
3	.2054	.2286	.2137			.2197	
4	.2054	.2286	.217			.2202	
5	.2054	.2286	.217			.2214	
6	.1867	.1905	.2219			.2371	
7	.2241	.1905	.2503			.2222	
8	.2801	.3361				.2333	
9				.3334		.2259	.2875
10	.3262			.3211		.2393	.3054
11	.3288			.2844		.2704	
12	.3288	.3028		.2535		.2355	
13	.3244	.3004		.2667		.2555	
14	.3073	.3045		.2831		.2363	
15	.3038			.2498		.235	
16	.2631			.2997		.2503	
17	.4191				.3004		
18	.4191	.4191			.3004		
19	.4191	.4382			.3073		
20	.4001	.2096			.2994		
21	.3048				.296		
22	.3048	.3048			.2152		
23	.2286	.2667			.2417		
24	.2241	.2477	.2197			.217	
Max	.4191	.4382	.2503	.3334	.3073	.2704	.3054
Min	.1867	.1905	.2137	.2498	.2152	.2026	.2875
Avg	.2895	.2738	.2217	.2865	.2801	.2308	.2965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 201 / 11 KV MANA FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7373	.8131	.7202	.6859
2	.6687	.7373	.8131	.6859	.6859
3	.6687	.7373	.8131	.6859	.6859
4	.6687	.7373	.8131	.6687	.6859
5	.6516	.7373	.8316	.6687	.6859
6	.6001	.7202	.8316	.6173	.6859
7	.6859	.8402	.924	.7202	.7545
8	.823	.9088		.8916	.8059
9	.9088	1.0117	1.1488	1.0802	
10	.9774		.8501	1.0117	
11	.8402		.9259	.9945	.7545
12	.8402		1.0117	1.046	.6687
13			.9431	.9602	.7888
14	.9431	1.0288	1.046	1.0802	.8402
15	.9602	1.0974	1.0288	.9945	.8059
16		1.1317	.9945	1.0288	
17		1.1317	1.0117	.823	
18	1.0974	1.1317	.9431	.8059	
19	1.0974	.9945	1.0631	.823	
20	1.0974	1.0802	1.0117	.823	
21	1.046	.9774	.9259		
22	.9602	.961	.823	.8916	
23	.8402	.8573	.7545	.823	
24	.703	.8059	.7716	.7373	.7716
Max	1.0974	1.1317	1.1488	1.0802	.8402
Min	.6001	.7202	.7545	.6173	.6687
Avg	.8459	.9183	.9171	.8514	.7361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 202 / 11 KV KURUM AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.037	1.0117	1.2003	.463	
2	.0343	.0343	.037	.9259	1.2003	.4458	
3	.0343	.0343	.037	.8745	1.2003	.4458	
4	.0343	.0343	.037	.7716	1.0974		
5	.0343	.0343	.037	.6859	1.2003		
6	.0343	.0343	.037	.9431	1.3032		
7	.0343	.0343	.037	1.3717	1.3546		
8	.0171	.1029		1.4575	1.286		
9	.0343	.12	.0514	1.4575			
10	1.2174	1.2689	.037	.0171			
11	1.3889	1.4575	.0373	.0343			
12	1.2174	1.2003	.0343	.0343			
13	1.1831	1.4413	.0343	.0514	.0343		
14	1.3717	.8097	.0343	.0514	.0343		
15	1.3717	1.3603	.0171	.0171	.0171		
16	1.4232	1.5947				.0171	
17	1.3546	1.6118			.0171	.0171	
18	.0686			.0343	.0171	.0171	.5316
19	.0514	.0924	.0343	.0514	.0171	.0343	.9774
20	.0343	.0739	.0343	.0514	.0343	.0343	.0343
21	.0343	.056	.0514	.0514	.0171	.0171	.0514
22	.0514	.0554	.0514	.0343	.0343	.0343	.0343
23	.0514	.056	.0514	.0343	.0343	.0343	.0343
24	.0343	.0343	.037	1.0802	1.2174	.463	
Max	1.4232	1.6118	.0514	1.4575	1.3546	.463	.9774
Min	.0171	.0343	.0171	.0171	.0171	.0171	.0343
Avg	.4644	.5033	.0382	.5019	.5956	.1686	.2772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 203 / 11 KV JAMATHI AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2572	.2772	.0514	.0343	.0343	.0686
2	.2058	.2572	.2772	.0343	.0343	.0343	.0686
3	.1886	.2572	.2772	.0343	.0343	.0343	.0686
4	.1886	.2572	.3696	.0343	.0343	.0343	.0686
5	.2572	.3429	.462	.0514	.0343	.0343	.0686
6	.2915	.4287	.5544	.0343	.0343	.0343	.0343
7	.4287	.5487	.6468	.0514	.0343	.0514	.0343
8	.4458	.5487		.0514	.0686	.0343	
9	.2743	.4458	.5144	.0514		.0686	
10	.0343	.0686	.6468	.6344		.2915	
11	.0514	.0686	.6099	.6859	.4458	.2743	
12	.0514		.5487	.5658	.4287	.2915	
13	.0514	.0339	.4115	.5316	.4287	.2743	
14	.0343	.0486	.5658	.4458	.4287	.2743	
15	.0514	.0972	.4458	.4458	.3944	.3429	
16	.0857	.0686	.4458	.5316		.2743	
17	.0857	.1029	.4287	.6344	.2058	.2401	
18	.0686	.0857	.0514	.0857	.1715	.0686	.1029
19	.0686	.0857	.0686	.12	.0343	.0686	.0857
20	.0514	.0934	.0514	.1029	.0514	.0686	.0686
21	.0514	.0934	.0514	.12	.0343	.0686	.1029
22	.0514	.0924	.0686	.12	.0343	.0686	.1029
23	.0514	.0934	.0686	.12	.0343	.0686	.1029
24	.2058	.2743	.2772	.0514	.0343	.0343	.0686
Max	.4458	.5487	.6468	.6859	.4458	.3429	.1029
Min	.0343	.0339	.0514	.0343	.0343	.0343	.0343
Avg	.1457	.2022	.353	.2329	.1445	.1279	.0747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 204 / 11 KV NAWASAL GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.6859	.7373	.7545	.7202	.6344	.583
2	.823	.6859	.7373	.7202	.7202	.6173	.583
3	.7716	.6859	.7373	.7202	.7202	.6173	.583
4	.7373	.6859	.7373	.7202	.7202	.6001	.583
5	.7373	.6859	.6859	.7373	.6859	.583	.583
6	.6687	.6516	.6001	.6516	.6859	.5658	.583
7	.6001	.6859	.6173	.5658	.5658	.5487	.6516
8	.6344	.6859		.6173	.583	.5658	.6001
9	.6173	.583	.6173	.6516		.6001	.6516
10	.5658	.6859	.463	.6516		.6001	.6516
11	.6001	.6173	.6516	.5316	.4801	.5658	.6001
12	.6001	.5316	.6173	.5658	.5144	.4973	.583
13	.6001	.6173	.5316	.5658	.5316	.4115	.5316
14	.6687		.5658	.6001	.4458	.4115	.463
15			.5658	.583	.4801	.463	.463
16	.6344	.7716	.5487	.6173		.4973	.4973
17	.6344	.6859	.5487	.6001		.4801	.4458
18	.5144	.6344	.5658	.5144	.4801	.4801	.4801
19	.6859	.7545	.8059	.5658	.7373	.6859	.703
20	.8573	.7716	.9088	.8745	.6173	.2058	.8059
21	.8573	.8402	.8916	.8745	.6344	.703	.7373
22	.9431	.7373	.8059	.8745	.7373	.6859	.7888
23	.9088	.7716	.8916	.8059	.6516	.6173	.6687
24	.8402	.823	.7716	.7888	.7545	.6344	.6001
Max	.9431	.8402	.9088	.8745	.7545	.703	.8059
Min	.5144	.5316	.463	.5144	.4458	.2058	.4458
Avg	.7097	.6945	.6784	.6730	.6233	.5530	.6009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 205 / 11 KV RAJURA GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3601	.4108	.3772	.3429
2	.3601	.3601	.4108	.3772	.3429
3	.3601	.3601	.4108	.3601	.3258
4	.3601	.3601	.3921	.3601	.3258
5	.3429	.3429	.2801	.3601	.2743
6	.2743	.2915	.2054	.2743	.2572
7	.1886	.2058	.2054	.2058	.1886
8	.1886	.2229		.1886	.1715
9	.1543	.2401	.2054	.2058	
10	.1543	.1715	.1867	.1886	
11	.1372	.1886	.168	.1715	.12
12	.1715	.056	.1715	.1543	.1372
13	.2229	.2801	.2058	.2058	.1543
14	.2572	.3174	.2229	.2401	.1886
15	.2572	.3174	.2058	.2058	
16	.2229	.2427	.2058	.2229	
17	.1886	.2427	.1715	.2058	
18	.2058	.2241	.1543	.1715	
19	.2229	.3174	.2743	.2572	
20	.3772	.4481	.3944	.3772	
21	.4115	.4854	.4115	.3944	
22	.4115	.4668	.4115	.3944	
23	.3944	.4294	.3944	.3772	
24	.3601	.3944	.4108	.3772	.3601
Max	.4115	.4854	.4115	.3944	.3601
Min	.1372	.056	.1543	.1543	.12
Avg	.2743	.3052	.2830	.2772	.2453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 201 / 11 KV DAHATONDA AG FEEDER Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2267	.3201	.4409	
2			.2429	.3201	.503	
3			.3239	.3239	.5087	
4			.3563	.3239	.5087	
5			.3563	.3563	.5087	
6			.3887	.5182	.5087	
7			.3239	.8097	.6104	
8				.8097	.6036	
9			.7125		.503	
10	.6859	.7122				.2753
11	.6516	.9069				
12	.6516					
13	.6443	.8421				
14	.6173	.7287				
15	.5426	.6478				
16	.5144	.6316				.2713
17	.5087	.5992				.3052
23		.2267				
24				.3201	.3391	
Max	.6859	.9069	.7125	.8097	.6104	.3052
Min	.5087	.2267	.2267	.3201	.3391	.2713
Avg	.6021	.6619	.3664	.4558	.5035	.2839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 202 / 11 KV SHIVAN FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.1006	.2915	.1147	.1341	.1296	.0324
2	.0678	.1017	.2429	.0983	.1357	.0972	.0324
3	.0678	.1006	.2429	.0983	.1341	.0648	.0324
4	.0678	.1017	.1943	.0983	.1357	.0648	.0312
5	.0678	.1017	.1619	.0332	.1372	.0648	
6	.0848	.1006	.1619	.0332	.1372	.0648	
7	.12	.1341	.1943	.0332	.1341	.081	
8	.1526	.2035		.0332	.1006	.081	
9		.1734	.2267	.0332	.1341	.1134	
10	.2204	.1696	.2267		.0972	.0972	
11	.1886	.2105	.2321	.0343	.1134		
12	.1715			.1029	.1134		
13	.1372			.0514	.1457		
14	.1372			.1372	.2267		
15	.1341			.1715	.1943		
16	.2058	.0486		.1715		.1006	
17	.2058	.0486	.0332	.1715	.2591	.1006	
18	.2012	.0486	.1823	.1696	.1619	.1029	
19		.2429	.1989	.2347	.2591	.0497	
20	.1357	.2591		.2401	.2267	.0663	
21	.1357	.2267		.2012	.1943	.0663	
22	.1372	.1619		.2058	.1781	.0503	
23	.1357	.2915	.1326	.1715	.1619	.0503	
24	.0678	.1006		.1147	.1357	.1296	.0324
Max	.2204	.2915	.2915	.2401	.2591	.1296	.0324
Min	.0678	.0486	.0332	.0332	.0972	.0497	.0312
Avg	.1323	.1463	.1944	.1197	.1587	.0829	.0322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 203 / 11 KV UMRI FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2713	.5668	.3315	.4024	.1943	.1619
2	.2743	.2713	.5668	.3315	.3353	.1943	.1619
3	.2743	.2683	.4858	.3315	.3353	.1943	.1619
4	.2743		.4858	.3149	.3353	.1943	.1619
5	.2743	.3018	.4534	.2984	.2743	.1943	.1619
6	.2743	.3391	.4534	.3647	.2035	.1943	.1619
7	.3772	.4748	.6478	.4475	.3391	.2429	.2105
8	.3772	.6935		.663	.3772	.2915	.3391
9		.8573	.9069	.788	.2713	.3239	.3887
10	.5487		1.0174		.3563	.3239	
11	.5144			.8048	.4049		
12	.5144			.7377	.4534		
13		.6554		.6706	.4534		
14	.5258	.8421					
15	.503	.7468			.4534		
16	.4801	1.0829					
17	.5426	.8421			.4858	.3353	
18	.631	.6722	.7625	.6706	.4534	.3978	
19	.6859	.8421		.6783	.4534	.407	.6036
20	.6783	.7773	.57		.0373	.3391	.5144
21	.6104	.6478	.4191	.4748	.4372	.2883	
22	.4115		.4024	.4801	.4534	.2374	.4458
23	.3429	.5182	.3856	.407	.4858	.1696	.4359
24	.2915	.2683	.583	.3481	.407	.1943	.1638
Max	.6859	1.0829	1.0174	.8048	.4858	.407	.6036
Min	.2743	.2683	.3856	.2984	.0373	.1696	.1619
Avg	.4408	.5986	.5804	.5079	.3731	.2620	.2909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 204 / 11 KV KHANDALA W/W EXPRESS Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1341	.1307	.1494	.1357	.0377	.1134
2	.1307	.1372	.1307	.1494	.1341	.0377	.1174
3	.1307	.1357	.1307	.1494	.1357	.0377	.0495
4	.1307	.1357	.1307	.1494	.1341	.0377	.0495
5	.1307	.1017	.1132	.1307	.1357	.0377	.0495
6	.0526	.0671	.1132	.1307	.1341	.0377	.0495
7	.1307	.0663	.132	.0518	.1357	.0566	.0495
8	.1307	.0678		.0518	.0671	.0566	.0495
9		.0686	.0754	.0518	.1341	.0324	.0495
10	.1372	.0648	.1307		.0747	.056	
11	.1543	.0566		.1187	.0747		
12	.1543			.12	.0747		
13	.1543			.12	.056		
14	.1543	.1307					
15	.1543	.1296			.056		
16	.1372	.1134					
17	.0686	.1494			.056	.0671	
18	.0686	.0648	.1526	.0671	.056	.0671	.0678
19	.0678	.0934	.0526	.0671	.0373	.0667	.0686
20	.0678	.0747	.0518	.0671		.0686	
21	.0686	.0747	.0518	.0602	.0162	.0541	.0671
22	.1341		.1494	.0686	.0373	.0549	.0671
23	.1357	.1494	.1307	.1017	.0373	.1494	.0686
24	.1307	.1372	.1307	.1494	.1341	.0377	.1134
Max	.1543	.1494	.1526	.1494	.1357	.1494	.1174
Min	.0526	.0566	.0518	.0518	.0162	.0324	.0495
Avg	.1198	.1025	.1129	.1029	.0884	.0552	.0687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 205 / 11 KV MURAMBA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4024		.394	.3688	.4534	.3077
2	.394	.4115		.394	.3315	.4049	.3077
3	.394	.3772		.394	.3353	.3239	.3185
4		.3688		.4108	.3391	.3239	.3077
5		.3429		.4108	.3391	.2915	.3185
6		.3353		.3582	.3391	.2915	.2683
7		.2347	.2915	.3224	.2713	.2429	.1844
8		.2347		.2686	.2035	.1638	.2012
9		.2713	.2267	.2865	.2058	.1296	.1943
10	.2401	.2591	.112		.1943	.1296	
11		.2591		.2058	.1943		
12	.2713			.2401	.1943		.2058
13	.2713	.3239		.2401	.1875		.2058
14	.2683	.2591			.1943		.1006
15	.2713	.2915			.1943		.1677
16		.2591				.2035	.1677
17			.2713		.2267	.2012	.1677
18	.2743	.3239	.3052	.2374	.2591	.2374	.2374
19	.3086	.3239	.3898	.2743	.3239	.3224	
20	.4694	.3887	.4477		.3239	.3582	
21	.4359	.421	.4477	.2713	.3563	.3761	
22	.4458		.4477	.407	.3401	.3582	
23	.4359	.3887	.4119	.4115	.3239	.3582	
24	.4163	.407	.3563	.4119	.373	.4534	.3185
Max	.4694	.421	.4477	.4119	.373	.4534	.3185
Min	.2401	.2347	.112	.2058	.1875	.1296	.1006
Avg	.3530	.3278	.3371	.3299	.2791	.2960	.2341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 206 / 11 KV BIDGAON GF

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1526	.1457	.1867	.1715	.1457	.1457
2		.1509	.1457	.1867	.1696	.1457	.1457
3		.1526	.1457	.1867	.1715	.1457	.1457
4		.1543	.1457	.1867	.1696	.1457	.1509
5		.1509	.1457	.1867	.1677	.1457	.1509
6			.1619	.1867	.1341	.1457	.1509
7		.12	.1134	.1307	.1006	.1134	.0857
8		.1006		.0934	.0848	.081	.0495
9		.0686	.0625	.0747	.0678	.0648	.081
10	.0686	.081	.0747		.081	.0486	.0509
11	.0686	.081		.0503	.0648		.0514
12	.0686			.0514	.0486		.0497
13	.0686	.0648		.0514	.0486		
14	.0686	.0486			.0486		.0509
15	.0671	.081			.0486		.0678
16	.0686	.081				.0686	.0686
17	.0686				.0486	.0671	.0848
18	.0848	.1134	.0924	.0671	.0972	.1029	
19		.1296	.1494	.1006	.1296	.1307	.1543
20	.1543	.1457	.1867			.168	.1696
21	.1715	.1619	.1848		.1619	.1867	.1696
22	.1677	.1619	.2054	.1865	.1619	.1867	.1677
23	.1734	.1457	.1867	.1844	.1619	.168	.1696
24		.1543	.1457	.1867	.1696	.1457	.1457
Max	.1734	.1619	.2054	.1867	.1715	.1867	.1696
Min	.0671	.0486	.0625	.0503	.0486	.0486	.0495
Avg	.0999	.1191	.1433	.1351	.1140	.1267	.1139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 207 / 11 KV DHANORA P GF

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4973	.4858	.5601	.5304	.4372	.4938
2		.4748	.4534	.5601	.503	.4372	.4887
3		.4801	.4534		.503	.4372	.4938
4		.4748	.4372		.503	.4372	.4938
5		.4409	.4372		.4748	.4372	.5121
6		.4239	.4372			.4372	.3475
7		.3561	.3563			.4049	
8	.2987	.3185				.3401	.4024
9		.3086	.3077			.3239	.3292
10	.3086	.3185	.3174		.2591	.2429	.2984
11	.2743	.2429		.2572	.2429		.2572
12					.2105		.2543
13	.3052	.2753		.2915	.2267		.2134
14	.3391	.3401			.2267		.2543
15	.3601	.3401			.2591		.2713
16		.3401					.3052
17					.3077	.1989	.3052
18	.3258	.3887	.4481	.407	.3887	.3521	.3856
19	.4527	.421	.5601	.4748	.4534	.5601	.4801
20	.5935	.4534	.6348		.502	.5601	.5228
21	.5868	.5344	.6348		.4372	.5601	.4801
22	.5487		.6161	.5765	.4534	.5228	.5144
23	.5087	.502	.5975	.5426	.4858	.5228	.5144
24		.4973	.4858	.5788	.5426	.4372	.4938
Max	.5935	.5344	.6348	.5788	.5426	.5601	.5228
Min	.2743	.2429	.3077	.2572	.2105	.1989	.2134
Avg	.4085	.4014	.4789	.4721	.3953	.4250	.3962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 201 / 11 KV SIRSO AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3201	.4428	.3395		
2			.3161	.427	.3395		
3			.3161	.4218	.3395		
4			.3121	.4374	.3395		
5			.3567	.4687	.463		
6			.3567	.4725	.4784		
7			.3418	.5864	.4938		
8				.6481	.5535		
9			.5487	.6944	.2688		
10	.6325	.6562				.2134	
11	.7274	.7811					.5596
12	.6642	.6944				.2896	.5426
13	.6958	.7099				.3658	.39
14	.6958	.6636				.4268	.4287
15	.679	.7253					.3258
16	.6944	.6944					
17	.7099	.7655				.2031	
23			.4641				
24			.4641		.3241		
Max	.7274	.7811	.5487	.6944	.5535	.4268	.5596
Min	.6325	.6562	.3121	.4218	.2688	.2031	.3258
Avg	.6874	.7113	.3797	.5110	.3940	.2997	.4493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 202 / 11 KV HIRPUR GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3696	.4108	.4108	.3841	.3174	.3174
2	.3142	.3696	.3269	.3921	.3841	.2987	.3174
3	.3142	.3696	.3121	.3921	.3841	.2801	.3174
4	.2957	.3696	.4481	.3734	.3841	.2801	.2987
5	.2772	.3696	.3734	.3547	.3841	.2801	.2987
6	.2801	.3326	.3361	.3361	.3475	.2987	.2801
7	.2402	.2587	.2587	.2614	.2561	.2054	.2587
8	.2402	.2218		.2614	.2926	.2054	.2218
9	.2427	.2614	.2561	.2241	.2195	.2054	.2218
10	.1867	.2172	.1829	.1848		.168	
11	.181	.2353	.1646		.1463		.168
12	.1478	.2218	.2195		.1463	.1109	.168
13	.1848	.1848	.2195	.1848	.1463	.1494	.168
14	.1848	.2218	.2378		.1646	.1494	.168
15	.679	.2772	.2195		.2218	.168	.1867
16	.2006	.2957	.2561	.2402		.1848	
17		.2561	.2561	.2012		.1478	
18	.2033	1.7194	.2353	.1848	.2507	.168	.2987
19	.2957	.2957	.3077	.2561	.2987	.2241	.2987
20	.3881	.3734	.3258	.3658	.3361	.3547	.2987
21	.3734	.3921	.3841	.3658	.3326	.3174	.3174
22	.4066	.4294		.4755	.3547	.3206	
23	.4108	.4294	.4108	.3841	.3547	.3174	
24	.3696	.3881	.4108		.3841	.3547	.3174
Max	.679	1.7194	.4481	.4755	.3841	.3547	.3174
Min	.1478	.1848	.1646	.1848	.1463	.1109	.168
Avg	.2943	.3692	.2979	.3079	.2940	.2394	.2590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 203 / 11 KV PUNDLIK NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.4854	.4108	.4108	.4108	.3174	.3734
2	.2402	.4854	.4108	.4294	.4108	.2987	.3361
3	.2402	.4854	.4108	.4108	.4108	.2801	.3361
4	.2218	.4854	.3734	.3921	.4108	.2801	.3361
5	.2218	.4481	.3734	.3734	.3734	.2614	.3361
6	.2218	.3547	.3921	.3734	.3361	.3361	.3361
7	.2587	.4668	.5601	.3361	.3361	.4108	.4854
8	.3696	.4854		.5415	.4668	.4108	.4294
9	.3881	.5544	.5975	.6348	.4294	.5601	.4294
10	.5914	.6348	.6535	.7095	.5729	.6161	
11	.6099	.5601	.6908		.6161		.4108
12	.6722		.6722		.3921	.5788	.4294
13	.6653	.5788	.6535	.6348	.5415	.5601	.4108
14	.6468	.5601	.6722		.5975	.4294	.2054
15	.5729	.4854	.6348	.6722	.5914	.5975	.2241
16	.7095	.5041	.6161	.6348		.5041	
17		.4294	.6348	.5788		.4481	
18	.5359	.4481	.5975	.5228	.3921	.4481	.1867
19	.5175	.4294	.5788	.5228	.3734	.4668	.1867
20	.5175	.4854	.5975	.5415	.5041		.2241
21	.5175	.4854	.4668	.4854	.4294	.3734	
22	.5175	.4854		.4481	.3921	.3921	
23	.5175	.4668	.4668	.4294	.3734	.3921	
24	.2772	.4854	.4294		.4108	.3547	.3734
Max	.7095	.6348	.6908	.7095	.6161	.6161	.4854
Min	.2218	.3547	.3734	.3361	.3361	.2614	.1867
Avg	.4474	.4909	.5406	.5041	.4442	.4235	.3361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 201 / 11 KV KHADAKA FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8764	.8413	.8413	.3696	.5731
2		.8413	.8322	.8063	.3361	.5373
3		.7888	.8149	.7712	.3361	.5373
4		.7362	.8413	.7712	.3361	.5373
5		.7362	.8238	.7282	.3361	.5258
6		.7202	.8149	.7108	.3881	.5258
7		.8402	.7712	.8383	.3326	.5083
8		.9602	.8619	.9116	.2534	.4801
9		1.0288	.8619	.9614		.5658
10		1.1271	.8288	.9724		.6516
11		1.1568		.7956		.8048
12				1.0442		.8718
13		1.1904				.8383
14		1.1105		.9389		.8215
15		1.2407		1.0277		.8383
16		1.1401		.9448		
17		1.0898				.5935
18		1.073		.3605		.5935
19		1.0802		1.0442		.6687
20		1.0802		1.0277		.6588
21		1.0174		1.0227		.6241
22		.9326		1.0059		.5548
23		.8573		.8383		.5316
24	.4207	.9114	.8589	.8413	.3506	.5731
Max	.4207	1.2407	.8619	1.0442	.3881	.8718
Min	.4207	.7202	.7712	.3605	.2534	.4801
Avg	.4207	.9798	.8319	.8729	.3376	.6267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 202 / 11KV SONORI AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2972	.3429	.2896		
2	.2972	.3429	.3041		
3	.3121	.3841	.2934		
4	.3269	.4001	.2787		
5	.3475	.4572	.2934		
6	.3858	.5761	.3269		
7	.6472	.5624	.5135		
8	.5796	.6622	.6241		
9	.5944	.535	.6321		.5053
10			.4778	.7316	
11			.4778	.7468	
12			.4715	.7468	
13			.4633		
14			.4778	.5639	
15			.4923	.5498	
16			.5068	.535	
17			.5213	.5716	
24	.2972	.3429	.2606		
Max	.6472	.6622	.6321	.7468	.5053
Min	.2972	.3429	.2606	.535	.5053
Avg	.4085	.4606	.4281	.6351	.5053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 203 / 11 KV KURANKHED AG FEEDER Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7449	.5243	
2			.7449	.4915	
3			.7773	.4588	
4			.7773		
5			.8002		
6			.8223		
7			.8855		
8			.9962	.5668	
9			.9646	.5668	
10	1.3032	.0937		.583	.4115
11	1.3032	.0781		.578	.7773
12	1.3146			.5937	.7655
13	1.2346	.0625		.6874	.7811
14	1.2003	.0781		.6718	
15		1.3763			.7621
16	1.2334	1.5684		.6718	.7655
17	1.2492	1.4723		.6562	.7968
24			.7449	.547	
Max	1.3146	1.5684	.9962	.6874	.7968
Min	1.2003	.0625	.7449	.4588	.4115
Avg	1.2626	.6756	.8258	.5844	.7228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 201 / 11KV NAGOLI AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.181	.1372	.2058	.2058	.1372	.0709
2	.0354	.181	.1372	.181	.2058	.1372	.0686
3	.0354	.1463	.1372	.1715	.2058	.1372	.0709
4	.0362	.1463	.1372	.1715	.2058	.1372	.0709
5	.0362	.1646	.1372	.1715	.2058	.1372	.0709
6	.0362	.1448	.1715	.1715	.2058	.1372	.0709
7	.1448	.2926	.2401	.2058	.2401	.1372	.1063
8		.3155		.3429	.2743	.1417	.1715
9	.1715	.4458	.4294	.3944	.3772	.1715	.2743
10	.2743	.583	.4801	.4801	.4801	.1543	.2572
11	.3772	.6173	.4801	.4801	.4458	.1715	.3086
12	.4115	.583	.5487		.3601	.1543	.2743
13	.4115	.6173		.1715	.5068	.1886	.3086
14	.4458	.5487	.5144	.463	.463	.1715	.2743
15	.4458	.3963	.5144		.5144	.1715	.2572
16	.4458	.4877	.4115	.5731		.1715	.0686
17	.543	.4877	.5487		.3429	.1524	.1715
18	.5121	.5182	.4706	.1448	.3086	.1524	.1372
19	.4344	.3048	.4755	.5068	.2401	.1524	.1372
20	.4344	.2439	.4344	.4344	.1829	.1524	.1372
21	.439	.2058	.3982	.4755	.1829	.0914	.1372
22	.2896	.1715	.3292	.3258	.1463	.1063	.1448
23	.181	.1715	.2534	.2896	.1372	.1886	.1086
24	.0709		.1372	.2172	.2743	.1448	.1063
Max	.543	.6173	.5487	.5731	.5144	.1886	.3086
Min	.0354	.1448	.1372	.1448	.1372	.0914	.0686
Avg	.2716	.3459	.3420	.3132	.2918	.1499	.1585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 202 / 11 KV TOWN - 2

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.9412	.9877	.9214	.8859	.7796	.7087
2	.8859	.9231	.9877	.905	.8859	.6859	.7087
3	.8688	.9412	.9511	.905	.8505	.6859	.7087
4	.8688	.905	.9511	.905	.8505	.6859	.7087
5	.815	.8688	.9145	.8505	.8505	.7087	.6859
6	.815	.8326	.9431	.8505	.815	.6859	.7087
7	.724	.7964	.8413	.7964	.7442	.6379	.7087
8	.7602	.8326		.6859	.7442	.6379	.7202
9	.7202	.823	.8059	.7202	.7011	.6173	.7202
10	.6859	.7888	.7202	.7373	.6173	.583	.7202
11	.7202	.823	.7202	.6859	.6154	.6173	.6859
12	.6516	.7545	.7888	.7202	.6859	.583	.6859
13	.6859	.7545		.9259	.6173	.5792	.6344
14	.8573	.7545	.7373	.8059	.6516	.5792	.583
15	.7888	.8048	.7888		.6516	.5487	.6001
16	.7888	.8779	.7545	.8326		.5144	.6173
17	.7964	.8413	.724	.724	.8413	.6219	.695
18	.7682	.9511	.724	.724	.8413	.7316	.7316
19	.7964	.9145	.7602	.8326	.8413	.7316	.7682
20	.8326	1.0242	.9412	1.0136	.9145	.8413	.8048
21	.9412	1.0242	.9145	.9412	.8779	.8048	.8413
22	.9412	.9511	.9412	.9774	.8326	.7442	.7796
23	1.0029	1.0974	1.0136	1.0136	.823		.815
24	.905		1.0242	.9412	.9259	.7964	.7442
Max	1.0029	1.0974	1.0242	1.0136	.9259	.8413	.8413
Min	.6516	.7545	.7202	.6859	.6154	.5144	.583
Avg	.8136	.8794	.8607	.8441	.7854	.6696	.7119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 203 / 11 KV TOWN-1

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.4842	1.4266	1.448	1.4175	1.0985	1.086
2	1.4118	1.4815	1.3535	1.3756	1.3032	1.0288	1.0136
3	1.3756	1.4842	1.3535	1.3032	1.3535	1.0631	1.0136
4	1.3756	1.448	1.3535	1.3032	1.3535	1.0631	1.0136
5	1.3032	1.3575	1.2803	1.267	1.3535	1.0974	1.0136
6	1.1946	1.1946	1.2803	1.2308	1.2346	1.0288	1.0136
7	1.1222	1.1584	1.134	1.1222	1.1694	1.134	1.086
8	1.086			1.0288	1.134	1.0277	.9602
9	1.0288	1.166	1.166	1.0288		1.0288	1.0288
10	1.1317	1.0974	1.166	1.1145		.9602	1.0702
11	1.1317	1.1317	1.2003	1.2003	1.1317	1.0288	1.0288
12	1.166	1.2003	1.2346	1.2346	1.2003	1.0288	1.0288
13	1.2689	1.2003		1.2346	1.1317	1.1145	1.0631
14	1.2346	1.2003	1.2689	1.2346	1.1317	1.0288	1.0631
15	1.2346	1.2803	1.2346		1.166		1.1317
16	1.2003	1.2437	1.2003	1.3611			1.0631
17	1.267	1.1706	1.1946	1.2071	1.3535	1.4632	1.134
18	1.2071	1.1706	1.2803	1.2308	1.2803	1.4632	1.134
19	1.3169	1.3169	1.3756	1.3535	1.3535	1.4266	1.2803
20	1.5203	1.4632	1.5565	1.5565	1.4998	1.4632	1.0242
21	1.448	1.4632	1.5364	1.5203	1.39	1.3535	1.3169
22	1.4842	1.5729	1.4998	1.5729	1.3394	1.2048	1.2403
23	1.5592	1.6461	1.5927	1.6651	1.3394	1.2403	1.2403
24	1.4175		1.5729	1.5203	1.5565	1.2437	1.134
Max	1.5592	1.6461	1.5927	1.6651	1.5565	1.4632	1.3169
Min	1.0288	1.0974	1.134	1.0288	1.1317	.9602	.9602
Avg	1.2889	1.3151	1.3301	1.3093	1.2949	1.1632	1.0909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 204 / 11KV Goyanaka fdr

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326	.9412	.9511	.8688	.9259	.7522	.7602
2	.7964	.905	.8916	.7964	.8859	.7442	.724
3	.7796	.9145	.9511	.724	.8859	.7442	.724
4	.7964	.8779	.9511	.724	.8859	.7316	.724
5	.7964	.8316	.9145	.724	.8573	.7087	.724
6	.7602	.8131	.9145	.724		.7202	.724
7	.724	.9145	.8048	.7964	.8505	.815	.7964
8	.6516	.8688		.6859	.7796	.7796	.7202
9	.6516	.6859	.8059	.6516		.6859	.7202
10	.8573	.7545	.7888	.8573		.823	.9602
11	.8916	.7888	.7888	.9259	.823	.8573	1.0288
12	.7888	.7888	.7888	.9259	.8573	.8916	1.1203
13	.8573	.7888		.7202	.8573	.8573	.9602
14	.823	.823	.7716	.8573	.7202	.6859	.823
15	.8916	.8779	.823		.8573	.6859	.8573
16	.9945	.8779	.7888	.9511		.823	.823
17	1.0136	.815	.905	.8688	.9877	.8048	.7316
18	.905	.8048	.8326	.8688	.8048	.8048	.7316
19	.905	.8048	.724	.8779	.8413	.8779	.7682
20	.9774	.9145	.9412	.9145	.9877	.9145	.8048
21	.9412	.9877	.8779	.8596	.9145	.8413	.8779
22	1.0136	1.0242	.9511	1.0136	.9774	.815	.7442
23	1.0985	1.134	.9774	1.086	.8688	.7796	.6733
24	.815		.9877	.9412	1.0498	.8326	.7796
Max	1.0985	1.134	.9877	1.086	1.0498	.9145	1.1203
Min	.6516	.6859	.724	.6516	.7202	.6859	.6733
Avg	.8568	.8668	.8696	.8419	.8809	.7907	.8042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 206 / 11 KV Water /W EXPRESS Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0366	.0381	.1063	.0857	.0857	.0354
2	.0362	.0362	.0381	.1086	.0857	.0857	.0886
3	.0362	.0732	.0381	.1063	.0857	.0857	.0886
4	.0362	.0724	.0366	.1063	.0857	.0857	.0886
5	.0362	.0905	.0381	.1086	.0857	.0857	.0362
6	.0362	.0905		.1086	.0857	.0857	.0362
7	.0362	.0362	.0381	.1029	.0857		.0362
8	.0362	.0362	.0366	.1029	.0886	.0886	.0343
9	.0343	.0343	.0343	.1029	.0343		.0343
10	.0343	.0343	.0343	.0343	.0343	.0857	.0343
11	.0343	.0343	.0343	.0343	.0343	.1029	.0343
12	.0343	.0343	.0343	.0343	.0343	.1029	.0343
13	.0343	.0343		.0857	.0343	.1029	.0343
14	.0857	.0343	.0857	.0857	.0343	.1029	.0343
15	.0857	.0381	.0857		.0343	.0343	.0343
16	.0857	.0381	.0857	.0905		.0343	.0343
17	.0905	.0381	.0905	.0362	.0381	.0381	.0381
18	.0905	.0381	.0362	.0362	.0381	.0381	.0381
19	.0362	.0381	.0362	.0362	.0381	.0381	.0381
20	.0362	.0381	.0366	.0362	.0381	.0381	.0381
21	.0362	.0381	.0366	.0362	.0381	.0381	.0381
22	.0366	.0381	.0362	.0366		.0354	.0354
23	.0358	.0381	.0362	.0362	.0343	.0354	.0354
24	.0886		.0381	.0905	.0362	.0905	.0354
Max	.0905	.0905	.0905	.1086	.0886	.1029	.0886
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0487	.0444	.0457	.0723	.0541	.0691	.0423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 207 / 11 KV ANBHORA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.2851		1.3394	1.3112	1.0631	.9945
2	1.2308	1.267		1.3394	1.2403	1.0631	.9602
3	1.2308	1.2803		1.3032	1.2403	1.0288	1.0136
4	1.2308	1.2308		1.3032	1.2403	1.0631	1.0136
5	1.1584	1.267		1.3032	1.2403	1.0277	1.0136
6	1.1222	1.1222		1.3032	1.2757	.9568	.9774
7	.9412	1.2308		1.1946	1.134	.8859	1.0136
8	1.086	1.2536		1.2003	1.0631	.8505	.9259
9	1.0288	1.2003	1.1317	1.2689		.7202	1.0117
10	1.0974	1.3375	1.0974	1.3375		.8916	1.0974
11	1.2003	1.3032	1.0974	1.3203	1.0631	.8402	1.0974
12	1.166	1.3032	1.2346	1.4403	1.046	.8573	1.0974
13	1.1317	1.2689	1.2346	1.2689	.9945	.9774	1.0288
14	1.166	1.3717	1.2689	.6344	1.1317	1.0288	1.166
15	1.166	1.3717	1.2346		1.0974	.9431	1.166
16	1.2689	1.3375	1.3032	1.5729		.9259	1.0631
17	1.0136	.6859	1.4685		1.1317	.9259	1.0631
18	1.3756	.8573	1.5524		1.2003	.5487	1.0631
19	1.3394	1.2003	1.5565	1.5927	1.0974	1.0288	1.2003
20	1.5565	1.406	1.7013	1.7193	1.0288	1.0974	1.3717
21	1.448	1.4998	1.6651	1.6289	1.2003	1.0974	1.5364
22	1.4842	1.406	1.5565	1.6461	1.1946	1.0985	1.4175
23	1.3466	1.2689	1.4842	1.5203	1.1584	1.0631	1.2757
24	1.2403			1.448	1.4118	1.1222	1.0631
Max	1.5565	1.4998	1.7013	1.7193	1.4118	1.1222	1.5364
Min	.9412	.6859	1.0974	.6344	.9945	.5487	.9259
Avg	1.2207	1.2502	1.3725	1.3660	1.1667	.9627	1.1096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 208 / 11KV J.K. GINING

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1829	.1463	.181	.1715	.1372	.1417
2	.181	.181	.1829	.181	.1829	.1372	.1417
3	.181	.1646	.1829	.181	.1772	.1372	.1448
4	.181	.1448	.1829	.181	.1715	.1372	.1417
5	.181	.1448	.1829	.181	.1829	.1372	.1448
6	.181	.1448		.181	.1772	.1372	.1417
7	.181	.1463	.1463	.1417	.1829	.1715	.1448
8	.181	.1463	.1829	.1715	.1417	.1772	.1372
9	.1372	.1372	.1543	.12		.1029	.12
10	.1372	.1372	.1715	.1372		.1029	.1029
11	.1372	.1372	.1715	.1372	.1372	.12	.1029
12	.1372	.1372	.1715		.12		.1372
13	.1715	.1372		.1715	.1372	.12	.12
14	.1372	.1372	.1715	.1543	.1372	.12	.1029
15	.1715	.1372	.1715		.1402	.0857	.12
16	.1715	.1372	.1715	.1448		.0857	.1029
17	.1086	.1372	.1448	.1086	.1097	.1097	.1097
18	.1086	.1372	.1086	.1086	.1029	.1097	.1097
19	.1086	.1372	.1463	.1448	.1029	.1463	.1097
20	.1448	.1715	.1448	.181	.1032	.1829	.1463
21	.1448	.1829	.1448	.181	.2058	.1372	.1372
22	.181	.1829	.181	.181	.181	.1417	.1417
23	.2149	.2195	.2172	.2172	.181	.1772	.1772
24	.1772		.1463	.181	.181	.181	.1417
Max	.2149	.2195	.2172	.2172	.2058	.1829	.1772
Min	.1086	.1372	.1086	.1086	.1029	.0857	.1029
Avg	.1599	.1531	.1647	.1622	.1537	.1346	.1300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 401 / 33 KV Murtizapur Main I/C EHV Express Feeder
Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.3279	26.8776		24.6914	26.046	21.0906	19.5474
2	8.8889	26.0631		24.0741	25.7802	22.1537	19.6502
3	8.7792	26.0631		22.3766	25.6207	21.4747	19.0329
4	8.7792	26.3889		23.1482	25.9397	20.8505	19.2387
5	8.7792	25.1852		23.1482	25.8334	19.2759	19.1358
6	8.7792	24.7057		22.891	26.046	19.2044	18.5185
7	8.7792	26.1717		24.4342	22.3251	17.2222	19.2902
8	21.5021	27.0559		9.928	23.654	17.807	19.8046
9	21.142	26.6976	10.5453	10.2881		7.0473	8.8477
10	28.9609	25.7202	8.8477	9.2593		7.9218	9.465
11	***	23.9712	9.2593	9.105	7.7161	7.7161	10.6996
12	***	20.9362	9.3622	7.5103	7.5103	7.7675	9.6194
13	25.463	24.4342	9.3622	8.8477	9.0535	7.5103	8.9506
14	25.6173	26.749	8.4362	9.6708	9.8251	6.9445	8.1276
15	27.7778	11.2483	8.0761		8.3333	5.2469	9.2078
16	***	13.1687	9.0535	25.9545		8.3333	7.4589
17	***	11.797	25.5202	16.5158	6.6444	8.3402	7.2428
18	26.2826	9.4376	18.3745	17.6469	8.7792	8.2305	
19	26.2277	9.4376	25.2487	23.9455	8.8889	8.7792	8.011
20	***	10.6447	26.5518	26.4432	9.0535	9.4376	9.8766
21	29.4651	10.4253	25.303	22.7264	9.0535	8.7792	9.8766
22	28.7237	10.2058	22.4966	25.3573	22.5881	20.6773	22.4314
23	26.737	9.9863	24.6514	25.1944	21.2895	19.9863	20.7305
24	23.3351			27.312	27.8007	23.0767	20.8899
Max	32.0902	27.0559	26.5518	27.312	27.8007	23.0767	22.4314
Min	8.7792	9.4376	8.0761	7.5103	6.6444	5.2469	7.2428
Avg	22.0038	19.7118	16.0726	19.1508	17.0372	13.5364	14.1589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 403 / 33 KV O/G -I (To Mana S/S)

EHV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3388	2.7149		3.0864	3.4019	2.2325	1.9547
2	2.3388	2.7149		2.8807	3.2956	2.0576	1.9547
3	2.2325	2.6063		3.0407	3.2956	2.0576	1.9547
4	2.2325	2.6063		2.8807	3.2956	1.749	1.9547
5	2.1719	2.552		2.7778	3.4019	1.6975	1.9033
6	2.1719	2.4977		2.7778	3.4019	1.5947	1.9033
7	2.1262	2.6063		3.1893	3.1893	1.4918	1.9547
8	2.3348	2.8778			3.2956	1.5415	2.1605
9	2.1605	2.6235	2.7263			1.6461	2.3663
10	3.035	2.3148	2.3663			1.9033	2.572
11	3.3436	.9259	2.6749		2.0576	1.8004	2.8292
12	3.0864	1.749	2.5206		1.9033	1.3889	1.5947
13	2.3148	2.6749	2.4177		2.0062	1.5947	1.3889
14	2.5206	3.1379	2.3148		2.1091	1.749	1.3889
15	2.8292	3.2922	2.4177		1.286	1.749	1.3375
16	2.7263	3.8066	2.4177	2.8235		1.6975	1.2346
17	2.6606	4.321	2.6886	1.2003	.5487	1.8656	1.4266
18	2.1719	2.1605	2.0302	1.8461	1.8107	1.9204	1.4266
19	2.3348	2.1605	2.364	2.1176	2.3045	1.9204	1.9204
20	2.8532	2.572	2.7692	2.4691	2.1948	2.2497	2.3594
21	2.8532	2.7435	2.6063	1.5203	2.0851	2.0851	2.1948
22	2.6063	2.4691	1.5746	2.552	2.1719	1.9136	1.9136
23	2.6578	2.4691	2.3891	2.4434	2.009	1.8073	1.9547
24	2.3388			3.4208	3.6923	2.4434	2.1794
Max	3.3436	4.321	2.7692	3.4208	3.6923	2.4434	2.8292
Min	2.1262	.9259	1.5746	1.2003	.5487	1.3889	1.2346
Avg	2.5184	2.6346	2.4185	2.5642	2.5122	1.8399	1.9095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 404 / 33 KV O/G -II (To Kherda EHV Express Feeder
S/S) Feeder KV- 33 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1948	7.276		4.6296	4.784	5.6344	4.6296
2	2.2634	7.3303		4.4239	4.5713	5.3155	4.4239
3	2.1948	7.2428		4.1152	4.5182	5.4218	4.4239
4	2.1948	7.1331		4.1152	4.5182	4.784	4.321
5	5.2092	6.6941		4.2181	4.784	4.2524	4.321
6	5.2092	6.5701		4.2181	5.3155	3.8803	4.2696
7	5.6344	8.199		5.4298	2.392	3.4465	4.8868
8	5.9185	9.3393			3.9335	4.6245	4.784
9	6.1728	8.9506	2.7778			1.8004	2.3148
10	10.1852	7.5103	1.8519			2.0062	2.572
11	10.8025	7.7675	1.9033		1.286	1.9547	3.3436
12	11.3683	3.8066	1.8519		.9774	2.4177	3.4465
13	7.6132	5.144	1.8519		2.4691	1.8519	3.2407
14	7.0988	6.1728	1.8519		3.1893	1.1831	2.3663
15	8.2819	2.4143	1.9033		2.9321	.823	3.4979
16	10.9568	2.8532	1.3889	4.6696		2.6235	2.1605
17	11.8913	1.9753	4.8868	3.6923	1.3169	2.6337	1.3169
18	7.3303	1.5364	1.3575	3.8009	1.7558	1.9753	1.3169
19	6.733	1.9753	5.1029	4.5068	1.9753	2.1948	2.1948
20	8.5048	2.1948	4.0055	4.7188	1.7558	2.1948	2.1948
21	8.0361	2.1948	3.638	4.2896	1.9753	2.1948	2.1948
22	7.7103	1.7558	4.181	3.546	4.6153	4.7308	5.1029
23	7.0165	1.9753	4.1267	4.3439	4.0604	4.784	5.0497
24	5.5927			4.8325	5.3212	5.9728	5.3155
Max	11.8913	9.3393	5.1029	5.4298	5.3212	5.9728	5.3155
Min	2.1948	1.5364	1.3575	3.546	.9774	.823	1.3169
Avg	6.9214	5.1309	2.8453	4.3469	3.2594	3.2792	3.4870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 201 / 11 KV PATUR

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	1.7741	1.7924	1.8111	1.7924	1.4784	1.4937
2	1.7558	1.7558	1.8111	1.8111	1.7741	1.4266	1.39
3	1.7558	1.7372	1.7002	1.8111	1.7741	1.4266	1.3535
4	1.7013	1.7741	1.7193	1.8111	1.7741	1.4415	1.3535
5	1.7013	1.7372	1.7372	1.8111	1.7741	1.4415	1.3535
6	1.848	1.7177	1.848	1.8111	1.8111	1.5684	1.6263
7	1.7924	1.7741	1.8111	1.8671	1.8671	1.6804	1.6263
8	1.7002	1.7741	1.7741	1.7372	1.8099	1.5893	1.7924
9	1.7002	1.7558	1.848	1.7558	1.6827	1.6632	1.829
10	1.7924	1.7364	1.8099			1.5927	1.6827
11	1.7558	1.8099	1.8461				1.6095
12	1.8099	1.7718	1.6834	1.5203	1.4842		1.5927
13	1.6651	1.6301	1.6301	1.4883	1.4415	1.3321	1.5927
14	1.6651	1.5424	1.576			1.134	1.5203
15	1.6651	1.6301	1.5927			1.1919	1.3611
16	1.6651	1.576	1.5592	1.7193		1.3466	1.3611
17	1.6834	1.6118		1.4685	2.0553	1.3394	
18	1.6476	1.701	1.8099	1.6476	1.9136	1.6651	1.7193
19	1.8099	1.8983	1.8823	1.8099	2.0995	1.9022	1.7558
20	2.1437	2.0698	1.922	1.9753	2.0995	1.922	1.7741
21	2.0328	2.0328	1.9959	1.9022	2.0119	1.6461	1.6827
22	2.0328	2.0119	1.9959	2.0119	1.8099	1.7372	1.6095
23	1.922	1.9753	1.922	1.8823	1.7193	1.5893	1.5203
24	1.829	1.848	1.829	1.8111	1.829	1.4998	1.4937
Max	2.1437	2.0698	1.9959	2.0119	2.0995	1.922	1.829
Min	1.6476	1.5424	1.5592	1.4685	1.4415	1.134	1.3535
Avg	1.7861	1.7769	1.7868	1.7732	1.8170	1.5279	1.5693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 202 / 11 KV KARLA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3688	.3814	.6036	.5658	.5658	.2949	.3429
2	.3688	.3814	.6036	.5658	.5658	.2915	.3429
3	.3688	.4359	.5658	.5658	.5658	.2984	.3429
4	.3688	.4458	.5658	.5658	.5658	.2652	.3353
5	.3647	.4748	.5281	.5658	.5281	.3052	.3353
6	.3978	.4641	.4904	.5281	.5281	.2774	.4024
7	.5898		.2926	.3772	.3772	.2652	.4915
8	.5693	.5312	.2641	.2263	.2263	.2812	.4744
9	.5693	.3567	.2263	.2263	.2263	.253	.463
10		.2641	.6097			.2263	.1886
11	.2614		.6325				.1886
12	.2641	.2987	.9069	.7499	.5487		.1886
13	.2641	.2987	.6325	.7186	.6173	.2263	.1886
14	.3018	.2987	.7682			.2263	.1886
15	.3018	.3734	.7362			.2263	.1886
16	.3018	.3734	.7499	.4973	.5487	.2641	.1886
17	.3018	.3395		.602	.3567	.2263	
18	.3018	.2957	.3361	.2587	.3395	.2641	.3395
19	.415	.4481	.4527	.4527	.4904	.4904	.5281
20	.679	.679	.6413	.679	.6413	.6036	.679
21	.7167	.7167	.679	.679	.7545	.679	.679
22	.679	.7545	.7167	.7167	.679	.679	.6036
23	.679	.679	.679	.679	.6413	.6413	.6413
24		.3391	.6413	.6413	.6036	.2984	.3189
Max	.7167	.7545	.9069	.7499	.7545	.679	.679
Min	.2614	.2641	.2263	.2263	.2263	.2263	.1886
Avg	.4288	.4377	.5792	.5431	.5185	.3447	.3757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 203 / 11 KV SHIRLA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.5967	.9709	.9335	.9335	.4694	.4801
2	.6706	.5967	.9335	.9335	.9335	.4641	
3	.6706	.6371	.9335	.8962	.9335	.4694	
4	.6706	.6371	.9335	.8962	.9335	.4359	
5	.6706	.6706	.9335	.8962	.9335	.4458	
6	.9389	.9945	.9431	.8962	.9335	.407	
7	1.3763	1.2803	.7545	.7545	.7545	.4641	
8	1.5074	1.4723	.6036	.5658	.6036	.4801	.1898
9	1.3763	1.3603	.4904	.5281	.5281	.5312	.2134
10	.4527	.5281	1.1111			.3018	
11	.4904	.5658	1.4723				
12	.1509	.5228	1.3283	1.3123	.7526		.4801
13	.1867	.5975	1.3916	1.142	.8025	.4527	
14	.2263	.6722	1.3123			.4527	.1783
15	.6348	.6722	1.2651			.4904	.1486
16	.5975	.6722	1.2346	.9259	.7316	.415	.1353
17	.5601	.6722		.8128	.6706	.4527	
18	.5914	.6348	.5281	.5228	.4854	.4801	.506
19	.6722	.7468	.7468	.7468	.679	.7842	.8589
20	.9709	.9709	.9808	.9054	.9054	.8299	.9709
21	1.0456	1.0456	1.0456	.9335	.9709	.9709	.9709
22	1.0456	1.0456	1.0456	1.0456	.9709	.9431	.9709
23	.9709	1.0456	.9709	.9709		.9054	.9335
24		.6036	.9709	.9335	.9709	.4321	.4801
Max	1.5074	1.4723	1.4723	1.3123	.9709	.9709	.9709
Min	.1509	.5228	.4904	.5228	.4854	.3018	.1353
Avg	.7456	.8017	.9957	.8776	.8119	.549	.5369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 204 / 11 KV KHANAPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8298	1.8671	1.3226	1.4022	1.3226		1.7177
2	1.8298	1.8298	1.2689	1.387	1.3413	.8215	1.7177
3	1.8298	1.7551	1.262	1.387	1.3748	.8215	1.6804
4	1.8298	1.7551	1.2689	1.4022	1.4083	.7842	1.6804
5	1.8298	1.7924	1.4022	1.491	1.4754	.7842	1.6804
6	1.8298	1.7924	1.6297	1.7337	1.5424	.7842	1.8671
7	1.4335	1.4937	1.989	1.9669	1.8652	.7922	1.4937
8	1.1317	1.2323	2.2043	2.1365	2.079	.679	1.094
9	1.0185	1.2323	2.3205	1.8785	1.9292	1.2696	1.0562
10	1.5912	1.6385	.8589				.6299
11	1.8896	2.146	.9709				.5967
12	1.8351		.9709	.9054	.7468		.7209
13		2.2611	1.0456	.9335	.7468	.5182	
14	1.6907	1.4746	1.0456			.3932	.7209
15	1.7368	2.0119	.8215			.7125	.6371
16	1.6575	2.3137	.7545	.0373	1.0082	.3887	.759
17	1.8351	2.3061		.0373	1.1203	.8383	
18	1.1827	1.2437	1.1458	1.0608	1.2696	.9156	1.1576
19	1.419	1.3443	1.531	1.7002	1.4563	.9602	1.5684
20	1.9791	2.0165	1.9791	2.0328	1.9418	1.0136	1.9044
21	2.0911	2.2032	2.0538	2.2177	2.0698	2.0698	2.0165
22	2.0698	2.0698	2.1807	2.1437	1.9791	2.0165	1.9418
23	1.9418	1.9959	2.037	1.9959		1.8671	1.8298
24		1.8671	1.3565	1.4022	1.2887		1.7924
Max	2.0911	2.3137	2.3205	2.2177	2.079	2.0698	2.0165
Min	1.0185	1.2323	.7545	.0373	.7468	.3887	.5967
Avg	1.7037	1.8105	1.4530	1.4626	1.4719	.9700	1.3756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 205 / ww patur

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.0377	.0377
2	.0377	.0377	.0377	.0377	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.0377	.0377	.0377	.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10	.0377	.0377	.0377			.0377	.0377
11	.0377	.0377	.0377				.0377
12	.0377	.0377	.0377	.0377	.0377		.0377
13	.0377	.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377			.0377	.0377
15	.0377	.0377	.0377			.0377	.0377
16	.0377	.0377	.0377	.0377	.0377	.0377	.0377
17	.0377	.0377		.0377	.0377	.0377	
18	.0377	.0377	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377		.0377	.0377	.0377
20	.0377	.0377	.0343	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	.0377	.0377	.0377	.0377	.0377	.0377
24		.0377	.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0377	.0377	.0343	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0376	.0377	.0377	.0377	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 201 / 11 KV SASTI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2614	.5975	.4801	.4801	.2427	.2058
2		.2614	.5975	.4801	.4801	.2427	.2058
3		.2614	.5975	.4801	.4801	.2427	.2058
4		.2614	.5975	.5144	.4801	.2427	.2229
5		.2614	.5975	.4572	.5144	.2427	.2401
6		.2614	.5975	.5144		.2614	.2401
7		.2614	.7842	.6516	.6687	.2614	.2401
8		.2614	.8589	.823	.7716	.2241	.2058
9		.1867	.8215	.7716	.703	.2054	.1715
10		.6173	.1715			.3086	.463
11		.7716	.1372		.1372	.3086	.5144
12		.8402	.12	.1372	.1372	.2915	.4801
13		.7468	.1372	.168	.1372	.3086	.4801
14		.7095	.1543	.168	.112		.4801
15		.7095	.1543	.168	.112	.3086	.4801
16		.7095	.1715	.168	.1494	.3086	
17		.7468	.1543	.168	.168	.3086	
18	.1494	.168	.1543	.168	.168	.1543	.1543
19	.1867	.2054	.1543	.1867	.2054	.1715	.1886
20	.2801	.2241	.2286	.2801	.2241	.1715	.1886
21	.2801	.2801	.2286	.2801	.2614	.1715	.2401
22	.2801	.2801	.2439	.2572	.2614	.2058	.2401
23	.2801	.2987	.2286	.2572	.2427	.2229	.2401
24		.2614	.5975	.4801	.4801	.2427	.2058
Max	.2801	.8402	.8589	.823	.7716	.3086	.5144
Min	.1494	.168	.12	.1372	.112	.1543	.1543
Avg	.2428	.4103	.3786	.3663	.3352	.2456	.2861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 202 / 11 KV SUKALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3174	.2054	.1524	.1886	.3361	.2743
2	.3086	.3734	.2054	.1524	.1886	.3361	.2743
3	.3086	.3734	.2054	.1715	.1886	.3361	.2743
4	.3086	.4108	.2054	.1886	.1886	.3361	.3086
5	.3772	.4108	.2054	.1886	.1886	.3361	.3086
6	.4801	.5601	.2241	.2058	.1886	.3547	.3086
7	.583	.6722	.2054	.1543	.1886	.3547	.4801
8	.6173	.6535	.1494	.12	.1543	.3547	.5144
9	.583	.6161	.1494	.0857	.1543	.3547	.4115
10	.0934	.1494	.5144			.12	.2572
11	.0934	.1494	.5316		.4115	.1029	.2058
12	.0934	.1494	.5487	.4458	.4115	.0857	.1886
13	.0934	.1494	.5144	.5228	.4458	.0686	
14	.1307	.1372	.4458	.4108	.3361	.0686	
15	.1494	.1867	.3086	.4108	.3734	.0686	
16	.1494	.1867	.5144	.3734	.2241	.0686	
17	.1307	.168	.3772	.4706	.2241	.12	
18	.1494	.1494	.1029	.1307	.1494	.12	.1543
19	.168	.1867	.1543	.2241	.1867	.1543	.1715
20	.2054	.2241	.1886	.2241	.2054	.1715	.1715
21	.2054	.2241	.1886	.1867	.2054	.1715	.1715
22	.2054	.2241	.1886	.1715	.2054	.1715	.1715
23	.2054	.2241	.1886	.1886	.1867	.1715	.1715
24	.3086	.2987	.2054	.1524	.1886	.3361	.2743
Max	.6173	.6722	.5487	.5228	.4458	.3547	.5144
Min	.0934	.1372	.1029	.0857	.1494	.0686	.1543
Avg	.2607	.2998	.2803	.2423	.2340	.2124	.2680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 203 / 11 KV KHETRI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.5228	2.0538	1.8519	.4287	.4108	.3772
2	.4287	.5041	2.0538	1.8519	.4287	.4108	.3772
3	.4287	.5041	2.0538	1.8519	.4287	.4108	.3772
4	.4287	.5041	2.0538	1.8861	.4287	.4481	.4115
5	.4287	.5041	2.0538	1.7071		.4854	.4115
6	.3429	.5415	2.0538	1.9204			.4115
7	.2286	.5788	2.6139	2.1605	2.0233	.5975	.4458
8	.2915	.3361	2.4646	2.1262	2.4863	.2054	.4287
9	.2743	.2987	2.5019	2.1262	2.332	.4854	.4115
10	2.6139	2.0538	.3086			.9259	1.046
11	2.8006	2.7073	.3086		.3086	.9259	1.0631
12	2.726	2.5393	.3258	.3258	.3086	.8916	1.0802
13	2.7073	2.1216	.3429	.3547	.3086	.8745	
14	2.6139	1.7833	.3429		.3361	.8916	
15	1.6804	1.9418	.3086		.3734	.9945	
16	1.4563	1.9605		.4108	.4108	1.0631	
17		2.3899	.4115	.4668	.4108	1.2689	
18	1.9605	.3921	.4458	.4668	1.531	.3944	.4287
19	1.9605	.5041	.4801	.4854	1.7551	.4287	.4458
20	2.0538	.5228	.4801	.543	.3734	.4287	.4287
21	.5228	.5228	.4801	.5601		.4287	.4115
22	.5228	.4668	.4801	.4801	.4481	.4458	.4115
23	.4854	.4668	.4458	.4458	.4294	.4458	.4115
24	.4287	.5228	2.0119	1.8519	.4287	.4108	.3772
Max	2.8006	2.7073	2.6139	2.1605	2.4863	1.2689	1.0802
Min	.2286	.2987	.3086	.3258	.3086	.2054	.3772
Avg	1.2093	1.0496	1.1772	1.1937	.7990	.6206	.5135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 204 / 11 KV WADEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.6804	.4294	.3772	.3772	1.307	1.0288
2	1.5432	1.6991	.4294	.3772	.3772	1.307	1.0288
3	1.5432	1.7164	.4294	.3772	.3772	1.307	1.0288
4	1.5432	1.6804	.4294	.3506	.3772	1.307	1.0631
5	1.5432	1.6804	.4668	.3658	.3772	1.2696	1.0631
6	1.6289	1.8298	.4854	.4287	.3772	1.2696	1.0631
7	1.7147	2.0538	.3734	.3601	.3601	1.307	1.1317
8	1.8004	2.0165	.2801	.2743	.2743	1.307	1.1831
9	1.3032	1.8858	.2614	.2401	.2058	1.2323	1.1145
10	.168	.2241	1.5432			.2058	.1886
11	.168	.2427	1.8861		1.7147	.1886	.1715
12	.1867	.2801	2.0919	1.749	1.749	.1715	.1715
13	.1867	.2801	2.0576	2.2405	1.8176	.1543	
14	.2241	.2801	1.989	2.3899		.1886	
15	.2801	.2801	2.1262	2.2405	2.0165	.1886	
16	.2801	.3174	1.8519	2.0165	2.0911	.1372	
17	.2427	.2801	2.2977	2.3152	1.643	.2401	
18	.2427	.2801	.2229	.2427	.2427	.2401	.2058
19	.2987	.3361	.2743	.3174	.2987	.2743	.2915
20	.4481	.4108	.3944	.4668	.2987	.3429	.3429
21	.4668	.4668	.3944	.4668	.2987	.3601	.3944
22	.4481	.4668	.3772	.4458	.3734	.3601	.3772
23	.3921	.4668	.3353	.4458	.4108	.3601	.3772
24	1.5432	1.1203	.4294	.3353	.3772	1.307	1.0288
Max	1.8004	2.0538	2.2977	2.3899	2.0911	1.307	1.1831
Min	.168	.2241	.2229	.2401	.2058	.1372	.1715
Avg	.8225	.9156	.9107	.8556	.7471	.6805	.6976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 201 / 11 KV CHONDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0974	.924	1.0242	.9665	.5249	.4656
2	.8573	.7682	.924	1.0242	.9665	.5068	.4298
3	.8916	.823	.9425	1.0242	.9326	.5083	.4207
4	.8916	.7316	.9709	1.0269	.8987	.5258	.4207
5	.9259	.695	.9709	1.0082	.8987	.5258	.463
6	1.0631	.695	.9335	.9709	.8817	.5611	.463
7	1.2689	1.4969	.8775	.8775	.8817	.5249	.3814
8	1.2003	1.2936	.8402	.7468	.5426	.4801	.4161
9	1.0974	.9145	.499	.5975	.5426	.4115	.4508
10		1.3352	1.1174			.4706	.3292
11	.439	.8642					.3018
12	.439	.5258		1.6842	1.6221	.4805	.3361
13	.4755	.5373		1.6549			.4108
14	.4805	.5121		1.6907			.3881
15	.4938	.5853		1.6712	1.3765		.3881
16	.567	.6219		1.6385	1.4918	.4525	.4481
17	.5304	.6401		1.6057	1.326	.4435	.4854
18	.6335	.7392		.5533	.5506	.7468	.7468
19	.9145	.8215		.8718	.9221	.8029	.8402
20	1.1157	1.0829		1.1065	1.1403		1.0642
21	1.1088	1.1203	1.0974	1.0898	1.1222	1.0829	1.1203
22	1.1643	1.1827	1.0974	1.073	1.0136	.9145	1.1576
23	1.134	1.1088	1.0608	1.0227	.9955	.7316	1.0642
24	.8059	1.0808	1.0719	1.0242	.9496	.5544	.5194
Max	1.2689	1.4969	1.1174	1.6907	1.6221	1.0829	1.1576
Min	.439	.5121	.499	.5533	.5426	.4115	.3018
Avg	.8415	.8864	.9520	1.1358	1.0011	.5921	.5630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 202 / 11 KV ALEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.924	.759	.7682	.8288	.8785	.9795
2	.8048	.9425	.7773	.7682	.8383	.8619	1.0164
3	.8048	.961	.7773	.7682	.8288	.852	1.0829
4	.8048	.961	.8383	.8002	.8619	.8356	1.1203
5	.788	.9877	.8383	.8002	.8951	.9339	1.1203
6	.788	.9877	.8573	.8322	.8951	.9945	1.1576
7	.8048	.9145	.823	.8642	.8951	.9339	1.1203
8	.7042	.8779	.8383	.8848	.8619	.9717	1.1576
9	.6036	.8501	.8619	.9389	.8619	.9231	1.0829
10		.7796	.6325			.2429	.4066
11	.9816	.8288					.3544
12	.8505	.8192		.407	.3605		.3353
13	.8596	.8192		.4641		.3395	.373
14	.8775	.7682		.5365			.4108
15	.8954	.7773		.6036	.6478		.3841
16	.9145	.7537		.6036	.7499	.2507	.426
17	.9511	.7865		.5868		.3772	.4641
18	.8048	.8097		.7293		.7316	.7164
19	.924	.8002		.7459	1.0623	1.0829	.8779
20	.9877	.8642		.8619	1.0526	1.1203	1.1203
21	.9877	.8642	.9054	.8453	1.0159	1.1016	1.1203
22	.9979	.8592	.8718	.8288	.9282	1.0456	1.0456
23	.9055	.8002	.8383	.8619	.9116	1.6057	1.0349
24	.7865	.9055	.759	.7362	.7625	.8583	.9795
Max	.9979	.9877	.9054	.9389	1.0623	1.6057	1.1576
Min	.6036	.7537	.6325	.407	.3605	.2429	.3353
Avg	.8536	.8601	.8127	.738	.8477	.8471	.8286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 203 / 11 KV AMBASHI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8229	1.9605	1.8656	2.1582	1.9784	.905	.9114
2	1.7833	2.0538	1.8656	2.1582	1.9951	.9231	.9313
3	1.7833	1.9605	1.885	2.1582	2.0178	.9412	.8954
4	1.8347	1.9044	1.9589	2.1582	1.9669	.9313	.9114
5	1.869	1.9044	1.9589	2.0851	1.933	.8954	.9671
6	1.869	1.9044	2.0351	2.0851	1.933	.9671	
7	2.3491	2.726	2.0351	2.0485	1.8991	.9955	
8	2.5968	2.6139	1.7924	1.8298	1.4074	1.0288	
9	2.2611	2.4691	1.6244	1.6057	1.4074	.9945	
10		1.5154	2.1382			1.267	
11	.9556	1.531			1.8896		1.2125
12	1.4266	1.6057	2.6406		1.9334		1.2803
13	1.4449	1.6057	2.5034			1.0829	
14	1.46	1.6263	2.1262				.9335
15		1.6632			1.7004		1.0903
16		1.6817			2.13	1.1273	1.2936
17	1.5912	1.6078			1.9433	1.307	1.4415
18	1.6461	1.8671			1.0322	1.6804	1.8671
19	1.8107	2.0165		1.6787	1.757	1.8484	2.0725
20	2.0851	2.2405		1.8107	2.1622	2.2032	2.1472
21	2.1765	2.3899	2.3045	2.0119	2.2546	2.1658	2.2032
22	2.3899	2.4394	2.2314	2.1293	2.1033	1.829	2.2032
23	2.3339	2.4025	2.1948	2.0454	2.0485	1.6461	2.0538
24	1.7703	1.9605	1.9204	2.1582	2.0008	.905	.9465
Max	2.5968	2.726	2.6406	2.1582	2.2546	2.2032	2.2032
Min	.9556	1.5154	1.6244	1.6057	1.0322	.8954	.8954
Avg	1.8695	1.9854	2.0636	2.0081	1.8806	1.2822	1.4090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024053 / CHANNI

Feeder No / Name : 201 / 11 KV CHANNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2743	.2743	.3429	.3601	.1219	.1219
2	.2286	.2743	.2743	.3086	.3429	.1219	.1219
3	.2134	.2743	.2743	.3086	.3429		.1219
4	.2134	.2743	.2743	.3258	.3429	.1219	.1372
5	.2286	.2915	.3048	.3429	.3429	.1219	.1372
6	.2439	.2915	.3048	.3601	.3258	.1372	.1219
7	.3201	.4458	.3048	.2743	.2743	.1372	.1372
8	.3963	.4458	.2439	.2743	.2401	.1372	.1829
9	.3658	.3772	.1981	.2058	.2058	.1372	.1524
10	.1715	.2058	.3506	.3506	.3772	.1524	.1886
11	.2401	.2286	.3963				.1715
12	.2915	.2286	.3506	.3772	.2134		.1886
13	.3086	.2743	.2896	.2915		.1543	.1715
14	.3258	.2896	.2743	.3086		.1715	.1715
15	.3086	.3048	.2591		.2591	.1886	.1886
16	.2915	.2591	.3201	.2743	.2439	.1715	.2058
17	.2915	.2896	.3429	.2915	.1981	.1886	
18	.2572	.2286	.2058	.1886	.2439	.2229	.2401
19	.2915	.3048	.2743	.2743	.2591	.3086	
20	.3772	.3353	.3772	.3772	.2439	.2915	.3601
21	.3772	.3048	.3772	.3601	.1524	.3429	.3772
22	.3772	.3353	.3772		.1677	.3258	.3601
23	.3601	.3201	.3601		.1372	.3086	.3429
24	.2286	.2743	.3201	.3601	.3601	.1524	.1372
Max	.3963	.4458	.3963	.3772	.3772	.3429	.3772
Min	.1715	.2058	.1981	.1886	.1372	.1219	.1219
Avg	.2897	.2972	.3054	.3099	.2683	.1912	.1972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024053 / CHANNI

Feeder No / Name : 202 / 11 KV UMRA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5144	.2743	.9907	1.0288	.2591	.4801
2	.4973	.5144	.2743	.9755	1.0288	.2591	.463
3	.4801	.5144	.2743	.9755	1.046	.2591	.4458
4	.5144	.5487	.2743	.9907	1.0631		.4458
5	.5658	.583	.3048	1.0212	1.0974		.463
6	.6859	.6516	.3353	1.0974	1.1317		.583
7	.6516	.6344	.3048	.5182	1.1488		.3506
8	.4973	.4287	.2591	.4572	1.1831		.3944
9	.4115	.3258	.1981	1.0364	1.166		.3258
10	.7164	1.0802		.2572	.2915	.1372	.2591
11	.2915	1.1279					.2743
12		1.0212	.3258	.3944	.2743		.2743
13	1.0631	1.0822	.8383	.4801			
14	1.0631	.9907	1.0364	.463		.061	.4287
15	1.166	1.0212	1.0669		.3353	.1067	.3258
16	1.2003	1.0974	.4458	.3944	.3506	.1219	.3429
17	1.2517	1.1279	.4973		.3506	.2286	
18	.4801	.442	.4115	.5658	.3963	.4287	.4115
19	.9088	.5487	.6173	.6859	.5182	.4973	.5144
20	.6516	.5944	.5487	.703	.4572	.5658	.6001
21	.6344	.5335	.6344	.6687	.4877	.583	.5658
22	.6001	.5487	.583	.6687		.5316	.5487
23	.5487	.4725	.4973	.6516	.2439	.5144	.5144
24	.5316	.5144	.2134	.945	1.0288	.2743	.4973
Max	1.2517	1.1279	1.0669	1.0974	1.1831	.583	.6001
Min	.2915	.3258	.1981	.2572	.2439	.061	.2591
Avg	.6899	.7049	.4643	.7115	.7314	.3219	.4322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024053 / CHANNI

Feeder No / Name : 203 / 11 KV MALSUR

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8993	.9945	.945	1.0288	1.0631		.4725
2	.8383	.9774	.945	1.0117	1.0631	.3963	.4572
3	.8078	.9774	.945	.8993	1.046	.3963	.442
4	.7621	.9602	.945	.9945	1.0631	.3963	.442
5	.7316	.9431	.9755	1.0288	1.0802	.4268	.4572
6	.8383	.9431	.9907	1.0288	1.0802	.4268	.442
7	.884	1.2003	.945	.8916	.8745	.4572	.4268
8	.8383	1.3203	.6859	.7716	.703	.3963	.4877
9	.8078	1.046	.4877	.6173	.6344	.3353	.4572
10	.5658	.4115	1.0364	.9907	1.1488	.4877	.4115
11	.6173	.3353	1.1126			.463	.4115
12		.5639	1.0212	1.2346	.884	.463	.3772
13	.6173	.5944	1.0364	1.166		.4458	
14	.6001	.6401	.9602	1.046		.4973	
15	.6516	.6706	.9755		.823	.6001	.4801
16	.7716	.6554	.884	.9774	.823	.5658	.4458
17	.7373	.6706	.945	.9602		.6001	
18	.7202	.6554	.7373	.6516	.7926	.6859	.6344
19	.9088	1.0669	.9259	.9431	.884	.9259	.8402
20	1.2346	1.0974	1.166	1.1831	.8993	1.0802	1.0288
21	1.286	1.0669	1.2174	1.2003	.9145	1.1317	1.0631
22	1.2003	1.0974	1.166	1.166	.945	1.0802	1.0974
23	1.0974	1.0364	1.0974	1.1145	.4268	1.0631	1.0631
24	.8078	.9945	.9907	1.0631	1.0631	.4572	.4877
Max	1.286	1.3203	1.2174	1.2346	1.1488	1.1317	1.0974
Min	.5658	.3353	.4877	.6173	.4268	.3353	.3772
Avg	.8358	.8716	.9640	.9986	.9106	.5991	.5917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 201 / 11 KV Rajeshwar Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.6626	.7316	.7316	.695	.567	.5487
2	.6767	.6584	.695	.7133	.6584	.5487	.5304
3	.6584	.6401	.6767	.7133	.6401	.5304	.4938
4	.6401	.6401	.6401	.695	.6401	.5304	.4938
5	.6584	.6722	.6401	.6767	.6401	.7659	.5121
6	.6767	.6908	.6584	.6767	.6767	.8208	.6036
7	.6767	.7316	.7133	.7865	.7499	.695	.695
8	.6401		.695	.6767		.6767	.6767
9	.6219	.6584	.695	.6036	.6099	.6219	.6584
10	.6036	.6401	.6584			.567	.567
11	.5304	.567	.5304	.5304			.4938
12	.5304	.5304	.5121	.4755	.4755	.4572	.4755
13	.5304	.5304	.5304	.4938	.4572	.4755	
14	.4207	.567	.5121	.695	.4938		.4755
15	.5853	.567			.4572		.4755
16	.5304	.567		.5853	.4572	.4572	.4755
17	.6036	.5487	.6036	.5487	.4938	.439	
18	.567	.5853	.567		.5304	.4938	.4938
19	.6036	.6036	.6401	.6036	.6767		.6219
20	.7316	.695	.7133		.6401		.7133
21	.7682	.7865	.7682	.8779	.7316	.6584	.7316
22	.8048	.823	.823	.8048	.6979		.695
23	.7865	.823	.7499	.7682	.6401	.6219	.6767
24	.7316	.7499	.7499	.7499	.7316	.567	.567
Max	.8048	.823	.823	.8779	.7499	.8208	.7316
Min	.4207	.5304	.5121	.4755	.4572	.439	.4755
Avg	.6371	.6495	.6593	.6703	.6092	.5830	.5761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 204 / 11 KV Renuka Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0534	1.0164	1.134	1.0719	.8962	
2	.8871	1.0164	.9328	1.1157	1.0349	.8962	.8215
3	.8871	.9795	.8954	1.0974	.9877	.8686	.8029
4	.9149	.9795	.8596	1.0608	.9877	.8501	.7842
5	.9335	.9709	.8775	1.0242	.9671	.8413	.7842
6	.985	1.0642	.9511	1.1203	1.0829	.9522	.9149
7	1.0242	1.1389	1.0642	1.1203	1.1041	1.0082	1.0642
8	.9979		.9979	1.1088		1.0164	.9979
9	.9055	1.0164	.8962	.9511	.9795	.9979	.9412
10	.8501	.961	.8048			.8501	.8501
11	.7762	.823	.6838	.823			.7133
12	.7499	.823	.6767	.7421	.6516	.5973	.6219
13	.7499	.8779	.695	.7421	.7499	.6154	
14	.7577	.8779	.7207	.7865	.7316		.6653
15	.7577	.9055	.7682		.7023		.6838
16	.7316	.9055	.8048	.8326	.724	.5853	
17	.7762	.9425	.823	.788	.7602	.6878	
18	.8417	.8962	.8417		.8596	.7522	.7316
19	.9511	.9511	.9955	.9313	1.0059		.9335
20	1.134	.9877	1.1643	1.0903	1.0349		.9896
21	1.2012	1.1273	1.1827	1.1458	1.0534	.9979	1.0082
22	1.2323	1.1827	1.2567	1.2197	1.0829		1.0082
23	1.2323	1.1827	1.2567	1.2197	1.0082	.8775	.9149
24	.9145	1.1458	1.0534	1.1706	1.1458	.9335	.8589
Max	1.2323	1.1827	1.2567	1.2197	1.1458	1.0164	1.0642
Min	.7316	.823	.6767	.7421	.6516	.5853	.6219
Avg	.9211	.9917	.9258	1.0107	.9393	.8458	.8545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 205 / 11 KV Shivsena Vasahat Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029	.8029	.8215	.8589	.7762	.7282	.6722
2	.7762	.8029	.7842	.8402	.7392	.7095	.6348
3	.7762	.8029	.7468	.8215	.7392	.6908	.6348
4	.7762	.8029	.8215	.8029	.7577	.7207	.6535
5	.7947	.8215	.8402	.8402	.7947	.7577	.6908
6	.8316	.9896	.9522	1.0642	.8686	.8962	.7468
7	.9425	1.134	1.1016	1.1016	1.1088	1.0642	1.1203
8	1.1273		1.1389	1.1949		1.1949	1.1576
9	1.2382	1.1949	1.1016	1.1576	1.1203	1.1763	1.1763
10	.9709	1.1389	1.0456			.9896	.8962
11	.9522	1.0456	.9522	.7842			.8962
12	.8589	1.0269	.8775	.6908	.8215	.8215	.9896
13	.8029	.9709	.7842	.7655	.7282	.7468	
14	.7842	.8589	.7392	.8402	.7023		.7095
15	.7577	.8029	.7023		.6653		.6908
16	.6908	.7762	.7468	.8413	.7282	.6535	.6722
17	.8215	.8686	.7842	.8779	.7655	.7842	
18	.7947	.8402	.8316		.8962	.8589	.8402
19	.9335	.9149	.6535	.8316	1.0642		1.0082
20	1.1016	1.1016	1.1763	1.1088	1.0829		.9709
21	1.1203	1.1203	1.0269	.961	.9709	.9149	1.0082
22	.9896	1.0082	1.0082	.9425	.8775		.8775
23	.9149	.9335	.9522	.8686	.7842	.7468	.7842
24	.8029	.8402	.8402	.8589	.8131	.7282	.6722
Max	1.2382	1.1949	1.1763	1.1949	1.1203	1.1949	1.1763
Min	.6908	.7762	.6535	.6908	.6653	.6535	.6348
Avg	.8901	.9391	.8929	.9073	.8478	.8435	.8410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 241 / 11KV DABKI I/C NO.1

SPARE FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1098	1.9231	2.0165		1.9791	1.7924	
2	2.0165		1.9044			1.7177	1.6057
3	1.9605		1.8858			1.643	1.5684
4	1.8671	2.0538	1.9231	1.9605	2.1285	1.6804	1.6057
5	1.8671	2.0911	1.9418		1.9044	1.7737	1.7364
6	1.9231	2.4646	2.0351	2.1845	2.3339	1.8858	1.9044
7	2.0351	2.2965	2.1658		2.2965	2.1658	2.2218
8	2.1845		2.1845	2.3712		2.1845	2.2218
9	2.2779	2.2592		2.1472	2.0165	2.1098	2.1845
10	2.1098	2.1845	2.1658			1.9231	1.8298
11	2.0165	2.0725	1.9418	1.8484			1.8298
12	1.9231	2.1285	1.7737	1.7924	1.8111		1.8111
13	1.7737	2.0538	1.8298	1.8671	1.6617	1.643	
14	1.7364	1.9791	1.7364	2.0911	1.6617		1.587
15	1.9044	1.9044	1.1763		1.6057		
16	1.6804	1.9791	1.1576	1.8671	1.643		
17	1.9605	1.9044	1.4003	2.0351	1.6991	1.6244	
18	1.8298	1.9231	1.8858		1.8858	1.7737	1.7364
19	1.9418	1.9978	1.7737	2.0165	2.2592		2.1658
20	2.3899	2.3339	2.3712	2.3777	2.2779		2.1845
21	2.4459	2.4459	2.2965	2.4326	2.2405	2.1098	2.2405
22	2.4832	2.3339	2.4459	2.3339	2.3152		2.3525
23	2.4646	2.2592	2.2405	2.1472	2.0725	1.8671	1.9418
24	2.1472	2.0351	2.0725	2.0538	2.1472	1.7924	1.6617
Max	2.4832	2.4646	2.4459	2.4326	2.3339	2.1845	2.3525
Min	1.6804	1.9044	1.1576	1.7924	1.6057	1.6244	1.5684
Avg	2.0437	2.1249	1.9272	2.0954	1.9968	1.8554	1.9152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 242 / 11 KV DABKI I/C NO.2

SPARE FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7375	1.8111	1.9774		1.9959	1.6804	1.5123
2	1.6817		1.8665			1.6617	1.475
3	1.6263		1.7002			1.6078	1.4377
4	1.6448	1.7926	1.7002	1.9387	1.848	1.5708	1.419
5	1.6817	1.8111	1.7556		1.885	1.5181	1.4563
6	1.8296	1.9231	1.8671	2.0328	1.9753	1.6991	1.6078
7	1.7741	2.0351	1.8858		1.885	1.7551	1.8296
8	1.7741		1.7924	1.9418		1.7187	1.7551
9	1.6448	1.7926		1.6095	1.848	1.7177	1.7002
10	1.5927	1.6827	1.5402			1.475	1.5497
11	1.4998	1.5546	1.3756	1.5384			1.3032
12	1.4685	1.5546	1.4175	1.4506	1.2894		1.1706
13	1.5364	1.6108	1.4148	1.3696	1.4083	1.1706	
14	1.5181	1.4815	1.448	1.4661	1.4449		1.2567
15	1.5203	1.4998	1.5746		1.3535		
16	1.3756	1.4815	1.5565	1.4842	.724		
17	1.4266	1.7741	1.6297	1.6057	.7602	1.2536	
18	1.4842	1.6832	1.5939		1.6991	1.379	1.3169
19	1.5927	1.7375	1.9004	1.7737	1.9004		1.6095
20	2.0452	1.8823	2.1216	2.0668	1.9387		1.7556
21	2.1622	2.1399	2.1807	2.1582	1.9774	1.7558	1.8298
22	2.1807	2.2546	2.3655	2.2916	1.9404		1.8298
23	2.2361	2.2916	2.3285	2.2405	1.848	1.5939	1.6991
24	1.7558	2.0883	2.0513	2.1216	2.1068	1.7177	1.531
Max	2.2361	2.2916	2.3655	2.2916	2.1068	1.7558	1.8298
Min	1.3756	1.4815	1.3756	1.3696	.724	1.1706	1.1706
Avg	1.6996	1.8039	1.7845	1.8181	1.6752	1.5797	1.5522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 401 / 33KV I/C APATAPA TO DABKI Sheddable Rural/Mix Feeder
SOUR Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0329	3.9209	3.9769		4.369	3.6408	
2	3.8649		3.7529			3.5848	3.2487
3	3.6408		3.6214			3.5288	3.1602
4	3.5288	3.9043	3.6408	4.0741	3.9918	3.5082	3.1047
5	3.5288	4.0175	3.8477		3.9918	3.3951	3.1047
6	3.9769	4.1872	4.0741	4.1872	4.257	3.6214	3.8089
7	4.0889	4.481	4.3004		4.481	4.1872	4.145
8	4.257		4.2438	4.7051		4.0175	3.7529
9	4.0889	4.201		4.0329	4.369	3.8649	3.7912
10	3.8255	3.9209	3.8809			3.5288	3.3608
11	3.6969	3.7529	3.3048	3.5288			3.0247
12	3.5482	3.8089	3.1927	3.3471	3.2487		3.0247
13	3.4168	3.6037	3.3265	3.3819	3.1367	2.8567	
14	3.4928	3.4168	3.2487	3.6591	3.2487		2.8292
15	3.4928	3.5648			3.0807		2.9127
16	3.1927	3.5848	8.2899		2.3525	2.7446	
17	3.4728	3.6969	3.1927	3.638	2.4086	2.9687	
18	3.3265	3.7529	3.5848		3.1824	3.2156	2.9938
19	3.4374	3.8809	3.9363	3.7311	4.1027		3.8649
20	4.481	4.3799	4.537	4.6016	4.313		
21	4.537	4.5931	4.537	5.3778	4.313	3.8809	4.201
22	4.537	4.7611	4.7051	4.6571	4.257		
23	4.6491	4.7051	4.5931	4.4907	3.8649	3.7529	3.6408
24	4.145	4.1872	4.313	4.1872	4.369	3.6969	3.3048
Max	4.6491	4.7611	8.2899	5.3778	4.481	4.1872	4.201
Min	3.1927	3.4168	3.1927	3.3471	2.3525	2.7446	2.8292
Avg	3.8441	4.0153	4.0955	4.1066	3.7546	3.5290	3.4041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 201 / 11KV RPTS Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.251	1.1317	1.307	1.307	1.1488	1.307	1.0456
2	1.2136	1.0974	1.2696	1.2696	1.1145	1.0829	1.0082
3	1.1763	1.0974	1.2323	1.2323	1.0974	1.0829	1.0082
4	1.1949	1.0974	1.2323	1.2136	1.0974	1.0829	1.0082
5	1.1576	1.0974	1.2136	1.251	1.1145	1.0829	1.0642
6	1.1763	1.0974	1.2136	1.2696	1.1317	1.1203	1.1203
7	1.3443	1.2003	1.3817	1.363	1.3032	1.2323	1.2323
8	1.4563	1.3032	1.475	1.3256	1.2689	1.3443	1.0456
9	1.4003	1.286	1.419	1.307	1.2174	1.4003	1.3443
10	1.2346	1.3443	1.307	1.2003	1.1949	1.2883	1.2003
11	1.1488	1.4003	1.1949		1.1203		1.166
12	1.2174	1.3443	1.0829	1.0288	1.0269	1.251	1.2517
13	1.1831	1.2696	1.1949	1.1317	1.1203	1.2136	1.2689
14	1.0288	1.1203	1.0829	.9602	1.0456	1.0269	.9945
15	1.0288	1.0642	1.0456		1.0829	1.0269	.8573
16	.9945	1.1016	1.0117	1.0631	1.1763	1.0456	.8402
17	1.1488	1.2696	1.1949	1.1317	1.1763	1.2136	
18	1.2003	1.307	1.307	1.2346	1.1203	1.3817	1.0631
19	1.2689	1.3443	1.3817	1.286	1.2323	1.4003	1.3032
20	1.4232	1.4937	1.4937	1.3889	1.307	1.419	1.3717
21	1.3032	1.4377	1.3817	1.3203	1.1576	1.2323	1.2003
22	1.2003	1.4377			1.2696	1.1949	1.0974
23	1.2346	1.4003	1.3817	1.2346	1.1949	1.1203	1.0288
24	1.307	1.2003	1.3443	1.3256	1.166	1.1203	1.0829
Max	1.4563	1.4937	1.4937	1.3889	1.307	1.419	1.3717
Min	.9945	1.0642	1.0117	.9602	1.0269	1.0269	.8402
Avg	1.2205	1.2476	1.2673	1.2307	1.1619	1.2031	1.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 204 / 11 KV Cotton Market Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.8573	1.0456	1.0082	.8916	.8589	.8215
2	.7842	.8573	1.0082	.9709	.8573	.8589	.7842
3	.7468	.7716	.9335	.9709	.823	.8215	.7842
4	.7468	.7716	.8589	.9709	.8573	.7468	.7468
5	.7468	.7716	.8589	.9335	.8573	.7468	.7468
6	.7468	.7716	.8402	.8962	.823	.7468	.8215
7	.8215	.823	.9335	.9335	.9602	.7842	.8962
8	.8402	.9259	.9335	.9335	.9431	.7468	.8962
9	.8962	.9431	1.0082	.9335	.8573	.8402	.8402
10	.8573	1.0269	1.0269	.9602	1.0456	.8215	1.0288
11	.7716	1.0456	.9149		.9335		.8916
12	.7888	1.0829	.8589	.8916	.8962	.8962	1.0288
13	.8402	.9709	.8962	.8916	.9335	.8962	1.0288
14	.7888	.8962	.8402	.823	.8589	1.0456	.8916
15	.7545	.8962	.8215		.7468		.7545
16	.7545	.9335	.8402	.823	.8775	1.0456	.7202
17	.7716	.9709	.8402	.823	.9335	1.0456	
18		.9335	.9335	.8916	.9335	1.0456	.7545
19		.9335	.9335	.9259	1.0456	1.0456	.9602
20	1.2003	1.1203	1.0269	.9602	1.0456	1.0456	.9602
21	1.0288	1.0456	1.0082	.8916	.9709	.9522	.8916
22	1.0288	1.0456		.9602	.9709	.9335	.823
23	.9602	1.0269	1.0456	.9431	.8962	.8962	.7716
24	.8962	.9602	1.0456	1.0456	.9602	.8962	.8215
Max	1.2003	1.1203	1.0456	1.0456	1.0456	1.0456	1.0288
Min	.7468	.7716	.8215	.823	.7468	.7468	.7202
Avg	.8451	.9326	.9327	.9264	.9133	.8962	.8550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 205 / 11 KV Tajnapeth Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	.9431	1.0829	1.0719	.9602	.9335	.8501
2	.9335	.9431	1.0456	1.0349	.9259	.8775	.8501
3	.924	.9431	1.0269	1.0349	.8916	.8402	.8316
4	.8871	.8916	1.0269	.961	.8916	.8402	.8131
5	.8316	.8916	1.0269	.961	.8916	.8402	.8316
6	.8316	.8573	1.0269	1.0164	.9431	.8402	.8871
7	.8871	.8573	1.0269	1.0349	.9602	.9335	.924
8	.8871	.8916	1.0269	1.0164	.9431	.9335	.924
9	.7392	.9431	1.0456	1.0164	.9431	1.0269	1.1088
10	1.0631	1.0269	1.0164	.9602	1.1203	1.0164	1.0288
11	1.0631	.9335	1.0349		1.0456		1.0631
12	1.0974	1.0269	.9795	.9945	.9335	1.0349	1.1317
13	1.0974	.9709	1.0534	.9602	1.0456	1.0164	1.1317
14	1.0288	.9709	1.0164	.9945	1.0269	1.0829	.9774
15	.9602	.9709	.9979		1.0082		.8916
16	.9602	.9709	1.0349	1.0288	1.0456	1.0349	.8916
17	.9602	.9709	1.0349	.9602	1.0456	1.0349	
18	.9602	.9709	1.0349	1.0288	1.0642	1.1088	.8916
19	.8916	.9709	1.0349	.9602	1.0642	.9979	.8916
20	1.0631	1.0456	1.1088	1.0631	1.1203	1.0349	1.0288
21	1.0288	1.0456	1.0349	1.0288	1.0456	.961	.9431
22	1.0288	1.1203		1.0288	1.0456	.9425	.9088
23	1.0288	1.2136	1.1458	1.0288	1.0269	.924	.8573
24	1.0349	1.0288	1.1203	1.1088	1.0288	.9709	.8871
Max	1.0974	1.2136	1.1458	1.1088	1.1203	1.1088	1.1317
Min	.7392	.8573	.9795	.9602	.8916	.8402	.8131
Avg	.9645	.9750	1.0428	1.0133	1.0007	.9648	.9367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 206 / NAIGAON

SPARE FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.9431	1.1203	1.531	.823
2	.9335	.9259	1.1203	1.4937	.7716
3	.9335	.8916	1.1203	1.4937	.7716
4	.8962	.8573	1.0456	1.4563	.7716
5	.8962	.8573	1.0456	1.419	.7716
6	.9335	.7716	1.0269	1.4003	.8573
7	.9335	.7373	1.0269	1.4003	.7545
8	.9709	.7545	.8589	1.3443	.7716
9	.8962	.7716	.8402	1.307	.6859
10	.7716	.7468	.8402	1.2003	.8402
11	.7716	.8402	.7468		.8402
12	.8573	.8402	.7468	.6859	.7468
13	.8573	.8402	1.4003	.6859	.7468
14	.823	.8589	1.3717	.6859	.7468
15	.8573	.8402	1.531		
16	.8573	.9335	1.475	.6859	
17	.8573	1.0269	1.419	.8573	
18	.8573	1.0269	1.4003	.8573	
19	.9431	1.0269	1.4003	.8573	
20	.9259	1.1203	1.531	1.0288	
21	1.0288	1.2136	1.5684	1.1145	
22	.9431	1.307		1.1145	
23	.9431	1.307	1.643	1.0288	
24	1.0829	.9431	1.307	1.5684	1.0288
Max	1.0829	1.307	1.643	1.5684	1.0288
Min	.7716	.7373	.7468	.6859	.6859
Avg	.9059	.9326	1.1994	1.1462	.7952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 241 / 11KV MOHATA I/C NO.1

SPARE FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.251	1.1317	1.307	1.307	1.1488	2.5393	2.2032
2	1.2136	1.0974	1.2696	1.2696	1.1145	2.3525	2.1472
3	1.1763	1.0974	1.2323	1.2323	1.0974	2.2405	2.1285
4	1.1949	1.0974	1.2323	1.2136	1.0974	2.2405	2.1098
5	1.1576	1.0974	1.2136	1.251	1.1145	2.2405	2.1472
6	1.1763	1.0974	1.2136	1.2696	1.1317	2.3525	2.2405
7	1.3443	1.2003	1.3817	1.363	1.3032	2.4646	2.4646
8	1.4563	1.3032	1.475	1.3256	1.2689	2.4646	2.1658
9	1.4003	1.286	1.419	1.307	1.2174	2.5579	2.5766
10	1.2346	1.3443	1.307	1.2003	1.1949	2.1845	2.332
11	1.1488	1.4003	1.1949		1.1203		2.4177
12	1.2174	1.3443	1.0829	1.0288	1.0269	2.4832	2.4691
13	1.1831	1.2696	1.1949	1.1317	1.1203	2.4086	
14	1.0288	1.1203	1.0829	.9602	1.0456	2.1845	2.1262
15	1.0288	1.0642	1.0456		1.0829		1.9547
16	.9945	1.1016	1.1016	1.0631	1.8484	2.2032	1.9376
17	1.1488	1.2696	1.1949	1.1317	2.0165	2.4086	
18	1.2003	1.307	1.307	1.2346	1.9418	2.6886	2.2119
19	1.2689	1.3443	1.3817	1.286	2.2779	2.7446	1.3032
20	1.4232	1.4937	1.4937	1.3889	2.3525	2.838	2.7778
21	1.3032	1.4377	1.3817	1.3203	2.2032	2.5766	2.6063
22	1.2003	1.4377		1.2689	2.2779	2.5206	2.4177
23	1.2346	1.4003	1.3817	1.2346	2.4646	2.3899	2.3148
24	1.307	1.2003	1.3443	1.3256	1.166	2.4646	2.2779
Max	1.4563	1.4937	1.4937	1.3889	2.4646	2.838	2.7778
Min	.9945	1.0642	1.0456	.9602	1.0269	2.1845	1.3032
Avg	1.2205	1.2476	1.2713	1.2324	1.4847	2.4340	2.2423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 242 / 11 KV MOHATA I/C NO. 2

SPARE FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7633	2.7435	3.2487	3.6222	2.6749	1.7924	1.6804
2	2.6513	2.7263	3.1741	3.5101	2.5549	1.7364	1.643
3	2.6139	2.6063	3.0807	3.5101	2.4863	1.6617	1.6244
4	2.5393	2.5206	2.9313	3.3981	2.5206	1.587	1.5684
5	2.4832	2.5206	2.9313	3.3234	2.5206	1.587	1.587
6	2.5206	2.4006	2.894	3.3234	2.6235	1.587	1.7177
7	2.6513	2.4177	2.9874	3.3794	2.6749	1.7177	1.8298
8	2.7073	2.572	2.8193	3.3048	2.6578	1.6804	1.8298
9	2.5393	2.6578	2.894	3.2674	2.4863	1.8671	1.9605
10	2.692	2.8006	2.894	3.1207	3.006	1.8484	2.0576
11	2.6063	2.8193	2.7073		2.8193		1.9547
12	2.7435	2.95	2.5953	2.4006	2.5766	1.9418	2.1605
13	2.7949	2.782	3.3608	2.5377	2.726	1.9231	2.1605
14	2.6406	2.726	3.3608	2.5034	2.6326	2.1285	1.869
15	2.572	2.7073	3.3608		1.7551		1.6461
16	2.572	2.838	3.3608	2.5377	1.9231	2.0911	.8402
17	2.5892	2.9687	3.3048	2.6406	1.9231	2.0911	
18	1.8176	2.9313	3.3794	2.7778	1.9978	2.1658	1.6461
19	1.8347	2.9313	3.3794	2.7435	2.1098	2.0538	1.8519
20	3.1893	3.2861	3.6782	3.0521	2.1658	2.0911	1.989
21	3.0864	3.3048	3.6222	3.035	2.0165	1.9231	1.8347
22	3.0007	3.4728		3.1036	2.0165	1.8858	1.7318
23	2.9321	3.5475	3.8462	3.0007	1.9231	1.8298	1.6289
24	3.0247	2.9321	3.4728	3.7342	3.0178	1.8671	1.7177
Max	3.1893	3.5475	3.8462	3.7342	3.0178	2.1658	2.1605
Min	1.8176	2.4006	2.5953	2.4006	1.7551	1.587	.8402
Avg	2.6486	2.8401	3.1862	3.0830	2.4087	1.8662	1.7622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 401 / 33KV APATAPA TO MOHATA S/S

DIVISION FEEDER

I/C Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.1136	6.7387	8.0098	8.3716	6.9445	7.0016	6.3203
2	6.7084	6.6358	7.7298	7.9836	6.6358	6.6655	6.0431
3	6.5421	6.3272	7.4497	7.8727	6.2757	6.4975	5.9877
4	6.5535	6.1728	7.1136	7.6509	6.2757	6.2734	5.9322
5	6.154	6.07	6.8896	7.4291	6.1214	6.2734	5.9322
6	6.2649	5.9671	6.8896	7.4846	6.4301	6.3855	6.3758
7	6.653	6.2757	7.1136	7.7063	6.6873	7.0016	7.041
8	6.653	6.4815	6.8896	7.3737	6.4301	6.7776	3.9363
9	6.5421	6.5844	7.1136	7.4291	6.2243	4.5931	4.4907
10	6.4301	6.8896	7.041	6.9959		5.655	4.3724
11	6.2757	6.9456	6.8193		6.8336		4.3724
12	6.5844	7.0576	3.9918	4.9383	6.5535	7.0965	4.6296
13	6.6358	6.7776	4.8234	5.607	6.7776	7.041	4.6811
14	6.3272	6.6655	4.6091	5.3498	6.6655	6.9302	4.0124
15	6.3786	6.6095	4.7051		5.7693		3.6008
16	6.3786	7.0016	8.5934	6.2757	6.6655	6.9302	3.5494
17	6.4301	7.3937	8.1499	5.6584	6.8896	7.0965	
18	5.7099	7.2257	8.3162	7.0988	6.9456	7.54	3.858
19	5.9156	7.2817	8.4271	7.0988	7.6178	7.7618	3.1379
20	7.7675	8.1779	8.8152	7.7675	7.9538	7.9281	7.7161
21	7.6646	8.4019	8.7043	7.7675	7.5057	7.3737	7.3045
22	7.5103	8.85			7.8418	7.3737	6.9445
23	7.6646	9.1301	9.3141	7.8704	7.6178	6.9856	6.6358
24	7.54	7.3045	8.682	8.7597	7.4074	7.2257	6.5975
Max	7.7675	9.1301	9.3141	8.7597	7.9538	7.9281	7.7161
Min	5.7099	5.9671	3.9918	4.9383	5.7693	4.5931	3.1379
Avg	6.6832	7.0402	7.2257	7.1662	6.8291	6.8367	5.3683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 402 / 33KV MOHATA TO VIDYUT B DIVISION FEEDER
S/S O/ Feeder KV- 33 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	2.8807	3.4728	3.4568	3.1379	2.6886	2.4691
2	2.9127	2.8292	3.3048	3.2373	2.9835	2.5766	2.2497
3	2.7435	2.6235	3.1367	3.1276	2.7263	2.5766	2.2497
4	2.7435	2.572	2.9687	3.0727	2.6749	2.4646	2.2497
5	2.524	2.4691	2.7446	2.8532	2.5206	2.4646	2.1948
6	2.5789	2.4691	2.8006	2.9081	2.6749	2.4646	2.4143
7	2.6886	2.6749	2.7446	2.963	2.7263	2.8006	2.7435
8	2.524	2.6235	2.5766	2.7435	2.5206	2.6326	
9	2.6337	2.6235	2.8006	2.8532	2.5206	.168	
10	2.5206	2.7446	2.8532	2.6749	2.8567	1.6461	
11	2.5206	2.7446	2.9081		2.9127		
12	2.6235	2.7446	.3292	1.4918	2.9687	2.6886	
13	2.6749	2.7446	.3292	1.9547	2.9127	2.7435	
14	2.6749	2.8006	.2743	1.9033	2.9687	2.6337	
15	2.7778	2.8567	.2743		2.9127		
16	2.6235	3.0807	4.1152	2.6749	2.9127	2.6337	
17	2.6749	3.1367	3.6763	1.9033	2.9127	2.6337	
18	2.6749	2.9687	3.6214	3.0864	3.0247	2.6886	
19	2.8292	3.0247	3.6763	3.0864	3.2487	2.963	
20	3.1379	3.4168	3.6763	3.3436	3.4168	3.0178	2.9321
21	3.2922	3.6408	3.7311	3.3436	3.3048	2.9081	2.8807
22	3.2922	3.9209	3.8958	3.6008	3.5288	2.963	2.7778
23	3.4979	4.201	4.1152	3.6523	3.2487	2.7984	2.6749
24	3.2373	3.1893	3.8649	3.7311	3.2407	2.9127	2.6337
Max	3.4979	4.201	4.1152	3.7311	3.5288	3.0178	2.9321
Min	2.5206	2.4691	.2743	1.4918	2.5206	.168	2.1948
Avg	2.8091	2.9575	2.8288	2.8938	2.9524	2.5485	2.5392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 202 / 11 KV Kholeshwar Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4191	.4191	.4191	.4382		.381
2	.381	.4191	.4191	.4191	.4382		.381
3	.381	.4191	.4191	.4001	.4382		.381
4	.381	.4191	.4191	.381	.4191		.381
5	.381	.4191	.4191	.381	.4191		.362
6	.3429	.3429	.362	.381	.4001		.362
7	.3429	.3239	.3239		.3429	.362	.3429
8	.381	.381	.4001	.381	.4191	.381	.3429
9	.4001	.4001	.4572	.4001		.381	.4001
10	.4001	.4191	.4763	.4001		.4382	.4191
11	.4191	.4191	.4954	.5144	.4954		.4954
12	.4382	.4763	.5144		.5525	.5144	.4954
13	.4572	.4763	.4954	.5335	.5525	.5144	.4763
14	.5144	.4763	.2858	.5144	.5144	.4954	.4001
15	.4763	.4191	.5144	.5716	.5335	.4763	.4954
16	.4572	.4954		.6287	.5716	.4954	.4954
17	.4954	.4763		.5716	.5335	.5144	
18	.4572	.4572	.4954	.5716	.5525	.5335	.4954
19	.5335	.5335	.5335	.5906	.5716	.5525	.5716
20	.5525	.5716	.4763	.6287		.5525	.5716
21	.5144		.5525	.5906		.4954	.5335
22	.4763	.4954	.4954	.4954		.4191	.4572
23	.4954	.5144	.4572	.4763		.4001	.4001
24	.4191	.4763	.4572	.4572	.4572	.362	.381
Max	.5525	.5716	.5525	.6287	.5716	.5525	.5716
Min	.3429	.3239	.2858	.381	.3429	.362	.3429
Avg	.4366	.4456	.4495	.4867	.4805	.4640	.4357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 203 / 11 KV Rajputpura Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3239	.3048	.3429	.362	.3048	.3048
2	.3429	.3429	.3048	.3429	.362	.2858	.3048
3	.3429	.3239	.3048	.3239	.3429	.2858	.3048
4	.3429	.3239	.3048	.3048	.3429	.2667	.2858
5	.3429	.3239	.3048	.3048	.3239	.2477	.2858
6	.3429	.2858	.2858	.3048	.3048	.2286	.2667
7	.3048	.2858	.3048		.2667	.2858	.2667
8	.3239	.3048	.2858	.3048	.3239	.2858	.2667
9		.3239	.3239	.3429		.2667	.3048
10		.3239	.4382	.4191		.381	
11	.4001	.4763	.6478	.5906	.5335		.5716
12	.6097	.5906	.724		.6097	.5716	.6478
13	.724	.5906	.8192	.7049	.6097	.6097	
14	.724	.6097	.8383	.743	.6287	.6287	.6287
15	.724	.6097	.8002	.7621	.6287	.6478	.6478
16	.6668	.6097		.7049	.6287	.6859	.6287
17	.2286	.6097		.724	.5525	.6859	
18	.7621	.6287	.7621	.7621	.5525	.724	.6668
19	.7621	.6859	.8002	.743	.5906	.724	.743
20	.7811	.724	.7621	.724		.724	.7049
21	.6097	.5716	.6287	.6287		.5335	
22	.4382	.4382	.4191	.4572		.362	
23	.381	.4001	.381	.381	.3239	.3048	.3239
24	.381	.3429	.3429	.362	.362	.3048	.3048
Max	.7811	.724	.8383	.7621	.6287	.724	.743
Min	.2286	.2858	.2858	.3048	.2667	.2286	.2667
Avg	.4945	.4604	.5040	.5127	.4552	.4498	.4452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 204 / 11 KV NEW CLOTH MARKET Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5335	.5716	.5335	.6859	.5906	.5716
2	.6097	.5335	.5716	.5144	1.829	.5716	.5716
3	.6097	.5335	.5716	.5144	.6478	.5716	.5716
4	.6097	.5335	.5716	.4954	.6478	.5335	.4382
5	.6097	.5335	.5716	.4763	.5716	.4954	.4954
6	.6097	.4572	.4763	.4763	.5335	.4954	.4763
7	.5335	.4763	.4954		.5525	.5144	.5144
8	.4763	.4763	.5144	.5716	.5335	.5335	.4954
9	.381	.5716	.5525	.5906		.5716	.5716
10	.5716	.6097	.7811	.7621		.6668	
11	.8002	.8764	1.1431	1.105	1.0669		.9526
12	1.1241	1.0098	1.2193		1.1812	1.1431	1.2574
13	1.2955	1.0669	1.1622	1.3336	1.1812	1.1622	.6478
14	1.2574	.9907	1.2574	1.3527	1.1431	1.2003	1.2193
15	.724	.9907	1.2384	1.3146	1.0669	1.1241	1.1812
16	.9907	1.105		1.3146	1.105	1.1812	1.1431
17	1.086	1.0479		1.3336	1.105	1.2003	
18	1.1431	1.105	1.2955	1.3908		1.2765	1.1812
19	1.2384	1.2193	1.3717	1.4098	1.2193	1.2955	1.3336
20	1.2765	1.2955	1.4098	1.3717		1.3336	1.2193
21	.9907	.9145	1.1431	1.0669		.9526	1.0098
22	.6668	.6478	.724	.7621		.7049	.6668
23	.5906	.6287	.6478	.6859		.6097	.5906
24	.6668	.5716	.6097	.5906	.7049	.5906	.5906
Max	1.2955	1.2955	1.4098	1.4098	1.829	1.3336	1.3336
Min	.381	.4572	.4763	.4763	.5335	.4954	.4382
Avg	.8113	.7804	.8591	.9076	.9279	.8400	.8045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 206 / 11 KV COLLECTOR OFFICE Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0382	.0191	
2	.0191	.0382	.0191	
3	.0191	.0382	.0191	
4	.0191	.0382	.0191	
5	.0191	.0382	.0191	
6	.0191	.0382	.0191	
7	.0191	.0382	.0191	
8	.0191	.0191	.0191	
9	.0191	.0191	.0191	
10	.0191	.0191	.0572	
11	.0191	.0191	.0762	
12	.0191	.0191	.0762	
13	.0191	.0191	.0762	
14	.0191		.0762	
15	.0191	.0191	.0762	
16	.0191	.0191		
17	.0191	.0191		
18	.0191	.0191	.0762	
19	.0191	.0191	.0381	
20	.0191	.0191	.0381	
21	.0191	.0191	.0191	
22	.0191	.0191	.0191	
23	.0191	.0191	.0191	
24	.0191	.0382	.0191	.0191
Max	.0191	.0382	.0762	.0191
Min	.0191	.0191	.0191	.0191
Avg	.0191	.0257	.0381	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 241 / 11 KV COLLECTOR OFFICE I/C

SPARE FEEDER

NO. Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.743	.724	.7621	.8002	.6668	.6859
2	.724	.743	.724	.7621	.8002	.6668	.6859
3	.724	.743	.724	.743	.7811	.6668	.6859
4	.724	.743	.724	.6859	.7621	.6287	.6668
5	.724	.743	.724	.6859	.743	.6097	.6478
6	.6478	.6287	.6478	.6859	.7049	.5906	.6287
7	.6478	.6097	.6287		.6097	.6478	.6097
8	.7049	.6859	.6859	.5716	.743	.6668	.6097
9	.724	.724	.7811	.743		.6478	.7049
10	.8383	.743	.9145	.8192		.8192	.8192
11	.8192	.8954	1.1431	1.105	1.0288		1.0669
12	1.0479	1.0669	1.2384		1.1622	1.086	1.1431
13	1.1812	1.0669	1.3146	1.2384	1.1622	1.1241	1.1241
14	1.2384	1.086	1.1241	1.2574	1.1431	1.1241	1.0288
15	1.2003	1.0288	1.3146	1.3336	1.1622	1.1241	1.1431
16	1.1241	1.105		1.3336	1.2003	1.1812	1.1431
17	.724	1.086		1.2955	1.086	1.2003	
18	1.2193	1.086	1.2574		1.105	1.2574	1.1622
19	1.2955	1.2193	1.3336	1.3336	1.1622	1.2765	1.3146
20	1.3336	1.2955	1.2384	1.3527		1.2765	1.2765
21	1.1241	1.105	1.1812	1.2193		1.0288	1.0669
22	.9145	.9335		.9526		.7811	.8192
23	.8764	.9145	.8383	.8573	.724	.7049	.724
24	.8002	.8192	.8002	.8192	.8192	.6668	.6859
Max	1.3336	1.2955	1.3336	1.3527	1.2003	1.2765	1.3146
Min	.6478	.6097	.6287	.5716	.6097	.5906	.6097
Avg	.9201	.9089	.9553	.9789	.9315	.8888	.8888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 242 / 11KV COLLECTOR OFFICE I/C SPARE FEEDER
NO.2 Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.5525	.5906	.5525	.6859	.5906	.5716
2	.6287	.5525	.5906	.5144	.6859	.5716	.5716
3	.6287	.5525	.5906	.5144	.6478	.5716	.5716
4	.6287	.5525	.5906	.4954	.6478	.5335	.5335
5	.6287	.5525	.5906	.4763	.5716	.4954	.4954
6	.6287	.4763	.4954	.4763	.5335	.4954	.4763
7	.5525	.4954	.5144		.5525	.5144	.5144
8	.4954	.4954	.5335	.6859	.5335	.5335	.4954
9	.4001	.5906	.5716	.5906		.5716	.5716
10	.5906	.6287	.8383	.7621		.6668	.724
11	.8192	.8954	1.2193	1.105	1.0669		.9526
12	1.1431	1.0288	1.2955		1.1812	1.1431	1.2574
13	1.3146	1.086	1.2384	1.3336	1.1812	1.1622	1.3527
14	1.2765	1.0098	1.3336	1.3527	1.1431	1.2003	1.2193
15	1.086	1.0098	1.3146	1.3146	1.0669	1.1241	1.1812
16	1.0098	1.1241		1.3146	1.105	1.1812	1.1431
17	1.105	1.0669		1.3336	1.105	1.2003	
18	1.1622	1.1241	1.3717	1.4289	1.0669	1.2765	1.1812
19	1.2574	1.2384	1.4098	1.4098	1.2193	1.2955	1.3336
20	1.2955	1.3146	1.448	1.3717		1.3336	1.2193
21	1.0098	.9335	1.1622	1.0669		.9526	1.0098
22	.6859	.6668	.743	.7621		.7049	.6668
23	.6097	.6478	.6668	.6859	.6478	.6097	.5906
24	.6859	.5906	.6287	.6097	.7049	.5906	.5906
Max	1.3146	1.3146	1.448	1.4289	1.2193	1.3336	1.3527
Min	.4001	.4763	.4954	.4763	.5335	.4954	.4763
Avg	.8446	.7994	.8972	.9162	.8604	.8400	.8358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 401 / 33KV APATAPA TO COLLECTOR SPARE FEEDER
I/C Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3717	1.4861	2.2291	1.4861	1.2574	1.2574
2	1.3717	1.3717	1.4861	1.4289	1.4861	1.2003	1.2574
3	1.3717	1.3717	1.4861	1.3146	1.4289	1.2003	1.2574
4	1.3717	1.3717	1.4861	1.3146	1.3717	1.2003	1.2003
5	1.3717	1.3717	1.4861	1.3146	1.3146	1.1431	1.1431
6	1.2574	1.2574	1.3146	1.3146	1.3146	1.086	1.1431
7	1.3146	1.3146	1.3717		1.3146		1.3146
8	1.3146	1.2574	1.3717	1.3146	1.3146	1.3717	1.2003
9	1.2003	1.3717	1.3717	1.3717		1.3717	1.3146
10	1.5432	1.6004	1.7718	1.6575		1.5432	1.5432
11	1.8861	1.8861	2.3434	2.2862	2.1148		2.1148
12	2.1719	2.1719	2.572		2.3434	2.2862	2.4006
13	2.4577	2.1719	2.6292	2.6292	2.3434	2.2862	2.4006
14	2.572	2.1719	2.4577	2.6292	2.2862	2.1719	2.2862
15	2.3434	2.2291	2.7435	2.6292	2.2862	2.2291	2.2862
16	2.1719	2.2291		2.6292	2.2862	2.3434	2.2862
17	1.829	2.2291		2.6863	2.2862	2.4006	
18	2.4577	2.2862	2.6292	2.6863	2.2291	2.4577	2.2862
19	2.572	2.4577	2.8006	2.8006	2.4006	2.6292	2.2862
20	2.6863	2.5149	2.7435	2.8006		2.6292	2.5149
21	2.8006	2.1719	2.4006	2.3434	1.7147	2.0576	2.0576
22	1.7718	1.7718	1.8861	1.7147	1.5432	1.5432	1.4861
23	1.6004	1.829	1.6575	1.6004	1.4861	1.3717	1.3146
24	1.5432	1.5432	1.6575	1.3717	1.5432	1.3717	1.3146
Max	2.8006	2.5149	2.8006	2.8006	2.4006	2.6292	2.5149
Min	1.2003	1.2574	1.3146	1.3146	1.3146	1.086	1.1431
Avg	1.8480	1.8052	1.9615	2.0031	1.8045	1.7796	1.7246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 201 / 11KV Bhim Nagar Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.7202	.7545	.8048	.7202	.6584	.6001
2	.703	.7202	.7202	.7682	.703	.6219	.6173
3	.703	.703	.6859	.7682	.6859	.6219	.6001
4	.703	.6859	.6859	.7682	.6859	.6219	.583
5	.703	.703	.6859	.7682	.6859	.6401	.6173
6	.7545	.7373	.7373	.8048	.7545	.6767	.6516
7	.7888	.7545	.7888	.823	.7716	.7316	.703
8	.7545	.7202	.7202	.8413	.7202	.7316	.6859
9	.6859	.7202	.6859		.6859	.8048	
10	.6173	.6859	.6516				.695
11	.583	.6859	.6173	1.2071	.6516		.7316
12	.6173	.7202	.583	1.4998	.6173		.6516
13	.6173	.6516	.583	1.4266	.583	.5144	.6344
14	.6173	.6516	.5487	.5853	.5316	.4801	.583
15		.6344	.5658	.5487	.5487	.4801	.6001
16	.6219	.6173	.583	.583	.5853	.5487	
17	.583	.6344	.583	.583	.5853	.5658	
18	.695	.6516	.6687		.7316	.6859	.6584
19	.7316	.7202	.7202	.6516	.7682	.6687	.7316
20	.8413	.8059	.7545	.7545	.7682	.703	.7682
21	.8048	.7888	.7545	.7888	.7499	.6516	.7499
22	.7716	.823	.7865	.7888	.7316	.6687	.7316
23	.7888	.7888	.8596	.823	.7316	.6859	.7316
24	.7545	.7545	.7888	.823	.7545	.695	.6516
Max	.8413	.823	.8596	1.4998	.7716	.8048	.7682
Min	.583	.6173	.5487	.5487	.5316	.4801	.583
Avg	.7026	.7116	.6880	.8290	.6848	.6408	.6656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-sta

Feeder No / Name : 202 / 11KV Tilak Road Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6687	.703	.7316	.6687	.5853	.5316
2	.6173	.6516	.6687	.695	.6344	.5487	.5144
3	.6173	.6516	.6173	.6584	.6001	.5487	.5144
4	.6173	.6344	.6173	.6219	.6001	.5487	.5144
5	.6173	.6344	.6173	.6219	.583	.5487	.5144
6	.583	.583	.583	.6219	.583	.5487	.5144
7	.583	.583	.6173	.6584	.583	.5853	.5316
8	.6173	.583		.6219	.6001	.5853	.5658
9	.6173	.6001	.583			.6584	
10	.8402	.6687	.6516		.6516		.9511
11	1.0974	.7716	1.166	1.2071	1.2346		1.2803
12	1.2003	.8745	1.3032	1.4998	1.406	1.2517	1.3375
13	1.2003	.8916	1.2517	1.4266	1.3717	1.3375	1.4403
14	1.3032	.8573	.1029	1.3535	1.2346	1.2174	1.2689
15	1.4266	.823	.1029	1.2689	1.39	1.166	1.286
16	1.2437	.7716	1.4746	1.2003	1.3535	1.1145	
17	1.4918	.7545	1.4403	1.2689	1.4998	1.2517	
18	1.3535	.7545	1.3375		1.4266	1.3375	1.3169
19	1.3717	.823	1.3375	1.3032	1.3535	1.2346	1.3535
20	1.2803	.8573	1.3032	1.1831	1.0974	1.166	1.2071
21	1.0425	.7888	1.0631	.9259	.8779	.9602	.9877
22	.7545	.7888	1.134	.7545	.695	.6859	.9877
23	.7202	.7545	.8048	.7202	.695	.6173	.6584
24	.6859	.6859	.7202	.7682	1.2003		.5487
Max	1.4918	.8916	1.4746	1.4998	1.4998	1.3375	1.4403
Min	.583	.583	.1029	.6219	.583	.5487	.5144
Avg	.9375	.7273	.8783	.9577	.9713	.8809	.8964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-sta

Feeder No / Name : 204 / 11KV Bhandpura Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.7147	1.7833	1.9022	1.7318	1.4746	1.406
2	1.6461	1.6804	1.749	1.829	1.7147	1.4746	1.406
3	1.6461	1.6632	1.7147	1.829	1.6632	1.4746	1.3889
4	1.6461	1.6461	1.7147	1.829	1.6632	1.4918	1.3889
5	1.6461	1.6461	1.7147	1.829	1.6632	1.5089	1.4575
6	1.749	1.749	1.8176	1.9753	1.749	1.6289	1.6804
7	1.8176	1.8519	1.869	2.0119	1.8861	1.749	1.8176
8	1.7833	1.9204	1.8861	2.0668	1.9204	1.749	1.8004
9	1.8176	2.0233	1.8519		1.8861		1.9033
10	1.8861	1.9547	1.8861			1.4746	1.749
11	1.8519	1.9204	1.5261	1.8473	1.749		1.749
12	1.8176	1.9204	1.7147	1.9022	1.749	1.5432	1.7147
13	1.8176	1.7833	1.6804	1.134	1.6118	1.4403	1.6804
14	1.6461	1.6461	1.6118	1.7558	1.5432	1.9204	1.2689
15	1.6095	1.6804	1.6461	1.6289	1.4998	1.3375	1.286
16	1.6461	1.6461	1.3375	1.5432	1.5729	1.406	
17	1.5432	1.7318		1.6461	1.6461	1.5432	
18	1.957	1.8519	1.8519		1.9387	1.749	1.6278
19	2.1948	2.0233	2.0919	2.0919	2.1582	1.989	2.0851
20	2.4143	2.1605	2.1948	2.0576	2.1582	1.9204	2.1033
21	2.0851	1.9547	1.9204	1.9547	2.0485	1.7147	1.9022
22	1.9204	2.0233	2.0119	1.9547	1.829	1.6804	1.7924
23	1.8861	1.989	1.9936	1.8861	1.7558	1.5775	1.7558
24	1.749	1.7833	1.8861	1.9022	1.8176	1.5089	1.4746
Max	2.4143	2.1605	2.1948	2.0919	2.1582	1.989	2.1033
Min	1.5432	1.6461	1.3375	1.134	1.4998	1.3375	1.2689
Avg	1.8107	1.8318	1.8024	1.8370	1.7807	1.6071	1.6563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 205 / 11 KV Ganesh Nagar Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.6118	1.6804	1.7924	1.5947	1.0631	1.0288
2	1.5261	1.5775	1.5775	1.6644	1.5261	1.0631	.9945
3	1.5261	1.4746	1.4746	1.6461	1.4232	1.0288	.9602
4	1.5261	1.406	1.4575	1.6095	1.4232	1.0288	.9602
5	1.5261	1.3889	1.4232	1.6095	1.4232	1.0117	.9774
6	1.4575	1.3717	1.4232	1.6095	1.4918	1.2003	1.0631
7	1.4575	1.5261	1.3889	1.6827	1.5432	1.2003	1.1831
8	1.3889	1.5261	1.3546	1.6278	1.4403	1.2003	1.1488
9	1.4232	1.4918	1.3546		1.4575		
10	1.3546	1.3546	1.3203				1.2437
11	1.2517	1.3203	1.0802	1.2986	1.2003		1.134
12	1.3032	1.3546	1.1317	1.3535	1.1317	.9602	1.0974
13	1.3375	1.3375	1.1145	1.3169	1.2003	1.0117	1.0631
14	1.2174	1.3375	1.1488	1.3717	1.2346	1.9204	1.0117
15	1.2174	1.406	1.3032	1.286	1.2986	.9259	1.0288
16	1.2803	1.4232	1.3375	1.3375	1.262	.9431	
17	1.2003	1.4232		1.2346	1.0974	1.0288	
18	1.0059	1.3717	1.3546		1.2254	1.0802	1.0608
19	1.0974	1.4918	1.4918	1.3889	1.4083	1.2517	1.2986
20	2.0119	1.6289	1.7318	1.6461	1.39	1.3375	1.4266
21	1.9753	1.749	1.7661	1.6804	1.3717	1.286	1.4266
22	1.8519	1.8176	1.8656	1.7661	1.3535	1.2689	1.2803
23	1.8519	1.869	1.9936	1.7661	1.2986	1.1488	1.2254
24	1.6632	1.7147	1.8004	1.8839	1.6461	1.1317	1.046
Max	2.0119	1.869	1.9936	1.8839	1.6461	1.9204	1.4266
Min	1.0059	1.3203	1.0802	1.2346	1.0974	.9259	.9602
Avg	1.4610	1.4989	1.4598	1.5511	1.3670	1.1472	1.1266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 206 / 11 KV Shivji Nagar Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.4115	.4207	.3944	.2915	.2915
2	.3601	.3429	.3944	.4024	.3601	.2915	.2915
3	.3601	.3429	.3772	.4024	.3429	.2915	.2743
4	.3601	.3429	.3772	.4024	.3429	.2915	.2743
5	.3601	.3429	.3772	.4024	.3429	.3429	.2743
6	.3601	.3601	.3772	.4024	.3944	.3772	.2915
7	.3601	.3429	.3601	.439	.3772		.3086
8	.3601	.3429	.3258	.3658	.3601		.2743
9	.3601	.3429	.3601				
10	.2915	.3429	.3429		.3258		.3109
11	.3086	.3258	.3258	.3475	.3258		.3086
12	.2401	.3258	.3258	.2743	.3086	.2915	.2915
13	.2572	.3258	.3086	.2561	.3086	.3086	.3086
14	.3258	.3258	.3086	.2743	.2915	.2743	.2743
15	.3475	.3086	.3429	.2572	.3109	.2743	.2743
16	.3292	.3086			.3292	.2572	
17	.3086	.3086		.3429	.3109	.2572	
18	.3292	.3258	.3429		.4024	.3086	.2926
19	.3841	.3601	.3944	.4115	.4207	.3086	.3841
20	.4207	.4115	.3944	.4287	.4024	.3429	.4024
21	.4207	.4287	.4115	.4115	.3841	.3429	.4207
22	.4115	.4287	.439	.4115	.3658	.3429	.3841
23	.4115	.4458	.4755	.4115	.3841	.3258	.3658
24	.3944	.3944	.4115	.4572	.3944	.3258	.2915
Max	.4207	.4458	.4755	.4572	.4207	.3772	.4207
Min	.2401	.3086	.3086	.2561	.2915	.2572	.2743
Avg	.3516	.3544	.3720	.3761	.3557	.3077	.3138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
sta

Feeder No / Name : 241 / 11 KV Shivji Nagar I/C No.

SPARE FEEDER

1 Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.3889	1.4575	1.5364	3.7209	1.2437	1.1317
2	1.3203	1.3717	1.3889	1.4632	1.3375	1.1706	1.1317
3		1.3546	1.3032	1.4266	1.286	1.1706	1.1145
4	1.3203	1.3203	1.3032	1.39	1.286	1.1706	1.0974
5	1.3203	1.3375	1.3032	1.39	1.2689	1.2254	1.1317
6	1.3375	1.3203	1.3203	1.4266	1.3375		1.166
7	1.3717	1.3375	1.406	1.4815	1.3546	1.3169	1.2346
8	1.3717	1.3032	1.3032	1.4632	1.3203	1.3169	1.2517
9	1.3032	1.3203	1.3375		1.3375	1.4632	
10	1.4575	1.3546	1.5089				1.6461
11	1.6804	1.4575	1.7833	1.8656	1.8861		2.0119
12	1.8176	1.5947	1.8861	2.1216	2.0233	1.8176	1.989
13	1.8176	1.5432	1.8347	2.0119	1.9547	1.8519	2.0748
14	1.9204	1.5089		1.9387	1.7661	1.6975	1.8519
15	2.0485	1.4575	.6687	1.8176	1.9387	1.6461	1.8861
16	1.8656	1.3889	2.0919	1.7833	1.9387	1.6804	
17	2.0748	1.3889		1.8519	2.0851	1.8176	
18		1.406	2.0062		2.1582	2.0233	1.9753
19	2.1033	1.5432	2.0576	1.9547	2.1216	1.9033	2.0851
20	2.1216	1.6632	2.0576	1.9376	1.8656	1.869	1.9753
21	1.8473	1.5775	1.8176	1.7147	1.6278	1.6118	1.7375
22	1.5261	1.6118	1.9204	1.5432	1.4266	1.3546	1.7193
23	1.5089	1.5432	1.6644	1.5432	1.4266	1.3032	1.39
24		1.4403	1.5089	1.5912	1.4403	1.3535	1.2003
Max	2.1216	1.6632	2.0919	2.1216	3.7209	2.0233	2.0851
Min	1.3032	1.3032	.6687	1.39	1.2689	1.1706	1.0974
Avg	1.6415	1.4389	1.5877	1.6787	1.7352	1.5242	1.5620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 242 / 11 KV Shivji Nagar I/C No.
2 Feeder KV- 11 / OUTGOING

SPARE FEEDER

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6694	3.7037	3.8752	4.1152	3.7209	3.0361	2.7263
2	3.5322	3.6008	3.7209	3.8958	3.6008	3.0178	2.692
3	3.5322	3.4808	3.5665	3.8775	3.4294	2.9813	2.6235
4	3.5322	3.3951	3.5494	3.8409	3.4294	2.9995	2.6235
5	3.5665	3.3779	3.5151	3.8409	3.4294	2.9995	2.7092
6		3.4808	3.618	3.9872	3.6351	3.3836	3.035
7	3.6351	3.7209	3.618	4.1335	3.8066	3.5482	3.3093
8	3.5322	3.7894	3.5665	4.0604	3.7209	3.5482	3.2236
9	3.6008	3.858	3.5665		3.6694	3.6397	
10	3.5322	3.6523	3.5494				3.4202
11	3.4122	3.5665	2.9321	3.4934	3.275		3.3288
12	3.3608	3.6008	3.1722	3.53	3.155	1.0802	3.1036
13	3.4122	3.4465			3.1207	2.7263	3.0521
14	3.1893	3.3093		3.4019	3.0693	4.1152	2.5549
15		3.3951	1.5775	3.1722	3.1093	2.5377	2.5892
16	3.2556	3.3779	3.3608	2.8807	3.1642	2.6063	
17	3.0521	3.4637		3.2236	3.0544	2.8292	
18	3.2922	3.5494	3.5494		3.5665	3.1379	2.9813
19	3.6763	3.8752	3.9781	3.8923	3.9872	3.5494	3.7677
20	4.8468	4.201	4.321	4.1324	3.9506	3.6008	3.9323
21	4.481	4.1324	4.0981	4.0466	3.8043	3.3436	3.7494
22	4.1838	4.2696	4.3164	4.1324	3.5482	3.2922	3.4568
23	4.1495	4.3038	4.4627	4.0638	3.4385	3.0521	3.3471
24		3.8923	4.0981	4.2433	3.858	3.1642	2.8121
Max	4.8468	4.3038	4.4627	4.2433	3.9872	4.1152	3.9323
Min	3.0521	3.3093	1.5775	2.8807	3.0544	1.0802	2.5549
Avg	3.6402	3.6851	3.6196	3.7982	3.5019	3.0995	3.0970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024055 / P.K.V. Washim Road, Sub

Statio

Feeder No / Name : 201 / 11 KV Gajraj Feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2054	.2172	.2241	.2054	.181	.168
2	.2054	.1867	.2172	.2241	.1867	.181	.168
3	.2054	.2054	.2172	.2241	.1867	.181	.168
4	.2054	.1848	.2172	.2241	.1867	.181	.168
5	.2054	.1867	.2172	.2263	.2054	.2172	.1867
6	.2054	.2033	.2172	.2263	.2241	.2172	.1867
7	.2241	.2241	.2172	.2263	.2241	.2172	.2054
8	.2427	.2427	.2172	.2054	.1991	.2172	.2054
9	.2241	.2241	.2218	.2427	.2033	.181	.2241
10	.2427	.2195	.2614		.2012		.1867
11	.2241	.2561	.2241				.2427
12	.2241		.1867				.2427
13	.2241	.2402	.1867		.2534	.2427	
14	.1867	.2195			.2561	.2427	.2614
15	.2241	.2587		.2402			.2241
16	.2427	.2427		.2241	.2012	.3174	.2172
17	.2241			.168	.2195	.2987	.2353
18	.2427	.2378	.1867	.1848	.2561	.2801	.2587
19	.2614	.2561	.2614	.1867		.2614	.2772
20	.2614	.2378	.2801	.2614		.2241	.2715
21	.2427	.2561	.2614	.2427	.2172	.1867	
22	.2427	.2561	.2614	.2427	.1928	.1867	.2172
23	.2241	.2195	.2241	.2218	.1949	.1867	.1829
24	.2054	.2054	.2172	.2241	.2054	.1753	.168
Max	.2614	.2587	.2801	.2614	.2561	.3174	.2772
Min	.1867	.1848	.1867	.168	.1867	.1753	.168
Avg	.2248	.2259	.2255	.2221	.2115	.2188	.2121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024055 / P.K.V. Washim Road, Sub

Statio

Feeder No / Name : 202 / 11 KV Kamala Nagar Feeder Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.8686	.905	.9431	.8686	.724	.6722
2	.8589	.8501	.8688	.8962	.8589	.724	.6722
3	.8215	.8402	.8688	.9335	.8402	.724	.6722
4	.8215	.8402	.8688	.9335	.8215	.7602	.6722
5	.8215	.8215	.8326	.9335	.8402	.7964	.6722
6	.8215	.8029	.8326	.9335	.8589	.7964	.7095
7	.8215	.8029	.8326	.9709	.8589	.7964	.7842
8	.8215	.8501	.8326	.8962	.8326		.7842
9	.8775	.8501	.8501	.8215	.7682	.7682	.8029
10	.8962	.8962	.8589				.7947
11	.9055	.8413	.8215				.7762
12	.9055		.7655				.8029
13	.8589	.8596	.7842			.6348	.7468
14	.6908	.7682	.7095			.6161	.5975
15	.7392	.695	.7468	.6838			.6161
16	.6838	.7421	.7468	.6722	1.1157	.5975	.5914
17	.7207	.7133	.7282	.7095	.9055	.6161	.5914
18	.7392	.7682	.7468	.7655	.823	.7282	.6653
19	.8962	.8596	.8775	.8589	.8779	.7842	
20	.9335	.8779	.9709	.9335	.8869	.8029	.8145
21	.9335	.9145	.8962	.8962	.8688	.7655	.7207
22		.9774	.9522	.9335	.8059	.7842	.7421
23	.924	.9511	1.0082	.9522	.7442	.7095	.7316
24	.9149	.8962	.9412	.9335	.8962	.724	.6722
Max	.9335	.9774	1.0082	.9709	1.1157	.8029	.8145
Min	.6838	.695	.7095	.6722	.7442	.5975	.5914
Avg	.8377	.8386	.8436	.8737	.8596	.7291	.7089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024055 / P.K.V. Washim Road, Sub

Statio

Feeder No / Name : 402 / 33 KV Incommmer No.2

SPARE FEEDER

Khadaki to Feeder KV- 33 /
INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.4563	1.4815	1.5123	1.4563	1.1946	1.0642
2	1.4003	1.4563	1.4266	1.5123	1.4563	1.1946	.8402
3	1.3443	1.4563	1.4266	1.5123	1.3443	1.1946	.8402
4		1.4003	1.4266	1.5278	1.3443	1.2489	.8402
5	1.3443	1.3443	1.3717	1.5123	1.4563	1.3575	.8402
6	1.3443	1.3443	1.3717	1.5123	1.4563	1.3575	.8402
7	1.3443	1.3443	1.3717	1.6244	1.4563	1.3575	.8402
8		1.5123	1.386	1.4003	1.4118	1.3032	.9522
9	1.4003	1.4563	1.4415	1.4003	1.386		1.4563
10	1.4563	1.4815	1.4563				1.3443
11	1.4563	1.4266	1.2883				1.2883
12	1.3443		1.1203		.5973		1.2883
13	1.4003	1.4266	1.2323			1.0082	1.2883
14	1.1763	1.3032	1.1763		.6099	1.0082	1.0642
15	1.2323	1.2489	1.1763	1.2883	.4938	.9522	1.0642
16	1.2323	1.3169	1.1203	1.1763	1.5912	1.1203	1.0534
17	1.2323		.8962	1.2323	1.3717	1.1203	1.0534
18	1.3443		1.2883	1.2883		1.2323	1.1523
19	1.5123	1.2894	1.5684	1.4003	1.3575	1.2323	1.4266
20	1.5684	1.4352	1.5684	1.5684	1.6289	1.2883	1.3717
21	1.5684	1.4883	1.5123	1.5123	1.4118	1.2323	1.2752
22	1.5684	1.701	1.5684	1.5684	1.3032	1.1763	1.3306
23	1.6244	1.5203	1.5684	1.6244	1.3169	1.1763	1.262
24	1.5123	1.5123	1.5203	1.5684	1.5123	1.0974	1.1203
Max	1.6244	1.701	1.5684	1.6244	1.6289	1.3575	1.4563
Min	1.1763	1.2489	.8962	1.1763	.4938	.9522	.8402
Avg	1.4029	1.4248	1.3652	1.4601	1.2981	1.1926	1.1207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 201 / 11 KV KHADKI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1491	2.3529	2.4253	2.2443	1.9591	1.8099	1.6651
2	2.1176	2.1616	2.2923	2.2081	1.9244	1.8656	1.6289
3	1.9879	2.0814	2.1948	2.1719	1.9071	1.922	1.5927
4	1.8204	1.8004	2.0995	2.1719	1.8604	1.9185	1.5927
5	1.8031	1.8347	2.0119	2.1357	1.7635	1.8823	1.6651
6	1.8551	1.9591	1.9366	2.1719	1.9105	1.8461	1.8099
7	1.7556	2.009	2.1357	2.0271	1.7353	1.8823	1.8461
8	1.6651	1.8755	1.8823	1.8823	1.7372	1.9185	1.7737
9		1.9366	1.8642		1.7375	1.7013	1.7013
10		1.6651	1.6126		1.6289	1.6108	1.6095
11	1.6289	1.7375	1.6301				1.3213
12	1.6289	1.6651	1.5415	1.448	1.4118	1.2136	
13	1.6651	1.7375	1.5402	1.5203	1.4842	1.286	
14		1.8099	1.6118		1.5203	1.3112	1.2851
15	2.0271	1.8823	1.6478		1.5203		1.267
16	1.8099	1.9185	1.6124	1.647	1.5203	1.3112	1.3032
17	1.828		1.6651	1.6655	1.4842	1.3032	1.3394
18	1.7924		1.6651		1.6832	1.448	1.2986
19	1.8823	1.9547	2.0633	1.6655	1.7741	1.7375	1.1641
20	2.2805	2.3348		1.7541	1.9547	1.8823	2.0271
21	2.3891	2.4874		2.1971	2.009	1.9185	2.0271
22	2.4451	2.6606	2.5339	2.3034	2.0633	1.448	1.9547
23	2.4274	2.6425	2.6063	2.2436	1.9728	1.8099	1.9366
24	2.2443	2.3312	2.4977	2.3529	2.0978	1.7737	1.6651
Max	2.4451	2.6606	2.6063	2.3529	2.0978	1.922	2.0271
Min	1.6289	1.6651	1.5402	1.448	1.4118	1.2136	1.1641
Avg	1.9620	2.0381	1.9577	1.9895	1.7678	1.6727	1.6125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 202 / 11 KV MALKAPUR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1734	.1753	.1829	.2402	.2103	.1867	.168
2	.1753	.156	.1448	.2218	.1886	.1829	.1494
3	.1772	.1595	.128	.2218	.1907	.1848	.1494
4	.181	.1715	.112	.2218	.2103	.1867	.1494
5	.1907	.1715	.1097	.2218	.2279	.168	.1663
6	.1886	.1886	.1097	.2427	.2303	.1867	.1867
7	.181	.1886	.112	.2241	.2103	.1848	.1829
8	.1753	.1907	.1829	.1829	.1928	.1829	.1829
9		.181	.1991		.1578	.1829	.1612
10	.1629	.181	.1387		.156	.1417	.1578
11	.1791	.1791	.1387				.1595
12	.1928	.1753	.1578	.1543	.1387	.1433	
13	.1886	.1791	.1417	.1578	.1372	.1227	
14	.181	.1829	.1448		.1448	.1214	.1227
15	.1791	.1463	.1543		.1578		.1254
16	.1949	.1791	.1417	.1848	.1677	.1214	.1254
17	.1753	.181	.1463	.1578	.1578	.124	.1402
18	.1543	.1612	.1612		.1402	.1372	.1772
19	.156	.1772	.1612	.1772	.1433	.1629	.1753
20	.1829	.2195		.2103	.1753	.1867	.1753
21	.2054	.2172		.2303	.197	.1867	.1907
22	.2103	.2353	.2378	.2279	.1791	.1867	.1949
23	.2103	.2378	.2402	.2279	.1753	.1867	.1772
24	.1791	.1928	.2587	.2402	.2254	.1848	.168
Max	.2103	.2378	.2587	.2427	.2303	.1867	.1949
Min	.1543	.1463	.1097	.1543	.1372	.1214	.1227
Avg	.1824	.1845	.1593	.2081	.1789	.1660	.1630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 241 / 11 KV INCOMER NO-I

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.4691			1.701
2	2.0858	2.1559		2.4143	2.0058		1.6644
3				2.3529			1.6278
4	1.8755	1.989		2.3529	1.8781		1.6278
5				2.3529			1.701
6	1.9313	1.95		2.4508	1.9071		1.8665
7				2.4434			1.9035
8	1.7372	1.8313	2.3211	2.3034	1.6991	2.009	1.7918
9		1.9342	2.3819		1.9845	1.7909	1.7013
10		1.9313	1.5947		1.8054	1.5432	1.6301
11	1.9982	2.1262	1.5947				1.3672
12	1.9982	2.0683			1.4022		
13	2.0553	2.1735			1.5775	1.2887	
14	.3185	2.2786	1.701		1.6126	1.286	
15	2.3487	2.3565	1.7878		1.4175		
16	2.0683	2.3565	1.7541	1.6476	1.5061	1.3289	1.4022
17	2.1209		1.7551	1.6301	1.4548	1.2934	1.3904
18	1.7353		1.6827			1.4175	1.2483
19	1.8404	1.9521		1.6124		1.7556	1.1443
20						1.9204	1.9806
21				2.1498		1.957	1.9806
22	2.4099		2.6337			1.4969	
23			2.7069			1.8473	
24	2.2325	2.4253	2.6703	2.5789	2.0687	1.8656	1.701
Max	2.4099	2.4253	2.7069	2.5789	2.0687	2.009	1.9806
Min	.3185	1.8313	1.5947	1.6124	1.4022	1.286	1.1443
Avg	1.9171	2.1092	2.0487	2.2122	1.7169	1.6286	1.6350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 242 / 11 KV INCOMER NO-II

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9116			.9036
2	.8859	.8309		.8785	.8589		.8682
3				.9189			.8139
4	.8859	.8309		.9015	.8842		.823
5				.929			.8589
6	.9774	.8939		.8592	.9774		.8745
7				.8642			.9036
8	.9593	.8939	.9242	.9391	.9391	.9465	.9412
9	1.0136	.8775	.9619		1.0456	.9134	.9431
10		1.0456	.9189		1.0751	.929	.9709
11	.9593	1.0751	.9088				.961
12	.9492	.9795			.9328		
13	.9774	1.0082			1.0374	.8669	
14	1.086	.9134	.9795		1.0829	.8583	
15	1.0349	.985	.9922		1.0642		
16	1.0829	.9945	.9189	1.0562	1.1128	.8939	1.0164
17	1.0456		1.0185	.9945	1.0751	.9709	.964
18	.9412		.7455			.961	.9189
19	.8478	.9328		.9114		.905	.8495
20						.8939	.8669
21				.9189		.9492	.8669
22	.8987		.8688			.9036	
23			.9431			.8764	
24	.9214	.8669	.7209	.9116	.8842	.8939	.9036
Max	1.086	1.0751	1.0185	1.0562	1.1128	.9709	1.0164
Min	.8478	.8309	.7209	.8592	.8589	.8583	.8139
Avg	.9667	.9377	.9084	.9227	.9977	.9116	.9027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 401 / 33KV I/C Khadki feeder

SPARE FEEDER

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			7.8464	7.8727		6.4415	5.4893
2	6.3255	6.31	7.6269	7.7618	6.877	6.2552	5.2652
3			7.276	7.54		6.3295	5.1532
4	5.8253	5.9419	7.4623	7.54	7.0696	6.2649	5.1532
5			7.5172	7.7618		6.0357	5.2652
6	5.9814	6.2574	7.656	8.0944	7.4897	6.1054	5.5967
7			8.3402	8.2853		6.0494	5.6573
8	5.5281	6.9633	8.3276	7.3303	7.572	5.7133	5.655
9	6.733	7.0045	8.1664		7.4389	5.5967	5.5967
10		8.0361	6.9696		6.6787	4.8891	6.0814
11	7.656	8.2533	6.6575				5.2584
12	7.4932	8.2202		6.3935	5.0503		
13	7.3605	8.5963	6.5547	5.6344	4.561	4.6811	
14	4.513	8.65			5.4264	5.0503	5.2115
15	7.7103	8.8112	7.1994		4.2798		5.3755
16	7.0588	9.1873	7.2217	5.8562	6.0814	5.048	4.9897
17	7.0382	9.249	6.7158	5.7213	5.4801	5.3755	5.679
18	5.3755	6.3935	5.1578		5.4264	5.3778	5.3109
19	6.0431	6.0174		5.4613	5.6344	4.7051	5.0497
20	7.0016	6.5547			6.1786	6.1677	5.9294
21	7.0965	7.0233	5.3772	6.4849	6.1786	6.2809	5.8128
22	6.5621	7.0588	7.2428	6.7095	6.1786	5.6584	
23		7.2257	7.0576		5.9637	5.7716	
24	6.733	6.5535	7.9281	8.0944	6.5621	6.3855	5.6573
Max	7.7103	9.249	8.3402	8.2853	7.572	6.4415	6.0814
Min	4.513	5.9419	5.1578	5.4613	4.2798	4.6811	4.9897
Avg	6.5575	7.4154	7.2151	7.0339	6.1120	5.7230	5.4594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 402 / 33 KV DABAKI-NIMBI O/G

DIVISION FEEDER

FEEDER Feeder KV- 33 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			4.3896	4.8171		3.5117	3.0247
2	3.3488	3.3488	4.2353	4.7051	3.9866	3.4374	2.9127
3			4.1701	4.4525		3.3265	2.7721
4	3.1893	3.1539	4.3896	4.4525	4.3056	3.3608	2.7721
5			4.4525	4.6153		3.2487	2.8829
6	3.1727	3.2556	4.6742	4.8834	4.7308	3.1927	3.0247
7			4.8377	5.104		3.1927	2.9384
8	2.8704	3.9678	5.0497	4.2444	5.0503	2.8829	2.8532
9	3.9758	4.137	4.9931		4.3519	2.8532	3.1024
10		4.9966	4.3724		3.7609	2.4446	3.4019
11	4.7279	5.0503	4.1152				3.0298
12	4.6245	5.2092		3.8912	2.7343		
13	4.6571	5.3635		3.0498	2.6526	2.4691	
14	3.1727	5.4687	4.4445		2.7343	2.7343	2.9321
15	4.2981	5.6344	4.265		1.7741		3.0727
16	3.8683	5.9419	4.4593	3.2236	3.5082	2.8395	2.4949
17	3.8272	5.9294	3.9963	3.155	2.8921	3.083	3.3665
18	2.6886	3.5997	2.7692		2.7938	2.5503	3.1893
19	3.1602	3.3048		2.9973	2.9767	1.9044	3.0298
20	3.7146	3.6408			3.2076	3.3608	3.155
21	3.6763	3.7311		3.3488	3.2236	3.3048	3.035
22	3.3808	3.6969	3.7529	3.6145	3.1893	3.3048	
23		3.6214	3.6969		3.0498	3.1367	
24	3.4551	3.4922	4.4993	4.9291	3.7449	3.4928	3.1367
Max	4.7279	5.9419	5.0497	5.104	5.0503	3.5117	3.4019
Min	2.6886	3.1539	2.7692	2.9973	1.7741	1.9044	2.4949
Avg	3.6560	4.3272	4.2928	4.0927	3.4035	3.0301	3.0063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

SPARE FEEDER

Feeder KV- 33 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.4177			1.6832
2	2.0285	2.1794		2.364	1.9033		1.6289
3				2.3102			1.6289
4	1.8204	1.8804			1.8404		1.6289
5				2.3102			1.6832
6	1.9136	2.0199		2.4434	1.8519		1.8656
7				2.4177			1.8461
8	1.6827	1.8519	2.3137	2.2365	1.701	1.9667	1.7918
9	1.6827	1.9136	2.364		1.9456		
10		1.893	1.6655		1.7684	1.5249	
11	1.9765	2.1033	1.6124				
12	1.9547	2.0285			1.3889		
13	2.0062	2.1325	1.5604		1.5261	1.3146	
14	.3841	2.2365	1.701		1.6124	1.3003	
15	2.3405	2.3137	1.7878		1.5278		
16	2.0062	2.3137	1.7164		1.4723	1.3003	
17			1.7541	1.6301	1.4403	1.262	
18			1.6461			1.4043	
19	1.8404	1.9136		1.6478		1.701	1.1946
20						1.9004	
21			2.364			1.9547	1.9456
22	2.3926		2.6063	2.2857		1.4661	
23			2.6606			1.8461	
24	2.2565	2.4434	2.6606	2.5252	2.1325	1.8267	1.6832
Max	2.3926	2.4434	2.6606	2.5252	2.1325	1.9667	1.9456
Min	.3841	1.8519	1.5604	1.6301	1.3889	1.262	1.1946
Avg	1.8775	2.0874	2.0295	2.2353	1.7008	1.5975	1.6891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO-II
Feeder KV- 33 / INCOMING

SPARE FEEDER

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9259			.9328
2	.8505	.8048		.9259	.8413		.8779
3				.8539			.8505
4	.8505	.8322					.8505
5				.8539			.8505
6	.9036	.9362		.8951	.9465		.8939
7				.9054			.9231
8	.9036	.8842	.9054	.9671	.8939	.9671	.9425
9	1.0425	.9054			1.0751		
10		1.0751	.9568		1.0751	1.5604	
11	.9877	1.0751	2.7566				
12	.9979	1.0082			.9522		
13	1.0534	1.0185	.9425		1.0082	.8842	
14	1.0974	.9328	.9231		1.0642	.9362	
15	1.0534	.9774	.9362		1.0642		
16	1.0751	1.0174	.9465		1.1317	.8842	
17			1.0185	1.0099	1.0751	.9619	
18			.7973			.9522	
19	.8939	.9522		.9036		.9425	.8596
20						.9134	
21			.9774			.9877	.8939
22	.8842		.9231	.9036		.9328	
23			.9465			.9231	
24	.8842	.9134	.7716	.9156	.8842	.9036	.9328
Max	1.0974	1.0751	2.7566	1.0099	1.1317	1.5604	.9425
Min	.8505	.8048	.7716	.8539	.8413	.8842	.8505
Avg	.9627	.9524	1.0617	.9145	1.0010	.9807	.8916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 204 / TRANSPORT NAGAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9						.1905	
10	.0381						
11	.0381	.0191					.0381
12	.0381	.0381		.0191		.0191	
13		.0191	.0191	.0191		.0191	
14	.0381	.0191		.0381	.0191	.0191	.0191
15	.0381	.0191	.0191		.0381		.0381
16	.0572	.0381	.0191	.0381	.0381	.0191	
17	.0381	.0381	.0191	.0381	.0572	.0381	
18	.0191	.0191			.0381	.0191	.0191
19	.0191	.0381	.0191	.0381	.0381	.0191	.0191
20	.0191	.0191	.0191	.0381			.0191
21	.0191	.0191		.0381			.0191
Max	.0572	.0381	.0191	.0381	.0572	.1905	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0329	.0260	.0191	.0334	.0381	.0429	.0245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 205 / 11KV NARAYAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048	.3429	.3239	.362	.362	.3429
2	.3429	.3048	.3429	.3239	.3429	.3429	.3429
3	.3429	.3048	.3429	.3048	.3429	.3429	.3429
4	.3429	.3048	.3429	.3239	.3429	.3429	.3429
5	.3429	.3048	.3429	.3239	.3429	.3429	.3429
6	.3429	.3048	.3429	.3239	.3429	.3429	.3239
7	.3239	.3239	.3429	.3429	.3429	.3429	.3429
8	.3429	.3239	.3429	.3239	.3429	.3429	.362
9	.4191	.4191	.3429	.381	.4001	.4382	.4763
10	.5906	.5906	.3239		.7049	.6859	.7049
11	.724	.6859	.3239		.6668		.8002
12	.8383	.7049	.3048	.0762	.6668	.724	
13	.5716	.5525	.3429	.5144	.4954	.5525	
14	.7049	.6287	.3239	.6478	.6668	.6478	.5906
15	.7621	.7621	.3239		.724		.8383
16	.8002	.6668	.3239	.7049	.8192	.6859	
17	.8954	.743	.3239	.8192	.7049	.724	
18	.7811	.6668	.3429		.6859	.6097	.6478
19	.5716	.5525	.3429	.5906	.6478	.6097	.6287
20	.4191	.4763	.3429	.4572	.4572	.4191	.4191
21	.362	.362	.3239	.362	.362	.362	.362
22	.3239	.3429		.381	.381	.3429	.381
23	.3239	.3429	.3239	.362	.381	.3429	.381
24	.3239	.3239	.3429	.3239	.362	.381	.3429
Max	.8954	.7621	.3429	.8192	.8192	.724	.8383
Min	.3239	.3048	.3048	.0762	.3429	.3429	.3239
Avg	.5057	.4707	.3346	.4106	.4953	.4676	.4658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 206 / 11 KV B.K. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2477	.1905	.1524	.2667	.2286	.2477
2	.2096	.2286	.1905	.1524	.2667	.2286	.2477
3	.2096	.2286	.1905	.1334	.2667	.2286	.2477
4	.2096	.2286	.1905	.1524	.2667	.2286	.2286
5	.2096	.2286	.1905	.1524	.2667	.2286	.2286
6	.2096	.1905	.1905	.1715	.2667	.2286	.2667
7	.2667	.2286	.1905	.1715	.2286	.2667	.2858
8	.2667	.2286	.1905	.1905	.2096	.2477	.2858
9	.3429	.362	.2096	.2667	.2667	.3239	.3239
10	.5716	.5906	.1715	.5716	.3429	.4191	.4954
11	.5716	.6478	.1905		.4191		.5144
12	.6097	.6097	.1905	.6097	.4382	.5716	
13	.5335	.4954	.1905	.4954	.362	.4954	
14	.5335	.5716	.1905	.4763	.3239	.4763	.4954
15	.5906	.6097	.1905		.381		.5335
16	.5906	.5525	.1905	.6668	.3429	.5525	
17	.4763	.5716	.1905	.5716	.3239	.5525	
18	.4763	.5906	.1715		.381	.5906	.4763
19	.4382	.5525	.1715	.4763	.3429	.4954	.5716
20	.4001	.4382	.1905	.4191	.3048	.4382	.4763
21	.1905	.2477	.1715	.3239	.2477	.2858	.3048
22	.2096	.2286		.2667	.2286	.2667	.2858
23	.2477	.2286	.1524	.3048	.2477	.2477	.2667
24	.2286	.2286	.2096	.1524	.2667	.2286	.2477
Max	.6097	.6478	.2096	.6668	.4382	.5906	.5716
Min	.1905	.1905	.1524	.1334	.2096	.2286	.2286
Avg	.3668	.3890	.1872	.3275	.3024	.3559	.3515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 207 / 11KV DADAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3048	.3429	.2096	.2858	.3429	.3048
2	.3239	.3048	.3048	.2096	.2858	.3429	.3048
3	.3239	.3048	.3048	.1905	.2667	.3429	.3048
4	.3239	.3048	.3048	.2096	.2667	.3429	.3048
5	.3239	.3048	.3048	.2096	.2667	.3429	.3239
6	.3239	.3048	.3048	.2096	.2667	.3429	.3048
7	.3239	.3048	.3048	.2096	.2858	.3429	.3048
8	.3048	.2858	.2477	.2096	.2858	.3239	.3048
9	.5144	.5525	.2286	.5144	.7049	.6478	.6287
10	.724	.8192	.2286		.9526	.724	
11	.9907	1.0669	.2286		1.105		.8383
12	.9145	1.0669	.2286	1.1431	1.2384	1.1431	
13	1.0288	.9526	.2286	.9907	1.0098	1.1431	
14	1.2193	.8764	.2286	.9335	1.105	.8954	.8954
15	1.2384	1.1431	.2286		1.086		.8573
16	1.3146	1.1622	.2286	.8954	1.2384	1.1431	.8954
17	1.2574	1.105	.2286	.9526	.9526	1.1241	
18	1.2003	.8002	.1905		.6859	1.0288	.9145
19	.9907	.7811	.2096	.8573	.6859	.6287	.724
20	.4001	.4382	.2096	.5906	.4382	.381	.4572
21	.362	.4001	.2096	.3239	.362	.3429	.381
22	.3429	.4001		.3239	.381	.362	.362
23	.3048	.362	.2096	.2858	.381	.3239	.3429
24	.3429	.3048	.362	.2096	.2858	.362	.3048
Max	1.3146	1.1622	.362	1.1431	1.2384	1.1431	.9145
Min	.3048	.2858	.1905	.1905	.2667	.3239	.3048
Avg	.6549	.6104	.2551	.4839	.6176	.5897	.5030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 208 / 11KV YEVATA ROAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.1715	.0953	.2096	.2286	.2477
2	.1715	.1905	.1715	.0953	.1905	.1905	.2477
3	.1715	.1905	.1715	.0953	.1524	.1715	.2477
4	.1715	.1905	.1715	.0762	.1524	.1715	.2477
5	.1715	.1905	.1715	.0762	.1334	.1715	.2477
6	.1715	.1905	.1715	.1334	.1334	.1715	.3048
7	.2286	.2096	.1524	.1334	.1524	.2286	.2858
8	.2096	.1715	.1715	.1143	.1905	.1905	.2477
9	.2096	.1715	.1334	.1143	.1905	.1905	.2477
10	.4191	.2858	.0953	.2477	.3048	.3048	.5525
11	.4382	.381	.0762		.381		.6287
12	.4572	.4191	.0953	.4001	.4763	.5144	
13	.4191	.381	.0762	.3429	.4382	.4954	
14	.3048	.2858	.0953	.2858	.4572	.381	.4191
15	.3429	.3239	.0953		.4191		.381
16	.381	.3048	.0762	.5525	.4191	.5144	.381
17	.4001	.3048	.0953	.5716	.4382	.4763	
18	.362	.3239	.0381		.362	.4763	.4763
19	.4572	.2477	.0953	.4954	.362	.4382	.5144
20	.381	.2477	.1524	.4954	.3048	.381	.4954
21	.2286	.2096	.1524	.362	.2858	.3429	.3429
22	.1715	.1715		.2096	.1715	.1905	.2096
23	.1905	.2477	.1143	.2096	.1905	.2096	.2286
24	.1905	.1905	.2096	.1524	.2477	.2667	.2477
Max	.4572	.4191	.2096	.5716	.4763	.5144	.6287
Min	.1715	.1715	.0381	.0762	.1334	.1715	.2096
Avg	.2850	.2516	.1284	.2504	.2818	.3048	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 241 / 11 KV INCOMER NO-I

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048	.3429	.3239	.362	.362	
2	.3429	.3048	.3429	.3239	.3429	.3429	
3	.3429	.3048	.3429	.3048	.3429	.3429	
4	.3429	.3048	.3429	.3239	.3429	.3429	
5	.3429	.3048	.3429	.3239	.3429	.3429	
6	.3429	.3048	.3429	.3239	.3429	.3429	
7	.3239	.3239	.3429	.3429	.3429	.3429	
8	.3429	.3239	.3429	.3239	.3429	.3429	.362
9	.4191	.4191	.3429	.381	.4001	.4382	.4763
10	.6287	.5906	.3239	1.5623	.7049	.6859	.7049
11	.7621	.7049	.3239		.6668		.8383
12	.8764	.743	.3048	.7811	.6668	.743	
13	.5716	.5716	.362	.5335	.4954	.5716	
14	.743	.6478	.3239	.6859	.6859	.6668	.6097
15	.8002	.7811	.3429		.7621		.8764
16	.8573	.7049	.3429	.743	.8573	.7049	.8383
17	.9335	.7811	.3429	.8573	.7621	.7621	
18	.8002	.6859	.3429		.724	.6287	.6668
19	.5906	.5906	.362	.6287	.6859	.6287	.6478
20	.4382	.4954	.362	.4954		.4191	.4382
21	.381	.381	.3239	.4001	.362	.362	.381
22	.3239	.3429		.381		.3429	.381
23	.3239	.3429	.3239	.362	.381	.3429	.381
24	.3239	.3239	.3429	.3239	.362	.381	.3429
Max	.9335	.7811	.362	1.5623	.8573	.7621	.8764
Min	.3239	.3048	.3048	.3048	.3429	.3429	.3429
Avg	.5207	.4826	.3396	.5108	.5127	.4746	.5675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 242 / 11 KV INCOMER NO-II

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7621	.7049	.4572	.7621	.8002	
2	.7049	.724	.6668	.4572	.743	.7621	
3	.7049	.724	.6668	.4191	.6859	.743	
4	.7049	.724	.6668	.4572	.6859	.743	
5	.7049	.724	.6668	.4382	.6668	.743	
6	.7049	.6859	.6668	.5144	.6668	.743	
7	.8192	.743	.6478	.5144	.6668	.8383	.8002
8	.7811	.6859	.6097	.5144	.6859	.7621	.8383
9	1.0669	1.086	.5716	.8954	1.1622	1.1622	1.2003
10	1.7147	1.6956	.4954		1.6004	1.448	1.8099
11	2.0005	2.0957	.4954		1.9052		1.9814
12	1.9814	2.0957	.5144	.724	2.1529	2.2291	
13	1.9814	1.829	.4954	1.829	1.8099	2.1338	
14	2.0576	1.7337	.5144	1.6956	1.8861	1.7528	1.8099
15	2.1719	2.0767	.5144		1.8861		1.7718
16		2.0195	.4954	2.1148	2.0005	2.21	2.0195
17	2.1338	1.9814	.5144	2.0957	1.7147	2.1529	
18	2.0386	1.7147	.381		1.6385	2.0957	1.8671
19	1.8861	1.5813	.4572	1.829	1.3908	1.5623	
20	1.1812	1.1241	.5525	1.5051	1.0479	1.2003	1.4289
21	.7811	.8573	.5335	1.0098	.8954	.9717	1.0288
22	.724	.8002		.8002		.8192	.8573
23	.743	.8383	.4763	.8002	.8002	.7811	.8383
24	.7621	.724	.7811	.5144	.8002	.8573	.8002
Max	2.1719	2.0957	.7811	2.1148	2.1529	2.2291	2.0195
Min	.7049	.6859	.381	.4191	.6668	.743	.8002
Avg	1.2640	1.2511	.5691	.9793	1.2284	1.2505	1.3609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 401 / 33 KV INCOMER NO-I

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER MIDC EQUIVALENT

HAVING WEEKLY STAGGERING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.086	1.0288	.8002	1.1431	1.1431	1.1431
2	1.0288	1.0288	1.0288	.8002	1.086	1.086	1.1431
3	1.0288	1.0288	1.0288	.743	.1715	1.086	1.1431
4	1.0288	1.0288	1.0288	.8002	1.0288	1.086	1.1431
5	1.0288	1.0288	1.0288	.743	1.0288	1.086	1.1431
6	1.0288	.9717	1.0288	.8573	1.0288	1.086	1.2003
7	1.1431	1.086	.9717	.8573	1.0288	1.2003	1.2003
8	1.1431	1.0288	.8573	.8573	1.0288	1.0288	1.2003
9	1.4861	1.4861	.9145	1.2574	1.5432	1.6004	1.6575
10	2.4006	2.2862	.8002	2.2862		2.1148	2.5149
11	1.0288	2.8006	.8002				2.8006
12	2.8578	2.8006	.8002	2.915	2.8006	2.9721	
13	2.572	2.4006	.8573	2.3434	2.2862	2.6863	2.8578
14	2.8006	2.4006	.8573	2.4006	2.572	2.4006	2.4006
15	2.9721	2.8578	.8573		2.6292		2.6292
16	3.1436	2.8578	.8573	2.8578	2.8578	2.915	2.8578
17	3.0864	2.7435	.8573	2.9721	2.4577	2.915	
18	2.8578	2.4006	.743	2.8006	2.3434	2.7435	2.5149
19	2.4577	2.1719	.8002	2.4577	2.1148	2.1719	2.4577
20	1.6004	1.6004	.9145	2.0005	1.5432	1.6004	1.8861
21	1.1431	1.2574	.8573	1.4289	1.2574	1.3146	1.4289
22	1.0288	1.1431		1.2003	1.1431	1.1431	1.2574
23	1.086	1.2003	.8002	1.1431	1.2003	1.086	
24	1.086	1.0288	1.1431	.8573	1.1431	1.2574	1.1431
Max	3.1436	2.8578	1.1431	2.9721	2.8578	2.9721	2.8578
Min	1.0288	.9717	.743	.743	.1715	1.0288	1.1431
Avg	1.7552	1.7385	.9070	1.6082	1.6108	1.7147	1.7963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 402 / 33 KV INCOMER NO-II

SPARE FEEDER

Feeder KV- 33 / INCOMING

DATE	08-JUL-17
HR	Load (MW)
16	6.8587
Max	6.8587
Min	6.8587
Avg	6.8587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

SPARE FEEDER

Feeder KV- 33 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2858	.3429	.3429	.3429	.3429	.3429
2	.3429	.2858	.3429	.3429	.3429	.3429	.3429
3	.3429	.2858	.3429	.2858	.3429	.3429	.3429
4	.3429	.2858	.3429	.3429	.3429	.3429	.3429
5	.3429	.2858	.3429	.3429	.3429	.3429	.3429
6	.3429	.2858	.3429	.3429	.3429	.3429	.3429
7	.3429	.3429	.3429	.3429	.3429	.3429	.3429
8	.3429	.3429	.3429	.3429	.3429	.3429	.3429
9	.4001	.4001	.3429	.4001	.4001	.4572	.4572
10	.6287	.5716	.3429			.6859	.743
11	.743	.6859	.3429				.8573
12	.8573	.743	.2858	.0572	.5144	.743	
13	.5716	.5716	.3429	.5144		.5716	
14	.743	.6287	.3429	.6859	.6859	.6859	.6287
15	.8002	.8002	.3429		.743		.8573
16	.8573	.6859	.3429	.743	.8573	.6859	.8573
17	.9145	.8002	.3429	.8573	.743	.743	
18	.8002	.6859	.3429	.743	2.2291	.6287	.6859
19	.5716	.5716	.3429	.6287	.6859	.6287	.6287
20	.4572	.5144	.3429	.5144	.5144	.4001	.4572
21	.4001	.4001	.3429	.4001	.3429	.3429	.4001
22	.3429	.3429				.3429	.4001
23	.3429	.3429	.3429	.3429	.4001		
24	.3429	.3429	.3429	.3429	.3429	.4001	.3429
Max	.9145	.8002	.3429	.8573	2.2291	.743	.8573
Min	.3429	.2858	.2858	.0572	.3429	.3429	.3429
Avg	.5215	.4787	.3404	.4458	.5601	.4790	.5029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO- SPARE FEEDER
II Feeder KV- 33 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.743	.6859	.4572	.743	.8002	.8002
2	.6859	.743	.6859	.4572	.743	.743	.8002
3	.6859	.743	.6859	.4572	.6859	.743	.8002
4	.6859	.743	.6859	.4572	.6859	.743	.8002
5	.6859	.743	.6859	.4572	.6859	.743	.8002
6	.6859	.6859	.6859	.5144	.6859	.743	.8573
7	.8002	.743	.6287	.5144	.6859	.8573	.8573
8	.8002	.6859	.5716	.5144	.6859	.743	.8573
9	1.086	1.086	.5716	.9145	1.1431	1.1431	1.2003
10	1.6575	1.7147	.5144	1.4289	1.6004	1.4289	1.829
11	.743	2.1148	.5144		1.8861		2.0005
12	2.0005	2.1148	.5144	2.1719	2.1719	2.2291	
13	2.0005	1.829	.5144	1.829	1.829	1.6575	
14	2.0576	1.7147	.5144	1.7147	1.8861	1.7718	
15	2.1719	2.0576	.5144		1.8861		
16	2.2862	2.0576	.5144	2.1148	2.0005	2.2291	2.0005
17	2.1148	2.0005	.5144	6.2872	1.7147	2.1719	
18	2.0576	1.7147	.4001		1.6575	2.1148	1.8861
19	1.8861	1.6004	.4572	1.829	1.3146		1.829
20	1.5432	1.1431	.5716	1.4861	1.0288	1.2003	1.4289
21	.8002	.8573	.5144	1.0288	.9145	.9717	1.0288
22	.743	.8002				.8002	.8573
23	.743	.8573	.4572	.8002	.8002	.8002	.8573
24	.743	.3429	.8002	.5144	.8002	.8573	.8002
Max	2.2862	2.1148	.8002	6.2872	2.1719	2.2291	2.0005
Min	.6859	.3429	.4001	.4572	.6859	.743	.8002
Avg	1.2670	1.2431	.5741	1.2974	1.2276	1.2139	1.1732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 201 / 11KV TUKARAM Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2986	1.2986	1.4083	1.3535	1.3169	1.1888	.8779
2	1.1888	1.2254	1.3169	1.3352	1.2254	1.0791	.823
3	1.1523	1.1706	1.2437	1.2437	1.2071	1.0059	.823
4	1.0974	1.1157	1.2071	1.1888	1.1523	.9328	.823
5	1.0608	1.0608	1.1523	1.1157	1.134	.9145	.7973
6	1.0425	1.0059	1.0791	1.1157	1.134	.9328	.8962
7	.9511	1.0242	1.0608	1.0608	1.1706	.9694	.9694
8	.9511	1.0059	.9694	1.0242	1.0791	.9511	.9145
9	.9877	.9877	1.0425	.9511	.9877	1.0059	.9877
10	.8962	.9511	.9145			.8413	
11	.8779	.924	.8962				.823
12		.9145	.8596	.8596	.823		.7499
13	.9511	.9145		.8596	.8413	.6767	
14	.9511	1.0059		.9328	.8596	.7316	.7316
15	1.0242	1.0425	1.0059		.8596	.7316	.7499
16	.9877	1.0791	.9877	.9877	.8413	.7499	.7499
17	.9694	1.0059	.9328	.9425	.8596	.7316	
18	.9145	.9877	.9511	.9511	.9145	.823	.7682
19	1.0608	1.1157	1.0791	1.0242	1.0425	1.0059	1.0242
20	1.2803	1.3169	1.2986	1.2986	1.2071	1.0974	1.1706
21	1.3169	1.4266	1.3717	1.3535	1.1888	1.0608	1.134
22	1.4083	1.5181	1.5181	1.4632	1.1706	1.0242	1.1157
23	1.5181	1.6278	1.5912	1.4998	.3292	1.0242	1.0425
24	1.3717	1.4083	1.5364	1.4632	1.4083	.2743	.8962
Max	1.5181	1.6278	1.5912	1.4998	1.4083	1.1888	1.1706
Min	.8779	.9145	.8596	.8596	.3292	.2743	.7316
Avg	1.0982	1.1306	1.1556	1.1440	1.0342	.8979	.8985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 202 / 11KV KOTHARI WATIKA Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	.7207	.8131	.7762	.7207	.5729	.5175
2	.7023	.6838	.7762	.7392	.7207	.5729	.5175
3	.6838	.6468	.7207	.7392	.6838	.5544	.499
4	.6468	.6653	.6653	.7023	.6653	.5544	.4805
5	.6468	.6283	.6468	.6653	.6653	.5544	.499
6	.6219	.6283	.7023	.7023	.6653	.5729	.5544
7	.6036	.6283	.6838	.6468	.7023	.6468	.5544
8	.5729	.6653	.5544	.5729	.6283	.5544	.5175
9	.6283	.6283	.6099	.5729	.6099	.6099	.5544
10	.5914	.6099	.5175			.4805	
11	.5175	.5914	.4805				.4805
12	.5544	.5544		.4435	.4435		.4251
13	.5544	.5544		.4805	.462	.3696	
14	.5359	.6099		.499	.462	.4066	.4251
15	.5729	.6099			.462	.3881	.4066
16	.5729	.6283	.5544	.5175	.4805	.4066	.4251
17	.5914	.6283	.5304	.5175	.462	.4251	
18	.5175	.5914	.5359	.5359	.499	.462	.4066
19	.5729	.6099	.6283	.6099	.6283	.5729	.5914
20	.7207	.7392	.7207	.7207	.7207	.6401	.6653
21	.7392	.8131	.7762	.7762	.7023	.6219	.6653
22	.8316	.8871	.9055	.8686	.7023	.6283	.6653
23	.8501	.9055	.8686	.8316	.6468	.5914	.6099
24		.7577	.8501	.8131	.7762	.6099	.5544
Max	.8501	.9055	.9055	.8686	.7762	.6468	.6653
Min	.5175	.5544	.4805	.4435	.4435	.3696	.4066
Avg	.6318	.6661	.6770	.6539	.6141	.5362	.5245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 203 / 11KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1431	1.1241	1.3527	1.3336	1.3336
2		1.1431	1.1622	1.3336	1.2955	1.2765
3		1.1431	1.1241	1.3527	1.2193	1.2574
4		1.105	1.1431	1.2765	1.3336	1.3146
5		1.0669	1.1431	1.2955	1.2574	1.2574
6		1.1812	1.1241	1.3146	1.2765	1.2384
7		1.1812	1.1241	1.0669	1.2955	1.2955
8		1.105	1.1812	1.0669	1.3146	1.3146
9		.8573	1.6194	1.0669	1.8099	1.7337
10		.8383			2.3053	
11						2.3815
12			2.21	2.1338		2.4006
13	2.1338		2.1719	1.848	1.8861	
14	2.1338		2.2672	1.9814	1.9814	2.3053
15	2.3053	.9145		2.0005	2.1148	2.4387
16	2.2291		2.1148	2.0386	2.1338	2.4387
17	2.0957	.9145	2.2291	2.0005	2.1148	
18	1.5242	.8954	2.0195	1.7718	1.9624	1.9052
19	1.3527	.8954	1.6956	1.6385	1.6766	1.6956
20	1.2193	.8764	1.2955	1.1812	1.1812	1.3527
21	1.1431	.8764	1.1812	1.086	1.1622	1.1622
22	1.0479	.8764	1.1431	1.105	1.105	1.105
23	1.0479	.9335	1.1431	1.086	1.086	1.086
24		.9145	1.1241	1.3146	1.105	1.105
Max	2.3053	1.1812	2.2672	2.1338	2.3053	2.4387
Min	1.0479	.8383	1.1241	1.0669	1.086	1.086
Avg	1.6575	.9927	1.4924	1.4687	1.5432	1.5904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 204 / 11KV CHAITANYA Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1643	1.2254	1.2986	1.3169	1.2803	.9511	.7865
2	1.0903	1.0608	1.2071	1.1706	1.134	.9511	.8413
3	1.0903	1.1523	1.134	1.0974	1.0791	.823	.7865
4	.9795	.9328	1.0242	1.0059	1.0242	.823	.6767
5	.924	.9145	.9145	.9328	.9511	.7682	.695
6	.9055	.8413	.9145	.9145	.9145	.7865	.7682
7	.9055	.8779	.9145	.9145	1.0242	.8779	.8779
8	.9425	.8962	.8962	.8962	1.0242	.8596	.7865
9	.8686	.8779	.9328	.8779	.9694	.8413	.8779
10	.8871	.8779	.8962			.8779	
11	.8871	.9055					.7865
12		.7762		.7207	.7682		.7316
13		.8501		.0366	.7133	.6767	
14	1.2197	.924		1.0425	.8413	.6767	.7499
15	1.0903	.9425	.9328		.8316	.6767	.6767
16	1.0349	.924	.9328	.9511	.8131	.6767	.695
17	.9145	.8501	.8962	.8131	.7499	.6767	
18	.9145	.8871	.7865	.9511	.7865	.7682	.7133
19	.9694	.9877	.9328	.9694	.9694	.8962	.9328
20	1.1157	1.1888	1.2254	1.1888	1.0791	1.0059	1.0608
21	1.2254	1.2437	1.3169	.9511	1.1157	1.0608	1.0974
22	1.3535	1.4815	1.4632	1.4815	1.134	1.0242	1.0059
23	1.4083	1.4815	1.4632	1.3535	1.1523	.9694	.9328
24	1.2567	1.39	1.4632	1.39	1.3169	1.0242	.9328
Max	1.4083	1.4815	1.4632	1.4815	1.3169	1.0608	1.0974
Min	.8686	.7762	.7865	.0366	.7133	.6767	.6767
Avg	1.0522	1.0204	1.0773	.9989	.9851	.8496	.8291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 241 / 11 KV INCOMER NO-I

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1643	1.2254	1.2986	1.3169	1.2803	.9511	.7865
2	1.0903	1.0608	1.2071	1.1706	1.134	.9511	.8413
3	1.0903	1.1523	1.134	1.0974	1.0791	.823	.7865
4	.9795	.9328	1.0242	1.0059	1.0242	.8488	.6767
5	.924	.9145	.9145	.9328	.9511	.7682	.695
6	.9055	.8413	.9145	.9145	.9145	.7865	.7682
7	.9055	.8779	.9145	.9145	1.0242	.8779	.8779
8	.9425	.8962	.8962	.8962	1.0242	.8596	.7865
9	.8686	.8779	.9328	.8779	.9694	.8413	.8779
10	.8871	.8779	.8962			.8779	
11	.8871	.9055					.7865
12		.7762		.7207	.7682		.7316
13		.8501		.0366	.7133	.6767	
14	1.2197	.924		1.0425	.8413	.6767	.7499
15	1.0903	.9425	.8596		.8316		.6767
16	1.0349	.924	.9328	.961	.8131	.6767	.695
17	.9145	.8501	.8962	.8048	.7499	.6767	
18	.9145	.8871	.7865	.9511	.7865	.7682	.7133
19	.9694	.9877	.9328	.9694	.9694	.8962	.9328
20	1.1157	1.1888	1.2254	1.1888	1.0791	1.0059	1.0608
21	1.2254	1.2437	1.3169	1.2437	1.1157	1.0608	1.0974
22	1.3535	1.4815	1.4632	1.4815	1.134	1.0562	1.0059
23	1.4083	1.4815	1.4632	1.3535	1.1523	.9694	.9328
24	1.2567	1.39	1.4632	1.39	1.3169	1.0242	1.0608
Max	1.4083	1.4815	1.4632	1.4815	1.3169	1.0608	1.0974
Min	.8686	.7762	.7865	.0366	.7133	.6767	.6767
Avg	1.0522	1.0204	1.0736	1.0129	.9851	.8606	.8352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 242 / 11 KV INCOMER NO-II

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0559	2.0538	3.3794	3.3008	3.4328	3.131	2.7538
2	1.9427	1.9418	3.2487	3.2487	3.3196	2.9801	2.6406
3	1.8861	1.8484	3.1181	3.1181	3.2819	2.8387	2.6029
4	1.7918	1.8111	2.9874	3.0434	3.131	2.8769	2.6406
5	1.7541	1.7177	2.8753	2.9313	3.131	2.7816	2.6029
6	1.7164	1.6617	2.9687	2.95	3.1499	2.8387	2.7161
7	1.6032	1.6804	2.9313	2.838	2.9801	2.9721	2.8481
8	1.5655	1.6991	2.6326	2.782	2.8104	2.8769	2.7726
9	1.6598	1.643	2.5206	3.1367	2.6972	3.4517	3.3008
10	1.5432	1.587	2.2779			3.6403	
11	1.448	1.531	1.4003				3.6969
12	1.5242	1.4937	.8775	3.4915			3.5837
13	1.531	3.5848		3.4915	3.1687	2.9424	
14	1.5123	3.7342		3.6782	3.3196	3.131	3.4705
15	1.6244	3.9396	2.4646		3.2373		3.6025
16	1.587	3.9209	2.4646	3.6035	3.2739	3.3008	3.6214
17	1.6032	3.7534	2.3899	3.6595	3.3385	3.2819	
18	1.4563	3.131	2.3899	3.5271	3.2065	3.263	3.0933
19	1.6617	3.0807	2.6139	3.3573	3.3385	3.2819	3.3385
20	2.0351	3.2861	2.9127	3.3573	3.1499	2.9613	3.2253
21	2.0911	3.3981	3.0744	3.3573	3.0178	2.8858	2.999
22	2.2779	3.4728		3.7157	3.0178	2.7915	2.9235
23	2.4086	3.6035	3.4517	3.5271	2.0748	2.7349	2.7726
24	2.1879	2.2032	3.3234	3.4517	3.546	1.9993	2.584
Max	2.4086	3.9396	3.4517	3.7157	3.546	3.6403	3.6969
Min	1.448	1.4937	.8775	2.782	2.0748	1.9993	2.584
Avg	1.7695	2.5740	2.6811	3.3127	3.1249	2.9982	3.0376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 402 / 33 KV INCOMER (TUKARAM DIVISION FEEDER
SST) Feeder KV- 33 / INCOMING

DATE	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.7529	3.7346	3.1687	2.7161
2		3.5648	3.5648	3.0556	2.6029
3		3.3385	3.4517	2.7726	2.4331
4		3.1121	3.2253	2.7726	2.5463
5		2.999	3.2253	2.6595	2.6029
6		2.999	3.2253	2.8292	2.6595
7		2.8292	3.2819	2.9424	2.8292
8		2.7161	3.0556	2.7726	2.7161
9	2.5503	3.1687	3.5082	3.3951	3.2253
10	2.2262			3.8477	
11	1.4118				3.678
12	.8145		3.2922		3.5082
13		2.9127	3.0727	2.8858	
14		3.8409	3.2922	3.0556	3.3951
15	2.2805		3.3665	3.1687	3.5082
16	2.3594	3.7311	3.5082	3.2819	3.6214
17	2.2965	3.6214	3.3385	3.2819	
18	2.1285	3.678	3.2253	3.2819	3.1121
19	2.4646	3.7912	3.5648	3.3951	3.5082
20	3.2253	3.9609	3.3951	3.1687	3.5648
21	3.4728	3.8477	3.3951	3.2253	3.2253
22	3.8089	4.0175	3.3385	3.0556	3.0556
23	3.9769	4.0175	2.3765	2.8292	2.8858
24		3.7529	4.1307	2.2634	2.7161
Max	3.9769	4.0175	4.1307	3.8477	3.678
Min	.8145	2.7161	2.3765	2.2634	2.4331
Avg	2.5397	3.4826	3.3440	3.0504	3.0529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

SPARE FEEDER

Feeder KV- 33 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.2574	1.3717	1.3146	1.2574	.9717	.8573
2	1.0059	1.086	1.2574	1.2003	1.1431	.9717	.8002
3	.9556	1.1431	1.2003	1.086	1.086	.9145	.743
4	.9054		1.0288	.9717	1.0288	.8002	.6859
5	.8048	.9145	.9717	.9717	.9717	.8002	.6859
6	.7545	.8573	.9145	.9145	.9717	.743	.743
7	.8048	.8573	.9717	.9145	1.0288	.9145	.8573
8	.8048	.9717	.9145	.8573	.9717	.8002	.8002
9	.7545	.9145	.9717	.9145	.9717	.8573	.9145
10	.8573	.9145	.8573			.9145	
11	.9145	.9145					.8002
12		.8573		.743	.743		.743
13		.8573			.6859	.6287	
14	1.2574	.9145		1.086	.8573	.6859	.743
15	1.086	.9717	.9145	.9717	.8573	.6859	.6859
16	.9717	.9717	.9145	.9145	.8002	.6859	.6859
17	.9717	.763	.9145	.8573	.743	.6859	
18	.9717	.8048	.8002	.9717	.8002	.743	.743
19	1.0288	1.0288	.9145	.9717	.9717	.9145	.9145
20	1.2003	1.1431	1.2574	1.2003	1.0288	1.0288	1.0288
21	1.3146	1.2574	1.3717	1.2574	1.1431	1.086	1.086
22	1.3717	1.4861	1.4289	1.3717	1.1431	1.0288	.9717
23	1.4289	1.4861	1.4289	1.4289	1.1431	.9145	.9717
24	1.1065	1.3717	1.5432	1.4289	1.3717	1.0288	.9145
Max	1.4289	1.4861	1.5432	1.4289	1.3717	1.086	1.086
Min	.7545	.763	.8002	.743	.6859	.6287	.6859
Avg	1.0126	1.0324	1.0974	1.0642	.9872	.8548	.8274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO- SPARE FEEDER
II Feeder KV- 33 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1148	1.9456	2.915	2.5149	2.5149	2.2862	1.9433
2	1.9433	1.8804	2.8006	2.4006	2.4577	2.1148	1.7718
3	1.8861	1.8461	2.6863	2.2291	2.4006	1.9433	1.7718
4	1.7718	1.7918	2.5149	2.1719	2.2862	2.0005	1.829
5	1.7718	1.7718	2.3434	2.1148	2.2862	1.8861	1.8861
6	1.7718	1.7147	2.3434	2.0576	2.2862	2.0576	2.0005
7	1.6575	1.7147	2.2862	1.9433	2.3434	2.0576	2.0576
8	1.6004	1.7147	1.9433	1.8861	2.2291	2.0005	1.9433
9	1.6575	1.6118	1.6575	2.2862	2.5149	2.6292	2.3434
10	1.4661	1.6004	1.4289			2.9721	
11	1.4118	1.5203	1.4861				2.915
12	1.4118	1.4118	.8573	2.915	2.6863		2.8006
13	1.4661	3.0407		2.8578	2.4577	2.2862	
14	1.5203	3.2036	1.3717	2.915		2.3434	2.6863
15	1.6289	3.4208	1.5432	3.1436	2.6863	2.5149	2.8578
16	1.5746	3.3665	1.4506	2.915	2.6863	2.6292	2.915
17	1.4883	3.2253	1.4289	2.9721	2.6863	2.6292	
18	1.4198	2.6029	1.3146	2.8578	2.4577	2.5149	2.4006
19	1.6655	2.5149	1.6004	2.8006	2.572	2.5149	2.6292
20	2.0416	2.6863	2.0005	2.2862	2.4006	2.2291	2.5149
21	2.1719	2.6292	2.2291	2.572	2.2862	2.1719	2.2291
22	2.2805	2.8006	2.4577	2.6292	2.1719	2.0576	2.1148
23	2.2857	2.915	2.572	2.6863	1.3146	1.8861	1.9433
24	2.1719	2.1262	2.8006	2.4006	2.8006	1.2574	1.7718
Max	2.2857	3.4208	2.915	3.1436	2.8006	2.9721	2.915
Min	1.4118	1.4118	.8573	1.8861	1.3146	1.2574	1.7718
Avg	1.7575	2.2940	2.0014	2.5253	2.4060	2.2265	2.2536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 201 / 11 KV PKV FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2534	.2896	.2715	.2896	.2195	.181
2	.2587	.2534	.2896	.2715	.2896	.2172	.181
3	.2587	.2534	.2715	.2896	.2715	.2172	.181
4	.2218	.2534	.2715	.2896	.2743	.2172	.181
5	.2587	.2534	.2534	.2896	.2715	.1991	.1991
6	.2587	.2534	.2534	.2896	.2561	.1991	.1991
7	.2587	.2715	.2534	.2896	.2561	.1991	.2172
8	.2772	.2715	.2534	.2715		.1991	.1991
9	.2715	.2743	.2896	.2715	.2896	.2534	.2195
10	.2172	.2715					.2743
11	.2353	.2534	.2896	.3841	.362		.2926
12	.2353	.2534	.4207			.3077	.2926
13	.2715	.2534	.4344		.4706	.3077	.2926
14	.2896	.2534	.362	.4207	.3658		.2743
15	.2896	.2715	.3982		.3258		.2926
16	.2534	.2715	.4024		.3658	.2743	
17	.2534	.2715	.4024		.3109	.2743	
18	.2926	.2926	.2926		.2561	.2561	.2378
19		.2926	.2926	.2561	.2926	.2561	.2378
20	.3077	.3326	.3109	.3109	.3109	.2561	.2926
21		.3109	.3109	.3109	.3109	.2743	.2926
22	.3077	.3077	.3077	.3109	.2896	.2534	.2715
23	.2896	.2896		.3109	.2715	.2534	.2534
24	.2957	.2534	.2896	.2715	.2896	.2561	.1991
Max	.3077	.3326	.4344	.4207	.4706	.3077	.2926
Min	.2172	.2534	.2534	.2561	.2561	.1991	.181
Avg	.2673	.2715	.3154	.3006	.3057	.2445	.2392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 202 / 11 KV PANCHSHIL FEEDER
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	.7059	.724	.724	.7316	.6036	.5121
2	.7023	.7059	.724	.724	.7316	.6036	.5121
3	.6838	.7059	.724	.7059	.695	.6036	.5121
4	.6838	.6878	.6878	.7059	.695	.5487	.4755
5	.6653	.6878	.6878	.6878	.695	.5487	.5121
6	.6838	.6878	.6335	.6878	.6767	.5487	.5487
7	.6099	.6335	.6878	.6516	.6767	.6036	.5729
8	.5914	.5973	.5792	.5611		.567	.5175
9	.567	.5729	.5487	.5729	.5601	.5487	.5487
10	.5853	.5304					.439
11	.5487	.6468	.5304	.4938	.4572		.3841
12	.4938		.5121		.4755	.4024	.3841
13	.5121	.6584	.5121		.5121	.4024	.3841
14	.567	.5914	.5304	.6838	.6584		.3841
15	.3658	.6283	.5487		.4755		.4024
16	.5487	.6584	.5359		.4938	.4024	
17	.5304	.6401	.5359		.4755	.4024	
18	.5792	.5914	.5729		.4938	.4207	.4572
19	.6036	.6283	.5853	.567	.5853	.5121	.5121
20	.7499	.7577	.7133	.695	.695	.6219	.6219
21	.7682	.8048	.7865	.7499	.7133	.6219	.6584
22	.8145	.905	.7602	.8048	.695	.6099	.6653
23	.8326	.8145		.8413	.6401	.5729	.6468
24	.7023		.7602	.724	.7499	.6036	.5304
Max	.8326	.905	.7865	.8413	.7499	.6219	.6653
Min	.3658	.5304	.5121	.4938	.4572	.4024	.3841
Avg	.6288	.6746	.6309	.6812	.6174	.5374	.5083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 203 / 11 KV SUDHIR COLONY FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0328	2.1719	2.3529	2.3529	2.2131	1.8111	1.6057
2	1.9404	2.0814	2.2624	2.2624	2.19	1.8111	1.6057
3	1.885	1.9909	2.1719	2.1719	2.1948	1.8111	1.531
4	1.8111	1.9004	2.0814	2.0814	2.1719	1.8111	1.4937
5	1.8111	1.8099	1.9909	1.9909	2.1399	1.7926	1.643
6	1.8296	1.7375	1.9185	1.9004	2.0814	1.7556	1.7551
7	1.8296	1.7737	1.828	1.8823	2.0452	1.7556	1.8671
8	1.7187	1.7918	1.7194	1.7737		1.7741	1.7177
9	1.6244	1.8111	1.6244	1.6617	1.7737	1.6804	1.6289
10	1.6244	1.7924					1.5546
11	1.6057	1.5497	1.4937	1.4937	1.5123		1.3169
12	1.5497	1.5684	1.5123	1.4563	1.4563	1.2323	1.2254
13	1.6617	1.643	1.4937	1.4937	1.419	1.2883	1.2803
14	1.6617	1.7551	1.5497		1.4377		1.2254
15	1.6804	1.7364	1.643		1.475		1.2803
16	1.5746	1.9004	1.5729		1.5565	1.2851	
17	1.5729	1.7558	1.4998		1.4842	1.2489	1.2851
18	1.5364	1.6827	1.4998		1.5384	1.4299	1.3394
19	1.8107	1.957	1.7918	1.828	1.7737	1.6108	1.4842
20	1.9909	2.1399	2.0668	2.1399	2.0119	1.7741	
21	2.1176	2.2361	2.2497	2.2497	2.009	1.8839	2.2262
22	2.2986	2.5882	2.4796	2.3529	2.0271	1.9044	2.0165
23	2.4253	2.6606		2.4874	1.9185	1.7924	1.8858
24	2.1992	2.2081	2.4796	2.371	2.2862	1.829	1.6617
Max	2.4253	2.6606	2.4796	2.4874	2.2862	1.9044	2.2262
Min	1.5364	1.5497	1.4937	1.4563	1.419	1.2323	1.2254
Avg	1.8247	1.9268	1.8765	1.9972	1.8507	1.6641	1.5741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 204 / 11kv Vishwakarma Feeder Urban/Sheddable Urban Feeder
 Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1222	1.086	1.1403		.7842
2		1.086	1.086	1.1222		.7842
3		1.0498	1.0679	1.1041		.7842
4		1.0498	1.0498	1.1041		.7468
5		1.0136	1.0498	1.086		.8215
6		.9955	.9955	1.0679		.8589
7		.9593	1.0136	1.0498		.9335
8		.9412	.9412	.905		.8029
22	1.2308	1.267	1.2308		.9149	
23	1.2127	1.2851			.8962	.9709
24		1.1765	1.1403	1.1584		.8029
Max	1.2308	1.2851	1.2308	1.1584	.9149	.9709
Min	1.2127	.9412	.9412	.905	.8962	.7468
Avg	1.2218	1.086	1.0661	1.0820	.9056	.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 210 / 11 kv Incomer No.1

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0328	2.0814	2.0995	2.1538	2.073	1.7013	1.4937
2	1.9959	2.0452	2.0995	2.1357	2.1176	1.6832	1.4937
3	1.9404	2.009	2.0633	2.1176	2.0022	1.6301	1.4563
4	1.8665	1.9909	2.009	2.0995	2.0452	1.6301	1.419
5	1.9404	1.9547	1.9909	2.0633	2.0022	1.6124	1.5497
6	1.9959	1.9366	1.8823	2.0452	1.9728	1.6478	1.6244
7	1.885	1.8642	1.9547	1.9909	1.9136	1.701	1.7364
8	1.8111	1.8099	1.828	1.7375		1.6476	1.531
9	1.7737	1.6991	1.7924	1.6804	1.6804	1.7177	1.5415
10	1.643	1.643					1.4352
11	1.587	1.7364	1.6617	1.6804	1.6057		1.258
12	1.5123	1.1203	1.6617		1.2136	1.3256	1.2757
13	1.6244	1.6804	1.7177		1.6617	1.363	1.258
14	1.6991	1.7177	1.6617	1.4937	1.5684		1.258
15	1.6057	1.8111	1.8111		1.5497		1.258
16	1.6124	1.8073	1.7926		1.5364	1.262	
17	1.6118	1.7541	1.7187		1.4266	1.2986	
18	1.6655	1.701	1.7002		1.5546	1.4083	1.39
19	1.5223	1.8073	1.829	1.7558	1.7924	1.6461	1.6278
20	2.0908	2.1616	2.1216	2.1399	2.0119	1.8656	1.8839
21	2.1616	2.2502	2.268	2.2314	1.0242	1.8656	1.9753
22	2.3529	2.4796	2.2986	2.2502	1.949	1.7924	1.9605
23	2.3348	2.3891		2.3034	1.8267	1.7364	1.8858
24	2.1068	2.1357	2.19	2.1538	2.1439	1.7372	1.5497
Max	2.3529	2.4796	2.2986	2.3034	2.1439	1.8656	1.9753
Min	1.5123	1.1203	1.6617	1.4937	1.0242	1.262	1.258
Avg	1.8488	1.8994	1.9160	2.0019	1.7578	1.6136	1.5392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 211 / Incomer No.2

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0328	2.1719	2.3529	2.3529	2.1439	1.7364	1.6057
2	1.9404	2.0814	2.2624	2.2624	2.1439	1.7364	1.6057
3	1.885	1.9909	2.1719	2.1719	2.1262	1.7551	1.531
4	1.8111	1.9004	2.0814	2.0814	2.1262	1.7187	1.4937
5	1.8111	1.8099	1.9909	1.9909	2.1176	1.7187	1.643
6	1.8296	1.7375	1.9185	1.9004	2.0376	1.6832	1.7551
7	1.8296	1.7737	1.828	1.8823	2.0022	1.6832	1.8671
8	1.7187	1.7918	1.7194	1.7737	1.6124	1.701	1.7177
9	1.6244	1.8298	1.5261			1.7177	1.5947
10	1.4918	1.7924					1.5061
11	1.6057	1.5497	1.4937	1.4937	1.5123		1.2894
12	1.5497	1.5684	1.5123	1.4563	1.4563	1.2323	1.1871
13	1.6617	1.643	1.4937	1.4937	1.419	1.2883	1.2803
14	1.6617	1.7551	1.5497		1.4377		1.1871
15	1.6804	1.7364	1.643		1.475		1.2403
16	1.5415	1.8804	1.5729		1.5565	1.2851	
17	1.5238	1.7193	1.4998		1.4842	1.2489	
18	1.4883	1.6301	1.4998		1.5384	1.4299	1.3394
19	1.7541	1.8959	1.7918	1.828	1.7737	1.6108	1.4842
20	1.949	2.0953	2.0668	2.1399	1.9909	1.7741	
21	1.949	2.1439	2.2497	2.2497	2.009	1.8839	2.2262
22	2.2986	2.5882	2.4796	2.3034	1.9845	1.9044	2.0165
23	2.4253	2.6606		2.4356	1.8983	1.7924	1.8858
24	2.1992	2.2081	2.4796	2.371	2.2148	1.7718	1.6617
Max	2.4253	2.6606	2.4796	2.4356	2.2148	1.9044	2.2262
Min	1.4883	1.5497	1.4937	1.4563	1.419	1.2323	1.1871
Avg	1.8026	1.9148	1.8720	2.0110	1.8209	1.6336	1.5770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 402 / 33 KV I/C MIDC TO UMARI

DIVISION FEEDER

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9638	4.2353	4.4525	4.5068	4.2524	3.4551	3.2487
2	3.8552	4.1267	4.3439	4.3982	4.2524	3.5294	3.2487
3	3.7466	3.9638	4.2353	4.2896	4.1461	3.5294	3.0247
4	3.5837	3.8552	4.0724	4.181	4.1461	3.3488	2.4646
5	3.6923	3.7466	3.9638	4.0181	4.0398	3.3488	3.1367
6	3.7466	3.638	3.8009	3.9095	3.8409	3.3488	3.2487
7	3.638	3.638	3.7466	3.8552	3.5082	3.4019	3.6969
8	3.4751	3.5837	3.5294	3.4751	3.6145	3.3488	3.5288
9	3.4728	3.5848	3.4168	3.4168	3.6969	3.5288	3.2076
10	3.2487	3.5848		3.4728			2.9973
11	3.2487	3.4728	3.3048	3.4168	3.2487		2.7641
12	3.1927	3.4728	3.5288	1.7364	2.8006	2.8006	2.4714
13	3.3048	3.5848	3.2487	1.7364	3.2487	2.8006	2.6578
14	3.2487	3.6408	3.6408	1.7364	3.2487		2.5514
15	3.2487	3.5848	3.5848		3.3048		2.6578
16	3.1893	3.774	3.2425		3.0298	2.4983	
17	3.1361	3.5614	3.1361		2.8704	2.4983	
18	3.3488	3.4385	3.083		3.0298	2.7641	2.6578
19	3.3311	3.9095	3.5082	3.5082	3.5082	3.1893	3.083
20	4.1993	4.2524	4.0929	4.1461	3.9335	3.5997	
21	4.3056	4.513	4.4593	4.3587	2.9767	3.7071	4.0929
22	4.6153		4.7782	4.6776	4.0724	3.7529	4.0889
23	4.7239	1.2489		4.8868	3.8803	3.5848	3.7529
24	4.2353	4.3439	4.6696	4.5068	4.4119	3.5082	3.3048
Max	4.7239	4.513	4.7782	4.8868	4.4119	3.7529	4.0929
Min	3.1361	1.2489	3.083	1.7364	2.8006	2.4983	2.4646
Avg	3.6563	3.6850	3.8109	3.7117	3.6114	3.2772	3.1374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 201 / WOMEN HOSPITAL EXPRESS Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0572	.0762	.0572	.0762	.1143
2	.0572	.0762	.0572	.0762	.0572	.0762	.0572
3	.0572	.0739	.0762	.0762	.0572	.0762	.0572
4	.0532	.0762	.0762	.0762	.0572	.0762	.0572
5	.0572	.0762	.0762	.0762	.0572	.0762	.0572
6	.0572	.0739	.0762	.0762	.1143	.0762	.0572
7	.0572	.0762	.0762	.0762	.0572	.0762	.0572
8	.0572	.0762	.0762	.0762	.1143	.0572	.0572
9	.0572	.0762	.0549	.0762	.0572	.0762	.1143
10		.0953	.0762	.0762	.1143	.0762	
11	.0762	.0953		.1143	.1143	.0953	
12	.1143	.0762		.1143	.1143	.1109	
13	.0953	.0762		.1143	.1143	.1143	
14	.0953	.0762		.1143	.1143	.1143	
15	.0953	.0762		.1143	.1143	.1143	
16	.0953	.0762		.1143	.1143	.1143	
17	.0762	.0762		.1143	.1143	.1143	.0953
18	.0762	.0572	.0953		.1143	.1143	.0953
19	.0762	.0381	.0953	.0572	.0953	.0572	.0953
20	.0762	.0572		.1143	.0953	.1143	.0953
21	.0762	.0762		.0572	.0762	.0572	.0953
22	.0762	.0572		.0572	.0762	.0572	.0953
23	.0762	.0572	.0762	.0572	.0762	.0572	.0762
24		.0762	.0572	.0762	.1143	.0762	.0572
Max	.1143	.0953	.0953	.1143	.1143	.1143	.1143
Min	.0532	.0381	.0549	.0572	.0572	.0572	.0572
Avg	.0742	.0728	.0733	.0861	.0913	.0856	.0785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 202 / RAMDASPETH

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5154	1.5565	1.6632	1.4969	1.2715	1.1088
2	1.3432	1.4784	1.4998	1.6263	1.4784	1.267	1.0349
3	1.3032	1.4045	1.4901	1.5708	1.423	1.2489	.9979
4	1.2715	1.3306	1.39	1.5154	1.386	1.2489	.9979
5	1.2803	1.2567	1.3535	1.4784	1.3676	1.2308	1.0719
6	1.2357	1.1088	1.262	1.419	1.3121	1.2308	1.1643
7	1.2489	1.1458	1.2071	1.307	1.3121	1.2127	1.2012
8	1.2437	1.2197	1.1888	1.2197	1.262	1.1888	1.3121
9	1.1694	1.1157	1.1706	1.1827	1.2012		1.1827
10		1.1088	1.2254	1.1706	1.2986		
11	1.1888	1.1088		1.2012	1.3169	1.2012	
12	1.1888	1.1458		1.2197	1.2803	1.2012	
13	1.2437	1.1827		.2218	1.2437	1.2012	
14	1.2803	1.2012		.2772	1.2437	1.2012	
15	1.2437	1.2567		1.3121	1.2437	1.1088	
16	1.2254	1.3336		1.386	1.2071	1.1088	
17	1.2197	1.3121		.2772	1.134	1.1088	1.0608
18	1.2071	1.1888	1.4998		1.2308	1.1888	1.0974
19	1.2803	1.3717	1.5364	1.4969	1.4083	1.2254	1.3169
20		1.4632		1.6095	1.4842	1.2936	1.3535
21	1.39	1.4706		1.6278	1.6289	1.3121	1.3717
22	1.6632	1.7375		1.7193	1.7193	1.3306	1.3676
23	1.7002	1.7924	1.848	1.7558	1.6095	1.2936	1.2936
24		1.6057	1.6289	1.6632	1.6078	1.3169	1.1643
Max	1.7002	1.7924	1.848	1.7558	1.7193	1.3306	1.3717
Min	1.1694	1.1088	1.1706	.2218	1.134	1.1088	.9979
Avg	1.2964	1.3273	1.4184	1.3009	1.3707	1.2269	1.1822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 204 / D. P.

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7556	1.8473	1.885	1.6461	1.3394	1.134
2	1.5729	1.7002	1.7924	1.848	1.5729	1.3352	1.0791
3	1.5181	1.6632	1.7193	1.7741	1.5364	1.3352	1.0719
4	1.4815	1.6632	1.647	1.7372	1.4815	1.3352	1.0719
5	1.4266	1.5893	1.5927	1.6632	1.4449	1.3169	1.1458
6	1.3535	1.5154	1.5023	1.5684	1.4083	1.3032	1.2803
7	1.2986	1.5154	1.3352	1.531	1.39	1.2986	1.3491
8	1.2803	1.4998	1.3169	1.4045	1.3169	1.267	1.3169
9	1.2437	1.4632	1.2986	1.3306	1.3491		1.2752
10		1.4415	1.2986	1.2803	1.3169	1.3352	
11	1.2936	1.4415		1.4784	1.3169	1.2936	
12	1.3676	1.4784			1.3535	1.2197	
13	1.386	1.4784		1.5154	1.3717	1.2567	
14	1.4045	1.4784		1.4784	1.39	1.2567	
15	1.386	1.5339		1.5893	1.39	1.1827	
16	1.386	1.5708		1.5154	1.4266	1.2197	
17	1.386	1.5708		1.4784	1.3535	1.2567	1.2803
18	1.39	1.4998	1.9204		1.4083	1.2803	1.3169
19	1.4998	1.6461	1.829	1.5364	1.4842	1.3535	1.4632
20	1.6095	1.6834		1.7193	1.5565	1.4266	1.4632
21	1.6827	1.7741		1.7193	1.5546	1.4083	1.4998
22	1.7741	1.9936		1.9204	1.5927	1.4083	1.4415
23	1.848	2.0953	2.0698	1.9022	1.4299	1.3535	1.386
24		1.8298	1.9022	1.922	1.7558	1.3394	1.2437
Max	1.848	2.0953	2.0698	1.922	1.7558	1.4266	1.4998
Min	1.2437	1.4415	1.2986	1.2803	1.3169	1.1827	1.0719
Avg	1.4566	1.6200	1.6480	1.6271	1.4520	1.3096	1.2835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 206 / 11 KV VIDYUT BHAWAN FEEDER

LT WW Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0351	.0362	.0358	.0351	.0362	.0351
2	.0358	.0351	.0362	.0358	.0343	.0366	.0332
3	.0362	.0351	.0362	.0358	.0343	.0366	.0343
4	.0366	.0351	.0362	.0354	.0343	.0354	.0343
5	.0362	.0347	.0366	.0351	.0343	.0354	.0343
6	.0366	.0347	.0366	.0351	.0343	.0366	.0343
7	.0354	.0343	.0366	.0347	.0343	.0366	.0343
8	.0366	.0343	.0362	.0358	.0343	.0362	.0343
9	.0354	.0343	.0362	.0358	.0343		.0362
10		.0358	.0362	.0351	.0343	.0366	
11	.0343	.0358		.0886	.0701	.0716	
12	.0343	.0358		.1063	.1052	.0716	
13	.0343	.0358		.1075	.1052	.1075	
14	.0343	.0358		.1063	.1052	.1075	
15	.0343	.037		.1075	.1052	.1075	
16	.0343	.0358		.1052	.104	.1075	
17	.0343	.0358		.1052	.0857	.1075	.1063
18	.0351	.0366	.104		.0914	.1029	.0895
19	.0351	.0366	.0867	.1029	.0905	.104	.0895
20	.0343	.0354		.1029	.0905	.104	.0716
21	.0343	.0358		.0347	.0543	.0347	.0537
22	.0347	.0358		.0343	.0366	.0347	.0358
23	.0351	.0358	.0358	.0343	.0354	.0347	.0358
24		.0354	.0362	.0358	.0347	.0366	.0347
Max	.0366	.037	.104	.1075	.1052	.1075	.1063
Min	.0343	.0343	.0358	.0343	.0343	.0347	.0332
Avg	.0351	.0355	.0447	.0620	.0607	.0634	.0487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 207 / 11KV ICON HOSPITAL

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334	.1334	.1334	.1334	.1143	.1334
2	.1143	.1334	.1334	.1334	.1334	.1143	.1143
3	.1143	.1334	.1334	.1334	.1334	.1143	.1143
4	.1143	.1334	.124	.1334	.1143	.1143	.0953
5	.0953	.1334	.1334	.1143	.1143	.1097	.0953
6	.0953	.1334	.1143	.1143	.1143	.1143	.0953
7	.0953	.1334	.1143	.1143	.0762	.0953	.1143
8	.1143	.1334	.1143	.0953	.1334	.0953	.1143
9	.1715	.1334	.0953	.0953	.1524	.0953	.1334
10		.1334	.1715	.1524	.1143	.0953	
11	.1905	.1334		.1905	.2096	.1524	
12	.2096	.1524		.2096	.1905	.1715	
13	.1905	.1524		.2096	.1715	.1524	
14	.1715	.1524		.1905	.1715	.1524	
15	.1905	.1715		.1715	.1524	.1663	
16	.1905	.1715		.1905	.1715	.1524	
17	.1478	.1715		.2096	.1524	.1524	.1524
18	.1524	.1463	.1715		.1524	.1524	.1715
19	.1524	.0914	.1715	.1524	.1524	.1524	.1646
20	.1524	.1143	.1715	.1715	.1524	.1524	.1715
21	.1524	.1334		.1715	.1448	.1334	.1715
22	.1524	.1334		.1143	.1433	.1524	.1524
23	.1524	.1334	.1334	.1334	.1334	.1143	.1143
24		.1334	.1334	.1334	.0953	.1086	.1143
Max	.2096	.1715	.1715	.2096	.2096	.1715	.1715
Min	.0953	.0914	.0953	.0953	.0762	.0953	.0953
Avg	.1486	.1385	.1366	.1508	.1422	.1303	.1307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 210 / 11 kvIncommer 1

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4506	1.5893	1.6108	1.7372	1.5524	1.3717	1.2197
2	1.4118	1.5524	1.5384	1.7002	1.5339	1.3535	1.0903
3	1.3575	1.4784	1.5023	1.6448	1.4784	1.2934	1.0534
4	1.3394	1.4045	1.448	1.5893	1.4415	1.3352	1.0534
5	1.3213	1.3306	1.4118	1.5524	1.4083	1.3169	1.1273
6	1.3032	1.1827	1.3213	1.4784	1.423	1.3169	1.2071
7	1.3169	1.2197	1.267	1.3676	1.3676	1.2986	1.2567
8	1.2715	1.2803	1.262	1.2936	1.386	1.2308	1.3676
9	1.2071	1.1888	1.2437	1.2567	1.2752	.0724	1.2567
10		1.1888	1.2986	1.2567	1.4083	.0732	
11	1.2752	1.2012		1.3121	1.4266	1.2803	1.2936
12	1.3121	1.2197		1.3169	1.39	1.3121	1.2382
13	1.3491	1.2567		.3361	1.3535	1.3121	1.2567
14	1.386	1.2752		.3921	1.3535	1.3121	1.2567
15	1.3352	1.3306		1.423	1.3535	1.2197	1.2012
16	1.3169	1.3676		1.4969	1.3169	1.2197	1.1273
17	1.2803	1.386		.3881	1.2437	1.2197	1.1523
18	1.2803	1.2048	1.5912		1.3394	1.3121	1.1888
19	1.3535	1.4083	1.6278	1.5364	1.4998	1.2803	1.4083
20	1.4632	1.4864		1.7193	1.5912	1.4045	1.4449
21	1.5729	1.5415		1.6827	1.7193	1.3676	1.4632
22	1.7193	1.7924		1.7741	1.7924	1.386	1.46
23	1.7558	1.828	1.922	1.8107	1.6827	1.3491	1.3676
24		1.6632	1.701	1.7372	1.7187	1.39	1.2197
Max	1.7558	1.828	1.922	1.8107	1.7924	1.4045	1.4632
Min	1.2071	1.1827	1.2437	.3361	1.2437	.0724	1.0534
Avg	1.3809	1.3907	1.4819	1.3827	1.4607	1.2095	1.2483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 211 / Incommmer No.2

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.922	2.0119	2.0513	1.8296	1.4998	1.2986
2	1.7013	1.8665	1.957	2.0144	1.7556	1.4815	1.2382
3	1.6124	1.8296	1.8446	1.9404	1.7187	1.4352	1.2197
4	1.5939	1.8296	1.829	1.9035	1.6448	1.4506	1.2012
5	1.5223	1.7556	1.7556	1.8111	1.5912	1.4632	1.2752
6	1.4506	1.6817	1.647	1.7002	1.5546	1.4632	1.423
7	1.4266	1.6817	1.4661	1.6632	1.4998	1.4266	1.4815
8	1.3969	1.6644	1.4327	1.5524	1.4815	1.4083	1.4632
9	1.3535	1.6278	1.39	1.46	1.3676	.1086	1.4784
10		1.6078	1.4998	1.4632	1.4632	1.4327	
11	1.5154	1.6078		1.7556	1.5912	1.5154	1.46
12	1.6078	1.6632		.3174	1.6461	1.46	1.4969
13	1.6078	1.6632		1.8296	1.6461	1.5154	1.4969
14	1.6078	1.6632		1.7741	1.6644	1.5154	1.4415
15	1.6078	1.7372		1.8665	1.6461	1.46	1.4969
16	1.6078	1.7741		1.8111	1.701	1.4784	1.4969
17	1.5708	1.7741		1.7926	1.5912	1.5154	1.5364
18	1.5729	1.6301	2.1948	1.8111	1.6289	1.5524	1.5912
19	1.6827	1.7741	2.0851	1.7924	1.7375	1.6095	1.7193
20	1.7924	1.8656		1.9936	1.7918	1.7002	1.701
21	1.8656	1.9387		1.9204	1.7558	1.5729	1.7193
22	1.9387	2.1582		2.0668	1.7737	1.6078	1.6263
23	1.9753	2.2565	2.2361	2.0668	1.6095	1.4998	1.5339
24		1.9774	2.0668	2.0883	1.8839	1.4998	1.4045
Max	1.9753	2.2565	2.2361	2.0883	1.8839	1.7002	1.7193
Min	1.3535	1.6078	1.39	.3174	1.3676	.1086	1.2012
Avg	1.6195	1.7896	1.8155	1.7686	1.6489	1.4447	1.4696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 401 / 33KV VIDYUT BHAVAN I/C

DIVISION FEEDER

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1699	3.5482	3.6214	3.8255	3.3819	2.7938	2.5503
2	3.1276	3.4374	3.5117	3.7146	3.271	2.8235	2.3285
3	2.955	3.3265	3.2956	3.6037	3.2156	2.7692	2.2731
4		3.271	3.2922	3.4928	3.1047	2.7692	2.2731
5	2.9081	3.1047	3.1824	3.3819	3.0493	2.7692	2.384
6	2.7984	2.8829	3.0178	3.2156	2.963	2.7109	2.6612
7	2.7149	2.9384	2.7149	3.0493	2.8829	2.7435	2.7721
8	2.7149	2.963	2.7435	2.8829	2.8532	2.5514	
9	2.5252	2.8532	2.7435	2.7166	2.7166	.2743	
10		2.7984	2.7984	2.7435	2.8829	1.5364	
11	2.8275	2.7984	2.8829	3.1047	3.0178	2.8275	
12	2.9384	2.8532		1.6632	3.0727	2.7721	
13	2.9938	2.9081		3.271	3.0178	2.8275	
14	2.9938	2.9081		3.271	3.0178	2.8275	
15	2.9938	3.0727		3.3265	3.0178	2.7166	
16	2.9384	3.1276		3.3265	3.0178	2.7166	
17	2.8532	3.1276		2.2177	2.8532	2.7721	
18	2.8532	2.9081	3.786		2.955	2.8532	
19	3.0727	3.1824	3.7311	3.3819	3.2373	2.9384	
20	3.2922	3.2956		3.7311	3.4019	3.1047	3.1824
21	3.4568	3.4019		3.6214	3.4568	2.9384	3.1824
22	3.6763	3.8272			3.4551	2.9938	3.1047
23	3.7311	4.1701	4.1581	3.8958	3.2579	2.8829	2.9384
24	3.2922	3.6969	3.786	3.8255	3.6037	2.8778	2.6057
Max	3.7311	4.1701	4.1581	3.8958	3.6037	3.1047	3.1824
Min	2.5252	2.7984	2.7149	1.6632	2.7166	.2743	2.2731
Avg	3.0376	3.1834	3.2844	3.2392	3.1127	2.6579	2.6880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 410 / T/F no.1

Station Trasformer Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6078	1.6289	1.7741	1.5524		1.2197
2	1.4118	1.5524	1.5364	1.7187	1.5524		1.1088
3	1.3717	1.4969	1.4815	1.6632	1.4969		1.0425
4	1.3432	1.4415	1.4506	1.6078	1.4415		1.0534
5	1.3169	1.3306	1.3969	1.5524	1.4415		
6	1.3032	1.2197	1.2894	1.4969			1.2197
7	1.3169	1.2197	1.2489	1.386	1.4415		1.2752
8	1.262	1.3169	1.3014	1.2752	1.3717		1.386
9	1.2071	1.2071	1.262	1.2752	1.2752		1.2752
10		1.2071	1.3032	1.262	1.4266	1.5364	
11	1.262	1.2071		1.3306	1.4266	1.3306	
12	1.3169	1.2071		1.3306	1.4266	1.3306	
13	1.3717	1.262		.3326	1.3717	1.3306	
14	1.3717	1.262		.3881	1.3717	1.3306	
15	1.386	1.3169		1.4415	1.3717	1.2197	
16	1.3306	1.3717		1.4969	1.3169	1.2197	
17	1.3169	1.3717		.3881	1.262		1.1523
18	1.3169	1.8107	1.5912		1.3575	1.3169	1.2071
19	1.3717	1.4118	1.6461	1.5364	1.4661	1.2752	1.4266
20	1.4815	1.5203		1.701	1.5203	1.386	1.4815
21	1.5912	1.5581		1.701	1.6832	1.386	1.4815
22	1.7741	2.1399			1.7918	1.386	1.4969
23	1.7741	2.2325	1.9404	1.8107	1.6832	1.3306	1.386
24		1.6632	1.701	1.7741	1.7187	1.3717	1.2197
Max	1.7741	2.2325	1.9404	1.8107	1.7918	1.5364	1.4969
Min	1.2071	1.2071	1.2489	.3326	1.262	1.2197	1.0425
Avg	1.3904	1.4556	1.4841	1.3747	1.4682	1.3393	1.2770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 411 / T./F NO. 2

Station Trasformer Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9404	2.0302	2.0513	1.8296		1.3306
2	1.6478	1.885	1.9547	2.0513	1.7558		1.2197
3	1.5947	1.8296	1.8267	1.9404	1.7187		1.2071
4	1.5947	1.8296	1.8107	1.9404	1.6632		1.2197
5	1.4883	1.7741	1.7193	1.8296	1.6078		1.2752
6	1.4815	1.7187	1.6461	1.7187	1.5364		1.4415
7	1.4118	1.7187	1.4815	1.6632	1.4969		1.4969
8	1.4266	1.701	1.4661	1.5524	1.4815		1.4969
9	1.3169	1.6461	1.4118	1.4969	1.3169		1.386
10		1.6078	1.4661	1.4815	1.4815	1.4506	
11	1.5524	1.6078		1.7741	1.5912	1.5524	
12	1.6078	1.6632		.3326	1.6461	1.4969	
13	1.6078	1.6632		1.8296	1.6461	1.5524	
14	1.6078	1.6632		1.7741	1.701	1.5524	
15	1.6078	1.7741		1.885	1.6461	1.4969	
16	1.6078	1.7741		1.8296	1.701	1.4969	
17	1.6078	1.7741		1.8296	1.5912	1.5524	1.5364
18	1.5912	1.701	2.1948		1.7375	1.5364	1.5912
19	1.701	1.701	2.0851	1.8107	1.7375	1.5912	1.7558
20	1.8107	1.8656		1.9753	1.7918	1.7187	1.701
21	1.8656	1.9004		1.9204	1.7375	1.6078	1.7558
22	1.9959	2.1176		2.0851	1.7918	1.6078	1.6632
23	1.9959	2.2565	2.2731	2.0851	1.5746	1.4969	1.5524
24		1.9959	2.0633	2.1068	1.885	1.4815	1.386
Max	1.9959	2.2565	2.2731	2.1068	1.885	1.7187	1.7558
Min	1.3169	1.6078	1.4118	.3326	1.3169	1.4506	1.2071
Avg	1.6248	1.7962	1.8164	1.7810	1.6528	1.5461	1.4715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 201 / DAMANI Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2445	.2635	.2633	.2633	.2633	.2257	.2257
2	.2445	.2447	.2633	.2633	.2633	.2257	.2068
3	.2445	.2447	.2633	.2633	.2635	.2257	.2068
4	.2445	.2447	.2633	.2633	.2445	.2257	.2068
5	.2445	.2447	.2445	.2445	.2282	.2257	.2068
6	.2445	.2447	.2633	.2633	.2445	.2257	.2257
7	.2257	.2635	.2445	.2257	.2445	.2068	.2068
8	.188	.2259	.2068	.188	.188	.188	.188
9	.1692	.2259	.188	.1692	.1692	.188	.188
10		.2054	.1692		.2068	.1692	
11	.1692	.1867	.1494				.188
12	.168	.168		.1692	.1504	.1504	.1504
13	.2054	.2054	.168		.1504	.1504	
14	.2012	.2241	.1867		.188	.1316	.1692
15	.2054	.2241	.2054		.188		.1504
16	.1867	.2054	.2054	.188	.1692	.1316	.1504
17	.1867	.2241	.1867	.188	.1692	.1692	
18	.1848	.2068	.188	.188	.1692	.188	.1692
19	.2071	.2068	.188	.188	.2068	.188	.188
20	.2635	.2633	.2445	.3009	.2445	.2257	.2445
21	.2635	.2821	.2633	.2821	.2445	.2445	.2445
22	.2824	.2821	.2633	.3009	.2445	.2241	.2445
23	.2824	.2821	.2821	.3009	.2633	.2257	.2445
24		.2635	.2633	.2633	.2633	.2445	.2257
Max	.2824	.2821	.2821	.3009	.2635	.2445	.2445
Min	.168	.168	.1494	.1692	.1504	.1316	.1504
Avg	.2207	.2347	.2245	.2375	.2160	.1991	.2015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 202 / GOYANAKA Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.3443	1.4003	1.3817	1.4377	1.2136	1.1389
2	1.307	1.3256	1.3443	1.363	1.4003	1.1949	1.1576
3	1.307	1.3443	1.3443	1.3443	1.3817	1.1763	1.1203
4	1.2696	1.3256	1.3443	1.3443	1.363	1.1949	1.1203
5	1.1763	1.3443	1.363	1.363	1.3443	1.1949	1.2136
6	1.2883	1.3443	1.3443	1.3817	1.3443	1.2323	1.307
7	1.363	1.3443	1.3817	1.4377	1.4003	1.2696	1.3256
8	1.3256	1.3443	1.307	1.4003	1.3817	1.2696	1.2696
9	1.307	1.3256	1.3443	1.307	1.307	1.3443	1.1763
10		1.3443	1.1203		1.307	1.1389	
11	1.1389	1.3256	1.1763				1.1763
12	1.2136	1.4003	1.1949	1.2136	1.3256	1.1949	1.307
13	1.1203	1.363	1.1576		1.363	1.1203	
14	1.0829	1.3443	1.1016		1.1576	1.0829	1.0829
15	1.1389	1.2883	1.0456	1.251	1.1203		.9896
16	1.1389	1.2323	1.0456	1.1389	1.1203	.9896	.9522
17		1.2696	1.1203	1.1949	1.2136	1.1389	
18		1.307	1.251	1.3443	1.3443	1.3256	.9709
19	1.5123	1.4377	1.363	1.4377	1.4377	1.475	1.4003
20	1.6617	1.6991	1.587	1.587	1.531	1.4563	1.475
21	1.4937	1.5497	1.475	1.4937	1.4003	1.307	1.4003
22	1.5497	1.5123	1.5123	1.4937	1.419	1.2696	1.2696
23	1.475	1.5123	1.4937	1.4855	1.3443	1.251	1.2323
24		1.419	1.4563	1.4377	1.4377	1.251	1.1949
Max	1.6617	1.6991	1.587	1.587	1.531	1.475	1.475
Min	1.0829	1.2323	1.0456	1.1389	1.1203	.9896	.9522
Avg	1.3088	1.3770	1.3031	1.3701	1.3427	1.2314	1.2038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 204 / PANKAJ Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.58	.5987	.6355	.6355	.6355	.5233	.4985
2	.5613	.58	.6168	.5794	.6168	.5046	.542
3	.5613	.5613	.6168	.5607	.5981	.4859	.542
4	.5613	.5613	.6168	.5794	.5981	.4859	.5233
5	.5426	.58	.5981	.5794	.5981	.4486	.5607
6	.5239	.5426	.5233	.5794	.5794	.4859	.5607
7	.58	.58	.5981	.5981	.5794	.5046	.6542
8	.5426	.58	.5607	.542	.5981	.542	.5981
9	.5239	.6361	.5607	.5607	.5607	.542	.6092
10		.5975	.542		.5607	.542	
11	.5051	.5601	.5228				.5987
12		.5788	.5228	.4859	.542	.4859	.58
13	.5415	.5975	.5041		.5607	.4859	
14	.4854	.5228	.5041		.5046	.4486	.3742
15	.4668	.5228	.5041	.5046	.4673		.4116
16	.4854	.5415	.4854	.4859	.4299	.4299	.4116
17	.5228	.5601	.5041	.4859	.4673	.4486	
18	.5415	.5641	.4864	.5607	.542	.5046	.4486
19	.5607	.6168	.5987	.5981	.5607	.5233	.6361
20	.6542	.7102	.6728	.6542	.6355	.5981	.6922
21	.6174	.7102	.6355	.6542	.6168	.6168	.6548
22	.6548	.6542	.7102	.6355	.5981	.6277	.6174
23	.6361	.6542	.6728	.6067	.5794	.5981	.58
24		.6361	.6542	.6542	.6542	.5607	.5354
Max	.6548	.7102	.7102	.6542	.6542	.6277	.6922
Min	.4668	.5228	.4854	.4859	.4299	.4299	.3742
Avg	.5547	.5936	.5770	.5770	.5688	.5179	.5538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 205 / NEW TAPADIYA NAGAR Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4985	.5354	.5538	.5538	.5538	.4431	.4062
2	.48	.4985	.5354	.5354	.5354	.4431	.4062
3	.48	.48	.5354	.5169	.4985	.4246	.4062
4	.48	.4615	.5169	.4985	.48	.4246	.4062
5	.4615	.48	.4985	.4985	.4615	.4062	.4246
6	.4615	.4985	.5723	.5354	.4985	.4431	.4431
7	.48	.5041	.5354	.5354	.4985	.4431	.48
8	.4985	.4985	.4615	.5169	.5538	.4246	.4431
9	.4431	.48	.4615	.4615	.4246	.4062	.4615
10		.439	.4062		.4062	.4062	
11	.3877	.4024	.3841				
12	.4024	.4207	.3841	.3692	.3508	.3692	
13	.4024	.4207	.3841		.3692	.2954	
14	.4024	.4024	.3658		.3692	.2954	.4246
15	.4207	.439	.3841	.4062	.3692		.3877
16	.4251	.4207	.3841	.3877	.3692	.3138	.3508
17	.4024	.439	.3696	.3877	.3508	.3138	
18	.4435	.48	.4062	.4431	.3692	.4062	.3692
19	.4431	.4985	.4615	.4431	.4615	.4615	.4246
20	.5354	.5538	.5538	.5538	.4985	.48	.4985
21	.5723	.5908	.5723	.5723	.5169	.48	.4985
22	.5908	.6461	.6092	.6092	.5538	.4985	.5169
23	.6092	.6646	.6277	.5883	.5169	.4611	.48
24		.5354	.5908	.5908	.5908	.4615	.4431
Max	.6092	.6646	.6277	.6092	.5908	.4985	.5169
Min	.3877	.4024	.3658	.3692	.3508	.2954	.3508
Avg	.4691	.4912	.4814	.5002	.4607	.4137	.4353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 206 / Ashok nagar Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5386	1.5386	1.6128	1.6128	1.6128	1.3718	1.2923
2	1.483	1.5201	1.5942	1.5942	1.5942	1.3532	1.2606
3	1.483	1.483	1.5572	1.5757	1.5732	1.3718	1.2049
4	1.4645	1.5015	1.5201	1.5201	1.5386	1.3347	1.1493
5	1.4459	1.5015	1.4645	1.5572	1.5386	1.3532	1.242
6	1.4645	1.5015	1.5201	1.5386	1.5386	1.3718	1.4274
7	1.483	1.4645	1.483	1.5942	1.5757	1.3718	1.3903
8	1.4089	1.5015	1.5201	1.5572	1.5015	1.3718	1.3347
9	1.3718	1.4645	1.5015	1.3903	1.4459	1.4089	1.3903
10		1.423	1.3162		1.4089	1.2976	
11	1.2049	1.3676	1.2936				1.3162
12	1.3676	1.3676	1.2197	1.3347	1.2606	1.1123	1.4089
13	1.2936	1.386	1.2567		1.242	1.1237	
14	1.2197	1.3306	1.2567		1.1864	1.0752	1.1123
15	1.2012	1.3306	1.1827	1.1864	1.2049		1.0566
16	1.2382	1.3121	1.2382	1.2049	1.1493	1.1123	1.0196
17	1.3121	1.3491	1.2254	1.2235	1.2606	1.2606	
18	1.3306	1.3532	1.2976	1.3903	1.3903	1.3347	1.1679
19	1.5	1.5757	1.4645	1.3903	1.5015	1.5386	1.483
20	1.7407	1.7425	1.6869	1.7055	1.6498	1.6106	1.5572
21	1.6852	1.7796	1.6498	1.724	1.5942	1.5572	1.5572
22	1.7055	1.724	1.7425	1.7425	1.5386	1.483	1.5201
23	1.6869	1.6869	1.7425	1.68	1.5015	1.4274	1.4645
24		1.6128	1.7611	1.6498	1.6313	1.4274	1.3532
Max	1.7407	1.7796	1.7611	1.7425	1.6498	1.6106	1.5572
Min	1.2012	1.3121	1.1827	1.1864	1.1493	1.0752	1.0196
Avg	1.4377	1.4924	1.4628	1.5086	1.4539	1.3486	1.3195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 210 / 11KV Incommer no.I NTN

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0496	2.1428	2.2173	2.1987	2.2546	1.8819	1.752
2	2.031	2.0682	2.1428	2.1614	2.1987	1.8633	1.7701
3	2.031	2.0682	2.1428	2.1241	2.1428	1.826	1.7329
4	1.9937	2.031	2.1241	2.1055	2.0869	1.8447	1.7329
5	1.8819	2.0682	2.1055	2.1055	2.031	1.826	1.8447
6	1.9937	2.0869	2.18	2.18	2.0869	1.9006	1.9751
7	2.0682	2.1055	2.1614	2.1987	2.1428	1.9192	2.0123
8	2.0123	2.0682	1.9751	2.1055	2.1241	1.8819	1.9006
9	1.9192	2.031	1.9937	1.9378	1.9006	1.9378	1.826
10		1.9774	1.6956		1.9192	1.7142	
11	1.6973	1.9035	1.7002				1.3602
12	1.7741	1.9774	1.7372	1.7515	1.826	1.7142	1.4534
13	1.701	1.9774	1.7002		1.8819	1.5652	
14	1.6817	1.9589	1.6448		1.7142	1.5093	1.677
15	1.7556	1.9404	1.6263	1.8633	1.677		1.5279
16	1.7372	1.848	1.6263	1.7142	1.6583	1.4347	1.4534
17	.5914	1.922	1.6632	1.7701	1.7329	1.6211	
18	.6219	1.9937	1.8428	1.9751	1.8819	1.9192	1.5015
19	2.1592	2.1428	2.0103	2.0408	2.1055	2.1241	2.0123
20	2.457	2.5154	2.385	2.4409	2.2732	2.1614	2.2173
21	2.3267	2.4223	2.3105	2.3477	2.1614	2.031	2.1428
22	2.4198	2.4409	2.385	2.4036	2.2173	1.9937	2.031
23	2.364	2.4595	2.4036	2.2538	2.1241	1.9121	1.9564
24		2.215	2.3105	2.2918	2.2918	1.9564	1.8633
Max	2.457	2.5154	2.4036	2.4409	2.2918	2.1614	2.2173
Min	.5914	1.848	1.6263	1.7142	1.6583	1.4347	1.3602
Avg	1.8758	2.0985	2.0035	2.0985	2.0188	1.8426	1.7973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 211 / 11KV Incommer no.2 NTN

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8363	2.9475	3.2189	2.9754	2.9723	2.4923	2.4528
2	2.7621	2.8919	3.1264	2.8829	2.8984	2.4738	2.4369
3	2.7621	2.7806	3.0524	2.8275	2.8246	2.4923	2.3631
4	2.7436	2.725	2.9784	2.7905	2.8246	2.4369	2.2892
5	2.688	2.725	2.8304	2.846	2.8246	2.3446	2.4184
6	2.6323	2.7992	2.7749	2.8275	2.8061	2.4554	3.1524
7	2.7436	2.7806	2.8489		2.8615	2.3631	2.6031
8	2.6694	2.9289	2.9414	3.0123	2.8061	2.4579	2.4738
9	2.7065	3.0772	2.9414	2.9569	2.64	2.4949	2.5846
10		2.9754	2.7934		2.5846	2.3655	
11	2.5397	2.8829	2.6981				2.4394
12	2.8645	2.846	2.6427	2.7323	2.5953	2.1231	2.5423
13	2.6703	2.9199	2.4394		2.7138	2.1969	
14	2.6612	2.8275	2.7166		2.64	2.1784	2.1437
15	2.6057	2.7721	2.6612	2.64	2.5846		2.1784
16	2.347	2.6981	2.7166	2.3631	2.5477	2.2523	1.9938
17	2.4209	2.9014	2.7351	2.2523	2.6954	2.3631	
18	2.5185	2.963	2.6323	2.5661	2.9014	2.4554	2.385
19	2.6111	3.2929	3.0587	2.7323	3.0493	2.7692	2.8984
20	3.0926	3.5704	3.5113	3.1754	3.2156	2.9354	3.0277
21	3.3519	3.6814	3.3634	3.1754	3.1047	2.88	3.0277
22	3.3889	3.4039	3.4558	3.1341	2.9569	2.8246	2.8431
23	3.2812	3.3669	3.308	2.9169	2.8061	2.721	2.6954
24		3.0587	3.3669	3.1047	3.0092	2.6612	2.5398
Max	3.3889	3.6814	3.5113	3.1754	3.2156	2.9354	3.1524
Min	2.347	2.6981	2.4394	2.2523	2.5477	2.1231	1.9938
Avg	2.7681	2.9924	2.9505	2.8375	2.8201	2.4881	2.5471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 401 / 33 kv I/C Appatapa to New Tapd Feeder KV- 33 / OUTGOING DIVISION FEEDER

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.8637	5.0244	5.4052	5.1295	5.1846	4.3573	4.144
2	4.7532	4.9139	5.2398	5.0192	5.0192	4.3021	4.1875
3	4.7532	4.8035	5.1295	4.9088	4.9088	4.3021	4.0222
4	4.6979	4.6931	5.0743	4.8537	4.8537	4.247	3.9671
5	4.5321	4.7483	4.9088	4.9088	4.7985	4.1367	4.1875
6	4.5874	4.8587	4.9088	4.964	4.8537	4.3021	4.5181
7	4.7532	4.8587		5.0743	4.964	4.247	4.5732
8	4.6427	4.7483	4.8537	5.0743	4.9088	4.2977	4.2977
9	4.5874	5.0796	4.9088	4.8537	4.4676	4.4079	4.3528
10		4.8834	4.4676		4.4676	4.0264	
11	4.2005	4.7188	4.3896				3.7506
12	4.6091	4.7737	4.3347	4.4445	4.3573	3.8057	3.9712
13	4.4993	4.8834	4.1152		4.5779	3.7506	
14	4.2798	4.7188	4.3347		4.3021	3.6403	3.8057
15	4.3347	4.6639	4.225	4.4676	4.247		3.6954
16	4.0055	4.4993	4.2798	4.0264	4.1918	3.6403	3.4196
17	3.0807	4.7737	4.3347	3.9712	4.4124	3.9712	
18	3.0727	4.9139	4.417	4.4676	4.7434	4.3528	3.8609
19	4.763	5.4108	5.0244	4.7434	5.1295	4.8537	4.8537
20	5.5384	6.0182	5.8465	5.5707	5.4604	5.0192	5.1846
21	5.6317	6.0734	5.6259	5.4604	5.2398	4.8537	5.1295
22	5.7421	5.7973		5.5156	5.1295	4.7985	4.8537
23	5.5765	5.7913	5.681	5.2891	4.9088	4.6331	4.6331
24		5.2452	5.6259	5.3501	5.2398	4.5779	4.3573
Max	5.7421	6.0734	5.8465	5.5707	5.4604	5.0192	5.1846
Min	3.0727	4.4993	4.1152	3.9712	4.1918	3.6403	3.4196
Avg	4.6139	5.0372	4.8696	4.9046	4.7985	4.2965	4.2745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 410 / Transformer no.1

Station Trasformer Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0534	2.1089	2.2199	2.1644	2.2199	1.8869	1.776
2	1.9979	2.0534	2.1089	2.1089	2.1644	1.8314	1.776
3	1.9979	2.0534	2.1089	2.1089	2.1089	1.8314	1.7205
4	1.9979	1.9979	2.1089	2.1089	2.0534	1.8314	1.7205
5	1.8869	2.0534	2.1089	2.1089	1.9979	1.8314	1.8314
6	1.9979	2.0534	2.1644	2.1644	2.0534	1.8869	1.9424
7	2.0534	2.1089	2.1644	2.1644	2.1089	1.8869	1.9979
8	1.9979	2.0534	1.9424	2.1089	2.1089	1.8869	1.8733
9	1.8869	1.9979	1.9979	1.9424	1.8869	1.9424	1.776
10		1.9959	1.665		1.8869	1.7205	
11	1.665	1.885	1.7187				1.332
12	1.7741	1.9959	1.7187	1.7205	1.8314	1.7205	1.4444
13	1.7187	1.9959	1.7187		1.8314	1.554	
14	1.6632	1.9404	1.6632		1.7205	1.4985	1.665
15	1.7741	1.9404	1.6078	1.8314	1.665		1.5
16	1.7187	1.8296	1.6078	1.7205	1.665	1.443	1.4444
17	.6099	1.9404	1.6632	1.776	1.665	1.6095	
18	.6099	1.9979	1.8314	1.9424	1.8869	1.8869	1.5
19	2.1622	2.1089	1.9979	2.0534	2.1089	2.1089	2
20	2.4394	2.4974	2.3864	2.4419	2.2754	2.1089	2.2222
21	2.3285	2.3864	2.2754	2.3309	2.1644	1.9979	2.1111
22	2.3864	2.4419	2.3864	2.3864	2.2199	1.9979	2
23	2.3309	2.4419	2.3864	2.3165	2.1089	1.9424	1.9444
24		2.2199	2.2754	2.2754	2.2754	1.9424	1.8314
Max	2.4394	2.4974	2.3864	2.4419	2.2754	2.1089	2.2222
Min	.6099	1.8296	1.6078	1.7205	1.665	1.443	1.332
Avg	1.8660	2.0874	1.9928	2.0888	2.0003	1.8340	1.7814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 411 / Transformer no.2

SPARE FEEDER

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7984	2.9081	3.1824	2.963	2.9323	2.4691	2.4042
2	2.7435	2.8532	3.0727	2.8532	2.8532	2.4691	2.4268
3	2.7435	2.7435	3.0178	2.7984	2.7984	2.4691	2.2949
4	2.6886	2.6886	2.963	2.7435	2.7984	2.4419	2.2614
5	2.6337	2.6886	2.7984	2.7984	2.7984	2.3045	2.4797
6	2.5789	2.7435	2.7435	2.7984	2.7984	2.4143	2.5789
7	2.6886	2.7435	2.7984	2.9081	2.8532	2.3594	2.5923
8	2.6337	2.9081	2.9081	2.963	2.7984	2.4143	2.4268
9	2.6886	3.0178	2.9081	2.9081	2.5789	2.4691	2.5789
10		2.963	2.7435		2.5789	2.3594	
11	2.524	2.8532	2.6886	2.7435			2.4143
12	2.8532	2.7984	2.6337	2.6886	2.5789	2.0851	2.524
13	2.7984	2.9081	2.4143		2.6886	2.1948	
14	2.6337	2.8275	2.6886		2.6337	2.1399	2.1399
15	2.5789	2.7435	2.6612	2.6337	2.5789		2.1399
16	2.3285	2.6886	2.6886	2.3594	2.524	2.2497	1.9938
17	2.4143	2.8829	2.7166	2.2497	2.6886	2.3594	
18	2.4949	2.9081	2.5789	2.524	2.8532	2.4143	2.3594
19	2.5789	3.2373	3.0178	2.7026	3.0178	2.7435	2.8532
20	3.0727	3.5117	3.4568	3.1276	3.1824	2.9081	3.0178
21	3.2922	3.6214	3.3471	3.1276	3.0727	2.8532	3.0178
22	3.3471	3.3471	3.4019	3.1439	2.9081	2.7867	2.7984
23	3.2373	3.3471	3.2922	3.0115	2.7984	2.6774	2.6886
24		3.0178	3.3471	3.0727	2.963	2.6337	2.5135
Max	3.3471	3.6214	3.4568	3.1439	3.1824	2.9081	3.0178
Min	2.3285	2.6886	2.4143	2.2497	2.524	2.0851	1.9938
Avg	2.7433	2.9563	2.9196	2.8152	2.7946	2.4644	2.5002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 201 / 11 KV ITI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9425	.9795	1.0642	1.1458	1.1576	.924	.7947
2	.9055	.9055	1.0269	1.1088	1.1389	.8871	.7762
3	.8871	.8686	.9896	1.0719	1.1016	.8501	.7762
4		.8501	.9522	.9979	1.0642	.8316	.7577
5	.7762	.8316	.9335	.961	1.0269	.8131	.7577
6	.7392	.8131	.8962	.9425	1.0082	.8501	.7762
7	.7577	.7947	.9149	.9979	1.0642	.924	.8686
8	.8316	.8686	.9522	.961	1.1016	1.0534	.9425
9	.8686	.8686	.9709	.9425	1.0829	.9979	.961
10	.9979	.8686	1.0642	1.1763	1.0719	1.0719	1.0349
11	1.2382	.961	1.363				1.2382
12	1.2936	.8686	1.4415	1.4377	1.3676		1.2567
13	1.2936		1.386	1.531	1.4415	1.3121	1.2936
14	1.2752	1.2197	1.3676	1.5123	1.3676	1.2197	1.3121
15	1.2752	1.1827	1.5339		1.4415	1.2382	1.2936
16	1.2752	1.2012	1.46	1.5708	1.3676		
17	1.4415	1.1643	1.4784	1.5154	1.3121	1.2752	
18	1.3491	1.1458	1.46	1.423	1.386	1.3306	1.3676
19	1.4045	1.2936	1.5893	1.5524	1.531	1.46	1.423
20	1.5893	1.386	1.7372	1.6632	1.5684	1.386	1.46
21	1.4969	1.2936	1.5339	1.5708	1.4003	1.2382	1.3121
22	1.2382	1.251	1.3676	1.4003	1.1458	1.1088	1.0534
23	1.1458	1.2323	1.3121	1.307	1.0903	.9979	.9979
24		1.0164	1.1016	1.2012	1.1949	1.0164	.8686
Max	1.5893	1.386	1.7372	1.6632	1.5684	1.46	1.46
Min	.7392	.7947	.8962	.9425	1.0082	.8131	.7577
Avg	1.1374	1.0376	1.2457	1.2723	1.2362	1.0851	1.0601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 202 / 11 KV MHADA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2033	.1848	.2033	.2033	.1663	.1478
2	.2033	.2033	.1848	.1478	.1848	.1478	.1294
3	.1663	.1848	.1663	.1294	.1663	.1478	.1294
4	.1663	.1663	.1663	.1294	.1663	.1294	.1294
5	.1478	.1663	.1478	.1294	.1478	.1294	.1294
6	.1294	.1294	.1478	.1294	.1478	.1294	.1109
7	.1294	.1294	.1478	.1478	.1478	.1663	.1294
8	.1109	.1294	.1478	.1294	.1294	.1663	.1294
9	.1663	.1294	.1478	.1294	.1294	.1478	.1294
10	.1478	.1294	.1294	.1294	.1294	.1663	.1109
11	.1663	.1478	.1294				.1478
12	.1294	.1663	.1478	.1848			.1663
13	.1663	.1663	.1478	.1848	.1663	.1663	.1294
14	.1478	.1663	.1663	.1848	.1663	.1478	.1478
15	.1478	.1646	.1663		.1478	.1478	.1478
16	.1663	.1848	.1663	.1663	.1663		
17	.1294	.1663	.1663	.1478	.1294	.1478	
18	.1478	.1663	.1478	.1478	.1478	.1478	.1478
19	.2033	.2033	.1478	.1478	.2033	.1663	.1663
20	.1848	.2033	.1663	.1848	.2218	.1848	.1848
21	.2033	.2033	.1848	.2033	.1848	.1848	.1848
22	.2218	.2402	.2218	.2587	.1848	.2033	.1848
23	.2402	.2402	.2402	.2402	.2033	.1848	.1848
24		.2402	.2033	.2218	.2218	.1848	.1478
Max	.2402	.2402	.2402	.2587	.2218	.2033	.1848
Min	.1109	.1294	.1294	.1294	.1294	.1294	.1109
Avg	.1663	.1763	.1655	.1672	.168	.1601	.1462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 203 / 11 KV SHITALA MATA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4024	.439	.4207	.4207	.3475	.2926
2	.3658	.4024	.4024	.4024	.4024	.3292	.2926
3	.3658	.3475	.3841	.3658	.3841	.3292	.2743
4	.3475	.3475	.3658	.3658	.3658	.3109	.2743
5	.3292	.3109	.3475	.3475	.3475	.2926	.2743
6	.3109	.2926	.3292	.3475	.3292	.2926	.2926
7	.2926	.2926	.3475	.3475	.3658	.3292	.3475
8	.2743	.3109	.3292	.3475	.3292	.3658	.2926
9	.3109	.2926	.4024	.4066	.4024	.3841	.3658
10	.3292	.3292	.4024	.4024	.439	.4207	.4024
11	.3658	.3658	.4938				.439
12	.3841	.3292	.4938		.4572		.4207
13	.4207	.3841	.4805		.4755	.4207	.4207
14	.4024	.3658	.4938	.6036	.5121	.439	.4024
15	.4024	.3881	.4938		.4938	.4207	.4024
16	.4207	.4024	.5304	.5359	.4755		
17	.4207	.3658	.4938	.5304	.4572	.4207	
18	.3841	.3658	.4755	.4755	.439	.4207	.4207
19	.499	.439	.5487	.5487	.5121	.5121	.5121
20	.4755	.4572	.499	.5304	.5487	.439	.4572
21	.4572	.4207	.4938	.4938	.439	.4024	.439
22	.439	.4572		.4938	.4207	.4024	.3658
23	.4572	.5304	.4938	.4938	.4066	.3511	.3475
24		.4572	.4572	.4572	.439	.3658	.3109
Max	.499	.5304	.5487	.6036	.5487	.5121	.5121
Min	.2743	.2926	.3292	.3475	.3292	.2926	.2743
Avg	.3851	.3774	.4434	.4458	.4288	.3808	.3658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 207 / 11 KV INCOMMER

SPARE FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5524	1.5893	1.6817	1.7741	1.7741	1.4415	1.2382
2	1.4784	1.4784	1.6078	1.6632	1.7187	1.3676	1.2012
3	1.423	1.4045	1.5339	1.5708	1.6448	1.3306	1.1827
4	1.3491	1.3676	1.4784	1.4969	1.5893	1.2752	1.1643
5	1.2567	1.3121	1.423	1.4415	1.5154	1.2382	1.1643
6	1.1827	1.2382	1.3676	1.423	1.4784	1.2752	1.1827
7	1.1827	1.2197	1.4045	1.4969	1.5708	1.423	1.3491
8	1.2197	1.3121	1.423	1.4415	1.5524	1.5893	1.3676
9	1.3491	1.2936	1.5154	1.4784	1.6078	1.5339	1.46
10	1.4784	1.3306	1.5893	1.7002		1.6632	1.5524
11	1.7741	1.4784	1.9774				1.8296
12	1.8111	1.3676	2.0883	1.6078	1.9774	1.9035	1.848
13	1.885	.5544	2.0144	1.7002	2.0883	1.9035	1.848
14	1.8296	1.7556	2.0328	2.2916	2.0513	1.8111	1.8665
15	1.8296	1.7372	2.1992		2.0883	1.8111	1.848
16	1.8665	1.7926	2.1622	2.3101	2.0144		
17	1.9959	1.7002	2.1437	2.1992	1.9035	1.848	
18	1.885	1.6817	2.0883	2.0513	1.9774	1.9035	1.9404
19	2.1068	1.9404	2.2916	2.2546	2.2361	2.1437	2.1068
20	2.2546	2.0513	2.4025	2.384	2.3285	2.0144	2.1068
21	2.1622	1.922	2.2177	2.2731	2.0144	1.8296	1.9404
22	1.9035	1.9404		2.1437	1.7556	1.7187	1.6078
23	1.848	1.9959	2.0513	2.0328	1.7002	1.5339	1.5339
24		1.7187	1.7556	1.885	1.848	1.5708	1.3306
Max	2.2546	2.0513	2.4025	2.384	2.3285	2.1437	2.1068
Min	1.1827	.5544	1.3676	1.423	1.4784	1.2382	1.1643
Avg	1.6793	1.5493	1.8456	1.8464	1.8380	1.6423	1.5759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024012 / KUTASA

Feeder No / Name : 201 / 11 KV KUTASA FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2241	.2402	.2218	.2218	.2263	.1848
2	.2402	.2218	.2402	.2218	.2218	.2195	.1848
3	.2402	.2054	.2218	.2218	.2218	.2172	.1848
4	.2218	.2075	.2218	.2402	.2218	.1886	.1848
5	.2033	.1867	.1848	.2033	.2033	.1463	.1663
6	.1848	.1478	.1478	.1848	.2033	.128	.1663
7	.1109	.1307	.1109	.1294	.1478	.1097	.1109
8	.0924	.112	.0924	.1109	.1097	.1132	.0924
9	.0924	.1294	.0924	.0924		.1097	.0895
10	.0934	.1097	.0739				.0924
11	.1109	.1097	.1307				.0747
12	.112	.1109	.1294	.1109	.1478		
13	.1478	.1478	.1478	.1478	.1294	.0924	
14	.1663	.1646	.168	.1848	.1478		.1294
15	.168	.1848	.168	.1663	.1663		
16	.1097	.1848	.168	.1478	.128	.0924	.1294
17	.0934	.1478	.1307	.1109		.0924	.0924
18	.1097	.128	.1109	.1109	.132	.0924	.1109
19	.1867	.2012	.1478	.1109	.1886	.1663	.1307
20	.2054	.2614	.2218	.1791	.2012	.2033	.2263
21	.2427	.2641	.2427	.2218	.1991	.2033	.2263
22	.2402	.2614	.2427	.2378	.2195	.2033	.2054
23	.2402	.2561	.2402	.2402	.2075	.2033	.1867
24	.2402	.2195	.2452	.2402	.2218	.2378	.1848
Max	.2427	.2641	.2452	.2402	.2218	.2378	.2263
Min	.0924	.1097	.0739	.0924	.1097	.0924	.0747
Avg	.1705	.1799	.1717	.1744	.1820	.1603	.1502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024012 / KUTASA

Feeder No / Name : 202 / 11KV Dahihanda

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	1.0642	1.0317	.9412	.8954	.7545	.5975
2	.9335	1.0349	1.0317	.9231	.905	.7316	.5975
3	.8962	1.0456	1.0242	.924	.8688	.724	.5788
4	.8402	1.0374	1.0242	.9055	.8688	.6413	.5788
5	.7655	.961	.9511	.8871	.8779	.5658	.5601
6	.7095	.9709	.8596	.8402	.8413	.4938	.5415
7	.6161	.8962	.8316	.7468	.6401	.4715	.4668
8	.6161	.8131	.7577	.6722	.543	.3841	.4294
9	.7095	.7762	.7577	.7655		.3841	.4207
10	.7282	.7133	.7842				
11	.462	.7316	.6908				
12	.6283	.7602	.6161	.7087	.6653		
13		.8869	.8029	.7343	.0724	.3734	
14	.8962	.9055	.9149	.8145	.0732		.4108
15	.695	.8962	.961	.8145	.0732		.3921
16	.7842		.9055	.7783	.0754	.4108	.3881
17	.7682	.8962	.7947	.5611	.0549	.3921	.3881
18	.8775	.823	.7468	.5731	.0566	.4481	.4066
19	.9511	.9145	.9335	.6626	.9694	.5975	.547
20	1.1016	1.0791	1.0456	.985	1.0562	.6535	.679
21	1.2136	1.1317	1.1576	1.0029	1.0059	.6722	.6535
22	1.1827	1.1506	1.1088	1.0317	.9877	.6908	.6413
23	1.0642	1.0374	1.1016	.9425	.7133	.6535	.6413
24	.9522	1.0099	1.0425	1.0082	.9231	.7922	.5975
Max	1.2136	1.1506	1.1576	1.0317	1.0562	.7922	.679
Min	.462	.7133	.6161	.5611	.0549	.3734	.3881
Avg	.8435	.9363	.9115	.8283	.6270	.5703	.5258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 201 / 11 KV TAKLI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3206		.4066	.3326	.2987
2	.3109	.2987		.3696	.3361	.2987
3	.3142	.2614		.3734	.3206	.2772
4	.3174	.2587		.3734	.3109	.2772
5	.3174	.2378		.3696	.3109	.2801
6	.2587	.2427		.3142	.2987	.2427
7	.2033	.2263		.2587	.2241	.1698
8	.1829	.2402			.1867	.168
9	.181	.2241			.1867	.1478
10	.197	.2452			.1494	.1463
11	.1629	.2658			.1463	.1463
12	.1646	.2658		.2454	.1629	.1663
13	.2402	.2658		.2454	.1646	.1663
14	.2614	.2865		.2715	.1646	.1867
15	.2218	.3077		.2715	.1663	.1886
16	.2801		.2686	.2103	.1494	.1848
17	.2218		.2427	.208	.1494	
18	.2054			.2658	.1848	.2263
19	.2957		.333	.3403	.2957	.2801
20	.3921		.3898	.3841	.3326	.3584
21	.4066		.4525	.3734	.3292	.3361
22	.4108		.4572	.3696	.3174	.2957
23	.3511		.4024	.3326	.2987	.2801
24	.3361	.3395		.4066	.3361	.2987
Max	.4108	.3395	.4572	.4066	.3361	.3584
Min	.1629	.2241	.2427	.208	.1463	.1463
Avg	.2739	.2679	.3637	.3195	.2439	.2357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 202 / 11 KV RAIL

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.7207	.7762	.7207	.7468	.6468	.5304
2	.6036	.6838	.7468	.7207	.7468	.6468	.5415
3	.6036	.6401	.7468	.6535	.7207	.5975	.5415
4	.6283	.6348	.7545	.6099	.7207	.5853	.5359
5	.6154	.6722	.7468	.5788	.7207	.5853	.5359
6	.5359	.6908	.7023	.5544	.6838	.6224	.5041
7	.4835	.6099	.6335	.5304	.5544	.4805	.415
8	.4334	.5847	.5493	.5415		.4805	.3961
9	.4733	.4854	.5434	.6161		.3921	.3921
10	.5083	.5121	.5316	.499		.3696	.3547
11	.4835	.5373	.5304			.3511	.3142
12	.4854	.5731	.5729		.4854	.3292	.3206
13	.5228	.6089	.5487		.5375	.3258	.3326
14	.5729	.6201	.6036		.5493	.3582	.2957
15	.5847	.6201	.6584		.5201	.3544	.3018
16	.5544	.6135	.6036	.6024		.2804	.3361
17	.6036	.6135		.5316	.4161	.2835	
18	.5228	.631	.5487		.543	.2686	.4066
19	.6413	.6878	.5914	.6089	.6219	.499	.5093
20	.7842	.8048		.7888	.6838	.567	.6036
21	.8299	.8048	.8215	.823	.7282	.5544	.5729
22	.8215	.8131	.823	.8316	.7207	.6036	.5601
23	.7577	.7762	.7762	.4435	.6908	.5658	.5658
24	.6348	.7545	.7762	.7392	.7577	.6908	.547
Max	.8299	.8131	.823	.8316	.7577	.6908	.6036
Min	.4334	.4854	.5304	.4435	.4161	.2686	.2957
Avg	.5967	.6539	.6630	.633	.6394	.4766	.4528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 203 / 11 KV CHOHATA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.8676		.2452	.2241	.1886
2	.2241	.8676		.2452	.2241	.1886
3	.2263	.8316		.2427	.2241	.1886
4	.2241	.8131		.2427	.2263	.1886
5	.2241	.8029		.2402	.2427	.1886
6	.2054	.8131		.2402	.2263	.1886
7	.1886	.7842		.2054	.2054	.1698
8	.1886	.8131			.2033	.1698
9	.2033	.1886			.1886	.1698
10	.2241	.3206			.2012	.2195
11	.1886	.2241			.1829	.1698
12	.1848	.2218		.2481	.1646	.1867
13	.2054	.2218		.2402	.1646	.1698
14	.2054	.2075		.1991	.1848	.1698
15	.2263	.2054		.1991	.1663	.1663
16	.2241		.2033	.2149	.1509	.2054
17	.2263		.1991	.1991	.1867	
18	.2033			.2033	.2218	.1848
19	1.2826		1.0117	.2452	.2054	.2054
20			1.2269	.2641	.2427	.2452
21	.8029		.2641	.2452	.2263	.2241
22	.9808		.2829	.2263	.2263	.2054
23	.9149		.2641	.2263	.2075	.1886
24	.2402	.8962		.2452	.2263	.1886
Max	1.2826	.8962	1.2269	.2641	.2427	.2452
Min	.1848	.1886	.1991	.1991	.1509	.1663
Avg	.3485	.5675	.4932	.2309	.2051	.1900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 204 / 11 KV KELIVELI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4294	.4108	.3734	.4108	.4481	.3734
2	.4066	.3921	.4108	.3734	.4108	.4251	.3772
3	.3841	.3696	.4066	.3547	.4066	.415	.3584
4	.415	.3361	.4066	.3547	.3881	.4108	.3547
5	.3921	.3511	.4024	.3292	.3921	.3881	.3511
6	.3921	.3511	.3696	.3511	.3734	.3921	.3326
7	.3292	.3395	.3258	.3077	.2987	.3206	.2743
8	.3224	.3547	.3224	.3292		.2452	.2926
9	.3761	.3696	.3366	.3511		.2957	.3077
10	.4252	.3734	.3045	.2987		.2614	.2195
11	.2926	.2896	.3292			.2402	.1848
12	.3142	.3403	.3881		.3898	.2033	.2402
13	.4108	.3582	.3921		.3582	.2195	.2263
14	.4251	.362	.4251		.3841	.2534	.3584
15	.3961	.362	.439		.3658	.2534	.3326
16	.3696	.3475	.3982	.394	.3801	.2743	.3361
17	.3174	.3439		.298	.3582	.2865	.3395
18	.3142	.362			.4075	.3155	.3547
19	.4108	.4024		.3761	.4706	.3403	.3584
20	.499	.4805		.4066	.5121	.4163	.5228
21	.4904	.4805	.4805	.4435	.499	.4024	.4854
22	.439	.462	.499	.462	.499	.4108	.4481
23	.499	.4435	.4207	.4435	.4854	.3921	.3734
24	.4066	.4668	.4251	.4108	.4108	.4854	.3734
Max	.499	.4805	.499	.462	.5121	.4854	.5228
Min	.2926	.2896	.3045	.298	.2987	.2033	.1848
Avg	.3929	.3820	.3947	.3699	.4101	.3373	.3407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 201 / 11 KV UMARA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.4534		1.9753	1.0974	.5487	.5144
2	.5853	.4534		1.9753	2.4143	.5487	.5144
3	.5853	.4534		1.9753	2.4143	.5487	.4458
4	.5853	.421		1.9753	2.3777	.5121	.4458
5	.5487	.3887		1.9753	2.3411	.4755	.4458
6	.3658	.3239		1.9387	2.1948	.4024	.4115
7	.2926	.2591		2.1948	2.0119		.2743
8	.2561	.1943		2.1948	2.0485		.2743
9	.2195	.1943		2.3594	2.2314		.2743
10	2.4143	2.332	.0183	.2195			.3155
11	2.2291	2.3472					.2804
12	2.2291	2.5057	.2195		.2195		.2926
13	2.2634	2.4691	.2195	.2561	.2561		.2926
14	2.2634	2.5972	.2378	.2378	.2561	.5487	.2926
15	2.2634	2.6337	.2378	.2195	.2195	.4115	.2926
16	2.2634	2.5972	.2378	.2195	.2195	.3734	.2926
17	2.2291	2.5606		.2195	.2195	.3429	.3109
18	.3258	.3109	.2561	.2743	.3292	.2896	.2926
19	.543	.3841	.3475	.4024	.439	.543	.2926
20	.5144	.4755	.5487	.5487	.5121	.543	.439
21	.5144	.5121	.6219	.5853	.567	.543	.439
22	.6154	.5487	.6219	.5487	.567	.543	.4755
23	.6154	.5487	.6036	.5487	.5487	.543	.4755
24	.5853	.4534	2.268	1.9753	2.4508	.5487	.5144
Max	2.4143	2.6337	2.268	2.3594	2.4508	.5487	.5144
Min	.2195	.1943	.0183	.2195	.2195	.2896	.2743
Avg	1.0789	1.1007	.4953	1.1282	1.1789	.4862	.3708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 202 / 11 KV KASOD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4715		1.3957	1.0974	.3961	.3395
2	.4527	.4715		1.3957	1.0791	.3961	.3395
3	.4527	.4715		1.3957	1.0791	.3961	.3395
4	.4527	.4715		1.3957	1.0791	.3961	.3018
5	.4338	.415		1.3957	1.0608	.3772	.3018
6	.3772	.3772			1.0608	.3018	.2641
7	.2452	.3018		1.1317	1.0608	.2452	.2263
8	2.5857	.2452		1.358	1.0974	.2075	.2075
9	.2075	.1886		1.358	1.0425	.1886	.1886
10	1.4712	1.2689		.1886		.415	.1753
11	1.3203	1.3413	.2075	.2195		.3086	
12	1.3203	1.39	.2075	.2195	.2452	.3429	
13	1.3203	1.3535	.2452	.2743	.2452	.3086	.1097
14	1.3203	1.3535	.3018	.3109	2.5526	.2401	.1097
15	1.3203	1.3535	.3018	.2926	.2641	.2058	.1097
16	1.3375	1.3535	.2829	.2743	.2075	.2058	.1097
17	1.3717	1.3535		.2195	.2075	.2058	.128
18	.2452		.2641	.2012	.2263	.2263	.1829
19	.3018	.2195	.2641	.2561	.3018	.2829	.3292
20	.3772	.4207	.415	.4024	.3772	.3018	.3292
21	.4527	.439	.4715	.439	.2641	.3395	.3658
22	.4527	.439	.4715	.4572	.3772	.3395	1.2986
23	.4715	.4572	.6602	.4572	.3961	.3395	.3841
24	.4527	.4715	1.1888	1.3957	1.0974	.3961	.3395
Max	2.5857	1.39	1.1888	1.3957	2.5526	.415	1.2986
Min	.2075	.1886	.2075	.1886	.2075	.1886	.1097
Avg	.7998	.7230	.4063	.7145	.7463	.3068	.2945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 203 / 11 KV BORDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1382	2.4006		.3961	.3658	1.4586	.6859
2	2.1382	2.4006		.3481	.3292	1.4586	.6859
3	2.1382	2.4006		.3481	.3292	1.4586	.6859
4	2.1382	2.4006		.3481	.2926	1.4586	.6859
5	2.0885	2.2291		.3481	.2926	1.4586	.6859
6	2.2708	2.1434		.2984	.2743	1.4586	.5487
7	2.5526	2.0233		.2321	.2743		.5487
8		1.5424		.1989	.2195		.5487
9	2.6189	2.6825		.1989	.1829		.4801
10	.1658	.2263		3.0167	.1829		.1698
11	.2263	.2263	2.7018	3.2922			.1698
12	.2263	.2195	2.9338	3.2922	2.6023		.1646
13	.3018	.2195		3.1093	2.536	.1886	.1646
14	.3018	.2561	2.9172	2.963		.2452	.1829
15	.3018	.2926		3.1093	2.1548	.2075	.1829
16	.3018	.1829	3.0167	3.219	2.2211	.1886	.1646
17	.2263	.1646		3.0361	2.0719	.1886	.1829
18	.1886	.2195	.2012	.1646	.1492	.2263	.1646
19	.3018	.2926	.2984	.2378	.1658	.3018	.2378
20	.3018	.439	.3481	.3292	.2321	.3018	.3475
21	.3395	.4024	.3647	.3841		.3018	.3475
22	.3772	.3841	.3647	.4024	.3315	.3018	.3475
23	.3772	.3658	.3481	.4024	.2984	.3018	.3475
24	2.1216	2.4691	2.9504	.3481		1.4586	.6859
Max	2.6189	2.6825	3.0167	3.2922	2.6023	1.4586	.6859
Min	.1658	.1646	.2012	.1646	.1492	.1886	.1646
Avg	1.0497	1.1076	1.4950	1.2510	.7753	.7202	.3923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 204 / 11 KV ADGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8656	1.8138	2.8166	.5487	2.8166	1.6095	1.3413
2	1.8656	1.8138	2.8166	.5487	2.7801	1.6095	1.3413
3	1.8656	1.8138	2.7801	.5487	2.7801	1.6095	1.3413
4	1.8656	1.8138	2.7801	.5487	2.7435	1.6095	1.3413
5	1.8473	1.8461	2.7801	.5487	2.7069		1.3413
6	1.9022	1.8623	2.7618	.4572	2.5606		1.4575
7	1.9387	1.9271	2.7435	.2561	2.3777		1.5432
8	1.957	1.9109		.2561	2.4508		1.5604
9	1.9936	1.9433		.2195	2.2314		1.0974
10	.2195	.2743		.1395			.1753
11	.3086	.2683	2.1948	2.4143			.1753
12	.3086	2.7801	2.1765	2.3777	2.1582		.4755
13		2.7435	2.1582	2.4691		.3018	.4572
14		2.8898	2.1948	2.5606	2.0851	.2743	.439
15		2.9995	2.2131	2.5606	2.0302	.3018	.439
16	.3086	2.9081	2.1399	2.5606	2.0119	.2743	.439
17	.3429	2.8166		2.3411	2.0119	.2058	.439
18	.2896	.3109	.2561	.2743	.2926	.2896	.4755
19	.543	.4024	.3109	.4024	.3841	.3982	.439
20	.543	.4755	.4572	.5487	.4572	.3982	.5304
21	.5144	.5121	.5487	.5853	.4755	.3982	.5304
22	.5144	.5487	.5487	.6219	.4938	.4344	.5487
23	.5487	.5853	.5487	.6219	.4755	.4344	.5487
24	1.8656	1.8138	2.8166	.5487	2.8166	1.6095	1.3413
Max	1.9936	2.9995	2.8166	2.5606	2.8166	1.6095	1.5604
Min	.2195	.2683	.2561	.1395	.2926	.2058	.1753
Avg	1.1147	1.6281	1.9022	1.0400	1.8638	.7349	.8258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 201 / 11 KV PANAJ

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8404	2.1068	2.9797	2.7854	2.5749	1.6126	1.5912
2	1.8054	2.0698	2.8921	2.6886	2.5587	1.5249	1.5546
3	1.7703	2.0328	2.822	2.6406	2.5587	1.4723	1.5203
4	1.7353	2.0513	2.6642	2.7046	2.556	1.4022	1.5729
5	1.6476	2.0513	2.6292	2.7041	2.5396	1.4373	1.5912
6	1.6118	1.885	2.6642	2.7526	2.5069	1.4198	1.6095
7	1.5927	1.6817	2.8045	2.7357	2.5934	1.4548	1.6263
8	1.4548	1.6651	2.8746	2.7199	2.2885		1.4815
9	1.4198	1.7187	3.12	2.8006	2.0978		1.4449
10	3.4179	3.4179	1.3672	1.5364			.9831
11	2.9607	3.3303		1.3306	1.1919		1.0242
12	2.8807	3.3653			1.2094		
13	2.9127	3.3478	1.4198		1.2445	.7935	.8642
14	2.9127	3.3478	1.4632		1.5249	.7865	.9031
15	2.9127	3.3653	1.5729	1.7002	.9991	.8192	.6478
16	3.0045	3.453	1.5181	1.6461	1.0867	.9667	.6483
17	3.0045	3.3303	1.3352	1.4449	1.1218	.9012	
18	1.3169	1.3672	1.3169		1.4723	1.0425	.905
19	1.4449	1.4373	1.5546	1.4449	1.5775	1.3756	1.134
20	1.9035	1.4723		1.9281	1.7177	1.5565	1.3676
21	1.9404	1.7353		1.9631	1.7528	1.6278	1.7002
22		2.1033		2.0332	1.7353	1.5746	1.8111
23	2.1807	1.9982	2.0157	1.9982	1.7002	1.5023	1.7193
24	1.9281	2.1068	3.0674	3.0148	2.5749	1.7177	1.5424
Max	3.4179	3.453	3.12	3.0148	2.5934	1.7177	1.8111
Min	1.3169	1.3672	1.3169	1.3306	.9991	.7865	.6478
Avg	2.1565	2.3517	2.2148	2.2286	1.8775	1.3152	1.3292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 202 / 11 KV AKOLI J

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.3763	1.1142	1.0322	1.0159	.7209	.4752
2	1.3599	1.3763	1.0814	.9995	1.0159	.6882	.4915
3	1.4582	1.3763	1.0814	.9831	1.0159	.7865	.5243
4	1.5238	1.3599	.9503	.9503	1.0159	.8192	.5898
5	1.5893	1.3599	1.0486	.9012	1.0159	.7537	.639
6	1.6385	1.4091	1.1305	.8192	1.0486	.7209	.6226
7	1.6549	1.5074	.9012	.8356	.9339	.7373	.6062
8	1.6549	1.5565	.8192	.7701			.5571
9		1.7204	.7209	.7045			.6226
10		.8356	.6718	1.6876			.6554
11	.6882	.8029		1.7368	1.0867		.6226
12	.6554	.8192			1.065		.5243
13	.7045	.8356	1.5893	1.7695	1.2289	.4752	.5243
14	.7045	.8192		1.7532	.9503	.4752	.5243
15	.6882	.8192	1.6876	1.7204	1.0486	.5571	.5243
16	.7045	.8848	1.6385	1.7695	1.0159	.5407	.5243
17	.7045	.2785	1.6549	1.6549	.9831	.5243	
18	.6718	.6718	.6062		.9831	.5407	.5243
19	.639	.9503	.8029	1.5238	.8192	.7537	.6882
20	1.0814	1.0322		1.1142	1.0486	.9831	.9175
21	1.1142	1.0486		1.1469	.9995	.9012	.9503
22	1.1633	1.1469		1.1305	.9831	.8848	.9503
23	1.1142	1.1469	1.065	1.0978	.7701	.9012	.8848
24	1.278	1.3763	1.065	1.0322	1.0159	.7701	.4424
Max	1.6549	1.7204	1.6876	1.7695	1.2289	.9831	.9503
Min	.639	.2785	.6062	.7045	.7701	.4752	.4424
Avg	1.0955	1.1046	1.0905	1.2333	1.0029	.7123	.6255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 203 / 11 KV RUIKHED

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2286	.2134	2.2862	2.5301	.2286	.1981
2	.2134	.2286	.1829	2.332	2.5301	.1981	.1981
3	.2286	.2286	.1677	2.3472	2.4387	.2134	.2134
4	.2134	.2286	.1524	2.3015	2.4082	.1524	.1981
5	.1981	.2286	.1981	2.4082	2.2253	.1677	.2134
6	.1981	.2286	.2286	2.4234	2.2253		.2134
7	.1981	.1981	.1524	2.4387	2.21		.2134
8	.1829	.1981	.1677	2.4844	2.1338		.2134
9		.1829	.1829	2.4691	1.7223		.1981
10		2.5606	.1219	.1677			.6859
11	2.713	2.5453		.1524	.1638		.7621
12	2.6063	2.5758			.1638		.7773
13	2.5606	2.4996		.1829	.1219	.5944	.7926
14	2.5606	2.332		.1829		.6097	.7926
15	2.5606	2.2558	.1677	.1524	.1219	.5944	.7926
16	2.5606	2.4387	.1677		.1219	.6554	.9297
17	2.5606	2.2558	.1524		.1372	.6097	
18	.1524	.1372	.1219		.1524	.1372	.1219
19	.1524	.1829	.1677	.1829	.2134	.1981	.1981
20	.2439	.2439		.1829	.2439	.2286	.2286
21	.2439	.1829		.2622	.2286	.2134	.2286
22	.2439	.2439		.2439	.1981	.2134	.2286
23	.2439	.1981	2.332	.2439	.2134	.2134	.2134
24	.2439	.2286	.2134	2.3015	2.5301	.2134	.1981
Max	2.713	2.5758	2.332	2.4844	2.5301	.6554	.9297
Min	.1524	.1372	.1219	.1524	.1219	.1372	.1219
Avg	.9692	.9513	.2995	1.2873	1.1379	.3201	.3830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 204 / 11 KV RAJURA Feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2944	1.6129	.0995	.0983	.0983	.3315	.1147
2	1.3435	1.5813	.0829	.0983	.0983	.2984	.1147
3	1.4091	1.5813	.0663	.0983	.0983	.2818	.1147
4	1.5684	1.5497	.0497	.0819	.0983	.2652	.1311
5	1.6004	1.5181	.0829	.0819	.0983	.2486	.1311
6	1.6804	1.4548	.0995	.0819	.0983	.2294	.1311
7	1.7284	1.8404	.0663	.0819	.0819	.2652	.1311
8	1.8679		.0829	.0819	.0983		.1475
9		2.1125	.0829	.0678	.0819		.1311
10		.096	1.989	2.1792			.0655
11	.0312	.0497	2.0972	2.2405	.8619		.0486
12		.0663	2.4691		.9614		.0492
13	.0469	.0497	2.3266	2.2405	.9779	.0328	.0486
14	.0469	.0497	2.1464	1.2163	.9614	.0328	.0492
15	.0469	.0663	1.278	2.1125	.9116	.0328	.0492
16		.0829	1.278	2.13	.8619	.0328	.0492
17	.0625	.0497	2.0317	2.2283	.8288	.0328	
18	.0781	.0663	.0328		.0663	.0328	.0819
19	.0937	.0497	.0983	1.6057	.0995	.0819	.0983
20	.1094	.3315		.0655	.1326	.0819	.0983
21	.1107	.0497		.0983	.0995	.0819	.0983
22	.1107	.0497		.1147	.0829	.0819	.0983
23	.0937	.0995	.0983	.1147	.0829	.0983	.0983
24	1.2616	1.6129	.0995	.1017	1.0322	.4144	.1147
Max	1.8679	2.1125	2.4691	2.2405	1.0322	.4144	.1475
Min	.0312	.0497	.0328	.0655	.0663	.0328	.0486
Avg	.7292	.6965	.7932	.7827	.3832	.1556	.0954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 201 / 11 KV BORDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6908	.6722	1.2498	1.4632		.6722	
2	.6908	.6722	1.2651	1.4632		.6722	
3	.6722	.6722	1.2498	1.4632		.5975	
4	.6722	.6722	1.2498	1.4632		.5975	
5	.6722	.6348	1.4022	1.4632		.5975	
6	.5601	.6348	1.4373	1.3717		.4481	
7	.5228	.5975	1.4373	1.3717		.4481	
8	.4481	.5601	1.4373	1.3717		.3734	
9		.4481	1.4373	1.5242		.3734	
10		1.5813	.4108			.6249	
11	1.5242		.3734			.4572	.3239
12	1.4998	1.656	.3734	.3734	1.4723		.3277
13	1.5466	1.656	.4481	.4481	.9922	.4214	.3277
14	1.6248	1.656	.4481	.4481	.9922		.3277
15	1.6446	1.5623	.4481	.4481	.9922		.3277
16	1.6604	1.5623	.4108	.4481	.3734	.3612	.3277
17	1.6762	1.5623	.3734		.3734	.3612	.3277
18	.4481	.7468	.3921		.3734	.415	.3734
19	.5228	.7468	.5228	.5975	.5975	.4481	.5975
20	.6348	.7842	.6722		.7468	.5228	.5975
21	.6722	.7842	.6722		.7468	.5601	.5975
22	.7468	.7842	.6722			.5975	.5975
23	.7468	.7468	.6722			.5975	.5975
24	.6908	.6722	1.2498	1.4632		.7468	
Max	1.6762	1.656	1.4373	1.5242	1.4723	.7468	.5975
Min	.4481	.4481	.3734	.3734	.3734	.3612	.3239
Avg	.9349	.9594	.8461	1.0739	.7660	.5187	.4347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 202 / 11 KV RAMAPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1307	1.8747	1.5242	1.9204	.112	
2	.1334	.1307	1.8747	1.829	1.9204	.1143	
3	.1334	.1307	1.8747	1.9814	1.9204		
4	.1334	.112	1.829	2.0424	1.9204		
5	.1334	.112	2.3434	1.9814	1.9204		
6	.1143	.112	2.2862	2.1338	1.9204		
7	.0762	.0747	2.2862	2.2862	1.7604		
8	.0572	.0747	2.3434	2.3167	1.6004		
9		.056	2.3434	2.2862			
10		1.3443	.0373				
11	2.4387		.056		.0572		.1715
12	2.3777	2.5301	.0373	.0572	.0572	.1372	.2
13	2.4996	2.5301	.056	.0572	.0572	.2134	.2225
14	2.5617	2.4996	.056	.0572	.0572		.2256
15	2.5934		.056		.0572		.2256
16	2.625	2.3434	.056		.0572	.176	.2439
17	2.6558	2.3434	.056		.0572	.1486	.2439
18	.0747	.112	.0572		.0572	.0572	.0572
19	.0934	.112	.1143	.0762	.1143	.0953	.112
20	.112	.112	.1334	.112	.1494	.0953	.1494
21	.1494	.1307		.1494	.1494	.1143	.1494
22	.168	.1494		.1494		.1524	.1494
23	.1494	.1494	.1524			.1524	.1494
24	.1334	.1307	1.8747	1.829	1.9204	.1494	
Max	2.6558	2.5301	2.3434	2.3167	1.9204	.2134	.2439
Min	.0572	.056	.0373	.0572	.0572	.0572	.0572
Avg	.8885	.7009	.9908	1.2276	.8837	.1321	.1769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 203 / 11 KV POPATKHED

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9362	.8573	.8573	.8573	.8764	
2	.8573	.8916	.8669	.8573	.8573	.7011	
3	.8573	.9465	.8669	.8573	.8573	.7011	
4	.8573	.9015	.8573	.8916	.8573	.7011	
5	.8573	.8669	.7628	.9259	.8573	.7011	
6	.823	.823	.7628	.9259	.8573	.7011	
7	.823	.7975	.7712	.9602	.8573	.631	
8	.8573	.8413	.7811	1.0029	.8573	.631	
9		.9114	.8573	1.0136		.5144	
10		.9709	.7202			.5144	
11	.8916		.7202		.7545	.5144	.6379
12	.8573	.8916	.6859	.8573	.7545	.5487	.5959
13	.9015	.8916	.823	.8573	.6859	.583	.5609
14	.9114	.8916	.8573	.8573	.6859		.5609
15	.9568	.8573		.8573	.6859		.5609
16	.8916	.8669		.8573	.6859	.5144	.5609
17	.9465	.8573			.6859	.4801	.5609
18	.9709	.8669	.8573		.6859	.6241	.1372
19	.9602	.8764	.9015	1.0288	.7888	.6661	.7011
20	.964	.8669		1.0288	.7888	.7164	.7362
21	1.0056	1.0517		1.0288	.7888	.7602	.7362
22	1.0631	1.0402		1.0288		.8048	.7362
23	1.0056	.8669	1.0288			.7682	.7362
24	.8573	.9259	.8573	.8573	.8573	.8764	
Max	1.0631	1.0517	1.0288	1.0288	.8573	.8764	.7362
Min	.823	.7975	.6859	.8573	.6859	.4801	.1372
Avg	.9079	.8973	.8242	.9237	.7853	.6604	.6016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 204 / 11 KV MOHADA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.3579				.6249
2	2.7435	2.3405				.6249
3	2.7435	2.4966				.6249
4	2.7435	2.5377				.6249
5	2.8121	3.086				.3125
6	3.0864	3.2442				.3125
7	3.2236	3.3036				.3125
8	3.3093	3.4979				.3125
9	3.4294	3.5208				.3277
10			3.3836			
11			3.658		.6706	
12			3.9171	4.3583	.6706	
13			3.8104	4.2764	1.3413	
14			3.597	3.4408	1.3413	
15				3.4408	1.3077	
16				3.4408	1.291	
17					1.291	
24	2.6749	2.3405				.7449
Max	3.4294	3.5208	3.9171	4.3583	1.3413	.7449
Min	2.6749	2.3405	3.3836	3.4408	.6706	.3125
Avg	2.9510	2.8726	3.6732	3.7914	1.1305	.4822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 205 / water supply express
Feeder KV- 11 / OUTGOING

Only one consumer of WW with HT-IV

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0185		
2		.0189			.0185		
3				.0187	.0185		
4				.0187			
5	.0187	.0189		.0187	.0185		
6	.0187			.0187	.0185		.0187
7	.0187			.0187			.0187
8	.0187			.0187			.0187
9				.0187			
11	.0187				.0185	.0187	
12		.0189			.0185	.0187	
13		.0189	.0187		.0366	.0187	
14	.0189	.0189	.0187	.0185	.0366		
15	.0189	.0187		.0185	.0366		
16	.0189	.0189		.0185			
17	.0189	.0189					
18	.0189				.0183		
19	.0189				.0183		
20	.0189				.0183		
21	.0189						
22	.0189						
23	.0189						
Max	.0189	.0189	.0187	.0187	.0366	.0187	.0187
Min	.0187	.0187	.0187	.0185	.0183	.0187	.0187
Avg	.0188	.0189	.0187	.0186	.0226	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 201 / 11 KV RUIKHED

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4656	1.6644	1.8564	1.7284	.4481	.3772
2	.5281	.4656	1.6804	1.8564	1.7284	.4481	.3772
3	.4904	.4161	1.6644	1.9109	1.7284	.415	.3395
4	.4904	.4298	1.6804	1.7604	1.4723	.4108	.3395
5	.5281	.4298	1.6804	1.6324	1.4723	.4108	.3772
6	.5281	.4298	1.6804	1.6964	1.4723	.4108	.3772
7	.3395	.4481	1.7604	1.8244	1.4723	.3734	.3772
8	.2263		1.8564	1.9204		.3395	.3395
9	.2641	.4108	1.8564	1.9524		.3361	.3018
10	1.9204	2.0165	.2641	.2507		.3563	.3201
11	1.9204	2.1125	.2641	.2507	.2241		.2865
12	1.9204	2.1125	.2641	.2241	.2241		.2865
13	1.9204	2.0805	.2641	.2241		.2915	.3224
14	2.1445	2.0485	.2641	.2241	.2614	.2561	.3224
15	2.1445	2.0805	.3018	.2865	.2614	.2915	.3582
16	2.1445	2.0805	.3018	.2865	.2241	.2591	.3582
17	2.1445	2.2085	.2641	.1791	.1886	.2881	.3582
18	2.1445	.2641	.3018	.1791	.2614	.3395	.16
19	.192	.3395	.3395	.4298	.3361	.3772	.2561
20	.5014	.4527	.4904	.4298	.415	.415	.3521
21	.5014	.5228	.4904	.4298	.4527	.415	.3521
22	.4656	.5281	.4904	.4298	.4715	.415	.3582
23	.4656	.4904	.4904	.4298	.4527	.415	.3582
24	.4904	.4656	1.6964	1.8244	1.7284	.4527	.3772
Max	2.1445	2.2085	1.8564	1.9524	1.7284	.4527	.3772
Min	.192	.2641	.2641	.1791	.1886	.2561	.16
Avg	1.0377	1.0130	.9171	.9370	.8288	.3711	.3347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 203 / 11 KV VASTAPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6842	.4481	.5544	.5487	.4481	.8322	.3887
2	1.6644	.4481	.5175	.5487	.4481		.3887
3	1.7166	.4481	.5175	.5487	.4481		.3563
4	1.6964	.3841	.5175	.543	.3201		.3521
5	1.7604	.3841	.5175	.5487	.3201		.3563
6	1.8244	.3841	.4805	.439	.3201		.3563
7	2.1445	.3887	.4481	.3658	.3201		.3563
8	2.3205	1.7284	.3734	.3658			.3201
9	2.3685	.3887	.2957	.3292			.3239
10	.2865		2.2405	2.8807			.3658
11	.2865	.3361	2.4966	2.7846		.2926	.2865
12	.2865	.2957	2.5926	2.7846	.9602	.2926	.2865
13	.3224	.2957	2.6566	2.7846		.2926	.2865
14	.3224	.2957	2.7206	2.7846	1.6004	.2561	.2865
15	.3224	.3326	2.7526	2.7846	1.4403	.2896	.3224
16		.3326	2.7846		1.4723	.2926	.3224
17	.4656	.3696	2.8807	2.6886	1.2163	.3292	.3224
18	.4656	.3696	.3658	2.6886	1.1523	.3658	.3224
19	.4656	2.0805	.439	.5731	1.0402	.439	.4298
20	.4656	2.0805	.6516	.5731	.5544	.5792	.5373
21	.4656	.5914	.6219	.4481	.6219	.5487	.5373
22	.4656	.6283	.5853	.5014	.5914	.5658	.4801
23	.5014	.5853	.6036	.4481	.5544	.5281	.5373
24	1.6324	.4481	.5601	.5487	.5014	.8962	.3887
Max	2.3685	2.0805	2.8807	2.8807	1.6004	.8962	.5373
Min	.2865	.2957	.2957	.3292	.3201	.2561	.2865
Avg	1.0406	.6106	1.2156	1.2831	.7542	.4534	.3713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 204 / 11 KV Khirkund new

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2507	1.0402	.7682	.9602	.2241	.1886
2	.3018	.2241	1.0562	.7773		.2241	.1886
3	.3018	.2241	1.0402	.8002		.1867	.1698
4	.2829	.2401	1.0242	.8002		.1867	.1698
5	.2829	.2401	1.0402	.8642		.1867	.1886
6	.2829	.2401	1.0883	.9602		.1867	.1886
7	.2641	.2801	1.1843	1.0242	.9442	.1867	.1886
8	.2452	.2801	1.2803	.9922	.8322	.1494	.1886
9	.1698	.2801	1.2483	1.0242	.8322		.1698
10	1.3763	1.2963	.1886		.6882	.2241	.1134
11	1.4864	1.3443	.1886		.0895	.16	.2241
12	1.3283	1.4403	.1886	.2149	.0934	.1619	.2241
13	1.3283	1.4723	.1886	.192		.1781	.112
14	1.2163	1.4403		.2149	.112	.1781	.112
15	1.2163	1.4403		.2149	.0934	.1781	.16
16	1.2163	1.4723		.2149	.112	.1781	.16
17	1.2163	1.4403		.2149	.0934	.1619	.16
18	.2401	.2263		.192	.2241	.1886	.176
19	.2401	.2614		.3045	.2829	.1886	.2241
20	.2721	.3018	.2641	.3045	.2987	.2075	.2401
21	.3045	.2987	.2829	.2865	.2801	.2075	.2401
22	.2507	.3018	.2641	.2865	.2829	.2075	.2401
23	.2507	.3018	.2829	.2865	.2641	.1886	.208
24	.3018	.2241	1.0402	.7522	.9602	.2641	.1886
Max	1.4864	1.4723	1.2803	1.0242	.9602	.2641	.2401
Min	.1698	.2241	.1886	.192	.0895	.1494	.112
Avg	.6116	.6467	.7162	.5314	.4135	.1915	.1843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024034 / 33 kv SAWARA

Feeder No / Name : 201 / 201 -11 kv sawara gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.3214	1.4803	1.1203		1.1561	.9469
2	1.6461	1.3409	1.4861	1.1088		1.1279	.9335
3	1.6118	1.3146	1.438	1.0974		1.1431	1.0288
4	1.4899	1.3146	1.4098	1.086		1.1145	1.0717
5	1.4413	1.3203	1.3032	1.0745			1.0574
6	1.2346	1.2536	1.2407	.9717			1.0717
7	1.1736	1.2489	1.2071	.9259			.9335
8	1.3108	1.2437	1.2803	1.0174			.9335
9	1.3413	1.2826	1.3336	1.4632			.8269
10	.9442	1.1096	1.3003				
11	.8642	.6316	1.3169	.9259			1.0745
12	.9602	1.2382	1.2483	.6188	.8987		.9671
13	.9665		1.4003	1.7164	.8642		.929
14	.9882			1.7878	.8745		.8939
15	1.0317	1.3146	1.5242	1.7661	.8785		.9922
16	1.0454	1.2803	1.4937	1.0608	.7674	.6401	
17	.9667	1.2489	1.2955	.8848	.7573	.4191	
18	.8322	1.0425	1.0517	.9614	.7021	.6173	1.1283
19	1.0719	1.3746	1.5851	1.0056	1.1191	1.0574	1.2851
20	1.5485	1.6194	1.8442	1.5485	1.2178	1.2955	1.6644
21	1.5592	1.4883	1.829	1.5718	1.166	1.1736	1.7013
22	1.4935	1.4365	1.7375	1.446	1.1869	1.1888	1.6278
23	1.4552	1.387	1.6613	1.4169	1.1203	1.0574	1.491
24	1.6975	1.3603	1.4003	1.1317		1.1523	1.0288
Max	1.6975	1.6194	1.8442	1.7878	1.2178	1.2955	1.7013
Min	.8322	.6316	1.0517	.6188	.7021	.4191	.8269
Avg	1.2648	1.2806	1.4290	1.2047	.9627	1.0110	1.1232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024034 / 33 kv SAWARA

Feeder No / Name : 202 / 11 kv sawara ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3676	1.4403		
2			1.3306	1.4129		
3			1.3535	1.3992		
4			1.3169	1.3717		
5			1.3676	1.3443		
6			1.3676	1.5242		
7			1.4815	1.5699		
8			1.579	1.7223		
9			1.5775	1.7528		
10	2.1148	2.4996				
11	2.1853	2.4684				.7093
12	2.0584	2.2445			.1429	.8288
13	2.0576	2.3034			.2096	.8543
14	2.0561	2.2733			.2382	.9065
15	2.0706	2.1574				.9482
16	2.1712	2.2588			.3334	
17	2.0538	1.9115			.3429	
24			1.3306	1.454		
Max	2.1853	2.4996	1.579	1.7528	.3429	.9482
Min	2.0538	1.9115	1.3169	1.3443	.1429	.7093
Avg	2.0960	2.2646	1.4072	1.4992	.2534	.8494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 201 / Pimpri(kh)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4513	1.6695		1.6004	.3969	.3547
2		.4518	1.6347		1.6004	.3784	.3555
3		.4334	1.6173		1.6004	.3788	.3378
4		.4338	1.5833		1.6004	.3412	.3354
5		.4154	1.5653		1.6004	.3416	.3006
6		.378	1.5216		1.5752	.3036	.2815
7		.2654	1.6152		1.5752	.2469	.2245
8		.2282	1.6032		1.5257	.2282	.2245
9	.1515	.1877	1.9669	1.8991		.1867	
10	1.807	1.782	.2186	.1886		.4081	
11	1.9364	1.9454	.1833	.1886		.3475	
12	1.9083	1.8898	.1833	.2263	.189	.2623	
13	1.8804	1.8844	.2108	.2241	.1886	.2235	
14	1.8719	1.8671	.2151	.2614	.2266	.1452	
15	1.85	1.8576	.2204	.2614	.2266	.1496	
16	1.81	1.8147	.2245	.2241	.2257	.1505	
17	1.7604	1.749	.2202	.2241	.1879	.1454	
18	.2266	.3753	.2601	.3361	.3018	.2804	.2263
19	.2459	.462	.2993	.3734	.3409	.3361	.3584
20	.3965	.4845	.3749	.4108	.3795	.3799	.3772
21	.4527	.4889		.4527	.417	.3753	.3772
22	.472	.4879		.4527	.417	.3738	.3772
23	.4527	.4696		.4715	.3985	.3953	.3772
24		.4504	1.7198		1.6156	.3961	.3761
Max	1.9364	1.9454	1.9669	1.8991	1.6156	.4081	.3772
Min	.1515	.1877	.1833	.1886	.1879	.1452	.2245
Avg	1.1482	.8856	.9099	.4130	.8473	.2988	.3256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 202 / Shahapur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1373	.1504		.1509	.8173	.1452
2		1.1295	.1509		.1509	.8208	.1457
3		1.1065	.1501		.132	.7978	.1457
4		1.0957	.1504		.132	.7628	.1189
5		1.1309	.1486		.132	.75	.1152
6		1.1443	.1314		.132	.6685	.1158
7		1.1665	.1118		.132	.5624	.1192
8		1.2419	.093		.1132	.4401	.1341
9	1.2529	1.2534	.0751	.0566		.3935	
10	.0756	.0747	1.506	1.6118		.0747	
11	.0758	.0564	1.6722	1.6297		.0563	
12	.0949	.0937	1.6581	1.6297	1.2179	.0563	
13	.0951	.0932	1.7247	1.4899	1.1873	.0564	
14	.0949	.0948	1.6566	1.4899	1.1553	.0561	
15	.0761	.0939	1.7394	1.4373	1.1164	.0559	
16	.0761	.0938	1.7229	1.4175	1.09	.0561	
17	.0761	.0932	1.7833	1.4148	1.0642	.0564	
18	.0946	.1127	.092	.112	.0756	.0935	.0943
19	.1139	.131	.0935	.132	.1136	.1316	.1132
20	.1517	.1503	.1658	.132	.1521	.1501	.1509
21	.171	.1706		.1509	.1708	.1494	.1698
22	.1696	.1677		.1698	.171	.1478	.1698
23	.1509	.1677		.1698	.1521	.1489	.1509
24		1.1342	.1494		.1698	.8185	.1448
Max	1.2529	1.2534	1.7833	1.6297	1.2179	.8208	.1698
Min	.0756	.0564	.0751	.0566	.0756	.0559	.0943
Avg	.1846	.5472	.7203	.8696	.4243	.3384	.1356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 203 / Shivpur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4873			.1783	.0437
2	.4332	.4829			.1791	.0434
3	.4223	.4646			.1667	.0449
4	.4032	.4401			.1642	.0449
5	.3806	.4372			.1607	.0449
6	.412	.4725			.1457	.0432
7	.4704	.5188			.1429	.0436
8	.4727	.4589			.0758	.0446
9	.4713	.4664			.0897	
10			.6516			
11			.6516			
12			.6697	.4719		
13			.5735	.4407		
14			.4999	.4124		
15			.4268	.3553		
16			.4515	.3393		
17			.4548	.3661		
24		.4743			.1786	.0598
Max	.4727	.5188	.6697	.4719	.1791	.0598
Min	.3806	.4372	.4268	.3393	.0758	.0432
Avg	.4375	.4703	.5474	.3976	.1482	.0459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 201 / M.I.D.C Lohari road
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0613	.08	.1867	.08	.1686	.176	.184
2	.0533	.0829	.1814	.0774	.1743	.1627	.136
3	.0587	.0714	.1734	.0854	.18	.1814	.1414
4	.064	.0747	.1707	.088	.1829	.2058	.1627
5	.0667	.08	.16	.0743	.1915	.2201	.1414
6	.072	.088	.1547	.0817	.1787	.1972	.1387
7	.0267	.08	.1147	.0793	.1787	.1947	.1387
8	.0396	.0693	.168	.1164	.1814	.1467	.1254
9	.25	.2515	.2134		.2343		.1867
10	.3326	.2883	.2591		.3041		.3544
11	.3292	.3155	.25	.2675	.3439	.3658	.3582
12	.3439	.3361	.2225	.2679	.3772	.3801	.362
13	.3439	.3584	.2378	.2572	.3772	.3658	.3582
14	.3658	.3109	.2439		.333	.3696	.3841
15	.3155	.2494	.25		.3772	.362	.3721
16	.3155	.2846	.2408	.3077	.3547	.333	.3582
17	.333	.2812	.2343	.3189	.3189	.3294	.3681
18	.2743	.2591	.2229	.3475	.3467	.3258	.3881
19	.3547	.2656	.2172	.3921	.3239	.3052	.415
20	.2606	.2818	.1738	.3052	.3521	.2641	.3734
21	.1543	.128	.1067	.253	.2881	.2103	.2317
22	.0854	.1574	.096	.2591	.1658	.1515	.2317
23	.0667	.1574	.088	.2343	.14	.2454	.2469
24	.0507	.072	.1947	.0747	.16	.1707	.2187
Max	.3658	.3584	.2591	.3921	.3772	.3801	.415
Min	.0267	.0693	.088	.0743	.14	.1467	.1254
Avg	.1924	.1926	.1900	.1984	.2597	.2574	.2657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 202 / Hiwarkhed Road industry

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3498	.1389	.16	.1974	.1768	.3517
2	.3144	.3433	.144	.1654	.2027	.1934	.3549
3	.3458	.3563	.144	.1494	.2187	.1989	.3022
4	.3521	.3647	.1437	.1602	.2212	.176	.2526
5	.3292	.3521	.1486	.1823	.2109	.1814	.2031
6	.3231	.3772	.1387	.16	.2187	.1654	.213
7	.3304	.2058	.1067	.1492	.2187	.176	.213
8	.3269	.4405	.08	.112	.2048	.2321	.1932
9	.7545	.8764	.08		.7545		
10	1.1273	1.2382	.0686		1.0242		
11	1.0829	1.2136	.0686	.8145	1.1016	.8413	.8688
12	1.0534	1.0719	.0663	.8417	1.0562	.9492	.6935
13	.9922		.0686	.6952	.7316	.8764	.7202
14	.985	.9795	.0663		.9335	.78	.7362
15	1.1523	.9979	.0743		.8962	.8764	.8686
16	1.1458	.9694	.08	.8686	.8676	.985	.7762
17	1.1273	.7545	.0743	.8131	.8488	.9492	.8402
18	.9774	.6173	.0743	.7499	.8316	.8954	.7164
19	.7087	.6173	.0884	.5792	.9055	.7282	.5895
20	.6722	.2614	.1014	.3788	.7373	.5376	.4464
21	.4016	.192	.1547	.2526	.578	.3361	.2801
22	.4001	.192	.176	.2477	.3258	.2229	.2686
23	.4001	.1654	.176	.2378	.2481	.4755	.2743
24	.317	.3239	.1337	.144	.1852	.1879	.4359
Max	1.1523	1.2382	.176	.8686	1.1016	.985	.8688
Min	.3144	.1654	.0663	.112	.1852	.1654	.1932
Avg	.6645	.5765	.1082	.3931	.5716	.5064	.4818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 203 / 11KV Water supply

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.168	.1494	.168	.1867	.1715	.1848
2	.1595	.1698	.1494	.1867	.1663	.1715	.1829
3	.1612	.168	.1494	.1886	.1646	.1698	.1734
4	.1629	.1886	.1494	.1886	.1646	.1509	.1772
5	.1612	.1886	.1494	.1867	.1829	.1509	.1829
6	.0991	.1886	.1663	.1886	.1829	.1698	.2012
7	.125	.1886	.1886	.1886	.1646	.1698	.2075
8	.1235	.1886	.1886	.1886	.1663	.1698	.2075
9	.2241	.2241	.1886		.2241		.2286
10	.2858	.2829	.1372		.2858		.3429
11	.3206	.2801	.2075	.1867	.2241	.2829	.3206
12	.3547	.2614	.2286	.1886	.3018	.3361	.3018
13	.3584	.2452	.2075	.2452	.2667	.2801	.2801
14	.3239	.3048	.1867		.2427	.2641	.2452
15	.2858	.2641	.1698		.2452	.2987	.2286
16	.2096	.2452	.1905	.2263	.3174	.2427	.2452
17	.2427	.2096	.1357	.1478	.2427	.2427	.2801
18	.2241	.1886	.1886	.1698	.1595	.1698	.2452
19	.156	.1867	.1905	.1905	.2286	.1698	.2286
20	.125	.1829	.1886	.1905	.1905	.1886	.2241
21	.1886	.1663	.1867	.1698	.1905	.1698	.1905
22	.1886	.1646	.1867	.1886	.1715	.1698	.1886
23	.1698	.168	.1663	.1886	.1715	.1886	
24	.1829	.168	.1494	.1663	.1886	.1698	.1829
Max	.3584	.3048	.2286	.2452	.3174	.3361	.3429
Min	.0991	.1646	.1357	.1478	.1595	.1509	.1734
Avg	.2090	.2080	.1750	.1872	.2096	.2044	.2283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 204 / 11KV Wadali-S

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4207	.439	.4207	.4024	.3658	.3475
2	.4024	.4207	.439	.4024	.4024	.3658	.3475
3	.3841	.4024	.439	.4024	.4024	.3475	.3475
4	.3841	.4024	.439	.4024	.4024	.3475	.3475
5	.4024	.4024	.4207	.4024	.3841	.3292	.3475
6	.4024	.3841	.439	.3658	.3658	.3658	.3292
7	.3109	.3658	.3658	.3292	.3658	.2926	.3292
8	.2743	.3475	.3109	.3292	.3292	.2926	.2587
9	.2743	.3292	.3292		.3292		
10	.2743	.2926	.3109		.2926		
11	.2743	.2926	.2926	.2743	.2378	.1829	.2402
12	.2561	.2561	.2561	.2561	.2561	.2012	.2033
13	.2561	.2012	.2743	.2926	.2561	.2012	.2012
14	.2743	.3292	.2926		.2378	.1829	.1829
15	.3109	.3109	.2926		.2378	.1829	.2195
16	.2926	.2926	.2561	.2195	.2012	.2012	.1848
17	.2743	.2926	.2561	.2012	.2378	.1829	.2075
18	.2743	.2378	.2561	.2195	.2743	.2195	.2218
19	.2926	.3475	.2926	.2561	.3841	.3292	.2772
20	.4207	.439	.4024	.3475	.3841	.3475	.3881
21	.4207	.439	.4024	.3658	.4024	.3475	.3696
22	.439	.439	.439	.4207	.4024	.3292	.3696
23	.439	.439	.4207	.439	.3841	.3475	.3696
24	.4024	.4207	.439	.4207	.4207	.3658	.3475
Max	.439	.439	.439	.439	.4207	.3658	.3881
Min	.2561	.2012	.2561	.2012	.2012	.1829	.1829
Avg	.3391	.3544	.3544	.3384	.3330	.2876	.2926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 205 / 11KV Mundgoan AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9633	.9633				.2397	.0177
2	.9482	.9633				.2462	.0181
3	.9362	.9214				.2256	.0181
4	.9095	.9332				.2397	.0181
5	.9362	.9362				.1882	.0181
6	.8802	.8916					.0181
7	.9877	.9633					.0181
8	.9659	1.1584					.0181
9	1.0105	1.0837					
10			1.142		.192		
11			1.1888	1.2186	.2187		
12			1.1888	1.1584	.2343		
13			1.1888	1.1431	.4214		
14			1.1873		.6706		
15			1.0974		.6874		
16			1.0802	1.0536	.5182		
17			1.1279	1.0105	.4054		
23						.0173	
24	.9145	1.0669				.2538	.0177
Max	1.0105	1.1584	1.1888	1.2186	.6874	.2538	.0181
Min	.8802	.8916	1.0802	1.0105	.192	.0173	.0177
Avg	.9452	.9881	1.1502	1.1168	.4185	.2015	.0180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 201 / 11 KV GADEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	1.387	.7209	.8002	.8002	.6935	.5304
2	1.3565	1.3717	.6882	.7773	.8097	.5548	.5304
3	1.4529	1.3375	.6802	.7773	.8097	.4854	.4973
4	1.3435	1.3226	.6325	.7449	.8097	.4854	.4915
5	1.4403	1.2887	.6401	.6802	.8097	.4801	.4588
6	1.4746	1.2597	.5864	.6478	.8002	.4801	.4858
7	1.3413	1.3077	.4877	.4744	.5693	.4801	.4534
8	1.2407	1.1469	.3963	.3086	.5182	.3391	.4481
9	1.2125	1.2811	.2743	.2778	.5182	.3467	.5624
10	.3052	.3605	1.4083	1.4746			.2622
11	.2915	.4096	1.406	1.3717			.2652
12		.3887	1.3763		.9755	.5312	.2949
13	.4161	.421	1.3279		.9145	.5182	
14	.4049	.4858			.9503	.5792	.3391
15		.4915	1.2742		.9724		.3277
16		.4588	1.3413	1.3565	.8951	.6097	.3018
17		.4588	1.6289		1.004	.6882	.3429
18		.3982	.543	.4801	.6447	.4115	.394
19	.6447	.4755	.7392	.5914	.7392	.5014	.439
20	.7316	.7392	.924	.5914	.7468	.5792	.5121
21	.7164	.7762			.7095	.543	.5914
22	.9145	.8063		.8962	.7468	.5068	.5544
23	.8413	.7377	.7293	.9145	.7392	.6805	.7023
24	1.491	1.387	.7293	.8288	.8288	.6783	.5304
Max	1.491	1.387	1.6289	1.4746	1.004	.6935	.7023
Min	.2915	.3605	.2743	.2778	.5182	.3391	.2622
Avg	1.0044	.8541	.8826	.7774	.7869	.5320	.4485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 202 / 11 KV BELKHED

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4842	1.4217	.6554	.6478	.8097	.8669	
2	1.406	1.406	.6226	.6478	.8097	.8322	
3	1.4175	1.3717	.6154	.6478	.8097	.6935	
4	1.3108	1.3226	.5693	.6478	.8097	.6935	
5	1.3375	1.2887	.6081	.6478	.8097	.5144	
6	1.3032	1.2266	.6173	.6478	.8002	.463	
7	1.166	1.2407	.5792	.6154	.759	.5144	
8	1.0513	1.1869	.5937	.5556	.7316	.5087	
9	.9831	1.0623	.5792	.5556	.7316	.3467	
10	.6783	.6882	1.5089				.0983
11	.7125	.7373	1.6385				.0995
12		.7125	1.7695			.9374	.0983
13	.6722	.7287	1.7814				
14	.6478	.6802	1.8442				.12
15	.7125	.7373	1.933		1.8564		.1638
16	.7202	.7373	1.933	1.9204	1.8442		.1677
17	.7537	.7373	2.1719	1.8442	1.6194		.1715
18			1.8099	1.5089	1.7193		
19			1.848	1.6095	1.6263		
20			2.0328	1.6461	1.6804		
21					1.8671		
22				1.7558	1.9044		
24	1.4403	1.387	.663	.663	.8288	.8478	
Max	1.4842	1.4217	2.1719	1.9204	1.9044	.9374	.1715
Min	.6478	.6802	.5693	.5556	.7316	.3467	.0983
Avg	1.0469	1.0374	1.2559	1.0351	1.2232	.6562	.1313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 203 / 11 KV TELHARA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.6057	1.5223	1.6194	1.7337	1.0774
2			1.5729	1.4575	1.6194	1.5604	1.094
3			1.5223	1.3765	1.6194	1.2136	1.065
4			1.4232	1.3279	1.6194	1.0749	1.065
5			1.3763	1.2955	1.6194	1.0631	1.1142
6			1.358	1.2631	1.6004	1.0288	1.1012
7			1.3108	1.1069	1.2334	1.0288	1.0526
8			1.2811	.9877	1.2193	1.1022	.9602
9			1.1888	.9686	1.2193	1.0402	.9061
10	1.6278	1.6385		1.6385			.9282
11	1.7004	1.7368		1.6156			.9945
12	1.7166	1.7814			1.7985		.9831
13	1.8404	1.8884			1.7185		
14	1.8623	1.8138			1.8442	1.0974	1.0288
15	1.8461	1.9662					.9496
16	1.9204	1.9334				1.1279	.9724
17	2.0317	1.9662				1.1469	1.0288
18	1.5074	1.2071				1.3717	1.3611
19	1.4327	1.2548				1.5402	1.5364
20	1.6827	1.6461				1.6289	
21	1.6118	1.7193				1.5565	1.8111
22	1.7193	1.6827				1.448	1.7741
23	1.5729	1.5261	1.5581	1.7558	1.848	1.3432	1.4415
24			1.6575	1.5546	1.6575	1.6956	1.1271
Max	2.0317	1.9662	1.6575	1.7558	1.848	1.7337	1.8111
Min	1.4327	1.2071	1.1888	.9686	1.2193	1.0288	.9061
Avg	1.7195	1.6972	1.4413	1.3747	1.5883	1.3054	1.1533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 204 / 11 KV MALEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6063	3.4675	.852			.823	.663
2	2.524	3.4637	.8192			.6859	.6962
3	2.4348	3.3951	.7811			.3772	.6882
4	2.2939	3.3913	.759			.3429	.6554
5	2.3472	3.3573	.7362			.3429	.6478
6	2.3061	3.2819	.7099			.3429	.6154
7	2.6791	3.2861	.6097			.3429	.6154
8	2.9508	3.2217	.5624			.5426	.6401
9	3.0476	3.2808	.4572		1.2193	.5201	.6874
10	.5087	.5735	3.6885	1.4091			.4973
11	.5506	.5571	3.5627	1.2803			.4588
12	.5601	.583	.5144		1.2193	.7865	.5898
13	.6401	.6401	.583		1.1584	.7316	
14	.7125	.6154	1.3108		1.2742		.6859
15	.7042	.6882	1.4083		2.652		.6783
16	.6722	.6478	1.3077	3.5208	2.6825		.6706
17	.6882	.6554		3.5208	2.4615	.7865	.6516
18	.8764	.6661		3.5947	2.4356	.6516	.7164
19	.8954	.7316		4.0238	2.7351	.6447	.8413
20	.9145	1.0242		3.658	2.9127	.7964	.9145
21	.8954	1.0719					.9979
22	.9877	1.0517		3.2922	2.9874	.6878	.961
23	.9511	.9835			1.1088	.788	.924
24	2.7435	3.4675	.9282			1.0174	.6962
Max	3.0476	3.4675	3.6885	4.0238	2.9874	1.0174	.9979
Min	.5087	.5571	.4572	1.2803	1.1088	.3429	.4588
Avg	1.5204	1.8376	1.1524	3.0375	2.0706	.6228	.7040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 205 / TUDGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3467	1.9334	1.7814	1.7814	1.0402	.2652
2	.3429	.3086	1.9334	1.7814	1.7814	1.0402	.2486
3	.3258	.3429	1.8122	1.7814	1.7814	1.0402	.2486
4	.2984	.3052	1.8343	1.7814	1.7814	.8573	.2622
5	.3086	.2713	1.8884	1.749	1.6004	.0686	.2294
6	.3086	.2321	1.829	1.4575	1.4403	.0686	.2294
7	.1677	.2012	1.7985	1.7166	1.5023	.0343	.1619
8	.1372	.2035	1.7497	1.781	1.3108	.0339	.096
9	.1311	.1562	1.7375	1.7185	1.3108	.3467	.0937
10	1.8991	1.7368	.1677	.1311			.2984
11	1.8785	2.0481	.1372	.1219			.2984
12	1.8623	1.9109	.1311		.0914	.0937	
13	1.6804	1.8623	.1943		.1174	.0914	
14	1.6842	1.7814			.1341	.0762	.3086
15	1.7814	1.9334	.2012		.0995		.3277
16	1.8244	1.8842	.1677	.0686	.1174	.061	.3391
17	1.9662	1.9662	.2534	.1029	.1296	.0983	
18	.1753	.2195	.181	.1017	.2149	.1029	
19	.1791	.2195	.2587	.1848	.3326	.1433	
20	.2926	.3658	.3326	.3292	.1296	.3258	.3658
21	.3761	.3658			.3734	.2896	.3696
22	.3658	.3856		.4481	.4108	.3258	.3326
23	.3658	.373	.3315	.3658	.3696	.2865	.3326
24	.3506	.3467	1.989	1.8233	1.7404	1.0174	.2652
Max	1.9662	2.0481	1.989	1.8233	1.7814	1.0402	.3696
Min	.1311	.1562	.1311	.0686	.0914	.0339	.0937
Avg	.7943	.8236	.9934	1.0119	.8432	.3544	.267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 201 / 11 KV HKD feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.3443	1.3817	1.3817	1.419	1.2136	1.0456
2	1.1145	1.307	1.3443	1.3443	1.2689	1.1576	1.0456
3	1.1145	1.2696	1.3443	1.3443	1.2689	1.1576	1.0269
4	1.1145	1.2696	1.307	1.4003	1.1984	1.1576	1.0269
5	1.2003	1.2696	1.307	1.4003	1.2346	1.1203	1.0269
6	1.2003	1.3443	1.307	1.4563	1.2174	1.1203	1.0269
7	.9717	.9335	1.2696	1.1576	1.2136	1.1203	1.0269
8	1.0269	1.0269	1.0829	1.0456	1.0269	1.1203	.9896
9	1.0456	1.0269	1.0456	1.0456	1.0456	.9335	.9335
10	.9335	1.0082	1.0288		1.0456		.7545
11		1.0456	.8907		.9808		.7545
12	1.0269	1.1203	.9945	1.0829	.9335		
13	1.1203	1.2136	.9602	1.1203	.8962	.7888	.7773
14	1.0829	1.2136	1.0288	1.1949	.9709	.7888	.7125
15		1.251	1.0974		.9431		.7125
16		1.1949	1.1145	1.0829	.9808	.8215	.7125
17	1.1203	1.1576	.9896	.9431	.9709	.8402	
18	1.1949	1.0082	.9709	1.0288	1.0562	.8402	.9335
19		1.1203	1.1203	1.1145	1.2136	1.0829	.8589
20	1.2696	1.3443	1.3443	1.4003	1.251	1.1506	1.1576
21	1.3443	1.419	1.4937	1.419	1.251	1.1576	1.2136
22	1.4563	1.4937	1.475	1.475	1.2696	1.1576	1.1203
23	1.419	1.3817	1.4937	1.4937	1.2136	1.1203	1.1389
24		1.3817	1.3817	1.4377	1.419	1.2136	1.0829
Max	1.4563	1.4937	1.4937	1.4937	1.419	1.2136	1.2136
Min	.9335	.9335	.8907	.9431	.8962	.7888	.7125
Avg	1.1511	1.2144	1.1989	1.2557	1.1370	1.0532	.9581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 202 / GORDHA FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0526	1.1869				.5935	.0339
2	.9717	1.1869				.5975	.0339
3	.9717	1.1022				.5087	.0339
4	.8907	1.1022					.0339
5	.8907	1.0513					.0339
6	.8907	1.0513					.0339
7	1.0174	1.1191					.0339
8	1.153	1.1869					.0678
9	1.1022	1.1869					.0328
10			1.2955	1.3565			
11			1.2955		1.0174		
12			1.4251	1.6956	.9945	.1029	
13			1.4899	1.7804	1.0288	.2401	
14			1.5384	1.5769	.8573	.2401	
15			1.5384		.8951		
16			1.5384	1.7295	.9156	.2058	
17			1.6108	1.6194	.8916	.1658	
18			1.6108				
19			1.5261				
24		1.1869				.5935	.0339
Max	1.153	1.1869	1.6108	1.7804	1.0288	.5975	.0678
Min	.8907	1.0513	1.2955	1.3565	.8573	.1029	.0328
Avg	.9934	1.1361	1.4869	1.6264	.9429	.3609	.0372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 203 / SAUNDALA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0328	1.7204	1.8023	1.8351	.0328	.0328
2	.0324	.0328	1.7204	1.8023	1.8351	.0339	.0328
3	.0324	.0328	1.6385	1.8023	1.8138	.0328	.0328
4	.0324	.0328	1.6385	1.6385	1.6385		.0328
5	.0324	.0328	1.6385	1.6385	1.587		.0328
6	.0324	.0328	1.4746	1.5074	1.5061		.0328
7	.0324	.0328	1.7368	1.7859	1.4746		.0328
8	.0328	.0328	1.7368	1.7465	1.3108		.0328
9	.0328	.0328	1.8023	1.7695	1.3599		.0328
10	1.8023	2.0481	.0324	.0328	.0373		.1296
11	1.9662	2.2611	.0324		.0373		.1296
12	1.9662	2.1628	.0324	.0328	.0373	.3429	.1943
13	1.8023	2.0481	.0324	.0328	.0362	.2743	.1943
14	1.9662	1.9662	.0324	.0328	.0373	.2743	.1943
15		2.0481	.0324		.0373		.1943
16		1.8842	.0324	.0328	.0373	.2987	.1619
17	2.0481	1.8023	.0328	.0324	.0373	.2458	
18	2.0481	.0328	.0328		.0373	.0328	.0373
19		.0328	.0328	.0324	.0373	.0328	.0373
20	.0328	.0328	.0328	.0328	.0373	.0373	.0373
21	.0328	.0328	.0328	.0339	.0328	.0328	.0328
22	.0328	.0328	.0328	.0328	.0339	.0328	.0328
23	.0328	.0328	.0328	.0328	.0328	.0328	.0328
24		.0328	1.7204	1.8023	1.8351	.0328	.0328
Max	2.0481	2.2611	1.8023	1.8023	1.8351	.3429	.1943
Min	.0324	.0328	.0324	.0324	.0328	.0328	.0328
Avg	.7012	.6977	.7202	.8408	.6960	.1180	.0755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 204 / Wari express

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.032	.032	.032	.032	.032	.032
2	.0324	.032	.032	.032	.0324	.032	.032
3	.0324	.032	.032	.032	.0324	.032	.032
4	.0324	.032	.032	.032	.0324	.032	.032
5	.0324	.032	.032	.032	.0324	.032	.032
6	.0324	.032	.032	.032	.0324	.032	.032
7	.0324	.032	.032	.032	.032	.032	.032
8	.032	.032	.032	.032	.032	.032	.032
9	.032	.032	.032	.032	.032	.032	.032
10	.032	.032	.0324	.032	.0267		.0324
11	.032	.032	.0324		.0267		.0324
12	.032	.032	.0324	.032		.0343	.0324
13	.032	.032	.0324	.032		.0324	
14	.032	.032	.0324	.032		.0324	.0324
15		.032	.0324				.0324
16		.032	.0324	.032		.0267	.0324
17	.032	.032	.032	.0324		.032	
18	.032	.032	.032	.0324		.032	.0267
19		.032	.032	.0324		.032	.0267
20	.032	.032	.032	.032	.0267	.0259	.0267
21	.032	.032	.032	.032	.032	.032	.032
22	.032	.032	.032	.032	.032	.032	.032
23	.032	.032	.032	.032	.032	.032	.032
24		.032	.032	.032	.032	.032	.032
Max	.0324	.032	.0324	.0324	.0324	.0343	.0324
Min	.032	.032	.032	.032	.0267	.0259	.0267
Avg	.0321	.032	.0321	.0321	.0311	.0316	.0314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 205 / DIWANZARI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1989	2.9835	2.4034	2.9007	.1658	.1658
2	.1619	.1989	2.8178	2.4034	2.8673	.1658	.1658
3	.0324	.1989	2.7206	2.4034	2.834		.1658
4	.1619	.0332	2.652	2.3205	2.834		.1658
5	.1619	.1989	2.652	2.3205	2.834		.1326
6	.1619	.1658	2.652	2.1548	2.332		.1326
7		.0995	2.8178	2.1548	2.4034		.116
8	.1619	.0829	2.9835	3.1493	2.4034		.0995
9	.116	.0663	2.9835	3.2322	2.3205		.0995
10	3.2322	3.6466	.0972	.0829	.0934		.2591
11	3.4476	3.6797	.0972		.0934		.2591
12	3.0001	3.4808	.0972	.0995	.0934		.2267
13	2.9835	3.315	.0972	.0995	.0934		.1943
14	2.9835	3.315		.116	.0934	.4858	.1943
15		3.3979	.0972		.0943		.1619
16		3.3979	.0972	.116	.0934	.4115	.1943
17	3.4808	3.2819	.0995	.1134	.112	.3647	
18	3.1493	.0663	.0995	.1134		.0995	.0943
19		.1326	.116	.1296	.1402	.0995	.1448
20	.1658	.1658	.1989	.1658	.2172	.1494	.1448
21	.1823	.1989	.1989	.1658	.1989	.1658	.1658
22	.1989	.1989	.1823	.1989	.1989	.1658	.1658
23	.1989	.1989	.1823		.1658	.1658	.1658
24		.1989	2.9835	2.4034	3.0167	.1658	.1658
Max	3.4808	3.6797	2.9835	3.2322	3.0167	.4858	.2591
Min	.0324	.0332	.0972	.0829	.0934	.0995	.0943
Avg	1.2707	1.2466	1.3003	1.2546	1.2362	.2171	.1644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 206 / KHANDALA FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0769	2.915				1.8004	.6478
2	2.915	2.915				1.7147	.6478
3	2.753	2.915					.5992
4	2.753	3.0769					.5992
5	2.5911	2.915					.5992
6	2.4996	2.5911					.6478
7	2.915	2.915					.6478
8	2.915	2.915					.6478
9	2.915	2.9959					.6478
10			3.0769	3.2388	2.572		
11			3.4008		2.7435		
12			3.2388	3.2388	2.7435		
13			3.2388	3.1579	2.8959		
14			3.2388	3.2388	2.8959		
15			3.2388		2.7778		
16			3.2388	3.2388	2.2291		
17			3.2388	3.2388	2.2291		
24		3.0769			.0324	1.7004	.6478
Max	3.0769	3.0769	3.4008	3.2388	2.8959	1.8004	.6478
Min	2.4996	2.5911	3.0769	3.1579	.0324	1.7004	.5992
Avg	2.8148	2.9231	3.2388	3.2253	2.3466	1.7385	.6332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 201 / 11 KV KHARKHED

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		2.572			
8				.1715	
9	3.3951				
11	2.4863		2.0919	.407	
12		.1715			
13	2.915	2.6063	1.9204		
14	2.7778	2.8121			
15		2.915			
16	2.8807				
17	2.9835		1.9631		
18	.2347	2.572			
19			1.8861		
20	.2683	2.6063			
22	.3353		1.989		
23		2.572			
24		2.0576	.2058		1.0288
Max	3.3951	2.915	2.0919	.407	1.0288
Min	.2347	.1715	.2058	.1715	1.0288
Avg	2.0307	2.3205	1.6761	.2893	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 203 / 11KV ADGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						1.4922	
6	2.9835		1.1022				1.3717
7				2.7778			
8					2.0576		
9	2.7778	2.6406		2.8807		1.0174	.9259
11		.8478		2.0576	2.0348		
12			2.6235			.3772	
13		.8478	2.4348	2.0576		.7202	1.4575
14		1.0174	2.2977			.7202	1.0288
15			2.3834				1.0974
16		1.0174				.7202	
17		1.0174	2.4006				
18	2.8121	.3018	.3429			.5144	
19				.4115		.5487	
20		.3688				.583	
21			.3772		1.3413		.8573
22		.3018		.4801		.5144	
23			.4115				
24			1.0174	2.915		1.3717	1.3032
Max	2.9835	2.6406	2.6235	2.915	2.0576	1.4922	1.4575
Min	2.7778	.3018	.3429	.4115	1.3413	.3772	.8573
Avg	2.8578	.9290	1.5391	1.9400	1.8112	.7800	1.1488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 204 / 11 KV CHITTALWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						1.8004	
6	.6859		2.2291				
7				2.0919			.6516
8					1.4022		
9	.6859	.7202	2.0576	2.2634		.6783	.6173
11		2.8292		.6859	.6706		
12			.8745			.6859	
13		2.9492	.9431	.6173		.6859	1.7147
14		2.915	.9774			.6516	
15			.9431				1.0974
16		2.8826				.6516	
17		2.713	.9259	.7011	.5868		
18	.9259	.5868	.8916			.6516	
19				.8764		.6859	
20		.6706				.7202	
21			.823				.9259
22		.5868		.9259		.6859	
23			.7888				
24			2.0576	2.0576		.503	.7202
Max	.9259	2.9492	2.2291	2.2634	1.4022	1.8004	1.7147
Min	.6859	.5868	.7888	.6173	.5868	.503	.6173
Avg	.7659	1.8726	1.2283	1.2774	.8865	.7637	.9545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 205 / 11 KV Water Supply Express Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0343		.0335	.0343			.0343
7				.0171			
9	.0343	.0514		.0514		.0503	.0514
11		.0503		.0514	.0335		
12			.0343			.0171	
13		.0168	.0343	.0514		.0343	.0526
14		.0503	.0343			.0343	.0343
15			.0343				.0343
16		.0503				.0343	
17		.0168		.0514	.0335		
18	.0343	.0335	.0343			.0343	
19				.0171		.0171	
20						.0171	
21			.0343				
22						.0171	
23			.0171				
24				.0171			.0171
Max	.0343	.0514	.0343	.0514	.0335	.0503	.0526
Min	.0343	.0168	.0171	.0171	.0335	.0171	.0171
Avg	.0343	.0385	.0321	.0364	.0335	.0284	.0373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 201 / 11 KV PANCHGAVHAN

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7716	1.5432	1.5261	1.5432	.7202	.6516
2	.7545	.7373	1.5432	1.5089	1.5089	.7202	.6516
3	.7545	.7202	1.5432	1.5261	1.4575	.7545	.6516
4	.7373	.6859	1.5432	1.5261	1.406		.6687
5	.7545	.6859	1.5432	1.5089	1.3717		.6173
6	.583	.6173	1.3546	1.5261	1.3375		.5144
7	.4287	.463	1.5604	1.749			.4287
8	.4458	.4287	1.6118				.4287
9	1.3889	.3944	1.6461				.3601
10	1.3889	1.5947					.6859
11	1.3717	1.6632	.3601		1.046	.6859	.7202
12	1.5089	1.6632	.3944	1.286		.6516	.7373
13	1.4746	1.6975	.4115	.4458	.4287		.8573
14	1.4232	1.749	.4115		.4287	.5487	.8573
15	1.5432	1.7833	.4287		1.4918	.2915	.8573
16	1.6632	1.8004		.2915	1.4918	.6859	.8573
17	1.7318	1.8004		.12	1.406	.6516	.4801
18	.5144	.6173			.5144	.4801	.3944
19		.6173	.6859	.7716	.4458	.6001	.6516
20	.9945	.8059	.8573	.7888	.6516	.6001	.6516
21	.9774	.8573	.8573	.823	.823	.6687	
22	.9431	.8916	.8745	.8573	.7888	.703	.4801
23	.8059	.8573	.8573	.823	.7545	.6859	.4801
24	.7545	.7888	1.5432		1.5604	.7202	.6687
Max	1.7318	1.8004	1.6461	1.749	1.5604	.7545	.8573
Min	.4287	.3944	.3601	.12	.4287	.2915	.3601
Avg	1.0303	1.0288	1.0785	1.0674	1.0766	.6355	.6240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 203 / 11 KV WANGESHWAR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3608	2.7435	2.1262	1.4575	1.406	.5144	.7202
2	3.3951	2.915	2.1262	1.4575	1.406	.5144	.7202
3	3.3951	2.915	2.1262	1.4746	1.3717	.5144	.7202
4	3.3779	3.0007	2.1262	1.4746	1.2517		.7202
5	3.3779	3.0864	2.1434	1.4746	1.3717		.703
6	3.3436	3.0864	1.989	1.4232	1.3032		.6516
7	3.3779	3.2407	1.869	1.4403			.6173
8		.2058	1.7833				.5487
9	2.7435	.1715					.1715
10	.4287	1.8519					
11	1.749	2.1434	3.6694		1.7147	.2229	.3601
12	1.7833	2.1605	.5144		1.1831		.3772
13	1.7661	2.1605	.5658	.7202	1.1831		.3772
14	1.749	2.1605	.5487	.7202	1.0631	.2229	.3772
15	1.7147	2.1776		.7202	.823	.1715	.3772
16	1.7147	2.1434	.9431		.6859	.1372	.3772
17	1.7147	2.1091	.9774		.5144	.1715	.3772
18	.583	.4801	1.0117			.2572	.1715
19		.4801	.8402			.4458	.5144
20	1.0631	.9602	.9431			.4801	.5487
21	1.0802	.9259	.9431			.6001	.6001
22	1.0288	.9259				.583	.5144
23	1.0288	.9259				.7716	.5144
24	3.3779	2.572	2.1262	1.4746	1.4403	.5144	.7716
Max	3.3951	3.2407	3.6694	1.4746	1.7147	.7716	.7716
Min	.4287	.1715	.5144	.7202	.5144	.1372	.1715
Avg	2.1434	1.8976	1.5459	1.2580	1.1941	.4081	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 201 / 11 KV Danapur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6001	1.5384	1.4074	1.3108	.823	.7922
2	.6036	.6001	1.5223	1.2342	1.2651	.7716	.7922
3	.5658	.5487	1.5223	1.2191	1.2498	.7202	.7545
4	.5658	.5144	1.5384	1.2191	1.2193	.6516	.679
5	.4904	.5144	1.5223	1.2041	1.1888	.5144	.6602
6	.4338	.4801	1.4899	1.174	1.0669	.4287	.6036
7	.3772	.4287		1.1288	.9145	.4115	.4904
8	.3018	.3429		1.1288	.7773	.3601	.3961
9	.3018	.1886		1.189	.7468	.3086	.3772
10	1.2803	1.4937				.2743	.2591
11	1.2193	1.531	.2641			.2561	.2743
12	1.2498	1.5684	.4715			.2591	.2915
13	1.2651	1.5844	.679	.5316		.2591	.3086
14	1.2955	1.6032	.7167	.703		.2721	.2915
15	1.3565	1.6004	.7545	.6859	.5316	.2753	.2229
16	1.326	1.6194	.6979	.583	.4973	.2591	.2229
17	1.3565	1.4403	.679	.4801	.4115	.2429	.2229
18	.3048	.2263	.6602	.4115	.4458	.4904	.4458
19		.3018	.6224	.5144	.6516	.6036	.583
20	.5487	.415	.9808	.7545	.7716	.7356	.7621
21	.6516	.4715			.8573	.7545	.8192
22	.7202	.4904			.8573	.8299	
23	.6859	.4904	1.0829	.9945	.8573	.8676	.8764
24	.6602	.6344	1.5364	1.5261	1.2651	.823	.8299
Max	1.3565	1.6194	1.5384	1.5261	1.3108	.8676	.8764
Min	.3018	.1886	.2641	.4115	.4115	.2429	.2229
Avg	.7914	.8204	1.0155	.9521	.8887	.5080	.5198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 202 / 11 KV Warkhed

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.4937	.2829	.2829	.2743	.4268	.3725
2	1.2811	1.5394	.2641	.2829	.2229	.4268	.3563
3	1.3443	1.7147	.2641	.2829	.2229	.3963	.3521
4	1.3279	1.4632	.2263	.2641	.2229		.3401
5	1.3748	1.4327	.2263	.2641	.2058		.3401
6	1.4243	1.4022	.2263	.2075	.1715		.3521
7	1.3765	1.5394		.1334	.1372	.3658	.3887
8	1.2963	1.5394		.132	.12	.3506	
9	1.4529	1.5242		.132	.1029		
10	.0943	.12					
11	.1029	.132	1.7532			.3563	.0953
12	.12	.12	2.0698	1.829		.4715	.1143
13	.1372	.1509	2.2916	1.8138		.1509	.1143
14	.1543	.1509	2.2177	1.7223		.132	.1143
15	.1715	.1698	2.1437	1.8747	.9907	.132	.1334
16	.1715	.1698	2.1807	1.8138	.9602	.132	.1334
17	.1372	.132	2.1622	1.7375	.8993	.1509	.1334
18	.1372	.1886	.1886	.1029	.0686	.1509	.1524
19		.2075	.1886	.1543	.2058	.2263	.1905
20	.2572	.2829	.3018	.2743	.2572	.2452	.2477
21	.2743	.3206		.3086	.2058	.2452	.2858
22	.2743	.3395		.3086	.2058	.2641	.2858
23	.2743	.3018	.3018	.2915	.1372	.2641	.2858
24	1.2654	1.448	.2829	.2829	.2743	.442	.4321
Max	1.4529	1.7147	2.2916	1.8747	.9907	.4715	.4321
Min	.0943	.12	.1886	.1029	.0686	.132	.0953
Avg	.6839	.7451	.9763	.6589	.3098	.2805	.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 203 / 11 KV Hingani

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2743	.2263	.2829	.2743	.2401	
2	.2263	.2743		.2829	.2743	.2401	
3	.2263	.2058	.1886	.2829	.2572	.2058	
4	.1886	.2058	.1905	.2829	.2572	.1715	
5	.1509	.1715	.1524	.2263	.2229	.1372	
6	.132	.1543	.0953	.1886	.1715	.1029	
7	.1132	.0857		.1334	.1372	.1029	
8	.0943	.0686		.1143	.1029	.0686	
9	.0943	.0857		.0953	.0857		
10	.0754	.1029					
11	.1029	.1132	.1334				.0762
12	.1029	.1132	.1524				.0762
13	.1372	.1132	.1524	.1372		.1132	.0762
14	.1372	.132		.1543		.1132	.0762
15	.1543	.132	.1524	.1543	.1029	.1132	.0953
16	.1372	.132	.1698	.1543	.1029	.132	.1143
17		3.0308	.1143		2.2405	.2915	.3429
18	2.6825	3.0933	.1509	3.2007	2.3472	.3201	.3429
19		2.8807	.1143	2.8502	2.4691	.3401	.3429
20	2.4082	2.7496	3.8142		1.9052	.3201	.3429
21	2.8121	2.7526			2.0576	.3239	.3429
22	2.5606	2.7496			2.0729	.3361	.3601
23	2.5606	2.9127	3.3498	2.8635	2.0729	.3361	.3601
24	2.6558	2.6216	2.9371	3.2977	2.7435	2.0881	.3239
Max	2.8121	3.0933	3.8142	3.2977	2.7435	2.0881	.3601
Min	.0754	.0686	.0953	.0953	.0857	.0686	.0762
Avg	.8190	1.0481	.7559	.8648	1.0473	.3048	.2338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 204 / balhadi feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7496	2.7206	.4527	2.9508	.3258	2.1186	
2	2.6871	3.1398	.4527	2.934		2.21	
3	2.7206	3.0178	.415	2.934	.1715		
4	2.5926	2.5339	.415	2.934	.1543		
5	2.4684	3.0864	.3961	2.8344	.1543		
6	2.4646	2.6978	.415	2.8178	.1372		
7	2.5606	2.7435		2.7846	.1372		
8	2.6246	2.4939		2.6749			
9	2.1091	2.21		2.2771	.0514		
10	2.2184	2.2405					
11	1.8595	2.2725	2.7035		.9297		.12
12	2.0233	2.1091	2.6235	2.5301	.7164	.1781	.12
13	1.89	2.1872	2.6073	2.4691	.2743	.1943	.12
14	1.9509	2.4326		2.4691	2.6063	.7042	
15	2.2558	2.5309	2.4985	2.4234		.7125	
16		2.3903	2.451	2.1338	.8535	.6802	.0762
17		.0754	.2263	.1715	.1677	.4049	.2096
18	.2058	.1509	.1905	.1715	.2134	.2452	.2667
19		.1886	.2263	.2401	.2401	.3018	.3048
20	.3772	.2641	.415		.3772	.3395	.381
21	.4287	.3018			.3944	.3395	.381
22	.4287	.3772			.3944	.3772	.4001
23	.4287	.415	.4904	.4954	.3944	.3961	.4001
24	.4527	.4115	.4715	.4715	.4287	.3772	.3772
Max	2.7496	3.1398	2.7035	2.9508	2.6063	2.21	.4001
Min	.2058	.0754	.1905	.1715	.0514	.1781	.0762
Avg	1.7856	1.7913	1.0265	2.0377	.4561	.6386	.2631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 201 / Talegaon Bz

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	2.8178	1.3565	.724	.6859		.5906
2	.6287	2.7854	.7049	.6859	.6859		.5906
3	.6287	2.7854	.7049	.6859	.6478		.5716
4	.6097	2.753	.6859	.6859	.6478		.5716
5	.6097	2.753	.6668	.6859	.6668		.5335
6	.5525		.6287	.5906	.5716		.5144
7	.362	2.8016	.4572	.4763	.381		.4191
8	.381	2.8826	.381	.381	.3429		.362
9	.3429	2.834	.4001	.381	.3429		.3429
10	3.2065	.3048	.381	3.0931	1.2517		.373
11	3.3036	.3239			2.5888	.381	.39
12		.4001	3.2226	3.0445	2.672	.3429	.4572
13		.4191	2.915	3.0167	2.7368		.4382
14	.4954	.4572	2.915	2.6825	2.8826	.5906	.4001
15	.5335	.5335	2.9635	2.915		.5335	.381
16	.5144	.4954	3.086	2.8664			.3429
17	.4572	.4191	3.0283	3.1093		.4382	.4572
18		.381	3.0283	.3239	.4572	.3239	.3429
19		.4954	.4001	.4572	.5525	.4763	.4572
20	3.2712	.6668	.6668	.6668	.6668	.5716	.5716
21	3.0769	.743	.7049	.724	.6859	.6287	.6097
22	2.8988	.7811	.7621	.743	.6097	.6287	.6478
23	2.7854	.7621	.7621	.724	.6859	.6287	.6097
24		2.8016	.4917	.724	.7049	2.1874	.5906
Max	3.3036	2.8826	3.2226	3.1093	2.8826	2.1874	.6478
Min	.3429	.3048	.381	.3239	.3429	.3239	.3429
Avg	1.3329	1.4086	1.3615	1.3212	1.0223	.6443	.4819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 202 / industrial feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381		.0381
2	.0381	.0381	.0381	.0381	.0381		.0381
3	.0381	.0381	.0381	.0381	.0381		.0381
4	.0381	.0381	.0381	.0381	.0381		.0381
5	.0381	.0381	.0381	.0381	.0381		.0381
6	.0381	.0381	.0381	.0381	.0381		.0381
7	.0381	.0381	.0381	.0381	.0381		.0381
8	.0381	.0381	.0381	.0381	.0381		.0381
9	.0381	.0381	.0381	.0381	.0381		.0381
10	.0381	.0381	.0381	.0381	.0381		.0381
11	.0381	.0381	.0381		.0381		.0381
12	.0381	.0381	.0381	.0381	.0381	.0381	.0381
13	.0381	.0381	.0381	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381	.0381	.0381
15	.0381	.0381	.0381	.0381	.0381	.0381	.0381
16	.0381	.0381	.0381	.0381	.0381	.0381	.0381
17	.0381	.0381	.0381	.0381	.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24		.0381	.0381	.0381	.0381	.0381	.0381
Max	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0381	.0381	.0381	.0381	.0381	.0381	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 203 / Borwa

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3579	.724	.724	2.8597	2.6787		.7461
2	2.3579	.724	.724	2.8597	2.6787		.7291
3	2.2634	.6859	.724	2.8235	2.6425		.7291
4	2.1874	.6859	.6859	2.8235	2.6787		.7291
5	2.1026	.6478	.6478	2.6606			.7042
6	2.0008	.6478	.6287	2.7149			.7042
7	2.3405	.4954	.4572	2.8235			.6706
8	2.2885	.381	.3429	2.8959			.6783
9	2.3663	.381	.3239	2.7511			.6783
10	.2667	2.9321	2.696	.3048			.3239
11		2.713	2.8086		.381	1.105	.3048
12	.4191	2.7435	.3429	.3429	.1715	.9145	.3048
13	.4382	2.8292	.381	.4001		.8573	.3429
14	.5335	3.0521	.4191	.4572	.381	.8192	.3429
15	.5335	3.0693	.4191	.4572	.4191	.8192	.381
16	.4763	3.035	.4191	.4191	.4572	.8002	.381
17	.4001	3.4294	.4001	.4001	.4191	.8002	.362
18	.3429	2.7639	.4572	.362	2.0233	.3429	.4191
19	.3429	2.6873	2.8959	.4572	1.7804	.4954	.4572
20	.6668	.6668	3.1312	.6287	1.7126	.5906	.5335
21	.724	.743	2.9864	.743	.724	.6287	.5716
22	.7811	.7811	2.8959	.7621	.724	.6478	.6478
23	.743	.1715	2.9864	.6859	.6859	.6287	.6097
24	2.3663	.743	.743	2.8959	2.7149	.6668	.7461
Max	2.3663	3.4294	3.1312	2.8959	2.7149	1.105	.7461
Min	.2667	.1715	.3239	.3048	.1715	.3429	.3048
Avg	1.2739	1.5722	1.2183	1.5012	1.3690	.7226	.5457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 201 / 11 KV KODRI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2042	.192	.2858		
2			.2042	.192	.3001		
3			.2042	.192	.3001		
4			.1915	.204	.3001		
5			.1915	.192	.2681		
6			.2298	.204	.2042		
7			.2681	.2521	.2195		
8			.2936	.2401	.1976		
9			.2808	.216	.1911		
10	.2229	.2244				.096	.0894
11	.2778	.2717				.096	.1183
12	.2244	.3064				.096	.1183
13	.2244	.2425					.1183
14	.2126	.2298				.06	.1149
15	.2126	.2298				.0429	.1149
16	.2126	.2553				.0429	.1149
17	.2244	.2808				.0429	.1149
24			.1915	.192	.2572		
Max	.2778	.3064	.2936	.2521	.3001	.096	.1183
Min	.2126	.2244	.1915	.192	.1911	.0429	.0894
Avg	.2265	.2551	.2259	.2076	.2524	.0681	.1130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 202 / Wadi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5893	1.6716	.9335	.9145	.9717	1.2498	.4239
2		1.6716	.9145	.9145	.9717	1.2498	.4239
3	1.5384	1.6404	.8573	.8764	.9717	1.2498	.4239
4	1.439	1.5779	.8573	.8764	.9717	1.2498	.4024
5	1.4969	1.5935	.8002	.8383	.9717	1.1717	.4024
6	1.3117	1.6091	.6287	.5716	.7811	.9374	.3856
7	1.5844	1.6404	.5144	.5716	.5144	.7186	.3506
8	1.6105	1.6091	.3429	.4763		.6249	.3292
9	1.5466	1.6248	.4382	.362	.4572	.4999	.3755
10	.3048	.4191	1.8747	2.0309	1.382	.4001	.3429
11	.381	.4382	1.813	2.0645	1.5935	.4191	.3048
12	.4191	.5335	1.6644	1.7497	1.5779	.4001	.3429
13	.4382	.5716	1.7071	1.599	1.656		.362
14	.6287	.6097	1.781	1.7375	1.6872	.4382	.4382
15	.6287	.6478	1.7185	.6802	1.5623		.4572
16	.5906	.6287	1.8747	.8741	1.6404	.4191	.4572
17	.5525	.6097	1.9685	1.9444	1.5466	.4191	.4763
18	.4954	.5335	.4954	.4572	.4572	.5525	.381
19	.6097	.6478	.6097	.6859	.6478	.6979	.6668
20	.9907	.9717		.8954	.9145	.811	.9335
21	1.0669	1.0669		1.0479	.9717	.9335	.8573
22	1.0669	1.086	.9907	1.0669	.9335	.8775	.8573
23	.9907	.9335	.9335	1.0479	.9335	.8215	.8383
24	1.6598	1.7185	.9335	.9145	.9907	1.2498	.407
Max	1.6598	1.7185	1.9685	2.0645	1.6872	1.2498	.9335
Min	.3048	.4191	.3429	.362	.4572	.4001	.3048
Avg	.9974	1.0856	1.1205	1.0499	1.0916	.7905	.4850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 203 / Warud

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4954	.7449	.7042	.8162	.4763	.4715
2	.4001	.4954	.7362	.7042	.8162	.4763	.4715
3	.4001	.4763	.7202	.6722	.7907	.4763	.4715
4	.381	.4763	.703	.6401	.759	.4572	.4715
5	.381	.4572	.7099	.5921	.6958	.4572	.415
6	.362	.4191	.7316	.7202	.6718	.4191	.3048
7	.1905	.2096	.7526	.8962	.8173	.2858	
8	.1524	.1905	.7628	.9602	.6144		.1715
9	.1334	.1715	.7674	.9762	.5858	.2286	.1524
10	.9069	.8962	.1715	.1334	.1715	.2401	.1486
11	.9393	.9282	.1715	.1334	.1334	.176	.1337
12	.8002	.9297	.2477	.1334	.2096	.192	.1698
13	.8962	1.0242	.3239	.2477	.2096		.2315
14	.9122	1.012	.2858	.2858	.1905	.16	.2561
15	.8962	1.0279	.2858	.2477	.1715	.1715	.25
16	.9122	1.0031	.2477	.1905	.2096	.192	.2743
17	.8802	1.0155	.2286	.1715	.1905	.192	.286
18	.2667	.2667	.2286	.1905	.2096	.381	.2096
19	.3048	.3239	.3048	.3048	.3429	.381	.3429
20	.5144	.4763		.5144	.5144	.415	.4763
21	.5525	.5716		.5525	.5335	.5093	
22	.5716	.5716		.5525	.4954	.5093	
23	.5144	.5716	.5144	.4954	.4763	.4527	.4001
24	.4572	.5335	.7865	.6722	.8002	.4763	.4715
Max	.9393	1.0279	.7865	.9762	.8173	.5093	.4763
Min	.1334	.1715	.1715	.1334	.1334	.16	.1337
Avg	.5477	.6060	.4964	.4871	.4761	.3511	.3133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024049 / 33/11 KV BELKHED S/S

Feeder No / Name : 201 / 11 KV BELKHED

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642	1.307	2.5143	2.1214	2.3562	.9808	.8676
2	.9774	1.307	2.4074	2.1464	2.3403	.9619	.8589
3	1.0642	1.2696	2.4059	2.13	1.9528	.9431	.8589
4	.9465	1.2136	2.4036	1.9662	1.8976	.9054	.8589
5	.9391	1.1203	2.3365	1.917	1.7185	.8676	.8215
6	.6697	.9709	2.0466	1.8023	1.531	.8299	.7468
7	.5658	.7468	2.2771	1.9685	1.4175	.4338	.5658
8	.4904	.5975	2.392	2.4741	1.2498	.4715	.4854
9		.5601	2.2862	2.4741	1.247		.4668
10	2.5724	2.9635	.5281	.5041			.4424
11	2.5775	3.1417	.547				.4807
12	2.5143	3.546	.5658	.5975	.5415	.3429	.503
13	2.4669	.8488	.6485	.7282	.6413	.3113	.5182
14	2.3562		.7537	.7842	.6602	.3441	.4167
15		2.5459	.7202	.7733	.6413		.4115
16		2.7027			.6224	.3277	.3704
17		2.5301	.6535	.5415	.5847	.3441	
18		.6413	.5415		.5847	.4801	.6161
19		.7167	.6348	.679	.7356	.6348	.7468
20	2.9254	1.0185	.9709	1.0374	.9054	.8029	.8589
21	2.9995	1.1576	1.1128	1.0562	1.0185	.811	.9054
22	3.0445	1.2637	1.2071	1.1883	1.0374	.9242	.9242
23	1.363	1.226	1.2071	1.1694	1.0185	.9242	.9054
24	1.0642	1.363	2.6408	2.5396	2.0965	.9997	.8865
Max	3.0445	3.546	2.6408	2.5396	2.3562	.9997	.9242
Min	.4904	.5601	.5281	.5041	.5415	.3113	.3704
Avg	1.7001	1.5112	1.4696	1.4571	1.2181	.6821	.6746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024049 / 33/11 KV BELKHED S/S

Feeder No / Name : 202 / 11 kV Warud (Bihade).

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8509	.415	.3772	.4338	.4338	1.9919	.5668
2	2.7854	.415	.3584	.4294	.415	1.9204	.6535
3	2.7854	.3961	.3395	.4294	.3961	1.8501	.6535
4	2.7035	.3772	.3206	.4294	.3772	1.7654	.6535
5	2.2939	.3584	.3018	.4108	.3772	1.4232	.5898
6	2.3922	.3206	.2829	.2987	.3584	1.3603	.5636
7	2.5425	.2263	.1698	.1698	.2075	.7773	.6802
8	2.5911	.1886	.1509	.168	.1886	.583	.7537
9	2.4777	.1886	.1698	.1867	.1509	.4049	.7045
10	.128	.2075	.1509	2.9984			.1307
11	.1886	.1886	.132				.1307
12	.2452	.2075		3.3198	.1781	.1494	.132
13	.2829	3.2606	3.1131	.6316	.1296	.1494	.1494
14	.2829		.2572	3.7534	2.834	.1867	.1867
15		.2829	.2801	.1943	2.5101		.1867
16		.2829	3.6046		2.4939	.1475	.168
17		.3018	.1886	.0934	2.4291	.168	
18		.2075	.1867		.2075	.168	.1494
19		.2829	.2427	.2614	.3018	.2427	.2427
20	.4715	.4338	.3921	.415	.3961	.3361	.3734
21	.4715	.4904	.4715	.4527	.4338	.3772	.415
22	.4715	.4904	.4715	.4527	.3961	.3961	.3961
23	.4527	.4715	.4715	.4527	.3772	.3961	.3772
24	2.8018	.4527	.3961	.4294	.4338	2.0405	.583
Max	2.8509	3.2606	3.6046	3.7534	2.834	2.0405	.7537
Min	.128	.1886	.132	.0934	.1296	.1475	.1307
Avg	1.5379	.4542	.5578	.7815	.7284	.8016	.4104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024050 / 33/11 kV SAUNDALA

Feeder No / Name : 201 / 11 kV SAUNDALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.958	.4287	.4527	.4801	.3963	.1739
2	.6706	.856	.3944	.4251	.4458	.3963	.1581
3	.6472	.9074	.3772	.4251	.4382	.381	.1581
4	.6321	.929	.3772	.4251	.4401	.381	.1581
5	.6097	.902	.3429	.4066	.4249	.3353	.1423
6	.6249	.827	.3086	.3511	.4249	.3201	.1406
7	.8322	.858	.2743	.1848	.3467	.1219	.1265
8	.8383	.8824	.1543	.1646	.2515	.1219	.1423
9	.8579	.9531	.1543	.1848	.1867	.1524	.1265
10	.2263	.1715	.8383	.9907		.12	.1698
11	.1848	.1029	.8429	1.0212			.1372
12	.2343	.2401	.8128	1.0669	.7773	.132	.1562
13	.2858	.2572	.9552	.9755	.7011	.1509	.1943
14	.3086	.3258	.8674	.9297	.6706	.1509	.2134
15	.3201	.3429	.9552	1.0774	.6401	.1509	.2324
16	.3201	.2743	.945	.902	.7011	.2075	.2172
17	.2705	.2743	.9755	1.0409	.6554	.2075	.2058
18	.2896	.2572	.2075	.2218	.2058	.2263	.2515
19	.282	.2743	.2263	.2402	.2743	.2641	.2934
20	.442	.4287	.415	.4024	.3772	.3018	.3849
21	.5106	.4801	.0476	.4915	.4115	.3772	.423
22	.503	.4801		.5106	.4115	.415	.4191
23	.4896	.463	.4763	.503	.3772	.3772	.3944
24	.6773	.9307	.4287	.4715	.4763	.381	.16
Max	.8579	.958	.9755	1.0774	.7773	.415	.423
Min	.1848	.1029	.0476	.1646	.1867	.12	.1265
Avg	.4887	.5573	.5133	.5777	.4599	.2638	.2158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024050 / 33/11 kV SAUNDALA

Feeder No / Name : 202 / 11kV PIMPARKHED

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0212	1.3042				.3201	.0633
2	1.0212	1.3641				.2934	.0474
3	.9934	1.3014					.0474
4	.9934	1.1829					.0474
5	1.0084	1.1629					.0474
6	.9783	1.3042					.0474
7	1.0254	1.3959				.2439	.0633
8	1.0837	1.317				.0934	.0474
9	1.0235	1.442				.0934	.0633
10			1.4937			.0934	
11			1.6556	1.5699			
12			1.5804	1.6613	.9907		
13			1.4623	1.3413	.8669		
14			1.281	1.4327	.8802		
15			1.6227	1.6907			
16			1.5242	1.4959	.6001		
17			1.5699	1.4721	.5735		
24	1.0084	1.2911				.2801	.064
Max	1.0837	1.442	1.6556	1.6907	.9907	.3201	.064
Min	.9783	1.1629	1.281	1.3413	.5735	.0934	.0474
Avg	1.0157	1.3066	1.5237	1.5234	.7823	.2025	.0538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024050 / 33/11 kV SAUNDALA

Feeder No / Name : 203 / 11kV KARLA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2782	1.7871	1.9753	2.2988	.2058	.2075
2	.2641	.2782	1.7471	1.9357	2.3237	.2058	.2075
3	.2452	.2763	1.7204	1.9204	2.1147	.2058	.1886
4	.2452	.282	1.7071	1.829	2.343	.1715	.1886
5	.2452	.2782	1.6671	1.768	2.3237	.1715	.1886
6	.1698	.1962	1.6937	1.0974	2.3119	.1543	.1509
7	.1109	.1581	1.7337	2.0271	2.3465	.1372	.132
8	.0754	.1238	1.6537	2.0576	.8777	.1029	.0943
9	.0732	.1029	1.7471	2.077	.893	.1029	
10	2.3781	2.4406	.1029			.12	.112
11	2.4371	2.3205	.1097	.128			.1715
12	2.5396	2.1072	.128	.1097	.12		.2515
13	2.473	2.1072	.1524	.1663	.12	.116	.2362
14	2.4664	1.8271	.1658	.1848	.1372	.0995	.2515
15	2.2487	2.1738	.16	.1791	.12	.0995	.1276
16	2.501	2.1338	.1663	.1734	.12	.116	.1399
17	2.5316	1.7737	.1478	.1353	.12	.0937	.2134
18	.1524	.1029	.1132	.0924	.1543	.1107	.1372
19	.1486	.1715	.1698	.1646	.1886	.1886	.1962
20	.301	.2743	.2452	.2587	.2401	.2263	.2515
21	.3277	.2743	.0286	.3086	.2572	.2452	.2667
22	.2782	.2915		.3182	.2572	.2452	.261
23	.2915	.2743	.2858	.2915	.2401	.2263	.2439
24	.2641	.2801	1.7204	2.0576	2.1895	.2229	.2263
Max	2.5396	2.4406	1.7871	2.077	2.3465	.2452	.2667
Min	.0732	.1029	.0286	.0924	.12	.0937	.0943
Avg	.9597	.8553	.8327	.9242	1.0044	.1622	.1932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024054 / 33/11 kV YEDLAPUR S/S

Feeder No / Name : 201 / 11kV YEDLAPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1806	.1932	1.7387	1.7604		.1635	.1656
2	.1806	.176	1.709	1.7604		.1486	
3	.1505	.1882	1.7238	1.7311		.1486	
4	.1505	.1882	1.709	1.7311		.1337	
5	.1204	.1907	1.6284	1.643		.132	
6	.1204	.1783	1.5404	1.5257		.1337	
7	.0903	.1027	1.6284	1.7604		.104	
8	.0743	.1027	1.8044	1.7604		.1337	
9	.0903	.1014	1.7164	1.7897		.1174	
10	1.813	1.7575	.0903			.4694	
11	1.781	1.781	.0753		.0724		.2027
12	1.729	1.7231	.0753		.0869		
13	1.6796	1.7311	.0753				
14		1.7457	.1204				.0857
15	1.6072	1.6871	.1355				.2172
16	1.7981	1.7604	.1204		.0734	.2709	.2172
17	1.7311	1.7164	.1204		.1174	.2347	.2172
18	1.6651	.1189	.1054		.132	.0903	.2027
19	.1467	.1337	.1505		.132		.1738
20	.2229	.208	.1806		.1907		.1907
21	.1932	.2054	.2107		.176		.1882
22	.2054	.2054	.2107		.176		.1907
23	.1882	.1907	.2107		.1614		.1738
24	.1932	.1932	1.6871	1.7604		.1614	.1656
Max	1.813	1.781	1.8044	1.7897	.1907	.4694	.2172
Min	.0743	.1014	.0753	1.5257	.0724	.0903	.0857
Avg	.7005	.6908	.7820	1.7223	.1318	.1744	.1839