

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 201 / TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.6097	.6859	.6859	.6859	.6859
2	.6097	.6097	.6097	.6859	.6097	.6859	.6859
3	.6097	.6097	.6097	.6097	.6097	.6859	.6097
4	.6097	.6097	.6097	.6097	.6859	.6859	.6097
5	.6859	.6859	.6859	.7621	.7621	.8383	.7621
6	.9145	.9145	.9145	.9907	1.0669	1.1431	.9145
7	1.1431	1.1431	.9907	.9907	1.1431	.9907	
8	1.2193	1.1431	1.2193			1.2955	
9	1.2193	1.1431	1.2193	1.1431	.6097	1.2955	1.2193
10	1.2193	1.0669	1.1431	1.1431	1.3717	1.2193	1.5242
11	1.1431	.9145	1.1431	.9907	1.2955	1.2193	1.3717
12	1.0669	.1524	.2286	.0762	.1524	.2286	.2286
13	.9907						
14	.9145		.2286				
15	.7621	1.1431	1.0669	1.0669	1.2193	.6859	1.2193
16	.7621	1.0669	.9907	1.0669	1.1431	1.1431	1.1431
17	.9145	1.0669	.9907	1.1431	1.0669	1.1431	1.2193
18	1.1431	1.1431	1.0669	1.2193	1.2955	1.2193	1.2955
19	1.1431	1.2193	1.2193	1.2955	1.3717	1.448	1.3717
20	1.1431	1.2955	1.2193	1.3717	.3048	.3048	.3048
21	.9145	1.0669	1.0669	1.0669			
22	.7621	.8383	.9145	.9145	1.2193	1.0669	1.0669
23	.6859	.7621	.7621	.8383	.9907	.9145	.9145
24	.6097	.6859	.6859	.7621	.8383	.7621	.7621
Max	1.2193	1.2955	1.2193	1.3717	1.3717	1.448	1.5242
Min	.6097	.1524	.2286	.0762	.1524	.2286	.2286
Avg	.9082	.9041	.8780	.9254	.9221	.9363	.9426

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 202 / TOWN2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.8383	.9145	.9907	.9907	1.0669	.9907
2	.9145	.8383	.9145	.9145	.9145	.9907	.9145
3	.9145	.8383	.8383	.9145	.9145	.9145	.9145
4	.9145	.8383	.8383	.9145	.9145	.9145	.9145
5	.9907	.9145	.9145	.9907	1.0669	1.1431	1.0669
6	1.2193	1.1431	1.2193	1.2955	1.2955	1.5242	1.5242
7	1.448	1.448	1.448	1.1431	1.3717	1.1431	.1524
8	1.448	1.448	1.448			1.6004	
9	1.5242	1.3717	1.5242	.6859	.9145	1.448	.6097
10	1.448	1.2955	1.448	1.7528	1.2955	1.448	1.7528
11	1.3717	1.2955	1.3717	1.448	1.0669	1.3717	1.6004
12	1.1431	1.1431	1.2955	1.2955	1.1431	1.2193	1.2955
13	1.0669	.0762		.2286	.2286	.0762	.1524
14	.9907						
15	.9145	.0762	.3048				
16	.9145	1.2193	1.2193	1.2955	1.0669	1.1431	1.2193
17	1.0669	1.2955	1.2955	1.2193	1.3717	1.2955	1.2955
18	1.1431	1.2955	1.2955	1.2955	1.3717	1.3717	1.3717
19	1.2193	1.3717	1.448	1.5242	1.5242	1.6004	1.448
20	1.2955	1.448	1.5242	1.5242	.1524	.1524	.1524
21	1.1431	1.2955	1.3717	1.3717	.2286		
22	1.1431	1.1431	1.2955	1.2193	1.6004	1.448	1.3717
23	.9907	1.0669	1.1431	1.2193	1.2955	1.2955	1.2955
24	.9145	.9907	1.0669	1.0669	1.1431	1.0669	1.0669
Max	1.5242	1.448	1.5242	1.7528	1.6004	1.6004	1.7528
Min	.9145	.0762	.3048	.2286	.1524	.0762	.1524
Avg	1.1304	1.0735	1.1882	1.1576	1.0415	1.1540	1.0555

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 207 / TOWN NO-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.381	.4572	.4572	.4572	.4572	.4572
2	.4572	.381	.4572	.4572	.4572	.4572	.4572
3	.4572	.381	.4572	.4572	.4572	.4572	.4572
4	.5335	.4572	.4572	.4572	.4572	.5335	.5335
5	.5335	.6097	.5335	.6097	.6097	.6097	.1524
6	.6097	.6097	.5335	.6859	.3048	.2286	.0762
7	.5335	.5335	.6097	.5335		.8383	.0762
8	.5335	.4572	.5335	.4572	.6859	.5335	.7621
9	.4572	.4572	.4572	.4572	.6097	.5335	.7621
10	.4572	.4572	.4572	.5335	.5335	.4572	.6097
11	.4572	.4572	.4572	.4572	.4572	.4572	.5335
12	.4572	.4572	.5335	.4572	.5335	.4572	.5335
13	.4572	.4572	.5335	.5335	.5335	.4572	.4572
14	.4572	.4572	.5335	.4572	.5335	.4572	.4572
15	.4572	.4572	.5335	.5335	.5335	.5335	.5335
16	.5335	.4572	.4572	.5335	.5335	.5335	.5335
17	.5335	.5335	.6097	.5335		.0762	.0762
18	.6097	.6097	.6097	.6859	.0762	.0762	.0762
19	.6097	.6097	.6859	.6859	.2286	.0762	.0762
20	.5335	.6097	.6097	.6859	.6859	.8383	.7621
21	.5335	.5335	.6097	.6097	.6859	.7621	.7621
22	.4572	.5335	.5335	.5335	.6859	.6097	.6859
23	.4572	.4572	.4572	.5335	.6097	.5335	.5335
24	.381	.4572	.4572	.4572	.5335	.4572	.4572
Max	.6097	.6097	.6859	.6859	.6859	.8383	.7621
Min	.381	.381	.4572	.4572	.0762	.0762	.0762
Avg	.4985	.4922	.5239	.5335	.5092	.4763	.4509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 203 / GONDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.381	.381	.381	.381	.381
2	.381		.381	.381	.381	.381	.381
3	.381		.4572	.381	.381	.381	.381
4	.4572		.4572	.4572	.4572	.4572	.4572
5	.5335		.6097	.5335	.6097	.5335	.6097
6	.6097		.8383	.8383	.8383	.7621	.6859
7	.9145		1.0669	.9907	.8383	.6859	
8	.9145		.9907	.6859		.6859	
9	.8383	.381	.8383	.5335	.381	.6859	.8383
10	.6859	.5335	.4572	.6097	.381	.6097	.9145
11	.5335	.6097	.6097	.4572	.7621	.381	.6859
12	.6097	.5335	.5335	.3048	.5335	.5335	.5335
13	.381						
14	.3048						
15	.3048	.0762	.1524		.1524		.1524
16	.3048	.5335	.4572	.4572	.4572	.381	.4572
17	.4572	.6097	.5335	.5335	.5335	.5335	.381
18	.6097	.6859	.6097	.6097	.6859	.6859	.6097
19	.7621	.7621	.7621	.8383	.6097	.8383	.7621
20	.7621	.0762	.6859		.0762	.0762	.0762
21	.6859		.5335				
22	.4572		.4572				
23	.381	.5335	.381	.5335	.5335	.4572	.5335
24	.381	.4572	.381	.4572	.381	.381	.4572
Max	.9145	.7621	1.0669	.9907	.8383	.8383	.9145
Min	.3048	.0762	.1524	.3048	.0762	.0762	.0762
Avg	.5430	.4827	.5716	.5546	.4933	.5174	.5165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 209 / CANNEL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***						***
2	***	***					***
3		***					***
4		***					***
5		***					***
6		***					***
7							***
8							***
10			***	***		***	
11	***		***	***		***	
12			***	***		***	
13			***		***	***	
14			***			***	
15	***		***	***		***	
16	***	***	***	***	***	***	
17	***		***	***	***	***	
18	***		***	***	***	***	
24						***	***
Max	152.416	76.208	152.416	152.416	76.208	76.208	76.208
Min	76.208	76.208	76.208	76.208	76.208	76.208	76.208
Avg	108.8686	76.208	101.6107	130.6423	76.208	76.208	76.208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 202 / SIRNER GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.2332	.2332	.2462	.2362	.2606	.2904
2	.2416	.2416	.2362	.2469	.2362	.25	.2835
3	.2728	.2507	.2484	.2614	.2416	.2553	.2926
4	.3117	.2995	.2835	.2942	.266	.2904	.346
5	.4214	.4047	.3826	.3887	.3666	.3925	.4466
6	.4923	.5868	.567	.6241	.4969	.4298	.4725
7		.7064	.6783	.612	.5571		
8	.6501	.6851	.6173				
9	.6097	.5517	.4931	.234	.407		
10	.4816	.3765	.4321	.4397	.5281	.33	.2995
11	.2858	.2705	.2698	.2507	.3772	.333	
12		.2058	.1684	.1478	.3071	.2263	.1684
13		.1684					
14		.1532					
15	.1532	.1799	.0838			.0511	
16	.2119	.1821	.1837	.1433		.1943	.2644
17	.3239	.2111	.2103	.1875		.2111	.3239
18	.5053		.3155	.2873		.2995	.3879
19	.4908	.3635	.4946	.4931		.3231	.442
20	.3917	.4999	.5075	.5167		.013	.1052
21	.3025	.365	.3666				
22	.2652	.2957	.3041	.2957	.0236	.3414	.0038
23	.2378	.2606	.266	.2622	.2873	.3315	.3117
24	.2294	.2431	.25	.2408	.2652	.2904	.301
Max	.6501	.7064	.6783	.6241	.5571	.4298	.4725
Min	.1532	.1532	.0838	.1433	.0236	.013	.0038
Avg	.3557	.3363	.3451	.3249	.3283	.2680	.2962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 201 / WATER SUPPLY

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3						.0556	
4						.0358	
7		.003	.0008	.0423			
8		.0709		.0419	.0019		
9		.0827		.0476	.0419	.0305	.0427
10			.0594	.0937	.0705	.0423	.0522
11		.1017	.0804	.0678	.0998	.0823	.0808
12		.0956	.0587	.0747	.1055	.0956	.0937
13		.1078	.0652	.0644	.0995	.0968	.1002
14	.0594	.0907	.0945	.0716	.0412	.0846	.0827
15	.0732	.0972	.0956	.0865	.0781	.0922	.0926
16	.0876	.1006	.0469	.1071	.0808	.0884	.0503
17	.088	.0903	.0617	.1059	.0686	.0846	.0739
18	.0472	.0926	.0579	.101	.0633	.0865	.0724
19	.0549	.104	.053	.104	.053	.0171	.0091
20	.0739	.1025	.0842	.0842	.0815	.0472	.0526
21	.0663	.0865	.0686	.0674	.0633	.0591	.0594
22	.0594	.0568	.0682	.0659	.069	.0598	.0652
23	.0541	.053	.0472	.0553	.0629	.0469	.0648
24		.0278	.0434		.0621		.0461
Max	.088	.1078	.0956	.1071	.1055	.0968	.1002
Min	.0472	.003	.0008	.0419	.0019	.0171	.0091
Avg	.0664	.0802	.0616	.0754	.0672	.0650	.0649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 201 / HARATHKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.381	.3048	.381	.381
2	.2286	.2286	.2286	.381		.381	.381
3	.3048	.2286	.2286	.381		.381	.381
4	.3048	.2286	.2286	.381		.381	.381
5	.3048	.2286	.2286	.4572		.4572	.4572
6	.0762	.3048	.2286	.4572		.6097	.6097
7	.3048	.2286	.3048	.6097		.7621	.5335
8	.3048	.3048	.3048	.6097	.0762	.6859	.6859
9	.2286	.3048	.381	.5335	.2286	.6097	.5335
10	.2286	.2286	.3048	.381	.2286	.4572	.381
11	.2286	.3048		.2286	.0762	.2286	.0762
12	.0762	.2286		.1524	.0762	.2286	
13	.1524		.1524	.2286		.2286	.1524
14	.1524	.1524	.1524	.2286		.2286	.1524
15	.2286	.2286	.1524	.1524	.0762	.1524	.1524
16	.2286	.2286	.1524	.2286	.1524	.1524	.1524
17	.381	.3048	.2286	.2286	.2286	.2286	.2286
18	.381	.381	.3048	.2286	.1524	.2286	.3048
19	.4572	.5335	.4572	.4572	.5335	.5335	.5335
20	.4572	.5335	.3048	.5335	.6097	.5335	.5335
21	.381	.4572	.381	.4572	.5335	.4572	.4572
22	.381	.4572	.4572	.4572	.4572	.4572	.4572
23	.381	.381	.381	.381	.381	.381	.381
24	.3048	.381	.381	.381	.381	.381	.381
Max	.4572	.5335	.4572	.6097	.6097	.7621	.6859
Min	.0762	.1524	.1524	.1524	.0762	.1524	.0762
Avg	.2794	.3081	.2806	.3715	.2810	.3969	.3777



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 204 / 11KV EXPRESS FDR MANGRUL NON SHEDDABLE EXPRESS HV FEEDERS  
 BARRA Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0488	.0549	.0472	.0488	.0556
2		.0591	.0503	.0568	.0503	.0492	.0568
3	.0061	.0625	.0541	.0522	.0747	.0518	.056
4		.0633	.0495	.0507	.0774	.0594	.0564
5		.0633	.0465	.0476	.0667	.0537	.053
6		.0549	.0232	.0354	.0667	.0503	.0412
7		.0476			.0568	.0579	.0739
8		.0362		.0232	.0743	.069	.0781
9		.0099		.0636	.077	.0084	.0789
10		.0179		.0423	.0133	.0019	.0392
11			.0091	.0377		.0011	.0076
12			.0118	.0099	.0008	.0156	.0232
13			.045	.0553		.0442	.0164
14			.021	.0617	.0343	.0423	.0671
15			.053	.0381	.0175		.0591
16	.0019		.0213			.0004	.0217
17	.0061		.0027				.016
18			.0118	.003	.0053	.0107	.0133
19	.0503		.0472	.0511	.0392	.0499	.0533
20	.0545		.0396	.0846	.0678	.085	.0793
21	.0644		.0518	.0766	.0743	.0819	.0857
22	.0693	.0621	.0602	.0789	.0751	.0823	.0777
23	.0716	.0564	.0644	.0705	.0659	.0728	.0701
24	.0728	.0545	.0598	.0575	.0511	.0602	.0621
Max	.0728	.0633	.0644	.0846	.0774	.085	.0857
Min	.0019	.0099	.0027	.003	.0008	.0004	.0076
Avg	.0441	.0496	.0386	.0501	.0518	.0453	.0517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 201 / 11KV BORGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2812	.2382	.293	.3022	.2926	.2915	.2968
2	.3048	.1204	.3094	.3094	.3033	.3029	.2976
3	.3323	.2831	.3254	.3121	.3121	.3178	.3296
4	.4169	.314	.41	.3608	.3433	.3814	.4119
5	.5022	.4325	.5365	.5136	.4351	.5281	.4988
6	.5937	.5255	.6139	.5445	.5159	.4454	.0888
7	.546	.4786	.5243	.2785	.6443	.2481	
8	.4954	.4523	.2919		.5655	.5777	
9	.431	.3757	.3048		.4268	.4542	.3433
10	.3178	.237	.2618		.3227	.2961	.3704
11	.2218	.1844	.2088		.2229	.2351	.2778
12	.1368	.1787			.1261	.0796	.0446
13	.12	.1665					
14	.1235	.1581	.2122				
15	.1223	.1901	.2252				
16	.1528	.2724	.2275	.1749	.2366		.2884
17		.306	.2881	.2888	.3749	.3525	.3993
18		.3578	.2564	.3304	.4378	.4527	.4279
19		.3959	.4828	.5125	.4553	.5304	.439
20	.3452	.4138	.4359	.4393			
21	.3262	.3639	.3658	.3422			
22	.2751	.3193	.3456	.3231	.2671	.2359	.2382
23	.253	.2827	.2995	.2934	.3048	.3132	.2797
24	.2294	.277	.2964	.2827	.2972	.2976	.2686
Max	.5937	.5255	.6139	.5445	.6443	.5777	.4988
Min	.12	.1204	.2088	.1749	.1261	.0796	.0446
Avg	.3108	.3052	.3416	.3505	.3623	.3522	.3118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 202 / PATODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5335	.5335	.5335	.5335	.3048	.3048
2	.6097	.5335	.5335	.5335	.5335	.3048	.3048
3	.6097	.5335	.5335	.5335	.3048	.381	.3048
4	.6859	.5335	.6097	.5335	.3048	.381	.381
5	.6859	.3048	.381	.6097		.381	.4572
6	.7621			.5335		.2286	.4572
7				.5335		.381	.5335
8				.6097	.1524	.381	.6097
9				.6097		.381	.4572
10	.3048	.3048	.3048	.5335		.3048	.4572
11	.6859	.3048	.4572				
12	.6859	.381	.381		.381		
13	.6859	.381	.381		.3048		
14	.6097		.3048		.0762		
15	.6097	.3048	.3048				
16	.6097	.3048	.3048	.3048	.3048	.2286	.1524
17	.6097	.381	.381	.4572	.5335	.4572	.4572
18	.6097	.4572	.2286	.5335	.6859	.4572	.381
19	.7621	.6859	.5335	.6859	.6859	.3048	.6859
20	.5335	.7621	.6859	.6859	.6859	.6097	.6859
21		.6859	.6859	.6097	.6859	.6097	.6097
22	.5335	.6097	.6097	.6097	.6097	.5335	.6097
23	.5335	.5335	.6097	.5335	.5335	.5335	.381
24	.5335	.5335	.5335	.5335	.5335	.4572	.381
Max	.7621	.7621	.6859	.6859	.6859	.6097	.6859
Min	.3048	.3048	.2286	.3048	.0762	.2286	.1524
Avg	.6135	.4773	.4649	.5535	.4617	.4011	.4532

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 203 / IDOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.3048	.6859	.7621	.6859	.6859	.6859
2	.9907	.381	.6859	.7621	.7621	.7621	.7621
3	.5335	.381	.6859	.7621	.7621	.8383	.7621
4	.5335	.381	.7621	.8383		.8383	.8383
5	.6097	.4572	.6859	.8383		.4572	.5335
6	.6859	.5335	.6097				
7	.8383	.381	.5335				
8	1.0669	.381	.5335				
9	1.0669	.381	.4572				
10	.6859	.3048	.5335	.3048		.3048	
11				.6097		.4572	
12				.6097		.381	
13				.6097	.2286	.381	
14				.4572	.381	.381	
15				.4572	.2286	.3048	.381
16			.0762	.4572	.3048	.3048	.381
17	1.2955		.6859	.5335	.381	.3048	.381
18	1.2955	.7621	.6859	.6097	.4572	.5335	.6859
19	.9907	.8383	.7621	.8383	.6097		.7621
20	.8383	.8383	.8383	.8383	.8383	.8383	.7621
21	.6097	.8383	.8383	.7621	.7621	.7621	.7621
22	.381	.7621	.8383	.6097	.6859	.7621	.7621
23	.381	.6859	.7621	.6859	.6859	.6859	.6859
24	.3048	.6859	.6859	.6859	.6859	.6859	.6859
Max	1.2955	.8383	.8383	.8383	.8383	.8383	.8383
Min	.3048	.3048	.0762	.3048	.2286	.3048	.381
Avg	.7833	.5469	.6498	.6516	.5639	.5615	.6554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 204 / KAWAJAWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.3048	.381	.6859	.7621	.5335	.6859
2	.6097	.3048	.381	.6859	.7621	.5335	.6859
3	.6097	.3048	.381	.7621	.7621	.5335	.7621
4	.5335	.3048	.381	.7621	.6859	.6097	.8383
5	.6097	.381	.3048	.9145	.6859	.6097	.9145
6	.5335	.4572	.4572	.8383	.7621	.5335	.6859
7	.6859	.4572	.4572	.4572	.7621	.4572	
8	.6097	.4572	.381	.1524	.5335		
9	.6097	.4572	.4572	.2286	.381		
10	.4572	.4572	.4572	.381	.3048	.3048	.381
11	.381	.381	.381	.4572	.381	.381	.4572
12	.3048	.381	.381	.4572	.381	.3048	.4572
13	.3048	.381	.381	.4572	.381	.3048	.381
14	.3048	.3048	.3048	.4572	.3048	.2286	.3048
15	.3048	.381	.3048	.4572	.381	.2286	.3048
16	.3048	.4572	.3048	.4572	.381	.2286	.381
17	.4572	.5335	.381	.4572	.4572	.3048	.381
18	.5335	.381	.3048	.4572	.381	.3048	.381
19	.5335	.2286	.2286	.5335	.381	.3048	.4572
20	.4572	.8383	.9145	.9145	.6859	.6097	.8383
21	.381	.7621	.9145	.8383	.6859	.8383	.7621
22	.5335	.6859	.8383	.8383	.6097	.8383	.7621
23	.5335	.6859	.7621	.7621	.6097	.7621	.7621
24	.381	.6097	.7621	.7621	.5335	.6859	.6859
Max	.6859	.8383	.9145	.9145	.7621	.8383	.9145
Min	.3048	.2286	.2286	.1524	.3048	.2286	.3048
Avg	.4827	.4541	.4667	.5906	.5398	.4746	.5843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 207 / 11 KV AMBA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335					
2	.5335					
3	.5335					
4	.4572					
5	.4572					
6	.4572					
7		.0762				
8		.1524				
9		.0762				
10		.0762	.0762			
11			.1524	.0762		.0762
12			.1524	.0762		.0762
13			.1524	.0762	.0762	
14			.0762	.0762		
15			.1524			.0762
16			.1524		.0762	
17			.1524			.0762
18			.0762			.0762
Max	.5335	.1524	.1524	.0762	.0762	.0762
Min	.4572	.0762	.0762	.0762	.0762	.0762
Avg	.4954	.0953	.127	.0762	.0762	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 201 / TAKALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.0762	.0762				
2	.2286	.0762	.0762				
3	.1524	.0762	.0762				
4	.1524	.0762	.0762				
5	.1524	.0762	.0762	.0762			.0762
6	.1524		.0762	.0762	.0762		
7	.2286	.1524	.0762	.1524	.1524		
8	.2286	.1524	.0762	.0762	.1524		
9	.1524	.1524	.1524	.0762	.0762		
10	.1524	.0762	.1524	.0762	.0762	.0762	.0762
11				.2286	.0762	.1524	.0762
12				.2286	.0762	.1524	.1524
13				.2286	.1524	.1524	.1524
14				.1524	.1524	.1524	.0762
15				.1524	.0762	.1524	.0762
16				.2286	.0762	.1524	.0762
17				.2286	.0762	.1524	.0762
18				.2286	.0762	.0762	.0762
19	.0762	.0762	.0762			.0762	
20	.0762	.0762	.0762	.0762	.0762	.0762	
21		.0762	.0762		.0762	.0762	
22			.0762				
23		.0762					
24	.0762	.0762					
Max	.2286	.1524	.1524	.2286	.1524	.1524	.1524
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1583	.0925	.0871	.1524	.0965	.1207	.0914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 202 / KHANDVI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8383	.9145	.6859	.6859	.4572	.381
2	.9145	.8383	.9145	.6859	.6859	.4572	.381
3	.9907	.8383	.9907	.6859	.6859	.4572	.381
4	.9907	.8383	1.0669	.7621	.381	.4572	.4572
5	1.1431	1.0669	1.2193	.7621	.7621	.6097	.5335
6	1.448	1.2955	1.5242	.7621		.8383	.6859
7	1.5242	1.3717	1.6004	.9907		.8383	.7621
8	1.3717	1.2955	1.2955	.9145		.7621	.7621
9	1.0669	.9907	1.1431	.8383		.6097	.7621
10	.8383	.3048	.6097	.8383		.6097	.0762
11	.7621	.6097	.6859	.5335			
12	.7621	.6097	.7621	.4572			
13	.8383	.6097	.6859	.5335			
14	.9907	.6097	.6859	.4572			
15	1.0669	.6097	.6859	.4572	.5335		
16	1.0669	.6097	.6859	.4572	.8383	.4572	.5335
17	1.0669	.3048	.6097	.6097	.8383	.6859	.6859
18	1.0669	.6097	.6859	.6859	.9145	.7621	.7621
19	.9907	1.0669	.9907	1.0669	1.0669	1.0669	1.0669
20	.9907	1.1431	1.1431	1.1431	1.1431	1.2193	1.1431
21	.9907	1.0669	1.0669	1.0669	1.0669	1.0669	.9907
22	.9145	1.0669	1.0669	1.0669	1.0669	.9907	.9907
23	.9145	.9907	.9907	.9907	.9907	.9907	.9907
24	.8383	.9145	.9145	.9145	.9145	.9145	.9145
Max	1.5242	1.3717	1.6004	1.1431	1.1431	1.2193	1.1431
Min	.7621	.3048	.6097	.4572	.381	.4572	.0762
Avg	1.0193	.8542	.9558	.7653	.8383	.7500	.6979



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 203 / USMANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.1524		.3048	.3048	.2286
2	.6859		.1524		.3048	.3048	.3048
3	.6097		.1524		.3048	.3048	.3048
4	.5335		.2286		.0762	.3048	.3048
5	.5335		.2286		.381		.381
6	.381		.3048		.4572		.1524
7	.6097		.381		.6859		
8	.6859		.2286		.6859		
9	.6859		.2286		.5335		
10	.5335		.2286		.4572		.2286
11	.4572		.2286		.4572	.3048	.381
12	.3048		.1524		.381	.2286	.4572
13	.3048		.0762		.381	.2286	.4572
14	.2286		.0762	.3048	.4572	.2286	.381
15	.2286		.0762	.381	.381	.2286	.381
16	.2286		.0762	.4572	.381	.2286	.381
17	.2286		.1524	.4572	.4572	.5335	.4572
18	.4572		.1524	.4572	.5335	.4572	.381
19	.5335	.381	.1524	.381	.4572	.381	.1524
20	.4572	.5335	.1524	.5335	.4572	.381	.3048
21	.3048	.4572		.4572	.3048	.381	.3048
22	.2286	.381		.381	.3048	.3048	.3048
23		.381		.381	.3048	.2286	.3048
24		.3048		.3048	.3048	.2286	.3048
Max	.6859	.5335	.381	.5335	.6859	.5335	.4572
Min	.2286	.3048	.0762	.3048	.0762	.2286	.1524
Avg	.4503	.4064	.1791	.4087	.4064	.3090	.3266

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 201 / TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.7621	.7621	.7621	.8383	.7621
2	.6859	.7621	.7621	.7621	.7621	.7621	.7621
3	.6859	.6859	.6859	.6859		.7621	.7621
4	.6859	.6859	.6859	.6859		.7621	.7621
5	.7621	.7621	.7621	.7621		.8383	.8383
6	.9145	.9145	.9145	.9907		.9907	.2286
7	1.1431	1.0669	1.1431	1.2193		1.2193	
8	1.2193	1.1431	1.1431	1.2193		1.2193	
9	1.2193	1.1431	1.1431	1.2193		1.2193	1.3717
10	1.1431	.9907	1.1431	1.0669	1.2955	1.0669	1.0669
11	1.0669	.9907	1.0669	.9907	.6097	.4572	.1524
12	.9907	.9145		.9145			
13	.9145	.8383		.8383			
14	.9145	.8383		.8383	1.2193	.9907	.9145
15	.8383	.7621		.8383	1.2193	1.0669	.9145
16	.8383	.8383	.7621	.8383	1.1431	1.1431	.8383
17	.9145	.9145	1.2193	.9145	1.2193	1.2193	1.2193
18		.9145	.4572	.7621	.7621	.2286	.3048
19	.3048		1.2955				
20	1.0669		1.3717				
21	1.0669	1.1431	1.0669	1.2955	1.2955	1.2193	1.1431
22	.9145	1.1431	1.0669	1.2193	1.2955	1.2193	1.0669
23	.8383	.9145	.9145	.9907	1.0669	1.0669	.9907
24	.7621	.8383	.8383	.8383	.9145	.9145	.8383
Max	1.2193	1.1431	1.3717	1.2955	1.2955	1.2193	1.3717
Min	.3048	.6859	.4572	.6859	.6097	.2286	.1524
Avg	.8979	.9076	.9602	.9387	1.0435	.9602	.8298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 202 / RAMKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.0669	1.0669	1.1431	.6859	.9907	.9907
2	1.2193	1.1431	1.1431	1.2193	1.2193	1.0669	.9907
3	1.1431	1.2193	1.2193	1.2955	1.2193	1.0669	1.0669
4	1.2955	1.5242	1.448	1.5242	1.3717	1.2955	1.2193
5	1.448	1.6766	1.829	1.829	1.6004	1.5242	1.2955
6		1.829	1.448	1.829	1.7528	1.5242	
7	.4572	1.5242	.0762	.0762	1.6004	1.2955	1.7528
8	1.448	1.2955	.381	1.1431	1.2955	1.0669	1.6766
9	1.2955	1.0669	1.6766	.9145	1.2955	.9907	1.2955
10	1.0669	.7621	1.3717	.5335		.6097	.9907
11	.7621	.6097	.6859	.381		.6097	
12	.6859	.5335	.6859	.6859		.4572	
13	.6097	.5335	.6097	.6097		.6097	
14	.6097	.381	.6097	.6859	.6097	.6097	
15	.5335	.0762	.6097	.6859	.5335		.0762
16	.6097	.4572	.381	.6097	.6097	.3048	.4572
17	.2286	.6097	.381	.4572	.6859	.6859	.5335
18	.0762	.8383	.6097	.9145	.8383	.7621	1.0669
19	1.6766	.0762	1.6766	1.3717	1.3717	1.6004	1.1431
20	1.5242	1.5242	1.7528	1.7528	1.2955	1.2955	1.2955
21	1.2955	1.448	1.448	1.6004	1.2193	1.2193	1.1431
22	1.2193	1.2955	1.2955	1.3717	1.2193	1.1431	1.0669
23	1.0669	1.1431	1.1431	1.2193	.9907	.9145	.9145
24	1.0669	1.0669	1.0669	1.1431	.8383	.9145	.9145
Max	1.6766	1.829	1.829	1.829	1.7528	1.6004	1.7528
Min	.0762	.0762	.0762	.0762	.5335	.3048	.0762
Avg	.9775	.9875	1.0256	1.0415	1.1126	.9808	1.0468

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 203 / AMBADGAON-AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.381	.381	.3048	.4572	.4572
2	.3048		.381	.381	.1524	.381	.4572
3	.3048		.381	.381		.381	.4572
4	.3048		.381	.381		.4572	.4572
5	.381		.381	.4572		.5335	.4572
6			.5335	.5335		.5335	
7			.5335	.6097		.381	
8			.6097	.6859		.8383	
9		.381	.6097	.6097	.0762	.7621	.2286
10	.1524	.381	.6097	.5335	.4572	.6859	.1524
11	.0762	.3048	.3048	.2286	.3048	.2286	.0762
12	.381	.2286	.2286	.1524	.2286	.1524	.3048
13	.381	.1524	.1524				.0762
14	.381		.1524				
15	.3048		.0762		.1524	.0762	
16	.3048	.2286	.1524	.1524	.2286	.2286	
17		.3048	.2286	.2286	.3048	.2286	
18		.381	.3048	.2286	.4572	.381	
19		.4572	.4572	.4572	.4572	.4572	
20	.3048	.0762	.381		.3048		.0762
21	.3048		.3048				
22			.3048				
23		.3048	.3048	.3048	.3048	.3048	.381
24		.381	.381	.3048	.4572	.381	.5335
Max	.381	.4572	.6097	.6859	.4572	.8383	.5335
Min	.0762	.0762	.0762	.1524	.0762	.0762	.0762
Avg	.2994	.2985	.3556	.3895	.2994	.4131	.3165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 204 / KUSALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.9145	.8383	.9145	.8383	.9145
2	.8383	.7621	.9907	.8383	.9145	.8383	.8383
3	.8383	.7621	.9907	.9145	.9145	.8383	.9145
4	.9145	.8383	1.0669	.9907	.9145	.9145	.9907
5	.9907	.9145	1.2955	.9907	.9907	.9907	1.2193
6	.9907		1.448	1.3717	1.1431	1.2955	.6859
7	.9145	1.448	1.448	1.448	.9907	1.3717	1.5242
8	.9145	1.3717	1.2955	1.2955	.9907	1.2955	1.5242
9	.9145	1.2193	.9907	1.1431	.9907	1.1431	1.2955
10	.8383	.9907	1.0669	.9907	.7621	.9907	.8383
11	.6859	.6859	.6859	.7621	.5335	.6859	.6097
12	.6097	.6859		.7621	.5335	.6859	.6859
13	.5335	.6859		.7621	.6097	.6097	.6859
14	.3048	.6859		.7621	.6097	.6097	.6859
15	.6097	.6859		.6859	.6097	.6097	.6097
16	.6097	.6859	.5335	.7621	.6097	.6859	.4572
17	.7621	.6097	.8383	.8383	.6097	.7621	.7621
18	.8383	.7621	.9145	.9145	.3048	.7621	1.1431
19	1.1431	1.1431	.7621	1.3717	1.2193	1.2955	1.1431
20	1.0669	1.1431	1.448	1.5242	1.2193	1.3717	1.1431
21	.9907	1.1431	1.3717	1.1431	1.0669	1.1431	1.0669
22	.9145	1.1431	1.2193	1.2193	1.1431	1.0669	.9907
23	.7621	.9907	1.0669	1.0669	.9907	.9907	.9145
24	.7621	.9145	.9907	.9907	.9145	.9907	.8383
Max	1.1431	1.448	1.448	1.5242	1.2193	1.3717	1.5242
Min	.3048	.6097	.5335	.6859	.3048	.6097	.4572
Avg	.8129	.9145	1.0669	1.0161	.8542	.9494	.9367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 205 / ROSHANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.381	.4572	.4572		.5335	.4572
2	.9145	.381	.4572	.5335		.4572	.4572
3	.9907	.4572	.5335	.5335		.4572	.4572
4	1.0669	.4572	.5335	.6097		.4572	.4572
5	1.2955	.4572	.6097	.6859		.5335	.5335
6	1.448	.6097	.6859	.7621		.6859	
7	1.2955	.6097	.7621	.8383		.8383	
8	.9145	.6859	.7621	.9145		.8383	
9	.8383	.6097	.7621	.9145		.8383	
10	.6859	.6097	.8383	.7621		.6859	
11	.381	.6097	.7621	.1524		.6859	
12	.4572	.5335	.6097		.1524	.4572	
13	.4572	.5335	.5335		.6859	.4572	.8383
14	.381	.4572	.5335		.6859	.381	.5335
15	.381	.4572	.5335		.4572		
16	.381	.4572	.4572	.2286	.6859	.0762	
17	.5335	.8383	.6859	.6859	.7621	.6859	
18	.6097	1.1431	.9145	.9145	.9907	.9907	
19	.5335	1.448	1.1431	1.0669	1.0669	1.2193	
20	.5335	1.3717	1.1431	1.2193	1.1431	1.1431	.3048
21	.4572	1.0669	1.0669	1.0669	.4572	.9145	.9907
22	.4572	1.0669	.9145	.9145	1.0669	.8383	.9145
23	.381	.9907	.8383	.8383	.9907	.7621	.8383
24	.381	.6097	.7621	.5335	.8383	.6859	.7621
Max	1.448	1.448	1.1431	1.2193	1.1431	1.2193	.9907
Min	.381	.381	.4572	.1524	.1524	.0762	.3048
Avg	.6922	.7017	.7208	.7316	.7679	.6792	.6287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 207 / WARUDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.3048	.3048	.3048	.3048	.3048	.3048
2	.5335	.3048	.3048	.3048	.3048	.3048	.3048
3	.5335	.3048	.3048	.3048	.3048	.3048	.3048
4	.5335	.3048	.3048	.3048	.3048	.3048	.3048
5	.6097	.3048	.381	.3048	.381	.381	.381
6		.381	.4572	.4572	.381	.3048	.4572
7	.9907	.4572	.4572	.6097	.5335	.5335	.4572
8	.9145	.381	.5335	.6097	.5335	.6097	.4572
9	.8383	.381	.5335	.5335	.5335	.6097	.4572
10	.6097	.3048	.381	.4572	.5335	.4572	.4572
11	.381	.2286	.381	.381	.4572	.2286	.4572
12	.3048	.2286	.3048	.2286	.3048	.1524	.381
13	.3048	.2286	.3048	.2286	.3048	.1524	.3048
14	.3048	.2286	.3048	.2286	.3048	.1524	.3048
15	.2286	.2286	.3048	.1524	.3048	.1524	.3048
16	.3048	.381	.3048	.2286	.3048	.1524	.3048
17	.3048	.381	.2286	.3048	.4572	.1524	.381
18	.1524	.4572	.3048	.381	.4572	.381	.381
19	.381	.6097	.5335	.6097	.6097	.6097	.5335
20	.381	.6859	.6859	.7621	.381	.6859	.6097
21	.381	.6097	.6097	.6859	.6097	.6097	.5335
22	.3048	.6097	.6097	.6097	.6097	.5335	.5335
23	.3048	.5335	.5335	.5335	.5335	.5335	.4572
24	.3048	.381	.5335	.4572	.5335	.4572	.3048
Max	.9907	.6859	.6859	.7621	.6097	.6859	.6097
Min	.1524	.2286	.2286	.1524	.3048	.1524	.3048
Avg	.4539	.3842	.4128	.4160	.4287	.3779	.4032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 206 / W/W EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		***				
7		***	***	***		***
8	***	***	***	***	***	***
9	***				***	***
10		***		***		***
11	***	***	***	***	***	***
12	***		***		***	***
13	***	***			***	
14		***	***	***		***
15	***	***	***	***	***	***
16	***	***	***			***
17				***	***	***
18		***	***	***	***	***
19	***	***	***	***		***
20		***	***	***		***
21	***		***	***		
22	***			***		
24	***					
Max	38.104	38.104	38.104	38.104	38.104	38.104
Min	38.104	38.104	38.104	38.104	38.104	38.104
Avg	38.104	38.104	38.104	38.104	38.104	38.104



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 201 / NALNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335		.381	.381	.3048	.1524	.3048
2	.5335		.381	.381	.381		.381
3	.5335		.381	.381	.381		.381
4	.6097		.4572	.381	.381		.381
5	.6859		.6097	.5335	.4572		.4572
6	.7621		.1524	.6097	.6097		.6097
7	.7621			.6097	.6859		.6859
8	.7621		.9145	.7621	.8383		.9145
9	.6859		.8383	.8383	.8383		.9145
10	.6097		.6097	.7621	.7621	.381	.8383
11	.6859		.6097	.381	.381	.4572	
12	.7621		.6097	.2286	.3048	.381	
13	.7621		.5335	.3048	.2286	.381	
14	.6859	.3048	.5335	.3048	.2286	.3048	
15	.6097	.3048	.4572	.3048	.2286	.3048	
16	.6097	.381	.6097	.3048	.3048	.381	.3048
17	.5335	.381	.6097	.4572	.381	.381	.381
18	.6097	.4572	.6097	.6859	.4572	.6097	.7621
19	.8383	.7621	.8383	.7621	.6097	.8383	.8383
20	.8383	.6859	.7621	.7621	.8383	.7621	.7621
21		.5335	.6859	.5335	.6859	.6097	.6859
22		.4572	.5335	.5335	.5335	.6097	.6097
23		.381	.5335	.3048	.5335	.5335	.381
24		.381	.381	.3048	.381	.4572	.381
Max	.8383	.7621	.9145	.8383	.8383	.8383	.9145
Min	.5335	.3048	.1524	.2286	.2286	.1524	.3048
Avg	.6707	.4572	.5666	.4922	.4890	.4715	.5776

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 202 / PASODI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.5335	.381	.381	.381	.381	.3048
2	.7621	.6097	.381	.381	.381	.381	.381
3	.8383	.6097	.381	.381	.4572	.381	.381
4	.8383	.6097	.4572	.4572	.4572	.381	.381
5	.9907	.6097	.5335	.4572	.5335	.4572	.4572
6	.9907	.6859	.6859	.5335	.6097	.5335	.6097
7	1.1431	.8383	.7621	.6097	.6097	.5335	.6859
8	1.0669	.9907	.6859	.381	.5335	.381	.5335
9	1.1431	1.2193	.5335	.381	.381	.3048	.4572
10	.9907	1.2193	.7621	.4572	.5335	.2286	.3048
11	.2286	.2286	1.448	1.2955	1.0669	.381	
12	.1524	.1524	1.5242	1.2955	1.3717	.4572	.381
13	.1524	.1524	1.6004	1.5242	1.3717	.4572	.381
14	.1524	.2286	1.448	1.5242	1.3717	.4572	.381
15	.1524	.2286	1.3717	1.5242	1.3717	.5335	
16	.1524	.2286	1.2193	1.2955	1.2955	.5335	
17	.3048	.3048	1.1431	1.2193	1.3717	.5335	
18	.4572	.4572	1.1431	1.1431	1.2193	.5335	
19	.5335	.6097	.5335	.5335	1.0669	.381	.1524
20	.6097	.6097	.5335	.4572	.4572	.381	.381
21	.4572	.4572	.4572	.381	.381	.381	.3048
22	.4572	.4572	.381	.381	.3048	.381	.3048
23	.381	.4572	.381	.381	.3048	.3048	.3048
24	.5335	.381	.381	.381	.3048	.3048	.2286
Max	1.1431	1.2193	1.6004	1.5242	1.3717	.5335	.6859
Min	.1524	.1524	.381	.381	.3048	.2286	.1524
Avg	.5938	.5366	.7970	.7398	.7557	.4160	.3850

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 203 / KADRABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6767	.5571	.6889	.663	.7293	.7194	.663
2	.6356	.535	.6432	.631	.6737	.6508	.602
3	.5998	.5175	.6005	.602	.6272	.6485	.5799
4	.6028	.5258	.5921	.5883	.618	.6188	.5799
5	.6203	.5655	.6142	.628	.6638	.7087	.6836
6	.7423	.6584	.6859	.759	.833	.9252	.8421
7	.8398	.8551	.8131	.7674	.2362	.9343	
8	.8741	.8848	.8688			.9534	
9	.8528	.8307	.8406			.8703	
10	.8436	.7788					
11	.791	.7857	1.0639	1.2605	1.1576	.9686	
12	.7766	.7781	.9488	1.0082	.9854	.8169	
13	.775	.7468	.8497	.9069	.9175	.7796	1.15
14	.7484	.727	.7987	.8672	.8093	.8139	1.0982
15	.7156	.7278	.7987	.7743	.8703	.7834	.9717
16	.692	.6904	.7301	.7651	.7964	.7606	.8711
17	.7324						
18	.7788		.4252				
19	.7926		1.1553				
20	.9008	1.1271	1.1614	1.2529	1.0905	1.0303	1.1957
21	.8787	1.1873	1.0547	1.3085	1.3275	1.1302	1.2216
22	.7522	1.0456	.945	1.1309	1.2117	1.0242	1.0364
23	.6775	.9244	.8162	1.0014	1.0357	.8901	.9496
24	.6295	.7804	.7354	.8627	.8512	.7743	.8177
Max	.9008	1.1873	1.1614	1.3085	1.3275	1.1302	1.2216
Min	.5998	.5175	.4252	.5883	.2362	.6188	.5799
Avg	.7470	.7728	.8105	.8765	.8575	.8401	.8842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 205 / JINDAL COMPLEX INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0191	.0191	.0191	.0191	.0191	.0191
2	.0381	.0191	.0191	.0191	.0191	.0191	.0191
3	.0381	.0191	.0191	.0191	.0191	.0191	.0191
4	.0381	.0191	.0191	.0191	.0191	.0191	.0191
5	.0381	.0191	.0191	.0191	.0191	.0191	.0191
6	.0381	.0191	.0191	.0191	.0191	.0191	.0191
7			.0191	.0191	.0191	.0191	
8	.0191	.0191	.0191	.0191	.0191	.0191	
9	.0191	.0191	.0191	.0191	.0191	.0191	
10	.0381	.0191	.0191	.0191	.0381	.0191	
11	.0762	.0381	.0381	.0572	.0381	.0381	
12	.0762	.0572	.0191	.0381	.0572	.0381	
13	.0572	.0572	.0191	.0191	.0381	.0191	.0381
14	.0381	.0381	.0191	.0191	.0381	.0381	.0381
15	.0572	.0381	.0191	.0191	.0381	.0191	.0381
16	.0762	.0381	.0191	.0191	.0381	.0381	.0381
17	.0572	.0381	.0381	.0191	.0381	.0191	.0381
18	.0762	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0572	.0381	.0381	.0381	.0191	.0381	.0572
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0191	.0381	.0191	.0191	.0191
23	.0191	.0381	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0762	.0572	.0381	.0572	.0572	.0381	.0572
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0447	.0315	.0239	.0254	.0286	.0254	.0297

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 206 / Mangal Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0128	.9175	1.0395	.996	1.0547	1.057	.993
2	.98	.8939	.9953	.9656	1.0082	.9823	.9648
3	.9556	.8893	.9717	.9511	.9838	.9785	.9442
4	.9884	.9099	1.0052	.977	.9831	1.0341	.9892
5	1.1271	1.0585	1.1439	1.0623	1.1614	1.31	1.2666
6	1.3611	1.3176	1.374	1.4586	1.563	1.7939	1.7124
7	1.7528	1.624	1.6872	1.3573	.2629	1.8785	
8	1.8412	1.7375	1.8419			1.97	
9	1.9136	1.6545	1.5851			1.9143	
10	1.7756	1.5455					
11	1.6392	.6036	.9777	.9564	.6249	.8208	
12	1.7101	1.5424	1.8846	1.8663	1.8671	1.7429	
13	1.4259	1.2856	1.4929	1.5127	1.6522	1.4579	1.6491
14	1.3565	1.1218	1.2841	1.3679	1.4701	1.3115	1.8061
15	1.1416	1.0783	1.198	1.342	1.4723	1.3291	.5106
16	1.1317	.0526		.1608	.2103	.0343	
17	1.3573						
18	1.669		.9122				.0038
19	1.579		1.8869				.0046
20	1.6065	2.1064	1.9372	1.9303	2.0287	1.8564	2.0317
21	1.3809	1.9867	1.6811	2.0972	2.0927	1.8983	1.8793
22	1.2498	1.5722	1.422	1.6956	1.7215	1.5539	1.5905
23	1.1233	1.3496	1.262	1.406	1.4327	1.3451	1.438
24	.9938	1.1401	1.0921	1.1942	1.2026	1.1393	1.2109
Max	1.9136	2.1064	1.9372	2.0972	2.0927	1.97	2.0317
Min	.9556	.0526	.9122	.1608	.2103	.0343	.0038
Avg	1.3780	1.2565	1.3655	1.2943	1.2662	1.3704	1.1872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 201 / 11 kv Sarswati Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6539	.6638	.6409	.663	.6386	.6165
2	.6622	.6318	.6516	.628	.6341	.6081	.6013
3	.6523	.618	.6478	.6219	.6211	.602	.5982
4	.6577	.6272	.6661	.6417	.6226	.599	.6074
5	.6805	.695	.7674	.7362	.7019	.6722	.6592
6		.7781	.9038	.8383	.8269	.8528	.7727
7	.7278	.8932	.9503	1.086	1.0715	1.0875	1.0021
8	.8291	1.0402	1.1119	1.1363	1.102	1.0707	1.0159
9	.7019	.913	1.041	1.0974	1.0822	1.0044	.9869
10	.66	.8657	.9442	.9442	.9915	.8985	.9358
11	.5121	.7004	.8535	.7849	.8246	.8101	.775
12	.4801	.6127	.7247	.6683	.6615	.6554	.6546
13	.4656	.6165	.6744	.676	.5746	.5639	.5632
14	.4603	.5403	.6394	.6562	.5975	.6592	.554
15	.4115	.5403	.6074	.6455	.5586	.5617	.5167
16	.2576	.6173	.6257	.6783	.57	.6097	.5403
17	.7209	.6379	.7316	.7034	.644	.6211	.57
18	.8932	.8322	.7842	.7103	.7407	.7621	.708
19		.9244	.9031	.9496	.9099	.9229	.791
20		.9739	1.0105	.9922	.9534	.9633	.8596
21		.8817	.9046	.8909	.8459	.7819	.7827
22		.7941	.8208	.8131	.8314	.7377	.7506
23	.0617	.7545	.7453	.7872	.7743	.7049	.6874
24	.6996	.6965	.679	.7004	.6752	.6516	.6462
Max	.8932	1.0402	1.1119	1.1363	1.102	1.0875	1.0159
Min	.0617	.5403	.6074	.6219	.5586	.5617	.5167
Avg	.5895	.7433	.7938	.7928	.7699	.7516	.7165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 202 / 11 KV Bholeshwar Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2932	1.2132	1.31	1.291	1.3268	1.2803	1.2765
2	1.259	1.1927	1.2666	1.2269	1.2529	1.2308	1.2292
3	1.2605	1.1759	1.2468	1.2148	1.2399	1.2437	1.2193
4	1.2917	1.1744	1.3032	1.2498	1.2468	1.3146	1.2651
5	1.4761	1.2711	1.4091	1.3893	1.3565	1.5021	1.5318
6	1.6461	1.5287	1.6438	1.7253	1.5104	2.0469	1.7261
7	1.9829	1.8945	2.063	2.1826	.3749	1.9403	
8	2.098	1.9906	2.239			2.2634	
9	2.0881	1.9502	.1745			.4687	
10	1.9456	1.7154					
11	1.8808	1.8785	2.1635	2.1879	2.223	.2865	2.3091
12	1.7825	1.7132	1.97	2.0127	2.0218	1.9174	2.114
13	1.6758	1.5127	1.7886	1.7055	1.7657	1.8221	1.6857
14	1.4015	1.3618	1.5234	1.5409	1.7032	1.6423	1.6103
15	1.3291	1.3626	1.4358	1.4861	1.6644	1.5821	1.6941
16	1.4495						
17	1.8374						
18	2.0431		2.0645				
19			2.2779				
20		2.1178	2.1651	2.4348	2.3449	1.8633	2.2428
21		1.9921	1.8846	2.1651	2.1872	1.7307	1.9662
22		1.765	1.704	1.7406	1.8846	1.6339	1.7535
23	.8352	1.5836	1.5158	1.6034	1.656	1.5402	1.5082
24	1.3237	1.4068	1.355	1.4312	1.4121	1.3672	1.3237
Max	2.098	2.1178	2.2779	2.4348	2.3449	2.2634	2.3091
Min	.8352	1.1744	.1745	1.2148	.3749	.2865	1.2193
Avg	1.5950	1.5900	1.6431	1.6816	1.5983	1.5093	1.6535

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 201 / 11 KV Gokulnagari feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7895	.6813	.7781	.7697	.8444	.7865	.7506
2	.7385	.6653	.74	.7316	.7926	.8048	.711
3	.7255	.6622	.7156	.7156	.7491	.8794	.7004
4	.7247	.6737	.7011	.7225	.7377	.8291	.7202
5	.7849	.7263	.7651	.7888	.8139	.9137	.8512
6	.9267	.9427	.9381	1.0235	1.1126	1.1485	1.0822
7	1.1446	1.1424	1.1507	.6996	1.0067	.5746	.1417
8	1.0326	1.1446	1.1782			1.1774	
9	1.1515	1.1035	.5274			.945	
10	1.0273	.9267					
11	.9175	.9191	1.3108	1.387	1.2048	.9915	1.1256
12	.8109	.8627	1.2285	1.0898	1.1043	.8787	1.0349
13	.7735	.8154	.9808	.9854	.9793	.9015	.9099
14	.7842	.7613	.8101	.9259	.9175	.884	.9678
15	.7004	.6775	.7971	.8596	.8619	.8215	.9236
16	.6859	.6821	.7545	.8139	.8551	.833	.8192
17	.7263						
18	.7971		.0472				
19	.8413		1.1827				
20	1.0227	1.166	1.2216	1.4129	1.3573	1.2224	1.2132
21	.9884	1.3428	1.1683	1.3855	1.374	1.2719	1.1172
22	.945	1.2109	1.1203	1.2711	1.2277	1.1187	1.0555
23	.836	1.0517	.9983	1.1119	1.1043	.961	.9983
24	.7385	.8863	.8467	.9595	.8909	.8291	.8459
Max	1.1515	1.3428	1.3108	1.4129	1.374	1.2719	1.2132
Min	.6859	.6622	.0472	.6996	.7377	.5746	.1417
Avg	.8589	.9069	.9073	.9808	.9963	.9386	.8871



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 202 / 11 KV Dukhi Nagar SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4038	1.2673	1.4708	1.4243	1.4792	1.3519	1.3893
2	1.3352	1.2231	1.3801	1.3603	1.3763	1.2567	1.3176
3	1.3024	1.2094	1.3512	1.3199	1.3176	1.5287	1.2833
4	1.3359	1.2071	1.342	1.3321	1.3047	1.2971	1.3207
5	1.4358	1.2506	1.4487	1.4464	1.4274	1.4335	1.5417
6	.5571	1.5524	1.7162	1.8397	1.8359	1.9578	.4854
7	1.025	1.9997	1.8564	.7583	1.0905	.4367	
8	2.3099	2.021	2.2192			2.3175	
9	2.4935	1.8892	.4672			1.3702	
10	2.5248	1.9143					
11	2.4882	1.9936	2.7755	2.7458	2.8075	2.3922	.0747
12	2.2367	1.8724	2.5918	2.5568	2.6825	2.2413	2.5202
13	2.0828	1.8351	2.1125	2.1407	2.3312	2.3251	
14	2.0165	1.704	1.9654	2.0858	2.0546	2.1856	
15	1.5882	1.5882	1.9082	1.9342	1.9806	2.111	2.6711
16	1.5188	1.1812	1.5874	1.3702	1.4571	1.5127	
17	1.8686						
18	2.1072		.6051				
19	1.9425		2.4508				
20	1.9029	2.8197	2.6467	2.8753	2.8586	2.4989	2.6475
21	1.8465	2.6757	2.3518	2.7389	2.7008	2.4356	2.2763
22	1.6949	2.2016	2.0401	2.2641	2.3396	2.1338	2.1087
23	1.5699	1.9342	1.8054	1.9806	2.0218	1.8541	1.925
24	1.3839	1.6408	1.5905	1.6667	1.7032	1.5043	1.781
Max	2.5248	2.8197	2.7755	2.8753	2.8586	2.4989	2.6711
Min	.5571	1.1812	.4672	.7583	1.0905	.4367	.0747
Avg	1.7488	1.7610	1.8038	1.8800	1.9316	1.8072	1.6673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA

Feeder No / Name : 201 / TOWN-4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.9145	.9145	.9145	.9145	.9145
2	.6097	.6097	.6097	.6097	.6097	.6097	.6097
3	.6097	.6097	.6097	.6097	.6097	.6097	.6097
4	.6097	.6097	.6097	.6097	.6097	.6097	.6097
5	.6097	.6097	.6097	.6097	.6097	.6097	.6097
6	.6097	.6097	.9145	.9145	.6097	.6097	.9145
7		.9145	.9145	.9145	.9145	.6097	.9145
8		.9145	.9145	.9145	.9145	1.2193	.9145
9	1.2193	.9145	.9145	.9145	.9145	1.2193	1.2193
10	1.2193	.9145	.9145	1.2193	.6097	1.2193	1.2193
11	1.2193	.9145	.9145	1.2193		1.2193	1.2193
12	1.2193	.9145	.9145	1.2193		1.2193	
13	1.2193		.9145	.9145		.9145	
14	1.2193	1.2193			1.5242		1.2193
15	.9145	.9145			1.2193		1.2193
16	.9145	.9145			1.2193		.9145
17	.9145		1.2193	1.2193		1.2193	
18	1.2193		1.2193	1.2193		1.2193	
19	.9145		1.2193	1.5242		1.2193	
20	1.2193	1.5242	1.2193	1.5242	1.5242	1.2193	1.5242
21	1.2193	1.5242	1.2193	1.2193	1.5242	1.2193	1.2193
22	1.829	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
23		1.2193	.9145	1.2193	1.2193	.9145	.9145
24	.9145	.9145	.9145	.9145	.9145	.9145	.9145
Max	1.829	1.5242	1.2193	1.5242	1.5242	1.2193	1.5242
Min	.6097	.6097	.6097	.6097	.6097	.6097	.6097
Avg	1.0161	.9450	.9435	1.0306	.9823	.9871	.9947

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA

Feeder No / Name : 204 / TOWN-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2193	1.2193	1.2193	1.2193	1.5242	1.2193
2	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
3	1.2193	.9145	1.2193	1.2193	1.2193	1.2193	1.2193
4	1.2193	.9145	1.2193	1.2193	1.2193	1.2193	1.2193
5	1.2193	.9145	1.2193	1.2193	1.2193	1.5242	1.2193
6	1.5242	1.2193	1.5242	1.5242	1.5242	1.829	1.829
7	1.829	1.829	1.829	1.829	1.829	1.829	2.1338
8	1.829	1.829	1.829			2.1338	1.829
9	1.829	1.829	1.5242			1.5242	.9145
10	1.5242	1.5242					
11	1.2193						
12	1.2193	1.5242	2.1338	2.4387	2.1338	1.829	1.2193
13	.9145	1.2193	1.5242	1.829	1.5242	1.5242	1.2193
14	1.2193	1.2193	1.2193	1.5242		1.2193	1.5242
15	.9145	1.2193	1.2193	1.2193	1.5242	1.2193	1.2193
16	1.2193	.6097	.6097	.6097	.9145	1.2193	.6097
17	1.2193						
18	1.5242						
19			2.1338				
20	1.5242		1.829				
21	.3048	2.1338	1.829	2.4387	2.7435	2.1338	2.1338
22		2.1338	1.5242	2.1338	2.1338	1.829	1.829
23	.3048	1.829	1.5242	1.5242	1.829	1.5242	1.5242
24	1.2193	1.5242	1.2193	1.5242	1.5242	1.5242	1.2193
Max	1.829	2.1338	2.1338	2.4387	2.7435	2.1338	2.1338
Min	.3048	.6097	.6097	.6097	.9145	1.2193	.6097
Avg	1.2470	1.4119	1.4784	1.5432	1.5851	1.5580	1.4056

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA

Feeder No / Name : 205 / TOWN-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	1.829	2.1338	1.829	2.1338	2.1338	1.829
2	1.829	1.5242	1.829	1.829	1.829	1.829	1.829
3	1.829	1.5242	1.829	1.829	1.829	1.829	1.829
4	1.829	1.5242	1.829	1.829	1.829	1.829	1.829
5	1.829	1.5242	1.829	1.829	1.829	1.829	1.829
6	2.1338	2.1338	2.1338	2.1338	2.1338	2.1338	2.4387
7	3.0483	2.7435	2.4387	2.7435	2.7435	2.4387	2.7435
8	3.0483	3.0483	3.0483	3.0483	3.0483	3.658	3.0483
9	3.3532	3.0483	3.3532	3.0483	3.0483	3.3532	3.3532
10	3.0483	2.7435	3.0483	3.0483	3.0483	2.4387	3.3532
11	3.0483	2.7435	3.0483	3.0483		3.3532	3.0483
12	2.7435		2.7435	2.7435		3.0483	
13	2.7435			.9145			
14	2.7435	3.3532			3.658		3.3532
15	2.4387	3.0483			3.658		3.0483
16	2.4387	2.7435	3.3532	3.3532	3.0483	3.3532	2.7435
17	2.7435		3.0483	3.3532		3.3532	
18	3.0483		3.0483	3.3532		3.3532	
19	2.7435		3.3532	3.658		3.9628	
20	3.0483	4.5725	3.658	3.9628	4.8773	3.9628	4.2676
21	2.7435	4.2676	3.3532	3.658	4.5725	3.658	3.9628
22	2.4387	3.3532	2.7435	3.0483	3.3532	2.7435	3.3532
23	2.1338	2.7435	2.4387	2.4387	3.0483	2.4387	2.7435
24	1.829	2.4387	2.1338	2.4387	2.4387	2.1338	2.1338
Max	3.3532	4.5725	3.658	3.9628	4.8773	3.9628	4.2676
Min	1.829	1.5242	1.829	.9145	1.829	1.829	1.829
Avg	2.5403	2.6793	2.6854	2.6881	2.8959	2.8016	2.7756

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA

Feeder No / Name : 402 / 33 KV ROHANWADI

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / OUTGOING

(NON CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3575	3.4431	.1389	3.1473	4.3861	4.1281	1.0562
2	.3326	3.402	.1406	3.1473	4.3287	3.876	1.106
3	.3652	3.4756	.1406	3.3188	4.2078	3.8674	1.0134
4	.3052	3.5742	.138	3.1464	4.3235	4.279	1.0262
5	.3481	3.5819	.1389	3.2339	4.3579	4.1521	1.0751
6	.2761	3.4173	.144	3.2364	4.2927	4.1504	1.0631
7	.3069	3.576	.1655	3.1447	4.399	4.0912	1.0005
8	.1595	3.7637	.1603	3.2828	4.3141	4.0672	.9971
9	.3601	3.4653	.1415	3.1601	4.3133	3.997	.8119
10	.3078	3.552		3.3085	4.2661	3.8717	.7373
11	.3524	3.6437		3.6428	4.6237	3.9575	.7124
12	.2838	3.5948		3.9386	4.5551	3.9678	.7982
13	.3155	3.6163		4.0407	4.5053	3.8897	.7973
14	.3695	3.3016		3.9532	4.4221	3.7115	.8659
15	.3832	3.3393	.1389	4.1204	4.651	4.0038	.9002
16	.3344	3.3359	.1432	4.3288	4.6211	4.1684	.8993
17	.2949	3.4808	.138	4.1993	4.6348	4.111	
18	.2709	3.7071	.1946	4.1675	4.3647	4.0338	
19	.3001	3.6455	.1535	3.7654	4.0322	4.0561	
20	.3369	3.6728	.1706	3.9061	3.305	3.9532	
21	.3258	3.6858	.1423	4.0372	3.8015	3.9249	
22	.3318	3.4594	.1432	4.0295	4.2627	3.9464	
23	.3215	3.456	.1457	4.0055	4.4084	4.0424	
24	.3455	3.5185	.1466	3.9944	4.3055	4.0578	
Max	.3832	3.7637	.1946	4.3288	4.651	4.279	1.106
Min	.1595	3.3016	.138	3.1447	3.305	3.7115	.7124
Avg	.3202	3.5295	.1487	3.6773	4.3201	4.0127	.9288

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 202 / RAVIRAJ FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4387	2.4387	2.4387	2.4387	2.1338	1.829	2.1338
2	2.1338	2.1338	2.7435	2.4387	2.4387	2.7435	2.4387
3	2.4387	1.5242	2.1338	2.1338	1.2193	2.1338	1.829
4	1.829	2.4387	2.1338	1.829	2.1338	2.4387	1.5242
5	2.4387	2.4387	2.4387	1.5242	1.829	2.4387	1.829
6	1.5242	1.829	2.4387	2.1338	2.1338	2.7435	2.1338
7	1.5242	2.1338	2.4387	2.4387	1.5242	2.1338	2.1338
8	2.7435	1.829	2.4387	1.5242	1.829	2.4387	2.1338
9	1.829	2.7435	1.5242	2.1338	1.829	1.829	1.829
10	1.5242	1.5242	1.5242	1.829	2.4387	1.5242	2.1338
11	1.5242	2.7435	1.829	1.829	1.5242	1.5242	2.1338
12	1.5242	2.7435	1.5242	1.5242	1.5242	1.5242	1.5242
13	1.5242	1.5242	1.5242	2.4387	1.5242	1.5242	1.829
14	1.5242	1.829	1.5242	1.829	1.5242	2.1338	1.829
15	1.5242	2.1338	1.5242	1.5242	1.5242	1.829	2.1338
16	1.5242	1.829	1.5242	2.4387	1.5242	1.829	2.1338
17	1.5242	2.7435	1.5242	2.1338	1.5242	1.5242	1.2193
18	1.5242	2.4387	2.1338	2.1338	1.829	2.1338	2.4387
19	1.5242	2.1338	1.829	2.4387	2.4387	2.1338	2.7435
20	1.5242	2.4387	2.1338	1.5242	1.829	1.5242	2.1338
21	1.829	1.829	2.4387	2.4387	2.1338	1.5242	2.4387
22	1.5242	1.829	2.1338	1.829	1.829	2.1338	1.829
23	1.5242	2.4387	2.1338	1.5242	2.1338	2.4387	2.1338
24	2.4387	2.4387	2.4387	2.7435	2.1338	2.1338	2.4387
Max	2.7435	2.7435	2.7435	2.7435	2.4387	2.7435	2.7435
Min	1.5242	1.5242	1.5242	1.5242	1.2193	1.5242	1.2193
Avg	1.7909	2.1719	2.0195	2.0322	1.8544	2.0068	2.0449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 204 / 11KV SHAKTI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	.9145	.9145	.9145	.9145	.9145
2		.9145		.9145	.9145	.9145	.9145
3		.9145		.9145	.6097	.9145	.9145
4		.9145		.9145		.9145	.9145
5		.9145		.9145		.9145	.9145
6		1.2193		.9145		.9145	.9145
7		1.2193		.9145		.9145	.9145
8		.9145		.9145		.9145	.9145
9	.9145	.9145		.9145	.9145	.9145	.9145
10	1.2193	1.5242		.9145	1.2193	1.5242	1.2193
11	1.5242	1.5242		.9145	1.2193	1.829	1.2193
12	1.5242	1.829		.9145	1.5242	1.829	1.5242
13	1.5242	1.829		.9145	1.5242	1.829	1.5242
14	1.5242	1.5242		.9145	1.5242	1.829	1.5242
15	1.5242	1.5242		.9145	1.5242	1.829	1.2193
16	1.5242	1.5242		.9145	1.5242	1.829	1.5242
17	1.5242	1.829		.9145	1.5242	1.829	1.5242
18	1.5242	1.5242		.9145	1.5242	1.829	1.5242
19	1.2193	1.2193		.9145	1.2193	1.2193	1.2193
20	1.2193	1.2193		.9145	.9145	1.2193	1.2193
21	.9145	.9145		.9145	.9145	.9145	.9145
22	.9145	.9145		.9145	.9145	.9145	.9145
23	.9145	.9145		.9145	.9145	.9145	.9145
24	.9145	.9145		.9145	.9145	.9145	.9145
Max	1.5242	1.829	.9145	.9145	1.5242	1.829	1.5242
Min	.9145	.9145	.9145	.9145	.6097	.9145	.9145
Avg	1.2765	1.2320	.9145	.9145	1.1712	1.2701	1.1304

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 205 / MOTIBAG 11KV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
2	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
3	1.2193	.9145	1.2193	.9145	.9145	1.2193	1.2193
4	1.2193	.9145	1.2193	.9145	.9145	1.2193	1.2193
5	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
6	1.5242	1.2193	1.5242	1.5242	1.5242	1.829	1.829
7	1.5242	1.5242	1.5242	1.2193	1.5242	1.5242	.6097
8	1.829	1.829	1.829			1.829	
9	1.829	1.829	1.2193			1.829	
10	1.829	1.5242					
11	1.829						
12	1.829	1.5242	2.1338	2.1338	2.1338	1.829	2.4387
13	1.829	1.5242	1.829	1.829	2.1338	1.829	1.829
14	1.5242	1.2193	1.5242	1.5242	1.829	1.5242	1.829
15	1.2193	1.2193	1.5242	1.5242	1.829	1.5242	1.829
16	1.2193	1.2193	1.5242	1.5242	1.829	1.829	1.829
17	1.5242						
18	1.5242						
19			1.829				
20	1.5242		2.1338				
21	1.5242	2.4387	1.829	2.4387	2.4387		2.1338
22	1.5242	2.1338	1.5242	1.829	1.829	1.829	1.829
23	1.2193	1.5242	1.5242	1.5242	1.5242	1.829	1.5242
24	1.2193	1.5242	1.2193	1.5242	1.5242	1.5242	1.2193
Max	1.829	2.4387	2.1338	2.4387	2.4387	1.829	2.4387
Min	1.2193	.9145	1.2193	.9145	.9145	1.2193	.6097
Avg	1.4844	1.4600	1.5394	1.5051	1.6004	1.5780	1.5623



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 206 / GEDORE 11KV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.9145	.6097	.6097	.6097	.6097
2	.6097	.9145	.9145	.6097	.3048	.6097	.6097
3	.6097	.6097	.6097	.6097	.3048	.6097	.6097
4	.6097	.6097	.9145	.6097	.3048	.6097	.6097
5	.6097	.6097	.9145	.6097	.3048	.6097	.6097
6	.6097	.6097	.9145	.6097	.3048	.6097	.6097
7	.6097	.6097	.6097	.6097	.6097	.6097	.6097
8	.6097	.6097	.6097	.6097	.3048	.6097	.6097
9	.6097	.6097	.6097	.6097	.6097	.6097	.6097
10	.6097	1.5242	1.5242	.6097	1.2193	1.2193	1.5242
11		1.829	1.5242	.6097	1.829	1.5242	1.5242
12	1.829	1.829	1.829	.6097	1.829	1.829	1.5242
13	1.829	1.829	1.829	.6097	1.829	1.5242	1.5242
14	1.5242	1.5242	1.5242	.3048	1.829	1.5242	.9145
15	1.829	1.829	1.5242	.3048	1.5242	1.2193	1.2193
16	1.829	1.829	1.829	.6097	1.5242	1.2193	1.2193
17	1.829	1.829	1.829	.6097	.9145	1.2193	1.2193
18	1.5242	1.5242	1.2193	.3048	.9145	.9145	.9145
19	1.2193	.9145	.9145	.3048	.9145	.9145	.9145
20	.9145	.9145	.9145	.3048	.9145	.6097	.9145
21	.6097	.6097	.6097	.6097	.6097	.6097	.6097
22	.6097	.9145	.9145	.6097	.6097	.6097	.6097
23	.9145	.9145	.9145	.6097	.6097	.6097	.6097
24	.9145	.9145	.9145	.6097	.6097	.6097	.6097
Max	1.829	1.829	1.829	.6097	1.829	1.829	1.5242
Min	.6097	.6097	.6097	.3048	.3048	.6097	.6097
Avg	1.0205	1.1050	1.1177	.5462	.8891	.9018	.8891

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 207 / SURENDRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.2193	1.2193	1.5242	1.5242	1.5242	1.2193
2	1.5242	1.2193	1.2193	1.5242	1.5242	1.5242	1.2193
3	1.5242	1.2193	.9145	1.5242	1.5242	1.5242	1.2193
4	1.5242	1.2193	.9145	1.5242	1.5242	1.5242	1.2193
5	1.5242	1.2193	1.2193	1.5242	1.5242	1.5242	1.2193
6	1.5242	1.2193	1.2193	1.5242	1.5242	1.5242	1.2193
7	1.2193	1.2193	1.2193	1.5242	1.5242	1.5242	1.2193
8	1.2193	1.2193	1.2193	1.5242	1.5242	1.2193	1.2193
9	1.5242	1.5242	1.5242	1.5242	1.5242	1.5242	1.829
10	1.829	1.829	2.1338	1.5242	1.829	1.5242	2.1338
11	1.829	2.1338	2.1338	1.5242	2.1338	1.829	2.4387
12	2.4387	2.4387	2.4387	1.5242	2.4387	1.829	2.4387
13	2.4387	2.4387	2.4387	1.5242	2.4387	2.1338	2.1338
14	2.1338	2.1338	2.4387	1.5242	2.1338	1.829	2.1338
15	1.829	2.1338	2.4387	1.5242	2.1338	2.1338	2.4387
16	2.1338		2.4387		1.829	2.1338	2.1338
17	2.1338		2.4387		1.829	2.1338	2.1338
18	1.829		1.829		1.829	2.1338	1.829
19	1.5242	1.5242	1.829	1.5242	1.5242	2.1338	1.5242
20	1.2193	1.5242	1.829	1.5242	1.5242	1.5242	1.5242
21	1.2193	1.5242	1.5242	1.5242	1.5242	1.2193	1.5242
22	1.2193	1.5242	1.5242	1.5242	1.5242	1.2193	1.5242
23	1.2193	1.2193	1.5242	1.5242	1.5242	1.2193	1.5242
24	1.2193	1.2193	1.5242	1.5242	1.5242	1.2193	1.5242
Max	2.4387	2.4387	2.4387	1.5242	2.4387	2.1338	2.4387
Min	1.2193	1.2193	.9145	1.5242	1.5242	1.2193	1.2193
Avg	1.6385	1.5677	1.7147	1.5242	1.7274	1.6512	1.6893

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 401 / KALIKA

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.7435	2.7435		2.7435	2.7435
2	2.7435	2.7435	2.7435		2.7435	2.7435
3	2.7435	2.7435	2.7435		2.7435	2.7435
4	2.7435	2.7435	2.7435		2.7435	2.7435
5	2.7435	2.7435	2.7435		2.7435	2.7435
6	2.7435	2.7435	2.7435		2.7435	2.7435
7	2.7435	2.7435	2.7435		2.7435	2.7435
8		2.7435	2.7435		2.7435	2.7435
9	2.7435	2.7435	2.7435		2.7435	
10	2.7435	2.7435	2.7435		2.7435	
11	2.7435	2.7435	2.7435		2.7435	
12	2.7435	2.7435	2.7435		2.7435	
13	2.7435	2.7435	2.7435		2.7435	
14	2.7435	2.7435	2.7435		2.7435	
15	5.487	2.7435	2.7435		2.7435	
16	2.7435	2.7435	2.7435		2.7435	
17	2.7435	2.7435		2.7435	2.7435	
18	2.7435	2.7435		2.7435	2.7435	
19	2.7435	2.7435		2.7435	2.7435	
20	2.7435	2.7435		2.7435	2.7435	
21	2.7435	2.7435		2.7435	2.7435	
22	2.7435	2.7435		2.7435	2.7435	
23	2.7435	2.7435		2.7435	2.7435	
24	2.7435	2.7435		2.7435	2.7435	
Max	5.487	2.7435	2.7435	2.7435	2.7435	2.7435
Min	2.7435	2.7435	2.7435	2.7435	2.7435	2.7435
Avg	2.8628	2.7435	2.7435	2.7435	2.7435	2.7435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 402 / REGENT 33KV EXPRESS FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	***	***	***	***	***	***	***
3	***	***	***	***	***	***	***
4	***	***	***	***	***	***	***
5	***	***	***	***	***	***	***
6	***	***	***	***	***	***	***
7	***	***	***	***	***	***	***
8	***	***	***	***	***	***	***
9	***	***	***	***	***	***	***
10	***	***	***	***	***	***	***
11	***	***	***	***	***	***	***
12	***	***	***	***	***	***	***
13	***	***	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	***	***	***	***	***	***	***
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	***	***	***	***
Max	49.3828	49.3828	49.3828	49.3828	52.1263	52.1263	52.1263
Min	35.6653	35.6653	38.4088	38.4088	41.1523	35.6653	32.9219
Avg	43.6672	42.5241	43.3242	42.9813	44.8103	42.2954	44.2387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 403 / MATSYODARI FEEDER  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	24.6914	***	***
2	27.4349	***	27.4349	27.4349	21.9479	***	***
3	***	***	27.4349	27.4349	24.6914	***	***
4	***	***	24.6914	24.6914	21.9479	***	***
5	***	27.4349	24.6914	***	21.9479	***	***
6	***	24.6914	24.6914	27.4349	21.9479	27.4349	***
7	***	27.4349	27.4349	***	24.6914	***	***
8	***	***	27.4349	24.6914	21.9479	***	27.4349
9	***	27.4349	24.6914	27.4349	24.6914	27.4349	***
10	***	24.6914	24.6914	24.6914	21.9479	***	24.6914
11	***	***	24.6914	19.2044	24.6914	***	10.974
12	***	27.4349	21.9479	19.2044	24.6914	***	21.9479
13	***	***	19.2044	21.9479	21.9479	27.4349	24.6914
14	24.6914	27.4349	24.6914	21.9479	24.6914	24.6914	24.6914
15	24.6914	***	27.4349	24.6914	24.6914	24.6914	24.6914
16	21.9479	24.6914	27.4349	21.9479	24.6914	24.6914	24.6914
17	21.9479	21.9479	21.9479	19.2044	24.6914	21.9479	24.6914
18	24.6914	21.9479	21.9479	21.9479	24.6914	24.6914	27.4349
19	24.6914	24.6914	21.9479	24.6914	21.9479	21.9479	***
20	21.9479	21.9479	***	21.9479	24.6914	19.2044	***
21	19.2044	24.6914	27.4349	24.6914	24.6914	21.9479	***
22	19.2044	27.4349	19.2044	24.6914	21.9479	***	***
23	24.6914	27.4349	***	24.6914	***	***	***
24	24.6914	27.4349	27.4349	24.6914	***	***	***
Max	35.6653	32.9219	30.1784	30.1784	30.1784	35.6653	35.6653
Min	19.2044	21.9479	19.2044	19.2044	21.9479	19.2044	10.974
Avg	27.6635	27.3206	25.3773	24.5771	24.1198	28.3494	28.4637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134007 / NER 33/11 KV SUB-STATION

Feeder No / Name : 202 / SHIVNI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.5335	.5335	.6859	.5335	.5335
2	.6859		.5335	.6097		.5335	.6097
3	.7621		.6097	.6097		.6097	.6097
4	.9145		.6859	.6859		.6859	.6859
5	1.1431		.7621	.7621	.7621	.7621	.7621
6	1.2193		.8383	.3048	.6097	.8383	.7621
7			.6859				
8			.6859				
9			.6097				
10	.5335		.5335	.2286	.381		.381
11	.9145			.5335	.6859	.3048	.5335
12	.7621			.2286	.6097	.6097	.4572
13	1.2193				.4572	.4572	.2286
14	.8383				.4572	.4572	.4572
15	1.1431				.4572	.4572	.4572
16	1.2193		.5335		.4572	.5335	
17	1.2193		.6097		.0762	.6859	.4572
18	1.2193	1.0669	.6859	.8383	.6097	.8383	.8383
19		.9907	1.1431	.9145	.8383	.9145	.7621
20		.6859	1.2193	.8383	.7621	.6859	.6859
21		.6859	.6859	.6859	.6859	.6859	.6097
22		.6097	.6859	.8383	.6097	.6097	.5335
23		.6097	.6097	.7621	.5335	.6097	.4572
24		.5335	.5335	.7621	.5335	.5335	.4572
Max	1.2193	1.0669	1.2193	.9145	.8383	.9145	.8383
Min	.5335	.5335	.5335	.2286	.0762	.3048	.2286
Avg	.9653	.7403	.6939	.6335	.5673	.6173	.5639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134007 / NER 33/11 KV SUB-STATION

Feeder No / Name : 205 / shevga SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.1524	.1524	.1524	.1524	.0762
2	.2286		.1524	.1524	.1524	.1524	.0762
3	.2286		.1524	.1524	.0762	.1524	.0762
4	.2286		.1524	.1524		.1524	.0762
5	.3048		.2286	.3048		.2286	.1524
6	.4572		.4572	.3048	.1524	.4572	.3048
7	.5335		.6859	.381	.3048	.6859	.381
8	.5335		.6859	.381	.381	.6097	.381
9	.6097		.6097	.381	.3048	.5335	.3048
10	.6097		.0762	.3048	.2286	.4572	.3048
11	.4572		.2286			.0762	
12	.381		.2286				
13	.4572		.1524				
14	.6859		.0762				
15	.6859		.1524				
16	.5335		.1524		.0762	.0762	.1524
17	.5335		.1524		.3048	.1524	.2286
18	.3048	.3048	.2286	.2286	.381	.2286	.1524
19		.3048	.4572	.381	.381	.3048	.381
20	.1524	.2286	.4572	.4572	.381	.2286	.381
21		.1524	.3048	.3048	.2286	.1524	.2286
22		.1524	.2286	.2286	.1524	.1524	.1524
23		.1524	.1524	.1524	.1524	.0762	.0762
24		.1524	.1524	.1524	.1524	.0762	.0762
Max	.6859	.3048	.6859	.4572	.381	.6859	.381
Min	.1524	.1524	.0762	.1524	.0762	.0762	.0762
Avg	.4292	.2068	.2699	.2689	.2331	.2553	.2085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 206 / RAMNAGAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383		.9145	.3048	.9907	.9907	.9145
2	.8383		.9145	.2286	.9907	.9907	.9145
3	.9145		.9907	.2286		1.0669	.9145
4	1.0669		1.1431	.2286		1.0669	.9907
5	1.2955		1.3717	.2286		1.0669	1.2193
6			1.6004	.3048		1.0669	1.2955
7			1.6766	.381		.381	
8			1.448			.9145	
9			1.2193	.4572		.8383	
10			1.2193	.5335		.6859	
11			.9907	.381		.6097	
12	.4572		.8383	.4572		.5335	
13	.381	.4572			.5335		
14	.8383	.4572			.7621		
15	.6097	.9907		.1524		.0762	
16	.8383	1.0669	.9145	.9907		.6097	1.2193
17		1.1431	.9907	.9907	.9145	.4572	1.2955
18		1.448	1.1431	1.0669	1.3717	.7621	.6097
19		1.6004	1.6766	1.6004	1.3717	1.1431	1.2193
20		1.5242	1.7528	.4572	.1524	.1524	.3048
21		1.2955	1.3717				
22		1.2193	.6097		.4572	.8383	
23		1.0669	.1524	.3048	1.0669	1.0669	.9145
24		.9907	.3048	.9907	1.0669	.9907	.6097
Max	1.2955	1.6004	1.7528	1.6004	1.3717	1.1431	1.2955
Min	.381	.4572	.1524	.1524	.1524	.0762	.3048
Avg	.8078	1.1050	1.1068	.5415	.8798	.7766	.9555



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 202 / KAJALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1593	1.1744	.1578	.1562	.157	.1539	.1585
2	.1585	1.1888	.1555	.1547	.1555	.1532	.1585
3	.16	1.1812	.1555	.1555	.1585	.1547	.157
4	.1608	1.2071	.157	.1555	.1585	.1524	.1585
5	.16	1.2148	.1555	.1555	.1562	.1539	.1585
6	.16	.1837	.1562	.1585	.157	.1555	.1585
7	.1738	.1753	.1638	.1608	.1768	.1715	
8	.1616	.1654	.1654	.1623	.1699	.1547	
9	.1463	.157	.1593	.1638	.1562	.1555	.1555
10	1.0844	.1578	.1593	.192	.1585	.1753	.1593
11	1.089	.1585	.16	.1959	.1593	.1578	.1578
12	1.0197		.16	.1966	.1593	.16	.1608
13	1.1713			.1959	.1616	.1585	.16
14	1.1934	.1593	.1638	.1585	.1623	.1608	.1578
15	1.1667	.16	.1631	.16	.1616	.16	.1585
16	1.1965	.176	.1608	.1585	.1608	.16	.1547
17	1.153	.1608	.1608	.1524	.1593	.1593	.1539
18	1.1584	.1631	.1616	.1562			
19	1.2079		.1661				
20	1.1988		.1669				
21	1.1591	.1608	.1616	.1585	.1585	.1623	.1646
22	1.1751	.1608	.1593	.16	.1593	.1631	.1638
23	1.1256	.1593	.1585	.1578	.1562	.1608	.1638
24	1.1744	.1578	.1562	.1593	.1547	.1593	.1547
Max	1.2079	1.2148	.1669	.1966	.1768	.1753	.1646
Min	.1463	.157	.1555	.1524	.1547	.1524	.1539
Avg	.7797	.4211	.1602	.1647	.1599	.1592	.1587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 204 / GOLAPANGHRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0381	.0381	.0381	.0381	.0381	.0762
2	.0762	.0381	.0381	.0381	.0381	.0381	.0762
3	.0762	.0381	.0381	.0381	.0381	.0381	.1143
4	.0762	.0381	.0381	.0381	.0381	.0381	.1143
5	.0762	.0381	.0381	.0381	.0381	.0381	.1143
6		.0381	.0381	.0381	.0762	.0381	.1143
7	.0762	.0762	.0381	.0381	.0762	.0762	
8	.0762	.0762	.0762			.0762	
9	.0381	.0762	.0381	.0762	.0762	.0762	.1143
10	.0381	.0762	.0381	.0762	.0762	.0381	.1143
11	.0381	.0381	.0762	.0762	.0762	.0381	.1143
12	.0381		.0762	.0381	.0762	.0381	.0762
13	.0381						
14	.0381						
15	.0381						
16	.0381		.0762	.0381	.0381	.0381	.1143
17	.0381		.0762	.0762	.0381	.0762	.1143
18	.0381		.0762	.0762	.0762	.1143	.1143
19	.0381	.0762	.0762	.0762	.0762	.1524	.1143
20	.0381	.0762	.0762				
21	.0381	.0381	.0381				
22	.0381	.0381	.0381				
23	.0381	.0381	.0381	.0381	.0381	.1143	.1143
24	.0381	.0381	.0381	.0381	.0381	.1143	.1143
Max	.0762	.0762	.0762	.0762	.0762	.1524	.1143
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0762
Avg	.0497	.0515	.0526	.0515	.0560	.0656	.1072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 205 / mali pimpalgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.2286	.2286	.3048	.2286
2	.2286	.2286	.2286	.2286	.3048	.3048	.2286
3	.2286	.2286	.3048	.3048	.3048	.3048	.2286
4	.3048	.3048	.3048	.0762	.3048	.3048	.3048
5	.4572	.381	.4572		.4572	.4572	.4572
6		.6859	.6859		.6097	.7621	.6097
7	.8383	.8383	.9145		.6859	.8383	
8	.7621	.7621	.8383			.7621	
9	.7621	.7621	.8383	.6859	.6097	.7621	.7621
10	.5335	.6859	.6097	.6859	.3048	.6097	.6097
11	.4572	.4572	.5335	.4572	.5335	.4572	.5335
12	.3048		.3048	.3048	.381	.3048	.381
13	.2286						
14	.2286						
15	.2286		.1524		.1524	.0762	
16	.2286		.3048	.2286	.3048	.3048	.4572
17	.4572		.3048	.3048	.4572	.381	.5335
18	.5335		.4572	.381	.6097	.5335	.381
19	.5335	.7621	.6859	.6859	.6859	.6097	.5335
20	.4572	.7621	.6859				
21	.3048	.5335	.4572				
22	.3048	.381	.381		.0762	.0762	.0762
23	.2286	.3048	.3048	.3048	.3048	.3048	.3048
24	.2286	.3048	.2286	.3048	.3048	.2286	.3048
Max	.8383	.8383	.9145	.6859	.6859	.8383	.7621
Min	.2286	.2286	.1524	.0762	.0762	.0762	.0762
Avg	.3943	.5066	.4642	.3701	.4011	.4344	.4079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 207 / Daregaon feeder

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)
1	.0434	.2126
2		.234
3		.234
4		.2256
5		.2157
6		.0724
8	.3628	
9	.455	.3033
10	.3673	.298
24	.208	.1974
Max	.455	.3033
Min	.0434	.0724
Avg	.2873	.2214

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 206 / GADE SAWARGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***		***	***	***	***	***
2	***	***	***	***	***	***	
3	***	***	***	***	***	***	***
4	***			***		***	
5				***			
10		***					
16							***
19	***	***	***	***	***	***	
20	***	***		***	***	***	
21	***	***		***	***	***	
22		***	***	***	***		
23	***	***	***	***	***	***	
24	***	***	***	***	***		
Max	152.416	152.416	152.416	152.416	152.416	152.416	152.416
Min	152.416	76.208	152.416	76.208	152.416	76.208	152.416
Avg	152.416	143.9484	152.416	145.488	152.416	133.364	152.416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 201 / KADVANCHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.599	.5258	2.0668	1.3032	.5487	1.0242	.7971
2	.5853	.5289	2.021	1.3093		.9877	.7834
3	.6066	.5365	2.0332	1.3169		.9633	.8017
4	.6173	.5502	2.0332	1.3748		.9541	.8352
5	.6752	.5898	2.1917	1.5348		1.0075	.8871
6	.8657	.7468	2.4341	1.7299	.849	1.1599	
7	.9206	.9572	2.7877	1.9601	1.0867	1.2788	1.0349
8	.8794	.9572	2.3487	1.9799	1.1523	1.3641	1.0974
9	.8169	.9175	2.0881	1.8595	1.0867	1.1325	1.1629
10	.6706		1.8793	1.3047	.9084	1.2574	1.1751
11	.5396		1.6156	1.3504	.3445	1.169	.8962
12	.4039		1.6065		.0472	1.1126	.9556
13	.3841					1.1721	.9541
14	.3917				.5624	1.2087	1.0486
15	.0244				.4054	1.2666	1.044
16						1.1614	.9998
17				.4222		.4603	
18				1.0227		.7468	
19		1.4632	.3963	1.2087	.9404	.9724	.8215
20		1.3062	2.1186	1.1385	1.1142	.9998	.8993
21		2.3243	2.05	.9099	1.198	.9358	.8368
22	.4999	2.3381	1.8564	.7301	1.1599	.916	.7926
23	.5289	2.2969	1.3077	.7194	1.0639	.8672	.7529
24	.5274	2.1155	1.3214	.6828	1.0395	.8276	.7545
Max	.9206	2.3381	2.7877	1.9799	1.198	1.3641	1.1751
Min	.0244	.5258	.3963	.4222	.0472	.4603	.7529
Avg	.5854	1.2103	1.8976	1.2557	.8442	1.0394	.9205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 202 / ASARKHEDA - AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0838	
2					.0053	.0884	
3				.0008	.0061	.0899	.0107
4				.0023	.0122	.0815	.0884
5				.0107	.0838	.0625	.0907
6				.029	.0907	.0914	.0869
7				.0152	.0899	.1006	.093
8				.0076	.0968	.109	.1029
9				.0282	.0373	.1448	.0838
10		.0008			.0091	.112	
11	.0053	.0008	.0244				
12	.0008		.0137				
13			.0091				
14			.0023				
15		.0015	.0076				
16			.0053				
24					.003		
Max	.0053	.0015	.0244	.029	.0968	.1448	.1029
Min	.0008	.0008	.0023	.0008	.003	.0625	.0107
Avg	.0031	.0010	.0104	.0134	.0434	.0964	.0795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 201 / MANEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572			.4572	.381		.381
2	.4572			.4572	.4572		.381
3	.5335			.4572			.381
4	.6097			.4572			.381
5	.6097			.0762			
6	.7621						
7	.9145		.4572				
8	.9145		.7621				
9	.9145		.6097				
10	.8383		.5335	.381			.2286
11				.5335	.4572		.3048
12				.5335			.2286
13							.3048
14							.3048
15							.3048
16			.2286				.3048
17	.381		.381	.3048			.3048
18	.4572	.381	.381	.5335		.3048	.3048
19		.5335	.5335	.5335		.5335	.4572
20		.4572	.5335	.5335		.5335	.4572
21		.4572	.4572	.4572		.5335	.4572
22		.4572	.4572	.4572		.4572	.4572
23			.4572	.4572		.381	.381
24			.4572	.381		.381	.381
Max	.9145	.5335	.7621	.5335	.4572	.5335	.4572
Min	.381	.381	.2286	.0762	.381	.3048	.2286
Avg	.6541	.4572	.4807	.4382	.4318	.4464	.3529



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 202 / PAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.2286	.1524	.1524	.1524	.1524
2	.2286		.2286	.1524	.1524	.1524	.1524
3	.2286		.2286	.1524	.0762	.1524	.1524
4	.2286		.2286	.1524	.0762	.1524	.1524
5	.0762		.3048	.1524	.0762	.1524	.1524
6			.3048	.2286	.1524	.1524	.1524
7			.3048	.3048	.2286	.3048	.2286
8				.2286	.2286	.3048	.3048
9				.2286	.1524	.3048	.2286
10	.1524			.3048	.1524	.2286	.2286
11	.381		.3048				
12	.5335		.2286				
13	.6097						
14	.6097		.0762				
15	.6097		.2286				
16	.5335		.2286			.0762	.0762
17	.5335		.2286		.1524	.1524	.2286
18	.381	.1524	.1524	.1524	.2286	.1524	.2286
19		.1524	.2286	.2286	.2286	.2286	.2286
20		.1524	.2286	.2286	.2286	.2286	.2286
21		.1524	.2286	.2286	.2286	.2286	.2286
22		.2286	.2286	.2286	.2286	.2286	.2286
23		.2286	.2286	.2286	.2286	.2286	.2286
24		.2286	.1524	.2286	.2286	.1524	.2286
Max	.6097	.2286	.3048	.3048	.2286	.3048	.3048
Min	.0762	.1524	.0762	.1524	.0762	.0762	.0762
Avg	.3810	.1851	.2286	.2107	.1778	.1965	.2005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-SEP-17 and 14-SEP-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 203 / SAWANGI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-SEP-17	09-SEP-17	10-SEP-17	11-SEP-17	12-SEP-17	13-SEP-17	14-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.3048	.2286	.2286	.3048	.2286
2	.381		.3048	.2286	.2286	.3048	.2286
3	.4572		.3048	.3048		.3048	.3048
4	.5335		.381	.3048		.3048	.381
5	.0762		.4572	.4572		.381	.381
6			.381	.5335	.4572	.4572	.4572
7			.381	.6097	.5335	.4572	.6097
8				.4572	.3048	.381	.6097
9				.5335	.4572	.5335	.4572
10	.7621		.1524	.381	.4572	.4572	
11	.9145		.381				
12	.9145		.381				
13	.9907		.3048				
14	.6097		.381				
15	.9145		.3048				
16	.9907		.3048		.0762	.2286	.2286
17	1.0669		.3048		.4572	.3048	.5335
18	1.0669		.4572	.4572	.5335	.5335	.6097
19		.0762	.6859	.6859	.6097	.6859	.6097
20		.381	.7621	.6859	.6097	.6859	.6097
21		.381	.5335		.4572	.4572	.4572
22		.3048	.381	.381	.381	.381	.381
23		.3048	.381	.381	.381	.381	.381
24		.3048	.2286	.3048	.3048	.2286	.3048
Max	1.0669	.381	.7621	.6859	.6097	.6859	.6097
Min	.0762	.0762	.1524	.2286	.0762	.2286	.2286
Avg	.7185	.2921	.3845	.4334	.4048	.4091	.4318