

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 204 / 11 KV Dhargaon Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.061	.061	.0305
2	.061	.0914	.061
3	.061	.0914	.061
4	.061	.0914	.061
5	.061	.0914	.061
6	.061	.0914	.061
7	.061	.061	.061
8	.061	.061	.061
9	.061	.061	.0305
10	.061	.0305	
11	.0305		
12	.0305		
13	.061		
14	.061	.0305	
15	.061		
16	.061	.0305	
17	.061	.0305	
18	.061	.0305	
19	.061	.0305	
20	.061	.0305	
21	.061	.0305	.0305
22	.061	.0305	.0305
23	.061	.0305	.0305
24	.061	.0305	.0305
Max	.061	.0914	.061
Min	.0305	.0305	.0305
Avg	.0585	.0518	.0469

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 205 / 11 KV MIDC II feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT  
HAVING WEEKLY STAGGERING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.8627	1.3954
2	.8619	1.3672
3	.8711	1.39
4	.852	1.3245
5	.8406	1.2109
6	.8505	1.2879
7	.849	1.4266
8	1.0014	1.3931
9	1.275	1.7337
10	1.4518	1.6667
11	1.5257	1.8488
12	1.3794	1.7406
13	1.6095	2.1498
14	1.5859	1.9806
15	1.7109	1.9311
16	1.5272	1.8808
17	1.4899	1.8839
18	1.4053	1.733
19	1.4015	1.8252
20	1.3672	1.7528
21	1.2513	1.7421
22	1.3809	1.7177
23	1.3474	1.6499
24	1.3329	1.6811
Max	1.7109	2.1498
Min	.8406	1.2109
Avg	1.2513	1.6547

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 207 / 11KV COBRA BN.

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0987	.0968	.0937
2	.0968	.0979	.0895
3	.0972	.0964	.0888
4	.0979	.096	.0892
5	.0895	.0899	.0815
6	.0579	.0602	.0533
7	.0556	.0583	.0511
8	.0514	.0602	.0583
9	.0514	.0682	.0621
10		.0613	.0716
11	.0461	.0625	.0579
12	.0621	.0594	.0594
13	.0633	.0613	.0625
14	.0591	.0594	.061
15	.0572	.0572	.0598
16	.0583	.0587	.0602
17	.0606	.0549	.0652
18	.0613	.0564	.0659
19	.0671	.0934	.0983
20	.1155	.1094	.1139
21	.1082	.1105	.1166
22	.1075	.1105	.1067
23	.1029	.1021	.101
24	.0983	.0953	.0949
Max	.1155	.1105	.1166
Min	.0461	.0549	.0511
Avg	.0767	.0782	.0776

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 401 / 33 KV Ashok Leyland Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5149	2.0576	1.829	1.829
2	3.2007	2.0576	2.0576	1.829
3	2.5149	2.2862	2.0576	1.829
4	2.7435	2.0576	1.6004	1.6004
5	2.2862	1.829	1.6004	1.829
6	2.2862	2.0576	1.829	1.6004
7	2.5149	2.0576	1.6004	1.6004
8	2.5149	2.0576	1.829	1.3717
9	2.7435	1.829	1.6004	1.6004
10	2.2862	2.0576	1.6004	1.3717
11	2.0576	1.829	1.3717	1.1431
12	2.5149	2.0576	1.3717	1.6004
13	2.5149	2.2862	1.6004	1.6004
14	2.0576	2.0576	1.3717	1.6004
15	2.5149	2.0576	1.6004	1.3717
16	2.5149	2.0576	1.6004	1.1431
17	2.9721	2.2862	1.3717	1.6004
18	3.2007	2.2862	1.829	1.3717
19	3.4294	2.2862	1.829	1.6004
20	2.5149	2.2862	1.6004	1.3717
21	2.9721	2.0576	1.3717	1.6004
22	3.2007	2.0576	1.6004	1.829
23	2.9721	1.6004	1.6004	1.6004
24	2.0576	1.829	1.6004	1.6004
Max	3.4294	2.2862	2.0576	1.829
Min	2.0576	1.6004	1.3717	1.1431
Avg	2.6292	2.0576	1.6385	1.5623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 203 / 11 KV KHAT ROAD FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.9465	.8817
2	.8932	.8535
3	.8634	.8185
4	.8391	.7979
5	.8177	.7743
6	.7971	.7621
7	.7667	.7392
8	.6798	.7026
9	.6744	.644
10	.6539	.6417
11	.6744	.6539
12	.6699	.6767
13	.6729	.6729
14	.6691	.6722
15	.6958	.6775
16	.6927	.6554
17	.644	.6363
18	.5777	.6104
19	.6973	.7133
20	.8101	.8109
21	.7987	.836
22	.8528	.913
23	.9153	.961
24	.9366	.9717
Max	.9465	.9717
Min	.5777	.6104
Avg	.7600	.7532

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 201 / 11kv korambhi (GAOTHAON)

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	2.2672	2.2291
2	2.2062	2.1719
3	2.1681	2.1224
4	2.0767	2.1033
5	2.0957	2.0881
6	2.0805	2.0729
7	1.8747	1.9166
8	1.4556	1.467
9	1.2917	1.326
10	1.4098	1.2727
11	1.4289	1.3527
12	1.5927	1.5508
13	1.7185	1.6347
14	1.7337	1.6423
15	1.7032	1.2346
16	1.6461	1.4175
17	1.387	1.3984
18	1.3984	1.3679
19	1.909	1.9433
20	2.191	2.3015
21	2.3205	2.4158
22	2.4082	2.4463
23	2.332	2.4196
24	2.271	2.2977
Max	2.4082	2.4463
Min	1.2917	1.2346
Avg	1.8736	1.8414

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 202 / 11 KV Rajola Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6554
2			1.5203	1.4327
3			1.5051	1.4137
4			1.4937	1.4213
5			1.4975	1.4175
6			1.5165	1.4327
7			1.5546	1.5966
8			1.6461	1.7109
9			1.7223	1.749
10	.5296	.6935		
11	1.6842	1.6728		
12	1.7452	1.8023		
13	1.8557	1.9166		
14	1.8442	1.97		
15	1.8442	1.9243		
16	1.9166	1.9471		
17	1.9128	1.9738		
18	1.8671	1.9357		
Max	1.9166	1.9738	1.7223	1.749
Min	.5296	.6935	1.4937	.6554
Avg	1.6888	1.7596	1.5570	1.4255

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 203 / 11 KV Shahapur Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5775	2.1872	2.1948	2.1072
2	1.5432	2.1529	2.1224	2.0119
3	1.5051	2.1033	2.0729	1.9585
4	1.4784	2.0805	2.0538	1.9319
5	1.4632	2.069	2.0424	1.9166
6	1.4365	2.0462	2.0233	1.8938
7	1.3832	1.9395	1.909	1.8214
8	1.2346	1.6461	1.6042	1.5394
9	1.0822	1.5889	1.4975	1.5127
10	1.0707	1.627	1.5966	1.5813
11	1.0364	1.6651	1.7375	1.7032
12	.9945	1.669	1.8061	1.7299
13	1.3832	1.6842	1.8366	1.6918
14	1.4403	1.6842	1.8557	1.6575
15	1.4327	1.6994	1.8023	1.6842
16	1.4327	1.6918	1.8214	1.6537
17	1.467	1.5699	1.7414	1.5889
18	1.4365	1.4441	1.5013	1.5165
19	1.9509	1.7756	1.909	1.9014
20	2.2177	2.0157	2.069	2.1681
21	2.2901	2.0614	2.0957	2.2215
22	2.351	2.1757	2.1681	2.2862
23	2.3396	2.2824	2.191	2.2748
24	2.2558	2.271	2.1719	2.1986
Max	2.351	2.2824	2.1948	2.2862
Min	.9945	1.4441	1.4975	1.5127
Avg	1.5751	1.8804	1.9093	1.8563



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 205 / 11 KV Explosive - I Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-SEP-17
HR	Load (MW)
1	1.3413
2	1.2879
3	1.1965
4	1.1812
5	1.1736
6	1.2574
7	1.4022
8	1.2803
9	1.2727
10	.7773
11	.7316
12	.5411
13	.8307
14	1.044
15	1.044
16	1.3717
17	1.5089
18	1.1507
19	.9602
20	.9983
21	.9755
22	.9755
23	.9678
24	1.3794
Max	1.5089
Min	.5411
Avg	1.1104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 206 / 11 KV Bhandara Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
2	1.5318	3.1207
3	2.9874	3.1017
4	2.7092	3.0826
5	2.8692	3.0826
6	2.8121	3.0636
7	2.7587	3.1207
8	3.0559	3.0559
9	3.235	3.0902
10	1.9243	.8459
Max	3.235	3.1207
Min	1.5318	.8459
Avg	2.6537	2.8404

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 208 / 11 KV Explosive - II NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	30-SEP-17
HR	Load (MW)
1	1.2346
2	1.0822
3	.9602
4	.8459
5	.7392
6	.9145
7	.6859
8	.5868
9	1.0898
10	1.0364
11	.8459
12	.8078
13	.9526
14	.8307
15	.9221
16	1.1736
17	1.4327
18	1.5851
19	1.3717
20	1.448
21	1.3108
22	1.3489
23	1.3489
24	1.4403
Max	1.5851
Min	.5868
Avg	1.0831

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 209 / 11 KV Awarmara Gaothan **SEPARATED GAOTHAN FEEDERS**

Feeder Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.6744	.6554	.6478
2	.6516	.6668	.6478	.6363
3	.6516	.663	.6516	.6287
4	.6478	.6592	.6478	.6287
5	.6401	.6783	.6554	.6478
6	.6401	.6897	.6592	.6401
7	.6097	.6401	.6211	.5982
8	.5144	.5373	.5182	.503
9	.503	.5068	.4801	.4725
10	.4687	.4954	.503	.4572
11	.4001	.4801	.4039	.4191
12	.381	.4534	.4115	.3887
13	.3658	.4458	.4077	.3658
14	.3887	.4496	.4077	.3963
15	.381	.4496	.4077	.4001
16	.4001	.4382	.3887	.3963
17	.3849	.4268	.3658	.3734
18	.3887	.3925	.381	.3696
19	.6135	.5525	.5601	.5563
20	.7049	.6706	.6401	.6897
21	.724	.6821	.6668	.7049
22	.743	.6935	.7011	.7049
23	.7125	.6935	.6859	.6935
24	.6859	.6706	.6706	.663
Max	.743	.6935	.7011	.7049
Min	.3658	.3925	.3658	.3658
Avg	.5524	.5712	.5474	.5409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 202 / 11 KV Sunflag Feeder  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.6842	1.4822
2		2.3929	2.3853
3		2.3777	2.2939
4		2.3586	2.2824
5		2.3396	2.2901
6		2.2634	2.3396
7		.4115	2.6825
8			2.652
9			2.5873
10	1.4137	.061	
11	2.6673	.8383	
12	2.8616	2.4577	
13	2.5796	2.4806	
14	2.7359		
15	2.7435		
16	2.7435		
17	2.5873		
18	2.5606		
Max	2.8616	2.4806	2.6825
Min	1.4137	.061	1.4822
Avg	2.5437	1.7878	2.3328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 205 / Sahakar Nagar Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2591	.2591
2	.2629	.2591	.2629
3	.2591	.2553	.2629
4	.2591	.2553	.2629
5	.2591	.2553	.2591
6	.2629	.2629	.2515
7	.2591	.2553	.2439
8	.2667	.2591	.2743
9	.3734	.362	.3772
10	.3887	.4344	.4306
11	.4306	.4496	.4572
12	.4534	.4839	.4725
13	.4572	.4611	.4763
14	.4534	.4306	.5258
15	.4687	.503	.5563
16	.4725	.522	.5296
17	.4496	.503	.5106
18	.3734	.4039	.4382
19	.2362	.3544	.3734
20	.282	.3544	.3544
21	.2591	.3391	.3391
22	.2591	.3353	.3315
23	.1753	.2629	.3315
24	.2553	.2591	.2553
Max	.4725	.522	.5563
Min	.1753	.2553	.2439
Avg	.3285	.3550	.3682

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 401 / 33KV BHANDARA

Feeder KV- 33 / INCOMING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	22.7024	22.5652	21.1934	19.8903
2	21.6736	21.262	19.7531	18.7243
3	20.8505	20.5076	18.8615	18.0384
4	20.2332	19.7531	18.3128	17.6955
5	19.6845	19.3416	17.8327	17.284
6	19.6845	18.7243	17.5583	17.0096
7	19.4788	17.8327	16.8725	16.5981
8	17.8327	16.118	15.0892	15.5693
9	16.8039	14.952	14.4719	14.4033
10	16.941	15.1578	14.8834	14.952
11	17.1468	15.4321	16.0494	15.5693
12	18.7243	15.4321	16.4609	15.8436
13	18.8615	15.2949	16.3923	15.9808
14	18.7243	15.5693	16.5981	16.8725
15	18.9987	15.7065	17.284	16.8725
16	18.5185	15.7065	16.8725	16.4609
17	18.8615	15.5007	16.0494	15.9808
18	17.9698	14.5405	15.0892	15.3635
19	18.6557	16.5295	16.8725	17.9013
20	20.2332	17.6269	18.107	18.7929
21	20.3704	18.6557	18.3814	19.2044
22	21.262	20.3704	19.0672	20.1646
23	23.1825	21.8793	20.3018	21.1934
24	23.5254	22.0165	20.2332	21.262
Max	23.5254	22.5652	21.1934	21.262
Min	16.8039	14.5405	14.4719	14.4033
Avg	19.6217	17.7698	17.4412	17.4011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 201 / 11 KV Ambedkar ward

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5876	.6188	.6188	.5944
2	.5815	.6097	.6013	.5876
3	.5685	.5967	.5761	.567
4	.5578	.5906	.5708	.5617
5	.5525	.5838	.5639	.5525
6	.5563	.5761	.5556	.5449
7	.5525	.5617	.5479	.5426
8	.5441	.551	.5319	.5373
9	.5304	.5327	.5319	.5205
10	.5274	.5319	.535	.5289
11	.5197	.5411	.5319	.5342
12	.5114	.5289	.5228	.5228
13	.5121	.5342	.522	.5258
14	.5258	.5388	.522	.5251
15	.5296	.535	.5266	.5235
16	.5296	.5335	.5274	.5182
17	.5304	.5426	.5235	.5251
18	.5251	.5228	.5205	.5129
19	.535	.5281	.5098	.4999
20	.5487	.5441	.5327	.5251
21	.5624	.5517	.5426	.5449
22	.5906	.5784	.5533	.554
23	.5959	.5853	.5647	.5738
24	.6097	.612	.5876	.5898
Max	.6097	.6188	.6188	.5944
Min	.5114	.5228	.5098	.4999
Avg	.5494	.5596	.5467	.5422



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 204 / 11 KV Kham Talao (Takiya  
Ward) Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6621	.8436	.7621
2	1.5882	.7811	.7125
3	1.5386	.7567	.6859
4	1.483	.7346	.6706
5	1.435	.7026	.6501
6	1.4426	.6783	.6341
7	1.467	.6645	.6348
8	1.3382	.5868	.5959
9	1.2315	.5456	.5175
10	1.2384	.5411	.5213
11	1.3268	.5388	.522
12	1.4342	.5708	.5731
13	1.4594	.6089	.6013
14	1.3969	.6081	.6219
15	1.3839	.6036	.6219
16	1.3725	.602	.6028
17	1.3893	.5738	.6081
18	1.3626	.5441	.5883
19	.7827	.6622	.6699
20	.8413	.7316	.7575
21	.8162	.7316	.7697
22	.8169	.727	.7796
23	.8505	.7606	.8093
24	.8863	.788	.8253
Max	1.6621	.8436	.8253
Min	.7827	.5388	.5175
Avg	1.2727	.6619	.6556

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 205 / 11 KV Nashik Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0447	2.2001	2.0835	2.0409
2	1.9867	2.1003	1.9791	1.9639
3	1.9403	2.0355	1.8999	1.9082
4	1.9052	2.0119	1.8511	1.8938
5	1.8854	1.9715	1.8176	1.8602
6	1.9029	1.8945	1.8008	1.829
7	1.8221	1.8259	1.7558	1.7871
8	1.6354	1.6088	1.5234	1.6453
9	1.3977	1.5013	1.4045	1.406
10	1.4868	1.4167	1.5089	1.5173
11	1.5333	1.4426	1.5394	1.5524
12	1.6324	1.4678	1.6187	1.6476
13	1.6453	1.5043	1.6148	1.688
14	1.6629	1.547	1.611	1.6956
15	1.7299	1.5493	1.6598	1.7414
16	1.6255	1.5676	1.6545	1.6644
17	1.6103	1.528	1.5546	1.6568
18	1.592	1.4297	1.4822	1.5867
19	1.8839	1.595	1.7619	1.8122
20	2.1498	1.7886	1.8839	1.9639
21	2.1445	1.9235	1.9395	2.018
22	2.1049	2.0485	1.97	2.0485
23	2.2474	2.1597	2.0843	2.1193
24	2.271	2.1529	2.0782	2.1011
Max	2.271	2.2001	2.0843	2.1193
Min	1.3977	1.4167	1.4045	1.406
Avg	1.8267	1.7613	1.7532	1.7978

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 206 / 11KV Station Road  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4984	.5258	.5495
2	.4923	.4999	.5098
3	.4847	.4862	.4992
4	.4763	.4702	.487
5	.4641	.4649	.4847
6	.4626	.4542	.4755
7	.4679	.4435	.4534
8	.3978	.3742	.4161
9	.3536	.3551	.362
10	.4321	.4748	.4451
11	.4161	.471	.4466
12	.4245	.4824	.4656
13	.413	.4854	.4633
14	.3749	.423	.4321
15	.4374	.5197	.4931
16	.4466	.5014	.4565
17	.4367	.4672	.4572
18	.3993	.4329	.4527
19	.4374	.4443	.4679
20	.4717	.4633	.4527
21	.4893	.5098	.4786
22	.5556	.5327	.5091
23	.5792	.5517	.5304
24	.6081	.5418	.5396
Max	.6081	.5517	.5495
Min	.3536	.3551	.362
Avg	.4592	.4740	.4720

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 202 / 11 KV Civil Line Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	1.5356	1.4441
2	1.467	1.387
3	1.4137	1.3565
4	1.3984	1.326
5	1.3641	1.3184
6	1.3336	1.3032
7	1.3222	1.2993
8	1.2041	1.2155
9	1.1622	1.1469
10	1.1927	1.1965
11	1.2422	1.2269
12	1.326	1.326
13	1.3565	1.3984
14	1.3679	1.4365
15	1.3908	1.4365
16	1.3946	1.4403
17	1.3184	1.4022
18	1.2536	1.3603
19	1.4975	1.5851
20	1.5051	1.5813
21	1.4899	1.5623
22	1.4441	1.5394
23	1.4518	1.5546
24	1.4632	1.5813
Max	1.5356	1.5851
Min	1.1622	1.1469
Avg	1.3706	1.3927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 205 / 11 KV Shastri Nagar Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.1355	1.1203	1.0783
2	1.1012	1.0936	1.0402
3	1.0517	1.0479	.9945
4	1.044	1.0212	.9907
5	1.0174	.9983	.9412
6	1.0136	.9831	.8954
7	.9793	.9793	.8954
8	.9145	.884	.8459
9	.8573	.8459	.7811
10	.8878	.8802	.8192
11	.9259	.9069	.8916
12	1.0059	.9869	.9983
13	1.0631	1.0707	1.0479
14	1.0707	1.1088	1.0974
15	1.1012	1.1241	1.1279
16	1.0783	1.1355	1.0974
17	1.0364	1.0898	1.0822
18	1.0021	1.1012	1.0555
19	1.1888	1.3032	1.2651
20	1.1927	1.3336	1.307
21	1.1355	1.2917	1.2879
22	1.1507	1.2079	1.2689
23	1.1774	1.1317	1.2193
24	1.1507	1.1203	1.1812
Max	1.1927	1.3336	1.307
Min	.8573	.8459	.7811
Avg	1.0534	1.0736	1.0504

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 206 / 11 KV Vidya Nagar Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.0919	2.0652	1.8671
2	1.97	1.9243	1.7985
3	1.9014	1.8595	1.7147
4	1.8442	1.7985	1.6613
5	1.7871	1.7528	1.6156
6	1.7375	1.7299	1.5966
7	1.6423	1.6918	1.5851
8	1.528	1.5242	1.4784
9	1.4784	1.4594	1.387
10	1.5623	1.5127	1.4022
11	1.6004	1.5432	1.528
12	1.608	1.6004	1.6804
13	1.5813	1.6613	1.6804
14	1.5813	1.6804	1.7642
15	1.6347	1.7109	1.7337
16	1.6309	1.7147	1.6804
17	1.5889	1.5623	1.6232
18	1.4784	1.5051	1.5356
19	1.7414	1.7642	1.8633
20	1.768	1.8671	1.97
21	1.8938	1.8252	1.9738
22	2.0881	1.909	2.0881
23	2.1834	1.9852	2.1643
24	2.21	1.9738	2.13
Max	2.21	2.0652	2.1643
Min	1.4784	1.4594	1.387
Avg	1.7555	1.7342	1.7301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 208 / 11 KV Hospital Feeder  
 (EXPRESS Feeder KV- 11 /  
 OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.2591	.1905
2	.2553	.2629
3	.2515	.2477
4	.2324	.2439
5	.1753	.2286
6	.1791	.1524
7	.2477	.2362
8	.2591	.2629
9	.2553	.2591
10	.1753	.2096
11	.2439	.1372
12	.1943	.1943
13	.3086	.2972
14	.2896	.282
15	.2782	.2667
16	.2591	.2629
17	.2172	.2439
18	.1867	.1372
19	.2629	.2248
20	.2477	.2858
21	.2401	.282
22	.2362	.2591
23	.2362	.2477
24	.1905	.2515
Max	.3086	.2972
Min	.1753	.1372
Avg	.2367	.2361

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 203 / 11 KV Dhop Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3102	.3185	.2972
2	.2964	.3025	.2896
3	.2919	.2942	.285
4	.2888	.2926	.2858
5	.2919	.2134	.2835
6	.298		.2804
7	.2667	.1357	.269
8	.2042	.2149	.1974
9	.1905	.1867	.1578
10	.1859	.1844	.1326
11	.1699	.1707	.1509
12	.1738	.1677	.1715
13	.1791	.1875	.1814
14	.189	.1966	.1867
15	.1898	.1791	.1882
16	.1677	.1608	.1638
17	.16	.157	.1478
18	.1585	.1745	.1334
19	.2431	.2576	.2576
20	.3056	.3262	.3445
21	.3292	.3361	.3513
22	.3528	.3346	.346
23	.3445	.3178	.3224
24	.3262	.3048	.2934
Max	.3528	.3361	.3513
Min	.1585	.1357	.1326
Avg	.2464	.2354	.2382



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 204 / 11kv JAMB AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.275	1.2422
2			1.8458	1.8808
3			1.832	1.8801
4			1.8221	1.8389
5			1.8183	1.8061
6			1.7566	1.8534
7			2.0127	2.0119
8			2.0828	2.2367
9			2.0919	2.1521
10	1.0471	1.3931		
11	2.1803	2.0241		
12	2.1399	2.0873		
13	2.3381	2.1956		
14	2.1346	2.1392		
15	2.1963	2.0538		
16	2.1041	2.1963		
17	2.2344	2.2085		
18	2.1795	1.8755		
Max	2.3381	2.2085	2.0919	2.2367
Min	1.0471	1.3931	1.275	1.2422
Avg	2.0616	2.0193	1.8375	1.8780

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383] BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 207 / 11kv Dhop Agp

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.9739	1.0486
2	1.6392	1.8808
3	1.6255	1.8458
4	1.6141	1.8541
5	1.6095	1.8465
6	1.7269	1.8679
7	1.8747	1.8511
8	2.021	1.9563
9	1.9936	1.9563
18		.0998
Max	2.021	1.9563
Min	.9739	.0998
Avg	1.6754	1.6207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 206 / 11 KV Chichkheda Feeder SINGLE PHASING

SP Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3815	2.4684	2.761	2.6833
2	2.3708	2.4486	3.1291	2.931
3	2.367	2.4364	3.0948	3.0056
4	2.4006	2.4425	3.0841	3.1779
5	2.4676	2.4798	3.11	3.1687
6	2.4173	2.447	3.1375	3.1863
7	1.7177	1.8351	3.0605	3.1939
8	1.2498	1.4129	3.1352	3.1398
9	1.1347	1.3999	2.8296	2.7496
10	2.0652	2.0012	1.2551	1.23
11	3.1139	3.1763	1.3275	1.2475
12	3.2099	3.2427	1.3801	1.3557
13	2.1978	3.1024	1.4556	1.422
14	2.9264	3.3036	1.4822	1.4457
15	3.1207	3.0163	1.4944	1.4175
16	3.0849	3.1916	1.3588	1.2704
17	3.0857	3.0026	1.1667	1.0776
18	2.963	3.1078	1.4601	1.2102
19	2.4059	2.1582	2.226	2.3403
20	2.6764	2.4135	2.4554	2.604
21	2.7443	2.6886	2.6101	2.7275
22	2.7145	2.6894	2.5705	2.6901
23	2.6109	2.5659	2.4623	2.5271
24	2.5019	2.4646	2.3762	2.428
Max	3.2099	3.3036	3.1375	3.1939
Min	1.1347	1.3999	1.1667	1.0776
Avg	2.4970	2.5623	2.2676	2.2596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 208 / 11 KV Express Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3986	.2408	.2263
2	.3879	1.8069	1.7917
3	.3765	1.797	1.7635
4	.3849	1.7779	1.768
5	.2858	1.7688	1.7574
6	.2782	1.7673	1.7474
7	.3734	1.72	1.6827
8	.3818	1.6362	2.0401
9	.4344	1.669	2.0431
10	.301	.5014	.602
11	1.6263	.298	.3765
12	1.7764	.2919	.3978
13	1.7726	.298	.4031
14	1.7452	.2934	.4351
15	1.7444	.3064	.4908
16	1.7513	.3041	.3902
17	1.7292	.3094	.3734
18	1.659	.2789	.3635
19	.4108	.2477	.2439
20	.2439	.2622	.2248
21	.2454	.2622	.2347
22	.2423	.2599	.2454
23	.2408	.2256	.2416
24	.2431	.2324	.2446
Max	1.7764	1.8069	2.0431
Min	.2408	.2256	.2248
Avg	.7931	.7731	.8370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 210 / 11kv Kanhalgaon SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.6958	.7872	.6813
2	.676	.6897	.9015	.6676
3	.6706	.6874	.8299	.6577
4	.6722	.6889	.8322	.6569
5	.7064	.7354	.8406	.6783
6	.6699	.7118	.8269	.6729
7	.4954	.4999	.8429	.8093
8	.3925	.4412	.8215	.8345
9	.3429	.4191	.8169	.8269
10	.6318	.647	.3871	.349
11	.8467	.9282	.3871	.3628
12	.8787	.9579	.3917	.3727
13	.8657	.9412	.4108	.426
14	.852	.8558	.413	.4275
15	.8345	.8634	.394	.4191
16	.772	.8444	.3544	.4009
17	.7857	.8581	.3086	.3269
18	.8269	.8276	.3849	.3605
19	.628	.5746	.6081	.6409
20	.711	.6752	.6943	.7247
21	.7689	.7514	.7331	.7651
22	.7659	.7598	.7285	.7819
23	.7392	.7354	.7125	.7423
24	.7072	.711	.6882	.7095
Max	.8787	.9579	.9015	.8345
Min	.3429	.4191	.3086	.3269
Avg	.7050	.7292	.6290	.5956

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 401 / 33 KV MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.9433	1.8976
2	1.8976	2.1262	1.9662
3	1.8976	2.1033	1.9433
4	1.8747	2.1033	1.9204
5	1.8747	2.0576	1.8747
6	1.8747	2.0348	1.8976
7	1.669	1.8976	1.6918
8	1.4861	1.7604	1.6232
9	1.4403	1.7833	1.669
10	1.6004	1.4403	1.3032
11	1.8519	1.4403	1.6461
12	1.9662	1.4861	1.6461
13	2.0805	1.7375	.8002
14	2.0576	1.7375	1.2574
15	2.0348	1.6461	1.7147
16	1.989	1.6232	1.6461
17	1.8747	1.6461	1.6461
18	1.7375	1.5089	1.5775
19	1.6232	1.7375	1.7604
20	1.6918	1.7147	1.829
21	1.8976	1.829	1.8976
22	1.9662	1.8519	1.8976
23	1.9662	1.8061	1.8519
24	1.8747	1.7147	1.8061
Max	2.0805	2.1262	1.9662
Min	1.4403	1.4403	.8002
Avg	1.8404	1.7804	1.6985

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 207 / 11kv HASARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.4572	.4572
2	.4572	.4572
3	.4572	.4191
4	.4191	.4191
5	.4191	.4191
6	.4191	.4191
7	.381	.3429
8	.3048	.3429
9	.3048	.3048
10	.3429	.3429
11	.3429	.3429
12	.3429	.3429
13	.381	.3429
14	.381	.381
15	.381	.3429
16	.3429	.3429
17	.3048	.3429
18	.3429	.3429
19	.4572	.4572
20	.4954	.4954
21	.4954	.4954
22	.4954	.4954
23	.4572	.4954
24	.4572	.4572
Max	.4954	.4954
Min	.3048	.3048
Avg	.4017	.4001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064040 / MIDC MOHADI

Feeder No / Name : 201 / 11 kv Mohadi Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8688	.897	.8246
2	.8505	.8657	.7994
3	.8421	.8543	.7842
4	.8368	.849	.7766
5	.8421	.8406	.7865
6	.8421	.82	.7819
7	.7827	.7781	.7301
8	.676	.7057	.6569
9	.6592	.7217	.6851
10	.6851	.7636	.692
11	.7636	.7842	.7651
12	.7468	.7651	.6935
13	.7971	.7933	.7537
14	.8093	.7781	.7316
15	.8002	.7888	.7209
16	.7948	.7682	.6927
17	.7712	.7872	.6683
18	.7049	.6904	.6462
19	.8025	.8154	.8131
20	.8558	.8474	.8505
21	.932	.8916	.8634
22	1.0059	.9092	.881
23	.9816	.8901	.8627
24	.9313	.8429	.8223
Max	1.0059	.9092	.881
Min	.6592	.6904	.6462
Avg	.8159	.8103	.7618



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064040 / MIDC MOHADI

Feeder No / Name : 202 / 11 KV MOHADI MIDC  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1684	.2904
2		.3239	.3871
3		.3224	.3841
4		.3216	.365
5		.3208	.3064
6		.3246	.3307
7		.3307	.3155
8		.4291	.4298
9		.4397	.4367
10	.1783		.0091
11	.4085		.013
12	.4123	.0008	.0099
13	.4146	.0008	.0069
14	.41		.029
15	.4009		.0122
16	.4077	.0008	.0038
17	.4115		.0008
18	.3681		.0572
19			.0099
20			.0114
21			.029
22			.0107
24			.0404
Max	.4146	.4397	.4367
Min	.1783	.0008	.0008
Avg	.3791	.2486	.1517

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 201 / 11 KV BHAVAD FEEDER  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4954	.423	.3376
2	.4824		
3	.4801		
4	.4793		
5	.4748		
6	.4443		
7	.2538		
8	.1928		
9	.1966	.1517	.1456
10	.1936	.1082	.1715
11		.1494	.125
12		.1631	.192
13		.2439	.2462
14		.2705	.2629
15		.2599	.2507
16		.1433	.1966
17		.1738	.16
18	.202	.2904	.2317
19	.4451	.4001	.4306
20	.519	.4412	.4733
21	.5327	.4748	.455
22	.5136	.4877	.4687
23	.4938	.4656	.474
24	.4801	.4504	.471
Max	.5327	.4877	.474
Min	.1928	.1082	.125
Avg	.4047	.2998	.2996

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 202 / 11 KV GOSE FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	1.8701	1.8
2	1.7886	1.7154
3	1.7772	1.7032
4	1.7756	1.6933
5	1.7947	1.7132
6	1.7772	1.6911
7	1.3489	1.2902
8	1.0822	1.0143
9	1.0082	.9556
10	.7575	1.2033
11	2.0873	1.9593
12	2.2016	2.1735
13	2.1072	2.2657
14	2.1392	2.3122
15	2.1681	2.3541
16	1.8298	2.332
17	1.8214	2.3137
18	1.7711	2.1788
19	1.6735	1.8221
20	1.8854	2.0027
21	1.9418	2.0828
22	1.8953	2.0378
23	1.8587	1.9151
24	1.813	1.8366
Max	2.2016	2.3541
Min	.7575	.9556
Avg	1.7572	1.8486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 203 / 11 KV KONDHA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.0523	2.1917	2.0744
2	2.0073	2.2329	2.069
3	1.9791	2.2314	2.0348
4	1.9669	2.2146	2.034
5	1.9555	2.223	2.0348
6	1.7856	2.175	1.9723
7	1.3474	2.005	1.8427
8	1.2041	2.0233	1.9067
9	1.2894	2.082	1.685
10	1.3496	1.1142	1.0959
11	1.9319	1.262	1.2193
12	2.0165	1.3695	1.2841
13	2.0972	1.4563	1.419
14	2.0348	1.4769	1.3992
15	1.9913	1.4259	1.3634
16	1.9845	.9587	1.2277
17	2.0058	.6142	.98
18	2.0043	1.3847	1.3146
19	1.8656	1.7917	1.8839
20	1.986	1.8755	1.9715
21	2.1125	1.941	1.954
22	2.1628	2.0355	2.0767
23	2.0614	2.0187	2.0668
24	1.9654	1.9624	1.9898
Max	2.1628	2.2329	2.0767
Min	1.2041	.6142	.98
Avg	1.8816	1.7528	1.7042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 204 / 11 KV Virlee Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9305	.9899	1.2468	1.3649
2	.9069	.9396	1.9029	1.7086
3	.9015	.9305	1.8823	1.6926
4	.8932	.929	1.8831	1.6964
5	.8947	.9168	1.8724	1.685
6	.8672	.9008	1.8503	1.6674
7	.5243	.5906	1.7322	1.576
8	.3993	.426	1.7695	1.6171
9	.397	.4702	1.8092	1.6392
10	.3772	.8025	.4123	.3963
11	.4435	1.7459	.487	.3993
12	.4679	1.8343	.5502	.4222
13	.5075	1.8648	.5891	.4793
14	.5083	1.9075	.5998	.5136
15	.4961	1.8945	.5632	.5075
16	.4816	1.8153	.0419	.4291
17	.4496	1.8633	.2964	.378
18	.4588	1.8534	.2134	.3711
19	.945	.9785	.9114	.9823
20	1.0715	1.0738	1.0113	1.0997
21	1.1363	1.1126	1.0174	1.1309
22	1.1385	1.1043	1.0296	1.0623
23	1.0669	1.041	.9739	.9686
24	1.0059	.9998	.9358	.9313
Max	1.1385	1.9075	1.9029	1.7086
Min	.3772	.426	.0419	.3711
Avg	.7196	1.2077	1.0659	1.0299

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 205 / 11 KV Palora Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17
HR	Load (MW)	Load (MW)
1	1.3596	1.4243
2	1.5973	1.7787
3	1.6316	1.7688
4	1.6263	1.7627
5	1.6385	1.7795
6	1.6476	1.7642
7	1.7002	1.7901
8	1.7756	1.8793
9	1.8038	1.9166
10	.3955	.4793
11	.3589	.4138
12	.3826	.5396
13	.49	.5929
14	.4908	.5815
15	.4771	.57
16	.4374	.4854
17	.4001	.3917
18	.4854	.4191
19	.8573	.852
20	.881	.8741
21	.9114	.9122
22	.9381	.9305
23	.9236	.8985
24	.8901	.8627
Max	1.8038	1.9166
Min	.3589	.3917
Avg	1.0042	1.0695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 201 / 11 KV ADYAL FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6401	.6097	.6097
2	.5792	.6401	.5792	.5792
3	.5792	.6097	.5792	.5487
4	.6097	.6097	.5487	.5487
5	.5792	.6097	.6097	.5487
6	.5792	.6097	.5487	.5487
7	.4572	.4877	.4572	.4572
8	.4268	.4268	.3658	.3963
9	.4572	.4268	.4268	.4268
10	.4572	.4572	.4268	.3963
11	.5182	.4268	.4877	.4572
12	.5182	.4572	.4877	.4877
13	.4572	.4877	.5487	.5487
14	.4268	.5182	.5487	.5182
15	.4572	.4877	.5182	.5182
16	.4572	.4572	.4572	.5182
17	.4572	.4268	.4268	.4877
18	.5182	.4268	.4877	.4572
19	.6706	.5487	.6097	.6401
20	.6706	.6706	.6401	.6401
21	.6706	.6706	.6401	.7011
22	.7316	.6706	.6401	.6706
23	.7316	.6401	.6097	.6706
24	.6401	.6097	.6097	.6097
Max	.7316	.6706	.6401	.7011
Min	.4268	.4268	.3658	.3963
Avg	.5525	.5423	.5360	.5411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 203 / 11 KV Nerala Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2896	.2591	.2896
2	.3353	.2896	.2591	.2743
3	.3201	.2591	.2439	.2591
4	.2743	.2743	.2439	.2591
5	.2896	.2743	.2439	.2591
6	.2743	.2743	.2743	.2743
7	.2591	.2439	.2439	.2286
8	.2439	.2591	.3048	.2743
9	.2439	.2591	.3201	.2896
10	.2591	.2591	.3201	.3048
11	.2591	.2439	.3353	.3048
12	.2439	.2439	.3201	.2896
13	.2439	.2591	.3201	.2896
14	.2439	.2591	.3201	.3048
15	.2439	.2591	.3048	.3048
16	.2286	.2439	.2134	.3048
17	.2286	.2286	.2134	.2896
18	.2439	.2134	.2591	.2743
19	.3048	.2743	.2896	.3048
20	.3048	.3048	.3048	.2896
21	.3201	.3201	.3048	.3048
22	.3201	.3201	.3048	.2896
23	.3201	.3048	.2896	.2743
24	.3048	.2743	.2896	.2439
Max	.3353	.3201	.3353	.3048
Min	.2286	.2134	.2134	.2286
Avg	.2744	.2680	.2826	.2826



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 204 / 11 KV KABARA FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524
2	.1524	.1524	.1524
3	.1524	.1524	.1524
4	.1524	.1524	.1524
5	.1524	.1905	.1905
6	.1905	.1905	.2286
7	.1905	.2286	.2286
8	.1905	.1905	.1905
9	.1905	.1905	.1524
10	.1524	.1905	.1524
11	.1524	.1905	.1524
12	.1524	.1905	.1143
13	.1524	.1524	.1143
14	.1524	.1905	.1524
15	.1524	.1905	.1524
16	.1524	.1524	.1905
17	.1524	.1524	.1905
18	.1524	.1524	.1905
19	.1524	.1524	.1905
20	.1524	.1524	.1905
21	.1524	.1524	.1524
22	.1524	.1524	.1524
23	.1524	.1524	.1524
24	.1524	.1524	.1524
Max	.1905	.2286	.2286
Min	.1524	.1524	.1143
Avg	.1588	.1699	.1667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 202 / 11 KV Sawarla Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17
HR	Load (MW)
11	1.2803
12	1.4327
13	1.6461
14	1.7375
17	1.6156
18	1.5851
19	1.7985
20	1.7985
Max	1.7985
Min	1.2803
Avg	1.6118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 203 / 11 KV Amgaon Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
2	2.5301	2.4387
3	2.5301	2.4387
4	2.4996	2.4387
5	2.4996	2.4387
6	2.4996	2.4691
7	2.652	2.5301
8	2.9264	2.6825
9	2.8654	2.5606
Max	2.9264	2.6825
Min	2.4996	2.4387
Avg	2.6254	2.4996

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 206 / 11 KV SVK MILK PLANT

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762
2	.0762	.0762	.0762
3	.0762	.0762	.0762
4	.0762	.0762	.0762
5	.0762	.0762	.0762
6	.0762	.0762	.0762
7		.0762	
8	.0762	.0762	
9	.0762	.1524	.0762
10	.0762	.1524	.0762
11	.1524	.1524	.1524
12	.1524	.1524	.1524
13	.1524	.1524	.1524
14	.1524	.1524	.1524
15	.1524	.1524	.1524
16		.1524	.1524
17	.1524	.1524	.1524
18	.1524	.1524	.1524
19	.1524	.0762	.1524
20	.1524	.0762	.1524
21	.0762	.0762	.1524
22	.0762	.0762	.0762
23	.1524	.0762	.1524
24	.1524	.0762	.1524
Max	.1524	.1524	.1524
Min	.0762	.0762	.0762
Avg	.1143	.1080	.1212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 207 / 11 KV SHINDHPURI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
11	1.2269	1.0898
12	1.387	1.3946
13	1.4251	1.2574
14	1.448	1.3413
15	1.3108	1.3794
16	1.3108	1.3489
17	1.1812	1.2269
18	1.1888	1.2651
19	.2667	.2743
Max	1.448	1.3946
Min	.2667	.2743
Avg	1.1939	1.1753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 201 / 11 KV PAHELA-GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4572
2	.4572	.4572	.4572
3	.4572	.4572	.4572
4		.4572	.4572
5		.4572	.4572
6		.4572	.4572
7		.381	.381
8		.3048	.381
9		.381	.381
10		.381	.381
11		.381	.4572
12		.381	.4572
13		.381	.4572
14		.4572	.4572
15		.381	.4572
16		.381	.5335
17		.381	.4572
18		.381	.381
19		.4572	.5335
20		.5335	.5335
21		.5335	.5335
22		.5335	.5335
23		.5335	.5335
24		.5335	.5335
Max	.4572	.5335	.5335
Min	.4572	.3048	.381
Avg	.4572	.4350	.4636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 202 / 11 KV Wakeshwar Gaothan  
feeder Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381
2	.381	.381	.381
3	.381	.381	.381
4	.381	.3048	.381
5	.381	.381	.381
6	.381	.381	.381
7	.3048	.2286	.3048
8	.2286	.2286	.2286
9	.2286	.2286	.2286
10	.2286	.3048	.3048
11	.2286	.3048	.3048
12	.2286	.3048	.3048
13	.2286	.3048	.3048
14	.2286	.3048	.381
15	.2286	.3048	.3048
16	.2286	.2286	.2286
17	.2286	.2286	.3048
18	.2286	.3048	.2286
19	.4572	.381	.4572
20	.4572	.4572	.4572
21	.4572	.4572	.4572
22	.4572	.4572	.4572
23	.4572	.381	.4572
24	.381	.381	.381
Max	.4572	.4572	.4572
Min	.2286	.2286	.2286
Avg	.3239	.3334	.3493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 203 / 11 kv Nimgaon Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.381	.381	.381
2	.4572	.381	.381	.381
3	.4572	.381	.381	.381
4	.4572		.381	.381
5	.4572	.381	.381	.381
6	.381	.381	.381	.3048
7	.381	.3048	.3048	.3048
8	.381	.3048	.3048	.3048
9	.381	.3048	.3048	.3048
10	.381	.3048	.2286	.3048
11	.3048	.381	.3048	.3048
12	.3048	.381	.3048	.381
13	.3048	.381	.381	.381
14	.3048	.381	.381	.381
15	.381	.381	.381	.381
16	.381	.381	.381	.381
17	.381	.381	.3048	.0762
18	.381	.381	.3048	.0762
19	.381	.381	.381	.3048
20	.4572	.381	.381	.3048
21	.4572	.381	.381	.3048
22	.4572	.381	.381	.3048
23	.4572	.381	.381	.3048
24	.381	.381	.381	.3048
Max	.4572	.381	.381	.381
Min	.3048	.3048	.2286	.0762
Avg	.3969	.3677	.3524	.3175



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 205 / 11 KV PAHELA-AG FEEDER

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.3384	.2919
2	.3635	.3643
3	.3163	.3018
4	.2911	.301
5	.2911	.2972
6	.3071	.3071
7	.3483	.3406
8	.407	.4527
9	.4146	.4557
Max	.4146	.4557
Min	.2911	.2919
Avg	.3419	.3458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 204 / 11 KV ASGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5876	.5914	.5693
2	.5685	.5761	.5464
3	.5677	.5693	.5357
4	.5777	.5693	.5319
5	.5838	.5822	.5563
6	.5914	.5723	.5403
7	.4923	.4595	.439
8	.4489	.3932	.4024
9	.4351	.3826	.3498
10	.439	.3887	.3757
11	.4443	.3925	.439
12	.4268	.4146	.4313
13	.4626	.4291	.4329
14	.4595	.4336	.3673
15	.4344	.423	.3727
16	.3727	.3277	.4268
17	.3353	.3742	.4252
18	.3102	.423	.4016
19	.5456	.535	.5655
20	.5845	.5792	.5937
21	.6219	.5868	.6264
22	.6287	.5906	.6234
23	.6196	.5921	.6051
24	.6028	.5769	.5937
Max	.6287	.5921	.6264
Min	.3102	.3277	.3498
Avg	.5059	.4901	.4896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 205 / 11 KV KHAIRY-AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.3062	1.1881
2		1.3656	1.2308
3		1.3588	1.2163
4		1.3542	1.2193
5		1.3672	1.2163
6		1.374	1.233
7		1.4388	1.3154
8		1.5463	1.3321
9		1.6088	1.3923
10	1.2346		
11	1.4647		
12	1.5226		
13	1.5623		
14	1.5943		
15	1.6049		
16	1.6049		
17	1.6293		
18	1.6446		
Max	1.6446	1.6088	1.3923
Min	1.2346	1.3062	1.1881
Avg	1.5402	1.4133	1.2604

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 208 / 11 KV DHAMNI - G feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.5335	.4572
2	.5335	.4572
3	.4572	.4572
4	.4572	.4572
5	.4572	.4572
6	.4572	.4572
7	.4572	.4572
8	.381	.3048
9	.2286	.2286
10	.2286	.2286
11	.2286	.2286
12	.2286	.2286
13	.3048	.2286
14	.3048	.3048
15	.381	.3048
16	.381	.3048
17	.3048	.2286
18	.2286	.2286
19	.3048	.2286
20	.4572	.4572
21	.4572	.4572
22	.5335	.5335
23	.5335	.5335
24	.5335	.4572
Max	.5335	.5335
Min	.2286	.2286
Avg	.3905	.3620

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 201 / 11 KV PAUNA KH -AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.4839	.4481
2		.9221	.8398
3		.9229	.8352
4		.9221	.8368
5		.9236	.8345
6		.9366	.8672
7		1.0273	.9602
8		1.0806	1.0349
9		.8893	.8627
10	.4557		.0876
11	1.1424		
12	1.2292		
13	1.2414		
14	1.2056		
15	1.243		
16	1.246		
17	1.2567		
18	1.2414		
Max	1.2567	1.0806	1.0349
Min	.4557	.4839	.0876
Avg	1.1402	.9009	.7607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 202 / 11 KV SHIVNALA-AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3612	.3185
2		.6158	.5228
3		.6135	.5396
4		.6142	.538
5		.6158	.5373
6		.6424	.5517
7		.7186	.5731
8		.7743	.5197
9		.7857	.5335
10	.3056		
11	.7659		
12	.8284		
13	.849		
14	.8634		
15	.8589		
16	.8467		
17	.8551		
18	.8589		
Max	.8634	.7857	.5731
Min	.3056	.3612	.3185
Avg	.7813	.6379	.5149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 203 / 11 KV BHENDALA-GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7476	.7255	.7164
2	.7354	.7217	.7011
3	.7278	.7179	.6927
4	.6859	.7179	.6859
5	.7316	.7339	.7156
6	.7141	.7202	.7072
7	.5403	.5396	.5403
8	.4786	.4793	.4344
9	.4451	.4618	.4618
10	.4481	.5274	.5037
11	.5418	.6051	.554
12	.5449	.6523	.5914
13	.554	.631	.6142
14	.4588	.6066	.5053
15	.4588	.551	.5114
16	.4092	.4184	.4443
17	.3429	.4893	.3757
18	.381	.5495	.4161
19	.6226	.6401	.6295
20	.6996	.6592	.6821
21	.7377	.7095	.6965
22	.7598	.7285	.7727
23	.7628	.7407	.7758
24	.7468	.7331	.727
Max	.7628	.7407	.7758
Min	.3429	.4184	.3757
Avg	.5948	.6275	.6023

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 402 / 33 KV Gose feeder INCOMER

Feeder KV- 33 / INCOMING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	2.7435	2.7435
2	7.316	6.4015
3	7.316	6.4015
4	6.4015	6.4015
5	6.4015	6.4015
6	6.4015	6.4015
7	6.4015	6.4015
8	7.316	6.4015
9	7.316	7.316
10	1.829	1.829
11	3.658	2.7435
12	3.658	3.658
13	4.5725	3.658
14	4.5725	3.658
15	3.658	3.658
16	3.658	3.658
17	3.658	3.658
18	3.658	3.658
19	2.7435	2.7435
20	2.7435	3.658
21	2.7435	3.658
22	2.7435	3.658
23	2.7435	3.658
24	2.7435	2.7435
Max	7.316	7.316
Min	1.829	1.829
Avg	4.4582	4.3820



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 208 / 11 KV Lohara AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.4092	.4039
2	.8787	.7865
3	.8162	.7644
4	.7895	.7697
5	.7842	.7758
6	.7994	.7682
7	.8764	.8688
8	.9602	1.0067
9	.8269	1.0219
Max	.9602	1.0219
Min	.4092	.4039
Avg	.7934	.7962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 207 / 11 KV Bagheda

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6872	1.5402	1.4982
2	1.672	1.5409	1.483
3	1.6659	1.4632	1.4548
4	1.6568	1.4586	1.4502
5	1.6476	1.4586	1.4373
6	1.4312	1.4617	1.4403
7	1.3809	1.3016	1.2833
8	1.3443	1.2955	1.2437
9	1.3603	1.3184	1.2719
10	.8733	1.3771	1.2597
11	1.3908	1.5226	1.3931
12	1.4464	1.6004	1.3756
13	1.5127	1.6476	1.3695
14	1.5615	1.5127	1.3634
15	1.5463	1.6415	1.243
16	1.4975	1.6019	1.2841
17	1.4891	1.5059	1.3237
18	1.4777	1.4876	1.3138
19	1.7055	1.6438	1.6141
20	1.7513	1.6446	1.5257
21	1.7657	1.6644	1.5455
22	1.6331	1.6202	1.5165
23	1.6027	1.5653	1.4472
24	1.56	1.5242	1.3916
Max	1.7657	1.6644	1.6141
Min	.8733	1.2955	1.243
Avg	1.5275	1.5166	1.3971

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 209 / 11 KV Dongri bz

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0098	1.1104	1.2026
2	.9976	1.0898	1.1934
3	.9869	1.0799	1.1614
4	.98	1.0722	1.1538
5	.9671		1.1599
6	.9717		1.1599
7	.9427		1.1035
8	1.0006	.7606	1.1035
9	1.0661	.9633	1.1325
10	1.1309	1.0364	.9945
11	1.1805	1.1088	1.1347
12	.9998	1.1744	1.1713
13	1.1065	1.3253	1.2087
14	1.1835	1.2414	1.1629
15	1.1789	1.2148	1.1957
16	1.1789	1.2056	1.217
17	1.1827	1.3253	1.2109
18	1.2353	1.3199	1.1805
19	1.4929	1.4662	1.3458
20	1.4883	1.4838	1.3656
21	1.4868	1.467	1.1096
22	1.2163	1.3641	1.1058
23	1.1591	1.2788	1.0219
24	1.1424	1.2148	.9686
Max	1.4929	1.4838	1.3656
Min	.9427	.7606	.9686
Avg	1.1369	1.2049	1.1568

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 210 / 11 KV Chikhala

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8711	.3544	.4127	.5316
2	.9442	.3304	.3616	.6283
3	.8642	.3216	.3414	.5437
4	.7209	.3147	.341	.4519
5	.8558	.3163	.3281	.4557
6	.9808	.3094	.333	.4401
7	.756	.3201	.45	.3681
8	.5845	.3052	.4553	.4572
9	.6676	.2934	.4077	.3909
10	.6226	.4138	.7686	.2957
11	.538	.3902	.7373	.3311
12	.6653	.3429	.7343	.3547
13	.5228	.3647	.6619	.4226
14	.6104	.3487	.5689	.325
15	.6485	.3494	.612	.3102
16	.6401	.3319	.4096	.3323
17	.8459	.4016	.6215	.3304
18	.5693	.3117	.9614	.3662
19	.6264	.3155	.8592	.2976
20	.7118	.3304	.6542	.2804
21	.6158	.3258	.4473	.3003
22	.6455	.3357	.4195	.2984
23	.6584	.2877	.4515	.3128
24	.6371	.2869	.2778	.3437
Max	.9808	.4138	.9614	.6283
Min	.5228	.2869	.2778	.2804
Avg	.7001	.3334	.5257	.3820

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 211 / 11 KV Nakadongari AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8101	.8878	.8871
2	.8093	.9168	.9084
3	.7926	.9122	.9061
4	.7796	.9031	.8993
5	.7735	.9008	.8977
6	.788	.8993	.8954
7	.7087	.8345	.8383
8	.6097	.724	.7644
9	.6363	.7179	.7697
10	.6569	.5914	.5777
11	.7598	.6165	.6036
12	.8048	.6264	.644
13	.8444	.644	.6462
14	.852	.6523	.6478
15	.8444	.6249	.6523
16	.8581	.599	.6325
17	.7712	.612	.6211
18	.7339	.6767	.6341
19	.8269	.9145	.9183
20	.8558	.948	.9198
21	.916	.9686	.9335
22	.9297	.9518	.9259
23	.9175	.9107	.8711
24	.8718	.8642	.8253
Max	.9297	.9686	.9335
Min	.6097	.5914	.5777
Avg	.7980	.7874	.7842

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)

Feeder No / Name : 201 / 11 KV EMD

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5662	.0427		
2	.5426	.032		
3	.5517	.0251		
4	.5213			
5	.5167			
6	.5068			
7	.4877			
8	.5296			
9	.5898			
10	.5228		.1113	.0998
11	.4717		.0008	.1097
12	.5647		.0008	.0716
13	.551		.0061	
14	.5517			
15	.5479			
16	.1707		.1242	
17	.1539		.1067	
18	.1364		.061	
19	.1265		.0008	
20	.1349		.003	
21	.0998			
22	.0655			
23	.0732			
24	.0602			
Max	.5898	.0427	.1242	.1097
Min	.0602	.0251	.0008	.0716
Avg	.3768	.0333	.0461	.0937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)

Feeder No / Name : 202 / 11kv Balapur

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.538	.506	.2949	.4961
2	.5411	.5251	.2888	.4992
3	.538	.5563	.2934	.4946
4	.4633	.5479	.2926	.4984
5	.4755	.5312	.285	.4946
6	.4755	.3391	.285	.2995
7	.4115	.2378	.2355	.237
8	.3948	.221	.3948	.2241
9	.4672	.394	.4085	.1532
10	.5022	.4062	.4809	.1638
11	.4702	.4595	.4854	.16
12	.4938	.4504	.4885	.2454
13	.2233	.4694	.2957	.3894
14	.2301	.4771	.234	.2202
15	.4024	.3277	.2561	.2606
16	.4626	.2256	.426	.4047
17	.4832	.2218	.4374	.3917
18	.455	.218	.4512	.3224
19	.5197	.3086	.5289	.2439
20	.3346	.3033	.5662	.2858
21	.3361	.2926	.5738	.3048
22	.3315	.314	.3292	.3117
23	.3064	.3117	.3521	.3048
24	.4946	.3025	.5075	.3003
Max	.5411	.5563	.5738	.4992
Min	.2233	.218	.234	.1532
Avg	.4313	.3728	.3830	.3211

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 211 / 11 KV Sihora SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17
HR	Load (MW)
11	.884
12	.884
13	.945
14	.945
15	.945
16	.884
17	.7316
18	1.0364
Max	1.0364
Min	.7316
Avg	.9069



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 212 / 11 KV Bapera SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
2		.945	.945
3		.945	.9145
4		.945	.9145
5		.945	.9145
6		.945	.9145
7		.945	.9145
8		1.0059	.945
9		.9755	.9145
11	.9145		
12	.9755		
13	.945		
14	.945		
15	.9755		
17	1.0059		
18	.9145		
Max	1.0059	1.0059	.945
Min	.9145	.945	.9145
Avg	.9537	.9564	.9221

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 213 / 11 KV Gondekhari SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.5546	1.6156
3			1.5242	1.6156
4			1.4937	1.6156
5			1.5242	1.6156
6			1.5242	1.6156
7			1.6156	1.6461
8			1.6766	1.6766
9			1.6766	1.7375
11	1.6461	1.7985		
12	1.768	1.7985		
13	1.6766	1.768		
14	1.768	1.7985		
15	1.5851	1.768		
16	1.7375	1.6156		
17	1.6766	1.6766		
18	1.6156	1.7375		
Max	1.768	1.7985	1.6766	1.7375
Min	1.5851	1.6156	1.4937	1.6156
Avg	1.6842	1.7452	1.5737	1.6423

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 214 / 11 KV Silegaon SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.1355	1.1965	1.2193
2	1.1355	1.5546	1.4327
3	1.1355	1.547	1.4403
4	1.1355	1.547	1.4556
5	1.1431	1.5394	1.4556
6	1.1203	1.5394	1.4327
7	.8612	1.547	1.4327
8	.7316	1.5089	1.4708
9	.7087	1.4556	1.4175
10	.9526	.724	.6859
11	1.448	.7392	.7164
12	1.6385	.8078	.7545
13	1.669	.8002	.8154
14	1.7147	.8307	.8154
15	1.7299	.8002	.8002
16	1.6918	.7316	.6554
17	1.6842	.7011	.6249
18	1.6309	.8612	.5639
19	1.1507	1.1736	1.044
20	1.2422	1.2041	1.1279
21	1.2346	1.2422	1.1355
22	1.2117	1.2041	1.0593
23	1.166	1.1507	1.0212
24	1.1279	1.1126	.9907
Max	1.7299	1.5546	1.4708
Min	.7087	.7011	.5639
Avg	1.2667	1.1466	1.0653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 215 / 11 KV Karkapur SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
2	1.0364	1.0364
3	1.0364	1.0364
4	1.0364	1.0364
5	1.0364	1.0364
6	1.0669	1.0669
7	1.0669	1.0974
8	1.0669	1.1584
9	1.0974	1.1279
Max	1.0974	1.1584
Min	1.0364	1.0364
Avg	1.0555	1.0745

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 203 / 11 KV TUMSAR town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.644	.6783	.6706	.5982
2	.6059	.6249	.6363	.5677
3	.5792	.602	.6249	.5487
4	.5639	.5944	.6097	.5373
5	.5601	.5944	.6097	.5335
6	.5563	.5982	.5944	.5335
7	.5335	.5563	.5601	.522
8	.5754	.5944	.583	.5677
9	.5716	.5944	.5639	.5335
10	.6363	.6059	.5754	.5258
11	.7049	.6516	.6287	.6325
12	.7849	.6897	.663	.6897
13	.8002	.6935	.6935	.7278
14	.7735	.7087	.6935	.7049
15	.7659	.6897	.7164	.6859
16	.7735	.6783	.6859	.6973
17	.7506	.6744	.7011	.7087
18	.7735	.6859	.8002	.743
19	.8916	.743	.8421	.8802
20	.8878	.6668	.8154	.8421
21	.8154	.6783	.7468	.804
22	.7392	.6935	.6516	.6973
23	.724	.724	.6516	.6173
24	.724	.7164	.6287	.6478
Max	.8916	.743	.8421	.8802
Min	.5335	.5563	.5601	.522
Avg	.6973	.6557	.6644	.6478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 204 / 11 KV JAMB town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0174	2.1033	2.7588	2.492
2	.964	2.0271	2.6368	2.3701
3	.9297	1.9662	2.5911	2.3168
4	.9107	1.9204	2.5225	2.2787
5	.9183	1.8671	2.4844	2.2329
6	.9107	1.8442	2.4463	2.271
7	.8802	1.6994	2.3244	2.1644
8	.8002	1.6766	2.0804	2.0347
9	.7964	1.6842	2.0728	1.9052
10	.7888	1.7071	2.0118	2.0042
11	.7811	1.7223	2.1566	1.9737
12	.7811	1.6918	2.1109	2.0118
13	.7811	1.6766	2.1033	2.0957
14	.8116	1.7147	2.1947	2.1566
15	.8192	1.7528	2.1033	2.2025
16	.8269	1.7452	2.0347	2.0804
17	.7926	1.6385	1.8823	2.0118
18	.8078	1.5546	1.9356	1.9433
19	1.025	1.89	2.4692	2.4768
20	1.0021	1.8214	2.5606	2.5911
21	1.0136	1.9814	2.5759	2.713
22	1.1088	2.2481	2.6749	2.774
23	1.166	2.3396	2.6978	2.7892
24	1.1393	2.271	2.5987	2.6597
Max	1.166	2.3396	2.7588	2.7892
Min	.7811	1.5546	1.8823	1.9052
Avg	.9072	1.8560	2.3345	2.2729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064040 / MIDC MOHADI

Feeder No / Name : 204 / 11kv Khapa Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9625	.8764	.8116
2	.9518	.8589	.7926
3	.9435	.852	.7796
4	.9389	.8535	.7766
5	.9435	.8619	.7888
6	.9252	.8558	.788
7	.8116	.772	.6889
8	.7209	.6508	.5792
9	.7247	.6333	.5586
10	.7545	.6485	.5441
11	.7453	.6615	.8345
12	.7453	.6783	.932
13	.7583	.8977	
14	.7583	.9076	.3574
15	.7552	.7987	.9564
16	.724	.7392	.8909
17	.6173	.8101	.8932
18	.5815	.7575	.8505
19	.7575	.8871	.8993
20	.7903	.8718	.9145
21	.8962	.8916	.9473
22	.9244	.9008	.961
23	.9366	.8672	.9473
24	.8932	.8474	.9122
Max	.9625	.9076	.961
Min	.5815	.6333	.3574
Avg	.8150	.8075	.8002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 203 / 11 KV Betala G Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6592	.6356	.6234
2	.6539	2.8845	2.8083
3	.631	2.8929	2.7603
4	.6272	2.8753	2.4501
5	.6531	2.8875	2.6124
6	.6523	2.9142	2.6299
7	.615	2.8982	2.6414
8	.4146	2.915	2.8555
9	.4009	2.9927	2.8822
10	.4626	3.0171	2.4623
11	2.7953	.4298	.3978
12	3.0056	.4374	.4222
13	3.1161	.4611	.4618
14	3.2068	.3849	.4481
15	3.283	.4672	.4862
16	3.2053	.4481	.4473
17	3.1238	.3849	.3849
18	2.9409	.378	.3628
19	2.223	.5121	.4649
20	.6173	.6333	.644
21	.6554	.6683	.6943
22	.7354	.6996	.7316
23	.7217	.6988	.7156
24	.6706	.6417	.6912
Max	3.283	3.0171	2.8822
Min	.4009	.378	.3628
Avg	1.5029	1.4233	1.3366



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 205 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6569	.6783
2	.6714	.6729	.6882
3	.6904	.6729	.6882
4	.6729	.6729	.6882
5	.6676	.6706	.6813
6	.6714	.6714	.6866
7	.676	.6943	.7034
8	.6729	.6889	.6813
9	.7087	.6714	.5662
10	.7057	.6394	.6333
11	.6859	.6904	.6409
12	.6851	.695	.6569
13	.6767	.6783	.6691
14	.6653	.6432	.6447
15	.6638	.6699	.6546
16	.6653	.6859	.6653
17	.6668	.6958	.6706
18	.679	.6889	.6699
19	.6676	.6661	.6539
20	.6615	.6737	.66
21	.66	.6828	.6943
22	.6607	.6783	.6904
23	.6478	.6874	.6516
24	.6569	.6882	.6615
Max	.7087	.6958	.7034
Min	.6478	.6394	.5662
Avg	.6736	.6765	.6658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 206 / 11 KV UFIL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.4159	1.4982	.5388
2	1.3115	1.4525	.5396
3	1.3428	1.3237	.5632
4	1.4007	1.2285	.5914
5	1.217	.9092	.6722
6	1.057	.7331	.8909
7	1.2582	.7461	1.1698
8	1.2955	.7194	1.3923
9	1.262	.7423	1.5082
10	1.3946	.6272	1.4022
11	1.5638	.5982	1.467
12	1.4609	.5647	1.4304
13	1.4068	.5769	1.2178
14	1.3733	.5708	1.2056
15	1.3824	.554	1.4289
16	1.4159	.5426	1.4472
17	1.4038	.5266	1.4114
18	1.342	.5258	1.3474
19	1.3977	.5556	1.4289
20	1.323	.5525	1.3557
21	1.233	.5502	1.3207
22	1.3237	.5251	1.2468
23	1.4739	.5197	1.419
24	1.4182	.5136	1.4571
Max	1.5638	1.4982	1.5082
Min	1.057	.5136	.5388
Avg	1.3531	.7357	1.1855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 201 / 11 KV LAKHANDUR FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.4336	.4111
2	.4214	.3909
3	.407	.3784
4	.4058	.3795
5	.4081	.3723
6	.4043	.386
7	.3643	.3662
8	.306	.3041
9	.2984	.2839
10	.3083	.2919
11	.3346	.3014
12	.3723	.3395
13	.3906	.3662
14	.4199	.3696
15	.4123	.3974
16	.3734	.4054
17	.3323	.3829
18	.3669	.3597
19	.4614	.4793
20	.4797	.5224
21	.4759	.4767
22	.474	.4904
23	.4572	.4858
24	.439	.4588
Max	.4797	.5224
Min	.2984	.2839
Avg	.3978	.3917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 203 / 11 KV PERSODI AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
11	.5967	.4001
12	.7019	.4222
13	.7232	.3864
14	.7506	.5586
15	.7308	.5868
16	.5815	.5502
17	.0053	.5533
18		.5571
19		.237
Max	.7506	.5868
Min	.0053	.237
Avg	.5843	.4724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 204 / 11 KV BARWA AG FEEDER ( FEEDER SEPERATION/PURE AG  
CHICHO Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
2	.2568	.1768
3	.2553	.1753
4	.2538	.1745
5	.2515	.176
6	.2492	.1745
7	.2614	.1753
8	.2904	.2058
9	.3155	.1981
10	.1616	.0991
Max	.3155	.2058
Min	.1616	.0991
Avg	.2551	.1728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 205 / 11 KV REST HOUSE Feeder SEPARATED GAOTHAN FEEDERS  
Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2484	.2484	.2282
2	.245	.2393	.221
3	.2385	.2374	.2134
4	.2351	.2321	.2122
5	.2313	.2298	.2096
6	.2374	.2561	.2366
7	.2583	.2629	.2545
8	.202	.1936	.2035
9	.2046	.1768	.1795
10	.2027	.1859	.181
11	.1989	.1848	.189
12	.1993	.1951	.1821
13	.1593	.1612	.1459
14	.1718	.1658	.16
15	.1753	.1699	.1612
16	.1684	.1128	.1497
17	.1497	.1551	.1349
18	.1219	.1589	.1425
19	.1692	.2298	.2199
20	.2564	.253	.2721
21	.269	.2591	.277
22	.2751	.2587	.2785
23	.2755	.2515	.2675
24	.2519	.2362	.2488
Max	.2755	.2629	.2785
Min	.1219	.1128	.1349
Avg	.2144	.2106	.2070

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 206 / 11 KV SONI AG Feeder FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
2		.33	.3483
3		.33	.3536
4		.3414	.3544
5		.3391	.3551
6		.333	.3574
7		.3437	.3635
8		.3551	.4809
9		.3955	.5159
10		.1989	.2561
11	.4062		
12	.5327		
13	.5609		
14	.5784		
15	.6135		
16	.6318		
17	.6363		
18	.5373		
19	.2683		
Max	.6363	.3955	.5159
Min	.2683	.1989	.2561
Avg	.5295	.3296	.3761

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 207 / 11 KV Parsodi Gaothan SEPARATED GAOTHAN FEEDERS  
Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1128	.1135	.0987
2	.1067	.1101	.0968
3	.1063	.109	.0934
4	.1048	.1071	.0926
5	.1048	.1067	.0934
6	.1017	.104	.0945
7	.0911	.085	.0796
8	.053	.0522	.0541
9	.0545	.0606	.0617
10	.0572	.0583	.0373
11	.0541	.0537	.0488
12	.0621	.0541	.053
13	.0678	.0537	.0541
14	.0735	.0522	.0606
15	.0701	.061	.0495
16	.0667	.0453	.0492
17	.0625	.0476	.0476
18	.0472	.08	.064
19	.085	.1002	.1055
20	.1303	.1254	.1315
21	.1349	.1177	.1349
22	.1276	.1124	.1284
23	.12	.1055	.1185
24	.1139	.1002	.1113
Max	.1349	.1254	.1349
Min	.0472	.0453	.0373
Avg	.0879	.0840	.0816



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 208 / 11 KV Barwha Gaothan GAOTHAN FEEDER  
 (CHICHOLI Feeder KV- 11 /  
 OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.1905	.1905
2	.1905	.1905
3	.1905	.1524
4	.1905	.1524
5	.1905	.1524
6	.1905	.1524
7	.1524	.1524
8	.1143	.0762
9	.0762	.0762
10	.0762	.0762
11	.0762	.0381
12	.0762	.0762
13	.0762	.0762
14	.0762	.0762
15	.1143	.0762
16	.0762	.1143
17	.0762	.0762
18	.1143	.0762
19	.1524	.1524
20	.1905	.1905
21	.1905	.2286
22	.1905	.2286
23	.1905	.1905
24	.1905	.1905
Max	.1905	.2286
Min	.0762	.0381
Avg	.1397	.1318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 209 / 11 KV Soni Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.4191	.381
2	.381	.381
3	.381	.3429
4	.381	.3429
5	.381	.3429
6	.381	.3429
7	.3429	.3048
8	.1905	.1905
9	.1524	.1524
10	.1524	.1524
11	.2667	.2286
12	.2667	.2667
13	.2667	.3429
14	.2667	.381
15	.3048	.4191
16	.2286	.381
17	.2667	.3429
18	.3429	.381
19	.4191	.4954
20	.4572	.4954
21	.4572	.4954
22	.4191	.4954
23	.4191	.4191
24	.381	.4191
Max	.4572	.4954
Min	.1524	.1524
Avg	.3302	.3540

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 201 / 11 KV VIRLEE AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.4076	1.2079
2		1.6171	1.4228
3		1.6347	1.4411
4		1.6095	1.4617
5		1.611	1.4617
6		1.6499	1.5066
7		1.7703	1.6751
8		1.8633	1.7886
9		1.8801	1.7627
10	.9991		
11	1.7231		
12	1.8983		
13	1.8473		
14	1.8633		
15	1.8808		
16	2.0195		
17	2.0911		
18	2.1232		
Max	2.1232	1.8801	1.7886
Min	.9991	1.4076	1.2079
Avg	1.8273	1.6715	1.5254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 202 / 11 KV GOURALA AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0137	.0297		
2	1.483	1.5539		
3	1.5036	1.5676		
4	1.4952	1.5691		
5	1.4251	1.5272		
6	1.4906	1.5287		
7	1.6857	1.7391		
8	1.9075	1.9959		
9	1.9822	2.1209		
10		.0305	.0023	.0343
11			2.2687	1.9212
12			2.4912	2.1597
13			2.4829	2.0401
14			2.5126	2.1254
15			2.303	2.0447
16			2.274	2.0622
17			1.9052	2.1491
18			1.8023	2.2337
Max	1.9822	2.1209	2.5126	2.2337
Min	.0137	.0297	.0023	.0343
Avg	1.4430	1.3663	2.0047	1.8634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 203 / 11 KV Kiramati AG Feeder FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.5479		
3	.5472		
4	.5464		
5	.5453		
6	.5426		
7	.5582		
8	.5811		
9	.5857		
10	.1002		
11		.7247	.708
12		.8482	.7834
13		.844	.7899
14		.8718	.8112
15		.8726	.8219
16		.8612	.8379
17		.7278	.8448
18		.7244	.8326
19		.096	.0998
Max	.5857	.8726	.8448
Min	.1002	.096	.0998
Avg	.5061	.7301	.7255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 204 / 11 KV Kiramti Gaothan

SEPARATED GAOTHAN FEEDERS

Feeder Feeder KV- 11 /  
OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143
2	.0762	.0762	.0762
3	.0762	.0762	.0762
4	.0762	.0762	.0762
5	.0762	.0762	.0762
6	.0762	.0762	.1143
7	.0762	.0762	.0762
8	.0381	.0381	.0381
9	.0381	.0381	.0381
10	.0381	.0381	.0381
11	.0381	.0381	.0381
12	.0762	.0381	.0381
13	.0762	.0381	.0381
14	.0762	.0381	.0381
15	.0381	.0381	.0381
16	.0381	.0381	.0381
17	.0381	.0381	.0381
18	.0381	.0762	.0381
19	.0762	.0762	.1143
20	.1143	.1143	.1143
21	.1143	.1143	.1143
22	.1143	.1143	.1143
23	.1143	.1143	.1143
24	.1143	.0762	.1143
Max	.1143	.1143	.1143
Min	.0381	.0381	.0381
Avg	.0730	.0683	.0714

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 205 / 11kv virli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381
2	.381	.381	.381
3	.381	.381	.3048
4	.381	.381	.3048
5	.381	.381	.3048
6	.381	.381	.3048
7	.3048	.3048	.3048
8	.1524	.1524	.2286
9	.1524	.1524	.1524
10	.2286	.0762	.1524
11	.2286	.2286	.1524
12	.2286	.3048	.2286
13	.2286	.3048	.2286
14	.2286	.3048	.2286
15	.2286	.2286	.2286
16	.2286	.2286	.2286
17	.2286	.2286	.2286
18	.2286	.2286	.1524
19	.381	.381	.3048
20	.4572	.381	.4572
21	.4572	.4572	.4572
22	.4572	.4572	.4572
23	.4572	.381	.4572
24	.381	.381	.381
Max	.4572	.4572	.4572
Min	.1524	.0762	.1524
Avg	.3143	.3112	.2921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 201 / 11 KV Barwaha Feeder  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4329		
2	.439		
3	.4405		
4	.442		
5	.4397		
6	.4618		
7	.5022		
8	.5845		
9	.57		
10		.567	
11		.7781	
12		.8253	
13		.8406	
14		.8467	.0008
15		.8269	.2012
16		.0213	.2324
17			.2347
18			.2446
Max	.5845	.8467	.2446
Min	.4329	.0213	.0008
Avg	.4792	.6723	.1827



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 204 / 11KVCHIKANA (GAOTHAN)  
Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524
2	.1524	.1524	.1143
3	.1524	.1524	.1143
4	.1524	.1524	.1143
5	.1524	.1524	.1143
6	.1524	.1524	.1143
7	.1143	.1143	.0762
8	.0762	.0762	.0762
9	.0762	.0762	.0762
10	.0762	.0762	.0762
11	.0762	.0762	.0762
12	.0762	.0762	.0762
13	.1143	.0762	.0762
14	.1143	.1143	.1143
15	.0762	.1143	.0762
16	.0762		.0762
17	.0381	.0381	.0762
18	.0762	.1143	.0762
19	.1524	.1524	.1905
20	.1905	.1524	.1905
21	.1905	.1524	.1905
22	.1905	.1524	.1905
23	.1905	.1524	.1905
24	.1524	.1524	.1524
Max	.1905	.1524	.1905
Min	.0381	.0381	.0762
Avg	.1238	.1209	.1159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 205 / BARWHA GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4191	.381
2	.381	.4191	.381
3	.381	.381	.3429
4	.381	.381	.3429
5	.381	.381	.3429
6	.381	.3429	.3429
7	.2286	.2286	.2286
8	.1905	.1524	.1524
9	.2286	.1905	.1524
10	.2286	.1905	.1524
11	.2286	.1905	.1524
12	.2286	.2286	.2286
13	.2667	.2667	.2667
14	.2667	.3048	.2286
15	.2667	.2667	.2286
16	.2286	.0762	.2286
17	.1905	.1143	.1905
18	.1905	.3048	.2667
19	.381	.381	.4572
20	.4572	.4191	.4954
21	.4572	.4191	.4954
22	.4572	.4191	.4572
23	.4191	.381	.4191
24	.4191	.381	.4191
Max	.4572	.4191	.4954
Min	.1905	.0762	.1524
Avg	.3191	.3016	.3064

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 206 / Murmadi Gaothaon

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905
2	.1905	.1905	.1905
3	.1905	.1905	.1905
4	.1524	.1905	.1905
5	.1524	.1905	.1905
6	.1524	.1905	.1524
7	.1143	.1143	.1143
8	.0762	.0762	.0762
9	.0762	.0762	.0762
10	.0762	.0762	.0762
11	.0762	.0762	.0762
12	.0762	.1143	.0762
13	.0762	.1143	.1143
14	.0762	.1143	.1143
15	.0762	.1143	.1143
16	.0762	.0762	.1143
17	.0762	.0762	.0762
18	.1143	.1143	.1143
19	.2286	.1905	.2286
20	.2286	.2286	.2667
21	.2286	.2286	.2286
22	.2286	.1905	.2286
23	.2286	.1905	.2286
24	.1905	.1905	.1905
Max	.2286	.2286	.2667
Min	.0762	.0762	.0762
Avg	.1397	.1461	.1508

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 201 / kudegaon

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.6097	
2	.7621	.8383	1.5242	
3	.7621	.8383	1.5242	
4	.7621	.8383	1.5242	
5	.7621	.8383	1.5242	
6	.7621	.8383	1.6004	
7	.9145	.9907	1.7528	
8	.9907	.9907	1.9814	
9	1.0669	.9907	1.9814	
10	.6097	.6859	.381	.4572
11	1.9052	2.0576	1.2193	1.1431
12	1.9052	2.0576	1.3717	1.2193
13	1.6766	2.0576	1.3717	1.2193
14	1.7528	1.829	1.2193	2.3624
15		1.9052	1.2193	2.4387
16		1.9052	.6859	2.7435
17		1.9814	.9145	2.8959
18		1.9814	.9145	2.8959
19				1.6004
20				1.6004
21				1.6004
22				.0762
Max	1.9052	2.0576	1.9814	2.8959
Min	.3048	.3048	.381	.0762
Avg	1.0669	1.3294	1.2955	1.7117

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 203 / 11 KV KUDEGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.4572	.381
2	.4572	.381
3	.4572	.381
4	.4572	.381
5	.4572	.381
6	.4572	.381
7	.3048	.3048
8	.2286	.2286
9	.2286	.2286
10	.2286	.2286
11	.2286	.1524
12	.3048	.2286
13	.3048	.2286
14	.3048	.2286
15	.3048	.2286
16	.1524	.2286
17	.2286	.2286
18	.3048	.3048
19	.4572	.5335
20	.5335	.5335
21	.5335	.5335
22	.4572	.5335
23	.4572	.4572
24	.381	.4572
Max	.5335	.5335
Min	.1524	.1524
Avg	.3620	.3397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 201 / 11 KV DHOLSAR FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3887	.3887	.2858
2	.378	.3818	.2774
3	.3734	.3833	.2721
4	.3742	.3833	.2713
5	.3742	.3818	.2713
6	.3696	.3765	.2683
7	.2751	.3696	.2622
8	.2629	.3727	.25
9	.2774	.3696	.2644
10	.3246	.3978	.2789
11	.314	.397	.2675
12	.317	.3384	.2423
13	.3338	.3772	.2644
14	.3445	.3864	.2713
15	.3414	.3887	.2469
16	.3429	.3094	.2423
17	.3666	.2309	.2545
18	.3772	.2324	.2995
19	.3986	.2599	.3445
20	.4138	.2675	.3605
21	.407	.2698	.3628
22	.4047	.2843	.3582
23	.3932	.2835	.3559
24	.3887	.2843	.3666
Max	.4138	.3978	.3666
Min	.2629	.2309	.2423
Avg	.3559	.3381	.2891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 203 / 11 KV BELATHI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17
HR	Load (MW)
2	.1661
3	.1661
4	.1631
5	.1646
6	.1623
7	.1638
8	.1715
9	.192
10	.0907
Max	.192
Min	.0907
Avg	.1600

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-  
StationFeeder No / Name : 409 / Station T/F Feeder  
Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048
2	.3048	.3048	.3048
3	.3048	.3048	.3048
4	.3048	.3048	.3048
5	.3048	.3048	.3048
6	.3048	.3048	.3048
7	.2286	.3048	.2286
8	.1524	.1524	.2286
9	.1524	.2286	.2286
10	.1524	.2286	.2286
11	.1524	.2286	.2286
12	.1524	.2286	.2286
13	.1524	.2286	.2286
14	.1524	.2286	.2286
15	.1524	.2286	.2286
16	.1524	.2286	.2286
17	.1524	.2286	.2286
18	.2286	.2286	.2286
19	.3048	.3048	.3048
20	.3048	.3048	.3048
21	.3048	.3048	.3048
22	.3048	.3048	.3048
23	.3048	.3048	.3048
24	.3048	.3048	.3048
Max	.3048	.3048	.3048
Min	.1524	.1524	.2286
Avg	.2350	.2667	.2667



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 201 / 11 KV Lakhani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5792	.5792	.6706
2	.5792	.5792	.6401
3	.5487	.5792	.6401
4	.5487	.5792	.6401
5	.5487	.5487	.6401
6	.5487	.5487	.6401
7	.4877	.4572	.5792
8	.5182	.3963	.5487
9	.5182	.4572	.5792
10	.5487	.5487	.5487
11	.5487	.5792	.6097
12	.5487	.5792	.6401
13	.5487	.6401	.6097
14	.5792	.6706	.6097
15	.5487	.6706	.6401
16	.5182	.6097	.6097
17	.4877	.5792	.6097
18	.5182	.6401	.6097
19	.5792	.7621	.7926
20	.7011	.7926	.7926
21	.7316	.7621	.823
22	.7316	.7316	.7926
23	.6706	.7316	.7621
24	.6401	.7011	.7011
Max	.7316	.7926	.823
Min	.4877	.3963	.5487
Avg	.5741	.6135	.6554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 202 / 11 KV Salebhata

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
2		1.4937	1.4937
3		1.4937	1.4937
4		1.4937	1.4632
5		1.4937	1.4632
6		1.4937	1.4632
7		1.5242	1.4937
8		1.5546	1.5546
9		1.4327	1.5242
11	1.7375		
12	1.768		
13	1.7985		
14	1.7985		
15	1.7985		
16	1.7375		
17	1.7071		
18	1.6461		
Max	1.7985	1.5546	1.5546
Min	1.6461	1.4327	1.4632
Avg	1.7490	1.4975	1.4937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 203 / 11 KV Pohara

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
1	.7621	.823
2	.7621	.823
3	.7621	.8535
4	.7621	.8535
5	.7316	.823
6	.7316	.8535
7	.7621	.884
8	1.5546	1.6766
9	1.6156	1.7071
10	1.6461	1.6766
11	1.5851	1.6461
12	1.0974	1.7071
13	1.0364	1.0364
14	1.0364	1.0669
15	1.0364	.7011
16	1.0974	1.1888
17	1.1584	1.1888
18	1.3717	1.1888
19	1.6766	1.1888
20	1.4327	1.1279
21	.823	.823
22	.823	.823
23	.823	.9145
24	.823	.884
Max	1.6766	1.7071
Min	.7316	.7011
Avg	1.0796	1.1025

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 201 / 11 KV Palandur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0959	1.1264	.9488
2	.9335	1.0738	.9023
3	.9198	1.0616	.8985
4	.9076	1.0486	.8954
5	.8947	1.0334	.8924
6	.8581	.9625	.836
7	.82	.6356	.5601
8	.8711	.5175	.4443
9	.8566	.5312	.4717
10	.6363	.7095	.5601
11	.6874	1.0029	.6714
12	.7164	1.105	.6554
13	.7644	1.1248	.6691
14	.7857	1.1111	.6706
15	.7453	1.0745	.6409
16	.6325	.5304	.6272
17	.5876	.5815	.6173
18	.5449	.6767	.6295
19	1.0387	.9945	1.0875
20	1.1332	1.028	1.134
21	1.198	1.0418	1.15
22	1.2102	1.0349	1.1485
23	1.1911	1.0136	1.102
24	1.1469	.9701	1.0517
Max	1.2102	1.1264	1.15
Min	.5449	.5175	.4443
Avg	.8823	.9162	.8027

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 202 / 11 KV Maregaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7613	1.5226	1.2026
2	.727	1.7894	1.3938
3	.7209	1.7726	1.3786
4	.708	1.7589	1.3672
5	.6615	1.7467	1.3588
6	.6455	1.7132	1.3428
7	.4214	1.6552	1.3298
8	.3993	1.7482	1.2856
9	.3948	1.8381	1.2315
10	1.403	.4412	.2774
11	1.7528	.4702	.3003
12	1.8625	.522	.3422
13	1.8983	.5517	.4062
14	1.925	.5716	.4077
15	1.9418	.3605	.3887
16	1.906	.2873	.3269
17	1.8618	.3368	.2972
18	1.8389	.5121	.407
19	.7453	.6927	.7621
20	.8406	.7171	.8223
21	.8718	.7263	.8086
22	.8688	.7004	.7613
23	.8436	.6851	.7217
24	.8261	.6683	.6988
Max	1.9418	1.8381	1.3938
Min	.3948	.2873	.2774
Avg	1.1178	.9912	.8175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 204 / 11 KV Murmadi Tupkar AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0303		
2	1.3321		
3	1.3359		
4	1.2483		
5	1.2468		
6	1.2689		
7	1.5066		
8	1.5531		
9	1.5211		
10		1.137	.0015
11		1.6476	.0099
12		1.8351	
13		1.8587	
14		1.6994	
15			.3361
16			1.5333
17		.0099	1.5676
18			1.5699
19			1.5181
20			1.5234
21			1.5249
22			1.5203
23			1.0425
Max	1.5531	1.8587	1.5699
Min	1.0303	.0099	.0015
Avg	1.3381	1.3646	1.1043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 205 / 11 KV MURMADI GAOTHON

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.1957	1.214	1.1187
2	1.1728	1.1927	1.1073
3	1.169	1.1919	1.1012
4	1.1561	1.1896	1.0966
5	1.1355	1.1843	1.0898
6	1.0966	1.153	1.0623
7	.8208	.8764	.8421
8	.7735	.8017	.7773
9	.7964	.8177	.7727
10	.8109	.8429	.8116
11	.8002	.9366	.8551
12	.868	.9808	.8269
13	.9343	1.0044	.8497
14	.961	.9724	.8581
15	.9153	.0602	.8215
16	.8612	.4062	.8192
17	.8017	.74	.7796
18	.8413	.8779	.9328
19	1.2155	1.2742	1.3999
20	1.3375	1.3009	1.4441
21	1.3847	1.2879	1.4426
22	1.3695	1.2125	1.3664
23	1.291	1.166	1.2811
24	1.2391	1.1241	1.2239
Max	1.3847	1.3009	1.4441
Min	.7735	.0602	.7727
Avg	1.0395	.9920	1.0284

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 403 / 33 KV PALANDUR (Incomer)      NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.2862	1.829
2	4.1152	5.487	4.1152
3	4.1152	5.0297	4.1152
4	4.1152	5.0297	4.1152
5	4.1152	5.0297	4.1152
6	4.1152	5.0297	4.1152
7	3.658	4.5725	3.658
8	3.658	4.5725	3.2007
9	3.658	4.5725	3.2007
10	1.3717	1.3717	1.3717
11	4.5725	4.1152	1.829
12	5.0297	4.5725	1.829
13	5.0297	4.5725	1.829
14	5.0297	4.1152	1.829
15	5.0297	1.3717	1.829
16	5.0297	.4572	3.2007
17	4.5725	1.3717	3.2007
18	4.5725	1.3717	3.2007
19	2.2862	2.2862	3.658
20	2.2862	2.2862	4.1152
21	2.7435	2.2862	4.1152
22	2.7435	2.2862	4.1152
23	2.2862	2.2862	3.658
24	2.2862	1.829	2.2862
Max	5.0297	5.487	4.1152
Min	1.3717	.4572	1.3717
Avg	3.6961	3.2579	3.1055



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 201 / 11 KV SINDHIPAR AGP FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.5563		
3	.5563		
4	.5563		
5	.5639		
6	.5563		
7	.5792		
8	.602		
9	.602		
10	.1296		
11		.6325	.7164
12		.724	.6935
13		.7164	.663
14		.724	.7164
15		.7316	.7164
16		.7164	.7087
17		.724	.7011
18		.7011	.6554
19		.1753	.1448
Max	.602	.7316	.7164
Min	.1296	.1753	.1448
Avg	.5224	.6495	.6351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 202 / 11 KV RENGEPAR FEEDER AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1		2.2588	1.9524
2		2.2428	2.0073
3		2.1087	1.9479
4		2.0911	1.9364
5		2.0851	1.9448
6		2.1491	1.9585
7		2.2177	2.0942
8		2.3373	2.2718
9		2.1795	2.3015
10	2.4684		
11	2.5819		
12	2.5484		
13	2.537		
14	2.5804		
15	2.604		
16	2.54		
17	2.476		
18	2.4821		
Max	2.604	2.3373	2.3015
Min	2.4684	2.0851	1.9364
Avg	2.5354	2.1856	2.0461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 203 / 11 kv lakhori AG feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2896		
2	1.5623		
3	1.5318		
4	1.5242		
5	1.4937		
6	1.4708		
7	1.5013		
8	1.5775		
9	1.4251		
10		.2743	.1677
11		1.7147	1.5851
12		1.7452	1.6613
13		1.7147	1.7452
14		1.829	1.7909
15		1.7071	1.9128
16		1.326	1.9585
17		1.3717	1.89
18		1.6842	1.9052
Max	1.5775	1.829	1.9585
Min	.2896	.2743	.1677
Avg	1.3751	1.4852	1.6241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 204 / 11 KV LAKHORI GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1212	.1242	.1105
2	.1128	.1174	.1059
3	.1097	.1151	.1021
4	.109	.1166	.0998
5	.1082	.1166	.1006
6	.112	.1135	.1036
7	.1059	.1067	.0953
8	.0709	.0633	.0221
9	.0701	.0549	
10	.0846	.0267	
11	.0869	.0633	.048
12	.0854	.0846	.0023
13	.0846	.0838	.0076
14	.0899	.0823	.0724
15	.0861	.0145	
16	.0777		
17	.0541		
18	.003		.0008
19	.1075	.1235	.1082
20	.1364	.1456	.144
21	.144	.141	.1433
22	.1494	.1311	.1349
23	.1417	.1204	.1242
24	.1288	.1135	.1135
Max	.1494	.1456	.144
Min	.003	.0145	.0008
Avg	.0992	.0980	.0863

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 205 / 11 KV RENGEPAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4039	.4603	.3879
2	.3826	.3788	.3696
3	.3818	.3635	.3673
4	.3719	.3574	.3681
5	.3696	.3628	.3643
6	.3559	.3597	.3597
7	.2751	.3064	.3132
8	.2766	.301	.3185
9	.2683	.3071	.2865
10	.3155	.317	.3307
11	.3429	.3376	.3368
12	.3467	.3719	.2728
13	.3635	.3711	.2705
14	.362	.3765	.2782
15	.3536	.3574	.3498
16	.3445	.3506	.3544
17	.3361	.346	.3353
18	.3696	.3986	.394
19	.4641	.4755	.5235
20	.4976	.49	.5266
21	.5167	.4954	.5121
22	.5075	.4153	.5091
23	.4816	.4054	.4961
24	.4672	.3978	.4763
Max	.5167	.4954	.5266
Min	.2683	.301	.2705
Avg	.3815	.3793	.3792

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 204 / 11 KV NILAGONDI GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3521	.333	.3033
2	.3353	.3178	.2873
3	.3338	.3155	.2904
4	.3338	.3003	.2896
5	.3498	.3117	.2964
6	.3589	.3125	.2873
7	.2728	.2561	.2446
8	.2332	.2172	.2271
9	.2355	.2393	.2103
10	.2355	.2317	.221
11	.234	.2172	.1867
12	.2439	.2256	.2111
13	.2576	.2599	.2332
14	.2591	.2583	.2248
15	.2515	.2256	.2111
16	.2202	.2141	.1974
17	.1814	.2362	.1936
18	.202	.2561	.2065
19	.3391	.3285	.3513
20	.3582	.3422	.3612
21	.365	.349	.3696
22	.3551	.3437	.3635
23	.3399	.3239	.3422
24	.3368	.3079	.3323
Max	.365	.349	.3696
Min	.1814	.2141	.1867
Avg	.2910	.2801	.2684

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 205 / MANEGAON AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.5357	
2		.913	.1456
3		.8916	.9633
4		.8939	.9465
5		.8779	.9236
6		.8772	.916
7		.8916	.9549
8		.9015	.9678
9		.9069	.9587
10	.6173		
11	1.0044		
12	.9945		
13	.9945		
14	1.0044		
15	1.0082		
16	1.0037		
17	1.0006		
18	1.0021		
Max	1.0082	.913	.9678
Min	.6173	.5357	.1456
Avg	.9589	.8544	.8471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 201 / 11 KV Adarsh Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9484	.937	.8417
2	.9118	.8985	.8162
3	.8756	.868	.7857
4	.8387	.8425	.7773
5	.833	.8383	.7491
6	.8185	.8166	.7392
7	.7891	.8051	.7396
8	.6241	.7404	.7011
9	.4793	.6863	.6123
10	1.0094	.7015	.6516
11	.8124	.7259	.7453
12	.7526	.7929	.767
13	.7434	.8211	.7598
14	.7552	.8291	.7724
15	.7609	.8413	.7606
16	.7739	.8299	.7743
17	.7522	.7343	.7632
18	.7133	.6943	.7453
19	.7415	.7994	.8093
20	.7331	.8451	.8897
21	.8234	.8657	.8939
22	.9648	.8779	.9187
23	.9858	.9061	.9141
24	.9644	.8695	.8962
Max	1.0094	.937	.9187
Min	.4793	.6863	.6123
Avg	.8085	.8153	.7843



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 202 / 11 KV Alesur Gaothan  
Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.202	.1962	.1928
2	.1997	.1909	.1905
3	.1974	.1882	.1875
4	.197	.1875	.1875
5	.1959	.1867	.1814
6	.1943	.1837	.1856
7	.1844	.1776	.184
8	.1623	.1581	.1574
9	.1638	.1558	.1578
10	.1696	.1589	.1654
11	.1638	.1513	.1574
12	.1593	.1589	.1566
13	.1638	.1581	.1623
14	.1688	.1562	.1699
15	.1658	.1562	.1692
16	.168	.1421	.1608
17	.1619	.1387	.1566
18	.1475	.1566	.1276
19	.1543	.1829	.1821
20	.1741	.2138	.21
21	.21	.2168	.2115
22	.2202	.216	.2016
23	.2168	.208	.1978
24	.2031	.1993	.1859
Max	.2202	.2168	.2115
Min	.1475	.1387	.1276
Avg	.1810	.1766	.1766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 203 / 11 KV Sanjay Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.1336	1.1153	1.0326
2	1.0947	1.0795	1.0101
3	1.0639	1.0448	.9766
4	1.0368	1.0216	.9556
5	1.0292	.9949	.9507
6	1.0033	.9983	.9568
7	.9663	.9564	.9343
8	.8836	.9069	.8714
9	.8829	.8802	.8421
10	1.0574	.8947	.8653
11	.9949	.9408	.8749
12	.9816	.9747	.9545
13	.9987	1.0848	1.0033
14	1.0147	1.0833	1.025
15	1.0265	1.0818	1.041
16	1.0151	1.0056	1.0277
17	.9739	.8996	.9995
18	.9236	.9217	.94
19	.8878	1.0216	1.07
20	.8749	1.0974	1.2014
21	.993	1.0959	1.19
22	1.1351	1.0856	1.166
23	1.2068	1.1092	1.1656
24	1.1919	1.0841	1.1271
Max	1.2068	1.1153	1.2014
Min	.8749	.8802	.8421
Avg	1.0154	1.0158	1.0076

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064038 / 33/11 KV POHORA S/S

Feeder No / Name : 201 / 11 KV Shivni AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
2	1.5981		
3	1.6377		
4	1.6324		
5	1.5364		
6	1.5226		
7	1.6133		
8	1.7444		
9	1.7779		
10	1.0326		
11		1.9006	1.7604
12		1.9997	1.7886
13		2.0492	1.8267
14		1.861	1.89
15		1.861	1.8968
16		1.8229	1.9014
17		1.7863	1.9555
18		1.7772	1.8869
19		.9701	1.057
Max	1.7779	2.0492	1.9555
Min	1.0326	.9701	1.057
Avg	1.5662	1.7809	1.7737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 201 / 11 KV SASRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
2	2.1948	2.6216	2.4082
3		2.5911	2.4082
4	2.1338	2.5911	2.4082
5	2.1338	2.5911	2.4082
6	2.0729	2.4996	2.3777
7	2.3167	2.4996	2.3777
8	2.3472	2.7435	2.4387
9	2.2862	2.8045	2.4387
Max	2.3472	2.8045	2.4387
Min	2.0729	2.4996	2.3777
Avg	2.2122	2.6178	2.4082

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 202 / 11KV SANGADI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.326	1.4053	1.4312	1.4312
2	1.326	1.3992	1.4137	1.4137
3	1.2948	1.3938	1.406	1.406
4	1.2803	1.3687	1.3961	1.3961
5	1.2666	1.3367	1.3748	1.3748
6	1.0014	1.1027	1.1629	1.1629
7	.7506	1.044	.8672	.8169
8	.6462	.868	.868	.743
9	.7316	.9038	.9038	.804
10	.7606	1.2209	1.2209	1.3862
11	.8299	1.2269	1.2269	1.5013
12	.3864	1.2879	1.2879	1.5729
13	.9343	1.342	1.342	1.5844
14	1.2193	1.2925	1.2925	.9351
15	1.2475	1.2772	1.2772	.9648
16	1.2338	1.2369	1.2369	1.0235
17	1.1805	1.1911	1.1911	1.137
18	1.5013	1.1942	1.1942	1.2795
19	1.6575	1.4624	1.4624	1.3961
20	1.7756	1.5737	1.5737	1.4159
21	1.7977	1.6651	1.6651	1.4236
22	1.7071	1.7139	1.7139	1.4076
23	1.5303	1.5981	1.5981	1.3717
24	1.5005	1.56	1.56	1.3474
Max	1.7977	1.7139	1.7139	1.5844
Min	.3864	.868	.8672	.743
Avg	1.2036	1.3194	1.3194	1.2623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 201 / 11 KV KINHI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-SEP-17
HR	Load (MW)
1	.1677
2	1.1965
3	1.1431
4	1.1355
5	1.1355
6	1.1279
7	1.2041
8	1.3336
9	1.3413
Max	1.3413
Min	.1677
Avg	1.0872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 205 / 11 KV SATALWADA GT.

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	02-OCT-17
HR	Load (MW)
1	.6859
2	.6859
3	.6859
4	.6859
5	.6859
6	.6859
7	.6859
8	.6097
9	.6097
10	.6097
11	.6097
12	.6097
13	.6097
14	.5335
15	.5335
16	.6859
17	.6859
18	.7621
19	.9145
20	.9907
21	.9907
22	.9145
23	.8383
24	.8383
Max	.9907
Min	.5335
Avg	.7145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 201 / 11 KV GONDUMRI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.5554	1.3877
2		1.5005	1.5059
3		1.4914	1.5059
4		1.4906	1.5074
5		1.4838	1.5028
6		1.4845	1.5516
7		1.5646	1.6872
8		1.5927	1.7292
9		1.5874	1.7695
10	1.3443		
11	1.7894		
12	1.7993		
13	1.8038		
14	1.8503		
15	1.8214		
16	1.7787		
17	1.848		
18	1.8465		
Max	1.8503	1.5927	1.7695
Min	1.3443	1.4838	1.3877
Avg	1.7646	1.5279	1.5719



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 202 / 11 KV WADAD AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)
2	.961	.913
3	.9541	.916
4	.9496	.9107
5	.9496	.9107
6	.9435	.913
7	.9678	.948
8	1.0288	1.0311
9	1.0722	1.0829
10	.3917	.3879
Max	1.0722	1.0829
Min	.3917	.3879
Avg	.9131	.8904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391] BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 201 / 11 KV S'Wafa AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)
9	1.1584		
10	1.4022		
11	1.5546	2.7435	1.4937
12	2.1338	2.7435	1.5546
13	2.2253	2.7435	1.5851
14	2.2558	2.5911	1.9204
15	2.3167	2.4691	2.0119
16	2.3472	2.4082	1.9814
17		2.3167	2.0119
18		2.0729	2.0729
<b>Max</b>	<b>2.3472</b>	<b>2.7435</b>	<b>2.0729</b>
<b>Min</b>	<b>1.1584</b>	<b>2.0729</b>	<b>1.4937</b>
<b>Avg</b>	<b>1.9243</b>	<b>2.5111</b>	<b>1.8290</b>

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 203 / 11KV SAKOLI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.3413	1.4327	1.2498
2	1.2498	1.2803	1.3413	1.2193
3	1.2193	1.2803	1.3108	1.1584
4	1.2193	1.2498	1.2803	1.1584
5	1.2193	1.2498	1.2498	1.1279
6	1.2498	1.2498	1.2498	1.1279
7	1.2193	1.1888	1.2193	1.0974
8	1.1279	1.1584	1.1279	1.0669
9	1.1584	1.1888	1.1584	1.0669
10	1.2193	1.2193	1.2193	1.0974
11	1.4022	1.3108	1.2498	1.1888
12	1.4937	1.3108	1.1888	1.2193
13	1.5242	1.3108	1.2193	1.2803
14	1.5242	1.3108	1.1279	1.3413
15	1.4022	1.3108	1.1584	1.3413
16	1.3717	1.2803	1.0974	1.3413
17	1.3717	1.2193	1.0974	1.2803
18	1.4022	1.2498	1.2193	1.3108
19	1.4937	1.3717	1.4022	1.5546
20	1.4937	1.4937	1.4022	1.5546
21	1.4632	1.5242	1.4022	1.5242
22	1.4937	1.5546	1.3717	1.5242
23	1.4632	1.5242	1.3717	1.4937
24	1.4022	1.4937	1.3108	1.4022
Max	1.5242	1.5546	1.4327	1.5546
Min	1.1279	1.1584	1.0974	1.0669
Avg	1.3527	1.3197	1.2587	1.2803

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 204 / 11 KV LAKHANDUR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.0914	.1524	.1829
2	.1829	.0914	.1524	.1829
3	.1829	.0914	.1524	.1829
4	.1829	.0914	.1524	.1829
5	.1829	.0914	.1524	.1829
6	.1829	.0914	.1524	.1829
7	.1829	.061	.1524	.1829
8	.1524	.0914	.1524	.1524
9	.1829	.0914	.1829	.1524
10	.1829	.0914	.1524	.1829
11	.1524	.1219	.2134	.1524
12	.1524	.1219	.2134	.1829
13	.1524	.1219	.2134	.1829
14	.1829	.1219	.2134	.1829
15	.1829	.1219	.2134	.2134
16	.1524	.1524	.2134	.1829
17	.1524	.1219	.1829	.1829
18	.1219	.1524	.1829	.1829
19	.1219	.1829	.1829	.1829
20	.0914	.1829	.2134	.1829
21	.0914	.1829	.2134	.1829
22	.0914	.1829	.2134	.1829
23	.0914	.1524	.2134	.1829
24	.0914	.1524	.1829	.1829
Max	.1829	.1829	.2134	.2134
Min	.0914	.061	.1524	.1524
Avg	.1511	.1232	.1842	.1804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-SEP-17 and 05-OCT-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&amp;M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 205 / 11 KV EKODI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-SEP-17	30-SEP-17	01-OCT-17	02-OCT-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4022	1.7375	1.7375	1.7071
2	1.3717	1.7071	1.7375	1.7071
3	1.3717	1.7071	1.7375	1.6766
4	1.3717	1.6766	1.7071	1.5242
5	1.3717	1.6766	1.7071	1.5242
6	1.4022	1.6766	1.7071	1.5242
7	1.4327	1.6461	1.6461	1.5546
8	1.4632	1.6156	1.6766	1.6156
9	1.5546	1.6766	1.6766	1.6766
10	1.5851	1.6766	1.7375	1.7071
11	1.5546	1.7071	1.7985	1.768
12	1.5851	1.6766	1.4327	1.7375
13	1.5851	1.768	1.6461	1.829
14	1.6766	1.829	1.5546	1.8595
15	1.768	1.8595	1.5851	1.8595
16	1.7071	1.8595	1.6156	1.829
17	1.7071	1.7985	1.6766	1.7071
18	1.7071	1.768	1.768	1.7375
19	1.829	1.829	1.89	1.89
20	1.8595	1.829	1.8595	1.89
21	1.8595	1.8595	1.8595	1.7985
22	1.8595	1.8595	1.7985	1.7375
23	1.768	1.7985	1.768	1.6766
24	1.7375	1.768	1.7375	1.6461
Max	1.8595	1.8595	1.89	1.89
Min	1.3717	1.6156	1.4327	1.5242
Avg	1.6054	1.7503	1.7109	1.7160