

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 206 / 11 KV CHORAKHALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.2286
2	.2286
3	.2286
4	.2286
5	.3048
6	.5335
7	.8383
8	.8383
9	.6859
10	.5335
11	.381
12	.2286
13	.2286
14	.2286
15	.3048
16	.3048
17	.3048
18	.3048
19	.5335
20	.5335
21	.4572
22	.4572
23	.3048
24	.2286
Max	.8383
Min	.2286
Avg	.3937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 201 / 11 KV PADOLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	1.2719
2	1.2963
3	1.3283
4	1.3885
5	1.4319
21	.1402
22	1.2818
23	1.2483
24	1.1881
Max	1.4319
Min	.1402
Avg	1.1750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 203 / 11 KV NAIGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.7057
2	.8048
3	.9953
4	1.3512
5	1.608
6	.1052
9	.9938
10	.4862
11	1.3748
12	1.6446
13	1.6629
14	1.7238
15	1.752
16	1.7718
17	1.7436
18	1.0105
19	1.323
20	1.3131
21	1.2071
22	.9938
23	.775
24	.6645
Max	1.7718
Min	.1052
Avg	1.1823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 204 / 11 KV WATWADA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.2515
2	.2568
3	.3155
4	.4222
5	.6516
6	.7705
9	.7705
10	.7285
11	.4999
12	.5396
13	.5304
14	.5312
15	.5411
16	.5898
17	.6158
18	.6264
19	.6737
20	.6432
21	.5502
22	.3948
23	.3246
24	.2583
Max	.7705
Min	.2515
Avg	.5221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194090 / 33/11 KV SUBSTATION DHORALA

Feeder No / Name : 201 / 11 KV DHORALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
10	.0975
11	.7727
12	.8657
13	.8764
14	.8932
15	.8924
16	.9015
17	.9313
18	.9404
Max	.9404
Min	.0975
Avg	.7968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194090 / 33/11 KV SUBSTATION DHORALA

Feeder No / Name : 202 / 11 KV DEOLALI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.3582
2	.3467
3	.3376
4	.3277
5	.3201
6	.2644
22	.2225
23	.3361
24	.3239
Max	.3582
Min	.2225
Avg	.3152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194090 / 33/11 KV SUBSTATION DHORALA

Feeder No / Name : 203 / 11 KV DHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.1417
2	.1372
3	.1585
4	.1859
5	.2904
6	.3879
7	.4283
8	.4001
9	.3536
10	.3018
11	.2507
12	.1806
13	.1463
14	.1448
15	.1448
16	.144
17	.1638
18	.1997
19	.2644
20	.2599
21	.2492
22	.2187
23	.1776
24	.1555
Max	.4283
Min	.1372
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194093 / 33/11 KV SUBSTATION DIKSAL

Feeder No / Name : 201 / 11 Kv DIKSAL FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.9884
2	.9427
3	.8703
4	.8741
5	.9198
6	.8947
Max	.9884
Min	.8703
Avg	.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194093 / 33/11 KV SUBSTATION DIKSAL

Feeder No / Name : 203 / 11 KV KHADKI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.1059
2	.109
3	.1097
4	.1135
5	.1318
6	.2141
7	.2286
8	.2141
9	.1753
10	.141
11	.3871
12	.4633
13	.5319
14	.5647
15	.5548
16	.5838
17	.5761
18	.5708
19	.1463
20	.1402
21	.1326
22	.1212
23	.1135
24	.1067
Max	.5838
Min	.1059
Avg	.2723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194052 / 33 KV S/SN ,RUIBHAR

Feeder No / Name : 203 / 11 KV Ruibhar Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	19-OCT-17
HR	Load (MW)
1	.1859
2	.1837
3	.1875
4	.2042
5	.3056
6	.4207
7	.4268
8	.3605
9	.282
10	.192
11	.1562
12	.157
13	.125
14	.1326
15	.1357
16	.0907
17	.1677
18	.2157
19	.3064
20	.2888
21	.2446
22	.2332
23	.1936
24	.1844
Max	.4268
Min	.0907
Avg	.2242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194088 / 33/11 KV CHILWADI SUB-STATION

Feeder No / Name : 202 / 11KV WALGUD AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	19-OCT-17
HR	Load (MW)
11	.234
12	.2591
13	.2553
14	.2591
15	.2675
16	.2561
17	.2202
18	.2492
Max	.2675
Min	.2202
Avg	.2501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 202 / 11 KV NEHARU CHOWK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.6859
2	.6097
3	.6097
4	.6097
5	.6097
Max	.6859
Min	.6097
Avg	.6249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 204 / 11KV TER FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.535
2	.5182
3	.5136
4	.5304
5	.679
6	.9816
7	1.3009
8	1.3618
9	1.2536
10	1.0677
11	.9122
12	.7514
13	.6501
14	.5906
15	.6226
16	.615
17	.6653
18	.7362
19	1.0159
20	1.0098
21	.961
22	.8284
23	.7659
24	.6051
Max	1.3618
Min	.5136
Avg	.8113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 205 / 11KV UPLA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.7964
2	.7613
3	.7369
4	.7141
5	.7156
6	.8101
7	1.0166
8	1.1157
9	1.118
10	1.0639
11	.9503
12	.8345
13	.7895
14	.7606
15	.8139
16	.7971
17	.7529
18	.8101
19	1.0837
20	1.102
21	1.0829
22	1.0883
23	1.0395
24	.9198
Max	1.118
Min	.7141
Avg	.9031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 206 / 11 KV VIP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.3414
2	.3338
3	.3262
4	.3353
5	.3788
6	.4854
7	.586
8	.5769
9	.5014
10	.4862
11	.4062
12	.407
13	.3559
14	.3704
15	.3765
16	.4108
17	.4382
18	.5075
19	.5441
20	.4527
21	.4496
22	.4344
23	.4138
24	.3658
Max	.586
Min	.3262
Avg	.4285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 211 / New CollecTtor Office
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	19-OCT-17
HR	Load (MW)
10	.0046
19	.0076
20	.0198
21	.0815
22	.0122
23	.0023
24	.0023
Max	.0815
Min	.0023
Avg	.0186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 201 / 11 KV MIDC _I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	19-OCT-17
HR	Load (MW)
1	.0351
2	.0168
8	.0556
9	.0168
10	.0175
11	.0107
12	.0206
13	.0297
14	.0511
15	.0213
18	.0015
19	.0366
20	.0008
Max	.0556
Min	.0008
Avg	.0242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 202 / 11 KV DNYANESHWAR TEMPLE SHEDDABLE URBAN
TOWN Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	1.0319
2	.9717
3	.9381
4	.9084
5	.9145
6	1.0059
7	1.1767
8	1.3413
9	1.3908
10	1.4114
11	1.2109
12	1.1629
13	1.1866
14	1.15
15	1.0669
16	1.0883
17	1.1317
18	1.1355
19	1.4784
20	1.467
21	1.4708
22	1.4403
23	1.3184
24	1.1751
Max	1.4784
Min	.9084
Avg	1.1906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 204 / 11KV MIDC -II FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	19-OCT-17
HR	Load (MW)
1	.1997
2	.2103
3	.2012
4	.189
5	.1859
6	.1837
7	.1943
8	.2096
9	.2332
10	.2492
11	.2263
12	.1997
13	.2065
14	.1608
15	.1829
16	.1669
17	.1936
18	.1943
19	.2263
20	.2141
21	.2279
22	.2256
23	.2103
24	.1943
Max	.2492
Min	.1608
Avg	.2036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 206 / 11 KV CKT HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.0431
2	.0415
3	.0412
4	.0404
5	.0427
6	.0476
7	.0545
8	.0613
9	.0644
10	.0659
11	.061
12	.0682
13	.0648
14	.0671
15	.0846
16	.024
17	.0191
18	.0194
19	.0564
20	.0556
21	.0575
22	.0572
23	.0564
24	.0537
Max	.0846
Min	.0191
Avg	.0520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 207 / 11KV EXPRESS UPALA WW NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	19-OCT-17
HR	Load (MW)
1	.1017
2	.1017
3	.101
4	.1002
5	.0995
6	.0975
7	.096
8	.0953
9	.096
10	.0975
11	.0975
12	.0934
13	.093
14	.0926
15	.0914
16	.0911
17	.0907
18	.0926
19	.0983
20	.101
21	.1014
22	.1025
23	.1006
24	.101
Max	.1025
Min	.0907
Avg	.0972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194060 / 33KV TAMBARI SUB_STATION

O'BAD

Feeder No / Name : 201 / 11 KV TAMBARI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.9739
2	.8993
3	.8566
4	.8482
5	.8543
6	.9739
7	1.2544
8	1.438
9	1.3702
10	1.2711
11	1.1279
12	1.0044
13	1.0402
14	.9579
15	.9404
16	.9244
17	1.0059
18	1.0578
19	1.4091
20	1.4883
21	1.3855
22	1.3992
23	1.342
24	1.2064
Max	1.4883
Min	.8482
Avg	1.1262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194060 / 33KV TAMBARI SUB_STATION

O'BAD

Feeder No / Name : 202 / 11 KV VAIRAG NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
8	.0118
9	.0236
10	.0057
Max	.0236
Min	.0057
Avg	.0137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194060 / 33KV TAMBARI SUB_STATION

O'BAD

Feeder No / Name : 203 / 11KV EXPRESS FEEDER CIVIL NON SHEDDABLE EXPRESS HV FEEDERS
HOS Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	19-OCT-17
HR	Load (MW)
5	.2587
6	.2625
7	.2637
8	.261
9	.2572
10	.2564
11	.2614
12	.2633
13	.2629
14	.2648
15	.2644
16	.266
17	.2667
18	.2656
19	.2705
20	.2656
Max	.2705
Min	.2564
Avg	.2632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /

STATION

Feeder No / Name : 401 / 33 KV OSMANABAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	19-OCT-17
HR	Load (MW)
1	3.9552
2	3.7952
3	3.658
4	3.5894
5	3.7952
6	4.5496
7	5.5784
8	5.8528
9	5.807
10	5.4184
11	5.0983
12	4.5953
13	4.3896
14	4.2524
15	4.2524
16	4.2524
17	4.4124
18	4.7782
19	6.3329
20	6.2872
21	5.8528
22	5.6013
23	5.0755
24	4.4582
Max	6.3329
Min	3.5894
Avg	4.8183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /

STATION

Feeder No / Name : 405 / 33 KV POHNER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	19-OCT-17
HR	Load (MW)
1	3.155
2	2.9321
3	2.7949
4	2.7606
5	2.7778
6	3.8409
7	4.7497
8	5.3669
9	5.0583
10	4.8868
11	4.4239
12	3.9952
13	4.1495
14	3.9266
15	3.8409
16	3.8066
17	4.0295
18	4.201
19	5.2641
20	5.4527
21	4.9211
22	4.4925
23	4.2867
24	3.8237
Max	5.4527
Min	2.7606
Avg	4.1224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194044 / 33/11 KV SUB-STATION

WARADWADI

Feeder No / Name : 202 / ASSU

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.2926
2	.2964
3	.2881
4	.2972
5	.3185
6	.3628
7	.1623
8	.1578
9	.1265
10	.125
11	.1196
12	.1021
13	.0937
14	.0899
15	.0412
16	.061
17	.0823
18	.0968
19	.1334
20	.1387
21	.141
22	.3147
23	.3155
24	.2934
Max	.3628
Min	.0412
Avg	.1854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194044 / 33/11 KV SUB-STATION

WARADWADI

Feeder No / Name : 203 / WAKADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.2637
2	.2675
3	.2797
4	.3163
5	.3955
6	.3734
7	.3605
8	.2629
9	.2416
10	.1913
11	.16
12	.1166
13	.1593
14	.1532
15	.1456
16	.1585
17	.173
18	.2225
19	.3246
20	.3384
21	.3391
22	.3353
23	.2888
24	.2721
Max	.3955
Min	.1166
Avg	.2558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194011 / 33/11 KV SUB-STATION

KAMEGAON

Feeder No / Name : 203 / 11 KV KAMEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.8619
2	.8551
3	.8474
4	.8833
5	1.1119
6	1.2811
7	.9915
8	.9374
9	.8733
10	.7499
11	.4077
12	.849
13	.948
14	.9412
15	.5998
16	.9534
17	.9297
18	1.1614
19	.7042
20	.7369
21	.6333
22	.5723
23	.8467
24	.9061
Max	1.2811
Min	.4077
Avg	.8576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 KV SUB-STATION TER

Feeder No / Name : 203 / 11 KV WAGHOLI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.1593
2	.1555
3	.1486
4	.1539
5	.192
6	.2591
7	.333
8	.3231
9	.2545
10	.2012
11	.6615
12	.7423
13	.7956
14	.8109
15	.599
16	.6638
17	.7064
18	.6615
19	.2286
20	.2553
21	.2286
22	.2012
23	.189
24	.157
Max	.8109
Min	.1486
Avg	.3784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 KV SUB-STATION TER

Feeder No / Name : 204 / 11 KV PANWADI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.4626
2	.4679
3	.471
4	.4984
5	.586
6	.2919
7	.2797
8	.2035
9	.1821
10	.0968
11	.0686
12	.0328
13	.0541
14	.0053
15	.0716
16	.0328
17	.0815
18	.1463
19	.2111
20	.192
21	.176
22	.5388
23	.5182
24	.4809
Max	.586
Min	.0053
Avg	.2562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 KV SUB-STATION TER

Feeder No / Name : 207 / 11 KV TER WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

FEEDER Feeder KV- 11 /

UTILITY

OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.0762
2	.0762
3	.0762
4	.0762
5	.0762
6	.0762
7	.0762
8	.0762
9	.0762
10	.0762
11	.0762
12	.0762
13	.0762
14	.0762
15	.0762
16	.0762
17	.0762
18	.0762
19	.0762
20	.0762
21	.0762
22	.0762
23	.0762
24	.0762
Max	.0762
Min	.0762
Avg	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33/11 KV SUB-STATION PADOLI

(A

Feeder No / Name : 205 / 11 KV VISHWARUPA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	19-OCT-17
HR	Load (MW)
6	.0053
7	.0831
8	.061
9	.0023
11	.0046
12	.0381
13	.0732
14	.0305
15	.0686
Max	.0831
Min	.0023
Avg	.0407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194094 / 33/11 KV SUB-STATION

TADAWALA

Feeder No / Name : 201 / 11 KV GOPALWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.3749
2	.3696
3	.3567
4	.3544
5	.3376
6	.3307
7	.1692
8	.141
9	.1181
10	.0572
14	.003
16	.0008
19	.08
20	.0876
21	.0564
22	.4466
23	.4733
24	.4649
Max	.4733
Min	.0008
Avg	.2346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194094 / 33/11 KV SUB-STATION

TADAWALA

Feeder No / Name : 202 / 11 KV TADAWALA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.7255
2	.7042
3	.6935
4	.7438
5	.8627
6	1.1492
7	1.1919
8	1.1279
9	.916
10	.66
11	.5944
12	.7331
13	.7788
14	.727
15	.7011
16	.6904
17	.6813
18	.7194
19	1.073
20	1.0639
21	1.0364
22	.9496
23	.82
24	.7225
Max	1.1919
Min	.5944
Avg	.8361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194013 / 33/11 KV SUBSTATION WASHI

Feeder No / Name : 206 / 11 KV S S K EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	19-OCT-17
HR	Load (MW)
1	.0781
2	.0758
3	.0774
4	.0758
5	.0743
6	.0819
7	.0861
8	.0598
9	.1055
10	.1101
11	.0937
12	.0979
13	.0831
14	.0537
15	.0648
16	.0594
17	.0381
18	.0434
19	.0549
20	.0667
21	.0705
22	.053
23	.0069
24	.0122
Max	.1101
Min	.0069
Avg	.0676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194040 / 33/11KV SUB-STATION PARA

Feeder No / Name : 203 / 11 KV PARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.2713
2	.2675
3	.2896
4	.3422
5	.4946
6	.6851
7	.7415
8	.7438
9	.6188
10	.5563
11	.4763
16	.3277
17	.4893
18	.4771
19	.5228
20	.5403
21	.5388
22	.4641
23	.3681
24	.3064
Max	.7438
Min	.2675
Avg	.4761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194087 / 33/11 kv LINGI PIMPALGAON

S/S

Feeder No / Name : 201 / L.PIMPALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.3902
2	.3986
3	.4428
4	.5754
5	.8459
6	1.1157
7	1.1477
8	1.0181
9	.9435
10	.8368
11	.6562
12	.5114
13	.3986
14	.4466
15	.4374
16	.4496
17	.5106
18	.6493
19	.8558
20	.8528
21	.7057
22	.5937
23	.5197
24	.4512
Max	1.1477
Min	.3902
Avg	.6564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 203 / 11KV TUGAON SPP feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.2286
2	.2286
3	.3048
4	.3048
5	.3048
6	.381
7	.4572
8	.6097
9	.5335
10	.5335
11	.2286
12	.1524
13	.1524
14	.0762
15	.1524
16	.1524
17	.1524
18	.2286
19	.2286
20	.3048
21	.3048
22	.3048
23	.2286
24	.2286
Max	.6097
Min	.0762
Avg	.2826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194016 / LOHARA

Feeder No / Name : 204 / 11 KV UNDARGAON SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.0739
2	.0198
5	.0305
6	.0968
7	.1257
8	.1318
9	.1219
10	.0366
11	.3658
12	.4481
13	.4961
14	.4115
15	.4451
16	.4893
17	.5609
18	.2362
19	.1128
20	.1166
21	.1128
22	.0945
23	.0777
Max	.5609
Min	.0198
Avg	.2193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194016 / LOHARA

Feeder No / Name : 205 / 11 KV MOGHA FEEDER SPP SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.5898
2	.5624
3	.5495
4	.5578
5	.6401
6	.7499
7	.8063
8	.807
9	.8002
10	.6409
11	.6409
12	.6516
13	.6943
14	.628
15	.6447
16	.6333
17	.6036
18	.5517
19	.772
20	.7956
21	.7522
22	.7103
23	.6569
24	.6287
Max	.807
Min	.5495
Avg	.6695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194016 / LOHARA

Feeder No / Name : 206 / 11 KV KHED SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.5075
2	.3506
3	.3353
4	.346
5	.413
6	.4557
7	.4877
8	.5792
9	.5472
10	.4496
11	.3155
12	.189
13	.2606
14	.2865
15	.2408
16	.3262
17	.3201
18	.4329
19	.695
20	.7133
21	.7087
22	.5914
23	.5655
24	.5045
Max	.7133
Min	.189
Avg	.4426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 203 / 11 KV jewalii SPP feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.5014
2	.3528
3	.3437
4	.394
5	.4801
6	.6722
7	.7842
8	.8063
9	.8147
10	.7491
11	.7598
12	.5495
13	.0686
14	.474
15	.4893
16	.4717
17	.5045
18	.109
19	.9915
20	.9671
21	.8596
22	.7971
23	.6943
24	.5571
Max	.9915
Min	.0686
Avg	.5913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 204 / 11 kv ashta new feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.6584
2	.5967
3	.6089
4	.6729
5	.7171
6	.8215
7	.9503
8	.9869
9	.8261
10	.5213
11	.4786
12	.4062
13	.3955
14	.3132
15	.4001
16	.3704
17	.4016
18	.4992
19	.7651
20	.7697
21	.791
22	.7849
23	.7087
24	.6523
Max	.9869
Min	.3132
Avg	.6290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 205 / 11 kv rudrawadi new SINGLE PHASING
feeder Feeder KV- 11 /
OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.5281
2	.5197
3	.5464
4	.6135
5	.7202
6	.9244
7	.9816
8	.7697
9	.5304
10	.3582
11	.4214
12	.4588
13	.4885
14	.439
15	.4443
16	.455
17	.4306
18	.4816
19	.6638
20	.6859
21	.6904
22	.6798
23	.5784
24	.5258
Max	.9816
Min	.3582
Avg	.5806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 206 / 11 kv PANDHARI fedder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.2141
2	.2035
3	.205
4	.2012
5	.208
6	.2721
7	.2667
8	.237
9	.1829
10	.2012
11	.2065
12	.2202
13	.2812
14	.2705
15	.2858
16	.2964
17	.2774
18	.1608
19	.218
20	.2423
21	.2218
22	.2218
23	.2164
24	.2111
Max	.2964
Min	.1608
Avg	.2301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194092 / SASTUR

Feeder No / Name : 206 / 11 KV Sastur Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	19-OCT-17
HR	Load (MW)
1	.3688
2	.3319
3	.3418
4	.3875
5	.5194
6	.6043
7	.5887
8	.4534
9	.3749
10	.37
11	.3441
12	.3326
13	.3151
14	.2915
15	.0713
17	.1113
18	.3692
19	.5083
20	.4931
21	.5018
22	.4534
23	.4134
24	.3799
Max	.6043
Min	.0713
Avg	.3881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194092 / SASTUR

Feeder No / Name : 207 / 11 kv karajgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.9305
2	.9457
3	.932
4	.9869
5	1.0997
6	1.1424
7	1.2041
8	1.2841
9	1.1675
10	1.5394
11	1.4731
12	.2804
13	.1059
14	.8337
15	.8025
16	.8269
17	.9023
18	1.1043
19	1.6728
20	1.7452
21	1.752
22	1.6461
23	1.5546
24	1.528
Max	1.752
Min	.1059
Avg	1.1442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194005 / 33/11KV NALDURGA

Feeder No / Name : 201 / 11KV NALDURG URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.8695
2	.8551
3	.8863
4	1.0319
5	1.262
6	1.5722
7	1.6735
8	1.7261
9	1.7109
10	1.2285
11	1.1934
12	1.0334
13	1.0159
14	.9938
15	.9297
16	.9556
17	1.0433
18	1.2117
19	1.5531
20	1.4312
21	1.3184
22	1.1637
23	1.0501
24	.929
Max	1.7261
Min	.8551
Avg	1.1933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 203 / 11 KV KAKRAMBA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	19-OCT-17
HR	Load (MW)
2	.3719
3	.378
4	.3887
5	.3826
6	.3506
7	.5258
8	.6539
9	.7225
10	.1844
19	.1113
20	.0488
21	.0107
Max	.7225
Min	.0107
Avg	.3441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 206 / 11 KV SALAGARA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	19-OCT-17
HR	Load (MW)
10	.3262
11	.349
12	.3749
13	.4374
14	.4527
15	.4435
16	.3932
17	.3887
18	.3475
Max	.4527
Min	.3262
Avg	.3903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 210 / 11 KV TULJAPUR NP EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
WATE Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	19-OCT-17
HR	Load (MW)
1	.0762
2	.0762
3	.0762
4	.0762
5	.0762
6	.0762
7	.0381
8	.0762
9	.0762
10	.0762
11	.0762
12	.0381
13	.0381
14	.0381
15	.0381
16	.0762
17	.0762
18	.0381
19	.0762
20	.0762
21	.0762
22	.0762
23	.0762
24	.0762
Max	.0762
Min	.0381
Avg	.0667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 405 / 33KV YEOTI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	19-OCT-17
HR	Load (MW)
1	.6859
2	.6859
3	.9145
4	.9145
5	.9145
6	1.1431
7	1.3717
8	1.3717
9	1.1431
10	.6859
11	.6859
12	.6859
13	.6859
14	.6859
15	.2286
16	.9145
17	.9145
18	.6859
19	.9145
20	.9145
21	.9145
22	.6859
23	.6859
24	.6859
Max	1.3717
Min	.2286
Avg	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 203 / 11 KV ITKAL GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.4572
2	.4572
3	.4572
4	.4572
5	.6097
6	.7621
7	.8383
8	.7621
9	.6859
10	.6097
11	.5335
12	.4572
13	.4572
14	.4572
15	.4572
16	.4572
17	.5335
18	.5335
19	.6859
20	.7621
21	.6097
22	.5335
23	.4572
24	.381
Max	.8383
Min	.381
Avg	.5589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 204 / 11 KV VAISHNODEVI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	19-OCT-17
HR	Load (MW)
1	.3166
2	.2904
3	.2442
4	.2648
5	.2244
6	.2587
7	.3692
8	.3372
9	.3395
10	.3357
11	.2953
12	.3936
13	.3925
14	.3597
15	.3456
16	.2599
17	.2107
18	.2096
19	.2092
20	.1852
21	.1962
22	.3155
23	.3761
24	.3929
Max	.3936
Min	.1852
Avg	.2968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 203 / 11 KV TAMALWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
1	.2637
2	.2553
3	.2595
4	.2858
5	.4245
6	.5072
7	.4995
8	.4542
9	.3262
10	.3045
11	.2987
12	.2534
13	.2446
14	.2263
15	.2321
16	.2442
17	.2644
18	.3064
19	.3715
20	.3749
21	.3551
22	.3235
23	.2968
24	.2572
Max	.5072
Min	.2263
Avg	.3179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-OCT-17 and 21-OCT-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194081 / 33/11 KV KATI SUBSTATION

Feeder No / Name : 202 / 11 KV WANEWADI SPP FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	19-OCT-17
HR	Load (MW)
2	.3963
3	.4572
4	.4877
5	.5487
6	.6401
7	.8535
8	.945
9	1.0669
Max	1.0669
Min	.3963
Avg	.6744