

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV CHAITANYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .5312 | .6348 |
| 2 | .5251 | .644 |
| 3 | .5411 | .6348 |
| 4 | .5434 | .6333 |
| 5 | .538 | .6264 |
| 6 | .5456 | .6203 |
| 7 | .5548 | .6668 |
| 8 | .5632 | .6935 |
| 9 | .5662 | .9564 |
| 10 | .6295 | 1.2963 |
| 11 | .6699 | 1.3573 |
| 12 | .5289 | 1.358 |
| 13 | .5205 | 1.3435 |
| 14 | .5266 | 1.1858 |
| 15 | .4824 | 1.105 |
| 16 | .5159 | 1.198 |
| 17 | .5746 | 1.4213 |
| 18 | .6173 | 1.4609 |
| 19 | .6142 | 1.2635 |
| 20 | .6493 | .9938 |
| 21 | .6455 | .9343 |
| 22 | .6409 | .8863 |
| 23 | .6485 | .8733 |
| 24 | .6485 | .8474 |
| Max | .6699 | 1.4609 |
| Min | .4824 | .6203 |
| Avg | .5759 | .9848 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV OLD SHASHAKIYA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .506 | .5014 |
| 2 | .5144 | .5045 |
| 3 | .5152 | .5129 |
| 4 | .5098 | .5129 |
| 5 | .5098 | .519 |
| 6 | .5159 | .522 |
| 7 | .5441 | .5586 |
| 8 | .5533 | .5472 |
| 9 | .5418 | .6188 |
| 10 | .503 | 1.0029 |
| 11 | .4946 | 1.1858 |
| 12 | .5632 | 1.1606 |
| 13 | .5617 | 1.2498 |
| 14 | | 1.1286 |
| 15 | | 1.0959 |
| 16 | .5045 | 1.1637 |
| 17 | .5403 | 1.2247 |
| 18 | .5479 | 1.0928 |
| 19 | .5403 | .8825 |
| 20 | .5548 | .7301 |
| 21 | .5525 | .644 |
| 22 | .5289 | .535 |
| 23 | .5136 | .5213 |
| 24 | .506 | .5098 |
| Max | .5632 | 1.2498 |
| Min | .4946 | .5014 |
| Avg | .5283 | .7885 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV TEXTILE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3353 | .3582 |
| 2 | .3536 | .3688 |
| 3 | .3567 | .3704 |
| 4 | .3521 | .3749 |
| 5 | .3475 | .3719 |
| 6 | .3506 | .3765 |
| 7 | .349 | .381 |
| 8 | .3643 | .4268 |
| 9 | .349 | .4207 |
| 10 | .4054 | .5213 |
| 11 | .3841 | .631 |
| 12 | .3597 | .7026 |
| 13 | .3658 | .7743 |
| 14 | .3993 | .8154 |
| 15 | .3643 | .6889 |
| 16 | .3841 | .7636 |
| 17 | .3551 | .8185 |
| 18 | .3887 | .8429 |
| 19 | .3551 | .8032 |
| 20 | .381 | .6569 |
| 21 | .3871 | .6036 |
| 22 | .3795 | .4359 |
| 23 | .3841 | .3521 |
| 24 | .3734 | .3399 |
| Max | .4054 | .8429 |
| Min | .3353 | .3399 |
| Avg | .3677 | .5500 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.9174 | 1.9265 |
| 2 | 1.7657 | 1.7985 |
| 3 | 1.7269 | 1.7253 |
| 4 | 1.6903 | 1.6941 |
| 5 | 1.6644 | 1.6888 |
| 6 | 1.6865 | 1.7886 |
| 7 | 1.752 | 1.9479 |
| 8 | 1.8473 | 1.9814 |
| 9 | 1.8503 | 1.9776 |
| 10 | 1.9098 | 2.05 |
| 11 | 2.146 | 2.1696 |
| 12 | 2.2542 | 2.3449 |
| 13 | 2.1727 | 2.4989 |
| 14 | 2.223 | 2.3868 |
| 15 | 2.1155 | 2.2695 |
| 16 | 2.1163 | |
| 17 | 2.146 | 1.2612 |
| 18 | 2.316 | 3.0224 |
| 19 | 2.7 | 3.187 |
| 20 | 2.806 | 3.1809 |
| 21 | 2.6779 | 2.9881 |
| 22 | 2.5263 | 2.7359 |
| 23 | 2.3693 | 2.428 |
| 24 | 2.1392 | 2.1521 |
| Max | 2.806 | 3.187 |
| Min | 1.6644 | 1.2612 |
| Avg | 2.1050 | 2.2263 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 201 / 11 KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .599 | .599 |
| 2 | .5761 | .5761 |
| 3 | .5624 | .5624 |
| 4 | .5655 | .5594 |
| 5 | .6051 | .5655 |
| 6 | .6874 | .6325 |
| 7 | .8032 | .7011 |
| 8 | .8169 | .6874 |
| 9 | .8017 | .6859 |
| 10 | .7255 | .6401 |
| 11 | .6371 | .6173 |
| 12 | .6127 | .6051 |
| 13 | .6112 | .567 |
| 14 | .5868 | .5914 |
| 15 | .5517 | .5548 |
| 16 | .5685 | .5929 |
| 17 | .5639 | .6508 |
| 18 | .6005 | .7651 |
| 19 | .695 | .8398 |
| 20 | .7072 | .8002 |
| 21 | .7133 | .8017 |
| 22 | .724 | .7621 |
| 23 | .6889 | .6965 |
| 24 | .6401 | .6447 |
| Max | .8169 | .8398 |
| Min | .5517 | .5548 |
| Avg | .6518 | .6541 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 202 / 11 KV DWARAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.893 | 1.9311 |
| 2 | 1.7894 | 1.8397 |
| 3 | 1.7116 | 1.8275 |
| 4 | 1.6872 | 1.6872 |
| 5 | 1.7269 | 1.7269 |
| 6 | 1.7909 | 1.7909 |
| 7 | 1.8458 | 1.8458 |
| 8 | 1.9555 | 1.9555 |
| 9 | 2.0332 | 2.0332 |
| 10 | 2.0835 | 2.0835 |
| 11 | 2.2329 | 2.2329 |
| 12 | 2.1887 | 2.1887 |
| 13 | 2.0774 | 2.0774 |
| 14 | 2.0546 | 2.0546 |
| 15 | 2.0043 | 2.0043 |
| 16 | 2.021 | 2.021 |
| 17 | 2.0759 | 2.0759 |
| 18 | 2.271 | 2.271 |
| 19 | 2.5652 | 2.5652 |
| 20 | 2.5499 | 2.5499 |
| 21 | 2.4874 | 2.4874 |
| 22 | 2.4371 | 2.4371 |
| 23 | 2.3061 | 2.3061 |
| 24 | 2.1094 | 2.1094 |
| Max | 2.5652 | 2.5652 |
| Min | 1.6872 | 1.6872 |
| Avg | 2.0791 | 2.0876 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 204 / 11 KV SWAMI SAMARTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.448 | 1.448 |
| 2 | 1.3717 | 1.3717 |
| 3 | 1.3717 | 1.3717 |
| 4 | 1.2955 | 1.2955 |
| 5 | 1.2955 | 1.2955 |
| 6 | 1.3717 | 1.448 |
| 7 | 1.448 | 1.6004 |
| 8 | 1.5242 | 1.6004 |
| 9 | 1.5242 | 1.5242 |
| 10 | 1.448 | 1.448 |
| 11 | 1.3717 | 1.3717 |
| 12 | 1.2955 | 1.2955 |
| 13 | 1.2955 | 1.2955 |
| 14 | 1.2193 | 1.2193 |
| 15 | 1.1431 | 1.2193 |
| 16 | 1.2193 | 1.2193 |
| 17 | 1.2193 | 1.2955 |
| 18 | 1.5242 | 1.5242 |
| 19 | 1.9052 | 1.7528 |
| 20 | 1.9052 | 1.829 |
| 21 | 1.9052 | 1.829 |
| 22 | 1.829 | 1.829 |
| 23 | 1.7528 | 1.7528 |
| 24 | 1.6004 | 1.5242 |
| Max | 1.9052 | 1.829 |
| Min | 1.1431 | 1.2193 |
| Avg | 1.4702 | 1.4734 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 205 / 11 KV SIDDESHWAR MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2004 | .205 |
| 2 | .1951 | .1905 |
| 3 | .1959 | .1867 |
| 4 | .1943 | .1859 |
| 5 | .1966 | .192 |
| 6 | .2004 | .1936 |
| 7 | .2637 | .3292 |
| 8 | .2934 | .3559 |
| 9 | .3041 | .3727 |
| 10 | .3117 | .349 |
| 11 | .3269 | .3475 |
| 12 | .2873 | .3056 |
| 13 | .3269 | .2759 |
| 14 | .3391 | .2637 |
| 15 | .2553 | .2583 |
| 16 | .2957 | .2583 |
| 17 | .3208 | .333 |
| 18 | .3513 | .3559 |
| 19 | .3307 | .3567 |
| 20 | .2926 | .2705 |
| 21 | .2911 | .2454 |
| 22 | .2865 | .2454 |
| 23 | .2736 | .2309 |
| 24 | .2454 | .2195 |
| Max | .3513 | .3727 |
| Min | .1943 | .1859 |
| Avg | .2741 | .2720 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 204 / 11 KV URBAN/SOS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2309 | .2149 |
| 2 | .2248 | .2088 |
| 3 | .2225 | .1997 |
| 4 | .2195 | .1989 |
| 5 | .2362 | .218 |
| 6 | .2538 | .2561 |
| 7 | .2789 | .3353 |
| 8 | .3246 | .3269 |
| 9 | .3201 | .3033 |
| 10 | .3437 | .3246 |
| 11 | .3384 | .3437 |
| 12 | .2629 | .3353 |
| 13 | .2309 | .3132 |
| 14 | .2637 | .2881 |
| 15 | .3201 | .2797 |
| 16 | .2919 | .2477 |
| 17 | .2728 | .2606 |
| 18 | .2507 | .2919 |
| 19 | .3193 | .3315 |
| 20 | .3079 | .2957 |
| 21 | .2644 | .2782 |
| 22 | .2561 | .2675 |
| 23 | .2576 | .2568 |
| 24 | .2408 | .2355 |
| Max | .3437 | .3437 |
| Min | .2195 | .1989 |
| Avg | .2722 | .2755 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 204 / 11 kV Subhash Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4915 | .506 |
| 2 | .4733 | .4771 |
| 3 | .4481 | .4611 |
| 4 | .4367 | .4397 |
| 5 | .4412 | .4306 |
| 6 | .4435 | .4382 |
| 7 | .4778 | .4938 |
| 8 | .5014 | .5274 |
| 9 | .4733 | .5868 |
| 10 | | .5868 |
| 11 | 1.0974 | .8169 |
| 12 | 1.1088 | 1.1271 |
| 13 | 1.0966 | 1.1446 |
| 14 | 1.057 | 1.1469 |
| 15 | 1.0189 | 1.1485 |
| 16 | .9945 | 1.153 |
| 17 | .9739 | 1.1888 |
| 18 | 1.0265 | 1.3184 |
| 19 | 1.1385 | 1.4822 |
| 20 | 1.1332 | 1.4914 |
| 21 | .9435 | 1.4647 |
| 22 | .7956 | 1.1446 |
| 23 | .6196 | .6272 |
| 24 | .5487 | .5335 |
| Max | 1.1385 | 1.4914 |
| Min | .4367 | .4306 |
| Avg | .7713 | .8640 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 206 / 11 KV SALE GALLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7415 | .7423 |
| 2 | .6996 | .7194 |
| 3 | .6912 | .7118 |
| 4 | .6927 | .7133 |
| 5 | .7369 | .7331 |
| 6 | .7491 | .7872 |
| 7 | .7636 | .8131 |
| 8 | .8116 | .8756 |
| 9 | .8086 | .8551 |
| 10 | | .7682 |
| 11 | 1.1081 | .743 |
| 12 | 1.0524 | .7636 |
| 13 | .8467 | .7316 |
| 14 | .7278 | .6813 |
| 15 | .6737 | .6287 |
| 16 | .6836 | .6135 |
| 17 | .6562 | .6889 |
| 18 | .7712 | .7727 |
| 19 | .9023 | .9389 |
| 20 | .9175 | .9541 |
| 21 | .9092 | .9183 |
| 22 | .8863 | .9 |
| 23 | .8604 | .8848 |
| 24 | .7926 | .8055 |
| Max | 1.1081 | .9541 |
| Min | .6562 | .6135 |
| Avg | .8036 | .781 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 206 / 11 KV KIRTI GOLD
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.6309 | 1.8671 |
| 2 | 1.6651 | 1.7947 |
| 3 | 1.6537 | 1.8214 |
| 4 | 1.6499 | 1.829 |
| 5 | 1.4708 | 1.8176 |
| 6 | 1.4137 | 1.848 |
| 7 | 1.4556 | 1.8519 |
| 8 | 1.4098 | 1.8328 |
| 9 | 1.6118 | 1.8023 |
| 10 | 1.528 | 1.848 |
| 11 | 1.6347 | 1.8823 |
| 12 | 1.2879 | 1.9547 |
| 13 | 1.7909 | 2.0081 |
| 14 | 1.8404 | 1.909 |
| 15 | 1.2346 | 1.9243 |
| 16 | 1.7414 | 1.9738 |
| 17 | 1.7375 | 1.9204 |
| 18 | 1.4975 | 1.9624 |
| 19 | 1.5051 | 1.9166 |
| 20 | 1.4327 | 1.8138 |
| 21 | 1.5242 | 1.768 |
| 22 | 1.688 | 1.909 |
| 23 | 1.688 | 1.9204 |
| 24 | 1.8861 | 1.89 |
| Max | 1.8861 | 2.0081 |
| Min | 1.2346 | 1.768 |
| Avg | 1.5824 | 1.8777 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 402 / 33 KV MEDICAL COLLEGE

SHEDDABLE URBAN

FEEDER Feeder KV- 33 /
INCOMING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 15.1578 | 15.2264 |
| 2 | 14.2661 | 14.2661 |
| 3 | 13.7174 | 13.9232 |
| 4 | 13.3745 | 13.7174 |
| 5 | 13.3059 | 13.5803 |
| 6 | 13.6489 | 14.1976 |
| 7 | 14.5405 | 15.9122 |
| 8 | 15.3635 | 16.5981 |
| 9 | 15.0206 | 16.118 |
| 10 | 14.8148 | 15.6379 |
| 11 | 14.3347 | 15.2264 |
| 12 | 13.786 | 14.129 |
| 13 | 14.0604 | 13.5117 |
| 14 | 13.5803 | 13.9232 |
| 15 | 12.7572 | 14.0604 |
| 16 | 12.963 | 13.8546 |
| 17 | 14.1976 | 14.6091 |
| 18 | 15.2264 | 15.8436 |
| 19 | 18.3128 | 18.1756 |
| 20 | 19.3416 | 18.7929 |
| 21 | 19.1358 | 18.8615 |
| 22 | 18.5871 | 18.6557 |
| 23 | 17.8327 | 17.9698 |
| 24 | 16.7353 | 16.6667 |
| Max | 19.3416 | 18.8615 |
| Min | 12.7572 | 13.5117 |
| Avg | 15.1692 | 15.5607 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 404 / 33 KV ADM AGRO. INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 4.5268 | 4.3896 |
| 2 | 4.5268 | 4.4239 |
| 3 | 4.5268 | 4.3896 |
| 4 | 4.5268 | 4.2524 |
| 5 | 4.561 | 4.2867 |
| 6 | 4.561 | 4.3553 |
| 7 | 4.561 | 4.3896 |
| 8 | 4.4925 | 4.2867 |
| 9 | 4.3553 | 4.2524 |
| 10 | 4.3553 | 4.2524 |
| 11 | 4.4582 | 4.1495 |
| 12 | 3.5665 | 4.2524 |
| 13 | 4.2524 | 4.4582 |
| 14 | 4.4239 | 4.4239 |
| 15 | 3.5322 | 4.1838 |
| 16 | 3.1893 | 4.2181 |
| 17 | 4.1838 | 4.2181 |
| 18 | 4.0124 | 4.4925 |
| 19 | 4.2181 | 4.5953 |
| 20 | 3.7723 | 4.6296 |
| 21 | 3.4979 | 4.6639 |
| 22 | 4.321 | 4.561 |
| 23 | 4.4239 | 4.5268 |
| 24 | 4.2524 | 4.4925 |
| Max | 4.561 | 4.6639 |
| Min | 3.1893 | 4.1495 |
| Avg | 4.2124 | 4.3810 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 201 / 11KV BHADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1524 | .1524 |
| 2 | .1524 | .1524 |
| 3 | .2286 | .1524 |
| 4 | .2286 | .1524 |
| 5 | | .2286 |
| 6 | | .2286 |
| 7 | | .3048 |
| 8 | | .3048 |
| 9 | | .3048 |
| 11 | .2286 | |
| 12 | .2286 | |
| 13 | .2286 | |
| 14 | .2286 | |
| 15 | .2286 | |
| 16 | .3048 | |
| 17 | .3048 | .0762 |
| 18 | .1524 | .0762 |
| 19 | .2286 | .2286 |
| 20 | .3048 | .2286 |
| 21 | .3048 | .2286 |
| 22 | .2286 | .2286 |
| 23 | .1524 | .1524 |
| 24 | .1524 | .1524 |
| Max | .3048 | .3048 |
| Min | .1524 | .0762 |
| Avg | .2244 | .1972 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 202 / 11KV MAMDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .1524 |
| 2 | .1524 |
| 3 | .0762 |
| 4 | .0762 |
| 5 | .0762 |
| 6 | .1524 |
| 7 | .2286 |
| 8 | .2286 |
| 9 | .1524 |
| 17 | .1524 |
| 18 | .1524 |
| 19 | .2286 |
| 20 | .2286 |
| 21 | .2286 |
| 22 | .2286 |
| 23 | .2286 |
| 24 | .1524 |
| Max | .2286 |
| Min | .0762 |
| Avg | .1703 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 202 / KATGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .3048 |
| 2 | .3048 |
| 3 | .381 |
| 4 | .381 |
| 10 | .0762 |
| 11 | 1.1431 |
| 12 | 1.2193 |
| 13 | 1.5242 |
| 14 | 1.448 |
| 15 | 1.5242 |
| 16 | 1.3717 |
| 17 | .9145 |
| 18 | .6097 |
| 19 | .4572 |
| 20 | .4572 |
| 21 | .4572 |
| 22 | .381 |
| 23 | .381 |
| 24 | .3048 |
| Max | 1.5242 |
| Min | .0762 |
| Avg | .7179 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 201 / 11KV BORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .6097 |
| 2 | .4572 |
| 3 | .5335 |
| 4 | .5335 |
| 5 | .5335 |
| 6 | .6097 |
| 7 | .9907 |
| 8 | 1.2955 |
| 9 | 1.2955 |
| 16 | .2286 |
| 17 | .6097 |
| 18 | .7621 |
| 19 | .9145 |
| 20 | .9145 |
| 21 | .6859 |
| 22 | .381 |
| 23 | .381 |
| 24 | .381 |
| Max | 1.2955 |
| Min | .2286 |
| Avg | .6732 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 202 / 11KV MUSHIRABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2286 | .2286 |
| 2 | .2286 | .2286 |
| 3 | .3048 | .2286 |
| 4 | .3048 | .2286 |
| 5 | .3048 | .3048 |
| 6 | .381 | .381 |
| 7 | | .5335 |
| 8 | | .6097 |
| 9 | | .6097 |
| 11 | .4572 | |
| 12 | .4572 | |
| 13 | .5335 | |
| 14 | .5335 | |
| 15 | .5335 | |
| 16 | .5335 | |
| 17 | .5335 | .0762 |
| 18 | .5335 | .1524 |
| 19 | .3048 | .3048 |
| 20 | .381 | .3048 |
| 21 | .3048 | .3048 |
| 22 | .3048 | .2286 |
| 23 | .2286 | .2286 |
| 24 | .2286 | .2286 |
| Max | .5335 | .6097 |
| Min | .2286 | .0762 |
| Avg | .3810 | .3048 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 203 / 11KV SALGARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .0762 | .1524 |
| 2 | .0762 | .1524 |
| 3 | .1524 | .1524 |
| 4 | .3048 | .1524 |
| 5 | .381 | |
| 6 | .4572 | |
| 7 | .6859 | |
| 8 | .7621 | |
| 9 | .7621 | |
| 10 | | .1524 |
| 11 | | .7621 |
| 12 | | .9145 |
| 13 | | .9145 |
| 14 | | .9907 |
| 15 | | .9907 |
| 16 | | .8383 |
| 17 | .0762 | .7621 |
| 18 | .0762 | .6859 |
| 19 | .1524 | .1524 |
| 20 | .2286 | .2286 |
| 21 | .2286 | .1524 |
| 22 | .1524 | .1524 |
| 23 | .1524 | .1524 |
| 24 | .1524 | .0762 |
| Max | .7621 | .9907 |
| Min | .0762 | .0762 |
| Avg | .2869 | .4492 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 202 / 11KV KHOPEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .2286 |
| 2 | .2286 |
| 3 | .2286 |
| 4 | .2286 |
| 5 | .2286 |
| 11 | .2286 |
| 12 | .2286 |
| 13 | .2286 |
| 14 | .1524 |
| 15 | .1524 |
| 16 | .2286 |
| 17 | .2286 |
| 18 | .2286 |
| 19 | .2286 |
| 20 | .2286 |
| 21 | .3048 |
| 22 | .2286 |
| 23 | .2286 |
| 24 | .2286 |
| Max | .3048 |
| Min | .1524 |
| Avg | .2246 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 203 / 11KV RAJIV NAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1947 | .1658 |
| 2 | .1993 | .1711 |
| 3 | .1985 | .1932 |
| 4 | .1806 | .1806 |
| 5 | .2199 | .2199 |
| 6 | .2488 | .2488 |
| 7 | .3326 | .3326 |
| 8 | .3563 | .3563 |
| 9 | .322 | .322 |
| 16 | .08 | .08 |
| 17 | .0724 | .0724 |
| 18 | .0953 | .0953 |
| 19 | .1825 | .1825 |
| 20 | .1818 | .1818 |
| 21 | .1585 | .1585 |
| 22 | .1638 | .1638 |
| 23 | .1509 | .1509 |
| 24 | .1539 | .1539 |
| Max | .3563 | .3563 |
| Min | .0724 | .0724 |
| Avg | .1940 | .1905 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11KV WASANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3269 | .2248 |
| 2 | .5472 | .2218 |
| 3 | .538 | .2286 |
| 4 | .5319 | .2309 |
| 5 | .5357 | |
| 6 | .6226 | |
| 7 | .7857 | |
| 8 | .9069 | |
| 9 | .8634 | |
| 10 | | .2439 |
| 11 | | .6851 |
| 12 | | .7781 |
| 13 | | .7971 |
| 14 | | .7796 |
| 15 | | .7796 |
| 16 | .0671 | .8086 |
| 17 | .1471 | .7964 |
| 18 | .1608 | .6706 |
| 19 | .2233 | .2035 |
| 20 | .2324 | .2279 |
| 21 | .2362 | .2256 |
| 22 | .2507 | .2782 |
| 23 | .2576 | .2713 |
| 24 | .2446 | .2507 |
| Max | .9069 | .8086 |
| Min | .0671 | .2035 |
| Avg | .4155 | .4580 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11KV PETH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .5068 | .5708 |
| 2 | .3673 | .6059 |
| 3 | .362 | .6828 |
| 4 | .4108 | .5998 |
| 5 | .4915 | |
| 6 | .6257 | |
| 7 | .961 | |
| 8 | .8467 | |
| 9 | .7064 | |
| 10 | | .6013 |
| 11 | | .6805 |
| 12 | | .6882 |
| 13 | | .7308 |
| 14 | | .8482 |
| 15 | | .8101 |
| 16 | .4085 | .852 |
| 17 | .4473 | .8391 |
| 18 | .5769 | .8177 |
| 19 | .7354 | .66 |
| 20 | .7103 | .6699 |
| 21 | .6927 | .6851 |
| 22 | .6653 | .6714 |
| 23 | .6249 | .5967 |
| 24 | .5838 | .5556 |
| Max | .961 | .852 |
| Min | .362 | .5556 |
| Avg | .5957 | .6929 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 202 / 11KV KHANDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 2 | 1.0364 |
| 3 | 1.0364 |
| 4 | 1.0364 |
| 5 | 1.2803 |
| 6 | 1.6461 |
| 7 | 2.5606 |
| 8 | 2.9264 |
| 9 | 2.8045 |
| Max | 2.9264 |
| Min | 1.0364 |
| Avg | 1.7909 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 204 / SHANKARSHETH POLYMERS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .0762 | .0762 |
| 2 | .0762 | .0762 |
| 3 | .0762 | .0762 |
| 4 | .0762 | .0762 |
| 5 | .0762 | .0762 |
| 6 | .0762 | .0762 |
| 7 | .0762 | .0762 |
| 8 | .0762 | .0762 |
| 9 | .0762 | .0762 |
| 10 | .0762 | .0762 |
| 11 | .0381 | .0762 |
| 12 | .0762 | .0762 |
| 13 | .0762 | .0762 |
| 14 | .0381 | .0381 |
| 15 | .0381 | .0381 |
| 16 | .0762 | .0762 |
| 17 | .0762 | .1143 |
| 18 | .0762 | .1143 |
| 19 | .0381 | .0762 |
| 20 | .0762 | .0762 |
| 21 | .0762 | .0762 |
| 22 | .0762 | .0762 |
| 23 | .0762 | .0762 |
| 24 | .0762 | .0762 |
| Max | .0762 | .1143 |
| Min | .0381 | .0381 |
| Avg | .0699 | .0762 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 206 / Gajraj

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .487 | .4702 |
| 2 | .4992 | .49 |
| 3 | .503 | .4816 |
| 4 | .4839 | .4862 |
| 5 | .4961 | .4862 |
| 6 | .4885 | .4733 |
| 7 | .4938 | .503 |
| 8 | .4809 | .4923 |
| 9 | .4512 | .5007 |
| 10 | .503 | .5068 |
| 11 | .5335 | .5121 |
| 12 | .5517 | .5053 |
| 13 | .4748 | .5175 |
| 14 | .4816 | .5014 |
| 15 | .5152 | .4984 |
| 16 | .5121 | .5411 |
| 17 | .4839 | .5319 |
| 18 | .4999 | .5243 |
| 19 | .4618 | .5266 |
| 20 | .4626 | .506 |
| 21 | .474 | .4824 |
| 22 | .4542 | .4908 |
| 23 | .4611 | .4992 |
| 24 | .4633 | .4839 |
| Max | .5517 | .5411 |
| Min | .4512 | .4702 |
| Avg | .4882 | .5005 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 207 / 11 KV Dhoot feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3894 | .2789 |
| 2 | .3361 | .2782 |
| 3 | .3048 | .2576 |
| 4 | .3315 | .3033 |
| 5 | .1852 | .1562 |
| 6 | .1852 | .1395 |
| 7 | .2248 | .2027 |
| 8 | .2515 | .221 |
| 9 | .2355 | .2522 |
| 10 | .2804 | .314 |
| 11 | .269 | .2698 |
| 12 | .1974 | .1905 |
| 13 | .0869 | .2789 |
| 14 | .253 | .2797 |
| 15 | .192 | .2766 |
| 16 | .2233 | .3224 |
| 17 | .2477 | .3125 |
| 18 | .2446 | .3391 |
| 19 | .2301 | .3346 |
| 20 | .2088 | .2926 |
| 21 | .2218 | .3582 |
| 22 | .1738 | .3018 |
| 23 | .1814 | .2515 |
| 24 | .1951 | .2629 |
| Max | .3894 | .3582 |
| Min | .0869 | .1395 |
| Avg | .2354 | .2698 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 208 / 11 KV Kalantri feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.2559 | .833 |
| 2 | 1.2551 | .8993 |
| 3 | 1.2719 | .9389 |
| 4 | 1.2125 | .9351 |
| 5 | 1.2628 | .8901 |
| 6 | 1.326 | .9259 |
| 7 | 1.3161 | .945 |
| 8 | 1.3253 | .8688 |
| 9 | 1.1957 | .7865 |
| 10 | 1.2353 | .8825 |
| 11 | 1.3573 | 1.262 |
| 12 | 1.3847 | 1.4556 |
| 13 | 1.371 | 1.4319 |
| 14 | 1.2323 | 1.3786 |
| 15 | 1.2704 | 1.3016 |
| 16 | 1.3626 | 1.243 |
| 17 | 1.3649 | 1.2666 |
| 18 | 1.3458 | 1.2719 |
| 19 | .9054 | 1.3199 |
| 20 | .9153 | 1.2978 |
| 21 | .6683 | 1.2841 |
| 22 | .5822 | 1.3367 |
| 23 | .2888 | 1.3253 |
| 24 | .8116 | 1.2864 |
| Max | 1.3847 | 1.4556 |
| Min | .2888 | .7865 |
| Avg | 1.1466 | 1.1403 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 201 / 11KV Nagazari

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1707 | .1852 |
| 2 | .1334 | .2058 |
| 3 | .1387 | .2241 |
| 4 | .1524 | .2423 |
| 5 | .1539 | |
| 6 | .2263 | |
| 7 | .3551 | |
| 8 | .3727 | |
| 9 | .3917 | |
| 10 | .205 | .1539 |
| 11 | | .4047 |
| 12 | | .4359 |
| 13 | | .4039 |
| 14 | | .4153 |
| 15 | | .3849 |
| 16 | .0777 | .3612 |
| 17 | .1364 | .3216 |
| 18 | .1486 | .3041 |
| 19 | .2027 | .2561 |
| 20 | .2279 | .2766 |
| 21 | .2446 | .2279 |
| 22 | .237 | .2111 |
| 23 | .1997 | .2042 |
| 24 | .1859 | .1837 |
| Max | .3917 | .4359 |
| Min | .0777 | .1539 |
| Avg | .2084 | .2843 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 202 / 11 KV SAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2705 | .2683 |
| 2 | .2713 | .2096 |
| 3 | .301 | .2218 |
| 4 | .3163 | .2423 |
| 5 | | .2843 |
| 6 | | .266 |
| 7 | | .4016 |
| 8 | | .4336 |
| 9 | | .3932 |
| 10 | .1143 | .1585 |
| 11 | .2683 | |
| 12 | .2881 | |
| 13 | .4085 | |
| 14 | .3955 | |
| 15 | .3909 | |
| 16 | .4367 | .0564 |
| 17 | .4519 | .1539 |
| 18 | .4153 | .1837 |
| 19 | .3292 | .3056 |
| 20 | .3422 | .3048 |
| 21 | .317 | .2942 |
| 22 | .298 | .2995 |
| 23 | .2698 | .269 |
| 24 | .2614 | .2683 |
| Max | .4519 | .4336 |
| Min | .1143 | .0564 |
| Avg | .3235 | .2639 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 203 / 11 KV RAIWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .535 | .5411 |
| 2 | .5761 | .5898 |
| 3 | .6539 | .6706 |
| 4 | .4428 | .0838 |
| 10 | .4428 | .378 |
| 11 | .3711 | .4275 |
| 12 | .41 | .4329 |
| 13 | .4572 | .4809 |
| 14 | .4367 | .4717 |
| 15 | .4473 | .4694 |
| 16 | .458 | .442 |
| 17 | .4428 | .423 |
| 18 | .4946 | .189 |
| 19 | .5777 | .2362 |
| 20 | .5975 | .6607 |
| 21 | .5799 | .6356 |
| 22 | .5586 | .5677 |
| 23 | .5258 | .5327 |
| 24 | .5258 | .4908 |
| Max | .6539 | .6706 |
| Min | .3711 | .0838 |
| Avg | .5018 | .4591 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154121 / Ganjur Substation

Feeder No / Name : 202 / 11KV WAKDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .0892 | .0777 |
| 2 | .1158 | .1143 |
| 3 | .1768 | .1196 |
| 4 | .1753 | .1227 |
| 5 | | .1288 |
| 6 | | .1707 |
| 7 | | .202 |
| 8 | | .2233 |
| 9 | | .2073 |
| 10 | .0655 | .0861 |
| 11 | .1837 | |
| 12 | .2103 | |
| 13 | .2111 | |
| 14 | .2004 | |
| 15 | .2141 | |
| 16 | .2241 | .0381 |
| 17 | .2324 | .0876 |
| 18 | .2241 | .1547 |
| 19 | .112 | .1859 |
| 20 | .1608 | .1715 |
| 21 | .1463 | .144 |
| 22 | .1242 | .1257 |
| 23 | .109 | .0953 |
| 24 | .0221 | .0823 |
| Max | .2324 | .2233 |
| Min | .0221 | .0381 |
| Avg | .1577 | .1336 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157001 / 132 KV KOYANA

Feeder No / Name : 203 / 11 KV TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .9526 | .9145 |
| 2 | .8993 | .8688 |
| 3 | .8612 | .8459 |
| 4 | .8612 | .8383 |
| 5 | .8764 | .8535 |
| 6 | .9221 | .9069 |
| 7 | .9526 | .945 |
| 8 | .9755 | 1.0136 |
| 9 | .9983 | 1.0136 |
| 10 | .9755 | .9678 |
| 11 | .9374 | .9069 |
| 12 | .9526 | .8916 |
| 13 | .8764 | .884 |
| 14 | .8535 | .8535 |
| 15 | .8078 | .823 |
| 16 | .8002 | .7926 |
| 17 | .7773 | .7392 |
| 18 | .823 | .9069 |
| 19 | 1.0745 | 1.0745 |
| 20 | 1.1355 | 1.1736 |
| 21 | 1.1203 | 1.1279 |
| 22 | 1.0669 | 1.0974 |
| 23 | 1.0745 | 1.0745 |
| 24 | .9983 | 1.0059 |
| Max | 1.1355 | 1.1736 |
| Min | .7773 | .7392 |
| Avg | .9405 | .9383 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157001 / 132 KV KOYANA

Feeder No / Name : 204 / 11 KV SHIDDHESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.0136 | 1.0898 |
| 2 | .9602 | 1.044 |
| 3 | .9374 | 1.0212 |
| 4 | .9297 | 1.025 |
| 5 | .9488 | 1.0326 |
| 6 | 1.0326 | 1.0745 |
| 7 | 1.0745 | 1.2308 |
| 8 | 1.2155 | 1.2841 |
| 9 | 1.2193 | 1.2917 |
| 10 | 1.2841 | 1.3108 |
| 11 | 1.3146 | 1.3717 |
| 12 | 1.307 | 1.4022 |
| 13 | 1.1279 | 1.1584 |
| 14 | 1.0669 | 1.1431 |
| 15 | 1.1241 | 1.1927 |
| 16 | 1.1622 | 1.246 |
| 17 | 1.2117 | 1.2193 |
| 18 | 1.2346 | 1.2993 |
| 19 | 1.3756 | 1.4861 |
| 20 | 1.4251 | 1.5699 |
| 21 | 1.3946 | 1.4746 |
| 22 | 1.3184 | 1.2727 |
| 23 | 1.2803 | 1.2422 |
| 24 | 1.1698 | 1.1546 |
| Max | 1.4251 | 1.5699 |
| Min | .9297 | 1.0212 |
| Avg | 1.1720 | 1.2349 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157001 / 132 KV KOYANA

Feeder No / Name : 205 / 11 KV INDUSTRIAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1943 | .1981 |
| 2 | .1829 | .1867 |
| 3 | .1791 | .1829 |
| 4 | .1753 | .1791 |
| 5 | .1753 | .1829 |
| 6 | .1753 | .1791 |
| 7 | .1753 | .1791 |
| 8 | .1791 | .1905 |
| 9 | .1791 | .1981 |
| 10 | .1638 | .202 |
| 11 | .1715 | .1677 |
| 12 | .1562 | .16 |
| 13 | .1524 | .16 |
| 14 | .1562 | .1448 |
| 15 | .1677 | .1524 |
| 16 | .1448 | .1372 |
| 17 | .1524 | .1448 |
| 18 | .1524 | .1715 |
| 19 | .1791 | .2058 |
| 20 | .2248 | .2134 |
| 21 | .221 | .2172 |
| 22 | .2172 | .221 |
| 23 | .2134 | .2134 |
| 24 | .2096 | .2096 |
| Max | .2248 | .221 |
| Min | .1448 | .1372 |
| Avg | .1791 | .1832 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157001 / 132 KV KOYANA

Feeder No / Name : 206 / 11 KV SOOT MILL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.5851 | 1.7337 |
| 2 | 1.4708 | 1.5737 |
| 3 | 1.3984 | 1.5051 |
| 4 | 1.3489 | 1.4899 |
| 5 | 1.3298 | 1.4899 |
| 6 | 1.3794 | 1.5966 |
| 7 | 1.4822 | 1.7337 |
| 8 | 1.6842 | 1.8366 |
| 9 | 1.6461 | 1.7566 |
| 10 | 1.6423 | 1.8214 |
| 11 | 1.6385 | 1.8519 |
| 12 | 1.6309 | 1.8366 |
| 13 | 1.5051 | 1.6842 |
| 14 | 1.4937 | 1.8138 |
| 15 | 1.4594 | 1.909 |
| 16 | 1.4861 | 1.8976 |
| 17 | 1.608 | 1.9395 |
| 18 | 1.7718 | 2.0424 |
| 19 | 2.0309 | 2.2443 |
| 20 | 2.0881 | 2.3129 |
| 21 | 2.05 | 2.3358 |
| 22 | 2.0995 | 2.2329 |
| 23 | 2.0843 | 2.0881 |
| 24 | 1.8823 | 1.8671 |
| Max | 2.0995 | 2.3358 |
| Min | 1.3298 | 1.4899 |
| Avg | 1.6582 | 1.8581 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157001 / 132 KV KOYANA

Feeder No / Name : 207 / 11 KV SAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .663 | .644 |
| 2 | .6173 | .6135 |
| 3 | .5944 | .5982 |
| 4 | .5868 | .5944 |
| 5 | .6059 | .5982 |
| 6 | .6325 | .5754 |
| 7 | .6249 | .5982 |
| 8 | .663 | .602 |
| 9 | .6401 | .5906 |
| 10 | .6668 | .6173 |
| 11 | .6592 | .5944 |
| 12 | .5792 | .5487 |
| 13 | .5411 | .5449 |
| 14 | .4763 | .4954 |
| 15 | .4687 | .4801 |
| 16 | .4611 | .4611 |
| 17 | .4534 | .4725 |
| 18 | .4915 | .5601 |
| 19 | .6821 | .6706 |
| 20 | .7506 | .7164 |
| 21 | .7316 | .7087 |
| 22 | .7125 | .724 |
| 23 | .7125 | .7087 |
| 24 | .6859 | .6783 |
| Max | .7506 | .724 |
| Min | .4534 | .4611 |
| Avg | .6125 | .5998 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157001 / 132 KV KOYANA

Feeder No / Name : 208 / 11 KV AUSA ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.6079 | 1.5852 |
| 2 | 1.5012 | 1.4784 |
| 3 | 1.4099 | 1.4099 |
| 4 | 1.3794 | 1.387 |
| 5 | 1.3642 | 1.3642 |
| 6 | 1.4023 | 1.4936 |
| 7 | 1.5013 | 1.6309 |
| 8 | 1.7299 | 1.7908 |
| 9 | 1.7908 | 1.8671 |
| 10 | 1.6613 | 1.7527 |
| 11 | 1.646 | 1.707 |
| 12 | 1.6079 | 1.6842 |
| 13 | 1.5775 | 1.6842 |
| 14 | 1.5089 | 1.6842 |
| 15 | 1.5546 | 1.6842 |
| 16 | 1.547 | 1.6003 |
| 17 | 1.5622 | 1.6308 |
| 18 | 1.7528 | 1.8747 |
| 19 | 1.9814 | 2.0423 |
| 20 | 2.0423 | 2.0804 |
| 21 | 2.0119 | 2.0423 |
| 22 | 1.9814 | 1.9966 |
| 23 | 1.8975 | 1.9052 |
| 24 | 1.7985 | 1.7832 |
| Max | 2.0423 | 2.0804 |
| Min | 1.3642 | 1.3642 |
| Avg | 1.6591 | 1.7150 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157001 / 132 KV KOYANA

Feeder No / Name : 209 / 11 KV SINHGAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7049 | .7202 |
| 2 | .6668 | .6859 |
| 3 | .6554 | .6744 |
| 4 | .6401 | .6706 |
| 5 | .6706 | .7011 |
| 6 | .7011 | .7659 |
| 7 | .7964 | .8688 |
| 8 | .8154 | .8764 |
| 9 | .8307 | .8116 |
| 10 | .7811 | .9069 |
| 11 | .7125 | .823 |
| 12 | .7811 | .8002 |
| 13 | .7583 | .7621 |
| 14 | .7316 | .7926 |
| 15 | .7087 | .7506 |
| 16 | .6821 | .7011 |
| 17 | .7202 | .7697 |
| 18 | .7506 | .7659 |
| 19 | .8954 | .8802 |
| 20 | .9678 | .9297 |
| 21 | .9335 | .9412 |
| 22 | .9031 | .8993 |
| 23 | .8916 | .8688 |
| 24 | .8002 | .7583 |
| Max | .9678 | .9412 |
| Min | .6401 | .6706 |
| Avg | .7708 | .7969 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 204 / 11 KV DAYANAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 3.1779 | 3.2007 |
| 2 | 2.995 | 3.0407 |
| 3 | 2.8883 | 2.9416 |
| 4 | 2.8426 | 2.9111 |
| 5 | 2.8654 | 2.9035 |
| 6 | 2.9492 | 3.0331 |
| 7 | 3.2007 | 3.3532 |
| 8 | 3.4065 | 3.6046 |
| 9 | 3.315 | 3.5513 |
| 10 | 3.1398 | 3.3379 |
| 11 | 3.0407 | 3.094 |
| 12 | 2.995 | 2.934 |
| 13 | 2.9188 | 2.8578 |
| 14 | 2.873 | 2.9188 |
| 15 | 2.774 | 2.9188 |
| 16 | 2.7664 | 2.7664 |
| 17 | 2.8959 | 2.7968 |
| 18 | 3.0483 | 3.1017 |
| 19 | 3.6808 | 3.6656 |
| 20 | 4.0314 | 3.9857 |
| 21 | 3.9781 | 3.94 |
| 22 | 3.9552 | 3.9628 |
| 23 | 3.818 | 3.8637 |
| 24 | 3.5208 | 3.5132 |
| Max | 4.0314 | 3.9857 |
| Min | 2.7664 | 2.7664 |
| Avg | 3.2115 | 3.2582 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 205 / 11 KV BANDHKAM BHAVAN
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.89 | 1.8823 |
| 2 | 1.7528 | 1.768 |
| 3 | 1.6766 | 1.7147 |
| 4 | 1.6385 | 1.6613 |
| 5 | 1.6461 | 1.6613 |
| 6 | 1.669 | 1.7375 |
| 7 | 1.8519 | 1.9204 |
| 8 | 2.0271 | 2.1491 |
| 9 | 2.05 | 2.1719 |
| 10 | 1.989 | 2.0805 |
| 11 | 1.9662 | 1.9357 |
| 12 | 1.9052 | 1.9204 |
| 13 | 1.7909 | 1.9204 |
| 14 | 1.7223 | 1.8366 |
| 15 | 1.7604 | 1.7604 |
| 16 | 1.8138 | 1.7375 |
| 17 | 1.8138 | 1.9433 |
| 18 | 2.0043 | 2.1262 |
| 19 | 2.3853 | 2.4006 |
| 20 | 2.4996 | 2.4996 |
| 21 | 2.431 | 2.4996 |
| 22 | 2.3929 | 2.4463 |
| 23 | 2.3472 | 2.3015 |
| 24 | 2.1414 | 2.0805 |
| Max | 2.4996 | 2.4996 |
| Min | 1.6385 | 1.6613 |
| Avg | 1.9652 | 2.0065 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 206 / 11 kV Ekurga new

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4435 | .5533 |
| 2 | .4931 | .9945 |
| 3 | .5784 | 1.0075 |
| 4 | .6036 | 1.0296 |
| 5 | | 1.0829 |
| 6 | | 1.1637 |
| 7 | | 1.5988 |
| 8 | | 1.5249 |
| 9 | | 1.5836 |
| 10 | .6424 | .3948 |
| 11 | 1.3489 | |
| 12 | 1.4426 | |
| 13 | 1.5211 | |
| 14 | 1.7551 | |
| 15 | 1.7955 | |
| 16 | 1.7246 | .0854 |
| 17 | 1.72 | .2995 |
| 18 | 1.7193 | .3856 |
| 19 | .5738 | .6386 |
| 20 | .6828 | .692 |
| 21 | .5982 | .551 |
| 22 | .4496 | .458 |
| 23 | .4024 | .4115 |
| 24 | .3963 | .3887 |
| Max | 1.7955 | 1.5988 |
| Min | .3963 | .0854 |
| Avg | .9943 | .7813 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 207 / 11 KV MBF New

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 14 | .0434 |
| 15 | .0282 |
| Max | .0434 |
| Min | .0282 |
| Avg | .0358 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 205 / 11kv AADI AGRO Exp Fed NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1231 | .1578 |
| 2 | .1238 | .1593 |
| 3 | .128 | .1578 |
| 4 | .1261 | .1562 |
| 5 | .1166 | .1555 |
| 6 | .1265 | .1532 |
| 7 | .128 | .1673 |
| 8 | .1429 | .1715 |
| 9 | .1368 | .1497 |
| 10 | .1528 | .1269 |
| 11 | .1578 | .1113 |
| 12 | .1566 | .1189 |
| 13 | .1604 | .1307 |
| 14 | .1932 | .1391 |
| 15 | .1879 | .1337 |
| 16 | .2012 | .1421 |
| 17 | .1688 | .1273 |
| 18 | .1562 | .1208 |
| 19 | .1326 | .1109 |
| 20 | .1303 | .1265 |
| 21 | .1311 | .1612 |
| 22 | .1497 | .1604 |
| 23 | .1558 | .1608 |
| 24 | .1547 | .1604 |
| Max | .2012 | .1715 |
| Min | .1166 | .1109 |
| Avg | .1475 | .1441 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 204 / 11 KV Kanadi Borgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .6158 | .5487 |
| 2 | .9214 | .57 |
| 3 | .945 | .5982 |
| 4 | .9701 | .6173 |
| 5 | 1.0105 | |
| 6 | 1.1218 | |
| 7 | .9015 | |
| 8 | 1.2224 | |
| 9 | 1.2163 | |
| 10 | | .5205 |
| 11 | | 1.2468 |
| 12 | | 1.0021 |
| 13 | | 1.3573 |
| 14 | | 1.5988 |
| 15 | .1067 | 1.6148 |
| 16 | .3201 | 1.6766 |
| 17 | .4184 | 1.6766 |
| 18 | .5396 | 1.5546 |
| 19 | .6363 | .6417 |
| 20 | .6165 | .5982 |
| 21 | .4893 | .519 |
| 22 | .4915 | .5014 |
| 23 | .5037 | .5456 |
| 24 | .519 | .5746 |
| Max | 1.2224 | 1.6766 |
| Min | .1067 | .5014 |
| Avg | .7140 | .9454 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 206 / 11KV Tandulja AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | | .1075 |
| 2 | | .3018 |
| 3 | | .2995 |
| 4 | | .3033 |
| 5 | | .2987 |
| 6 | | .3079 |
| 7 | | .3544 |
| 8 | | .3506 |
| 9 | | .3368 |
| 10 | .1349 | |
| 11 | .394 | |
| 12 | .4626 | |
| 13 | .4771 | |
| 14 | .4824 | |
| 15 | .4946 | .1158 |
| 16 | .5014 | .0396 |
| 17 | .4687 | |
| 18 | .4633 | |
| Max | .5014 | .3544 |
| Min | .1349 | .0396 |
| Avg | .431 | .2560 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 201 / 11 KV Shiur Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2286 | .2286 |
| 2 | .3048 | .1524 |
| 3 | .3048 | .1524 |
| 4 | .1524 | .2286 |
| 5 | | .2286 |
| 6 | | .2286 |
| 7 | | .3048 |
| 8 | | .381 |
| 9 | | .381 |
| 10 | | .2286 |
| 11 | .3048 | |
| 12 | .381 | |
| 13 | .381 | |
| 14 | .381 | |
| 15 | .381 | |
| 16 | .381 | |
| 17 | .381 | .1524 |
| 18 | .381 | .1524 |
| 19 | .2286 | .3048 |
| 20 | .2286 | .3048 |
| 21 | .3048 | .2286 |
| 22 | .2286 | .2286 |
| 23 | .2286 | .2286 |
| 24 | .2286 | .2286 |
| Max | .381 | .381 |
| Min | .1524 | .1524 |
| Avg | .3006 | .2413 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 202 / 11 KV Utti Tawarja Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 2 | | .2286 |
| 3 | | .2286 |
| 4 | .0762 | .2286 |
| 5 | | .2286 |
| 6 | | .1524 |
| 7 | | .1524 |
| 8 | | .2286 |
| 9 | | .3048 |
| 10 | | .1524 |
| 11 | .2286 | |
| 12 | .3048 | |
| 13 | .381 | |
| 14 | .3048 | |
| 15 | .3048 | |
| 16 | .3048 | |
| 17 | .3048 | |
| 18 | .381 | |
| 19 | .1524 | |
| 20 | .0762 | .0762 |
| 21 | .0762 | .0762 |
| 22 | .0762 | .0762 |
| 23 | .0762 | .0762 |
| 24 | .0762 | |
| Max | .381 | .3048 |
| Min | .0762 | .0762 |
| Avg | .2083 | .1700 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 203 / 11 KV SAWARGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3048 | .3048 |
| 2 | .381 | .381 |
| 3 | .381 | .4572 |
| 4 | .381 | .4572 |
| 5 | .4572 | |
| 6 | .5335 | |
| 7 | .6859 | |
| 8 | .6859 | |
| 9 | .6097 | |
| 10 | .4572 | |
| 11 | | .6859 |
| 12 | | .9145 |
| 13 | | .9145 |
| 14 | | .9907 |
| 15 | | .9907 |
| 16 | | .6859 |
| 17 | .1524 | .8383 |
| 18 | .2286 | .8383 |
| 19 | .381 | .4572 |
| 20 | .5335 | .5335 |
| 21 | .4572 | .4572 |
| 22 | .381 | .381 |
| 23 | .3048 | .381 |
| 24 | .3048 | .381 |
| Max | .6859 | .9907 |
| Min | .1524 | .3048 |
| Avg | .4234 | .6139 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 205 / 11 KV Bhoyra New SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2614 | .221 |
| 2 | .2881 | .218 |
| 3 | .3033 | .2248 |
| 4 | .301 | .2477 |
| 5 | | .2759 |
| 6 | | .3147 |
| 7 | | .397 |
| 8 | | .3528 |
| 9 | | .301 |
| 10 | .1059 | .1189 |
| 11 | .2759 | |
| 12 | .3208 | |
| 13 | .3307 | |
| 14 | .349 | |
| 15 | .3589 | |
| 16 | .3666 | .016 |
| 17 | .3826 | .1166 |
| 18 | .3681 | .1608 |
| 19 | .2713 | .2606 |
| 20 | .3307 | .314 |
| 21 | .2949 | .2698 |
| 22 | .2728 | .2462 |
| 23 | .2515 | .2134 |
| 24 | .2301 | .2073 |
| Max | .3826 | .397 |
| Min | .1059 | .016 |
| Avg | .2981 | .2356 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 206 / 11 KV Ankoli new

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .535 | .4191 |
| 2 | .5838 | .3033 |
| 3 | .6135 | .3094 |
| 4 | .647 | .3368 |
| 5 | | .3688 |
| 6 | | .4481 |
| 7 | | .5738 |
| 8 | | .6051 |
| 9 | | .5655 |
| 10 | .144 | .4344 |
| 11 | .4641 | |
| 12 | .4847 | |
| 13 | .266 | |
| 15 | .3551 | |
| 16 | .4679 | .1357 |
| 17 | .5083 | .3185 |
| 18 | .4954 | .4702 |
| 19 | .6333 | .6135 |
| 20 | .6371 | .5891 |
| 21 | .5396 | .4626 |
| 22 | .4717 | .4222 |
| 23 | .426 | .3955 |
| 24 | .4123 | .3826 |
| Max | .647 | .6135 |
| Min | .144 | .1357 |
| Avg | .4825 | .4292 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 207 / 11 KV Dhanori

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .0594 | |
| 2 | .1181 | |
| 3 | .1181 | |
| 4 | .1174 | |
| 5 | .1174 | |
| 6 | .1181 | |
| 7 | .1661 | |
| 8 | .1837 | |
| 9 | .1806 | |
| 10 | | .0564 |
| 11 | | .1654 |
| 12 | | .2035 |
| 13 | | .2233 |
| 14 | | .2408 |
| 15 | | .2324 |
| 16 | | .2256 |
| 17 | | .2233 |
| 18 | | .221 |
| Max | .1837 | .2408 |
| Min | .0594 | .0564 |
| Avg | .1310 | .1991 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 201 / 11 KV KARKHANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .8078 | .4954 |
| 2 | .8078 | .5456 |
| 3 | .8177 | .6158 |
| 4 | .8627 | .4946 |
| 5 | .8741 | |
| 6 | 1.0219 | |
| 7 | 1.0479 | |
| 8 | 1.0128 | |
| 9 | .8177 | |
| 10 | .2614 | .9777 |
| 11 | | 1.1523 |
| 12 | | 1.1789 |
| 13 | | 1.1866 |
| 14 | | .4237 |
| 15 | | 1.1126 |
| 16 | .2812 | 1.1431 |
| 17 | .3658 | 1.1873 |
| 18 | .5312 | .9168 |
| 19 | .7476 | .6836 |
| 20 | .7232 | .7004 |
| 21 | .6737 | .6234 |
| 22 | .5845 | .5799 |
| 23 | .5266 | .474 |
| 24 | .4649 | .4542 |
| Max | 1.0479 | 1.1873 |
| Min | .2614 | .4237 |
| Avg | .6963 | .7866 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 202 / 11 KV NIVALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4618 | .4481 |
| 2 | .471 | .7773 |
| 3 | .5647 | .8025 |
| 4 | .6104 | .8482 |
| 5 | .3163 | .9191 |
| 6 | | .9488 |
| 7 | | 1.041 |
| 8 | | 1.2437 |
| 9 | | 1.2658 |
| 10 | | .7148 |
| 11 | .7888 | .112 |
| 12 | 1.0303 | |
| 13 | 1.1843 | |
| 14 | 1.3115 | |
| 15 | 1.3428 | |
| 16 | 1.1424 | |
| 17 | 1.2993 | |
| 18 | 1.3138 | .2721 |
| 19 | .9015 | .4885 |
| 20 | .6409 | .7278 |
| 21 | .6264 | .676 |
| 22 | .5738 | .5876 |
| 23 | .5114 | .5136 |
| 24 | .4633 | .4961 |
| Max | 1.3428 | 1.2658 |
| Min | .3163 | .112 |
| Avg | .8187 | .7157 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 203 / 11 KV DHAKNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1478 | .4451 |
| 2 | .1753 | .522 |
| 3 | .2157 | .5197 |
| 4 | .2286 | .5403 |
| 5 | | .5815 |
| 6 | | .6836 |
| 7 | | .9031 |
| 8 | | .9854 |
| 9 | | .9617 |
| 10 | .5045 | .1357 |
| 11 | .945 | |
| 12 | 1.0319 | |
| 13 | 1.0517 | |
| 14 | 1.0921 | |
| 15 | .8436 | |
| 16 | .8756 | .003 |
| 17 | .9054 | .0282 |
| 18 | .9015 | .1349 |
| 19 | .234 | .2713 |
| 20 | .2591 | .2538 |
| 21 | .1852 | .1829 |
| 22 | .1677 | .1547 |
| 23 | .1532 | .141 |
| 24 | .141 | .1273 |
| Max | 1.0921 | .9854 |
| Min | .141 | .003 |
| Avg | .5294 | .3987 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 203 / 11 KV GONDEGAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | *** | *** |
| 2 | | *** |
| 3 | | *** |
| Max | 152.4145 | 152.4145 |
| Min | 152.4145 | 152.4145 |
| Avg | 152.4145 | 152.4145 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 201 / 11KV Bhisewagholi SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3292 | .5777 |
| 2 | .3376 | .5738 |
| 3 | .3643 | .5708 |
| 4 | .4237 | .5677 |
| 5 | | .5898 |
| 6 | | .7186 |
| 7 | | 1.0319 |
| 8 | | 1.0982 |
| 9 | | .615 |
| 10 | .4603 | .1265 |
| 11 | .9061 | |
| 12 | .7948 | |
| 13 | 1.2559 | |
| 14 | 1.2742 | |
| 15 | 1.2506 | |
| 16 | 1.2704 | .112 |
| 17 | .9739 | .2949 |
| 18 | .9762 | .3734 |
| 19 | .5876 | .5655 |
| 20 | .6005 | .567 |
| 21 | .5037 | .4969 |
| 22 | .4291 | .4306 |
| 23 | .3643 | .3635 |
| 24 | .5007 | .3399 |
| Max | 1.2742 | 1.0982 |
| Min | .3292 | .112 |
| Avg | .7160 | .5270 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 202 / 11kv Wadiwagholi SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 3 | | .0633 |
| 4 | .0594 | .0892 |
| 5 | .5601 | .1014 |
| 6 | .6264 | |
| 7 | .8893 | |
| 8 | .8505 | |
| 9 | .7956 | |
| 10 | .0328 | .6904 |
| 11 | | .9579 |
| 12 | | 1.0509 |
| 13 | | 1.0547 |
| 14 | | 1.0837 |
| 15 | | 1.0768 |
| 16 | | .865 |
| 17 | | .9709 |
| 18 | .0457 | .9572 |
| 19 | .1334 | .141 |
| 20 | .1235 | .1417 |
| 21 | .0968 | .1052 |
| 22 | .0808 | .0831 |
| 23 | .0686 | .0069 |
| Max | .8893 | 1.0837 |
| Min | .0328 | .0069 |
| Avg | .3356 | .5553 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 203 / 11kv Khuntephal SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 4 | .0015 | |
| 6 | .1014 | |
| 7 | .2446 | |
| 8 | .285 | |
| 9 | .2964 | |
| 10 | | .1448 |
| 11 | | .2789 |
| 12 | | .3147 |
| 13 | | .3102 |
| 14 | | .3178 |
| 15 | | .3224 |
| 16 | | .3155 |
| 17 | | .3025 |
| 18 | | .2888 |
| 20 | .0061 | .0015 |
| Max | .2964 | .3224 |
| Min | .0015 | .0015 |
| Avg | .1558 | .2597 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154036 / 33/11 KV Pangaon S/S

Feeder No / Name : 202 / 11 Kv Bhandarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .2286 |
| 2 | .3048 |
| 3 | .3048 |
| 4 | .3048 |
| 5 | .381 |
| 6 | .4572 |
| 7 | .6097 |
| 8 | .6859 |
| 9 | .6859 |
| 16 | .2286 |
| 17 | .2286 |
| 18 | .2286 |
| 19 | .381 |
| 20 | .4572 |
| 21 | .3048 |
| 22 | .2286 |
| 23 | .2286 |
| 24 | .2286 |
| Max | .6859 |
| Min | .2286 |
| Avg | .3599 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154036 / 33/11 KV Pangaon S/S

Feeder No / Name : 203 / 11 Kv Muslewadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .5792 | .5243 |
| 2 | .6508 | .5853 |
| 3 | .7484 | .6158 |
| 4 | .8169 | .7057 |
| 5 | | .8368 |
| 6 | | 1.0684 |
| 7 | | 1.4922 |
| 8 | | 1.5455 |
| 9 | | 1.4098 |
| 10 | .7895 | |
| 11 | 1.3062 | |
| 12 | 1.3382 | |
| 13 | 1.4373 | |
| 14 | 1.4281 | |
| 15 | 1.4403 | .2683 |
| 16 | 1.4373 | .3064 |
| 17 | 1.39 | .4176 |
| 18 | 1.1584 | .6432 |
| 19 | .9709 | .9755 |
| 20 | .98 | .9297 |
| 21 | .8291 | .7651 |
| 22 | .7285 | .6356 |
| 23 | .6036 | .5517 |
| 24 | .538 | .5456 |
| Max | 1.4403 | 1.5455 |
| Min | .538 | .2683 |
| Avg | 1.0090 | .7801 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 201 / 11 Kv Poharegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .3048 |
| 2 | .381 |
| 3 | .381 |
| 4 | .381 |
| 5 | .381 |
| 6 | .4572 |
| 7 | .6097 |
| 8 | .6859 |
| 9 | .6859 |
| 10 | .0762 |
| 16 | .3048 |
| 17 | .381 |
| 18 | .381 |
| 19 | .4572 |
| 20 | .5335 |
| 21 | .4572 |
| 22 | .4572 |
| 23 | .381 |
| 24 | .381 |
| Max | .6859 |
| Min | .0762 |
| Avg | .4251 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 202 / 11 Kv Shera SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .2286 |
| 2 | .1524 |
| 3 | .1524 |
| 4 | .1524 |
| 5 | .2286 |
| 6 | .2286 |
| 7 | .381 |
| 8 | .4572 |
| 9 | .4572 |
| 10 | .1524 |
| 17 | .0762 |
| 18 | .1524 |
| 19 | .3048 |
| 20 | .381 |
| 21 | .3048 |
| 22 | .2286 |
| 23 | .2286 |
| 24 | .2286 |
| Max | .4572 |
| Min | .0762 |
| Avg | .2498 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN

Feeder No / Name : 201 / 11kv Khalangri SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4344 | .2881 |
| 2 | .4771 | .2987 |
| 3 | .4832 | .3628 |
| 4 | .5091 | .3704 |
| 5 | .5182 | |
| 6 | .5822 | |
| 7 | .5761 | |
| 8 | .567 | |
| 9 | .5487 | |
| 10 | | .4954 |
| 11 | | .5106 |
| 12 | | .5167 |
| 13 | | .5502 |
| 14 | | .2134 |
| 15 | .0046 | .474 |
| 16 | | .4557 |
| 17 | | .4603 |
| 18 | .1814 | .4603 |
| 19 | .3597 | .378 |
| 20 | .3292 | .3856 |
| 21 | .3429 | .3628 |
| 22 | .3094 | .3307 |
| 23 | .3048 | .3216 |
| 24 | .2911 | .2576 |
| Max | .5822 | .5502 |
| Min | .0046 | .2134 |
| Avg | .4011 | .3944 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN

Feeder No / Name : 202 / 11 Kv Koshtagaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4313 | 1.0532 |
| 2 | .4527 | 1.1751 |
| 3 | .4847 | 1.2559 |
| 4 | .4862 | 1.2605 |
| 5 | .4359 | 1.39 |
| 6 | | 1.6537 |
| 7 | | 2.0287 |
| 8 | | 2.146 |
| 9 | | 1.2407 |
| 10 | 1.2681 | |
| 11 | 1.6293 | |
| 12 | 1.8732 | |
| 13 | 1.9235 | |
| 14 | 1.9585 | |
| 15 | 1.7421 | .2683 |
| 16 | 1.7894 | .3262 |
| 17 | 1.8458 | .3658 |
| 18 | .7148 | .3719 |
| 19 | .8322 | .7712 |
| 20 | .6081 | .7407 |
| 21 | .5655 | .5898 |
| 22 | .5563 | .506 |
| 23 | .4572 | .4268 |
| 24 | .4115 | .2728 |
| Max | 1.9585 | 2.146 |
| Min | .4115 | .2683 |
| Avg | 1.0233 | .9391 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN

Feeder No / Name : 203 / 11 Kv Ghodala SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3277 | .3094 |
| 2 | .3414 | .3208 |
| 3 | .3475 | .3483 |
| 4 | .3833 | .3803 |
| 5 | .4161 | |
| 6 | .5723 | |
| 7 | .6889 | |
| 8 | .5091 | |
| 9 | .5083 | |
| 10 | | .4108 |
| 11 | | .5571 |
| 12 | | .5228 |
| 13 | | .4839 |
| 14 | | .2888 |
| 15 | .1379 | .3582 |
| 16 | .269 | .3833 |
| 17 | .2378 | .4108 |
| 18 | .2675 | .4595 |
| 19 | .5617 | .6112 |
| 20 | .6196 | .6302 |
| 21 | .5609 | .5075 |
| 22 | .4694 | .4649 |
| 23 | .3704 | .3925 |
| 24 | .3353 | .3788 |
| Max | .6889 | .6302 |
| Min | .1379 | .2888 |
| Avg | .4171 | .4326 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN

Feeder No / Name : 204 / 11KV W/W

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 7 | .0488 | |
| 8 | .048 | |
| 9 | .048 | |
| 10 | .0484 | |
| 11 | .0476 | .0556 |
| 12 | .0126 | .0549 |
| 13 | | .0549 |
| 14 | | .0495 |
| 15 | | .0472 |
| 16 | | .0476 |
| 17 | | .0476 |
| 18 | | .0476 |
| 23 | | .0004 |
| Max | .0488 | .0556 |
| Min | .0126 | .0004 |
| Avg | .0422 | .0450 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154049 / 33/11 KV KHALAGRI S/STN

Feeder No / Name : 205 / 11 KV Karepur SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7072 | .6318 |
| 2 | .7354 | .7194 |
| 3 | .7712 | .7827 |
| 4 | | .8391 |
| 5 | | .9488 |
| 6 | | 1.0418 |
| 7 | | 1.0707 |
| 8 | | 1.1119 |
| 9 | | 1.1065 |
| 10 | .4793 | |
| 11 | .9938 | |
| 12 | 1.0905 | |
| 13 | .9366 | |
| 14 | .8467 | |
| 15 | .9572 | .2728 |
| 16 | 1.0197 | .5708 |
| 17 | .932 | .7133 |
| 18 | .5281 | .7377 |
| 19 | .823 | .9137 |
| 20 | 1.0357 | .9838 |
| 21 | .9465 | .8703 |
| 22 | .8406 | .7842 |
| 23 | .6341 | .6158 |
| 24 | .6173 | .5883 |
| Max | 1.0905 | 1.1119 |
| Min | .4793 | .2728 |
| Avg | .8275 | .8054 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 201 / 11 Kv Sindhgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3955 | .474 |
| 2 | .3056 | .4893 |
| 3 | .3086 | .5891 |
| 4 | .3125 | .6501 |
| 5 | .3948 | |
| 6 | .5449 | |
| 7 | .8451 | |
| 8 | .9389 | |
| 9 | .9267 | |
| 10 | | .2705 |
| 11 | | .7141 |
| 12 | | .7705 |
| 13 | | .7964 |
| 14 | | .7994 |
| 15 | .1669 | .583 |
| 16 | .3643 | .4877 |
| 17 | .3696 | .4458 |
| 18 | .4397 | .5632 |
| 19 | .8055 | .852 |
| 20 | .8711 | .865 |
| 21 | .6897 | .6615 |
| 22 | .631 | .6043 |
| 23 | .5304 | .5167 |
| 24 | .4664 | .4512 |
| Max | .9389 | .865 |
| Min | .1669 | .2705 |
| Avg | .5425 | .6097 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154057 / 33/11 KV PALSI S/S

Feeder No / Name : 203 / 11 Kv Garsoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2172 | .253 |
| 2 | .1989 | .2789 |
| 3 | .2027 | .3193 |
| 4 | .2157 | .3528 |
| 5 | .2896 | |
| 6 | .4169 | |
| 7 | .5289 | |
| 8 | .4969 | |
| 9 | .4283 | |
| 10 | | .1448 |
| 11 | | .4153 |
| 12 | | .4001 |
| 13 | | .3704 |
| 14 | | .3711 |
| 15 | .0069 | .0465 |
| 16 | .1684 | .2644 |
| 17 | .2187 | .3041 |
| 18 | .3338 | .33 |
| 19 | .4435 | .5075 |
| 20 | .4489 | .4816 |
| 21 | .4245 | .4306 |
| 22 | .3681 | .3544 |
| 23 | .317 | .2812 |
| 24 | .2545 | .2515 |
| Max | .5289 | .5075 |
| Min | .0069 | .0465 |
| Avg | .3147 | .3241 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154057 / 33/11 KV PALSI S/S

Feeder No / Name : 204 / 11KV Aashirwad Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 7 | .0335 | |
| 9 | .0545 | .0503 |
| 10 | .0613 | .0697 |
| 11 | .0412 | |
| 12 | .0431 | |
| 13 | .0453 | |
| 14 | .0137 | |
| Max | .0613 | .0697 |
| Min | .0137 | .0503 |
| Avg | .0418 | .06 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154057 / 33/11 KV PALSI S/S

Feeder No / Name : 205 / Shririshna Avdoot Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1044 | .0758 |
| 2 | .1059 | .0819 |
| 3 | .1059 | .0785 |
| 4 | .1017 | .0785 |
| 5 | .0949 | .0793 |
| 6 | .0975 | .0823 |
| 7 | .0937 | .0846 |
| 8 | .0945 | .0899 |
| 9 | .1002 | .0869 |
| 10 | .1021 | .0907 |
| 11 | .101 | .0857 |
| 12 | .1067 | .0876 |
| 13 | .1097 | .0907 |
| 14 | .1055 | .1029 |
| 15 | .1067 | .0137 |
| 16 | .1044 | .0968 |
| 17 | .1071 | .0926 |
| 18 | .1021 | .0945 |
| 19 | .0964 | .0903 |
| 20 | .0884 | .0914 |
| 21 | .0914 | .0861 |
| 22 | .0834 | .0876 |
| 23 | .0728 | .0846 |
| 24 | .0659 | .0812 |
| Max | .1097 | .1029 |
| Min | .0659 | .0137 |
| Avg | .0976 | .0839 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 201 / 11 Kv Kharola SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .8124 | .6767 |
| 2 | .8589 | .6874 |
| 3 | 1.0143 | .7293 |
| 4 | .3094 | .7674 |
| 5 | | .9069 |
| 6 | | 1.0433 |
| 7 | | 1.0936 |
| 8 | | 1.1942 |
| 9 | | .3155 |
| 10 | .9366 | |
| 11 | 1.0159 | |
| 12 | 1.1111 | |
| 13 | .0274 | |
| 14 | 1.0997 | |
| 15 | 1.1058 | .6668 |
| 16 | 1.1462 | .6821 |
| 17 | 1.0227 | .7484 |
| 18 | .7971 | .9412 |
| 19 | 1.1363 | 1.0296 |
| 20 | 1.105 | 1.0273 |
| 21 | 1.0227 | .9313 |
| 22 | .8802 | .8429 |
| 23 | .8025 | .7804 |
| 24 | .7735 | .7354 |
| Max | 1.1462 | 1.1942 |
| Min | .0274 | .3155 |
| Avg | .8936 | .8316 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 202 / 11 Kv Kumbharwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2469 | .2096 |
| 2 | .2538 | .3178 |
| 3 | .2987 | .3254 |
| 4 | .3452 | .3589 |
| 5 | | .4009 |
| 6 | | .4847 |
| 7 | | .618 |
| 8 | | .6409 |
| 9 | | .5426 |
| 11 | .5106 | |
| 12 | .5754 | |
| 13 | .5639 | |
| 14 | .487 | |
| 15 | .5952 | .0297 |
| 16 | .6661 | .1334 |
| 17 | .6241 | .1555 |
| 18 | .2911 | .1722 |
| 19 | .2713 | .4191 |
| 20 | .4047 | .4016 |
| 21 | .3757 | .3399 |
| 22 | .3323 | .2675 |
| 23 | .2401 | .2241 |
| 24 | .2241 | .2172 |
| Max | .6661 | .6409 |
| Min | .2241 | .0297 |
| Avg | .4059 | .3294 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 203 / 11 Kv Selu (J)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3986 | .4588 |
| 2 | .3178 | .4908 |
| 3 | .33 | .5441 |
| 4 | .3285 | .567 |
| 5 | .3871 | |
| 6 | .4854 | |
| 7 | .5373 | |
| 8 | .583 | |
| 9 | .5228 | |
| 10 | | .0815 |
| 11 | | .5571 |
| 12 | | .5312 |
| 13 | | .5662 |
| 14 | | .6081 |
| 15 | .0732 | .4191 |
| 16 | .3048 | .3246 |
| 17 | .2713 | .3696 |
| 18 | .2949 | .3597 |
| 19 | .5091 | .4954 |
| 20 | .5967 | .5891 |
| 21 | .5822 | .5594 |
| 22 | .5296 | .5182 |
| 23 | .5022 | .4534 |
| 24 | .4298 | .4077 |
| Max | .5967 | .6081 |
| Min | .0732 | .0815 |
| Avg | .4202 | .4685 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 205 / Faradpur SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2042 | .25 |
| 2 | .1692 | .2804 |
| 3 | .1738 | .3368 |
| 4 | .1951 | .3475 |
| 5 | .2378 | |
| 6 | .2835 | |
| 7 | .3437 | |
| 8 | .3643 | |
| 9 | .346 | |
| 10 | | .0831 |
| 11 | | .3117 |
| 12 | | .3727 |
| 13 | | .4001 |
| 14 | | .3582 |
| 15 | .0107 | .2545 |
| 16 | .0152 | .1768 |
| 17 | .077 | .1981 |
| 18 | .1151 | .2431 |
| 19 | .2012 | .378 |
| 20 | .3818 | .362 |
| 21 | .3323 | .3109 |
| 22 | .285 | .2553 |
| 23 | .2515 | .2286 |
| 24 | .2294 | .2218 |
| Max | .3818 | .4001 |
| Min | .0107 | .0831 |
| Avg | .2219 | .2826 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 206 / Wala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4664 | .4405 |
| 2 | .57 | .5571 |
| 3 | .676 | .5799 |
| 4 | .7232 | .5876 |
| 5 | | .7011 |
| 6 | | .791 |
| 7 | | 1.057 |
| 8 | | 1.1126 |
| 9 | | 1.038 |
| 10 | .237 | |
| 11 | .6904 | |
| 12 | .4214 | |
| 13 | .8177 | |
| 14 | .8147 | |
| 15 | .7705 | .0846 |
| 16 | .8642 | .3163 |
| 17 | .8916 | .285 |
| 18 | .8688 | .4405 |
| 19 | .6562 | .7842 |
| 20 | .7811 | .7773 |
| 21 | .6851 | .6607 |
| 22 | .5883 | .5258 |
| 23 | .4733 | .4374 |
| 24 | .4291 | .4115 |
| Max | .8916 | 1.1126 |
| Min | .237 | .0846 |
| Avg | .6539 | .6099 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 201 / 11 KV DARJI BORGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2401 | .2141 |
| 2 | .2652 | .1158 |
| 3 | .3018 | .1219 |
| 4 | .3338 | .1257 |
| 5 | .061 | .1456 |
| 6 | | .1829 |
| 7 | | .2462 |
| 8 | | .2629 |
| 9 | | .2538 |
| 10 | | .048 |
| 11 | .2164 | |
| 12 | .1951 | |
| 13 | .2362 | |
| 14 | .2301 | |
| 15 | .221 | |
| 16 | .2172 | .1745 |
| 17 | .2141 | .1593 |
| 18 | .2271 | .1852 |
| 19 | .2408 | .2705 |
| 20 | .3056 | .33 |
| 21 | .2683 | .2736 |
| 22 | .2614 | .2599 |
| 23 | .2324 | .2515 |
| 24 | .2172 | .2187 |
| Max | .3338 | .33 |
| Min | .061 | .048 |
| Avg | .2360 | .2021 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 203 / 11 KV INDARTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3178 | .3803 |
| 2 | .1417 | .4191 |
| 3 | .1448 | .5022 |
| 4 | .1562 | .5083 |
| 5 | .2225 | |
| 6 | .3246 | |
| 7 | .3772 | |
| 8 | .3894 | |
| 9 | .3757 | |
| 10 | | .1341 |
| 11 | | .3467 |
| 12 | | .3018 |
| 13 | | .2751 |
| 14 | | .2439 |
| 15 | .1273 | .2355 |
| 16 | .269 | .2233 |
| 17 | .2629 | .234 |
| 18 | .378 | .2972 |
| 19 | .583 | .4809 |
| 20 | .5159 | .4969 |
| 21 | .4915 | .4725 |
| 22 | .4565 | .4329 |
| 23 | .3643 | .3948 |
| 24 | .3765 | .3643 |
| Max | .583 | .5083 |
| Min | .1273 | .1341 |
| Avg | .3303 | .3549 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 204 / 11kv Borphal AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | | .2317 |
| 2 | | .3224 |
| 3 | | .3246 |
| 4 | | .3559 |
| 5 | | .346 |
| 6 | | .3833 |
| 7 | | .6417 |
| 8 | | .8269 |
| 9 | | .8284 |
| 10 | .0046 | |
| 11 | .4085 | |
| 12 | .6356 | |
| 13 | .7971 | |
| 14 | .8512 | |
| 15 | .8985 | |
| 16 | 1.0204 | |
| 17 | 1.0159 | |
| 18 | .9435 | |
| 19 | .0015 | |
| 24 | | .0023 |
| Max | 1.0204 | .8284 |
| Min | .0015 | .0023 |
| Avg | .6577 | .4263 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV Ausa

Feeder No / Name : 206 / 11kv Old midc of 33KV Ausa SHEDDABLE FEEDER HAVING WEEKLY
sub Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | *** |
| 2 | *** |
| 3 | *** |
| 4 | *** |
| 5 | *** |
| 6 | *** |
| 7 | *** |
| 8 | *** |
| 9 | *** |
| Max | 114.312 |
| Min | 76.208 |
| Avg | 84.6756 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 207 / 11kv Karajgaon gaathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1707 | .1707 |
| 2 | .173 | .173 |
| 3 | .1715 | .1715 |
| 4 | .2157 | .2157 |
| 5 | .2362 | .2362 |
| 6 | .2934 | .2934 |
| 7 | .2568 | .2568 |
| 8 | .0274 | .0274 |
| 10 | .0343 | .0343 |
| 11 | .1128 | .1128 |
| 12 | .112 | .112 |
| 13 | .1082 | .1082 |
| 14 | .0854 | .0854 |
| 15 | .0907 | .0907 |
| 16 | .0739 | .0739 |
| 17 | .0625 | .0625 |
| 18 | .1036 | .1036 |
| 19 | .202 | .202 |
| 20 | .2385 | .2385 |
| 21 | .2431 | .2431 |
| 22 | .218 | .218 |
| 23 | .189 | .189 |
| 24 | .1661 | .1661 |
| Max | .2934 | .2934 |
| Min | .0274 | .0274 |
| Avg | .1559 | .1559 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 201 / 11KV Bhada Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .378 | .4291 |
| 2 | .3216 | .4306 |
| 3 | .1555 | .4572 |
| 4 | .1677 | .4862 |
| 5 | .1799 | |
| 6 | .2446 | |
| 7 | .3102 | |
| 8 | .5556 | |
| 9 | .6379 | |
| 10 | | .0137 |
| 11 | | .5335 |
| 12 | | .2111 |
| 13 | | .8474 |
| 14 | | .961 |
| 15 | | .9922 |
| 16 | .2149 | .9374 |
| 17 | .1776 | .9358 |
| 18 | .2949 | .5761 |
| 19 | .4306 | .5479 |
| 20 | .6036 | .5921 |
| 21 | .5937 | .5228 |
| 22 | .5114 | .5075 |
| 23 | .4321 | .4611 |
| 24 | .4336 | .4153 |
| Max | .6379 | .9922 |
| Min | .1555 | .0137 |
| Avg | .3691 | .5715 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 203 / 11 kv Karkhana Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2736 | .2439 |
| 2 | .365 | .2042 |
| 3 | .3841 | .2202 |
| 4 | .3944 | .2324 |
| 5 | .4508 | |
| 6 | .4923 | |
| 7 | .7434 | |
| 8 | .8009 | |
| 9 | .7205 | |
| 10 | .3056 | .2683 |
| 11 | | .4424 |
| 12 | | .5559 |
| 13 | | .8208 |
| 14 | | .9054 |
| 15 | | .9076 |
| 16 | .0724 | .7564 |
| 17 | .1673 | .7442 |
| 18 | .2382 | .6824 |
| 19 | .3544 | .3528 |
| 20 | .357 | .349 |
| 21 | .3227 | .3414 |
| 22 | .2972 | .3406 |
| 23 | .2751 | .2995 |
| 24 | .2561 | .2877 |
| Max | .8009 | .9076 |
| Min | .0724 | .2042 |
| Avg | .3827 | .4713 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 204 / Gukheda Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4839 | .4992 |
| 2 | .7171 | .5289 |
| 3 | .7743 | .5647 |
| 4 | .7987 | .6036 |
| 5 | .9015 | |
| 6 | 1.0372 | |
| 7 | 1.5188 | |
| 8 | 1.6895 | |
| 9 | 1.6583 | |
| 10 | .6158 | |
| 11 | | 1.1767 |
| 12 | | .6943 |
| 13 | | 1.3016 |
| 14 | | 1.7238 |
| 15 | | 1.5668 |
| 16 | | 1.4449 |
| 17 | .0282 | 1.4053 |
| 18 | .2987 | 1.3161 |
| 19 | .7362 | .7263 |
| 20 | .8512 | .7087 |
| 21 | .7324 | .6401 |
| 22 | .5998 | .6059 |
| 23 | .5693 | .5571 |
| 24 | .5411 | .5251 |
| Max | 1.6895 | 1.7238 |
| Min | .0282 | .4992 |
| Avg | .8084 | .9216 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 205 / Malumbra Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .5853 | .5777 |
| 2 | .5746 | .9709 |
| 3 | .6165 | .9915 |
| 4 | .7354 | 1.0059 |
| 5 | .4816 | 1.0806 |
| 6 | | 1.1797 |
| 7 | | 1.5104 |
| 8 | | 1.7764 |
| 9 | | 1.5097 |
| 10 | | 1.5615 |
| 11 | .5571 | .1334 |
| 12 | 1.7322 | |
| 13 | 2.0858 | |
| 14 | 2.1643 | |
| 15 | 2.1369 | |
| 16 | 1.4098 | |
| 17 | 1.8115 | .4146 |
| 18 | 1.8252 | .615 |
| 19 | .6203 | .7042 |
| 20 | .8916 | .9259 |
| 21 | .9396 | .8406 |
| 22 | .7834 | .7225 |
| 23 | .6607 | .6241 |
| 24 | .5906 | .5609 |
| Max | 2.1643 | 1.7764 |
| Min | .4816 | .1334 |
| Avg | 1.1159 | .9319 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 201 / 11 KV Jawalga Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .4572 |
| 2 | .4572 |
| 3 | .5335 |
| 4 | .5335 |
| 10 | .0762 |
| 11 | 1.5242 |
| 12 | 1.6766 |
| 13 | 2.0576 |
| 14 | 2.1338 |
| 15 | 1.9052 |
| 16 | 1.2193 |
| 17 | 1.0669 |
| 18 | .9907 |
| 19 | .6097 |
| 20 | .6859 |
| 21 | .6859 |
| 22 | .5335 |
| 23 | .4572 |
| 24 | .381 |
| Max | 2.1338 |
| Min | .0762 |
| Avg | .9466 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 203 / 11 KV Haregaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .0347 | .061 |
| 2 | .0438 | .1368 |
| 3 | .0602 | .1494 |
| 4 | .0686 | .1718 |
| 5 | | .2096 |
| 6 | | .2564 |
| 7 | | .4317 |
| 8 | | .4169 |
| 9 | | .3799 |
| 13 | .1497 | |
| 14 | .3567 | |
| 15 | .3708 | |
| 16 | .3871 | |
| 17 | .3929 | .0918 |
| 18 | .3967 | .1353 |
| 19 | .2149 | .1875 |
| 20 | .2622 | .1806 |
| 21 | .1456 | .104 |
| 22 | .1071 | .085 |
| 23 | .0789 | .0827 |
| 24 | .0625 | .0636 |
| Max | .3967 | .4317 |
| Min | .0347 | .061 |
| Avg | .1958 | .1849 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 201 / 11 KV Pethe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .0762 | .0762 |
| 2 | .0762 | .0762 |
| 3 | .0762 | .0762 |
| 4 | .0762 | .0762 |
| 5 | .0762 | .0762 |
| 6 | .0762 | .0762 |
| 7 | .0762 | .0762 |
| 8 | .0762 | .0762 |
| 9 | .0762 | .0762 |
| 10 | .1524 | .1524 |
| 11 | .2286 | .1524 |
| 12 | .1524 | .1524 |
| 13 | .1524 | .2286 |
| 14 | .1524 | .1524 |
| 15 | .1524 | .1524 |
| 16 | .1524 | .1524 |
| 17 | .1524 | .2286 |
| 18 | .1524 | .1524 |
| 19 | .1524 | .0762 |
| 20 | .0762 | .0762 |
| 21 | .0762 | .0762 |
| 22 | .0762 | .0762 |
| 23 | .0762 | .0762 |
| 24 | .0762 | .0762 |
| Max | .2286 | .2286 |
| Min | .0762 | .0762 |
| Avg | .1111 | .1111 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 202 / 11kv Selu SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2286 | .2286 |
| 2 | .2286 | .2286 |
| 3 | .3048 | .2286 |
| 4 | .3048 | .2286 |
| 5 | .3048 | .2286 |
| 6 | | .3048 |
| 7 | | .5335 |
| 8 | | .5335 |
| 9 | | .6097 |
| 11 | .5335 | |
| 12 | .6097 | |
| 13 | .7621 | |
| 14 | .6859 | |
| 15 | .6859 | |
| 16 | .6859 | |
| 17 | .7621 | .1524 |
| 18 | .6097 | .2286 |
| 19 | .3048 | .3048 |
| 20 | .3048 | .3048 |
| 21 | .381 | .3048 |
| 22 | .3048 | .3048 |
| 23 | .3048 | .2286 |
| 24 | .2286 | .2286 |
| Max | .7621 | .6097 |
| Min | .2286 | .1524 |
| Avg | .4492 | .3048 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 203 / 11kv Almala

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .0762 |
| 2 | .0762 |
| 4 | .0762 |
| 11 | .6859 |
| 12 | .9907 |
| 13 | 1.0669 |
| 14 | 1.2193 |
| 15 | 1.1431 |
| 16 | 1.0669 |
| 17 | .9145 |
| 18 | .4572 |
| 19 | .2286 |
| 20 | .0762 |
| 21 | .0762 |
| 22 | .0762 |
| 23 | .0762 |
| 24 | .0762 |
| Max | 1.2193 |
| Min | .0762 |
| Avg | .4931 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 201 / 11KV Tungi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4085 | .4458 |
| 2 | .4275 | .4572 |
| 3 | .4954 | .487 |
| 4 | .5716 | |
| 5 | .4382 | |
| 13 | | .269 |
| 14 | | .2622 |
| 15 | 1.624 | .2804 |
| 16 | 2.0736 | .2797 |
| 17 | 1.3908 | .4976 |
| 18 | | 1.1568 |
| 19 | .5053 | 1.3016 |
| 20 | .8307 | .9976 |
| 21 | .7011 | .9556 |
| 22 | .6417 | .9686 |
| 23 | .538 | .9328 |
| 24 | .4649 | .8962 |
| Max | 2.0736 | 1.3016 |
| Min | .4085 | .2622 |
| Avg | .7937 | .6792 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 201 / 11 KV Andhora feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .7385 |
| 2 | .7407 |
| 3 | .7667 |
| 4 | .8169 |
| 10 | 1.1629 |
| 11 | 1.7497 |
| 12 | 1.9464 |
| 13 | 2.0233 |
| 14 | 1.8968 |
| 15 | 1.8153 |
| 16 | 1.6537 |
| 17 | .9549 |
| 18 | .8848 |
| 19 | .8383 |
| 20 | .692 |
| 21 | .57 |
| 22 | .5533 |
| 23 | .5053 |
| 24 | .5007 |
| Max | 2.0233 |
| Min | .5007 |
| Avg | 1.0953 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 202 / 11KV Jaifal Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .5144 | .4755 |
| 2 | .9739 | .4176 |
| 3 | 1.0867 | .4298 |
| 4 | 1.0143 | .4397 |
| 5 | 1.1134 | .1471 |
| 6 | 1.2902 | |
| 7 | 1.8046 | |
| 8 | 1.9395 | |
| 9 | .4245 | 1.6735 |
| 10 | | 1.9151 |
| 11 | | 2.0774 |
| 12 | | 2.1247 |
| 13 | | 1.922 |
| 14 | | 2.1536 |
| 15 | .1799 | 2.2024 |
| 16 | .2058 | 2.1483 |
| 17 | .2256 | .2804 |
| 18 | .2743 | |
| 19 | .4999 | .5639 |
| 20 | .5548 | .5388 |
| 21 | .5274 | .5335 |
| 22 | .503 | .5327 |
| 23 | .4938 | .5152 |
| 24 | .4954 | .5098 |
| Max | 1.9395 | 2.2024 |
| Min | .1799 | .1471 |
| Avg | .7432 | 1.0801 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA/Gondri

Feeder No / Name : 202 / 11KV Dhanora SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7697 | .6341 |
| 2 | .9831 | .6531 |
| 3 | 1.0486 | .7354 |
| 4 | 1.0669 | .7735 |
| 5 | 1.166 | .2355 |
| 6 | 1.4281 | |
| 7 | 1.7848 | |
| 8 | 1.9204 | |
| 9 | 1.8961 | |
| 10 | | .8009 |
| 11 | | 1.9662 |
| 12 | | 2.1887 |
| 13 | | .5258 |
| 14 | | 1.4784 |
| 15 | | .9899 |
| 16 | .1936 | 1.4213 |
| 17 | .3361 | .5411 |
| 18 | .4306 | 1.3794 |
| 19 | 1.0166 | .7293 |
| 20 | .7712 | .7255 |
| 21 | .6843 | .7247 |
| 22 | .6584 | .7019 |
| 23 | .631 | .6401 |
| 24 | .6089 | .6333 |
| Max | 1.9204 | 2.1887 |
| Min | .1936 | .2355 |
| Avg | .9664 | .9239 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 201 / 11 KV NEW MIDC FEEDER.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1814 | .2431 |
| 2 | .1837 | .2507 |
| 3 | .1837 | .2462 |
| 4 | .1844 | .25 |
| 5 | .1837 | .2469 |
| 6 | .1943 | .2591 |
| 7 | .2027 | .2576 |
| 8 | .1997 | .2484 |
| 9 | .2743 | .2675 |
| 10 | .3536 | .3117 |
| 11 | .3749 | .3292 |
| 12 | .3506 | .3399 |
| 13 | .3536 | .3452 |
| 14 | .3201 | .3406 |
| 15 | .3147 | .3437 |
| 16 | .3277 | .3544 |
| 17 | .3239 | .3772 |
| 18 | .3117 | .362 |
| 19 | .2599 | .3521 |
| 20 | .2591 | .314 |
| 21 | .2378 | .2484 |
| 22 | .2507 | .237 |
| 23 | .2484 | .2378 |
| 24 | .2393 | .2324 |
| Max | .3749 | .3772 |
| Min | .1814 | .2324 |
| Avg | .2631 | .2915 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 202 / 11 KV CHOWRASTA FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7407 | .7735 |
| 2 | .7034 | .7461 |
| 3 | .6981 | .7346 |
| 4 | .7255 | .7446 |
| 5 | .807 | .8078 |
| 6 | .8337 | .8817 |
| 7 | .8025 | .9145 |
| 8 | .8657 | .9092 |
| 9 | .8337 | .8825 |
| 10 | .8901 | .8391 |
| 11 | .8985 | .868 |
| 12 | .8863 | .7842 |
| 13 | .8688 | .7941 |
| 14 | .8657 | .7659 |
| 15 | .8109 | .7278 |
| 16 | .8413 | .7301 |
| 17 | .8551 | .8619 |
| 18 | .9092 | .948 |
| 19 | 1.0943 | 1.0395 |
| 20 | 1.0776 | .9998 |
| 21 | 1.0288 | .9793 |
| 22 | .9823 | .9244 |
| 23 | .9008 | .881 |
| 24 | .8147 | .7865 |
| Max | 1.0943 | 1.0395 |
| Min | .6981 | .7278 |
| Avg | .8639 | .8468 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 203 / 11 KV SAMTA NAGER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .8802 | .881 |
| 2 | .8314 | .8558 |
| 3 | .8276 | .8474 |
| 4 | .8398 | .8459 |
| 5 | .8893 | .9198 |
| 6 | 1.0006 | 1.0593 |
| 7 | 1.0814 | 1.1827 |
| 8 | 1.0707 | 1.1523 |
| 9 | 1.0654 | 1.0174 |
| 10 | 1.0235 | 1.0631 |
| 11 | 1.0067 | 1.0471 |
| 12 | .9785 | .9473 |
| 13 | .9724 | .9374 |
| 14 | .9861 | .9427 |
| 15 | .9656 | .9038 |
| 16 | .9175 | .852 |
| 17 | .8947 | .9214 |
| 18 | 1.0372 | 1.0654 |
| 19 | 1.2727 | 1.2559 |
| 20 | 1.2971 | 1.262 |
| 21 | 1.2475 | 1.1683 |
| 22 | 1.1553 | 1.0936 |
| 23 | 1.0258 | .9938 |
| 24 | .9267 | .9038 |
| Max | 1.2971 | 1.262 |
| Min | .8276 | .8459 |
| Avg | 1.0081 | 1.0050 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 202 / 11 kv Yelawat AG feeder

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 2 | .1379 | |
| 3 | .1837 | |
| 4 | .1959 | |
| 5 | .2126 | |
| 6 | .2492 | |
| 7 | .4291 | |
| 8 | .5098 | |
| 9 | .5121 | |
| 10 | | .1105 |
| 11 | | .1456 |
| 12 | | .4931 |
| 13 | | .6607 |
| 14 | | .6622 |
| 15 | | .6744 |
| 16 | | .2301 |
| Max | .5121 | .6744 |
| Min | .1379 | .1105 |
| Avg | .3038 | .4252 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 203 / 11 kv Old Killari Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .5213 | .8787 |
| 2 | .5266 | .868 |
| 3 | .5335 | .8741 |
| 4 | .5914 | .4321 |
| 5 | .6661 | .4283 |
| 6 | .8086 | .4466 |
| 7 | .8878 | .5129 |
| 8 | .3605 | .9236 |
| 9 | | .9625 |
| 10 | | .9777 |
| 11 | | .9701 |
| 12 | | 1.0349 |
| 13 | | 1.0174 |
| 14 | .1837 | .9823 |
| 15 | .1821 | .9488 |
| 16 | .8833 | |
| 17 | .7895 | .1989 |
| 18 | 1.0875 | .5838 |
| 19 | 1.1706 | .6348 |
| 20 | 1.118 | .5731 |
| 21 | 1.0448 | .5136 |
| 22 | .9617 | .4611 |
| 23 | .9526 | .4191 |
| 24 | .9236 | .7552 |
| Max | 1.1706 | 1.0349 |
| Min | .1821 | .1989 |
| Avg | .7470 | .7129 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 203 / 11 KV Kharosa Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3643 | .3208 |
| 2 | .3361 | .2888 |
| 3 | .3551 | .2934 |
| 4 | .3628 | .3285 |
| 5 | | .4016 |
| 6 | | .4412 |
| 7 | | .5335 |
| 8 | | .708 |
| 9 | | .6683 |
| 10 | .1059 | |
| 11 | .3102 | |
| 12 | .4001 | |
| 13 | .4313 | |
| 14 | .4877 | |
| 15 | .5449 | |
| 16 | .4915 | |
| 17 | .5357 | .2317 |
| 18 | .5319 | .3628 |
| 19 | .4306 | .4862 |
| 20 | .4915 | .474 |
| 21 | .4702 | .4009 |
| 22 | .3711 | .3749 |
| 23 | .3513 | .3612 |
| 24 | .3391 | .3353 |
| Max | .5449 | .708 |
| Min | .1059 | .2317 |
| Avg | .4059 | .4124 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 201 / 11 KV Limbala Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .2286 |
| 2 | .2286 |
| 3 | .2286 |
| 4 | .2286 |
| 5 | .3048 |
| 6 | .381 |
| 7 | .4572 |
| 8 | .7621 |
| 9 | .7621 |
| 19 | .381 |
| 20 | .4572 |
| 21 | .381 |
| 22 | .3048 |
| 23 | .2286 |
| 24 | .2286 |
| Max | .7621 |
| Min | .2286 |
| Avg | .3709 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 202 / 11 KV Mangrool SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .692 | .4748 |
| 2 | .6935 | .5197 |
| 3 | .7019 | .6424 |
| 4 | .7392 | .7354 |
| 5 | .8429 | |
| 6 | .9968 | |
| 7 | 1.2818 | |
| 8 | 1.3847 | |
| 9 | 1.3481 | |
| 10 | .0069 | .0114 |
| 11 | | 1.1507 |
| 12 | | 1.3093 |
| 13 | | .804 |
| 14 | | .8284 |
| 15 | | 1.3344 |
| 16 | | 1.4091 |
| 17 | | .6158 |
| 18 | | .6965 |
| 19 | .8558 | .791 |
| 20 | .9534 | .9236 |
| 21 | .9656 | .8604 |
| 22 | .8063 | .7171 |
| 23 | .6554 | .5251 |
| 24 | .4954 | .4748 |
| Max | 1.3847 | 1.4091 |
| Min | .0069 | .0114 |
| Avg | .8387 | .7802 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 201 / 11 KV Karla SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2492 | .2324 |
| 2 | .237 | .2233 |
| 3 | .2568 | .2233 |
| 4 | .0663 | .2294 |
| 5 | | .2766 |
| 6 | | .3147 |
| 7 | | .3125 |
| 8 | .2599 | .208 |
| 9 | .5045 | .205 |
| 10 | .5175 | .1692 |
| 11 | .4694 | |
| 12 | .5121 | |
| 13 | .5594 | |
| 14 | .4778 | |
| 15 | .4786 | |
| 16 | .4946 | |
| 17 | | .2484 |
| 18 | .1867 | .3025 |
| 19 | .2507 | .3246 |
| 20 | .2591 | .3071 |
| 21 | .2545 | .2827 |
| 22 | .2462 | .2721 |
| 23 | .237 | .2591 |
| 24 | .2324 | .2096 |
| Max | .5594 | .3246 |
| Min | .0663 | .1692 |
| Avg | .3375 | .2556 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 202 / 11 KV Kumtha SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1959 | .4298 |
| 2 | .2157 | .4374 |
| 3 | .2393 | .4504 |
| 4 | .2515 | .4481 |
| 5 | .2942 | .4687 |
| 6 | .3917 | .4656 |
| 7 | .3269 | .583 |
| 8 | .2484 | .618 |
| 9 | .1715 | |
| 10 | .1981 | |
| 14 | | .0114 |
| 15 | | .1219 |
| 16 | .1715 | .1562 |
| 17 | .7453 | .2347 |
| 18 | .7324 | .2942 |
| 19 | .602 | .3018 |
| 20 | .5868 | .3086 |
| 21 | .49 | .2515 |
| 22 | .4572 | .2385 |
| 23 | .4222 | .2279 |
| 24 | .4252 | .221 |
| Max | .7453 | .618 |
| Min | .1715 | .0114 |
| Avg | .3771 | .3299 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 203 / 11 KV Sirsal SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2667 | .2873 |
| 2 | .2484 | .2919 |
| 3 | .25 | .3125 |
| 4 | .3003 | |
| 5 | .3589 | |
| 6 | .5304 | |
| 7 | .7019 | |
| 8 | .7103 | .176 |
| 9 | | .5662 |
| 10 | | .5731 |
| 11 | | .4519 |
| 12 | | .4496 |
| 13 | | .4527 |
| 14 | .0854 | .4999 |
| 15 | .2172 | .4512 |
| 16 | .218 | .3483 |
| 17 | .2393 | .1943 |
| 18 | .3163 | .2591 |
| 19 | .5342 | .5967 |
| 20 | .6173 | .5426 |
| 21 | .4778 | .4336 |
| 22 | .378 | .3437 |
| 23 | .3224 | .3094 |
| 24 | .301 | .3064 |
| Max | .7103 | .5967 |
| Min | .0854 | .176 |
| Avg | .3723 | .3923 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 201 / 11 KV SHINDKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2942 | .2942 |
| 2 | .2683 | .2683 |
| 3 | .3041 | .3041 |
| 4 | .3483 | .3483 |
| 5 | .4169 | .4169 |
| 6 | .0389 | .0389 |
| 8 | .6295 | |
| 9 | .5838 | .4054 |
| 10 | .3414 | .4679 |
| 11 | .3605 | .4984 |
| 12 | .141 | .5213 |
| 13 | | .5068 |
| 14 | | .5586 |
| 15 | .3536 | .4908 |
| 16 | .4702 | .5426 |
| 17 | .5037 | .6013 |
| 18 | .5495 | .6264 |
| 19 | .4832 | .5335 |
| 20 | .3826 | .4542 |
| 21 | .3353 | .4123 |
| 22 | .2644 | .3757 |
| 23 | .25 | .3414 |
| 24 | .2477 | .3368 |
| Max | .6295 | .6264 |
| Min | .0389 | .0389 |
| Avg | .3603 | .4247 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 204 / 11 KV HADGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .5845 | .6066 |
| 2 | .6142 | .5868 |
| 3 | .6821 | .5891 |
| 4 | .7621 | .6043 |
| 5 | .7857 | .6501 |
| 6 | .173 | .7621 |
| 7 | | 1.3237 |
| 8 | | 1.5988 |
| 9 | | 1.6705 |
| 10 | .0549 | 1.4982 |
| 11 | 1.246 | |
| 12 | 1.5554 | |
| 13 | 1.7307 | |
| 14 | 1.7612 | |
| 15 | 1.701 | |
| 16 | 1.6834 | .0419 |
| 17 | 1.2826 | .3605 |
| 18 | 1.2849 | .4374 |
| 19 | .5175 | .5838 |
| 20 | .6722 | .6059 |
| 21 | .6539 | .6226 |
| 22 | .6112 | .6043 |
| 23 | .5586 | .538 |
| 24 | .5213 | .5144 |
| Max | 1.7612 | 1.6705 |
| Min | .0549 | .0419 |
| Avg | .9255 | .7473 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 203 / NEW COURT FEEDER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.1721 | 1.1546 |
| 2 | 1.1424 | 1.1317 |
| 3 | 1.1515 | 1.1248 |
| 4 | 1.246 | 1.1827 |
| 5 | 1.3916 | 1.3519 |
| 6 | 1.531 | 1.5524 |
| 7 | 1.5272 | 1.6438 |
| 8 | 1.768 | 1.7878 |
| 9 | 1.733 | 1.7856 |
| 10 | 1.7665 | 1.6842 |
| 11 | 1.5333 | 1.5524 |
| 12 | 1.4632 | 1.39 |
| 13 | 1.3458 | 1.291 |
| 14 | 1.2788 | 1.1767 |
| 15 | 1.1911 | 1.1004 |
| 16 | 1.1553 | |
| 17 | 1.1667 | 1.5104 |
| 18 | 1.3641 | 1.6659 |
| 19 | 1.6438 | 1.7231 |
| 20 | 1.6324 | 1.6522 |
| 21 | 1.5043 | 1.5059 |
| 22 | 1.3634 | 1.3321 |
| 23 | 1.2567 | 1.2414 |
| 24 | 1.1927 | 1.1675 |
| Max | 1.768 | 1.7878 |
| Min | 1.1424 | 1.1004 |
| Avg | 1.3967 | 1.4221 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 201 / 11 KV DIGOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7712 | .6752 |
| 2 | .8261 | .6874 |
| 3 | .8703 | .7042 |
| 4 | .2317 | .7621 |
| 5 | | .9069 |
| 6 | | 1.3946 |
| 7 | | 1.6461 |
| 8 | | 1.7314 |
| 9 | | .8993 |
| 10 | 1.2209 | .218 |
| 11 | 1.4906 | |
| 12 | 1.4601 | |
| 13 | 1.4769 | |
| 14 | 1.48 | |
| 15 | 1.5074 | |
| 16 | 1.3458 | .4527 |
| 17 | 1.3763 | .6036 |
| 18 | .6188 | .9099 |
| 19 | .9755 | .948 |
| 20 | .9861 | .8916 |
| 21 | .8581 | .7819 |
| 22 | .7301 | .6783 |
| 23 | .6691 | .6264 |
| 24 | .6737 | .6371 |
| Max | 1.5074 | 1.7314 |
| Min | .2317 | .218 |
| Avg | 1.0299 | .8502 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 202 / 11 KV YEROL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3986 | .4656 |
| 2 | .3346 | .4938 |
| 3 | .3376 | .6333 |
| 4 | .3788 | .644 |
| 5 | .4702 | |
| 6 | .5449 | |
| 7 | .7689 | |
| 8 | .8017 | |
| 9 | .7674 | |
| 10 | .5556 | .0564 |
| 11 | | .5914 |
| 12 | | .6318 |
| 13 | | .6211 |
| 14 | | .6737 |
| 15 | | .6455 |
| 16 | .0991 | .4976 |
| 17 | .3071 | .426 |
| 18 | .2888 | .4161 |
| 19 | .5114 | .5967 |
| 20 | .6264 | .6059 |
| 21 | .5799 | .567 |
| 22 | .5403 | .4832 |
| 23 | .4862 | .4679 |
| 24 | .4397 | .4679 |
| Max | .8017 | .6737 |
| Min | .0991 | .0564 |
| Avg | .4862 | .5255 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 202 / 11 KV Nandura AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-OCT-17 | 02-OCT-17 |
|------------|---------------|--------------|
| HR | Load (MW) | Load (MW) |
| 2 | .724 | |
| 3 | .7484 | |
| 4 | .756 | |
| 5 | .7438 | |
| 6 | .8352 | |
| 7 | 1.0822 | |
| 8 | 1.2681 | |
| 9 | 1.3702 | |
| 15 | | .0457 |
| 16 | | .4268 |
| 17 | | .4893 |
| 18 | | .5213 |
| 19 | | .503 |
| 20 | | .4512 |
| 21 | | .1387 |
| Max | 1.3702 | .5213 |
| Min | .724 | .0457 |
| Avg | .9410 | .368 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 204 / 11 KV NANDURA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2961 | .2945 |
| 2 | .29 | .2961 |
| 3 | .2919 | .301 |
| 4 | .3212 | .3174 |
| 5 | .3887 | .3791 |
| 6 | .4976 | .4961 |
| 7 | .5727 | .583 |
| 8 | .4702 | .2035 |
| 9 | .3487 | .0918 |
| 10 | .2644 | |
| 11 | .2191 | .29 |
| 12 | .1631 | .2587 |
| 13 | .1448 | .2221 |
| 14 | .1364 | |
| 15 | .1448 | .0019 |
| 16 | .1482 | .1928 |
| 17 | .1581 | .208 |
| 18 | .2073 | .2797 |
| 19 | .3929 | .389 |
| 20 | .4481 | .4927 |
| 21 | .4176 | .4519 |
| 22 | .3738 | .3551 |
| 23 | .3429 | .3319 |
| 24 | .3102 | .3117 |
| Max | .5727 | .583 |
| Min | .1364 | .0019 |
| Avg | .3062 | .3067 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 201 / 11KV Thodga GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .6981 | .66 |
| 2 | .6744 | .66 |
| 3 | .6546 | .6615 |
| 4 | .695 | .7019 |
| 5 | .8368 | .8444 |
| 6 | 1.0669 | 1.1241 |
| 7 | 1.1439 | 1.2048 |
| 8 | 1.0265 | .9465 |
| 9 | .9427 | .8977 |
| 10 | .8413 | .6447 |
| 11 | .612 | .66 |
| 12 | .4915 | .5418 |
| 13 | .4451 | .4496 |
| 14 | .4275 | .2286 |
| 15 | .3986 | .397 |
| 16 | .4016 | .3955 |
| 17 | .3429 | .4412 |
| 18 | .3658 | .5464 |
| 19 | .9686 | .9183 |
| 20 | .9328 | .8893 |
| 21 | .8337 | .8002 |
| 22 | .7651 | .7354 |
| 23 | .7042 | .6805 |
| 24 | .6767 | .6539 |
| Max | 1.1439 | 1.2048 |
| Min | .3429 | .2286 |
| Avg | .7061 | .6951 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 202 / 11KV MOGHA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.2239 | |
| 2 | 1.8099 | |
| 3 | 1.9532 | |
| 4 | 1.9646 | |
| 5 | 1.9761 | |
| 6 | 2.0363 | |
| 7 | 2.175 | |
| 8 | 2.3358 | |
| 9 | 2.364 | |
| 12 | | .1829 |
| 13 | | 1.1995 |
| 14 | | 1.4952 |
| 15 | | 1.7391 |
| 16 | | 1.8435 |
| 17 | | 2.0462 |
| 18 | | 2.0317 |
| Max | 2.364 | 2.0462 |
| Min | 1.2239 | .1829 |
| Avg | 1.9821 | 1.5054 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 203 / 11KV TEMBHURNI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 10 | .4565 |
| 11 | 2.0386 |
| 12 | 2.2458 |
| 13 | 2.2519 |
| 14 | 2.2916 |
| 15 | 1.8915 |
| 16 | 2.1148 |
| 17 | 1.9303 |
| Max | 2.2916 |
| Min | .4565 |
| Avg | 1.9026 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB

ST

Feeder No / Name : 201 / 11KV BUSTAND FEEDER.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.8831 | 1.7977 |
| 2 | 1.7955 | 1.8016 |
| 3 | 1.7749 | 1.736 |
| 4 | 1.8221 | 1.7208 |
| 5 | 1.9136 | 1.8435 |
| 6 | 2.0462 | 1.9692 |
| 7 | 2.1293 | 2.1346 |
| 8 | 2.127 | 2.1193 |
| 9 | 2.0652 | 2.0187 |
| 10 | 1.9387 | 2.0104 |
| 11 | 1.9456 | 1.8801 |
| 12 | 1.8686 | 1.8191 |
| 13 | 1.8938 | 1.7193 |
| 14 | 1.8503 | 1.72 |
| 15 | 1.6979 | 1.6644 |
| 16 | 1.7109 | 1.6804 |
| 17 | 1.7292 | 1.7848 |
| 18 | 1.7673 | 1.986 |
| 19 | 2.3731 | 2.3213 |
| 20 | 2.2146 | 2.2771 |
| 21 | 2.0736 | 2.2314 |
| 22 | 2.0645 | 2.1544 |
| 23 | 1.9982 | 2.0271 |
| 24 | 1.8877 | 1.8846 |
| Max | 2.3731 | 2.3213 |
| Min | 1.6979 | 1.6644 |
| Avg | 1.9405 | 1.9292 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB

ST

Feeder No / Name : 202 / 11KV TELEPHONE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.2048 | 1.1591 |
| 2 | 1.1515 | 1.1325 |
| 3 | 1.1325 | 1.1195 |
| 4 | 1.1515 | 1.1515 |
| 5 | 1.1797 | 1.1797 |
| 6 | 1.2071 | 1.2071 |
| 7 | 1.3154 | 1.3154 |
| 8 | 1.3009 | 1.3009 |
| 9 | 1.3489 | 1.3489 |
| 10 | 1.2559 | 1.2559 |
| 11 | 1.057 | 1.057 |
| 12 | 1.2155 | 1.2155 |
| 13 | 1.1957 | 1.1957 |
| 14 | 1.1744 | 1.1744 |
| 15 | 1.1515 | 1.1515 |
| 16 | 1.1698 | 1.1698 |
| 17 | 1.1767 | 1.1767 |
| 18 | 1.169 | 1.169 |
| 19 | 1.5043 | 1.5043 |
| 20 | 1.4967 | 1.4967 |
| 21 | 1.4259 | 1.4259 |
| 22 | 1.3519 | 1.3519 |
| 23 | 1.2879 | 1.2879 |
| 24 | 1.2224 | 1.2224 |
| Max | 1.5043 | 1.5043 |
| Min | 1.057 | 1.057 |
| Avg | 1.2436 | 1.2404 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB

ST

Feeder No / Name : 203 / 11KV EXPRESS FEEDER

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1116 | .0899 |
| 2 | .0815 | .021 |
| 3 | .0903 | .0377 |
| 4 | .0808 | .0758 |
| 5 | .0255 | .0911 |
| 6 | .0751 | .0918 |
| 7 | .1113 | .0888 |
| 8 | .1109 | .0937 |
| 9 | .0663 | .0926 |
| 10 | .0347 | .0922 |
| 11 | .0747 | .0899 |
| 12 | .08 | .0914 |
| 13 | .112 | .109 |
| 14 | .0854 | .1082 |
| 15 | .0777 | .0743 |
| 16 | .0564 | .0766 |
| 17 | .0895 | .0785 |
| 18 | .0819 | .1288 |
| 19 | .0815 | .1341 |
| 20 | .1269 | .1341 |
| 21 | .1238 | .1376 |
| 22 | .1097 | .1387 |
| 23 | .0693 | .133 |
| 24 | .093 | .133 |
| Max | .1269 | .1387 |
| Min | .0255 | .021 |
| Avg | .0854 | .0976 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 207 / 11 KV GILDA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 11 | .0354 |
| 12 | .0263 |
| 13 | .0244 |
| 17 | .0029 |
| Max | .0354 |
| Min | .0029 |
| Avg | .0223 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7415 | .3955 |
| 2 | .7468 | .4207 |
| 3 | .7545 | .4527 |
| 4 | .7888 | .4961 |
| 5 | .9183 | |
| 6 | 1.0326 | |
| 7 | 1.4792 | |
| 8 | 1.6453 | |
| 9 | 1.4777 | |
| 10 | 1.3573 | .599 |
| 11 | | 1.073 |
| 12 | | 1.1477 |
| 13 | | 1.0311 |
| 14 | | 1.118 |
| 15 | | 1.2483 |
| 16 | .2957 | 1.0044 |
| 17 | .4893 | .9595 |
| 18 | .4702 | 1.0052 |
| 19 | .7415 | .7994 |
| 20 | .6363 | .8322 |
| 21 | .5792 | .7766 |
| 22 | .5014 | .7476 |
| 23 | .4451 | .6424 |
| 24 | .4047 | .6379 |
| Max | 1.6453 | 1.2483 |
| Min | .2957 | .3955 |
| Avg | .8161 | .8099 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 202 / 11KV Jadhala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7285 | 1.4769 |
| 2 | .7537 | 1.5143 |
| 3 | .8352 | 1.5706 |
| 4 | .7979 | 1.6286 |
| 5 | | 1.7139 |
| 6 | | 1.8785 |
| 7 | | 2.0218 |
| 8 | | 2.0904 |
| 9 | | 2.0713 |
| 10 | 1.6606 | 1.9852 |
| 11 | 2.3655 | |
| 12 | 2.4143 | |
| 13 | 2.3792 | |
| 14 | 2.5659 | |
| 15 | 2.6071 | |
| 16 | 2.6452 | .3178 |
| 17 | 1.1919 | .4687 |
| 18 | 1.7604 | .7179 |
| 19 | .964 | .9724 |
| 20 | 1.0875 | 1.0204 |
| 21 | 1.0052 | .9267 |
| 22 | .9008 | .8124 |
| 23 | .8177 | .788 |
| 24 | 1.1988 | 1.3596 |
| Max | 2.6452 | 2.0904 |
| Min | .7285 | .3178 |
| Avg | 1.5094 | 1.3334 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 204 / 11KV Tivghal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.3717 | .6981 |
| 2 | 1.4647 | .7011 |
| 3 | 1.5562 | .7301 |
| 4 | .6097 | .8307 |
| 5 | | .9404 |
| 6 | 1.1584 | 1.2026 |
| 7 | 1.5135 | 1.1736 |
| 8 | 1.5089 | 1.5211 |
| 9 | 2.0622 | 2.0576 |
| 10 | 1.9677 | 1.7756 |
| 11 | 2.0348 | 1.5257 |
| 12 | 1.7695 | 1.4906 |
| 13 | 1.8107 | 1.5135 |
| 14 | 1.893 | 1.2803 |
| 15 | 2.1597 | .98 |
| 16 | 1.6049 | .9313 |
| 17 | .1463 | 1.4403 |
| 18 | .125 | 1.5409 |
| 19 | 1.0623 | 1.6842 |
| 20 | 1.012 | 1.6644 |
| 21 | .8962 | 1.5684 |
| 22 | .82 | 1.5089 |
| 23 | .7438 | 1.4586 |
| 24 | .7087 | 1.4342 |
| Max | 2.1597 | 2.0576 |
| Min | .125 | .6981 |
| Avg | 1.3043 | 1.3188 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 205 / 11KV Bothi Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1616 | .176 |
| 2 | .1616 | .1768 |
| 3 | .1623 | .176 |
| 4 | .1623 | .176 |
| 5 | .1631 | .176 |
| 6 | .1631 | .1799 |
| 7 | .1684 | .157 |
| 8 | .1661 | .1524 |
| 9 | .1677 | .1524 |
| 10 | .0907 | .1486 |
| 11 | | .1067 |
| 12 | .1349 | .1357 |
| 13 | .1509 | .1357 |
| 14 | .1501 | .1357 |
| 15 | .1562 | .157 |
| 16 | .1555 | .1593 |
| 17 | .1509 | .16 |
| 18 | .1745 | .1669 |
| 19 | .1776 | .1646 |
| 20 | .1776 | .1646 |
| 21 | .1753 | .1623 |
| 22 | .1753 | .1623 |
| 23 | .1753 | .1623 |
| 24 | .1753 | .1623 |
| Max | .1776 | .1799 |
| Min | .0907 | .1067 |
| Avg | .1607 | .1586 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 203 / 11KV Gharola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .6097 | .4572 |
| 2 | .6097 | .3048 |
| 3 | .6097 | .3048 |
| 4 | .7621 | .3048 |
| 5 | | .4572 |
| 6 | | .4572 |
| 7 | | .9145 |
| 8 | | .9145 |
| 9 | | .7621 |
| 10 | .1524 | .3048 |
| 11 | .9145 | |
| 12 | 1.0669 | |
| 13 | 1.2193 | |
| 14 | 1.2193 | |
| 15 | 1.2193 | |
| 16 | 1.3717 | |
| 17 | 1.2193 | .3048 |
| 18 | 1.2193 | .3048 |
| 19 | .4572 | .6097 |
| 20 | .6097 | .6097 |
| 21 | .6097 | .6097 |
| 22 | .6097 | .6097 |
| 23 | .6097 | .6097 |
| 24 | .6097 | .4572 |
| Max | 1.3717 | .9145 |
| Min | .1524 | .3048 |
| Avg | .8263 | .5165 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 201 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .7621 |
| 2 | .7621 |
| 3 | .7621 |
| 4 | .9145 |
| 5 | .9145 |
| 11 | .7621 |
| 12 | .9907 |
| 13 | 1.0669 |
| 14 | .9907 |
| 15 | .9907 |
| 16 | .8383 |
| 17 | .7621 |
| 18 | .7621 |
| 19 | .6859 |
| 20 | .8383 |
| 21 | .8383 |
| 22 | .8383 |
| 23 | .7621 |
| 24 | .7621 |
| Max | 1.0669 |
| Min | .6859 |
| Avg | .8423 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 202 / 11KV Devangra SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 02-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 11 | .0762 |
| 12 | .0762 |
| 14 | .0762 |
| 15 | .0762 |
| 16 | .0762 |
| 17 | .0762 |
| 18 | .0762 |
| Max | .0762 |
| Min | .0762 |
| Avg | .0762 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 2 | .0762 | |
| 3 | .0762 | |
| 4 | .0762 | |
| 5 | .0762 | |
| 6 | .1524 | |
| 7 | .2286 | |
| 8 | .3048 | |
| 9 | .381 | |
| 11 | | .2286 |
| 12 | | .3048 |
| 13 | | .2286 |
| 14 | | .2286 |
| 15 | | .3048 |
| 16 | | .3048 |
| 17 | | .2286 |
| 18 | | .2286 |
| Max | .381 | .3048 |
| Min | .0762 | .2286 |
| Avg | .1715 | .2572 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 204 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1448 | .3048 |
| 2 | .141 | .3048 |
| 3 | .141 | .301 |
| 4 | .141 | .301 |
| 5 | .141 | .3048 |
| 6 | .2362 | .1753 |
| 7 | .3429 | .3163 |
| 8 | .3544 | .3163 |
| 9 | .3887 | .3201 |
| 10 | .3887 | .3315 |
| 11 | .3696 | .3277 |
| 12 | .3506 | .2858 |
| 13 | .3544 | .2134 |
| 14 | .3506 | .2743 |
| 15 | .3506 | .3163 |
| 16 | .3582 | .3163 |
| 17 | .2858 | .3163 |
| 18 | .3734 | .3201 |
| 19 | .3734 | .3201 |
| 20 | .3734 | .3201 |
| 21 | .3696 | .3201 |
| 22 | .3734 | .3201 |
| 23 | .3048 | .3163 |
| 24 | | .3163 |
| Max | .3887 | .3315 |
| Min | .141 | .1753 |
| Avg | .3047 | .3025 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 201 / 11 KV TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 1.2193 |
| 2 | 1.1431 |
| 3 | 1.1431 |
| 4 | 1.1431 |
| 5 | 1.2193 |
| 6 | 1.2193 |
| 7 | 1.3717 |
| 8 | 1.448 |
| 9 | 1.448 |
| 10 | 1.448 |
| 11 | 1.2955 |
| 12 | 1.2193 |
| 13 | 1.1431 |
| 14 | 1.1431 |
| 15 | 1.0669 |
| 16 | 1.1431 |
| 17 | 1.0669 |
| 18 | 1.2193 |
| 19 | 1.448 |
| 20 | 1.5242 |
| 21 | 1.448 |
| 22 | 1.448 |
| 23 | 1.2955 |
| 24 | 1.2955 |
| Max | 1.5242 |
| Min | 1.0669 |
| Avg | 1.2733 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 204 / 11KV AMBEDKAR CHOWK
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7788 | .7743 |
| 2 | .7484 | .7476 |
| 3 | .743 | .727 |
| 4 | .7674 | .759 |
| 5 | .8169 | .7948 |
| 6 | .9153 | .9473 |
| 7 | 1.0448 | 1.0768 |
| 8 | 1.1126 | 1.2384 |
| 9 | 1.185 | 1.1751 |
| 10 | 1.1347 | 1.1652 |
| 11 | 1.2056 | 1.0707 |
| 12 | 1.1073 | 1.0883 |
| 13 | 1.1088 | 1.1004 |
| 14 | 1.1164 | 1.0197 |
| 15 | 1.0616 | .9435 |
| 16 | 1.0814 | .9099 |
| 17 | 1.0562 | 1.0509 |
| 18 | 1.2666 | 1.2567 |
| 19 | 1.4807 | 1.3626 |
| 20 | 1.4403 | 1.2285 |
| 21 | 1.2971 | 1.057 |
| 22 | 1.0943 | .9732 |
| 23 | .9534 | .9328 |
| 24 | .8383 | .8261 |
| Max | 1.4807 | 1.3626 |
| Min | .743 | .727 |
| Avg | 1.0565 | 1.0094 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 202 / 11 KV TALWES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .6859 |
| 2 | .6859 |
| 3 | .6097 |
| 4 | .6097 |
| 5 | .6859 |
| 6 | .7621 |
| 7 | .9145 |
| 8 | 1.0669 |
| 9 | 1.0669 |
| 10 | .9907 |
| 11 | .9145 |
| 12 | .8383 |
| 13 | .7621 |
| 14 | .7621 |
| 15 | .6859 |
| 16 | .7621 |
| 17 | .7621 |
| 18 | .7621 |
| 19 | .6859 |
| 20 | 1.0669 |
| 21 | .9145 |
| 22 | .9145 |
| 23 | .7621 |
| 24 | .7621 |
| Max | 1.0669 |
| Min | .6097 |
| Avg | .8097 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 205 / 11KV MIDC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4268 | .5548 |
| 2 | .4283 | .5144 |
| 3 | .4245 | .5213 |
| 4 | .4626 | .602 |
| 5 | .5159 | .7049 |
| 6 | .7727 | .8551 |
| 7 | 1.2048 | 1.2071 |
| 8 | 1.2574 | 1.1515 |
| 9 | 1.0479 | 1.4891 |
| 10 | 1.4304 | 1.6659 |
| 11 | 1.7764 | 1.736 |
| 12 | 1.7261 | 1.2452 |
| 13 | 1.624 | 1.2452 |
| 14 | 1.3908 | .8581 |
| 15 | 1.5417 | 1.0319 |
| 16 | 1.5386 | 1.1485 |
| 17 | 1.3428 | .647 |
| 18 | 1.217 | .8177 |
| 19 | 1.6491 | 1.2003 |
| 20 | 1.2864 | 1.0143 |
| 21 | .8368 | .9534 |
| 22 | .7628 | .6897 |
| 23 | .6272 | .6165 |
| 24 | .5693 | .5716 |
| Max | 1.7764 | 1.736 |
| Min | .4245 | .5144 |
| Avg | 1.0775 | .9601 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 204 / 11 KV MAHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------------|--------------|--------------|
| HR | Load (MW) | Load (MW) |
| 7 | | .0419 |
| 8 | | .093 |
| 9 | .0404 | .1059 |
| 10 | | .0381 |
| 11 | | .0633 |
| 12 | .0137 | .093 |
| 13 | .0815 | .0991 |
| 14 | .0503 | .0953 |
| 15 | .1006 | .0876 |
| 16 | .0259 | .0815 |
| 17 | .0191 | .0198 |
| 18 | .0122 | |
| 19 | .0823 | |
| 23 | | .003 |
| Max | .1006 | .1059 |
| Min | .0122 | .003 |
| Avg | .0473 | .0685 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 205 / 11 KV VETERINARY COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4237 | .4092 |
| 2 | .4039 | .3963 |
| 3 | .3978 | .3826 |
| 4 | .3932 | .3681 |
| 5 | .3917 | .3711 |
| 6 | .4199 | .3849 |
| 7 | .4611 | .4306 |
| 8 | .5327 | .5342 |
| 9 | .6638 | .6142 |
| 10 | .6478 | .631 |
| 11 | .583 | .5807 |
| 12 | .6356 | .5495 |
| 13 | .5914 | .5304 |
| 14 | .5777 | .474 |
| 15 | .4946 | .5098 |
| 16 | .5274 | .5312 |
| 17 | .5761 | .5022 |
| 18 | .5571 | .5487 |
| 19 | .6165 | .5845 |
| 20 | .5967 | .4748 |
| 21 | .5777 | .5045 |
| 22 | .5708 | .503 |
| 23 | .4519 | .4466 |
| 24 | .365 | .41 |
| Max | .6638 | .631 |
| Min | .365 | .3681 |
| Avg | .5190 | .4863 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .5228 | .5411 |
| 2 | .4946 | .5144 |
| 3 | .49 | .4938 |
| 4 | .4862 | .4854 |
| 5 | .5022 | .4976 |
| 6 | .5365 | .5136 |
| 7 | .5716 | .5822 |
| 8 | .6196 | .6523 |
| 9 | .6051 | .6462 |
| 10 | .6287 | .6127 |
| 11 | .6874 | .6203 |
| 12 | .7682 | .6249 |
| 13 | .7514 | .6401 |
| 14 | .7362 | .6234 |
| 15 | .6927 | .5929 |
| 16 | .7385 | .5868 |
| 17 | .7057 | .5761 |
| 18 | .7636 | .6729 |
| 19 | .9031 | .7506 |
| 20 | .9069 | .7453 |
| 21 | .8672 | .7194 |
| 22 | .7491 | .6729 |
| 23 | .6882 | .5876 |
| 24 | .6028 | .5327 |
| Max | .9069 | .7506 |
| Min | .4862 | .4854 |
| Avg | .6674 | .6036 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 207 / 11KV EXPRESS RUDRANI
HEALTHCAR Feeder KV- 11 /
OUTGOING

SHEDDABLE RURAL

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1052 | .1113 |
| 2 | .1067 | .1006 |
| 3 | .1067 | .0998 |
| 4 | .1044 | .0968 |
| 5 | .1014 | .0968 |
| 6 | .1036 | .0953 |
| 7 | .1021 | .125 |
| 8 | .0945 | .1318 |
| 9 | .1562 | .1357 |
| 10 | .0854 | .1357 |
| 11 | .0008 | .1059 |
| 12 | | .1631 |
| 13 | | .1273 |
| 14 | .0008 | .218 |
| 15 | .1075 | .1898 |
| 16 | .2058 | .1837 |
| 17 | .1989 | .2324 |
| 18 | .2279 | .25 |
| 19 | .2096 | .2843 |
| 20 | .1745 | .2827 |
| 21 | .1715 | .2827 |
| 22 | .1608 | .282 |
| 23 | .0907 | .269 |
| 24 | .112 | .205 |
| Max | .2279 | .2843 |
| Min | .0008 | .0953 |
| Avg | .1240 | .1752 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 201 / 11 KV Bus Stand

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.0364 | .9907 |
| 2 | .945 | .9221 |
| 3 | .9069 | .8993 |
| 4 | .9145 | .8764 |
| 5 | .9297 | .8764 |
| 6 | .9755 | .9145 |
| 7 | 1.0136 | 1.0288 |
| 8 | 1.2193 | 1.2193 |
| 9 | 1.2422 | 1.2498 |
| 10 | 1.2346 | 1.2193 |
| 11 | 1.166 | 1.1965 |
| 12 | 1.0822 | .7849 |
| 13 | 1.0822 | 1.0822 |
| 14 | 1.044 | 1.044 |
| 15 | 1.0212 | .9831 |
| 16 | 1.0288 | .9678 |
| 17 | 1.0517 | .3963 |
| 18 | 1.0288 | 1.0898 |
| 19 | 1.166 | 1.1965 |
| 20 | 1.3032 | 1.2803 |
| 21 | 1.2879 | 1.2955 |
| 22 | 1.2879 | 1.2574 |
| 23 | 1.2193 | 1.1126 |
| 24 | 1.1126 | 1.0745 |
| Max | 1.3032 | 1.2955 |
| Min | .9069 | .3963 |
| Avg | 1.0958 | 1.0399 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 202 / 11 KV RAILWAY STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.3489 | 1.3184 |
| 2 | 1.2803 | 1.2879 |
| 3 | 1.2422 | 1.2651 |
| 4 | 1.2269 | 1.2498 |
| 5 | 1.2727 | 1.2803 |
| 6 | 1.3565 | 1.3717 |
| 7 | 1.4022 | 1.4861 |
| 8 | 1.5851 | 1.6232 |
| 9 | 1.5242 | 1.6232 |
| 10 | 1.4937 | 1.6232 |
| 11 | 1.6994 | 1.7909 |
| 12 | 1.7604 | 1.7604 |
| 13 | 1.7604 | 1.6461 |
| 14 | 1.6613 | 1.6156 |
| 15 | 1.5927 | .3277 |
| 16 | 1.5623 | 1.0669 |
| 17 | 1.6537 | 1.2727 |
| 18 | 1.6232 | 1.6004 |
| 19 | 1.7071 | 1.6613 |
| 20 | 1.7985 | 1.7985 |
| 21 | 1.7452 | 1.669 |
| 22 | 1.7071 | 1.5927 |
| 23 | .7926 | 1.5013 |
| 24 | 1.326 | 1.3565 |
| Max | 1.7985 | 1.7985 |
| Min | .7926 | .3277 |
| Avg | 1.5051 | 1.4495 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 401 / 33 KV UDGIR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | *** | 29.6296 |
| 2 | *** | *** |
| 3 | *** | *** |
| 4 | *** | *** |
| 5 | *** | *** |
| 6 | *** | *** |
| 7 | 27.9836 | *** |
| 8 | *** | *** |
| 9 | *** | *** |
| 10 | *** | *** |
| 11 | *** | *** |
| 12 | *** | *** |
| 13 | *** | *** |
| 14 | *** | *** |
| 15 | *** | 17.2154 |
| 16 | *** | 19.9589 |
| 17 | *** | 11.1111 |
| 18 | *** | 20.6448 |
| 19 | *** | 26.2003 |
| 20 | *** | 23.3882 |
| 21 | *** | 25.0344 |
| 22 | *** | 21.7421 |
| 23 | *** | 20.3704 |
| 24 | *** | 18.8615 |
| Max | 69.2731 | 51.2347 |
| Min | 27.9836 | 11.1111 |
| Avg | 42.4726 | 31.0500 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 402 / 33 KV NALGIR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 11.5912 | 12.0713 |
| 2 | 19.6159 | 19.9589 |
| 3 | 20.5076 | 20.2332 |
| 4 | 21.0563 | 20.5762 |
| 5 | 19.2044 | 16.941 |
| 6 | 20.439 | 17.7641 |
| 7 | 21.8793 | 20.3704 |
| 8 | 25.1715 | 22.2908 |
| 9 | 25.8574 | 24.6228 |
| 10 | 16.1866 | 15.2264 |
| 11 | 21.262 | 22.2223 |
| 12 | 24.6228 | 23.6626 |
| 13 | 22.4966 | 25.3773 |
| 14 | 25.1715 | 26.2003 |
| 15 | 24.8972 | 24.3485 |
| 16 | 24.6228 | 18.3814 |
| 17 | 27.8464 | 25.0343 |
| 18 | 27.4349 | 25.926 |
| 19 | 16.7353 | 17.1468 |
| 20 | 17.0782 | 15.7065 |
| 21 | 16.7353 | 15.1578 |
| 22 | 15.4321 | 14.4033 |
| 23 | 13.2373 | 13.3745 |
| 24 | 12.8258 | 12.2771 |
| Max | 27.8464 | 26.2003 |
| Min | 11.5912 | 12.0713 |
| Avg | 20.4961 | 19.5531 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 201 / 11 KV KARADKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .415 | .4043 |
| 2 | .4142 | .3913 |
| 3 | .4607 | .4081 |
| 4 | .5034 | .4351 |
| 5 | .5327 | .0042 |
| 6 | .6588 | |
| 7 | .9907 | |
| 8 | 1.0681 | |
| 9 | 1.0486 | |
| 10 | .5209 | |
| 11 | .0038 | .4523 |
| 12 | | .506 |
| 13 | | .9953 |
| 14 | | 1.0982 |
| 15 | | .4668 |
| 16 | | .5617 |
| 17 | .3045 | .6207 |
| 18 | .2839 | .6192 |
| 19 | .3925 | .5041 |
| 20 | .5209 | .5666 |
| 21 | .5559 | .5316 |
| 22 | .5018 | .4904 |
| 23 | .4637 | .4531 |
| 24 | .423 | .4317 |
| Max | 1.0681 | 1.0982 |
| Min | .0038 | .0042 |
| Avg | .5296 | .5232 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 202 / 11 KV HER SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .349 | .4908 |
| 2 | .317 | .5258 |
| 3 | .3498 | .5708 |
| 4 | .3658 | .3658 |
| 5 | .4336 | |
| 6 | .6127 | |
| 7 | .8185 | |
| 8 | .8665 | |
| 9 | .692 | |
| 10 | .3452 | .5777 |
| 11 | | .695 |
| 12 | | .5906 |
| 13 | | .692 |
| 14 | | .6432 |
| 15 | | .3292 |
| 16 | .317 | .4123 |
| 17 | .3422 | .4222 |
| 18 | .4473 | .4938 |
| 19 | .612 | .583 |
| 20 | .6767 | .5906 |
| 21 | .5883 | .506 |
| 22 | .5403 | .4603 |
| 23 | .4778 | .4412 |
| 24 | .4694 | .4527 |
| Max | .8665 | .695 |
| Min | .317 | .3292 |
| Avg | .5064 | .5181 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 204 / 11 KV KSHTRAPHAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3669 | .3445 |
| 2 | .3563 | .3399 |
| 3 | .3597 | .3376 |
| 4 | .3841 | .3593 |
| 5 | .5007 | .4607 |
| 6 | .7255 | .6451 |
| 7 | .7609 | .7457 |
| 8 | .6645 | .7461 |
| 9 | .5864 | .6523 |
| 10 | .4984 | .5346 |
| 11 | .4466 | .4283 |
| 12 | .2972 | .3246 |
| 13 | .2858 | .2816 |
| 14 | .3029 | .2736 |
| 15 | .3315 | .2 |
| 16 | .3528 | .2016 |
| 17 | .3323 | |
| 18 | .3075 | .3761 |
| 19 | .4748 | .5647 |
| 20 | .5121 | .5018 |
| 21 | .4405 | .4565 |
| 22 | .3898 | .3887 |
| 23 | .3639 | .3376 |
| 24 | .3559 | .3227 |
| Max | .7609 | .7461 |
| Min | .2858 | .2 |
| Avg | .4332 | .4271 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 207 / 11 KV Haknakwadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1848 | .1254 |
| 2 | .1757 | .1273 |
| 3 | .1741 | .1417 |
| 4 | .1821 | .1501 |
| 5 | .218 | .1768 |
| 6 | .3269 | .25 |
| 7 | .3631 | .3528 |
| 8 | .4477 | .4241 |
| 9 | .3551 | .4252 |
| 10 | .365 | .3814 |
| 11 | .2614 | .2884 |
| 12 | .2743 | .1669 |
| 13 | .317 | .1646 |
| 14 | .3003 | .1494 |
| 15 | .277 | .1246 |
| 16 | .3037 | .1379 |
| 17 | .1566 | .1513 |
| 18 | .2218 | .2206 |
| 19 | .3616 | .3102 |
| 20 | .3898 | .25 |
| 21 | .2618 | .2458 |
| 22 | .221 | .1981 |
| 23 | .1315 | .1646 |
| 24 | .1299 | .1536 |
| Max | .4477 | .4252 |
| Min | .1299 | .1246 |
| Avg | .2667 | .2200 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 204 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 10 | | .0168 |
| 11 | | .0579 |
| 12 | .0206 | .0724 |
| 13 | .0038 | .0869 |
| 14 | | .0587 |
| Max | .0206 | .0869 |
| Min | .0038 | .0168 |
| Avg | .0122 | .0585 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 202 / 11 KV S.OMARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3993 | .7491 |
| 2 | .4481 | .7895 |
| 3 | .5175 | .8238 |
| 4 | .3734 | .8886 |
| 5 | | 1.0349 |
| 6 | | 1.3535 |
| 7 | | 1.7337 |
| 8 | | 1.8519 |
| 9 | | 1.3672 |
| 10 | 1.2544 | .3094 |
| 11 | 1.5691 | |
| 12 | 1.7215 | |
| 13 | 1.8153 | |
| 14 | 1.8359 | |
| 15 | 1.893 | |
| 16 | 1.4586 | .2164 |
| 17 | 1.3268 | .2622 |
| 18 | .9335 | .3704 |
| 19 | .5289 | .5502 |
| 20 | .5914 | .519 |
| 21 | .5121 | .4626 |
| 22 | .4664 | .4329 |
| 23 | .3696 | .3643 |
| 24 | .3612 | .3452 |
| Max | 1.893 | 1.8519 |
| Min | .3612 | .2164 |
| Avg | .9672 | .7592 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 203 / 11 KV KARWANDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .2888 | .3521 |
| 2 | .2961 | .394 |
| 3 | .3064 | .4386 |
| 4 | .3635 | .2042 |
| 5 | .3818 | |
| 6 | .423 | |
| 7 | .5011 | |
| 8 | .6093 | |
| 9 | .4458 | |
| 10 | .0941 | .4862 |
| 11 | | .5708 |
| 12 | | .5491 |
| 13 | | .5876 |
| 14 | | .6219 |
| 15 | | .3372 |
| 16 | .1947 | .4412 |
| 17 | .1859 | .3944 |
| 18 | .3216 | .3426 |
| 19 | .5003 | .5201 |
| 20 | .514 | .5117 |
| 21 | .4405 | .4557 |
| 22 | .4344 | .3902 |
| 23 | .3681 | .357 |
| 24 | .3749 | .3738 |
| Max | .6093 | .6219 |
| Min | .0941 | .2042 |
| Avg | .3708 | .4383 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-OCT-17 and 07-OCT-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 203 / 11KV NAGALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-OCT-17 | 02-OCT-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7621 | .6859 |
| 2 | .7621 | 1.2193 |
| 3 | .7621 | 1.2193 |
| 4 | .8383 | 1.2193 |
| 5 | | 1.2193 |
| 6 | | 1.3717 |
| 7 | | 1.5242 |
| 8 | | 1.6766 |
| 9 | | 1.6004 |
| 10 | .381 | .9145 |
| 11 | 1.7528 | |
| 12 | 1.7528 | |
| 13 | 1.829 | |
| 14 | 1.9052 | |
| 15 | 1.829 | |
| 16 | 1.829 | .1524 |
| 17 | 1.829 | .6097 |
| 18 | 1.7528 | .6859 |
| 19 | .8383 | .9145 |
| 20 | 1.0669 | .9907 |
| 21 | .9907 | .9145 |
| 22 | .8383 | .8383 |
| 23 | .7621 | .7621 |
| 24 | .6859 | .6859 |
| Max | 1.9052 | 1.6766 |
| Min | .381 | .1524 |
| Avg | 1.2193 | 1.0108 |