

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213309 / O ZONE IT PARK

Feeder No / Name : 201 / NAIK NAWARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.7468	.7468	.8316	.8316	.8316	.8316
2	.6468	.6535	.6535	.7392	.7392	.8316	.8316
3	.6468	.6535	.6535	.7392	.7392	.8316	.8316
4	.6468	.6535	.6535	.7392	.7392	.924	.924
5	.8316	1.0269	.8402	.924	.924	1.1088	1.1088
6	1.386	1.4003	1.2136	1.0164	1.2012	1.2012	1.2936
7	1.7556	1.6804	1.4937	1.2936	1.7556	1.6632	1.848
8	1.848	1.8671	1.8671	1.6632	2.0328	2.0328	2.0328
9	1.6632	1.7737	1.9605	1.8671	1.9404	2.0328	1.848
10	1.773	1.587	1.6804	1.307			
11	1.3817	1.4003	1.587	1.1576			
12	1.3443	1.307	1.4937	1.4563			
13		1.1203	1.307	1.419			
14	1.0456	1.1203	1.1203	1.4937		1.2323	
15	1.0456	.9335	1.1203	1.2323			1.2323
16	.9808	1.0269	1.1203	1.2696	1.1949		1.1088
17	1.2323	1.1203	1.1203	1.2012	1.1827		1.2197
18	1.0829	1.2136	1.307	1.2936	1.1088	1.2012	1.2936
19	1.3443	1.587	1.587	1.6632	1.4784	1.2936	1.6078
20		1.587	1.587	1.6632	1.5708	1.6263	1.6632
21	1.6221	1.587	1.587	1.4784	1.5708	1.5708	1.5893
22		1.307	1.307	1.386	1.386	1.386	1.4784
23	1.0269	1.1203	1.0269	1.1088	1.1088	1.1088	1.1088
24	.8316	.8316	.8402	.8402	.924	.924	.924
Max	1.848	1.8671	1.9605	1.8671	2.0328	2.0328	2.0328
Min	.6468	.6535	.6535	.7392	.7392	.8316	.8316
Avg	1.1845	1.2210	1.2447	1.2410	1.2460	1.2824	1.3040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213309 / O ZONE IT PARK

Feeder No / Name : 202 / Satvwadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.1203	1.1203	1.0164	1.0164	1.0164	1.0164
2	1.0164	1.0269	1.0269	.924	.924	1.0164	1.0164
3	1.0164	1.0269	.6535	.924	.924	1.0164	1.0164
4	.6468	1.0269	1.0269	.8288	.924	1.1088	1.1088
5	1.2012	1.2136	1.2136	1.2936	1.1088	1.2936	1.4784
6	1.5708	1.587	1.587	1.386	1.5708	1.386	1.6632
7	2.3101	2.2405	2.0538	1.4784	2.1253	1.848	2.2177
8	2.4025	2.4272	2.4272	2.0328	2.4025	2.4025	2.4025
9	2.4025	2.3339	2.3339	2.2405	2.3101	2.4025	2.2177
10	1.9791	1.9605	2.0538	2.0538			
11	1.8298	1.9605	1.9605	1.8671			
12	1.531	1.6804	1.8671				
13		1.6804	1.6804				
14	1.3817	1.4937	1.4937	1.7177			
15	1.3817	1.4937	1.4937	1.8298		1.3817	1.3817
16	1.3817	1.4003	1.4937	1.531			1.5893
17	1.3817	1.4937	1.4937	1.5708	1.5154		1.5893
18	1.531	1.7737	1.6804	1.6632	1.6632	1.6817	1.9589
19	2.3899	2.1472	2.1472	2.0328	2.0328	1.9589	2.347
20	2.3899	2.1472	2.1472	2.0328	2.1253	2.1068	2.1807
21	1.9791	1.9605	1.9605	1.848	1.9404	2.0144	2.1807
22	1.7737	1.6804	1.6804	1.7556	1.7556	1.7556	1.848
23	1.4003	1.4937	1.4003	1.4784	1.4784	1.4784	1.6632
24	1.2012	1.2012	1.2136	1.0269	1.1088	1.1088	1.1088
Max	2.4025	2.4272	2.4272	2.2405	2.4025	2.4025	2.4025
Min	.6468	1.0269	.6535	.8288	.924	1.0164	1.0164
Avg	1.6177	1.6488	1.6337	1.5697	1.5839	1.5869	1.6834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213309 / O ZONE IT PARK

Feeder No / Name : 203 / Gajanan Maharaj

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4668	.5658	.5601	.4668	.4668	.4668
2	.4715	.4668	.4715	.4668	.4668	.4668	.4668
3	.4715	.4668	.4715	.5228	.4668	.4668	.4668
4	.4715	.4668	.4715	.4668	.5601	.5601	.4668
5	.6602	.6535	.6602	.4668	.6535	.5601	.6535
6	.9431	.9335	.8488	.5601	.7468	.6535	.9335
7	1.1317	1.1203	1.0374	.7468	1.1203	1.0269	1.1203
8	1.4146	1.307	1.3203	1.2136	1.2136	1.307	1.307
9	1.226	1.1203	1.3203	1.307	1.1203	1.307	1.2012
10	.9709	1.0269	1.1317				
11	.8589	.8402	1.0374				
12	.7095	.7468	.8488				
13		.6535	.7545				
14	.5228	.6535	.6602				
15	.5228	.5601	.6602			.6348	.6348
16	.5601	.5601	.6602	.6348	.5601		.6348
17	.6348	.6535	.6602	.7468	.7468		.7842
18	.6722	.8402	.8488	.8402	.7468		.9335
19	.9335	.9335	1.1317	1.1203	.9335	.8589	1.1203
20	.8962	1.0269	1.0374	1.0269	.9335	.9709	1.0456
21	.8962	1.0269	.9431	1.0269	.8402	.9335	.9709
22	.7468	.9335	.8488	.8402	.7468	.7468	.7468
23	.6535	.7468	.7545	.6535	.6535	.7468	.7392
24	.5601	.5658	.6535	.5658	.5601	.5601	.5601
Max	1.4146	1.307	1.3203	1.307	1.2136	1.307	1.307
Min	.4715	.4668	.4715	.4668	.4668	.4668	.4668
Avg	.7565	.7821	.8249	.7648	.7520	.7667	.8028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213309 / O ZONE IT PARK

Feeder No / Name : 204 / LAKSHMI COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4668	.5658	.5601	.4668	.4668	.4668
2	.4715	.4668	.4715	.4668	.4668	.4668	.4668
3	.4715	.4668	.4715	.4668	.4668	.4668	.4668
4	.4715	.4668	.4715	.4668	.5601	.5601	.4668
5	.5658	.5601	.5658	.4668	.6535	.5601	.5601
6	.7545	.7468	.6602	.6535	.7468	.6535	.7468
7	.8488	1.0269	.7545	.7468	.8402	.7468	.9335
8	1.0374	1.1203	1.0374	.9335	1.0269	1.1203	1.0269
9	1.0374	1.1203	1.226	1.0269	.9335	1.1203	.924
10	1.0082	1.0269	1.1317	1.0082			
11	.8589	.9335	.9431	1.0082			
12	.8589	.8402	.9431	.9335			
13		.7468	.8488	.8215			
14	.6348	.6535	.7545	.7095			
15	.6348	.7468	.7545	.7468		.7095	.7842
16	.6722	.7468	.7545	.7468	.8215		.8215
17	.6722	.7468	.7545	.7468	.8215		.7842
18	.7095	.7468	.823	.7468	.8402	.7842	.8215
19	.8962	.9335	.9431	.9335	.9335	.8215	.8962
20	.8215	.8402	.8488	.8402	.9335	.8215	.8962
21	.7922	.8402	.7545	.8402	.8402	.8215	.8589
22	.6535	.7468	.6602	.7468	.7468	.7468	.7468
23	.5601	.6535	.6602	.5601	.5601	.6535	.6535
24	.5658	.5658	.5601	.5658	.5601	.5601	.5601
Max	1.0374	1.1203	1.226	1.0269	1.0269	1.1203	1.0269
Min	.4715	.4668	.4715	.4668	.4668	.4668	.4668
Avg	.7160	.7587	.7650	.7393	.7344	.7106	.7306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213309 / O ZONE IT PARK

Feeder No / Name : 205 / Vitthalnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1867	.1886	.1867	.1867	.1867	.1867
2	.1886	.1867	.1886	.1867	.1867	.1867	.1867
3	.1886	.1867	.1886	.1867	.1867	.1867	.1867
4	.1886	.1867	.1886	.1867	.1867	.1867	.1867
5	.2829	.2801	.2829	.1867	.1867	.1867	.2801
6	.3772		.3772	.2801	.3734	.3734	.3734
7	.4668	.4668	.4715	.3734	.4668	.4668	.3734
8	.5658	.5601	.4715	.4668	.3734	.5601	.4668
9	.3772	.3734	.4715	.4668	.3734	.5601	.462
10	.3734	.3734	.3772				
11	.2614	.2801	.2829				
12	.2241	.2801	.2829				
13		.2801	.2829				
14		.1867	.2829				
15	.1867	.1867	.2829			.2241	.1867
16	.2241	.1867	.2829	.2614	.2241		.2241
17	.1867	.2801	.2829	.1867	.2614		.2614
18	.2614	.2801	.3772	.2801	.2801	.2987	.3361
19	.3361	.3734	.3772	.3734	.3734	.3361	.4481
20	.3361	.3734	.3772	.3734	.3734	.3734	.4108
21	.3361	.3734	.3772	.3734	.3734	.3361	.3734
22	.2801	.3772	.3772	.2801	.3734	.3734	.3734
23	.2801	.2801	.2829	.2801	.2801	.2801	.2772
24	.1867	.1886	.1867	.1886	.1867	.1867	.1867
Max	.5658	.5601	.4715	.4668	.4668	.5601	.4668
Min	.1867	.1867	.1867	.1867	.1867	.1867	.1867
Avg	.2862	.2925	.3143	.2843	.2915	.3119	.3042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213309 / O ZONE IT PARK

Feeder No / Name : 303 / SPCL CO 3

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.1317	.9431	.7545	.9431	1.1317
2	1.1317	.9431	.9431	.9431	.7545	.9431	1.1317
3	1.1317	.9431	.9431	.9431	.7545	.9431	.9431
4	.9431	.9431	.9431	.9431	.7545	.9431	.9431
5	.9431	.9431	.9431	.9431	.7545	.9431	.9431
6	1.1317	.9431	.9431	.9431	.9431	1.1317	1.1317
7	1.1317	.9431	.9431	.9431	.9431	1.1317	.9431
8	1.1317	1.3203	.9431	.9431	1.3203	1.3203	1.3203
9	1.3203	1.3203	1.1317	.9431	1.3203	1.3203	1.3203
10	1.7353	1.5089	1.1317				
11	1.7353	1.6975	1.1317				
12	1.7353	1.6975	1.3203				
13	1.8861	1.6975	1.3203				
14	1.9616	1.6975	1.1317				
15	2.037	1.6975	1.1317			1.7924	1.8861
16	1.8861	1.6975	1.1317	.9808	1.8861		1.9616
17	1.8861	1.6975	1.3203	.9431	1.8861		1.8861
18		1.6975	1.1317	.9431	1.6975	1.6975	1.8107
19	1.7353	1.5089	.9431	.9431	1.6975	1.5089	1.6975
20	1.5844	1.5089	.9431	.9431	1.5089	1.4335	1.5089
21	1.4335	1.3203	1.1317	.9431	1.3203	1.5089	1.358
22	1.3203	1.3203	1.1317	.9431	1.3203	1.3203	1.3203
23	1.1317	1.1317	.9431	.7545	1.3203	1.1317	1.1317
24	1.1317	1.1317	1.1317	.9431	.7545	1.1317	1.1317
Max	2.037	1.6975	1.3203	.9808	1.8861	1.7924	1.9616
Min	.9431	.9431	.9431	.7545	.7545	.9431	.9431
Avg	1.4433	1.3517	1.0767	.9347	1.2050	1.2438	1.3421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213345 / VARDHMAN SWITCHING STATION

Feeder No / Name : 301 / DESAI HOSPITAL

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3734	.4527	.4481	.6036	.3734	.3734
2	.381	.3361	.3395	.3734	.6036	.3361	.3361
3	.381	.3361	.3395	.3361	.5658	.3395	.3361
4	.4572	.3772	.415	.3734	.5658	.3361	.4108
5	.6036	.4854	.4904	.4481	.6036	.4481	.4854
6	.7545	.5601	.6413	.5975	.7545	.6036	.6348
7	.8299	.8589	.7922	.7095	.8299	.7468	.8215
8	.8962	.9808	.9054	.7842	.9808	.8962	1.0082
9	.9709	1.1203	.9054	1.0456	.9431	.9709	1.0456
10	.9335	1.0082	.8962	1.0829	.9709	1.0185	1.0456
11	.8962	1.0082	.8962	.8962	.7842	.9709	.8962
12	.6348	.8962	.6348	.924	.7842	.8589	.7468
13	.5975	.8962	.7095	.7468	.7842	.8215	.7468
14	.5975	.6348	.6348	.7468	.6283	.6413	.5975
15	.4854	.5975	.5975	.5975	.5544	.5975	.5975
16	.4854	.5228	.5975	.6348	.4854	.5975	.5975
17		.4805	.5853	.5975	.5175	.5175	.5658
18	.5228	.5544	.5914	.6413	.5175	.5975	.6722
19	.7023	.7023	.7468	.7167	.7545	.7545	.7468
20	.7545	.7762	.8215	.7545	.7545	.7468	1.8671
21	.7468	.7468	.7392	.7095	.7545	.7468	.7468
22	.7468	.8215	.7468	.6722	.7095	.7468	.7095
23	.6348	.7167	.7468	.6722	.6348	.7167	.6722
24	.5658	.5228	.4854	.4854	.6413	.4481	.4904
Max	.9709	1.1203	.9054	1.0829	.9808	1.0185	1.8671
Min	.381	.3361	.3395	.3361	.4854	.3361	.3361
Avg	.6535	.6797	.6546	.6664	.6969	.6596	.7146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213345 / VARDHMAN SWITCHING STATION

Feeder No / Name : 302 / Runwal

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1478	.1494	.1478	.2641	.1867	.1463
2	.1509	.1463	.1509	.1463	.2263	.1463	.1478
3	.1509	.1463	.1886	.1463	.2263	.1463	.1478
4	.1509	.1829	.1886	.1848	.2263	.1848	.1848
5	.1886	.2195	.1886	.1848	.3018	.1848	.1848
6	.2263	.2561	.2263	.2218	.3018	.2195	.2195
7	.2987	.2926	.2641	.2587	.3018	.2241	.2614
8	.439	.3292	.3018	.2614	.3395	.2587	.4066
9	.439	.2987	.3018	.2987	.3395	.2987	.3361
10	.4435		.3326	.3696	.3361	.3772	.3734
11	.3361	.2987	.4108	.4435	.3361	.3772	.3696
12	.3361	.3361	.3361	.439	.3361	.3772	.3696
13	.2987	.2987	.3361	.3696	.3361	.3018	.2957
14	.2614	.2241	.2957	.3696	.2587	.3018	.2218
15	.2987	.2241	.2614	.2926	.2218	.2641	.2218
16	.1867	.2614	.2587	.2987	.2195	.2218	.2614
17		.2218	.2534	.2987	.2561	.2195	.2241
18	.2987	.2957	.2561	.3018	.2195	.2957	.2241
19	.3326	.3326	.3696	.3395	.2987	.3734	.3361
20	.3395	.2957	.2957	.3772	.3734	.3696	.3326
21	.2926	.2957	.3326	.3361	.2987	.3326	.3696
22	.2957	.2587	.3326	.2987	.3326	.2987	.3361
23	.2195	.2195	.2561	.2987	.2926	.2587	.2218
24	.1848	.1848	.0732	.1848	.3018	.2218	.1848
Max	.4435	.3361	.4108	.4435	.3734	.3772	.4066
Min	.1509	.1463	.0732	.1463	.2195	.1463	.1463
Avg	.2764	.2507	.2650	.2862	.2894	.2684	.2657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213345 / VARDHMAN SWITCHING STATION

Feeder No / Name : 303 / Handewadi Road

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.4937	1.5089	1.4937	1.8861	1.4563	1.4563
2	1.448	1.419	1.3957	1.3817	1.5089	1.3817	1.3817
3	1.3717	1.3817	1.2826	1.2826	1.5089	1.2696	1.2696
4	1.448	1.4563	1.4712	1.358	1.5844	1.4712	1.4712
5	1.5844	1.7551	1.7353	1.4937	2.2634	1.773	1.7551
6	2.0576	1.9993	1.9616	1.8671	3.0178	1.8671	1.8861
7	2.5652	2.5019	2.3011	2.037	3.0178	2.2032	2.1502
8	2.8669	2.7915	2.5274	2.1879	3.0178	2.7161	2.8669
9	2.6886	2.8292	2.7538	2.9874	2.8292	2.8753	2.9874
10	2.6886	2.8006	3.0933	2.9801	3.2861	3.2065	3.1367
11	2.4646	2.838	2.9874	2.6886	2.8753	2.9127	2.9874
12	2.2405	2.4646	2.6139	2.9569	2.726	2.6783	2.8006
13	1.7924	2.2405	2.5393	2.6139	2.4272	2.1125	2.3899
14	1.7924	1.9418	2.2405	2.2405	2.2916	2.037	2.2405
15	1.9791	2.0911	2.0911	2.2405	2.4764	1.8484	2.2405
16	1.9791	2.2032	2.3152	2.2032	2.3525	2.2405	2.3525
17		2.0698	2.3411	2.2405	2.3152	2.2177	2.1285
18	1.8298	2.1807	2.5133	2.8292	1.922	2.0911	2.2779
19	2.4394	2.7721	2.726	2.7538	2.7161	2.8006	2.9874
20	2.452	2.4025	2.6406	2.6029	2.5393	2.6139	2.7161
21	2.2779	2.4143	2.5393	2.5019	2.5652	2.3899	2.5393
22	2.1285	2.2405	2.2634	2.0911	2.2405	2.2634	2.2405
23	1.8671	1.9791	1.8484	2.0911	1.9791	2.1285	2.037
24	1.6221	1.5844	1.6057	1.6221	2.037	1.6057	1.6057
Max	2.8669	2.838	3.0933	2.9874	3.2861	3.2065	3.1367
Min	1.3717	1.3817	1.2826	1.2826	1.5089	1.2696	1.2696
Avg	2.0475	2.1605	2.2207	2.1977	2.3910	2.1733	2.2460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213376 / 22/22 KV NYATI SWITCHING

S/STN

Feeder No / Name : 301 / Kailas Kanchan

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.1132	.1132	.1132	.1132
2	.1132	.1132	.1132	.1132	.1132	.1132	.1132
3	.1132	.1132	.1132	.1132	.1132	.1132	.1132
4	.1132	.1132	.1132	.1132	.1132	.1132	.1132
5	.1132	.1132	.1132	.1132	.1132	.1132	.1132
6	.1132	.1132	.1132	.1132	.1132	.1132	.1132
7	.1132	.1132	.1132	.1132	.1132	.1132	.1132
8	.1132	.1132	.1132	.1132	.1132	.1132	.1132
9	.1132	.1132	.1132	.1132	.1132	.1132	.1132
10	.1132	.1132	.1132	.1132	.1132	.1132	.1132
11	.1132	.1132	.1132	.1132	.1132	.1132	.1132
12	.1132	.1132	.1132	.1132	.1132	.1132	.1132
13	.1132	.1132	.1132	.1132	.1132	.1132	.1132
14	.1132	.1132	.1132	.1132	.1132	.1132	.1132
15	.1132	.1132	.1132	.1132	.1132	.1132	.1132
16	.1132	.1132	.1132	.1132	.1132	.1132	.1132
17	.1132	.1132	.1132	.1132	.1132	.1132	.1132
18	.1132	.1132	.1132	.1132	.1132	.1132	.1132
19	.1132	.1132	.1132	.1132	.1132	.1132	.1132
20	.1132	.1132	.1132	.1132	.1132	.1132	.1132
21	.1132	.1132	.1132	.1132	.1132	.1132	.1132
22	.1132	.1132	.1132	.1132	.1132	.1132	.1132
23	.1132	.1132	.1132	.1132	.1132		.1132
24	.1132	.1132	.1132	.1132	.1132	.1132	.1132
Max	.1132	.1132	.1132	.1132	.1132	.1132	.1132
Min	.1132	.1132	.1132	.1132	.1132	.1132	.1132
Avg	.1132	.1132	.1132	.1132	.1132	.1132	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213376 / 22/22 KV NYATI SWITCHING

S/STN

Feeder No / Name : 302 / Corienthal Club

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.9431	.9431	.8676	.8299	.7922	.7922
2	.8676	.8676	.8676	.8299	.7922	.7545	.7545
3	.8299	.8299	.8299	.7922	.7545	.7167	.7545
4	.7922	.8299	.8299	.7545	.7545	.7545	.7545
5	.7922	.8299	.8299	.7545	.7545	.7167	.7545
6	.9431	.9431	.9431	.8676	.9431	.8299	.9431
7	1.0185	1.0185	1.0185	1.0185	1.0185	.9431	1.0185
8	1.094	1.1317	1.1317	1.0562	1.094	1.0185	1.1694
9	1.1317	1.2449	1.2826	1.094	1.0562	1.0562	1.2449
10	1.0185	1.1317	1.2071	1.094	1.0562	1.0562	1.1317
11	.8299	.9431	1.1694	1.0562	.9054	.9431	.9808
12	.7545	.9808	1.094	1.094	.9054	.8299	.9054
13	.6036	1.0562	1.2071	.9431	1.0185	.8299	.7922
14	.7167	.9808	.9054	.8299	1.0185	.7922	.9054
15	.8299	.9808	1.1694	.9054	1.1317	.8676	.9808
16	.8676	1.0185	1.094	.9808	1.1694	.9431	1.0562
17	.9808	1.1317	.1132	1.1317	1.1317	1.0185	1.1694
18	1.1694	1.2826	1.2826	1.2449	1.2071	1.2826	1.3203
19	1.5089	1.6598	1.6221	1.5466	1.6221	1.6221	1.5089
20	1.4712	1.5466	1.5089	1.4712	1.5844	1.5089	1.4335
21	1.4712	1.5844	1.4335	1.4335	1.358	1.4335	1.4335
22	1.2449	1.3957	1.2826	1.2449	1.3203	1.2826	1.2826
23	1.1317	1.1694	1.094	1.0562	.9431	1.0562	1.1694
24	.9431	1.0185	1.0185	.9054	.8299	.8299	.8299
Max	1.5089	1.6598	1.6221	1.5466	1.6221	1.6221	1.5089
Min	.6036	.8299	.1132	.7545	.7545	.7167	.7545
Avg	.9965	1.1050	1.0783	1.0405	1.0500	.9949	1.0453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213376 / 22/22 KV NYATI SWITCHING

S/STN

Feeder No / Name : 304 / Life Park

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18
HR	Load (MW)
14	.1132
Max	.1132
Min	.1132
Avg	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213376 / 22/22 KV NYATI SWITCHING

S/STN

Feeder No / Name : 305 / Nyati Garden

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4527	.4527	.415	.415	.4527	.415
2	.4527	.415	.415	.3772	.3772	.3772	.3772
3	.415	.415	.415	.3772	.3772	.3772	.3772
4	.415	.415	.415	.3395	.3772	.3772	.3772
5	.415	.415	.415	.3772	.3772	.3772	.3772
6	.4904	.5658	.5658	.4527	.4904	.4904	.4904
7	.6413	.6413	.6413	.5658	.6413	.5658	.6413
8	.7167	.7167	.7167	.6413	.679	.6413	.7167
9	.7545	.7167	.7545	.679	.7167	.7167	.7922
10	.7167	.7545	.7545	.7545	.7167	.7545	.7167
11	.679	.6413	.7167	.679	.6036	.679	.6413
12	.5658	.6413	.679	.6413	.5658	.6036	.6036
13	.5658	.6036	.6413	.6036	.4904	.5658	.5281
14	.5658	.5281	.6036	.6413	.5658	.5658	.5281
15	.5281	.6036	.6036	.6036	.5281	.5658	.5658
16	.5281	.6036	.6036	.6036	.5281	.6036	.5281
17	.5281	.5658	.5658	.6413	.5658	.6413	.5658
18	.5658	.6036	.6413	.6036	.6036	.6413	.6036
19	.7545	.7167	.7545	.7545	.7545	.7922	.7545
20	.7922	.7167	.7167	.7167	.679	.7545	.7545
21	.679	.6413	.679	.679	.679	.7167	.7167
22	.6413	.6036	.6413	.6413	.6413	.6036	.6413
23	.5658	.5281	.5281	.5281	.5658	.5281	.5658
24	.5281	.4904	.5281	.4527	.4527	.4904	.4527
Max	.7922	.7545	.7545	.7545	.7545	.7922	.7922
Min	.415	.415	.415	.3395	.3772	.3772	.3772
Avg	.5831	.5831	.6020	.5737	.5580	.5784	.5721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213376 / 22/22 KV NYATI SWITCHING

S/STN

Feeder No / Name : 307 / KUMAR KERING I/C

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.8676	.8299	.8299	.7922	.8299	.7922
2	.7922	.8299	.7922	.7922	.7545	.7545	.7545
3	.7545	.7922	.7545	.7545	.7545	.7545	.7545
4	.7545	.7922	.7545	.7167	.7167	.7167	.7167
5	.7545	.7922	.7545	.7167	.7167	.7167	.7545
6	.9431	.9431	.9431	.8299	.8676	.8676	.9431
7	1.094	1.094	1.1317	1.0185	1.094	1.094	1.094
8	1.2449	1.2071	1.1694	1.1694	1.2071	1.1317	1.2449
9	1.4335	1.3957	1.2826	1.2071	1.3203	1.2071	1.5089
10	1.4712	1.4712	1.3957	1.3203	1.5089	1.2449	1.4712
11	1.4335	1.358	1.3203	1.358	1.358	1.2071	1.358
12	1.2449	1.2449	1.3203	1.3957	1.358	1.2071	1.3203
13	1.2449	1.1694	1.2449	1.2071	1.1317	1.1317	1.3203
14	1.1317	1.1317	1.0185	1.0562	1.0562	1.0185	1.2071
15	1.0185	1.094	1.0185	1.0185	1.0185	.9431	1.094
16	.9808	.9808	1.0185	.9808	.9808	.9808	1.0185
17	.9808	.9808	1.0185	.9431	.9431	.9054	1.0185
18	1.0185	.9054	1.0185		.9431	.9431	.9808
19	1.2071	1.2826	1.2449	1.2826	1.2449		1.1317
20	1.4712	1.2071	1.2071	1.2071	1.1694	1.1694	1.2826
21	1.2071	1.1317	1.1317	1.1317	1.1694	1.2071	1.2071
22	1.094	1.094	1.094	1.094	1.1317	1.094	1.094
23	1.0185	.9808	1.0185	.9808	.9431	.9431	1.0185
24	.8676	.9431	.8676	.8676	.8299	.8676	.8299
Max	1.4712	1.4712	1.3957	1.3957	1.5089	1.2449	1.5089
Min	.7545	.7922	.7545	.7167	.7167	.7167	.7167
Avg	1.0830	1.0704	1.0562	1.0382	1.0421	.9972	1.0798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213385 / 22/11 KV Kumar Park Infinia

Feeder No / Name : 302 / Park Infinia

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1097	.1086	.1886	.1509	.1509	.1886
2	.1109	.1097	.1097	.2263	.1886	.1509	.1509
3	.1109	.1109	.1097	.1886	.1886	.1509	.1509
4	.1109	.1086	.1086	.1886	.1886	.1509	.1463
5	.112	.1097	.1075	.1886	.1886	.1886	.1509
6	.1478	.2195	.112	.1886	.1886	.1886	.1509
7	.2263	.1886	.1132	.1886	.1886	.1886	.1509
8	.2641	.3018	.1867		.1886	.1886	.1886
9	.3018	.2641	.1867	.2614	.3018	.2641	.2641
10	.2241	.2641	.2263	.2263	.2263	.2641	.2614
11	.1867	.2263	.1867	.2263	.1867	.2263	.1867
12	.1848	.1886	.1867	.2241	.1829	.2241	.1848
13	.1478		.1494	.1848	.1448	.1478	.1463
14	.1097		.1867	.1848	.1109	.112	.1478
15	.1086	.1886	.112	.1829	.1075	.1463	.1097
16	.1417	.1086	.1097	.1886	.1063	.1463	.1086
17	.1387	.104	.1448	.1886	.1063	.1052	.1063
18	.1402	.1433	.1448	.1886	.1075	.1402	.1402
19	.1829	.1478	.1867		.1463	.1494	.1867
20	.181	.1478	.1867		.1463	.1848	.1478
21	.2218	.1829	.1478		.1463	.1886	.1478
22	.1848	.1463				.1886	
23	.1132	.1109				.1509	
24				.1509	.1509	.1509	.1509
Max	.3018	.3018	.2263	.2614	.3018	.2641	.2641
Min	.1086	.104	.1075	.1509	.1063	.1052	.1063
Avg	.1635	.1658	.1481	.1981	.1655	.1728	.1621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213385 / 22/11 KV Kumar Park Infinia

Feeder No / Name : 303 / Park Infinia II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1886	.2263	.2263	.1886
2	.1524	.1524	.1524	.1886	.1886	.1886	
3	.1524	.1524	.1524	.1886	.1886	.1886	.1886
4	.1524	.1524	.1524	.2263	.1886	.1886	.2263
5	.1905	.1524	.1905	.2641	.2641	.3018	.2641
6	.2263	.2286	.2286	.3018	.3018	.3772	.3772
7	.3018	.2667	.2641	.3772	.415	.4527	.5281
8	.415	.415	.3018		.4527	.415	.6036
9	.3772	.3772	.3772	.3018	.3772	.415	.415
10	.4108	.3395	.3395	.3361	.4108	.415	.415
11	.3361	.3395	.3734	.3361	.3734	.3018	.2987
12	.2926	.3018	.3696	.2587	.2561	.3361	.2561
13	.1829		.2561	.2614	.2587	.2241	.2218
14	.1829		.2218	.2241	.1829	.1867	.1867
15	.2195	.2641	.1867	.1848	.1829	.2218	.1867
16	.2195	.1463	.1848	.2263	.181	.1848	.2195
17	.2126	.1478	.2172	.3018	.2126	.2195	.181
18	.1848	.1829	.2534	.415	.181	.2195	.2241
19	.2614	.2614	.3018		.2241	.2641	.2641
20	.2614	.2641	.2641		.2614	.2641	.2641
21	.2641	.2641	.2641		.2641	.3018	.2641
22	.2641	.2263					
23	.2263	.2263				.2263	
24	.1886	.1886	.1886	.1509	.1886	.2263	.2263
Max	.415	.415	.3772	.415	.4527	.4527	.6036
Min	.1524	.1463	.1524	.1509	.181	.1848	.181
Avg	.2444	.2382	.2469	.2629	.2628	.2759	.2857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213386 / 22/11 KV ECP

Feeder No / Name : 201 / Ganga Village

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6722	.6722	.6283	.6348	.6348	.6722
2	.6722	.6722	.6722	.5914	.6348	.6348	.6722
3	.6722		.6348	.5487	.6348	.6348	.6722
4	.6722	.6722	.6348	.5914	.6348	.6348	.6722
5	.6722	.7095	.6722	.5914	.7095	.6722	.8215
6	.7842	.8589	.7842	.6219	.8589	.7842	.9709
7	1.0456	1.0082	1.0082	.7762	1.0829	.8962	1.0082
8	1.1949	1.1203	1.0456	1.0242	1.0829	1.1949	1.1203
9	1.0719	1.2437	1.0456	1.0719	1.1458	1.1458	1.1203
10	.9979	1.1827	1.0829	1.1827	1.0349	1.1088	1.0829
11	.961	1.1458	1.0829	1.1088	1.0349	1.0349	1.0082
12	.9145	1.0349	.9709	1.1458	.924	.924	.8962
13	.7682	1.0719	.9709	.9979	.8501	.961	.9335
14	.7095	.7762	.7468	.8779	.7392	.7545	.7842
15	.6348	.7095	.6653	.7468	.679	.679	.679
16	.6722	.7095	.5914	.7095	.679	.679	.7545
17	.6348	.7095	.6283	.7095	.7167	.7167	.7545
18	.7468	.8215	.8501	.8215	.7922	.8676	.8676
19	.9335	.9979	.9979	1.0082	.9808	1.0185	1.0562
20	.9335	1.0456	.9979	1.0456	1.0185	1.0562	1.0562
21	.9709	1.0349	.9979	1.0829	1.0185	1.0562	1.094
22	1.0456	1.0829	1.1088		1.0082	.9709	1.0082
23	.8962	.9709	.8779	.8962	.9335	.9335	1.0349
24	.7095	.6722	.6722	.6219	.6348	.6348	.6722
Max	1.1949	1.2437	1.1088	1.1827	1.1458	1.1949	1.1203
Min	.6348	.6722	.5914	.5487	.6348	.6348	.6722
Avg	.8328	.9097	.8505	.8435	.8526	.8595	.8922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213386 / 22/11 KV ECP

Feeder No / Name : 202 / S.V Industrial

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7842	.8215	.7392	.7842	.7468	.7842
2	.7468	.7468	.7842	.7392	.7842	.7468	.7468
3	.7468	.7468	.7842	.7095	.7468	.7468	.7468
4	.7468	.7468	.7842	.7392	.7468	.7468	.7468
5	.7468	.7842	.8215	.7682	.7842	.7468	.8215
6	.8215	.8215	.8215	.7682	.8215	.7842	.8962
7	.8589	.8589	.8589	.7762	.8962	.8215	.9709
8	1.0456	.9709	.9709	.924	1.0829	1.0456	1.0456
9	.9511	1.1827	1.307	1.0719	1.2197	1.1827	1.1576
10	.924	1.0719	1.3817	1.1827	1.3306	1.2197	1.1576
11	.924	1.1088	1.307	1.1827	1.2567	1.2936	1.1576
12	.9145	1.0719	1.2696	1.0608	1.1088	1.2567	1.0829
13	.7762	.924	1.0456	.961	.924	.961	.8962
14	.7842	.8871	1.0456	1.0349	.961	1.0608	1.0082
15	.8215	.8962	1.1088	.9709	1.0562	.9877	.9877
16	.7842	.9335	1.1088	.9335	1.0608	1.0974	1.0242
17	.7468	.9709	1.0349	.9709	.9877	1.0242	.961
18	.7842	1.0082	.961	.8589	.9877	.9511	.8413
19	.924	1.0456	1.0349	1.0829	1.134	1.0498	.9511
20	.8962	.9979	.9979	.9335	.9313	.9877	.9511
21	.8962	.9335	.9979	.9335	.9511	.9145	.9412
22	.8589	.8962	.8501	.9335	.8962	.9335	.924
23	.8215	.8589	.8048	.8215	.8215	.8962	.8048
24	.7842	.7842	.8215	.7682	.7842	.7468	.7842
Max	1.0456	1.1827	1.3817	1.1827	1.3306	1.2936	1.1576
Min	.7468	.7468	.7842	.7095	.7468	.7468	.7468
Avg	.8355	.9180	.9885	.9110	.9608	.9562	.9329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213386 / 22/11 KV ECP

Feeder No / Name : 203 / SASANE NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.1949	1.1949	1.1458	1.2323	1.2696	1.2323
2	1.2323	1.1949	1.1949	1.1088	1.2323	1.2696	1.2323
3	1.2323	1.1949	1.1576	1.0719	1.1949	1.2323	1.2323
4	1.2696	1.1949	1.1576	1.134	1.1949	1.2323	1.2323
5	1.3817	1.3443	1.2323	1.2071	1.307	1.307	1.4937
6	1.8671	1.7924	1.531	1.4045	1.643	1.6057	1.9791
7	2.3152	2.2779	2.0165	1.6263	2.2405	2.0911	2.2779
8	2.7633	2.6513	2.4646	2.3285	2.5393	2.6886	2.6513
9	2.3655	2.6612	2.5393	2.5133	2.5133	2.809	2.4272
10	2.1582	2.2177	2.4646	2.5133	2.0698	2.4394	2.1285
11	1.848	2.0328	2.1285	2.3285	1.885	2.1807	1.9791
12	1.6263	1.7372	1.9418	2.0119	1.6632	1.885	1.7924
13	1.4415	1.5893	1.643	1.6632	1.4784	1.5154	1.4937
14	1.307	1.3306	1.3817	1.4784	1.3676	1.358	1.307
15	1.1949	1.2696	1.2197	1.419	1.358	1.2449	1.2826
16	1.307	1.2696	1.2567	1.419	1.2449	1.3957	1.3957
17	1.3443	1.4563	1.5524	1.531	1.2826	1.4712	1.5089
18	1.5684	1.6804	1.7002	1.643	1.5844	1.6221	1.6598
19	1.9791	2.1285	2.1807	2.0911	2.0748	2.037	2.1125
20	2.0538	2.0911	2.0698	2.0538	2.1125	2.0748	2.1879
21	1.9044	2.0165	1.9959	2.0165	1.9239	1.9616	2.1502
22	1.7924	1.7177	1.7741	1.8298	1.8298	1.7924	1.848
23	1.4937	1.4937	1.4784	1.4937	1.531	1.4937	1.4784
24	1.2323	1.1949	1.1949	1.1827	1.2323	1.2696	1.2323
Max	2.7633	2.6612	2.5393	2.5133	2.5393	2.809	2.6513
Min	1.1949	1.1949	1.1576	1.0719	1.1949	1.2323	1.2323
Avg	1.6629	1.6972	1.6863	1.6756	1.6557	1.7186	1.7215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213386 / 22/11 KV ECP

Feeder No / Name : 204 / Kohinoor

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	.0373	.0373	.0373	.0373
2	.0373	.0373	.0373	.0377	.0373	.0373	.0373
3	.0373	.0373	.0373	.0377	.0373	.0373	.0373
4	.0373	.0373	.0373	.0373	.0373	.0373	.0373
5	.0373	.0373	.0373	.0373	.0373	.0373	.0373
6	.0373	.0373	.0373	.0377	.0373	.0373	.0373
7	.0373	.0373	.0373	.0377	.0373	.0373	.0373
8	.0373	.0373	.0373	.0373	.0373	.0373	.0373
9	.0373	.0373	.0754	.0754	.0373	.0377	.0373
10	.037	.0366	.0377	.0747	.0377	.0377	.0373
11	.0373	.0373	.0377	.0747	.0373	.0377	.0373
12	.0377	.0373	.0377	.0373	.0373	.0377	.0373
13	.0377	.0373	.0373	.0373	.0373	.0373	.0373
14	.0377	.0373	.0377	.0377	.0377	.0377	.0373
15	.0377	.0377	.0373	.0373	.0377	.0377	.0377
16	.0377	.0377	.0377	.0373	.0377	.0377	.0377
17	.0377	.0377	.0377	.0373	.0377	.0377	.0377
18	.0377	.0377	.0373	.0373	.0377	.0377	.0377
19	.0377	.0377	.0373	.0373	.0377	.0377	.0377
20	.0377	.0377	.0373	.0373	.0377	.0377	.0377
21	.0754	.0377	.0747	.0373	.0377	.0377	.0377
22	.0373	.0373	.0373	.0373	.0373	.0373	.0373
23	.0373	.0373	.0377	.0373	.0373	.0373	.0377
24	.0373	.0373	.0373	.0377	.0373	.0373	.0373
Max	.0754	.0377	.0754	.0754	.0377	.0377	.0377
Min	.037	.0366	.0373	.0373	.0373	.0373	.0373
Avg	.0390	.0374	.0406	.0421	.0375	.0375	.0374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213396 / JENNURAM SWITCHING STATION

Feeder No / Name : 301 / VISHAL GADH

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						.0876	
7						.0953	
8				.0838		.1029	
9				.1105		.1067	
10	.1334			.1143		.1143	
11		.1257	.1181	.1448		.1067	
12		.1257		.1448		.0914	
13				.141		.0762	
14	.0724	.0648	.061	.1143	.1105	.061	.0648
15	.0533	.0495	.0495	.1105	.0762	.1029	.0724
16	.061	.0686	.0686	.1029	.0686		.0686
17	.0762	.1219	.1219	.1067	.0762		.061
18	.0724	.1219	.1219		.08		.1029
19	.1257	.1143	.1143		.1219		.1257
20	.1143	.1105	.1105		.1067		
21		.1143	.1143				
23				.0838			
24	.1143	.08					.0991
Max	.1334	.1257	.1219	.1448	.1219	.1143	.1257
Min	.0533	.0495	.0495	.0838	.0686	.061	.061
Avg	.0914	.0997	.0978	.1143	.0914	.0945	.0849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213408 / KUMAR KERING

Feeder No / Name : 301 / KUMAR PRINCE TOWN
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3395	.3395	.5281	.3395	.3772	.3772
2	.3395	.3018	.3018	.4527	.3395	.3395	.3395
3	.3395	.3018	.3018	.4527	.3395	.3395	.3395
4	.3395	.3395	.3395	.415	.3772	.3772	.3772
5	.3772	.3772	.3772	.415	.4527	.415	.3772
6	.4527	.4904	.3772	.415	.5281	.415	.4527
7	.4904	.5281	.4527	.3772	.5658	.4527	.5281
8	.6413	.6413	.4904	.4904	.7167	.4904	.6413
9	.6413	.7167		.6036	.7545	.6036	.7545
10	.3772	.5658	.6413	.6036	.8299	.5658	.7545
11	.7545	.7167	.5658	.679	.7545	.5658	.6036
12	.6413	.6036	.5658	.6036	.7545	.5658	.7545
13	.5658	.5658	.5658	.5658	.6036	.5658	.6036
14	.4904	.5658	.4904	.5658	.4904	.3772	.6036
15	.5658	.4904	.3772	.5658	.5658	.3772	.4904
16		.4904	.4904	.5658	.4904	.3772	.4527
17		.4904	.5658	.4904	.415	.3772	.3772
18		.4904	.4527	.415	.415	.3772	.4527
19		.5658	.5658	.5658	.6036	.5281	.679
20		.6036	.5658	.6036	.5658	.4904	.679
21		.5658	.5658	.5658	.4904	.4904	.6036
22	.4904	.4904	.5658	.4904	.4904	.4904	.4904
23	.3772	.415	.4904	.415	.415	.415	.4904
24	.3772	.3395	.3772	.5658	.3772	.415	.3772
Max	.7545	.7167	.6413	.679	.8299	.6036	.7545
Min	.3395	.3018	.3018	.3772	.3395	.3395	.3395
Avg	.4799	.4998	.4707	.5171	.5281	.4495	.5250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213408 / KUMAR KERING

Feeder No / Name : 302 / KUMAR PALMS SPRING

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0686	.0754	.0754	.0754	.0754
4	.0754	.0754	.0754	.0754	.0754	.0754	.0754
5	.0754	.0754	.0754	.0754	.0754	.0754	.0754
6	.0754	.0754	.0754	.0754	.0754	.0754	.0754
7	.1132	.1132	.1132	.0754	.1132	.1132	.1132
8	.1132	.1132	.1132	.1132	.1132	.1132	.1132
9	.1509	.1509		.1132	.1509	.1509	.1509
10	.1886	.1509	.1132	.1509	.1509	.1509	.1509
11	.1509	.1509	.1509	.1132	.1509	.1509	.1509
12	.1509	.1132	.1509	.1509	.1509	.1509	.1509
13	.1509		.1509	.1132	.1509	.1509	.1509
14	.1509	.1132	.1509	.1509	.1509	.1509	.1509
15	.1509	.1132	.1132	.1132	.1509	.1509	.1132
16	.1509	.1132	.1132	.1132	.1132	.1509	.1132
17	.1509	.1132	.1132	.1132	.1132	.1509	.1132
18	.1509	.1132	.1132	.1132	.1132	.1509	.1132
19	.1509	.1509	.1509	.1132	.1132	.1509	.1132
20	.1509	.1509	.1509	.1132	.1132	.1509	.1132
21	.1132	.1509	.5658	.1132	.1132	.1132	.1132
22	.1132	.1132	.1509	.1132	.1132	.1132	.1132
23	.1132	.1132	.1132	.1132	.1132	.1132	.1132
24	.1132	.1132	.1132	.1132	.1132	.1132	.1132
Max	.1886	.1509	.5658	.1509	.1509	.1509	.1509
Min	.0754	.0754	.0686	.0754	.0754	.0754	.0754
Avg	.1242	.1132	.1342	.1069	.1147	.1226	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213408 / KUMAR KERING

Feeder No / Name : 303 / Cavalcade

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.415	.381	.381	.381
2	.3429	.3429	.381	.3772	.3429	.3429	.3429
3	.3429	.3429	.3429	.3772	.3429	.3429	.3429
4	.381	.381	.3429	.3395	.381	.3429	.381
5	.381	.381	.381	.3395	.381	.381	.381
6	.4191	.4191	.4191	.3772	.4191	.4572	.4191
7	.4572	.4572	.4572	.3395	.4572	.4954	.4954
8	.5335	.5335	.4954	.4904	.5335	.5335	.5716
9	.5716	.6097		.4904	.5716	.6097	.6097
10	.6097	.6036	.6097	.5658	.6478	.5716	.6097
11	.5716	.5658	.6097	.6413	.5716	.6097	.6097
12	.4191	.4904	.6097	.5658	.4954	.6097	.5335
13	.4572		.4954	.4904	.4572	.4954	.5335
14	.4572	.415	.4191	.4904	.4191	.4954	.4954
15	.4572	.415	.4191	.3772	.4191	.4191	.4954
16	.3772	.415	.4527	.4191	.4191	.4572	.4191
17	.415	.3772	.4527	.4572	.4572	.4572	.4954
18	.4527	.415	.415	.4572	.4191	.4572	.4572
19	.4904	.5281	.5281	.5335	.4954	.5716	.5281
20	.4904	.4904	.4904	.4954	.4954	.5335	.4904
21	.4904	.4904	.4904	.4954	.4572	.4954	.4904
22	.4954	.4572	.4527	.4572	.4572	.4572	.4572
23	.4191	.4191	.415	.4191	.4191	.4191	.4191
24	.381	.381	.4191	.415	.381	.381	.381
Max	.6097	.6097	.6097	.6413	.6478	.6097	.6097
Min	.3429	.3429	.3429	.3395	.3429	.3429	.3429
Avg	.4497	.4483	.4556	.4511	.4509	.4715	.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213409 / Margosa

Feeder No / Name : 301 / PEERWADI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.415	.415	.3772	.3772	.415	.415
2	.3772	.3772	.3772	.3395	.3395	.3772	.3772
3	.3395	.3395	.3395	.3018	.3018	.3395	.3395
4	.3018	.3018	.415	.2641	.3395	.3018	.3018
5	3.546	.4527	.415	.3772	.4527	.415	.415
6	.5658	.5658	.4527	.4527	.6036	.5281	.6036
7	.679	.679	.4904	.5281	.7167	.679	.7167
8	.679	.7545	.679	.6413	.7922	.7167	.7545
9	.7545	.7922	.7167	.7922	.7545	.7545	.7545
10	.7167	.7545	.7922	.8299	.7545	.7167	.7167
11	.679	.7167	.8299	.8299	.7922	.7545	.7167
12		.7167	.7167	.7922	.679	.7545	.6413
13	.7922	.679	.679	.679	.6036	.679	.5281
14	.5658	.5281	.6036	.6036	.5281	.5658	.5658
15	.5664	.5281	.5658	.5658	.5281	.5281	.6036
16	.6036	.5281	.6036	.5281	.5281	.5658	.5658
17	.5658	.4904	.5658	.6036	.5658	.5658	.6036
18	.6413	.6036		.6036	.5281	.5281	.6036
19	.7167	.7167	.7922	.679	.679	.7167	.7545
20	.7167	.679	.7922	.7545	.7167	.679	.7167
21	.6036	.679	.7167	.7167	.679	.679	.6413
22	.6036	.6413	.6036	.6413	.6036	.6413	.6036
23	.5281	.6036	.4904	.5658	.5658	.6036	.5658
24	.4527	.4527	.4527	.415	.415	.4527	.4527
Max	3.546	.7922	.8299	.8299	.7922	.7545	.7545
Min	.3018	.3018	.3395	.2641	.3018	.3018	.3018
Avg	.7135	.5831	.5872	.5784	.5768	.5816	.5816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213409 / Margosa

Feeder No / Name : 302 / Suvarna Mangal

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.8676	.8676	.8299	.9808	1.0185	1.0185
2	.7545	.8299	.8299	.7922	.9054	.9808	.9808
3	.7167	.7922	.8676	.7545	.7545	.9054	.9431
4	.6413	.6036	.8299	.7167	.7167	.9054	.9054
5	.9054	.9054	.8676	.9054	.9054	.9431	1.0185
6	1.3957	1.2449	1.1317	1.0562	1.1317	1.358	1.2071
7	1.6598	1.5844	1.4712	1.2826	1.6221	1.4335	1.5466
8	1.7353	1.7353	1.5844	1.6221	1.6221	.1132	1.6598
9	1.5844	1.6221	1.5466	1.5466	1.5089	1.6598	1.358
10	1.3203	1.2826	.8299	1.5089	1.358	1.4712	1.2449
11	1.1317	1.3203	1.2071	1.2826	1.1694	1.358	1.1694
12		1.094	1.094	1.0185	.8299	1.2071	1.0185
13	1.2449	.9054	.9808	1.1317	.9808	1.0562	.9808
14	1.0185	.9054	1.0562	1.0562	1.0562	1.0185	.9431
15	1.0185	.9054	.9431	1.0185	1.0562	.8299	.9808
16	.9054	.9054	.9054	.9054	.9808	.9431	.9431
17	.8676	.8676	.9431	.9054	.9431	.8676	.9054
18	.8676	1.0562	1.0562	.9808	.9054	1.0562	.9808
19	1.3203	1.4712	1.3957	1.2071	1.4335	1.3957	1.4335
20	1.2449	1.4335	1.4712	1.2826	1.3957	1.4335	1.4712
21	1.2071	1.358	1.3203	1.1317	1.2071	1.358	1.3957
22	1.2071	1.1694	1.0562	1.094	1.2071	1.3203	1.2826
23	1.1317	.9054	.9431	1.0562	1.1694		.9431
24	.8299	.9054	.9054	.8676	1.0185	1.0562	1.0562
Max	1.7353	1.7353	1.5844	1.6221	1.6221	1.6598	1.6598
Min	.6413	.6036	.8299	.7167	.7167	.1132	.9054
Avg	1.1087	1.1113	1.0877	1.0814	1.1191	1.1169	1.1411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213417 / Atur

Feeder No / Name : 301 / Pisoli (Matoshree)

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.8383	.9907	.9907	.9907	.9145	1.0082
2	.9145	.9145	.9145	1.0669	1.0669	.8383	1.1203
3	.8383	.9907	.9907	1.1431	1.1431	.9145	1.1203
4	.9907	.9526	1.0669	1.0669	1.2193	.9526	1.1949
5	1.0669	1.0669	1.105	.9526	1.2955	1.0288	1.307
6	1.2193	1.1431	1.0288	.9907	1.2955	1.105	1.531
7	1.4098	1.2955	1.1431		1.3717	1.3717	1.5684
8	1.4861	1.5242	1.3336	1.448	1.3817	1.5242	1.5684
9	1.5524	1.3717	1.6004	1.5623	1.4937	1.5089	1.5684
10	1.4045	1.3336	1.7147	1.6766	1.7177	1.5089	1.5684
11	1.3443	1.6004	1.5242	1.5242	1.4937	1.643	1.6804
12	1.3443	1.2955	1.5242	1.5242	1.6057	1.4937	1.4937
13	1.1203	1.3336	1.2955	1.448	1.4937	1.1203	1.1949
14	1.1203	1.3336	1.3717	1.2574	1.307	1.1203	1.2696
15	1.1431	1.2193	1.448	1.1431	1.2955	1.1203	1.3443
16	1.2955	1.1431	1.5242	1.1431	1.2955	1.307	1.307
17	1.3717	1.2193	1.2955	1.1812	1.2193	1.3817	1.2696
18	1.2193	1.3717	1.3717	1.2955	1.2193	1.419	1.2696
19	1.5242	1.6004	1.6766	1.448	1.6385	1.6057	1.5684
20	1.448	1.448	1.5242	1.448	1.5623	1.419	1.448
21	1.3717	1.3336	1.2574	1.2193	1.5242	1.3817	1.2955
22	1.2193	1.2574		1.2193	1.2193	1.1949	1.2193
23	1.0669	1.1431	1.1431	.9526	.9907	.9335	1.105
24	1.0669	.9145	.9145	.9526		.9907	.9335
Max	1.5524	1.6004	1.7147	1.6766	1.7177	1.643	1.6804
Min	.8383	.8383	.9145	.9526	.9907	.8383	.9335
Avg	1.2304	1.2352	1.2939	1.2458	1.3409	1.2416	1.3314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213417 / Atur

Feeder No / Name : 303 / Shree Sai

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.2955	1.9052	1.2955	.9907	2.0576	2.3152
2	1.6766	1.1431	1.829	1.2193	.9526	1.9052	2.2405
3	1.6004	1.0669	1.5623	1.0669	.8383	1.829	2.3152
4	1.448	.9907	1.3336	.9907	.9145	1.6004	2.0538
5	1.2955	1.0669	1.105	.9145	.9907	1.3717	1.9418
6	1.1431	.9526	.8764		1.0669	.8002	1.7924
7	1.0288	1.448	1.1431			1.0288	1.6804
8	1.5242	2.0576	1.4098	.4572		1.5242	1.531
9	1.9418	2.4387	2.6673	1.2193		2.2405	2.3899
10	2.2405	2.5911	2.5149	1.2955		2.838	2.8753
11	2.4646	2.6673	2.7435	1.2193	3.2487	2.6139	2.9127
12	2.6787	2.8959	3.1245	1.2193	2.6139	2.3152	2.3152
13	2.838	3.0483	2.8197	1.1431	2.9874	2.8006	3.1367
14	1.8671	3.2388	2.6673	1.105	3.3608	1.8671	2.9874
15		2.7435	2.8959	.9145	2.8959	2.6139	2.5766
16	2.4387	2.5911	.5335	.9145	2.9721	2.0538	2.6886
17	.8383	2.21	1.0669	.8383	2.6673	1.9418	2.5393
18	1.6004	1.9814	2.7054	.8764	2.5911		
19	1.2193	1.5242	1.6385	1.0288	2.3243	1.8298	1.7924
20	1.7528	1.7528	1.6004		1.6004	1.9418	1.9052
21	1.829	2.0957	2.6673	.9145	1.6766	1.9044	1.9814
22	1.6004		2.4768	.8764	1.829	2.0165	2.0576
23	1.448	2.2862	1.8671	.8002	1.9814	2.0911	2.21
24	1.9052	1.2574	1.9814	1.2574	.9145	2.1719	2.4272
Max	2.838	3.2388	3.1245	1.2955	3.3608	2.838	3.1367
Min	.8383	.9526	.5335	.4572	.8383	.8002	1.531
Avg	1.7482	1.9715	1.9640	1.0270	1.9709	1.9721	2.2898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213420 / Cavalcade

Feeder No / Name : 301 / Raheja Vista

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2667	.3048	.3048		.381	
10	.3429	.381	.381		.4572	
11	.4191	.4572	.4191		.381	
12	.4572				.3048	
13			.3048			
15	.381			.381		
16				.3048		.3048
17						.381
Max	.4572	.4572	.4191	.381	.4572	.381
Min	.2667	.3048	.3048	.3048	.3048	.3048
Avg	.3734	.381	.3524	.3429	.381	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR (I) SUB-DN.[745] BU 4745

Substation No/ Name :- 213420 / Cavalcade

Feeder No / Name : 302 / Raheja Vista III

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10					.1524	
11		.1524	.1524			
12	.1524				.1524	
13			.1524			
15	.1524			.1524		
16				.1143		.1524
17						.1524
Max	.1524	.1524	.1524	.1524	.1524	.1524
Min	.1524	.1524	.1524	.1143	.1524	.1524
Avg	.1524	.1524	.1524	.1334	.1524	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 201 / MAGARPATTA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	1.0374	.8573	.9431			.9431
2	.9431	.9431	.9431	.8488			1.0374
3	1.0426	.9431	.9431	.8488			.9431
4	.9431	.9431	.9431	.9431			.9431
5	1.0374	1.1317	1.0374	1.0374			1.0374
6	1.226	1.226	1.1317	1.0374			1.1317
7	1.4146	1.3203	1.226	1.1317	2.7073	1.2136	1.3203
8	1.6032	1.6032	1.3203	1.226	3.1741		1.5089
9	2.0748	1.8861	1.6975	1.5089	3.2674	1.9605	1.9805
10	1.9805	1.8671	1.6975	1.6032	1.7918	1.9805	1.9805
11	2.1691	1.9605	1.7918	1.5089	1.8861	1.9805	1.8861
12	1.9805	1.8671	1.6032	1.5089	1.8861	1.9805	1.8861
13	1.7918	1.8671	1.6032	1.5089	1.7918	1.7918	1.8861
14	1.8861		1.5089	1.3203	1.6975	1.7918	1.9805
15	1.8861	1.8671	1.6032	1.3203	1.6975	1.8861	1.8861
16				1.3203		1.7918	1.8004
17	1.7737	1.7737		1.3203	1.8671	1.7918	1.8004
18				1.5089	1.6804	1.7918	1.8004
19	2.0538		1.7737	3.3008	1.9605	1.9805	1.9719
20		1.6804	1.587	3.2065	1.7737	1.7918	1.6289
21	1.6804	1.587	1.4937	2.8292	1.4937	1.6032	1.5432
22	1.5089	1.4146	1.3203			1.4146	1.3717
23	1.226	1.226	1.226		1.1203	1.3203	1.1145
24	1.0374	1.1317	1.1317	1.1317	1.8671	1.0269	1.1317
Max	2.1691	1.9605	1.7918	3.3008	3.2674	1.9805	1.9805
Min	.9431	.9431	.8573	.8488	1.1203	1.0269	.9431
Avg	1.5379	1.4638	1.3543	1.4961	1.9789	1.7116	1.5214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 202 / HADAPSAR MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.8488	.9431	.8488			.8488
2	.8488	.7545	.9431	.7545			.8488
3	.8488	.7545	.9431	.7545			.8488
4	.8488	.7545	.8488	.8488			.8488
5	1.1317	1.1317	1.0374	.9431			1.0374
6	1.4632	1.5089	1.0374	1.1317			1.4146
7	1.8861	1.6975	1.6032	1.3203	1.7737	1.4937	1.7918
8	2.0748	1.8861	1.7918	1.6975	1.8671		1.9805
9	1.8861	1.9805	1.8861	1.8861	1.9605	2.0538	1.9805
10	1.6975	1.8671	1.6975	1.9805	1.7918	1.8861	1.7918
11	1.6975	1.7737	1.6975	1.8861	1.6975	1.6032	1.6975
12	1.6975	1.6804	1.6975	1.7918	1.6975	1.6975	1.6975
13	1.4146	1.4937	1.5089	1.6032	1.4146	1.4146	1.5089
14	1.3203		1.3203	1.4146	1.3203	1.3203	1.4146
15	1.226	1.307	1.3203	1.3203	1.3203	1.226	1.4146
16				1.3203		1.4146	1.3717
17	1.307	1.4003		1.4146	1.4003	1.4146	
18				1.4146	1.4937	1.5089	1.4575
19	1.8671		1.8671	1.7918	1.8671	1.8861	1.8004
20		1.8671	1.8671	1.6975	1.7737	1.8861	1.7147
21	1.587	1.587	1.6804	1.6032	1.587	1.6975	1.5432
22	1.3203	1.4146	1.4146			1.4146	1.286
23	1.1317	1.1317	1.1317		1.1203	1.226	1.0288
24	1.0374	1.6975	.9431	1.0374	.9335	.9335	1.0374
Max	2.0748	1.9805	1.8861	1.9805	1.9605	2.0538	1.9805
Min	.8488	.7545	.8488	.7545	.9335	.9335	.8488
Avg	1.3877	1.4269	1.3895	1.3846	1.5637	1.5339	1.4072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 206 / MUNDHAWA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	.0943			.0943
2	.0943	.0943	.0943	.0943			.0943
3	.0943	.0943	.0948	.0943			.0943
4	.0943	.0943	.0943	.0943			.0943
5	.0943	.0948	.0943	.0943			.0943
6	.0943	.0943	.0943	.0943			.0943
7	.0943	.0943	.0943	.0943	.0934	.0934	.0943
8	.0943	.0943	.0943	.0943	.0934		.0943
9	.0943	.0943	.0943	.0943	.0934	.0934	.0943
10	.0943	.0934	.0943	.0943	.0943	.0943	.0943
11	.0943	.0934	.0943	.0943	.0943	.0943	.0943
12	.0943	.0934	.0943	.0943	.0943	.0943	.0943
13	.0943	.0934	.0943	.0943	.0943	.0943	.0943
14	.0943		.0943	.0943	.0943	.0943	.0943
15	.0943	.0934	.0943	.0943	.0943	.0943	.0943
16				.0943		.0943	.0857
17	.0934	.0934		.0943	.0934	.0943	.0857
18				.0943	.0934	.0943	.0857
19	.0934		.0934	.0943	.0934	.0943	.0857
20		.0934	.0934	.0943	.0934	.0943	.0857
21	.0934	.0934	.0934	.0943	.0934	.0943	.0857
22	.0943	.0943	.0943			.0943	.0857
23	.0943	.0943	.0943		.0934	.0943	.0857
24	.0943	.0943	.0943	.0943	.0934	.0934	.0943
Max	.0943	.0948	.0948	.0943	.0943	.0943	.0943
Min	.0934	.0934	.0934	.0943	.0934	.0934	.0857
Avg	.0942	.0940	.0942	.0943	.0937	.0941	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 207 / SASANE NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.2829			.3772
2	.2829	.2829	.2829	.2829			.3772
3	.2829	.2829	.2829	.2829			.4715
4	.2829	.2829	.2829	.3772			.3772
5	.4715	.4715	.3772	.4715			.5658
6	.6602	.0566	.5658	.4715			.6602
7	.7545	.6602	.7167	.5658	.7468	.6535	.7545
8	.9431	.7545	.8488	.7545	.9335		.9431
9	.9431	.8488	.8488	.9431	.8402	.9335	.8488
10	.6602	.6535	.7545	.8488	.7545	.8488	.6602
11	.5658	.6535	.6602	.7545	.5658	.6602	.6602
12	.4715	.5601	.5658	.6602	.5658	.5658	.4715
13	.3772	.5601	.4715	.5658	.4715	.4715	.4715
14	.3772		.3772	.4715	.3772	.4715	.3772
15	.3772	.3734	.3772	.3772	.3772	.3772	.3772
16				.4715		.4715	.3429
17	.3734	.4668		.4715	.4668	.4715	.4287
18				.5658	.4668	.5658	.4287
19	.5601		.6535	.5658	.5601	.6602	.6001
20		.6535	.6535	.6602	.6535	.6602	.6859
21	.5601	.6535	.6535	.5658	.6535	.6602	.6001
22	.6602	.5658	.5658			.6602	.6001
23	.5658	.4715	.4715		.4668	.5658	.4287
24	.4715	.4715	.4715	.3772	.3734	.3734	.4715
Max	.9431	.8488	.8488	.9431	.9335	.9335	.9431
Min	.2829	.0566	.2829	.2829	.3734	.3734	.3429
Avg	.5247	.5050	.5361	.5358	.5796	.5924	.5408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 208 / INCAB

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.7545	.3772	.5658			.4715
2	.6602	.5658	.6602	.5658			.4715
3	.7316	.7167	.6602	.4715			.3772
4	.6602	.5658	.6602	.4715			.2829
5	.6602	.5658	.6602	.4715			.3772
6	.6602	.7167	.6602	.3772			
7	.7356	.5658	.6602	.3772	.3734	.5601	.6602
8	.6602	.5658	.6602	.2829	.3734		.6602
9	.7545	.6602	.5658	.1886	.3734	.5601	
10	.4715	.7468	.6602	.3772	.5658	.6602	.5658
11	.6602	.7468	.5658	.3772	.4715	.5144	.5658
12	.7545	.7468	.6602	.3772	.5658	.6602	.5658
13	.6602	.7468	.6602	.3772	.4715	.5658	.5658
14	.7545		.7545	.3772	.5658	.5658	.4715
15	.7545	.6535	.6602	.3772	.4715	.6602	.5658
16				.3772		.5658	.5144
17	.7468	.4668		.3772	.3734	.5658	.5144
18				.3772	.3734	.6602	.5144
19	.5601		.5601	.2829	.2801	.6602	.5144
20		.3734	.5601	.3772	.2801	.6602	.4287
21	.5601	.3734	.5601	.3772	.3734	.5281	.5144
22	.7545	.6602	.6602			.5658	.5144
23	.6602	.5658	.7167		.3734	.4715	.5144
24	.4715	.5658	.5658	.5658	.3734	.3734	.4715
Max	.7545	.7545	.7545	.5658	.5658	.6602	.6602
Min	.4715	.3734	.3772	.1886	.2801	.3734	.2829
Avg	.6663	.6162	.6261	.3986	.4162	.5763	.5046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 209 / SATAVWADI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4146		1.6975	1.5089			1.5089
2	1.4146		1.5089	1.3203			1.4146
3	1.4146			1.3203			1.4146
4	1.4146	1.226	1.4146	1.6975			1.4146
5	1.8861	1.6975	1.8861	2.0748			1.6975
6	2.9235	2.1691	2.452	2.2634			2.452
7	3.4894	2.5463	2.9235	2.6406	3.3608	4.201	3.1121
8	3.9232	2.6406	3.5837	3.3951	3.7342		3.9609
9	3.9609	2.8292	3.5837	3.678	3.5475	5.0412	3.4894
10	3.0178	2.5206	3.2065	3.3008	3.0178	4.5268	2.9235
11	2.7349	2.2405	3.0178	3.2065	2.6406	4.1495	2.7349
12	2.3577	2.0538	2.7349	3.0178	2.5463	3.5837	2.452
13	2.1691	1.8671	2.452	2.5463	2.2634	3.1121	2.3577
14	2.0748		2.0748	2.1691	2.0748	3.0178	2.2634
15	1.9805	2.1472	2.0748	2.0748	1.9805	2.9235	2.0748
16				1.9805		3.0178	1.9719
17	1.9605	2.1472		2.0748	2.2405	2.0748	2.0576
18				2.3577	2.4272	2.3577	2.3148
19	2.8006		3.3608	3.0178	2.894	3.2065	3.0007
20		3.3608	2.9874	2.9235	4.5744	3.2065	2.915
21	2.7073	2.9874	2.9874	2.7349	4.0143	3.0178	2.6578
22	2.6406	2.5463	2.6406			2.5463	2.4006
23	2.1691	2.1691	2.2257		2.9874	2.1691	1.9719
24	1.7918	1.7918	1.7918	1.6975	1.7737	2.5206	1.7918
Max	3.9609	3.3608	3.5837	3.678	4.5744	5.0412	3.9609
Min	1.4146	1.226	1.4146	1.3203	1.7737	2.0748	1.4146
Avg	2.3927	2.2906	2.5302	2.4091	2.8798	3.2160	2.3480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 302 / IND ESTATE

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748	1.6975	1.8861	1.8861			1.8861
2	2.0748	1.6975	1.8861	1.8861			1.8861
3	1.8861	1.6975	1.8861	1.8861			1.8861
4	1.8861	1.8861	1.8861	1.8861			2.0748
5	1.8861	1.8861	1.8861	1.8861			2.0748
6	1.8861	1.8861	2.0748	1.8861			2.0748
7	2.0748	1.8861	2.0748	2.0748	2.0538	1.8671	1.8861
8	2.0748	2.2634	2.0748	3.0178	2.2405		2.2634
9	2.2634	2.6406	2.6406	2.2634	2.6139	2.9874	2.6406
10	2.2634	2.9874	3.0178	2.452	3.2065	3.3951	3.2065
11	2.452	3.3608	3.2065	2.8292	3.3951	3.3951	3.5837
12	2.452	2.9874	3.3951	3.0178	3.2065	3.2065	3.5837
13	2.2634	2.9874	3.2065	2.6406	3.0178	3.2065	3.2065
14	2.452		3.2065	2.452	3.2065	3.2065	3.7723
15	2.452	3.1741	3.5837	2.2634	3.3951	3.7723	3.5837
16				2.2634		3.5837	3.4294
17	2.2405	3.1741		2.2634	3.1741	3.1093	2.915
18				2.2634	2.9874	2.8292	2.7435
19	1.8671		2.2405	2.2634	2.6139	2.8292	2.4006
20		2.6139	2.2405	2.0748	2.2405	2.2634	2.4006
21	1.6804	2.4272	2.2405	2.0748	2.0538	2.2634	2.2291
22	1.8861	2.2634	2.2634			2.0748	2.0576
23	1.6975	2.0748	2.0748		1.8671	1.8861	1.8861
24	1.8861	1.6975	1.8861	1.8861	1.8671	1.8671	1.8861
Max	2.452	3.3608	3.5837	3.0178	3.3951	3.7723	3.7723
Min	1.6804	1.6975	1.8861	1.8861	1.8671	1.8671	1.8861
Avg	2.0809	2.3644	2.4218	2.2462	2.6962	2.8084	2.5649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 303 / ST MARY NO 1

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.3772	.3772			.5658
2	.3772	.3772	.679	.3772			.5658
3	.5658		.3772	.3772			.5658
4	.5658	.3772	.3772	.3776			.5658
5	.5658	.5658	.5658	.3772			.5658
6	.7545	.7545	.5658	.5658			.7545
7	.7545	.7545	.7545	.5658	.7468	.5601	.7545
8	.9431	.9431	.9431	.7545	.9335		.9431
9	.9431	1.1317	.9431	.9431	.9335	.9335	.9431
10	.7545	.9335	.7545	.9431	.7545	.9431	.7545
11	.9431	.7468	.9431	.9431	.7545	.9431	.9431
12	.9431	.7468	.9431	.9431	.7545	.9431	.7545
13	.7545	.7468	.7545	.9431	.7545	.7545	.7545
14	.7545		.7545	.9431	.7545	.7545	.7545
15	.7545	.7468	.7545	.7545	.7545	.7545	.7545
16				.7545		.7545	.6859
17	.7468	.7468		.7545	.7468	.7545	.6859
18				.9431	.9335	.7545	.8573
19	.9335		.9335	.9431	.9335	1.1317	1.0288
20		.9335	.9335	.9431	.9335	.9431	.8573
21	.9335	.9335	.9335	.9431	.9335	.9431	.8573
22	.7545	.7545	.7545			.7545	.6859
23	.5144	.5658	.5658		.5601	.5658	.5144
24	.5658	.5658	.5658	.5658	.5601	.5601	.7545
Max	.9431	1.1317	.9431	.9431	.9335	1.1317	1.0288
Min	.3772	.3772	.3772	.3772	.5601	.5601	.5144
Avg	.7238	.7403	.7226	.7288	.7964	.8087	.7445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 307 / KPC FEEDER

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.7545	.5658	.3772			.5658
2	.5658	.5658	.5658	.3772			.5658
3	.3772	.5658	.3772	.3772			.5658
4	.3772	.3772	.3772	.3772			.5658
5	.3772		.5658	.5658			.7545
6	.5658	.5658	.5658	.5658			.7545
7	.5658	.5658	.3772	.5658	.3734	.5601	.9431
8	.7545	.9431	.9431	.5658	.5601		1.1317
9	.9431	1.1317	.9431	.5658	.7468	1.1203	1.1317
10	1.6975	1.307	1.1317	.3772	.9431	1.1317	1.3203
11	1.3203	1.307	1.3203	.3772	1.1317	1.8861	1.1317
12	1.5089	1.1203	1.6975	.3772	1.6975	2.0748	1.5089
13	1.1317		.9431	.5658	2.0748	1.5089	.9431
14	1.5089		1.6975	.3772	2.0748	.9431	1.8861
15	1.1317	2.0538	1.6975	.3772	1.8861	1.8861	1.6975
16				.3772		1.1317	1.5432
17	.9335	1.1203		.3772	.9335	1.1317	1.2003
18				.3772	.9335	.7545	1.2003
19	.7468		.7468	.3772	.9335	.9431	1.0288
20		.7468	.5601	.3772	.7468	.7545	.6859
21	.9335	.7468	.5601	.3772	.7468	.9431	.6859
22	1.1317	.7545	.5658			.7545	.8573
23	1.3203	.679	.5658		.7468	.5658	.6859
24	.5658	.7545	.5658	.5658	.3734	.5601	.5658
Max	1.6975	2.0538	1.6975	.5658	2.0748	2.0748	1.8861
Min	.3772	.3772	.3772	.3772	.3734	.5601	.5658
Avg	.8969	.8922	.8254	.4372	1.0564	1.0971	.9967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 309 / TATA

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.5658	.3772	.3772			.5658
2	.5658	.5658	.3772	.3772			.5658
3	.5658	.5658	.3772	.3772			.5658
4	.3772	.5658	.3772	.3772			.5658
5	.3772	.5658	.3772	.3772			.3772
6	.3772	.5658	.3772	.3772			.3772
7	.679	.5658	.3772	.3772	.3734	.3734	.3772
8	.5658	.5658	.3772	.3772	.3734		.3772
9	.7545	.5658	.3772	.3772	.7468	.7468	.7545
10	.9431	.7468	.3772	.3772	.9431	.9431	.9431
11	.9431	.7468	.3772	.3772	.9431	.9431	.9431
12	.9431	.9335	.3772	.3772	.9431	.9431	.9431
13	.9431	.9335	.3772	.3772	.9431	.9431	.9431
14	.9431		.3772	.3772	.9431	.9431	.9431
15	.9431	.9335	.3772	.3772	.9431	.9431	.9431
16				.3772		.9431	.8573
17	.7468	.7468		.3772	.9335		.8573
18				.3772	.7468	.5658	.6859
19	.5601		.3734	.3772	.5601	.3772	.5144
20		.3734	.3734	.3772	.3734	.3772	.3429
21	.3734	.3734	.3734	.3772	.3734	.3772	.3429
22	.3772	.3772	.3772			.3772	.3429
23	.3772	.3772	.3772		.5601	.5658	.5144
24	.5658	.3772	.3772	.3772	.3734	.5601	.3772
Max	.9431	.9335	.3772	.3772	.9431	.9431	.9431
Min	.3734	.3734	.3734	.3772	.3734	.3734	.3429
Avg	.6333	.6006	.3767	.3772	.6921	.6827	.6258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 311 / 22 KV RUBY HALL

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.1317	1.1317			1.1317
2	.9431	.9431	1.1317	.9431			1.1317
3	.9431	.9431	1.1317	1.0562			.9431
4	.9431	1.1317	.9431	1.3203			1.1317
5	1.5089	1.5089	1.4335	1.6975			1.5089
6	1.8861	1.8861	1.6975	1.6975			1.8861
7	2.2634	2.2634	2.0748	1.8861	2.2405	1.8671	2.2634
8	2.6406	2.2634	2.452	2.2634	2.6139		2.452
9	2.452	2.452	2.6406	1.8861	2.4272	2.6139	2.452
10	2.2634	2.2405	2.2634	2.452	2.0748	2.452	2.0748
11	2.0748	1.8671		2.2634	2.0748	2.0748	2.0748
12	1.8861	1.8671	1.8861	1.8861	1.6975	1.8861	1.6975
13	1.5089	1.8671	1.6975	1.6975	1.5089	1.6975	1.6975
14	1.5089		1.5089	1.5089	1.5089	1.5089	1.5089
15	1.3203	1.307	1.3203	1.3203	1.3203	1.5089	1.5089
16				1.3203		1.3203	1.3717
17	1.307	1.4937		1.5089	1.4937	1.5089	1.5432
18				1.5089	1.4937	1.3203	1.5432
19	1.8671		1.8671	1.8861	1.8671	1.8861	1.8861
20			1.8671	1.8861	1.8671	1.8861	1.8861
21	1.6804	1.8671	1.8671	1.6975	1.6804	1.8861	1.8861
22	1.6975	1.6975	1.6975			1.6975	1.7147
23	1.5089	1.5089	1.5089		1.307	1.5089	1.3717
24	1.4335	1.1317	1.3203	1.3203	1.307	1.307	1.3203
Max	2.6406	2.452	2.6406	2.452	2.6139	2.6139	2.452
Min	.9431	.9431	.9431	.9431	1.307	1.307	.9431
Avg	1.6557	1.6511	1.6720	1.6426	1.7802	1.7606	1.6661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213025 / 22/22/11 KV HENLEY S/SN

Feeder No / Name : 312 / RAMTEKADI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
 ESTATE Feeder KV- 22 / STAGGERING (MIDC, EQUIVALENT)
 OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748	1.8861	1.8861	2.0748			1.8861
2	1.8861	1.8861	2.0748	1.8861			1.8861
3	2.0748	2.0748	1.8861	1.8861			1.8861
4	1.8861	2.0748	2.0748	1.8861			1.8861
5	1.8861	1.8861	1.8861	1.8861			1.8861
6	1.8861	1.8861	1.8861	1.8861			1.8861
7	1.8861	1.8861	1.8861	2.0748	2.2405	1.8671	1.8861
8	2.0748	2.2634	1.8861	1.8861	2.0538		1.8861
9	2.0748	2.6406	2.8292	2.0748	2.8006	2.4272	2.6406
10	2.6406	3.1741	3.3951	2.6406	3.3951	3.0178	2.8292
11	2.6406	3.3608	3.3951	2.452	3.3951	3.0178	3.0178
12	2.2634	2.6139	3.0178	2.6406	2.8292	3.3951	3.2065
13	2.2634	2.9874	3.0178	2.2634	3.2065	2.8292	2.6406
14	2.452		2.8292	2.452	3.0178	2.8292	3.0178
15	2.6406	3.3608	3.3951	2.2634	3.0178	3.0178	3.0178
16				2.452		3.2065	2.7435
17	1.8671	2.6139		2.2634	2.8006	2.6406	2.572
18				2.2634	2.6139	2.452	2.2291
19	2.2405		2.2405	2.0748	2.2405	2.2634	2.0576
20		2.2405	2.2405	2.0748	2.0538	2.0748	1.8861
21	2.0538	2.2405	2.0538	2.0748	1.8671	1.8861	1.7147
22	2.0748	2.0748	2.0748			2.0748	1.7147
23	2.0748	2.0748	2.0748		1.8671	1.8861	1.7147
24	2.2634	2.0748	2.0748	2.0748	2.0538	1.8671	1.8861
Max	2.6406	3.3608	3.3951	2.6406	3.3951	3.3951	3.2065
Min	1.8671	1.8861	1.8861	1.8861	1.8671	1.8671	1.7147
Avg	2.1526	2.3650	2.3859	2.1605	2.5908	2.5149	2.2491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213352 / 22/22 KV DSK Sunderban SW

Feeder No / Name : 301 / DSK SUDERBAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1886	.1886	.1886	.1886
2	.1886	.1886	.1886	.1886	.1886	.1886	.1886
3	.1886	.1886	.1886	.1886	.1886	.1886	.1886
4	.1886	.0381	.1886	.1886	.1886	.1886	.1886
5	.1886	.1886	.1886	.1886	.1886	.1886	.1886
6	.2263	.1886	.1886	.1886	.1886	.1886	.1886
7	.2641	.2263	.1886	.1886	.1886	.1886	.2263
8	.1886	.2263	.1886	.1886	.2263	.2263	.2263
9	.2263	.2263	.2641	.2641	.2641	.2641	.2263
10	.303	.3018	.3018	.2641	.2263	.2641	.2263
11	.3033	.3018	.3018	.2263	.1886	.2263	.2641
12	.2641	.2641	.2641	.3018	.1886	.2263	.3018
13	.1886	.2263	.1886	.2263	.1886	.2263	.1886
14	.1886	.2263	.1886	.1886	.1886	.1886	.1886
15	.1886	.1886	.1886	.1886	.1886	.1886	.1886
16	.1886	.1886	.1886	.1886	.2286	.1886	.1886
17	.1886	.1886	.1886	.1886	.1886	.1886	.1886
18	.1886	.1886	.1886	.1886	.1886	.1886	.1886
19	.1886	.1886	.1886	.1886	.1886	.1886	.1886
20	.1886	.1886	.1886	.1886	.1886	.1886	.1886
21	.1886	.1886	.1886	.1886	.1886	.1886	.1886
22	.1886	.1886	.1886	.1886	.1886	.1886	.1886
23	.1886	.1886	.1886	.1886	.1886	.1886	.1886
24	.1886	.1886	.1886	.1886	.1886	.1905	.1886
Max	.3033	.3018	.3018	.3018	.2641	.2641	.3018
Min	.1886	.0381	.1886	.1886	.1886	.1886	.1886
Avg	.2076	.2028	.2043	.2028	.1966	.2013	.2027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213352 / 22/22 KV DSK Sunderban SW

Feeder No / Name : 302 / MARVEL DIVA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.0562	1.0562	1.1317	1.094	1.1317
2	1.094	1.1694	1.0185	.9808	1.094	1.0185	1.094
3	1.094	1.1317	1.094	.9431	1.0562	.9808	1.0562
4	1.094	1.3203	1.1317	1.0562	1.094	1.0185	1.1317
5		1.3957	1.1317	1.0562	1.1694	1.094	1.2826
6		1.4335	1.1694	1.1317	1.358	1.1694	1.358
7		1.5089	1.2071	1.2071	1.4335		1.4335
8	1.5466	1.5466	1.358	1.2826	1.5089	1.5466	1.5089
9	1.5844	1.6221	1.4335	1.3957	1.6221	1.7353	1.6221
10	1.7493	1.8107	1.6598	1.6598	1.773	1.8861	1.773
11	1.5196	1.7353	1.7353	1.6221	.1886	1.8107	1.6975
12	1.4335	1.6221	1.6221	1.6598	1.5844	1.773	1.7353
13	1.3203	1.5844	1.5466	1.5089	1.5089	1.5844	1.6221
14	1.2826	1.4712	1.4335	1.5089	1.5089	1.6221	1.5466
15	1.3203	1.4335	1.4335	1.4335	1.5466	1.6598	1.5844
16	1.5089	1.4335	1.4335	1.3203	1.5466	1.5089	1.5089
17	1.5466	1.5089	1.3957	1.358	1.5089	1.5089	1.5089
18	1.5089	1.5466	1.5089	1.3203	1.5466	1.5844	1.5844
19	1.8107	1.6598	1.6975	1.6975	1.773	1.8861	1.773
20	1.6975	1.5089	1.7353	1.5466	1.8861	1.6975	1.6975
21	1.6975	1.4335	1.5466	1.5089	1.6221	1.5089	1.6975
22	1.4712	1.358	1.4335	1.358	1.5089	1.4712	1.5089
23	1.358	1.2826	1.3203	1.358	1.2826	1.3203	1.6221
24	1.1694	1.2071	1.1694	1.1317	1.2071	1.1317	1.1694
Max	1.8107	1.8107	1.7353	1.6975	1.8861	1.8861	1.773
Min	1.094	1.1317	1.0185	.9431	.1886	.9808	1.0562
Avg	1.4257	1.4523	1.3863	1.3376	1.3942	1.4614	1.4853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213352 / 22/22 KV DSK Sunderban SW

Feeder No / Name : 303 / MARVEL RITZ SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.9054	.9808	.7545	.7167	.7922	.8676
2	.9054	.9431	.9431	.679	.679	.7922	.8299
3	.8299	.9808	.9054	.679	.7922	.7545	.8676
4	.9054	1.0185	.8299	.7545	.8676	.8299	.9431
5	.9431	1.0185	.8676	.7922	.9808	.9145	.9808
6	.9808	1.0562	.9054	.8299	1.0562	.9808	1.0562
7	1.0562	1.094	.9431	.8299	1.1317	1.094	1.1694
8	1.2071	1.358	1.0185	.9054	1.2071	1.3203	1.3203
9	1.4335	1.5089	1.1317	.9808	1.4712	1.4712	1.3957
10	1.4712	1.4335	1.1317	1.0562	1.3957	1.5089	1.4712
11	1.4712	1.4335	1.0185	1.1317	1.3957	1.5089	1.5089
12	1.4335	1.3957	.9431	1.0185	1.3203	1.4335	1.3957
13	1.358	1.4335	.8299	.9431	1.3203	1.3957	1.358
14	1.3203	1.2826	.8299	.9054	1.2449	1.3957	1.358
15	1.3957	1.3203	.8299	.8676	1.2826	1.3957	1.5089
16	1.3957	1.4335	.7922	.8676	1.2449	1.358	1.4335
17	1.3957	1.3203	.7922	.9431	1.3203	1.4335	1.4335
18	1.358	1.2449	.8299	.9431	1.2826	1.3203	1.358
19	1.2826	1.2449	.9431	1.0185	1.2071	1.3957	1.3203
20	1.1317	1.1694	.9054	.9431	1.1317	1.2071	1.3203
21	1.1317	1.1317	.8299	.9054	1.094	1.094	1.1317
22	1.1317	1.0185	.8299	.9054	1.0185	1.094	1.0562
23	1.0562	.9808	.8299	.7922	.9808	1.0185	.9431
24	.9431	.9808	.9054	.7922	.7545	.8676	.9054
Max	1.4712	1.5089	1.1317	1.1317	1.4712	1.5089	1.5089
Min	.8299	.9054	.7922	.679	.679	.7545	.8299
Avg	1.1851	1.1961	.9069	.8849	1.1207	1.1824	1.2056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

HADAPSAR SUB-DN.[603] BU 4603

Substation No/ Name :- 213352 / 22/22 KV DSK Sunderban SW

Feeder No / Name : 304 / 22 kV Marvel Bounty

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0762	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0381	.0381	.0381
5	.0381	.0381	.0381	.0381	.0381	.0381	.0381
6	.0381	.0381	.0381	.0381	.0381	.0381	.0381
7	.0381	.0381	.0381	.0381	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381	.0381	.0381	.0381
9	.0381	.0381	.0381	.0381	.0381	.0381	.0377
10	.0381	.0381	.0381	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	.0381	.0381	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381	.0381	.0381
13	.0381	.0381	.0377	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381	.0381	.0381
15	.0381	.0381	.0381	.0381	.0381	.0381	.0381
16	.0381	.0381	.0381	.0381	.0381	.0381	.0381
17	.0381	.0381	.0381	.0381	.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.0381	.0762	.0381	.0381	.0381	.0381	.0381
Min	.0381	.0381	.0377	.0381	.0381	.0381	.0377
Avg	.0381	.0397	.0381	.0381	.0381	.0381	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S CITY CORP.LTD.[844] BU 4844

Substation No/ Name :- 213367 / 22 kV Amanora ESS V

Feeder No / Name : 201 / Amanora/ESS5/FDR 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
9		.1334
12		.3429
15		.3239
24	.1905	
Max	.1905	.3429
Min	.1905	.1334
Avg	.1905	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S CITY CORP.LTD.[844] BU 4844

Substation No/ Name :- 213367 / 22 kV Amanora ESS V

Feeder No / Name : 202 / AMANORA/ESS 5/FDR 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
9		.1715
12		.743
15		.7049
24	.4763	
Max	.4763	.743
Min	.4763	.1715
Avg	.4763	.5398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S CITY CORP.LTD.[844] BU 4844

Substation No/ Name :- 213367 / 22 kV Amanora ESS V

Feeder No / Name : 203 / Amanora ESS 5 Fdr III
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	09-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
9		.1334
12		.6478
15		.5906
24	.2286	
Max	.2286	.6478
Min	.2286	.1334
Avg	.2286	.4573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S CITY CORP.LTD.[844] BU 4844

Substation No/ Name :- 213367 / 22 kV Amanora ESS V

Feeder No / Name : 204 / AMANORA/ESS-5/FDR-4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
9		.0953
12		.5144
15		.4954
24	.1334	
Max	.1334	.5144
Min	.1334	.0953
Avg	.1334	.3684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S CITY CORP.LTD.[844] BU 4844

Substation No/ Name :- 213367 / 22 kV Amanora ESS V

Feeder No / Name : 205 / AMANORA/ESS5/FDR5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-FEB-18	13-FEB-18
HR	Load (MW)	Load (MW)
9		.3239
12		.8954
15		.9717
24	.3048	
Max	.3048	.9717
Min	.3048	.3239
Avg	.3048	.7303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213306 / 22/11 KV MAGARPATTA PHASE I

Feeder No / Name : 201 / COSMOS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5281	.5281	.5281	.5281	.5281	.5281
2	.415	.4715	.4715		.4715	.4715	.5093
3		.415	.415		.4338	.4338	.4527
4		.415	.415		.4338	.4338	.4527
5	.547	.4715	.4715		.4904	.4527	.4715
6		.5093	.5093		.5658		.5281
7		.6224	.5658		.6602	.6224	.6036
8	.9619	.7922	.6036	.6224	.8299	.7167	.7167
9	.9054	.7733	.7356	.7356	.8488	.7922	.7922
10	.8299	.7922	.7545	.6979	.7356	.7545	.7733
11	.6413	.547		.679	.6224	.6036	.5847
12	.5658	.547	.6224	.6602	.5281	.4904	.5281
13	.4904	.4527	.6036	.5847	.4715	.4904	.4527
14	.4527		.547	.5658	.4338	.4338	.4715
15	.4527	.4527	.4715	.5281	.415	.4338	.4338
16	.415	.4338	.5093	.4904	.415	.415	.4527
17	.4338	.4527	.5281	.5281	.4527	.4527	
18	.5281	.5281	.5847	.547	.5658	.5093	.547
19	.6979	.679	.7545	.7922	.6979	.7167	.7356
20	.7356	.7167	.7545	.7167	.7356	.7356	.7356
21	.7545	.6979	.7545	.7356	.7545	.7167	.7545
22	.7167	.6979	.6413	.7167	.7167	.6979	.7356
23	.6413	.6413	.6036	.6602	.6413	.679	.6413
24	.547	.5658	.5847	.5658	.5847	.5658	.5847
Max	.9619	.7922	.7545	.7922	.8488	.7922	.7922
Min	.415	.415	.415	.4904	.415	.415	.4338
Avg	.6175	.5740	.5839	.6308	.5847	.5716	.5863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213306 / 22/11 KV MAGARPATTA PHASE I

Feeder No / Name : 202 / PATNI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.0751	1.105	.9907	.9145	1.0479	1.105
2	1.0479	1.0374	1.0288	.9526	.9526	.9907	1.0479
3	.9907	.9619	.9526	.9145	.9717	.9907	.9907
4		.9242	.8764	.8954	1.0098	1.0669	1.0288
5		.9808	.8192		1.086		
6	1.0669	1.0374	.8573	.8764	1.1431	1.2003	
7	1.1431	1.1506	.8954	.9335	1.2765	1.3336	
8	1.8671	1.905	.9907	.9997	2.0386	1.7528	
9	2.4006	2.452	1.0479	1.2003	2.6482	2.4387	2.6482
10	2.4006	2.5149	1.2574	1.0479	2.7054	2.553	2.6292
11	1.4098	2.553		.9907	2.4577	2.4577	2.4196
12	1.448	2.5339	1.1812	1.1431	2.6482	2.553	2.5339
13	1.6004	2.5911	1.1431	1.1431	2.4768	2.4387	2.4577
14	1.5242		1.105	1.1241	2.553	2.5149	2.7054
15	1.4861	2.5911	1.2193	1.1431	2.6292	2.6863	2.7054
16	1.5623	2.6482	1.2955	1.1812	2.4006	2.6482	2.6482
17	1.467	2.3434	.8573	1.1431	2.4958	2.5911	
18	2.3243	2.3815	1.1431	1.105	2.4387	2.4958	2.4387
19	1.9427	2.1529	1.086	1.105	1.829	1.848	2.0195
20	1.7541	2.0195	1.105	1.086	1.6409	1.6975	1.9052
21	1.6409	1.6787	.9619	1.0374	1.5089	1.5655	1.6598
22	1.4146	1.2637	1.0751	.9997	1.3203	1.358	1.358
23	1.3014	1.226	1.094	.9619	1.226	1.2449	1.2637
24	1.1622	1.1694	1.1622	1.0669	.9145	1.105	1.1622
Max	2.4006	2.6482	1.2955	1.2003	2.7054	2.6863	2.7054
Min	.9907	.9242	.8192	.8764	.9145	.9907	.9907
Avg	1.5482	1.7909	1.0548	1.0453	1.8036	1.8513	1.9330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213306 / 22/11 KV MAGARPATTA PHASE I

Feeder No / Name : 205 / IRIS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.1698	.1509	.1698	.1698	.1698
2	.1698	.1509	.1509	.132	.1509	.1698	
3	.1509	.1509	.1509	.132	.1509	.1698	.1509
4	.1509	.1509	.1509		.1509	.1698	.1509
5		.1509	.1509		.1509	.1698	.1509
6	.1698	.1698	.1509	.1698	.1698	.1886	.1509
7	.2452	.1886	.1698	.1886	.2263	.1886	.1886
8	.3018	.2452	.1886	.2075	.3206	.2263	.2452
9	.2641	.2452	.2075	.2075	.2452	.2641	.2641
10	.2452	.2254	.2263	.2263	.2075	.2075	.2452
11	.1698	.132		.1698	.1698	.1886	.1509
12	.132	.132	.1886	.1509	.1509	.1509	.132
13	.132	.132	.2263	.1698	.132	.1509	.132
14	.1509		.1509	.1698	.1132	.1509	.132
15	.1132	.1132	.1509	.1509	.132	.1132	.1132
16	.1132	.1132	.1509	.1509	.1132	.1132	.1132
17	.1132	.1132	.1509	.1509	.1132	.1132	
18	.1132	.132	.1698	.1509	.132	.132	.132
19	.2075	.1886	.2263	.2075	.1886	.2075	.1886
20	.2075	.1509	.3772	.2075	.2075	.2263	.2075
21	.2075	.1886	.2263	.2075	.2263	.2452	.2263
22	.2075	.2075	.1886	.2075	.2263	.2263	.2263
23	.1886	.1886	.1698	.2075	.1886	.2075	.2075
24	.1886	.1698	.1698	.1509	.1698	.1698	.1886
Max	.3018	.2452	.3772	.2263	.3206	.2641	.2641
Min	.1132	.1132	.1509	.132	.1132	.1132	.1132
Avg	.1788	.1656	.1853	.1758	.1753	.1800	.1758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213306 / 22/11 KV MAGARPATTA PHASE I

Feeder No / Name : 206 / DESTINATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2263	.2075	.2263	.2263	.2263	.2263
2	.1886	.2263	.1886	.1886	.2263	.1886	.2075
3		.2075	.1886		.2075	.1886	.2075
4		.2075	.1886		.2075	.1886	.2075
5	.1886	.2075	.1886		.2075	.1886	.2075
6	.1886	.2075	.1886	.1886	.2075	.1886	.2263
7	.2075	.2452	.1886	.1886	.2075	.2075	.2452
8	.2263	.3018	.2263	.2075	.2452	.2075	.3018
9	.3206	.2829	.3395	.3206	.3395	.3018	.2452
10	.3018	.3584	.3206	.2829	.3395	.3395	.3772
11	.3395	.3584		.3018	.3395	.3018	.4338
12	.3961	.4715	.3584	.3584	.3961	.3961	.415
13	.3961	.415	.3961	.3584	.3961	.3584	.3961
14	.3772		.4338	.415	.3961	.3961	.3961
15	.3584	.3961	.3961	.415	.3018	.3395	.3018
16	.3395	.3206	.2452	.2829	.3206	.3018	.3395
17	.3395	.3018	.3395	.3395	.3018	.3206	
18	.3584	.4527	.415	.3018	.4527	.3018	.3018
19	.3772	.3961	.4338	.4338	.4715	.3961	.4527
20	.3772	.3395		.3584	.3772	.3772	.3772
21	.415	.3584	.4338	.3772	.3395	.3395	.3584
22	.3961	.3395	.3018	.3395	.3206	.3018	.3395
23	.2829	.3018	.2829	.3018	.2829	.2829	.2829
24	.2452	.2452	.2829	.2452	.2452	.2452	.2452
Max	.415	.4715	.4338	.4338	.4715	.3961	.4527
Min	.1886	.2075	.1886	.1886	.2075	.1886	.2075
Avg	.3138	.3116	.2975	.3063	.3065	.2869	.3083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213306 / 22/11 KV MAGARPATTA PHASE I

Feeder No / Name : 207 / GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.2637	1.2003	.9145	.7811	1.2193	1.2955
2		1.1506	1.086	.8383	.7621		1.2384
3	1.0288	1.094	.9907		.8573	1.105	1.1622
4		.9997	.8573		.8954	1.0098	1.105
5		.9242	.7621		.9717	.9526	1.0669
6		.9808	.7167		1.086		1.0288
7	1.105	1.0185	.7811	.6668	1.2003	1.0669	1.086
8	1.1622	1.1506	.8383	.743	1.4098	1.105	1.2193
9	1.4098	1.5655	.8573	.7621	1.5432	1.5432	1.7337
10	1.7909	1.5844	.8954	.9145	1.6004	1.6004	1.6385
11	1.7337	1.6004		.8954	1.7909	1.7147	1.5623
12	1.829	1.6766	1.105	.8764	1.7147	1.6766	1.6575
13	1.7909	1.6385	1.086	.9526	1.7147	1.7718	1.7909
14	1.7909		1.1241	.9526	1.7528	1.7718	1.8671
15	1.848	1.8099	1.1622	.9526	1.829	1.7528	1.8861
16	1.8861	1.8099	1.1317	.9526	1.7337	1.7909	1.8861
17	1.8861	1.7718	.9145	.9907	1.7909	1.829	
18	1.7909	1.5242	.9717	1.086	1.7147	1.6575	1.6004
19	1.6975	1.7147	.9526	.9526	1.6766	1.7147	1.7718
20	1.6409	1.6004	.9717	.9145	1.5844	1.5844	1.6766
21	1.5655	1.5466	.9242	.8676	1.5089	1.5278	1.6032
22	1.4523	1.4901	.9808	.8488	1.3392	1.4901	1.5655
23		1.3769	.9431	.8299	1.3392	1.4523	1.358
24	1.3146	1.3203	1.2955	.9717	.7811	1.2765	1.3908
Max	1.8861	1.8099	1.2955	1.086	1.829	1.829	1.8861
Min	1.0288	.9242	.7167	.6668	.7621	.9526	1.0288
Avg	1.5769	1.4179	.9804	.8942	1.3908	1.4824	1.4865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213313 / 22/11 KV MAGARAPATTA PH-II

Feeder No / Name : 201 / EDS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5324	.6084	.5324	.2662	.2472	.6655	
2	.5134	.5894	.4944	.2282	.2282	.6084	
3	.4944	.5704	.4563	.2092	.2662	.5514	
4	.4944	.5514	.4183	.2282	.3042	.4944	
5	.4753	.5324	.3803	.2472	.3423	.4373	
6	.4373	.5324	.3423	.2662	.3993	.3993	
7	.4563	.5134	.2852	.2662	.4753	.4563	
8		.4563		.2662		.4753	
9		.4373	.2852	.2472		.5134	.5123
10		.5134	.2662	.2662		.6662	.7606
11	.6838	.6845	.2662	.2662		.8374	.7796
12	.7749	.8746	.2852	.2662	1.0458	.9507	.9507
13		.8937	.2852	.2662	1.1039	1.1028	1.0468
14		.9317	.3423	.2662	1.1587	1.1028	1.1017
15	1.1385	.9507	.3993	.4854	.9317	1.0278	1.1039
16	1.0268	.2092	.5514	.4854		1.0087	1.0658
17	1.0468	.9127	.3613	.3961	1.0067	1.161	1.0637
18			.5514	.3961	.9687	1.1039	1.0268
19	.9887	.8556			.8937	.8556	.8176
20	.8349	.7796	.3423	.3416		.8176	.8556
21	.7986				.8366		.7986
22	.7986				.7986	.7606	.7035
23	.5894				.7415	.6845	.7225
24	.5324	.6084	.5704	.2852	.2472	.7225	
Max	1.1385	.9507	.5704	.4854	1.1587	1.161	1.1039
Min	.4373	.2092	.2662	.2092	.2282	.3993	.5123
Avg	.7009	.6503	.3903	.2973	.6664	.7567	.8873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213313 / 22/11 KV MAGARAPATTA PH-II

Feeder No / Name : 202 / SAS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4753	.4563	.4183	.4175	.4183	.4753	
2	.5134	.4753	.3993	.4373	.4563	.4563	
3	.5514	.4944	.4183	.4744	.4944	.4373	
4	.5894	.5134	.4563	.4944	.5324	.4183	
5	.6275	.5514	.4944	.5319	.5704	.4563	
6	.6655	.6084	.5324	.5497	.6275	.4753	
7	.6845	.6655	.5704	.5687	.6655	.7796	
8		.6845		.4929		.8366	
9		1.1028	.5324	.4563		1.1765	1.1955
10		1.1789	.6275	.5514		1.1955	1.2929
11	1.4056	1.2929	.7225	.5514		1.2157	1.312
12	1.4232	1.2739	.6465	.5704	1.369	1.3676	1.35
13		1.331	.6275	.6084	1.2942	1.2916	1.3323
14		1.388	.6655	.5894	1.4626	1.3473	1.3866
15	1.3473	1.426		.5914	1.4641	1.4042	1.5036
16	1.4641	1.388	.6845	.6161		1.4436	1.4846
17	1.3513	1.2739	.4944	.5914	1.4816	1.3676	1.3676
18			.4563	.3174	1.2347	1.1587	1.35
19	1.1028	1.0077			1.0268	1.0816	1.1408
20	1.0057	.8556	.4373	.4364	.8548		.7796
21	.7986				.7796	1.0067	.7796
22	.7415				.7035	.7035	.6655
23	.4563				.5704	.6084	.5704
24	.4563	.3993	.4373	.3993	.3993	.4944	
Max	1.4641	1.426	.7225	.6161	1.4816	1.4436	1.5036
Min	.4563	.3993	.3993	.3174	.3993	.4183	.5704
Avg	.8700	.9184	.5345	.5123	.8634	.9216	1.1674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213313 / 22/11 KV MAGARAPATTA PH-II

Feeder No / Name : 203 / AMDOCS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7986	.6845	.7225	.4753	.4753	.7225	
2	.7606	.6655	.7035	.4563	.4944	.7035	
3	.7225	.6465	.6845	.4338	.5134	.6845	
4	.6845	.6084	.6465	.4183	.5324	.6465	
5	.6275	.5894	.6084	.4373	.5514	.6275	
6		.5704	.5704	.4183	.5894	.6084	
7	.5894	.5514	.5324	.4563	.6084	.6275	
8	.5514	.7986		.4753		.7035	
9		.9697	.5134	.4563		.9877	1.0816
10		1.0268	.5514	.4563		1.0637	1.0838
11	1.0447	1.0077	.5324	.4753		1.0458	1.1789
12	1.0437	1.2739	.5324	.4944	1.1789	1.0648	1.1789
13		1.2549	.5324		.9897	1.0087	1.18
14		1.2929	.5514	.4753	1.0827		1.2537
15	1.1196	1.1028	.5514	.5041	1.1408	1.0838	1.2181
16	1.2929	1.2359	.5704	.5175		1.1218	1.2371
17	1.0849	1.1408	.5134	.5041	.3229	1.1207	1.2157
18			.5134	.5281	1.1777	1.0458	1.1979
19	1.1408	.9887			1.1218	1.0257	1.0838
20	1.0057	.9507	.4753	.4934	.9877	.9497	1.0077
21	.9697				.9887		.9887
22	.9317				.9507	.9317	.9317
23	.7415				.8556	.8366	.8937
24	.8556	.7415	.7415	.4753	.4753	.7606	
Max	1.2929	1.2929	.7415	.5281	1.1789	1.1218	1.2537
Min	.5514	.5514	.4753	.4183	.3229	.6084	.8937
Avg	.8870	.9051	.5814	.4711	.7914	.8805	1.1154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213313 / 22/11 KV MAGARAPATTA PH-II

Feeder No / Name : 204 / MULBERRY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5704		.5324	.6084	.5704	.5134	
2	.5514	.6465	.5324	.5894	.5514	.4944	
3	.5514	.6275	.5134	.5704	.5134	.4753	
4	.5324	.5894	.4944	.5324	.4944	.4563	
5	.5324	.5514	.4753	.5134	.4753	.4753	
6	.5134	.5324	.4753	.4944	.4563	.4944	
7	.4944	.5134	.4944	.4944	.4373	.5134	
8		.8366		.4944		.7986	
9		1.1789	.7225	.7225		1.312	.7211
10		1.5782	.9317	.8366		1.7493	1.6352
11	1.6715	1.9014	.7796	.7415		1.9033	1.8253
12	1.7647	1.6922	1.0458	.8176	1.9394	1.9033	1.8634
13		1.7493	1.0648	.7796	1.7891	1.8652	1.8081
14		1.8063	1.0268	.7986	1.9565	1.8443	1.9375
15	1.537	1.7303	.9887	.6908	2.0535	1.8652	1.9985
16	1.8063	1.5972	1.0648	.7468		1.9985	1.9604
17	1.6939	1.7683	.9317	.7655	1.9375	1.8652	
18			.7986	.7842	1.8995	1.713	1.9204
19	1.5782	1.35			1.5972	1.5591	1.5972
20	1.1955	1.0458	.6465	.816	1.1207	1.3323	1.0268
21	1.1218				.9697		.9507
22	1.0648				.8746	1.0838	.8937
23	1.0648				.7796	.5514	.7225
24	.7225	.8556	.5514	.6275	.5894	.5134	
Max	1.8063	1.9014	1.0648	.8366	2.0535	1.9985	1.9985
Min	.4944	.5134	.4753	.4944	.4373	.4563	.7211
Avg	1.0537	1.1869	.7406	.6712	1.1055	1.1861	1.4901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

M/S MAGARPATTA TOWNSHIP BU 4856

LTD[856]

Substation No/ Name :- 213313 / 22/11 KV MAGARAPATTA PH-II

Feeder No / Name : 208 / JASMINIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2852	.2472	.2472	.2662	.2472	.2662	
2	.3042	.2282	.2282	.2472	.2662	.2472	
3	.3232	.2472	.2092	.2282	.2852	.2282	
4	.3423	.2662	.2282	.2092	.3042	.2092	
5	.3613	.2852	.2662	.2282		.2472	
6	.3803	.3232	.2852	.2472	.3423	.2662	
7	.3993	.3423	.3042	.2662	.3613	.2852	
8		.3803		.2852		.3423	
9		.3803	.3232	.3423		.3799	.3985
10		.3423	.3613	.4183		.3803	.3423
11	.3609	.2472	.3423	.3423		.3042	.2852
12	.2846	.2472	.3613	.3232	.2472	.2659	.2662
13		.2282	.3042	.3232	.2284	.2474	.2665
14		.2092	.2852	.3232	.2469	.2279	.2279
15	.2467	.2282	.2852	.2402	.2282	.2472	.2094
16	.2282	.2092	.2282	.2241		.2282	.2094
17	.2284	.2092	.2662	.2241	.2279	.2472	
18			.2852	.2614	.2659	.2662	.2852
19	.3423	.3613			.3423	.3042	.3613
20	.3416	.3613	.3803	.3416	.3989	.3613	.3803
21	.3993				.3613		.3993
22	.3803				.3423	.3613	.3803
23	.2852				.3042	.3232	.3042
24	.2472		.2662	.2852	.2472	.2641	
Max	.3993	.3803	.3803	.4183	.3989	.3803	.3993
Min	.2282	.2092	.2092	.2092	.2279	.2092	.2094
Avg	.3189	.2812	.2872	.2813	.2915	.2826	.3083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213009 / 22/11 KV NAIDU SUB-STATION

Feeder No / Name : 201 / BOAT CLUB SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.2136	1.2384	1.3203	1.3203		1.3203
2	1.307	1.1203	1.1431	1.3203	1.3203		1.2334
3	1.5089	1.1203	1.1431	1.3203	1.226		1.1317
4	1.6975	1.2936	1.2384	1.1317	1.1317		1.1317
5	1.8861	1.4784	1.3336	1.1317	1.1317		1.3203
6	2.1691	1.8671	1.7147	1.5089	1.3296		1.5089
7	2.452	2.3339	1.9052	1.8861	2.0748		2.2634
8	2.7349	2.7349	2.2862	2.2634			2.6406
9	2.6406	2.7349	2.6673	2.452	2.6673	2.7625	2.6406
10		2.7349	2.5206	2.452	2.4768	2.7625	2.6673
11		2.452		2.452	2.4768	2.572	2.553
12		2.2634		2.3339	2.191	2.3815	2.2862
13		2.2634		1.8671	2.191	2.0957	2.0957
14		1.8861		1.7737	2.0005	2.0005	2.0957
15		1.8861	1.8099	1.7737	2.0005	1.9052	2.0005
16	1.9052	2.0005	1.7147	1.587	1.9805	1.7528	2.0538
17	1.9052	2.0005	1.7147	2.1253	1.9805	1.8099	1.9909
18	1.9052	2.0005	1.8099	2.1472	2.0538		2.1253
19	2.0957	2.2862	2.0957	2.1253	2.2405	2.2177	2.4272
20	2.0957	2.191	2.191	2.0328	2.1472	2.1253	2.2177
21	2.0957	2.0957	1.9052	2.0328	2.0748	2.0328	2.1253
22	1.9052	1.9052	1.9052	1.9404	1.9605	1.8671	
23	1.6975	1.7147		1.6975		1.6975	
24	1.4937	1.4937	1.5242	1.5089	1.3203		1.3203
Max	2.7349	2.7349	2.6673	2.452	2.6673	2.7625	2.6673
Min	1.307	1.1203	1.1431	1.1317	1.1317	1.6975	1.1317
Avg	1.9335	1.9613	1.7822	1.8410	1.8771	2.1416	1.9614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601]

BU 4601

Substation No/ Name :- 213009 / 22/11 KV NAIDU SUB-STATION

Feeder No / Name : 202 / ENGG COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.7373	.9526	.9431	.9431		.9431
2	.8478	.663	.8573	.9431	.9431		1.0374
3	.8573	.6783	.7621	.9431	.8522		.9431
4	1.0402	.8669	.7621	.9431	.9431		.9431
5	1.0631	1.0631	.9526	.9431	.9431		.9431
6	1.1393	1.0745	1.1431	.9431	.9431		.9431
7	1.0402	1.1888	1.1431	.9431	1.1317		1.1317
8	1.3289	1.1765	1.1431	1.1317	1.226		1.3203
9	1.2536	1.3717	1.2384	1.1317	1.3336	1.2384	1.307
10		1.4003	1.226	1.0745	1.3336	1.3336	1.3336
11		1.3203	1.1317	1.0517	1.4289	1.3336	1.4289
12		1.3203		.964	1.3336	1.2384	1.3336
13		1.3203		.8669	1.3336	1.1431	1.3336
14		1.1317		.7716	1.2384	1.1431	1.3336
15		1.3203	1.0479	.7716	1.3336	1.0479	1.307
16	1.2384	1.3336	1.0479	.7716	1.3203	1.0974	1.307
17	1.2384	1.2384	.9526	.9536	1.226	1.1088	1.307
18	1.2384	1.2384	1.0479	.964	1.307	1.1203	1.2012
19	1.3336	1.3336	1.1431	1.1517	1.4937	1.2936	1.2803
20	1.3336	1.2384	1.2384	1.0631	1.4146	1.2136	1.2803
21	1.1431	1.2384	1.1431	1.0631	1.3203	1.0745	1.1888
22	1.1431	1.1431	1.0479	.964	1.2136	1.0402	
23	1.0402	1.0479		.9478		.9431	
24	.8573	.8192	1.0479	.9431	.9431		.9431
Max	1.3336	1.4003	1.2384	1.1517	1.4937	1.3336	1.4289
Min	.8192	.663	.7621	.7716	.8522	.9431	.9431
Avg	1.1087	1.1360	1.0514	.9661	1.1956	1.1580	1.1859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601]

BU 4601

Substation No/ Name :- 213009 / 22/11 KV NAIDU SUB-STATION

Feeder No / Name : 204 / BRAHMA BAJAJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	1.0374	.9526	1.2384	1.0479		
2	1.0374	.9431	.9526	1.1431	1.0479		
3	1.226	.9431	.9526	1.1431	1.0479		
4	1.3336	1.0374	1.0479	1.2384	.9526		
5	1.3336	1.1431	1.0479	1.2384	.9526		
6	1.2384	1.1431	1.0479	1.2384	1.0479		
7	1.2384	1.4289	1.1431	1.2384	1.1431		
8	1.2384	1.4289	1.1431	1.2384	1.2384		
9	1.9052	1.6032	1.4289	1.5242	1.8099	1.5242	
10		1.9805	1.4289	1.6194	2.0957	1.7147	1.7147
11		1.9805	1.7147	1.6194	1.7147	1.9052	1.9052
12		1.7918	1.7147	1.4289	1.9052	1.5242	1.8099
13		1.9805	1.7147	1.5242	1.9052	1.6194	1.9052
14		1.7918	1.5089	1.5242	1.9052	1.6194	2.0005
15		1.9805	1.6194	1.6194	1.7147	1.5242	1.8099
16	2.0957	2.0005	1.5242	1.6194	1.6975	1.7918	1.8099
17	2.0005	1.9814	1.5242	1.6194	1.5089	1.7918	1.8099
18	2.0005	2.0005	1.7147	1.6194	1.8099	1.7918	1.9052
19	2.0005	2.0005	1.7147	1.6194	2.0005	1.8099	1.6975
20	1.7147	1.9052	1.6194	1.6194	1.9052	1.5242	1.6975
21	1.4289	1.5242	1.6194	1.6194	1.6194	1.6194	1.6194
22	1.2384	1.5242	1.4289	1.5242	1.4289	1.2384	
23	1.1317	1.4289		1.2384			
24	1.0374	1.0374	1.0479	1.2384	1.0479		
Max	2.0957	2.0005	1.7147	1.6194	2.0957	1.9052	2.0005
Min	1.0374	.9431	.9526	1.1431	.9526	1.2384	1.6194
Avg	1.4576	1.5674	1.3744	1.4289	1.5020	1.6428	1.8071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213009 / 22/11 KV NAIDU SUB-STATION

Feeder No / Name : 205 / RBM SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.8402	.8573	.9431	.7545		.9526
2	.8488	.8488	.8573	.9431	.7545		.9526
3	.9431	.8316	.8573	.9431	.7545		.9526
4	1.0269	.924	.8573	.9431	.7545		.9526
5	1.1203	1.0059	.8573	.9431	.7545		.9526
6	1.1203	1.1088	.8573	.9431	.8488		.9526
7	1.226	1.2012	.8573	.9431	1.0374		1.2384
8	1.4146	1.386	1.1431	1.0374	1.226		1.4146
9	1.6032	1.5089	1.2384	1.1317	1.6194	1.5242	1.6032
10		1.8861	1.4937	1.1431	1.7147	1.5242	1.9052
11		1.8671	1.6804	1.2384	1.9052	1.9052	2.0957
12		2.0748		1.1203	1.9052	1.8099	2.191
13		1.8671		1.1317	1.9052	1.8099	2.0957
14		1.8671		1.1317	1.9052	1.2384	
15		1.8671	1.5242	1.3203	1.9052	1.8099	2.3577
16	2.0957	1.9052	1.5242	1.1317	1.8671	1.7737	2.1691
17	1.9052	1.9052	1.4289	1.3203	1.9805	1.5432	2.0748
18	1.9052	1.9052	1.4289	1.307	1.8861	1.1203	1.8861
19	1.9052	1.8099	1.7147	1.4937	1.6975	1.7918	1.8861
20	1.6194	1.6194	1.5242	1.2936	1.5089	1.5089	1.6975
21	1.4289	1.3336	1.3336	1.1088	1.4146	1.4146	1.4146
22	1.2384	1.2384	1.2384	1.1088	1.2936	1.2384	
23	.9335	.9526		.9431		1.1431	
24	.9526	.9335	.8573	1.1317	.8488		.9526
Max	2.0957	2.0748	1.7147	1.4937	1.9805	1.9052	2.3577
Min	.8488	.8316	.8573	.9431	.7545	1.1203	.9526
Avg	1.3409	1.4453	1.2066	1.1123	1.4018	1.5437	1.5570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213009 / 22/11 KV NAIDU SUB-STATION

Feeder No / Name : 206 / WADIA COLLEGE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.985	1.0374	1.0479	.9431	.9431		
2	1.0059	1.0269	.9526	.9431	.9431		
3	1.1088	1.0269	.9526	.9431	.9431		
4	1.2136	1.1203	.9526	.9431	.9431		
5	1.267	1.2136	1.1431	.9431	.9431		
6	1.4327	1.4784	1.1431	.9431	.9431		
7	1.3146	1.5708	1.2384	1.1317	1.226		
8	1.647	1.7556	1.5242	1.226	1.6032		
9	1.6832	1.8671	1.7147	1.5089	1.8099	1.7147	
10		2.0538	1.6804	1.4784	1.9052	1.9052	2.0005
11		1.8671	1.6804	1.5708	1.9052	1.9052	1.9052
12		1.8671		1.4784	1.7147	1.7147	1.8099
13		1.9052		1.2803	1.7147	1.5242	1.7147
14		1.6975		1.0974	1.5242	1.4289	1.6194
15		1.5089	1.3336	1.0974	1.5242	1.4289	1.5242
16	1.7147	1.5242	1.3336	1.1088	1.4632	1.6032	1.6032
17	1.5242	1.5242	1.2384	1.307	1.5546	1.5242	1.6804
18	1.5242	1.5242	1.3336	1.307	1.6632	1.5242	1.6975
19	1.6194	1.5242	1.5242	1.2936	1.6804	1.6032	1.5089
20	1.4289	1.5242	1.3336	1.2803	1.4784	1.4784	1.4937
21	1.3336	1.3336	1.3336	1.2803	1.386	1.3717	1.4003
22	1.3336	1.2384	1.2384	1.2936	1.2936	1.1765	
23	1.3203	1.1431		1.1317			
24	1.0631	1.1317	1.0479	1.1317	1.0374		
Max	1.7147	2.0538	1.7147	1.5708	1.9052	1.9052	2.0005
Min	.985	1.0269	.9526	.9431	.9431	1.1765	1.4003
Avg	1.3622	1.4777	1.2873	1.1942	1.3975	1.5645	1.6632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601]

BU 4601

Substation No/ Name :- 213009 / 22/11 KV NAIDU SUB-STATION

Feeder No / Name : 207 / MANIKCHAND IKON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2458	.2858	.2858	.2858	.2858		
2	.2515	.1905	.2858	.1905	.2858		
3	.2543	.1905	.2858	.1905	.2858		
4	.1734	.2829	.2858	.2858	.1905		
5	.1753	.3772	.2858	.2858	.1905		
6	.2658	.3734	.2858	.2858	.2858		
7	.2572	.4668	.2858	.2858	.381		
8	.4382	.462	.2858	.2858	.4763		
9	.5601	.6668	.2858	.1905	.6668	.5716	
10		.6668	.2858	.2858	.6668	.6668	.6668
11		.6602	.3772	.2543	.7621	.6668	.6668
12		.6602		.2458	.7621	.6668	.6668
13		.6602		.3315	.7621	.6668	.6668
14		.6602		.3315	.6668	.6668	.7621
15		.6602	.2858	.2372	.6668	.6668	.7621
16	.6668	.6668	.2858	.2286	.7545	.6602	.8488
17	.6668	.5716	.2858	.2372	.7545	.6602	.6602
18	.5716	.5716	.2858	.2458	.6535	.6602	.7545
19	.5716	.5716	.2858	.2372	.6535	.6602	.5658
20	.4763	.4763	.2858	.2429	.5544	.5601	.5658
21	.4763	.4763	.2858	.2401	.4572	.462	.4715
22	.381	.4763	.2858	.1524	.4572	.4668	
23	.381	.2858		.2829			
24		.2858	.2858	.2829	.2858		
Max	.6668	.6668	.3772	.3315	.7621	.6668	.8488
Min	.1734	.1905	.2858	.1524	.1905	.462	.4715
Avg	.4008	.4852	.2904	.2551	.5176	.6216	.6715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213009 / 22/11 KV NAIDU SUB-STATION

Feeder No / Name : 301 / GODREJ I/C 1

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	1.6975	1.7147	1.6975			1.5089
2	1.6975	1.5089	1.7147	1.6975			1.5089
3	1.6975	1.5089	1.7147	1.6975			1.5089
4	1.8861	1.5089	1.7147	1.6975			1.5089
5	1.8861	1.6975	1.9052	1.6975			1.5089
6	1.8861	1.6975	1.9052	1.6975			1.6975
7	1.8861	1.8861	1.9052	1.6975			1.8861
8	2.2634	2.0748	2.0957	1.8861			2.2634
9	2.6406	2.452	2.2862	1.8861	2.4768	2.6673	
10		2.8292	2.452	1.8861	3.0483	3.0483	3.0483
11		2.8292	2.8292	2.0748	3.0483	3.2388	2.6673
12		3.0178	2.6406	2.0748	3.2388	3.0483	3.0483
13		3.2065	2.6406	2.0748	3.2388	3.0483	3.2388
14		3.0178	2.6406	2.0748	3.2388	3.0483	
15		3.0178		2.2634	3.2388	3.0483	3.2065
16	3.2388	3.0483	2.8578	2.2634	3.0178	2.9874	3.0178
17	3.0483	3.0483	2.6673	2.2634	3.0178	2.8292	3.0178
18	2.8578	2.8578	2.4768	2.2634	2.8292	2.8292	2.8292
19	2.8578	2.6673	2.4768	2.0748	2.6406	2.6406	2.8292
20	2.6673	2.4768	2.2862	1.8861	2.452	2.2634	2.6406
21	2.4768	2.2862	2.0957	1.8861	2.2634	2.0748	2.452
22	2.2862	2.0957	2.0957	2.0748	2.0748	2.0748	
23	1.8861	2.0957		1.9052		1.8861	
24	1.8861	1.6975	1.9052	1.8861	1.6975		1.6975
Max	3.2388	3.2065	2.8578	2.2634	3.2388	3.2388	3.2388
Min	1.6975	1.5089	1.7147	1.6975	1.6975	1.8861	1.5089
Avg	2.2742	2.3427	2.2282	1.9419	2.7681	2.7155	2.3542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213009 / 22/11 KV NAIDU SUB-STATION

Feeder No / Name : 305 / Sweage plant

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6325	.7621	.3429			.5601
2	.1829	.663	.5716	.3429			.5658
3	.1848	.6935	.5716	.3429			.5601
4	.1867	.5316	.5716	.3429			.5658
5	.1886	.5201	.5716	.3429			.5601
6	.1905	.5316	.6859	.3429			.5607
7	.1905	.6859	.6859	.5144			.7468
8	.6783	.7011	.6859	.5144			.7545
9	.6783	.7716	.7621	.5144	.7621	.5716	
10		.5144	.6859	.8669	.9145	.7621	.6097
11		.6859	.6859	.8573	.9145	.9145	.7621
12		.5144	.6859	.8002	.3048	.7621	.7621
13		.6859	.6859	.8192	.7621	.7621	.6859
14		.6859	.6859	.5373	.7621	.6859	
15		.5144	.7621	.6783	.7621	.6097	.6722
16	.7621	.6097	.7621	.6554	.6554	.7164	.924
17	.7621	.6859	.7621	.663	.663	.7164	.905
18	.7621	.381	.7621	.503	.6706	.7164	.905
19	.7621	.8383	.6097	.8954	.9156	.543	.6935
20	.7621	.7621	.6097	.8859	.8669	.5316	.7087
21	.7621	.7621	.6097	.8859	.8764	.5544	.7011
22	.7621	.7621	.6859	.7087	.8764	.5316	
23	.6935	.7621		.6859		.5658	
24	.7164	.5563	.7621	.5144	.5144		.5601
Max	.7621	.8383	.7621	.8954	.9156	.9145	.924
Min	.1829	.381	.5716	.3429	.3048	.5316	.5601
Avg	.5527	.6438	.6793	.6066	.7481	.6629	.6882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213017 / 22/11KV BHAIROBA SUB-STATION

Feeder No / Name : 202 / Bhairoba

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4572	.4572	.381	.381	.4191	.4572
2	.4954	.4191	.4191	.3429	.3429	.381	.4191
3	.4763	.381	.381	.3429	.3048	.3429	.381
4	.4763	.381	.3429	.381	.3429	.3429	.381
5	.4954	.4191	.3429	.4191	.381	.381	.4191
6	.4191	.4572	.381	.4572	.4191	.4191	.4572
7	.5335	.4954		.4954	.4572	.4572	.4954
8	.5335	.5144	.4191	.5144	.5335	.4954	.5144
9	.5335	.5335	.4954	.5335	.5335	.5144	.5335
10	.6668	.5144	.5335	.6287	.5525	.5144	.5906
11	.5525	.4572	.6668	.5525	.5335	.6287	.6859
12	.6668	.4382	.5525	.6478	.6478	.6287	.5525
13	.6478	.4572	.5335	.6478	.5335	.5335	.5525
14	.6478	.4382	.6478	.5335	.5144	.5335	.5335
15	.5525	.4191	.5716	.5335	.5335	.5144	.6287
16	.5335	.381	.381	.5144	.5144	.5144	.5335
17	.5144	.4572	.5144	.4954	.4954	.5144	.5144
18	.5144	.4763	.5144	.4954	.5906	.6097	.4954
19	.5335	.4001	.5335	.5144	.5144	.5335	.5144
20	.5335	.4382	.5335	.5144	.5144	.5144	.5144
21	.5144	.4382	.5144	.5144	.4954	.4954	.4954
22	.5144	.4382	.5144	.5144	.4954	.4954	.4954
23	.5144	.4191	.5144	.4382	.4191	.5144	.4954
24	.5144	.5144	.4954	.4191	.4191	.4572	.4954
Max	.6668	.5335	.6668	.6478	.6478	.6287	.6859
Min	.4191	.381	.3429	.3429	.3048	.3429	.381
Avg	.5366	.4477	.4896	.4930	.4779	.4898	.5065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213017 / 22/11KV BHAIROBA SUB-STATION

Feeder No / Name : 203 / KAPILA DAIRY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1905	.1905	.1905	.1524	.1524
2	.1715	.1334	.1524	.1524	.1524	.1334	.1334
3	.1334	.1334	.1334	.1334	.1334	.1143	.1143
4	.1143	.1143	.1143	.1334	.0953	.0953	.0953
5	.0953	.0953	.8764	.1143	.0953	.0953	.0953
6	.0953	.0953	.9145	.1143	.1143	.1143	.1143
7	.1143	.1143	.1143	.1334	.1143	.1143	.0953
8	.1334	.1143	.1334	.1334	.1143	.1143	.1143
9	.1524	.1524	.1524	.1334	.1334	.1524	.1334
10	.1905	.1905	.1524	.1334	.1524	.1524	.1524
11	.2096	.2096	.1524	.1715	.1715	.1715	.1715
12	.2286	.2477	.2096	.1715	.1905	.1905	.2286
13	.2667	.2667	.1905	.1905	.2477	.2286	.2096
14	.2096	.2286	.2477	.1715	.2096	.2667	.2286
15	.2096	.2286	.2286	.1905	.2667	.2286	.2667
16	.2096	.2096	.2477	.1905	.2286	.2286	.2667
17	.2286	.2477	.1905	.1905	.2286	.2286	.2858
18	.2477	.2667	.2286	.1905	.2096	.2096	.2667
19	.2477	.2858	.2667	.2477	.2858	.2477	.2096
20	.2477	.3048	.2477	.2286	.2667	.2286	.2667
21	.2477	.2667	.2858	.2286	.2477	.2286	.2667
22	.2096	.2667	.2667	.2286	.2286	.2286	.2667
23	.2096	.2477	.2667	.2096	.1715	.1905	.2667
24	.2286	.1905	.2477	.2286	.2096	.1905	.1715
Max	.2667	.3048	.9145	.2477	.2858	.2667	.2858
Min	.0953	.0953	.1143	.1143	.0953	.0953	.0953
Avg	.1913	.1985	.2588	.1754	.1858	.1794	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213017 / 22/11KV BHAIROBA SUB-STATION

Feeder No / Name : 204 / RUBY HALL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.9907	.9145	.8383	.9526	.8764	.8383
2	.9145	.9526	.8764	.8002	.9145	.8383	.8002
3	.8954	.9145	.8383	.7621	.8383	.8002	.7621
4	.8764	.8764	.8764	.724	.8002	.8002	.724
5	.8383	.9145	.9145	.7621	.8383	.8383	.7621
6	.9145	.9526	.8764	.8002	.8764		.8383
7	.9526	.9907	.8764	.8383	.9526	.9717	.9335
8	1.1431	1.086	.9335	.9145	1.0479	1.0288	1.0669
9	1.3527	1.3908	1.0098	.9907	1.4289	1.2003	1.3908
10	1.6956	1.5813	1.2193	1.0669	1.6766	1.6385	1.6956
11	1.848	1.8861	1.2955	1.0669	1.8671	1.6385	1.8671
12	1.9243	1.8671	1.4098	1.1431	1.9433	1.7147	2.0005
13	1.8099	1.7528	1.3717	.9717	1.9243	1.6575	1.9814
14	1.829	1.8099	1.2003	1.0479	1.848	1.5813	2.0386
15	1.9433	1.9052	1.3717	1.1431	1.8861	1.848	2.1148
16	1.9624	1.9624	1.3146	1.0098	1.9814	1.7718	2.0957
17	1.8671	1.7909	1.2003	.9907	1.848	1.6956	1.9624
18	1.6385	1.5813	1.2003	1.1622	1.6766	1.6766	1.8099
19	1.6385	1.5623	1.2384	1.1812	1.6766	1.6004	1.6575
20	1.3908	1.3717	1.1812	1.1241	1.467	1.3717	1.3336
21	1.1622	1.2003	1.0479	1.1431	1.2193	1.2003	1.2955
22	1.1431	1.105	.9907	1.105	1.1241	1.1622	1.3336
23	1.1241	1.0669	.9526	1.0098	1.086	1.0288	1.2193
24	1.0098	1.0288	.9717	.8764	.9907	.9335	.8954
Max	1.9624	1.9624	1.4098	1.1812	1.9814	1.848	2.1148
Min	.8383	.8764	.8383	.724	.8002	.8002	.724
Avg	1.3678	1.3559	1.0868	.9780	1.3694	1.2989	1.3924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601]

BU 4601

Substation No/ Name :- 213017 / 22/11KV BHAIROBA SUB-STATION

Feeder No / Name : 205 / VIDYUT NGR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.2955	1.2574	1.3336	1.2193	1.2193	1.2193
2	1.2574	1.2193	1.1812	1.2574	1.1431	1.1431	1.1431
3	1.1812	1.1431	1.105	1.1812	1.105	1.105	1.105
4	1.105	1.2574	1.0669	1.1431	1.1431	1.1431	1.0669
5	1.0669	1.3336	1.1812	1.2193	1.2193	1.1812	1.1812
6	1.3336	1.4098	1.2955	1.2955	1.2955	1.2574	1.3336
7	1.5623	1.5242	1.4098	1.3717	1.4098	1.4861	1.5242
8	1.7528	1.7337	1.6004	1.5242	1.7147	1.7147	1.6956
9	1.9052	1.9052	1.7718	1.6575	1.8099	1.7528	1.829
10	1.9624	2.0386	2.0195	1.8861	2.0386	1.9243	1.9243
11	1.7718	2.0195	1.9052	1.8099	2.0195	2.0195	1.9433
12	1.7337	1.9624	1.8671	1.7909	1.9052	1.8099	1.9052
13	1.7528	1.8671	1.6956	1.6575	1.7718	1.7147	1.7147
14	1.6575	1.7337	1.6194	1.6385	1.6575	1.6004	1.6385
15	1.6385	1.848	1.6766	1.6385	1.7147	1.6004	1.7337
16	1.6956	1.7528	1.6004	1.5623	1.6766	1.6194	1.7718
17	1.6766	1.7147	1.6004	1.7337	1.6575	1.6194	1.7718
18	1.6575	1.7528	2.0576	1.6194	1.7528	1.7718	1.8671
19	1.9243	2.0386		1.9624	1.9243	1.9624	2.191
20	1.9624	1.9624	1.9624	1.848	1.9243	2.0005	2.0195
21	1.8099	1.8671	1.848	1.7528	1.8671	1.9052	1.9433
22	1.6766	1.6385	1.7147	1.6194	1.6004	1.829	1.8099
23	1.5051	1.5242	1.6004	1.5432	1.4098	1.448	1.6385
24	1.4098	1.3336	1.3146	1.4098	1.2955	1.2955	1.2955
Max	1.9624	2.0386	2.0576	1.9624	2.0386	2.0195	2.191
Min	1.0669	1.1431	1.0669	1.1431	1.105	1.105	1.0669
Avg	1.5972	1.6615	1.5805	1.5607	1.5948	1.5885	1.6361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213017 / 22/11KV BHAIROBA SUB-STATION

Feeder No / Name : 206 / BUND PUMPING SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8764	.8383	.8002	.8764	.8002	.8764
2	.8192	.8383	.8002	.743	.8383	.7621	.8383
3	.7811	.8002	.7621	.724	.8002	.743	.8002
4	.743	.8002	.8002	.7621	.8002	.7621	.7621
5	.724	.8383	.8764	.8002	.8764	.8764	.8002
6	.8192	.9335	.9335	.8383	.9526	.9526	.8764
7	1.0288	1.0288	.9907	.8764	1.0288	1.0288	.9907
8	1.2003	1.2193	1.0669	.9907	1.1431	1.105	1.2003
9	1.3717	1.3146	1.105	1.0669	1.3527	1.2765	1.3146
10	1.5813	1.5051	1.2003	1.1241	1.5623	1.3717	1.5242
11	1.6766	1.5623	1.2765	1.2003	1.6194	1.448	1.6385
12	1.6194	1.6194	1.3527	1.2384	1.5623	1.4289	1.6004
13	1.4098	1.5242	1.2384	1.2955	1.5623	1.3908	1.5623
14	1.467	1.5051	1.2003	1.1241	1.5051	1.3146	1.5432
15	1.4289	1.448	1.3146	1.086	1.5242	1.467	1.5813
16	1.4861	1.4861	1.2193	1.1622	1.4098	1.3527	1.6004
17	1.467	1.5051	1.2955	1.1431	1.5242	1.4098	1.6194
18	1.467	1.448	1.3336	1.1812	1.4289	1.3717	1.6575
19	1.5813	1.5623	1.4861	1.3336	1.5242	1.448	1.6766
20	1.3908	1.4098	1.2955	1.3336	1.3908	1.4098	1.4289
21	1.3717	1.2955	1.2193	1.2574	1.2955	1.3146	1.448
22	1.1812	1.105	1.105	1.086	1.1431	1.1622	1.1812
23	1.0098	1.0479	.9526	1.0288	.9907	1.086	1.0479
24	.8954	.8954	.9145	.8764	.8954	.8383	.8954
Max	1.6766	1.6194	1.4861	1.3336	1.6194	1.467	1.6766
Min	.724	.8002	.7621	.724	.8002	.743	.7621
Avg	1.2241	1.2320	1.1074	1.0447	1.2336	1.1717	1.2694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601]

BU 4601

Substation No/ Name :- 213017 / 22/11KV BHAIROBA SUB-STATION

Feeder No / Name : 207 / PHILIPS QTR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8383	.8002	.7621	.8002	.8573	.8383
2	.8954	.8764	.8383	.724	.8383	.8002	.8002
3	.8954	.9907	.9526	.6859	.9526	.7621	.8002
4	.8954	1.0669	1.0288	.8002	1.0288	.8383	.8764
5	.9145	1.1431	1.1431	.8764	1.1431	.9145	.9526
6	1.0098	1.2574	1.2574	.9526	1.2193	1.0288	1.0669
7	1.2765	1.3336	1.3336	1.0288	1.2574	1.1812	1.2193
8	1.5242	1.3908	1.3717	1.1431	1.3146	1.3717	1.4289
9	1.467	1.5242	1.467	1.2384	1.5242	1.4098	1.467
10	1.6575	1.6385	1.6385	1.1622	1.6004	1.6766	1.7147
11	1.6004	1.7147	1.6575	1.2955	1.8099	1.6004	1.6575
12	1.6766	1.5051	1.6194	1.2765	1.6194	1.5242	1.7147
13	1.467	1.6385	1.5813	1.2384	1.7147	1.5242	1.5242
14	1.5432	1.6004	1.467	1.3336	1.7337	1.6385	1.467
15	1.6956	1.5623	1.5242	1.2384	1.5051	1.448	1.6385
16	1.5623	1.5432	1.5623	1.1812	1.5813	1.5432	1.7909
17	1.6385	1.5051	1.7718	1.3146	1.5623	1.5623	1.6194
18	1.448	1.5242	1.448	1.2574	1.5432	1.4289	1.7147
19	1.3717	1.448	1.4861	1.2193	1.448	1.5051	1.448
20	1.2955	1.3336	1.1812	1.3336	1.2384	1.2765	1.3146
21	1.2955	1.2574	1.2574	1.3146	1.2193	1.1622	1.2574
22	1.0288	1.086	1.1431	.9907	1.105	1.086	1.1431
23	.9526	.9145	1.0669	.8954	1.0288	.9907	.9717
24	.9335	.8573	.8002	.8002	.8192	.8764	.8573
Max	1.6956	1.7147	1.7718	1.3336	1.8099	1.6766	1.7909
Min	.8954	.8383	.8002	.6859	.8002	.7621	.8002
Avg	1.2900	1.3146	1.3082	1.0860	1.3170	1.2503	1.3035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213017 / 22/11KV BHAIROBA SUB-STATION

Feeder No / Name : 208 / MEERA NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.7621	.8383	.8383	.8002	.8383	.8002
2	.724	.743	.8002	.8002	.7621	.7621	.7621
3	.7049	.7811	.8002	.7621	.7621	.8002	.8002
4	.6668	.8383	.8383	.7621	.8002	.8383	.8383
5	.6478	.8764	.8764	.8383	.8383	.8764	.9145
6	.7621	.9526	.9145	.9145	.8764	.9335	.9907
7	.8954	1.0288	.9526	.9907	.9145	.9907	1.0669
8		1.105	.9717	1.0669	.9717	1.0479	1.105
9	1.3146	1.2955	1.2193	1.1431	1.3527	1.2955	1.2765
10	1.2574	1.2765	1.3527	1.2955	1.3336	1.3717	1.3717
11	1.3527	1.4098	1.448	1.2955	1.4289	1.3908	1.3527
12	1.448	1.467	1.5051	1.4289	1.4861	1.5051	1.3908
13	1.2955	1.3336	1.448	1.3908	1.467	1.448	1.5432
14	1.4289	1.3717	1.3146	1.3527	1.3527	1.2765	1.4289
15	1.2765	1.3336	1.3527	1.2003	1.3336	1.2765	1.467
16	1.2955	1.3717	1.3527	1.2193	1.3908		1.4861
17	1.2765	1.3908	1.2955	1.2574	1.3527	1.3336	1.467
18	1.3336	1.3146	1.3717	1.2955	1.3146	1.4098	1.467
19	1.4098	1.3717	1.4098	1.3336	1.448	1.3908	1.5432
20	1.3717	1.3336	1.2765	1.2955	1.3336	1.3908	1.3908
21	1.2574	1.2384	1.1812	1.2574	1.2574	1.3336	1.3336
22	1.105	1.1622	1.105	1.1812	1.1622	1.1812	1.3717
23	1.0288	1.086	1.0288	1.0479	.9907	1.0479	1.105
24	.8192	.8002	.8954	.9145	.8573	.8764	.8573
Max	1.448	1.467	1.5051	1.4289	1.4861	1.5051	1.5432
Min	.6478	.743	.8002	.7621	.7621	.7621	.7621
Avg	1.1067	1.1518	1.1479	1.1201	1.1495	1.1572	1.2138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213034 / 22/11 KV GODREJ

Feeder No / Name : 201 / GPIL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1696	.1677	.1619	.1619	.1619	.16
2	.1886	.1677	.1886	.1619	.1619	.16	.144
3	.1372	.1638	.1296	.16	.1457	.1457	.1457
4	.1372	.1638	.1311	.1457	.1457	.1619	.1457
5	.1619	.1619	.1311	.1619	.144	.1619	.1457
6	.1844	.1638	.1677	.1619	.1619	.1457	.1457
7	.2012	.1989	.1886	.176	.1781	.1619	.176
8	.1619	.2058	.1753	.1781	.1781	.1943	
9	.1715	.3086	.1595	.1457	.2591	.2591	.2753
10	.3887	.3201	.181	.1524	.3887	.3801	.4163
11	.3887	.3563	.2195	.1677	.4344	.4525	
12	.421	.3887	.2195	.1677	.4344	.4066	.4755
13	.3887	.3887	.2172	.2075	.4294	.4108	.4344
14	.3681	.3563	.2149	.1677	.4294	.3801	.4854
15	.3841	.3681	.2012	.1619	.4481	.4031	.4904
16	.4252	.5068	.2172	.1677	.4163	.4338	.4715
17	.3982	.4024	.2172	.1677	.4294	.4338	.4527
18	.3801	.4024	.2012	.1844	.3982	.3961	.4338
19	.3045	.362	.156	.1844	.3258	.3206	.3772
20	.2774	.3045	.1886	.1844	.2629	.2452	.2829
21	.2452	.2172	.1781	.1781	.2012	.2075	.2267
22	.1886	.2058	.1619	.1781	.1619	.1619	.1943
23	.1886	.1844	.1781	.1781	.1781		.1781
24	.1677	.1886	.1715	.1619	.1781	.1619	.1619
Max	.4252	.5068	.2195	.2075	.4481	.4525	.4904
Min	.1372	.1619	.1296	.1457	.144	.1457	.144
Avg	.2686	.2773	.1818	.1693	.2772	.2759	.2918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213034 / 22/11 KV GODREJ

Feeder No / Name : 203 / Ruby Hall

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	.7545	.679	.6348	.5729	.6348	.6468
2	.7167	.6979	.6413	.5975	.5544	.5975	.5506
3	.7167	.6602	.6224	.5788	.5544	.5788	.583
4	.7733	.6602	.6224	.5601	.5729	.5975	.6283
5	.811	.7545	.6979	.5914	.5914	.6161	.6535
6	.9054	.8488	.7922	.6161	.7842	.7842	.7655
7	1.0185	.9431	.8299	.6653	.8215	.9335	.8962
8	1.0185	.9619	1.0562	.7095	.9335	1.1203	1.0829
9	1.1694	1.0562	1.0562	.7095	1.1203	1.2323	1.2696
10	1.1576	1.1576	1.1317	.6979	1.2696	1.3203	1.3014
11	1.1949	1.307	1.3203	.8215	1.1317	1.3392	1.4146
12	1.3443	1.2696	1.2449	.7842	1.2449	1.226	1.1694
13	1.1576	1.2696	1.1317	.7282	1.2637	1.2449	1.2826
14	1.1763	1.3817	1.1506	.8299	1.3392	1.2449	1.2071
15	1.1949	1.2696	1.1694	.7282	1.2449	1.2071	1.2826
16	1.2826	1.2826	1.094	.8215	1.1506	1.2071	1.4335
17	1.2449	1.2449	1.1317	.7545	1.1317	1.1128	1.1883
18	1.094	1.0374	.9808	.7922	1.2071	1.1317	1.1694
19	1.0374	1.1128	.9431	.7356	1.0751	1.0185	1.0751
20	.9997	.9808	.9431	.7545	.9808	.9808	1.0562
21	.9808	.9242	.8589	.7095	.9054	.9431	1.0082
22	.8676	.7922	.7468	.7095	.8215	.7842	.8215
23	.7922	.7545	.6722	.6722	.7468		.7468
24	.7545	.7733	.7167	.6348	.5975	.6722	.6722
Max	1.3443	1.3817	1.3203	.8299	1.3392	1.3392	1.4335
Min	.7167	.6602	.6224	.5601	.5544	.5788	.5506
Avg	1.0060	.9956	.9264	.7016	.9423	.9795	.9961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213303 / 22/11 KV ALANKAR

Feeder No / Name : 201 / 11 KV NUCLUES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.679	.6413	.7167	.6478	.6602	.6859
2	.6224	.6413	.6036	.6979	.6287	.6413	.6478
3	.6036	.6224	.5847	.6979	.6097	.6413	.6287
4	.5847	.6602	.6224	.6979	.6097	.6413	.6287
5	.6413	.6979	.6602	.6979	.6097	.6413	.6478
6	.6979	.7167	.679	.7167	.6668	.6413	.6859
7	.7167	.7167	.679	.7167	.6859	.679	.7049
8	.8299	.8676	.7922	.7356	.7811	.7733	.7621
9	1.0288	1.094	.9431	.811	1.0098	.9242	
10	1.3717	1.4523	1.2637	.9619	1.3336	1.1506	1.3014
11	2.2291	2.1502	1.8673	1.6975	2.21	2.0182	2.1502
12	2.3624	2.5274	2.1502	1.8107	2.3815	2.1502	2.3011
13	2.5149	2.5086	2.1691	2.0182	2.3624	2.1502	2.4331
14	2.3815	2.4709	2.1691	2.1502	2.4768	2.2257	2.4143
15	2.4709	2.3954	2.3011	2.1338	2.5911	2.32	2.4331
16	2.4897	2.2445	2.1502	2.0957	2.4387	2.4006	2.5086
17	2.452	2.32	2.0936	2.0576	2.3624	2.1719	2.5086
18	2.2822	2.2445	2.1879	2.21	2.2862	2.1338	2.32
19	2.2634	2.3011	2.1879	2.2862	2.2481	2.21	2.3011
20	2.1125	2.0936	2.2822	2.2481	2.1338	2.21	2.2634
21	1.9427	1.8673	2.0182	1.829	1.9814	1.9052	2.1719
22	1.1128	1.094	1.1883	1.2193	1.1317	1.1431	1.3146
23	.8299	.8488	.9242	.8764	.8865	.8573	.9717
24	.7167	.7167	.6979	.7356	.6859	.7167	.724
Max	2.5149	2.5274	2.3011	2.2862	2.5911	2.4006	2.5086
Min	.5847	.6224	.5847	.6979	.6097	.6413	.6287
Avg	1.4966	1.4971	1.4107	1.3674	1.4900	1.4169	1.5439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213303 / 22/11 KV ALANKAR

Feeder No / Name : 202 / QUEENS GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.6413	.5658	.6602	.6478	.5847	.6097
2	.5847	.6036	.5281	.6224	.6097	.5847	.5716
3	.5658	.5847	.547	.6224	.5716	.5847	.5525
4	.6036	.6224	.5847	.6224	.5335	.5847	.5335
5	.6602	.6602	.5847	.6224	.5716	.5847	.5716
6	.679	.7167		.6224	.6287	.6036	.6287
7	.7167	.811	.7167	.6602	.7621	.6979	.8383
8	.8676	.9997	.9054	.8676	.9335	.8676	.9907
9	1.0669	1.1317	1.0185	.9619	1.105	.9619	1.0751
10	1.105	1.2071	.9431	.9431	1.0479	.9997	1.0751
11	1.1241	1.094	1.0185	.9619	1.105	.9431	1.0562
12	1.0669	1.094	.9619	.9054	.9907	.8676	1.1317
13	.9907	1.0374	.9054	.9054	.9145	.8865	1.0185
14	.9335	1.0374	.8299	.8676	.9145	.7733	.9808
15	.9054	.9431	.8299	.8764	.9526	.7545	.9997
16	.9619	.9808	.7545	.8383	.8573	.8192	.9808
17	.9808	.9997	.811	.8002	.9335	.8383	.9431
18	1.0374	1.0374	.9054	.9145	.8764	.8002	.9619
19	1.2449	1.1883	1.1506	1.086	1.0669	1.0669	1.1694
20	1.2637	1.1128	1.1694	1.1431	.9526	.9717	1.0562
21	1.094	1.0185	1.0185	.9907	.9335	.8383	1.0098
22	.9242	.8676	1.0185	.9145	.7922	.8002	.9717
23	.811	.7356	.8488	.8002	.7167	.6859	.8002
24	.6602	.679	.6413	.6979	.7049	.6036	.6478
Max	1.2637	1.2071	1.1694	1.1431	1.105	1.0669	1.1694
Min	.5658	.5847	.5281	.6224	.5335	.5847	.5335
Avg	.8946	.9085	.8373	.8295	.8384	.7793	.8823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601]

BU 4601

Substation No/ Name :- 213303 / 22/11 KV ALANKAR

Feeder No / Name : 203 / L K CORPORATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3395	.3395	.3206	.3584	.3584
2	.3206	.3018	.3206	.3206	.3018	.3584	.3206
3	.3206	.2829	.3018	.3206	.2829	.3395	.3206
4	.3584	.2829	.3018	.3206	.3018	.3584	.3395
5	.3584	.3584	.3206	.3206	.3018	.3584	.3395
6	.3772	.3961	.3395	.3395	.3395	.3584	.3772
7	.415	.415	.3961	.3772	.415	.3961	.4338
8	.4904	.4904	.3961	.3961	.4904	.4338	.4715
9	.6979	.7922	.5281	.415	.6979	.5658	.8488
10	1.0185	1.226	.6413	.5093	1.0374	.9619	.9808
11	1.1506	1.2826	.7167	.5093	1.1506	1.1883	1.1128
12	1.1317	1.2071	.7545	.5093	1.1694	1.1506	1.0374
13	1.1506	1.226	.7167	.6036	1.1317	1.0751	1.2071
14	1.1128	1.2071	.679	.5093	1.1694	1.1506	1.1506
15	1.3014	1.2071	.6602	.4715	1.2071	1.0374	1.1694
16	1.3203	1.1883	.679	.4715	1.2071	1.0185	1.1506
17	1.2449	1.226	.6036	.4527	1.1317	1.094	1.1317
18	1.0751	1.1317	.6413	.415	1.0374	.9431	
19	1.0562	1.0374	.6224	.5281	.9431	.8299	.8676
20	.7545	.7922	.5093	.4904	.6602	.6036	.679
21	.6413	.4904	.4904	.4338	.5847	.547	.5658
22	.4904	.4527	.4527	.4338	.5093	.4527	.5281
23	.4527	.4338	.4527	.415	.4338	.4527	.4715
24	.3961	.3961	.3772	.3584	.3584	.3772	.3772
Max	1.3203	1.2826	.7545	.6036	1.2071	1.1883	1.2071
Min	.3206	.2829	.3018	.3206	.2829	.3395	.3206
Avg	.7490	.7568	.5100	.4275	.7160	.6837	.7061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213303 / 22/11 KV ALANKAR

Feeder No / Name : 204 / INOX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.415	.3772	.381	.3772	.381
2	.3206	.3018	.3772	.2829	.3239	.3395	.2858
3	.3206	.3018	.3584	.2452	.3048	.2829	.2667
4	.2829	.2641	.3206	.2452	.3048	.2641	.2477
5	.2829	.2641	.2829	.2452	.2858	.2641	.2667
6	.2641	.2829	.2641	.2452	.3048	.2641	.2667
7	.2829	.2829	.2641	.2641	.3048	.2829	.2858
8	.3395	.3772	.3206	.3206	.3429	.3206	.3048
9	.4572	.415	.3772	.3584	.4001	.3961	.3961
10	.5335	.4904	.4338	.4527	.4382	.5658	.4715
11	.6413	.5847	.4904	.547	.6097	.6224	.6602
12	.7049	.6979	.6036	.5281	.6668	.7167	.7733
13	.6478	.7167	.5658	.5658	.6859	.6979	.7356
14	.6478	.6979	.5658	.5847	.6859	.6979	.7922
15	.7167	.6979	.6413	.5906	.8002	.7167	.7733
16	.7356	.6979	.6413	.6668	.743	.6859	.7733
17	.7733	.8299	.6036	.5906	.7049	.724	.7167
18	.7356	.679	.6413	.5716	.6859	.6478	1.094
19	.679	.6036	.6602	.5525	.6478	.6859	.7167
20	.6413	.6224	.6036	.5335	.6097	.5716	.679
21	.6224	.5658	.5658	.6859	.6287	.5716	.6287
22	.4904	.4904	.4527	.5716	.5093	.4572	.5335
23	.4715	.4904	.4527	.4954	.4904	.4191	.5144
24	.415	.415	.4338	.4338	.4382	.415	.4191
Max	.7733	.8299	.6602	.6859	.8002	.724	1.094
Min	.2641	.2641	.2641	.2452	.2858	.2641	.2477
Avg	.5144	.5046	.4723	.4564	.5124	.4995	.5410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601]

BU 4601

Substation No/ Name :- 213303 / 22/11 KV ALANKAR

Feeder No / Name : 205 / B J MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5658	.6413	.6224	.6224	.6602	.6224
2	.5847	.5281	.6036	.6036	.6036	.6224	.5847
3	.547	.547	.5847	.6036	.5847	.6036	.5658
4	.547	.6036	.6224	.6036	.5847	.6036	.5658
5	.6224	.6224	.6602	.6036	.6036	.6036	.6036
6	.6413	.6602	.6602	.6224	.6413	.6224	.6602
7	.7167	.6979	.6602	.6979	.6979	.6979	.679
8	.8299	.8488	.8488	.679	.8299	.7167	.8299
9	1.0185	1.0185	1.0185	.9054	1.0751	.9808	1.0751
10	1.2071	1.3203	.9619	.8299	1.2449	1.0751	1.3203
11	1.2449	1.3769	.9808	.8488	1.3014	1.0562	1.3203
12	1.226	1.4146	.9054	.8865	1.2449	1.0562	1.3957
13	1.226	1.2637	.9808	.7167	1.2449	.9054	1.3203
14	1.1883	1.2449	.811	.7545	1.2826	.8865	1.3957
15	1.2071	1.2449	.7922	.6979	1.2826	.9054	1.3203
16	1.1506	1.2637	.7545	.6602	1.2826	.8299	1.3203
17	1.1694	1.226	.6979	.7545	1.2449	.8488	1.3392
18	.9997	1.0751	.6979	.679	1.1317	.7922	.9808
19	1.0751	1.0185	.8488	.7922	1.0185	.8299	1.0185
20	.9619	.9619	.8299	.7922	.8488	.8299	.9054
21	.8488	.811	.811	.811	.8676	.7922	.8299
22	.7545	.7922	.7356	.7733	.811	.7922	.7922
23	.6413	.679	.7167	.7167	.7545	.7167	.7733
24	.6224	.6224	.7167	.6413	.679	.6979	.679
Max	1.2449	1.4146	1.0185	.9054	1.3014	1.0751	1.3957
Min	.547	.5281	.5847	.6036	.5847	.6036	.5658
Avg	.9014	.9336	.7725	.7207	.9368	.7969	.9541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213303 / 22/11 KV ALANKAR

Feeder No / Name : 208 / Jahangir Hospital
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2829	.3206		.3018	.3584	.3395
2	.3018	.3206	.3018	.2641	.2641	.3584	.3018
3	.2829	.3395	.3018	.2641	.2641	.3772	.2829
4	.2829	.3584	.2829	.2641	.2641	.3772	.3018
5	.3206	.3584	.3206	.2641	.3018	.3772	.3018
6	.3206	.3961	.3395	.2641	.3772	.3772	.3206
7	.4527	.4527	.3395	.2829	.4338	.415	.415
8	.4904	.5093	.4904	.415	.4904	.4904	.5093
9	.5281	.547	.547	.415	.5281	.5281	.6224
10	.5658	.547	.5093	.3772	.5847	.547	.5658
11	.6224	.547	.6224	.4338	.5847	.5847	.6224
12	.5847	.6224	.547	.4527	.6036	.5847	.5847
13	.6036	.6036	.547	.4527	.6413	.6036	.6979
14	.679	.6036	.547	.4527	.6224	.547	.6602
15	.5658	.5847	.5658	.4715	.6036	.6413	.5658
16	.5847	.5658	.5658	.4527	.5281	.6602	.5847
17	.547	.5281	.5847	.415	.547	.6224	.5658
18	.5093	.4904	.5847	.4338	.5093	.5281	.6036
19	.5093	.5093	.5093	.4338	.5281	.5281	.5281
20	.3961	.4338	.3961	.4338	.4527	.3772	.4715
21	.415	.415	.4527	.3772	.4904	.4338	.4527
22	.3395	.415	.3961	.3395	.3772	.3961	.3772
23	.415	.3395	.3961	.3206	.3961	.3772	.3772
24	.3584	.3772	.3395	.3584	.3206	.3584	.3395
Max	.679	.6224	.6224	.4715	.6413	.6602	.6979
Min	.2829	.2829	.2829	.2641	.2641	.3584	.2829
Avg	.4574	.4645	.4503	.3756	.4590	.4770	.4747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213303 / 22/11 KV ALANKAR

Feeder No / Name : 301 / BSNL

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9239	1.1694	1.1317	1.094	1.1317	1.094	1.1317
2	1.1317	1.1317	1.1317	1.094	1.094	1.094	1.094
3	1.1317	1.1317	1.1317	1.094	1.094	1.094	1.094
4	1.094	1.1317	1.094	1.094	1.094	1.094	1.094
5	1.094	1.1694	1.094	1.094	1.094	1.094	1.094
6	1.1317	1.1694	1.1317	1.1317	1.094	1.1317	1.1317
7	1.1317	1.1317	1.1317	1.1317	1.1317	1.1317	1.1317
8	1.1694	1.1694	1.1317	1.1694	1.1694	1.1694	1.1694
9	1.2449	1.1694	1.1694	1.1317	1.2071	1.2071	1.2449
10	1.2826	1.2826	1.2071	1.1694	1.2826	1.2826	1.2826
11	1.3957	1.3957	1.2826	1.2071	1.358	1.3203	1.3203
12	1.4712	1.4712	1.2826	1.2449	1.358	1.3203	1.3203
13	1.3957	1.3203	1.2449	1.2449	1.358	1.3203	1.3203
14	1.3957	1.3203	1.2826	1.2449	1.358	1.3203	1.358
15	1.3957	1.3203	1.2449	1.2826	1.358	1.3203	1.358
16	1.358	1.4335	1.2449	1.2449	1.3957	1.3203	1.358
17	1.3203	1.358	1.2449	1.2071	1.3203	1.2826	1.358
18	1.2826	1.2826	1.2071	1.2071	1.2449	1.2826	1.9993
19	1.3203	1.2449	1.2826	1.2449	1.2449	1.2826	1.2826
20	1.2071	1.2071	1.2071	1.1694	1.2071	1.2071	1.2826
21	1.1694	1.1694	1.2071	1.2071	1.1694	1.2071	1.2071
22	1.2071	1.1694	1.1694	1.1317	1.2071	1.2071	1.2071
23	1.1694	1.1694	1.1694	1.1694	1.1694	1.1694	1.2071
24	1.1694	1.1694	1.1317	1.1317	1.1317	1.1317	1.1694
Max	1.9239	1.4712	1.2826	1.2826	1.3957	1.3203	1.9993
Min	1.094	1.1317	1.094	1.094	1.094	1.094	1.094
Avg	1.2747	1.2370	1.1899	1.1726	1.2197	1.2119	1.2590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213348 / 22kv classic city (westin)SW

Feeder No / Name : 301 / WESTIN

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.7545	.8299	.9054	.679	.679	.5281
2	.6036	.679	.679	.8299	.6036	.6036	.5281
3	.5281	.5281	.5281	.7545	.4527	.5281	.5281
4	.4527	.5281	.5281	.5281	.4527	.4527	.5281
5	.4527	.5281	.5281	.5281	.5281	.4527	.7545
6	.4527	.5281	.6036	.4527	.6036	.5281	.7545
7	.5281	.8299	.7545	.679	.6036	.679	.8299
8	.679	.679	.8299	1.1317	.679	.6036	.8299
9	1.1317	1.2826	.679	1.0562	.7545	.679	.9054
10	.9054	1.2696	.8299	.7545	.9054	1.1317	.8299
11	1.2696	1.2696	.8299	1.1317	1.1317	.9054	.8299
12	.9054	.8299	.9808	1.2071	1.1317	1.2071	.9054
13	1.1317	1.2696	1.2071	1.1317	1.2071	.9054	1.1203
14	.8962	.9054	.679	1.0562	1.1317	.9808	1.2071
15	1.1949	1.0562	1.0562	1.2071	1.2071	1.0562	.9808
16	.8962	1.0562	1.2826	1.1317	.9808	.9808	1.1317
17	1.2071	1.1317	1.2071	.9054	1.1317	.9054	1.1317
18	1.2071	1.1317	1.1317	1.2071	1.2071	.9054	1.1317
19	1.2826	1.1317	1.0562	1.2071	1.2071	1.1317	1.1317
20	1.2826	1.1317	1.2071	1.1317	1.1317	1.0562	1.0562
21	.9808	1.0562	.679	1.0562	1.0562	.9808	1.0562
22	.9808	.9808	1.2071	.679	.9808	.6036	.7545
23	.9054	.7545	1.1317	1.0562	.9054	.5281	.9808
24	.7545	.7545	.8299	.9808	.9054	.7545	.5281
Max	1.2826	1.2826	1.2826	1.2071	1.2071	1.2071	1.2071
Min	.4527	.5281	.5281	.4527	.4527	.4527	.5281
Avg	.8878	.9194	.8865	.9462	.8991	.8016	.8734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213348 / 22kv classic city (westin)SW

Feeder No / Name : 302 / ONYX SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.1509	.1509	.1509	.1509
2	.1509	.1509	.1509	.1509	.1509	.1509	.1509
3	.1509	.1509	.1509	.1509	.1509	.1509	.1509
4	.1509	.1509	.1509	.1509	.1509	.1509	.1509
5	.1509	.1509	.1509	.1509	.1509	.1509	.1509
6	.1509	.1509	.1509	.1509	.1509	.1509	.1509
7	.1509	.2263	.1509	.1509	.1509	.1509	.1509
8	.2263	.2263	.2263	.1509	.2263	.1509	.2263
9	.3018	.3018	.1509	.1509	.3772	.3018	.2263
10	.3772		.1509	.1509	.3772	.3772	.3772
11	.5175	.4527	.2263	.1509	.5281	.3696	.4527
12	.5175	.5228	.2263	.1509	.5281	.3696	.4527
13	.5228	.5175	.2241	.1509	.5281	.4435	.4435
14	.4481	.4527	.2263	.1509	.5281	.4527	.5281
15	.5121	.4527	.2241	.1509	.5281	.4527	.5281
16	.5975	.4527	.3018	.1509	.5281	.4527	.6036
17	.6036	.4527	.3018	.1509	.5281	.4527	.5281
18	.5281	.3772	.2263	.1509	.5281	.3772	.4527
19	.5281	.3772	.2263	.1509	.4527	.3772	.4527
20	.3772	.3018	.2263	.1509	.3772	.3018	.3772
21	.2263	.3018	.2263	.1509	.2263	.2263	.3018
22	.2263	.2263	.2263	.1509	.2263	.2263	.2263
23	.2263	.2263	.2263	.1509	.2263	.2263	.2263
24	.1509	.1509	.2263	.1509	.1509	.1509	.2263
Max	.6036	.5228	.3018	.1509	.5281	.4527	.6036
Min	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Avg	.3310	.3011	.2041	.1509	.3301	.2819	.3203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

BUNDGARDEN DIVISION[303]

WADIA SUB-DN.[601] BU 4601

Substation No/ Name :- 213348 / 22kv classic city (westin)SW

Feeder No / Name : 303 / K.P MALL

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2263	.4527	.3018	.2263	.3772	.2263
2	.3018	.1509	.3772	.3018	.1509	.3018	.2263
3	.1509	.1509	.3018	.2263	.1509	.2263	.1509
4	.1509	.1509	.1509	.2263	.1509	.1509	.1509
5	.1509	.1509	.1509	.1509	.1509	.1509	.1509
6	.1509	.1509	.2263	.1509	.1509	.1509	.1509
7	.2263	.2263	.2263	.1509	.2263	.1509	.1509
8	.3018	.3018	.2263	.2263	.3018	.1509	.2263
9	.3772	.3772	.3018	.3772	.3018	.2263	.3772
10	.6036	.8215	.7545	.8299	.8299	.6036	.5281
11	1.1088	1.2696	1.358	1.1317	1.2826	1.1088	1.0562
12	1.1827	1.5089	1.5089	1.2826	1.358	1.4632	1.6598
13	1.2696	1.1706	1.1203	1.5089	1.4335	1.2567	1.39
14	1.4632	1.5844	1.5364	1.4335	1.2826	1.358	1.4335
15	1.1827	1.4335	1.2567	1.5089	1.358	1.4335	1.5844
16	1.1203	1.5089	1.4937	1.5844	1.4335	1.5089	1.4335
17	1.4335	.1509	1.4335	1.5844	1.4335	1.4335	1.358
18	1.5844	1.5844	1.358	1.5089	1.5089	1.5089	1.358
19	1.5844	1.5844	1.358	1.5844	1.4335	1.4335	1.358
20	1.4335	1.5844	1.4335	1.358	1.2826	1.358	1.4335
21	1.2826	1.4335	1.2826	1.2071	1.1317	1.2826	1.4335
22	.9808	1.0562	.9808	.9054	.9054	.6036	.679
23	.679	.5281	.4527	.679	.679	.3018	.679
24	.5281	.4527	.5281	.4527	.3772	.4527	.3018
Max	1.5844	1.5844	1.5364	1.5844	1.5089	1.5089	1.6598
Min	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Avg	.8177	.8149	.8446	.8613	.8142	.7914	.8124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213032 / 22/11 KV NAGAR RAOD S/STN

Feeder No / Name : 205 / YARWADA INVESTMENT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3361	.3547	.2987	.2987	.3174	.3547
2	.2987	.2987	.3547	.2987	.2987	.3174	.3361
3	.2801	.2987	.3174	.2987	.2987	.2987	.3174
4	.2801	.2801	.3174	.3174	.3361	.2987	.2987
5	.2801	.3174	.3547	.3174	.3734	.3174	.2987
6	.3174	.3547	.4481	.3361	.3921	.3361	.3361
7	.4108	.4294	.4108	.3361	.3734	.3174	.3734
8	.4668	.4668	.4481	.3547	.4481	.3547	.4338
9	.5415	.4481	.4481	.3961	.5415	.4668	.5041
10	.4854	.5228	.4854	.4854	.5415	.5041	.5601
11	.5601	.5415	.4854	.4668	.5415	.5228	.6161
12	.5601	.5415	.5415	.4108	.5415	.4668	.5788
13	.5041	.5658	.4481	.3921	.5415	.4481	.5415
14	.5228	.4668	.4294	.4108	.4668	.4668	.5415
15	.5041	.5228	.4854	.3734	.4668	.5041	.5415
16	.5415	.5041	.4854	.3547	.5228	.5041	.5601
17	.5788	.4854	.5041	.3547	.5228	.4481	.5228
18	.4668	.4854	.4668	.3734	.5041	.4294	.5228
19	.4294	.4854	.4668	.4668	.4854	.4294	.4854
20	.4294		.4294	.4294	.4481	.4108	.4854
21	.4108	.3361	.3921	.3921	.3921	.4294	.3734
22	.3547	.3547	.3734	.3961	.3547	.3921	.3921
23	.4294	.4668	.3361	.3734	.3361	.3361	.3921
24	.3734	.3921	.3734	.2987	.2987	.3361	.2987
Max	.5788	.5658	.5415	.4854	.5415	.5228	.6161
Min	.2801	.2801	.3174	.2987	.2987	.2987	.2987
Avg	.4310	.4305	.4232	.3722	.4302	.4022	.4444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213032 / 22/11 KV NAGAR RAOD S/STN

Feeder No / Name : 206 / LAXMI NAGAR (KALYANI SHEDDABLE URBAN
 NAGAR) Feeder KV- 11 /
 OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6244	1.643	1.5684	1.7737	1.8298	1.7737	1.6057
2	1.4937	1.531	1.4937	1.6804	1.7737	1.6804	1.4937
3	1.4003	1.4563	1.3817	1.6617	1.587	1.587	
4	1.419	1.4563	1.3817	1.8298	1.6804	1.6244	1.531
5	1.6804	1.6804	1.5684	1.9044	1.8111	1.8111	1.9418
6	3.1741	3.3608	2.95	2.7073	3.4915	3.2114	3.5662
7	4.481	4.5557	3.9396	3.4541	4.6117	3.9022	4.6117
8	4.7424	4.7798	4.5184	4.2756	4.7238	4.2756	4.5931
9	4.0703	4.3503	4.2756	4.3317	4.1823	4.2383	4.2196
10	3.8275	4.3381	4.2383	4.5744	3.9956	4.369	3.8836
11	3.3608	3.7342	3.8836	3.9769	3.3608	3.9022	3.4355
12	2.8753	2.95	3.1741	3.5662	2.95	2.9874	3.0247
13	2.4086	2.6699	2.6139	3.1741	2.2032	2.7633	2.1658
14	2.1658	2.2466	2.3712	2.4646	2.0911	2.2218	2.2032
15	1.9418	2.0165	2.0165	1.9791	1.9418	2.0538	1.9791
16	1.9978	1.8671	1.8671	2.0165	1.8298	1.9418	1.8671
17	1.9978	2.0538	2.0165	2.0165	1.9231	1.9978	2.0538
18	2.0725	2.2405	2.3525	2.3339	2.2032		2.2965
19	2.7633	2.8567	2.8753	2.9127	2.838	3.1367	3.006
20	2.7633		2.8753	2.838	2.9313	2.8753	3.0434
21	2.7446	2.8006	2.726	2.8753	2.8006	2.8567	2.894
22	2.9313	2.782	2.5206	2.6699	2.7446	2.8567	2.8193
23	2.4272	2.5393		2.2592	2.3899	2.3899	2.7726
24	2.0538	1.9044	1.9791	1.9605	1.8858	2.0936	1.8671
Max	4.7424	4.7798	4.5184	4.5744	4.7238	4.369	4.6117
Min	1.4003	1.4563	1.3817	1.6617	1.587	1.587	1.4937
Avg	2.6007	2.6875	2.6342	2.7182	2.6575	2.7196	2.7337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213032 / 22/11 KV NAGAR RAOD S/STN

Feeder No / Name : 207 / ALANDI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5228	.5228	.5601	.5601	.5601	.5228
2	.4481	.4481	.4481	.5228	.5228	.5228	.4458
3	.3734	.3734	.3734	.4854	.5041	.5228	.4481
4	.3734	.3734	.3734		.5601	.5601	.4481
5	.5228	.5228	.5228	.6602	.8402	.6535	.7095
6	.9335	1.0082	.8962	.7468	.9896	.8962	.9896
7	1.419	1.4563	1.2696	1.1389	1.419	1.2883	1.5123
8	1.307	1.419	1.3443	1.2696	1.3817	1.3256	1.2696
9	1.1576	1.1203	1.1949	1.2323	1.1576	1.1949	1.0829
10	1.1128	1.1016	1.1016	1.307	1.0829	1.1949	1.1576
11	.9149	.9896	1.0642	1.1576	1.0829	.9709	.9522
12	.8402	.9335	.8589	1.0082	.8215	.9335	.8962
13	.7167	.8029	.7655	.8029	.7842	.7842	.6722
14	.6722	.6722	.6722	.7095	.6348	.7095	.6722
15	.5975	.5975	.5601	.5601	.5975	.6348	.5975
16	.5788	.5975	1.0829	.6722	.5975	.5788	.6348
17	.6908	.6722	.7095	.6722	.7095	.6348	.7842
18	.6908	.7468	.7842	.7468	.7095	.7468	.8215
19	.8962	.9896	.9709	.9522	.9709	.9709	1.0082
20	.9149		.9335	.9335	.9335	.9522	1.0082
21	.8589	.8962	.8962	.8775	.8962	.9522	.9709
22	.7842	.8589	.8402	.8029	.8962	.8402	.9522
23	.7095	.7095	.7468	.8775	.7282	.7842	.7468
24	.5975	.5601	.5601	.5788	.6036	.5975	.5975
Max	1.419	1.4563	1.3443	1.307	1.419	1.3256	1.5123
Min	.3734	.3734	.3734	.4854	.5041	.5228	.4458
Avg	.7764	.7988	.8122	.8380	.8327	.8254	.8292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213032 / 22/11 KV NAGAR RAOD S/STN

Feeder No / Name : 208 / Sambhaji Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.8215	.8215	.8402	.8775	.8775	.8215
2	.7468	.7468	.7468	.8029	.8402	.8402	.7842
3	.6722	.6348	.6348	.7842	.8029	.8029	.7468
4	.6722	.6348	.6348	.8962	.8775		.9522
5	.9335	.9335	.8402	.9335	1.0082	.9709	1.1763
6	1.307	1.307	1.1016	.9896	1.363	1.1203	1.3256
7	1.7364	1.7551	1.4563	1.2323	1.6991	1.3817	1.7924
8	1.8671	1.9044	1.7364	1.6617	1.8671	1.7737	1.8298
9	1.8671	1.9418	1.8298	1.8111	1.7551	1.8111	1.8671
10	1.6787	1.6617	1.7364	1.8111	1.6057	1.9418	1.643
11		1.4937	1.6057	1.6991	1.419	1.6804	1.531
12	1.1576	1.363	1.363	1.6057	1.307	1.4563	1.3443
13	1.0269	1.2883	1.2136	1.2696	1.1203	1.1763	1.0456
14	.9522	1.0082	1.0082	1.1203	.9709	1.0456	1.0829
15	1.0082	.9149	.9522	.9335	.9149	.9896	.9709
16	.9335	.8962	.8962	1.0082	.8215	.8589	.8589
17	.9335	.9149	.8962	1.0082	.8589	.9335	.8589
18	1.0456	1.0642	1.1576	1.0642	1.0082	1.1203	1.0829
19	1.531	1.4937	1.4937	1.6244	1.475	1.5497	1.5684
20	1.475		1.4937	1.531	1.5684	1.531	1.6057
21	1.475	1.4937	1.4937	1.5123	1.4937	1.531	1.5684
22	1.3817	1.4003	1.307	1.3443	1.363	1.4377	1.4146
23	1.1389	1.1203	1.1576	1.1203	1.1576	1.1576	1.1949
24	.9335	.9335	.8962	.8775	.9149	.9149	.8551
Max	1.8671	1.9418	1.8298	1.8111	1.8671	1.9418	1.8671
Min	.6722	.6348	.6348	.7842	.8029	.8029	.7468
Avg	1.1867	1.2055	1.1864	1.2284	1.2121	1.2566	1.2467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213032 / 22/11 KV NAGAR RAOD S/STN

Feeder No / Name : 209 / Parnkuti

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3361	.3361	.3395	.3174	.3361	.3206
2	.3361	.2987	.3361	.3174	.2987	.2987	.2987
3	.2987	.2614	.2987	.3174	.2987	.2987	.2987
4	.2987	.2614	.2987	.3921	.3361	.3361	.2987
5	.3734	.3734	.3734	.4715	.4668	.4668	.4668
6	.6722	.6722	.6348	.5415	.6908	.6161	.6535
7	.8215	.8962	.7842	.6602	.8029	.7095	.8589
8	.8962	.8962	.8589	.7842	.8775	.8775	.8775
9	.8589	.7842	.7468	.7095	.7282	.7842	.7842
10	.6908	.679	.6161	.6908	.6722	.7468	.6348
11	.5281	.5601	.5788	.6722	.5601	.6722	.5041
12	.4481	.4854	.5601	.5788	.4481	.5228	.4108
13	.4527	.5041	.4668	.5601	.4854	.4854	.3734
14	.3734	.3921	.4108	.4481	.4108	.4108	.3734
15	.3584	.3361	.3921	.3361	.3734	.3734	.3361
16	.3361	.3361	.3361	.3734		.3547	.3734
17	.3547	.4108	.4108	.3734	.4108	.3361	.4108
18	.3547	.4481	.4481	.4108	.4481	.4294	.4481
19	.5041	.5415	.5228	.5228	.5601	.5041	.5975
20	.5228		.5601	.5041	.5601	.5041	.5601
21	.5041	.4854	.5228	.4854	.5228	.4854	.5601
22	.4854	.5228	.4668	.4854	.4854	.4854	.4854
23	.4854	.4481	.4481	.4108	.4294	.4294	.4854
24	.4108	.3734	.3361	.3547	.3361	.3547	.3391
Max	.8962	.8962	.8589	.7842	.8775	.8775	.8775
Min	.2987	.2614	.2987	.3174	.2987	.2987	.2987
Avg	.4876	.4914	.4893	.4892	.5009	.4924	.4896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213032 / 22/11 KV NAGAR RAOD S/STN

Feeder No / Name : 210 / Air Port

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.0456	1.0456	.9335	.8535	.9335	.6722
2	.9335	1.0082	.9335	.7842	1.0082	.7095	.6348
3	.8589	.9335	.8589	.6908	.9709	.6535	.5975
4	.8589	.8962	.8589	.7095	.8775	.7468	.5975
5	.9335	.8589	.9335	.7095	.8029	.7655	.6348
6	1.0456	.8215	1.0456	.6908	.8215	.8029	.6535
7	.5601	.7468	1.0456	.6722	.7095	.7468	.6535
8	.7468	.6722	1.0082	.5788	.6535	.7095	.6413
9	.7468	.6722	1.0456	.7842	.6535	.6722	.6348
10	1.1694	.9709	.9335	.9335	.9335	1.0829	1.0082
11	1.0642	.9896	.6161	.9335	1.0829	1.0829	.9709
12	1.0269	.9896	.5041	.9335	1.0456	1.0082	1.1576
13	.9896	.9896	.4108	.9522	1.0456	.9709	1.0642
14	.9997	1.0082	.4481	.8215	1.0456	1.0082	1.0642
15	.9896	.9896	.4294	.8589	.5601		1.0082
16	.9997	1.0456	1.0829	.8402	.9709	.9709	.9709
17	1.0185	1.0082	1.0082	.8402	.9335	1.0456	1.0456
18	1.0374	.9335	.9709	.9709	1.0829	.9896	1.0082
19	1.1576	1.0456	1.0829	1.1763	1.1576	1.1576	1.1203
20	1.1317		1.0829	1.1576	1.1576	1.1576	1.1949
21	1.1317	1.0456	1.0829	1.1203	1.1203	1.1203	1.1203
22	.7095	1.0082	1.0642	.9709	1.1203	1.0829	1.1694
23	1.1203	1.0829	1.0642		1.0642	.9945	1.1389
24	1.0456	1.0456	1.0456	1.0562	1.0829	.9896	.9389
Max	1.1694	1.0829	1.0829	1.1763	1.1576	1.1576	1.1949
Min	.5601	.6722	.4108	.5788	.5601	.6535	.5975
Avg	.9717	.9482	.9001	.8747	.9481	.9305	.9042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213032 / 22/11 KV NAGAR RAOD S/STN

Feeder No / Name : 212 / Nyati

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.307	1.307	1.5684	1.4003	1.5684	1.3817
2	1.2323	1.2323	1.2323	1.531	1.307	1.531	1.3443
3	1.1203	1.1203	1.1203	1.4937	1.2136	1.4937	1.307
4	1.1203	1.1203	1.1203	1.531	1.3443	1.587	1.4003
5	1.307	1.307	1.307	1.531	1.5497	1.6804	1.4937
6	1.7551	1.7924	1.643	1.531	1.7177	1.7177	1.8111
7	2.1658	2.2779	1.9044	1.6991	2.2218	1.9418	
8	2.4646	2.5019	2.2405	2.0351	2.4459	2.5953	2.6326
9	2.8006	2.9127	2.2405	2.1098	2.692	2.9874	2.838
10	3.2065	3.1927	2.3525	2.4272	3.2861	3.4728	3.2114
11	3.0994	3.3048	2.3525	2.3712	3.2487	3.3608	3.1741
12	3.0178	3.062	2.0538	2.2218	3.062	3.2114	3.2301
13	2.7633	2.9127	1.8671		2.9874	2.95	2.8006
14	2.6326	2.5766	1.7918	1.8671	2.8006	2.6886	2.8006
15	2.7073	2.5206	1.6057	1.6991	2.2405	2.6139	2.8753
16	2.6699	2.4832	1.5684	1.7551	2.6139	2.5019	2.95
17	2.5766	2.5019	1.643	1.7551	2.6139	2.5579	2.8753
18	2.5579	2.5019	1.8671	1.7551	2.6513	2.6886	2.8753
19	2.726	2.894	2.2032	2.1285	2.9874	2.5766	2.9874
20	2.5393		2.1285	2.0538	2.6139		2.6886
21	2.2965	2.2592	2.0165	2.0165	2.3899	2.3388	2.3525
22	1.8298	2.2032	1.8671	1.8673	2.1658	2.0351	2.1125
23	1.7177	1.8671	1.8484	1.7737	1.9418	1.8858	2.0165
24	1.5684	1.4937	1.6057	1.6057	1.5089	1.6057	1.531
Max	3.2065	3.3048	2.3525	2.4272	3.2861	3.4728	3.2301
Min	1.1203	1.1203	1.1203	1.4937	1.2136	1.4937	1.307
Avg	2.2159	2.2324	1.7869	1.8403	2.2919	2.3300	2.3778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213032 / 22/11 KV NAGAR RAOD S/STN

Feeder No / Name : 214 / 11 KV Pumping

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0187				
2			.0187				
3			.0187				
4	.0934	.0934	.0934		.0934	.0934	.0934
5	.0934	.0934	.0934		.0934	.0934	.0934
6	.0934	.0934	.0934		.0934	.0934	.0934
7	.0934	.0934	.0934	.0934	.0934	.0934	.112
8	.0934	.0934	.0934	.0747	.0934	.0747	.0934
9	.0934	.0934	.0934	.0754	.0934	.0934	.0934
10	.0934		.0934	.0747	.0187	.0187	.0187
11			.0187	.0187	.0187	.0187	.0187
12			.0187	.0187	.0187	.0187	.0187
13			.0187	.0187	.0187	.0187	.0187
14			.112	.112		.0934	.0187
15	.112	.112	.112	.0943	.112	.112	.112
16	.112	.0934	.112	.0934	.112	.112	.112
17	.0934	.0934	.0934	.0943	.0934	.0934	.0934
18	.0934	.0934	.0934	.112	.0934	.0934	.0934
19	.0934	.0934	.0934	.0934	.0934	.112	.0934
20			.0187	.0187	.0187	.0187	.0187
21		.0187	.0187	.0187	.0187	.0187	.0187
22		.0187					
23		.0187					
24			.0187				
Max	.112	.112	.112	.112	.112	.112	.112
Min	.0934	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0965	.0787	.0654	.0674	.0692	.0706	.0675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213032 / 22/11 KV NAGAR RAOD S/STN

Feeder No / Name : 301 / Jain

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2987	.2614	.2614	.2987	.2614	.2614
2	.2614	.2614	.2614	.2614	.2614	.2614	.2614
3	.2614	.2614	.2614	.2614	.2614	.2614	.2614
4	.2614	.2614	.2614	.2614	.2614	.2614	.2614
5	.2614	.2614	.2614	.2614	.2614	.2614	.2614
6	.2614	.2614	.2614	.2614	2.5019	.2614	.2614
7	.3361	.3361	.2614	.2241	.3734	.2614	.2987
8	.3361	.3734	.2614	.2614		.4108	.4481
9	.5228	.5228	.2987	.2614	.5228	.4854	.4854
10	.6413	.6348	.4108	.2614	.5975	.5975	.5975
11	.6722	.6348	.3734	.2987	.6722	.6348	.5975
12	.6722	.6722	.3734	.2614	.7095	.6348	.6722
13	.6722	.7095	.3734	.2614	.6348	.6722	.6722
14	.6722	.6348	.3734	.2987	.6722	.6722	.6722
15	.7095	.6722	.3361	.2614	.7095	.6722	2.0165
16	.679	.6722	.3734	.2987	.7095	.6348	.7842
17	.679	.6722	.3361	.2987	.6722	.7095	.7468
18	.6413	.6348	.3361	.0373	.6722	.6348	.7095
19	.5658	.5975	.2987	.0373	.5601	.5601	.6348
20	.4527		.2987	.0373	.4481	.4481	.4854
21	.4527	.4854	.2614	.2987	.4481	.4108	.4481
22	.3361	.3361	.2614	.2641	.2987	.3361	.3734
23	.3361	.2987	.2614	.2614	.2743	.2987	.3395
24	.2987	.2987	.2987		.3018	.2683	
Max	.7095	.7095	.4108	.2987	2.5019	.7095	2.0165
Min	.2614	.2614	.2614	.0373	.2614	.2614	.2614
Avg	.4701	.4692	.3065	.2388	.5706	.4546	.5457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213310 / 22/11 KV GIGASPACE

Feeder No / Name : 201 / KPDL-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2772	.2587	.1848	.1715	.2561	.2401
2	.2402	.2402	.2218	.1848	.1543	.2378	.2058
3	.2033	.2033	.1663	.1663	.1543	.2195	.1886
4	.2033	.1848	.1663	.1663	.1543	.2195	.1886
5	.2033	.1848	.1663	.1663	.1543	.2012	.1886
6	.2218	.2033	.1848	.1663	.1715	.2012	.2058
7	.2402	.2402	.2402	.1848	.1886	.2195	.2058
8	.3326	.2957	.2402	.1848	.2401	.2743	.2743
9	.463	.4115	.2957	.2401	.463	.4805	.499
10	.5658	.5658	.3086	.2915	.5658	.6099	.5914
11		.6173	.3429	.2915	.6001	.6099	.6653
12	.6344	.6001	.3086	.2743	.6173	.5914	.6838
13	.6173	.583	.3258	.2743	.6001	.5914	.7023
14	.6173	.6344	.3601	.2915	.6001	.6219	.7023
15	.6767	.6219	.3658	.2915	.6584	.6219	.6767
16	.695	.6219	.4207	.2572	.695	.6219	.7316
17	.695	.6584	.4572	.2743	.7133	.5853	.7682
18	.6584	.6401	.3658	.2915	.6584	.6219	.695
19	.5853	.6036	.3292	.2743	.6584	.6219	.6401
20	.5487	.4938	.2926	.2572	.5853	.5121	.567
21	.4938	.4024	.2772	.2229	.4755	.4287	.463
22	.462	.4066	.2402	.1886	.439	.463	.3944
23	.3326	.3326	.2402	.2058	.3292	.3086	.3258
24	.3142	.2957	.2957	.2033	.2058	.2926	.2915
Max	.695	.6584	.4572	.2915	.7133	.6219	.7682
Min	.2033	.1848	.1663	.1663	.1543	.2012	.1886
Avg	.4478	.4299	.2863	.2306	.4272	.4338	.4623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213310 / 22/11 KV GIGASPACE

Feeder No / Name : 202 / Viman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.3756	1.448	1.2489	1.0631	1.3032	1.2689
2	1.1946	1.3213	1.3575	1.1946	1.0288	1.267	1.2003
3	1.1765	1.3032	1.267	1.1584	1.0288	1.2308	1.1488
4	1.1765	1.3032	1.267	1.1584	1.0288	1.2127	1.1488
5	1.2489	1.3394	1.267	1.1584	1.046	1.2489	1.2174
6	1.448	1.4661	1.3213	1.1584	1.2174	1.3032	1.286
7	1.5927	1.5565	1.4118	1.1765	1.4403	1.5203	1.4575
8	1.9366	1.9366	1.6832	1.4661	1.7661	1.8461	1.869
9	1.9719	2.1091	1.9004	1.4403	2.0405	2.19	2.2081
10	2.0405	2.2291	1.8347	1.6118	2.1262	2.2986	2.2624
11	2.0576	2.2634	2.0062	1.6289	2.1434	2.2262	2.3167
12	2.0233	2.1776	1.989	1.6118	2.1262	2.0995	2.3167
13	2.1091	2.0233	2.0405	1.5261	2.0748	2.0995	2.19
14	1.9204	1.989	1.8347	1.6461	1.9376	2.0633	2.1538
15	2.1357	2.2805	1.9185	1.6289	2.0633	2.0995	2.3891
16	2.2081	2.2805	1.9185	1.5432	2.2805	2.1176	2.2805
17	2.0271	2.1357	1.9185	1.4918	2.0271	1.9728	2.1176
18	2.0995	2.2081	1.9004	1.4403	2.0995	1.9547	2.0995
19	2.2081	2.1719	1.9909	1.6461	2.2081	2.0814	2.2262
20	2.0995	1.9728	1.9185	1.5947	1.9728	2.0452	2.0633
21	2.009	1.9185	1.8823	1.5947	1.8823	1.8347	1.8861
22	1.8099	1.8461	1.7556	1.5775	1.7375	1.7318	1.7318
23	1.6651	1.6651	1.5384	1.3032	1.5565	1.5775	1.5775
24	1.4661	1.3756	1.4842	1.3213	1.1488	1.448	1.3889
Max	2.2081	2.2805	2.0405	1.6461	2.2805	2.2986	2.3891
Min	1.1765	1.3032	1.267	1.1584	1.0288	1.2127	1.1488
Avg	1.7872	1.8437	1.7023	1.4303	1.7102	1.7822	1.8252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213310 / 22/11 KV GIGASPACE

Feeder No / Name : 204 / KPDL-III

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3018	.3018	.2452	.2058	.3142	.2572
2	.2829	.3018	.2641	.2452	.2058	.2957	.2401
3	.2829	.2829	.2641	.2263	.2058	.2957	.2401
4	.2829	.2829	.2452	.2263	.2058	.2957	.2401
5	.2829	.2829	.2452	.2075	.2058	.2957	.2401
6	.3584	.3395	.2452	.2075	.2572	.3142	.2743
7	.3395	.3395	.2452	.2263	.3258	.3326	.3258
8	.415	.3961	.2641	.2263	.3772	.3881	.4287
9	.5658	.6001	.3584	.2229	.5658	.5093	.6036
10	.7716	.7716	.4115	.2401	.823	.8676	.9431
11	.8402	.8745	.4115	.2572	.9259	.8488	.9619
12	.8745	.8916	.4458	.2572	.9431	.8488	.9619
13	.8573	.8745	.4115	.2572	.9088	.8676	1.0185
14	.9431	.9431	.4287	.2572	.9088	.8686	.9997
15	1.0164	.924	.4251	.2401	1.0719	.8871	.9979
16	1.0349	.924	.4805	.2743	.961	.924	.9979
17	.9979	.9979	.4805	.2743	.9979	.8686	.961
18	.8871	.8501	.4251	.2572	.924	.8316	.961
19	.8131	.6838	.3696	.2572	.8316	.7023	.7207
20	.6468	.5729	.2957	.2229	.5544	.5914	.5914
21	.462	.4805	.2641	.2229	.4805	.3944	.4287
22	.4904	.4527	.2641	.2229	.462	.4287	.4458
23	.4527	.4527	.2452	.2229	.462	.4115	.4115
24	.3395	.3395	.3584	.2452	.2229	.3326	.3086
Max	1.0349	.9979	.4805	.2743	1.0719	.924	1.0185
Min	.2829	.2829	.2452	.2075	.2058	.2957	.2401
Avg	.6058	.5900	.3396	.2393	.5847	.5715	.6067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213310 / 22/11 KV GIGASPACE

Feeder No / Name : 206 / Nico Garden

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.5487	.5316	.5658	.5487	.6024	.5316
2	.4973	.5144	.5144	.5144	.5144	.6024	.5144
3	.4801	.5144	.5144	.4973	.4973	.567	.5144
4	.4801	.5144	.5144	.4973	.4973	.5847	.5144
5	.4801	.5658	.5144	.4973	.5316	.6201	.5316
6	.5658	.6344	.5487	.5144	.6516	.6556	.6173
7	.7373	.7373	.6173	.5487	.7373	.7265	.7716
8	.8573	.8916	.7373	.703	.8745	.9036	.8573
9	.8916	.9774	.7888	.7545	.9259	.8573	
10	.8916	.9259	.8745	.9088	.8573	.9088	.9945
11	.8573	.823	.8059	.9774	.8573	.8402	.8573
12	.8402	.8402	.9088	.9602	.8402	.8402	.8916
13	.7716	.8059	.703	.8573	.7716	.8402	.7888
14	.7373	.7545	.8745	.8402	.7373	.7087	.8059
15	.815	.4607	.8328	.7888	.7442	.7796	.7973
16	.7442	.8505	.8682	.7888	.7973	.815	.815
17	.7442	.8505	.8328	.823	.7973	.815	.7973
18	.7973	.9214	.9036	.8402	.7973	.815	.815
19	1.0277	1.0277	1.0631	.9431	.9568	.9922	1.0099
20	.9391	.9745	.9922	.9431	.9568	.9922	.9922
21	.9391	.9745	.9088	.9088	.8859	.9259	.9259
22	.8059	.7888	.8059	.8059	.8505	.7716	.8059
23	.7202	.7202	.7202	.7545	.7087	.7202	.7373
24	.6001	.6001	.6344	.6001	.6344	.6024	.583
Max	1.0277	1.0277	1.0631	.9774	.9568	.9922	1.0099
Min	.4801	.4607	.5144	.4973	.4973	.567	.5144
Avg	.7397	.7590	.7504	.7430	.7488	.7703	.7595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213310 / 22/11 KV GIGASPACE

Feeder No / Name : 207 / KPDL-II

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1629	.1448	.1448	.12	.1698	.1715
2	.1448	.1448	.1448	.1267	.12	.1698	.12
3	.1267	.1267	.1267	.1267	.12	.1509	.12
4	.1267	.1267	.1267	.1267	.12	.1509	.12
5	.1448	.1267	.1267	.1267	.12	.1509	.12
6	.1448	.1448	.1267	.1448	.1372	.1509	.1372
7	.181	.181	.181	.1448	.1715	.2263	.1886
8	.2534	.2534	.1991	.1629	.2572	.2263	.2058
9	.3944	.3601	.2534	.2058	.3944	.3801	.3982
10	.4458	.4458	.2743	.2401	.4801	.4525	.4525
11	.5144	.4801	.2743	.2401	.5144	.4887	.5249
12	.5658	.583	.3086	.2401	.5316	.5792	.5249
13	.583	.583	.3086	.2743	.5316	.543	.543
14	.5487	.5316	.3429	.2743	.5316	.5658	.5068
15	.6224	.6413	.415	.2743	.6036	.6036	.6036
16	.6036	.6036	.3961	.2915	.5847	.6036	.5658
17	.6413	.6036	.3206	.2915	.6224	.5658	.5316
18	.6224	.547	.3206	.2743	.5658	.5281	.5658
19	.5281	.5093	.3018	.2229	.4904	.4904	.4715
20	.4527	.3961	.3018	.2058	.4527	.4527	.4338
21	.3961	.3772	.2172	.1886	.4715	.2915	.2915
22	.3439	.2896	.181	.2058	.3018	.2401	.2572
23	.2715	.2172	.181	.1886	.2263	.2229	.2229
24	.181	.1629	.1448	.1448	.1372	.2263	.2058
Max	.6413	.6413	.415	.2915	.6224	.6036	.6036
Min	.1267	.1267	.1267	.1267	.12	.1509	.12
Avg	.3750	.3583	.2383	.2028	.3586	.3596	.3451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213311 / 22/11 KV IMPERIAL RESIDENCE

Feeder No / Name : 201 / Naiknaware-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4607	.5847	.567	.5493	.5316	.4784	.5144
2	.4607	.5316	.5316	.5493	.4961	.443	.4287
3	.4252	.5316	.4784	.5316	.4961	.4252	.4287
4	.3898	.4961	.443	.5316	.443	.4075	.4287
5	.3898	.443	.443	.4961	.443	.3544	.4287
6	.5847	.5138	.6024	.4961	.6024	.4607	.6001
7	.7265	.6201	.5493	.5316	.7619	.6379	.6859
8	.7087	.7796	.6556	.6201	.7619	.7973	.7716
9	.9036	.7973	.7265	.6859	.7796	.7973	.8573
10	.7716	.8573	.8573	.8573	.8573	.9335	.9335
11	.8573	.7716	.7716	.8573	.7716	.8402	.8402
12	.7716	.7716	.7716	.7716	.8573	.8402	.8402
13	.7716	.7716	.6859	.7716	.7716	.7468	.7468
14	.6859	.6859	.6859	.7716	.7716	.6535	.7468
15	.6859	.6859	.6859	.6859	.6859	.6535	.7468
16	.7468	.7545	.7468	.7468	.6733	.6001	.691
17	.7468	.8402	.7468	.7468	.6556	.7373	.691
18	.7468	.8402	.7468	.8402	.7265	.7545	.7619
19	.9335	.9335	.8402	.9335	.7619	.7888	.7973
20	.8402	.8402	.8402	.8402	.7973	.8573	.7796
21	.8402	.7468	.7468	.7468	.7619	.823	.7796
22	.691	.6733	.7087	.6379	.7087	.6859	.6859
23	.6024	.6379	.6722	.6201	.6556	.6001	.6859
24	.4961	.5847	.6024	.5847	.5493	.5138	.5144
Max	.9335	.9335	.8573	.9335	.8573	.9335	.9335
Min	.3898	.443	.443	.4961	.443	.3544	.4287
Avg	.6766	.6955	.6711	.6835	.6800	.6596	.6827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213311 / 22/11 KV IMPERIAL RESIDENCE

Feeder No / Name : 202 / Modi Solidare

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7468	.7842	.6908	.695	.6468	.6401
2	.7468	.6908	.7468	.6908	.6401	.6161	.5487
3	.7095	.6535	.6908	.6535	.6401	.5601	.5487
4	.6535	.6535	.6348	.6535	.6036	.5601	.5487
5	.6535	.5975	.5601	.6161	.5487	.5041	.5487
6	.8215	.7655	.6535	.5601	.695	.8215	.7316
7	.9896	.9709	.7468	.6348	.8962	1.0829	1.0059
8	1.1763	1.1203	.8589	.7095	1.2403	1.1389	1.0974
9	1.3817	1.643	.9335	.823	1.5546	1.5497	1.5546
10	1.5546	1.5546	1.0974	.9145	1.3717	1.4937	1.4003
11	1.3717	1.4632	1.0974	1.0059	1.4632	1.587	1.4003
12	1.3717	1.3717	1.0974	.9145	1.3717	1.307	1.4937
13	1.2803	1.2803	1.0974	1.0059	1.3717	1.307	1.4003
14	1.2803	1.2803	.9145	.9145	1.2803	1.2136	1.4003
15	1.2803	1.1888	.9145	.823	1.2803	1.1203	1.307
16	1.2136	1.2136	.8402	.8402	1.1763	1.0974	1.2136
17	1.2136	1.2136	.8402	.8402	1.1888	1.1706	1.1763
18	1.1203	1.1203	.9335	.8402	1.1576	1.134	1.1389
19	1.1203	1.1203	.9335	.9335	1.0269	1.0608	1.1016
20	.9335	.9335	.8402	.8402	.8775	1.0059	1.1203
21	.9335	.8402	.8402	.8402	.8775	.8779	.9335
22	.9335	.8029	.8215	.9335	.8962	.9145	.9145
23	.8962	.8402	.7842	.8402	.8029	.823	.9145
24	.7655	.7842	.8029	.7282	.7316	.6908	.7316
Max	1.5546	1.643	1.0974	1.0059	1.5546	1.587	1.5546
Min	.6535	.5975	.5601	.5601	.5487	.5041	.5487
Avg	1.0494	1.0354	.8527	.8020	1.0162	1.0118	1.0363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213311 / 22/11 KV IMPERIAL RESIDENCE

Feeder No / Name : 203 / Gera 77

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1115	.0991	.1036	.12	.1052	.0975	.1334
2	.1115	.0991	.1036	.12	.1052	.1021	.1334
3	.0991	.0867	.0907	.1067	.092	.0894	.1334
4	.0991	.0867	.0907	.1067	.092	.0894	.1334
5	.0991	.0867	.0907	.0934	.092	.0894	.1334
6	.1115	.0991	.1036	.0934	.1052	.1021	.1334
7	.1238	.1238	.0907	.1067	.1183	.1276	.1334
8	.1115	.1362	.1166	.1067	.1446	.1404	.1334
9	.1858	.161	.1555	.1334	.1709	.1787	.2
10	.2667	.2667	.2	.2	.2667	.2801	.3734
11	.2667	.2	.2	.2	.2667	.2801	.2801
12	.2667	.2	.2	.1334	.2	.3734	.3734
13	.2667	.2	.2	.1334	.2	.3734	.3734
14	.2	.2	.2	.1334	.2	.3734	.3734
15	.2	.2667	.2	.2	.2667	.3734	.3734
16	.2801	.2801	.2801	.1867	.2317	.2267	.2298
17	.2801	.2801	.2801	.2829	.1951	.2401	.2042
18	.2801	.1867	.2801	.1867	.1829	.2134	.2042
19	.2801	.2801	.2801	.1867	.1707	.2	.217
20	.2801	.1867	.2801	.1867	.1829	.2	.1787
21	.2801	.1867	.1867	.2801	.1585	.16	.217
22	.1362	.1166	.1467	.1467	.1463	.1334	.2
23	.1238	.1036	.1334	.12	.1097	.1334	.1334
24	.1115	.0991	.1036	.12	.1052	.1097	.1334
Max	.2801	.2801	.2801	.2829	.2667	.3734	.3734
Min	.0991	.0867	.0907	.0934	.092	.0894	.1334
Avg	.1905	.1680	.1715	.1535	.1629	.1953	.2138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213311 / 22/11 KV IMPERIAL RESIDENCE

Feeder No / Name : 204 / Water Front

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5041	.5228	.4108	.3921	.4294	.3772
2	.4481	.4668	.4668	.3734	.3921	.4108	.3772
3	.4294	.4668	.4668	.3734	.3734	.3734	.3772
4	.3921	.4668	.4668	.3734	.3734	.3734	.4715
5	.3921	.4108	.4294	.3361	.3734	.3734	.4715
6	.5415	.5415	.3734	.3361	.4668	.4668	.5658
7	.6908	.6722	.4108	.3547	.5601	.5788	.6602
8	.7095	.8029	.4294	.3734	.7655	.6722	.6602
9	.8029	.9896	.5228	.5658	.8775	.6722	.8488
10	.8488	1.0374	.5658	.6602	.8488	.8402	.8488
11	.9431	.9431	.5658	.6602	.9431	.8402	.9335
12	.9431	.9431	.5658	.6602	.8488	.9335	.9335
13	.8488	.8488	.5658	.6602	.8488	.8402	.8402
14	.8488	.8488	.5658	.5658	.8488	.7468	.9335
15	.8488	.8488	.5658	.6602	.8488	.8145	.9335
16	.8402	.8402	.5601	.5601	.8402	.8676	.9335
17	.8402	.8402	.5601	.4668	.8775	.8299	.9335
18	.8402	.7468	1.1203	.5601	.9149	.8299	.9149
19	.8402	.9335	.6535	.5601	.9335	.9054	.8775
20	.7468	.8402	.5601	.6535	.8775	.9431	.4108
21	.7468	.8402	.5601	.5601	.7842	.7922	.8962
22	.7282	.6348	.5601	.5415	.7095	.7545	.8488
23	.6722	.5415	.4668	.5041	.6722	.7545	.7545
24	.4108	.5041	.5415	.4108	.3921	.4854	.5658
Max	.9431	1.0374	1.1203	.6602	.9431	.9431	.9335
Min	.3921	.4108	.3734	.3361	.3734	.3734	.3772
Avg	.7016	.7297	.5444	.5075	.6985	.6887	.7237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213311 / 22/11 KV IMPERIAL RESIDENCE

Feeder No / Name : 205 / Kalyani Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0387	1.1403	1.1765	1.0498	.9955	1.0498	.9745
2	.9313	1.0679	1.1403	.9955	.9231	.9774	.8859
3	.8238	.9955	1.0679	.9593	.8688	.9231	.8859
4	.7343	.9412	.9955	.905	.8145	.8688	.8859
5	.7164	.8688	.905	.8145	.8145	.8145	.8859
6	1.1283	1.2127	1.086	.7421	1.1041	1.0317	1.1517
7	1.4685	1.4118	1.0136	1.0679	1.3756	1.3575	1.3289
8	1.6297	1.6832	1.2851	1.2851	1.5384	1.6289	1.6832
9	1.8267	1.8642	1.5023	1.4175	1.7556	1.8461	1.8604
10	1.8604	1.6832	1.7718	1.5947	1.7718	1.9605	1.8671
11	1.7718	1.6832	1.5947	1.6832	1.5947	1.7737	1.8671
12	1.5947	1.5947	1.5947	1.5947	1.5061	1.587	1.6804
13	1.4175	1.5061	1.4175	1.5947	1.5061	1.4937	1.4937
14	1.4175	1.4175	1.4175	1.4175	1.4175	1.4003	1.587
15	1.4175	1.4175	1.3289	1.3289	1.4175	1.4937	1.587
16	1.4937	1.4937	1.4003	1.307	1.448	1.3643	1.5203
17	1.4937	1.587	1.4003		1.5203	1.4706	1.5565
18	1.4937	1.4937	1.4003	1.4003	1.5203	1.4529	1.6289
19	1.6804	1.6804	1.587	1.587	1.6289	1.4352	1.7556
20	1.6804	1.587	1.587	1.4937	1.6832	1.4883	1.6832
21	1.587	1.4937	1.4937	1.4937	1.6289	1.4175	1.6651
22	1.4864	1.3575	1.4118	1.3575	1.4842	1.4175	1.5061
23	1.3073	1.3032	1.2489	1.2851	1.2489	1.2403	1.3289
24	1.182	1.1462	1.2308	1.086	1.0679	1.1041	1.1517
Max	1.8604	1.8642	1.7718	1.6832	1.7718	1.9605	1.8671
Min	.7164	.8688	.905	.7421	.8145	.8145	.8859
Avg	1.3826	1.4013	1.3357	1.2809	1.3598	1.3582	1.4342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213311 / 22/11 KV IMPERIAL RESIDENCE

Feeder No / Name : 206 / 11 KV Victoriya Garden

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.0857
6	.052	.052			.0537	.052	.0857
7	.052	.052			.0537	.052	.0857
8	.0693	.0693	.0537		.0716	.0693	.0857
9	.0867	.0693	.0895	.0857	.0895	.0693	.0857
10	.0857	.0857	.0857	.0857	.0857	.0934	.0934
11	.0857	.0857	.0857	.0857	.0857	.0934	.0934
12	.0857	.0857	.0857	.0857	.0857	.0934	.0934
13	.0857	.0857	.0857	.0857	.0857	.0934	.0934
14	.0857	.0857	.0857	.0857			
15	.0857	.0857	.0857	.0857	.0857		
16				.0934	.0537	.0514	
17	.0934	.0934		.0943		.0686	
18	.0934	.0934	.0934	.0934	.052	.0514	.0526
19	.0934	.0934			.052	.0514	.0526
20	.0934		.0934	.0934	.052	.0514	.0701
21	.0934		.0934		.052	.0686	.0526
22	.052		.0526		.052	.0857	.0857
23			.0526		.052		
Max	.0934	.0934	.0934	.0943	.0895	.0934	.0934
Min	.052	.052	.0526	.0857	.052	.0514	.0526
Avg	.0808	.0798	.0802	.0886	.0664	.0696	.0797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213311 / 22/11 KV IMPERIAL RESIDENCE

Feeder No / Name : 301 / G Corp I

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.4066	.3696	.3658	.3734	.2926	.3429
2	.2926	.3696	.3326	.3658	.2987	.2561	.3429
3	.2926	.3696	.2957	.2926	.2987	.2195	.3429
4	.2926	.2957	.2957	.2926	.2987	.2195	.3429
5	.3292	.2957	.2957	.2926	.3361	.2195	.3429
6	.3658	.3326	.4435	.2561	.3734	.2926	.3429
7	.4024	.3696	.4066	.3658	.4481	.4024	.3429
8	.4755	.4435	.3326	.439	.4024	.4755	.3429
9	.439	.4805	.4066	.5144	.4024	.4435	.5144
10	.5144	.5144	.3429	.5144	.5144	.5228	.5228
11	.5144	.5144	.3429	.5144	.5144	.4854	.4481
12	.5144	.5144	.5144	.5144	.3429	.4854	.4481
13	.3429	.5144	.5144	.5144	.5144	.4854	.4854
14	.3429	.5144	.5144	.5144	.3429	.4481	.4854
15	.3429	.5144	.5144	.5144	.3429	.4481	.415
16	.4481	.4854	.4854	.4481	.3696	.3772	.4066
17	.4108	.5228	.4481	.4108	.4066	.3772	.4435
18	.4108	.4481	.4481	.4481	.4066	.3429	.4805
19	.5228	.5228	.4854	.4854	.4435	.3772	.5175
20	.4108	.4854	.5228	.4481	.4805	.4115	.5175
21	.4481	.4854	.5228	.4481	.4435	.4115	.4805
22	.4656	.3696	.4805	.4435	.4066	.3429	.5144
23	.394	.3696	.4435	.3696	.3696	.3429	.5144
24	.3292	.4066	.3696	.3658	.3734	.3326	.3429
Max	.5228	.5228	.5228	.5144	.5144	.5228	.5228
Min	.2926	.2957	.2957	.2561	.2987	.2195	.3429
Avg	.3998	.4394	.4220	.4224	.3960	.3755	.4283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 202 / Zercon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.1509	.0857	.1509	.1509
2	.132	.132	.1509	.1509	.0686	.132	.132
3	.132	.1132	.132	.1132	.0857	.132	.132
4	.1509	.1132	.132	.132	.12	.1509	.1509
5	.1698	.1509	.1509	.132	.0857	.1509	.1698
6	.1886	.1698	.1886	.132	.1372	.1509	.2075
7	.2263	.1886	.2075	.1509	.1715	.1886	.2075
8	.2263	.2263	.1698	.1509	.2058	.2263	.2641
9	.3018	.2829	.2452	.1698	.2401	.2452	.2829
10	.3429	.3258	.2572	.2229	.3086	.2915	.3429
11	.2572	.3086	.2572	.1886	.3086	.2743	.2915
12	.2572	.2915	.2229	.1886	.2743	.2401	.2743
13	.2229	.2401	.2058	.1543	.2743	.2743	.2572
14	.2401	.2058	.1543	.1372	.2058	.0686	.2229
15	.1886	.2229	.1372	.1372	.2743	.2229	.2058
16	.2829	.2829	.2075	.1698	.2263	.2263	.2829
17	.3206	.2641	.2075	.1509	.3018	.2829	.2829
18	.2641	.2452	.2263	.1698	.2452	.2263	.2641
19	.2452	.2075	.2075	.1886	.1886	.2452	.2263
20	.2075	.1886	.2263	.2075	.2452	.2263	.2263
21	.2075	.2075	.2263	.1698	.2263	.2263	.2263
22	.1886	.1886	.1698	.1372	.1698	.1886	.1543
23	.1509	.1509	.1509	.12	.1698	.1886	.1543
24	.1509	.1509	.1698	.1509	.1029	.1509	.1509
Max	.3429	.3258	.2572	.2229	.3086	.2915	.3429
Min	.132	.1132	.132	.1132	.0686	.0686	.132
Avg	.2169	.2087	.1898	.1573	.1968	.2025	.2192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 203 / Sakore Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6979	.6602	.679	.7167	.6001	.7922	.7167
2	.6602	.6224	.6413	.6413	.4801	.7545	.6602
3	.6224	.5658	.5847	.6036	.4287	.7167	.6224
4	.679	.5847	.6602	.5658	.5144	.679	.6036
5	.7356	.6602	.6979	.6036	.6001	.6413	.6602
6	.8299	.811	.7356	.6036	.6859	.679	.7356
7	.8865	.9054	.7733	.6979	.7202	.8865	.8488
8	.9808	.9808	.8488	.7922	.9259	.9808	.9431
9	1.2826	1.1883	.9431	.811	1.1145	1.1317	1.226
10	1.3203	1.2003	1.0288	.9945	1.2003	1.2003	1.2346
11	1.3203	1.2346	1.046	.9774	1.1488	1.1831	1.2003
12	1.2003	1.286	.9945	.9259	1.2003	1.1488	1.2174
13	1.0974	1.2003	.9602	.8402	1.1488	1.0802	1.1831
14	1.1317	1.0288	.9431	.8402	1.0631	1.1145	1.0974
15	1.0802	1.1317	.9088	.7888	1.1317	1.0631	1.1831
16	1.2071	1.1883	.9619	.8488	1.1694	1.1694	1.3392
17	1.2449	1.226	.9997	.8299	1.1883	1.226	1.3392
18	1.2637	1.2071	.9997	.9242	1.1883	1.1317	1.226
19	1.1506	1.2071	1.1694	1.0374	1.3014	1.226	1.2826
20	1.1128	1.1317	1.0562	.9808	1.1694	1.094	1.1883
21	1.0374	1.0562	.9808	.9431	1.0374	.9997	
22	.9808	.9431	.8865	.8059	.9431	.9242	.8745
23	.8299	.8488	.811	.703	.9054	.811	.8402
24	.811	.7356	.7733	.7545	.6516	.811	.7545
Max	1.3203	1.286	1.1694	1.0374	1.3014	1.226	1.3392
Min	.6224	.5658	.5847	.5658	.4287	.6413	.6036
Avg	1.0068	.9835	.8785	.8013	.9382	.9769	.999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 204 / 11 KV Symbiosis

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3206	.3018	.3018	.2572	.3395	.3018
2	.3018	.3018	.3018	.2829	.2401	.3018	.2829
3	.2829	.2829	.2829	.2829	.2229	.3018	.2641
4	.2829	.2641	.2829	.3018	.2743	.2829	.2641
5	.3018	.2641	.3018	.3395	.2572	.3018	.3018
6	.3395	.3018	.3018	.3772	.2401	.3395	.3395
7	.3772	.3395	.3206	.3772	.2743	.3772	.3395
8	.4715	.415	.3772	.3772	.3601	.5093	.4527
9	.5658	.5281	.4904	.4527	.5144	.5658	.6036
10	.583	.5487	.463	.4115	.5487	.5487	.6344
11	.6173	.5487	.5487	.4115	.5487	.5487	.6344
12	.6001	.5487	.5487	.4115	.6859	.5487	.703
13	.6173	.4973	.5487	.4115	.5487	.5487	.6344
14	.583	.4973	.4973	.4115	.5487	.4115	.6173
15	.6173	.5487	.4801	.4115	.5487	.5487	.6173
16	.8865	.7922	.6224	.5281	.8676	.679	.7167
17	.7545	.7545	.5658	.5281	.7922	.6036	.6224
18	.679	.6413	.6224	.5847	.679	.5658	.5658
19	.679	.7167	.5658	.6036	.6413	.5281	.6224
20	.6036	.6413	.4904	.5847	.5658	.4527	.5281
21	.5658	.6036	.4904	.5281	.4904	.4527	.5281
22	.4338	.415	.4527	.3429	.4527	.4527	.4115
23	.3772	.3772	.3772	.3086	.415	.3772	.3601
24	.3206	.3395	.3206	.3395	.3086	.3772	.3018
Max	.8865	.7922	.6224	.6036	.8676	.679	.7167
Min	.2829	.2641	.2829	.2829	.2229	.2829	.2641
Avg	.5068	.4787	.4398	.4129	.4701	.4568	.4853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 205 / 11 KV N V Reality 2

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9997	.9997	.9997	.8676	.7716	1.0185	.9808
2	.9808	.9431	.9431	.8299	.7202	.9431	.9431
3	.9431	.9054	.9054	.8299	.6859	.9054	.9054
4	.9054	.8865	.8676	.8676	.823	.9054	.9054
5	1.0185	.9619	.9054	.8676	.8573	.9808	.9997
6	1.094	1.0751	.9431	.9054	.9431	1.0374	1.1128
7	1.1883	1.1694	.9808	.9054	1.0631	1.1506	1.2071
8	1.3203	1.2826	.9808	.9242	1.2003	1.3014	1.3203
9	1.7164	1.5844	1.0374	.9054	1.5432	1.6598	1.6975
10	1.5432	1.5604	.9602	.8573	1.6461	1.6632	1.5775
11	1.6975	1.749	.9945	.8402	1.6804	1.5947	1.6804
12	1.8004	1.8861	1.0288	.8402	1.7318	1.749	1.7833
13	1.7318	1.7318	.9945	.823	1.749	1.6289	1.7661
14	1.7147	1.6804	.9431	.8402	1.7833	1.6461	1.8176
15	1.7661	1.6118	.9945	.8916	1.7661	1.7318	1.8176
16	1.9805	1.8107	1.226	.9242	1.8296	1.8673	2.0748
17	1.9239	1.905	1.0751	.9619	1.905	1.9805	1.9805
18	1.9239	1.7918	1.0751	.9808	1.9805	1.9427	1.9427
19	1.7918	1.8296	.9997	.9619	1.8861	1.8484	1.8484
20	1.6409	1.5466	.9431	.9431	1.5278	1.6787	1.5844
21	1.3957	1.3769	.9619	.9054	1.3957	1.3957	1.4335
22	1.2637	1.226	.9808	.823	1.1883	1.3203	1.2174
23	1.1694	1.2071	.9431	.8402	1.094	1.1883	1.046
24	1.0751	1.0374	1.0374	.9054	.823	1.0374	1.0374
Max	1.9805	1.905	1.226	.9808	1.9805	1.9805	2.0748
Min	.9054	.8865	.8676	.823	.6859	.9054	.9054
Avg	1.4410	1.4066	.9884	.8851	1.3581	1.4240	1.4450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 206 / SKY MAX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.6036	.5847	.5658	.5144	.5658	.5658
2	.5847	.5658	.5281	.5281	.4801	.5281	.5281
3	.547	.5281	.5093	.4904	.4287	.5093	.4904
4	.6036	.4904	.5281	.4904	.463	.4904	.547
5	.679	.547	.5658	.5281	.5144	.5281	.6036
6	.7167	.679	.6036	.5658	.6001	.5658	.6602
7	.7733	.7545	.6413	.6036	.7373	.7167	.811
8	1.0562	1.0751	.8488	.7356	.9431	.8676	1.0562
9	1.0185	1.0562	.8676	.7733	.9774	1.0185	1.0751
10	1.0802	1.1488	.9259	.8745	1.1488	1.1831	1.0974
11	1.0802	.8745	.9259	.8745	1.0631	1.1145	1.1145
12	1.0117	.8916	.9259	.8402	1.0631	1.0974	1.0802
13	.9945	1.0631	.8745	.8059	.9602	1.046	1.0631
14	.9945	1.046	.8573	.823	1.0117	1.0117	1.0802
15	.8059	1.0117	.823	.8402	.9431	.9945	1.1145
16	1.0562	1.0562	.8488	.7167	1.0751	1.0562	1.3203
17	1.094	1.0751	.9054	.8299	1.1883	1.1883	1.2071
18	1.0185	1.1694	.9431	.811	1.1506	1.1128	1.226
19	1.0562	1.1317	.9431	.9054	1.094	1.1694	1.2637
20	.9619	1.0185	.9054	.8299	.9619	1.0374	1.094
21	.9431	.8676	.8488	.7733	.8865	.9054	.9054
22	.8488	.811	.7733	.7202	.7922	.811	.8059
23	.7356	.7356	.679	.6516	.679	.6979	.703
24	.6602	.6602	.6602	.6413	.5658	.5847	.6224
Max	1.094	1.1694	.9431	.9054	1.1883	1.1883	1.3203
Min	.547	.4904	.5093	.4904	.4287	.4904	.4904
Avg	.8711	.8692	.7715	.7174	.8434	.8667	.9181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 207 / Dunkar Line

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5093	.5093	.4904	.5316	.4904	.5658
2	.5093	.4715	.4715	.4904	.4801	.4715	.5093
3	.5658	.4527	.5093	.5281	.4287	.5281	.4715
4	.6413	.547	.5658	.5658	.5144	.5658	.6036
5	.6979	.679	.6413	.6413	.6001	.679	.7922
6	.7922	.7545	.7356	.679	.6859	.811	1.0374
7	.9054	.8676	.8299	.7545	.823	.8299	.9054
8	1.0751	.9242	.9997	.9242	.8573	.9431	1.0185
9	1.0562	.9808	.9619	.9054	.8402	.9619	.9242
10	.9431	.8059	.8745	.7888	.8573	.8059	.8573
11	.8573	.7888	.8059	.703	.7202	.7373	.7373
12	.7545	.7716	.7373	.7716	.7545	.8573	.7545
13	.703	.6859	.6859	.6687	.7373	.7202	.6859
14	.6687	.6687	.6001	.6173	.6687	.7202	.6516
15	.6516	.6516	.6859	.6516	.6516	.6516	.703
16	.5847	.5847	.5847	.5281	.6413	.6224	.6979
17	.2641	.7545	.679	.6979	.7356	.7922	.8299
18	.8676	.8299	.7733	.7545	.8676	.8488	.9054
19	.9242	.9054	.8488	.9431	.9997	1.0374	1.0751
20	.8865	.8488	.8299	.8676	.9619	.9619	.9619
21	.7733	.7733	.8299	.8299	.9054	.9054	.9242
22	.7922	.811	.7356	.6687	.811	.8676	.7545
23	.7356	.679	.6036	.6687	.6602	.6979	.703
24	.6036	.5281	.5658	.5281	.5658	.4904	.6036
Max	1.0751	.9808	.9997	.9431	.9997	1.0374	1.0751
Min	.2641	.4527	.4715	.4904	.4287	.4715	.4715
Avg	.7401	.7197	.7110	.6944	.7208	.7499	.7780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 208 / 11 KV Weikfield B Block SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2452	.2452	.1715	.2452	.2452
2	.2452	.2452	.2263	.2263		.2263	.2452
3	.2452	.2452	.2075	.2263	.1715	.2263	.2263
4	.2641	.2263	.2075	.2263	.2229	.2263	.2263
5	.2641	.2263	.2263		.2058	.2452	.2452
6	.2829	.2641	.2452	.2452	.2401	.2641	.2641
7	.2829	.2829	.2641	.2452	.2572	.2829	.2829
8	.3018	.3206	.2641	.2641	.3258	.3206	.3018
9	.3961	.415	.2641	.2452	.3429	.3961	.4527
10	.4458	.463	.2743	.2401	.463	.4458	.4458
11	.5316	.4973	.2401	.2229	.5144	.5144	.5316
12	.5487	.5144	.2572	.2401	.5144	.5487	.5144
13	.5658	.4973	.2572	.2572	.5316	.5487	.583
14	.5658	.5144	.2401	.2401	.5487	.5316	.6001
15	.5316	.4801	.2572	.2572	.5316	.5658	.6173
16	.6602	.5658	.3206	.2641	.5847	.6602	.6036
17	.679	.6224	.3018	.2641	.6413	.679	.6413
18	.5658	.4904	.3206	.3206	.4715	.547	.6036
19	.4715	.4527	.2641	.2641	.4715	.4715	.4715
20	.3772	.3395	.2829	.2641	.3772	.3961	.415
21	.3206	.3018	.2641	.2641	.3206	.3206	.3395
22	.2829	.2829	.2829	.2229	.2829	.2829	.2572
23	.2829	.2641	.2452	.2229	.2641	.2641	.2401
24	.2641	.2641	.2452	.2452	.2058	.2641	.2641
Max	.679	.6224	.3206	.3206	.6413	.679	.6413
Min	.2452	.2263	.2075	.2229	.1715	.2263	.2263
Avg	.4017	.3767	.2585	.2484	.3766	.3947	.4007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 302 / Hyatt

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6036	.679	.679	.4458	.6036	.5658
2	.4904	.5658	.6036	.6036	.4801	.5658	.4904
3	.4527	.5658	.5281	.5658	.4458	.5658	.4904
4	.4527	.5281	.5281	.5658	.5144	.5658	.5658
5	.5281	.6036	.5658	.6036	.5144	.6036	.6036
6	.6036	.6413	.6413	.6413	.583	.6036	.6413
7	.6413	.679	.679	.6413	.6173	.6413	.679
8	.679	.679	.7167	.7545	.6173	.6413	.7545
9	.679	.7545	.7922	.7922	.6516	.6413	.7545
10	.6516	.6859	.7545	.7545	.7202	.6173	.6859
11	.6516	.6859	.7545	.823	.7545	.6516	.6859
12	.6859	.7888	.7545	.7888	.7202	.6516	.7202
13	.6859	.7545	.7888	.7888	.7202	.6173	.7202
14	.6516	.7888	.7888	.7888	.7545	.6516	.6859
15	.6859	.7545	.7545	.7888	.6516	.6516	.7202
16	.7167	.7922	.8676	.8299	.8299	.7922	.8299
17	.7167	.7922	.8299	.8299	.8676	.7545	.8676
18	.8299	.8676	.9054	.8299	.8676	.7922	.8676
19	.7922	.8299	.8676	.8299	.8676	.7922	.9054
20	.679	.7922	.8676	.8299	.7545	.7545	.7922
21	.7167	.7167	.7922	.7545	.7545	.7167	.8299
22	.7167	.7922	.7922	.6859	.7167	.679	.6859
23	.679	.7545	.7922	.6173	.679	.6413	.6516
24	.6036	.6413	.7545	.7545	.583	.6036	.5658
Max	.8299	.8676	.9054	.8299	.8676	.7922	.9054
Min	.4527	.5281	.5281	.5658	.4458	.5658	.4904
Avg	.6482	.7107	.7416	.7309	.6713	.6583	.6983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 305 / 22 KV W.N.S

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6036	.6413	.4904	.2743	.5281	.5658
2	.4527	.5281	.5658	.4527	.3086	.4527	.5281
3	.4527	.4527	.4527	.4527	.2743	.4527	.4904
4	.415	.415	.3772	.415	.3086	.415	.415
5	.415	.4527	.3772	.3772	.3429	.415	.415
6	.6036	.5658	.415	.415	.5144	.415	.4527
7	.8299	.679	.415	.415	.7202	.5658	.4527
8	.5658	.5658	.415	.415	.5144	.6036	.6036
9	.5658	.6036	.4527	.415	.5487	.679	.6413
10	.583	.6173	.3772	.3429	.6173	.6516	.6173
11	.6173	.6173	.6859	.3772	.6516	.6516	.6516
12		.6516	.3772	.3429	.6516	.6516	.6859
13	.6859	.6516	.4115	.7888	.6859	.7202	.6516
14	.6516	.6859	.4115	.5487	.7888	.7202	.5487
15	.6859	.7202	.4458	.5487	.7202	.7202	.6516
16	.8676	.9431	.4527	.415	.7922	.8299	.9808
17	.8299	.7922	.8676	.3772	.7922	.8299	.8676
18	.7545	.7167	.5658	.415	.7922	.7922	.7545
19	.7545	.679	.4527	.415	.7545	.7922	.7545
20	.679	.679	.4527	.9054	.679	.7167	.8299
21	.679	.679	.4527	.5281	.7545	.7167	.679
22	.7167	.679	.9054	.3772	.679	.7167	.6516
23	.6413	.679	.5658	.3772	.6413	.6413	.6859
24	.6036	.6036	.7167	.5281	.3772	.6036	.6036
Max	.8676	.9431	.9054	.9054	.7922	.8299	.9808
Min	.415	.415	.3772	.3429	.2743	.415	.415
Avg	.6388	.6359	.5105	.4640	.5910	.6367	.6324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 307 / MYSTIQUE MOODS

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1132	.1509	.1509	.1029	.1132	.1509
2	.1509	.1132	.1132	.1132	.0686	.1132	.1132
3	.1132	.1132	.0754	.1132	.0686	.1132	.1132
4	.1132	.0754	.0754	.1132	.1029	.1132	.1132
5	.1132	.1132	.1132	.1132	.1372	.1509	.1509
6	.1509	.1509	.1509	.1132	.1372	.1509	.1886
7	.1886	.2263	.1886	.1509	.1715	.1886	.1886
8	.2263	.2641	.1886	.1886	.2058	.2263	.2263
9	.3018	.3018	.2641	.1886	.2743	.2641	.3018
10	.3429	.3086	.2743	.2743	.3086	.3429	.3086
11	.3086	.3429	.3086	.2401	.3086	.3429	.3086
12	.3086	.3086	.3086	.3086	.3086	.3086	.3086
13	.3086	.2743	.2743	.2743	.2743	.2743	.3086
14	.3086	.2401	.2743	.2401	.2743	.2743	.3086
15	.2743	.2401	.2401	.2058	.2743	.3086	.3086
16	.3018	.3018	.2641	.2263	.3018	.3018	.3395
17	.3018	.3018	.2263	.2263	.2641	.3018	.3395
18	.3018	.3395	.2641	.2263	.3018	.3018	.3395
19	.3018	.2641	.2641	.2263	.3018	.3018	.3772
20	.3018	.3018	.2641	.2263	.2641	.2641	.3018
21	.3018	.2641	.2263	.1886	.2641	.2263	.2641
22	.2263	.2263	.1886	.1715	.1886	.2263	.2058
23	.1886	.1886	.1509	.1372	.1509	.1886	.1715
24	.1509	.1509	.1886	.1509	.1372	.1509	.1509
Max	.3429	.3429	.3086	.3086	.3086	.3429	.3772
Min	.1132	.0754	.0754	.1132	.0686	.1132	.1132
Avg	.2391	.2302	.2099	.1903	.2163	.2312	.2453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213320 / 22/11 KV WEIKFIELD IT

Feeder No / Name : 308 / 22KV NOVOTEL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3395	.3772	.3772	.2743	.3395	.3772
2	.3018	.3018	.3395	.3395	.2401	.3395	.3395
3	.3018	.3018	.3018	.3018	.2743	.3018	.3018
4	.2641	.2641	.2641	.3395	.3086	.3018	.3018
5	.2641	.2641	.2641	.3772	.2401	.2641	.2641
6	.3018	.3018	.3018	.3772	.2743	.2641	.2263
7	.3395	.3395	.3772	.3395	.2743	.3018	.3395
8	.3772	.3395	.2641	.3395	.3429	.3018	.3772
9	.3395	.3772	.3772	.3772	.2401	.3772	.3772
10	.3429	.3772	.4458	.3772	.3086	.3772	.3772
11	.3086	.3772	.3429	.4115	.3429	.3429	.3772
12	.3772	.3772	.3772	.3772	.3772	.3429	.3429
13	.3429	.3429	.3429	.3772	.3429	.3429	.3772
14	.3772	.4115	.3772	.3429	.3429	.3772	.4115
15	.3772	.3772	.4115	.5487	.4801	.4115	.3772
16	.5281	.415	.5281	.415	.3772	.4904	.415
17	.4904	.4527	.415	.4527	.3772	.3772	.415
18	.3772	.5281	.5281	.415	.3395	.3395	.415
19	.3772	.4904	.415	.415	.3772	.3772	.415
20	.3772	.415	.415	.4527	.3772	.415	.3772
21	.3395	.415	.415	.4904	.415	.3772	.3395
22	.3772	.4527	.415	.4801	.3772	.3772	.3772
23	.4904	.3772	.415	.3429	.3395	.3772	.3429
24	.3772	.3772	.415	.3772	.3772	.3395	.3772
Max	.5281	.5281	.5281	.5487	.4801	.4904	.415
Min	.2641	.2641	.2641	.3018	.2401	.2641	.2263
Avg	.3636	.3757	.3802	.3935	.3342	.3524	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213349 / 22/22 kV Mystic moods SW

Feeder No / Name : 301 / Mystique moods

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.0377	.0377
2	.0377	.0377	.0377	.0377	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.049	.0377	.0377	.0377	.0377	.0377
6	.049	.0641	.0377	.0377	.0377	.0415	.0415
7	.0717	.0679	.0453	.0377	.0528	.049	.0604
8	.0566	.0641	.0528	.0415	.0641	.0604	.0717
9	.0896	.1008	.0747	.056	.083	.0717	.0792
10	.0792	.0672	.0822	.0672	.0747	.0635	.0717
11	.0622	.0554	.0679	.0822	.0635	.056	.0641
12	.0512	.0517	.0566	.0747	.0517	.0485	.0566
13	.0439	.0407	.0528	.0717	.048	.0448	.049
14	.0402	.037	.0453	.056	.0362	.0411	.049
15	.0366	.037	.0377	.0373	.0362	.0373	.0373
16	.0411	.0411	.037	.0411	.0402	.0411	.0411
17	.0373	.0373	.0407	.0373	.0362	.0485	.0485
18	.0373	.0411	.0461	.0448	.0362	.0523	.056
19	.0448	.0453	.0517	.0485	.0402	.0523	.0523
20	.0448	.0415	.0517	.0485	.0448	.0485	.0523
21	.0523	.049	.0485	.0453	.0448	.049	.0485
22	.049	.0453	.0453	.0415	.0377	.049	.0415
23	.0453	.0377	.0415	.0415	.0377	.0453	.0377
24	.0377	.0415	.0377	.0415	.0415	.0377	.0377
Max	.0896	.1008	.0822	.0822	.083	.0717	.0792
Min	.0366	.037	.037	.0373	.0362	.0373	.0373
Avg	.0483	.0486	.0476	.0475	.0457	.0469	.0494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213349 / 22/22 kV Mystic moods SW

Feeder No / Name : 303 / HT 2

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0407	.0444	.048	.0407	.0411	.037	.0444
2	.037	.0407	.0407	.037	.0373	.037	.0377
3	.037	.037	.037	.037	.0373	.037	.037
4	.037	.037	.037	.037	.0373	.037	.037
5	.037	.037	.037	.037	.0373	.037	.037
6	.037	.037	.0407	.037	.0377	.037	.037
7	.0407	.048	.0398	.037	.0411	.0407	.0407
8	.0476	.0471	.0362	.0407	.0411	.0507	.0615
9	.0652	.0688	.056	.0554	.0523	.0688	.0878
10	.1122	.1122	.0822	.0695	.085	.0768	.1134
11	.1317	.1267	.0998	.0792	.1244	.0988	.122
12	.1376	.1267	.1072	.0878	.1231	.1061	.1109
13	.1376	.1231	.1035	.0961	.1267	.1097	.1257
14	.128	.1361	.1035	.0914	.1267	.0914	.1331
15	.1353	.1303	.0971	.0878	.1231	.1061	.128
16	.1244	.1353	.1035	.0776	.1303	.1146	.1244
17	.1427	.1244	.0998	.085	.1158	.1368	.1244
18	.1171	.1441	.0924	.0747	.1412	.1294	.1171
19	.1086	.1257	.0998	.0784	.128	.122	.1207
20	.1122	.1183	.0961	.0784	.1097	.122	.1146
21	.1086	.1035	.0896	.0672	.0977	.1109	.1035
22	.0961		.0591	.0597	.0665	.0702	.0628
23	.0665	.0702	.048	.0485	.0444	.0554	.0554
24	.048	.0517	.0554	.0444	.0485	.0407	.048
Max	.1427	.1441	.1072	.0961	.1412	.1368	.1331
Min	.037	.037	.0362	.037	.0373	.037	.037
Avg	.0869	.0881	.0712	.0619	.0814	.0780	.0843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213355 / VAMONA SWITCHING STATION

Feeder No / Name : 304 / Spare

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18
HR	Load (MW)
21	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213355 / VAMONA SWITCHING STATION

Feeder No / Name : 306 / City II

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1626	2.934	3.0483	2.6673	2.5911	2.7435	2.8197
2	3.0483	2.8578	2.934	2.5911	2.9721	2.6673	2.6673
3		2.7435	2.7435	2.5149	2.9721	2.5911	2.6292
4	2.8578	2.6673	2.5149	2.4006	3.0483	2.5149	2.5911
5	2.7435	2.7054	2.4768	2.3243	3.2769	2.553	2.7435
6	2.7816	2.7435	2.553	2.3624	3.4294	2.8578	3.0483
7	2.9721		2.7054	2.4768	3.8104	3.8104	3.6199
8	3.658	3.5056	3.2769	2.6292	4.5725	4.2676	4.5344
9	4.6868	4.5725	3.4294	2.7435	4.8773	5.1059	5.5251
10	5.4108	5.487	3.7342	2.9721	5.7156	5.5632	5.9442
11	5.9061	6.1347	3.6961	3.0483	5.9061	5.868	6.4396
12	5.9823	6.1728	3.7723	3.1245	6.1728	6.0585	6.2872
13	5.6775		3.8866	3.4294	6.211	6.1347	6.1728
14	5.9061	6.3634	4.1152	3.1245	6.2491		6.211
15	6.0204	6.3634	3.7342	3.3913	6.2491	6.3253	6.3634
16	6.1728	6.0966	3.7342	3.2769	6.3634	6.4015	6.6682
17	6.2491	5.7537	3.7723	3.2388	6.0966	6.1347	6.4777
18	5.3727	5.7537	3.658	3.1626	5.7918	5.9442	5.9442
19	5.3727	5.4489	3.5437	3.1245	5.6394	5.4489	5.868
20	4.9916	4.5725	3.315	3.0483	5.6394	4.5725	4.8011
21	4.2295	4.5725	3.1626	2.8578	4.763	4.1533	3.8104
22	3.8104	3.6961	3.0102	2.7054	3.7723	3.8104	3.7723
23	3.5437	3.315	2.8578	2.7054	3.5056	3.4294	3.5818
24	3.2769	3.0864	3.1626	2.7435	1.3336	2.8959	3.0102
Max	6.2491	6.3634	4.1152	3.4294	6.3634	6.4015	6.6682
Min	2.7435	2.6673	2.4768	2.3243	1.3336	2.5149	2.5911
Avg	4.5145	4.4339	3.2849	2.8610	4.6233	4.4283	4.6471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213384 / 22 /11KV KHULEWADI

SUBSTATION

Feeder No / Name : 204 / 11 KV Indian Oil (IOCL)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754			.0761	.0761	.0761	.0761
2				.0761	.0761	.0761	.0761
3	.0754			.0754	.0761	.0761	.0761
4				.0761	.0761	.0761	.0761
5	.0754			.0761	.0761	.0754	.0761
6				.0761	.0761	.0761	.0761
7	.0754			.0761	.0761	.0761	.0761
8				.0761	.0761	.0761	.0761
9	.0754			.0761		.0754	.0761
10	.0754	.0754	.0754		.0754	.0754	.0754
11	.0754	.0754	.0754		.0754	.0754	
12	.0754	.0754	.0754		.0754	.0754	.0754
13	.0754	.0754	.0754			.0754	
14	.0754	.0754	.0754			.0754	.0754
15		.0754	.0754		.0754	.0754	.0754
16	.0754	.0761	.0754	.0761	.0754	.0754	.0754
17	.0754	.0761	.0754	.0761	.0754		.0754
18	.0754	.0761	.0754	.0761	.0754		.0754
19	.0754	.0761	.0754	.0761	.0754	.0761	.0754
20	.0754	.0761	.0754	.0761	.0754		.0754
21	.0754		.0761	.0761		.0754	
22			.0761	.0761		.0761	.0761
23			.0761	.0761	.0761	.0761	.0761
24	.0754	.0754	.0754	.0761	.0761	.0761	.0761
Max	.0754	.0761	.0761	.0761	.0761	.0761	.0761
Min	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Avg	.0754	.0757	.0755	.0761	.0758	.0758	.0758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213384 / 22 /11KV KHULEWADI

SUBSTATION

Feeder No / Name : 302 / 22KV ROHAN MITHILA

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107		1.8861	1.751	1.8272	1.8272	1.8861
2	1.6598		1.7353	1.6749	1.751	1.751	1.8272
3	1.5089		1.5089	1.5988	1.5988	1.6749	1.751
4	1.7353		1.7353	1.5988	1.5988	1.6749	1.751
5	2.037		1.8107	1.751	1.751	1.751	1.9033
6	2.2634		1.9616	1.9033	1.9794	1.9794	2.2078
7	2.5652		2.1125	1.9033	2.4362	2.2078	2.5123
8	2.7915		2.5652	2.2078	2.8169	2.893	2.6646
9	3.0178		2.7915			3.1687	3.2737
10	3.0178	3.0933	2.8669		2.8669	3.2442	3.0933
11	2.5652	1.9616	2.7161		2.8669	2.6063	2.6406
12	2.4143	1.6598	2.5652		2.5652		2.2634
13	2.2634	2.4143	2.4897			2.2634	2.1879
14	1.2071	2.1879	2.2634			2.1125	2.1879
15		2.1125	2.1125		2.037	2.037	2.1125
16	2.2634	2.2078	2.1879	1.9794	2.037	2.1125	2.1879
17	2.1879	2.1317	2.1125	2.0556	2.2634	2.1879	2.1125
18	2.3388	2.284	2.2634	2.1317	2.4143	2.3388	2.2634
19	2.7161	2.6646	2.6646	2.6646	2.7915	2.6406	2.7161
20	2.7915	2.6646	2.7161	2.6646	2.8669	2.7915	2.7915
21	2.7915		2.6646	2.5885	2.6646	2.7161	
22			2.5123	2.4362	2.5123	2.5885	2.6646
23			2.284	2.2078	2.2078	2.1879	2.284
24	1.9616	1.8861	1.8861	1.9033	1.9033	1.9033	.1523
Max	3.0178	3.0933	2.8669	2.6646	2.8669	3.2442	3.2737
Min	1.2071	1.6598	1.5089	1.5988	1.5988	1.6749	.1523
Avg	2.2813	2.2724	2.2672	2.0600	2.2741	2.2895	2.2363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213384 / 22 /11KV KHULEWADI

SUBSTATION

Feeder No / Name : 303 / 22 KV GANGA GERA

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7353		1.8861	2.284	1.8272	1.9033	1.9033
2	1.5844		1.7353	2.2078	1.6749	1.8272	1.8272
3	1.4335		1.5844	2.1317	1.5988	1.751	1.751
4	1.8861		1.8107	2.1317	1.5988	1.751	1.8272
5	2.4897		2.1125	2.0556	1.9033	1.9794	2.1317
6	2.9424		2.5652	2.2078	2.5123	2.5885	2.5123
7	3.2442		2.7915	2.3601	2.9691	2.893	2.9691
8	3.6969		3.0178	2.893	3.6543	3.8066	3.2737
9	3.546		3.3196			3.9232	3.7305
10	3.3196	3.1687	3.0933		3.1687	3.6214	3.1687
11	3.1687	2.7915	3.1687		3.0178	3.0933	2.9424
12	2.7161	2.7915	3.0933		2.7161	2.9424	2.4897
13	2.4362	2.4897	2.7161			2.5652	2.4897
14	2.1879	2.2634	2.5652			2.2634	2.2634
15		2.1125	2.2634		2.1125	2.2634	2.2634
16	2.037	2.284	2.3388	2.3601	2.1879	2.1879	2.3388
17	2.1125	2.1317	2.4143	2.2078	2.1879	2.2634	2.4143
18	2.1125	2.284	2.4897	2.4362	2.2634	2.4143	2.4143
19	2.8669	3.0453	2.6646	3.0453	3.0933	3.0933	3.0933
20	3.0178	2.9691	3.0178	3.0453	3.0178	3.0178	3.2442
21	2.8669		2.893	2.8169	3.0453	2.9424	
22			2.6646	2.5885	2.6646	2.7407	2.893
23			2.3601	2.284	2.284	2.3601	2.5123
24	1.9616	2.037		2.3601	1.9033	2.0556	2.0556
Max	3.6969	3.1687	3.3196	3.0453	3.6543	3.9232	3.7305
Min	1.4335	2.037	1.5844	2.0556	1.5988	1.751	1.751
Avg	2.5411	2.5307	2.5463	2.4362	2.4477	2.5937	2.5439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213384 / 22 /11KV KHULEWADI

SUBSTATION

Feeder No / Name : 305 / 22 KV DHANORI

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1687			.1523	.1523	3.4259	3.5782
2	3.0178			.1523	.1523	3.3498	3.5021
3	2.7915			.1523	.1523	3.2737	3.4259
4	3.7723			.1523	.1523	3.2737	3.4259
5	4.7531			.1523	.1523	3.4259	3.7305
6	5.583			.1523	.1523	4.5679	4.9486
7	6.0357			.1523	.1523	5.2531	6.0905
8	6.6392			.1523	.4568	6.8519	6.4712
9	5.8848			.1523		6.8656	6.5473
10	5.583	.1509	.1509		1.2826	6.6392	5.2812
11	4.7531	.1509	.1509		6.3375	5.5076	4.7531
12	4.3759	.1509	.1509		4.8285	4.904	4.4513
13	3.7723	.1509	.1509			4.225	3.9232
14	3.3196		.1509			3.8477	3.6214
15			.1509		3.4705	3.6214	3.546
16	3.2442		.1509	.1523	3.2442	3.4705	3.4705
17	3.2442	.1523	.1509	.1523	3.546	3.6969	3.6214
18	3.6214	.1523	.1509	.1523	3.6969	3.9986	
19	4.9794	.1523	.1523	.1523	5.3567	5.7339	5.6584
20	5.3567	.1523	.1509	.1523	5.6584	5.7339	6.0357
21	5.2058				5.786	5.6584	
22			.1523	.1523	5.0247	5.1008	5.5576
23			.1523	.1523	4.035	4.1111	
24	3.3196	.1509	.1509	.1523	.1523	3.5021	3.6543
Max	6.6392	.1523	.1523	.1523	6.3375	6.8656	6.5473
Min	2.7915	.1509	.1509	.1523	.1523	3.2737	3.4259
Avg	4.4010	.1515	.1512	.1523	2.5687	4.5849	4.5378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213384 / 22 /11KV KHULEWADI

SUBSTATION

Feeder No / Name : 306 / shastri nagar

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2442			3.4259	3.4259	3.4259	3.4259
2	3.0178			3.3498	3.3498	3.3498	3.3498
3	2.7915			3.3498	3.2737	3.2737	3.2737
4	3.6214			3.2737	3.1975	3.2737	3.1975
5	4.4513			3.3498	3.4259	3.4259	3.3498
6	4.7531			3.7305	4.5679	4.4156	3.3498
7	4.9794			4.2634	5.177	4.644	2.8169
8	5.2812			4.7202		5.4815	5.3292
9	5.583			5.177		5.583	5.5576
10	6.1111	5.9602	5.1303		6.0357	6.5638	5.9602
11	5.8093	5.8093	4.4513		5.8093	6.1866	5.7339
12	5.3567	5.4321	3.9986		5.3567	5.7339	5.583
13	4.9794	5.2058	3.4705			4.9794	5.8848
14	4.7531		3.2442			4.8285	5.1303
15			2.9424		3.9986	4.6022	9.5062
16	4.6022		3.546	3.5782	4.6022	4.4513	4.904
17	4.6022	4.5679	3.7723	3.5782	4.6022	4.6776	5.0549
18	4.6022	4.644	3.9986	3.8066	4.904	4.7531	5.2058
19	5.2812	5.4054	8.4499	4.7202	5.583	5.5076	5.8093
20	5.1303	5.177	4.6022	4.644	5.2058	5.1303	5.5076
21	4.7531		4.5679	4.4156	5.0247	4.7531	
22			4.3395	4.1111	4.5679	4.4918	4.8724
23			3.8827	3.7305	4.1111	3.9589	4.3395
24	3.4705	3.3951	3.4705	3.5021	3.5021	3.5021	3.5021
Max	6.1111	5.9602	8.4499	5.177	6.0357	6.5638	9.5062
Min	2.7915	3.3951	2.9424	3.2737	3.1975	3.2737	2.8169
Avg	4.6273	5.0663	4.2578	3.9293	4.4861	4.6247	4.8106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213391 / 22/11KV ROHAN MITHILA

SUBSTATI

Feeder No / Name : 201 / 11KV Rohan Mithila 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.112	.112	.112	.112	.112	.1494
2	.112	.112	.112	.112	.112	.1132	.112
3	.112	.112	.112	.112	.112	.112	.112
4	.112	.112	.112	.112	.112	.1494	.112
5	.112	.112	.112	.112	.112	.1494	.1867
6	.1494	.1494	.112	.112	.1494	.1494	.2241
7	.1867	.2241	.1494	.112	.2241	.1867	.2614
8	.2614	.2614	.1867	.1494	.2241	.2241	.2241
9	.2614	.2614	.1867	.2241	.2614	.2614	.2987
10	.2987	.2614	.2241	.3361	.2987	.3361	.2614
11	.2241	.2241	.2614	.2614	.2614	.2614	.2614
12	.2241	.1867	.2614	.2614	.2218	.1867	.1867
13	.1867	.2241	.2241	.2241	.1867	.1494	.1867
14	.1494	.1867	.1867	.1867	.1494	.1494	.1494
15	.1494	.1494	.1867	.1867	.1494	.1494	.1494
16	.112	.1494	.1867	.1867	.1494	.112	.1494
17	.1494	.112	.1867	.1494	.112	.1494	.1494
18	.1494	.1494	.1867	.1867	.1494	.1494	.1867
19	.1494	.1867	.1867	.1867	.1867	.1867	.1886
20	.1867	.1494	.1867	.1867	.1886	.2263	.2263
21	.1867	.1867	.1867	.1867	.1886	.2241	.2263
22	.1867	.1867	.1494	.1867	.1867	.1867	.1867
23	.1494	.1494	.1494	.1867	.1867	.1867	.1867
24	.112	.1494	.1494	.1494	.112	.1494	.1494
Max	.2987	.2614	.2614	.3361	.2987	.3361	.2987
Min	.112	.112	.112	.112	.112	.112	.112
Avg	.1680	.1712	.1712	.1758	.1728	.1775	.1885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213391 / 22/11KV ROHAN MITHILA

SUBSTATI

Feeder No / Name : 202 / 11KV Rohan Mithila 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2957	.3326	.2957	.2957	.2987	.2957
2	.2957	.2987	.2957	.2957	.2587	.2987	.2957
3	.2957	.2957	.2957	.2957	.2587	.2614	.2957
4	.2587	.2587	.2957	.2957	.2957	.2614	.3326
5	.2587	.2957	.2957	.2957	.2957	.2957	.3326
6	.2957	.3326	.2957	.2957	.3696	.3361	.3326
7	.3326	.2957	.3326	.2957	.3696	.3361	.3326
8	.4805	.4066	.3326	.3326	.4066	.4066	.4435
9	.4805		.3696	.3734	.4435	.4435	.4435
10	.4435	.4066	.4066	.3326	.4435	2.3282	.4805
11	.4066	.4066	.4435	.2957	.4066	.3696	.3696
12	.3696	.3326	.4066	.2987	.3326	.3696	.3326
13	.3326	.2587	.4066	.2957	.3696	.2957	.3326
14	.2587	.2587	.3696	.2587	.2587	.2587	.2587
15	.3326	.3326	.3696	.2587	.2957	.2957	.2587
16	.2957	.3696	.3696	.2587	.2957	.3326	.2957
17	.2957	.3696	.3326	.2957	.3326	.3326	.3326
18	.3696	.3696	.4066	.3696	.3696	.3696	.3734
19	.4066	.4435	.4435	.4066	.4854	.4435	.4481
20	.4805	.4805	.4805	.4435	.4854	.4854	.4854
21	.4805	.4435	.3696	.4066	.4904	.5228	.4481
22	.4435	.4435	.3696	.3696	.4481	.4435	.4481
23	.3734	.4066	.3326	.3696	.3734	.3696	.3696
24	.2957	.3326	.3696	.2957	.3361	.3361	.3326
Max	.4805	.4805	.4805	.4435	.4904	2.3282	.4854
Min	.2587	.2587	.2957	.2587	.2587	.2587	.2587
Avg	.3574	.3537	.3634	.3222	.3632	.4371	.3613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

NAGAR ROAD SUB-DN.[604] BU 4604

Substation No/ Name :- 213391 / 22/11KV ROHAN MITHILA

SUBSTATI

Feeder No / Name : 203 / 11KV Sanjay Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4327	1.3253	1.3253	1.3969		1.2536	1.3611
2	1.2536	1.2894	1.2178	1.2894	1.2178	1.2178	1.2536
3	1.182	1.2178	1.182		1.1462	1.182	1.2178
4	1.2894	1.182	1.1462	1.1462	1.182	1.2536	1.2536
5	1.3253	1.2536	1.2178	1.2178	1.2536	1.2894	1.2894
6	1.6834	1.5043	1.4685	1.3253	1.5043	1.2894	1.5043
7	1.9342	1.9342	1.6118	1.6118	1.8983	1.7372	1.8983
8	1.9342	2.2565	1.9342	1.7909	2.0774	2.1132	2.1132
9	2.2207	2.3282	2.0416	2.0271	2.3282	2.3998	2.5431
10	2.2207	2.2923	2.0416	2.0774	2.1491		2.364
11	1.9342	1.182	2.0058	2.0774	2.0774	2.1491	2.0416
12	1.8267	1.1104	1.8267	1.97	1.8625	1.97	1.8625
13	1.6834	1.97	1.8267	1.8983	1.6834	1.9342	1.7551
14	.8596	1.6834	1.6476	1.8983	1.8625	1.7909	1.6476
15	.8596	1.6834	1.5043	1.7551	1.6834	1.6118	1.7551
16	1.8625	1.7193	1.576	1.4327	1.5402	1.5402	1.6476
17	1.8267	1.6834	1.6476	1.576	1.6476	1.6118	1.576
18	1.8267	1.7551	1.7909	1.5402	1.7193	1.6476	1.6476
19	1.97	2.0416	2.0774	1.9342	1.9342	2.0058	1.9342
20	2.0774	2.0416	2.0416	1.9342	2.0416	1.97	1.97
21	1.97	1.9342	1.97	1.97	2.0774	1.97	2.0058
22	1.8267	1.8625	1.8625	1.8267	1.8625	1.8625	1.8625
23	1.6834	1.6834		1.6834	1.576	1.6118	1.7193
24	1.5402	1.4327	1.4327	1.4685	1.4685	1.4327	1.3969
Max	2.2207	2.3282	2.0774	2.0774	2.3282	2.3998	2.5431
Min	.8596	1.1104	1.1462	1.1462	1.1462	1.182	1.2178
Avg	1.6760	1.6819	1.6694	1.6890	1.7301	1.6889	1.7342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213033 / 22/11 KV MOHANWADI

Feeder No / Name : 201 / 11 KV Vidya Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.9526	.9526	.9526	.9526	.9907
2	.8002	.8002	.8764	.8764	.8764	.8954	.8764
3	.7621	.7621	.8383	.8383	.8383	.8192	.9145
4	.9145	1.3336	.9145	.8764	.9145	.8764	1.0288
5	1.0288	.9907	1.0288	.9335	1.0288	.9907	1.1812
6	1.5051	1.3203	1.3146	.9522	1.3717	1.1203	1.5242
7	2.0386	1.9418	1.4861	1.3336	1.7718	1.6194	1.9052
8	2.2291	2.1338	1.9814	1.7718	2.1148	2.191	2.3624
9	2.0957	1.9624	1.9052	1.9814	2.1719	2.1338	2.0386
10	1.7718	1.7147	1.848	1.9433	1.7909	1.9624	1.8099
11	1.6575	1.6385	1.8671	1.829	1.6575	1.848	1.6956
12	1.5242	1.5051	1.5432	1.7718	1.5623	1.7528	1.5432
13	1.3336	1.3717	1.4861	1.6766	1.4289	1.6575	1.4289
14	1.2193	1.3146	1.3717	1.3336	1.1812	1.2384	1.2574
15	1.2384	1.2193	1.2384	1.2193	1.1812	1.1241	1.2193
16	1.1812	1.2384	1.2193	1.1431	1.1812	1.1241	1.2574
17	1.3717	1.2574	1.2193	1.2574	1.2193	1.1812	1.2574
18	1.3717	1.4289	1.3717	1.448	1.7147	1.4098	1.2955
19	1.5089	1.829	1.4289	1.7337	1.8099	1.7909	1.7528
20	1.6057	1.7718	1.4289	1.7337	1.7909	1.7909	1.829
21	1.6004	1.6956	1.6956	1.6385	1.6766	1.6956	1.7147
22	1.448	1.4098	1.467	1.467	1.5242	1.5623	1.6004
23	1.2765	1.1812		1.1812	1.3717	1.3336	1.2955
24	.9907	.9717	1.0098	.9907	1.0098	1.0479	1.086
Max	2.2291	2.1338	1.9814	1.9814	2.1719	2.191	2.3624
Min	.7621	.7621	.8383	.8383	.8383	.8192	.8764
Avg	1.3888	1.4021	1.3693	1.3701	1.4225	1.4216	1.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213033 / 22/11 KV MOHANWADI

Feeder No / Name : 202 / 11 KV Ambanagari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.724	.724	.7621	.724	.8002
2	.6478	.6097	.6478	.724	.724	.6859	.724
3	.6097	.6097	.6478	.6478	.6478	.6478	.724
4	.724	.743	.724	.6478	.6478	.6478	.8002
5	.9907	.8573	.8573	.8002	.8002	.8192	.9526
6	1.3717		1.0288	.9145	.9907	1.0288	1.3146
7	1.6194	1.531	1.2193	1.1241	1.5432	1.3908	1.6004
8	1.7528	1.7909	1.6004	1.448	1.7337	1.7528	1.7337
9	1.6766	1.6004	1.5813	1.6956	1.6766	1.848	1.6766
10	1.3336	1.3336	1.5432	1.7528	1.5242	1.6575	1.4098
11	1.1241	1.2384	1.2955	1.6575	1.1431	1.3146	1.2574
12	.7621	1.0288	1.1812	1.2574	1.0098	1.1431	.9717
13	.9335	.9145	1.105	1.1431	.8383	1.0098	.9145
14	.8192	.7621	.9145	.9717	.8002	.7811	.8002
15	.7049	.724	.8954	.9145	.743	.8002	.724
16	.6859		.8764	.8573	.7621	.7621	.7621
17	.7049	1.2003	.9335	.9526	.8192	.8573	.8383
18	.724	1.0479	1.086	.9907	.9335	.9907	.9145
19	1.1812	1.3717	1.1763	1.3146	1.3146	1.3527	1.2384
20	1.2955	1.3717	1.2574	1.3146	1.3336	1.3717	1.3527
21	1.1431	1.3146	1.2955	1.3146	1.3717	1.3146	1.3527
22		1.2003	1.1812	1.2384	1.3336	1.2384	1.3527
23	.9907	1.0479	1.0479	1.0288	1.1812	.9526	.9907
24	.7811	.7621	.7811	.8002	.8573	.743	.8383
Max	1.7528	1.7909	1.6004	1.7528	1.7337	1.848	1.7337
Min	.6097	.6097	.6478	.6478	.6478	.6478	.724
Avg	1.0114	1.0794	1.0667	1.0931	1.0621	1.0764	1.0852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213033 / 22/11 KV MOHANWADI

Feeder No / Name : 203 / 11 KV Pratik Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4572	.4954	.4763	.4763	.4763	.5335
2	.4572	.4191	.4572	.4572	.4572	.4572	.4572
3	.4191	.4191	.4572	.4572	.4572	.4191	.4572
4	.4572	.5144	.5335	.5144	.5335	.4572	.5335
5	.6097	.5716	.6097	.5525	.6478	.5525	.6478
6	.8002	.7621	.743	.5716	.7621	.6287	.8192
7	1.0098	.8954	.7621	.6097	.9145	.8573	.9717
8	1.1622	1.0669	.9717	.8764	1.0479	1.1812	1.1812
9	1.0479	1.086	1.0098	1.0479	1.086	1.1622	1.086
10	.8573	.8954	.9907	1.0479	.9526	1.0479	.9526
11	.743	.8002	.8764	1.0098	.8192	.8764	.8764
12	.6097	.743	.7811	.9526	.743	.8002	.724
13	.6097	.6668	.724	.8573	.7049	.7049	.6668
14	.6478	.6478	.6668	.7049	.7049	.6097	.6097
15	.6287	.5716	.6478	.6668	.5716	.6097	.6097
16	.6097	.6097	.6478	.6287	.5716	.5906	.6097
17	.6097	.6478	.7049	.7049	.6287	.6097	.6478
18	.6287	.6668	.743	.6859	.8002	.7621	.6478
19	.7468	.9145	.7621	.9335	.9145	.9145	.8573
20	.8402	.9335	.8002	.8764	.9145	.9145	.9717
21	.8002	.8383	.8383	.8002	.8573	.8764	.9526
22	.7621	.8383	.7811	.7811	.8002	.8192	.8764
23	.6859	.6668	.6859	.6668	.7621	.7621	.6535
24	.5335	.5144	.5525	.5525	.5525	.5716	.5716
Max	1.1622	1.086	1.0098	1.0479	1.086	1.1812	1.1812
Min	.4191	.4191	.4572	.4572	.4572	.4191	.4572
Avg	.6980	.7144	.7184	.7264	.7367	.7359	.7465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213033 / 22/11 KV MOHANWADI

Feeder No / Name : 204 / DIGHI SPARE FDR

Feeder KV- 11 / OUTGOING

DATE	13-FEB-18
HR	Load (MW)
3	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213033 / 22/11 KV MOHANWADI

Feeder No / Name : 205 / 11 KV Shanti Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.5716	.5335	.5716
2		.5716	.4572	.4572	.5335
3		.5525	.4572	.4572	.4954
4		.5525	.5716	.4954	.5716
5		.6097	.6478	.5525	.6478
6		.6668	.8002	.6348	.9335
7		.7468	1.0479	.8954	.9907
8		1.0288	1.2384	1.2765	1.2384
9		1.2193		1.2193	1.1622
10		1.1812	.9907	1.1431	1.1241
11		1.0479	.9335	1.0669	1.0098
12		.8764	.8002	.9717	.8002
13		.8383	.724	.8383	.7621
14		.7621	.7621	.724	.724
15		.7049	.7811	.7621	.7049
16		.6668	.8002	.743	.724
17	.6287	.7049	.6668	.7621	
18	.7049	.7621	.9335	.9145	.7811
19	.7621	1.0288	.9335	1.086	.9907
20	.8002	.9526	.8764	1.0669	1.0288
21	.8573	.8764	.8192	.9335	.9907
22	.8764	.8192	.7621	.8573	.9335
23	.7621	.6668	.6478	.7621	.7811
24		.6287	.5906	.5716	.6097
Max	.8764	1.2193	1.2384	1.2765	1.2384
Min	.6287	.5525	.4572	.4572	.4954
Avg	.7702	.7932	.7745	.8219	.8308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213033 / 22/11 KV MOHANWADI

Feeder No / Name : 206 / 11 KV Vishrantwadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2477	.2477	.2286	.2286	.2667
2	.2286	.2286	.2286	.2286	.1905	.1905	.2286
3	.2096	.2096	.2286	.2286	.1905	.2286	.2286
4	.2286	.2096	.2667	.2286	.2286	.2286	.2667
5	.2667	.2667	.3048	.2477	.2667	.2667	.3048
6	.362	.362	.3429	.2667	.381	.3048	.362
7	.4001	.381	.3048	.3048	.4382	.2858	.3429
8	.4954	.5335	.4572	.4191	.4382	.5335	.4954
9	.5525	.5144	.4763	.4954	.4954	.5525	.5144
10	.5144	.5525	.4763	.5525	.4191	.5335	.5144
11	.4572	.4763	.4763	.4954	.4001	.4954	.4572
12	.362	.4382	.4382	.4572	.362	.4572	.381
13	.3429	.4001	.4382	.4191	.3239	.4001	.381
14	.3239	.3429	.362	.381	.3048	.3239	.3429
15	.2858	.3048	.381	.381	.3048	.3048	.3429
16	.2858	.3048	.3429	.362	.3429	.3239	.381
17	.3239	.3239	.4191	.362	.362	.3239	.381
18	.3239	.362	.4108	.381	.362	.381	.381
19	.4001	.4572	.4191	.4763	.4763	.4763	.4572
20	.4572	.4572	.4108	.4382	.4572	.4572	.4572
21	.4191	.4001	.4001	.4191	.4382	.4191	.4191
22	.381	.381	.381	.4001	.4191	.4001	.4001
23	.3048	.3429	.3048	.3429	.2667	.381	.362
24	.2667	.2858	.2667	.2667	.2667	.2667	.2858
Max	.5525	.5525	.4763	.5525	.4954	.5525	.5144
Min	.2096	.2096	.2286	.2286	.1905	.1905	.2286
Avg	.3509	.3652	.3660	.3667	.3485	.3652	.3731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213033 / 22/11 KV MOHANWADI

Feeder No / Name : 207 / 11 KV Tingrenagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1241	1.2193	1.3527	1.6004	1.6385	1.4289
2	1.105	1.0669	1.1812	1.2193	1.5242	1.448	1.2384
3	1.0288	1.0288	1.1431	1.2574	1.4861	1.448	1.2384
4	1.1812	1.0669	1.2193	1.1812	1.5623	1.5242	1.3717
5	1.5813	1.2193	1.3336	1.5623	1.7528	1.7147	1.6766
6	2.2481	1.8861	1.6956	1.9052	2.2862	.1905	2.191
7	2.7816	2.4579	2.0957	2.1658	3.0674	2.2291	2.6101
8	3.1055	2.9721	2.8387	2.8197	3.3722	3.7342	3.1817
9	3.0293	2.934	2.8387	3.3532	3.4294	3.677	2.9531
10	2.4768	2.5149	2.7816	3.2007	3.0483	3.1626	2.7054
11	2.2672	2.0576	2.6863	2.8959	2.4577	2.7054	2.3053
12	1.7528	1.8861	2.2672	2.8006	2.3243	2.572	1.8861
13	1.5432	1.7337	1.829	2.3053	2.0957	2.3624	1.6766
14	1.467	1.6004	2.0195	2.0957	1.9433	1.9433	1.5623
15	1.467	1.4289	2.0767	1.9433	1.7551	1.8099	1.5242
16	1.4289	1.448	1.9052	1.8861	1.8671	1.848	1.5242
17	1.5242	1.5051	1.9624	2.0195	1.9624	1.8671	1.5432
18	1.5813	1.7718	2.2481	2.2291	2.3243	2.0386	1.7337
19	2.191	2.2672	2.553	2.6863	2.6482	2.3243	2.2481
20	2.2257	2.2481	2.6482	2.7054	2.6673	2.3624	2.4577
21	2.0957	2.2481	2.6673	2.6863	2.6863	2.3053	2.3815
22	2.0005	2.0767	2.4958	2.5149	2.6292	2.21	2.3053
23	1.7337	1.6004	2.2779	1.9433	2.2291	1.7528	1.8099
24	1.3527	1.3336	1.3527	1.7718	1.7528	1.8671	1.5051
Max	3.1055	2.9721	2.8387	3.3532	3.4294	3.7342	3.1817
Min	1.0288	1.0288	1.1431	1.1812	1.4861	.1905	1.2384
Avg	1.8463	1.8115	2.0557	2.1875	2.2697	2.1140	1.9608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213033 / 22/11 KV MOHANWADI

Feeder No / Name : 208 / 11 KV Pumping

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2096	.362		.3048
2	.2667	.2286	.3429		.2667
3	.2286	.1867	.2858		.2667
4	.2667	.1848	.3048		.3048
5	.2858	.3547	.3429		.3048
6	.3239	.3921	.4382		.3239
7	.4572	.3511	.4382		.362
8	.4763	.381	.4382		.2858
9	.4001	.4572	.4001		.3048
10	.3239	.4572	.381		.3048
11	.2667	.381	.4001		.3048
12	.2096	.3048	.362		.3239
13	.2096	.3239			.3048
14	.1905	.362			.2858
15	.1905	.4382			.381
16	.0191	.381			.362
17	.0191	.362		.2286	.3048
18	.021	.4191		.2667	.3048
19	.021	.381		.3048	.381
20	.021	.4001		.362	.381
21	.2096	.4382		.2858	.381
22	.2054	.4001		.3239	.381
23	.2096	.4001		.3239	.3048
24	.362	.1848	.381		.3429
Max	.4763	.4572	.4382	.362	.381
Min	.0191	.1848	.2858	.2286	.2667
Avg	.2279	.3491	.3752	.2994	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213321 / 22/11 KV HARIGANGA

Feeder No / Name : 201 / 11 KV Mahalaxmi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.056	.056	.056	.0754	.0754	.0754
2	.0747	.056	.056	.056	.0754	.0754	.0754
3	.056	.056	.056	.056	.0754	.0754	.0754
4	.0747	.056	.056	.056	.0754	.0754	.0943
5		.0747	.056	.056	.0754	.0943	.0943
6	.1494	.112	.0747	.056	.0754	.0943	.1132
7	.1307	.112	.112	.0747	.1509	.132	.1509
8	.168	.1494	.1307	.1307	.1509	.1886	.1886
9	.2054	.1494	.168	.1307	.2075	.1867	.1886
10	.2075	.168	.2263	.1886	.1698	.1867	.168
11	.1509	.112	.1698	.2075	.1698	.168	.168
12	.132	.1307	.132	.1886	.132	.168	.1294
13	.1509	.112	.1698	.1886	.132	.1478	.1294
14	.1132	.112	.132	.1509	.132	.112	.1109
15	.1132	.0934	.1132	.1132	.0943	.1307	.1109
16	.1132	.0943	.1294	.0943	.1132	.0934	.112
17	.0943	.132	.1109	.1132	.1132	.0934	.112
18		.132	.1478	.132	.1132	.1307	.112
19	.1698	.1509	.1886	.1886	.1698	.2054	.1867
20	.1698	.1886	.1886	.1886	.1698	.1867	.1867
21	.1698	.1886	.1886	.1886	.1698	.1867	.1867
22	.112	.112	.1307	.132	.132	.132	.132
23	.0934	.112	.0934	.0943	.0943	.1132	.1132
24	.0934	.056		.0747	.0943	.0754	.0754
Max	.2075	.1886	.2263	.2075	.2075	.2054	.1886
Min	.056	.056	.056	.056	.0754	.0754	.0754
Avg	.1280	.1132	.1255	.1215	.1234	.1303	.1287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213321 / 22/11 KV HARIGANGA

Feeder No / Name : 202 / 11 KV Hariganga I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1907	.1907	.1928	.1928	.181	.1991	.197
2	.1907	.1907	.1753	.1753	.1698	.197	.197
3	.1753	.156	.1578	.1578	.1698	.1949	.1791
4	.1753	.1578	.1595	.1578	.1791	.2172	.2126
5	.2103	.2126	.1772	.1772	.2353	.2353	.2865
6	.3189	.2865	.2328	.2103	.2686	.2715	.3801
7	.3982	.3801	.2715	.2715	.362	.3801	.4119
8	.4755	.4854	.3841	.3658	.4607	.5068	.4835
9	.499	.4481	.462	.4805	.4904	.543	.4887
10	.4656	.4481	.4525	.5093	.415	.4706	.4525
11	.3721	.3547	.5194	.5281	.3772	.394	.3761
12	.3189	.3224	.4477	.4527	.3772	.394	.3012
13	.2507	.2614	.3258	.3584	.3018	.3189	.2279
14	.1949	.1867	.2686	.3018	.2452	.2303	.2279
15	.1886	.197	.2149	.2452	.1886	.2126	.1928
16	.1886	.1886	.2279	.2452	.2263	.1951	.1753
17	.2075	.2263	.2279	.2641	.2452	.2481	.2103
18		.2641	.2835	.2829	.2829	.2507	.1772
19	.3206	.3395	.3258	.3584	.3258	.3258	.2715
20	.3395	.3206	.3258	.3395	.3772	.3258	.3258
21	.3395	.3206	.3258	.3206	.3366	.3258	.3439
22	.3045	.298	.2987	.2896	.3045	.3258	.3077
23	.2658	.2629	.2801	.2715	.2686	.2715	.2715
24	.2254	.208	.2254	.2103	.2172	.2172	.2172
Max	.499	.4854	.5194	.5281	.4904	.543	.4887
Min	.1753	.156	.1578	.1578	.1698	.1949	.1753
Avg	.2877	.2795	.2901	.2986	.2919	.3021	.2881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213321 / 22/11 KV HARIGANGA

Feeder No / Name : 203 / 11 KV Hariganga II (RTO)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1867	.1867	.2075	.1886	.1698
2	.168	.168	.168	.168	.2075	.1886	.1698
3	.168	.168	.168	.168	.1886	.2075	.1698
4	.168	.1867	.1867	.168	.1886	.2263	.1886
5	.1867	.2054	.2054	.1867	.2263	.2263	.2829
6	.2614	.3174	.2801	.2427	.2641	.2452	.3395
7	.3734	.3174	.2614	.2427	.3584	.3395	.3772
8	.3921	.3174	.2987	.2801	.3584	.3584	.415
9	.3734	.3361	.3734	.3734	.4338	.4527	.3772
10	.3584	.3547	.3395	.3961	.415	.3772	.3584
11	.3018	.3174	.3018	.3584	.3395	.3206	.3018
12		.2614	.2452	.2829	.3395	.3018	.2452
13	.1886	.2241	.2263	.2641	.2263	.2452	.2452
14	.2263	.2614	.2075	.2075	.2263	.2614	.2641
15	.2641	.3174	.2263	.2263	.2829	.2987	.2829
16	.2641	.2829	.2075	.2829	.2641	.2801	.2614
17	.2452	.2263	.2641	.2263	.2829	.2801	.2427
18		.2641	.3018	.2263	.2641	.2801	.2614
19	.3772	.3961	.3772	.3395	.3206	.3584	.3961
20	.3584	.3772	.3584	.3018	.3206	.3734	.3206
21	.3395		.3395	.3206	.3206	.3734	.3547
22	.2801	.2987	.2801	.2829	.2829	.2829	.3206
23	.2427	.2427	.2427	.3018	.2263	.2452	.2641
24	.2054	.2054	.2056	.2054	.2452	.2075	.2075
Max	.3921	.3961	.3772	.3961	.4338	.4527	.415
Min	.168	.168	.168	.168	.1886	.1886	.1698
Avg	.2695	.2710	.2605	.2600	.2829	.2883	.2840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213321 / 22/11 KV HARIGANGA

Feeder No / Name : 204 / 11 KV Dew Drop

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0938	.0934	.0934	.1132	.0943	.1132
2	.0934	.112	.0934	.0938	.0943	.0943	.1132
3	.0934	.0934	.0934	.0934	.0943	.0943	.0943
4	.0934	.0934	.0934	.0934	.0943	.1132	.0943
5	.0934	.112	.0934	.0934	.0943	.1132	.132
6	.112	.1307	.112	.0934	.1132	.132	.1509
7	.1307	.1494	.112	.112	.1509	.1509	.1698
8	.1494	.168	.1307	.1307	.1698	.1698	.1698
9	.1867	.2054	.168	.1307	.1886	.168	.1886
10	.2641	.2801	.2263	.1886	.2641	.2452	.2452
11	.2829	.2987	.2829	.2229	.3206	.3018	.3018
12	.3772	.2801	.2829	.3018	.3018	.2614	.415
13	.3395	.3921	.2829	.2263	.3206	.3018	.3206
14	.3395	.2987	.3018	.2075	.3395	.2987	.3018
15	.3395	.3361	.2452	.2075	.2829	.2614	.3206
16	.3018	.3018	.2427	.2075	.3395	.3547	.2801
17	.2829	.2829	.2987	.2263	.2829	.2801	.2987
18		.3584	.3174	.2829	.3206	.2614	.3174
19	.3584	.2829	.3206	.3584		.2614	.3921
20	.3206	.3018	.3018	.3018	.3772	.2801	.2801
21	.3018	.2452	.2829	.2829	.2641	.2801	.2427
22	.168	.168	.168	.1509	.1698	.2075	.1886
23	.168	.1494	.1494	.132	.132	.1509	.1509
24	.1307	.1307	.112	.112	.1132	.1132	.132
Max	.3772	.3921	.3206	.3584	.3772	.3547	.415
Min	.0934	.0934	.0934	.0934	.0943	.0943	.0943
Avg	.2191	.2194	.2002	.1810	.2149	.2079	.2256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213321 / 22/11 KV HARIGANGA

Feeder No / Name : 205 / 11 KV Phule Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.8962	.8962	.3734	.3772	.3734	.3734
2	.8962	.8589	.8215	.3734	.3361	.3361	.3361
3	.8589	.8215	.7842	.3361	.3361	.3361	.3361
4	.8249	.8215	.7842	.3361	.4108	.3734	.3734
5	.7842	.9335	.8215	.3734	.4481	.4108	.4481
6	1.2696	1.307	1.1576	.4481	.4854	.4854	.6036
7	1.643	1.6804	1.5684	.4854	.5975	.5601	.7095
8	1.9418	1.7924	1.7551	.6722	.7095	.6722	.6722
9	1.7924	1.7177	1.7551	.7468	.6413	.6348	.6348
10	1.4937	1.643	1.5684	.6036	.6413	.6348	.5975
11	1.3443	1.3443	1.3817	.6036	.5281	.5228	.5175
12	1.0456	1.1576	1.1949	.5281	.4527	.4805	.5175
13	1.0082	1.0082	1.1203	.5281	.4904	.4435	.5175
14	1.0456	1.0829	1.0829	.415	.4527	.3734	.439
15	1.0562	1.0082	1.0829	.3018	.3772	.4108	.3658
16	1.1317	1.1317	1.0456	.415	.415	.4108	.4481
17	1.1694	1.2071	.5175	.3584	.5281	.4481	.4854
18		1.3203	.5601	.3772	.4904	.4854	.5228
19	1.4335	1.5844	.5975	.6036	.5658	.5975	.5975
20	1.4335	1.5089	.583	.6413	.5658	.5601	.5975
21	1.3957	1.3957	.5175	.5281	.5228	.5601	.5601
22	1.2696	1.307	.5228	.5228	.5228	.5228	.5601
23	1.1949	1.1949	.5228	.5228	.4108	.4854	.5601
24	.9709	.9335	.9335	.4108	.4108	.3734	.4854
Max	1.9418	1.7924	1.7551	.7468	.7095	.6722	.7095
Min	.7842	.8215	.5175	.3018	.3361	.3361	.3361
Avg	1.2147	1.2357	.9823	.4794	.4882	.4788	.5108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213321 / 22/11 KV HARIGANGA

Feeder No / Name : 206 / 11 KV BEG

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3395	.378	.3584	.3584	.3584	.3584
2	.3584	.3395	.3772	.3584	.3395	.3395	.3584
3	.3584	.3584	.3547	.3772	.3395	.3395	.3395
4	.415	.3772	.3584	.3961	.3584	.3772	.3395
5	.4904	.4904	.415	.4338	.4904	.547	.4904
6	.8299	.8488	.679	.5093	.8299	.811	.9242
7	.9431	.8745	.9242	.6413	.9619	.9619	.9431
8	.8676	.8676	.9242	.8488	.7733	.8299	.8299
9	.7545	.811	.8676	.8865	.679	.7356	.7356
10	.6602	.7167	.6979	.7733	.679	.6979	.5847
11	.6224	.6413	.6036	.6602	.6413	.5847	.6036
12	.547	.5788	.5281	.5847	.5658	.547	.547
13	.4904	.5228	.4904	.4715	.4904	.4715	.4904
14	.4715	.4527	.4527	.3961		.4338	.4715
15	.415	.3961	.415	.3584		.3961	.4338
16	.415	.415	.4338	.3395	.415	.3961	.4338
17	.5281	.5093	.4715	.415	.4715	.4715	.4904
18		.6224	.5847	.4527	.5281	.547	.6224
19	.7545	.7167	.6979	.6224	.679	.6413	.3326
20	.7356	.6602	.7167	.6413	.7167	.6413	.3584
21	.6602	.6413	.6224	.6224	.5281	.6224	.4527
22	.547	.4904	.5093	.4904	.4904	.4715	.415
23	.3961	.4338	.4338	.3961	.3772	.3961	.3206
24	.3772	.3584	.3961	.3772	.3584	.3584	.3584
Max	.9431	.8745	.9242	.8865	.9619	.9619	.9431
Min	.3584	.3395	.3547	.3395	.3395	.3395	.3206
Avg	.5659	.5610	.5555	.5171	.5487	.5407	.5098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213321 / 22/11 KV HARIGANGA

Feeder No / Name : 207 / 11 KV Line Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5993	.6348	.5993	.5975	.5975	.5975	.5975
2	.5601	.5975	.5601	.5601	.5601	.5601	.5601
3	.5601	.5975	.5601	.5601	.5228	.5228	.5228
4	.5601	.6348	.5975	.5975	.5975	.5228	.5228
5	.6348	.7468	.6348	.5975	.6722	.7095	.6348
6	.8215	.8589	.7468	.7095	.8215	.7842	.9709
7	.9709	.9709	.7842	.7095	.8962	.8589	.9709
8	1.0456	1.0082	.9709	.8999	.9335	1.0082	.9709
9	.9335	1.0456	1.0082	1.0456	1.0185	1.0082	1.0082
10	.9335	1.0082	.9709	1.0185	.8299	.9335	.8962
11	.8962	.8215	1.0082	.9431	.9054	.9335	.8501
12	.7095	.8215	.8215	.8676	.7922	.8501	.7762
13	.6348	.7095	.6722	.679	.6413	.6584	.6584
14	.6348	.6348	.5975	.6413	.6036	.5975	.5487
15	.6036	.5975	.5601	.6036	.5658	.5601	.5853
16	.6036	.5658	.5121	.6036	.6036	.5228	.5975
17	.5658	.6036	.5487	.6036	.5658	.5601	.6348
18		.6413	.6653	.6413	.6413	.6348	.6722
19	.9431	.9431	.9808	.9431	.9808	.9709	.9709
20	.9431	.9431	.9808	.9054	.9431	.9709	.9709
21	.9054	.9054	.8962	.9431	.8589	.9335	.9335
22	.8589	.8215	.8589	.8589	.8589	.8962	.9335
23	.7468	.7095	.7468	.7468	.7468	.7468	.7468
24	.6722	.6722	.6348	.6348	.6722	.6348	.6348
Max	1.0456	1.0456	1.0082	1.0456	1.0185	1.0082	1.0082
Min	.5601	.5658	.5121	.5601	.5228	.5228	.5228
Avg	.7538	.7706	.7465	.7463	.7429	.7490	.7570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213321 / 22/11 KV HARIGANGA

Feeder No / Name : 208 / 11 KV Spare feeder

Feeder KV- 11 / OUTGOING

DATE	13-FEB-18
HR	Load (MW)
13	.6653
Max	.6653
Min	.6653
Avg	.6653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213327 / 22/22 KV K RAHEJA SWICHING

STN

Feeder No / Name : 301 / 22 KV K'Raheja Feeder No-1 NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3395	.2641	.2641	.3772	.3772
2	.3772	.3018	.3018	.2641	.2641	.3018	.3018
3	.3395	.2641	.3018	.2641	.2641	.3018	.3018
4	.3018	.2641	.3018	.2263	.2641	.3018	.2641
5	.3018	.3018	.2641	.2263	.2641	.2641	.2641
6	.2641	.3018	.3018	.2263	.2641	.3018	.2641
7	.3018	.3395	.3018	.2641	.3018	.3018	.3018
8	.3772	.3772	.3018	.2641	.3395	.3772	.3018
9	.5658	.6036	.3018	.2641	.4904	.4904	.6036
10	.679	.6413	.2926	.2641	.679	.6413	.6722
11	.7167	.7167	.3292	.2641	.679	.7167	.7468
12	.7167	.7167	.3292	.2641	.7545	.7167	.7468
13	.7545	.7167	.3395	.2641	.7545	.7545	.7621
14		.6036	.3734		.7167	.679	.7167
15	.7922		.2957	.2614			
16	.8215	.679	.3734	.2641	.679	.7922	.8299
17	.7468	.7922	.3734	.2641	.7167	.7545	.8676
18	.7468	.679	.3361	.2987	.7167	.7167	.7545
19	.6348	.5658	.3361	.2614	.6413	.679	.6413
20	.5975	.5281	.2614	.2286	.6413	.6036	.5658
21	.4904	.4904	.2481	.2641	.4909	.5281	.5281
22		.4527	.2641	.2641	.415	.415	.4904
23		.3395	.2641	.2641	.3772	.3772	.415
24	.3395	.3395	.3772	.2641	.2641	.3772	.3772
Max	.8215	.7922	.3772	.2987	.7545	.7922	.8676
Min	.2641	.2641	.2481	.2263	.2641	.2641	.2641
Avg	.5336	.4937	.3129	.2589	.4888	.5117	.5259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213327 / 22/22 KV K RAHEJA SWICHING

STN

Feeder No / Name : 302 / 22 KV K Raheja Feeder no-2 NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	.4527	.3772	.3772	.4904	.4904
2	.4527	.4527	.3772	.3395	.3772	.4527	.4527
3	.5281	.415	.3772	.3395	.3772	.3772	.4527
4	.4527	.415	.3772	.3395	.3772	.3772	.415
5	.4527	.3772	.3395	.3395	.3772	.3772	.415
6	.4527	.4527	.3395	.3395	.4527	.3772	.415
7	.4527	.4527	.3395	.3772	.4904	.4527	.4527
8	.5281	.4904	.3772	.3772	.5658	.5281	.4904
9	.8299	.7545	.3772	.3772	.9054	.8299	.8299
10	.9808	.9054	.4572	.3772		.9808	.8962
11	1.0562	1.0562	.4954	.373	1.0562	1.0082	1.0185
12	1.0456	1.1317	.4954	.415	1.1317	1.0456	1.1694
13	1.0562	1.094	.5335	.4527	1.1317	1.1203	1.1576
14		1.1317	.5121		1.2449	1.094	1.1317
15	1.4335		.5544	.4904			
16	1.1088	1.094	.4904	.4904	1.1694	1.1694	1.0562
17	1.0349	1.1317	.5281	.5228	1.0562	1.1317	1.0562
18	.961	1.0562	.4481	.4108	1.1317	1.1694	1.0185
19	.8413		.415	.4527	.9054	.9054	1.0185
20	.8048	.7545	.415	.415	.7922	.8299	.7922
21	.8676	.679	.3772	.4527	.7545	.7545	.7922
22		.5658	.415	.415	.679	.7545	.7545
23		.4904	.3772	.3772	.5658	.6413	.679
24	.5281	.5281	.4904	.3772	.3772	.5658	.6036
Max	1.4335	1.1317	.5544	.5228	1.2449	1.1694	1.1694
Min	.4527	.3772	.3395	.3395	.3772	.3772	.415
Avg	.7772	.7219	.4317	.4012	.7407	.7580	.7634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213327 / 22/22 KV K RAHEJA SWICHING

STN

Feeder No / Name : 303 / 22 KV K. Raheja Buldg No- NON SHEDDABLE EXPRESS HV FEEDERS
 3 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.679	.5658	.415	.679	.679
2	.679	.679	.6036	.4904	.3772	.6036	.5658
3	.6036	.6036	.5281	.4527	.3772	.5658	.4527
4	.5281	.5281	.5281	.4527	.3772	.5658	.4527
5	.4527	.4527	.4904	.4527	.3772	.5281	.4527
6	.4527	.4527	.5281	.4527	.4527	.5658	.4527
7	.5281	.4527	.4904	.4904	.5658	.6036	.5658
8	.6036	.5281	.4904	.4904	.7922	.679	.679
9	.8299	.7922	.5281	.4527	.679	.7545	.7545
10		.9054	.5068	.4527		.9335	.8589
11		1.0562	.8048		.8676	1.0288	1.0456
12		1.094	.8048		1.0185	1.0456	1.0082
13		1.1576	.7842		1.105	1.1317	1.0829
14	.8962	1.2449	.8215		1.1694	.8299	1.1949
15	1.2826		1.0082				
16	1.3336	1.1694	.8676		1.1694		1.358
17	1.2574	1.1694	.8215		1.2071	1.3203	.9808
18	1.2193	1.1317	.8676	.4527	1.1694	1.2071	1.3203
19	1.1949	1.1694	.415	.679	1.1694	1.1694	1.3203
20	1.094	1.0562	.7922	.679	1.1694	1.1317	.9431
21	1.0185	.9054	.7167	.4904	1.094	1.0185	.9431
22		.9054	.679	.4904	.8299	.9431	1.0185
23		.8299	.7167	.4527	.8676	.8299	.9054
24	.7922	.8299	.8299	.6036	.4527	.7545	.7545
Max	1.3336	1.2449	1.0082	.679	1.2071	1.3203	1.358
Min	.4527	.4527	.415	.4527	.3772	.5281	.4527
Avg	.8623	.8638	.6793	.5059	.8047	.8586	.8604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213327 / 22/22 KV K RAHEJA SWICHING

STN

Feeder No / Name : 304 / 22 KV K Raheja No 4

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.4527	.415	.3395	.3772	.3395
2	.3772	.3772	.3772	.3772	.3395	.3772	.3395
3	.3395	.3395	.3772	.3772	.3395	.3658	.3395
4	.3395	.3772	.3772	.3772	.3395	.3395	.3018
5	.3772	.4531	.3395	.3772	.3395	.3395	.3018
6	.4527	.5281	.3772	.415	.3772	.3772	.3018
7	.5281	.6042	.5281	.415	.415	.4527	.4527
8	.679	.6413	.4527	.415	.6413	.5658	.6036
9	.7922	.7922	.6036		.8676	.679	.7167
10	.7468		.4954	.4527		.5975	.8962
11	.8589		.5716	.4527	.9054	.8002	.8676
12	.8676		.6036	.4904	.8676	.7842	.9054
13	.8589		.5658	.5281	.9054	.7468	.8589
14			.5975		.8676	1.0185	.8962
15	.8676	.9431	.679	.5658			
16	.8676	.8676	.6036	.5658	.8676	.679	.8299
17	.8299	.7922	.6036	.5281	.7545	.679	.8299
18	.7922	.7922	.6036	.5281	.7545	.679	.7545
19	.7095	.7545	.5601	.439	.7167	.6413	.7545
20	.6036	.6036	.5281	.5281	.7167	.6036	.679
21	.5716	.4904	.4527	.5281	.5281	.6413	.5281
22		.4527	.415	.4527	.4527	.415	.4904
23		.4527	.415	.415	.4527	.4904	.4527
24	.415	.415	.4904	.415	.3772	.415	.3772
Max	.8676	.9431	.679	.5658	.9054	1.0185	.9054
Min	.3395	.3395	.3395	.3772	.3395	.3395	.3018
Avg	.6294	.5818	.5029	.4572	.5984	.5680	.6008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213327 / 22/22 KV K RAHEJA SWICHING

STN

Feeder No / Name : 306 / 22 KV Raheja Buldg No-6

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4531	.5281	.3772	.3772	.4904	.6036
2	.4527	.4527	.415	.3772	.3772	.4527	.6036
3	.4527	.3772	.3772	.3772	.3772	.4527	.5658
4	.5281	.3772	.3772	.415	.3772	.4527	.4904
5	.5281	.3772	.415	.415	.3772	.4904	.4904
6	.4527	.4527	.415	.415	.415	.4904	.4527
7	.5281	.4527	.4527	.415	.4527	.5658	.5658
8	.6036	.5281	.4904	.4904	.7167	.7167	.7167
9	.9808	.9054	.4527	.415	.9054	.8676	1.1694
10	.9907	.9808	.4954	.415		.9808	1.0456
11	1.0082	1.0082	.4954	.415	1.0185	1.0562	1.094
12	.9897	.9808	.4954	.415	1.0562	.9808	1.0562
13	1.0456	.9808	.4954	.415	1.0185	.8299	1.0456
14		.9709	.4904		1.0562	.8676	1.0082
15	.9808		.5658	.4527			
16	.9907	1.0185	.4904	.415	1.0206	.8676	1.0562
17	.9907	.9808	.4527	.4904	.9054	.7922	1.0562
18	.9907	.9431	.4527	.4527	.9072	.7545	.9808
19	.8764	.8676	.6036	.4527	.8676	.7922	.9808
20	.7545	.7545	.5658	.415	.8299	.7167	.6413
21	.7167	.7167	.415	.415	.679	.679	.679
22		.679	.4527	.415	.679	.679	.6036
23		.6413	.415	.415	.6413	.6413	.679
24	.6036	.5281	.6413	.415	.415	.5281	.5658
Max	1.0456	1.0185	.6413	.4904	1.0562	1.0562	1.1694
Min	.4527	.3772	.3772	.3772	.3772	.4527	.4527
Avg	.7616	.7142	.4771	.4215	.7032	.7020	.7892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213327 / 22/22 KV K RAHEJA SWICHING

STN

Feeder No / Name : 307 / 22 KV K' Raheja Bldg No- NON SHEDDABLE EXPRESS HV FEEDERS
 7 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3772	.3772	.3772	.3395	.3772	.415
2	.3772	.3772	.3395	.3395	.3395	.3772	.3772
3	.3772	.3395	.3395	.3395	.3395	.3395	.3772
4	.3018	.3395	.3395	.3395	.3395	.3395	.3772
5	.3018	.3776	.3772	.3395	.3772	.3395	.3772
6	.3772	.415	.3772	.3772	.3772	.3772	.415
7	.4527	.415	.415	.3772	.415	.4527	.4527
8	.6036	.4527	.4904	.3772	.5658	.7545	.4904
9	.7922	.7167	.415	.3772	.7545	.7922	.7545
10	.9526	.9054	.4527	.415		.9054	.9808
11	.9808	.9431	.4527	.4527		.9431	.9808
12	.9808	.9431	.4904			.9431	1.0082
13	.9431	1.0185	.5281			.9431	.9897
14		.9808	.4904			.9526	1.0082
15	.9709		.4904	.4904			
16	1.0288	.9808	.5335	.4527	.9808	.9828	.9808
17	.9907	.9054	.4954	.4527	.9828	.9054	.9808
18	.9526	.8299	.5335	.4527	.9072	.9072	.9808
19	.8383		.4954	.4527	.8299	.8299	.9054
20	.7922	.7545	.3772	.4108	.7545	.7175	.6413
21	.6097	.6413	.3772	.3772	.6036	.6036	.6413
22		.5658	.3772	.415	.5658	.5658	.6036
23		.4904	.3772	.3395	.5281	.5281	.6036
24	.4527	.415	.415	.3772	.3772	.4527	.4527
Max	1.0288	1.0185	.5335	.4904	.9828	.9828	1.0082
Min	.3018	.3395	.3395	.3395	.3395	.3395	.3772
Avg	.6919	.6447	.4315	.3968	.5765	.6665	.6867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213327 / 22/22 KV K RAHEJA SWICHING

STN

Feeder No / Name : 308 / 22 kv K'Raheja Buldg no-8 NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5281	.4904	.415	.415	.4527	.4904
2	.4527	.4527	.4527	.415	.3772	.4527	.4527
3	.4527	.4527	.4527	.415	.3772	.415	.3772
4	.3772	.5281	.4527	.3772	.3772	.415	.3772
5	.4527	.6036	.4527	.3772	.3772	.4024	.3772
6	.6036	.6036	.4904	.3772	.415	.5281	.4527
7	.679	.6036	.4904	.415	.5658	.6036	.5658
8	.7545	.679	.4904	.4527	.7922	.679	.7922
9	.8299	.679	.4755	.4904	.8299	.9808	.679
10	.905	.9431	.4973			.8299	.9709
11	1.0185	.9808	.5426		.9808	.7922	.9709
12	1.0562	1.0185	.5304	.6036	1.0185	.7842	1.0082
13	1.0456	1.0185	.5426	.6036	1.0185	.8299	1.0562
14		1.0082	.5975		1.0185	.8589	1.0829
15	1.0456		.6653	.5487			
16	1.094	.9808	.5914	.5335	1.0584	.8694	1.0562
17	1.0562	1.0456	.5601	.6036	.9828	.8299	.9808
18	1.0185	.9808	.5601	.5121	1.0185	.8676	.9808
19	1.094	1.0185	.5975	.5228	.9072	.8299	.9808
20	.8676	.7922	.5175	.4755	.8299	.7545	.7167
21	.8215	.7545	.5068	.5281	.7922	.679	.7167
22		.679	.4527	.4904	.6413	.6413	.7167
23		.5658	.5658	.4527	.6036	.5658	.6036
24	.5281	.5281	.5281	.4527	.4527	.5281	.5658
Max	1.094	1.0456	.6653	.6036	1.0584	.9808	1.0829
Min	.3772	.4527	.4527	.3772	.3772	.4024	.3772
Avg	.7943	.7585	.5210	.4791	.7204	.6778	.7379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213327 / 22/22 KV K RAHEJA SWICHING

STN

Feeder No / Name : 309 / 22 kv K'Raheja Buldg No 5 NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.7545	.6036	.6413	.7545	.7545
2	.679	.679	.679	.6036	.6413	.679	.679
3	.679	.6036	.6413	.6036	.6413	.679	.679
4	.6036	.6036	.6413	.6036	.6413	.679	.6413
5	.679	.679	.6413	.6413	.679	.679	.6413
6	.8299	.7545	.679	.6413	.7545	.7167	.679
7	.9808	.9072	.7545	.6413	.8299	.7922	.7922
8	1.094	1.1718	.8299	.679	1.094	.9808	1.0562
9	1.0185	1.0185	.7545	.7545	1.0562	1.0562	1.0562
10	1.0082	1.0288	.7922	.8002		1.0562	1.0669
11	1.1203	1.1317	.8676	.8002	1.1317	1.0829	1.1317
12	1.094	1.0562	.9431	.7922	1.0562	1.0456	1.0829
13	1.105	1.094	.9054	.7545	1.0562	1.0082	1.0829
14		1.0562	.8676		1.094	1.0829	1.1203
15	1.0456		.8299	.7545			
16	1.1317	1.0562	.8676	.7621	1.0962	1.0562	.9054
17	1.094	1.0562	.7545	.7545	1.0584	.9808	1.0562
18	1.0185	.9808	.8299	.7922	1.0185	.9828	
19	.9431	1.0082	.8676	.8002	.9808	.9808	.9808
20	.9808	.9907	.7545	.7842	.9808	.9808	.8299
21	.9808	.9431	.7167	.7545	.9808	.9808	1.0185
22		.9054	.7167	.7167	.9431	.9431	.9808
23		.9054	.679	.7167	.8676	.8676	.9054
24	.8316	.9054	.8676	.7545	.7167	.8299	.8299
Max	1.1317	1.1718	.9431	.8002	1.1317	1.0829	1.1317
Min	.6036	.6036	.6413	.6036	.6413	.679	.6413
Avg	.9368	.9257	.7765	.7178	.9073	.9085	.9077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213354 / 22/11 KV Kalas (GREF) S/Stn.

Feeder No / Name : 201 / 11 KV Kalas (PATHAN BABA) Feeder KV- 11 / OUTGOING SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7842	.7842	.7842	.8215	.8215	.7842
2	.7468	.7468	.7095	.7095	.7468	.7842	.7842
3	.7095	.7095	.6722	.7095	.7095	.7468	.7468
4	.7095	.7095	.6722	.7095	.7095	.7468	.7468
5	.8589	.9335	.9335	.7468	.8215	.7842	.8215
6	1.1576	1.307	1.0829	.8962	1.1576	1.0456	1.2696
7	1.5684	1.643	1.2696	1.2323	1.6057	1.419	1.7177
8	1.7924	1.8671	1.643	1.531	1.9044	1.9418	1.9044
9	1.8671	1.7551	1.8298	1.7551	1.7924	2.0165	1.7924
10	1.6057	1.5684	1.7551	1.7924	1.6057	1.7551	1.643
11	1.3443	1.3817	1.6057	1.7551	1.307	1.5684	1.3443
12	1.1203	1.1949	1.4563	1.4937	1.1576	1.307	1.1949
13	1.0456	1.0456	1.1949	1.2696	1.0082	1.1203	1.1203
14	.8962	.9335	1.0829	1.0829	.9709	1.0456	1.0185
15	.8962	.8962	.9335	1.0082	.9335	.9709	.9709
16	.8215	.8589	.9335	.9709	.8962	.8962	.9335
17	.924	.9709	.9709	1.0829	.9335	.9709	1.0082
18	1.0456	1.0829	1.1949	1.1576	1.0349	1.1088	1.1949
19	1.4563	1.5684	1.531	1.5154	1.6263	1.5524	1.5684
20	1.531	1.5684	1.531	1.5684	1.5684	1.6057	1.643
21	1.419	1.531	1.4937	1.5684	1.4937	1.531	1.5684
22	1.307	1.3443	1.307	1.3443	1.3676	1.4045	1.419
23	1.1203	1.1203	1.1203	1.1203	1.1088	1.1203	1.1949
24	.9335	.8962	.9335	.8962	.9335	.8962	.9335
Max	1.8671	1.8671	1.8298	1.7924	1.9044	2.0165	1.9044
Min	.7095	.7095	.6722	.7095	.7095	.7468	.7468
Avg	1.1510	1.1841	1.1934	1.1959	1.1756	1.2150	1.2218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213354 / 22/11 KV Kalas (GREF) S/Stn.

Feeder No / Name : 202 / 11 KV GREF centre

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0886	.0886	.0886	.0886	.0895	.0905
2	.0886	.0886	.0886	.0886	.0886	.0905	.0905
3	.0886	.0886	.0886	.0886	.0886	.0905	.0905
4	.0886	.0886	.0886	.0886	.0886	.0905	.0905
5	.1417	.124	.124	.1063	.1417	.1267	.1086
6	.2126	.1949	.1417	.124	.1772	.181	.1629
7	.2481	.2481	.1595	.124	.1772	.2172	.1448
8	.1595	.1772	.1772	.1595	.1417	.1991	.1991
9	.1949	.1772	.1772	.5601	.2126	.2172	.181
10	.1612	.1612	.1772	.1791	.1612	.197	.1595
11	.1612	.1753	.1663	.1612	.181	.1629	.1075
12	.1612	.1448	.1433	.1254	.1254	.1254	.1097
13	.1254	.124	.124	.1075	.1294	.1267	.0895
14	.1063	.1052	.1109	.1063	.1267	.1086	.0914
15	.0886	.1052	.2896	.0709	.1063	.0886	.0886
16	.0876	.0886	.0701	.0701	.0693	.0867	.0886
17	.1227	.0886	.1227	.1052	.1227	.1214	.124
18	.1578	.1402	.1387	.1227	.1402	.1387	.1417
19	.1865	.1753	.1772	.1734	.1753	.1753	.1417
20	.1543	.1595	.1595	.156	.1578	.1578	.1595
21	.1543	.1578	.1772	.156	.1578	.1578	.1595
22	.1417	.1417	.1417	.1417	.1402	.1402	.1417
23	.1063	.1063	.1063	.1063	.1052	.1063	.1063
24	.0886	.0709	.0886	.0886	.0886	.0886	.1063
Max	.2481	.2481	.2896	.5601	.2126	.2172	.1991
Min	.0876	.0709	.0701	.0701	.0693	.0867	.0886
Avg	.1381	.1342	.1386	.1374	.1330	.1368	.1239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213354 / 22/11 KV Kalas (GREF) S/Stn.

Feeder No / Name : 203 / 11 KV VSNL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2614	.2614	.2614	.2987	.3018	.2641
2	.2614	.2614	.2614	.2614	.2987	.3018	.2641
3	.2614	.2614	.2614	.2614	.2614	.3018	.2641
4	.2614	.2987	.2614	.2614	.2614	.3018	.2641
5	.3734	.3734	.3361	.2987	.3361	.415	.3395
6	.4481	.5228	.4108	.3734	.4108	.5281	.4904
7	.5601	.6348	.4854	.4854	.5601	.5281	.5658
8	.5601	.5228	.4854	.5228	.5228	.5281	.5658
9	.5601	.5228	.5228	.5601	.5601	.5658	.5281
10	.5658	.5281	.4527	.5281	.5658	.5281	.4904
11	.4904	.4904	.5281	.6036	.4904	.5281	.5281
12	.415	.4904	.5281	.5281	.3395	.4527	.415
13	.3772	.3772	.2641	.415	.2641	.3395	.3395
14	.3018	.3018	.3018	.3395	.2263	.2641	.3395
15	.2641	.2641	.3018	.3018	.1886	.2641	.2641
16	.2641	.3018	.3018	.2641	.3395	.2641	.2987
17	.2641	.3018	.3395	.3772	.3018	.3018	.2987
18	.415	.415	.3772	.4527	.4527	.4108	.4108
19	.3772	.5658	.5281	.5658	.5658	.5658	.5601
20	.4904	.5658	.4904	.5281	.5281	.5281	.5658
21	.4904	.4904	.4904	.4527	.5281	.4904	.4854
22	.4481	.4481	.4108	.4854	.4527	.4527	.4904
23	.3361	.3361	.3361	.3734	.3772	.3395	.3772
24	.2987	.2614	.2835	.2987	.2987	.3395	.3018
Max	.5658	.6348	.5281	.6036	.5658	.5658	.5658
Min	.2614	.2614	.2614	.2614	.1886	.2641	.2641
Avg	.3894	.4082	.3842	.4083	.3929	.4101	.4046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213403 / 22/11 KV Dhanori

Feeder No / Name : 202 / 11 KV Ganesh vihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4108	.4108	.4108	.4108	.3961	.415
2	.3772	.3921	.3921	.3772	.3921	.3584	.3772
3	.3772	.3734	.3734	.3734	.3734	.3584	.3547
4	.4527	.3734	.3734	.3734	.3734	.3584	.4108
5	.5281	.4527	.415	.415	.415	.415	.4668
6	.5658	.5281	.4904	.4527	.6224	.4715	.5658
7	.7842	.7842	.6535	.5975	.7733	.679	.7922
8	.9619	.9335	.7655		.8865	.9054	.9997
9	.8775	.9335	.8402		.8402	5.7716	.9431
10	.7842	.7655	.7468	.8029	.7095	.8962	.7577
11	.6161	.7468	.7842	.8962	.7095	.8029	.7023
12	.6099	.6653	.7207	.8029	.6219	.6468	.6468
13	.5415	.6468	.6838	.7023	.5487	.5729	.5487
14	.4572	.499	.5544	.5788	.4755	.4435	.4706
15	.4207	.4755	.5041	.5544	.4024	.4435	.4805
16		.4572	.499	.499	.4163	.4024	.439
17		.4572	.4755	.5304	.4525	.4344	.4887
18	.5068	.5611	.6283	.567	.4572	.4938	.5611
19	.6908	.7468	.7922	.7655	.7762	.7468	.7468
20	.7282	.7468	.7842	.7842	.7842	.8029	.7655
21	.7095	.7468	.7655	.7947	.7655	.7842	.7842
22	.7207	.6908	.6535	.6908	.6908	.6602	.7167
23	.5658	.5281	.5281	.5601	.5658	.5658	.5658
24	.4338	.4527	.4668	.4527	.4854	.4338	.4481
Max	.9619	.9335	.8402	.8962	.8865	5.7716	.9997
Min	.3772	.3734	.3734	.3734	.3734	.3584	.3547
Avg	.5957	.5987	.5959	.5901	.5812	.7852	.6020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213403 / 22/11 KV Dhanori

Feeder No / Name : 203 / 11 KV Hans Garden(Dhanori)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5652	2.5652	2.6406	2.5393	2.5019	2.452	2.5274
2	2.452	2.4897	2.4143	2.2257	2.3899	2.3577	2.3577
3	2.4143	2.452	2.4143	2.1502	2.3525	2.2257	2.2634
4	2.4143	2.4272	2.4897	2.1502	2.3152	2.2257	2.4143
5	2.6029	2.6406	2.7538	2.3765	2.5019	2.4143	2.8104
6	3.4328	3.7342	3.0556	2.6783	3.6591	3.0178	3.6214
7	4.6022	4.7424	3.6595	3.5082	4.3381	3.9609	4.6399
8	5.3189	5.2279	4.7051		5.0412	5.3189	5.4698
9	5.3026	5.1532	4.8918		4.8731	5.7716	5.2812
10	4.5557	4.6304	4.8544	4.9291		5.1532	4.2943
11	4.0329	4.1076	4.481	4.4437	5.4702	4.3317	3.8089
12	3.4374	3.6595	4.0657	4.369	3.8775	3.8809	3.4004
13	3.1047	3.4355	3.6591	3.77	3.3653	3.3265	3.1459
14	2.7633	2.9874	3.2156	3.3265	2.9264	3.0727	2.8829
15	2.7435	2.5972	3.1047	3.0308	2.7801	2.809	2.8829
16		2.7069	2.8829	2.9264	2.6787	2.7435	2.7721
17		2.8597	2.963	3.0727	2.7221	3.0045	2.8532
18	3.0361	3.2556	3.3836	3.3288	3.0045	3.1131	3.1459
19	4.145	4.4063	4.5184	4.5931	4.2196	4.369	4.369
20	4.369	4.4437	4.4063	4.6304	4.369	4.5184	4.5931
21	4.3759	4.4063	4.4063	4.5184	4.4437	4.481	4.5184
22	4.2196	4.0703	4.0741	4.257	4.1076	4.0741	4.3381
23	3.4705	3.3951	3.3608	3.5662	3.5082	3.5837	3.5837
24	2.9424	2.7915	2.8669	2.838	2.9127	2.8669	2.9047
Max	5.3189	5.2279	4.8918	4.9291	5.4702	5.7716	5.4698
Min	2.4143	2.4272	2.4143	2.1502	2.3152	2.2257	2.2634
Avg	3.5591	3.5494	3.5528	3.4195	3.4938	3.5447	3.5366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213403 / 22/11 KV Dhanori

Feeder No / Name : 204 / 11 KV Mayur Kilbil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0412	.0434	.0274	.0282	.0423	.0274	.0263
2	.0417	.0423	.0271	.0278	.0286	.0293	.0244
3	.0274	.0412	.0267	.0278	.0286	.0297	.024
4	.029	.0263	.0267	.0282	.0286	.0305	.0255
5	.0297	.0259	.0271	.0274	.0267	.0286	.0263
6	.0463	.0271	.0274	.0259	.0278	.0255	.0271
7	.0457	.0417	.0429	.0251	.0474	.044	.0452
8	.0497	.0486	.0255		.0463	.0457	.0412
9	.0492	.0301	.0324		.0463	.0463	.0301
10	.0509	.0497	.0492	.0509	.0492	.0274	.0463
11	.048	.0286	.052	.0457	.0469	.0509	.0423
12		.0324	.0332	.0469	.0474	.0309	.0492
13		.0293	.0278	.0469	.0305	.0324	.0429
14	.0095	.0263	.0297	.0278	.024	.0255	.0274
15	.0038	.029	.0278	.0282	.0278	.0236	.0263
16		.024	.0274	.0286	.0213	.0274	.0278
17		.0271	.0282	.0286	.0229	.0259	.0278
18	.0191	.0286	.0474	.0312	.0274	.0259	.024
19	.0191	.0497	.0678	.0492	.0474	.0457	.0486
20	.0191	.0503	.0486	.0469	.0497	.0463	.048
21	.0191	.0497	.0486	.048	.0469	.0486	.0474
22	.0532	.0486	.0514	.048	.0492	.0469	.0457
23	.0503	.0463	.0463	.0486	.0463	.0446	.0474
24	.0446	.0446	.0434	.044	.044	.0286	.0417
Max	.0532	.0503	.0678	.0509	.0497	.0509	.0492
Min	.0038	.024	.0255	.0251	.0213	.0236	.024
Avg	.0348	.0371	.0372	.0368	.0376	.0349	.0360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213403 / 22/11 KV Dhanori

Feeder No / Name : 301 / 22 KV Kirti castle

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.2622	.2622	.2622	.2622	.2622	.2622
2	.2622	.2622	.2622	.2622	.2622	.2622	.2622
3	.2622	.2622	.2622	.2622	.2622	.2622	.2622
4	.2622	.2622	.2622	.2622	.2622	.2622	.2622
5	.2622	.2622	.2622	.2622	.2622	.2622	.2622
6	.2622	.2622	.2622	.2622	.2622	.2622	.2622
7	.2622	.2622	.2622	.2622	.2622	.2622	.2622
8	.2622	.2622	.2622		.2622	.2622	.2622
9	.2622	.2622	.2622		.2622	.2622	.2622
10	.2622	.2622	.2622	.2622	.2622	.2622	.2622
11	.2622	.2622	.2622	.2622	.2622	.2622	.2622
12	.2622	.2622	.2622	.2622	.2622	.2622	.2622
13	.2622	.2622	.2622	.2622	.2622	.2622	.2622
14	.2622	.2622	.2622	.2622	.2622	.2622	.2622
15	.2622	.2622	.2622	.2622	.2622	.2622	.2622
16	.2622	.2622	.2622	.2622	.2622	.2622	.2622
17	.2622	.2622	.2622	.2622	.2622	.2622	.2622
18	.2622	.2622	.2622	.2622	.2622	.2622	.2622
19	.2622	.2622	.2622	.2622	.2622	.2622	.2622
20	.2622	.2622	.2622	.2622	.2622	.2622	.2622
21	.2622	.2622	.2622	.2622	.2622	.2622	.2622
22	.2622	.2622	.2622	.2622	.2622	.2622	.2622
23	.2622	.2622	.2622	.2622	.2622	.2622	.2622
24	.2622	.2622		.2622	.2622	.2622	.2622
Max	.2622	.2622	.2622	.2622	.2622	.2622	.2622
Min	.2622	.2622	.2622	.2622	.2622	.2622	.2622
Avg	.2622	.2622	.2622	.2622	.2622	.2622	.2622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213403 / 22/11 KV Dhanori

Feeder No / Name : 302 / 22KV Porwal Road swt. stn NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3011	2.1879	2.0774	2.0698	2.1502	2.1502	2.1879
2	2.037	1.9616	1.893	1.8461	2.1125	2.0748	2.0485
3	2.037	1.9616	1.8724	1.7551	2.1125	2.037	1.97
4	2.1125	2.037	1.8724	1.7551	2.0748	2.037	2.1582
5	2.3011	2.1879	2.1262	1.8823	2.1879	2.2634	2.3899
6	2.8292	2.7161	2.6063	2.0851	3.0178	2.6406	2.9047
7	4.0364	3.8855	3.2487	2.95	3.81	3.3951	3.8855
8	4.6776	4.3759	3.9986		4.3381	.6036	4.225
9	4.2627	4.0741	4.1872		4.0741	5.2058	3.9232
10	3.6969	3.81		4.3759	3.3951	4.1872	3.546
11	3.3573	2.7161	3.81	3.6969	3.3573	3.546	3.546
12	3.0178	2.4143	3.6969	3.4705	3.131	3.0933	3.0556
13	2.7538	3.0178	3.2819	3.0556	2.8292	2.9801	2.6783
14	2.4143	2.5274	2.9047	2.7538	2.5274	2.5274	2.452
15	2.4897	2.6029	2.7538	2.9801	2.5652	2.5652	2.5274
16	2.4143	2.6406	2.7161	2.7161	2.6783	2.6406	2.6783
17	2.3388	2.7161	2.8292	2.8669	2.7538	2.7538	2.8292
18	2.5652	3.0178	3.131	2.9424	2.8292	2.8669	3.0556
19	3.5082	3.9986	4.0741	3.8855	3.6969	3.8477	3.9609
20	3.6214	3.9232	3.8855	3.8855	3.8477	3.9232	3.8855
21	3.5837	3.6969	3.81	3.6969	3.6969	3.81	3.8477
22	3.2819	3.4728	.431	3.4705	3.5082	3.3573	3.4328
23	2.7915	2.846	2.0748	2.8669	2.9424	2.8669	2.8669
24	2.452	2.3388	2.3891	2.0328	2.4897	2.3765	2.3765
Max	4.6776	4.3759	4.1872	4.3759	4.3381	5.2058	4.225
Min	2.037	1.9616	.431	1.7551	2.0748	.6036	1.97
Avg	2.9534	2.9636	2.8552	2.8654	3.0053	2.9062	3.0180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213404 / 22/22 KV Kirti Castle

Feeder No / Name : 301 / 22 KV MMIT

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0732	.0753	.0761	.0754	.0753	.0751
2	.0752	.0739	.071	.0729	.0754	.0751	.0751
3	.0753	.0761	.0729	.0734	.0747	.0761	.0751
4	.1507	3.062	.15	.141	.0754	.0761	.0751
5	.1521	.0754	.1454	.1421	.1494	.0734	.1503
6	.1472	.1478		.1494	.1494	.1503	.1503
7	.1495	.1494	.2211	.1503	.1494	.1468	.1504
8	.1498	.1463	.1503	.1472	.2218	.1503	.1503
9	.1509	.1509	.1478	.1472	.1478	.1471	.1494
10	.1494	.2241	.1478	.1494	.1478	.1495	.1478
11	.2241	.1463	.1478	.0754	.1478	.1478	.1494
12	.1494	.1494	.1478	.0732	.1478	.1509	.1509
13	.0754	.1509	.1494	.1478	.1478	.0747	.0747
14	.1494	.1494	.0747	.1494	.1478	.0754	.0732
15	.1509	.1463	.0732	.0754	.1478	.0747	.0754
16	.1478	.1494	.0739	.0732	.1463	.0739	.0732
17	.1463	.1494	.1478	.0739	.0747		.0732
18	.1478	.1494	.1478	.0739	.1463	.0732	.0732
19	.1478	.1478	.1478	.1478	.1494	.1463	.1478
20	.1478	.1509	.1478	.1478	.1509	.1463	.1478
21	.1506	.1509	.1478	.1478	.1494	.1468	.1478
22	.151	.1404	.1503	.0754		.1471	.1509
23	.1509	.1503	.0751	.0754		.1503	.1494
24	.1472	.0761	.0759	.0753	.0754	.0751	.1472
Max	.2241	3.062	.2211	.1503	.2218	.1509	.1509
Min	.0752	.0732	.071	.0729	.0747	.0732	.0732
Avg	.1401	.2578	.1256	.1109	.1317	.1132	.1180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213404 / 22/22 KV Kirti Castle

Feeder No / Name : 302 / 22 KV Gaothan

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.271	.3772	.3009	.3042	.3018	.2936	.3006
2	.3042	.2987	.3006	.2808	.3018	.3009	.3006
3	.2951	.2926	.3045	.3009	.3018	.3009	.3006
4	.3009	.2987	.2993	.3012	.3018	.3042	.3757
5	.3761	.3696	.3521	.3757	.3734	.3681	.3761
6	.4513	.4527	.423	.4481	.3734	.4353	.4508
7	.5244	.5121	.5137	.5319	.5175	.526	.526
8	.5871	.6722	.5255	.5281	.5121	.5639	.6011
9	.4527	.5975	.5121	.5975	.5175	.5137	.439
10	.3734	.4527	.439	.5914	.4435	.5153	.4435
11	.3734	.3734	.439	.5281	.3696	.4527	.3696
12	.2987	.2987	.439	.4435	.3696	.3734	.3772
13	.3018	.3772	.3696	.3734	.2957	.3696	.2987
14	.2241	.2987	.2957	.3734	.2957	.3018	.2241
15	.3018	.2926	.2957	.3018	.2957	.2987	.3018
16	.2957	.2957	.2957	.2957	.2926	.2926	.2926
17	.2957	.2957	.2957	.2957	.2957		.2926
18	.2957	.3696	.3696	.2957	.2926	.2926	.3658
19	.3696	.439	.4435	.4435	.4435	.4435	.4435
20	.3696	.1494	.4435	.5175	.4527	.4435	.4435
21	.4513	.4527	.4435	.4435	.4481	.3521	.4435
22	.4563	.3803	.3688	.4481		.3757	.4527
23	.3772	.3757	.3757	.3734		.3765	.3734
24	.3042	.3807	.2814	.3045	.2987	.3006	.3012
Max	.5871	.6722	.5255	.5975	.5175	.5639	.6011
Min	.2241	.1494	.2814	.2808	.2926	.2926	.2241
Avg	.3605	.3793	.3803	.4041	.3679	.3824	.3789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213410 / 22/22 KV Porwal Road

Switching

Feeder No / Name : 301 / 22 KV Elemento

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.292	.2203	2.2181	.2565	.295	.2339
2	.2181	.2341	.1996	2.1808	.2188	.2726	.2263
3	.1996	.2158	.1792	2.1548	.2226	.2476	.2188
4	.2378	.2425	.1939	2.1659	.2263	.2048	.2091
5	.2698	.289	.2292	2.192	.2301	.2513	.239
6	.3357	.3395	.2763	2.2106	.2754	.2641	.3621
7	.4115	.4039	.282	2.9198	.415	.3544	.4306
8	.5243	.5357	.4414		.4866	.5809	.5583
9	.5432	.4829	.4564	.4344	.5583	.5734	.4564
10	.4829	.5017	.503	.4942	.4112	.5206	.4074
11	.4451	.4036	.4763	.5545	.3772	.4942	.4153
12	.3621	.3999	.4602	.5319	.3433	.3658	.4187
13	.2972	.3224	.4263	.4678	.3093	.3391	.3131
14	.301	2.022	.3999	.4187	.298	.2858	.2829
15	.2591	.2791	.3018	.3471	.2905	.2972	.2829
16	.2591	.2565	.298	.3546	.249	.282	.2791
17	.2743	.2867	.3018	.3093	.2641	.3086	.298
18	.2629	.2942	.3584	.3471	.3056	.2743	.3244
19	.362	.3735	.3697	.3772	.381	.3963	.4263
20	.3772	.3772	.3772	.4376	.3471	.3925	.4074
21	.4001	.3772	.3848	.3923	.4036	.3734	.3506
22	.3506	.3696	.3068	.3659	.3963	.3544	.3696
23	.3282	.3282	2.3388	.3056	.3621	.2565	.2829
24	.2565	.2678	.2414	2.1917	.2565	.3282	
Max	.5432	2.022	2.3388	2.9198	.5583	.5809	.5583
Min	.1996	.2158	.1792	.3056	.2188	.2048	.2091
Avg	.3331	.4123	.4176	1.0596	.3285	.3464	.3388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 213410 / 22/22 KV Porwal Road

Switching

Feeder No / Name : 302 / 22 KV Parkspring (Sant Nagar I Feeder KV- 22 / INCOMING NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8436	1.8619	1.8628		1.773	1.882	1.885
2	1.818	1.7991	1.8144		1.6598	1.8296	1.7556
3	1.7665	1.7701	1.7888		1.6598	1.8	1.7086
4	1.8034	1.8144	1.7852		1.6975	1.8107	1.647
5	2.2029	2.0476	2.0351		1.773	1.9534	
6	2.7558	2.6587	2.3115		2.452	2.2953	2.8679
7	3.9156	3.3649	3.0933		3.0933	2.9726	3.5309
8	4.0619	3.719	3.3611		3.5837		3.8256
9	3.5665	3.3498	3.7456	1.8107	3.3196	4.0009	3.2922
10	3.2312	3.2312	3.5361	3.8628	3.0712	3.517	3.1817
11	2.8959	2.1948	3.2312	3.2922	2.9569	3.1207	3.048
12	2.6216	2.0521	3.1084	3.0178	2.6597	2.713	2.6067
13	2.4082	2.4996	2.7538	2.5953	2.412	2.5263	2.3053
14	2.1125	2.022	2.4463	2.5274	2.2332	2.2785	2.1049
15	2.1502	2.3049	2.2481	2.4897	2.2862	2.2024	2.2138
16	2.037	2.3426	2.2481	2.2634	2.2862	2.2748	2.4082
17	2.037	2.4294	2.3243	2.452	2.3624	2.3929	2.4671
18	2.1879	2.6859	2.8959	2.4897	2.4006	2.4958	2.6444
19	3.0178	3.5686	3.5437	3.2819	3.1626	3.6466	3.4366
20	3.0933	3.4252	3.315	3.3196	3.2769	3.4141	3.4598
21	3.0178	3.2781	3.2388	3.0933	3.1626	3.2846	3.2894
22	2.8066	2.8368		2.8669	2.8669	2.9877	2.9575
23	2.304	2.4011		2.5652	2.4294	2.3003	2.36
24	2.0402	1.9022	1.9626		1.9616	1.9352	2.0107
Max	4.0619	3.719	3.7456	3.8628	3.5837	4.0009	3.8256
Min	1.7665	1.7701	1.7852	1.8107	1.6598	1.8	1.647
Avg	2.5706	2.565	2.6659	2.7952	2.5225	2.5928	2.6525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

VISHRANTWADI SUB-DN.[602] BU 4602

Substation No/ Name :- 218059 / 220/22 KV VSNL S/Stn.

Feeder No / Name : 302 / 22 KV Kalas S/Stn Incommmer NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4675	3.4675	3.8104	3.3532	3.0864	3.7723	3.2819
2	3.1245	3.1245	3.4294	3.2769	3.0483	3.7723	3.2065
3	3.1245	3.1626	3.4294	3.2388	3.0483	3.3951	3.2007
4	3.1626	3.2388	3.3951	3.131	3.0483	3.3951	3.2007
5	3.4294	3.3951	3.6591	3.2769	3.0483	3.3951	3.5056
6	5.6584	6.4883	5.0297	4.1872	6.0357	5.2812	5.4108
7	6.6392	7.0165	6.0357	5.0297	6.7147	6.4129	6.6392
8	7.6578	7.2428	6.8279	6.5638	7.3552	7.3937	7.62
9	6.9033	6.4129	6.941	7.1674	5.7716	7.5446	6.7147
10	5.9602	5.8848	6.5261	6.7901	5.7716	6.4129	5.6207
11	5.1303	4.9665	5.8471	5.6584	5.1532	5.6584	5.168
12	4.3317	4.5931	5.2279	5.2279	4.4437	4.7424	4.481
13	3.9609	3.9209	4.1076	4.3004	3.7715	4.1076	3.9582
14	3.5848	3.5848	3.7342	3.8089	3.4328	3.6969	3.5852
15	3.4728	3.5475	3.6222	3.3608	3.3981	3.4355	3.6969
16	3.3981	3.5852	3.6222	3.3608	3.546	3.5101	3.6595
17	3.6222	3.77	3.807	3.8462	3.6961	3.6222	3.9918
18	4.1396	4.5462	4.8544	4.4063	4.0657	4.2875	5.2115
19	5.998	6.3481	6.1988	5.9137	5.9747	6.2361	6.4228
20	5.8848	6.3481	6.0867	6.0616	5.9747	6.1614	6.5348
21	5.8471	5.9747	5.8471	5.6013	5.9747	6.0357	6.2361
22	5.3189	5.5076	5.2812	5.2812	5.2812	5.4698	5.6584
23	4.225	4.1495	4.7531	4.1118	4.3381	4.1495	4.5268
24	3.658	3.7342	3.7723	3.6214	3.5082	3.6969	3.7342
Max	7.6578	7.2428	6.941	7.1674	7.3552	7.5446	7.62
Min	3.1245	3.1245	3.3951	3.131	3.0483	3.3951	3.2007
Avg	4.6542	4.7504	4.8269	4.6073	4.5620	4.8161	4.8028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213035 / 22/11KV MERIGOLD SUBSTATION

Feeder No / Name : 201 / 11KV VENTURA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5228	.5975	.5975	.4854	.6602	.5415
2	.6161	.5601	.4668	.4668	.4481	.5975	.4854
3	.5415	.4668	.5228	.4854	.4294	.5601	.4108
4	.5601	.4481	.5228	.5228	.4108	.4854	.4108
5	.5415	.4294	.3734	.3921	.4481	.4294	.4294
6	.5415	.4481	.3921	.4294	.4668	.4338	.4108
7	.4668	.4108	.4854	.4294	.4294	.4668	.5041
8	.6348	.6535	.5041	.3921	.8029	.6908	.5975
9	.7655	.7282	.4668	.4854	.7468	.7842	.8589
10	.8215	.8402	.4338	.4904	.6979	.7842	.8402
11	.6908	.7842	.5415	.5093	.7922	.8029	.7842
12	.8775	.8962	.6535	.6036	1.0185	.8029	.8029
13	.9709	.7341	.7842	.7167	.8488	.8402	.9709
14	.9522	.8215	.8775	.6602	.9619	.8589	.9242
15	.8775	.9709	.8775	.7356	.6602	.9709	.9242
16	.9997	.9808	.8962	.7095	.8775	.8402	.8589
17	.9054	.9997	.7842	.7468	.9335	.8589	.9709
18	.9054	1.0185	.7282	.7655	.8029	.8775	.9896
19	.8865	.9808	.8029	.6908	.8775	.8962	.9709
20	.8865	.811	.6722	.6161	.8589	.8589	.8215
21	.8299	.7545	.7282	.6535	.8589	.8589	.8402
22	.6722	.6908	.5601	.5975	.7655	.8471	.9149
23	.6722	.6535	.5975	.5601	.7468	.7842	.8402
24	.6535	.5228	.5601	.5228	.6348	.7655	.6348
Max	.9997	1.0185	.8962	.7655	1.0185	.9709	.9896
Min	.4668	.4108	.3734	.3921	.4108	.4294	.4108
Avg	.7445	.7136	.6179	.5741	.7085	.7398	.7391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213035 / 22/11KV MERIGOLD SUBSTATION

Feeder No / Name : 203 / 11KV PTC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7049	.7049	.7049	.6287	.6287	.6535	.6668
2	.7049	.7049	.6859	.6097	.6097	.6287	.6287
3	.7049	.7049	.6859	.6287	.5906	.6287	.6161
4	.6478	.6668	.6097	.6097	.6097	.6161	.6161
5	.6478	.6668	.6287	.6287	.6097	.6287	.6478
6	.6097	.6478	.5906	.6097	.6287	.6478	.6478
7	.6859	.6478	.6287	.6097	.6478	.6859	.6668
8	.7621	.743	.6478	.6478	.7621	.8002	.7621
9	1.0288	1.2003	.743	.724	1.1622	1.1241	1.1812
10	1.3146	1.3146	.8383	.6979	1.358	1.2384	1.3527
11	1.467	1.3717	.8764	.6979	1.4335	1.4098	1.448
12	1.4861	1.448	.8589	.6979	1.5278	1.467	1.467
13	1.5432	1.467	.8573	.6979	1.4523	1.4098	1.5432
14	1.4937	1.4861	.8954	.7356	1.5655	1.467	1.5278
15	1.5432	1.448	.9145	.7356	1.4712	1.5242	1.5278
16	1.4712	1.4523	.8954	.7811	1.5623	1.5623	1.6004
17	1.4901	1.3957	.8573	.7621	1.448	1.5051	1.5242
18	1.4712	1.3014	.8573	.724	1.4861	1.448	1.5432
19	1.2071	1.2071	.7621	.7049	1.4098	1.3908	1.3717
20	1.0562	1.1694	.724	.6668	1.1431	1.0669	1.1431
21	.9242	.9054	.7049	.6478	.9717	.9526	.9907
22	.8573	.8383	.6859	.6478	.8573	.8192	.8954
23	.8002	.8002	.6668	.6478	.743	.8192	.8002
24	.7811	.724	.724	.6478	.6478	.7049	.7621
Max	1.5432	1.4861	.9145	.7811	1.5655	1.5623	1.6004
Min	.6097	.6478	.5906	.6097	.5906	.6161	.6161
Avg	1.0585	1.0424	.7518	.6746	1.0553	1.0500	1.0805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213035 / 22/11KV MERIGOLD SUBSTATION

Feeder No / Name : 204 / 11 KV CYPRUS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3921	.3921	.4294	.4108		.3921
2	.3174	.3361	.3547	.3547	.3361		.3961
3	.3174	.3174	.3174	.3361	.3547		.4108
4	.3361	.3174	.3174	.3361	.3547		.4108
5	.3174	.3174	.2987	.2987	.3921		.4108
6	.3921	.3921	.3174	.3547	.4108		.4108
7	.4854	.5041	.3734	.3361	.5041	.4294	.4668
8	.5601	.5975	.4481	.4668	.5041	.5415	.5415
9	.5601	.6348	.5601	.5788	.5788	.6908	.6348
10	.6722	.6348	.6722	.4904	.5847	.6535	.6161
11	.5601	.5601	.6535	.6413	.6036	.5975	.5601
12	.5415	.5281	.5415	.6224	.5847	.5788	.5228
13	.5228	.5228	.4854	.6036	.547	.5041	.5601
14	.5041	.5093	.5041	.5093	.4904	.4854	.5281
15	.4668	.4668	.4668	.4715	.5093	.4668	.5093
16	.5281	.4715	.5041	.4854	.5228	.4481	.5415
17	.4904	.4527	.5228	.5041	.5601	.5228	.5415
18	.4904	.4854	.4668	.5415	.5041	.5228	.5228
19	.6036	.5281	.5975	.5788	.5228	.5601	.6348
20	.6036	.5601	.5788	.5601	.5788	.5601	.6535
21	.5847	.5658	.5788	.5788	.5788	.5601	.6348
22	.5415	.5601	.5601	.5601	.5601	.5601	.5415
23	.4854	.5228	.5041	.5041	.4668	.4854	.5041
24	.4108	.4481	.4854	.4481	.4481		.4481
Max	.6722	.6348	.6722	.6413	.6036	.6908	.6535
Min	.3174	.3174	.2987	.2987	.3361	.4294	.3921
Avg	.4853	.4844	.4792	.4830	.4962	.5393	.5164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213035 / 22/11KV MERIGOLD SUBSTATION

Feeder No / Name : 208 / 11KV CIPLA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2054	.2427	.2054	.1698	.168	.1886
2	.2054	.1867	.2054	.2054	.1509	.1494	.1509
3	.1867	.1867	.1867	.168	.132	.1494	.1494
4	.168	.168	.1494	.168	.1494	.1494	.1509
5	.1867	.1867	.168	.1494	.1509	.1494	.1494
6	.1867	.168	.168	.168	.1698	.1494	.1494
7	.1867	.1867	.168	.168	.1698	.1867	.1867
8	.2241	.2054	.1867	.168	.2075	.2054	.1886
9	.2987	.2987	.2054	.1867	.2829	.2987	.2987
10	.3584	.4294	.2614	.2641	.3772	.4108	.4294
11	.4854	.5093	.3361	.3018	.4715	.5041	.4294
12	.5041	.5415	.415	.3206	.5281	.5601	.5415
13	.4527	.5041	.5041	.4904	.679	.5228	.7282
14	.5601	.6908	.4294	.4715	.6224	.5601	.6224
15	.5788	.6348	.3961	.415	.5281	.5788	.6224
16	.5658	.5093	.3584	.3584	.5281	.679	.6036
17	.5658	.4904	.3961	.4481	.6036	.6036	.6036
18	.6036	.5281	.3961	.3961	.6224	.5658	.6036
19	.5658	.4904	.3772	.3772	.6224	.5658	.5847
20	.547	.4338	.3772	.3961	.5281	.547	.5658
21	.4338	.3961	.3961	.3206	.4668	.4338	.415
22	.3734	.3361	.3174		.3921	.3547	.4481
23	.2987	.2987	.2427	.2452	.3361	.2987	.3547
24	.2427	.2427	.2614	.2241	.1698	.2075	.2427
Max	.6036	.6908	.5041	.4904	.679	.679	.7282
Min	.168	.168	.1494	.1494	.132	.1494	.1494
Avg	.3736	.3678	.2977	.2877	.3774	.3749	.3920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213323 / 22/11 KV BRAMHA SUNCITY

Feeder No / Name : 201 / 11 KV BRAMHA SUNCITY I
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5415	.5228	.5228	.5601	.5228	.5041	.5228
2	.5041	.4854	.5228	.5228	.5093	.4854	.5228
3	.4854	.4854	.4854	.4854	.5093	.4854	.4854
4	.5228	.5228	.4854	.4668	.547	.5228	.5228
5	.5975	.5601	.5228	.4854	.6036	.5601	.5975
6	.7095	.6722	.5601	.5228	.6908	.6161	.7095
7	.8215	.7842	.6722	.5975	.7468	.7655	.8775
8	.9522	.9709	.7468	.7095	.8215	.8402	.8962
9	.8962	.8775	.8402	.8029	.9335	.8775	.8962
10	.9149	.8775	1.0082	.9149	.8775	.9896	.8299
11	.7468	.8029	.9709	.9335	.8402	.8589	.811
12	.7655	.7468	.8962	.9335	.7282	.8299	.7545
13	.6535	.6535	.7468	.8215	.5788	.7167	.679
14	.6161	.5788	.6722	.7282	.6161	.6602	.5847
15	.6535	.6348	.7282	.6348	.5228	.6602	.6224
16	.5975	.6602	.6535	.6535	.5601	.679	.6348
17	.6413	.5847	.6348	.6348	.6224	.7167	.6535
18	.5658	.7167	.7468	.6722	.7282	.679	.7282
19	.7733	.7922	.7842	.7842	.7922	.8299	.8029
20	.7733	.7356	2.1691	.7655	.811	.7733	.8029
21	.7922	.7733	.7545	.7468	.7922	.7733	.7842
22	.7095	.7282	.7282	.7095	.7282	.7468	.7842
23	.6535	.6908	.6908	.6908	.5415	.6722	.6908
24	.5788	.5601	.5788	.6036	.5601	.5601	.5975
Max	.9522	.9709	2.1691	.9335	.9335	.9896	.8962
Min	.4854	.4854	.4854	.4668	.5093	.4854	.4854
Avg	.6861	.6841	.7551	.6825	.6743	.7001	.6996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213323 / 22/11 KV BRAMHA SUNCITY

Feeder No / Name : 202 / 11 KV ADARSHANAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3772	.3772	.3961	.3772	.3961	.3961
2	.3772	.3584	.3584	.3584	.3584	.3772	.3772
3	.3772	.3584	.3395	.3395	.3395	.3395	.3772
4	.415	.3772	.3584	.3395	.3772	.3772	.415
5	.4904	.3961	.3772	.3584	.4338	.4527	.4527
6	.6602	.4715	.415	.3961	.5281	.5281	.5847
7	.7545	.6979	.547	.4715	.7167	.6224	.6979
8	.8676	.811	.679	.5658	.7733	.811	.8488
9	.8865	.8299	.7095	.6413	.8775	.8865	.8865
10	.7733	.8865	.679	.7356	.8299	.8962	.8316
11	.7167	.7356	.811		.7545	.8029	.7282
12	.6602	.6224	.6224	.5847	.5847	.6602	.6036
13	.6413	.6413	.5658		.5847	.6036	.5847
14	.5658	.5281	.4904	.5093	.4904	.3584	.5281
15	.5093	.547	.4904	.4338	.547	.5093	.547
16	.4854	.5093	.4251	.4338	.547	.547	.5093
17	.5658	.547	.4251	.4527	.5658	.6036	.547
18	.6036	.6602	.5729	.5658	.6036	.6224	.5847
19	.6979	.6413	.6348	.7167	.7545	.6908	.679
20	.7167	.6224	.547	.6224	.6413	.7545	.6979
21	.6413	.6036	.6036	.6224	.6224	.6602	.6602
22	.5658	.5658	.5281	.5281	.6036	.6224	.6413
23	.4715	.4904	.4527	.4904	.547	.547	.5093
24	.4338	.415	.415	.415	.3772	.4715	.4527
Max	.8865	.8865	.811	.7356	.8775	.8962	.8865
Min	.3772	.3584	.3395	.3395	.3395	.3395	.3772
Avg	.5947	.5706	.5177	.4990	.5765	.5892	.5892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213323 / 22/11 KV BRAMHA SUNCITY

Feeder No / Name : 203 / 11 KV SAINIKWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.3961	.3961	.3961	.415	.4066	.3881
2	.3696	.3772	.3772	.3584	.3772	.3696	.3696
3	.3696	.3772	.3395	.3395	.3584	.3326	.3696
4	.4066	.415	.3584	.3584	.3772	.3696	.4066
5	.4435	.4715	.3961	.3961	.4338	.4435	.462
6	.5544	.5658	.4715	.4527	.547	.499	.5359
7	.7577	.7356	.5658	.5847	.7545	.6468	.7392
8	.7947	.8865	.7167	.7167	.9054	.8686	.8316
9	.9795	.8676	.8215	.8488	.9149	.961	.924
10	.8316	.8871	.8871	.8501	.9054	.8871	.8779
11	.6838	.6838	.7577	.7392	.7545	.7842	.7762
12	.6099	.6838	.7762	.7762	.6979	.7545	.6722
13	.5175	.5729	.6468	.6468	.5847	.5658	.5415
14	.5175	.5729	.5914	.6099	.6036	.5847	.547
15	.4251	.5544	.5359	.5544	.5658	.5658	.547
16	.4854	1.1016	.5121	.5729	.5788	.5658	.5847
17	.4904	.5281	.5731	.6099	.5975	.6036	.6602
18	.5281	.6224	.6584	.6838	.6413	.6224	.6602
19	.7167	.7922	.8029	.7947	.7545	.7842	.8299
20	.7167	.7545	.811	.7392	.7167	.7356	.7922
21	.679	.6979	.6979	.7392	.6979	.7356	.811
22	.6602	.6413	.6413	.7167	.6653	.7023	.6838
23	.547	.5281	.5658	.5658	.5175	.5359	.5359
24	.4435	.4715	.4527	.4527	.4715	.4435	.4435
Max	.9795	1.1016	.8871	.8501	.9149	.961	.924
Min	.3696	.3772	.3395	.3395	.3584	.3326	.3696
Avg	.5806	.6327	.5980	.6043	.6182	.6153	.6246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213323 / 22/11 KV BRAMHA SUNCITY

Feeder No / Name : 206 / 11 KV MATE NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2197	1.1949	1.2323	1.2136	1.2136	1.2197	1.2197
2	1.1458	1.1203	1.1576	1.1576	1.1576	1.1458	1.1458
3	1.1088	1.1203	1.1203	1.1203	1.1576	1.1088	1.1458
4	1.1827	1.2136	1.1576	1.1203	1.307	1.1827	1.1827
5	1.3306	1.3676	1.307	1.1949	1.5497	1.3306	1.3306
6	1.7002	1.6632	1.4937	1.3443	1.8111	1.4784	1.7002
7	2.5873	2.4025	1.9044	1.7924	2.5688	1.9589	2.3655
8	2.8829	2.7905	2.7166	2.3339	2.809	2.6612	2.7721
9	2.7721	2.809	2.6057	2.6612	2.7166	3.0308	2.7351
10	2.3101	2.3655	2.5873	2.5873	2.4025	2.6612	
11	1.9959	2.1437	2.4025	2.4764	1.9589	2.3152	2.0119
12	1.8296	1.922	2.2177	2.2177	1.7737	1.9044	1.8298
13	1.6263	1.7002	1.9589	1.9959	1.6244	1.7924	1.643
14	1.5339	1.5893	1.7372	1.848	1.5339	1.6057	1.6057
15	1.386	1.4415	1.6632	1.6632	1.5123	1.4937	1.4937
16	1.3443	1.531	1.6057	1.6263	1.5497	1.6057	1.5893
17	1.4563	1.5684	1.7177	1.7002	1.6057	1.6804	1.6632
18	1.4937	1.9044	1.7924	1.922	1.8298	1.8671	1.848
19	2.0911	2.3525	2.2405	2.4025	2.4272	2.4272	2.4394
20	2.1285	2.2779	2.3525	2.3655	2.3152	2.3899	2.5206
21	2.4646	2.5766	2.6886	2.6242	2.6886	2.8006	2.838
22	2.4025	2.5873	2.6242	2.6699	2.7351	2.7351	2.809
23	1.7556	1.885	1.9418	2.0538	1.9959	1.9959	2.0698
24	1.5154	1.4377	1.5123	1.4937	1.4563	1.4415	1.4784
Max	2.8829	2.809	2.7166	2.6699	2.809	3.0308	2.838
Min	1.1088	1.1203	1.1203	1.1203	1.1576	1.1088	1.1458
Avg	1.8027	1.8735	1.9057	1.8994	1.9042	1.9097	1.8886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213323 / 22/11 KV BRAMHA SUNCITY

Feeder No / Name : 207 / 11 KV JAWALE COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4344	.4706	.4525	.4525	.439	.439
2	.439	.3982	.4344	.4163	.4344	.439	.4024
3	.439	.3982	.3982	.3801	.4344	.439	.4024
4	.439	.4344	.4163	.3982	.4706	.4755	.439
5	.4805	.5014	.4706	.4344	.5249	.5121	.4755
6	.5487	.6089	.543	.5068	.6154	.5487	.5853
7	.8413	.8238	.6154	.6335	.788	.6154	.8413
8	.905	.8954	.7164	.7602	.8417	.905	.905
9	.9774	.9795	.9492	.9313	.9492	1.0136	.9412
10	.9231	1.0498	1.086	1.0498	.8596	.9877	.8779
11	.8145	.9412	.9774	.9412	.8059	.8779	.8413
12	.6878	.8326	.8688	.905	.7421	.7682	.695
13	.6154	.6516	.7602	.7964	.6878	.7316	.6584
14	.5973	.6154	.6878	.724	.6447	.6584	.695
15	.5973	.6878	.6878	.6878	.6154	.695	.695
16	.6219	.6219	.6584	.6516	.6173	.695	.6447
17	.5853	.6584	.695	.6878	.695	.7316	.6516
18	.5487	.695	.7316	.7602	.695	.7316	.7421
19	.8413	.8413	.8413	.9412	.9328	.8413	.8775
20	.7682	.8413	.8779	.905	.8779	.8413	.905
21	.8048	.8413	.9145	.8688	.8413	.9145	.9231
22	.7164	.7343	.7701	.7964	.7964	.7602	.7602
23	.6268	.6626	.6335	.6516	.6219	.6154	.6584
24	.5121	.5249	.543	.5068	.5068	.5121	.5121
Max	.9774	1.0498	1.086	1.0498	.9492	1.0136	.9412
Min	.439	.3982	.3982	.3801	.4344	.439	.4024
Avg	.6571	.6947	.6978	.6995	.6855	.6979	.6904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213325 / 22/11 KV KUMAR CEREBRUM

Feeder No / Name : 201 / 11 KV B II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3239	.3239	.3239	.3429	.2477	.3048
2	.3048	.3048	.3048	.3048	.3048	.1905	.3048
3	.3048	.2858	.3239	.2858	.2858	.1715	.2858
4	.2858	.3048	.3048	.3048	.3048	.1905	.3048
5	.3239	.3048	.3239	.3048	.3239	.2096	.3239
6	.3048	.3239	.3429	.3239	.3239	.2286	.3429
7	.3048	.3429	.3239	.3239	.1905	.2477	.3429
8	.3239	.3429	.3239	.3048	.381	.2477	.362
9	.3239	.362	.3239	.3239	.4191	.2667	.4001
10	.3429	.4382	.3429	.3239	.3601	.2572	.3429
11	.3239	.4191	.381	.3239	.3601	.3086	.3258
12	.3429	.381	.362	.2915	.3258	.4001	.3258
13	.3239	.4191	.381	.2915	.3258	.3086	.3258
14	.3239	.4191	.381	.2915	.3258	.3086	.3258
15	.4001	.4001	.381	.2915	.3429	.3086	.4001
16	.3429	.3258	.381	.2915	.3429	.362	.4191
17	.3258	.3429	.381	.2915	.3239	.381	.381
18	.3429	.3258	.3258	.2743	.3239	.3429	.3601
19	.3258	.3258	.3086	.3239	.3048	.3429	.3258
20	.3258	.3086	.2915	.3239	.2858	.362	.362
21	.3086	.3086	.2915	.3048	.2667	.3429	.362
22	.3429	.2743	.3429	.3239	.2667	.3239	.381
23	.3429	.2858	.3239	.3048	.2667	.3429	.3429
24	.3429	.3239	.2667	.3239	.3239	.2667	.3429
Max	.4001	.4382	.381	.3239	.4191	.4001	.4191
Min	.2858	.2743	.2667	.2743	.1905	.1715	.2858
Avg	.3282	.3414	.3349	.3074	.3176	.2900	.3456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213325 / 22/11 KV KUMAR CEREBRUM

Feeder No / Name : 202 / 11 KV SPARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-FEB-18
HR	Load (MW)
17	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213325 / 22/11 KV KUMAR CEREBRUM

Feeder No / Name : 203 / 11 KV BI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6097	.5716	.4954	.4191	.6287	.5716
2	.6097	.5716	.5335	.4191	.381	.6097	.4954
3	.5716	.5335	.4191	.381	.3429	.5716	.4191
4	.5335	.4954	.4572	.3429	.362	.5335	.4382
5	.4954	.4572	.4191	.362	.381	.4763	.4191
6	.4954	.4191	.4191	.381	.381	.4572	.4763
7		.4572	.4572	.4191	.4191	.4954	.5335
8	.8002	.7049	.5335	.4954	.4191	.5144	.6478
9	.9335	.9145	.5716	.5525	.7621	.8192	.9526
10	1.1241	1.0669	.6859	.5716	1.2174	1.0117	1.046
11	1.105	1.2193	.8573	.5906	1.2003	1.046	1.166
12	1.1241	1.2574	.8002	.5316	1.166	1.1622	1.166
13	1.1241	1.2765	.7049	.5316	1.0974	1.046	1.0631
14	1.105	1.2193	.6859	.4973	1.0802	1.0631	1.0631
15	1.2765	1.1812	.6859	.4973	.6287	1.0802	1.2384
16	1.1831	1.0631	.6478	.4973		1.1812	1.2955
17	1.046	.9431	.6478	.4801	1.0479	1.2003	1.2765
18	1.1145	.9259	.6344	.5316	1.086	1.1431	1.0802
19	.9088	.9088	.703	.5906	.9526	.9907	1.0117
20	.7888	.7888	.4973	.5716	.9717	1.0669	.8002
21	.6173	.6687	.463	.5335	.8002	.8002	.7049
22	.7049	.6344	.4382	.4572	.7621	.7811	.5716
23	.6859	.7049	.4382	.4191	.6287	.7621	.6097
24	.724	.6097	.6478	.4572	.4191	.6859	.5525
Max	1.2765	1.2765	.8573	.5906	1.2174	1.2003	1.2955
Min	.4954	.4191	.4191	.3429	.3429	.4572	.4191
Avg	.8574	.8180	.5800	.4836	.7359	.8386	.8166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213325 / 22/11 KV KUMAR CEREBRUM

Feeder No / Name : 204 / 11 KV BIII

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.5335	.4001	.2667	.381	.4382	.381
2	.4001	.4954	.381	.2286	.3429	.4191	.3429
3	.362	.4763	.3429	.2477	.3239	.381	.3048
4	.381	.381	.3048	.2667	.3048	.4191	.2667
5	.3429	.3048	.2858	.2477	.3429	.4382	.2858
6	.4001	.3048	.2858	.2477	.3239	.4763	.2858
7	.4191	.3429	.3429	.2858	.362	.4954	.381
8	.4763	.4572	.4001	.3048	.4572	.6097	.5335
9	.4954	.7049	.4763	.3429	.743	.8002	.6859
10	.8002	.8383	.4954	.381	.8573	.7716	.7545
11	.7621	.8954	.5335	.4572	.9431	.8745	.9945
12	.8002	.9145	.5525	.4287	.8402	.9526	.8916
13	.8383	.9526	.743	.4458	1.0117	.823	.8402
14	.8192	1.0288	.6287	.4973	.9945	.9945	.8916
15	.9717	1.0479	.4763	.4801	.8916	1.0288	1.0479
16	.9259	.8916	.4572	.4801	.8764	.9907	1.0098
17	.7545	.8059	.7049	.4801	.8573	.8954	1.0479
18	.9774	.5487	.583	.4801	.8383	.8192	.8402
19	.9088	.703	.4115	.5144	.7621	.8002	.823
20	.8916	.7888	.5144	.4954	.724	.7811	.8002
21	.6687	.703	.4458	.4572	.6097	.8002	.6097
22	.6097		.4763	.4382	.5906	.6097	.5716
23	.5716	.4382	.4572	.4191	.5525	.5144	.5335
24	.4001	.5335	.4191	.381	.2858	.5144	.4382
Max	.9774	1.0479	.743	.5144	1.0117	1.0288	1.0479
Min	.3429	.3048	.2858	.2286	.2858	.381	.2667
Avg	.6399	.6561	.4633	.3864	.6340	.6936	.6484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213325 / 22/11 KV KUMAR CEREBRUM

Feeder No / Name : 205 / 11 KV KRUTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0572	.0953	.0762	.0762		.0953
2	.1143	.0762	.0762	.0762	.0953	.0762	.0762
3	.0953	.0953	.0953	.0762	.0762	.0572	.0953
4	.0953		.0572	.0953	.0762	.0762	.0762
5	.1143	.1334	.0572	.0762	.1143	.0762	.0953
6	.1143	.1334	.0572	.0762	.1334	.0953	.1334
7	.1524	.1524	.0953	.0953	.1524	.1143	.1334
8	.1905	.1524	.1143	.1143	.1524	.1524	.1524
9	.2096		.1524	.1143	.1715	.1524	.1715
10	.1715	.1524	.1524	.1334	.1372	.12	.1372
11	.1524	.1143	.1524	.1524	.1029	.1543	.1029
12	.1334	.1334	.1524	.12	.1029	.1524	.1029
13	.1143	.1143	.1524		.0857	.1372	.0857
14	.1143	.1334	.0953	.12	.0857	.12	.0857
15	.0953	.1143	.0953	.0857	.1029	.1029	.0953
16	.0686	.0857	.1334	.1029	.0953	.1334	.1143
17	.0857	.0686	.1334	.0857	.1143	.0953	.0953
18	.0857	.1029	.1029	.0857	.1143	.0953	.0857
19	.12	.1029	.12	.1334	.1334	.1143	.1029
20	.12	.1029	.1029	.1334	.1524	.1524	.1143
21	.12	.1029	.12	.1524	.1143	.1334	.1334
22	.1143	.1029	.1334	.1524	.1334	.1143	.1143
23	.1143	.1143	.1143	.1334	.1143	.0953	.1334
24	.0953	.1143	.1143	.1334	.0953	.1143	.0953
Max	.2096	.1524	.1524	.1524	.1715	.1543	.1715
Min	.0686	.0572	.0572	.0762	.0762	.0572	.0762
Avg	.1203	.1118	.1115	.1098	.1138	.1146	.1095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213325 / 22/11 KV KUMAR CEREBRUM

Feeder No / Name : 207 / 11 KV Vodafone Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.8954	.8764	.8954	.8954	.8573	.8573
2	.8764	.8954	.8573	.9145	.8383	.8383	.8383
3	.8954	.9145	.8573	.8764	.8573	.8573	.8764
4	.8954	.9145	.8383	.8383	.8764	.8383	.8573
5	.8954	.8764	.8573	.8383	.8954	.8192	.8764
6	.8954	.9145	.8383	.8383	.8764	.8573	.8764
7	.8764	.9145	.8954	.8573	.9145	.8573	.8954
8	.8954	.9526	.9145	.8764	.9335	.8573	.9145
9	.9145	.9335	.9335	.8954	.9907	.9526	.9335
10	.9145	.9145	.9526	.9335	.823	.823	.823
11	.9335	.9717	.9526	.9526	.823	.823	.8402
12	.9526	.9526	.9335	.8402	.8402	.9907	.8402
13	.9526	.9907	.9335	.8402	.8745	.823	.8402
14		.9717	.9526		.823	.823	.8745
15	.9907	.9526	.9907	.8573	.8059	.8402	1.0098
16	.8745	.8573	.9526	.8916		.9526	1.0098
17	.8573	.823	.9335	.8573	.9335	.9526	.9907
18	.823	.8573	.8402	.8402	.9526	.9335	.8402
19	.8402	.8573	.8402	.9717	.9526	.9526	.8402
20	.8573	.823	.8402	.9526	.9145	.9717	.9526
21	.8059	.8402	.8402	.9335	.9335	.9526	.9526
22	.9335	.823	.9145	.9145	.9145	.9335	.9526
23	.9335	.9335	.9335	.9145	.9145	.9145	.9335
24	.9145	.9145	.9145	.9145	.8764		.9335
Max	.9907	.9907	.9907	.9717	.9907	.9907	1.0098
Min	.8059	.823	.8383	.8383	.8059	.8192	.823
Avg	.8967	.9039	.8997	.8889	.8895	.8879	.8983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213325 / 22/11 KV KUMAR CEREBRUM

Feeder No / Name : 301 / 22 KV CYABAGE

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2667	.2286	.2286	.2667	.2286
2	.2286	.3048	.2286	.2286	.2286	.3048	.1905
3	.2286	.2667	.2667	.2286	.1905	.2667	.1905
4	.2667	.3048	.2286	.2286	.1905	.2286	.2286
5	.3048	.3048	.2286	.1905	.2286	.2667	
6	.3429	.3048	.2286	.2286	.2667	.2286	.3429
7	.381	.4572	.2667	.2286	.4572	.3048	.381
8	.6478	.724	.2667	.2667	.8383	.9145	.5335
9	.9907	1.0288	.2667	.2286	1.0669	1.105	1.0669
10	1.105	1.0669	.3048	.2286	.9602	.9945	1.0288
11	1.1431	1.2193	.3048	.2286	1.1317	1.0288	1.0974
12	1.2193	1.2574	.3048	.1715	1.0974	1.2574	1.0631
13	1.2574	1.2955	.3048	.1715	1.166	1.0974	1.166
14	1.2574	1.2574	.3048	.1715	1.0974	1.0631	1.0974
15	1.2574	1.2574	.3048	.1715	1.166	1.166	1.3717
16	1.1317	1.0631	.3429	.2401		1.3336	1.2955
17	1.1317	1.0631	.3048	.2401	1.2955	1.4098	1.4098
18	1.166	1.0631	.2058	.2401	1.2193	1.2193	1.0288
19	.9945	.9602	.2401	.2667	1.1431	1.0288	1.0631
20	.5144	.4458	.2058	.2667	.8383	.5716	.8383
21	.4801	.4115	.2058	.2286	.6859	.381	.4954
22	.381	.3086	.2667	.2286	.4954	.381	.381
23	.381	.3048	.2286	.2286	.3429	.3429	.3429
24	.2667	.3429	.2667	.2286	.2286	.381	.2667
Max	1.2574	1.2955	.3429	.2667	1.2955	1.4098	1.4098
Min	.2286	.2667	.2058	.1715	.1905	.2286	.1905
Avg	.7227	.7200	.2643	.2237	.7202	.7309	.7438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213347 / 22 KV Gera switching Station

Feeder No / Name : 301 / 22 KV GANGA GERA II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1867	.1867	.1867	.1867	.1867
2	.1867	.1867	.1867	.1867	.1867	.1867	.1867
3	.1867	.1867	.1867	.1867	.1867	.1867	.1867
4	.1867	.1867	.1867	.1867	.1867	.1867	.1867
5	.1867	.1867	.1867	.1867	.1867	.1867	.1867
6	.1867	.1867	.2241	.2241	.1867	.1867	.1867
7	.1867	.1867	.2241	.2241	.2241	.1867	.2241
8	.1867	.1867	.2241	.2241	.2241	.2241	.2241
9	.1867	.1867	.2241	.2241	.2241	.2241	.2241
10	.1867	.1867	.2241	.2241	.2241	.2241	.2241
11	.1867	.1867	.2241	.2241	.2241	.2241	.2241
12	.1867	.1867	.2241	.2241	.2241	.2241	.2241
13	.1867	.1867	.2241	.2241	.2241	.2241	.2241
14	.1867	.1867	.2241	.2241	.2241	.2241	.2241
15	.1867	.1867	.2241	.2241	.2241	.2241	.2241
16	.1867	.1867	.2241	.2241	.2241	.1867	.2241
17	.1867	.1867	.2241	.2241	.2241	.1867	.2241
18	.1867	.1867	.2241	.2241	.2241	.1867	.2241
19	.2241	.1867	.2241	.2241	.2241	.1867	.2241
20	.2241	.1867	.2241	.2241	.2241	.1867	.2241
21	.2241	.1867	.1867	.1867	.2241	.1867	.2241
22	.2241	.1867	.1867	.1867	.2241	.1867	.1867
23	.2241	.1867	.1867	.1867	.1867	.1867	.1867
24	.1867	.1867	.1867	.1867	.1867	.1867	.1867
Max	.2241	.1867	.2241	.2241	.2241	.2241	.2241
Min	.1867	.1867	.1867	.1867	.1867	.1867	.1867
Avg	.1945	.1867	.2101	.2101	.2116	.1992	.2101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

NAGAR DIVISION[312]

WADGAON SHERI SUB-DN[746] BU 4746

Substation No/ Name :- 213347 / 22 KV Gera switching Station

Feeder No / Name : 303 / 22 KV Gera Trinity Tower NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1112	.1112	.1112	.1132	.1132	.1132
2	.1132	.1112	.1112	.1112	.1132	.1132	.1132
3	.1132	.1112	.1112	.1112	.1132	.1132	.1132
4	.1132	.1112	.1112	.1112	.1132	.1132	.1132
5	.1132	.1112	.1112	.1494	.1132	.1132	.1132
6	.1132	.1112	.1494	.1494	.1132	.1132	.1132
7	.1132	.1112	.1494	.1494	.1509	.1509	.1132
8	.1132	.1112	.1494	.1494	.1509	.1509	.1494
9	.1112	.1112	.1132	.1494	.1494	.1509	.1494
10	.1112	.1132	.1132	.1494	.1494	.1509	.1494
11	.1112	.1112	.1132	.1494	.1494	.1509	.1494
12	.1132	.1132	.1132	.1494	.1494	.1509	.1494
13	.1132	.1132	.1132		.1494	.1509	.1494
14	.1132	.1132	.1132	.1132	.1494	.1132	.1494
15	.1112	.1132	.1132	.1132	.1494	.1132	.1494
16	.1112	.1112	.1112	.1132	.1494	.1112	.1112
17	.1112	.1112	.1112	.2263	.1132	.1112	.1112
18	.1112	.1112	.1112	.1132	.1132	.1112	.1112
19	.1112	.1112	.1112	.1132	.1132	.1112	.1112
20	.1112	.1112	.1112	.1132	.1132	.1112	.1112
21	.1112	.1112	.1112	.1132	.1132	.1112	.1112
22	.1112	.1112	.1112	.1132	.1132	.1112	.1112
23	.1112	.1112	.1112	.1132	.1132	.1132	.1112
24	.1132	.1112	.1112	.1112	.1132	.1132	.1132
Max	.1132	.1132	.1494	.2263	.1509	.1509	.1494
Min	.1112	.1112	.1112	.1112	.1132	.1112	.1112
Avg	.1126	.1123	.1170	.1304	.1284	.1238	.1249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213319 / 22/22KV RAJIV GANDHI SW/STN

Feeder No / Name : 300 / 22KV R/G Station T/F
Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.08	.08	.08	.08	.08	.08
2	.08	.08	.08	.08	.08	.08	.08
3	.08	.08	.08	.08	.08	.08	.08
4	.08	.08	.08	.08	.08	.08	.08
5	.08	.08	.08	.08	.08	.08	.08
6	.08	.08	.08	.08	.08	.08	.08
7	.08	.08	.08	.08	.08	.08	.08
8	.08	.08	.0762	.08	.08	.08	.08
9	.08	.08	.0762	.08	.0686	.0686	.08
10	.0747	.0747	.0762	.0747	.0686	.0686	.0686
11	.0709	.0709	1.2955	.0672	.0686	.0686	.0686
12	.0672	.0672	.0686	.0672	.0686	.0686	.0686
13	.0672	.0672	.0686	.0672	.0686	.0672	.0686
14	.0672	.0672	.0686	.0672	.0686	.0686	.0686
15	.0672	.0672	.0686	.0672	.0686	.0672	1.2193
16	.0672	.0686	.0686	.0672	.0672	.0672	.0686
17	.0686	.0686	.0686	.0672	.0672	.0672	.0686
18	.0686	.0686	.08	.0686	.0672	.0672	.08
19	.08	.08	1.6004	.08	.0672	.0672	.08
20		.08	.08	1.105	.08	.0686	.08
21	.08	.08	.08	.08	.08	1.5623	.08
22	.08	.08	.08	.08	.08	.08	.08
23	.08	.08	.08	.08	.08	.08	.08
24	.08	.08	.08	.08	.08	.08	.08
Max	.08	.08	1.6004	1.105	.08	1.5623	1.2193
Min	.0672	.0672	.0686	.0672	.0672	.0672	.0686
Avg	.0756	.0758	.1907	.1183	.0745	.1357	.1241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213319 / 22/22KV RAJIV GANDHI SW/STN

Feeder No / Name : 301 / 22kv Katraj Water Works NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 22 / OUTGOING UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5601	.5601	.5601	.5601	.5975	.5601
2	.5601	.5601	.5601	.5228	.5601	.5601	.5601
3	.5601	.5601	.5228	.1494	.1494	.1494	.1494
4	.5601	1.0456	.5228	.5228	.5228	.5601	.5601
5	1.1203	1.0456	1.1949	1.0829	1.1949	1.2323	1.1949
6	.5228	1.0829	1.0829	1.0829	1.0829	1.1949	1.1949
7	.5601	1.0829	1.1203	1.0829	1.0829	1.0829	1.0456
8	.5601	1.0456	1.0829	1.0456	1.0456	1.0456	1.0456
9	.1494	1.0829	1.1203	1.0829	1.0456	1.0829	1.0829
10	.1494	1.0456	1.643	1.0456	1.0829	1.0829	1.0829
11	.1494	1.2696	1.2696	1.2696	1.307	1.307	1.2323
12	.1494	1.1949	1.2323	1.2696	1.2323	1.307	1.2696
13	.1494	1.1949	1.2323	1.1949	1.2323	1.2696	1.2323
14	.1494	1.1949	1.2323	1.1949	.6348	.1494	1.1949
15	.1494	1.1949	1.1576	1.1949	1.1949	1.2323	.6722
16	.1494	1.1949	1.1203	.5228	1.0456	.5975	1.2323
17	.1494	1.0456	1.531	1.4937	1.4937	1.4937	1.5684
18	.1494	1.0829	1.531	1.5684	1.4937	1.4937	1.5684
19	.1494	1.6804	1.5684	1.5684	1.5684	1.5684	1.6057
20	.1494	1.0456	1.5684	1.0829	1.531	1.5684	1.5684
21	.1494	1.643	1.5684	1.1949	1.531	1.531	1.531
22	.1494	1.0829	.5975	.6348	.5975	.9335	.5975
23	.1494	1.2696	.5975	1.1949	.5975	1.1576	1.1576
24	.5601	.112	.5601	.5601	.5601	.6097	.5975
Max	1.1203	1.6804	1.643	1.5684	1.5684	1.5684	1.6057
Min	.1494	.112	.5228	.1494	.1494	.1494	.1494
Avg	.3252	1.0549	1.0907	1.0051	1.0145	1.0336	1.0627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213319 / 22/22KV RAJIV GANDHI SW/STN

Feeder No / Name : 302 / 22kv Dattanagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7095	.7468	.7095	.7468	.7095	.7095
2	.6722	.6348	.7095	.6722	.7095	.6722	.6722
3	.6348	.5975	.6348	.6348	.6348	.6348	.6722
4	.7095	.6722	.7095	.7095	.6348	.6348	.7095
5	.7468	.7842	.8215	.7842	.9335	.6722	.7468
6	1.0082	1.0082	1.0082	.9335	1.1576	.8215	.8962
7	1.3443	1.2696	1.307	.8962	1.3443	1.3817	1.4937
8	1.531		1.4563	1.419	1.4937	1.643	1.6804
9	1.4563	1.643	1.6057	1.4937	1.4937	1.6804	1.5684
10	1.3443	1.4937	1.6804	1.5684	1.3817	1.2323	1.419
11	1.1203	1.2696	1.3443	1.3443	1.2696	1.0829	1.2696
12	1.0456	1.2696	1.2696	1.2696	1.2323	1.1203	1.2323
13	.9709	1.1949	1.1576	1.1949	1.0829	1.0456	1.1949
14	.8215	1.1203	1.0456	1.0456	1.0829	.9709	1.0456
15	.8962	1.1203	.9709	1.0456	1.0456	.9335	1.0456
16	.8962	1.0082	1.2323	.9709	.9709	.8962	1.0456
17	.8962	1.2323	1.0829		1.0456	1.0456	1.1203
18	1.0082	1.1576	1.2323	1.0456	1.1203	1.1949	1.1576
19	1.3443	1.531	1.4937	1.3817	1.5684	1.4937	1.531
20	1.3443	1.419	1.4937	1.307	1.4563	1.4937	1.4937
21	1.307	1.307	1.2696	1.1949	1.3817	1.3443	1.3817
22	1.1203	1.1203	1.0829	1.1576	1.1203	1.1576	1.1203
23	.9709	1.0082	1.0082	.9709	.9709	1.0082	1.0082
24	.7468	.7468	.8215	.8215	.8215	.7468	.7468
Max	1.531	1.643	1.6804	1.5684	1.5684	1.6804	1.6804
Min	.6348	.5975	.6348	.6348	.6348	.6348	.6722
Avg	1.0269	1.1008	1.1327	1.0683	1.1125	1.0674	1.1234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213319 / 22/22KV RAJIV GANDHI SW/STN

Feeder No / Name : 303 / 22kv Bhilarewadi

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5393	1.8671	1.643	1.1949	1.1949	1.6804	1.5684
2	2.4646	1.7924	.9709	1.2696	1.1203	1.6057	1.4937
3	2.3899	1.8298	1.1949	1.3817	1.0456	1.4937	1.4563
4	2.2405	1.9044	1.2323	1.2696	.9709	1.419	1.419
5	2.2779	1.9791	1.2696	1.307	1.307	1.307	1.4563
6	2.4646	2.3152	1.307	1.3443	1.4937	1.3817	1.531
7	3.1741	3.0247	1.6804	1.4937	1.7177	1.6804	2.0911
8	3.5101	3.5475	1.9791	1.9418		2.0165	2.0538
9	3.3981	4.481	2.3525	1.9418	2.8006	2.8006	2.2779
10	3.4355	4.257	2.2779	1.8671	2.726	2.6886	2.2405
11	3.2114	4.5557	2.6139	1.7177	2.8006	2.6886	2.6139
12	2.7633	4.1076	2.3899	1.643	2.5393	3.1367	2.1285
13	2.5393	1.2696	2.4272	1.3443	2.1658	1.8298	2.726
14	2.2405	1.5684	2.1658	1.2696	1.8671	1.7177	2.5393
15	2.3152	2.3899	2.6139	1.3443	2.4272	1.2323	2.7633
16	2.3899	2.5766	2.9127	1.3443	2.1658		2.5393
17	2.6139	2.3899	3.0247	1.3443	2.3899	2.2405	2.7633
18	2.8006	2.838	2.9874	1.419	2.838	2.0165	2.6513
19	2.7633	1.9418	2.7633	1.6804	2.5393	2.0165	2.6513
20	2.3899	1.6804	1.9791	1.7177	1.8671	1.8298	1.9418
21	2.3899	1.5684	1.7924	1.6804	1.643	1.7177	1.9791
22	2.5019	1.7924	1.9418	1.6057	1.8671	1.9791	2.0911
23	1.9418	1.9044	1.8671	1.4563	1.9418	1.9418	1.9044
24	2.6139	2.0165	1.7924	1.7177	1.2696	1.7551	1.643
Max	3.5101	4.5557	3.0247	1.9418	2.838	3.1367	2.7633
Min	1.9418	1.2696	.9709	1.1949	.9709	1.2323	1.419
Avg	2.6404	2.4832	2.0491	1.5123	1.9434	1.9207	2.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213319 / 22/22KV RAJIV GANDHI SW/STN

Feeder No / Name : 304 / 22kv Katraj Kondwa Road SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5975	1.643	1.419	1.5684	1.419	1.419
2	.5975	.5975	1.3817	1.3817	1.419	1.307	1.3443
3	.6348	.6348	1.3817	1.3443	1.307	1.2696	1.419
4	.6348	.6722	1.531	1.419	1.3443	1.307	1.4937
5	.6722	.7095	1.7177	1.6057	1.6804	1.3817	1.5684
6	.9907	.9335	2.0165	1.8298	2.2032	1.6057	1.8671
7	1.307	1.307	2.3525	1.9791	2.3525	2.0911	2.5766
8	1.4937	1.531	2.8006	2.838	2.9874	2.8753	2.9874
9	1.2323	1.307	3.1367	2.9874	3.1367	2.9127	2.9127
10	1.1949	1.1203	3.2861	3.062	2.95	2.95	2.838
11	.8962	.9709	3.2861	3.062	2.8006	3.0247	2.8753
12	.7468	.8962	2.9874	2.838	2.7633	2.9127	2.3899
13	.6722	.7468	2.3152	2.4646	2.1658	2.1658	2.3899
14	.6722	2.0911	2.4272	2.2405	2.1285	2.3152	2.2405
15	.5975	2.2405	2.5019	2.3899	2.2779	2.3525	2.2779
16	.5975	2.2779	2.4646	2.1658	2.2405	2.1658	2.4272
17	.6722	2.4646	2.5766	2.3152	.5228	2.3899	2.5766
18	.7095	2.4646	2.6513	2.2405	.5975	2.3525	2.5393
19	1.0082	3.062	2.726	2.6886	2.7633	2.5393	2.7633
20	1.0456	2.5766	2.4272	2.5019	2.5766	2.3899	2.6139
21	1.0082	2.2405	2.2032	2.2032	2.2405	2.3152	2.3152
22	.9335	2.0165	1.9791	2.0538	1.9791	2.1285	1.9791
23	.8215	1.8671	1.8671	1.8671	1.7551	1.7924	1.7924
24	.6348	.6348	1.7177	1.6804	1.643	1.4563	1.4937
Max	1.4937	3.062	3.2861	3.062	3.1367	3.0247	2.9874
Min	.5975	.5975	1.3817	1.3443	.5228	1.2696	1.3443
Avg	.8488	1.4984	2.3074	2.1907	2.0585	2.1425	2.2125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213319 / 22/22KV RAJIV GANDHI SW/STN

Feeder No / Name : 305 / 22 KV Waghjai Feeder

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8383	.8383	.8764	.8764	.8764	.8764
2	.7621	.7621	.8002	.9145	.8383	.8383	.8383
3	.724	.9145	.8383	.9526	.8002	.8383	.9526
4	.8002	1.0669	.9526	1.0288	.9145	.9145	1.0288
5	.8764	1.1431	1.1812	1.1431	1.3336	.9526	1.105
6	1.5623	1.5242	1.3717	1.2193	1.6385	1.2193	1.448
7	2.3243	2.1338	1.7909	1.2574	1.9433	2.1338	2.1719
8	2.553	2.4006	2.4387	2.4387	2.2862	2.553	2.7816
9	2.21	2.0957	2.0576	2.4387	2.0957	2.5149	2.21
10	1.829	1.9052	1.9052	1.9052	1.9052	1.829	1.7528
11	1.448	1.5242	1.7528	1.7528	1.6385	1.4098	1.4098
12	1.1431	1.2193	1.4861	1.6004	1.0288	1.2955	1.2955
13	.9907	.9907	1.2574	1.2193	.8764	.9907	.9907
14	.9907	.9145	1.1431	.9907	.8764	.9907	.9145
15	.8383	.9145	1.0669	.9145	.8764	.9907	.9145
16	.8383	.9145	.9145	.9145	.9145	.9145	.9907
17	.8002	1.105	.9907	.9907	.9907	.9907	.9907
18	.9145	1.1812	1.0669	1.3717	1.1431	1.0669	1.4098
19	1.4098	1.7147	1.7147	1.7147	1.5242	1.6004	1.7909
20	1.448	1.4861	1.6004	1.7147	1.5242	1.5242	1.6766
21	1.3717	1.4098	1.4098	1.6385	1.448	1.4098	1.4861
22	1.2193	1.4861	1.3717	1.4098	1.3336	1.4098	1.3717
23	1.0669	1.0669	1.105	1.105	1.0669	1.1812	1.1431
24	.8764	.9145	.9145	.9526	.9145	.9145	.9145
Max	2.553	2.4006	2.4387	2.4387	2.2862	2.553	2.7816
Min	.724	.7621	.8002	.8764	.8002	.8383	.8383
Avg	1.2416	1.3178	1.3321	1.3527	1.2828	1.3066	1.3527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213365 / 22/22 kV Panchavati Sw/Stn

Feeder No / Name : 301 / 22 kV Raut Bag

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	.9808	.9808	.9054	.9054	.9526	1.1317
2	.9808	.9431	.9054	.8676	.8676	.8383	1.0562
3	.9054	.9054	.8299	.8299	.8299	.7621	.9431
4	.8299	.8676	.7545	.7922	.7922	.8383	1.3203
5	.7545	.8299	.7545	.7545	.7545	1.0288	1.6975
6	1.2071	1.1317	1.4335	1.358	1.4335	1.1431	2.0748
7	1.6221	1.9616	1.9993	1.6221	2.2257	1.6385	2.452
8	1.9993	2.452	2.3388	2.1502	2.4897	2.6292	2.452
9	2.1879	2.3011	2.2634	2.3765	2.2634	2.6292	2.2634
10	1.8861	1.8861	2.0748	2.2634	1.6975	1.8861	1.8861
11	1.6975	1.6975	1.6975	2.0748	1.3203	1.6221	1.5844
12	1.1317	1.3203	1.3203	1.6975	1.3203	1.5089	1.4335
13	1.3203	1.1317	1.3203	1.3203	1.1317	1.2826	1.2955
14	1.3203	1.1317	1.0562	.9431	1.1317	1.2449	1.2193
15	.9431	1.1317	1.1317	1.1317	1.1431		1.1812
16	.9054	1.0562	1.0562		.9526		1.0669
17	.8676	1.0185	1.1317	1.1694	.9526		1.9052
18	1.0185	1.5089	1.358	1.4335	1.3336		1.9052
19	1.8484	1.8861	1.8484	1.8861	1.6004		2.0576
20	1.8484	1.8861	1.8861	1.9616	1.9052		1.9616
21	1.8107	1.8107	1.8107	1.8484	1.9052	1.773	1.8861
22	1.5089	1.6975	1.5089	1.3203	1.7147	1.5089	1.6975
23	1.1317	1.3957	1.3203	1.2071	1.5242	1.3203	1.5089
24	1.1317	1.0185	1.0562	.9431	1.1431		1.1317
Max	2.1879	2.452	2.3388	2.3765	2.4897	2.6292	2.452
Min	.7545	.8299	.7545	.7545	.7545	.7621	.9431
Avg	1.3297	1.4146	1.4099	1.4286	1.3891	1.4475	1.6297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213365 / 22/22 kV Panchavati Sw/Stn

Feeder No / Name : 302 / 22 kV Gulab nagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.1317	.415	.3772	.415	.724	1.1317
2	1.0562	1.0562	.415	.3395	.3772	.6478	1.0562
3	1.0185	.9808	.3772	.3772	.4527	.6478	.9431
4	.9808	.9054	.415	.4527	.3395	.7621	1.1317
5	.9431	.8299	.3395		.4527	1.1431	1.6975
6	1.2826	1.2826	.5658	.4904	.5658	1.3336	1.8861
7	1.5089	1.9239	.6413	.5281	.6036	1.5623	2.0748
8	1.8107	2.0748	.679	.5658	.679	2.0195	2.0748
9	2.037	2.0748	.7545	.6413	.7545	2.0957	1.8861
10	1.8861	1.8861	.5658	.7545	.5658	1.8861	1.8861
11	1.6975	1.6975	.5658	.5658	.5658	1.773	1.6598
12	1.6975	1.6975	.5658	.5658	.5658	1.6598	1.5844
13	1.3203	1.5089	.5658	.5658	.3772	1.4335	1.6004
14	1.3203	1.5089	.4527	.5658	.3772	1.3957	1.3717
15	1.3203	1.5089	.3772	.3772	.381		1.4861
16	1.358	1.4335	.4527	.415	.4191		1.448
17	1.3203	1.3957	.4527	.4904	.4191		1.5242
18	1.3957	1.5844	.6036	.5281	.5716		1.7147
19	1.773	.679	.7167	.679	1.448		1.9052
20	1.8484	.679	.7545	.679	1.9052		1.9616
21	1.8107	.679	.679	.6413	1.7528	1.773	1.8861
22	1.6598	.5658	.5658	.7167	1.6385	1.5089	1.6975
23	1.5089	.6413	.4527	.4527	.7621	1.3203	1.5089
24	1.1317	1.2449	.4527	.415	.7621		1.1317
Max	2.037	2.0748	.7545	.7545	1.9052	2.0957	2.0748
Min	.9431	.5658	.3395	.3395	.3395	.6478	.9431
Avg	1.4492	1.2904	.5344	.5298	.7146	1.3933	1.5937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213365 / 22/22 kV Panchavati Sw/Stn

Feeder No / Name : 303 / 22 kV Balajinagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	2.2634	2.4143	2.4143	2.3011	2.0957	2.2634
2	2.1879	2.1879	2.3388	2.3388	2.2257	1.9052	2.2634
3	2.1125	2.1125	2.2634	2.2634	2.1502	1.829	2.0748
4	2.037	2.037	2.1879	2.1879	2.0748	2.0957	2.6406
5	2.0748		2.1125	2.1125	1.9993	2.2862	3.0178
6	2.2634	2.7538	2.7915	2.5652	2.3388	2.5911	3.5837
7	2.9424	3.3951	3.0933	2.7915	3.3196	2.8959	4.1495
8	3.4705	3.9986	3.6969	3.3196	3.9986	4.2295	3.9609
9	3.81	3.9232	3.9986	3.6591	3.8477	4.1914	3.9609
10	3.5837	3.7723	3.7723	3.9609	3.7723	3.8477	3.6214
11	3.2065	3.3951	3.5837		3.5837	3.6214	3.4705
12	3.0178	3.0178	3.3951		3.2065	3.3196	3.131
13	2.6406	2.8292	3.0178		2.8292	2.9424	3.0483
14	3.0178	2.8292	2.6406	1.1317	2.6406	2.8292	2.8959
15	2.6406	3.0178	2.6406	.9431	2.6673		2.9721
16	2.6406	2.7161	2.5652	2.1879	2.8959		2.8959
17	2.7161	2.7161	2.8669	3.0933	3.0483		3.0483
18	3.0178	3.5837	3.0178	3.3196	3.2769		3.6199
19	3.8477	3.9609	3.9609	3.9232	3.4294		4.0771
20	3.6214	3.8477	3.8477	3.9609	3.7723		4.1495
21	3.4705	3.6969	3.6214	3.6214	3.5437	3.4328	3.5837
22	3.1687	3.131	3.0178	3.0556	3.315	2.8292	3.3951
23	2.9047	2.7538	2.7161	2.6783	3.0483	2.6406	2.8292
24	2.3011	2.3388	2.4897	2.4897	2.2862		2.2634
Max	3.8477	3.9986	3.9986	3.9609	3.9986	4.2295	4.1495
Min	2.037	2.037	2.1125	.9431	1.9993	1.829	2.0748
Avg	2.8732	3.0556	3.0021	2.7628	2.9821	2.9166	3.2048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213365 / 22/22 kV Panchavati Sw/Stn

Feeder No / Name : 305 / 22 KV Rajiv Gandhi

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8669	2.2257	.3395	2.4143	1.6598	1.829	2.0748
2	2.7915	2.1502	.3395	2.3765	1.6598	1.7147	
3	2.7161	2.0748	.3395	2.3388	1.5089	1.6766	1.8861
4	2.6406	1.9993	.3395	2.3011	1.4335	1.9052	2.0748
5	2.5652	1.9239	.3395	2.2634	1.4712	2.0957	2.2634
6	2.8292	3.0178	.3395	2.5274	2.0748	2.2862	2.6406
7	3.0178	3.9609	.3395	2.6783	2.8669	2.5911	3.0178
8	3.3573	4.7908	.3395	2.8669	3.7723	3.1245	3.0178
9	3.5082	5.2812	.3018	2.9047	3.5837	3.7723	3.3951
10	3.0178	5.2812	.3018	2.8292	3.7723	3.7723	3.3573
11	3.2065	5.0926	.3018	2.8292	3.7723	3.7723	3.4705
12	2.8292	5.2812	.3395	1.8861	3.5837	3.6969	2.9424
13	2.6406	2.452	.3395	2.2634	3.0178	3.0178	3.2769
14	2.452	2.6406	.3395	2.2634	2.8292	1.9616	3.4294
15	2.452	3.3951	.3395	2.452	3.2388		
16	2.452	3.4705	.3395	2.6406	3.6199		
17	2.452	2.9424	.3395	2.8292	3.8104		
18	2.6406	3.7723	.3395	2.7161	3.8485		
19	2.6406	3.2065	3.7723	3.0933	3.4294		
20	2.6406	2.6406	3.2442	2.5274	2.9721		
21	2.6406	2.8669	3.0178	2.6406	2.4768	2.8669	
22	2.4143	.3395	2.6406	2.3765	2.3624	2.8292	
23	2.2634	.3395	2.4143	2.1879	2.0957	2.452	
24	2.9424	2.3011	.3395	2.452	1.9052		2.0748
Max	3.5082	5.2812	3.7723	3.0933	3.8485	3.7723	3.4705
Min	2.2634	.3395	.3018	1.8861	1.4335	1.6766	1.8861
Avg	2.7491	3.0603	.8928	2.5274	2.7819	2.6685	2.7801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213375 / 22/22/11 kV Amit Substation

Feeder No / Name : 201 / 11 kV Ambegaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.7167	.7167	.6602	.6602	.6036	.6602
2	.6036	.6979	.679	.6036	.6224	.5658	.6224
3	.5658	.679	.6602	.5658	.6036	.547	.5658
4	.6602	.7356	.6979	.5847	.679	.6036	.6413
5	.7922	.9054	.7733	.679	.7922	.6602	.8676
6	1.0751	1.1203	1.0751	.7922	1.1128	.8865	1.1203
7	1.5466	1.643	1.4563	1.1576	1.5684	1.3443	1.531
8	1.9978	1.9605	1.8861	1.6221	1.7551	1.9605	1.9044
9	1.8671	1.7737	1.8298	1.9231	1.7177	1.9044	1.7551
10	1.4003	1.5684	1.7737	1.9418	1.4003	1.7364	1.531
11	1.3256	1.4563	1.6244	1.6617	1.363	1.3817	1.4937
12	1.1763	1.307	1.419	1.363	1.1949	1.2323	1.2883
13	1.0082	1.1576	1.0829	1.2136	1.0829	.9522	1.0642
14	1.0642	1.0642	1.2136	1.0269	.9709	.9896	.9896
15	.9709	1.0456	1.0829	1.0456	1.0082	1.0456	1.0642
16	.9896	1.1016	1.1389	1.0082	.9522	1.0269	.9896
17	.9709	1.1949	1.0829	1.0082	1.0269	1.1389	1.1763
18	.9709	1.1203	1.0829	1.0829	1.1389	1.1203	1.2323
19	1.3443	1.4563	1.3817	1.3817	1.363	1.419	1.4937
20	1.3203	1.4937	1.4003	1.3443	1.4377	1.4712	1.5123
21	1.2826	1.3443	1.3256	1.251	1.251	1.307	1.363
22	1.1883	1.2323	1.1506	1.1883	1.1203	1.1763	1.2136
23	.9522	.9709	.9431		.8962	.8962	.9431
24	.7356	.7545	.7545	.6979	.6979	.6979	.7167
Max	1.9978	1.9605	1.8861	1.9418	1.7551	1.9605	1.9044
Min	.5658	.679	.6602	.5658	.6036	.547	.5658
Avg	1.1021	1.1875	1.1763	1.1219	1.1007	1.1111	1.1558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213375 / 22/22/11 kV Amit Substation

Feeder No / Name : 202 / 11 kV Astonia Royal

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.0943	.1132	.0943	.0943	.0943
2	.0754	.0943	.0943	.0943	.0943	.0943	.0754
3	.0566	.0754	.0754	.0754	.0754	.0754	
4	.0754	.0943	.0943	.0943	.0943	.0754	.1132
5	.0943	.1132	.0943	.0943	.1132	.0943	.132
6	.1307	.168	.0934	.0943	.1509	.132	.1494
7	.168	.1867	.0934	.112	.1494	.1132	.1307
8	.2614	.2427	.132	.1509	.1494	.1307	.1494
9	.2054	.168	.2054	.168	.168	.2241	.1867
10	.2054	.2054	.2054	.1867	.1867	.2054	.1867
11	.168	.1494	.1867	.2054	.1867	.168	.168
12	.168	.1307	.1867	.1494	.112	.168	.1307
13	.1307	.1307	.1494	.112	.1307	.0747	.0747
14	.1307	.0934	.0934	.0747	.0747	.0934	.0747
15	.0934	.112	.112	.0747	.112	.0747	.0747
16	.0934	.112	.112		.112	.0747	.0934
17	.0934	.112	.1307	.0747	.0934	.0934	.0934
18	.0934	.112	.0934	.0934	.0747	.0934	.112
19	.1494	.168	.168	.1494	.1494	.1494	.1494
20	.132	.1494	.1494	.112	.1307	.1509	.1494
21	.1509	.1494	.1494	.1307	.1307	.1307	.1307
22	.132	.1307	.132	.1132	.1494	.1307	.1307
23	.112	.0934	.1132	.1132	.112	.112	.1132
24	.0943	.0943	.0943	.1132	.0943	.1132	.0943
Max	.2614	.2427	.2054	.2054	.1867	.2241	.1867
Min	.0566	.0754	.0754	.0747	.0747	.0747	.0747
Avg	.1287	.1325	.1272	.1174	.1224	.1194	.1220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213375 / 22/22/11 kV Amit Substation

Feeder No / Name : 203 / 11 kV Sunbright School

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.4904	.5281	.5658	.4715	.547	.5281
2	.5281	.4715	.4904	.5281	.4527	.5658	.4904
3	.4904	.4527	.4715	.4904	.415	.5093	.4527
4	.5658	.5281	.547	.547	.4904	.5281	.4715
5	.679	.5847	.5975	.5847	.5847	.5658	.6413
6	.8299	.7095	.679	.6413	.6979	.7167	.7468
7	1.4335	.9522	1.2323	.9709	1.0562	.9242	1.1203
8	1.6057	1.4563	1.6409	1.1128	1.3817	1.5684	1.6617
9	1.6804	1.7177	1.8671	1.1763	1.8298	1.2136	1.9978
10	2.0538	2.2218	1.531	1.7177	2.2032	1.2323	2.6699
11	2.0911	1.9605	2.2032	1.1016	2.4272	1.419	1.7551
12	1.8298	2.1658	1.9978	1.475	2.5019	1.1949	1.8858
13	1.587	1.3443	1.3817	1.1763	1.419	.7842	1.0829
14	1.1949	1.1389	1.8671	.7655	1.4563	.9149	.6161
15	1.4377	1.531	1.9044	.9709	1.6244	1.0456	.5788
16	1.2323	1.363	1.9791	1.0269	2.4272	1.5497	.6535
17	1.1949	2.0351	1.9044	.9896	1.4003	.9522	1.1576
18	1.1949	1.5123	1.7924	1.0829	1.8671	1.3256	1.3443
19	.8402	.8962	.9896	1.2696	1.0829	.9709	1.4563
20	.9242	1.0082	.8775	1.0642	1.0082	1.0185	.9335
21	.8299	.8215	1.2637	.8962	1.1949	.9335	.9709
22	.6979	1.1203	1.1128	.9997	.9709	1.0829	.7842
23	.6348	.5975	.6979	.6036	.6161	.6348	.6602
24	.5847	.5093	.5658	.6036	.5093	.5975	.5658
Max	2.0911	2.2218	2.2032	1.7177	2.5019	1.5684	2.6699
Min	.4904	.4527	.4715	.4904	.415	.5093	.4527
Avg	1.1120	1.1495	1.2551	.9317	1.2537	.9498	1.0511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213375 / 22/22/11 kV Amit Substation

Feeder No / Name : 301 / 22 kV Dabhadi

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5281	.5281	.4527	.4527	.4527	.5281
2	.4527	.4527	.4527	.3772	.3772	.4527	.5281
3	.3772	.3772	.3772	.3395	.3395	.4527	.4904
4	.5281	.4904	.415	.415	.4904	.4527	.4527
5	.5658	.5658	.4904	.4904	.5658	.4904	.6036
6	.6722	.7842	.6722	.5658	.7167	.6413	.7468
7	1.0829	.9709	.9335	.7095	.9709	.9054	1.0082
8	1.419	1.3443	1.2071	1.0185	1.2323	1.2323	1.2696
9	1.1949	1.1576	1.1203	1.0829	1.0829	1.1949	1.1949
10	1.0829	1.0456	1.0456	1.1203	.9709	1.1203	.9709
11	.7842	.9335	.8962	1.0082	.8962	.9709	.8962
12	.7095	.7842	.8215	.8962	.7842	.8215	.7842
13	.6348	.7468	.6722	.7468	.6722	.6348	.7095
14	.5601	.6348	.6348	.6348	.6348	.6348	.5975
15	.5975	.1494	.5975	.5601	.5975	.5601	.6348
16	.5601	.5975	.5601	.5601	.6348	.5601	.5975
17	.5975	.5975	.6348	.5975	.6348	.5975	.5975
18	.6036	.6348	.7095	.5601	.5975	.6348	.6722
19	.8215	.8589	.7842	.8215	.8962	.8215	.8589
20	.8215	.8589	.8589	.8215	.8589	.8676	.8589
21	.8299	.8589	.7922	.8215	.8215	.8215	.8962
22	.7922	.7842	.7545	.7167	.8215	.7468	.8589
23	.6722	.6722	.679	.6413	.6722	.6348	.7167
24	.5658	.5281	.5281	.5281	.5281	.5281	.5281
Max	1.419	1.3443	1.2071	1.1203	1.2323	1.2323	1.2696
Min	.3772	.1494	.3772	.3395	.3395	.4527	.4527
Avg	.7257	.7232	.7152	.6869	.7187	.7179	.7500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213375 / 22/22/11 kV Amit Substation

Feeder No / Name : 302 / 22 kV Agam Mandir

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8484	1.9616	1.7353	2.0748	1.6975	1.6975	1.7353
2	1.8107	1.8861		1.9616	1.6598	1.7353	1.6975
3	1.7353	1.8107	1.4937	1.8861	1.5844	1.6221	1.5844
4	1.773	1.9239	1.5844	1.6975	1.7353	1.5844	1.6598
5	1.9239	2.1125	1.7924	1.7353	1.8484	1.4712	1.9239
6	2.2032	2.2779	2.0165	1.8107		1.8484	2.2032
7	2.9127	2.9874		2.1285	3.062	2.6029	3.062
8	3.6222	3.5848	.7468	3.2065	3.6969	3.5101	3.7342
9	3.4728	3.4728	.7468	3.6595	3.4728	3.5475	3.4728
10	3.2487	3.3608	3.3981	3.5101	3.2861	3.6595	3.062
11	3.0994	3.3608	3.2487	3.3608	2.7633	3.6969	3.2487
12	2.5393	2.7633	2.4646	2.8006	2.5393	2.9874	2.8006
13	2.0911	2.1658	2.2405	2.3152	1.9791	2.1658	2.2779
14	1.7924	2.0911	.5601	2.0538	.5601	2.1658	2.1285
15	.3734	2.5766	2.726	2.0165	2.5019	2.9874	2.7633
16	2.4272	2.4272	2.2032	1.9044	2.3525	2.5766	2.6139
17	.4108	2.2779	2.2405	2.0538	2.4272	2.726	2.838
18	2.4646	2.3152	2.5019	2.1658	2.5393	2.7633	2.3525
19	2.5393	.7095	2.3152	2.7633	2.6513	2.9127	2.7633
20	2.8006	2.726	2.7633	2.6886	3.2114	3.3951	3.3981
21	2.6783	2.8753	2.6886	2.6139	3.0247	2.7633	2.838
22	2.5274	2.5393	2.5652	2.3765	2.4646	2.5766	2.5393
23	2.1658	2.1285	2.5652	1.9993	2.5393	2.5019	2.452
24	2.0748	1.9616	1.773	2.1125	1.7353	1.9239	1.773
Max	3.6222	3.5848	3.3981	3.6595	3.6969	3.6969	3.7342
Min	.3734	.7095	.5601	1.6975	.5601	1.4712	1.5844
Avg	2.2723	2.4290	2.1077	2.3707	2.4058	2.5592	2.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213375 / 22/22/11 kV Amit Substation

Feeder No / Name : 303 / 22 kV Potdar School

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.5089	1.4712	1.5089	1.5089	1.3203	1.4335
2	1.2826	1.4335	1.419	1.358	1.4335	1.2071	1.358
3	1.2449	1.3203	1.307	1.2071	1.3203	1.1203	1.3203
4	1.358	1.358	1.3957	1.2826	1.4712	1.2071	1.3957
5	1.5466	1.6221	1.5684	1.4335	1.6598	1.3203	1.6598
6	1.8671	1.9044	1.7551	1.5844	1.9239	1.6221	1.8861
7	2.5766	2.6139	2.3152	1.9044	2.6513	2.3011	2.726
8	3.3608	3.3981	3.131	2.5652	3.0994	3.1741	3.2114
9	2.9874	3.062	3.0247	2.95	2.95	3.2487	2.9874
10	2.8006	2.838	3.2114	2.95	2.9127	3.1741	2.95
11	2.5766	2.8006	2.9874	2.9874	2.7633	2.838	2.7633
12		2.5019	2.6513	2.8006	2.3525	2.5019	2.4646
13	1.8671	2.2405	2.2032	2.4272	2.0911	1.9791	2.1658
14	1.6804	1.9791	2.1285	3.062	1.7833	2.0165	1.9791
15	1.8298	2.0165	2.0911	2.838	2.0911	2.0165	2.1285
16	1.7924	1.9791	1.9418	2.95	2.1285	1.9418	2.0911
17	1.7924	2.0911	2.0165	1.9418	2.1658	2.1285	2.0911
18	1.9418	2.4272	2.3152	2.2405	2.3152	2.2779	2.5393
19		2.838	2.838	2.8006	2.7633	2.7633	2.9127
20	2.7633	2.8006	2.726	2.8006	2.7633	2.7161	2.8006
21	2.6783	2.6513	2.6139	2.726	2.5766	2.5766	2.6886
22	2.3011	2.2779	2.3152	2.3765	2.2779	2.3525	2.4272
23	1.9791	1.8671	1.9616	1.9616	1.9791	1.9616	2.037
24	1.5466	1.4712	1.4712	1.5466	1.5844	1.4335	1.4712
Max	3.3608	3.3981	3.2114	3.062	3.0994	3.2487	3.2114
Min	1.2449	1.3203	1.307	1.2071	1.3203	1.1203	1.3203
Avg	2.0497	2.2084	2.2025	2.2585	2.1903	2.1333	2.2287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213375 / 22/22/11 kV Amit Substation

Feeder No / Name : 304 / 22 kV K B Developers

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1886	.1886	.1509	.1886
2	.1886	.1509	.1886	.1886	.1886	.1509	.1886
3	.1509	.1132	.1509	.1509	.1886	.1509	.1886
4	.1886	.1509	.1886	.1886	.1886	.1509	.1509
5	.1886	.1886	.1886	.1886	.1886	.1509	.1886
6	.2241	.2241	.2241	.2263	.2263	.1509	.2241
7	.2614	.2614	.2614	.2614	.2614	.1886	.2641
8	.2987	.2987	.3018	.3018	.2987	.2241	.2987
9	.2614	.2241	.2987	.2614	.2987	.2241	.2241
10	.2241	.2241	.2614	.2614	.2614	.2241	.2614
11	.2241	.1867	.2241	.2241	.2241	.1867	.2241
12	.1494	.1867	.1867	.2614	.1867	.2241	.1494
13	.1494	.1494	.1494	.2241	.1494	.1867	.1494
14	.1494	.1494	.1494	.1867	.1494	.1494	.1494
15	.1494	.1494	.1494	.1494	.1494	.1494	.1494
16	.112	.1494	.112	.112	.1494	.1494	.1494
17	.112	.112	.1494	.112	.1494	.1867	.1494
18	.1494	.1494	.1494	.1494	.1494	.2241	.1867
19	.2241	.1867	.1494	.1867	.1867	.2614	.2241
20	.1867	.1867	.1867	.1867	.2241	.2641	.2987
21	.1886	.1867	.1867	.1867	.1867	.2614	.2614
22	.1509	.1494	.1867	.1886	.1867	.2241	.2241
23	.1867	.1494	.1886	.1886	.1867	.2241	.2263
24	.2263	.1886	.1886	.1886	.1886	.1509	.2263
Max	.2987	.2987	.3018	.3018	.2987	.2641	.2987
Min	.112	.112	.112	.112	.1494	.1494	.1494
Avg	.1889	.1794	.1921	.1984	.1982	.1920	.2061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213432 / 22 KV Sai Mystique Swt. Stn

Feeder No / Name : 301 / 22 KV Sai Siddhi

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.7167	.7545	.7545	.7842	.7545	.7545
2	.7922	.679	.7167	.679	.7095	.7545	.7167
3	.8676	.6413	.679		.679		.6413
4	.9054	.679	.7545		.8962		.7922
5	.9808	.7922	.9431		1.3443		1.0185
6	1.358	1.0185	1.3203	1.0185	1.5844	1.358	1.6221
7	2.1879	1.3957	1.8484	1.5844	1.9993	1.8484	2.1502
8	2.6406	2.6783	2.5274	2.6029	2.6783	2.7915	2.6783
9	2.2257	2.3765	2.452	2.5274	2.3011	2.5652	2.3011
10	1.773	1.8861	1.8861	2.2634	1.773	2.037	1.773
11	1.4335	1.5089	1.5089	1.8861	1.3957	1.6221	1.358
12	1.1317	1.2071	1.3957	1.5844	1.1694	1.8484	1.2071
13	1.0562	1.0562	1.2449	1.3957	1.0562	1.2449	1.0562
14	.9431	.9808	1.0185	1.1694	.9808	1.0562	.9808
15	.9054	.9431	.9431	1.0562	.9431	1.0562	.9431
16	.8676	.9431	.9431	1.0562	.8676	1.0185	.9054
17	.9431	1.1317	1.094	1.094	1.0185	1.094	1.0185
18	1.0562	1.3203	1.2449	1.358	1.1317	1.2071	1.3203
19	1.5089	1.6975	1.7353	1.6975	1.6975	1.6221	1.773
20	1.5466	1.6975	1.7353	1.773	1.7353	1.773	1.8861
21	1.5466	1.6975	1.6221	1.6221	1.6598	1.6598	1.7353
22	1.4335	1.4712	1.4712	1.4712	1.4712	1.5089	1.4712
23	1.2071	1.1694	1.2449	1.1694	1.2449	1.1694	1.2826
24	.8676	.8299	.8676	.9054	.8676	.8676	.9054
Max	2.6406	2.6783	2.5274	2.6029	2.6783	2.7915	2.6783
Min	.7922	.6413	.679	.679	.679	.7545	.6413
Avg	1.2920	1.2716	1.3313	1.4604	1.3329	1.4694	1.3455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213432 / 22 KV Sai Mystique Swt. Stn

Feeder No / Name : 302 / 22 KV Jija Mata

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	.9808	1.6221	1.6221	1.643	.9431	.9431
2	1.0562	.9431	1.5466	1.4712	1.4937	.9054	.7922
3	1.1317	.8676	1.4712		1.4937		.7545
4	1.2071	.9054	1.5844		1.7924		.8299
5	1.358	1.094	1.8861		2.3152		1.2449
6	1.7353	1.358	2.452	1.9616	2.6406	1.6975	1.8861
7	2.7915	1.8107	3.131	2.9424	3.2065	2.037	2.452
8	3.131	2.9424	3.8855	4.1872	4.225	2.9424	
9	2.5652	2.6406	4.1495	3.7723	3.9232	2.9424	2.6783
10	1.9993	1.9993	3.546	3.7346	3.3573	2.452	2.037
11	1.5466	1.6221	3.1687	3.3196	2.9801	1.9993	1.6221
12	1.3203	1.4335		2.8669	2.5652	1.5844	1.5466
13	1.1694	1.3203	2.6406	2.5652	2.3765	1.3957	1.358
14	1.1694	1.2071	2.3011	2.3388	2.1502	1.2449	1.1694
15	1.094	1.1694	2.3388	2.0748	2.1125	1.2071	1.2071
16	1.0562	1.1694	2.1125	1.9239	2.1502	1.1317	1.1694
17	1.1317	1.2826	2.2257	2.0748	1.2071	1.3203	1.2826
18	1.3203	1.5466	2.4143	2.4897	1.4335	1.4335	1.4712
19	1.9239	3.4328	3.0933	3.1687	2.037	2.037	1.9993
20	1.9993	3.3573	3.1687	3.0933	1.9993	2.1125	2.1879
21	1.9239	3.131	3.1687	2.9801	1.9616	2.0748	2.0748
22	1.773	2.7915	2.7538	2.8669	1.6975	1.8484	1.8107
23	1.3957	2.3765	2.2257	2.2634	1.5089	1.3957	1.4712
24	1.1317	1.1317	1.8107	1.8107	1.8107	1.1317	1.094
Max	3.131	3.4328	4.1495	4.1872	4.225	2.9424	2.6783
Min	1.0562	.8676	1.4712	1.4712	1.2071	.9054	.7545
Avg	1.5844	1.7714	2.5520	2.6442	2.2534	1.7065	1.5253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213432 / 22 KV Sai Mystique Swt. Stn

Feeder No / Name : 303 / 22 KV Kasegaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4527	.4527	.4527	.4108	.4527	.415
2	.4527	.4527	.415	.415	.3734	.415	.5658
3	.3772	.415	.3772		.3361		.3772
4	.415	.3772	.4527		.4108		.4904
5	.4904	.4904	.5281		.5228		.4527
6	.5144	.6413	.679	.4904	.6036	.5281	.5658
7	.8676	.8299	.7167	.5658	.7545	.6036	.7167
8	1.0562	.9808	.7922	.8676	.8676	.8299	
9	1.0185	.9431	.7922	.7922	.8676	.9054	.9054
10		.9431	.8676	.9431	.7922	.9431	1.0185
11		.9054	.8299	.8676	.7922	.9431	.8676
12		.7545	.7922	.8299	.7167	.8299	.7922
13		.679	.7167	.7545	.6036	.6413	.679
14		.6036	.6413	.679	.6036	.5658	.6413
15		.6036		.5658	.6036	.6036	.6036
16		.6413	.6036	.6036	.6036	.6413	.6036
17	.8676	.6413	.6413	.6036	.5658	.6413	.6413
18	.8299	.7167	.7167	.679	.6413	.6036	.7167
19	.9808	.8676	.8676	.8299	.8676	.8299	.9054
20	.9054	.7922	.7922	.7167	.7922	.7922	.8299
21	.8676	.7545	.7545	.7167	.7545	.7545	.7922
22	.7167	.679	.679	.7545	.679	.7167	.7167
23	.6036	.5658	.6036	.5658	.6036	.5281	.6036
24	.5281	.4904	.4904	.4904	.4527	.4904	.4904
Max	1.0562	.9808	.8676	.9431	.8676	.9431	1.0185
Min	.3772	.3772	.3772	.415	.3361	.415	.3772
Avg	.7048	.6759	.6610	.6754	.6341	.6790	.6692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

DHANKAWADI SUB-DN.[637] BU 4637

Substation No/ Name :- 213462 / 22/22 KV Akruti Swt. Stn.

Feeder No / Name : 301 / 22 KV ISCCON Temple

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	09-FEB-18	11-FEB-18
HR	Load (MW)	Load (MW)
10	2.5652	
11	2.3765	2.8292
12	2.1502	
13	1.8484	
Max	2.5652	2.8292
Min	1.8484	2.8292
Avg	2.2351	2.8292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

FIRE BRIGADE SUB-DN.[607] BU 4607

Substation No/ Name :- 213316 / 22/11 KV HYDE PARK

Feeder No / Name : 201 / 11 KV SHOPPING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0943	.132	.1132	.0943	.112	.112
2	.0943	.0943	.1132	.0943	.0943	.0934	.0943
3	.0943	.0943	.0943	.0943	.0754	.0934	.0943
4	.0943	.0943	.0943	.0943	.0754	.0934	.0934
5	.1132	.1132	.0943	.0943	.0943	.112	.112
6	.1509	.132	.132	.1132	.112	.1494	.1494
7	.1509	.1509	.132	.1132	.1494	.1494	.1494
8	.1886	.2075	.1698	.1509	.168	.1494	.168
9	.2263	.2075	.1886	.168	.1867	.1867	.2054
10	.2427	.2054	.2054	.2075	.1867	.2241	.2427
11	.1867	.2054	.2427	.1867	.2054	.2075	.1867
12	.1867	.1867	.2241	.168	.168	.2054	.2054
13	.1867	.1867	.2054	.1307	.1867	.168	.168
14	.168	.1494	.168	.1307	.168	.168	.168
15	.1867	.168	.1867	.112	.1867	.168	.1494
16	.1867	.168	.1886	.1307	.1867	.168	.1509
17	.1867	.1829	.1698	.112	.168	.1867	.1698
18	.168	.1646	.1698	.1307	.1867	.1867	.1886
19	.2054	.1867	.2075	.1494	.1867	.1867	.2075
20	.2054	.1867	.1698	.1494	.1867	.1867	.1886
21	.2054	.168	.1886	.1494	.168	.1867	.168
22	.1509	.1698	.1698	.1307	.168	.1494	.1867
23	.1132	.132	.132		.1307	.1307	.1307
24	.132	.1132	.132	.132	.112	.112	.1307
Max	.2427	.2075	.2427	.2075	.2054	.2241	.2427
Min	.0943	.0943	.0943	.0943	.0754	.0934	.0934
Avg	.1641	.1567	.1629	.1329	.1519	.1572	.1592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

FIRE BRIGADE SUB-DN.[607] BU 4607

Substation No/ Name :- 213316 / 22/11 KV HYDE PARK

Feeder No / Name : 202 / 11 KV CLUB HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0189	.0373	.0373
2	.0189	.0189	.0189	.0189	.0189	.0189	.0189
3	.0189	.0189	.0189	.0189	.0189	.0189	.0187
4	.0189	.0189	.0189	.0189	.0189	.0189	.0187
5	.0377	.0377	.0189	.0377	.0189	.0189	.0189
6	.0377	.0377	.0377	.0377	.0373	.0373	.0189
7	.0377	.0189	.0189	.0189	.0187	.0187	.0373
8	.0377	.0377	.0377	.0373	.0373	.0373	.0373
9	.0377	.0566	.0566	.0373	.0373	.0373	.0373
10	.0373	.056	.0373	.0377	.056	.0373	.0373
11	.0747	.0373	.056	.0377	.0373	.0373	.0373
12	.0373	.0373	.0373	.0373	.0373	.0373	.0373
13	.056	.0187	.0187	.0187	.0187	.0373	.0187
14	.056	.0187	.0373	.0187	.0373	.056	.0187
15		.0373	.0373	.0373	.0373	.0373	.0373
16	.056	.0187	.0377	.0373	.056	.0373	.0377
17	.056	.0183	.0566	.0373	.0373	.056	.0377
18	.0373	.0549	.0754	.0373	.0373	.0373	.0377
19	.112	.0747	.0754	.056	.056	.0747	.0943
20	.0747	.0747	.0754	.0747	.0934	.0747	.0754
21	.0747	.0747	.0943	.0747	.0747	.0747	.056
22	.0377	.0377	.0377	.0373	.0373	.0373	.0373
23	.0377	.0377	.0377	.0373	.0373	.0373	.0373
24	.0377	.0377	.0377	.0377	.0373	.0373	.0373
Max	.112	.0747	.0943	.0747	.0934	.0747	.0943
Min	.0189	.0183	.0187	.0187	.0187	.0187	.0187
Avg	.0464	.0382	.0423	.0367	.0382	.0397	.0367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

FIRE BRIGADE SUB-DN.[607] BU 4607

Substation No/ Name :- 213316 / 22/11 KV HYDE PARK

Feeder No / Name : 203 / 11 KV SAFALYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3547	.3361	.3734	.3772	.3174	.3547
2	.3361	.3361	.3174	.3547	.3395	.3206	.3584
3	.3174	.2987	.2987	.3174	.3018	.3018	.3395
4	.3547	.3174	.3174	.3174	.3018	.3174	.3395
5	.3921	.4294	.3547	.3361	.3395	.3395	.3772
6	.6722	.6722	.4668	.4294	.3961	.4108	.4904
7	.8215	.6908	.5788	.5228	.8589	.6908	.811
8	.9709	.9335	.7842	.7095	.9335	.4108	.8962
9	.9522	.8402	1.0456	.9149	.9149	.9522	.8962
10	.8775	.8589	.9522	.9896	.8299	.9709	.8402
11	.6535	.6535	.8029	.8299	.7095	.8402	.6722
12	.6161	.6161	.6908	.6535	.5788	.5975	.5788
13	.5041	.5788	.5601	.6348	.5228	.4854	.5041
14	.4108	.4668	.5228	.5041	.4668	.4854	1.5684
15		.4108	.4108	.4294	.4294	.4668	.3921
16	.3734	.3921	.4294	.4108	.3921	.4108	.3921
17	.4294	.4024	.4668	.4481	.4481	.5041	.4294
18	.4481	.4755	.5228	.4854	.4668	.4668	.4854
19	.6348	.6535	.6535	.6348	.6535	.6722	.6602
20	.6348	.6535	.6535	.6348	.6535	.7282	.6535
21	.6535	.6161	.6161	.6161	.6348	.6348	.6348
22	.5975	.5788	.6161	.5601	.6161	.6348	.6161
23	.5041	.5041	.5228	.5041	.4854	.5041	.4854
24		.3921	.4108	.4108	.3921	.4108	.4294
Max	.9709	.9335	1.0456	.9896	.9335	.9709	1.5684
Min	.3174	.2987	.2987	.3174	.3018	.3018	.3395
Avg	.5695	.5469	.5555	.5426	.5435	.5364	.5919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

FIRE BRIGADE SUB-DN.[607] BU 4607

Substation No/ Name :- 213316 / 22/11 KV HYDE PARK

Feeder No / Name : 204 / 11 KV BLACK POOL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.924	.924	.924	.9431	.8589	.8775
2	.8316	.8686	.8686	.8501		.8215	.8676
3	.7947	.7947	.7947	.7947	.7545	.7922	.8299
4	.8131	.8316	.8131	.8131	.8299	.7842	.8299
5	1.0164	.924	.9055	.8316	.8676	.8299	.9054
6	1.4045	1.2012	1.0349	1.0164	.9896		1.1694
7	1.7002	1.7741	1.2567	1.2012	1.643		1.6244
8	1.9404	1.9774	1.7741	1.5893	1.8484		1.9418
9	2.0883	2.0513	1.9774	1.8671	2.0351	1.9978	2.0538
10	2.2032	1.8671	2.0538	1.9605	2.1502	2.1285	2.1098
11	2.0538	2.0538	1.9605	1.9978	2.0936	2.2218	2.1658
12	1.9605	1.8111	1.8111	1.9044	1.7924	1.9978	1.8858
13	1.6991	1.7551	1.587	1.5684	1.5497	1.6991	1.6804
14	1.6057	1.419	1.5123	1.3443	1.6244	1.5497	1.5684
15		1.363	1.2696		1.5123	1.4937	1.4563
16	1.4003	1.363	1.2197	1.1203	1.419	1.363	1.4784
17	1.4377	1.3717	1.2752	1.2696	1.5497	1.419	1.5154
18	1.6244	1.6278	1.4784	1.3817	1.6244	1.6057	1.7002
19	1.9231	1.9231	1.6817	1.5684	1.8858	1.8671	1.8665
20	1.6804	1.7177	1.6632	1.5123	1.6617	1.6244	1.6632
21	1.643	1.531	1.4415	1.4563	1.531	1.587	1.5684
22	1.4563	1.4415	1.3676	1.363	1.1763	1.4563	1.4003
23	1.2197	1.2012	1.1827	1.1949	1.1763	1.2323	1.1763
24	.9979	.9979	1.0164	.9979	.9896	.9522	.9335
Max	2.2032	2.0538	2.0538	1.9978	2.1502	2.2218	2.1658
Min	.7947	.7947	.7947	.7947	.7545	.7842	.8299
Avg	1.4964	1.4496	1.3696	1.3273	1.4629	1.4420	1.4695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

FIRE BRIGADE SUB-DN.[607] BU 4607

Substation No/ Name :- 213316 / 22/11 KV HYDE PARK

Feeder No / Name : 300 / Station Transformer

Feeder KV- 22 / OUTGOING

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0189			
10			.0747	.0754	.0754
24	.0377	.0377			
Max	.0377	.0377	.0747	.0754	.0754
Min	.0377	.0189	.0747	.0754	.0754
Avg	.0377	.0283	.0747	.0754	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213011 / 22/11 KV PADMAAVTI

Feeder No / Name : 201 / 11 KV MAHALAXMI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.6161	.6161	.5788	.5601	.6348	.6348
2	.5975	.5975	.5975	.5601	.4694	.5975	.5975
3	.5975	.5975	.5788	.5415	.5228	.5601	.5601
4	.6535	.6535	.5788	.5601	.5228	.5601	.5601
5	.6722	.6722	.5975	.5788	.5601	.6348	.6348
6	.6908	.7468	.5975	.5975	.6722	.6371	.6908
7	.7842	.8215	.6535	.6348	.7842	.7282	.7655
8	.9709	1.0269	.8402	.7842	.8775	.9896	.9335
9	1.1506	1.1016	1.094	.9335	1.0829	1.0829	1.0829
10	1.2696	1.2696	1.1576	1.0829		1.3256	1.2323
11	1.2323	1.3443	1.1203	1.1389	1.2883	1.2883	1.251
12	1.2136	1.2696	1.0829	1.1203	1.2696	1.2696	1.2696
13	1.1389	1.1763	1.1203	1.0456	1.1949	1.1763	1.251
14	1.1203	1.2136	1.0269	1.0269	1.1949	1.1763	1.2323
15	1.1763	1.2883	1.1203	.9896	1.1576	1.2071	1.2136
16	1.1016	1.1949	1.0829	.9709	1.1389	1.1949	1.3256
17	1.1389	1.1949	1.0829	.9149	1.1576	1.1949	1.1949
18	1.2136	1.0829	1.1016	.8775	1.2136	1.1576	1.1203
19	1.1949	1.1949	1.1576	1.0269	1.2136	1.2136	1.2323
20	1.1763	1.1949	1.0829	.9896	1.2136	1.1389	1.2323
21	1.1016		1.0082	.9335	1.1203	1.1203	1.1128
22	.9522		.8299	.811	.9335	.8775	.9522
23	.7842		.7468	.7095	.7655	.7655	.7468
24	.6348	.6348		.5975	.5788	.6908	.6535
Max	1.2696	1.3443	1.1576	1.1389	1.2883	1.3256	1.3256
Min	.5975	.5975	.5788	.5415	.4694	.5601	.5601
Avg	.9659	.9949	.9076	.8335	.9345	.9676	.9784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213011 / 22/11 KV PADMAAVTI

Feeder No / Name : 203 / 11 KV SAIBABA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.056	.056	.056	.056	.056
2	.0532	.056	.056	.056	.056	.056	.056
3	.056	.056	.056	.056	.056	.056	.056
4	.056	.056	.056	.056	.056	.056	.056
5	.056	.0747	.056	.056	.0747	.0747	.0747
6	.0747	.0747	.0747	.056	.0934	.0747	.0747
7	.0934	.0747	.0747	.0747	.0934	.0747	.0934
8	.112	.0747	.0934	.0747	.0747	.112	.112
9	.1307	.0934	.112	.0934	.1494	.112	.1307
10	.112	.1307	.1307	.0747		.112	.112
11	.168	.1494	.168	.0747	.1307	.112	.168
12	.168	.168	.168	.0934	.2054	.112	.2054
13	.168	.168	.1307	.0747	.1494	.1097	.1867
14	.1494	.1307	.112	.0934		.112	.1307
15	.1494	.1307	.0934	.0747	.1307	.112	.1494
16	.1307	.1307	.0747	.056	.132	.112	.168
17	.112	.1494	.0747	.056	.1307	.0934	.1494
18	.112	.1494	.0934	.056	.112	.112	.1494
19	.112	.0934	.0934	.0747	.112	.112	.1307
20	.0934	.0934	.0747	.056	.0934	.0934	.112
21	.0747		.056	.056	.0747	.0747	.0934
22	.056		.0747	.0747	.0747	.0934	.0934
23	.056		.0747	.056	.056	.0747	.0747
24	.056	.056		.0747	.056	.056	.056
Max	.168	.168	.168	.0934	.2054	.112	.2054
Min	.0532	.056	.056	.056	.056	.056	.056
Avg	.1002	.1031	.0893	.0677	.0985	.0901	.1120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213011 / 22/11 KV PADMAAVTI

Feeder No / Name : 204 / 11 KV SOBA SAVERA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0747	.0747	.0671	.0934	.0934
2	.0934	.0747	.0747	.0747	.0747	.0747	.0747
3	.0934	.0747	.0747	.0747	.0747	.0747	.0747
4	.0934	.0934	.0747	.0747	.0747	.0747	.0747
5	.0934	.0934	.0747	.0747	.0934	.0747	.0747
6	.0934	.0934	.0747	.0747	.0934	.0934	.0747
7	.0747	.0934	.0747	.0747	.112	.0747	.0934
8	.112	.112	.112	.0934	.1006	.112	.1307
9	.112	.0934	.112	.0934	.1307	.0934	.112
10	.1307	.112	.112	.112		.112	.0934
11	.112	.112	.1494	.0934	.1307	.112	.112
12	.112	.112	.112	.112	.112		.112
13	.1307	.1307	.112	.112	.1006	.112	.112
14	.0934	.1307	.0934	.0747	.112	.112	.1307
15	.0934	.0934	.0934	.0934	.0747	.0934	.0934
16	.112	.0747	.0747	.0943	.0747	.0747	.0934
17	.1307	.112	.0934	.112	.112	.0934	.0934
18	.0934	.112	.112	.112	.0934	.112	.112
19	.112	.1494	.112	.112	.1307	.1307	.1307
20	.112	.1132	.112	.112	.1307	.112	.112
21	.1307		.112	.1307	.1307	.0934	.112
22	.112		.1132	.1132	.112	.1307	.112
23	.0934		.0934	.1132	.0934	.0934	.0934
24	.0934	.0934		.0747	.0671	.0934	.0934
Max	.1307	.1494	.1494	.1307	.1307	.1307	.1307
Min	.0747	.0747	.0747	.0747	.0671	.0747	.0747
Avg	.1050	.1032	.0975	.0951	.0998	.0974	.1004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213011 / 22/11 KV PADMAAVTI

Feeder No / Name : 205 / 11 KV Amit

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0934	.0747	.0934	.0934	.112
2	.0934	.0934	.0934	.0747	.0934	.0747	.112
3	.0934	.0934	.0934	.0747	.0934	.0747	.0934
4	.112	.0934	.112	.0747	.0934	.0934	.0934
5	.1294	.112	.1307	.0747	.112	.112	.112
6	.1307	.1494	.1494	.0747	.1307	.112	.1494
7	.2054	.168	.1307	.112	.2054	.168	.168
8	.1867	.168	.1867	.1494	.2054	.2241	.2054
9	.2054	.2241	.2054	.168	.2054	.168	.1867
10	.2427	.2054	.2801	.2241		.2054	.1867
11	.1867	.181	.2241	.2054	.2054	.2241	.168
12	.2054	.168	.168	.168	.1509	.1509	.1867
13	.1867	.1867	.1867	.168	.168	.1494	.168
14	.1494	.168	.168	.1494	.168	.1494	.1494
15	.168	.1494	.1307	.1307	.1494	.112	.1494
16	.112	.1307	.1307	.112	.1307	.112	.1494
17	.1307		.1494	.112	.112	.1494	.1307
18	.1494	.112	.1494	.112	.112	.112	.1494
19	.168	.168	.1867	.168	.168	1.643	.168
20	.2054	.1867	.168	.168	.1867	.1867	.1867
21	.1867		.1867	.168	.1867	.1867	.1886
22	.168		.1494	.1307	.1494	.1494	.168
23	.1494		.112	.112	.112	.1307	.112
24	.0934	.0934		.0934	.0934	.0934	.1174
Max	.2427	.2241	.2801	.2241	.2054	1.643	.2054
Min	.0934	.0934	.0934	.0747	.0934	.0747	.0934
Avg	.1563	.1472	.1559	.1291	.1446	.2031	.1504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213011 / 22/11 KV PADMAAVTI

Feeder No / Name : 301 / 22 KV Chaitraban

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1658	2.1658	2.0538	2.0165	2.1658	2.2405	2.1658
2	2.1285	2.1285	2.0165	1.9791	1.8107	2.0911	2.0911
3	2.0911	2.0911	1.9791	1.9418	1.8671	1.9418	1.9418
4	2.2032	2.2032	2.2032	2.0538	2.3152	1.8778	2.0911
5	2.726	2.6139	2.4646	2.2032	2.6139	2.3152	2.6139
6	3.2114	3.4355	2.9127	2.3525	3.3234	2.5766	3.4355
7	4.0329	3.9209	3.3608	2.8753	3.8089	3.5101	3.9582
8	4.9291	4.7051	4.369	4.1823	4.7798	4.7051	4.7798
9	4.6677	4.481	4.9417	4.7798	4.5931	4.8171	4.481
10	3.9209	3.8089	3.9956	4.369		4.1823	3.6595
11	2.9874	3.3234	3.7342	3.9209	3.3234	3.5848	3.2861
12	2.6513	2.95	3.2861	3.5475	2.5484	3.062	2.8753
13	2.3899	2.726	2.95	2.8753	1.7924	2.6513	2.95
14	2.2032		2.6886	2.5393	2.2779	2.6783	2.4646
15	2.0911	2.2779	2.1658	2.3152	2.1285	2.2779	2.3525
16	2.0911	2.3525	2.2032	2.2405	2.1285	2.1658	2.2779
17	2.1658	2.5766	2.3899	2.6513	2.3152	2.3525	2.6513
18	2.5766	3.1367	3.2487	2.6886	2.8753	2.726	3.1741
19	3.5848	4.0329	4.0703	3.8089	3.7342	3.9582	4.145
20	3.7715		3.8462	3.8462	3.8836	4.0329	4.145
21	3.6969		3.7342	3.6969	3.7342	3.9956	4.0329
22	3.5475		3.4355	3.3573	3.4355	3.3981	3.5848
23	2.9127	3.0247	2.9127	2.7633	2.5149	2.95	2.9874
24	2.2032	2.2779	2.3152	2.2779	2.2405	2.3152	2.3152
Max	4.9291	4.7051	4.9417	4.7798	4.7798	4.8171	4.7798
Min	2.0911	2.0911	1.9791	1.9418	1.7924	1.8778	1.9418
Avg	2.9562	3.0116	3.0532	2.9701	2.8787	3.0169	3.1025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213011 / 22/11 KV PADMAAVTI

Feeder No / Name : 302 / 22 KV Vasantbaug

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0538		1.7924	1.8671	1.8671	1.8671
2	2.0165	2.0165		1.7551	1.7924	1.7177	1.6804
3	1.9791	1.9791		1.7177	1.5089	1.5684	1.531
4	2.3899	2.0911		1.8671	2.0165	1.643	1.8298
5	2.6513	2.3525		1.9044	2.3899	1.8671	2.2405
6	2.838	3.0994		2.0165	2.6886	2.1658	2.726
7	3.4355	3.2487		2.4646	3.2487	2.8753	3.2114
8	4.1076	4.0703		3.3196	3.8836	3.7342	4.1823
9	4.145	4.0703		3.7715	4.0329	4.3317	4.0703
10	3.8089	3.7342		3.8089		3.0247	3.8836
11	2.5766	3.5475		3.4355	3.0247	3.8462	3.2861
12	2.1285	3.2861		3.1741	3.2487	3.2819	3.2114
13	2.838	3.1367		2.6886	2.8006	2.8753	2.8006
14	2.5766	2.726		2.3899	2.5766	2.5393	2.6513
15	2.5766	2.6139		2.2032	2.6513	2.3765	2.8006
16	2.4646	2.5393		2.2405	2.2779	2.3899	2.6886
17	2.726	2.6513		2.2405	2.4272	2.3525	2.9127
18	2.9874	3.1741		2.5393	3.0247	3.062	3.0994
19	3.6222	3.6969	3.7342	3.3234	3.6222	3.6969	3.6595
20	3.3234		3.5101	3.3234	3.5475	3.3608	3.5475
21	3.1367		3.2487	3.2861		3.2114	3.3234
22	2.8753	3.2861	2.9424	2.95	2.9127	2.8753	3.062
23	2.4646		2.5766	2.5766	2.5393	2.6139	2.6513
24	2.0538	1.9791		2.0911	1.9791	1.9791	1.8107
Max	4.145	4.0703	3.7342	3.8089	4.0329	4.3317	4.1823
Min	1.9791	1.9791	2.5766	1.7177	1.5089	1.5684	1.531
Avg	2.8575	2.9216	3.2024	2.62	2.7301	2.719	2.8636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213011 / 22/11 KV PADMAAVTI

Feeder No / Name : 303 / Water Pumping
Feeder KV- 22 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9418	1.9418	1.8298	1.9418	1.7551	1.7551	1.7551
2	1.9418	1.9418	1.9418	1.9418	1.8671	1.8671	1.8671
3	1.9418	1.9418	1.9418	1.9418	1.9418	1.9418	1.8671
4	1.9418	1.9418	1.9418	1.9418	1.9418	1.9418	1.9418
5	2.0165	2.0165	1.9418	1.9418	1.8107	2.0165	2.0165
6	2.0911	2.0538	1.9418	2.0538	2.0538	2.0538	2.0911
7	2.0538	2.0911	1.9791	2.0911	2.1285	2.0911	2.1285
8	2.0911	2.0911	1.9418	1.9909	2.0538	2.0538	2.0538
9	.7842	2.0538	1.9044	2.2032	1.9791	2.2405	2.0538
10	.7842	1.8298	1.7177	2.2032		2.2032	1.8298
11		1.643	1.6804	1.8671	1.8671	1.8298	1.8298
12		1.7924	1.6804	1.8298	1.8298	1.7924	1.8298
13		1.7924	1.643	1.7924	1.7924	1.7924	1.7924
14		1.7924	1.643	1.7551	1.7924	1.7551	1.7551
15		1.7924	1.6804	1.7551	1.8107	1.7551	1.7924
16	.2614	1.7924	1.643	1.7551	2.1285	1.7924	1.7924
17	.2614	2.0911	1.9791	2.0911	2.1285	2.0911	2.1658
18	.2614	1.1203	1.8671	1.7551	2.1285	2.2032	1.8298
19	.2614	1.531	1.531	1.4937	1.4937	1.531	1.4937
20	.2614		1.4563	1.419	1.419	1.4563	1.419
21	2.0165		1.7924	1.419	1.4563	1.419	1.419
22	2.0538	1.643	1.8298	1.8107	1.7551	1.7551	1.7924
23	1.5684	1.6804	1.3817	1.7551	1.3817	1.3443	1.3817
24	1.3443	1.531	1.8671	1.531	1.3443	1.531	1.531
Max	2.0911	2.0911	1.9791	2.2032	2.1285	2.2405	2.1658
Min	.2614	1.1203	1.3817	1.419	1.3443	1.3443	1.3817
Avg	1.3620	1.8230	1.7815	1.8450	1.8200	1.8422	1.8095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213011 / 22/11 KV PADMAAVTI

Feeder No / Name : 304 / 22 KV Sahakarnagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.5684	1.3443	1.3817	1.419	1.4937	1.4937
2	1.5684	1.531	1.307	1.3443	1.307	1.3443	1.2696
3	1.531	1.4937	1.2696	1.307	1.4937	1.1949	1.073
4	1.7177	1.643	1.4563	1.419	1.6598	1.2696	1.3443
5	1.8298	1.7924	1.7177	1.4563	1.8671	1.4937	1.6804
6	2.0165	2.1658	1.9418	1.5684	2.0165	1.7551	2.0911
7	2.8006	2.5393	2.3899	2.0165	2.5766	2.2779	2.5766
8	2.95	2.9127	2.7633	2.5393	2.8753	2.838	3.0247
9	3.2114	2.95	3.062	2.9127	3.2487	3.1367	3.062
10	2.8753	2.9127	3.062	2.95		2.95	2.9127
11	2.5766	2.6886	2.9127	2.7633	2.6886	2.7351	2.6886
12	2.2405	2.4272	2.6886	2.5766	2.4272	2.5019	2.3525
13	2.0165	2.3152	2.3525	2.3152	2.2032	2.2405	2.2032
14	1.8671	2.2032	2.0165	2.0538	2.0165	1.9791	2.0165
15	1.7924	1.9418	1.8298	1.8861	1.8671	1.8107	1.9418
16	1.8298	1.9044	1.7177	1.7551	1.8298	1.7924	1.9418
17	1.8298	1.9418	1.9418	1.7551	1.9418	1.7551	2.1285
18	2.0165	2.2032		1.9418	2.0911	2.0911	2.3152
19	2.6139	2.9127	3.0247	2.6139	2.6886	2.7633	2.9127
20	2.6513		2.8753	2.5766	2.726	2.838	2.8753
21	2.4646		2.6886	2.5393	2.5393	2.6886	2.7633
22	2.2779	2.6139	2.4646	2.2779	2.3152	2.2405	2.4646
23	1.9044	2.0165	2.0165	2.2779	1.8671	1.9791	1.9418
24	1.5684	1.531	1.6057	1.6057	1.531	1.531	1.5684
Max	3.2114	2.95	3.062	2.95	3.2487	3.1367	3.062
Min	1.531	1.4937	1.2696	1.307	1.307	1.1949	1.073
Avg	2.1550	2.1913	2.1934	2.0764	2.1390	2.1125	2.1934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213011 / 22/11 KV PADMAAVTI

Feeder No / Name : 305 / 22 KV K K Market

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.4937	1.2696	1.2323	1.2696	1.419	1.4937
2	1.4563	1.419	1.2323	1.1949	1.1203	1.2696	1.3443
3	1.419	1.419	1.1949	1.1576	1.1203	1.1949	1.1401
4	1.4563	1.4563	1.4563	1.2696	1.4083	1.3443	1.4937
5	1.7177	1.6804	1.7551	1.3443	2.0165	1.5684	1.4937
6	2.0911	2.3899	1.9418	1.419	2.3152	1.7924	2.2405
7	2.6886	2.5766	2.2779	1.8671	2.5766	2.2779	2.6513
8	3.4355	3.3608	3.0556	2.5393	3.2487	3.2114	3.3981
9	3.3981	3.2114	3.1741	2.9874	3.1367	3.4728	3.1367
10	3.0994	2.838	2.9874	3.0247		3.062	2.9874
11	2.6139	2.6513	2.8753	2.8006	2.6139	2.8006	2.6139
12	2.2779	2.4272	2.5393	2.726	2.3899	2.5019	2.4272
13	2.1285	2.1285	2.2032	2.3525	2.1658	2.3152	2.2032
14	1.9044	1.9791	2.0911	2.0538	1.9791	2.0538	2.0165
15	1.9044	1.8298	1.8671	1.7924	1.7177	1.9791	1.9418
16	1.8298	1.8298	1.8298	1.6804	1.8298	1.8298	1.9791
17	1.9791	2.0165	2.0165	1.8671	1.9418	2.0911	2.0538
18	2.0538	2.2779		2.0911	2.2032	2.2405	2.3899
19	2.7633	2.9127	2.8753	2.838	2.838	2.838	2.9874
20	2.7633		2.838	2.7538	2.8753	2.838	2.9874
21	2.6886		2.6886	2.5393	2.6886	2.726	2.8753
22	2.2779	2.726	2.2405	2.2634	2.3152	2.2779	2.4272
23	1.8298	1.9418	1.8671	1.9418	2.1285	1.9418	1.9044
24	1.4937	1.5684	1.419	1.419	1.4563	1.4563	1.5684
Max	3.4355	3.3608	3.1741	3.0247	3.2487	3.4728	3.3981
Min	1.419	1.419	1.1949	1.1576	1.1203	1.1949	1.1401
Avg	2.1985	2.1879	2.1607	2.0481	2.1459	2.1876	2.2398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213439 / Shanti Nagar S/stn

Feeder No / Name : 301 / Gangadham area

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4904	.5281	.4904	.5281	.4904	.5281
2	.3772	.3772	.415	.3772	.4527	.3772	.4904
3	.3395	.3395	.3772	.3395	.3772	.3395	.3772
4	.4904	.4904	.4527	.415	.4904	.415	.5658
5	.6036	.5658	.5281	.4904	.6036	.5658	.679
6	.7922	.679	.6036	.6036	.7545	.7922	.7922
7	.9808	.9808	.9054	.8676	.9054	.9054	.9808
8	1.2449	1.3203	1.1694	1.0562	1.1317	1.094	1.1317
9	1.4712	1.5844	1.3957	1.3203	1.3203	1.4335	1.358
10	1.3957	1.2826	1.6221	1.4335	1.2449	1.3203	1.2449
11	1.2071	1.094	1.3203	1.2826	1.0185	1.2071	1.0185
12	.9431	.8676	1.1694	1.094	.9431	1.0562	1.0185
13	.8676	.9054	.9431	.9431	.8676	.7922	.8676
14	.7922	.7167	.8299	.7922	.7167	.7167	.7545
15	.7545	.7922	.7545	.7545	.7545	.7545	.7922
16	.7545	.8299	.7922	.7922	.7167	.7922	.8299
17	.7545	.7922	.8299	.7545	.7545	.8299	.7922
18	.8676	.8676	.8676	.8299	.8299	.7922	.8676
19	1.0185	1.0185	.9808	.9808	.9808	.9431	1.0185
20	.9431	1.0185	.9431	.9054	.9054	.9808	.9808
21	.9808	.9808	.9054	.9431	.9431	.9054	1.0185
22	.9808	.9054	.8676	.8676	.9054	.8676	.9054
23	.7545	.7922	.7167	.7545	.7545	.7545	.7167
24	.6036	.6036	.6413	.6036	.6413	.5658	.6036
Max	1.4712	1.5844	1.6221	1.4335	1.3203	1.4335	1.358
Min	.3395	.3395	.3772	.3395	.3772	.3395	.3772
Avg	.8488	.8456	.8566	.8205	.8142	.8205	.8472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213439 / Shanti Nagar S/stn

Feeder No / Name : 302 / Padmavati - II

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1687	3.1687	4.0741	3.2442	3.1687	2.9424	3.2065
2	2.9424	2.9801	3.81	3.0556	3.0178	2.6783	2.9801
3	2.6406	2.8292	3.5082	2.9047	2.8669	2.452	2.7915
4	3.2819	3.2442	3.8855	3.1687	3.131	2.7161	3.0178
5	3.6969	3.6969	4.489	3.3573	3.4705	3.2442	3.4705
6	4.225	4.1872	4.9794	3.5837	4.0741	3.9232	4.1118
7	5.1303	4.8285	5.998	4.2627	4.8663	4.7531	4.5645
8	5.7716	5.3189	6.941	4.9417	5.7716	5.5076	5.7716
9	6.1866	5.8093	7.8841	5.7339	5.9225	5.998	5.9225
10	5.8848	5.4698	7.5446	5.8093	5.583	4.8285	5.8848
11	4.5268	6.0357	7.2428	5.4321	5.3189	5.8848	5.4321
12	2.1125	5.2812	6.7901	4.904	5.2058	5.0926	5.168
13	2.8292	2.037	6.1488	4.4136	4.7908	4.6022	4.8663
14	4.7154	1.773	5.7339	4.1118	4.4513	4.225	4.6022
15	4.6776	1.773	5.2435	3.6591	4.4136	4.1495	4.5645
16	4.5268	1.8107	5.2435	3.7346	4.1495	4.0364	4.5268
17	4.6022	1.773	5.5453	3.81	4.3759	4.4513	4.904
18	4.8285	1.773	1.8107	3.9609	4.8663	4.6776	4.904
19	5.8093	2.1879	5.9225	5.0926	5.8471	5.6207	5.8471
20	5.4698	1.9993	5.583	5.0926	5.4321	5.3567	5.7339
21	5.0172	1.7353	4.9794	5.0549	5.2058	5.0549	5.2435
22	4.6022	6.1111	4.5268	4.5645	4.6776	4.5645	4.7908
23	3.9986	5.6584	4.1118	4.1118	4.0741	3.9986	4.1118
24	3.3951	3.4705	4.6399	3.4328	3.4328	3.3951	3.4328
Max	6.1866	6.1111	7.8841	5.8093	5.9225	5.998	5.9225
Min	2.1125	1.7353	1.8107	2.9047	2.8669	2.452	2.7915
Avg	4.335	3.5397	5.2765	4.2265	4.5048	4.3397	4.5771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213439 / Shanti Nagar S/stn

Feeder No / Name : 303 / Akruti

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.1812	1.3336	1.2955	1.2574	1.2955	1.2574
2	1.105	.9907	1.1812	1.1812	1.0669	1.1431	1.105
3	1.2193	.9145	.9907	1.2193	1.105	1.105	1.1812
4	1.4861	1.2193	1.2955	1.2955	1.3717	1.1812	1.3717
5	1.7909	1.5242	1.4861	1.4098	1.5623	1.6385	1.6766
6	2.21	2.0195	1.9052	1.5623	1.9814	2.0576	2.1338
7	2.4387	2.2862	2.2481	2.1338	2.5911	2.6292	2.6292
8	2.6673	2.4387	2.4768	2.7435	3.1626	3.1245	3.1245
9	2.8578	2.8959	2.7435	3.2388	2.8197	3.0102	2.934
10	2.4768	2.553	2.7816	2.9721	2.6673	3.0864	3.0102
11	2.2862	2.4006	2.7054	2.8197	2.4387	2.6673	2.4006
12	1.8671	2.1338	2.4006	2.4006	2.0957	2.3243	2.0957
13	1.7147	1.8671	1.9814	2.0576	1.8671	1.9052	1.7909
14	1.6004	1.829	1.8671	1.8671	1.7147	1.7909	1.7909
15	1.6004	1.9433	1.9433	1.9052	1.9052	1.9052	
16	1.5623	1.9052	1.9433	1.9052	1.7909	1.9433	
17	1.5623	1.9052	1.9814	1.9433	1.7909	1.9052	.4954
18	1.6766	2.0576	2.1338	1.9814	1.8671	1.9433	2.7054
19	2.3624	2.7435	2.7435	2.5149	2.553	2.6292	2.8959
20	2.3243	2.5149	2.553	2.5149	2.4768	2.553	2.7054
21	2.2481	2.3243	2.4006	2.3624	2.4006	2.3624	2.4387
22	2.0957	2.1719	2.21	2.0957	2.1125	2.1338	2.1719
23	1.7147	1.7528	1.829	1.7528	1.7909	1.829	1.7909
24	1.4861	1.448	1.448	1.4861	1.4861	1.4098	1.5242
Max	2.8578	2.8959	2.7816	3.2388	3.1626	3.1245	3.1245
Min	1.105	.9145	.9907	1.1812	1.0669	1.105	.4954
Avg	1.9004	1.9592	2.0243	2.0274	1.9948	2.0655	2.0559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213439 / Shanti Nagar S/stn

Feeder No / Name : 304 / Lake Town

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	1.6766	1.6385	1.6766	1.7147	1.6004	1.7528
2	1.5623	1.5623	1.4861	1.5242	1.5242	1.4098	1.4861
3	1.4861	1.4098	1.3717	1.448	1.448	1.2574	1.2955
4	1.6766	1.7147	1.6766	1.5623	1.6385	1.4861	1.5623
5	2.0195	2.0195	1.8671	1.6385	1.9433	2.0195	1.8671
6	2.5149	2.4768	2.21	1.9052	2.4006	2.5911	2.3624
7	3.0483	3.0102	2.7054	2.7435	3.3532	3.3913	3.5437
8	3.658	3.5056	3.5437	3.5818	4.1914	4.3058	4.2676
9	4.1914	4.1152	4.1914	4.2295	4.1914	4.1152	4.1914
10	3.3913	3.8485	3.8866	4.2676	3.8866	4.1152	3.5437
11	2.9721	3.315	3.658	4.0009	3.2388	3.3913	3.3532
12	2.3243	2.934	3.4675	3.4675	2.934	3.0864	2.934
13	2.0957	2.3243	2.8197	2.8959	2.4768	2.4768	2.3243
14	1.8671	2.0957	2.21	2.4387	2.1719	2.0576	2.1338
15	1.8671	2.2862	2.3624	2.553	2.3243	2.21	2.3243
16	1.7147	2.3243	2.3624	2.3243	2.1719	2.1719	2.21
17	1.9433	2.4387	2.3624	2.4387	2.4006	2.2862	2.4387
18	2.0576	2.553	2.6292	2.553	2.5149	2.553	2.5911
19	2.8197	3.315	3.2769	3.2007	3.2007	3.1245	3.3913
20	2.8959	3.0864	3.1626	3.0483	3.1626	3.1245	3.2769
21	2.8578	3.0102	2.8959	2.934	3.0483	3.0102	3.0483
22	2.7816	2.7816	2.7435	2.7435	2.8197	2.7816	2.8197
23	2.2481	2.2862	2.2481	2.2862	2.3624	2.3243	2.3243
24	1.9052	1.8671	1.9052	1.8671	1.8671	1.829	1.9433
Max	4.1914	4.1152	4.1914	4.2676	4.1914	4.3058	4.2676
Min	1.4861	1.4098	1.3717	1.448	1.448	1.2574	1.2955
Avg	2.4021	2.5815	2.6117	2.6387	2.6244	2.6133	2.6244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PADMAVATI DIVISION[304]

MARKET YARD SUB-DN.[606] BU 4606

Substation No/ Name :- 213439 / Shanti Nagar S/stn

Feeder No / Name : 305 / Ambika Nagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7167	.7167	.679	.679	.7167	.7922
2	.7167	.6036	.6036	.6036	.5658	.6036	.679
3	.6036	.679	.4904	.5658	.6036	.4904	.6036
4	.7922	.7922	.6413	.7167	.7922	.679	.679
5	.9808	.9808	.9431	.7922	.9808	.9431	.9054
6	1.3957	1.2071	1.2449	.9808	1.3203	1.2826	1.094
7	1.5089	1.4335	1.4712	1.2826	1.5844	1.6221	1.5466
8	1.6975	1.6598	1.6598	1.7353	1.8861	2.0748	2.1125
9	1.8484	1.8861	1.9239	2.1879	1.8861	2.2257	1.9993
10	1.6598	1.773	1.8861	2.0748	1.8107	1.8484	1.6975
11	1.6598	1.5844	1.6598	1.9239	1.6221	1.6221	1.5466
12	1.3203	1.4335	1.3957	1.6221	1.5089	1.5089	1.3957
13	1.2071	1.4335	1.358	1.4712	1.358	1.358	1.4335
14	1.1317	1.2449	1.1317	1.3203	1.0562	1.094	1.094
15	1.0185	1.094	1.094	1.2071	.9808	1.0562	1.1317
16	1.0185	1.094	1.0562	1.2071	1.0185	1.094	1.094
17	1.0562	1.2071	1.1694	1.2826	1.094	1.1694	1.1694
18	1.1694	1.4712	1.2449	1.3957	1.358	1.2071	1.4335
19	1.5089	1.8107	1.7353	1.6975	1.6221	1.6598	1.773
20	1.5844	1.773	1.6598	1.6975	1.5844	1.7353	1.8107
21	1.5466	1.6221	1.5089	1.5089	1.6221	1.5466	1.6598
22	1.4712	1.4335	1.3957	1.358	1.3957	1.3957	1.4335
23	1.1317	1.1694	1.1317	1.0562	1.1317	1.094	1.1317
24	.8676	.8676	.9054	.8676	.8299	.8299	.9054
Max	1.8484	1.8861	1.9239	2.1879	1.8861	2.2257	2.1125
Min	.6036	.6036	.4904	.5658	.5658	.4904	.6036
Avg	1.2354	1.2904	1.2511	1.3014	1.2621	1.2857	1.2967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

MANDAI SUB-DN.[692] BU 4692

Substation No/ Name :- 213014 / 22/11 KV Mandai Sub Station

Feeder No / Name : 201 / TARUN BHARAT SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9526	.8962	.7842	.7842	.7842	.8029
2	.8192	.9145	.8962	.7282	.7282	.7282	.7282
3	.8383	.8764	.8962	.6535	.6535	.7095	.7095
4	.9145	.8383	.8215	.6535	.6535	.7095	.7095
5	.9145	1.0098	.9896	.7095	.7095	.7095	.7282
6	1.0288	1.1812	.9709	.8589	.8589	.9896	1.0456
7	1.2765	1.3908	1.1203	.9896	1.251	1.1203	1.1203
8	1.5623	1.5242	1.4377	1.3443	1.5123	1.3817	1.4377
9	1.4003	1.475	1.6244	1.4937	1.4937	1.4563	1.5497
10	1.4377	1.5497	1.475	1.4377	1.475	1.5684	1.531
11	1.419	1.531	1.531	1.531	1.475	1.4377	1.587
12	1.3817	1.5497	1.5123	1.3817	1.4377	1.4003	1.587
13	1.3443	1.3817	1.3817	1.2883	1.363	1.307	1.4003
14	1.1949	1.2696	1.1576	1.1949	1.2136	1.2323	1.2696
15	1.2136	1.251	1.2696	1.1203	1.1763	1.2574	1.307
16	1.2323	1.2696	1.1763	1.0082	1.1576	1.2574	1.3717
17	1.2323	1.307	1.251	1.1389	1.251	1.3336	1.4098
18	1.4003	1.6057	1.4937	1.2696	1.419	1.5432	1.6575
19	1.7177	1.9418	1.8111	1.6244	1.8298	1.9052	2.0005
20	1.6991	1.7551	1.6617	1.587	1.6804	1.7337	1.8099
21	1.5123	1.6057	1.5497	1.4937	1.5123	1.531	1.6057
22	1.2765	1.2696	1.2696	1.2883	1.3256	1.307	1.2696
23	1.0479	1.1016	1.0642		1.1016	1.0829	1.1016
24	.8954	1.0098	.9149	.8775	.8402	.8775	.9149
Max	1.7177	1.9418	1.8111	1.6244	1.8298	1.9052	2.0005
Min	.8192	.8383	.8215	.6535	.6535	.7095	.7095
Avg	1.2340	1.3151	1.2572	1.1503	1.2043	1.2235	1.2773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

MANDAI SUB-DN.[692] BU 4692

Substation No/ Name :- 213014 / 22/11 KV Mandai Sub Station

Feeder No / Name : 202 / NAGNATH PAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3429	.3174	.2801	.2801	.2987	.2801
2	.3239	.3239		.2614	.2614	.2614	.2614
3	.2858	.3239	.3174	.2427	.2427	.2427	.2427
4	.2858	.381	.3734	.2427	.2427	.2427	.2427
5	.381	.4382	.4481	.2427	.2427	.2801	.2801
6	.4572	.5144	.3921	.3361	.3361	.4294	.4294
7	.5525	.5525	.4481	.4481	.5228	.4668	.4668
8	.6668	.6668		.5041		.6348	.6535
9	.6535	.5788	.6348	.5788	.6722	.6908	.7095
10	.6535	.6908	.6722	.6722	.6722	.6535	.7095
11	.9149	.8962	.9335	.8029	.8029	.9335	.9149
12	1.0082	.9896	1.0456	.9335	.8589	1.0082	1.0829
13	.9709	.9709	1.0642	.9709	.7842	1.0269	1.0082
14	1.0456	.8962	.9896	.9709	.7842	1.0082	.9709
15	1.0082	.9149	1.0082	.9149	.8215	1.0288	.9522
16	1.0082	1.0456	1.0456	1.0082	.8402	1.1622	1.0479
17	1.1203	1.0082	1.1389	.9335	.8402	1.1431	1.086
18	1.1389	1.1016	1.1763	.9896	.8775	1.1812	1.2193
19	1.3443	1.2136	1.3256	1.2136	1.0269	1.2193	1.3908
20	1.2323	1.1949	1.2323	1.1576	1.0829	1.2574	
21	1.0829		.9896	1.0082	.8029	1.0269	1.0456
22	.5335	.5228	.5601		.5228	.5228	.5041
23	.4001	.3921	.3921		.3921	.4108	.4108
24	.362	.381	.3361	.3174	.3361	.3361	.3361
Max	1.3443	1.2136	1.3256	1.2136	1.0829	1.2574	1.3908
Min	.2858	.3239	.3174	.2427	.2427	.2427	.2427
Avg	.7398	.7105	.7655	.6832	.6194	.7278	.7063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

MANDAI SUB-DN.[692] BU 4692

Substation No/ Name :- 213014 / 22/11 KV Mandai Sub Station

Feeder No / Name : 203 / SHREENATH SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0187	.0373	.0187	.0187	.0187
2	.0381	.0381	.0187	.0187	.0187	.0187	.0187
3	.0381	.0381	.0373	.0187	.0187	.0187	.0187
4	.0381	.0381	.0373	.0187	.0187	.0187	.0187
5	.0381	.0381	.0373	.0373	.0187	.0373	.0187
6	.0381	.0381	.0373	.0373	.0187	.0373	.0373
7	.0381	.0572	.0373	.0373	.0187	.0373	.0373
8	.0572	.0572	.0747	.056	.0373	.056	.056
9	.056	.056	.0373	.056	.0373	.056	.056
10	.0747	.056	.056	.056	.0747	.056	.0747
11	.0934	.0934	.0747	.0934	.0747	.0934	.0934
12	.0934	.0934	.0934	.0747	.0934	.0934	.112
13	.0934	.0934	.0747	.0747		.0747	.112
14	.0934	.0747	.0747	.0747	.0934	.0934	.112
15	.112	.0934	.0934	.0747	.0934	.0953	.112
16	.112	.0934	.0934	.0747	.0934	.0953	.1143
17	.112	.112	.0934	.0747	.0934	.0762	.1143
18	.0934	.112	.0934	.0934	.0934	.1143	.1143
19	.1307	.1307	.1307	.1307	.1307	.1334	.1524
20	.1307	.1307	.1307	.1307	.1307	.1334	.1334
21	.0934	.0934	.112	.112	.112	.0934	.0934
22	.0572	.056	.056		.056	.056	.056
23	.0381	.0373	.0373		.0373	.0373	.0373
24	.0191	.0191	.0373	.0373	.0187	.0373	.0187
Max	.1307	.1307	.1307	.1307	.1307	.1334	.1524
Min	.0191	.0191	.0187	.0187	.0187	.0187	.0187
Avg	.0712	.0695	.0661	.0645	.0609	.0659	.0721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

MANDAI SUB-DN.[692] BU 4692

Substation No/ Name :- 213014 / 22/11 KV Mandai Sub Station

Feeder No / Name : 204 / FARASKHANA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1867	.2054		.2054	.1867
2	.1905	.1905	.1867	.1867		.168	.168
3	.1905	.1905	.1867	.1494		.168	.168
4	.2096	.2286	.2054	.1494		.168	.168
5	.2096	.2286	.2241	.1494		.168	.168
6	.2096	.2286	.2054	.2241		.2241	.2427
7	.2477	.2477	.2427	.2427		.2427	.2427
8	.3048	.3239	.2801	.3174		.2987	.3174
9	.2614	.3174	.2801	.3361	.3734	.3547	.3921
10	.3547	.3547	.3361	.3734	.4854	.4481	.4481
11	.5415	.5415	.5601	.6535	.6161	.7468	.7655
12	.5975	.5975	.5975	.7095	.6348	.7655	.7655
13	.5975	.5975	.6348	.7468	.6722	.7655	.8029
14	.5788	.5601	.5601	.7655	.6535	.7842	.7842
15	.5788	.5975	.5601	.7842	.6535	.8002	.8215
16	.5601	.5788	.5601	.7655	.6722	.7811	.8764
17	.5975	.6161		.7842	.6348	.8573	.9335
18	.6161	.6161	.6722	.8402	.6535	.8954	.8764
19	.7468	.7095	1.0082	.9522	.7655	1.0098	1.0479
20	.7095	.6908	.9335	.9149	.7095	.9526	
21	.5228	.5415	.7842	.8029	.5601	.7095	.7655
22	.3048	.2987	.3921		.3547	.3547	.3361
23	.2096	.2241	.2801		.2801	.2427	.2801
24	.2096	.1905	.1867	.2427		.2241	.2054
Max	.7468	.7095	1.0082	.9522	.7655	1.0098	1.0479
Min	.1905	.1905	.1867	.1494	.2801	.168	.168
Avg	.4058	.4109	.4376	.5135	.5813	.5140	.5114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

MANDAI SUB-DN.[692] BU 4692

Substation No/ Name :- 213014 / 22/11 KV Mandai Sub Station

Feeder No / Name : 205 / NAKODA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1905	.1867	.2427		.2427	.2614
2	.1905	.1905	.1867	.2241		.2241	.2614
3	.1905	.1905	.1867	.2054		.2241	.2427
4	.2477	.2667	.2614	.2241		.2241	.2241
5	.2477	.2667	.2614	.2427		.2427	.2427
6	.3239	.3048	.3174	.2801		.3174	.3361
7	.4001	.381	.3734	.3734		.3921	.3921
8	.4382	.4763		.4294		.4854	.4481
9	.4854	.4854	.4668	.4108	.4481	.4481	.4294
10	.4668	.5228	.4108	.4294	.4668	.4481	.5415
11	.5788	.6161	.5228	.4668	.5415	.5601	.5788
12	.5415	.5601	.5228	.4108	.5228	.5415	.5415
13	.5415	.5415	.5228	.3734	.5041	.5041	.5601
14	.5041	.4854	.4668	.9335	.4668	.5041	.5041
15	.5041	.5228	.4668	.3174	.4854	.5335	.5228
16	.5601	.5041	.4854	.3361	.5041	.5335	.4954
17	.5415	.5041	.4854	.3361	.5041	.4954	.4954
18	.4854	.4854	.4668	.3547	.4854	.5144	.5144
19		.4854	.5228	.4108	.4668	.4572	.5716
20	.4481	.4668	.4668	.3734	.4668	.4763	.4191
21	.3921	.4294	.4108	.3547	.4294	.4108	.3734
22	.3239	.3361	.3174		.3361	.3361	.3174
23	.2858	.2801	.2801		.2987	.2801	.2987
24	.2096	.2286	.2427	.2427		.2614	.2427
Max	.5788	.6161	.5228	.9335	.5415	.5601	.5788
Min	.1905	.1905	.1867	.2054	.2987	.2241	.2241
Avg	.3964	.4050	.3840	.3624	.4618	.4024	.4090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

MANDAI SUB-DN.[692]

BU 4692

Substation No/ Name :- 213014 / 22/11 KV Mandai Sub Station

Feeder No / Name : 206 / 11 kv Mahalaxmi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2858	.2801	.2801	.2801	.2614	.2614
2	.2801	.2858	.2801	.2427	.2427	.2427	.2427
3	.2614	.2858	.2801	.2427	.2427	.2427	.2427
4	.2987	.3048	.2987	.2427	.2427	.2427	.2427
5	.2987	.3429	.3361	.2614	.2614	.2614	.2241
6	.3361	.381	.3174	.2801	.2801	.3174	.3361
7	.3734	.4191	.3547	.3174	.3734	.3361	.3361
8	.4481	.4382	.3921	.3734		.3734	.4481
9	.4854	.5228	.4481	.4481	.4854	.5041	.5415
10	.6535	.6161	.6161	.5975	.5788	.6348	.6161
11	.9709	.9335	.8775	.8589		.9335	.9522
12	1.0269	1.0456	.9709	.9709	.8589	1.0082	1.0642
13	1.0456	1.0829	.9149	.9709	.8029	.6908	1.0829
14	1.0456	1.0642	.9522	.9896	.8029	.6908	1.0456
15	1.0642	1.0269	1.0456	1.0082	.8029	.9907	1.0456
16	1.0456	1.0829	.9896	1.0456	.7842	1.0288	1.1431
17	1.1016	1.0456	1.0642	1.0829	.8402	1.0098	1.2003
18	1.1389	1.1389	1.2136	1.1576	.8029	1.2003	1.1812
19	1.251	1.2696	1.2883	1.2696	.9335	1.2955	1.4098
20	1.1949	1.251	1.2696	1.2136	.8402	1.1812	1.2574
21	.9335	.9149	1.0269	1.0642		.8962	.9709
22	.4572	.4668	.5228	.5415	.3921	.4668	.4481
23	.362	.3361	.3361		.3174	.3547	.3547
24	.3174	.3239	.2987	.2987	.2801	.2987	.2987
Max	1.251	1.2696	1.2883	1.2696	.9335	1.2955	1.4098
Min	.2614	.2858	.2801	.2427	.2427	.2427	.2241
Avg	.6946	.7027	.6823	.6851	.5450	.6443	.7061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213005 / 22/11 kv Old Parvati

Feeder No / Name : 203 / 11 kv Peshwe Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4481	.4715		.5041	.5228	.4481
2		.4108	.4715		.462	.4805	.3734
3		.4108			.4435	.462	.6348
4		.4108			.4435	.462	.7468
5	.4715	.4854			.5041	.499	.7842
6	.7545	.7095	.8488	.5658	.6535	.7468	.8215
7	1.0374	1.0082	.9431	.8488	.9431	.9619	1.094
8	1.226	1.1203	1.0374	1.1317	1.2384	1.2384	1.1949
9	1.1576	1.1431	1.1949	1.2696	1.1576	1.2955	1.2193
10	.9709	.8775	.9709	1.1576	1.0456	1.1203	.9619
11	.8215	.8029	.9335	.9709	.9335	1.0082	.8676
12	.7842	.7762	.8215	.8215	.8215	.8589	.7468
13	.7468	.6283	.7842	.7842	.7095	.7842	.7655
14	.6722	.6099	.6722	.6348	.7095	.7095	.7023
15	.6468	.6036	.7095	.5975	.7095	.6348	.6838
16	.6468	.5914	.6653	.5788	.6722	.6602	.6602
17	.7023	.6653	.6653	.5544	.6722		
18	.7282	.7095	.6838	.7282	.7468		
19	.8676	.9054	.8865	.9054	.9431	.8488	.9431
20	.8865	.9054	.9149	.9054	.9526	.8488	
21	.811	.8299	.811	.8676	.8676		
22	.7468	.7545	.7545	.7545	.7468	.7842	.7842
23	.6722	.5658	.5658	.6413	.7095		.6722
24	.5658	.4854	.4715	.5658	.5601	.5601	.5228
Max	1.226	1.1431	1.1949	1.2696	1.2384	1.2955	1.2193
Min	.4715	.4108	.4715	.5544	.4435	.462	.3734
Avg	.7958	.7024	.7751	.8044	.7562	.7743	.7814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213005 / 22/11 kv Old Parvati

Feeder No / Name : 206 / 11 kv Dattawadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5175	.4715		.5601	.5601	.5228
2		.4805	.4715		.5041	.4805	.4481
3		.4805			.462	.4435	.3734
4		.4805			.462	.439	.5228
5	.5658	.6283			.5359	.5359	.7468
6	.9431	.924	.9431	.6602	.8962	.8962	.9709
7	1.226	1.2197	1.0374	.8488	1.1812	1.094	1.1949
8	1.4146	1.5154	1.226	1.226	1.3717	1.4098	1.4563
9	1.307	1.448	1.3306	1.3676	1.4045	1.5051	1.4098
10	1.1576	1.1431	1.1827	1.3306	1.2437	1.2567	1.3336
11	.9709	.9707	1.0719	1.1458	1.0349	1.1088	1.0562
12	.8215	.8589	.9979	.9979	.8871	.924	.9808
13	.7468	.7842	.8501	.8501	.8131	.8131	.8402
14	.6722	.7282	.7023	.7392	.7392	.7023	.7468
15	.6348	.6653	.6653	.6348	.6283	.6653	.6722
16	.6348	.6468	.5729	.5975	.7282	.5658	.6602
17	.6468	.7023	.6283	.7095	.6722		
18	.7468	.8215	.8215	.7655	.8402		
19	1.0288	1.086	1.1431	1.0098	1.1431	1.0374	1.0374
20	1.0185	1.0669	1.086	1.0185	1.0562	1.0374	
21	1.0185	1.0374	1.0185	.9808	1.0479		
22	.961	.9431	.8488	.8865	.9431	.8962	.9335
23	.8131	.7545	.6602	.7922	.8215	.7842	.8215
24	.5658	.6283	.6602	.6602	.5975	.5788	.5975
Max	1.4146	1.5154	1.3306	1.3676	1.4045	1.5051	1.4563
Min	.5658	.4805	.4715	.5975	.462	.439	.3734
Avg	.8947	.8555	.8757	.9064	.8572	.8445	.8663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213005 / 22/11 kv Old Parvati

Feeder No / Name : 207 / 11 kv Sarita Nagari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	14-FEB-18
HR	Load (MW)
16	.4715
19	.6602
22	.4854
23	.4108
Max	.6602
Min	.4108
Avg	.5070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213005 / 22/11 kv Old Parvati

Feeder No / Name : 210 / 11 kv Waghjai Mandir
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1494	.0943		.1294	.1478	.1494
2		.1494	.0943		.1097	.128	.112
3		.1494			.1097	.128	.112
4		.1494			.1097	.1294	.1867
5	.1886	.2241			.1478	.1848	.3361
6	.3772	.3734	.3772	.2829	.3395	.3547	.4108
7	.5658	.4854	.5658	.3772	.5144	.5281	.5601
8	.5658	.5975	.5658	.5658	.5847	.6413	.6348
9	.4481	.4904	.4854	.5228	.4854	.547	.415
10	.2987	.2614	.3361	.4108	.3361	.3361	.3174
11	.1867	.2218	.2614	.2987	.2241	.2614	.2218
12	.1494	.1663	.2241	.2241	.1867	.2241	.1829
13	.1494	.1478	.1867	.2241	.1867	.2241	.1646
14	.1494	.1463	.1494	.2241	.1867	.1867	.1448
15	.128	.1448	.1494	.1848	.1867	.1867	.1646
16	.128	.1267	.1463	.1646	.1478		.1886
17	.1663	.1463	.1663	.1646	.1478		
18	.1848	.1848	.2012	.2218	.1848		
19	.2829	.2987	.3174	.3174	.2987	.2829	.3772
20	.3206	.3206	.3361	.3361	.3206	.2829	
21	.3018	.3206	.3206	.3018	.3174		
22	.2987	.2829	.2829	.2614	.2801	.7842	.2987
23	.2614	.1886	.1886	.2218	.2195	.6722	.2241
24	.1886	.1867	.1886	.1886	.1478	.1663	.1494
Max	.5658	.5975	.5658	.5658	.5847	.7842	.6348
Min	.128	.1267	.0943	.1646	.1097	.128	.112
Avg	.2670	.2464	.2685	.2891	.2459	.3198	.2676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213005 / 22/11 kv Old Parvati

Feeder No / Name : 307 / 22 kv Janatavasahat

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2241	.1886		.2218	.2195	.2241
2		.2241	.1886		.181	.181	.2241
3		.2241			.181	.181	.1867
4		.2241			.181	.181	.1867
5	.1886	.3734			.2987	.2195	.3734
6	.5658	.5228	.5658	.3772	.4854	.4481	.5601
7	.7545	.6722	.7545	.5658	.679	.6348	.7095
8	.7545	.7468	.7545	.7545	.7922	.7922	.7842
9	.5601	.679	.6722	.7468	.6722	.7545	.6413
10	.4481	.4481	.5228	.6722	.5228	.5228	.4481
11	.3361	.3696	.4481	.5228	.3734	.4481	.3696
12	.2987	.3326	.3734	.4481	.2987	.3734	.2926
13	.2614	.2926	.2987	.3734	.2987	.2987	.2561
14	.2614	.2534	.2987	.2987	.2987	.2987	.2561
15	.2195	.2534	.2987	.2534	.2241	.2987	.2195
16	.2172	.2172	.2172	.2561	.2195	.1886	.1886
17	.2195	.2587	.2926	.3326	.2957		
18	.2957	.3361	.3696	.3696	.3326		
19	.4481	.6036	.5228	.5281	.5228	.5658	.5658
20	.4854	.5228	.5601	.5658	.5658	.5658	
21	.4481	.6036	.5281	.5601	.5228		
22	.4481	.5658	.3772	.4854	.4435	.4854	.5601
23	.3734	.3772	.1886	.3696	.3326	.3734	.4108
24	.2641	.2987	.3772	.1886	.2587	.2587	.2614
Max	.7545	.7468	.7545	.7545	.7922	.7922	.7842
Min	.1886	.2172	.1886	.1886	.181	.181	.1867
Avg	.3924	.401	.4190	.4563	.3834	.3947	.3859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213010 / 22/11 kv Navi Peth

Feeder No / Name : 201 / SHASTRI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		1.1576			
10		1.1763			
11		1.1576			
12		1.1016			
13		1.0269			
14		.9149			
22	.9522		.9896	1.0082	1.0269
23	.8402		.8589	.8589	
24		.6722		.6722	.7282
Max	.9522	1.1763	.9896	1.0082	1.0269
Min	.8402	.6722	.8589	.6722	.7282
Avg	.8962	1.0296	.9243	.8464	.8776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213010 / 22/11 kv Navi Peth

Feeder No / Name : 202 / PHULE MANDAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.8402			
10		.7842			
11		.8402			
12		.8589			
13		.7655			
14		.7842			
22	.7095		.7282	.7095	.7282
23	.5228		.5601	.5415	
24		.4108		.4108	.4294
Max	.7095	.8589	.7282	.7095	.7282
Min	.5228	.4108	.5601	.4108	.4294
Avg	.6162	.7549	.6442	.5539	.5788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213010 / 22/11 kv Navi Peth

Feeder No / Name : 203 / S P COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		1.6244			
10		1.6057			
11		1.5123			
12		1.5123			
13		1.2883			
14		1.2696			
22	1.2696		1.2136	1.1763	1.2696
23	1.0269		1.0082	.9522	
24		.8775		.7655	.7842
Max	1.2696	1.6244	1.2136	1.1763	1.2696
Min	1.0269	.8775	1.0082	.7655	.7842
Avg	1.1483	1.3843	1.1109	.9647	1.0269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213010 / 22/11 kv Navi Peth

Feeder No / Name : 204 / RAJENDRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		1.7364			
10		1.6617			
11		1.5123			
12		1.2136			
13		1.0456			
14		.8589			
22	1.0642		1.1203	1.1016	1.1389
23	.8962		.9335	.9522	
24		.7468		.7842	.8215
Max	1.0642	1.7364	1.1203	1.1016	1.1389
Min	.8962	.7468	.9335	.7842	.8215
Avg	.9802	1.2536	1.0269	.946	.9802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213010 / 22/11 kv Navi Peth

Feeder No / Name : 206 / 11 kv Ram

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.1494			
10		.1494			
11		.1307			
12		.0747			
13		.0934			
14		.056			
22	.0747		.0747	.0934	.0747
23	.0187		.0747	.0747	
24		.112		.1494	.056
Max	.0747	.1494	.0747	.1494	.0747
Min	.0187	.056	.0747	.0747	.056
Avg	.0467	.1094	.0747	.1058	.0654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213010 / 22/11 kv Navi Peth

Feeder No / Name : 207 / 11 kv Poona Hospital
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.3547			
10		.2801			
22	.2987		.2614	.3174	.2801
23	.2614		.1867	.2427	
24		.2427		.2054	.2054
Max	.2987	.3547	.2614	.3174	.2801
Min	.2614	.2427	.1867	.2054	.2054
Avg	.2801	.2925	.2241	.2552	.2428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213010 / 22/11 kv Navi Peth

Feeder No / Name : 303 / MANDAI NO-2

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.8962			
10		.9709			
11		1.2696			
12		1.2696			
13		1.2696			
14		1.307			
22	.8215		.8215	.7842	.8215
23	.6722		.7095	.6722	
24		.5975		.5601	.5601
Max	.8215	1.307	.8215	.7842	.8215
Min	.6722	.5975	.7095	.5601	.5601
Avg	.7469	1.0829	.7655	.6722	.6908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213322 / 22/11 KV Sainagar

Feeder No / Name : 201 / 11 kv VeetBhatti No1
(Avanti) Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.5249	.5601	.5249	.5975	.5249	.5068
2	.6161	.4887	.5228	.5068	.5544	.4887	.4706
3	.5544	.4706	.5041	.4887	.5415	.4706	.4525
4	.5121	.4706	.5228	.4887	.4854	.4706	.4525
5	.5601	.5068	.5601	.543	.499	.5068	.5611
6	.7282	.6697	.6348	.6154	.5788	.6697	.6878
7	.823	.7964	.7282	.6154	.8775	.7964	.8326
8	1.0059	1.0136	.8962	.8145	.8316	.9412	.9774
9	1.0642	1.0317	1.0562	.8507	1.0456	1.0498	1.0082
10	1.0349	1.0498	1.0498	1.0642	1.0829	1.1016	1.0829
11	1.0903	1.0082	1.1041	1.0164	1.0269	1.1088	1.0082
12	.961	.9709	.905	.9709	.9335	.9694	1.0082
13	.9335	.9335	.8869	.823	.8775	.8962	.9335
14	.8402	.8215	.7964	.7655	.8029	.7762	.8029
15	.7207	.8029	.7602	.7468		.7392	.8029
16	.7577	.8402	.7783	.6535	.8029	.7207	.8215
17	.8488	.8775	.7602	.7468	.7842	.7468	.8316
18	.8402	.8589	.7783	.8402	.8215	.8029	.9522
19	1.0164	1.0456	1.0374	.9979	1.0082	1.0269	1.0719
20	1.0349	1.0456	.9774	.9896	1.0456	1.0456	1.0903
21	1.0349	1.0456	.9774	.9709	.9709	.9522	1.0829
22	.7964	.8775	.8326	.9055	.8145	.8688	.9149
23	.724	.7655	.7602	.7392	.724	.724	.7095
24	.6722	.5792	.5975	.5792	.6161	.6348	.6335
Max	1.0903	1.0498	1.1041	1.0642	1.0829	1.1088	1.0903
Min	.5121	.4706	.5041	.4887	.4854	.4706	.4525
Avg	.8252	.8123	.7911	.7607	.7966	.7930	.8207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

PESHWE PARK SUB-DN.[612] BU 4612

Substation No/ Name :- 213322 / 22/11 KV Sainagar

Feeder No / Name : 202 / 11 kv VeetBhatti No2
(Shravan Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3395	.3772	.3772	.3921	.3395	.3361
2	.3361	.3206	.3395	.3395	.3547	.3077	.2987
3	.3174	.3206	.3206	.3206	.3361	.3206	.3018
4	.3174	.3584	.3361	.3395	.3174	.3734	.3174
5	.3258	.3961	.3961	.4338	.3881	.3921	.4108
6	.4668	.6413	.5281	.4904	.4668	.6348	.5788
7	.8215	.7733	.6224	.5658	.8962	.7545	.7468
8	.9522	.9242	.7545	.7356	.8589	.8865	.8775
9	1.0082	.9242	.7922	.8488	.924	.9997	.9997
10	.7842	.9242	.7545	.8775	.8488	.8589	.7356
11	.6535	.7545	.7733	.8589	.7167	.7468	.6979
12	.5729	.6036	.679	.7842	.5847	.6348	.6224
13	.5228	.5281	.6224	.6535	.4904	.5729	.6036
14	.4668	.4527	.5847	.5975	.4715	.5228	.5093
15	.4294	.4527	.5281	.5041	.4338	.5093	.132
16	.4435	.4527	.4904	.4294	.415	.4481	.168
17	.5093	.4715	.5281	.5415	.4904	.4854	.1848
18	.6099	.547	.5658	.5914	.5847	.5975	.1509
19	.7023	.7095	.7733	.7282	.7167	.6908	.1867
20	.7392	.7545	.7545	.6908	.7922	.7282	.2033
21	.7577	.679	.679	.6908	.679		.1867
22	.679	.5658	.6602	.6722	1.3817	.5847	.1698
23	.547	.5093	.547	.5041	1.1203	.6224	.1132
24	.4481	.4338	.415	.415	.4294	.4338	.415
Max	1.0082	.9242	.7922	.8775	1.3817	.9997	.9997
Min	.3174	.3206	.3206	.3206	.3174	.3077	.1132
Avg	.5744	.5765	.5759	.5829	.6287	.5846	.4145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

SWARGATE SUB-DN.[605] BU 4605

Substation No/ Name :- 213006 / 22/11 KV GULTEKADI

Feeder No / Name : 201 / 11 KV MUKUNDNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5847	1.226	1.2071	.6224	.679	.679
2	.4904	.5281	1.1506	1.1317	.6224	.6413	.6413
3	.4527	.4904	1.094	1.0751	.5847	.5658	.6036
4	.4904	.5281	1.0374	.9997	.5658	.6036	.6413
5	.5281	.5658	.9619	.9242	.547	.6413	.7167
6	.811	.8299	1.1317	1.1506	.7356	.6413	.7922
7	.9808	.9808	1.2071	1.0562	.8299	.7545	.9431
8	1.1694	1.1506	1.5466	1.4335	1.1317	.9808	.9808
9	1.1317	1.1694	1.773	1.6221	1.0829	1.1576	1.1203
10	1.1317	1.2449	2.037	1.8107	1.1949	1.1949	1.2696
11	1.2071	1.2449	2.037	1.8861	1.0829	1.1576	1.1949
12	1.0185	1.1317	1.6975	1.5089	.9709	1.1203	1.0829
13	.9808	1.1317	1.5089	.9808	.9335	.9709	1.0082
14	.9431	.9431	1.3203	.8676	.8962	.8215	.8589
15	.9431	.9431	1.2449	.7922	.8215	.8589	.8962
16	.9054	.9335	1.2449	.7922	.9054	.8676	.9431
17	.9054	.9335	1.3203	.7545	.9431	.9431	.9808
18	.9054	.9709	1.4712	.8299	.9808	.9431	.9997
19	1.1317	1.1203	1.7353	1.0562	1.1317	1.2071	
20	1.1317	1.0456	1.5844	.9808	1.0562	1.0562	1.1128
21	1.0185	1.0082	1.4712	.9054	.9431	.9808	1.0374
22	.9054	1.358	1.3014	.8299	.8676	.8676	.8299
23	.679	1.2071	1.1506	.6979	.7545	.7545	.7167
24	.5281	.5658	1.3014	1.2637	.679	.7167	.7167
Max	1.2071	1.358	2.037	1.8861	1.1949	1.2071	1.2696
Min	.4527	.4904	.9619	.6979	.547	.5658	.6036
Avg	.8716	.9421	1.3981	1.1065	.8702	.8803	.9029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

SWARGATE SUB-DN.[605] BU 4605

Substation No/ Name :- 213006 / 22/11 KV GULTEKADI

Feeder No / Name : 203 / 11 KV NEW TIMBER MARKET SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2075	.1886	.1886	.2263	.1886
2	.2075	.2263	.2075	.1886	.1698	.1886	.1509
3	.1886	.2075	.1886	.1886	.1698	.1886	.1509
4	.1886	.1886	.1886	.2075	.1886	.2263	.2263
5	.1886	.1886	.1886	.2263	.2075	.2641	.2641
6	.2829	.2829	.3018	.2641	.2452	.3018	.3206
7	.3772	.3961	.3018	.3206	.3772	.3395	.3584
8	.3961	.415	.3772	.3584	.3584	.3584	.3584
9	.4904	.4904	.415	.415	.4854	.4481	.4854
10	.5658	.5281	.4527	.4527	.5228	.4854	.5228
11	.5093	.4715	.4715	.3961	.4854	.4481	.5228
12	.415	.5093	.4715	.3961	.4481	.4108	.4481
13	.415	.4904	.3961	.3018	.4108	.3734	.4108
14	.4338		.3772	.3206	.3734	.3734	.4108
15	.4338	.4527	.3584	.2801	.4108	.3361	.4481
16	.4481	.4854	.3361	.2614	.4108	.3361	.4715
17	.4108	.4481	.3547	.2801	.4108	.3734	.415
18	.4435	.4854	.3696	.2587	.4024	.3696	.4527
19	.4854	.4854	.4108	.3361	.4805	.4481	
20	.4108	.3734	.4108	.2987	.4066	.3734	.415
21	.3734	.3361	.3361	.3361	.3696	.3584	.3584
22	.3206	.2829	.3018	.2829	.3018	.2987	.3018
23	.2452	.2641	.2829	.2452	.2829	.2452	.2829
24	.2452	.2452	.2263	.2075	.1886	.2641	.2263
Max	.5658	.5281	.4715	.4527	.5228	.4854	.5228
Min	.1886	.1886	.1886	.1886	.1698	.1886	.1509
Avg	.3626	.3687	.3305	.2922	.3457	.3348	.3561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

SWARGATE SUB-DN.[605] BU 4605

Substation No/ Name :- 213006 / 22/11 KV GULTEKADI

Feeder No / Name : 204 / 11 KV Gurunanak

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.7167	.679	.6413	.6224	.7922	.8299
2	.6413	.679	.6602	.6224	.6036	.7545	.7922
3	.6036	.6413	.6036	.5847	.6036	.7167	.7545
4	.5658	.6036	.5847	.5658	.5847	.7167	.7167
5	.7356	.7733	.7545	.547	.5847	.7545	.7167
6	.811	.8488	.811	.7545	.811	.7922	.7167
7	.9808	.9997	.8676	.7545	1.0374	.8676	.9808
8	1.1694	1.3014	.9808	.9997	1.2071	1.0185	1.0562
9	1.2826	1.4712	1.2449	1.1317	1.3817	1.307	1.419
10	1.2071	1.4712	1.2071	1.39	1.307	1.3817	1.2696
11	1.0185	1.5089	1.2449	1.2071	1.2323	1.3817	1.2323
12	.9054	1.358	1.1317	1.2826	1.1576	1.2696	
13	.8676	1.3203	1.1317	1.2449	1.0082	1.1203	
14	.8676	1.0562	.9808	1.1317	.9709	1.0829	
15	.7922	.8676	.8779	.8962	.9335	.9709	
16	.7468	.7842	.8215	.8589	.8962	.8589	
17	.7842	.8589	.8215	.8589	.9335	.8215	
18	.8501	.9335	.8871	.8501	.9145	.8501	
19	.9709	1.0829	1.0082	.9709	1.0719	1.0082	
20	.9709	1.0456	.9709	.9709	1.0349	1.0082	
21	.9709	1.0082	.9709	.9709	.9979	1.0082	
22	.9808	.9431	.9054	.9054	.9808	.9709	
23	.9431	.9431	.9054	.8865	.9054	.9054	
24	.6979	.7356	.7167	.679	.6979	.8299	.8676
Max	1.2826	1.5089	1.2449	1.39	1.3817	1.3817	1.419
Min	.5658	.6036	.5847	.547	.5847	.7167	.7167
Avg	.8768	.9980	.907	.9044	.9366	.9662	.9460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

SWARGATE SUB-DN.[605] BU 4605

Substation No/ Name :- 213006 / 22/11 KV GULTEKADI

Feeder No / Name : 206 / 11 KV APALA MARUTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132	.132	.1132	.0943	.0754	.1132
2	.0754	.0943	.1132	.0943	.0754	.0566	.0754
3	.0754	.0754	.0754	.0754	.0566	.0754	.0754
4	.0754	.0754	.0754	.0754	.0566	.0754	.1132
5	.0754	.1132	.0754	.0754	.0566	.1132	.1132
6	.1509	.1698	.132	.132	.1132	.1132	.1132
7	.1886	.1886	.1698	.1509	.1698	.1509	.1886
8	.2263	.2075	.2452	.1886	.2263	.2058	.1715
9	.2263	.1509	.1903	.2263	.1867	.1867	.2054
10	.1509	.1509	.1509	.1886	.1494	.1494	.1307
11	.1509	.1132	.1132	.1509	.112	.112	.112
12	.0943	.1132	.1132	.1132	.0934	.112	.112
13	.0943	.0943	.0943	.0943	.112	.0934	.112
14	.0943	.0943	.0943	.0943	.0934	.0934	.0934
15	.0943	.0943	.0943	.0754	.0934	.0934	.0934
16	.0943	.0934	.0754	.0754	.0943	.0754	.0943
17	.0943	.0934	.0754	.0754	.0754	.0754	.1132
18	.0943	.112	.0943	.0943	.0943	.0943	.1132
19	.1132	.1307	.1132	.132	.1109	.132	
20	.1132	1.0456	.112	.132	.132	.132	.132
21	.1132	.112	.1132	.1132	.1132	.132	.132
22	.1132	.132	.1132	.1132	.1132	.1132	.1132
23	.0943	.1132	.1132	.1132	.0943	.1132	.0943
24	.1132	.132	.1509	.132	.0943	.0943	.1132
Max	.2263	1.0456	.2452	.2263	.2263	.2058	.2054
Min	.0754	.0754	.0754	.0754	.0566	.0566	.0754
Avg	.1171	.1589	.1179	.1179	.1088	.1112	.1186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

SWARGATE SUB-DN.[605] BU 4605

Substation No/ Name :- 213006 / 22/11 KV GULTEKADI

Feeder No / Name : 207 / 11 KV VEGA CENTER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.8676	.811	.7733	.7922	.8676	.8299
2	.7922	.8299	.7733	.7356	.7545	.7922	.7922
3	.7545	.7922	.7356	.7167	.7356	.7545	.7545
4	.7922	.8299	.7167	.679	.7356	.8299	.7167
5	.8299	.8676	.6979	.6602	.6602	.8676	.9054
6	.9431	.9808	.7356	.9054	.7922	.8676	.9431
7	.9808	.9808	.9619	.8676	.9431	.8573	.9808
8	.2263	.9808	.9997	.9431	.9997	.9808	.9431
9	1.0562	1.1317	1.0185	.9808	1.0082	1.1203	1.0456
10	1.2449	1.3203	1.2071	.9808	1.3443	1.2323	1.2323
11	1.3203	1.3203	1.358	1.0562	1.307	1.3443	1.3817
12	1.3203	1.358	1.3203	.9877	1.307	1.307	1.3817
13	1.2449	1.4335	1.2449	1.1317	1.3443	1.2323	1.3817
14	1.2449	1.3203	1.2449	1.0562	1.2323	1.2323	1.3443
15	1.3957	1.2826	1.2826	1.0185	.4854	1.2323	1.3443
16	1.3203	1.2696	1.2826	1.0562	1.4712	1.2826	1.2826
17	1.3203	1.2323	1.2449	.9808	1.358	1.2449	1.4146
18	1.2449	1.1949	1.1317	.9808	1.2071	1.1694	1.2826
19	1.2071	1.1949	1.1317	.9431	1.1694	1.1694	
20	1.0562	1.0456	1.094	.9054	1.094	1.0562	1.094
21	1.0185	.9709	1.0185	.9054	1.0562	1.0185	1.094
22	.9619	.9431	.9431	.9054	.9808	.9808	.9619
23	.9242	.9431	.9242	.9054	.9431	.9431	.9619
24	.8676	.9054	.8488	.811	.8299	.9054	.9054
Max	1.3957	1.4335	1.358	1.1317	1.4712	1.3443	1.4146
Min	.2263	.7922	.6979	.6602	.4854	.7545	.7167
Avg	1.0374	1.0832	1.0303	.9119	1.0230	1.0537	1.0858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

SWARGATE SUB-DN.[605] BU 4605

Substation No/ Name :- 213006 / 22/11 KV GULTEKADI

Feeder No / Name : 208 / 11 KV MAHARSHINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.7545	.6602	.6224	.8299	1.0562	.9431
2	.679	.7167	.6036	.5847	.8299	1.0185	.8676
3	.6413	.679	.547	.5281	.811	.9808	.8299
4	.6036	.679	.6224	.5093	.7733	.9431	.9054
5	.679	.6413	.7545	.6602	.7733	1.094	1.1694
6	1.0185	1.1317	.7545	.7356	1.0374	1.1317	1.3203
7	1.6975	1.6409	.9997	.7922	1.5089	1.4335	1.6221
8	1.9239	1.905	1.1694	1.1317	1.7164	1.5844	1.6598
9	2.2634	2.2634	1.358	1.2071	1.8298	2.1285	2.1285
10	2.1502	2.1879	1.5844	1.2071	1.8671	2.1285	2.1285
11	1.7353	1.8861	1.5089	1.3203	1.7177	1.9418	1.9418
12	1.6221	1.6975	1.358	1.2071	1.7177	2.0165	1.7177
13	1.3203	1.5089	1.2071	1.5466	1.4563	1.3443	1.6804
14	1.2803	1.6221	1.1317	1.3203	1.3443	1.3817	1.531
15	1.3203	1.4335	1.094	1.1317	1.307	1.3817	1.531
16	1.3203	1.3817	1.094	1.2826	1.3957	1.5089	1.5089
17	1.358	1.419	1.094	1.094	1.4712	1.5844	1.5844
18	1.3203	1.3817	1.0562	1.2449	1.6221	1.358	1.5278
19	1.5089	1.531	1.0562	1.3957	1.5466	1.6221	
20	1.358	.9335		1.358	1.4712	1.4335	1.6787
21	1.3203	.8215	.9808	1.2449	1.358	1.3957	1.5089
22	1.1694	.7733	.7545	1.1317	1.2071	1.2071	1.226
23	.9054	.6979	.7356	.9619	1.1317	1.0185	.9997
24	.7356	.7733	.7167	.679	.8865	1.094	.9808
Max	2.2634	2.2634	1.5844	1.5466	1.8671	2.1285	2.1285
Min	.6036	.6413	.547	.5093	.7733	.9431	.8299
Avg	1.2770	1.2692	.9931	1.0374	1.3171	1.4078	1.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

SWARGATE SUB-DN.[605] BU 4605

Substation No/ Name :- 213006 / 22/11 KV GULTEKADI

Feeder No / Name : 209 / 11 KV Idea Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5466	1.5655	1.5466	1.5278	1.5089	1.5466	1.5089
2	1.5089	1.5278	1.5089	1.4712	1.4901	1.3717	1.4712
3	1.4712	1.4901	1.4901	1.4523	1.4712	1.4712	1.3957
4	1.4523	1.4712	1.4523	1.4335	1.4712	1.4335	1.4712
5	1.5089	1.5278	1.5089	1.4901	1.4901	1.3717	1.5278
6	1.5278	1.5466	1.5466	1.5278	1.5089	1.5278	1.5655
7	1.6032	1.6409	1.5844	1.5466	1.6032	1.5844	1.6409
8	1.6032	1.6221	1.6032	1.5844	1.6032	1.6409	1.6221
9	1.6787	1.6975	1.6975	1.6787	1.643	1.7177	1.6991
10	1.773	1.7918	1.7541	1.6787	1.7364	1.7364	1.7177
11	1.7918	1.8296	1.8107	1.7918	1.7551	1.7737	1.8111
12	1.7918	1.8107	1.7918	1.8107	1.7551	1.7924	1.8298
13	1.7918	1.7918	1.7918	1.7353	1.7737	1.8111	1.8298
14	1.7918	1.773	1.773	1.7164	1.7737	1.7737	1.7924
15	1.7918	1.773	1.8107	1.773		1.8111	1.8298
16	1.8296	1.6991	1.8296	1.6787	1.7164	1.8296	1.8673
17	1.773	1.6617	1.7164	1.7164	1.6975	1.773	1.7541
18	1.6975	1.6617	1.7541	1.6598	1.6787	1.7541	1.6975
19	1.7164	1.6804	1.7164	1.6787	1.6787	1.7541	
20	1.6975	1.6991	1.6787	1.6409	1.6598	1.7353	1.7353
21	1.6221	1.6244	1.6598	1.7164	1.5844	1.6598	1.6409
22	1.6409	1.6032	1.6221	1.6221	1.6032	1.6221	1.6598
23	1.6221	1.6032	1.6221	1.6221	1.6409	1.6221	1.6221
24	1.5655	1.5844	1.5655	1.5466	1.5278	1.5844	1.5466
Max	1.8296	1.8296	1.8296	1.8107	1.7737	1.8296	1.8673
Min	1.4523	1.4712	1.4523	1.4335	1.4712	1.3717	1.3957
Avg	1.6582	1.6532	1.6598	1.6292	1.6248	1.6541	1.6625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213016 / 22/11 KV KHADAKWASLA

Feeder No / Name : 201 / DHAYARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6139	2.0538	1.587	2.4272	1.8671	1.307	
2	2.4272	1.8671	2.5206	2.3339	1.8671	1.1203	2.0538
3	2.0538	1.6804	2.4272	2.5206	1.6804	1.1203	1.8671
4	1.8671	1.8671	2.1472	2.0538	1.8671	.9335	2.2405
5	2.1472	2.2405	2.2405	2.1472	2.2405	1.4937	2.6139
6	2.2405	2.7073	3.2341	2.6139	2.6139	2.0538	2.9874
7	2.5206	3.3608	3.6408		2.9874	3.5475	2.6139
8	2.9874	2.8006	2.894		2.7073	2.894	4.2943
9	2.5206	2.7073	2.9874	2.7073	2.6139	3.0807	2.7073
10	3.0807	4.0143	3.1741	2.8006	3.5475	4.481	4.7611
11	2.9569	3.1741	3.5475	2.7349	3.1741	4.1076	3.5475
12		2.2405	2.9874	2.7073	3.6408	4.481	4.5744
13		3.6408	2.9874	1.8652	2.7073	4.2943	3.9209
14		3.3265	2.8006	2.3339	2.894	4.201	4.1076
15	2.4272	3.5475	3.5475	2.3339	2.894	4.2943	4.3429
16	1.1203	3.7342	3.7342	1.8671	2.9874	4.1076	3.9609
17	1.4003	4.1076	3.5475	1.8671	2.8006	3.2674	3.7342
18	2.9874	3.5475	3.4541	2.4272	3.6408	3.8666	4.2505
19	3.1741	3.3608	3.1741	2.6139	3.9209		
20	2.6139	2.6139	2.3339	2.6139	2.6139	2.5206	2.3339
21		2.8006	2.1472			3.1741	3.2674
22		2.8006	1.9605			2.8006	3.5475
23		3.0807	2.9874			2.4272	
24	2.894	2.5206	2.7073	2.3339	2.0538	1.4003	2.6139
Max	3.1741	4.1076	3.7342	2.8006	3.9209	4.481	4.7611
Min	1.1203	1.6804	1.587	1.8652	1.6804	.9335	1.8671
Avg	2.4463	2.9081	2.8654	2.3844	2.7295	2.9119	3.3496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213016 / 22/11 KV KHADAKWASLA

Feeder No / Name : 202 / SHIVANE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9335	1.1203	1.1203	.9335	1.1203	1.1203
2	.8402	.8402	1.1203	1.0269	.9335	.9335	.9335
3	.7468	.8402	1.1203	1.0269	.8402	.8402	.8402
4	.7468	.9335	1.1203	1.0269	1.0269	.8402	.8402
5	1.1203	1.1203	1.307	1.0269	1.2136	1.0269	1.1203
6	1.4937	1.4937	1.5708	1.4937	1.4937	1.4003	1.6804
7	1.8671	1.9605	1.8671		2.1472	2.1472	2.0538
8	1.8671	1.9605	1.9605		2.1472	2.2405	2.2405
9	1.8671	2.0538	1.8671	2.3339	2.1472	2.5206	2.4272
10	1.8671	2.4272	2.2405	2.4272	2.4272	2.5206	2.5206
11	1.7737	2.2405	2.6139	2.4272	2.2779	2.7073	2.5206
12		2.0538	2.4272	2.2634	2.1472	2.3339	2.2405
13		1.6804	2.2405	1.5708	1.7737	1.9605	1.587
14		2.0538	2.0538	1.7737	2.1472	2.1472	2.0538
15	1.307	1.9605	2.0538	1.8671	1.8671	2.0538	2.0328
16	1.307	2.0538	1.9605	1.6804	1.8671	2.1472	1.9909
17	1.307	2.0538	1.9605	1.6804	1.9605	2.1472	2.0538
18	1.4003	1.8671	2.0538	1.6804	1.6804		1.9404
19	1.4003	1.7737	2.0748	1.7737	1.8671	1.9909	
20	1.4003	1.587	1.8671	1.587	1.2136	1.7737	1.6804
21		1.4937	1.6804			1.6804	1.4937
22		1.307	1.587			1.4003	1.307
23		1.2136	1.4003			1.2136	
24	1.0269	1.0269	1.2136	1.3443	1.1203	1.2136	1.2136
Max	1.8671	2.4272	2.6139	2.4272	2.4272	2.7073	2.5206
Min	.7468	.8402	1.1203	1.0269	.8402	.8402	.8402
Avg	1.3485	1.6220	1.7701	1.6385	1.6777	1.7548	1.7223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213016 / 22/11 KV KHADAKWASLA

Feeder No / Name : 203 / WADGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.5658	.7468	.4715	.3772	.3772	.2801
2	.3772	.4715	.7468	.4715	.2829	.2829	.2801
3	.2829	.3772	.8402	.4715	.2829	.2829	.2801
4	.2829	.3772	.8402	.3772	.2829	.2829	.2801
5	.2829	.3772	.7468	.3206	.2829	.2829	.2801
6	.2829	.3772	.8962	.3206	.2829	.2801	.2801
7	.3772	.3772	1.1203		.3772	.3772	.2801
8	.3772	.3772	1.587		.3772	.3772	.4668
9	.3734	.5601	1.8671	.4668	.5658	.5658	.5601
10	.4715	.7468	1.8671	.5601	.6535	.6602	.6535
11	.4668	.6535	2.1472	.6535	.7762	.7545	.6535
12		.6535	1.9605	.5544	.8402	.6535	.8402
13		.6535	1.6804	.4191	.7468	.6535	.5601
14		.6535	1.4003	.5601	.6535	.5601	.5601
15		.6535	1.307	.4668	.8402	.5601	.5487
16		.9335	1.6632	.5601	.7468	.6602	.543
17		.0747	1.6632	.5601	.8402	.5601	.6468
18	.2801	.6535	.4668	.4715	.7468	.4525	.5544
19	.2829	.6535	.5601	.4668	.6535	.462	
20	.3734	.6602	.462	.4668	.4668	.3734	.4715
21		1.4003	.4108			.3772	.3734
22		1.1203	.3734			.2801	.2801
23		.9335	.3772			.2801	
24	.2829	.5658	.8402	.3772	.3772	.2829	.2801
Max	.4715	1.4003	2.1472	.6535	.8402	.7545	.8402
Min	.2801	.0747	.3734	.3206	.2829	.2801	.2801
Avg	.3448	.6196	1.1071	.4745	.5454	.4450	.4524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213016 / 22/11 KV KHADAKWASLA

Feeder No / Name : 204 / NARHE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.2801	.3772	.3206	.2801	.3734	.3734
2	.2801	.2801	.3772	.3206	.2801	.2801	.2801
3		.2801	.3772	.3018	.2801	.2801	.2801
4	.2801	.2801	.3772	.3018	.2801	.3361	.2801
5	.2801	.2801	.3772	.3206	.2801	.3734	.2801
6	.3734	.2801	.3734	.3772	.2801	.3734	.3734
7	.3734	.3734	.3734		.3734	.4668	.4668
8	.3734	.4668	.5601		.4668	.5601	.4668
9	.4668		.7468	.6535	.7468	.8488	.7468
10	.543	.9335	.9335	.8402	1.0269	1.0269	1.0269
11	.6535	1.0269	1.0269	1.0269	1.1203		1.2136
12		.8402	1.0269	.9335	1.1203	.9335	1.1203
13		.8402	.9335	.6535	.8402	.8402	.7468
14		.9335	.9335	.7468	.9431	.9335	.9335
15		1.0269	1.0269	.8402	1.0269	.9335	1.0164
16		.9335	1.0269	.8402	.9335	.905	.924
17		.9335	1.0269	.7468	.8402	.823	1.0164
18	.4668	.8402	.9335	.8402	.9335	.9335	.8316
19	.4668	.8402	.8402	.7468	.8402	.8488	
20	.4668	.6602	.6535	.6535	.6535	.6535	.6468
21		.5658	.5228			.4668	.5601
22		.3772	.4668			.4668	.4668
23		.3772	.3772			.3734	
24	.3734	.2801	.3734	.3772	.3734	.3734	.3734
Max	.6535	1.0269	1.0269	1.0269	1.1203	1.0269	1.2136
Min	.2801	.2801	.3734	.3018	.2801	.2801	.2801
Avg	.4122	.6056	.6684	.6233	.6628	.6263	.6556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213016 / 22/11 KV KHADAKWASLA

Feeder No / Name : 205 / 11 KV Kirkitwadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0377	.0377
2	.0366	.0366	.0377
3	.0366	.0366	.0377
4	.0366	.0366	.0377
5	.0366	.0366	
6	.0366	.0366	.0377
7	.0366	.0366	.1132
8	.0914	.0914	.0943
9	.0943	.0943	
10	.0905	.0934	
11	.0934	.0943	
12		.0943	
13		.0934	
14		.0943	
15	.0934	.0943	
16		.0943	
17	.0934	.0943	
18	.0934	.0943	
19	.0943	.0934	
20	.0943	.0943	
21		.0943	
22		.0943	
23		.0377	
24	.0366	.0914	.0377
Max	.0943	.0943	.1132
Min	.0366	.0366	.0377
Avg	.0665	.0748	.0542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213016 / 22/11 KV KHADAKWASLA

Feeder No / Name : 306 / IAT

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1431	.4001	.4668	1.5242	1.3336	1.307
2	1.1431	1.3336	.3429	.4668	1.5242	1.1431	1.1203
3	1.1431	1.1431	.3429	.439	1.3336	1.1431	1.1203
4	1.7147	1.5242	.3429	.4001	1.5242	1.1431	1.307
5	2.0957	1.9052	.5335	.4572	2.2862	2.0957	1.6804
6	2.8578	2.4768	.8002	.6287	2.6673	2.4768	2.4272
7	3.8104	3.6199	.9145		3.2388	3.4294	3.3608
8	4.0009	3.8104	1.267		4.0009	3.6199	3.7342
9	1.5432	2.9874	3.2065	1.7909	1.0288	3.8104	3.2388
10	1.5432	3.1741	2.8292	1.4937	1.0002	3.6199	3.0483
11	1.1393	2.7435	2.8006	1.3432	.8573	3.0483	
12		2.6673	2.0748	1.0288	.8002	2.8578	2.8292
13		2.2634	2.0748	.5601	.743	2.0957	1.9052
14		2.2634	2.2634	.7011	.8002	2.4768	1.848
15		2.2634	1.8671	1.6975	2.0538	2.4768	.7202
16		2.4272	.985	1.6804	2.2405	1.1145	.8573
17	2.2405	2.4272	1.0974	1.8861	2.2405	1.2536	.9145
18	2.4272	2.6406	1.0745	2.0538	2.2634	1.0517	1.0745
19	2.6139	2.6406	2.6139	2.6406	2.8006	1.3146	
20	2.6673	2.6406	1.2269	2.452	2.8006	1.2269	1.0669
21		.9907	.7602			2.6406	2.6139
22		.9145	.7602			2.4272	2.452
23		.5601	.6001			1.8671	
24	1.5242	1.3336	.4668	.5335	1.7147	1.5242	1.4937
Max	4.0009	3.8104	3.2065	2.6406	4.0009	3.8104	3.7342
Min	1.1393	.5601	.3429	.4001	.743	1.0517	.7202
Avg	2.1005	2.1622	1.3186	1.1958	1.8782	2.1330	1.9105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213312 / 22KV RAJYOG SUB STATION

Feeder No / Name : 201 / RAJYOG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2263	.1886		.1867		.2263
2		.1886	.1698		.1663		.1886
3		.2263	.1698		.1886		.2263
4		.2641	.1867		.1848		.2641
5		.2263	.2012		.2427		.2614
6		.2641	.2054		.2772		.2987
7		.2641	.2263		.3206		.3361
8		.3395	.2987		.3961	.4435	.4435
9		.3772	.3961		.4207		.4066
10	.3696	.3395	.415	.3772	.415	.4527	
11	.3326	.415	.3395	.415	.3772	.415	
12	.2987	.3018	.3395	.4527	.3772	.3395	
13	.2641	.3395	.3018	.3772	.3395	.3395	
14	.2218	.3018	.3018	.3395	.3018	.3018	
15	.2587	.2641	.2641	.3018	.2263	.2641	
16	.2263	.2241	.2641				.2641
17	.2263	.2263	.2561				.2987
18	.2641	.2641	.2957				.2772
19	.3395	.2957	.2957				.3547
20	.3772	.3361	.3734				.3584
21	.3018	.3206	.3361				.3326
22		.2614	.3206	.3018		.2987	
23	.2263		.2402	.2641		.2614	
24		.2614	.1829		.2075		.1886
Max	.3772	.415	.415	.4527	.4207	.4527	.4435
Min	.2218	.1886	.1698	.2641	.1663	.2614	.1886
Avg	.2852	.2838	.2737	.3537	.2893	.3462	.2954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213312 / 22KV RAJYOG SUB STATION

Feeder No / Name : 202 / 11KV MANIK BAUG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8299	.9145		1.8671		1.1694
2		.8676	.8596		1.7177		1.2071
3		.7922	.8316		1.5684		1.2449
4		.7545	.8596		1.7924		1.2071
5		.8676	.8962		1.8656		1.1203
6		.9431	1.0562		2.0485		.9709
7		1.0562	1.3392		2.268		1.0456
8		1.3203	1.4003		2.4806		1.2197
9		1.8484			3.1459		1.5893
10		2.3388	2.4897	1.8484	3.5082	2.452	
11		2.452	2.5274	1.9993	3.0556	2.452	
12		2.3011	2.3388	1.9616	3.2065	2.5274	
13	1.2071	1.6598	1.6975	1.5089	1.6598	1.8484	
14	1.2936	2.1125	2.0748	1.7353	1.9239	2.3011	
15	1.2936	2.037	2.1879	1.8484	2.0748	2.1125	
16	1.3203	2.0538	2.2634				2.3011
17	1.4335	2.0182	2.1216				2.2965
18	1.4712	1.8861	2.0698				2.0883
19	1.3957	2.0328	1.848				2.1472
20	1.358	1.6617	1.9418				1.8296
21	1.4335	1.0562	1.531				1.5893
22		1.3014	1.3203	1.226			1.3203
23	.8962			1.8839			1.1694
24	1.3336	.9431	1.2826		2.0485		1.1694
Max	1.4712	2.452	2.5274	1.9993	3.5082	2.5274	2.3011
Min	.8962	.7545	.8316	1.226	1.5684	1.8484	.9709
Avg	1.3124	1.5276	1.6296	1.7515	2.2645	2.2822	1.4825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213312 / 22KV RAJYOG SUB STATION

Feeder No / Name : 203 / 11 kv wanjale bridge
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545					
2		.6413					
3		.6036					
4		.5658					
6		.7167					
7		.7922					
8		1.1694					
9		1.3203					
10		1.2826		1.1317	1.1694	1.2826	
11		1.2449		1.1694	1.3203	1.2449	
12		1.0185		1.0185	1.0185	.9877	
13		.9808		.8676	1.0562	.8676	
14		1.0185		.7922	.9808	.9054	
15		1.0456		.7545	1.0185	.7922	
16	1.0185						1.0185
17	1.2071						1.0269
18	.8299		1.1088				1.0903
19	1.1317		1.0349				1.2323
20	1.0562		1.0082				1.1506
21	.9054		.9335				1.0349
23	.7167		1.0082				
24		.679					
Max	1.2071	1.3203	1.1088	1.1694	1.3203	1.2826	1.2323
Min	.7167	.5658	.9335	.7545	.9808	.7922	1.0185
Avg	.9808	.9222	1.0187	.9557	1.0940	1.0134	1.0923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213312 / 22KV RAJYOG SUB STATION

Feeder No / Name : 204 / 11 KV DATTAKRUSHNAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)
16		1.643
17	1.7193	1.7918
18	1.848	1.7926
19	2.0328	2.3339
20	2.3152	2.3765
21	2.0911	2.2177
23	1.7353	
Max	2.3152	2.3765
Min	1.7193	1.643
Avg	1.9570	2.0259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213312 / 22KV RAJYOG SUB STATION

Feeder No / Name : 205 / Aux.feeder for station
transfo Feeder KV- 11 / OUTGOING

DATE	10-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)
16	.3772	.3395
17	.3658	.3206
18	.3511	.3326
19	.3511	.3547
20	.3361	.3018
21	.3361	.2957
Max	.3772	.3547
Min	.3361	.2957
Avg	.3529	.3242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213315 / 22/11 KV TUKAINAGAR

Feeder No / Name : 201 / Vikasnagar
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3961	.415	.415	.415	.415	.4527
2	.3734	.3772	.3772	.3772	.3734	.3772	.4338
3	.3734	.3772	.3395	.3395	.3395	.3395	.4338
4	.3772	.3772	.3395	.3395	.3395	.3395	.4338
5	.4108	.3961	.4527	.3772	.3772	.3772	.4715
6	.679	.6602	.5658	.4527	.6413	.5281	.6224
7	.9431	.9242	.9431	.679	.9054	.7468	.8865
8	.9808	1.1883	.9431	.9431	1.094	1.1203	1.0751
9	.9808	1.0082	.9335	.8962	.9335	1.0829	.8962
10	.8488	.8589	.8589	.8215	.7842	.9335	.7468
11	.6602	.7167	.6722	.8215	.6348	.7468	.6722
12	.5093	.5658	.7095	.7095	.5601	.5601	.5601
13	.4904	.5228	.5228	.6348	.5601	.5228	.5601
14	.4338	.4108	.5228	.5228	.4481	.4481	.4481
15	.3961	.4481	.4854	.5281	.4481	.4481	.4854
16	.4108	.4108	.4904	.547	.4904	.415	.4481
17	.4481	.4854	.5281	.5093	.4904	.5281	.4854
18	.4854	.5601	.6224	.5281	.5847	.5093	.5975
19	.7468	.7468	.8488	.7922	.811	.7922	.8215
20	.7468	.8589	.811	.811	.811	.8488	.7842
21	.7468	.7842		.7922	.7842	.7733	.7842
22	.6979	.7095	.6348	.6722	.7095	.7167	.7095
23	.5658	.5975	.5975	.6348	.5975	.6036	.5975
24	.4481	.4715	.4527	.4527	.4527	.4527	.5093
Max	.9808	1.1883	.9431	.9431	1.094	1.1203	1.0751
Min	.3734	.3772	.3395	.3395	.3395	.3395	.4338
Avg	.5904	.6189	.6116	.6082	.6077	.6094	.6215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213315 / 22/11 KV TUKAINAGAR

Feeder No / Name : 202 / RAMNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6602	.679	.679	1.358	.6413	.7167
2	.6036	.6036	.6413	.6413	1.2449	.6036	.6602
3	.5658	.6036	.6036	.6036	1.2071	.5658	.6602
4	.5601	.6036	.6036	.6036	1.2071	.5658	.6602
5	.6413	.6036	.6413	.679	1.3203	.6413	.679
6	.8589	.9431		.7167	1.9993	.8299	.9054
7	1.0829	.7733	1.094	.8676	2.4897	.9431	1.2071
8	1.2696	1.4146	1.3203	1.2071	2.9801	1.3203	1.5089
9	1.3957	1.4377	1.4937	1.1949	3.1367	1.4563	1.4937
10	1.2637	1.3817	1.4937	1.307	2.9127	1.4563	1.3817
11	1.2826	1.3443	1.307	1.3817	2.8753	1.3443	1.5123
12	1.1317	1.2696	1.419	1.307	2.6139	1.419	1.3817
13	1.0374	1.0829	1.1203	1.0456	1.1576	1.0456	1.307
14	.9808	1.1203	1.1949	1.0829	1.0829	1.1203	1.1203
15	.9808	1.0829	1.0829	.9054	1.1203	1.0829	1.1576
16	1.1203	1.0456	1.094	.9997	1.1317	1.094	1.0829
17	1.1576	1.1576	1.226	.9431	1.1883	1.094	1.0829
18	1.0829	1.1576	1.4523	1.0751	1.2826	1.1128	1.2696
19	1.4563	1.531	1.6409	1.3769	1.5655	1.3957	1.6057
20	1.419	1.4937	1.5466	1.3769	1.5466	1.5278	1.531
21	1.307	1.419		1.226	1.3817	1.3769	1.4937
22	1.1506	1.1203	1.1576	2.3152	1.1203	1.1883	1.2136
23	.9431	.9709	.9709	1.9418	.9709	1.0185	.9709
24	.7545	.7545	.7545	.7545	1.4712	.6413	.811
Max	1.4563	1.531	1.6409	2.3152	3.1367	1.5278	1.6057
Min	.5601	.6036	.6036	.6036	.9709	.5658	.6602
Avg	1.0318	1.0656	1.1153	1.0930	1.6819	1.0619	1.1422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213315 / 22/11 KV TUKAINAGAR

Feeder No / Name : 203 / 11 KV Pawjai

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6036	.6036	.6036	.6413	.6413	.7545
2	.6036	.5658	.5658	.5658	.5658	.6036	.679
3	.5658	.5658	.5281	.5281	.5658	.5658	.679
4	.5658	.6036	.5281	.5281	.5658	.5658	.679
5	.6413	.6224	.6036	.6602	.6413	.679	.7167
6	.9808	1.1506	.9808	.7922	1.094	.9431	1.0374
7	1.5089	1.4146	1.5089	1.0562	1.4563	1.2826	1.4712
8	1.773	1.773	1.6598	1.419	1.6617	1.6804	1.7164
9	1.5466	1.6244	1.6804	1.4563	1.4937	1.4937	1.4563
10	1.2071	1.2696	1.307	1.4563	1.307	1.2696	1.2323
11	1.0374	1.0456	1.1576	1.307	.9335	1.1203	1.1949
12	.811	.8962	.9335	1.1203	.8215	.8962	.9709
13	.7545	.7095	.8962	.8589	.7842	.8962	.8589
14	.6979	.6722	.6722	.8589	.6722	.7468	.7468
15	.679	.6348	.7095	.7167	.7468	.7468	.7095
16	.6348	.5975	.7167	.7356	.679	.6602	.6348
17	.6348	.6348	.7545	.7733	.679	.8865	.7468
18	.7468	.8215	.9997	.8676	.9619	.8865	.8962
19	1.2323	1.2323	1.3392	1.3014	1.3014	1.1883	1.3817
20	1.2696	1.1949	1.3203	1.3203	1.3392	1.3769	1.3817
21	1.2323	1.307		1.3203	1.307	1.1317	1.307
22		1.1576			1.1203	1.1317	1.1576
23	.9242	.8962	.9335	.9335	.9335	.9619	.9709
24	.7167	.7545	.7167	.7167	.7167	.7167	.7922
Max	1.773	1.773	1.6804	1.4563	1.6617	1.6804	1.7164
Min	.5658	.5658	.5281	.5281	.5658	.5658	.6348
Avg	.9307	.9478	.9598	.9520	.9579	.9613	1.0072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213315 / 22/11 KV TUKAINAGAR

Feeder No / Name : 204 / 11 KV Bhansali Campus

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2075	.1886	.1886	.1886	.1886
2	.1509	.1698	.1886	.1886	.132	.1509	.1509
3	.132	.1698	.1509	.1509	.1509	.132	.1509
4	.132	.1698	.1509	.1509	.132	.132	.1509
5	.1867	.1886	.1886	.1509	.1886	.1509	.1698
6	.2263	.2452	.2263	.2075	.2263	.2075	.2075
7	.4527	.3206	.3395	.2641	.3395	.2829	.3018
8	.4527	.4904	.415	.3395	.4527	.4108	.4527
9	.5281	.4668	.4481	.3361	.4108	.4108	.4854
10	.4904	.5228	.4854	.4481	.4108	.4481	.4481
11	.4715	.2614	.4108	.4854	.3361	.4108	.4481
12	.3395	.1867	.4481	.4108	.3734	.3734	.3734
13	.3584	.2054	.3734	.3361	.2614	.2614	.3361
14	.2829	.1494	.2614	.2614		.2614	.2427
15	.2263	.3361	.2614		.2614	.2241	.2427
16	.2614	.2614	.2641	.3018	.2641	.2641	.2614
17	.2614	.2614	.2829	.2641	.2829	.2641	.2987
18	.2614	.2614	.3018	.2829	.2829	.2452	.2987
19	.3361	.3547	.3584	.3961	.3584		.3361
20	.3361	.3361	.3584	.3395	.3395	.3018	.3361
21	.3361	.2987		1.3203	.2987	.3206	.2987
22		.2987	1.1203	.2987	.2614	.3018	.2987
23	.2641	.2241	.2614	.2614	.2427	.2452	.2614
24	.2263	.2263	.2075	.2075	.2075	.1886	.2263
Max	.5281	.5228	1.1203	1.3203	.4527	.4481	.4854
Min	.132	.1494	.1509	.1509	.132	.132	.1509
Avg	.3001	.2748	.3352	.3301	.2784	.2686	.2902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213315 / 22/11 KV TUKAINAGAR

Feeder No / Name : 205 / 11 KV Damodarnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3584	.3395	.3018	.3395	.415
2	.3018	.3206	.3395	.3395	.2641	.3018	.3584
3	.3018	.3206	.3206	.3018	.2641	.2641	.3584
4	.3018	.3206	.3206	.3018	.3018	.2641	.3772
5	.3772	.3395	.3772	.3395	.3018	.3395	.3961
6	.5658	.547	.4527	.3772	.5281	.4904	.4904
7	.7167	.6979	.7545	.4904	.679	.6036	.7545
8	.8488	.9054	.8676	.7167	.9808		.8865
9	.8299	.8029	.8029	.7095	.7842	.8962	.8215
10	.6979	.6722	.7842	.7842	.7842	.7842	.7468
11	.679	.6348	.6348	.7095	.6348	.7468	.6348
12	.5281	.5228	.6722	.6348	.5228	.6348	.5601
13	.4715	.4481	.5228	.4481	.5601	.5228	.5601
14	.4715	.4481	.5228	.4481	.5228	.4854	.4481
15	.4904	.4854	.4854	.4527	.3734	.5228	.5228
16	.4481	.4481	.5093	.4904	.5281	.5281	.4854
17	.4481	.5601	.5658	.5093	.5281	.6036	.5601
18	.4481	.5601	.6602	.5281	.6602	.5847	.6036
19	.6722	.7842	.7545	.7167	.7545	.7356	.8215
20	.6722	.7842	.7545	.7167	.811	.7922	.7842
21	.5975	.6722		.7167	.7095	.811	.7468
22		.6348	.6722	.5601	.5975	.679	.6348
23	.4527	.5228	.4854	.4481	.5228	.547	.5281
24	.3395	.3772	.3772	.3772	.3395	.3772	.4527
Max	.8488	.9054	.8676	.7842	.9808	.8962	.8865
Min	.3018	.3206	.3206	.3018	.2641	.2641	.3584
Avg	.5217	.5479	.5650	.5190	.5523	.5589	.5812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213315 / 22/11 KV TUKAINAGAR

Feeder No / Name : 301 / TUKAINAGAR
Feeder KV- 22 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6406	3.546	2.4897	2.1125	2.4143	2.7161	2.5652
2	2.4143	3.546	2.4143	2.1125	2.3388	2.5652	2.5652
3	1.9616	3.4705	2.6406	2.5652	2.5652	2.4143	2.5652
4	1.8861	3.7723	3.1687	2.6406	2.7161	2.7915	3.6214
5	1.9616	3.7723	3.6969	3.4705	3.0933	3.546	3.7723
6	1.5844	3.7723	3.7715	3.6969	3.6591	3.6591	3.8477
7	.9808	3.7346	3.7346	3.7723	3.8855	3.81	3.7723
8	.4904	3.7346	3.6595	3.6591	3.6969	3.6214	3.8477
9	.0754	3.7715	4.1823	3.3608	3.3981	3.5101	4.369
10		4.1076	4.0329	4.0329	4.0329	3.8836	4.3381
11		4.0329	3.9582	3.3608	4.1823	4.0329	4.257
12	.0754	3.9582	3.9582	3.5848	3.5848	3.9582	
13		3.9209	3.9582	3.4355	3.5848		3.5848
14	.0754	3.9956	3.3608	3.4355	3.4355	3.5101	3.5848
15	.0754	3.9582	3.6595	3.546	3.4355	3.5848	3.5475
16	.0328	3.5848	3.3951	3.4705	3.3951	3.546	3.6214
17	.0328	3.3608	3.4705	3.3951	3.4328	3.6591	3.5101
18	.0373	3.4355	3.5082	3.5082	3.4705	3.4705	3.546
19	.0747	***		3.6214	3.5082	3.4705	3.7342
20	.0747	3.5101	3.6214	3.1687	3.0933	3.1687	3.1367
21	.0747	3.062		2.8292	3.062	2.9801	3.1367
22		2.4272	2.5019	2.9874	2.5393	2.6029	2.6139
23	2.2634	2.332	2.5019	2.5393	2.4646	2.6406	2.5393
24	3.0178	3.131	2.5652	2.4897	2.4897	3.0178	2.6406
Max	3.0178	35.6242	4.1823	4.0329	4.1823	4.0329	4.369
Min	.0328	2.332	2.4143	2.1125	2.3388	2.4143	2.5393
Avg	.9915	4.8984	3.3750	3.1998	3.2283	3.3113	3.4225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213336 / 22/11 KV DSK S/SN

Feeder No / Name : 201 / 11 KV KAILAS JEEVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.8488	.8488	.8488		.8488	.7545
2	.6535	.7545	.7545	.7545		.7545	.7545
3	.6535	.7545	.7545	.6602		.7545	.6602
4	.7468	.6602	.6602	.6602		.6602	.6602
5	.8316	.6602	.6602	.7545		.6602	.6602
6	1.1203	1.226	1.1317	.8488		1.226	1.226
7	1.6804	1.6975	1.5089	1.226	1.587	1.6975	1.6975
8	1.9605	2.0748	1.8671	1.5089	2.0538	1.8671	1.8861
9	1.6804	1.7918	1.8861	1.8671	1.7737	1.8671	1.8671
10	1.4003	1.587	1.6804	1.8671	1.587	1.6804	1.587
11	1.2012	1.2936	1.587	1.6804	1.2936	1.4784	1.386
12	1.0974	1.2403	1.4003	1.4937	1.0974	1.2803	1.2936
13	.9145	1.0745	1.1203	1.2136	1.0745	.9955	.985
14		.985	.9335	1.1203	.964	.8859	.985
15	.724	.985	.9335	1.1203	.9536	.8859	.8859
16	.7164	.905	.905	.9145	.8669	.9335	.9335
17	.7164	.9955	.985	.905	.8478	.9335	1.1203
18	.9145	1.0974	1.2012	.9955	.964	1.1203	1.1203
19	1.307	1.386	1.4784	1.4003	1.2936	1.307	1.4937
20	1.307	1.386	1.4003	1.4003	1.4003	1.4003	1.4937
21	1.307	1.4003	1.307	1.307	1.307	1.307	1.4003
22	1.307	1.307	1.1317	1.1203	1.1203	1.2136	1.307
23	1.1317	1.1317	1.0374	1.0269	1.0269	1.1317	1.2136
24	.8402	.9335	.9431	.9431		.9335	.9431
Max	1.9605	2.0748	1.8861	1.8671	2.0538	1.8671	1.8861
Min	.6535	.6602	.6602	.6602	.8478	.6602	.6602
Avg	1.0851	1.1740	1.1715	1.1516	1.2477	1.1593	1.1798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213336 / 22/11 KV DSK S/SN

Feeder No / Name : 202 / 11 KV ESHA RAYKARMALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1867	.1886	.1867	.1867	.1867
2	.1867	.1867	.1867	.1886	.1867	.1867	.1867
3	.0934	.0934	.0934	.0943	.0943	.0934	.0934
4	.0934	.0934	.0934	.0943	.0934	.0934	.0934
5	.1867	.1867	.1867	.1886	.1867	.1867	.1867
6	.2801	.1867	.1867	.1886	.2801	.1867	.1867
7	.2829	.2801	.1867	.2829	.2801	.2801	.2801
8	.4668	.3734	.2801	.3772	.3734	.3734	.3734
9	.3734	.2801	.3734	.2829	.3734	.3734	.2801
10	.2829	.2801	.3734	.3734	.2801	.3734	.2801
11	.2829	.2801	.2241	.3734	.2801	.2801	.2801
12	.2829	.1867		.3734	.2801	.1867	.1867
13	.1886	.1867	.1867	.2801	.1867	.1867	.1867
14	.1886	.1867	.1867	.1867	.1867	.1867	.0934
15	.1886	.1886	.1867	.1867	.1867	.1867	.1867
16	.0934	.1886	.1886	.1867	.1867	.1867	.1886
17	.1867	.1886	.1886	.1867	.1867	.1867	.1867
18	.1867	.1886	.1886	.1867	.1867	.1867	.1867
19	.2801	.2829	.1886	.2801	.2801	.1867	.2801
20	.2801	.2829	.2829	.2801	.2801	.2801	.2801
21	.2801	.2829	.2829	.2801	.2801	.2801	.2829
22	.1867	.1867	.2829	.2801	.2801	.2801	.2801
23	.1867	.1867	.1886	.1867	.1867	.1867	.1867
24	.1867	.1867	.1867	.1886	.1867	.1867	.1867
Max	.4668	.3734	.3734	.3772	.3734	.3734	.3734
Min	.0934	.0934	.0934	.0943	.0934	.0934	.0934
Avg	.2263	.2146	.2135	.2381	.2295	.2217	.2141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213336 / 22/11 KV DSK S/SN

Feeder No / Name : 203 / 11 KV SAVITRI GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4715	.5658	.5658	.4763	.4715	.4715
2	.3734	.3772	.3772	.4715	.381	.3772	.3772
3	.3734	.3772	.3772	.3772	.381	.3772	.3772
4	.4668	.3772	.3772	.3772	.3772	.3772	.3772
5	.5601	.3772	.3772	.4715	.5658	.3772	.3772
6	.8402	.6602	.6602	.6602	.8402	.6602	.6602
7	1.1317	1.1317	1.0374	.8488	1.226	1.226	1.226
8	1.4937	1.4146	1.4146	1.226	1.3203	1.4146	1.4146
9	1.307	1.226	1.226	1.3203	1.1203	1.3203	1.226
10	1.0269	.8488	1.1317	1.1317	1.0374	1.0374	.9431
11	.8402	.7545	.9431	1.1317	.7545	.8488	.7545
12	.6535	.7545	.7545	.8488	.6602	.7545	.6602
13	.5601	.5658	.5658	.7545	.5658	.6602	.5601
14	.5601	.5658	.5601	.6535	.5658		.5658
15	.7468	.5601	.5658	.6602	.4715	.6602	.5658
16	.4715	.5601	.5601	.5658	.5601	.5658	.5658
17	.5658	.5601	.6535	.6602	.6535	.5658	.6602
18	.5658	.7468	.7468	.7545	.7468	.6602	.7545
19	.8488	.9335	.9335	.9431	.9335	.9431	.9431
20	.8488	.9335	.9335	.9335	.9335	.9431	1.0269
21	.8488	.9335	.9335	.9335	.9431	.9335	.9431
22	.7545	.8488	.9431	.9431	.8488	.8488	.8488
23	.6602	.7545	.7545	.7468	.6602	.6602	.7545
24	.4668	.5658	.6602	.6602	.5658	.5658	.5658
Max	1.4937	1.4146	1.4146	1.3203	1.3203	1.4146	1.4146
Min	.3734	.3772	.3772	.3772	.3772	.3772	.3772
Avg	.7265	.7208	.7522	.7767	.7329	.7499	.7341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213336 / 22/11 KV DSK S/SN

Feeder No / Name : 301 / 22 KV DSK VISHWA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3696	.3696	.3658	.3658	.3696	.3696
2	.3658	.3734	.3734	.3658	.3658	.3734	.3734
3	.3658	.3734	.3772	.3696	.3658	.3772	.3772
4	.3658	.3772	.3772	.3696	.3658	.3772	.3772
5	.3658	.3772	.3772	.3734	.3696	.3772	.3772
6	.5544	.5658	.3772	.3734	.3696	.3772	.3772
7	.5658	.7545	.5658	.3772	.5658	.5658	.5658
8	.7392	.7468	.5601	.7545	.7316	.7545	
9	.7392	.7545	.7545	.7545	.5601	.7545	.7545
10	.5658	.7545	.5487	.7545	.7545	.7545	.7545
11	.5544	.5601	.5544	.7392	.5601	.5658	.5601
12	.5487	.5544	.5544	.5544	.5544	.5544	.5601
13	.5487	.362	.5544	.5487	.543	.543	.362
14	.3582	.3582	.5487	.5487	.3658	.362	.3658
15	.3506	.362	.362	.3696	.362	.3658	.3658
16	.3544	.362	.3696	.362	.362	.3658	.3658
17	.3391	.5144	.3582	.3696	.3582	.3696	.5487
18	.3506	.5316	.543	.5487	.3467	.3696	.3658
19	.543	.7316	.5487	.5544	.5373	.5544	.5487
20	.543	.724	.543	.5487	.5544	.5544	.5601
21	.7087	.543	.5544	.5487	.5601	.5601	.5487
22	.5487	.5544	.5487		.5487	.5487	.5487
23	.5601	.5544	.5487		.5544	.5544	.5544
24	.3658	.3658	.3658	.3658	.3658	.3658	.3658
Max	.7392	.7545	.7545	.7545	.7545	.7545	.7545
Min	.3391	.3582	.3582	.362	.3467	.362	.362
Avg	.4861	.5219	.4848	.4962	.4745	.4881	.4760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213373 / 22/11 kV Narhe Substation

Feeder No / Name : 201 / Atma Poultry

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.9431	.7922	.7545	
11	.7922	.7545	.8299	
12	.7922	.7545	.8299	
13	.6036	.5281	.5658	
14	.7167	.679	.679	
15	.7167		.679	
16	.6036		.5281	.7167
17	.6036		.5658	.6979
18	.5658		.5658	.6413
19	.7167		.6036	
20	.5093		.6036	.679
21	.5847		.6036	.5658
22				.5658
23				.4527
Max	.9431	.7922	.8299	.7167
Min	.5093	.5281	.5281	.4527
Avg	.6790	.7017	.6507	.6170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213373 / 22/11 kV Narhe Substation

Feeder No / Name : 202 / 11 kV AMBEGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.4712	1.8861	2.0748	
11	1.2449	1.773	1.9616	
12	1.1317	1.7353	1.8484	
13	.9054	1.2826	1.3957	
14	1.0562	1.6598	1.773	
15	.9808		1.8484	
16	.9431		1.8484	1.8861
17	.9431		1.8861	1.8296
18	.9808		1.6598	1.7353
19	1.0185		1.7353	1.6598
20	.8676		1.4335	1.5844
21	.8676		1.358	1.3203
22				1.1694
23				1.0185
Max	1.4712	1.8861	2.0748	1.8861
Min	.8676	1.2826	1.358	1.0185
Avg	1.0342	1.6674	1.7353	1.5254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213373 / 22/11 kV Narhe Substation

Feeder No / Name : 203 / Aditya Sanskruti

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	12-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.9054	1.2449	1.1694	
11	.8676	1.1317	1.358	
12	.7545	1.1317	1.1694	
13	.5658	.7545	.8676	
14	.6413	.9431	1.094	
15	.5658		1.0185	
16	.5658		1.0562	1.094
17	.5658		1.0185	1.094
18	.679		.9808	1.0562
19	.7545		1.0374	.8676
20	.7167		.9431	1.0374
21	.679		.8676	.8299
22				.7922
23				.6036
Max	.9054	1.2449	1.358	1.094
Min	.5658	.7545	.8676	.6036
Avg	.6884	1.0412	1.0484	.9219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213388 / 22/11 KV ABHIRUCHI

Feeder No / Name : 201 / 11 kv GOEL GANGA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1867	.1867	.1867	.1867	.1867	.2303
2	.1829	.1867	.1905	.1867	.1867	.1867	.2103
3	.1829	.1867	.1905	.1886	.1867	.1867	.2103
4	.2195	.1867	.1905	.1867	.1867	.1867	.1949
5	.2561	.2241	.1867	.1867	.2427	.1867	.1791
6	.2926	.2801	.2987	.2801	.3174	.2801	.2926
7	.4024	.3734	.3734	.2801	.3734	.3547	.4572
8	.4755	.5041	.4108	.4668	.4668	.5601	.4755
9	.4755	.5601	.4481	.4668	.4668	.4938	.4572
10	.439	.4572	.5121	.5121	.4207	.5121	.439
11	.439	.4572	.439	.4755	.439	.439	.4024
12	.4024	.3841	.439	.439	.3109	.3292	.3658
13	.3292	.3475	.3841	.3658	.3109	.2926	.2926
14	.2926	.3292	.2926	.2926	.3109	.2926	.2926
15	.2926	.3292		.3658	.2926	.3109	.2926
16	.2561	.2561	.2926	.3292	.2561	.2926	.2561
17	.3018	.2926	.2926	.3658	.2926	.2561	.2926
18	.3109	.3292	.2926	.4024	.3292	.2926	.2926
19	.4024	.439	.439	.439	.4572	.3658	.4755
20	.4024	.4024	.4755	.4755	.4024	.439	.4755
21	.439	.439	.439	.4755	.4755	.439	.439
22		.4108	.4294	.4481	.4108	.4024	.4024
23	.3734	.0373	.4108	.3734	.2241	.3292	.3658
24	.2195	.2241	.2801	.1867	.1886	.2241	.2658
Max	.4755	.5601	.5121	.5121	.4755	.5601	.4755
Min	.1829	.0373	.1867	.1867	.1867	.1867	.1791
Avg	.3307	.3260	.3432	.3490	.3223	.3266	.3357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213388 / 22/11 KV ABHIRUCHI

Feeder No / Name : 202 / 11 kv bhidewadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826	.9526	1.1431	.9526	.9431	.9526	.9242
2	1.2449	.9526	1.1431	.9526	.9431	.9526	.9054
3	1.2071	.9526	1.1431	.9526	.9526	.9526	.8764
4	1.1317	.9431	1.1431	.9526	.9526	.9526	.8954
5	1.2071	1.1317	1.1317	.9431	1.226	1.1317	.9054
6	1.3957	1.4146	1.3203	.9997	1.4146	1.226	1.3957
7	2.037	2.037	1.6975	1.4146	1.9616	1.7918	2.2068
8	2.6406	2.5274	2.452	2.3577	2.6217	2.452	2.4143
9	2.4143	2.3388	2.4143	2.5463	2.3577	2.5652	2.4331
10	2.2634	2.32	2.5274	2.452	2.5463	2.5274	2.4143
11	1.9616	2.1691	2.3765	2.4897	2.3011	2.3388	2.0748
12	1.7353	2.0182	2.037	2.1502	2.0748	2.1502	2.037
13	1.4712	1.7164	1.7164	1.6221	1.8673	1.6221	1.6975
14	1.5089	1.773	1.1317	1.6975	1.6787	1.6975	1.7353
15	1.3957	1.773		1.6221	1.6598	1.6787	1.7353
16	1.4335	1.8484	1.5729	1.5466	1.4335	1.7353	1.6221
17	1.4335	1.8484	1.773	1.6221	1.5844	1.6975	1.8861
18	1.4523	1.773	1.7353	1.6221	1.6975	1.6975	1.773
19	1.9616	2.2257	2.1502	1.7353	2.1691	1.9616	2.1502
20	1.8861	2.1125	1.9993	2.037	1.9239	1.9239	2.0748
21	1.8484	1.9616	1.773	1.9239	1.8484	1.8484	1.8107
22		1.8861	1.6032	1.6975	1.6975	1.358	1.6598
23	1.4335	1.5089	1.358	1.5089	1.3203		1.358
24	1.3203	1.1317	1.226	1.1317	1.1431	1.1317	1.0374
Max	2.6406	2.5274	2.5274	2.5463	2.6217	2.5652	2.4331
Min	1.1317	.9431	1.1317	.9431	.9431	.9526	.8764
Avg	1.6377	1.7215	1.6769	1.6221	1.6799	1.6672	1.6676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213401 / 22/11 kv Prayeja

Feeder No / Name : 201 / 11 KV PRAYEJA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7356	1.6975	.7545		.7922	.811
2	.7922	.7167	1.5466	.7167		.7545	.7356
3	.7545	.7167	1.5089	.7167		.7167	.7167
4	.7167	.6979	1.5089	.6979		.6979	.7545
5	.7545	.7545	1.6032	.7545		.7167	.9242
6	1.0374	.9808	1.9805	.8488		.9054	1.226
7	1.4523	1.5466	2.5652	1.094		1.2637	1.4901
8	1.7918	1.7918	3.5837	1.3957		1.8484	1.9239
9	1.7918	1.7918	3.8666	1.7918		1.9427	1.8673
10	1.5278	1.6787	3.6214	1.8861		1.6787	1.7353
11	1.4712	1.5466		1.8296		1.6221	1.6221
12	1.226	1.4146		1.6598		1.5089	1.5089
13	1.1128	1.1506	2.2257	1.5089	1.1317	1.1506	1.1694
14	1.0751	1.1694	2.6029	1.3203	1.226	1.2449	1.2826
15	1.0374	1.1506	2.4331	1.2071	1.1694	1.1128	1.2071
16	1.0185	1.1317	2.3765	1.2071	1.1506	1.226	1.2826
17	1.3203	1.358	1.4712	1.3014	1.358	1.226	1.358
18	1.2826	1.4523	1.5466	1.358	1.5089	1.3392	1.4901
19	1.6221	1.7353		1.6975	1.8296	1.6032	1.773
20	1.6598	2.5274	1.7353	1.6032	1.6975	1.5278	1.7164
21	1.6032	2.7726	1.5844		1.5466	1.5089	1.5466
22	1.4335	2.584	1.3957		1.358	1.3957	1.4712
23	1.0562	2.0936	1.1694		1.094	1.094	1.094
24	.8676	.8488	1.9239	.8596		.8488	.8865
Max	1.7918	2.7726	3.8666	1.8861	1.8296	1.9427	1.9239
Min	.7167	.6979	1.1694	.6979	1.094	.6979	.7167
Avg	1.2150	1.4311	2.0927	1.2481	1.3700	1.2386	1.3164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213401 / 22/11 kv Prayeja

Feeder No / Name : 202 / 11 KV ZAGADE GOTHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.1157	1.0974	1.2437		1.0791	1.134
2	1.0425	1.0608	1.0425	1.0974		1.0425	1.0791
3	1.0425	1.0425	1.0425	1.0608		1.0608	1.0974
4	1.0608	1.0425	1.0608	1.0608		1.0791	1.0242
5	1.1888	1.0974	1.0974	1.0974		1.0974	1.262
6	1.4632	1.3169	1.262	1.1706		1.4266	1.4632
7	2.1033	1.9753	1.6461	1.5912		1.8839	2.0485
8	2.2314	2.3594	2.0668	2.0485		2.3228	2.5789
9		2.4326	2.3045	2.3228		2.5057	2.4691
10	2.0851	2.1948	2.652	2.7984		2.7618	2.3411
11	1.8656	2.268	2.3777	2.7435		2.4143	2.1948
12	1.4998	2.0119	2.3411	2.5423		2.268	1.9753
13	1.6644	1.8656	2.1216	2.1948	.9145	2.0302	1.9387
14	1.4632	1.6461	1.829	1.8656	.8962	1.6461	1.6461
15	1.4083	1.5466	1.7375	1.7193	.9511	1.7741	1.5364
16	1.3535	1.6461	1.6461	1.6461	1.6644	1.4632	1.4998
17	1.7558	1.6827	1.7193	1.701	1.6827	1.7375	1.6461
18	1.6095	1.8107	1.829	1.7193	1.6461	1.7375	1.7558
19	1.829	1.8656	2.5972	2.0485	1.957	2.0668	2.1033
20	1.8656	1.9387	2.0851	1.9204	2.0119	1.9753	2.0119
21	1.9204	1.9204	2.0119		2.0485	2.0119	1.9753
22	1.8473	1.829	1.9204		1.9387	1.7741	1.9022
23	1.4632	1.4449	1.6095		1.5546	1.6095	1.4815
24	1.2803	1.2803	1.2986	1.3169		1.2437	1.2254
Max	2.2314	2.4326	2.652	2.7984	2.0485	2.7618	2.5789
Min	1.0425	1.0425	1.0425	1.0608	.8962	1.0425	1.0242
Avg	1.5713	1.6831	1.7665	1.7576	1.5696	1.7505	1.7246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213437 / 22/11kv TAKSHASHILA

SUBSTATION

Feeder No / Name : 201 / 11 kv sai dham

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0754	.1132	.1509	.1132	.0754
2	.0377	.0377	.0377	.0754	.0754	.0377	.0377
3	.0754	.0377	.0377	.0754	.0754	.0754	.0377
4	.1132	.0377	.0377	.1132	.1132	.0754	.1509
5	.1509	.0754	.0754	.1886	.1509	.1132	.1886
6	.1886	.1509	.1132	.3395	.2263	.1509	.2641
7	.3018	.2641	.1509	.415	.3018	.2263	.3395
8	.3395	.3206	.2263	.4527	.3018	.3018	.4527
9	.3772	.3018	.3018	.3772	.3018	.3395	.3395
10	.2829	.2641	.3018	.3395	.2641	.3395	.3395
11	.2263	.2263	.2829	.3395	.2263	.2641	.2263
12	.1886	.2263	.2263	.2641	.1886	.2263	.2263
13	.1509	.2263	.2263	.2263	.1886	.1886	.1509
14	.1132	.1886	.1886	.1886	.1509	.2263	.1509
15	.1132	.1132	.1132	.1509	.1494		.1509
16	.1132	.1509	.1132	.1132	.1886		.1509
17	.1132	.1509	.1509	.0754	.1867		.1509
18	.1132	.0754	.1886	.1132	.1886		.1886
19	.2641	.1509	.2641	.2641	.2801		.2641
20	.2641	.3018	.2641	.2641			
21	.2641	.2641	.2263	.2641	.2801		.2641
22	.2263	.2263	.2263	.2263	.2263	.2263	.2263
23	.1886	.1509	.1886	.1886	.1509	.1886	.1509
24	.0754	.0754	.1132	.1509	.1886	.0754	.1509
Max	.3772	.3206	.3018	.4527	.3018	.3395	.4527
Min	.0377	.0377	.0377	.0754	.0754	.0377	.0377
Avg	.1800	.1690	.1721	.2216	.1981	.1864	.2034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213437 / 22/11kv TAKSHASHILA

SUBSTATION

Feeder No / Name : 202 / 11 KV JSPM FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.7545	.4904	1.0185	.8299	.7922	.9054
2	.7922	.7167	.4527	.9808	.7545	.7922	.8676
3	.9054	.7545	.4527	.9431	.7922	.9054	.9054
4	1.358	.9054	.5658	.9054	.9431	.9054	1.1317
5	1.3203	1.2449	.6036	1.0185	1.1694	1.2449	1.358
6	1.7353	1.7353	.6036	1.5844	1.4712	1.5844	1.5089
7	2.037	1.8861	.679	2.0748	1.9993	1.7353	1.9239
8	2.0748	2.037	.7167	2.1125	1.9616	2.037	2.3388
9	2.1125	2.0748	.9431	2.037	2.037	2.1502	2.037
10	1.7541	1.8861	.9808	1.8861	1.8861	1.9239	1.7353
11	1.6598	1.5844	.8488	1.5844	1.6221	1.6598	1.5466
12	1.5466	1.5466		1.4335	1.4335	1.5089	1.4335
13	1.2071	1.3957	.7922	1.2449	1.2449	1.358	1.3203
14	1.1694	1.2071	.6036	1.1317	1.1317		1.1694
15	1.094	1.2071	.6224	1.094	1.2323		1.2071
16	1.1317	1.1694	.679	1.0562	1.1203		1.2071
17	1.0562	1.2826	1.1317	1.1317	1.2136		1.358
18	1.1317	1.358	1.4712		1.2136		1.3203
19	1.5089	1.4712	1.8484	1.6598	1.6804		1.773
20		1.4712	1.6221	1.5844			1.6975
21	1.4335	.7545	1.5089	1.5466	1.4937		1.5466
22	1.358	.679	1.3203	1.3957	1.4712	1.358	1.3957
23	1.094	.5658	1.1317	1.0562	1.0185	1.0185	1.1317
24	.8676	.7922	.4904	1.0562	.8676	.8676	.9431
Max	2.1125	2.0748	1.8484	2.1125	2.037	2.1502	2.3388
Min	.7922	.5658	.4527	.9054	.7545	.7922	.8676
Avg	1.3556	1.2700	.8939	1.3711	1.3299	1.3651	1.4067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213437 / 22/11kv TAKSHASHILA

SUBSTATION

Feeder No / Name : 203 / 11 kv siddhi lawns

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	1.1694	.3395	.3395	.3018	.3395
2	.3018	.2641	1.1694	.3018	.3018	.3018	.3395
3	.2641	.2263	1.1317	.3018	.2263	.2641	.3018
4	.3018	.2263	1.1694	.3395	.3395	.2641	.2641
5	.3395	.2263	1.3203	.4904	.4527	.9619	.2641
6	.415	.3018	1.6598	.5658	.6036	.415	.3395
7	.5281	.3395	2.037	.8299	.7545	.5281	.6036
8	.6036	.6036	2.4143	.9054	.7922	.7545	.9054
9	.8676	.8299	2.8292	.8676	.8299	.8676	.7545
10	.7167	.7545	2.8669	.7922	.679	.7167	.6036
11	.679	.679		.7545	.6036	.6413	.5658
12	.679	.5658	2.452	.7167	.5658	.6036	.4904
13	.4527	.5281	2.037	.5658	.5281	.5658	
14	.415	.4527	1.8484	.4904	.4527		.415
15	.415	.5093	1.9239	.4904	.4481		.415
16	.415	.5281	1.8861	.4904	.4668		.415
17	.415	.4904	.4904	.5281			.4527
18	.415	.5281	.5281	.5658	.4668		.5281
19	.4527	.5281	.6413	.6036	.6535		.6413
20	.5658	1.8861	.6413	.6036			.5658
21	.5658	1.6598	.5658	.5658	.5601		.5281
22	.4904	1.4712	.4904	.5281	.5281	.4904	.4904
23	.3772	1.358	.415	.415	.415	.415	.415
24	.3395	.3018	1.1317	.3772	.3395	.3395	.3772
Max	.8676	1.8861	2.8669	.9054	.8299	.9619	.9054
Min	.2641	.2263	.415	.3018	.2263	.2641	.2641
Avg	.4700	.6468	1.4269	.5596	.5158	.5270	.4789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

PARVATI DIVISION[310]

WADGAON SUB-DN.[677] BU 4677

Substation No/ Name :- 213437 / 22/11kv TAKSHASHILA

SUBSTATION

Feeder No / Name : 204 / 11 KV PRABHAT PRESS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.3203	2.452	2.037	1.6975	1.8484	1.8861
2	1.773	1.358	2.4143	1.9993	1.5466	1.8107	1.8484
3	1.6975	1.3957	2.4143	1.8861	1.5089	1.8107	1.8107
4	1.6975	1.5089	2.2634	1.6975	1.6221	1.6975	1.773
5	1.7353	1.5844	2.2634	1.8861	1.6975	1.8484	1.6975
6	1.773	1.6598	2.3011	2.0748	1.7353	1.8484	1.8484
7	1.8861	1.8484	2.6406	2.1125	1.773	2.037	1.9239
8	1.9239	2.037	3.7723	2.2257	2.2634	2.3011	2.2257
9	1.8861	2.5652	4.3381	2.7161	2.8669	2.9047	2.7538
10	1.9616	2.7915		3.5837	3.5082	3.4328	3.2442
11	1.9993	3.131	4.9983	3.4705	3.5837	3.546	3.5837
12	2.037	3.3573	4.904	3.0556	3.4705	3.5837	3.4705
13	1.6975	2.6783	4.3381	2.4897	2.8292	2.7538	3.2065
14	1.6598	3.0933	4.0741	3.4328	3.2065		3.131
15	1.7353	3.5271	4.5268	3.3573	3.5848		3.5837
16	1.6598	3.3951	4.4513	2.7161	3.5475		3.6214
17	1.5844	3.4328	3.5082	2.6783	3.2674		3.2065
18	1.4335	3.4705	3.2065	2.6406	3.1741		2.8669
19	1.358	2.8669	2.8669	2.452	2.894		2.9801
20	1.4335	1.8861	2.4897	2.2257	2.4272		2.5652
21		3.0556	2.2634	1.9616	2.3339		2.452
22	1.3203	2.2257	2.1125	1.8484	2.1502	2.037	2.0748
23	1.3957	2.6406	2.1125	1.5844	2.1125	1.9616	2.1125
24	1.8107	1.358	2.4897	2.0748	1.7353	1.8861	1.9239
Max	2.037	3.5271	4.9983	3.5837	3.5848	3.5837	3.6214
Min	1.3203	1.3203	2.1125	1.5844	1.5089	1.6975	1.6975
Avg	1.7074	2.4245	3.1827	2.4253	2.5223	2.3317	2.5746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

KASBA SUB-DN.[609]

BU 4609

Substation No/ Name :- 213012 / KASBA PETH SUB-DIV

Feeder No / Name : 201 / Surya Hospital

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.4805	.4805	.4435	.4435	.5175	.5544
2	.4435	.4435	.4435	.4066	.4066	.4435	.5175
3	.4435	.4435	.4435	.4066		.4435	.5175
4	.4435	.4435	.4435	.4066	.4066	.4435	.5175
5	.4435	.4805	.4435	.4435	.4066	.4805	.5175
6	.5544	.5544	.4805	.4435	.4805	.5175	.5544
7	.6653	.7392	.5914	.5175	.6653	.6283	.7023
8	.924	.924	.8131	.6653	.8131	.8501	.8871
9	.9979	.924	.8871	.7762	.8501	.8871	.924
10	.8501	.8871	.8501	.8779	.8131	.924	.924
11	.8131	.8131	.8501	.924	.8131	.8501	.8501
12	.7023	.8131	.8131	.8131	.7762	.8131	.7392
13	.7762	.7762	.7392	.6653	.7316	.7762	.7762
14	.6653	.6653	.6283	.6219	.695	.6653	.6653
15	.5914	.5914	.5914	.5544	.6283	.6283	.6653
16	.5914	.5914	.6283	.5544	.6283	.6283	.6219
17	.6584	.7023	.6653	.5544	.6653	.6283	.6653
18	.7762	.7762	.7023	.5914	.7392	.7762	
19	.9145	1.0242	.924	.8131	.961	1.0349	.9979
20	.9054	.961	.961	.8131	.924	.961	.961
21	.8131	.8131	.8131	.7762	.8501	.924	.8501
22	.7392	.7023	.7392	.7023	.7392	.7762	.7392
23	.6283	.5914	.6283	.6283	.6283	.6283	.6283
24	.5544	.5175	.4805	.4805	.4805	.5175	.5544
Max	.9979	1.0242	.961	.924	.961	1.0349	.9979
Min	.4435	.4435	.4435	.4066	.4066	.4435	.5175
Avg	.6823	.6941	.6684	.6200	.6759	.6976	.7100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

KASBA SUB-DN.[609]

BU 4609

Substation No/ Name :- 213012 / KASBA PETH SUB-DIV

Feeder No / Name : 202 / Gundacha Ganpati

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7316	.8048	.7392	.7392	.7316	.8048
2	.7316	.695	.7682	.7023	.7023	.7316	.7682
3	.7316	.695	.7682	.6653	.6653	.7316	.7682
4	.7316	.7316	.7682	.6653	.6653	.7316	.7682
5	.7316	.7682	.8413	.7023	.6653	.8048	.8413
6	.9145	.9877	.8779	.7392	.924	.8413	.9145
7	1.1827	1.2437	1.0974	.8501	1.2197	1.0719	1.2323
8	1.5524	1.5729	1.39	1.2567	1.4784	1.4632	1.4998
9	1.5364	1.6461	1.4998	1.5154	1.5524	1.5364	1.5893
10	1.4266	1.4632	1.4632	1.5524	1.4415	1.4632	1.4784
11	1.1706	1.3169	1.2437	1.3306	1.2197	1.3535	1.2197
12	.9877	1.0974	1.134	1.2197	1.0349	1.2071	.8002
13	.9145	1.0242	1.0242	1.0719	.9511	.961	.9979
14	.8048	.9145	.8779	.924	.8413	.924	.8871
15	.7762	.8501	.8501	.8131	.8501	.8131	.8871
16	.7392	.8131	.7762	.8131	.8048	.7762	.8501
17	.8131	.8871	.8871	.8501	.8413	.8871	.924
18	.961	1.1088	.9979	.9979	1.0608	1.0719	1.1088
19	1.2197	1.3306	1.7741	1.2936	1.2803	1.3169	1.3676
20	1.1827	1.3676	1.2936	1.2936	1.3169	1.2803	1.4045
21	1.2071	1.2437	1.2197	1.2197	1.2197	1.2803	1.2071
22	1.0974	1.134	1.1088	1.1088	1.1706	1.2071	1.2071
23	.9511	.9511	.9979	.9979	.9511	1.0059	1.0242
24	.8048	.7682	.8048	.7762	.7762	.7682	.8048
Max	1.5524	1.6461	1.7741	1.5524	1.5524	1.5364	1.5893
Min	.7316	.695	.7682	.6653	.6653	.7316	.7682
Avg	.9974	1.0559	1.0529	1.0041	1.0155	1.0400	1.0565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

KASBA SUB-DN.[609] BU 4609

Substation No/ Name :- 213012 / KASBA PETH SUB-DIV

Feeder No / Name : 204 / OH I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6283	.924	.924		.8871	1.0349	1.0349
2	.5914	.8501	.8871	.8871	.8501	.9979	.9979
3	.5544	.8501	.8871	.8501	.8501	.9979	.9979
4	.5544	.8871	.8871	.8501	.8501	.9979	.9979
5	.5544	.961	.961	.8871	.8501	1.0349	1.0719
6	.7023	1.1088	.9979	.924	1.1088	1.0349	1.1458
7	.961	1.5524	1.3306	1.1827	1.5154	1.2936	1.5524
8	1.2567	1.8107	1.7002	1.5154	1.8111	1.7002	1.7741
9	1.3306	1.885	1.885	1.8111	1.848	1.922	1.9589
10	1.1827	1.848	1.885	1.7372	1.922	1.9959	1.848
11	1.1458	1.7002	1.7741	1.7002	1.7741	1.848	1.848
12	1.0349	1.5524	1.7002	1.5893	1.5893	1.5893	1.7002
13	.9979	1.5154	1.5524	1.4784	1.5729	1.4784	1.5893
14	.961	1.4784	1.3306	1.2936	1.39	1.2936	1.4784
15	.8871	1.3306	1.2936	1.1088	1.3306	1.2197	1.4415
16	.8131	1.2936	1.2567		1.2567	1.1827	1.4045
17	.961	1.4045	1.2936	1.1088	1.3676	1.2936	1.4415
18	1.4415	1.5893	1.4415	1.1827	1.5154	1.5154	1.6263
19	1.6632	1.848	1.7741	1.6263	1.8111	1.7741	1.922
20	1.6263	1.7002	1.7002	1.5893	1.7372	1.7372	1.7372
21	1.5154	1.5893	1.5154	1.4784	1.5893	1.5893	1.6263
22	1.3306	1.3676	1.3306	1.3306	1.4415	1.5154	1.4415
23	1.1458	1.1458	1.2197	1.1458	1.1458	1.2567	1.2567
24	.6653	.961	.961	.9979	.961	1.0349	1.0349
Max	1.6632	1.885	1.885	1.8111	1.922	1.9959	1.9589
Min	.5544	.8501	.8871	.8501	.8501	.9979	.9979
Avg	1.0210	1.3814	1.3537	1.2852	1.3740	1.3891	1.4553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

KASBA SUB-DN.[609] BU 4609

Substation No/ Name :- 213012 / KASBA PETH SUB-DIV

Feeder No / Name : 302 / 22 KV PMC Express Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.1886	.1886	.1905	.1886	.1886	.1886
2	.1886	.1886	.1886	.1905	.1886	.1886	.1886
3	.1886	.1886	.1886	.1905	.1886	.1886	.1886
4	.1886	.1886	.1886	.1905	.1886	.1886	.1886
5	.2641	.1886	.1886	.1905	.1886	.1886	.1886
6	.1886	.1886	.1886	.1905	.1886		.1886
7	.1886	.1886	.1886	.1905	.2263	.1886	.1886
8	.3395	.1886	.1886	.1905	.2263	.3018	.3395
9	.3772	.415	.3772	.415	.3429	.3018	.3395
10	.3395	.3395	.3395	.3395	.3395	.3395	.3395
11	.415	.3395	.415	.3395	.1905	.3395	.3395
12	.3395	.3395	.3395	.3395	.1524	.3292	.3395
13	.3395	.3395	.3395	.415	.1494	.3395	.3395
14	.2641	.3018	.3395	.3395		.3395	.3429
15	.2641	.2263	.3361	.3395	.1509	.3395	.3429
16	.2641	.1886	.3018	.2263	.2263	.3395	.3018
17	.3395	.3395	.3018	.2641	.3018	.2641	.2263
18	.3018	.3018	.2641	.2263	.3018	.3018	.2641
19	.3395	.3395	.2987	.2263	.3018	.3395	.3395
20	.2641	.3395	.2987	.3395	.3018	.3395	.3018
21	.1886	.3018	.3018	.3395	.3018	.3395	.3018
22	.1829	.3018	.3018	.3395	.2641	.3018	.3018
23	.1886	.2641	.3018	.3395	.1886	.1886	.3018
24	.2641	.1886	.1886	.1905	.1886		.1886
Max	.415	.415	.415	.415	.3429	.3395	.3429
Min	.1829	.1886	.1886	.1905	.1494	.1886	.1886
Avg	.2701	.2656	.2731	.2726	.2298	.2807	.2738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 201 / Alpana

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.8402	.9335	.8402	.924	.924	.8962
2	.7468	.7468	.7468	.7468	.8316	.8316	.7842
3	.7468	.7468	.7468	.7468	.8316	.8316	.7468
4	.7468	.7468	.7468	.7468	.8316	.8316	.724
5	.9335	.9335	.9335	.8402	.924	.924	.8962
6	1.307	1.2136	1.1203	.9335	1.1088	1.1088	1.1203
7	1.587	1.7737	1.4003	1.307	1.4784	1.2936	1.531
8	1.9605	1.9605	1.6804	1.4937	1.848	1.7556	1.848
9	2.0538	2.1472	1.9605	1.9605	1.8671	2.0538	2.0328
10	1.9605	2.3339	2.1472	2.0538	1.9605	2.1472	2.2177
11	2.1472	2.4272	2.1285	2.1472	1.9605	2.4272	2.3101
12	1.9605	2.2405	2.1472	2.1472	2.0538	2.2405	2.2177
13	1.8671	2.3339	2.0538	1.9605	1.8671	2.0538	2.1253
14	1.7737	1.9605	1.8671	1.7737	1.8671	1.8671	1.9404
15	1.7737	1.7737	1.7737	1.4937	1.7737	1.7737	1.9404
16	1.7737	1.848	1.848	1.5708	1.6632	1.8671	1.587
17	1.7924	1.9404	1.848	1.6632	1.7556	1.9605	1.7737
18	1.9231	2.5206	2.3339	1.7556	1.9404	2.1472	2.3339
19	2.2965	2.5206	2.6797	2.2177	2.4025	2.5206	2.6139
20	2.1845	2.4025	2.5206	2.0538	2.2177	2.4272	2.3339
21	1.6804	1.7556	2.0328	1.7556	1.7556	1.8671	1.8671
22	1.363	1.4003	1.4003	1.4937	1.4784	1.4937	1.4937
23	1.2136	1.2136	1.2136	1.2936	1.2936	1.2696	1.4003
24	1.0269	.9335	1.0269	1.0269	1.1088	1.1088	1.0829
Max	2.2965	2.5206	2.6797	2.2177	2.4025	2.5206	2.6139
Min	.7468	.7468	.7468	.7468	.8316	.8316	.724
Avg	1.5691	1.6964	1.6371	1.5009	1.5727	1.6552	1.6591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 202 / Geeta Society

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.543	.543	.543	.543	.4525	.5121
2	.4525	.4525	.4525	.543	.4525	.4525	.4755
3	.4525	.4525	.4525	.543	.4525	.4525	.4668
4	.4525	.4525	.4525	.543	.4525	.4525	.4572
5	.543	.543	.543	.543	.543	.4525	.5121
6	.724	.724	.724	.543	.6335	.543	.6535
7	.905	.905	.8145	.724	.8145	.724	.8775
8	1.086	.9955	.905	.8145	.9955	.905	.905
9	1.0974	1.1888	1.0974	.9145	1.0974	1.1888	.9955
10	1.0059	1.0974	1.0974	1.0059	1.0974	1.0974	.9955
11	1.0059	1.0974	1.0791	1.0974	1.0974	1.0974	1.086
12	.9145	1.0059	1.0974	.9145	1.0059	1.0059	1.086
13	1.0059	1.0059	1.0059	1.0059	.9145	.9145	.9955
14	.9145	.9145	.9145	.9145	.9145	.823	.905
15	.823	.9145	.823	.7316	.823	.823	.8145
16	.8596	.905	.8145	.724	.8145	.8145	.8145
17	.9335	.905	.8145	.724	.8145	.8145	.8145
18	.8596	.905	.905	.8145	.905	.8145	
19	1.0059	.9955	.9955	.905	.9955	.9955	
20	.9709	.905	.9955	.905	.905	.9955	
21	.8954	.9955	.905	.8145	.905	.905	
22	.7682	.8145	.8145	.724	.8145	.8145	
23	.6335	.724	.724	.6335	.6335	.6401	
24	.543	.543	.543	.6335	.543	.543	.567
Max	1.0974	1.1888	1.0974	1.0974	1.0974	1.1888	1.086
Min	.4525	.4525	.4525	.543	.4525	.4525	.4572
Avg	.8081	.8327	.8131	.7608	.7987	.7801	.7741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 203 / Police Line

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4668	.4668	.4668	.3734	.3734	.3982
2	.3734	.3734	.3734	.3734	.3734	.3734	.3658
3	.3734	.3734	.3734	.3734	.3734	.3734	
4	.3734	.3734	.3734	.3734	.3734	.3734	.3734
5	.4668	.3734	.3734	.3734	.3734	.3734	.4108
6	.5601	.4668	.3734	.3734	.4668	.4668	.5041
7	.6535	.6535	.4668	.4668	.5601	.4668	.6722
8	.6535	.5601	.5601	.5601	.6535	.6535	.6535
9	.7468	.6535	.6535	.6535	.7468	.7468	.8402
10	.8402	.8402	.7468	.6535	.8402	.8402	.9335
11	.9335	.8402	.7655	.6535	.8402	.9335	.9335
12	.8402	.9335	.7468	.6535	.8402	.9335	.9335
13	.8402	.8402	.7468	.6535	.8402	.9335	.9335
14	.7468	.7468	.6535	.5601	.8402	.7468	.9335
15	.8402	.8402	.7468	.5601	.8402	.7468	.8402
16	.8029	.8402	.6535	.5601	.8402	.7468	.9335
17	.8215	.8402	.7468	.5601	.8402	.7468	.7468
18	.7282	.7468	.6535	.5601	.7468	.7468	.7468
19	.7468	.8402	.7468	.6535	.7468	.7468	1.307
20	.6908	.6535	.6535	.5601	.7468	.7468	1.2136
21	.6722	.5601	.5601	.5601	.6535	.5601	1.1203
22	.6348	.5601	.5601	.5601	.5601	.5601	1.1203
23	.5601	.4668	.5601	.5601	.5601	.5228	1.0269
24	.4668	.5601	.4668	.4668	.4668	.4668	.4481
Max	.9335	.9335	.7655	.6535	.8402	.9335	1.307
Min	.3734	.3734	.3734	.3734	.3734	.3734	.3658
Avg	.6558	.6418	.5842	.5329	.6457	.6325	.7995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 205 / ADMIN BUILDING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0183	.0183	.0183	.0185	.0185	.0183
2	.0183	.0183	.0183	.0183	.0185	.0185	.0183
3	.0183	.0183	.0183	.0183	.0185	.0185	.0183
4	.0183	.0183	.0183	.0183	.0185	.0185	.0187
5	.0183	.0183	.0183	.0183	.0185	.0185	.0187
6	.0183	.0183	.0183	.0183	.0185	.0185	.0183
7	.0183	.0183	.0183	.0183	.0185	.0185	.0187
8	.0183	.0183	.0183	.0183	.0185	.0185	.0185
9	.0549	.0549	.0183	.0183	.0366	.0183	.0739
10	.0914	.0732	.0183	.0183	.0732	.0183	.0739
11	.1097	.0914	.0366	.0183	.0914	.0183	.1109
12	.1097	.1097	.0366	.0183	.0914	.0366	.1109
13	.1097	.1097	.0366	.0183	.1097	.0183	.1109
14	.0914	.0914	.0366	.0183	.0914	.0366	.0924
15	.0914	.0914	.0366	.0183	.0914	.0183	.0924
16	.0934	.1109	.0185	.0185	.0924	.0183	.1097
17	.112	.0914	.0185	.0185	.0924	.0183	.1097
18	.0732	.037	.0185	.0185	.0554	.0183	.0549
19	.0549	.037	.0185	.0185	.0185	.0183	.0366
20	.0373	.037	.0185	.0185	.037	.0183	.0183
21	.0366	.0185	.0185	.0185	.0185	.0183	.0183
22	.0183	.0183	.0183	.0185	.0185	.0183	.0183
23	.0183	.0183	.0183	.0185	.0185	.0183	.0183
24	.0183	.0183	.0183	.0183	.0185	.0185	.0185
Max	.112	.1109	.0366	.0185	.1097	.0366	.1109
Min	.0183	.0183	.0183	.0183	.0185	.0183	.0183
Avg	.0528	.0481	.0222	.0184	.0460	.0199	.0507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 206 / Gaffar Baig

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.1888	1.0974	1.0974	1.1888	1.0974	1.134
2	1.0974	1.0974	1.0059	1.0974	1.0059	1.0059	1.0608
3	1.0974	1.0974	1.0059	1.0059	1.0059	.9145	1.0242
4	1.0974	1.0974	1.0059	1.0059	1.0059	.9145	1.0242
5	1.1888	1.0974	1.0974	1.0059	1.0974	.9145	1.0608
6	1.3717	1.3717	1.2803	1.1888	1.2803	1.1888	1.3817
7	1.5546	1.5546	1.3336	1.3717	1.5546	1.3717	1.6827
8	1.829	1.9204	1.6461	1.5546	1.9204	1.7375	1.9204
9	2.0119	2.1948	2.1033	1.9204	2.0119	2.0119	2.1033
10	2.1033	2.2862	2.1033	2.0119	2.1033	2.2862	2.2862
11	2.1033	2.3777	2.1582	2.2862	2.1033	2.2862	2.3777
12	2.0119	2.3777	2.1948	2.2862	2.1033	2.1033	2.1948
13	2.0119	2.4691	2.0119	2.1948	1.9204	2.1033	2.0119
14	1.829	2.1033	1.829	1.9204	1.829	1.829	2.0119
15	1.7375	1.829	1.7375	1.7375	1.7375	1.7375	1.829
16	1.7193	1.7375	1.7556	1.7375	1.6461	1.6461	1.829
17	1.7924	1.829	1.9753	1.829	1.829	1.9204	1.829
18	2.0165	2.0119	2.0119	1.9204	1.829	1.9204	2.0119
19		2.2862	2.2862	2.1948	2.1948	2.2862	2.9264
20	2.2405	2.1948	2.1948	2.0119	2.2862	2.2862	2.7435
21	2.0851	2.0119	2.0119	1.9204	2.1033	2.1033	2.5606
22	1.7741	1.7375	1.7375	1.7375	1.829	1.829	2.1948
23	1.5546	1.5546	1.4632	1.5546	1.5546	1.587	1.9204
24	1.3717	1.2803	1.2803	1.2803	1.3717	1.2803	1.3169
Max	2.2405	2.4691	2.2862	2.2862	2.2862	2.2862	2.9264
Min	1.0974	1.0974	1.0059	1.0059	1.0059	.9145	1.0242
Avg	1.6864	1.7794	1.6803	1.6613	1.6880	1.6817	1.8515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 207 / New City

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.6535	.6535	.6535	.6535	.6535	.6584
2	.5601	.5601	.5601	.5601	.5601	.5601	.6219
3	.5601	.5601	.5601	.5601	.5601	.5601	
4	.5601	.5601	.5601	.5601	.5601	.5601	.6036
5	.6535	.7468	.6535	.6535	.6535	.5601	.6219
6	.8402	.8402	.8402	.7468	.8402	.7468	.823
7	1.0269	1.0269	.8402	.8402	.9335	.8402	.9877
8	1.1203	1.1203	1.1203	1.0269	1.2136	1.2136	1.1203
9	1.2136	1.2136	1.2136	1.1203	1.2136	1.2136	1.2136
10	1.2136	1.307	1.2136	1.1203	1.2136	1.2136	1.307
11	1.307	1.4003	1.3817	1.2136	1.307	1.4003	1.4003
12	1.307	1.4003	1.4003	1.2136	1.307	1.4003	1.4937
13		1.2136	1.307	1.2136	1.2136	1.307	1.307
14	1.307	1.307	1.2136	1.1203	1.2136	1.307	1.4003
15	1.2136	1.2136	1.2136	1.1203	1.2136	1.307	1.307
16	1.3169	1.307	1.307	1.1203	1.2136	1.307	1.307
17	1.2803	1.4003	1.307	1.1203	1.307	1.307	1.4003
18	1.3169	1.4937	1.587	1.307	1.4003	1.4937	1.4937
19	1.6461	1.7737	1.7737	1.587	1.587	1.6804	1.6804
20	1.5684	1.587	1.587	1.4937	1.4937	1.6804	1.6804
21	1.2437	1.307	1.307	1.2012	1.2136	1.307	1.307
22	.9145	.9335	.9335	.9335	1.0269	.9335	1.0269
23	.8402	.8402	.8402	.8402	.8402	.8589	.9335
24	.7468	.6535	.7468	.7468	.7468	.7468	.7499
Max	1.6461	1.7737	1.7737	1.587	1.587	1.6804	1.6804
Min	.5601	.5601	.5601	.5601	.5601	.5601	.6036
Avg	1.0613	1.1008	1.0884	1.0031	1.0619	1.0899	1.1498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 209 / Daruwala Bridge

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.6468	.5544	.5544	.5544	.5544	.5601
2	.5544	.5544	.5544	.5544	.5544	.5544	.5228
3	.5544	.5544	.5544	.5544	.5544	.5544	.5041
4	.5544	.5544	.5544	.5544	.5544	.5544	.5041
5	.6468	.6468	.6468	.5544	.6468	.5544	.5228
6	.8316	.7392	.7392	.6468	.7392	.7392	.7842
7	.924	1.0164	.924	.8316	.924	.924	1.0269
8	1.1088	1.2936	1.1088	1.0164	1.1088	1.0164	1.2012
9	1.2012	1.1888	1.2936	1.1088	1.2012	1.2012	
10	1.2936	1.386	1.2936	1.2936	1.2936	1.386	1.2012
11	1.4937	1.4784	1.46	1.4784	1.386	1.4784	1.4784
12	1.4937	1.4784	1.5708	1.2936	1.386	1.4784	1.4784
13	1.386	1.4784	1.4784	1.2012	1.386	1.386	1.4784
14	1.386	1.386	1.2936	1.2012	1.2936	1.2936	1.386
15	1.2936	1.2936	1.2936	1.1088	1.2012	1.2012	1.2936
16	1.363	1.386	1.2936	1.0164	1.2012	1.2936	1.4784
17	1.4377	1.386	1.386	1.0164	1.2012	1.2936	1.4784
18	1.5123	1.5708	1.5708	1.1088	1.2936	1.386	1.5708
19	1.8111	1.9404	1.9404	1.4784	1.6632	1.7556	1.9404
20	1.6991	1.7556	1.6632	1.386	1.5708	1.6632	1.6632
21	1.307	1.4784	1.4784	1.2936	1.2012	1.386	1.386
22	1.0269	1.0164	1.0164	1.0164	1.0164	1.1088	1.1088
23	.8316	.8316	.7392	.8316	.8316	.8402	.924
24	.6468	.6468	.7392	.6468	.6468	.6468	.7282
Max	1.8111	1.9404	1.9404	1.4784	1.6632	1.7556	1.9404
Min	.5544	.5544	.5544	.5544	.5544	.5544	.5041
Avg	1.1213	1.1545	1.1311	.9895	1.0588	1.0938	1.1400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 210 / Sathe

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5544	.5544	.5544	.5544	.5544	.5601
2	.462	.462	.462	.5544	.462	.462	.5228
3	.462	.462	.462	.462	.462	.462	.4668
4	.462	.462	.462	.462	.462	.462	.4668
5	.5544	.462	.462	.462	.5544	.462	.5228
6	.7392	.5544	.5544	.5544	.6468	.5544	.6535
7	.8316	.7392	.7392	.6468	.8316	.6468	.8589
8	1.0164	.8316	.924	.8316	1.0164	.8316	1.0164
9	1.0164	.924	1.0164	1.0164	1.0164	1.1088	1.0164
10	1.0164	.924	1.0164	1.1088	1.1088	1.2012	1.1088
11	.8316	1.0164	1.0164	1.1088	.924	1.1088	1.0164
12	.7392	1.1088	1.0164	1.1088	.924	1.1088	1.0164
13	.8316	1.1088	.924	1.0164	1.0164	.924	.924
14	.8316	.924	.8316	.924	.924	.924	.924
15	.7392	.8316	.8316	.8316	.8316	.8316	.7392
16	.7095	.8316	.7392	.7392	.7392	.7392	.7392
17	.7655	.7392	.7392	.7392	.7392	.7392	.7392
18	.8029	1.0164	.8316	.7392	.8316	.8316	.924
19	.9896	1.0164	1.0164	.924	1.0164	1.0164	1.0164
20	.9149	1.0164	1.0164	.8316	1.0164	1.0164	.924
21	.8589	.924	.924	.8316	.924	.924	.924
22	.8402	.8316	.8316	.8316	.8316	.8316	.924
23	.7392	.7392	.7392	.7392	.7392	.6908	.7392
24	.6468	.6468	.6468	.6468	.6468	.6468	.6348
Max	1.0164	1.1088	1.0164	1.1088	1.1088	1.2012	1.1088
Min	.462	.462	.462	.462	.462	.462	.4668
Avg	.7648	.7970	.7816	.7777	.8008	.7949	.8074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 212 / Laxmi Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6468	.5544	.5544	.5544	.5544	.6468	.6348
2	.5544	.5544	.5544	.5544	.5544	.5544	.5601
3	.5544	.5544	.5544	.462	.462	.462	.5041
4	.5544	.5544	.5544	.462	.462	.462	.5041
5	.6468	.6468	.6468	.5544	.5544	.5544	.5601
6	.8316	.7392	.8316	.6468	.7392	.7392	.7655
7	1.1088		.924	.8316	.924	.8316	1.0642
8	1.2936	1.2012	1.1088	1.0164	1.2012	1.1088	1.2012
9	1.2936	1.2936	1.386	1.2936	1.2012	1.386	1.3717
10	1.2936	1.386	1.386	1.2936	1.2936	1.4784	1.3717
11	1.2012	1.386	1.386	1.386	1.2936	1.386	1.2936
12	1.1088	1.386		1.1088	1.2012	1.2012	1.2936
13	1.0164	1.2936	1.1088	1.0164	1.1088	.924	1.1088
14	1.0164	1.1088	1.0164	.924	1.0164	1.1088	1.0164
15	1.0164	1.0164	1.0164	.8316	1.0164	1.1088	.6468
16	1.0082	1.0164	1.0164	.7392	1.0164	1.1088	1.1088
17	1.0642	1.1088	1.1088		1.0164	1.1088	1.1088
18	1.1203	1.2012	1.2012	.8316	1.1088	1.2012	1.2012
19	1.2883	1.4784	1.4784	1.1088	1.386	1.4784	1.4784
20	1.251	1.386	1.2936	1.0164	1.2936	1.2936	1.2936
21	1.0829	1.2012	1.1088	.924	1.1088	1.1088	1.2012
22	.9709	.924	.924	.924	1.0164	1.0164	1.0164
23	.8316	.8316	.924	.8316	.8316	1.0269	.924
24	.7392	.6468	.7392	.7392	.6468	.7392	.7207
Max	1.2936	1.4784	1.4784	1.386	1.386	1.4784	1.4784
Min	.5544	.5544	.5544	.462	.462	.462	.5041
Avg	.9789	1.0204	.9923	.8718	.9587	1.0014	.9979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 214 / City Appolo

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.1905
2	.1905	.1905	.1905	.1905	.1905	.1715	.1715
3	.1905	.1905	.1905	.1905	.1715	.1715	.1715
4	.1905	.1905	.1905	.1905	.1715	.1715	.1867
5	.1905	.1905	.1905	.1905	.1905	.1905	.1905
6	.2858	.2858	.2858	.1905	.1905	.1905	.2667
7	.381	.2858	.2858	.2858	.2858	.2858	.3239
8	.381	.381	.381	.2858	.381	.381	.381
9	.381	.4763	.381	.381	.381	.4763	.4763
10	.4763	.4763	.4763	.381	.381	.4763	.4763
11	.4763	.4763	.4954	.4763	.4763	.5716	.4763
12	.4763	.5716	.4763	.4763	.4763	.4763	.4763
13	.4763	.4763	.4763	.4763	.4763	.4763	.4763
14	.4763	.4763	.4763	.381	.4763	.4763	.4763
15	.381	.4763	.4763	.381	.381	.4763	.4763
16	.4382	.4763	.4763	.381	.381	.4763	.4763
17	.0438	.4763	.4763	.381	.381	.4763	.4763
18	.4854	.4763	.4763	.381	.4763	.5716	.4763
19	.5658	.6668	.5716	.4763	.5716	.5716	.5716
20	.5335	.5716	.5716	.4763	.4763	.5716	.4763
21	3.8485	.4763	.4763	.381	.381	.381	.381
22	.0305	.2858	.2858	.2858	.381	.2858	.2858
23	.2858	.2858	.2858	.2858	.2858	.2858	.2858
24	.1905	.1905	.1905	.1905	.1905	.1905	.2286
Max	3.8485	.6668	.5716	.4763	.5716	.5716	.5716
Min	.0305	.1905	.1905	.1905	.1715	.1715	.1715
Avg	.4819	.3850	.3739	.3294	.3477	.3747	.3698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

RASTA PETH SUB-DN.[608] BU 4608

Substation No/ Name :- 213007 / 22/11 KV Rasta s/stn

Feeder No / Name : 216 / Parshi Agyari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	1.0479	1.0479	1.0479	1.0669	1.0479	1.0479
2	.9526	.9526	.9526	.9526	.9526	.9526	.9526
3	.9526	.9526	.9526	.8573	.8573	.9526	.9145
4	.9526	.9526	.9526	.8573	.8573	.9526	.9145
5	1.1431	.9526	.9526	.9526	.9526	1.0479	.9526
6	1.3336	1.2384	1.1431	1.0479	1.2384	1.2384	1.2003
7	1.6194	1.6194	1.3336	1.2384	1.6194	1.3336	1.6575
8	1.9052	2.0005	1.6194	1.5242	1.9052	1.7147	1.7147
9	1.9052	2.0005	2.0005	1.9052	1.9052	2.0005	2.0957
10	1.9052	2.0005	2.0005	1.9052	1.9052	2.0005	2.191
11	1.9052	2.0957	2.0576	2.0005	1.9052	1.9052	2.0005
12	1.8099	2.0957	2.0957	1.9052	1.9052	2.0005	1.8099
13	1.7147	2.0005	1.9052	1.8099	1.8099	1.9052	2.0005
14	1.7147	1.7147	1.6194	1.6194	1.6194	1.7147	1.8099
15	1.6194	1.7147	1.6194	1.4289	1.6194	1.6194	1.7147
16	1.5684	1.7147	1.5242	1.4289	1.5242	1.6194	1.6194
17	1.6194	1.8099	1.6194	1.5242	1.6194	1.7147	1.8099
18	1.7909	2.0957	2.0005	1.5242	1.8099	1.8099	1.9052
19	2.0386	2.2862	2.3815	2.0005	2.191	2.191	2.191
20	1.9791	2.0957	2.0957	1.8099	2.0005	2.0005	1.9052
21	1.7147	1.9052	1.8099	1.7147	1.8099	1.7147	1.8099
22	1.5242	1.5242	1.6194	1.6194	1.6194	1.6194	1.6194
23	1.3336	1.3336	1.3336	1.4289	1.4289	1.467	1.3336
24	1.1431	1.1431	1.2384	1.1431	1.2384	1.2384	1.1431
Max	2.0386	2.2862	2.3815	2.0005	2.191	2.191	2.191
Min	.9526	.9526	.9526	.8573	.8573	.9526	.9145
Avg	1.5497	1.6353	1.5781	1.4686	1.5567	1.5734	1.5964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213003 / 22/11KV ST MARY

Feeder No / Name : 201 / Solapur Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6602	.6602	.6602		.5658	.6602
2	.6602	.6602	.6602	.6602		.5658	.5658
3	.5658	.5658	.5658	.6602		.5658	.5658
4	.5658	.5658	.5658	.5658		.5658	.5658
5	.5658	.6602	.6602	.5658		.5658	.5658
6	.7545	.8488	.6602	.6602		.6622	.6602
7	.9431	.9431	.7545	.6602		.7545	.8488
8	1.1317	1.1317	1.0374	.8488	.0943	1.1317	1.1317
9	1.3203	1.1145	1.1317	.9431	.0934	1.1317	1.226
10	1.226	1.2136	1.226	.9431	.0934	1.226	1.3203
11	1.3203	1.4003	1.3203	.9431		1.226	1.3203
12	1.3203	1.7737	1.226	.9431	.0934	1.3203	1.3203
13	1.3203	1.307	1.1317	.8488	.0934	1.226	1.226
14	1.226	1.2136	1.0374	.8488	.0934	1.1317	1.1317
15	1.226	1.1203	.9431	.8488	.0934	1.0374	1.1317
16	1.0374	1.0269	.9335	.7545		.9431	.9431
17	.9431	.9335	.8402	.8488	.9335	.9431	1.0374
18	.9431	.9335	.9335	.8488	.8402	1.0374	1.0374
19	1.1317		.9335	1.0374	1.1203	1.1317	1.226
20	1.0374	.9335	.9335	.9431	.9335	1.1317	1.1317
21	.9431	.9335	.9335	.9431	.9335	1.0374	1.0374
22	.9431	.9431	.8488	.8488	.9431	.9431	.9431
23	.7545	.8488	.8488	.7545	.8488	.8488	.8488
24	.7545	.6602	.6602	.6602	.6602	.6602	.7545
Max	1.3203	1.7737	1.3203	1.0374	1.1203	1.3203	1.3203
Min	.5658	.5658	.5658	.5658	.0934	.5658	.5658
Avg	.9706	.9736	.8936	.8016	.5245	.9314	.9667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213003 / 22/11KV ST MARY

Feeder No / Name : 202 / Golibar Maidan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.462	.5658	.4715	.5658	.6602	.5658
2	.462	.462	.5658	.4715	.4715	.5658	.5658
3	.4572	.462	.5658	.4715	1.1317	.5658	.5658
4	.4572	.462	.5658	.4715	1.0374	.4715	.5658
5		.462	.5658	.4715	1.1317	.5658	.5658
6	.6468	.6468	.5658	.5658	1.226	.5658	.5658
7	.7468	.7392	.5658	.5658	1.4146	.6602	.6602
8	.8402	.8316	.7545	.6602	1.7918	.8488	.8488
9	1.0374	1.0269	.924	.8316	2.2405	.924	.924
10	1.0374	1.1203	1.0164	.924	2.1472	1.0164	1.0164
11	1.0374	1.1203	.924	.8316	2.2405	1.0164	1.0164
12	1.0374	1.2136	1.1088	.924	2.2405	1.0164	1.0164
13	1.1317	1.1203	1.0164	.924	2.0538	1.0164	.924
14	.9431	1.1203	.924	.7392	1.8671	.924	.8316
15	.9431	1.0269	.924	.6468	1.8671	.924	1.0164
16	.924	1.0269	.7468	.6468	1.7737	.9335	1.0164
17	.924	.9335	.8402	.6468	.9335	.9335	1.0269
18	.924	.9335	.9335	.7392	1.0269	1.0269	1.0269
19	1.1088	1.1203	1.1203	.924	1.1203	1.1203	1.1088
20	1.0164	1.0269	.9335	.924	1.0269	1.1203	1.1088
21	.924	.9335	.9335	.8316	.9335	.9335	.9335
22	.8316	.8488	.7545	.8488	.8488	.8488	.9335
23	.6468	.7545	.6602	.7545	.7545	.6602	.7468
24	.5544	.5544	.6602	.5658	.6602	.6602	.6602
Max	1.1317	1.2136	1.1203	.924	2.2405	1.1203	1.1088
Min	.4572	.462	.5658	.4715	.4715	.4715	.5658
Avg	.8302	.8504	.7973	.7022	1.3544	.8324	.8421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213003 / 22/11KV ST MARY

Feeder No / Name : 203 / Bombay garage

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1886	.1886	.1886	.2829	.2829	.2829
2	.1867	.1886	.1886	.1886	.2829	.1886	.1886
3	.1867	.1886	.1886	.1886	.1886	.1886	.1886
4	.1867	.1886	.1886	.1886	.1886	.1886	.1886
5	.1867	.1886	.1886	.1886	.1886	.1886	.1886
6	.2801	.2829	.2829	.2829	.2829	.1886	.2829
7	.3734	.3772	.2829	.2829	.3772	.2829	.3772
8	.3734	.3772	.3772	.3772	.3772	.3772	.4715
9	.5658	.5601	.4715	.3772	.5601	.5658	.4715
10	.7545	.7468	.5658	.4715	.7468	.6602	.6602
11	.7545	.8402	.7545		.7468	.7545	.8488
12	1.0374	.9335	.8488	.6602	.8402	.8488	.9431
13	.9431	.9335	.8488	.6602	.7468	.8488	1.0374
14	.8488	.9335	.7545	.6602	.8402	.7545	.9431
15	.8488	.9335	.8488	.5658	.8402	.8488	.9431
16	.9431	.9335	.7468	.5658	.8402	.8402	1.0269
17	.9431	.9335	.7468	.5658	.7468	.8402	.9526
18	.9431	.9335	.8402	.6602	.9335	.8402	
19	.9431	.9335	.8402	.6602	.9335	.9335	.9431
20	.8488	.7468	.7468	.6602	.7468	.9335	.8402
21	.6602	.6535	.6535	.5658	.6535	.7468	.7468
22	.4715	.3772	.4715	.4715	.4715	.4715	.5601
23	.3772	.3772	.3772	.3772	.3772	.3772	.2801
24	.3734	.2829	.2829	.2829	.2829	.2829	.2829
Max	1.0374	.9335	.8488	.6602	.9335	.9335	1.0374
Min	.1867	.1886	.1886	.1886	.1886	.1886	.1886
Avg	.5924	.5847	.5285	.4387	.5615	.5597	.5934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213003 / 22/11KV ST MARY

Feeder No / Name : 205 / Command Hospital

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1867	.1886	.1886	.1886	.1886	.1886
2	.1848	.1867	.1886	.1886	.1886	.1886	.1886
3	.1867	.1867	.1886	.1886	.1886	.1886	.1886
4	.1848	.1867	.1886	.1886	.1886	.1886	.1886
5	.3696	.3734	.2829	.2829	.2829	.2829	.2829
6	.5601	.5601	.4715	.3772	.4715	.4715	.4715
7	.6535	.6535	.6602	.4715	.7545	.6602	.6602
8	.7468	.7468	.7545	.5658	.6602	.6602	.7545
9	.6602	.6535	.7468	.5601	.6535	.7468	.7468
10	.6602	.6535	.6535	.5601	.6535	.6535	.6535
11	.6602	.6535	.5601	.4668	.6535		.5601
12	.6602	.6535	.6535	.4668	.6535	.5601	.5601
13	.5658	.5601	.5601	.3734	.5601	.6535	.5601
14	.4715		.4668	.3734	.4668	.5601	.4668
15	.4715	.4668	.3734	.2801	.4668	.5601	.3734
16	.4668	.4668	.3734	.2801	.4668		.3696
17	.3734	.3734	.3734	.3734	.3734		.3734
18	.3734	.3734	.3734	.3734	.3734	.462	.4668
19	.4668	.4668	.4668	.4668	.4668	.5601	
20	.4668		.4668	.4668	.4668	.4668	.5544
21	.3734	.3734	.3734	.3734	.4668	.4668	.3696
22	.2801	.2829	.2829	.3772	.3772	.3772	.3734
23	.1867	.2829	.2829	.2829	.2829	.2829	.3696
24	.1848	.1867	.1886	.1886	.1886	.1886	.1886
Max	.7468	.7468	.7545	.5658	.7545	.7468	.7545
Min	.1848	.1867	.1886	.1886	.1886	.1886	.1886
Avg	.4330	.4331	.4216	.3631	.4372	.4461	.4309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213003 / 22/11KV ST MARY

Feeder No / Name : 206 / Water Works
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.0957	2.0957	2.2862	2.0957	1.9052	2.0957
2	2.2862	2.3815	2.3815	2.4768	2.2862	2.0957	2.2862
3	2.191	2.3815	2.6673	2.6673	2.4768	2.3815	2.3815
4	2.3815	2.4768	2.6673	2.572	2.6673	2.4768	2.4768
5	2.2862	2.572	2.7625	2.6673	2.6406	2.6673	
6	2.2862	2.4768	2.6673	2.3815	2.7625	2.572	2.6673
7	2.3815	2.572	2.572	2.572	2.7625	2.3815	2.2862
8	2.4768	2.572	2.572	2.4768	2.7625	2.2862	2.572
9	2.4768	2.6673	2.572	2.4768	3.0483	2.3815	2.572
10	2.2862	2.3339	2.2862	2.4768	2.8578	2.3815	2.2862
11	2.572	2.3339	2.3815	2.191	2.894	2.4768	2.3815
12	2.4768	2.2405	2.572	2.3815	2.6139	2.4768	2.3815
13	2.4768	2.2862	2.4768	2.4768	2.8006	2.572	2.3815
14	2.572	2.6673	2.572	2.4768	2.9874	2.572	2.4768
15	2.6673	2.9531	2.6673	2.8578	2.894	2.6673	2.572
16	2.6673	2.7073	2.6673	2.572	2.6139	2.572	2.572
17	2.6673	2.5206	2.6673	2.572	2.6139	2.6673	2.6673
18	2.7625	2.8578	2.8578	2.7625	2.6139	2.572	2.8578
19	2.572	2.6673	2.6673	2.572	2.8006	2.572	2.6673
20	2.2862	2.3815	2.191	2.3815	2.3339	2.4768	2.572
21	2.191	2.3815	2.191	2.191	2.3815	2.191	2.3815
22	1.8099	2.0957	2.0957	2.0957	2.2862	2.0957	2.191
23	1.5242	2.0957	2.191	2.0957	2.0005	2.0957	1.8099
24	2.0957	1.7147	2.0005	2.0957	1.8099	1.8099	2.0005
Max	2.7625	2.9531	2.8578	2.8578	3.0483	2.6673	2.8578
Min	1.5242	1.7147	2.0005	2.0957	1.8099	1.8099	1.8099
Avg	2.3537	2.4347	2.4768	2.4490	2.5835	2.3894	2.4146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213003 / 22/11KV ST MARY

Feeder No / Name : 300 / Substation Transformer
Feeder KV- 22 / OUTGOING

DATE	09-FEB-18
HR	Load (MW)
13	.0373
Max	.0373
Min	.0373
Avg	.0373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 300 / Substation Transformer
Feeder KV- 22 / OUTGOING

DATE	10-FEB-18
HR	Load (MW)
12	.3353
Max	.3353
Min	.3353
Avg	.3353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 304 / Brahma

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7468	.7468	.7545	.7468	.7468	.7545
2	.7468	.7392	.7468	.7468	.7468	.7545	.7545
3	.7468	.7392	.5658	.7468	.7468	.5658	.7545
4	.7545		.5658	.7545	.7468	.7545	.7545
5	.7545	.7468	.5658	.7545	.7545	.7545	.9431
6	.9431	.9431	.7545	.7545	.9431	.9431	.9431
7	1.1317	1.1317	.9431	.7545	1.1317	1.1317	1.1317
8	1.3203	1.3203	1.1317	.9431	1.3203	1.3203	1.3203
9	1.5089	1.5089	1.3203	1.1317	1.3203	1.3203	1.5089
10	1.5089	1.5089	1.5089	1.3203	1.5089	1.5089	1.5089
11	1.5089	1.5089	1.5089	1.3203	1.5089	1.5089	1.5089
12	1.3203	1.6975	1.3203	1.3203	1.3203	1.5089	1.3203
13	1.5089	1.5089	1.5089	1.307	1.1317	1.3203	1.3203
14	1.1317	1.3203	1.3203	1.1203	1.307	1.1317	1.3203
15	1.1317	1.3203	1.1317	1.1203	1.1317	1.1317	1.1317
16	1.1317	1.4335	1.1317	.9335	1.1317	1.1317	1.1317
17	1.1317	1.1317	1.1317	.9335	1.1317	1.1317	1.3203
18	1.1317	1.0974	1.1317	1.1203	1.1203	1.1317	1.3203
19	1.5089	1.4784	1.3203	1.307	1.307	1.5089	1.3203
20	1.3203	1.2936	1.3203	1.1203	1.307	1.307	1.307
21	1.3203	1.1088	1.1317	1.1203	1.1203	1.307	1.307
22	1.1317	1.1088	1.1317	1.1203	1.1088	1.1317	1.1203
23	.9431	.9335	.9431	.9335	.9335	.9431	.9431
24	.7468	.7545	.7468	.7545	.7468	.7468	.7545
Max	1.5089	1.6975	1.5089	1.3203	1.5089	1.5089	1.5089
Min	.7468	.7392	.5658	.7468	.7468	.5658	.7545
Avg	1.1304	1.1774	1.0679	1.0080	1.0947	1.1142	1.1458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 305 / CTC

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3506	.3353	.3315	.3086	.3163	.3239
2	.3467	.3467	.3391	.3125	.3048	.3163	.3163
3	.3467	.3429	.3429	.3125		.3125	.3125
4	.3506	.3506	.3467	.3125		.3125	.3429
5	.543	.543	.5087	.3391	.5144	.3391	.3506
6	.5487	.543	.5258	.5258	.7087	.543	.543
7	.5487	.7316	.724	.543	.5487	.5544	.5544
8	.7316	.7316	.7316	.5544	.5487	.5544	.5487
9	.5544	.5544	.7316	.5544	.5601	.5544	.5544
10	.5544	.5544		.5544	.5601	.5544	.5544
11	.5544	.7468	.7468	.0554	.5544	.5544	.5544
12	.543	.724	.7392		.5544	.5544	.5544
13		.543	.543		.543	.5487	.5544
14	.5544	.5373	.5487	.3582	.543	.5487	.5487
15	.543	.5201	.3696	.3544	.5792	.5544	.5487
16	.543	.5316	.5544	.3544	.5487	.5544	.5487
17	.5373	.663	.5544	.3467	.5487	.5544	.5487
18	.5316	.5144	.5373	.362	.5544	.5487	.543
19	.543	.7164	.543	.362	.7392	.5544	.7316
20	.5373	.5258	.5316	.5373	.5544	.5544	.5544
21	.5316	.5144	.5373	.5258	.5544	.3658	.5487
22	.3544	.4973	.3544	.3506	.5487	.362	.362
23	.3582	.3315	.3544	.3506	.3582	.3582	.3582
24	.3544	.3544	.3391	.3391	.3315	.3315	.3315
Max	.7316	.7468	.7468	.5544	.7392	.5544	.7316
Min	.3467	.3315	.3353	.0554	.3048	.3125	.3125
Avg	.4940	.5320	.5147	.3926	.5257	.4709	.4870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 306 / Kondhwa

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	13-FEB-18
HR	Load (MW)
7	2.5606
Max	2.5606
Min	2.5606
Avg	2.5606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 309 / NIBM

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.7909		1.7909	1.7718	1.7909	1.7909
2	1.829	1.7909		1.5947	1.5947	1.5947	1.7909
3	1.829	1.8099		1.5947	1.5947	1.5947	1.5947
4	1.848	1.8099		1.5947	1.5947	1.5947	1.5947
5	1.848	1.8099		1.7909	2.0119	1.9909	1.9909
6	2.5873	2.5873		1.9909	2.5873	2.3777	2.4025
7	3.1417	3.1741		2.1719	2.9569	2.5606	2.9569
8	3.5475	3.5475		2.7721	3.3265	3.1093	3.5113
9	3.7342	3.9209		3.3265	3.5475	3.5475	3.7342
10	3.7342	3.7342		3.7342	3.7342	3.7342	3.7342
11	3.7342	3.7342		3.7342	3.5475	3.5475	3.5475
12	3.1417	3.7342		3.7342	3.3608	3.3608	3.1417
13	2.9569			3.6961	3.1093	3.1417	2.9264
14	2.9569	1.1088		3.1093	2.9264	2.9264	2.9264
15	2.5873			2.7149	2.7435	2.5606	2.7435
16	2.5339		2.6139	2.7149	2.5606	2.5606	2.5873
17	2.5072			2.8349	2.7721	2.5873	2.7721
18	2.6578		3.0445	2.8654	2.9569	2.9569	2.9569
19	3.4389		3.4751	3.4389	3.5848	3.5475	3.5113
20	3.2579		3.4389	3.2236	3.5475	3.2922	3.5113
21	3.0769		3.2579	2.8959	3.3608	3.3265	3.2922
22	2.8959		2.8959	2.8654	2.9569	2.9569	3.1093
23	2.3529		2.5606	2.8654	2.5606	2.5606	2.5606
24	2.0119	1.97		2.1719	2.1491	2.1719	2.1719
Max	3.7342	3.9209	3.4751	3.7342	3.7342	3.7342	3.7342
Min	1.829	1.1088	2.5606	1.5947	1.5947	1.5947	1.5947
Avg	2.7516	2.6088	3.0410	2.7178	2.7857	2.7247	2.7858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 310 / 22 KV MANDKE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.7545	.7621	.7621	.7621	.7621
2	.7545	.7545	.7545	.7621	.7621	.7621	.7621
3		.7545	.7545	.7621	.7621	.7621	.7621
4	.7621	.7545	.7545	.7621	.7621	.7621	.7621
5	.7621	.7545	.7545	.7621	.9526	.9526	.9526
6	1.3336	1.3203	.9526	.9526	1.3336	1.1431	1.1431
7	1.5242	1.5242	1.1431	.9526	1.5242	1.3336	1.5242
8	1.5089	1.5242	1.3336	1.3336	1.5242	1.7147	1.7147
9	1.5242	1.5242	1.3336	1.3203	1.5242	1.5242	1.7147
10	1.5242	1.5242	1.5242	1.5089	1.5242	1.5242	1.5242
11	1.3203	1.5242	1.5242	1.5089	1.5242	1.3336	1.5242
12	1.1317	1.3336	1.3336	1.3336	1.3336	1.3336	1.3336
13	.9431	1.3203	1.1317	1.1431	1.1431	1.1431	1.1431
14	.9526	1.1317	1.1317	.9431	1.1431	1.1431	1.1431
15	.9526	1.1317	.9431	.9431	1.1431	1.1431	1.1431
16	.9526	1.1317	.9431	.9526	.9526	.9526	1.1317
17	.9431	1.1317	1.1317	.9431	1.1317	.9431	1.1317
18	1.1203	.9431	1.1317	.9431	.9431	1.1317	1.1317
19	1.5089	1.3203	1.3203	1.3203		1.3203	1.3203
20	1.3203	1.3203	1.3203	1.3203	1.5089	1.3203	1.3203
21	1.3203	1.307	1.3203	1.1317	1.3203	1.307	1.3203
22	1.1317	1.1317	1.1317	1.1317	1.1317	1.1317	1.3203
23	.9431	.9431	.9526	.9431	.9526	.9526	1.1317
24	.7545	.7545	.7545	.9526	.7621	.7621	.7621
Max	1.5242	1.5242	1.5242	1.5089	1.5242	1.7147	1.7147
Min	.7545	.7545	.7545	.7621	.7621	.7621	.7621
Avg	1.1193	1.1506	1.0888	1.0579	1.1488	1.1316	1.1866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 311 / 22 KV Kumar Palms

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6406	2.2634	2.6406	2.452	2.452	2.4272	2.452
2	2.2634	2.2634	2.452	2.2405	2.2405	2.2405	2.2634
3	2.2634	2.2634	2.452	2.2405	2.2405	2.2405	2.2405
4	2.2634	2.452	2.452	2.2405	2.2405	2.2405	2.4272
5	2.452	2.452	2.452	2.4272	2.6406	2.9874	2.8006
6	3.3951	3.2065	3.0178	2.6139	3.3951	2.9874	3.3608
7	4.1495	4.1495	3.9609	3.1741	4.1495	3.7342	4.1495
8	5.0926	5.0926	4.7154	4.3381	5.144	4.904	5.0926
9	4.904	5.2812	5.0926	4.904	5.3346	5.2812	5.4698
10	4.904	5.0926	5.4698	5.2812	5.0926	5.6584	5.0926
11	4.3381	5.0926	5.4698	4.904	4.9535	5.0926	4.904
12	3.9609	4.7154	4.7154	4.7154	4.382	4.7154	4.5268
13	3.5837	4.1495	4.1495	4.1914	3.8104	4.3381	4.1495
14	3.3951	3.7723	4.1495	3.6199	3.7723	3.9609	3.9609
15	3.2065	3.7723	3.9609	3.6199	3.9609	3.7723	3.9609
16	3.2065	3.5837	3.7723	3.3951	3.7723		4.1495
17	3.2065	3.9609	3.7723	3.3951	3.5837	4.3381	3.9609
18	3.2065	3.9209	3.9609	3.5837	3.9609	3.9609	3.9609
19	4.1495	4.904	4.904	4.5268	4.7154	4.7154	4.7154
20	4.1495	4.5268	4.5268	4.1495	4.5268	4.5268	4.904
21	3.9609	4.1495	4.1495	3.9609	4.1495	4.1495	4.3381
22	3.7723	3.9609	3.9609	3.7723	3.7723	3.9609	3.9609
23	3.2065	3.5837	3.3951	3.3951	3.2065	3.3951	3.3951
24	2.8292	2.6406	3.0178	2.8292	2.6406	2.8292	2.6406
Max	5.0926	5.2812	5.4698	5.2812	5.3346	5.6584	5.4698
Min	2.2634	2.2634	2.452	2.2405	2.2405	2.2405	2.2405
Avg	3.5208	3.8021	3.8587	3.5821	3.7557	3.8459	3.8699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 312 / Hyde Park Feeder

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0538	2.0119	1.97	2.0119	1.9909	1.829	2.0119
2	2.0538	2.0119	1.9909	1.8099	1.7909	1.829	1.848
3	1.848	2.0328	1.9909	1.8099	1.7909	1.829	1.848
4	1.8671	2.0328	2.0119	1.8099	1.7909	1.829	2.2405
5	2.0538	2.2177	2.0538	2.0119	2.1948	2.2177	2.4272
6	2.9874	2.9874	2.6139	2.2177	2.9874	2.8006	2.9874
7	3.3608	3.3608	2.9874	2.5873	3.5475	3.1741	3.5837
8	3.7342	3.7342	3.3608	2.9569	3.7342	3.5475	3.9209
9	3.9609	3.9609	3.9609	3.5475	3.9209	3.9609	4.1495
10	3.9609	3.9609	4.3381	4.1076	4.3381	4.3381	4.1495
11	3.9609	4.3381	4.481	3.9209	3.9609	4.3381	4.1495
12	3.5837	3.9609	4.1076	4.1076	3.5837	4.5268	3.7342
13	3.3951	3.7723	3.9209	3.7342	3.1741	3.9209	3.7342
14	3.2065	3.5837	3.7723	3.3265	3.8809	3.3608	3.5475
15	3.0178	3.1417	3.3951	2.9569	3.3608	3.1741	3.3608
16	3.1741	3.2922	3.5837	2.9264	3.3608	3.1741	3.3608
17	3.3265	3.2579	3.7723		3.5848	3.3608	3.5475
18	3.2922	3.4389	3.5837	3.2579	3.5475	3.5475	3.7342
19	3.8809	3.6199	4.1495	3.6199	4.1076	4.1076	4.1076
20	3.6961	4.0238	3.8809	3.658	3.9209	3.8809	4.1076
21	3.658	3.6199	3.5113	3.4751	3.9209	3.7342	3.9209
22	3.4751	3.2236	3.1417	3.2579	3.3608	3.3608	3.3265
23	2.7435	2.6863	2.7721	2.7435	2.6139	2.5873	2.9569
24	2.452	2.1948	2.3282	2.4025	2.3777	2.1948	2.1948
Max	3.9609	4.3381	4.481	4.1076	4.3381	4.5268	4.1495
Min	1.848	2.0119	1.97	1.8099	1.7909	1.829	1.848
Avg	3.1143	3.1861	3.2366	2.9677	3.2017	3.1927	3.2896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 313 / 22KV Shivneri Brahma
Feeder KV- 22 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.1886
6							.1886
7	.1829	.1829			.181	.181	.0572
8	.1848	.1829	.1867	.181	.1829	.1829	.0857
9	.1848	.1829	.1867	.1829	.2454	.1829	.181
10	.1734	.1848	.1867	.1848	.1715	.1848	.1829
11	.1772		.1867	.1867			
12				.1905			
13					.1772		
19		.0895	.1543		.1791	.181	.1829
20						.1848	.181
21	.1315				.1791	.1848	.1791
22	.1524		.0476	.0724			.1772
Max	.1848	.1848	.1867	.1905	.2454	.1848	.1886
Min	.1315	.0895	.0476	.0724	.1715	.181	.0572
Avg	.1696	.1646	.1581	.1664	.1880	.1832	.1604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213024 / 22/22KV LULLANAGAR

Feeder No / Name : 314 / Raheja Garden

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.7468	.7545	.7545	.7545	.7545
2	.7545	.7545	.7468	.7545	.7545	.7545	.7545
3	.7545	.7545	.7545	.7545	.7545	.7545	.7545
4	.7545	.7545	.7545	.7545	.7545	.7545	.7621
5	.7545	.7545	.7545	.7545	.9526	.9431	1.0669
6	1.1431	1.1317	.9526	.9431	1.1431	1.1431	1.1431
7	1.3336	1.3336	1.3336	.9526	1.3203	1.1431	1.3336
8	1.5089	1.5242	1.5242	1.1431	1.5089	1.5089	1.5089
9	1.5089	1.5089	1.5089	1.1431	1.5089	1.5089	1.5089
10	1.5089	1.5089	1.5089	1.3336	1.5089	1.5089	1.5089
11	1.5089	1.5089	1.5089	1.1431	1.5089	1.5089	1.5089
12	1.3203	1.4937	1.4937	1.1431	1.5089	1.5089	1.3203
13	1.3203	1.4784	1.3203		1.307	1.5089	1.1317
14	1.3203	1.2936	1.1317	.9431	1.3203	1.3203	1.1431
15	1.307	1.1203	.9431	.7621	1.1203	1.1317	.9526
16	1.1317	1.1203	.9431	.9526	1.1317	1.1317	.9431
17	1.1203	.9335	.9431	.9431	1.1317	.9431	.9335
18	1.1203	1.1203	1.1317	.9431	.7545	1.1317	.9431
19	1.4937	1.4937	1.5089	1.307	1.3203	1.3203	1.3203
20	1.3203	1.307	1.3203	1.307	1.3203	1.3203	1.3203
21	1.1203	1.1203	1.1203	1.1203	1.3203	1.1317	1.1317
22	1.1317	1.1088	.9431	1.1317	1.1317	.9431	1.1317
23	.9431	.9335	.9431	.9431	.9431	.9431	.9431
24	.7545	.7545	.7468	.7545	.7545	.7545	.7545
Max	1.5089	1.5242	1.5242	1.3336	1.5089	1.5089	1.5089
Min	.7545	.7545	.7468	.7545	.7545	.7545	.7545
Avg	1.1537	1.1486	1.1076	.9862	1.1473	1.1405	1.1072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213379 / 22 KV Sobha Switching
StationFeeder No / Name : 301 / 22 KV Sobha - Kondhawa
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.481	3.9609	4.481	3.7723	3.7723	3.7723	3.7723
2	4.481	3.3951	3.7342	3.3951	3.5837	3.3951	3.5837
3	3.7723	3.2065	3.7723	3.2065	3.3951	3.3951	3.3951
4	3.7723	3.2065	3.5837	3.2065	3.2065	3.2065	3.2065
5	3.7723	3.5837	3.5837	3.3951	3.3951	3.3951	3.3951
6	4.5268	5.2812	4.5268	4.1495	4.904	4.5268	5.0926
7	6.7901	6.6015	5.6584	4.904	6.4129	5.6584	6.6015
8	7.9218	8.1104	6.9787	6.6015	7.5446	7.5446	7.7332
9	7.9218	8.8649	7.9218	7.5446	7.9218	8.1104	8.1104
10	7.5446	8.6763	7.8418	8.2991	7.9218	8.1104	7.8418
11	6.7215	8.1104	7.2817	8.2152	6.9787	7.7332	6.9083
12	5.9747	8.0285	6.9083	8.1104	6.7215	7.095	6.9083
13	5.788	8.1104	6.1614		6.1614	6.7215	6.7215
14	5.2279	6.7215	5.6013	6.5348	5.6013	5.6013	5.6013
15	4.8544	5.2279	5.2279	5.6013	4.8544	5.4146	5.4146
16	4.481	4.6677	4.481	4.8544	4.481	4.6677	4.481
17	4.481	4.6677	4.481	4.6677	4.481	4.8544	4.8544
18	5.3041	5.4146	5.487	5.6013	5.6013	5.6013	5.788
19	6.6015	6.5348	6.7215	6.7215	6.5348	6.7215	6.7215
20	6.5348	6.7215	6.7215	6.7215	6.3481	6.7215	6.8378
21	6.3481	5.9747	6.5348	6.5348	6.7215	6.7215	6.7215
22	6.2243	5.6013	6.0357	6.1614	6.1614	6.2243	6.5348
23	5.4698	5.2279	5.4698	5.4698	5.4698	5.6584	5.6584
24	4.481	4.5268	4.481	4.5268	4.3381	4.5268	4.3381
Max	7.9218	8.8649	7.9218	8.2991	7.9218	8.1104	8.1104
Min	3.7723	3.2065	3.5837	3.2065	3.2065	3.2065	3.2065
Avg	5.5615	5.8509	5.5698	5.5737	5.5213	5.6407	5.6759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213379 / 22 KV Sobha Switching
StationFeeder No / Name : 302 / 22 KV Sobha Aarti
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.7545	.7545	.7545	.7545	.7545
2	.5658	.7545	.5658	.7545	.7545	.7545	.7545
3	.5658	.5601	.5658	.5601	.5601	.5601	.5601
4	.7545	.7392	.7545	.7468	.7468	.7545	.7468
5	.7545	.7468	.7545	.7545	.7545	.7545	.7545
6	.7545	.7545	.7545	.7392	.7545	.7545	.7545
7	.7545	.7545	.7545	.7545	.7545	.7545	.7545
8	.7545	.7545	.7545	.7545	.7545	.7545	.7545
9	.7545	.7545	.7621	.7545	.7545	.7621	.7621
10	.7545	.7621	.7621	.7545	.7621	.7621	.7621
11	.7545	.7545	.7545	.7545	.7545	.7621	.7545
12	.7621	.7545	.7621	.7545	.7545	.7621	.7545
13	.7621	.7545	.7621	.7545	.7545	.7545	.7545
14	.7545	.7545	.7621	.7545	.7621	.7545	.7621
15	.7545	.7545	.7621	.7545	.7545	.7621	.7545
16	.7545	.7545	.7621	.7545	.7621	.7545	.7621
17	.7545	.7545	.7621	.7545	.7545	.7545	.7621
18	.7545	.7545	.7545	.7545	.7545	.7545	.7545
19	.7545	.7545	.7545	.7545	.7545	.7621	.7545
20	.7545	.7545	.7545	.7545	.7545	.7545	.7545
21	.7545	.7545	.7545	.7545	.7545	.7545	.7545
22	.7545	.7545	.7545	.7545	.7545	.7545	.7545
23	.7545	.7545	.7545	.7545	.7545	.7545	.7545
24	.7545	.7545	.7545	.7545	.7545	.7545	.7545
Max	.7621	.7621	.7621	.7545	.7621	.7621	.7621
Min	.5658	.5601	.5658	.5601	.5601	.5601	.5601
Avg	.7394	.7458	.7413	.7454	.7470	.7483	.7477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213379 / 22 KV Sobha Switching
StationFeeder No / Name : 303 / 22 KV Sobha - Kumar Palm
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.2003	1.6766	1.5813	1.5432	1.6004	1.4861
2	1.5089	1.046	1.4403	1.5813	1.4861	1.5623	1.4861
3	1.3717	1.0288	1.4403	1.3717	1.3032	1.3717	1.3032
4	1.3889	.9145	1.5051	1.467	1.4098	1.4861	1.448
5	1.3889	1.0288	1.5051	1.467	1.4289	1.448	1.3908
6	1.3889	1.0288	1.6004	1.467	1.467	1.4289	1.3908
7	1.5432	1.3336	1.6004	1.5813	1.5432	1.5432	1.5432
8	1.5813	1.4861	1.7604	1.7814	2.0119	1.9433	1.7814
9	1.5623	2.0348	2.3034	2.2786	2.3529	2.3034	2.2786
10	2.0119	3.0178	3.3951	2.8292	3.3951	3.3951	3.3951
11	2.2405	3.2388	3.6199	3.0178	3.4294	3.8104	3.8104
12	2.2405	3.6199	3.8104	3.0178	3.6199	3.6199	3.8104
13	1.4575	2.5606	2.7435	2.3282	2.5606	2.9264	2.5606
14	1.7147	3.0178	2.9874	2.5873	3.0178	3.0178	3.0178
15	2.0119	3.4294	3.4294	2.8006	3.0178	3.2065	3.6199
16	1.829	3.4294	3.6199	2.6139	3.4294	3.4294	3.8104
17	1.8861	3.4294	3.6199	2.4272	3.2065	3.4294	3.6199
18	1.5947	3.0178	3.0178	2.4272	2.8292	2.6139	3.0178
19	1.7528	3.0178	3.2065	2.4025	2.8292	2.5339	3.1741
20	1.6194	2.452	2.3529	2.0328	2.6406	2.1491	2.5873
21	1.4098	2.2634	2.1262	1.848	2.1948	1.8442	2.0805
22	1.2955	1.8861	1.7147	1.6194	1.8652	1.6575	1.8233
23	1.2193	1.8861	1.5813	1.6004	1.6194	1.5432	1.6385
24	1.7147	1.2384	1.7147	1.5432	1.5623	1.6194	1.5242
Max	2.2405	3.6199	3.8104	3.0178	3.6199	3.8104	3.8104
Min	1.2193	.9145	1.4403	1.3717	1.3032	1.3717	1.3032
Avg	1.6436	2.1919	2.4072	2.0697	2.3235	2.3118	2.3999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213389 / 22/11KV RACE COURSE

Feeder No / Name : 201 / KAWADE MALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2218	.2587	.2218	.2218	.2926	.2561
2	.2218	.2218	.2218	.2218	.1848	.2561	.2561
3	.2218	.2218	.2218	.1848	.1848	.2561	.2561
4	.2218	.2218	.2218	.1848	.2218	.2561	
5	.2957	.2957	.2587	.2218	.2587	.2561	.2926
6	.3326	.3326	.2957	.2587	.3326	.2926	.3292
7	.2957	.3734	.3326	.2957	.4108	.3292	.3658
8	.3326	.4108	.3361	.3696	.4108	.3292	.4024
9	.3734	.4108	.4108	.4108	.4108	.415	.439
10	.3658	.4527	.4527	.3658	.4481	.4527	.4481
11	.3292	.3772	.4527	.3658	.4108	.3772	.3772
12	.3292	.3361	.4108	.3292	.3361	.3361	.2987
13	.2926	.3018	.3395	.3292	.2987	.3361	.3018
14	.2561	.2614	.3361	.2957	.2987	.2614	.2987
15	.2561	.2241	.2987	.2926	.2987	.2987	.2263
16	.2987	.2561	.2614	.2561	.2614	.2987	.2218
17	.2241	.2561	.2587	.2561	.2641	.2641	.2587
18	.2987	.2957	.2957	.2926	.3395	.2641	.2957
19	.3734	.3292	.3734	.3658	.415	.3395	.3734
20	.4108	.3292	.4108	.3696	.415	.3772	.3734
21	.3696	.2926	.3734	.3734	.3292	.415	.3696
22	.3326	.2587	.3361	.3361	.3292	.3658	.3292
23	.2957	.2587	.2587	.2987	.2926	.2926	.3292
24	.2957	.2587	.2587	.2587	.2587	.2926	.2926
Max	.4108	.4527	.4527	.4108	.4481	.4527	.4481
Min	.2218	.2218	.2218	.1848	.1848	.2561	.2218
Avg	.3034	.3000	.3198	.2981	.3180	.3190	.3214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213389 / 22/11KV RACE COURSE

Feeder No / Name : 202 / RACE COURSE MES COMPUTER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	1.1458	1.2567	1.2567	1.1088	1.1203	1.1203
2	.9979	1.1088	1.1827	1.2197	1.0719	1.0829	1.0829
3	.961	1.0719	1.1088	1.1458	1.0349	1.0456	1.1203
4	1.2197	1.3676	1.2197	1.1827	.9979	1.0082	1.2323
5	1.4784	1.4784	1.4415	1.2936	1.1827	1.1949	1.307
6	1.8111	1.7741	1.6632	1.4045	1.7372	1.7551	1.6804
7	2.3152	2.2405	1.922	1.848	2.3152	2.0538	2.0538
8	2.3525	2.3525	2.3152	2.2032	2.2779	2.2405	2.3899
9	2.2779	2.2779	2.3899	2.3899	2.2779	2.2032	2.2405
10	2.0911	2.2634	2.2257	2.2405	2.2032	2.1285	2.1879
11	1.8671	2.037	2.2257	2.0538	1.9993	2.1658	1.9616
12	1.6804	1.8671	1.8298	1.8671	1.8107	1.7924	1.6804
13	1.4937	1.643	1.7353	1.7924	1.643	1.6057	1.4937
14	1.419	1.3817	1.4563	1.6804	1.4563	1.531	1.4563
15	1.3817	1.3817	1.3957	1.643	1.3443	1.3443	1.4712
16	1.2323	1.2323	1.3443	1.531	1.307	1.2696	1.2567
17	1.2696	1.307	1.2936	1.4937	1.4523	1.4335	1.3817
18	1.7551	1.6804	1.7741	1.8671	1.6975	1.6221	1.848
19	2.0911	2.2779		2.2405	2.2445	2.2257	2.2405
20	2.2032	2.1658	2.2405	2.0328	2.1313	2.3388	2.1807
21	1.9589	2.0538	2.3525	1.9418	1.8671	2.2068	2.1068
22	1.7372	1.848	1.7741	1.7177	1.6804	1.7924	1.8671
23	1.4784	1.5893	1.5893	1.5524	1.4937	1.643	1.6804
24	1.2936	1.2567	1.2936	1.3306	1.2936	1.307	1.3443
Max	2.3525	2.3525	2.3899	2.3899	2.3152	2.3388	2.3899
Min	.961	1.0719	1.1088	1.1458	.9979	1.0082	1.0829
Avg	1.6433	1.7001	1.6970	1.7054	1.6512	1.6713	1.6827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213389 / 22/11KV RACE COURSE

Feeder No / Name : 300 / Substation Transformer
Feeder KV- 22 / OUTGOING

DATE	08-FEB-18
HR	Load (MW)
18	.1509
Max	.1509
Min	.1509
Avg	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213389 / 22/11KV RACE COURSE

Feeder No / Name : 301 / 22KV Big Bazaar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.2957	.2957	.2957	.2957	.3326	.2957
2	.2957	.2957	.2957	.2587	.2957	.3326	.2957
3	.2957	.2587	.2587	.2587	.2587	.2957	.2587
4	.2587	.2587	.2957	.2957	.2587	.2957	.2587
5	.2957	.2587	.2957	.2587	.2587	.2957	.2957
6	.2957	.2957	.3326	.3326	.2957	.3326	.2957
7	.3326	.3326	.3326	.3326	.3326	.3326	.3326
8	.3326	.3361	.3696	.3326	.3734	.3696	.3696
9	.3361	.3734	.3696	.3361	.3734	.3734	.3696
10	.3696	.4527	.3734	.3696	.3734	.4904	.3772
11	.4066	.5281	.4904	.4066	.4904		.4854
12	.4805	.5601	.4854	.4435	.5228	.5228	.5228
13	.4805	.5228	.5281	.4435	.5228	.5601	.5601
14	.4805	.4854	.5228	.4805	.5228	.4481	.5228
15	.4435	.4854	.4854	.4435	.5228	.4481	.5281
16	.4854	.4805	.4481	.4805	.5228	.5228	.4805
17	.5228	.4066	.4805	.4435	.5658	.5281	.5544
18	.5228	.4805	.5175	.4435	.5658	.5281	.5175
19	.5601	.5544		.4435	.5658	.5281	.5175
20	.4481	.4805	.4854	.4066	.4904	.4904	.4805
21	.3696	.4435	.3696	.3696	.4435	.415	.4805
22	.3326	.4435	.3326	.3326	.4066	.4066	.4435
23	.3326	.3696	.3326	.3326	.3696	.3696	.4066
24	.3696	.2957	.3326	.3326	.3326	.3696	.3326
Max	.5601	.5601	.5281	.4805	.5658	.5601	.5601
Min	.2587	.2587	.2587	.2587	.2587	.2957	.2587
Avg	.3908	.4039	.3926	.3697	.4150	.4169	.4159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213389 / 22/11KV RACE COURSE

Feeder No / Name : 302 / 22KV Shinde Chhattri

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8131	.924	.8871	.924	.8501	.924	.924
2	.8871	.8871	.8131	.8871	.7762	.7762	.7762
3	.961	.961	.8501	.7762	.8131	.8131	.8131
4	1.0719	1.0719	.8871	.8501	.961	.961	.961
5	1.1458	1.2936	1.0349	.9979	1.1827	1.1827	1.1827
6	1.2567	1.4784	1.1458	1.2197	1.4045	1.4045	1.4045
7	1.7002	1.6632	1.2567	1.4045	1.643	1.5524	1.5524
8	1.8298	1.9418	1.6804	1.5684	1.8671	1.7372	1.7741
9	1.9418	1.8671	1.8298	1.8671	1.8298	1.8298	1.7372
10	1.7741	1.8298	1.9791	1.922	1.9044	1.9044	1.7924
11	1.6632	1.7924	1.8671	2.1437	1.7177	1.7924	1.6804
12	1.5154	1.5684	1.7177	1.848	1.4563	1.643	1.531
13	1.4415	1.419	1.5684	1.5893	1.3817	1.3817	1.3817
14	1.3306	1.307	1.3817	1.5154	1.3443	1.3443	1.307
15	1.2936	1.1949	1.2696	1.4784	1.2323	1.2323	1.2071
16	1.2696	1.2197	1.2323	1.4045	1.1576	1.1949	1.1827
17	1.2323	1.2567	1.2936	1.3676	1.4335	1.2449	1.3306
18	1.531	1.4784	1.4415	1.5524	1.4335	1.5089	1.4937
19	1.7924	1.7372		1.8111	1.9239	1.8484	1.7177
20	1.7924	1.7002	1.6804	1.6632	1.773	1.8484	1.7551
21	1.6263	1.5524	1.5524	1.531	1.5524	1.6598	1.7177
22	1.5154	1.4045	1.5154	1.3676	1.4784	1.4045	1.4784
23	1.1827	1.1827	1.2936	1.1827	1.4045	1.1827	1.4045
24	.961	.961	.924	.961	.9979	1.2567	1.1088
Max	1.9418	1.9418	1.9791	2.1437	1.9239	1.9044	1.7924
Min	.8131	.8871	.8131	.7762	.7762	.7762	.7762
Avg	1.3970	1.4039	1.3523	1.4097	1.3966	1.4012	1.3839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213389 / 22/11KV RACE COURSE

Feeder No / Name : 303 / 22KV Fatima Nagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	1.0349	1.0719	.9979	.961	.961	.961
2	.8871	.9979	.9979	.961	.8871	.8871	.8871
3	.961	.961	.961	.8871	.8501	.8501	.8501
4	1.1088	1.0719	1.0349	.924	.9979	.9979	.9979
5	1.2567	1.2197	1.1827	1.0719	1.2567	1.2567	1.2567
6	1.3676	1.4784	1.3306	1.2197	1.5524	1.4784	1.4784
7	1.8298	1.7924	1.4784	1.4563	1.7924	1.7002	1.7002
8	2.0911	1.9791	1.7924	1.7177	1.9791	1.8111	2.0328
9	2.2032	2.0538	2.0911	1.8671	2.0538	1.9791	2.1437
10	1.922	2.0538	2.0911	2.2177	1.9791	2.1285	1.9044
11	1.7741	1.9418	2.0911	2.2916	1.7924	2.0165	1.8671
12	1.6632	1.8298	1.9791	2.1437	1.7177	1.8298	1.8298
13	1.4784	1.7551	1.7551	1.848	1.643	1.6057	1.7551
14	1.4784	1.531	1.6057	1.7741	1.4563	1.4563	1.6057
15	1.4415	1.4563	1.531	1.7002	1.4563	1.4563	1.5466
16	1.4563	1.4415	1.531	1.5524	1.4563	1.4937	1.5154
17	1.5684	1.5154	1.5524	1.5154	1.5466	1.5844	1.5893
18	1.643	1.7002	1.7002	1.7002	1.5844	1.6221	1.8111
19	1.9791	1.922		1.885	1.9616	2.037	2.0538
20	1.9418	1.848	1.9044	1.8671	1.9616	2.037	2.0165
21	1.7741	1.848	1.7372	1.7924	1.848	1.8861	1.9418
22	1.5893	1.5524	1.5524	1.4784	1.4784	1.4784	1.7002
23	1.3306	1.3676	1.4415	1.3306	1.4045	1.3306	1.4784
24	1.1088	1.1088	1.1088	1.1458	1.1088	1.1827	1.1827
Max	2.2032	2.0538	2.0911	2.2916	2.0538	2.1285	2.1437
Min	.8871	.961	.961	.8871	.8501	.8501	.8501
Avg	1.5324	1.5609	1.5444	1.5561	1.5302	1.5444	1.5877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213455 / 22/22KV Siddhivinayak

Switchin

Feeder No / Name : 301 / 22KV Nyati II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4784	1.4784	3.6961	1.4784	1.4937	1.4784	1.4937
2	1.1088	1.1088	3.3265	1.4784	1.4632	1.4784	1.4784
3	1.1088	1.1088	3.3265	1.4784	1.4632	1.4784	1.4784
4	1.1088	1.1088	3.3265	1.4784	1.4632	1.4784	1.4784
5	1.1088	1.4784		1.4784	1.4937	1.4784	1.4784
6	1.4784	1.848	4.2505	1.4784	2.0538	1.4784	1.4784
7	1.8671	2.5873	4.8544	1.848	2.4272	2.2177	2.2405
8	2.6139	2.8006	5.6013	2.2405	2.8006	2.2177	2.8292
9	3.0178	2.9874	6.3481	2.2405		2.9874	2.9874
10	2.6406	2.8006	7.095	2.6139	2.6406	3.0178	2.8006
11	2.6406	2.6139	6.3481	2.6406		2.6406	2.6139
12	2.2405	2.4272	6.1614	2.6139	2.2634	2.4272	2.4272
13	2.4272	2.2405	5.9747	2.2405	2.2634	2.2405	2.2405
14	2.0538	2.2405	5.4146	2.2405		2.0538	2.0538
15	2.0538	5.9747		2.0748	2.0538	1.8671	2.0748
16	2.0748	5.788		1.8671	2.0538	.2241	2.0538
17	2.0538	1.6804		2.0538	2.0538		2.0538
18	2.2177	5.487		2.2405	2.0538		2.2405
19	2.4272	6.3481		2.6139	2.2405	2.2405	3.0178
20	2.6139	2.6139		2.2405	2.2405		2.6139
21	2.2177	5.9747		2.2634	2.2405		2.2405
22	1.8671	5.9747		2.2405	2.2405		2.2405
23	1.848	4.481		1.8671	2.2405	1.8671	
24	1.8671	1.4784	4.1076	1.8671	1.6804	1.8671	1.8671
Max	3.0178	6.3481	7.095	2.6406	2.8006	3.0178	3.0178
Min	1.1088	1.1088	3.3265	1.4784	1.4632	.2241	1.4784
Avg	2.0056	3.1096	4.9880	2.0366	2.0440	1.9336	2.1514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

PUNE ZONE[051]

RASTAPETH (U) CIRCLE[519]

RASTAPETH DIVISION[305]

ST. MARRY SUB-DN.[610] BU 4610

Substation No/ Name :- 213455 / 22/22KV Siddhivinayak

Switchin

Feeder No / Name : 302 / 22KV Nine Hills

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3734	.3696	.3734	.5601	.3734	.3696
2	.3696	.3734	.3696	.3734		.3734	.3696
3	.3696	.3734	.3696	.3734	.3734	.3734	.3696
4	.3696	.3734	.3696	.3696	.3734	.3734	.3696
5	.3696	.3734	.3696	.3696		.3734	.3696
6	.3696	.3734	.3696	.3696	.5601	.3734	.5544
7	.5601	.3734	.7468	.3696	.7468	.3734	.7468
8	.7468	.7468	.7468	.5544	.7468	.7468	.9431
9		.7468	.9335	.7468	.7468	.9335	.9335
10	.7468	.9335	.7468	.7468		.9335	.9335
11	.7468	.7468	.7468	.7468	.7392	.7468	.7468
12	.7468	.5601	.7468	.7468	.7468	.7468	.7468
13	.7468	.7468	.7468	.7468		.7468	.7468
14	.5601	.5601	.5601	.7468	.5601	.5601	.5601
15	.5601	.5601		.5601	.5601	.5544	.5601
16	.5601	.5601		.5601	.5601	.5601	.5601
17	.5601	.5601		.5487	.5601	.5601	.5601
18	.7468	.7468		.7392	.5601	.7468	.7468
19	.7468	.7468		.7392	.7468	.7468	.7468
20	.7468	.7468		.7468	.7468	.7468	.7468
21	.7468			.7468	.7468	.7468	.7468
22	.7468	.7468		.7468	.7468	.7468	.7468
23	.7468	.7468		.5601	.3734	.3734	.3734
24	.3734	.3734	.0373	.3734	.5601	.3734	.3696
Max	.7468	.9335	.9335	.7468	.7468	.9335	.9431
Min	.3696	.3734	.0373	.3696	.3734	.3734	.3696
Avg	.5916	.5845	.5486	.5815	.6157	.5910	.6215