

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 201 / 11 KV HUTATMA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.3734	.3395	.3361	.3326	.2801	.3772
2	.3224	.3734	.3395	.3361	.3326	.2801	.3772
3	.3224	.3734	.3395	.3361	.3326	.3174	.3772
4	.3326	.3734	.3395	.3361	.3361	.3547	.3772
5	.3696	.7282	.415	.3734	.4108	.415	.4715
6	.6653	.8402	.679	.6535	.6722	.6036	.6602
7	.9522	.9522	.9242	.9335	.8962	.7545	.9242
8	.8589	.7762	.8299	.8402	.7762	.6979	.7922
9	.6099	.6722	.6283	.6908	.6653	.5041	.6653
10	.5853	.5788	.5601	.5975	.5068	.4481	.6535
11	.5068	.5228	.5121	.5601	.4656	.4294	.5601
12	.4163	.4668	.5121	.4835	.5373	.3174	.5041
13	.3077	.5041	.4706	.4887	.4656	.3361	.5041
14	.4252	.5041	.4706	.4607	.4119	.3734	.5041
15	.362	.5041	.4706	.4961	.4477	.3734	
16	.443	.5041	.4706	.4835	.5373	.4481	.4854
17	.543	.5041	.5434	.5609	.5611	.5228	.5975
18		.5249	.5601	.5487	.6089	.5487	.7095
19	.9896	.7865	.7095	.8131	.8131	.7023	.8775
20	.9055	.7762	.8589	.7947	.7282	.7282	.8402
21	.8316	.6767	.7842	.7023	.5093	.6908	.7842
22	.5544	.5601	.7095	.5788	.4904	.5601	.5975
23	.5041	.3961	.3734	.4294	.3174	.4481	.3734
24	.3403	.4294	.3395	.3361	.3326	.2801	.3734
Max	.9896	.9522	.9242	.9335	.8962	.7545	.9242
Min	.3077	.3734	.3395	.3361	.3174	.2801	.3734
Avg	.5422	.5709	.5492	.5487	.5203	.4756	.5820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 202 / 11 KV WALWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.166	.181	.1867	.1578	1.2955	1.3413
2	1.2574	1.166	.181	.1867	.1595	1.2955	1.3413
3	1.2597	1.247	.181	.1867	.1595	1.2955	1.3413
4	1.2742	1.247	.181	.1867	.1612	1.3765	1.3413
5	1.4586	1.5091	.2218	.1867	.1791	1.4413	1.3413
6	1.6221	1.8652	.3018	.2614	.2896	1.8138	1.5424
7	1.8351	1.95	.3734	.3734	.3801	1.8461	1.9784
8	2.1714	1.9757		.3174	.3511	2.4078	2.3137
9	2.3569	2.304	.2926	.2801	.2507	2.4615	2.6139
10	.197	.2054	.2012	2.4291	.2126	.2241	.1865
11	.2103	2.9673	3.1855	3.086	.2279	.2241	.1867
12	.1949	2.9673	3.3196	3.1255	.2254	.2054	.1494
13	.1658	2.9673	3.3196	2.9959	.218	.1867	.1494
14	.16	2.9673	2.9843	3.0011	.2012	.1867	.1494
15	.1949	2.9673	2.73	3.0011	.1865	.1867	
16	.1734	2.9673	3.0521	3.1878	.1865	.2054	
17	.7087	2.5434	2.7496	3.0352	.208	.2241	.2054
18	.1844	2.34	2.2891	2.5652	.2427	.2254	.2241
19	.3395	.2926	.2801	.2686	.2926	.2926	.2987
20	.3109	.3109	.3174	.3045	.3109	.2896	.3174
21	.2957	.2926	.2801	.2686	.2743	.2926	.2801
22	.2263	.2561	.2241	.2328	.2378	.2561	.2241
23	.1886	.197	.1867	.1928	.1848	.2103	.1867
24	1.2574	1.1797	.1772	.1867	.1578	1.2955	1.3916
Max	2.3569	2.9673	3.3196	3.1878	.3801	2.4615	2.6139
Min	.16	.197	.1772	.1867	.1578	.1867	.1494
Avg	.8042	1.6605	1.1831	1.2519	.2273	.8225	.8684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 203 / 11 KV.BAWACHI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7558	1.7924	1.0974	1.8671	1.1706	1.0059
2	1.7924	1.7924	1.0974	1.8671	1.1706	1.0059
3	1.7924	1.7924	1.0974	1.8671	1.1706	1.0059
4	1.7924	1.829	1.0974	1.8861	1.2437	1.0059
5	1.829	2.5606	1.0974	1.8671	1.2437	1.0059
6	1.9753	2.2131		1.8671	2.3411	2.2314
7	2.1216	2.5789	2.5606	2.6406	2.4874	2.3228
8	2.3777	2.7435	2.524	2.7073	2.6703	2.2497
9	2.7984	2.8166	2.5789	2.3899	2.8898	2.4326
10	2.8715	2.8715	2.7435	2.5953	2.8715	2.5579
11	2.9447	2.8006	2.6337	2.7252	2.8715	2.5579
12	2.9995	2.7073	2.7069	2.6703	2.7435	2.5579
13	2.9264	2.7073	2.8532	2.6337	2.7801	2.7073
14	2.8898	2.7073	2.963	2.6337	2.7435	
15	2.9447	2.7073	2.9447	2.6703	2.1948	
16	.9877	.9149	1.0974	.9694	.9511	
Max	2.9995	2.8715	2.963	2.7252	2.8898	2.7073
Min	.9877	.9149	1.0974	.9694	.9511	1.0059
Avg	2.3000	2.3459	2.0729	2.2411	2.0965	1.8959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 204 / 11 KV PADAWALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.132	1.0526	1.1022	.9116	.132	.1307
2	.1509	.132	1.0526	.9326	.9116	.132	.1307
3	.1509	.132	1.0526	1.1145	.9221	.132	.1307
4	.1509	.132	1.0526	1.1145	.9389	.1698	.1307
5	.1886	.1886	1.0526	1.1022	1.0608	.1886	.1867
6	.2452	.2263	1.247	1.5261	1.166	.2829	.2614
7	.3395	.3395	1.7004	1.7804	1.3117	.3584	.3734
8	.2641	.2641	1.7814	1.8482	1.4883	.2829	.2801
9	.2452	.2452	1.7004	1.7465	1.6004	.2075	.2427
10	2.0567	.1307	.1509	.1509		.1886	.2241
11	2.4453	.0566	.1509	.1509	2.0965	2.4587	2.4587
12	2.5101	.1307	.1509	.1509	2.1445	2.4587	2.4587
13	2.3158	.1307	.132	.2402	2.1445	2.2405	2.4587
14		.1307	.132	.2353	2.0965	2.3739	2.4078
15	2.3158	.1307	.132	.1132	2.1125	2.2891	2.2043
16	2.3158	.1307	.1509	.132	2.1285	2.2891	2.3777
17	2.2186	.1307	.1509	.1509	2.1925	2.2043	1.8652
18	2.0243	.1867	.2054	.2075	1.9109	1.9271	1.6956
19	.3018	.2743	.2452	.2641	.2641	.2427	.2987
20	.2452	.2241	.2614	.2452	.2641	.2801	.2614
21	.2263	.3841	.2241	.2263	.2263	.2427	.2614
22	.1886	.1867	.1867	.1698	.1698	.2054	.1867
23	.1509	.1494	.1307	.132	.1509	.1494	.168
24	.1509	.132	1.0688	1.1145	.9116	.132	.1307
Max	2.5101	.3841	1.7814	1.8482	2.1925	2.4587	2.4587
Min	.1509	.0566	.1307	.1132	.1509	.132	.1307
Avg	.9284	.1792	.6319	.6646	1.2663	.8987	.8885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 205 / 11 KV HUTATMA DUDH SANGH NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.6722	.6161	.6535	.5601	.6722	.6722
2	.6535	.6722	.6161	.6535	.5601	.6722	.6722
3	.6535	.6722	.6161	.6535	.5228	.6722	.6722
4	.6535	.6908	.6161	.6535	.5228	.6908	.6722
5	.7095	.6908	.6161	.6535	.5228	.6908	.6722
6	.7095	.7095	.6161	.5601	.5041	.7095	.6722
7	.7282	.7282	.6535	.5041	.5041	.7282	.7468
8	.7282	.7095	.7468	.5228	.6161	.7468	.7282
9	.8215	.8029	.7282	.6908	.7282	.7842	.8029
10	.7468	.8775	.8775	.6908	.6722	.8402	.8029
11	.7655	.8775	.8775	.7468	.7468	.7468	.8215
12	.8029	.8589	.8962	.7655	.7842	.3921	.8215
13	.7655	.8215	.8589	.7095	.7468	.5228	.7468
14	.7468	.7842	.8589	.7095	.6908	.7468	.7095
15	.7655	.7842	.8215	.6535	.7095	.7468	
16	.7282	.7842	.8215	.5601	.7468	.7468	
17	.8029	.7468	.9709	.6348	.8215	.8215	
18	.7655	.7655	.6908	.6161	.8402	.8215	
19	.6535	.695	.6908	.6161	.7468	.7655	
20	.6535	.6908	.6908	.6161	.6535	.6161	
21	.6161	.6626	.7468	.6348	.7282	.6161	
22	.6348	.7468	.7468	.6348	.7842	.7655	
23	.7095	.7095	.7468	.5788	.6908	.6908	
24	.6908	.6722	.6908	.6908	.5788	.6722	.7282
Max	.8215	.8775	.9709	.7655	.8402	.8402	.8215
Min	.6161	.6626	.6161	.5041	.5041	.3921	.6722
Avg	.7149	.7427	.7422	.6418	.6659	.7033	.7294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 206 / 11KV AHIRWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1509	.1509	.1867	.1698	.1307	.1698
2	.168	.1509	.1509	.1867	.1698	.1307	.1698
3	.168	.1509	.1509	.1867	.1698	.1307	.1698
4	.168	.1509	.1509	.1867	.1698	.1663	.1698
5	.2075	.1867	.2263	.2614	.2263	.2218	.2263
6	.3395	.3511	.3395	.3361	.3361	.3511	.3584
7	.4527	.4715	.4715	.3734	.4481	.4294	.415
8	.4854	.4294	.4338	.3734	.4251	.4668	.3921
9	.3921	.3326	.3109	.2987	.3547	.3547	.3361
10	.3696	.2987	.3326	.2957		.2614	.3361
11	.2195	.2801	.2926	.3077	.2481	.2801	
12	.2378	.2427	.2561	.2587	.2126	.2801	.3174
13	.2534	.2241	.2378	.2402	.1991	.2241	.2543
14	.2149	.2241	.2195	.2353		.2241	.2427
15	.168	.2241	.2172	.2241	.1448	.2054	.2427
16	.1829	.1867	.2033	.1663	.181	.2054	.2427
17	.2012	.2801	.2402	.2195	.2353	.2614	.2987
18	.2957	.2926	.3361	.3361	.3077	.3224	.3361
19	.4481	.4572	.3734	.4481	.462	.4572	.4481
20	.4481	.4481	.4481	.4294	.4344	.4805	.4481
21	.3961	.4024	.4294	.3734	.3921	.462	.3734
22	.3584	.3206	.3734	.2987	.2957	.3174	.2987
23	.2054	.2075	.2054	.2218	.2241	.2054	.2054
24	.1494	.1509	.1509	.3361	.1698	.1307	.1698
Max	.4854	.4715	.4715	.4481	.462	.4805	.4481
Min	.1494	.1509	.1509	.1663	.1448	.1307	.1698
Avg	.2791	.2756	.2792	.2825	.2716	.2792	.2879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 207 / 11KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4748	.502	.0566	.0566	.0566	.0566	.4858
2	.4748	.502	.0566	.0566	.0566	.0566	.4858
3	.4748	.502	.0566	.0549	.0566	.0566	.4858
4	.5087	.5182	.0566	.0566	.0566	.0566	.4858
5	.503	.583	.0566	.0566	.0566	.0566	.4858
6	.5365	.6154	.0566	.0566	.0566	.0754	.5992
7	.5868	.6964	.0754	.0566	.0566	.0566	.6478
8	.6203	.7611	.0943	.0566	.0566		.7125
9	.6706	.8259	.0566	.0566	.0566	.4858	.7611
10	.0566	.056	.0509	.9231	.0566	.0566	.0566
11	.0566	1.0682	1.0513	.9878	.0566	.0566	.0566
12	.0754	1.0802	1.0277	1.004	.0754	.0566	.056
13	.0566	1.0682	1.0277	1.004	.0754	.0566	.0566
14	.0377	1.1022	1.0277	1.004	.1715	.0566	.0566
15	.0566	1.0174	1.0111	.9878	.0754	.0566	
16	.0754	.9835	1.0227	1.0688	.0754	.0566	
17	.0566	.9496	.9282	.9878	.0566	.0566	
18	.0566	.8951	.8453	.9116	.0754	.0754	
19	.0566	.0549	.0566	.0566	.0566	.0566	
20	.0754	.0566	.0566	.0566	.0566	.0566	
21	.0754	.0732	.0566	.0566	.0566	.0566	
22	.0566	.0566	.0566	.0566	.0566	.0566	
23	.0566	.0566	.0566	.0566	.0566	.0566	
24	.4801	.502	.0566	.0566	.0566	.0566	.4858
Max	.6706	1.1022	1.0513	1.0688	.1715	.4858	.7611
Min	.0377	.0549	.0509	.0549	.0566	.0566	.056
Avg	.2575	.6053	.3708	.4053	.0653	.0769	.3945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 208 / 11KV Kisan No 3 LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0185	.0185	.0183	.0185	.0185
2	.0185	.0739	.0185	.0183	.0185	.0185
3	.0185	.0739	.0185	.0183	.0185	.0185
4	.0185	.1109	.0185	.0183	.0185	.0185
5	.0185	.1109	.0185	.0183	.0185	.0185
6	.1109	.1109	.1109	.1097	.1109	.0995
7	.1109	.1294	.1109	.1097	.1109	.1109
8	.1109	.2218	.0185	.2195	.2218	.2218
9	.1109	.2402	.0185	.2195	.2402	.2241
10	.0185	.2427	.0185	.2195	.2402	.2241
11	.2218	.2378	.0185	.2378	.2218	.2241
12	.2218	.2427	.0185	.2378	.2402	.2427
13	.2218	.2378	.0185	.2402	.2402	.2378
14	.2218	.2378	.2402	.2402	.2218	.2378
15	.2218	.2378	.2402	.2402	.2218	.2378
16	.2218	.2378	.2402	.2402	.2402	.2378
Max	.2218	.2427	.2402	.2402	.2402	.2427
Min	.0185	.0185	.0185	.0183	.0185	.0185
Avg	.1178	.1728	.0716	.1504	.1502	.1494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 401 / 33KV Walwa LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8656	.9877	1.2071	1.5364	1.2071	.9877
2	1.3169	.9877	1.2071	1.5364	1.2071	.9877
3	1.4266	1.0974	1.2071	1.5364	1.2071	.9877
4	1.4266	1.3169	1.2071	1.5364	1.2071	.9877
5	1.4266	1.3169	1.2071	1.5364	1.2071	.9877
6	1.4815	1.5912	1.5364	1.5364	1.5364	1.5364
7	1.5912	1.701	1.5364	1.5364	1.5364	1.5364
8		1.9204	1.6461	1.8107	1.7558	1.701
9	2.0302	2.0302	1.9753	1.8107	1.9753	1.6461
10	2.0302	1.9753	1.9753	1.9204	1.9753	1.5364
11	2.0302	2.0302	1.9753	2.0302	1.9753	1.5684
12	2.0302	2.0302	2.0302	2.0302	1.9753	1.6461
13	2.0302	2.0302	2.0302	1.9753	1.9753	1.6461
14	1.9753	2.0302	2.0302	1.9753	1.9753	1.6461
15	2.0302	2.0302	2.0302	1.9753	1.8656	1.6461
16	1.3169	1.3169	1.3169	1.3717	1.3169	.9328
Max	2.0302	2.0302	2.0302	2.0302	1.9753	1.701
Min	1.3169	.9877	1.2071	1.3717	1.2071	.9328
Avg	1.7339	1.6495	1.6324	1.7284	1.6187	1.3738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 201 / 11 KV. SHIGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3961	.0107	.0229	.04	.535	.5502
2	.4572	.4064	.0107	.0255	.04	.535	.5502
3	.4793	.3814	.0114	.0267	.0394	.535	.5575
4	.5144	.4161	.0114	.0267	.0389	.5281	.5575
5	.5792	.4515	.0103	.0274	.04	.5575	.5796
6	.6161	.4489	.0103	.0278	.0412	.7335	.5944
7	.6455	.5868	.0114	.0267	.0394	.8025	.7133
8	.7133	.8278	.0171	.0259	.0406	.8619	.8322
9	.7526	.7526	.0114	.0354	.0269	.8509	.8173
10	.0206	.0171	.0152	.0213	.0152	.0211	
11	.0286	1.142	1.2498	1.3117	.0145	.0263	.032
12	.032	1.2346	1.2498	1.3117	.0133	.0067	.0198
13	.0343	1.358	1.2498	1.2346	.0133	.0069	.0179
14	.0314	1.3123	1.2498	1.1888	.0137	.0133	.0225
15	.0274	1.2803	1.2498	1.1431	.0137	.0133	.0343
16	.028	1.2643	1.2498	1.0669	.0152	.0133	.0343
17	.0286	1.2803	1.1717	1.0364	.0171	.0069	.0297
18	.0314	.9242	1.0936	.8025	.0179	.024	.0412
19	.0434	.0171	.0229	.036	.021	.032	.0404
20	.045	.0171	.0366	.0372	.0314	.0225	.0396
21	.0326	.04	.0244	.0427	.0221	.021	.0396
22	.0291	.044	.0229	.028	.0183	.0191	.0246
23	.0286	.0293	.021	.024	.0168	.021	.024
24	.4344	.3715	.0122	.0217	.0291	.5418	.4988
Max	.7526	1.358	1.2498	1.3117	.0412	.8619	.8322
Min	.0206	.0171	.0103	.0213	.0133	.0067	.0179
Avg	.2538	.6250	.4177	.3980	.0258	.2804	.2892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 202 / 11 KV. BHADKAMBE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3688	.3761	.4066	.3944	.4024	.39
2	.3688	.3801	.4066	.4031	.4024	.3944
3	.3353	.3898	.4066	.4031	.3982	.4031
4	.3391	.4119	.4024	.4075	.394	.4031
5	.3391	.4163	.4024	.4075	.3898	.4075
6	.3391	.4075	.4024	.4031	.394	.4119
7	.3391	.4031	.4024	.3506	.4119	.4075
8	.3544	.4075	.3658	.3506	.3898	.4075
9	.3658	.0023	.3429	.3898	.4031	.4119
10	.4119	.3658	.3856	.3898	.3856	
11	.4031	.3658	.3898	.4075	.3856	.4031
12	.4031	.4024	.394	.4075		.3898
13	.1658	.4024		.4031	.3856	.3898
14	.4075	.3658		.4075	.3898	.4075
15	.4031	.3658		.4075	.2263	.4075
16	.2454	.2195		.2454	.1658	.2454
Max	.4119	.4163	.4066	.4075	.4119	.4119
Min	.1658	.0023	.3429	.2454	.1658	.2454
Avg	.3493	.3551	.3923	.3861	.3683	.392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 203 / 11 KV.POKHARNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.037	.037	.0366	.0554	.0362	.0532
2	.0532	.056	.0351	.037	.056	.0362	.0543
3	.0537	.0549	.0532	.037	.056	.0362	.0549
4	.0543	.0554	.0701	.037	.0566	.0366	.0914
5	.0732	.056	.0686	.0747	.056	.0366	.0924
6	.0924	.0754	.0857	.0934	.0554	.0724	.1109
7	.1109	.0747	.0857	.0732	.0754	.0905	.1109
8	.1254	.0716	.1029	.0543	.1063	.0895	.1086
9	.1448	.0532	.0838	.0747	.0693	.0895	.0914
10	.0892	.0514	.0876	.0709	.0686	.0686	
11	.116	.0876	.0886	.0732	.0876	.0701	.0549
12	.0366	.0514	.0895	.0732	.0709	.0514	.0554
13	.0179	.0339	.0905	.1029	.0716	.0497	.0549
14	.0183	.0514	.0886	.0693	.0686	.0503	.0554
15	.037	.1029	.0876	.0876	.0671	.0497	.056
16	.0474	.12	.0701	.0716	.0949	.0503	.056
17	.0509	.1029	.0663	.0724	.08	.0509	.0716
18	.0335	.0857	.0819	.104	.08	.0648	.052
19	.1214	.1227	.1086	.1086	.1086	.1063	.0686
20	.1063	.1052	.1097	.1294	.1097	.1086	.128
21	.0924	.0857	.0924	.0924	.0914	.128	.0739
22	.056	.0754	.0724	.0554	.0905	.1109	.0549
23	.0554	.0566	.0537	.0543	.0362	.0747	.0549
24	.0362	.0366	.0377	.0366	.0366	.0362	.0543
Max	.1448	.1227	.1097	.1294	.1097	.128	.128
Min	.0179	.0339	.0351	.0366	.0362	.0362	.052
Avg	.0698	.0710	.0770	.0717	.0729	.0664	.0721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 204 / 11 KV SHIGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1509	.1132	.1132	.1494	.1132	.132
2	.1132	.1509	.1132	.1132	.1494	.1132	.132
3	.1132	.1509	.1132	.1132	.056	.1132	.132
4	.2075	.1886	.2263	.1132	.1886	.1132	.132
5	.2829	.2263	.3395	.3772	.3772	.1509	.1886
6	.3395	.3584	.3772	.4481	.4527	.2614	.3772
7	.3772	.4668	.4481	.3734	.4854	.4108	.4294
8	.3326	.3734	.3921	.3292	.4251	.3696	.3696
9	.3109	.2926	.2926	.3258	.3224	.3292	.2926
10	.2835	.2229	.2454	.2957	.2507	.2481	
11	.2401	.2279	.2103	.2328	.2149	.2303	.2774
12	.2103	.2328	.2126	.1949	.2126	.2103	.2229
13	.2103	.2149	.2126	.1949	.2126	.208	.208
14	.1543	.1867	.1772	.1772	.1791	.208	.2149
15	.1886	.1867	.2126	.1595	.1791	.1928	.1991
16	.208	.1867	.1772	.1753	.1753	.1928	.2126
17	.2378	.1867	.1791	.1949	.2103		.218
18	.2454	.2103	.2149	.2713	.2481	.2601	.2835
19	.4557	.3658	.3658	.4298	.3292	.4344	.3982
20	.4656	.4024	.3696	.439	.4108	.439	.4207
21	.3881	.4024	.3361	.3547	.3734	.3696	.3734
22	.2829	.2263	.2987	.2829	.3361	.2829	.2614
23	.1886	.1509	.1886	.1886	.1867		.1848
24	.1132	.1509	.1132	.1132	.1509	.1132	.1509
Max	.4656	.4668	.4481	.4481	.4854	.439	.4294
Min	.1132	.1509	.1132	.1132	.056	.1132	.132
Avg	.2526	.2464	.2471	.2505	.2615	.2438	.2527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 205 / 11 KV POKHARNI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0179	.5796	.5944	.3668	.0358	.0335
2	.0366	.0177	.5868	.5944	.3913	.0362	.0343
3	.0366	.0175	.5868	.5944	.3963	.0362	.0351
4	.037	.0181	.5944	.5944	.3864	.0366	.0537
5	.037	.0179	.7526	.6622	.4401	.0366	.0549
6	.0554	.0549	.9031	.7225	.503	.0554	.0549
7	.0739	.0739	.9482	.743	.5268	.0554	.0554
8	.0739	.0543	1.1443	.7727	.6472	.0549	.0739
9	.0686	.0175	1.1443	.8916	.8173	.0543	.056
10	.0335	.0526	.0373	.0526	.0335	.0366	
11	1.2498	.0686	.0354	.0339	.9755	1.0235	.9031
12	1.3108	.0332	.0354	.0514	.9934	1.0536	1.0235
13	1.034	.0335	.0351	.0463	.9934	1.0837	1.0562
14	1.0517	.0514	.0354	.0305	.9633	1.0837	1.0974
15	1.2597	.0514	.0354	.0301	.7133	.9511	.9934
16	1.0997	.0343	.0343	.0305	.7922	.9181	.602
17	1.0848	.0343	.0332	.0309	.7727	.8688	.7579
18	.8655	.052	.048	.0351	.7133	.7727	.6516
19	.0358	.0514	.0526	.0716		.0526	.0171
20	.0347	.0526	.0532	.0724	.0543	.0532	.0171
21	.0362	.0514	.0537	.0358	.0543	.0514	.017
22	.0179	.0189	.0354	.0171	.0324	.0503	.0162
23	.0175	.0189	.0351	.0158	.032	.0339	.0164
24	.0335	.017	.5213	.4161	.333	.0358	.0168
Max	1.3108	.0739	1.1443	.8916	.9934	1.0837	1.0974
Min	.0175	.017	.0332	.0158	.032	.0339	.0162
Avg	.4007	.0380	.3467	.2975	.5188	.3529	.3321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 206 / HUTATMA SURESHKUMAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2561	.2829	.0191	.0191	.0191
2	.2641	.2772	.2829	.0191	.0191	.0191
3	.2641	.2743	.2829	.0191	.0191	.0191
4	.2641	.2743	.2801	.0191	.0191	.0191
5	.2614	.2743	.2801	.0191	.0191	.0191
6	.2801	.2743	.2801	.0191	.0191	.0191
7	.2801	.2743	.2801	.2452	.2402	.0191
8	.2772	.2743	.2801	.2641	.2743	.2829
9	.2772	.2402	.2743	.2641	.2772	.2829
10	.2743	.2587	.2829	.2829	.2829	
11	.2743	.2772	.2829	.2829	.2829	.2829
12	.2743	.2743	.2829	.2829	.2829	.2829
13	.2743	.2743	.0029	.3018	.2829	.2829
14	.2772	.2743	.2641	.3018	.2829	.2829
15	.2772	.2743	.2641	.3018	.1334	.2829
16	.2772	.2743	.0191	.2829	.2641	.2641
Max	.2801	.2772	.2829	.3018	.2829	.2829
Min	.2614	.2402	.0029	.0191	.0191	.0191
Avg	.2726	.2704	.2452	.1828	.1699	.1585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 207 / 11KV Bahadurwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2751	.2347	.0189	.0189	.0189	.2378	.2572
2	.2751	.2462	.0189	.0189	.0189	.2378	.2606
3	.2896	.2429	.0189	.0189	.0189	.2378	.2606
4	.2934	.2538	.0189	.0189	.0189	.2347	.2641
5	.3269	.2606	.0373	.0189	.0189	.2641	.2641
6	.3567	.2787	.0373	.0189	.0377	.3814	.2934
7	.3864	.3668	.0373	.0183	.0377	.4161	.3913
8	.4458	.4012	.0377	.0179	.0373	.4458	.5053
9	.431	.4967	.0189	.0187	.0189	.4401	.4904
10	.0189	.0189	.0175	.0183	.0183	.0177	
11	.0183	.695	.6874	.602	.0181	.0179	.0179
12	.0158	.7316	.7011	.6097	.0181	.0181	.0181
13	.0177	.7316	.7011	.5796	.0179	.0181	.0179
14	.0179	.703	.5944	.5719	.0175	.0183	.0177
15	.0179	.6859	.5944	.5639	.0171	.0185	.0181
16	.0179	.6687	.6321	.5428	.0171	.0185	.0179
17	.0171	.6516	.602	.535	.017	.0187	.0173
18	.017	.6036	.5647	.5053	.017	.0164	.0351
19	.0183	.0189	.0185	.0183	.0185	.0185	.0183
20	.0185	.0189	.0185	.0185	.0187	.0187	.0185
21	.0185	.0189	.0187	.0373	.0187	.0187	.0187
22	.0185	.0189	.0187	.0187	.0187	.0187	.0187
23	.0185	.0189	.0185	.0187	.0187	.0187	.0189
24	.2641	.2317	.0189	.0189	.0189	.2408	.2
Max	.4458	.7316	.7011	.6097	.0377	.4458	.5053
Min	.0158	.0189	.0175	.0179	.017	.0164	.0173
Avg	.1498	.3582	.2271	.2011	.0207	.1413	.1496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 401 / 33KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.5658	.7356	.2641	.0114	.0057
2	.6859	.6224	.7356	.3961	.0103	.0057
3	.6859	.6224	.7356	.3961	.0114	.0057
4	.6859	.679	.679	.3961	.008	.0549
5	.6859	.679	.679	.3961	.0091	.4572
6	.6859	.679	.679	.3961	.0103	.6859
7	.6859	.679	.679	.3961	.0091	.6859
8	.9145	.9619	.9054	.5716	.6859	.9054
9	.9054	.9619	.9619	.6287	.6859	.9054
10	.9619	.9619	.9054	.6287	.6287	
11	.9619	.9619	.9054	.6859	.6287	
12	.9619	.9054	.9054	.6859	.6287	
13	.4481	.9054	.9054	.6859	.6287	
14	.9619	.9054	.9054	.6859	.6287	
15	.9619	.9054	.9054	.6859	.2743	
16	.679	.9054		.5658	.5658	
23		.0566				
Max	.9619	.9619	.9619	.6859	.6859	.9054
Min	.4481	.0566	.679	.2641	.008	.0057
Avg	.7844	.7622	.8148	.5291	.3391	.4124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 201 / 11 KV KRISHNAMAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.2949			.2155
2	.2652	.2949			.2155
3	.2652	.2949			.2347
4	.2652	.2949			.2347
5	.2652	.2949			.2347
6	.2818	.2949			.2743
7	.2915	.2812			.2652
8	.2915	.2949			.3315
9	.3277	.3761			.3647
11		.4807	.4973	.5182	
12		.5138	.5571	.5182	
13		.4915	.5636	.5182	
14		.5868	.5243	.4534	
15		.5636	.5243	.4534	
16		.5735	.5079	.4534	
17		.5801	.4961	.4534	
18		.4862	.4915	.4372	
24	.2561	.2812			.1966
Max	.3277	.5868	.5636	.5182	.3647
Min	.2561	.2812	.4915	.4372	.1966
Avg	.2775	.4044	.5203	.4757	.2567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 202 / 11KV MAHALAXMI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1963	1.2178	1.2048	1.2437	1.1946	1.2437
2	1.1963	1.2178	1.2178	1.2437	1.1946	1.2308
3	1.1963	1.2178	1.2489	1.2567	1.1946	1.2437
4	1.2136	1.2178	1.2357	1.2567	1.1946	1.2308
5	1.2136	1.2178	1.2357	1.2489	1.1946	1.2308
6	1.2136	1.2178	1.2489	1.2489	1.1946	1.2308
7	1.2136	1.2178	1.2357	1.2178	1.1946	1.2437
8	1.2136	1.2178	1.2226	1.2536	1.2308	1.1999
9	1.2136	1.3306	1.2536	1.267	1.2178	1.2437
10	1.2894	1.2757	1.267	1.3032	1.2308	1.2437
11	1.2894	1.2757	1.2851	1.3032	1.1999	1.2437
12	1.2536	1.2757	1.2178	1.3032	1.2178	1.2437
13	1.2894	1.2757	1.267	1.267	1.2178	1.2437
14	1.2894	1.2894	1.2803	1.267	1.1999	1.2437
15	1.2894	1.2715	1.267	1.267	1.1999	1.2437
16	1.2536	1.2403	1.2536	1.2308	1.1871	1.2437
Max	1.2894	1.3306	1.2851	1.3032	1.2308	1.2437
Min	1.1963	1.2178	1.2048	1.2178	1.1871	1.1999
Avg	1.2390	1.2486	1.2463	1.2612	1.204	1.2377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 203 / 11KV YASHWANT AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.4641			.3561	.3688
2	.2774	.4641				.4024
3	.2774	.4641				.4024
4	.2774	.4641				.4024
5	.2774	.4641				.4359
6	.2947	.4641				.5087
7	.3277	.4641				.5765
8	.3605	.57				.5967
9	.4588	.8048				.663
11		1.3077	1.406	1.094		
12		1.4083	1.4243	1.094		
13		1.3077	1.4243	1.1271		
14		1.4243	1.406	1.1271		
15		1.3565	1.3375	1.1271		
16		1.3077	1.1191	.9282		
17		1.3226	1.2209	1.0277		
18		1.1904	1.2003	.9614		
24	.2984	.3978			.3018	.3688
Max	.4588	1.4243	1.4243	1.1271	.3561	.663
Min	.2652	.3978	1.1191	.9282	.3018	.3688
Avg	.3115	.8693	1.3173	1.0608	.3290	.4726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 204 / 11 KV ASHTA PWW

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0709	.0716	.0716		.0709	.0709
2	.0716	.0709	.0709	.0716	.0709	.0709	.0709
3	.0716		.0709	.0716	.0709	.0709	.0716
4	.0716	.0709	.0709	.0716	.0709	.0716	.0709
5	.0716	.0709	.0716	.0716	.0716	.0716	.0716
6	.0716	.0709	.0716	.0716	.0716	.0716	.0716
7	.0709	.0709	.0716	.0716	.0709	.0709	.0716
8	.0709	.0709	.0701	.0709	.0709	.0701	.0716
9	.0709	.0709	.0709	.0709	.0709	.0701	.0716
10	.0709	.0709	.0716	.0709	.0716	.0701	.0701
11	.0709	.0709	.0709	.0709	.0701		.0716
12	.0709	.0709	.0709	.0709	.0709		.0716
13	.0709	.0701	.0709	.0709	.0709		.0716
14	.0709	.0716	.0709	.0709	.0709		.0716
15	.0709	.0709	.0709	.0709	.0709		.0716
16	.0709	.0709	.0709	.0709	.0701		.0716
17	.0709	.0709	.0716	.0709	.0701		.0716
18	.0709	.0709	.0716	.0709	.0701		.0716
19	.0709	.0701	.0709	.0716	.0701		.0716
20	.0709	.0701	.0709	.0716	.0701		.0709
21	.0701	.0701	.0716	.0716	.0701	.0701	.0701
22	.0701	.0701	.0716	.0716	.0701	.0701	.0701
23	.0701	.0716	.0716	.0716	.0701	.0709	.0701
24	.0709	.0709	.0716	.0716	.0716	.0716	.0709
Max	.0716	.0716	.0716	.0716	.0716	.0716	.0716
Min	.0701	.0701	.0701	.0709	.0701	.0701	.0701
Avg	.0710	.0708	.0712	.0713	.0707	.0708	.0712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 205 / 11KV TRYAMBKESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0053	.1307	.0732	.005	.0048	.005
2	.0053	.1307	.0732	.0051	.0048	.005
3	.0053	.1307	.0924	.005	.0048	.0051
4	.0053	.1307	.0924	.005	.0048	.005
5	.0053	.1307	.0934	.005	.0048	.0051
6	.0053	.1307	.0924	.005	.0048	.0051
7	.0943	.1307	.0924	.0044	.0876	.112
8	.0943	.2149	.343	.2149	.1753	.197
9	.0943	.2149	.1734	.2149	.156	.2328
10	.1494	.2328	.1734	.2149	.1753	.2103
11	.1494	.2328	.1753	.2149	.1734	.2103
12	.168	.2328	.1734	.2149	.1734	.2103
13	.2218	.2328	.1734	.2149	.1734	.2103
14	.2218	.2328	.1753	.2149	.1734	.2103
15	.2218	.2328	.1753	.2149	.1734	.2103
16	.2103	.2328	.1734	.1075	.1734	.2103
18						.2103
Max	.2218	.2328	.343	.2149	.1753	.2328
Min	.0053	.1307	.0732	.0044	.0048	.005
Avg	.1036	.1859	.1466	.1163	.1040	.1326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 206 / 11KV Dhadak LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.1029	.0693	.1372	.0191	.2294
2	.1341	.1029	.0701	.1372	.0191	.2321
3	.1341	.1029	.0709	.1372	.0191	.2321
4	.1341	.1029	.0886	.1372	.0191	.2347
5	.1341	.1029	.0876	.1372	.0191	.2321
6	.2012	.1029	.0876	.1372	.0191	.2294
7	.1989	.1029	.0857	.663	.0829	.6962
8	.3647	.1029	.8029	.7459	.7293	.7956
9	.2321	.2743	.8453	.7956	.7956	.8288
10	.3391	.2515	.7373	.7956	.8551	.8421
11	.3391	.2683	.763	.7956	.8356	.8745
12	.3391	.2429	.8453	.7625	.8453	.8745
13	.3391	.2652	.8453	.7625	.8453	.9175
14	.3391	.3521	.8718	.7956	.8453	.9175
15	.3391	.5898	.7712	.7956	.8453	.9175
16	.3391	.5533	.6226	.431	.7125	.5571
Max	.3647	.5898	.8718	.7956	.8551	.9175
Min	.1341	.1029	.0693	.1372	.0191	.2294
Avg	.2526	.2263	.4790	.5104	.4692	.6007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 201 / 11KV BAGNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.052	.0554	.9282	.7682	.6249	.0554	.0537
2	.0543	.0549	.9282	.759	.6249	.0549	.0537
3	.0543	.0554	.9282	.7682	.6249	.0549	.0537
4	.0549	.0554	.9282	.7773	.6325	.0554	.0549
5	.0549	.0732	.9393	.7865	.6483	.0739	.0549
6	.0739	.0924	.9374	.8482	.6958	.0914	.0739
7	.0924	.1097	.9686	.9217	.9012	.0914	.0934
8	.0934	.0732	1.2334	1.1385	1.1469	.0905	.0934
9	.0554	.0716	1.1702	1.1248	1.4403	.0514	.0724
10	.0549	.0526	.048	1.0562	.0486	.0549	.0693
11	2.1628	.0497	.0509		2.0405	2.1216	1.8351
12	2.2211	.0497	.0514	.0503	2.1382	2.0885	1.9498
13	2.1052	.048	.0514	.0486		1.9662	1.9372
14	2.0481	.0469	.0474	.0486	2.0481	1.9662	1.9725
15	2.0317	.0328	.0469	.0316	2.0165	1.9062	1.9334
16	1.9595	.0328	.0474		1.9925		1.8679
17	1.8343	.052	.0678	.0486	1.9524		1.757
18	1.6549	.0503	.0549	.0686	1.8623	1.4251	1.5074
19	.0554	.052	.0693	.0686	.0554	.0543	.0509
20	.0732	.0716	.0701	.0678	.0732	.0543	.0509
21	.0739	.0716	.0709	.0686	.0739	.0543	
22	.0732	.0526	.0514	.0514	.0701	.0532	.0509
23	.0554	.0514	.0509	.0516	.0716	.0526	.0503
24	.052	.056	.9282	.759	.6562	.0543	.0537
Max	2.2211	.1097	1.2334	1.1385	2.1382	2.1216	1.9725
Min	.052	.0328	.0469	.0316	.0486	.0514	.0503
Avg	.7100	.0588	.4445	.4687	.9756	.5669	.6822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 202 / 11KV ASHTA CHADOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0486	.3395	.3887	.3353	.0469	.0463
2	.0305	.048	.3437	.3932	.3161	.0474	.0469
3	.0309	.0474	.3437	.3887	.3161	.048	.0469
4	.0309	.0469	.3395	.3932	.3048	.0648	.0469
5	.0469	.0633	.3395	.3978	.3241	.0983	.0625
6	.0625	.064	.3749	.4424	.3506		.0762
7	.0937	.0791	.4572	.4801	.381		.0914
8	.0949	.096	.5487	.5735	.4531	.0829	.1067
9	.064	.08	.5898	.502	.5121	.08	.081
10	.0474	.0474		.4843	.0633	.064	.0663
11	.7499	.0937			.4938	.6562	.6718
12	.7907	.0625	.0492	.0474	.5312	.7811	.8288
13	.7362	.0463	.0497	.0463	.5441	.7316	.7865
14	.6718	.0457	.0328	.0463	.5535	.6706	.8122
15	.6325	.0305	.0328	.0457	.5761	.6706	.7865
16	.571	.0305	.0332	.0309			.7209
17	.5624	.0914	.0492	.0457	.5761		.6796
18	.5376	.0625	.0497	.0617	.5506	.5693	.5992
19	.048	.0781	.0655	.0602	.0633	.0625	.0829
20	.0633	.0772	.0829	.0781	.08	.0781	.0819
21	.064	.0772	.0819	.0625	.0791	.0762	.0829
22	.0633	.0617	.0663	.0469	.0648	.0772	.0678
23	.0469	.0457	.0492	.0474	.0469	.0617	.0503
24	.2084	.048	.3353	.3841	.3395	.0474	.0463
Max	.7907	.096	.5898	.5735	.5761	.7811	.8288
Min	.0305	.0305	.0328	.0309	.0469	.0469	.0463
Avg	.2616	.0613	.2116	.2368	.3415	.2507	.2904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 203 / 11KV SHIGAON RIVER AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9393	1.004	.0377	.0366	.037	1.0883	1.1271
2	.8907	.9922	.0377	.037	.037	1.0753	1.1271
3	.9012	1.012	.0377	.037	.0373	1.0753	1.1271
4	.8848	1.012	.0377	.0366	.0377	1.0936	1.1271
5	.8962	1.0364	.0377	.0366	.0377	1.1523	1.1271
6	.9282	1.166	.0377	.037	.0377	1.1385	1.1934
7	.9282	1.2452	.0377	.0366	.0373	1.2452	1.326
8	1.0688	1.3748	.0373	.037	.0377	1.3279	1.3763
9	1.1603	1.5912	.037	.0377	.037	1.3279	1.3108
10	.0366	.0366	.0366	.0377	.0366	.0377	.0366
11	.037	2.0454	2.0553		.037	.0377	.0366
12	.0366	2.146	2.1956	2.3807	.037	.7811	.0366
13	.037	2.1795	2.2283	2.2775		.0377	.0366
14	.0366	2.0119	2.2708	2.1956	.0366	.037	.0343
15	.037	1.989	2.2211	2.1628	.037	.037	.0358
16	.037	1.989	2.1792	2.1795	.0366		.0351
17	.0366	2.1125	2.2131	2.0719	.037		.0362
18	.037	1.9113	2.1216	1.9062	.037	.0373	.0358
19	.037	.0377	.0343	.0377	.0366	.0373	.0366
20	.0366	.0377	.0373	.0377	.037	.0377	.0366
21	.037	.0377	.037	.0377	.037	.0377	
22	.0373	.0377	.037	.0377	.0377	.0377	.0366
23	.037	.0377	.037	.0377	.0373	.0377	.0366
24	.9995	1.0277	.0377	.037	.0373	1.166	1.1271
Max	1.1603	2.1795	2.2708	2.3807	.0377	1.3279	1.3763
Min	.0366	.0366	.0343	.0366	.0366	.037	.0343
Avg	.4214	1.1696	.7533	.6856	.0371	.5856	.5408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 204 / SWARAJYA AGRO INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1494	.2641	.1848	.181	.1867	.2263
2	.1294	.1478	.2641	.1829	.1791	.2218	.2263
3	.1267	.1848	.2641	.1829	.1663	.2218	.2263
4	.1448	.1867	.2641	.1848	.1753	.2241	.2263
5	.1463	.1478	.2641	.2012	.1886	.2614	.2263
6	.1478	.1848	.2641	.2218	.1715	.2587	.2263
7	.1448	.1848	.2614	.2033	.1267	.2241	.2263
8	.1629	.2241	.2587	.2033	.1296	.2218	.2241
9	.1848	.2241	.2587	.2012	.2353	.2218	.1848
10	.2561	.2218	.2218	.1848	.1097	.2195	.1463
11	.2402	.2218	.2218		.1478	.2195	.128
12	.2561	.2195	.1848	.2172	.1829	.0377	.1848
13	.2218	.1791	.1848	.181	.1478	.0377	.2012
14	.1867	.1791	.1478	.1402	.1478	.1433	.2195
15	.2195	.1753	.2033	.1844	.1463	.1791	.2033
16	.1848	.1772	.1848	.1595	.1294		.2195
17	.1829	.181	.2218	.1267	.1463		.2033
18	.1463	.2561	.1848	.1267	.2218	.1052	.1867
19	.1463	.2587	.1848	.1433	.1867	.2149	.2195
20	.1109	.2587	.2218	.1448	.1848	.2172	.2402
21	.1494	.2614	.2012	.1448	.1463	.2195	.2195
22	.1848	.2614	.1829	.1509	.1109	.2218	.2561
23	.2218	.2641	.1848	.2452	.1478	.2241	.2743
24	.1494	.112	.2641	.2218	.2054	.1478	.2263
Max	.2561	.2641	.2641	.2452	.2353	.2614	.2743
Min	.1109	.112	.1478	.1267	.1097	.0377	.128
Avg	.1756	.2026	.2233	.1799	.1631	.1923	.2134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 205 / 11KV BAGNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2195	.1886	.2012	.2012	.1829	.2641
2	.1829	.1848	.1886	.2012	.2012	.1829	.2641
3	.181	.1848	.1886	.2033	.181	.1848	.2641
4	.1629	.1829	.1886	.2012	.7421	.2218	.2641
5	.2033	.2195	.1886	.2402	.2172	.2195	.2641
6	.2772	.2587	.2263	.2743	.2772	.2561	.3018
7	.3696	.3475	.3018	.3292	.3511	.3511	.3584
8	.3475	.3511	.2987	.3326	.3292	.3547	.3734
9	.2587	.2587	.3142	.2743	.2957	.3292	.3326
10	.2378	.2353	.3142	.2896	.2987	.3077	.2926
11	.2402	.2658	.3142		.2957	.2865	.2957
12	.2561	.2507	.3511	.2926	.2614	.2865	.2378
13	.2587	.2507	.3292	.2743	.2957	.2686	.2743
14		.2353	.2587	.2378	.2957	.2561	.2353
15	.2218	.2195	.2957	.2534	.2561	.2378	.2378
16	.2195	.2481	.2926	.2561	.2957		.2957
17	.2561	.2481	.3658	.2957	.3361	.2561	.3142
18	.3142	.3189	.3292	.3326		.2926	.3475
19	.3696	.4755	.4435	.4251	.4024	.4108	.4066
20	.439	.4481	.4251	.4668	.4066	.4715	.4207
21	.4066	.4108	.4066	.4207	.439	.4527	.4066
22	.3292	.3584	.3475	.2587	.3696	.3961	.3475
23	.2561	.2641	.2402	.2587	.2561	.3018	.2772
24	.2033	.2218	.1886	.2033	.2218	.2218	.2641
Max	.439	.4755	.4435	.4668	.7421	.4715	.4207
Min	.1629	.1829	.1886	.2012	.181	.1829	.2353
Avg	.2684	.2774	.2911	.2836	.3142	.2926	.3058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 201 / 11 Kv Ashta Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1132	1.2071	.9259	.6952	.1132	.1463
2	.1867	.0943	1.226	.9297	.6613	.0943	.1267
3	.2054	.0943	1.2696	.8688	.8309	.0943	.1267
4	.2427	.1132	1.307	.8993	.7969	.0754	.128
5	.2241	.1494	1.4146	.9568	.7291	.112	.1448
6	.2054	.1867	1.1728	1.0648	.8478	.1494	.1698
7	.2054	.1848	1.2955	1.2346	1.1869	.2054	.2263
8	.2054	.1829	1.4937	1.448	1.3226	.1867	.2263
9	.2054	.1867	1.4022	1.4022	1.4074	.1663	.1886
10	.2054	.1646	.1629	.1494	.1698	.1463	.1663
11	1.8056	.1254	.1448		1.4937		
12	1.7528	.1254	.1448		1.6204		
13	1.713	.1254	.1254		1.5895		
14	1.6821	.1254	.1267		1.5278		
15	1.5895	.1267	.1086		1.5699		
16	1.2498	.1294	.1086		1.5851		
17	1.4148	.1307	.1612		1.5278		
18	1.326	.168	.1612		1.4632		
19	.181	.2241	.1848		.1848	.2507	
20	.168	.1867	.2054		.1698	.2172	
21	.1494	.1867	.168		.1509	.1646	
22	.132	.1307	.132		.132	.1646	
23	.1132	.1132	.1132		.0943	.1478	
24	.2241	.1132	.9877	.8951	.7291	.0943	.1478
Max	1.8056	.2241	1.4937	1.448	1.6204	.2507	.2263
Min	.1132	.0943	.1086	.1494	.0943	.0754	.1267
Avg	.6489	.1450	.6177	.9795	.9369	.1489	.1634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 202 / 11KV PATOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5218	.5864	.064	.0949	.1107	.7362	.8002
2	.6167	.571	.064	.0791	.1107	.7042	.8162
3	.5693	.5247	.08	.0633	.1265	.6722	.8322
4	.7748	.571	.08	.0791	.1423	.6562	.8482
5	.9172	.6019	.112	.1107	.1107	.7682	.8642
6	1.0753	.6944	.1562	.1423		.9442	.9014
7	1.1544	.8025	.1718	.1581	.1265	1.2483	1.1702
8	1.2651	.9877	.1875	.1898	.1423	1.2003	1.3441
9	1.0911	1.1574	.1406	.1581	.1265	1.2323	1.2018
10	.8381	.1389	.1406	.1107	.1265	.096	.1107
11	.0457	1.5684	1.3279		.112		
12	.0463	1.6164	1.7078		.096		
13	.0463	1.7124	1.866		.064		
14	.0617	1.7124	1.7394		.064		
15	.0926	1.6964	1.7711		.064		
16	.0926	1.6804	1.6762		.08	.144	
17	.0926	1.6644	1.5497		.096	.096	
18	.0772	1.4723	1.4548		.096	.112	
19	.1235	.128	.1265		.128	.128	
20	.1543	.128	.1581		.144	.128	
21	.1235	.144	.1265		.112	.128	
22	.0926	.112	.1107		.096	.128	
23	.0772	.08	.0791		.08	.112	
24	.4586	.5556	.0625	.0791	.1423	.6882	.8002
Max	1.2651	1.7124	1.866	.1898	.144	1.2483	1.3441
Min	.0457	.08	.0625	.0633	.064	.096	.1107
Avg	.4337	.8711	.6230	.1150	.1086	.5222	.8809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 203 / 11 KV ASHTA GAOTHAN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7619	.4607	.4252	.4031	.815	.4733	.5784
2	.7265	.4252	.4252	.3856	.7619	.4557	.5609
3	.7796	.4252	.4075	.3856	.7973	.4557	.5609
4	.8328	.4961	.3898	.4207	.7619	.4207	.5258
5	.7442	.5493	.4784	.5083	.815	.5083	.5258
6	.815	.6556	.6733	.5784	.8682	.5959	.631
7	.8682	.7619	.7973	.6836	.9036	.8063	.7888
8	.9214	.9036	.9036	.8413	.9214	.7712	.8939
9	.4784	.8328	.8682	.8063	.8505	.8238	.8238
10	.6024	.8859	.8859	.9036	.7619	.7186	.8505
11	.8682	.8505	.8505		.929		
12	.8682	.815	.7888		.7888		
13	.815	.7619	.7362		.6661		
14	.7087	.7442	.7888		.6836	.6661	
15	.6379	.7265	.8063		.7186	.631	
16	.7087	.7442	.8238		.7537	.5959	
17	.7796	.7973	.7888		.7888	.6485	
18	.8328	.7619	.8063		.7888	.7537	
19	.9036	.9922	.8413		.8939	.9816	
20	1.0099	1.0277	.964		.9991	.929	
21	.7796	.9568	.7362		.8589	.7888	
22	.6556	.7087	.5959		.6485	.6135	
23	.5138	.5847	.4557		.5083	.6135	
24	.815	.4784	.4252	.4207	.7265	.4908	.5784
Max	1.0099	1.0277	.964	.9036	.9991	.9816	.8939
Min	.4784	.4252	.3898	.3856	.5083	.4207	.5258
Avg	.7678	.7228	.6943	.5761	.7921	.6544	.6653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 204 / 11KV BAWACHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1509	.1294	.1509	.2126	.1509	.2241
2	.2195	.132	.1294	.132	.2126	.132	.2054
3	.1829	.132	.1463	.1132	.2303	.1132	.1848
4	.1829	.1867	.1463	.168	.2303	.1307	.1848
5	.2378	.2241	.1478	.2427	.2658	.1867	.168
6	.2561	.3174	.3142	.3361	.2835	.2427	.2987
7	.2561	.3142	.3292	.3326	.3189	.3511	.4294
8	.3475	.3292	.3439	.3475	.3366	.2686	.3475
9	.2378	.2561	.2507	.2561	.2835	.2279	.2561
10	.1829	.181	.181	.2126	.2303	.1928	.2507
11	.1357	.128	.1696		.1612		
12	.12	.1463	.1372		.1595		
13	.1387	.128	.1492		.1595		
14	.1227	.128	.1619		.1753		
15	.1052	.128	.1619		.1052		
16	.124	.1463	.16		.1214	.112	
17	.1417	.1646	.1715		.1417	.128	
18	.1612	.1829	.1715		.1629	.1715	
19	.2012	.2743	.2218		.2012	.3258	
20	.2801	.2743	.2987		.2587	.2865	
21	.2241	.2195	.2241		.1848	.2743	
22		.1478	.1698		.168	.2587	
23	.132	.1294	.132		.1307	.2402	
24	.2378	.132	.1334	.132	.2126	.132	.2241
Max	.3475	.3292	.3439	.3475	.3366	.3511	.4294
Min	.1052	.128	.1294	.1132	.1052	.112	.168
Avg	.1934	.1897	.1909	.2203	.2061	.2066	.2521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 205 / 11 KV BAWACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1132	.6554	.6554	.4807	.1132	.1494
2	.168	.0943	.6706	.6401	.547	.0943	.1494
3	.168	.0943	.6706	.5944	.5636	.0943	.1294
4	.1494	.1307	.6944	.6019	.5967	.1132	.1478
5		.1494	.7316	.6481	.7127	.1307	.1663
6	.2054	.168	.7468	.7099	.6133	.168	.1867
7	.2054	.168	.7827	.8688	.8453	.2054	.2054
8	.2054	.168	.9633	.9783	.9614	.1829	.1848
9	.2054	.1478	1.0385	.9602	1.2597	.1448	.1663
10	.2241	.1463	.1448	.1478	.2033	.1267	.1417
11	1.3108	.1494	.1448		1.0669		
12	1.387	.1307	.1448		1.2346		
13	1.3426	.1494	.1448		1.25		
14	1.2963	.1307	.1463		1.2037		
15	1.2955	.112	.1646		1.1279		
16	1.2346	.1307	.1463		1.1431	.9602	
17	1.2963	.1307	.1463		1.1265	1.1736	
18	1.1584	.1494	.1463		1.0648	1.1736	
19	.181	.1867	.1848		.1646	.2054	
20	.1848	.1867	.2033		.1867	.1848	
21	.1663	.1867	.168		.168	.1848	
22	.1307	.1494	.1494		.1509	.1663	
23	.1132	.1307	.132		.132	.1663	
24	.168	.1132	.6554	.6249	.431	.1132	.1494
Max	1.387	.1867	1.0385	.9783	1.2597	1.1736	.2054
Min	.1132	.0943	.132	.1478	.132	.0943	.1294
Avg	.5637	.1424	.4073	.6754	.7181	.3001	.1615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 206 / 11KV Ashta Pump House

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.4572	.4525	.4706	.7059	.4706	.5792
2	.6584	.439	.4706	.4344	.6697	.4706	.5792
3	.6584	.439	.4706	.4163	.6878	.4344	.5973
4	.7499	.4572	.4706	.4344	.7059	.4163	.6036
5	.6767	.4755	.4525	.4887	.6878	.4706	.5853
6	.7499	.5304	.6697	.543	.7783	.6878	.5973
7	.7865	.6401	.724	.6697	.8145	.8507	.7783
8	.8413	.7682	.8145	.7783	.8688	.7602	.8326
9	.7316	.8413	.7602	.8145	.8326	.724	.8688
10	.695	.6219	.7783	.6335	.7421	.6878	.724
11	.5853	.6036	.7682		.6335		
12	.6401	.4207	.7316		.7059		
13	.6036	.4207	.6036		.5792		
14	.5853	.4572	.6219		.5611		
15	.5487	.5121	.6401		.543		
16	.6036	.5487	.6584		.5973		
17	.6584	.6036	.6584		.6154		
18	.695	.6584	.6401		.6878		
19	.7499	.8962	.7682		.7964	.9955	
20	.8596	.8596	.8507		.905	.905	
21	.7499	.7865	.7421			.8507	
22	.6219	.7316	.6335		.6697	.724	
23	.4938	.6036	.5068		.543	.6335	
24	.7499	.4755	.4938	.4706	.7602	.4887	.6036
Max	.8596	.8962	.8507	.8145	.905	.9955	.8688
Min	.4938	.4207	.4525	.4163	.543	.4163	.5792
Avg	.6836	.5937	.6409	.5595	.6996	.6607	.6681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 201 / 11KV KOREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1848	.2241	.2241	.2241	.2241	.2054
2	.1867	.1848	.2241	.1848	.2241	.1867	.1886
3	.1867	.2241	.2263	.1848	.2241	.1867	.1886
4	.2075	.2641	.2587	.2614	.2241	.2263	.2241
5	.2614	.3772	.3361	.3361	.2241	.3018	.2957
6	.4715	.4294	.4668	.462	.4108	.415	.4668
7	.5415	.5601	.5914	.6468	.5601	.5415	.5544
8	.4938	.5175	.5359	.5729	.6099	.5359	.5487
9	.4298	.4477	.4835	.5373	.5487	.5068	.4784
10	.333	.3467	.3814	.443	.4525	.3761	.373
11	.3429	.39	.4115	.4207	.3988	.3052	.3521
12	.3561	.3601	.3467	.3856	.3601		.3353
13	.3429	.3391	.3294	.3721	.3429		.2254
14	.3155	.3155	.3121	.3258	.298		.2103
15	.3086	.3045	.3121	.3582	.3155	.2572	.2774
16	.3222	.3561	.3121	.3544	.3258	.2601	.2883
17	.3429	.3772	.407	.3988	.3506	.2774	.3353
18	.3601	.4161	.4508	.3721	.3681	.3772	.3721
19	.543	.5611	.6219	.6283	.5121	.5853	.463
20	.6219	.6401	.6036	.6468	.5544	.6036	.5544
21	.5121	.5914	.5788	.5975	.5228	.499	.5175
22	.4251	.4805	.4668	.5041	.4108	.4066	.3881
23	.3326	.2957	.2987	.4108	.2987	.2427	.2402
24	.2054	.1715	.2641	.2427	.2801	.2241	.2218
Max	.6219	.6401	.6219	.6468	.6099	.6036	.5544
Min	.1867	.1715	.2241	.1848	.2241	.1867	.1886
Avg	.3597	.3806	.3935	.4113	.3767	.3590	.3460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 202 / 11KV Bhadurwadi AG
(Koregaon) Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7773	.8025	.1017	.0838	.081	.7926	.7407
2	.7811	.823	.1029	.0848	.081	.7926	.7253
3	.7716	.823	.1052	.0857	.0791	.8128	.7011
4	.7926	.9031	.1052	.0867	.0772	.8128	.7407
5	.8333	.9783	.1075	.1052	.0762	.8429	.7621
6	.8642	1.0105	.1075	.124	.081	.8768	.7773
7	.9095	1.0402	.1417	.1433	.104	.9362	.9065
8	1.1294	1.2193	.1357	.1612	.156	1.0002	1.0402
9	1.1439	1.4043	.1341	.1578	.1772	1.1294	.9682
10	.1187	.2294	.1526	.1402	.1387	.156	.088
11	.1134	1.866	1.945	1.6248	.1543	.1372	.1107
12	.1296	1.9608	1.9292	1.6049	.1457	.112	.0937
13	.1147	2.0153	1.9134	1.5741	.112	.096	.0949
14	.1187	2.0005	1.9608	1.2803	.0892	.088	.0914
15	.1094	1.8976	1.8501	1.4506	.0903	.0926	.0714
16	.1107	1.8278	1.7497	1.3717	.1027	.0949	.1107
17	.128	1.7711	1.6156	1.3108	.112	.1107	.0629
18	.1296	1.6804	1.4937	1.2041	.0983	.1235	.096
19	.1372	.1214	.1578	.1227	.1029	.1387	.1017
20	.1417	.1227	.1595	.1402	.1254	.1214	.1029
21	.1052	.1214	.1254	.1227	.1254	.12	.1017
22	.1029	.1187	.1017	.1214	.1063	.0983	.1147
23	.104	.0983	.1017	.1006	.1052	.08	.0743
24	.787	.8025	.0995	.0838	.0829	.7621	.7499
Max	1.1439	2.0153	1.9608	1.6248	.1772	1.1294	1.0402
Min	.1029	.0983	.0995	.0838	.0762	.08	.0629
Avg	.4356	1.0683	.6832	.5536	.1085	.4303	.3928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 203 / 11KV Koregaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0301	.0293	.6895	.7099	.639	.0274	.0248
2	.0309	.0297	.6923	.7011	.639	.0282	.0267
3	.0305	.0297	.7011	.7316	.6161	.0282	.0286
4	.0312	.0293	.7407	.7282	.6602	.0305	.0324
5	.0324	.0434	.7716	.7827	.7188	.0457	.0347
6	.0514	.0434	.8592	.8383	.7621	.0469	.0343
7	.0617	.0587	1.034	.8951	.9414	.0678	.0463
8	.0617	.0469	1.1431	.9568	1.1288	.0434	.0594
9	.0429	.0349	1.1279	.9297	1.406	.0457	.036
10	.044	.0383	.0286	.0354		.0251	.0246
11	1.8519	.0309	.0221	.032	1.656	1.7394	1.5586
12	1.9216	.0202	.0229	.0286	1.6716	1.7966	1.6049
13	1.9685	.0309	.0314	.0337	1.656	1.7654	1.7869
14	1.9845	.0354	.0326	.0332	1.656	1.7185	1.7869
15	1.8027	.0229	.032	.0343	1.656	1.8404	1.692
16	1.7593	.0198	.032	.036	1.656	1.7497	1.5935
17	1.5242	.0267	.0332	.0337	1.5623	1.6288	1.2643
18	1.4937	.0324	.0291	.0354	1.5181	1.4685	1.2811
19	.0452	.0417	.0434	.0452	.0452	.0394	.0434
20	.0452	.0429	.044	.0406	.0446	.0429	.0457
21	.0309	.0423	.0434	.0434	.0417	.0383	.0423
22	.0312	.0366	.0389	.0412	.0271	.036	.0349
23	.0305	.0217	.0248	.0251	.0267	.021	.0217
24	.0293	.0293	.7133	.6944	.6773	.0267	.0229
Max	1.9845	.0587	1.1431	.9568	1.6716	1.8404	1.7869
Min	.0293	.0198	.0221	.0251	.0267	.021	.0217
Avg	.6223	.0341	.3721	.3527	.9307	.5959	.5470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 201 / 11KV MARDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.1334
Max	.1334
Min	.1334
Avg	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 202 / 11KV KARANDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.583
Max	.583
Min	.583
Avg	.583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 204 / 11 KV FALKEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.3487
Max	.3487
Min	.3487
Avg	.3487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 401 / 33 KV MARDWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.7442
Max	.7442
Min	.7442
Avg	.7442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 402 / ANKALKHOP

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.6379
Max	.6379
Min	.6379
Avg	.6379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 403 / 33 KV ASHTA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.8604
Max	1.8604
Min	1.8604
Avg	1.8604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 404 / 33KV KASBE DIGRAJ
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	2.0199
Max	2.0199
Min	2.0199
Avg	2.0199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 405 / 33 KV NAGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.1694
Max	1.1694
Min	1.1694
Avg	1.1694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 406 / 33 KV KOREGAON

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-FEB-18
HR	Load (MW)
24	.8505
Max	.8505
Min	.8505
Avg	.8505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 407 / 33 KV KASTURI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	3.8272
Max	3.8272
Min	3.8272
Avg	3.8272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 201 / 11 KV ISLAMPUR-I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9511	.924	.9335	.9145	.9511	.961
2	.8871	.924	.924	.9335	.924	.9145	.9335
3	.8871	.924	.9335	.9335	.8871	.924	.9335
4	.8962	.9145	.8962	.9335	.8779	.924	.961
5	.9335	.9145	.924	.9709	.9511	.9145	1.0456
6	1.1827	1.134	1.2071	1.0829	1.2071	1.2197	1.307
7	1.6461	1.6095	1.5729	1.4937	1.5524	1.5154	1.5684
8	1.8111	1.848	1.6827	1.7924	1.885	1.8111	1.9589
9	1.6057	1.6263	1.5893	1.643	1.7002	1.6804	1.5893
10	1.9022	1.848	1.9022	1.8473	1.8642	1.7741	1.8642
11	1.448	1.5203	1.4998	1.4998	1.3969	1.2803	1.4998
12	1.4118	1.3756	1.3756	1.3756	1.3643	1.2437	1.379
13	1.3394	1.267	1.3032	1.2489	1.267	1.0974	1.3394
14	1.2986	1.267	1.2803	1.2536	1.267		1.2308
15	1.3169	1.3169	1.262	1.2308	1.2308		1.1946
16	1.2803	1.3169	1.2489	1.1946	1.2308		1.2178
17	1.39	1.3169	1.267	1.3032	1.3756	1.5154	1.3394
18	1.4784	1.5154	1.4118	1.4632	1.4266	1.4784	1.5729
19	2.1068	2.1068	2.1068	2.0119	2.0485	2.0485	2.1068
20	1.9022	1.9589	1.885	1.922	1.9022	1.9589	1.885
21	1.6651	1.6827	1.7002	1.6632	1.7741	1.7002	1.6827
22	1.5565	1.4632	1.531	1.5729	1.5154	1.5364	1.4784
23	1.2308	1.2071	1.2696	1.1706	1.267	1.2071	1.1706
24	.9511	.9877	.961	1.0082	.9511	.9412	.9979
Max	2.1068	2.1068	2.1068	2.0119	2.0485	2.0485	2.1068
Min	.8871	.9145	.8962	.9335	.8779	.9145	.9335
Avg	1.3768	1.3748	1.3608	1.3534	1.3659	1.3636	1.3841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 203 / 11 KV LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.5121	.7522	.8383	.3506	.3429
2	.7682	.5975	.7522	.8383	.3856	.3429
3	.7762	.679	.7442	.8383	.3898	.3467
4	.7602	.7922	.788	.8383	.439	.3467
5	.788	.8676	.8505	.8383	.439	.3544
6	.8238	.8676	.8954	.8383	.4344	.3544
7	.8688	.8962	.8954	.9054	.695	.3224
8	.9145	.8871	.8596	.9431	.9979	.3224
9	.9808	.9808	.9431	.9054	1.0269	.068
10	.9997	.9808	.9808	.9808	1.0082	.679
11	1.0185	.9808	1.423	.9431	.9709	.8676
12	.9808	.9808	1.4045	.9431	.9709	.8676
13	.9242	.9808	1.3676	.9054	.9709	1.2197
14	.9808	.9808	1.3676	.9242	.9709	1.2936
15	.9808	.9808	1.3676	.9431	.9709	1.2936
16	.3395	.1646	.1749	.2263	.4607	.1097
24	.5716					
Max	1.0185	.9808	1.423	.9808	1.0269	1.2936
Min	.3395	.1646	.1749	.2263	.3506	.068
Avg	.8349	.8206	.9729	.8531	.7176	.5707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 204 / 11 KV ISLAMPUR-II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1109	.0924	.1307	.1109	.1097	.1086
2	.0924	.112	.0934	.1307	.1097	.1109	.1086
3	.0924	.112	.0934	.1307	.1097	.112	.1075
4	.0934	.1109	.0934	.1307	.1097	.112	.1075
5	.112	.112	.112	.1307	.1463	.1109	.1086
6	.1463	.1494	.1463	.1698	.1848	.1848	.1448
7	.2195	.2241	.181	.2641	.2218	.1848	.1829
8	.2218	.2614	.2195	.2987	.2587	.2561	.2561
9	.1494	.1848	.1478	.2195	.2012	.2054	.2218
10	.1097	.1448	.1509	.1448	.1448	.1463	.1612
11	.0886	.124	.1086	.1448	.1063	.124	.1448
12	.0857	.1227	.1402	.1029	.104	.1227	.104
13	.0701	.1052	.1063	.124	.0701	.0876	.104
14	.0549	.0886	.1063	.1075	.0716		.1052
15	.0724	.1052	.1075	.1075	.0895		.0867
16	.0914	.0876	.1052	.1063	.0732		.0876
17	.1097	.0716	.1254	.1433	.1109	.1402	.1402
18	.1097	.1086	.1433	.1075	.1109	.1402	.1433
19	.1848	.181	.2218	.2561	.1848	.2561	.181
20	.1848	.181	.2587	.2195	.2218	.2195	.2195
21	.1867	.181	.2614	.2195	.2218	.2195	.1829
22	.1867	.1463	.2427	.1848	.1848	.2218	.1829
23	.112	.1097	.1867	.1478	.1463	.1478	.1478
24	.0914	.1109	.0924	.1494	.1109	.1097	.1097
Max	.2218	.2614	.2614	.2987	.2587	.2561	.2561
Min	.0549	.0716	.0924	.1029	.0701	.0876	.0867
Avg	.1232	.1352	.1474	.1613	.1419	.1582	.1436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 205 / 11 KV ISLAMPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0892	.1029	.0743	.0189	.0183	.0187
2	.0183	.0892	.104	.0743	.0189	.0183	.0173
3	.0183	.0903	.104	.0743	.0187	.0185	.0189
4	.0181	.0903	.104	.0743	.0187	.0185	.0189
5	.0181	.1189	.104	.0903	.0187	.0185	.0189
6	.0366	.1524	.1715	.1219	.0373	.0185	.0189
7	.037	.216	.2058	.1898	.0373	.0183	.0373
8	.0366	.25	.208	.2401	.0187	.0362	.0373
9	.0191	.2846	.25	.2469	.0377	.0566	.0189
10	.0373	.0377	.0191	.0362	.0655	.0189	.0332
11	.3841	.0377	.0358	.0175	.4062	.4111	.3841
12	.3704	.0377	.0377	.0366	.4428	.4111	.3953
13	.3953	.0187	.0189	.0366	.4428	.3795	.3749
14	.3795	.0377	.0189	.0366	.3479		.3749
15	.3749	.0377	.0191	.0354	.3125		.3704
16	.3395	.0189	.0191	.0377	.427		.3704
17	.3086	.0189	.0191	.0189	.4458	.3795	.3688
18	.2743	.0187	.0377	.0377	.3814	.3479	.2743
19	.0358	.0373	.0377	.0187	.0347	.0187	.0351
20	.0366	.0373	.0189	.0187	.0347	.0377	.0358
21	.0377	.0185	.0377	.0187	.0358	.0189	.0358
22	.0377	.0183	.0189	.0189	.0358	.0189	.0362
23	.0189	.0183	.0189	.0189	.0181	.0187	.0183
24	.0181	.0892	.0701	.0743	.0189	.0183	.0187
Max	.3953	.2846	.25	.2469	.4458	.4111	.3953
Min	.0181	.0183	.0189	.0175	.0181	.0183	.0173
Avg	.1362	.0776	.0742	.0687	.1531	.1096	.1388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 206 / 11 KV Peth Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.823	1.1317	.9755	.1509	.1734	.1509
2	.1715	.823	1.1191	.9145	.1494	.1734	.1494
3	.1734	.8642	1.1191	.9145	.1494	.1734	.1494
4	.1715	.9259	1.1065	.9145	.1478	.1715	.1478
5	.1734	1.0494	1.1736	.9755	.1867	.1715	.1867
6	.2058	1.1873	1.3413	1.1728	.2241	.2058	.2241
7	.2401	1.7711	1.8861	1.6446	.2241	.2058	.2614
8	.2401	2.1765	2.4006	2.2672	.2263	.2347	.3018
9	.2058	2.1506	2.1247	1.9608	.2218	.2218	.2172
10	.2058	.2149	.1448	.1463	.2126	.2804	.2126
11	3.0445	.1772	.1463		2.8807	3.2007	3.1741
12	3.1741	.1772	.1991		3.2007	3.2007	3.2007
13	3.1367	.1402	.1433	.1372	3.2648	3.0407	3.1367
14	3.0727	.1753	.0732	.1433	3.2388		2.9447
15	2.9447	.1417	.1402	.1433	3.0727		2.9096
16	2.8166	.1791	.1372	.1402	3.0087		2.6871
17	2.5621	.2058	.1638	.1753	3.2236		2.7435
18	2.0729	.2058	.1852	.1753	1.989		2.2634
19	.2195	.208	.2218	.2149	.2058	.2149	.2058
20	.2218	.2103	.2218	.2149	.208	.2149	.208
21	.2241	.2058	.2241	.2241	.2058	.2241	.2058
22	.2241	.2058	.2054	.2263	.2058	.2241	.1715
23	.2241	.1715	.1867	.1886	.1734	.1886	.1372
24	.5544	.8535	1.0974	.9755	.1509	.1715	.1886
Max	3.1741	2.1765	2.4006	2.2672	3.2648	3.2007	3.2007
Min	.1715	.1402	.0732	.1372	.1478	.1715	.1372
Avg	1.1021	.6351	.7039	.6748	1.1217	.6680	1.0908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 401 / 33KV GANESH NAGAR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2883	1.5912	1.701	1.6078	1.6575	1.3306	1.5123
2	1.2323	1.5364	1.6632	1.5524	1.5432	1.2197	1.4003
3	1.262	1.5364	1.6078	1.5524	1.5432	1.2197	1.4003
4	1.386	1.5364	1.7187	1.5524	1.5432	1.3443	1.4003
5	1.701	2.1068	2.1068	1.9404	1.7718	1.6804	1.7741
6	2.1068	2.4143	2.4143	2.1948	2.1719	2.0725	2.2177
7	2.7435	3.1276	3.2156	3.0178	2.7435	2.5766	2.6337
8	2.7984	3.5665	3.2922	3.1824	2.572	2.7446	3.0178
9	2.1719	3.1276	3.0727	3.0864	2.1262	2.2965	2.5789
10	2.4577	2.2497	2.1399	2.5149	2.2497	2.3045	2.5149
11	2.8578	1.9547	1.9004	1.8861	2.5514	2.7692	3.2579
12	2.9721	1.9004	1.8461	1.829	2.6006	.6036	3.0864
13	2.8578	1.6832	1.8461	1.829	2.4691	.6036	3.0293
14	2.8006	1.5043	1.7918	1.829	2.5486		2.8578
15	1.6004	1.6289	1.6289	1.829	2.6749		2.8006
16	2.572	1.701	1.6289	1.829	2.572		2.915
17	2.572	1.701	1.7918	1.9433	2.6749	.823	3.0293
18	2.5514	1.1283	2.0416	2.0576	2.7778	.7682	3.0293
19	2.9864	2.9321	2.8235	2.915	2.8778	3.4374	3.0864
20	2.9081	2.7692	2.6886	2.5149	2.4714	3.0493	2.6863
21	2.6337	2.3891	2.524	2.4577	2.3594	2.6612	2.6292
22	2.0851	2.1948	2.3045	2.3434	2.1948	2.2731	2.4006
23	1.7558	1.701	1.8107	1.9433	1.6461	1.8296	2.1148
24	1.4415	1.7558	1.7558	1.701	1.829	1.4415	1.6244
Max	2.9864	3.5665	3.2922	3.1824	2.8778	3.4374	3.2579
Min	1.2323	1.1283	1.6078	1.5524	1.5432	.6036	1.4003
Avg	2.2393	2.0724	2.1381	2.1295	2.2571	1.8595	2.4582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9431	1.1694	1.0374	1.0562	.7545	.583
2	.9431	.9431	1.1694	1.0374	1.0562	.7545	.583
3	.9431	.9431	1.1694	1.0374	1.0562	.7545	.583
4	.9431	.9431	1.1317	1.0374	1.0562	.7545	.583
5	.9431	.9431	1.1128		1.0562	.7545	.5182
6	1.0185	1.0185	1.094	1.1694	1.0562	.679	.5868
7	1.0185	1.094	.9619	1.0974	1.1317	.7545	.6539
8	.9808	.8488	.8596	.9808	1.2449	.6036	.7537
9	1.5655	1.5089	1.3203	1.4523	1.3203	.6036	.9015
10	1.8484	1.6787	1.4712	1.905	1.9805	.5853	1.6032
11	1.8484	1.7164	1.4712	1.9239	1.9805	.378	1.6032
12	1.8484	1.7353	1.7164	1.8673	1.9805	.3963	1.6975
13	1.6409	1.4335	1.6032	1.8484	1.5655	.3961	1.4712
14	1.773	1.5844	1.5844	1.8107	1.773	.3961	1.6975
15	1.773	1.773	1.5466	1.7541	1.773	.4268	1.7353
16	1.773	1.6598	1.5844	1.6787	1.773	.4075	1.7918
17	1.7353	1.5844	1.5089	1.6598	1.6975	.4401	1.8484
18	1.358	1.5278	1.2449	1.6032	1.5089	.439	1.4632
19	1.358	1.1506	1.2071	1.358	1.2449	.4527	1.5089
20	1.0185	1.094	1.2071	1.0751	.9054	.439	1.3957
21	1.0185	.9054	1.1694	1.1317	.9054	.5624	1.2449
22	1.0185	1.0374	1.134	1.1506	1.0562	.5407	1.2449
23	1.094	1.094	1.0631	1.0374	1.0562	.57	1.2826
24	.9431	.9808	1.1694	1.094	1.0562	1.0562	.5895
Max	1.8484	1.773	1.7164	1.9239	1.9805	1.0562	1.8484
Min	.9431	.8488	.8596	.9808	.9054	.378	.5182
Avg	1.3062	1.2559	1.2779	1.3803	1.3455	.5791	1.1635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV SAKHRALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0914	.0943	.0914	.0914	.0943	.0914
2	.0732	.0914	.0943	.0914	.0886	.0914	.0914
3	.0732	.0914	.0943	.0914	.0914	.0914	.0914
4	.0732	.0914	.0943	.0914	.0914	.0914	.0914
5	.128	.128	.132	.1097	.1463	.128	.128
6	.1829	.1829	.1698	.1829	.2241	.1829	.2054
7	.2561	.2743	.3395	.2926	.2926	.2561	.2987
8	.2195		.2241	.2303	.2378	.2378	.2801
9	.1646	.1829	.1629		.2033	.2012	.2012
10	.1097	.1646	.1448	.181	.1463	.1097	.1829
11	.1097	.1433	.128	.1254	.1097	.0686	.1509
12	.1097	.1267	.1097	.1075	.1097	.0876	.1463
13	.1097	.0876	.1097	.1029	.1097	.0701	.1097
14	.0914	.1052	.1097	.104	.1097	.0686	.0924
15	.0914	.0905	.1097	.1052	.1097	.0701	.0924
16	.1097	.0876	.0914	.1029	.1097	.0701	.0914
17	.1097	.128	.1097	.1063	.128	.0914	.128
18	.1463	.128	.1463	.1433	.1829	.1086	.1463
19	.2378	.2012	.2743	.2402	.2378	.2378	.2561
20	.2378	.2195	.2195	.2241	.2378	.2561	.2561
21	.1829	.2012	.1949	.1886	.2195	.2033	.1886
22	.1646	.2012	.1463	.168	.1463	.1867	.1663
23	.1097		.1097	.112	.1097	.128	.0914
24	.0732	.0914	.0943	.0914	.0914	.0914	.0914
Max	.2561	.2743	.3395	.2926	.2926	.2561	.2987
Min	.0732	.0876	.0914	.0914	.0886	.0686	.0914
Avg	.1349	.1414	.1460	.1428	.1510	.1343	.1529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV BAHE AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5761	.0189	.0189	.0171	.6722	.5693	.6722
2	.5761	.0189	.0189	.0171	.6722	.5693	.6722
3	.5761	.0189	.0189	.0171	.6722	.5693	.6722
4	.5761	.0189	.0189	.0171	.6722	.5693	.6722
5	.6081	.0189	.0189	.0171	.6722	.5693	.7682
6	.7682	.0189	.0189	.0171	.6722	.6642	.7682
7	.8002	.0189	.0189	.0171	.8745	.1898	.9393
8	.8962	.0189	.0189	.0171	.9122	.8539	1.0688
9	.8962	.0189	.0189	.0171	.9717	.8539	1.0202
10	.0189	.0189	.0179	.0189	.0189	.0189	.0171
11	.0189	1.2631	1.6057	1.2483	.0189	.0189	.0171
12	.0189	1.3443	1.6057	1.4575	.0189	.0189	.0171
13	.0189	1.3923	1.6712	1.4575	.0189	.0189	.0171
14	.0189	1.4403	1.6057	1.4575	.0189	.0189	.0171
15	.0189	1.4403	1.6057	1.3443	.0189	.0189	.0171
16	.0189	1.3603	1.4723	1.2809	.0189	.0189	.0171
17	.0189	1.4575	1.4403	1.2483	.0189	.0189	.0171
18	.0189	1.3443	1.2803	1.1523	.0189	.0189	.0171
19	.0189	.0189	.0171	.0189	.0189	.0189	.0171
20	.0189	.0189	.0171	.0189	.0189	.0189	.0171
21	.0189	.0189	.0171	.0189	.0189	.0189	.0171
22	.0189	.0189	.0171	.0189	.0189	.0189	.0171
23	.0189	.0189	.0171	.0189	.0189	.0189	.0171
24	.5761	.0189	.0189	.0171	.5624	.5693	.6722
Max	.8962	1.4575	1.6712	1.4575	.9717	.8539	1.0688
Min	.0189	.0189	.0171	.0171	.0189	.0189	.0171
Avg	.2964	.4727	.5241	.4555	.3174	.2601	.3402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV DUDH SANGH FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.679	.547	.415	.3018	.4715	.3395
2	.4527	.679	.547	.415	.3018	.4715	.3395
3	.4527	.679	.6602	.415	.3018	.4715	.3395
4	.4527	.679	.547	.415	.3018	.4715	.3395
5	.3584	.679	.3395		.3018	.4715	.3395
6	.3018	.679	.3395	.2829	.3018	.4715	.3395
7	.2641	.5658	.3018	.3018	.2829	.3961	.3018
8	.3395	.5281	.3395	.3018	.3395	.3772	.3395
9	.3584	.3961	.4715		.3961	.3961	.3772
10	.6979	.5847	.679	.4715	.811	.4527	.5281
11	.6979	.5658	.8676	.5658	.811	.5093	.6224
12	.6979	.5658	.7733	.6413	.8488	.5658	.6224
13	.6413	.5093	.6979	.6036	.8488	.5658	.5093
14	.5093	.547	.7167	.5658	.6979	.3961	.6979
15	.5093	.5658	.7545	.5281	.6979	.3961	.6979
16	.5658	.5847	.6979	.5093	.6413	.4338	.679
17	.5658	.679	.6413	.4904	.6413	.4338	.6979
18	.7922	.6224	.6413	.4715	.6413	.415	.679
19	.7922	.6979	.6979	.4527	.6413	.415	.6413
20	.7922	.7167	1.0562	.3772	.6979	.415	.5658
21	.679	.7167	.7167	.3772	.6979	.415	.5281
22	.679	.6224	.7167	.3961	.6979	.415	.5281
23	.679	.6036	.6413	.3772	.6979	.3772	.4715
24	.5847	.679	.547	.4715	.3395	.6224	.3018
Max	.7922	.7167	1.0562	.6413	.8488	.6224	.6979
Min	.2641	.3961	.3018	.2829	.2829	.3772	.3018
Avg	.5593	.6177	.6224	.4475	.5517	.4511	.4928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV NAGARPALIKA PWW
FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3584	.3961	.3584	.3772	.3395
2	.3772	.3772	.3584	.3961	.3584	.3772	.3395
3	.3772	.3772	.3584	.3961	.3584	.3772	.3395
4	.3772	.3772	.3584	.3772	.3584	.3772	.3395
5	.3772	.3772	.3772	.3395	.3584	.3772	.3395
6	.415	.3772	.415	.3772	.3584	.3772	.3395
7	.4527	.415	.4338	.3772	.3772	.3772	.3961
8	.415	.415	.4338	.415	.415	.415	.4338
9	.4904	.415	.4338	.3961	.415	.1829	.4338
10	.4527		.4338	.4715	.4527	.4715	.4338
11	.4527	.4527	.4715	.4904		.5281	.4527
12	.4527	.4527	.4527	.4527	.415	.5093	.415
13	.4527	.415	.4715	.4338	.415	.4904	.415
14	.4527	.415	.4527	.4338	.415	.4715	.4527
15	.4527	.415	.4338	.415	.415	.4715	.4527
16	.4527	.415	.415	.4715	.415	.4715	.4338
17	.4527	.415	.415	.4527	.415	.4527	.415
18	.4527	.415	.415	.415	.415	.4338	.4024
19	.3772	.415	.2829	.2401	.2641	.415	.3018
20	.3395	.2372	.2641	.2401	.2641	.2241	.2641
21	.2641	.2372	.2641	.1715	.2263	.2429	.2641
22	.2641	.2835	.2641	.2058	.2263	.2429	.2641
23	.3772	.2926	.2829	.2401	.2641	.2429	.3018
24	.3772	.3772	.3584	.3772	.3395	.3772	.2804
Max	.4904	.4527	.4715	.4904	.4527	.5281	.4527
Min	.2641	.2372	.2641	.1715	.2263	.1829	.2641
Avg	.4055	.3803	.3835	.3742	.3609	.3868	.3688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV KAPUSKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0732	.0732	.0732	.0747	.0732	.0732
2	.0754	.0732	.0754	.0732	.0747	.0732	.0732
3	.0732	.0732	.0732	.0732	.0747	.0732	.0732
4	.0732	.0732	.0732	.0732	.0747	.0732	.0732
5	.0914	.1097	.0943	.1029	.1494	.1097	.1097
6	.2195	.1829	.1494	.1463	.1886	.1829	.1867
7	.2378	.2195	.2614	.2126	.2641	.2195	.2241
8	.2561	.2195	.2427	.2195	.2263	.2561	.2054
9	.1463	.1463	.1646	.1772	.168	.1829	
10	.0732	.128	.1463	.1075	.1097	.1463	.1463
11	.0732	.1075	.0914	.1063	.0732	.0514	.1097
12	.0732	.0701	.0914	.1227	.0732	.0526	.0732
13	.0732	.0686	.0914	.1052	.0732	.0526	.0732
14	.0732	.0514	.0914	.0867	.0732	.0526	.0914
15	.0732	.0701	.0914	.0686	.0732	.1063	.0914
16	.1097	.0876	.128	.0701	.0732	.1063	.0914
17	.1097	.1254	.128	.0886	.0732	.1075	.1829
18	.1463	.1646	.128	.1075	.1097	.0905	.1829
19	.1829	.1829	.2012	.2218	.2195	.2195	.2195
20	.1829	.2012	.2012	.1867	.2195	.2195	.2218
21	.1829	.1829	.1829	.1867	.1463	.2195	.2218
22	.1463	.128	.1463	.1698	.1097	.1494	.1829
23	.0732	.132	.0914	.0934	.0732	.1463	.0914
24	.0732	.0732	.0754	.0732	.0747	.0732	.0732
Max	.2561	.2195	.2614	.2218	.2641	.2561	.2241
Min	.0732	.0514	.0732	.0686	.0732	.0514	.0732
Avg	.1206	.1227	.1289	.1228	.1196	.1266	.1336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 207 / 11 KV SAKHRALE AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.3696	.3277	.2622	.0171	.0189	.0168
2	.0171	.3658	.3277	.2622	.0171	.0189	.0168
3	.0171	.362	.3277	.2622	.0171	.0189	.0168
4	.0171	.3582	.3506	.2622	.0171	.0189	.0168
5	.0171	.3544	.3658	.2622	.0171	.0189	.016
6	.0171	.3391	.3658		.0171	.0189	.0152
7	.0171	.3391	.3772	.4161	.0171	.0189	.0137
8	.0171	.4908	.4428	.4801	.0171	.0189	.0152
9	.0171	.5228	.4908	.4588	.0171	.0189	.0147
10	.0171	.0181	.0171	.0171	.0189	.0189	.0171
11	.8779	.0181	.0171	.0171	.7545	.7964	.6882
12	.8779	.0181		.0171	.8299	.8299	.6962
13	.8779	.0181	.0171	.0171	.7545	.8299	.6962
14	.8779	.0181	.0171	.0171	.7545	.7316	.6882
15	.8779	.0189	.0171	.0171	.7545	.7682	.6554
16	.8779	.0189	.0171	.0171	.7545	.6722	.6882
17	.7316	.0189	.0171	.0171	.679	.7095	.5898
18	.6584	.0175	.0171	.0171	.679	.6722	.4915
19	.0189	.0171	.0171	.0171	.0189	.0168	.0171
20	.0189	.0154	.0171	.0171	.0189	.0164	.0171
21	.0189	.0158	.0171	.0171	.0189	.0164	.0171
22	.0189	.0158	.0171	.0171	.0189	.0164	.0171
23	.0189	.0158	.0171	.0171	.0189	.0168	.0171
24		.4481	.3277	.2622	.0171	.0189	.0168
Max	.8779	.5228	.4908	.4801	.8299	.8299	.6962
Min	.0171	.0154	.0171	.0171	.0171	.0164	.0137
Avg	.3010	.1748	.1707	.1377	.2602	.2625	.2273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 209 / 11 KV Siddhanath LIS
feeder Feeder KV- 11 /
OUTGOING

PURELY LIS FEEDERS

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.032	.0503	.0497	.0164	.016	.0497
2	.064	.0503	.0497	.0164	.0492	.0497
3	.128	.0503	.0497	.0655	.0492	.0497
4	.128	.0503	.0497	.0655	.0492	.0497
5	.128	.3353	.3315	.1311	.0492	.0497
6	.3521	.3353	.3353	.1802	.0492	.0497
7	.3521	.3353	.3856	.1823	.0492	.0497
8	.3812	.3688	.3688	.176	.3315	.0497
9	.3812	.3353	.3647		.3647	.3688
10	.3647	.3521	.3605	.3647	.3647	.3605
11	.3647	.3688	.4096	.3647	.3647	.3647
12	.3647	.3688	.3768	.3647	.3647	.3647
13	.3647	.3688	.4096	.3647	.3647	.3812
14	.3647	.3688	.3768	.3647	.3647	.3768
15	.3647	.3688	.3768	.3647	.3647	.3768
16	.3647	.3688	.3768	.3277	.3647	.3768
Max	.3812	.3688	.4096	.3647	.3647	.3812
Min	.032	.0503	.0497	.0164	.016	.0497
Avg	.2812	.2798	.2920	.2233	.2225	.2105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 401 / 33 KV EXPRESS FEEDER
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7718	1.5844	1.9805	1.7147	1.3717	1.2449	1.1317
2	1.7718	1.5844	1.9805	1.7147	1.3717	1.2449	1.1317
3	1.7718	1.5844	1.9805	1.7147		1.2449	1.1317
4	1.7718	1.5844	1.9805	1.6004	1.3717	1.2071	1.1317
5	1.7718	1.5844	1.9805	1.4861	1.3717	1.2449	1.1317
6	1.7147	1.6975	1.7541	1.4861	1.3717	1.2449	1.0751
7	1.829	1.6975	1.9239	1.6004	1.3717	1.358	1.0751
8	1.7147	1.5844	1.7541	1.6575	1.3717	1.2449	1.0751
9	1.7718	1.9239	2.0936	1.7147	1.6575	1.358	1.3014
10	2.0936	1.8673	2.1719	1.7147	1.5844	1.2449	1.3717
11	2.0936	2.037	2.2862	1.7147	1.5844	1.358	1.5432
12	2.037	2.037	2.1719	1.7718	1.5844	1.4146	1.3717
13	2.037	2.1502		1.7718	1.5844	1.3014	1.3717
14	2.037	2.32	2.1719	1.829	1.8107	1.3014	1.3717
15	2.037	2.3765	2.4006	1.829	1.8107	1.3014	1.4289
16	2.037	2.5463	2.5149	1.9433	1.8107	.7356	1.7147
17	2.037	2.3765	2.1719	1.9433	1.8107	1.2449	1.4861
18	1.8107	2.32	2.1719	1.5432	1.9239	1.1883	1.3717
19	1.8107	1.9805	2.0576	1.4861	1.9239	1.1883	1.3717
20	1.6975	1.8673	1.829	1.5432	1.5844	1.0751	1.3717
21	1.6975	1.8673	1.6575	1.5432	1.5844	1.1317	1.3717
22	1.6975	1.8673	1.6004	1.5432	1.5844	1.1883	1.2574
23	1.6975	1.8673	1.6004	1.5432	1.5844	1.1883	1.2574
24	1.7718	1.6975	1.9239	1.7147	1.4861	1.4712	1.1317
Max	2.0936	2.5463	2.5149	1.9433	1.9239	1.4712	1.7147
Min	1.6975	1.5844	1.6004	1.4861	1.3717	.7356	1.0751
Avg	1.8534	1.9168	2.0069	1.6718	1.5874	1.2386	1.2908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 201 / 11 KV RHX & TAKARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.3018	.2715	.2452	.2534	.2829	.2715
2	.2686	.3018	.2715	.2452	.2507	.2829	.2686
3	.2865	.3018	.2686	.2452	.2507	.2829	.2715
4	.362	.3206	.4298	.2829	.3077	.3018	.3403
5	.5853	.3584	.5249	.3395	.4525	.3584	.4207
6	.6335	.6535	.6335	.5281	.5194	.5658	.5792
7	.7602	.8029	.7421	.7655	.7421	.7842	.7499
8	.788	.7499	.7164	.7499	.7682	.7095	.6984
9	.6154	.6516	.6516	.7059	.5973	.5175	.6516
10	.567	.5552	.5784	.591	.5316	.4525	.6268
11	.5552	.6154	.5548	.543	.4973	.4938	.567
12	.5493	.5731	.5316	.4887	.5487	.5068	.4801
13	.5083	.5249	.5201	.5014	.4854	.4207	.4557
14	.4557	.5068	.5201	.4525	.4733	.4344	.443
15	.463	.543	.5083	.4119	.4801	.394	.4382
16	.5087	.5304	.4607	.4525	.4527	.4207	.4334
17	.5487	.5249	.4748	.128	.5087	.5068	.4801
18	.5935	.567	.5765	.1867	.6344	.567	.5658
19	.9145	.8145	.8145	.9412	.8962	.7701	.8596
20	.8779	.7865	.823	.9134	.8413	.7783	.8131
21	.7682	.724	.7392	.7421	.7207	.695	.6838
22	.5853	.5792	.6283	.5611	.6161	.5792	.5601
23	.5544	.3258	.3547	.3224	.5041	.394	.415
24	.2896	.3361	.2865	.2801	.2715	.3018	.3077
Max	.9145	.8145	.823	.9412	.8962	.7842	.8596
Min	.2686	.3018	.2686	.128	.2507	.2829	.2686
Avg	.5546	.5395	.5367	.4843	.5252	.4917	.5159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 202 / 11 KV TAKARI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.2753	.3239	.3479	.0566	.0566	.056
2	.0566	.2753	.3605	.3479	.056	.0566	.0566
3	.0566	.2753	.3521	.3521	.0566	.0566	.0747
4	.056	.2881	.3521	.3887	.0566	.0754	.0754
5	.0747	.3041	.3887	.3887	.0747	.0754	.0754
6	.0924	.3521	.421	.4372	.0739	.0943	.0943
7	.112	.502	.4915	.5571	.1132	.0934	.112
8	.0943	.5624	.5182	.6882	.0934	.0934	.1132
9	.0934	.6167	.5571	.6154	.0739	.0934	.112
10	.0943	.0934	.0754	.0924	.0754	.0924	.1132
11	1.0159	.0924	.0754	.112	.8642	.9393	.9488
12	1.0202	.0934	.0754	.1109	.9995	.9762	.933
13	1.0202	.0934	.0566	.112	1.0242	1.0159	.9804
14	.9172	.0739	.0566	.0943	.9488	.9717	.9282
15	.8745	.0747	.0754	.0934	.9374	.9339	.9393
16	.8288	.112	.0754	.112	.9259	.9231	.9503
17	.8048	.1132	.0754		.8796	.8848	.9116
18	.7293	.0934	.0943		.7716	.8259	.8002
19	.0754	.0934	.1132	.112		.112	.0943
20	.0943	.0747	.0934	.0934	.1132	.1109	.0754
21	.0754	.0739	.0754	.0924	.0754	.0934	.0754
22	.0754	.0747	.0754	.0747	.0754	.0754	.0754
23	.0754	.056	.0566	.0554	.0566	.0747	.0754
24	.056	.0754	.2881	.3361	.056	.0566	.056
Max	1.0202	.6167	.5571	.6882	1.0242	1.0159	.9804
Min	.0554	.056	.0566	.0554	.056	.0566	.056
Avg	.3520	.1975	.2136	.2552	.3677	.3659	.3636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 203 / 11 KV RETHRE HARNAX AG SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.0362	.0554	.0503	.6722	.547	.6081
2	.5898	.0362	.0566	.0509	.6802	.547	.6154
3	.6133	.0366	.056	.0509	.7125	.5533	.6226
4	.6062	.0549	.056	.0514	.7042	.57	.663
5	.639	.0537	.0754	.052	.7116	.5801	.6554
6	.664	.0709	.056	.0543	.7842	.6539	.6802
7	.7537	.0876	.056	.0732	.9231	.7125	.8029
8	.9116	.0876	.0566	.0857	1.0322	.8223	.9069
9	.8684	.0686	.0747	.0739	.9878	.7811	.9667
10	.0594	.0914	.0714	.0747	.0663	.0747	.0469
11	.0335	1.3283	1.2803	1.3443	.0686	.0554	.0486
12	.0309	1.3603	1.3923		.0671	.056	.0655
13	.0655	1.4251	1.4403	1.4091	.0663	.0943	.0663
14	.0663	1.4419	1.4083	1.2955	.0663	.0747	.0663
15	.0663	1.3763	1.3123	1.3117	.0655	.0747	.0497
16	.0819	1.2643	1.2483	1.2125	.0648	.0739	.0492
17	.0762	1.1336	1.0494	1.1336	.0655	.0747	.0663
18	.0743	1.004	.9568	.9602	.0829	.0934	.0663
19	.0716	.0532	.0716	.0724	.0838	.0739	.0503
20	.0701	.0554	.0526	.0739	.0663	.0747	.0514
21	.0701	.056	.0514	.056	.0671	.0739	.0514
22	.0532	.037	.0509	.056	.0503	.0747	.0526
23	.0532	.037	.0503	.056	.0497	.056	.0526
24	.6283	.0358	.0373	.0497	.7392	.5571	.5921
Max	.9116	1.4419	1.4403	1.4091	1.0322	.8223	.9667
Min	.0309	.0358	.0373	.0497	.0497	.0554	.0469
Avg	.3221	.4680	.4590	.4195	.3699	.3062	.3290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 204 / 11KV Bhavaninagar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.5533	.4744	.5571	.5506	.5441
2	.5898	.6036	.583	.5898	.5761	.5668
3	.5898	.5967	.5761	.5898	.5761	.5801
4	.583	.5967	.5693	.5967	.5898	.5898
5	.5898	.5898	.5761	.5967	.583	.583
6	.5898	.5967	.583	.5967	.5761	.5735
7	.5898	.5967	.5898	.5967	.5898	.5601
8	.583	.583	.583	.5967	.583	.5668
9	.583	.5898	.5898	.5898	.5967	.5735
10	.5967	.583	.5693	.583	.6062	.5801
11	.6203	.5898	.6062	.5898	.5967	.5967
12	.5967	.6062	.6062	.583	.5967	.583
13	.5967	.5992	.6062	.583	.5967	.5898
14	.5967	.5898	.6062	.5898	.4428	.5243
15	.5898	.5992	.6062	.583	.5761	.5243
16	.5898	.583	.6062	.5898	.583	.5243
Max	.6203	.6062	.6062	.5967	.6062	.5967
Min	.4858	.5533	.4744	.5571	.4428	.5243
Avg	.5857	.5910	.5832	.5882	.5762	.5663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 201 / 11 KV BAHE GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0895	.1109	.0895	.0693	.1063	.0905
2	.1109	.0905	.1109	.0895	.0709	.1075	.0914
3	.1109	.0895	.1109	.0886	.0701	.1052	.0924
4	.1663	.0914	.1663	.0716	.2126	.1075	.1663
5	.2402	.2218	.2402	.2534	.2507	.2378	.2378
6	.2957	.3292	.3511	.3109	.3475	.3142	.2926
7	.2772	.3475	.3292	.3292	.3658	.3326	.3109
8	.2507	.2481	.3258	.2507	.2896	.2686	.2715
9	.1949	.208	.2254	.208	.2103	.156	.2328
10	.1492	.1457	.1526	.1578	.1296	.1341	.1543
11	.1638	.1372	.125	.1423	.1372	.1143	.1562
12	.144	.1311	.1423	.1423	.1235	.1219	.112
13	.144	.1311	.1311	.112	.112	.128	.1107
14	.1406	.1341	.1457	.1326	.1134	.1134	.0972
15	.1134	.144	.1311	.108	.0937	.1134	.1067
16	.1389	.112	.1219	.0937	.1134	.1067	.0972
17	.1718	.112	.125	.1372	.16	.144	.1581
18	.1423	.0972	.128	.1389	.1852	.1581	.2035
19	.2481	.2507	.2572	.2172	.2481	.2303	.2686
20		.2507	.2507	.2012	.2149	.2401	.2507
21	.2507	.2353	.2149	.2195	.1991	.2353	.2328
22	.181	.1848	.181	.1478	.1791	.181	.1463
23	.1075	.1097	.1075	.0914	.124	.1097	.128
24	.1017	.0895	.1052	.0895	.0693	.1052	.0905
Max	.2957	.3475	.3511	.3292	.3658	.3326	.3109
Min	.1017	.0895	.1052	.0716	.0693	.1052	.0905
Avg	.1719	.1659	.1787	.1593	.1704	.1655	.1708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 202 / 11 KV KHARATWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1235	.0937	.0914			
2		.1219	.0937	.0914			
3		.125	.0937	.0914			
4		.1235	.0937	.0937			
5		.1372	.125	.1094			
6		.1524	.1406	.112			
7		.2006	.1698	.125			
8		.1957	.216	.1372	.0175		
9		.25	.2134	.1656			
11	.4696				.381	.3567	.4161
12	.4696				.3963	.3963	.4321
13	.4641				.4218	.4012	.4321
14	.4428				.4475	.4218	.3841
15	.421				.4687	.427	.3437
16	.4161				.4801	.4481	.3479
17	.3521				.4218	.4111	.3086
18	.3125				.4012	.3549	.2846
24		.1219	.0892	.0903			
Max	.4696	.25	.216	.1656	.4801	.4481	.4321
Min	.3125	.1219	.0892	.0903	.0175	.3549	.2846
Avg	.4185	.1552	.1329	.1107	.3818	.4021	.3687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 203 / 11 KV HUBALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185	.0377	.0377	.0537	.5268	.4161	.3567
2	.3185	.0373	.0377	.0537	.5335	.4214	.3567
3	.3185	.037	.0377	.0543	.5468	.4268	
4	.3185		.0566	.0543	.5535	.4321	.381
5	.3185	.0377	.0754	.0732	.5693	.4572	.4321
6	.333	.0566	.0943	.0732	.6081	.4784	.463
7	.362	.0754	.0943	.0943	.7362	.5944	.547
8	.4144	.0754	.0739	.0739	.7522	.6481	.5801
9	.4548	.056	.0747	.0554	.7274	.6554	.5967
10	.056	.0554	.0554	1.1043	.037	.048	.0532
11	.0373	1.2289	1.4255	1.2643	.0366	.048	.0509
12	.0373	1.1883	1.3916	1.3443	.0332	.048	
13	.037	1.2483	1.4243	1.2963	.0343	.048	
14	.0373	1.2944	1.4243	1.2003	.0335	.048	.0305
15	.0377	1.2498	1.4083	1.1683	.0347	.048	.0263
16	.0347	1.186	1.2963	1.1683	.0362	.0474	.0316
17	.0354	1.1385	1.2803	1.0722	.0343	.048	.0434
18	.0549	1.1544	1.2643	.9762	.0343	.048	.052
19	.0739	.0754	.0503	.048	.0732	.0503	.0747
20	.0739	.0754	.0486	.0554	.0739	.0549	.0554
21	.0754	.0754	.0503	.0566	.0754	.0554	
22	.056	.0754	.0554	.0566	.0554	.037	.0366
23	.0554	.0566	.0537	.0566	.0377	.0366	.0358
24	.2921	.0566	.0566	.0537	.5135	.4214	.3374
Max	.4548	1.2944	1.4255	1.3443	.7522	.6554	.5967
Min	.0347	.037	.0377	.048	.0332	.0366	.0263
Avg	.1730	.4596	.4945	.4795	.2790	.2340	.2271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 201 / 11 KV MANCHHINDRANAT

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2477	.2587	.2667	.2667	.2614	.2614
2	.2477	.2477	.2452	.2667	.2667	.2641	.2427
3	.2477	.2477	.2477	.2667	.2667	.2641	.2427
4	.2858	.2452	.2667	.3048	.2641	.2801	.2987
5	.4382	.381	.4382	.362	.3239	.3584	.3547
6	.7545	.7811	.6287	.6602	.7356	.6224	.679
7	.8402	.8676	.8488	.9054	.8676	.7922	.9431
8	.8029	.811	.7356	.8215	.8131	.6838	.8215
9	.5914	.6535	.6348	.7023	.6535	.5228	.6535
10	.4207	.5487	.5121	.5359	.5121	.3696	.5121
11	.3761		.4887	.4607	.4477	.3292	.4805
12	.3506	.4075	.4733	.443	.3814	.3439	.4656
13	.3721	.3721	.4252	.333	.3582	.3403	.3582
14	.3544	.3403	.3681	.3582	.3506	.2926	.3403
15	.3582	.3224	.3761	.2715	.3506	.3109	.3403
16	.3641	.3641	.3189	.3403	.3601	.2926	.3898
17	.4031	.3761		.3898	.4252	.3734	.4119
18	.4961	.5194	.4908	.4681	.5493	.4251	.567
19	.7682	.7023	.8413	.7133	.8326	.7207	.7947
20	.7577	.7655	.8316	.7392	.7947	.7577	.7207
21	.7095	.7095	.7095	.6722	.6908	.7167	.6602
22	.7095	.5658	.5658	.547	.5175	.5788	.5093
23	.3361	.3547	.3734	.3584	.3292	.3361	.3174
24	.2667	.2667	.2772	.2858	.2829	.2801	.2829
Max	.8402	.8676	.8488	.9054	.8676	.7922	.9431
Min	.2477	.2452	.2452	.2667	.2641	.2614	.2427
Avg	.4791	.4825	.4938	.4780	.4850	.4382	.4853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 202 / 11KV KRISHNA LIS

PURELY LIS FEEDERS

YEDEMACHHINDR Feeder KV- 11 /
OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3005	.3658	.3749	.3858	.3858	.3005
2	.3437	.3658	.3749	.3906	.3704	.3749
3	.3437	.3549	.3593	.3704	.3658	.3749
4	.3593	.3549	.3593	.3704	.3549	.3749
5	.3593	.3353	.3749	.3658	.3506	.3658
6	.3506	.5468	.3749	.4843	.3506	.3658
7	.3593	.5693	.3749	.506	.5693	.3612
8	.3658	.5556	.3704	.5851	.5556	.4784
9	.3506	.5468	.3353	.5693	.5624	.5693
10	.3593	.5401	.3311	.5556	.5556	.5487
11	.3506	.5247	.3593	.5624	.5624	.5693
12	.3506	.3658	.3593	.5693	.5693	.5624
13	.3161	.3462	.3593	.5418	.5624	.5624
14	.0171	.2824	.0032	.5468	.5556	.5624
15	.4586	.3506	.216	.5624	.5624	.5624
16	.5487	.3374	.5487	.5624	.5624	.5556
Max	.5487	.5693	.5487	.5851	.5693	.5693
Min	.0171	.2824	.0032	.3658	.3506	.3005
Avg	.3459	.4214	.3422	.4955	.4872	.4681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 203 / 11KV Kilemachindragad Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.2715	.3001	.2715	.0381	3.2733	.0343
2	.0381	.2715	.3041	.2715	.0381	.0328	.0351
3	.0381	.2715	.3041	.2751	.0381	.0339	.0354
4	.0381	.2715	.3081	.2751	.0381	.0549	.0362
5	.0572	.3001	.3185	.2934	.0572	.0554	.037
6	.0762	.3668	.3521		.0762	.0739	.056
7	.0762	.4607	.4607	.4572	.0953	.0724	.0732
8	.0572	.5647	.5792	.6401	.0762	.0716	.0905
9	.0762	.587	.5647	.5944	.0762	.0497	.0543
10	.0572	.0572	.0572	.0572	.0953	.0655	.0503
11	.823	.0572	.0762	.0572	.7316	.8128	.6944
12	.8383	.0572	.0572	.0572	.8078	.7827	.7316
13	.7526	.0381	.0572	.0762	.8078	.7977	.7468
14	.7621	.0572	.0383	.0762	.7827	.8383	.7468
15	.6836	.0572	.0572	.0381	.7727	.8333	.7316
16	.6455	.0572	.0572	.0286	.7375	.7773	.7282
17	.6401	.0572	.0572	.0572	.6401	.7407	.6539
18	.5864	.0572	.0714	.0572	.6173	.6401	.6093
19	.0762	.0762	.0762	.0762	.0716	.0716	.0732
20	.0762	.0762	.0572	.0762	.0716	.0543	.0724
21	.0762	.0762	.0762	.0762	.0526	.0537	.0724
22	.0762	.0762	.0572		.0526	.0358	.0537
23	.0572	.0572	.0572	.0572	.0486	.0343	.0526
24	.0381	.2715	.3001	.2429	.0572	.0328	.0347
Max	.8383	.587	.5792	.6401	.8078	3.2733	.7468
Min	.0381	.0381	.0383	.0286	.0381	.0328	.0343
Avg	.2785	.1873	.1935	.1869	.2867	.4287	.2710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 204 / 11KV Shirte Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3807	.0446	.0474	.048	.5441	.4744	.4428
2	.3807	.0446	.0469	.048	.5281	.4744	.427
3	.3715	.0446	.0469	.048	.5281	.4744	.427
4	.3715	.0446	.0469	.048	.5281	.4902	.4531
5	.3858	.0594	.0625	.064	.5601	.5535	.4843
6	.5287	.0743	.0781	.08	.6722	.6325	.5624
7	.6001	.104	.1107	.096	.8962	.8381	.7968
8	.7922	.0892	.0949	.112	1.0242	.9804	.9217
9	.7335	.0743	.0791	.08	.933	.9962	.9217
10	.0587	.0743	.0791	.08	.0633	.0633	.0781
11	.0587	1.4415	1.692	1.5684	.0633	.0633	.0625
12	.0587	1.5699	1.8027	1.6324	.0633	.0633	.0469
13	.0587	1.6204	1.8185	1.6324	.0633	.0633	.0469
14	.0587	1.6204	1.7553	1.6004	.0633	.0474	.0469
15	.044	1.6248	1.7604	1.6004	.0633	.0474	.0625
16	.0587	1.5779	1.6644	1.5043	.0633	.0633	.0469
17	.0587	1.3904	1.5684	1.4403	.0633	.0474	.0625
18	.0587	1.2811	1.4083	1.2323	.0791	.0633	.0781
19	.0734	.0937	.112	.096		.0949	.0937
20	.0734	.0937	.112	.096	.0949	.0949	.0937
21	.0734	.0949	.096	.096	.0949	.0949	.0781
22	.0734	.0791	.096	.08	.0791	.0791	.0625
23	.0594	.0625	.08	.064	.0633	.0633	.0469
24	.4115	.0594	.0625	.048	.5441	.4428	.427
Max	.7922	1.6248	1.8185	1.6324	1.0242	.9962	.9217
Min	.044	.0446	.0469	.048	.0633	.0474	.0469
Avg	.2426	.5527	.6134	.5581	.3337	.3044	.2821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 205 / 1KV Yede Lvanmachi Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.3704	.3048	.3269	.0446	.0602	.0457
2	.0343	.3704	.3201	.3269	.0446	.0452	.0457
3	.0349	.3704	.3201	.3269	.0446	.0452	.0457
4	.0343	.3658	.3311	.3269	.0446	.0452	.0457
5	.0349	.3963	.3658	.3567	.0594	.0602	.0457
6	.0638	.5182	.4064	.4458	.0743	.0753	.0762
7	.0812	.5487	.5268	.5053	.0743	.0753	.0914
8	.0846	.6554	.6171	.5796	.0892	.0903	.0914
9	.0724	.5792	.6171	.6241	.0743	.0602	.061
10	.0572	.0762	.0753	.0743		.0753	.061
11	.9297	.0762	.0602	.0594	.9362	1.0084	.9145
12	.945	.061		.0594	1.0254	1.0987	.9755
13	.945	.061		.0594	1.1294	1.0987	.9755
14	1.0031	.061		.0594	1.1145	1.1138	.945
15	.9568	.061		.0594	1.07	1.0686	.9755
16	.9105	.0762	.0903	.0594	1.0235	.9633	.9297
17	.8488	.061	.0753	.0594	.9934	.8993	.823
18	.787	.061	.0903	.0743	.9181	.7926	.7773
19	.0772	.0914	.0892	.0743	.0903	.0762	.0762
20	.0772	.0914	.0903	.0743	.0753	.0762	.0762
21	.0772	.0762	.0903	.0743	.0753	.0762	.0762
22	.0772	.061	.0753	.0594	.0602	.061	.061
23	.0617	.061	.0753	.0594	.0602	.061	.061
24	.3549	.0617	.3048	.3161	.0446	.0602	.0457
Max	1.0031	.6554	.6171	.6241	1.1294	1.1138	.9755
Min	.0343	.061	.0602	.0594	.0446	.0452	.0457
Avg	.3576	.2172	.2463	.2101	.3985	.3786	.3467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 201 / 11 KV RAJARAM NAGER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1494	.1478	.1132	.1334	.1509	.1509
2	.1097	.1307	.1494	.1132	.1334	.1132	.132
3	.1109	.128	.112	.1132	.1334	.1132	.132
4	.1307	.132	.112	.1132	.1524	.1132	.132
5	.1494	.1698	.1494	.132	.1715	.1509	.1494
6	.1829	.1867	.1886	.1509	.1905	.1886	.1886
7	.2587	.2801	.2641	.2075	.2667	.2263	.2241
8	.2926	.3395	.2987	.2263	.3239	.3018	.3206
9	.2957	.2987	.2614	.2667	.2743	.2587	.3174
10	.2477	.2195	.2561	.2667	.2218	.2172	.2667
11	.2286	.2507	.2561	.2096	.2195	.2149	.2667
12	.2286	.2507	.2378	.1905	.2126		.2096
13	.1905	.181	.2378	.1905	.1791		.1905
14	.1715	.1772	.2172	.1715	.181		.1905
15	.2096	.1791	.181	.1715	.2126		.1905
16	.2096	.208	.1791	.1524	.1753		.2286
17	.2477	.208	.197	.1715	.1772		.2667
18	.2126	.2401	.2149	.1905	.2126		.2667
19	.2743	.2587	.2195	.3048	.2218	.3174	.2858
20	.2957	.2587	.2402	.2477	.2241	.3018	.2667
21	.2587	.2241	.2241	.2286	.2241	.2641	.2286
22	.2218	.2241	.2075	.1905	.2241	.2263	.1905
23	.1848	.1848	.1698	.1905	.1886	.1886	.1905
24	.128	.168	.1478	.132	.1715	.1509	.1698
Max	.2957	.3395	.2987	.3048	.3239	.3174	.3206
Min	.1097	.128	.112	.1132	.1334	.1132	.132
Avg	.2071	.2103	.2029	.1852	.2011	.2058	.2148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 202 / 11 KV Uran-Islampur

GAOTHAN FEEDER

Gaothan. Feeder KV- 11 /
OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5228	.5792	.5601	.7049	.543	.5975
2	.499	.5228	.5487	.5228	.6287	.5121	.5601
3	.5121	.5228	.5487	.5228	.5716	.5121	.5601
4	.5914	.5228	.5853	.5228	.724	.5487	.5601
5	.7392	.7842	.7682	.7095	.8383	.695	.7762
6	.9145	.924	.924	.8962	1.0288	.8871	.9709
7	1.1273	1.0974	1.1203	1.1088	1.0288	1.1203	1.0974
8	1.0425	1.0608	1.0456	.9795	1.0098	.9709	1.0719
9	.8316	.9145	.8962	.9526	.8596	.8501	.9145
10	.8383	.8779	.8131	.8192	.8326	.8413	.9526
11	.724	.7164	.695	.7811	.6447	.6516	.7621
12	.724	.6805	.695	.724	.6447	.5853	.743
13	.6478	.6447	.695	.724	.6024	.5853	.724
14	.6097	.567	.6584	.7049	.567		.6668
15	.6097	.6089	.6219	.7811	.567		.6668
16	.8192	.7442	.6219	.8573	.7442		.6668
17	.724	.7011	.724	.8383	.7282	.8413	.7811
18	.7522		.8145	.7811	.7712	.7865	1.086
19	1.134	1.1104	1.1827	1.2384	1.1462	1.1949	1.1812
20	1.1273	1.0745	1.0456	1.086	.8954	1.1016	1.1241
21	1.0349	.9313	1.0456	1.0098	.905	1.0456	1.0669
22	.9055	.905	.9335	.9717	.8688	.8589	.8954
23	.7023	.6516	.7468	.8192	.6516	.7095	.8192
24	.5729	.5544	.6154	.5975	.7621	.5792	.6348
Max	1.134	1.1104	1.1827	1.2384	1.1462	1.1949	1.1812
Min	.499	.5228	.5487	.5228	.567	.5121	.5601
Avg	.7790	.7670	.7885	.8129	.7802	.7819	.8283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 203 / 11KV Mahadev Nagar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.5914	.6219	.5975	.724	.5914	.6722
2	.5544	.5544	.5914	.5601	.7049	.5544	.6348
3	.543	.5544	.5914	.5601	.7049	.5544	.6348
4	.6036	.5544	.6283	.5601	.743	.5975	.6535
5	.7602	.7392	.7392	.7095	.8192	.7842	.7762
6	.9328	.9522	.8962	.8589	.9907	.9335	.9335
7	1.3306	1.2071	1.1949	1.1827	1.2955	1.1949	1.2567
8	1.3717	1.4266	1.2696	1.4045	1.3527	1.419	1.5708
9	1.1088	1.1157	1.1576	1.1812	1.1222	1.1203	1.262
10	1.2765	1.0974	.9979	1.086	1.134	1.1706	1.2574
11	.8573	.9511	.9145	.9335	.8779	.8507	1.0098
12	.8764	.905	.8779	.8573	.8048		.9526
13	.8764	.7964	.8779	.8192	.724		.8002
14	.8573	.724	.8413	.8192	.7964		.7811
15	.7811	.7964	.7865	.7621	.724		.7811
16	.724	.724	.7682	.7811	.724		.9145
17	.8002	.7522	.7964	.8954	.7964		.9526
18	.9492	.815	.9593	1.0098	.9412		1.2765
19	1.4998	1.5043	1.4083	1.6004	1.448	1.8107	1.5242
20	1.4083	1.39	1.3169	1.4861	1.3535	1.5893	1.3527
21	1.2803	1.1706	1.2071	1.1812	1.1706	1.307	1.2765
22	1.0974	1.0242	1.0974	1.1241	1.0608	1.1203	1.0098
23	.823	.8048	.8501	.9145	.7762	.8962	.9526
24	.6468	.6468	.6584	.6468	.8192	.6283	.7468
Max	1.4998	1.5043	1.4083	1.6004	1.448	1.8107	1.5708
Min	.543	.5544	.5914	.5601	.7049	.5544	.6348
Avg	.9386	.9082	.9187	.9388	.9420	1.0072	.9993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 204 / 11KV Urun Ag Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.3201	.3201	.3201	.0762	.0762	.0754
2	.0732	.3201	.3125	.3201	.0762	.0762	.0754
3	.0732	.3201	.3125	.3201	.0762	.0762	.0754
4	.0724	.3201	.3395	.3201	.0762	.0762	.0754
5	.0732	.3563	.3704	.3361	.0762	.0762	.0754
6	.0724	.4049	.4012	.3725	.0762	.0762	.0754
7	.0732	.502	.5693	.4858	.0762	.0762	.0754
8	.0732	.6478	.6722	.5182	.0762	.0762	.0943
9	.0739	.7125	.7042	.6859	.0633	.0754	.0754
10	.0762	.0762	.0754	.0762	.0754	.0754	.0762
11	.743	.0754	.0754	.0762	.8097		1.2193
12	1.105	.0754	.0754	.0762	.9602		1.2384
13	1.086	.0754	.0754	.0762	.9602		1.2955
14	1.105	.0754	.0754	.0762	.9922		1.2765
15		.0754	.0754	.0762	.9922		1.2384
16	.724	.0754	.0754	.0762	.9172		1.2003
17	.8002	.0754	.0754	.0762	.9804		.9526
18	.6081	.0739	.0754	.0762	.8855		.9145
19	.0934	.0754	.0754	.0762	.0762	.0943	.0762
20	.0754	.0762	.0943	.0762	.0762	.0943	.0762
21	.0754	.0762	.0943	.0762	.0762	.0943	.0762
22	.0754	.0762	.0754	.0762	.0762	.0754	.0762
23	.0754	.0189	.0754	.0762	.0762	.0754	.0762
24	.0732	.3361	.3201	.3201	.0762	.0762	.0754
Max	1.105	.7125	.7042	.6859	.9922	.0943	1.2955
Min	.0724	.0189	.0754	.0762	.0633	.0754	.0754
Avg	.3206	.2184	.2256	.2111	.3626	.0794	.4402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV KHED GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV WALWA FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	1.9719
Max	1.9719
Min	1.9719
Avg	1.9719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV LIS BOR FEEDER
Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-FEB-18
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV KHED AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV BORGON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 402 / 33 KV Kirloskar Wadi
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	3.4294
Max	3.4294
Min	3.4294
Avg	3.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 403 / RATHARE BK

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 404 / 33KV BAHE

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.086
Max	1.086
Min	1.086
Avg	1.086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 701 / Rajaram Bpau SSK Sakharale NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-FEB-18
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV Kasegaon Gaothan-
Village Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1629		.1478		.1829	.1509
2	.1509	.168	.1509	.1478		.1867	.1509
3		.2241	.1509	.1753		.2241	.1509
4		.2149	.1509	.1753		.362	.1509
5		.3582	.1886	.3475		.5068	.1886
6		.5175		.5041		.543	.3772
7		.5914		.5914		.543	.5853
8		.5853	.1509	.5914		.6219	
9	.5121	.394	.5121	.4435	.5487	.3292	
10	.3155	.3761	.3982	.3403	.4344	.3109	
11	.3696	.3982	.3801	.3292	.3658	.2896	
12	.3077	.3658	.3801	.362	.3258	.3582	
13	.2926	.3475	.3658	.3658	.3439	.5792	
14		.362	.2195	.333	.3224	.394	
15		.3841	.2195	.3326	.2507	.3582	
16		.3841	.2658	.2804	.3544	.394	
17	.4108	.3582	.3326		.439	.1829	.3658
18	.4755	.3658	.4435		.4755	.3292	
19	.6535	.6219	.6036		.6348	.5853	.5914
20	.6219	.5487	.5304		.5975	.5487	.5175
21	.5121	.439	.4207		.4481	.5487	.4207
22	.362	.3658	.3292		.3326	.3696	.362
23	.2218	.2263	.2218		.2218	.2241	.2353
24	.5258	.1629	.1509	.1478		.1829	.1509
Max	.6535	.6219	.6036	.5914	.6348	.6219	.5914
Min	.1509	.1629	.1509	.1478	.2218	.1829	.1509
Avg	.3922	.3718	.3127	.3303	.4064	.3815	.3142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV Nerle Gaothan feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3395		.3395		.3018	
2		.2587		.2926		.2614	
3		.2587		.2926		.2614	
4		.3077		.3734		.3475	
5		.362		.4527		.439	
6		.4481		.5093		.5601	
7		.4854		.6348		.5975	
8		.6348		.6036		.6602	
9		.5788	.4755	.543	.5487	.5601	
10		.5729	.4344	.3982	.5373	.5175	
11			.4344	.5068	.1254	.4024	
12		.5175	.5068	.4706	.124	.439	
13		.3292	.4024	.4755	.0709	.0701	
14		.2328	.567	.4706	.3506	.1052	
15		.2012	.567	.362	.4207	.1753	
16		.2195	.5959	.362	.4908	.2947	
17	.5975		.6036		.5601		.5415
18	.6348		.6036		.7095		.6722
19	.7922		.695		.7133		.7545
20	.7842		.7468		.7545		.7356
21	.6602		.7167		.7095		.6908
22	.5487		.5415		.5601		.4572
23	.3734		.4527		.3772		.3361
24	.3395	.3395		.3395		.2926	
Max	.7922	.6348	.7468	.6348	.7545	.6602	.7545
Min	.3395	.2012	.4024	.2926	.0709	.0701	.3361
Avg	.5913	.3804	.5562	.4369	.4702	.3698	.5983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV Tambave Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743		.2926		.2926	
2		.2481		.2481		.2561	
3		.2481		.2481		.2507	
4		.3361		.3109		.3403	
5		.4294		.439		.4755	
6		.5175		.5228		.5544	
7		.5729		.5601		.5544	
8		.543		.5729		.5544	
9		.3982	.439	.4066	.4024	.499	
10		.3544	.4344	.3801	.362	.4024	
11		.3544	.362	.3475	.3258	.3696	
12		.3544	.3292	.3258	.3045	.3292	
13		.3155	.3841	.3658	.3077	.2957	
14		.2804	.2743	.3658	.2804	.3326	
15		.2629	.2743	.3696	.2454	.2804	
16		.2454	.1829	.2218	.2743	.1753	
17	.3292		.2715		.3326		.3734
18	.3292		.362		.4066		.3734
19	.4938		.4572		.4887		.439
20	.439		.4525		.4066		.4435
21	.362		.362		.4024		.3658
22	.3734		.4163		.3696		.3361
23	.3258		.362		.3326		.3292
24	.2641	.2743		.2926		.2865	
Max	.4938	.5729	.4572	.5729	.4887	.5544	.4435
Min	.2641	.2454	.1829	.2218	.2454	.1753	.3292
Avg	.3646	.3535	.3576	.3688	.3494	.3676	.3801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV Wategaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.112		.1109		.112	.1132
2	.0754	.1075		.1086		.1075	.1132
3		.1109		.1086		.1075	.1132
4		.1463		.1772		.1848	.1132
5		.2195		.2126		.2587	.1509
6		.2896		.2957		.3174	.2641
7		.3326		.3326		.3109	.3292
8		.3841		.3658		.362	
9	.2926	.2454	.2926	.3582	.2926	.3292	
10	.3077	.2103	.2561	.2947	.2715	.2561	
11	.2172	.1372	.2561	.3155	.2012	.2378	
12	.2195	.1715	.2561	.2103	.2195	.2195	
13	.2195		.2561	.208	.1463	.1772	
14	.2012	.1886	.1829	.1886	.1848	.1928	
15	.1829	.2103	.1829	.2058	.2033	.1753	
16	.1829	.2601	.181	.1715	.2012	.1753	
17	.2172	.2561	.2561		.2402	.1829	.2686
18	.2896	.3292	.2534		.2926	.3292	.3582
19	.4294		.4163		.439		.4163
20	.3841	.4024	.4251		.4435		.3921
21	.3224	.3292	.3475		.3475		.3292
22	.2149	.1848	.2896		.2402	.2218	.2149
23	.1294	.1509	.168		.1663	.1867	.1463
24	.5258	.112		.1109		.112	.1132
Max	.5258	.4024	.4251	.3658	.4435	.362	.4163
Min	.0754	.1075	.168	.1086	.1463	.1075	.1132
Avg	.2493	.2223	.2680	.2221	.2593	.2170	.2291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 205 / 11 KV KASEGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9602	.8962	.9602		.0457	
2		1.0322	.8962	1.0242		.0457	
3		1.0082	.8962	1.0486		.0457	
4		1.0883	.8962	1.0911		.0914	
5		1.0753	.8962	1.0911		.0914	
6		1.1227		1.1683		.125	
7		1.1363		1.2163		.125	
8		1.4243		1.4083		.125	
9	.061	1.4083	1.3443	.112	.061	2.0309	
10	1.5623	.125	.112	.125	1.1111	2.0881	
11	2.0778	.0937	.0937	.1094	2.0216	2.1643	
12	2.0679	.0914	.0937	.0926	2.0119	2.2184	
13	2.0622	.0914	.0937	.0926	2.0119	2.2028	
14	2.0622	.061	.125	.0914	2.037	2.1296	
15	2.1247	.0762	.08	.0762	1.9753	1.9599	
16	2.1142	.0937	.0926	.0762	1.9204		
17	2.0805		.1094		1.7966		1.6004
18	1.6644		.1094		1.6324		.4588
19	.0762		.125		.0762		.0762
20	.0762		.0762		.0762		.0762
21	.0762		.061		.0762		.061
22	.061		.061		.061		.061
23	.061		.061		.061		.061
24	.061	.9602	.8962	.9602		.0457	
Max	2.1247	1.4243	1.3443	1.4083	2.037	2.2184	1.6004
Min	.061	.061	.061	.0762	.061	.0457	.061
Avg	1.1431	.6970	.3817	.6320	1.1287	.9709	.3421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 206 / 11 KV NERLE AG. FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457		.061		.9602	
2		.0457		.0625		1.0242	
3		.0457		.0457		1.0486	
4		.0457		.0469		1.1469	
5		.0457		.0457		1.278	
6		.0457		.0762		1.3108	
7		.0457		.0762		1.3927	
8		.0457		.061		1.0159	
9	.1219	.0625	.061	.0781	1.4083	1.2498	
10	1.656	1.7604	1.7497	2.037	.112	.1094	
11	2.3967	1.8122	2.1247	2.1451	.096	.096	
12	2.2965	1.9109	2.1403	2.2184	.1094	.112	
13	2.3903	2.0622	2.1559	2.2184	.1094	.1219	
14	2.2558	2.1296	2.1033	2.2028	.0949	.1067	
15	2.2965	2.1759	2.1559	2.0881	.0937	.1067	
16	2.0309	2.1605	2.2497	1.9216	.0949	.0914	
17	.0914		2.0805		.0914		.061
18	.0762		1.8244		.061		.0762
19	.0762		.0762		.061		.0762
20	.0762		.061		.061		.061
21	.0762		.061		.061		.061
22	.061		.061		.061		
23	.061		.0457		.061		.061
24	.8322	.0457		.061		.9602	
Max	2.3967	2.1759	2.2497	2.2184	1.4083	1.3927	.0762
Min	.061	.0457	.0457	.0457	.061	.0914	.061
Avg	1.0497	.8521	1.2634	.9086	.1717	.7136	.0661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 207 / 11 KV Wategaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7682		.8322		.0762	
2		.7682		.9069		.061	
3		.8848		.9069		.061	
4		.8848		.9831		.0937	
5		1.0279		1.1305		.0937	
6		1.1069		1.1961		.1406	
7		1.2323		1.2803		.1406	
8		1.5364		1.7124		.125	
9			1.6004	1.6164	.1219	.0937	
10			.1094	.125	1.8435	2.2405	
11			.0972	.1094	2.4383	2.6825	
12		.0937	.0937	.1094	2.6216	2.8086	
13		.0937	.1389	.096	2.6825	2.9371	
14		.0772	.1094	.0926	2.7183	2.7496	
15		.0617	.1562	.1094	2.5152	2.8277	
16		.0937		.0937	2.4059	2.3278	
17	2.0005		.125		2.3205		1.8884
18	1.6004		.125		1.9685		1.8404
19	.1875		.1406		.1406		.1406
20	.1875		.1406		.1406		.1406
21	.1562		.1406		.1406		.1406
22	.1562		.125		.125		.125
23	.125		.0914		.125		.0762
24	.061	.7682		.8322		.0762	
Max	2.0005	1.5364	1.6004	1.7124	2.7183	2.9371	1.8884
Min	.061	.0617	.0914	.0926	.1219	.061	.0762
Avg	.5593	.6713	.2281	.7137	1.4872	1.1491	.6217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 208 / 11 KV Tambave Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457		.0457		.7865	
2		.0457		.0457		.8048	
3		.0457		.0457		.9054	
4		.061		.0457		.8848	
5		.061		.0457		.9831	
6		.0457		.0762		1.0402	
7				.0762		1.0722	
8				.061		1.2944	
9	1.0242	.1067	.061	.1067	1.2803	1.2186	
10	.112	1.5586	1.7071	1.7497	.112	.108	
11	.0937	1.6872	2.3167	2.0309	.096	.1094	
12	.0949	1.7185	2.4215	2.1559	.0937	.1094	
13	.1094	2.1403	2.3278	2.2965	.08	.1311	
14	.0926	2.1759	2.284	2.2685	.096	.0937	
15	.0937	2.1914	2.3122	2.1605	.096	.1094	
16	.1094	2.1914	2.3122	2.2024	.0937		
17	.1094		2.3205		.0625		
18	.0457				.061		.061
19	.0762		.0762		.061		.0457
20	.0762		.061		.061		.061
21	.0762		.061		.061		.061
22	.0457		.061		.061		.061
23	.0457		.0457		.061		.0762
24	.6478	.0457		.0457		.7865	
Max	1.0242	2.1914	2.4215	2.2965	1.2803	1.2944	.0762
Min	.0457	.0457	.0457	.0457	.061	.0937	.0457
Avg	.1783	.9414	1.3120	.9093	.1584	.6523	.0610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 209 / 11 KV Someshwar

PURELY LIS FEEDERS

Bhairavnath LI Feeder KV- 11 /
OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187		.0187		.1075
2		.0187		.0187		
3		.0181		.0543		.1075
4		.0181		.0543		.1075
5		.3174		.0543		.1075
6		.5041		.3881		.1075
7		.6036		.4207		.2601
8		.8962		.7207		
9	.6908	.8402	.6908	.7207	.6859	
10	.7023	.924	.6908	.7207	.6687	
11	.6805	.924	.6908	.7133	.6001	
12	.7023	.905	.6908	.695	.6687	
13	.6838	.961	.6908	.7133	.6516	
14	.7023	.9511	.6653	.6878	.6687	
15	.7207	.9511	.6653	.6984	.6687	
16	.7207	.9328	.6767	.1097	.6859	
Max	.7207	.961	.6908	.7207	.6859	.2601
Min	.6805	.0181	.6653	.0187	.6001	.1075
Avg	.7004	.6115	.6827	.4243	.6623	.1329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 210 / 11 KV Krishna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.1898	.12		.1989
2	.0514	.0514	.1898	.12		.1989
3		.0514	.1898	.1526		.1989
4		.0509	.1898	.1526		.1989
5		.3222	.1898	.463		.4578
6		.6687		.9088		.9326
7		1.166		1.286		1.2689
8		.1029		1.286		1.2689
9	.6274	1.1458	.0497	1.2346	1.6617	1.2656
10	.7969	1.5775	1.543	1.3032		1.5339
11	.7969	1.6289	1.6448	1.283		1.7337
12	1.0513	1.6118	1.6278	1.6827		1.8031
13	1.1022	1.6126	1.6632	1.7337		1.7857
14	1.0898	1.4922	1.6804	1.7164		1.7857
15	1.0898	1.4022	1.6956	1.6632	.8383	1.7857
16	.9892	1.2269	.8987	1.6461	.3749	1.4217
24	.0514					
Max	1.1022	1.6289	1.6956	1.7337	1.6617	1.8031
Min	.0514	.0509	.0497	.12	.3749	.1989
Avg	.6998	.8852	.9040	1.0470	.9583	1.1149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 202 / 11 KV YELUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1829	.1886	.1886	.1867	.1698	.1698
2	.1698	.1829	.1698	.2075	.1829	.1509	.1509
3	.1509	.2149	.1698	.2075	.2172	.1509	.1509
4	.2263	.2218	.2263	.2263	.2149	.2263	.1886
5	.3018	.2987	.2829	.2829	.3189	.3018	.2641
6	.3395	.362	.3584	.3772	.3982	.3772	.3584
7	.5228	.4481	.4668	.4668	.4854	.5041	.4668
8	.462	.4108	.4805	.462	.4435	.4066	.4251
9	.4024	.3658	.3511	.4024	.3696	.3292	.3658
10	.2572	.362	.2804	.298	.2804	.2572	.3258
11	.2103	.2804	.2401	.2279	.2454	.2279	.2715
12	.2103	.2454	.2401	.2103	.2454	.2103	.2149
13	.2103	.2058	.2401	.2103	.2401		.1791
14	.2058	.2012	.1753	.2103	.2454	.2103	.1791
15	.2103	.1753	.1543		.2195	.2058	.1791
16	.1753	.2103	.1578	.2058	.2103	.2103	.2195
17	.1715	.2103	.1578	.2103	.2103	.2279	.2572
18	.2947	.3224	.2865	.3121	.3258	.2896	.3544
19	.5121	.4572	.499	.394	.4572	.4572	.4805
20	.4805	.4481	.5041	.4755	.4805	.462	.439
21	.3734	.3961	.4338	.4066	.4108	.3921	.3361
22	.2987	.3018	.3395	.3142	.3018	.3018	
23	.1867	.2263	.2452	.2218	.2075	.1886	
24	.1886	.1867	.1886	.1886	.1848	.1698	.1698
Max	.5228	.4572	.5041	.4755	.4854	.5041	.4805
Min	.1509	.1753	.1543	.1886	.1829	.1509	.1509
Avg	.2812	.2882	.2849	.2916	.2951	.2795	.2794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 203 / 11 KV Aitwadi Kh -Gaothan-
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1829	.1698	.1886	.1829	.1494	.1509
2	.1698	.1791	.1698	.1886	.181	.132	.1509
3	.1698	.2103	.1886	.2075	.1791	.132	.132
4	.2263	.2172	.2075	.2075	.2126	.2263	.2075
5	.2801	.3292	.2641	.2075	.2534	.2987	.2801
6	.3547	.4108	.3772	.3961	.3326	.4108	.3921
7	.5175	.4805	.5228	.5228	.3658	.5175	.4805
8	.4572	.5175	.4805	.499	.4252	.439	.439
9	.362	.3982	.3511	.4207	.3696	.362	.3982
10	.2804	.3155	.2454	.3506	.2865	.3086	.3224
11	.2454	.2401	.2804	.3155	.2454	.2865	.3258
12	.2454	.2454	.2804	.3155	.2401	.2454	.2126
13	.2401	.2454	.2743	.2804	.2454		.2263
14	.2103	.2103	.2683	.2804	.2103		.1753
15	.2103	.1753	.2401	.2401	.1886		.1772
16	.2103	.2103	.2454	.2103	.2103		.2454
17	.2401	.2454	.2454	.1928	.2401		.3086
18	.3353	.3258	.2896	.3353	.2865	.4298	.3429
19	.4656	.4938	.4572	.4656	.4344	.5792	
20	.4706	.4854	.4805	.4656	.4207	.5487	
21	.439	.4338	.4108	.4024	.4066	.4805	.3658
22	.3292	.3395	.3206	.3326	.3361	.3174	
23	.2195	.2641	.2263	.4435	.1867	.1886	
24	.1886	.1848	.1698	.1886	.1848	.1494	.1509
Max	.5175	.5175	.5228	.5228	.4344	.5792	.4805
Min	.1698	.1753	.1698	.1886	.1791	.132	.132
Avg	.2940	.3059	.2986	.3191	.2760	.3264	.2742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 204 / 11 KV WASHI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.12	.132	.132	.1029	.1132	.1509
2	.1132	.1227	.1509	.132	.1052	.1132	.132
3	.1132	.1254	.1698	.1509	.1791	.1132	.132
4	.1509	.1463	.2075	.1698	.2561	.1509	.1886
5	.2263	.2172	.2641	.2263	.3361	.2263	.2452
6	.3018	.7087	.3772	.3395	.4066	.3018	.3206
7	.4668	.373	.5041	.4481	.3467	.4668	.4854
8	.4805	.3932	.462	.462	.3932	.4066	.4805
9	.4207	.2915	.4024	.3658	.3605	.3475	.4207
10	.3506	.2984	.3086	.3018	.3155	.3224	.362
11	.3155	.2804	.2804	.3429	.2804	.3155	.362
12	.3086	.2454	.2804	.3086	.2804		.3429
13	.3018	.2263	.2804	.2454	.2804		.2454
14	.2454	.2103	.2103	.2058	.2743		.1715
15	.2058	.2058	.1753	.1753	.2743	.3353	.1791
16	.1715	.2804	.2401	.2058	.2743	.3052	.2401
17	.2058	.3429	.2108	.2103	.2103	.3856	.2683
18	.2652	.3012	.2328	.2439	.2865	.362	.2622
19	.2229	.4887	.4572	.3772	.439	.5121	
20	.4207	.462	.462	.431	.4435	.499	
21	.3647	.3961	.3921	.3353	.4108	.4108	.3647
22	.2652	.2829	.3206	.3086	.3018	.3018	
23	.1341	.2075	.2263	.1658	.1698	.1886	
24	.1132	.1187	.132	.132	.1006	.1132	.1509
Max	.4805	.7087	.5041	.462	.4435	.5121	.4854
Min	.1132	.1187	.132	.132	.1006	.1132	.132
Avg	.2616	.2852	.2866	.2673	.2845	.2996	.2753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 205 / 11 KV Aitwade Kh Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7186	.037	.0377	.0377	1.0059	.9667	.7287
2	.7116	.0366	.0377	.0377	1.0288	.9779	.7209
3	.6958	.0362	.0377	.0377	.1052	.9614	.7209
4	.7202	.0354	.0377	.0377	1.2178	.9831	.7956
5	.7682	.0549	.0377	.0377	1.262	1.0159	.9116
6	.8421	.0554	.0566	.0566	1.4685	1.1336	1.004
7	.9393	.0754	.0754	.0754	1.4922	1.2631	1.1498
8	.9602	.056	.0566	.0754	1.5424	1.3763	1.2452
9	.9602	.0366	.0377	.0566	1.4746	1.2944	1.1469
10	.0351	.056	.0377	.0377	.0351	.0343	.0377
11	.0351	1.9631	1.9631	2.1735	.0343	.0351	.0377
12	.0377	1.8983	1.9281	2.1033	.0351	.0351	.0566
13	.0377	1.8671	1.9281	2.1033	.0343		.0377
14	.0377	2.0576	2.0576	2.1033	.0351		.0377
15	.0377	2.0576	2.3487	2.1384	.0351	.0351	.0377
16	.0377		2.1033	2.0576	.0343	.0351	.0377
17	.0377	2.3137	1.893	2.1384	.0351	.0351	.0377
18	.0566	1.8204	1.7337	1.829	.0373	.0566	.0566
19	.056	.0732	.0566	.0543	.0754	.0754	
20	.0566	.0754	.0566	.0537	.0754	.0754	
21	.0566	.0566	.0566	.0549	.0566	.0566	.0566
22	.0377	.0566		.0554	.0377	.0566	
23	.0343	.0377	.0377	.0366	.0377	.0377	
24	.7186	.0377	.0377	.0377	.9717	.9503	.7287
Max	.9602	2.3137	2.3487	2.1735	1.5424	1.3763	1.2452
Min	.0343	.0354	.0377	.0366	.0343	.0343	.0377
Avg	.3595	.6432	.7241	.7262	.5070	.5223	.4793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 207 / 11 KV WASHI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.6401	.68	.8223	.0554	.0377	.0377
2	.0566	.5898	.6958	.7968	.0549	.0377	.0377
3	.0566	.6036	.7362	.7907	.0543	.0377	.0377
4	.0566	.6516	.7362	.8124	.0537	.0377	.0566
5	.0566	.7712	.8002	.8697	.0549	.0377	.0566
6	.0754	.8139	.8907	.9762	.0724	.0566	.0754
7	.0754	.9393	.9878	1.0242	.0678	.0754	.0943
8	.0754	1.166	1.1469	1.247	.0617	.0754	.0754
9	.0754	1.0059	1.2616	1.3603	.0709	.0566	.0747
10	.0701	.0754	.0335	1.4373	.0754	.0566	.0739
11	2.2085	.0754	.0343	.0343	2.1033	2.3388	2.5149
12	2.2436	.0701	.0343	.0351	2.0348		2.2939
13	2.2786	.0686	.0343	.0351	2.2786		2.3205
14	2.1033	.0701	.0351	.0701	2.3834		2.2672
15	1.9982	.0686	.0351	.0686	2.4348		2.0485
16	1.9281	.0701	.0343	.0701	2.1033	2.2291	1.989
17	1.6476	.0701	.0351	.0701	2.0332	2.4006	1.5546
18	1.2018	.0724	.0543	.1132	1.9281	1.9334	1.5546
19	.0914	.0943	.0943	.056	.1132	.0943	.0914
20	.0934	.0943	.0943	.056	.1132	.0943	
21	.112	.0754	.0943	.0934	.0943	.0943	.0943
22	.0943	.0754	.0754	.0924	.0754	.0754	
23	.0754	.0566	.0754	.0566	.0754	.0566	
24	.0566	.7499	.6882	.8322	.056	.0377	.0377
Max	2.2786	1.166	1.2616	1.4373	2.4348	2.4006	2.5149
Min	.0566	.0566	.0335	.0343	.0537	.0377	.0377
Avg	.6995	.3737	.3912	.4925	.7687	.4932	.8279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 208 / 11 KV YELUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.8322	.9282	.8907	.056	.0754	.0754
2	.0754	.8192	.9014	.8642	.056	.0566	.0754
3	.0754	.8048	.9014	.8642	.0554	.0566	.0566
4	.0754	.823	.9172	.8855	.0732	.0566	.0754
5	.0943	.9816	.9762	.933	.0724	.0754	.0943
6	.1132	1.166	1.0242	1.0242	.0895	.0943	.1132
7	.132	1.1843	1.1523	1.1363	.1132	.1132	.132
8	.1132	1.6194	1.4575	1.4737	.0943	.1132	.1132
9	.0754	1.5043	1.5729	1.5384	.0934	.1132	.1132
10	.0701	.1097	.0377	1.5089	.1791	.1132	.1132
11	2.7168	.0678	.0343	.0514	2.4714	2.6292	2.3472
12	2.572	.0686	.0343	.0514	2.4006	2.572	2.2283
13	2.4249	.0701	.0343	.0526	2.6505		2.2939
14	2.2291	.0686	.0526	.0526	2.6292	2.4006	2.2283
15	2.2466	.0701	.0526		2.572	2.4006	1.9524
16	2.2611	.0701	.0701		2.4539	2.4539	1.9227
17	1.9281	.0701	.0701		2.1735	2.4364	1.5935
18	1.704	.0895	.1075	.1235	2.0576	2.0553	1.5729
19	.1029	.1132	.132	.1494	.1509	.1698	.0566
20	.1132	.1132	.132	.1132	.132	.1509	.1132
21	.0943	.0943	.1132	.1132	.1132	.132	.1132
22	.1132	.0754	.0943	.0943	.0943	.1132	
23	.0716		.0754	.0754	.0754	.0943	
24	.0754	.828	.9282	.8907	.0566	.0754	.0943
Max	2.7168	1.6194	1.5729	1.5384	2.6505	2.6292	2.3472
Min	.0701	.0678	.0343	.0514	.0554	.0566	.0566
Avg	.8147	.5062	.4917	.6137	.8714	.8066	.7945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 209 / 11 KV Kundalwadi Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7293	.0351	.0377	.0377	1.7147	1.3226	1.1736
2	.7293	.0358	.0377	.0377	1.6126	1.291	1.153
3	.7042	.0358	.0377	.0377	1.6476	1.2574	1.1361
4	.7209	.0351	.0377	.0377	1.5927	1.3395	1.1271
5	.763	.0514	.0377	.0377	1.829	1.3904	1.1603
6	.8139	.0503	.0566	.0566	2.0058	1.4251	1.2239
7	.9259	.0617	.0754	.0754	2.0805	1.5089	1.4419
8	.9835	.0457	.0754	.0754	1.8861	1.6617	1.5091
9	1.5091	.056	.0566	.0566	1.858	1.6448	1.4752
10	.0343	.056	.0566	.0526	.0351	.0343	.0343
11	.0351	1.9982	2.1502	2.9047	.0351	.0351	.0297
12	.0351	2.2634	2.3388	2.7435	.0351		.0354
13	.0343	2.2786	2.2634	2.5377	.0351		.0362
14	.0343	2.3137	2.4188	2.1338	.0343		.0347
15	.0351	2.3487	2.6749		.0351		.056
16	.0343	2.3137	2.489	2.4539	.0351	.0343	.0549
17	.0343	2.2634	2.4539	2.3487	.0351	.0343	.037
18	.0549	2.1262	2.3232	2.4539	.0701	.0566	.0377
19	.0537	.0732	.0754	.0354	.0701	.0566	
20	.0543	.0754	.0754	.0537	.0686	.0566	
21	.052	.0566	.0566	.0693	.0686	.0566	.0566
22	.0509	.0566	.0566	.0358	.0526	.0377	
23	.0347	.0377	.0566	.0543	.0343	.0377	
24		.0343	.0377	.0377	1.7295	1.3226	1.1904
Max	1.5091	2.3487	2.6749	2.9047	2.0805	1.6617	1.5091
Min	.0343	.0343	.0377	.0354	.0343	.0343	.0297
Avg	.3677	.7793	.8325	.7986	.7750	.7302	.6502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 202 / 11 KV ITKARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	.0924	.0838	.0914	.8916	.9061	.9724
2	.9831	.0924	.0838	.0924	.8718	.8855	.9389
3	1.0059	.0914	.0838	.0934	.8718	.8749	.9389
4	.9831	.0914	.0857	.0934	.8718	.9374	.9389
5	1.0974	.1267	.0857	.0934	.9259	.9686	.9945
6	1.2407	.1772	.12	.1132	1.0288	1.0311	1.0631
7	1.5432	.1402	.1509	.1509	1.406	1.5181	1.6095
8	1.6712	.1629	.1509	.1307	1.6126	1.7394	1.6804
9	1.749	.1267	.132	.1109	1.7558	1.692	1.7878
10	.1227	.156	.1267	.1132	.0876	.12	.104
11	.124	2.8607	2.5065	2.524	.0747	.0943	.104
12	.0924	2.8433	2.8086	2.7069	.1075	.0943	.1086
13	.0924	2.9473	2.8086	2.452	.1075	.0943	.0876
14	.0934	2.8121	2.774	2.1735	.1075	.1132	.0876
15	.0934	2.5377	2.7435	2.079	.1075	.1132	.0876
16	.0924	2.4863	2.2634	2.0576	.0876	.0943	.0838
17	.128	2.2552	2.2119	1.9631	.104	.1132	.1075
18	.128	1.9071	1.8861	1.5775	.1372	.1132	.1402
19	.1595	.1698	.168	.1509	.1448	.1698	.1629
20	.1595	.1543	.1307	.1698	.168	.1698	.1646
21	.1448	.1698	.1109	.1509	.1494	.1509	.1307
22	.1086	.1147	.0924	.132	.128	.132	.112
23	.0924	.1006	.0914	.1029	.0914	.1132	.0934
24	1.1218	.0924	.0857	.0914	.9259	.9061	1.0166
Max	1.749	2.9473	2.8086	2.7069	1.7558	1.7394	1.7878
Min	.0924	.0914	.0838	.0914	.0747	.0943	.0838
Avg	.5866	.9462	.9077	.8089	.5319	.5477	.5631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 204 / 11 KV ITKARE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1463	.1463	.1463	.1463	.1463	.1463
2	.1463	.1463	.1463	.1463	.1463	.1463	.1463
3	.1463	.1463	.1417	.1463	.1463	.1463	.1463
4	.1463	.1463	.1463	.1463	.1463	.1463	.1463
5	.1829	.1829	.1829	.1829	.1829	.1829	.1829
6	.2561	.3109	.2561	.2378	.2561	.2561	.2561
7	.3292	.2743	.3292	.3292	.3292	.3292	.2926
8	.3292	.2926	.3292	.3292	.3292	.3658	.3292
9	.3292	.3109	.2926	.2743	.2926	.3475	.2926
10	.2957	.3292	.2561	.2561	.2561	.2561	.2587
11	.2587	.2587	.2218	.2195	.2561	.2561	.2587
12	.2402	.2402	.2561	.2561	.2033	.2195	.2033
13	.2033	.2561	.2378	.2195	.1867	.2195	.1848
14	.2054	.2218	.2195	.2195	.1867	.1829	.1848
15	.2427	.2218	.2195	.2195	.1867	.1829	.2033
16	.2054	.2218	.2195	.1829	.1132	.2561	.168
17	.2172		.2195	.1829	.2402	.2561	.2218
18	.2172	.2561	.2012	.2195	.2743	.3292	.2561
19	.362	.3658	.3841	.3658	.3658	.3658	.3841
20	.3801	.4024	.3841	.4024	.4024	.3658	.3658
21	.3475	.3658	.3292	.3658	.3109	.3292	.3109
22	.2926	.2926	.2561	.2195	.2378	.2561	.2743
23	.1829	.1829	.2012	.1463	.2012	.1829	.2378
24	.1463	.1463	.1463	.1463	.1463	.1463	.1829
Max	.3801	.4024	.3841	.4024	.4024	.3658	.3841
Min	.1463	.1463	.1417	.1463	.1132	.1463	.1463
Avg	.2420	.2486	.2384	.2317	.2310	.2446	.2347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 205 / Shivtirtha Express Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	07-FEB-18
HR	Load (MW)
23	.3475
Max	.3475
Min	.3475
Avg	.3475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 201 / 11 KV Karanjawade Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.2218	.2454	.2481	.2218	.2149	.2149
2	.1791	.2218	.2481	.2481	.2218	.2149	.2149
3	.1829	.2195	.2507	.2481	.2218	.1991	.2149
4	.1848	.2561	.2534	.2481	.2218	.1829	.2149
5	.2241	.2926	.2534	.2835	.2587	.2218	.2507
6	.2987	.3658	.2987	.2835	.3174	.2987	.2507
7	.3547	.362	.3547	.3189	.3326	.3547	.3582
8	.3511	.4706	.2987	.4656	.3881	.4075	.4656
9	.3814	.3224	.2561	.394	.3395	.3761	.394
10	.3982	.3189	.362	.3856	.3467	.3224	.3258
11	.3982	.3121	.2534	.3988	.3391	.3224	.2743
12	.3292	.2883	.3258	.3155	.2683	.3582	.3077
13	.2926	.1791	.2896	.2774	.2947	.2507	.2896
14	.2561	.2229	.181	.2743	.2915	.1791	.1991
15	.2534	.2652	.2172	.2743	.2743	.2149	.2715
16	.3982	.1844	.2172	.2401	.2401	.2865	.2328
17	.2534	.2155	.2172	.2947	.2374	.2865	.3077
18	.2561		.2534	.3045	.2515	.2507	.3109
19	.4755	.543	.5068	.5068	.4973	.5731	.5175
20	.5121	.6089	.6154	.5853	.5373	.5373	.5914
21	.4435	.5373	.5792	.5121	.5249		.4805
22	.3326	.3361	.2534		.3361	.3224	.2987
23	.2587	.1886	.2507	.2218	.3511	.2507	.2054
24	.2401	.2587	.2454	.2835	.2012	.2149	.2149
Max	.5121	.6089	.6154	.5853	.5373	.5731	.5914
Min	.1753	.1791	.181	.2218	.2012	.1791	.1991
Avg	.3096	.3127	.3011	.3310	.3131	.2974	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 202 / 11 KV Devarde AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.5864	.6401	.6562	.0554	.056	.056
2	.0747	.5864	.6401	.6249	.0554	.056	.056
3	.0747	.5937	.6401	.6249	.0554	.056	.056
4	.0747	.6249	.6401	.6249	.0554	.056	.056
5	.0747	.6642	.7042	.7499	.0554	.056	.056
6	.0747	.7274	.8322	.9061	.0934	.0747	.0747
7	.0934	.9998	1.0883	1.0936	.1132	.112	.112
8	.112	1.2811	1.3923	1.2811	.0924	.1307	.0934
9	.0747	1.2346	1.2003	1.2811	.0914	.0747	.0747
10	.0934	.056	.0747	.0543	.056	.0747	.0732
11	1.9753	.0747	.0747	.0724	2.0325	2.1247	2.0317
12	2.1296	.0934	.056	.0724	2.1925	2.2184	2.1862
13	2.2184	.0747	.056	.0724		2.3434	2.1862
14	2.1872	.0747	.0747	.0724	2.2565	2.3122	2.2405
15	2.037	.0747	.0747	.0724	2.4806	2.2497	2.1765
16	1.9753	.0747	.0747	.0543	2.3365	2.1872	2.0805
17	1.9136	.0747	.112	.0724	2.3365	1.9685	1.9364
18	1.4937		.0934	.0724	2.1605	2.3122	1.6004
19	.0747	.0934	.0934	.0732	.0934	.0934	.0732
20	.0934	.0934	.0934	.0914	.0934	.0934	.0732
21	.0924	.0747	.0934	.0739	.0934	.0934	.0739
22	.0739	.0747	.0747	.0739	.0747	.0747	.0747
23	.0739	.056	.0747	.0554	.0747	.056	.056
24	.0747	.6173	.6401	.6874	.0554	.056	.056
Max	2.2184	1.2811	1.3923	1.2811	2.4806	2.3434	2.2405
Min	.0739	.056	.056	.0543	.0554	.056	.056
Avg	.7181	.3872	.3974	.3964	.7393	.7888	.7314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 203 / KARVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4652	.0554	.0724	.0549	.2896	.3429	.2812
2	.4715	.0554	.0724	.0366	.2896	.3315	.2812
3	.4778	.0554	.0724	.0366	.2896	.3201	.2812
4	.6283	.0554	.0543	.0366	.2896	.3086	.3125
5	.6535	.0747	.0543	.0549	.3353	.3353	.4374
6	.5719	.112	.0362	.0914	.463	.5117	.4999
7	.7977	.112	.0549	.1463	.7655	.7773	.7499
8	.9602	.1509	.0537	.1463	1.0467	1.0822	.9686
9	.9031	.1132	.0537	.1097	.9374	1.0494	.9374
10	.0739	.1063	.0366	.1086	.0732	.0549	.0549
11	.0739	1.3123	1.0936	1.0936	.0914	.0914	.0549
12	.0739	1.3279	1.2811	.7499	.0678	.0732	.0549
13	.0739	1.3735	1.4685	1.2654	.0701	.0914	.0549
14	.0739	1.406	1.406	1.2498	.0663	.0914	.0914
15	.0747	1.4373	1.4373	1.2967	.0686	.0732	.0732
16	.0747	1.3435	1.406	1.3916	.0876	.0732	.0914
17	.112	1.3272	1.406	1.1248	.104	.1097	
18	.1109		1.1248	.4268	.12	.1097	.0924
19	.1109	.112	.1097	.1097	.1254	.1097	.1109
20	.1109	.0924	.1097	.1109	.1294	.1097	.1109
21	.112	.0924	.1097	.1109	.1097	.1097	.0924
22	.0747	.0914	.0914	.0924	.1086	.0914	.0934
23	.0747	.0724	.0549	.0924	.0895	.0914	.0934
24	.2921	.0554	.0905	.0549	.2896	.3544	.2812
Max	.9602	1.4373	1.4685	1.3916	1.0467	1.0822	.9686
Min	.0739	.0554	.0362	.0366	.0663	.0549	.0549
Avg	.3103	.4754	.4896	.4163	.2628	.2789	.2652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 204 / Ganesh Chikurde LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.181	.1991	.181	.1448	.1448
2	.1991	.181	.1991	.181	.1448	.1448
3	.1991	.181	.1991	.181	.1448	.1448
4	.1991	.181	.1991	.181	.1448	.1448
5	.2172	.1991	.2172	.181	.1448	.181
6	.2353	.1991	.2353	.2172	.2012	.1991
7	.2353	.2172	.2353	.2172	.2012	.181
8	.2353	.2172	.2353	.2172	.1991	.1991
9	.2353	.2172	.2353	.2172	.2172	.1991
10	.2353	.2353	.2172	.2149	.2353	.2012
11	.2353	.2353	.2172	.2172	.1991	.2012
12	.2172	.2353	.2172	.2172	.1991	.2012
13	.2172	.2172	.2172	.2172	.1991	.2012
14	.2172	.2172	.2172	.2149	.1991	.1829
15	.2172	.2172	.2172	.2149	.1991	.1829
16	.2172	.2353	.2172	.2149	.1991	.1829
Max	.2353	.2353	.2353	.2172	.2353	.2012
Min	.1991	.181	.1991	.181	.1448	.1448
Avg	.2195	.2104	.2172	.2053	.1858	.1808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 201 / 11 KV SURUL AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.0543	.0543	.0526	.1932	.208	.2675
2	.3201	.0543	.0543	.0526	.1932	.2107	.3311
3	.3201		.0362	.0526	.1932	.2107	.3612
4	.3201		.0732	.0526	.2559	.2896	.4268
5	.3841		.0914	.0701	.2932	.2896	.463
6	.4481		.0914	.0876	.3281	.4115	.4784
7	.8642		.0914	.0876	.68	.7186	.7907
8	1.0883		.1097	.1052	.8223	1.1069	1.1336
9	1.0883		.1109	.1052	.8905	1.0437	
10	.0895	.0469	.218	.1402	.1097	.0867	.0747
11	.0914	1.4083	1.2483	1.2967	.0753	.0747	.0876
12	.0716	1.6324	1.4083	1.0936	.0905	.0549	.0876
13	.0895	1.5971	1.4083	1.1717	.0895	.0633	.0876
14	.0867	1.6004	1.4883	1.1873	.0895	.0655	.0876
15	.1075	1.4998	1.4883	1.1717	.0549	.0671	.0876
16	.0895	1.4352	1.4403	1.2342	.0886	.1052	.0876
17	.1052		1.3443	1.078	.0914	.0867	.0876
18	.0905		1.1203	.823	.0678	.124	.1052
19	.1448	.1109	.0895	.128	.0914	.0924	.1097
20	.1097	.112	.0895	.1086	.0924	.0924	.1097
21	.0905	.1097	.0895	.1075	.0739	.0934	.1097
22	.0876	.0905	.0716	.0886	.0724		.0914
23	.0857		.0716	.0716	.0526		.0549
24	.3201	.0543		.0526	.1932	.2229	.2641
Max	1.0883	1.6324	1.4883	1.2967	.8905	1.1069	1.1336
Min	.0716	.0469	.0362	.0526	.0526	.0549	.0549
Avg	.2839	.7004	.5343	.4341	.2159	.2599	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 202 / 11 KV RETHRE DHARAN
GAOTHAN Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.132	.1307	.132	.1698	.1663
2	.132	.1509	.132	.1307	.132	.1509	.1478
3	.132		.1132	.1307	.132	.1509	.2218
4	.132		.2641	.1867	.1886	.1886	.2987
5	.2241		.3395	.2378	.3206	.2452	.3361
6	.3921		.3772	.3109	.3772	.3584	.3772
7	.3921		.4108	.3658	.4294	.4904	.4338
8	.3921		.4435	.4024	.4481	.4854	.4904
9	.3921		.3582	.4024	.4207	.4066	
10	.3721	.2507		.3292	.3012	.4207	.3721
11	.298	.333	.3506	.2865	.2572	.2686	.2629
12	.2957	.3511	.298	.2629	.2103	.2149	.2279
13	.3012	.2883	.298	.2427	.2347	.2401	.2279
14	.2279	.2686	.2629	.2454	.2454	.2401	.2279
15	.2126	.2686	.2629	.2481	.2481	.2401	.2279
16	.2303	.2427	.2279	.2172	.2254	.2401	.2279
17	.2658	.2204	.1928	.2534	.2126	.1715	.2454
18	.3045	.3113	.2629	.2686	.3086	.2629	.2804
19	.5359	.5415	.4024	.5228	.5359	.5415	.3734
20	.5228	.5415	.4755	.547	.5228	.5041	.5228
21	.4668	.4481	.4481	.4904	.4854	.4854	.4854
22	.3547	.3584	.3361	.3772	.3921		.3547
23	.2218		.1867	.2075	.2402		.1867
24	.1509	.168	.132	.1494	.1509	.1867	.1663
Max	.5359	.5415	.4755	.547	.5359	.5415	.5228
Min	.132	.1509	.1132	.1307	.132	.1509	.1478
Avg	.2959	.3059	.2916	.2894	.2980	.3029	.2983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 203 / 11 KV RETHRE DHARAN AG SEPARATED AG FEEDERS HAVING SPECIAL
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0987	.1448	.16	.0362	.0366	.0351
2	.0366	.0987	.1158	.128	.0362	.037	.0354
3	.0366		.1303	.128	.0366	.0373	.0362
4	.0366		.176	.128	.037	.0373	.0366
5	.0366		.2229	.16	.0373	.037	.037
6	.0366		.2526	.192	.0373	.037	.0373
7	.0366		.4214	.3201	.0366	.0366	.0373
8			.5487	.4481	.0362	.037	.0373
9	.0366		.5401	.4481	.037	.056	
10	.0829	.0343	.3641	.0358	.0678	.048	.0335
11	.6554	.0358	.0343	.0351	.6472	.6874	.4801
12	.6718	.037		.0351	.7407		.5921
13	.679	.0324		.0351	.7375	.6161	.5921
14	.679	.032		.0351	.7526	.6081	.5921
15	.7253				.6923	.5573	.5921
16	.6481	.0332	.0343	.0347	.6472	.4858	.5921
17	.5944	1.4022	.0343	.0526	.6249	.2881	.4801
18	.3913	.024	.0343	.0543	.5068	.2934	.4001
19	.0362	.0366	.0343	.0549	.0362	.0373	.0358
20	.037	.037	.0358	.037	.037	.0373	.0358
21	.0366	.037	.0358	.0366	.037	.037	.0358
22	.0362	.037	.0358	.0358	.0362		.0358
23	.0339		.0358	.0354	.0354	.0373	.0358
24	.0366	.096	.1448	.16	.0354	.0362	.0351
Max	.7253	1.4022	.5487	.4481	.7526	.6874	.5921
Min	.0339	.024	.0343	.0347	.0354	.0362	.0335
Avg	.2451	.1381	.1688	.1213	.2485	.1873	.2113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 403 / (Kurloop)Shirala

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
13	2.7435
24	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 405 / 33 KV Dindayal Sut Girani NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 406 / 33 KV Echo Board

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	4.9383
Max	4.9383
Min	4.9383
Avg	4.9383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 407 / 33 KV Kasegaon Feeder
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	3.8409
Max	3.8409
Min	3.8409
Avg	3.8409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 702 / 132 KV Peth Wategaon NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder Feeder KV- 132 / (CONTINUOUS PROCESS)(NO STAGGERING
OUTGOING

DATE	01-FEB-18
HR	Load (MW)
13	.5487
24	.5487
Max	.5487
Min	.5487
Avg	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 201 / 11 KV BIUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	1.8747	1.8027	1.8785	.0457	.0457	.0625
2	.0648	1.9845	1.8122	1.8785	.0457	.0457	.0617
3	.0648	2.0241	1.8435	1.8785	.061	.0457	.0633
4	.0648	2.0557	1.9292	1.9433	.061	.0457	.0617
5	.0648	2.0873	1.9925	2.0081	.061	.061	.0633
6	.0648	2.1445	2.0679	2.1376	.0625	.061	.0617
7	.081	1.012	2.4646	2.5911	.0914	.0762	.0625
8	.0972	1.0936	2.6246	2.7854	.0914	.0762	.0625
9	.0914	2.5621	2.7526	2.5965	.0762	.061	.0633
10		.0972	.0972	.0457	.0937	.081	.0937
11		.0914	.0781	.0914	3.2065	2.0081	1.9006
12	2.0309	.0937	.0648	.0914	3.2712	1.9685	2.0081
13	3.0445	.061	.0648	.0762	2.0309	2.0645	1.9372
14	2.9683	.0762	.0819	.0762	1.4899	1.9372	1.8122
15	3.2712	.0762	.0625	.0762	2.0622	1.8435	1.7185
16	1.4091	.1067	.0972	.0762	2.17	1.2955	1.6248
17	3.0769	.0983	.0781	.0914	2.0081	1.7166	1.6842
18	2.6882	.1265	.0972	.0914	1.6766	1.5813	1.5223
19	.0937	.0949	.0972	.0781	.0625	.0625	.0324
20	.0625	.0625	.0972	.0914	.061	.0625	.0486
21	.0937	.0937	.0972	.0914	.0762	.0937	.0486
22	.096	.0937	.1006	.0914	.061	.0633	.0486
23	.0949	.0949	.0648	.061	.061	.0617	.0324
24	.0648	1.8884	1.7711	1.8138	.061	.0457	.0625
Max	3.2712	2.5621	2.7526	2.7854	3.2712	2.0645	2.0081
Min	.0625	.061	.0625	.0457	.0457	.0457	.0324
Avg	.8933	.8331	.9267	.9434	.7912	.6418	.6307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 202 / 11 KV SHIRALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.2214	.2881	.2591	.0305	.0305	.0316
2	.0324	.2241	.2812	.2591	.0305	.0305	.0316
3	.0324	.216	.253	.2591	.0305	.0305	.032
4	.0324	.2561	.253	.2591	.0305	.0305	.0316
5	.0324	.253	.2846	.2915	.0305	.0305	.0316
6	.0324	.2469	.3201	.3239	.0305	.0305	.0309
7	.0324	.3395	.3795	.3887	.0305	.0305	.0309
8	.0324	.3163	.3125	.421	.0305	.0305	.0309
9	.0305	.4161	.4744	.3963	.0305	.0305	.0312
10	.0305	.0305	.0305	.0305	.0312	.0305	.0312
11	.5487	.0305	.0297	.0305	.3048	.4999	.5624
12	.5182	.0297	.0305	.0305	.4572	.4999	.5312
13	.5182	.0305	.0305	.0305	.4877	.5312	.5487
14	.5182	.0305	.0305	.0305	.5182	.4572	.4877
15	.5182	.0305	.0305	.0305	.5624	.5182	.3048
16	.5182	.0305	.0305	.0305	.5937	.5312	.4999
17	.4877	.0305	.0297	.0305	.5624	.4687	.4999
18	.463	.0312	.0324	.0305	.4725	.4428	.4858
19	.0309	.032	.0324	.0305	.0305	.032	.0324
20	.0316	.0312	.0324	.0305	.0305	.032	.0324
21	.0312	.0312	.0362	.0305	.0305	.032	.0324
22	.0309	.032	.0324	.0305	.0305	.032	.0324
23	.032	.032	.0362	.0305	.0305	.0309	.0324
24	.0324	.2187	.2778	.2915	.0305	.0305	.032
Max	.5487	.4161	.4744	.421	.5937	.5312	.5624
Min	.0305	.0297	.0297	.0305	.0305	.0305	.0309
Avg	.1917	.1309	.1487	.1490	.1853	.1851	.1845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 203 / 11 KV NATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.0316	.0633	.0324	.3906	.4374	.4744
2	.2591	.0316	.0309	.0324	.3749	.4268	.463
3	.2591	.0617	.0617	.0324	.3658	.4687	.506
4	.2915	.0633	.0633	.0324	.3963	.5312	.4999
5	.3239	.0625	.0625	.0648	.442	.578	.5312
6	.3239	.0633	.0633	.0648	.4877	.6249	.5376
7	.421	.0625	.0617	.0648	.5792	.6562	.679
8	.583	.0617	.0617	.0648	.5944	.6706	.6874
9	.5182	.0633	.0625	.061	.6706	.7011	.7907
10	.0625	.0625	.0937	.061	.0655	.0625	.0648
11	.061		.9686	.9602	.0648	.0457	.0648
12	.061	.9069	1.1336	.9907	.081	.0457	.0469
13	.0781	1.0059	1.166	.9907	.061	.061	.0469
14	.0625	1.0059	1.1012	.9907	.061	.0469	.0625
15	.0625	1.0669	1.0688	.9755	.0648		.0625
16	.0625	1.1142	.852	.9755	.0625		.0625
17	.061	.9503	.9069	.945	.0648		.081
18	.0625	.8333	.8421	.7773	.061	.0617	.0648
19	.064	.0926	.0972	.0762	.0762	.0937	.0648
20	.0617	.0617	.081	.061	.0762	.0625	.0486
21	.0633	.064	.081	.061	.0762	.0791	.0486
22	.0633	.0633	.0486	.0762	.061	.0625	.0486
23	.0625	.0633	.0324	.0762	.0457	.0633	.0324
24	.2915	.0316	.0633	.0324	.3963	.3963	.4428
Max	.583	1.1142	1.166	.9907	.6706	.7011	.7907
Min	.061	.0316	.0309	.0324	.0457	.0457	.0324
Avg	.1841	.3402	.3778	.3541	.2341	.2941	.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 204 / 11 KV KAPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7449	.6009	.6908	.6326	.8947	.8947	.7906
2	.7449	.6298	.7309	.6326	.8947	.9267	.8123
3	.7449	.6695	.6481	.6326	.8947	.948	.8135
4	.3563	.658	.6882	.6649	.9267	.9267	.8436
5	.4211	.6851	.6824	.7277	.9587	.9587	.8653
6	.4534	.6542	.7407	.7906	1.0227	1.0227	.9492
7	.5182	.9088	.9602	.9488	1.2628	1.3588	1.2646
8	.6478	.9725	.9725	1.0441	1.3108	1.4388	1.296
9	.6459	1.0021	1.1192	1.0364	1.4388	1.4228	1.4198
10	.2248	.2271	.1943	.2065	.1924	.2599	.1623
11	1.2289	1.9311	1.6682	1.7909	.7636	1.1553	1.3161
12	1.0753	1.9967	1.9414	1.7429	1.0402	1.1553	1.1866
13	1.1984	1.9639	1.8	1.7429	1.1759	1.2521	1.2289
14	1.2064	1.9967	1.8119	1.7109	1.1984	1.1126	1.1439
15	1.1984	1.9738	1.8328	1.6949	1.2612	1.2307	.7582
16	1.2391	1.9639	1.7543	1.6309	1.3386	1.2307	1.1431
17	1.2002	1.8656	1.7471	1.5707	1.2833	1.0624	1.1801
18	.719	1.5939	1.2955	1.3908	1.1126	1.099	1.1012
19	.2187	.2232	.2591	.2866	.2791	.2476	.2001
20	.2168	.221	.2591	.2546	.2546	.2187	.2267
21	.2168	.2184	.2591	.2225	.2225	.0316	.2267
22	.1581	.1581	.1943	.1905	.2065	.1901	.1943
23	.1551	.1577	.1943	.1585	.1745	.1871	.162
24	.7449	.6276	.6874	.7125	.9267	.8627	.7495
Max	1.2391	1.9967	1.9414	1.7909	1.4388	1.4388	1.4198
Min	.1551	.1577	.1943	.1585	.1745	.0316	.162
Avg	.6783	.9958	.9638	.9340	.8764	.8831	.8348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 206 / 11 KV BIUR GAOTAHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1494	.2195	.181	.2218	.2218	.2195
2	.181	.1867	.2587	.181	.2218	.2195	.2218
3	.181	.1848	.2587	.181	.2218	.2218	.2587
4	.181	.1867	.2561	.181	.2241	.2378	.2614
5	.2172	.2614	.2987	.2172	.2587	.2587	.2926
6	.2896	.3696	.2987	.2896	.3142	.2957	.3326
7	.3258	.4024	.3326	.362	.462	.4066	.4108
8	.362	.3658	.3696	.3982	.3881	.3921	.3841
9	.3292	.3361	.2926	.3696	.3696	.4251	.2812
10	.3326	.3696	.3292	.3696	.3361	.3696	.3326
11	.3292	.3326	.3326	.3326	.2926	.2926	.2587
12	.2587	.2587	.2561	.2587	.2218	.1478	.2241
13	.2195	.2195	.3361	.2218	.2195	.2218	.2218
14	.2218	.1829	.2218	.2218	.2587	.1638	.2195
15	.2587	.1478	.2195	.2218	.2561	.1463	.2587
16	.2561	.1848	.2587	.2772	.2926	.1109	.1494
17	.2957	.2561	.2195	.2772	.2195	.1848	.2561
18	.2957	.2926	.3258	.3921	.2957	.4024	.2172
19	.4755	.439	.4706	.499	.462	.439	.3258
20	.439	.439	.4706	.4805	.4805	.4024	.4344
21	.4108	.4108	.4344	.4066	.499	.4755	.362
22	.3292	.3326	.362	.3511	.4066	.2561	.2534
23	.1829	.1848	.2896	.2587	.2957	.2195	.2534
24	.181	.1463	.2241	.2172	.2218	.2218	.2218
Max	.4755	.439	.4706	.499	.499	.4755	.4344
Min	.181	.1463	.2195	.181	.2195	.1109	.1494
Avg	.2806	.2767	.3057	.2978	.3100	.2806	.2772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 208 / 11 KV SHIRALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4435	.3658	.4344		.4668	.4481
2	.362	.439	.5175	.4344		.4668	.439
3	.362	.5175	.5175	.4344	.4805	.4668	.5228
4	.5068	.5228	.5121	.4344	.5175	.5228	.5175
5	.5792	.5975	.3696	.5068	.6161	.7095	.5914
6	.6516	.7392	.5228	.6516	.7282	.7392	.7316
7	.7964	.8962	.8048	.7964	.924	.8589	.8871
8	.7964	.8962	.8962	.8688	.9149	.8215	.8131
9	.6653	.8131	.7392	.8215	.8215	.8589	.8131
10	.2926	.6653	.8131	.8215	.7392	.6653	.7392
11	.7316	.6653	.7392	.7095	.6653	.6653	.5898
12	.7316	.6584	.7392	.6722	.6653	.5175	.6653
13	.5853	.5914	.6653	.6161	.5853	.6653	.5914
14	.6653	.5853	.5853	.5601	.6584	.5544	.5914
15	.5853	.5914	.5853	.5601	.6584	.5914	.6722
16	.6653	.5914	.5914	.6348	.5914	.5975	.5914
17	.5914	.5914	.5975	.6283	.6653	.5914	.6653
18	.7392	.6653	.724	.7282	.7023	.5975	.724
19	.8131	.8316	.7964	.8775	.9709	.7392	.7964
20	.8871	.8871	.8688	.8589	.961	.7392	.8688
21	.7468	.6653	.7964	.7762	.8131	.8215	.724
22	.5914	.5975	.6516	.6838	.7468	.5975	.5792
23	.5228	.4435	.5068	.5601	.5359	.5175	.4344
24	.362	.4435	.3696	.4344	.5228	.4805	.3734
Max	.8871	.8962	.8962	.8775	.9709	.8589	.8871
Min	.2926	.439	.3658	.4344	.4805	.4668	.3734
Avg	.6080	.6391	.6365	.6460	.7038	.6355	.6404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 209 / 11 KV KAPARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1829	.3292	.1448	.1848	.2218	.1097
2	.1448	.1494	.2957	.1448	.1829	.2218	.1109
3	.1448	.1494	.2587	.1448	.1848	.2218	.1478
4	.1448	.1097	.2195	.1448	.1646	.2195	.1494
5	.1448	.112	.1848	.181	.1663	.2218	.1463
6	.181	.1097	.1463	.2172	.1294	.2195	.1848
7	.181	.2241	.1867	.2172	.2012	.2957	.1829
8	.181	.1463	.1494	.2218	.1848	.2587	.2561
9	.1478	.1829	.2241	.1848	.2772	.1478	.1463
10	.2926	.3326	.2218	.1646	.4435	.1109	.2218
11	.2561	.3696	.2957	.1463	.2957	.2195	.2561
12	.2587	.3658	.2561	.1294	.4024	.2587	.2587
13	.1463	.3658	.1463	.0934	.3292	.2195	.2218
14	.1829	.3292	.1848	.1109		.1848	.2561
15	.2561	.3658	.1829	.1109	.1848	.2218	.2614
16	.2195	.3292	.2587	.1478	.3696	.2614	.2218
17	.2587	.2926	.2561	.1463	.2926	.2195	.3361
18	.7468	.1848	.2172	.1478	.2195	.1848	.181
19	.1494	.2195	.2172	.1463	.2033	.1867	.181
20	.1829	.2241	.2172	.1848	.2012	.1867	.181
21	.2561	.1829	.181	.2195	.1829	.1848	.1448
22	.2926	.2561	.181	.2218	.2378	.1109	.1086
23	.2218	.1829	.1448	.1848	.2402	.1097	.1086
24	.2172	.2241	.3658	.181	.1867	.2195	.1109
Max	.7468	.3696	.3658	.2218	.4435	.2957	.3361
Min	.1448	.1097	.1448	.0934	.1294	.1097	.1086
Avg	.2245	.2330	.2217	.1640	.2376	.2045	.1868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 401 / 33 KV GLUCOSE EXPRESS

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.6882	.5407	.5144	.5967	.639	
2	.2572	.6464	.5967	.5144	.5898	.6962	
3	.2572	.5967	.6036	.5144	.5898	.6464	
4	.3086	.547	.6962	.5144	.7865	.5898	
5	.3086	.4915	.7042	.6173	.6962	.5898	
6	.3601	.4424	.7956	.6687	.6882	.4475	
7	.6173	.8048	.6882	.6687	.7373	.4424	
8	.3086	.547	.6962	.6687	.7373	.5967	
9	.4218	.7459	.7545	.6722	.5898	.7459	
10	.3441	.8356	.7373	.8356	.7762	.5407	
11	.3281	.6316	.6882	.7865	.6316	.3932	
12	.639	.639	.4915	.3932	.5407	.7373	
13	.6316	.8259	.8848	.6464	.583		
14	.583	.7865	.8259	.6464	.583		
15	.4858	.8745	.6316	.639	.5407		
16	.4372	.7968	.5344	.6464	.6093		
17	.6882	.8436	.6802	.639	.7373		
18	.8048	.6036	.7202	.639	.5898		.7716
19	.7865	.6962	.6687	.7373	.7373		.823
20	.7956	.7956	.7059	.6882	.7865		.823
21	.3978	.7459	.6687	.6882	.3441		.7716
22	.6962	.547	2.2634	.547	.4915		.7202
23	.6464	.5967	.7202		.7373		.6173
24	.3086	.7042	.547	.6173	.5898	.6882	
Max	.8048	.8745	2.2634	.8356	.7865	.7459	.823
Min	.2572	.4424	.4915	.3932	.3441	.3932	.6173
Avg	.4862	.6847	.7435	.6306	.6371	.5964	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 402 / 33 KV RETHARE DHARAN

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.2812	.3281	.4344	.3441	.3932	.4687
2	.543	.2778	.3704	.4344	.3441	.3932	.5556
3	.543		.4744	.4344	.3441	.3932	.6167
4	.6516		.463	.4344	.4915	.4973	.6562
5	.7602		.5624	.543	.5967	.639	.703
6	.8145		.5693	.543	.6882	.7956	.759
7	1.4118		.9014	.7602	1.0322	1.1934	1.0185
8	1.8461		1.0185	1.0317	1.278	1.4918	1.4352
9	1.5947		.8905	.8356	1.442	1.5729	1.3889
10	.7499	.7865	.4858	.4424	.3441	.4424	.3441
11	.9842	1.5729	1.6712	1.3272	.9831	.8745	.8356
12	1.0682	1.8679	1.7004	1.3272	1.0322	.8745	.7968
13	1.0814	1.749	1.5466	1.3272	.9717	1.0322	.8848
14	.9831	1.7695	1.6032	1.3272	1.0322	1.0288	.7865
15	1.0814	1.749	1.6032	1.3272	.9339	1.0288	.7716
16	.9339	1.6221	1.6032	1.278	.9339	.8356	.8139
17	.9448	1.4998	1.4255	1.278	.9665	.4915	.7373
18	.703	1.2963	1.7375	1.094	.8848	.2812	.7602
19	.5093	.5155	.5973	.5407	.547	.5155	.7602
20	.5093	.5155	.543	.5967	.5407	.4687	.5973
21	.5218	.4687	.4344	.4915	.4915	.4687	.4887
22	.3281	.3281	.3258	.4475	.4424	.3749	.3801
23	.2343	.2343	.2715	.3481	.2984	.2343	.2715
24	.4344	.2812	.2812	.2715	.2458	.3441	.427
Max	1.8461	1.8679	1.7375	1.3272	1.442	1.5729	1.4352
Min	.2343	.2343	.2715	.2715	.2458	.2343	.2715
Avg	.8240	.9891	.8920	.7865	.7170	.6944	.7191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 201 / 11 KV CHARAN AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0514	.0514			
2		.0171	.0514	.0514			
3		.0171	.0514	.0514			
4		.0343	.0514	.0514			
5		.0514	.0686	.0514			
6		.0514	.0857	.0857			
7		.12	.1029	.1029			
8		.1372	.1543	.12			
9		.12	.0857	.0686			
11	.2401				.2743	.2229	.2401
12	.2401				.2743	.2401	.2229
13	.2743				.2572	.0857	.2401
14	.2572				.2743	.2401	
15	.2401				.2401	.2401	
16	.2743				.2401	.2229	.2229
17	.2229				.1715	.2229	.2401
18	.1372				.1715	.1543	.1372
24		.0171	.0514	.0343			
Max	.2743	.1372	.1543	.12	.2743	.2401	.2401
Min	.1372	.0171	.0514	.0343	.1715	.0857	.1372
Avg	.2358	.0583	.0754	.0669	.2379	.2036	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 202 / 11 KV MANDOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.1715	.2058	.2058	.2058	.1886
2	.2058	.1715	.1715	.1715	.2058	.1715	.1715
3	.2058	.1715	.1715	.1715	.2058	.1715	.1715
4	.2058	.2743	.1715	.2058	.2058	.1715	.1715
5	.2401	.2743	.2743	.2401	.2401	.2401	.2401
6	.2915	.3429	.3429	.2743	.3086	.3429	.3258
7	.463	.4801	.4287	.4801	.463	.463	.4458
8	.5316	.5316	.5316	.5144	.5144	.5144	.5316
9	.4801	.4973	.4801	.4801	.5316	.4801	.4973
10	.463	.4801	.3601	.463	.5144	.3086	.5316
11	.3944	.3944	.3601	.4458	.463	.2743	.4115
12	.2743	.4287	.4115	.3601	.463	.2572	.3601
13	.3258	.3772	.3772	.3429	.3944	.2401	.3772
14	.3258	.3601	.3429	.3258	.3772	.1886	
15	.9088	.2743	.3601	.3258	.3429	.1886	
16	.3429	.3601	.3772		.3258	.3772	.4115
17	.4801	.3944	.4287	.3944	.4115	.3772	.4458
18	.5144	.5316	.4973	.6001	.4115	.4458	.5487
19	.6687	.6344	.6516	.7545	.6516	.6516	.6687
20	.6687	.6344		.6687	.6516	.6001	.6516
21	.6173	.5487	.5487	.583	.583	.5487	.5316
22	.4115	.4115	.4115	.463	.3772	.4287	.4115
23	.2743	.2743	.2915	.3086	.3086	.2915	.3258
24	.2058	.2229	.1886	.2401	.2401	.2401	.2229
Max	.9088	.6344	.6516	.7545	.6516	.6516	.6687
Min	.2058	.1715	.1715	.1715	.2058	.1715	.1715
Avg	.4044	.3865	.3631	.3921	.3915	.3408	.3928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 203 / 11 KV CHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1372	.1543	.1372	.1543	.1543
2	.1372	.1372	.1372	.1372	.1372	.1372	.1372
3	.1372	.1372	.1372	.1372	.1372	.1372	.1372
4	.1372	.1372	.1372	.1372	.1372	.1372	.1372
5	.1543	.1715	.1715	.1715	.1715	.1886	.1715
6	.2401	.2229	.2401	.2229	.2572	.2229	.2401
7	.4287	.4115	.3772	.3772	.3772	.4287	.4115
8	.5316	.5316	.4973	.5144	.5316	.4801	.4973
9	.5144	.463	.4973	.463	.4973	.4801	.4973
10	.4458	.3944	.4115	.4115	.4115	.4458	.3772
11	.4115	.3772	.3944	.4458	.3429	.3601	.3429
12	.3772	.8573	.3429	.2229	.3601	.3601	.3086
13	.3601	.3258	.4115	.2229	.2743	.3086	.3429
14	.3258	.2401	.3086	.3429	.2743	.2229	
15	.2743	.2401	.2058	.3429	.2743	.2401	
16	.3086	.2743	.2915	.3944	.2572	.2743	.3601
17	.3601	.3086	.3086	.3601	.3086	.3086	.3772
18	.4458	.3772	.3772	.3429	.3429	.3772	.4801
19	.6173	.5144	.583	.5316	.5487	.5144	.6859
20	.583	.5658	.6173	.5487	.5487	.5144	.5658
21	.5144	.463	.4801	.4458	.4801	.463	.4973
22	.3944	.3772	.3772	.3601	.3429	.3772	.3772
23	.2401	.2401	.2401	.2572	.2229	.2401	.2401
24	.1715	.1715	.1543	.1715	.1715	.1715	.1715
Max	.6173	.8573	.6173	.5487	.5487	.5144	.6859
Min	.1372	.1372	.1372	.1372	.1372	.1372	.1372
Avg	.3437	.3372	.3265	.3215	.3144	.3144	.3414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 204 / 11 KV MANDOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.5144	.4458	.3429			
2	.0171	.5144	.4287	.3772			
3	.0171	.5144	.4458	.3772			
4	.0171	.4801	.4458	.3772			
5	.0171	.5144	.463	.3944			
6	.0171	.6001	.4973	.4115			
7	.0171	.6687	.5658	.583			
8	.0171	.7545	.7202	.703	.0171		
9	.0171	.7202	.6344	.703	.0171		
10	.0171	.0343	.0171	.0171	.0171		
11	1.0117	.0343	.0171	.0171	1.0974	1.0631	.8573
12	1.046	.0343	.0171	.0171	1.2346	1.0974	.2915
13	1.046	.0343	.0171	.0171	1.2689	1.1317	.2915
14	.8916	.0343	.0171	.0171	1.2689	1.166	
15	1.0288	.0343	.0171	.0171	1.2346	1.0974	
16	1.0802	.0343	.0171	.0171	1.1831	1.0974	1.0117
17	.9602	.0343	.0171	.0171	.8916	1.0631	1.0288
18		.0343	.0171	.0171	.7716	.9945	.9088
19	.0171	.0171		.0171	.0171		
20	.0171	.0171		.0171	.0171	.0171	
21	.0171	.0171		.0171	.0171		
22	.0171	.0171		.0171	.0171		
23	.0171	.0171		.0171			
24	.0171	.4973	.4458	.3258			
Max	1.0802	.7545	.7202	.703	1.2689	1.166	1.0288
Min	.0171	.0171	.0171	.0171	.0171	.0171	.2915
Avg	.3190	.2572	.2761	.2014	.6047	.9697	.7316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 401 / 33 KV WARNAWATI

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0874	.0823	.0874	.2572	.2212	.2521	.2726
2	.0926	.0823	.0977	.2521	.2366	.2469	.2623
3	.0926	.0823	.2212	.2469	.2469	.2469	.2675
4	.0926	.0823	.2469	.2469	.2469	.2469	.2572
5	.0926	.0874	.2623	.2212	.2469	.2469	.2675
6	.0926	.0926	.2675	.1543	.2469	.2521	.2572
7	.0926	.0977	.2675	.2315	.2315	.2572	.2521
8	.0874	.0926	.2469	.2366	.2263	.2521	.2675
9	.0926	.0977	.2006	.2418	.2315	.3189	.0772
10	.0772	.0772	.2006	.2418		.2623	.072
11	.0874	.0874	.2058	.1955	.0823	.2881	.072
12	.0823	.0926	.2058	.1955	.2263	.2623	.0823
13	.0926	.0874	.216	.1337	.2263	.2572	.0669
14	.0823	.2984	.0669	.2984	.1337	.2109	.0772
15	.0772	.3035	.2726	.2675	.0926	.2778	.072
16	.072	.2984	.2675	.2418	.0257	.2572	.2623
17	.0772	.2932	.2469	.2778	.0257	.2521	.2778
18	.0823	.0874	.0566	.2521	.2572	.2829	.2881
19	.0823	.1595	.2572	.2263	.2572	.2572	.2623
20	.0823	.2521	.2572	.2315	.2521	.2726	.2675
21	.0874	.0977	.2521	.2263	.2366	.2726	.2572
22	.0823	.0977	.2469	.2212	.2623	.2469	.2572
23	.0823	.0977	.2572	.2263	.2521	.2572	.2572
24	.0874	.0823	.0823	.2623	.2212	.2572	.2675
Max	.0926	.3035	.2726	.2984	.2623	.3189	.2881
Min	.072	.0772	.0566	.1337	.0257	.2109	.0669
Avg	.0857	.1337	.2079	.2328	.2037	.2598	.2092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 201 / 11 KV KANDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.7625	.6554	.7287	.032	.0332	.0312
2	.0324	.7625	.6554	.7287	.032	.0343	.0312
3	.032	.7625	.6554	.7287	.0324	.0332	.0312
4	.032	.8139	.6554	.7287	.0324	.0332	.0312
5	.0324	.8288	.6882	.7773	.0328	.0332	.0312
6	.0324	.8619	.7537	.8259	.0328	.0332	.0312
7	.0328	1.0898	1.1142	.9995	.0347	.0332	.0324
8	.0324	1.21	1.1469	1.2289	.0324	.0332	.0305
9	1.6409	1.2125	1.0159	1.0898	1.8233	1.8896	1.6244
10	1.7404	.0343	.0305		1.9559	1.9559	1.6385
11	1.873	.0343	.0305	.0339	1.9062	1.989	1.8023
12	1.7901	.0343	.0332	.0328	1.8233	1.8896	1.8023
13	1.7295	.0343	.0343	.0328	1.9227	1.8564	1.8023
14	1.6975	.0343	.0343	.0332	1.917	1.8564	1.6385
15	1.6933	.0343		.0324	1.8233	1.6741	1.5074
16	1.6448	.0343		.0328	1.8233	1.5912	1.4091
17	.0343	.0343		.032	.0332	.0332	.0343
18	.0339	.0343	.0343	.0328	.0332	.0343	.0343
19	.0332	.0343	.0343	.0335	.0332	.0312	.0343
20	.0332	.0343	.0343	.0335	.0343	.0324	.0343
21	.0332	.0343	.0343	.0328	.0343	.0324	.0343
22	.0339	.0343	.0343	.032	.0332	.0324	.0343
23	.0332	.0343	.0343	.0316	.0332	.0324	.0343
24	.0324	.7625	.6554	.6964	.0316	.0332	.0343
Max	1.873	1.2125	1.1469	1.2289	1.9559	1.989	1.8023
Min	.032	.0343	.0305	.0316	.0316	.0312	.0305
Avg	.5973	.3978	.3983	.3895	.6468	.6346	.5729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 202 / 11 KV NATOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.4475	.4268	.4287	.0328	.0339	.0343
2	.0328	.4475	.4268	.4287	.0332	.0332	.0343
3	.0328	.4475	.4268	.4287	.0332	.0332	.0343
4	.0332	.4641	.4268	.4287	.0335	.0332	.0343
5	.0335	.5138	.4572	.4287	.0335	.0332	.0343
6	.0339	.5304	.4999	.4287	.0339	.0328	.0362
7	.0347	.6882	.7621	.6401	.0362	.0332	.0362
8	.0362	.8288	.823	.7621	.0366	.0332	.037
9	.0332	.7209	.7621	.5937	.0332	.0339	.0343
10		.0343	.0332	.032	.0332	.0328	.0343
11	.0332	.0343	.0332	.0343	.0343	.0328	.0343
12	1.442	.0343	.0335	.032	1.5746	1.4586	1.2498
13	1.5565	.0343	.0343	.032	1.6766	1.5581	1.3717
14	1.56	.0343	.0343	.032	1.6741	1.5912	1.3717
15	1.5746	.0343	.0343	.0324	1.6741	1.5249	1.3717
16	1.4091	.0343	.0343	.0328	1.6409	1.5746	1.3108
17	1.3592	.0343	.0343	.0312	1.5912	1.4899	1.2193
18	1.2574	.0343	.0343	.0312	1.3923	1.1498	.9145
19	.8453	.0343	.0343	.0343	1.1105	.8745	.6874
20	.0328	.0343	.0343	.0339	.0332	.0343	.0343
21	.0332	.0343	.0343	.0332	.0332	.0343	.0343
22	.0332	.0343	.0343	.0324	.0332	.0343	.0343
23	.0332	.0857	.0343	.0328	.0332	.0343	.0343
24		.4475	.3963	.4344	.0328	.0332	.0343
Max	1.5746	.8288	.823	.7621	1.6766	1.5912	1.3717
Min	.0324	.0343	.0332	.0312	.0328	.0328	.0343
Avg	.5215	.2528	.2452	.2275	.5364	.4899	.4188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 204 / 11 KV KANDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1357	.1463	.1307	.1478	.1326	.112
2	.112	.1357	.1463	.1307	.1478	.1017	.112
3	.1132	.0995	.1463	.1307	.1494	.0995	.112
4	.1132	.0995	.1463	.1307	.1494	.1017	.112
5	.1132	.1357	.1463	.1494	.1494	.1326	.1494
6	.1509	.1989	.1829	.1867	.1867	.1658	.1886
7	.2075	.1989	.2195	.2641	.2263	.1989	.2241
8	.1829	.1989	.2195	.2614	.2218	.1989	.2241
9	.1696	.1829	.1829	.1829	.1696	.2035	.2172
10	.1658	.1463	.181		.1696	.1791	.1829
11	.1658	.1463	.181	.1772	.1326	.1402	.1463
12	.1696	.1463	.1417	.1402	.1326	.1254	.1463
13	.1357	.1463	.1433	.1772	.0995	.1433	.1829
14	.1357	.0343	.1433	.2507	.1311	.1433	.2195
15	.1357	.0343		.2481	.1326	.1402	.2195
16	.1357	.0343		.2481	.1326	.1402	.2195
17	.1696	.1715		.1341	.1326	.1578	.1829
18	.1989	.2195	.2103	.2012	.2035	.1928	.2195
19	.2321	.2561	.3258	.2534	.2321	.2926	.2926
20	.2294	.2561	.2715	.2195	.2321	.2587	.2743
21	.1989	.2195	.2378	.1829	.1989	.2587	.3704
22	.1638	.1829	.2054	.1848	.1715	.2218	.4253
23	.1658	.1463	.1867	.1867	.1326	.1848	.3186
24	.1494	.1658	.1463	.1463	.1478	.0995	.1478
Max	.2321	.2561	.3258	.2641	.2321	.2926	.4253
Min	.112	.0343	.1417	.1307	.0995	.0995	.112
Avg	.1594	.1538	.1862	.1877	.1637	.1672	.2083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 205 / 11 KV NATOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0995	.0543	.0554	.0358	.0995	.0732
2	.0362	.0663	.0543	.0554	.0358	.0663	.0739
3	.0362	.0663	.0543	.0554	.0366	.0663	.0739
4	.037	.0678	.0543	.1109	.0366	.0663	.0739
5	.037	.0663	.0724	.0554	.0747	.0663	.0739
6	.0739	.0995	.1086	.0924	.112	.0995	.112
7	.1463	.0995	.1448	.112	.1478	.1341	.112
8	.1387	.1357	.1448	.1463	.1448	.1357	.1478
9	.1326	.1417	.1448	.1075	.0995	.1326	.1448
10	.1326	.1037	.1052		.0995	.1029	.1402
11	.1357	.1063	.1029	.1029	.1017	.0497	.1402
12	.0983	.1063	.1147	.0926	.1017	.0358	.1402
13	.1017	.1086	.1029	.096	.0995	.0343	.1267
14	.0995	.1086	.1029	.0671	.0995	.0514	.124
15	.0995	.1086	.1029	.1006	.0995	.0343	.124
16	.0995	.1029	.1029	.0655	.0995	.0343	.1448
17	.1326	.124	.1457	.0995	.0995	.0343	.1448
18	.1326	.1417	.1326	.0995	.1326	.1372	.181
19	.1638	.2195	.2172	.1612	.1658	.1928	.2172
20	.1989	.1991	.2012	.1829	.1989	.2126	.2172
21	.1311	.1991	.1646	.1448	.1658	.1991	.181
22	.1017	.1267	.128	.1097	.1326	.1646	.1448
23	.0995	.0905	.0914	.0709	.0995	.128	.1086
24	.0358	.1017	.0543	.0526	.0351	.0995	.0914
Max	.1989	.2195	.2172	.1829	.1989	.2126	.2172
Min	.0358	.0663	.0543	.0526	.0351	.0343	.0732
Avg	.1015	.1162	.1126	.0972	.1023	.0991	.1296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 401 / 33 KV JYOTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4973	.503	.503		.2515
2		.4973	.503	.5533	.4915	.2515
3		.4973	.503	.5533	.4973	.503
4		.4973	.503	.5533	.4973	.503
5		.4973	.503	.5533	.4915	.503
6	.1063	.4973	.503	.5533	.4915	.503
7	.2572	.4973	.503	.503	.503	.503
8	.2572	.4973	.503	.5533	.503	.503
9	.2486	.503	.503	.5087	.4973	.503
10	.2486	.503	.503	.5087	.4973	.503
11	.2486	.503	.503	.5087	.4973	.503
12	.2458	1.4084	.5658	.503	.4973	.503
13	.2486	.503	.5658	.503	.4973	.503
14	.0995	.503	.5658	.503	.4973	.503
15	.2486	.503	.5658	.4973	.4973	.503
16	.547	.2515	.503	.4973	.4973	.503
Max	.547	1.4084	.5658	.5533	.503	.503
Min	.0995	.2515	.503	.4973	.4915	.2515
Avg	.2505	.5410	.5187	.5222	.4969	.4716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 201 / 11 KV WAKURDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963	.0312	.0324	.0312	1.0442	.703	
2	.3963	.0312	.0328	.0312	1.0442	.7209	.9614
3	.3963	.0312	.0309	.0316	1.0442	.6882	.9614
4	.3963	.0316	.0305	.0305	1.0562	.7701	.9614
5	.4321	.0316	.0663	.0305	1.0898	.7407	1.326
6	.4784	.032	.0617	.0305	1.2039	.9259	1.326
7	.6562	.0648	.0625	.0625	1.4754	1.0608	1.6278
8	.7432	.0648	.061	.0625	1.5927	1.0494	1.8313
9	.7042	.061	.0633	.0648	1.576	.9755	1.757
10	.0648	.061	.061	.1054	.0648	.032	.0686
11	.0648	1.9845	2.2721	1.6933	.0625	.0312	.0823
12	.0625	1.9753	1.9989	2.1195		.032	.0754
13	.061	2.1125	2.4587	2.0287		.032	.072
14	.0305	2.1506	2.2131	2.0287		.0343	.0709
15	.061	1.89	2.079	1.9227		.0171	.0572
16	.0305	1.8442	1.9448	1.9951	.0663		.0827
17	.061	1.387	1.9616	1.6549	.0633		.088
18	.061	1.1218	1.6842	1.5893	.0617	.0343	
19	.0625	.0686	.061	.0869	.0663	.0553	.0312
20	.0633	.064	.0625	.0823	.0926	.0553	.016
21	.0791	.0914	.061	.08	.061	.0373	.0152
22	.0633	.0617	.061	.0777	.0633	.0373	.016
23	.061	.0633	.0594	.0373	.0332	.0312	.016
24	.3963	.0305	.0312	.061	1.0277	.6958	.9614
Max	.7432	2.1506	2.4587	2.1195	1.5927	1.0608	1.8313
Min	.0305	.0305	.0305	.0305	.0332	.0171	.0152
Avg	.2426	.6369	.7271	.6641	.6395	.3982	.5639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 202 / 11 KV TAKAVE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.8697	.9709	.8539	.0867	.0655	.0335
2	.0671	.8802	.8745	.8539	.0867	.0663	.0335
3	.0671	.8642	.9012	.8482	.0867	.0617	.0347
4	.0671	.8745	.8796	.8642	.0876	.0633	.0876
5	.0671	.9175	.884	.5453	.0876	.0648	.0876
6	.0895	.8951	1.142	.9602	.1097	.0625	.0876
7	.0905	1.0911	1.4022		.1254	.0671	.0934
8	.1075	1.4575	1.5947		.1448	.0949	.1097
9	.1254	1.3765	1.5746	.6562	.1254	.128	.1063
10	.1267	.0655	.1187	.0181	.0701	1.4918	.1134
11	2.3304	.0663	.12	.104	1.8898	1.4918	2.6791
12	2.5149	.0633	.1357	.1254	2.4348	1.4918	2.8487
13	2.5819	.0819	.1086	.1029	2.5312	1.4091	2.6825
14	2.5149	.0625	.1052	.1029	2.9973	1.4091	2.73
15	2.431	.0949	.104	.1174	2.5606	1.3927	2.5316
16	2.431	.0625	.104	.1543	2.8182		2.4366
17	2.1051	.0762	.124	.1578	2.392		2.2377
18	1.8233	.0972	.1357	.1433	2.2138	1.8778	.9602
19	.1463	.061	.1478	.1463	.0972	.1086	.128
20	.128	.0995	.1478	.124	.096	.1086	.1097
21	.1097	.0617	.1294	.1075	.0772	.0724	.1109
22	.0693	.0594	.1097	.1063	.0625	.0724	.0914
23	.0678	.0572	.0732	.0857	.0663	.0678	.0886
24	.0663	.8697	.9431	.8539	.0867	.0686	.0335
Max	2.5819	1.4575	1.5947	.9602	2.9973	1.8778	2.8487
Min	.0663	.0572	.0732	.0181	.0625	.0617	.0335
Avg	.8415	.4627	.5346	.3651	.8889	.5335	.8523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 203 / 11 KV PADALI AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2214	.0297	.0309	.0286	.2656	.2006	.2846
2	.2214	.0297	.0312	.0286	.2656	.192	.2846
3	.2187	.0305	.0316	.0297	.2656	.2267	.2881
4	.2187	.0305	.0332	.0286	.2688	.2458	.2881
5	.2187	.0305	.032	.0286	.2846	.3467	.3841
6	.2372	.0305	.0324	.0286	.3277	.4161	.3841
7	.2846	.061	.0663	.0533	.4372	.4161	.3749
8	.4218	.061	.0617	.0274	.5121	.4908	.5967
9	.3953	.061	.0648	.0572	.4586	.4801	.5693
10	.0305	.0625	.061	.0309	.0617	.0221	.0305
11	.0305	.4801	.5636	.4531	.0663	.0503	.0305
12	.0297	.5182	.6226	.5344	.0625	.0503	.0312
13	.0286	.5281	.5992	.5693	.0305	.0194	.0305
14	.0286	.5093	.6154	.5601	.032	.0194	.0305
15	.0297	.5761	.5761	.5468	.0324	.0194	.0305
16	.0297	.5468	.5487	.5693	.064		.0305
17	.0297	.5506	.5487	.5624	.0309		.0297
18	.0297	.4481	.4961	.4999	.0633	.0255	.0293
19	.061	.0625	.061	.064	.061	.0271	.0316
20	.0625	.061	.061	.0324	.0678	.0271	.0316
21	.061	.0309	.061	.032	.0309	.029	.0316
22	.0625	.032	.0286	.0316	.0316	.0286	.0312
23	.0572	.0309	.0286	.0305	.0324	.0248	.029
24	.2056	.0286	.032	.0297	.2656	.192	.2846
Max	.4218	.5761	.6226	.5693	.5121	.4908	.5967
Min	.0286	.0286	.0286	.0274	.0305	.0194	.029
Avg	.1339	.2013	.2203	.2024	.1674	.1614	.1736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 204 / 11 KV PADALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.0914	.0876	.1052	.1227
2	.124	.0914	.0895	.0876	.1227
3	.124	.0914	.0924	.0876	.124
4	.1227	.0914	.0886	.1052	.124
5	.1402	.1294	.1715	.104	.124
6	.1753	.1772	.208	.1612	.1772
7	.2534	.2534	.2561	.2172	.2534
8	.2454	.2303	.2481	.2454	.2454
9	.2103	.1928	.2012	.2126	.2103
10	.1696	.1492	.1865	.156	.1214
11	.112	.108	.1357	.1509	.08
12	.1094	.1311	.1543	.1492	.1898
13	.1094	.096	.1619	.1423	.1698
14	.112	.1265	.1492	.116	.0914
15	.1147	.1406	.1509	.116	.0974
16	.1147	.1389	.1562	.1147	.112
17	.1326	.1389	.1457	.116	
18	.1677	.1739	.1781	.1802	
19	.2686	.3258	.2507	.2686	
20	.2195	.2686	.2195	.2402	
21	.1646	.2378	.2195	.2218	
22	.1663	.2172	.1829	.1829	
23	.1097	.1578	.1417	.1433	
24	.124	.0905	.104	.1052	.1227
Max	.2686	.3258	.2561	.2686	.2534
Min	.1094	.0905	.0876	.0876	.08
Avg	.1548	.1604	.1658	.1554	.1464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 205 / 11 KV WAKURDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0905	.0857	.0895	.1063
2	.0905	.0914	.0876	.0895	.1063
3	.0895	.0914	.0857	.0905	.1075
4	.0895	.0914	.0876	.0886	.1075
5	.0914	.1109	.1387	.0886	.1086
6	.1478	.1612	.1886	.1629	.168
7	.2957	.2195	.2402	.2534	.2561
8	.2865	.2715	.2715	.2686	.2629
9	.2835	.2454	.2303	.2658	.2454
10	.2427	.2401	.218	.2601	.1886
11	.1844	.1734	.2229	.2204	.1781
12	.1781	.1886	.1715	.218	.1898
13	.1989	.1638	.2012	.2012	.176
14	.1844	.1677	.1865	.1658	.132
15	.1696	.144	.2294	.1619	.1406
16	.1865	.1543	.1957	.1898	
17	.1943	.1858	.2267	.25	
18	.2652	.2915	.2155	.2315	
19	.3761	.4207	.362	.4252	
20	.3658	.362	.3511	.3841	
21	.3142	.3326	.3142	.3142	
22	.2218	.2218	.2195	.2587	
23	.128	.1227	.1267	.1448	
24	.0895	.0905	.1052	.0886	.1063
Max	.3761	.4207	.362	.4252	.2629
Min	.0895	.0905	.0857	.0886	.1063
Avg	.1985	.1930	.1984	.2047	.1613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 206 / 11 KV TAKAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0724	.0693	.0934	.0754	.0686	.1132
2	.1132	.0732	.0701	.0924	.0754	.0724	.1132
3	.0943	.0732	.0732	.0924	.0754	.0701	.1132
4	.0943	.0739	.1387	.0924	.0754	.0732	.1132
5	.0943	.1109	.1753	.1086	.0943	.1753	.1867
6	.1509	.1867	.3155	.168	.1509	.208	.1886
7	.2772	.2614	.3506	.3174	.2452	.2915	.3018
8	.2772	.2801	.3142	.3326	.2957	.2774	.3772
9	.2772	.2614	.2774	.3361	.2587	.2629	.2896
10	.2587	.2058	.2534	.2561	.2149	.2195	.2427
11	.2172	.2149	.2012	.1829	.1753	.2149	.1848
12	.2126	.1907	.1478	.156	.1734	.1791	.1463
13	.1663	.1372	.1267	.1509	.1753	.1063	.1417
14	.1663	.1448	.1267	.156	.1509	.1063	.1387
15	.1494	.1387	.1267	.1417	.1341	.1063	.1949
16	.1448	.1753	.1387	.1658	.1372		.168
17	.1448	.1753	.156	.1791	.1448		.1509
18	.181	.2172	.2303	.1629	.1734	.2454	.2263
19	.3109	.3467	.3475	.3326	.362	.3982	.3584
20	.3326	.3224	.3475	.3511	.3326	.3982	.2987
21	.2561	.3121	.3292	.3174		.2987	.3206
22	.2378	.2452	.2402	.2614	.2103	.2957	.2263
23	.1478	.1387	.1463	.1494	.1214	.1478	.132
24	.1509	.0895	.0876	.112	.0754	.0701	.1132
Max	.3326	.3467	.3506	.3511	.362	.3982	.3772
Min	.0943	.0724	.0693	.0924	.0754	.0686	.1132
Avg	.1904	.1853	.1996	.1962	.1708	.1948	.2017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 201 / 11 KV MANGLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.1052	.1214	.1214	.1052	.1029
2	.1132	.0934	.0876	.104	.104	.1097	.1029
3	.132	.2846	.0876	.104	.104	.112	.1029
4	.1524	.1063	.1227	.1214	.1387	.104	.1227
5	.1886	.1254	.1753	.1387	.1734	.1372	.1578
6	.2033	.2378	.1928	.1734	.208	.2035	.2103
7	.2772	.3467	.2454	.208	.2254	.2321	.298
8	.3326	.2865	.2454	.2601	.2601	.2622	.298
9	.2561	.2481	.2279	.2427	.2481	.2543	.2804
10	.2218	.2686	.2103	.208	.2507	.2279	.2629
11	.2427	.2507	.2454	.208	.2254		.2279
12	.2378	.2303	.2279	.1907	.2507		.1875
13	.2481	.2279	.1928	.208	.2279		.2103
14	.2686	.2103	.2103	.208	.2195		.2103
15	.2427	.2279	.1928	.208	.1417		.2279
16	.2561	.2279	.2804	.2254	.2561		.2103
17	.2957	.2454	.3155	.2774	.2458	.2454	.2103
18	.2987	.298	.3155	.2774	.3052	.2804	.2804
19	.4024	.3506	.4161	.3121	.3688	.3155	.3681
20	.4294	.3681	.4161	.3467	.3467	.3856	.2454
21	.3658	.3155	.3121	.2947	.3467	.2629	.3506
22	.2957	.2629	.2427	.2254	.2561	.2103	.2629
23	.1886	.1753	.1734	.1734	.1791	.1715	.1753
24	.1334	.128	.1227	.1387	.1387	.1214	.1214
Max	.4294	.3681	.4161	.3467	.3688	.3856	.3681
Min	.1132	.0934	.0876	.104	.104	.104	.1029
Avg	.2457	.2398	.2235	.2073	.2226	.2078	.2178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 202 / 11 KV DEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.8002	.8288	.8951	.0328	.016	.0166
2	.0332		.7956	.852	.0328	.0164	.0166
3	.0332	.7865	.7956	.852	.0328	.0166	.0166
4	.0332	.8288	.8619	.8951	.0328	.0164	.0166
5	.0332	.8322	.9116	.9831	.0328	.0162	.0332
6	.0332	.9069	.9448	1.0814	.0328	.016	.0332
7	.0381	1.3176	1.1768	1.1797	.0328	.0164	.0332
8	.0366	1.3923	1.3426	1.3763	.0328	.0324	.0332
9	.0358	1.4752	1.3094	1.5729	.0332	.032	.0332
10	1.4045	.0332	.0332	.0328	.0328	.852	.0332
11	1.8267	.0332	.0332	.0328	1.4723	1.704	2.0553
12	2.0851	.0332	.0332	.0328	1.6385	1.917	2.1051
13	1.9845	.0332	.0166	.0328	1.7284	1.9662	1.989
14	1.9418	.0332	.0166	.0328	1.8023	2.0056	1.8896
15	1.8781	.0332	.0166	.0328	1.8343		1.8067
16	1.7295	.0332	.0166	.0328	1.9662		1.7238
17	1.5684	.0332		.0492	1.8564		1.6078
18	1.4922	.0332		.0328	1.7465		1.4586
19	.0332	.0332	.0166	.0328	.0328	.0332	.0332
20	.032	.0332	.0166	.0328	.0316	.0332	.0332
21	.0328	.0332	.0166	.0328	.0164	.0332	.0332
22	.016	.0332	.0166	.0328		.0332	.0332
23	.0166	.0332	.0166	.0328	.016	.0332	.0332
24	.0332	.852	.6962	.8951	.0328	.0164	.0166
Max	2.0851	1.4752	1.3426	1.5729	1.9662	2.0056	2.1051
Min	.016	.0332	.0166	.0328	.016	.016	.0166
Avg	.6827	.4198	.4506	.4608	.6306	.4403	.6285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 203 / 11 KV MANGLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0173	.3315	.3467	.3086	.0168	.0164	.0171
2	.0173	.2846	.2949	.3086	.0168	.016	.0171
3	.0175	.2846	.2846	.3086	.0168	.0158	.0171
4	.0175	.3277	.2984	.3086	.0168	.016	.0171
5	.0175	.373	.3391	.3391	.0168	.0168	.0171
6	.0177	.426	.3605	.373	.0168	.0164	.0171
7	.0181	.7274	.3887	.4748	.0168	.016	.0171
8	.0177	.5571	.4588	.4409	.0168	.0328	.0171
9	.0179	.6783	.4801	.4748	.0328	.0328	.0171
10	.8779	.0173	.017	.0168	.032	.5376	.0171
11	.7783	.0173	.017	.0168	.6882		.8402
12	.7362	.0173	.017	.0168	.8817		.823
13	.7373	.0173	.017	.0168	.852		.8745
14	.7461	.0173	.017	.0168	.8048		.8573
15	.7865	.0173	.017	.0168	.7701		.8402
16	.7362	.0173	.017	.0168			.7888
17	.68	.0173	.017	.0168	.7042	.6009	.7716
18	.6882	.0173	.017	.0168	.7865	.6325	.0173
19	.0347	.0173	.0171	.0168	.0335	.0171	.0173
20	.0339	.0173	.0171	.0168	.032	.0171	.0173
21	.0332	.0173	.0171	.0168	.0158	.0171	.0173
22	.0164	.0173	.0171	.0168		.0171	.0173
23	.017	.0173	.0171	.0168	.0183	.0164	.0173
24	.0173	.3605	.3467	.3429	.0168	.0168	.0171
Max	.8779	.7274	.4801	.4748	.8817	.6325	.8745
Min	.0164	.0173	.017	.0168	.0158	.0158	.0171
Avg	.2949	.1914	.1599	.1631	.2638	.1140	.2536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 204 / 11 KV CHIKHALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.0316	.0332	.0332	.8951	.8002	.8907
2	.8288	.0316	.0332	.0332	.9667	.7865	.9442
3	.8356	.0324	.0332	.0332	.9667	.7956	.852
4	.8421	.0328	.0332	.0332	1.1305	.8309	1.1022
5	.852	.0339	.0332	.0332	1.1603	.9614	1.094
6	.8322	.0655	.0332	.0332	1.3592	1.1142	1.3923
7	1.0242	.1017	.0663	.0663	1.4918	1.4723	1.4255
8	1.2483	.064	.0663	.0663	1.6741	1.6712	1.7238
9	1.2125	.064	.0663	.0663	1.6057	1.8023	1.5249
10	.032	.064	.0663	1.5581	.064	.0663	.0663
11	.0655	2.2939	2.1879	1.5581	.0655		.0663
12	.064	2.3371	2.3205	1.5746	.032		.0663
13	.0655	2.3205	2.3868	2.0719	.0328		.0663
14	.0655	2.3205	2.3537	2.2542	.064		.0663
15	.096	2.3205	2.1879	2.2211	.0633		.0332
16		2.3371	2.1216	2.1548	.064		.0663
17		2.3205	2.0222	1.9559	.0663	.0663	.0663
18	.0655	1.757	1.7238	1.757	.1017	.0663	.0663
19	.096	.0663	.0663	.0332	.0983	.0663	.0663
20	.0949	.0663	.0663	.0332	.0678	.0663	.0663
21	.0663	.0663	.0663	.0332	.0686	.0663	.0663
22	.016	.0663	.0663	.0332		.0663	.0663
23	.0164	.0332	.0663	.0332	.0335	.0347	.0663
24	.9054		.0332	.0663	.663	.8223	.852
Max	1.2483	2.3371	2.3868	2.2542	1.6741	1.8023	1.7238
Min	.016	.0316	.0332	.0332	.032	.0347	.0332
Avg	.4611	.8186	.7556	.7390	.5537	.6420	.5290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 205 / 11 KV DEOWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0358	.0358	.0377	.1509	.0373	.0377
2	.0358	.0373	.0366	.0381	.0366	.0366	.0351
3	.0351	.0377	.0347	.0381	.0543	.0358	.0343
4	.0537	.0377	.0532	.0381	.0549	.0566	.0537
5	.0549	.056	.0549	.0566	.0747	.0716	.0732
6	.0934	.0886	.0934	.0934	.132	.124	.1086
7	.1463	.1463	.1848	.1646	.1494	.1387	.1417
8	.128	.1417	.1254	.1448	.1433	.1509	.1448
9	.1086	.1387	.1214	.1543	.128	.1311	.1294
10	.1307	.1219	.1017	.128	.1075	.1543	.1097
11		.0914	.1307	.112	.112	.1017	.0829
12		.1094	.1189	.0972	.1075	.0686	.1187
13	.124	.0857	.1006	.0819	.0914	.0701	.0838
14	.1097	.0693	.0772	.0739	.0747	.0543	.0983
15	.0857	.0686	.0762	.0876	.0886	.0373	.0791
16	.1052	.0617	.108	.088	.0732		.0819
17	.128	.0469		.1094	.0857		.08
18	.0995	.0678		.108	.128		.1227
19	.1595	.1227	.1949	.128	.1663	.1086	.1612
20	.1829	.1629	.181	.1646	.1886	.1478	.1829
21	.1698	.1448	.1629	.128	.1949	.1478	.1612
22	.112	.1463	.1109	.1109		.1307	.128
23	.0754	.0732	.0739	.0914	.112	.0739	.0739
24	.0366		.0373	.056	.056	.0566	.056
Max	.1829	.1629	.1949	.1646	.1949	.1543	.1829
Min	.0351	.0358	.0347	.0377	.0366	.0358	.0343
Avg	.1005	.0910	.1007	.0971	.1092	.0921	.0991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 206 / 11 KV DHANTAKE WARANA

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0362	.0366	.0366	.0366	.0366	.0358
4	.0362	.0366	.0366	.0366	.0366	.0358
5	.0362	.0549	.0549	.0366	.0366	.0358
6	.0747	.0537	.0732	.1629	.1463	.2353
7	.1478	.1463	.1463	.2353	.1433	.2402
8	.1494	.1463	.1463	.2353	.1433	.2328
9	.1463	.1463	.1646	.2172	.1629	.2328
10	.1463	.1478	.1646	.2172	.1646	.2149
11	.1463	.1478	.1646	.2172	.1629	.2149
12	.1463	.1478	.1646	.2353	.1646	.2328
13	.1463	.1478	.1646	.2353	.1646	.2149
14	.1463	.1478	.1646	.2328	.2534	.2149
15	.056	.1463	.1646	.2328	.2561	.2149
16	.0566	.1463	.1646	.2328	.2561	.2149
17	.0566	.1463	.1646	.2328	.2534	.2149
18	.1509	.1463	.1629	.2149	.2328	.2149
22			.1629			
Max	.1509	.1478	.1646	.2353	.2561	.2402
Min	.0362	.0366	.0366	.0366	.0366	.0358
Avg	.1049	.1216	.1354	.1882	.1634	.1875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 401 / 33KV INGRUL KAPARI LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4481	.4481	.7282	.7282	.7282
2	.5601	.679	.7282	.7282	.7282	.7282
3	.6722	.679	.7282	.7282	.7282	.7282
4	.6722	.679	.7282	.7282	.7282	.7282
5	.7282	.679	.7282	.7282	.7282	.7282
6	.7282		.7282	.7282	.7282	.7282
7	.7282	.7356	.7282	.7282	.7282	.7282
8	.7282	.7282	.7282	.7282	.7282	.7282
9	.7282	.7282	.7282	.7282	.7282	.7282
10	.7282	.7282	.7282	.7282	.7282	.7282
11	.7282	.7282	.7282	.7282	.7282	.7282
12	.7282	.7282	.7282	.7282	.7282	.7282
13	.7282	.7282	.7282	.7282	.7282	.7282
14	.7282	.7282	.7282	.7282	.7282	.7282
15	.7282	.7282	.7282	.7282	.7282	.7282
16	.1143		.112	.168	.1143	.112
Max	.7282	.7356	.7282	.7282	.7282	.7282
Min	.1143	.4481	.112	.168	.1143	.112
Avg	.6551	.6947	.6722	.6932	.6898	.6897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 201 / 11 KV KANDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0383	.2561	.3353	.3567	.04	.044	.0429
2	.0383	.2498	.3281	.3658	.0429	.0446	.0429
3	.04	.2606	.3201	.3658	.0446	.0446	.0429
4	.04	.3094	.3395	.3963	.0457	.0446	.0429
5	.04	.3315	.3749	.4111	.0469	.0434	.0429
6	.0446	.3801	.5155	.4111	.048	.044	.0429
7	.0492	.4561	.8259	.6401	.0474	.048	.0429
8	.0486	.6078	.9442	.852	.0429	.0486	
9	.0417	.5636	.8097	.7042	.0446	.0509	.04
10	.0457	.0423	.0417	.0429	.044	.0497	.0349
11	1.1088		.044	.04	1.3496	1.3094	1.4091
12	1.1273	.044	.0446	.0511	1.4723	1.3108	1.5074
13	1.1041	.0412	.0446	.0377	1.587	1.247	1.5223
14	1.197	.0429	.044	.0383	1.6221		1.5565
15	1.1774	.0423	.0446	.0389	1.5364	1.0416	1.4251
16	1.1203	.0423	.0457	.0394	1.5844	1.3279	1.2809
17	1.0004		.0412	.0389	1.3117	1.1822	1.2483
18	.7625	.04	.0594	.0383	1.085	.9231	.0434
19	.048	.044	.0446	.044	.0434	.0556	.0434
20	.0457	.0579	.0457	.044	.0446	.0429	.0429
21	.0423	.044	.0446	.044	.0446	.0429	.0429
22	.0429	.0446		.0446	.0457	.0417	.04
23	.04	.0434	.0434	.0434	.044	.0429	.0389
24	.0383	.2515	.3269	.2172	.0389	.0429	.0429
Max	1.197	.6078	.9442	.852	1.6221	1.3279	1.5565
Min	.0383	.04	.0412	.0377	.0389	.0417	.0349
Avg	.3867	.1907	.2482	.2211	.5107	.3945	.4617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 202 / 11 KV PUNVAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0255	.0366	.0732	.0739	.0724	.0724	.0701
2	.0255	.0389	.056	.0739	.0549	.0732	.0709
3	.0255	.0423	.056	.0739	.0554	.0732	.0716
4	.0394	.0579	.0739	.0739	.0739	.0739	.0905
5	.0657	.0743	.1086	.1109	.1109	.0924	.1086
6	.1067	.1189	.1646	.1478	.1478	.1663	1.6289
7	.1932	.208	.2218	.2218	.2033	.2195	.2054
8	.1957	.16	.2378	.2353	.2378	.2149	.1848
9	.1486	.1734	.1928	.2254	.1791	.1829	.2149
10	.1486	.1463	.1865	.1886	.1433	.1619	.1865
11	.1181		.1715	.1886	.1595	.1187	.1677
12	.0854	.096	.1715	.1619	.1578	.1147	.1174
13	.0838	.0827	.1187	.1423	.1402	.0838	.0983
14	.0808	.0732	.1296	.0926	.1372		.1107
15	.0892	.1166	.1296	.108	.1372	.0648	.1337
16	.0991	.1235	.1311	.125	.1526	.116	.1677
17	.1048		.1543	.1581	.1619	.16	.1543
18	.1212	.2187	.176	.192	.1966	.1457	.3045
19	.2073	.2713	.2103	.2481	.2481	.2172	.3045
20	.2134	.2804	.2686	.2686	.2686	.2012	.2896
21	.1833	.2507	.2534	.2172	.2149	.2402	.2561
22	.1334	.1629		.181	.1629	.1663	
23	.08	.0905	.1097	.1267	.1267	.0819	.1267
24	.0255	.048	.0732	.0554	.0716	.0724	.0716
Max	.2134	.2804	.2686	.2686	.2686	.2402	1.6289
Min	.0255	.0366	.056	.0554	.0549	.0648	.0701
Avg	.1083	.1305	.1508	.1538	.1506	.1354	.2233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 203 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	.0509	.0747	.0754	.0747	.0671	.0848
2	.0503	.0503	.0754	.0754	.0747	.0671	
3	.0503	.0503	.0754	.0754	.0747	.0754	.0693
4	.0503	.0678	.0754	.0943	.0934	.0754	.0701
5	.0838	.0838	.0943	.132	.132	.0943	.0754
6	.1341	.116	.1698	.1509	.2054	.1698	.2263
7	.2012	.1943	.2452	.2263	.2614	.2427	.2263
8	.218	.1781	.2241	.2241	.2241	.2054	.2427
9	.1505	.1467	.1867	.1848	.181	.1867	.2033
10	.1128	.1303	.1629	.1595	.1578	.1753	.1772
11	.1132		.1417	.1578	.1578	.1448	.1543
12	.12	.1269	.1402	.1543	.156	.1214	.1214
13	.1067	.1115	.1387	.1543	.12	.1214	.1134
14	.0947	.0974	.1402	.12	.1227		.1227
15	.0934	.1337	.1402	.1341	.1357	.1387	.1509
16	.1257	.1372	.1638	.1475	.1658	.1543	.1619
17	.1238		.1658	.1696	.1658	.156	.144
18	.1162	.213	.1844	.1696	.2012	.156	.2561
19	.1932	.2507	.2534	.2353	.2534	.2254	.2561
20	.2134	.2926	.2534	.2561		.2254	.2561
21	.1943	.2561	.2402	.2378	.2378	.2149	.2241
22	.1638	.1848		.2218	.2033	.2054	
23	.0838	.1109	.112	.1478	.1478	.1307	.1132
24	.0503	.0509	.0924		.0924	.0739	.0867
Max	.218	.2926	.2534	.2561	.2614	.2427	.2561
Min	.0503	.0503	.0747	.0754	.0747	.0671	.0693
Avg	.1206	.1379	.1544	.1610	.1582	.1490	.1607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 204 / 11KV DATT LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.096	.0926	.1406	
2	.096	.0926	.1406	
3	.096	.0926	.1372	
4	.096	.0943	.1406	
5	.096	.0943	.1406	
6	.096	.0943	.1406	
7	.096	.0943	.1423	
8	.096	.096	.1423	
9	.0943	.096	.1423	
10	.0943	.0943	.1389	
11	.096		.1423	
12	.0943	.0977	.1423	.1406
13	.0943	.096	.1423	.1389
14	.0943	.096	.0142	.1406
15	.0943	.0943	.1423	.1389
16	.096	.0943	.1406	.1372
Max	.096	.0977	.1423	.1406
Min	.0943	.0926	.0142	.1372
Avg	.0954	.0946	.1331	.1392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 201 / 11 KV KARMALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.061	.0914	.0983	.0566	.0566	.0754
2	.0566	.0617	.0914	.0819	.0566	.0566	.0754
3	.0566	.0937	.0914	.0838	.0566	.0566	.0754
4	.0566	.0937	.0914	.0848	.0566	.0566	.0747
5	.0754	.1235	.0914	.1017	.0754	.0566	.112
6	.1132	.1524	.1219	.1187	.0943	.0943	.1494
7	.1509	.2134	.1981	.2486	.1509	.1886	.1886
8	.1509	.2743	.2439	.2652	.2075	.1886	.1509
9	.1132	.2439	.1829	.213	.1698	.132	.1494
10	.1097	.0943	.0754	.0732	.132	.1097	.112
11	.253	.0943	.0943	.0549	.2439	.2241	.2688
12	.2721		.0943	.0532	.2439	.2372	.2688
13	.2721	.0754	.0934	.0732	.2439	.2315	.2721
14	.2214	.0566	.0732	.0716	.2591	.2229	.2881
15	.253	.0754	.0732	.0724	.2439	.2134	.2429
16	.2561	.0566	.0739	.0732	.2439	.1898	.2949
17	.25	.0566	.0924	.0732	.1829	.1966	.1966
18	.2343	.1132	.1109	.0914	.2286	.1492	.1638
19	.1698	.1509	.1494	.0943	.1509	.1698	.1829
20	.1829	.1698	.1867	.1886	.1886	.1886	.2012
21	.1463	.1698	.1494	.1698	.1886	.1886	.1829
22	.1478	.1132	.1132	.0754	.1886	.1132	.1097
23	.0732	.0754	.0754	.0754	.0754	.0754	.0732
24	.0566	.061	.0914	.0983	.0754	.0566	.0754
Max	.2721	.2743	.2439	.2652	.2591	.2372	.2949
Min	.0566	.0566	.0732	.0532	.0566	.0566	.0732
Avg	.1553	.1165	.1146	.1098	.1589	.1439	.1660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 203 / 11 KV PADALIWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4687	.0617	.0579	.0663	2.0485	1.7924	1.5581
2	.4572	.061	.0579	.0663	2.0485	1.7924	1.4918
3	.4515	.0617	.0579	.0663	2.0485	1.7924	1.4918
4	.4816	.0625	.0579	.0663	2.0485	1.7924	1.4918
5	.5117	.0781	.0579	.0829	2.0805	1.7924	1.5912
6	.5647	.0772	.0724	.0829	2.0805	1.8244	1.6907
7	.639	.0762	.1014	.116	2.3266	1.9433	1.989
8	.7225	.0926	.1158	.1326	2.2939	2.1376	2.1382
9	.7773	.0625	.1014	.0829	2.2939	2.1052	1.989
10	.0655	.061	.1147	.0829	.0705	.0829	.0655
11	.0655	2.13	2.7526	2.6686	.0564	.0829	.0655
12	.0655	2.2939	2.8837	2.7018	.0564	.0829	.0663
13	.0762	2.7199	2.8837	2.7515	.0564	.0829	.0655
14	.061	2.8509	2.8673	2.652	.04	.0663	.0655
15	.0762		2.8182	2.7846	.0533	.0829	.0655
16	.061	2.5232	2.7526	2.8178	.0533	.0829	.0819
17	.0914	2.4577	2.7854	2.7183	.0667	.0829	.0829
18	.0914	2.4577	2.7854	.0762	.0667	.0995	.0983
19	.0914	.0724	.0663	.0914	.08	1.1271	.0819
20	.061	.0869	.0663		.08	.0995	.0819
21	.0914	.0869	.0663	.0762	.0533	.0995	.0829
22	.0625	.0724	.0829	.0762	.0533	.0829	.0663
23	.061	.0579	.0829	.061	.0533	.0829	.0655
24	.5243	.061	.0579	.0663	1.6804	1.6004	1.5581
Max	.7773	2.8509	2.8837	2.8178	2.3266	2.1376	2.1382
Min	.061	.0579	.0579	.061	.04	.0663	.0655
Avg	.2758	.8072	.9894	.8864	.9079	.8671	.7510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 204 / 11 KV MIDC NEW

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.9431	1.1317	1.2826	1.1317	.4527	.5281
2	.8676	.9054	1.1317	1.2826	1.1317	.3772	.5281
3	.8299	.8676	1.1317	1.3203	1.1317	.3772	.4904
4	.7545	.8676	1.1317	1.2071	1.1317	.3772	.3772
5	.7922	.8676	1.1317	1.1317	1.1317	.3772	.3018
6	.6036	.679	1.1317	1.094	.9808	.3584	.3018
7	.6413	.679	1.1883	1.3014	1.0751	.3395	.3395
8	1.2826	.7167	1.2449	.6224	1.1317	.2829	.3206
9	1.9239	.9619	1.4146	.7922	1.1317	.2641	.5093
10	1.905	.8299	1.7541	1.0374	1.6032	.3584	.7167
11	1.7164	1.8861	1.7353	1.0562	1.4335	.4527	.679
12	1.5466	1.8861	1.094	.9997	1.4335	.4715	.5847
13	1.6221	1.5089	1.7353	.9431	1.4335	.4715	.6036
14	1.7918	1.5089	1.7353	1.094	1.2826	.4715	.6224
15	1.9616	1.6032	1.6221	1.0374	1.358	.4715	.6413
16	1.8107	1.358	1.4712	1.1694	1.3957	.4715	.6979
17	1.6975	1.3769	1.4335	1.0185	1.1694	.4527	.6602
18	1.5278	1.3769	1.3392	.9808	1.2449	.4527	.6036
19	1.5655	1.358	1.2826	.9054	.8299	.5281	.6036
20	1.1128	1.358	1.3769	.8676	.6224	.547	.6224
21	1.0185	1.4712	1.3014	1.1317	.8299	.547	.6224
22	1.094	1.6032	1.3957	1.2826	.8299	.547	.6036
23	1.0562	1.5466	1.4335	1.5844	.8299	.547	.5853
24	.8676	.9808	1.1694	1.3203	1.2449	.7167	.5093
Max	1.9616	1.8861	1.7541	1.5844	1.6032	.7167	.7167
Min	.6036	.679	1.094	.6224	.6224	.2641	.3018
Avg	1.2857	1.2142	1.3549	1.1026	1.1466	.4464	.5439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 201 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2486	.0164	.0166	.0166	.3647	.2515	.2012
2	.2486	.0164	.0166	.0166	.3647	.2515	.2012
3	.2486	.0164	.0166	.0166	.3647	.2347	.2012
4	.2486	.0164	.0166	.0166	.3812	.2515	.218
5	.2818	.0166	.0166	.0166	.3812	.285	.2515
6	.3149	.0166	.0166	.0166	.4144	.3353	.3353
7	.4475	.0328	.0166	.0166	.4144	.4694	.4359
8	.5636	.0164	.0166	.0166	.5636	.6371	.5868
9	.4641	.0328	.0166	.0166	.5138	.5197	.5533
10	.0166	.0328	.0166	.0166	.0168	.0168	.0335
11		.8192	.7459	.7293	.0168	.0168	.0168
12		.9012	.7956	.8785	.0168	.0335	.0168
13		.9175	.7625	.8619	.0168	.0168	.0168
14		.9175	.3481	.7625	.0168	.0347	.0335
15		.852	.7625	.8453	.0168	.0335	.0168
16		.8356	.779	.8785	.0168	.0335	.0168
17		.7701	.7127	.7625	.0335	.0335	.0335
18		.6062	.5801	.0166	.0335	.0335	.0335
19		.0164	.0166	.0166	.0335	.0335	.0168
20	.0166	.0328	.0166	.0166	.0335	.0335	.0168
21	.0166	.0328	.0166	.0166	.0335	.0168	.0168
22	.0166	.0328	.0166	.0166	.0335	.0168	.0168
23	.0166	.0332	.0166	.0166	.0335	.0168	.0166
24	.2652	.0164	.0166	.0166	.3315	.2515	.2012
Max	.5636	.9175	.7956	.8785	.5636	.6371	.5868
Min	.0166	.0164	.0166	.0166	.0168	.0168	.0166
Avg	.2276	.2916	.2397	.2500	.1853	.1607	.1453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 202 / 11 KV KOKARUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0154	.0158	.108	.0903	.0154	.0151	.0152
2	.0154	.0791	.108	.0903	.0154	.0151	.0152
3	.0154	.0791	.108	.0903	.0154	.0151	.0152
4	.0154	.0949	.1235	.0903	.0154	.0151	.0152
5	.0154	.1107	.1235	.1204	.0154	.0151	.0152
6	.0154	.1581	.1389	.1505	.0154	.0151	.0152
7	.0154	.2623	.2778	.2107	.0154	.0151	.0152
8	.0154	.3086	.3311	.3241	.0154	.0151	.0152
9	.0154	.2469	.301	.2778	.0154	.0151	.0152
10	.0158	.0154	.0151	.0154	.0149	.0152	.0152
11	.6167	.0154	.0151	.0154	.5647	.5792	.5944
12	.5693	.0154	.0151	.0154	.5647	.5944	.5487
13	.6009	.0154	.0151	.0154	.602	.6097	.5487
14	.6167	.0154	.0151	.0154	.602	.5487	.5487
15	.5851	.0154	.0151	.0154	.5719	.5335	.4725
16	.5376	.0154	.0151	.0154	.5418	.503	.4115
17	.4744	.0154	.0151	.0154	.5268	.5548	.3658
18	.3005	.0154	.0151	.0154	.3763	.4334	.3506
19	.0158	.0154	.0151	.0154	.0151	.0152	.0152
20	.0158	.0154	.0151	.0154	.0151	.0152	.0152
21	.0158	.0154	.0151	.0154	.0151	.0152	.0152
22	.0158	.0154	.0151	.0154	.0151	.0152	.0152
23	.0158	.0154	.0151	.0154	.0151	.0152	.0154
24		.0791	.0926	.0903	.0154	.0151	.0152
Max	.6167	.3086	.3311	.3241	.602	.6097	.5944
Min	.0154	.0154	.0151	.0154	.0149	.0151	.0152
Avg	.1972	.0688	.0802	.0729	.1914	.1916	.1702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 203 / 11 KV KOKARUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2279	.2103	.2103	.1753	.2454	.2254	.208
2	.2103	.2103	.2103	.1753	.2454	.208	.208
3	.2103	.1928	.1928	.1753	.2279	.208	.208
4	.2103	.1928	.2454	.2103	.2279	.208	.208
5	.298	.3681	.3506	.2629	.333	.2774	.2601
6	.4031	.4557	.4031	.3681	.4908	.3988	.4161
7	.5959	.5959	.5959	.5959	.5959	.6241	.6241
8	.7011	.7362	.631	.6661	.7011	.6539	.6836
9	.5959	.631	.5434	.6485	.6135	.6068	.6588
10	.5434	.5258	.5609	.5083	.5784	.4681	.5083
11	.5083	.5258	.4733	.5434	.5028	.4161	.4161
12	.3155	.4207	.4207	.5258	.4334	.3467	.3121
13	.2629	.3681	.3856	.4557	.4508	.3467	.4161
14	.2454	.3681	.3506	.4031	.3641	.3121	.3988
15	.2629	.4031	.4031	.4207	.3988	.3641	.3814
16	.2804	.4733	.3856	.431	.4508	.3814	.3814
17	.3155	.1753	.4733	.4807	.4681	.4161	.4508
18	.3155	.5609	.5258	.5434	.5028	.5201	.5548
19	.8063	.7186	.5959	.7712	.7108	.7282	.7282
20	.7712	.7011	.7011	.7712	.7282	.6935	.7282
21	.6661	.6135	.5609	.6485	.6241	.5895	.5895
22	.4733	.4557	.4908	.5258	.4508	.4854	.4508
23	.298	.298	.298	.333	.2947	.2774	.298
24	.2279	.2279	.2279	.2629	.2629	.2254	.2427
Max	.8063	.7362	.7011	.7712	.7282	.7282	.7282
Min	.2103	.1753	.1928	.1753	.2279	.208	.208
Avg	.4061	.4345	.4265	.4543	.4543	.4159	.4305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 201 / 11 KV Dafalapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6602	.1867	.1357	.1698	.5487
2		.6602	.1867	.1326	.1886	.583
3		.7545	.1867	.1311	.1886	.583
4		.7545	.2241	.1326	.2263	.6173
5		.6882	.2987	.1619	.3018	.7716
6	1.0576	.7701	.4066	.3441	.4527	1.0004
7	1.4575	1.2125	.567	.4915	.5093	1.5424
8	1.8652	1.3763		.421	.4715	2.0222
9	.5249	.3961	.3361	.2915	.3584	.4481
10	.2587	1.4419	1.1904	1.2452	.2829	
11	.2263	1.9616	1.5708	1.6712	.2054	
12	.2075	1.9227	1.7444	1.8351	.2054	
13		1.8778	1.9393	1.8842	.2054	
14		1.9062	1.7814	1.8023	.1867	
15	.1698	1.9062	1.8778	1.9006	.1494	
16	.2452	1.8233	1.8623	2.0481	.1494	
17	.2452	1.7404	1.6716	1.8679	.2054	
18	.2452	.2241	.1966	.2452	.2614	
19	.3772	.4294	.3361	.3961	.3921	
20	.3961	.4108	.3149	.3772	.3734	
21	.3395	.3361	.2753	.3395	.3174	
22	.2452	.2427	.2035	.2641	.2241	
23	.4715	.1867			.4973	
24	1.4575	.5658	.1867	.1357	.1698	.5144
Max	1.8652	1.9616	1.9393	2.0481	.5093	2.0222
Min	.1698	.1867	.1867	.1311	.1494	.4481
Avg	.5759	1.0103	.7974	.7937	.2789	.8631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 202 / 11 KV Baj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1469	.3921	.2753	.3395	1.1869	
2		1.6385	.3921	.2458	.3772	1.2209	
3		1.6385	.4481	.2515	.3772	.0934	
4		1.6385	.5175	.2458	.4715	.0934	
5		1.8023	.6219	.4096	.5093	.0934	
6	2.323	2.1956	.7133	.4915	.6224	.112	
7	2.8837	2.7199	.8402		.7922	.1307	
8	3.1855	2.9001			.679	1.291	3.1352
9	.4755	.547	.3734	.39	.5093	.5228	
10	.3881	2.6052	2.2634	2.3758	.3961		.3142
11	.3018	3.2322	3.2819	3.1459	.3174		.2543
12		3.0498	2.4478	2.6216	.3174		.2458
13		2.9338	3.3234	3.2442	.2987		.2294
14		2.8675	2.915	3.2606	.2801		.2321
15		2.7846	2.878	3.0967	.2801		.3391
16		2.7846	2.9984	3.3753	.2987		.2294
17		2.7846	2.9797	3.3097	.2987		.2622
18		.2987	.16	.2452			.3561
19		.5788	.3812	.5658	.5601	.4938	.4752
20	.547	.6161	.4096	.547	.5975		.4917
21	.547	.5415	.3856	.4338	.4854		.4409
22	.4527	.5228	.3437	.3961	.4481	.4024	.3277
23	1.0374	.4294		.3584	1.1191	1.2934	.9217
24	1.4575	.9831	.3921	.2818	.3395	1.153	
Max	3.1855	3.2322	3.3234	3.3753	1.1191	1.2934	3.1352
Min	.3018	.2987	.16	.2452	.2801	.0934	.2294
Avg	1.2363	1.8017	1.3390	1.3440	.4658	.6221	.5503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 203 / 11KV Mirwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.9602	1.1768	.8356	.1867	
2		.1886	.9496	1.1336	.9831	.1867	
3		.2263	1.0513	1.1869	.9995	.1867	
4		.2263	1.2407	1.1603	1.3108	.2054	
5		.2641	1.8778	1.6575	1.4746	.2427	
6	.3511	.3206	2.4143	2.1262	1.9498	.4108	
7	.439	.4715	2.7526	2.6543	2.6216	.5415	
8	.5121	.4338		3.3753	2.8018	.4108	.4207
9	.3696	.3395	.3361	.3077	.2829	.3174	
10	2.0687	.2075	.2614	.2263	1.9989		1.7974
11	3.4899	.168	.1823	.1886	2.8016		2.6189
12	3.5719	.1867	.2652	.1886	2.8016		3.0769
13	3.5555	.1867	.2486	.1698	2.753	3.3573	2.7035
14	3.5555	.1867	.2721	.1698			2.8837
15	3.5555	.168	.1718	.1698	2.7854		2.982
16	3.2769	.168	.16	.1698	3.0283		2.6543
17	3.4572	.2054	.1658	.2075	2.7368		1.491
18	.2075	.2614	.1781	.2829		.2218	.213
19	.415	.3921	.3481	.415	.4108	.3658	.3481
20	.3961	.3734	.3401	.3772	.3921		.3441
21	.3018	.3174	.2881	.3206	.2987		.2515
22	.2075	.2614	.192	.2452	.2427	.2402	.1781
23	.1886	.823		.7373	.1867	.2033	.125
24	1.3717	.1698	.8916	.9717	.8192	.1867	
Max	3.5719	.823	2.7526	3.3753	3.0283	3.3573	3.0769
Min	.1886	.168	.16	.1698	.1867	.1867	.125
Avg	1.6469	.2806	.7067	.8174	1.5689	.4843	1.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 204 / 11 Kv Baj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0934	.1097	.0943	.0934	
2		.1132	.0934	.0914	.0943	.0934	
3		.1132	.0934	.0914	.0943	.0934	
4		.1132	.0934	.0914	.1132	.112	
5		.1509	.112	.112	.1509	.112	
6	.2218	.2075	.1848	.1494	.1886	.1867	
7	.2772	.2829	.2801	.1494	.2452	.2801	
8	.2402	.2263		.1698	.2452	.2427	.2957
9	.2033	.132	.1867	.1494	.1886	.2241	
10	.168	.132	.168	.132	.1509		.1848
11	.132	.1307	.1307	.132	.1494		.0943
12	.1132	.112	.1132	.1132	.112		.0934
13	.1132	.112	.1132	.0943	.0934	.0943	.081
14	.1132	.112	.0934	.0943	.0747		.0943
15	.0943	.0934	.0905	.1132	.0747		.0943
16	.1132	.1307	.0934	.1132	.0934		.0943
17	.1132	.168	.1463	.1509	.1307		.112
18	.1886	.1867	.1494	.1509	.1867	.1132	.1886
19	.3206	.2987	.1991	.3018	.2801	.2772	.1867
20	.2641	.2614	.1509	.2452	.2614		.1886
21	.2263	.2054	.168	.1698			.1886
22	.132	.168	.1867	.1132	.1307	.1307	.2172
23	.1132	.112		.0943	.0934	.0943	.1867
24	1.4575	.0943	.0934	.1307	.0943	.0934	
Max	1.4575	.2987	.2801	.3018	.2801	.2801	.2957
Min	.0943	.0934	.0905	.0914	.0747	.0934	.081
Avg	.2424	.1563	.1379	.1360	.1452	.1494	.1534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 205 / 11 KV Dafalapur GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0934	.0914	.0943	.0934
2		.0943	.0934	.0934	.0943	.0934
3		.1132	.0934	.0914	.0943	.0934
4		.1132	.0934	.0934	.1132	.0934
5		.132	.112	.0934	.132	.1307
6	.1494	.1509	.1494	.112	.1698	.1494
7	.2033	.2075	.2427	.1509	.2641	.2054
8	.1307	.1509		.1698	.1698	.1307
9	.1132	.0943	.0747	.1307	.1509	.0934
10	.0943	.1132	.2614	.132	.1132	
11	.132	.1494	.0943	.132	.0934	
12	.1509	.1494	.1132	.0754	.0934	
13	.0943	.112	.0934	.0754	.0934	
14	.1132	.112	.0732	.0754	.0934	
15	.0943	.112	.0914	.0943	.1307	
16	.132	.112	.0934	.0943	.112	
17	.0943	.1307	.132	.1132	.168	
18	.132	.1307	.112	.132	.1494	
19	.2075	.2054	.2054	.1886	.2241	
20	.2075	.2054	.1509	.1698	.2054	
21	.1886	.1867	.1646	.1698	.2054	
22	.1698	.1494	.1494	.1509	.1494	
23	.1132	.112		.132	.1307	
24	.112	.0943	.0934	.0754	.1132	.112
Max	.2075	.2075	.2614	.1886	.2641	.2054
Min	.0943	.0943	.0732	.0754	.0934	.0934
Avg	.1386	.1344	.1264	.1182	.1399	.1195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 206 / 11 KV ANKALE DORLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3018	1.4419	1.5223	1.1797	.2801	
2		.3018	1.5424	1.5565	1.3108	.2427	
3		.3395	1.6766	1.4842	1.3272	.2427	
4		.3395	1.8778	1.5023	1.4746	.2801	
5		.415	2.4366	1.8351	1.7204	.3361	
6	.6697	.6413	2.8837	2.2775	2.2119	.4481	
7	.7701	.7922	3.3522	2.4417	2.5232	.6535	
8	.6516	.7733		2.5434	2.5888	.4854	.543
9	.543	.6413	.4481	.431	.4338	.4481	
10	2.9843	.5658	.5041	.415	2.4577		1.8143
11	3.9323	.499	.3725	.4338	2.9959		2.9835
12	3.9323	.4668	.2949	.3206	3.0769		3.0769
13	3.6046	.3921	.4096	.3772	3.1741	.2772	3.0445
14	3.5719	.4294	.4359	.3395	3.2874		3.2217
15	2.2939	.4668	.4527	.3772	3.2065		3.0498
16		.4854	.3932	.3584	3.1417		2.7978
17		.4854	.431	.415	2.834		2.6282
18	.415	.5601	.2753	.4527	.3547		.2949
19	.5847	.7095	.4915	.6036	.6161	.6154	.4973
20	.6413	.6348	.4917	.5847	.5415		.4752
21	.5658	.5975	.426	.4527	.5228		.4321
22	.4715	.4668	.3277	.3772	.4108	.3881	.3441
23	.3772	1.1904		1.0159	.3547	.3511	.2881
24	.4024	.3395	1.3413	1.4419	1.1469	.3174	
Max	3.9323	1.1904	3.3522	2.5434	3.2874	.6535	3.2217
Min	.3772	.3018	.2753	.3206	.3547	.2427	.2881
Avg	1.5536	.5348	1.0139	.9816	1.7872	.3833	1.6994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 201 / 11 KV Billur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.2658	1.3565	1.326	1.5384	.1867	.2195
2		.2835	1.4918	1.4089	1.5384	.2195	.2378
3	.2267	.2865	1.4918	1.5746	1.5384	.2172	.2926
4	.2267	.3155	1.7404	1.8233	1.5384	.2926	.3292
5		.3224	1.7404	1.989	1.7004	.3292	.3544
6	.3401	.333	1.8233	2.1548	1.7814	.3658	.439
7	.3725	.3353	2.1548	2.4863	1.9433	.4525	.4024
8	.3401		2.1548	2.4863	2.2672	.2896	.1829
9	.2591		.1989	.3391	.4138	.2926	.1829
10			.2543	.2543	3.7723	2.0814	2.0119
11	2.2923	.2204	.2543	.2429	2.3529	2.4806	2.6337
12	2.652	.1696	.2543		2.3891	2.3101	
13	2.7069	.1696	.2035	.1943	1.949	2.3529	2.3529
14	2.5339	.1696	.2035	.1943	1.9185	2.009	
15	2.3838	.1357	.1696	.1943	2.0538	2.0119	2.1262
16	2.3529	.1357	.1696	.1619	2.1658	2.0814	
17	2.5606	.1357	.1696	.1943	2.2314	1.0349	1.9281
18	.3086	.1696	.3052	.1943	.2743	.181	.2321
19		.2543	.3391	.2591	.2743	.2715	
20		.2374	.3391	.2591	.2378	.3366	.2949
21	.2743	.2035	.2543	.2591	.2743	.2896	.2804
22	.2804	.1696	.2035	.2267	.2561	.2715	.2629
23	.2804	1.0174	.9945	1.2955	.2427	.2561	
24	1.888	.2629	1.1869	1.1603	1.5384	.2195	.2378
Max	2.7069	1.0174	2.1548	2.4863	3.7723	2.4806	2.6337
Min	.2267	.1357	.1696	.1619	.2378	.181	.1829
Avg	1.1845	.2663	.8106	.8991	1.5079	.8681	.7896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 202 / 11kv salmalgewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7004	1.6194	2.0119	1.829
2		1.7814	1.6194	2.4434	2.3529
3		1.7814	1.6194	2.8054	2.5339
4		2.0243	1.6194	2.9864	3.2579
5		2.1052	1.7814	3.2007	3.4389
6		2.1052	2.0405	3.3846	3.5837
7		2.5911	2.2672	.9955	2.2624
8		2.5911	2.2672	3.5656	3.3484
9		.4858	.4858	.4066	.3077
10		2.753	2.5625	2.3339	2.2624
11		3.2388	2.2916	2.652	
12		3.1417	2.4949	2.7149	
13		3.3036	2.6244	2.7073	
14		2.9797	2.8006	2.6244	
15		3.0445	2.6155	1.9909	
16		2.9797	2.2405	2.0538	
17		2.9797	2.8006	1.9909	
18		.2915		.5068	
19		.421		.543	
20		.421		.5973	
21		.3887	.4024	.5487	
22		.3563	.4108	.4525	
23		1.2308	.362	.905	
24	3.0521	2.8826	1.6194	1.8823	1.1765
Max	3.0521	3.3036	2.8006	3.5656	3.5837
Min	3.0521	.2915	.362	.4066	.3077
Avg	3.0521	1.9824	1.8355	1.9293	2.3958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 203 / 11 KV Wajrawad ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.004	1.4327	.1989	.2035	.2105	1.2936	1.3575
2		1.5061	.2035	.2035	.2105	1.4784	1.6461
3	1.1336	1.6461	.2035	.1696	.2105	1.6461	1.829
4	1.2146	1.6118	.2035	.2035	.2429	1.8099	2.0538
5		1.7013	.2543	.3052	.3239	2.2177	2.2405
6		2.3777	.3391	.373	.4049	2.3891	2.3167
7		2.6749	.4239	.4239	.421	3.1131	3.0544
8	1.1984		.4239	.4239	.421	3.1786	3.0769
9			.3391	.3391	.7587	.2896	.2195
10			1.8233	1.989	.563	.181	.1829
11	.3292	1.989	2.3205	2.672	.2743	.2353	.2012
12	.3224	1.6575	1.989	2.4615	.2743	.181	
13	.3155	1.8233	2.652	2.5587	.2195	.181	.2012
14	.2926	1.9062	2.652	2.5587	.2172	.1949	
15	.2715	1.989	2.652	2.0729	.181	.1848	.1341
16	.2172	1.9062	2.4863	2.2348	.181	.2033	
17	.1677	1.9062	2.652	2.2024	.2172	.1086	.1357
18	.2103	.1326	.2374	.3401	.181	.181	.2347
19		.2543	.3052	.2753	.2743	.2715	
20		.3052	.3391	.2915	.3547	.3439	.2683
21	.3189	.2543	.3391	.2429	.2896	.2402	.2686
22	.3292	.2035	.2543	.2105	.2715	.2743	.2561
23	1.1393	.2035	.2543	.1943	.7316	.905	
24	2.2024	1.4022	.2035	.2543	.2105	.9745	1.1888
Max	2.2024	2.6749	2.652	2.672	.7587	3.1786	3.0769
Min	.1677	.1326	.1989	.1696	.181	.1086	.1341
Avg	.6667	1.3754	.9896	.9668	.3185	.9199	1.0982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 205 / 11 kv Wajrwad Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.1052	.1294	.1478	.1086	.0724	.1267
2		.1097	.1109	.1294	.1086	.0724	.1086
3	.1086	.1267	.1294	.1294	.1086	.1086	.0905
4	.1086	.1433	.1294	.1294	.1448	.1267	.0905
5		.1646	.1848	.1848	.181	.1448	.1086
6	.2896	.3109	.2218	.2587	.2534	.181	.1629
7	.362	.3292	.2772	.3326	.2896	.3258	.181
8	.3077		.3696	.2772	.2715	.2896	.2172
9	.2172		.2772	.1848	.1991	.181	.2172
10			.2218	.1848	.1494	.1086	.181
11	.2229	.1848	.1848	.1267	.1448	.0724	.181
12	.2103	.1478	.1478	.1448	.1267	.1086	
13	.2149	.1294	.1294	.1448	.1267	.0724	.1109
14	.2507	.1478	.1294	.1448	.1086	.0747	
15	.2378	.1294	.1109	.1448	.112	.0732	.0732
16	.2481	.1187	.1109	.1448	.1307	.0724	
17	.2454	.1357	.1294	.1629	.1086	.0905	.0716
18	.2926	.1848	.1848	.181	.1867	.1448	.1772
19		.2543	.2402	.2534	.2896	.181	
20		.3052	.2772	.2353	.2926	.2534	.2561
21	.2835	.2772	.3326	.2172	.2241	.181	.2401
22	.2149	.2402	.2772	.181	.1267	.1448	.2195
23	.2172	.2218	.2218	.1448	.0905	.1307	
24	1.4575	.1372	.1848	.1848	.1086	.0724	.1097
Max	1.4575	.3292	.3696	.3326	.2926	.3258	.2561
Min	.0905	.1052	.1109	.1267	.0905	.0724	.0716
Avg	.2937	.1859	.1964	.1821	.1663	.1368	.1539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 206 / 11 kv Gugwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0351	.1696	.1696	.3239	.0362	.0543
2	.0324	.0366	.1696	.2035	.3239	.0543	.0366
3	.0324	.0362	.1696	.2035	.3239	.0549	.0362
4	.0486	.0549	.1696	.2543	.3563	.0549	.0549
5	.0486	.0549		.3391	.3887	.0543	.0549
6	.0648	.0366		.4239	.4534	.0362	.0549
7	.0972	.0648		.4239	.6154	.0549	.0549
8	.0648			.5087	.583	.0543	.0549
9	.4534			.0339	.2069	.0362	.0366
10				.0339	.6276	.4572	.543
11	.3155	.0509		.0324	.4668	.543	.5087
12	.3658	.0339		.0324	.5068	.5544	
13		.0339	.0339	.0324	.6335	.5792	.5487
14	.3506	.0339	.0339	.0324	.6535	.5792	
15	.4024	.0339	.0339	.0324	.5975	.362	.3239
16	.3429	.0332	.0339	.0324	.6722	.4024	
17	.3544	.0339	.0339	.0324	.4572	.543	.3429
18	.0549	.0339	.0339	.0324	.1109	.0362	.0328
19		.0339	.0339	.081	.0543	.0543	
20		.0509	.0509	.0648	.1092	.0543	.0492
21	.0351	.0509	.0509	.0648	.0543	.0362	.0351
22	.0366	.0509	.0339	.0486	.0543	.0543	.0351
23	.0351	.1696	.1696	.1943	.0532	.0362	
24	1.6613	.0351	.2543	.1696	.3239	.0366	.0543
Max	1.6613	.1696	.2543	.5087	.6722	.5792	.5487
Min	.0324	.0332	.0339	.0324	.0532	.0362	.0328
Avg	.2415	.0475	.0922	.1449	.3729	.1985	.1533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 201 / 11 KV SHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.5365	.4973	.4973	.1311	.1307
2	.1509	.1509	.57	.5304	.5636	.1311	.1307
3	.1509	.1509	.57	.5304	.6299	.1311	.1494
4	.1989	.2012	.6371	.6299	.7127	.1638	.1867
5	.2984	.3315	.8718	.8453	.7956	.2949	.3361
6	.4641	.4641	1.073	.9831	.9282	.4588	.5228
7	.5243	.5898	1.7604	1.6385	1.1271	.5735	.6161
8	.3932	.4588	2.0454	2.2024	1.3435	.426	.5228
9	.2984	.3481	.6036	.4588	.2683	.2458	.3361
10	.9945	.2347	.3113	.2321	1.2763	1.0322	1.0608
11	1.4746	.213	.2321	.2155	1.7436	1.6057	1.3592
12	1.6221	.213	.1989	.2321	1.8778	1.7532	1.3923
13	1.4582	.1966	.1658	.2012	1.8107	1.8351	1.5061
14	1.7368	.1966	.1638	.2012	1.7101	1.6876	1.4413
15	1.6876	.1966	.1326	.2012	1.6095	1.7859	1.3603
16	1.7204	.2294	.1966	.218	1.5592	1.8351	1.3117
17	1.9334	.2622	.1966	.2515		1.7368	1.2955
18	.2486	.2785	.2622	.2683	.1966	.2801	.3174
19	.3647	.3932	.3277	.3812	.2949	.3547	.4294
20	.3481	.3563	.3277	.3978	.3277	.3734	.3734
21	.3315	.2915	.2652	.3018	.2622	.3361	.3361
22	.2515	.2429	.2486	.2515	.1966	.2614	.2614
23	.1677	.4024	.4915	.4144	.1475	.1867	.2054
24	.1677	.1677	.503	.4915	.4641	.1311	.1509
Max	1.9334	.5898	2.0454	2.2024	1.8778	1.8351	1.5061
Min	.1509	.1509	.1326	.2012	.1475	.1311	.1307
Avg	.7141	.2800	.5288	.5240	.8845	.7396	.6555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 202 / 11 KV kashilingwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0335	.57	.5138	.5197	.0566	.0373
2	.0335	.0335	.5967	.547	.5197	.0377	.0373
3	.0335	.0335	.6133	.5967	.5533	.0566	.0373
4	.0335	.0335	.639	.5967	.5636	.0754	.056
5	.0663	.0663	.639	.6133	.5636	.0943	.0747
6	.116	.116	.6796	.6062	.5967	.1509	.1307
7	.1311	.1326	.8356	.8192	.6962	.1886	.168
8	.0995	.116	.9339	.9175	.7956	.1698	.1494
9	.0829	.0829	.037	.0663	.0671	.0943	.0747
10	.7625	.0503	.0566	.0663	.7956	.7459	.779
11	.9448	.0867	.0671	.0838	.9614	.9012	.9779
12	.9614	.1097	.0671	.1174	1.0814	.9503	1.0111
13	1.065	.0905	.0671	.1006	1.0814	1.0322	1.0526
14	1.1305	.0876	.0838	.1006	1.0486	.9012	.9555
15	1.1469	.1063	.0995	.1174	.9175	1.0322	.9717
16	1.1469	.0886	.0829	.1174	.8848	1.1469	.9717
17	1.1961	.0709	.116	.1006	.852	1.1633	.8421
18	.0671	.0934	.1311	.0671	.0934	.0934	.056
19	.0838	.1109	.116	.1174	.1307	.0934	.112
20	.0995	.1478	.0995	.116	.112	.112	.0934
21	.0829	.1109	.0838	.1006	.0934	.0934	.0934
22	.0503	.0739	.0838	.0838	.0754	.0747	.0934
23	.0503	.5304	.5243	.431	.0566	.056	.056
24	1.5078	.0335	.57	.5079	.431	.0566	.056
Max	1.5078	.5304	.9339	.9175	1.0814	1.1633	1.0526
Min	.0335	.0335	.037	.0663	.0566	.0377	.0373
Avg	.4552	.1016	.3247	.3127	.5621	.3907	.3703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 203 / 11 KV AWANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6299	.6133	.1848	.1989	.2241	.6133	.7377
2	.6299	.7127	.1848	.1823	.2241	.6464	.7377
3	.7127	.779	.1848	.1823	.2614	.6962	.7545
4	.779	.8122	.2587	.1658	.3326	.9503	.8551
5	1.094	.9945	.3326	.2984	.4435	1.3435	1.1401
6	1.326	1.2929	.5914	.4641	.5788	1.6876	1.3916
7	1.7695	1.5402	.6653	.4641	.6219	1.8842	1.9113
8	2.1628	1.5074	.4755	.3647	.4887	2.0153	2.2131
9	.4973	.2515	.3326	.2949	.3258	.3658	.3547
10	.2984	1.326	1.2936	1.4746	.2195	.2402	.2561
11	.3045	1.9498	2.1948	1.9334	.2195	.2033	.2012
12	.2353	1.9559	2.1948	1.9826	.2195	.2033	.2012
13	.1991	1.9006	1.9662	1.9757	.2195	.2033	.2195
14	.2195	1.7204	2.2283	2.1052	.2561	.2033	.1829
15	.2195	1.6907	1.9662	1.917	.2012	.2402	.2195
16	.2402	1.8564	2.3967	1.8842	.2155	.3142	.2195
17	.2402	1.7859	1.9662	1.9006	.2587	.2587	.2378
18	.2587	.2957	.1966	.2629	.3142	.3696	.3547
19	.462	.4805	.3277	.4477	.4435	.4435	.4668
20	.4572	.462		.4163	.462	.4066	.3734
21	.3292		.2984	.3258	.3326	.3174	.3361
22	.2614	.2378	.2486	.2534	.2801	.2614	.2829
23	.4527	.2012	.1989	.2402	.547	.6539	.5571
24	1.4575	.4641	.1848	.1989	.2218	.5801	.7042
Max	2.1628	1.9559	2.3967	2.1052	.6219	2.0153	2.2131
Min	.1991	.2012	.1848	.1658	.2012	.2033	.1829
Avg	.6349	1.0796	.9075	.8306	.3297	.6292	.6212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 204 / 11 Kv Walekhindi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0189	.0187	.0189	.0189	.0187
2	.0189	.0189	.0189	.0187	.0189	.0189	.0187
3	.0189	.0189	.0189	.0187	.0189	.0189	.0187
4	.0189	.0189	.0189	.0187	.0189	.0189	.0187
5	.0189	.0189	.0377	.0187	.0373	.0373	.0373
6	.037	.0373	.0377	.037	.0373	.056	.056
7	.0549	.0554	.0566	.0554	.0554	.056	.0747
8	.037	.0373	.0377	.037	.0373	.0373	.0373
9	.037	.0187	.0377	.037	.0373	.0373	.0373
10	.037	.0373	.0377	.037	.0373	.0373	.0183
11	.0187	.0373	.0187	.037	.0373	.0373	.0187
12	.0187	.0187	.0187	.0187	.0377	.0373	.0373
13	.0187	.0171	.0187	.0187	.0377	.0187	.0189
14	.0189	.0187	.0189	.0187	.0189	.0187	.0189
15	.0189	.0187	.0189	.0187	.0189	.0187	.0189
16	.0189	.0187	.0189	.0187	.0189	.0187	.0189
17	.0189	.0187	.0189	.0187	.0189		.0189
18	.0189	.0373	.037	.0373	.0187	.0373	.037
19	.0373	.0566	.0549	.0554	.0566	.0747	.0566
20	.056	.0566	.0366	.037	.0566	.056	.0377
21	.0373	.0377	.0366	.0373	.0377	.056	.0377
22	.0189	.0377	.037	.0373	.0377	.0373	.0189
23	.0189	.0189	.0187	.0189	.0189	.0187	.0189
24	.2761	.0189	.0189	.0187	.0189	.0189	.0187
Max	.2761	.0566	.0566	.0554	.0566	.0747	.0747
Min	.0187	.0171	.0187	.0187	.0187	.0187	.0183
Avg	.0372	.0288	.0288	.0287	.0313	.0341	.0297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 205 / 11 KV SHEGAON GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0943	.0739	.0747	.0934	.0934
2	.0747	.0747	.0943	.0739	.0747	.0934	.0934
3	.0747	.0747	.0943	.0739	.0747	.0934	.0934
4	.0747	.0747	.0943	.0739	.0747	.1307	.112
5	.1307	.1307	.1698	.1109	.1663	.1494	.168
6	.2033	.2033	.2241	.1294	.2033	.2427	.2241
7	.2402	.2587	.2614	.2195	.2218	.2427	.2801
8	.2218	.1848	.2054	.1646	.1663	.2033	.1867
9	.1848	.2033	.1867	.2378	.2033	.1715	.168
10	.1848	.2402	.2054	.2012	.1848	.2241	.128
11	.1848	.2054	.2218	.1848	.1478	.2054	.1294
12	.168	.1494	.1663	.1663	.1294	.2054	.1478
13	.1494	.168	.1478	.1663	.1294	.1307	.1294
14	.112	.1494	.1109	.1307	.1307	.1494	.1294
15	.112	.1494	.0934		.1494	.1307	.1478
16	.1494	.168	.1463	.1494	.1494	.112	.1478
17	.1478	.1494	.1646	.168	.2241	.1307	.2033
18	.1494	.2241	.2195	.2218	.2427	.2614	.2378
19	.3142	.2801	.2715	.2402	.2801	.2987	.2561
20	.2402	.2241	.2353	.2402	.1867	.2427	.2587
21	.2033	.168	.1646	.1494	.1867	.2241	.1886
22	.1294	.1307	.1109	.112	.1307	.168	.1698
23	.0747	.0943	.0739	.0747	.0934	.112	.0943
24	.3506		.0943	.0739	.0747	.0934	.112
Max	.3506	.2801	.2715	.2402	.2801	.2987	.2801
Min	.0747	.0747	.0739	.0739	.0747	.0934	.0934
Avg	.1646	.1644	.1605	.1494	.1542	.1712	.1625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 201 / 11 KV Umrani AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1			1.6194
2			1.6194
3			1.7004
4			1.7004
5			1.7814
6			1.8623
7			2.0972
8			2.3922
9			.2858
10			.0953
11		.1334	.0953
12		.0953	.0953
13		.0953	
14		.0953	
15		.0953	
16		.0953	
17		.0953	
18		.1334	
19		.2286	
20		.2286	
21		.1905	
22		.1715	
23		.6097	
24	1.6108		1.6194
Max	1.6108	.6097	2.3922
Min	1.6108	.0953	.0953
Avg	1.6108	.1744	1.3049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 202 / 11KV Khojanwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.915	2.3403	2.2405		.4108
2			2.915	2.3403	2.2405		.4108
3			2.9959	2.4006	2.2405		.4294
4			2.9959	2.6406	2.2405		.4668
5			3.0769	2.9473	2.5606		.5228
6			3.2388	3.2278	2.7206		.5975
7			3.4008	3.4408	3.0407		.5975
8			3.4818	3.5227	2.9927		.5975
9			.6283	.4572			.5228
10			.4435	.5487			2.3758
11		.695	.7023	.5544			
12		.7947	.7392	.5544			
13		.7392	.6767	.5487		2.9656	
14		.6653	.6584	.5304		2.9656	
15		.7023	.5487	.5853		2.9492	
16		.7207	.6584	.5853		2.7035	
17		.7392	.6767	.5853		2.9492	
18		.7762	.6099	.6584		.4572	
19		.7023	.6535	.6584		.5304	
20		.6838	.5975	.6584		.5304	
21		.6838	.5601	.5853		.5304	
22		.4251	.5601	.5853		.439	
23		1.9204	2.0241	1.829		.4207	
24	1.6289		2.915	2.2929	2.0805		.4294
Max	1.6289	1.9204	3.4818	3.5227	3.0407	2.9656	2.3758
Min	1.6289	.4251	.4435	.4572	2.0805	.4207	.4108
Avg	1.6289	.7883	1.6114	1.4616	2.4841	1.5856	.6692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 203 / 11 KV SINDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0373	.0366	.0549	
2			.0373	.0366	.0549	
3			.0373	.0366	.0549	
4			.0373	.037	.0549	
5			.0373	.0554	.0549	
6			.0373	.0934	.0732	
7			.0373	.0914	.0732	
8			.0373	.0366	.0732	
9			.0373	.0366	.0732	
10			1.0486	1.2651		
11		1.3927	1.3435	1.3603		
12		1.4091	1.3763	1.4575		
13		1.1469	1.3765	1.4091		.0366
14		1.1469	1.3927	1.3441		.0366
15		1.2452	1.3435	1.3441		.0366
16		1.2452	1.2955	1.3765		.0366
17		1.278	1.2289	1.3441		.0366
18		.0373	.0366	.0732		.0366
19		.0373	.0366	.0732		.0366
20		.0373	.0549	.0732		.0549
21		.0373	.0549	.0732		.0732
22		.0373	.0549			.0549
23		.0373	.0366	.0549		
24	1.6289		.0373	.0366	.0549	
Max	1.6289	1.4091	1.3927	1.4575	.0732	.0732
Min	1.6289	.0373	.0366	.0366	.0549	.0366
Avg	1.6289	.6991	.4605	.5107	.0622	.0439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 204 / 11 Kv Umrani Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0492	.0324	.0486		.0324
2			.0492	.0324	.0486		.0324
3			.0492	.0324	.0486		.0324
4			.0492	.0324	.0486		.0324
5			.0492	.0324	.0486		.0486
6			.0819	.0486	.0972		.0648
7			.0983	.0972	.0972		.081
8			.0492	.0486	.0648		.0648
9			.0328	.0328	.081		.0324
10			.0492	.0324			.0324
11		.0492	.0328	.0324			
12		.0328	.0328	.0324			
13		.0328	.0324	.0324		.0324	
14		.0328	.0324	.0324		.0324	
15		.0328	.0324	.0324		.0324	
16		.0328	.0324	.0324		.0324	
17		.0492	.0648	.0324		.0324	
18		.1638	.0648	.0486		.0324	
19		.1638	.0648	.0972		.0648	
20		.1638	.081	.1134		.0648	
21		1.4746	.0486	.1134		.081	
22		.0492	.0486	.0972		.0486	
23		.0492	.0324	.0486		.0324	
24	.2058		.0492	.0324	.0486		.0324
Max	.2058	1.4746	.0983	.1134	.0972	.081	.081
Min	.2058	.0328	.0324	.0324	.0486	.0324	.0324
Avg	.2058	.1790	.0503	.0500	.0632	.0442	.0442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 201 / 11 KV DEVANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.945	.3005	.2846	.3479	1.7078	1.8976	2.2138
2	2.2613	.3005	.2846	.3479	2.1348	1.9925	2.3878
3	2.372	.3005	.3163	.3479	2.1348	2.1348	2.3878
4	2.451	.3163	.3163	.3563	2.4036	2.372	2.4669
5	2.5143	.3321	.3479	.3479	2.7989	2.5459	2.5143
6	2.6408	.4111	.3795	.3563	2.9729	2.6092	2.5143
7	2.5459	.2688	.4902	.4428	3.0045		2.3087
8	2.5301	.4111	.4428	.3953	2.625	2.625	2.7831
9	.2688	.3479	.2846	.3163	.2372	.2214	
10	.1581	2.2771	2.4985	2.451	.2372	.2372	
11	.253	2.878	2.7831	2.9729	.2056	.2372	
12	.2846	2.878	2.8464	3.0045	.3005	.3005	
13	.2846	2.9096	2.7515	3.1626	.3005	.3005	
14	.2846	2.8464	2.8464	2.9729	.3005	.1898	
15	.2846	2.9412	2.9096	2.8147	.3321	.1898	
16	.3005	2.9096	2.9096	2.6092	.3321	.1898	
17	.2846	2.5934	1.7394	3.1626	.3321	.1898	.253
18	.2846	.3163	.1739	.3163	.253	.253	.2056
19	.3163	.3637	.4111	.2846	.253	.253	.2056
20	.4111	.3479	.4586	.2214	.253	.2846	.2846
21	.3795	.3479	.427	.253	.2846	.2846	.2372
22	.3163	.3479	.3795	.3163	.2846	.2846	.2214
23		.2846	.3795	.3795	1.6446	1.5813	1.6604
24	1.5813	.3005	.2846	.3795	.4428	1.7869	2.2138
Max	2.6408	2.9412	2.9096	3.1626	3.0045	2.625	2.7831
Min	.1581	.2688	.1739	.2214	.2056	.1898	.2056
Avg	1.0849	1.1471	1.1227	1.1900	1.0740	.9983	1.5536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 202 / 11 KV PACCHPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.0633	.0724	.0579	.5502	.5068	.5937
2	.5213	.0633	.0724	.0579	.5502	.5937	.7095
3	.5937	.0633	.0724	.0579	.6081	.7095	.7674
4	.7964	.0579	.0869	.0579	.6371	.8253	.8253
5	.8543	.0579	.0869	.0579	.8977	.8398	.8977
6	.8833	.0579	.0869	.0724	.695	.8833	.9556
7	.9556	.0724	.0869	.081	.9556		.9991
8	.9701	.0724	.0869		.7964	.7964	1.1149
9	.0579	.1014	.0724		.0579	.0434	.0869
10	.0579	.8109	.8109		.0579	.0724	.0579
11	.0579	1.0715	1.3279		.0579	.0724	.0434
12	.0579	.9991	1.2955		.0724	.0724	.0434
13	.0579	1.086	1.1584		.0724	.0579	.0434
14	.0579	.9846	1.0136		.0724	.0579	.0434
15	.0579	1.1873	.9846		.0724	.0579	.0434
16	.0579	1.1584	.9846		.0724	.0579	.0434
17	.0579	.8688	.724		.0434	.0579	.0579
18	.0724	.0869	.0724		.0869	.0724	.0579
19	.0869	.1158	.0579		.0869	.0724	.0579
20	.0724	.1303	.0579		.0724	.0724	.0579
21	.0579	.1014	.0579		.0724	.0579	.0579
22	.0579	.0724	.0579		.0579	.0579	.0579
23		.0579	.0579		.3909	.3909	.362
24	.362	.0579	.0724	.0579	.0724	.4199	.4344
Max	.9701	1.1873	1.3279	.081	.9556	.8833	1.1149
Min	.0579	.0579	.0579	.0579	.0434	.0434	.0434
Avg	.3148	.3916	.3941	.0626	.2962	.2978	.3505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 203 / 11 KV Rawalgundwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	1.4575	1.6518	1.5384	.2267	.2105	.2429
2	.2429	1.4575	1.7814	1.5384	.2267	.2105	.421
3	.2429	1.4899	2.0243	1.6194	.2267	.2429	.2591
4	.3725	1.5384	2.1052	1.7814	.2591	.2591	.2915
5	.3725	1.6194	2.1376	2.0243	.2915	.2915	.2915
6	.421	1.7328	2.2348	2.2672	.3563	.3239	.2915
7	.4534	2.4129	2.7206	2.8178	.4049		
8	.2591	2.8178	1.9757		.3887	.3887	
9	.2915	.1943	.3239		.3563	.3563	.2267
10	1.587	.2267	.2915		1.7814	1.6194	2.2996
11	2.5911	.1619			3.1093	2.1214	2.7368
12	2.9959				3.0769	2.2348	2.915
13	3.1093				2.2672	2.5425	2.7854
14	2.9959				2.4615	2.5911	2.6235
15	2.9312				2.753	2.3967	2.5587
16	2.9312				2.8502	2.4291	2.753
17	2.9312				3.0283	2.8826	2.6882
18	.2267	.3401	.3563		.2591	.2915	.1943
19	.3239	.3563	.4858		.2591	.2915	.2267
20	.3725	.3725	.4858		.3239	.3401	.2915
21	.3239	.3725	.4534		.3563	.3725	.2591
22	.3258	.3725	.3887		.3887	.421	.2267
23		1.4413	1.4413		.2105	.1943	.2267
24	.1943	1.4575	1.6518	1.4575	.2267	.2105	.2429
Max	3.1093	2.8178	2.7206	2.8178	3.1093	2.8826	2.915
Min	.1943	.1619	.2915	1.4575	.2105	.1943	.1943
Avg	1.1625	1.1012	1.3241	1.8806	1.0870	1.0097	1.1387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 204 / 11 kv Rawalgundwadi Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0724	.0362	.0543	.0724	.0362	.0543
2	.0543	.0724	.0362	.0543	.0724	.0362	.0543
3	.0543	.0724	.0362	.0724	.0724	.0543	.0543
4	.1086	.0724	.1086	.0905	.0905	.0905	.0724
5	.1086	.0724	.1448	.0905	.1086	.1267	.0905
6	.1086	.1086	.1629	.1086	.1448	.1267	.1267
7	.1629	.1629	.1629	.1448	.181		.1086
8	.1448		.1448		.1448	.1267	.1086
9	.181	.0905	.0724		.1267	.1086	.0724
10	.0905	.0905	.0543		.0905	.0905	.0724
11	.1086	.0724	.0362		.0724	.0905	.0724
12	.0905	.1086	.0362		.0905	.0905	.0905
13	.0905	.0905	.0543		.0724	.0724	.0724
14	.0905	.0724	.0724		.0724	.0905	.0362
15	.0905	.0724	.0724		.0724	.0905	.0543
16	.0724	.0543	.0724		.0724	.0905	.0724
17	.0905	.0905	.0724		.0905	.0905	.0724
18	.1086	.1448	.1086		.1086	.1448	.0724
19	.1991	.1448	.1629		.1086	.1629	.0724
20	.181	.1086	.181		.1448	.0905	.0905
21	.1448	.1086	.1448		.0724	.0905	.1267
22	.0724	.0724	.0724		.0724	.0724	.181
23		.0543	.0724		.0362	.0724	.0724
24	.3115	.0724	.0362	.0724	.0724	.0362	.0543
Max	.3115	.1629	.181	.1448	.181	.1629	.181
Min	.0543	.0543	.0362	.0543	.0362	.0362	.0362
Avg	.1182	.0905	.0897	.0860	.0943	.0905	.0815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 205 / 11 kv Pachhapur Amrutwadi
gav Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0181	.0181	.0181	.0181	.0181	.0181
2	.0181	.0181	.0181	.0181	.0181	.0181	.0181
3	.0181	.0181	.0181	.0181	.0181	.0181	.0181
4	.0543	.0181	.0362	.0181	.0181	.0362	.0362
5	.0543	.0181	.0362	.0181	.0181	.0362	.0362
6	.0724	.0362	.0362	.0362	.0543	.0362	.0543
7	.0543	.0724	.0543	.0724	.0543		.0543
8	.0724	.0543	.0362		.0362	.0362	.0543
9	.0362	.0181	.0181		.0181	.0362	.0181
10	.0181	.0362	.0181		.0181	.0181	.0362
11	.0181		.0181		.0181	.0181	.0181
12	.0181	.0181	.0181		.0181	.0181	.0181
13	.0181	.0181	.0181		.0181	.0181	.0181
14	.0181	.0181	.0181		.0181	.0181	.0181
15	.0181	.0181	.0181		.0181	.0181	.0181
16	.0181	.0181			.0181	.0181	.0181
17	.0181	.0181	.0181		.0181	.0181	.0181
18	.0181	.0724	.0181		.0181	.0362	.0181
19	.0905	.0543	.0543		.0362	.0362	.0181
20	.1086	.0362	.0724		.0543	.0362	.0181
21	.1086	.0362	.0543		.0543	.0362	.0181
22	.0362	.0181	.0543		.0543	.0362	.0181
23		.0181	.0181		.0181	.0181	.0181
24	.0181	.0181	.0181	.0181	.0181	.0181	.0181
Max	.1086	.0724	.0724	.0724	.0543	.0362	.0543
Min	.0181	.0181	.0181	.0181	.0181	.0181	.0181
Avg	.0401	.0291	.0299	.0272	.0272	.0260	.0249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 201 / 11 KV Kosari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4801	.1543	.2401	.1543	.4572	.5658
2	.583	.5144	.1543	.2229	.1543	.4572	.5658
3	.583	.5144	.1715	.2229	.1715	.6097	.5658
4	.6001	.5144	.1715	.2401	.1715	.7202	.6001
5	.6859	.583	.2058	.2572	.1886	.7202	.7888
6	.7888	.7202	.2743	.3086	.2743	.8402	.9431
7	1.1145	1.2384	.3086	.3944	.2915	1.6004	1.1831
8	1.2689	1.4289	.3086	.3601	.2915	1.6766	1.5261
9	.2915	.1886	.2572	.3258	.2743	.1886	.2743
10	.2915	1.0288	.9602	.9602	.2572	.2572	.2572
11	.0551	1.3889	1.3717	1.3717	.3239	.2229	.2743
12	.3239	1.6632	1.4575	1.5261	.2858	.2572	.2743
13	.381	1.8004	1.2517	1.749	.3048	.2572	.2743
14	.381	1.3717	1.5261	1.7147	.3048	.2401	.2743
15	.381	1.5604	1.6118	1.5775	.3239	.2401	.2743
16	.381	1.5775	1.5261	1.6118	.3429	.2572	.2915
17	.381	1.5947	1.5604	1.5947	.3429	.3086	.2915
18	.2743	.1543	.2229	.2401	.3429	.3086	.3258
19	.2743	.2401	.3086	.2572	.3429	.3086	.3429
20	.3086	.2229	.3258	.2401	.3086	.3086	.2915
21	.2572	.2229	.2915	.2229	.1829	.2572	.2401
22	.2401	.2058	.2572	.2058	.1829	.2229	.2229
23	.3772	.1715	.2401	.1543	.3048	.4115	.3601
24	1.9033	.4458	.1543	.2401	.1543	.381	.5487
Max	1.9033	1.8004	1.6118	1.749	.3429	1.6766	1.5261
Min	.0551	.1543	.1543	.1543	.1543	.1886	.2229
Avg	.5288	.8263	.628	.6766	.2616	.4796	.4815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 202 / 11 KV Kumbharwadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1715	.703	.7202	.6516	.1524	.1886
2	.1543	.1372	.7888	.7716	.703	.1524	.1886
3	.1543	.1372	.8916	.7716	.7888	.1829	.1886
4	.1543	.2058	.9945	.7716	.8402	.2058	.1886
5	.2401	.2401	1.1488	.9774	.9259	.2401	.2229
6	.3258	.3086	1.3546	1.2517	1.1145	.3429	.3258
7	.463	.4763	1.9033	1.7833	1.4403	.4954	.4801
8	.4458	.381	2.1434	2.1434	1.5432	.4382	.463
9	.2743	.3429	.2401	.2572	.2401	.3429	.2572
10	1.5432	.2058	.1715	.2058	1.2517	1.286	1.046
11	1.7147	.2058	.1886	.1886	2.0195	1.8519	1.749
12	2.3243	.2058	.2058	.2058	2.3243	2.1776	1.8861
13	2.4768	.2058	.2058	.1886	2.0005	1.989	2.0233
14	2.572	.2058	.2229	.1715	1.9624	1.9376	1.9719
15	2.5911	.2229	.2572	.2058	1.9624	1.869	1.9719
16	2.5911	.2058	.2229	.2058	2.1719	1.6289	1.8861
17	2.5911	.2058	.1886	.1886	2.0386	1.8347	1.6118
18	.1829	.1886	.2058	.1886	.2286	.1886	.1886
19	.2286	.3429	.2743	.2915	.3048	.3086	.3086
20	.3086	.3258	.2743	.2743	.2743	.3258	.2915
21	.2229	.2401	.2572	.2229	.1829	.2572	.2058
22	.2058	.2229	.1886	.2058	.1677	.2058	.1886
23	.1715	.5144	.4973	.5144	.1524	.1886	.1372
24	1.6804	.1715	.6173	.6859	.6001	.1524	.1886
Max	2.5911	.5144	2.1434	2.1434	2.3243	2.1776	2.0233
Min	.1543	.1372	.1715	.1715	.1524	.1524	.1372
Avg	.9905	.2529	.5894	.5580	1.0787	.7814	.7566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 203 / 11 KV Birnal GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0514	.0514	.0457	.0514
2	.0514	.0343	.0686	.0514	.0514	.0457	.0514
3	.0514	.0343	.0686	.0514	.0514	.0762	.0514
4	.0514	.0857	.0686	.0514	.0686	.1029	.0514
5	.0857	.0857	.0857	.0686	.0857	.1029	.0857
6	.12	.12	.12	.1372	.12	.2915	.1372
7	.2058	.2286	.2058	.1715	.2058	.2096	.1886
8	.1886	.1715	.1715	.1715	.1715	.1905	.1886
9	.1372	.1372	.12	.1372	.1372	.1543	.1543
10	.12	.1543	.1715	.1543	.12	.12	.1372
11	.12	.12	.1715	.12	.1524	.1029	.1543
12	.1334	.1029	.12	.12	.1143	.1029	.1372
13	.1334	.1029	.0857	.1372	.1143	.1029	.12
14	.1334	.1029	.1029	.0857	.1334	.1029	.0857
15	.1334	.1029	.12	.0857	.1143	.1029	.0857
16	.1524	.1029	.12	.1029	.1143	.1029	.1029
17	.1905	.1029	.1543	.12	.1143	.1372	.1543
18	.1677	.1543	.1372	.1543	.1524	.1372	.1543
19	.1829	.2058	.2058	.1543	.1524	.1886	.2229
20	.2058	.2058	.2229	.1886	.1715	.1715	.1886
21	.12	.1372	.12	.1029	.0914	.12	.12
22	.1029	.12	.0857	.0857	.0762	.0857	.1029
23	.0686	.0686	.0514	.0686	.061	.0686	.0514
24	1.6803	.0514	.0514	.0514	.0514	.0457	.0514
Max	1.6803	.2286	.2229	.1886	.2058	.2915	.2229
Min	.0514	.0343	.0514	.0514	.0514	.0457	.0514
Avg	.1912	.1160	.1200	.1093	.1115	.1213	.1179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 204 / 11 KV Dhawadwadi GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0343	.0343	.0343	.0514	.0305	.0343
2	.0171	.0343	.0343	.0343	.0514	.0305	.0343
3	.0171	.0514	.0343	.0343	.0514	.0457	.0343
4	.0343	.0514	.0514	.0514	.0514	.0686	.0343
5	.0343	.0514	.0857	.0686	.0686	.0686	.0514
6	.0686	.0686	.1029	.0857	.0857	.12	.0857
7	.0857	.12	.12	.0857	.1029	.1143	.1029
8	.12	.0686	.0686	.0857	.0686	.0762	.1029
9	.0857	.0686	.0514	.0343	.0686	.0686	.0514
10	.0686	.0514	.0343	.0514	.0514	.0343	.0514
11	.0514	.0343	.0343	.0343	.0343	.0343	.0343
12	.0514	.0343	.0171	.0343	.0381	.0343	.0343
13	.0572	.0343	.0343	.0343	.0381	.0343	.0343
14	.0572	.0343	.0343	.0171	.0381	.0171	.0343
15	.0381	.0343	.0343	.0343	.0381	.0171	.0343
16	.0381	.0343	.0343	.0171	.0381	.0514	.0343
17	.0572	.0857	.0343	.0343	.0381	.0343	.0343
18	.0953	.0686	.0686	.0514	.0572	.0514	.0514
19	.0914	.1029	.0857	.0857	.0572	.0857	.1029
20	.1067	.1029	.1029	.0857	.0857	.1029	.0857
21	.0686	.0857	.0857	.0686	.061	.0857	.0686
22	.0514	.0857	.0514	.0686	.0762	.0514	.0686
23	.0343	.0514	.0514	.0343	.0305	.0514	.0343
24	.2401	.0343	.0343	.0514	.0514	.0305	.0343
Max	.2401	.12	.12	.0857	.1029	.12	.1029
Min	.0171	.0343	.0171	.0171	.0305	.0171	.0343
Avg	.0661	.0593	.0550	.0507	.0556	.0558	.0529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 205 / 11 KV Hivare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.7202	.6859	.6344	.1219	.0857
2	.1372	.12	.8059	.703	.6687	.1219	.0857
3	.1372	.12	.8745	.7202	.7202	.1219	.0857
4	.1543	.1372	.9602	.7202	.7716	.1715	.0857
5	.1715	.1543	1.0631	.8059	.8059	.1715	.1372
6	.2401	.2229	1.2689	1.0117	.9945	.2401	.2058
7	.3429	.3086	1.8347	1.5775	1.4403	.381	.3086
8	.3429	.2572	2.1434	1.989	1.6118	.3048	.2743
9	.2401	.2572	.2229	.2572	.1372	.2229	.1715
10	1.3717	.1372	.1886	.1029	1.0631	1.3032	.9602
11	1.7147	.1886	.12	.12	1.7833	1.8176	1.5775
12	2.0576	.1372	.1543	.12	2.0957	1.8861	1.8347
13	2.2862	.1029	.1029	.1543	2.1338	2.0233	1.8861
14	2.2862	.1029	.12	.1543	2.1719	1.9719	1.7661
15	2.2862	.12	.1372	.1715	2.1148	1.6289	1.6118
16	2.2291	.1372	.1543	.1886	2.1338		1.6461
17	2.2291	.1886	.2229	.1886	2.0767	1.8176	1.5775
18	.1677	.1372	.2058	.1886	.1905	.1886	.1372
19	.1829	.2058	.2401	.2229	.1905	.2058	.2229
20	.2229	.2401	.2229	.2229	.1886	.1886	.2229
21	.2058	.2058	.2058	.1886	.1524	.1715	.1886
22	.1886	.1715	.1715	.1715	.12	.1372	.1715
23	.1372	.463	.5658	.5144	.1219	.0857	.1372
24	1.5947	.1372	.6516	.6859	.5658	.1219	.0857
Max	2.2862	.463	2.1434	1.989	2.1719	2.0233	1.8861
Min	.1372	.1029	.1029	.1029	.12	.0857	.0857
Avg	.8777	.1829	.5566	.4944	1.0370	.6698	.6444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 206 / 11 KV Pratapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.5487	.0686	.0514	.0514	.7621	.823
2	.7716	.5144	.0686	.0514	.0514	.7621	.823
3	.7888	.5144	.0686	.0514	.0514	.9145	.823
4	.8059	.6859	.0857	.0514	.0514	1.0631	.8573
5	.8745	.823	.0857	.0514	.0686	1.0631	1.1317
6	1.0288	.9259	.1029	.0857	.0857	1.2346	1.2346
7	1.3203	1.4403	.1372	.1372	.1372	1.9433	1.5947
8	1.5604	1.5604	.1029	.1029	.12	2.0386	1.9376
9		.1543	.0686	.0686	.0686	.1543	.0857
10		1.0974	1.1317		.0686	.0686	.0686
11		1.4746	1.5089		.0686	.0857	.0514
12		1.8519	1.5947	1.4746	.0762	.0857	.0514
13		1.7661	1.2689	1.6975	.0762	.0686	.0514
14		1.5432	1.8176	1.8519	.0572	.0514	.0514
15		1.6289	1.6975	1.7661	.0572	.0514	.0686
16		1.6118	1.5604	1.4746	.0762	.0686	.0686
17		1.5604	1.6804	1.5432	.0762	.0686	.0686
18		.0857	.0514	.0514	.0953	.0514	.0686
19		.12	.1029	.0857	.1143	.0857	.1029
20		.12	.0857	.0857	.1334	.1029	.1029
21		.1029	.0857	.0857	.0914	.0857	.0857
22		.0857	.0686	.0686	.0667	.0686	.0686
23		.0686	.0514	.0514	.3048	.7202	.6687
24	2.4596	.6001	.0686	.0514	.0514	.6097	.823
Max	2.4596	1.8519	1.8176	1.8519	.3048	2.0386	1.9376
Min	.7716	.0686	.0514	.0514	.0514	.0514	.0514
Avg	1.1535	.8702	.5651	.4972	.0875	.5087	.4880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 201 / 11 KV JIRGYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1105	.9945	.2096	.1905	.1524	1.2431	1.2146
2	1.1105	1.1934	.2096	.1905	.1524	1.2431	1.2146
3	1.1105	1.4089	.1905	.1905	.1524	1.2431	1.2146
4	1.1603	1.4918	.1905	.1905	.1905	1.4089	1.3765
5	1.3117	1.7404	.2858	.2858	.2286	1.6907	1.6194
6	1.8056	1.8564	.381	.3429	.3429	1.989	1.9757
7	2.5926	2.4577	.381	.381	.4382	2.8837	2.8016
8	2.8549	2.8018	.4382	.381	.362		2.3644
9	.381	.2477	.2858	.2477	.2667	.2858	.2858
10	.2477	2.1464	1.8623	1.9925	.1715	.2286	.1905
11	.1905	2.7362	2.834	2.9254	.1143	.1524	.1334
12	.1524	2.6871	2.834	3.0045	.0953	.1143	.1334
13	.1715	2.6379	2.753	2.8306	.0953	.1143	.1334
14	.1143	1.8187	2.753	2.6707	.1143	.1143	.1334
15	.1524	2.2447	2.3482	2.13	.0762		.1524
16	.1715	2.3266	2.834	2.4577	.1334		.1524
17	.1905	2.3758	2.9959	2.6543	.1143		
18	.2096	.1334	.1905	.1524	.1715		.1905
19	.3429	.3429	.2858	.3239	.3239	.2286	.381
20	.3429	.2477	.2858	.3048	.3048	.362	.381
21	.2477	.2477	.2858	.2477	.2477	.362	.2477
22	.2286	.2096	.2286	.2286	.2286	.2096	.1905
23	.5967	.2096	.1905	.1524	.663	.7287	.5668
24	.6962	.9116	.2096	.1905	.1524	1.1603	1.1336
Max	2.8549	2.8018	2.9959	3.0045	.663	2.8837	2.8016
Min	.1143	.1334	.1905	.1524	.0762	.1143	.1334
Avg	.7289	1.4779	1.0610	1.0278	.2205	.8296	.7907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 202 / 11 KV SHINGANAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2286	.3239	.2753	.2315	.1715	.1524
2	.1715	.2286	.4049	.2753	.2315	.1715	.1524
3	.1715	.2286	.4049	.2753	.2315	.1715	.1524
4	.1715	.2286	.4049	.2753	.3315	.1905	.1905
5	.2286	.2477	.4372	.3239	.3315	.2477	.2858
6	.3048	.3239	.5506	.4858	.4144	.3048	.3429
7	.362	.4001	.8097	.8907	.6299	.381	.3429
8	.381	.3429	.9717	.9717	.8619	.3239	.3239
9	.2477	.2477	.2858	.381	.2667	.2477	.2858
10	.5138	.2477	.2858	.2858	.7956	.4534	.4687
11	1.065	.2477	.2858	.2858	1.0774	.7773	.7287
12	1.1961	.2667	.2858	.3048	.9945	.9393	.7287
13	1.1633		.2858	.2667	1.065	.9231	.9717
14	.9282		.2477	.2286	1.0159		.9717
15	1.0814		.2286	.2477	1.0814		.9717
16	1.1271		.3239	.2286	1.065		.8907
17	1.065		.2858	.3048	1.0111		.8907
18	.2858		.2858	.2667	.1524		.2286
19	.3429	.362	.381	.3048	.2858	.2858	.3429
20	.3239	.2858	.381	.3239	.3239	.3048	.381
21	.2858	.2477	.2858	.3048	.2858	.2858	.2858
22	.2477	.2667	.2477	.2286	.2286	.2286	.2286
23	.2286	.2267	.2105	.1852	.1905	.1905	.2286
24	.1715	.2286	.2591	.2753	.2315	.1715	.1524
Max	1.1961	.4001	.9717	.9717	1.0814	.9393	.9717
Min	.1715	.2267	.2105	.1852	.1524	.1715	.1524
Avg	.5098	.2698	.3697	.3415	.5556	.3563	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 203 / 11 KV JIRGYAL GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0762	.0572	.0572
2	.0572	.0572	.0572	.0572	.0762	.0572	.0572
3	.0572	.0572	.0572	.0572	.0762	.0572	.0572
4	.0572	.0572	.0572	.0572	.0762	.0572	.0572
5	.0953	.0762	.0762	.0762	.0953	.0762	.0762
6	.1334	.1143	.0953	.1143	.1334	.1143	.0953
7	.1334	.1334	.1143	.1715	.1524	.1524	.1524
8	.1334	.1334	.1334	.1524	.1524	.1334	.1334
9	.1524	.1334	.1334	.0953	.1143	.0953	.0953
10	.0953	.0762	.0953	.1143	.0953	.0953	.0762
11	.1143	.1334	.0953	.0762	.0572	.0762	.0572
12	.1143	.0572		.0762	.0762	.0953	.0572
13	.1143	.0953	.0953	.0762	.0762	.0762	.0572
14	.0953	.0762	.1143	.0572	.0762	.0381	.0572
15	.0953	.0572	.0953	.0762	.0762		.0762
16	.0953	.0762	.1143	.0953	.0762		.0762
17	.0953	.0953	.1143	.0762	.0762		.0572
18	.1334	.1334	.1524	.1524	.1143		.0572
19	.1905	.1715	.1905	.1715	.1524	.1334	.1905
20	.1715	.1524	.1905	.1715	.1715	.1524	.1905
21	.1524	.1143	.1334	.1143	.1334	.1334	.1143
22	.1143	.0953	.1143	.0953	.0953	.0953	.0762
23	.0953	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0572	.0572	.0572	.0762	.0572	.0572
Max	.1905	.1715	.1905	.1715	.1715	.1524	.1905
Min	.0572	.0572	.0572	.0572	.0572	.0381	.0572
Avg	.1096	.0953	.1052	.0969	.0992	.0915	.0858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 204 / 11 KV EKUNDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.3048	.4096	.4858	.9282	.2477	.2667
2	.2858	.3048	.4096	.4858	.3978	.2477	.2667
3	.2858	.3239	.4096	.4858	.4144	.2477	.2667
4	.3429	.362	.4096	.4858	.4144	.3048	.2667
5	.381	.4191	.4915	.5668	.4572	.362	.381
6	.5144	.4763	.6554	.6478	.7011	.4763	.4572
7	.5335	.4954	.9831	1.0526	.945	.5144	.5144
8	.4382	.4001	1.1961	1.1336	.9755	.4001	.4954
9	.4763	.3429	.2858	.3239	.3239	.3239	.4763
10	.6299		.381	.3239	.7537	.7537	.5668
11	1.004	.381	.2858	.2667	.9175	1.0978	
12	1.1822	.3429		.1715	.9614	1.2125	.8907
13	1.1822	.381		.1905	.9503	1.1469	.8907
14	1.0978	.3048	.2286	.2096	.8684	1.0486	.8907
15	1.004	.3048	.381	.1905	1.0159		.8907
16	.9831	.2477	.381	.2286	.9831		.8097
17	1.085	.3048	.381	.3239	.9995	1.0486	.8097
18	.2858	.2477	.4382	.3239	.2667	.2286	.2477
19	.4954	.2858	.381	.4382	.4001	.381	.4191
20	.4763	.2858	.381	.4382	.4191	.4191	.381
21	.4001	.362	.2858	.3239	.3429	.4191	.3429
22	.3239	.2667	.2858	.2858	.2858	.3048	.2858
23	.3048	.3277	.4049	.3481	.2667	.2667	.2858
24	.2858	.3048	.4096	.4372	.3978	.2477	.2667
Max	1.1822	.4954	1.1961	1.1336	1.0159	1.2125	.8907
Min	.2858	.2477	.2286	.1715	.2667	.2286	.2477
Avg	.5952	.3381	.4489	.4237	.6411	.5318	.4943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 201 / 11KV WALEKHINDI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	1.5927
Max	1.5927
Min	1.5927
Avg	1.5927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 202 / 11KV BEVNOOR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	1.6617
Max	1.6617
Min	1.6617
Avg	1.6617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 201 / 11 Kv Basargi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	1.643
Max	1.643
Min	1.643
Avg	1.643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 202 / 11 Kv Basargi Gavtaon
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18
HR	Load (MW)
24	.181
Max	.181
Min	.181
Avg	.181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 203 / 11 KV Sindur Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	1.6289
Max	1.6289
Min	1.6289
Avg	1.6289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 201 / 11 KV TIPPEHALLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	1.3565
Max	1.3565
Min	1.3565
Avg	1.3565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 203 / 11 KV MALLAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 204 / 11 KV Jath

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 205 / 11 KV Rampur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	1.166
Max	1.166
Min	1.166
Avg	1.166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 206 / 11 KV Achakanhalli AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	1.4413
Max	1.4413
Min	1.4413
Avg	1.4413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 207 / 11 KV SUGAR FACTORY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	.1052
Max	.1052
Min	.1052
Avg	.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 208 / 11 kv Achakanhallii Gav
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18
HR	Load (MW)
24	.12
Max	.12
Min	.12
Avg	.12

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 209 / 11 Kv JATH West

Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	01-FEB-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 201 / 11KV K. MAHANKAL GAO
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6219	.5853	.695	.6401	.6401	.695
2	.5853	.6401	.5487	.695	.6036	.6036	.6584
3	.6401	.695	.5853	.6401	.5853	.6584	.6584
4	.695	.7316	.6584	.6401	.6584	.695	.6219
5	.7316	.7682	.7133	.6401	.7133	.7682	.7682
6	.8596	.8596	.8048	.7316	.823	.8779	.8596
7	1.134	1.0425	1.0791	.9511	1.0791	1.0974	1.1888
8	1.2437	1.0974	1.0608	1.0242	1.134	1.0608	1.1706
9	.9694	1.0974	.9511	.9328	.9877	1.0242	1.0425
10	1.1888	1.0242	.9328	.8596	.9511	.9877	.9511
11	.8413	1.0059	.9511	.8779	.8596		.8779
12	.9145	.9877	.9694	.8779	.8779		.8779
13	.8596	.9145	.9328	.8413	.8048		.9145
14	.8596	.8413	.8779		.7316		.7499
15	.823	.8048	.8779	.7316	.7865		
16	.8413	.7865	.8962	.7316	.7682	1.2803	
17	.8962	.8413	.8048		.823	1.0059	1.0242
18	.9511	.9145	.9511	.9511	1.0974	1.0791	1.0974
19	1.2254	1.2254	1.0425	1.2254	1.2254	1.2437	1.4815
20	1.0425	1.1706	1.134	1.134	1.2437	1.3535	1.2986
21	1.0425	1.0425	1.0242	.9877	.9877	1.134	.9877
22	.9145	.823	.8596	.8413	.8962	.9877	.7316
23	.695	.6401	.7865	.6767	.6767	.8413	.5853
24	.6219	.6584	.6036	.7316	.6584	.6584	.695
Max	1.2437	1.2254	1.134	1.2254	1.2437	1.3535	1.4815
Min	.5853	.6219	.5487	.6401	.5853	.6036	.5853
Avg	.8825	.8848	.8596	.8372	.8589	.9472	.9062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 202 / 11KV KUCHI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.788		1.1462
2	.7701		1.2178
3	.8596		1.3611
4	.8954		1.5043
5	1.0029		1.5043
6	1.2178		1.6476
7	1.6118		2.0416
8	2.0058		2.4535
9	.2686		.2328
10	.1791	.197	.197
11			.197
12			.1791
13			.2149
14			.1612
15			.1791
16		.1612	
17		.2328	.1097
18		.2686	.2149
19		.2507	.2328
20		.2507	.2149
21		.2328	.197
22		.1612	.1791
23		1.0387	
24	.8059		1.0745
Max	2.0058	1.0387	2.4535
Min	.1791	.1612	.1097
Avg	.9459	.3104	.7482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 203 / 11 KV HINGANGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394	.3582	.7343	1.0029	.7164	.3582	.4119
2	.3761	.3761	.7164	1.0387	.6984	.394	.4119
3	.3582	.4119	.788	1.0387	.788	.394	.394
4	.3761	.4119	.8954	1.1104	.8596	.4119	.4119
5	.4119	.4298	1.0924	1.1462		.4119	.4298
6	.4477	.4477	1.2536	1.1999	1.0208	.4477	.4477
7	.4656	.4656	1.6118	1.4685	1.4148	.4835	.4835
8	.4835	.4477	2.1849	1.9163	1.7372	.4477	.4656
9	.4477	.4298	.4119	.4477	.394	.4298	.4656
10	1.7193	.4298	.4298	.4656	2.0237	1.9342	2.1399
11	2.4714	.4298	.4298	.4477	2.1491		2.3228
12	2.5431	.4298	.4477	.4835	2.2028		2.4691
13	2.5789	.4477	.4477		2.2744		2.4508
14	2.5789	.4477	.4477		2.2028		2.3411
15	2.3282	.4298	.4656	.4298	2.1491		2.3411
16	2.3282	.4477	.4477	.4477	2.2207	1.9521	2.1399
17	.4119	.4119	.4477	.4298	2.1491	2.758	2.2862
18	.4119	.4656	.4477	.4119	.3761	.4119	.439
19	.4656		.4477	.4835	.2686	.4477	.4656
20	.4119		.4656	.4656	.4477	.4656	.4656
21	.4119		.4477	.4656	.394	.4477	.4298
22	.4119	.4298	.4119	.4119	.4298	.4298	.394
23	.394	.7701	.9492	.7522	.394	.4119	.4119
24	1.065	.3761	.7522	.9313	.7343	.3761	.394
Max	2.5789	.7701	2.1849	1.9163	2.2744	2.758	2.4691
Min	.3582	.3582	.4119	.4119	.2686	.3582	.394
Avg	1.0122	.4426	.7156	.7725	1.2194	.7060	1.0589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 204 / 11KV RANJANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9134	.8059	.197	.2149	.2149	.9134	1.0566
2	.8954	.8954	.197	.197	.2149	1.0029	1.1104
3	.9671	.9492	.1791	.197	.197	1.1104	1.1462
4	1.0745	1.0745	.2149	.197	.2507	1.2536	1.2178
5	1.2894	1.1462	.3045	.3045	.3045	1.4685	1.5043
6	1.4506	1.3432	.394	.3761	.3582	1.6834	1.7551
7	2.0595	1.7909	.5194	.4119	.4656	2.3282	2.6326
8	4.7996	2.0237	.4298	.3582	.4119	2.8296	3.0266
9	.7522	.2686	.3582	.3403	.2686	.3582	.3224
10	.573	7.3068	1.8983	1.9521	.3224	.2865	.197
11	.6448	2.4714	2.8296	2.4535	.3582		.2686
12	.573	2.5252	3.0445	2.6326	.3761		.2328
13	.6448	1.9342	2.9729	2.4177	.3761		.2865
14	.7164	2.1312	2.5968		.2507		.2686
15	.6448	2.0953	2.561	2.4893	.2328		.2865
16	.6448	2.1491	2.5072	2.5252	.394	.3761	.3582
17	.6806	2.4356	2.4714	2.4714	.4119	.2507	.3403
18	.788	.3045	.2865	.3224	.4477	.4119	.4477
19	.967	.4298	.3224	.5014	.5014	.394	.4656
20	.7164	.4298	.394	.4477	.4835	.4298	.3761
21	.5194	.394	.3403	.3582	.394	.3761	.3224
22	.5372	.2865	.2686	.2686	.2865	.2686	.3403
23	1.6834	.2328	.2328	.2507	.9671	1.0029	.8775
24	.9313	.8417	.2149	.2149	.2328	.9313	1.0208
Max	4.7996	7.3068	3.0445	2.6326	.9671	2.8296	3.0266
Min	.5194	.2328	.1791	.197	.197	.2507	.197
Avg	1.0611	1.5111	1.0723	.9523	.3634	.9303	.8275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 205 / 11KV LANGERPETH AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1254		.1433
2	.1254		.1433
3	.1433		.1612
4	.1612		.1612
5	.197		.197
6	.2328		.2328
7	.3224		.2686
8	.2865		.2865
9	.2149		.2507
10	1.9342	2.0058	2.3461
11			2.4893
12			2.5968
13			2.6505
14			2.5789
15			2.3411
16		3.0445	2.3282
17		2.7759	2.3411
18		.197	.2149
19		.2328	.2507
20		.2507	.2149
21		.2149	.1791
22		.1791	.1612
23		.1791	.1433
24	.1433		.1433
Max	1.9342	3.0445	2.6505
Min	.1254	.1791	.1433
Avg	.3533	1.0089	.951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 206 / 11KV S.FACTORY AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0029	.8417	.1254	.1254	.1254	1.0387	1.1462
2	.9671	.9313	.1075	.1254	.1254	1.1641	1.2178
3	1.0566	1.0387	.1254	.1254	.1254	1.2894	1.3432
4	1.1462	1.1104	.1612	.1612	.1433	1.3969	1.4685
5	1.2894	1.1462	.197	.1791	.1791	1.4685	1.5581
6	1.5581	1.2715	.2507	.2507	.2686	1.6834	1.7558
7	1.97	1.6476	.3224	.2865	.3045	2.3819	2.0774
8	2.1849	1.7551	.2507	.2686	.2865	.3582	2.5072
9	.2149	.2328	.2507	.2507	.2686	.0716	.2686
10	.1791	1.6834	2.0237	2.0595	.1612	.0358	.2012
11	.2328	2.1132		2.2386	.197		.1646
12	.1791	2.1491	2.2565	2.3998	.1791		.1463
13	.1612	1.8804	2.2744		.1612		.1463
14	.1612	1.9521	2.2744		.1254		.1829
15	.1433	2.0058	2.3282	2.3998	.1254		.1829
16	.1612	2.0774	2.364	2.3282	.1433	.0179	.1829
17	.2149	.2328	2.1312	2.8654	.1791	.0358	.1829
18	.1791	.2328	.1612	.197	.2149	.3045	.2378
19	.2328	.2865	.197	.2686	.2686	.2865	.2926
20	.1791	.2507	.2507	.2507	.2507	.2686	.2561
21	.2149	.2328	.2149	.2149	.1791	.2328	.2195
22	.1433	.1791	.1433	.1612	.1612	.1612	.1791
23	.8954	.1433	.1433	.1433	1.1104	1.0387	.985
24	1.0387	.8596	.1254	.1254	.1433	1.0745	1.1104
Max	2.1849	2.1491	2.364	2.8654	1.1104	2.3819	2.5072
Min	.1433	.1433	.1075	.1254	.1254	.0179	.1463
Avg	.6544	1.0939	.8121	.7921	.2261	.7531	.7506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 207 / 11 KV EXPRESS MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.0914		.0914
2	.0732		.0732
3	.0732		.0732
4	.0732		.0549
5	.0914		.0549
6	.1097		.0549
7	.0732		.0366
8	.0914		.0549
9	.1097		.0732
10	.0914	.1097	
16		.0549	
17		.0914	
18		.0732	
19		.0914	
20		.0732	
21		.1097	
22		.1463	.1097
23		.1097	.1097
24			.0914
Max	.1097	.1463	.1097
Min	.0732	.0549	.0366
Avg	.0878	.0955	.0732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 208 / 11KV LANGERPETH GAO
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2378		.2561
2	.2195		.2378
3	.1829		.2378
4	.2195		.2378
5	.3109		.3109
6	.4207		.4024
7	.5853		.5853
8	.5487		.5487
9	.3658		.4024
10	.3109	.394	.2926
11			.3475
12			.3109
13			.2012
14			.2378
15			.2743
16		.2328	.2561
17		.2561	.2561
18		.3475	.4207
19		.4207	.567
20		.439	.4938
21		.3841	.439
22		.3475	.4755
23		.3109	.2561
24	.2561		.2561
Max	.5853	.439	.5853
Min	.1829	.2328	.2012
Avg	.3326	.3481	.3460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 202 / 11KV SHIRDHON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.1402	.8145	.6642	.6009	.0972	.1063
2	.1402	.1254	.7522	.6958	.6325	.0829	.1075
3	.124	.1254	.7522	.703	.6882	.0829	.1254
4	.124	.1433	.7628	.7499	.7362	.1063	.1267
5	.1595	.1629	.8718	.8535	.7907	.124	.1463
6	.2172	.2033	1.3272	.9482	.8592	.1772	.1829
7	.2561	.2149	1.8027	1.4506	1.1728	.2149	.2353
8	.2481	.2149	1.9608	1.8027	1.3546	.2926	.2926
9	.2279	.2149		.2035	.2103	.2012	.2172
10	1.2963	.1734		.2058	1.4842	1.5181	1.3108
11	1.5935	.1734	.208	.2103	1.6512	1.7604	1.4998
12	1.8404	.1734	.2401	.2149	1.6762	1.8884	1.5154
13	1.7924	.1949	.2204	.1772	1.7185	1.7394	
14	1.7604	.1791		.1772	1.7185	1.6872	1.3094
15	1.6461	.1791		.1791	1.7341	1.6248	1.0364
16	1.6827	.1791	.1387	.1991	1.821	1.7553	1.6667
17	1.6126	.1791	.2303	.2149	1.7711	1.3279	1.5623
18	.181	.1753	.2058	.2328	.1791	.1457	.2126
19	.2353	.2172	.2149	.2507	.2195	.1928	.2195
20	.1991	.2195	.2378	.2865	.1829	.208	.2172
21	.1612	.181	.2172	.2353	.1829	.1907	.181
22	.1612	.1433	.1991	.1791	.1543	.1753	.1578
23	.1578	.8688	.6081	.4374	.1187	.1417	.1235
24	.156	.1402	.8326	.6401	.5312	.0972	.124
Max	1.8404	.8688	1.9608	1.8027	1.821	1.8884	1.6667
Min	.124	.1254	.1387	.1772	.1187	.0829	.1063
Avg	.6714	.2051	.6299	.4963	.9245	.6597	.5512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 203 / 11KV BORGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.0943	.1132	.132	.0943	.1132
2	.0943	.0943	.0754	.1132	.132	.0943	.1132
3	.0943	.0943	.0754	.0943	.1132	.0943	.0943
4	.1132	.0943	.0943	.0943	.1132	.0943	.0943
5	.1132	.1132	.132	.1132	.132	.0943	
6	.1132	.1132	.1509	.132	.1509	.1132	.132
7	.1886		.1886	.1886	.1886	.1698	.1698
8	.168		.168	.1698	.1867	.1698	.1698
9	.1509	.1494		.1698	.168	.132	.1494
10	.1334	.1494	.132	.1509	.128	.132	.1307
11	.1334	.168	.1698	.1509	.0905	.1132	.1307
12	.1663	.1494	.1463	.132	.1109	.1132	.1097
13	.1663	.1132	.1132	.132	.1132	.0943	
14	.1478	.1097	.112	.1132	.1132	.0914	.0943
15	.1448	.1254		.1132	.0914	.1063	.0886
16	.1417	.1254	.1029	.1307	.0943	.1075	.0934
17	.1629	.1433	.124	.1448	.0905	.1417	.0905
18	.1663	.1734	.1387	.1595	.1132	.1526	.1214
19	.2054	.1772	.2012	.2172	.2241	.2033	.2172
20	.1867	.2263	.2427	.2427	.2075	.2241	.2075
21	.1494	.1663	.1509	.2263	.1698	.2054	.1698
22	.1307	.1334	.1698	.1886	.1307	.1698	.1698
23	.132	.132	.1509	.1698	.1307	.1509	.132
24	.132	.132	.0943	.132	.1509	.1132	.132
Max	.2054	.2263	.2427	.2427	.2241	.2241	.2172
Min	.0943	.0943	.0754	.0943	.0905	.0914	.0886
Avg	.1437	.1362	.1376	.1497	.1365	.1323	.1329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 204 / 11KV BORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.8697	.8322	.6325	.1886	.1886
2	.1509	.1886	.8223	.8962	.6642	.1698	.1698
3	.1509	.1886	.8539	.9602	.7202	.1698	.1698
4	.1698	.2075	.8436	1.0623	.7682	.1886	.1886
5	.2075	.2263	.953	1.1561	.8421	.2075	.2075
6	.2641	.2641	1.3435	1.3592	1.0202	.2452	.2263
7	.3018	.2772	2.3903	.2452	1.2651	.3395	.3018
8	.3547	.3292	2.3087	2.5126	1.5779	.3584	.3361
9	.3326	.3142		.2715	.2033	.3361	.3174
10	2.0165	.3395	.2641	.2402	2.0165	2.1091	1.9685
11	2.2085	.3395	.3018	.2614	1.9444	2.4646	2.3685
12	2.3685	.2987	.2614	.2427	2.2245	2.6246	2.4166
13	2.3685	.2987	.2772	.2241	2.2138	2.4669	
14	2.3205	.2801	.2054	.2241	2.198	2.2138	1.9685
15	2.2929	.2801		.2614	2.0622	2.1032	2.1091
16	2.2929	.2614	.2987	.2801	2.2184	2.2405	2.037
17	2.1765	.2801	.3142	.2957	2.3403	2.0965	1.906
18	.2241	.2957		.2534	.2149	.2534	.2218
19	.2801	.2987		.3174	.3361	.2587	.2987
20	.2427	.3395	.3206	.2801	.3206	.2987	.2614
21	.2241	.2427	.2829	.2614	.2614	.2614	.2241
22	.2241	.2241	.2452	.2427	.2054	.2241	.2054
23	.2241	1.1203	.6882	.463	.1886	.2075	.1867
24	.1867	.2075	.8855	.7537	.5624	.1886	.1886
Max	2.3685	1.1203	2.3903	2.5126	2.3403	2.6246	2.4166
Min	.1509	.1886	.2054	.2241	.1886	.1698	.1698
Avg	.9064	.3038	.7365	.5790	1.1251	.9256	.8029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 205 / 11KV SHIVGANGA GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0924	.0914	.112	.1132	.1132	.0943
2	.0732	.0934	.0914	.112	.0943	.0943	.0943
3	.0739	.0934	.0914	.1109	.0943	.0934	.0943
4		.1109	.0924	.1109	.1132	.0934	.1132
5		.1109	.1109	.0914	.1132	.112	.1132
6	.128	.1109	.112	.0914	.132	.112	.1132
7	.1132	.112	.1132	.1509	.132	.1307	.1132
8	.1254	.1132	.112	.1086	.1132	.1132	.0924
9	.0754	.1867		.1132	.1294	.0848	.1132
10	.1307	.2241	.132	.1886	.168	.0943	.1294
11	.1227	.2241	.1886	.2263	.1509	.1132	.1848
12	.1457	.2054	.1663	.2263	.1886	.1132	.1698
13	.1457	.1524	.1132	.2075	.1132	.1886	
14	.1341	.1509		.2075	.1132	.1698	.1357
15	.1417	.1698	.2054	.2075	.1698	.1698	.1478
16	.1307	.1698	.1509	.1886	.1509	.1509	.1254
17	.1267	.1509	.132	.1886	.2075	.1509	.1463
18	.1448	.1143	.128	.124	.1509	.0895	.1267
19	.124	.1097	.128	.1612	.1478	.0934	.1848
20	.1075	.0886	.1109	.1463	.1463	.1132	.1663
21	.1097	.0905	.1509	.1463	.1294	.1132	.1307
22	.0914	.0905	.1509	.1097	.1097	.112	.1307
23	.0924	.0905	.132	.112	.1109	.1132	.1063
24	.1109	.0924	.0914	.1307	.112	.1132	.1132
Max	.1457	.2241	.2054	.2263	.2075	.1886	.1848
Min	.0732	.0886	.0914	.0914	.0943	.0848	.0924
Avg	.1154	.1312	.1271	.1489	.1335	.1186	.1278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 206 / 11KV SHIRDHON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1698	.2075		.1698	.112	.132
2	.1132	.1509	.1886	.1698	.1509	.0934	.1132
3	.0943	.1509	.1848	.1509	.1509	.0934	.1132
4	.1132	.1307	.1848	.1509	.132	.0934	.0943
5	.132	.1307	.2033	.1698	.1509	.112	.132
6	.1698	.168	.2195	.1886	.1886	.1494	.168
7	.1867	.1829	.2561	.2402	.2427	.2353	.2561
8	.2402	.1991	.2172	.2353	.2378	.2172	.2378
9	.0532	.181		.2452	.1791	.1753	.197
10	.1753	.1612	.1646	.2149	.1433	.1772	.1595
11	.1578	.1612	.1772	.197	.1791	.1791	.1417
12	.1417	.1612	.0145	.1772	.1578	.1612	.1448
13	.1417	.1772	.1734	.1578	.1677	.1417	
14	.1402	.1402	.1402	.1595	.1492	.1372	.1341
15	.12	.1402		.1417	.1492	.1526	.1509
16	.12	.1387	.1715	.1433	.1526	.1753	.1372
17	.1578	.1543	.1387	.1214	.12	.1734	.1372
18	.2353	.1696	.1734	.1543	.1734	.1677	.197
19	.2987	.2204		.2743	.2772	.2587	.3142
20	.2801	.285	.3109	.3018	.2987	.3174	.2957
21	.2263	.2601	.2772	.2641	.2987	.2452	.2402
22	.2075	.2263	.2263	.2263	.1886	.2075	.2075
23	.1886	.2075	.1886	.1886	.1509	.1509	.132
24	.132	.1886	.2075	.2075	.1698	.112	.132
Max	.2987	.285	.3109	.3018	.2987	.3174	.3142
Min	.0532	.1307	.0145	.1214	.12	.0934	.0943
Avg	.1641	.1773	.1917	.1948	.1825	.1683	.1725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 207 / 11KV ALKUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.5243	.1509	.1886	.1698	.759	.7042
2	.6226	.5243	.132	.1698	.1698	.7202	.7362
3	.6554	.5407	.132	.1698	.1509	.7362	.8259
4	.7865	.5898	.1509	.1509	.1509	.7682	.8745
5		.6796	.1509	.1698	.1698	.7842	.9555
6	.9448	.8785	.2641	.2641	.2452	1.0402	1.0814
7	1.3426	1.0608	.3772	.415	.3772	1.4091	1.4752
8	1.5223	1.4255	.2641	.3584	.3206	1.7695	1.9062
9	.3045	.2402		.2801	.2614	.2402	.2427
10	.1928	1.5912	1.4582	1.4083	.2263	.1886	.168
11	.1433	1.9062	1.8679	1.6385	.1867	.1509	.132
12	.1086	1.8399	1.8187	1.7238	.1867	.132	.1307
13	.1086	1.7532	1.749	1.7901	.168	.1132	
14	.1267	1.6712		1.6876	.0934	.112	.0549
15	.128	1.6385	1.7695	1.749	.0934	.1109	.0532
16	.1478	1.6057	1.7695	1.8187	.1109	.1307	.0554
17	.1867	1.5581	1.6549	1.7204	.1294	.1494	.0739
18	.2075	.1848	.2012	.181	.2054	.1646	.132
19	.2641	.2241	.2801	.2987	.3206	.2614	.2075
20	.2452	.2641	.2987	.3206	.3018	.3206	.2801
21	.2075	.2263	.2641	.2641	.2263	.2452	.2427
22	.2075	.1886	.2241	.2054	.2075	.2263	.1867
23	.5898	.1509	.2075	.1886	.6722	.5535	.6249
24	.5668	.5571	.1509	.2075	.1886	.759	.6325
Max	1.5223	1.9062	1.8679	1.8187	.6722	1.7695	1.9062
Min	.1086	.1509	.132	.1509	.0934	.1109	.0532
Avg	.4435	.9093	.6971	.7237	.2222	.4935	.5120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 401 / 33 KV JOLLY BOARD
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6687	.5658	.5658	.679	.5093	.1698
2	.5658	.6687	.5144	.5658	.7356	.4527	.3395
3	.5658	.7202	.4115	.6173	.7356	.5093	.3395
4	.6173	.7202	.5144	.6173	.6224	.5658	.3961
5	.6173	.6687	.5144	.7202	.6224	.7922	.3961
6	.7202	.7202	.5658	.7716	.5658	.7922	.4527
7	.463	.5144	.5658	.5144	.5658	.3961	.4527
8	.2572	.3086	.4115	.4115	.4527	.2829	.3961
9	.1543	.4115		.6224	.5093	.1698	.679
10	.1029	.3086	.4115	.4527	.5658	.1698	.7922
11	.1029	.3086	.1543	.1132	.2829	.2263	.4527
12	.1029	.2058	.3086	.1698	.1698	.2829	.6224
13	.1029	.2058	.1543	.2263	.0857	.1698	
14	.1543	.2058	.3086	.2263	.0857	.1698	.4527
15	.2572	.2572		.1698	.0857	.1698	.3961
16	.2572	.6687	.2058	.5093	.2263	.1698	.679
17	.3086	.7202	.3086	.6224	.6224	.1698	.679
18	.5658	.7716	.6173	.5093	.6224	.1698	.3961
19	.7716	.7202	.5144	.5093	.7922	.1698	.8488
20	.7716	.7202	.463	.7356	.5658	.1698	.7356
21	.7202	.7202	.5144	.5658	.5658	.1698	.6224
22	.7202	.7716	.5144	.8488	.7922	.1698	.7356
23	.6173	.6687	.5658	.5658	.5093	.1698	.4527
24	.463	.6687	.5658	.5658	.6224	.5093	.1698
Max	.7716	.7716	.6173	.8488	.7922	.7922	.8488
Min	.1029	.2058	.1543	.1132	.0857	.1698	.1698
Avg	.4372	.5551	.4396	.5082	.5035	.3136	.5068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 201 / 11KV DUDHEBHAVI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	1.065
Max	1.065
Min	1.065
Avg	1.065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 202 / 11KV NAGAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8817	.5868			.1677	.8048	
2	.8987	.5868			.1677	.8383	
3	.8987	.6962			.1677	.8383	
4	1.0682	.8288			.1844	1.0059	
5	1.2239	1.0059			.218	1.2071	
6	1.4074	1.0059			.285	1.5089	
7	1.4251	1.2239			.3018	1.7269	
8		1.4754			.3185	1.8107	
9		.2347	.2572	.2515	.2515	.218	.218
10		1.8004	1.286	1.3904	.2012		.2012
11		1.8861	1.6289	1.3916	.1844		.1677
12		1.9719	1.6118	1.4586	.1677		
13		1.7147	1.5947	1.4918	.1509		
14		1.6975	1.5947	1.4918	.1509		.1509
15		1.6632	1.5775	1.5257	.1677		
16		1.6118	1.5775	1.5089	.1677		
17			1.286	1.4754	.2012		
18				.218	.2347		
19				.2683	.2713		
20				.2683	.2713		
21				.2515	.2515		
22				.1696	.2347		
23				.1844	.5868		
24	1.5117	.5365			.1844	.7042	
Max	1.5117	1.9719	1.6289	1.5257	.5868	1.8107	.218
Min	.8817	.2347	.2572	.1696	.1509	.218	.1509
Avg	1.1644	1.2074	1.3794	.8897	.2287	1.0663	.1845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 203 / 11KV CHOROCHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357				.4191	.2012	
2	.1509				.503	.2012	
3	.1526				.503	.2012	
4	.1526				.5365	.2012	
5	.1526				.6371	.2012	
6	.1865				.7545	.218	
7	.2204				1.0059	.2347	
8					1.073	.2347	
9		.2012	1.9033	.1677	.2012		.218
10		.1715	.1543	.1509	.8048		1.0562
11		.1715	.1715	.1677	1.3413		1.2239
12		.1543	.1372	.1844	1.4251		1.3413
13		.1543	.1372	.1844	1.4251		1.3413
14		.1372	.1372	.1844	1.4251		1.3413
15		.12	.12	.1844	1.3413		
16		.1372	.12	.1677	1.3413		
17		.12	.12	.1844	1.2742		
18				.2012	.2012		
19				.2347	.2347		
20				.2347	.2347		
21				.218	.218		
22				.2012	.2012		
23				.3353	.2012		
24	1.0593				.4191	.2012	
Max	1.0593	.2012	1.9033	.3353	1.4251	.2347	1.3413
Min	.1357	.12	.12	.1509	.2012	.2012	.218
Avg	.2763	.1519	.3334	.2001	.7384	.2105	1.087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 204 / 11KV DHALEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848				.7545	.218	
2	.0848				.8048	.2012	
3	.0848				.8383	.2012	
4	.1509				.9221	.218	
5	.1526				1.0898	.2515	
6	.1865				1.1603	.3353	
7	.1865				1.4419	.4024	
8					1.5089	.3521	
9			1.7318	.2347	.218		.2515
10		.1543	.1886	.1844	1.3413		1.3748
11		.1715		.1509	1.4419		
12		.1715	.1886	.1677	1.576		1.8442
13		.1715	.1715	.1677	1.5089		1.8442
14		.1715	.1886	.1677	1.5089		1.8778
15		.1715	.1543	.1341	1.4754		
16		.1715	.1372	.1677	1.4419		
17		.1715	.1372	.1844	1.4251		
18				.2347	.218		
19				.2683	.2515		
20				.2683	.2683		
21				.2515	.2347		
22				.218	.218		
23				.5365	.218		
24	1.5413				.6706	.218	
Max	1.5413	.1715	1.7318	.5365	1.576	.4024	1.8778
Min	.0848	.1543	.1372	.1341	.218	.2012	.2515
Avg	.3090	.1694	.3622	.2224	.9390	.2664	1.4385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 205 / 11KV CHOROCHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372				.12	.1214	
2	.1543				.1214	.1214	
3	.1715				.12	.12	
4	.2229				.1214	.1387	
5	.2572				.1734	.1715	
6	.2774				.2254	.2254	
7	.2743				.2572	.2743	
8					.2743	.1907	
9			.2229	.1543	.2427		
10		.1543	.1715	.1372	.208		.1844
11		.1372	.1715		.1928		
12		.1372	.1715	.1387	.1734		.1214
13		.1543	.1715	.1387	.1387		.1029
14		.1372	.1543	.12	.1387		.1029
15		.1543	.1543	.12	.1372		
16		.1372	.1543	.1387	.1372		
17		.1543	.1543	.1734	.1734		
18				.208	.208		
19				.2601	.2572		
20				.2401	.2572		
21				.1715	.208		
22				.156	.1734		
23				.1387	.156		
24	.1724				.1214	.1372	
Max	.2774	.1543	.2229	.2601	.2743	.2743	.1844
Min	.1372	.1372	.1543	.12	.12	.12	.1029
Avg	.2084	.1458	.1696	.1640	.1807	.1667	.1279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 206 / 11 KV DUDHEBHAVI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.156				.1214	.1387	
2	.1543				.12	.1387	
3	.1543				.12	.1372	
4	.1543				.1372	.1372	
5	.1543				.156	.1734	
6	.2572				.1907	.1907	
7	.2572				.1886	.1886	
8					.1387	.1734	
9			.1886	.156	.1734		.1734
10		.12	.1715	.1387	.1734		.1387
11		.1372	.1543	.1029	.1907		.1387
12		.1372	.1543	.1214	.1734		.1387
13		.1372	.1543	.1029	.156		.1372
14		.1307	.1372	.1029	.156		.12
15		.12	.1543	.104	.1387		
16		.1029	.1543	.104	.104		
17		.0857	.1543	.104	.1214		
18				.1214	.1387		
19				.1372	.1387		
20				.1372	.1372		
21				.12	.1372		
22	.104			.104	.1387		
23				.104	.1387		
24	.1715				.104	.1372	
Max	.2572	.1372	.1886	.156	.1907	.1907	.1734
Min	.104	.0857	.1372	.1029	.104	.1372	.12
Avg	.1737	.1214	.1581	.1174	.1455	.1572	.1411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 201 / 11KV SHELKEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.5601	.1829	.1663	.168	.8436	
2	.1417	.5182	.1829	.1663	.168	.8592	
3	.1829	.5601	.2378	.2033	.168	.8962	
4	.2149	.7373	.2987	.2772	.1886	.9602	
5	.2896	.8097	.3734	.3772	.2452	1.0814	
6	.5014	1.1706	.4527	.4715	.4904	1.291	
7	.5731	1.4403	.5281	.6224	.5658	2.0454	
8	.6733	1.6385	.4527	.4904	.415	2.4981	
9	.2149		.3547	.2987	.3174	.3511	
10		1.1523	1.5223	1.4575	.2241		.2561
11	.3045	1.5223	1.5708	1.704	.1867		.2012
12	.2328	1.4243	1.078	1.3603	.1357		.1829
13		1.4413	1.078	1.3443	.1595		.1612
14		1.2483	1.0595	1.4083	.2012		.1595
15		1.1069	1.1702	1.2967	.1949		.2012
16		1.2334	1.6221	1.6907	.2303	.2772	.2012
17	1.1523	1.3123	1.7368	1.8945	.3361	.3109	.2033
18	.3898	.1848	.2743	.2402	.3361	.3734	.2743
19	.394	.415	.4108	.3961	.3734	.415	.4294
20	.4252	.3961	.415	.4338	.3961		.3921
21	.3189	.3206	.3206	.3395	.3018		.3395
22	.2658	.2427	.2614	.2641	.2452		.2402
23	.6081	.1663	.2033	.2263	.759		.7968
24	.1772	.6478	.1829	.1663	.1886	.8124	
Max	1.1523	1.6385	1.7368	1.8945	.759	2.4981	.7968
Min	.1417	.1663	.1829	.1663	.1357	.2772	.1595
Avg	.3791	.8804	.6654	.7207	.2915	.9297	.2885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 202 / 11 KV GATHNANDRE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0886	.6642	.6325	.6562	.1307	
2	.0895	.0886	.7116	.68	.6722	.1307	
3	.0905	.0905	.7773	.7116	.6802	.132	
4	.128	.1254	.8421	.759	.6964	.1509	
5	.1595	.1402	.9503	.852	.7537	.1886	
6	.1949	.1772	1.0159	1.065	.8453	.2263	
7	.197	.1791	1.3763	1.3927	1.0898	.2641	
8	.2149	.2126	1.5415	1.7404	1.3094	.2263	
9	.1772		.1663	.168	.1509	.168	
10		.1433	.1132	.1494	.7125		1.0202
11	.852	.1132	.1132	.1307	1.0883		1.4251
12	1.1105	.1097	.1254	.0924	1.085		1.5384
13		.0895	.0895	.1109	.7274		1.6385
14		.056	.0895	.1086	1.2944		1.5546
15	1.3603	.0554	.0895	.1267	1.4091		1.4899
16	1.5364	.0739	.0686	.056	1.6385	1.6078	1.5546
17	1.0242	.0549	.0686	.1478	1.4746	1.9062	1.5565
18	.1063	.132	.1478	.1294	.1509	.1848	.168
19	.1433	.2452	.2054	.1886	.1886	.2829	.2263
20	.197	.2263	.2075	.1886	.1886		.2075
21	.1595	.1886	.1698	.1698	.1886		.1886
22	.1417	.1698	.1509	.1509	.1509		.1307
23	.1063	.5992	.6882	.4062	.1509		.112
24	.1075	.1075	.6325	.6325	.5693	.1307	
Max	1.5364	.5992	1.5415	1.7404	1.6385	1.9062	1.6385
Min	.0886	.0549	.0686	.056	.1509	.1307	.112
Avg	.3898	.1507	.4585	.4496	.7447	.4093	.9151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 203 / 11KV RAIWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.0358	.286	.2743	.2896	.0566	
2	.0358	.0354	.301	.3048	.3048	.0566	
3	.0362	.0537	.3593	.3048	.3281	.0566	
4	.1063	.0905	.4062	.3658	.3812	.0566	
5	.128	.1063	.5344	.4161	.4161	.0754	
6	.1595	.1417	.583	.4481	.5506	.1509	
7	.1612	.1433	.8987	.6722	.6964	.2263	
8	.1791	.1448	.9555	.9602	.7682	.1886	
9	.1254		.1509	.1132	.0943	.1494	
10		.0895	.0943	.0943	.6722		.5312
11	.5182	.0566	.0943	.0943	.8381		.7811
12	.583	.0739	.0943	.0566	.8322		.9014
13		.0747	.0943	.0381	.679		.852
14		.0754	.0747	.0381	.6481		.8381
15	.7682	.0754	.0747	.0381	.7407		.8907
16	.7125	.0566	.0934	.0381	.8642	.6093	.9069
17	.3521	.0739	.0934	.1132	.8642	.8642	.8097
18	.0895	.0566	.0943	.112	.112	.112	.112
19	.0886	.1307	.1494	.1509	.1494	.1698	.1494
20	.1063	.1132	.1132	.1509	.132		.1494
21	.0895	.0943	.0943	.1132	.1132		.112
22	.0709	.0754	.0754	.0754	.0943		.0754
23	.0358	.2006	.2187	.1677	.0754		.0754
24	.0358	.0354	.2559	.2743	.2743	.056	
Max	.7682	.2006	.9555	.9602	.8642	.8642	.9069
Min	.0354	.0354	.0747	.0381	.0754	.056	.0754
Avg	.2103	.0884	.2579	.2256	.4549	.2020	.5132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 204 / 11 KV SHELKEWADI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.124	.1494	.1646	.1698	.1698	
2	.1433	.1254	.1494	.1646	.1698	.1698	
3	.1448	.124	.1494	.1646	.1698	.1698	
4	.2126	.197	.1867	.2241	.1886	.1886	
5	.2743	.2303	.2829	.3361	.2263	.2263	
6	.3761	.3189	.3772	.3734	.362	.3961	
7	.3721	.3224	.415	.4108	.4527	.4715	
8	.3721	.3544	.3174	.3921	.3206	.415	
9	.2865		.2195	.2378	.2427	.3018	
10		.197	.1991	.2126	.2402		.2614
11	.1791	.1612	.181	.1867	.1612		.2172
12	.1433	.1294	.1254	.168	.1463		.1698
13	.1417	.132	.1254	.168	.0146		.1509
14	.181	.1334	.1494	.1698	.1433		.1307
15	.1772	.132	.1494	.1509	.1254		.1646
16	.1791	.1494	.1629	.1886	.1254	.2218	.1829
17	.197	.197	.1629	.1698	.1433	.2587	.2353
18	.2835	.2561	.2103	.2587	.3018	.2926	.2801
19	.3224	.4024	.3696	.3734	.4715	.4294	.3734
20	.3898	.3696	.3696	.3584	.3961		.5487
21	.3189	.3326	.3326	.3395	.3584		.3142
22	.2328	.2452	.2829	.2477	.2829		.2075
23	.1991	.168	.1698	.2096	.2427		.1886
24	.1417	.1433	.1494	.1646	.1698	.1698	
Max	.3898	.4024	.415	.4108	.4715	.4715	.5487
Min	.1417	.124	.1254	.1509	.0146	.1698	.1307
Avg	.2352	.215	.2244	.2431	.2344	.2772	.2447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 205 / 11 KV GHATNANDRE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0532	.0537	.0566	.0572	.0572	
2	.0532	.0537	.0537	.0566	.0572	.0572	
3	.0526	.0543	.0537	.0566	.0762	.0572	
4	.0886	.0895	.112	.1132	.1132	.0762	
5	.1267	.1433	.1307	.1698	.132	.1143	
6	.1886	.197	.2096	.2263	.2075	.1905	
7	.2149	.1949	.2263	.2427	.2641	.2263	
8	.2534	.2149	.2096	.2075	.2263	.2075	
9	.1612		.1509	.1509	.1307	.1509	
10		.0895	.0754	.0934	.112		.0924
11	.0905	.0914	.0754	.0739	.0895		.1109
12	.0709	.0895	.0754	.1086	.0732		.0905
13	.0716	.0747	.0943	.0905	.0537		.0924
14	.0716	.0747	.0924	.0739	.0549		.0566
15	.0716	.0754	.0924	.0905	.0554		.0543
16	.0709	.0754	.0905	.0754	.1109	.0914	.0724
17	.1075	.0953	.0905	.0934	.1478	.1075	.1132
18	.1063	.132	.0924	.112	.1848	.168	.1463
19	.1433	.2075	.2195	.2033	.2218	.2378	.2218
20	.197	.2075	.2054	.2241	.2241		.2033
21	.1595	.1698	.168	.1509	.1698		.1848
22	.1254	.132	.1132	.1132	.1132		.112
23	.0709	.0724	.0754	.0943	.0762		.0754
24	.0537	.0537	.0537	.0566	.0754	.0572	
Max	.2534	.2149	.2263	.2427	.2641	.2378	.2218
Min	.0526	.0532	.0537	.0566	.0537	.0572	.0543
Avg	.1132	.1149	.1173	.1223	.1261	.1285	.1162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 206 / 11KV RAIWADI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0358	.0339	.0829	.0655	.0173	
2	.0354	.0362	.0339	.0829	.0663	.0177	
3	.0362	.0354	.0339	.0829	.0678	.0177	
4	.0354	.0366	.0543	.1063	.0701	.0362	
5	.0537	.0543	.0543	.1063	.0895	.0554	
6	.0566	.0554	.056	.1267	.1109	.0747	
7	.0716	.0914	.0943	.1612	.112	.1086	
8	.0905	.1086	.128	.1097	.0747	.1086	
9	.0537		.0716	.0716	.1017	.104	
10		.0709	.1029	.0895	.1341		.0701
11	.0358	.0537	.1029	.0709	.1147		.0537
12	.0358	.0724	.0937	.0532	.1147		.0633
13	.0358	.0514	.0937	.0709	.1107		.064
14		.0532	.0972	.052	.1134		.064
15	.0358	.0848	.0972	.0497	.1107		.0709
16	.0537	.0663	.0983	.0532	.1107	.0526	.0709
17	.0537	.0678	.0983	.0724	.112	.0876	.0492
18	.0709	.0876	.0972	.0724	.0943	.104	.0791
19	.0895	.1086	.1402	.128	.1132	.1448	.1063
20	.1075	.1267	.1402	.1294	.1267		.0943
21	.0886	.1086		.1086	.1097		.0924
22	.0716	.0905		.1052	.0739		.1052
23	.0532	.0532		.0857	.0358		.0709
24	.0354	.0358	.0339	.0829	.0663	.0171	
Max	.1075	.1267	.1402	.1612	.1341	.1448	.1063
Min	.0354	.0354	.0339	.0497	.0358	.0171	.0492
Avg	.0562	.0689	.0836	.0898	.0958	.0676	.0753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 207 / 11KV JAKHAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.0791		.0566	.0572	.2241	
2	.0949	.08	.0566	.0566	.0572	.2241	
3	.0983	.081	.0566	.0566	.0572	.2241	
4	.1296	.1265	.0934	.0754	.0754	.2429	
5	.16	.16	.112	.1307	.0943	.2785	
6	.213	.1966	.1494	.168	.132	.3353	
7	.4001	.3887	.1307	.1494	.2263	.503	
8	.5761	.4961	.2241	.1867	.2263	.6874	
9	.0895		.168	.112	.1698	.0381	
10		.4252	.4424	.426	.132		.0762
11	.0537	.426	.4424	.5243	.0754		.0953
12	.0362	.4534	.426	.5304	.0943		.0754
13	.0709	.3768	.426	.4915	.0377		.0377
14	.0895	.421	.4752	.426	.0377		.0943
15	.1063	.4001	.4752	.4372	.0377		.0943
16	.124	.426	.4801	.4359	.0377	.1524	.0943
17	.0886	.4915	.5121	.4359	.0377	.1143	.0943
18	.0895	.1132	.0754	.1867	.1334	.2096	.132
19	.1063	.1494	.1494	.132	.1334	.1715	.1132
20	.1433	.1132	.112	.132	.1143		.1132
21	.1075	.1132	.1227	.0953	.1143		.1132
22	.0886	.0943	.1029	.0762	.0953		.0754
23	.1147	.0754	.0848	.0572	.208		.1509
24	.128	.1147	.0566	.0566	.0572	.2241	
Max	.5761	.4961	.5121	.5304	.2263	.6874	.1509
Min	.0362	.0754	.0566	.0566	.0377	.0381	.0377
Avg	.1394	.2522	.2337	.2265	.1017	.2592	.0971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 208 / 11 KV AGALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0177	.0177	.0474	.0312	.0474	.0191	
2	.0179	.0179	.0474	.0312	.0474	.0191	
3	.0181	.0177	.0474	.0312	.0474	.0191	
4	.0179	.0179	.0633	.0312	.048	.0381	
5	.0366	.0181	.0648	.048	.0492	.0572	
6	.0354	.0177	.081	.048	.0671	.0762	
7	.0175	.0177	.081	.064	.0983	.0943	
8	.0179	.0179	.081	.096	.0655	.0566	
9	.0177		.0191	.0189	.0191	.0381	
10		.0177	.0191	.0189	.0972		.1357
11	.0655	.0189	.0191	.0189	.0972		.1509
12	.081	.0187	.0191	.0189	.1134		.1619
13	.08	.0189	.0191	.0189	.0819		.1581
14	.0983	.0189	.0191	.0189	.0671		.1898
15	.1311	.0189	.0191	.0189	.0838		.2031
16	.1475	.0377	.0191	.0377	.0838	.2785	.1875
17	.1296	.0187	.0191	.0377	.0838	.2785	.1543
18	.0179	.0191	.0189	.0377	.0572	.0566	.0566
19	.0179	.0191	.0189	.0381	.0572	.0762	.0566
20	.0177	.0191	.0189	.0381	.0572		.0566
21	.0177	.0191	.0189	.0191	.0572		.0377
22	.0179	.0191	.0189	.0191	.0381		.0377
23	.0177	.0358	.0177	.0312	.0191		.0191
24	.0179	.0179	.0474	.0312	.0316	.0191	
Max	.1475	.0377	.081	.096	.1134	.2785	.2031
Min	.0175	.0177	.0177	.0189	.0191	.0191	.0191
Avg	.0458	.0200	.0352	.0335	.0631	.0805	.1147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 401 / 33 KV Suzlon

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	2.4434
Max	2.4434
Min	2.4434
Avg	2.4434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 201 / 11 KV LONARWADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	.7682
Max	.7682
Min	.7682
Avg	.7682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 202 / 11KV KOKLE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	.3547
Max	.3547
Min	.3547
Avg	.3547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 203 / 11 KV IRALI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	.3292
Max	.3292
Min	.3292
Avg	.3292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 204 / 11 KV LONARWADI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18
HR	Load (MW)
24	.6335
Max	.6335
Min	.6335
Avg	.6335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 205 / 11 KV KOKLE GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.8145
Max	.8145
Min	.8145
Avg	.8145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 206 / 11 KV IRALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.7316
Max	.7316
Min	.7316
Avg	.7316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 201 / 11 KV SHINDEWADI (H) AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924		1.2266		1.3592	.2241	
2	.0924		1.2929		1.3592	.2054	
3	.0924		1.2431		1.3923	.2427	
4	.1109		1.2597		1.5912	.2427	
5	.1109		1.326		1.8564	.2427	
6	.1294		1.3923		1.9559	.2241	
7	.1294		2.6189		2.0388	.4481	
8	.1848		2.9504		2.4863	.5228	
9	.2218		.2587		.3326	.3174	
10	2.0388		.2218	.2195	2.0885		
11	2.4697	.1848		.2012	2.0553		2.6355
12	2.2542	.1848		.1829	2.0885		2.4531
13	2.2708	.1848		.1463	2.1216		2.3205
14	2.2377	.2033		.128	2.1382		2.2708
15	2.4531	.2033		.0914	2.1548		2.2211
16	2.5194	.2033		.0914	2.1879		1.7404
17	2.5692	.1663		.1097	2.4034		1.8233
18	.2957	.1663		.128	.3174		.3326
19	.4066	.1663		.128	.3361		.1663
20	.462	.1848		.128	.4108		.0924
21	.5175	.3511		.1463	.4481		.0924
22	.4251	.2587		.1463	.4668		.0924
23	.2772	1.2431		1.326	.2801		.0924
24	1.1822		1.2266			.2614	
Max	2.5692	1.2431	2.9504	1.326	2.4863	.5228	2.6355
Min	.0924	.1663	.2218	.0914	.2801	.2054	.0924
Avg	.9810	.2847	1.3652	.2266	1.4726	.2931	1.2564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 202 / 11 KV KUKTOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829		1.1934		1.0978	.1848	
2	.1829		1.2266		1.0978	.2033	
3	.1829		1.2597		1.1797	.1848	
4	.2561		1.2929		1.278	.2218	
5	.3109		1.3592		1.3763	.2033	
6	.3475		1.5249		1.4419	.2587	
7	.3841		1.9559		1.5074	.3696	
8	.3292		2.0719		1.7204	.3142	
9	.2195		.2427		.3142	.2218	
10	1.7238		.1174	.1294	1.7404		
11	2.0719		.128	.1294	1.6575		2.1792
12	1.9725	.1294		.1109	1.7238		2.1628
13	1.9559	.1109		.1109	1.7404		2.1792
14	1.9559	.1294		.1109	1.7238		2.1628
15	2.0553			.1109	1.6575		2.13
16	2.1051	.1109		.1478	1.5581		2.0153
17	2.1051	.1294		.1478	1.4918		1.8515
18	.1109	.1478		.1663	.1848		.2402
19	.2218	.1663		.3142	.2218		.2587
20	.2587			.2957	.2402		.2957
21	.2402	.2772		.2772	.2587		.2772
22	.2218	.2587		.2402	.2402		.2402
23	.2033	1.1437		1.0814	.2033		.2033
24	.1829		1.1603		1.0978	.1848	
Max	2.1051	1.1437	2.0719	1.0814	1.7404	.3696	2.1792
Min	.1109	.1109	.1174	.1109	.1848	.1848	.2033
Avg	.8242	.2604	1.1277	.2409	1.1147	.2347	1.2459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 203 / 11 KV KONGNOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1105		.2402		.2402	1.1105	
2			.2218		.2402	1.1437	
3	1.1437		.2402		.2402	1.1603	
4	1.2597		.2402		.2772	1.1271	
5	1.4586		.2587		.3511	1.1437	
6	1.6244		.2587		.4435	1.2266	
7	2.1051		.4805		.5175	2.3537	
8	2.3868		.462		.3696	2.7349	
9	.3696		.2772		.3326	.3361	
10	.2957		2.3868	1.9393	.2772		
11	.2772	2.2211		2.2874	.2402		.2402
12	.2218	2.2874		2.5857	.2587		.2218
13	.2218	2.2211		2.1714	.2218		.2218
14	.2218	2.1879		2.2211	.2218		.2218
15	.2402	2.2045		2.2708	.2218		.2402
16	.2587	2.0222		2.1714	.2587		.2033
17	.2587	1.989			.2957		.2587
18	.2402	.2402		.2218	.3511		.2957
19	.4251	.2587		.499	.4066		.3511
20	.499	.3326		.4805	.5175		.4435
21	.4435	.462		.4251	.4435		.3881
22	.3881	.3326		.3696	.4251		.3326
23	1.0111	.2772		.2772	1.1271		.9945
24	1.9829		.2587		.2614	1.1105	
Max	2.3868	2.2874	2.3868	2.5857	1.1271	2.7349	.9945
Min	.2218	.2402	.2218	.2218	.2218	.3361	.2033
Avg	.8019	1.3105	.4841	1.3785	.3558	1.3447	.3395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 204 / 11 KV KAROLI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012		.2012		.2378	.2195	
2	.2012		.2195		.2378	.2012	
3	.2378		.2012		.2378	.2195	
4	.3109		.2378		.2743	.2378	
5	.3475		.2195		.3109	.2195	
6	.4207		.2561		.4207	.3292	
7	.4938		.4207		.439	.4207	
8	.4207		.3658		.4024	.4024	
9	.4024		.3292		.3658	.3658	
10	.3475		.3109	.4024	.2561		
11	.2926	.2926		.3292	.2195		.2561
12	.2378	.2195		.2561	.2378		.2195
13		.2378		.2743	.2561		.2012
14		.2195		.2561	.2195		.2012
15				.2378	.1829		.2195
16		.3292		.2561	.2195		.2378
17		.2926		.3109	.2561		.3109
18		.3109		.3658	.2926		.4207
19		.3292		.5304	.3292		.4938
20		.547		.5487	.5304		.5487
21		.4024		.3109	.4207		.4572
22		.3658		.2743	.2926		.2743
23		.2195		.2561	.2195		.2378
24	.9252		.2012		.2378	.2195	
Max	.9252	.547	.4207	.5487	.5304	.4207	.5487
Min	.2012	.2195	.2012	.2378	.1829	.2012	.2012
Avg	.3723	.3138	.2694	.3292	.2957	.2835	.3137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 205 / 11 KV SARATI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6203	.0739			.0934	.5636	
2	.6203	.0924	.0739		.0934	.5801	
3	.6203	.0924	.0924		.0934	.5304	
4	.8048	.1109	.1109		.1307	.5636	
5	.9556		.0924		.168	.5801	
6	1.073		.1109		.2054	.7293	
7	1.1736		.2587		.2427	1.1934	
8	1.2071		.2218		.2427	1.4918	
9	.128		.1294		.1494	.1307	
10	.0914		1.1603	.9054	.112		
11	.0914	1.0774		1.2742	.1109		.112
12	.0732	1.094		1.3245	.0924		.112
13		1.1934		1.1904	.0739		.0934
14		1.1603		1.1736	.0739		.0934
15		1.1768		1.1568	.0924		.0934
16		1.21		1.1633	.1109		.0914
17		1.094		1.2071	.0924		.128
18		.0995		.1307	.0924		.1307
19		.1294		.1867	.1109		.1307
20		.1663		.1494	.1109		.112
21		.1294		.112	.1294		.1097
22		.0924		.0914	.1109		.112
23		.0739		.0934	.6468		.6036
24	.5868	.0739	.0739		.0934	.5801	
Max	1.2071	1.21	1.1603	1.3245	.6468	1.4918	.6036
Min	.0732	.0739	.0739	.0914	.0739	.1307	.0914
Avg	.6189	.5078	.2325	.7256	.1447	.6943	.1479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 201 / 11 KV DESHING GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1174	.1341	.2012	.1509	.1509	.1509
2		.1174	.1341	.2012	.1509	.1509	.1509
3		.1174	.1341	.218	.1509	.1509	.1509
4		.1174	.1341	.2347	.1509	.1677	.1509
5		.2012	.1341	.2347	.1677	.2012	.2012
6		.285	.3018	.2515	.2683	.285	.3018
7		.3353	.3018	.2683	.3688	.3353	.3688
8		.3018	.285	.3353	.3018	.3018	.3353
9		.2347	.2012	.218	.218	.3353	.2683
10		.2012	.2012	.2012	.2347	.3521	.2515
11		.2347	.0671	.218	.1341		.218
12		.2347	.2515	.2515	.1509		.2012
13		.218	.218	.2515	.1509		.1844
14		.1677	.2347	.1677	.1509		.2012
15		.1677		.1509	.1509		.218
16		.1677		.1509	.218	.1677	.2347
17		.2347		.1677	.2515	.218	.2683
18		.3018		.2347		.2347	.3353
19		.4024		.3018	.3018	.2683	.4024
20		.4024		.3856	.3856	.4024	.4359
21		.3353		.2347	.2347	.3018	.3688
22		.2347		.1677	.1677	.1677	.218
23		.1509		.1509	.1509	.1509	.1509
24	.2682	.1174	.1341	.1677	.1509	.1509	.1509
Max	.2682	.4024	.3018	.3856	.3856	.4024	.4359
Min	.2682	.1174	.0671	.1509	.1341	.1509	.1509
Avg	.2682	.2250	.1911	.2236	.2070	.2365	.2466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 202 / 11 KV BANEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9724	.1174	.1341	.1174	1.2071	1.0562
2		.9724	.1174	.1677	.1174	1.2071	1.0562
3		.9892	.1174	.1677	.1341	1.2071	1.0562
4		.9724	.1174	.2012	.1677	1.2071	1.3413
5		1.0059	.1677	.218	.2012	1.2742	1.5927
6		1.2574	.2683	.2347	.2012	1.4251	1.6766
7		1.4586	.2347	.2347	.2515	1.9113	2.2298
8		1.9784	.2012	.2347	.2347	2.3472	2.3472
9		.1844	.1677	.2347	.2347	.1509	.2012
10		1.7772	1.8442	1.5927	.2012	.1509	.1844
11		1.9951	2.2466	1.8442	.1677		.1677
12		2.0119	2.3137	2.1963	.1509		.1844
13		2.0454	1.6766	2.1795	.1341		.1844
14		1.8442	2.0119	2.0119	.1341		.1006
15		1.7436	1.8442	2.0119	.1341		.1006
16		1.7101	1.8107	2.0119	.1341	.1509	.1174
17		1.7101	1.7436	1.6766	.1509	.2347	.1174
18		.1341	.1677	.1677		.218	.1844
19		.218	.1677	.2012	.2012	.218	.1677
20		.218	.1844	.218	.218	.218	.1677
21		.1844	.1677	.1677	.1677	.1677	.1677
22		.1677	.1677	.1509	.1509	.1341	.1174
23		.1509	.1174	.1174		1.0562	.9892
24	1.8778	.9724	.1174	.1174	.1174	1.2071	1.0562
Max	1.8778	2.0454	2.3137	2.1963	.2515	2.3472	2.3472
Min	1.8778	.1341	.1174	.1174	.1174	.1341	.1006
Avg	1.8778	1.1114	.7538	.7705	.1692	.8259	.6902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 203 / 11 KV MORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6203	.0671	.1174	.0762	.6874	.7712
2		.6203	.0671	.1174	.0838	.6874	.7712
3		.6203	.0671	.1341	.0838	.6874	.7712
4		.6203	.0671	.1341	.1174	.6874	1.0059
5		.6706	.0838	.1341	.1509	.7712	1.0898
6		.7712	.1341	.1341	.1677	.8886	1.2574
7		.9054	.1341	.1677	.218	1.2407	1.3413
8		1.1065	.1341	.1677	.2012	1.5927	1.7436
9		.1509	.1341	.2012	.1844	.1174	.1509
10		1.4922	1.2071	1.5089	.2012	.1174	.1509
11		1.7101	1.5424	1.5927	.1509		.1006
12		1.7101	.503	1.7269	.1509		.1174
13		1.7269	1.6766	1.6766	.1341		.1174
14		1.576	1.576	1.6766	.1174		.1174
15		1.576	1.643	1.6263	.1174		.1341
16		1.643	1.5089	1.5424	.1174		.1341
17		1.643	1.5089	1.5089			.1341
18		.1341	.1006	.1174			.1509
19		.1341	.1174	.1174		.1174	.1677
20		.1341	.1341	.1341		.1844	.1677
21		.1006	.1174	.1174		.2012	.1006
22		.0838	.1174	.1006		.1341	.1006
23		.0838	.1341	.0838		.7712	.7545
24	1.3412	.6203	.0671	.1341	.0838	.6874	.7712
Max	1.3412	1.7269	1.6766	1.7269	.218	1.5927	1.7436
Min	1.3412	.0838	.0671	.0838	.0762	.1174	.1006
Avg	1.3412	.8522	.5351	.6238	.1386	.5983	.5051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 204 / 11 KV KHARSHING AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0503		.6036	.5868	.0335	.0335
2		.0503		.6371	.5868	.0335	.0335
3		.0671		.6706	.5868	.0503	.0503
4		.0671		.7042	.7545	.0503	.0503
5		.0838		.7042	.7545	.0838	.0671
6		.1006		.7377	.8383	.1006	.1006
7		.1341		.9389	.9389	.1341	.1341
8		.1174		1.073	1.1233	.1006	.1174
9		.0838		.1006	.0838	.1006	.1006
10		.0838		.0838	1.073	1.1012	1.2574
11		.1006		.0838	1.3916		1.4754
12		.1006	.0671	.0838	1.3748		1.5592
13		.0671	.0671	.0838	1.4251		1.5592
14		.0671	.0503	.0838	1.4419		1.5424
15		.0671	.0503	.0671	1.4419		1.5089
16		.0671	.0671	.0503	1.4251	1.2742	1.4251
17		.0671	.0671	.0671	1.4251	1.576	1.4251
18		.0838	.0838	.0671		.0671	.1006
19		.1341	.0838	.0838		.0838	.1006
20		.1341	.1006	.1006		.1006	.1006
21		.1174	.1006	.1006		.0671	.0503
22		.0838	.1006	.0838			.0503
23		.5197	.503	.5365		.0335	.0503
24	.067	.0503	.57	.5868	.5868	.0503	.0335
Max	.067	.5197	.57	1.073	1.4419	1.576	1.5592
Min	.067	.0503	.0503	.0503	.0838	.0335	.0335
Avg	.067	.1041	.1470	.3472	.9911	.2801	.5386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 205 / 11 KV SONI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-FEB-18
HR	Load (MW)
11	.0168
12	.0168
13	.0168
14	.0168
15	.0164
16	.0168
Max	.0168
Min	.0164
Avg	.0167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 206 / 11 KV HAROLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0492	.6062	.4096	.5197	.0655	.0655
2		.0492	.6062	.4588	.5197	.0492	.0655
3		.0492	.6062	.5243	.5197	.0492	.0655
4		.0655	.6062	.5898	.5868	.0655	.0655
5		.0655	.6062	.6226	.5868	.0819	.0983
6		.0819	.6718	.6706	.5735	.1147	.0983
7		.1147	.8192	.852	.6554	.1311	.1311
8		.1147	.852	.9175	.7701	.1311	.1311
9		.0655	.0655	.0492	.1067	.1311	.0983
10		.0819	.0819	.0655	.9339	.9831	1.065
11		.0655	.0819	.0655	1.0486		1.1961
12		.0655	.0983	.0819	1.0322		1.1469
13		.0492	.0983	.0819	1.0322		1.1142
14		.0492	.0983	.0819	.9831		1.1142
15			.0983	.0655	.9175		1.1305
16		.0492	.0983	.0655	.9221	1.0159	1.0814
17		.0492	.0983	.0655	.9012	1.1904	1.0814
18		.0655	.1147	.0819		.0819	.0983
19		.1147	.1147	.0819		.0983	.0983
20		.1147	.1311	.0983		.1147	.0983
21		.0983	.1311	.0819		.1147	.0819
22		.0819	.1311	.0655		.0983	.0819
23		.6226	.3605	.5079		.0655	.0655
24	.0492	.0492	.6062	.4096	.5079	.0655	.0655
Max	.0492	.6226	.852	.9175	1.0486	1.1904	1.1961
Min	.0492	.0492	.0655	.0492	.1067	.0492	.0655
Avg	.0492	.0962	.3243	.2914	.7287	.2446	.4308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 201 / 11 KV VITTHALWADI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0724	.0716	.0716	.0739	.0732	.0914
2	.0914	.0724	.0716	.0732	.0739	.0732	.0732
3	.0732	.0732	.0716	.0732	.0739	.0914	.0732
4	.0732	.0943	.1254	.1097	.0739	.0914	.1097
5	.0914	.112	.2658	.1463	.0924	.1097	.1646
6	.1646	.1509	.2126	.1829	.1698	.1646	.1829
7	.2012	.2452	.2658	.2378	.2054	.2195	.2195
8	.2012	.1848	.1949	.1829	.1646	.1463	.1629
9	.1097	.1463	.1214	.1307	.1267	.112	.1086
10	.0732	.0905	.1063	.1307	.0895	.1307	.1097
11	.0701	.0905	.0886	.0876	.0914		.128
12	.0857	.1267	.1063	.0876	.1097		.0914
13	.0895	.1086	.1063	.0838	.0914		.1097
14	.0876	.1267	.0886	.0701	.0914		.1097
15	.0838	.1097	.0886	.0867	.0914		.1097
16	.1017	.1097	.1063	.0914	.0914	.1734	.1097
17	.0995	.128	.124	.081	.128	.1578	.128
18	.1341	.1663	.1646	.112	.1494	.2149	.168
19	.2658	.2587	.2378	.1991	.2241	.2686	.2427
20	.2195	.2218	.2012	.2054	.2054	.2378	.2241
21	.1663	.1848	.1646	.1663	.1867	.1829	.168
22	.1307	.1463	.128	.1294	.1494	.128	.112
23	.0914	.0914	.0914	.0934	.0934	.128	.112
24	.1097	.0747	.0895	.0895	.0732	.0732	.1097
Max	.2658	.2587	.2658	.2378	.2241	.2686	.2427
Min	.0701	.0724	.0716	.0701	.0732	.0732	.0732
Avg	.1211	.1327	.1372	.1218	.1217	.1461	.1341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 202 / 11 KV KEREWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8288	.6562	.132	.1307	.1097	.8288	1.2431
2	.9614	.6562	.132	.112	.1097	.9614	1.442
3	1.0111	.6562	.1698	.1307	.1097	1.0442	1.5249
4	1.2929	.6874	.168	.1494	.1097	1.2597	1.5912
5	1.3592	.7432	.1867	.168	.168	1.3757	1.6057
6	1.4752	.8907	.2402	.2801	.2427	1.6244	1.6712
7	1.5083	1.3592	.3142	.3734	.3206	1.9227	1.7404
8	2.0729	1.6876	.2587	.3174	.2587	2.2211	2.3922
9	.2054	.1949	.1772	.2614	.1991	.2801	.3174
10	.1307	1.5203	1.2793	1.4582	.1578	.168	.112
11	.0876	1.7328	1.8947	1.8623	.1307		.112
12	.1753	1.8138	1.7814	1.9433	.1494		.1307
13	.1595	1.7814	1.7328	1.917	.1494		.1494
14	.1492	1.749	1.7814	1.8842	.1494		.1494
15	.156	1.7004	1.6356	1.5524	.112		.1494
16	.1734	1.668	1.749	1.749	.1307	.1928	.1307
17	.1753	1.6842	1.6356	1.6964	.1867	.2328	.1307
18	.1886	.168	.1663	.156	.1867	.2561	.168
19	.2641	.2427	.2402	.2378	.2801	.2926	.2614
20	.2402	.2614	.2218	.2241	.2427	.2926	.2241
21	.2033	.2054	.2033	.2075	.2241	.2378	.1867
22	.1867	.1886	.1663	.168	.168	.1829	.168
23	.6325	.1698	.1663	.1307	.6299	.6226	.6464
24	.6962	.6325		.1494	.1109	.6796	.9779
Max	2.0729	1.8138	1.8947	1.9433	.6299	2.2211	2.3922
Min	.0876	.168	.132	.112	.1097	.168	.112
Avg	.5972	.9604	.7145	.7191	.1932	.7724	.7177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 203 / 11 KV AGALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.168	.7701	.7865	.8421	.1494	.1478
2	.1494	.168	.9012	.8848	.8745	.1494	.1478
3	.1494	.168	1.1633	1.1961	.9069	.168	.168
4	.1509	.2054	1.6057	1.6057	.9393	.2054	.2054
5	.2829	.2829	1.917	1.9006	.9878	.2987	.3206
6	.3772	.3961	1.9662	2.2592	1.1768	.3734	.4715
7	.4904	.5281	2.2775	2.0645	1.5927	.5041	.6161
8	.4338	.4527	2.0972	2.0972	1.6907	.4108	.415
9	.2829	.3584	.2427		.2033	.2427	.3395
10	1.1603	.2614	.1867	.2054	1.2955	1.3592	1.2597
11	1.587	.2012	.1307	.1867	1.5061		1.442
12	1.7695	.181	.1307	.0739	1.4089		1.4586
13	1.6518	.1629	.112	.1294	1.3279		1.5249
14	1.4575	.1463	.1307	.1307	1.3603		1.6078
15	1.6324	.1086	.1307	.1478	1.2631		1.5415
16	1.7124	.0716		.1267	1.4575	2.3758	1.5581
17	1.8138	.1075	.1494	.1478	1.7328	2.13	
18	.181	.2012	.2241	.1829	.2054	.2561	.2614
19	.3584	.3361	.3921	.3547	.3921	.3734	.4108
20	.3584	.3547	.3734	.2829	.3734	.4108	.3734
21	.3018	.2801	.2801	.2829	.2241	.3174	.2987
22	.2452	.2452	.2241	.2452	.2427	.2614	.2241
23	.1867	.4588	.4752	.8848	.168	.2054	.1867
24	.168	.168	.5735	.5571	.8421	.1494	.168
Max	1.8138	.5281	2.2775	2.2592	1.7328	2.3758	1.6078
Min	.1494	.0716	.112	.0739	.168	.1494	.1478
Avg	.7112	.2505	.7154	.7275	.9589	.5443	.6586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 201 / KHANDERAJURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7127	.7842	.2096	.2096	.1905	.8583	.8648
2	.7127	.7842	.2096	.2096	.1905	.8745	.8551
3	.7127	.8259	.2096	.2096	.1905	.9667	.8551
4	.7373	.8907	.2096	.2096	.1905	1.0402	.8619
5	.8192	.9995	.2477	.3048	.1905	1.1043	1.065
6	1.0526	1.1012	.3395	.381	.2858	1.2289	1.4582
7	1.7814	1.6549	.4572	.4191	.4382	2.0222	2.1538
8	2.4166	2.0481	.381	.4001	.362	2.7199	2.5926
9	.3239	.2477	.1905	.3048	.2858	.2667	.3429
10	.2096	1.8679	1.5249	1.8067	.2096	.2286	.2286
11	.1524	2.1376	2.2211	2.3805	.1715	.1905	.2286
12	.1715	2.3644	2.3102	2.4646	.1524	.1715	
13	.1143	2.2024	1.5546	2.6558	.1524	.1715	
14	.1524	1.9524	2.0481	2.5606	.1524	.1524	
15	.1334	1.9204	1.8023	2.4166	.1715	.1524	
16	.1524	1.8785	2.1628	2.4615	.1715	.1715	
17	.2096	2.0153	2.4086	2.4291	.1715	.2477	
18	.2096	.1715	.2286	.1905	.2286	.2286	
19	.2858	.3429	.362	.3429	.2858	.3429	
20		.3239	.362	.3048	.3239	.3239	
21	.2477	.3048	.3429	.2858	.2858	.2858	
22	.2286	.2667	.3048	.2286	.2667	.2667	
23	.7042	.2286	.2477	.2096	.8356	.9259	
24	1.4748	.8097	.2096	.2096	.2096	.8192	.8817
Max	2.4166	2.3644	2.4086	2.6558	.8356	2.7199	2.5926
Min	.1143	.1715	.1905	.1905	.1524	.1524	.2286
Avg	.5963	1.1718	.8560	.9831	.2547	.6567	1.0324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 202 / 11 KV Khatav

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 203 / 11 KV Mallewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.4287	.4111	.4001	.0953	.0953
2	.1334	.1143	.4239	.4111	.4001	.0953	.0953
3	.1334	.1334	.4239	.3749	.4049	.0953	.0953
4	.1334	.1334	.4359	.3749	.4049	.1143	.1143
5	.1334	.1524	.4915	.4801	.4858	.1143	.1524
6	.1524	.2286	.6962	.5992	.5601	.1905	.2286
7	.1905	.2477	1.0814	1.2003	.8259	.2286	.2477
8	.2286	.1905	1.4413	1.3765	1.0883	.1905	.2286
9	.1905	.1715	.1524	.1905	.1334	.1524	.1715
10	.9116	.1143	.1524	.1334	.9667	.9667	.8065
11	1.4582	.1143	.1715	.1334	1.2125	1.166	1.1012
12	1.4251	.1143	.1524	.1334	1.3765	1.3117	
13	1.3927	.1143	.1524	.1524	1.3927	1.2955	
14	1.3108	.1143	.1524	.1524	1.2308	1.2643	
15	1.3272	.1334	.1524	.1334	1.2452	1.2483	
16	1.3923	.1334	.1524	.1524	1.2407	1.2146	
17	1.4255	.1143	.1334	.1715	.7291	1.2631	
18	.1334	.1143	.1334	.1715	.1334	.1143	
19	.2096	.1905	.2477	.2096	.1905	.1905	
20	.2286	.1715	.2286	.1905	.1905	.1905	
21	.1524	.1715	.1905	.1715	.1524	.1524	
22	.1334	.1524	.1524	.1334	.1334	.1334	
23	.1143	.4458	.4534	.3521	.0953	.0953	
24	.1334	.1143	.4287	.427	.4001	.0953	.0953
Max	1.4582	.4458	1.4413	1.3765	1.3927	1.3117	1.1012
Min	.1143	.1143	.1334	.1334	.0953	.0953	.0953
Avg	.5491	.1583	.3596	.3432	.6414	.4991	.286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 204 / 11 kv shivganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0572	.0953	.0572	.0762	.0762
2	.0762		.0572	.0953	.0762	.0762	.0572
3	.0762	.0762	.0953	.0953	.0762	.0762	.0572
4	.0762	.0762	.0953	.0953	.0762	.0762	.0572
5	.0762	.0762	.0762	.0953	.0762	.0762	.0762
6	.0953	.0762	.0572	.0953	.0762	.0762	.0572
7	.2286	.0572	.0572	.0762	.0953	.2286	.0572
8	.2477	.3239	.0953	.0953	.362	.2667	.1715
9	.1905	.2858	.1334	.2667	.2477	.1905	.0762
10	.1143		.1143	.3048	.2096	.2858	.2858
11	.3429		.3048	.3239	.2858	.1905	.2286
12	.2096		.3048	.3048	.1524	.2667	
13	.3429		.1715	.1715	.1715	.2286	
14			.1143	.2667	.1143	.1524	
15		.2858	.3048	.1524	.2286	.2858	
16	.2667	.2477	.1715	.1334	.2667	.2286	
17	.2667	.2858	.2858	.0762	.2477	.1143	
18	.0762	.3048	.1524	.2477	.2286	.1524	
19	.0762	.1715	.0572	.2667	.2858	.1334	
20	.0953	.0572	.0762	.2286	.2667	.2858	
21	.0762	.0572	.0762	.0762	.1143	.1905	
22	.0762	.0572	.0572	.0572	.0762	.0572	
23	.0762	.1143	.0953	.0572	.0762	.0572	
24	.0762	.0762	.0762	.0953	.0381	.0762	.0762
Max	.3429	.3239	.3048	.3239	.362	.2858	.2858
Min	.0762	.0572	.0572	.0572	.0381	.0572	.0572
Avg	.1472	.1503	.1286	.1572	.1627	.1604	.1064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 205 / 11KV Salgare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5243	.0762	.0953	.1143	.5609	.5596
2	.4801	.5636	.0762	.0953	.1143	.5959	.5596
3	.4801	.6133	.0762	.0953	.1143	.6001	.5533
4	.4801	.6062	.0953	.0953	.1143	.7282	.5868
5	.5144	.639	.1143	.1715	.1143	.8048	.6962
6	.5365	.6882	.1524	.2286	.1715	.9175	.8848
7	.9221	1.073	.1715	.2858	.2858	1.2597	1.1797
8	1.3426	1.0277	.1524	.2477	.2096	1.5565	1.7166
9	.2286			.1905	.1905	.1905	.1143
10	.1905	1.1469	1.1305	1.0322	.1524	.1524	.1524
11	.1715	1.1961	1.4998	1.3094	.1715	.1524	.1143
12	.1334	1.1984	1.5546	1.3592	.0953	.1334	
13	.1143	1.1336	1.4685	1.4419	.0953	.1143	
14	.1143	1.0402	1.4998	1.3603	.1334	.0953	
15	.0762	1.166	1.3937	1.2308	.1143	.0953	
16	.0953	1.2631	1.39	1.278	.0953	.0953	
17	.1715	1.1043	1.4083	1.3763		.1143	
18	.1905	.1334	.1524	.2286	.1524	.1143	
19	.1715	.1715	.2477	.2096	.2096	.1905	
20	.1905	.1905	.2286	.1905	.2096	.1715	
21	.1524	.1524	.1715	.1715	.1524	.1524	
22	.1334	.1143	.1524	.1524	.1334	.1334	
23	.4424	.0953	.1334	.1334	.5935	.583	
24	.4801	.5079	.0762	.0953	.1143	.5721	.583
Max	1.3426	1.2631	1.5546	1.4419	.5935	1.5565	1.7166
Min	.0762	.0953	.0762	.0953	.0953	.0953	.1143
Avg	.3455	.7108	.5836	.5448	.1675	.4202	.6417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 206 / BELANKI gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1334	.1143	.0953	.1143
2	.1143	.1143	.1143	.1334	.1143	.0953	.1143
3	.1143	.1143	.1143	.1334	.1143	.1143	.1143
4	.1143	.1524	.1143	.1334	.1143	.1334	.1524
5	.1143	.2096	.1524	.1905	.1334	.1715	.1905
6	.2286	.2865	.2286	.2858	.2667	.2667	.3048
7	.381		.3239	.362	.362	.333	.362
8	.3048	.3077	.3239	.3239	.3048	.3403	.3429
9	.3048	.2477	.2286	.2096	.1905	.2477	.2858
10	.2096	.2667	.1143	.2096	.2477	.2858	.2715
11	.2096	.2286	.2096	.2096	.2096	.2477	.181
12	.2096	.1715	.1334	.1905	.1334	.2096	
13	.1905	.1524	.1524	.1524	.1334	.1905	
14	.1524	.1334	.1334	.1524	.1334	.1715	
15	.1524	.1334	.1524	.1524	.1334	.2096	
16	.2096	.1524	.1905	.1905	.1334	.0572	
17	.2096	.1715	.1715	.2667	.1334	.1524	
18	.2096	.1334	.1905	.2667	.1334	.1334	
19	.3239	.2667	.2858	.2477	.3048	.2667	
20	.3429	.2477	.3048	.2286	.3239	.2858	
21	.2667	.2286	.2667	.2096	.2477	.2286	
22	.2096	.1905	.1905	.1715	.1905	.1905	
23	.1334	.1143	.1334	.1524	.1143	.1143	
24	.1143	.1143	.1143	.1334	.1143	.0953	.1143
Max	.381	.3077	.3239	.362	.362	.3403	.362
Min	.1143	.1143	.1143	.1334	.1143	.0572	.1143
Avg	.2056	.1849	.1858	.2016	.1834	.1932	.2123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 201 / 11 Kv Arag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)
24	.6874	.1334
Max	.6874	.1334
Min	.6874	.1334
Avg	.6874	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 202 / 11 KV Bedag gav

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)
24	.2096	.2667
Max	.2096	.2667
Min	.2096	.2667
Avg	.2096	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 203 / 11 KV Vijaynagar
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)
24	1.3485	.1524
Max	1.3485	.1524
Min	1.3485	.1524
Avg	1.3485	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 204 / 11 KV Bedag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)
24	.7537	.1715
Max	.7537	.1715
Min	.7537	.1715
Avg	.7537	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 205 / 11 KV rade ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)
24	.2667	1.1336
Max	.2667	1.1336
Min	.2667	1.1336
Avg	.2667	1.1336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 206 / 11 Kv Bolwad Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18
HR	Load (MW)	Load (MW)
11		.7621
24	.7621	
Max	.7621	.7621
Min	.7621	.7621
Avg	.7621	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 201 / 11 kv Erandoli Gav.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	1.0102
Max	1.0102
Min	1.0102
Avg	1.0102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 203 / 11 KV Takali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	.9726
Max	.9726
Min	.9726
Avg	.9726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 204 / 11 kv Erandoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	.2241
Max	.2241
Min	.2241
Avg	.2241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 206 / 11 KV VanKochiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)
11		1.8176
23		.1715
24	.2096	
Max	.2096	1.8176
Min	.2096	.1715
Avg	.2096	.9946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 201 / 11 KV Lingnoor Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0953	.0747	.1132	.0701	.0739	.0953
2	.0747	.0953	.0747	.0924	.0716	.0739	.0762
3	.0747	.0924	.0724	.0914	.0732	.0739	.0762
4	.0747	.0867	.0724	.0701	.0724	.0739	.0762
5	.0934	.0693	.0905	.0686	.0747	.0924	.0934
6	.1132	.0886	.1086	.1132	.1132	.1086	.1132
7	.0943	.1097	.112	.128	.0924	.1097	.132
8	.0953	.112	.1132	.1307	.0934	.1097	.0934
9	.0762	.1143	.0953	.1143	.0943	.0754	.1132
10	.1448	.1463	.1132	.1387	.112	.112	.1595
11	.1334	.1646		.1478	.1629	.1132	.1448
12	.1143	.1478	.1132	.1307	.1478	.132	.128
13	.0953	.1307	.1132	.1307	.1494	.1132	.1267
14	.0953	.1307	.1132	.112	.112	.1132	.0754
15	.0934	.0754	.0943	.0953	.0747	.0943	.0572
16	.0762	.1109	.0739	.0953	.0747	.0754	.0943
17	.0762	.1132	.0739	.0953		.132	.0934
18	.0914	.1097	.0953	.1143	.112	.1417	.124
19	.168	.1509	.1886	.1867	.1663	.2149	.2195
20	.2075	.2241	.2561	.2195	.2054	.2534	.2402
21	.1886	.1867	.2378	.1867	.2054	.2241	.1848
22	.1509	.1509	.168	.168	.1494	.1867	.1509
23	.1143	.1132	.1143	.1029	.1132	.1509	.0953
24	.0943	.0953	.0747	.1132	.0709		.0943
Max	.2075	.2241	.2561	.2195	.2054	.2534	.2402
Min	.0747	.0693	.0724	.0686	.0701	.0739	.0572
Avg	.1090	.1214	.1149	.1233	.1135	.1238	.1191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 202 / 11 KV Shindewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0762	.9831	.9686	.8025	.0747	.0754
2	.0934	.0754	.9831	.9686	.8025	.0747	.0754
3	.0924	.0754	.9831	.9998	.7926	.0747	.0754
4	.0943	.0754	1.0159	1.0311	.7926	.0747	.0754
5	.0943	.0762	1.004	1.0936	.8688	.0747	.0943
6	.1132		1.1012	1.1069	.9374	.0934	.0943
7	.1524	.1132	1.6518	1.5074	1.1984	.1132	.132
8	.1886	.1715	1.8679	2.0809	1.5223	.132	.1524
9	.124	.128	.2218	.128	.208	.1478	.1294
10	1.4752	.1097	.1448	.0754	1.6004	2.2119	1.4899
11	1.6575	.0953		.1132	1.8023	2.0972	1.9334
12	1.9559	.1132	.132	.0754	1.704	1.9662	2.0553
13	2.0553	.132	.1509	.0943	1.8351	1.917	1.9662
14	2.1714	.1509	.1143	.1307	1.749	2.0885	1.9433
15	2.2708	.1509	.1132	.112	1.7532	2.1548	2.0317
16	2.3205	.1307	.112	.112	1.917	2.2542	1.9498
17	2.304	.1494	.1463	.1097	1.9334	1.8564	1.7695
18	.128	.1753	.2035	.1294	.1052	.1267	.124
19	.1307	.1848	.1991	.1991	.1294	.1478	.1494
20	.1307	.1829	.197	.1307	.1294	.1494	.1494
21	.112	.1663	.181	.128	.1307	.1294	.1294
22	.112	.1478	.1254	.1109	.1109	.112	.1086
23	.0754	.8539	.9061	.7621	.0754	.0747	.0754
24	.0934	.0762	.9503	.9374	.7926	.0754	.0754
Max	2.3205	.8539	1.8679	2.0809	1.9334	2.2542	2.0553
Min	.0754	.0754	.112	.0754	.0754	.0747	.0754
Avg	.7516	.1570	.5864	.5461	.9872	.7592	.7023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 203 / 11 KV Landgewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.663	.6642	.5376	.0381	.0381
2	.0381	.0381	.663	.6249	.5312	.0381	.0381
3	.0381	.0381	.663	.6249	.5376	.0381	.0381
4	.0381	.0381	.663	.6562	.5312	.0381	.0381
5	.0572	.0381	.663	.6718	.5376	.0381	.0381
6	.0572	.0381	.7625	.7362	.6009	.0381	.0381
7	.0572	.0381	1.0111	.9175	.7287	.0381	.0381
8	.0381	.0381	1.21	.1905	.8962	.0381	.0381
9	.0381	.0572	.0381	.0572	.0762	.0381	.0572
10	.7522	.0381	.0381	.0381	.8785	.8482	.8421
11	.9442	.0572		.0572	.9667	.8642	.9878
12	1.1843	.0381	.0762	.0572	1.0159	.8642	1.0202
13	1.1523	.0381	.0572	.0381	1.0111	.8962	.9717
14	1.0883	.0381	.0572	.0381	.9945	.8097	.8802
15	.9922	.0381	.0572	.0381	.9945	.7449	.8322
16	.8097	.0381	.0381	.0381	.9945	.6802	.8583
17	1.0526	.0381	.0381	.0381	.9945	.8802	.9393
18	.0381	.0572	.0381	.0572	.0381	.0381	.0572
19	.0572	.0572	.0762	.0953	.0762	.0762	.0762
20	.0762	.0762	.0762	.0953	.0572	.0762	.0762
21	.0762	.0762	.0762	.0953	.0572	.0762	.0572
22	.0762	.0572	.0572	.0762	.0572	.0762	.0572
23	.0381	.5801	.6642	.5312	.0572	.0572	.0381
24	.0381	.0381	.6299	.6642	.5624	.0381	.0572
Max	1.1843	.5801	1.21	.9175	1.0159	.8962	1.0202
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.3657	.0678	.3616	.2959	.5722	.3070	.3380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 204 / 11 KV Lingnoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0105	.9755	.1509	.1509	.1886	1.1469	1.2654
2	1.0235	.9633	.1509	.1509	.1867	1.1469	1.2498
3	1.0364	1.0084	.1509	.1509	.1867	1.1469	1.2346
4	1.0235	1.0987	.1509	.1698	.1867	1.1469	1.25
5	1.1736	1.1574	.1478	.1698	.2075	1.3763	1.3272
6	1.358	1.3904	.2218	.2263	.2829	1.4403	1.7284
7	1.9989	1.5813	.2452	.2641	.2829	1.989	2.1862
8	2.5263	1.9524	.2641	.2641	.2641	2.6189	2.4777
9	.2743	.1791	.2452	.2481	.2534	.2835	.2865
10	.1494	1.9685	2.0485	2.1376	.2614	.2641	.2241
11	.1494	2.2996		2.6216	.2641	.2614	.2263
12	.1867	2.1445	2.5911	2.8837	.2452	.1867	.2641
13	.1867	2.3685	2.5911	2.6216	.2641	.1867	.2452
14	.1867	2.4291	2.5587	2.4939	.2126	.2075	.2452
15	.1867	2.2996	2.3967	2.4006	.2263	.2263	.2427
16	.2033		2.2996	2.3434	.2452	.2829	.2427
17	.2096	2.2245	2.2672	2.372	.2452	.2452	.1886
18	.2033	.2481	.2035	.2263	.2561	.3326	.2507
19	.2241	.2926	.2987	.2829	.2452	.3361	.2801
20		.2614	.2402	.2054	.2427	.3174	.2801
21	.2957	.2587	.2241	.2801	.2427	.3142	.2561
22	.2957	.2218	.2218	.2402	.2218	.2987	.2195
23	1.0364	.1698	.1698	.1867	1.0623	1.1883	.873
24	.9783	1.0031	.1494	.1698	.1867	1.1469	1.3123
Max	2.5263	2.4291	2.5911	2.8837	1.0623	2.6189	2.4777
Min	.1494	.1698	.1478	.1509	.1867	.1867	.1886
Avg	.6920	1.2390	.8690	.9692	.2692	.7538	.7649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 205 / 11 KV Khatav Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7625	.8478	.3018	.3395	.3206	1.073	.9831
2	.7712	.8951	.3018	.3395	.3206	1.073	.9555
3	.7625	.9555	.2896	.3772	.3206	1.073	.9231
4	.8288	.9878	.2896	.3772	.3206	1.2071	1.0364
5	1.1736	1.085	.362	.3772	.3961	1.3748	1.1336
6	1.3748	1.3435	.3982	.4527	.4338	1.6766	1.5729
7	2.1125	1.4918	.4904	.4715	.4527	2.0119	1.9334
8	2.3472	2.0388	.4805	.4715	.4854	2.146	2.2874
9	.3174	.2987	.3772	.3361	.4294	.3395	.3206
10	.2452	1.7368	1.6907	1.5912	.4854	.3772	.3921
11	.3772	2.0222		2.2874	.5601	.415	.3772
12	.4338	2.2211	2.3205	2.3537	.5228	.3961	.4481
13	.4527	.0332	2.2377	2.3205	.4854	.3961	.4481
14	.4527	2.1382	2.1548	.8951	.4854	.415	.4481
15	.4715	2.0553	2.3371	2.146	.4481	.415	.4338
16	.4338	2.1548	2.2874	2.0348	.4481	.4527	.4338
17	.4715	1.8896	2.4863	2.0348	.5601	.5281	.4854
18	.5093	.2987	.2835	.3772	.5975	.6413	.547
19	.5281	.4108	.4904	.4904	.5975	.6413	.6036
20	.5281	.415	.4904	.415	.6036	.6413	.4527
21	.4527	.415	.4715	.415	.5281	.5658	.4572
22	.415	.3395	.4338	.3772	.415	.5281	.3772
23	.6371	.3018	.3395	.3018	.7209	.6464	.5935
24	.7291	.7461	.3018	.3395	.3206	.8718	.8951
Max	2.3472	2.2211	2.4863	2.3537	.7209	2.146	2.2874
Min	.2452	.0332	.2835	.3018	.3206	.3395	.3206
Avg	.7328	1.1301	.9398	.9134	.4691	.8294	.7725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 201 / 11 KV Arag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1886	.1698	.2054	.1886	.2218	.2263
2	.2033	.1509	.1698	.2075	.1886	.2218	.2263
3	.2033		.1698	.2075	.1886	.2218	.2075
4	.2033	.1509	.1698	.2075	.1886	.2218	.2263
5	.2033	.1698	.2075	.2218	.2075	.2587	.2641
6	.2987	.2452	.2829	.2715	.2829	.3326	.3206
7	.4108	.3961	.3961	.3077	.3395	.3734	.415
8	.4024	.362	.3475	.3544	.3584	.4024	.439
9	.3801	.394	.394	.3761	.3696	.3761	.394
10	.362	.3761		.3721	.333	.394	
11	.4115	.3681		.3121	.3982	.3467	
12	.3258	.3506		.3294	.3582	.3045	
13	.3601	.2915		.2915	.3582	.2865	
14	.3258	.3086		.2572	.3582	.2481	
15	.2427	.3467		.2401	.2686	.2804	
16	.2915	.3155		.2572	.2865	.2835	
17	.3294	.2629		.2915	.3224	.2601	
18	.2947	.3582		.3506	.362	.3582	
19	.4161	.4525		.4298	.4805	.4887	
20	.4607	.4572		.4435	.4668	.4572	
21	.462	.3982		.3961	.4294	.4251	
22	.3395	.3258		.3206	.3475	.3696	
23	.2263	.1886		.2263	.2561	.2641	
24	.2218	.2075	.1509	.2054	.2075	.2218	.2452
Max	.462	.4572	.3961	.4435	.4805	.4887	.439
Min	.2033	.1509	.1509	.2054	.1886	.2218	.2075
Avg	.3165	.3072	.2458	.2951	.3144	.3175	.2964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 202 / Arag mix Laxmiwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2452	.8002	.852	.7811	.2641	.2075
2	.2641	.2263	.8162	.852	.7499	.2641	.2075
3	.2641	.2263	.8162	.8259	.7499	.2641	.2075
4	.2263	.2263	.8322	.8259	.7499	.2641	.2075
5	.2829	.2452	.9069	.8259	.7499	.3018	.2263
6	.3206	.2829	1.1174	1.0159	.8436	.3772	.3018
7	.415	.415	1.5238	1.8351	1.1984	.415	.3772
8	.3961	.3584	1.8842	2.0891	1.4243	.3018	.3018
9	.3584	.3018	.3584	.2641	.2829	.2641	.2641
10	1.2452	.2263		.2452	1.1498	1.3443	
11	1.7814	.1886		.2829	1.5729	1.8842	
12	1.8947	.1509		.2641	1.4737	1.8842	
13	1.7444	.1509		.2452	1.5074	1.6876	
14	1.6762	.132		.1698	1.5565	1.5729	
15	1.7124	.132		.2452	1.5729	1.6221	
16	1.6762	.1886		.1886	1.6221	1.7368	
17	1.7497	.2263		.2075	1.7204	1.8233	
18	.2075	.3206		.2452	.1509	.1886	
19	.3584	.3961		.4338	.415	.3961	
20	.1698	.3584		.415	.3961	.3772	
21	.3584	.3206		.3772	.3772	.3584	
22	.3018	.2829		.3395	.3018	.2829	
23	.2829	.7373		.7499	.2641	.2263	
24	.2452	.2641	.7682	.8684	.7811	.2641	.2075
Max	1.8947	.7373	1.8842	2.0891	1.7204	1.8842	.3772
Min	.1698	.132	.3584	.1698	.1509	.1886	.2075
Avg	.7582	.2751	.9824	.6110	.9330	.7652	.2509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 203 / 11 KvAshoknagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.5851	.1132	.1132	.1132	.6478	.703
2	.5344	.5921	.1132	.1132	.1132	.6478	.703
3	.5344	.5921	.1132	.1132	.1132	.583	.6874
4	.4858	.5921	.1132	.1132	.1132	.583	.703
5	.5668	.5937	.1132	.132	.132	.6478	.8322
6	.7287	.7274	.1509	.1509	.1698	.8907	.9831
7	1.491	.9014	.1509	.1509	.1509	1.4255	1.587
8	1.5083	1.2492	.132	.1509	.1509	1.8842	1.9559
9	.1509	.132	.1132	.132	.132	.1698	.1132
10	.132	1.3763		1.4091	.1509	.1132	
11	.0943	1.587		1.692	.132	.1132	
12	.0943	1.1227		1.7284	.132	.0943	
13	.0943	1.5223		1.6129	.132	.132	
14	.1132	1.5061		1.5497	.132	.1132	
15	.132	1.5223		1.5779	.132	.0943	
16	.132	1.4723		1.7284	.132	.0754	
17	.132	1.5043		1.6484	.132	.1132	
18	.132	.1132		.1132	.1698	.0754	
19	.1886	.2075		.1886	.2263	.1886	
20	.1886	.1886		.1698	.2263	.1886	
21	.1886	.1886		.1509	.2075	.1886	
22	.1698	.1698		.1509	.1886	.1509	
23	.5468	.1132		.1132	.7287	.7202	
24	.583	.5624	.1132	.1132	.1132	.6478	.6874
Max	1.5083	1.587	.1509	1.7284	.7287	1.8842	1.9559
Min	.0943	.1132	.1132	.1132	.1132	.0754	.1132
Avg	.3960	.7967	.1226	.6298	.1718	.4370	.8955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 204 / railway station Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3563	.3077	.0943	.0943	.0943	.3563	.2824
2	.3401	.3077	.0754	.0943	.0754	.3563	.2824
3	.3401	.3077	.0754	.0943	.0754	.3401	.2824
4	.3401	.2968	.0754	.0943	.0754	.3401	.2824
5	.3401	.2896	.0943	.0943	.0943	.3725	.2972
6	.421	.2968	.1132	.1132	.0943	.5182	.4062
7	.6478	.4744	.1132	.132	.0943	.6802	.6327
8	.852	.6097	.1132	.1509	.0943	.8192	.787
9	.132	.1132	.1132	.0943	.0566	.0566	.1132
10	.0754	.5487		.6316	.0754	.0754	
11	.0566	.571		.7202	.0754	.0566	
12	.0566	.5792		.6882	.0754	.0754	
13	.0566	.5556		.6401	.0754	.0566	
14	.0566	.4725		.5668	.0754	.0943	
15	.0754	.5247		.5571	.0754	.0377	
16	.0754	.5117		.5937	.0566	.0754	
17	.0754	.535		.759	.0754	.0566	
18	.0943	.0754		.0754	.0754	.0943	
19	.1509	.1698		.132	.132	.1509	
20	.1509	.132		.132	.132	.1509	
21	.1509	.132		.1132	.1132	.132	
22	.132	.1132		.1132	.1132	.1132	
23	.3086	.0943		.0943	.4534	.3749	
24	.4049	.3163	.0943	.0943	.0943	.4049	.2896
Max	.852	.6097	.1132	.759	.4534	.8192	.787
Min	.0566	.0754	.0754	.0754	.0566	.0377	.1132
Avg	.2371	.3473	.0962	.2864	.1022	.2412	.3656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 205 / Malwadi Ag feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.6327	.6882	.5937	.1132	.0943
2	.0943	.1132	.6481	.6718	.578	.1132	.0943
3	.0943	.1132	.6401	.6718	.578	.1132	.0943
4	.0943	.1132	.6636	.664	.5792	.1132	.0943
5	.1132	.132	.759	.664	.6097	.1509	.1132
6	.132	.1698	.9172	.8583	.6554	.1886	.1509
7	.1886	.2075	1.3283	1.5708	1.0753	.2263	.2075
8	.1509	.1886	1.7124	1.7166	1.2176	.2075	.1886
9	.1698	.1509	.1509	.1867	.132	.1886	.1698
10	1.0814	.132		.1886	1.0688	1.0648	
11	1.4842	.1132		.132	1.3279	1.5061	
12	1.5466	.132		.1509	1.2631	1.3757	
13	1.439	.0943		.132	1.2452	1.2963	
14	1.3916	.0943		.1509	1.3765	1.1888	
15	1.3283	.0943		.1509	1.3272	1.1736	
16	1.3592	.0943		.132	1.3927	1.0185	
17	1.4548	.1132		.1509	1.4255	1.2963	
18	.1509	.1509		.1509	.1132	.0943	
19	.2075	.2263		.1886	.1698	.3772	
20	.2075			.2075	.1698	.2075	
21	.2075	.1886		.1886	.1698	.1509	
22	.1698	.1509		.1698	.1509	.132	
23	.132	.664		.6249	.1132	.1132	
24	.1132	.1132	.6097	.6882	.6249	.1132	.0943
Max	1.5466	.664	1.7124	1.7166	1.4255	1.5061	.2075
Min	.0943	.0943	.1509	.132	.1132	.0943	.0943
Avg	.5593	.1593	.8062	.4625	.7482	.5218	.1302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 201 / Salgare Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 202 / Chabukswarwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 203 / Janraowadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 202 / 11 KV BHIVARGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
23	1.9433
Max	1.9433
Min	1.9433
Avg	1.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 203 / 11 KV ANKALGI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18
HR	Load (MW)
23	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 204 / 11 KV SANKH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 205 / 11 KV ANKALGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	2.0243
Max	2.0243
Min	2.0243
Avg	2.0243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 206 / 11 KV ASANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	2.1052
Max	2.1052
Min	2.1052
Avg	2.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 207 / 11 KV SANKH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	3.0769
Max	3.0769
Min	3.0769
Avg	3.0769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 201 / 11 KV AKKALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.6539	.1334	.1334	.1524	1.0526	.9012
2	.8288	.7127	.1524	.1334		1.1271	.9945
3	.8907	.779	.1524	.1334	.1334	1.2266	1.2574
4	1.0059	.8619	.1715	.1524	.1524	1.3413	1.3592
5	1.0774	.9339	.1905	.1524	.1715	1.4089	1.4419
6	1.2431	.9831	.1905	.1715	.1715	1.5384	1.5384
7	1.6385	1.2289	.2286	.2286	.1905	1.749	1.7604
8	1.7004	1.4575	.2096	.2096		1.9662	2.0243
9	.1715	.2667	.1905	.2286	.1905	.1334	.1143
10	.1715	1.3279	.8907	1.2146	.1524	.1715	.1524
11	.1715	1.6194	1.7604	1.7814	.2096	.1524	.1334
12	.0953	1.7204	1.9662	2.0317	.2286	.1524	.1524
13	.1334	1.5708	2.0243	2.0243	.2286		.2096
14	.1715	1.5223	1.8404		.2096		.1143
15		1.6194	1.8299	1.9662	.2286	.1619	.1715
16		1.7814	2.0481	1.9433	.2286	.1715	.1715
17		1.668	1.9334	1.7004	.2286	.1143	.1143
18	.1905	.1715	.1905	.1715	.2477	.1524	.1905
19	.1715	.1905	.1715	.1905	.1715	.2477	.1905
20	.2096	.2096	.2096	.2286	.1334	.2286	.1715
21	.2096	.1905	.1905	.1905	.1524	.2096	.1715
22	.2096	.1715	.1715	.1715	.1334	.1905	.1905
23	.3353	.1524	.1715	.1524	.8192	.6722	.583
24	.4858	.5365	.1334	.1334	.1524	.9831	.8097
Max	1.7004	1.7814	2.0481	2.0317	.8192	1.9662	2.0243
Min	.0953	.1524	.1334	.1334	.1334	.1143	.1143
Avg	.5603	.9304	.7146	.6715	.2130	.6887	.6216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 202 / 11 KV BORGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1524	1.4575	1.3765	1.5384	.1334	.1334
2	.1715	.1524	1.6194	1.5912	1.7859	.1334	.1334
3	.1715	.1715	1.6804	1.7269	1.8623	.1715	.1524
4	.1905	.2096	1.8185	1.7814	1.9204	.1905	.1715
5	.2096	.2286	2.1605	1.989	2.0243	.2096	.1715
6	.2667	.2667	2.3644	2.7854	2.0481	.2667	.2286
7	.362	.2667	2.6397	2.5101	2.5888	.3239	.3429
8	.3429	.3239	2.8664	2.9607	2.3205	.3239	.3048
9	.2667	.3239	.2477	.2667	.2286	.2667	.2477
10	1.8724	.2286	.2477	.2858	2.2024	2.2565	2.251
11	2.9527	.1715	.1524	.2858	2.8807	2.7854	2.9329
12	2.4939	.1715	.1905	.3239	2.8826	3.2648	.583
13	2.0481	.1905	.2477	.1905	3.195	2.9473	1.2289
14	3.0464	.1524	.2096	.1905	2.7046	2.9492	2.769
15	3.1089	.1524	.2667	.1715	2.8988	2.9287	3.1093
16	2.9571	.1715	.3048	.1905	2.7692		3.0445
17	2.6558	.2096	.2667	.1905	2.8967	3.1741	1.6194
18	.2667	.2667	.3239	.2667	.1905	.2096	.1715
19	.2667	.381	.381	.3048	.3048	.3239	.2858
20	.2858	.3429	.3429	.2858	.2667	.3048	.2667
21	.2096	.2667	.2667	.2477	.2286	.2286	.2286
22	.1905	.2477	.1905	.1905	.1715	.1905	.1905
23	.1715	.9717	.9762	1.1336	.1715	.1524	.1905
24	.1334	.1715	1.2289	1.2163	1.3108	.1524	.1524
Max	3.1089	.9717	2.8664	2.9607	3.195	3.2648	3.1093
Min	.1334	.1524	.1524	.1715	.1715	.1334	.1334
Avg	1.0323	.2580	.9354	.9359	1.7247	1.0386	.8713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 203 / 11 KV BALGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1			1.1142
2			1.1934
3			1.4754
4			1.5746
5			1.9662
6			2.5101
7			2.7206
8			2.834
9			.2858
10			.3239
11			.2667
12			.2286
13			.362
14			.3429
15		.1334	.3429
16			.3048
17		.1334	.2096
18		.2286	.1715
19		.381	.3429
20		.3429	.2858
21		.2667	.2667
22		.2667	.1905
23		.8002	.7125
24	.6478		.9717
Max	.6478	.8002	2.834
Min	.6478	.1334	.1715
Avg	.6478	.3191	.8749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 204 / 11 KV AKKALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0762	.0572	.0762	.0572	.0572
2	.0572	.0572	.0762	.0572	.0572	.0572	.0572
3	.0762	.0572	.0572	.0572	.0572	.0762	.0762
4	.0762	.0762	.0572	.0762	.0762	.0762	.0762
5	.0953	.0762	.1524	.0762	.1143	.0953	.0953
6	.1334	.0953	.1715	.1143	.1715	.1143	.0953
7	.1715	.1143	.1524	.1715	.1905	.1524	.1143
8	.1334	.1143	.1715	.1334	.1715	.1524	.1143
9	.1143	.0953	.1334	.0953	.1524	.1143	.0572
10	.0762	.0953	.1143	.0762	.1143	.0762	.0572
11	.0762	.0762	.0572	.0762	.0572	.0572	.0572
12	.0572	.0762	.0572	.0762	.0572	.0572	.0572
13	.0572	.0572	.0572	.0572	.0572		.0572
14	.0572	.0572	.0572	.0572	.0572		.0572
15	.0572	.0762	.0572	.0762	.0572	.0572	.0572
16	.0572	.0953	.0572	.0953	.0572	.0572	.0572
17	.0762	.0953	.0762	.0953	.0762	.0572	.0762
18	.0762	.1524	.1143	.1524	.0762	.0953	.0762
19	.1143	.1715	.1715	.1715	.1524	.1334	.1143
20	.1334	.1905	.1524	.1905	.1143	.1143	.0953
21	.0953	.1715	.1334	.1715	.0953	.1143	.0762
22	.0762	.1524	.0953	.1524	.0762	.0572	.0762
23	.0762	.1334	.0762	.1143	.0572	.0572	.0762
24	.0572	.0572	.0953	.0572	.0953	.0572	.0572
Max	.1715	.1905	.1715	.1905	.1905	.1524	.1143
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0858	.1000	.1008	.1024	.0945	.0858	.0746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 205 / 11 KV BORGI BALGAON

GAVTHAN Feeder KV- 11 /

OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.0762
2			.0953
3			.1143
4			.1334
5			.1715
6			.2096
7			.2286
8			.2286
9			.1715
10			.0953
11			.1143
12			.1143
13			.0762
14			.0762
15		.0953	.0762
16			.0762
17		.1143	.1143
18		.1524	.1715
19		.2477	.2096
20		.1905	.2286
21		.1143	.1334
22		.0762	.0953
23		.0762	.0762
24	.0953		.0762
Max	.0953	.2477	.2286
Min	.0953	.0762	.0762
Avg	.0953	.1334	.1318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 201 / 11 KV SUSLAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	2.3482
Max	2.3482
Min	2.3482
Avg	2.3482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 202 / 11 KV UMADI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1286	.1238	.1174	.2469	.2743
2		.1303	.1115	.104	.3001	.2572
3		.1174	.1115	.1158	.2534	.2134
4		.1448	.1238	.141	.2286	.3001
5		.2	.161	.1947	.2667	.2896
6		.2429	.2105	.2782	.3185	.2715
7		.3001	.2724	.3616	.3475	.3227
8		.2896	.3344	.3018	.3199	.3286
9	.1646	.2572	.2808	.2667	.2202	.3024
10	.1509	.1974	.2629	.1709	.1943	.192
11	.1646	.1593		.1555		.1627
12	.1646	.1656	.1858	.1143		.1461
13	.1235	.1509	.1536	.168		.1326
14	.1143	.1509	.1372	.1143		.1278
15	.1158	.1858	.1536	.1395		.1143
16	.1303	.1572	.1511	.168	.144	.1395
17	.1429	.1738	.1372	.1417	.2073	.1153
18	.1692	.2	.1858	.2286	.2126	.1932
19	.2256	.2462	.2591	.2801	.2477	.1806
20	.2538	.2027	.2892	.2743	.2801	.2
21	.2572	.1715	.2667	.2534	.2643	.1882
22	.2	.1715	.2058	.1833	.1734	.1783
23			.1669	.2	.1486	.1783
24	.1219	.141	.1238	.1429	.2134	.1867
Max	.2572	.3001	.3344	.3616	.3475	.3286
Min	.1143	.1174	.1115	.104	.144	.1143
Avg	.1666	.1863	.1917	.1923	.2414	.2081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 203 / 11 KV SONALGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431	2.6139	2.1125	.9335	.7468
2		.8676	2.838	2.1691	.9808	.8488
3		.8299	3.0807	2.6029	1.0185	.9431
4		.8215	2.9874	2.6406	.905	.8029
5		.9149	3.2114	2.8104	.9149	1.0562
6		.9896	3.2065	2.9801	.9997	.9335
7		1.0456	3.2114	3.0556	1.0456	1.0082
8		1.0269	3.81	2.2634	.8962	1.0082
9	.8676	.9709	.5281	.6722	.8589	.9709
10	3.4328	.9054	.6413	1.6221	2.1691	2.4331
11	3.4894	.8962		2.7538		2.9047
12	3.4328	.8962	.9054	2.6406		3.4675
13	3.2442	.8962	.9431	3.1436		3.5437
14	3.2065	.8962	.9808	3.3722		3.4865
15	3.3951	.8871	.9808	3.1436		3.5056
16	3.3951	.8962	.9431	3.0556	2.2218	3.3913
17	3.4328	.8962	.9054	3.0556	3.4484	2.396
18	.8962	.8962	.9431	.7468	.6348	.7922
19	.9709	.9709	.9808	.8589	.7545	.7468
20	.9335	1.0642	1.0185	.8029	.9522	.7023
21	.9709	.7842	.6036	.8145	.9896	.7282
22	.9808	.7282	1.8861	.8962	.7468	.7468
23			2.0748	.9431	.8589	.8029
24	.8589	.9431	2.2218	2.0748	.9149	.9431
Max	3.4894	1.0642	3.81	3.3722	3.4484	3.5437
Min	.8589	.7282	.5281	.6722	.6348	.7023
Avg	2.2338	.9116	1.8050	2.1346	1.1707	1.6212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 204 / 11 KV UMADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	2.9959
Max	2.9959
Min	2.9959
Avg	2.9959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 205 / 11 KV SUSLAD GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0373	.0187	.0366	.1097
2		.0189	.0377	.0187	.0509	.0747
3		.0189	.0189	.0377	.0905	.0905
4		.0377	.0189	.0566	.0373	.1075
5		.0566	.0377	.0747	.0549	.0747
6		.0943	.0754	.0943	.0739	.0914
7		.1698	.1267	.1267	.0566	.112
8		.1132	.112	.1075	.0566	.0914
9	.0724	.0924	.0709	.0732	.0381	.056
10	.0739	.0554	.0905	.0543	.0312	.0671
11	.0739	.037		.0373		.0554
12	.0747	.0554	.0554	.0343		.0373
13	.056	.037	.0373	.0724		.0566
14	.056	.0377	.0377	.0549		.0377
15	.0373	.0189	.0168	.0492		.0373
16	.0373	.0377	.0305	.0339	.0335	.0554
17	.0747	.0924	.0446	.0602	.0526	.0511
18	.112	.1109	.0602	.0762	.112	.056
19	.1509	.1478	.081	.12	.0857	.0377
20	.1509	.1478	.1174	.0648	.0648	.0554
21	.132	.0732	.0857	.0914	.1063	.0747
22	.0377	.0739	.0514	.0554	.0543	.0732
23			.0351	.0724	.0739	.0549
24	.0543	.0377	.0373	.0362	.0514	.0934
Max	.1509	.1698	.1267	.1267	.112	.112
Min	.0373	.0189	.0168	.0187	.0312	.0373
Avg	.0796	.0697	.0572	.0634	.0611	.0688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 201 / 11 KV MADGYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336	.852	.1829	.2103	.2103	1.4089	1.326
2	1.1336	.852	.1829	.2172	.2103	1.3927	1.326
3	1.2146	.9602	.1829	.2172	.2629	1.4746	1.4575
4	1.3765	1.2003	.2195	.3121	.3467	1.6575	1.4575
5	1.9662	1.6004	.2926	.3856	.3467	1.989	1.9662
6	2.3205	1.6004	.3658	.5609	.3856	2.3758	2.652
7		1.9281	.4572	.583	.4382	2.0481	3.0178
8	2.5587	2.6406	.3292	.6335	.4382	2.672	2.982
9	.4607	.2829	.1829	.4557	.4477	.3292	.3856
10	.3224	1.4403	1.7814	.7287	.2126	.1791	.1791
11	.1715	1.467	2.6216	2.2119	.1629	.1646	.1772
12	.1772	2.3482	2.6216	2.5194	.1463	.181	.1772
13		2.4291	2.7846	2.7349	.1629	.2801	.1791
14	.2172	2.6825	2.7035	2.652	.1629	.2743	.1619
15		2.6216	2.652	3.0178	.1646	.2987	.1619
16	.2896	2.5396	2.7349	3.2007	.1829	.2743	.1619
17	.2772	1.2289	2.9172	1.6804	.1829	.2601	.2263
18	.3734	.2195	.3326	.3239	.2195	.362	.3258
19	.2743	.2926	.4854	.3467	.2926	.4572	.3189
20	.2658	.3292	.4382	.3224	.3258	.5068	.3189
21	.2658	.2743	.3467	.3155	.2353	.4607	.3582
22	.2658	.2378	.3224	.3155	.2012	.362	.3582
23	.6859	.1829	.2804	.2658	.6706	.852	.6859
24	.6562	.7865	.1829	.2103	.2103	1.326	1.2431
Max	2.5587	2.6825	2.9172	3.2007	.6706	2.672	3.0178
Min	.1715	.1829	.1829	.2103	.1463	.1646	.1619
Avg	.7813	1.2915	1.0667	1.0176	.2758	.8994	.9002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 202 / 11 KV SONYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.0463	.3201	.2372	.2343	.0503	.048
2	.032	.0474	.3201	.3163	.2343	.0486	.048
3	.032	.0469	.3201	.3163	.3163	.0486	.048
4	.0324	.0486	.3201	.3201	.3953	.0486	.0648
5	.0648	.0655	.4049	.4001	.5535	.0648	.081
6	.0983	.0655	.4858	.5182	.6401	.0819	.0972
7		.0655	.6154	.7449	.6401	.0972	.1147
8	.081	.0819	.6249	.7907	.6173	.064	.0983
9	.0625	.0474	.0633	.064	.0486	.048	.0648
10	.3479	.0469	.0486	.0625	.3858	.4062	.4687
11	.7287	.0579	.0625	.048	.6173	.6401	.6249
12	.7125	.0457	.0625	.048	.4458	.703	.6562
13		.0474	.0617	.0469	.6097	.7407	.6249
14	.7116	.064	.0617	.0469	.6481	.6944	.5647
15		.064	.061	.0316	.6859	.6706	.5647
16	.6401	.064	.061	.0316	.6687	.6249	.5647
17	.6325	.0469	.0602	.0278	.5792	.6562	.3239
18	.0457	.064	.0469	.0469	.0463	.0625	.0469
19	.064	.08	.08	.0474	.0633	.0937	.0469
20	.064	.081	.08	.0791	.08	.0781	.0469
21	.064	.064	.0633	.0791	.0633	.0781	.0469
22	.048	.048	.0633	.0633	.0469	.0625	.0469
23	.048	.192	.1543	.2543	.048	.0625	.0492
24	.0316	.0463	.2881	.2372	.2343	.0486	.048
Max	.7287	.192	.6249	.7907	.6859	.7407	.6562
Min	.0316	.0457	.0469	.0278	.0463	.048	.0469
Avg	.2178	.0636	.1971	.2024	.3709	.2573	.2246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 203 / 11 KV UTAGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2972	.3286	.0486	.0486	.0474	.5068	.5335
2	.3048	.3429	.0486	.0486	.0474	.5944	.5401
3	.381	.4115	.0486	.0486	.0474	.5944	.5468
4	.4687	.5001	.0486	.081	.0983	.6097	.6249
5	.6642	.5868	.081	.1311	.1311	.7621	.6562
6	.8642	.6401	.1457	.2458	.1638	.7716	.759
7		.6401	.1781	.2949	.1966	1.186	1.1336
8	.9877	1.1069	.0095	.2622	.1966	1.1431	.945
9	.1943	.192	.1296	.1581	.192	.128	.144
10	.1296	.7727	.6944	.6325	.1296	.048	.08
11	.0648	.7964	1.0936	.9717	.064	.064	.0474
12	.0648	.7859	1.1248	1.07		.064	.0474
13		.7859	1.1873	1.07	.0633	.0781	.0469
14	.0648	.9907	1.0802	.8916	.0633	.061	.0474
15		1.0669	1.0059	1.0402	.0633	.0572	.0469
16	.064	1.1431	1.0669	1.07	.0633	.0617	.0469
17	.0316	.362	1.0974	.5411	.08	.0949	.061
18	.0633	.0791	.128	.0937	.1107	.125	.08
19	.0633	.1147	.1966	.0949	.128	.1265	.0791
20	.064	.1311	.1619	.096	.1296	.1107	.0781
21	.0633	.096	.144	.08	.0781	.1107	.0463
22	.0633	.0625	.0791	.064	.0617	.061	.0463
23	.1578	.0486	.064	.048	.2858	.3144	.2225
24	.2	.2629	.0486	.0486	.0474	.5068	.4572
Max	.9877	1.1431	1.1873	1.07	.2858	1.186	1.1336
Min	.0316	.0486	.0095	.048	.0474	.048	.0463
Avg	.2503	.5103	.4130	.3805	.1082	.3408	.3049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 204 / 11 KV SONYAL GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0366	.0566	.0566	.0566	.0747	.0566
2	.056	.0366	.0566	.0566	.0566	.0747	.056
3	.056	.0732	.0566	.056	.0566	.0934	.056
4	.0943	.1097	.0943	.0934	.1109	.1132	.0934
5	.1886	.1829	.1886	.1494	.1478	.2075	.132
6	.2829	.3292	.3206	.2829	.2195	.3206	.2075
7		.3841	.2829	.3395	.3109	.3206	.3292
8	.3174	.3475	.2427	.3018	.2926	.3395	.2801
9	.2587	.2195	.2054	.2241	.2378	.2402	.2427
10	.1663	.1646	.112	.1848	.1463	.2172	.168
11	.1097	.1052	.1097	.1097	.0934	.1629	.1097
12	.1097	.0739	.0732	.0732	.0701	.0526	.0732
13		.0739	.0732	.0732	.0716	.0343	.0732
14	.0924	.0543	.0716	.0732	.0532	.052	.0549
15		.0701	.0709	.0732	.0532	.0526	.0732
16	.0554	.1029	.0876	.0732	.0686	.0724	.0914
17	.1109	.112	.0983	.0732	.0895	.1267	.128
18	.1848	.1638	.1578	.1829	.1543	.1646	.1829
19	.2218	.2561	.2865	.2743	.2279	.2743	.2743
20	.2772	.2743	.2534	.3292	.2743	.2033	.2195
21	.2772	.2033	.1829	.2195	.2012	.1663	.1097
22	.1478	.1132	.112	.1097	.1267	.1132	.1097
23	.0747	.0754	.0566	.0549	.0934	.056	.0549
24	.056	.037	.0566	.0566	.0549	.0747	.0566
Max	.3174	.3841	.3206	.3395	.3109	.3395	.3292
Min	.0554	.0366	.0566	.0549	.0532	.0343	.0549
Avg	.1521	.1500	.1378	.1467	.1362	.1503	.1347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 205 / 11 KV UTAGI VHASPETH

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /

OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0943	.0549	.0566	.0566	.0549	.056
2	.056	.0943	.0549	.0566	.0566	.0549	.056
3	.056	.0943	.0549	.0566	.0566	.0549	.056
4	.0754	.0943	.0549	.0747	.0566	.0549	.0754
5	.0943	.0943	.0732	.0934		.0732	.0943
6	.132	.1132	.0914	.1132	.0943	.0914	.1307
7		.1698	.128	.168	.1132	.128	.1698
8	.0934	.1294	.0549	.168	.0754	.1097	.112
9	.1086	.0905	.128	.1448	.0914	.0914	.1254
10	.1294	.1075	.1294	.1267	.1063	.0732	.1075
11	.1109	.1478	.0914	.1086	.1267	.0732	.1063
12	.0943	.1478	.0914	.1086	.128	.0724	.1063
13		.1478	.0934	.1097	.128	.0709	.0732
14	.0943	.1109	.0914	.0724	.128	.0724	.0532
15		.128	.1086	.0724	.128	.0876	.0678
16	.0914	.128	.0895	.0905	.128	.0905	.0848
17	.0937	.0732	.0876	.096	.1463	.1109	.1294
18	.1265	.1097	.0924	.128	.1463	.1029	.1294
19	.1448	.1463	.181	.1296	.1646	.1646	.1478
20	.1629	.1612	.168	.1311	.1829	.2012	.1663
21	.1646	.1097	.1494	.0983	.128	.1991	.1132
22	.1509	.0914	.112	.0943	.0914	.1307	.0943
23	.1132	.0732	.0754	.0943	.0549	.1109	.0754
24	.0739	.0943	.0549	.0566	.0566	.0549	.0747
Max	.1646	.1698	.181	.168	.1829	.2012	.1698
Min	.0554	.0732	.0549	.0566	.0549	.0549	.0532
Avg	.1058	.1146	.0963	.1020	.1063	.0970	.1002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 206 / 11 KV LAMANTANDA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	.0162
Max	.0162
Min	.0162
Avg	.0162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 207 / 11 KV JADAR BOBALAD AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.2957	.3361
2		.2957	.3361
3		.2957	.3658
4		.2957	.462
5		.3361	.5914
6		.4108	.7282
7		.5601	.6401
8		.5601	.7095
9		.5544	.7392
10		1.7004	1.7404
11		2.3205	2.2377
12		2.2939	2.4697
13		2.332	2.3205
14		1.9433	2.2874
15		1.866	2.3205
16		1.8976	2.3868
17		2.0805	1.0111
18		.3658	.431
19		.6401	.431
20		.5792	.4144
21		.5914	.3647
22		.5853	.3647
23		.4572	.3315
24	.4066	.2957	.3361
Max	.4066	2.332	2.4697
Min	.4066	.2957	.3315
Avg	.4066	.9814	1.0148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 201 / 11 KV SIDHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	1.3108	.1638	.1638	.1638	.9831	.9831
2	.6554	1.3108	.1638	.1638	.1638	.9831	.9831
3	.6554	1.3108	.1638	.1638	.1638	.9831	.9831
4	.6554	1.3108	.1638	.1638	.1638	1.1469	1.4746
5	.8192	1.4746	.1638	.1638	.1638	1.1469	1.6385
6	1.4746	1.4746	.1638	.2458	.2458	1.6385	1.9662
7	1.8023	1.6385	.1638	.2458	.2458	1.9662	2.0481
8	2.2119	2.0481	.1638	.1638	.2458	2.13	1.9662
9	.1638	.1638	.1638	.1638	.1638	.2458	.1638
10	.1638	1.3927	1.2289	1.8023	.1638	.2458	.1638
11	.1638	1.7204	1.9662	1.8023	.1638	.2458	.1638
12	.1638	1.8842	2.13	2.13	.1638	.2458	.1638
13	.1638	1.8842	2.13	2.13	.1638	.2458	.1638
14	.1638	1.9662	2.13	2.13	.2458	.2458	.1638
15	.1638	1.9662	1.8023	1.6385	.2458	.2458	.2458
16	.1638	2.13	1.9662	1.9662	.2458	.2458	.2458
17	.1638	2.13	1.9662	1.9662	.2458	.2458	.2458
18	.1638	.1638	.1638	.1638	.2458	.2458	.2458
19	.1638	.1638	.1638	.1638	.2458	.1638	.1638
20	.1638	.1638	.1638	.1638	.2458	.1638	.1638
21	.1638	.1638	.1638	.1638	.2458	.1638	.1638
22	.1638	.1638	.1638	.1638	.1638	.1638	.1638
23	.9831	.1638	.1886	.1638	.6554	.6554	.6554
24	.4915	1.1469	.1638	.1638	.1638	.8192	.8192
Max	2.2119	2.13	2.13	2.13	.6554	2.13	2.0481
Min	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Avg	.5253	1.2186	.7486	.7646	.2219	.6486	.6724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 202 / 11 KV DARIKONUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.1638	.8192	.8192	.4915	.0819	.0819
2	.0819	.1638	.9831	.8192	.4915	.0819	.0819
3	.0819	.1638	.9831	.8192	.4915	.0819	.0819
4	.0819	.1638	1.1469	.8192	.4915	.0819	.0819
5	.0819	.1638	1.1469	.9831	.6554	.0819	.0819
6	.1638	.1638	1.3108	1.1469	.8192	.0819	.0819
7	.1638	.1638	1.3108	1.1469	1.3108	.1638	.1638
8	.1638	.1638	1.4746	1.4746	1.3108	.1638	.1638
9	.0819	.1638	.1638	.0819	.1638	.1638	.1638
10	1.4746	.1638	.1638	.0819	.8192	.9831	.9831
11	1.4746	.1638	.1638	.0819	1.4746	1.4746	1.6385
12	.9831	.1638	.1638	.0819	1.6385	1.6385	1.6385
13	1.4746	.1638	.1638	.0819	1.6385	1.6385	1.6385
14	1.4746	.1638	.0819	.0819	1.6385	1.6385	1.4746
15	1.4746	.1638	.0819	.0819	1.6385	1.6385	1.3108
16	1.4746	.1638	.0819	.0819	1.6385	.1638	1.3108
17	1.3108	.1638	.0819	.0819	1.4746	1.6385	.6554
18	.1638	.1638	.1638	.1638	.1638	.0819	.0819
19	.1638	.1638	.1638	.1638	.1638	.0819	.0819
20	.1638	.1638	.1638	.1638	.1638	.0819	.1638
21	.1638	.1638	.1638	.1638	.0819	.0819	.1638
22	.1638	.1638	.1638	.1638	.0819	.0819	.0819
23	.1638	.6554	.6554	.3277	.0819	.0819	.0819
24	.0819	.1638	.8192	.8192	.4915	.0819	.0819
Max	1.4746	.6554	1.4746	1.4746	1.6385	1.6385	1.6385
Min	.0819	.1638	.0819	.0819	.0819	.0819	.0819
Avg	.5495	.1843	.5257	.4471	.8090	.5154	.5154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 203 / 11 KV SHEDYAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0754	.0566	.0566	.0754	.0754	.0566	.0754
7	.0754	.0566	.0566	.0754	.0754	.0566	.0754
8	.0754	.0566	.0566	.0566	.0754	.0566	.0754
9	.0566	.0566	.0566	.0566	.0566	.0566	.0566
10	.0566	.0566	.0566	.0566	.0566	.0566	.0566
11	.0566	.0566	.0566	.0566	.0566	.0566	.0566
12	.0492	.0566	.0566	.0566	.0492	.0566	.0566
13	.0566	.0566	.0566	.0566	.0566	.0566	.0377
14	.0566	.0566	.0566	.0566	.0566	.0377	.0566
15	.0566	.0566	.0566	.0566	.0566	.0566	.0566
16	.0566	.0566	.0566	.0566	.0566	.0566	.0566
17	.0566	.0566	.0492	.0566	.0566	.0566	.0566
18	.0566	.0566	.0943	.0943	.0943	.0566	.0754
19	.0943	.0943	.0943	.0943	.0943	.1132	.0943
20	.0943	.0943	.0943	.0819	.0943	.1132	.0943
21	.0943	.0943	.0943	.0943	.0943	.1132	.0943
22	.0566	.0566	.0566	.0943	.0566	.0754	.0754
23	.0566	.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.0943	.0943	.0943	.0943	.0943	.1132	.0943
Min	.0492	.0566	.0492	.0566	.0492	.0377	.0377
Avg	.0634	.0613	.0626	.0655	.0649	.0637	.0644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 204 / 11 KV SHEDYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.1696	1.1869	.8192	.6554	.0848	.0848
2	.0819	.1696	1.1869	.8192	.6554	.0848	.0848
3	.0819	.1696	1.5261	.8192	.6554	.0848	.0848
4	.0819	.1696	1.6956	.8192	.8192	.0848	.0848
5	.0819	.1696	2.0348	1.4746	1.3108	.0848	.1696
6	.1638	.1696	2.0348	1.9662	1.4746	.1696	.1696
7	.1638	.1696	2.2043	2.0481	1.9662	.1696	.1696
8	.1638	.1696	2.3739	2.2939	1.9662	.1696	.1696
9	.0819	.1696	.1696	.0819	.1638	.1696	.1696
10	2.0481	.1696	.1696	.0819	1.6385	1.5261	1.3565
11	2.0481	.1696	.1696	.0819	2.13	2.2043	2.0348
12	1.6385	.1696	.1696	.1311	2.2939	2.2043	2.2043
13	2.0348	.1696	.1638	.1509	2.2043	2.2043	2.2043
14	2.2043	.1696	.0819	.1311	2.2043	2.2043	2.2043
15	2.2043	.1696	.0819	.1311	2.2043	2.2043	2.2043
16	2.0348	.1696	.0819	.1311	2.2043	2.3739	2.2043
17	2.2043	.1696	.0819	.1311	2.2043	2.2891	1.3565
18	.1696	.1696	.1638	.1638	.1696	.0848	.1696
19	.1696	.1696	.1638	.1638	.1696	.1696	.1696
20	.1696	.1696	.1638	.1638	.1696	.1696	.1696
21	.1696	.1696	.1638	.1638	.1696	.1696	.1696
22	.1696	.1696	.1638	.1638	.1696	.1696	.1696
23	.1696	.8478	.6554	.4915	.0848	.1696	.1696
24	.0819	.1696	.8478	.8192	.6554	.0848	.0848
Max	2.2043	.8478	2.3739	2.2939	2.2939	2.3739	2.2043
Min	.0819	.1696	.0819	.0819	.0848	.0848	.0848
Avg	.7708	.1979	.7390	.5934	1.1808	.8054	.7525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 205 / 11 KV DARIKONUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	
2	.0566	.0566	.0566	.0566	.0566	.0566	
3	.0566	.0566	.0566	.0566	.0566	.0566	
4	.0566	.0566	.0566	.0566	.0566	.0566	
5	.0566	.0566	.0566	.0566	.0566	.0566	
6	.0754	.0566	.0566	.0754	.0754	.0566	
7	.0754	.0566	.0566	.0754	.0754	.0566	
8	.0754	.0566	.0566	.0566	.0754	.0566	.0566
9	.0566	.0566	.0566	.0566	.0566	.0566	.0566
10	.0566	.0566	.0566	.0566	.0566	.0566	.0566
11	.0566	.0566	.0566	.0566	.0377	.0566	.0566
12	.0566	.0566	.0566	.0566	.0566	.0566	.0566
13	.0566	.0566	.0566	.0566	.0377	.0377	.0377
14	.0566	.0566	.0566	.0566	.0377	.0377	.0377
15	.0566	.0566	.0566	.0566	.0377	.0377	.0377
16	.0566	.0566	.0566	.0566	.0566	.0377	.0377
17	.0566	.0566	.0566	.0566	.0566	.0566	.0566
18	.0566	.0566	.0943	.0943	.0943	.0566	.0566
19	.0566	.0566	.0943	.0819	.0943	.0943	.0943
20	.0566	.0566	.0943	.0943	.0943	.0943	.0943
21	.0566	.0566	.0943	.0943	.0943	.0943	.0943
22	.0566	.0566	.0566	.0943	.0566	.0754	.0566
23	.0566	.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	
Max	.0754	.0566	.0943	.0943	.0943	.0943	.0943
Min	.0566	.0566	.0566	.0566	.0377	.0377	.0377
Avg	.0590	.0566	.0629	.0655	.0621	.0589	.0589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 206 / 11 KV SIDDHANATH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0754	.0754	.0754	.0754	.0754
4	.0655	.0754	.0754	.0754	.0754	.0754	.0754
5	.0754	.0754	.0754	.0754	.0754	.0754	.0754
6	.0943	.0754	.0754	.0943	.0943	.0754	.0754
7	.0943	.0754	.0754	.0943	.0943	.0754	.0754
8	.0943	.0754	.0754	.0754	.0943	.0754	.0943
9	.0754	.0943	.0754	.0754	.0754	.0754	.0943
10	.0754	.0943	.0754	.0754	.0754	.0754	.0754
11	.0754	.0754	.0754	.0754	.0754	.0754	.0754
12	.0754	.0754	.0754	.0754	.0754	.0754	.0754
13	.0754	.0754	.0655	.0754	.0754	.0754	.0754
14	.0754	.0754	.0754	.0754	.0754	.0754	
15	.0754	.0754	.0754	.0754	.0754	.0754	.0566
16	.0754	.0754	.0754	.0754	.0754	.0754	.0754
17	.0754	.0754	.0754	.0754	.0754	.0754	.0754
18	.0754	.0754	.132	.132	.0943	.0754	.0943
19	.1132	.0754	.132	.132	.1509	.132	.1132
20	.1132	.1132	.132	.132	.1509	.1132	.1132
21	.1132	.1132	.132	.132	.0943	.132	.1132
22	.0754	.0754	.0754	.132	.0943	.0943	.0943
23	.0754	.0754	.0754	.0754	.0754	.0754	.0754
24	.2458	.0754	.0754	.0754	.0754	.0754	.0754
Max	.2458	.1132	.132	.132	.1509	.132	.1132
Min	.0655	.0754	.0655	.0754	.0754	.0754	.0566
Avg	.0892	.0801	.0844	.0888	.0864	.0825	.0828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 207 / 11 KV DARIBADCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2458	1.1469	.2458	.2458	.2458	.9831	1.0059
2	.2458	1.3108	.2458	.2458	.2458	.9831	1.0059
3	.2458	1.3108	.2458	.2458	.2458	.9831	1.0059
4	.2458	1.3108	.2458	.2458	.2458	.9831	1.5089
5	.2372	1.4746	.2458	.2458	.2458	1.1469	1.6766
6	.4915	1.6385	.2458	.3277	.3772	1.6385	2.5149
7	.6554	2.0481	.2458	.3277	.3277	2.6216	2.5987
8	.7373	2.4577	.2458	.3277	.3163	2.7854	2.6825
9	.3277	.3277	.2458	.3277	.3277	.3277	.3353
10	.3277	1.9662	1.4746	.4096	.3277	.3277	.503
11	.3277	2.5396	2.4577		.3277	.3277	.503
12	.3277	2.6216	2.8673		.3277	.3277	.503
13	.3277	2.7854	2.6216	2.9492	.3277	.503	.503
14	.3277	2.6216	2.6216	2.9492	.3277	.503	.503
15	.3277	2.6216	2.7035	2.9492	.3277	.503	.503
16	.3277	2.9492	2.6216	2.8673	.3277	.503	.4191
17	.3277	2.2119	2.6216	2.8673	.3277	.503	.4191
18	.3277	.3277	.3277	.132	.4096	.503	.4191
19	.3277	.3277	.3277	.132	.4096	.503	.4191
20	.3277	.3277	.3277	.132	.4096	.4191	.4191
21	.3277	.3277	.3277	.3277	.3277	.4191	.3353
22	.3277	.3277	.2458	.3277	.3277	.3353	.3353
23	.8192	.2458	.2458	.2458	.6554	.6706	.6706
24		1.1469	.2458	.2458	.2458	.8192	.8383
Max	.8192	2.9492	2.8673	2.9492	.6554	2.7854	2.6825
Min	.2372	.2458	.2458	.132	.2458	.3277	.3353
Avg	.3701	1.5156	1.0104	.8670	.3327	.8175	.9012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 208 / 11 KV MUCHANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1696	1.3565	.9831	.8192	.1696	.1696
2	.1638	.1696	1.3565	.9831	.8192	.1696	.1696
3	.1638	.1696	1.3565	.9831	.8192	.1696	.1696
4	.1638	.1696	1.5261	.9831	.8192	.1696	.1696
5	.1638	.1696	1.5261	1.1469	.9831	.1696	.2543
6	.2458	.1696	1.6956	1.6385	1.2289	.1696	.2543
7	.2458	.1696	2.0348	1.8023	2.0481	.1696	.2543
8	.2458	.1696	2.3739	2.2939	2.0481		.2543
9	.1638	.1696	.1696	.1638	.1638		.2543
10	2.0481	.1696	.1696	.1638	1.6385		1.3565
11	2.0481	.1696	.1696	.1638	1.8842		1.8652
12	1.6385	.1696	.1696	.1638	1.7204	1.8652	1.8652
13	1.95	.1696	.1638	.1638	1.8652	2.0348	1.8652
14	1.95	.1696	.1638	.1638	1.5261	2.3061	2.0348
15	2.0348	.1696	.1638	.1638	1.5261	2.2891	2.0348
16	2.0348	.1696	.1638	.1638	1.6956	2.2891	
17	1.95	.1696	.1638	.1638	1.8652	2.2043	.6783
18	.1696	.1696	.1638	.1638	.1696	.6783	.1696
19	.1696	.1696	.1638	.1638	.2543	.1696	.1696
20	.1696	.1696	.1638		.2543	.2543	.1696
21	.1696	.1696	.1638	.1638	.1696	.2543	.1696
22	.1696	.1696	.1638	.1638	.1696	.2458	.1696
23	.1696	.8478	.8192	.6554	.1696	.1696	.1696
24	.1638	.1696	1.0174	.9831	.8192	.1696	.1696
Max	2.0481	.8478	2.3739	2.2939	2.0481	2.3061	2.0348
Min	.1638	.1696	.1638	.1638	.1638	.1696	.1696
Avg	.7732	.1979	.7241	.6340	1.0615	.8059	.6451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 202 / 11 KV KONTEBOBLAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2543	.2374		1.1934	1.0277	.2652	.2543
2	.2374	.2543		1.2071	1.0395	.2652	.2543
3	.2374	.2543		1.2929	1.1401	.2683	.2515
4	.2347	.2683		1.4918	1.1934	.285	.2652
5	.2622	.3018		1.8351	1.4255	.3018	.3315
6	.3856	.3018		1.9662	1.704	.3481	.4475
7	.4359	.3647		2.8837	2.2672	.4144	.4694
8	.4527	.431		3.0148	2.556	.4641	.4359
9	.4527	.3647		.4239	.3052	.3353	.3688
10	2.0719	.3688		.3018	2.0553	1.989	1.9281
11	2.9835	.3018		.4024	2.915	1.7901	2.3537
12	1.989	.3185	.3353	.4024	3.0312	2.9007	2.4034
13	2.9835	.3315	.3315	.407	3.0148	2.8346	2.652
14	2.2542	.0829	.3315	.4024	3.0445	1.3927	2.3758
15	2.6216	.2321	.3353	.373	2.915	2.7854	2.556
16	2.7854	.2984	.373	.4024	2.7854	2.8346	2.4905
17	2.7526	.2347	.3391	.373	2.1628	2.9504	1.0774
18	.2402	.3521	.4854	.4854	.2402	.2984	.2957
19	.3881	.4191	.4755	.4805	.4435	.3856	.3511
20	.4251	.407	.4755	.4435	.4251	.3688	.3361
21	.3696	.373	.4024	.3658	.3361	.2683	.3142
22	.2957	.3222	.2614	.3361	.3174	.2713	.2987
23	.2374	.8648	.8048	.7042	.2652	.2543	.2515
24	.2543	.2374		1.1271	.9282	.2818	.2543
Max	2.9835	.8648	.8048	3.0148	3.0445	2.9504	2.652
Min	.2347	.0829	.2614	.3018	.2402	.2543	.2515
Avg	1.0669	.3301	.4126	.9298	1.5641	1.0231	.9590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 203 / 11 KV PANDOZARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4754			.4527	.3391
2	1.6263	.6962		.4409	.3222
3	1.8442	1.4255		.4748	.3353
4	2.1293	1.7901		.4862	.3561
5	2.4531	.8785		.5138	.4527
6	3.0167	2.2119		.5801	.5967
7	3.2322	2.982		.788	.7956
8	3.1161	2.7199		.9054	.8551
9	.4973	.3605		.7291	.8573
10	.5898	2.6686	2.1628	2.652	.8139
11	.6882	3.0996	2.9165	3.2278	.788
12	.3113	2.8675	2.8675	3.083	.7545
13	.6299	3.2819	2.9492	3.2114	.6706
14	.4144	2.13	2.7854		.6203
15	.5138	3.195	3.1131	3.1903	.5801
16	.6203	3.1741	1.1904	3.2278	.5304
17	.6371	1.6518	2.4577	2.9656	
18	.7499	.7373	.5359	.7207	
19	.8871	.7045	.7865	.7133	
20	.7762	.6226	.7023	.695	
21	.6653	.5304	.6219	.5544	
22	.5729	.4475	.5729	.4805	
23	.9556	.4641	.4917	.373	
24	1.0227	1.1568		.4527	.3391
Max	3.2322	3.2819	3.1131	3.2278	.8573
Min	.3113	.3605	.4917	.373	.3222
Avg	1.2260	1.7303	1.7253	1.3443	.5886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 204 / 11 KV TIKONDI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.056		.0554	.056	.056	.0754
2	.056	.056		.056	.0554	.056	.0747
3	.056	.056		.056	.056	.0566	.0747
4	.0747	.0924		.0747	.0747	.0754	.0934
5	.1132	.1109		.1463	.1294	.0934	.1307
6		.1478		.2218	.1829	.1494	.1886
7	.1509	.1848		.2012	.2012	.1867	.2075
8	.1307	.1867		.128	.1463	.1494	.1698
9	.112	.168		.1109	.0747	.1109	.1307
10	.1109	.112	.0747	.0732	.0924	.0924	
11	.0924	.0739	.112	.0739	.0739	.0739	.0739
12	.0739	.0924	.0924	.0732	.0739	.0549	.0554
13	.0739	.0924	.0934	.0739	.0739	.0549	.0739
14	.056	.0732	.0554	.056	.056	.0549	.0747
15	.056	.0732	.0554	.0739	.0373	.0549	.0747
16	.0747	.0724	.0739	.0914	.056	.0554	.0747
17	.0739	.0905	.0924	.0924	.056	.0554	.0554
18	.1109	.1267	.112	.112	.0739	.0995	.0924
19	.1663	.2012	.1663	.1663	.1663	.1663	.1307
20	.2033	.1848	.1663	.1663	.1867	.168	.1494
21	.1494	.1478	.1294	.1307	.1307	.1307	.1494
22	.112	.0934	.0934	.0934	.0934	.0934	.0924
23	.0747	.0747	.0739	.0924	.0747	.0754	.0554
24	.0747	.056		.0739	.0739	.0747	.0754
Max	.2033	.2012	.1663	.2218	.2012	.1867	.2075
Min	.056	.056	.0554	.0554	.0373	.0549	.0554
Avg	.0987	.1093	.0994	.1039	.0957	.0933	.1032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 205 / 11 KV PANDOZARI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381		.0381	.0191
2	.0381	.0381		.0191	.0191
3	.0381	.0381		.0191	.0381
4	.0381	.0381		.0381	.0381
5	.0572	.0572		.0381	.0572
6	.0953	.0762		.0762	.0762
7	.0953	.0953		.0953	.0953
8	.0953	.0762		.0953	.0953
9	.0762	.0572		.0572	.0572
10	.0381	.0381	.0381	.0381	.0572
11	.0381	.0381	.0191	.0381	.0191
12	.0381	.0381	.0381	.0381	.0191
13	.0191	.0381	.0191	.0191	.0191
14	.0381	.0191	.0191	.0191	.0191
15	.0191	.0191		.0381	.0191
16	.0191	.0191		.0191	.0191
17	.0191	.0381		.0381	
18	.0381	.0572	.0381	.0381	
19	.0762	.0572	.0762	.0762	
20	.0953	.0953	.0762	.0762	
21	.0762	.0572	.0572	.0572	
22	.0572	.0381	.0381	.0381	
23	.0381	.0381	.0381	.0381	
24	.0381	.0381		.0381	.0381
Max	.0953	.0953	.0762	.0953	.0953
Min	.0191	.0191	.0191	.0191	.0191
Avg	.0508	.0476	.0416	.0453	.0415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 206 / 11 KV KAGNARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5939	1.3735		.4578	.3185	1.861	1.9784
2	1.7126	1.4752		.4527	.3052	2.079	2.1534
3	1.8652	1.5424		.4748	.3052	2.2891	2.2213
4	1.9951	1.6095		.4748	.3688	2.3739	2.5095
5	2.2466	1.6933		.4807	.4239	2.2466	2.713
6	2.6825	2.0287		.4973	.503	2.536	2.9843
7	2.8837	2.4034		.6962	.6706	2.2542	3.1017
8	3.1017	2.0622		.779	.8383	.0671	2.9843
9	.4359	.3222		.6299	.7969	.0339	.4239
10	.503	2.4981	1.9448	2.5724	.8048	.0509	.5935
11	.6203	2.5819	2.9005	3.0639	.8551	.4917	.763
12	.5087	2.9172	.8192	2.5724	.9389	.8886	.8886
13	.7461	2.9005		2.5692	.9614	.9892	
14	.6036	2.2542		3.1295	.9448	1.094	
15	.7042	2.8675		3.195	.8383	1.0442	.7712
16	.6874	2.9338		3.0148	.8718	1.0277	.8718
17	.6274	2.7349		2.4863	.57	.8718	.3391
18	.7682	.5365	.6099	.2033	.6783	.6706	.6653
19	.6767	.503	.7865	.7133	.7023	.6443	.6653
20	.5359	.5087	.6653	.567	.6219	.5935	.5853
21	.462	.4917	.5487	.5359	.5487	.4748	.5175
22	.4066	.4239	.499	.4435	.4435	.4409	.4481
23	.8309	.4239	.4801	.4024	1.0898	1.3226	.9835
24	1.153	1.0174		.4748	.3521	1.4586	1.4419
Max	3.1017	2.9338	2.9005	3.195	1.0898	2.536	3.1017
Min	.4066	.3222	.4801	.2033	.3052	.0339	.3391
Avg	1.1813	1.6710	1.0282	1.2870	.6563	1.1585	1.3911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 207 / 11 KV KAREWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829	.0829		.7459	.503	.0671	.0655
2	.0829	.0829		.7459	.5426	.0671	.0655
3	.0819	.0829		.9339	.5935	.0663	.0819
4	.0819	.0983		1.0277	.6962	.0829	.0983
5	.1147	.1147		1.0486	.8048	.0995	.1326
6	.1492	.1475		1.1336	.9339	.1326	.1823
7	.1658	.1492		1.278	1.1633	.1802	.1658
8	.1658	.1492		1.6385	1.3599	.1475	.1658
9	.1475	.1492		.1526	.1865	.0995	.1475
10	.7701	.1341	.1781	.1341		.9614	1.1469
11	1.4255	.116	.1296	.1509		1.5893	1.4746
12	1.0486	.0995	.0995	.1509	.9012	1.5238	1.4582
13	1.4091	.0983	.1311	.1357	1.4419	1.5074	1.278
14	1.0159	.0983	.1677	.1677	1.4582	1.4575	1.1797
15	1.3763		.116	.1509	1.3603	1.4575	1.2793
16	1.4899	.0972	.1677	.1823	1.3603	1.3279	1.2146
17	1.3603	.1134	.1509	.1844	1.065	1.5546	.6882
18	.1663	.1134	.1494	.2054	.1294	.0983	.0924
19	.2033	.1296	.1663	.2402	.1478	.1311	.1478
20	.2033	.1475	.2012	.1848	.1663	.1492	.1294
21	.1867	.1311	.1646	.168	.1307	.116	.1109
22	.112	.1147	.1294	.1307	.0934	.0995	.0747
23	.0838	.3315	.4694	.3561	.0671	.0829	.0663
24	.0829	.0829		.7209	.503	.0671	.0819
Max	1.4899	.3315	.4694	1.6385	1.4582	1.5893	1.4746
Min	.0819	.0829	.0995	.1307	.0671	.0663	.0655
Avg	.5003	.1245	.1729	.4987	.7095	.5444	.4803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 201 / 11 KV SANMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.1905	.0953	.0953	.0953	.1905
6	.0953	.1905	.1905	.0953	.0953	.1905
7	.1905	.1905	.1905	.0953	.1905	.1905
8	.1905	.0953	.1905	.1905	.1905	.1905
9	.0953	.1905	.0953	.1905	.1905	.1905
10	.0953	.0953	.0953	.1905	.0953	.0953
11	.0953	.0953	.0953	.0953	.0953	.0953
12	.0953	.0953	.0953	.0953	.0953	.0953
13	.0953	.0953	.0953	.0953	.0953	.0953
14	.0953	.0953	.0953	.0953	.0953	.0953
15	.0953	.0953	.0953	.0953	.0953	.0953
16	.0953	.0953	.0953	.0953	.0953	.0953
17	.0953	.0953	.0953	.0953	.0953	.0953
18	.0953	.1905	.0953	.0953	.0953	
19	.0953	.0953	.1905	.1905	.0953	
20	.0953	.0953	.1905	.1905	.0953	
21	.0953	.0953	.0953	.1905	.0953	
22	.0953	.0953	.0953	.1905	.0953	
23	.0953	.0953	.0953	.0953	.0953	
24	.0953	.0953	.0953	.1715	.0953	.0953
Max	.1905	.1905	.1905	.1905	.1905	.1905
Min	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1032	.1151	.1151	.1262	.1072	.1217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 202 / 11 KV GHOLESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1097	.1311	.2439	.0983	.0895	.1143
2	.0934	.1075	.1423	.2241	.1492	.0934	.1075
3	.1029	.104	.1619	.2949	.2294	.0857	.0905
4	.1402	.1494	.1989	.25	.2241	.1097	.0934
5	.1417	.124	.2561	.4973	.3201	.1433	.1097
6	.1698	.1715	.4801	.5506	.3768	.1886	.1524
7	.1509	.1132	.639	.5898	.426	.1698	.1143
8	.1509	.1132	.6802	.6642	.5344	.1698	.0953
9	.132	.0934	.0943	.0943	.0905	.112	.0953
10	.2812	.0934	.0953	.0943	.3749	.3086	.2343
11	.6167	.0943	.0943	.0943	.503	.3906	.3681
12	.6722	.0943	.0943	.0943	.4988	.427	.5121
13	.68	.0943	.0943	.0943	.5218	.4902	.4374
14	.68	.0943	.0943	.0943	.5155	.5218	.4012
15	.6722	.0943	.0943	.0943	.4999	.5376	.4115
16	.6154	.0943	.0943	.0943	.4938	.5218	.3353
17	.6882	.0943	.0943	.0924	.4374	.4862	.3932
18	.0914	.0934	.0943	.0943	.0924	.0943	.1006
19	.0895	.0876	.0876	.0943	.1052	.1075	.1433
20	.0867	.0895	.0914	.0943	.1075	.1097	.0876
21	.0943	.0943	.0943	.0943	.0943	.0943	.0953
22	.0886	.1402	.096	.0943	.1063	.0895	.0895
23	.0953	.0972	.2656	.0857	.0895	.0914	.0914
24	.0934	.0934	.108	.2458	.0838	.0943	.0953
Max	.6882	.1715	.6802	.6642	.5344	.5376	.5121
Min	.0867	.0876	.0876	.0857	.0838	.0857	.0876
Avg	.2806	.1056	.1824	.2069	.2905	.2303	.1987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 203 / 11 KV KONIKUNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.1075	.4801	.3932	.5197	.1086	.0895
2	.104	.1097	.6371	.4359	.5138	.1372	.0914
3	.112	.1029	.7122	.4725	.5636	.0895	.0905
4	.1433	.1387	.7186	.6009	.6036	.0867	.1494
5	.1372	.1402	.7907	1.1888	.7209	.1612	.12
6	.1334	.1524	.9054	1.1385	.852	.1509	.1334
7	.1132	.1132	1.278	1.2125	.9175	.1509	.1143
8	.1132	.1132	1.4918	1.0722	1.1336	.1132	.1132
9	.1109	.0914	.0924	.1227	.208	.0934	.0943
10	.6958	.0934	.0943	.1132	1.1142	.4694	.759
11	1.4083	.0934	.0934	.0943	1.2239	1.4586	.9962
12	1.3763	.0924	.0934	.0886	.3286	1.4918	1.2955
13	1.4083	.1097	.0934	.0876	1.4419	1.4419	1.3283
14	1.4074	.0924	.0924	.0886	1.3765	1.4089	1.3279
15	1.4243	.0914	.0914	.0876	1.3283	1.4582	1.2955
16	1.4255	.0905	.0886	.0876	1.2163	1.4419	1.2631
17	1.442	.0886	.0924	.0886	1.2955	1.3413	.3201
18	.0857	.0905	.0857	.0867	.0876	.0914	.1311
19	.0895	.0895	.1433	.1029	.1402	.1075	.1677
20	.0876	.1029	.1097	.124	.1867	.1402	.1463
21	.0934	.112	.0943	.0934	.112	.112	.1132
22	.0876	.25	.0895	.0943	.0914	.0895	.1433
23	.0943	.3563	.3109	.3768	.0895	.0914	.1646
24	.0943	.0914	.3795	.3429	.4694	.0943	.0943
Max	1.442	.3563	1.4918	1.2125	1.4419	1.4918	1.3283
Min	.0857	.0886	.0857	.0867	.0876	.0867	.0895
Avg	.5115	.1214	.3774	.3581	.6889	.5137	.4393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 204 / 11 KV SANAMADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0983	.0648	.0553	.0762	.0983	.0819
2	.0937	.1006	.0667	.0562	.0743	.1017	.08
3	.1311	.0937	.0705	.0648	.0743	.0857	.1006
4	.128	.1219	.0686	.0495	.0724	.1107	.1189
5	.1638	.1265	.0791	.0591	.0734	.1578	.08
6	.1219	.1054	.0762	.0667	.0724	.1107	.1204
7	.1677	.1372	.0753	.0743	.0724	.1875	.1372
8	.1852	.1875	.0762	.0743	.0914	.2623	.2591
9	.1372	.0943	.0762	.0762	.0943	.0943	.0943
10	.0943	.1656	.1265	.125	.0943	.0934	.0943
11	.0943	.2214	.1829	.2056	.0943	.0943	.0943
12	.0943	.25	.2778	.25	.0943	.0924	.0943
13	.0943	.2134	.2591	.2778	.0943	.0943	.0943
14	.0943	.1806	.2439	.2778	.0943	.0943	.0943
15	.0943	.1932	.2896	.2778	.0943	.0943	.0943
16	.0943	.1783	.3201	.0943	.0943	.0943	.0943
17	.0943	.25	.2968	.0943	.0943	.0943	.0895
18	.0943	.0943	.0914	.0914	.0943	.0943	.0914
19	.0895	.0895	.1372		.0914	.0886	.0934
20	.0934	.0857	.1402		.0895	.0876	.0876
21	.0657	.0591	.0514	.0943	.0638	.0905	.0934
22	.0743	.0705	.0572	.0934	.0838	.0914	.08
23	.0857	.0667	.0619	.0924	.0819	.1612	.0983
24	.06	.096	.06	.061	.0914	.096	.0772
Max	.1852	.25	.3201	.2778	.0943	.2623	.2591
Min	.06	.0591	.0514	.0495	.0638	.0857	.0772
Avg	.1051	.1367	.1354	.1187	.0855	.1113	.1018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 205 / 11 KV GHOLESHWAR GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0934	.0895	.0895	.0953	.0914
2	.0914	.104	.0876	.0914	.0953	.0857
3	.0857	.0876	.0867	.0934	.0943	.0876
4	.0867	.1867	.0876	.0943	.0943	.0905
5	.1791	.1753	.1867	.0895	.0943	.1848
6	.2829	.1886	.2858	.1867	.1886	.2829
7	.1772	.1867	.2829	.2829	.2829	
8	.1886	.1848	.1715	.1886	.2801	.1715
9	.0838	.1829	.0857	.1734	.1753	.1772
10	.08	.1696	.0905	.0876	.0905	.1753
11	.0857	.0857	.0886	.0905	.0895	.0886
12	.0876	.0867	.0905	.0886	.0886	.0934
13	.0857	.0876	.0886	.0924	.0876	.0943
14	.0895	.0886	.0876	.0886	.0895	.0924
15	.0876	.0867	.0857	.0886	.0876	.0934
16	.0857	.0857	.0876	.0876	.0886	.0914
17	.0867	.0781	.0867	.0895	.0867	.0943
18	.1581	.1619	.1658	.0848	.08	
19	.16	.1638	.16	.2572	.0983	
20	.1677	.1715	.1753	.2572	.1619	
21	.1829	.1867	.1829	.1867	.1867	
22	.0867	.0895	.0895	.0943	.0895	
23	.0953	.0943	.0914	.0953	.0886	
24	.0943	.0895	.0943	.0876	.0953	.0943
Max	.2829	.1886	.2858	.2829	.2829	.2829
Min	.08	.0781	.0857	.0848	.08	.0857
Avg	.1208	.1298	.1262	.1278	.1212	.1229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 206 / 11 KV NIGADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1646	.2865	.2622	.2622	.1595	.1433
2	.2241	.2149	.3292	.4024	.3481	.1886	.1867
3	.2561	.2804	.5228	.3201	.3315	.2507	.2058
4	.2743	.3361	.4458	.3749	.373	.2987	.2865
5	.3294	.3582	.5175	.8962	.5533	.3258	.3292
6	.4338	.3961	.7975	.9831	.7122	.4338	.4338
7	.3961	.3292	1.2071	1.1568	.9496	.3395	.3881
8	.3395	.2829	1.3094	1.4918	.8619	.3206	.3018
9	.3547	.1494	.2481	.2743	.2587	.2054	.2075
10	.5281	.1132	.132	.1629	.6802	.5639	.3963
11	.8421	.112	.132	.1494	.8381	.8223	.6882
12	.9231	.112	.132	.1109	.9842	1.0688	.8802
13	1.0202	.1097	.1132	.1063	1.0279	1.012	.8179
14	1.1498		.112	.1063	1.0526	.9922	.8436
15	1.278		.0943	.1063	.9804	1.065	.7773
16	1.3435	.0943	.0943	.1254	.9061	1.1469	.5624
17	.8785	.112	.1307	.1433	.7907	1.0608	.5731
18	.1494	.112	.1646	.1791	.1829	.1646	.3658
19	.2241	.1791	.197	.1949	.2507	.1829	.2743
20	.2926	.2454	.2401	.1928	.2926	.1829	.2835
21	.2263	.2075	.2263	.2241	.2452	.2452	.2263
22	.1791	.2774	.2507	.2012	.1612	.1494	.2507
23	.1132	.218	.2926	.1966	.1829	.1227	.1829
24	.132	.1867	.2294	.3086	.2347	.132	.1132
Max	1.3435	.3961	1.3094	1.4918	1.0526	1.1469	.8802
Min	.1132	.0943	.0943	.1063	.1612	.1227	.1132
Avg	.5028	.2087	.3419	.3612	.5609	.4764	.4049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 207 / 11 KV YELAVI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.5121	.4161
2		.5407	.6249
3		.6859	.6882
4		.8596	.8002
5		.9175	1.073
6		.9646	1.166
7		1.8299	1.5238
8		1.8842	1.9227
9		.1991	.2012
10		.181	.1991
11		.1829	.1646
12		.1646	.1478
13		.1595	.1494
14		.1753	.1478
15		.1595	.1646
16		.1646	.1829
17		.197	.1886
18		.2103	.2507
19		.2987	.3086
20		.3045	.2804
21		.2587	.2587
22		.3582	.2865
23		.4108	.3292
24	.2721	.3041	.3913
Max	.2721	1.8842	1.9227
Min	.2721	.1595	.1478
Avg	.2721	.4968	.4944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 201 / 11 KV KONTEBOBLAD MIX
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.7459	
2	.0953	.1524	.7459	
3	.0762	.1334	.8288	
4	.0953	.2667	.9012	
5	.1334	.2477	.9116	
6	.1715	.3239	.9945	
7	.2286	.2858	1.065	
8	.1905	.3048	1.2431	
9	.1715	.2667	.1524	
10	1.1498	.2096	1.2431	
11	1.2643	.2477	1.1603	.9717
12	1.3603	.1905	1.1271	1.7204
13	1.4899	.1905	1.326	1.9662
14	1.6741	.1905	1.5746	1.9433
15	1.5524	.1905		1.4575
16	1.5546	.1905		1.6385
17	1.757	.2286		1.5746
18	.1715	.2286		.1524
19	.2667	.2286		.1524
20	.2477	.1905		.1905
21	.2286	.1905		.1905
22	.2858	.1905		.1905
23	.2667	.7373		.2286
24	.1334	.1334	.8097	
Max	1.757	.7373	1.5746	1.9662
Min	.0762	.1334	.1524	.1524
Avg	.6116	.2400	.9886	.9521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 202 / 11 KV JALYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)
1	.1524	.2286
2	.1334	.2286
3	.1143	.2477
4	.0953	.2477
5	.1524	.2667
6	.2286	.2858
7	.362	.3239
8	.3239	.2667
9	.2858	.2286
10	1.0526	1.2803
11	1.2763	1.6194
12	1.3443	1.6385
13	.7611	1.7328
14	1.6842	1.5844
15	1.7238	1.6575
16	1.6518	1.7166
17	1.6194	1.668
18	.1905	
19	.2667	
20	.2858	
21	.2477	
22	.1905	
23	.2667	
24	.1715	.2286
Max	1.7238	1.7328
Min	.0953	.2286
Avg	.6075	.8584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 203 / 11 KV GIRGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.5735	.4858	
2	.663	.5921	
3	.7459	.5801	
4	.8288	.6706	
5	.9116	.8482	
6	.9614	1.1105	
7	1.0442	1.166	
8	1.442	1.3123	
9	.1334	.1334	
10	.1143	1.004	
11	.0762	1.0883	.0953
12	.0953	1.2266	.1143
13	.0762	1.3108	.0953
14	.0572	1.4089	.0953
15	.0953	1.2003	.0762
16	.0762	1.2431	.0953
17	.0572	.9717	.1143
18	.0762	.1334	.1334
19	.0953	.1524	.1334
20	.1334	.1524	.0953
21	.1143	.1334	.0953
22	.0953	.1334	.1143
23	.2818	.1143	.6783
24	.4915	.4321	
Max	1.442	1.4089	.6783
Min	.0572	.1143	.0762
Avg	.3850	.7335	.1489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 204 / 11 KV MORBAGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)
1	.7865	.9012
2	.852	.9831
3	.9448	1.1603
4	1.2003	1.1603
5	1.1437	1.3413
6	1.2431	1.5089
7	1.442	1.6766
8	1.6907	1.6804
9	.1334	.1143
10	.0953	.0953
11	.1334	.1143
12	.1143	.0953
13	.1143	.1143
14	.0953	.1524
15	.0953	.1524
16	.0762	.1524
17	.0762	.1524
18	.0953	
19	.1334	
20	.0953	
21	.0953	
22	.0953	
23	.3563	
24	.6882	.8192
Max	1.6907	1.6804
Min	.0762	.0953
Avg	.4915	.6875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244138 / 33/11KV UTAGI

Feeder No / Name : 201 / 11 KV HALLI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	.9014
Max	.9014
Min	.9014
Avg	.9014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244138 / 33/11KV UTAGI

Feeder No / Name : 202 / 11 KV LAMAN TANDA AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	.2753
Max	.2753
Min	.2753
Avg	.2753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 201 / 11 KV KANKESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.0492	.9339	1.004	.8802	.048	.048
2	.064	.0492	.9831	1.004	.8802	.032	.048
3	.064	.0492	.9831	1.004	.8802	.032	.048
4	.064	.0492	1.0159	1.0202	.8802	.032	.048
5	.0716	.0492	1.0159	1.0202	.8802	.032	.064
6	.0716	.0655	1.1469	1.1336	.8802	.048	.064
7	.0716	.0655	1.3763	1.1984	.9602	.064	.064
8	.0716	.0655	1.4582	1.2955	1.1043	.064	.08
9	.0532	.0655	1.4255	1.247	1.2483	.048	.08
10	1.4737	.0328	.0492	.048	1.2483	1.2003	1.2643
11	1.9393	.0492	.0324	.048	1.6164	1.7124	1.5524
12		.0492	.0324	.048	1.7444	1.7924	1.2003
13		.0492	.0648	.048	1.7604	1.8244	1.4403
14	1.8896	.0328	.0486	.048	1.6964	1.8244	1.6356
15	1.9498	.0492	.0486	.048	1.6804	1.8404	1.6484
16	1.9989	.0492	.0492	.048	1.6644	1.8244	1.6324
17	1.8351	.0492	.0324	.032	1.5364	1.7604	1.4883
18	.0492	.0492	.0486	.032		.064	.048
19	.0655	.0655	.0648	.08	.064	.064	.064
20	.0655	.0655	.0648	.064	.064	.08	.064
21	.0655	.0655	.0648	.064	.064	.064	.064
22	.0655	.0655	.0648	.048	.048	.064	.064
23	.0492	.0492	.0486	.048	.048	.064	.048
24	.064	.0492	.9339	.9069	.7842	.048	.048
Max	1.9989	.0655	1.4582	1.2955	1.7604	1.8404	1.6484
Min	.0492	.0328	.0324	.032	.048	.032	.048
Avg	.5503	.0533	.4994	.4807	.9832	.6095	.5336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 202 / 11 KV MHAISHAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3506	.3681	.2328	.3582	.3801	.362
2	.3086	.333	.3506	.2328	.3582	.362	.3258
3	.3086	.3155	.3506	.2328	.3582	.3258	.2896
4	.3086	.333	.3506	.2328	.3582	.3439	.2896
5	.373	.3506	.3681	.2507	.3761	.362	.2896
6	.4748	.4031	.4031	.3761	.4525	.5068	.4163
7	.5721	.4908	.5258	.5014	.543	.5611	.5249
8	.5258	.5083	.5083	.5194	.4887	.5611	.4887
9	.4733	.4382	.3856	.4656	.4163	.4706	.5249
10	.4031	.3856	.3506	.5552	.362	.362	.4163
11	.3506	.4031	.3582	.4477	.4525	.3982	.5249
12	.4207	.3681	.394	.4477	.4344	.4163	.5249
13	.4207	.4908	.3403	.591	.4887	.3982	.5068
14	.5609	.3681	.3403	.4656	.4344	.4344	.4525
15	.5083	.4733	.3224	.4835	.4525	.3801	.543
16	.5959	.5258	.0358	.4477	.4887	.362	.543
17	.631	.5434	.3403	.4835	.4706	.5068	.6335
18	.6661	.631	.394	.5552	.6335	.6335	.543
19	.8238	.7888	.7164	.8059	.7964	.905	.8688
20	.8413	.8589	.6984	.8596	.7964	.8326	.8326
21	.7362	.724	.6268	.7701	.7964	.7602	.7602
22	.5784	.6697	.5731	.5731	.6516	.5792	.5973
23	.4382	.4706	.3403	.4298	.5068	.4344	.4525
24	.3258	.3681	.3681	.2507	.3761	.3982	.362
Max	.8413	.8589	.7164	.8596	.7964	.905	.8688
Min	.3086	.3155	.0358	.2328	.3582	.3258	.2896
Avg	.4981	.4830	.4087	.4671	.4938	.4864	.5030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 203 / 11 KV MAHAVEER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7209	.7701			.8192	.7459
2	.7209	.7701			.8192	.7459
3	.7209	.7701			.8192	.7459
4	.7209	.7701			.8192	.7459
5	.7209	.7701			.8192	.7459
6	.7537	.7865			.8356	.7625
7	.7701	.8192			.9503	.8453
8	.7701	.8848			.9667	.8288
9	.7537	.8848			.9503	.8453
10		.9503	1.0159	.9614		
11		.9667	1.1105	1.094		
12		1.2616	1.0277	1.1603		
13		1.0486	1.094	1.1768		
14		1.065	1.1271	1.1437		
15		1.065	1.21	1.1105		
16		1.0978	1.1934	1.0442		
17		1.1142	1.1603	1.0277		
24	.7209	.639			.8192	.7625
Max	.7701	1.2616	1.21	1.1768	.9667	.8453
Min	.7209	.639	1.0159	.9614	.8192	.7459
Avg	.7373	.913	1.1174	1.0898	.8618	.7774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 204 / 11 KV NARWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.048	.4801	.4641	.3479	.048	.0469
2	.0633	.048	.5121	.4801	.3479	.048	.0469
3	.0633	.048	.5121	.4801	.3479	.048	.0469
4	.0633	.048	.5121	.5121	.3479	.048	.0469
5	.0732	.048	.5281	.5441	.3479	.048	.0625
6	.0914	.064	.6241	.6241	.427	.048	.0625
7	.1097	.08	.9442	.8322	.8697	.08	.0781
8	.0924	.08	.9922	1.0242	.6874	.064	.0937
9	.0924	.096	1.0402	1.0722	.7907	.096	.0781
10	.7602	.08	.048		.9061	.6081	.5937
11	1.2616	.064	.032	.064	1.1717	1.1248	1.0623
12	1.2944	.064	.048	.064	1.1561	1.2811	1.078
13	1.278	.064	.08	.08	1.1092	1.2811	1.0155
14	1.2452	.064	.08	.08	1.078	1.1561	.9998
15	1.2963	.064	.064	.064	1.1092	1.1092	1.012
16	1.2643	.08	.08	.08	1.078	1.0623	.9804
17	1.2163	.064	.08	.08	1.0155	1.0467	.9488
18	.048	.08	.096	.08	.8749	.0625	.0633
19	.096	.096	.096	.1107	.0937	.1094	.0791
20	.112	.096	.112	.1107	.0781	.0937	.0949
21	.112	.0983	.096	.1107	.0781	.0937	.0949
22	.096	.0819	.08	.0791	.0781	.0937	.0791
23	.064	.0655	.064	.0633	.0625	.0625	.0633
24	.0633	.064	.4801	.4481	.3321	.0469	.0625
Max	1.2963	.0983	1.0402	1.0722	1.1717	1.2811	1.078
Min	.048	.048	.032	.0633	.0625	.0469	.0469
Avg	.4550	.0702	.3201	.3282	.6140	.4067	.3663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 205 / 11 KV MHAISHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1248	.9061	.0655	.064	.064	1.0402	1.0082
2	1.1248	.8905	.0655	.064	.064	1.0402	1.0082
3	1.1248	.8905	.0655	.064	.064	1.0242	1.0082
4	1.1248	.8905	.0655	.064	.064	1.0242	1.0082
5	1.1248	.9061	.0655	.08	.064	1.1203	1.0722
6	1.1248	.9995	.0655	.096	.096	1.2483	1.1523
7	1.4842	1.0486	.0655	.096	.096	1.3923	1.3443
8	1.4373	1.3599	.0492	.096	.096	1.7124	1.6324
9	1.2811	1.5565	.0655	.08	.08	1.7284	1.5844
10	.0312	1.7695	1.5565	1.5844	.08	.064	.064
11	.0312	1.9662	1.9204	2.0325	.08	.08	.096
12	.0469	2.0972	2.1285	2.1445	.08	.08	.08
13	.0625	2.1792	2.1285	2.0805	.08	.08	.08
14	.0625	2.1792	2.0325	2.0965	.08	.08	.08
15	.0469	2.0153	2.0485	1.9524	.064	.064	.096
16	.0625	1.9334	2.0645	2.0005	.08	.064	.096
17	.0469	1.9334	1.9204	1.9524	.08	.048	.096
18	.0625	.0655	.08	.064	.08	.064	.096
19	.0625	.0819	.096	.08	.096	.08	.096
20	.0625	.0983	.08	.08	.096	.096	.096
21	.0625	.0819	.08	.096	.096	.08	.096
22	.0625	.0819	.08	.08	.08	.08	.096
23	.0625	.0819	.08	.064	.08	.08	.08
24	1.1873		.0655	.064	.064	1.0082	.8802
Max	1.4842	2.1792	2.1285	2.1445	.096	1.7284	1.6324
Min	.0312	.0655	.0492	.064	.064	.048	.064
Avg	.5377	1.131	.7056	.7115	.0793	.5574	.5394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 206 / 11 KV MALIWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0381	.0191	.0362	.0354	.0177	.0358
2	.037	.0191	.0191	.0362	.0354	.0177	.0179
3	.037	.0191	.0191	.0362	.0354	.0177	.0179
4	.037	.0191	.0191	.0354	.0354	.0177	.0179
5	.037	.0381	.0191	.0354	.0354	.0177	.0179
6	.0381	.0381	.0381	.0354	.0354	.0354	.0358
7	.0381	.0381	.0381	.0354	.0354	.0354	.0358
8	.0381	.0381	.0381	.0354	.0354	.0354	.0358
9	.0381	.0381	.0191	.0354	.0354	.0354	.0358
10	.0381	.0381	.0381	.0354	.0354	.0354	.0179
11	.0381	.0381	.0358	.0354	.0354	.0354	.0358
12		.0381	.0358	.0354	.0354	.0354	.0358
13		.0191	.0358	.0354	.0354	.0179	.0358
14	.0191	.0191	.0358	.0354	.0354	.0179	.0358
15	.0381	.0381	.0358	.0177	.0177	.0179	.0179
16	.0191	.0381	.0358	.0177	.0354	.0179	.0358
17	.0191	.0381	.0358	.0354	.0177	.0179	.0358
18	.0381	.0381	.0358	.0354	.0354	.0179	.0358
19	.0381	.0381	.0362	.0354	.0354	.0358	.0358
20	.0381	.0381	.0362	.0354	.0354	.0358	.0358
21	.0381	.0187	.0181	.0354	.0354	.0179	.0358
22	.0381	.0373	.0362	.0354	.0354	.0358	.0358
23	.0381	.0187	.0362	.0354	.0354	.0358	.0179
24	.037	.0381	.0191	.0362	.0354	.0354	.0173
Max	.0381	.0381	.0381	.0362	.0354	.0358	.0358
Min	.0191	.0187	.0181	.0177	.0177	.0177	.0173
Avg	.0352	.0325	.0306	.0341	.0339	.0267	.0298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 207 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0526	.0526	.0526	.052	.0526	.0532
2	.0532	.0526	.0526	.0526	.0526	.0526	.0532
3	.0532	.0526	.0526	.0526	.0526	.0526	.0532
4	.0532	.0526	.0526	.0526	.0526	.0526	.0532
5	.0532	.0526	.0526	.0526	.0526	.0526	.0532
6	.0532	.0526	.0526	.0526	.0526	.0526	.0532
7	.0532	.0526	.0526	.0526	.0532	.0526	.0532
8	.0514	.0526	.0351	.0526	.052	.0526	.0532
9	.0514	.0701	.0526	.0526	.0693	.0526	.0532
10	.0701	.0701	.0526	.0701	.0701	.0526	.0701
11	.0693	.0701	.0693	.0701	.0701	.0532	.0532
12	.0701	.0701	.0693	.0701	.0686	.0532	.0709
13	.0701	.0701	.0693	.0701	.0686	.0532	.0709
14	.0701	.0701	.0693	.0701	.0686	.0526	.0709
15	.0701	.0701	.0693	.0701	.0686	.0526	.0532
16	.0701	.0701	.0693	.0526		.0526	.0532
17	.0693	.0701	.0693	.0526	.0526	.0526	.0532
18	.0526	.0526	.0526	.0526	.0526	.0514	.0532
19	.0526	.0526	.0526	.0526	.0526	.0686	.0532
20	.0526	.0526	.0526	.0526	.0526	.0686	.0532
21	.0526	.0526	.0526	.0526	.0526	.0686	.0532
22	.0526	.0526	.0526	.0526	.0526	.0686	.0532
23	.0526	.0526	.0526	.052	.0526	.0686	.0532
24	.0526	.0526	.0526	.0526	.052	.0526	.0526
Max	.0701	.0701	.0693	.0701	.0701	.0686	.0709
Min	.0514	.0526	.0351	.052	.052	.0514	.0526
Avg	.0584	.0592	.0567	.0570	.0576	.0560	.0561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 201 / 11 KV Dhavali Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	1.0513	.9054	.7377	.0191	.0191
2	.0191	.0191	1.0513	.9054	.7377	.0191	.0191
3	.0191	.0191	1.0513	.9054	.7377	.0191	.0191
4	.0191	.0191	1.0513	.9054	.7377	.0191	.0191
5	.0191	.0191	1.0513	.9054	.8048	.0191	.0191
6	.0191	.0191	1.1191	.9496	.8886	.0191	.0191
7	.0191	.0191	1.1736	1.0059	.9054	.0191	.0191
8	.0191	.0191	1.2742	1.1233	1.0395	.0191	.0191
9	.0382	.0191	1.2071	1.1736	1.3748		
10	1.6461	.0191	.0191	.0191	1.6617	1.2378	1.2209
11	2.0978	.0191	.0191	.0191	1.8313	1.8519	1.7147
12	2.1152	.0191	.0191	.0191	1.9204	1.8519	1.8031
13	2.2712	.0191	.0191	.0191	1.8482	1.8176	1.8004
14	2.3059	.0191	.0191	.0191	1.7295	1.8176	1.6804
15	2.2018	.0191	.0191	.0191	1.869	1.7147	1.6632
16	2.0458	.0191	.0191	.0191	1.8176	1.8004	1.6118
17	2.0285	.0191	.0191	.0191	1.749	1.7857	1.6644
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.7461	.663	.6371	.0191	.0191
Max	2.3059	.0191	1.2742	1.1736	1.9204	1.8519	1.8031
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.7099	.0191	.4602	.4046	.9643	.6158	.5846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 202 / 11 KV Nilaji Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5967	.5735	.0191	.0191	.0191	.6371	.6036
2	.5967	.5735	.0191	.0191	.0191	.6371	.6036
3	.5967	.5801	.0191	.0191	.0191	.6371	.6036
4	.5967	.5801	.0191	.0191	.0191	.6371	.6036
5	.5967	.5801	.0191	.0191	.0191	.6371	.6371
6	.663	.5868	.0191	.0191	.0191	.7042	.7042
7	.7377	.7127	.0191	.0191	.0191	.8718	.8718
8	.0191	.8288	.0191	.0191	.0191	1.0395	.9282
9	.0191	1.2548	.0191	.0191	.0191		
10	.0191	1.4563	1.2717	1.1361	.0191		.0191
11	.0191	1.7002	1.7556	1.531	.0191	.0191	.0191
12	.0191	1.7187	1.7002	1.6263	.0191	.0191	.0191
13	.0191	1.7372	1.7002	1.6078	.0191	.0191	.0191
14	.0191	1.7002	1.6632	1.6057	.0191	.0191	.0191
15	.0191	1.6632	1.6632	1.6057	.0191	.0191	.0191
16	.0191	1.5684	1.5154	1.531	.0191	.0191	.0191
17	.0191	1.4377	1.4377	1.4377	.0191	.0191	.0191
18	.0191	.0191		.0191	.0191	.0191	.0191
19	.0191	.0191		.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.5967	.5243	.0191	.0191	.0191	.6443	.6036
Max	.7377	1.7372	1.7556	1.6263	.0191	1.0395	.9282
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.2203	.8288	.5898	.5161	.0191	.3043	.2794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1463	.1509	.1949	.1646	.1509	.1494
2	.1478	.1463	.1509	.1949	.1646	.1509	.1494
3	.1478	.1494	.1509	.1949	.1646	.1509	.1494
4	.1478	.1494	.1509	.197	.1646	.1494	.1494
5	.1478	.1494	.1698	.2075	.2012	.1494	.1848
6	.2218	.2054	.2054	.2686	.2686	.168	.2715
7	.2218	.1886	.2054	.2743	.2561	.1829	.2926
8	.2658	.2715	.2686	.3506	.298	.2353	.3366
9	.2804	.2658	.3641	.3772	.3121		
10	.3429	.3641	.407	.4409	.407	.3294	.3988
11		.3601	.4917	.4527	.4475	.3772	.3467
12	.3856	.373	.4862	.4862	.4359	.3772	.3467
13	.373	.3561	.4527	.4694	.426	.3429	.3561
14	.3086	.3429	.3688	.4409	.421	.2774	.3601
15	.3395	.1715	.3018	.4024	.3978	.2915	.3429
16	.3772	.3086	.3688	.4475	.4424	.3086	.3086
17	.3772	.3052	.3353	.3561	.3688	.2804	.3467
18	.3201	.2629	.3052	.2652	.2818	.2058	.2427
19	.2686	.2195	.333	.3189	.2534	.2534	.2686
20	.2686	.2561	.3366	.2865	.2561	.2896	.2715
21	.2507	.2402	.3224	.2865	.2218	.2507	.2534
22	.2218	.2054	.2686	.2033	.1886	.1829	.2054
23	.1991	.1867	.2686	.1829	.1698	.1663	.1848
24	.1663	.181	.1663	.2481	.1646	.1509	.1494
Max	.3856	.373	.4917	.4862	.4475	.3772	.3988
Min	.1478	.1463	.1509	.1829	.1646	.1494	.1494
Avg	.2577	.2419	.2929	.3145	.2865	.2357	.2637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 204 / 11 KV Takali Bolwad Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.7773	.7274	.6325	.0943	.132
2	.0943	.0943	.7773	.7274	.6325	.0943	.132
3	.0943	.0943	.7773	.7362	.6325	.0943	.132
4	.0943	.0943	.7773	.7362	.6325	.0943	.132
5	.1132	.0943	.7773	.7362	.6722	.1132	.1509
6	.1509	.0953	1.0978	.9175	.7522	.1509	.1698
7	.1509	.1132	1.3108	1.0526	.8848	.1509	.1886
8	.168	.0943	1.4089	1.2631	.953	.1521	.2075
9	.2988	.0754	1.4089	1.2955	1.1797		
10	1.1843	.0754	.1109	.1132	1.6385	1.1142	.9555
11	1.7204	.0566	.1132	.1132	1.6842	1.8187	1.4746
12	1.9393	.112	.1448	.0914	1.6712	1.7814	1.5729
13	1.9062	.0924	.0924	.0914	1.6032	1.6804	1.5223
14	1.8399	.0914	.0924	.0732	1.5384	1.6324	1.0883
15	1.8023	.0724	.0724	.0732	1.6221	1.6004	1.4575
16	1.8023	.0905	.0732	.0716	1.6057	1.587	1.4899
17	1.6712	.1086	.112	.0537	1.4899	1.6876	1.5074
18	.1147	.1494	.132	.0876	.132	.0895	.1132
19	.1698	.2075	.1886	.1886	.1886	.1698	.1886
20	.1698	.1886	.1698	.1886	.1886	.1886	.1886
21	.1509	.1886	.1698	.1698	.1698	.1886	.1509
22	.132	.1698	.1509	.1698	.1509	.1698	.1509
23	.1132	.132	.132	.1509	.132	.1509	.1509
24	.0943	.0943	.7773	.6325	.5535	.0943	.132
Max	1.9393	.2075	1.4089	1.2955	1.6842	1.8187	1.5729
Min	.0943	.0566	.0724	.0537	.132	.0895	.1132
Avg	.6696	.1116	.4852	.4359	.8892	.6477	.5821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 206 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1886	.1509	.1698	.1698	.1509	.1509
2	.1509	.1698	.1509	.1698	.1698	.1509	.1509
3	.1509	.1698	.1509	.1698	.1698	.1509	.1509
4	.1509	.1698	.1509	.1698	.1698	.1509	.1509
5	.1886	.2263	.1509	.1698	.1886	.1698	.1886
6	.3018	.2641	.2829	.2641	.2829	.2452	.2263
7	.3395	.3395	.3395	.3395	.3018	.2641	.2263
8	.3206	.3395	.3395	.3584	.3018	.2829	.2641
9	.2641	.3206	.3018	.3018	.2641		.2829
10	.2641	.2452	.2829	.2641	.2641	.2452	.2641
11	.2452	.2641	.2641	.2452	.2452	.2075	.2452
12	.2452	.2641	.2263	.2263	.2263	.2075	.2263
13	.2263	.2075	.2452	.2263	.2075	.2075	.2263
14	.2263	.2075	.2075	.2075	.2075	.1509	.2075
15	.2263	.2075	.1698	.1509	.1886	.1509	.2075
16	.2263	.1698	.1509	.1698	.132	.1509	.2263
17	.1886	.1509	.1698	.1698	.1886	.1509	.2263
18	.1698	.1698	.2075	.2075	.1886		.2641
19	.3018	.3018	.2829	.3018	.3206	.3018	.3395
20	.2829	.3018	.3018	.2641	.3206	.2641	.2641
21	.2263	.2829	.2263	.2452	.3018	.2452	.2263
22	.2263	.2452	.2263	.2263	.2452	.2263	.1509
23	.2075	.1886	.2075	.1886	.2263	.1886	.1509
24	.1886	.1886	.1509	1.0562	.1698	.1509	.1509
Max	.3395	.3395	.3395	1.0562	.3206	.3018	.3395
Min	.1509	.1509	.1509	.1509	.132	.1509	.1509
Avg	.2279	.2326	.2224	.2609	.2271	.2006	.2153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 201 / Soni Gavathan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.1509	.1509	.1698	.1509	.1509
2	.132	.132	.1509	.1494	.1698	.1509	.1509
3	.132	.132	.1509	.1509	.1698	.1509	.1509
4	.132	.1509	.1698	.1698	.1698	.1509	.1698
5	.1886	.1886	.1886	.2075	.1867	.1886	.1886
6	.2241	.2263	.2452	.2641	.2614	.2452	.2641
7	.2801	.3018	.2829	.2801	.3174	.2829	.3018
8	.2801	.2801	.2614	.2427	.2241	.2241	.2829
9	.2054	.2241	.1867	.1867	.2054	.2054	.2263
10	.168	.1867	.2054	.1867	.168	.168	.1448
11	.168	.168	.168	.168	.1867	.168	.1612
12	.1307	.1494	.1494	.128	.1307	.1494	.1463
13	.1494	.1307	.1494	.1294	.1494	.1307	.1086
14	.1307	.1307	.1494	.1294	.1494	.1307	.1402
15	.1494	.1307	.1494	.128	.1307		.1267
16	.1494	.1494	.1307	.1109	.1307	.1867	.1254
17	.1307	.1494	.1307	.1478	.1494	.2241	.181
18	.2054	.1867	.2241	.1867	.2241	.2263	.2427
19	.3584	.3584	.3361	.3547	.3395	.3584	.3361
20	.3584	.3395	.3361	.3174	.3206	.3772	.3174
21	.3018	.3018	.2987	.2801	.2829	.3395	.2987
22	.2452	.2263	.2241	.2427	.2452	.2263	.2263
23	.3222	.1886	.1867	.1886	.1886	.1886	.1886
24	.132	.132	.1509	.1494	.1698	.1509	.1509
Max	.3584	.3584	.3361	.3547	.3395	.3772	.3361
Min	.1307	.1307	.1307	.1109	.1307	.1307	.1086
Avg	.2003	.1957	.1990	.1937	.2017	.2076	.1992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 202 / 11 KV Bhose Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1698	.132	.1132	.1886	.1886	.1886
2	.1886	.1698	.132	.1132	.1886	.1886	.1698
3	.1886	.1698	.132	.1132	.1886	.1886	.1698
4	.1886	.1698	.1509	.1132	.1886	.1886	.1698
5	.2075	.1698	.2075	.1509	.2263	.1886	.1698
6	.2427	.1698	.2641	.2641	.2987	.2263	.1698
7	.2241	.2075	.2263	.2987	.2241	.2641	.2263
8	.2427	.2054	.2241	.2241	.2427	.2054	.2263
9	.2801	.2054	.1867	.2054	.3174	.2241	.2263
10	.3734	.3361	.3361	.4108	.2614	.1494	.2241
11	.5228	.4668	.4668	.2614	.2987	.2241	.2987
12	.6161	.4668	.5601	.2241	.5228	.2614	.4481
13	.5975	.4481	.5601	.1307	.3547	.2801	.4668
14	.3547	.1494	.2801	.2614	.5601	.2614	.0934
15	.4108	.2801	.5601	.2427	.5788		
16	.5041	.3361	.6161	.3174	.2987	.2241	.4294
17	.5788	.4294	.4668	.1307	.4854	.4294	.4481
18	.3174	.2987	.3361	.168	.2427	.3206	.3734
19	.2075	.2641	.2241	.2241	.2075	.2829	.2241
20	.2075	.2263	.2054	.2427	.2075	.2075	.2427
21	.1886	.2452	.1867	.2054	.2075	.2263	.1867
22	.1886	.2641	.1494	.168	.2075	.2641	.2054
23	.1886	.2263	.1307	.1867	.2075	.2452	.1886
24	.2075	.1886	.1886	.112	.2241	.1886	.2263
Max	.6161	.4668	.6161	.4108	.5788	.4294	.4668
Min	.1886	.1494	.1307	.112	.1886	.1494	.0934
Avg	.3090	.2610	.2885	.2034	.2887	.236	.2510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 203 / 11 KV PATGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.2753	.2622	.2486	.0754	.0566
2	.0754	.0754	.2753	.2622	.2486	.0754	.0566
3	.0754	.0754	.2753	.2622	.2486	.0754	.0566
4	.0754	.0754	.2915	.2949	.3277	.0754	.0566
5	.0754	.0754	.3239	.3277	.3563	.0754	.0754
6	.0934	.0943	.4049	.3563	.4372	.1132	.0754
7	.112	.1132	.8097	.583	.5121	.1132	.0943
8	.0747	.0934	.8907	.8583	.6478	.1307	.0943
9	.0747	.0934	.9231	1.004	.8421	.0934	.0943
10	.5668	.0934	.0747	.0934	.9878	.5898	.4534
11	1.085	.0934	.0934	.0747	1.1012	1.0202	.9393
12	.9717	.0934	.0747	.0934	1.166	1.1012	1.0526
13	1.1336	.0747	.0747	.0747	.9878	1.1174	1.0364
14	1.1174	.0747	.0747	.0934	1.0526	1.1012	1.004
15	1.166	.0747	.0747	.0934	1.1174		1.004
16	1.2308	.0934	.0747	.0747	1.1012	.421	1.0688
17	1.0364	.0934	.0934	.0747	1.0364	1.0202	1.085
18	.0747	.0934	.0934	.0934	.0747	.0943	.056
19	.132	.1132	.0934	.0934	.1132	.0943	.112
20	.132	.132	.0934	.1307	.132	.0943	.112
21	.132	.132	.0934	.112	.0943	.0943	.0934
22	.0943	.1132	.0934	.0747	.0943	.0754	.0754
23	.0754	.0943	.0747	.0747	.0943	.0754	.0566
24	.0754	.0754	.2105	.2486	.2486	.0754	.0566
Max	1.2308	.132	.9231	1.004	1.166	1.1174	1.085
Min	.0747	.0747	.0747	.0747	.0747	.0754	.056
Avg	.4065	.0923	.2440	.2379	.5530	.3392	.3694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 204 / Soni AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.3239	.3277	.3315	.0943	.0943
2	.0754	.0943	.3239	.3277	.3315	.0943	.0943
3	.0754	.0943	.3239	.3277	.3277	.0943	.0943
4	.0754	.1132	.3401	.3605	.3605	.1132	.1132
5	.0943	.132	.3887	.4588	.4049	.132	.1509
6	.1307	.1509	.6154	.5506	.4858	.1698	.1886
7	.1494	.1698	.8907	.7449	.6241	.1886	.2075
8	.168	.1867	1.085	1.0364	.7865	.168	.1886
9	.1867	.168	1.1822	1.1984	.9231	.1494	.2075
10	.5344	.168	.0747	.0747	.9717	.503	.4534
11	.9555	.1494	.112	.1307	1.0364	.9231	.8583
12	1.1498	.1494	.112	.112	1.0202	1.0364	.9717
13	1.1174	.1307	.1307	.112	1.0364	1.0688	1.004
14	1.1336	.1494	.112	.0934	1.004	1.0526	1.0526
15	.7449	.1494	.112	.112	.9717		1.0364
16	1.0526	.1494	.112	.1494	1.0364	.4858	1.1174
17	.9717	.1494	.168	.2054	1.0526	.9231	1.1174
18		.168	.1867	.1867	.112	.0943	.1307
19	.1509	.1886	.2054	.2241	.2075	.1698	.168
20	.1698	.1886	.2054	.168	.1698	.1886	.1307
21	.132	.1509	.1867	.168	.1698	.1509	.1307
22	.1132	.132	.168	.1307	.132	.132	.0943
23	.0943	.0943	.1307	.0943	.1132	.1132	.0943
24	.0754	.0943	.2915	.3353	.3315	.0943	.1132
Max	1.1498	.1886	1.1822	1.1984	1.0526	1.0688	1.1174
Min	.0754	.0943	.0747	.0747	.112	.0943	.0943
Avg	.4098	.1423	.3242	.3179	.5809	.3539	.4088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 206 / 11kv Karoli AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.3563	.3605	.2984	.132	.132
2	.1132	.1132	.3563	.3605	.2984	.132	.132
3	.1132	.1132	.3563	.3605	.2984	.132	.132
4	.1132	.132	.3725	.3605	.3277	.1509	.1509
5	.1886	.1509	.4534	.426	.4049	.1886	.1886
6	.2241	.2452	.664	.6802	.6154	.2829	.2829
7	.3174	.3206	1.1822	1.0364	.8482	.3018	.3206
8	.3174	.2987	1.2631	1.5708	1.1336	.2801	.3584
9	.1867	.1867	1.3765	1.4575	1.1822	.2427	.2263
10	.6154	.1867	.1494	.1494	1.2793		.4696
11	1.1822	.168	.168	.168	1.247		.9555
12	1.1984	.1494	.168	.1494	1.1822		1.1174
13	1.1174	.1494	.168	.168	1.1012		1.1822
14		.1494	.168	.1867	1.1498		1.2146
15	1.1174	.1494	.168		1.1984		1.1822
16	1.004	.1307	.2054	.1494	.6478		1.2146
17	1.0202		.2801	.2054	.8421		1.1984
18	.1867	.1867	.2987	.2241	.1494	.1509	.2054
19	.2641	.2263	.3174	.3174	.3206	.3018	.2987
20	.2452	.2829	.2801	.2801	.2829	.3018	.2801
21	.2075	.2452	.2241	.2801	.2452	.2452	.2427
22	.1509	.1886	.1867	.1867	.1698	.2075	.1867
23	.132	.1509	.168	.1494	.1509	.1886	.1509
24	.2085	.1132	.3077	.3647	.2984	.132	.1509
Max	1.1984	.3206	1.3765	1.5708	1.2793	.3018	1.2146
Min	.1132	.1132	.1494	.1494	.1494	.132	.132
Avg	.4494	.1805	.4016	.4170	.6530	.2107	.4989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 207 / 11KV Bhose AG Spare
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.7287	.0754	.0754	.0943	.8259	.8097
2	.9945	.7287	.0754	.0754	.0943	.8259	.8097
3	.9717	.7287	.0754	.0754	.0943	.8259	.8097
4	1.0526	.7449	.0943	.0754	.0943	.8745	.5556
5	1.1336	.7773	.1132	.0943	.0943	.9393	.9555
6	1.2955	.9231	.132	.132	.1307	1.166	1.1174
7	2.0005	1.1822	.1509	.1494	.1307	1.6842	1.6356
8	.112	1.4899	.1494	.1307	.1307	2.0081	2.0243
9	.112	1.8138	.1494	.1307	.168	2.0809	2.1214
10	.168	2.2834	1.1336	1.4899	.1307	.112	.0747
11	.1494	2.5587	2.5606	2.4615	.1494	.168	.1307
12	.1494	2.2996	2.6073	2.332	.1307	.168	.1307
13	.168	2.0891	2.5101	2.2996	.1307	.1494	.1307
14	.1494		2.4577	2.3967	.1307	.1494	.1307
15	.1494	2.251	2.3482	2.3644	.1307		.112
16	.1494	2.1376	2.3482	2.4291	.1494	.0934	.112
17	.1494	2.0081	1.8404	2.5587	.1494	.0934	.1307
18	.1494	.1307	.0934	.0934	.168	.132	.1307
19	.1698	.1509	.1307	.168	.168	.1509	.168
20	.1698	.1509	.1494	.1494	.1509	.1698	.168
21	.1698	.132	.1494	.1307	.1509	.1509	.1494
22	.132	.0943	.1307	.112	.1132	.1509	.1307
23	.0943	.0943	.112	.0934	.1132	.132	.1307
24	.9907	.7287	.0943	.0747	.0943	.8259	.8259
Max	2.0005	2.5587	2.6073	2.5587	.168	2.0809	2.1214
Min	.0943	.0943	.0754	.0747	.0943	.0934	.0747
Avg	.4906	1.1403	.8201	.8372	.1288	.6033	.5623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 201 / 11 KV Savali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.1494	.112	.1294	.4481	.4108	.4481
2	.5853	.1294	.1478	.128	.4668	.4108	.4481
3	.5975	.128		.1294	.4481	.4108	.5228
4	.5975	.1294	.1829	.1294	.4481	.4108	.4854
5	.6584	.1307	.1829	.1867	.5228	.5601	.5601
6	.7762	.1829	.2241	.1829	.5975	.7095	.7468
7	1.2696	.2587	.2263	.2587	.8589	1.0456	1.251
8	.2033	.2195	.2614	.2012	1.0456	1.307	1.363
9	.1829	.2218	.2241	.2033	.961	1.2696	1.3306
10	.1663	.4481	.5601	.7468	.1494	.1294	.1494
11	.1494	1.3443	1.3443	1.531	.1463	.1463	.1463
12	.1494	1.3957	1.5684	1.5154	.1494	.1478	.1478
13	.1698	1.419	1.4563	1.4563	.1494	.1867	.1494
14	.168	1.4712	1.4003	1.3676	.1478	.1478	.1848
15	.1886	1.4937	1.4377	1.3443	.1097		.1463
16	.168	1.4335	1.4003	1.3306	.112	.1478	.1478
17	.168	1.419	1.4003	1.419	.1698	.168	.168
18	.1848	.112	.112	.1307	.1867	.1698	.1886
19	.2743	.1698	.2427	.2614	.2218	.1867	.1867
20	.2772	.1867	.2427	.2241	.2195	.2218	.2241
21	.2614	.2263	.2241	.1867	.2218	.2241	.2263
22	.1848	.168	.2241	.1867	.1867	.1886	.1867
23	.1829	.1478	.168	.1494	.1494	.1867	.1494
24	.5975	.1848	.112	.168	.4854		.3696
Max	1.2696	1.4937	1.5684	1.531	1.0456	1.307	1.363
Min	.1494	.112	.112	.128	.1097	.1294	.1463
Avg	.3647	.5487	.5850	.5653	.3584	.3994	.4136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 202 / 11 KV SAIPRASAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5175	.4755	.5487	.4854	.4481	.4108
2	.5175	.5041	.4706	.5544	.4668	.4481	.4108
3	.5041	.4938	.4525	.5601	.4668	.4481	.3921
4	.4938	.5175	.4572	.5175	.4854	.4481	.3921
5	.4805	.5228	.439	.5121	.4854	.4481	.4108
6	.4854	.499	.462	.499	.4668	.4481	.3921
7	.439	.4668	.4481	.5041	.4668	.4108	.3921
8	.4108	.462	.4904	.4755	.4294	.3921	.3921
9	.4435	.5041	.5847	.499	.4805	.4024	.462
10	.7468	.5658	.5788	.6348	.823	.3881	.6908
11	.7922	.6413	.7468	.8413	.8871	.4294	.8131
12	.8962	.6722	.8029	.8501	.8402	.4024	.8215
13	.7922	.7167	.9896	.7842	.8131	.4066	.7762
14	.7468	.7468	.7842	.6468	.8029	.4481	.6767
15	.7167	.7842	.7655	.8589	.8775		.9335
16	.7468	.7545	.8402	.8501	.8596	.4108	.8871
17	.7468	.7095	.9522	.8402	.7392	.3734	.7468
18	.6348	.7095	.8402	.5975	.6722	.3772	.5281
19	.5729	.6036	.6161	.4854	.5658	.4108	.5228
20	.5601	.5601	.5601	.4294	.4481	.415	.4854
21	.5175	.4904	.5228	.5041	.4108	.3734	.4527
22	.5121	.5041	.5041	.5041	.4527	.3772	.4854
23	.5175	.5228	.5228	.5041	.4481	.4108	.5281
24	.5228	.5228	.5175	.5601	.5228		.3881
Max	.8962	.7842	.9896	.8589	.8871	.4481	.9335
Min	.4108	.462	.439	.4294	.4108	.3734	.3881
Avg	.5962	.5830	.6177	.6067	.5999	.4144	.5580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 203 / 11 KV Savali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.112	.1307	.1097	.112	.112	.112
2	.1097	.1109	.1307	.1097	.112	.112	.112
3	.0549	.1097	.1509	.1109	.112	.112	.112
4	.1109	.1086	.168	.112	.112	.112	.112
5	.1307	.1448	.1663	.1294	.1307	.112	.112
6	.1463	.1448	.1829	.1307	.1494	.1307	.168
7	.1848	.2012	.1829	.2012	.2054	.168	.2054
8	.1829	.2218	.2054	.2033	.2241	.2427	.2427
9	.1663	.2054	.1886	.2054	.2012	.1848	.1663
10	.1663	.1886	.1886	.1848	.2054	.1494	.1307
11	.1867	.1867	.1698	.2241	.1848	.1646	.1829
12	.1886	.1698	.2075	.2218	.1829	.1494	.2033
13	.1867	.168	.1886	.2241	.168	.1294	.1829
14	.1698	.1848	.168	.2033	.1663	.1307	.1494
15	.1715	.1829	.1494	.2195	.1646		.1829
16	.1886	.1646	.1867	.2241	.1663	.2054	.1848
17	.1867	.1629	.2054	.1867	.1867	.2218	.2241
18	.2743	.1829	.2054	.2427	.2263	.2195	.2614
19	.3326	.1867	.3018	.4854	.1867	.2454	.2587
20	.2926	.2263	.2829	.2614	.168	.2686	.2241
21	.2218	.2263	.2263	.2614	.1509	.2534	.2263
22	.1867	.1867	.1698	.1867	.1307	.2195	.1829
23	.1463	.1494	.1307	.1307	.132	.1848	.1086
24	.112	.1109	.1109	.112	.112		.1075
Max	.3326	.2263	.3018	.4854	.2263	.2686	.2614
Min	.0549	.1086	.1109	.1097	.112	.112	.1075
Avg	.1754	.1682	.1833	.1950	.1621	.1740	.1730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 204 / BOTHRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.5544	.7392	.7842	.7095	.7468	.5975
2	.4572	.5601	.7023	.7762	.7282	.7655	.6161
3	.4108	.5853	.7095	.7499	.7095	.7655	.5975
4	.4066	.5914	.7095	.7577	.7095	.7468	.5975
5	.3658	.6219	.7392	.7655	.6535	.7655	.6161
6	.3361	.6335	.695	.7392	.5601	.8029	.6161
7	.3696	.567	.7316	.6348	.6161	.5975	.5601
8	.1848	.5914	.5975	.5914	.5415	.5975	.5228
9	.3361	.6161	.6908	.6161	.4481	.5228	.6219
10	.4435	.7095	.8029	.7392	.5853	.5544	.6283
11	.5228	.7922	.9709	.695	.6283	.6584	.8775
12	.679	.8215	.7842	.7023	.8589	.6283	.8871
13	.7095	.8676	.5601	.6908	.7133	.5487	.7468
14	.7468	.8962	.8402	.6653	.7207	.5544	.6099
15	.7922	.9431	.7468	.7682	.6722		.8048
16	.8215	.8402	.7842	.7577	.6767	.1109	.8029
17	.8589	.6653	.8402	.6348	.7023	.2195	.6602
18	.8048	.5487	.7095	.5601	.7468	.2865	.5601
19	.7392	.5228	.5601	.7468	.7167	.2804	.5658
20	.6722	.5281	.6161	.6535	.6535	.3155	.5228
21	.5914	.5601	.6535	.6161	.6036	.3403	.5281
22	.5853	.6535	.6908	.6535	.6722	.362	.5544
23	.5544	.7023	.7842	.6908	.7468	.3658	.6584
24	.4668	.5601	.7316	.7842	.7468		.4207
Max	.8589	.9431	.9709	.7842	.8589	.8029	.8871
Min	.1848	.5228	.5601	.5601	.4481	.1109	.4207
Avg	.5549	.6638	.7246	.6989	.6717	.5244	.6322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 205 / 11 KV REX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	1.0269	.8501	.7762	.7655	.7468	.5601
2	.9511	1.0164	.7392	.7682	.7655	.7468	.5788
3	.9335	1.0269	.7468	.7842	.7468	.7468	.6161
4	.924	1.0059	.7095	.7762	.7468	.7655	.6161
5	.9145	1.0164		.7842	.7095	.7468	.5975
6	.8686	.9896	.8676	.7762	.6535	.6722	.5975
7	.8775	.9511	.9335	.7282	.6348	.7655	.5228
8	.8413	.961	.9808	.7577	.6535	.5975	.5601
9	.8871	.9896	.7356	.7842	.6401	.6535	.6468
10	.9335	1.094	.8029	.8871	.6653	.7207	.6908
11	.9709	1.1576	.5975	.8215	.6584	.6219	.7133
12	1.0374	1.1317	.7842	.7207	.7282	.6283	.7207
13	1.0082	1.0829	.7468	.7655	.7133	.6348	.8962
14	.9808	1.0456	.7282	.6767	.7207	.6348	.924
15	1.0185	1.0185	.9335	.6653	.8029		.9145
16	1.0829	1.0269	.8402	.6908	.7865	.4572	.8962
17	1.1203	1.0562	.7095	.8029	.7023	.5175	.5281
18	1.0608	1.0829	.7095	.7468	.6722	.5975	.2614
19	.924	1.0374	.6722	.7842	.6602	.7545	.4805
20	1.0829	1.0082	.6348	.7655	.6348	.8215	.5975
21	1.0719	1.0456	.6348	.6908	.5975	.7545	.7545
22	1.0829	.9335	.6348	.7095	.7167	.6535	.7762
23	1.0164	.9335	.6535	.7468	.7922	.5544	.8413
24	.9709	.961	.8962	.6535	.7468		.6348
Max	1.1203	1.1576	.9808	.8871	.8029	.8215	.924
Min	.8413	.9335	.5975	.6535	.5975	.4572	.2614
Avg	.9800	1.0250	.7627	.7526	.7048	.6724	.6636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 208 / 11KV KANADWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.1109	.1097	.0924	.112	.0934	.0934
2	.0934	.112	.1294	.0934	.112	.0934	
3	.0914	.1097	.1294	.0914	.112	.0934	.0934
4	.0924	.1109	.1494	.0924	.112	.0934	.0934
5	.0934	.112	.1494	.0934	.112	.0934	.0934
6	.0914	.1097	.1698	.0914	.1307	.112	.0934
7	.1109	.0924	.1698	.1109	.0934	.0934	.0934
8	.112	.112	.112	.0747	.0934	.0934	.112
9	.1109	.1109	.0934	.0924	.1109	.0914	.1109
10	.1307	.0934	.112	.1307	.112	.0739	.128
11	.1294	.1132	.1494	.1494	.0914	.0747	.1294
12	.1494	.112	.1494	.1478	.1109	.0549	.1494
13	.1294	.1132	.0934	.128	.0914	.0554	.1463
14	.1307	.1307	.0747	.0934	.0924	.056	.1109
15	.1132	.132	.1307	.1109	.1307		.1494
16	.112	.1494	.1307	.1097	.1097	.0554	.1463
17	.112	.1478	.112	.1494	.0924	.0724	.1294
18	.128	.168	.112	.1494	.0934	.0716	.1494
19	.1478	.1509	.1867	.1494	.132	.0876	.1109
20	.1494	.1307	.1494	.1494	.168	.1075	.128
21	.1109	.112	.1307	.112	.1886	.1086	.1307
22	.112		.0934	.112	.1494	.0914	.1109
23	.1109		.0747	.112	.0934	.0924	.0914
24	.112	.1097	.1097	.0934	.112		.0934
Max	.1494	.168	.1867	.1494	.1886	.112	.1494
Min	.0914	.0924	.0747	.0747	.0914	.0549	.0914
Avg	.1153	.1202	.1259	.1137	.1148	.0845	.1168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 201 / 11 KV malgaon Gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18
HR	Load (MW)
24	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 202 / 11 KV Cannal AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1905	.7287	.4696	.4999	.1524	.2286
2	.2286	.1715	.7287	.506	.4999	.1334	.2096
3	.1905	.1715	.8097	.5243	.506	.1524	.2096
4	.1905	.1905	1.0526	.5087	.506	.1524	.2096
5	.2667	.2667	1.0526	.6154	.6401	.2286	.2858
6	.362	.381	1.3765	.9069	.8482	.3239	.3429
7	.4572	.4191	1.7814	1.5154	1.186	.3429	.4191
8	.4572	.4191	1.8027		1.4074	.3429	.4191
9	.4763	.4382	1.6288	1.0364	1.6288	.2667	.4001
10	2.1376	.4382	.2286	.1905	1.8818	.7099	.3637
11	2.1052	.4001	.3048	.2096	1.8785	1.4074	1.5971
12	2.0243	.3429	.1143		1.7532	1.3763	1.7078
13	1.9757	.362	.1334	.0572	1.6712		1.7166
14	1.829	.3048	.1143	.0762	1.6129		1.6712
15	1.8785	.3048	.1143	.0953	1.5741		1.7368
16	1.4737	.3239	.1524	.1143	1.6644		1.2146
17	.4973	.3429	.1524	.0953	.6661	1.2809	1.2967
18	.5716	.381	.4191	.0953	.2858	.2667	.3048
19	.5144	.381	.6097	.6478	.381	.2858	.4382
20	.4001	.3429	.5144	.5335	.381	.4763	.381
21	.381	.2858	.4382	.4001	.3048	.4191	.362
22	.2858	.3239	.362	.381	.2286	.3429	.3048
23	.2477	.2667	.2858	.3048	.1905	.2667	.2667
24	.2286	.2096	.2286	.4696	.5093	.1524	.2286
Max	2.1376	.4382	1.8027	1.5154	1.8818	1.4074	1.7368
Min	.1905	.1715	.1143	.0572	.1905	.1334	.2096
Avg	.8087	.3191	.6306	.4433	.9461	.454	.6798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 203 / 11KV RAMNAGAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.3109	.1524	.1334	.1143		.4075
2	.463	.3361	.0953	.1143	.1143		.3982
3	.463	.3174	.0953	.1143	.1143		.3982
4	.5468	.3174	.0953	.0953	.1143		.4239
5	.5468	.4755	.0953	.1334	.1524		.6859
6	.6325	.5316	.1524	.1905	.2477		.9114
7	.9172	.6706	.1905	.2477	.2477		1.1248
8	.1524	.7209	.2477	.2477	.2858		1.1984
9	.1905	.852	.3048	.2286	.2477		1.0279
10	.2477	.9488	.743	.5304	.2286		.0953
11	.2286	.9878	1.0185	.8025	.1334		.1334
12	.1905	.9962	1.1111	1.0235	.1524		.1334
13	.1524	1.0322	1.0031	.9556	.1524		.1524
14	.1524	.8848	.9633	.9808	.1524		.1524
15	.1524	.8749	.9181	.9783	.1715		.1334
16	.1524	.9717	.9602	1.0669	.1715		.1715
17	.1715	.6478	.8697	.9907	.1905	.2096	.1524
18	.2286	.0953	.4954	.0953	.1905	.3048	.1905
19	.2286	.1524	.2096	.2477	.2096	.2858	.2286
20	.2477	.1905	.2286	.2286	.1905	.2858	.2477
21	.2096	.2286	.2286	.2096	.1715	.2286	.2096
22	.1715	.2096	.1905	.2096	.1524	.1905	.1715
23	.1334	.1715	.1524	.1524	.1524	.1143	.1334
24	.503	.2096	.1334	.1334	.1334	.3403	.4075
Max	.9172	1.0322	1.1111	1.0669	.2858	.3403	1.1984
Min	.1334	.0953	.0953	.0953	.1143	.1143	.0953
Avg	.3161	.5473	.4439	.4213	.1746	.2450	.3871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 201 / 11 KV Sidhewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.0914	.2214	.2561	.2401	.1132	.1132
2	.112	.1109	.2214	.3077	.2804	.132	.1132
3	.132	.1132	.2214	.3077	.2774	.1132	.1132
4	.1509	.1463	.2214	.3681	.3086	.132	.1132
5	.168	.1478	.3163	.3681	.3353	.132	.132
6	.1886	.1886	.5182	.4534	.4588	.1509	.1698
7	.2378	.1886	.8745	.8583	.5441	.2452	.2641
8	.1886	.1698	.9717	.8962	.5735	.2075	.2452
9	.1494	.112	.7935	.8642	.6036	.2075	.1698
10	.2812	.0747	.0554	.112	.7522	.2932	.1715
11	.9282	.0895	.132	.1132	.8002	.7682	.6325
12	.8539	.112	.0943	.1294	.8539	.7682	.703
13	.7186	.0739	.132	.112	.703	.8381	.787
14	.1543	.0934	.132	.1132	.8855	.8002	
15	.9762	.0934	.0943	.0924	.8539		.7811
16	1.0082		.0934	.0924	.9172	.1907	.7811
17	.828	.0943	.0934	.112	.8065	.7202	.7811
18	.0549	.0934	.0934	.1132	.0532	.0934	.0554
19	.1698	.1698	.1698	.1294	.2075	.1886	.2012
20	.168	.1886	.1698	.1494	.1886	.1886	.2012
21	.1698	.1698	.1698	.1698	.1698	.1698	.1509
22	.1509	.132		.1494	.1698	.1698	.1509
23	.1132	.1132	.1132	.1478	.1132	.132	.0943
24	.1132	.0943	.176	.2401	.2195	.1132	.132
Max	1.0082	.1886	.9717	.8962	.9172	.8381	.787
Min	.0549	.0739	.0554	.0924	.0532	.0934	.0554
Avg	.3386	.1244	.2643	.2773	.4715	.2986	.3068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 202 / 11KV Kalambi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0914	.0943	.0924	.1075	.1132	.0943
2	.0914	.0924	.0943	.1294	.1075	.1509	.0943
3	.112	.1132	.0943	.1307	.1227	.1509	
4	.1509	.112	.0943	.1109	.128	.1307	.0943
5	.1646	.1463	.0943	.1132	.1478	.1307	.1132
6	.1848	.1509	.132	.132	.1494	.1509	.132
7	.2263	.1509	.132	.2263	.1698	.1698	.2614
8	.2715	.1509	.2075	.2075	.1307	.132	.2378
9	.4066	.132	.3045	.2033	.0924	.2263	.2957
10	.3121	.1509	.2629	.2614	.2481	.2452	.4344
11	.298	.333	.2561	.2614	.2896	.2353	.2543
12	.3121	.3403	.2263	.2614	.2865	.2378	.2774
13	.333	.3109	.2835	.2772	.2075	.1509	.2947
14	.0709	.2743	.2835	.2561	.1848	.2054	.2804
15	.3721	.2896	.3582	.2801	.1663		.2195
16	.2774	.2896	.1132	.3018	.1829	.0754	.1677
17	.2507	.2427	.2715	.2218	.3077	.1132	.1677
18	.3045		.2402	.1463	.2743	.2987	.1698
19	.2402	.2075	.2075	.1294	.2054	.2241	.2075
20	.2241	.1698	.2075	.1494	.2075	.2075	.2075
21	.1698	.1698	.2075	.1509	.1886	.1698	.1886
22	.132	.132	.1509	.1294	.1886	.1509	.1886
23	.112	.1132	.1509	.112	.132	.1132	.1132
24	.0943	.0934	.0943	.0924	.0943	.0943	.0943
Max	.4066	.3403	.3582	.3018	.3077	.2987	.4344
Min	.0709	.0914	.0943	.0924	.0924	.0754	.0943
Avg	.2168	.1851	.1901	.1824	.1800	.1686	.1995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 203 / 11 KV Kalambi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2538	.1738	.0895	.0895	.0739	.1907	.2201
2	.2606	.1715	.0895		.0739	.1806	.2201
3	.2675	.1974	.0895	.0905	.0747	.2258	.2201
4	.2934	.1947	.0895	.112	.0943	.2641	.2201
5	.5601	.2195	.0895	.1307	.1109	.2641	.2494
6	.5135	.2332	.112	.1307	.112	.3612	.3121
7	.6687	.2364	.1307	.112	.128	.5719	.5719
8	.1254	.2643	.112	.1478	.1109	.6687	.6687
9	.1063	.5357	.0914	.1829	.1307	.6171	.6455
10	.1267	.587	.2751	.4298	.1017	.0686	.0497
11	.0867	.7011	.587	.8962	.0678	.128	.0886
12	.0876	.639	.6093	.9808		.0886	.0876
13	.0886	.6161	.639	.7628	.0819	.0876	.0857
14	.0526	.5428	.6241	.8402	.0876	.0876	.0886
15	.0895	.5647	.6161		.0857		.0886
16	.0905	.5647		.5944	.0848	.0848	.0867
17	.1075	.5144	.5921	.7545	.1086	.1086	.0867
18	.1448	.0693	.124	.0876	.1463	.1663	.0905
19	.1478	.1478	.1267	.0934	.1294	.1307	.112
20	.1109	.1294	.1097	.1109	.1294	.1294	.112
21	.1294	.1097	.1097		.1109	.1109	.1109
22	.0924	.1109		.0943	.1109	.0914	.1109
23	.0732	.0905	.1097	.0924	.0716	.0914	.0905
24	.2606	.1593	.0905	.0716	.0754	.176	.2201
Max	.6687	.7011	.639	.9808	.1463	.6687	.6687
Min	.0526	.0693	.0895	.0716	.0678	.0686	.0497
Avg	.1974	.3239	.2503	.3240	.1001	.2128	.2015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 201 / 11 KV NARWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0543	.0549	.0549	.0549	.0543	.0732
2	.0543	.0543	.0549	.0549	.0549	.0543	.0549
3	.0543	.0549	.0549	.0549	.0549	.0549	.0549
4	.0543	.0732	.0549	.0549	.0732	.0543	.0549
5	.0724	.0732	.0732	.0732	.0732	.0724	.0549
6	.0905	.0732	.0914	.0732	.0914	.0905	.0914
7	.1086	.0914	.1097	.0914	.1097	.0914	.1097
8	.1109	.1097	.1097	.0914	.0914	.0724	.1097
9	.0924	.0732	.0914	.0914	.0914	.0914	.0914
10	.0924	.0732	.0732	.0914	.0914	.0914	.0914
11	.0732	.0732	.0549	.0732	.0732	.0914	.0732
12	.0732	.0732	.0549	.0732	.0549	.0732	.0732
13	.0549	.0732	.0549	.0732	.0549		.0732
14	.0549	.0549	.0549	.0732	.0549		.0732
15	.0549	.0549	.0549	.0732	.0549		.0549
16	.0549	.0549	.0732	.0914	.0732		.0732
17	.0914	.0914	.0732	.1097	.0914		.0914
18	.1629	.1097	.128	.128	.1267	.2012	.1267
19	.181	.1646	.1829	.1829	.1646	.2012	.1267
20	.181	.1646	.1646	.1646	.1463	.1829	.1448
21	.1448	.1463	.1463	.1646	.128	.1463	.1267
22	.0905	.0914	.0914	.0914	.0914	.1097	.0905
23	.0543	.0549	.0732	.0549	.0543	.0914	.0543
24	.0543	.0543	.0549	.0549	.0549	.0549	.0732
Max	.181	.1646	.1829	.1829	.1646	.2012	.1448
Min	.0543	.0543	.0549	.0549	.0543	.0543	.0543
Avg	.0879	.0830	.0846	.0892	.0838	.0989	.0851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 202 / 11 KV GAYRANWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.056	.4586	.5376	.4801	.0762	.0754
2	.0566	.0566	.4641	.5921	.4801	.0762	.056
3	.056	.0566	.4372	.6241	.5218	.0762	.0566
4	.0566	.0572	.4481	.6642	.5218	.0762	.056
5	.0754	.0572	.6081	.6958	.5693	.0953	.0754
6	.0934	.056	.8421	.7362	.6009	.0953	.1132
7	.0934	.0934	1.2003	1.012	.7432	.1143	.112
8	.0934	.0747	1.3441	1.2967	.9014	.1307	.1132
9	.1132	.112	1.3599	1.3923	1.1702	.132	.1494
10	.9282	.112	.056	.0754	1.2809	.5535	.6327
11	1.2955	.0747	.0762	.0754	1.2334	1.2176	1.1883
12	1.5708	.0754	.0762	.0566	1.2018	1.3923	1.2037
13	1.4737	.0566	.0762	.0754	1.1544	1.2334	1.1561
14	1.4403	.056	.0762	.0754	1.1405	.9488	1.1248
15	1.4403	.0747	.0762	.0754	1.1405	.9998	1.1385
16	1.3763	.0754	.0943	.0934	1.1873	1.186	1.1544
17	1.1203		.0953	.112	1.0311	1.1385	.8381
18	.056	.0747	.0762	.112	.0566	.0754	.0754
19	.112	.112	.132	.112	.0943	.1307	.0943
20	.0934	.1132	.132	.1132	.1132	.132	.0943
21	.0934	.112	.112	.1132	.0943	.1307	.0943
22	.0747	.0943	.0943	.0754	.0754	.1132	.0754
23	.056	.0747	.0754	.0566	.0762	.0934	.0566
24	.0747	.056	.427	.506	.4481	.0762	.0747
Max	1.5708	.1132	1.3599	1.3923	1.2809	1.3923	1.2037
Min	.056	.056	.056	.0566	.0566	.0754	.056
Avg	.4966	.0775	.3683	.3866	.6799	.4289	.4087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 203 / 11 KV BHAVANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.0625	.5851	.5937	.463	.0463	.061
2	.0617	.0625	.578	.6249	.4475	.0463	.061
3	.0617	.0625	.5624	.6249	.4687	.0457	.061
4	.0617	.0625	.5624	.6562	.4938	.061	.061
5	.0772	.0781	.6249	.6944	.4938	.0772	.0762
6	.0924	.0781	.7343	.679	.5468	.0926	.1067
7	.1294	.0937	1.078	.9259	.6944	.108	.1067
8	.1109	.1094	1.2342	1.1728	.7562		.1067
9	.1109	.1094	1.2342	1.2037	.9568	.0914	.1067
10	.9492	.0937	.0625	.0926	1.0185	.6097	.6097
11	1.3466	.0937	.0625	.0772	1.0648	1.2193	1.1736
12	1.5223	.0949	.0625	.0772	.9755	1.2651	1.1279
13	1.2643	.0949	.0781	.0617	.9602	1.1126	1.0364
14	1.186	.0949	.0781	.0617	.945	1.0669	.9297
15	1.2651	.0949	.0781	.0617	.945	1.0212	.7926
16	1.3599	.1107	.0781	.0617	1.0212	1.0974	.945
17	1.0279	.1107	.0781	.0772	.8535	1.1584	.7316
18	.0781	.1107	.1094	.1235	.061	.061	.0914
19	.0937	.1107	.1406	.1235	.1219	.1372	.1067
20	.0937	.1107	.1406	.108	.1067	.1372	.1067
21	.1094	.1107	.125	.108	.0914	.1219	.0914
22	.0937	.0949	.1094	.0926	.061	.0914	.0762
23	.0781	.0791	.0781	.0772	.0457	.0762	.061
24	.0617	.0625	.5535	.5468	.4321	.0463	.061
Max	1.5223	.1107	1.2342	1.2037	1.0648	1.2651	1.1736
Min	.0617	.0625	.0625	.0617	.0457	.0457	.061
Avg	.4707	.0911	.3762	.3719	.5844	.4257	.3620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 201 / 11 KV Anjani AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0469		.3963	.25	.061	.0309	.061
2	.0457		.4321	.25	.064	.048	.061
3	.064		.4374	.253	.0633	.048	.061
4	.0949		.4475	.2846	.0972	.0791	.0937
5	.128		.463	.3479	.128	.1094	.128
6	.1619		.4725	.4001	.1638	.1475	.1638
7	.1943	.6483	.6249	.6062	.1966	.1638	.1966
8	.176	.9374	.9145	.7522	.176	.1457	.1781
9	.128	.8951	1.2803	.8065	.125	.1457	.1473
10	.9962	.0926	.104	.0937	.8697	.8697	.7499
11	1.4083	.1094	.0949	.1094	1.2651	1.3763	1.1702
12	1.5655	.0937	.0937	.0937	1.2963	1.2334	1.2483
13	1.5339	.0903	.0903	.0914	1.2809	1.2029	1.1561
14	1.4198	.108	.0772	.0772	1.2346	1.2498	1.2492
15	1.5497	.0762	.0762	.0926	1.2498	1.2498	1.186
16	1.3435	.0937	.0926	.1107	1.2963	1.1405	1.2498
17	1.1288	.0903	.0937	.1107	1.2651	1.142	1.1728
18	.0533	.0869	.0617	.1094	.0762	.0724	.1219
19	.0937	.0914	.064	.128	.112	.1296	.1311
20	.112	.1107	.0819	.144	.1296	.112	.1134
21	.1107	.0926	.0819	.112	.112	.0972	.112
22	.0791	.0926	.08	.0937	.0949	.0949	.0781
23	.0625	.0781	.0648	.0772	.0791	.0781	.0781
24	.0625		.3593	.25	.0791	.0633	.0655
Max	1.5655	.9374	1.2803	.8065	1.2963	1.3763	1.2498
Min	.0457	.0762	.0617	.0772	.061	.0309	.061
Avg	.5233	.2228	.2910	.2352	.4798	.4596	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 202 / 11 KV Bastavade Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2163	.132	.132	.1478	.68	.6081	.7045
2	1.2163	.132	.132	.1478	.7202	.6154	.7373
3	1.2955	.132	.132	.1463	.7287	.7602	.7373
4	1.3763	.1886	.1888	.1829	.7682	.7202	.7865
5	1.4251	.2241	.2263	.1829	.8421	1.0208	.852
6	1.4403	.2614	.2641	.2534	.9602	1.182	.9831
7	1.8244	.3174	.3206	.3224	1.3279	1.4083	1.3435
8	.8855	.3142	.3206	.3772	1.6644	1.9528	1.9595
9	.9374	.2218	.2801	.2427	1.7764	2.0934	2.1052
10	.1109	1.0159	1.1317	1.1043	.1478	.1867	.1463
11	.0924	2.0405	2.1628	1.9433	.1848	.1867	.1463
12	.1294	2.2834	2.3685	1.9685	.1848	.168	.1448
13	.1663	2.2405	2.0081	1.9845	.1848	.1867	.1463
14	.1478	2.1925	2.0485	2.1376	.1848	.1494	.1478
15	.1478	2.3644	2.332	1.7924	.1494	.1494	.1478
16	.1663	2.2405	2.3685	2.2024	.1494	.168	.1646
17	.2218	2.1376	2.2672	2.0805	.1867	.1867	.2149
18	.2427	.1867	.1433	.1214	.1867	.2033	.2172
19	.2987	.2241	.1791	.2987	.2614	.2829	.2865
20	.2614	.2801	.2534	.2614	.2641	.3018	.2534
21	.2452	.3921	.2195	.2263	.2452	.2641	.2561
22	.2263	.2263	.1848	.2054	.1509	.1886	.2195
23	.1698	.1494	.168	.1494	.0943	.168	.1448
24	1.1873	.1509	.132	.1494	.5601	.5601	.6154
Max	1.8244	2.3644	2.3685	2.2024	1.7764	2.0934	2.1052
Min	.0924	.132	.132	.1214	.0943	.1494	.1448
Avg	.6430	.8354	.8318	.7762	.5251	.5713	.5609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 203 / 11 KV Dongarsoni AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5425	.2829	.2829	.2195	2.0553	1.8404	2.079
2	2.5888	.2641	.2641	.2218	2.146	1.9044	2.0972
3	2.6825	.2641	.2641	.2172	2.0972	2.0005	2.0972
4	2.8502	.3292	.3395	.2896	2.1862	2.1605	2.1862
5	3.1161	.5228	.5281	.5014	2.4531	2.4806	2.3967
6	3.3234	.7207	.7356	.5973	2.6993	2.8016	2.6379
7	2.8166	.8501	.8676	.6556	2.5774	3.1468	2.4615
8	2.6852	.6653	.679	.6535	3.0011	3.1207	3.2226
9	2.2348	.4251	.6054	.4668	2.3922	2.7686	2.8938
10	.2957	2.9797	1.9006	2.2377	.2587	.2987	.2572
11			2.9412	3.2693	.3326	.3174	.2804
12	.3881	1.5844	3.2007	1.3443	.2957	.2987	.3045
13	.3696	1.5497	2.3087	1.3916	.2587	.3361	.2715
14	.3142	1.6032	3.0247	1.2651	.2587	.3174	.2149
15	.2957	2.7018	1.5893	3.0996	.2957	.3206	.2126
16	.2772	2.8502	1.587	3.0996	.4066	.3326	.2686
17	.4435	2.8509	1.3283	2.9007	.4805	.499	.3721
18	.5359	.4024		.3658	.5544	.5426	.4835
19	.5914	.5601	.4915	.7095	.6161	.5847	.5853
20	.5228	.5601	.591	.6036	.5415	.4984	.5014
21	.4527	.5175	.5121	.5658	.4527	.4677	.4525
22	.3584	.3326	.3801	.4108	.3961	.3734	.3898
23	.3206	.2587	.3109		.3584	.321	.3045
24	2.5724	.3018	.2241	.2172	1.8023	1.7604	1.7652
Max	3.3234	2.9797	3.2007	3.2693	3.0011	3.1468	3.2226
Min	.2772	.2587	.2241	.2172	.2587	.2987	.2126
Avg	1.4164	1.0164	1.0851	1.1001	1.2049	1.2289	1.1973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 204 / 11 KV Jarandi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	.0949	.0972	.0791	.68	.4858	.6964
2	.7432	.096	.0983	.08	.7202	.5182	.7287
3	.8002	.096	.0972	.081	.7202	.5182	.7287
4	.8749	.1296	.1341	.112	.7449	.6478	.7449
5	1.0883	.1943	.1943	.1457	.7682	.7865	.7773
6	1.186	.2622	.2591	.2105	.8259	.8848	.8259
7	1.6164	.2949	.2915	.2721	1.2146	1.3599	1.2146
8	1.5154	.2458	.2429	.2949	1.2955	1.5708	1.6032
9	1.3123	.2429	.2429	.2591	1.2803	1.6876	1.6518
10	.16	1.2289	.8421	.9282	.1107	.113	.1107
11	.176	1.8351	1.6057	1.6032	.125	.1134	.1265
12	.16	1.6644	1.5844	1.6842	.1406	.16	.1265
13	.176	1.5061	1.6194	1.6194	.1107	.16	.128
14	.192	1.7814	1.4723	1.6356	.1265	.1619	.16
15	.208	1.6356	1.4089	1.587	.128	.192	.16
16	.2105	1.8785	1.3441	1.6194	.144	.208	.176
17	.2056	1.7814	1.3123	1.4883	.208	.208	.2056
18	.2241	.144	.1107	.1094	.2429	.2429	.2105
19	.2591	.2241	.1943	.2267	.2591	.2591	.2241
20	.2267	.2429	.2241	.2591	.2591	.2753	.2105
21	.1781	.144	.1107	.1781	.192	.2267	.1781
22	.144	.128	.1107	.128	.1296	.1619	.128
23	.1265	.1134	.112	.0949	.096	.1457	.08
24	.7343	.1107	.081	.0791	.3953	.4534	.5601
Max	1.6164	1.8785	1.6194	1.6842	1.2955	1.6876	1.6518
Min	.1265	.0949	.081	.0791	.096	.113	.08
Avg	.5529	.6698	.5746	.6156	.4549	.4809	.4898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 205 / 11 KV Savalaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2075	.2075	.2054	.2241	.2263	.2263
2	.2054	.1886	.1886	.2075	.2241	.2075	.2263
3	.2263	.1886	.1886	.2054	.2241	.2075	.2263
4	.3018	.2829	.2829	.2427	.2452	.2829	.2452
5	.3772	.3734	.3391	.2957	.3018	.3584	.3018
6	.5281	.4805	.4715	.439		.4481	.4715
7	.6224	.6653	.679	.5792	.5975	.6099	.6036
8	.5729	.5729	.5847	.5415	.5544	.5544	.5788
9	.4525	.4251	.3961	.4251	.4024	.4251	.4854
10	.3292	.3475	.3189	.3292	.3292	.2926	.3475
11	.3109	.3403	.2328	.2715	.3326	.2561	.2507
12	.2926	.2865	.2172	.2865	.2772	.2561	.2481
13	.2743	.2427	.2303	.2353	.2402	.2507	.2507
14	.2743	.2617	.2507	.2658	.1915	.2378	.2353
15		.2328	.2378	.2507	.2218	.2378	.2195
16	.2378	.2534	.2715	.2715	.2218	.2378	.2328
17	.2561	.2957	.2507	.3189	.3142	.2534	.2715
18	.3511	.3982	.3658	.3681	.3511	.543	.4298
19	.5788	.5792	.5249	.567	.6161	.5729	.5792
20	.5415	.6036	.5194	.5914	.6348	.5618	.5373
21	.4715	.4668	.439	.462	.5093	.5544	.4525
22	.3584	.3921	.3658	.3881	.3961	.4116	
23	.2452	.2452	.2587	.2614	.2641	.3547	.2561
24	.2054	.2263	.2075	.2054	.2241	.2452	.2614
Max	.6224	.6653	.679	.5914	.6348	.6099	.6036
Min	.2054	.1886	.1886	.2054	.1915	.2075	.2195
Avg	.3574	.3565	.3345	.3423	.3434	.3578	.3451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 207 / 11 KV Savlaj Water Supply NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0149	.0149	.016	.0293	.0152	.0149	.0152
2	.0152	.0149	.016	.0293	.0149	.0149	.0152
3	.0156	.0152	.016	.0297	.016	.0152	.016
4	.0152	.0156	.016	.0301	.0158	.0152	.0152
5	.0164	.0156	.016	.0293	.0156	.0156	.0162
6	.016	.0312	.016	.0579	.016	.0312	.0162
7	.0162	.0312	.032	.0587	.016	.0312	.0162
8	.0312	.032	.032	.0633	.032	.0625	.0152
9	.0316	.0156	.016	.0648	.032	.0305	.0152
10	.0156	.032	.016	.032	.016	.016	.0297
11	.0152	.016	.0312	.0328	.0156	.016	.0301
12	.0149	.016	.0301	.0328	.0152	.016	.0297
13	.0149	.016	.0297	.0324	.0149	.0152	.0149
14	.0149	.016	.0301	.0156	.0149	.0156	.0151
15	.0149	.016	.0305	.016	.0149	.0152	.0149
16	.0149	.016	.0301	.0164	.0149	.016	.0151
17	.0149	.016	.0301	.0324	.0149	.0152	.0297
18	.0149	.016	.0301	.0312	.0152	.0152	.0301
19	.0156	.016	.0297	.0309	.0149	.0152	.0297
20	.0156	.016	.0297	.0309	.0149	.0152	.0297
21	.0156	.016	.0147	.0301	.0145	.016	.0301
22	.0156	.016	.0149	.0297	.0145	.016	.0297
23	.0149	.016	.0151	.0301	.0149	.016	.0293
24	.0147	.0149	.0162	.0149	.0301	.0149	.0152
Max	.0316	.032	.032	.0648	.032	.0625	.0301
Min	.0147	.0149	.0147	.0149	.0145	.0149	.0149
Avg	.0166	.0184	.0231	.0334	.0172	.0194	.0214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 209 / 11 KV Savlaj Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	1.1523	1.166	.4534	.2241	.2263	.2241
2	.2054	1.1984	1.1984	.4534	.2241	.2075	.2427
3	.2241	1.1984	1.1984	.4588	.2614	.2075	.2614
4	.3018	1.2631	1.2631	.9069	.3018	.2829	.2987
5	.415	1.3603	1.3765	1.4403	.415	.3584	.4108
6	.5281	1.6004	1.6194	1.749	.547	.5228	.5415
7	.5847	1.9685	1.9919	2.4966	.5847	.5914	.5788
8	.5041	2.4966	2.4966	3.0996	.547	.462	.4904
9	.3547	2.7526		2.5724	.3547	.4066	.3921
10	2.4326	.2218	.2241	.2263	1.7604	1.9498	1.704
11	2.9058	.2804	.2149	.2614	2.7808	2.7854	2.2405
12	2.8487	.2218	.2172	.2427	.0579	2.7044	2.2672
13	2.9447	.2772	.2374	.2427	2.5465	2.672	2.1765
14	2.8647	.2218	.2401	.2241	2.6402	1.9757	2.0317
15	2.672	.1848	.1791	.2427	2.609	2.4006	2.0081
16	2.9214	.2241	.2926	.2772	2.8433	2.4905	2.2405
17	2.5446	.2614		.3696	2.7846	2.5797	2.2771
18	.1867	.3734	.3658	.3077	.2241	.2241	.2149
19	.5041	.4338	.4298	.4854	.4108	.4527	.439
20	.4527	.4251	.4344	.4481	.4338	.4527	.4344
21	.3961	.3772	.4024	.3734	.3584	.415	.4024
22	.3584	.3584	.362	.2801	.3206	.3395	.2896
23	.2641	.2641	.2561	.2587	.2641	.3018	.2534
24	.2054	1.1203	1.2793	.4588	.2241	.2452	.2641
Max	2.9447	2.7526	2.4966	3.0996	2.8433	2.7854	2.2771
Min	.1867	.1848	.1791	.2241	.0579	.2075	.2149
Avg	1.1594	.8432	.7930	.7637	.9883	1.0523	.9452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 201 / 11 KV Manerajuri Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6164	1.1385	.3258	.2774	.2926	1.1469	1.2191
2	1.704	1.2163	.3292	.2534	.2865	1.2742	1.3283
3	1.7236	1.2631	.3258	.2835	.3109	1.3108	1.3435
4	1.8056	1.3108	.3395	.3121	.3326	1.4419	1.5384
5	1.9372	1.3599	.4525	.3761	.3658	1.5238	1.6248
6	2.4646	1.6872	.5316	.5959	.6516	1.5851	1.8884
7	2.5775	1.8404	.7602	.691	.7343	2.0525	1.9599
8	2.3594	2.0241	.7202	.6588	.6516	2.3472	2.1925
9	2.2186	2.1376	.5316	.631	.5853	2.2405	2.2455
10		2.2085	1.6461	1.4232	.5611	.5144	.5487
11	.3292	2.0881	2.1628	1.5203	.4024	.4908	
12	.3582	2.0988	2.1765	1.6091	.3475	.4477	
13	.3801	2.1795	2.1214	1.7444	.3292	.3721	.3982
14		1.6975	2.1382	1.9109	.3292	.3258	.439
15		1.8519	2.0972	2.0241	.3658	.3467	.4251
16		2.1136	2.0062	2.1285	.439	.394	.4715
17		1.8023	1.7236	1.9292	.5014	.4706	.4835
18		.6783	.3439	.3258	.5611	.5316	.5304
19		.6401	.394	.3292	.6468	.4854	.5228
20		.5144	.4252	.3224	.543	.4557	.4904
21		.4755	.4854	.3077	.5068	.4344	.4887
22		.439	.4344	.3109	.4572	.443	.4251
23		.4024	.3403	.3045	.3734	.3641	.3292
24	1.4661	1.0883	.362	.2804	.3077	1.1736	1.1203
Max	2.5775	2.2085	2.1765	2.1285	.7343	2.3472	2.2455
Min	.3292	.4024	.3258	.2534	.2865	.3258	.3292
Avg	1.6108	1.4273	.9656	.8562	.4535	.9239	1.0006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 202 / 11 KV Yogewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2658	.197	.9172	.787	.7362	.181	.181
2	.2629	.1772	.9835	.9069	.7748	.1829	.1595
3	.2947	.181	.9831	.9962	.8097	.1829	.1907
4	.3258	.2149	1.0395	1.2342	.7811	.181	.2328
5	.3224	.2835	1.094	1.3283	1.0883	.2353	.298
6	.3814	.439	1.1904	1.4043	1.186	.3012	.3801
7	.4557	.5068	1.6385	1.5466	1.3443	.3772	.4334
8	.4252	.4298	1.8023	1.6049	1.406	.3814	.4298
9	.394	.362	1.6385	1.7394	1.4883	.3292	.4031
10	.8333	.3224	.5533	.1949	1.587	.9061	.9393
11	1.0437	.3109	.4161	.2149	1.4746	1.3443	1.4737
12	1.2483	.3547	.3801	.2353	1.4255	1.3889	1.5729
13	1.3904	.3142	.333	.2378	1.3916	1.3763	1.3272
14		.2987	.3045	.2149	1.3927	1.2342	1.2492
15		.2926	.2835	.1991	1.4419	1.3283	1.2955
16		.2378	.2507	.197	1.4419	1.4403	1.2654
17		.2614	.2686	.2715	1.3108	1.25	1.3603
18		.2427	.2896	.3109	.3772	.2031	.1543
19		.2743	.3121	.2896	.3326	.1907	.2149
20		.3109	.3012	.2614	.2896	.2149	.2254
21		.3258	.3403	.2378	.2801	.2303	.2658
22		.2743	.3189	.2149	.2452	.2103	.2534
23		.2561	.298	.181	.2149	.181	.1928
24	.2427	.2172	.9259	.7202	.6964	.1991	.1387
Max	1.3904	.5068	1.8023	1.7394	1.587	1.4403	1.5729
Min	.2427	.1772	.2507	.181	.2149	.181	.1387
Avg	.5633	.2952	.7026	.6470	.9799	.5854	.6099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 203 / 11 KV Bhosalenagar Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197	.1254	.7865	.8333	.8539	.132	.156
2	.2279	.1086	.7956	.9442	.8745	.128	.197
3	.208	.1109	.8048	.9962	.852	.128	.1772
4	.2481	.1417	.8192	1.1012	.8642	.1629	.2279
5	.2328	.1791	.9221	1.1248	.9172	.1829	.2172
6	.2601	.2172	.9804	1.2163	.9686	.2172	.2328
7	.2896	.2561	1.3077	1.2191	1.0562	.2926	.2427
8	.2835	.3045	1.5089	1.4563	.9804	.2926	.3012
9	.2947	.3439	1.6716	1.4969		.3109	.3439
10	.6874	.3012	.4694	.2126		1.0974	1.0688
11	.9282	.2743	.2328	.2149	1.1469	1.2963	1.3441
12	1.3279	.2926	.2427	.2303	1.1683	1.3283	1.4746
13	1.4232	.2715	.2126	.2353	1.2125	1.2654	1.3123
14		.2328	.2279	.2328	1.1401	1.2498	1.1385
15		.2378	.197	.2561	1.2936	1.2483	1.1305
16		.2743	.2254	.2507	1.2986	1.2452	1.0957
17		.3077	.3189	.2743	.9945	1.2186	1.1544
18		.362	.3506	.3045	.3658	.216	.1718
19		.4024	.3224	.2896	.2772	.2303	.1791
20		.3439	.2896	.2561	.2402	.1907	.1907
21		.2378	.2481	.2218	.1848	.2149	.2303
22		.2012	.2254	.2218	.1646	.1991	.181
23		.1791	.2149	.1991	.1494	.1753	.156
24	.1907	.1267	.8002	.7968	.8162	.1494	.1595
Max	1.4232	.4024	1.6716	1.4969	1.2986	1.3283	1.4746
Min	.1907	.1086	.197	.1991	.1494	.128	.156
Avg	.4857	.2430	.5906	.6077	.8100	.5488	.5451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 204 / 11 KV Manerajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1097	.1433	.132	.1086	.2195	.1294
2	.1109	.1132	.1433	.1629	.1294	.1829	.1509
3	.1509	.1307	.1448	.1494	.1307	.1448	.1086
4	.1448		.1448	.1663	.1509	.1463	.128
5	.1663	.1478	.1463	.1829	.1646	.1463	.1698
6	.1886	.1829	.1463	.1991	.1848	.1463	.181
7	.1829	.2075	.181	.1848	.1867	.1848	.1867
8	.2054	.2772	.2172	.2075	.2172	.2195	.2033
9	.2263	.3292	.3292	.2195	.2987	.1829	.2195
10	.1478	.2926	.3292	.2172	.2587	.2896	.2715
11	.1646	.3292	.2926	.2378	.2427	.2452	.1829
12	.1867	.3658	.2241	.2218	.2378	.181	.2033
13	.1886	.2743	.1848	.2241	.2402	.2195	.1886
14		.1848	.1646	.1991	.1478	.2641	.1463
15		.1829	.1509	.1886	.1848	.2402	.1448
16		.3696	.1448	.2012	.1829	.2263	.1663
17		.362	.1663	.2715	.362	.2427	.1867
18		.362	.1646	.3395	.4656	.2195	.2195
19		.3898	.181	.2743	.5914	.2641	.2452
20		.4252	.2033	.2172	.5487	.2402	.2715
21		.3544	.2263	.1886	.5175	.362	.2587
22		.3658	.1829	.168	.3326	.4108	.2012
23		.3258	.1494	.1463	.2926	.128	
24	.0934	.1132	.1829	.1109	.1132	.2561	.0943
Max	.2263	.4252	.3292	.3395	.5914	.4108	.2715
Min	.0934	.1097	.1433	.1109	.1086	.128	.0943
Avg	.1619	.2694	.1893	.2004	.2621	.2234	.1851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 205 / 11 KV AG LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0358	.0183		.0358	
2	.0358	.0362	.0362	.0354	.0362	.0347
3	.0347	.037	.0366	.0362	.0366	.0358
4	.0354	.0549	.0362	.0358	.0358	.0354
5	.0362	.0537	.0377	.0549	.0532	.0351
6	.0366	.0549	.0377	.0709	.0537	.0537
7	.0354	.0543	.037	.0716	.0543	.0532
8	.0358	.0549	.0366	.0709	.0549	.0537
9	.0358	.0554	.0366	.0905	.0537	.0526
10	.0366	.0549	.0183	.0537	.0543	.0362
11	.037	.0366	.0366	.0549	.0549	.0366
12	.0366	.0366	.0537	.0537	.0537	.0362
13	.0362	.037	.0362	.0543	.0549	.0358
14		.0366	.0537	.0549	.0554	.0549
15		.0366	.0549	.0537	.0549	.0532
16		.0366	.0537	.0543	.0549	.0549
Max	.037	.0554	.0549	.0905	.0554	.0549
Min	.0347	.0358	.0183	.0354	.0358	.0347
Avg	.0360	.0445	.0388	.0564	.0498	.0441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 206 / 11 kv Yogewadi Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1132	.1187	.1463	.1097	.0914	.1509
2	.1478	.112	.1267	.1509	.1086	.0905	.1829
3	.168	.1267	.1267	.1867	.132	.0905	.1663
4	.181	.1478	.1267	.1991	.1494	.1086	
5	.2033	.1646	.1463	.2218	.1663	.1463	.2054
6	.2195	.2218	.2126	.2427	.1886	.2126	.2378
7	.2452	.2987	.2378	.2561	.2172		.2534
8	.4435	.415	.2353	.3584	.1886	.2218	.2263
9	.5304	.4572	.4024	.462	.1463	.4024	.1478
10	.5041	.415	.3721	.4755	.2241	.439	.132
11	.2172	.2743	.3582	.4251	.3109	.4904	.1097
12	.1698	.1109	.4024	.3921	.362	.5304	.1086
13	.1294	.0914	.4344	.3584	.3292	.4251	.128
14		.0914	.4338	.3292	.3142	.3258	.0943
15		.0914	.2241	.1629	.128	.3734	.1294
16		.1254	.3326	.132		.4024	.1494
17		.1294	.3658		.3696	.3696	.128
18		.1448	.3982	.1307	.4435	.3584	.1086
19		.181	.3475	.1509	.4481	.3077	.1294
20		.1772	.2614	.1646	.3658	.2743	.1463
21		.1772	.1829	.1629	.2772	.2218	.1509
22		.181	.1629	.1509	.1663	.1629	.1307
23		.1629	.1698	.1307	.1478	.1646	.1646
24	.1806	.128	.128	.1294	.1294	.1109	.1307
Max	.5304	.4572	.4344	.4755	.4481	.5304	.2534
Min	.1294	.0914	.1187	.1294	.1086	.0905	.0943
Avg	.2507	.1891	.2628	.2400	.2358	.2748	.1527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 201 / 11 KV WAIFALE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.1334	.0953	.1143	.0953	.0953
3	.0953	.0953	.1334	.0953	.1143	.0953	.0953
4	.0953	.0953	.1334	.0953	.0762	.0953	.0953
5	.1334	.1143	.1715	.1143	.1143	.1143	.1334
6	.1905	.1905	.1905	.1334	.1524	.1905	.1905
7	.1905	.2286	.2286	.1715	.2286	.2286	.2667
8	.1905	.2286	.2096	.1905	.1715	.2286	.1905
9	.1715	.1334	.0953	.1524	.1524	.1143	.1334
10	.1524	.1143	.1334	.1143	.0953	.1334	.0953
11	.1334	.1143	.0953	.1143		.0953	.0953
12	.1334	.0953	.0762	.1143	.0762	.0762	.0953
13	.1143	.0953	.0762	.0762		.0762	.0762
14	.1143	.0953	.0762	.0762		.0762	.0762
15	.0953	.0762	.0762	.1143		.0762	.0762
16	.0762	.0762	.0762	.0953		.0762	.0762
17	.0762	.0953	.0953	.1334		.0762	.0953
18	.1334	.1143	.1334	.1334		.1143	.1524
19	.1905	.2096	.1905	.1143		.1905	.1524
20	.1715	.1715	.1905	.1143		.2096	.1905
21	.1524	.1524	.1524	.1524		.1715	.1524
22	.1143	.1143	.1334	.1143	.1143	.1143	.1334
23	.0953	.0953	.1143	.0953	.0953	.1143	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.1905	.2286	.2286	.1905	.2286	.2286	.2667
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1294	.1246	.1294	.1167	.1211	.1231	.1231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 202 / 11 KV Waifale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.0762	.1905	.0953	.5556	.6697	.6668
2	.7011	.0762	.1905	.0953	.6173	.6697	.6401
3	.7011	.0762	.1905	.0953	.6859	.6697	.6401
4	.7011	.0762	.2667	.0953	.7316	.6697	.7133
5	.8764	.1334	.2667	.1905	.6859	1.0745	.679
6	1.1145	.2667	.3048	.3239	.9602	1.3847	1.4327
7	1.3413	.381	.381	.3048	1.3375	1.5432	1.4403
8	1.4918	.3239	.3048	.2858	1.1279	1.6461	1.6933
9	1.0898	.2096	.2286	.2096	1.2483	1.6118	1.5604
10	.1715	1.4861	1.0479	1.0669	.1524	.1334	.1334
11	.1334	1.7353	1.7101	1.286		.1143	.1143
12	.1143	1.701	1.7204	1.4737	.1143	.0953	.1143
13	.1143	1.6832	1.6385	1.6632		.1143	.1143
14	.1143	1.6651	1.4746	1.4918		.1143	.1143
15	.1143	1.7177	1.4419	1.6461		.1143	.1143
16	.1143	1.6832	1.442	1.358		.1334	.1143
17	.1524	1.6655	1.2003	1.4232		.1715	.1143
18	.1905	.1334	.1524	.1715		.1334	.1905
19	.2286	.3048	.2667	.1524		.2667	.2096
20	.1905	.2667	.2667	.1715		.2286	.2286
21	.1524	.1905	.2096	.1905		.1905	.2096
22	.1334	.1334	.0953	.1905	.1334	.1524	.1905
23	.0953	.1715	.0953	.1143	.0953	.1143	.1524
24	.7011	.0762	.1905	.0953	.6173	.6697	.6401
Max	1.4918	1.7353	1.7204	1.6632	1.3375	1.6461	1.6933
Min	.0953	.0762	.0953	.0953	.0953	.0953	.1143
Avg	.4766	.6764	.6365	.5913	.6474	.5286	.5092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 203 / 11 KV Biranwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	1.0679	1.1765	1.5432	.1905	.1715	.1905
2	.1334	1.0679	1.6118	1.5432	.1905	.1715	.1905
3	.1334	1.0679	1.6118		.1905	.1715	.1905
4	.1334	1.0679	1.9281	1.5089	.2286	.1715	.1905
5	.1905	1.2757	2.0576	1.6766	.2667	.2096	.2286
6	.4191	1.5775	2.0576	1.8442	.3429	.4763	.4191
7	.4572	2.0576	2.5316	2.6216	.5525	.5525	.5335
8	.4715	2.4478	2.9492	2.6882	.3429	.5144	.4954
9	.3048	2.4143	2.9492	2.7206	.3429	.3048	.362
10		.2286		.1886	1.989	1.5432	1.267
11	1.4022	.2286	.2667	.2096		2.7526	2.5095
12	2.431	.1905	.2667	.2096	2.7854	2.6707	2.4863
13	2.5484	.1715	.2667	.2477		2.6216	2.4577
14	2.4981	.1524	.2667	.2286		2.556	2.3758
15	2.5316	.1905	.2477	.2286		2.2969	2.343
16	2.5149	.1905	.2477	.2286		2.6707	2.3371
17	2.3137	.2477	.2667	.2858		2.5316	2.4577
18	.1715	.1905	.2667	.3239		.2286	.1524
19	.2667	.381	.2667	.3048		.3239	.3048
20	.3048	.3239	.2667	.3048		.2858	.3239
21		.1905	.3239	.3239		.2858	.3048
22	.2286	.2096	.2858	.3048	.2477	.2477	.2667
23	.1905	.2858	.3239	.2096	.1905	.2096	.1905
24	.1334	1.0679	1.1765	1.5432	.1905	.1715	.1905
Max	2.5484	2.4478	2.9492	2.7206	2.7854	2.7526	2.5095
Min	.1334	.1524	.2477	.1886	.1905	.1715	.1524
Avg	.9051	.7623	1.0266	.9256	.5751	1.0058	.9487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 204 / 11 KV Agrani agro express NON SHEDDABLE EXPRESS HV FEEDERS
 fdr Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.061	.04
2			.0591	.0553
3			.0553	.0514
4			.0514	.0381
5			.0553	.061
6			.0648	.0743
7			.0686	.0762
8			.0591	.0743
9			.0286	.0648
10			.04	.0533
11			.0419	.0533
12		.04	.0438	.0495
13			.04	.0495
14			.0229	.0495
15			.0152	.0286
16			.0381	.0248
17			.0171	.0286
18			.0343	.0305
19			.04	.0324
20			.0381	.0343
21			.0419	.0362
22		.0457	.0476	.0381
23		.0876	.04	.0838
24	.0953		.0591	
Max	.0953	.0876	.0686	.0838
Min	.0953	.04	.0152	.0248
Avg	.0953	.0578	.0443	.0490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 201 / 11 KV Savarde Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6923	.1867	.2241	.2263	.4877	.5121	.5182
2	.6687	.168	.2241	.2075	.4572	.4801	.5639
3	.6773	.1886	.2241	.2075	.4572	.4858	.5719
4	.6923	.2075	.2241	.2075	.5182	.5344	.5719
5	.7316	.2614	.2427	.2263	.5487	.5693	.5719
6	1.0279	.3206		.3018	.5944	.6718	.8065
7	1.6032	.3961	.3961	.4338	.8436	1.0648	1.1288
8	.5401	.3921	.4668	.4668	1.0623	1.4403	1.4373
9	.5851	.3921	.4481	.3921	1.1248	1.5043	1.4043
10	.2614	.8592	.7562	.6478	.2587	.2427	.2195
11	.3361	1.6964	1.5546	1.4403	.3511	.3734	.3326
12	.3734	1.5655	1.3765	1.4563	.2587	.3547	.2772
13	.3547	1.387	1.4529	1.4083	.2957	.3881	.2743
14	.3174	1.2967	1.3757	1.3603	.3142	.4066	.2926
15	.3881	1.3748	1.3272	1.4083	.3142	.4066	.3109
16	.4294	1.4373	1.3717	1.4563	.2926	.4435	.3292
17	.2614	1.3272	1.4198	1.4243	.4066	.4435	.4066
18	.4108	.2957	.1848	.2561	.5359	.3881	.4066
19	.3921	.3361	.4066	.3142	.4294	.3734	.3547
20	.3361	.3361	.3326	.2957	.3734	.3361	.3547
21	.3361	.2829	.2614	.2587	.2587	.3174	.3361
22	.2801	.2263	.2241	.2402	.2263	.2614	.2801
23	.2054	.2241	.2452	.2012	.1867	.2427	.2402
24	.7225	.1867	.2241	.2263	.463	.5376	.4531
Max	1.6032	1.6964	1.5546	1.4563	1.1248	1.5043	1.4373
Min	.2054	.168	.1848	.2012	.1867	.2427	.2195
Avg	.5260	.6394	.6506	.6277	.4608	.5324	.5185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 202 / 11 KV Khujgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573		.6405	.7011
2			.6249	.7188
3			.6562	.7573
4			.7186	.7716
5			.8025	.7716
6			1.0517	.9122
7			1.5684	1.3321
8			2.332	1.6766
9			1.9595	1.5954
10			.2195	.1886
11			.2218	.2195
12			1.0709	.2561
13			.1646	.2012
14		.0953	.1829	.2195
15		.1829	.1829	.2561
16		.1848	.2172	.2195
17		.2218	.2743	.3142
18		.2743	.2772	.2957
19		.3142	.3142	.3734
20		.2987	.2801	.3547
21		.2427	.2427	.3174
22		.2054	.2241	.2427
23		.168	.1867	.2054
24	.081		.7099	.6481
Max	.8573	.3142	2.332	1.6766
Min	.081	.0953	.1646	.1886
Avg	.4692	.2188	.6301	.5645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 207 / 11 KV Sawarde Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0572	.0572	.0572	.0762	.0943
2	.0572	.0953	.0572	.0572	.0572	.0762	.0754
3	.0572	.0762	.0572	.0572	.0762	.0762	.0943
4	.0572	.0953	.0572	.0572	.0953	.0953	.0754
5	.0762	.0953	.0762	.0762	.1334	.1143	.0943
6	.1334	.1524	.1524	.1143	.1715	.1524	.1698
7	.1905	.2286	.1905	.1905	.1715	.1905	.2427
8	.1334	.1715	.1334	.1715	.1334	.1524	.1848
9	.0953	.1143	.0953	.1143	.1143	.1143	.1097
10	.1143	.0953	.0762	.0953	.0953	.0762	.1052
11	.0953	.0762	.0762	.0953	.0953	.0716	.0549
12	.0953	.0762	.0762	.0762	.0953	.0693	.0732
13	.0953	.0572	.0572	.0762	.0953	.0549	.0732
14	.0762	.0762	.0572	.0762	.0953	.0543	.0549
15	.0953	.0762	.0572	.0762	.2286	.0709	.0549
16	.0953	.0762	.0953	.0953	.2286	.0716	.0914
17	.0953	.0762	.1143	.0953	.2286	.0716	.0732
18	.1143	.0953	.1334	.0953	.2286	.1448	.1307
19	.2286	.2477	.2858	.1905	.2286	.2561	.2172
20	.2667	.2667	.2667	.2667	.2667	.2715	.2241
21	.2286	.2096	.2096	.2096	.4668	.2241	.2054
22	.1524	.1334	.1715	.1524	.1715	.168	.1307
23	.0953	.0762	.1334	.0953	.1334	.1307	.0943
24	.0572	.0762	.0572	.0953	.0572	.1143	.0943
Max	.2667	.2667	.2858	.2667	.4668	.2715	.2427
Min	.0572	.0572	.0572	.0572	.0572	.0543	.0549
Avg	.1151	.1175	.1143	.1119	.1552	.1207	.1174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 201 / 11 kv Vadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.3113	.4001	.4161	.0754	.0762	.0754
2	.1132	.3113	.426	.4161	.0754	.0762	.0754
3	.1132	.2949	.4961	.426	.0943	.0762	.0754
4	.132	.3605	.5571	.4915	.132	.1143	.1132
5	.1698	.4588	.6562	.5636	.2263	.1509	.1509
6	.2641	.5735	.7287	.7293	.2829	.2263	
7	.3206	.7907	1.0562	1.1469	.3018	.3018	.3395
8	.2641	1.012	1.2803	1.2967	.2829	.2641	.2829
9	.2263	1.1702	1.3763	1.4685	.0943	.2452	.2263
10	.9488	.0943	.1097	.1509	.9998	.2932	.5639
11	1.3916	.1886	.1109	.1509	1.3748	.5376	1.2003
12	1.2334	.1494	.1509	.1509	1.406	.6081	.7537
13	1.4232	.1646	.1698	.1698	1.2498	1.1405	.9602
14	1.4403	.1663	.1698	.1698	1.2346	1.2498	1.1961
15	1.4403	.1829	.1886	.1509	1.1574	1.1728	1.2803
16	1.2289	.2054	.1886	.1663	1.1279	1.3279	.3506
17	.9831	.1886	.1886	.1494	.9907	1.2811	.3521
18	.1867	.1886	.2241	.132	.1663	.1509	.1132
19	.2263	.2054	.2075	.1509	.2054	.2427	.1494
20	.1886	.1848	.2075	.1886	.1886	.2075	.1698
21	.1509	.1494	.1698	.132	.1509	.1509	.132
22	.1132	.112	.1132	.0943	.1132	.132	.0943
23	.0943	.0943	.0943	.0943	.0943	.0943	.0943
24	.1132	.3277	.3768	.3795	.0754	.0953	.0754
Max	1.4403	1.1702	1.3763	1.4685	1.406	1.3279	1.2803
Min	.0943	.0943	.0943	.0943	.0754	.0762	.0754
Avg	.5366	.3286	.4020	.3911	.5042	.4257	.3837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 202 / 11KV Anjani Vadgaon

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1524	.1524	.1698	.1509	.1524	.1509
2	.1698	.1524	.1524	.1698	.1509	.1524	.1509
3	.1698	.1524	.1334	.1698	.1698	.1524	.1509
4	.2075	.2096	.1715	.2263	.2641	.1905	.1886
5	.3018	.3018	.3048	.3395	.3584	.2829	.3018
6	.4527	.4527	.4715	.4715	.4338	.415	.4715
7	.547	.5093	.415	.5847	.4904	.4904	.5658
8	.3921	.4668	.3584	.5041	.4527	.3921	.499
9	.2926	.3109	.2614	.3292	.2427	.2587	.3077
10	.2378	.2402	.1848	.2149	.1829	.197	.2279
11	.1663	.1478	.1494	.181	.1463	.1629	.2149
12	.1478	.1463	.1791	.1463	.1433	.1463	.1791
13	.1294	.1267	.1307	.1307	.1448	.1629	.1629
14	.1294	.1478	.1646	.1463	.1463	.1097	.1463
15	.1294	.168	.1829	.1448	.1463	.1629	.1478
16	.1433	.181	.1463	.1612	.1478	.1629	.1629
17	.1612	.1663	.1478	.1646	.1791	.181	.1867
18	.2587	.2328	.2033	.2353	.2957	.2378	.3045
19	.4066	.3841	.3921	.3696	.4108	.4294	.3841
20	.4527	.4344	.415	.4207	.4715	.4854	.4294
21	.3584	.3511	.3961	.3584	.3584	.3772	.3395
22	.2641	.2829	.3395	.2829	.2641	.2829	.2641
23	.2075	.2075	.2263	.2075	.1886	.2075	.2075
24	.1698	.1715	.1715	.1698	.1698	.1715	.1509
Max	.547	.5093	.4715	.5847	.4904	.4904	.5658
Min	.1294	.1267	.1307	.1307	.1433	.1097	.1463
Avg	.2527	.2540	.2438	.2624	.2546	.2485	.2623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 203 / 11 KV Gavan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9998	.0762	.0943	.0747	.5921	.6081	.8002
2	.9998	.0762	.0762	.0747	.6081	.5693	.8002
3	.9998	.0762	.0762	.0747	.6718	.6009	.8097
4	1.0753	.1143	.1143	.0943	.7362	.7042	.8745
5	1.1385	.1509	.1698	.1509	.8192	.8802	1.004
6	1.2967	.2075	.2075	.2075	.9122	1.2163	1.1984
7	1.5384	.2263	.2263	.2641	1.4419	1.5043	1.5684
8	1.8027		.2263	.2075	1.5364	1.9044	1.8884
9	1.5813		.1867	.1867	1.4548	1.9204	1.9524
10	.1097		1.2452	1.2967	.1109	.1294	.1132
11	.1097		2.1792	1.6644	.1478	.1494	.168
12	.128	2.4249	2.2119	2.0153	.1463	.1294	
13	.168	2.3365	2.0567	2.0165	.0914	.1494	.1494
14	.168	2.3158	1.9685	1.9595	.0914	.1132	.1698
15	.1663	2.3758	2.0729	1.9006	.0732	.1307	.1509
16	.1848	2.4249	2.0729	1.9204	.0924	.112	.1629
17	.2033	2.1214	1.8404	1.7204	.1267	.1494	.1509
18	.2054	.1372	.1109	.0934	.1663	.1867	.2012
19	.2075	.1791	.2075	.1294	.2054	.1867	.2218
20	.1886	.2012	.1509	.168	.1886	.1698	.2075
21	.1509	.1478	.1494	.132	.1509	.168	.1509
22	.1132	.112	.112	.0943	.1132	.1294	.1132
23	.0943	.1132	.0924	.0754	.0754	.0934	.0943
24	1.0311	.0953	.0943	.0739	.5571	.6401	.7682
Max	1.8027	2.4249	2.2119	2.0165	1.5364	1.9204	1.9524
Min	.0943	.0762	.0762	.0739	.0732	.0934	.0943
Avg	.6109	.7956	.7476	.6915	.4629	.5227	.5965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 201 / 11 KV DATTANAGAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.8002	.68	.7811	.0754	.0754	.0943
2	.0754	.8802	.6642	.7407	.0754	.0754	.0754
3	.0754	.9717	.6802	.7407	.0754	.0754	.0754
4	.0943	1.073	.7842	.7716	.0754	.0943	.0754
5	.132	1.2003	.8436	.8333	.0943	.1132	.132
6	.1698	1.283	.9842	.9842	.1698	.1886	.1886
7	.2641	1.2803	1.5339	1.2967	.2641	.2641	.2829
8	.2614	1.4232	1.6248	1.6091	.2263	.2641	.2829
9	.2172	1.3748	1.6248	1.5895	.1494	.1698	.168
10	.9332	1.0155	.0934	.0739	.8916	.743	.7674
11	1.5242	.112	.0934	.0943	1.4175	1.3272	1.2654
12	1.6049	.1307	.1109	.0747	1.656	1.4969	1.3889
13	1.6049	.1294	.112	.112	1.6358	1.5895	1.4661
14	1.6404	.1307	.0924	.1109	1.6821	1.5895	1.5154
15	1.6324	.112	.1109	.1109	1.6091	1.5895	1.4842
16	1.6964	.1307	.1097	.0876	1.5432	1.4998	1.4043
17	1.5623	.0934	.1267	.0914	1.4998	1.4998	1.4198
18	1.406	.112	.1478	.1097	.0724	.112	.0739
19	.1886	.2075	.1886	.168	.1698	.1848	.1867
20	.1886	.1698	.1698	.1698	.1698	.1698	.1509
21	.1886	.1509	.1698	.1509	.1509	.1698	.132
22	.1886	.132	.132	.132	.1132	.132	.0943
23	.1509	.0943	.0943	.0943	.0943	.112	.0943
24	.0754	.7202	.68	.7116	.0943	.0754	.0943
Max	1.6964	1.4232	1.6248	1.6091	1.6821	1.5895	1.5154
Min	.0754	.0934	.0924	.0739	.0724	.0754	.0739
Avg	.6646	.5720	.4938	.4850	.5836	.5671	.5380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 202 / 11 KV GOURGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.0354	.0554	.0709	.5418	.4652	.5401
2	.5858	.0488	.0554	.0709	.5213	.4652	.503
3	.5858	.0503	.0549	.0709	.5213	.4778	.4877
4	.6081	.096	.0732	.0716	.5213	.5068	.4816
5	.6081	.1006	.0914	.0716	.5357	.5213	.6097
6	.7042	.1402	.1109	.1109	.6001	.639	.7676
7	1.0837	.168	.1829	.1848	.8688	.9214	1.07
8	1.1443	.1867	.1612	.181	1.0212	1.2041	1.1591
9	.8833	.1294	.1387	.1433	.9482	1.189	1.2041
10	.0701	.0937	.6485	.6661	.0867	.0587	.0949
11	.064	1.2963	1.2654	1.2193	.0663	.0895	.0886
12	.064	1.4815	1.3696	1.3735	.0895	.1029	.0693
13	.0579	1.5741	1.4784	1.3094	.1433	.1174	.064
14	.061	1.6204	1.4632	1.3565	.1448	.0829	.0671
15	.061	1.5895	1.448	1.3546	.1052	.0829	.0693
16	.0857	1.5123	1.3847	1.46	.1075	.0867	.0857
17	.1029	1.4449	1.3847	1.3094	.1478	.0857	.0857
18	.1094	.0867		.08	.1294	.124	.1227
19	.1848	.1646	.1463	.1829	.1494	.1629	.1448
20	.128	.128		.1848	.1307	.128	.1448
21	.128	.1294	.1254	.1612	.1294	.1463	.1254
22	.128	.0886	.0905	.128	.1097	.1267	.0895
23	.0914	.0709	.0701	.1075	.0905	.0895	.0914
24	.6001	.0326	.056	.0732	.4666	.5182	.5401
Max	1.1443	1.6204	1.4784	1.46	1.0212	1.2041	1.2041
Min	.0579	.0326	.0549	.0709	.0663	.0587	.064
Avg	.3642	.5112	.5389	.4976	.3407	.3497	.3628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 203 / 11 KV MANJARDE VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0229	.0514	.0549	.0532	.0532	.0486	.0549
2	.0554	.0526	.037	.0532	.0543	.0509	.056
3	.0554	.052	.037	.0537	.0543	.0514	.0377
4	.0739	.0716	.0366	.0537	.0554	.052	.037
5	.0739	.1086	.0732	.0732	.0739	.052	.0747
6	.0924	.128	.1097	.0905	.112	.1097	.112
7	.1509	.1612	.1524	.132	.0934	.1509	.132
8	.132	.112	.112	.132	.1132	.1132	.132
9	.0739	.0943	.0747	.0943	.0754	.0747	.0943
10	.0566	.0747	.0543	.0549	.0358	.0362	.0566
11	.0358	.0532	.0554	.0343	.0543	.0543	.0366
12	.0358	.0343	.0452	.0354	.0554	.0343	.0572
13	.0347	.0554	.0358	.0566	.116	.0554	.0324
14	.029	.0305	.0328	.0328		.0343	.032
15	.0358	.056	.0351	.037		.0347	.0343
16	.0566	.0549	.0701	.0554	.0566	.0305	.0526
17	.0747	.0543	.0532	.052	.0305	.0543	.0566
18	.0747	.0537	.0543	.0943	.0739	.0739	.0754
19	.1715	.1334	.1509	.132	.1334	.132	.1524
20	.1509	.132	.1715	.132	.132	.1307	.1524
21	.1294	.1097	.1307	.112	.132	.1294	.132
22	.1109	.1109	.0914	.1132	.1109	.1109	.0914
23	.0934	.0709	.0754	.0732	.0716	.0724	.0537
24	.052	.0497	.0492	.0532	.0532	.0503	.0716
Max	.1715	.1612	.1715	.132	.1334	.1509	.1524
Min	.0229	.0305	.0328	.0328	.0305	.0305	.032
Avg	.0780	.0794	.0747	.0752	.0791	.0724	.0757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 201 / 11 KV Jarandi Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2987	.2829	.1509	.2772	.2614	.2241
2	.2241	.2801	.2641	.112	.2772	.2614	.1886
3	.1509	.2614	.2641	.132	.2587	.2614	.1509
4	.1132	.2614	.2641	.1698	.2772	.2614	.112
5	.1886	.2801	.2829	.2987	.2987	.2801	.132
6	.2926	.3734	.4108	.4755	.3547	.3547	.3881
7	.3841	.3921	.4294	.4294	.4481	.4294	.4572
8	.439	.4527	.4344	.3696	.3734	.3921	.4066
9	.3174	.3658	.3761	.3511	.2772	.3142	.3658
10	.3292	.3696	.3326	.2926	.1991	.2561	.2772
11	.2987	.2801	.3475	.2641	.2353	.1886	.2241
12	.3801	.2587	.2957	.2772	.2402	.1509	.2427
13	.394	.2865	.2614	.3109	.2012	.2195	.2012
14	.362	.3439	.3921	.2614	.2561	.2614	.1867
15	.3801	.3439	.3696	.3475	.3292	.3142	.2033
16	.3801	.3475	.3018	.2957	.2957	.1132	.2743
17	.3109	.3898	.4066	.3475	.3511	.1494	.3361
18	.4706	.3511	.439	.3761	.3658	.3326	.4066
19	.4668	.4435	.4706	.4572	.3921	.3658	.5121
20	.462	.4251	.4207	.3921	.4294	.462	.439
21	.3961	.4066	.3696	.4066	.4108	.4066	.3292
22	.3584	.2402	.3511	.3547	.3395	.3547	.2218
23	.3547	.2614	.2957	.3547	.3018	.3018	.168
24	.3658	.3361	.3018	.1886		.3174	.2641
Max	.4706	.4527	.4706	.4755	.4481	.462	.5121
Min	.1132	.2402	.2614	.112	.1991	.1132	.112
Avg	.3366	.3354	.3485	.3090	.3126	.2921	.2797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 202 / 11 KV Jarandi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.0754	.0754	.0754	.6562	.68	.6325
2	.7099	.0754	.0754	.0566	.6562	.6405	.7811
3	.5944	.0754	.0754	.0566	.6562	.6562	.7926
4	.7926	.0754	.0754	.0754	.6562	.6562	.8333
5	1.0155	.132	.132	.1132	.703	.6874	.9145
6	1.1069	.1886	.2075	.1478	.7907	.8697	1.2186
7	1.5203	.3018	.2641	.2772	.9922	1.1702	1.4403
8	1.406	.2452	.2075	.2263	1.186	1.3763	1.5708
9	1.0837	.1886	.1509	.1494	1.034	.9686	1.4083
10	.0739	.9217	.2743	.6249	.0732	.128	.128
11	.0543	1.5364	1.4723	1.3123	.0724	.0747	.0943
12	.0554	1.3916	1.4232	1.4403	.0934	.0934	.0934
13	.0732	1.3283	1.3123	1.4548	.0537	.1132	.0747
14	.0747	1.3279	1.3435	1.4074	.0724	.0934	.0754
15	.0943	1.4217	1.3757	1.439	.0914	.0754	.0934
16	.0934	1.5181	1.5684	1.4548	.0914	.112	.0747
17	.1109	1.595	1.2498	1.406	.1307	.1294	.1132
18	.132	.0924	.2218	.0554	.1463	.1494	.1494
19	.1886	.2075	.2561	.2075	.1886	.1848	.2195
20	.1886	.1886	.2075	.1886	.1886	.1698	.1886
21	.1509	.1698	.1698	.1509	.132	.1307	.1663
22	.132	.1132	.1307	.132	.1132	.1132	.1509
23	.1132	.0943	.0943	.0943	.0754	.0943	.132
24	.7827	.0754	.0754	.0754	.4877	.5441	.5601
Max	1.5203	1.595	1.5684	1.4548	1.186	1.3763	1.5708
Min	.0543	.0754	.0754	.0554	.0537	.0747	.0747
Avg	.4712	.5558	.5183	.5259	.3892	.4130	.4961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 203 / 11 KV Dahiwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.5079	.5121	.4321	.056	.056	.0566
2	.0754	.4801	.4801	.5937	.056	.056	.056
3	.0943	.4801	.4801	.7274	.056	.056	.0566
4	.1132	.4801	.4801	.8097	.056	.056	.0747
5	.1307	.5312	.5851	.7968	.1132	.1307	.1478
6	.1478	.5898	.7701	.8322	.2075	.2075	.1829
7	.2263	.8097	1.0202	.8583	.2641	.2641	.2402
8	.1867	1.1363	1.2643	1.1203	.2263	.2054	.2075
9	.1478	1.078	1.2643	1.1843	.1294	.1494	.1307
10	.6706	.0914	.0914	.1294	.6718	.4877	.5487
11	1.0911	.112	.0747	.112	1.2176	1.1683	.8855
12	1.1702	.0739	.1109	.0895	1.2029	1.3603	.9374
13	1.1092	.1063	.0943	.0886	1.1883	1.3283	1.0402
14	1.2029	.0895	.1294	.0701	1.2967	1.3763	.7811
15	1.1385	.0886	.1132	.0924	1.3283	1.2498	.9907
16	1.2803	.1109	.0943	.1097	1.2811	1.0669	1.0467
17	1.2041	.1086	.112	.0732	1.2967	.9686	.8993
18	.0886	.1254	.1494	.0914	.1029	.112	.1052
19	.1509	.1848	.1294	.1509	.1663	.1478	.1698
20	.132	.168	.1307	.1132	.132	.132	.1509
21	.112	.112	.1132	.1132	.1132	.112	.1307
22	.0934	.0924	.0934	.0754	.0943	.0943	.1132
23	.0747	.0747	.0754	.0566	.0754	.0747	.0934
24	.0537	.3521	.4801	.3353	.056	.0566	.0754
Max	1.2803	1.1363	1.2643	1.1843	1.3283	1.3763	1.0467
Min	.0537	.0739	.0747	.0566	.056	.056	.056
Avg	.4480	.3327	.3687	.3773	.4745	.4549	.3801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 201 / 11 KV KUMTHE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1524	.112	.1132	.1524	.1132	.1132
2	.0953	.1334	.1132	.112	.1334	.112	.112
3	.0953	.1334	.1132	.1132	.1334	.1132	.1132
4	.0953	.1715	.1132	.112	.1334	.1132	.112
5	.1524	.2096	.1494	.1509	.1715	.1494	.1509
6	.2286	.2477	.2402	.2263	.2286	.2241	.2614
7	.2858	.2858	.2987	.2987	.2477	.2987	.2987
8	.2477	.2286	.2829	.2452	.2096	.2801	.2587
9	.1715	.1715	.1886	.2218	.1905	.2033	.1867
10	.1715	.1334	.2096	.1905	.2096	.1524	.1524
11	.1524	.1524	.1227	.1715	.1334	.0953	.1524
12	.1524	.1143	.1086	.1334	.1334	.1143	.1143
13	.1334	.1372	.12	.1334	.1143	.1334	.1052
14	.1524	.12	.12	.1524	.1143	.1524	.1006
15	.1715	.1017	.1214	.1524	.0953		.124
16	.1715	.0857	.1214	.1524	.1334		.1372
17	.2033	.1387	.1372	.1524	.1143	.2263	.1402
18	.2149	.2075	.2075	.1905	.168		.1905
19	.2477	.3511	.2987	.2804	.2218	.3326	.2858
20	.2858	.3292	.2772	.3109	.3142	.3361	.3429
21	.2286	.2801	.2641	.2286	.2801	.3174	.2286
22	.1905	.2263	.2452	.1905	.2054	.2263	.1905
23	.1524	.168	.1698	.1524	.1886	.1494	.1524
24	.0953	.1524	.1132	.1132	.4572	.1494	.1307
Max	.2858	.3511	.2987	.3109	.4572	.3361	.3429
Min	.0953	.0857	.1086	.112	.0953	.0953	.1006
Avg	.1746	.1847	.177	.1791	.1868	.1901	.1731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 204 / 11 KV Kumthe Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5401	.442	.112	.132	.1334	.4687	.4858
2	.5535	.4167	.1132	.112	.1524	.4481	.4374
3	.5344	.421	.1109	.1132	.1524	.4115	.4111
4	.547	.4999	.112	.1132	.2286	.4531	.4115
5	.6464	.5556	.1494	.1494	.2286	.5535	.5155
6	.7865	.6249	.1886	.2075	.2858	.7499	.759
7	1.2967	.6483	.2614	.2614	.3048	1.2334	1.1584
8	1.4251	.9842	.2218	.2263	.2477	1.4883	1.5741
9	1.0753	1.1385	.2263	.2241	.2096	1.4784	1.5154
10	.1334	1.9814		1.8623	.1715	.1334	.1143
11	.1334	2.037	1.5813	1.8233	.1524	.1334	.1143
12	.1143	2.1125	2.1992	1.7236	.1715	.1524	.0953
13	.1143	2.0595	1.866	1.7966	.1524	.1524	.0953
14	.1143	1.7078	1.7711	1.768	.1905	.1143	.1143
15	.1715	1.8724	1.7924	1.866	.1715		.1143
16	.1905	1.8982	1.866	1.8122	.1334		.1334
17	.1905	1.6716	1.6804	1.1265	.1905	.132	.1715
18	.2096	.1132	.1886	.2477	.1886		.1715
19	.2286	.1867	.2801	.2286	.2241	.2402	.2096
20	.2286	.1848	.2587	.2286	.2801	.2452	.2096
21	.1905	.1663	.2427	.1905	.2452	.2427	.1905
22	.1905	.1646	.2402	.1715	.1867	.2218	.1524
23	.1524	.1307	.1886	.1334	.1698	.1867	.1524
24	.5639	.4687	.1132	.1494	.1334	.5121	.4999
Max	1.4251	2.1125	2.1992	1.866	.3048	1.4883	1.5741
Min	.1143	.1132	.1109	.112	.1334	.1143	.0953
Avg	.4305	.9369	.6854	.6945	.1960	.4644	.4086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 206 / 11 KV Upalavi Matkunki Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.1132	.6401	.5624	.4115	.0943	.0934
2	.0754	.0943	.5992	.5601	.506	.0934	.0943
3	.0754	.0943	.5535	.5218	.5668	.0943	.0943
4	.0754	.1509	.6154	.5535	.6093	.0934	.0934
5	.0943	.1698		.6405	.6636	.132	.1307
6	.132	.2075	.9922	.8886	.7316	.1886	.2075
7	.2263	.2263	1.5089	1.3125	.933	.2427	.2641
8	.2075	.1867	1.7071	1.5546	1.1126	.2452	.2641
9	.1509	.1867	1.6667	1.7124	1.2963	.1867	.1867
10	1.0669	.0924	.0857	.1595	1.4685	.8025	.9602
11	1.6129	.1109	.1109	.1448	1.4998	1.3426	1.1227
12	1.7901	.1097	.1075	.1478	1.4198	1.2929	1.3546
13	1.7124	.1097	.1267	.1463	1.4198	1.2323	1.4373
14	1.7029	.1097	.1448	.1448	1.4175	1.2186	1.3413
15	1.6604	.1267	.1448	.1417	1.3998		1.3117
16	1.4175	.1433	.1267	.1494	1.423		1.3123
17	1.2186	.1848	.1829	.1494	1.3696	.9389	1.1431
18	1.0031	.1848	.1867	.1698	.1132		.1029
19	.1543	.1829	.2218	.1698	.1307	.2054	.1086
20	.1578	.1848	.1867	.1698	.1867	.1509	.1509
21	.1478	.1867	.1698	.1509	.1307	.132	.1509
22	.1478	.1509	.1307	.1509	.112	.1307	.0934
23	.1132	.132	.132	.1132	.112	.1132	.0934
24	.0754	.1132	.703	.6249	.3549	.0943	.0943
Max	1.7901	.2263	1.7071	1.7124	1.4998	1.3426	1.4373
Min	.0754	.0924	.0857	.1132	.112	.0934	.0934
Avg	.6289	.1480	.4802	.4600	.8079	.4298	.5086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 207 / Nagaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2126	.1886	.1867	.2263	.1698	.2054
2	.1663	.1928	.1848	.1886	.2075	.168	.1848
3	.1663	.1991	.1867	.1886	.2075	.1698	.1867
4	.168	.2195	.1848	.1867	.1886	.168	.1886
5	.1867	.2328	.2241	.2452	.1886	.1886	.2241
6	.2772	.2896	.3696	.3206	.2452	.3018	.3511
7	.3326	.3511	.4108	.3696	.3206	.3174	.3547
8	.3142	.3258	.3696	.3326	.3018	.2957	.3142
9	.2772	.3109	.3658	.3018	.2587	.2241	.2987
10	.2743	.2715	.2715	.2715	.2172	.1991	.2686
11	.2303	.3077	.2534	.2454	.1991	.181	.3012
12	.2218	.2534	.2534	.2686	.1991	.1267	.2601
13	.2534	.2534	.2353	.2402	.1991	.1629	.2229
14	.2401	.2534	.2172	.2534	.1991	.1646	.2103
15	.2658	.2534	.2172	.2804	.1991		.2572
16	.3142	.2715	.2172	.2658	.2172		.2835
17	.3224	.2353	.2715	.298	.2172	.2896	.2947
18	.3258	.3174	.3361	.3439	.3326		.3544
19	.3921	.4251	.462	.4668	.3772	.462	.4251
20	.462	.439	.4294	.4251	.4108	.4668	.5121
21	.4784	.4251	.3881	.3696	.3696	.4066	.4338
22	.362	.3361	.3395	.2987	.2801	.3361	.3772
23	.2801	.2829	.2614	.2263	.2054	.2427	.2452
24	.2012	.2402	.2241	.2075	.2263	.1886	.2241
Max	.4784	.439	.462	.4668	.4108	.4668	.5121
Min	.1663	.1928	.1848	.1867	.1886	.1267	.1848
Avg	.2790	.2875	.2859	.2826	.2497	.2490	.2908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 208 / Nagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2201	.0514	.0377	.0377	.0514	.4321	.5121
2	.2107	.0532	.0381	.0373	.0354	.3906	.4572
3	.216	.0347	.0381	.0377	.0362	.3479	.4428
4	.2107	.0358	.0381	.0373	.0701	.3479	.463
5	.2559	.0701	.0566	.0566	.0739	.381	.4877
6	.3161	.0686	.0934	.0754	.0895	.4999	.5937
7	.3763	.0693	.0924	.0934	.0934	.7748	.7748
8	.3081	.4999	.0934	.0754	.0886	.9842	.9686
9	.2787	.5719	.0754	.0739	.0876	.945	1.0279
10	.1214	.4904	.5761	.8905	.0739	.0463	.0474
11	.0886	.8278	1.1248	1.0202	.0709	.0739	.0457
12	.0554	.3612	1.174	1.0385	.0886	.0648	.0594
13	.0543	1.0517	1.2651	1.1265	.0886	.0625	.0663
14	.0526	1.1431	1.1589	1.1069	.0857	.0625	.0686
15	.0543	1.1431	1.1288	1.1984	.081		.0701
16	.0739	1.2041	1.174	1.1431	.0848		.0739
17	.0709	1.0822	1.1591	.6944	.0829	.0474	.0732
18	.0857	.0754	.0747	.0686	.0934		.0686
19	.0857	.1109	.0754	.0701	.0943	.0943	.0526
20	.0867	.0747	.0747	.0693	.0943	.0754	.0514
21	.0867	.0754	.0747	.0686	.0747	.0747	.0469
22	.0762	.0747	.0754	.052	.0754	.0566	.0457
23	.0724	.0747	.0754	.0492	.0566	.056	.0434
24	.2172	.3704	.0566	.056	.0503	.4801	.4531
Max	.3763	1.2041	1.2651	1.1984	.0943	.9842	1.0279
Min	.0526	.0347	.0377	.0373	.0354	.0463	.0434
Avg	.1531	.4006	.4096	.3824	.0759	.2999	.2914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 201 / 11 KV PED AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.132		
2					.132		
3					.1509		
4					.1698		
5					.1886		
6					.2452		
7					.3395		
8					.3018		
9					.1886		
10					.168		
11				2.7526	.1494		
12					.1132		
13					.1132		
23	.1509	.1509		.1543	.1509	.1886	.1372
24	2.2939	1.3603	.132		.1372	1.2955	1.278
Max	2.2939	1.3603	.132	2.7526	.3395	1.2955	1.278
Min	.1509	.1509	.132	.1543	.1132	.1886	.1372
Avg	1.2224	.7556	.132	1.4535	.1787	.7421	.7076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 202 / 11 KV HATNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.9709		
2					1.0082		
3					1.0456		
4					1.1203		
5					1.1576		
6					1.2323		
7					1.0402		
8					.9511		
9					1.0402		
10					.1509		
11				.0857	1.2498		
12					1.5364		
13					1.6004		
23	.0943	.1132		.1372	.0943	.0943	.1029
24	.1132	.0754	.7682		.743	.0943	.0857
Max	.1132	.1132	.7682	.1372	1.6004	.0943	.1029
Min	.0943	.0754	.7682	.0857	.0943	.0943	.0857
Avg	.1038	.0943	.7682	.1115	.9961	.0943	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 204 / 11KV HATNUR GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.132		.1307		
2					.1494		
3					.168		
4					.1867		
5					.2241		
6					.2614		
7					.3547		
8					.2427		
9					.1867		
10					.1494		
11				.168	.1357		
12					.1214		
13					.124		
23	.2452	.1448		.168	.1646	.1612	.1772
24	.4508	.1698	.132		.1494	.1509	.1509
Max	.4508	.1698	.132	.168	.3547	.1612	.1772
Min	.2452	.1448	.132	.168	.1214	.1509	.1509
Avg	.348	.1573	.132	.168	.1833	.1561	.1641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 206 / 11 KV PED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0377		
2				.0377		
3				.0566		
4				.0566		
5				.0566		
6				.0867		
7				.1886		
8				.1734		
9				.1734		
10				.1214		
11			.0754	.0543		
12				.0514		
13				.0526		
23	.0747	.0754	.0377	.0747	.0732	.0754
24	.0566	.0566		.0377	.0566	.0566
Max	.0747	.0754	.0754	.1886	.0732	.0754
Min	.0566	.0566	.0377	.0377	.0566	.0566
Avg	.0657	.066	.0566	.0840	.0649	.066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 208 / VIJAYNAGAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.1509		
3					.132		
4					.1509		
5					.1698		
6					.2452		
7					.3547		
8					.3961		
9					.2241		
11				.8907			
21					.1509		
23	.1509	.1698		.1715	.1886	.1886	.1543
24	1.1498	.663	.1509		.1372	.7125	.7449
Max	1.1498	.663	.1509	.8907	.3961	.7125	.7449
Min	.1509	.1698	.1509	.1715	.132	.1886	.1543
Avg	.6504	.4164	.1509	.5311	.2091	.4506	.4496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 209 / 11 KV HONAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11				.7373			
23	.0377	.0377		.0514	.0377	.0566	.0514
24	.4641	.3978	.0377		.0514	.4641	.463
Max	.4641	.3978	.0377	.7373	.0514	.4641	.463
Min	.0377	.0377	.0377	.0514	.0377	.0566	.0514
Avg	.2509	.2178	.0377	.3944	.0446	.2604	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV PANMALEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1132	1.2492	1.2146	1.1984	.1509	.1494
2	.132	.1132	1.2483	1.2452	1.1523	.1494	.1307
3	.112	.0943	1.2334	1.2125	1.1363	.132	.1307
4	.1494	.1132	1.2803	1.278	1.1203	.132	.132
5	.1698	.1509	1.2803	1.326	1.1363	.168	.1698
6	.2075	.1886	1.2963	1.4255	1.1683	.2452	.2241
7	.2477	.2263	1.668	1.704	1.2631	.3206	.2829
8	.2641	.2829	2.0317	2.1216	1.3108	.3018	.3206
9	.2452	.3018	2.304	2.3703	1.6842	.2452	.2452
10	2.0885	.2829	.2075	.2075	1.7814	1.6549	1.9559
11	2.1051	.2829	.2801	.2829	2.13	2.1382	2.1548
12		.2641	.2829	.2614	2.42	2.3537	2.3537
13		.2641	.2829	.2641	2.4478	2.0972	2.304
14	2.1216	.2452	.2452	.2641	2.4143	2.2611	2.4863
15	2.0719	.2614	.2241	.2263	2.2211	2.4034	2.5692
16	1.9845	.3018	.3174	.3018	2.1548	2.1216	2.2283
17	2.3703	.3018	.2801	.2286	2.1548	1.0486	1.4918
18	.1867	.2829	.2926	.3142	.2241	.1463	.2241
19	.2263	.2772	.2641	.2987	.2987	.2587	.2452
20	.2263	.2427	.2279	.2641	.2801	.2614	.2263
21	.2075	.2054	.2103	.2263	.2241	.2452	.2263
22	.1698	.1867	.2054	.2263	.2263	.2075	.1886
23	.132	.1792	.2054	1.278	.1886	.2075	.2075
24	.1524	.1132	1.2616	1.1822	1.1984	.1698	.1886
Max	2.3703	.3018	2.304	2.3703	2.4478	2.4034	2.5692
Min	.112	.0943	.2054	.2075	.1886	.132	.1307
Avg	.7138	.2198	.7658	.8218	1.3139	.8092	.8682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0754	.0747	.112	.0754	.0943	.112
2	.0934	.0754	.0754	.1132	.0754	.0747	.112
3	.112	.0754	.0566	.0943	.0754	.0754	.132
4	.132	.0943	.0572	.1132	.0943	.0747	.132
5	.1698	.132	.1132	.1524	.132	.0943	.1509
6	.1886	.1886	.1905	.1886	.1698	.2241	.1886
7	.2452	.2263	.2452	.2075	.2263	.2452	.2452
8	.2614	.2263	.2427	.2263	.1867	.2241	.2241
9	.1848	.168	.1737	.1867	.1494	.1478	.1663
10	.2012	.1612	.1646	.1478	.1494	.1448	.1433
11	.1663	.181	.1448	.1448	.1254	.128	
12		.181	.1433	.1254	.1478	.1075	
13		.1463	.1433	.1433	.0739	.1075	
14	.1494	.1646	.1254	.1267	.0739	.0914	.1402
15	.1509	.1448	.1267	.1109	.0914	.0924	.1578
16	.1478	.1509	.1267	.1463	.0905	.0943	.1417
17	.168	.1509	.1494	.1646	.0724	.0905	.1433
18	.1886	.168	.1402	.1612	.1463	.1387	.1772
19	.3018	.2378	.2743	.2743	.2561	.2402	.2743
20	.2801	.2587	.2587	.2587	.2402	.2587	.2772
21	.2614	.2427	.2218	.2427	.2054	.2241	.2218
22	.2054	.168	.1867	.1698	.1792	.1867	.1848
23	.1509	.0934	.132	.0943	.1509	.1307	.0934
24	.1143	.0754	.0754	.1307	.0754	.0943	.132
Max	.3018	.2587	.2743	.2743	.2561	.2587	.2772
Min	.0934	.0754	.0566	.0943	.0724	.0747	.0934
Avg	.1813	.1578	.1518	.1598	.1360	.1410	.1691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV SHIRGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.132	.1698	.1905	.1509	.1698	.1715
2	.1494	.132	.1509	.1509	.132	.168	.1698
3	.1509	.132	.1494	.1509	.132	.1524	.1494
4	.2075	.1509	.132	.1715	.1509	.1524	.1494
5	.2477	.2075	.1132	.2096	.2075	.1886	.1886
6	.3239	.2829	.1307	.2667	.3048	.3734	.3772
7	.4191	.3961	.439	.415	.3584	.3921	.381
8	.4338	.4251	.3961	.3961	.3772	.3961	.4108
9	.2987	.2402	.2452	.2743	.2427	.2427	.2987
10	.1886	.3045	.1867	.2075	.2507	.2254	.2103
11	.1886	.3403	.1867	.2263	.2454	.2218	.1867
12		.362	.2402	.2263	.1867	.2353	.1991
13		.2378	.2587	.2075	.1867	.2033	.2263
14	.2075	.3258	.2218	.2353	.132	.2218	.2075
15	.2263		.2033	.2075	.1791	.1991	.2263
16	.2075	.1494	.2218	.1867	.1991	.2075	.1433
17	.2263	.1791	.2033	.2075	.181	.2172	.197
18	.2378	.2561	.2587	.2378	.2772	.2378	.2896
19	.3921	.3734	.3921	.3921	.4066	.4251	.3921
20	.3961	.3961	.4108	.415	.3734	.4481	.3772
21	.3206	.3395	.3696	.3584	.3395	.3921	.3206
22	.2829	.2987	.3206	.2829	.2667	.3018	.2452
23	.2096	.1905	.2263	.2075	.2241	.2286	.1715
24	.1886	.1509	.1698	.2075	.1524	.1886	.1905
Max	.4338	.4251	.439	.415	.4066	.4481	.4108
Min	.1494	.132	.1132	.1509	.132	.1524	.1433
Avg	.2579	.2610	.2415	.2513	.2357	.2579	.2450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2146	1.1174	.1698	.1494	.132	1.2963	.9282
2	1.1961	1.0722	.1494	.1494	.132	1.2955	.8802
3	1.1469	1.0562	.1509	.1307	.132	1.2483	.9069
4	1.1797	1.1012	.1698	.1698	.1509	1.2018	.9393
5	1.2266	1.1336	.2241	.2286	.1886	1.2163	.9393
6	1.326	1.1797	.2829	.2641	.2263	1.3279	.9831
7	1.5074	1.3108	.3018	.3018	.2987	1.6741	1.094
8	1.6842	1.4918	.2829	.3206	.1867	1.8299	1.1843
9	1.4251	1.8351	.2452	.3018	.2427	1.9662	1.1984
10	.2012	1.9662	2.2542	2.0056	.2614	.1629	
11	.1848	1.8351	2.3537	2.1051	.168	.1848	
12			2.5857	2.1052	.1478	.2054	
13			2.2996	2.2611	.1867	.2241	
14	.2195		2.343	2.2708	.1867	.1867	.1663
15	.2402		2.3868	2.1956	.168	.1307	.1848
16	.2772	2.1445	2.3868	2.2874	.181	.1867	.1867
17	.2614	2.2775	2.3205	2.0153	.1991	.2033	.1478
18	.2801	.2378	.1753	.1478	.2561	.2614	.2614
19	.2427	.2801	.2452	.2241	.2452		.2614
20	.2427	.2614	.2452	.2054	.2614	.2614	.2427
21	.2241	.2427	.2452	.2054	.2427	.2402	.2241
22	.1886	.2241	.2075	.1698	.2075	.1867	.2075
23	.1509	.2075	.1886	.0943	.1867	.1663	.1698
24	1.2631	1.1012	.1811		.132	1.3441	.9717
Max	1.6842	2.2775	2.5857	2.2874	.2987	1.9662	1.1984
Min	.1509	.2075	.1494	.0943	.132	.1307	.1478
Avg	.7220	1.1038	.9331	.8830	.1967	.7392	.6039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1294	1.2483	1.1203	.9172	.1307	.1307
2	.1294	.1294	1.2163	1.166	.9172	.1132	.112
3	.1494	.1294	1.1702	1.1797	.9282	.1143	.1132
4	.1494	.1494	1.2163	1.2125	.9442	.1132	.1698
5	.1886	.1867	1.2955	1.2146	.9442	.1307	.1715
6	.2263	.2241	1.3603	1.247	.9602	.2263	.2286
7	.3018	.2614	1.6194	1.5546	1.2308	.2829	.3018
8	.2926	.2957	1.8884	1.8884	1.3443	.2987	.2801
9	.2353	.2033	1.9595	1.6324	1.749	.1829	.2402
10	2.5232	.1848	.112	.1829	1.7764	1.6762	1.8623
11	2.3922	.2033	.1463	.2033	2.3365	2.5101	1.8842
12		.2218	.1646	.1829	2.3644	2.7199	2.0485
13		.2054	.1646	.1629	2.3644	2.4166	2.0645
14	2.2382	.2033	.1417	.1663	2.3805	2.4291	2.1285
15	2.17		.1646	.1829	2.2186	2.4453	2.2245
16	2.7206	.1646	.1646	.1848	2.2245	2.1052	1.9766
17	1.7604	.181	.1791	.2033	1.8884	2.0567	1.6762
18	.0914	.2378	.1991	.1991	.1792	.1543	.1753
19	.2587	.2772	.2402	.2587	.2772	.2218	.2218
20	.2241	.2614	.2241	.2427	.2427	.2402	.2427
21	.1848	.2402	.2218	.2241	.2054	.2033	.2075
22	.1646	.2054	.1867	.1867	.1792	.1663	.1886
23	.128	.1663	.168	.1478	.168	.1294	.1509
24	.1494	.128	1.2308	1.085	.9488	.1307	.1307
Max	2.7206	.2957	1.9595	1.8884	2.3805	2.7199	2.2245
Min	.0914	.128	.112	.1478	.168	.1132	.112
Avg	.7640	.1995	.6951	.6679	1.2371	.8833	.7888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV PANMALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0366	.056	.0377	.0377	.0566
2	.0381	.0377	.0362	.0377	.0377	.0381	.0377
3	.0381	.0377	.0366	.0377	.0377	.0381	.0377
4	.0566	.0566	.056	.0572	.0377	.0377	.0532
5	.0754	.0754	.0566	.0754	.0566	.056	.0754
6	.0943	.0943	.0754	.0762	.0943	.0943	.112
7	.1494	.1867	.132	.1307	.168	.1307	.1867
8	.1433	.1267	.1132	.1629	.1307	.1075	.181
9	.0732	.168	.0905	.1097	.0716	.112	.1829
10	.0732	.0709	.0895	.0543	.0537	.0876	.0739
11	.0739	.0886	.0549	.0701	.0701	.0924	.0566
12		.0724	.0716	.0876	.0701	.0747	.056
13		.0732	.0895	.0716	.0537	.0876	.0747
14	.1097	.0537	.0537	.0554	.0724	.0857	.056
15	.0549	.0549	.0716	.0747	.0905	.0829	.0754
16	.0724	.0754	.0716	.0566	.0724	.0532	.1227
17	.0914	.048	.0716	.0754	.0549	.0905	.0895
18	.0943	.0747	.0926	.0895	.0739	.0819	.1052
19	.1848	.1307	.1595	.1646	.1595	.1791	.1595
20	.168	.1494	.2075	.1463	.1463	.181	.1646
21	.132	.132	.1478	.1307	.112	.1478	.1307
22	.1132	.1132	.112	.0943	.0943	.1109	.1132
23	.0566	.056	.0747	.0566	.0747	.0739	.0754
24	.0566	.0566	.0434	.056	.0377	.0453	.0747
Max	.1848	.1867	.2075	.1646	.168	.181	.1867
Min	.0377	.0377	.0362	.0377	.0377	.0377	.0377
Avg	.0903	.0863	.0852	.0845	.0795	.0886	.0980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 207 / 11 Kv Nimbalk Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4899	1.1104	.109		.1387	1.5769	1.6301
2	1.4148	1.0924	.1139		.1387	1.5238	1.6118
3	1.3575	1.0924	.1286		.1494	1.5729	1.576
4	1.2536	1.1104	.1387		.1602	1.643	1.5061
5	1.2757	1.1283	.16		.1768	1.6632	1.5775
6	1.3289	1.1462	.189		.1934	1.829	1.7528
7	1.5592	1.3112	.2058		.2683	2.1033	1.9806
8	1.6827	1.4022	.2008		.2362	2.2018	2.2712
9	1.3998	1.8404		.2195	.1772	2.1033	2.2539
10	.2229	2.226	2.5065	2.4013	.189		
11	.1943	2.489	2.8607	2.7566	.1829		
12		2.5415	2.982	2.8433	.2244		
13		2.6337	2.5312	2.6699	.2185		
14	.2244	2.6787	2.6179	2.7913	.25		.0514
15	.2067		2.6179	2.7913	.2622		.0686
16	.2439	2.4508	2.774	2.7566	.2829		.1337
17	.2667	2.2965	2.5486	2.7566	.2743		.2115
18	.2115	.5847	.4908	.1713	.2835		.2126
19	.2622	.6036		.2244	.2955		.25
20	.25	.2439		.2303	.2561		.2683
21	.2185	.2134		.2115	.2126		.189
22	.1943	.1715		.1886	.1715		.1658
23	.1547	.1271		.1602	.1105		.1174
24	1.5947	1.1283	.1029		.1492	1.6124	1.5777
Max	1.6827	2.6787	2.982	2.8433	.2955	2.2018	2.2712
Min	.1547	.1271	.1029	.1602	.1105	1.5238	.0514
Avg	.7730	1.3749	1.2932	1.5448	.2084	1.7830	.9703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 208 / 11kv VISAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.132	1.012	1.0526	.9602	.1509	.132
2	.1143	.132	.9804	1.085	.9646	.1307	.112
3	.1132	.132	.9922	1.1012	.9282	.1334	.112
4	.132	.132	.9488	1.1336	.9602	.1334	.132
5	.1509	.1509	1.0242	1.1469	.9922	.1509	.1509
6	.1698	.1698	1.1203	1.1822	1.0722	.1867	.1715
7	.2075	.2641	1.4575	1.4582	1.3117	.2452	.2667
8	.2263	.1867	1.7166	1.6356	1.3443	.2075	.2452
9	.1663	.1294	1.6787	1.7004	1.4091	.1867	.2075
10	1.8399	.1494	.1307	.132	1.4575	1.3441	1.5061
11	1.8896	.168	.1097	.1494	1.6518	1.8351	1.4575
12		.1509	.1109	.1698	1.7695	1.9006	2.1376
13		.1494	.1294	.168	1.7652	1.9006	1.7328
14	1.8233	.1715	.1294	.2075	1.668	1.8842	1.7444
15	1.8785		.132	.1886	1.6356	1.7532	1.7924
16	1.8947	.168	.1494	.1886	1.6484	2.0153	1.7604
17	1.439	.168	.168	.2075	1.5223	1.7859	1.6164
18	.0732	.1494	.1867	.1867	.128	.1829	.1848
19	.2075	.168	.2263	.2075	.2263	.2263	.2054
20	.2075	.1867	.2075	.2075	.2054	.2263	.2263
21	.1886	.168	.1886	.1886	.1886	.1886	.1886
22	.1698	.1509	.1886	.1886	.1698	.1698	.1698
23	.1509	.1307	.1698	.1509	.1698	.1509	.1509
24	.132	.132	1.0322	.9602	.9282	.1509	.132
Max	1.8947	.2641	1.7166	1.7004	1.7695	2.0153	2.1376
Min	.0732	.1294	.1097	.132	.128	.1307	.112
Avg	.6049	.1583	.5912	.6249	1.0449	.7183	.6890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 416 / 33 kv visapur lis

Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	01-FEB-18
HR	Load (MW)
24	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 201 / 11 KV ANKALKHOP GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0686	.0686	.0686	.0686	.0686
2	.0686	.0686	.0686	.0686	.0686	.0343	.0686
3	.0686	.0686	.0686	.0686	.0686	.0343	.0857
4	.1029	.1029	.0686	.1029	.0686	.0686	.0857
5	.1543	.1029	.1372	.1715	.1372	.1715	.1372
6	.1715	.1715	.2229		.2058	.1715	.2058
7	.2401	.2058	.2572	.2058	.2058	.2058	.16
8	.1715	.2058	.2058		.1715	.1715	.2401
9	.1372	.1372	.1715	.2401	.1372	.1029	.2058
10	.1029	.1372	.1372	.1029	.1372	.1029	.1372
11	.1029	.1372	.1372	.1029	.1372	.0857	.1372
12	.1372	.1372	.1372	.1372	.1029	.1029	.1372
13	.1372	.1029	.1372	.1372	.1029	.0857	.1372
14	.1029	.1029	.1372	.1029	.1029		.1029
15	.1029	.12	.1029	.1372	.1372		.1029
16	.1372		.1029	.1372	.1372		.1372
17	.1372		.1372	.1372	.1372	.1029	.1372
18	.1372		.1715	.1715	.1715	.1372	.1715
19	.2401	.3086	.2058	.2058	.2058	.2401	.2058
20	.2743	.2743	.2401	.2058	.2401	.2401	.2401
21	.2401	.2058	.2058	.2401	.2058	.2058	.2058
22	.1715	.2058	.1372	.1372	.1372	.1372	.1372
23	.0686	.1029	.1029	.0686	.1029	.0857	.1029
24	.0686	.0686	.0857	.0686	.0686	.0686	.0857
Max	.2743	.3086	.2572	.2401	.2401	.2401	.2401
Min	.0686	.0686	.0686	.0686	.0686	.0343	.0686
Avg	.1393	.1445	.1436	.1372	.1358	.1249	.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 202 / 11 KV AUDUMBER GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0686	.0686	.1029	.0686	.0686
2	.0686	.0686	.0686	.0686	.1029	.0686	.0686
3	.0686	.1029	.0686	.0686	.1029	.0686	.0857
4	.1029	.1372	.0686	.1029	.1029	.1029	.0857
5	.1715	.1715	.1372	.1715	.1715	.1715	.12
6	.2058	.2743	.2229		.1715	.2743	.2229
7	.2572	.2401	.2743	.2401	.1715	.2743	.2572
8	.1715	.2058	.2229		.2058	.2401	.2229
9		.1372	.1372	.2058	.2058	.1715	.1543
10	.1029	.1029	.1029	.1372	.1715	.1029	.1029
11	.1029	.1029	.0857	.1372	.1715	.0857	.1029
12	.1029	.0857	.0857	.1372		.0857	.1029
13	.1029	.0686	.1029	.12	.1372	.0857	.1029
14	.1029	.0857	.1029	.1029	.1029		.1029
15	.1029	.0857	.1029	.1029	.1029		.1029
16	.1029	.0857	.1029	.12	.1372		.1372
17	.1372	.0857	.1029	.1543	.1715	.12	.1715
18		.1372	.1372	.1543	.1715	.1372	.2401
19	.2401	.2572	.2058	.2058	.2058	.2401	.2743
20		.2229	.2401	.2401	.2401	.2229	.2743
21	.2058	.2058	.2058	.2401	.2058	.1886	.1715
22	.1715	.1372	.1372	.1543	.1715	.1372	.1372
23	.1029	.0857	.1029	.1543	.1029	.0857	.1029
24	.6097	.0857			.1029	.1029	.0857
Max	.6097	.2743	.2743	.2401	.2401	.2743	.2743
Min	.0686	.0686	.0686	.0686	.1029	.0686	.0686
Avg	.1572	.1350	.1342	.1470	.1536	.1445	.1458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 203 / 11 KV BHILAWADI GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2058	.2058	.2401	.2058	.2401
2	.2401	.2058	.2058	.2058	.2401	.1715	.2401
3	.2401	.2058	.2058	.2058	.2401	.1715	.2401
4	.3086	.2743	.2229	.2743	.4115	.2401	.2401
5	.3944	.4115	.2915	.3429	.4973	.3772	.3086
6	.6001	.6173	.6173		.583	.5144	.583
7	.6859	.583	.6516	.583	.6859	.6173	.6516
8	.5487	.4801	.5144		.4973	.4801	.4801
9	.4458	.3429	.3772	.3772	.4458	.3772	.4115
10	.3772	.3429	.2743	.3429	.4458	.3086	.3429
11	.3429	.3086	.2743	.2743	.4115	.2743	.3429
12	.3086	.2743	.3086	.2743	.4115	.3086	.3086
13	.3086	.2401	.3086	.2743	.3429	.3086	.3086
14	.3429	.2401	.3086	.2743	.2743		.2743
15	.3429	.3086	.3086	.3086	.3086		.2743
16	.3772	.3772	.3429	.3086	.3429		.3772
17	.4115	.3944	.3772	.3429	.3772	.4115	.4458
18	.4458	.4801	.4115	.3772	.4801	.4458	.5144
19	.5144	.703	.5144	.4973	.5144	.6173	.583
20	.583	.6173	.6173	.5487	.583	.6344	.6173
21	.5144	.5487	.5487	.583	.5487	.5487	.5144
22	.4458	.4458	.4801	.4458	.4801	.4115	.4115
23	.3086	.2743	.3429	.2743	.2401	.2915	.3086
24	.2401	.2401	.2401	.2401	.2401	.2058	.2743
Max	.6859	.703	.6516	.583	.6859	.6344	.6516
Min	.2401	.2058	.2058	.2058	.2401	.1715	.2401
Avg	.3987	.3815	.3729	.3437	.4101	.3772	.3872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 204 / 11 KV NAGATHANE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1372	.12	.1372	.1372	.1372	.1372
2	.1029	.1372	.12	.1372	.1372	.1029	.1372
3	.1029	.1372	.12	.1372	.1372	.1372	.1372
4	.1372	.1715	.1372	.1715	.2058	.2058	.1372
5	.2058	.2743	.2572	.3086	.2743	.3772	.2743
6	.3944	.4115	.4115		.3772	.3772	.3944
7	.4801	.4801	.4973	.4801	.3944	.5144	.4801
8	.3429	.4458	.3772	.4801	.2401	.3772	.4115
9	.3429	.3086	.3258	.3429	.2401	.2743	.3429
10	.2229	.2058	.2058	.2401	.2058	.2058	.2401
11	.2058	.2058	.2058	.2058	.2058	.2058	.2401
12	.1715	.2058	.2401	.2058	.2058	.2058	.2058
13	.1715	.1715	.2058	.2058	.2058	.2058	.1715
14	.1372	.1715	.1715	.1715	.2058		.1372
15	.1372	.1715	.1372	.1543	.1715		.1372
16	.1715	.1715	.1715	.1543	.1372		.1715
17	.2058	.2401	.2058	.1886	.1715	.2058	.2058
18	.2401	.2058	.2401	.2229	.3086	.2572	.2401
19	.3429	.3429	.3086	.2572		.3772	.3086
20	.3772	.3772	.3772	.3086	.3772	.3429	.3429
21	.3429	.3258	.3429	.3429	.3429	.3429	.3086
22	.2743	.2743	.2743	.2743	.2743		.2401
23	.1372	.1715	.1715	.1543	.1715	.1715	.1372
24	.12	.1372	.1372	.1372	.1372	.1372	.1543
Max	.4801	.4801	.4973	.4801	.3944	.5144	.4801
Min	.1029	.1372	.12	.1372	.1372	.1029	.1372
Avg	.2279	.2451	.2401	.2356	.2289	.2581	.2372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 205 / 11 KV ANKALKHOP AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.4458	.3772	.3429	.0343	.0514
2	.0343	.0343	.4458	.3429	.3429	.0343	
3	.0343	.0343	.4458	.3429	.3772	.0343	.0343
4	.0343	.0343	.4458	.3772	.3772	.0343	.0343
5	.0343	.0343	.4458	.3772	.3772	.0343	.0343
6	.0343	.0343	.5487		.3772	.0343	.0343
7	.0343	.0343	.583	.583	.4801	.0343	.0343
8	.0343	.0343	.7545	.6516	.6859	.0343	.0343
9	.0343	.0343	.7202	.6516	.7545	.0343	.0343
10	.823	.0343	.0343	.0343	1.0288	.9602	.0343
11	1.0974	.0343	.0343	.0343	1.1317	1.2003	1.2003
12	1.2003	.0343	.0343	.0343	1.2689	1.1317	1.2689
13	1.2003	.0343	.0343	.0343	1.2346	1.2689	1.2346
14	1.2003	.0343	.0343	.0343	1.2003		1.2003
15		.0343	.0343	.0343	1.1317		1.1317
16	.9945		.0343	.0343	1.0631		1.0631
17	.9259		.0343	.0343	.9259	1.0974	.9945
18	.0343		.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.4115	.3772	.3429	.0343	.0343
Max	1.2003	.0343	.7545	.6516	1.2689	1.2689	1.2689
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.3474	.0343	.2386	.1983	.5687	.2956	.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 206 / 11KV AUDUMBER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	1.4403	1.2689	.0343	.0343
2	.0343	.0343	.0343	1.406	1.3546	.0343	.0343
3	.0343	.0343	.0343	1.4403	1.3717	.0343	.0343
4	.0343	.0343	.0343	1.4403	1.3717	.0343	.0343
5	.0343	.0343	.0343	1.4746	1.286	.0343	.0343
6	.0343	.0343	.0343		1.3203	.0343	.0343
7	.0343	.0343	.583	1.6804	1.4918	.0343	.0343
8	.0343	.0343	.7716		1.7147	.0343	.0343
9		.0343	1.4575	1.8519	2.1434	.0343	.0343
10		.0343	.0343	.0343	2.6406	2.5034	.0343
11	2.7092		.0343	.0343	2.7778	2.9492	2.9492
12	2.7778		.0343	.0343		2.7778	3.0178
13	2.7778		.0343	.0343	2.915	2.915	3.0178
14	2.7778		.0343	.0343	3.0178		3.0178
15	2.8807		.0343	.0343	3.0178		1.4746
16	2.9492		.0343	.0343	3.0178		2.8121
17	2.8464		.0343	.0343	2.8807	1.5432	2.7092
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19		.0343	.0343	.0343	.0343	.0343	.0343
20		.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343		1.4403	1.2689	.0343	.0343
Max	2.9492	.0343	1.4575	1.8519	3.0178	2.9492	3.0178
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	1.0082	.0343	.1521	.5752	1.5246	.6304	.8159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 207 / 11 KV BHILAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8916	.0343	.0343	.0343	1.2346	1.1145
2	.7545	.8916	.0343	.0343	.0343	1.2003	1.0974
3	.7545	.9259	.0343	.0343	.0343	1.2003	1.0974
4	.7545	.9259	.0686	.0343	.0343	1.2346	1.0974
5	.7545	.9602	.0343	.0343	.0343	1.3032	1.0974
6	.7545	1.0288	.0343		.0343	1.3032	1.166
7	.823	1.0974	.0343	.0343	.0343	1.4403	1.3717
8	.8573	1.3032	.0343		.0343	1.4403	1.3717
9	.8916	1.6461	.0343	.0343	.0343	1.4403	1.4403
10	.0343	2.0576	.0343	2.1948	.0343	.0343	.0343
11	.0343	2.1948	2.1948	2.2634	.0343	.0343	.0343
12	.0343		2.4006	2.4006	.0343	.0343	.0343
13	.0343	2.2634	2.5377	2.4006	.0343	.0343	.0343
14	.0343	2.1948	2.4691	2.4006	.0343		.0343
15	.0343	2.0576	2.4006	2.332	.0343		.0343
16	.0343	2.1262	2.4006	2.332	.0686		.0343
17	.0343	1.989	2.332	2.1948	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.7545	.823	.0343	.0343	.0343	1.2346	1.0288
Max	.8916	2.2634	2.5377	2.4006	.0686	1.4403	1.4403
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.3472	1.1123	.7230	.8636	.0357	.6385	.5151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 208 / 11 KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	.9602	.0686	.0686	.0686	1.0288	.9602
2	1.0631	.9945	.0686	.0686	.0686	1.0288	.9602
3	1.0631	.9945	.0686	.0686	.0686	1.0631	.9602
4	1.166	1.0288	.0686	.0686	.0686	1.1317	1.0288
5	1.2003	1.0631	.0686	.0686	.1372	1.2346	1.0974
6	1.3032	1.0974	.1372		.1372	1.3032	1.2346
7	1.5775	1.2346	.1715	.1372	.1372	1.6804	1.4403
8	1.3717	1.4403	.1372	.0686	.1372	1.8519	1.7833
9	1.3375	2.1948	.0686	.0686	.1372	1.7833	1.7147
10	.0686	2.7435	.0686	2.4691	.1372	.1372	.1372
11	.0686	3.0178	2.8807	2.7435	.1372	.1372	.1372
12	.0686	3.2236	3.0864	2.9492	.1372	.1372	.0686
13	.0686	3.0178	3.0178	2.915	.1372	.1372	.0686
14	.0686	2.8807	2.9835	2.8807	.0686		.0686
15	.0686	2.7435	2.9492	2.7092	.0686		.1372
16	.0686	2.6749	2.8807	2.5377	.0686		.1372
17	.0686	2.4691	2.6406	2.2634	.0686	.1372	.1372
18	.1372	.1372	.1372	.1372	.1372	.1372	.0686
19	.1372	.1372	.1372	.1372	.1372	.1372	.1372
20	.1372	.0343	.1372	.1372	.1372	.1372	.1372
21	.1372	.0343	.1372	.1372	.1372	.1372	.0686
22	.0686	.1372	.1372	.0686	.1372	.0686	.0686
23	.0686	.0686	.0686	.0686	.0686	.0686	.0686
24	.8916	.9602	.0686	.0686	.0686	1.0288	.8916
Max	1.5775	3.2236	3.0864	2.9492	.1372	1.8519	1.7833
Min	.0686	.0343	.0686	.0686	.0686	.0686	.0686
Avg	.5530	1.4703	.9245	.9930	.1086	.6908	.5630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 201 / 11 KV YELAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.4428	.5693	.4687	.0943	.1132
2	.0943	.0754	.4801	.571	.4531	.0747	.0943
3	.1132	.0943	.4999	.5937	.4744	.0943	.0943
4	.1132	.1132	.506	.6009	.4687	.0943	
5	.132	.132	.5624	.6325	.5182	.1132	.132
6	.1698	.1698	.6802	.7125	.6062	.1698	.1886
7	.2452	.2263	.9717	.9717	.6964	.2075	.2263
8	.1886	.2075	1.0562	1.166	.7116	.1886	.1886
9	.1698	.1867	1.1523	1.1363	.9488	.1509	.1307
10			.1433	.1494	1.1843	.759	.6405
11	.8905	.1867	.132	.2241	1.2483	1.1385	.9602
12		.168	.1294	.1886	1.2651	1.2334	1.1203
13	1.4413	.168	.1267	.1886	1.1717	1.1385	1.0936
14		.1494	.1478	.1494	1.142	1.2186	1.0437
15	1.4899	.1509	.1448	.1294	1.2029	1.0802	1.0242
16	1.4575	.1307	.1294	.1494	1.2186	1.1385	.9217
17	1.3599	.1478	.1307	.1494	1.0753	1.1069	.9014
18	.1086	.1294	.1698	.1663	.1063	.1097	.1109
19	.1698	.1886	.1698	.1886	.168	.1509	.132
20	.1698	.1886	.1509	.1698	.1509	.1509	.132
21	.1509	.1867	.1698	.1698	.1509	.132	.132
22	.132	.1307	.132	.132	.1132	.132	.1132
23	.1132	.1132	.1509	.1132	.0934	.1132	.1132
24	.0943	.0943	.4321	.4858	.4481	.0943	.1132
Max	1.4899	.2263	1.1523	1.166	1.2651	1.2334	1.1203
Min	.0943	.0754	.1267	.1132	.0934	.0747	.0943
Avg	.4237	.1492	.3671	.4045	.6702	.4535	.4226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 202 / 11 KV Laxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3765	1.5893	1.5424	1.5775	1.8404	.644
2	1.4918	1.5893	1.5769	1.6651	1.8229	.7042
3	1.543	1.6244	1.6817	1.7353	1.8404	.8002
4	1.543	1.643	1.7511	1.7164	1.825	.8642
5	1.5927	1.8176	1.858	1.949	1.97	.9305
6	1.7465	1.9845	1.9845	2.1719	2.0814	.9846
7	1.9938	2.2624	2.2081	2.1357	2.2262	1.0269
8	2.2805	2.3777	2.4691	2.5133	2.4949	1.4922
9	2.4143	2.5318	2.5688	1.7295	2.6513	2.2916
10	2.6513		2.6147	2.8481	2.3899	2.6513
11	2.6513	2.0271	2.8567	2.726	2.2779	2.8669
12	2.5206	.7903	2.8858	2.7073	2.6513	2.8292
13	2.5206	2.6699	2.4086	2.6326	2.2405	2.6326
14		2.6139	2.4086	2.5688	2.2032	2.7446
15	2.5318	2.6326	2.384	2.1719	2.0119	2.726
16	2.1357	2.2081	2.384	1.9667	1.9753	2.2916
Max	2.6513	2.6699	2.8858	2.8481	2.6513	2.8669
Min	1.3765	.7903	1.5424	1.5775	1.8229	.644
Avg	2.0662	2.0241	2.2239	2.1759	2.1564	1.7800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 203 / 11 KV Yelavi Bu'wadi

GAOTHAN FEEDER

Gaonthan Feeder KV- 11 /
OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2054	.2263	.2452	.2075	.2075	.2263
2	.2263	.2054	.2075	.2641	.2075	.2075	.2075
3	.2263	.2241	.2263	.2641	.2075	.2263	.2263
4	.2452	.2641	.2641	.3018	.2263	.2641	.2641
5	.3584	.3584	.3395	.3395	.3584	.3772	.3395
6	.679	.6224	.6036	.547	.5658	.547	.5847
7	.7167	.7167	.6979	.679	.6979	.6979	.6979
8	.6036	.5788	.5601	.6224	.5601	.5228	.5975
9	.4435	.4805	.4251	.462	.3881	.3881	.4066
10	.3077		.3045	.3403	.3045	.2686	.2534
11	.2686	.2507	.2534	.2686	.2658	.2481	.2534
12		.2743	.2865	.2686	.2149	.2328	.2507
13	.2303	.2658	.2835	.2507	.2103	.2303	.2279
14	.0848	.2126	.2835	.2353	.2103	.1433	.2149
15	.2481	.2303	.2481	.2328	.2126	.2454	.2279
16	.2279	.2126	.2534	.2507	.2427	.2303	.2454
17	.3121		.2835	.3012	.2572	.2658	.3045
18	.3681	.3721	.3681	.3366	.333	.3189	.4119
19	.6401	.6219	.6036	.6401	.6036	.5914	.6099
20	.6767	.6468	.6099	.5914	.5853	.6099	.5914
21	.5729	.5601	.5415	.5041	.5041	.5228	.5415
22	.4294	.4338	.415	.3961	.3921	.3961	.3921
23	.2641	.3395	.3395	.2641	.2614	.3018	.2614
24	.2452	.2263	.2263	.2452	.2263	.2263	.2452
Max	.7167	.7167	.6979	.679	.6979	.6979	.6979
Min	.0848	.2054	.2075	.2328	.2075	.1433	.2075
Avg	.3740	.3774	.3688	.3688	.3435	.3446	.3576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 204 / 11 KV Burungwadi

Industrial Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2683	.2027	.3048	.2267	.221	.2865	.2063
2	.2429	.1783	.2332	.2029	.257	.2343	.1886
3	.2315	.1799	.2225	.1972	.2248	.2229	.1646
4	.2286	.204	.2235	.1981	.204	.2164	.1738
5	.2641	.2324	.2092	.2134	.2092	.2362	.2073
6	.3227	.2315	.286	.2503	.2641	.2652	.2683
7	.3361	.3544	.3641	.4066	.2686	.3113	.3881
8	.3658	.3189	.394	.3361	.2984	.3294	.4527
9	.4163	.462	.6838	.362	.4668	.3881	.4715
10	.5658	.4251	.6979	.3721	.543	.4207	.5281
11	.6224	.6036	.4904	.6036	.7545	.415	.4066
12	.6413	.4527	.6413	.679	.5729	.3439	.5658
13	.7167	.4904	.679	.7545	.7545	.3584	.4715
14	.9054	.415	.679	.679	.4805	.3658	.547
15	.8676	.5658	.8488	.7733	.7922	.3258	.6413
16	.9054	.5281	.6602	.679	.5914	.3881	.679
17	.6413	.4904	.5658	.3881	.4904	.3582	.5788
18	.5658	.4527	.4481	.2987	.415	.3547	.4854
19	.5658	.5041	.4668	.2881	.4904	.3982	.547
20	.4435	.3544	.4527	.2389	.3772	.3961	.5093
21	.4527	.5281	.3772	.2324	.4668	.3856	.5093
22	.4904	.4904	.415	.2372	.4668	.3761	.4904
23	.3841	.4287	.3001	.2343	.3584	.3086	.2841
24	.3467	.3292	.3725	.2601	.2126	.3142	.2401
Max	.9054	.6036	.8488	.7733	.7922	.4207	.679
Min	.2286	.1783	.2092	.1972	.204	.2164	.1646
Avg	.4913	.3926	.4590	.3797	.4242	.3333	.4169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 205 / 11Kv Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335	1.5466	1.4712	1.5089	1.5655	1.4712	1.5278
2	1.4712	1.5089	1.5466	1.5466	1.5278	1.4523	1.6032
3	1.4712	1.4712	1.6032	1.6032	1.5655	1.4335	1.5089
4	1.5089	1.4523	1.5089	1.6032	1.6032	1.4712	1.4901
5	1.5844	1.4712	1.5655	1.6409	1.5466	1.4901	1.3957
6	1.6221	1.4712	1.6598	1.6787	1.6032	1.5089	1.6032
7	1.6598	1.6598	1.5844	1.5089	1.6598	1.6975	1.7164
8	1.5844	1.6598	1.5089	1.5466	1.6032	1.6409	1.5844
9	1.2071	1.1317	1.094	.9619	1.0751	1.1694	1.1694
10	1.2071	1.0751	1.1694	1.1317	1.2826	1.3203	1.2071
11	1.226	1.1883	1.3513	1.4523	1.3203	1.3392	1.2637
12	1.3203	1.3203	1.3957	1.6032	1.6598	1.4335	1.3957
13	1.5466	1.5844	1.7541	1.7353	1.7353	1.7918	1.5466
14	1.7353	1.6975	1.773	1.7918	1.6975	1.6975	1.6975
15	1.7353	1.8296	1.8861	1.8296	1.8107	1.7541	1.9616
16	1.7541	1.7541	1.7353	1.8296	1.7541	1.6787	1.9239
17	1.7918	1.7918	1.7164	1.7541	1.7353	1.7353	1.9239
18	1.6975	1.773	1.6975	1.7918	1.6032	1.5844	1.7164
19	1.0829	1.1317	1.2449	1.1317	1.094	1.1883	1.1694
20	1.0456	1.094	1.0562	1.1694	1.0082	1.1317	1.1506
21	.9979	.9431	1.0562	1.1317	.9896	1.2449	1.1506
22	1.1317	1.226	1.1317	1.358		1.358	1.1883
23	1.5844	1.4712	1.4901	1.5466	1.6409	1.5278	1.4146
24	.5144	1.4712	1.5089	1.6221	1.6975	1.5466	1.4901
Max	1.7918	1.8296	1.8861	1.8296	1.8107	1.7918	1.9616
Min	.5144	.9431	1.0562	.9619	.9896	1.1317	1.1506
Avg	1.4131	1.4468	1.4796	1.5199	1.5121	1.4861	1.4916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 206 / Yelavi Ag -2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0286	.6154	.6554	.6203	.0457	.0191
2	.0133	.0274	.6554	.6802	.5967	.0438	.0154
3	.0133	.0267	.7459	.7042	.6062	.0343	.0171
4	.0147	.0251	.8288	.7773	.5967	.0272	.021
5	.0274	.0229	.8718	.8907	.7127	.0267	.0322
6	.0305	.0274	1.1012	1.004	.8436	.0343	.0377
7	.0366	.0438	1.6575	1.6057	1.1523	.057	.0419
8	.0381	.0549		1.9334	1.3117	.0579	.0543
9	.0789	.0615	1.9227	1.8947	1.7695	.048	.06
10	1.4255		.0619	.0533	1.9757	1.1271	1.0562
11	2.0972	.0389	.0476	.0372	2.1628	1.8564	1.6385
12		.0457	.0457	.048	2.1136	2.0317	1.6876
13		.052	.0503	.0446	1.8945	1.9662	1.8351
14		.0471	.0503	.0297	1.7939	1.7436	1.8515
15	2.4249	.032	.0366		1.8564	1.8778	1.6575
16	2.4939	.04	.032		1.873	1.7901	1.643
17	2.0553	.0347	.0396		1.8233	1.7238	1.5074
18	.0362	.0551	.0507	.081	.0701	.065	.0461
19	.0671	.0457	.0446	.0507	.0471	.0419	.0335
20	.0434	.0309	.0389	.0453	.0356	.0259	.0305
21	.0396	.0305	.0305	.0366	.0372	.0305	.0347
22	.032	.0272	.0267	.0297	.0396	.0293	.0274
23	.0293	.0231	.0248	.0314	.0356	.0251	.0248
24	.0229	.021	.6226	.6226	.6154	.044	.021
Max	2.4939	.0615	1.9227	1.9334	2.1628	2.0317	1.8515
Min	.0133	.021	.0248	.0297	.0356	.0251	.0154
Avg	.5255	.0366	.4175	.5360	1.0243	.6147	.5581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 201 / 11 KV VASAGADE GAON
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0914	.0905	.0905	.0914	.0914	.0914
2	.0895	.0724	.0716	.0732	.0905	.1086	.0724
3	.0732	.0732	.0732	.0724	.0914	.0914	.0732
4	.0732	.0732	.0914	.0914	.1086	.1097	.0905
5	.1086	.1086	.1097	.1086	.0914	.1478	.1097
6	.1612	.1646	.1629	.1646	.0905	.2012	.1448
7	.1991	.2012	.197	.2012	.1086	.181	.2012
8	.1791	.1829	.1629	.1448	.0905	.128	.1663
9	.1463	.1463	.128	.1448	.128	.1097	.1646
10	.1086	.1463	.1086	.1463	.1086	.1097	.1267
11	.1086	.1086	.1075	.1086	.1097	.1097	.1086
12	.1097	.1097	.1086	.0914	.1097	.1097	.1097
13	.1086	.1086	.1075	.1086	.1086		.1086
14	.1097	.1086	.1086	.0914	.0924		.0914
15	.1086	.1097	.1086	.0905	.0914		.1109
16	.128	.1086	.1075	.1097	.1086		.1097
17	.128	.1097	.1075	.1097	.1109	.1097	.1097
18	.128	.0905	.1254	.0905	.128	.0914	.1294
19	.1829	.1463	.1433	.1463	.128	.9145	.1463
20	.2195	.2172	.2172	.2172	.2218	.2033	.2195
21	.2195	.2195	.2195		.2012	.1463	.1294
22	.1829	.1829	.1829		.1463	.1294	.1097
23	.1463	.1448	.1463	.1097	.1109	.1097	.1097
24	.1097	.1097	.1097	.1097	.0905	.1086	.1086
Max	.2195	.2195	.2195	.2172	.2218	.9145	.2195
Min	.0732	.0724	.0716	.0724	.0905	.0914	.0724
Avg	.1341	.1306	.1290	.1191	.1149	.1655	.1226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 202 / 11KV KHATAV GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0914	.0905	.0924	.0914		.0732
2	.0716	.0724	.0732	.0739	.0905		.0732
3	.0732	.0732	.0732	.0732	.0914		.0914
4	.0732	.0732	.0914	.0924	.0905		.1109
5	.1097	.1097	.1109	.1097	.1097		.1478
6	.1612	.1646	.1629	.1646	.1086		.1829
7	.2149	.2195	.2149	.2012	.2195		.2195
8	.2172	.2195	.181	.2195	.2195		.1829
9	.1646	.1646	.1463	.1829	.1448	.128	.1848
10	.1086	.1463	.1086	.1646	.1463	.1463	.1463
11	.1267	.1086	.1086	.1086	.128	.1463	.128
12	.1097	.1097	.1086	.1097	.1086	.1267	.1086
13	.1294	.1086	.1086	.0905	.1097	.128	.1097
14	.1097	.1097	.0895	.0914	.0739	.128	.0724
15	.1109	.1109	.0905	.0905	.0914	.0914	.0739
16	.128	.1086	.0905	.1097	.0914	.0914	.0914
17	.128	.0914	.1086	.0914	.1097	.1294	.1086
18	.128	.0905	.128		.1109	.1478	.1097
19	.2195	.1463	.1829		.128	.1848	.2012
20	.2378	.2172	.2195		.181	.2218	.2172
21	.2195	.2328	.2172		.1829	.2195	.1294
22	.1829	.2012	.1829			.1829	.1097
23	.1463	.1629	.1463	.1097		.1463	.1109
24	.1097	.1097	.1109	.1097	.0905		.0905
Max	.2378	.2328	.2195	.2195	.2195	.2218	.2195
Min	.0716	.0724	.0732	.0732	.0739	.0914	.0724
Avg	.1405	.1351	.1311	.1203	.1236	.1479	.1281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 203 / 11 KV SUKHWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287	.0181	.0179	.0181	.664	.583
2		.4287	.0183	.0179	.0183	.6554	.583
3		.4287	.0179	.0183	.0181	.6478	.583
4		.4287	.0179	.0179	.0183	.6478	.583
5		.4287	.0181	.0181	.0181	.6718	.6516
6	.4287	.5144	.0183	.0179	.0181	.6882	.7716
7	.4915	.6001	.0183	.0179	.0181	.7449	.7716
8	.5304	.6859	.0181	.0179	.0171	.852	.6859
9	.503	.9431	.0183	.0179	.0171		.7716
10	.0175	1.0974	.6882	1.1145	.035	.0179	.0181
11	.0179	1.1469	1.326		.0179	.0179	.0179
12	.0179	1.1934	1.3735		.0181	.0179	.0181
13	.0179	1.1869	1.3748		.0179	.0179	.0179
14	.0179	1.1401	1.326		.0179	.0179	.0173
15	.0179	1.1022	1.3916		.0181	.0179	.0175
16	.0179	1.0974	1.3032		.0181	.0179	.0181
17	.0179	1.0974	1.2689		.0179	.0179	.0179
18	.0179	.0173	.0179		.0183	.0179	.0183
19	.0179	.0173	.0179		.0183	.0179	.0179
20	.0179	.0175	.0179		.0181	.0179	.0177
21	.0179	.0179	.0179		.0181	.0179	.0179
22	.0181	.0181	.0179		.0179	.0179	.0177
23	.0179	.0183	.0181	.0181	.0181	.0179	.0173
24		.4287	.0181	.0179	.0183	.567	.583
Max	.5304	1.1934	1.3916	1.1145	.035	.852	.7716
Min	.0175	.0173	.0179	.0179	.0171	.0179	.0173
Avg	.1224	.6035	.4309	.1094	.0187	.2778	.2840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 204 / 11 KV VASAGADE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2149	.8619	1.0802	1.2003	.2534	.2149
2	.2012	.2149	.8383	1.0802	1.2003	.2149	.2149
3	.197	.2149	.8478	1.0288	1.2136	.2149	.2149
4	.2172	.2172	.7956	1.0802	1.2003	.2172	.2328
5	.2353	.2328	.8718	1.0802	1.2346	.2353	.2353
6	.2378	.2328	.9831	1.2003	1.2346	.2507	.2328
7	.2328	.2507	1.2616	1.2346	1.2483	.2534	.2328
8	.2353	.2507	1.4582	1.4232	1.262	.2507	.2328
9	.2561	.2328	1.3923	1.4918	1.7528	.2534	.2328
10	1.6549	.2328	.2374	.2149	1.9765	1.3889	1.5257
11	1.989	.2353	.2229		2.226	2.0062	2.0458
12	2.0454	.2378	.2328		2.2018	1.9784	2.0458
13	2.0957	.2353	.2149		2.226	1.989	2.1033
14	2.1125	.2149	.2149		2.2148	1.9784	1.949
15	2.0454	.2149	.2328		2.073	1.9839	.1907
16	2.0348	.2149	.2328		2.0858	1.9281	1.8959
17	1.8652	.2195	.2328		1.9418	1.9839	1.858
18	.2328	.2172	.2328		.2149	.218	.2328
19	.2328	.2195	.2328		.2172	.2328	.2195
20	.2328	.2353	.2353		.2328	.2328	.2353
21	.2328	.2378	.2328		.2353	.2507	.2328
22	.2328	.2328	.2328		.2378	.2507	.2328
23	.2328	.2195	.2328	.2172	.2534	.2328	.2561
24	.2195	.2328	.6554	1.0802	.4458	.2534	.2328
Max	2.1125	.2507	1.4582	1.4918	2.226	2.0062	2.1033
Min	.197	.2149	.2149	.2149	.2149	.2149	.1907
Avg	.8120	.2276	.5494	1.0177	1.2637	.7938	.7208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 205 / 11 KV PARSHWNATH LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801	.4458	.4801	.5014	.4801
2		.4801	.4409	.4801	.5068	.4801
3		.4801	.4748	.4801		.4801
4		.4801	.4801	.4801		.4801
5		.4801	.4458	.4801	.5121	.4801
6		.4801	.4748	.4801	.543	.4801
7				.4801	.5487	
8			.4694			
9			.4748	.4801	.543	.4801
10			.4801	.4801	.5487	.5068
11	.4801				.5175	.5014
12	.4801		.4801		.5121	.362
13	.4801	.4748	.4801		.3696	.5121
14	.4801	.4801	.4801		.5121	.5068
15	.4801	.4641	.4801		.4706	.4755
16	.4801	.4748	.4801		.5121	.4805
Max	.4801	.4801	.4801	.4801	.5487	.5121
Min	.4801	.4641	.4409	.4801	.3696	.362
Avg	.4801	.4774	.4705	.4801	.5075	.4790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 201 / 11 KV Tasgaon I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.5281		.547		.5041		.547
6	.7167		.7545		.6535	.7842	.7468
7	.8029	.8029	.8029		.7207	.8131	.4921
8	.8507	.8316	.7865	.8048	.8507	.8316	.8131
9	.7796			.8238	.8326	.7701	.8145
10	.7265	.7442		.7282	.7973	.6626	
11	.779	.7362		.6836	.7282	.6556	.8589
12	.7611	.6613		.6783			.7455
13	.6516			.6274		.4784	
14		.6516		.583		.4298	
15				.5375		.3982	
16	.7888	.8048		.6613		.5194	.8648
17		.7712		.6687		.6089	
18	.8139	.8745		.6859		.788	.9465
19	1.1157	1.1157		1.1041		1.1088	1.1088
20	1.0059	1.0242		.9877		.9979	.9511
21	.8871	.9425		.8686		.9335	
22	.7762	.8501		.7762		.8686	.8131
23		.6348		.6653		.7095	
24	.5975	.5788	.547	.6161	.5093	.5975	.6413
Max	1.1157	1.1157	.8029	1.1041	.8507	1.1088	1.1088
Min	.5281	.5788	.547	.5375	.5041	.3982	.4921
Avg	.7863	.8016	.6876	.7353	.6996	.7198	.7957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 202 / 11 KV Tasgaon II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.4858		.4934		.4729		.4793
6	.7291		.7461		.6316	.7973	.7122
7	.905	.815	.8505		.8063	.7712	.8328
8	.8775	.7973	.7973	.7712	.7796	.7973	.8238
9	.7186			.7282	.7842	.6762	.7011
10	.6661	.6556		.6415	.7087	.6485	
11	.6805	.691		.6556	.6626	.6626	.6001
12	.6201	.631		.6068			.4961
13	.6241			.5407		.547	
14		.57		.5281		.5868	
15				.5281		.583	
16	.631	.6241		.57		.583	.6447
17		.6878		.6485		.6173	
18	.8215	.8402		.7577		.7783	.8775
19	1.1317	1.1506		1.094		1.0642	1.1016
20	1.0456	1.0642		.9795		.9979	1.0456
21	.9425	.9231		.905		.905	
22	.7973	.7545		.7628		.7975	.7628
23		.5401		.5401		.5851	
24	.4858	.459	.4793	.5441	.4652	.4793	.4793
Max	1.1317	1.1506	.8505	1.094	.8063	1.0642	1.1016
Min	.4858	.459	.4793	.5281	.4652	.4793	.4793
Avg	.7601	.7469	.6733	.6942	.6639	.7154	.7351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 203 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.567		.6024		.5434		.5609
6	.5138		.6485		.631	.5316	.4031
7	.5083	.6135	.5083		.4961	.567	.4908
8	.583	.7011	.5784	.5895	.583	.5895	.6135
9	.6415			.6836	.5959	.6068	.6241
10	.6485	.6485				.6135	
11	.5375	.5014		.5434	.6024	.5258	.5493
12	.5375	.1867		.5434			.5434
13	.3582			.5784		.5083	
14		.4854		.4119		.5609	
15				.4733		.4252	
16	.5765	.6415		.5721		.5784	.6415
17		.6415		.6588		.6485	
18	.6241	.6661		.6241		.5258	.631
19	.5784	.5258		.6201		.4908	.6485
20	.4298	.2804		.6135		.5258	.4557
21	.4075	.2896		.6135		.443	
22		.2804		.3544		.443	.4508
23		.132		.3681		.4656	
24	.5014	.5493	.3761	.5014	.567	.5316	.567
Max	.6485	.7011	.6485	.6836	.631	.6485	.6485
Min	.3582	.132	.3761	.3544	.4961	.4252	.4031
Avg	.5342	.4762	.5427	.5468	.5741	.5323	.5523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 204 / 11KV NEW TASGAON

INDUSTRIAL FE Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.0179		.0351		.0171		.0133
6	.0168		.0347		.0175	.0202	.016
7	.0221	.032	.0709		.0164	.021	.016
8	.0282	.0312	.0358	.0377	.0217	.0221	.0171
9	.0655			.037	.0701	.0377	.0633
10	.0724	.1886		.1063	.1772	.024	
11	.1143	.1509		.1086	.2126	.0762	.1867
12	.0972	.1734		.1086			.2172
13	.1075			.1478		.0701	.1494
14		.1753		.0747		.0278	
15				.1132		.0248	
16	.0754	.1036		.1848		.0221	.1109
17		.1791		.1463		.0663	
18	.0373	.0671		.1109		.0678	.1109
19	.0366	.1311		.1478		.0648	.0762
20	.0762	.0716		.0724		.0678	.0339
21	.0206	.0191		.0381		.0297	
22	.0187	.0213		.0175		.0179	.016
23		.0164		.0179		.0137	
24	.0175	.0122	.0351	.0351	.0141	.0373	.0126
Max	.1143	.1886	.0709	.1848	.2126	.0762	.2172
Min	.0168	.0122	.0347	.0175	.0141	.0137	.0126
Avg	.0515	.0915	.0423	.0885	.0683	.0395	.0743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 205 / 11 KV Bendri - Nimani

GAOTHAN FEEDER

GAONTHA Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.0377		.0373		.0373		.0373
6	.0377		.0377			.0377	.0381
7	.0381	.0754	.0377		.0381	.0381	.0381
8	.0377	.0747	.0381	.0377	.0377	.0377	.0377
9	.0739			.0377	.0381	.0377	.0747
10	.0377	.0362		.0381	.0381	.0377	
11	.0373	.0362		.0377	.0377	.0381	.0377
12	.0381	.0373		.0377			.0381
13	.0377			.0377		.0381	.0747
14		.0381		.0381		.0381	
15				.0377		.0377	
16	.0373	.0377		.0381		.0377	.0381
17		.0377		.0377		.0381	
18	.0373	.0366		.0377		.0366	.0747
19	.0747	.0377		.0754		.0747	.0747
20	.0739	.0762		.0754		.0747	.0754
21	.0747	.0754		.0754		.0754	
22	.0747	.0381		.0366		.0754	.0739
23		.0373		.0377		.0373	
24	.159	.037	.0373	.0381	.037	.0377	.037
Max	.159	.0762	.0381	.0754	.0381	.0754	.0754
Min	.0373	.0362	.0373	.0366	.037	.0366	.037
Avg	.0567	.0474	.0376	.0444	.0377	.0460	.0536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 201 / 11 KV NIMANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.8539	.7811	.8124	.0953	.0762
2	.0953	.0762	.8436	.8065	.8381	.0953	.0762
3	.0953	.0762	.8592	.8002	.8333	.0953	.0762
4	.0953	.0762	.9922	.7842	.8539	.0953	.0762
5	.0953	.0953	1.1702	.7811	.8905	.1143	.0953
6	.1524	.1524	1.2967	.8855	.8905	.1524	.1524
7	.1715	.2096	1.5023	1.1561	.9842	.1905	.2096
8	.1715	.1715	1.7869	1.5655	1.2176	.1524	.2096
9	.1715	.1905	1.7284	1.3916	1.5466	.1524	.1905
10	.5182	.2096		.1524	1.9925	1.1717	1.0722
11	1.9685	.1905	.1905	.1524	2.2024	2.0153	1.7166
12	2.4194	.2286	.2096	.1715	2.1879	2.0241	1.8278
13	2.2725	.2286	.2096	.1715	1.9841	1.9216	1.9044
14	2.3245	.2286	.2286	.1905	2.0165	1.7341	1.8623
15	2.2184	.2286	.2096	.1905	2.0405	1.8027	1.8138
16	2.1664	.2286	.2286	.1905	1.8976	1.6964	1.6804
17	1.6872	.2286	.2286	.1905	1.7497	1.6762	1.6385
18	.0953	.1905	.2286	.2096	.2096	.1524	.1905
19	.1905	.2096	.2286	.2286	.1905	.1905	.1715
20	.1715	.2286	.1905	.2096	.1715	.2096	.1715
21	.1715	.1905	.1524	.1715	.1715	.1905	.1524
22	.1143	.1524	.1334	.1524	.1524	.1524	.1143
23	.0953	.1334	.0953	.1143	.1143	.1143	.0953
24	.0953	.0762	.8697	.759	.7907	.1143	.0762
Max	2.4194	.2286	1.7869	1.5655	2.2024	2.0241	1.9044
Min	.0953	.0762	.0953	.1143	.1143	.0953	.0762
Avg	.7355	.1699	.6277	.5086	1.1141	.6796	.6521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 202 / 11 KV TURACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6802	.5376	.0953	.0572	.0572	.3841	.6081
2	.663	.5601	.0953	.0572	.0572	.3887	.578
3	.6706	.5668	.0762	.0572	.0572	.3658	.5624
4	.6401	.5441	.0762	.0572	.0572	.3749	.5693
5	.6802	.5601	.0953	.0762	.0762	.4481	.5937
6	.9389	.5851	.1143	.0953	.0953	.7545	.7116
7	1.0688	.68	.1334	.1143	.1143	.9339	.828
8	1.0608	.8002	.1143	.1143	.0953	1.0688	1.1574
9	.9556	1.0437	.1143	.0762	.1143	1.1498	1.1248
10	.0762	1.142		.6325	.0953	.0953	.0762
11	.0762	1.1248	1.3592	1.2289	.0953	.0762	.0762
12	.0762	1.2003	1.1888	1.2803	.0762	.0762	.0572
13	.1524	1.2018	1.3279		.0762	.0572	.0572
14	.1715	1.2018	1.1883		.0762	.0762	.0572
15	.1905	1.2186	1.0623	1.1405	.0762	.0572	.0572
16	.1715	1.1717	1.0911	1.1248	.0762	.0572	.0572
17	.1524	1.1227	1.078	1.1069	.0762	.0762	.0762
18	.0762	.1334	.0953	.0953	.0953	.0762	.0762
19	.0762	.1334	.0953	.1143	.1143	.0953	.0953
20	.0953	.1334	.0953	.1524	.0953	.0953	.0953
21	.0953	.1143	.0762	.1143	.0953	.0953	.0953
22	.0953	.1143	.0762	.0953	.0762	.0762	.0762
23	.0762	.0953	.0762	.0762	.0572	.0762	.0572
24	.7611	.4801	.0953	.0572	.0572	.4374	.6167
Max	1.0688	1.2186	1.3592	1.2803	.1143	1.1498	1.1574
Min	.0762	.0953	.0762	.0572	.0572	.0572	.0572
Avg	.4042	.6861	.4270	.3602	.0818	.3080	.3483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 203 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.168	.1867	.1509	.1509	.1307	.1509
2	.1509	.1509	.1698	.1509	.1509	.132	.1509
3	.1509	.1509	.1698	.132	.1663	.132	.132
4	.1509	.1509	.2263	.1509	.1646	.132	.132
5	.1886	.1886	.2801	.3961	.2054	.1698	.1698
6	.4344	.4668	.4668	.3921	.3142	.4066	.4294
7	.5359	.5601	.5601	.499	.4715	.5121	.5175
8	.5487	.499	.5121	.5121	.5121	.5068	.5304
9	.3511	.3403	.3045	.3658	.3475	.3292	.3258
10	.2427	.2658		.3326	.2012	.2534	.2328
11	.2229	.298	.2103	.2896	.197	.2149	.2103
12	.2105	.2401	.2195	.2534	.1928	.2328	.2172
13		.1844	.2149	.2534	.2172	.1907	.2328
14	.2254	.1823	.1991	.2195	.181	.1875	.2103
15	.2058	.1619	.2328	.2172	.2328	.1844	.2353
16	.2279	.1781	.2572	.2378	.2279	.2058	.2534
17	.2835	.2155	.2454	.2402	.2715	.2347	.2715
18	.2865	.2629	.2347	.2534	.3475	.2683	.3077
19	.4755	.5014	.4572	.4572	.4938	.5194	.5175
20	.5121	.5175	.499	.4854	.4755	.5487	.5359
21	.4805	.462	.4251	.4108	.4435	.4251	.4251
22	.3174	.3361	.3174	.3326	.3511	.3206	.3174
23	.2241	.2218	.2241	.2241	.2241	.2452	.2427
24	.7983	.1867	.1867	.168	.168	.168	.1698
Max	.7983	.5601	.5601	.5121	.5121	.5487	.5359
Min	.1509	.1509	.1698	.132	.1509	.1307	.132
Avg	.3207	.2871	.2956	.2969	.2795	.2771	.2883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 204 / 11 kv RAJAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2742	1.0242	.0762	.0762	.0572	.9717	1.0623
2	1.1984	.9488	.0762	.0572	.0572	.852	1.0311
3	1.1843	.9145	.0572	.0572	.0572	.852	1.0279
4	1.1561	.884	.0572	.0572	.0762	.8421	.9877
5	1.2308	.8951	.0762	.0762	.0953	.8749	1.0311
6	1.3592	.9214	.1143	.1143	.1334	1.1012	1.0648
7	1.6004	1.0974	.1334	.1715	.1524	1.2955	1.3279
8	1.7436	1.2654	.1334	.1524	.1524	1.5623	1.7078
9		1.5779	.1524	.1143	.1334	1.6644	1.656
10		1.7438		1.4232	.1524	.0762	.0762
11		1.7966	2.1765	1.8947	.1334	.0953	.0762
12		1.8343	2.0083	1.9292	.1143	.1143	.0953
13	.1143	1.8122	1.8122	1.9524	.1143	.0953	.0953
14	.0953	1.7497	1.8027	1.9524	.0953	.1524	.1334
15	.0953	1.7124	1.8747	1.8501	.0953	.1334	.1143
16	.0953	1.6288	1.713	1.8747	.0953	.1524	.0953
17	.0953	1.4883	1.6404	1.866	.0953	.1524	.0953
18	.1143	.0762	.0572	.0953	.1143	.1524	.1143
19	.1524	.1143	.1524	.1143	.0953	.1524	.1143
20	.1334	.1143	.1334	.1524	.0953	.1334	.0953
21	.1334	.0953	.1334	.1334	.0953	.1143	.0762
22	.0953	.0953	.1143	.1143	.0572	.1715	.0572
23	.0762	.0762	.0953	.0953	.0572	.0953	.0572
24	1.3748	1.0562	.0762	.0762		1.0242	1.0595
Max	1.7436	1.8343	2.1765	1.9524	.1524	1.6644	1.7078
Min	.0762	.0762	.0572	.0572	.0572	.0762	.0572
Avg	.6661	1.0384	.6377	.6834	.1011	.5346	.5522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 205 / 11 KV Nimani Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.1052	.1132	.0914	.0943	.1132
2	.0943	.0943	.0867	.0943	.0886	.0943	.1132
3	.0943	.0943	.0886	.0943	.0905	.0943	.0943
4	.0943	.0943	.1063	.0943	.1086	.0943	.0943
5	.1132	.1132	.1791	.132	.1433	.1509	.132
6	.2801	.2829	.2507	.2427	.2303	.3174	.2801
7	.3841	.3547	.3721	.3547	.3658	.3734	.3696
8	.3077	.3142	.3045	.3109	.3189	.2957	.3292
9	.2353	.197	.208	.2353	.197	.1991	.197
10	.1646	.1595		.1612	.1595	.1402	.124
11	.1097	.1227	.1417	.1254	.1267	.0876	.1075
12	.1448	.12	.1227	.0886	.1075	.0709	.0876
13	.124	.1134	.1029	.1063	.1052	.1052	.1075
14	.1402	.112	.12	.1448	.0716	.0857	.1086
15	.1254	.1134	.1227	.1463	.0724	.1052	.1086
16	.1267	.112	.124	.124	.0732	.104	.1075
17	.1463	.128	.1433	.1448	.1063	.124	.1267
18	.1829	.1989	.1448	.1629	.1612	.1402	.1829
19	.2957	.2947	.2957	.3109	.2715	.2743	.3475
20	.3326	.3582	.3142	.3224	.3292	.3326	.3109
21	.3174	.3012	.2957	.2715	.2957	.2987	.2743
22	.2241	.2149	.2241	.2353	.2033	.2452	.2218
23	.1509	.1417	.1494	.1829	.168	.1698	.1494
24	.1132	.1132	.1052	.1132	.1086	.1132	.132
Max	.3841	.3582	.3721	.3547	.3658	.3734	.3696
Min	.0943	.0943	.0867	.0886	.0716	.0709	.0876
Avg	.1832	.1768	.1786	.1797	.1664	.1713	.1758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi)

Feeder No / Name : 201 / 11 KV MALWADI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0629	.0457	.0734	.0547	.064	.0838	.06
2	.0629	.0457	.0734	.056	.061	.0734	.06
3	.0629	.0503	.0734	.056	.0533	.0734	.0549
4	.0629	.0503	.0734	.0613	.0533	.0734	.0488
5	.0629	.0652	.0734	.0587	.0467	.0734	.0457
6	.0629	.072	.0734	.052	.0533	.0734	.0457
7	.0734	.0772	.0734	.0547	.0564	.0943	.0427
8	.0734	.048	.0838	.052	.0579	.0943	
9	.0734	.032		.0669	.0789	.0943	.0518
10	.0943		.0943	.0772	.181	.1448	.1698
11	.1429	.1629	.1181	.1235	.1991	.1578	.1698
12	.2012	.2172	.1739	.1562	.2172	.1718	.2614
13	.2012	.2172	.1753	.1353	.2172	.1718	.2241
14	.1829	.2172	.1509	.1802	.2172	.1718	.2096
15	.1337	.2172	.0945	.2427	.1991	.1524	.1494
16	.1006	.1629	.0793	.1166	.181	.1698	.1867
17	.1183	.1629	.1052	.0823	.181	.0701	.1478
18	.0669	.1267	.0693	.0995		.0686	.064
19	.0772	.1267	.068	.0747		.0686	.0412
20	.0762	.1267	.0613	.0703	.1629	.0686	.084
21	.0686	.1267	.068	.0772	.181	.072	.0857
22	.0686	.1267	.0974	.0747	.1629	.0789	.1315
23	.0617	.0734	.1014	.0655	.1448	.0686	.1257
24	.1267	.06	.0734	.0934	.064	.1448	.0669
Max	.2012	.2172	.1753	.2427	.2172	.1718	.2614
Min	.0617	.032	.0613	.052	.0467	.0686	.0412
Avg	.0966	.1135	.0925	.0909	.1288	.1048	.1099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi)

Feeder No / Name : 203 / 11 KV MALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5668	.3593	.1134	.0724	.0895	1.3765	.6062
2	.5668	.3637	.1134	.0724	.0905	.7287	.6464
3	.5668	.3163	.1134	.0732	.0905	.7287	.6718
4	.5668	.3521	.1134	.0739	.1097	.7287	.6964
5	.5668	.3841	.1134	.0934	.128	.7287	.7287
6	.5668	.4372	.1619	.1509	.1646	.7287	.7682
7	.6964	.502	.2105	.1494	.1848	.8583	.8322
8	.583	.6241	.1619	.1663	.1663	1.0364	
9	.5506	.8381	.1134	.1448	.1254	1.085	.9217
10	.0648	1.267	.8097	.9555	.0905	.0655	.0876
11	.0686	1.5746	1.3283	1.4089	.0905	.0686	.0469
12	.0886	1.5927	1.2967	1.3927	.1086	.0876	.0648
13	.0886	1.5927	1.3435	1.4083	.1086	.0876	.0617
14	.1075	1.5746	1.1431	1.3927	.1086	.0686	.0829
15	.1254	1.5384	1.3117	1.3283	.1086	.0678	.0663
16	.1433	1.5384	1.2944	1.2191	.1086	.0701	.064
17	.1433	1.4118	1.1138	1.1385	.0905	.0867	.0895
18	.1595	.1086	.1006	.0819	.1086	.081	.0829
19	.1629	.1629	.1448	.1097	.1448	.1267	.1463
20	.1663	.1629	.1663	.1097	.1448	.1448	.128
21	.1663	.1629	.1478	.1097	.1086	.128	.1097
22	.1478	.1629	.1097	.1097	.1086	.1097	.1097
23	.128	.1134	.0724	.0895	.1086	.0914	.0716
24	.543	.3749	.1094	.0724	.0895	.543	.5735
Max	.6964	1.5927	1.3435	1.4089	.1848	1.3765	.9217
Min	.0648	.1086	.0724	.0724	.0895	.0655	.0469
Avg	.3139	.7298	.4878	.4968	.1157	.4095	.3329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 201 / 11 KV ARWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	1.3245		.2458		.2294		1.5424
6	1.576		.3149		.2486	1.9006	1.7101
7	1.9113	1.5249	.3481		.2458	2.2348	2.146
8	1.9113	1.8233	.2785	.3315	.3149	2.5232	2.2874
9	1.7604			.3149	.3052	2.2939	2.2377
10	.1943	2.431		2.146	.2713	.1966	
11	.2267	2.5987		2.9843	.2804	.2458	.1296
12		1.9281		3.1184		.1989	.2267
13				2.8837		.213	.2105
14		2.5987		3.0849		.2321	
15				3.0346		.2458	
16	.1296	2.4086		3.1017		.1966	.2429
17		2.2119		2.8669		.2486	
18	.2881	.2105		.1966		.2949	.2753
19	.3725	.3768		.2949		.3441	.3077
20	.3077	.3647		.3077		.3149	.3077
21	.2915	.3441		.2785		.3113	
22	.2753			.2294		.2818	.2561
23		.2785		.1943		.2294	
24	1.3748	1.2266	.2321	.1966	.213	1.4419	1.3763
Max	1.9113	2.5987	.3481	3.1184	.3149	2.5232	2.2874
Min	.1296	.2105	.2321	.1943	.213	.1966	.1296
Avg	.8531	1.4519	.2839	1.5038	.2636	.7341	.9469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 204 / 11 KV DHAVLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.0183		1.0364		.7754		.016
6	.04		1.2346		.8177	.1677	.0206
7	.0272	.0229	1.5741		1.0551	.04	.0297
8	.0545	.0305	1.9134	1.6842	1.3696	.0343	.0257
9	.0524			1.692	1.749	.0438	.0333
10	1.9524	.0362		.0307	1.9227	1.6129	
11	2.4806	.0495		.0293	2.0645	2.2565	1.3435
12	2.4806	.0396		.0429			1.8185
13	2.4966			.0387		2.3205	1.9685
14		.0381		.0347		2.2405	
15				.0396		2.2085	
16	2.2885	.0413		.0387		2.1125	1.7185
17		.0503		.0488		1.9685	
18	.0686	.0579		.0667		.0457	.029
19	.0671	.0608		.0572		.0524	.048
20		.0457		.0587		.04	.0381
21	.0394	.044		.0377		.032	
22	.0307	.0366		.0366		.0307	.0472
23		.0274		.0389		.0248	
24	.0257	.0162	1.0385	1.0562	.8362	.1402	.0162
Max	2.4966	.0608	1.9134	1.692	2.0645	2.3205	1.9685
Min	.0183	.0162	1.0364	.0293	.7754	.0248	.016
Avg	.8082	.0398	1.3594	.2960	1.3238	.8540	.5109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 212 / 11 KV NIMANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.9332		.0381		.0747		.884
6	1.0311		.0762		.0762	1.1523	.9374
7	1.2186	1.1203	.0754		.1132	1.4419	1.1248
8	1.1439	1.1523	.112	.112	.0747	1.5939	1.3123
9	1.0669			.1132	.0739	1.4548	1.3748
10	.0732	1.6644		1.4403	.112	.0739	
11	.0732	1.8785		1.8138	.1494	.0747	.1848
12	.0732	1.7924		1.9109			.1463
13				1.8244		.0732	.0366
14		1.6644		1.7166		.0739	
15				1.6964		.1097	
16	.0747	1.6446		1.7284		.1086	
17		1.4373		1.6446		.1075	
18	.112	.0671		.0678		.1029	.104
19	.1109	.1109		.1109		.1463	.1109
20	.1097	.1086		.112		.1478	.1109
21		.1109		.112		.1097	
22	.0732	.1109		.0739		.1075	.1086
23		.0724		.0739		.0716	
24	1.0837	.8855	.0754	.0701	.0377	1.0486	.9998
Max	1.2186	1.8785	.112	1.9109	.1494	1.5939	1.3748
Min	.0732	.0671	.0381	.0678	.0377	.0716	.0366
Avg	.5127	.9214	.0754	.8601	.0890	.4444	.5719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 401 / 33KV Hatnoor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	2.037		2.1502		2.1502		2.0165
6	2.6029		2.8292		2.7435	2.8292	2.4897
7	2.8292	2.8578	2.6292		2.7435	2.8292	2.6292
8	2.8292	2.9424	2.6029	2.7161	2.8292	2.7161	2.8578
9	2.7161			2.7161	2.8292	2.7161	2.7161
10	2.7161	2.8006		2.4897	2.9127	2.4897	
11	2.6886	2.6029		2.4646	2.8292	2.3765	2.8006
12	2.8235	2.3525		2.5766			2.7721
13	2.3525			2.5766		1.9433	1.3032
14		2.4897		2.2405		1.9433	
15				2.3525		1.829	
16	2.6612	2.6337		2.6886		2.0576	2.8532
17		2.8829		2.7161		2.3765	
18	3.1047	2.8829		2.8006		2.4897	3.1047
19	3.6969	3.5848		3.4728		3.2819	3.6969
20	3.1687	3.0556		3.2819		3.0556	3.1687
21	2.8292	2.7435		2.9424		2.8578	
22	2.5149	2.4006		1.9239		2.5149	2.6292
23		1.9044		2.037		2.1502	
24	2.037	2.1502	1.9805	2.037	1.9044	2.1502	2.0165
Max	3.6969	3.5848	2.8292	3.4728	2.9127	3.2819	3.6969
Min	2.037	1.9044	1.9805	1.9239	1.9044	1.829	1.3032
Avg	2.7255	2.6856	2.4384	2.5902	2.6177	2.4782	2.6467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 406 / 33 KV Sut Girani

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
23	1.8484
24	1.4146
Max	1.8484
Min	1.4146
Avg	1.6315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 201 / 11 KV KASABE DIGRAJ

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2353	.2263	.3077	.2263	.2427	.2641
2	.3395	.2353	.2263	.3077	.2263	.2427	.2641
3	.3395	.2353	.2641	.3077	.2263	.2427	.2641
4	.3395	.2353	.2641	.3077	.2263	.2427	.2829
5	.3772	.2353	.2641	.4525	.2452	.4938	.3584
6	.5093	.362	.3772	.5552	.3395	.6154	.3584
7	.6036	.3761	.415	.567	.3395	.5731	.3961
8	.5281	.3403	.415	.3982	.3772	.6335	.3772
9	.5281	.5014	.5847	.5552	.415	.5304	.3772
10	.3395	.5788	.3772	.5415	.4527	.4668	.3772
11	.3584	.5415	.4527	.5788	.5093	.3584	.4904
12	.3018	.3734	.4715	.3961	.5975	.3772	.5658
13	.2641	.3921	.3206	.5093	.415	.3018	.3018
14	.3018	.3734	.4715	.5658	.4338	.2263	.4527
15	.3018	.6161	.547	.4904	.3206	.2075	.3584
16	.2641	.3547	.6036	.4527	.4715	.2452	.5658
17	.3206		.4854	.5281	.5093	.2075	.4527
18	.4477	.6036	.4525	.4527	.4755	.3206	.415
19	.7619	.7922	.5194	.7922	.7059	.4527	.7167
20	.5014	.6036	.691	.7167	.7343	.4715	.7167
21	.5373	.679	.6733	.6036	.5792	.4338	.6224
22	.6201	.6413	.3761	.5093	.5792	.3961	.5847
23	.5014	.5658	.3258	.4715	.5041	.3206	.4338
24	.3584	.2353	.2641	.3077	.3772	.2427	.2829
Max	.7619	.7922	.691	.7922	.7343	.6335	.7167
Min	.2641	.2353	.2263	.3077	.2263	.2075	.2641
Avg	.4202	.4394	.4195	.4865	.4286	.3686	.4283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0747	.2713	.3005	.3429	.0747	.0754
2	.0754	.0747	.2713	.3005	.3429	.0747	.0754
3	.0754	.0747	.2713	.3005	.3429	.0747	.0754
4	.0754	.0747	.2713	.3005	.3772	.0747	.0754
5	.0754	.0747	.2713	.3005	.3772	.0747	.0754
6	.0754	.0747	.3052	.3163	.3772	.0747	.0754
7	.0754	.0747	.3561	.3593	.3944	.0747	.0754
8	.0754	.0747	.373	.3858	.4115	.0747	.0754
9	.0754	.0747	.407	.3858	.547	.056	.0754
10	.6613	.0566	.0566	.0566	.5487	.5596	.7545
11	.6783	.0566	.0566	.0566	.6173	.7122	.78
12	.6443	.0566	.0754	.0754	.6516	.7291	.8478
13	.6613	.0566	.0754	.0754	.6613	.7291	.8648
14	.703	.0566	.0754	.0754	.6516	.6952	.8309
15	.6104	.0566	.0754	.0754	.6443	.6952	.8139
16	.5935	.0566	.0754	.0754	.6344	.6613	.7202
17	.5596	.0566	.0754	.0754	.583	.6613	.6613
18	.056	.0566	.056	.0566	.0747	.0566	.0754
19	.0747	.0754	.056	.0566	.0747	.0754	.0754
20		.0754	.0747	.0566	.0747	.0754	.0754
21	.0747	.0754	.0747	.0566	.0747	.0754	.0754
22	.0747	.0566	.0747	.0566	.0747	.0754	.0754
23	.0747	.0566	.0747	.0566	.0747	.0754	.0754
24	.1564	.0747	.2883	.3005	.3258	.0747	.0754
Max	.703	.0754	.407	.3858	.6613	.7291	.8648
Min	.056	.0566	.056	.0566	.0747	.056	.0754
Avg	.2740	.0665	.1693	.1731	.3866	.2752	.3117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 203 / 11 KV TUNG GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1097	.0914	.0914	.0732	.0924	.0732
2	.0914	.1097	.0914	.0914	.0732	.0924	.0732
3	.0914	.1097	.0914	.0914	.0732	.0924	.0732
4	.1097	.1097	.0914	.0914	.0914	.0924	.0914
5	.1829	.1097	.128	.1463	.1829	.1097	.2012
6	.2561	.2743	.2743	.2534	.2743	.2172	.2561
7	.2561	.2896	.2926	.2686	.2561	.2534	.2926
8	.2378	.2715	.2378	.2534	.2561	.2172	.2743
9	.2012	.2353	.1829	.2172	.2012	.2012	.2195
10	.2561	.1463	.2012	.2012	.2195	.1646	.1829
11	.1646	.1829	.1463	.2012	.2012	.1829	.1829
12	.1829	.1829	.1463	.1646	.1829	.1463	.1463
13	.1829	.1646	.2012	.1463	.1646	.0732	.128
14	.1463	.1463	.1646	.1646	.1829	.1463	.1463
15	.128	.1132	.1097	.1646	.1097	.0914	.1646
16	.128	.1132	.112	.1829	.0914	.0914	.1829
17	.1646	.1698	.1886	.1829	.1829	.1463	.2012
18	.181	.2075	.2195	.2012	.2012	.1463	.2195
19	.2896	.3018	.2715	.2926	.2896	.2743	.2926
20		.2743	.2715	.2378	.2896	.2561	.2743
21	.2534	.2561	.2561	.2743	.2534	.2561	.2378
22	.2353	.2012	.2195	.2012	.2172	.2195	.2012
23	.181	.1463	.1646	.1646	.1629	.1646	.1463
24	.0914	.1463	.1097	.0914	.0732	.1097	.0914
Max	.2896	.3018	.2926	.2926	.2896	.2743	.2926
Min	.0914	.1097	.0914	.0914	.0732	.0732	.0732
Avg	.1784	.1822	.1776	.1823	.1793	.1599	.1814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 205 / 11 KV TUNG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0373	.5093	.5155	.5898	.0373	.0754
2	.0566	.0373	.5093	.5155	.5898	.0373	.0754
3	.0566	.0373	.5093	.5155	.5898	.0373	.0754
4	.0566	.0373	.5093	.5155	.6226	.0373	.0754
5	.0566	.0373	.5093	.5155	.6226	.0373	.0754
6	.0566	.0373	.5556	.5312	.6226	.0373	.0754
7	.0566	.056	.7099	.679	.7373	.056	.0754
8	.0566	.056	.8796	.7773	.8848	.056	.0754
9	.0754	.056	.8333	.9297	1.1022	.056	.0754
10	1.1961	.0754	.0754	.0377	1.3904	1.0322	1.3108
11	1.3927		.0754	.0566	1.4413	1.3108	1.3927
12	1.4255		.0754	.0566	1.291	1.3927	1.491
13	1.3272	.0754	.0754	.0566	1.3592	1.2163	1.491
14	1.2631	.0754	.0754	.0566	1.2763	1.2289	1.3599
15	1.2125	.0943	.0943	.0566	1.3272	1.2323	1.3599
16	1.1822	.0943	.0943	.0754	1.3426	1.1683	1.2308
17	1.1043	.0943	.1132	.0943	1.2929	1.1683	1.2631
18	.0747	.0943	.0934	.0754	.056	.0943	.0566
19	.056	.0754		.0754	.056	.0754	.0566
20	.056	.0754	.0747	.0754	.0747	.0754	.0566
21	.056	.0754	.0747	.0754	.0747	.0754	.0566
22	.056	.0566	.056	.0754	.056	.0754	.0566
23	.0373	.0566	.056	.0754	.056	.0754	.0566
24	.0566	.0373	.4938	.5155	.5571	.0373	.0754
Max	1.4255	.0943	.8796	.9297	1.4413	1.3927	1.491
Min	.0373	.0373	.056	.0377	.056	.0373	.0566
Avg	.4594	.0624	.3066	.2897	.7505	.4438	.4997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 206 / 11 KV VASANT LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.1063	.2075	.0686	.0943	.0566
2	.0566	.1063	.2075	.0686	.0943	.0566
3	.0566	.1063	.2075	.0686	.0943	.0566
4	.0566	.1063	.2075	.0686	.0943	.0566
5	.0566	.1052	.2075	.0686	.0943	.1509
6	.0566	.2279	.1886	.0876	.1509	.1509
7	.2641	.2743	.1886	.1696	.1886	.2263
8	.2641	.2915	.3206	.3401	.3961	.3395
9	.2641	.2915	.415	.3841	.5658	.3395
10	.3961	.3206	.4338	.5281	.6036	.3395
11	.3961	.3772	.5281	.5847	.5658	.5847
12	.3772	.3772	.5093	.5847	.5658	.5847
13	.3772	.3584	.5093	.5658	.5658	.5847
14	.3772	.3584	.4715	.5847	.5658	.5847
15	.3584	.3584	.3961	.5847	.5658	.5847
16	.3395	.3395	.415	.5281	.5658	.5658
24	.0566					
Max	.3961	.3772	.5281	.5847	.6036	.5847
Min	.0566	.1052	.1886	.0686	.0943	.0566
Avg	.2241	.2566	.3383	.3303	.3607	.3289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 201 / 11 KV Mouje Digraj Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0187		.0189		
2			.0183				
3			.0187				
4			.0187	.0187			
5			.0187		.0187		
6			.0187	.0187	.0187		
7			.0187	.0187	.0187		
8			.0187	.0185	.0187		
9			.0187	.0187	.0187		
10	.0162				.0373	.0187	.0164
11	.0324				.0373		.016
12	.0158				.0373		.016
13	.0316				.0373		.0316
14	.0316				.0373		.0316
15	.0316				.0373	.0187	.016
16	.0316				.0373	.0187	.016
17	.0324				.0366	.0187	.016
23		.0187	.0187				
24			.0187	.0187			
Max	.0324	.0187	.0187	.0187	.0373	.0187	.0316
Min	.0158	.0187	.0183	.0185	.0187	.0187	.016
Avg	.0279	.0187	.0187	.0187	.0293	.0187	.0200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 203 / 11 KV PWV BRAMHNAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.1463	.2801		.1867	.0934	.0187
2	.0716	.1463	.2801			.0934	.0187
3	.0716	.2401	.2801			.2572	.0187
4	.0716	.2572	.2801	.1867		.2572	.0187
5	.0716	.2572	.2801		.2987	.2572	.0373
6	.0716	.2572	.2801	.2987	.3174	.2572	.1307
7	.1307	.2572	.2801	.3174	.3174	.2572	.1307
8	.1307	.3366	.2801	.3361	.3174	.2572	
9	.1254	.2743	.2427	.3361	.3174	.2572	.0934
10	.1307	.2743	.112	.3361	.2241	.0934	.112
11	.1307	.2715	.0373	.3547	.2241		.112
12	.1463	.2195	.0189		.2241		.0934
13	.0895	.2195		.0754	.0934		.0934
14	.0895	.2195	.0754		.0934		.0934
15	.2629	.0934	.0373	.0747	.0934	.0187	.0934
16	.0914	.0934	.0373	.0747	.0934	.0187	.0934
17	.0566	.1494	.0189	.0187	.0934	.0187	.0934
18	.0566	.1463	.0189	.0747	.0934	.056	.0934
19	.0566	.2427	.2054	.0747	.0934	.1494	
20	.0566	.2427			.0934	.1494	
21	.0566	.2427	.2054	.1307	.0934	.056	
22	.1478	.2427			.0934	.0373	
23	.1478	.2427	.2054		.0934	.0187	
24	.4908		.2427		.0934		.0187
Max	.4908	.3366	.2801	.3547	.3174	.2572	.1307
Min	.0566	.0934	.0189	.0187	.0934	.0187	.0187
Avg	.1178	.2206	.1761	.1921	.1690	.1370	.0757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 204 / 11 KV EXPRESS LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2172	.2987		.0924	
2	.2241	.2172	.2987			.2241
3	.2172	.2172	.2987			
4	.2172	.2172	.2987	.0747		.2241
5	.2172	.2172	.2987		.0934	.2241
6	.2172	.2172	.2987	.0934	.0934	.2614
7	.362	.2172	.2987	.0934	.0934	.2241
8	.362	.3142	.2987	.0914	.0934	
9	.362	.3361	.2987	.0924	.0934	.2241
10	.362	.3361	.3292	.0924	.0934	.2427
11	.3439	.3361	.3475	.0934	.0934	.2427
12	.3547	.3361	.3511		.0934	.2427
13	.3439	.3361		.0934	.0934	.2987
14	.3439	.3361	.3511		.0934	.2987
15	.3475	.2987	.3475	.0934	.112	.2987
16	.3475	.2987	.3326	.0934	.112	.2987
Max	.362	.3361	.3511	.0934	.112	.2987
Min	.2172	.2172	.2987	.0747	.0924	.2241
Avg	.3029	.2780	.3165	.0911	.0962	.2542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 205 / 11 KV YESHWANT EXPRESS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8505	.8859	1.0974		.7316	
2	.8505	.8859	1.0974			.2587
3	.8505	.8859	1.0974			
4	.8954	.8859	1.0974	.8779		.2561
5	.9134	.9134	1.1203		.8688	.2561
6	.9134	.9134	1.1203	1.0136	.8779	.4344
7	.8954	1.0924	1.0974	1.267	.905	.3982
8	1.2178	1.2308	1.3717	1.6095	1.2071	
9	1.3466	1.4632	.4534	1.5565	1.267	.7602
10	1.4175	1.4632	1.3756	1.6461	1.3169	1.1706
11	1.3643	1.4632	1.5565	1.6632	1.3169	1.1706
12	1.4529	1.4937	1.5364		1.3169	1.1584
13	1.2757	1.4937		1.6632	1.3443	1.0974
14	1.2757	1.4937	1.4842		1.3443	1.0974
15	1.2757	1.4937	1.5364	1.6461	1.1203	1.1203
16	1.0277	1.4937	1.0242	1.3676	1.1203	.7316
17					1.1203	
24	.1715					
Max	1.4529	1.4937	1.5565	1.6632	1.3443	1.1706
Min	.1715	.8859	.4534	.8779	.7316	.2561
Avg	1.0585	1.2220	1.2044	1.4311	1.1327	.7623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 206 / 11 KV NAWARASWADI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0886	.2054		.4344	
2	.0886	.0886	.2054			.0914
3	.0886	.0886	.2054			
4	.0886	.0886	.2054	.3439		.0895
5	.0886	.0876	.2054		.4706	.0905
6	.0886	.0876	.2054	.3292	.4706	.0905
7		.0876	.2054	.3292	.4656	.2229
8		.1227	.3547	.3292	.4656	
9		.2303	.3475	.3292	.4607	.0354
10		.2303	.3326	.3258	.4755	.2686
11	.0867	.2303	.3326	.3292	.4755	.2715
12	.1772	.3258	.3292		.4755	.2715
13	.2303	.3258		.2534	.4755	.2926
14	.2303	.3258	.3292		.4755	.2926
15	.2303	.3292	.3189	.3155	.4755	.2926
16	.2303	.3292	.362	.3582	.4755	.2987
Max	.2303	.3292	.362	.3582	.4755	.2987
Min	.0867	.0876	.2054	.2534	.4344	.0354
Avg	.1431	.1917	.2763	.3243	.4689	.2006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244037 / 33/11 KV PRAKASH AGRO

Feeder No / Name : 201 / 11 KV HARIPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3637	.4372	.0189	.0189	.0189	.5668	.4744
2	.3479	.4372	.0189	.0189	.0189	.5601	.4531
3	.3437	.4372	.0189	.0189	.0189	.5376	.442
4	.3681	.4372	.0189	.0189	.0189	.5441	.4572
5	.3361	.4534	.0189	.0189	.0189	.5506	.4321
6	.3401	.4641	.0377	.0189	.0189	.5506	.4374
7	.427	.4801	.0189	.0189	.0189	.5937	.4877
8	.4064	.5376	.0377	.0189	.0189	.6642	.587
9	.4161	.68	.0377	.0189	.0189	.6562	.6327
10	.0189	.8259	.7682	.9231	.0189	.0189	.0189
11	.0189	.8029	1.0486	1.1336	.0189	.0189	.0189
12	.0189	.9878	1.1498	1.2146	.0189	.0189	.0189
13	.0189	1.0242	1.166	1.1683	.0189	.0189	.0189
14	.0189	1.0562	1.1498	1.1336	.0189	.0189	.0189
15	.0189	.9717	1.1336	1.1174	.0189	.0189	.0189
16	.0189	.9686	1.1043	1.0623	.0189	.0189	.0189
17	.0189	1.004	1.1174	1.0031	.0189	.0189	.0189
18	.0189	.0189	.0189	.0189	.0189	.0189	.0189
19	.0189	.0189	.0189	.0189	.0189	.0189	.0189
20	.0189	.0189	.0189	.0377	.0189	.0189	.0189
21	.0189	.0189	.0189	.0377	.0189	.0189	.0189
22	.0189	.0189	.0189	.0189	.0189	.0189	.0189
23	.0189	.0189	.0189	.0189	.0189	.0189	.0189
24	.3749	.421	.0189	.0189	.0189	.4534	.4586
Max	.427	1.0562	1.166	1.2146	.0189	.6642	.6327
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.1662	.5225	.3749	.379	.0189	.2476	.2136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 201 / 11 KV DUDHGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.25	.2134	.0152	.0175	.0158	.3048	.2846
2	.2315	.2187	.0152	.0177	.0151	.3086	.2812
3	.2343	.2187	.0152	.0171	.0154	.3086	.3005
4	.2134	.216	.0152	.0175	.0158	.3086	.3125
5	.1875	.2134	.0152	.0171	.016	.3353	.3395
6	.2006	.2214	.0152	.0173	.0168	.4062	.3479
7	.2343	.2241	.0152	.0175	.0175	.4374	.3637
8	.2315	.3125	.0152	.0171	.017	.4515	.3681
9	.2187	.3658	.0152	.017	.0171	.4214	.3795
10	.0171	.4877	.5801	.639	.0162	.0177	.0152
11	.0171	.5792	.7209	.7202	.0162	.0168	.0152
12	.0175	.5792	.7127	.7449	.016		.0152
13	.0171	.5792	.7209	.68	.0133		.0152
14	.0152	.5487	.7202	.6401	.0137		.0152
15	.0156	.5182	.6874	.0995	.0137	.0171	.0152
16	.0154	.4877	.6783	.5937	.0133	.017	.0152
17	.016	.4725	.6443	.5761	.0141	.0166	.0154
18		.0152	.0164	.0135	.0133	.0133	.0152
19	.0175	.0152	.0162	.0173	.0171	.0175	.0152
20	.0173	.0152	.0164	.0173	.0175	.0162	.0152
21	.0175	.0152	.0162	.017	.0173	.016	.0152
22	.0175	.0152	.0158	.0164	.0173	.0158	.0152
23	.0173	.0152	.0158	.0156	.0171	.016	.0152
24	.3991	.1353	.0152	.016	.0168	.2469	.2846
Max	.3991	.5792	.7209	.7449	.0175	.4515	.3795
Min	.0152	.0152	.0152	.0135	.0133	.0133	.0152
Avg	.1139	.2785	.2381	.2068	.0158	.1766	.1448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 202 / 11 KV KAVATHE PIRAN

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1886	.1867	.2033	.2033	.1886	.1867
2	.1886	.1886	.1867	.1867	.1867	.1886	.1867
3	.2241	.1886	.1867	.1829	.1867	.1867	.1886
4	.1867	.1886	.1867	.1848	.2054	.1886	.1867
5	.2263	.1886	.1867	.2195	.2452	.2263	.3395
6	.3361	.3361	.4481	.3326	.3734	.415	.3921
7	.4715	.415	.4854	.439	.5093	.4854	.4904
8	.415	.3395	.4294	.4435	.3961	.415	.4338
9	.3547	.2987	.3174	.4251	.3361	.415	.3961
10	.2587	.2614	.3292	.3326	.3395	.3326	.3361
11	.2641	.2241	.2772	.3403	.2641		.2987
12	.2641	.2054	.2772	.3045	.3018		.2987
13	.2263	.1867	.2614	.2507	.2218		.2801
14	.1886	.1867	.2614	.2743	.2263		.2614
15	.1886	.1867	.2587	.2378	.1886	.2987	.2427
16	.1509	.2427	.2957	.2534	.2263	.2587	.2427
17	.1509	.2614	.3142	.3045	.2987	.3045	.2987
18	.2641	.2658	.3511	.2865	.3018	.3761	.3361
19	.415	.4854	.5175	.4435	.4904	.5359	.4854
20	.415	.4854	.4805	.4805	.4904	.5544	.4854
21	.415	.4294	.4572	.4668	.4527	.5544	.4294
22	.3018	.3921	.2957	.3511	.415	.462	.3734
23	.2263	.2614	.2561	.2427	.2614	.3658	.3361
24	.1886	.1886	.1867	.2012	.2241	.1886	.2772
Max	.4715	.4854	.5175	.4805	.5093	.5544	.4904
Min	.1509	.1867	.1867	.1829	.1867	.1867	.1867
Avg	.2704	.2748	.3097	.3078	.3060	.3470	.3243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 203 / 11 KV KAVATHE PIRAN AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.583	.0114	.0093	.009	.6859	.6516
2	.5256	.583	.0114	.0095	.0091	.6859	.6661
3	.5144	.5765	.0114	.0097	.0095	.6859	.691
4	.5197	.583	.0114	.0099	.0093	.6859	.691
5	.5426	.583		.0095	.0097	.6859	.6836
6	.5316	.6173	.0114	.0099	.0101	.7202	.7087
7	.5426	.6859	.0114	.0101	.0109	.7461	.6859
8	.5197	.7545	.0114		.0093	.8048	.7059
9	.5087	.9835	.0114	.0088	.0091	.7461	.6805
10	.0111	1.2517	.8573	1.1831	.0111	.009	.0114
11	.0103	1.2174	1.0974	1.17	.0109	.0088	.0114
12	.0101	1.1831	1.0974	1.286	.0111		.0114
13	.0099	1.166	1.1317	1.2887	.0107		.0114
14	.0103	1.1145	1.1443	1.2209	.0107		.0114
15	.0097	1.0631	1.1317	1.17	.0099	.009	.0114
16	.0099	.9945	1.0117	1.153	.0101	.0091	.0114
17	.0099	.9774	.9602	1.166	.0099	.0086	.0114
18	.0097		.009	.0093	.0099	.0107	.0114
19	.0103	.0114	.0088	.009	.0103	.0107	.0114
20	.0099	.0114	.009	.009	.0103	.0109	.0114
21	.0103	.0114	.009	.009	.0097	.0107	.0114
22	.0099	.0114	.0088	.0088	.0101	.0107	.0114
23	.0097	.0114	.009	.0088	.0099	.0109	.0114
24	.5658	.5365	.0114	.009	.009	.6859	.6516
Max	.5658	1.2517	1.1443	1.2887	.0111	.8048	.7087
Min	.0097	.0114	.0088	.0088	.009	.0086	.0114
Avg	.2275	.6744	.3734	.4251	.01	.3448	.2906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 204 / 11 KV SAMDOLI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.1006	.1307	.1267	.1063	.1006	.124
2	.104		.1307	.1063	.1227	.1006	.1063
3	.1227	.0995	.1307	.1086	.1387	.1017	.1063
4	.1372	.1017	.1307	.1097	.1052	.1017	.1063
5	.124	.1029	.1307	.1294	.12	.1029	.1578
6	.1928	.1753	.2054	.1629	.1734	.2103	.1772
7	.2481		.2427	.2353	.2279	.2378	.2279
8	.208	.2012	.2054	.1829	.2012	.2012	.1949
9	.1663	.1646	.168	.1663	.1829	.1494	.1848
10	.1867	.1663	.1886	.1646	.1886	.181	.2054
11	.1494	.1463	.1886	.1663	.112	.132	.1867
12	.1494	.1463	.1848	.1886			.1867
13	.1463	.1463	.1867	.1463	.168		.1867
14	.1494	.128	.1698	.1646	.1494		.168
15	.1494	.128	.1478	.1463	.1494	.132	.168
16	.1494	.1463	.1867	.1646	.168	.132	.168
17	.1663	.1829	.2263	.168	.1886	.132	.1867
18	.168	.2402	.2801	.1886	.2075	.2054	.2614
19	.3174	.2987	.3326	.3109	.3395	.3109	.2987
20	.2987	.2987	.3109	.2865	.3206	.3018	.2987
21	.2743	.2614	.2715	.2686	.3174	.2743	.2427
22	.2353	.2241	.1791	.2172	.2328	.1772	.2054
23	.1578	.168	.1595	.1612	.1372	.1402	.168
24	.1254	.12	.1307	.1227	.1227	.12	.1402
Max	.3174	.2987	.3326	.3109	.3395	.3109	.2987
Min	.104	.0995	.1307	.1063	.1052	.1006	.1063
Avg	.1771	.1703	.1924	.1747	.1817	.1688	.1857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 205 / 11 KV SAMDOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0189	.5316	.5658	.4715	.0189	.0189
2	.0191	.0189	.5316	.6036	.4715	.0189	.0189
3	.0191	.0189	.5316	.6036	.4668	.0189	.0189
4	.0191	.0189	.5316	.6036	.4668	.0189	.0189
5	.0191	.0189	.5316	.6413	.4715	.0189	.0189
6	.0191	.0189	.6173	.6413	.5601	.0189	.0189
7	.0191	.0189	.6687	.6413	.6979	.0189	.0189
8	.0191	.0189	.703	.679	.8299	.0189	.0189
9	.0191	.0189	.7373	.7545	1.0374	.0189	.0189
10	1.1317	.0189	.0189	.0191	1.2071	1.0374	1.0802
11	1.358	.0189	.0189	.0191	1.358	1.3203	1.1317
12	1.358	.0189	.0189	.0191	1.3957		1.1317
13	1.358	.0189	.0189	.0191	1.3203		1.1317
14	1.2826	.0189	.0189	.0191	1.3203		1.1145
15	1.358	.0189	.0189	.0191	1.3203	1.226	1.0288
16	1.2826	.0189	.0189	.0191	1.2071	1.1317	.9945
17	1.1694	.0189	.0189	.0191	1.1694	.9619	.9774
18	.0189	.0189	.0189	.0191	.0189	.0189	.0189
19	.0189	.0189	.0189	.0191	.0189	.0189	.0189
20	.0189	.0189	.0189	.0191	.0189	.0189	.0189
21	.0189	.0189	.0189	.0191	.0189	.0189	.0189
22	.0189	.0189	.0189	.0191	.0189	.0189	.0189
23	.0189	.0189	.0189	.0191	.0189	.0189	.0189
24	.0191	.0189	.5316	.5658	.4715	.0189	.0189
Max	1.358	.0189	.7373	.7545	1.3957	1.3203	1.1317
Min	.0189	.0189	.0189	.0191	.0189	.0189	.0189
Avg	.4418	.0189	.2575	.2736	.6815	.2847	.3705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 206 / 11 KV SHAURYA INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0934	.0549	.0514	.056	.0747	.0171
2	.0724	.0934	.0549	.0514	.0566	.0747	.0171
3	.0732	.0934	.0549	.0514	.0747	.0747	.0171
4	.0739	.0934	.0549	.0514	.0566	.0747	.0171
5	.0934	.0934	.0549	.0514	.0924	.0747	.0171
6	.0754	.0934	.0549	.0514	.0732	.0934	.0171
7	.0572	.0747	.0549	.0514		.0343	.0171
8	.0191	.0343	.0549	.0686	.0173	.0343	.0171
9	.1334	.112	.0183	.0686	.1143	.0152	.0686
10	.0934	.0905	.0343	.1294	.0934	.0171	.0857
11	.1307	.0905	.0343	.0924	.0747	.0171	.0514
12	.0152	.0905	.0343	.0924	.0934		.0343
13	.1307	.0914	.0343	.0762	.0934		.0857
14	.0934	.0754	.0343	.0943	.1307		.0857
15	.0934	.0754	.0343	.168	.0934	.0171	.0686
16	.112	.0747	.0514	.0924	.0747	.0171	.0514
17	.0747	.0934	.0686	.0754	.1132	.0171	.0686
18	.0934	.112	.0857	.0354	.1307	.0171	.0343
19	.0934	.0747	.0857	.0366	.0934	.0171	.0343
20	.0934	.037	.0857	.056	.0343	.0171	.0343
21	.0934	.0373	.0857	.1132	.0747	.0171	.0514
22	.0934	.0373	.1029	.0924	.0747	.0171	.0514
23	.0934	.0373	.1029	.0549	.0747	.0171	.0514
24	.0566	.0934	.0373	.0514	.056	.0747	.0171
Max	.1334	.112	.1029	.168	.1307	.0934	.0857
Min	.0152	.0343	.0183	.0354	.0173	.0152	.0171
Avg	.0847	.0788	.0571	.0732	.0803	.0387	.0421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 207 / 11 KV WARANA KATH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3479	.4024			.4458	.3953
2	.3281	.4024			.4458	.4001
3	.3521	.407			.4458	.427
4	.3281	.4024			.4458	.4218
5	.3479	.4458			.4359	.427
6	.3725	.5144			.3978	.4321
7	.3841	.503			.503	.4475
8	.3521	.5487			.503	.4481
9	.3401	.6516			.4641	.4428
10		.5967	.7042	.7625		
11		.7209	.8421	.7773		
12		.7373	.8421	.7611		
13		.7373	.8322	.6478		
14		.7373	.7621	.6154		
15		.7209	.8002	.6964		
16		.6554	.7842	.6316		
17		.6554	.7682	.6882		
24	.3521	.3932			.4458	.4144
Max	.3841	.7373	.8421	.7773	.503	.4481
Min	.3281	.3932	.7042	.6154	.3978	.3953
Avg	.3505	.5685	.7919	.6975	.4533	.4256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081] BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 201 / 11 KV BUDHGAON GAONTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.4144		
3	.663				
4			.5243		
6			.5636		
7	.5801				.4973
9			.5801		
10					.5898
11					.6226
12		.5571			.5636
13				.547	
14		.5801			
16		.5243		.5801	
24	.7293		.5243		
Max	.7293	.5801	.5801	.5801	.6226
Min	.5801	.5243	.4144	.547	.4973
Avg	.6575	.5538	.5213	.5636	.5683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 202 / 11 KV KALERAN (KAVALPUR) SEPARATED AG FEEDERS HAVING SPECIAL
 AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.4096		
3	.0663				
4			.4973		
6			.6299		
7	.0663				.4144
8			.6718		
10		.0819			.9831
11					1.094
12		.0819			1.1142
13				.0332	
14		.0655			
16		.0655		.0663	
24	.0663		.0497		
Max	.0663	.0819	.6718	.0663	1.1142
Min	.0663	.0655	.0497	.0332	.4144
Avg	.0663	.0737	.4517	.0498	.9014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 203 / 11 KV BISUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.0943		
3	.1867				
4			.1132		
6			.1886		
7	.2241				.1867
8			.1698		
10					.1029
11					.0867
12		.0934			.052
13				.1867	
14		.112			
16		.0934		.1867	
23	.2241				
24	.2241		.1494		
Max	.2241	.112	.1886	.1867	.1867
Min	.1867	.0934	.0943	.1867	.052
Avg	.2148	.0996	.1431	.1867	.1071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 204 / 11 KV BUDHGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.0492		
3	.2486				
4			.0492		
6			.0497		
7	.2486				.0663
8			.0663		
10		.5304			.056
12		.5735			.0566
13				.4641	.056
14		.5636			
16		.5079		.4973	
24	.1658		.0492		
Max	.2486	.5735	.0663	.4973	.0663
Min	.1658	.5079	.0492	.4641	.056
Avg	.221	.5439	.0527	.4807	.0587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 205 / 11 KV EXPRESS COLLEGE

NON SHEDDABLE WATER SUPPLY AND

FEEDER Feeder KV- 11 /

UTILITY

OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.1307		
3	.0747				
4			.1307		
6			.168		
7	.0747				.0934
8			.168		
10		.1132			
12		.0943			
13				.0995	
14		.1132			
16		.0943		.0663	
24	.0747		.132		
Max	.0747	.1132	.168	.0995	.0934
Min	.0747	.0943	.1307	.0663	.0934
Avg	.0747	.1038	.1459	.0829	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 207 / 11 KV JYPTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747				
2			.0566		
3	.0747				
4			.0377		
6			.0377		
7	.0663				.0343
8			.0566		
10		.0943			
12		.1132			
13				.037	
14		.1132			
16		.1132		.0332	
Max	.0747	.1132	.0566	.037	.0343
Min	.0663	.0943	.0377	.0332	.0343
Avg	.0719	.1085	.0472	.0351	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 208 / 11 KV BISUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.4755		
3	.056				
4			.5135		
6			.5944		
7	.056				.5967
8			.6602		
10		.0587			
12		.0594			
13				.0678	
14		.0587			
16		.0587		.0747	
24	.056		.044		
Max	.056	.0594	.6602	.0747	.5967
Min	.056	.0587	.044	.0678	.5967
Avg	.056	.0589	.4575	.0713	.5967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081] BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 401 / 33 KV SHERINALA

Feeder KV- 33 / OUTGOING

DATE	05-FEB-18
HR	Load (MW)
7	.028
Max	.028
Min	.028
Avg	.028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 201 / 11 KV DUDHGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1494	.1867	.1867	.2054	.1509	.1698
2	.1494	.1494	.1867	.1867	.2054	.1509	
3	.1494	.1494	.1867	.1867	.2054	.1509	.1698
4	.168	.168	.2054	.1867	.2241	.1698	.2075
5	.2218	.1867	.2427	.2614	.2987	.1886	.2452
6	.3326	.3174	.3696	.3174	.3696	.2829	.3584
7	.4066	.3547	.4066	.3921	.3696	.3961	.4715
8	.3326	.3734	.3511	.3921	.3511	.3772	.4668
9	.3881	.3921	.3734	.3361	.4066	.3772	.4294
10	.3361	.3734	.3547	.2987	.3696	.3174	.3734
11	.3174	.3734	.3547	.2987	.4251	.2801	.3547
12	.3547	.3547	.3174	.2427	.3881	.2987	.3547
13	.3584	.3361	.3921		.3881	.3174	.3361
14	.3547	.3174	.2987	.2987	.3881	.2427	.3174
15	.3734	.3174	.3361	.2987	.3696	.2427	.3361
16	.3734	.3547	.3547	.2987	.3511	.2427	.3734
17	.3734	.4108		.3361	.3734	.2801	.4294
18	.4108	.4805	.4294	.3547	.3921	.3174	.4668
19	.5975	.5729	.4854	.462	.5788	.4668	.5601
20	.6161	.5175		.462	.5788	.4668	.4668
21	.4294	.4854	.4668	.4435	.4108	.4294	.3921
22	.3361	.3921	.3921	.3696	.3361	.3361	.2987
23	.2241	.2987	.2801	.2614	.2054	.2263	.2241
24	.1494	.168	.2054	.1867	.2241	.1698	.1886
Max	.6161	.5729	.4854	.462	.5788	.4668	.5601
Min	.1494	.1494	.1867	.1867	.2054	.1509	.1698
Avg	.3293	.3331	.3262	.3069	.3506	.2866	.3474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 202 / 11 KV SAWALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.3401	.3239	.0191	.0191
2	.0191	.0191	.0191	.3401	.3239	.0191	.0191
3	.0191	.0191	.0191	.3401	.3605	.0191	.0191
4	.0191	.0191	.0191	.3401	.3605	.0191	.0191
5	.0191	.0191	.0191	.3921	.3605	.0191	.0191
6	.0381	.0381	.1943	.3401	.3932	.0381	.0381
7	.0381	.0381	.2429	.4049	.4424	.0381	.0381
8	.0381	.0381	.4752	.4696	.4752	.0381	.0381
9	.0381	.0381	.4915	.502	.5571	.0381	.0381
10	.7935	.0191	.0191	.0191	.664	.6316	.6554
11	.8259	.0191	.0191	.0191	.6478		.6962
12	.8259	.0381	.0191	.0191	.7287	.7468	.788
13	.8259	.0381	.0191	.0191	.7287	.7621	
14	.7773	.0191	.0191	.0191	.7287	.7316	.7209
15	.7537	.0191	.0191	.0191	.7125	.7011	.5668
16	.7449	.0191	.0191	.0191	.7125	.6859	.4696
17	.7287	.0191		.0191	.7125	.5792	.5735
18	.0191	.0191	.0381	.0381	.0381	.0381	.0191
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381		.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0191	.0191	.0381	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.3401	.3077	.0191	.0191
Max	.8259	.0381	.4915	.502	.7287	.7621	.788
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.2798	.0262	.0829	.1730	.4055	.2303	.2134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 203 / 11 KV DHARAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5079	.421			.5571	.3768
2	.5079				.5571	.3768
3	.4915	.421			.5571	.3768
4	.4915	.421			.5571	.3768
5	.503	.421			.5571	.3768
6	.5197	.4696			.639	.3932
7	.57	.5668			.6882	.4752
8	.5365	.6478			.6882	.5898
9	.4588	.7773			.7209	.5735
10		.9779	.9503	1.0059		
11		1.1012	1.2125	1.153		
12		1.1012	1.1961	1.2039		
13		1.1012	1.2289	1.1191		
14		1.1012	1.1797	1.17		
15		1.065	1.1469	1.0898		
16		1.0688	1.1961	1.0395		
17		1.004		1.0059		
24	.5079	.3563			.5243	.4096
Max	.57	1.1012	1.2289	1.2039	.7209	.5898
Min	.4588	.3563	.9503	1.0059	.5243	.3768
Avg	.5095	.7660	1.1586	1.0984	.6046	.4325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 204 / 11 KV BAGANI ROAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.2622	.2267	.2753	.0191	.0191
2	.0191	.0191	.2622	.2267	.2753	.0191	.0191
3	.0191	.0191	.2785	.2267	.2915	.0191	.0191
4	.0191	.0191	.2785	.2267	.2915	.0191	.0191
5	.0191	.0191	.2785	.2267	.2949	.0191	.0191
6		.0191	.3277	.2753	.2949	.0381	.0381
7	.0381	.0191	.3647	.3077	.3277	.0381	.0381
8	.0191	.0191	.3812	.3725	.431	.0381	.0381
9	.0381	.0191	.431	.3768	.5533	.0381	.0381
10	.4801	.0191	.0191	.0191	.5898	.4858	.4049
11	.4858	.0191	.0191	.0191	.6226		.5304
12	.4858	.0191	.0191	.0191	.5441	.6154	.57
13	.4696	.0191	.0191	.0191	.6554	.5992	.6036
14	.4696	.0191	.0191	.0191	.6554	.5992	.6036
15	.4696	.0191	.0191	.0191	.5735	.583	.5967
16	.4752	.0191	.0191	.0191	.5735	.5668	.5801
17	.4696	.0191		.0191	.5735	.5182	.5243
18	.0191	.0381	.0381	.0381	.0191	.0381	.0191
19	.0381	.0572	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381		.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0191	.0381	.0191	.0191	.0381	.0191	.0191
24	.0191	.0191	.2622	.2294	.2753	.0191	.0191
Max	.4858	.0572	.431	.3768	.6554	.6154	.6036
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1829	.0246	.1560	.1274	.3462	.1932	.2030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 205 / 11 KV A1 PPS EXPRESS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2452	.2614	.1886	.2452
2	.2641	.2641	.2452	.2614	.1886	.2452
3	.2641	.2641	.2641	.2614	.2263	.2452
4	.3018	.2641	.2641	.2614	.2263	.2452
5	.3395	.2641	.2829	.2614	.2641	.2452
6	.4715	.3772	.415	.3174	.3584	.3018
7	.7922	.5601	.6224	.6348	.4527	.5975
8	.811	.6722	.5658	.7095	.7167	.5975
9	.7922	.7095	.5847	.7282	.7167	.6535
10	.8676	.7655	.6535	.7282	.7282	.6036
11	.8402	.7468	.6908	.415	.7282	.7356
12	.8402	.7468	.7282	.6036	.7842	.7545
13	.8402	.7095	.7282	.5281		.7356
14	.8215	.7468	.7095	.3584	.6348	.6979
15	.8215	.7468	.7095	.415	.7282	.7356
16	.6908	.6908	.6908	.415	.7282	.679
Max	.8676	.7655	.7282	.7282	.7842	.7545
Min	.2641	.2641	.2452	.2614	.1886	.2452
Avg	.6264	.5495	.5250	.4475	.5113	.5199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 201 / 11 KV NANDRE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4338	.4066	.4527	.4715	.415	.499
2	.4338	.3961	.4108	.4715	.4527	.3961	.4668
3	.4338	.3961	.5601	.4715	.4527	.4338	.5228
4	.4338	.4338	1.0374	.5093	.4715	.4715	.5601
5	.7316	.5415	.9242	.6036	.5788	.6979	.9709
6	.823	.8215	1.0374	.8299	.9055	.8215	1.094
7	.9412	.924	.9335	.9511	.9979	.924	1.0562
8	.8507	.8501	.7842	.8417	.8413	.7682	.8686
9	.7701		.7762	.7975	.7964	.7619	.8316
10	.6379	.6626	.6335	.6935	.7011	.6283	.724
11	.631	.6447	.6268	.7202	.6241		.6089
12	.6485	.5792	.5493	.5895	.5784		
13	.5721	.543	.5493	.6135	.5493		.6379
14	.5144	.4938	.5434	.5493	.5258	.724	.5201
15	.5201	.4755	.5083	.4961	.4607	.6283	.4733
16	.5083	.5611	.4961	.5194	.5258	.6283	.5316
17	.5847	.5792	.4835	.543	.5138	.5975	.5552
18	.5973	.6154	.5973	.6099	.695	.7682	
19	1.0719	1.0242	1.0242	1.0269	1.0349	1.0387	1.0498
20	1.0456	1.0608	1.0059	.9808	.9979	1.0387	
21	1.0562	.9795	.9593	.9431	.9328	.9412	.9412
22	.8299	.8316	.8316	.8029	.7762	.8048	.7499
23	.6224	.5544	.6036	.5658	.6036	.6036	
24	.4527	.4904	.4435	.4904	.4904	.4338	
Max	1.0719	1.0608	1.0374	1.0269	1.0349	1.0387	1.094
Min	.4338	.3961	.4066	.4527	.4527	.3961	.4668
Avg	.6735	.6475	.6969	.6697	.6658	.6917	.7190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0377	.088	.1646	.1572	.0339	.029
2	.0335	.0377	.0743	.1738	.1551	.0343	.0297
3	.0332	.0377	.0743	.1715	.1572	.0347	.0297
4	.0332	.0377	.1189	.1715	.1593	.0347	.0297
5	.0328	.0377	.1505	.1738	.1572	.0343	.0446
6	.0328	.0377	.1806	.1882	.1692	.0509	.0446
7	.0332	.0377	.2494	.2286	.1808	.0514	.0446
8	.0339	.0377	.2606	.2143	.2	.0316	.0286
9	.0526		.2751	.2462	.2961	.0469	.0429
10	.3506	.0362	.029	.0429	.3715	.12	.3227
11	.4666	.0358	.029	.0286	.3765		.3765
12	.431	.0297	.0301	.0145	.3909		.3858
13	.4458	.0297	.0446	.0145	.3715		.4054
14	.4199	.0297	.0297	.0145	.3475	.282	
15	.4064	.0297	.0297	.0286	.3429	.3286	.362
16	.3913	.0297	.0293	.0286	.3429	.3572	.3572
17	.381	.0297	.0293	.0286	.3475	.3384	.362
18	.0457	.0293	.0446	.0572	.0446	.0429	
19	.0343	.0293	.0452	.0457	.0452	.0429	.0434
20	.0537	.0293	.0457	.0309	.0457	.0429	
21	.0554	.0293	.0301		.029	.0429	.044
22	.0377	.0293	.0446	.0514	.0286	.0286	.0297
23	.0373	.0293	.029	.0343	.029	.029	.0297
24	.0339	.0373	.1027	.1623	.1572	.0339	
Max	.4666	.0377	.2751	.2462	.3909	.3572	.4054
Min	.0328	.0293	.029	.0145	.0286	.0286	.0286
Avg	.1629	.0333	.0860	.1007	.2043	.0972	.1521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 203 / 11 KV MALBHAG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1204	.0187	.0554	.0189	.0869	.108
2	.1543	.1219	.0185	.0554	.0189	.0734	.125
3	.1543	.1219	.0185	.0554	.0189	.0724	.1094
4	.1543	.1219	.0185	.0554	.0189	.0869	.1067
5	.1677	.1204	.0185	.056	.0189	.0869	.1372
6	.1806	.1204	.0179	.0549	.0189	.0857	.1204
7	.1806	.1337	.0354	.037	.0189	.1143	.1486
8	.1738	.1505	.0354	.037	.0189	.1303	.1783
9	.1593		.0362	.0549	.0189	.132	.208
10	.0549	.2494	.2408	.2408	.0554	.0185	.0739
11	.0549	.2778	.2968	.2623	.056		.0747
12	.0724	.2932	.3125	.2812	.0373		.0747
13	.1075	.2778	.3201	.2439	.0554		.0739
14	.0732	.2778	.3201	.2439	.0554	.0373	.0934
15	.0732	.2743	.3048	.2656	.0373	.0373	.0739
16	.1086	.2896	.2743	.25	.0373	.056	.0747
17	.0549	.2526	.2778		.037	.0373	.056
18	.0554	.0362	.0716	.0185	.0189	.0362	
19	.0377	.0373	.0732	.037	.0377	.037	.0358
20	.0377	.0373	.0739	.037	.0377		
21	.0754	.0373	.037	.0377	.0377	.0373	
22	.0377	.0187	.0549	.0377	.0377	.0373	.0358
23	.0377	.0187	.0554	.0189	.0373	.0377	.0358
24	.1829	.1219	.0187	.0373	.0377	.0903	
Max	.1829	.2932	.3201	.2812	.056	.132	.208
Min	.0377	.0187	.0179	.0185	.0189	.0185	.0358
Avg	.1059	.1527	.1229	.1075	.0327	.0666	.0972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 201 / 11 KV KAVALAPUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2195	.2427	.2218	.2218	.2427	.9511
2	.2218	.2195	.2402	.2218	.2241	.2427	.9511
3	.2378	.2218	.2614	.2218	.2241	.2427	.9511
4	.2402	.2957	.3395	.2427	.2427	.2452	1.2936
5	.3511	.4108	.4904	.2743	.2402	.3206	1.4784
6	.5041	.5228	.5228	.3326	.3326	.3961	1.6632
7	.5228	.4904	.499	.4108	.5121	.5228	1.6078
8	.4294	.4481	.5041	.4805	.439	.5228	1.6263
9	.362	.3921	.3761	.3772	.3841	.4024	1.4864
10	.3475	.3326	.2915	.3696	.3582	.2865	1.3998
11	.2715	.3292	.362	.3658	.2947	.2601	.2947
12	.2715	.2926	.3258	.2715	.2713	.2103	.2401
13	.2353	.2534	.3077	.2715	.2629	.1696	.2947
14	.2149	.2353	.2865	.2865	.2279	.1543	.2774
15	.2353	.2534	.2715	.3077	.2427		.2279
16	.2534	.2534	.1791	.2896	.2713		.2481
17	.2715	.2715	.2172	.3045	.2743		.3121
18	.4207	.3841	.2926	.362	.3222	.2686	.4334
19	.5853	.5487	.5853	.5121	.5973	.5249	.5853
20	.5228	.5175	.5359	.5487	.5853	1.7193	.567
21	.4805	.4805	.5359	.5121	.5359	1.6817	.5359
22	.4024	.4435	.4481	.4066	.4481	1.587	.4294
23	.2772	.2926	.3361	.2772	.3174	1.2012	.3361
24	.2614	.2402	.2427	.2353	.2218	.2452	.961
Max	.5853	.5487	.5853	.5487	.5973	1.7193	1.6632
Min	.2149	.2195	.1791	.2218	.2218	.1543	.2279
Avg	.3400	.3479	.3623	.3377	.3355	.5451	.7980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 202 / 11 KV TUKAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0701	.3048	.1524	.3401	.0554	.1063
2	.0625	.0732	.3048	.1524	.3239	.056	.1063
3	.064	.0732	.3086	.1524	.3125	.056	.1075
4	.064	.0739	.381	.2315	.3437	.0566	.1433
5	.0686	.0924	.5335	.3086	.3479	.0754	.1629
6	.0876	.1109	.6249	.4572	.3858	.0943	.1629
7	.1097	.0934	.6859	.4904	.4428	.132	.181
8	.1109	.0739	.787	.6944	.578	.112	.1463
9	.1109	.0934	.8025	.7468	.7186	.1109	.0886
10	.7343	.0895	.0876	.0678	.7562	.2286	.5312
11	1.0648	.0905	.0886	.0701	.9998	.7011	.7099
12	1.0936	.0886	.0895	.0709	.945	.7716	.8124
13	1.0031	.0724	.0895	.0724	.9602	.7621	.7716
14	.9877	.0895	.1063	.0716	.7579	.7827	.8855
15	.9568	.0724	.1075	.0724	.8128		.7968
16	.9145	.0886	.1086	.0709	.7727		.8179
17	.7968	.0716	.1097	.0905	.5719		.7907
18	.1017	.0724	.0905	.0895	.0724	.0876	.0678
19	.0886	.0895	.1075	.1086	.0934	.1227	.1109
20	.1052	.0876	.0905	.1075	.0934	.0876	.0934
21	.0867	.0876	.0924	.1086	.0943	.1052	.1109
22	.0876	.0739	.0934	.0895	.0934	.1227	.0914
23	.0867	.0739	.0739	.0905	.0747	.1214	.0924
24	.0732	.0701	.3125	.0739	.3481	.0747	.1075
Max	1.0936	.1109	.8025	.7468	.9998	.7827	.8855
Min	.0625	.0701	.0739	.0678	.0724	.0554	.0678
Avg	.3722	.0822	.2659	.1934	.4683	.2246	.3331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 203 / 11 KV KONDAKA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.2439	.0914	.0914	.0895	.3814	.3048
2	.5182	.2439	.0914	.0739	.0895	.3864	.3048
3	.5335	.2439	.0914	.0739	.0724	.3715	.381
4	.6859	.3086	.0924	.0747	.0905	.3864	.3858
5	.7716	.3906	.112	.0934	.0914	.431	.6019
6	1.0031	.4572	.1494	.112	.1629	.5575	.7811
7	1.0364	.5556	.168	.132	.181	.945	.8579
8	1.0212	.6984		.2054	.181	1.034	.9907
9	.7926	.8383	.1629	.1867	.1433	1.0648	.9065
10	.1029	.9568	.3048	.583	.112	.1029	.0914
11	.1417	1.0467	.9842	1.0185	.1294	.0876	.1109
12	.1433	1.0212	.9877	1.0155	.1478	.0867	.1109
13	.124	1.0648	1.0155	1.034	.128	.0867	.1075
14	.1086	.953	.9259	1.0212	.124		.1097
15	.1063	.9877	.8951	1.0185	.1227		.1097
16	.1086	.9602	1.0155	.9998	.1214		.1097
17	.1254	.5937	.9998	.9877	.1086		.1307
18	.1417	.0509	.0678	.0678	.1646	.1433	.1848
19	.1612	.1595	.1543	.1772	.1867	.1772	.1867
20	.1612	.156	.1417	.1791	.1867	.1867	.168
21	.1595	.1402	.1494	.1791	.1848	.1663	.1867
22	.1433	.1294	.1307	.1448	.1663	.1463	.1494
23	.1227	.1109	.1294	.1267	.1294	.1478	.1494
24	.5335	.1109	.1109	.0934	.1097	.4064	.2401
Max	1.0364	1.0648	1.0155	1.034	.1867	1.0648	.9907
Min	.1029	.0509	.0678	.0678	.0724	.0867	.0914
Avg	.3867	.5176	.3901	.4037	.1343	.3648	.3192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 210 / 11 KV Dhamni gaonthan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.924
Max	.924
Min	.924
Avg	.924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081] BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 401 / 33KV KASABE DIGRAJ

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	3.2579
Max	3.2579
Min	3.2579
Avg	3.2579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 201 / 11KV GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.4298	.4607	.6089	.4908	.5316	.5373
2	.4607	.4344	.4656	.6089	.4607	.5014	.5552
3	.4607	.4163	.4298	.591	.4656	.5014	.5373
4	.4656	.3982	.4344	.5731	.4706	.4656	.5373
5	.4706	.4024	.4656	.5552	.5068	.4706	.5552
6	.5068	.4024	.543	.5373	.5487	.4706	.6447
7	.5853	.6401	.6516	.5552	.5914	.5792	.6447
8	.6089	.6468	.6661	.6089	.6219	.6767	.7164
9	.6516	.6805	.695	.6584	.6447	.6516	.6697
10	.6805	.6447	.6379		.6805	.6805	.7265
11	.7164	.6626	.724	.7316	.6984	.6447	.7701
12	.6733	.7164	.6805	.6335	.6805	.567	.7164
13	.6733	.6447	.6447	.5731	.6089	.6024	.6135
14	.6447	.6447	.6089	.543	.6447	.5258	.567
15	.5792	.6268	.6447	.543	.5731	.5316	.5847
16	.6024	.6447	.6089	.5068	.631	.5373	.5609
17	.6805	.6447	.6379	.567	.6379	.5731	.6024
18	.7712	.6984	.7011	.6089	.7282	.6447	.7796
19	1.0631	.9922	1.0517	1.0056	.964	1.0566	.9816
20	1.0517	1.0029	1.0692	.9816	.9214	1.0208	.9816
21	.8764	.905	.9036	.8764	.8859	.9671	.9114
22	.7888	.7522	.8059	.7282	.7087	.8238	.7282
23	.5847	.567	.6984	.5895	.6135	.6984	.5895
24	.5258	.4835	.4961	.6268	.5258	.5316	.5552
Max	1.0631	1.0029	1.0692	1.0056	.964	1.0566	.9816
Min	.4607	.3982	.4298	.5068	.4607	.4656	.5373
Avg	.6505	.6284	.6552	.6440	.6377	.6356	.6694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 202 / 11KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5853	.543	.5552	.543	.5601	.394
2	.5068	.5544	.5121	.5373	.5121	.5228	.4119
3	.5121	.5544	.4755	.5552	.5121	.4854	.394
4	.5121	.5228	.4706	.5373	.5175	.4854	.394
5	.5487	.5228	.5121	.5552	.5228	.4854	.4119
6	.5914	.5228	.5544	.591	.5228	.4854	.4656
7	.6653	.7468	.6283	.5194	.5658	.4481	.4656
8	.7522	.7964	.5853	.591	.6219	.499	.5014
9	.7164	.591	.6878	.6516	.6089	.5487	.5487
10	.7164	.788	.7796	.6805	.5373	.5373	.7973
11	.7087	.8238	.8326	.6878	.6089	.5731	.8954
12	.4458	.8059	.8238	.724	.5014	.5792	.8954
13	.7796	.788	.724	.6268	.6268	.567	.8764
14	.7522	.7343	.724	.6335	.5194	.5731	.8328
15	.724	.6805	.7964	.6335	.5373	.5731	.8596
16	.724	.6984	.8238	.5121	.5121	.5792	.815
17	.8505	.8417	.7164	.6089	.6516	.5014	.8505
18	.9431	.788	.7164	.5316	.7087	.5014	.7522
19	1.0745	1.0136	1.0029	.6805	.9774	.788	.9774
20	.9955	.9412	.8954	.7964	.905	.7522	.905
21	.8238	.8413	.8059	.7602	.8145	.6447	.8596
22	.7602	.724	.7343	.6878	.695	.6447	.7522
23	.6697	.6154	.6626	.5792	.5853	.5014	.6447
24	1.3641	.5853	.5792	.5731	.543	.5601	.4298
Max	1.3641	1.0136	1.0029	.7964	.9774	.788	.9774
Min	.4458	.5228	.4706	.5121	.5014	.4481	.394
Avg	.7352	.7111	.6911	.6170	.6104	.5582	.6721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 203 / 11KV VAKHARBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5041	.5175	.4656	.5068	.4668	.4835
2	.5014	.4854	.4854	.4477	.5014	.4481	.4656
3	.4706	.4668	.4481	.4477	.4706	.4481	.4477
4	.4706	.4481	.4481	.4298	.4805	.4481	.4656
5	.4755	.4527	.4805	.4298	.4854	.4481	.443
6	.4805	.4527	.4854	.4477	.4854	.4481	.4835
7	.5228	.4904	.5281	.4477	.4904	.5228	.5552
8	.543	.5658	.5601	.4656	.5175	.5601	.591
9	.5853	.6154	.5228	.5601	.5731	.5544	.6219
10	.6805	.7164	.5914	.5975	.591	.6283	.6878
11	.8299	.905	.679	.7468	.788	.7392	.8131
12	.8299	.8238	.8299	.8589	.8775	.7762	.7468
13	.8131	.8596	.8215	.8402	.8596	.8048	.7682
14	.7762	.8059	.8215	.7922	.8059	.7602	.6908
15	.7468	.8238	.8589	.7842	.788	.7762	.6908
16	.8871	.8596	.8589	.8316	.8131	.7762	.7468
17	.7468	.8238	.8962	.7842	.8215	.7343	.7842
18	.905	.8775	.8962	.8589	1.0059	.788	.9335
19	1.0269	1.0456	1.1088	1.0242	1.0164	.9671	1.0082
20	.961		1.0387	1.0242	.9709	1.0029	.961
21	.961	.8131	.9492	.9335	.924	.9492	.8871
22	.7392	.7468	.7343	.7602	.7762	.7164	.724
23	.5975	.5914	.591	.6447	.5544	.6268	.5792
24	.543	.5041	.5544	.4656	.5373	.4668	.5014
Max	1.0269	1.0456	1.1088	1.0242	1.0164	1.0029	1.0082
Min	.4706	.4481	.4481	.4298	.4706	.4481	.443
Avg	.6917	.6816	.6961	.6704	.6934	.6607	.6700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 201 / 11 KV Balaji Mill Road
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3749	.431	.4161	.4752	.4111	.4694	.4862
2	.3437	.4144	.3864	.4641	.4012	.4359	.4372
3	.3479	.4096	.3864	.421	.3704	.421	.421
4	.3401	.4096	.3913	.421	.3658	.421	.4111
5	.3563	.421	.3913	.4111	.381	.4218	.4167
6	.4359	.4696	.4115	.4115	.3963	.4054	.4268
7	.5144	.5243	.4531	.4752	.4784	.4365	.4858
8	.4961	.5144	.5658	.5243	.5087	.4534	.5258
9	.5316	.7421	.6697	.6626	.4862	.4807	.6516
10	.5609	.724	.7682	.724	.5784	.4915	.8215
11	.5434	.7762	.7842	.7421	.6335	.5201	.7762
12	.7059	.7392	.8029	.695	.6089	.4696	.7023
13	.4858	.7207	.7316	.5847	.6201	.5304	.7023
14	.5721	.7392	.7059	.6733	.5895	.5658	.6878
15	.6201	.6838	.7602	.6447	.5609	.5658	.6401
16	.6089	.695	.724	.7059	.6154	.5658	.7842
17	.583	.5487	.7059	.7059	.5731	.5784	.7468
18	.6036	.6201	.6984	.6653	.6468	.5197	.6838
19	.5973	.6516	.7577	.6348	.6401	.6201	.6089
20	.5611	.5609	.6335	.5194	.6036	.6024	.5784
21	.5493	.6201	.6335	.543	.6653	.4917	.5609
22	.5609	.5784	.6201	.6516	.6584	.4694	.6653
23	.4973	.5487	.6024	.6201	.567	.5847	.6089
24	.3953	.463	.4531	.5197	.4588	.5144	.4973
Max	.7059	.7762	.8029	.7421	.6653	.6201	.8215
Min	.3401	.4096	.3864	.4111	.3658	.4054	.4111
Avg	.5077	.5836	.6022	.5790	.5341	.5015	.5970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 202 / 11 KV Circuit House

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1132	.132	.132	.132	.1132	.1132
2	.1132	.1132	.1132	.1132	.132	.0943	.0943
3	.1132	.1132	.1132	.1132	.132	.0943	.0943
4	.1132	.1132	.1132	.1132	.132	.0943	.1132
5	.132		.132	.132	.1509	.132	.1509
6	.1509	.1509	.1509	.1509	.1509	.1698	.1886
7	.1494	.1698	.1698	.1509	.1509	.2075	.2075
8	.1886	.1698	.1886	.1698	.1698	.2075	.2263
9	.1698	.1509	.2075	.1698	.1698	.1698	.2263
10	.1509	.1509	.132	.1509	.1698	.1509	.2075
11	.132	.1132	.1509	.132	.132	.1132	.1509
12	.0943	.1132	.1132	.0943	.1132	.1132	.1886
13	.0943	.1132	.0943	.1886	.0754	.0943	.1509
14	.1132	.1132	.0943	.1698	.1132	.0943	.1509
15	.0886	.132	.0943	.1698	.1132	.0943	.132
16	.132	.132	.0943	.2263	.132	.1509	.1509
17	.132	.1509	.1698	.2452	.1886	.1509	.1509
18	.1698	.1886	.1509	.1698		.1698	.2075
19	.2263	.2263	.2452	.2641	.2772	.2263	.2452
20	.2641	.2263	.2452	.2801	.2772	.2452	.2263
21	.2263	.2263	.2263	.2263	.2241	.2263	.2263
22	.2075	.1886	.2263	.2263	.2241	.2263	.2075
23	.1509	.1509	.1698	.2075	.1509	.1698	.1698
24	.132	.132	.132	.132	.1509	.132	.132
Max	.2641	.2263	.2452	.2801	.2772	.2452	.2452
Min	.0886	.1132	.0943	.0943	.0754	.0943	.0943
Avg	.1490	.1501	.1525	.172	.1592	.1517	.1713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 203 / 11 KV Timber Area

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2075	.2263	.2263	.2263	.2263
2	.2075	.2263	.2075	.2075	.2263	.2075	
3	.2075	.2263	.2075	.2075	.2263	.2075	.2075
4	.2075	.2263	.2075	.2075	.2452	.2075	.2075
5	.2263	.2641	.2452	.2263	.2641	.2452	.2263
6	.2772	.3018	.2829	.2641	.3018	.3018	.2801
7	.2865	.3018	.3395	.2374	.2835	.2641	.3012
8	.2957	.3206	.3292	.2896	.3109	.3018	.3077
9	.3395	.3395	.415	.3206	.3395	.2829	.415
10	.3772	.3961	.3961	.3206	.3395	.2987	.415
11	.4108	.3584	.3961	.3206	.3395	.2587	.3961
12	.3584	.3584	.3961	.2829	.3018	.2427	.3961
13	.2658	.2658	.2641	.2347	.2614	.2263	.2641
14	.2241	.2534	.2641	.2056	.2454	.2075	.3206
15	.3395	.3772	.3772	.3018	.3018	.2263	.3584
16	.3395	.3734	.3772	.3018	.2829	.2054	.3584
17	.3772	.4338	.3018	.2641	.3206	.2263	.3961
18	.415	.3734	.3584	.3206	.3772	.2452	.3961
19	.547	.4481	.415	.3921	.4481	.3772	.4481
20	.415	.3921	.3772	.3772	.4108	.3772	.3921
21	.3584	.3584	.3395	.3395	.3584	.3395	.3584
22	.3206	.3206	.3018	.3206	.3206	.3395	.3206
23	.2641	.2641	.2641	.3018	.2829	.2641	
24	.2263	.2452	.2263	.2263	.2452	.2452	.2452
Max	.547	.4481	.415	.3921	.4481	.3772	.4481
Min	.2075	.2263	.2075	.2056	.2263	.2054	.2075
Avg	.3130	.3188	.3124	.2790	.3025	.2635	.3290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 201 / 11 KV MADHAVNAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4108	.3961	.4338	.0943	.1132	.3584
2		.4108	.3961	.4338	.0943	.0943	.3584
3		.4108	.3772	.4527	.0943	.0943	.3584
4		.4108	.3772	.4715	.0943	.0943	.3772
5		.4294	.3961	.4715	.0943	.0943	.415
6		.4294	.4527	.4715	.0943	.0943	.4715
7		.5041	.5658	.4904	.0943	.0754	.4715
8		.5121	.547	.6036	.0943	.0943	.5658
9	.6468	.5658	.5658	.6602	.1132	.0943	.679
10	.7282	.5847	.5847	.7282	.1132	.0943	.7655
11	.7421	.6413	.5975	.6348	.1132		.8775
12	.6584	.6602	.6224	.5415	.1132		.7468
13	.5304	.6413	.679	.5415	.1132	.3961	.6535
14	.5853	.6224	.7167	.5601	.132	.3584	.7095
15	.7682	.679	.7545	.5601	.1698	.3772	.7655
16	.7796	.7356	.7545	.0914	.1509	.5093	.7655
17	.7701	.7682	.7545	.0943	.1509		.7577
18	.7343	.7499	.7733		.1509	.6224	.7865
19	.8962	.9335	.9054	.1132	.132	.6036	.9055
20	.7499	.8488	.8488	.1132	.132		.7947
21	.6219	.679	.6979	.1132	.1132	.5847	.6908
22	.5487	.5847	.5658	.1132	.1132	.5093	.6348
23	.4755	.5093	.4338	.1132	.1132	.415	.5093
24		.4108	.4715	.4338	.0943	.1132	.3584
Max	.8962	.9335	.9054	.7282	.1698	.6224	.9055
Min	.4755	.4108	.3772	.0914	.0943	.0754	.3584
Avg	.6824	.5889	.5931	.4018	.1155	.2716	.6157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 203 / 11 KV INDOTEX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9335	1.0374	.8745	.9335	.9149	.9145
2		.9522	.9997	.8745	.9335	.9335	.8962
3		.9522	.9997	.8745	.9335	.9335	.8962
4		.9522		.8916	.9335	.9335	.8962
5		.9522	.9808	.8916	.8962	.9335	.8962
6		.9522	.9997	.8916	.8962	.9335	.8962
7		.9335	1.0185	.8916	.8962	.9335	.8962
8		.9335	.9242	.8745	.8962	.9335	.8779
9	.9431	.9522	.9335	.8573		.9335	.9328
10	.9619	.9709	.9335	.8402	.9619	.9149	.9145
11	.9619	.9896	.9335	.8589	.9619	.9149	.8596
12	.9431	1.0082	.9522	.8413	.9619	.9149	.8417
13	.9242	.9709	.9328	.8775	.9431	.9149	.8417
14	.9619	.9511	.7499	.8954	.9431	.9335	.9145
15	1.0185	.9709	.9896	.9145	.9431	.9335	.9511
16	.9808	.9709	1.0269	.9328	.9619	.9335	.8779
17	.9709	.9808	1.0082	.9335	.9619		.9431
18	.9709	1.0185	.9709	.9335	.9709	.9522	.9619
19	.9145	.9808	.9335	.9145	.9511	.9335	.9808
20	.9145	.9808	.9335	.9335	.9145	.9149	.9619
21	.8962	.9619	.9335	.9335	.8779	.8775	.9242
22	.9145	.9808		.9522	.8962	.9054	.9431
23	.9145	.9808	.9522	.9335	.9149	.9335	.9242
24		.9522	.9619	.8745		.9149	.9335
Max	1.0185	1.0185	1.0374	.9522	.9709	.9522	.9808
Min	.8962	.9335	.7499	.8402	.8779	.8775	.8417
Avg	.9461	.9660	.9593	.8955	.9311	.9250	.9115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 205 / 11 KV COTTON MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431	.9619	1.1694	1.2826	1.4335	.8299
2		.9808	.9431	1.1317	1.2826	1.4335	.8299
3		1.0185	.9431	1.0374	1.2826	1.4146	.8299
4		1.0562	.9242	.9431	1.2826	1.4146	.8299
5		1.1128	.9242	.9431	1.2826	1.3957	.8299
6		1.1694	.9619	.9431	1.2826	1.3957	.8299
7		1.2071	.9431	.9431	1.3203	1.2449	.8299
8		.9431	.9808	.8865	1.3957	.811	.8676
9		1.1317	1.094	.9808	2.0559	.679	1.358
10		1.2449	1.1317	1.1128	2.1313	.1886	1.2449
11	1.3957	1.307	1.2071	1.094	2.0559	.2263	1.1506
12	1.3014	1.3817	1.2637	1.0562	1.8107	.2829	1.094
13	1.1317	1.2449	1.2449	1.0751	1.6221	.3206	1.0562
14	1.1694	1.1506	1.2449	1.094	1.773	.3018	1.094
15	1.1883	1.2449	1.226	1.1694	1.9805	.2829	1.1506
16	1.1883	1.3769	1.226	1.2637	1.9993	.2829	1.1506
17	1.1694	1.4335	1.1694	1.2449	2.0182	.3772	1.1128
18	1.1506	1.1506	1.1506	1.2449	1.9427	.415	1.1506
19	1.1317	1.1883	1.226	1.4712	1.8861	.5093	1.226
20	.9997	1.0562		1.5089	1.7164	.5658	1.0185
21	.8865	.9997		1.5466	1.5089	.6602	.8488
22	.8676	.9808		1.3769		.7167	.8865
23	.8676	.9431	.9808	1.3769	1.4901	.7545	.9242
24		.9431	.9619	1.1883	1.3014	1.4335	.8299
Max	1.3957	1.4335	1.2637	1.5466	2.1313	1.4335	1.358
Min	.8676	.9431	.9242	.8865	1.2826	.1886	.8299
Avg	1.1114	1.1337	1.0814	1.1584	1.6393	.7725	.9989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 208 / 11 KV SIE Ag FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.2778	.2915	.2641	.0754	.0943
2		.0943	.2778	.2785	.2134	.0754	.0943
3		.0943	.2932	.3277	.2134	.0754	.0943
4		.0943	.2932	.3277	.2134	.0754	.1132
5		.1132	.3241	.3647	.2286	.0943	.1132
6		.132	.3549	.4024	.2743	.1132	.132
7		.1509	.4321	.4359	.3048	.1509	.1509
8		.1509	.1132	.1017	.3506	.3772	.3932
9	.4586	.132	.0943	.1132	.5556	.4572	.5079
10	.5376	.1132	.0943	.1132	.6249	.6097	.5079
11	.6642	.1132	.0754	.1132	.6249	.6249	.5243
12	.68	.1132	.0754	.1132	.6093	.6249	.5281
13	.6249	.0943	.0754	.0943	.5864	.6405	.5281
14	.578	.0754	.0754	.0943	.571	.6249	.4843
15	.6093	.0754	.0747	.0943	.6019	.5937	.4687
16	.0943	.0754	.0747	.132	.0754	.0943	.0943
17	.0943	.0943	.0943	.132	.0566	.1132	.0943
18	.0943	.0943	.1132	.1509	.1132	.1132	.132
19	.1509	.1509	.1132	.132	.1509	.1132	.1698
20	.1509	.1509	.132	.1132	.1509	.132	.1509
21	.1509	.132	.132	.132	.132	.132	.132
22	.132	.2623	.2629	.1524	.1132	.132	.1132
23	.1132	.2778	.298	.1806	.0943	.0943	.0943
24		.0943	.2778	.298	.2107	.0754	.0943
Max	.68	.2778	.4321	.4359	.6249	.6405	.5281
Min	.0943	.0754	.0747	.0943	.0566	.0754	.0943
Avg	.3422	.1239	.1846	.1954	.3056	.2589	.2421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 201 / 11 KV OM COLD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2634	2.1879	1.8107		1.9239	1.1317
2		2.1879	2.1502	1.8107		1.8861	1.1317
3		2.1125	2.1125	1.8107		1.8107	1.1506
4		1.9993	2.0936	1.8107		1.6975	1.1317
5		2.0748	2.0559	1.8484		1.7541	1.1506
6		2.1125	2.037	1.8861		1.6598	1.1506
7		2.0936	2.3388	2.1125		1.6221	1.2637
8	2.1125	2.0936	2.1313	2.0936		.9619	1.3769
9		2.3011	2.4143	2.584			2.2634
10		2.452	2.7726	2.7161			2.3388
11	2.999	3.1499	2.8669	2.9047	2.5652		2.6217
12	3.1876	2.9235	3.0744	2.9235	2.5652		
13	2.8858		2.5652	2.6029	2.2257		
14	2.999		2.7915	2.452			
15	3.0744		3.1687	2.7349	2.3954		
16	3.0367		3.0367	2.7915	2.4709		
17	2.9801	3.0367	2.9424		2.3577		
18	2.9424	2.6783	2.8858		2.2068		
19	2.6029	2.6406	2.5463	2.3388	2.0936		2.3954
20		2.2634	2.3011		1.9616	.9997	2.1125
21	2.3765	2.32	2.2445		1.9993	1.1128	2.0748
22		2.1691	2.0182		2.037		2.0182
23		2.3765	1.9239		1.9616	1.1506	2.0559
24	2.1125	2.3011	2.2068		2.1691	1.9616	1.1317
Max	3.1876	3.1499	3.1687	2.9235	2.5652	1.9616	2.6217
Min	2.1125	1.9993	1.9239	1.8107	1.9616	.9619	1.1317
Avg	2.7758	2.3775	2.4528	2.3078	2.2315	1.5451	1.6765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 202 / 11 KV KVC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5466	1.7164	1.4523		1.6221	1.1317
2		1.5089	1.6975	1.4335		1.5844	1.1694
3		1.4335	1.6598	1.4335		1.5466	1.2071
4		1.358	1.6409	1.4712		1.5089	1.2449
5		1.4901	1.6032	1.5466		1.5655	1.2826
6		1.6409	1.5844	1.6787		1.6032	1.3203
7		1.6221	1.773	1.4901		1.6032	1.1883
8	1.358	1.773	1.7164	1.7353		1.2637	1.358
9		1.9239	1.8107	1.9616			1.7164
10		1.9993	2.1125	1.9993			1.905
11	2.3765	2.1502	2.1313	2.0182	2.2068		1.9239
12	2.0936	2.1879	2.1125	2.2257	2.0936		
13	1.8107	2.2257	2.3011	2.0748	1.7918		
14	1.7918	2.3011	2.2634	1.9239			
15	2.1879	2.4143	1.9993	2.1313	2.2822		
16	1.9239		2.5463	2.584	2.3011		
17	1.773	2.3388	2.3011		2.1879		
18	1.6787	2.2445	2.037		2.0936		
19	1.6221	2.0559	2.2822	1.8484	1.9616		1.773
20		1.773	2.037		1.5278	1.094	1.4901
21	1.4901	1.6598	1.6409		1.6032	1.1883	1.5089
22		1.6409	1.7353		1.6975		1.5278
23		1.7541	1.5466		1.6598	1.2449	1.5844
24	1.3957	1.4146	1.7353	1.4712	1.4712	1.6032	1.1317
Max	2.3765	2.4143	2.5463	2.584	2.3011	1.6221	1.9239
Min	1.358	1.358	1.5466	1.4335	1.4712	1.094	1.1317
Avg	1.7918	1.8460	1.9160	1.8044	1.9137	1.4523	1.4390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 203 / 11 KV DIAMOND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2452	.7545	.6979		.8299	.2075
2		.2263	.7545	.6979		.7922	.2075
3		.2263	.7733	.6979		.7545	.2075
4		.2075	.7545	.6979		.7167	.2075
5		.2075	.7545	.6979		.7733	.2263
6		.2263	.7733	.7167		.7922	.2263
7		.2263	.547	.7922		.7733	.1886
8	.2075	.2075	.3018	.3584		.1886	.1698
9		.3018	.3772	.3395			1.0374
10		.3395	.9619	.4338			1.0374
11	.3018	.3584	.9619	.415	1.0374		1.0374
12	.3206	.3206	.9808	.4338	1.094		
13	.3018	.3206	.9242	.3018	.3772		
14	.3772	.3395	.9619	.3395			
15	.3961	.3395	.9997	.3961	.4527		
16	.3206		.415	.3961	.9619		
17	.3018	.3395			.9431		
18	.3206	.3206			.9242		
19	.2641	.3206	.9431	.3206	.3584		.9242
20		.3961	.9242		.7356	.2263	.3772
21	.2641	.5658	.7922		.2641	.2075	.3772
22		.811	.5847		.9054		.8865
23		.7922	.679		.8865	.2075	.3772
24	.1886	.2452	.7545	.7167	.7545	.8676	.2075
Max	.3961	.811	.9997	.7922	1.094	.8676	1.0374
Min	.1886	.2075	.3018	.3018	.2641	.1886	.1698
Avg	.2971	.3428	.7579	.5250	.7458	.5941	.4649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 204 / 11KV NATRAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.358	1.1506	1.1883		1.2071	.9997
2		1.2826	1.2071	1.2071		1.1694	.9997
3		1.2071	1.2449	1.2071		1.1317	1.0185
4		1.2071	1.3014	1.2071		1.0562	1.0185
5		1.3014	1.358	1.2071		1.094	1.0374
6		1.1317	1.3957	1.226		1.1317	1.0374
7		1.226	1.226	1.3014		1.0562	1.2071
8		1.2071	1.3392	1.2071		1.0562	1.2826
9		1.5089	1.4712	1.5655			1.3392
10		1.6598	1.6032	2.1879			1.5278
11	1.9239	1.9616	1.7353	2.1125	1.9427		1.9805
12	2.0936	1.8296	1.9993	2.0748	2.1691		
13	1.4712	1.8484	1.4901	1.773	1.7164		
14	1.9993	1.8861	1.8107	1.6975			
15	2.2634	1.9427	1.905	2.2068	1.905		
16	2.2257		2.0559	1.8861	1.9616		
17	1.773	1.7164	1.9239		1.8107		
18	1.6409	1.5089	1.7541		1.4146		
19	1.4712	1.3769	1.3203	1.4335	1.1883		1.5466
20		1.2637	1.2071		1.1506	.9808	1.358
21	1.5278	1.226	1.226		1.226		1.3203
22		1.358	1.2637		1.226		1.1694
23		1.358	1.2071		1.1883	.9242	1.3957
24	1.3203	1.3203	1.094	1.1883		1.1694	.9808
Max	2.2634	1.9616	2.0559	2.2068	2.1691	1.2071	1.9805
Min	1.3203	1.1317	1.094	1.1883	1.1506	.9242	.9808
Avg	1.7918	1.4646	1.4704	1.5487	1.5749	1.0888	1.2482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 205 / 11 KV OMKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8107	1.5089	1.3957		1.5844	.7545
2		1.7353	1.4901	1.3957		1.6975	.7922
3		1.6975	1.4712	1.3769		1.6221	.8299
4		1.6598	1.4523			1.5466	
5		1.7353	1.4335	1.3769		1.6787	.8865
6		.9808	1.4146	1.2826		1.4712	.8865
7		1.3957	1.7918	1.6409		1.2071	.8676
8	1.8296	1.3769	1.5844	1.7164		.5281	.9808
9		1.9239	1.7353	1.3769			1.5655
10		2.0748	2.0936	2.1125			1.7541
11	1.6221	2.3388	2.1313	2.3954	1.8861		2.32
12	2.3388	1.8107	2.3954	2.4143	2.2257		
13	2.0559	1.773	1.9427	1.7353	2.037		
14	2.037	1.773	1.8107	1.773			
15	2.32	1.7918	1.4901	2.1502	1.7353		
16	2.1125		1.6975	1.9993	.7167		
17	1.9993	2.037	1.5844		1.7353		
18	1.773	1.2637	1.4523		1.6409		
19	1.7541	1.7353	1.3769	1.9239	1.1317		1.9427
20		1.6787	1.358		1.3957	.4904	1.1317
21	1.5089	1.1883	1.226		1.4523	.5658	1.3014
22		2.0182	1.8673		1.7353		1.8107
23		1.1694	1.8484		1.6598	.6413	1.4335
24	1.7541	1.9616	1.5089	1.5466	1.6221	1.094	.7167
Max	2.3388	2.3388	2.3954	2.4143	2.2257	1.6975	2.32
Min	1.5089	.9808	1.226	1.2826	.7167	.4904	.7167
Avg	1.9254	1.6926	1.6527	1.7419	1.6134	1.1773	1.2484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 206 / 11 kv Adimaya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.226	1.3392	1.0751		1.2449	1.1883
2		1.2071	1.3203	1.0751		1.2071	1.2071
3		1.1694	1.3014	1.0751		1.1694	1.1883
4		1.1317	1.2826	1.0751		1.094	1.1694
5		1.1506	1.2637	1.0751		1.1317	1.1506
6		1.1883	1.2449	1.094		1.1506	1.1317
7		1.1694	1.2637	1.0562		1.2449	1.2449
8	1.094	1.1506	1.3203	1.4335		.9431	1.3014
9		1.358	1.358	1.6409			1.6975
10		1.4712	1.5089	1.7918			1.6975
11	1.7918	1.905	1.5089	1.6598	1.9239		1.6975
12	1.7164	1.8861	1.5466	1.8107	1.8673		
13	1.3392	1.8861	1.5466	1.6409	1.5844		
14	1.6032	1.8484	1.5844	1.6221			
15	2.037	1.9239	1.5466	1.6975	1.7918		
16	1.7353		1.4712	1.5466	1.773		
17	1.773	1.773	1.5466		1.6975		
18	1.7164	1.6787	1.6221		1.6787		
19	1.4712	1.6032	1.4901	1.2826	1.5089		1.5655
20		1.2826	1.358		1.226	.8676	1.3392
21	1.1506		1.1317		1.1694		1.3014
22		1.2071	1.1317		1.2449		1.2826
23		1.3392			1.2071	1.0751	1.3014
24	1.094	1.2071	1.3392	1.094	1.1317	1.2637	1.2071
Max	2.037	1.9239	1.6221	1.8107	1.9239	1.2637	1.6975
Min	1.094	1.1317	1.1317	1.0562	1.1317	.8676	1.1317
Avg	1.5435	1.4438	1.3925	1.3748	1.5234	1.1266	1.3336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 207 / 11 kv mandhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3203	1.4712	1.2826		1.3014	.7545
2		1.2826	1.4335	1.2637		1.2449	.7733
3		1.2637	1.5655	1.2449		1.2071	.7733
4		1.2071	1.3203	1.2449		1.1694	.7922
5		1.2449	1.2637	1.2826		1.2071	.811
6		.9997	1.2071	1.3014		1.1694	.811
7		1.1128	.9997	1.3957		1.0374	.7545
8	1.3203	1.1317	1.2826	1.2449		.8488	.9431
9		1.6598	1.7541	1.6598			.9054
10		1.8107	1.7541	1.7353			.8865
11	1.9239	1.905	1.8673	1.7541	1.773		1.9993
12	1.4901	1.5844	1.8673	1.7164	1.7918		
13	1.3769	1.6975	1.5655	1.1883	1.4335		
14	1.6787	1.7353	1.5844	1.3203			
15	1.4335	1.773	2.0559	1.4523	1.6787		
16	1.5844		1.6598	1.6598	1.4712		
17	1.5089	1.905	1.5089		1.6598		
18	1.2826	1.4712	1.4335		1.8673		
19		1.4901	1.6221	1.3957	1.6787		1.7541
20		1.5278	1.5089		1.094	.7922	1.4712
21	1.5278	1.3769	1.358		1.5466	.7545	1.4335
22		1.5844	1.5278		1.5089		1.3203
23			1.358		1.2637	.7733	1.1694
24	1.3769	1.3392	1.4901	1.3203	1.6221	1.2637	.7545
Max	1.9239	1.905	2.0559	1.7541	1.8673	1.3014	1.9993
Min	1.2826	.9997	.9997	1.1883	1.094	.7545	.7545
Avg	1.5004	1.4738	1.5191	1.4146	1.5684	1.0641	1.0651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 208 / 11 KV Devika

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.1509	.1698		.1698	.1698
2		.1698	.1509	.1698		.1698	.1698
3		.1698	.1509	.1698		.1509	.1698
4		.1698	.1509	.1698		.1509	.1698
5		.1698	.1698	.1886		.1698	.1698
6		.1698	.1698	.2075		.1886	.1698
7		.1886	.1698	.2075		.1886	.1698
8	.1886	.2075	.2075	.2452		.2263	.1886
9		.2075	.2263	.1886			.1698
10		.2263	.2263	.2452			.1698
11	.2829	.2452	.2263	.2641	.2452		.1886
12	.2641	.2263	.2452	.2641	.2641		
13	.2452	.2263	.2263	.2075	.2452		
14	.2452	.2075	.2263	.2263			
15	.2829	.2075	.2263	.2263	.2829		
16	.2641		.2263	.1886	.3206		
17	.2641	.2263	.2263		.3018		
18	.2829	.2263	.2075		.2263		
19	.1886	.2075	.1886	.1698	.2075		.1886
20		.1698	.1886		.1886	.1886	.1698
21	.1698	.1698	.1698		.1698	.1698	.1698
22		.1698	.1698		.1698		.1509
23		.1698	.1698		.1698	.1886	.1509
24	.1509	.1886	.1509	.1698	.1698	.1698	.1886
Max	.2829	.2452	.2452	.2641	.3206	.2263	.1886
Min	.1509	.1698	.1509	.1698	.1698	.1509	.1509
Avg	.2358	.1960	.1925	.2044	.2278	.1776	.172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 402 / 33 KV Shah Presicast Unit NON SHEDDABLE EXPRESS HV FEEDERS
 III Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2263	.2263	.2263		.2263	.2942
2		.2263	.2263	.2263		.2263	.2942
3		.2263	.2263	.2263		.2263	.2942
4		.2263	.2263	.2263		.2263	.2942
5		.2263	.2263	.2263		.2263	.249
6		.2263	.2263	.2263		.2263	.249
7		.2263	.2263	.2263		.2263	.2263
8	.4923		.2263	.2263		.249	.2263
9		.2263	.2263	.2263			.2263
10		.2263	.2263	.2263			.2263
11	.2263	.2263	.2263	.4131	.2263		.2263
12	1.3297	1.319	.2263	1.2901	1.2166		
13	1.3014	1.3128	1.1826	.2263	.6168		
14	.2263	1.2901	1.1996	1.2109			
15	1.2731	.2263	1.1996	1.2335	.5772		
16	.8771		.5545	.7695	1.2449		.6337
17	1.1487	.2263	.5319				.5432
18	.2263	.2263	.2263				.5772
19	.2263	.2263		.2263	.2263		.2263
20		.2263	.2263		.2263		.2263
21		.2603	.2263		.2263		.2263
22		.5093	.2263		.2263		.2263
23		.4017	.2263		.2263	.2942	.2263
24	.2263	.2263	.2263	.2263	.2263	.2263	.2942
Max	1.3297	1.319	1.1996	1.2901	1.2449	.2942	.6337
Min	.2263	.2263	.2263	.2263	.2263	.2263	.2263
Avg	.6867	.3961	.3801	.4366	.4763	.2354	.2993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 201 / 11 KV Mahavir

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 202 / DATTANAND FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 203 / 11 KV Godavari

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 204 / 11 KV Galaxy
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	.4191
Max	.4191
Min	.4191
Avg	.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 205 / 11 KV Bamnoli

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.2772
Max	.2772
Min	.2772
Avg	.2772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 401 / 33 KV Parvati Agro Plast
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.679
Max	.679
Min	.679
Avg	.679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 404 / 33KV BASHKO

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.8002
Max	.8002
Min	.8002
Avg	.8002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 201 / 11 KV Ankur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6733	.8413	.5426	.7011	.8596	1.2437	.1387
2	.6805	.8322	.5426	.7087	.8505	1.0974	.1189
3	.6661	.8048	.631	.6379	.8596	1.0745	.1097
4	.6516	.7865	.7011	.6447	.8688	.7202	.0229
5	.4744	.7956	.8596	.7602	.8779	.5571	.0732
6	.8573	.7682	.8954	.8238	.7964	.4321	.2439
7	.9114		1.0456	.8505	.8131	.3269	.3841
8	.8916	.7964	1.2178	.8962	.7712	.1372	.2008
9	1.4937	1.2894	1.6598	1.2696	1.1462	.1189	1.0631
10	1.773	1.4045		1.3817	1.39	.1867	.759
11	1.1462	1.2437	1.5844	1.5089	1.5089	.1334	1.2567
12	1.4327	1.2308	1.5089	1.358	1.307	.1494	1.3032
13	1.2826	1.1827	1.4335	.7087	1.358	.104	.9945
14	1.3443	1.2936	1.5089	1.419	1.4937	.0842	1.1789
15	1.4335	1.419	1.5089	1.5089	1.4175	.1067	1.1706
16	1.4563	1.3957	1.358	1.358	1.358		1.419
17	1.2696	1.3957	1.2826	1.358	1.39	.064	1.39
18	1.1203	1.2826	.8048	1.2803	1.358	.0286	1.419
19	.5182	1.1827	1.1203	.8505	1.3443	.0495	.9412
20	.8505	.9412	.7796	.7796	1.0242	.0743	.8322
21	1.0029	1.0349	.961	1.2178	1.1088	.0693	.823
22	.9313	.7011	.8596	1.134	.9214	.0907	.7316
23	.9412	.5426	.8596	.9313	1.0745	.08	.7621
24	.6733	.8505	.5426	.7712	.9214	1.2437	.0854
Max	1.773	1.419	1.6598	1.5089	1.5089	1.2437	1.419
Min	.4744	.5426	.5426	.6379	.7712	.0286	.0229
Avg	1.0198	1.0442	1.0525	1.0358	1.1175	.3553	.7259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 202 / 11 KV LOKMAT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4054	.3841	.3521	.3319	.4108	.3018	.128
2	.3948	.3201	.3521	.3018	.4001	.3018	.1097
3		.3292	.3574	.2766	.3292	.2926	.1257
4	.3567	.3246	.3574	.2808		.2926	.1257
5		.3681	.3521	.3109	.3841	.317	.1372
6	.4054	.3734	.3772	.3368	.4001	.3414	.1654
7	.4999	.3628	.3841	.3829	.439	.16	.2
8	.506	.3887	.6413	.3574	.4599	.1486	.2686
9	.7712	.6379	.7164	.6104	.7964	.1494	.5144
10	.9709	.8596	1.0562	.9335	1.0745	.1974	.7628
11	.9431	1.1317	1.1949	.9808	1.2071	.1654	.9709
12	1.0349	1.0456	1.1088	.7628	1.3203	.1536	.9709
13	.7956	.8505	.9568	.6859	1.086	.2027	.8505
14	.9808	.9511	.9214	.8299		.2286	.8413
15	.9979	.961	.9412	.9709	1.1203	.2187	.9511
16	.8962	1.0349	1.0456	.9709	1.0136		1.0242
17	.9511	.9412	.9313	.961	.9412	.1829	.9412
18	.7164	.823	.7712	.7164	.8596	.1654	.8322
19	.6783	.6173	.7042	.6554	.7461	.1833	.6478
20	.4999	.6104	.5182	.3254	.631	.1783	.602
21	.4374	.4146	.447	.4458	.3574	.1536	.4793
22	.3948	.4146	.7545	.4054	.4451	.1635	.5075
23	.4054	.3772	.3887	.4108	.4001	.1387	.4599
24	.4054	.3948	.3521	.3628	.4161	.2743	.1387
Max	1.0349	1.1317	1.1949	.9808	1.3203	.3414	1.0242
Min	.3567	.3201	.3521	.2766	.3292	.1387	.1097
Avg	.6567	.6215	.6659	.5670	.6926	.2135	.5315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 206 / 11 KV MIDC Water Supply

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6036	.6224	.7545	.6036	.5658	.6468
2	.5658	.5658	.6036	.679	.6036	.5658	.6468
3		.5658	.6036	.6413	.6036	.5658	.6468
4	.5658	.5658	.7167	.6413	.6036	.5658	.6468
5	.5658	.7167	.5658	.6413	.7167	.7356	.6468
6	.7545	.7733	.6036	.679	.8676	.7356	.7392
7		.8865	.8676	.7545	.9242	.7545	.8686
8		.8676	.811	.8488	.8488	.7545	.924
9	.7392	.7545	.7167	.8299	.7545	.811	.8316
10	.6468	.7545	.7577	.8299	.679	.6224	.7167
11	.6468	.679	.6653	.7207	.6099	.5093	.6979
12	.5544	.6036	.6468	.6838	.499	.4527	.6036
13	.5914	.5658	.6283	.6283	.5359	.4338	.5658
14	.5914	.5658	.5914	.6283	.5658	.4904	.4904
15	.5914	.5658	.5729	.6283	.5729	.4715	.4904
16	.4251	.6036	.5544	.6099	.5544		.5093
17	.5914	.5658	.5914	.6283	.5914	.4904	.5847
18	.7733	.6413	.7023	.7023	.7207	.6224	.7922
19	1.2071	1.1317	1.1694	1.1694	1.1317	1.0534	1.1317
20	1.2449	1.1317		1.1694	1.1317	1.0719	1.1317
21	1.1128	1.226	1.1128	1.1128	1.0751	1.0534	1.094
22	.9619	1.226	1.0751	.9431	.9808	.924	.9808
23	.7545	.7545	.9054	.7545	.7545	.7392	.9431
24	.5658	.6413	.6224	.8299	.6413	.5658	.7023
Max	1.2449	1.226	1.1694	1.1694	1.1317	1.0719	1.1317
Min	.4251	.5658	.5544	.6099	.499	.4338	.4904
Avg	.7150	.7482	.7264	.7712	.7321	.6763	.7513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 207 / 11 KV Bharat Steel
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0061	.0061		.0122	.0076	.0057	.0038
2	.0061	.0091	.0057	.0152	.0114	.0057	.0038
3	.0061	.0122	.0057	.0152	.0171	.0057	.0038
4	.0076	.0152	.0057	.0183	.021	.0057	.0038
5	.003	.0213	.0038	.0213	.0305	.0057	.0095
6	.0061	.0488	.0038	.0274	.04	.0057	.0572
7	.0076	.061	.1818	.0286	.3429	.0057	.0857
8	.2427	.192	.2724	.1966	.3475	.0057	.7095
9	.7461	1.4335	.2724	.3704	.3521	.0057	1.5089
10	1.6446	1.2826	.6241	.3315	1.1919	.0019	1.0242
11	1.8861	.2591	1.4045	1.448	.0274	.0057	.3018
12	2.0698	1.3443	1.7924	1.6598	.759	.0019	.3338
13	1.1012	1.358	1.2803	1.7177	1.5844	.0019	1.4723
14		1.358	1.5089	1.3032	1.5089	.0019	1.4175
15		.2743	1.4937	.2366	.3353	.0019	
16	1.2803	.3418	1.6095	1.7909	1.1203	.0019	1.8111
17	.9412	.9214	1.1203	.0084	1.5203	.0019	.3475
18	.8299	2.037	1.643	.0572	.8299	.0019	1.3169
19	1.419	1.5089	1.7353	.0095	1.5089	.0076	1.5089
20	1.1088	.0057	2.1125	.0114	.7392	.0057	1.5089
21	.0107	.0057	.0305	.0171	.0183	.0076	.0057
22	.0061	.0057	.0587	.0152	.0057	.0076	.0057
23	.0061	.0057	.0114	.0057	.0057	.0038	.0057
24	.0061	.0046	.0057	.0152	.0057	.0057	.0038
Max	2.0698	2.037	2.1125	1.7909	1.5844	.0076	1.8111
Min	.003	.0046	.0038	.0057	.0057	.0019	.0038
Avg	.6064	.5213	.7470	.3889	.5138	.0046	.5848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 201 / 11 KV Milk Dairy

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
16	.0362
Max	.0362
Min	.0362
Avg	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 205 / 11 KV Vidyanagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
16	.0358
Max	.0358
Min	.0358
Avg	.0358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 207 / 11 KV Kupwad City

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
17	.0181
Max	.0181
Min	.0181
Avg	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 201 / 11 KV MIRAJ CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4266	1.3969	1.4266	.9145	.9877	.8954	.924
2	1.39	1.3466	1.3717	.8871	.9511	.8596	.9145
3	1.39	1.3146	1.3717	.8507	.9145	.8505	.8779
4	1.39	1.3432	1.4632	.8238	.8779	.8238	.8871
5	1.4632	1.4842	1.5546	.8775	.9877	.8954	1.2567
6	1.6263	1.8839	1.6975	.9313	1.1827	1.1643	1.2936
7	2.0405	2.1253	1.9547	1.1157	1.3535	1.2986	1.3121
8	2.4025	2.4508	2.384	1.3213	1.4266	1.46	1.4969
9	.2743	2.4025	2.3228	1.4083	1.3352	1.2986	1.4083
10	2.3411	2.2916	1.7372	1.5565	1.3756	1.2986	1.3717
11	2.2497	2.2361		1.4299	1.2536	1.1946	1.0608
12	2.19	2.0144		1.3998	1.1789	1.1523	1.0136
13	1.8625	1.6632	1.1641	1.2795	1.1218	1.086	1.0242
14	1.7918	1.6632	1.0808	1.1641	.9745	.9145	1.0498
15	1.7013	1.7002	1.0808	1.134	1.0277	.0183	1.134
16	1.7013	1.6834	1.134	1.1568	1.0402	.0183	1.134
17	1.7375	1.8983	1.0985	1.262	1.1568	.0183	1.267
18	1.1946	2.1262	1.1694	1.258	1.2445		1.3535
19	2.5606	2.6968	1.6476	1.6297	1.7013		1.6827
20	2.6981	2.6787	1.6108		1.6461		1.6461
21	2.5766	2.524	1.4864		1.5893		1.5729
22	2.2546	2.2314	1.3756		1.4083		1.3676
23	1.8111	1.7924	1.134		1.0566		1.1157
24	1.4632	1.4784	1.4449	.9425	.9774	.9145	.961
Max	2.6981	2.6968	2.384	1.6297	1.7013	1.46	1.6827
Min	.2743	1.3146	1.0808	.8238	.8779	.0183	.8779
Avg	1.8141	1.9344	1.4869	1.1672	1.1987	.8979	1.2136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 204 / 11 KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1075	.0914	.1097	.128	.1075	.1294
2	.0914	.0886	.0914	.1109	.128	.1075	.1097
3	.0914	.0876	.0914	.0905	.1097	.0886	.1109
4	.1097	.0895	.1097	.0895	.1097	.1052	.0924
5	.128	.1086	.128	.0895	.1463	.1433	.1478
6	.1478	.128	.1372	.1075	.1663	.2033	.1848
7	.2058	.2218	.2058	.128	.1829	.2378	.2402
8	.1848	.2195	.1848	.1448	.181	.2033	.2033
9	.2743	.2033	.2378	.1829	.2012	.2561	.2561
10	.2561	.2587	.1791	.2172	.2353	.2743	.2561
11	.2195	.1848	.2507	.2172	.2686	.2926	.2353
12	.2195	.2218		.1595	.1907	.2561	.2353
13	.2378	.2033	.1433	.1227	.2279	.2012	.1991
14	.1646	.1433	.7087	.1254	.1772	.1448	.1848
15	.1829	.181	.1595	.1595	.1949	.1646	.1646
16	.1463	.1254	.1595	.1052	.1734	.1267	.1463
17	.1463	.1254	.1417	.1227	.1227	.128	.1646
18	.1267	.124	.124	.1063	.1227		.1646
19	.1463	.1448	.1612	.1433	.1448		.1646
20	.1478	.1629	.1267		.1646		.1463
21	.1307	.1463	.1254		.1478		.1646
22	.1294	.128	.1267		.1463		.1646
23	.112	.1463	.128		.1254		.128
24	.1097	.1109	.1097	.1109	.1267	.1097	.1294
Max	.2743	.2587	.7087	.2172	.2686	.2926	.2561
Min	.0914	.0876	.0914	.0895	.1097	.0886	.0924
Avg	.1591	.1526	.1705	.1322	.1634	.1750	.1718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 205 / 11KV Dairy Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5611	.5487	.5194	.5729	.5249	.6099
2	.463	.5552	.5121	.5249	.5487	.5014	.5975
3	.463	.5487	.5121	.5194	.5544	.5014	.5975
4	.463	.5249	.5121	.5014	.5544	.5068	.5601
5	.5144	.5373		.5014	.5914	.5249	.6413
6	.5721	.5853	.5914	.5249	.6283	.5973	.6722
7	.679	.6447	.6535	.5975	.6584	.6447	.7095
8	.7023	.6838	.6468	.6584	.7392	.6447	.7842
9	.7316	.7577	.8048	.6447	.7577	.6878	.7682
10	.7762	.8215	.7762	.7167	.7011	.7023	.8501
11	.7133	.7842	.7023	.6602	.7922		.7499
12	.7207	.8029	.7095	.5975	.7167		.7577
13	.7499	.7468	.8029	.6348	.6979		.7316
14	.6767	.7095	.7095	.6036	.7733		.7133
15	.6838	.7095	.6722	.5847	.7167	.823	.6584
16	.6468	.6908	.6161	.5658	.6979	.7207	.6838
17	.7392	.6908	.6722	.6036	.6979	.7947	.695
18	.7421	.7087	.9511	.6447	.7499		.8048
19	1.0534	1.0454	.9795	.8682	.9671		.9511
20	.9511	.9492	.9425		.9412		.924
21	.8869	.8954	.8779		.924		.8962
22	.8131	.8507	.8145		.8145		.8686
23	.6219	.7059	.695		.6447		.6468
24	.5316	.5729	.567	.543	.5792	.5487	.6099
Max	1.0534	1.0454	.9795	.8682	.9671	.823	.9511
Min	.463	.5249	.5121	.5014	.5487	.5014	.5601
Avg	.6837	.7118	.7074	.6007	.7092	.6231	.7284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 206 / Vidya nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3077	.2926	.2686	.2715	.2896	.2957
2	.2572	.3045	.2926	.2715	.2534	.2865	.2801
3	.2572	.2926	.2926	.2686	.2561	.2686	.2614
4	.2572	.3077	.2926	.2686	.2378	.2896	.2614
5	.2915	.3224	.3109	.2686	.3292	.3077	.3395
6	.3294	.4024	.3511	.3077	.3658	.362	.4294
7	.415	.394	.4294	.3734	.4207	.3761	.4207
8	.3142	.462	.4805	.4572	.3881	.4298	.462
9	.2926	.3696	.4024	.4119	.3658	.362	.4344
10	.3696	.3547	.3511	.415	.333	.3511	.4024
11	.2926	.3174	.2772	.3961	.3206	.3292	.3511
12	.2743	.3174	.2987	.3361	.3018	.2926	.2926
13	.2402	.2801	.2801	.3361	2.5652	.2587	.2772
14	.2561	.2987	.2427	.2829	.2829	.2772	.2378
15	.2772	.2772	.2801	.2829	.2829	.2743	.2561
16	.2743	.2801	.2427	.2829	.2641	.2561	.2402
17	.2957	.2801	.2427	.2641	.3018	.2561	.2743
18	.3439	.3544	.3292	.3582	.3292		.4207
19	.4251	.5316	.5359	.5316	.591		.5304
20	.5487	.5373	.5359		.543		.5304
21	.5249	.5373	.4938		.5544		.5121
22	.5175	.4887	.4706		.4887		.4755
23	.3841	.3982	.3841		.3761		.3511
24	.2743	.3142	.3109	.2896	.2715	.2926	.3142
Max	.5487	.5373	.5359	.5316	2.5652	.4298	.5304
Min	.2402	.2772	.2427	.2641	.2378	.2561	.2378
Avg	.3321	.3638	.3509	.3336	.4456	.3089	.3604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 401 / 33 KV Bedag outgoing(
Crossove Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8235	2.0953	2.7149	2.6886	4.6811	4.2981	2.6749
2	2.8235	1.8604	2.5789	3.2156	5.1532	4.1907	2.572
3	2.7401	1.7878	2.4714	2.6063	5.144	3.9866	2.7566
4	2.7401	1.773	2.4977	2.5252	5.9156	3.9438	2.8607
5	2.7149	1.8461	2.552	2.4714	6.5729	4.7279	2.9647
6	2.8235	1.8656	2.5789	2.4691	6.9102	5.7659	3.7551
7	3.1893	2.6057	4.6696	4.5542	7.0696	8.834	3.9815
8	3.095	6.0357	7.3303	6.5701	9.0895	10.6447	4.8097
9	3.3848	1.8296	3.8409	3.6214	1.749	1.5364	3.9283
10	4.2267	5.2469	4.3724	3.8146	9.1221	7.9138	4.0809
11	7.0782	5.2092	5.8774	4.5068	10.8596	6.7833	3.2933
12	6.5867	4.3644	5.8128	3.9095	10.5881	6.5101	4.8325
13	7.1765	4.7325	5.1955	5.695	10.3155	6.4392	4.768
14	5.072	4.3644	4.9411	5.0503	10.0452	4.7531	4.9228
15	6.0951	5.3635	4.8377	4.9954	7.3846	4.5668	5.8493
16	7.0445	5.5739	4.161	4.8354	7.2531	5.112	5.4898
17		5.2532	5.0497	5.9185	9.3393	5.0223	5.1612
18	3.6928	3.922	3.6145	3.1361	1.6118	3.7037	3.0967
19	2.7984	3.095	3.1699	1.7375	2.2262	3.1379	2.4577
20	2.2177	1.086	2.9864		2.1399	2.9647	3.2442
21	2.2405	3.0407	3.3311		1.9959	3.3288	3.2933
22	2.6057	3.1493	3.6923		1.5364	2.3137	3.2065
23	1.6244	2.0633	5.048		4.513	2.572	2.2119
24	2.9864	1.9959	2.7692	2.3285	4.1152	4.3896	2.7778
Max	7.1765	6.0357	7.3303	6.5701	10.8596	10.6447	5.8493
Min	1.6244	1.086	2.4714	1.7375	1.5364	1.5364	2.2119
Avg	3.8165	3.3400	4.0039	3.8325	6.0555	4.8933	3.7079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 201 / 11 KV KRIPAMAYEE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 203 / 11 KV INDIAN OIL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 201 / 11KV Jagdish IRON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9427			1.905		
2	1.8107			2.1529		
3	1.7353			2.191		
4	1.9805			2.0559		
5	1.8484			2.2291		
6	2.0195			2.1719		
7	1.9624			2.2291		
8	1.475					
9	1.105	1.6766			.9335	
10	1.5242	1.7147			1.0374	
11	1.6766	2.0576			1.6221	
12	1.5089	2.0748			1.6194	
13	1.5497	1.6385			1.5432	
14	.3868	2.3243			.3292	
15	2.3624	1.7147			1.3908	
16		1.6975			1.4146	
17			2.191			1.8296
18			2.1529			2.1338
19			1.1317			2.3815
20			2.0576			2.0559
21			1.4146			2.2068
22			2.21			2.3053
23			2.1691			2.4387
24	1.6032			2.1148		
Max	2.3624	2.3243	2.21	2.2291	1.6221	2.4387
Min	.3868	1.6385	1.1317	1.905	.3292	1.8296
Avg	1.6557	1.8623	1.9038	2.1312	1.2363	2.1931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 202 / 11 KV Mahabal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712			1.4712		
2	1.2071			1.3392		
3	1.358			1.4335		
4	1.3203			1.3203		
5	1.1576			1.4335		
6	.7164			1.4146		
7	.7964			1.4335		
8	1.6004					
9	1.9052	1.2193			.2953	
10	1.9433	1.905			.1486	
11	1.9814	1.3717			.3467	
12	1.8671	1.1694			.3254	
13	1.1317	.7392			.2429	
14	1.6975	.9619			.2675	
15	2.1529	2.1125			.2984	
16		1.3336			.2	
17			1.9805			1.6004
18			1.448			1.5432
19			1.4712			1.3769
20			.9522			1.5432
21			1.5623			1.6575
22			1.5242			1.0082
23			1.4712			.9896
24	1.5051			1.5623		
Max	2.1529	2.1125	1.9805	1.5623	.3467	1.6575
Min	.7164	.7392	.9522	1.3203	.1486	.9896
Avg	1.4882	1.3516	1.4871	1.4260	.2656	1.3884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 203 / 11KV Shreeji

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207			.462		
2	.4163			.4854		
3				.4207		
4	.439			.462		
5	.4251			.4207		
6	.4294			.462		
7	.3982			.5014		
8	.3721					
9	.5335	.6979			.1646	
10	.5335	.6602			.216	
11	.5716	.6908			.1669	
12	.4954	.679			.0966	
13	.3772	.547			.1235	
14	.547	.7733			.1257	
15	.7049	.7468				
16		.6722			.1257	
17			.591			.7282
18			.567			.6653
19			.5201			.6908
20			.4887			.3761
21			.4835			.3898
22			.3721			.2949
23			.4572			.3761
24	.4715			.5041		
Max	.7049	.7733	.591	.5041	.216	.7282
Min	.3721	.547	.3721	.4207	.0966	.2949
Avg	.4757	.6834	.4971	.4648	.1456	.5030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 204 / 11KV JK ICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5497			1.3394		
2	1.4563			1.2536		
3	1.3535			1.3169		
4	1.4415			1.166		
5	1.2894			1.258		
6	1.2136			1.0802		
7	1.3352			.8097		
8	1.4377					
9	1.0974	1.5089			.4561	
10	2.0576	1.8861			.5325	
11	2.21	2.1313			.4321	
12	1.7147	1.9814			.4561	
13	.9214	1.1827			.3113	
14	1.6221	1.6975			.3906	
15	1.9814	1.9243			.3601	
16		1.8099			.2915	
17			1.905			1.4523
18			1.7541			1.0425
19			.9425			1.4784
20			.7802			1.2986
21			1.5278			1.4335
22			1.423			1.4937
23			.9745			1.531
24	1.6787			1.5339		
Max	2.21	2.1313	1.905	1.5339	.5325	1.531
Min	.9214	1.1827	.7802	.8097	.2915	1.0425
Avg	1.5225	1.7653	1.3296	1.2197	.4038	1.39

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 205 / 11KV Shakti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326			.6882		
2	.8505			.8495		
3	.7362			.9114		
4	.8063			.78		
5	.8402			.8718		
6	.7619			.6836		
7	.8764			.6562		
8	.6964					
9	1.1949	1.3817			.337	
10	1.2449	1.9814			.3267	
11	1.2826	2.2481			.2467	
12	1.2449	2.2634			.2606	
13	1.2637	1.9052			.2542	
14	1.358	1.9052			.2953	
15	1.7353	1.4861			.2743	
16		2.1879			.2926	
17			1.9433			1.2826
18			1.9814			1.1203
19			1.4901			1.2826
20			1.2437			1.1041
21			1.0498			.985
22			.8192			.9412
23			.9362			.964
24	.8775			.6958		
Max	1.7353	2.2634	1.9814	.9114	.337	1.2826
Min	.6964	1.3817	.8192	.6562	.2467	.9412
Avg	1.0376	1.9199	1.3520	.7671	.2859	1.0971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 206 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203			1.5278		
2	1.3769			1.4335		
3	1.2826			1.5089		
4	1.3392			1.2637		
5	1.3014			1.5655		
6	1.2637			1.2071		
7	1.2323			1.1763		
8	1.2323					
9	1.6385	1.5242			.4902	
10	1.6004	2.1125			.8775	
11	1.5623	1.9427			.8962	
12	1.7147	1.9239			.8326	
13	1.5466	1.7353			.4199	
14		1.3392			.3467	
15	2.0386	1.8296			.8775	
16		1.2955			.8238	
17			2.0576			2.0386
18			1.6575			1.848
19			1.773			1.7353
20			1.3769			1.6409
21			1.226			.7316
22			1.5432			1.6409
23			1.7718			1.4712
24	1.3014			1.6787		
Max	2.0386	2.1125	2.0576	1.6787	.8962	2.0386
Min	1.2323	1.2955	1.226	1.1763	.3467	.7316
Avg	1.4501	1.7129	1.6294	1.4202	.6956	1.5866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 210 / 11KV Saptrang
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9425			.7282		
2	.8779			.815		
3	.6836			.6104		
4	.7522			.5079		
5	.6733			.4696		
6	.631			.4801		
7	.6556			.3605		
8	.5571					
9	1.1431	1.3769			.0667	
10	1.4861	1.3769			.0964	
11	1.6004	1.307			.0572	
12	1.3336	.7442			.0526	
13	1.226	.4481			.0644	
14	1.2826	1.1016			.048	
15	1.1883	1.3957			.0934	
16		1.5278			.0644	
17			1.1203			.426
18			1.0562			.8775
19			1.0562			.9335
20			.583			.7602
21			1.0642			.8215
22			1.226			.6268
23			1.2071			1.1203
24	1.1694			1.1949		
Max	1.6004	1.5278	1.226	1.1949	.0964	1.1203
Min	.5571	.4481	.583	.3605	.048	.426
Avg	1.0127	1.1598	1.0447	.6458	.0679	.7951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 401 / 33KV Super Craft Foundry NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0556			2.7161		
2	2.9424			2.8292		
3	2.7161			3.0556		
4	3.0556			2.7726		
5	3.1121			2.6029		
6	2.7161			1.8673		
7	1.7718			.2401		
8	1.7147					
9	1.4861	1.8673			.132	
10	2.8292	3.1367			.1183	
11	3.1687	3.1367			.0772	
12	3.0556	2.6595			.0669	
13	2.8292	2.8858			.108	
14	1.4289	2.7161			.036	
15	3.1121	3.0247			.0594	
16		3.0807			.0874	
17			1.8107			2.1502
18			2.6595			2.6595
19			2.9424			1.9239
20			1.6575			2.5463
21			1.7541			2.037
22			1.7718			3.1687
23			2.6029			1.3717
24	3.0556			3.0556		
Max	3.1687	3.1367	2.9424	3.0556	.132	3.1687
Min	1.4289	1.8673	1.6575	.2401	.036	1.3717
Avg	2.6281	2.8134	2.1713	2.3924	.0857	2.2653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 401 / 33 KV SAHYADRI STARCH
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 201 / 11KV JACKWELL LIS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.8299	.724	.7621	.8002	.5281	.4954
2	.7733	.8299	.7356	.7621	.8002	.6602	.5144
3	.7733	.8299	.6908	.7621	.8002	.6602	.4715
4	.7545	.8299	.724	.7621	.8002	.6602	.4854
5	.7545	.8299	.6908	.7621	.8192	.6859	.5041
6	.7545	.8299	.7167	.6097	.8002	.6859	.4904
7	.7733	.811	.7545	.7621	.8002	.3772	.5144
8	.7733	.811	.7356	.7621	.8002	.5041	.5144
9	.6478	.7577	.7095	.6024	.8002	.5228	.6602
10	.7733	.5658	.7095	.7545	.6668	.3475	.6036
11	.7545	.7922	.8299	.7545	.7811	.2027	.5975
12		.811	.7545	.7545	.8002	.2012	.5975
13	.7468	.7733	.7545	.7167	.7621	.2012	.7468
14	.7468	.7733	.7922	.7356	.7049	.2012	.7468
15	.7356	.7733	.7545	.7545	.7049	.2012	.7207
16	.7468	.7733	.811	.7356	.7049	.5144	.7207
17	.7545	.7733	.811	.7356	.7049	.5144	.7733
18	.811	.7545	.811	.7545	.4904	.2667	.7733
19	.7522	.7922	.811	.7545	.5093	.381	.7733
20	.7701	.811	.7545	.6859	.3772	.5144	.7392
21	.6335	.6478	.7545	.6859	.3772	.4763	.7545
22	.6335	.6097	.6097	.5487	.3921	.5144	.7922
23	.7947	.7621	.6097	.6602	.5281	.5144	.7733
24	.7922	.8299	.7621	.7621	.811	.5281	.5335
Max	.811	.8299	.8299	.7621	.8192	.6859	.7922
Min	.6335	.5658	.6097	.5487	.3772	.2012	.4715
Avg	.7497	.7751	.7421	.7225	.6890	.4527	.6374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 202 / 11KV GANPATI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.57	.6068	.6335	.5609	.5487	.5959	.6024
2	.5365	.6135	.6516	.5609	.5487	.5959	.6135
3	.5087	.543	.6219	.5609	.5544	.6154	.5847
4	.5087	.543	.6401	.5853	.5544	.5973	.6089
5	.583	.6024	.6697	.7316	.5487	.6379	.6135
6	.6173	.6379	.6447	.7362	.7316	.6379	.6379
7	.6697	.691	.7133	.8413	.7316	.691	.6733
8	.788	.7602	.7343	.8063	.7316	.7865	.8145
9	.8326	.7291	.7619	.7442	.7316	.8316	.7701
10	.8238	.8238	.7619	.7619	.823	.7619	.7888
11	.8764	.9134	.8962	.8596	.7499	.8413	.8939
12		.8328	.8676	.8063	.7682	.7628	.8764
13	.8063	.8063	.8413	.7628	.7682	.7802	.8149
14	.7973	.7796	.8962	.7973	.7682	.6935	.8149
15	.7701	.7619	.8962	.7164	.7133	.7265	.7842
16	.7442	.7975	.8402	.7537	.7282	.7522	.7842
17	.7164	.8413	.8402	.7888	.7133	.788	.9709
18	.9665	.9391	.8402	.8413	.8383	1.0745	1.0517
19	1.3672	1.3847	1.475	1.3203	1.2003	1.134	1.4043
20	1.3756	1.3146	1.475	1.3203	1.1831	1.3146	1.3672
21	1.134	1.0631	1.134	1.046	1.0277	1.046	1.1222
22	.9593	.8916	.9511	.9511	.9036	.9088	.961
23	.7602	.7202	.7682	.7122	.7499	.7455	.7602
24	.5765	.6068	.6089	.7095	.5765	.5959	.6135
Max	1.3756	1.3847	1.475	1.3203	1.2003	1.3146	1.4043
Min	.5087	.543	.6089	.5609	.5487	.5959	.5847
Avg	.7951	.8002	.8401	.8031	.7580	.7881	.8303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 203 / 11KV SANGLI WADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4252	.4572	.5373	.5544	.5373	.4938	.4961
2	.4252	.4298	.5792	.5175	.567	.462	.5316
3	.5068	.4119	.6089	.5121	.5729	.462	.5194
4	.543	.4119	.6516	.5121	.5729	.462	.4961
5	.5487	.5359	.695	.5175	.5729	.5359	.5373
6	.695	.6838	.7392	.5121	.7316	.7316	.6024
7	.7655	.7682	.7842	.695	.7865	.7783	.7087
8	.823	.7783	.7947	.8413	.7865	.823	.7392
9	.7522	.7011	.8131	.8328	.7865	.8413	.8059
10	.7796	.7011	.8131	.8495	.7865	.7265	.8149
11	.7186	.7455	.9335	.8842	.7316	.6935	.8507
12		.7108	.8871	.823	.7865		.8316
13	.5784	.6935	.8871	.7545	.7316	.6068	.7577
14	.567	.5959	.7392	.6661	.6838	.6024	.7577
15	.5731	.6241	.7392	.6024	.6979	.591	.7095
16	.6024	.6415	.7108	.6762	.6556	.6089	.7095
17	.591	.6173	.7108	.6762	.6979	.6089	.7087
18	.7122	.6762	.7108	.7455	.6516	.6379	.7265
19	.7207	.9568	.9015	.964	.9391	.7442	.9231
20	.9522	.9134	.9015	.964	.8688	.8596	.9231
21	.8962	.7964	.7011	.8589	.8316	.8145	.8145
22	.7842	.7602	.7011	.7362	.8029	.7682	.7577
23	.5853	.6447	.5853	.6089	.6161	.567	.5729
24	.4572	.4572	.4961	.5304	.5373	.4938	.4656
Max	.9522	.9568	.9335	.964	.9391	.8596	.9231
Min	.4252	.4119	.4961	.5121	.5373	.462	.4656
Avg	.6523	.6547	.7342	.7015	.7055	.6484	.6984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 403 / 33 KV- BALAJIMANDIR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.8688	.9717	.8871	.9328	.9877	.9717
2	.8688	.7602	.9145	.8871	.9134	.9979	.9717
3	.9328	.7762	.9145	.8505	.9134	.9425	1.0288
4	.9328	.7682	.9717	.8413	.7888	.8316	1.0288
5	1.0425	.8779	1.0288	.8505	.7888	.823	1.0288
6	1.0317	.9877	.9717	.9328	.8596	.8779	1.0288
7	1.0425	1.0974	1.086	1.0425	.8413	.9979	1.0288
8	1.0317	1.086	1.1431	1.0974	.9991	.9877	1.086
9	1.1431	1.2357	1.2357	1.2574	1.0745	1.0317	1.1694
10	1.2574	1.2357	1.2357	1.3146	1.0974	.9671	1.3289
11	1.1431	1.2226	1.3032	1.2574	1.0974	.8505	1.2757
12		1.1163	1.3306	1.1431	1.0974	.8745	1.2757
13	.9717	1.0517	1.1523	1.086	1.0425	.8842	1.1043
14	1.0288	1.0745	1.0425	1.2003	.9877	.8939	1.1043
15	1.1431	1.1568	1.0974	1.2003	1.0974	.8939	1.1963
16	1.1431	1.1568	1.0642	1.2574	1.0631	.9134	1.1963
17	1.1431	1.1431	1.0642	1.2574	1.0974	1.0288	1.1963
18	1.0923	1.2003	1.0642	1.182	1.0923	1.1431	1.2226
19	1.2757	1.4289	1.4563	1.2357	1.3289	1.2003	1.2757
20	1.1694	1.2574	1.3443	1.2357	1.2894	1.2574	1.2757
21	1.1043	1.2574	1.3443	1.0745	1.2489	1.1431	1.0631
22	1.0745	1.2003	1.2883	1.0208	1.182	1.2574	1.1163
23	.9671	1.086	1.1088	1.0208	1.0317	1.0288	1.0208
24		.8688	.9717	.9979	.9134	.9877	.9717
Max	1.2757	1.4289	1.4563	1.3146	1.3289	1.2574	1.3289
Min	.8688	.7602	.9145	.8413	.7888	.823	.9717
Avg	1.0640	1.0798	1.1294	1.0888	1.0324	.9918	1.1236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 404 / 33 KV -MJP SHERINALA STAGE NON SHEDDABLE EXPRESS HV FEEDERS
NO- Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1629	.2286	.2218	.2195	.1646	.0572
2	.1629	.1629	.2286	.2218	.2149	.1663	.0572
3	.1646	.1663	.2286	.2126	.2218	.1663	.1143
4	.1646	.1646	.2286	.2126	.2629	.1663	.1143
5	.1646	.1646	.2286	.2126	.2103	.1646	.0572
6	.2172	.1646	.2286	.2195	.2149	.1646	.1143
7	.2195	.2743	.2286	.2195	.2103	.1663	.1143
8	.1629	.2172	.1715	.1646	.2103	.1646	.0572
9	.1715	.1612	.1612	.2286	.2149	.1629	.0532
10	.1715	.2149	.1612	.2286	.2195	.1612	.0532
11	.1143	.2126	.2172	.1715	.2195	.1595	.0532
12		.2126	.2218	.2286	.2195	.1543	.0532
13	.2286	.2103	.2195	.2286	.2195	.156	.1578
14	.2286	.2686	.2743	.2286		.1578	.1578
15	.2286	.2629	.2743	.2858		.1052	.156
16	.1715	.2629	.2801	.2858	.2126	.1075	.156
17	2.1148	.2286	.2801	.2858	.2195	.1143	.156
18	.156	.2286	.2801	.2686	.208	.0572	.1595
19	.1595	.2286	.2801	.2149	.1595	.1143	.1595
20	.1595	.2286	.2801	.2149	.1612	.1143	.1595
21	.1578	.2286	.2801	.2149	.1629	.1143	.1595
22	.2149	.1715	.2801	.2149	.1612	.0572	.1595
23	.2149	.2286	.2218	.2149	.1629	.0572	.1612
24	.1612	.1629	.2286	.2218	.2149	.1646	.0572
Max	2.1148	.2743	.2801	.2858	.2629	.1663	.1612
Min	.1143	.1612	.1612	.1646	.1595	.0572	.0532
Avg	.2640	.2079	.2380	.2259	.2055	.1367	.1124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 201 / 11KV RAMMANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6668	.724	.7545	.5853	.6287	.6478
2	.5853	.6097	.6287	.7167	.5853	.6097	.6097
3	.5792	.5906	.5716	.679	.5792	.5906	.5906
4	.5487	.5525	.5335	.6036	.567	.5906	.5716
5	.5853	.6097	.5906	.5658	.5853	.6478	.5906
6	.6401	.6478	.6287	.6036	.6036	.6668	.6287
7	.6767	.7049	.743	.679	.6838	.724	.724
8	.7133	.724	.7049	.7545	.7316	.7811	.7621
9	.7316	.7621	.724	.7545	.7133		.8002
10	.7133	.7049	.7621	.6859	.6859	.6859	.8192
11	.724	.6767	.724	.5906	.6859	.6478	.8192
12	.6668	.6584	.7049	.6287	.6859		.7621
13	.6097	.6401	.6859	.6668	.724		.724
14	.6287	.6154	.6668	.6097	.6668		.6668
15	.7922	.6036	.6287	.5525	.6287	.7922	.6287
16	.5716	.6219	.5906	.4954	.6287	.679	.6287
17	.6668	.6036	.7049	.5716	.6097	.7545	.6859
18	.8383	.7621	.743	.5853	.8383	.7922	.7865
19	1.2003	1.1241	1.094	.9877	1.1622	1.1241	1.0608
20	1.1622	1.105	1.094	.9511	1.1241	1.0669	1.0608
21	1.0288	1.0479	.9808	.9877	1.0288	1.0288	.9694
22	.9145	.9526	.9054	.8962	.7811	.8764	.8779
23	.8383	.8764	.8299	.7682	.7811	.8002	.7682
24	.0191	.724	.7811	.7922	.6219	.6478	.6859
Max	1.2003	1.1241	1.094	.9877	1.1622	1.1241	1.0608
Min	.0191	.5525	.5335	.4954	.567	.5906	.5716
Avg	.7099	.7327	.7394	.7034	.7203	.7568	.7446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 202 / 11KV SHAMRAO NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.5906	.6287	.6036	.5175	.5716	.5906
2	.499	.5525	.5906	.5658	.4938	.5335	.5525
3	.499	.5144	.5335	.4904	.4805	.4954	.5144
4	.4805	.4763	.4954	.4527	.4805	.4954	.4954
5	.5121	.5144	.5335	.4527	.5121	.5335	.5335
6	.567	.5906	.6097	.5658	.5544	.5716	.6287
7	.6099	.6097	.6287	.6036	.5729	.6478	.7049
8	.6584	.6287	.6668	.6979	.6283	.7049	.724
9	.6584	.6668	.6478	.679	.6838		.743
10	.5853	.6287	.6668	.724	.6859	.6287	
11	.6859	.5914	.7049	.7049	.7049	.5906	.8002
12	.6287	.6283	.6859	.6859	.7049	.5281	.7049
13	.5716	.6219	.6668	.6287	.6859		.6478
14	.5716	.5304	.6478	.5906	.6478		.6097
15	.5335	.5121	.6097	.5525	.6287		.5906
16	.5906	.5359	.6478	.5144	.6097	.6413	.6097
17	.6287	.5304	.6478	.5335	.5906	.6413	.5906
18	.6668	.6478	.743	.5853	.8192	.679	.7207
19	.9717	.9717	.9431	.924	1.0479	.9526	.924
20	.9526	1.0288	.9619	.8871	1.0288	.9145	.9328
21	.9145	.9717	.9054	.8316	.9335	.8954	.8596
22	.8573	.8954	.8299	.8048	.8764	.8383	.8413
23	.743	.8192	.679	.6767	.6668	.724	.6401
24	.0191	.6287	.6859	.6413	.5487	.5906	.6478
Max	.9717	1.0288	.9619	.924	1.0479	.9526	.9328
Min	.0191	.4763	.4954	.4527	.4805	.4954	.4954
Avg	.6218	.6536	.6817	.6415	.6710	.6589	.6786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 204 / 11KV CIVIL HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5525	.5335	.5281	.5601	.4763	.4763
2	.4854	.5144	.5144	.5281	.5415	.4572	.4763
3	.4854	.4954	.4954	.5281	.5415	.4572	.4572
4	.4854	.4763	.4572	.5281	.5228	.5144	.4763
5	.5041	.5335	.5144	.415	.5601	.5525	.5144
6	.5415	.5716	.5906	.5281	.5601	.6097	.5525
7	.5975	.5906	.6287	.5658	.5975	.5335	.5716
8	.6722	.6097	.6097	.6036	.5788	.4763	.6097
9	.5975	.6478	.6478	.6413	.4668		.6478
10	.5788	.4191	.6287	.4191	.5525	.5525	.5906
11	.6287	.6722	.4763	.4763	.5525		
12	.5716	.5788	.5335	.5335	.5335		.6668
13	.5144	.4854	.6287	.4954	.5525		.6287
14	.6097	.3547	.5906	.4382	.5716		.5906
15	.4382	.5041	.5716	.4001	.5716	.5658	.5716
16	.4191	.5228	.5525	.362	.5335	.3395	.5906
17	.4572	.4481	.4001	.5335	.4954	.4527	.6668
18	.6287	.4954	.6097	.5415	.4572	.5658	.6722
19	.743	.5906	.7167	.6535	.5716	.4763	.7095
20	.7049	.7049	.679	.6722	.6859	.6859	.5601
21	.6859	.6668	.679	.5228	.5716	.6478	.5415
22	.6287	.6478	.6413	.5228	.5144	.5716	.6722
23	.6097	.6287	.6036	.5975	.4763	.5335	.6348
24	.0382	.6097	.5906	.5658	.5601	.4954	.4954
Max	.743	.7049	.7167	.6722	.6859	.6859	.7095
Min	.0382	.3547	.4001	.362	.4572	.3395	.4572
Avg	.5479	.5550	.5789	.5250	.5471	.5244	.5815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 205 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.4001	.4572	.4527	.3696	.362	.4001
2	.3326	.3429	.4001	.415	.3511	.3429	.362
3	.3292	.3429	.3429	.3772	.3511	.3429	.3429
4	.3142	.3239	.3239	.3395	.3326	.3429	.3429
5	.3547	.3429	.362	.3395	.3696	.4001	.381
6	.4024	.4572	.4382	.3772	.4294	.4572	.4191
7	.4668	.5144	.4954	.4527	.499	.4763	.4954
8	.4938	.4763	.4572	.4904	.499	.4954	.4954
9	.4207	.4954	.4763	.415	.439		.4954
10	.3696	.4191	.5144	.381	.4191	.4001	.5335
11	.4001	.3511	.3429	.381	.362	.3239	.5144
12	.3429	.3292	.3429	.362	.3048	.3018	.362
13	.3239	.2587	.3239	.362	.3429	.3018	.3429
14	.3048	.3109	.3048	.3429	.3239	.3018	.3239
15	.2858	.2926	.3239	.3429	.3048		.3048
16	.2477	.2926	.3048	.3429	.2667	.2829	.2858
17	.3048	.2772	.3239	.362	.2858	.3018	.3048
18	.4001	.4001	.381	.4066	.4763	.3772	.4805
19	.7049	.7049	.679	.7207	.743	.6859	.6767
20	.724	.724	.679	.695	.724	.6859	.6584
21	.6859	.6859	.6413	.6468	.6859	.6478	.6401
22	.5906	.6287	.6036	.6099	.6478	.5525	.6036
23	.5144	.5716	.5658	.499	.4763	.4763	.4755
24	.0191	.4382	.4954	.4904	.3881	.381	.4191
Max	.724	.724	.679	.7207	.743	.6859	.6767
Min	.0191	.2587	.3048	.3395	.2667	.2829	.2858
Avg	.4035	.4325	.4408	.4418	.4330	.4200	.4442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 206 / 11KV TRIMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.5144	.5716	.5658	.4668	.4763	.5144
2	.4481	.4763	.5144	.5281	.4481	.4572	.4763
3	.4481	.4572	.4763	.4904	.4481	.4382	.4382
4	.4481	.4382	.4572	.4527	.4481	.4382	.4191
5	.4668	.4954	.5144	.4527	.4854	.4954	.4763
6	.4854	.5716	.5716	.5281	.5041	.6287	.5335
7	.6348	.6097	.6097	.5658	.6161	.7049	.6478
8	.6722	.6478	.6478	.6413	.6908		.6859
9	.6722	.6859	.6859	.6036	.6908		.7049
10	.6908	.724	.7049	.724	.743	.743	
11	.7811	.8215	.8383	.6859	.7621	.8383	.8192
12	.7621	.7655	.8002	.6859	.8002	.7167	.7621
13	.724	.7468	.7621	.6287	.8192		.724
14	.6859	.7468	.7621	.6097	.7811		.7049
15	.7049	.7468	.7621	.6287	.743		.6859
16	.7621	.7655	.743	.6097	.8002	.9054	.743
17	.8002	.7842	.8002	.6478	.8383	.9054	.8002
18	.8192	.8192	.8192	.7095	.9335	.8676	.8215
19	1.0288	1.0098	1.094	.8962	1.105	1.1241	1.0082
20	1.0098	.9907	1.0185	.9335	1.0669	1.0479	.9709
21	.9335	.9145	.9054	.8775		.9335	.8775
22	.7811	.8383	.7167	.7282	.8002	.8192	.7468
23	.6668	.7049	.6413	.5975	.6668	.6668	.6348
24	.0191	.5335	.6287	.6036	.4668	.4954	.5525
Max	1.0288	1.0098	1.094	.9335	1.105	1.1241	1.0082
Min	.0191	.4382	.4572	.4527	.4481	.4382	.4191
Avg	.6630	.7004	.7102	.6415	.7011	.7212	.6847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 403 / 33 KV RISALA ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8461	2.1148	2.4577	2.3765	1.8107	2.1719	2.2862
2	1.7375	1.8861	2.1148	2.2634	1.7558	1.7718	2.0576
3	1.6289	1.7718	1.8861	2.037	1.6289	1.7718	1.8861
4	1.5746	1.6004	1.6575	1.9239	1.5746	1.829	1.829
5	1.7375	1.829	1.829	1.6975	1.7375	1.8861	1.8861
6	1.8461	2.0005	2.0576	1.8107	1.9004	1.8861	1.9433
7	2.0851	2.2862	2.1719	1.9239	2.009	2.1719	2.2862
8	2.524	2.6292	2.3434	2.1502	2.2805	2.3434	2.4006
9	2.524	2.8006	2.5149	2.3765	2.3891		2.4577
10	2.5789	2.6863	2.6863	2.4006	2.5149	2.4577	
11	2.8006	3.1493	2.9721	2.915	2.6863	2.572	3.3722
12	2.5149	3.1493	2.9721	2.8006	2.8578	2.5463	3.2579
13	2.9721	3.1493	3.0293	2.7435	2.915	2.6029	3.0293
14	2.8578	2.8778	2.915	2.6863	2.7435	2.4897	2.8578
15	2.8006	2.8778	2.8578	2.6292	2.6292	2.3765	2.8006
16	2.915	2.8778	2.8006	2.4006	2.7435	2.4331	2.8578
17	3.0293	2.9081	3.1436	2.5149	2.8578	2.4897	3.0293
18	3.5437	2.9721	3.2579	2.3348	3.315	2.6029	3.1493
19	4.1152	4.0581	3.8477	3.4751	3.9438	3.7723	3.7466
20	4.0581	3.8295	3.8477	3.5837	3.8295	3.6008	3.6923
21	3.658	3.6008	3.2819	3.3665	3.3722	3.3722	3.4019
22	3.2579	3.4294	2.8292	2.7692	2.9721	3.1436	2.8235
23	2.8006	3.2007	2.7161	2.3594	2.5149	2.915	2.3594
24	.1144	2.4006	2.8578	2.6029	1.9004	2.2862	2.5149
Max	4.1152	4.0581	3.8477	3.5837	3.9438	3.7723	3.7466
Min	.1144	1.6004	1.6575	1.6975	1.5746	1.7718	1.829
Avg	2.5634	2.7536	2.7103	2.5059	2.5368	2.4997	2.6924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 404 / 33KV KOLHAPUR ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3608	3.4865	3.5437	3.7346	3.4728	3.5437	3.6008
2	3.2487	3.3722	3.3722	3.6214	3.2487	3.4865	3.4865
3	3.2487	3.315	3.2579	3.5082	3.2487	3.315	3.3722
4	3.1367	3.1436	3.2007	3.3951	3.2487	3.315	3.315
5	3.3608	3.3722	3.315	3.3951	3.5848	3.6008	3.5437
6	3.5288	3.5437	3.658	3.6214	3.7529	3.7723	3.8295
7	3.9769	4.1724	4.2295	3.8477	4.0329	4.0009	3.8866
8	4.313	4.2867	4.401	4.1872	4.0889	4.1724	4.0009
9	4.257	4.401	4.6296	4.4136	4.0889		4.5153
10	4.7051	4.3439	4.7439	4.6868	4.5725	3.9438	
11	4.5725	4.8171	5.0869	4.8011	4.5725	3.658	4.9154
12	4.7439	4.7611	4.9726	4.6868	4.5153	3.6214	4.8011
13	4.1152	4.481	4.7439	4.4582	4.5153	3.4517	4.5725
14	4.1152	4.313	4.7439	4.401	4.1724	3.3951	4.3439
15	4.3439	4.0329	4.7439	4.401	4.0009	3.1687	4.2867
16	4.401	3.7529	4.8583	4.401	4.0009	3.5082	4.5725
17	4.6296	4.481	4.7439	4.6296	4.0581	3.5082	4.6296
18	4.9154	4.8583	5.0869	4.369	4.6296	3.6214	4.9291
19	5.7728	6.1157	6.1111	5.6573	5.7728	4.9154	5.7693
20	5.6584	5.6584	5.5453	5.4332	5.2584	5.0869	5.6013
21	5.0297	5.144	5.0926	5.0412	4.9726	4.5725	4.9851
22	4.5153	4.6296	4.7531	4.6491	4.6296	4.2295	4.7051
23	4.1152	4.1152	4.1872	4.0889	4.0009	4.0009	4.145
24	3.53	3.7151	3.7723	3.8477	3.5848	3.658	3.7151
Max	5.7728	6.1157	6.1111	5.6573	5.7728	5.0869	5.7693
Min	3.1367	3.1436	3.2007	3.3951	3.2487	3.1687	3.315
Avg	4.2331	4.2630	4.4497	4.3032	4.1677	3.8064	4.3271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 201 / 11 KV SHASTRI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6036	.5281	.6036	.5144	.5658	.4973
2	.5144	.5658	.5281	.547	.5144	.5281	.4973
3	.5144	.5658	.5281	.547	.5144	.5281	.4973
4	.5144	.5658	.547	.547	.5144	.5658	.4973
5	.5316	.6413	.5658	.6036	.5658	.6224	.5658
6	.6173	.7167	.679	.6224	.6859	.679	.7202
7	.7545	.7922	.8299	.6979	.7202	.7733	.7202
8	.7888	.9054	.8299	.7545	.7888	.8488	.7888
9	.7922	.7716	.7202	.7922	.7922	.7545	.8676
10	.8299	.7716	.7888	.811	.7922	.7356	.9242
11	.9054	.7373	.8059	.811	.8488	.811	.9054
12	.8299	.7888	.8059	.7545	.8299	.7733	.8676
13	.811	.7202	.6859	.7167	.811	.7545	.8488
14	.811	.7202		.7167	.7922	.7545	.7733
15	.7922	.7202	.7202	.6979	.7733	.7922	.7356
16	.8299	.6859	.7373	.679	.8299	.8299	.811
17	.7922	.7733	.7733		.811	.7202	.8299
18	.8676	.9054	.9242	.7202	.9808	.7888	.9619
19	1.2637	1.2449	1.1694	.9945	1.2826	1.0631	1.2071
20	1.1506	1.1694		.9259	1.1128	1.0288	1.1506
21	1.0751	1.0562	1.0374	.9259	1.0374	.9945	1.0562
22	.9431	.9619	.9431	.8573	.9242	.8916	.9242
23	.7922	.7733	.7733	.6516	.7545	.7202	.7733
24	.0382	.6413	.6224	.6413	.5316	.6224	.5487
Max	1.2637	1.2449	1.1694	.9945	1.2826	1.0631	1.2071
Min	.0382	.5658	.5281	.547	.5144	.5281	.4973
Avg	.7614	.7833	.7520	.7226	.7801	.7561	.7904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 202 / 11 KV FRUIT MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0754	.0943	.0943	.0857	.0943	.0857
2	.0686	.0754	.0754	.0754	.0857	.0754	.0857
3	.0686	.0754	.0754	.0754	.0857	.0754	.0857
4	.0686	.0754	.0754	.0754	.0857	.0754	.0857
5	.0686	.0754	.0754	.0754	.0857	.0754	.0857
6	.0857	.0943	.0943	.0943	.0857	.0943	.0857
7	.0857	.0943	.0943	.0943	.1029	.0943	.0857
8	.0857	.0943	.0943	.0943	.1029	.0754	.0857
9	.132	.0857	.0857	.1132	.1132	.0754	.1509
10	.1509	.12	.1029	.1132	.132	.1132	.132
11	.1886	.1029	.1029	.132	.1132	.0943	.132
12	.132	.1029	.1372	.1132	.132	.0943	
13	.0943	.1029	.1029	.0943	.1509	.0943	.132
14	.0943	.12		.0943	.1132	.0943	.132
15	.132	.1372	.1372	.1132	.1509	.1132	.1698
16	.1509	.1029	.1029	.1509	.1509	.1132	.132
17	.1509		.132	.1372	.132	.0857	.132
18	.132	.1509	.1509	.12	.132	.1029	.1509
19	.1698	.1698	.1886	.1372	.1509	.1372	.1698
20	.132	.1509	.1509	.1372	.132	.1372	.1509
21	.132	.132	.1509	.12	.132	.12	.132
22	.1132	.132	.132	.1029	.132	.12	.132
23	.0943	.1132	.1132	.1029	.0943	.1029	.1132
24	.0382	.0943	.0943	.0943	.0857	.0943	.0857
Max	.1886	.1698	.1886	.1509	.1509	.1372	.1698
Min	.0382	.0754	.0754	.0754	.0857	.0754	.0857
Avg	.1099	.1077	.1114	.1065	.1153	.0980	.1188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 203 / SPARE1

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.0191
Max	.0191
Min	.0191
Avg	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 204 / SPARE2

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.0191
Max	.0191
Min	.0191
Avg	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 402 / 33KV SHERINALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3148	2.6029	2.7726	2.9424	2.4691	2.6029	2.1091
2	2.3148	2.4331	2.7161	2.7161	2.4691	2.4897	2.1091
3	2.3148	2.4331	2.7161	2.7161	2.4691	2.4897	2.1091
4	2.3148	2.4331	2.7726	2.7161	2.4691	2.6029	2.1091
5	2.3148	2.6029	2.8858	2.9424	2.572	2.8292	2.2634
6	2.8292	3.0556	3.3385	3.1687	3.035	3.0556	2.572
7	3.035	3.3951	3.5648	3.3951	3.0864	2.999	2.7778
8	2.9321	3.4517	3.2407	3.678	3.1893	3.2819	2.8292
9	3.3951	3.3951	3.4979	3.7912	3.3951	3.0556	3.6214
10	3.7346	3.1893	3.4979	3.8477	3.5082	2.999	3.5082
11	3.5082	3.4979	3.7037	3.9609	3.6214	2.8292	3.7912
12	3.7912	3.4465	3.6008	3.7912	3.5082	2.7726	3.7346
13	3.3385	3.2922	3.3951	3.5648	3.3385	2.6595	3.5648
14	3.2819	3.1893	3.4465	3.5082	2.9424	2.6029	3.4517
15	3.4517	3.2922	3.4979	3.4517	3.0556	2.4897	3.4517
16	3.4517	2.7778	3.3951	3.678	3.1687	2.4691	3.678
17	3.5082		3.7912	3.4465	3.1121	2.6235	3.678
18	3.9609	3.9043	4.1307	3.5494	3.5648	2.6235	4.0741
19	4.3004	4.7531	4.8097	4.321	4.4136	3.4979	4.6965
20	4.4702	4.5268	4.4702	4.0638	4.0175	3.6008	4.5268
21	3.9043	3.9609	4.0741	3.7551	3.678	3.1893	3.9043
22	3.6214	3.678	3.7346	3.3951	3.5082	3.035	3.7912
23	3.2825	3.3951	3.5648	2.9321	3.1121	2.6235	3.2819
24	.0572	2.8858	3.0556	3.1687		2.7161	2.3148
Max	4.4702	4.7531	4.8097	4.321	4.4136	3.6008	4.6965
Min	.0572	2.4331	2.7161	2.7161	2.4691	2.4691	2.1091
Avg	3.1428	3.2866	3.4864	3.4375	3.2045	2.8391	3.2478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 201 / 11 KV Government Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3361	.3511	.3361	.3361
2			.3174	.3547	.3326	.3361
3			.3206	.3547	.3361	.3361
4			.3018	.3547	.3361	.3361
5			.3361	.3696	.3361	.4066
6			.3734	.4108	.415	.5175
7		.4805	.4668	.5281	.5658	.5729
8		.5544	.5415	.547	.547	.6099
9		.4435	.5228	.5041	.5041	.5359
10		.3511	.4481	.3734	.4066	.4066
11		.3696	.4108	.3174	.3142	.3511
12		.3361	.3734	.3142	.2957	.2987
13		.3174	.3361	.2957	.2987	.3174
14		.3174	.3361	.2957	.2801	.2829
15		.2957	.3361	.2957	.2987	.2829
16		.3511	.3361	.2772	.2829	.3174
17		.3142	.3361	.3326	.2772	.3511
18		.4066	.3734	.3881	.4066	.4066
19		.6219	.5847	.6283	.6219	.5544
20		.6036	.6447	.6653	.6401	.6283
21		.6036	.6161	.6348	.6401	.5914
22		.5914	.543	.5729	.567	.5544
23	.4294	.4251	.4207	.4251	.4435	.462
24			.3547	.3475	.3696	.3696
Max	.4294	.6219	.6447	.6653	.6401	.6283
Min	.4294	.2957	.3018	.2772	.2772	.2829
Avg	.4294	.4343	.4153	.4141	.4105	.4234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 202 / 11 KV Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2241	.2614	.2241	.2641	.2402	.2263
2		.2241	.2452	.2241	.2614	.2402	.2263
3		.2263	.2452	.2263	.2587	.2427	.2263
4		.2263	.2452	.2263	.2614	.2427	.2263
5		.2829	.2641	.2263	.3018	.2427	.2801
6		.3206	.3174	.2641	.3395	.3018	.3174
7		.3772	.3361	.2801	.3584	.3961	.3547
8		.415	.3734	.3361	.3961	.4191	.3921
9		.4108	.3734	.462	.3961	.3734	.3881
10		.3395	.3547	.3326	.3547	.2957	.3142
11		.1886	.3361	.2957	.3174	.2957	.3326
12		.2801	.2829	.2772	.2427	.2614	.2957
13		.2614	.3206	.2587	.2614	.2427	.2427
14		.2641	.2452	.2402	.2427	.2427	.2452
15		.2587	.3206	.2587	.2241	.2218	.2263
16		.2263	.2452	.2587	.2241	.2241	.2241
17		.2772	.2427	.2587	.2614	.2402	.2402
18	.3734	.3881	.3547	.3174	.3174	.2801	.3511
19	.4854	.5121	.4755	.4755	.4805	.4066	.4805
20	.4854	.4938	.439	.4435	.4805	.4435	.4805
21		.4755	.4572	.462	.4435	.4435	.4805
22		.439	.4066	.4066	.4251	.4066	.4066
23	.3174	.3142	.3142	.3326	.3326	.3326	.3696
24		.2614	.2801	.2614	.2641	.2587	.2427
Max	.4854	.5121	.4755	.4755	.4805	.4435	.4805
Min	.3174	.1886	.2427	.2241	.2241	.2218	.2241
Avg	.4154	.3203	.3224	.3062	.3212	.3040	.3154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 205 / 11 KV CENTRAL BUILDING

SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0189	.3921	.4294	.3921	.3696	.4108
2		.0189	.3734	.4108	.3881	.3734	.4108
3		.0019	.3734	.415	.3921	.3734	.4108
4		.0189	.3734	.3961	.3961	.3734	.4108
5		.0189	.3734	.3961	.4481	.4481	.4108
6		.0189	.4481	.4294	.4904	.547	.499
7		.0189	.4805	.4108	.5544	.5788	.5914
8		.0189	.5544	.4481	.5914	.6535	.7499
9			.7023	.462	.7392	.7282	.8048
10			.7947	.5359	.7392	.8048	.823
11		.0549	.7023	.462	.7947	.7316	.8686
12		.0185	.7023	.4066	.7392	.7682	.8501
13		.0366	.6722	.3881	.7023	.7207	.7762
14		.0358	.6161	.2957	.6468	.5914	.7468
15		.0179	.6348	.3881	.7468	.724	.8131
16		.0358	.6653	.3696	.6653	.5359	.7655
17		.0183	.5359	.4435	.6348	.6348	.6161
18		.439	.499	.3511	.5228	.5359	.5601
19	.2829	.6335	.6283	.5853	.5975	.4294	.5975
20	.2829	.5792	.5544	.5304	.5601	.5853	.5975
21		.5792	.5175	.5175	.5228	.5487	.5788
22		.5487	.4294	.439	.4805	.5359	.5041
23	.0189	.499	.4854	.4066	.4251	.439	.462
24		.0189	.4294	.4294	.3921	.4066	.439
Max	.2829	.6335	.7947	.5853	.7947	.8048	.8686
Min	.0189	.0019	.3734	.2957	.3881	.3696	.4108
Avg	.1949	.1659	.5391	.4311	.5651	.5599	.6124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 201 / 11 KV Doordarshan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.3982	.3982		.3841	.439	.4572
2	.3801	.3801	.362		.3841	.3841	.439
3	.3801	.3801	.362		.3841	.3841	.3881
4	.3841	.3801	.3658		.3841	.3841	.3881
5	.439	.4024	.3658		.4435	.439	.4805
6	.7207	.5914	.6516		.5544	.5175	.695
7	.7762	.8131	.7602		.7762	.7762	.8048
8	.7682	.8131	.7602	.7947	.8316	.7316	.823
9	.7602	.7316	.7602	.8316		.695	.8131
10	.6335	.7059	.6878	.7023	.6335	.6516	.6516
11	.5973	.591	.591	.6584	.5973	.5316	.5493
12	.5731	.5373	.567	.6401	.4706	.4733	.5028
13	.5014	.4733	.5434	.5611	.4748	.4801	.4801
14	.4887	.4207	.5258	.4887	.4287	.463	.4334
15	.4706	.4207	.4733	.4706	.3258	.4578	.4161
16	.4344	.4334	.4382	.4706	.4508	.4161	.4334
17	.4908	.4908		.5373	.5784	.4252	
18	.6104	.6379		.5784	.6173	.6201	
19	.8417	.8238		.7973	.7973	.7442	.7362
20	.8505	.8238		.7973	.8059	.7973	.7362
21	.8328	.7164		.7265	.788	.7265	.7362
22	.7522	7.8441		.6379	.6697	.6733	.6447
23	.543	.5068		.439	.543	.5853	.5373
24	.4298	.4525	.3982	.4163	.439	.4572	.5121
Max	.8505	7.8441	.7602	.8316	.8316	.7973	.823
Min	.3801	.3801	.362	.4163	.3258	.3841	.3881
Avg	.5872	.8654	.5300	.6205	.5549	.5522	.5754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 202 / 11 KV WALCHAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18
HR	Load (MW)	Load (MW)
1	.3881	.4066
2	.3881	.3696
3	.3326	.3696
4	.3326	.3696
5	.3921	.3734
6	.5041	.4527
7	.6161	.5544
8	.499	.6283
9	.7133	.695
10	.7421	.7682
11	.724	.7602
12	.7316	.7133
13	.6219	.7059
14	.6219	.6099
15	.6219	.6584
16	.6878	.6584
17	.6154	.6099
18	.5175	
20	.3696	
21	.5175	
22	.543	
23	.439	
24	.3881	.4435
Max	.7421	.7682
Min	.3326	.3696
Avg	.5351	.5637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 203 / 11 KV VISHRAMBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4266	1.2437	1.1946		1.262	1.2752	1.3717
2	1.4266	1.1157	1.1946		1.2071	1.2197	1.3169
3	1.4266	1.1273	1.1403		1.2197	1.2071	1.2752
4	1.4815	1.1273	1.1523		1.2197	1.2071	1.2752
5	1.4969	1.2936	1.2071		1.3306	1.2071	1.4415
6	1.8296	1.6078	1.6832		1.6078	1.5524	1.701
7	2.1285	1.9239	1.7918		1.7541	1.9044	1.9753
8	2.384	1.9418	1.9605	1.8484	1.9044	2.0165	2.0851
9	2.2731	1.9035	1.8296	1.8484	1.8107	1.885	1.9753
10	2.0485	1.6632	1.6632	1.7741	1.5912	1.5912	1.8107
11	1.8107	1.6078	1.6078	1.5912	1.6461	1.5912	1.701
12	1.7375	1.4415	1.5203	1.4815	1.5364	1.3672	1.5912
13	1.6461	1.3717	1.4661	1.4266	1.4506	1.3289	1.4506
14	1.5364	1.3032	1.4118	1.3169	1.3969		1.3169
15	1.5729	1.3169	1.3717	1.3169	1.3432		1.3169
16	1.5546	1.3717	1.4118	1.2752	1.4118		1.3575
17	1.6827	1.4506		1.3169	1.4118	1.9404	
18	1.7364	1.6655		1.5364	1.701	2.0513	
19	2.364	2.4177		2.364	2.4177	2.4983	2.4434
20	2.4893	2.3102		2.2028	2.4434	2.392	2.3348
21	2.1312	2.1176		2.0953	2.1176	2.1794	2.1176
22	1.9004	1.9547		1.9404	1.9547	1.9667	1.8804
23	1.5364	1.5203		1.6289	1.5364	1.6461	1.5746
24	1.5203	1.2752	1.3575	1.3717	1.3717	1.3306	1.4266
Max	2.4893	2.4177	1.9605	2.364	2.4434	2.4983	2.4434
Min	1.4266	1.1157	1.1403	1.2752	1.2071	1.2071	1.2752
Avg	1.7975	1.5864	1.4685	1.6668	1.6103	1.6837	1.6700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 206 / 11 KV DATTANAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.3467	.3544		.3721	.3224	.3544
2	.591	.3155	.3366		.3189	.3224	
3	.5973	.3224	.3224		.3224	.3224	.3224
4	.5973	.3292	.3224		.3224	.3224	.3224
5	.7059	.3658	.3258		.3761	.3224	.394
6	.9328	.5121	.5068		.4887	.4755	.5068
7	1.1203	.6219	.591		.6653	.6584	.6154
8	1.1523	.6154	.5487	.5853	.5973	.5792	.6516
9	1.0425	.5792	.6036	.6584	.5487	.5068	.6219
10	.8413	.4835	.5068	.2896	.5014	.4887	.5316
11	.7602	.4298	.4298	.2896	.4298	.3224	.4607
12	.724	.4207	.3898	.4706	.394	.3155	.3898
13	.6878	.3681	.3467	.3761	.3391	.3544	.3467
14	.6584	.3641	.3155	.3761	.3391	.3561	.3467
15	.6219	.3086	.3155	.3403	.39	.2715	.3121
16	.6036	.3582	.3429	.3439	.2743	.3086	.3391
17	.6733	.3429		.3801	.3086	.3189	
18	.4115	.5144		.4161	.4024	.3898	
19	.5959	.6516		.6173	.6379	.631	.5959
20	.6241	.6516		.631	.6379	.631	.5959
21	.5895	.6068		.5959	.6024	.5959	.5959
22	.5316	.5375		.5847	.5731	.5959	.5258
23	.4252	.4031		.4733	.4298	.4961	.4207
24	.691	.3544	.3506	.3898	.3721	.3582	.3544
Max	1.1523	.6516	.6036	.6584	.6653	.6584	.6516
Min	.4115	.3086	.3155	.2896	.2743	.2715	.3121
Avg	.7010	.4501	.4064	.4599	.4435	.4277	.4573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 201 / 11 KV Madgule AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9004	2.5339	.3658	.2561	.2534	2.3529	2.9995
2	1.8099	2.652	.3658	.2172	.2561	2.4691	2.9995
3	1.829	2.7149	.3658	.2149	.2353	2.4434	3.0727
4	2.1033	2.9264	.3658	.2507	.2561	2.5606	3.1459
5	2.3777	2.9864	.4344	.3258	.2534	2.5339	3.3303
6	2.5606	3.1093	.543	.3658	.2561	2.7435	3.6199
7	.4024	3.0769	.543	.3982	.2715	2.8959	3.6199
8	.362	.3439	.5373	.4572	.2743	.3077	.3582
9	.362	2.1948	2.9264	2.4072	.2715	.3292	.4344
10	.3258	2.1719	2.6244	2.4434	.2896	.3258	.4207
11	.3292	2.9264	3.2922	2.5339	.2896	.3658	.4024
12	.3439	2.9995	2.7801	2.6505	.2896	.362	.2896
13	.3475	2.7801	2.3167	2.3282	.2896	.362	.2378
14	.3801	3.3653	2.8166	2.4177	.2896	.362	.1829
15	.362	3.5848	2.963	2.5072	.3109	.362	.181
16	.3658	3.4019	2.5339	2.7759	.3077	.3582	.1829
17	.3475	.3582	.2195		.2926	.2865	.2172
18	.3258	.3582	.4024		.2896	.2865	.2926
19	.3292	.5373	.4706		.3109	.4298	.362
20	.3077	.5373	.4344		.3077	.3582	.4024
21	.3439	.5014	.3292		.3292	.3582	.3109
22	2.3529	.4706	.2715		2.1357	2.8959	1.829
23	2.5339	.439	.3109		2.1948	3.0361	2.1719
24	1.5432	2.5789	.3658	.2896	.2507	2.3529	2.9995
Max	2.5606	3.5848	3.2922	2.7759	2.1948	3.0361	3.6199
Min	.3077	.3439	.2195	.2149	.2353	.2865	.181
Avg	1.0102	2.0646	1.1908	1.3435	.4377	1.2974	1.4193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 202 / 11 KV Atpadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.9412	.7316	.7316	1.0498	1.0498	.7316
2	.6584	.9328	.7316	.8688	1.0974	1.0242	.7316
3	.6878	.9955	.7316	.8048	1.1157	.9774	.7316
4	.7602	1.0608	.7964	.905	1.1765	.9877	.8048
5	.905	1.086	.8688	.8779	1.2437	.9955	.8688
6	1.134	1.1157	1.086	.8688	1.267	1.0242	1.1584
7	1.2803	1.1222	1.5203	1.4083	1.39	1.0679	1.448
8	1.2308	1.1222	1.3611	1.3032	1.267	1.086	1.4685
9	1.2308	1.1523	1.2894	1.2536	1.2308	1.2071	1.3253
10	1.2127	1.1765	1.4118	1.2178	1.2437	1.2127	1.2308
11	1.2254	1.182	1.2437	1.182	1.1765	1.1946	1.2803
12	1.1946	1.2536	1.2308	1.1462	1.1765	1.182	1.086
13	1.2254	1.2178	1.1584	1.086	1.134	1.1462	.9511
14	1.2308	1.2178	1.086	1.0974	1.086	1.1104	1.0136
15	1.1765	1.182	1.0136	1.0608	1.1157	1.0745	1.0745
16	1.2071	1.182	1.0974	1.0974	1.1041	1.182	1.086
17	1.1706	1.2894	1.1222		1.1157	1.182	1.1584
18	1.1222	1.4327	1.3717		1.1222	1.182	1.3394
19	1.1523	1.5043	1.4118		1.1888	1.4327	1.4632
20	1.1222	1.4327	1.2803		1.1946	1.2894	1.3394
21	1.1157	1.2894	1.086		1.2254	1.0745	1.086
22	1.086	1.0745	.9511		1.1765	.9774	.9511
23	1.086	.8688			1.0974	.8048	.724
24	.695	1.0791	.8048	.695	.8326	1.086	.7316
Max	1.2803	1.5043	1.5203	1.4083	1.39	1.4327	1.4685
Min	.6584	.8688	.7316	.695	.8326	.8048	.724
Avg	1.0669	1.1630	1.1038	1.0356	1.1595	1.1063	1.0743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 203 / 11 KV Pujarwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.1086	.3292	.2561	.2195	.1097	.0366
2	.0366	.1097	.3292	.2195	.2172	.1086	.0366
3	.0366	.0905	.3292	.2172	.2378	.1097	.0366
4	.0362	.0914	.3292	.2561	.2353	.1086	.0366
5	.0362	.0905	.3258	.2715	.2561	.128	.0362
6	.0724	.0914	.3439	.3109	.2534	.1267	.0543
7	.0905	.0905	.4525	.4706	.2743	.1267	.0724
8	.0732	.1086	.0716	.0732	.2743	.1267	.1075
9	.2378	.1097	.0716	.0724	.2896	.2195	.4344
10	.4163	.1086	.0362	.0543	.2926	.2896	.5731
11	.439	.0724	.0366	.0362	.2896	.5304	.5121
12	.4344	.0537	.0181	.0366	.2896	.5121	.4525
13	.4572	.0358	.0366	.0366	.2896	.4755	.4755
14	.4706	.0537	.0362	.0366	.3077	.4572	.4572
15	.4706	.0537	.0362	.0366	.3109	.5121	.4344
16	.4755	.0537	.0366	.0366	.2896	.5068	.4024
17	.1829	.0537	.0362		.1267	.0537	.0362
18	.1629	.0716	.0549		.128	.0716	.0549
19	.1463	.1075	.0543		.1267	.0716	.0724
20	.1448	.1075	.0549		.1097	.0716	.0549
21	.128	.0716	.0543		.1097	.0716	.0724
22	.1086	.2715	.2561		.1086	.0543	.0362
23	.1086	.3109	.2896		.1086	.0366	.0362
24	.0366	.1097	.3292	.2561	.2195	.1097	.0366
Max	.4755	.3109	.4525	.4706	.3109	.5304	.5731
Min	.0362	.0358	.0181	.0362	.1086	.0366	.0362
Avg	.2016	.1011	.1645	.1575	.2235	.2079	.1899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 204 / 11 KV Pujarwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.1448	.1097	.1829	.1629	.181	
2	.1254	.128	.1097	.1463	.1629	.2012	
3	.1254	.1448	.1097	.1448	.1646	.1991	
4	.128	.1463	.1448	.1097	.181	.1991	
5	.1829	.1448	.181	.1086	.1829	.2195	
6	.2195	.1646	.2172	.1463	.181	.2172	
7	.2561	.181	.2534	.2172	.1991	.2195	
8	.2172	.181	.2149	.2195	.2012	.2172	
9	.2172	.1829	.2149	.2195	.1991	.2378	1.4685
10	.1991	.181	.2172	.2195	.181	.2353	
11	.2012	.2149	.2926	.1829	.181	.2172	
12	.2172	.2865	.2534	.181	.181	.1791	
13	.2195	.2149	.2195		.2172	.1791	
14	.2353	.1433	.2172	.181	.2172	.1433	
15	.2353	.1433	.2561	.1991	.2172	.1433	
16	.2378	.1075	.2172	.1991	.2172		
17	.2172	.1433	.2507		.2012		
18	.2012	.1433	.2715		.1991		
19	.1991	.1791	.2896		.2195		
20	.1991	.1791	.2896		.2172		
21	.2012	.1433	.3258		.2012		
22	.181	.1086	.2534		.1991		
23	.1629	.1086	.2195		.1829		
24	.1254	.1646	.1097	.181	.181	.181	
Max	.2561	.2865	.3258	.2195	.2195	.2378	1.4685
Min	.1254	.1075	.1097	.1086	.1629	.1433	1.4685
Avg	.1929	.1616	.2183	.1774	.1937	.1981	1.4685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 205 / 11 KV Madgule Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.2353	.1829	.181	.3109	.2561	.1463
2	.181	.2561	.1829	.1829	.3077	.2561	.1463
3	.181	.2534	.1829	.2172	.2926	.2561	.1463
4	.1991	.2561	.2195	.2561	.2896	.2715	.181
5	.2865	.2715	.2534	.2896	.1463	.2743	.2172
6	.2926	.2743	.362	.3292	.3258	.2896	.3258
7	.3582	.2896	.362	.362	.3292	.2896	.362
8	.3658	.3077	.3582	.3658	.3439	.3077	.3582
9	.2926	.3109	.3224	.2896	.1829	.3292	.394
10	.2534	.3258	.1097	.2172	.1991	.3439	.2715
11	.2561	.1791	.1086	.2172	.2172	.3258	.2378
12	.2715	.1433	.1463	.1829	.2172	.2865	.2534
13	.2743	.1433	.1448	.1463	.2378	.2865	.1829
14	.3077	.1433	.1829	.1448	.2378	.2507	.181
15	.2896	.1433	.1448	.1448	.2534	.2149	.2172
16	.2743	.1433	.1463	.1494	.2534	.1791	.2195
17	.2378	.1791	.181		.2534	.1791	.2534
18	.2172	.2507	.2172		.2743		.2743
19	.2195	.3582	.3292		.3258	.3582	.3258
20	.2172	.3582	.2534		.2926	.3224	.2195
21	.2378	.2865	.2195		.4706	.2507	.181
22	.2353	.2507	.1829		.2926	.2172	.2195
23	.2534	.181	.2172		.2743	.1829	.181
24	.7716	.2561	.1829	.1829	.1448	.2715	.1829
Max	.7716	.3582	.362	.3658	.4706	.3582	.394
Min	.181	.1433	.1086	.1448	.1448	.1791	.1463
Avg	.2773	.2415	.2164	.2270	.2697	.2695	.2366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 206 / 11 KV Atpadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1629	1.1706	.9145	1.1888	.1267
2	.1075	.1463	1.1706	.8688	1.1403	.1267
3	.1086	.1448	1.2437	.8413	1.267	.128
4	.1086	.128	1.2803	.905	1.4632	.1267
5	.1448	.1267	1.267	1.0974	1.448	.1463
6	.1829	.128	1.3756	1.2308	1.6461	.1448
7	.1829	.1267	2.0995	2.3411	1.6289	.1448
8	.181	.1267	.3582	.2172	1.7194	.1448
9	1.1888	.128	.1448	.1829	.1829	1.0974
10	2.2262	.1267	.1829	.1463	1.8099	1.267
11	2.3045	.1463	.1448	.1463	1.9909	2.268
12	2.2624	.1829	.1097	.1448	1.828	2.4143
13	2.3777	.1829	.1086	.1448	1.8099	2.4143
14	2.5339	.1829	.1448	.1448	1.8099	2.268
15	2.4434	.1829	.1829	.1448	1.8099	2.4143
16	2.5423	.2195	.181	.1448	1.8099	
17	.1829	.2149	.1829		.1646	
18	.181	.2149	.2172		.1629	
19	.1829	.2507	.2172		.1463	
20	.1629	.2507	.2561		.1448	
21	.1646	.2149	.2896		.1463	
22	.1629	1.0136	.9145		.1448	
23	.181	1.1706	.9412		.128	
24	1.5432	.1829	1.1706	.8688	1.2071	.1267
Max	2.5423	1.1706	2.0995	2.3411	1.9909	2.4143
Min	.1075	.1267	.1086	.1448	.128	.1267
Avg	.9069	.2481	.6398	.6167	1.1166	.9599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 401 / 33 KV Soot Girani

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.963	2.8778	3.1824	2.7435	2.3348	2.9864	3.1824
2	2.9321	2.7435	3.2922	2.8235	2.3594	2.963	3.1824
3	3.0407	2.7692	3.2922	2.9321	2.4434	2.8778	3.1824
4	3.0407	2.8532	3.0727	2.963	2.4691	2.7984	3.2579
5	3.2579	2.8778	2.9321	2.8532	2.4977	2.8235	3.0407
6	3.3665	2.9081	2.9321	2.7149	2.5789	2.8778	2.8235
7	3.3665	2.9321	2.8235	2.7149	2.6063	2.9321	2.7149
8	2.9012	2.9321	2.7938	2.8532	2.7435	2.963	2.4714
9	2.364	2.552	3.095	2.8532	2.7692	2.9321	3.2773
10	2.4434	2.4691	2.8532	2.7435	2.7692	2.8778	2.6063
11	2.4691	2.524	2.9321	2.7435	2.8235	2.963	2.2497
12	2.6063	2.963	2.8235	2.8532	2.8235	2.963	2.7149
13	2.6606	2.8532	2.963	2.6863	2.8778	2.963	2.9321
14	2.7149	2.7435	2.8235	2.8235	2.8778	3.2036	2.8235
15	2.7692	2.6337	2.963	2.9321	2.9081	3.095	2.6337
16	2.8532	2.5789	2.9321	3.0407	2.9321	2.9321	2.7149
17	2.7984	2.9012	2.963		2.8778	2.4714	2.6337
18	2.7692	2.9012	2.6063		2.7435	2.0416	2.7149
19	2.8532	2.7938	2.2497		2.7692	2.364	2.8532
20	2.8778	2.6863	2.3348		2.8532	2.1491	2.552
21	2.9081	2.6863	2.4143		2.9081	2.5789	2.7435
22	2.9321	2.7149	2.6063		2.8778	2.2805	2.6337
23	2.8778	2.963	2.963		2.8532	2.963	2.6886
24	2.3148	2.963	3.0727	2.8235	2.6063	28.2351	3.0727
Max	3.3665	2.963	3.2922	3.0407	2.9321	28.2351	3.2773
Min	2.3148	2.4691	2.2497	2.6863	2.3348	2.0416	2.2497
Avg	2.8367	2.7842	2.8715	2.8293	2.7210	3.8431	2.8208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 201 / 11 KV Nelkaranji AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7741	1.4784	1.5074		.0819
2			1.8111	1.2936	1.4918		.0819
3			2.0698	1.2936	1.4918		.0819
4			2.3655	1.6632	1.5249		.0819
5			2.5688	1.848	1.757		.0983
6			2.5873	1.9959	1.8896		.1311
7			2.6797	2.6612	2.3703		.213
8			.2218	.2402	.2172		.213
9			.1848	.1663	1.7652		
10			.1478	.1663	2.5888		
11		.1478				2.9492	
12		.1294		.1663		3.0312	
13				.1646		3.1459	
14		.1294		.1646		2.9165	
15		.1294		.1677		2.7035	
16		.1478		.2033		2.6707	
17				.1848		.1311	
18				.1658		.1638	
19				.2195		.213	
20				.2378		.2458	
21		.2033				.1638	
22		1.4045				.1475	
23		1.4784					
24	.168		1.5154	1.4784	1.5893		.0983
Max	.168	1.4784	2.6797	2.6612	2.5888	3.1459	.213
Min	.168	.1294	.1478	.1646	.2172	.1311	.0819
Avg	.168	.4713	1.6296	.7980	1.6539	1.5402	.1201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 202 / 11 KV Zare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0819	.0819	.0754
2			.0819	.0819	.0754
3			.0819		.0754
4			.0819	.0655	.0943
5			.0983	.0655	.0943
6			.0983	.0655	.1132
7			.0983	.0655	.1132
8			.0819	.0983	.1132
9			.6882		.1132
10			1.1797	1.3108	.0943
11		1.917			
12		2.0153		1.9227	
13		1.8023		1.7604	
14		1.5729		1.7101	
15		1.6876		1.643	
16		1.7204		1.5089	
17		.0819		.1132	
18		.0983		.132	
19		.1475		.132	
20		.1311		.1509	
21		.0983			
22		.0819			
23		.0819			
24	.6874		.0819	.0819	.0754
Max	.6874	2.0153	1.1797	1.9227	.1132
Min	.6874	.0819	.0819	.0655	.0754
Avg	.6874	.8797	.2413	.6106	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 203 / 11 KV Zare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2534	.2896	.2172	
2			.2172	.2715	.1991	
3			.2172	.2715	.2172	
4			.2534	.2715	.2353	
5			.3258	.2896	.3258	
6			.3982	.3077		
7			.5249	.4525	.5068	
8			.4706	.4525	.4706	
9			.4344	.4525	.4525	
10			.362	.4887		
11		.362		.4251		1.5432
12		.3258		.3142		
13		.2896				
14		.2534		.2534		
15		.2896		.2353		
16		.2896		.3258		
17		.3439		.3801		
18		.5068		.3982		
19		.6154				
20		.5792		.543		
21		.5068		.5973		
22		.4525				
23		.362				
24	.2172		.2896	.2896	.2172	
Max	.2172	.6154	.5249	.5973	.5068	1.5432
Min	.2172	.2534	.2172	.2353	.1991	1.5432
Avg	.2172	.3982	.3406	.3655	.3157	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 204 / 11 KV Nelkaranji Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0905	.1448	
2			.0905	.1448	
3			.0905	.1448	
4			.1086	.1448	
5			.1267	.1448	
6			.1448	.1629	
7			.2715	.1991	
8			.181	.1991	
9			.1448	.1448	
10			.1086	.0724	
11		.0905		.1132	
12		.0905		.132	
13		.0905		.0566	
14		.0905		.0943	
15		.0905		.1132	
16		.0905		.0566	
17		.1086		.1494	
18		.1663		.2012	
19		.1848		.2172	
20		.2772		.181	
21		.1448			
22		.1267			
23		.1086			
24	.0724		.0905	.1448	.0724
Max	.0724	.2772	.2715	.2172	.0724
Min	.0724	.0905	.0905	.0566	.0724
Avg	.0724	.1277	.1316	.1410	.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 205 / 11 KV Mitaki AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9877	.823	.6718
2			.9694	.8779	.6718
3			1.0608	.8779	.6554
4			1.134	.9145	.7045
5			1.4266	1.0974	.7865
6			1.4815	1.1523	.8192
7			1.5181	1.5364	.9995
8			.0914	.128	.0983
9			.0914	.0549	1.1797
10			.0914	.0549	1.4746
11		.0914		.0566	
12		.0914		.0566	
13		.0914		.0754	
14		.0914			
15		.0914			
16		.0914			
17		.0914		.0754	
18		.1097		.0943	
19		.128		.1132	
20		.1463		.132	
21		.1097			
22		.6584			
23		.7682			
24	.0543		.8779	.823	.6554
Max	.0543	.7682	1.5181	1.5364	1.4746
Min	.0543	.0914	.0914	.0549	.0983
Avg	.0543	.1969	.8846	.4969	.7924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 206 / 11 KV Walvan AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0819	.0655	
2			.0819	.0655	
3			.0819	.0655	
4			.0819	.0655	
5			.0983	.0655	
6			.0983	.0655	
7			.0983	.0819	
8			.0819	.1311	
9			.8192	1.4746	
10			1.3272	1.8187	
11		1.7204		2.0809	
12		1.7695		2.0481	
13		1.5729		1.9006	
14		1.4746		1.8515	
15		1.6549		1.8023	
16		1.7368		1.5402	
17		.0819		.0914	
18		.0983		.1097	
19		.1311		.128	
20		.1147		.128	
21		.0983			
22		.0819			
23		.0819			
24	.5407		.0819	.0655	.0754
Max	.5407	1.7695	1.3272	2.0809	.0754
Min	.5407	.0819	.0819	.0655	.0754
Avg	.5407	.8167	.2666	.7450	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11 KV Zare (Zare) AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5197	.3201	.1187	.128	.1612	.4191	.6283
2	.5304	.3549	.1174	.124	.181	.4239	.5571
3	.5407	.3658	.1187	.1294	.1829	.4191	.5636
4	.5365	.4062	.1187	.1494	.2033	.4239	.639
5	.547	.4475	.1341	.1867	.2402	.7545	.8383
6	.8619	.6249	.1677	.2149	.2926	1.326	.9389
7	1.2654	1.0936	.1677	.2835	.3326	1.4918	1.406
8	1.7284	.2987	.1357	.3109	.2772	.1696	.2686
9	.1829	1.1469	.4652	.7968	.181	.1696	.2195
10	.181	1.3108	.8215	1.2955	.2149	.2012	.1867
11	.1475	1.326	.9724	1.5203	.181	.1595	.1663
12	.16	1.3927	.9945	1.5497	.1433	.1663	.1829
13	.1781	1.3108	.9835	1.7966	.1612	.1417	.1829
14	.1696	1.1603	.9831	1.7236	.1417	.1433	.1772
15	.1886	1.1736	1.0898	1.4563	.1791	.1612	.1612
16	.1907	1.326	1.1437	1.3765	.1791	.181	.1829
17	.2172	.1357	.2149	.181		.1829	.2218
18	.2743	.1357	.2012	.2012		.1991	.2427
19	.3142	.1677	.2241	.2957		.2195	.2987
20	.2926	.1696	.2452	.2743		.2402	.2743
21	.2743	.1696	.2075	.2195	.181	.2507	.2353
22	.2743	.1509	.1867	.1991	.5087	.4694	.3086
23	.3086	.1526	.1646	.1829	.4239	.4973	.3593
24	.503	.3311	.1174	.1478	.1629	.4191	.5365
Max	1.7284	1.3927	1.1437	1.7966	.5087	1.4918	1.406
Min	.1475	.1357	.1174	.124	.1417	.1417	.1612
Avg	.4328	.6447	.4206	.6143	.2264	.3846	.4074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / Vibhutwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0732	.1254	.0886	.0739	.181	.1063
2	.0924	.0739	.1086	.0895	.0554	.1433	.0895
3	.0914	.0554	.1075	.0895	.0554	.1267	.0914
4	.0934	.0549	.1063	.0905	.0732	.128	.0924
5	.1097	.0914	.124	.0886	.0924	.1254	.128
6	.112	.1294	.1402	.1307	.1307	.1267	.1772
7	.2054	.1867	.1753	.1829	.1867	.1463	.2054
8	.2103	.1698	.1772	.2054	.2054	.1791	.1791
9	.1463	.1867	.1227	.1448	.2195	.1063	.1463
10	.1267	.1791	.124	.1254	.1791	.0895	.1294
11	.128	.1612	.1463	.104	.181	.0914	.112
12	.1086	.1578	.124	.0876	.1791	.1109	.0924
13	.128	.1753	.0905	.1063	.2149	.0924	.1086
14	.1267	.1715	.0914	.1267	.2172	.0886	.128
15	.1075	.1543	.0924	.1267	.1791	.0895	.1478
16	.124	.1578	.1063	.1075	.1791	.1075	.1478
17	.128	.1612	.1063	.128		.1063	.1494
18	.1478	.1791	.1254	.1478		.1174	.168
19	.1867	.2172	.1829	.1867		.1326	.1848
20	.1663	.2172	.1848	.168		.1696	.1663
21	.1294	.2172	.1509	.1294	.2172	.1578	.1478
22	.1097	.1433	.1595	.1097	.2149	.1595	.1494
23	.0905	.1417	.1006	.1086	.2149	.1463	.1109
24	.0934	.0724	.1433	.0848	.0914	.1791	.1063
Max	.2103	.2172	.1848	.2054	.2195	.181	.2054
Min	.0905	.0549	.0905	.0848	.0554	.0886	.0895
Avg	.1273	.1470	.1298	.1232	.1580	.1292	.1360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.8383	1.1203	.9116	.1524	.0886
2	.0953	.0953	.8383	1.1797	.9724	.1334	.0914
3	.0953	.0953	.6706	1.1934	1.0059	.1334	.0924
4	.0953	.1143	.6783	1.2407	1.0562	.1143	.0914
5	.1143	.1334	.8478	1.2742	1.1904	.1143	.1294
6	.1334	.1524	1.5089	1.3763	1.4413	.1524	.1595
7	.2096	.2096	2.0957	2.0622	1.9951	.1905	.1949
8	.2286	.1905	.1905	.1524	.2096	.1905	.1595
9	1.358	.1524	.1143	.1524	2.1795	1.8442	1.4089
10	1.5746	.1524	.1334	.1334	2.3205	2.2377	2.146
11	1.9498	.1524	.1334	.1334	2.1795	2.3266	2.4366
12	2.536	.1715	.1143	.1143	2.1795	2.4034	2.4813
13	2.7018	.1905	.1143	.1143	2.0957	2.4577	2.3371
14	2.364	.1905	.1143	.1334	2.3205	2.6993	2.3975
15	2.34	.1524		.1524	2.0957	2.6825	2.3137
16	2.4646	.1524	.1143	.1334	2.3472	2.649	2.1714
17	.1334	.1334	.1143	.1524		.1494	.132
18	.1524	.1715	.1143	.1524		.1595	.1509
19	.2096	.1905	.1524	.2096		.1646	.1886
20	.1905	.1905	.1524	.1905		.1772	.1886
21	.1524	.1905	1.0227	.1905	.1905	.1791	.1698
22	.1334	1.0174	1.0227	.763	.1715	.1417	.1509
23	.1143	1.0059	1.0898	.9724	.1715	.1254	.1334
24	.0953	.1143	.9221	1.1568	1.0227	.1715	.1097
Max	2.7018	1.0174	2.0957	2.0622	2.3472	2.6993	2.4813
Min	.0953	.0953	.1143	.1143	.1715	.1143	.0886
Avg	.8141	.2264	.5695	.6022	1.4028	.9063	.8301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 201 / 11 KV Hivtad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075		1.2323	1.1203	.0905	.0857
2	.1086		1.2323	1.1069	.0895	.0867
3	.128		1.2323	1.0753	.0886	.0895
4	.128		1.2955	1.0623	.104	.1086
5	.1867		1.4899	1.1544	.1372	.1417
6	.2241		1.6385	1.2631	.2149	.2534
7	.2587		2.1548	1.3108	.2587	.2561
8	.2328		.1848	.2058	.181	.2195
9	1.2803		.1		1.6712	2.0645
10		.2561			2.5072	2.1376
11		.1772		2.2085	2.652	2.5857
12		.1372	.12	2.2771	2.6871	2.3205
13		.1063	.1402	2.2405	2.753	2.4905
14		.1267	.1402	1.8976	2.6543	2.4577
15		.1829	.1417	2.7206	2.5857	2.5396
16		.1254	.1029	2.7183	2.4249	2.2939
17		.0914	.1417	.1433	.1402	.0812
18		.0914	.1753	.1715	.1734	.1829
19		.2195		.208	.2126	.2172
20		.181		.2279	.2353	.2012
21		.1791		.1791	.1753	.181
22		1.0437		.1307	.1387	.181
23					.1075	
24	.1063		1.2323	1.1523	.0895	.0876
Max	1.2803	1.0437	2.1548	2.7206	2.753	2.5857
Min	.1063	.0914	.1	.1307	.0886	.0812
Avg	.2761	.2245	.7503	1.1702	.9322	.9245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 202 / 11 KV Shetphale AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961		.1478	.1509	.503	.4687
2	.5182		.1509	.1509	.5487	.0463
3	.5182		.1509	.1698	.5544	.4801
4	.6154		.1698	.1867	.6219	.5898
5	.9503		.2263	.2614	.7023	.8002
6	1.2125		.3018	.3395	1.4091	1.3923
7	1.3763		.3584	.3772	1.5912	1.6385
8	.2804		.2801	.3395	.2896	.3077
9	.2743		.7611		.2561	.2195
10		1.2894			.1848	.1478
11		1.2955		.1433	.1509	.1294
12		1.5813	1.6842	.1578	.1463	.1267
13		1.6004	1.7814	.156	.1629	.124
14		1.587	1.8351	.1753	.1433	.1387
15		1.5203	1.8623	.2149		.1214
16		1.5223	1.4746	.2353	.1578	.0762
17		.1886	.1791	.1791	.1734	.1886
18		.2481	.1448	.1387	.1402	.3109
19		.2957		.3086	.3292	.362
20		.2743		.3045	.3077	.3292
21		.2587		.2561	.2614	.2801
22		.2054		.503	.5201	.5243
23					.506	
24	.4801		.1478	.168	.503	.4801
Max	1.3763	1.6004	1.8623	.503	1.5912	1.6385
Min	.2743	.1886	.1448	.1387	.1402	.0463
Avg	.6722	.9128	.6857	.2341	.4419	.4036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 203 / 11 KV Banpuri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6009		.1267	.1433	.6642	.6401
2	.5693		.128	.1267	.6562	.6478
3	.5761		.128	.1267	.6481	.6401
4	.6401		.1448	.1463	.7011	.6958
5	1.0526		.1829	.2218	.7682	.7811
6	1.3599		.2241	.2614	1.4582	1.6004
7	1.5729		.2378	.3174	1.8023	1.8138
8	.2743		.2402	.2801	.2149	.2195
9	.1949		1.0526		.1772	.16
10		1.0974			.1387	.1113
11		1.2289		.112	.1052	.104
12		1.2955	1.8351	.1311	.1029	.0995
13		1.8896	1.9662	.1219	.1214	.0972
14		1.8233	1.9433	.1303	.1214	.0914
15		1.8351	1.7004	.1128	.0983	.0743
16		1.6004	1.6575	.0812	.0869	.1174
17		.096	.1372	.125	.1189	.128
18		.1715	.2195	.1852	.1829	.181
19		.2195		.2774	.2865	.2195
20		.2012		.2507	.2427	.2012
21		.1848		.2195	.2149	.1848
22		.1646		.6722	.6859	.5556
23					.7125	
24	.6081		.1267	.1417	.6642	.6554
Max	1.5729	1.8896	1.9662	.6722	1.8023	1.8138
Min	.1949	.096	.1267	.0812	.0869	.0743
Avg	.7449	.9083	.7089	.1993	.4572	.4356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 204 / 11 KV Hivtad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895		.0732	.0924	.0914	.0739
2	.0914		.0732	.0924	.0905	.0732
3	.1097		.0739	.1097	.0914	.0739
4	.1294		.0914	.128	.1086	.0934
5	.1494		.112	.1448	.1294	.1097
6	.2054		.1372	.1829	.2195	.2054
7	.2641		.2195	.2587	.2452	.2263
8	.2218		.1949	.2218	.2054	.1848
9	.1772		.128		.1646	.16
10		.2172			.1402	.1054
11		.1646		.112	.1227	.1097
12		.0914	.1063	.108	.104	.1029
13		.1109	.1227	.0914	.1052	.1227
14		.1097	.1227	.0869	.124	.1029
15		.0914	.1075	.0914	.1075	.1029
16		.1097	.0895	.0772	.0905	.1029
17			.128	.12	.128	.1543
18		.1646	.1433	.1387	.1463	.1772
19		.1829		.2149	.2218	.2012
20		.1646		.2126	.2195	.181
21		.1463		.1734	.1848	.1463
22				.132	.1097	.0914
23					.0754	
24	.0886		.0732	.0914	.0934	.0747
Max	.2641	.2172	.2195	.2587	.2452	.2263
Min	.0886	.0914	.0732	.0772	.0754	.0732
Avg	.1527	.1412	.1174	.1372	.1383	.1294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 205 / 11 KV Shetphale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886		.1698	.1886	.1867	.1848
2	.1867		.1698	.1867	.1829	.1867
3	.2054		.1698	.1867	.1791	.1867
4	.2241		.1886	.2218	.208	.2033
5	.3018		.2641	.2957	.2534	.2641
6	.415		.3772	.4108	.4755	.4904
7	.4904		.5281	.4854	.5281	.5093
8	.4481		.3395	.4527	.4066	.4108
9	.3361		.2801		.3292	.3326
10		.3018			.2896	.2614
11		.2715		.2195	.2378	.2033
12		.1949	.2195	.2172	.2172	.2012
13		.1646	.1991	.197	.2195	.1829
14		.1612	.1949	.2054	.2012	.1612
15		.197	.1753	.1791	.1848	.1928
16		.1949	.1991	.1991	.1848	.197
17			.2804	.2926	.2926	.2303
18		.2172	.2835	.2896	.2926	.439
19		.2218		.4298	.4298	.5601
20				.3988	.4251	.4904
21				.3224	.3361	.3772
22				.2829	.2614	.2452
23					.2075	
24	.1886		.1698	.1886	.1886	.1867
Max	.4904	.3018	.5281	.4854	.5281	.5601
Min	.1867	.1612	.1698	.1791	.1791	.1612
Avg	.2985	.2139	.2476	.2786	.2799	.2912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 206 / 11 KV Banpuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943		.0943	.0886	.1646	.1109
2	.0934		.0943	.0886	.1663	.1075
3	.112		.0943	.0895	.1646	.1075
4	.1307		.1132	.1086	.1848	.1267
5	.1509		.1509	.1267	.1829	.128
6	.1886		.1698	.1829	.2241	.2218
7	.2241		.2075	.2218	.2402	.2402
8	.2054		.1698	.1867	.2012	.2195
9	.1478		.124		.2033	.2218
10		.2195			.1829	.213
11		.1829		.128	.1629	.1372
12		.1006	.1357	.1075	.144	.1029
13		.1029	.1372	.1214	.1423	.1067
14		.1267	.1214	.104	.1619	.1147
15		.1417	.1214	.1387	.1829	.1063
16		.0983	.1402	.1475	.1802	.12
17		.128	.1448	.1341	.1372	.1475
18		.1463	.1791	.1715	.1791	.1829
19		.2195		.1829	.1753	.2402
20				.1791	.1829	.181
21				.1463	.1494	.2012
22		.1494		.1494	.128	.1294
23					.128	
24	.0943		.0943	.0895	.168	.1086
Max	.2241	.2195	.2075	.2218	.2402	.2402
Min	.0934	.0983	.0943	.0886	.128	.1029
Avg	.1442	.1469	.1348	.1378	.1724	.1555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 207 / 11 KV GOMEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549		.6173	.6068	.0514	.0514
2	.0549		.6173	.5895	.052	.0514
3	.0543		.6249	.5658	.0526	.0526
4	.0724		.68	.583	.0709	.0693
5	.0895		.7773	.7042	.0701	.0686
6	.124		.8097	.8383	.1417	.1307
7	.1433		1.1271	.9282	.0747	.1254
8	.1494		.1463	.12	1.1218	.0914
9	.9602		.0724		1.3032	1.0004
10		.0819			1.3032	1.1869
11		.0724		1.4255	1.4255	1.326
12		.0526	.0514	1.4575	1.4754	1.3927
13		.0343	.0537	1.5238	1.5775	1.4746
14		.0549	.0549	1.4752	1.5777	1.3599
15		.0549	.0554	1.4746	1.5775	1.3599
16		.0549	.0526	1.3904	1.4746	1.2163
17		.0543	.0739	.0686	.0693	.0732
18		.0914	.0934		.0876	.0914
19		.1097		.1254	.124	.1254
20		.1097		.1063	.1075	.1086
21		.0867		.0867	.0895	.0914
22		.6783		.0693	.0701	.0732
23				.0867	.0509	
24	.0739		.6173	.6135	.0503	.0509
Max	.9602	.6783	1.1271	1.5238	1.5777	1.4746
Min	.0543	.0343	.0514	.0686	.0503	.0509
Avg	.1777	.1182	.3838	.7066	.5833	.5031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 201 / 11 KV Palaskhel

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6415	.6068	.0953	.0953	.0953	.7802	.7628
2	.631	.5895	.0953	.0953	.0953	.7712	.7973
3	.631	.5959	.0953	.0953	.0953	.7545	.7973
4	.6733	.6024	.0953	.0953	.0953	.7712	.7716
5	.7975	.6935	.0953	.0953	.0953	.8682	.8238
6	1.0517	.8775	.1143	.1143	.1143	1.2403	.8413
7	1.2226	.9114	.1524	.1334	.1334	1.3717	1.1999
8	.1334	.1524	.1524	.1334	.1334	.1143	.1524
9	.1524	.8505	.8954	1.3146	.1334	.1334	.1334
10	.1143	1.1919	1.262	1.6476	.0953	.0953	.1334
11	.1143	1.3289	1.5592	1.6827	.0953	.1143	.1143
12	.1143	1.576	1.5947	1.8204	.0762	.0953	.0762
13	.1143	1.6476	1.7193	1.56	.0953	.0953	.0762
14	.1143	1.5947	1.6651	1.5424	.0762	.0953	.0953
15	.1334	1.595	1.7375	1.4918	.0762	.0572	.0762
16	.0953	1.5083	1.7164	1.4529	.0762	.1143	.1143
17	.1143	.1334	.0953	.0953	.0953	.0762	.1143
18	.0762	.0953	.0953	.0953	.0953	.1143	.1334
19	.1524	.1334	.1334	.1143	.1334	.1334	.1524
20	.1715	.1715	.1334	.1334	.1334	.1905	.1715
21	.1715	.1524	.1334	.1143	.1143	.1524	.1715
22	.5493	.1334	.1143	.1143	.6805	.631	.5535
23	.5721	.0953	.1143	.1143	.7712	.7682	.6483
24	.6485	.6001	.0953	.1143	.1143	.8238	.8059
Max	1.2226	1.6476	1.7375	1.8204	.7712	1.3717	1.1999
Min	.0762	.0953	.0953	.0953	.0762	.0572	.0762
Avg	.3829	.7432	.5817	.5944	.1550	.4317	.4049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 202 / 11 KV Rajewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.905	.8954	.929	.1143	.1143
2	.1524	.1334	.905	.8842	.929	.1143	.1143
3	.1524	.1334	.8954	.9036	.9259	.1143	.1143
4	.1524	.1334	.9694		.9568	.1143	.1143
5	.1715	.1334	1.0208	1.0208	.9882	.1143	.1334
6	.1715	.1524	.985	1.1919	1.0924	.1334	.1524
7	.1715	.1524	1.1163	1.5893	1.1763	.1905	.2096
8	.1905	.1715	.1715	.1143	.0953	.1524	.1905
9	.788	.1524	.1524	.1334	1.0867	1.182	1.2403
10	1.3112	.1524	.1715	.1334	1.5746	1.7187	1.6651
11	1.6476	.1524	.1334	.1143	1.7511	1.7737	1.8625
12	1.8378	.1715	.1143	.1143	1.9204	1.8073	1.7718
13	1.949	.1715	.1143	.1334	1.8983	1.9366	1.8755
14	2.0332	.1715	.1143	.1524	1.9753	1.8551	1.7337
15	1.9313	.1524	.1143	.1524	1.7878	1.9774	1.7364
16	1.6651	.1524	.0953	.1524	1.3032	1.8839	1.5402
17	.1334	.1715	.1143	.1524	.1143	.0953	.1143
18	.1143	.1715	.1334	.1334	.1334	.1143	.1334
19	.1715	.1905	.1334	.1334	.1524	.0953	.1524
20	.1715	.1905	.1524	.1524	.1334	.1334	.1715
21	.1715	.1905	.1334	.1334	.1334	.1524	.1715
22	.1334	.8238	.8507	.823	.1524	.1334	.1715
23	.1524	.8682	.8669	.929	.1334	.1334	.1143
24	.1524	.1334	.9145	.9114	.9088	.1334	.1143
Max	2.0332	.8682	1.1163	1.5893	1.9753	1.9774	1.8755
Min	.1143	.1334	.0953	.1143	.0953	.0953	.1143
Avg	.6533	.2150	.4699	.4806	.9272	.6739	.6547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 203 / 11 KV Dhole Mala,
Dighanchi Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.4344	.0381	.0572	.0572	.7011	.6268
2	.4525	.3982	.0381	.0572	.0572	.7343	.6268
3	.4572	.4024	.0381	.0572	.0572	.6935	.6068
4	.5304	.4066	.0381	.0572	.0572	.6859	.6201
5	.6838	.5611	.0381	.0572	.0572	1.2795	.631
6	.8779	.6767	.0572	.0762	.0762	1.1283	.6733
7	1.0679	.7392	.0953	.0953	.0953	1.1946	1.0136
8	.0953	.1143	.0953	.0762	.0762	.0953	.1143
9	.1143	.6584	.7577	1.1517	.0762	.0953	.0953
10	.0762	1.0679	1.1157	1.491	.0762	.0953	.1143
11	.0762	1.1706	1.4045	1.5083	.0762	.0953	.1143
12	.0762	1.379	1.4373	1.6118	.1143	.0953	.1143
13	.0572	1.448	1.5223	1.5089	.0953	.0762	.0953
14	.0572	1.4449	1.5402	1.5402	.0953	.0762	.0762
15	.0572	1.448	1.5565	1.4723	.0762	.0762	.0762
16	.0381	1.3969	1.5775	1.4175	.0762	.0953	.0762
17	.0381	.0953	.0953	.0762	.0762	.0953	.0953
18	.0381	.0572	.0762	.0762	.0572	.1143	.1143
19	.0762	.0762	.0953	.0953	.0762	.1524	.1143
20	.0762	.0953	.1143	.1143	.0953	.1715	.1334
21	.0762	.0762	.0953	.0953	.0762	.1143	.1143
22	.3801	.0762	.0953	.0762	.6068	.5434	.4207
23	.3761	.0572	.0762	.0762	.724	.6268	.4515
24	.4961	.4075	.0381	.0572	.0762	.6859	.631
Max	1.0679	1.448	1.5775	1.6118	.724	1.2795	1.0136
Min	.0381	.0572	.0381	.0572	.0572	.0762	.0762
Avg	.2818	.6120	.5015	.5376	.1253	.4051	.3229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.112	.0876	.0914	.0905	.0876
2	.1109	.1109	.1097	.0716	.0886	.0867	.0709
3	.1097	.1097	.1086	.0693	.0709	.0663	.0678
4	.1097	.1109	.1063	.0732	.0686	.064	.0716
5	.1307	.112	.1433	.0709	.0716	.0732	.0693
6	.168	.1478	.197	.0724	.128	.1214	.0914
7	.1848	.1494	.2054	.1867	.168	.1433	
8	.2033	.181	.2126	.1433	.1629	.2218	.2427
9	.1991	.1791	.2126	.1663	.1463	.1578	.1448
10	.156	.1526	.1907	.1214	.104	.0914	.1052
11	.1227	.1526	1.5604	.0972	.0716	.0876	.0678
12	.1214	.1526	.0838	.0876	.0857	.0829	.0686
13	.12	.1341	.9221	.0886	.0739	.0693	.0663
14	.116	.1341	.0886	.0663	.052	.0732	.0838
15	.1147	.1187	.0724	.0671	.0655	.0526	.0829
16	.1017	.1187	.0732	.0693	.0678	.0543	.096
17	.1187	.12	.0857	.0732	.0732	.0724	.104
18	.156	.1357	.0876	.1052	.0895	.112	.1417
19	.1928	.181	.1294	.1294	.1646	.1595	.1629
20	.2195	.2172	.2263	.2263	.2241	.1867	.1646
21	.2241	.2218	.1772	.181	.181		.1646
22	.1867	.2241		.1387	.1612	.1307	.0934
23	.132	.168	.1075	.1086	.1478	.1075	.0724
24	.0943	.1307	.1132	.0905	.1052	.1086	.1052
Max	.2241	.2241	1.5604	.2263	.2241	.2218	.2427
Min	.0943	.1097	.0724	.0663	.052	.0526	.0663
Avg	.1460	.1489	.2315	.1080	.1110	.1049	.1055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 201 / 11 KV Kauthuly

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8951	.2012	.181	.2481	1.6385	2.4646
2	1.7372	1.4419	.1991	.1791	.208	1.7238	2.4272
3	1.7194	1.5939	.2172	.2149	.2195	1.6712	2.4272
4	1.8099	1.5592	.2012	.2534	.1791	1.6956	2.5953
5	2.167	1.7238	.2172	.2172	.2126	1.7436	3.1367
6	2.5514	2.1628	.2743	.2561	.2427	2.2708	3.4355
7	3.5494	1.7695	.362	.3258	.2865	2.9447	3.2526
8	.3121	.2401	.2865	.3258	.2561	.2401	.2865
9	.2254	1.8313	1.9982	1.6476	.2865	.2686	.2804
10	.2507	2.8121	3.1901	3.12	.2481	.3109	.2427
11	.2195	3.4004	3.4196	3.2769	.2195	.2218	.2401
12	.2149	3.5231	3.4019	3.1786	.1791	.1509	.2035
13	.1829	3.4675	3.3478	3.0498	.2195	.2263	.2347
14	.1791	3.4155	3.4019	2.9767	.1791	.2263	.1658
15	.2561	3.3829	3.2956	2.8182	.2195	.2195	.1341
16	.2507	3.488	3.1901	2.3137	.2149	.2195	.1526
17	.2507	.1448	.1629	.2401	.2561	.2195	.1715
18	.2926	.2149	.2561	.2658	.2865	.1463	.2254
19	.2865	.3258	.3658	.2926	.2572	.3018	.298
20	.2481	.3045	.2715	.2507	.2601	.2957	.3012
21	.2774	.2686	.2149	.2507	.2374	.2987	.2865
22	1.1523	.2715	.1791	.2743	1.5424	1.7924	1.7337
23	1.2125	1.0242	.181	.2865	1.6842	2.0911	1.9071
24	1.5432	1.4922		.197	.2561	1.7695	2.5652
Max	3.5494	3.5231	3.4196	3.2769	1.6842	2.9447	3.4355
Min	.1791	.1448	.1629	.1791	.1791	.1463	.1341
Avg	.9082	1.6981	1.2537	1.0997	.3500	.9453	1.2153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 202 / 11 KV Nimbawade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.156	1.2048	1.2269	.9831	.1829	.1417
2	.1294	.1433	1.1218	1.2934	1.0277	.1791	.1463
3	.1307	.1595	1.2094	1.3672	1.0174	.1595	.1448
4	.1494	.1772	1.2445	1.4883	1.0395	.1612	.1629
5	.2033	.1791	1.4883	1.701	1.1142	.1734	.1663
6	.2715	.1595	1.7528	2.0058	.1311	.1753	.1848
7	.3109	.1791	2.0858	2.3211	1.4746	.1595	.2561
8	.2804	.1848	.2149	.2172	.1696	.1791	.2172
9	1.2689	.1646	.1448	.1448	2.1262	1.4582	1.6385
10	2.4249	.1254	.1254	.1646	2.2611		2.2447
11	2.7496	.0895	.1267	.1075	2.3922	3.1367	2.1862
12	2.9504	.1063	.1448	.1254	2.5069	3.1367	2.4577
13	2.7526	.0876	.1463	.1097	2.652	3.1741	2.3922
14	2.7496	.1052	.128	.1097	2.3685	3.0994	2.4291
15	2.8509	.1075	.1448	.1254	2.372	2.838	2.3758
16	3.0182	.1433	.1267	.124	2.5819	2.7633	2.2969
17	.1715	.1448	.1267	.1612	.1715	.1387	.1029
18	.1612	.1612	.1829	.1417	.1646	.104	.104
19	.1772	.2172	.2195	.1612	.1991	.208	.1753
20	.156	.2328	.2172	.1772	.1949	.2172	.2303
21	.1791	.2149	.1949	.1753	.1734	.181	.197
22	.1595	1.1744	1.0341	.9835	.1772	.1463	.1629
23	.1578	1.1145	1.1043	1.0288		.1463	.128
24	.1463	.1387	1.1568	1.2048	1.0486	.1612	.1478
Max	3.0182	1.1744	2.0858	2.3211	2.652	3.1741	2.4577
Min	.1294	.0876	.1254	.1075	.1311	.104	.1029
Avg	.9873	.2361	.6519	.6944	1.2325	.9687	.8621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 203 / 11 KV Kauthuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.1612	.0914	.1097	.0895	.1017	.0732
2	.1478	.0886	.1086	.1294	.0709	.0671	.0732
3	.1294	.1097	.0914	.1097	.0867	.0829	.0905
4	.1267	.1227	.1097	.1097	.1029	.0983	.0905
5	.1254	.1063	.1086	.1478	.12	.1006	.1294
6	.1417	.156	.1629	.1829	.1595	.1147	.1663
7	.0351	.2126	.2561	.2195	.156	.1254	.2743
8	.1907	.2507	.181	.2218	.2481	.2507	.2715
9	.1886	.3224	.1829	.2012	.2279	.208	.1886
10	.1791	.1629	.1629	.1433	.1772		.1526
11	.1097	.1612		.1612	.0895	.1307	.1526
12	.1387	.124	.0905	.1829	.0732	.1307	.1174
13	.0732	.1052	.1097	.2149	.0895	.1307	.1174
14	.0895	.1052	.128	.1063	.0709	.1307	.0663
15	.1075	.1254	.1097	.104	.0709	.1307	.0838
16	.1578	.1254	.1267	.124	.0876	.1307	.0678
17	.2743	.128	.1075	.1612	.156	.156	.1372
18	.2865	.181	.2218	.1753	.1772	.1734	.156
19	.3012	.1829	.2402	.1734	.1886	.2012	.3155
20	.2774	.181	.2195	.1543	.1372	.181	.2835
21	.2572	.1433	.1829	.333	.124	.181	.2328
22	.3403	.1086	.1267	.1612	.1387	.1829	.2353
23	.1772	.1063	.1086	.2427		.1463	.2195
24	.2195	.208	.0886	.1097	.1417	.0693	.0739
Max	.3403	.3224	.2561	.333	.2481	.2507	.3155
Min	.0351	.0886	.0886	.104	.0709	.0671	.0663
Avg	.1782	.1533	.1442	.1658	.1297	.1402	.1570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 204 / Nimbawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.2865	.2172	.1848	.2195	.2149	.1463
2	.1663	.3012	.1829	.2012	.2507	.2126	.1463
3	.1478	.2774	.2195	.1829	.1772	.2427	.1629
4	.1494	.2454	.1829	.2218	.156	.298	.1629
5	.1629	.2303	.181	.2195	.1715	.2303	.1848
6	.2126	.2427	.2172	.2012	.2103	.2454	.2218
7	.2454	.2427	.2195	.2587	.2126	.2865	.3292
8	.2427	.2804	.2378	.2218	.2454	.2481	.3258
9	.2058	.2507	.1829	.2561	.2328	.208	.2743
10	.2507	.2534	.181	.2195	.2427		.2374
11	.2195	.2149	.181	.2507	.2743	.2241	.2204
12		.2126	.2195	.2481	.2149	.1867	.2012
13	.2012	.2103	.181	.208	.2454	.2241	.2155
14	.2149	.1753	.2195	.2507	.208	.2241	.1658
15	.2427	.2149	.181	.2126	.2149	.2241	.1509
16	.2149	.1791	.1829	.2103	.197	.2241	.1357
17	.2561	.2195	.1448	.1949	.2507	.1734	.12
18	.2865	.2534	.1848	.1734	.2254	.1734	.1734
19	.2658	.2561	.2218	.1612	.2614	.2926	.2454
20	.3121		.2926	.2561	.2686	.2896	.3012
21	.2743	.2172	.2195	.2804	.3292	.2896	.3224
22	.3189	.2149	.2172	.2481	.2507	.2561	.2534
23	.3045	.1772	.181	.2774		.1829	.3475
24	.2012	.2835	.1772	.1829	.2865	.2561	.1478
Max	.3189	.3012	.2926	.2804	.3292	.298	.3475
Min	.1478	.1753	.1448	.1612	.156	.1734	.12
Avg	.2287	.2365	.2011	.2218	.2324	.2351	.2163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 201 / 11 KV Vithalapur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 202 / 11 KV Dighanchi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084] BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 203 / 11 KV Rajewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084] BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-FEB-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 205 / 11 KV Dighanchi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 201 / 11 KV Gorewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0693	.8048	.8951	.6299	.0678	.0876
2	.0709	.0693	.8139	.9339	.6299	.0686	.0886
3	.0709	.0693	.8048	.9995	.6299	.0686	.104
4	.0709	.0693	.8383	1.0608	.6226	.0857	.1052
5	.0886	.0857	.9326	1.094	.639	.0876	.1387
6	.1753	.1372	1.1022	1.1603	.8192	.1187	.1753
7	.2454	.2229	1.6956	1.587	1.1633	.2058	.2658
8	.2601	.2058	.2012	.2058	.2035	.2204	.2229
9	.9724	.1372	.1886	.1387	1.0227	1.2039	1.1843
10	1.5581	.1017	.12	.1187	1.0774	1.5424	1.4074
11	1.6712	.0848	.1029	.12	1.491	1.5699	1.543
12	1.7072	.1017	.1029	.1017	1.5083	1.5592	
13	1.6712	.1006	.1029	.1017	1.6057	1.5424	1.2597
14	1.5415	.0838	.1029	.1006	1.5415	1.576	1.3032
15	1.7974	.0838	.12	.1372	1.5249	1.6933	1.4575
16	2.0062	.1017	.1372	.1372	1.6385	1.6956	1.4746
17	.1227	.1372	.12	.1017	.1227	.1372	.1227
18	.1734	.1509	.1387	.1372	.1402	.1402	.1578
19	.1734	.2012	.2427	.208	.1715	.197	.1928
20	.1734	.2035	.2195	.1907	.1886	.1928	.2103
21	.156	.2515	.1867	.1753	.1509	.1772	.1772
22	.12	1.0174	.8648	.9221	.1187	.1227	.1227
23	.0686		.8383	.8951		.0895	.0886
24	.0701	.0686	.8139	.9389	.6299	.0686	.0886
Max	2.0062	1.0174	1.6956	1.587	1.6385	1.6956	1.543
Min	.0686	.0686	.1029	.1006	.1187	.0678	.0876
Avg	.6265	.1632	.4831	.5192	.7943	.6013	.5208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 202 / 11 KV Bhivghat AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.5426	.0678	.0886	.0709	.6783	.8648
2	.57	.5087	.0678	.0895	.0709	.6706	.8573
3	.57	.5087	.0671	.0905	.0709	.763	.8718
4	.5868	.5087	.0678	.1097	.0709	.7545	.8718
5	.6371	.5426	.0848	.1227	.0709	.8048	.9116
6	.7625	.6783	.1187	.124	.0876	.9326	.9779
7	1.1469	.8817	.1357	.1433	.1227	1.291	1.4251
8	.1357	.1341	.1187	.1612	.1387	.1526	.12
9	.1357	.8817	1.0174	1.1869	.12	.1357	.1214
10	.0867	1.0395	1.2209	1.3226	.0686	.1017	.1017
11	.1029	1.1934	1.2887	1.4413	.0857	.1017	.0838
12	.104	1.2125	1.2887	1.3565	.0867	.12	
13	.12	1.1469	1.1869	1.291	.0857	.1029	
14	.12	1.1142	1.2548	1.291	.0701	.1029	
15	.1357	1.2125	1.2887	1.3056	.0881	.0857	
16	.104	1.1271	1.3565	1.3565	.0886	.1029	
17	.1029	.1187	.1029	.1187	.1227	.1029	
18	.12	.1187	.1214	.0857	.1174	.1214	
19	.1372	.1341	.1829	.1402	.116	.1433	
20	.1372	.1187	.1543	.1227	.1187	.1214	
21	.12	.1174	.1387	.1052	.1017	.124	
22	.6274	.1006	.0857	.0876	.8478	.8648	
23	.6783		.0876	.0886		.7712	
24	.5868	.5935	.0678	.0895	.0709	.6783	.8817
Max	1.1469	1.2125	1.3565	1.4413	.8478	1.291	1.4251
Min	.0867	.1006	.0671	.0857	.0686	.0857	.0838
Avg	.3506	.6320	.4822	.5133	.1257	.4095	.6741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 203 / 11 KV Khanapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8478	.0671	.0701	.0886	.5935	.9496
2	.8048	.8139	.0671	.0709	.0886	.5868	.9724
3	.8048	.8139	.0678	.0876	.0886	.5868	1.0059
4	.8215	.8478	.0678	.0867	.0886	.6706	1.0174
5	.8383	.8817	.0671	.0876	.0876	.7545	.9945
6	1.1105	.9835	.0848	.0857	.0876	.8886	.9614
7	1.6385	1.2378	.1187	.1214	.1387	1.4754	1.5893
8	.2204	.1715	.1187	.1417	.1734	.1696	.1372
9	.1526	.9835	1.0227	1.3735	.1543	.1341	.1387
10	.0886	1.1736	1.4582	1.6956	.1402	.1357	.1187
11	.104	1.5249	1.7635	1.8991	.1029	.1187	.0848
12	.0857	1.5729	1.7635	1.8778	.1214	.1372	.0848
13	.0693	1.5238	1.933	1.8821	.1029	.1372	.0848
14	.0686	1.6221	1.9669	1.95	.104	.1372	.0848
15	.0701	1.6221	1.8652	1.8778	.1772	.12	.0838
16	.0686	1.6712	1.8991	1.9281	.1227	.1029	.1017
17	.0867	.1526	.0857	.1357	.124	.12	.1174
18	.12	.1187	.1387	.104	.12	.0716	.1029
19	.1029	.1187	.1448	.1227	.12	.1254	.1052
20	.12	.1006	.12	.1227	.1341	.1402	.1227
21	.1029	.0848	.124	.1402	.1006	.1254	.1227
22	.763	.0671	.0701	.1063	.8886	.9088	.7377
23	.8478		.0857	.1063		.9877	.7545
24	.8551	.8478	.0671	.0867	.0886	.6104	.9496
Max	1.6385	1.6712	1.9669	1.95	.8886	1.4754	1.5893
Min	.0686	.0671	.0671	.0701	.0876	.0716	.0838
Avg	.4493	.8601	.6320	.6733	.1497	.4099	.4759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 204 / 11 KV Khanapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1543	.1526	.1949	.1772	.1526	
2	.1595	.156	.1509	.1949	.1595	.1509	.2103
3	.1595	.156	.1526	.2103	.1595	.1696	.2401
4	.1595	.1734	.1677	.2254	.1772	.2012	.2601
5	.1772	.1715	.2035	.2572	.1949	.2374	.2058
6	.2804	.2743	.2883	.2915	.2804	.2713	.3086
7	.4557	.4287	.4748	.4161	.4908	.39	.4115
8		.4115	.39	.3944	.4508	.4239	.4334
9	.3772	.3086	.3052	.3155	.3086	.2683	.3429
10	.2774	.2543	.2543	.2713	.2601	.2713	.2543
11	.2401	.2713	.2743	.2713	.2229	.2713	.2713
12	.2401	.2883	.2743	.2543	.2774	.2229	.2543
13	.2427	.2683	.2401	.2374	.2572	.2401	
14	.2401	.2347	.2229	.2374	.2427	.2058	
15	.2058	.285	.2572	.2543	.2601	.2229	
16	.2572	.2683	.2572	.2374	.2915	.2401	
17	.2427	.2401	.2601	.2713	.2629	.2572	
18	.3121	.3052	.3429	.2915	.3561	.2774	
19	.4334	.4239	.4525	.3988	.4239	.3982	
20	.4161	.373	.3944	.3814	.373	.3814	
21	.3641	.3561	.3467	.3506	.3391	.3258	
22	.2743	.2683	.2743	.2629	.2543	.2774	
23	.1886		.2058	.2103			
24	.1595	.1543	.1526	.2281	.1772	.1526	.1907
Max	.4557	.4287	.4748	.4161	.4908	.4239	.4334
Min	.1595	.1543	.1509	.1949	.1595	.1509	.1907
Avg	.2619	.2707	.2706	.2774	.2781	.2613	.2819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 205 / 11 KV Bhivghat Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0857	.0857	.0716	.0709	.0876	.1063
2	.0709	.0867	.0857	.0724	.0709	.0876	.0876
3	.0709	.0867	.0857	.0716	.0709	.0876	.0872
4	.0886	.0867	.0848	.0914	.0709	.1029	.0857
5	.0886	.0857	.1017	.1267	.0701	.1029	.1227
6	.1227	.1372	.1341	.1433	.1402	.1174	.1543
7	.1928	.1715	.1174	.1791	.1227	.1715	.1578
8	.2058	.2058	.1696	.2126	.1372	.2374	.2572
9	.1029	.156	.1715	.1543	.1886	.1509	.1753
10	.1753	.1543	.1372	.1372	.1214	.1696	.1174
11	.1886	.1526	.1543	.1341	.1417	.1696	.1341
12	.1717	.1357	.1372	.1174	.1402	.1543	
13	.1387	.1341	.1029	.1017	.1372	.1543	.1174
14	.0686	.0838	.1029	.1017	.0867	.0857	.1052
15	.1029	.1006	.1029	.1029	.1052	.12	.0857
16	.1387	.1017	.12	.1029	.0857	.1372	.0857
17	.1227	.1029	.1387	.1006	.104	.1372	.1029
18	.1543	.1341	.1227	.1387	.1372	.1214	.1402
19	.2058	.1865	.2172	.1734	.1715	.2054	.2126
20	.2058	.1844	.2172	.1928	.1886	.2353	.2126
21	.1886	.1677	.1991	.1928	.8383	.2012	.1772
22	.1372	.1526	.1433	.1227	.1357	.124	.1417
23	.1029		.0886	.0886		.0895	.0886
24	.0886	.0857	.0838	.0886	.0709	.0857	.1052
Max	.2058	.2058	.2172	.2126	.8383	.2374	.2572
Min	.0686	.0838	.0838	.0716	.0701	.0857	.0857
Avg	.1343	.1295	.1293	.1258	.1481	.1390	.1331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 206 / 11 KV Balawadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1715	1.2717	1.5939	1.3094	.1017	.2126
2	.1772	.1543	1.2574	1.576	1.3094	.1006	.2149
3	.1772	.1543	1.2574	1.6575	1.3094	.1029	.2172
4	.1772	.1715	1.3565	1.7295	1.3108	.12	.2328
5	.1949	.1886	1.4251	1.8275	1.3435	.1543	.2279
6	.2279	.2229	1.6766	1.8351	1.491	.218	.2865
7	.3155	.3086	2.2801	2.5263	1.8187	.2743	.3189
8	.3467	.2915	.3086	.2713	.2374	.3086	.298
9	1.358	.2229	.2229	.2303	1.3916	1.5927	1.6289
10	2.0481	.1357	.2229	.1696	1.7101	2.0517	1.8313
11	2.3205	.1187		.1372	2.0056	2.2043	1.9839
12	1.9227	.1174	.1715	.1006	2.146	2.079	2.0119
13	1.9227	.1341	.1715	.0857	2.2708	2.1795	1.3904
14	2.2611		.1543	.0857	2.1293	2.1795	1.7604
15	2.304		.1372	.1029	1.95	2.2466	1.9448
16	2.4086	.1187	.1715	.1006	2.0454	2.2043	1.9161
17	.1326	.1387	.1734	.1865	.1063	.1017	.1865
18	.2229	.2058	.2303	.2254	.1715	.1886	.2629
19	.2915	.3018	.3361	.3121	.2572	.3258	.2804
20	.2743	.3018	.3292	.2804	.285	.3189	.2804
21	.2572	.2883	.3045	.2804	.2713	.2804	.2804
22	.2229	1.3375	1.4752	1.4419	.2058	.2401	.2303
23	.1715		1.4754	1.4089		.2058	.2126
24	.1772	.1715	1.2574	1.6263	1.326	.1029	.2103
Max	2.4086	1.3375	2.2801	2.5263	2.2708	2.2466	2.0119
Min	.1326	.1174	.1372	.0857	.1063	.1006	.1865
Avg	.8371	.2503	.7681	.8247	1.2348	.8284	.7675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 207 / 11 KV GOREWADI gaovthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0168	.0179		.017	.0526
2		.0173	.017	.0177		.0168	.0532
3		.0173	.0168	.0366		.017	.0351
4		.0173	.0335	.0362		.0339	.0347
5	.0354	.0343	.0339	.0537	.0177	.0335	.0514
6	.0701	.0514	.0671	.0543	.0526	.0509	.0686
7	.0876	.1029	.0848	.1254	.0876	.0678	.0701
8	.1029	.1029	.1017	.0876	.0857	.1187	.1063
9	.12	.12	.0848	.0686	.0514	.0848	.0881
10	.0867	.0686	.0857	.0678	.0686	.0848	.0678
11	.0514	.0339	.0857	.0678	.052	.0678	.0339
12	.052	.0339	.0514	.0678	.0514	.0686	.0339
13	.0343	.0509	.0686	.0339	.052	.0514	.0339
14	.0343	.0339	.0686	.0335	.0343	.0686	.0339
15	.0509	.0339	.0686	.0509	.0514	.0514	.0339
16	.0343	.0509	.0686	.0509	.0351	.0343	.0339
17	.052	.052	.052	.0509	.0514	.0514	.0339
18	.0857	.0678	.0686	.0686	.0857	.0867	.0693
19	.1372	.1006	.1063	.0686	.1017	.1267	.1052
20	.1372	.1017	.1052	.0876	.1017	.0876	.1052
21	.12	.0838	.0709	.0876	.0848	.0876	.0876
22	.0686	.0678	.0526	.0526	.0678	.0693	.0526
23	.0514		.0181	.0175		.0532	.0354
24		.0343	.0339	.0181		.0168	.0532
Max	.1372	.12	.1063	.1254	.1017	.1267	.1063
Min	.0343	.0171	.0168	.0175	.0177	.0168	.0339
Avg	.0743	.0563	.0609	.0551	.0629	.0603	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 201 / PALASHI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.9231	1.0395	.8223	.1463	.1372
2	.1715	.1524	.8642	.9945	.7748	.1463	.1341
3	.1715	.1524	.8322	.9831	.7522	.1478	.1357
4	.1715	.1715	.8745	1.0277	.759	.1478	.1509
5	.2096	.2096	.9667	1.0898	.8223	.1646	.1844
6	.381	.3174	1.4083	1.3056	1.0279	.3258	.2652
7	.4435	.4207	1.9376	2.1384	1.3123	.4024	.4409
8	.3898	.3511	.3403	.3258	.3547	.3881	.4031
9	.8322	.3045	.2835	.2629	.8436	1.2944	1.2548
10	.8065	.2743	.2534	.2686	1.3757	1.5844	1.6244
11	1.2631	.2858	.1595	.2103	1.4883	1.5364	1.5083
12	1.5546	.2012	.2103	.2058	1.5203	1.4419	1.5424
13	1.5684	.2012	.2328	.2126	1.3603	1.4586	1.442
14	1.4373	.181	.2172	.2149	1.2492	1.4083	1.3272
15	1.4243	.1646	.1928	.2126	1.3763	1.3565	1.3927
16	1.5339	.1991	.2103	.2149	1.5524	.9774	1.0722
17	.2279	.2561	.2572	.2172	.2561	.2279	.2454
18	.2883	.2561	.2374	.2743	.2801	.2686	.2572
19	.362	.3547	.3086	.3547	.3361	.3439	.3222
20	.362	.3734	.3439	.3547	.3174	.3658	.2804
21	.3048	.3326	.2865	.2801	.2801	.2715	.2658
22	.2477	1.1401	1.0513	.8065	.2218	.2103	.1886
23	.1905	1.1934	1.1736	.9105	.1646	.1372	.1696
24	.1715	.1524	.9393	1.0442	.9374	.1478	.1357
Max	1.5684	1.1934	1.9376	2.1384	1.5524	1.5844	1.6244
Min	.1715	.1524	.1595	.2058	.1646	.1372	.1341
Avg	.6119	.3249	.6044	.6229	.8411	.6208	.6200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 202 / 11 KV HIVARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5668	.5571	.1402	.1341	.1463	.6958	.6203
2	.5668	.5571	.1402	.1341	.1463	.6241	.5868
3	.5735	.5571	.1402	.1326	.1448	.6241	.5935
4	.5668	.5506	.1578	.1475	.1463	.6325	.6203
5	.6133	.5535	.197	.1658	.1663	.68	.663
6	.852	.7865	.3109	.2515	.2195	.8539	.7956
7	1.6907	1.3435	.4108	.3582	.3658	1.7124	1.7878
8	.4207	.3814	.3475	.3155	.4108	.3696	.4115
9	.3222	1.0526	1.1145		.3881	.2715	.3258
10	.2035	1.4752	1.5432	1.7002	.2561	.2328	.2543
11	.1907	1.668	.8785	1.9105	.2218	.2126	.2012
12	.1886	1.6518	1.5432	1.6278	.2378	.2103	.2279
13	.1989	1.6385	1.6118	1.5223	.2378	.2507	.2035
14	.2204	1.6221	1.7878	1.5844	.2402	.2507	.2012
15	.1928	1.4918	1.8861	1.7078	.2195	.2534	.2155
16	.2486	1.587	1.9547	1.8244	.2172	.2279	.1677
17	.2572	.2328	.2035	.2686	.2195	.3224	.2035
18	.2804	.2896	.2229	.2772	.2987	.3258	.2629
19	.4024	.4251	.3681	.3547	.4108	.394	.3601
20	.381	.3658	.3403	.3361	.3734	.3801	.3582
21	.362	.3077	.2957	.2987	.2987	.3224	.298
22	.5601	.2328	.2454	.2218	.7362	.7716	.5935
23	.6062	.1772	.1696	.1646	.7432	.6539	.5967
24	.583	.5668	.1578	.1326	.1448	.703	.6299
Max	1.6907	1.668	1.9547	1.9105	.7432	1.7124	1.7878
Min	.1886	.1772	.1402	.1326	.1448	.2103	.1677
Avg	.4604	.8363	.6737	.677	.2912	.4990	.4658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 203 / 11 KV HIVARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.0358	.0351	.0358	.0358	.0351	.0343
2	.0351	.0351	.0351	.0362	.0358	.0354	.0343
3	.0351	.0358	.0351	.0358	.0354	.0354	.0351
4	.0354	.0351	.0351	.0362		.0351	.0351
5	.0362	.0351	.0354	.0358	.0351	.0347	.0351
6	.0693	.0514	.0543	.0537	.0532	.0526	.0514
7	.0857	.0829	.0934	.0549	.0716	.0716	.0724
8	.0995	.104	.1294	.0716	.0724	.0886	.0716
9	.0514	.104	.0716	.0701	.0537	.0716	.0351
10	.0526	.0829	.0886	.0716	.0543	.1063	.0716
11	.0526	.0514	.0358	.0724	.0895	.0526	.0526
12	.052	.0905	.0526	.0351	.0362	.0716	.0895
13	.0335	.0724	.0362	.0354	.0358	.0362	.0343
14	.0343	.0537	.0366	.0358	.0354	.0543	.0509
15	.0663	.0724	.0543	.0351	.0351	.0549	.0503
16	.0671	.0537	.0358	.0532	.0709		
17	.0514	.0537	.0701	.0354	.1063	.0543	
18	.0514	.0724	.0537	.1086	.0537	.0537	
19	.0701	.0934	.0724	.0895	.0895	.0905	
20	.0701	.0934	.0732	.0905	.0724	.0762	
21	.0693	.0739	.056	.0716	.0716	.0747	
22	.0509	.0543	.0362	.0537	.0537	.0543	
23	.0351	.0358	.0358	.0358	.0354	.0358	
24	.0354	.0358	.0351	.0351	.0354	.0347	.0351
Max	.0995	.104	.1294	.1086	.1063	.1063	.0895
Min	.0335	.0351	.0351	.0351	.0351	.0347	.0343
Avg	.0531	.0629	.0540	.0537	.0551	.0570	.0493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 201 / 11 KV RENA VI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6009	.571	.0633	.0678	.0701	.7274	.7116
2	.7116	.571	.0633	.0686	.0701	.7274	.7116
3	.8539	.571	.0633	.0678	1.6126	.7907	.7116
4	.8539	.571	.0633	.0678	.0701	.9172	.759
5	1.0279	.5639	.0633	.0867	.0709	.9804	.8855
6	1.0753	.5944	.0633	.0848	.0895	.9804	.9804
7	1.1069	.7716	.0633	.1036	.0924	1.012	1.012
8	.0949	.1075	.0791	.1017	.1063	.0949	.1107
9	.0633	.6173	.7432	.9804	.1075	.0949	.0633
10	.0732	.828	1.0279	1.1683	.1086	.0791	.0678
11	.0701	1.0623	1.0155	1.2163	.0949	.0633	
12	.0848	1.0911	1.1385	1.2643	.0633	.0633	.0678
13	.0876	1.1227	1.2342	.9842	.0633	.0633	.0514
14	.0867	1.1385		1.1544	.0633	.0633	.0509
15	.0709	1.0753	1.1702	1.1405	.0633	.0633	.0514
16	.0876	1.1385	1.2811	1.0467	.0633	.0633	.0678
17	.0876	.0791	.0678		.0633	.0633	.0686
18	.0686	.0791	.0857	.08	.0633	.0791	.104
19	.0895	.0791	.1017	.0895	.0633	.0791	.0876
20	.0886	.0791	.0857	.104	.0633	.0791	.104
21	.0876	.0791	.0848	.0867	.0633	.0791	.1029
22	.571	.0633	.0857	.0886	.7116	.6642	.6009
23	.6173	.0633	.0848	.0701	.7274	.7116	.578
24	.5851	.5864	.0633	.0686	.0701	.7274	.7116
Max	1.1069	1.1385	1.2811	1.2643	1.6126	1.012	1.012
Min	.0633	.0633	.0633	.0678	.0633	.0633	.0509
Avg	.3810	.5627	.3823	.4431	.1931	.3861	.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 202 / 11 KV RENA VI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.056	.0549	.0724	.056	.0732	.0732
2	.0732	.056	.0549	.0716	.056	.0732	.0732
3	.0732	.056	.0549	.0716	.056	.0914	.0732
4	.1097	.056	.0549	.0709	.0739	.1097	.0914
5	.128	.0732	.0732	.0724	.0914	.128	.1097
6	.1463	.1294	.1097	.0895	.128	.1463	.128
7	.1463	.1663	.1463	.1629	.1646	.1829	.1463
8	.2012	.1448	.1646	.1829	.1791	.1829	.1463
9	.128	.124	.1097	.1086	.1417	.1463	.1097
10	.1063	.0895	.128	.124	.1063	.1097	.0724
11	.104	.0732	.1075	.1052	.0914	.0732	
12	.0732	.0732	.0724	.0895		.0732	.0543
13	.0554	.0549	.0716	.0554	.0732	.0732	.0716
14	.0549	.0732	.0543	.0554	.0732	.0732	.0724
15	.056	.0732	.0732	.0532	.0732	.0732	
16	.0549	.0732	.0905	.0701	.0732	.0914	.0895
17	.0716	.0914	.1254	.0709	.0732	.0914	.0905
18	.1052	.0914	.1097	.124	.0914	.1463	.1254
19	.128	.1463	.1448	.1463	.1463	.1463	.1629
20	.1478	.1463	.1254	.1307	.1463	.1463	.1254
21	.112	.128	.1086	.1307	.128	.1463	.1086
22	.0754	.0914	.0895	.0943	.1097	.1097	.0716
23	.0566	.0732	.0724	.0747	.0732	.0732	.0543
24	.0732	.0566	.0549	.0732	.0566	.0732	.0732
Max	.2012	.1663	.1646	.1829	.1791	.1829	.1629
Min	.0549	.0549	.0543	.0532	.056	.0732	.0543
Avg	.0981	.0915	.0938	.0959	.0983	.1097	.0965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 201 / 11 KV BURLI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0503	.6241	.5418	.535	.0701	.0514
2	.0701	.0514	.6241	.5281	.5418	.0806	.0503
3	.0671	.0514	.6241	.535	.5281	.0716	.0492
4	.0772	.0514	.6241	.5418	.5281	.0762	.0526
5	.0793	.0709	.6401	.6401	.5647	.072	.0583
6	.093	.0777	.7499	.6481	.6481	.0734	.0709
7	.0947	.0846	.9831	.7499	.7773	.0926	.084
8	.1046	.0995	.096	.1372	.101	.1075	.096
9	1.1385	.088	.076	.084	1.278	1.5729	1.5546
10	1.5729	.0674	.0514	.0772	1.5729	1.7695	1.7695
11	1.6712	.064	.0503	.0754	1.7901	1.9204	1.8679
12	1.6324	.0754	.0737	.0772	1.749	1.9433	1.8027
13	1.6129	.0737	.0671	.0876	1.6518	2.0405	1.7284
14	1.6324	.06	.0655	.0671	1.6518	1.9204	1.6518
15	1.5364	.0737	.064	.0772	1.6518	1.9662	1.6324
16	1.4575	.0709	.0737	.0573	1.749	1.7284	1.5181
17	.0573	.0663	.0701	.048	.0653	.072	.06
18	.0671	.0606	.0983	.0671	.0838	.068	.0716
19	.0857	.0787	.0977	.101	.0926	.1012	.1086
20	.0737	.076	.0874	.1069	.0953	.096	.0909
21	.1029	.084	.0754	.0895	.0922	.0857	.0985
22	.0762	.7407	.6401	.6401	.0737	.0747	.0671
23	.0492	.7316	.6321	.6401	.0671	.0734	.0613
24	1.7919	.0492	.6241	.535	.535	.0686	.0537
Max	1.7919	.7407	.9831	.7499	1.7901	2.0405	1.8679
Min	.0492	.0492	.0503	.048	.0653	.068	.0492
Avg	.6339	.1249	.3255	.2980	.7676	.6727	.6104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 202 / 11 KV RAMANANDNAGAR 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2263	.2263	.2263	.2263	.1886	.1886
2	.1886	.2263	.2263	.1886	.1886	.1886	.1886
3	.1886	.1886	.1886	.1886	.1886	.1886	.1886
4	.1886	.2263	.1886	.1886	.1886	.1886	.1886
5	.2263	.2641	.2641	.2614	.2263	.2263	.2263
6	.3018	.3018	.415	.3018	.3772	.3395	.3395
7	.5281	.4527	.5281	.3772	.4527	.4854	.4481
8	.4527	.4904	.5281	.4481	.4904	.4481	.5544
9	.679	.5914	.5487	.5792	.543	.4656	.6283
10	.6379	.5373	.543	.5258	.567	.4207	.5959
11	.5426	.5068	.5316	.4961	.5731	1.9433	.4854
12	.4207	.3734	.4252	.4706	.439	.2743	.4706
13	.4115	.3734	.394	.3814	.362	.3429	.394
14	.4748	.4298	.4908	.3898	.4298	.2683	.503
15	.3978	.4298	.4908	.4908	.5014	.2804	.5087
16	.4801	.4435	.4854	.4607	.4961	.3315	.4908
17	.5068	.439	.4557	.4557	.5068	.2774	.4656
18	.4557	.4805	.5487	.5373	.4961	.3224	.567
19	.543	.5914	.5731	.5544	.4755	.4344	.5487
20	.5544	.5658	.5121	.5228	.4435	.4344	.5281
21	.4527	.4527	.4108	.4854	.4108	.3696	.415
22	.415	.4527	.3772	.3772	.3734	.2987	.3772
23	.3018	.3395	.2641	.3018	.3018	.2614	.2641
24	.2263	.2263		.2263	.2641	.2263	.2263
Max	.679	.5914	.5731	.5792	.5731	1.9433	.6283
Min	.1886	.1886	.1886	.1886	.1886	.1886	.1886
Avg	.4068	.4004	.4181	.3932	.3968	.3836	.4080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 203 / 11 KV SAWANTPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0427	.0472	.8642	.8642	.8749	.0442	.048
2	.0404	.0465	.8642	.8749	.8855	.0434	.0465
3	.0389	.0472	.8749	.8855	.8855	.0434	.0472
4	.0524	.0511	.8749	.8749	.8855	.0442	.0488
5	.0581	.0526	.8749	.8642	.9602	.0511	.0495
6	.0762	.0714	1.0242	1.012	1.0364	.0724	.0714
7	.0926	.0734	1.2651	1.1523	1.1523	.0695	.108
8	.0834	.0857	.0541	.0762	.0974	.0714	.0892
9	1.8564	.0648	.0629	.0686	1.2955	1.8138	1.8351
10	2.1216	.0648	.0657	.1027	1.9662	2.2024	2.0972
11	2.3868	.0667	.0533	.0734	2.2283	2.332	1.9662
12	2.2283	.0667	.0714	.0549	2.3594	2.332	2.0972
13	2.2283	.08	.0549	.0743	2.2283	2.0729	1.9204
14	2.0729	.0695	.0549	.0823	2.2283	1.6518	1.9433
15	2.0972		.0526	.0526	2.2283	2.0972	1.9662
16	1.9433	.0638	.0472	.0518	2.1216	2.0729	1.9662
17	.0629	.0657	.0465	.0511	.0834	.0766	.0381
18	.0594	.092	.0543	.0743	.0766	.0754	.0743
19	.0974	.1027	.0743	.0974	.0556	.0834	.0667
20		.1097	.0734	.08	.0564	.08	.08
21	.061	.0667	.0714	.08	.0686	.0695	.08
22	.061	1.012	.8749	.8749	.0657	.0667	.0686
23	.048	1.012	.8535	.9374	.0495	.0667	.0629
24	.0543	.0472	.8642	.8855	.9488	.0457	.0503
Max	2.3868	1.012	1.2651	1.1523	2.3594	2.332	2.0972
Min	.0389	.0465	.0465	.0511	.0495	.0434	.0381
Avg	.7767	.1504	.4197	.4269	1.0349	.7324	.7009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 204 / 11 KV RAMANANDNAGAR 2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.3018	.2641	.2263	.2641	.2263
2	.2263	.2263	.2641	.2641	.2263	.2263	.2263
3	.2263	.2263	.2263	.2263	.2263	.2263	.2263
4	.2263	.2263	.2263	.2263	.2263	.2263	.2263
5	.2641	.3018	.3395	.3395	.2641	.3018	.3018
6	.5281	.5658	.5658	.4527	.5228	.5281	.5281
7	.7545	.7167	.7545	.679	.7167	.7545	.7167
8	.679	.5658	.6722	.679	.679	.7095	.679
9	.6283	.6348	.6722	.5914	.679	.5601	.6722
10	.5853	.6154	.6219	.5487	.5914	.5228	.5544
11	.5731	.5068	.5792	.567	.5175	.4252	.4706
12	.4481	.4108	.4805	.3982	.4481	.362	.4481
13	.4961	.439	.4805	.3658	.3734	.3658	.415
14	.5014	.439	.5792	.4435	.439	.4298	.4435
15	.4435	.4024	.567	.4066	.439	.3696	.439
16	.5175	.4481	.5258	.4108	.5068	.3658	.439
17	.4435	.415	.439	.415	.4481	.3658	.415
18	.439	.4854	.5068	.4854	.5121	.439	.5281
19	.7095	.679	.6653	.7468	.7468	.6722	.679
20	.695	.6413	.6348	.679	.679	.6722	.679
21	.6036	.6036	.6036	.6036	.5658	.6036	.6036
22	.4904	.4527	.4527	.4527	.4904	.4904	.5281
23	.3772	.3395	.3772	.415	.3772	.415	.3772
24	.3018	.3018	.3395	.3018	.3018	.3018	.2641
Max	.7545	.7167	.7545	.7468	.7468	.7545	.7167
Min	.2263	.2263	.2263	.2263	.2263	.2263	.2263
Avg	.4759	.4545	.4948	.4568	.4668	.4416	.4619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 401 / 33 KV KBL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 201 / 11 KV DUDHONDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0625	.2187	.2056	.2372	.0633	.0633	.0474
2	.0625	.25	.2056	.2214	.0633	.0633	.0474
3	.0625	.2187	.2214	.2214	.0633	.0633	.0474
4	.0937	.2812	.2214	.2214	.0633	.0791	.0633
5	.0937	.3125	.253	.253	.0949	.0949	.0791
6	.0937	.3437	.2846	.3321	.0949	.0949	.0791
7	.0937	.4374	.427	.4428	.1063	.0949	.1265
8	.0937	.0937	.0949	.1265	.0949	.0949	.1107
9	.3749	.0949	.0949	.0949	.5376	.8223	.6642
10	.6874		.0791	.0949	.4902	.8855	.8223
11	.7186	.0937	.0633	.0633	.9804	.9172	.8855
12	.7186	.0937	.0791	.0633	.933	.9488	.8855
13	.703	.0781		.0633	1.012	.8855	.9172
14	.6874	.0625		.0633	1.0279	.8855	.8539
15	.6249		.0791	.0633	1.012	.8539	.8223
16	.4062	.0625	.0633	.0633	.8223		.7274
17	.0625		.0791	.0949	.0791		.0633
18	.0625	.0791	.0781	.0949	.0949	.0949	.0633
19			.0781	.0949	.0949	.0949	.0633
20		.0633	.0781	.0633	.0949	.0791	.0474
21	.0781	.0633	.0791	.0633	.0633	.0791	.0474
22	.2187	.1898	.2214	.0633	.0633	.0633	.0474
23		.1898	.2372	.0633	.0633	.0474	.0474
24	.0625	.25	.2056	.2372	.0633	.0633	.0633
Max	.7186	.4374	.427	.4428	1.0279	.9488	.9172
Min	.0625	.0625	.0633	.0633	.0633	.0474	.0474
Avg	.2886	.1738	.1559	.1417	.3365	.3350	.3176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 202 / 11 KV NAGRALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887		.0457	.0633	.7449	.6802	.5506
2	.3725		.0457	.0633	.7125	.7125	.5506
3	.3725		.0457	.0633	.7125	.6802	.5506
4	.421		.061	.0633	.7449	.7125	.583
5	.4534		.061	.0791	.7773	.7449	.6154
6	.4534		.0914	.0949	.8097	.7773	.6802
7	.4534		.0914	.1265	.9069	.9393	.8097
8	.6478		.0914	.0949	.0972	.0972	.0972
9	.0972		.8383	1.3279	.0972	.0972	.0972
10	.081		1.0974	1.587	.081		.0648
11	.0648		1.3599	1.5546	.0972	.0648	.0648
12	.081		1.4232	1.4575	.081	.081	.0648
13	.0648		1.4232	1.3927	.0648	.0648	.0648
14	.081		1.3599	1.3603	.0791	.081	.0648
15	.0648		1.2967	1.4251	.0648	.081	.0648
16	.0648		.4744	1.3279	.0648		.0648
17	.081		.0633	.0648	.0648		.0648
18	.081		.0648	.0648	.0972	.0648	.081
19				.0972	.0648	.0648	.0648
20		.081		.0633	.0648	.081	.081
21		.2429	.0972	.0633	.0648	.0972	.0648
22		.061	.0949	.7773	.5506	.5668	.4858
23		.0762	.0633	.7773	.6478	.5506	.5182
24	.3887		.061	.0633	.7449	.6802	.5668
Max	.6478	.2429	1.4232	1.587	.9069	.9393	.8097
Min	.0648	.061	.0457	.0633	.0648	.0648	.0648
Avg	.2480	.1153	.4659	.5855	.3515	.3771	.2881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 203 / 11 KV TAKARI EXPS

NON SHEDDABLE WATER SUPPLY AND
UTILITY

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.6154	.5375	.3681	.4207	.6154	.5548
2	.583	.5731	.5258	.3641	.4458	.5373	.5609
3	.5609	.5959	.5083	.3506	.4298	.5609	.5959
4	.583	.5487	.5316	.3544	.4557	.5144	.5548
5	.5487	.5959	.5434	.3681	.5373	.5258	.5201
6	.5426	.5487	.5609	.3681	.583	.5609	.5144
7	.583	.5895	.5548	.3721		.5487	.5087
8	.583	.5765	.5784	.3761	.5426	.5144	.5609
9	.7362	.583	.4435	.4706	.5959	.5609	.6447
10	.724	.583	.4755	.5068	.6089	.4706	.6024
11	.6516	.631	.4755	1.5546	.6379	.4801	.7522
12	.6089	.5258	.4435	.4557	.5609	.5256	.5959
13	.6089	.567	.4805	.4161	.6805	.4687	.6516
14	.6379	.6447	.5487	.3772	.567	.6733	.583
15	.631		.5068	.4557	.5731	.5959	.5487
16	.6516	.6379	.543	.394	.6447		.5959
17	.6173	.5258	.4607	.3982	.6089		.2587
18	.583	.691	.0648	.4207	.6379	.439	.6104
19		.7442	.4908	.4908	.7087	.5609	.6588
20		.7362	.3841	.5373	.7202	.5959	.5895
21	.5487	.6036	.3641	.583	.583	.5548	.6173
22	.6733	.631	.3506	.583	.5487	.5609	.5658
23		.7186	.4656	.5144	.6935	.5144	.583
24	.6859	.6379	.5548	.3506	.4508	.631	.5548
Max	.7362	.7442	.5784	1.5546	.7202	.6733	.7522
Min	.5426	.5258	.0648	.3506	.4207	.439	.2587
Avg	.6178	.6132	.4747	.4763	.5755	.5459	.5743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 204 / 11 KV NAGRALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.4066	.3881	.3696	.3696		.3696
2	.3696	.3696	.3881	.3696	.3696		.3696
3	.4066	.3696	.4066	.3881	.4066		.3696
4	.5544	.5544	.4251	.3881	.5914		.5914
5	.7762	.7762	.5914	.6283	.7762		.7762
6	.924	.924	.8501	.7947	.924		.924
7	1.1088	1.1088	1.1088	1.0534	1.1088	1.1088	1.1088
8	.961	.9979	1.0349	1.0719	.924	.961	1.0349
9	.7392	.7762	.7762	.7762	.7842	.7392	.8686
10	.5914	.6099	.5544	.5914	.5914	.5544	.5914
11	.5544	.5729	.5544	.5914	.5544	.5544	.5544
12	.5175	.5544	.5544	.5544	.4805	.5359	.5175
13	.4805	.499	.5175	.5544	.4805	.5359	.5544
14	.5175	.462	.4805	.5175	.4066	.4066	.4066
15	1.3569		.4805	.4066	.4066	.4066	.5544
16	.5175	.4066	.5175	.5544	.4435		.5544
17	.5544	.3696	.5175	.6283	.499		.5544
18	.5914	.5544	.5544	.7023	.6653	.7392	.7207
19	.5914	.5544	.8871	.961	.924	.9425	.924
20		.8686	.8686	.924	.924	.9425	.9055
21	.924	.8871	.8131	.8871	.8871	.8871	.8686
22	.7392	.7392	.7392	.7392	.7392	.7023	.7023
23		.5359	.5544	.5544	.5544	.5175	.5175
24	.4066	.4435	.3696	.3696	.3696	.3696	.3696
Max	1.3569	1.1088	1.1088	1.0719	1.1088	1.1088	1.1088
Min	.3696	.3696	.3696	.3696	.3696	.3696	.3696
Avg	.6615	.6235	.6222	.6407	.6325	.6815	.6545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 205 / SATTESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.3174	.2987	.3174	.3142	.0377
2	.2801	.3326	.3361	.3361	.3361	.0377
3	.2957	.3734	.3395	.3361	.3734	.0377
4	.2801	.4108	.3361	.3174	.4108	.0377
5	.2987	.4294	.3395	.3361	.4294	.0377
6	.2987	.4108	.3395	.3361	.4294	.0377
7	.4108	.4294	.5847	.5281	.5975	.2614
8	.4108	.3921	.5847	.5788	.5601	.2614
9	.4108	.4108	.6036	.5975	.5975	.2614
10	.4338	.3961	.6036	.5975	.6036	.5975
11	.4338	.3961	.6224	.5975	.1132	.5975
12	.415	.3961	.6036	.5975	.2801	.5975
13	.1132	.3961	.6036	.5975	.2829	.5975
14	.0943	.415	.6036	.5975	.2801	.5975
15	.0943		.5847	.5975	.2801	.5601
16	.1132			.6348	.0373	.2587
17		.3018	.0377			
Max	.4338	.4294	.6224	.6348	.6036	.5975
Min	.0943	.3018	.0377	.3174	.0373	.0377
Avg	.2903	.3872	.4639	.4940	.3704	.3010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 201 / 11 KV PALUS CITY FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.679	.6602	.6413	.6413	.7167	.7545
2	.6413	.679	.6413	.6602	.6224	.6979	.7167
3	.6602	.6602	.6413	.679	.6224	.679	.7167
4	.8676	.7356	.6602	.7922	.6036	.7167	.8299
5	1.094	.9431	.7922	.9054	.7356	.9054	.9054
6	1.3392	1.1694	1.3392	.9808	1.1694	1.2071	1.2826
7	1.6032	1.4901	1.6409		1.4712	1.5089	1.3443
8	1.5089	1.6409	1.5524	1.4969	1.5497	1.5339	1.6244
9	1.4083	1.46	1.448	1.363	1.3306	1.3491	1.386
10	1.2308	1.2715	1.2178	1.2715	1.2071	1.2851	1.267
11	1.134	1.0924	1.182	1.182	1.0924	1.2094	1.1694
12	1.1744	1.1517	1.1871	1.1283	1.0208	.9922	1.1043
13	1.0277	.9922		1.0745	1.0029	.9568	1.0341
14	1.0277	.9313	1.0745	1.0029	1.0099	.8507	.9816
15	.9745	1.0349	1.0387	1.0242	1.0277	.9412	.9391
16	1.0808	.9922	1.1283	1.0425	1.182	.8682	.9774
17	1.1694	1.0745		1.1403	1.2178	1.1283	1.2048
18	1.2894	1.3253	1.3643	1.2357	1.3998	1.3213	
19	1.6827	1.885	1.7556	1.6448	1.848	1.6804	1.7002
20	1.5497	1.643	1.5893	1.531	1.6032	1.5497	1.531
21	1.363	1.3443	1.3817	1.307	1.4377	1.3392	1.3256
22	.9709	1.0829	1.1506	1.1128	1.0829	.9808	1.1128
23	.811	.7733	.8676	.7733	.9054	.8299	.8488
24	.6979	.7167	.6602	.679	.6602	.7545	.7733
Max	1.6827	1.885	1.7556	1.6448	1.848	1.6804	1.7002
Min	.6413	.6602	.6413	.6413	.6036	.679	.7167
Avg	1.1244	1.1154	1.1352	1.0725	1.1018	1.0834	1.1100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 202 / 11 KV MIDC PALUS FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.5093	.4715	.679	.547	.5281	.4904
2	.6036	.5093	.4715	.6413	.5281	.4904	.4904
3	.6224	.5093	.4904	.679	.5281	.5093	.4904
4	.6413	.5093	.4715	.6413	.547	.4715	.4904
5	.6224	.5847	.4904	.679	.547	.4715	.5093
6	.6413	.5847	.4715	.679	.5658	.4904	.5093
7	.6413	.6413	.5093		.6036	.4904	.5658
8	.6979	.6224	.6979	.6602	.5847	.5093	.6224
9	.8676	1.1317	.9242	.7373	.9431	.5281	.811
10	.924	1.1883	1.094	1.0456	1.0185	.5093	1.0829
11	1.094	1.4335	1.0562	.9522	1.226	.4715	.9055
12	.8299	.8676	.9997	.9242	.5658	.4338	.6908
13	.9335	1.1317		.8865	.9054	.4527	.8676
14	1.8107	1.1883	1.307	1.0562	1.3957	.547	1.7375
15	1.7918	1.3443	1.6057	1.094	1.4335	.547	.9522
16	1.4901	1.3392	1.4937	1.1506	1.2071	.5093	.8596
17	1.2012	1.0229	1.2637	.7356	1.2826	.5281	.7167
18	.679	.679	1.094	.6602	.7545	.5281	
19	.5658	.5847	.7167	.6224	.679	.5281	.5658
20	.4715	.547	.7356	.6036	.6036	.5281	.6036
21	.5093	.4715	.6036	.547	.6036	.547	.6224
22	.5093	.4527	.6224	.5847	.5847	.5281	.547
23	.5093	.4338	.6602	.5281	.5658	.4904	.5658
24	.5847	.5093	.4715	.6979	.547	.5281	.4904
Max	1.8107	1.4335	1.6057	1.1506	1.4335	.547	1.7375
Min	.4715	.4338	.4715	.5281	.5281	.4338	.4904
Avg	.8261	.7832	.8140	.7602	.7820	.5069	.7038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 203 / 11 KV GONDILWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.132	.9297	.8124	.6401	.132	.1509
2	.1132	.132	.9259	.933	.6481	.132	.1509
3	.132	.132	.9259	.9762	.6636	.1509	.1509
4	.1698	.1509	.953	1.004	.6636	.1698	.1886
5	.1886	.1886	1.0031	1.0402	.6874	.2829	.2263
6	.2452	.2241	1.186	1.0595	.7682	.3206	.2829
7	.3395	.2801	1.9271		.9922	.4338	.3395
8	.3395	.3734	.3206	.3142	.2957	.4024	.3361
9	1.3599	.3174	.2641	.3547	1.5655	1.8623	1.6164
10	2.1052	.3018	.3292	.3326	1.7604	2.2348	2.1445
11	2.3525	.2829	.2926	.2402	2.4966	2.4827	2.1032
12	2.5126	.2614	.3142	.2587	2.4966	2.372	1.9357
13	2.2929	.2641	.2587	.2587	2.4806	2.1872	1.9444
14	2.0715	.2641	.2772	.2218	2.4326	2.0399	1.8747
15	2.1822	.2075	.2772	.2587	1.9845	2.0241	1.8364
16	2.3562	.2452		.2587	1.9524	2.0083	1.8404
17	.1991	.2801		.3142	.2402	.1848	.2402
18	.2587	.2614	.3109	.2957	.2715	.2772	
19	.2587	.3206	.3361	.3174	.2926	.3206	.5601
20	.2402	.2829	.2829	.2829	.2614	.3206	.3206
21	.2402	.2829	.2452	.2452	.2452	.2452	.2263
22	.1867	1.1043	1.2071	.8697	.1886	.2263	.2075
23	.1307	.9877	.9259	.7253	.1509	.1698	.1698
24	.132	.132	1.8594	.8436	.6706	.132	.1509
Max	2.5126	1.1043	1.9271	1.0595	2.4966	2.4827	2.1445
Min	.1132	.132	.2452	.2218	.1509	.132	.1509
Avg	.8550	.3087	.6978	.5312	1.0354	.8797	.8260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 204 / 11 KV MINI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2075	.1886	.2263	.2075	.2075
2	.2263	.2075	.1886	.1698	.2075	.1886	.1886
3	.2075	.2075	.1886		.2075	.1698	.1886
4	.1886	.2075	.2075	.1509	.1886	.1886	.1886
5	.2075	.2263	.1886	.1698	.2075	.2075	.2075
6	.2075	.2263	.2075	.1886	.2075	.2263	.2075
7	.2075	.2829	.1886		.2075	.2263	.2075
8	.3772	.3772	.3772	.3584	.3961	.2075	.3772
9	.4715	.4904	.4527	.415	.3772	.2075	.3961
10	.4338	.4904	.4715	.415	.3772	.1886	.4527
11	.4904	.4527	.2926	.3772	.415	.1886	.3961
12	.3395	.3961	.3584	.3206	.3395	.2075	.3206
13	.3961	.3584	.3961	.3772	.3772	.1698	.3961
14	.2263	.4904	.415	.415	.4338	.1886	.3961
15	.3961	.3961	.415	.415	.1132	.1886	.3584
16	.4527	.4527	.4527	.415	.0943	.1698	.4338
17	.4527	.415	.3772	.3772	.0754	.1886	.3772
18	.3772	.3772	.3584	.3772	.2641	.1886	
19	.3772	.3018	.2829	.3772	.2452	.1886	.5847
20	.3018	.2829	.2452	.3206	.2641	.1886	.2452
21	.2263	.2641	.1886	.2641	.2263	.1886	.2452
22	.2452	.2829	.2075	.2452	.2263	.2075	.1886
23	.2452	.2263	.1886	.2641	.2075	.2075	.1698
24	.2452	.2263	.415	.2075	.2641	.2263	.2075
Max	.4904	.4904	.4715	.415	.4338	.2263	.5847
Min	.1886	.2075	.1886	.1509	.0754	.1698	.1698
Avg	.3136	.3277	.3030	.3095	.2562	.1965	.3018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 205 / 11 KV MAHADA COLONY

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0549	.0549	.0543	.0543	.0549	.0549
2	.0554	.0549	.0549	.0549	.0549	.0543	.0549
3	.0554	.0549	.0543	.0549	.0549	.0526	.0554
4	.0724	.0549	.0543	.0739	.0549	.0549	.0924
5	.1097	.0724	.0732	.0895	.0739	.0924	.0934
6	.128	.1086	.1494	.1109	.1109	.128	.1307
7	.1463	.1075	.1829		.1646	.1646	.1463
8	.1791	.1772	.1949	.1949	.197	.1928	.1991
9	.1402	.1433	.1734	.1907	.1578	.1595	.1214
10	.1341	.144	.1543	.1638	.1658	.12	.12
11	.1094	.1457	.1326	.144	.1658	.1235	.1326
12	.0914	.125	.128	.144	.112	.1107	.1094
13	.0914	.108	.116	.1475	.0995	.0937	.1094
14	.0926	.112	.116	.1311	.096	.0791	.0819
15	.108	.081	.096	.128	.0648	.0819	.0914
16	.108	.096	.1134	.096	.0949	.0819	.0983
17	.1265	.112	.1326	.0983	.144	.0848	.128
18	.1423	.1423	.16	.1311	.1619	.104	
19	.1578	.1949	.1772	.1928	.1772	.1097	.1595
20	.1578	.1612	.1791	.1433	.1433	.128	.1254
21	.1254	.128	.1417	.1267	.1254	.128	.128
22	.1086	.1097	.1109	.1109	.1086	.0914	.1097
23	.0905	.0732	.0724	.0732	.0732	.0732	.0554
24	.0554	.0724	.0549	.0543	.0543	.0543	.0549
Max	.1791	.1949	.1949	.1949	.197	.1928	.1991
Min	.0543	.0549	.0543	.0543	.0543	.0526	.0549
Avg	.11	.1098	.1199	.1178	.1129	.1008	.1066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 206 / 11 KV M.I.D.C. JAWAHAR SHEDDABLE FEEDER HAVING WEEKLY
 VIDYLAY Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.6413	.6224	.4904	.547	.4904	.547
2	.6036	.6413	.6036	.5093	.5281	.4715	.547
3	.6036	.6413	.6036	.5093		.4715	.547
4	.5847	.6602	.6224	.4904	.547	.4904	.5093
5	.6224	.6602	.6036	.5281	.5281	.4904	.5093
6	.6224	.6602	.6036	.5281	.5281	.4715	.4715
7	.6224	.6602	.6036		.4904	.4904	.4715
8	.5847	.6224	.6224	.5093	.5281	.4527	.4904
9	.6036	.811	.5847	.5093	.4715	.5093	.4715
10	.6602	.679	.5281	.5281	.5281	.547	.5041
11	.6135	.9242	.9054	.5093	.5281	.5281	1.358
12	.8865	.7922	.9997	.3961	.547	.5281	.8871
13	.4715	1.4377		.7545	.4715	.5281	.4298
14	1.3169	.7133	.9619	1.0562	.4904	.5093	.5493
15	.5093	.6283	1.1317	1.0562	1.1506	.5093	.4752
16	.5434	1.419	1.2449	1.2637	2.3954	.5281	.443
17	.4904	.8299	1.1317	.5093	1.2637	.5281	.4904
18	.5847	.8299	.5093	.7922	.4904	.5281	
19	.6036	.7545	.4527	.5281	.4904	.5281	.4904
20	.6036	.7922	.4715	.5281	.4904	.5281	.5093
21	.6413	.7545	.4527	.4715	.4715	.5281	.4904
22	.6413	.6224	.4715	.5093	.4904	.547	.5093
23	.679	.5847	.5281	.5281	.4904	.547	.5093
24	.6413	.6413	.6224	.5093	.547		.547
Max	1.3169	1.4377	1.2449	1.2637	2.3954	.547	1.358
Min	.0566	.5847	.4527	.3961	.4715	.4527	.4298
Avg	.6163	.7667	.6905	.6093	.6528	.5109	.5547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 201 / 11KV ASAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.2949	.5548	.7209	.0343	.0343	.0343
2	.0343	.2949	.5201	.6882	.0343	.0343	.0343
3	.0343	.2949	.5375	.639	.0343	.0343	.0343
4	.0343	.2949	.5201	.5735	.0343	.0343	.0343
5	.0343	.2949	.5375	.6062	.0343	.0343	.0343
6	.0343	.3277	.5935	.639	.0343	.0343	.0514
7	.0514	.3605	.2374	.6554	.0343	.0343	.0514
8	.0514	.0343	.0514	.0514	.0343	.0343	.0514
9	.852	.0343	.0514	.0514	.9175	1.1142	1.1142
10	.9389	.0343	.0343		.9221	1.2574	1.291
11	1.1233	.0343	.0343		.6036	1.3413	1.3077
12	1.1401	.0343	.0343		.6874	1.358	1.2574
13	1.1065	.0343	.0343		.8048	1.3413	1.1361
14	1.073	.0343	.0343		.9054	1.3245	1.1904
15	1.0562	.0343	.0343		1.1568	1.3748	1.2071
16		.0343	.0343	.0343	1.1065	1.3413	1.1401
17	.0343	.0343	.0343	.0343	.0229	.0343	.0343
18	.0343	.0351	.0343	.0343	.0343	.0343	.0343
19	.0343	.0526	.0514	.0343	.0343	.0514	.0343
20	.0343	.0526	.0514	.0343	.0343	.0514	.0343
21	.0343	.0526	.0514	.0343	.0343	.0514	.0343
22	.3277	.5959	.7537	.0343	.0343	.0514	.0343
23	.2949	.5721	.8029	.0343	.0343	.0343	.0343
24	.8916	.2949	.5548	.7865	.0343	.0343	.0343
Max	1.1401	.5959	.8029	.7865	1.1568	1.3748	1.3077
Min	.0343	.0343	.0343	.0343	.0229	.0343	.0343
Avg	.4037	.1734	.2574	.3159	.3184	.4613	.4268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 202 / 11KV M WADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6057	.0686	.0686	.0686	1.6057	1.6057	1.6712
2	1.5402	.0686	.0686	.0686	1.6617	1.6057	1.6221
3	1.5402	.0686	.0686	.0686	1.5729	1.5729	1.5893
4	1.5565	.0686	.0686	.0857	1.5402	1.5729	1.6385
5	1.5729	.0686	.0686	.0857	1.5074	1.5402	1.6712
6	1.5893	.1029	.0671	.1029	1.4091	1.5402	1.704
7	1.6057	.1029	.1006	.1029	1.6057	1.5238	1.7368
8	1.704	.1029	.1006	.1029	.1029	.12	.12
9	.0686	1.8023	2.2801	2.13	.0686	.0686	.0857
10	.0838	2.2283	2.343	2.13	.1006	.0686	.0693
11	.0671	2.3922	2.343	2.1628	.0838	.0857	.0693
12	.0838	2.2939	2.3758	1.6385	.1006	.0857	.1029
13	.1006	2.1628	2.4086	2.3266	.0838	.0857	.1029
14	.0838	2.2939	2.3266		.1006	.1029	.0857
15	.0838	2.2939	2.2447	2.2939	.1006	.0857	.1029
16		2.2447	2.1628	2.2611	.1006	.112	.12
17	.1029	.0686	.0655	.1029	.1029	.0857	.1029
18	.1029	.0857	.1029	.1543	.1372	.1029	.1029
19	.1029	.0857	.12	.1372	.1029	.12	.1029
20	.12	.0857	.12	.1372	.12	.12	.1029
21	.1029	.1029	.1029	.1029	.12	.12	.0857
22	.0686	.0686	.1029	1.704	1.5893	1.7204	1.6712
23	.0686	.0686	.0857	1.7368	1.6385	1.7532	1.704
24	1.6876	.0686	.0686	.0686	1.704	1.6385	1.7204
Max	1.704	2.3922	2.4086	2.3266	1.704	1.7532	1.7368
Min	.0671	.0686	.0655	.0686	.0686	.0686	.0693
Avg	.6801	.7916	.8277	.8597	.7192	.7265	.7535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 203 / 11 KV 4TH SONSAL FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0686	.0351	.0343	.4458	.4458	.4458
2	.1029	.0686	.0351	.0343	.4458	.4458	.463
3	.1029	.0686	.0351	.0343	.4458	.4458	.4458
4	.0983	.0686	.0351	.0343	.4458	.4458	.4287
5	.1029	.0686	.0351	.0343	.4458	.4458	.4287
6	.1029	.0686	.0343	.0343	.4458	.4458	.4115
7	.1029	.0686	.0514	.0343	.4458	.4458	.4287
8	.0686	.0686	.0343	.0343	.4458	.4458	.4115
9	.0686	.0686	.0514	.2743	.4458	.4973	.4458
10	.0503	.0343	.0343	.4458	.4508	.4359	.4359
11	.0503	.0686	.0343	.2401	.2254	.4359	.4191
12	.1006	.0343	.0343	.4115	.4334	.4359	.4024
13	.0514	.0343	.0343	.4458	.4334	.4359	.4024
14	.0857	.0343	.0686	.4458	.4161	.4024	.463
15	.0514	.1029	.0686	.4458	.4458	.4359	.4287
16		.1029	.0686	.4458	.4287	.4191	.4115
17	.0514	.1029	.0343	.4458	.4287	.4115	.4334
18	.0686	.0526	.0686	.4458	.4287	.4458	.463
19	.0686	.1052	.0686	.4458	.4458	.463	.4458
20	.0857	.0526	.0686	.4458	.4458	.463	.4458
21	.0686	.0526	.0686	.4458	.4458	.4458	.4458
22	.0686	.0526	.0686	.4458	.4458	.4458	.4458
23	.0686	.0351	.0686	.4458	.4458	.463	.4458
24	.1029	.0686	.0351	.0686	.4458	.4458	.4458
Max	.1029	.1052	.0686	.4458	.4508	.4973	.463
Min	.0503	.0343	.0343	.0343	.2254	.4024	.4024
Avg	.0794	.0646	.0488	.2758	.4324	.4437	.4352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 204 / 11KV M WADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195		.2427	.2195	.5121	.5121	.2561
2		.2195	.2427	.2195	.4755	.5121	.2561
3	.2195	.2195	.2614	.2195	.4572	.4755	.2561
4	.2926	.2195	.2801	.2926	.439	.439	.2926
5	.3658	.2926	.3361	.3658	.4755	.5121	.3658
6	.4755	.4755	.5228	.4755	.5487	.6219	.4755
7	.6584	.6584	.6722	.6584	.6219	.7316	.695
8	.6219	.6584	.6161	.6584	.6767	.6401	.6219
9	.4755	.5853	.4805	.4755	.4572	.4755	.4755
10	.4066	.4572	.3292	.439	.3326	.3174	.2957
11	.3142	.3109	.3292	.3109	.2772	.2427	.3142
12	.2957	.3475	.3292	.3292		.2801	.2587
13	.2614	.3292		.3109	.2402	.2241	.2587
14	.2614	.3109		.2926	.2587	.2218	.2402
15	.2614	.3292		.3109	.2427	.2218	.2241
16		.3109	.3658	.2926	.2987	.2218	.2614
17	.3292	.3475	.439	.3475	.3547	.0934	.3174
18	.4024	.3696	.5121	.3292	.439	.2561	.439
19	.6219	.6535	.5853	.6219	.7133	.5487	.7133
20	.6584	.5788	.6584	.5487	.6036	.5853	.695
21	.5487	.5228	.5487	.5304	.567	.5121	.5304
22	.3658		.439	.4572	.4755	.4024	.4755
23	.3292	.3361	.3292	.5121	.5121	.3292	.5121
24	.2195	.2195	.2614	.2561	.5487	.5487	.2926
Max	.6584	.6584	.6722	.6584	.7133	.7316	.7133
Min	.2195	.2195	.2427	.2195	.2402	.0934	.2241
Avg	.3911	.3978	.4181	.3947	.4577	.4136	.3968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 205 / 11 KV RAMAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	.0686	.0671	.0686	1.5074	1.3435	1.2125
2	1.278	.0686	.0671	.0686	1.4746	1.3763	1.1469
3	1.2944	.0686	.0671	.0686	1.4746	1.3435	1.1305
4	1.3108	.0686	.0671	.0686	1.4419	1.3108	1.1469
5	1.3272	.0686	.0671	.0686	1.1469	1.3108	1.2125
6	1.3272	.0686	.0671	.0857	1.1797	1.278	1.2944
7	1.3763	.0686	.1006	.0857	1.3763	1.3435	1.3435
8	1.5074	.0686	.0503	.1029	.0686		.12
9	.0857	1.3763	1.7695	1.9662	.0686	.0857	.0686
10	.0671	2.1628	1.8842	1.9989	.0503	.0655	.0514
11	.0503	2.2611	1.9498	1.9989	.0503	.0492	.0686
12	.0671	2.3922	2.0317	1.9989	.0503	.0492	.0686
13	.0492	2.2611	2.0481	1.9006	.0503	.0655	.0514
14	.0655	2.3758	1.9826	1.8351	.0503	.0492	.0503
15	.1147	2.0972	1.9334	1.8187	.0503	.0492	.0503
16		1.9989	1.8679	1.8187	.0671	.0671	.0671
17	.1029	.0686	.0686	.0686	.0514	.0503	.0848
18	.1029	.0838	.0686	.0686	.0686	.0686	.0686
19	.1029	.0838	.0857	.0686	.0686	.0686	.0686
20	.1029	.0838	.0857	.0686	.0686	.0686	.0686
21	.0686	.0671	.0857	.0686	.0686	.0686	.1029
22	.0686	.0838	.0857	1.3435	1.2452	1.2125	1.1142
23		.0671	.0857	1.4419	1.278	1.278	1.1797
24	1.3272	.0686	.0671	.0686	1.4746	1.3108	1.2452
Max	1.5074	2.3922	2.0481	1.9989	1.5074	1.3763	1.3435
Min	.0492	.0671	.0503	.0686	.0503	.0492	.0503
Avg	.5958	.7534	.6939	.7979	.6013	.6049	.5423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 206 / 11 KV CHINCHNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.6226	.7377	1.0159	.0686	.1029	.0686
2	.0686	.5571	.7042	.9339	.0686	.0686	.0686
3	.0686	.5571	.6874	.852	.0686	.0686	.0686
4	.0686	.5571	.6706	.8192	.1029	.1029	.1029
5	.0686	.6226	.6718	.8356	.1029	.1029	.12
6	.0857	.6554	.6882	.852	.1029	.1372	.12
7	.1029	.7373	.8848	.8848	.1372		.1372
8	.12	.0857	.8848	.12	.1543	.1715	.1543
9	1.0159	.0686	.0983	.1372	1.065	1.4746	1.4746
10	1.3413	.0686	.0857	.1029	1.278	1.5729	1.4746
11	1.4419	.0686	.1029	.1029	1.278	1.7204	1.5402
12	1.4251	.0686	.1029	.1372		1.6712	1.5565
13	1.3272	.0686	.1029	.1029	1.4582	1.6385	1.5402
14	1.2289	.0686	.1029	.1029	.5898	1.4419	1.4746
15	1.278	.0686	.1029	.1029		1.5729	1.4754
16		.0686	.1029	.1029		1.5729	1.4251
17	.0686	.0686	.12	.1715	.0335	.0838	.1187
18	.0686	.0671	.1029	.1715		.0857	.12
19	.0686	.1006	.1029	.1543	.12	.12	.12
20	.0686	.0838	.1029	.1372	.1029	.12	.12
21	.0686	.0838	.1029	.1029	.0686	.12	.12
22	.6554		.9667	.1372	.12	.12	.12
23	.6554	.8048	1.0978	.1372	.1372	.1029	.1029
24	.0686	.6554	.7712	1.065	.1029	.1372	.1029
Max	1.4419	.8048	1.0978	1.065	1.4582	1.7204	1.5565
Min	.0686	.0671	.0857	.1029	.0335	.0686	.0686
Avg	.4971	.2960	.4208	.3868	.3580	.6222	.5719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 207 / 11 KV AMBAK AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.6882	.9945	1.1105	.12	.1029	.0686
2	.0686	.6882	.9602	1.0608	.1029	.1029	.0686
3	.0686	.6882	.9602	1.0277	.1029	.0686	.0686
4	.1029	.6882	.9945	1.0277	.0686	.0686	.0686
5	.1029	.7209	.9892	1.0608	.0686	.0686	.1029
6	.12	.7865	1.0059	1.0608	.12	.1372	.1029
7	.1372	.8192	1.0059	1.0774	.1372	.1715	.1372
8	.1372	.12	.1341	.12	.1372	.1543	.1715
9	1.0608	.12	.1372	.0686	1.278	1.5074	1.4752
10	1.3032	.1372	.12	.1029	1.4922	1.6766	1.576
11	1.286	.1372	.12		1.4419	1.6095	1.6263
12		.1372	.1029		1.576	1.7939	1.643
13		.1372	.1029	.1029	1.6804	1.6598	1.6766
14	1.6118	.1372	.1029	.1029	1.7318	1.6461	1.7269
15	1.5947	.1715	.1029	.1029	1.749	1.6461	1.576
16		.1715	.12	.12	1.5775	1.5775	1.5424
17	.1029	.1715	.1029	.1372	.1052	.0701	.0876
18	.1029	.1402	.12	.1372	.1372	.1029	.1029
19	.1029	.1402	.12	.1715	.1372	.1029	.1029
20	.12	.1227	.12	.1715	.12	.1029	.1029
21	.1029	.1227	.12	.1543	.12	.1029	.0857
22	.7373	1.0517	1.1437	.1372	.1029	.0686	.1029
23	.7373	.9945	1.1934	.1372	.1372	.0686	.1029
24	.0686	.6882	1.0117	1.1603	.1372	.1029	.0686
Max	1.6118	1.0517	1.1934	1.1603	1.749	1.7939	1.7269
Min	.0686	.12	.1029	.0686	.0686	.0686	.0686
Avg	.4637	.4075	.4952	.4706	.5992	.6131	.5995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 201 / 11 KV WINE PARK 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1511	.1486	.1372	.0859	.2772	.1486	.1372
2	.1097	.1635	.1097	.1166	.2801	.144	.1216
3	.1075	.1635	.1139	.1153	.2801	.132	.1425
4	.1263	.1882	.1147	.1349	.2801	.1216	.1738
5	.1467	.2027	.1115	.1278	.2801	.1326	.1806
6	.1814	.5357	.0734	.1614	.2801	.1326	.1802
7	.2804	.6979	.1067	.2241		.1715	.4251
8	1.0829	.8676	.6535	.2641		.161	.3681
9	.7545	.679	1.1317	.5847	.7842	.1734	.7947
10	.9431	1.5089	.7577	.7545	.8589	.176	.9877
11	1.1317	1.5844	1.094	.8002	1.6194	.2075	.6283
12	.823	1.2637	.7356	.3052	1.3203	.2075	.6283
13	1.3203	.4687	.6762	.5716	.5281	.1886	
14	1.1317	1.1016	.4527	.7049	.6838		
15	.9431	1.2826	.7545	.9054	1.1128	.1698	
16	1.6975	1.3769	.7133	1.2637	.5316	.1698	
17	.9431	1.6004	.5792	1.0456	.7922	.1437	1.2012
18	.9054	.8488	.4359	.3506	.2429	.16	.6908
19	.1115	.3353	.3481	.3326	.2286	.1768	.3206
20	.1115	.2027	.1802	.2957	.1684	.1734	.1698
21	.0943	.144	.213	.1772	.1772	.1627	.2263
22	.109	.1635	.216	.1772	.1143	.1509	.2452
23	.1164	.1372	.1417	.2957	.1417	.1174	
24	.0966	.1189	.1635	.0859	.2957	.156	.1372
Max	1.6975	1.6004	1.1317	1.2637	1.6194	.2075	1.2012
Min	.0943	.1189	.0734	.0859	.1143	.1174	.1216
Avg	.5591	.6577	.4172	.4117	.5126	.1599	.4084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 202 / 11 KV ANDHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3603	.2641	.2263	.2263		1.3927	1.3765
2	1.3603	.2641	.2263	.2263			1.3927
3	1.4251	.2641	.2452	.2263			1.3763
4	1.4419	.2641	.2641	.2263			1.4255
5	1.4746	.2641	.2829	.2641			1.4255
6	1.7204	.4338	.3206	.3206			1.4752
7	2.0287	.4338	.4527	.4715			1.8351
8	2.1125	.4904	.415	.4338			.415
9	.3584	1.9993	2.0243	2.1136	.415	.415	.3395
10	.3018	2.3102	2.4034	2.5029	.3206	.3395	.3018
11	.3395	2.4777	2.3102	2.4366	.3772	.3772	.3395
12	.3584	2.3205	2.3266	2.2725	.3772	.3641	.3018
13	.3772	2.2672	2.3758	2.1765	.4527	.3772	
14	.3772	2.3758	2.1605	2.1792	.4338		
15	.3772	2.1605	2.1125	2.0317	.415	.3395	
16	.3961	2.2119	2.0805	2.0972	.415	.3772	
17	.3772	.3206	.0943	.3734	.3961	.3584	.2829
18	.3961	.3018	.3961	.2829	.3772	.3395	.3395
19	.415	.415	.3961	.2829	.415	.3961	.3584
20	.4338	.3772	.415	.3018	.3961	.415	.3961
21	.3772	.3584	.3206	.3018	.3772	.3584	.3961
22	.3206	.2829	.3018	1.6221	1.8861	1.4582	1.4548
23	.3018	.2263	.2641	1.6221	1.5203	1.4723	
24	1.3443	.2641	.1886	.2263	1.3957	1.4403	1.3765
Max	2.1125	2.4777	2.4034	2.5029	1.8861	1.4723	1.8351
Min	.3018	.2263	.0943	.2263	.3206	.3395	.2829
Avg	.8240	.9728	.9418	1.0508	.6231	.6388	.8741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 203 / 11KV ANDHALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 204 / 11KV BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.3841	.5601	.4801		.128	.1423
2	.128	.3521	.5601	.4641		.128	.1423
3	.144	.3521	.5601	.4641		.128	.1423
4	.144	.3521	.5601	.4641		.144	.1423
5	.176	.3521	.5601	.4801		.16	.1581
6	.176	.7682	.6562	.7362		.176	.1898
7	.2241	.7842	1.2163	1.0562		.2401	.253
8	.2214	.4161	.2241	.208		.2721	.2372
9	.9122	.176	.16	.176	1.0562	1.0562	.9962
10	1.3283	.144	.128	.16	1.4243	1.3443	1.2018
11	1.5684	.128	.16	.144	1.6804	1.4083	1.2651
12	1.5844	.144	.16	.128	1.1523	1.5043	1.3283
13	1.5203	.128	.112	.128	1.4403	1.5043	
14	1.4403	.096	.096	.112	1.2803		
15	1.3763	.112	.112	.112	1.3923	1.0562	
16		.128	.144	.112	1.2803	1.2483	
17	.128	.112	.144	.128	.128	.144	.128
18	.192	.16	.1739	.2241	.16	.16	.16
19	.192	.2241	.1898	.2241	.2241	.2214	.176
20	.192	.208	.2056	.208	.208	.2214	.192
21	.176	.192	.1898	.208	.192	.1898	.176
22	.4801	.5761	.4586	.176	.16	.1739	.16
23	.4801	.5441	.4744	.128	.128	.1581	
24	.1107	.4161	.5121	.4801		.128	.1423
Max	1.5844	.7842	1.2163	1.0562	1.6804	1.5043	1.3283
Min	.1107	.096	.096	.112	.128	.128	.128
Avg	.5662	.3021	.3466	.3001	.7938	.5172	.3859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 205 / 11 KV MORALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	1.0562	1.0082	1.1043		.048	.0633
2	.0633	1.0082	1.0082	1.1203		.048	.0474
3	.08		1.0082	1.1203		.048	.0474
4	.08	1.0082	1.0082	1.1363		.048	.0474
5	.096	1.0242	1.0082	1.2163		.064	.0474
6	.096	1.1843	1.0082	1.2963		.064	.0633
7	.112	1.2323	1.2803	1.3763		.08	.0633
8	.0949	.096	.096	.096		.08	.0791
9	1.2643	.096	.096	.096	1.4563	1.5684	1.3916
10	1.7284	.112	.096	.096	1.7124	1.7764	1.4232
11	1.6804	.096	.08	.08	1.8884	1.7444	1.5497
12	1.5844	.08	.08	.096	1.8084	1.6804	1.7236
13	1.7444	.08	.08	.08	1.6644	1.4883	
14	1.5844	.064	.064	.08	1.6324		
15	1.5844	.064	.064	.08	1.5684	1.3603	
16	1.6484	.08	.064	.08	1.5844	1.6004	
17	.096	.096	.064	.08	.048	.0633	.064
18	.096	.08	.0633	.064	.064	.0633	.064
19	.096	.08	.0633	.064	.064	.0633	.08
20	.096	.064	.0633	.048	.064	.0791	.08
21	.08	.064	.0633	.048	.064	.0633	.08
22	1.1363	1.0402	1.0911	.048	.064	.0633	.064
23	1.1043	1.0082	1.0911	.048	.048	.0633	
24	.0633	1.1043	.9922	1.1043	.048	.048	.0633
Max	1.7444	1.2323	1.2803	1.3763	1.8884	1.7764	1.7236
Min	.0633	.064	.0633	.048	.048	.048	.0474
Avg	.6780	.4704	.4809	.4441	.8612	.5307	.3706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 206 / 11KV LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987		.8299	.3961		.0732
2	.2987		.8676	.3961		.0732
3	.2987		.8676	.3961		.0732
4	.2987		.8676	.3961		.0732
5	.2987		.8676	.3961		.0732
6	.2987		.8676	.3961		.0732
7	.7655		.6036	.6036		.415
8	.6036		.811	.7356		.6979
9	.7095	.8589	.5658	.9054	.8775	.5658
10	.5847	.5847	.8775	.8962	.8775	.8865
11	.8865	.8488	.8775	.8775	.8775	.7733
12	.8676	.8215	.8775	.8775	.8589	.7733
13	.8676	.8589	.8589	.8775	.8589	
14	.8676	.8589	.8775	.8775	.8589	
15	.8676	.8775	.8775	.8775	.8775	
16	.8488	.8589	.8775	.8029	.8775	
24	.181					
Max	.8865	.8775	.8775	.9054	.8775	.8865
Min	.181	.5847	.5658	.3961	.8589	.0732
Avg	.5790	.8210	.8295	.6692	.8705	.3793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 207 / 11 KV Kranti LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0002		.208	.208		.2229
2	.0004		.2279	.208		.2279
3	.0002		.2279	.208		.2229
4	.0004		.2279	.208		.2229
5	.0004		.2279	.208		.2229
6	.0004		.2254	.208		.2279
7	.0002		.2279	.208		.2229
8	.0008		.2279	.2254		.2229
9	.0004	.0008	.2254	.2254	.2254	.2229
10	.0002	.0008	.2254	.2229	.2254	.2229
11	.0008	.0011	.2229	.2229	.2254	.2229
12	.0002	.0008	.2229	.2204	.2229	.2229
13	.0004	.0008	.2229	.218	.2204	
14	.0002	.2229	.2204	.2229	.218	
15	.0008	.2229	.2229	.2229	.2204	
16	.0008	.2204	.2229	.0008	.2204	
Max	.0008	.2229	.2279	.2254	.2254	.2279
Min	.0002	.0008	.208	.0008	.218	.2229
Avg	.0004	.0838	.2242	.2024	.2223	.2237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 401 / 33 KV SOOTGIRANI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.5844	1.6975	1.7924	1.5844	1.5844	1.6975
2	1.6975	1.6975	1.6975	1.7924	1.5844	1.6409	1.6975
3	1.6975	1.6975	1.6804	1.6804	1.5844	1.6409	1.6975
4	1.6975	1.6975	1.6804	1.6804	1.5844	1.5844	1.5844
5	1.6975	1.6975	1.6804	1.6804	1.5844	1.5844	1.6975
6	1.8107	1.6975	1.5844	1.6804	1.5844	1.5844	1.5844
7	1.7924	1.5844	1.6975	1.7924	1.5844	1.5844	1.5844
8	1.5844	1.5844	1.6975	1.7924	1.5844	1.5844	1.5844
9	1.5844	1.5844	1.5844	1.6804	1.5844	1.4146	1.4712
10	1.6975	1.4712	1.5844	1.4563	1.5844	1.6804	1.5844
11	1.5278	1.4712	1.4712		1.5844	1.6804	1.5844
12	1.4146	1.5844	1.4712	1.4712	1.5844	1.6804	1.5844
13	1.5278	1.4712	1.5844	1.4712	1.4712	1.4563	1.5844
14	1.4712	1.4712	1.4712	1.4712	1.358		1.5844
15	1.4146	1.5844	1.6975	1.4712	1.4712	1.4563	1.5844
16	1.4712	1.4712	1.1317	1.5844	1.6975	1.6804	1.5844
17	1.4146	1.4712	1.358	1.5844	1.6975	1.5844	1.5844
18	1.4712	1.3014	1.4563	1.5844	1.5844	1.4712	1.8107
19	1.4712	1.3014	1.4563	1.5844	1.5278	1.2449	1.6975
20	1.4712	1.2449	1.5684	1.5844	1.4146	1.358	1.5844
21	1.4712	1.3014	1.5684	1.5844	1.4146	1.2449	1.6975
22	1.4712	1.3014	1.7924	1.5844	1.4146	1.5844	1.6804
23	1.4712	1.5844	1.7924	1.5844	1.5278	1.5844	1.6804
24	1.8107	1.4712	1.6975	1.7924	1.5844	1.5844	1.6975
Max	1.8107	1.6975	1.7924	1.7924	1.6975	1.6804	1.8107
Min	1.4146	1.2449	1.1317	1.4563	1.358	1.2449	1.4712
Avg	1.5812	1.5136	1.5876	1.6252	1.5490	1.5432	1.6301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 201 / 11 KV PADLI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0297	.6173	.6882	.7926	.0305	.0297	.0297
2	.0297	.6173	.6882	.7926	.0305	.0305	.0297
3	.0297	.6173	.6882	.7926	.0305	.0305	.0297
4	.029	.6173	.7209	.7926	.0305	.0305	.0297
5	.029	.6173	.7865	.7926	.0305	.0297	.0297
6	.0301	.6173	.852	.8535	.0305	.0297	.0343
7	.0301	.8025	.8642	.9998	.0305	.029	.0343
8		.029	.0305	.0305	.0305	.029	.0351
9	1.2018	.029	.0305	.0305	.9145	1.2963	1.3916
10	1.3283	.029	.029	.0305	1.0974	1.5364	1.5432
11	1.4548	.029	.029	.0305	1.2193	1.5154	1.4661
12	1.5181	.029	.029	.0305	1.2803	1.4373	1.4661
13	1.5181	.0282	.029	.0305	1.3413	1.3904	1.4661
14	1.5181	.0282	.029	.0305	1.3413	1.3283	1.4661
15	1.3916	.0282	.029	.0305	1.3413	1.3283	1.3889
16	1.2651	.0282	.0282	.0305	1.3413	1.2809	1.3272
17	.0293	.0282	.029	.0305	.0305	.0236	.0309
18	.0293	.0282	.029	.0305	.0282	.0251	.0463
19	.0282	.0282	.0278		.029	.0297	.0457
20	.0282	.029	.0263	.0305	.029	.0297	.0305
21	.0282	.029	.0259	.0305	.0293	.029	.0305
22	.7407	.7468	.9145	.0305	.0293	.029	.0305
23	.7407	.7042	.9145	.0305	.0297	.029	.0305
24	.0301	.679	.6722	.8535	.0305		.0297
Max	1.5181	.8025	.9145	.9998	1.3413	1.5364	1.5432
Min	.0282	.0282	.0259	.0305	.0282	.0236	.0297
Avg	.5677	.2932	.3413	.3099	.4315	.5020	.5018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 202 / 11 SONSAL GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2957	.3658	.3772	.362	.3292	.3772
2	.3772	.2957	.3658	.3772	.362	.3292	.3772
3	.3734	.2957	.3658	.3772	.362	.3292	.3772
4	.4066	.2926	.4066	.3772	.362	.3292	.3772
5	.4805	.3658	.5175	.415	.362	.3658	.4904
6	.6348	.543	.5914	.5658	.6154	.6154	.6348
7	.7316	.6154	.7468	.7095	.724	.6154	.8215
8	.6805	.6516	.6516	.6516	.6516	.5792	.7392
9	.4066	.5853	.543	.5853	.6516	.4344	.5853
10	.5068	.5121	.5068	.5121	.5792	.4163	.543
11	.543	.5068	.4706	.4706	.543	.4163	.5068
12	.4908	.5068	.4706	.4344	.5068	.3109	.4344
13	.4557	.5014	.4344	.4344	.4344	.2743	.4024
14	.4557	.5175	.4344	.4344	.4344	.2172	.4024
15	.4252	.4344	.4344	.4344	.4344	.2172	.3982
16	.4344	.4344	.4706	.4706	.4344	.2172	.4344
17	.4706	.3801	.4961	.543	.4344	.3544	.4755
18	.5068	.362	.5258	.543	.5068	.4207	.567
19	.6154	.6722	.7682		.6516	.7023	.7545
20	.5792	.6722	.7023	.724	.6878	.6722	.7922
21	.543	.6722	.5975	.724		.5975	.679
22	.3982	.6348	.4904	.5792	.5068	.5228	.5658
23	.362	.5601	.4527	.362	.4344	.4904	.3696
24	.3772	.3292	.362	.415	.362	.362	.415
Max	.7316	.6722	.7682	.724	.724	.7023	.8215
Min	.362	.2926	.362	.362	.362	.2172	.3696
Avg	.4847	.4849	.5071	.5007	.4958	.4216	.5217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 203 / 11 KV SONKIRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8951	.0452	.061	.0457	1.004	.9804	1.0911
2	.8951	.0452	.061	.0472	1.004	.9804	1.0279
3	.8951	.0452	.0594	.0472	1.004	.9804	1.0279
4	.8951	.0452	.0446	.0472	1.004	.9804	1.0279
5	.8951	.0452	.0423	.0591	1.004	.9804	1.0279
6	.9061	.0452	.0423	.0442	1.0202	.9962	1.0595
7	1.0753	.0594	.0423	.0587	1.0202	1.0437	1.1203
8	1.012	.0594	.0564	.081	.081	.0457	.0834
9	.0533	1.2186	1.4403	1.5546	.081	.0457	.0667
10	.0549	1.576	1.7394	1.7166	.081	.0457	.0705
11	.0572	1.6598	1.7711	1.8299	.081	.0457	.0564
12	.0686	1.6907	1.7711	1.8461	.081	.061	.0594
13	.0714	1.6907	1.7394	1.8461	.081	.0914	.0743
14	.0686	1.6324	1.6762	1.8461	.081	.0914	.0594
15	.0667	1.6004	1.7553	1.8461	.081	.0914	.0724
16	.0638		1.6604	1.749	.081	.0914	.0724
17	.0533	.064	.0619	.0972	.081	.0867	.0724
18	.0594	.08	.0572	.0972	.0743	.088	.0743
19	.0579	.064	.06		.0743	.08	.0743
20	.0579	.061	.061	.081	.0594	.0754	.0594
21	.0579	.061	.0581	.081	.0594	.0823	.0594
22	.0594	.061	.0524	1.1012	1.0437	1.2018	.9065
23	.0452	.061	.0442	1.0364	1.0437	1.2018	.9568
24	.884	.0452	.061	.0457	1.004	1.012	1.1385
Max	1.0753	1.6907	1.7711	1.8461	1.0437	1.2018	1.1385
Min	.0452	.0452	.0423	.0442	.0594	.0457	.0564
Avg	.3854	.5198	.6008	.7480	.4679	.4741	.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 201 / 11 KV DEORASHTRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 202 / 11KV KUNDAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 203 / 11 KV PALUS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 204 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 205 / 11 KV TAKARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 401 / 33 KV KIRLOSKAR WADI NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	2.7149
Max	2.7149
Min	2.7149
Avg	2.7149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 403 / 33 KV PALUS

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	2.7149
Max	2.7149
Min	2.7149
Avg	2.7149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 404 / 33 KV MOHITE VADGAON
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	2.7149
Max	2.7149
Min	2.7149
Avg	2.7149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 405 / 33 KV EBARA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 406 / 33 KV SANDGEWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.543
Max	.543
Min	.543
Avg	.543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 407 / 33KV KRANTI CO-GENERATION NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.543
Max	.543
Min	.543
Avg	.543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 408 / KRANTI CO-GEN-II NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 259009 / 400KV KARAD STN.

Feeder No / Name : 807 / 220 KV KARAD KOP LINE 2 ND NON SHEDDABLE EHV INDUSTRIAL FEEDERS
CRT Feeder KV- 220 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-FEB-18
HR	Load (MW)
24	.181
Max	.181
Min	.181
Avg	.181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 201 / 11 KV KADEPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	1.2163	1.5074	1.4548	.0617	.0724	.1463
2	.1448	1.1385	1.4899	1.3748	.0617	.0732	.1448
3	.1448	1.1385	1.4899	1.2963	.0617	.0732	.1463
4	.1448	1.2803	1.4373	1.2654	.0625	.0732	.1478
5	.1612	1.3443	1.5546	1.3123	.0625	.0724	.1463
6	.1791	1.5074	1.6194	1.3283	.1326	.0716	.1848
7	.1791	1.6842	1.749	1.4548	.1478	.1448	.1848
8	.1772	.1417	.1341	.1326	.1341	.1341	.1848
9	1.8976	.208	.1402	.1341	1.7711	2.4905	2.2672
10	2.2939	.1402	.1387	.2035	2.2672	2.5301	2.4249
11	2.332	.1463	.1372	.1341	2.1765	2.7183	2.4615
12	2.5263	.1463	.2149	.1341	2.2024	2.6993	2.4326
13	2.7526	.1311	.1311	.1357	2.5263	2.9835	2.4669
14	2.6216	.1387	.1341	.1357	2.5606	2.8178	2.4326
15	2.556	.1402	.1341	.1357	2.7526	3.0445	2.3685
16	2.332	.1417	.2035	.1433	2.556	2.4615	2.1247
17	.1966	.2058	.2035	.1448	.1372	.1715	.0602
18	.1852	.2058	.2035	.0701	.1326	.1753	.064
19	.192	.1311	.2035	.0686	.1311	.1791	.0655
20	.1989	.1387	.2058	.0663	.1341	.181	.0671
21	.1387	.1029	.2058	.0633	.1311	.1791	.0671
22	1.2651	1.4723	1.4723	.0617	.0701	.1433	.0678
23	1.2651	1.4899	1.5364	.0602	.0724	.1448	.0671
24	.1433	1.2163	1.5074	1.5364	.061	.0732	.1448
Max	2.7526	1.6842	1.749	1.5364	2.7526	3.0445	2.4669
Min	.1387	.1029	.1311	.0602	.061	.0716	.0602
Avg	1.0072	.6503	.7397	.5353	.8503	.9878	.8695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 203 / 11 KV WANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8619	.0354	.0366	.0335	.6371	.7316	.6958
2	.8619	.0354	.0366	.0335	.5792	.6706	.6958
3	.852	.0358	.0366	.0332	.5281	.6706	.7042
4	.8619	.0358	.0362	.0332	.5868	.7407	.6958
5	.8745	.0724	.0362	.0655	.6371	.7926	.7907
6	.8642	.0739	.0724	.0709	.6539	.8642	1.012
7		.0739	.0724	.0686	.9145	1.1385	1.0883
8	.7811	.0709	.0633	.0678	.0663	.0648	.0701
9	.0701	1.0364	1.2651	1.1728	.0671	.0701	.0716
10	.0701	1.3123	1.3916	1.1873	.061	.0671	.0724
11	.0709	1.6644	1.4723	1.2498	.064	.0663	.064
12	.0701	1.6842	1.4548	1.3748	.0655		
13	.0701	1.6004	1.4548	1.358	.064	.0701	
14	.0716	1.6842	1.3748	1.358	.0648	.0716	.0602
15	.0724	1.4998	1.3123	1.3748	.0671	.0716	.0655
16	.0732	1.4373	1.3123	1.3413	.0686	.0716	.0625
17	.0701	.0564	.0686	.0633	.0655	.0732	.0564
18		.0633	.0686	.061	.064	.0724	.0602
19	.0716	.0678	.0686	.0625	.0655	.1646	.0617
20	.0709	.0671	.0686	.0633	.0663	.0724	.0633
21	.0701	.0648	.0686	.064	.0655	.0732	.0648
22	.0709	.0693	.0693	.6622	.6706	.6249	.6622
23	.0716	.0686	.0343	.7042	.7316	.7042	.6706
24	.8619	.0716	.0724	.0343	.7042	.7316	.7042
Max	.8745	1.6842	1.4723	1.3748	.9145	1.1385	1.0883
Min	.0701	.0354	.0343	.0332	.061	.0648	.0564
Avg	.3551	.5367	.4978	.5224	.3149	.3773	.3860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 204 / 11 KV AMARAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1132	.1097	.1509	.128	.1463	.1463
2	.1254	.0943	.112	.1307	.1097	.1463	.1433
3	.1254	.0754	.112	.112	.1097	.1448	.1402
4	.128	.0943	.112	.1109	.1267	.1829	.1417
5	.1848	.1132	.1494	.128	.1448	.1829	.2328
6	.1867	.1698	.1867	.1663	.2033	.2587	.3142
7	.1848	.2452	.2614	.2033	.2801	.3326	.3142
8	.1848	.2054	.2033	.2218	.2614	.2561	.3142
9	.1658	.1848	.2012	.1991	.1646	.197	.197
10	.128	.128	.1791	.1715	.1267	.1696	.156
11	.1075	.1075	.1543	.1372	.0867	.1578	.124
12	.1063	.1029	.1509	.1509	.1052	.1402	.1052
13	.0886	.0886	.104	.1341	.1075	.1402	.0895
14	.0905	.0857	.1006	.1341	.1029	.1227	.0895
15	.0732	.1029	.1052	.12		.1086	.0716
16	.0905	.1029	.12	.1214		.1086	.1029
17	.0867		.156	.12	.12	.1254	.1372
18	.1402	.1677	.1928	.1715	.1696	.1646	.2058
19	.2172	.2328	.2353	.2103	.2279	.1629	.2172
20	.2378	.2058	.2378	.2353	.2534	.1629	.2378
21	.2012	.1677	.2218	.2033	.2195	.2195	.2195
22	.1509	.1663	.1867	.1829	.2012	.1848	.1829
23	.132	.1463	.168	.1448	.1829	.1478	.1829
24	.128	.132	.128	.1509	.1478	.1463	.1478
Max	.2378	.2452	.2614	.2353	.2801	.3326	.3142
Min	.0732	.0754	.1006	.1109	.0867	.1086	.0716
Avg	.1413	.1406	.1620	.1588	.1627	.1712	.1756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 205 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1791	.2987	.1402	.1387	.1509	.1463
2	.1848	.1791	.2987	.1214	.1214	.1509	.1478
3	.1829	.1991	.2987	.1214	.1402	.1509	.1478
4	.181	.2172	.2987	.1402	.1578	.1509	.1478
5	.2534	.2534	.2987	.1595	.1772	.2075	.1463
6	.3109	.3326	.3292	.2195	.2561	.2829	.2402
7	.3077	.2926	.3403	.2743	.2926	.3475	.2402
8	.3077	.3224	.3121	.3045	.2715	.3012	.1848
9	.333	.2601	.2454	.2743	.2427	.2054	.1478
10	.2601	.2258	.2303		.2534	.2543	.1646
11	.2801	.2591	.2303	.1753	.2012	.197	.1753
12	.2591	.2622	.1753	.1753	.1629	.1753	
13	.2454	.2429	.1734	.1543	.1991	.1612	
14	.2683	.2294	.1907	.156	.1715	.181	.2229
15	.2688	.2241	.2279	.1715	.1417	.197	.1991
16	.2561	.2469	.2401	.1612	.1715	.1075	.1463
17	.253	.2378	.2572	.1928	.2149	.1075	.1791
18	.2427	.2881	.2713	.197	.1886	.1478	.2401
19	.3045	.3277	.2713	.2103	.2427	.2012	.2601
20	.3403	.3121	.3052	.2279	.2641	.181	.2507
21	.2715	.3005	.2515	.2427	.2452	.1791	.2353
22		.285	.2012	.2058	.2241	.1448	.2012
23	.2149	.2926	.181	.1696	.2054	.1448	.1829
24	.1829	.197	.2926	.1595	.1543	.1867	.1463
Max	.3403	.3326	.3403	.3045	.2926	.3475	.2601
Min	.181	.1791	.1734	.1214	.1214	.1075	.1463
Avg	.2563	.2570	.2592	.1893	.2016	.1881	.1888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 206 / 11 KV CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	1.2163	1.5074	1.4083	.0949	.1311	.1097
2	.0716	1.1523	1.5074	1.3916	.064	.0655	.1109
3	.0724	1.2163	1.5074	1.3283	.064	.0671	.1109
4	.0732	1.2955	1.5074	1.3283	.0995	.0671	.1109
5	.0716	1.2955	1.6385	1.3283	.1017	.1341	.1109
6	.0701	1.4586	1.704	1.4899	.1402	.1311	.112
7	.1753	1.6385	1.8351	1.8351	.1402	.1494	.112
8	.2149	.1006	.1875	.0983	.1254	.1433	.1109
9	.3547	.125	.1448	.1326	2.0081	2.5857	2.5194
10	2.2542	.1113	.1417	.0983	2.5857		2.556
11	2.2939	.1113	.1372	.0937	2.4905	2.9172	2.5857
12	2.3594	.1219	.1341	.0869	2.9835	2.652	2.5857
13	2.4249	.1219	.096	.096	2.8166	2.652	2.7183
14	2.2939	.1235	.1204	.1029	2.7526		2.5857
15	2.2283	.1189	.1075	.1097	2.7183	2.652	2.4531
16	2.0972	.1128	.1417	.1086	2.6246	2.4531	2.2283
17	.0617	.1341	.1387	.1075	.125	.1402	
18	.0926	.1433	.1357	.1417	.1311	.1433	.1417
19	.1029	.0701	.1341	.1387	.1235	.1448	.1372
20	.1029	.1372	.128	.1326	.1097	.0739	.0724
21	.1029	.1543	.1174	.128	.1235	.0732	.0693
22	1.2955	1.4723	1.4251	.1265	.125	.0739	.0701
23	1.2955	1.4899	1.4899	.1107	.1235	.0739	.0701
24	.0701	1.2955	1.5074	1.4899	.0949	.1311	.1294
Max	2.4249	1.6385	1.8351	1.8351	2.9835	2.9172	2.7183
Min	.0617	.0701	.096	.0869	.064	.0655	.0693
Avg	.8437	.6340	.7289	.5589	.9486	.8025	.9483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 207 / 11 KV KADEPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2865	.3772	.3206	.3772	.3206	.3395	.1646
2	.2957	.3395	.3206	.3395	.3018	.3395	.1612
3	.2926	.3206	.3206	.3018	.3395	.3395	.1629
4	.362	.3395	.3395	.3018	.3584	.3772	.1646
5	.439	.3584	.3772	.3395	.3772	.4527	.2743
6	.4715	.5658	.4904	.5093	.5093	.5847	.4481
7	.4481	.6413	.5658	.6036	.6602	.6602	.4435
8	.3696	.6224	.4527	.6224	.6036	.4527	.4435
9	.2587	.5093	.3961	.5658	.5093	.3018	.4572
10	.3772	.415	.3961	.415	.415	.2427	.4527
11	.4904	.3772	.415	.4338	.3018	.2054	.415
12	.415	.415	.3961	.4527	.3206	.1663	.3395
13	.4904	.4338	.4338	.415	.3961	.1848	.415
14	.415	.415		.3961	.4338	.2195	.415
15	.4338	.415	.4338	.3772	.4527	.2195	.415
16	.4338	.415	.4338	.3772	.3961	.2195	.415
17	.4527	.4338	.4338	.4338	.4904	.2149	.4338
18		.415	.4715	.4715	.3018	.2561	.4527
19	.547	.3961	.5093	.4715	.3584	.3142	.4904
20	.5281	.3772	.4715	.4904	.3772	.3142	.4904
21	.4715	.3395	.4338	.4904	.3584	.2743	.4715
22	.4338	.3206	.4715	.415	.3395	.2241	.415
23	.415	.3206	.4527	.3772	.3395	.168	.3961
24	.2957	.3961	.3206	.4338	.3584	.3395	.1663
Max	.547	.6413	.5658	.6224	.6602	.6602	.4904
Min	.2587	.3206	.3206	.3018	.3018	.1663	.1612
Avg	.4097	.4150	.4199	.4338	.4008	.3088	.3710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 401 / 33 KV SAGARESHWAR SAHAKARI NON SHEDDABLE EHV INDUSTRIAL FEEDERS

SOO Feeder KV- 33 / OUTGOING

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6029	2.6029	2.6029	2.4897	2.3765	2.6029
2	2.4897	2.6029	2.6029	2.3765	2.3765	2.6029
3	2.2634	2.6595	2.6029	2.3765	2.4331	2.6029
4	2.2634	2.6595	2.6029	2.4897	2.4331	2.6029
5	2.2634	2.7161	2.6029	2.6029	2.4897	2.6029
6	1.6975	2.8292	2.6029	2.6595	2.6595	2.6029
7	2.6595	2.4897	2.7161	2.5463	2.6595	2.6595
8	2.6595	2.6595	2.7161	2.6595	2.4897	2.6029
9	2.7161	2.7726	2.6029	2.7726	2.7726	2.7161
10	2.6029	2.3765	2.6595	2.4331	2.6029	2.6029
11	2.4897	2.5463	2.7161	2.4897	2.6029	2.8292
12	2.6595	2.7161	2.6595	2.6029	2.8292	2.7726
13	2.6595	2.5463	2.4897	2.5463	2.6029	2.7726
14	2.7726	2.5463	2.6029	2.5463	2.7161	2.6595
15	2.8858	2.4897	2.7726	2.5463	2.7161	2.6595
16	2.7161	2.5463	2.5463	2.4331	2.7161	2.7726
17	2.4897	2.5463	2.5463	2.7161	2.4331	2.6595
18		2.4897	2.5463	2.6595	2.5463	2.5463
19		2.4331	2.5463	2.6029	2.4897	
20	2.5463		2.4897	2.5463	2.4897	
21	2.4331	2.3765	2.4897	2.4897	2.5463	
22	2.5463	2.4897	2.4897	2.4331	2.6029	
23	2.5463	2.5463	2.4897	2.3765	2.6029	
24	2.6595	2.4897	2.6029	2.4897	2.4331	2.6029
Max	2.8858	2.8292	2.7726	2.7726	2.8292	2.8292
Min	1.6975	2.3765	2.4897	2.3765	2.3765	2.5463
Avg	2.5283	2.5709	2.5958	2.5369	2.5675	2.6565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 201 / 11 KV KADEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.5487	.4294	.5544	.6584	.462	.4527
2	.4066	.4805	.4294	.5175	.5792	.462	.4527
3	.4108	.4755	.4338	.5175	.5487	.4294	.4527
4	.4435	.6516	.4904	.5228	.6584	.4805	.4715
5	.5658	.8048	.5658	.5601	.7316	.5359	.5281
6	.9425	1.1088	.9054	.8962	.9412	.8779	.9054
7	1.3817	1.2986	1.4146	1.2696	1.0974	1.2382	1.4146
8	1.5844	1.3169	1.4937	1.6057	1.3032	1.419	1.5466
9	1.1949	1.2197	1.1203	1.307	1.2536	1.1458	1.1576
10	1.0082	.9795	.9145	1.0719	.9877	.8779	.924
11	.8413	.823	.8413	.9877	.8596	.7392	.905
12	.7602	.8145	.7964		.788	.7392	.8326
13	.7316	.7602	.7522	.7392	.7362	.6908	.7164
14	.6584	.724	.7164	.6584	.6697	.6838	.6447
15	.6283	.6335	.6805		.6154	.7392	.6447
16	.6584	.6268	.6516	.695	.6984	.7468	.6447
17	.7865	.724	.6733	.724	.6984	.7316	.7522
18	.9145	.8059	.9671	.9313	.8962	.7602	.9877
19	1.1584	1.1946	1.1827	1.2437	1.2567	1.2012	1.3306
20	1.3169	1.1458	1.2936	1.3306	1.1949	1.1458	1.1088
21	1.0745	1.0269	1.0349	1.0974	1.1694	1.0269	1.0719
22	.8859	.8589	.924	.9425	.9522	.9054	.8589
23	.7712	.5914	.6653	.7682	.6653	.6224	.6722
24	.4668	.6516	.4294	.5914	.7316	.5041	.4715
Max	1.5844	1.3169	1.4937	1.6057	1.3032	1.419	1.5466
Min	.4066	.4755	.4294	.5175	.5487	.4294	.4527
Avg	.8344	.8444	.8253	.8878	.8621	.7986	.8312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 202 / 11 KV MIDC NO.1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.406	1.5238	1.5927	1.5432	1.5249	
2	1.491	1.4327	1.4883	1.5927	1.6126	1.5083	1.4373
3	1.5238	1.5203	1.4883	1.5043	1.6478	1.5261	1.4217
4	1.5415	1.5043	1.4883	1.5043	1.6118	1.4563	1.387
5	1.5424	1.5238	1.4883	1.4883	1.5565	1.4373	1.387
6	1.576	1.4723	1.5238	1.5238	1.4506	1.576	1.387
7	1.5074	1.5089	1.576	1.5927	1.5043	1.5581	1.4217
8	1.5074	1.5074	1.4563	1.4529	1.5238	1.1797	1.406
9	1.6461	1.5402	1.5927	1.5565	1.4723	.815	1.5238
10	1.576	1.576	1.5927	1.5927	1.576	.8657	1.5947
11	1.4723	1.6126	1.5565	1.6461	1.7741	.8002	1.6289
12	1.5074	1.6118	1.6278		1.7193		1.6289
13	1.576	1.4883	1.6461	1.6095	1.6476		1.647
14	1.5364	1.5947	1.7002	1.5402	1.6834		1.647
15	1.5154	1.6461	1.6632		1.6476		1.647
16	1.4632	1.6118	1.6448	1.6095	1.6108		1.6289
17	1.4784	1.6289	1.7193	1.5364	1.576		1.647
18	1.406	1.5238	1.6827	1.5524	1.6108	.4268	1.6827
19	1.4022	1.5927	1.6461	1.4998	1.5415	.5155	1.701
20	1.3969	1.5592	1.6278	1.4842	1.5043	.7407	1.6461
21	1.4118	1.5402	1.6095	1.4022	1.6118	1.4883	1.576
22	1.4175	1.5402	1.6095	1.4685	1.576	1.4723	1.5074
23	1.4373	1.5074	1.6095	1.4883	1.576	1.387	1.4043
24	1.4352	1.4723	1.5238	1.5927	1.5238	1.5402	1.4723
Max	1.6461	1.6461	1.7193	1.6461	1.7741	1.576	1.701
Min	1.3969	1.406	1.4563	1.4022	1.4506	.4268	1.387
Avg	1.4927	1.5384	1.5869	1.5378	1.5876	1.2121	1.5405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 203 / 11 KV SHALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3923	.128	.0709	.0747	1.4083	1.4575	1.4746
2		.1109	.0709	.0747	1.2955	1.4083	1.4419
3	1.4517	.1086	.0716	.0747	1.3435	1.3923	1.4091
4	1.3916	.1097	.0905	.0754	1.3923	1.3599	1.3443
5	1.4403	.1478	.0905	.0943	1.4746	1.3757	1.3443
6	1.4723	.1829	.1494	.1132	1.4723	1.4723	.4572
7	1.5223	.2149	.1867	.1698	1.6324	1.8187	.5312
8	.2402	.1848	.1848	.1848	.128	.168	.0189
9	.1646	1.5043	2.1548	2.2874	.1109	.1663	.0189
10	.128	1.7166	2.3758	2.4577	.128	.1294	.0187
11	.1294	2.5692	2.5194	2.5926	.1646	.0934	.0732
12	.1109	2.7349	2.7681		.0914	.0724	.1075
13	.128	2.7035	2.6189	2.7199	.128	.0747	.1227
14	.1267	2.6216	2.7515	2.652	.1478	.0732	.12
15	.1097	2.4863	2.2939		.128	.1109	.1029
16	.0924	2.2939	2.1956	2.4577		.1097	.0995
17	.1097	.0857	.0709	.1097	.128	.1448	.1341
18	.128		.0716	.1267	.1307	.1109	.1402
19	.1478	.181	.1629	.1463	.1848	.1848	.1612
20	.1829	.1829	.1463	.1848	.1646	.1867	.1494
21	.2172	.1433	.128	.1829	.1294	.1494	.112
22	.1829	.1109	.112	1.3123	1.5074	1.3283	1.3123
23	.1663	.0905	.0747	1.3435	1.5729	1.2963	1.2803
24	1.4083	.1463	.0709	.0747	1.4403	1.4899	1.4746
Max	1.5223	2.7349	2.7681	2.7199	1.6324	1.8187	1.4746
Min	.0924	.0857	.0709	.0747	.0914	.0724	.0187
Avg	.5410	.9025	.8929	.8868	.7089	.6739	.5604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 204 / 11 KV KADEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	1.0402	.9877	1.1702	.1254	.1478	.112
2	.1494	.9717	.9568	1.1544	.1097	.1463	.1109
3	.1509	1.0159	.945	1.1544	.0924	.128	.1109
4	.1463	.9907	.945	1.1248	.0914	.1478	.112
5	.1663	1.0936	.945	1.0936	.1086	.1478	.112
6	.1848	1.1248	1.0623	1.0936	.1463	.1663	.1494
7	.2241	1.2803	1.5729	1.587	.1463	.2427	.1848
8	.2402	.1097	.181	.1848	.1478	.2218	.2172
9	1.5844	.1463	.1848	.1867	1.6004	1.8351	1.6004
10	1.8724	.1463	.181	.1663	1.8351	1.8515	1.8138
11	2.1792	.1294	.1494	.1463	2.1445	1.8351	1.9433
12	2.0805	.1478	.1663		2.2283	2.0119	1.9271
13	2.0481	.1463	.1463	.1267	2.1125	2.0119	1.9204
14	1.9845	.128	.1463	.128	2.2283	1.8778	1.9364
15	1.8023	.1254	.1463		2.1862	1.8564	1.7924
16	1.989	.128	.1448	.1097	1.9845	1.8564	1.7444
17	.1097	.12	.1772	.128	.1478	.1075	.1578
18	.1478	.1372	.1612	.1448	.1658	.1326	.1829
19	.1646	.1791	.1646	.1829	.1848	.1791	.2218
20	.1848	.1848	.1463	.2218	.1848	.1417	.1867
21	.1463	.1463	.1448	.2195	.2075	.1478	.168
22	.9602	1.1069	1.1405	.1848	.1867	.1494	.1494
23	1.065	1.0936	1.186	.1646	.1478	.1307	.1494
24	.1646	1.1271	.9877	1.1702	.1448	.1463	.112
Max	2.1792	1.2803	1.5729	1.587	2.2283	2.0119	1.9433
Min	.1097	.1097	.1448	.1097	.0914	.1075	.1109
Avg	.8289	.5341	.5404	.5383	.7774	.7342	.7131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 206 / 11 KV SHALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1829	.1829	.181	.2149	.2957	.2126
2	.1663	.1848	.1829	.1829	.1829	.2149	.2126
3	.168	.1646	.1848	.1829	.1478	.2012	.2103
4	.1886	.181	.1867	.2195	.1848	.2195	.2454
5	.2402	.2561	.2241	.2587	.3734	.2587	.2804
6	.3881	.4435	.4527	.4481	.5121	.4854	.4656
7	.6602	.5853	.6036	.6653	.6401	.6283	.695
8	.7392	.5544	.5544	.5853	.7023	.695	.6722
9	.5853	.4755	.5373	.5792	.4938	.4938	.543
10	.4656	.439	.3856	.4252	.4344	.3761	.3856
11	.4207	.3086	.3294	.3582	.3224	.3189	.3814
12	.3658	.3467	.3601		.2804	.2534	.3429
13	.2957	.2774	.3429	.2926	.2454	.2172	.3077
14	.2561	.2454	.3429	.2587	.2865	.2534	.2429
15	.2957	.2454	.3467		.2865	.2926	.2591
16	.3292	.2835	.3641	.2896	.2683	.2865	.3086
17	.3696	.2454	.3601	.3292	.2949	.2804	.3561
18	.439	.3772	.5014	.3696	.3353	.3429	.4161
19	.4755	.5373	.5853	.4755	.4755	.5121	.4733
20	.5544	.6154	.6219	.5792	.5359	.5487	.5373
21	.4755	.4481	.4805	.4656	.499	.4854	.4668
22	.4344	.3734	.4066	.4024	.4481	.4435	.4207
23	.3658	.2195	.2534	.3258	.3475	.3258	.3403
24	.1829	.2957	.1829	.2172	.2957	.333	.2507
Max	.7392	.6154	.6219	.6653	.7023	.695	.695
Min	.1663	.1646	.1829	.181	.1478	.2012	.2103
Avg	.3769	.3453	.3739	.3678	.3670	.3651	.3761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 207 / 11 KV KHAMBALE-A AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5581	.1063	.1109	.0934	1.1279	1.4575	1.5415
2	1.5729	.0876	.112	.0934	1.0936	1.4083	1.4746
3	1.4899	.0914		.0934	1.0105	1.3923	1.4419
4	1.4403	.0739	.1132	.112	1.0974	1.3763	1.4089
5	1.4403	.0914	.1132	.112	1.2163	1.4251	1.4089
6	1.5043	.1109	.1494	.112	1.3435	1.5546	1.4723
7	1.7204	.1463	.1509	.1509	1.4403	1.8023	1.7004
8	.1867	.128	.1848	.1494	.1463	.1478	.1448
9	.1886	1.9204	1.8564	1.9062	.1097	.1663	.1478
10	.1478	2.5149	2.0481	2.1548	.0724	.1294	.1109
11	.1478	2.4034	2.42	2.0317	.0934	.112	.112
12	.1646	2.2377	2.1548		.1478	.112	.112
13	.1448	2.13	2.1548	2.0885	.1109	.112	.1307
14	.1463	2.2119	1.7204	2.0317	.0914	.112	.1307
15	.1294	1.9062	1.8351		.1109	.0934	.112
16	.128	1.7004	1.9271	2.0719	.1307	.0934	.1097
17	.128	.124	.0934	.128	.128	.112	.1254
18	.1254	.1214	.112	.1267	.1294	.1109	.1097
19	.1402	.1448	.1509	.1463	.1463	.1307	.1494
20	.1595	.1463	.132	.1478	.1307	.1109	.1463
21	.1372		.132	.128	.132	.112	.1463
22	.124	.1307	.1132	.9831	1.5223	1.7204	1.4746
23	.1254	.1097	.1132	1.1561	1.5546	1.6549	1.5074
24	1.6057	.1086	.1109	.0934	1.1584	1.4575	1.6244
Max	1.7204	2.5149	2.42	2.1548	1.5546	1.8023	1.7004
Min	.124	.0739	.0934	.0934	.0724	.0934	.1097
Avg	.6107	.8151	.7830	.7323	.5935	.7043	.7018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 208 / 11 KV MIDC NO 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335	1.5947	1.1517	1.3957	1.3169	1.2071	1.086
2	1.4335	1.4403	1.1871	1.3957	1.086	1.2382	1.0387
3	1.3957	1.4373	1.1999	1.3957	1.1104	1.2752	1.0387
4	1.2883	1.4327	1.2536	1.4003	1.094	1.1949	1.0631
5	1.3014	1.3032	1.2536	1.4003	1.1576	1.2071	1.0631
6	1.3306	1.39	1.2803	1.4003	1.1273	1.262	1.0517
7	1.3203	1.4415	1.2803	1.358	1.2803	1.358	1.0631
8	.7293	1.4998	1.3575	1.5844	1.2197	.8215	1.0745
9	1.905	1.9909	1.1765	2.1691	1.848	.7537	1.2012
10	2.2257	2.3388	1.8861	1.6975	2.6217	.7362	1.6221
11	2.0748	1.8861	2.1125	1.9753	2.0182	.6401	1.5466
12	2.0485	2.5463	2.1691		2.2822		1.6598
13	2.0513	1.7918	1.9805	2.1719	2.1879		1.7353
14	2.1948	1.6975	1.6598	2.268	2.3954		1.7918
15	2.2916	2.3577	2.0748		2.1879		1.9616
16	2.3529	2.6406	2.1879	2.037	2.5652		2.0936
17	2.4143	2.0182	1.9805	1.9022	2.6217		2.0748
18	2.1948	2.2634	1.9616	1.7741	2.1879	.2256	1.6975
19	1.848	2.1691	1.9239	1.7375	2.0748	.2591	1.5466
20	1.9022	1.9805	1.8107	1.6461	1.9993	.3172	1.358
21	1.6289	1.4632	1.4335	1.5364	1.8107	1.0745	1.2826
22	1.7558	1.6804	1.6975	1.4784	1.5466	1.0745	1.773
23	1.7002	1.4937	1.3957	1.4266	1.5466	1.1403	2.2822
24	1.3957	1.6476	1.1517	1.3957	1.3756	1.251	1.086
Max	2.4143	2.6406	2.1879	2.268	2.6217	1.358	2.2822
Min	.7293	1.3032	1.1517	1.358	1.086	.2256	1.0387
Avg	1.7590	1.8127	1.6069	1.6612	1.7776	.9465	1.4663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 201 / 11 KV TONDOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5729	1.9662		.1478	
2		1.5729	1.9334		.1663	
3		1.5565	1.9006		.1646	
4		1.5912	1.8842		.1848	
5		1.5729	1.8842		.2402	
6		1.757	2.13		.3142	
7		2.1795			.4435	
8		.362	.3475		.4251	
9			.2926		3.4558	
10	3.4374	.2743		3.6214		2.9007
11	3.2653	.2743		3.8809		2.8841
12	3.0803	.2743		3.53		2.8841
13	3.315	.2926		2.7435		2.982
14	3.1161	.2743		2.8532		3.1161
15	3.083	.2926		2.8349		2.7854
16	2.7362	.2926		2.6337		2.4966
17	.2801	.3511		.3109		.2263
18	.2587	.3475		.3511		.2614
19	.3258	.3511		.3696		.2926
20	.3224	.3292		.3881		.2926
21	.2896	.3109		.3326		.2957
22	1.6057	2.0222		.2587		.2149
23	1.6057	1.9662		.2218		.2195
24	1.1022	1.5546	2.0153		.1663	
Max	3.4374	2.1795	2.13	3.8809	3.4558	3.1161
Min	.2587	.2743	.2926	.2218	.1478	.2149
Avg	1.8549	.9292	1.5949	1.7379	.5709	1.5609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 202 / 11 KV RAIGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2131	.1097	.1097	.1433	2.3148	2.2611	2.3655
2	2.2177	.0924	.1663	.1052	2.3405	2.2283	2.3045
3	2.2032	.1097	.1097	.1097	2.3487	2.1792	2.1195
4	2.1845	.1109	.1478	.1494	2.2805	2.13	2.079
5	2.3011	.1097	.128	.1886	2.2712	2.0809	2.0885
6	2.1795	.1463	.1463	.1791	2.1795	2.1792	2.146
7	2.3137	.1448		.2075	2.6282	2.556	2.2043
8	.1341	.2149	.1463	.1829	.1677	.1463	.1341
9	.1677		2.3266	2.0348	.1526	.128	.1696
10	.1658	2.5396		2.4272	.128	.1463	.1326
11	.2172	2.9656		2.4272	.1097	.1867	.1772
12	.2507	2.7199		2.2314	.0924	.1829	.2126
13	.2587	2.9165		2.1216	.1109	.1663	.2454
14	.2835	3.0148		2.2801	.128	.1463	.2481
15	.2804	2.4905		2.2634	.1463	.2427	.2481
16	.2507	2.4249		2.0287	.1463	.2195	.2561
17	.2481	.1147		.1677	.128	.2353	.2172
18	.2103	.1463		.1341	.1463	.2195	.2172
19	.2126	.1646		.2012	.1663	.1663	.2172
20	.1829	.1663		.1509	.1663	.168	.2149
21	.1478	.1463		.1448	.1463	.1509	.181
22	.1478	.1463		2.3777	2.0153	2.1098	2.079
23	.128	.128		2.2891	2.2775	2.2634	2.1216
24	2.1948	.1109	.1097	.1478	2.2801	2.2939	2.4272
Max	2.3137	3.0148	2.3266	2.4272	2.6282	2.556	2.4272
Min	.128	.0924	.1097	.1052	.0924	.128	.1326
Avg	.8789	.9232	.3767	1.0289	1.0363	1.0328	1.0336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 203 / 11 KV SOHOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3801	.4066	.4024	.3734	.5729	.4066	.3921
2	.3658	.3734	.3881	.3658	.5853	.4207	.3734
3	.362	.3734	.3841	.3506	.5792	.4066	.3841
4	.4572	.4066	.4066	.3982	.5731	.4251	.4525
5	.5487	.4481	.4066	.5014	.5611	.4435	.5014
6	.6068	.6413	.6653	.6653	.6697	.6653	.6335
7	.7011	.8299		.9431	.7316	.7762	.9431
8	.6485	.7167	.7577	.7164	.7316	.8871	.9335
9	.5373		.5729	.6036	.6468	.5729	.8488
10	.4024	.4938		.5201	.4805	.4572	.5975
11	.5121	.5544		.4572	.4805	.4525	.5014
12	.5316	.5304		.5544	.5544	.5487	.5731
13	.3189	.5487		.567	.4805	.5544	.5731
14	.4252	.4805		.4938	.4066	.4572	.5068
15	.4298	.4805		.4805	.5544	.4572	.5373
16	.4908	.5359		.4572	.5175	.4525	.5316
17	.5316	.5121		.5487	.5544	.6335	.5853
18	.5959	.5914		.5611	.6283	.5487	.6516
19	.7316	.7947		.7682	.8316	.8402	.8215
20	.8131	.8413		.8316	.8962	.8488	.7964
21	.7392	.7762		.8488	.7392	.7167	.7468
22	.5975	.5729		.5975	.6099	.5601	.5975
23	.4805	.4755		.5729	.499	.5281	.5175
24	.4024	.439	.4207	.394	.5975	.439	.4108
Max	.8131	.8413	.7577	.9431	.8962	.8871	.9431
Min	.3189	.3734	.3841	.3506	.4066	.4066	.3734
Avg	.5254	.5575	.4894	.5655	.6034	.5625	.6004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 204 / 11 KV UPALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	1.6385	2.0317	2.0687	.181	.1147	.1463
2	.1097	1.6385	1.9989	2.0119	.1829	.1147	.181
3	.1254	1.6575	1.917	2.0119	.1829	.1147	.2012
4	.1227	1.6385	1.8679	2.0317	.2402	.1311	.2172
5	.1063	1.6385	1.8023	2.1052	.2241	.1475	.2149
6	.1086	1.7532	1.9334	2.2542	.2241	.213	.2172
7	.2378	2.0481		2.3975	.2957	.2622	.2896
8	.2172	.1638	.1966	.2195	.2378	.2294	.2378
9	2.7149		.1638	.2241	2.6797	2.8182	2.8959
10	2.9007	.1475		.1991	2.6379	2.6686	3.2114
11	2.967	.1475		.2012	2.4577	2.9675	2.8509
12	2.4905	.1966		.2195	2.5724	3.2217	2.769
13	2.6543	.1802		.2378	2.4905	2.934	2.4413
14	2.5724	.1638		.2012	2.5232	2.7469	2.6052
15	2.7035	.1638		2.0119	2.6379	2.7831	2.6216
16	2.5888	.1802		.181	2.5724	2.5434	2.3594
17	.1311	.1966		.2012	.1311	.1907	.1966
18	.1311	.1966		.2218	.1802	.1928	.1966
19	.1802	.2294		.2378	.1802	.2686	.2294
20	.1802	.2294		.2402	.1966	.2896	.2294
21	.1638	.213		.2012	.1802	.2378	.213
22	1.6907	1.8842		.2033	.1638	.2172	.1638
23	1.6712	2.0809		.1829	.1475	.1629	.1311
24	.1086	1.6549	2.0972	2.0553	.1829	.1311	.1463
Max	2.967	2.0809	2.0972	2.3975	2.6797	3.2217	3.2114
Min	.1063	.1475	.1638	.181	.1311	.1147	.1311
Avg	1.1251	.8714	1.5565	.9217	.9876	1.0709	1.0403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 205 / 11 KV BOMBALEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2624	.0663	.0655	.1132	1.9605	1.8842	2.3211
2	2.0851	.0671	.0819	.1075	1.9022	1.9006	2.2786
3	2.1033	.0663	.0655	.1052	1.9022	1.8351	2.2192
4	2.1437	.0671	.0655	.1448	1.8461	1.8023	2.1776
5	2.2032	.0663	.0819	.1848	1.8473	1.7859	
6	2.0814	.116	.1147	.1829	1.8099	1.9334	2.191
7	2.3777			.2054	2.2314	2.2119	2.4272
8	.2033		.1475	.2033	.1991	.1475	.1646
9	.1646		2.3758	2.3266	.1646	.1311	.1267
10	.1663			2.3868	.1475	.0838	.116
11	.1658	2.3594		2.5149	.1802	.0848	.116
12	.1326	2.6379		2.3739	.1638	.12	.0995
13	.116	2.6871		2.2634	.1147	.1578	.116
14	.0995	2.4249		2.8921	.0983	.1433	.0995
15	.0995	2.4086		2.8349	.1311	.1448	.0995
16	.1326	2.3922		2.5072	.1311	.1463	.116
17	.116	.1147		.181	.1311	.1867	.1326
18	.116	.1475		.1463	.1311	.1646	.1492
19	.1326	.1638		.1629	.1475	.1646	.1658
20	.1326	.1802		.2103	.1475	.1478	.1658
21	.1492	.1475		.1848	.1311	.1463	.1492
22	.1006	.1147		2.1098	1.9662	2.2862	2.0885
23	.0838	.0819		2.0351	1.9826	2.4434	2.0222
24	2.3411	.0663	.0655	.112	1.9204	1.9334	2.364
Max	2.3777	2.6871	2.3758	2.8921	2.2314	2.4434	2.4272
Min	.0838	.0663	.0655	.1052	.0983	.0838	.0995
Avg	.8212	.8188	.3404	1.1037	.8911	.9161	.9524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 206 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.3734	.5359	.3772	.3734	.3696	.3841
2	.2743	.4481	.5544	.3658	.3881	.4066	.362
3	.2587	.5228	.5544	.3658	.4024	.5544	.3475
4	.2801	.5975	.6283	.4854	.4344	.5914	.3801
5	.2641	.6908	.6283	.5068	.439	.6468	.4024
6	.2743	.6722	.5359	.5544	.4527	.6099	.4706
7	.2743	.6722		.6584	.6722	.4066	.2865
8	.3292	.3547	.6653	.3841	.5544	.6283	.362
9	.6878		.7392	.8507	.3475	.7207	.8048
10	.6468	.7282		.8048	.3881	.2926	.4294
11	.6348	.9425		.499	.4251	.6283	.4668
12	.3921	.7577		.6036	.5359	.7095	.6535
13	.3921	.7762		.462	.3881	.6089	.6535
14	.6161	.9979		.6401	.5729	.6401	.6722
15	.5041	.7207		.6653	.3881	.6099	.4854
16	.112	.0739		.1646	.0554	.0366	.0934
24	.2103						
Max	.6878	.9979	.7392	.8507	.6722	.7207	.8048
Min	.112	.0739	.5359	.1646	.0554	.0366	.0934
Avg	.3778	.6219	.6052	.5243	.4261	.5288	.4534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 201 / 11 KV WANGI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	1.2452	1.2029	1.2308	.0886	.1097	.0848
2	.1029	1.2289	1.1717	1.2289	.0886	.0895	.0848
3	.1017	1.1633	1.1873	1.2452	.0876	.0895	.0838
4	.1017	1.1797	1.2186	1.2763	.0876	.1086	.0838
5	.1174	1.3435	1.2498	1.3094	.1387	.1063	.0838
6	.1844	1.3592	1.3123	1.3435	.2058	.1791	.116
7	.2321	1.5384	1.406	1.4091	.2347	.2614	.2155
8	.2155	.208	.2328	.2353	.1989	.2561	.2458
9	1.6204	.1612	.1791	.2012	1.5699	1.8564	1.6766
10	1.8122	.1433	.1433	.1991	1.9364	1.8724	1.821
11	1.9826	.1612	.1254	.181	1.9662	1.9204	1.8122
12	1.9334	.1433	.124	.1448	2.1136	1.9204	1.821
13	1.8399	.1433	.1612	.1646	1.9757	1.9044	1.8351
14	1.9662	.1612	.1772	.1646	1.9757	1.8884	1.7652
15	1.8896	.1433	.1772	.1848	1.9109	1.8404	1.6876
16	1.917	.1433	.1791	.1478	1.9334	1.8084	1.7328
17	.1052	.1612	.1463	.1848	.1433	.1357	.1646
18	.1006		.1463	.1646	.1612	.1543	.1326
19	.1526	.1791	.1991	.2378	.1829	.1715	.1629
20	.1372	.1791	.181	.2012	.197	.1543	.1463
21	.1372	.1612	.1646	.1448	.1433	.1372	.1629
22	1.3426	1.2651	1.2793	.1448	.128	.1029	.1097
23	1.3763	1.2651	1.2944	.1075	.128	.0857	.1086
24	.1029	1.3108	1.2186	1.2452	.1075	.1097	.0848
Max	1.9826	1.5384	1.406	1.4091	2.1136	1.9204	1.8351
Min	.1006	.1433	.124	.1075	.0876	.0857	.0838
Avg	.8156	.6516	.6199	.5457	.7376	.7193	.6759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 202 / 11 KV TADSAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	.2107	.2027	.1738	.9063	1.0288	
2	.9602	.1852	.1738	.1738	.8669	1.0002	
3	.9198	.1875	.1738	.1715	.8669	.9288	
4	.9198	.1562	.1882	.1858	.8535	.9179	
5	.9202	.25	.2172	.2027	.8676	.9596	
6	1.1469	.2656	.2896	.2317	1.0911	1.1138	
7	1.307	.2858	.362	.3121	1.2696	1.4769	
8	.3067	.3001	.333	.3269	.3001	.2961	
9	.3041	1.5493	1.3584	1.4118	.2896	.2896	
10	.2896	1.8679	1.5002		.2606	.3041	
11	.3163	1.6655	1.6204		.2715		.2298
12	.2778	1.7364	1.829		.2572	.2787	.2202
13	.2932	1.6065	1.7193		.2397	.2675	.2229
14	.2896	1.5002	1.7044		.2572	.2675	.2202
15	.3048	1.4529	1.7833		.2397		.3511
16	.3086	1.4293	1.6975		.2397	.3121	.2515
17	.3201	.2896	.2229	.2606	.2538	.3418	.1509
18	.2606	.3185	.2896		.3144	.3567	.161
19	.3185	.333	.3144	.2934	.3185	.3715	.2353
20	.2896	.3041	.3001	.2641	.2896	.2824	.2138
21	.2408	.3041	.2858	.2347	.2538	.2347	.2042
22	.2258	.2606	.2462	.9335	1.0856	1.1934	1.2308
23	.2258	.2172	.2	.9334	1.0574		1.2163
24	1.0014	.2107	.2172	.2	.9198	1.001	
Max	1.307	1.8679	1.829	1.4118	1.2696	1.4769	1.2308
Min	.2258	.1562	.1738	.1715	.2397	.2347	.1509
Avg	.5306	.7036	.7179	.3944	.5654	.6297	.3775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 203 / 11 KV YERALA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4531	.0732	.0537	.0716	.5335	.4588	.4784
2	.4321	.0934		.0895	.503	.4696	.463
3	.3086	.0934	.0716	.0886	.4725	.4961	.4268
4	.3201	.0934	.0895	.0709	.4515	.4961	.4115
5	.3353	.112	.1433	.1075	.4365	.4858	.4268
6	.3658	.1097	.156	.1086	.5268	.5121	.4877
7	.4515		.156	.124	.5647	.5937	.6097
8	.1966	.2149	.1907	.1949	.1638	.2149	.1966
9	.1802	.4961	.7202	.8596	.1341	.1612	.1475
10	.1492	.5121	.7682	.7865	.1187	.1463	.116
11	.1463	.5121	.7773	.8097	.1097	.0914	.1086
12	.1463	.4961	.8029	.8259	.1109	.128	.1097
13	.128	.5281	.7842	.8259	.112	.1294	.0905
14	.1097	.5601	.8002	.7773	.0934	.1294	
15	.1294	.7042	.8421	.7611	.112	.1109	.1075
16	.128	.8002	.8356	.8421		.1109	.1086
17	.1463	.104	.0972	.12	.1097	.0934	.0914
18	.1097	.104	.0819	.1372	.1254	.1307	.1097
19	.1075	.156	.1147	.1715	.168	.1478	.1086
20	.1254	.1387	.1267	.1372	.168	.1463	.1097
21	.1227	.104	.128	.12	.128	.1086	.1086
22	.0895	.0867	.0905	.571	.5533	.5312	.5853
23	.0895	.0693	.0732	.571	.5079	.5155	.4858
24	.4687	.0732	.0716	.0709	.5556	.5079	.4938
Max	.4687	.8002	.8421	.8596	.5647	.5937	.6097
Min	.0895	.0693	.0537	.0709	.0934	.0914	.0905
Avg	.2183	.2711	.3468	.3851	.2939	.2882	.2775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 204 / 11 KV AMBAK AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.7042	.7274	.7042	.0701	.081	.0509
2	.0678	.6401	.7116	.6483	.0693	.048	.0503
3	.0671	.5693	.6958	.7274	.0693	.048	.0503
4	.0671	.6081	.6958	.6882	.0686	.048	.0503
5	.0663	.7125	.7274	.6958	.0671	.064	.0497
6	.0829	.7042	.7432	.7274	.0829	.08	.0663
7	.1147	.7362	.7748	.7522	.0983	.1147	.0995
8	.0995	.1017	.1017	.096	.0829	.1134	.0829
9	.828	.1017	.0678	.0972	.7468	.9602	.8535
10	.8592	.1187	.0848	.1029	.8951	.9922	.9568
11	.9282	.0848	.0848	.0857	.9922		.9602
12	1.0242	.0848	.0671	.0867	1.0082	1.012	1.0031
13	1.0242	.1017	.1006	.1052	1.0322	.9922	.9842
14	1.0242	.1017	.0857	.1063		.9762	.9414
15	1.0402	.0848	.1017	.1075	.9602	.9762	1.0185
16	.9762	.1187	.1214	.1086	.9602	1.0202	
17	.096	.1187	.104	.1267	.0655	.0514	.0655
18	.112	.1187	.0857	.1267	.0819	.0867	.081
19	.112	.1187	.1029	.1254	.1147	.104	.0972
20	.096	.1017	.1029	.1254	.1147	.1029	.0983
21	.08	.1017	.104	.1075	.1147	.0857	.081
22	.7682	.759	.7748	.0886	.0819	.0686	.0995
23	.8002	.7907	.759	.0886	.0819	.0514	
24	.0686	.8002	.759	.7522	.0876	.0819	.0509
Max	1.0402	.8002	.7748	.7522	1.0322	1.0202	1.0185
Min	.0663	.0848	.0671	.0857	.0655	.048	.0497
Avg	.4363	.3534	.3618	.3075	.3455	.3547	.3542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 205 / 11 KV HINGANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8436	.1966	.1147	.1017	.9374	.9878	.9374
2	.828	.1638	.0983	.1187	.9105	.9717	.8951
3	.8025	.1638	.0983	.1006	.8951	.9069	.8796
4	.7716	.1802	.1147	.1187	.8796	.9069	.8642
5	.7773	.213	.1311	.1543	.9145	.9282	.8535
6	.945	.2214	.1638	.1886	1.0364	1.0437	1.0669
7	1.0974	.2688	.2458	.2254	1.1138	1.2163	1.2041
8	.2155	.2241	.2294	.2601	.2984	.2561	.2486
9	.2486		1.2037	1.5083	.2683	.2401	.2486
10	.2347	1.2643	1.3889	1.4548	.2374	.2294	
11	.208	1.5524	1.406	1.5203	.1943		.1966
12	.176	1.4083	1.543	1.6164	.1619	.2683	.1781
13	.2056	1.4403	1.4723	1.6004	.1781	.2713	.1966
14	.208	1.5364	1.5181	1.5844	.213	.2713	.2267
15		1.5364	1.5655	1.668	.213	.2743	.2926
16	.208	1.4243	1.5655	1.6194	.2294	.2601	.2267
17	.2401	.1638	.1696	.2035	.1966	.2454	.2105
18	.2241	.1802	.1543	.2058	.2458	.2454	.2294
19	.2401	.2294	.2035	.2401	.2785	.2804	.2591
20	.253	.213	.2058	.2401	.2622	.2629	.2458
21	.2401	.213	.2058	.2229	.2294	.2279	.2294
22	.208	.1638	.156	.9998	1.0242	1.0155	.9555
23	.208	.1311	.12	.9998	1.0562	.9842	.9231
24	.8749	.176	.1311	.1029	.9686	1.0402	.953
Max	1.0974	1.5524	1.5655	1.668	1.1138	1.2163	1.2041
Min	.176	.1311	.0983	.1006	.1619	.2279	.1781
Avg	.4460	.5767	.5919	.7106	.5393	.5798	.5444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 206 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1612	.1612	.1612	.1595	.1772	.1612
2	.1578	.1595	.1433	.1595	.1402	.1595	.1417
3	.1578	.1595	.1433	.1772	.1402	.1612	.1417
4	.156	.1772	.1612	.1595	.1387	.1433	.1402
5	.208	.2328	.1791	.2149	.2229	.2149	.1402
6	.4287	.3761	.3121	.3224	.3944	.394	.2601
7	.5256	.5194	.4854	.4784	.503	.5014	.4334
8	.4748	.4298	.4508	.5194	.4359	.4835	.4458
9	.3086	.3403	.3814	.4656	.4191	.394	.3258
10		.3224	.3403	.3403	.2883	.3582	.2947
11	.2328	.2507	.3224	.3403	.2865		.2686
12	.2865		.3189	.2353	.2658	.3258	.2686
13	.1791	.1433	.3045	.2561	.197	.3077	.2507
14	.197	.2507	.3045	.2561	.2686	.3077	.2328
15	.2126	.2507	.2865	.2957	.3045	.3292	.2507
16	.2686	.2507	.3045	.3142	.2896	.2378	.2686
17	.3189	.2686	.3012	.3142	.3045	.2743	.3439
18	.3761	.2865	.3403	.3109	.3189	.2378	.3292
19	.4298	.4298	.4119	.4024	.4119	.4572	.4477
20	.4656	.4119	.3582	.3658	.4656	.4163	.4607
21	.3582	.3582	.3366	.3258	.4252	.3801	.394
22	.2686	.2686	.2865	.2534	.2686	.3077	.3012
23	.2328	.197	.197	.197	.2328	.2149	.2686
24	.1772	.197	.1791	.1791	.1791	.2328	.1612
Max	.5256	.5194	.4854	.5194	.503	.5014	.4607
Min	.156	.1433	.1433	.1595	.1387	.1433	.1402
Avg	.2869	.2801	.2921	.2935	.2942	.3051	.2805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 201 / 11KV BHIKWADI-KH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2218	.2012	.2033	.1867	.1848	.2427
2	.168	.2033	.1829	.1867	.1886	.1848	.1867
3	.1698	.2033	.2402	.1848	.1886	.1848	.2772
4	.1646	.2033	.3109	.2241	.2054	.2033	.3881
5	.168	.2033	.462	.4435	.2263	.2402	.499
6	.3395	.3142	.5121	.5228	.4715	.3511	.5544
7	.6224	.5175	.6036	.6099	.5975	.5729	.6036
8		.5544	.567	.6722	.5788	.6283	.6036
9	.5658	.4435	.5359	.5175		.5359	.5544
10	.5228	.5729	.4108	.462	.5658		.5175
11	.5415	.3174	.4435	.3921	.3511	.4024	.3734
12	.4108	.3326	.4805	.1886	.4805	.3658	.3326
13	.4294	.3658	.3921	.168	.3696	.3658	.4119
14	.2987	.4251	.3439	.2075	.3142	.4251	.2926
15	.5041	.4805	.3696	.3734	.3696	.3841	.2353
16	.4066	.3475	.5415	.3961	.4066	.4251	.3511
17	.4435	.4251	.3696	.4668	.5175	.4024	.3734
18	.462	.4938	.5041	.4338	.4435	.3881	.4108
19	.6283	.4805	.5914	.5228	.7023	.4066	.6653
20	.6283	.462	.6535	.4904	.6099	.4207	.5544
21	.499	.462	.5729		.5359	.5175	.4668
22	.3696	.3174	.3801	.3395	.4251	.3841	.3326
23	.2402	.2427	.2926	.2801	.2772	.3109	.2054
24	.3734	.2218	.1867	.2218	.1886	.2218	.2033
Max	.6283	.5729	.6535	.6722	.7023	.6283	.6653
Min	.1646	.2033	.1829	.168	.1867	.1848	.1867
Avg	.3976	.3672	.4229	.3699	.4000	.3698	.4015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 202 / 11 KV NEWARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	1.9559	2.0645	2.0119	.2241	.1848	.1663
2	.1867	1.9062	2.13	1.9725	.2241	.1848	.1494
3	.1867	1.9062	2.0719	1.9662	.2263	.1848	
4	.2075	1.9227	2.1051	2.0222	.2452	.1848	.1478
5	.2241	1.873	2.2611	2.079	.2614	.1848	.2402
6	.2452	1.989	2.3205	2.0481	.2829	.1848	.2772
7	.2641	2.1628	2.3537	2.1776	.2987	.2402	.2801
8	.2801	.1867	.1791	.1629	.2614	.2402	.2957
9	2.5446	.2614	.2218	.2686	2.3922	2.3537	2.8673
10	2.9492	.2926	.2378	.2534	2.7206	2.7018	2.9504
11	2.9473	.2987	.2534	.2896	3.0769	2.9492	2.9005
12	2.672	.3174	.2507	.3174	2.9473	2.9473	3.1878
13	1.749	.2987		.3018	1.442	2.9329	3.0521
14	2.915	.2801		.2987	2.6558		3.1161
15	2.915	.2957		.3395	2.6558	3.083	2.9492
16	2.4939	.2987		.3395	2.5911	3.1093	2.9908
17	.1619	.2218	.2172		.2561	.2353	.2534
18	.2012	.1663	.2743	.3206	.2402	.2195	.2896
19	.2772	.1867	.2587	.3395	.2218	.2402	.2865
20	.2587	.168	.2195	.3361	.2033	.2587	.2715
21	.2218	.1867	.181		.1848	.2801	.2353
22	1.989	2.0719	2.0748	.3018	.1848	.1463	.2378
23	2.0222	2.0567	2.0919		.1848	.1478	.2172
24	.3772	1.989	2.0317	2.0056	.2241	.1848	.1478
Max	2.9492	2.1628	2.3537	2.1776	3.0769	3.1093	3.1878
Min	.1619	.1663	.1791	.1629	.1848	.1463	.1478
Avg	1.1866	.9705	1.1899	.9596	1.0086	1.0165	1.1961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 203 / 11 KV DHANEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7764	.168		.1267	1.5729	1.7833	2.0481
2	1.7185	.168	.2427	.128	1.5384	1.7101	2.0809
3	1.7394	.168	.2218	.1254	1.5565	1.7604	2.251
4	1.7497	.1867	.2801	.1448	1.6244	1.7604	2.0567
5	1.9109	.1867	.2957	.1829	1.6385	1.7772	2.2834
6	2.1136	.2614	.2743	.2534	1.7284	1.8107	2.5069
7	2.1872	.3361	.3142	.3155	2.2611	2.1795	2.5396
8	.2688	.3142	.2896	.3224	.2987	.3174	.2374
9	.2241	2.6326		3.095	.1867	.2427	.2103
10	.2241	2.7664	3.0333	3.4208	.1886	.168	.1715
11	.1867	2.8837	3.0521	2.955	.1867	.1494	.181
12	.1867	2.982	2.9508	2.878	.1867	.1326	.1791
13	.2218	2.9984	2.8509	2.6235	.168	.168	.181
14	.2218	2.8837	2.8178	2.7027	.1663	.1867	.1791
15	.1848	2.8344	2.556	2.6235	.1663	.1867	.1629
16	.2218	2.7515		2.4352	.1663		.181
17	.2587	.1791	.1463	.1867	.1848	.2195	.2012
18	.2218	.2172	.1991	.2075	.1848	.2054	.2328
19	.3174	.1829	.2353	.2263	.2033	.1867	.2534
20	.3142	.1991	.2743	.2427	.2218	.2427	.2353
21	.2772	.2012	.2534		.2218	.1848	.2172
22	.2054	.1663	.1791	1.5684	1.7147	1.917	1.989
23	.168	.1478	.1448	1.8351	1.749	2.0719	1.9376
24	3.6374	.168	.1307	.1294	1.5364	1.7833	2.0553
Max	3.6374	2.9984	3.0521	3.4208	2.2611	2.1795	2.5396
Min	.168	.1478	.1307	.1254	.1663	.1326	.1629
Avg	.8557	1.0826	.9877	1.2491	.8188	.9193	1.0238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 204 / 11 KV YETGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2452	.0972	.1307	.1097	1.3279	1.5061	1.4746
2	1.2003	.0972	.1109	.0905	1.3272	1.5061	1.4752
3	1.2146	.0972	.168	.0914	1.2803	1.5384	1.5074
4	1.3108	.0972	.1463	.1267	1.3108	1.5384	1.5083
5	1.5746	.1134	.1848	.1463	1.5023	1.5384	1.6907
6	1.7284	.1134	.2218	.181	1.6248	1.5384	1.8023
7	1.8501	.1619	.2033	.2012	1.8724	1.8947	1.8138
8	.1867	.1619	.2054	.2149	.1867	.1943	.1949
9	.1867	1.8623	2.17	2.2081	.1886	.1658	.1478
10	.1509	2.2834	2.4905	2.3282	.1307	.1492	.128
11	.0983	2.4034	2.572	2.6578	.1134	.1357	.1086
12	.1134	2.4413	2.5549	2.3685	.0972	.1187	.1254
13	.1457	2.2283	2.4348	2.2297	.0972	.1417	.1086
14	.1134	2.2377	2.3834	2.3845	.1134	.1646	.0895
15	.1134	2.2611	2.1548	2.2939	.0972	.168	.1086
16	.116	2.2542	1.9204	1.9204	.0972	.168	.1086
17	.1457	.1109	.0914	.112	.116	.1494	.1267
18	.0972	.1307	.1294	.1509	.0995	.168	.1448
19	.1943	.1494	.1663	.168	.1943	.1848	.197
20	.1943	.1663	.2033	.1867	.1619	.2033	.181
21	.1781	.1867	.1867		.1781	.1848	.181
22	.1457	.1109	.1478	1.2289	1.3603	1.442	1.3032
23	.0972	.1109	.1097	1.3123	1.4899	1.4091	1.406
24	1.2763	.0972	.112	.1086	1.3435	1.5061	1.4419
Max	1.8501	2.4413	2.572	2.6578	1.8724	1.8947	1.8138
Min	.0972	.0972	.0914	.0905	.0972	.1187	.0895
Avg	.5699	.8323	.8833	.9922	.6796	.7381	.7239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 205 / 11 KV TUPEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.0486	.0934	.0724	.4752	.5182	.547
2	.3734	.0486	.0747	.0716	.4696	.502	.5636
3	.3961	.0486	.0934	.0905	.4588	.4858	.5304
4	.3841	.0486	.0747	.0895	.4481	.502	.5636
5	.4481	.0486	.0747	.0895	.4915	.502	.4973
6	.4715	.0324	.0747	.0905	.5735	.502	.5304
7	.426	.0324	.0943	.0905	.5761	.5992	.57
8	.0829	.0648	.112	.0914	.0819	.0648	.0747
9	.112	.421	.6687	.6805	.0373	.0648	.056
10	.0943	.5668	.6554	.6859	.0566	.0648	.056
11	.0648	.6299	.7127	.6783	.0486	.0732	.0739
12	.081	.6554	.8048	.6722	.0648	.0739	.0543
13	.0648	.7045	.78	.703	.0648	.0747	.0716
14	.0972	.6882	.7969	.7116	.0648	.0747	.0724
15	.1134	.6554	.7545	.7045	.081	.0747	.0724
16	.0972		.7202	.68	.0972	.0747	.0905
17	.0972	.0671	.0716	.056	.0972	.0747	.0716
18	.081	.0838	.1086	.0943	.0972	.0747	.0543
19	.0648	.0857	.1267	.0934	.081	.0747	.0895
20	.0648	.0724	.1254	.0943	.081	.0747	.0724
21	.081	.0914	.1097			.0747	.0543
22	.0486	.0747	.0895	.4668	.4696	.5426	.5144
23	.0486	.0747	.0724	.4588	.5506	.5304	.5609
24	.3734	.0497	.0747	.0724	.4641	.5182	.5304
Max	.4715	.7045	.8048	.7116	.5761	.5992	.57
Min	.0486	.0324	.0716	.056	.0373	.0648	.0543
Avg	.1893	.2301	.3068	.3277	.2578	.2590	.2655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 206 / 11 KV YERALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	1.2955	1.5238	1.5261	.0943	.0648	.0934
2	.0566	1.2308	1.5565	1.6289	.0934	.0648	.0934
3	.0566	1.2146	1.5912	1.6297	.0943	.0648	.0934
4	.0377	1.2146	1.5893	1.6126	.0934	.0648	.0747
5	.0566	1.1984	1.5912	1.6804	.1132	.0648	.112
6	.056	1.2955	1.5893	1.6804	.112	.0648	.112
7	.056	1.3603	1.6057	1.7147	.112	.0972	.112
8	.0566	.0486	.112	.1086	.0943	.0648	.1307
9	1.6324	.0663	.1478	.1267	1.5402	1.749	
10	1.8023	.0972	.1307	.1075	1.7604	1.9433	
11	1.8138	.0914	.1109	.1267	1.9559	1.9989	
12	1.8138	.0914	.0924	.1307	1.8785		2.4025
13	1.8785	.1294	.0924	.1509	1.8623	2.0388	2.2291
14	1.668	.112	.0934	.112	1.9109	1.9498	2.1434
15	1.7652	.112	.1086	.0943	1.8947	2.0056	2.1262
16	1.6842	.0924	.0905	.1307	1.8623	1.9989	1.9033
17	.0324	.112		.1132	.0648	.1109	.0905
18	.0486	.1307	.1267	.112	.0972	.128	.0914
19	.0648	.1307	.1448	.1132	.1296	.112	.1086
20	.0486	.112	.1463	.1132	.1296	.128	.0905
21	.0486	.0934	.128		.1134	.128	.0895
22	1.2955	1.4899	1.5775	.0934	.0972	.1307	.0905
23	1.2955	1.4746	1.749	.0943	.0648	.0934	.0716
24	.0566	1.2955	1.5249	1.5424	.0934	.0648	.0934
Max	1.8785	1.4899	1.749	1.7147	1.9559	2.0388	2.4025
Min	.0324	.0486	.0905	.0934	.0648	.0648	.0716
Avg	.7242	.6037	.7575	.6410	.6776	.6579	.5882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 201 / 11 KV SHIVANI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.656	.0693		.0572		1.8818	1.7924
2	1.6049	.0686		.0579	1.8461	1.8435	1.7924
3	1.5741	.0686		.0602	1.8244	1.8122	1.7924
4	1.5741	.0617		.0753	1.866	1.8122	1.7394
5	1.5935	.0693		.0743	1.9044	1.8278	1.7553
6	1.5935	.0886		.1006	1.9433	1.8747	2.0165
7	1.7497	.1387		.1187	2.0729	1.9766	2.0729
8	.1341	.1526		.1147	.0857	.0995	.1054
9	.0743			2.4939	.0914	.088	.0781
10				2.6397	.0772		.0819
11				2.982	.0657	.0625	.0518
12					.0541	.0549	.0518
13					.0743	.0549	.0434
14				3.0312	.0657	.0564	.0404
15				3.0312	.0714	.0419	.0572
16			2.8673	2.8664	.0846	.0419	
17			.0743	.0857	.0869	.0518	.0629
18			.1027	.088	.0846	.0591	.072
19			.1054	.0903	.0743	.0903	.0846
20	.1027		.0914	.1067	.0753	.0903	.0834
21	.0983		.0914	.0846	.0734	.0695	.0869
22	.0838		.0914	2.0325	1.8818		1.6091
23	.0848		.0686	2.0805	1.9134	1.7924	1.7394
24	1.6872	.0686		.0705	2.0567	1.8976	1.8084
Max	1.7497	.1526	2.8673	3.0312	2.0729	1.9766	2.0729
Min	.0743	.0617	.0686	.0572	.0541	.0419	.0404
Avg	.9722	.0873	.4366	1.0156	.7989	.7991	.8269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 202 / 11 KV HANMANTWADIYE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	1.4089	1.5223	1.3599	.0701	.0497	.0895
2	.0709	1.3108	1.5223	1.3435	.0701	.0509	.0895
3	.0716	1.2955	1.7193	1.3279	.0686	.0509	.0895
4	.0724	1.4083	1.4746	1.3435	.0693	.0671	.0876
5	.0914	1.4575	1.4403	1.3279	.0914	.0663	.0867
6	.1097	1.587	1.4563	1.4074	.0867	.0886	.1097
7	.1433	1.6484	1.8233	1.8983	.1294	.1075	.1448
8	.1448	.1417	.2543	.1097	.1254	.1267	.1417
9	1.7764	.1433	2.2708	.0905	1.6484	2.0891	1.9044
10		.1267	2.7044	.0895	2.1628		2.2611
11		.1267	2.7854	.0924	2.1538	2.4036	2.1538
12		.1063	2.8837		2.2939	2.6686	2.251
13		.1063			2.0729	2.4531	2.2024
14		.0983		.0905	2.1214	2.2348	2.17
15		.124		.0876	2.3594	2.1715	2.0325
16		.0886	.1387	.104	2.1862	2.1445	2.0062
17			.1433	.1174	.0781	.1017	.0734
18	1.9757	.1957	.124	.1187	.0937	.116	.1017
19	2.0153	2.1214	.124	.1254	.1214	.124	.124
20	.124	.1981	.1254	.1214	.1052	.124	.1174
21	.1214	.1981	.1063	.0857	.0876	.1227	.0995
22	1.587	1.4373	1.3757	.0686	.0678	.0867	.0829
23	1.5546	1.5023	1.4074	.0686	.0663	.0905	.0838
24	.0686	1.4746	1.5546	1.3916	.0693	.0503	.0905
Max	2.0153	2.1214	2.8837	1.8983	2.3594	2.6686	2.2611
Min	.0686	.0886	.1063	.0686	.0663	.0497	.0734
Avg	.6248	.7959	1.2836	.5805	.7666	.7647	.7747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 203 / 11 KV SHIVANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.2804	.499	.3326	.3189	.2957	.4525
2	.3326	.2865	.3881	.3174	.298	.2957	.4108
3	.3361	.2957	.3881	.3174	.3045	.2926	.4108
4	.3395	.3326	.499	.3109	.3077	.3258	.4108
5	.4527		.5304	.3801	.4024	.394	
6	.5975	.6161	.5975	.5487	.4805	.5729	.7468
7	.8316	.8131	.7842	.8131	.7392	.7577	.7655
8	.7392	.823	.7316	.7783	.695	.6767	.7087
9	.6447	.7619	.6154	.6878	.4961	.6836	.6447
10		.5609	.6274	.6415	.4973		.5959
11		.724	.6104	.5256	.4372	.5729	
12		.6535	.5935		.3856	.57	.5487
13		.5487			.3258	.5014	.4748
14		.5194		.5959	.3467	.4298	.4207
15		.5552		.5493	.3294	.4805	.4334
16		.5359	.703	.6024	.3601	.5194	.4334
17			.6068	.6415	.3944	.5194	.5316
18	.815	.6241	.6036	.6485	.4862	.5373	.5895
19	.924	.7164	.7682	.8145	.6626	.7059	.724
20	.8962	.7023	.724	.6626	.6805	.7133	.7499
21	.7701	.6283	.7059	.6626	.5973	.6024	.6219
22	.6584	.5853	.543		.4525		.4805
23	.4435	.439	.4525	.3658	.3841	.4525	.3841
24	.3658	.3734	.439	.3658	.3582	.3475	.4525
Max	.924	.823	.7842	.8145	.7392	.7577	.7655
Min	.3292	.2804	.3881	.3109	.298	.2926	.3841
Avg	.5923	.5625	.5910	.5506	.4475	.5112	.5451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 400 / STATION TRANSFORMER

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 401 / 33 KV SHIRSGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	4.6639
Max	4.6639
Min	4.6639
Avg	4.6639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 406 / 33 KV ACORN-I (Wind Mill) NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / OUTGOING

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 407 / 33 KV WANGI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	5.1583
Max	5.1583
Min	5.1583
Avg	5.1583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 410 / 33 KV SHIVANI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	4.8834
Max	4.8834
Min	4.8834
Avg	4.8834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 411 / 33 KV BHIKWADI (KH.)

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	5.8213
Max	5.8213
Min	5.8213
Avg	5.8213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248016 / 220/132/33 KV WANGI

SUBSTATION

Feeder No / Name : 412 / 33 KV BELAWADE S/STN I/C NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / INCOMING

(NON CONTINUOUS PROCESS) (NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	4.4239
Max	4.4239
Min	4.4239
Avg	4.4239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 201 / 11 KV VITA(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	.961	1.0185	1.0562	1.0288	1.0185	.8383
2	1.0288	.9979	.9568	.9808	.9526	.9431	.8002
3	1.0288	.9979	.9511	.9526	.9145	.9431	.7922
4	.9526	1.0719	.9145	1.0669	.8383	.9054	.8676
5	1.105	1.1458	1.0562	1.1812	1.0288	1.105	.9526
6	1.2955	1.2567	1.2826	1.2449	1.2574	1.2193	1.2193
7	1.6004	1.5524	1.5089	1.3957	1.5623	1.448	1.3717
8	1.7924	1.7372	1.7353	1.6804	1.6804	1.6804	1.7924
9	1.7372	1.6461	1.7372	1.7372	1.8111	1.4712	1.7741
10	1.7741	1.7558	1.6827	1.7193	1.7013	1.2193	1.7924
11	1.7741	1.8461	1.7737	1.7193	1.7193	1.3957	1.6827
12	1.5893	1.6263	1.5203	1.4415	1.5927	1.1317	1.4415
13	1.5524	1.39	1.5364	1.2936	1.4842	1.3203	1.3676
14	1.6095	1.6095	1.5364	1.5364	1.5947	1.2696	1.6095
15	1.7193	1.6118	1.6289	1.6095	1.701	1.307	1.6834
16	1.6827	1.6118	1.5927	1.4632	1.5402	1.3203	1.6118
17	1.8656	1.7551	1.829	1.576	1.5729	.9431	1.7193
18	1.7372	1.829	1.6263	1.5565	1.6461	1.2449	1.7924
19	2.1285	2.0698	1.9791	1.922	2.0698	1.6975	1.9753
20	1.9387	1.9418	1.8298	1.848	1.9589	1.6221	1.8671
21	1.4998	1.5466	1.4712	1.4937	1.5089	1.4712	1.4861
22	1.3306	1.3203	1.3817	1.2574	1.3203	1.2193	1.3717
23	1.2197	1.2696	1.2696	1.2193	1.2449	.9907	1.1812
24	1.105	1.0719	1.1203	1.094	1.0669	1.094	.8383
Max	2.1285	2.0698	1.9791	1.922	2.0698	1.6975	1.9753
Min	.9526	.961	.9145	.9526	.8383	.9054	.7922
Avg	1.5072	1.4843	1.4558	1.4186	1.4498	1.2492	1.4095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 202 / 11 KV LENGARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.0829	1.0456	1.1088	1.2955	1.1706	.7621
2	1.2193	1.1458	1.134	1.0349	1.2193	1.1458	.724
3	1.1431	1.1088	1.0349	.9877	1.1431	1.1458	.724
4	1.0288	1.094	.9808	1.0829	1.0288	.9526	.7621
5	1.105	1.1317	1.1203	1.1576	1.105	.9907	.8002
6	1.1431	1.1694	1.2071	1.1949	1.1812	.9907	.8764
7	1.3717	1.2826	1.2449	1.1694	1.2955	.9907	.9526
8	1.4415	1.5524	1.5364	1.5565	1.5364	.9526	1.3203
9	1.6095	1.6289	1.5927	1.6118	1.6476	.8764	1.39
10	1.7528	1.7528	1.7684	1.6301	1.749	.8383	1.5257
11	1.7635	1.6991	1.7635	1.6991	1.9022	.8002	1.595
12	1.1458	1.2696	1.2437	1.0669	1.2197	.8764	1.0974
13	1.3394	1.0829	1.2567	1.1203	1.1584		1.094
14	1.7147	1.6461	1.6804	1.6617	1.6278		1.491
15	1.749	1.7177	1.7635	1.6804	1.643	.8764	1.5604
16	1.4883	1.4723	1.4175	1.4373	1.3672	.8383	1.4175
17	1.5424	1.5257	1.6126	1.6297	1.5074		1.4685
18	1.382	1.576	1.4118	1.3253	1.4175	.9145	1.39
19	1.6476	1.6655	1.5565	1.6118	1.6301	.9145	1.4415
20	1.448	1.4784	1.4415	1.4632	1.4842	.9526	1.3676
21	1.0288	1.0288	.9907	1.0669	1.105	.9145	.9526
22	1.39	1.3169	1.2574	1.2955	1.4045	.8764	1.3336
23	1.3394	1.3969	1.3394	1.448	1.4327	.8002	1.2193
24	1.3336	1.1827	1.3306	1.0456	1.3717	1.2936	.7621
Max	1.7635	1.7528	1.7684	1.6991	1.9022	1.2936	1.595
Min	1.0288	1.0288	.9808	.9877	1.0288	.8002	.724
Avg	1.3894	1.3753	1.3638	1.3369	1.3947	.9577	1.1678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 203 / 11 KV BHALWANI(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935	.6882	.7293	.0144	.8669	.6706	.6089
2	.6935	.6299	.7209	.7209	.8669	.6371	.5853
3	.6935	.5967	.7122	.6783	.8322	.6371	.5853
4	.6241	.6443	.6447	.7202	.7628	.6173	.6283
5	.7282	.7282	.7164	.7545	.8322	.6661	.6653
6	.7975	.7975	.8505	.7461	.9362	.7087	.7023
7	.8596	.8505	1.0277	.9362	1.0056	.8779	.7316
8	1.0056	1.166	1.1401	1.1317	1.0174	.9709	.9922
9	1.1317	1.073	1.2266	1.2407	1.094	.8669	1.0174
10	1.1271	1.004	1.2308	1.2929	1.2163	.631	.9998
11		1.1069	1.2334	1.2597	1.2193	.8048	1.012
12	1.0437	1.0437	1.0936	1.1843	1.0837	.78	1.0059
13	.9922	.8192	.6882	.9831	.8124	.8139	.8951
14	.9998	.9488	1.0753	1.0688	1.0059	.7545	.9602
15	1.0437	.9755	1.1702	1.1069	1.0802	.78	1.0311
16	1.0883	.9998	1.1561	1.142	1.1138	.8139	1.0185
17	1.1385	.9877	1.2483	1.2483	1.1385	.8573	1.1523
18	1.0185	1.0513	1.1069	1.0802	1.0311	.8764	.9393
19	1.1191	1.1065	1.2407	1.1271	1.094	.8764	1.0174
20	1.0059	1.0513	1.1271	.9156	1.0395	.8859	.8817
21	.9259	.8817	.9389	.9054	.8669	.788	.823
22	.7888	.8573	.9054	.8817	.9259	.7964	.6935
23	.7956	.9054	.8619	.8322	.8139	.7164	.6588
24	.6935	.6962	.7625	.7449	.8669	.7377	.6089
Max	1.1385	1.166	1.2483	1.2929	1.2193	.9709	1.1523
Min	.6241	.5967	.6447	.0144	.7628	.6173	.5853
Avg	.9134	.9004	.9837	.9465	.9801	.7736	.8423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 204 / 11 KV PARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.9671	.9922		1.1462	.9412	.543
2	.8954	1.0056	.9816	.9671	1.0745	1.0387	.5121
3	.8596	.9015	.9313	.9145	.9671	.9922	.5175
4	.788	1.0242	.8962	.8779	.8954	.8954	.5544
5	.8596	1.1088	1.0082	.9511	.9671	.8596	.7095
6	1.0029	1.0974	1.1458	1.0242	1.0277	.7796	.788
7	1.0985	1.3169	1.2803	1.2437	1.2437	.905	.9145
8	1.4175	1.4373	1.5424	1.5592	1.4217	.5487	1.1443
9	1.4217	1.5257	1.5604	1.5257	1.491	.8505	1.3611
10	1.5261	1.5089	1.4754	1.56	1.5074	.5014	1.4255
11	1.5043	1.4586	1.5074	1.4723	1.576	.9145	1.3923
12	1.0166	1.2346	1.1317	1.0387	1.0056	.2195	1.0852
13	1.0974	1.0517	.9816	.9671	.7186		1.1096
14	1.326	1.3375	1.2597	1.4419	1.2631		1.1797
15	1.3923	1.4419	1.4419	1.4091	1.3123	.5121	1.2308
16	1.326	1.4746	1.3592	1.326	1.2955	.5959	1.2125
17	1.4586	1.4251	1.4419	1.4419	1.3923	.6805	1.326
18	1.3108	1.4419	1.3375	1.3763	1.2266	.7682	1.3077
19	1.491	1.5089	1.595	1.5257	1.5261	.8764	1.387
20	1.4022	1.3672	1.2894	1.3523	1.387	.8413	1.3112
21	1.0719	1.0719	1.0719	1.0719	1.1458	.7602	1.0082
22	1.2048	1.1584	1.134	1.2178	1.1584	.724	1.182
23	1.1568	1.134	1.1568	1.2536	1.1568	.6089	1.182
24	.9313	1.0166	1.0867	1.0631	1.182	1.0985	.543
Max	1.5261	1.5257	1.595	1.56	1.576	1.0985	1.4255
Min	.788	.9015	.8962	.8779	.7186	.2195	.5121
Avg	1.1856	1.2507	1.2337	1.2427	1.2120	.7687	1.0386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083] BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 402 / 33kv NEW VITA

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-FEB-18
HR	Load (MW)
24	2.4926
Max	2.4926
Min	2.4926
Avg	2.4926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 403 / 33KV NAGEVADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6863	1.9982	2.1845	2.2085	3.2236	3.2047	3.0498
2	2.6863	1.7878	2.1325	2.1033	3.2236	2.8669	2.9447
3	2.6863	1.893	2.2028	2.3137	3.2236	2.6155	3.0087
4	2.6863	2.1033	2.3594	2.524	3.2236	2.5434	3.7609
5	2.6863	2.4188	2.7435	2.7343	3.2236	2.9321	4.7325
6	3.2236	2.524	3.7529	2.9447	3.7609	3.3436	4.9429
7	4.369	3.4705	4.0175	3.786	4.6811	4.7325	5.4092
8	1.7684	1.7878	1.6632	1.893	2.0805	1.3432	1.6632
9	3.6408	5.4801	5.715	6.2414	3.6008	3.9529	4.161
10	3.9529	6.3295	6.3375	7.8018	4.3244	3.6808	4.161
11	3.7334	7.2994	5.6584	7.2017	4.6091	4.5182	4.161
12	4.2067	8.3745	4.7531	3.6408	4.6639	4.1244	4.161
13	4.7325	8.3179	4.6399	5.6584	4.3896	4.1747	4.161
14	3.9963	8.035	6.9136	3.1207	4.2798	3.9232	3.6408
15	4.5222	7.5823	7.7915	5.6584	4.1027	3.866	3.6008
16	3.8912	4.5833	6.9136	5.2012	4.0472	3.7643	3.6408
17	1.7878	2.3388	1.4266	1.7684	1.2489	1.1643	1.3523
18	1.5775	2.0165	2.4143	1.749	1.382	1.4266	1.5604
19	1.893	2.3594	2.7435	2.2885	1.7558	1.7541	1.5604
20	2.4188	1.7187	1.6461	1.8267	1.8107	1.6244	1.5604
21	1.4723	1.5364	1.4266	1.8267	1.6461	1.8296	1.3969
22	2.2085	2.5766	2.4143	3.7609	3.5888	3.2407	3.2236
23	1.893	2.3405	2.524	3.2236	3.5608	3.1539	3.2236
24	2.5789	1.7878	2.3926	2.524	3.2236	3.2556	3.0864
Max	4.7325	8.3745	7.7915	7.8018	4.6811	4.7325	5.4092
Min	1.4723	1.5364	1.4266	1.749	1.2489	1.1643	1.3523
Avg	2.9708	3.7775	3.6153	3.5000	3.2864	3.0432	3.2568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 201 / 11 KV ALSAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0926	.1494	1.6057	1.3916	1.1385	.1387	.096
2	.0926	.1494	1.5729	1.3441	1.078	.1387	.096
3	.0926	.1494	1.5402	1.3441	1.0467	.1387	.096
4	.096	.1417	1.5223	1.2967	1.0311	.1387	.096
5	.1174	.1417	1.1984	1.2651	1.0311	.1433	
6	.116	.1417	1.5708	1.2334	1.0753	.1433	.1402
7	.1753	.1791	1.668	1.2811	1.1702	.1829	.1646
8	.1928	.2012	.1907	.2401	.1772	.1943	.1663
9	1.8084	.2534	.2561	.2126	1.3763	1.7124	1.8515
10	2.13	.1595	.2378	.2328	1.5384	2.0645	1.7604
11	2.2119	.1772	.2378	.2328	1.7004	2.13	1.9989
12	2.2672	.197	.2507	.2172	1.9989	2.13	1.8461
13	2.2834	.2149	.1928	.0474	1.9433	2.1376	1.8244
14	2.2939	.2103	.1753	.2534	1.9433	2.0405	1.7924
15	2.2939	.2454	.1886	.2715	1.9433	2.0405	1.7924
16	2.2119	.2427	.1886	.2481	1.8785	2.0729	1.7553
17	.1524	.2204	.1715	.2534	.1658	.16	.1524
18	.1524	.2374	.2058	.2658	.2454	.1829	.1739
19	.208	.2629	.2149	.2534	.2454	.1852	.1898
20	.208	.2686	.1829	.2507	.2058	.1698	.1875
21	.1848	.2328	.16	.2402	.2058	.1524	.1718
22	.1357		1.5684	1.186	.1715	.125	.1562
23	.1357	1.6518	1.439	1.2186	.1734	.0926	.1389
24	.0914	.1341	1.6194	1.4232	1.186	.1387	.0937
Max	2.2939	1.6518	1.668	1.4232	1.9989	2.1376	1.9989
Min	.0914	.1341	.16	.0474	.1658	.0926	.0937
Avg	.8227	.2592	.7566	.6751	1.0279	.7814	.7279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 202 / 11 KV BHALWANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7814	1.6518	.0732	.0709	.0747	1.9662	1.9006
2	1.7328	1.6194	.0747	.0724	.0747	1.9334	1.8842
3	1.6194	1.587	.0747	.0724	.0747	1.9006	1.8351
4	1.6194	1.5546	.0747	.0747	.0747	1.8023	1.8351
5	1.6032	1.6057	.0747	.0747	.0747	1.7695	1.9559
6	1.6712	1.6057	.0924	.0754	.0754	1.7368	1.989
7	1.7814	1.6842	.1294	.0754	.1132	1.9989	2.0222
8		.1387	.1029	.1075	.132	.1402	.1663
9	.128	1.9757	2.7161	2.4531	.0924	.0739	.0943
10	.1132	2.3537	2.9508	2.8837	.1372	.0943	.0895
11	.1448	2.6852	2.934	2.8837	.1296	.0943	.0934
12	.1075	2.7846	2.7846	2.9843	.1562	.0747	.1109
13	.1063	2.8502	2.9007	3.0514	.1204	.0747	.0739
14	.1097	2.7846	2.9172	2.9007	.1204	.0747	.0739
15	.1097	2.5526	2.9835	2.7183	.0926	.0747	.128
16	.1433	2.3537	2.8509	2.7199	.1109	.1086	.1254
17	.1433	.1063	.0914	.1107	.1448	.128	.0857
18	.1433	.1097	.1097	.1227	.0732	.1463	.104
19	.1075	.128	.112	.1629	.0732	.1463	.1086
20	.1075	.112	.1029	.1509	.0732	.128	.0914
21	.1086	.112	.1017	.1463	.0732	.0732	.128
22	1.6964		.0943	.1132	1.8785	2.0317	
23	1.6518	.0886	.0709	.0943	1.9989	1.9662	1.7284
24	1.8947	1.6842	.0732	.0709	.112	1.9989	1.9334
Max	1.8947	2.8502	2.9835	3.0514	1.9989	2.0317	2.0222
Min	.1063	.0886	.0709	.0709	.0732	.0732	.0739
Avg	.8098	1.4838	1.0204	1.0079	.2534	.8557	.8068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 203 / 11 KV KAMLAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9989	1.7166	.1677	.1387	.2614	1.8785	1.7238
2	1.9826	1.6518	.1677	.1448	.2614	1.8461	1.6907
3	1.9826	1.6194	.1677	.1448	.2614	1.8299	1.6575
4	1.9662	1.6057	.1677	.1494	.2614	1.8023	1.6575
5	1.9662	1.6385	.1677	.1494	.2641	1.8023	1.7072
6	1.9989	1.704	.2347	.1867	.3018	1.8023	1.8023
7	2.1879	1.7652	.2984	.2587	.3584	2.0809	1.8564
8	.2772	.2896	.2683	.2865	.3734	.3326	.3315
9	.2772	1.8461	2.4034	2.1628	.3547	.3326	.2347
10	.2896	2.4143	2.6825	2.4531	.3361	.2984	.2534
11	.2743	2.6686	2.6825	2.7357	.3361	.2984	.2772
12	.2926	2.7183	2.652	2.6852	.3467	.2984	.2743
13	.2683	2.7846	2.7846	2.6355	.4024	.2984	.2957
14	.3326	2.7349	2.652	2.6852	.4024	.3018	.3326
15	.3326	2.5194	2.5194	2.6852	.4066	.2984	.3326
16	.3292	2.4531	2.4531	2.652	.4066	.3647	.2926
17	.2926	.2347	.2195	.3658	.4066	.3353	.2926
18	.3326	.2347	.2195	.2926	.3696	.3353	.2218
19	.2957	.2347	.2957	.3921	.3696	.3315	.2427
20	.2534	.2347	.2772	.3547	.3361	.2984	.2587
21	.2507	.2347	.181	.3734	.2987	.2984	.2218
22	1.6484		.1829	.3174	1.8785	1.8233	1.6004
23	1.8564	.1677	.1387	.2987	1.9109	1.757	1.6004
24	1.9989	1.7652	.1677	.1387	.2987	1.9109	1.7404
Max	2.1879	2.7846	2.7846	2.7357	1.9109	2.0809	1.8564
Min	.2507	.1677	.1387	.1387	.2614	.2984	.2218
Avg	.9869	1.5320	1.0063	1.0286	.4668	.9565	.8708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 204 / BHALWANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.1132	.0934	.1143	.0701	.0671	.0943
2	.0709	.1132	.0934	.112	.0701	.0671	.0943
3	.0709	.1109	.0754	.112	.0701	.0686	.0754
4	.0709	.1109	.0754	.112	.0701	.0686	.0754
5	.0895	.1086	.0943	.112	.0686	.0747	.0943
6	.1307	.1086	.1494	.1307	.128	.112	.1509
7	.2263	.1509	.2054	.1494	.168	.1886	.1886
8	.2075		.1886	.1886	.168	.1509	.2075
9	.1698		.1463	.1509	.1663	.1509	.1334
10	.1132		.1097	.1663	.1753	.1132	.1294
11	.0739	.112	.1097	.0934	.104	.0953	.1143
12	.1132	.0934	.1109	.0754	.0754	.0943	.1417
13	.1132	.0943	.0754	.0905	.0754	.0943	.064
14	.0754	.112	.1132	.0747	.0754	.1132	.064
15	.0754	.112	.1109	.0754	.1086	.1132	
16	.0754	.112	.0905	3.0476	.0739	.1086	.1187
17	.1063	.1075	.0867	.0754	.0754	.112	.1448
18	.1063	.1829	.104	.1294	.1509	.112	.1448
19	.1867	.2195	.1867	.2075	.1886	.1494	.1867
20	.2241	.2218	.2241	.2241	.1886	.1886	.2263
21	.2241	.1478	.1886	.2075	.1509	.1886	.1886
22	.1509	.1509	.1509	.1698	.1132	.1509	.1109
23	.1132	.0953	.1143	.132	.0709	.1132	.0895
24	2.1195	.1132	.0943	.1143	.112	.0671	.0943
Max	2.1195	.2218	.2241	3.0476	.1886	.1886	.2263
Min	.0709	.0934	.0754	.0747	.0686	.0671	.064
Avg	.2074	.1281	.1246	.2527	.1132	.1151	.1275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 205 / ALSAND / KAMALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.2195	.2218	.1848	.1991	.2195	.2218
2	.1848	.2195	.2218	.1848	.1991	.2195	.2218
3	.1848	.2195	.2218	.1867	.1991	.2195	.2218
4	.2033	.2926	.2218	.1867	.2172	.2587	.2218
5	.3395	.3395	.2896	.1867	.3326	.3361	.2926
6	.5658	.4527	.3898	.4108	.5601	.4481	.3544
7	.7095	.6722	.6733	.6535	.7468	.695	.6733
8	.6468	.7023	.5316	.6283	.7023	.6283	.6733
9	.4938	.5249	.4656	.543	.5014	.5121	.4656
10	.3898	.3721	.3189	.443	.3467	.4298	.3467
11	.2683	.3189	.2835	.3944	.2984	.3898	.2774
12	.2622	.2835	.2713	.2984	.2683	.3189	.2012
13	.1966	.2481	.2515	.2267	.2683	.2507	.2294
14	.1966	.2507	.2458	.1966	.2622	.2507	.1966
15	.1943	.2507	.2543	.2515	.2622	.2507	.1943
16	.2012	.2507	.2622	.1526	.2683	.2507	.1898
17	.2683	.2835	.2401	.3018	.2949	.3224	.2035
18	.4024	.3189	.2401	.3521	.439	.3582	.373
19	.4755	.5316	.5068	.5731	.5544	.4607	.5068
20	.5121	.4656	.4706	.5249	.5121	.4607	.5068
21	.439	.394	.439	.4755	.4755	.3898	.439
22			.3326	.3658	.3292	.3224	.2957
23	.2218	.2534	.2218	.2353	.2561	.2507	.2195
24	.1829	.2195	.2195	.2218	.1781	.2195	.2195
Max	.7095	.7023	.6733	.6535	.7468	.695	.6733
Min	.1829	.2195	.2195	.1526	.1781	.2195	.1898
Avg	.3358	.3515	.3248	.3408	.3613	.3526	.3227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 206 / 11 KV Umar Kanchan AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.1387	1.7924	1.7604	1.4575	.1187	.1147
2	.1311	.1387	1.7814	1.7284	1.4918	.1187	.1147
3	.1311	.1433	1.7814	1.7204	1.4403	.1187	.1147
4	.1326	.1433	1.7166	1.7204	1.4403	.12	.1147
5	.156	.1463	1.749	1.7695	1.4403	.1463	.12
6	.1578	.1646	1.749	1.7859	1.4899	.1646	.1753
7	.2218	.1991	1.8138	1.8404	1.5546	.2218	.2195
8	.1989	.2012	.16	.213	.2279	.2458	.2427
9	2.2542	.2254	.1753	.1928	1.8404	2.1956	2.1956
10	2.4577	.1865	.1791	.0267	2.0891	2.556	2.3644
11	2.5263	.1907	.1791	.1677	2.1285	2.7035	2.4905
12	2.5911	.1907	.1844	.1718	2.332	2.6216	2.6397
13	2.6397	.2126	.1966	.1562	2.3758	2.5587	2.6235
14	2.4615	.2035	.1966	.1619	2.3922	2.5263	2.5911
15	2.3967	.2155	.16	.1658	2.4453	2.4615	2.4646
16	2.3482	.2105	.176	.1448	2.2186	2.2725	2.3205
17	.1829	.2155	.1715	.1907	.144	.1189	.1543
18	.1829	.218	.1791	.1492	.1677	.1286	.1886
19		.2229	.197	.1907	.1844	.1875	.1715
20	.1734	.208	.1886	.1696	.1638	.192	.1734
21	.1677	.1753	.1677	.1844	.1638	.1823	.1619
22	.1715		1.6484	1.4883	.1526	.1638	.1187
23	.1402	1.9044	1.7604	1.4403	.1341	.144	.0983
24	.1296	.1387	1.8564	1.7814	1.4575	.1187	.1134
Max	2.6397	1.9044	1.8564	1.8404	2.4453	2.7035	2.6397
Min	.1296	.1387	.16	.0267	.1341	.1187	.0983
Avg	.9601	.2606	.8400	.8050	1.2889	.9328	.9203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 207 / VITA WATER SUPPLY,ALSAND NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.1989	.2155	.1357	.1989	.1989	.213
2	.2012	.1989	.2155	.1326	.1989	.1989	.2155
3	.2012	.1989	.2155	.1341	.1989	.1989	.2155
4	.2012	.2347	.218	.1341	.1326	.1989	.2155
5	.218	.2347	.218	.1341	.1326	.1989	.2155
6	.2155	.2347	.218	.2012	.218	.1989	.218
7	.2155	.2012	.218	.1989	.218	.2012	.218
8	.2155	.1966		.1966	.2155	.1943	.2155
9	.2155	.1989	.218	.1989	.2155	.2012	.218
10	.2012	.2155	.2012	.2155	.2012	.218	.1989
11	.1989	.2155	.2012	.218	.1989	.218	.2012
12	.1989	.218	.1966	.0377	.2012	.1989	.1989
13	.1966	.218	.1966	.2155	.1989	.1989	.1966
14	.1989	.2155	.1989	.1966	.1989	.1989	.1966
15	.1989	.2155	.2155		.1966	.1989	.1966
16	.1989		.1966	.2105	.1989		.096
17	.1966	.213	.2012	.2155	.1989		
18	.1966	.213	.2012	.2155	.1966	.1296	.1147
19	.1966	.213	.1989	.2155	.1966	.1966	.1823
20		.213	.1966	.2155	.1966	.2105	.1966
21		.2155	.1966	.2155	.1966	.2105	.1966
22	.1989		.1989	.2155	.1989	.2105	.1989
23	.1989	.213	.1989	.2155	.1989	.1966	.1989
24	1.9989	.1989	.213	.1989	.218	.1989	.213
Max	1.9989	.2347	.218	.218	.218	.218	.218
Min	.1966	.1966	.1966	.0377	.1326	.1296	.096
Avg	.2845	.2125	.2065	.1855	.1969	.1989	.1970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 201 / 11 KV GARDI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7042				.6325	.7209	.7682
2	.6964				.6325	.6802	.759
3	.7042				.6325	.6722	.7274
4	.7287				.6325	.6882	.7362
5	.7362				.6325	.7125	.7682
6	.7842				.7125	.7449	.8192
7	.9717				.9069	.9503	.8684
8	.0695	.0625		.08		.0572	.096
9	.0488	1.0883	1.0608	1.6244		1.2803	.0655
10		.6962	1.1934	1.8442	.0579		.0734
11		2.0119	1.1961	2.0119			
12		2.079	1.6842	1.8778	.0594		
13	.0335	2.0119	2.0056	1.8564		.0772	.0564
14	.0533	2.0348	2.0885	1.6644	.0617	.0781	.0594
15	.0533		2.0287	1.6766	.061	.0753	.0602
16	.0579		1.873	1.4083	.0564	.0648	
17						.0648	
18					.0564	.0533	
19					.0633	.064	
20				.0556	.0587	.0648	.0541
21				.048	.0587	.061	.0526
22				.6958	.7449	.7773	.663
23				.6958	.7449	.7842	.7773
24	.7362				.6958	.7287	.8002
Max	.9717	2.079	2.0885	2.0119	.9069	1.2803	.8684
Min	.0335	.0625	1.0608	.048	.0564	.0533	.0526
Avg	.4556	1.4264	1.6413	1.1953	.3948	.4476	.4558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 202 / 11KV PRABHAT STEEL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0061	.0183	.0091	.0076	.0183	.0061	.0137
2	.0046	.0152	.0076	.0095	.0152	.0046	.012
3	.0061	.0122	.0076	.0086	.0122	.003	.012
4	.0046	.0122		.0069	.0122	.0046	.0137
5	.003	.0091	.0061	.0086	.0244	.0061	.0137
6	.0061	.0091	.0061	.0103	.0366	.0061	.0171
7	.012	.032	.0503	.029	.0351	.0061	.012
8	.0069	.0274	.0579	.0926	.0305	.0381	.0095
9	.2641	.2241	.3658	.2987	.0244	.0061	.0206
10	.1848	.679	.5624	.8215	.0046	.0061	.0874
11	.3018	.679	.0709	.9054	.0213	.032	.0671
12	.2263	.679	.9709	1.2071	.0229	.0457	.0183
13	.2218	.5658	.6602	.6036	.0061	.0351	.0057
14	.2263	.4527	.2987	.3018	.0061	.0457	.0362
15	.8299	.6413	.811	.7545	.0061	.0351	.0381
16	.8962	.7621	.3174	.0168	.0061	.0351	.0553
17	.6036	.5335	.0377	.5975	.0061	.0366	.0362
18	.8299	.4572	1.1128	.3772	.0061	.0381	.0514
19	.2218	.3189	.7621	.6036	.0061	.0183	.0564
20	.5281	.0198	.0213	.061	.0061	.0168	.0514
21	.0137	.0137	.0095	.0351	.0061	.0189	.0457
22	.032	.0091	.0076	.032	.0061	.0137	.0137
23	.0305	.0107	.0076	.032	.0061	.0154	.0107
24	.0061	.0213	.0122	.0076	.0213	.0061	.0137
Max	.8962	.7621	1.1128	1.2071	.0366	.0457	.0874
Min	.003	.0091	.0061	.0069	.0046	.003	.0057
Avg	.2278	.2584	.2684	.2845	.0144	.0200	.0297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 203 / 11 KV YETGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.8962	1.5089	1.576	.1905	.1524	.1509
2	.1698	.8962	1.5089	1.5424	.1905	.1334	.1509
3	.1509	.8962	1.5089	1.5424	.1905	.132	.132
4	.1524	.9069	1.576	1.5927	.1905	.1509	.1715
5	.1905	.9717	1.6095	1.6263	.2858	.1509	.2096
6	.2286	1.2452	1.6095	1.8482	.3048	.1494	.2667
7	.3048	1.8564	2.2721	2.146	.3048	.3206	.3239
8	.3048	.2263	.2743	.2858	.3048	.2829	.3239
9	1.4251	.3048	.2667	.3395	2.1704	2.4756	2.2382
10	2.1293	.3018	.2667	.3206	2.713	2.5434	2.6452
11	2.3205	.3018	.2858	.3772	3.12	3.0013	2.8487
12	2.4813	.3018	.3429	.3772	3.2556	2.9334	2.713
13	2.4143	.2829	.3395	.3048	3.12	2.7469	2.7808
14	2.4143	.2641	.3429	.381	3.086	2.6825	2.5606
15	2.146	.2667	.3961	.3772	2.9165	2.5774	2.4394
16	2.2131	.2667	.3772	.3018	2.6621	2.5987	2.3777
17	.1852	.3048	.415	.3772	.2096	.3018	.2263
18	.2286	.3048	.415	.3772	.2858	.3018	.3395
19	.2286	.3018	.415	.3772	.132	.415	.3772
20	.3048	.3018	.5335	.3772	.3429	.415	.362
21	.2263	.3018	.381	.381	.3429	.3772	.3048
22	.9602	1.3108	1.5257	.3048	.2858	.3395	.2858
23	.9602	1.3763	1.576	.2286		.2075	.2667
24	.1886	.9602	1.3763	1.5927	.1905	.1905	.1886
Max	2.4813	1.8564	2.2721	2.146	3.2556	3.0013	2.8487
Min	.1509	.2263	.2667	.2286	.132	.132	.132
Avg	.9374	.6395	.8801	.7898	1.1650	1.0658	1.0285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 204 / 11 KV SALSHINGE FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.004	.1509	.2772	.1509	1.3108	1.4586	1.278
2	.9831	.1509	.2801	.1509	1.3108	1.4746	1.278
3	.9831	.1509	.2218	.132	1.2955	1.491	1.247
4	1.0111	.1509	.2218	.1698	1.2955	1.4918	1.2944
5	1.0608	.1509	.2218	.1886	1.3108	1.6095	1.3592
6	1.326	.1509	.2218	.2452	1.3763	1.7238	1.576
7	1.7772	.3018	.3361	.3772	2.0119	2.2969	2.3739
8	.3696	.3772	.3018	.415	.2957	.3696	.3174
9	.2957	2.0119	2.146	2.3304	.2987	.3511	.3258
10	.2957	2.3472	2.3472	2.6155	.2263	.2957	.2987
11	.2241	2.8995	2.6322	3.0178	.1478	.3018	.3018
12	.1448	3.0521		2.4143	.1478	.3174	.2172
13	.2218	2.8826		2.4143	.1478	.2801	.2561
14	.1478	2.7808	2.7831		.2957	.3174	.2772
15	.1494	2.5819	3.0182	2.6825	.1663	.2614	.2957
16	.1494	2.4813	3.0514	2.6155	.2957	.2641	.2957
17	.2218	.2957	.2054	.2172	.3326	.2987	.823
18	.2218	.2957	.2241	.2241	.3142	.3109	.2957
19	.3018	.3734	.3772	.2957	.3326	.3206	.2957
20	.2263	.3734	.2987	.2987	.3326	.3395	.2614
21	.2241	.3018	.2614	.2241	.3155	.2614	.2241
22	.2263	.3018	.2614	1.3108	1.3923	1.2431	1.153
23	.1509	.2801	.2241	1.3108	1.4918	1.2944	1.2308
24	1.0364	.1509	.3018	.1886	1.3108	1.4586	1.3108
Max	1.7772	3.0521	3.0514	3.0178	2.0119	2.2969	2.3739
Min	.1448	.1509	.2054	.132	.1478	.2614	.2172
Avg	.5314	1.0414	.9188	1.0430	.7398	.8263	.7744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 206 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1595	.3012	.1509	.1772	.1402	.1524
2	.1402	.1595	.3012	.1509	.1417	.1402	.1524
3	.1402	.1595	.2835	.1509	.1417	.1578	.1334
4	.1753	.1949	.3012	.1886	.1772	.1928	.1905
5	.2279	.2303	.3012	.2452	.2481	.2629	.2667
6	.3856	.3366	.3012	.3395	.3544	.3681	.3961
7	.5258	.5316	.5493	.5228	.5138	.5083	.6161
8	.4557	.5493	.4961	.5359	.4607	.4557	.5544
9	.4031	.3721	.3721	.439	.3898		.4755
10	.333	.3012	.2481	.4075	.3721	.2804	.3582
11	.2658	.2835	.2835	.3189	.333	.3086	.2835
12	.2481	.2835	.3258	.2481	.2629	.2883	.3012
13	.2835	.2835	.2572	.3012	.2103	.2515	.2658
14	.3189	.2835	.2883	.3189	.2103	.2515	.2481
15	.3012	.2481	.2035	.2835	.2103	.2321	.2303
16	.2835	.2481	.2543	.2481	.2454	.2347	.2481
17	.2835	.3189	.3222	.3366	.298	.2713	.2658
18	.3721	.3366	.3258	.3544	.3856	.3155	
19	.4607	.4252	.5373	.4961	.4908	.5249	.4252
20	.4961	.4784	.5121	.4961	.4207	.5544	.443
21	.3898	.3189	.4481	.3721	.4207	.4287	.4607
22	.2835	.2658	.3206	.2835	.2454	.3547	.2835
23	.1772	.2835	.2263	.2126	.1753	.2452	.2126
24	.1578	.1772	.2835	.1886	.1772	.1578	.1886
Max	.5258	.5493	.5493	.5359	.5138	.5544	.6161
Min	.1402	.1595	.2035	.1509	.1417	.1402	.1334
Avg	.3028	.3012	.3352	.3162	.2943	.3011	.3110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 201 / 11 KV LENGARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1142	.0486	.0343	.061	1.1248	.933	1.0595
2	1.1523	.0486	.0347	.061	1.1702	.9172	1.1702
3	1.186	.0486	.0351	.0625	1.2003	.953	1.2809
4	1.2498	.0486	.0532	.0781	1.6194	.9686	1.4413
5	1.2498	.0486	.0537	.08	1.6004	.9998	1.5339
6	1.4403	.0486	.0543	.08	1.6975	.9998	1.6604
7	1.6804	.0486	.0724	.0876	1.781	1.6194	1.8299
8	.0914	.0486	.1052	.08	.0972	.0474	.104
9	.081	1.2651	1.8084	1.9204		.0633	
10	.081	1.9662	2.3102	2.1538	.0972		.0724
11	.064	2.343	2.4741	2.5101	.0648	.0617	.081
12	.048	2.7526	2.6543	2.5263	.0648	.0617	.081
13	.048	2.9172	2.6543	2.5446	.0486	.0781	.0678
14	.0486	2.9172	2.5911	2.4827	.0648	.0781	
15		2.8841	2.5911	2.4684	.0486	.0762	.0857
16	.0486	2.7199	2.6558	2.2771	.0648	.0663	.0857
17	.0486	.1372	.0678	.0648	.0486	.0829	.1029
18	.0486	.081	.0678	.0857	.0486	.0838	.0903
19	.0486	.0819	.0848	.0693	.0486	.0838	.1029
20	.0486	.0972	.0848		.0486	.0663	.1543
21	.0486	.0791	.0655	.0857	.0474	.064	.0857
22	.0486	.052		.8796	1.0364	.8128	.9105
23	.0486	.0509		1.0802	.9922	1.034	.8993
24	1.0814	.0486	.0335	.0594	1.1092	.9488	.9374
Max	1.6804	2.9172	2.6558	2.5446	1.781	1.6194	1.8299
Min	.048	.0486	.0335	.0594	.0474	.0474	.0678
Avg	.4785	.8659	.9357	.9478	.6141	.4826	.6290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 202 / 11 KV VEJEGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	1.3443	1.3226	1.4922	.0943	.0943	.132
2	.132	1.3923	1.2717		.0754	.0857	.1294
3	.132	1.4723	1.286		.0943	.1029	.1109
4	.132	1.587	1.286		.0754	.1029	.1052
5	.132	1.6518	1.3056		.1509	.12	.1052
6	.1509	1.8023	1.4586		.1509	.1372	.1052
7	.1698	1.9826	1.8442		.1509	.1886	.1132
8	.132	.1357	.112	.1463	.132	.1543	.168
9	1.5394	.1017	.0867	.1663	1.6194	2.1862	
10	2.1643	.1372	.1867	.1886	2.5425		2.1293
11	2.4577	.1509	.1494	.1698	2.8182	2.5724	2.4247
12	2.556	.1663	.1494	.1509	3.0967	2.6543	2.3975
13	2.5232	.2033		.1886	3.4808	2.7978	1.829
14	2.5396	.2149		.1698	4.3096	2.8487	2.3569
15	2.4291			.2075	3.5471	2.8826	2.323
16	2.5263			.1886	3.5968		2.0178
17	.2229	.1646	.1867		.1886		.1387
18	.1715	.1867	.168		.1698		.1417
19	.1372	.2054	.1494		.1581	.1698	.1612
20	1.5432	.1433	.1494		.1423	.1698	.1663
21	.1214	.1448	.112	.2263	.144	.1509	.1463
22	1.1544	1.1768		.132	.144	.1509	.1509
23	1.3443	1.326		.0943	.1132	.132	.132
24	.128	1.3443	1.3077	1.3916	.0943	.0943	.132
Max	2.556	1.9826	1.8442	1.4922	4.3096	2.8826	2.4247
Min	.1214	.1017	.0867	.0943	.0754	.0857	.1052
Avg	1.0280	.7743	.6962	.3509	1.1287	.8898	.7659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 203 / 11 KV SALSHINGE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7335	.1543	.1595	.1578	.9145	.6722	.8162
2	.7876	.1372	.1267	.1753	.9217	.6722	.8905
3	.9145	.1372	.1267	.1753	.9804	.7362	1.0322
4	.9842	.1372	.1629	.1715	1.0402	.7407	1.1305
5	1.1203		.1646	.1886	1.0802	.7716	1.2289
6	1.1203	.1543	.1829	.1886	1.1717	.8642	1.3272
7	1.2483	.1372	.2328	.197	1.2631	1.2955	1.3757
8	.2401	.156	.2454	.2058	.0829	.1898	.1907
9	.2058	.5487	1.3603	1.4403	.1006	.1581	
10	.1753	1.3592	1.7238	1.4737	.1029		.1718
11	.1543	1.576	1.7238	1.4083	.1387	.1372	.1357
12	.1543	1.643	1.7204	1.4737	.156	.156	.1357
13	.1734	1.8107	1.6842	1.4723	.1372	.1372	
14	.1734	2.0957	1.6518	1.4403	.1372	.1402	
15	.1543	2.0119	1.587	1.4251	.1372	.1204	.125
16	.1543	1.8233	1.5893	1.3916	.12	.1562	.1875
17	.1865	.1448	.2058	.1296	.1372	.1989	.1875
18	.1715	.2035	.2254		.1543	.218	.1783
19	.1715	.2572	.2454		.1543	.2401	.2401
20	.1543	.2601	.2454		.1543	.2229	.208
21	.1543	.2279	.2254	.2103	.1734	.2035	.2172
22	.1734	.197		.8688	.6325	.8223	.9339
23	.1543	.156		.8436	.6642	.7655	.9231
24	.7775	.1543	.1578	.156	.8688	.7042	.7202
Max	1.2483	2.0957	1.7238	1.4737	1.2631	1.2955	1.3757
Min	.1543	.1372	.1267	.1296	.0829	.1204	.125
Avg	.4349	.6732	.7158	.7235	.4760	.4488	.5884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 204 / 11 KV LENGARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1886		.1307	.132	.1543	.1448
2	.1509	.1698	.132	.1494	.132	.1543	.1629
3	.1698	.1509	.132	.1494	.132	.1387	.181
4	.1886	.1509	.132	.1478	.1509	.1387	.1848
5	.2075	.1886	.1478	.1848	.1509	.1753	.2218
6	.2452	.2507	.2427	.2957	.1698	.2507	.2957
7	.3696	.3361	.3547	.3292		.3582	.3696
8	.362	.2507	.3292	.3045	.3772	.2896	.3439
9	.2715	.2926	.2658	.2804	.3018	.2507	
10	.2534	.2126	.2454	.2454	.2263		.2454
11	.208	.2254	.2454	.1928	.1886	.2454	.2481
12	.1715	.2263	.2229	.1949	.1886	.2279	.2103
13	.1372	.2126	.1928	.2149	.1543	.2303	.1829
14	.1372	.1595	.1772	.1949	.1372	.2126	.1772
15	.156	.1612	.1433	.1753	.156	.2103	.1791
16	.156	.1949	.1578	.1753	.1372	.2534	.1865
17	.2058	.1791	.2103	.197	.1543	.2896	.208
18	.3961	.2126	.2534		.2865	.3258	.2427
19	.3772	.394	.3258		.3772	.3881	.3881
20	.3206	.3734	.3881		.3361	.3734	.2263
21	.3395	.3395	.3547	.3361	.3584	.3547	.3018
22	.2926	.2641		.2614	.2103	.2427	
23	.2103	.1886		.1886	.2103	.1698	.1509
24	.1886	.1886	.132	.1307	.1886	.1715	.1402
Max	.3961	.394	.3881	.3361	.3772	.3881	.3881
Min	.1372	.1509	.132	.1307	.132	.1387	.1402
Avg	.2361	.2296	.2279	.2133	.2112	.2437	.2269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 205 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1698	.2263	.2075	.132	.1698	.1478
2	.132	.1698	.1886	.1867	.1509	.1509	.1478
3		.1509	.1698	.1867	.132	.1509	.1663
4	.1698	.1509	.1698	.2054		.1698	.1663
5	.1698	.1698	.1867	.2054		.1698	.1848
6	.1698	.1886	.2402	.2241	.2829	.2263	.2218
7	.2452	.2641	.2957	.2241	.2829	.2829	.2402
8	.2452	.3018	.2561	.2801	.1698	.2452	.2033
9	.2452	.1886	.2353	.2614	.1886	.2263	
10	.2452	.1886	.2195	.2241	.1886		.2033
11	.1886	.2454	.2033	.1494	.1886	.2218	.1848
12	.1698	.1772	.1848	.168	.1886	.2218	.2033
13	.1886		.1848	.168	.1698	.2033	
14	.1698	.2126	.2218	.168	.1509	.1848	
15	.1509	.1949	.2218	.3174	.1886	.1663	.1848
16	.1509	.2149	.2587	.2801	.2263	.1848	
17	.1698	.2149	.2957	.2427	.1698	.2218	.2601
18	.3206	.2715	.3326		.2641	.2957	.3155
19	.3395	.3688	.3696		.3018	.3511	
20	.3206	.3734	.4435		.3584	.3326	.3696
21	.3395	.2987	.3361	.2987	.3206	.2957	
22	.2263	.2614		.2614	.2263	.2587	
23	.2075	.2075		.1867	.1886	.1848	
24	1.9181	.1886	.2263	.2075	.1886	.1698	.1663
Max	1.9181	.3734	.4435	.3174	.3584	.3511	.3696
Min	.132	.1509	.1698	.1494	.132	.1509	.1478
Avg	.2876	.2249	.2485	.2216	.2118	.2211	.2104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 206 / 11 KV VEJEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1524	.1109	.1307	.132	.1524	.1524
2	.132	.1524	.1109	.1494	.1509	.1334	.1715
3	.132	.1715	.1109	.1494	.132	.1334	.1715
4	.132	.1715	.1109	.1663	.132	.1715	.1905
5	.1509		.1307	.1848		.1905	.2286
6	.1698	.2096	.1848	.2587	.2263	.1905	.3048
7	.3018	.3048	.2957	.2801	.2452	.2858	.3239
8	.2641	.3048	.2772	.2241	.2452	.2667	
9	.1886	.2477	.2658	.2241	.2075	.2858	
10	.1698	.2286	.2126	.2427	.1698		.1905
11	.3018	.1928	.3142	.2987	.1143	.2667	.2263
12	.3239	.3189	.3326	.2801	.1143	.2286	.2075
13	.2667	.2804	.3511	.2987	.1334	.2286	
14	.2858	.2481	.3696	.3174	.1143	.2286	
15	.1905	.3761	.3734	.2987	.1905	.2286	.415
16	.2096	.394	.3734		.1905	.2641	
17	.1524	.2149	.3326	.2054	.1715	.2587	
18	.2286	.3224	.3326		.2286	.3326	.2686
19	.381	.3475	.3511		.3048	.4001	.3696
20	.2286	.3258	.2957		.362	.3429	.3772
21	.2667	.2715	.2614	.2452	.2858	.3048	.2829
22	.2096	.2218		.0566	.2286	.2427	.2263
23	.1524	.168		.1509	.1715	.2096	.2075
24	.1509	.1524	.112	.1307	.132	.1524	.1524
Max	.381	.394	.3734	.3174	.362	.4001	.415
Min	.132	.1524	.1109	.0566	.1143	.1334	.1524
Avg	.2134	.2512	.2550	.2146	.1906	.2391	.2482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 207 / 11KV KANDESARWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.3864	.5335	.5335	.0566	.0514	.0514
2	.0566	.4161	.5376	.6249	.0566	.0514	.0509
3	.0566	.4515	.5441	.6718	.0566	.0514	.0509
4	.0566	.4515	.5441	.7499	.0566	.052	.0509
5	.0566		.6226	.7811	.0566	.052	.0509
6	.0566		.6874	.8749	.0566	.052	.0509
7	.0566	.7316	1.0974	.9217	.0566	.0514	.0509
8	.0566	.0503	.0655	.0566	.0566	.052	.0514
9	.6859	.0503	.0693	.0509	.9061	.9374	
10	.9686	.0503	.0492	.0509	1.1561		1.0802
11	.9259	.0339	.0509	.0514	1.1873	1.2498	
12	.9877	.0347	.0509		1.2967	1.2811	
13	.884	.0347	.0509		.7621	1.2811	
14	.9145	.0343	.0509		.7316	1.3123	
15	.9297		.0514	.0514	.933	1.3435	1.358
16	.7926	.0492	.0514	.0526	1.2803	1.1584	1.2191
17	.0566	.0772	.0514	.0526	.0509	.0509	.0754
18	.052		.0514		.0509	.0509	.0754
19	.052	.0678	.052		.0509	.0509	.0754
20	.052	.0829	.052		.0509	.0509	.0943
21	.052	.081	.052		.0514	.0514	.0754
22	.4321	.503		.0566	.052	.0514	.0566
23	.3567	.6371		.0566	.052	.0514	.0566
24	.0566	.3864	.5335	.4816	.0566	.052	.0514
Max	.9877	.7316	1.0974	.9217	1.2967	1.3435	1.358
Min	.052	.0339	.0492	.0509	.0509	.0509	.0509
Avg	.3605	.2305	.2659	.3599	.3801	.4081	.2435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 201 / 11 KV TEXTILE PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6882	.6882	.7287	.7773	.9069	.664	.4049
2	.7209	.6882	.6478	.7611	.9069	.6478	.4049
3	.6882	.6554	.664	.7449	.852	.6478	.3887
4	.6554	.6554	.6154	.7611	.8421	.583	.3725
5	.6554	.6554	.6802	.7773	.8192	.583	.4049
6	.6802	.6226	.6802	.7935	.4534	.5506	.3563
7	.6478	.6226	.6478	.8097	.7865	.5182	.3401
8	.6554	.639	.7287	.8259		.5182	.3887
9	.852	.9503	.8259	.7773	.7449	.1619	.6316
10	.852	.9393	.8745		.7287	.1781	.6154
11	.9012	1.004	.8907		.7287	.1781	.6478
12	.8848	1.004	.9393	.9717	.7449	.2753	.583
13	.9831	1.0202	.9717	1.065	.6802	.2267	.6316
14	.9667	1.0202	.8749	1.0486	.6802	.2429	.7449
15	.9175	1.0526	.9069	.9831	.6802	.2429	.583
16	.9012	.9393	.8421	1.0364	.6478	.2591	.6478
17	.9831	.9231	.8583	1.0159	.6802	.2429	.6154
18	.9503	.8421	.8745	.9878	.7125	.2429	.7287
19	.9175	.8583	.9069	.9602	.7125	.3401	.7287
20	.9175	.8583	.9393	.9614	.6802	.3725	.6478
21	.8356	.8583	.8745	.9393	.7125	.3887	.6154
22	.7537	.8097	.8259	.8848	.6802	.4534	.6478
23	.7537	.7611	.8421	.9717	.664	.4372	.6802
24	.7449	.6882	.7611	.8259	.9717	.664	.4372
Max	.9831	1.0526	.9717	1.065	.9717	.664	.7449
Min	.6478	.6226	.6154	.7449	.4534	.1619	.3401
Avg	.8128	.8232	.8084	.8945	.7398	.4008	.5520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 202 / 11 KV PARE FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1448	1.6004	1.3443	1.3443	.1433	.0732
2		.1448	1.4575	1.3123	1.2651	.1433	.0732
3	.1294	.1463	1.3765	1.4091	1.2955	.1433	.1075
4	.1254	.1463	1.3765	1.4083	1.1603	.1433	.1463
5	.1463	.1478	1.6004	1.4419	1.1203	.1829	.2218
6	.1254	.1848	1.6324	1.6244	1.3927	.1829	.2218
7	.1294	.1867	1.6964	1.7814	1.5546	.2241	.2218
8	.1267	.1829	.1829	.1791	.1029	.1848	.2218
9	1.0242	.1463	.1753	.1991	1.3279	1.4723	1.4723
10	1.3927	.1791	.1772		1.6604	1.6518	1.7078
11	1.3748	.1433	.2058		1.5813	2.0081	1.7604
12	1.406	.181	.2126	.1463	1.7394	1.9433	1.7394
13	1.5123	.181	.2149	.1463	1.8185	1.9433	1.8023
14	1.4998	.181	.1991	.1463	1.7711	1.9433	1.7004
15	1.5497	.1829	.2195	.1448	1.7394	1.9433	1.8623
16	1.4373	.1448	.2126	.1463	1.6872	1.8244	1.7004
17	.1638	.1448	.1595	.1029	.1753	.1387	.1029
18	.1658	.1448	.1448	.1372	.1715	.1402	.1109
19	.1658	.1848	.2218	.1086	.1753	.2195	.1086
20	.1402	.2218	.2241	.1086	.1753	.2218	.1075
21	.1753	.2218	.2075	.1463	.2126	.1848	.1052
22	.1433	1.3443	1.3123	.9282	.1753	.1848	.1063
23	.1433	1.5043	1.3763	1.2125	.1402	.1829	.1097
24	.1086	.1448	1.6004	1.4586	1.2631	.1433	.0732
Max	1.5497	1.5043	1.6964	1.7814	1.8185	2.0081	1.8623
Min	.1086	.1433	.1448	.1029	.1029	.1387	.0732
Avg	.5797	.2723	.7411	.7106	1.0437	.7289	.6607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 203 / 11 KV WAZAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2407	1.2742		.0838	.0754	1.5089	1.4746
2	1.1736	1.2239		.0671	.0754	1.5089	1.2289
3	1.1736	1.2239		.0671	.0754	1.5089	1.1469
4	1.0898	1.2239		.0671	.0754	1.5089	1.3413
5	1.3413	1.1736		.0671	.0754	1.576	1.5089
6	1.3413	1.1736		.1006	.0754	1.6095	1.5089
7	1.576	1.1736		.1341	.0754	1.643	1.4746
8	.0754	.0671		.1174	.0754	.0671	.0671
9	.0754	1.6095		1.7604	.0754	.0671	.0671
10	.0671		2.2634		.0671		.1425
11	.0671		2.1963		.0671		.0671
12	.0671		2.1293	1.7604	.0671		.0671
13	.0671		2.3137	1.6766	.0671		.0671
14	.0671		2.1293	1.7604	.0671		.0671
15	.0671		2.0622	1.6766	.0671	.0671	.0671
16	.0671		1.9281	1.8861	.0671	.0671	.0671
17	.0671		.1006	.0943	.0671	.0671	.0838
18	.0671		.1006	.1029	.1006	.0671	.0838
19	.1006		.1341	.1132	.1006	.0671	.0838
20	.1006		.1341	.1132	.1006	.0671	.081
21	.1006		.1341	.0943	.1341	.0671	.0838
22	1.3748		.1006	.0943	1.6766	1.6575	1.2431
23	1.3413		.1006	.0754	1.6095	1.6766	1.1305
24	.763	1.2742		.0838	.0754	1.5089	1.6766
Max	1.576	1.6095	2.3137	1.8861	1.6766	1.6766	1.6766
Min	.0671	.0671	.1006	.0671	.0671	.0671	.0671
Avg	.5613	1.1418	1.1305	.5453	.2089	.8585	.6179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 204 / TEXTILE NO. 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3772	.1698	.4527	.415	.415	.4715
2	.415	.3772	.1886	.4715	.415	.415	.5093
3	.415	.3772	.2263	.4338	.3395	.415	.4904
4	.4527	.3772	.2075	.415	.3395	.415	.4338
5	.415	.3772		.4527	.3018	.4904	.5281
6	.3584	.3772	.2075	.4338	.3018	.5281	.547
7	.3772	.3772	.2452	.3961	.3018	.5658	.547
8	.3772	.3961	.2263	.3772	.3018	.5281	.4338
9	.415	.4715	.2452	.3772	.3018	.3961	.5658
10	.5281	.3772	.3395		.3582	.1698	.5658
11	.5658	.3395	.3395		.3395		
12	.5281	.415	.2829		.3018		.5658
13	.4338	.3584	.2641	.4715	.2452		.4904
14	.4715	.3018	.2263	.415	.3018		.5281
15	.4338	.2641	.3395	.415	.3395	.1886	.5281
16	.415	.2829	.5093	.4904	.3395	.1698	.5658
17	.415	.3018	.3584	.3395	.2452	.2075	.4904
18	.3961	.3018	.2641	.2641	.3772	.2075	.4715
19	.5093	.3018	.415	.3018	.3772	.2075	.3772
20	.5281	.2452	.4715	.3018	.415	.1886	.4527
21	.4338	.2075	.5093	.3018	.2452	.2641	.415
22	.3772	.3772	.5281	.3395	.4527	.415	.3772
23	.3772	.1886	.5093	.3584	.4338	.4904	.3395
24		.3772	.2075	.4904	.3395	.415	.4527
Max	.5658	.4715	.5281	.4904	.4527	.5658	.5658
Min	.3584	.1886	.1698	.2641	.2452	.1698	.3395
Avg	.4371	.3395	.3166	.3952	.3387	.3546	.4846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 201 / Yashodhan Garment

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2987	.3429	.3174	.3206	.3429	.3048
2	.2829	.2987	.3429	.3206	.3206	.3206	.3048
3	.2829	.2987	.3429	.3206	.3206	.3206	.2858
4	.2829	.2987	.3429	.3018	.3206	.3018	.2858
5	.2829	.2987	.3429	.3018	.3206	.3018	.2858
6	.2829	.2987	.3429	.3018	.3206	.3018	.2858
7	.3018	.2987	.362	.3048	.3206	.3206	.2858
8	.2829	.3584	.362	.3547	.3206	.3018	.2858
9	.381	.362	.381	.3772	.3961	.2263	.3018
10	.3961	.3772	.3961	.3584	.3772	.2286	.3429
11	.362	.381	.381	.3772	.3961	.2286	.3429
12	.3429	.3429	.381	.381	.3772	.2286	.3206
13	.3206	.362	.3772	.3429	.3772	.2286	.3048
14	.3395	.362	.3429	.362	.3772	.2286	.3018
15	.362	.4001	.362	.3961	.3772	.2286	.3395
16	.362	.381	.381	.415	.3584	.2286	.3206
17	.362	.381	.381	.3961	.3395	.2477	.3018
18	.4001	.381	.362	.3961	.3429	.2477	.3018
19	.362	.362	.362	.3772	.3429	.2477	.2829
20	.3395	.3429	.3395	.3584	.381	.2858	.3018
21	.3395	.3429	.3547	.3429	.3584	.3239	.2829
22	.3395	.3429	.362	.3429	.3395	.3239	.2829
23	.3174	.3429	.3395	.3395	.3239	.3239	.2686
24	.2829	.2987	.3429	.3206	.3429	.362	.3048
Max	.4001	.4001	.3961	.415	.3961	.362	.3429
Min	.2829	.2987	.3395	.3018	.3206	.2263	.2686
Avg	.3288	.3422	.3595	.3503	.3489	.2792	.3011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 202 / GHANWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.0732		.0754	.2469	.216	.2846
2	.2623	.0732		.0754	.2469	.1677	.2881
3	.2623	.0732		.0747	.2469	.1718	.2881
4	.2591	.0732			.2469	.1698	.2915
5	.2408	.0924	.0754		.3125	.2056	.3563
6	.301	.1109	.0943	.0943	.5247	.2881	.4481
7	.4843	.1109	.1132	.0943	.5556	.4744	.6081
8	.0934	.128	.1132	.0747	.1478	.1433	.1307
9	.1097	.3593	.4588	.4374	.0905		.1307
10	.0905	.4843	.5898	.4687			.0732
11		.506	.6718	.5182			.0905
12	.0886	.6483	.5556	.5556			.0924
13	.1075	.6722	.5601	.571			.0934
14	.1075	.5506	.578	.5401		.0678	.0934
15	.1629	.6401	.6001	.5556		.0732	.0716
16	.1086	.5921	.6405	.5937		.0924	.0686
17	.1097	.0924		.0716		.0924	.0686
18	.0886	.0924		.0914	.0693	.0924	.1052
19	.1463	.1132	.0732	.1109	.1109	.0924	.128
20	.1294	.1132	.0934	.0934	.1109	.0934	.1109
21	.0732	.0943	.132	.0934	.1097	.0934	.0934
22	.0914	.0934	.0754	.3361	.3077	.3361	.3563
23	.0732		.0762	.2656	.2753	.3479	.3201
24	.2896	.0732		.0754	.2469	.2343	.3125
Max	.4843	.6722	.6718	.5937	.5556	.4744	.6081
Min	.0732	.0732	.0732	.0716	.0693	.0678	.0686
Avg	.1719	.2548	.3236	.2667	.2406	.1817	.2043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 203 / GHANWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2601	.5894	.3292	.3292	.298	.2481	.3224
2	.2572	.5894	.3292	.3142	.298		.2865
3	.2572	.5894	.3292	.2896	.298		.2865
4	.2835	.6242	.3292	.2957	.298		.2865
5	.3439	1.086	.4024	.3841	.3506		.3582
6	.567	1.3756	.5068	.5175	.5609		.4835
7	.6767	1.3756	.6154	.6401	.631		.6805
8	.703	1.3322	.6697	.6173	.6661	.4656	.6984
9	.7122	1.1736	.583	.5935	.6135	.7011	.6516
10	.6299	.4588	.5344	.5197	.5426	.6516	.6203
11	.463	.5079	.5281	.5898	.4588	.57	.5801
12	.4365	.4961	.4902	.4111	.4372	.5407	.5079
13	.4531	.4372	.4801	.4372	.4481	.5407	.4534
14	.4428	.3812	.3887	.421	.4534	.5182	.4696
15	.4572	.4961	.4161	1.189	.4424	.4915	.4049
16	.4843	.5138	.4111	.4531	.4372	.4973	.4534
17	.4687	.5596	.463	.3887	.4588	.4694	.4409
18	.4475	.6001	.4748	.4641	.4917	.6024	.5144
19	.6556	.6733	.6687	.6447	.7164	.7522	.6984
20	.6805	.724	.6805	.6447	.7059	.7164	.6516
21	.6154	.6516	.6283	.5611	.543	.6447	.5611
22	.4344	.5014	.4344	.4344	.4525	.4706	.4066
23	.3189	.3761	.3961	.333	.3582	.3366	.362
24	.2629	.5894	.3292	.3174	.2947	.2835	.3189
Max	.7122	1.3756	.6805	1.189	.7164	.7522	.6984
Min	.2572	.3761	.3292	.2896	.2947	.2481	.2865
Avg	.4713	.6959	.4757	.4913	.4690	.5278	.4791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 201 / 11 KV PARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1905	.2286	.2477	.2286	.2477	.2096
2	.2096	.1905	.2286	.2075	.2096	.2096	.1905
3	.2096	.1595	.2096	.2033	.2096	.2096	.1905
4	.2096	.1991	.2096	.2075	.2096	.2477	.1905
5	.2858	.1848	.2667	.2353	.2477	.2667	.2286
6	.3429	.2427	.3048	.2658	.362	.3429	.2614
7	.5144	.2926	.4382	.3658	.4382	.4382	.4024
8	.5144		.462	.4954	.4805	.4954	.4572
9	.4191	.4382	.3841	.4572	.3721	.3439	.3881
10	.3189	.3898	.3544	.3511	.3544	.3077	.3258
11	.2804	.3841	.362	.3077	.362	.3077	.3189
12	.2572	.3506	.362	.333	.3326	.2896	.3012
13	.1907	.2715	.3429	.2896	.3206	.2896	.2774
14	.2303	.2507	.2667	.2743	.2601	.2715	.2835
15		.2896	.2858	.3121	.2534		.2715
16		.3077	.2858	.3475	.2743	.2614	.3189
17	.4001	.3077	.3429		.3429	.3696	.4763
18	.4191	.3506	.4001	.333	.4001	.3982	.3721
19	.4954	.5175	.5525	.5359	.5525	.543	.5175
20	.5335	.5359	.5335	.5175	.5716	.5121	.5014
21	.4954	.4954	.4954	.4805	.5335	.4755	.4887
22	.2926	.381	.3142	.4191	.381	.3921	.4715
23	.2033	.2858	.2858	.2858	.3048	.3048	.3048
24	.2477	.2075	.2477	.2477	.2477	.2858	.2477
Max	.5335	.5359	.5525	.5359	.5716	.543	.5175
Min	.1907	.1595	.2096	.2033	.2096	.2096	.1905
Avg	.3309	.3141	.3402	.3357	.3437	.3396	.3332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 202 / 11 KV PARE AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.4268	.5693	.5247	.0572	.0572	.0381
2	.0381	.3858	.5624	.4938	.0572	.0381	.0381
3	.0381	.3906	.5601	.506	.0572	.0381	.0381
4	.0381	.3749	.5851	.4687	.0572	.0381	.0381
5	.0381	.463	.6019	.5247	.0572	.0381	.0572
6	.0381	.506	.6706	.5624	.0572	.0572	.0572
7	.0572	.6019	1.1092	.9568	.0572	.0572	.0572
8	.0762		.1143	.0953	.0572	.0762	.0572
9	.5944	.0572	.0762	.0572	.787	.8905	.8488
10	.9374	.0572	.0762	.0762	1.1405	.9061	.7827
11	1.1561	.0572	.0762	.0762	1.186	.9061	.6327
12	1.1574	.0572	.0953	.0953	1.1405	.9842	.6405
13	1.1265	.0572	.0953	.0953	1.0957	.9686	.68
14	1.1248	.0572	.0953	.0953	1.0802	1.0031	.743
15	1.0494	.0572	.0762	.0953	1.078		1.0494
16	1.0648	.0953	.0953	.0762	1.0802		.953
17	.0762	.1143	.0762		.0762	.0381	.0572
18	.0572	.0762	.0572	.0953	.0572	.0762	.0762
19	.0762	.0762	.0762	.0762	.0762	.0762	.0572
20	.0572	.0762	.0762	.0762	.0762	.0762	.0572
21	.0572	.0572	.0762	.0572	.0572	.0572	.0572
22	.4687	.5639	.571	.0572	.0572	.0572	.0572
23	.4938	.6405	.578	.0572	.0572	.0572	.0572
24	.0572	.4687	.578	.5312	.0572	.0572	.0381
Max	1.1574	.6405	1.1092	.9568	1.186	1.0031	1.0494
Min	.0381	.0572	.0572	.0572	.0572	.0381	.0381
Avg	.4140	.2486	.3145	.2500	.3983	.2979	.2987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 203 / 11 KV GHOTI (BK) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.463	.5506	.4938	.0953	.0953	.0762
2	.0762	.4321	.5281	.4687	.0762	.0762	.0762
3	.0762	.4321	.506	.4687	.0762	.0953	.0762
4	.0762	.4531	.4999	.4744	.0762	.0953	.0762
5	.1143	.4902	.5155		.0953	.1143	.0953
6	.1334	.5401	.5247	.6405	.1334	.1524	.1334
7	.1905	.703	.759	.7926	.2096	.2096	.1715
8	.1715		.1143	.2096	.1715	.1905	.1905
9	.5864	.0572	.1143	.1905	.6718	.8333	.7202
10	.7716	.1143	.0953	.1524	.8539	.9259	.8025
11	.9014	.0762	.0953	.1334	.8592	.9568	.8592
12	1.0494		.0953	.1143	.8488	1.0031	.8124
13	1.0155	.0762	.0953	.0953	.8796	.9568	.6923
14	.9374	.0762	.0953	.1143	.9374	.9722	
15		.0762	.0762	.1143	1.0279	.9414	.6923
16	.9877		.0762	.0762	1.0031	.7125	.9374
17	.1334	.1143	.0953		.1143	.1143	.1334
18	.1334	.0953	.1143	.1524	.1334	.1524	.1334
19	.2286	.1715	.2667	.2096	.2096	.1905	.2096
20	.1524	.1715	.2477	.2286	.2286	.2286	.1905
21	.1334	.1524	.2286	.1905	.2096	.1905	.1715
22	.463	.5093	.6093	.1334	.1524	.1524	.1334
23	.5335	.5376	.5864	.1143	.0953	.1143	.0953
24	.0762	.4999	.5441	.5468	.0953	.0953	.0762
Max	1.0494	.703	.759	.7926	1.0279	1.0031	.9374
Min	.0762	.0572	.0762	.0762	.0762	.0762	.0762
Avg	.3921	.2972	.3097	.2779	.3856	.3987	.3285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 KV VITA NEW S/STN

Feeder No / Name : 201 / 11 KV Harewadi URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.4024	.3978	.4239	.3315	.3149	.39
2	.3315	.4024	.39	.4287	.3315	.2949	.3601
3	.3315	.3812	.3944	.4115	.3222	.2949	.3222
4	.3315	.3812	.3944	.4115	.3222	.2949	.3222
5	.3315	.3812	.407	.4287	.3258	.2949	.3467
6	.3315	.3812	.3887	.4359	.3353	.2984	.3521
7	.4191	.4973		.4641	.431	.4144	.4748
8	.5243	.5441	.5851	.4915	.4586	.4973	.5344
9	.5535	.664	.6081	.5407	.4744	.5441	.5535
10	.6554	.6882	.7045	.6133	.5668	.4049	.6964
11	.6802	.7459	.7537	.6962	.6081	.5304	.7287
12	.6722	.8785	.7773	.7287	.5851	.5898	.7907
13	.6401	.8356	.7865	.6722	.5992	.6478	.828
14	.6401	.8619	.8848	.6316	.5992	.6964	.7682
15	.6226	.7373	.852	.6478	.7537	.7125	.7935
16	.5571	.7125	.7773	.7287	.6722	.7125	.7682
17	.639	.7362	.7202	.8029	.6081	.7625	.6964
18	.5801	.664	.6478	.6226	.57	.664	.6226
19	.547	.6036	.6062	.5735		.5868	.4372
20	.5079	.5182	.5407	.5243	.503	.547	.426
21	.4915	.4858	.5138	.4534	.4359	.4694	.4144
22	.4527	.4372	.4973	.3856	.3856	.4748	.3768
23	.4191		.4534	.3812	.3481	.4144	.3277
24	.3647	.4191	.3932	.4409	.3688	.3315	.3856
Max	.6802	.8785	.8848	.8029	.7537	.7625	.828
Min	.3315	.3812	.3887	.3812	.3222	.2949	.3222
Avg	.4983	.5808	.5858	.5391	.4755	.4914	.5299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 KV VITA NEW S/STN

Feeder No / Name : 203 / 11 K V NEWARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.048	.1067	.0914	.0377	.0572	.0377
2	.0377	.0469	.108	.0914	.0377	.0381	.0377
3	.0377	.0469	.1094	.0914	.0377	.0381	.0377
4	.0377	.0463	.1054		.0377	.0191	.0377
5	.0377	.0457	.1219		.0377	.0191	.0377
6	.0377	.0457	.132		.0566	.0381	.0566
7	.0566	.0762	.2286	.1981	.0754	.0572	.0566
8	.0943	.0572	.0943	.0572	.0566	.0572	.0754
9	.128	.0572	.0566	.0572	.1581	.1423	.1718
10	.1898	.0381	.0754	.0377	.208	.1852	.2134
11	.2134	.0377	.0572	.0377	.2107	.2286	.2439
12	.176	.0377	.0381	.0566	.216	.1981	.2591
13	.176	.0377	.0381	.0377	.2187	.208	.2709
14	.1219	.0377	.0381	.0377	.2187	.1957	.1783
15		.0377	.0381	.0377	.2469	.2134	.1635
16	.2056	.0377	.0572	.0377	.2006	.176	.1467
17	.0381	.0566	.0572	.0377	.0572	.0566	.0572
18	.0381	.0754	.0572	.0566	.0572	.0762	.0572
19	.0381	.0754	.0572	.0754	.0572	.0943	.0572
20	.0381	.0943	.0572	.0943	.0762	.0762	.0572
21	.0381	.0943	.0572	.0754	.0762	.0953	.0572
22	.0497	.1265	.1543	.0566	.0572	.0566	.0572
23	.048		.1372	.0377	.0572	.0377	.0381
24	.0377	.048	.1094	.0914	.0377	.0572	.0377
Max	.2134	.1265	.2286	.1981	.2469	.2286	.2709
Min	.0377	.0377	.0381	.0377	.0377	.0191	.0377
Avg	.0832	.0567	.0872	.0664	.1055	.1009	.1018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 201 / 11 KV Shelakbav Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1629	.1267	.1448	.1629	.1448	.1629
2	.1791	.1991	.1629	.1629	.1646	.1448	.1629
3	.2172	.2378		.1629	.1646	.181	.1629
4	.2534	.2926	.2353	.1629	.1646	.2172	.1629
5	.2926	.3258	.2896	.2172	.181	.2534	.1629
6	.3326	.3658	.3258	.2715	.2896	.2896	.3077
7	.3696	.4024	.362	.362	.3475	.3077	.3801
8	.3547	.3658	.3475	.362	.3658	.3077	.3801
9	.2987	.3292	.2561	.3258	.3292	.2172	.3077
10	.2328	.2743	.2561	.3045	.2896	.1991	.2957
11	.2172	.2195	.2012	.2865	.2534	.2172	.2743
12	.1829	.2353	.1991	.2353	.2172	.1991	.2561
13	.1829	.1991	.2172	.1991	.1991	.181	.181
14	.1646	.181	.1991	.181	.181	.1448	.181
15	.1629	.1448	.181	.1629	.181	.1448	.181
16	.181	.1991	.1991	.181	.1991	.181	.1448
17	.181	.1629	.2172	.2353	.1991	.2172	.1629
18	.2105	.181	.2715	.2715	.2896	.2353	.1791
19	.3439	.1991	.3258	.2896	.3258	.3801	.2865
20	.3258	.2172	.362	.2926	.3439	.3801	.3077
21	.3077	.2353	.2172	.2926	.2715	.3258	.2715
22	.2172	.1486	.2172	.2172	.1448	.2172	.1791
23	.1267	.1448	.1267	.1829	.1448	.1267	.1612
24		.1267	.0905		.1629	.1267	.1267
Max	.3696	.4024	.362	.362	.3658	.3801	.3801
Min	.1267	.1267	.0905	.1448	.1448	.1267	.1267
Avg	.2382	.2313	.2342	.2393	.2322	.2225	.2241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 202 / 11 KV Dhawaleshawar AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1107	.128	.9667	.9122	.506	.1581	.0949
2	.1296	.144	1.0159	.8802	.4801	.1739	.1107
3	.1326	.16	1.0364	.8482	.4801	.1739	.1265
4	.1526	.1619	1.0688	.8322	.4801	.1898	.1265
5	.1734	.1781	1.1043	.8162	.506	.2056	.1265
6	.1949	.1781	1.1363	.8162	.5693	.2214	.1423
7	.1991	.1943	1.1843	1.1203	.5693	.2214	.1423
8	.1829	.2105	.208	.1581	.144	.1739	.1581
9	1.0343	.1943	.176	.1423	.8322	1.0911	.933
10	1.4091	.1619	.176	.1739	1.1385	1.2651	1.2803
11	1.5223	.1619	.192	.16	1.2809	1.3441	1.3123
12	1.5684	.1619	.176	.16	1.4232	1.5023	1.4864
13	1.5364	.1943	.176	.16	1.4706	1.4864	1.5023
14	1.5203	.1781	.176	.176	1.5339	1.3916	1.5043
15	1.5203	.1781	.16	.176	1.5655	1.3283	1.5203
16	1.5203	.1781	.192	.2881	1.5655	1.2651	1.3441
17	.128	.1781	.176	.16	.2214	.1898	.1581
18	.16	.1781	.16	.16	.1898	.1423	.1581
19	.176	.1781	.16	.16	.2056	.1898	.1739
20	.16	.1781	.16	.1581	.1898	.1898	.1739
21	.144	.1802	.16	.1265	.1739	.1581	.1581
22	.144	.0983	.8802	.6401	.1581	.1265	.1107
23	.112	.9393	.9762	.6081	.1423	.0949	.1107
24	.0937	.112	.9231	.9122	.5693	.1423	.0791
Max	1.5684	.9393	1.1843	1.1203	1.5655	1.5023	1.5203
Min	.0937	.0983	.16	.1265	.1423	.0949	.0791
Avg	.5844	.2002	.5308	.4477	.6831	.5594	.5431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 203 / 11 KV Shelakbav AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4198	1.2809	.181	.12	.1646	1.5023	1.6604
2	1.4327	1.2967	.2012	.128	.1478	1.5181	1.692
3	1.4842	1.3125	.2195	.1463	.1478	1.5181	1.7394
4	1.5339	1.3283	.2402	.1463	.1663	1.5339	1.8185
5	1.5123	1.3441	.2561	.128	.2012	1.5497	1.8501
6	1.5813	1.2967	.2772	.1463	.2402	1.5655	1.866
7	1.5971	1.3757	.2801	.2218	.2772	1.5813	1.8976
8	.2033	.2214	.2715	.2561	.2772	.1898	.2402
9	.1629	1.6484	1.692	1.8884	.2772	.1581	.1848
10	.1581	1.7553	1.9364	2.0399	.2056	.1581	.2012
11	.1898	1.945	2.0622	2.0873	.2056	.2402	.2172
12	.2214	2.0715	2.1125	2.1032	.2214	.2218	.2195
13	.1898	2.1032	2.0485	2.119	.2056	.2195	.2149
14	.1898	2.0557	2.0485	2.1285	.2214	.2218	.1612
15	.2056	1.9608	2.0645	2.0216	.2372	.2218	.1448
16	.2214	1.8903	1.9608	2.0805	.2056	.2772	.181
17	.2372	.1928	.1715	.208	.2214	.2957	.181
18	.253	.1753	.1989	.2507	.1898	.2957	.181
19	.2372	.1949	.197	.2328	.2056	.2587	.1991
20	.2056	.2126	.197	.2172	.2214	.2402	.1991
21	.1739	.2149	.2601	.1991	.1898	.2033	.181
22	1.2018	.1829	.208	.1646	1.5497	1.5023	1.2498
23	1.2176	.1629	.1341	.1646	1.5339	1.5339	1.2334
24	1.4043	1.2651	.1448	.12	.1646	1.4864	1.5813
Max	1.5971	2.1032	2.1125	2.1285	1.5497	1.5813	1.8976
Min	.1581	.1629	.1341	.12	.1478	.1581	.1448
Avg	.7181	1.1453	.8068	.8049	.3199	.7706	.8039