

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 201 / 11 KV HUTATMA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.7468	.7023	.7282	.7577	.8215	.7762
2	.6722	.7468	.7023	.7282	.7468	.8215	.7762
3	.6722	.7468	.7023	.6535	.7468	.8215	.7762
4	.6722	.7468	.7023	.6335	.7468	.8215	.7762
5	.7468	.7468	.7316	.724	.7468	.8589	.8131
6	.8402	.8402	.7865	.7602	.8402	.8775	.8686
7	.7783	.8589	.8048	.7602	.8589	.8775	.8871
8	.6516	.7468	.6268	.7421	.7343	.7842	.7392
9	.5609	.6535	.6335	.6805	.6556	.6556	.7392
10	.6447	.6626	.7207	.724	.6984	.7522	.7087
11	.6447	.7783	.7164	.7468	.6984	.788	.788
12	.7343	.7701	.7947	.7468	.6516	.7796	.5853
13	.7522	.724	.7762	.7468	.7023	.7619	.7499
14	.7522	.7783	.7468	.7468	.7282	.7964	.8596
15	.7701	.5658	.7655	.7468	.7468	.8145	.8962
16	.7701	.5853	.7059	.7468	.7392	.8145	.7421
17	.691	.6584	.7392	.7095	.4887	.7602	.8145
18	.8402	.7011		.6024		.8688	.8059
19	.8962	.8501	.7842	.724	.9313	.9412	.8688
20	.9335	.961	.961	.9425	1.0791	.9979	1.0534
21	.9335	.9425	.8962	.924	1.0719	.9425	.9795
22	.8962	.924	.8871	.9425	.9425	.8871	.9335
23	.8029	.8029	.8215	.8871	.9335	.823	.8402
24	.7095	.7468	.7282	.7282	.7947	.8589	.7682
Max	.9335	.961	.961	.9425	1.0791	.9979	1.0534
Min	.5609	.5658	.6268	.6024	.4887	.6556	.5853
Avg	.7516	.7619	.7581	.7531	.7844	.8303	.8144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 202 / 11 KV WALWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8645	2.4539	2.959	2.3158	.3121	.3344	.3292
2	2.894	2.4539	2.959	2.3158	.3121	.3344	.3292
3	2.8645	2.4539	2.959	2.3739	.3121	.3344	.3395
4	2.8645	2.4539	2.959	2.3739	.3121	.3344	.3395
5	2.9874	2.5415	3.0803	2.6116	.317	.3447	.3628
6	3.0434		3.1878	2.6642	.3702	.4001	.3887
7	3.3288	2.8833	3.2773	3.091	.3521	.3652	.3757
8	2.8898	2.758	2.9371	3.2407	.3048	.3517	.3368
9	.2423	.3292	.3048	3.3913	3.3105	3.276	.3239
10	.2835	.2858	.2905	3.4743	3.3436	3.5837	.2743
11	.2835	.2905	.3549	3.2236	3.5056	3.6923	.3048
12				3.1161	2.6749	3.5475	.439
13	.2835	.2953	.3549	3.1341	2.8532	3.528	.4572
14	.2835	.2858	.3868	3.0445	2.7938	3.4743	.4572
15	.2835	.4572	.3788	3.1741	2.7343	3.5117	.2953
16	.2835		.3652	2.9908	2.1262	2.9264	.2515
17	.2835	.6584	.3382	.4481		.2717	.2835
18	.3292	.2881		.2763			.2953
19	.3292	.3121	.4239	.281	.3286	.3536	.3071
20	.3841	.3662	.3944	.3574	.3978	.3662	.3868
21	.3841	.3662	.4311	.3757	.3812	.3426	.4058
22	.3292	.3662	.5544	.3757	.3923	.3536	.4001
23	2.6326	2.9843	2.3482	.3241	.3361	.3414	2.753
24	2.9384	2.6292	2.8807	2.3158		.3241	.3189
Max	3.3288	2.9843	3.2773	3.4743	3.5056	3.6923	2.753
Min	.2423	.2858	.2905	.2763	.3048	.2717	.2515
Avg	1.4474	1.3292	1.5512	2.1371	1.3224	1.4214	.4481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 203 / 11 KV.BAWACHI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6139	2.524	.4572	1.9753	2.1948	2.1582
2	2.6139	2.524	1.2803	1.9753	2.1948	2.1582
3	2.6139	2.524	1.2803	1.9753	2.1948	2.1582
4	2.6139	2.524	1.2803	1.9753	2.1948	2.1948
5	2.6139	2.5606	1.6461	2.0119	2.1948	2.3594
6	2.7073	2.5606	1.7741	2.0851	2.6155	2.4143
7	2.8006	2.5789	2.2862	2.3411	2.6155	2.4508
8	2.6886	2.6703	2.7252	2.3411	2.3594	2.5972
9	2.6139	2.524	2.7252	2.2862	2.4143	2.6155
10	2.6337	2.6886	1.9605	2.3411	2.5972	2.4143
11	2.6703	2.7252		2.3411	2.6337	2.5972
12	1.307	2.524	2.6139	1.3535	2.652	2.5972
13	1.4632	2.4691	2.7073	1.3535	2.5972	2.5789
14	1.4003	1.9204	2.7073	1.134	2.5972	2.2497
15	.823	1.2986	2.6513	1.0791	2.5606	1.2071
16	.823	1.1523	.4668	.8779	1.2071	1.0829
Max	2.8006	2.7252	2.7252	2.3411	2.652	2.6155
Min	.823	1.1523	.4572	.8779	1.2071	1.0829
Avg	2.1875	2.3605	1.9041	1.8404	2.3640	2.2396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 204 / 11 KV PADAWALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2241	.2241	.2641	1.4255	2.13	1.6804
2	.2427	.2241	.2241	.2641	1.4255	2.13	1.6804
3	.2427	.2241	.2241	.2641	1.4255	2.13	1.6804
4	.2427	.2241	.2241	.2263	1.4255	2.13	1.7604
5	.2801		.2987	.2829	1.4255	2.2119	1.9334
6	.3547		.3361	.3584	2.2447	2.3922	2.1956
7	.3547		.3547	.3961	2.6871	2.5396	2.3758
8	.3174		.3174	.3772	2.2283	2.2119	2.4806
9	2.982	3.152	2.8988	.3018	.2241	.3174	2.5126
10	3.0148	3.0803	2.9473	.2987	.2641	.2801	2.5396
11	.4588	2.6543	3.1093	.2987	.2641	.2614	2.4453
12		2.556	2.8178	.3734	.2075	.2427	1.861
13	2.8673	2.3758	2.8178	.2987	.2263	.2427	4.0787
14	2.8837	2.3758	2.753	.2614	.2641	.2427	2.8166
15	2.8837	2.7435	2.3967	.2614	.2829	.2427	1.8515
16	2.8673	2.8532		.2614	.2641	.2427	1.9826
17	.2303	.4207	.3018	.3174		.2987	.2801
18	.2427	.2614		.2801		.3547	.2829
19	.4481	.2987	.2829	.3361	.4108	.4108	.2829
20	.3174	.3174	.3395	.3547	.3734	.4108	.3206
21	.3174	.3174	.3395	.3921	.3734	.3174	.3206
22	.2987	.2987	.3206	.3547	.3361	.2987	.2829
23	.2801	.2614	.2641	2.2447	2.2447	1.8275	.2641
24	.2427	.2427	.2427	.2641	2.343	2.1792	1.7204
Max	3.0148	3.152	3.1093	2.2447	2.6871	2.5396	4.0787
Min	.2303	.2241	.2241	.2263	.2075	.2427	.2641
Avg	.9832	1.2553	1.0925	.3889	1.0166	1.0852	1.6512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 205 / 11 KV HUTATMA DUDH SANGH NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.4108	.9335		.8215	.9335	.9335
2	.6722	.4108	.9335		.8215	.9335	.9335
3	.6722	.4108	.9335		.8215	.9335	.9335
4	.6722	.4108	.8962		.8215	.9335	.9335
5	.6722	.3734	.8962		.8215	.9335	.9149
6	.5601	.3734	.8962		.9149	.9149	.9149
7	.5975	.3734	.8775		.8775	.9149	.9149
8	.5601	.3361	.8215		.8775	.9522	.8962
9	.5601	.4481	.9335	.6161	1.0642	1.1016	1.0456
10	.5228	.3921	.9149	.6348	1.0269	1.1016	1.0456
11	.5228	.5041	.9709	.7842	1.0269	1.0829	1.0456
12	.4854	.3921	.7842	.9522	1.0829	1.0829	1.0242
13	.4854	.3921	.7842	.9709	1.0269	.9896	.9328
14	.4854	.4854	.7468	.9709	1.0082	.9896	.9145
15	.4481	.4024	.6722	.9896	.9896	.9335	.9335
16	.4481	.3658	.8215	1.0082	1.0082	.9335	.9896
17	.4854	.4024	.7842	.9896		.9896	1.0642
18	.4522	.4854		1.0269		.9896	1.0082
19	.4481	.6348	.6908	1.0082	.7095	.9896	1.0082
20	.4854	.7842	.9522	1.0642	.9709	.9896	1.0082
21	.4481	.7842	.9335	1.0829	1.0082	.9896	.9896
22	.4481	.8215	.9149	1.0456	1.0082	.9896	1.0829
23	.4108	.9896	.9149	.9709	.9522	.9896	1.0082
24	.8775	.4108	.9522	.7655	.9335	.9522	.9328
Max	.8775	.9896	.9709	1.0829	1.0829	1.1016	1.0829
Min	.4108	.3361	.6722	.6161	.7095	.9149	.8962
Avg	.5486	.4914	.8678	.9300	.9361	.9810	.9754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 206 / 11KV AHIRWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3734	.3511	.3361	.3206	.3361	.3189
2	.3547	.3734	.3511	.3361	.3206	.3361	.3189
3	.3547	.3734	.3511	.2801	.3206	.3361	.3224
4	.3547	.3734	.3511	.2801	.3206	.3361	.3224
5	.4108	.3734	.3841	.3326	.3584	.3734	.3439
6	.4668	.4108	.4024	.3881	.3961	.4527	.3734
7	.4294	.4108	.4207		.4435	.3475	.3547
8	.3921	.3734	.3921	.3174	.3326		.3511
9	.2658	.3361	.3045	.3174	.2957	.3658	.3326
10	.2865	.3258	.3142	.3361	.3326	.3109	.3898
11	.3224	.3224	.3475	.3361		.2743	.3582
12		.3582	.3511	.3361		.2561	.3109
13	.3224	.3582	.3511	.3361	.3921	.2926	.3109
14	.3366	.2896	.3326	.3361	.3547	.3142	.3109
15	.3544	.4755	.3326	.3361	.3361	.3142	.3142
16	.3544	.3109	.3142	.2427	.2772	.3326	.3326
17	.3224	.3658	.3511			.3142	.3189
18	.3734	.362		.3801		.4481	.3696
19	.4854	.4755	.4805	.462	.6401	.5601	.3982
20	.5601	.5487	.5601	.5359	.5729	.5544	.5359
21	.5228	.5121	.3881	.5228	.499	.462	.499
22	.4481	.4755	.4668	.4481	.4108	.4119	.4668
23	.4108		.3921	.4108	.3921	.3982	.3881
24	.3547	.3734	.3547	.3361	.3547	.3361	.3403
Max	.5601	.5487	.5601	.5359	.6401	.5601	.5359
Min	.2658	.2896	.3045	.2427	.2772	.2561	.3109
Avg	.3843	.3892	.3759	.3610	.3836	.3680	.3618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 207 / 11KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9503	.9724	.7956	.664	.0566	.0566	.0566
2	.9503	.9724	.7956	.664	.0566	.0566	.0566
3	.9503	.9724	.7956	.7287	.0566	.0566	.0566
4	.9503	.9724	.7956	.7287	.0566	.0566	.0566
5	.9831	1.0059	.8951	.7935	.0566	.0566	.0566
6	1.0978	1.0898	.9614	.7935	.0566	.0566	.0566
7	1.1797	1.1736	1.0774	.7935	.0566	.0754	.0566
8	1.1633	1.1233	1.0608	.8421	.0754	.0566	.0566
9	.0566	.0566	.0566	.9878	1.1498	1.1797	.0566
10	.0566	.0566	.0566	1.0395	1.2146	1.2125	.0566
11	.0566	.0566	.0754	1.0562	1.2146	1.2616	.0754
12	.0566	.0754	.0754	1.1576	1.166	1.2266	.0549
13	.0566	.0754	.0566	1.0562	1.0688	1.2763	.0549
14	.0566	.0566	.0566	1.1233	1.0688	1.2597	.0514
15	.0566	.0549	.0754	1.251	1.0688	1.2266	.0754
16	.0566	.0549	.0754		1.1174	.9945	.0754
17	.0566	.0549	.0566			.0566	.0566
18	.0566	.0754		.0754		.0566	.0566
19	.0566	.0754	.0566	.0566	.0566	.0566	.0754
20	.0566	.0754	.0566	.0566	.0566	.0566	.0754
21	.0566	.0566	.0754	.0566	.0566	.0566	.0754
22	.0566	.0566	.0566	.0754	.0754	.0566	.0566
23	.9724	.7956	.8097	.0566	.0754	.0566	.9231
24	.9503	.9724	.7956	.664	.0566	.0566	.0566
Max	1.1797	1.1736	1.0774	1.251	1.2146	1.2763	.9231
Min	.0566	.0549	.0566	.0566	.0566	.0566	.0514
Avg	.4558	.4555	.4179	.6691	.4508	.4401	.0970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 208 / 11KV Kisan No 3 LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1109	.1109	.0185	.1109	.1109
2	.1097	.1109	.1109	.0185	.1109	.1109
3	.1097	.1109	.1109	.0185	.1109	.1109
4	.112	.1109	.1109	.0185	.1109	.1109
5	.1097	.1109	.1109	.0185	.1109	.1109
6	.1097	.1109	.1848	.0185	.1109	.1109
7	.2378	.2033	.1848		.2218	.1109
8	.2378	.2218	.1848	.2218	.2218	.2402
9	.2378	.2402	.2402	.2218	.2218	.2402
10	.2195	.2402	.2378	.2402	.2218	.2402
11	.2378	.2402	.2378	.2402	.2218	.2402
12	.2218	.0185	.2378	.2402	.2402	.2195
13	.2218	.0185	.2427	.2402	.2218	.2195
14	.2218	.0185	.2378	.2402	.2218	.6584
15	.2195	.0185	.2378	.2402	.2218	.2218
16	.2195	.0185	.2378	.2402	.2218	.2218
17			.2378			
Max	.2378	.2402	.2427	.2402	.2402	.6584
Min	.1097	.0185	.1109	.0185	.1109	.1109
Avg	.1835	.1190	.1916	.1491	.1814	.2049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 401 / 33KV Walwa LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8656	1.8656	.9877		1.7558	1.7558
2	1.8656	1.8656	.9877		1.9753	1.8656
3	1.8656	1.8656	1.0974		1.9753	1.8656
4	1.8656	1.8656	1.2071		1.9753	1.8656
5	1.8656	1.8656	1.3169		1.9753	2.0302
6	1.8656	1.8656	1.5364		2.0302	2.0302
7	1.8656	1.8656	1.9753		.2743	2.0302
8	1.8656	1.8656	2.0302		1.9753	2.0302
9	1.9753	1.8656	2.0851		2.0302	1.9753
10	1.9753	1.7558	1.9753		2.0851	1.9753
11	1.9753	2.0302	2.0302		2.0851	1.9753
12	1.9204	2.0302	2.0302	1.701	2.0851	1.9753
13	1.9204	1.9753	1.9753	1.9753	2.0851	1.9753
14	1.701	1.9204	1.9753	1.9753	2.0302	1.8004
15	1.3169	1.9753	1.9753	1.9753	2.0302	1.9753
16		1.262	1.3169	1.3169	1.3169	1.3169
Max	1.9753	2.0302	2.0851	1.9753	2.0851	2.0302
Min	1.3169	1.262	.9877	1.3169	.2743	1.3169
Avg	1.8473	1.8587	1.6564	1.7888	1.8553	1.9027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 201 / 11 KV. SHIGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.0974	1.0385	.6573	.0312	.0566	.0278
2	1.2041	1.0669	1.0517	.6661	.0312	.0566	.0274
3	1.174	1.0536	1.0957	.6661	.0316	.0566	.0274
4	1.174	1.0536	1.0974	.6748	.0316	.0566	.0271
5	1.1584	1.0402	1.0837	.7042	.048	.0566	.0271
6	1.1584	1.07	1.0987	.7042	.048	.0566	.0406
7	1.2955	1.07	1.2191	1.0536	.0274	.0754	.04
8	1.1888	1.0837	1.0402	1.1138	.0274	.0754	.0236
9	.0337	.0303	.0492	1.2193	1.5181	1.5935	.0251
10	.0156	.0509	.0297	1.2193	1.6872	1.5394	.0236
11		.0503	.0198	1.2191	1.5432	1.5813	.0236
12		.0509	.0198	1.0822	1.3717	1.4373	.0236
13		.0509	.0198	1.0494	1.2955	1.3272	.0236
14		.0514	.0229	1.0494	1.1888	1.2654	.0229
15	.0202	.0509	.0236	1.0494	1.1584	1.2193	.0229
16	.024	.0514	.0244	.9511	1.0385	1.189	.0343
17	.0202	.0372	.0229	.0429	.0566	.0263	.0354
18	.0225	.0829		.0423	.056	.0267	.0354
19	.0343	.0732	.0229	.0423	.0747	.0372	.0354
20	.0366	.0732	.0248	.0446	.0747	.04	.0354
21	.0354	.0724	.0255	.0452	.0739	.0394	.0236
22	.0354	.0549	.0255	.0452	.0566	.0267	.0457
23	1.2811	1.0974	.7335	.0457	.0474	.0221	1.5181
24	1.2955	1.2498	1.0235	.6573	.0457	.0566	.0278
Max	1.2955	1.2498	1.2191	1.2193	1.6872	1.5935	1.5181
Min	.0156	.0303	.0198	.0423	.0274	.0221	.0229
Avg	.6214	.4860	.4701	.6685	.4818	.4966	.0916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 202 / 11 KV. BHADKAMBE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.4066	.3506	.3856	.3582	.3856
2	.3856	.4066	.3856	.3856	.3841	.3856
3	.3856	.4207	.3544	.3898	.4066	.3898
4	.3898	.4251	.3898	.3898	.3982	.3898
5	.3898	.4207	.394	.4119	.394	.394
6	.3898	.4207	.394	.4119	.4075	.394
7	.394	.4207	.394	.3772	.4075	.394
8	.394	.4207	.394	.3772	.0686	.4075
9	.3856	.4119	.3898	.3982	.4031	.4075
10	.4163	.3856	.3898	.3898		.4075
11	.4031	.3898	.4031	.4119		.3898
12	.3988	.3898	.4119	.4163		.3544
13	.4031	.3856	.4477	.4207		.3544
14	.4119	.3856	.3982	.4294		.3544
15	.4207	.3856	.3982	.4075		.3544
16	.2481	.2481	.2507	.0312	.2481	.2126
Max	.4207	.4251	.4477	.4294	.4075	.4075
Min	.2481	.2481	.2507	.0312	.0686	.2126
Avg	.3876	.3952	.3841	.3771	.3476	.3735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 203 / 11 KV.POKHARNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1109	.1307	.0732	.0732	.0934	.0747
2	.1132	.1109	.1294	.0732	.0724	.0934	.0747
3	.112	.1109	.1307	.0739	.0724	.0943	.0747
4	.112	.112	.1307	.0924	.0732	.0943	.0924
5	.112	.112	.1307	.112	.0914	.1132	.1109
6	.1294	.1307	.1494	.112	.1097	.1132	.1109
7	.1448	.1494	.1294	.1109	.1086	.112	.132
8	.1086	.132	.0895	.0732	.0716	.0686	.0701
9	.0724	.0914	.0905	.0716	.0905	.0829	.1063
10	.0526	.0995	.1029	.0895	.1063	.08	.0857
11		.0914	.0914	.1372	.1029	.112	.0857
12		.0848	.0924	.081	.0926	.096	.1052
13		.0781	.1109	.0895	.108	.08	.1227
14		.0772	.1097	.1075	.1341	.0848	.1227
15	.0924	.1254	.1086	.1227	.1475	.1109	.1052
16	.0701	.1227	.1086	.1086	.081	.1402	.0701
17	.0819	.0762	.1075	.1227	.0848	.1097	.1029
18	.0848	.0819		.1227	.0857	.1109	.1029
19	.1109	.1478	.1075	.12	.104	.0895	.1402
20	.1417	.1791	.1254	.128	.1132	.1433	.1402
21	.1433	.1663	.1267	.1463	.1132	.128	.1372
22	.1254	.168	.1086	.1294	.1132	.1109	.1029
23	.128	.1448	.1097	.1109	.1109	.112	.1132
24	.1132	.1109	.1307	.0739	.0732	.0934	.0934
Max	.1448	.1791	.1494	.1463	.1475	.1433	.1402
Min	.0526	.0762	.0895	.0716	.0716	.0686	.0701
Avg	.1081	.1173	.1153	.1034	.0972	.1028	.1032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 204 / 11 KV SHIGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3395	.3734	.3395	.3395	.3395	.3206
2	.3018	.3395	.3772	.3395	.3395	.3395	.3206
3	.3018	.3395	.3734	.3395	.3395	.3584	.3206
4	.3018	.3395	.3961	.3395	.3395	.3772	.3395
5	.3395	.3772	.415	.3772	.3772	.415	.3772
6	.4338	.4527	.4481	.415	.415	.4338	.4481
7	.3881	.4481	.439	.4108	.4108	.4066	.4251
8	.3511	.3696	.362	.3696	.3658	.2561	.3658
9	.3292	.3258	.3294	.3292	.3258	.3582	.362
10	.2835	.3012	.3224	.3258	.2835	.2865	.3658
11		.3366	.3258	.3547	.3077	.2896	.3292
12		.3511	.3658	.3224	.3224	.2896	.3109
13		.3584	.3658	.3258	.3109	.3658	.3109
14		.3395	.362	.3224	.2957	.3658	.2915
15	.3582	.3658	.3258	.3658	.3142	.3439	.2915
16	.3582	.3142	.3292	.3658	.2328	.3439	.2926
17	.3012	.3109	.3258	.362	.2743	.3258	.3326
18	.3403	.3481		.3582	.3511	.3475	.3734
19	.4706	.499	.362	.3898	.4706	.362	.4108
20	.5121	.5359	.4755	.4755	.5121	.5068	.4854
21	.4805	.5228	.4755	.4805	.462	.4805	.4527
22	.4435	.4904	.4435	.4481	.4338	.4481	.415
23	.3734	.415	.3772	.3772	.3772	.3961	.3734
24	.3395	.3395	.3772	.3395	.3395	.3395	.3395
Max	.5121	.5359	.4755	.4805	.5121	.5068	.4854
Min	.2835	.3012	.3224	.3224	.2328	.2561	.2915
Avg	.3664	.3817	.3803	.3697	.3559	.3657	.3606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 205 / 11 KV POKHARNI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0549	.0566	.0549	.7225	.6836	.5213
2	.0566	.0554	.056	.0549	.7225	.6923	.5068
3	.056	.0554	.0554	.0543	.7225	.6773	.5068
4	.056	.0554	.056	.0543	.7225	.7468	.5001
5	.0549	.056	.0554	.0732	.7727	.7827	.5216
6	.0549	.0747	.0554	.0732	.8322	.8768	.5357
7	.0549	.0754	.0747	.0739	.9095	1.2191	.5921
8	.0732	.0747	.0373	.0747	.9682	.9214	.743
9	1.0536	1.174	1.1431	.0747	.0566	.0566	.873
10	1.0105	1.2963	1.1888	.0747	.056	.0566	1.174
11		1.2651	.8916	.056	.0554	.0566	1.1138
12		1.1736	.8802	.0943	.0566	.0566	1.0402
13		1.0105	.8802	.0566	.0377	.0566	1.0105
14		.9829	.8322	.0566	.0377	.056	.9511
15	.1829	.8535	.8322	.0566	.0332	.0554	.8916
16	.2439	.724	.8429	.0566	.0377	.0549	.8322
17	.048	.0377	.056	.056	.0554	.056	.04
18	.0509	.056		.056	.056	.0554	.0446
19	.0566	.0739	.0566	.0747	.0943	.0566	.0457
20	.0754	.0739	.0754	.0754	.0924	.0492	.0469
21	.0754	.0724	.0747	.0754	.0914	.0514	.0566
22	.0754	.0724	.0747	.0747	.0905	.0554	.0377
23	.0747	.0412	.0747	.6923	.7375	.6097	.0377
24	.0566	.056	.056	.0554	.7225	.6859	.535
Max	1.0536	1.2963	1.1888	.6923	.9682	1.2191	1.174
Min	.048	.0377	.0373	.0543	.0332	.0492	.0377
Avg	.1734	.3944	.3655	.0916	.3618	.3612	.5483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 206 / HUTATMA SURESHKUMAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.1132	.2829	.2641	.2195	.2801
2	.2801	.112	.2829	.2801	.2378	.2801
3	.2801	.112	.0019	.2801	.2587	.2801
4	.2801	.1294	.0019	.2801	.2587	.2987
5	.2801	.1294	.0019	.2801	.2772	.2987
6	.2801	.1307	.0019	.2801	.2957	.2987
7	.3018	.1294	.0023	.2829	.2987	.2987
8	.3018	.2987	.2829	.2829	.1478	.2987
9	.2829	.2957	.2829	.2987	.2987	.2987
10	.2772	.2987	.2829	.2801	.2987	.2987
11	.2772	.2801	.2987	.2957	.2987	.2987
12	.2772	.2801	.2957	.2957	.2987	.2987
13	.2801	.2801	.2957	.2957	.2987	.2801
14	.2772	.3018	.2957	.2957	.2801	.2801
15	.2987	.3018	.2987	.2957	.2801	.2801
16	.2957	.3018	.2829	.0191	.2614	.2801
Max	.3018	.3018	.2987	.2987	.2987	.2987
Min	.2587	.112	.0019	.0191	.1478	.2801
Avg	.2831	.2184	.1995	.2692	.2693	.2906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 207 / 11KV Bahadurwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4816	.4515	.4607	.176	.0183	.0189	.0187
2	.4816	.4515	.4816	.1738	.0179	.0189	.0187
3	.4816	.4515	.4877	.1738	.0179	.0189	.0187
4	.4755	.4458	.5093	.1715	.0181	.0189	.0189
5	.4755	.4755	.5155	.1715	.0181	.0189	.0189
6	.4755	.4755	.5093	.1715	.0183	.0189	.0189
7	.602	.5117	.4458	.2934	.0185	.0187	.0187
8	.4755	.5117	.5335	.4161	.0187	.0189	.0152
9	.0187	.0189	.0189	.4161	.4458	.5201	.0177
10	.0158	.0189	.0189	.4161	.4694	.5719	.0187
11		.0187	.0189	.5268	.4548	.6097	.0189
12		.0185	.0189	.4344	.4344	.5335	.0189
13		.037	.0189	.3814	.4401	.4877	.0189
14		.0347	.0189	.3814	.4489	.4572	.0189
15	.0171	.0183	.0189	.3814	.4254	.4458	.0189
16	.0189	.0189	.0187	.3765	.3668	.4694	.0189
17	.0177	.0189	.0187	.0187	.0189	.0177	.0189
18	.0177	.0185		.0189	.0189	.0181	.0189
19	.0189	.0171	.0189	.0189	.0189	.0189	.0189
20	.0187	.0147	.0187	.0189	.0187	.0183	.0189
21	.0183	.0181	.0183	.0189	.0187	.0185	.0189
22	.0183	.0179	.0183	.0189	.0189	.0183	.0189
23	.4877	.4365	.3227	.0189	.0177	.0185	.4816
24	.4816	.4572	.4548	.2934	.0189	.0189	.0187
Max	.602	.5117	.5335	.5268	.4694	.6097	.4816
Min	.0158	.0147	.0183	.0187	.0177	.0177	.0152
Avg	.2549	.2066	.2159	.2286	.1575	.1831	.0379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 401 / 33KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	.9054	.8488	.8488	.8488	.9054
2	.7356	.9054	.9054	.9054	.9054	.9054
3	.7356	.8962	.9054	.9054	.8962	.9054
4	.7356	.8871	.9054	.9054	.8962	.9054
5	.7356	.8962	.9054	.9054	.9054	.9054
6	.7356	.9054	.9054	.9054	.9054	.9054
7	.8488	.9054	.9054	.8488	.9054	.9054
8	.9054	.9054	.9054	.8488	.9054	.9054
9	.9054	.9054	.9054	.9054	.9054	.9054
10	.9054	.9054	.9054	.9054	.9054	.9054
11	.8962	.9054	.9054	.9054	.9054	.9619
12	.8962	.9054	.9054	.9054	.9054	.9619
13		.9054	.9054	.9054	.9054	.9619
14		.9054	.9054	.9054	.9054	.9619
15		.9054	.9054	.9054	.9054	.9619
16		.7922	.7922	.0069	.7922	.9619
Max	.9054	.9054	.9054	.9054	.9054	.9619
Min	.7356	.7922	.7922	.0069	.7922	.9054
Avg	.8143	.8960	.8948	.8386	.8936	.9266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 201 / 11 KV KRISHNAMAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7907	.6562	.7522	.6019			
2	.7499	.6562	.7522	.5944			
3	.759	.6562	.7522	.6173			
4	.7186	.6562	.7522	.6173			
5	.7343	.6562	.7522	.6173			
6	.7186	.664	.7522	.6173			
7	.7625	.583	.7522	.679			
8	.7293	.6299	.7522	.7811			
9				.8065		.8124	
10				.8192	.8288	.852	
11				.852	.8619	.8951	
12				.8288	.8619	.9175	
13				.8288	.8619	.8192	
14				.8288	.8619	.8192	
15				.8551	.8619	.8192	
16				.8453	.8223	.8192	
23	.5693	.7432	.6093				.6562
24	.8124	.6483	.7522	.5792			
Max	.8124	.7432	.7522	.8551	.8619	.9175	.6562
Min	.5693	.583	.6093	.5792	.8223	.8124	.6562
Avg	.7345	.6549	.7379	.7276	.8515	.8442	.6562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 202 / 11KV MAHALAXMI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	1.1694	1.2071	.0427	.0396	.5792
2	.6584	1.1694	1.1946	.0434	.0396	.5853
3	.6584	1.1694	1.2071	.0434	.0396	.6036
4	.6584	1.1694	1.2071	.045	.0404	.6036
5	.6584	1.1694	1.2071	.0442	.0404	.6036
6	.6584	1.1694	1.1946	.0524	.0606	.6036
7	.6584	1.1694	1.1946	.064	.0652	.5544
8	1.2071	1.2048	1.2178	.0869	.0434	.5487
9	1.3169	1.2048	1.2308	.0787	.0652	.5487
10	1.2757	1.2048	1.1999	.0869	.6588	.5249
11	1.2757	1.2048	1.182	.0869	1.1568	.5249
12	1.2757	1.1871	1.182	.0869	1.1694	.591
13	1.1694	1.1694	1.182	.0869	1.1694	1.1517
14	1.1694	1.1694	1.182	.0869	1.1694	1.1517
15	1.1694	1.1641	1.182	.0869	1.1694	1.1694
16	1.1694	1.1393	1.1641	.0869	1.1694	1.1871
Max	1.3169	1.2048	1.2308	.0869	1.1694	1.1871
Min	.6584	1.1393	1.1641	.0427	.0396	.5249
Avg	.9773	1.1771	1.1959	.0693	.5060	.7207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 203 / 11KV YASHWANT AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9389	1.1191	1.2378	.1772			
2	.9496	1.1191	1.2378	.583			
3	.9556	1.1191	1.2378	.5895			
4	.9496	1.1191	1.2378	.5658			
5	.9496	1.1191	1.2378	.5658			
6	.9665	1.1191	1.3226	.5895			
7	1.1361	1.1191	1.3565	.6687			
8	1.1361	1.153	1.1869	.763			
9				.7545		1.4582	
10				.9259	1.1401	1.5947	
11				1.3375	1.1401	1.6118	
12				1.406	1.4419	1.6297	
13				1.4403	1.4419	1.5775	
14				1.491	1.4419	1.5775	
15				1.406	1.4419	1.3321	
16				1.1488	1.4419	1.4175	
23	.8139	1.2378	1.153				1.2656
24	.9496	1.1191	1.2517	1.2209			
Max	1.1361	1.2378	1.3565	1.491	1.4419	1.6297	1.2656
Min	.8139	1.1191	1.153	.1772	1.1401	1.3321	1.2656
Avg	.9746	1.1344	1.2460	.9196	1.3557	1.5249	1.2656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 204 / 11 KV ASHTA PWW

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709		.0709	.0709	.0709	.0709	.0701
2	.0709	.0701	.0709	.0709	.0709	.0709	.0709
3	.0709	.0701	.0709	.0716	.0709	.0709	.0709
4	.0709	.0701	.0709	.0709	.0709	.0709	.0709
5	.0709	.0701	.0709	.0709	.0709	.0709	.0709
6	.0709	.0701	.0709	.0716	.0709	.0709	.0709
7	.0709	.0701	.0709	.0716	.0709	.0709	.0709
8	.0709	.0716	.0709	.0716	.0709	.0709	.0709
9	.0709	.0701	.0709	.0716	.0709	.0709	.0701
10	.0678	.0709	.0709	.0709	.0701	.0709	.0693
11		.0709	.0709	.0709	.0701	.0709	.0709
12		.0709	.0709	.0709	.0701	.0709	.0701
13		.0709	.0701	.0709	.0701	.0709	.0701
14		.0709	.0709	.0709	.0709	.0709	.0701
15	.0701	.0709	.0709	.0709	.0709	.0709	.0709
16	.0701	.0709	.0701	.0709	.0709	.0709	.0709
17	.0701	.0709	.0693	.0709	.0709	.0709	.0709
18	.0701	.0709		.0709	.0716	.0709	.0716
19	.0701	.0709	.0709	.0701	.0716	.0709	.0709
20	.0701	.0709	.0701	.0709	.0716	.0709	.0709
21	.0701	.0709	.0701	.0709	.0716	.0709	.0701
22	.0701	.0709	.0701	.0709	.0716	.0709	.0701
23	.0701	.0709	.0709	.0709	.0716	.0709	.0709
24	.0709	.0701	.0709	.0709	.0709	.0709	.0701
Max	.0709	.0716	.0709	.0716	.0716	.0709	.0716
Min	.0678	.0701	.0693	.0701	.0701	.0709	.0693
Avg	.0704	.0707	.0707	.0710	.0709	.0709	.0706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 205 / 11KV TRYAMBKESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.2279	.0492	.1612	.1267	.1509
2	.1254	.2279	.0492	.1612	.1267	.1696
3	.1254	.2279	.0486	.1612	.128	.1696
4	.1254	.2279	.0486	.1595	.128	.1677
5	.1254	.2279	.0492	.1595	.128	.1677
6	.197	.2279	.0486	.1612	.128	.1677
7	.197	.2279	.1595	.1612	.128	.197
8	.16	.2279	.1791	.1612	.128	.2149
9	.1791	.2279	.1791	.1629	.1267	.2126
10	.1791	.2279	.1791	.1595	.128	.2229
11	.197	.2279	.1791	.1595	.2378	.2229
12	.197	.2279	.1791	.1595	.2353	.2254
13	.1267	.1448	.181	.1595	.2328	.2279
14	.1267	.1267	.181	.0709	.2328	.2279
15	.1267	.1267	.1791	.1595	.2328	.2279
16	.1267	.1267	.1791	.1595	.2328	.2279
Max	.197	.2279	.181	.1629	.2378	.2279
Min	.1254	.1267	.0486	.0709	.1267	.1509
Avg	.1525	.2037	.1293	.1548	.1675	.2000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 206 / 11KV Dhadak LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.8453	.1966	.4694	.2984	.3978
2	.7956	.8453	.431	.4475	.2949	.3978
3	.7956	.8453	.5407	.4694	.2949	.3932
4	.7956	.8453	.5182	.5304	.2949	.3978
5	.7956	.8453	.5344	.6371	.2984	.4144
6	.8619	.8453	.5506	.7459	.2984	.4144
7	.8619	.8453	.6802	.8383	.663	.431
8	.8619	.8951	.9069	.8383	.663	.4527
9	.9614	.9614	.3812	.9945	.6962	.4527
10	.9503	.9175	.9614	.9831	.5407	.4862
11	.9503	.9175	.9282	.9831	.663	.4862
12	.9503	.9339	.9614	.9831	.6962	.4752
13	.9503	.9069	.9614	.6882	.8288	.4752
14	.9503	.9069	.9779	.6882	.8288	.4752
15	.9503	.8684	.9614	.6962	.1029	.4588
16	.7537	.7202	.0655	.6962	.4588	.4807
Max	.9614	.9614	.9779	.9945	.8288	.4862
Min	.7537	.7202	.0655	.4475	.1029	.3932
Avg	.8738	.8716	.6598	.7306	.4951	.4431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 201 / 11KV BAGNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.1307	.0905	.0905	2.5987	2.5232	2.2775
2	.1254	.1109	.0905	.0895	2.5987	2.4939	2.1664
3	.1254	.112	.0724	.0914	2.5987	2.5263	2.1664
4	.124	.1109	.0724	.0905	2.6322	2.4966	2.2245
5	.1254	.1109	.0905	.0895	2.6322	2.4669	2.2565
6	.1254	.1307	.1086	.0905	2.7161	2.4985	2.4006
7	.1417	.1307	.128	.1097	2.3472	2.5926	2.3158
8	.1433	.1097	.128	.1075	2.5149	2.4036	2.7161
9	3.0996	3.1493	2.8826	.1086	.1294	.1063	2.7808
10	2.9984	3.083	2.9835	.1086	.112	.0914	3.0178
11		3.1131	3.0521	.0895	.1109	.0554	3.0167
12		3.0333	3.12	.0905	.0739	.0739	2.6452
13		2.9984	3.0178	.0895	.0747	.0686	2.5549
14		2.9675	3.155	.0886	.0739	.0701	2.6467
15		2.967	3.155	.0724	.0747	.0709	2.7109
16	3.219	2.9001	2.9504	.0716	.0924	.0716	2.7042
17	.0739	.0724	.0876	.112	.112	.0709	.0362
18	.0924	.0732		.1086	.1109	.0709	.0914
19	.0934	.0934	.0886	.1086	.1294	.0886	.0924
20	.0924	.1109	.1075	.1294	.1494	.1086	.1326
21	.112	.1097	.1254	.1307	.1478	.1097	.1357
22	.1294	.1097	.1086	.1307	.112	.0924	.1326
23	.1109	.1109	.1097	2.5987	2.5484	2.2939	.1174
24	.1267	.1307	.0914	.0924	2.5987	2.5194	2.3537
Max	3.219	3.1493	3.155	2.5987	2.7161	2.5926	3.0178
Min	.0739	.0724	.0724	.0716	.0739	.0554	.0362
Avg	.5886	1.0820	1.1224	.2037	1.1371	1.0818	1.8205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 202 / 11KV ASHTA CHADOLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0739	.0739	.2195	.25	.7186	.7407
2	.0886	.0732	.0724		.25	.7274	.7099
3	.0857	.0732	.0724		.25	.7274	.7377
4	.0857	.0739	.0732		.25	.7362	.6587
5	.0867	.0924	.0732		.25	.7449	.7209
6	.0886	.0914	.128		.3125	.7611	.8179
7	.1063	.0739	.128		.3048	.779	
8	.0709	.0747	.0924		.2972	.7676	.8535
9	1.0364	.9217	.9282		.0526	.0914	.8993
10	1.0277	1.1248	.8886	.0905	.0358	.0549	.8951
11		1.0802	.9339	.0724	.0543	.0554	.8848
12		1.0437	.9779	.0934	.3109	.0739	.8785
13		.8905	.9339	.0924		.0732	.8648
14		.8025	.9614	.0739		.0732	.779
15		.828	.9339	.0747		.0732	.7865
16	.9878	.8124	.9614	.0747		.0732	.7293
17	.0747	.0716	.0678	.0934	.112	.0732	.0686
18	.0739	.0716		.0934	.1109	.1097	.0686
19	.0934	.0914	.2035	.0934	.1294	.0747	.0876
20	.1109	.1097	.2401	.0566	.112	.1294	.1063
21	.112	.1109	.2454	.0514	.1109	.1294	.1075
22	.0739	.1109	.2481	.1132	.1307	.1109	.1052
23	.0739	.0914	.2328	.7968	.7202	.7786	.0905
24	.0876	.0732	.0914	.2353	.3125	.7116	.7811
Max	1.0364	1.1248	.9779	.7968	.7202	.779	.8993
Min	.0709	.0716	.0678	.0514	.0358	.0549	.0686
Avg	.2344	.3692	.4157	.1453	.2178	.3603	.5814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 203 / 11KV SHIGAON RIVER AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6379	2.5526	2.2542	.852	.0377	.0373	.0373
2	2.6379	2.5232	2.2045	.8619	.0377	.0366	.0377
3	2.6379	2.4939	2.1628	.852	.0377	.037	.0378
4	2.6686	2.4806	2.4905	.852	.0377	.037	.0378
5	2.6686	2.451	2.1792	.8619	.0377	.0373	.0377
6	2.6543	2.5263	2.2374	.852	.0377	.0366	.0373
7	2.713	2.652	2.3102	.8987	.0377	.037	
8	2.6355	2.4939	2.2939	1.0288	.0377	.037	.0377
9	.037	.0377	.0339	.945	2.6825	2.7496	.0366
10	.0373	.037	.0343	2.5819	2.4684	3.0167	.0366
11		.037	.0351	2.8166	2.5301	3.1459	.0366
12		.0366	.0358	2.8502	2.5606	3.083	.0366
13		.0377	.0362	2.934	2.5301	.3681	.0366
14		.0377	.0366	1.9448	2.6235	2.672	.0366
15		.0373	.0366	2.9165	2.652	2.7526	.0366
16	.0373	.0373	.037	2.6825		2.672	.0366
17	.0366	.037	.0366	2.4478	.0373	.037	.037
18	.037	.0373		2.4078	.037	.0374	.0366
19	.037	.0373	.0366	.0332	.037	.0377	.0366
20	.037	.0377	.0366	.0377	.0373	.0377	.0366
21	.037	.0377		.0377	.037	.0373	.0358
22	.0373	.0377	.0362	.0377	.0373	.0328	.0362
23	2.6189	2.2874	.8785	.0377	.0373	.0377	2.3703
24	2.6686	2.5484	2.2611	.8785	.0377	.037	.0373
Max	2.713	2.652	2.4905	2.934	2.6825	3.1459	2.3703
Min	.0366	.0366	.0339	.0332	.037	.0328	.0358
Avg	1.4145	1.0638	.9865	1.3604	.8107	.8771	.1384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 204 / SWARAJYA AGRO INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.037	.0754	.0373	.0554
2			.0362	.0754	.037	.0554
3			.0549	.0754	.037	.0747
4			.0543	.0754		.056
5			.0366	.0754	.037	.056
6			.0554	.0747	.037	.0754
7			.0549	.0739		.0554
8			.0549	.0732		.0724
9			.0554	.0739		.0914
10			.0549	.0747	.037	.1478
11			.0549	.0566	.0189	.0739
12			.056	.0377	.0554	.0183
13			.056	.056	.0554	.0185
14			.0543	.0566	.0554	.0366
15			.0554	.0554	.0739	
16			.0549	.056	.037	
17	.056		.0554	.0554	.0549	
18			.0373	.0747	.0543	
19			.0373	.0554	.0566	
20			.0754		.0566	
21			.0754		.0554	
22		.037	.0754		.0554	
23		.0549	.0754		.0754	
24			.0366	.0754	.037	.056
Max	.056	.0549	.0754	.0754	.0754	.1478
Min	.056	.037	.0362	.0377	.0189	.0183
Avg	.056	.0460	.0539	.0663	.0482	.0629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 205 / 11KV BAGNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3801	.4024	.4024	.4024	.415	.4066	.3841
2	.3761	.3658	.3658	.4024	.415	.4108	.3666
3	.3801	.3696	.3439	.4024	.415	.3696	.3658
4	.3841	.3696	.3475	.3982	.415	.3658	.3658
5	.4066	.3734	.3658	.4207	.415	.3696	.3841
6	.4119	.4108	.4024	.4024	.4481	.4108	.4251
7	.3326	.3734	.3881	.3292	.3881	.3696	
8	.3077	.3696	.3475	.3292	.3258	.3921	.3511
9	.2957	.3881	.4024	.3224	.3511	.4066	.3658
10	.2987	.4024	.4207	.3544	.3511	.4207	.3921
11		.4207	.3881	.3721	.3734	.3849	.3475
12		.4066	.4207	.4075	.3921	.3704	.3292
13		.4024	.4024	.4163	.3696	.3841	.3292
14		.3841	.4435	.4207	.3841	.3841	.4251
15	.3696	.4251	.4207	.4024	.3881	.4024	.4024
16	.4294	.4251	.4024	.3982	.3511	.4024	.4251
17	.439		.462	.4344	.3658	.4024	.4572
18	.4805			.3898	.4066	.4444	
19	.5175	.5304	.4572	.4477	.4668	.5175	.4251
20	.5601	.5729	.5175	.5544	.5175	.5487	.567
21	.5175	.5544	.4755	.5415	.5175	.5487	.5544
22	.4854	.5544	.499	.5228	.5228	.4755	.5487
23	.4435	.5121	.4755	.4904	.5041	.4805	.4805
24	.4207	.4066	.4163	.4251	.415	.4108	.4251
Max	.5601	.5729	.5175	.5544	.5228	.5487	.567
Min	.2957	.3658	.3439	.3224	.3258	.3658	.3292
Avg	.4118	.4282	.4160	.4161	.4131	.4200	.4144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 201 / 11 Kv Ashta Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2033	.1698	.1509	1.8501	1.7341	1.6716
2	.1867	.2054	.1698	.132	1.8501	1.6667	1.6049
3	.168	.2033	.1494	.132	1.8818	1.6049	1.5432
4	.1698	.1867	.1307	.132	1.9134	1.6358	1.5895
5	.1886	.1848	.1663	.1494	1.945	1.7071	1.6975
6	.2614	.2218	.2033	.168	2.0241	1.7985	1.8122
7	.2402	.2427	.2378	.168	2.1664	1.9052	1.8903
8	.2218	.2427	.2172	.1646	2.0216	1.8138	1.929
9	2.234	2.2405	2.4352	.1629	.2033	.1646	1.9753
10	2.2377	2.3845	2.3434	.1791	.2054	.1629	1.9814
11		2.4352	2.2184	.1478	.1829	.1663	1.8364
12		2.2497	2.1715	.1109	.1791	.168	1.8595
13	.108	2.0466	2.1872	.1109	.1595	.1867	1.7071
14	.128	1.9444	2.1403	.1109	.1791	.1867	1.6766
15	.1294	.9755	2.1091	.112	.181	.2054	1.6309
16	.1478	.9755	2.0934	.0934	.1991	.2054	1.5394
17	.1848	.0895		.1307	.1663	.2054	.1463
18	.2195	.1991		.2614	.1663	.2054	.1829
19	.2561	.2402		.2241	.2054	.2241	.2561
20	.2378	.2801	.2801	.2054	.2241	.2427	.2378
21	.2378	.2614	.2801	.2075	.2263	.2263	.2195
22	.2402	.2263	.1886	.2075	.2263	.2263	.2195
23	.2427	.2075	.1509	1.8185	1.7394	1.656	.2054
24	.2075	.2218	.1886	.1509	1.8343	1.781	1.7185
Max	2.2377	2.4352	2.4352	1.8185	2.1664	1.9052	1.9814
Min	.108	.0895	.1307	.0934	.1595	.1629	.1463
Avg	.3835	.7779	.9634	.2263	.9138	.8366	1.2971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 202 / 11KV PATOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8404	1.5684	1.6804	1.2163		.1265	.1326
2	1.8404	1.5684	1.5844	1.1683		.1107	.112
3	1.8884	1.5524	1.5364	1.1043		.1107	.112
4	1.8884	1.5524	1.4883	1.1523		.0474	.128
5	1.9204	1.5844	1.5684	1.2483		.1265	.128
6	1.9044	1.6804	1.7284	1.3283		.1423	.144
7	1.7604	1.9845	1.8404	1.5684		.1581	.16
8	1.7764	1.8564	1.7924	1.5364		.1581	.144
9	.16	.16	.128	1.5043		2.2771	.128
10	.16	.16	.096	1.5524		2.2297	.128
11		.112	.096		1.8564	2.2405	.144
12		.096	.096	2.0005	1.9608	2.1605	.144
13	.096	.096	.096	1.6804	2.1348	2.0005	.128
14	.096	.096	.064	1.5524	2.119	1.9204	.128
15	.096	.096	.096	1.5524	2.0873	1.8884	.128
16	.128	.096	.128	1.5524	1.8501	1.8884	.128
17	.144	.128	.16	.128	1.7394	.128	.144
18	.144	.128		.112	.1423	.144	.112
19	.144	.144	.096		.1581	.144	.128
20	.16	.144	.144		.1581	.16	.16
21	.16	.144	.128		.1423	.16	.16
22	.16	.128	.112		.1265	.144	.176
23	1.6164	1.6324	1.2163		.1265	.128	1.9044
24	1.7924	1.6004	1.6804	1.2643		.1265	.128
Max	1.9204	1.9845	1.8404	2.0005	2.1348	2.2771	1.9044
Min	.096	.096	.064	.112	.1265	.0474	.112
Avg	.9035	.7628	.7633	1.2901	1.1232	.7800	.2095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 203 / 11 KV ASHTA GAOTHAN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0208	.9214	1.0099	.9313	.9745	.9568	.8775
2	.9671	.8859	.9214	.8596	.9568	.9036	.8238
3	.9313	.8859	.8682	.8059	.9391	.8505	.788
4	.8596	.8859	.8328	.788	.9214	.7796	.8059
5	.8596	.7973	.8682	.8238	.9036	.7973	.8596
6	.9313	.8505	.9036	.8775	.8859	.8505	.9313
7	.8954	.9391	.9568	.9134	.9214	.9214	1.0029
8	.8775	.9745	.9922	.9492	.9391	.9391	.985
9	.9134	.9036	1.0454	1.0029	.9036	.9568	.9671
10	.9313	1.2226	1.1517	1.1999	1.0099	1.0277	1.1462
11		1.2757	1.1462	1.3112	1.0454	1.0745	1.2403
12		1.1694	1.1283	1.3112	1.0631		1.134
13	1.0208	1.0808	1.2178	1.2757	1.0099	1.0387	1.1694
14	1.0387	1.0985	1.3611	1.2226	1.0454	1.1104	1.1517
15	1.0745	1.134	1.2403	1.2403	1.0808	1.1641	1.1517
16	1.0387	1.1517	1.0985	1.2403	.9745	1.2178	1.1517
17	.9671	1.1871	1.2934	1.2757	1.0808	1.2536	1.2757
18	1.0631	1.258		1.1163	1.134	1.2536	1.2048
19	1.2048	1.382		1.2048	1.2403	1.2357	1.3112
20	1.2226	1.4529		1.2403	1.3466	1.1999	1.3112
21	1.0277	1.3466	1.2536	1.2757	1.2226	1.1641	1.258
22	.9922	1.2403	1.3073	1.2048	1.0985	1.1283	1.2226
23	.9568	1.1163	1.0745	1.134	1.0631	1.0029	1.0631
24	1.0208	.9391	1.0454	1.0029	1.0631	1.0099	.9313
Max	1.2226	1.4529	1.3611	1.3112	1.3466	1.2536	1.3112
Min	.8596	.7973	.8328	.788	.8859	.7796	.788
Avg	.9916	1.0875	1.0817	1.0920	1.0343	1.0364	1.0735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 204 / 11KV BAWACHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3696	.2829	.2829	.3921	.2829	.3018
2	.3734	.3511	.2427	.2452	.3772	.2452	.2641
3	.4435	.3292	.2241	.2263	.3734	.2075	.2452
4	.4435	.3292	.2587	.2614	.3734	.2263	.2801
5	.4668	.3292	.3109	.3174	.4108	.2987	.3174
6	.4854	.3658	.3658	.3511	.4668	.3547	.3511
7	.4435	.4207	.4163	.4066	.4481	.4108	.3881
8	.2926	.3841	.362	.3658	.3761	.3658	.3292
9	.2865	.3109	.3403	.3109	.2865	.3258	.2926
10	.2865	.3292	.3366	.2172	.3045	.2865	.3077
11		.3077			.2715	.2957	.3224
12		.3045		.362	.2896	.2957	.2865
13		.2835	.3439	.3439	.2507	.2987	.1791
14		.2804	.3511	.3258	.2835	.3174	.2149
15	.3258	.2947	.3292	.3109	.298	.3174	.2507
16	.3258	.3121	.3475	.3109	.2835	.2957	.2865
17	.3077	.2926	.3582	.3475		.2957	.2865
18	.3475	.3511		.3109	.3077	.2957	.3045
19	.3841	.4108	.3761	.3475	.2033	.4108	.3439
20	.439	.4668	.394	.3658	.2241	.4294	.4163
21	.4024	.4294	.4066	.4024	.3921	.415	.3801
22	.3881	.3961	.3921	.3772		.3961	.3439
23	.3921	.3772	.3772	.3772	.2075	.3772	.3142
24	.3547	.3734	.3206	.3206	.3921	.3206	.3206
Max	.4854	.4668	.4163	.4066	.4668	.4294	.4163
Min	.2865	.2804	.2241	.2172	.2033	.2075	.1791
Avg	.3781	.3500	.3398	.3255	.3278	.3236	.3053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 205 / 11 KV BAWACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2054	.1698	.1698	1.4529	1.4661	1.2809
2	.2218	.1848	.1698	.1509	1.4373	1.4043	1.25
3	.2218	.1848	.1494	.1509	1.4373	1.3735	1.1883
4	.2614	.1867	.1494	.1494	1.4529	1.4198	1.2191
5	.2614	.2054	.1663	.168	1.4685	1.448	1.2811
6	.2218	.2241	.2033	.1663	1.4529	1.4937	1.3748
7	.2195	.2241	.2378	.1848	1.7185	1.5699	1.4998
8	.1991	.2054	.2353	.1829	1.6309	1.5394	1.5741
9	1.5741	1.6857	1.821	.181	.1829	.1629	1.6613
10	1.5699	1.8212	1.8827	.1791	.1829	.1791	1.7375
11		1.821	1.929	.2218	.1629	.1433	1.7071
12		1.7747	1.9444	.1991	.181	.1612	1.6156
13		1.6975	1.8519	.2172	.1791	.1829	1.5394
14	.1448	1.6309	1.7284	.2353	.1949	.1848	1.5089
15	.1646	1.6004	1.6716	.2715	.1949	.2054	1.4937
16	.1829	1.6461	1.5623	.3439	.1612	.1867	1.4784
17	.2012	.1463	.1646	.2195	.181	.2241	.1417
18	.2402	.1663		.1829	.1848	.2241	.1772
19	.2587	.2054		.2012	.2033	.2427	.2195
20	.2587	.2241	.2587	.2033	.2241	.2427	.2218
21	.2587	.2263	.1867	.2241	.2054	.2263	.2241
22	.2427	.2075	.1886	.2054	.2075	.2263	.2241
23	.2427	.2075	.1886	1.4842	1.4661	1.2346	.2054
24	.1829	.2241	.1886	.1698	1.4685	1.4969	1.3272
Max	1.5741	1.8212	1.9444	1.4842	1.7185	1.5699	1.7375
Min	.1448	.1463	.1494	.1494	.1612	.1433	.1417
Avg	.3482	.7044	.7749	.2526	.7347	.7183	1.0896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 206 / 11KV Ashta Pump House

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0136	.9328	.8413	.8145	.8779	.8413
2	.8779	1.0136	.8962	.7682	.8145	.8413	.7682
3	.823	1.0242	.8413	.695	.7964	.823	.695
4	.823	.9145	.8048	.6584	.7964	.7682	.6767
5	.8413	.8779	.8596	.6767	.8145	.8048	.7133
6	.8779	.8596	.8962	.7133	.8413	.8596	.7499
7	.823	.8779	.9328	.7682	.8779	.9145	.7682
8	.823	.8413	.9145	.7865	.8596	.8779	.7865
9	.7682	.8413	.9145	.823	.7682	.823	.8048
10		.9145	.9511	.8779	.5853		.8596
11		.9511	.8779	.9328	.8048	.823	.8962
12		.9145	.8413	.8596	.8779	.8779	.9328
13		.8779	.9511	.8962	.8413	.823	.9511
14	.8048	.8596	.9877	.6584	.8596	.8048	.9145
15	.8413	.8779	1.0242	.7316	.8779	.823	.8962
16	.823	.9145	1.0608	.823	.823	.7865	.8962
17	.823	.8779	.9877	.8596	.7865	.823	.9145
18	.9145	.9328		.8413	.8962	.8962	.9511
19	1.0242	1.1016		.9145	.9877	1.0974	1.0242
20	1.1523	1.1706	1.1157	1.0059	1.0974	1.1157	1.1157
21	1.1157	1.1157	1.0425	1.0974	1.134	1.0791	1.0974
22	1.0608	1.0791	1.0425	1.0242	1.0974	1.0242	1.1157
23	1.0608	1.0608	.9877	1.0242	1.0059	.9877	1.0059
24	.9328	1.0059	.9877	.8962	.9145	.9328	.9145
Max	1.1523	1.1706	1.1157	1.0974	1.134	1.1157	1.1157
Min	.7682	.8413	.8048	.6584	.5853	.7682	.6767
Avg	.9063	.9549	.9478	.8406	.8739	.8906	.8871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 201 / 11KV KOREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3961	.415	.4527	.3772	.4294	.4527
2	.415	.3921	.4108	.415	.3772	.4066	.4527
3	.3772	.3921	.3921	.4108	.3772	.4066	.4108
4	.4108	.3921	.4481	.4481	.3772	.4481	.4108
5	.4527	.415	.5175	.4435	.4338	.4854	.4527
6	.5041	.5175	.5544	.5175	.5788	.5175	.5228
7	.462	.5121	.543	.5249	.5487	.4938	.5304
8	.394	.4344	.4207	.443	.443	.3898	.4607
9	.3506	.407	.4115	.4508	.3982	.4161	.4161
10	.3224	.4382	.4681	.4458	.3856	.39	.4681
11		.3856	.4784	.4252	.3601	.3772	.4681
12		.3641	.4382	.4031	.333	.4031	.4508
13		.4075	.443	.4252	.3761	.4075	.4477
14		.4298	.4706		.4119	.4163	.4656
15	.4477	.4525	.4706	.4706	.3898	.4298	.4755
16	.4344	.4344	.4572	.4477	.3856	.4344	.4656
17	.3439	.4207	.4435	.4287	.3856	.4119	.4207
18	.3294	.4115		.3814	.3681	.4334	.4334
19	.4163	.591	.443	.4784	.5249	.4656	.567
20	.6219	.6767	.5973	.6335	.567	.5853	.6283
21	.5914	.6283	.5853	.6099	.5175	.5359	.6283
22		.6161	.5601	.5788	.4854	.5601	.5914
23	.5041	.5228	.4854	.4854	.4481	.5041	.5041
24	.4481	.415	.4338	.4668	.4294	.4294	.4854
Max	.6219	.6767	.5973	.6335	.5788	.5853	.6283
Min	.3224	.3641	.3921	.3814	.333	.3772	.4108
Avg	.4337	.4605	.4734	.4690	.4283	.4491	.4837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 202 / 11KV Bhadurwadi AG
(Koregaon) Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8785	1.5935	1.5043	1.3279	.1372	.1463	.1448
2	1.8461	1.5089	1.5023	1.3123	.1372	.1463	.128
3	1.8244	1.4937	1.5023	1.3279	.1357	.1663	.1294
4	1.8138	1.4449	1.4998	1.2955	.1372	.1663	.1294
5	1.8244	1.4937	1.531	1.2498	.1526	.1663	.1463
6	1.8343	1.6667	1.4937	1.25	.1848	.1663	.1646
7	2.1125	2.0165	1.6821	1.4506	.1829	.197	.1848
8	2.0399	1.8903	1.5851	1.6091	.2012	.2126	.2172
9	.1326	.1492	.1696	1.866	1.8187	1.866	.2012
10	.1402	.197	.1772	2.0241	1.9528	2.1664	.2172
11		.1753	.1463	1.945	1.9841	2.2348	.1612
12		.1715	.1612	2.0325	1.9997	2.0153	.1949
13		.156	.1578	2.0399	1.9685	1.9528	.2012
14		.1402	.1629		1.906	1.9925	.181
15	.1949	.1417	.1629	1.8244	1.6975	1.8747	.181
16	.1791	.1387	.1463	1.7654	1.5546	1.7901	.2012
17	.1791	.1578	.1448	.1355	.0857	.1595	.197
18	.1715	.1772		.1372	.0867	.1595	.1848
19	.2218	.181	.1357	.1738	.1612	.1578	.181
20	.2033	.1867	.1991	.1595	.181	.181	
21	.1663	.1867	.1772	.1448	.1829	.1629	.181
22	.1663	.1848	.1791	.1578	.1646	.1829	.2012
23	1.656	1.4373	1.3592	.156	.1463	.1402	1.692
24	1.8564	1.6804	1.5043	1.3272	.1387	.1463	.1433
Max	2.1125	2.0165	1.6821	2.0399	1.9997	2.2348	1.692
Min	.1326	.1387	.1357	.1355	.0857	.1402	.128
Avg	1.0221	.7737	.7515	1.1614	.7207	.7729	.2419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 203 / 11KV Koregaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0372	.0524	.0412	.0579	.6455	1.6049	1.8244
2	.0383	.04	.0412		.6622	1.6248	1.8244
3	.0394	.041	.0267		.639	1.6091	1.8351
4	.0389	.041	.0255		.6308	1.6129	1.8679
5	.0511	.0373	.0377		.639	1.6129	1.8785
6	.0511	.0572	.0349		.7316	1.6129	1.9364
7	.0564	.0556	.0518		.6554	1.5935	1.9685
8	.0442	.0419	.0412		.5868	1.6091	1.9845
9	2.0525	2.6246	2.4966			.0383	2.1214
10	2.4006	2.5446	2.672	.0389	.0251	.0438	2.0083
11		2.5143	2.8509	.0324	.0381	.0286	2.1765
12		2.4985	2.6886	.052	.0467	.0572	2.1348
13		2.5606	2.5606		.0457	.0486	2.3205
14		2.6397	2.5263		.0613	.0526	2.2885
15	2.1285	2.3805	2.5263		.0572	.0514	2.2085
16	2.4006	2.4741	2.4966	.0514	.0629	.0573	2.2405
17	.0434	.032	.0625	.0171	.0572	.0442	.0434
18	.0343	.0309		.0354	.0503	.0343	.0377
19	.0366	.0446			.0457	.041	
20	.0372	.0457	.088	.0452	.0404	.04	.0533
21	.0349	.0446	.0869	.0474	.0419	.0467	.045
22	.0406	.044	.0987	.044	.0434	.0412	.029
23	.0427	.0429	.0892	.6539	1.5699	1.8122	.0377
24	.0366	.0394	.0423	.0587	.6748	1.6204	1.8785
Max	2.4006	2.6397	2.8509	.6539	1.5699	1.8122	2.3205
Min	.0343	.0309	.0255	.0171	.0251	.0286	.029
Avg	.4823	.8720	.9812	.0945	.3500	.7057	1.5106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 201 / 11 KV ISLAMPUR-I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.848	1.9589	1.8111	1.922	1.9044	1.848
2	1.7924	1.7924	1.885	1.7924	1.848	1.848	1.7741
3	1.7924	1.7924	1.885	1.6095	1.848	1.8111	1.7924
4	1.7551	1.7558	1.885	1.4784	1.848	1.8111	1.7924
5	1.7558	1.7924	1.885	1.4266	1.848	1.8107	1.7741
6	1.7924	1.885	1.9791	1.829	1.9418	1.8671	1.8298
7	1.8111	1.8111	1.9418	1.7924	1.922	1.8671	1.848
8	1.6632	1.8298	1.7741	1.885	1.7193	1.7741	1.7741
9	1.7002	1.7193	1.829	1.848	1.701	1.7372	1.7924
10	2.1357	2.3167	2.371	2.3411	2.1719	2.1582	2.3167
11	1.9185	2.0633	2.1719	2.1216	2.0119	1.8983	2.1216
12	1.5339	2.1216	2.3411	2.1719	2.0144	1.9185	2.2314
13	1.5154	2.0953	2.268	2.2081	2.0485	1.957	2.1582
14	1.6263	2.1948	2.3411	2.2081	2.0698	1.848	2.2805
15	1.5893	2.2131	2.4025	2.2081	2.1253	2.0513	
16	1.5546	2.2177	2.3777	2.2314	2.1437	2.0698	2.6063
17		2.1948		2.2177	1.885	1.9909	2.3777
18	1.9022	2.1216	2.1582	2.0698	2.0328	1.9342	2.3411
19	2.5873	2.6612	2.3045	2.5019	2.3525	2.4253	2.6337
20	2.5873	2.7351	2.4394	2.5873	2.2779	2.4508	2.5972
21	2.4143	2.5503	2.3655	2.4764	2.2546	2.3899	2.5606
22	2.3045	2.5503	2.3525	2.4394	2.3655	2.3152	2.3655
23	2.2546	2.3045	2.2546	2.268	2.2032	2.2405	2.2177
24	2.0119	2.1068	2.0485	2.0328	2.1068	1.9418	1.9959
Max	2.5873	2.7351	2.4394	2.5873	2.3655	2.4508	2.6337
Min	1.5154	1.7193	1.7741	1.4266	1.701	1.7372	1.7741
Avg	1.9032	2.1114	2.1400	2.0648	2.0276	2.0009	2.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 203 / 11 KV LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.9709	.0209	1.0456	.3277	.0579
2	.0343	1.2936	.0048	1.2197	.3239	.0579
3	.0347	1.2936	.0045	1.2197	.3277	.061
4	.0347	1.2936	.0048	1.2197	.3353	.061
5	.0366	1.2936	.0048	1.2197	.3353	.064
6	.0732	1.3306	.0055	1.2567	.3429	.0914
7	.0732	1.3676	.0048	1.2567	.5959	.1311
8	.1478	1.3306	.0048	1.3306	.6089	.1515
9	.1067	1.2567	.0048	1.2567	.6478	.1172
10	.7922	1.2567	.3353	1.2752	.6224	.1174
11	1.3957	1.2382	.4115	1.2197	.8676	.1067
12	1.2936	1.2567	1.2197	1.2567	.8676	.1052
13	1.2936	1.2382	1.2567	1.2567	.7922	.1052
14	1.2752	1.2197	1.2567	1.2567	.7922	.1267
15	1.2936	1.2197	1.2567	1.2567	.6979	.1109
16	.1475	.1269	.08	.3018	.415	.0566
Max	1.3957	1.3676	1.2567	1.3306	.8676	.1515
Min	.0343	.1269	.0045	.3018	.3239	.0566
Avg	.5042	1.1867	.3673	1.1780	.5563	.0951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 204 / 11 KV ISLAMPUR-II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1829	.2218	.2218	.2033	.2241	.168
2	.2218	.1848	.2218	.2195	.2033	.2218	.1494
3	.2241	.1848	.2218	.2195	.2033	.2218	.1494
4	.2241	.1829	.2218	.2218	.2033	.2195	.1494
5	.2218	.1848	.2218	.2195	.2033	.2218	.1494
6	.2218	.2561	.2614	.2195	.2241	.2587	.1509
7	.1848	.2195	.2218	.2218	.2054	.1829	.1494
8	.1848	.2587	.2218	.1848	.1848	.2195	.1478
9	.1829	.1791	.1791	.1867	.1791	.1433	.1448
10	.1595	.1578	.181	.1791	.1646	.1417	.0905
11	.1448	.1791	.1791	.1578	.1629	.1417	.124
12	.1448	.1791	.1949	.1753	.1448	.1791	.1417
13	.1463	.1595	.181	.1753	.1463	.1448	.1402
14	.156	.1612	.181	.1753	.1848	.1417	.1254
15	.1578	.156	.2195	.1772	.1848	.1494	.1433
16	.1734	.156	.1829	.1928	.1848	.1463	.1417
17	.1433	.1629		.1949	.1463	.1433	.1463
18	.1448	.1791	.1829	.1791	.1829	.1753	.1463
19	.2195	.2534	.2218	.197	.2195	.1595	.1478
20	.2561	.2896	.2587	.2507	.2587	.2012	.2241
21	.2957	.2896	.2614	.2587	.2587	.2033	.2241
22	.2587	.3109	.2987	.2772	.2614	.1848	.2241
23	.2561	.2926	.2587	.2587	.2614	.1848	.1867
24	.2587	.2195	.2614	.2218	.2195	.2241	.1663
Max	.2957	.3109	.2987	.2772	.2614	.2587	.2241
Min	.1433	.156	.1791	.1578	.1448	.1417	.0905
Avg	.2002	.2075	.2198	.2077	.1996	.1848	.1555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 205 / 11 KV ISLAMPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0377	.1467	.1783	.1852	.0373
2	.0362	.0377	.0377	.1467	.1635	.1852	.0373
3	.0179	.037	.0377	.1467	.1635	.1852	.0377
4	.0179	.037	.0377	.1486	.1635		.0377
5	.0185	.0377	.0377	.1783	.1783	.1875	.0377
6	.0179	.0377	.0377	.1783	.2439	.2846	.0377
7	.0358	.0566	.056	.208	.3437	.3163	.0566
8	.0358	.056	.056	.2378	.3281	.3163	.056
9	.3749	.4111	.4062	.0373	.0377	.0373	.3437
10	.4111	.4534	.4641	.0373	.0373	.037	.427
11	.3906	.4858	.5182	.0373	.0554	.037	.4481
12	.3704	.4481	.4801	.037	.0373	.0373	.4428
13	.3658	.4001	.4062	.037	.0554	.0373	.4801
14	.3549	.4062	.3749	.037	.0554	.0373	.4161
15	.3704	.3749	.421	.0373	.0373	.037	.4062
16	.3521	.3749	.3658	.0373	.0377	.0377	.3749
17	.3521	.0554		.0373	.0373	.037	.0343
18	.0358	.0554	.0358	.0185	.056	.0362	.0343
19	.0366	.056	.0366	.0373		.0366	.0343
20	.0373	.056	.0373	.0566	.0373	.056	.0343
21	.0373	.056	.0373	.0566	.037	.056	.0347
22	.0377	.056	.0377	.0566	.037	.056	.0347
23	.0377	.056	.208	.1783	.1562	.056	.0347
24	.0358	.0373	.0377	.1783	.1783	.1875	.0373
Max	.4111	.4858	.5182	.2378	.3437	.3163	.4801
Min	.0179	.037	.0358	.0185	.037	.0362	.0343
Avg	.1644	.1717	.1828	.0962	.1155	.1078	.1648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 206 / 11 KV Peth Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1867	.2218	.5944	1.0105	.9145	.1663
2	.208	.1848	.2218	.5944	1.0105	.9145	.1663
3	.208	.1848	.2218	.5944	1.0105	.8642	.1663
4	.208	.1867	.2218	.5944	1.0105	.8535	.1663
5	.1715	.2218	.2218	.602	1.07	.9259	.168
6	.208	.2218	.2614		1.5051	1.4373	.2241
7	.2454	.2957	.2587		2.0622	1.8747	.2561
8	.2103	.2987	.2561	.602	1.8747	1.8747	.1829
9	2.5606	2.2222	2.3122	.1989	.1734	.1372	.9374
10	2.4996	2.5301	2.3457	.2035	.1886	.1989	2.8121
11	2.3122		2.284	.1753	.1402	.1448	1.9372
12	2.0729	2.1247	2.0729	.1696	.1417	.2149	2.5301
13	1.9265	1.9204	1.7833	.1696	.1494	.1463	2.3685
14	2.1247	1.8343	1.6049	.1715	.1791	.1448	2.2138
15	1.8564	1.8747	1.7238	.1753	.1433	.1509	2.1506
16	1.8663	1.89	1.8427	.2035	.2149	.1509	2.1765
17	.1753	.1966		.2774	.2149	.1658	.2058
18	.1433	.2012		.2454	.2172	.1943	.2058
19	.1829	.2454		.2103	.2172	.2035	.208
20	.2587	.2534		.2507	.2172	.2561	.2454
21	.2587	.2534		.2561	.2195	.2561	.2454
22	.2241	.2561		.2561	.2241	.2195	.2103
23	.2241	.2195		1.3375	.9755	.2195	.2103
24	.2058	.1867	.2218	.6371	1.3375	.9755	.1663
Max	2.5606	2.5301	2.3457	1.3375	2.0622	1.8747	2.8121
Min	.1433	.1848	.2218	.1696	.1402	.1372	.1663
Avg	.8565	.7822	1.0633	.3872	.6462	.5599	.8467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 401 / 33KV GANESH NAGAR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6863	2.6337	2.8532	2.7984	2.7435	2.7984	2.3594
2	2.572	2.5503	2.7435	2.6337	2.5149	2.8275	2.2262
3	2.4577	2.384	2.6886	2.524	2.6292	2.7721	2.2497
4	2.4006	2.384	2.6886	2.5789	2.7435	2.7166	2.3045
5	2.3434	2.4949	2.7984	2.7435	3.0293	2.7721	2.4394
6	2.6863	2.5789	2.9127	2.963	3.315	3.0727	2.524
7	2.7435	2.3594	2.6886	2.8532	3.2579	3.0178	2.4143
8	2.5149	2.4143	2.6886	3.095	3.2007	2.8532	2.4143
9	3.4551	3.2922	3.7723	2.3891	2.0633	2.0576	3.0178
10	3.4551	3.8958	3.8295	2.5789	2.3594	2.1719	3.4922
11	2.0851	3.786	3.6008	2.4691	2.3594	2.2862	3.5117
12	1.9204	3.6214	3.6008	2.5252	2.4691	2.2862	3.4568
13	3.2156	3.6763	4.0009	2.5252	2.4143	2.2862	3.6214
14	3.2156	3.6763	3.9438	2.524	2.5789	2.2862	3.6214
15	2.8532	3.5665	3.9438	2.524		2.3434	3.3848
16	3.4568	3.6763	3.7151	2.6326	2.6057	2.5149	3.546
17	2.3348	2.7984	.2715	2.7435	2.3594	2.3102	2.6292
18	2.2028	2.5789	1.6461	2.3434	2.2497	2.3891	2.8578
19	2.963	3.3471	2.9864	3.315	2.8532	2.8532	3.2007
20	3.4019	3.7146	3.4019	3.1436	3.2373	3.0178	3.2007
21	3.2373	3.6037	3.1493	3.1436	3.1276	2.9081	3.7723
22	3.0727	3.4374	3.1824	3.1436	3.0178	2.8235	2.8578
23	2.963	3.3819	3.3471	3.1436	3.0178	2.7984	2.915
24	2.6292	2.6337	3.0178	3.0178	3.3722	2.8532	2.5789
Max	3.4568	3.8958	4.0009	3.315	3.3722	3.0727	3.7723
Min	1.9204	2.3594	.2715	2.3434	2.0633	2.0576	2.2262
Avg	2.7861	3.1036	3.0613	2.7647	2.7617	2.6257	2.9415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.226	.8676	1.0185	.9431	1.3014	1.1317	1.2826
2	1.226	.8676	1.0185	.9431	1.3014	1.1317	1.2826
3	1.226	.8676	1.0185	.9431	1.3014	1.1317	1.2826
4	1.226	.8676	1.0185	.9431	1.3014	1.1317	1.2826
5	1.226	.8676	.9054	.9431	1.3203	1.1317	1.2826
6	1.2449	.8676	.9619	.9431	1.3392	1.1317	1.1694
7	1.2071	.8676	1.0185	1.0562	1.2449	1.1317	1.1694
8	.8048	.8676	1.0185	.9431	1.3014	1.1694	1.2437
9	.5079	1.3169	1.2826	1.1694	1.5466	1.5089	1.4712
10		1.4335	1.8107	1.8484	1.8484	1.6461	1.9993
11	.6516	1.6598	1.8107	1.8484	2.0748	1.8107	2.0182
12	.5441	1.6598	1.7353	1.5655	2.1691	1.8861	2.037
13	.4115	1.5089	1.7353	1.3957	2.1125	1.5466	1.9239
14	.4268	1.6975	1.5844	1.5089	2.0748	1.8107	1.9239
15	.4531	1.6975	1.5844	1.6221	2.037	1.4335	1.8861
16		1.6598	1.5844	1.7918	2.0748	1.4712	1.8861
17	.5487	1.5844	1.5089	1.773	1.8484	1.4712	1.8861
18	.5639	1.3203	1.2826	1.6598	1.6975	1.4335	1.6598
19	.5487	1.3203	1.226	1.6032	1.1317	1.4335	1.1317
20	.5668	.9431	1.0374	1.3203		1.3535	1.1317
21	.6516	1.0374	1.2449	1.2637	1.0185	1.358	1.3203
22	.7167	1.0374	1.2449	1.2826	1.0374	1.358	1.3203
23	.7356	1.0562	1.2449	1.5089	1.2637	1.4146	1.3203
24	1.4712	.6979	1.0562	.9808	1.2637	1.2071	1.2437
Max	1.4712	1.6975	1.8107	1.8484	2.1691	1.8861	2.037
Min	.4115	.6979	.9054	.9431	1.0185	1.1317	1.1317
Avg	.8266	1.1905	1.2897	1.3250	1.5483	1.3848	1.5065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV SAKHRALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1886	.1829	.2195	.2195	.2195	.1829
2	.2263	.1867	.1829	.2195	.2195	.2195	.1829
3	.2263	.1867	.1867	.2195	.2195	.2195	.1829
4	.2263	.1886	.1829	.2195	.2195	.2195	.1829
5	.2263	.1886	.2561	.2561	.2561	.2241	.2378
6	.2641	.2641	.2561	.2743	.2743	.2641	.2743
7	.2561	.2987	.2195	.2561	.3142	.3018	.2195
8	.2012	.2218	.2218	.2195	.1848	.2054	.1829
9	.2012	.1646	.2218	.2012	.2012	.1848	.1829
10		.1646	.4087	.2561	.1991	.1646	.1829
11	.1433	.1646	.4024	.2149	.1791	.1646	.1829
12	.1227	.1829	.4024	.2149	.1791	.1829	.1829
13	.1595	.1829	.4024	.197	.1753	.1829	.2012
14	.1753	.1829	.4024	.2149	.1734	.1829	.2012
15	.1753	.1829	.439	.2149	.1753	.1829	.1829
16		.1829	.439	.2507	.1949	.1829	.1829
17	.1387	.1829	.2195	.2172	.1753	.1867	.1829
18	.1772	.1829		.2012	.1772	.1829	.1829
19	.2715	.2561			.2012	.1829	.3292
20	.3395	.3292	.3475	.3109	.3174	.1829	.3292
21	.3018	.3292	.3395	.2743	.2829		.3292
22	.3174	1.0374	.3018	.2926	.2829	.2561	.2743
23	.2427	.2195	.2561	.2561	.2614	.2667	.2561
24	.2263	.2263	.2195	.2195	.4756	.2195	.2195
Max	.3395	1.0374	.439	.3109	.4756	.3018	.3292
Min	.1227	.1646	.1829	.197	.1734	.1646	.1829
Avg	.2201	.2457	.2950	.2357	.2316	.2078	.2187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV BAHE AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.9488	1.0814	.0189	.0189	.0189	.7682
2	1.0082	.9488	1.0814	.0189	.0189	.0189	.7682
3	1.0082	.9374	1.0814	.0189	.0189	.0189	.7682
4	.9602	.9602	.9831	.0189	.0189	.0189	.7682
5	.9122	.9374	.9831	.0189	.0189	.0189	.7682
6	1.0082	1.0311	1.0562	.0189	.0189	.0189	.9602
7	1.1523	1.0311	1.1523	.0189	.0189	.0189	1.0562
8	1.2146	1.0311	1.1523	.0189	.0189	.0189	1.0883
9	.0189	.0171	.0171	1.0562	1.2483	1.1888	.016
10		.0171	.0189	1.2483	1.3283	1.2803	.016
11	.0189	.0171	.0189	1.2483	1.2483	1.3443	.016
12	.0189	.0171	.0189	1.2483	1.2003	1.1523	.0189
13	.0189	.0171	.0189	1.2483	1.1248	1.1523	.016
14	.0189	.0171	.0189	1.0562	1.1248	1.1523	.016
15	.0189	.0171	.0189	1.1523	1.0311	1.0562	.0189
16	.0189	.0171	.0189	1.1174	1.0437	1.0562	.0189
17	.0189	.0171	.0189	.0189		.0171	.0189
18	.0189	.0171	.0189	.0189		.0171	.0189
19	.0189	.0189	.0189	.0189		.0171	.0189
20	.0189	.0171	.0189	.0189	.0189	.0171	.0189
21	.0189	.0171	.0189	.0189	.0189	.0171	.0189
22	.0189	.0171	.0189	.0189	.0189	.0171	.0189
23	.9374	.9831	.0189	.0189	.0189	.8002	.8539
24	1.0082	.9374	1.0814	.0189	.0189	.0189	.7956
Max	1.2146	1.0311	1.1523	1.2483	1.3283	1.3443	1.0883
Min	.0189	.0171	.0171	.0189	.0189	.0171	.016
Avg	.4549	.4162	.4139	.4032	.4569	.4357	.3686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV DUDH SANGH FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3772	.3961	.3772	.4527	.3772	.4024
2	.4527	.3772	.3961	.3772	.4527	.3772	.4191
3	.4527	.3772	.3961	.3772	.4527	.3772	.4191
4	.4527	.3772	.3961	.3772	.4527	.3772	.4191
5	.5093	.3772	.3772	.3772	.4527	.3772	.4001
6	.3961	.3772	.3584	.3772	.415	.3772	.3395
7	.3772	.3395	.3584	.3772	.3961	.3772	.3395
8	.3961	.415	.3584	.3772	.415	.3395	.3772
9	.4715	.4527	.5487	.5658	.5658	.415	.4715
10		.6036	.679	.6979	.6413	.5281	.5975
11	.5658	.679	.7922	.7545	.7545	.6036	.6722
12	.5658	.679	.7922	.7922		.6036	.6722
13	.5281	.679	.7922	.7922	.7545	.6036	.5975
14	.4904	.5853	.6224	.679	.7545	.5487	.5975
15	.4904	.6036	.6224	.679	.7545	.5093	.6161
16	.4527	.6036	.6224	.6224	.5658	.5658	.6161
17	.4527	.6036	.4715	.6413	.5658	.5658	.6224
18	.4527	.4527	.4715	.6413	.5281	.5658	.6224
19	.4527	.4527	.5093	.5658	.5281	.5658	.6979
20	.4527	.4527	.5093	.5093	.5658	.5281	.6979
21	.4715	.415	.5658	.5093	.5658	.5281	.679
22	.415	.4191	.5658	.547	.5658	.5281	.679
23	.415	.415	.5658	.5281	.4715	.415	.679
24	.4527	.3772	.3961	.415	.415	.3772	.3841
Max	.5658	.679	.7922	.7922	.7545	.6036	.6979
Min	.3772	.3395	.3584	.3772	.3961	.3395	.3395
Avg	.4617	.4788	.5235	.5399	.5429	.4763	.5424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV NAGARPALIKA PW

NON SHEDDABLE WATER SUPPLY AND

FEEDER Feeder KV- 11 /

UTILITY

OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3961	.415	.3772	.3772	.415
2	.3772	.3772	.3961	.415	.3772	.3772	.415
3	.3772	.3772	.3961	.415	.3772	.3772	.415
4	.3772	.3772	.3961	.415	.3772	.3772	.4024
5	.3772	.3772	.3961	.415	.3772	.3772	.3772
6	.3584	.4527	.4527	.415	.4338	.3772	.4904
7	.4527	.4527	.4527	.415	.4338	.4338	.4338
8	.4527	.4715	.4527	.415	.4527	.4338	.4207
9	.4527	.4527	.4527	.415	.3772	.4338	.4338
10		.4527	.4527	.4904	.4715	.439	.4527
11	.4904	.4527	.4527	.4527	.4715	.4715	.415
12	.4527	.4527	.415	.4338	.4904	.4527	.415
13	.3772	.4527	.415	.4527	.4527	.415	.4527
14	.415	.4527	.415	.4527	.4527	.4024	.4527
15	.415	.4527	.4527	.4527	.4527	.415	.4527
16	.415	.4527	.4527	.4527	.4715	.4527	.4527
17	.3395	.4527	.415	.4904	.415	.4527	.4527
18	.3772	.4527	.415	.4527	.3772	.415	.415
19	.3395	.4338	.3018	.3258	.3395	.415	.3018
20	.3395	.3395	.3018	.2896	.2561	.2829	.2829
21	.2534	.2641	.2263	.2715	.2058	.2829	.3018
22	.216	.2641	.2263	.2658	.2058	.2829	.3772
23	.2401	.2641	.2641	.2715	.216	.3018	.415
24	.3772	.3772	.3841	.415	.3772	.3772	.415
Max	.4904	.4715	.4527	.4904	.4904	.4715	.4904
Min	.216	.2641	.2263	.2658	.2058	.2829	.2829
Avg	.3761	.4055	.3909	.4044	.3850	.3926	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV KAPUSKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1886	.1829	.1886	.2012	.1463	.1663
2	.1867	.1886	.1829	.1886	.2012	.1463	.1646
3	.1867	.1886	.1829	.1886	.2012	.1463	.1646
4	.1867	.1886	.1772	.1829	.2012	.1463	.1646
5	.2054	.1867	.2012	.2195	.2195	.1848	.1829
6	.2452	.2641	.2195	.2561	.2561	.2241	.2195
7	.2378	.2241		.2195	.2218	.2075	.1848
8	.197	.128	.2012	.1829	.2195	.1848	.1829
9	.1646	.1463	.2012	.1829	.1646	.128	.128
10		.1463	.1463	.1433	.1417	.1463	.1463
11	.1387	.1463	.1463	.1402	.1753	.1463	.1463
12	.1052	.1595	.1463	.1402	.1907	.1463	.1463
13	.124	.1829	.1463	.1402	.1753	.1463	.1463
14			.1829	.1543	.1753	.1463	.1463
15	.1433	.1829	.1829	.1543	.1753	.1463	
16	.1417	.1829	.1829	.1227	.1772	.1417	
17	.1254	.1829	.1829	.1629	.1433	.1417	.1829
18	.124	.2195	.1829	.1991	.124	.1646	.1829
19	.1991	.2195	.2195	.2328	.181	.2195	.2561
20	.2801	.2641	.2195	.2926	.2614	.1372	.2561
21	.2263	.2561	.2195	.2926	.2641	.2561	.2561
22	.2075	.2378	.1829	.2641	.2263	.2195	.3772
23	.1867	.2195	.1829	.2195	.1867	.1829	.2195
24	.1867	.168	.1829	.1829	.2012	.1646	.1646
Max	.2801	.2641	.2195	.2926	.2641	.2561	.3772
Min	.1052	.128	.1463	.1227	.124	.128	.128
Avg	.1812	.1944	.1850	.1938	.1952	.1675	.1902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 207 / 11 KV SAKHRALE AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0149	.0171	.0171	.4858	.6878	.6036	.0171
2	.0149	.0171	.0171	.4858	.6878	.6036	.0171
3	.0149	.0171	.0171	.4858	.6878	.5853	.0171
4	.0149	.0171	.0171	.4858	.6516	.5853	.0171
5	.0141	.0171	.0171	.4858	.6653	.6036	.0171
6	.0135	.0171	.0171	.3932	.6241	.6173	.0171
7	.017	.0171	.0171	.4534	.7087	.679	.0171
8	.0168	.0171	.0171	.3887	.7356	.679	.0171
9	.8676	.8642	.9282	.0189	.0179	.0171	.8573
10		.9282	1.0059	.0181	.0183	.0171	.9922
11	.8589	.9175	.9602	.0171	.0181	.0171	.9922
12		.852	.9282	.0171	.0181	.0171	.9922
13	.8215	.852	.8322	.0166	.0177	.0171	.9709
14	.8299	.852	.7956	.0168	.0175	.0171	.9709
15	.8299	.852	.7362	.0175	.0171	.0171	.9709
16	.8299	.7865	.7042	.0171	.0171	.0171	.8215
17	.0189	.0171	.0189	.0168	.0187	.0171	.0189
18	.0187	.0171	.0189	.0185	.0185	.0171	.0189
19	.0187	.0171	.0189		.0171	.0171	.0189
20	.0175	.0171	.0189	.0162	.0187	.0171	.0189
21	.0171	.0171	.0189	.0152	.0171	.0171	.0189
22	.0171	.0171	.0189	.0151	.0171	.0171	.0189
23	.0171	.0171	.4858	.6878	.5658	.0171	.0189
24	.0149	.0171	.0171	.4858	.7059	.6036	.0171
Max	.8676	.9282	1.0059	.6878	.7356	.679	.9922
Min	.0135	.0171	.0171	.0151	.0171	.0171	.0171
Avg	.2409	.2991	.3185	.2200	.2904	.2424	.3273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 209 / 11 KV Siddhanath LIS
feeder Feeder KV- 11 /
OUTGOING

PURELY LIS FEEDERS

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.2949	.2949	.3361	.2987	.2881
2	.0655	.3277	.3395	.3361	.2987	.2881
3	.0655	.3277	.2949	.3361	.2987	.2881
4	.0655	.3277	.2949	.3361	.2987	.2881
5	.0655	.3277		.3361	.2987	.2881
6	.0655	.1311	.2949	.3361	.2987	.2881
7	.0655	.2561	.2622	.3174	.2987	.2881
8	.1989	.2561	.2622	.3361	.2987	.2401
9	.3277	.3018	.2949	.3547	.3361	.2401
10	.3277	.2561	.3292	.3149	.2949	.2241
11	.2949	.3395	.3547	.3149	.2881	.0187
12	.2949	.2984	.3547	.3149	.2949	.0187
13	.2949	.2984	.3547	.3149	.2949	.0187
14	.2949	.2984	.3547	.3149	.0983	.0187
15	.2949	.2984	.3547	.3149	.0492	.0187
16	.2458	.2984	.3547	.3149		.0187
Max	.3277	.3395	.3547	.3547	.3361	.2881
Min	.0164	.1311	.2622	.3149	.0492	.0187
Avg	.1865	.2899	.3197	.3268	.2697	.1771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 401 / 33 KV EXPRESS FEEDER
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.7147	1.6004	1.8107	1.6409	1.829	1.7147
2	1.8107	1.7147	1.6004	1.8107	1.6975	1.829	1.7147
3	1.8107	1.7147	1.6004	1.8107	1.6975	1.829	1.7147
4	1.8107	1.7147	1.6004	1.8107	1.6975	1.829	1.7147
5	1.6409	1.7147	1.829	1.8107	1.6975	1.829	1.6575
6	1.5844	1.5432	1.829	1.8107	1.6409	1.829	1.7718
7	1.6975	1.7147	1.829	1.8107	1.6409	1.7147	1.7147
8	1.4712	1.7147	1.829	1.8107	1.4712	1.7718	1.829
9	1.4712	1.7147	1.829	1.8107	1.8107	1.829	1.829
10		2.0576	2.037	1.7541	2.0576	1.9433	1.9239
11	1.4861	2.0576	2.037	1.9239	2.0576	2.0005	1.9805
12	1.6004	2.0576	2.037	1.9805	2.1148	1.9433	2.037
13	1.3717	2.0576	2.037	1.8107	2.0576	1.9433	1.8107
14	1.4861	2.0576	2.037	2.037	2.0576	1.9433	1.8107
15	1.6004	2.0576	2.037	2.037	2.0576	1.9433	1.8107
16	1.6004	2.0576	1.9239	2.0936	2.0576	1.829	1.8107
17	1.3717	1.9433	1.9239	1.9239	1.9433	1.829	1.8107
18	1.4861	1.9433	1.9239	1.6409	1.829	1.7147	1.8107
19	1.3717	1.829	1.9239		1.829	1.7147	1.8107
20	1.4289	1.7147	1.9239	1.8107	1.7147	1.6575	1.8107
21	1.6004	1.7147	1.9239	1.7541	1.829	1.7147	1.8107
22	1.6004	1.7147	1.9239	1.6975	1.829	1.7147	1.8107
23	1.7147	1.829	1.9239	1.6975	1.8861	1.829	1.8107
24	1.8107	1.7147	1.7147	1.9239	1.6975	1.9433	1.829
Max	1.8107	2.0576	2.037	2.0936	2.1148	2.0005	2.037
Min	1.3717	1.5432	1.6004	1.6409	1.4712	1.6575	1.6575
Avg	1.5929	1.8361	1.8698	1.8427	1.8339	1.8314	1.8062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 201 / 11 KV RHX & TAKARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.7167	.7095		.6979	.6979	.679
2	.7167	.7167	.7167	.5041	.6979	.6979	.679
3	.7167	.7167	.7167	.5093	.6979	.6908	.679
4	.7356	.7282	.7356	.5093	.7167	.7095	.6979
5	.7545	.7655	.7392	.5601	.7545	.7545	.7545
6	.7922	.8048	.7602	.6161	.8402	.7922	.8215
7	.7023	.8215	.7619	.5068	.823	.7655	.8501
8	.7265	.811	.7628	.5415	.7619	.7655	.7522
9	.6733		.7973	.5658		.679	.691
10	.7059	.7712	.7537	.5258	.7602	.703	.6805
11		.8059	.7783	.5068	.7316	.7087	.7059
12		.7282	.7499	.6268	.724	.7011	.7522
13		.7362	.7522	.7973	.6556	.7164	.7442
14		.6241	.7783	.7602	.7316	.7059	.7796
15		.6836	.8048	.7701	.724	.7265	.7701
16		.7087	.7421	.8328	.7265	.7455	.7783
17	.2534	.7461		.7265	.6401	.7712	.7655
18	.9511	.7459		.8669	.6908	.7712	.7499
19	1.086	.8478	.9335	.9671	.8676	.8596	.8775
20	1.086	1.0454	1.0642		1.0136	1.0974	.9877
21	.9593	1.0242	.9231	1.0164	.9015	.961	.9231
22	.9328	.9328	.8962	.9896	.905	.8962	.9328
23	.8688	.8215	.7842	.8962	.7922	.8215	.7655
24	.7356	.7059	.7655	.7167	.7282	.6908	
Max	1.086	1.0454	1.0642	1.0164	1.0136	1.0974	.9877
Min	.2534	.6241	.7095	.5041	.6401	.679	.679
Avg	.7841	.7830	.7921	.6960	.7645	.7679	.7747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 202 / 11 KV TAKARI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0934	.0943		.5937	.6009	.1132
2	.0943	.0934	.0943	.4481	.5937	.6009	.0943
3	.0943	.0943	.0943	.4588	.5937	.5937	.0943
4	.0943	.0943	.0943	.4915	.6167	.6093	.0943
5	.0943	.0943	.0943	.5121	.6249	.6483	.1132
6	.1132	.1307	.1132	.5735	.6636	.6882	.132
7	.1509	.1509	.132	.6882	.8907	.8482	.132
8	.1132	.1494	.132	.7449	.8539	.9069	.1509
9	1.2407	.1494	1.2176	.1132		.0943	1.1363
10	1.3108	1.4419	1.3603	.0943	.0934	.1132	1.278
11		1.3923	1.4243	.1132	.0566	.1132	1.1822
12		1.3916	1.3927	.1132	.112	.1132	1.2163
13		1.3916	1.2334	.0943	.1132	.132	1.2803
14		1.3283	1.2125	.1132	.0934		1.3108
15		1.2967	1.3927	.1132	.0934	.132	1.2631
16		1.2498	1.0242	.1132	.0943	.132	1.2163
17	.1307	.0754		.1132	.0747	.1132	.1132
18	.1698	.1132		.1132	.1509	.0943	.1307
19	.1494	.132	.1132	.1132	.1132	.1509	.1509
20	.1509	.132	.112	.1132	.112	.132	.1307
21	.1509	.132	.0943	.1132	.132	.132	.1132
22	.1307	.1132	.0943	.0943	.112	.132	.112
23	.1307	.1132	.5735	.6325	.5937	.132	.1132
24	.0943	.1132	.0934	.6882	.6173	.6722	.1132
Max	1.3108	1.4419	1.4243	.7449	.8907	.9069	1.3108
Min	.0943	.0754	.0934	.0943	.0566	.0943	.0943
Avg	.2504	.4778	.5540	.2942	.3475	.3428	.4910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 203 / 11 KV RETHRE HARNAX AG SEPARATED AG FEEDERS HAVING SPECIAL
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499	.8905	1.17		.0709	.0716	.8097
2	.7499	.8796	1.0648	.0693	.0716	.0709	.8097
3	.7499	.8796	1.1111	.0724	.0716	.0709	.8192
4	.7562	.9282	1.2186	.0701	.0709	.0701	.852
5	.7716	.9061	1.2654	.0693	.7087	.0876	.8745
6	.8179	1.0402	1.2963	.0693	.0701	.0716	1.0911
7	1.0494	1.3108	1.3279	.0724	.1029	.0867	1.2631
8	1.0185	1.1523	1.2963	.1097	.12	.0886	1.1405
9	.081		.0857	1.1523		1.3763	.061
10	.1029	.0686	.0876	1.1069	1.5074	1.3441	.0701
11		.0829	.0867	1.1683	1.5061	1.4089	.0693
12		.0663	.0857	1.2308	1.4413	1.3125	.0716
13			.0876	1.1843	1.3763	1.1385	.0905
14		.0648	.0857	1.2163	1.3441	1.0957	.0876
15		.0819	.0867	1.2018	1.2955	1.0802	.0895
16		.0663	.1029	1.2029	1.1797	1.0669	.1086
17	.081	.0648		.064	.0895	.0671	.1086
18	.0663	.0663		.0949	.1052	.0663	.1097
19	.0857	.081	.0701	.0983	.0886	.0848	.1086
20	.081	.1017	.104		.104	.0857	.1052
21	.1029	.0857	.1029	.1063	.0905	.0876	.128
22	.1029	.1006	.104	.0886	.0895	.0709	.1075
23	.7907	1.1363	.1052	.0886	.0905	.7682	.6642
24	.7468	.9217	1.0936	.0857	.0709	.0716	.7773
Max	1.0494	1.3108	1.3279	1.2308	1.5074	1.4089	1.2631
Min	.0663	.0648	.0701	.064	.0701	.0663	.061
Avg	.4947	.4989	.5472	.4828	.5072	.4893	.4340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 204 / 11KV Bhavaninagar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4374	.4531	.0065	.0072	.4481	.4973
2	.4744	.4902	.0103	.0072	.4915	.5304
3	.4915	.4902	.0103	.0072	.4915	.5365
4	.5138	.5079	.012	.0076	.4801	.5304
5	.5079	.5079	.012	.0069	.4858	.5304
6	.4961	.4961	.012	.0065	.02	.5182
7	.502	.502	.008	.0065	.4961	.5182
8	.4961	.4961	.0076	.0069	.5243	.5182
9		.502	.0076		.502	.5121
10	.5304	.4801	.0069	.502	.506	.5182
11	.5304	.5079	.0072	.4961	.5121	.4096
12	.5121	.5121	.0072	.5079	.0734	.5121
13	.5121	.427	.0069	.502	.3906	.5243
14	.5121	.5121	.0065	.4961	.4475	.5121
15	.506	.5182	.0065	.5079	.506	.5243
16		.5243	.0069	.4961	.506	.3812
24		1.0936				
Max	.5304	1.0936	.012	.5079	.5243	.5365
Min	.4374	.427	.0065	.0065	.02	.3812
Avg	.5016	.5306	.0084	.2376	.4301	.5046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 201 / 11 KV BAHE GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2241	.2402	.2241	.2378	.2378	.2587
2	.2378	.2218	.2378	.2241	.2402	.2328	.2587
3	.2353	.2195	.2353	.2241	.2427	.2353	.2772
4	.2402	.2587	.2402	.2614	.2402	.2534	.3142
5	.2743	.2926	.2801	.2987	.2743	.2743	.3326
6	.3142	.3326	.3326	.3361	.3881	.3142	.3547
7	.2353	.2865	.2743	.3326	.2896	.3045	.3142
8	.208	.2427	.2279	.2686	.2427	.298	
9	.1989	.2035	.2058	.2481	.2254	.2374	
10	.1581	.2347	.2401	.2012	.2058	.2012	
11	.218	.2155	.2401	.2204	.2229	.1715	
12	.1311	.218	.2204		.2204	.2401	
13	.1715	.2254	.2454	.2254	.2454	.2427	.2947
14	.2279	.2303	.2507	.2658	.2507	.2774	.3012
15	.2254	.2303	.2481	.2658	.2507	.2629	.298
16	.2058	.2427	.2454	.2774	.2103	.2629	.2947
17	.208	.218		.213	.1734	.2427	.2713
18	.2204	.2294	.2374	.2204	.2103	.2279	.2883
19	.2481	.2254	.2774	.3155	.2629	.2279	.2947
20	.3109	.3077	.3045	.3366	.3109	.3045	.3224
21	.2926	.3077	.2957	.3292	.3086	.3077	.362
22	.3142	.3142	.2801	.2957	.3326	.2957	.3142
23	.2772	.2614	.2241	.2614	.2772	.2772	.2614
24	.2378	.2241	.2427	.2241	.2402	.2427	
Max	.3142	.3326	.3326	.3366	.3881	.3142	.362
Min	.1311	.2035	.2058	.2012	.1734	.1715	.2587
Avg	.2346	.2486	.2533	.2639	.2543	.2572	.3007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 202 / 11 KV KHARATWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2006	.1107	.0762	
2				.1852	.1094	.0772	
3				.1852	.112	.08	
4				.1852	.1107	.0772	
5				.1852	.125	.0762	
6				.1543	.1406	.0753	
7				.1852	.1423	.1054	
8				.2187	.1718	.1562	
9	.4531	.4999	.5535				
10	.4365	.5468	.6325				
11	.4843	.5851	.6718				
12	.4902	.5468	.6241				
13	.4902	.5155	.5761				.2623
14	.4801	.5121	.5668				.3005
15	.4801	.4902	.5218				.3887
16	.4374	.4961	.4902				.4001
17				.0141			
23			.1932		.1097		
24				.2006	.112	.0743	
Max	.4902	.5851	.6718	.2187	.1718	.1562	.4001
Min	.4365	.4902	.1932	.0141	.1094	.0743	.2623
Avg	.4690	.5241	.5367	.1714	.1244	.0887	.3379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 203 / 11 KV HUBALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9069	.9804	1.004	.056	.037	.0514	.6241
2	.8962	.9922	.9804	.056	.0366	.0526	.6241
3	.8855	.9922	.9922	.056	.037	.0537	.6241
4	.9069	1.0526	1.004	.056	.0373	.0532	.6241
5	.9282	1.0595	1.012	.056	.0554	.0716	.6241
6		1.1043	1.0402	.056	.0732	.0724	.6944
7	1.0722	1.1363	1.2146	.0747	.0724	.0693	.8124
8	1.0402	1.1043	1.1203	.0693	.0549	.0625	
9	.0351	.0566	.0347	.7468	1.0562	.9602	
10	.0362	.0343	.0486	.9804	1.2003	1.034	
11	.037	.0347	.0549	1.0402	1.2323	1.0623	
12		.0332	.0537	1.0364	1.2323	1.078	
13	.0554	.0354	.0514	.9602	1.1843	1.0936	.064
14	.056	.0366	.056	1.012	1.2003	1.0467	.048
15	.0566	.037	.0739	.9602	1.1843	1.0155	.048
16	.056	.0358	.0554	.9602	1.1683	.9842	.048
17	.037	.0497		.0543	.0537	.0732	.0509
18	.0332	.0328	.0566	.0549	.0509	.0739	.064
19	.0554	.0526	.0886	.0537		.0739	.0339
20	.056	.056	.0747	.0724	.0739	.0924	.0497
21	.0566	.056	.0747	.0732	.0739	.0934	.0312
22	.0566	.056	.0747	.0549	.0549	.0747	.0316
23	.9842	1.012	.0543	.0554	.0543	.5575	1.3283
24	.8855	.9686	.9922	.0554	.0366	.0532	.5647
Max	1.0722	1.1363	1.2146	1.0402	1.2323	1.0936	1.3283
Min	.0332	.0328	.0347	.0537	.0366	.0514	.0312
Avg	.4151	.4587	.4440	.3604	.4461	.4106	.3679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 201 / 11 KV MANCHHINDRANAT

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.6535	.6535	.5975	.6413	.6224	.6224
2	.6036	.6413	.6348	.5975	.6413	.6224	.6224
3	.6036	.6224	.6413	.6036	.6224	.6224	.6224
4	.6036	.6224	.6224	.6224	.6224	.6224	.6224
5	.6602	.6602	.7356	.6413	.6979	.679	.6224
6	.7922	.9335	.8775	.7842	.8775	.8402	.7922
7	.6535	.7762	.7499		.7577	.7023	.7023
8	.5544	.7059	.6697	.3142	.6335	.6219	.6036
9	.4572		.6154	.6268	.5973	.5847	.5731
10	.4075	.6661	.6024	.631	.5784	.5847	.567
11		.6556	.591		.5552	.6089	.5731
12		.6135	.6335	.7888	.6089	.6379	.6268
13		.6201	.5973	.691	.5373	.6268	.6447
14		.591	.5792	.6733	.5611	.6154	.6335
15		.5973	.6626	.6733	.543	.5611	.5973
16		.5552	.5973	.6733	.5731	.4887	.5249
17	.6024	.5194		.6485	.5788	.5194	.4887
18	.6556	.5959	.631	.6485	.5493	.5014	.4961
19	.8238	.6984	.7059	.7602	.6516	.6767	.724
20	.961	.961	.9055	.9425	.8871	.9055	.9055
21	.9055	.8962	.8501	.8775	.8589	.8775	.8775
22	.8962	.8775	.8215	.8402	.8215	.8215	.8402
23	.8029	.7655	.7095	.7282	.7167	.7095	.7282
24	.6413	.7095	.6722	.6348	.6602	.6602	.6413
Max	.961	.961	.9055	.9425	.8871	.9055	.9055
Min	.4075	.5194	.5792	.3142	.5373	.4887	.4887
Avg	.6804	.6929	.6852	.6818	.6572	.6547	.6522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 202 / 11KV KRISHNA LIS

PURELY LIS FEEDERS

YEDEMACHHINDR Feeder KV- 11 /
OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.4744		.5624	.4641	.5693
2	.5535	.5556		.5624	.5535	.5624
3	.5468	.5556		.5693	.5624	.5624
4	.5468	.5468		.5624	.5624	.5693
5	.5535	.5401		.5624	.5624	.5624
6	.5535	.5693		.5624	.5624	.5693
7	.5693	.5624		.5693	.5624	.5468
8	.5693	.5556	.0036	.5556	.5693	.5468
9		.5693	.0191	.5693	.5624	.5312
10	.4481	.5401	.5601	.5693	.5556	.5376
11	.5535	.5693	.583	.5761	.5693	.5468
12	.5468	.5535	.5624	.5535	.5624	.5468
13	.5401	.5401	.5624	.5312	.5556	.5468
14	.5401	.5401	.5624	.5376	.5624	.5468
15	.5468	.5401	.5624	.5312	.5624	.5468
16	.5401	.5401	.5556	.503	.5693	.5401
Max	.5693	.5693	.583	.5761	.5693	.5693
Min	.2286	.4744	.0036	.503	.4641	.5312
Avg	.5225	.5470	.4412	.5548	.5561	.5520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 203 / 11KV Kilemachindragad Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0701	.0514	.3292	.4572	.4715	.0724
2	.0543	.0724	.052	.3384	.443	.4778	.0716
3	.0543	.0724	.0526	.3429	.4287	.4715	.0724
4	.0549	.0732	.0526	.362	.423	.4652	.0724
5	.0549	.0732	.0876	.4199	.423	.4715	.0732
6	.0747	.0739	.0924	.4064	.5281	.6161	.112
7	.0914	.1075	.124	.5502	.6836	.743	.1086
8	.0701	.0867	.0886	.5502	.6144	.7042	.1052
9	.8333		.9568	.0474	.052	.052	.823
10	.8768	.884	.9482	.0497	.0339	.0497	.9145
11		1.1092	.9297	.0492	.0526	.0537	.9031
12		1.1111	.9259	.0693		.0492	.9145
13		.9633	.8025	.0678	.0526	.0514	.873
14		.873	.7628	.052	.0358	.0701	.8069
15		.8429	.724	.0701	.0537	.0709	.7876
16		.7628	.724	.0686	.0503	.0678	.7775
17	.0895	.0469		.0509	.0324	.0709	.0514
18	.0867	.0503	.08	.0671	.0497	.0693	.0671
19	.1029	.0716	.0354	.0701	.0509	.0895	.0701
20	.0895	.0543	.0549	.0701	.0716	.0924	.0732
21	.0895	.0724	.0732	.0724	.0716	.0739	.0724
22	.0876	.0732	.0549	.0724	.0709	.0739	.0724
23	.0549	.0724	.4287	.4694	.5281	.0732	.0732
24	.0543	.0543	.0532	.4144	.4923	.5144	.0724
Max	.8768	1.1111	.9568	.5502	.6836	.743	.9145
Min	.0543	.0469	.0354	.0474	.0324	.0492	.0514
Avg	.1597	.3335	.3546	.2108	.2478	.2476	.3350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 204 / 11KV Shirte Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9339	1.1142	.0819	.081	.081	.081	1.0688
2	.9339	1.065	.5182	.081	.081	.081	1.0688
3	.9339	1.0486	.5182	.081	.081	.081	1.0688
4	.9339	1.0486	.5344	.081	.081	.081	1.0688
5	.9831	1.0814	.6316	.081	.081	.081	1.085
6	1.1797	1.2944	.664	.1134	.081	.0972	1.2631
7	1.4419	1.5565	.8259	.1134	.0972	.0972	1.4575
8	1.3763	1.4419	.7611	.0972	.0972	.081	1.3765
9	.0819	1.4419	.0486	1.3765	1.7976	1.8461	.0648
10	.0819	.0819	.0486	1.5708	1.9757	2.0567	.0648
11		.0819	.0648	1.7328	1.9919	2.17	.081
12		.0983	.081	1.8299	1.8785	2.1538	.081
13		.0819	.081	1.749	1.8461	1.9757	.081
14		.0819	.081	1.6194	1.7814	1.8785	.081
15		.0655	.0972	1.4089	1.7328	1.8138	.081
16		.0983	.0972	1.4251	1.668	1.7328	.081
17	.0983	.0983		.081	.0648	.0648	.081
18	.0983	.0819	.1134	.081	.081	.0972	.0972
19	.1147	.0983	.081	.081	.0972	.081	.0972
20	.1147	.1147	.0972	.0972	.0972	.0972	.1134
21	.0983	.1147	.0972	.1134	.1134	.0972	.1134
22	.0983	.0983	.0972	.0972	.0972	.0972	.0972
23	1.1305	1.0978	.0972	.081	.081	1.1174	1.1012
24	.9831	1.1305		.081	.081	.081	1.1012
Max	1.4419	1.5565	.8259	1.8299	1.9919	2.17	1.4575
Min	.0819	.0655	.0486	.081	.0648	.0648	.0648
Avg	.6454	.6049	.2599	.5898	.6694	.7517	.5364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 205 / 1KV Yede Lvanmachi Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.0781	.0937	.6249	.5624	.4999	.0772
2	.0617	.0781	.0937	.6093	.5624	.4999	.0772
3	.0617	.0781	.0937	.6093	.5312	.4843	.0772
4	.0617	.0781	.0937	.5937	.5312	.4843	.0772
5	.0617	.0781	.0937	.6093	.5312	.4218	.0772
6	.0772	.0937	.1094	.578	.6718	.5312	.0772
7	.0926	.0781	.1094	.703	.8642	.6944	.0926
8	.0772	.0781	.0937	.6562	.8436	.7253	.0926
9	1.2191		1.3123	.0937	.0937	.0309	1.2191
10	1.2967	1.2967	1.3592	.0781	.0625	.0463	1.2346
11		1.5154	1.3592		.0625	.0309	1.2346
12		1.4685	1.2654		.0625	.0463	1.2811
13		1.4998	1.2342	.0781	.0625	.0617	1.2811
14		1.3748	1.1873	.0937	.0625	.0463	1.2498
15		1.3435	1.1405	.0781	.0781	.0926	1.1561
16		1.2029	1.0936	.0937		.0926	1.1561
17	.1094	.1094		.0937	.0937	.108	.0937
18	.0937	.0937	.0781	.0781	.0937	.108	.0937
19	.1094	.0937	.0781	.1094	.0937	.0926	.0937
20	.1094	.1094	.0937	.1094	.1094	.0926	.1094
21	.1094	.1094	.0937	.0937	.1094	.0926	.1094
22	.0937	.1094	.0937	.0937	.1094	.0926	.1094
23	.0781	.0937	.703	.5624	.5312	.0772	.0781
24	.0617	.0781	.0937	.6718	.5937	.5155	.0772
Max	1.2967	1.5154	1.3592	.703	.8642	.7253	1.2811
Min	.0617	.0781	.0781	.0781	.0625	.0309	.0772
Avg	.2131	.4843	.5203	.3323	.3181	.2487	.4677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 201 / 11 KV RAJARAM NAGER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2195	.2987	.2378	.2286	.2195	.2378
2	.2286	.2218	.2801	.2402	.2286	.2218	.2218
3	.2286	.2218	.2614	.2172	.2096	.2218	.2218
4	.2286	.2241	.2614	.2195	.2096	.1848	.2195
5	.2477	.2241	.2801	.2353	.2286	.2218	.2402
6	.2477	.2195	.2987	.2353	.2477	.2614	.2534
7	.2667	.2614	.2987	.2534	.2477	.2987	.2926
8	.3048	.2561	.3361	.2715	.2667	.2561	.2896
9	.2772	.2865	.381	.2561	.2772	.2667	.3077
10	.2743	.3292	.3429	.2865	.2743	.2477	.2865
11		.3292	.3239	.3292	.2587	.2667	.2926
12		.3292	.3239	.2926	.3142	.2477	.2926
13		.3292	.3429	.2926	.2772	.2667	.2507
14		.3109	.3429	.2987	.2926	.2667	.2507
15		.3109	.362	.2614	.2896	.2858	.2926
16	.3109	.3292	.381	.2926	.3326	.2858	.2561
17	.3109	.3292	.3077	.3429	.2865	.2507	.2667
18	.2195	.2926	.3475	.3239	.2865	.2328	.2858
19	.2926	.3696	.2743	.3429	.2865	.2715	.3239
20	.3258	.4207	.3658	.362	.2926	.3109	.3429
21	.2896	.4024	.2715	.3239	.2561	.2896	.3048
22	.2926	.3696	.3475	.3048	.2561	.2896	.3048
23	.2507	.3547	.2926	.2667	.2195	.2743	.2858
24	.2667	.2195	.3361	.2772	.2477	.2195	.2534
Max	.3258	.4207	.381	.362	.3326	.3109	.3429
Min	.2195	.2195	.2614	.2172	.2096	.1848	.2195
Avg	.2690	.2984	.3191	.2818	.2631	.2566	.2739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 202 / 11 KV Uran-Islampur

GAOTHAN FEEDER

Gaothan. Feeder KV- 11 /
OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1241	1.0974	1.1576	.9511	1.0098	1.0608	.9145
2	1.0288	1.0498	1.1203	.9145	.9145	1.0349	.9055
3	1.0098	1.0136	1.0829	.9231	.9145	1.0349	.9055
4	.9717	1.0136	1.0829	.9328	.9717	.9979	.9328
5	1.0288	1.0498	1.1827	.9593	1.0288	.9979	.9877
6	1.2384	1.1949	1.2883	1.0608	1.1431	1.0719	1.0679
7	1.105	1.0029	1.0534	.8413	.9907	.9709	.9511
8	.8383	.8779	.9055	.8688	.8192	.7682	.8501
9	.9055	.9335	.9526	.8869	.8131	.7621	.7865
10	.9877	1.0456	1.0288	.9671	.8779	.9145	.9313
11	.905	1.0456	.9145	.9313	.9593	.9526	.8954
12	.8596	1.0164	.9717	.9877	.9694	.9145	.9511
13	.8779	1.0349	1.105	1.0242	.8688	.8764	.9511
14	.8688	1.0242	1.1241	.9313	.9511	.8954	.9671
15	.8859	1.0059	1.1431	.9313	.8869	.9145	.9671
16	1.0808	1.1706	1.105	1.0608	1.0242	1.0479	1.1706
17	.8688	1.0974		1.0669	.9145	.8779	1.1431
18	.8238	.9511		.9907	.8596	.924	1.1812
19	1.1462	1.2752	1.2071	1.2193	1.1462	1.134	1.2193
20	1.3169	1.3817	1.262	1.2574	1.3032	1.1888	1.3527
21	1.2803	1.3443	1.2127	1.2193	1.267	1.1222	1.3146
22	1.2696	1.307	1.1888	1.2003	1.2178	1.0974	1.2955
23	1.1827	1.2883	1.0791	1.1812	1.1462	1.1523	1.2574
24	1.1622	1.0974	1.1949	1.0349	1.0098	1.0745	1.0136
Max	1.3169	1.3817	1.2883	1.2574	1.3032	1.1888	1.3527
Min	.8238	.8779	.9055	.8413	.8131	.7621	.7865
Avg	1.0319	1.0966	1.1074	1.0143	1.0003	.9911	1.0380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 203 / 11KV Mahadev Nagar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2765	1.2437	1.3817	1.2437	1.105	1.1706	1.1458
2	1.2384	1.2197	1.3443	1.0513	.9907	1.1458	1.0719
3	1.1431	1.1088	1.307	1.0288	.9717	.7659	1.0719
4	1.105	1.1088	1.307	1.0974	.9717	1.1088	1.0791
5	1.0098	1.1458	1.307	1.1641	1.105	1.1458	1.0974
6	1.1622	1.1576	1.307	1.2803	1.2003	1.134	1.1222
7	1.2955	1.0829	1.3121	1.1888	1.2384	1.0608	1.1157
8	1.3146	1.307	1.3535	1.39	1.2765	1.1706	1.2071
9	1.1273	1.0242	1.2193	1.1706	.9795	.9526	.9671
10	1.1888	1.3717	1.2384	1.3169	1.134	.9717	1.2437
11		1.2986	1.3146	1.1104	1.0498	1.0288	1.0974
12		1.2437	1.3527	1.2178	1.0608	1.0479	.9671
13	1.2254	1.3169	1.5623	1.182	1.1706	1.0669	1.1462
14	1.382	1.39	1.5242	1.2803	1.2567	1.0288	1.2437
15	1.0985	1.3169	1.4861	1.2803	1.134	1.0669	1.134
16	1.1163	1.2803	1.4098	1.2894	1.0974	1.105	1.1104
17	1.0745	1.2803		1.3336	1.0974	1.0974	1.1812
18	1.134	1.2437	1.2308	.9907	1.0387	1.1643	1.3527
19	1.4998	1.6617	1.4632	1.6766	1.3611	1.3575	1.5813
20	1.6834	1.8484	1.701	1.7337	1.5565	1.448	1.7337
21	1.6834	1.7924	1.5927	1.5242	1.5203	1.39	1.5432
22	1.4784	1.7177	1.5912	1.5623	1.448	1.3717	1.4861
23	1.4632	1.6804	1.5546	1.3717	1.3032	1.2803	1.2955
24	1.3527	1.307	1.4563	1.3676	1.2003	1.1706	1.2071
Max	1.6834	1.8484	1.701	1.7337	1.5565	1.448	1.7337
Min	1.0098	1.0242	1.2193	.9907	.9717	.7659	.9671
Avg	1.2751	1.3395	1.4051	1.2855	1.1778	1.1354	1.2167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 204 / 11KV Urun Ag Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0747	.0747	.3658	.4191	.3521	.0732
2	.0762	.0754	.0747	.3155	.4191	.3887	.0739
3	.0762	.0754	.0747	.2804	.5335	.3887	.0747
4	.0762	.0754	.0754	.3045	.6287	.4161	.0747
5	.0762	.0754	.0943	.3086	.6859	.4161	.0724
6	.0762	.0754	.0934	.3582	.724	.6081	.0724
7	.0762	.0747	.0754	.5552	.7811	.6882	.0724
8	.0762	.0747	.1132	.5487	.8573	.7682	.0732
9	.9442	.9602	1.2003	.0716	.064	.0762	.8916
10	1.004	1.0242	1.2384		.08	.0762	.9922
11	1.0486	1.004	1.2574	.1097	.0848	.0762	1.0883
12	.9503	.9393	1.1622	.0747	.1029	.0762	1.1469
13	.9503	.8907	.9907	.0747	.1029		1.1142
14	.7499	.8259	.9717	.0747	.1063	.0953	1.0242
15	.6859	.9383	.9907	.0747	.1267	.0953	.9602
16	.7865	.7773	.8192	.0747	.1097	.0953	.9831
17	.0848	.0934		.0762	.0716	.0934	.1143
18	.0747	.112	.0678	.0762	.0732	.0914	.0762
19	.0747	.0934	.0678	.0762	.0732	.0724	
20	.0754	.0934	.0678	.0762	.0732	.0732	.0953
21	.0754	.0934	.0716	.0762	.0732	.0724	.0762
22	.0739	.0747	.0716	.0762	.0732	.0716	.0762
23	.0754	.0747	.394		.3201	.0716	.0953
24	.0762	.0747	.0747	.3841	.381	.3201	.0724
Max	1.0486	1.0242	1.2574	.5552	.8573	.7682	1.1469
Min	.0739	.0747	.0678	.0716	.064	.0716	.0724
Avg	.3475	.3613	.4401	.2015	.2902	.2384	.4084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV Kasegaon Gaothan-
Village Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4557		.439	.4527	.4755	.4527
2	.4904	.3982		.439	.4527	.4252	.4527
3	.4904	.3982		.3898	.4527	.4252	.4527
4	.4904	.4481		.3898	.4527	.4344	.4527
5	.4854	.5415		.499	.4904	.5068	.4527
6	.5601	.5853		.5487	.6348	.5975	.6036
7		.6653		.6653	.5544	.6653	.6413
8		.5975		.6036	.5853	.5611	.6283
9	.6283	.5544		.5544	.5068	.5487	.5121
10	.543	.5853		.543	.4755	.5729	
11	.5201	.5487		.5792	.5068	.5121	
12	.5609	.5121		.543	.4755	.5175	
13	.5373	.5487		.5544	.4344	.4854	
14	.5373	.5792		.5487	.4755		
15	.4961	.543		.5792	.5121	.462	
16	.4733	.5731		.5914		.5544	
17	.5487	.5731	.5731	.5487	.5121	.5544	.543
18	.567	.6379	.5373	.5487	.4207		.439
19	.6535	.6379	.7316	.6584	.5544	.6516	.7095
20	.7316	.7796	.823	.7316	.8048	.7316	.8131
21	.6219	.6348	.7577	.6219	.6219	.6283	.7059
22	.5493	.6348	.6733	.6348	.5914	.5544	.567
23	.5788	.5658	.5853	.5658	.543	.4904	.543
24	.4904	.4557	.5281	.5068	.4904	.4755	.4904
Max	.7316	.7796	.823	.7316	.8048	.7316	.8131
Min	.4733	.3982	.5281	.3898	.4207	.4252	.439
Avg	.5475	.5606	.6512	.5535	.5218	.5377	.5565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV Nerle Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6036		.7167	.8299	.7167	.7922
2	.6413	.5658		.5487	.5658	.6036	.7545
3	.6413	.5121		.4755	.5658	.4435	.6413
4	.6413	.439		.4904	.5658	.4435	.6413
5	.6413	.4481		.5658	.5658	.4706	.6413
6	.6413	.5041		.5975	.6348	.4706	.6036
7		.5014		.5281	.5281	.5601	.5281
8		.4715		.4854	.4904	.547	.5175
9	.4755	.6348		.5121	.5601	.4854	.5121
10	.2667	.6036		.6535	.6413	.6036	
11	.5487	.5914		.7545	.6348	.7468	
12	.5487	.7095		.7167	.5975	.7842	
13	.543	.6173		.7095	.7095	.7922	
14	.5487	.7023		.7468	.7392	.7682	
15	.5373	.6653		.7545	.7392	.8676	
16	.6661	.6584		.7167		.7468	
17	.6602	.6584	.7468	.7095	.5658	.7468	.7167
18	.5601	.6653	.6535	.7095	.4854	.7392	.695
19	.7167	.7392	.5658	.7842	.8299	.7392	.8299
20	.8299	.8871	.9335	.9335	.9709	.924	1.1203
21	.8962	.924	1.0374	.9431	.8299	.8676	1.0374
22	.7682	.9431	.9709	.9054	.7842	.8676	.9431
23	.7167	.7545	.9709	.9054	.9054	.8676	.9335
24	.7545	.6379	.679	.7842	.9054	.7682	.8676
Max	.8962	.9431	1.0374	.9431	.9709	.924	1.1203
Min	.2667	.439	.5658	.4755	.4854	.4435	.5121
Avg	.6311	.6432	.8197	.6936	.6802	.6904	.7515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV Tambave Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4344		.3658	.4024	.4557	.4706
2	.3982	.3898		.3292	.4024	.4066	.4706
3	.3982	.3544		.3189	.4024	.4066	.4706
4	.3982	.3696		.4252	.4024	.4252	.4706
5	.3898	.4435		.4887	.4755	.4252	.5068
6	.4607	.4706		.543	.5792	.5121	.5373
7		.5487		.5258	.5373	.5121	.5316
8		.4887		.4887	.4298	.443	.4908
9	.3666	.4733		.4656	.5014	.439	.4458
10	.3856	.3506		.3734	.4207	.4572	
11	.3429	.3582		.3174	.5014	.4207	
12	.3086	.3658		.3982	.4656	.4163	
13	.2572	.3658		.5138	.4656	.439	
14	.3506	.3982		.439	.3898	.394	
15	.3506	.3982		.4066	.3544	.4108	
16	.4115	.3582		.4207		.4024	
17	.4557	.3582	.3841	.3506	.3544		.3439
18	.5121	.3582	.3881	.3467	.3658	.3052	.3439
19	.4572	.4252		.3121	.4163	.3052	.439
20	.543	.567		.4854	.5853	.5426	.5175
21	.4938	.543	.4706	.5014	.543	.4706	.5121
22	.5121	.543	.5121		.543	.4706	.5415
23	.5228	.4706	.5068	.4706	.5121	.4656	.5304
24	.3982	.4344	.4706	.4706	.4706	.4557	
Max	.543	.567	.5121	.543	.5853	.5426	.5415
Min	.2572	.3506	.3841	.3121	.3544	.3052	.3439
Avg	.4142	.4278	.4554	.4242	.4574	.4340	.4764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV Wategaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4481		.4108	.3353	.9511	.3048
2	.3429	.3734		.2896	.3353	.3696	.3048
3	.3429	.3544		.2896	.3353	.3544	.3048
4	.3429	.2835		.3544	.3353	.3189	.3048
5	.3429	.3018		.3544	.3658	.3361	.3048
6	.4115	.3584		.4706	.3658	.3734	.407
7		.3801		.4024	.3658	.4207	.3772
8		.4163		.4481	.3429	.3982	
9	.3201	.4298		.3982	.3982	.439	.3772
10	.3353	.5281		.4108	.4298	.4108	
11	.3429	.4557		.4481	.3506	.4207	
12	.3155	.4207		.3544	.3856	.4294	
13	.3086	.3856		.3292	.3856	.4024	
14	.3506	.4115		.3921		.4382	
15	.3506	.3772		.0343	.3898	.4525	
16	.4115	.3772		.0686		.4024	
17	.0514	.3429	.3658	.1734	.362	.4024	.3856
18	.0514	.3429	.3292	.3467	.362	.4066	.4207
19	.0457	.3429	.4854	.5182	.4854	.4904	.5121
20	.6173	.5959	.5853	.5182	.543	.4572	.5975
21	.5609	.4572	.543	.4938	.5316	.4572	.5304
22	.5316	.4572	.5068	.463	.4887	.4915	.4784
23	.5121	.3658	.439	.3658	.4525	.4024	.4435
24	.3429	.439	.3658	.4108	.3658	.4024	.3898
Max	.6173	.5959	.5853	.5182	.543	.9511	.5975
Min	.0457	.2835	.3292	.0343	.3353	.3189	.3048
Avg	.3443	.4019	.4525	.3644	.3960	.4345	.4027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 205 / 11 KV KASEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1219		1.4419		1.9608	
2		.0937		1.4746		2.0645	
3		.0937		1.4403		2.0645	
4		.0926		1.4403		2.0557	
5		.108		1.4723		2.0557	
6		.1094				2.1628	
7		.1524				2.1628	
8		.1372				2.0153	
9	2.0622	2.0881			.1094	.0762	
10	2.1445	2.1338			.1094	.1524	
11	2.1445	2.2184			.128	.1524	
12	2.1605	2.2497		.1219	.08	.1524	
13	2.1765	2.2653		.1219	.1094	.0762	
14	2.1445	2.2531		.1219	.1094	.1219	
15	1.9997	2.2405		.1219	.0926	.1219	
16	2.0466	1.1888		.1219		.1524	
17	.0914		.0914		.1829		.1829
18	.0914				.1829		.1829
19	.1219		.1219		.1829		.1829
20	.1372		.1219		.1829		.1829
21	.1219		.0914		.1875		.1875
22	.1219		.0914		.1219		.2968
23	.1219		1.4022		2.1136		.1372
24		.1219		1.4419		1.89	
Max	2.1765	2.2653	1.4022	1.4746	2.1136	2.1628	.2968
Min	.0914	.0926	.0914	.1219	.08	.0762	.1372
Avg	1.1791	1.0393	.3200	.8473	.2781	1.1434	.1933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 206 / 11 KV NERLE AG. FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.704		.061		.0762	
2		1.7604		.061		.0762	
3		1.7604		.0457		.0781	
4		2.0645		.0457		.0781	
5		2.2119		.0625		.0937	
6		2.2775		.061		.0914	
7		2.3594		.061		.0914	
8		2.0317		.0914		.0762	
9	.0914	.0937		1.906	2.1559	2.1792	
10	.1067	.08		2.0309	2.1715	2.3102	
11	.1067	.0057		2.1792	2.2405	2.2405	
12	.0772	.0819		2.1628	2.2405	1.5684	
13	.0937	.096		2.1628	2.1872	1.9334	
14	.0781	.112		2.0972		2.0805	
15	.1094	.081		2.0645	2.1403	2.1628	
16	.125	.08		2.0972	1.9372	2.7199	
17	.0914		.0914		.0914		.0914
18	.0914		.1219		.0914		.0914
19	.0914		.0914		.0914		.0914
20	.0914		.0914		.0914		.0914
21	.1219		.0914		.0914		.0914
22	.1219		.0914		.0914		.0914
23	1.6385		.0762		.0762		1.8679
24		1.704		.061		.0762	
Max	1.6385	2.3594	.1219	2.1792	2.2405	2.7199	1.8679
Min	.0772	.0057	.0762	.0457	.0762	.0762	.0914
Avg	.2024	1.0885	.0936	1.0148	1.1213	1.0548	.3452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 207 / 11 KV Wategaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1981		.9995		1.3763	
2		.1562		1.0402		1.4243	
3		.1562		1.0402		1.4243	
4		.1852		1.0883		1.704	
5		.1852		1.1142		1.9662	
6		.2343		1.1142		2.0809	
7		.2343		1.5893		2.2283	
8		.25		1.3923		1.9989	
9	1.5935	1.8884		.2134	.1094	.1829	
10	1.0303	2.0165		.2134	.0914	.1829	
11	1.6872	1.9372		.1829	.0781	.1829	
12	1.7444	1.906		.1829	.1094	.1829	
13	1.7604	1.8903		.1875	.1265	.1875	
14	1.7185	1.7985		.1875	.1094	.2031	
15	1.7497	1.8138		.1829	.125	.2031	
16	1.6248	1.4632				.2031	
17	.2439		.1524		.2134		.2439
18	.253		.2134		.2134		.2439
19	.2846		.2134		.2187		.2439
20	.2214		.1829		.25		.25
21	.2187		.2187		.2134		.25
22	.2134		.1875		.2187		.2439
23	.2187		1.0322		1.3748		.2439
24		.1981		.9995		1.3763	
Max	1.7604	2.0165	1.0322	1.5893	1.3748	2.2283	.25
Min	.2134	.1562	.1524	.1829	.0781	.1829	.2439
Avg	.9708	.9713	.3144	.7330	.2465	1.0063	.2456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 208 / 11 KV Tambave Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1136			.0762	
2		2.0645			.0762	
3		2.1285			.0625	
4		2.2447			.0617	
5		2.2939			.0617	
6		2.2405			.0926	
7		2.3758			.0914	
8		2.1956			.0762	
9	.0914	.081		3.0464	2.8346	
10	.1067	.096		3.0933	2.7526	
11	.0914	.1094		3.0864	3.6046	
12	.0914	.1094		3.0636	3.6374	
13	.0914	.0914		3.187	3.3425	
14	.0781	.0914	.2439	3.0933	2.8807	
15	.0781	.1067	1.9334	2.6825	2.7846	
16	.0781	.0914	2.0317		2.9001	
17	.1219			.0914		.0762
18	.1219			.0914		.0762
19	.1219			.0914		.1219
20	.1219			.1219		.1219
21	.1219			.1067		.0914
22	.0914			.0914		.0914
23	2.1136			.0914		2.2283
24		2.1136			.0762	
Max	2.1136	2.3758	2.0317	3.187	3.6374	2.2283
Min	.0781	.081	.2439	.0914	.0617	.0762
Avg	.2347	1.2087	1.403	1.5670	1.4948	.4010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 209 / 11 KV Someshwar

PURELY LIS FEEDERS

Bhairavnath LI Feeder KV- 11 /
OUTGOING

DATE	09-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.333		.961	.7545	.9425
2	.333		.961	.7712	.9425
3	.3366		.961	.7888	.9425
4	.4075		.961	.7716	.9425
5	.7133		.8871	.7888	.9425
6	.823		.9055	.8145	
7	1.3847		.924	.8402	.924
8	.8413		.8871	.8413	.924
9	.8413		.823	.8507	.924
10	.8413	.724	.8596	.8505	
11	.823	.8507	.8501	.8413	
12		.8779	.8413	.8413	
13	.8573	.8413	.8413	.8688	
14	.8573	.8871	.7865	.8962	
15	.823	.8589	.8326	.8962	
16		.8871		.8507	
24				.7545	
Max	1.3847	.8871	.961	.8962	.9425
Min	.333	.724	.7865	.7545	.924
Avg	.7297	.8467	.8855	.8248	.9356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 210 / 11 KV Krishna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4578	.4973	1.5074	1.0802	1.858
2	.4578	.4973	1.5074	1.0802	1.858
3	.6836	.5609	1.5074	1.3847	1.858
4	.9114	.5609	1.3496	1.3847	1.858
5	.9431	.4973		1.5261	1.858
6	1.0288		1.3546	1.5261	1.8755
7	1.0513		1.5089	1.7924	1.8031
8	1.2174		1.5604	1.6289	1.8031
9	1.4022		1.6804	1.5775	1.8031
10	1.4582	1.3717	1.6632	1.5261	
11	1.4922	1.4575	1.8484	.9945	
12	1.6804	1.6832	1.7528	.9945	
13	1.7177	1.7147	1.7528	1.6632	
14	1.7353	1.7147	1.7147	1.701	
15	1.7918	1.7703	1.7147	1.7741	
16		1.4575		1.6632	
Max	1.7918	1.7703	1.8484	1.7924	1.8755
Min	.4578	.4973	1.3496	.9945	1.8031
Avg	1.2019	1.1486	1.6016	1.4561	1.8416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 202 / 11 KV YELUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3734	.4338	.415	.415	.415	.4338
2	.3961	.3734	.415	.4108	.3961	.3961	.415
3	.3961	.3292	.415	.3734	.3772	.3772	.415
4	.3772	.3224	.4338	.3658	.3772	.3961	.4338
5	.415	.3856	.4338	.4298	.415	.415	.4527
6	.4715	.4344	.4854	.4706	.4715	.4481	.4854
7	.5601	.4805	.5175	.499	.5041	.4805	.5175
8	.499	.4252	.4572	.4344	.4572	.4207	.439
9	.4572	.4344	.4163	.4298	.362	.3982	.4163
10	.4572	.4119	.3856	.3856	.3155	.3856	.3856
11		.3898	.3856	.4031	.3155	.3506	.3429
12		.3506	.3681	.3429	.3155	.333	.3258
13	.3772	.3506	.3506	.3856	.3155	.3155	.3155
14	.3772	.3641	.3506	.3506	.3155	.3856	.3155
15	.3772	.3506	.3681	.3506	.3155	.3506	.3429
16	.3856	.3856	.3681	.333	.3856	.298	.4031
17	.3856	.4075	.3681		.3429	.2804	.4908
18	.8764	.4298	.3982	.4784	.4031	.4066	.4508
19	.4477	.543	.443	.5792	.4525	.5068	.4961
20	.5914	.6584	.3982	.6219	.6584	.6584	.6878
21	.5601	.6283	.4656	.5788	.5914	.5914	.5914
22	.4854	.5601	.5601	.5281	.5415		.5601
23	.4527	.5093	.4481	.4715	.4715	.4904	.5041
24	.415	.3961	.4527	.439	.415	.415	.4338
Max	.8764	.6584	.5601	.6219	.6584	.6584	.6878
Min	.3772	.3224	.3506	.333	.3155	.2804	.3155
Avg	.4625	.4289	.4216	.4381	.4138	.4137	.4439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 203 / 11 KV Aitwadi Kh -Gaothan-
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4298	.415	.3982	.4338	.415	.415
2	.3961	.4344	.3961	.3658	.415	.415	.3961
3	.3772	.394	.3772	.3224	.3961	.3961	.3961
4	.3772	.3856	.3772	.2804	.3961	.415	.415
5	.3772	.4115	.3961	.2896	.415	.4338	.4527
6	.3961	.4607	.4294	.3224	.4715	.4481	.4668
7	.4294	.5068	.499	.3395	.5041	.4805	.4805
8	.3881	.4854	.4572	.2804	.462	.3658	.4207
9	.3658	.4656	.3982	.2507	.3841	.362	.4344
10		.4784	.4207	.2454	.3856	.3506	.3856
11		.4207	.3772	.2454	.3856	.3506	.3856
12		.3681	.3856	.2454	.3506	.3772	.4207
13			.3429	.2454	.3086	.3429	.3772
14		.3772	.3429	.2454	.3155	.3772	.3772
15		.4115	.3429	.2804	.3429	.3086	.3856
16		.3988	.3506	.4207	.3506	.2743	.3856
17		.4382			.3429	.2743	.5609
18	.4359	.3544	.3506	.5014	.394	.394	.8063
19	.5487	.5068	.3772	.5853	.4163	.4344	.4115
20		.6584	.3856	.6283	.6219	.6036	.567
21		.6099	.4298	.5975	.5729	.5544	.5658
22	.6036	.5601	.4755	.5658	.5228	.5228	.5014
23	.5228	.5093	.4755	.5093	.4527	.4527	.4108
24	.415	.439	.4338	.4656	.4527	.415	.4338
Max	.6036	.6584	.499	.6283	.6219	.6036	.8063
Min	.3658	.3544	.3429	.2454	.3086	.2743	.3772
Avg	.4307	.4567	.4016	.3752	.4206	.4068	.4522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 204 / 11 KV WASHI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3292	.3772	.3506	.3772	.3772	.3772
2	.3584	.3258	.3395	.3224	.3772	.3584	.3584
3	.3584	.3582	.3206	.3155	.3584	.3395	.3395
4	.3395	.3658	.3395	.3224	.3584	.3772	.3584
5	.3772	.4108	.3772	.3982	.3772	.415	.3772
6	.4338	.4344	.4481		.4338	.4481	.4294
7	.5041	.4252	.499	.543	.5228	.4805	.5175
8	.499	.4706	.4572	.439	.4755	.5121	.4755
9	.4755	.439	.3982	.4656	.4525	.4706	.4706
10		.4656	.3506	.4207	.3856	.4207	.4207
11		.4075	.3155	.4557	.3429	.4207	.4115
12		.3681	.3155	.4115	.3429	.2804	.4557
13	.5609	.3856	.3155	.3932	.3429	.2743	.3856
14	.5083	.3772	.2743	.362	.3429	.2743	.3506
15	.3429	.3681	.3506	.3429	.3429	.3086	.3506
16	.3506	.3506	.3772	.4207	.3086	.3506	.3506
17	.3856	.3366			.3155	.3429	.3429
18	.3814	.4298	.4298	.4119	.3582	.3506	.5144
19	.4382	.4706	.5258	.5121	.362	.4706	.4908
20	.2804	.6219	.4706	.5729	.6036	.6219	.5068
21	.543	.5914	.4298	.5415	.5544	.5544	.5014
22	.5121	.5415	.5175	.5093	.5228	.5041	.5121
23	.4066	.4904	.4207	.4527	.4527	.4338	.4338
24	.3772	.3696	.3772	.3582	.3961	.3961	.3772
Max	.5609	.6219	.5258	.5729	.6036	.6219	.5175
Min	.2804	.3258	.2743	.3155	.3086	.2743	.3395
Avg	.4195	.4222	.3925	.4237	.4045	.4076	.4212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 205 / 11 KV Aitwade Kh Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8399	2.0233	1.6078	.0366	.0377	.0754	1.5912
2	1.8442	2.0683	1.5927	.037	.0377	.0754	1.7737
3	1.8442	2.0774	1.5927	.0373	.0377	.0566	1.5592
4	1.8896	2.0851	1.6448	.0549	.0377	.0566	1.576
5	1.9559	2.2032	1.6956	.0537	.0377	.0754	1.6278
6	2.0957	2.2314	1.7436	.0526	.0566	.0754	1.7126
7	2.2298	2.1026	1.9448	.0497	.0754	.0754	1.861
8	2.2969	2.1262	1.8652	.0671	.0754		1.8442
9	.0566	.0701	.056		1.8652	2.1293	.0351
10		.0373	.0526	1.8861	1.9281	2.1033	.0351
11		.0377	.0526	1.7878	1.9281	2.0576	.0351
12		.0377		1.7147		2.3137	.0351
13				1.7528	2.0576	2.2291	.0351
14		.037		1.7147	2.2634	2.3663	.0351
15		.0366	.0526	1.7528	1.9982	2.4006	.0351
16		.0554	.0526	1.7528	2.0576	2.7949	.0351
17		.056			.0351	.0351	
18	.0566	.0566	.0537	.0537	.0554	.0373	.0377
19	.0554	.0566	.0526	.0566	.0747	.0377	.1132
20	.0566	.0566	.0537	.0566	.0754	.0566	.0537
21	.056	.0566	.0549	.0566	.0754	.0566	.0543
22	.056	.0566	.0566	.0566	.0754	.0566	.0549
23	2.0576	1.6244	.0537	.0566	.0754	1.7436	1.6956
24	1.8399	2.0348	1.6244	.0543	.0566	.0754	1.6095
Max	2.2969	2.2314	1.9448	1.8861	2.2634	2.7949	1.861
Min	.0554	.0366	.0526	.0366	.0351	.0351	.0351
Avg	1.2644	.9229	.7952	.5973	.6529	.9123	.7585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 207 / 11 KV WASHI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0701	.0943	.3647	.8322	.5992	.0943
2	.0943	.0716	.0943	.3391	.8907	.5601	.0943
3	.0943	.0905	.0943	.6859	.8907	.5441	.0943
4	.0943	.0895	.0943	.7712		.5898	.0943
5	.0943	.1097	.0943	.8596	.9995	.6554	.0943
6	.0943		.0943	.9602	1.1961	.6722	.1132
7	.1132	.1086	.112	1.0608	1.4586	.9172	.132
8	.1132	.1075	.1109	.9831	1.3748	1.2163	.0943
9	1.8564	2.1491	2.0119	.0747	.0934	.128	1.989
10		2.0287	2.2634	.1052	.1052	.128	2.5377
11		1.8778	1.7147	.1052	.1052	.1097	2.7435
12		1.5746	1.5424	.1052	.1052	.1052	2.1605
13	1.6118	1.4918	1.6095	.1052	.1052	.1029	2.0576
14	1.5432	1.4091	1.4746	.1029	.1075	.1052	2.0576
15	1.6126	1.3108	1.2269	.1029	.0914	.1132	2.1033
16	1.5432	1.2239	1.1218	.1029	.2103	.1052	2.1605
17	.0701	.112	1.1218		.2058	.1052	.1029
18	.0754	.1109	.0537	.0914	.1109	.1109	.1075
19	.0754	.112	.056	.0934	.1494	.112	.1132
20	.1494	.1132		.1132	.1509	.132	.1402
21	.0724	.1132	.0716	.1132	.132	.1132	.0732
22	.1463	.1132	.1097	.1132	.132	.0943	.1109
23	.0857	.1132	.1974	.7362	.7125	.0943	.0857
24	.1132	.0857	.0943	.421	.8322	.6154	.0943
Max	1.8564	2.1491	2.2634	1.0608	1.4586	1.2163	2.7435
Min	.0701	.0701	.0537	.0747	.0914	.0943	.0732
Avg	.4642	.6342	.6721	.3700	.4779	.3345	.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 208 / 11 KV YELUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.112	.0943	.7362	1.2146	1.3123	.1132
2	.0943	.0924	.0754	.7209	1.2289	1.3279	.0943
3	.0943	.0732	.0754	1.0059	1.2289	1.2955	.0943
4	.0943	.0732	.0754	1.2346	1.2616	1.3435	.0943
5	.0943	.0747	.0943	1.5424	1.3592	1.3763	.1132
6	.1132	.0924	.0943	1.6289	1.5912	1.4251	.1132
7	.1132	.112	.1132	1.7736	1.5912	.2454	.1132
8	.1132	.0732	.112	1.6712	1.643	.208	.112
9	2.364	2.6337	2.2874	.0754	.1294	.0171	2.3537
10		2.4366	2.2291	.0754	.0701	.0351	2.2291
11		2.3102	2.2786	.0377	.0701		2.3266
12		2.1956	2.1091	.0351	.0701		2.7606
13	2.0683	2.0729	2.1033			.0701	2.7435
14	1.9281	1.9109	2.0576			.0724	2.4539
15	1.9281	1.6804	1.9281			.1402	2.2085
16	1.9281	1.4899	1.6301	.0905	.0701	.1402	2.2085
17	.0838	.1075			.0701	.1402	.1052
18	.0983	.1097	.0876		.1097	.1294	.1357
19	.1448	.1109	.0886	.1663	.128	.1494	.1254
20	.1494	.1494	.1086	.168	.1663	.1698	.1294
21	.1509	.1509	.1097	.1509	.1698	.1698	.1478
22	.1509	.132	.1307	.132	.1509	.1509	.1478
23	.1132	.1132			1.3765	.132	.1132
24	.1132	.1132	.0943	.7362	1.1984	1.3443	.1132
Max	2.364	2.6337	2.2874	1.7736	1.643	1.4251	2.7606
Min	.0838	.0732	.0754	.0351	.0701	.0171	.0943
Avg	.5730	.7675	.8171	.6656	.7094	.5180	.8812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 209 / 11 KV Kundalwadi Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2462	2.4539	2.364	.0312	.0566	.0377	2.4756
2	2.2043	2.4539	2.3472	.0328	.0566	.0377	2.4143
3	2.2043	2.3891	2.2874	.0358	.0566	.0377	2.3975
4	2.2977	2.3388	2.3205	.0351	.0566	.0377	2.3868
5	2.3834	2.4272	2.3807	.0543	.0566	.0377	2.42
6	2.5312	2.5789	2.4813	.0532		.0377	2.5149
7	2.6699	2.572	2.6621	.0509	.0566	.0377	2.7161
8	2.572	2.7221	2.4417	.0566	.0754	.0566	2.4756
9	.0566	.0366	.0366	2.9874	3.0007	3.3913	.0366
10		.056	.0351	2.6292	3.0849	3.3265	.0351
11		.0554	.0351	2.524	2.9797	3.2579	.0351
12		.056	.0377	2.4539	3.155	3.1901	.0351
13	.0754	.037	.0351	2.4539	3.1878	3.155	.0351
14	.0754	.0366	.0351	2.4006	3.0849	3.0864	.0351
15	.0754	.0183	.0351	2.4539	3.0849	2.9797	.0351
16	.0377	.0185	.0351	1.6126	2.5034	2.7435	.0351
17	.0351	.0187	.0351		.0343	.0351	.0351
18	.0543	.037	.0362	.0549	.0366	.0549	.056
19	.0549	.0747	.0537	.056	.0554	.0554	.0724
20	.056	.0754	.0549	.0754	.0747	.056	.0537
21	.0754	.0754	.0549	.0754	.0566	.0566	.0732
22	.0754	.0754	.052	.0754	.0566	.0566	.0732
23	2.572	2.5434		.0754	.0377	2.323	2.7435
24	2.2634	2.4691	2.1365	.0543	.0754	.0377	2.4926
Max	2.6699	2.7221	2.6621	2.9874	3.1878	3.3913	2.7435
Min	.0351	.0183	.0351	.0312	.0343	.0351	.0351
Avg	1.1722	1.0675	.9562	.8840	1.0836	1.1719	1.0701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 202 / 11 KV ITKARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2334	1.5384	1.576	.128	.1132	.1307	.9568
2	1.2334	1.4548	1.4754		.1097	.1307	.9297
3	1.2037	1.4232	1.4754		.1132	.1307	.9259
4	1.2346	1.4232	1.4754		.1132	.1307	.9374
5	1.4083	1.5497	1.6118		.132	.1494	1.1574
6	1.8054	1.8185	1.8519		.1509	.1886	1.531
7	2.2712	2.3685	2.4874	.0924	.1698	.1848	1.9204
8	1.9938	1.9925	2.0119	.128	.1509	.168	1.5741
9	.124	.1433	.1509	2.0241	2.268	2.1765	.1097
10	.1417	.1478	.128	2.3482	2.3205	2.5587	.1267
11		.1478	.128	2.5911	2.3685	2.4453	.128
12		.1417	.1109	2.5911	2.0873	2.1125	.128
13		.1402	.1109	2.1348	1.906	1.8343	.128
14	.1402	.1402	.128	1.8435	1.7497	1.5432	.1267
15	.1463	.1463	.128	1.781	1.7497	1.5123	.1097
16	.1463	.1494	.1267	1.5352	1.6872	1.2643	.1097
17	.1772	.1612			.124	.1402	.1267
18	.0347	.1753	.1294	.1509	.1417	.1715	.1307
19	.181	.2263		.1509	.1646	.181	.1463
20	.1829	.2263	.128	.2263	.1848	.1867	.1991
21	.2218	.2263	.181	.2263	.1867	.1867	.1991
22		.1886	.1848	.1886	.1698	.1867	.1848
23	1.6604	2.0119	.056	.1509	.1509		1.1728
24	1.2041	1.5813	1.7147	.128	.132	.1494	.945
Max	2.2712	2.3685	2.4874	2.5911	2.3685	2.5587	1.9204
Min	.0347	.1402	.056	.0924	.1097	.1307	.1097
Avg	.8372	.8134	.7896	1.0233	.7685	.7766	.5835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 204 / 11 KV ITKARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3292	.3658	.3696	.3658	.3658	.3292
2	.3326	.3292	.3189	.3696	.3658	.3475	.3292
3	.3326	.3292	.3292	.3696	.3658	.3292	.3292
4	.3326	.3292	.3292	.3696	.3658	.3292	.3292
5	.3658	.3658	.3658	.3696	.4024	.3658	.3658
6	.4572	.439	.4024	.4251	.439	.4024	.4024
7	.4572	.4207	.4024	.4251	.3658	.3841	.3658
8	.4435	.3658	.3658	.3881	.4024	.3658	.3475
9	.4066	.3658	.439	.462	.3658	.3658	.3658
10	.439	.3658	.3841	.4024	.362	.3224	.4207
11		.4163	.439	.3944	.4298	.3224	.3696
12		.3658	.4251	.439	.3898	.362	.3881
13		.3658	.3881	.3801	.362	.3439	.3361
14	.3475	.3292	.4066	.362	.394	.3224	.4251
15	.4656	.3292	.4572	.362	.394	.3224	.3142
16	.3856	.3696	.4572	.4477	.362	.3658	.3881
17	.4801	.362			.362	.3258	.3881
18	.3353	.362	.3475		.362	.3121	.4435
19	.4024	.439		.3658	.439	.3475	.4938
20	.5121	.5121	.5068	.4755	.5121	.3841	.4755
21	.3109	.4755	.5068	.5121	.4572	.4207	.5121
22	.439	.439	.4344	.4755	.4207	.4024	.4572
23	.439	.439	.3881	.3658	.4207	.4207	.4207
24	.3292	.3841	.4024	.3881	.3658	.3658	.3475
Max	.5121	.5121	.5068	.5121	.5121	.4207	.5121
Min	.3109	.3292	.3189	.362	.362	.3121	.3142
Avg	.3974	.3845	.4028	.4054	.3947	.3582	.3894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 205 / Shivtirtha Express Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0095	.0156	.0126	.0137	.0126	.0072	.0061
2	.0095	.0149	.0126	.0118	.0126	.0076	.0065
3	.008	.0191	.0126	.0103	.0126	.008	.0069
4	.008	.0194	.0126	.0103		.0076	.0076
5	.0072	.0229	.0114	.0095	.0114	.0076	.0095
6	.0065	.0103	.0126	.0091	.0114	.005	.0053
7	.0061	.0091	.0084	.0095	.0084	.005	.005
8	.005	.0137	.0084	.0091	.0076	.0057	.005
9	.0061	.0091	.0084	.0152	.0084	.005	.0053
10	.0381	.0381	.0095	.0373	.0175	.0076	.0091
11		.0381	.0091	.0373	.0183	.037	.0566
12		.0572	.008	.0566	.0566	.0532	.0554
13		.0572	.013	.0566	.056	.0139	.0554
14	.0099	.0549	.0133	.0566	.056	.0057	.0554
15	.0099	.0566	.0111	.0566	.056	.0057	.0566
16	.0381	.0566	.0103	.056	.056	.0057	.056
17	.0377	.0091			.0572	.0057	.056
18	.0377	.0091	.0549	.0076	.0057	.0069	.0554
19	.0149	.0084	.056	.0084	.0072	.0061	.0554
20	.0191	.0084	.056	.0084	.0076	.0057	.0554
21	.0183	.0126	.0554	.0084	.0084	.0057	.0543
22	.0236	.0084	.0554	.0126	.0191	.0057	.0118
23	.0114	.0084	.056	.0126	.0061	.0057	.0103
24	.0099	.0114	.0084	.0347	.0126	.0069	.0057
Max	.0381	.0572	.056	.0566	.0572	.0532	.0566
Min	.005	.0084	.008	.0076	.0057	.005	.005
Avg	.0159	.0237	.0224	.0238	.0228	.0098	.0294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 201 / 11 KV Karanjawade Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4706	.4163	.3982	.4887	.3982	.3734
2	.4252	.3982	.4344	.362	.4887	.3982	.3734
3	.3898	.3982	.4344	.362	.4887	.3982	.3734
4	.3898	.3982	.4525	.3982	.4887	.3982	.3734
5	.4207	.3982	.4525	.4344	.4706	.3982	.4108
6	.4252	.4344	.4706	.4344	.4706	.3982	.4481
7	.4252	.362	.3982	.3982	.4525	.4344	.3658
8	.4207	.362	.5792	.5792	.4525	.4344	.4908
9	.4557	.5068	.3982	.5792	.5068	.543	.3429
10		.5068	.543	.4887	.4706	.4252	.4557
11		.4525	.5068	.4525	.5068	.4557	.5316
12		.3982	.4344	.3982	.4706	.4908	.5014
13	.4298	.3801	.362	.362	.362	.4207	.4607
14	.3582	.362	.5068	.4163	.5068	.4207	.4961
15	.4298	.3982	.5068	.4525	.5068	.5258	.4961
16	.4298	.4163	.5068	.4163	.4344	.3814	
17	.394	.3982	.543		.4344	.4207	
18	.3224	.3801	.362		.3258	.3506	.4607
19	.724	.4887	.543	.5068	.543	.4706	.6089
20	.724	.724	.6516	.7059	.724	.6653	.7164
21	.6878	.6154	.543	.6154	.5792	.6099	.6024
22	.543	.5249	.5068	.5792	.5068	.5175	.4961
23	.5068	.4525	.4344	.4706	.4344	.4108	.5068
24	.4706	.5068	.3982	.4344	.4887	.4344	.3734
Max	.724	.724	.6516	.7059	.724	.6653	.7164
Min	.3224	.362	.362	.362	.3258	.3506	.3429
Avg	.4668	.4472	.4744	.4657	.4834	.4500	.4663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 202 / 11 KV Devarde AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9686	1.1574	1.2811	
2				.9686	1.1574	1.2498	
3				.9686	1.1574	1.2498	
4				1.0623	1.2037	1.2498	
5				1.1248	1.2346	1.2811	
6				1.2498	1.4043	1.2811	
7				1.9685		1.6872	
8				1.8122	1.1873	1.406	
9	2.2184	2.3746	2.3434				1.9364
10		2.5777	2.6246				2.4646
11		2.4528	2.4059				2.5617
12		2.3278	2.3122				2.5606
13	2.2809	2.234	2.0309				2.4352
14	2.2497	2.1403	1.9997				2.3403
15	2.2184	2.0934	1.9685				2.1506
16	2.0934	1.7341	1.906				2.0309
23			1.0623	1.2191	1.2811		
24					1.1574	1.3123	
Max	2.2809	2.5777	2.6246	1.9685	1.4043	1.6872	2.5617
Min	2.0934	1.7341	1.0623	.9686	1.1574	1.2498	1.9364
Avg	2.2122	2.2418	2.0726	1.2603	1.2156	1.3331	2.3100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 203 / KARVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3437	.4024	.1097	.0724	.0914	.4725
2	.3086	.3125	.4024	.1097	.0724	.0914	.4725
3	.3086	.3125	.439	.1097	.0724	.0914	.4572
4	.3749	.3125	.439	.1463	.0724	.0914	.4572
5	.4062	.4999	.4938	.1463	.0905	.0914	.5247
6	.7274	.6874	.9511	.1829	.1086	.1097	.759
7	.8539	1.0311	1.262	.2561	.1629	.1463	1.1523
8	.7499	.8124	1.0059	.1829	.1629	.1829	.2031
9	.0914	.1097	.1097	.2984	.8869	.9374	.0179
10		.128	.0914	.2812	.9686	1.1069	.0181
11		.128	.0732	.1562	.9998	1.0562	.0181
12		.1463	.0914	.2343	.9374	.9804	.0181
13	.1097	.128	.0914		.8436	.9172	.0183
14	.1097	.1097	.0914	.703	.8436	.8223	.0732
15	.1463	.1097	.0914	.7343	.8749	.7907	.1478
16	.1097	.1097	.1463	.8436	.8436	.828	.128
17	.1463	.1097	.1097		.0732	.1086	.1109
18	.1463	.128	.1463	.0543	.1097	.1448	.1109
19	.1463	.1463	.1463	.1086	.1097	.1478	.1478
20	.1829	.1646	.1829		.1097	.1478	.181
21	.1829	.1463	.1829	.1086	.1097	.1494	.1448
22	.1829	.1463	.1463	.0905	.1097	.1494	.1463
23	.4062	.128	.1097	.0905	.0914	.503	.4938
24	.3437	.4062	.3841		.0724		.4877
Max	.8539	1.0311	1.262	.8436	.9998	1.1069	1.1523
Min	.0914	.1097	.0732	.0543	.0724	.0914	.0179
Avg	.3020	.2774	.3163	.2474	.3666	.4211	.2817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 204 / Ganesh Chikurde LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.2353	.181	.2353	.181	.2353
2	.1991	.2353	.181	.2353	.181	.2353
3	.1991	.2353	.181	.2353	.181	.2353
4	.1991	.2353	.181	.2353	.181	.2353
5	.1991	.2353	.181	.2353	.181	.2353
6	.2353	.2353	.2172	.2353	.2172	.2353
7	.2353	.2353	.2172	.2353	.1629	.2353
8	.2353	.2353	.2172	.2353	.1629	.1791
9	.2353	.0724	.2353	.2353	.1629	.2172
10	.2353	.2353	.2353	.2353	.0343	.181
11	.2353	.2353	.2353	.2353	.0362	.181
12	.2353	.2353	.2353	.2353	.1086	.181
13	.2353	.2353	.0905	.2353	.1086	.181
14	.2353	.2353	.2353	.181	.1086	.181
15	.2353	.2353	.2353	.1086	.2172	.181
16	.2353	.2353	.2353	.1086	.2353	.181
Max	.2353	.2353	.2353	.2353	.2353	.2353
Min	.1991	.0724	.0905	.1086	.0343	.1791
Avg	.2240	.2251	.2059	.2161	.1537	.2069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 201 / 11 KV SURUL AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1738	.1981	.192	.0943	.0934	.0747	.1429
2	.1593	.1852	.192	.0943	.0914	.0747	.1158
3	.1593	.1852	.192	.0943	.0914	.0747	.132
4	.2054	.3086	.2561	.0943	.0914	.0747	.2824
5	.2675	.4531	.3521	.1132	.1075	.0934	.4458
6	.431	.578	.4801	.132	.1075	.0934	.587
7	.7773	.6249	.7362	.1267	.1029	.1086	.535
8	.6859	.6622	.7202	.104	.0857	.1075	.5281
9	.0914	.0924	.0876	.282	.6081		.104
10	.0343	.0895	.0876	.3521	.5213		.0905
11	.0895	.0895	.0895	.3715	.4694	.5182	.0867
12	.0905	.0716	.0914	.3418	.333	.602	.0905
13	.0905	.0716	.0724	.2972	.3144	.5575	.0724
14	.0857	.0701	.0724	.2972	.2606	.5144	.0886
15	.0625	.0701	.0886	.3864	.2503	.4729	.0716
16	.0587	.0701	.0876	.4161	.3144	.4329	.0526
17	.1086	.0914		.0914	.0533	.0895	.0701
18	.1097	.0914	.0886	.0914	.0848	.0895	.0886
19	.1109	.1097	.1052	.112	.104	.0905	.1075
20	.112	.1075	.112	.112	.1097	.0914	.1097
21	.112	.1075	.112	.112	.1109	.0924	.1109
22	.1109	.1075	.0934	.112	.1109	.0747	.1307
23	.2258	.2241	.0747	.112	.1109	.1429	.153
24	.1692	.1981	.2241	.0943	.0934	.0739	.1429
Max	.7773	.6622	.7362	.4161	.6081	.602	.587
Min	.0343	.0701	.0724	.0914	.0533	.0739	.0526
Avg	.1884	.2024	.2003	.1848	.1925	.2066	.1808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 202 / 11 KV RETHRE DHARAN
GAOTHAN Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4294	.3772	.3772	.3772	.3961	.4294
2	.3395	.3734	.3395	.3584	.3395	.3395	.4108
3	.3395	.3547	.3395	.3395	.3395	.3395	.4481
4	.3584	.3734	.3395	.3395	.3361	.3772	.4668
5	.415	.3921	.415	.4338	.4108	.415	.4668
6	.4715	.4108	.4715	.4904	.4755	.4527	.4854
7	.3658	.4024	.4668	.5041	.4207	.3475	.4066
8	.3982	.4119	.4108	.5304	.3856	.394	.362
9	.3506	.3988	.4207	.4525	.3601	.3467	.3601
10	.3294	.3944	.4477	.4207	.3521	.373	.373
11	.3222	.3772	.4075	.4207	.3814	.3511	.3258
12	.3121	.3601	.3681	.4031	.3294	.3641	.3506
13	.3012	.3601	.3801	.4031	.3366	.3856	.3721
14	.3012	.3772	.394	.4031	.3403	.3544	.4119
15	.3045	.3506	.3721	.3856	.3403	.3189	.394
16	.3077	.333	.3681	.3681	.3224	.3045	.3721
17	.3012	.4024		.4755	.3155	.3582	.362
18	.394	.5121	.3391	.5121	.3052	.4344	.3721
19	.5249	.5601		.5975	.4298	.4706	.4298
20	.6036	.6348	.6219	.6722	.6099	.4938	.6283
21	.5729	.5975		.5975	.5914	.5175	.5975
22	.5415	.5658		.5788	.5788	.5415	.5788
23	.4481	.4904		.4904	.4854	.4854	.5041
24	.4108	.4481	.415	.4338	.4527	.4294	.4668
Max	.6036	.6348	.6219	.6722	.6099	.5415	.6283
Min	.3012	.333	.3391	.3395	.3052	.3045	.3258
Avg	.3913	.4296	.4050	.4578	.4007	.3996	.4323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244140 / 33/11 KV RETHARE DHARAN SUB-ST

Feeder No / Name : 203 / 11 KV RETHRE DHARAN AG SEPARATED AG FEEDERS HAVING SPECIAL
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0373	.0366	.084	.096	.1315	.037
2	.0362	.0373	.0366	.084	.096	.12	.037
3	.0362	.037	.0366	.072	.096	.12	.0366
4	.0366	.037	.0358	.084	.128	.1353	.0366
5	.0366	.037	.0358	.0991	.192	.1623	.0362
6	.0366	.037	.0358	.1867	.2561	.1894	.0362
7	.0358	.0358	.0351	.1867	.3521	.4287	.0351
8	.032	.0351	.0351	.2606	.3521	.2921	.0339
9	.2787	.3199	.3361	.0339	.0343	.0339	.3286
10	.3429	.3858	.3841	.0324	.0312	.0316	.4001
11	.3246	.4001	.3081	.0324	.0328	.0347	.4001
12	.2881	.3521	.2679	.0324	.0347	.0339	.3572
13	.2643	.3201	.2503	.0324	.0347	.0332	.3102
14	.2503	.2561	.2332	.0324	.0347	.0324	.2782
15	.2256	.2881	.2435	.0324	.0343	.0312	.2469
16	.1974	.2881	.2401	.0486	.0328	.0305	.2643
17	.0332	.0366		.0549	.0328	.0335	.0347
18	.0339	.0366	.0335	.0549	.0486	.0343	.0347
19	.0351	.0366	.0335	.056	.032	.0343	.0549
20	.0362	.0366	.0362	.056	.0339	.0351	.0554
21	.0362	.0549	.0543	.056	.0354	.0358	.0549
22	.0358	.0549	.0549	.056	.0543	.037	.0554
23	.0373	.0366	.108	.128	.1334	.0373	.0358
24	.0354	.0373	.0366	.084	.128	.1315	.037
Max	.3429	.4001	.3841	.2606	.3521	.4287	.4001
Min	.032	.0351	.0335	.0324	.0312	.0305	.0339
Avg	.1142	.1347	.1264	.0783	.0973	.0925	.1349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 201 / 11 KV BIUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.061	.0648	1.0936	1.0059	.9145	.0949
2	.064	.061	.0648	1.0802	1.0059	.9145	.0617
3	.0625	.061	.0648	1.0802	.9998	.9145	.0937
4	.0625	.061	.0648	1.0494	.9998	.945	.0949
5	.0633	.0762	.081	1.0494	1.0562	.9755	.0949
6	.0625	.0762	.0972	1.0311	1.0059	1.0311	.0926
7	.0633	.0914	.0972	1.1561	1.1888	1.0974	.0926
8	.0625	.0762	.0972	1.1561	1.0059	1.1279	.0926
9	1.9372	1.89	2.1376	.0617	.061	.0914	1.4506
10	2.0081	2.1376	2.1559	.061	.0648	.0625	1.4575
11		2.0309	2.1376	.061	.0648	.0625	1.4575
12	1.9685	1.9372	2.0081	.061	.0625	.061	1.2811
13	1.8435	1.8122	1.8435	.061	.0625	.0648	1.3123
14	1.8747	1.3279	1.8122	.061	.0648	.061	1.2186
15	1.3603	1.2498	1.8461	.0762	.0648	.061	1.1873
16	1.3435	1.8122	1.8138	.0914	.0937	.0625	1.1012
17	.0486	.0972		.0914	.0781	.0762	.0663
18	.0762	.0972	.0625	.0762	.0762	.0937	.0625
19	.0914	.0972	.0633	.0762		.0926	.0937
20	.0762	.0972	.0625	.0914	.0914	.0926	.0949
21	.0762	.0972	.064	.0762	.0762	.0926	.0949
22	.0762	.0972	.0625	.0762	.0762	.0926	.0937
23	.0762	.081	1.1248	1.0059	.884	.0926	.0926
24	.0625	.0762	.0648	1.0936	1.0059	.9145	.0937
Max	2.0081	2.1376	2.1559	1.1561	1.1888	1.1279	1.4575
Min	.0486	.061	.0625	.061	.061	.061	.0617
Avg	.5836	.6459	.7779	.4924	.4824	.4164	.4948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 202 / 11 KV SHIRALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0309	.0305	.0324	.3125	.2743	.3353	.0312
2	.0312	.0305	.0324	.3163	.2743	.3353	.0312
3	.0316	.0305	.0324	.2778	.2743	.3201	.0316
4	.0316	.0305	.0324	.2846	.2439	.3048	.0309
5	.032	.0305	.0324	.25	.2439	.2896	.0316
6	.0316	.0305	.0324	.216	.2439	.2896	.0309
7	.032	.0305	.0324	.2778	.2743	.2896	.0316
8	.0316	.0305	.0324	.2812	.2896	.3048	.0309
9	.5693	.5182	.5182	.0312	.0305	.0305	.4062
10	.5624	.5937	.5312	.0305	.0312	.0305	.3963
11	.5624	.5937	.4858	.0305	.0305	.0312	.3963
12	.5312	.5624	.4999	.0305	.0312	.0305	.4268
13	.5312	.4999	.4687	.0305	.0305	.0305	.4062
14	.5312	.4877		.0305	.0312	.0305	.3749
15	.4877	.4572		.0305	.0312	.0305	.3963
16		.4062	.4687	.0305	.0305	.0297	.3506
17	.0312			.0305		.0305	.0305
18	.0305		.0316	.0305		.0309	.0309
19	.0305	.0324	.0312	.0305	.0305	.0309	.0312
20	.0305	.0324	.0312	.0305	.0305	.0316	.0309
21	.0305	.0324	.0312	.0305	.0305	.0309	.0309
22	.0305	.0324	.0312	.0305	.0305	.0312	.0309
23	.0305	.0324	.3479	.3048	.3353	.0316	.0312
24	.0312	.0305	.0324	.3086	.3048	.3353	.0316
Max	.5693	.5937	.5312	.3163	.3353	.3353	.4268
Min	.0305	.0305	.0312	.0305	.0305	.0297	.0305
Avg	.1858	.2071	.1794	.1357	.1422	.1361	.1522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 203 / 11 KV NATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.759	.6554	.7125	.0633	.0762	.0762	.4111
2	.8002	.6706	.7125	.0633	.0762	.0762	.4111
3	.7811	.6706	.7125	.0617	.0762	.0762	.4012
4	.8223	.6706	.7773	.0633	.0762	.0762	.4428
5	.8124	.6706	.7773	.064	.0762	.0762	.4321
6	.8539	.7011	.8421	.0617	.0762	.0762	.4428
7	.9488	.7164	.8745	.0633	.1067	.0762	.5864
8	.9172	.7773	.8097	.0949	.1067	.0762	.4938
9	.0633	.0914	.081	.7274	.823	.7621	.0625
10	.0937	.0625	.0781	.8535	.2591	.8421	.0625
11		.0625	.0972	.8535		.7125	.0486
12		.0312	.0937	.8383	.9175	.5898	.0648
13		.0625		.7926	.8745	.5668	.0625
14		.0781	.0972	.7621	.7773	.583	.0648
15		.0625	.0972	.6706	.6249	.5506	.0648
16		.0625	.0781	.6706	.583	.4999	.0625
17	.0781	.0625		.0762	.0625	.061	.061
18	.0914		.0633	.0914	.0762	.0633	.0617
19	.0914		.0625	.061	.0914	.0617	.0926
20	.0914		.0633	.0914	.0914	.0617	.0633
21	.1067		.0926	.0914	.0914	.0617	.0617
22	.0914		.0633	.0762	.0914	.0617	.0617
23	.6401		.0937	.0762	.0762	.3749	.4428
24	.759	.6554	.7125	.0617	.0762	.0762	.3749
Max	.9488	.7773	.8745	.8535	.9175	.8421	.5864
Min	.0633	.0312	.0625	.061	.0625	.061	.0486
Avg	.4890	.3758	.3633	.3054	.2690	.2724	.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 204 / 11 KV KAPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8539	.9282	1.086	.4012	.3932	.4641	.7407
2	.8855	.9602	.9717	.4062	.3932		.7907
3	.9061	.9602	.9717	.3704	.3932	.4588	.8223
4	.9259	.9831	1.073	.3704	.426	.4588	.8642
5	.9374	1.0082	1.1012	.3395	.426	.4588	.9259
6	.9568	1.1142	1.1336	.3395	.426	.4752	1.0753
7	1.2651	1.4091	1.2308	.463	.5079	.4915	1.2346
8	1.1728	1.3763	1.1012	.4321	.5079	.4915	1.1111
9	.6958	.5571	.7125	1.142	1.1305	1.1961	.5864
10	.6874	.7865	.6802	1.4255	1.2308	1.2597	.5312
11	.6562	.7449	.6249	1.3763	1.3032	1.2631	.583
12	.6802	.7449	.6154	1.3272	1.0623	1.2308	.583
13	.6802	.6802	.6154	1.3108	1.0688	1.004	.4999
14	.6802	.6478	.6154	1.2452	1.0688	1.0688	.4858
15	.6478	.6154	.6154	1.1305	1.0688	1.0364	.5506
16	.6154	.5312	.6249	1.1633	.8124	.9686	.5182
17	.1619			.1802		.1562	.1677
18	.213		.1875	.1968		.216	.1543
19	.2458	.2267	.1852	.2294	.2458	.2187	
20	.2294	.2267		.192	.213	.1852	.1898
21	.2241	.2267	.1898	.213	.1966	.1898	.216
22	.2294	.1943	.1852	.1966	.1802	.1581	.216
23		.9393	.4687	.4424	.4752	.679	.8642
24	.8539	.9175	.9393	.4012	.426	.4752	.7186
Max	1.2651	1.4091	1.2308	1.4255	1.3032	1.2631	1.2346
Min	.1619	.1943	.1852	.1802	.1802	.1562	.1543
Avg	.6697	.7627	.7240	.6373	.6344	.6350	.6274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 206 / 11 KV BIUR GAOTAHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4066	.362	.4108	.4066	.4066	.4108
2	.4066	.3841	.362	.4066	.4066	.4066	.4108
3	.4024	.3881	.362	.4108	.4066	.3929	.4435
4	.4435	.3921	.362	.4024	.4066	.4066	.439
5	.439	.4251	.3982	.439	.4668	.4066	.4024
6	.4481	.463	.3982	.4481	.499	.4435	.4481
7	.5228	.4805	.4344	.5121	.499	.4668	.4435
8	.4805	.4805	.4706	.5121	.4251	.462	.4066
9	.3696	.462	.4344	.4805	.4251	.4066	.4481
10	.3658	.4435	.3696	.499	.3658	.3696	.3326
11		.3292	.4066		.3658	.4066	.3292
12		.2957	.3292	.4668	.3658	.4024	.1848
13		.3292	.3658	.462	.3658	.2926	.3658
14		.3326	.3326	.462	.3361	.3292	.3696
15		.3696	.2926	.4435	.3292	.3696	.2957
16		.3292	.3658	.3142	.2926	.3696	.3292
17	.3696	.3326			.3658	.3658	.2561
18	.5601	.543	.2195	.2957	.4481	.4435	.3658
19	.5544	.5068	.3326	.462	.462	.5121	.4755
20	.6099	.5068	.4481	.5544	.5729	.6584	.6348
21	.6099	.5068	.5121	.5359	.5601	.5487	.5853
22	.5544	.4344	.5175	.5041	.462	.439	.5544
23	.4251	.4344	.4481	.4854	.4294	.4024	.4435
24	.4108	.4066	.3982	.4108	.4108	.4108	.4024
Max	.6099	.543	.5175	.5544	.5729	.6584	.6348
Min	.3658	.2957	.2195	.2957	.2926	.2926	.1848
Avg	.4657	.4159	.3879	.4508	.4197	.4216	.4074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 208 / 11 KV SHIRALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.961	.7964	.8779	.924	.9425	.961
2	.8779	.961	.7964	.8962	.8871	.9425	.9709
3	.9709	.961	.7964	.8962	.8871	.9425	.9709
4	.9511	.9795	.7964	.9511	.924	.9425	.8779
5	.961	.9979	.8688	.961	.961	.9795	.8962
6	.9709	1.0349	.8688	.9511	1.0134	.9795	.8871
7	.9709	.961	.8688	.8779	.9709	.9335	.8779
8	.8131	.9709	.7964	.9709	.8962	.8131	.8215
9	.8779	.9709	.7964	.8962		.7468	.8048
10	.8871	.9511	.8871	.961	.8871	.8131	.8131
11	.8871	.8779	.9511	.9979	.8871	.8871	.961
12		.8871	1.0242	1.1203	.961	.7316	.9511
13		.8871	.9511	1.1203	.8131	.8871	.8779
14	.961	.9511	.9511	1.1203	.8871	.8779	.9145
15	1.0242	.9511	1.0349	1.0456	.8779	.8962	.961
16	.8871	.961	.8871	.9709	.8871	.8131	.9511
17	.961	.8779		.924	.8779	.8048	.9511
18	.8962	.9412	1.0242	.9896	.9149	.8962	.8871
19	1.0269	1.1584	1.0456	1.0829	1.1827	1.0242	1.0349
20	1.251	1.1203	1.0974	1.1827	1.1949	1.0456	1.0974
21	1.1088	1.0498	1.0456	1.1458	1.1576	1.0456	1.0349
22	1.0719	1.0136	1.0456	1.1576	1.1088	.961	1.0456
23	1.0269	.9412	.9511	1.0456	1.0269	.8871	1.0349
24	.9511	1.0082	.905	.8779	.924	.9709	.8779
Max	1.251	1.1584	1.0974	1.1827	1.1949	1.0456	1.0974
Min	.8131	.8779	.7964	.8779	.8131	.7316	.8048
Avg	.9650	.9740	.9211	1.0009	.9588	.9068	.9359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 209 / 11 KV KAPARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1848	.1448	.1829	.2402	.2033	.1478
2	.1848	.1848	.1448	.1829	.2402	.2033	.1494
3	.2195	.1848	.1448	.1663	.2402	.1848	.1848
4	.2195	.1848	.1448	.1494	.2402	.2033	.1867
5	.2241	.2033	.1448	.1848	.2402	.2033	.1829
6	.2195	.2218	.181	.1867	.2402	.2033	.1848
7	.2195	.2033	.181	.1848	.2218	.2033	.1829
8	.1829	.1848	.181	.2241		.1848	.1494
9	.2195	.1848	.1109	.2587		.1307	.1478
10	.2561		.3658	.2772	.3326	.2587	.1829
11	.2561	.4805	.3696	.2587	.3696	.2926	.2218
12		.4435	.3658	.2772	.3326	.2195	.2957
13		.2926	.2218	.2614	.2195	.2218	.1829
14	.1829	.3658	.2195	.2402	.3292	.1848	.2195
15	.2218	.4024	.2218	.4481	.3658	.2195	.181
16	.1848	.2926	.2195	.2402	.3658	.1848	.1848
17	.1463	.3696			.4024	.1829	.2195
18	.1848	.3258	.1463		.2957	.1463	.1463
19	.2218	.2534	.1829		.2587	.2218	.1829
20	.2772	.2534	.2561	.2772	.2957	.2587	.2587
21	.1848	.2534	.2926	.3881	.2587	.2561	.2587
22	.2587	.2172	.2926	.3142	.2378	.2195	.2218
23	.2033	.181	.1848	.2987	.2033	.1463	.1867
24	.1829	.1848	.181	.1848	.2402	.2033	.1463
Max	.2772	.4805	.3696	.4481	.4024	.2926	.2957
Min	.1463	.181	.1109	.1494	.2033	.1307	.1463
Avg	.2108	.2632	.2130	.2470	.2805	.2057	.1919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 401 / 33 KV GLUCOSE EXPRESS

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995	.1029	.1029	.0983
2	.1006	.1017	.1029	.1006
3	.0926	.1017	.1029	.0995
4	.0995	.1017	.1029	.1006
5	.0995	.1526	.1029	.0995
6	.0983	.1526	.1029	.0983
7	.0995	.1526	.1029	.1006
8	.0995	.1526	.1029	.1006
9	.1006	.1543	.1029	.0995
10	.0937	.1029	.1029	.0983
11	.0937	.0972	.0972	.1006
12	.0937	.0937	.0972	.1543
13	.0937	.0995	.0937	.1017
14	.0937	.0972	.0937	.0914
15	.0995	.0914	.0972	
16	.0995	.0972	.0937	
17	.0972	.0914		
18	.1526	.1029	.1006	
19	.1526	.1029	.0983	
20	.1526	.1086		
21	.1543	.1029	.0995	
22	.1526	.1029	.0983	
23	.1526	.1029	.0949	
24	.0983	.1543	.1029	.0995
Max	.1543	.1543	.1029	.1543
Min	.0926	.0914	.0937	.0914
Avg	.1112	.1134	.0998	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 402 / 33 KV RETHARE DHARAN

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7116	.7122	.8145	.4687	.7122	.7202	.6642
2	.759	.7122	.8145	.463	.6613	.721	.6481
3	.8333	.7122	.8688	.4744	.6687	.7202	.6642
4	.8436	.7122	.8688	.5093	.6613	.7202	.7116
5	.9122	.763	.8688	.5155	.7122	.6687	.7407
6	.9962	.823	1.0317	.5093	.721	.6687	.8539
7	1.2334	1.3735	1.4118	.6481	.9774	.7725	1.2037
8	1.1111	1.2209	1.2489	.6481	.824	.823	.9374
9	.6481	.7716	.8688	.6562	1.1317	.4115	.7499
10	.8259	.8951	.8259	.823	1.0202	.2343	.8745
11	.3401	.7956	.7773	.8139	.9717	.9231	.7773
12	.583	.7459	.6882	.823	.7287	1.2146	.7773
13	.583	.6802	.7287	.8139	.6562		.7773
14	.5967	.583	.6464	.8139	.6802	.9831	.6802
15	.583	.6316	.6316	.8139	.6316	.8905	.6962
16	.503	.6962	.6802	.9156	.6562	.8436	.6562
17	.2915	.3281	.6642	.3052	.3401	.3121	.3749
18	.3601	.4344	.3749	.3601	.4578	.2812	.3704
19	.463	.543	.4744	.4115	.5087	.4167	.3795
20	.6104	.6516	.5556	.6687	.6687	.5624	.6019
21	.6104	.6516	.5624	.6687	.6613	.5093	.5624
22	.6173	.6516	.5155	.6613	.6173	.5093	.5093
23	.6687	.8145	.5556	.6173	.6687	.5693	.6481
24	.6562	.7122	.8145	.463	.7122	.721	.6562
Max	1.2334	1.3735	1.4118	.9156	1.1317	1.2146	1.2037
Min	.2915	.3281	.3749	.3052	.3401	.2343	.3704
Avg	.6809	.7340	.7622	.6194	.7104	.6607	.6881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 201 / 11 KV CHARAN AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0857	.0686	.0686	
2				.0686	.0514	.0686	
3				.0686	.0514	.0686	
4				.0686	.0514	.0857	
5				.0857	.0686	.0857	
6				.12	.0857	.1029	
7				.1372	.1886	.1715	
8				.1372	.1715	.1543	
9	.2915	.3086	.2915				.2572
10	.2915	.3772	.3429				.2915
11	.2915	.3772	.3944				.2915
12	.2915	.3429	.3086				
13	.2743	.3429	.2915				.2915
14	.2401	.3086	.2915				.3429
15	.2572	.2572	.3086				.3429
16	.2743	.2229	.3086				.2743
23			.1029	.0686	.0686		
24				.1029	.0686	.0686	
Max	.2915	.3772	.3944	.1372	.1886	.1715	.3429
Min	.2401	.2229	.1029	.0686	.0514	.0686	.2572
Avg	.2765	.3172	.2934	.0943	.0874	.0972	.2988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 202 / 11 KV MANDOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4287	.4801	.4458	.4458	.4801	.4458
2	.4115	.3944	.4115	.4115	.4115	.4115	.4287
3	.3944	.3601	.3772	.3772	.4115	.4115	.4115
4	.3944	.3601	.3772	.3772	.4458	.4115	.4115
5	.3944	.4115	.4801	.4115	.4458	.463	.4458
6	.4287	.4973	.5658	.4801	.4973	.5144	.5487
7	.4973	.583	.6516	.583	.5487	.6001	.583
8	.583	.6001	.6516	.6173	.6001	.583	.6001
9	.5658	.6001	.6173	.6173	.583	.583	.5487
10	.5658	.583	.583	.6173	.5658	.5144	.6001
11	.6173	.3944	.4801	.6001	.583	.5487	.5658
12	.5316		.5144	.6173	.583	.5316	
13	.4801	.583	.5316	.5658	.5144	.5316	.583
14	.4458	.5487	.5487	.5316	.5144	.5144	.583
15	.463	.5487	.5316	.5144	.5144	.5316	.6173
16	.5658	.583	.4801	.5487	.4973	.5144	.6344
17	.5144	.6516			.4973	.5658	.6344
18	.5316	.703	.583	.5487	.5144	.583	.5658
19	.6516	.7373		.6516	.6173	.6687	.6516
20	.823	.9259	.8916	.703	.7716	.7716	.8059
21	.7716	.823	.8059		.7545	.7716	.7202
22	.6859	.6859	.7545	.7202	.703	.6859	.703
23	.5658	.6173	.583	.5658	.6344	.6173	.6001
24	.4801	.463	.5144	.4801	.4801	.4801	.5144
Max	.823	.9259	.8916	.7202	.7716	.7716	.8059
Min	.3944	.3601	.3772	.3772	.4115	.4115	.4115
Avg	.5337	.5688	.5643	.5448	.5473	.5537	.5740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 203 / 11 KV CHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3429	.4115	.4115	.3772	.3601	.3772
2	.3429	.3086	.3429	.3772	.3429	.3429	.3429
3	.3086	.3086	.3086	.3429	.3429	.3429	.3258
4	.3086	.3086	.3086	.3429	.3429	.3429	.3258
5	.3429	.3772	.3429	.3772	.4115	.3429	.3601
6	.3944	.4458	.4287	.4287	.463	.3772	.4458
7	.5316	.5144	.5658	.5658	.583	.5487	.5487
8	.5487	.5487	.5316	.5658	.5487	.5658	.5487
9	.4973	.5316	.5316	.5316	.5316	.5316	.5144
10	.463	.4801	.4973	.583	.4801	.5487	.5144
11	.4287	.5144	.583	.5316	.4973	.5316	.5487
12	.463		.5487	.6173	.5316	.5144	
13	.463	.5658	.5144	.583	.5144	.5144	.4973
14	.4801	.4801	.4458	.583	.4801	.5144	
15	.4801	.4801	.463	.5487	.4801	.5144	.5144
16	.4458	.4973	.5316	.5144	.4973	.4973	.5144
17	.4115	.5144		.4115	.463	.5316	.5487
18	.4287	.5144	.4973	.4458	.4973	.5487	.5144
19	.5144	.6001		.5316	.5658	.5658	.6173
20	.6001	.6859	.6687	.6859	.6516	.703	.7373
21	.6001	.6173	.6516	.6516	.6516	.6859	.6859
22	.5487	.5487	.583	.6344	.5658	.5658	.6516
23	.463	.5144	.5144	.4973	.4973	.4973	.5316
24	.3944	.3944	.4458	.4458	.3944	.4287	.4115
Max	.6001	.6859	.6687	.6859	.6516	.703	.7373
Min	.3086	.3086	.3086	.3429	.3429	.3429	.3258
Avg	.4508	.4823	.4871	.5087	.4880	.4965	.5035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 204 / 11 KV MANDOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5487	.5144	.5144	
2				.5487	.5144	.5144	
3				.5487	.4801	.5144	
4				.5487	.4801	.5144	
5				.583	.583	.5144	
6				.6859	.6859	.6344	
7				.823	.823	.7202	
8				.823	.7716	.7202	
9		.9431	1.1317		.0171		1.0974
10	1.0974	1.166	1.166		.0171		1.0974
11	1.1488	1.2346	1.2689		.0171		1.0974
12	1.1317	1.1488	1.166		.0171		
13	1.1488	1.166	1.166		.0171		1.0974
14	1.1317	1.1317	1.0802				1.0288
15	1.1488	1.0974	1.0288				1.0117
16	.9774	1.0631	.6001				1.0631
23			.5487	.4973	.4973		
24				.5487	.5144	.5144	
Max	1.1488	1.2346	1.2689	.823	.823	.7202	1.0974
Min	.9774	.9431	.5487	.4973	.0171	.5144	1.0117
Avg	1.1121	1.1188	1.0174	.6156	.3966	.5735	1.0705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 401 / 33 KV WARNAWATI

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0874	.0977	.0926	.0977	.072	.0823	.0874
2	.0874	.0926	.0926	.0977	.072	.0823	.0874
3	.0874	.0874	.0823	.0977	.072	.0823	.0823
4	.0874	.0874	.0874	.0977	.0772	.0823	.0823
5	.0874	.0977	.0926	.0977	.0772	.0874	.0874
6	.0926	.0977	.0977	.0977	.0772	.0874	.0874
7	.1029	.0874	.0977	.0977	.072	.0977	.0874
8	.1029	.0514	.1029	.1132	.072	.0977	.0977
9	.0977	.0514	.0977	.0977	.072	.0977	.0977
10	.0977	.0926	.0977	.0977	.1029	.0977	.0977
11	.0926	.0977	.0823	.0977	.1029	.0874	.0977
12	.0977	.0926	.0926	.0874	.0874	.0874	.0926
13	.0926	.0926	.0874	.0874	.0874	.0874	.0926
14	.0926	.0926	.0926	.0977	.0926	.0977	.0874
15	.0926	.0874	.0874	.0977	.1029	.0874	.0823
16	.0926	.0874	.0926	.0926	.0926	.0514	.0874
17	.0874	.0977		.0977	.0926	.0103	.0977
18	.0874	.0772		.0977	.1029	.0874	
19	.0926	.0977	.0926	.0977	.1029	.0874	
20	.0926	.0874	.0617		.0823	.0617	.0926
21	.0977	.0874	.0977	.0926	.0823	.0977	.0823
22	.0977	.0926	.0977	.0926	.0874	.0874	.0874
23	.0977	.0977	.0977	.0926	.0874	.0874	.0874
24	.0926	.0977	.0977	.0977	.072	.0874	.0874
Max	.1029	.0977	.1029	.1132	.1029	.0977	.0977
Min	.0874	.0514	.0617	.0874	.072	.0103	.0823
Avg	.0932	.0887	.0919	.0966	.0851	.0833	.0895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 402 / 33 KV GUDE PACHGANI

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.4115	.9259	.9259	.9259	.6173	1.6461
2	1.3375	.7716	.5144	.7202	1.0288	.5144	.9259
3	1.5432	1.0288	.6173	.823	1.0288	.4115	1.749
4	1.2346	.3086		.7202	1.1317	.2572	1.5432
5	1.0288	.4115		.6687	1.0288	.2058	.6173
6	.9774	.823	.6173	.7202	1.2346	.3086	.2058
7	.7202	.9259	1.2346	.6173	.6173	.2058	.2058
8	.5658	.3086	1.3375		.3086		.6173
9			.823		.7202		.4115
10			.5144		.4115		
11	.2058	1.1317	.4115	.2058	.5658		.2058
12	.3086	.823	.2058		.3086		.3086
13	.4115	.7202	.2058		.2572		
14	1.749	.2058	.9259	.3086	1.1317	.2058	.3601
15	1.5947	.4115	1.0288		1.4403		.463
16	1.9033	.823	.9259		2.0062	.463	.3086
17	1.5432	.2058	2.8807	1.5432	1.8519	.6173	1.3889
18	2.572	.6173	.4115	1.749	1.9033	1.0288	2.1605
19	1.6975	.5144	1.9547	1.749	.0823	1.2346	1.0288
20	1.0802	.823	.2058	1.5432	1.0288	1.1831	1.286
21	.4115	.823	.6687	1.749	.6687	.6687	1.4918
22	.4115	.4115	.7202	1.4403	.7202	1.4918	.9259
23	.3086	.7202	.6687	.3086	.7202	2.1605	1.286
24	.9259	.2058	1.0288	.823	.823	.823	2.0062
Max	2.572	1.1317	2.8807	1.749	2.0062	2.1605	2.1605
Min	.2058	.2058	.2058	.2058	.0823	.2058	.2058
Avg	1.0709	.6103	.8558	.9774	.9144	.7292	.9610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 201 / 11 KV KANDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0514	.0709	1.4586	1.4251	1.094	.124
2	.0335	.0514	.0532	1.4586	1.4251	1.094	.1052
3	.0335	.0514	.0537	1.4918	1.4251	1.0277	.1052
4	.0335	.0514	.0537	1.5581	1.4586	1.0277	.1052
5	.0335	.0876	.0701	1.5912	1.3916	1.0608	.1052
6	.0335	.0829	.0876	1.6078	1.5257	1.094	.1214
7	.0335	.081	.064	1.6598	1.7772	1.2597	.1402
8	.0335	.081	.0743	1.6907	1.291	1.326	.1578
9	2.1293	2.1714	2.2131	.0335	.0305	.156	2.0317
10	2.2377	2.3137	2.2466	.0335	.0305	.1372	1.8351
11	2.2542	2.1795	2.2708			.1387	1.5074
12	2.0222	2.1382	2.2874			.12	1.4091
13	2.1051	2.1125	1.989	.0335	.0305	.1174	1.8351
14	2.0553	2.0957	1.9559	.0335	.0305	.1174	1.8351
15	2.0885	2.1125	1.9559	.0335	.0305	.1187	1.8679
16	2.0388	1.9393	1.9062	.0335	.0305	.116	1.8023
17	.128	.0972		.0335	.0305	.1187	.1372
18	.1029	.1014	.1219	.0335	.0305		.1372
19	.1372	.096		.0335	.0305	.1715	.1372
20	.1372	.1006	.0819	.0335	.0305	.1387	.1372
21	.1029	.08	.0686	.0335	.0305	.1214	.1372
22	.0686	.0857	.0686	.0335	.0305	.1227	.1372
23	.0514	.0876	1.442	.218	1.1603	.124	.1372
24	.0335	.0514	.0701	1.4586	1.4083	1.1603	.124
Max	2.2542	2.3137	2.2874	1.6907	1.7772	1.326	2.0317
Min	.0335	.0514	.0532	.0335	.0305	.116	.1052
Avg	.7484	.7625	.8730	.6634	.6661	.5201	.6738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 202 / 11 KV NATOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335			.4268	.4191	.4062	
2	.0335			.4687	.4191	.4062	
3	.0335			.4687	.4191	.4062	
4	.0335			.4999	.4024	.421	
5	.0335			.5312	.4024	.4374	
6	.0335			.5624	.5533	.4687	.0179
7	.0335			.5937	.6874	.6874	
8	.0335			.5937	.5365	.6562	.0187
9	.6371	.679	.6327	.0335		.0151	.6478
10	.6859	.6173	.6481	.0335		.016	.7499
11	.6097	.5624	.5944	.0335			.6874
12	.5944	.503	.6097	.0343		.0152	.6249
13	.5182	.503	.4877	.0343			.703
14	.4877	.442	.4877	.0335			.7186
15	.4572	.4725	.4572	.0343			.7186
16	.5864	.4161	.503	.0335		.0181	.6249
17		.0149		.0335		.017	.0324
18		.0147	.0145	.0335			.0362
19	.0164	.0166		.0343		.0171	
20	.0164	.0185	.0183	.0335			
21		.0177	.0183	.0335			
22		.0179		.0343			
23		.0183	.3658	.4024	.4321		
24	.0335			.4268	.4191	.4374	
Max	.6859	.679	.6481	.5937	.6874	.6874	.7499
Min	.0164	.0147	.0145	.0335	.4024	.0151	.0179
Avg	.2585	.2876	.4031	.2270	.4691	.2950	.4650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 204 / 11 KV KANDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1886	.2987	.2614	.1677	.2561	.3174
2	.1677	.1886	.3018	.2614	.1677	.2561	.3206
3	.1677	.1886	.2829	.2614	.1677	.2561	.3206
4	.1677	.1886	.2829	.2987	.1677	.2561	.3206
5	.1677	.2263	.2829	.2987	.1677	.2561	.3395
6	.1524	.2241	.2614	.3361	.2012	.2926	.3547
7	.1677	.2195	.3475	.3361	.2012	.3292	.3142
8	.1677	.2195	.2926	.3361		.2926	.2926
9	.1677	.208	.2896	.1677		.2835	.2561
10	.1949	.1928	.208	.1677		.2658	.2195
11	.197	.3439	.2743			.2715	.2195
12	.2454	.3012	.2401			.2715	.2195
13	.1478	.2865	.2058	.1677	.2534	.2126	.2561
14	.1494	.2896	.1715	.2012	.2534	.2149	.2561
15	.168	.2926	.1715	.2012	.2534	.2328	.2561
16	.1463	.2328	.2401	.1677	.2534	.3077	.176
17	.2058	.2804		.1677	.2534	.2865	.2561
18	.1629	.3294	.2347	.1677	.2172	.3018	.2195
19	.2804	.3439		.2347	.2534	.2454	.2561
20	.3012	.3511	.3696	.2347	.362	.2896	.3292
21	.2896	.3881	.3361	.2347	.362	.3292	.3292
22	.2987	.3734	.3361	.2012	.3258	.3696	.2926
23	.2614	.3547	.3361	.2012	.3109	.3361	.2926
24	.1677	.2263	.3361	.2987	.1677	.2926	.3361
Max	.3012	.3881	.3696	.3361	.362	.3696	.3547
Min	.1463	.1886	.1715	.1677	.1677	.2126	.176
Avg	.1963	.2683	.2773	.2365	.2372	.2794	.2813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 205 / 11 KV NATOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.0754	.0934	.0747	.1006	.0724	.0739
2	.0671	.0754	.0754	.0747	.0671	.0724	.0739
3	.0671	.0754	.0754	.0747	.0671	.0724	.0739
4	.0671	.0754	.0747	.0747	.0671	.0724	.0732
5	.0671	.0754	.0934	.0747	.0671	.0724	.0914
6	.1006	.0943	.1109	.1109	.0671	.1086	.1097
7	.1006	.1132	.0905	.112	.1006	.1448	.0848
8	.1006	.1132	.0876	.112	.1006	.1086	.0867
9	.1006	.1187	.1187	.1006	.0983	.1475	.0867
10	.1134	.1017	.0949	.1006	.0983	.1265	.0876
11	.1296	.1052	.1296	.1006	.0983	.0648	.0876
12	.1296	.1326	.1296	.1006	.0983	.0838	1.5074
13	.104	.0848	1.3927	.1006	.0983	.1174	.1052
14	.192	.0848	.1029	.1006	.0983	.1029	.1052
15	.16	.116	.1029	.1006	.0983	.0857	.1052
16	.0867	.0972	.1372	.1006	.0983	.0983	
17	.0995	.096		.1006	.0983	.0829	.1052
18	.12	.1147	.0995	.1006	.0983	.112	.1227
19	.1214	.1372		.1341	.1147	.104	.1402
20	.1578	.1433	.1991	.1341	.1753	.1433	.181
21	.1612	.1448	.1829	.1341	.1402	.1433	.1448
22	.1478	.128	.1494	.1341	.1052	.1267	.1448
23	.1132	.112	.112	.1341	.1052	.0934	.0905
24	.1006	.0754	.0934	.112	.1006	.0724	.0934
Max	.192	.1448	1.3927	.1341	.1753	.1475	1.5074
Min	.0671	.0754	.0747	.0747	.0671	.0648	.0732
Avg	.1128	.1038	.1703	.1040	.0984	.1012	.1641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 401 / 33 KV JYOTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4527	.3961	.2515	.4527	.4527
2	.5093	.4527	.5093	.2515	.4527	.4527
3	.5093	.4527	.5093	.2515	.4527	.4527
4	.5093	.4527	.5093	.2515	.5093	.4527
5	.5093	.4527	.5093	.2515	.5093	.4527
6	.5093	.5093	.5093	.2515	.5093	.5093
7	.5093	.5093	.5093	.2515	.5093	.5093
8	.5093	.5093	.5093	.2515	.5093	.5093
9	.5093	.5093	.4527	.2829	.5093	.5093
10	.5093	.0457	.4527	.2829	.5093	.5093
11	.5093	.5093	.4527	.5093	.5093	.5093
12	.5093	.5093	.4527	.5093	.5093	.5093
13	.5093	.5093	.4527	.5093	.5093	.5093
14	.5093	.5093	.4527	.5093	.5093	.5093
15	.5093	.5093	.4527	.5093	.5093	.5093
16	.5093	.5093	.4527	.5093	.5093	.5093
Max	.5093	.5093	.5093	.5093	.5093	.5093
Min	.3961	.0457	.3961	.2515	.4527	.4527
Avg	.5022	.4626	.4739	.3521	.4987	.4916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 201 / 11 KV WAKURDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	1.2239	1.2574	.032	.061	.0549	1.1603
2	.7865	1.2239	1.2071	.0343	.0625	.0533	1.1736
3	.7865	1.21	1.1736	.0343	.0625	.0533	1.1736
4	.4588	1.21	1.1736	.0495	.061	.0533	1.1736
5	.7865	1.2209	1.1736	.0472	.061	.0533	1.326
6	.9724	1.2209	1.3565	.0472	.0625	.0495	1.326
7	1.1869	1.1603	1.56	.0335	.0781	.0572	1.1797
8	1.1065	1.1603	1.4922	.0335	.0781	.0789	1.2452
9	.1063	.0343	.061	.6706	1.6057	1.8991	.0366
10	.0351	.061	.061	1.0562	1.9839	2.0348	.1113
11	.032	.061	.0274		2.3061	2.0348	.0869
12		.061	.0274	1.6787	2.5972	2.0348	.0846
13		.0625	.0274	1.8821	1.9951		.0789
14	.0251	.0594		1.9281	1.9616	1.768	.0947
15	.0251		.032	1.9951	1.4746	1.757	.08
16	.0234	.061	.032	1.9669	1.7736	1.757	.0934
17	.0335	.061		.0743	.0629	.0366	.0947
18	.0335	.0762	.032		.0766	.0358	.0947
19	.04	.1094	.032	.1094	.0907	.0467	.0934
20	.041	.1094	.032	.125	.1014	.0553	.1158
21	.041	.1094	.0312	.0937	.1014	.0476	.1158
22	.032	.1094	.0312	.0762	.0857	.0553	.1
23	1.1271	1.2742	.032	.0781	.0579	1.1603	1.3599
24	.7712	1.2239	1.3565	.032	.0762	.0572	1.1603
Max	1.1869	1.2742	1.56	1.9951	2.5972	2.0348	1.3599
Min	.0234	.0343	.0274	.032	.0579	.0358	.0366
Avg	.4199	.5697	.5550	.5490	.7032	.6623	.5650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 202 / 11 KV TAKAVE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1109	.1097	.9282	1.0277	1.1142	.1478
2	.1097	.1109	.0924	.9282	1.0277	1.0688	.1478
3	.1086	.1109	.0914	.9282	1.0277	1.0688	.1448
4	.1075	.1109	.0914	.9503	1.0322	1.0688	
5	.1075	.1132	.0924	.9503	1.065	1.0688	.1478
6	.1086	.1132	.0914	.9503	1.2289	1.3279	.1478
7	.1052	.1448	.1075	1.1069	1.7404	1.587	.1463
8	.1029	.1463	.1267	1.1523	1.6409	1.491	.1463
9	2.2131	2.3472	2.1548	.1433	.1595	.1433	1.9227
10	2.1795	2.5774	2.1548		.1463	.1417	2.1963
11	2.1795	2.5434	2.1365	.1433	.1433	.1448	2.2043
12		2.2634	2.1365	.1086	.1448	.1448	2.079
13		2.0957	2.1365	.1086	.1448	.1086	2.0119
14	1.989	2.0957	2.1365	.1086	.124	.1086	1.9281
15	2.1216		1.7238	.0905	.1254	.1402	2.0622
16	2.1216	2.0957	1.7238	.0537	.1174	.1402	
17	.1017	.124		.0895	.124	.1448	.0678
18	.1357	.1417	.1387	.1267	.156	.1433	.0838
19	.1372	.1417	.1326	.1463	.1387	.1448	.1772
20	.1753	.1417	.1326	.1663	.1646	.1478	.1646
21	.1753	.1417	.1086	.1478	.1646	.1478	.1646
22	.1448	.1772	.1086	.1478	.1663	.1494	.1646
23	.1109	.1267	.9282	1.1142	1.2125	.1478	.1463
24	.1097	.1109	.1097	.9282	1.0322	1.1469	.1478
Max	2.2131	2.5774	2.1548	1.1523	1.7404	1.587	2.2043
Min	.1017	.1109	.0914	.0537	.1174	.1086	.0678
Avg	.6707	.7863	.8159	.5008	.5856	.5433	.7523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 203 / 11 KV PADALI AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.5182	.4428	.0286	.0429	.0324	.3932
2	.4481	.5182	.4428	.0286	.0446	.0324	.3932
3	.4481	.5121	.4428	.0286	.0446	.032	.3932
4	.4481	.5121	.4428	.0305	.0446	.032	.3932
5	.4481	.5243	.4374	.0305	.0429	.0324	.3725
6	.4915	.4588	.506	.0305	.0434	.0655	.3725
7	.639	.6036	.6009	.0305	.061	.064	.5898
8	.583	.5506	.6081	.0248	.061	.0781	.5182
9	.0309	.0394	.0457	.2035	.5624	.5344	.0246
10	.045	.0572	.0286	.2713	.5992	.5365	.0278
11	.0472	.0429	.0556		.5761	.5365	.0457
12		.0429	.0556		.6226	.5967	.0297
13		.0446	.0556	.176	.6081	.5967	.044
14	.0442	.0429	.0556	.2401	.6401	.5967	.0587
15	.0442	.0429	.0198	.3479	.5601	.583	.0602
16	.036	.0429	.0198		.5761	.583	.0587
17	.036	.0572		.0429	.0617	.0377	.0602
18	.045	.0714	.0198	.0446	.0602	.032	.0602
19	.0472	.0724	.0234	.0446	.061	.0332	.061
20	.0503	.0724	.0312		.0648	.0518	.0633
21	.0503	.0743	.0312	.0762	.0648	.0518	.0633
22	.0488	.0594	.0312	.0762	.0486	.0394	.0633
23	.4534	.3749	.0286	.061	.0328	.3932	.4481
24	.4752	.5182	.0469	.0286	.0429	.0328	.3932
Max	.639	.6036	.6081	.3479	.6401	.5967	.5898
Min	.0309	.0394	.0198	.0248	.0328	.032	.0246
Avg	.2458	.2439	.1944	.0923	.2319	.2335	.2078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 204 / 11 KV PADALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.1848	.1928	.1848	.1867	.1848
2	.1848	.1848	.1848	.1991	.1848	.1848	
3	.1848	.1829	.1848	.1991	.1848	.1848	.1829
4	.1829	.1829	.1867	.1991	.1848	.1867	.1829
5	.2012	.2218	.1848	.1886	.1829	.1848	.2195
6	.2534	.2218	.2402	.1886	.2195	.2353	.2195
7	.2481	.2126	.2195	.2896	.2534	.2481	.2328
8	.2204	.2126	.2103	.1943	.2279	.2427	.2103
9	.2254	.208	.2229	.2126	.208	.2401	.2058
10	.1715	.1715	.2229	.2126	.1677	.2058	.2058
11	.1296	.1696	.1433	.1772	.1677	.2058	.1907
12		.1526	.1433		.1357	.208	.2035
13		.1341	.1433	.2149	.1865	.1734	.1772
14	.1989	.1357	.0663	.1886	.1865	.1734	.1734
15	.1989	.1543	.0663	.1886	.1734	.1341	.1595
16	.1296	.1715	.0663	.1865	.1715	.1341	.1907
17	.1296	.1187		.1357	.1865	.208	.1696
18	.1898	.1357	.192	.1372	.2012	.208	.1865
19	.2683	.2454	.1265	.2587	.2058	.2427	.2572
20	.2835	.2896	.2587	.3174	.2561	.2195	.3224
21	.2835	.2896	.2587	.2987	.2561	.2195	.3109
22	.2561	.2743	.2587	.2614	.2402	.2218	.2772
23	.2172	.2218	.2103	.2218	.2241	.2218	.2195
24	.1848	.1848	.2012	.1928	.2012	.1848	.1848
Max	.2835	.2896	.2587	.3174	.2561	.2481	.3224
Min	.1296	.1187	.0663	.1357	.1357	.1341	.1595
Avg	.2058	.1942	.1816	.2111	.1996	.2023	.2116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 205 / 11 KV WAKURDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1829	.2427	.2378	.2614	.2587	.2641
2	.2218	.1829	.2452	.2378	.2614	.2587	.2534
3	.2218	.181	.2452	.2378	.2614	.2561	.2534
4	.2218	.181	.2427	.2303	.2587	.2561	.2534
5	.2218	.2172	.2402	.2614	.2587	.2561	.2534
6	.3109	.2172	.2801	.2614	.2743	.3077	.2534
7	.3012	.2534	.2772	.2896	.3109	.3506	.3292
8	.3121	.2507	.2835	.2865	.3012	.333	.2896
9	.2947	.2774	.298	.3189	.3086	.3258	.3224
10	.2321	.3045	.298	.3155	.2947	.2427	.3018
11	.2401	.3018	.3258		.3052	.2427	.3086
12		.2515	.3258	.3258	.3086	.2427	.3052
13		.2374	.3258	.3429	.285	.2865	.3222
14	.2835	.2229	.2743	.3121	.2683	.2865	.3258
15	.2835	.2427	.2743	.3294	.2743	.3086	.3018
16	.2713	.2743	.2743	.3121	.2785	.3086	.3201
17	.2713	.2774		.2774	.2949	.2652	.3361
18	.2984	.3155	.208	.3506	.2932	.2683	.3521
19	.3391	.3189	.3391	.3658	.3391	.3121	.4096
20	.4024	.4252	.4344	.499	.4706	.4344	.4961
21	.4024	.4024	.4344	.4481	.4163	.4344	.4525
22	.3018	.3511	.362	.415	.3696	.3696	.4066
23	.2263	.2987	.2926	.3174	.3326	.2641	.3326
24	.2402	.1829	.2427	.2378	.2614	.2772	.2641
Max	.4024	.4252	.4344	.499	.4706	.4344	.4961
Min	.2218	.181	.208	.2303	.2587	.2427	.2534
Avg	.2782	.2646	.2942	.3135	.3037	.2978	.3211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 206 / 11 KV TAKAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075		.2427	.2534	.2075	.1886	.2241
2	.2075	.2241	.2263	.2534	.2075	.1886	.2241
3	.2075	.2241	.2263	.2561	.2075	.1886	.2241
4	.2075	.2263	.2263	.2561	.2075	.1886	.2263
5	.2075	.2263	.2241	.2926	.2033	.1886	.2263
6	.2452	.2263	.2614	.2926	.2614	.2452	.2263
7	.2801	.2926	.2957	.2534	.2957	.2926	.2926
8	.3258	.2534	.2743	.1063	.2172	.3077	.2241
9	.3189	.2507	.2896	.2172	.2534	.3258	.2865
10	.2632	.2218	.2587		.2896	.2454	.2715
11	.181	.2218	.2587	.3361	.2835	.2454	.2743
12		.2172	.2587	.3258	.2715	.2454	.3012
13		.2218	.2587	.3077	.2149	.2172	.2658
14	.2481	.2172	.2587	.2715	.1991	.2172	.2534
15	.2481	.2279	.2218	.2561	.2149	.2172	.2926
16	.2103	.2103	.2218	.2172	.2012	.2172	.197
17	.2103	.1595		.2743	.2058	.1433	.2328
18	.2195	.1791	.1341	.2957	.2427	.2149	.2328
19	.2534	.2534	.2401	.3142	.3429	.3224	.2454
20	.4024	.4163	.208	.4163	.4938	.4344	.4755
21	.4024	.3881	.3467	.4481	.4207	.4344	.4527
22	.3361	.4066	.3467	.3921	.3881	.3734	.3584
23	.2614	.3921		.3174	.3174	.2263	.2829
24	.2263	.2263	.2427	.2534	.2241	.2263	.2263
Max	.4024	.4163	.3467	.4481	.4938	.4344	.4755
Min	.181	.1595	.1341	.1063	.1991	.1433	.197
Avg	.2577	.2558	.2510	.2873	.2655	.2539	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 201 / 11 KV MANGLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2835	.2481	.2835	.2804	.2804	.2804	.2804
2	.2835	.2481	.2629	.2629	.2629	.2629	.2601
3	.2835	.2658	.2658	.2629	.2629	.2629	.2629
4	.2835	.2481	.2835	.2804	.2629	.2629	.2804
5	.3012	.2835	.2835	.2804	.2804	.2804	.2835
6	.3012	.3189	.2865	.3155	.2804	.3155	.3258
7	.2835	.3189	.3189	.3155		.3506	.3155
8	.2835	.2835	.3155	.3506	.2804	.3155	.3155
9	.2835	.2865	.3155	.3155	.2804	.2804	.298
10	.2658	.2772	.3155	.3506	.2629	.3155	.333
11	.2835	.2835	.3155		.2804	.2835	.2804
12	.2658	.2865	.2804		.298	.3155	.3155
13	.2658	.2743	.3155	.4075	.2629	.2804	.3155
14	.2481	.2658	.298	.3544	.2454	.3292	.298
15	.2481	.2772	.3155		.2629	.3189	.3155
16	.2835	.2774	.3506	.4252	.2629	.3155	.298
17	.3012	.3544		.3721	.3155	.2658	.298
18	.3189	.3814	.4557	.3721	.3506	.2804	.3856
19	.4961	.4252	.4908	.3898	.3856	.3898	.4207
20	.4607	.373	.4908	.4908	.4557	.4252	.4557
21	.4252	.2427	.4557	.4382	.4207	.4207	.4207
22	.3898	.3391	.3856	.3856	.3681	.4066	.3856
23	.3366	.3121	.3155	.3155	.333	.3155	.3155
24	.3012	.3012		.2804	.2804	.2804	.2835
Max	.4961	.4252	.4908	.4908	.4557	.4252	.4557
Min	.2481	.2427	.2629	.2629	.2454	.2629	.2601
Avg	.3116	.2989	.3364	.3451	.3033	.3148	.3226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 202 / 11 KV DEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0312	.0343	1.1561	1.4575	1.4575	.0164
2	.0358	.0332	.0351	1.1523	1.4575	1.4746	.0332
3	.0324	.0328	.0362	1.1523	1.4899	1.5249	.032
4	.0362	.0332	.0328	1.1843	1.5402	1.576	.0328
5	.0362	.0301	.0339	1.2651	1.5729	1.5729	.0339
6	.0339	.0343	.0335	1.3763	1.6221	1.5074	.0332
7	.0351	.0351	.0339	1.5684		1.5074	.0328
8	.0362	.0503	.0171	1.5546	1.3927	1.5223	.0332
9	2.3594	2.0885	2.2801	.0324	.0358	.0339	1.6741
10	2.3472	2.1956	2.0454	.0324	.0354	.032	2.2045
11	2.2634	2.1879	2.0809		.0366	.0328	2.2211
12	2.1879	2.13	2.1376		.0373	.0328	2.2211
13	2.13	2.0485	2.0081	.0324		.0332	2.2377
14	2.0222	2.0317	1.9271	.0339	.0373	.017	2.1879
15	1.9662	1.866	1.8785		.0373	.0158	2.1216
16	1.873	1.9006	1.8515	.0328	.0373	.0166	2.1216
17	.0358	.0332		.0328	.0366	.017	.0339
18	.037	.0328	.0514	.0324	.0358	.0168	.0339
19	.037	.0509	.0351	.0328	.0366	.0328	.0366
20	.037	.0183	.0175	.0171	.0377	.032	.0366
21	.0366	.0492	.0181	.0173	.037	.0328	.0366
22	.037	.0339	.0181	.0179	.0377	.0339	.0366
23	.0335	.0358	1.2689	1.4918	1.6244	.0166	.0187
24	.0362	.0328	.0354	1.3032	1.4899	1.4575	.017
Max	2.3594	2.1956	2.2801	1.5684	1.6244	1.576	2.2377
Min	.0324	.0183	.0171	.0171	.0354	.0158	.0164
Avg	.7384	.7090	.7787	.6437	.6421	.5832	.7286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 203 / 11 KV MANGLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0173	.0171	.0166	.6173	.6104	.017	.016
2	.0173	.0171	.0166	.6173	.6104	.017	.017
3	.0173	.0171	.0168	.583	.6104	.017	.0168
4	.0173	.0171	.0164	.583	.6104	.017	.0166
5	.0173	.0171	.0166		.6443	.017	.016
6	.0173	.0171	.0328		.6783	.017	.0328
7	.0173	.0171	.0332	.017		.017	.0168
8	.0173	.0171	.0171	.0171	.6783	.017	.0164
9	.9362	.9282	1.1317	.0171	.0187	.0332	.8029
10	.8962	.9503	1.1317	.0171	.0179	.016	.8785
11	.9503	.8962	1.1317		.0171	.0164	1.1105
12		.9503	1.2003		.017	.7682	1.0852
13		.9945	1.1317		.017	.0158	1.0513
14		.9831	1.0974	.0171	.017	.0166	1.0513
15	.9282	.9282	1.0631		.017	.0164	1.0513
16	.8322	.9156	1.0288	.0171	.017	.017	1.0974
17	.017	.0332		.0171	.017	.0164	.0171
18	.0171	.0316	.0171	.017	.017	.0166	.0171
19	.0171	.0497	.0171	.017		.0328	.0171
20	.0171	.0509	.0171	.017		.032	.017
21	.0171	.0492	.0171	.0171	.017	.0164	.017
22	.0171	.048	.0171	.0171	.017	.017	.017
23	.0171	.0332	.6516	.5487	.017	.0166	.017
24	.0173	.0171	.0164	.6516	.6104	.017	.0164
Max	.9503	.9945	1.2003	.6516	.6783	.7682	1.1105
Min	.017	.0171	.0164	.017	.017	.0158	.016
Avg	.2294	.3332	.4277	.2114	.2513	.0500	.3505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 204 / 11 KV CHIKHALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6095	1.4746	1.5581	.1006	.0671	.0655	1.2742
2	1.5424	1.5746	1.5043	.1006	.0671	.0663	1.1797
3	1.5089	1.56	1.5729	.1006	.0671	.0655	1.1385
4	1.5089	1.6598	1.643	.1006	.1006	.0663	1.1203
5	1.5424	1.576	1.7295	.1006	.1006	.1006	1.3435
6	1.7772	2.0957	1.9071	.1006	.1006	.1006	1.4922
7	2.0119	2.146	2.1365	.1677		.1006	1.704
8	1.7772	2.2131	1.9784	.1677	.1006	.0671	1.6907
9	.1341	.1658	.1006	2.079	1.9784	1.8564	.1326
10	.1341	.1265	.1341	2.34	2.1795	1.8679	.1006
11	.1326	.1311	.1006		2.1628	1.9669	.1006
12	.1677	.0949	.1341		2.1548	1.9334	.1006
13	.1677	.096	.1006	2.079	2.1628	1.8991	.1006
14	.1658	.0983	.1341	2.079	2.146	1.6712	.1006
15	.1311	.0678	.1341		2.0348	1.7974	.1006
16	.1341	.0995	.1341	2.146	1.7695	1.7368	.1006
17	.1326	.1311		.1341	.0995	.1658	.1006
18	.1311	.0339	.1006	.1341	.1006	.1311	.1677
19	.1311	.1387	.1006	.1341	.0995	.1326	.1677
20	.1677	.1829	.1006	.1006	.1341	.1311	.1341
21	.1658		.1006	.1006	.1326	.0995	.1341
22	.1677		.1341	.1006	.1341	.096	.1341
23	1.643		.1006	.1006	.0995	1.3435	1.5424
24	1.643	1.6409	1.5729	.1006	.1006	.0983	1.326
Max	2.0119	2.2131	2.1365	2.34	2.1795	1.9669	1.704
Min	.1311	.0339	.1006	.1006	.0671	.0655	.1006
Avg	.7762	.8242	.7484	.5984	.7866	.7316	.6453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 205 / 11 KV DEOWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1097	.0983	.132	.112	.1063	.1132
2	.1075	.0895	.1017	.1132	.112	.1029	.0914
3	.1097	.1052	.1063	.112	.1132	.1052	.0905
4	.1075	.1086	.128	.1132	.132	.0905	.1063
5	.124	.132	.1147	.1494	.1494	.1132	.1433
6	.1494	.1372	.176	.1829	.1848	.1254	.1526
7	.1478	.1227	.1696	.1928		.124	.1646
8	.1543	.1595	.156	.1595	.1387	.1448	.1402
9	.128	.1492	.1696	.1509	.1311	.1372	.1402
10	.1372	.144	.1457	.1638	.1492	.1526	.1543
11	.125	.1357	.1475		.1402	.156	.1372
12	.1147	.116	.1696		.1227	.1595	.1227
13	.1132	.1017	.1417	.1638		.1357	.1063
14	.0895	.1147	.1357	.1341	.104	.1214	.1075
15	.112	.1326	.1341		.1029	.128	.1402
16	.1254	.1357	.1492	.1543	.0829		.0983
17	.0937	.1326		.1658	.1017	.1478	.1341
18	.1187	.156	.1844	.1475	.112	.1698	.1326
19	.1928	.1865	.197	.1543	.1372	.2241	.1612
20	.1829	.2195	.1907	.1928	.1791	.2054	.1991
21	.1791	.192	.197	.2172	.1698	.2126	.1991
22	.1867	.164	.181	.2012	.1829	.1867	.1829
23	.1494	.1475	.1663	.1663	.1448	.1417	.1494
24	.1307	.1509	.112	.1494	.1494	.1227	.1097
Max	.1928	.2195	.197	.2172	.1848	.2241	.1991
Min	.0895	.0895	.0983	.112	.0829	.0905	.0905
Avg	.1329	.1393	.1510	.1579	.1342	.1441	.1365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 206 / 11 KV DHANTAKE WARANA

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.1524
3	.2279	.156		.2103	.1595	.1646
4	.2279	.1595		.2103	.1612	.2378
5	.2279	.1595		.2279	.1595	.2378
6	.2279	.1595		.2279	.1417	.2328
7	.2279	.2279			.124	.2378
8	.2279	.2254		.2254	.1595	.2378
9	.2279			.2254	.1463	.2229
10	.2279	.0526		.2254	.1646	.2229
11	.2279	.0526		.2303	.1646	.2229
12	.2279	.2279		.2254	.1646	.2229
13	.2279	.2254		.2254	.0366	.2229
14	.2279	.2229	.2279	.2254	.0366	.2229
15	.2279	.2254		.2303	.0366	.2229
16	.2254	.2254	.2279	.0381	.0366	.2229
17	.2254		.2279	.2279	.1448	.2229
18			.2279	.2254	.2378	.2229
19			.2279			
Max	.2279	.2279	.2279	.2303	.2378	.2378
Min	.2254	.0526	.2279	.0381	.0366	.1524
Avg	.2276	.1785	.2279	.2121	.1297	.2194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 401 / 33KV INGRUL KAPARI LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.691	.6584	.7682	.4938	.4784	.5601
2	.7059	.7682	.7682	.7682	.5487	1.0082
3	.6984	.7682	.7682	.7682	.5544	.5601
4	.7059	.7682	.7682	.7682	.5544	.5601
5	.7602	.7682	.7682	.7682	.5544	.5601
6	.7602	.7682	.7682	.7682	.5544	.5601
7	.8145	.7682	.7682	.7682	.5544	.5601
8	.8145	.7682	.7682	.823	.5544	.5601
9	.8145		.7682	.823	.6099	.5601
10	.8145	.1646	.7842	.7682	.5544	.5601
11	.8145			.7682	.5544	.5601
12	.8145			.823	.5544	.5601
13	.8145	.1097	.7842	.6722	.5544	.5601
14	.8145	.1097	.7842	.5487	.5544	.5601
15	.7602	.823		.5601	.5544	.5601
16	.1143	.1132	.112	.1143	.1143	.112
22	.4572					
Max	.8145	.823	.7842	.823	.6099	1.0082
Min	.1143	.1097	.112	.1143	.1143	.112
Avg	.7158	.5658	.7214	.6877	.5253	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 201 / 11 KV KANDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0271	.0316	.0469	.4401	.5601	.5441	.0293
2	.0278	.0316	.0463	.4607	.5668	.5182	.0297
3	.0282	.032	.0469	.4877	.5668	.5182	.0274
4	.0278	.032	.048	.5344	.583	.5921	.0278
5	.0267	.032	.0469	.6952	.6722	.6722	.0271
6	.0282	.0332	.048	.6455	.9231	.8482	.0526
7	.0297	.0309	.0469	.8124	1.1336	1.0082	.0469
8	.0469	.032	.048	.7773	.9878	.9602	.0497
9	1.5565	1.6078	1.7695	.0526	.0286	.0324	1.5061
10	1.6032	1.8896	1.9227	.0514	.0305	.0463	1.5043
11	1.6385	1.8515	1.8404	.0514	.029	.0434	1.2643
12	1.6876	1.7532	1.6975		.0293	.0446	
13	1.587	1.7532	1.7695		.0297	.0412	1.587
14	1.5384	1.7204	1.6518	.0514	.0297	.0417	1.5402
15	1.4255	1.6876	1.6078	.052	.0293	.0423	1.6385
16	1.2631	1.5546	1.4563	.0457	.0297	.0429	1.5708
17	.0366	.0457	.04	.0463	.0297	.0446	.048
18	.04	.0457		.0469	.0297	.0412	.048
19	.0452	.0446		.0469	.0293	.0406	.0469
20	.0469	.0469	.0278	.0474	.0297	.0423	.0469
21	.0469	.0457	.0282	.048	.0305	.0412	.0434
22	.0474	.0457	.0297	.0497	.0305	.0417	.0446
23	.048	.0469	.4172	.5441	.4999	.0406	.0457
24	.0412	.0457	.0469	.4287	.5601	.5601	.0423
Max	1.6876	1.8896	1.9227	.8124	1.1336	1.0082	1.6385
Min	.0267	.0309	.0278	.0457	.0286	.0324	.0271
Avg	.5373	.6017	.6674	.2916	.3112	.2854	.4899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 202 / 11 KV PUNVAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1829	.1867	.181	.1848	.1867	.1802
2	.1791	.1848	.1867	.1612	.1848	.1867	.1581
3	.181	.1848	.1867	.1595	.1848	.1867	.1562
4	.1715	.2033	.1867	.1578	.1848	.1867	.1543
5	.1772	.2195	.2241	.2012	.2195	.2054	.16
6	.2279	.2378	.2743	.2149	.1991	.2534	.2267
7	.2534	.2481	.2378	.2629	.2126	.2328	.1989
8	.2303	.2254	.2279	.2481	.208	.2279	.2401
9	.2058	.2401	.2534	.2515	.1715	.2328	.213
10	.1989	.2204	.2172	.213	.1715	.1991	.213
11	.2012	.2012	.2454	.2294	.2012	.2126	.1802
12	.2012	.2035	.1886	.2429	.1989	.208	.1966
13	.2035	.1658	.2172	.2347	.1966	.2149	.218
14	.1886	.1677	.2149	.2012	.1865	.2103	.2035
15	.1886	.2012	.2279	.2229	.1865	.2353	.2204
16	.1943	.2486	.2328	.1966	.0819	.2534	.2515
17	.2031	.2458	.2214	.1943	.1823	.2241	.2785
18	.2056	.2429		.2056	.2105	.2267	.253
19	.2321	.2883		.2458	.2294	.2214	.2652
20	.2865	.3761	.2968	.2883	.298	.2778	.3429
21	.2896	.3224	.2778	.3012	.2804	.2881	.333
22	.2743	.3109	.2486	.2926	.2686	.253	.2865
23	.2378	.2587	.2149	.2561	.2353	.213	.2561
24	.1772	.1829	.2218	.1928	.2033	.2033	.1698
Max	.2896	.3761	.2968	.3012	.298	.2881	.3429
Min	.1715	.1658	.1867	.1578	.0819	.1867	.1543
Avg	.2118	.2318	.2268	.2231	.2034	.2225	.2232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 203 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1867	.1886	.1715	.2075	.1886	.1772
2	.181	.1698	.1886	.1612	.1886	.1886	.1612
3	.1829	.1698	.1886	.1595	.1886	.1886	.1629
4	.1928	.1886	.1886	.1734	.2075	.1886	.1663
5	.1949	.2075	.2075	.1928	.2427	.2075	.1802
6	.2279	.2263	.2452	.208	.2614	.2402	.2279
7	.2229	.2378	.2801	.2149	.2743	.2195	.2353
8	.2279	.1949	.2149	.1886	.2195	.1991	.2103
9	.2149	.2103	.2103	.181	.1753	.1928	.208
10	.1646	.1928	.2058	.2103	.1907	.2149	.2058
11		.1753	.2507	.208	.1886	.2012	.2058
12	.197	.1928	.1886	.2229	.1886	.192	.2254
13	.1791	.1715	.2149	.2229	.1886	.1943	.2035
14	.1829	.1753	.2149	.2103	.197	.2254	.2229
15	.1829	.197	.2279	.2195	.1791	.2149	.2229
16	.2149	.2103	.2353	.2204	.1928	.2172	.2254
17	.1928	.2103	.208	.218	.2279	.208	.2572
18	.2149	.208	.1753	.218	.208	.2328	.2204
19	.2172	.2328	.208	.2427	.2629	.2454	.2572
20	.2957	.3292	.2715	.2743	.2957	.2743	.3012
21	.2801	.2957	.2401	.2743	.2957	.2896	.2926
22	.2614	.2801	.2279	.2801	.2801	.2454	.2614
23	.2427	.2427	.1991	.2641	.2427	.2149	.2263
24	.1734	.1867	.2241	.1753	.2263	.2075	.1753
Max	.2957	.3292	.2801	.2801	.2957	.2896	.3012
Min	.1646	.1698	.1753	.1595	.1753	.1886	.1612
Avg	.2097	.2122	.2169	.213	.2221	.2163	.2180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 204 / 11KV DATT LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307	.132	.1307		.132
2		.1307	.1307	.1307		.1307
3		.1307	.1307	.1307		.1307
4		.1307	.132	.1307		.1307
5		.1307	.132	.1307		.132
6		.1307	.132	.1307		.132
7	.0377	.1307	.132	.1307		.132
8	.1307	.1307	.132	.1307		.132
9	.1307	.132	.1307	.1307		.1307
10	.1307	.132	.1307	.1307		.1294
11	.1307	.132	.1307	.1307		.1307
12	.1307	.132	.1307	.1307	.132	.1307
13	.1307	.132	.1307	.1307	.1307	
14	.1307	.132	.1307	.1307	.132	.1307
15	.1307	.1307	.1307	.1307	.132	.1307
16	.1307	.132	.1307		.132	.1307
Max	.1307	.132	.132	.1307	.132	.132
Min	.0377	.1307	.1307	.1307	.1307	.1294
Avg	.1214	.1313	.1312	.1307	.1317	.1310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 201 / 11 KV KARMALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.0914	.1524	.096	.132
2	.1132	.1132	.0943	.0926	.1524	.1107	.132
3	.1132	.1132	.0934	.0937	.1524	.1107	.132
4	.112	.1132	.1132	.0937	.1524	.112	.132
5	.112	.132	.112	.0772	.1524	.1265	.132
6	.132	.1509	.132	.108	.1829	.1562	.1509
7	.1509	.1867	.1494	.1852	.2469	.2214	.1509
8	.1494	.1494	.1663	.1562	.25	.176	.1509
9	.2214	.1966	.208	.128	.128	.128	.1524
10	.2187	.1943	.1852	.132	.128	.1132	.2462
11	.1718	.1943	.2054	.132	.128	.1132	.2675
12	.1562	.208	.1829	.132	.128	.1132	.2743
13	.1562	.176	.216	.132	.1294	.1132	.2439
14	.1718	.1311	.1718	.132	.128	.1132	.2286
15	.1372	.176	.1802	.132	.1463	.132	.2343
16	.1189	.2031	.1875	.132	.128	.0943	.208
17	.1494	.1063		.1132	.1097	.0943	.1494
18	.168	.1063		.1509	.0914	.132	.1509
19	.2054	.1663		.1509	.1646	.1886	.1886
20	.2054	.2241	.0732	.1509	.1848	.1886	.2075
21	.2075	.2263	.1109	.1509	.2012	.2075	.2263
22	.1886	.1886	.1097	.1509	.1848	.1886	.1886
23	.1509	.1509	.0983	.1524	.125	.1886	.1307
24	.1132	.1132	.1132	.0937	.1524	.0949	.1509
Max	.2214	.2263	.216	.1852	.25	.2214	.2743
Min	.112	.1063	.0732	.0772	.0914	.0943	.1307
Avg	.1557	.1597	.1436	.1277	.1541	.1380	.1817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 203 / 11 KV PADALIWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2801	2.1704	2.1125	.0857	.0857	.1029	2.2405
2	2.2043	2.1704	2.0553	.0848	.0857	.1017	2.2405
3	2.1948	2.1704	1.9662	.0848	.0857	.1006	2.2405
4	2.1498	2.1704	1.9559	.1017	.0857	.104	2.2405
5	2.2291	2.2043	1.9448	.1029	.0857	.1174	2.2405
6	2.3061	2.3061	1.9281	.1017	.12	.1326	2.3045
7	2.4587	2.3137	2.1026	.1187	.1372	.1696	2.6216
8	2.4078	2.2969	2.079	.1227	.1372	.1696	2.6216
9	.1147	.1187	.1052	2.1534	2.6216		.12
10	.112	.0663	.0983	2.2939	2.5774	.1524	.0937
11	.0937	.0995	.0497	2.2405	2.7808	.1677	.0949
12	.0937	.0995	.0492	.6401	2.7469	2.3922	.0972
13	.0914	.1107	.0514	2.6216	2.713	2.4577	.0972
14	.1067	.1017	.0509	2.6216	2.7092	2.6216	.081
15	.108	.1017	.0514	2.6216	2.6452	2.6871	.081
16	.1094	.1187	.0526	2.6216	2.5434	2.7199	.0972
17	.1187	.0509		.1029	.1017	.12	.1006
18	.1357	.1326	.12	.12	.1341	.12	.1357
19	.1526	.1509	.1227	.12	.1357	.12	.1357
20	.1526	.1357	.1402	.12	.1341	.12	.1357
21	.1526	.1372	.1372	.132	.1187	.12	.1341
22	.1526	.1387	.104	.12	.1017	.12	.116
23	2.1704	1.9113	.1029	.1029	.1006	1.9204	2.1795
24	2.2382	2.2043	2.2043	.1029	.0857	.1017	2.2405
Max	2.4587	2.3137	2.2043	2.6216	2.7808	2.7199	2.6216
Min	.0914	.0509	.0492	.0848	.0857	.1006	.081
Avg	1.0139	.9784	.8515	.8141	.9614	.7365	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 204 / 11 KV MIDC NEW

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	.7922	1.1694	1.1694	1.0185	1.1694	.8488
2	1.2071	.8676	1.226	1.0185	1.0185	1.1694	.8488
3	1.1317	.7545	1.094	1.0185	1.0185	1.1317	.8488
4	1.094	.7545	1.1317	1.0185	1.0185	1.094	.8488
5	1.1317	1.0185	1.1576	1.0751	1.0185	.9808	.8488
6	1.1883	1.094	1.094	1.1128	1.0185	.7922	.9054
7	.8215	.811	.7733	1.0374	.9054	.547	1.2449
8	.3704	.4904	.3856	.7356	.6224	.4715	.415
9	.2848	.5281	.5658	.8676	.6224	1.094	.5658
10	.5658	.6979	.7545	.9997	.8488	1.2071	.6413
11	.6036	.7545	.7922	.679	.8488	1.2826	.7922
12	.5281	.679	.7545	.7545	.9619	.8676	.8299
13	.415	.6602	.7356	.6224	.9242	.8488	.7545
14	.3772	.6413	.6979	.679	.9242	.7545	.8299
15	.4338	.6722	.6602	.679	.8488	.679	.7922
16	.4338	.6602	.6413	.679	.9242	.679	.7356
17	.4527	.6036		.6224	.811	.679	.679
18	.5281	.547	.3395	.4904	.6413	.5658	.6036
19	.5281	.5847	.3961	.4527	.6413	.5658	.6036
20	.4338	.547	.3961	.4527	.6413	.5658	.6413
21	.679	.8215	.7356	.679	.8676	.5658	.8676
22	.8676	.8488	.9242	.9808	.9997	.5658	1.094
23	.9054	1.2071	1.0374	1.226	1.0562	.5658	1.1883
24	1.1317	.7922	1.1317	1.2826	1.1317	1.2449	.5658
Max	1.2071	1.2071	1.226	1.2826	1.1317	1.2826	1.2449
Min	.2848	.4904	.3395	.4527	.6224	.4715	.415
Avg	.7201	.7428	.8084	.8472	.8888	.8370	.7914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 201 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4588	.4862	.4191	.0189	.0181	.0189	.4862
2	.4096	.4917	.4191	.0189	.0183	.0189	.4862
3	.4144	.4748	.4144	.0189	.0185	.0189	.4641
4	.4144	.4748	.4144	.0189	.0183	.0189	.4475
5	.503	.5365	.431	.0189	.0183	.0189	.4475
6	.57	.6036	.5533	.0189	.0187	.0189	.4424
7	.7373	.788	.7042	.0185	.0187	.0189	.7122
8	.7209	.6706	.6062	.0185	.0187	.0189	.5967
9	.0183	.0179	.0358	.4915	.7373	.9496	.0366
10	.0183	.0179	.037	.5898	.8322	.9496	.0373
11	.0187	.0181	.0373	.7042	.8162	1.0852	.0377
12	.0187	.0175	.0189	.7712	.8684	1.0513	.0377
13	.0187	.0179	.0187	.7712	.8684	.9496	.0373
14	.0187	.0179	.0187	.7712	.9116	.7712	.0354
15	.0183	.0179	.0189	.8478	.8785	.9054	.0183
16	.0183	.0181	.0185	.5868	.7625	.9054	.0187
17	.0183	.0183		.017	.0183	.0183	.0187
18	.0183	.0183	.0189	.0152	.0183	.0156	.0185
19	.0183	.037		.0173	.0366	.0183	.0183
20	.0183	.0373	.037	.0173	.0183	.0366	.0185
21	.0183	.0373	.0187	.0171	.0183	.0366	.0185
22	.0179	.037	.0189	.0179	.0183	.0366	.0177
23	.4527	.431	.0189	.0179	.0183	.503	.3239
24	.4588	.4862	.4359	.0189	.0181	.0189	.503
Max	.7373	.788	.7042	.8478	.9116	1.0852	.7122
Min	.0179	.0175	.0185	.0152	.0181	.0156	.0177
Avg	.2249	.2405	.2143	.2426	.2911	.3501	.2200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 202 / 11 KV KOKARUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.1113	.096	.1875	.0191
2	.0191	.0191	.0191	.1113	.096	.1718	.0191
3	.0191	.0191	.0191	.1189	.0934	.1677	.0191
4	.0191	.0191	.0191	.1337	.1219	.1981	.0191
5	.0191	.0191	.0191	.1524	.1524	.2656	.0191
6	.0191	.0191	.0191	.1852	.2439	.2812	.0191
7	.0191	.0191	.0191		.3749	.3749	.0191
8	.0191	.0191	.0191		.3437	.3704	.0191
9	.6562	.6167	.6562		.0191	.0191	.6249
10	.7042	.6722	.68		.0191	.0191	.7042
11	.7042	.7373	.7611		.0191	.0191	.6802
12	.6882	.6882	.7209		.0191	.0191	.7125
13	.6722	.7209	.6722	.0191	.0191	.0191	.7287
14	.6401	.6958	.6562	.0191	.0191	.0191	.7449
15	.5693	.664	.6562	.0191	.0191	.0191	.7287
16	.5218	.6316	.578	.0191	.0191	.0191	.6722
17	.0191	.0191		.0191	.0191	.0191	.0191
18	.0191	.0191		.0191	.0191	.0191	.0191
19	.0191	.0191		.0191	.0191	.0191	.0191
20		.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191		.0191
22	.0191	.0191	.0191	.0191	.0191		.0191
23	.0191	.0191	.1052	.0934	.1943		.0191
24	.0191	.0191	.0191	.1082	.0934	.1875	.0191
Max	.7042	.7373	.7611	.1852	.3749	.3749	.7449
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.2366	.2388	.2722	.0670	.0866	.1159	.2459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 203 / 11 KV KOKARUD GAOTHAN

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	10-MAY-18
HR	Load (MW)	Load (MW)
16	.0191	
22		.0191
23		.0191
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 201 / 11 KV Dafalapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6036	.6783	.2241	.2241	.1638	.6602
2	.7545	.6706		.2054	.2241	.1619	.5868
3	.7545	.6706	.7716	.2054	.2241	.1677	.6602
4	.9221	.8718	.7716	.2054	.2614	.1696	.7545
5	1.1736	1.1065	.8573	.3841	.3361	.2622	.9431
6	1.4251	1.4083	1.6289	.4938	.5041	.407	.9997
7	2.0119	1.9616	1.9376	.4572	.5041	.3647	1.2239
8	1.7269	1.9784	2.1262	.4024	.3921	.3018	1.291
9	1.7436	1.6766	1.8671	.3142	.3361	.2543	1.2071
10	1.4922	1.0898		.2587	.2614	.2572	1.1568
11	.2241	.3052		1.3413	1.5278	1.6598	
12	.1867	.3086		1.5424	1.7101	1.8945	
13	.3547	.1886		1.6095	1.6108	1.8107	.1886
14	.3547	.1715		1.4922	1.4586		
15	.2987	.1696		1.5089	1.4074	1.6263	
16	.2427	.2058		1.5089	1.8298		
17	.3174	.2058		1.358	1.4922	1.7939	
18	.2427	.2229		1.0227	1.406	1.6766	.2587
19	.3921	.3294		.3361	.3086	.3018	.4024
20	.4108	.4115		.3734	.3429	.3961	.4207
21	.3734	.3601		.2987	.2915	.3772	.3658
22	.3361	.3206		.2614	.2458	.3395	.3326
23	.2427	.2801	.2241	.2427	.1989	.2829	.2587
24	.2452	.2427	.2263	.2241	.2241	.1781	.2452
Max	2.0119	1.9784	2.1262	1.6095	1.8298	1.8945	1.291
Min	.1867	.1696	.2241	.2054	.1989	.1619	.1886
Avg	.7075	.6567	1.1089	.6780	.7218	.6749	.6642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 202 / 11 KV Baj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.2742	1.0454		.3361	.3467	.9221
2	1.0059	1.3748			.3361	.3467	.9221
3	1.5089	1.3748	1.0288		.3361	.3772	.9221
4	1.5089	1.576	1.0174			.3429	1.1736
5	1.8442	1.8442	1.2309		.4108	.3944	1.3413
6	2.0622	2.2131	2.2462			.6344	1.4419
7	2.6155	2.6155	2.8166	.5249	.5601	.5407	1.9951
8	2.4813	1.9951	2.8147	.4207		.4807	2.0119
9	2.1125	2.1795	2.2801	.3658	.3921	.3688	2.1125
10	.9892	1.8275		.3475			1.9951
11	.2241	.2374		2.0287	2.332	2.364	
12	.3734	.2401		1.8778	1.4754	2.5652	
13	.2801	.2427		1.861	1.8652	2.3975	.2957
14	.2801	.1981			2.0119	2.3472	
15	.2801	.213			2.3569	2.2131	
16	.3174	.218			2.2131	2.2131	.2957
17	.2801	.2713		1.9448	2.4587	2.6658	
18	.3174	.3222		1.6766	2.2119	2.364	.3658
19	.4668	.4382		.4854	.3944	.4338	.543
20	.5041	.5658		.5415	.5316	.5658	.5611
21	.4668	.4191		.4668	.4458	.4715	.5249
22	.4294	.373		.4108	.3772	.3961	.439
23	.3921	.3521	.2772	.3547	.3121	.3584	.4024
24	.2829	.3361	.3391		.3361	.3258	.3395
Max	2.6155	2.6155	2.8166	2.0287	2.4587	2.6658	2.1125
Min	.2241	.1981	.2772	.3475	.3121	.3258	.2957
Avg	.9179	.9459	1.5096	.9505	1.0847	1.1093	.9792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 203 / 11KV Mirwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2054	.197	.6154	.8048	.9012	.1886
2	.2263	.2054		.6335	.9724	.9012	.1886
3	.2263	.2054	.2058	.6335	.9724	.9012	.1886
4	.3018	.2241	.2058	.6805	1.073	.9116	.2263
5	.3584	.2801	.208	.8215	1.1904	1.0288	.3018
6	.3961	.3921	.3429	.8215	1.861	1.7772	.3772
7	.3584	.3921	.3113	1.0898	1.861	2.7263	.3584
8	.3018	.2801	.2818	1.3245	2.7328	2.8807	.1886
9	.2829	.2427	.218	.788	2.5149	2.4697	.2263
10	.2263	.168		.6984	2.2634	2.1956	.2075
11	2.3807	2.3569		.168	.1372	.2075	
12	2.4478	2.6578		.1867	.1509	.1698	
13	2.5149	2.652		.1867	.1865	.1698	2.7854
14	2.5149	2.6825		.2054	.1677	.1698	
15	2.5819	2.713		.1867	.2075	.1698	
16	2.649	3.0178		.168	.2054	.1698	
17	2.6155	2.8826		.1867	.2241	.1698	
18		2.3807		.1867	.2469	.2075	2.6852
19	.3174	.2515		.2801	.2812	.2829	.3142
20	.3921	.39		.3361	.3441	.3584	.3841
21	.3547	.4191		.2801	.2915	.3206	.3142
22	.2801	.2543		.2427	.2294	.2829	.2587
23	.2614	.2229	.2241	.2054	.1677	.2075	.2054
24	.2452	.2054	.208	.6154	.168	.1844	.1509
Max	2.649	3.0178	.3429	1.3245	2.7328	2.8807	2.7854
Min	.2263	.168	.197	.168	.1372	.1698	.1509
Avg	.9765	1.0701	.2403	.4809	.8023	.8235	.5306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 204 / 11 Kv Baj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1494	.132	.0943	.1494		.1509
2	.132	.1494		.0943	.1494	.1698	.1509
3	.1174	.1494	.1509	.0943	.1494	.168	.1509
4	.1341		.1509	.0943		.1698	.1698
5	.1886		.1509	.132		.1867	.1698
6	.2263		.2241	.1509		.168	.1698
7	.2263	.2054	.2263	.1698	.2614	.2452	.2075
8	.1886	.168	.1494	.1132	.2054	.1509	.1698
9	.1509	.2614	.1886	.1509	.2614	.1494	.1886
10	.1886	.2987				.1509	.1509
11	.168	.2263			.1698	.132	
12	.168	.2241			.1494	.1698	
13	.1494	.2263		.2054	.1886	.1132	.2402
14	.1494	.1867		.1307	.1509	.0943	
15	.1494	.1886		.1867	.2241	.0943	
16	.168	.168		.2054	.1509	.1132	
17	.168	.1886		.2614	.1867	.1886	
18	.2054	.2241		.2054	.2641	.1886	.2587
19	.2427	.1886		.2427		.2263	.2772
20	.2801	.2614		.2614	.1886	.3018	.2957
21	.2614	.2614		.2427	.2614	.2263	.2402
22	.2241	.2641		.2241	.2263	.1886	.1698
23	.168	.1867	.1132	.2054	.1132	.1886	.132
24	.132	.1494	.2263	.0943	.1494	.1886	.1698
Max	.2801	.2987	.2263	.2614	.2641	.3018	.2957
Min	.1174	.1494	.1132	.0943	.1132	.0943	.132
Avg	.1799	.206	.1713	.1695	.1895	.1727	.1924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 205 / 11 KV Dafalapur GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1494	.1509		.168	.1509	.1886
2	.1509	.1494			.168	.1509	.1886
3	.1509	.1494	.1509		.168	.1509	.1886
4	.1698	.1494	.1494		.168	.1509	.2075
5	.1698	.1494	.1886		.1867	.168	.2075
6	.1886	.1867	.2054		.2054	.1509	.2075
7	.2452	.2241	.2263		.2241	.1509	
8	.1509	.2241	.1494		.2054	.1509	.1886
9	.1698	.2241	.168		.1867	.1478	.2075
10	.1886	.2054		.2587	.2614	.1867	.2075
11	.2427	.2263		.2614	.1509	.2452	
12	.2054	.2263		.168	.2054	.2452	
13	.2241	.1886		.2614	.2075	.2263	.1867
14	.2241	.168				.2263	
15	.1867	.1698				.2263	
16	.1867	.1307			.168	.2263	
17	.1494	.1886		.3361	.2054	.2075	
18		.2054		.2801	.2829	.2263	.2402
19	.2054	.2263		.3174	.2614	.2452	.2957
20	.2614	.2829		.2614	.3395	.2829	.2772
21	.2427	.2427		.2987	.2641	.2263	.2772
22	.2241	.2263		.2427	.2452	.2075	.2402
23	.2054	.1494	.2241	.1867	.2054	.2075	.1867
24	.1698	.1867	.1698		.168	.1509	.2075
Max	.2614	.2829	.2263	.3361	.3395	.2829	.2957
Min	.1494	.1307	.1494	.168	.1509	.1478	.1867
Avg	.1941	.1929	.1783	.2611	.2112	.1962	.2178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 206 / 11 KV ANKALE DORLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3174	.3467	.3658	1.0059	1.0059	.3395
2	.2829	.3174		.5792	1.0898	.9831	.3395
3	.2829	.3174	.3429	.5792	1.0898	.9831	.3395
4	.3772	.3547	.3429	.7522	1.0898	1.3108	.415
5	.4904	.4668	.2774	1.0059	1.1904	1.4074	.5093
6	.6602	.7095	.6104	1.2209	1.5424	2.0454	.7545
7	.6413	.5975	.5658	1.2209	2.0119	2.5069	
8	.547	.4854	.5138	1.3077	2.6322	2.4366	.6602
9	.4904	.4294	.4862	1.1736	2.3137	1.4632	.4904
10	.3395	.2054		1.2071	1.8442	1.4582	.4527
11	2.1628	1.9662		.2614	.1865	.3584	
12	2.2298	2.431		.2614	.2915	.4338	
13	2.2801	2.5095		.3361	.3315	.4527	2.6023
14	2.2131	2.2377			.285	.415	
15	2.1628	2.0388			.3222		
16	2.0957	2.3807			.3391	.415	
17	2.2298	2.4587		.2987	.3772	.4904	
18	1.4754	2.0517		.3361	.4578	.4904	2.2552
19	.5415	.4409		.5228	.6344	.5658	.4755
20	.5601	.6001		.6535	.6516	.6979	.5068
21	.5415	.463		.5228	.5243	.5658	.4938
22	.4668	.3772		.4668	.3688	.5093	.439
23	.3547	.2949	.2587	.3174	.3391	.4338	.3475
24	.3018	.3174	.3481	.3658	.3361	.3429	.3961
Max	2.2801	2.5095	.6104	1.3077	2.6322	2.5069	2.6023
Min	.2829	.2054	.2587	.2614	.1865	.3429	.3395
Avg	1.0004	1.0320	.4093	.6550	.8856	.9466	.6951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 201 / 11 KV Billur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.1829	.1619	.5487		.8259	.1829
2	.2926	.2218	.1619	.7973		.8907	.1829
3	.2926	.2561	.1943	.7973		.8907	.2172
4	.3292	.2926	.1943	.8859		.9231	.2195
5	.3658	.3292	.2591	.8859		1.0526	.2534
6	.3801	.3841	.3401	.9922		1.5546	.2926
7	.3841	.3658	.2591	1.0242		2.1214	.3292
8	.2926	.2378	.2591	1.4175		1.5708	.2743
9	.1829	.1619	.2267			1.5061	.181
10	.1829	.1619	.2267	1.3375		1.7741	.1829
11	1.829	1.749				.1646	1.829
12	1.829	1.749		.1619		.1448	1.829
13	1.7558	1.5384	1.8861		1.2146	.1448	1.829
14	1.7741	1.4575	1.7833	.1296	.1619	.1448	1.829
15	1.7918	1.4251	1.9105	.1772	.1619	.1463	1.7147
16	1.829	1.5546		.1063	.1619	.1448	1.749
17	1.7375				.1619	.0914	1.8861
18	1.829	1.4251			.1943	.1097	.7716
19	.1829	.1943			.2429	.1829	.2743
20	.2172	.2429		.2267	.2429	.2561	.2835
21	.2012	.1943	.2058		.1943	.2195	.2481
22	.2012		.2103	.2481	.1781	.2172	.2195
23	.2012		.1772	.1715	.1619	.1829	.181
24	.2743	.2012	.1619	.1753		.1619	.181
Max	1.829	1.749	1.9105	1.4175	1.2146	2.1214	1.8861
Min	.1829	.1619	.1619	.1063	.1619	.0914	.181
Avg	.7755	.6822	.5070	.5931	.2797	.6426	.7142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 202 / 11kv salmalgewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	1.448	1.2955			.8097	.6468
2	1.6289	1.6289	1.6194			.9717	1.086
3	1.8099	1.7194	1.6842			.9717	1.1888
4	2.1357	1.848	1.9109			1.0202	1.267
5	2.3034	2.0119	2.251			1.2146	1.448
6	2.7149	2.7435	3.1579			1.5384	1.6289
7	3.0121		3.2065			2.0567	2.3339
8	2.7149		2.7854	.7682	.2915	1.6194	2.3777
9	1.5546		3.0121	1.0288	1.9719	1.9757	2.5339
10	1.9204		2.7206	.8573	2.0891		1.5746
11	2.2862	2.0081			.9555	2.2862	1.0974
12	2.2862	2.2186		2.572	1.0202	2.8054	
13	2.2862	2.1538	1.5912			2.7435	1.8861
14	2.1719	1.8623	1.949	2.6353	2.2024	1.0974	2.0576
15	2.0814	1.8623	1.7147	2.7618	2.5749	1.2803	2.2786
16	1.9909	1.8947		.0549	2.0567	1.5181	2.1262
17	1.9204	2.0405			2.6235	1.448	2.2786
18	2.0748	1.9433				1.2803	2.0805
19	.3439	.3563			.3887	.3658	.362
20	.439	.4049		.2429	.4372	.362	.362
21	.415	.4049	.2561		.421	.4207	.4572
22	.362		.1928	.1753	.421	.4207	.4024
23	.362		.2629	.1753		.4207	.3582
24	.3658	.362	.2753	.2058			.3658
Max	3.0121	2.7435	3.2065	2.7618	2.6235	2.8054	2.5339
Min	.3439	.3563	.1928	.0549	.2915	.362	.3582
Avg	1.6935	1.6062	1.7580	1.0434	1.3426	1.3012	1.3999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 203 / 11 KV Wajrawad ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.448	1.166	.2126		.2915	.5487
2	1.3575	1.6289	1.2146	.1829		.2915	.695
3	1.6108	1.7375	1.2146	.1753		.2915	.8962
4	1.6461	1.829	1.4899	.2401		.2915	.8145
5	1.7558	2.0119	1.5384	.2454		.3887	.8048
6	1.9185	2.0485	2.4615	.2835		.4858	.9145
7	2.0376	2.4143	2.8502	.2743		.4534	.9511
8	1.9909	2.0119	2.5911	.2835	.2915	.2915	1.8473
9	2.1948	2.17	2.2024		.2267	.3239	1.7558
10	2.3777	1.8461	1.1336	.2267	.1943	.3658	1.1403
11		.1296			1.8138	1.7375	.1448
12	.2743	.1296		1.0288	2.2348	1.8461	.1848
13	.1829	.1619	.1715		1.8138	1.7375	.1715
14	.181	.1296	.1463	1.2003	1.9433	1.7013	.1829
15	.1829		.1463	1.0631	1.7814	1.086	.1715
16	.181	.1619		.7716	2.332	1.3717	.1753
17	.181				2.4615	1.4632	.1753
18	.1829	.1943			1.6194	1.3213	.1772
19	.2172	.1943			.2591	.2715	.2172
20	.2743	.3887		.2683	.3563	.3258	.2126
21	.2743	.2915	.2561		.3239	.2195	.1829
22	.2896		.2454	.2126	.2915	.2172	.181
23	.2926		.2195	.2353	.2915	.2195	.181
24	.3658	.3658	.2267	.2058		.2915	.2195
Max	2.3777	2.4143	2.8502	1.2003	2.4615	1.8461	1.8473
Min	.181	.1296	.1463	.1753	.1943	.2172	.1448
Avg	.9199	1.0647	1.1338	.4182	1.1397	.7202	.5394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 205 / 11 kv Wajrwad Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1294	.1448	.1509		.1267	.1463
2	.1463	.1109	.1448	.1715		.1267	.1463
3	.1595	.1629	.1448	.1753		.1267	.1646
4	.1829	.1848	.1448	.1772		.1296	.1829
5	.2195	.1848	.181	.2103		.1619	.2561
6	.2561	.2587	.2353	.2481		.2105	.2926
7	.2534	.2195	.2715			.1629	.2195
8	.1829	.1829	.2172	.2835	.2401	.1448	.1829
9	.2195	.2172	.2172		.2401		.1829
10	.1829	.2353	.1991	.2058	.1629	.1448	.1463
11	.1463	.1991				.2195	.1629
12	.1097	.1991		.1715	.1267	.1829	.181
13	.1086	.1991	.1772			.1463	.181
14	.128	.1991	.1715	.1715	.1629	.1829	.1829
15	.1463	.181	.2241	.2126	.1448	.1829	.1715
16	.1463	.181		.1448	.1448	.1463	.1829
17	.1463				.1991	.1829	.1753
18	.1886	.2715			.1991	.2172	.2835
19	.2172	.2896			.2534	.2715	.3258
20	.2926	.3982		.2401	.3439	.3292	.3292
21	.2195	.3258			.2591	.2926	.2926
22	.1848		.1753	.1772	.2353	.2614	.2743
23	.1848		.1753	.1372	.1448	.2172	.2195
24	.1463	.1463	.1629	.1402		.1267	.1829
Max	.2926	.3982	.2715	.2835	.3439	.3292	.3292
Min	.1086	.1109	.1448	.1372	.1267	.1267	.1463
Avg	.1797	.2132	.1867	.1886	.2041	.1867	.2111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 206 / 11 kv Gugwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0543	.0486	.1829		.1619	.0549
2	.0366	.0549	.0486	.1829		.2915	.0543
3	.0366	.0543	.0486	.2172		.2915	.0549
4	.0549	.0543	.0486	.2195		.2915	.0549
5	.0549	.0554	.0648	.2172		.3239	.0549
6	.0549	.0543	.081	.2172		.3887	.0549
7	.0709	.1132	.081	.2126		.4858	.0549
8	.0732	.0549	.081	.2835	.4287	.3563	.0549
9	.0549	.0648	.0324		.4287	.421	.0549
10	.0549		.0324	.4287	.3239	.5121	.0549
11	.3292	.2915			.0324	.0549	.181
12	.3658	.3887		.0486	.0324	.0549	.3841
13	.3982	.2915	.3391		.0324	.0543	.3982
14	.3658	.3887	.373	.0486	.0324	.0549	.4207
15	.362	.421	.4382		.0162	.0549	.439
16	.3292	.421		.0366	.0162	.0549	.3982
17	.4572	.3563			.0324	.0549	.4755
18	.4715	.3563			.0486	.0549	.4163
19	.0566	.0486			.0648	.0543	.0543
20	.0566	.081		.0486	.081	.0549	.0549
21	.0566	.0648	.0526		.0648	.0549	
22	.0543		.0526	.0351	.0486	.0549	
23	.0566		.0543	.0362	.0486	.0549	
24	.0549	.0377	.0486	.0514		.0324	.0549
Max	.4715	.421	.4382	.4287	.4287	.5121	.4755
Min	.0351	.0377	.0324	.0351	.0162	.0324	.0543
Avg	.1642	.1765	.1133	.1542	.1083	.1779	.1822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 201 / 11 KV SHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2195	.2427		.4694	.2561	.1989
2	.2012	.2195	.2427		.503	.2561	.1989
3	.2012	.2218	.2427		.503	.2561	.1989
4	.2683	.2218	.2614		.5365	.2743	.1989
5	.3315	.3881	.3361		.6036	.3109	.2652
6	.3978	.4938	.3921	.5426	1.5091	.5487	.4588
7	.3978	.5068	.4854	.5087	1.8991	.5121	.4588
8	.2652	.3326	.3292	.4917	1.4074	.4207	.3277
9		.2641	.2926	.4748	1.2039	.2926	.2984
10	.2321	.2641	.2195		1.153		
11	.9945	1.094	1.3748	.2402	.2587	.3315	2.5194
12	.9282	1.2266	1.3916	.2587	.2402	.3315	2.8837
13	.6554		1.2574	.2587	.2772	.2652	2.9473
14	.7373	.9282		.2218	.2772	.2652	1.9662
15	.8192	.9282	1.1736	.2218	.2587	.3932	2.6379
16	.9831	1.1233	1.1568		.2587	.2652	2.2283
17	1.1142	1.1568			.3142	.1989	2.6216
18	.6718	1.0395			.3326	.3277	2.556
19	.3547	.3361			.3881	.2652	.4904
20	.4066	.4108		.499	.4805	.4588	.5658
21	.3841	.3921		.4251	.462	.4588	.5281
22	.3109		.2957	.3326	.3696	.3277	.5281
23	.2561	.2801	.2772	.2957		.2652	.3772
24	.218	.2218	.2427	.2772	.2587	.2772	.2321
Max	1.1142	1.2266	1.3916	.5426	1.8991	.5487	2.9473
Min	.2012	.2195	.2195	.2218	.2402	.1989	.1989
Avg	.4926	.5577	.5675	.3606	.6071	.3286	1.1168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 202 / 11 KV kashilingwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.0754	.056
2	.0503	.0754	.056
3	.0503	.0754	.056
4	.0503	.0754	.056
5	.1006	.0943	.0747
6	.1326	.112	.0934
7	.1006	.1478	.112
8	.0838	.0934	.0732
9		.0943	.0732
10	.0838	.0943	.0732
11	.9282	.8453	1.1904
12	.9945	1.0442	1.3077
13	.8848		1.291
14	.9339	1.0442	1.3245
15	.9175	1.1271	1.291
16	.9175	1.1401	1.291
17	.852	1.2239	
18	.852	1.2574	
19	.0934	.0934	
20	.112	.112	
21	.112	.112	
22	.1132		
23	.0943	.0747	
24	.0671	.0754	.056
Max	.9945	1.2574	1.3245
Min	.0503	.0747	.056
Avg	.3875	.4131	.4985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 203 / 11 KV AWANDI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.4807	.7377	.6203
2	.5636	.7712	.6371
3	.663	.7956	.6371
4	.7956	.9779	.6874
5	.9779	1.1797	.788
6	1.1797	1.3108	1.0562
7	1.6385	1.9006	1.6933
8	1.6712	1.7368	1.3599
9		1.6712	1.4746
10	.9175	1.4091	1.3927
11	.2054	.2641	.2218
12	.2241	.2452	.2427
13	.2075		.2614
14	.2075	.2452	.2801
15	.2054	.2452	.2801
16	.2241	.2452	.2801
17	.2427	.2641	
18	.3361	.3206	
19	.3921	.3547	
20	.4805	.3734	
21	.4108	.4108	
22	.3206		
23	.2829	.2427	
24	.1989	.2641	.2241
Max	1.6712	1.9006	1.6933
Min	.1989	.2427	.2218
Avg	.5577	.7257	.7139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 204 / 11 Kv Walekhindi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.0373	.037	.037	.0366	.0373
2	.0373	.0377	.0373	.037	.037	.0366	.0373
3	.0373	.0377	.0373	.037	.037	.0366	.0373
4	.0373	.0377	.0373	.037	.037	.0366	.0373
5	.037	.0377		.037	.037	.0366	.0373
6	.0549	.056	.0373	.0554	.056	.0549	.0554
7	.037	.0373	.056	.037	.0373	.0366	.037
8	.037	.0373	.037	.037	.037	.0366	.037
9		.0377	.037	.037	.037	.0366	.0373
10	.037	.0377	.037	.037	.037	.0366	.0554
11	.0366	.0373	.037	.037	.037	.037	.0362
12	.0362	.056		.037	.037	.037	.037
13	.0366		.037	.037	.037	.037	.037
14	.037	.0373	.037	.0185	.037	.0373	.0373
15	.0366	.0373	.037	.037	.037	.0373	.0373
16	.037	.0373	.037	.037	.037	.0373	.0373
17	.0358	.0373		.037	.037	.037	.037
18	.0362	.0373	.037	.037	.037	.037	.0362
19	.0554	.0373	.037	.0554	.0554	.0739	.0732
20	.0732	.056	.0554	.0554	.0739	.0739	.0549
21	.056	.056	.037	.0554	.0554	.0554	.0566
22	.0373		.037	.037	.037	.0373	.0566
23	.0373	.0373	.037	.037	.037	.0373	.0377
24	.0373	.0377	.0373	.037	.037	.037	.0373
Max	.0732	.056	.056	.0554	.0739	.0739	.0732
Min	.0358	.0373	.037	.0185	.037	.0366	.0362
Avg	.0409	.0408	.0389	.0393	.0409	.0415	.0425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 205 / 11 KV SHEGAON GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.2054	.0934		.1848	.1646	.1478
2	.1478	.1886	.0934		.1663	.1646	.1478
3	.1478	.1886	.0934		.1663	.1646	.1478
4	.1478	.1886	.0934		.1663	.1646	.1478
5	.1848	.2241	.112		.1663	.1646	.2218
6	.2402	.2402	.112		.2801	.2561	.2743
7	.2561	.2772	.1307		.2614	.2378	.2561
8	.2012	.2772	.1294		.2957	.2561	.2743
9	.2012	.3361	.3142		.3696	.2926	.2926
10	.3801	.2801	.2957		.3326	.2743	.3258
11	.2865	.2218	.2957		.2772	.2402	.2454
12	.2804	.2402	.2957		.2772	.2218	.3109
13	.2715		.2772		.2402	.2195	.2378
14	.2561	.2402	.2957		.2402	.0747	.2772
15	.2353	.2402	.2587		.2402	.1848	.2614
16	.2149	.2033	.2402		.2402	.2587	.2587
17	.2229	.2772			.2587	.3077	.2926
18	.4031	.3696			.3696	.3439	.2774
19	.3258	.3547		.1294	.3881	.3582	.3403
20	.3761	.3921	.3142	.3881	.3326	.3403	.3658
21	.3258	.3174	.1294	.3511	.2587	.2896	.3292
22	.2561			.2957	.2033	.2195	.2587
23	.2218	.0934		.2587	.1848	.2012	.2241
24	.2218	.2054	.0934		.2218	.1848	.1478
Max	.4031	.3921	.3142	.3881	.3881	.3582	.3658
Min	.1478	.0934	.0934	.1294	.1663	.0747	.1478
Avg	.2496	.2528	.1930	.2846	.2551	.2327	.2526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 201 / 11 KV Umrani AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1494	.3858	1.065		.1494
2			.1494	.3906	.9945		.168
3			.1494	.4062	.9724		.168
4			.1867	.4858	1.17		.168
5			.1867	.5761	1.0277		.168
6			.1867	.8583	1.1869		.168
7			.2241	1.085	2.0778		.1663
8			.2241	1.2146	1.7078		.1663
9			.2241	1.247	1.7078		.1494
10			.1494	1.2125	1.1498		.1494
11		1.7394			.0914		1.4175
12	1.6129	1.7394			.0914	.1294	
13	1.6446	1.7814	1.7166		.0732	.1109	
14	1.6446	1.8351	1.7859		.0732	.1109	
15	.7811	1.8023	1.7004		.0732	.1097	
16	.7811	1.7859			.0914	.1463	
17	1.7236	1.8351			.0914	.1463	
18	1.4864	1.8023	.4752		.1463	.1478	
19	.1294	1.8023	.1646	.1638	.1463	.2033	
20	.2218	.1867	.1448	.1134	.1829	.2614	
21	.2218	.1867	.1294	.0819	.2195	.2241	
22	.2218		.1448	.0995	.1829	.1867	
23	.1109		.2012	.1509	.1646	.168	
24			.168	.2172	.0995		.168
Max	1.7236	1.8351	1.7859	1.247	2.0778	.2614	1.4175
Min	.1109	.1867	.1294	.0819	.0732	.1097	.1494
Avg	.8817	1.4997	.4230	.5430	.6161	.1621	.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 202 / 11KV Khojanwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668	.3734	.9783	1.4327		.2957
2		.4668	.3734	.9907	1.5181		.2957
3		.4668	.3734	1.0669	1.6804		.2957
4		.4668	.3734	1.1873	2.3758		.2957
5		.4668	.3734	1.2498	2.3205		.2957
6		.6653	.4854	1.5813	2.343		.3696
7		.6653	.5228	2.1052	2.8837		.3881
8			.5228	2.1491	2.4366		.499
9			.4668	2.4387	2.6322		.3361
10			.4668	2.4646	2.3868		.3361
11		.9374		.2785	.3292		2.5926
12	2.8327	.9686		.2126	.3292		
13	2.4036	.4744	2.9473	.2865		.0373	
14	2.4036	2.8807	2.8549		.3658	.1867	
15	2.5926	2.9287	2.8938		.3658	.2957	
16	2.5926	2.8807	2.5587		.4024	.3696	
17	2.6406	2.8807			.439	.4066	
18	2.6406	2.8807	1.3927		.4572	.2957	
19	.3475	.3361	.3174		.6036	.6219	
20	.5487	.4108	.2614		.5487	.695	
21	.5487	.4481	.1715		.5914	.6468	
22	.462		.1829		.5975	.6468	
23	.4108		.2012	.2054	.5487	.6468	
24		.4108	.3734	.2353	.1772		.2587
Max	2.8327	2.9287	2.9473	2.4646	2.8837	.695	2.5926
Min	.3475	.3361	.1715	.2054	.1772	.0373	.2587
Avg	1.702	1.1633	.8803	1.1620	1.2072	.4408	.5216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 203 / 11 KV SINDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5335			.3258		.3048
2		.5335			.2713		.3201
3		.5335			.3012		.3201
4		.5639			.3155		.3353
5		.5639			.3403		.3353
6		.6173			.3439		.3906
7		.8905			.3395		.3906
8					.2926		.3281
9					.3012		.2968
10					.2149		.2968
11				.8421	.852		.0373
12	.0373			.759	.852	.8802	
13	.0373		.0366		.9667	.4268	
14	.0373		.0543		.8288	.7186	
15	.0373		.0366		.8785	.7811	
16	.0373				.8785	.7811	
17	.0373				.8619	.6562	
18	.0373				.8785	.6874	
19	.0373				.0739	.056	
20	.056	.0747			.0739	.0747	
21	.056	.0747			.0739	.0747	
22	.056				.0739	.0747	
23	.056			.0532	.0739	.0747	
24		.0373			.0716		.0373
Max	.056	.8905	.0543	.8421	.9667	.8802	.3906
Min	.0373	.0373	.0366	.0532	.0716	.056	.0373
Avg	.0435	.4423	.0425	.5514	.4368	.4405	.2828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 204 / 11 Kv Umrani Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0492	.0648	.0648	.08		.0655
2		.0492	.0648	.0486	.0972		.0655
3		.0492	.0655	.0486	.0648		.0655
4		.0655	.081	.0655	.081		.0655
5		.0655	.081	.0648	.081		.0655
6		.0655	.1296	.0655	.0648		.0655
7		.0655	.1296	.0791	.0648		.0983
8			.1296	.064	.08		.0655
9			.0648	.081	.0655		.0492
10			.0648	.064	.0829		.0492
11		.0655		.081	.0648		.0492
12	.0492	.0655		.064	.0648	.0655	
13	.0492	.0655	.0972		.0648	.0328	
14	.0492	.0486	.08		.0648	.0492	
15	.0492	.0486	.0648		.0648	.0655	
16	.0492	.0486	.0648		.0648	.0655	
17	.0492	.0648			.0972	.0655	
18	.0492	.0972	.128		.1134	.0983	
19	.0492	.1296	.1457		.1134	.1311	
20	.1311	.1296	.1296		.1296	.1475	
21	.0655	.1296			.1296	.1311	
22	.0655		.0972		.0972	.1311	
23	.0655		.08	.064	.0972	.0655	
24		.0655	.0648	.0972	.081		.0655
Max	.1311	.1296	.1457	.0972	.1296	.1475	.0983
Min	.0492	.0486	.0648	.0486	.0648	.0328	.0492
Avg	.0601	.0720	.0914	.0680	.0837	.0874	.0642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 201 / 11 KV DEVANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.186	1.4232	1.4232		.253		1.2334
2	1.5023	1.4232	1.4232		.253		1.2334
3	1.5023	1.4232	1.7394		.253		1.2492
4	1.6604	1.7394	1.9766		.253		1.2967
5	1.7394	1.9766	2.1032		.2846		1.3441
6	2.2138	2.3403	2.3087		.3163		1.9925
7	1.6446	2.5301			.3795	.3637	2.451
8	2.5301	2.0557	2.5934	.2214	.3479	.253	2.5301
9	2.5301	2.2929	2.4036	.253	.253	.2688	2.5143
10		2.0873	2.451	.253	.2372	.2688	1.5655
11		.2214	.2846	1.4548	2.198	2.4036	.2214
12	.2056	.1898	.253	1.5023	2.2613	2.4194	.2372
13	.2056	.2056	.253	1.7394	2.198	2.372	.2846
14	.2056	.2372	.2214	2.119	2.1348	2.2138	.2214
15	.2056	.2372	.1898	1.9766	2.2138	2.2455	.1898
16	.2214	.253	.1898	.6325	2.2929	2.2771	.2214
17	.253	.1581	.1898	1.186	2.4985	2.4669	.253
18	.3005	.2372	.1898	.9488	2.2613	2.4827	.3163
19	.3637	.2688		.2846	.2846	.2372	.3163
20	.3637	.3479		.3005	.3005	.2846	.3637
21	.3637	.3479		.2056	.3005	.3005	.3163
22	.3163	.2372		.253	.3163	.253	.2688
23	.3163	.1898		.253		.2372	.2846
24	.3163	.3163	.1898		.253		.2372
Max	2.5301	2.5301	2.5934	2.119	2.4985	2.4827	2.5301
Min	.2056	.1581	.1898	.2056	.2372	.2372	.1898
Avg	.9157	.9475	1.1324	.8490	.9715	1.2558	.8809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 202 / 11 KV PACCHPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2606	.2896	.2896	.0579	.0724	.0579	.2606
2	.2896	.2896	.2896	.0579	.0724	.0579	
3	.362	.2896	.362		.0724	.0724	.2606
4	.4054	.2896	.4489	.0579	.0724	.0724	.2606
5	.5068	.362	.5647	.0724	.0724	.0869	.2896
6	.5937	.6081	.6081	.0724	.0869	.0869	.5792
7	.8253	.8398		.0724	.0869	.0869	.7529
8	.724	.6516	.7674	.0724	.0869	.0579	.6371
9	.4054	.7529	.6371	.0724	.0579	.0579	.6226
10	.5792		.6661	.0791	.0579	.0579	.3765
11	.0434	.0869	.0579	.5357	.6371	.724	.0579
12	.0579		.0579	.5792	.724	.8253	.0579
13	.0579		.0633	.5792	.724	.7529	.0579
14	.0579	.0579	.0579	.5792	.7529	.695	.0579
15	.0579	.0579		.4344	.7964	.724	.0579
16	.0579	.0724	.0579	.2172	.7964	.724	.0579
17	.0579	.0724	.0434	.362	.7674	.8109	.0579
18	.0579	.0579	.0434	.4344	.724	.8109	.0579
19	.0869	.1303	.0434	.0579	.0579	.0579	.0869
20	.0869	.0579	.0579	.0869	.0579	.0869	.1014
21	.0869	.0579	.0579	.0869	.0724	.0724	.1158
22	.0724	.0579	.0579	.0869	.0724	.0579	.0579
23	.0724		.0579	.0869	.0579	.0579	.0724
24	.0579	.0724	.0655	.0579	.0724	.0579	.0579
Max	.8253	.8398	.7674	.5792	.7964	.8253	.7529
Min	.0434	.0579	.0434	.0579	.0579	.0579	.0579
Avg	.2443	.2577	.2434	.2087	.2938	.2980	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 203 / 11 KV Rawalgundwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.421	.3239	.2591	.9717	.9555	.3077
2	.3887	.421	.3239	.2915	.9717	.9555	.3077
3	.3887	.421	.3239	.2915	1.2955	1.2793	.3077
4	.3887	.421	.3239	.3401	1.2955	1.3441	.3077
5	.421	.4534	.3887	.3887	1.7814	1.9433	.3077
6	.5668	.4858	.3887	.4858	2.4453	2.4615	.4534
7	.5182			.3887	2.672	2.915	.4858
8			.3563	.5182	2.834	1.4899	.4534
9	.3725	.3077	.3239	.5182	2.6558	2.5587	.4696
10	.3401	.2591	.3563	2.0243	2.6558	2.5587	.2429
11	2.4291	2.8502	2.0729	.3887	.3077	.2915	2.7368
12	2.4291	2.8502	2.4615	.3077	.3239	.3563	2.834
13	2.4291	2.8502	2.6073	.3077	.3239	.3563	2.5911
14	2.5911	2.5263	2.5101	.2105	.3239	.3887	2.672
15	2.915		2.332	.2105	.3239	.4049	2.6882
16	2.753	2.6882	1.7814	.1943	.4534	.4534	2.4291
17	2.915	2.7206	.9231		.4534	.4696	1.9433
18	2.915	2.6558	1.7004	.3077	.502	.4858	2.8016
19	.3401	.3887	.2591	.3401	.3401	.5182	.3239
20	.4372	.3887	.2591	.4534	.4534	.5506	.4696
21	.4372	.2429	.2267	.4534	.4534	.5344	.5344
22	.4372	.2429	.2267	.4534	.502	.4534	.4534
23	.4372	.2267	.2267	.421	.2105	.4049	.4049
24	.3887	.421	.2429	.2429	.3887	.1943	.3239
Max	2.915	2.8502	2.6073	2.0243	2.834	2.915	2.834
Min	.3401	.2267	.2267	.1943	.2105	.1943	.2429
Avg	1.2012	1.1544	.9104	.4260	1.0391	1.0135	1.1187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 204 / 11 kv Rawalgundwadi Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0905	.0934	.0895	.0724	.0934	.0848
2	.0905	.0905	.0934	.0895	.0724	.0934	.0848
3	.0905	.0905	.0934	.1075	.0724	.1307	.0848
4	.0905	.0905	.1494	.0716	.0724	.1307	.0848
5	.1267	.1086	.1494	.1075	.0724	.1494	.0848
6	.181	.1629	.1494	.1433	.1629	.1494	.1187
7	.1448	.0905		.197	.1267	.1307	.1307
8	.0905	.1086	.1307	.2353	.1086	.112	.0934
9	.1267	.1086	.1254	.1267	.1294		.1307
10	.1267	.1086	.1075	.1267	.0924	.0905	.1307
11	.1267	.0724	.0716	.1086	.1294	.1086	.1307
12	.1267	.0724	.0895	.1086	.0739	.1448	.112
13		.0543	.0716	.1086	.0739	.1267	.112
14		.0724	.0895	.1086	.0739	.1086	.112
15	.0724	.0724	.1075	.0905	.0924	.1267	.112
16	.1086	.0724	.1075	.0905	.0924	.1086	.112
17	.1267	.1494	.0358	.1086	.0924	.1494	.112
18	.1448	.1494	.0716	.1086	.1294	.1307	.112
19	.181	.1494	.0716	.1629	.1478	.112	.1494
20	.1991	.1307	.0895	.1991	.1494	.2427	.1867
21	.1991	.112	.1075	.1991	.1494	.1867	.1494
22	.181	.0934	.1433	.181	.0934	.1307	.1307
23	.1267	.0934	.1791	.1267	.0739	.1307	.0747
24	.0905	.0905	.0905	.1433	.0905	.0934	.1029
Max	.1991	.1629	.1791	.2353	.1629	.2427	.1867
Min	.0724	.0543	.0358	.0716	.0724	.0905	.0747
Avg	.1292	.1014	.1051	.1308	.1018	.1296	.1140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 205 / 11 kv Pachhapur Amrutwadi
gav Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0181	.0187	.0185	.0181	.0187	.017
2	.0181	.0181	.0187	.0185	.0181	.0373	.017
3	.0181	.0181	.0187	.0185	.0181	.0373	.017
4	.0181	.0181	.056	.0185	.0181	.056	.017
5	.0181	.0181	.056	.0185	.0181	.056	.017
6	.0543	.0543	.056	.0554	.0362	.056	.0509
7	.0362	.0543		.0185	.0724	.056	.056
8	.0362	.0362	.0486	.0181	.0543	.0373	.0373
9	.0362	.0362	.0185	.0543	.037		.0373
10	.0181	.0362	.0185	.0181	.0185	.0362	.0187
11	.0181		.0185	.0181	.0185	.0181	.0187
12	.0181	.0181	.0185	.0181	.0185	.0362	.0187
13	.0181	.0181	.0185	.0181	.0185	.0181	.0187
14	.0181	.0181	.0185	.0181	.0187	.0181	.0187
15	.0181	.0181	.0185	.0181	.0187	.0181	.0187
16	.0181	.0362	.037	.0181	.0187	.0181	.0187
17	.0181	.0373		.0181	.0187	.0373	.0187
18	.0362	.0373		.0181	.0187	.0373	.0187
19	.0543	.0373	.0185	.0362	.056	.0373	.056
20	.0724	.0373	.037	.0724	.056	.0747	.056
21	.0724	.0373	.0554	.0724	.0373	.112	.0747
22	.0724	.0187	.037	.0543	.0373	.056	.056
23	.0543	.0187	.0185	.0181	.0187	.0373	.056
24	.0181	.0181	.0187	.037	.0181	.0187	.0171
Max	.0724	.0543	.056	.0724	.0724	.112	.0747
Min	.0181	.0181	.0185	.0181	.0181	.0181	.017
Avg	.0324	.0286	.0297	.0288	.0284	.0404	.0313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 201 / 11 KV Kosari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.6001	.8573		.0152		
2	.823	.6859	.9259		.0152		
3	.8573	.8573	1.0288		.0343		
4	.9602	.8916	1.1145		.0343		
5	1.1145	1.0974	1.2003		.0343		
6	1.4403	1.0288	1.3375		.0343		
7	1.5261	1.0288	1.5947		.0343		
8	1.6461	1.0288	1.5947		.0152		
9	1.3032	1.0288	1.5432				
10	1.3546	1.0288	1.3717				.0514
11	.2229	.1715	.3772				
12	.3086	.2572	.3086				
13	.3429	.2743	.3601			2.0576	.3086
14	.3429	.3258	.3772		.9145	2.915	.4287
15	.3429	.3429	.3601		.9907	3.0178	.4115
16	.3601	.3429			1.3717	2.915	.4115
17	.3258	.3601			1.6289	1.5775	.3944
18	.2915	.3772		.0457	1.3717	1.6804	
19	.3429	.3772		.0152	.3048	.2667	.4458
20	.3429	.3772		.0152		.2667	.4287
21	.3429	.3944		.0343		.3734	.3944
22	.3048	.3048		.0305	.1429	.3315	.3601
23	.2743	.2743		.0152		.2858	.3772
24	.2743	.2915	.2591		.0152		.2629
Max	1.6461	1.0974	1.5947	.0457	1.6289	3.0178	.4458
Min	.2229	.1715	.2591	.0152	.0152	.2667	.0514
Avg	.6757	.5728	.9132	.0260	.4348	1.4261	.3563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 202 / 11 KV Kumbharwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.1715	.1886		
2	.2229	.1715	.1886		
3	.2229	.1715	.3429		
4	.2401	.2058	.5144		
5	.2401	.2743	.5144		
6	.463	.2572	.4458		
7	.4115	.2572	.4801		
8	.3086	.2572	.4287		
9	.2743	.2572	.3772		
10	.2401	.2572	.2915		.2229
11	1.286	1.5432	1.3375		1.9376
12	1.3717	1.6632	1.9547		2.0919
13	1.4575	1.6289	1.749	.0381	2.4348
14	1.4575	1.5947	1.8861	.0514	2.452
15	1.4575	1.9052	1.9033	.0514	1.749
16	1.4918	1.9243		.0514	
17	1.4403	1.7661		.0514	
18	1.3203	.9945		.0514	
19	.2572	.3772		.04	
20	.3429	.3429		.04	.4287
21	.3086	.2915		.0343	.3772
22	.2286	.2286		.0229	.3601
23	.1981	.1829		.0229	.3086
24	.2229	.2058	.1677		.0229
Max	1.4918	1.9243	1.9547	.0514	2.452
Min	.1981	.1715	.1677	.0229	.0229
Avg	.6536	.7054	.7982	.0414	1.1260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 203 / 11 KV Birnal GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.1029	
2	.12	.1029	.1029	
3	.12	.0857	.1715	
4	.12	.1372	.1715	
5	.12	.1543	.1715	
6	.1886	.1715	.2058	
7	.1886	.1715	.1886	
8	.1715	.1715	.1715	
9	.1543	.1715	.2058	
10	.1715	.1715	.2229	
11	.1372	.1886	.2058	
12	.1372	.1886	.2058	
13	.1543	.1715	.1543	
14	.1543	.1715	.1543	
15	.1543	.1905	.1886	
16	.1543	.2096		
17	.1715			
18	.1543			
19	.1543			
20	.2572			.2915
21	.2229			.3429
22	.1524	.1524		.3258
23	.1372	.1067		.1886
24	.12	.12	.1067	
Max	.2572	.2096	.2229	.3429
Min	.12	.0857	.1029	.1886
Avg	.1557	.1547	.1707	.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 204 / 11 KV Dhawadwadi GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0686	.0686		.0686	.1029	
2	.1029	.0686	.0514		.0686	.0857	
3	.12	.0857	.0857		.0686	.1372	
4	.12	.0857	.1029		.0857	.1715	
5	.12	.1029	.12		.12	.1715	
6	.1543	.0857	.1372		.1543	.1715	
7	.0686	.0686	.061		.1029	.0514	
8	.0857	.0686	.0762		.0857	.0686	
9	.0686	.0686	.0686		.0686	.0457	
10	.0514	.0686	.0514		.0686	.0305	.0514
11	.0514	.0686	.0686		.0343	.0381	.0343
12	.0514	.0686	.0686		.0514	.0381	.0514
13	.0514	.0514	.0857		.0514	.0572	.0514
14	.0514	.0514	.0686	.0686	.0457	.0572	.0514
15	.0514	.0572	.0686	.0857	.0305	.0572	.0514
16	.0514	.0572		.0686	.0343		.0514
17	.061	.0686		.0857	.0686	.0572	.0857
18	.0762	.0857		.12	.0762	.0857	.0857
19	.1029	.1372		.12	.1524	.0857	.1372
20	.1543	.1372		.1372	.1048	.0762	.1886
21	.1372	.1372		.1372	.1715	.0762	.1543
22	.1029	.1067		.1372	.1372	.1029	.1372
23	.0857	.0762		.0857	.1029	.0857	.12
24	.1029	.0857	.061		.0686	.1029	.0686
Max	.1543	.1372	.1372	.1372	.1715	.1715	.1886
Min	.0514	.0514	.0514	.0686	.0305	.0305	.0343
Avg	.0886	.0817	.0778	.1046	.0842	.0851	.088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 205 / 11 KV Hivare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1715	.1543		.583	
2	.2058	.1715	.1543		.7716	
3	.2058	.1715	.1715		.8573	
4	.2058	.1715	.2572		1.0288	
5	.2058	.1886	.2572		1.5432	
6	.2915	.1715	.3086		1.7318	
7	.3258	.1715	.2134		1.4918	
8	.2572	.1715	.2667		1.4918	
9	.2743	.1715	.2401		1.3717	
10	.2229	.1715	.2401		1.4632	.3086
11	1.4918	1.7147	1.8347		.381	1.8519
12	1.5432	1.9204			.381	2.1262
13	1.5432	1.8861	1.869		.3429	2.1091
14	1.5775	1.749	1.869	.0914	.3429	2.3491
15	1.5775	1.9433	1.9376	.0762	.2858	
16	1.6289	1.9433			.381	
17	1.4937	1.8861			.4382	.6344
18	.503	1.6289		.0762	.3601	.583
19	.2572	.2915		.4572	.3429	.12
20	.2743	.3086		.0953	.3048	.3086
21	.2401	.3086		.1543	.2286	.2743
22	.2058	.1829		.3429	.2572	.2572
23	.1886	.1372		.3601	.2058	.1886
24	.2058	.1886	.1372		.2401	.1886
Max	1.6289	1.9433	1.9376	.4572	1.7318	2.3491
Min	.1886	.1372	.1372	.0762	.2058	.12
Avg	.6305	.7426	.6607	.2067	.7011	.8692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 206 / 11 KV Pratapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1488	.6516	1.2003		.0857	.1029	
2	1.2003	.8573	1.286		.0857	.0857	
3	1.2346	1.0288	1.3717		.0857	.0857	
4	1.3375	1.2003	1.3717		.0857	.1372	
5	1.5775	1.4575	1.5432		.1029	.1372	
6	1.7833	1.3717	1.6804		.12	.1543	
7	1.7661	1.3717	1.6004		.0857	.1029	
8	1.8176	1.286	2.0005		.0857	.12	
9	1.5775	1.2003	1.7147		.0857	.0914	
10		1.2003	1.5604		.0857	.0762	1.2346
11	.1029	.0514	.1029		1.1488	1.7147	.12
12	.1029	.0686	.1029		1.2346	1.8099	.1029
13	.1029	.0686	.1029		1.6289	1.8099	.1029
14	.1029	.0686	.1029	1.046	1.3413	1.7147	.12
15	.12	.0953		1.2174	1.326	1.7147	.2229
16	.12	.0953			1.3717	1.7147	.0857
17	.0914	.0686		1.3032	1.4784	1.848	.1029
18	.0914	.0857		1.286	1.3717	1.4403	
19	.1372	.12		.12	.1219	.1372	.12
20	.1372	.1372		.12	.1543	.1219	.1372
21	.1372	.1372		.1372	.12	.1219	.12
22	.12	.1067		.12	.12	.1543	.12
23	.1029	.0914		.1029	.1029	.12	.1029
24	.0857	.1029	.0914		.0857	.1029	.1029
Max	1.8176	1.4575	2.0005	1.3032	1.6289	1.848	1.2346
Min	.0857	.0514	.0914	.1029	.0857	.0762	.0857
Avg	.6521	.5385	1.0555	.6059	.5214	.6508	.1996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 201 / 11 KV JIRGYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4687	.9116	.8907		.1524	.1524	.6478
2	.703	1.4089	1.3603		.1524	.1524	.6478
3	.703	1.4089	1.3765		.1524	.1524	.664
4	.7811	1.4089	1.3765		.1905	.1715	.7287
5	1.0774	1.4918	1.6194		.2667	.2096	.8097
6	1.7072	2.1548	2.0567		.381	.381	1.2308
7	2.4366	2.9007	2.5911		.4001	.3429	1.8785
8	2.3868	2.8178	2.2348		.2477	.2477	1.9757
9	1.7404	2.3205	2.3266		.1905	.2477	2.0481
10	1.5746	2.0056	1.9989		.1905	.1334	.9831
11	.1524	.1524	.1334		1.5623	1.7814	.0953
12	.1524	.1524	.1143	1.1363	2.3758	2.1538	.1143
13	.1524	.1524	.1143	1.7124	2.3758	2.1052	.1143
14	.1524	.1524	.1143	1.6484	2.6482	1.9433	.0953
15	.1524	.1524	.1524	1.7444	1.9662	1.5384	.0953
16	.2858	.1905	.0953	.5735	2.1628	2.1052	.0953
17	.2858	.1143		.6718	2.3158	2.1052	.1524
18	.1524	.1334		.7701	2.2186	2.1052	.1334
19	.2286	.1905		.2096	.2286	.1524	.1905
20	.2858	.2667	.1905	.2858	.3048	.2286	.1905
21	.2477	.2477	.1334	.2286	.2286	.2286	.1905
22	.1905	.1905	.1143	.1905	.1715	.2286	.1905
23	.1905	.1905	.1143	.1715	.1524	.1524	.1905
24	.1905	.1905	.1905		.1524	.1524	.1524
Max	2.4366	2.9007	2.5911	1.7444	2.6482	2.1538	2.0481
Min	.1524	.1143	.0953	.1715	.1524	.1334	.0953
Avg	.6833	.8878	.9190	.7786	.8828	.7988	.5673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 202 / 11 KV SHINGANAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2858	.2096	.1543	.1852	.3944	.2477
2	.2286	.2858	.2096	.156	.1852	.3944	.2477
3	.2286	.2858	.2096	.156	.2315	.4287	.2858
4	.2286	.2858	.2096	.1734	.3086	.4458	.3048
5	.2858	.2858	.2096	.1734	.4144	.5144	.3048
6	.362	.381	.2096	.3121	.6962	.5304	.3048
7	.362	.381	.2477	.4475	1.0442	.9282	.3048
8	.2477	.381	.2477	.547	.8785	.6962	.3048
9	.1658	.2286	.2096	.5636	.7209	.6962	.1905
10	.1905	.2858	.3239	.5304	.663	.6299	.1905
11	.8288	.6478	.9945	.1715	.2096	.2286	.8583
12	.9116	1.1174	.7625	.2286	.1524	.2286	.8907
13	.7459	1.0526	.6796	.2096	.1905	.2286	.8907
14	.7459	.8907	.3315	.2286	.2667	.2286	.9116
15	.8288	.8097	.9116	.2286	.2858	.2286	.9116
16	.8288	.6478	.3812	.1334	.2858	.2477	.9116
17	.9116	.5182		.1905	.2858	.2286	.9116
18	.8288	.3239	.3647	.2286	.2667	.2286	.8288
19	.2858	.1905		.3048	.381	.2286	.2858
20	.381	.381	.3239	.381	.4763	.2286	.381
21	.381	.3239	.3239	.381	.4191	.2286	.381
22	.3239	.3239	.2477	.3429	.381	.2667	.3239
23	.2858	.2477	.2286	.2858	.3239	.3048	.2858
24	.2286	.2858	.2286		.1905	.3239	.3048
Max	.9116	1.1174	.9945	.5636	1.0442	.9282	.9116
Min	.1658	.1905	.2096	.1334	.1524	.2286	.1905
Avg	.4602	.4520	.3666	.2839	.3935	.3787	.4901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 203 / 11 KV JIRGYAL GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.0953	.0572	.1143	.1334	.1524
2	.1143	.0953	.0953	.0572	.1143	.1334	.1334
3	.1143	.0953	.0953	.0572	.1143	.1143	.1334
4	.1143	.0953	.0953	.0572	.1143	.1143	.1334
5	.1524	.1334	.0953	.0572	.1334	.1143	.2477
6	.2096	.1524	.1334	.1334	.1524	.1905	.2286
7	.2096	.1905	.1334	.1143	.1715	.1905	.2096
8	.1715	.1715	.1334	.0953	.1524	.1334	.1524
9	.1524	.1334	.1524	.0762	.1334	.1143	.1715
10	.0953	.1143	.1143	.0572	.1334	.2477	.1905
11	.1143	.0953	.0953	.0953	.1334	.1905	.1715
12	.0953	.0953	.1334	.1143	.1334	.1524	.1715
13	.1143	.0953	.0572	.1334	.0953	.1334	.1524
14	.1143	.0953	.0381	.1143	.0762	.1143	.1524
15	.0762	.1143	.0762	.1143	.0953	.1143	.1905
16	.0762	.1143	.0572	.0572	.0762	.1143	.1905
17	.0762	.0762		.0953	.0953	.1143	.1905
18	.1143	.1143	.0953	.0953	.1334	.1334	.1334
19	.1524	.1334		.1715	.1715	.1715	.1715
20	.1715	.1715	.1905	.2096	.2477	.1715	.2286
21	.1715	.1715	.1905	.1715	.2096	.1715	.2286
22	.1524	.1334	.1334	.1334	.1905	.1334	.1905
23	.1143	.0953	.1334	.1143	.1524	.1143	.1905
24	.1143	.0953	.0953		.1143	.1334	.1143
Max	.2096	.1905	.1905	.2096	.2477	.2477	.2477
Min	.0762	.0762	.0381	.0572	.0762	.1143	.1143
Avg	.1294	.1199	.1109	.1036	.1358	.1437	.1762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 204 / 11 KV EKUNDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2667	.2012	.2372	.2515	.3239
2	.2858	.2858	.2667	.2012	.2372	.285	.3239
3	.2858	.2858	.2667	.2012	.3163	.285	.3239
4	.2858	.2858	.2667	.2347	.3953	.4191	.3239
5	.381	.381	.4763	.285	.4915	.503	.381
6	.5144	.5716	.4954	.4191	.7537	.6226	.4954
7	.4382	.5144	.4954	.663	1.0322	.7373	.4954
8	.4001	.4954	.381	.7373	1.0159	.7701	.4954
9	.381	.2477	.3429	.5407	.9175	.7701	.381
10	.2858	.2477	.2667	.639	.7701	.6882	.2858
11	.9945	.7459	.8192	.1524	.2477	.2096	1.1222
12	.9945	.9282	.8684	.1524	.2667	.2096	.9231
13	.9116	.9116	.8684	.2286	.2477	.2096	1.0136
14	.8288	.8288	.7701	.2286	.2096	.2286	.8764
15	.7459	.8288	.8192	.1905	.1334	.2096	.964
16	.9116	.7459	.426	.1143	.1905	.2096	.964
17	.9116	.8288		.1905	.2477	.3048	1.0402
18	.9116	.2321	.2984	.2286	.3048	.3048	.6935
19	.2858	.2667		.3429	.362	.3048	.381
20	.4763	.2667	.3048	.4001	.4763	.3048	.381
21	.4191	.2667	.2477	.3239	.362	.3239	.3429
22	.3429	.2477	.2286	.2477	.3239	.3239	.2858
23	.2858	.2667	.2286	.2286		.3239	.2858
24	.2858	.2858	.2667		.2286		.3239
Max	.9945	.9282	.8684	.7373	1.0322	.7701	1.1222
Min	.2858	.2321	.2286	.1143	.1334	.2096	.2858
Avg	.5354	.4688	.4396	.3109	.4247	.3826	.5595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 201 / 11KV K. MAHANKAL GAO
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9492	1.0387	1.0745	1.1283	1.0745	.9313	.9313
2	.9313	.985	1.0745	1.1403	1.0829	.8954	.8954
3	1.0029	.985	1.0387	1.1041	1.0387	.8596	.8596
4	1.0208	1.0029	.985	1.0924	1.0208	.8954	.9313
5	1.0566	1.0387	.985	1.0924	1.0745	.9492	.9671
6	1.0745	1.0566	1.0387	1.0924	1.0745	1.0029	1.0387
7	1.1999	1.0745	1.0208	1.0924	1.0924	1.0387	1.1104
8	1.0745	1.0924	.9313	1.0387	1.0029	.9313	1.0029
9	1.1283	1.0029	.8954	1.0566	1.0029	.9671	1.0745
10	1.1283	1.0924	1.2357	1.2178	1.1462	1.0924	1.1999
11	1.2715	1.2357	1.3073	1.4327	1.1641	1.1462	1.2178
12	1.2536	1.2536	1.3969	1.3432	1.182	1.2178	1.3611
13	1.2894	1.2178	1.3611	1.2715	1.1641	1.3073	1.3611
14	1.2715	1.2536	1.3969	1.2536	1.1641	1.1641	1.3432
15	1.2894	1.2894	1.379	1.2536	1.1999	1.0387	1.3432
16	1.2536	1.2894	1.2894	1.2178	1.2536	1.0387	1.3253
17	1.2536	1.2536		1.182	1.1462	1.1104	1.3611
18	1.182	1.2536		1.2357	1.1999	1.0566	1.2715
19	1.3969	1.576	1.7013	1.5581	1.2536	1.2178	1.4685
20	1.5043	1.4327	1.5939	1.5402	1.4327	1.3432	1.5939
21	1.4327	1.379	1.5223	1.3611	1.3073	1.2715	1.5581
22	1.3611	1.2894	1.3253	1.2715	1.182	1.1104	1.2894
23	1.2357		1.2178		1.0387	1.0745	1.2178
24	.9671	1.0924	1.1641	1.1641	1.1104	.9492	.9492
Max	1.5043	1.576	1.7013	1.5581	1.4327	1.3432	1.5939
Min	.9313	.985	.8954	1.0387	1.0029	.8596	.8596
Avg	1.1887	1.1820	1.2243	1.2235	1.1420	1.0671	1.1947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 202 / 11KV KUCHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.153	1.0852	1.2209	1.1022	.2374	.2204	.2204
2	1.1191	1.153	1.3769	1.1361	.2374	.2035	.1865
3	1.3565	1.153	1.4146	1.1361	.2374	.2374	.2204
4	1.4922	1.1869	1.3395	1.17	.2713	.2543	.2543
5	1.6956	1.5939	1.4922	1.2209	.2883	.2883	.2883
6	1.9669	1.8652	1.7635	1.2717	.3222	.3052	.3222
7	2.2721	2.0008	2.2721	1.5091	.3222	.2713	.3561
8	2.2382	2.1026	2.0687	1.7465	.2543	.3222	.3561
9	1.9839	2.0348	2.1195	1.7635	.3222	.2883	.3052
10	1.5261	1.7295	1.6278	1.4752	.2035	.2543	.3222
11	.2543	.2035	.2035	1.6278	1.7804	2.3908	.3222
12	.2374	.2204	.2204	1.5939	1.933	2.2552	.3052
13	.2374	.2883	.2103	1.3904	1.6956	2.2721	.2713
14	.2374	.2543	.1949	1.3565	1.8652	2.2043	.2543
15	.2204	.2543	.1865	1.3056	2.0348	2.1365	.2374
16	.2507	.2204	.1865	1.3565	2.1704	2.2043	.2883
17	.2713	.2035		1.6956	1.7465	2.2382	.3561
18	.3052	.2035		.9835	1.6956	1.7804	.3561
19	.2713	.3222		.3222	.2543	.2374	.3391
20	.3391		.2204	.3222	.3222	.3052	.3561
21	.3222		.2035	.3391	.3222	.2883	.3391
22	.3052	.3222	.2035	.2883	.2713	.2374	.3222
23	.2713	.1865	.2035		.2204	.2543	.2883
24	.2374	.2713	.1865	.1865	.2543	.2374	.2374
Max	2.2721	2.1026	2.2721	1.7635	2.1704	2.3908	.3561
Min	.2204	.1865	.1865	.1865	.2035	.2035	.1865
Avg	.8568	.8571	.9007	1.1435	.8026	.9036	.2960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 203 / 11 KV HINGANGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.39	.407	.39	.39	1.0174	.8478	
2	.373	.39	.39	.39	.9835	.8139	
3	.407	.39	.39	.39	.9835	1.1022	
4	.4409	.4239	.407	.407	1.153	1.3226	
5	.4917	.4578	.4239	.4239	1.3226	1.5261	
6	.5426	.5087	.4578	.4239	1.543	1.7295	
7	.5426	.5087	.4578	.4239	2.2382	2.0178	
8	.4409	.4578	.4239	.4239	2.1534	2.2891	2.2043
9	.4578	.4409	.407	.4239	.2713	2.0687	2.4587
10	.407	.4239	.4239	.407	1.56	1.933	2.4756
11	2.1026	2.4926	2.4247		.0509	.407	2.4926
12	2.2891	2.5265	2.7469	.4239	.0509	.4239	2.4587
13	1.8991	2.1365	2.73	.4578	.0339	.4409	2.2552
14	2.0348	2.1195	2.7469	.4409	.373	.4409	2.1874
15	2.2213	2.1704	2.713	.4239	.407	.4748	2.0178
16	2.4247	2.1195	2.6113	.4239	.4578	.4409	2.323
17	2.1365	2.4417		.4239	.4239	.4239	2.4587
18	2.0008	2.4417		.4239	.4578	.4409	1.933
19	.373	.4578	.39	.4409	.4239	.4748	.39
20	.4409	.4409	.407	.4409	.4578	.5087	.4748
21	.4409	.4409	.407	.5256	.4409	.4748	.4578
22	.4578	.4239	.39	.407	.4409	.4578	.4409
23	.4409	.407	.39		.39	.4239	.4287
24	.4239	.4409	.407	.39	.39	.407	
Max	2.4247	2.5265	2.7469	.5256	2.2382	2.2891	2.4926
Min	.373	.39	.39	.39	.0339	.407	.39
Avg	1.0075	1.0612	1.0243	.4239	.7510	.9121	1.7161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 204 / 11KV RANJANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.2689	1.4403		.2204	.2035	.2204
2	.9945	1.3375	1.4746		.2035	.1696	.2035
3	1.166	1.3717	1.4746		.2035	.2204	.2543
4	1.286	1.4575	1.5089		.2204	.2713	.3052
5	1.5432	1.5775	1.8004			.3052	.3391
6	1.9719	1.8519	2.3663		.2374	.373	.407
7		1.8861	2.4863		.4578	.3561	.4578
8	2.1948	2.2805	2.4348	1.2039	.3391	.2543	.3222
9	1.9547	1.989	2.5377	1.4074	.3052	.2374	.3222
10	1.0974	1.749	1.8347	1.56	.2883	.3052	.3561
11	.2401	.2229	.3258	1.56	.4239	2.0687	.3391
12	.2743	.3601	.4115	1.6617	.5256	1.95	.3222
13	.4801	.2229	.3944	1.56	.4917	1.7974	.3391
14	.4287	.2401	.3429	1.5261	1.6956	1.8143	.3052
15	.3429	.2401	.2572	1.56	1.9839	1.8482	.3222
16	.2401	.2743	.2401	.9835	2.0517	2.1365	.2883
17	.3086	.3429		.9835	1.9839	2.1195	.2374
18	.3429	.3429			1.6956	1.8143	.3052
19	.3258	.4287	.3052		.3391	.3222	.373
20	.3772	.3601	.2915		.3561	.3391	.3391
21	.3429	.3429	.2743	.1526	.3052	.4239	.3222
22	.3258	.3086	.2915	.3052	.2713	.2713	.2883
23	.2743	.2572	.3086		.2374	.2374	.2713
24	.2401	.3258	.2401		.2374	.2204	.2374
Max	2.1948	2.2805	2.5377	1.6617	2.0517	2.1365	.4578
Min	.2401	.2229	.2401	.1526	.2035	.1696	.2035
Avg	.7731	.8766	1.0474	1.2053	.6554	.8358	.3116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 205 / 11KV LANGERPETH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.1526	.1526	.0848	.1187	.763	.7122
2	.1526	.1526	.1526	.0848	.1187	.7122	.6783
3	.1696	.1357	.1357	.1017	.1357	1.0174	.9326
4	.2035	.1865	.1357	.1017	.1526	1.3226	1.153
5	.2374	.2204	.1865	.1017	.2035	1.5261	1.2548
6	.2543	.2883	.2713	.1187	.2883	1.7465	1.56
7	.2204	.2713	.2543	.0848	.4578	1.8652	1.95
8	.1526	.2374	.1865	.1187	.2883	2.1704	1.7635
9	.1526	.1865	.1865		1.7635	2.0687	1.6956
10	.1696	.1187	.1526	.1696	1.8143	1.95	1.8143
11	1.5091	1.8821	2.0687	.2543	.1187	.1696	1.6956
12	1.7295	1.8482	1.9839	.1865	.1526	.1696	1.4922
13	1.1361	1.8313	2.0856	.1865	.1696	.2035	1.56
14	1.6787	1.8652	2.0517	.1696	.1696	.1865	1.6278
15	1.6956	2.0008	1.9669	.1526	.1865	.2035	1.6956
16	1.6617	2.1704	2.0008	.1696	.1865	.1526	1.9161
17	1.7295	1.9669		.2035	.1865	.1526	1.9839
18	1.1694	1.7974		.1696	.1017	.1865	1.7465
19	.1865	.2713		.2075	.1696	.2204	.2713
20	.2543	.2374	.2883	.2075	.2374	.2713	.2374
21	.2035	.2035	.2035	.2035	.2035	.2204	.2204
22	.1865	.1865	.0857	.1696	.2543	.1526	.2035
23	.1696	.1696	.0857		.2204	.1526	.1865
24	.1526	.1696	.1696	.0848	.1357	.1357	.1526
Max	1.7295	2.1704	2.0856	.2543	1.8143	2.1704	1.9839
Min	.1357	.1187	.0857	.0848	.1017	.1357	.1526
Avg	.6380	.7729	.7050	.1514	.3264	.7383	1.1877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 206 / 11KV S.FACTORY AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2717	1.2548	1.5939	1.0513	.3391	.3052	.3052
2	1.2378	1.3226	1.6108	1.153	.3052	.2543	.2713
3	1.5261	1.3565	1.6108	1.2717	.3052	.2883	.3222
4	1.95	1.4243	1.6617	1.3395	.3222	.3391	.3391
5	2.2043	1.56	1.8652	1.4752	.4239	.407	.373
6	2.4756	2.34	2.4587	1.6448	.5087	.5256	.407
7		3.0521	2.9673	2.0687	.5087	.4917	.4409
8	2.713	2.9843	3.0013	2.2552	.5426	.5256	.5194
9		2.8826	2.9673	2.323	.4748	.4917	.4917
10	2.7808	2.5265	2.5434	2.323	.39	.4748	.5596
11	.4578	.407	.4359	2.1704	1.8482	2.8826	.4748
12	.5256	.5087	.4578	2.2382	2.4587	3.0521	.373
13	.5087	.5256	.4239	2.323	2.5434	3.1539	.407
14	.5087	.5087	.39	2.4078	2.5774	3.086	.39
15	.5256	.5426	.373	2.5434	2.6282	3.1369	.407
16	.5596	.5256	.373	2.2721	2.713	2.9673	.4409
17	.5596	.6104		2.2213	2.8487	2.713	.5087
18	.5765	.6443		1.2717	2.4417	2.3739	.5426
19	.5426	.6274	.3052	.4578	.4748	.3391	.5087
20	.5765	.5765	.373	.4239	.5596	.39	.4917
21	.5087	.5256	.3561	.4239	.5256	.4239	.4578
22	.4748	.4917	.3222	.407	.4409	.39	.4409
23	.407	.39	.3052		.373	.3561	.407
24	.373	.3561	.373	.2883	.3391	.3391	.3391
Max	2.7808	3.0521	3.0013	2.5434	2.8487	3.1539	.5596
Min	.373	.3561	.3052	.2883	.3052	.2543	.2713
Avg	1.0575	1.1643	1.2168	1.5806	1.1205	1.2378	.4258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 207 / 11 KV EXPRESS MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.0905	.1791	.1433	.1433	.1254	.1433
2	.1254	.0905	.1791	.1075	.1254	.1075	.1075
3	.0895	.0716	.1433	.1075	.1254	.0895	.0895
4	.0716	.0537	.1075	.0716	.1075	.0716	.0716
5	.0716	.0537	.0895	.0716	.0895	.0716	.0716
6	.0895	.0537	.0895	.0716	.0895	.0537	.0895
7	.0895	.0537	.0895	.0716	.0895	.0358	.0537
8	.0537	.0716	.0895	.0895	.0895	.0358	.0537
9	.0358	.0895	.0716		.1254	.0537	.0716
10	.0895	.2149	.1433	.197	.1254	.1433	.1254
11	.0716	.1791	.1612	.1791	.1433	.1612	.1433
12	.1075	.1791	.1612	.2149	.2328	.1433	.1612
13	.1075	.2149	.197	.1791	.1791	.1254	.1612
14	.0895	.1791	.2149	.1791	.1791	.1433	.1433
15	.0895	.1612	.2328	.197	.197	.1433	.1433
16	.0895	.1433	.2149	.1254	.1433	.1254	.1254
17	.1075	.1791		.0716	.1433	.1433	.1075
18	.0895	.197	.1791	.1075	.0716	.1433	.1075
19	.0537	.0895	.1791	.1254	.0716	.0895	.1254
20	.0358	.1612	.1612	.1612	.0895	.1254	.1433
21	.0716	.1791	.1791	.1612	.1254	.1612	.1433
22	.1075	.1791	.1791	.1433	.1254	.1254	.1254
23	.1075	.197	.1791		.1075	.1433	.1254
24	.1791	.1075	.2149	.1612	.1433	.1433	.1612
Max	.1791	.2149	.2328	.2149	.2328	.1612	.1612
Min	.0358	.0537	.0716	.0716	.0716	.0358	.0537
Avg	.0910	.1329	.1581	.1335	.1276	.1127	.1164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 208 / 11KV LANGERPETH GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2865	.3045	.1254	.3155	.2543	.2883	.1187
2	.2507	.3045	.1075		.2374	.2543	.1017
3	.3224	.2865	.1075		.2374	.373	.1526
4	.3582	.3403	.1075		.3052	.407	.1865
5	.4119	.3582	.1254		.3222	.407	.2035
6	.4477	.4656	.1433		.39	.4409	.2374
7	.5194	.4835	.5194		.4748	.4748	.2204
8	.3761	.5014	.4835	.3681	.4409	.373	.2204
9	.4298	.4656	.5014	.4458	.407	.4409	.2035
10	.394	.4656	.4835	.4458		.4578	.2035
11	.4656	.4298	.4656	.4458		.4239	.2374
12	.4835	.5014	.4656	.463		.39	.2035
13	.3761	.4298	.4656	.39	.3391	.407	.3052
14	.3582	.4119	.4477	.3391	.3222	.407	.373
15	.3224	.3761	.4119	.3052	.3391	.3561	.407
16	.2865	.3582	.4119	.4239	.39	.0848	.39
17	.3045	.3403		.4239	.1865	.407	.373
18	.3761	.4477		.1526	.4578	.5087	.4748
19	.5014	.6089	.2328		.5087	.5765	.5596
20	.5731	.591	.5014	.5087	.5256	.5596	.6783
21	.5373	.5731	.443	.5087	.4917	.5765	.6104
22	.4298	.5014	.4031	.407	.4578	.2035	.4578
23	.3224	.2865	.3681		.3391	.1696	.373
24		.3224		.3155	.2713	.3222	.1357
Max	.5731	.6089	.5194	.5087	.5256	.5765	.6783
Min	.2507	.2865	.1075	.1526	.1865	.0848	.1017
Avg	.3971	.4231	.3486	.3912	.3666	.3879	.3095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 202 / 11KV SHIRDHON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.2402	.181	.1174	.8688	1.2003	1.0208
2	.3018	.2195	.1612	.1174	.8326	1.3523	.985
3	.3018	.2012	.1433	.1006	.8145	1.1789	.985
4	.2801	.2012	.1417	.0995	.8954	1.2971	1.0631
5	.2743	.2172	.1612	.116	1.1462	1.4563	1.3112
6	.2926	.2715	.2353	.1492	1.5238	1.647	1.7372
7	.3658	.2835	.4024	.1781	2.0157	2.1384	
8	.3921	.2835	.3224	.1698	2.3487	2.4619	2.4013
9	.2587	.2103	.3224	.132	1.5565		2.6353
10	.2534	.2126	.2658	.1966	1.4685		2.774
11	2.1033	2.5591	2.9127	.1524	.1696	.3734	2.1209
12	2.3838	2.5591		.1448	.1715	.4481	2.2436
13	2.4714	2.9473	2.9473		.1907	.4481	1.8031
14	2.5415	2.8607	.4401		.1865	.2865	1.9418
15	2.4539	2.8395	2.6642	.2172	.2172	.2865	2.2192
16	2.3579	2.9797	3.0167	.2507	.2561	.3077	2.4272
17	2.2885	3.034		.2328	.2715	.3475	2.6353
18	2.3579	2.8953		.2328	.2926	.3696	1.893
19	.3258	.2561	.1147	.2328	.2561	.4435	.3326
20	.3658		.1509	.2561	.3174	.4435	.4108
21	.3292	.2957	.1509	.2378	.3142	.3511	.3772
22	.2772	.2957	.1341	.2033	.2987	.2957	.3395
23	.2402	.2801	.1341	.2012	.2614	.2241	.2829
24	.3174	.2402	.2054	.1174	.2172	.2241	.2054
Max	2.5415	3.034	3.0167	.2561	2.3487	2.4619	2.774
Min	.2402	.2012	.1147	.0995	.1696	.2241	.2054
Avg	.9938	1.1471	.7242	.1753	.7038	.7992	1.4846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 203 / 11KV BORGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1698	.1509	.1509	.1334	.1307	.1509
2	.1715	.1509	.1509	.1509	.1143	.1132	.1509
3	.1715	.1509	.132		.1132	.1132	.132
4	.1524	.1509	.132	.132	.1132	.132	.1509
5	.1509	.1698	.1509	.1509		.132	.1698
6	.1509	.1886	.1698	.1698		.1509	.2075
7	.1509	.168	.1848	.168	.168	.1663	.2054
8	.132	.1294	.168	.1478	.1848	.168	.2033
9	.1494	.1307	.168	.1509	.1663	.1494	.1848
10	.1132	.1294	.168	.1494	.1478	.1448	.1629
11	.112	.1132	.1848	.112	.1433	.1791	.1612
12	.1494	.1132	.1478	.112	.1254	.1772	.1829
13		.132	.168	.112	.128	.1772	.1663
14		.132	.1698	.112	.1109	.1463	.1886
15		.132	.1698	.1509	.1109	.1494	.1509
16		.1509	.168	.1509	.1294	.112	.132
17		.1509		.1867	.1478	.112	.1509
18	.1267	.168		.1848	.1829	.1867	.1791
19	.1848	.2054	.168	.1867	.2012	.1886	.2033
20	.2241	.2452	.2263	.2241	.2263	.2263	.2614
21	.2241	.2075	.2263	.1886	.2075	.2075	.2452
22	.1886	.1886	.1886	.1524	.1698	.2096	.2075
23	.1886	.1698	.1698	.1334	.1509	.1886	.1886
24	.1886	.1698	.1698	.1509	.1334	.132	.1698
Max	.2241	.2452	.2263	.2241	.2263	.2263	.2614
Min	.112	.1132	.132	.112	.1109	.112	.132
Avg	.1641	.1590	.1697	.1534	.1504	.1580	.1794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 204 / 11KV BORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.2987	.3206	.1848	.9175	1.1096	.961
2	.3018	.2829	.3018	.1848	.8848	1.262	.8962
3	.3018	.2829	.3018	.1109	.8848	1.0692	.8596
4	.2829	.3018	.2829	.1848		1.2048	.8779
5	.2829	.3018	.3018	.1848		1.3321	1.2437
6	.3206	.3395	.3395	.2033		1.4883	1.5339
7	.3772	.3361	.4338	.181		1.8088	1.8642
8	.3961	.3361	.3734	.1791	2.0452	1.9879	2.0416
9	.3772	.4294	.4481	.197	1.9185	1.97	1.9909
10	.3292	.2743	.4066	.2126	1.5364	1.7896	1.97
11	2.364	2.5415	2.774	.1753	.2366		2.1616
12	2.5065	2.7641	2.878	.1402	.2469		2.1971
13	2.4272	3.0121	2.9096	.1433	.2322		1.9845
14	2.4272	2.8395	2.9096	.1433	.2332	.4481	2.1971
15	2.4188	2.7343	2.9096	.1448	.2423	.4481	2.268
16	2.3663	2.8349	2.8746	.1448	.2469	.4668	2.3388
17	2.3487	2.959		.1463	.2858	.4854	2.3388
18	2.4013	2.7109		.1663	.3001		2.268
19	.3258	.3696		.2033	.2953	.5228	.2772
20	.3734	.4108		.2987	.3086	.5228	.2801
21	.3734	.3921	.2012	.2801	.3022	.5041	.2614
22	.3547	.3734	.2012	.2614	.2824	.5041	.2614
23	.3361	.3584	.1829	.2241	.2572	.4668	.2241
24	.3174	.2987	.3395	.1848	.2241	.2378	.4251
Max	2.5065	3.0121	2.9096	.2987	2.0452	1.9879	2.3388
Min	.2829	.2743	.1829	.1109	.2241	.2378	.2241
Avg	1.0262	1.1576	1.0845	.1867	.5941	.9815	1.4051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 205 / 11KV SHIVGANGA GAO
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1463	.1267	.1294	.1052	.1509	.1294
2	.1509	.128	.1097	.112	.1075	.1509	.1307
3	.1334	.1307	.1097	.112	.0895	.132	.112
4	.1334	.1307	.1254	.1132	.0895	.132	.0934
5	.1307	.1509	.1075	.1132	.1086	.1509	.1132
6	.132	.1698	.1267	.1132	.1109	.1509	.0943
7	.132	.1509	.1267	.132	.112	.1698	.1991
8	.1509	.1509	.2507	.1132	.112	.3012	.3045
9	.132	.1509	.298	.0943	.132		.2427
10	.132	.2054	.3429	.1307	.1478	.2818	.2263
11	.168	.1886	.2241	.1307	.1698	.2587	.2263
12	.197	.2263	.2452	.168	.2263	.2218	.415
13	.2033	.2452	.1509	.168	.2641	.2033	.3429
14	.1867	.2614	.4481	.1494	.2829	.2033	.2774
15	.1867	.2452	.3734	.1698	.2241	.2195	.2452
16	.1698	.2641	.298	.1698	.2033	.2172	.2075
17	.1698	.1886		.1698	.1886	.2481	.168
18	.132	.1698		.1698	.1509	.2149	.1132
19	.132	.1698	.1132	.1663	.132	.197	.1132
20	.168	.1698	.168	.1448	.1509	.1448	.1307
21	.1646	.1448	.1307	.1448	.1494	.1463	.1294
22	.2801	.1417	.128	.1254	.1478	.1463	.128
23	.1595	.1254	.1478	.1254	.1478	.1478	.128
24	.1509	.1433	.1267	.1294	.1214	.1663	.1478
Max	.2801	.2641	.4481	.1698	.2829	.3012	.415
Min	.1307	.1254	.1075	.0943	.0895	.132	.0934
Avg	.1603	.1749	.1945	.1373	.1531	.1894	.1841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 206 / 11KV SHIRDHON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.2263	.2075	.2075	.2241	.2075	.2075
2	.3018	.2263	.1698	.1848	.2054	.1886	.1698
3	.3048	.2075	.1509	.1848	.2054	.1698	.1698
4	.2858	.2263	.1509	.1848	.2241	.1698	.168
5	.2829	.2263	.1698	.2033	.2241	.1886	.1867
6	.2801	.2427	.1886	.2402	.2427	.2075	.2033
7	.3361	.2454	.2353	.2534	.2218	.2743	.2012
8	.3547	.2427	.2328	.2254	.1991	.1928	.2353
9	.3547	.2229	.1928	.2126	.1907	.2229	.1867
10	.1991	.2353	.2195	.1734	.1791	.2035	.2254
11	.1448	.2601	.2454	.1734	.2126	.2035	.2507
12	.1509	.2629	.2229	.208	.2507	.2204	.2454
13	.181	.2835	.2303	.208		.2204	.2572
14	.2279		.2534	.2572	.2774	.2204	.2629
15	.1753	.2507	.2507	.2572	.2353	.208	.2481
16	.1402	.2353	.2507	.2743	.2534	.2103	.2328
17	.1402	.2149		.2743	.2427	.2149	.2279
18	.2303	.2103		.2427	.2427	.2715	.2427
19	.2715	.2835		.3045	.3224	.3696	.3292
20	.3326	.3961	.3584	.3696	.3961	.3361	.3734
21	.3174	.3584	.3206	.3547	.3395	.3018	.3547
22	.2801	.3395	.2829	.3018	.3018	.2865	.3206
23	.2641	.3018	.2452	.2427	.2641	.2641	.2641
24	.3206	.2263	.2263	.2075	.2241	.2263	.2263
Max	.3547	.3961	.3584	.3696	.3961	.3696	.3734
Min	.1402	.2075	.1509	.1734	.1791	.1698	.168
Avg	.2582	.2576	.2288	.2394	.2469	.2325	.2412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 207 / 11KV ALKUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	1.8442	.9362	.5028	.208	.197	.3292
2	.3521	1.7436	1.0387	.5083	.1907	.181	.2896
3	.3481	1.7238	1.134	.591	.1907	.1629	.2804
4	.3113	1.7901	1.0099	.6089	.208	.1791	.2743
5	.3281	1.8679	1.4022	.6219	.2629	.1928	.3185
6	.4108	2.0481	1.6461	.6468	.3506	.2658	.3395
7	.4668	2.2382	2.3663	.7087	.2804	.3898	.3961
8	2.2965	2.452	2.692	.5201	.2896	.3403	.3961
9	2.4366	2.4247	2.4177	.6443		.3721	.2454
10	2.2721	2.2213	2.1026	.3978	.1848	.2534	.2658
11	.1753	.2686	.2303	.421	.8684	1.2071	.2454
12	.2149	.2454	.2896	.4641	1.0111	1.4255	.2328
13	.2454	.2427	.2804	.5121	.9831	1.4089	.2507
14	.2454	.2229	.3189	.6401	.9231	1.4586	.2149
15	.2686	.2427	.2835	.6478	1.0159	1.4586	.2328
16	.2896	.2804	.3077	.6718	1.0774	1.5424	.2481
17	.2896	.298		.5441	1.1401	1.6766	.2658
18	.3224	.3155		.4161	1.1869	.1463	.3582
19	.3258	.3761		.2454	.3258	.1646	.3544
20	.3544	.4298	.3077	.2865	.3801	.1612	.3921
21	.3012	.3898	.2629	.2507	.3224	.2587	.3467
22	.2103	.3721	.2427	.2149	.2774	.4481	.2774
23	.1402	.3721	.2058	.2103	.2601	.3547	.2427
24	.3294	.1402	.3506	.1886	.2058	.2481	.3292
Max	2.4366	2.452	2.692	.7087	1.1869	1.6766	.3961
Min	.1402	.1402	.2058	.1886	.1848	.1463	.2149
Avg	.5525	1.0229	.9441	.4777	.5280	.6039	.2969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 401 / 33 KV JOLLY BOARD
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	.7716	.5093	.6224	.823	.679	.7716
2	.6984	.6173	.5093	.5093	.7716	.5658	.7716
3	.6447	.6173	.4527	.3961	.7716	.5658	.7716
4	.6447	.7202	.4527	.3841	.7716	.5093	.7202
5	.5373	.7202	.3961	.3961	.823	.4527	.5784
6	.5373	.823	.4527	.3961	.823	.5093	.463
7	.2686	.4115	.3961	.2829	.6173	.5093	.463
8	.2149	.2629	.3395	.0857	.463	.3961	.3086
9		.3601	.2829	.0857	.2058	.2058	
10	.1029	.1132	.3395	.3086	.1132	.3086	.3395
11	.1029	.4527	.2263	.1543	.1132	.2572	.0114
12	.1029	.3395	.0572	.1029	.1698	.1543	.2829
13	.1029	.2263	.0572	.1029	.1132	.1543	.1143
14	.1029	.3395	.0857	.1543	.1132	.1543	.1143
15	.1029	.1132	.3395	.1543	.1698	.1543	.0114
16	.1029	.2829	.0857	.2572	.3961	.4115	.2829
17	.1029	.679	.7356	.4115	.5093	.7716	.7922
18	.1029	.679		.7716	.7922	.7202	.7922
19	.2058	.8488	.5093	.6173	.6224	.6687	.5093
20	.3086	.679	.5093	.4115	.9054	.6687	.5658
21	.3086	.5658	.6224	.5144	.6224	.7202	.7356
22	.4115	.6224	.7922	.7202	.9054	.7716	.7922
23	.9774	.6224	.5658	.7716	.5658	.7362	.5658
24	.7522	.7202	.5658	.679	.823	.8488	.7202
Max	.9774	.8488	.7922	.7716	.9054	.8488	.7922
Min	.1029	.1132	.0572	.0857	.1132	.1543	.0114
Avg	.3560	.5245	.4036	.3871	.5418	.4956	.4990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 201 / 11KV DUDHEBHAVI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	09-MAY-18
HR	Load (MW)
1	.7122
2	.7545
3	.7545
4	.9724
5	1.2574
6	1.3748
7	1.8442
8	1.8442
24	.2012
Max	1.8442
Min	.2012
Avg	1.0795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 202 / 11KV NAGAJ AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-MAY-18	09-MAY-18	10-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.7545	.5365	.6783
2	.9496	.6539	.7291
3	1.0174	.7545	.6783
4	1.0059	.8383	.8478
5	1.2071	1.0395	1.0174
6	1.5089	1.3077	1.2717
7	1.8442	1.8945	
8	1.7101		
9	1.5089		
10	.503		
11	.1715		
12	.1543		
13	.1526		
14	.1526		
15	.1526		
16	.1543		
17	.2035		
18	.2204		
19	.2572		
20	.2543		
21	.2374		
22	.2204		
23	.2035		
24	.1865	.2012	.1865
Max	1.8442	1.8945	1.2717
Min	.1526	.2012	.1865
Avg	.6138	.9033	.7727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 203 / 11KV CHOROCHI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	09-MAY-18
HR	Load (MW)
1	.1865
2	.1886
3	.1886
4	.1886
5	.2035
6	.2204
7	.2204
8	.218
24	.2035
Max	.2204
Min	.1865
Avg	.2020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 204 / 11KV DHALEWADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	09-MAY-18
HR	Load (MW)
1	.1187
2	.12
3	.1372
4	.1372
5	.2204
6	.2713
7	.2683
8	.2035
24	.1341
Max	.2713
Min	.1187
Avg	.1790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 205 / 11KV CHOROCHI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	09-MAY-18	10-MAY-18
HR	Load (MW)	Load (MW)
1	.1387	.1543
2	.1387	.1543
3	.1402	.1543
4	.1578	.2058
5	.1734	.2058
6	.2254	.2058
7	.2058	
8	.208	
24	.1578	.156
Max	.2254	.2058
Min	.1387	.1543
Avg	.1718	.1766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 206 / 11 KV DUDHEBHAVI GAO
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	09-MAY-18	10-MAY-18
HR	Load (MW)	Load (MW)
1	.104	.1734
2	.1052	.1715
3	.1052	.1886
4	.1214	.2058
5	.1387	.2229
6	.1387	.2229
7	.1543	
8	.156	
24	.104	.1715
Max	.156	.2229
Min	.104	.1715
Avg	.1253	.1938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 201 / 11KV SHELKEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336	1.0526	1.0322	.6722	.2865		.2801
2	1.1523	1.1012	1.1142	.6401	.2926		.2801
3	1.2125	1.2616	1.1797	.7287	.2896		.2987
4	1.4548	1.4255	1.4586	.852	.3898		.3206
5	1.8233	1.6221	1.4918	1.0442	.4656		.3772
6	2.0081	1.933	1.7772	1.4083	.6024		.6036
7	2.4577	2.4478	2.4143	1.8778	.5487		.4904
8	2.5911	2.3537	2.5652	1.6409	.4252	.4904	.4527
9	2.2405	2.1464	2.0972	1.7772	.3582	.4481	.4715
10	1.7924	1.7652	1.8138	.9555	.3511	.3841	.415
11	.2263	.3109	.2987	1.3592	2.0622	2.5652	.4108
12		.2743	.3584			2.4646	.3547
13		.2303	.2801	.9717		2.431	.2987
14	.2241	.1949	.3361	1.4746		2.146	.2561
15	.2772	.2303	.3547	1.5402		1.7939	.2561
16	.3326	.2534	.3881	1.6644		2.3304	.2926
17	.3696	.2772		1.5729		2.6322	.3881
18	.4251	.3696		.7682		1.989	.3475
19	.4119	.6283	.4338	.4607	.3696	.4668	.4294
20	.5228	.5601	.4715	.4477	.4668	.5093	.5093
21	.4854	.5228	.4338	.4344	.4108	.4338	.3772
22	.4294	.4338	.3772	.394	.3395	.3734	.3772
23	.3547	.2987	.3395	.362	.2987	.3361	.3395
24	.2865	.3696	.2829	.2829	.3258		.2987
Max	2.5911	2.4478	2.5652	1.8778	2.0622	2.6322	.6036
Min	.2241	.1949	.2801	.2829	.2865	.3361	.2561
Avg	1.0096	.9193	.9681	1.0143	.4872	1.3621	.3719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 202 / 11 KV GATHNANDRE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063	.1109	.112	.1132	.4641		.4424
2	.1063	.1109	.112	.1132	.4534		.4161
3	.1075	.112	.112	.1132	.4801		.4372
4	.1086	.1494	.1494	.132	.5376		.4641
5	.1463	.1886	.1886	.1509	.6154		.5243
6	.2172	.2263	.2263	.2452	.852		.7956
7	.1791	.2054	.2452	.2263	1.1469		.9717
8	.1254	.1478	.1478	.1698	1.2955	1.4255	1.012
9	.1267	.1254	.1463	.1132	.5601	1.2125	1.004
10	.0886	.1063	.1267	.0732	.4784	1.0722	.9762
11	.9686	.9069	.9667	.0554	.0526	.0924	.7748
12	.953	.8745	1.2763			.1063	.9555
13	.8592	.8097	1.2929	.0709		.0905	.8322
14	.8482	.6642	1.21	.0716		.0914	.9442
15	.8162	.9646	.9831	.0724		.0914	1.0883
16	.8802	1.0978	1.1961	.0354		.1109	1.1797
17	1.0155	1.2289		.0358		.112	1.166
18	.884	1.1174		.0716	.1109	.1294	1.1336
19	.128	.1494	.132	.1254	.168	.1509	.1307
20	.1886	.1886	.1698	.1267	.1698	.1698	.168
21	.1886	.1886	.1509	.1267	.1509	.1698	.1494
22	.2054	.1494	.132	.1254	.1307	.1509	.1294
23	.1307	.1478	.1132	.1086	.1132	.1307	.1109
24	.1075	.1294	.1307	.1132	.1097		.1109
Max	1.0155	1.2289	1.2929	.2452	1.2955	1.4255	1.1797
Min	.0886	.1063	.112	.0354	.0526	.0905	.1109
Avg	.3952	.4208	.4236	.1126	.4383	.3317	.6632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 203 / 11KV RAIWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0537	.0554	.0754	.3239		.2881
2	.0732	.0537	.0554	.0754	.3201		.3005
3	.0709	.0549	.0554	.0754	.3163		.2812
4	.0895	.0914	.0934	.0754	.3841		.3005
5	.128	.1307	.1494	.1132	.4858		.3321
6	.1595	.1698	.2075	.1886	.6478		.5761
7	.1433	.168	.1509	.1698	.6882		.7274
8	.1075	.1086	.1494	.1698	.7773	.8322	.6562
9	.0905	.0867	.124	.112	.7655	.8583	.6249
10	.0724	.0716	.1052	.0549	.759	.7099	.6167
11	.4572	.5312	.6722	.0554	.0732	.0934	.571
12	.4778	.4999	.664	.0543		.0924	.7186
13	.4572	.4843	.5992	.0549		.0943	.5182
14	.4287	.4254	.5506	.0543		.0924	.6019
15	.4214	.4841	.6802	.0716		.0934	.6481
16	.4515	.5468	.7449	.0886		.112	.6405
17	.5001	.5937		.0716		.0924	.6718
18	.4793	.5944		.0724	.0566	.0566	.5639
19	.1267	.1214	.1494	.1254		.1254	.1267
20	.1402	.1307	.1494	.1267	.168	.1494	.1494
21	.128	.112	.1307	.128	.1509	.1307	.1307
22	.0914	.0934	.0943	.1086	.112	.1132	.112
23	.0739	.0716	.0566	.1086	.0943	.0943	.0934
24	.0724	.0716	.0739	.0754	.0914		.0934
Max	.5001	.5944	.7449	.1886	.7773	.8583	.7274
Min	.0709	.0537	.0554	.0543	.0566	.0566	.0934
Avg	.2214	.2396	.2596	.0961	.3656	.2338	.4310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 204 / 11 KV SHELKEWADI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2241	.2241	.1886	.2328		.2075
2	.2686	.2241	.2241	.1886	.2378		.2075
3	.2658	.2241	.2241	.1886	.2658		.2075
4	.3292	.2829	.2987	.1886	.2865		.2263
5	.3582	.3395	.3734	.2075	.3258		.2641
6	.439	.415	.4668	.2263	.3544		.3961
7	.3658	.3292	.3734	.2641	.3403		.3772
8	.3012	.2926	.2801	.2263	.3045	.3109	.2772
9	.3045	.2601	.2427	.1886	.3258	.3174	.2926
10	.3012	.2279	.2713	.1886	.2715	.2801	.2561
11	.3012	.2328	.2507	.2075	.2353	.1829	.2561
12	.2658	.2328	.2378			.1829	.2328
13	.2279	.2378	.2587	.2507		.2829	.2715
14	.2279	.2402	.1886	.2534		.2614	.2772
15	.2303	.2402	.2614	.2534		.2452	.2561
16	.2279	.2629	.2378	.2507		.2427	.2353
17	.2572	.2629		.2534		.2378	.2481
18	.2713	.2947		.2715	.2865	.2507	.2629
19	.3077	.3761	.3696	.362	.3658	.2772	.2926
20	.4066	.462	.3772	.3544	.4066	.4251	.4294
21	.3772	.3734	.3584	.3475	.4251	.3584	.3921
22	.3395	.3174	.2829	.2835	.3174	.3018	.3018
23	.2641	.2614	.1886	.2686	.2641	.2263	.2829
24	.2865	.2427	.2614	.1886	.2378		.2075
Max	.439	.462	.4668	.362	.4251	.4251	.4294
Min	.2279	.2241	.1886	.1886	.2328	.1829	.2075
Avg	.3007	.2857	.2842	.2435	.3047	.2740	.2774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 205 / 11 KV GHATNANDRE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.1097	.1109	.1132	.1267		.132
2	.128	.1097	.1109	.1132	.1254		.132
3	.124	.1097	.1109	.1132	.1595		.132
4	.1629	.1478	.1494	.1132	.1829		.1509
5	.2012	.1867	.2054	.132	.1991		.1698
6	.2353	.2614	.2614	.2263	.2328		.2641
7	.2149	.1867	.2427	.2075	.181		.2263
8	.1791	.1294	.1867	.132	.1417	.2054	.1663
9	.1595	.1097	.1478	.132	.1307	.1509	.1463
10	.1267	.1294	.1294	.0943	.1307	.1463	.1294
11	.1267	.1097	.128	.112	.128	.1294	.1646
12	.1097	.1097	.1294			.1294	.1478
13	.1097	.1097	.1509	.1772		.132	.1646
14	.128	.1294	.1132	.181		.1307	.1294
15	.1478	.1294	.1307	.1772		.1132	.1294
16	.1478	.1478	.1663	.1829		.112	.1109
17	.1294	.1478		.1629		.1294	.1294
18	.1294	.1663		.124	.1463	.1097	.1478
19	.1663	.2241		.2149	.1867	.2054	.168
20	.2054	.2801	.1509	.2172	.2378	.2641	.2452
21	.168		.1509	.2195	.2075	.2075	.2075
22	.1494	.168	.132	.181	.168	.1698	.1478
23	.1494	.1294	.1132	.1612	.1307	.1509	.1478
24	.124	.1097	.1294	.1132	.128		.132
Max	.2353	.2801	.2614	.2263	.2378	.2641	.2641
Min	.1097	.1097	.1109	.0943	.1254	.1097	.1109
Avg	.152	.1496	.1500	.1566	.1635	.1554	.1592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 206 / 11KV RAIWADI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0876	.0867	.0566	.1086		.1063
2	.0895	.0876	.0867	.0566	.1075		.104
3	.0914	.0876	.0867	.0566	.1063		.1052
4	.0895	.128	.1086	.0566	.1097		.1052
5	.0724	.1463	.1294	.0566	.1267		.1254
6	.0924	.1663	.132	.0943	.1433		.1646
7	.0724	.1294	.1478	.0934	.1267		.1307
8	.0724	.1075	.128	.0754	.0914	.0754	.1075
9	.0709	.1052	.0895	.0566	.1097	.0732	.0886
10	.0724	.104	.0886	.0686	.1097	.1086	.0838
11	.0716	.104	.1052	.0838	.1307	.1052	.0848
12	.0838	.104	.0895	.0895		.1006	.0671
13	.0492	.0701	.0914	.0886		.0876	.0857
14	.0492	.0709	.0895	.0895		.0867	.0701
15	.0514	.0709	.1097	.0914		.1052	.0701
16	.0514	.0867	.1075	.0905		.1017	.0347
17	.0671	.0867		.0895		.104	.0693
18	.0838	.104		.0709	.128	.1006	.0886
19	.0914	.1063	.0943	.1075	.1075	.1267	.1097
20	.0934	.1294	.1132	.1086	.6401	.1463	.1267
21	.0934	.1097	.0934	.1086	.1646	.1791	.1086
22	.0934	.0914	.0754	.1791	.1494	.1417	.0914
23	.1086	.104	.0566	.1463	.0905	.1227	.0732
24	.1075	.1086	.104	.0566	.1086		.104
Max	.1086	.1663	.1478	.1791	.6401	.1791	.1646
Min	.0492	.0701	.0566	.0566	.0905	.0732	.0347
Avg	.0803	.1040	.1006	.0863	.1477	.1103	.0961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 207 / 11KV JAKHAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.1006	.1677	.081	.0732		.0762
2	.2881	.1006	.2012	.0972	.0716		.0762
3	.2949	.1174	.2347	.0983	.0709		.0953
4	.3315	.1174	.2949	.1147	.0716		.0953
5	.3361	.1475	.3277	.1492	.0905		.1132
6	.4163	.1638	.3605	.2347	.1075		.132
7	.5407	.4588	.4588	.3149	.0914		.1886
8	.6062	.5407	.426	.3856	.0732	.168	.132
9	.4858	.4475	.4588	.3647	.0747	.168	.2075
10	.3637	.3812	.2515	.3113	.056	.128	.132
11	.0943	.1132	.1132	.2785		.503	.0943
12	.0943	.1132	.1132			.3978	.0754
13	.0566	.1494	.132	.192		.3521	.0566
14	.0943	.1132	.132	.2294		.3812	.0754
15	.0943	.1132	.1132	.2915		.3481	.0943
16	.1132	.1132	.1307	.3361		.4024	.112
17	.1307	.1132		.3077		.5197	.1494
18	.1494	.1867		.144	.2949	.4191	.1494
19	.1494	.168	.132	.1646	.112	.1132	.0754
20	.1494	.0943	.1509	.1267	.168	.1509	.0943
21	.1307	.0943	.1132	.0709	.1294	.132	.0943
22	.1307	.0943	.0943	.0724	.1307	.1132	.0754
23	.1132	.0566	.0943	.0724	.0943	.0953	.0754
24	.0709	.0943	.0566	.0943	.0724		.0953
Max	.6062	.5407	.4588	.3856	.2949	.5197	.2075
Min	.0566	.0566	.0566	.0709	.056	.0953	.0566
Avg	.2290	.1747	.2072	.1970	.1048	.2745	.1069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 201 / 11 KV LONARWADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.2772	.2772
2		.2987	.3326
3		.3658	.2587
4		.3961	.2587
5		.4435	.2957
6		.4854	.3696
7		.499	.5175
8	.4294		.3696
9			.3292
10			.2987
11			.2614
12			.2561
13			.2561
14			.2801
15			.2195
16			.2561
17			.2896
18			.3109
19			.439
20			.5415
21			.4755
22			.4207
23			.3841
24		.2801	.3475
Max	.4294	.499	.5415
Min	.4294	.2772	.2195
Avg	.4294	.3807	.3352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 202 / 11KV KOKLE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.6653	.8131
2		.7316	.924
3		.8865	.961
4		1.1643	1.0164
5		1.4415	1.0719
6		1.5181	1.4784
7		1.8665	1.7002
8	1.9978	1.7364	1.5339
9			1.0608
10			1.3169
11			1.2803
12			1.4083
13			1.3717
14			1.0242
15			1.2803
16			1.4998
17			1.4632
18			1.2696
19			.4344
20			.5415
21			.5068
22			.4668
23			.4294
24		.3018	.3658
Max	1.9978	1.8665	1.7002
Min	1.9978	.3018	.3658
Avg	1.9978	1.1458	1.0508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 203 / 11 KV IRALI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		1.3769	1.1523
2		1.46	1.2382
3		1.5364	1.2803
4		1.7926	1.3121
5		2.0452	1.6632
6		2.2546	1.848
7		2.7435	2.2731
8	2.7073	2.5019	2.2177
9			1.7924
14			2.1845
15			2.3411
16			2.5606
17			2.5606
18			2.1948
19			.6584
20			.7059
21			.7316
22			.5228
23			.4525
24		.439	.4207
Max	2.7073	2.7435	2.5606
Min	2.7073	.439	.4207
Avg	2.7073	1.7945	1.5055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 204 / 11 KV LONARWADI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.1294	.1663
2		.132	.1478
3		.112	.1478
4		.1132	.1494
5		.128	.1478
6		.1294	.1478
7		.1886	.1494
8	.1494	.1478	.1494
9			.1463
10			.1097
11			.0914
12			.128
13			.1463
14			.1494
15			.1307
16			.1463
17			.1307
18			.0914
19			.1867
20			.2743
21			.1867
22			.1646
23			.1463
24		.132	.1463
Max	.1494	.1886	.2743
Min	.1494	.112	.0914
Avg	.1494	.1347	.1492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 205 / 11 KV KOKLE GAO

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.1478	.1294
2		.112	.1294
3		.0924	.1307
4		.0914	.1109
5		.1132	.112
6		.1307	.112
7		.0566	.112
8	.1109	.0924	.112
9			.1097
10			.168
11			.1478
12			.128
13			.1294
14			.1267
15			.0747
16			.0747
17			.0732
18			.0905
19			.0914
20			.1294
21			.2195
22			.2012
23			.1646
24		.1478	.1463
Max	.1109	.1478	.2195
Min	.1109	.0566	.0732
Avg	.1109	.1094	.1260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 206 / 11 KV IRALI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.0934	.0934
2		.0924	.0934
3		.0943	.0934
4		.0924	.0934
5		.0934	.112
6		.1097	.1494
7		.1307	.1494
8	.112	.1132	.112
9		.1132	.0914
10			.0747
11			.0732
12			.0747
13			.0554
14			.0549
18			.0934
19			.128
20			.132
21			.1646
22			.1463
23			.128
24		.0934	.1097
Max	.112	.1307	.1646
Min	.112	.0924	.0549
Avg	.112	.1026	.1058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 201 / 11 KV DESHING GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.3258	.2896		.2172	.3258
2	.2353	.3258	.3077		.2172	.3258
3	.2353	.2896	.3077		.2172	.3258
4	.3077	.2896	.3077		.2172	.3258
5	.3258	.3258	.3077		.2715	.3258
6	.362	.362	.3258		.3077	.3258
7	.3439	.3258	.3258		.2896	.3258
8	.3077	.3258	.2534		.2172	.2896
9	.2534	.3258	.2534		.2534	.2715
10	.2534	.3258	.3439		.2534	.2896
11	.2353	.3258	.3801		.3077	.3258
12	.2353	.3258	.3801		.3258	.3258
13	.2896	.3258	.362		.3077	.3258
14	.3258	.3258	.362		.3077	.3439
15	.3077	.3258	.362		.3077	.3258
16	.3077	.3258	.362		.3077	
17	.181	.3258	.362		.2896	
18	.362		.362		.2534	.3439
19	.543		.4163		.362	.4525
20	.5068		.4706		.4887	.543
21	.4706		.4706		.362	.4706
22	.4344		.4344		.362	.362
23	.362	.2353	.362		.3439	.362
24	.2715	.362	.2896	.3258	.2353	.3361
Max	.543	.362	.4706	.3258	.4887	.543
Min	.181	.2353	.2534	.3258	.2172	.2715
Avg	.3213	.3210	.3499	.3258	.2926	.3477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 202 / 11 KV BANEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.3413			.0838	.1174
2	1.5257	1.5089			.0838	.1174
3	1.5257	1.643			.0838	.1341
4	1.5257	1.8107			.1341	.1341
5	1.5927	1.9448			.1677	.1509
6	1.9951	2.146			.2347	.2012
7	2.4981	2.6825			.285	.2515
8	2.7496	2.7161	.2515		.3353	.3018
9	1.7604	2.431	1.3748		.2515	.3353
10	1.7772	2.2969	1.4083		.218	.2683
11	.2012	.2683	1.2407		2.1795	.2683
12	.1677	.3018	1.3413		2.5987	.2683
13	.1844	.285			2.5149	.2683
14	.2012	.2683	1.6766		2.3472	.2683
15	.2515	.2683	1.6766		2.3472	.3018
16	.285	.3018	1.6933		2.4143	.3521
17	.3018	.2683	1.6766		2.4143	.3688
18	.1006		1.576		2.3807	
19	.1677		.218		.218	.3856
20	.1844		.218		.2683	.2683
21	.2012		.1844		.2012	.2515
22	.2515		.1844		.1677	.2347
23	.2347		.1677		.1174	.2347
24	.2347	.2347		.1341	.1006	.1174
Max	2.7496	2.7161	1.6933	.1341	2.5987	.3856
Min	.1006	.2347	.1677	.1341	.0838	.1174
Avg	.8865	1.2621	.9925	.1341	.9228	.2435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 203 / 11 KV MORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2742	1.1736	1.0059		.1341	.1341
2	1.3077	1.2742	1.0395		.1341	.1341
3	1.3413	1.3748	1.0395		.1341	.1341
4	1.3916	1.5089	1.0395		.1509	.1341
5	1.4922	1.5424	1.0898		.1844	.1677
6	1.5592	1.576	1.1736		.218	.2012
7	1.6933	1.8442	1.2071		.2347	.218
8	1.6095	1.9113	1.3077		.2012	.2347
9	1.6263	1.6766	1.2071		.1844	.2515
10	1.5089	1.4419	1.3413		.1677	.2347
11	.1677	.2683	1.291		1.6766	.2347
12	.1677		1.3413		1.8778	.2515
13	.1677		1.3413		1.8107	.218
14	.1844		1.4083		1.8107	.218
15	.2012	.2515	1.4083		1.7604	.2347
16	.2012	.2515	1.4083		1.8275	.2347
17	.2012	.2515	1.3413		1.4922	.2515
18	.1677		1.2239		1.4754	.2683
19	.1844		.1677		.2347	.2515
20	.2012		.1844		.218	.2347
21	.218		.1844		.2012	.2347
22	.2347		.1844		.1677	.2012
23	.1844	.1341	.1844		.1509	.2012
24	.1844	.1844	.1341	.1677	.1677	.1341
Max	1.6933	1.9113	1.4083	.1677	1.8778	.2683
Min	.1677	.1341	.1341	.1677	.1341	.1341
Avg	.7279	1.0416	.9689	.1677	.6923	.2089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 204 / 11 KV KHARSHING AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.1006	.0671		.5365	.503
2	.0671	.1174	.0671		.5365	.503
3	.0671	.1174	.0671		.5365	.503
4	.0671	.1341	.0671		.6036	.503
5	.0838	.1341	.0671		.6539	.7545
6	.1006	.1341	.0838		.6874	.8383
7	.1174	.1174	.0838		.9892	.9221
8	.1174	.1341	.1006		1.1401	1.1736
9	.0838	.1341	.0838		1.073	1.2407
10	.1006		.0671		1.0227	1.2071
11	1.5089	1.6766	.0838		.0671	1.1401
12	1.643	2.0957	.0838		.0838	1.2574
13	1.6095	2.0119	.0671		.0671	1.2071
14	1.5927	1.9784	.0838		.0671	1.2407
15	1.6095	1.9784	.0671		.0671	1.3077
16	1.643	1.9113			.0671	1.3413
17	1.7436	1.6766	.0671		.0671	1.4419
18	1.5424		.0671		.0671	1.5089
19	.0838		.1006		.0838	.1006
20	.1006		.1006		.1006	.1006
21	.1006		.0838		.0838	.0838
22	.1006		.0838		.0838	.0838
23	.1006	.0503	.0838		.0671	.0838
24	.0671	.1006	.0671	.0671	.0671	.0671
Max	1.7436	2.0957	.1006	.0671	1.1401	1.5089
Min	.0671	.0503	.0671	.0671	.0671	.0671
Avg	.5966	.8113	.0780	.0671	.3675	.7964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 205 / 11 KV SONI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0671	.0509	.0503	.0335
2	.0671	.0671		.0671	.0335
3	.0671	.0671		.0671	.0335
4	.0671	.0671		.0671	.0335
5	.0671	.0671		.0671	.0335
6	.0671	.0671		.0671	.0335
7	.0671	.0671		.0671	.0335
8	.0671	.0671		.0671	.0335
9	.0671	.0671		.0671	.0335
10	.0671	.0671		.0671	.0335
11	.0671	.0671	.0503	.0671	.0335
12	.0671	.0671	.0503	.0671	.0335
13	.0671	.0671	.0503	.0671	.0335
14	.0671	.0671	.0671	.0671	.0335
15	.0671	.0671	.0671	.0671	.0335
16	.0671	.0671	.0671	.0503	.0335
Max	.0671	.0671	.0671	.0671	.0335
Min	.0671	.0671	.0503	.0503	.0335
Avg	.0671	.0671	.0576	.065	.0335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 206 / 11 KV HAROLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1097	.0732		.5304	.695
2	.0914	.1097	.0732		.5304	.695
3	.0914	.128	.0732		.5304	.695
4	.0914	.128	.0732		.6036	.823
5	.0914	.128	.0732		.6767	.8779
6	.128	.128	.0914		.7682	.9145
7	.1463	.1463	.0914		.8596	1.0791
8	.128	.1646	.0732		1.0242	1.1888
9	.0914	.128	.0914		.9877	1.2071
10	.0914	.128	.0914		.9877	1.1888
11	1.0974	1.4632	.0914		.0732	1.1706
12	1.3717	1.4251	.0914		.0732	1.1706
13	1.39	1.5546	.0914		.0732	1.134
14	1.4083	1.5181	.0914		.0732	1.1888
15	1.4266	1.5181	.0732		.0732	1.2437
16	1.4266	1.5181	.0732		.0732	1.2071
17	1.4266	1.4632	.0914		.0732	1.134
18	1.39		.0914		.0732	1.0974
19	.1097		.0914		.1097	.0914
20	.1097		.1097		.0914	.0914
21	.128		.1097			.0914
22	.128		.1097		.0914	.0914
23	.1097	.0549	.0914		.0732	.0732
24	.0914	.1097	.0732	.0914	.0549	.0732
Max	1.4266	1.5546	.1097	.0914	1.0242	1.2437
Min	.0914	.0549	.0732	.0914	.0549	.0732
Avg	.5273	.6275	.0869	.0914	.3698	.8009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 201 / 11 KV VITTHALWADI GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1578	.1867	.1646	.1052	.1646	.1578
2	.1227	.1227	.1698	.1463	.1052	.1463	.1578
3	.1402	.1402	.1509	.1463	.1052	.1463	.1402
4	.1402	.1402	.1698	.1463	.1227	.1448	.1402
5	.1402	.1402	.1886	.1646	.1402	.1663	.1578
6	.1578	.1753		.1867	.1578	.2033	.1753
7	.1753	.1928	.1829	.2058	.1578	.1612	.1578
8	.1402	.1753	.1663	.1753	.1402	.1417	.1753
9	.1402	.1753	.1698	.1734	.1227	.1629	.1753
10	.1227		.168	.1402	.1052	.1509	.1928
11	.1402	.1629	.1928		.1417	.1578	.1677
12	.1578	.1772	.1928		.1543	.1402	.156
13	.1402		.1886	.1578	.1715	.1402	.1734
14	.1578	.2012	.2012		.1928	.1578	.1715
15	.1753		.1612		.1753	.1578	.1772
16	.2103	.2195	.1734		.1829	.2103	.1578
17	.1928	.2218			.1886	.1753	
18	.2103			.1928	.2172	.2103	.1715
19	.2629			.2804	.2454	.2629	.2254
20	.2804			.3155	.2926	.2804	.2686
21	.2629			.298	.2561	.2629	.2353
22	.2454		.2378	.2629	.2012	.2279	.2012
23	.2103		.181	.2629	.2033	.2103	.1646
24	.1928	.1928	.2241	.1646	.1928	.1663	.1928
Max	.2804	.2218	.2378	.3155	.2926	.2804	.2686
Min	.1227	.1227	.1509	.1402	.1052	.1402	.1402
Avg	.1782	.1730	.1837	.1991	.1699	.1812	.1780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 202 / 11 KV KEREWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.7127	.6226	.6224	.4294	.4715	.4294
2	.9448	.9282	.6718	.6036	.3734	.4715	.4294
3	1.2266	1.1437	.6882	.6036	.3734	.4715	.4294
4	1.2929	1.1934	.8288	.6036	.3734	.4904	.4668
5	1.5415	1.4918	1.0111	.6979	.4294	.5093	.4854
6	1.6741	1.6244		1.1317	.4668	.6224	.5228
7	1.7901	1.7404	1.6876	1.5466	.5228	.5847	.5228
8	1.6244		1.442	1.5546	.5041	.5093	.3734
9	.6299	1.5249	1.3245	1.7924	.4481	.5093	.3547
10	1.0277	1.4089	.7373	1.2197	.4108	.4715	.3361
11		.4338	.4715		2.2028	1.7901	.4715
12		.4904	.5658		2.0595	1.7072	.4115
13		.5041	.5658	.7459	1.7909	1.6741	.0362
14		.5281	.547		1.6651	1.8067	.3185
15		.5228	.4527		1.9004	1.9393	.2743
16		.5281	.4715		1.6651	1.9559	
17		.5281			1.949	1.9725	
18		.5601		.5636	1.8461	1.6078	.415
19		.5788		.5228	.4904	.4668	.5281
20		.5975		.6161	.5847	.5601	.5658
21		.5788		.5975	.5847	.4854	.5093
22		.5041	.4338	.5601	.5281	.5228	.4715
23		.5041	.4527	.5228	.5093	.4668	.4527
24	.4854	.4668	.3772	.4527	.5041	.4904	.4481
Max	1.7901	1.7404	1.6876	1.7924	2.2028	1.9725	.5658
Min	.4854	.4338	.3772	.4527	.3734	.4668	.0362
Avg	1.1848	.8302	.7418	.8310	.9422	.9399	.4206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244141 / 33/11 KV Kerewadi

Feeder No / Name : 203 / 11 KV AGALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2652	.3018			1.1469	.9614
2	.2801	.2987	.2987		.9614	1.1603	1.1934
3	.3361	.3361	.3361		1.2696	1.3108	1.442
4	.3921	.3734	.3961		1.8067	1.4419	1.6741
5	.4294	.4481	.4715		1.989	1.5746	1.8067
6	.5228	.4854			2.4366	2.4034	2.9338
7	.5041	.4854	.5041		2.4531	2.6216	2.1216
8	.4294	.3921	.3734	.2149	.9614	2.5888	2.3205
9	.2241	.2614	.3734	.1886	.7459	2.4366	2.1216
10	.3174	.2614	.2241	.1214		1.5384	2.0553
11	1.8067	2.2377	2.3703		.1387	.2801	1.917
12	1.9559	2.3371	2.3758		.1132	.2427	.0834
13	1.7072		2.13	.2427	.1772	.2427	
14	1.7404	2.146	2.13	.2801	.2686	.2614	1.5238
15	1.6741		1.7859	.3174	.2686	.3174	1.9227
16	1.9227	.5138	2.4249	.3361	.2926	.2801	2.1963
17	2.8178	2.3703		.3734	.2865	.3174	2.4577
18	2.0388			.2987	.2686	.2801	2.2634
19	.3315			.3547	.4344	.3921	.4251
20	.3921			.4481	.4294	.3921	.4481
21	.3315			.4108	.3961	.3734	.4108
22	.3547			.3734	.3326	.3547	.3361
23	.3361			.3921	.2987	.3361	.2427
24	.2987	.3174	.3174		.3921	.2534	.3174
Max	2.8178	2.3703	2.4249	.4481	2.4531	2.6216	2.9338
Min	.2241	.2614	.2241	.1214	.1132	.2427	.0834
Avg	.8934	.8456	1.0508	.3109	.7600	.9395	1.4424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 201 / KHANDERAJURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.6598	1.4575		.2667	.2477	.3048
2	1.5238	1.643	1.4575	.3185	.2667	.2477	.3048
3	1.6194	1.6057	1.4746		.2667	.2477	.3048
4	1.6518	1.6057	1.4746	.4694	.2858	.2477	.3429
5	2.0645	1.7814	1.5565	.5533		.3239	.3429
6	2.6073	2.4453	1.6804	.6133		.4382	.4572
7	2.7854	2.9127	2.4291	.8785	.4191	.4763	.4763
8	2.8018	2.6886	3.0727	.8551	.3429	.4191	.4001
9	2.9492	2.8178	2.834	.9389	.2667	.4191	.362
10	2.5263	2.6726	2.7362	.8848	.2667	.381	.381
11	.1905	.3429	.3429	1.0364	1.5181	2.2834	.3429
12	.2096	.3239	.362	1.6194	2.0081		.3048
13	.2286	.2667	.362	1.6518	1.9757	2.6189	.3048
14	.2667	.1905	.3239	1.6004	1.8947	2.5069	.3048
15	.2858	.2286	.2477	1.6804	1.9433	2.1136	.3048
16	.3048	.362	.3048	1.6842	1.1702	2.6397	.4763
17	.4001	.4572	.2286	1.5893	2.0405	2.834	.4763
18	.4382			1.4575	2.0729	2.3703	.362
19	.5335	.3048	.2477	.2667	.362	.362	.2858
20	.4954	.4572	.3429	.3239	.4382	.4763	.2858
21	.4763	.4572	.3048	.3048	.4382	.4191	.2858
22	.4572	.4191	.2858	.2858	.381	.381	.3239
23	.381	.381	.2667	.2667	.3239	.362	.3239
24	.362	.1524	.3429		.2667	.3048	.3239
Max	2.9492	2.9127	3.0727	1.6842	2.0729	2.834	.4763
Min	.1905	.1524	.2286	.2667	.2667	.2477	.2858
Avg	1.1271	1.1381	1.0494	.9181	.8734	1.0052	.3493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 202 / 11 KV Khatav
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2667	.2667		1.2407		.6718
2	.2858	.2667	.2667		1.2407		.8002
3	.2858	.2667	.2667		1.2407		.7293
4	.2858	.2858	.2667		1.1961		.8122
5	.3048	.3429	.2667				.7935
6	.3048	.4001	.2858				.9717
7	.4001	.3239	.3239	.2477			1.4737
8		.3048	.3048	.1905	1.1174		1.5729
9		.2667		.2477			1.6244
10	.2667	.2667	.3239	.1715		1.0098	1.704
11	2.2939	2.0243	2.0153	.1524			1.7238
12	2.0405	2.332	2.3158	.1715			
13	2.1214	2.2672	2.3482	.1715		.2096	
14	2.1445	2.1052	2.0972	.1524		.2096	
15	2.2085	2.1376	1.3765			.2286	
16	2.2996	2.1605	1.8233	.2477		.2477	
17	1.9204	2.3805	.7209	.2858		.2286	
18	1.9757	2.2245		.2477		.2286	
19	.2096	.2286	.2286	.2286		.2667	
20	.3239	.3239	.2286	.3048		.2858	
21	.3239	.3429	.2096	.2858		.2667	
22	.3048	.3048	.2096	.2667		.2286	
23	.2858	.2858	.1905	.2286		.2096	
24	.2858	.2667	.2858		.2096		.2096
Max	2.2996	2.3805	2.3482	.3048	1.2407	1.0098	1.7238
Min	.2096	.2286	.1905	.1524	.2096	.2096	.2096
Avg	.9617	.9323	.7555	.2251	1.0409	.3017	1.0906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 203 / 11 KV Mallewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2096	.1905	.1524	.7545	.664	.4694
2	.2096	.2096	.1905	.1334	.7545	.6964	.503
3	.2096	.2096		.1334	.7545	.6722	.4973
4	.2286	.2096	.1905	.1524	.7537	.6401	.5304
5	.2286	.2286	.1905	.1524		.7362	.6554
6	.3048	.2667	.2286	.2096		1.2631	.8029
7	.2667	.2667	.2477	.2096	1.7328	1.8023	1.2289
8		.2286	.2286	.2286	2.0005	1.8842	1.3094
9		.2286	.1905	.1715	1.8404	1.7859	1.3923
10	.1905	.2096	.2286	.2096	1.0402		1.4918
11	1.6712	1.8023	2.0222	.2096	.1905	.1715	1.5424
12	.5636	2.1464	1.9919	.2477	.1905	.1905	1.8067
13	.5735	1.9662	1.8299	.2477	.1905	.2096	1.9433
14	1.7328	1.8623	1.9334	.2286	.2096	.2096	1.8138
15	1.8785	1.8564	1.917	.2667	.1905	.2286	1.8138
16	2.0325	1.8724	2.0317	.2096	.1905	.1715	2.0805
17	2.0645	2.0243	.6539	.2477	.2477	.1715	2.0805
18	1.5223	1.8724		.2286	.1715	.2286	1.8785
19	.2667	.2286	.6539	.2477	.2286	.2667	.3048
20	.2858	.2858	.1905	.2858	.2667	.2858	.3048
21	.2667	.2858	.1905	.2667	.2667	.2477	.3048
22	.2477	.2477	.1905	.2477	.2477		.1905
23	.2286	.2286	.1524	.2286	.2286	.1334	.1905
24	.2096	.2096	.1905	.1334	.1905	.1905	.1143
Max	2.0645	2.1464	2.0317	.2858	2.0005	1.8842	2.0805
Min	.1905	.2096	.1524	.1334	.1715	.1334	.1143
Avg	.6996	.7982	.7197	.2104	.5746	.5841	1.0521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 204 / 11 kv shivganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.0762	.0572	.0572	.0572
2	.0572	.0572	.0762	.0762	.0572	.0572	.0572
3	.0572	.0572	.0762	.0762	.0762	.0572	.0572
4	.0572	.0762	.0762	.0762	.0572	.0572	.0762
5	.0762	.0572	.0762	.0762		.0572	.0762
6	.0762	.0762	.0762	.0762		.0762	.0762
7	.0762	.0762	.0762	.0762	.0572	.0762	.0762
8	.0762	.0762	.0762	.0762	.0572	.0762	.0762
9	.0762	.0762	.0572	.0762	.0762	.0762	.0762
10	.0762	.0762	.0953	.0762	.0762	.0572	.0762
11	.0572	.0762	.0953	.1334	.0762	.0953	.1715
12	.0762	.0762	.0762	.0762	.0762	.0762	.1715
13	.0762	.0762	.0762	.0762	.0762	.0762	.2858
14	.0762	.0762	.0762	.0572	.0762	.0762	.2667
15	.0572	.0762	.0762	.0762	.0762	.0762	.2667
16	.0191	.0762	.0953	.0762	.0762	.0762	.0762
17	.0762	.0762	.0762	.0762	.0762	.0762	.2667
18	.0572	.0572		.0762	.0381	.0762	.3048
19	.0572	.0762	.0762	.0191	.0762	.2667	.0953
20	.0572	.0762	.0762	.0572	.0762	.0762	.0953
21	.0762	.0762	.0762	.0762	.0762	.0762	.0762
22	.0572	.0762	.0762	.0572	.0762	.0762	.0762
23	.0572	.0762	.0762	.0572	.0762		.0762
24	.0762	.0762	.0762	.0762	.0572	.0762	.0762
Max	.0762	.0762	.0953	.1334	.0762	.2667	.3048
Min	.0191	.0572	.0572	.0191	.0381	.0572	.0572
Avg	.0651	.0730	.0779	.0730	.0693	.0804	.1254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 205 / 11KV Salgare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.57	.6443	.5801	.3944	.1524	.1524	.1715
2	.6371	.6036	.5801	.3641	.1524	.1524	.1715
3	.7293	.6371	.5801	.3856	.1524	.1524	.1905
4	.779	.663	.5868	.4382	.1715	.1524	.1905
5	.8848	.8848	.6371	.4908		.2096	.1905
6	.8848	1.1984	.8097	.5316		.2667	.2477
7	1.4419	1.4243	1.3108	.7209	.2477	.2286	.1905
8	1.7238	1.6194	1.6842	.8048	.2477	.1905	.1905
9	1.4918	1.4575	1.1469	.8288	.1905	.1905	.2096
10	1.3117	1.5238	1.1142	.7537	.1334	.1905	.2096
11	.1524	.1334	.1524	.8259	1.1174	1.2929	.1715
12	.1524	.1334		.9231	1.262	1.757	.1905
13	.1715	.1334	.1524	1.0526	1.4883	1.6057	.1905
14	.1905	.1334	.1715	1.0978	1.4118	1.2452	.2286
15	.1905	.1524	.1334	1.1336	1.3535	1.5061	.2286
16	.1715	.2477	.1524	.9012	1.5023	1.2308	.2286
17	.2667	.2096	.1524	.9878	1.6832	1.6876	.2286
18	.2667			.9555	1.5203	1.065	.1905
19	.2667	.3048	.1715	.1905	.1905	.2286	.2477
20	.2477	.2858	.1715	.1905	.2667	.2286	.2477
21	.2477	.2286	.1524	.1715	.2667	.2096	.2477
22	.2286	.2096	.1524	.1524	.1905	.1715	.1905
23	.2096	.1905	.1524	.1524	.1715	.1715	.1905
24	.1715	.1905	.1715	.1334	.1524	.1524	.1715
Max	1.7238	1.6194	1.6842	1.1336	1.6832	1.757	.2477
Min	.1524	.1334	.1334	.1334	.1334	.1524	.1715
Avg	.5578	.5743	.4962	.6075	.6375	.6016	.2048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 206 / BELANKI gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.1905	.2286	.1905	.1905	.1715	.1905
2	.2667	.1905	.2286	.1715	.1905	.1715	.1905
3	.2858	.1905	.2286	.2096	.1905	.1715	.1905
4	.2858	.1905	.2286	.2096	.1905	.1715	.2667
5	.2667	.2286	.2286	.2286		.2667	.2667
6	.3048	.3048	.2858	.3048		.381	.3239
7	.3048	.3048	.3429	.2858	.362	.362	.2477
8	.1905	.2667	.2286	.2477	.1905	.2477	.2286
9	.1715	.2286	.2096	.2667	.2667	.2667	.1715
10	.2286	.2858	.2477	.2667	.2743	.2477	
11	.2286	.2667	.1905	.2477	.2012	.2667	.2286
12	.2096	.2477	.1905	.1905	.2126	.2477	.1715
13	.2286	.2286	.2477	.2286	.2218	.2286	.2667
14	.2286	.2096	.2286	.2477	.168	.2667	.2286
15	.2286	.2286	.1905	.2477	.2328	.2858	.2286
16	.2096	.2477		.3048	.1867	.2858	.2858
17	.2286	.2477	.2477	.2858	.2743	.3239	.2858
18	.2286	.2096		.2477	.2926	.2477	.2286
19	.2858	.362	.3048	.2667	.2353	.362	.3239
20	.2858	.4572	.2858	.381	.3239	.3429	.3239
21	.2667	.4572	.2477	.3429	.3048	.3048	.3239
22	.2477	.2667	.2096	.2667	.2667	.2477	.2096
23	.2286	.3048	.1905	.2286	.2096	.1905	.2096
24	.2667	.1905	.2286		.1905	.1715	.1905
Max	.3048	.4572	.3429	.381	.362	.381	.3239
Min	.1715	.1905	.1905	.1715	.168	.1715	.1715
Avg	.2477	.2627	.2373	.2551	.2353	.2596	.2427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 201 / 11 KV Lingnoor Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1715	.1905	.0739	.1715	.1905	.2096
2	.1698	.1524	.1905	.0739	.1524	.1905	.1905
3	.1524	.1524	.1905	.0739	.1334	.1905	.1905
4	.1524	.1524	.1715	.0739	.1143	.1905	.1905
5	.1524	.1524	.2096	.0924		.2075	.1905
6	.2075	.1524	.2263	.112		.1886	.2075
7	.1524	.1509	.1509	.132	.1698	.1494	.1478
8	.1886	.1494	.1715	.1132	.1509	.1294	.1509
9	.1494	.168	.1494	.1663	.1867	.1509	.1663
10	.2263	.2241	.2054	.2054	.2054	.1886	.181
11	.1886	.2075	.2054	.2241	.181	.2263	.181
12	.2075	.132	.1509	.2241	.1646	.1886	.2149
13	.1698	.1905	.1886	.2263	.2195	.1524	.1848
14	.1494	.1905		.168	.1509	.1905	.1478
15	.1143	.1524	.1509	.1478	.1509	.1905	.1494
16	.1132	.1509	.1109	.1307	.1307	.132	.1494
17	.1132	.1509		.1433	.1132	.1509	.1494
18	.0762	.1132		.2149	.1663	.1524	.1494
19	.1829	.2658	.2218	.2149	.1509	.1886	.1829
20	.2957	.3326	.2641	.2896	.2614	.3395	.3439
21	.2801	.2987	.1867	.2896	.2801	.3174	.2896
22	.2452	.2829	.1867	.2402	.2263	.2987	.2561
23	.2096	.2263	.1494	.1698	.2263	.2641	.2561
24	.2075	.1905	.2096	.1494		.2096	.2096
Max	.2957	.3326	.2641	.2896	.2801	.3395	.3439
Min	.0762	.1132	.1109	.0739	.1132	.1294	.1478
Avg	.1781	.1879	.1848	.1646	.1765	.1991	.1954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 202 / 11 KV Shindewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1698		1.0402	1.4937	1.4586
2	.1524	.1524	.1715		1.0883	1.4784	1.4918
3	.1524	.1524	.1715		1.0883	1.4937	1.5912
4	.1524	.1524	.1715			1.4937	1.5912
5	.1524	.1509	.1715			1.326	1.6907
6	.1715	.1509	.1698	.1463		1.5729	1.9227
7	.2075	.1886	.1478	.1097	1.8564	2.304	2.1216
8		.1698	.168	.1494	2.5316	2.3205	2.1051
9		.1509	.168	.1097	2.0222	2.3975	2.2211
10	.1509	.1867	.168	.0924	1.9662	2.0454	2.2466
11	2.5149	2.3472	2.4981	.0934	.0934	.0934	2.1051
12	2.2969	1.7901	2.6825	.112	.1494	.1509	1.9559
13	2.0885	2.4249	2.649	.1307	.1698	.1509	2.4863
14	2.0957	2.4905	2.4863	.1307	.2218	.1143	1.8945
15	2.1795	2.5029	2.4863	.1132	.2054	.1143	2.0119
16	2.2298	2.5484	2.2939	.0924	.2195	.1132	2.1293
17	2.146	2.4863		.1132	.1402	.112	2.2542
18	2.1963	2.3137		.0934	.144	.1478	2.1879
19	.2195	.1791		.1772	.1753	.1848	.1829
20	.2427	.2402	.1463	.1848	.1928	.1867	.2075
21	.2241	.2241	.156	.1867	.181	.1867	.2054
22	.2054	.2054	.156	.168	.1629	.1867	.1867
23	.1663	.1886	.104	.1478	.1294	.1646	.1494
24	.1886	.1663	.1886	.104	.1307	.1294	1.4586
Max	2.5149	2.5484	2.6825	.1867	2.5316	2.3975	2.4863
Min	.1509	.1509	.104	.0924	.0934	.0934	.1494
Avg	.9221	.9048	.8345	.1292	.6623	.8317	1.5773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 203 / 11 KV Landgewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1143	.1143	.0762	.852	.8288	.7865
2	.0762	.0953	.0953	.0762	.8848	.8383	.8192
3	.0762	.0953	.0953	.0762	.8745	.8288	.8192
4	.0762	.0953	.0953	.0762	.7682	.8192	.8122
5	.0762	.0953	.1143	.0762		.9448	.8619
6	.0762	.0953	.1143	.0762		.852	1.004
7	.0762	.1143	.0953	.0953	1.0059	1.065	1.1498
8	.0953	.1143	.0762	.0953	1.2431	1.2597	1.278
9	.0953	.1143	.0953	.0953	1.358	1.2239	1.2763
10	.1143	.0953	.0762	.0953	1.2125	1.004	1.1603
11	1.326	1.0688	1.2597	.0762	.0572	.0762	.9945
12	1.3413	1.1012	1.1768	.0762	.0762	.0953	1.0608
13	1.2742	1.0688	1.2763	.0762	.0762		.9945
14	1.326	1.0978	1.326	.0953	.0762		1.0111
15	1.1904	1.0978	1.3923	.0953	.0762	.0953	1.1603
16	1.2239	1.1305	1.3094	.1143	.0572	.0953	1.21
17	1.2597	1.1271		.0762	.0762	.0762	1.2323
18	1.2071	1.3077		.0762	.0762	.0762	1.0402
19	.1143	.1334	.1595	.0953	.0953	.0953	.0953
20	.1143	.1334	.1143	.1143	.1334	.1334	.1143
21	.1143	.1334	.1143	.1143	.1334	.1334	.1143
22	.0953	.1143	.1143	.1143	.1143	.1143	
23	.1143	.1143	.1143	.0572	.0953	.0953	.0953
24	.0762	.1143	.1143	.0953	.0762	.0762	.0953
Max	1.3413	1.3077	1.3923	.1143	1.358	1.2597	1.278
Min	.0762	.0953	.0762	.0572	.0572	.0762	.0953
Avg	.4840	.4488	.4292	.0881	.4281	.4921	.8342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 204 / 11 KV Lingnoor Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9845	1.8976	1.7924	1.0719	.2054	.2641	.2641
2	2.0165	1.9204	1.8785	.9145	.1867	.2641	.2477
3	2.0645	1.9433	1.9109	.9145	.1886	.2641	.2477
4	2.0885	1.9433	2.0885	.9145		.2641	.2286
5	2.1293	2.1925	2.4531	1.0669		.2641	.2286
6	2.6852	3.0664	2.8166	1.3426		.3206	.2987
7	2.8509	3.315	2.7526	1.5242	.2987	.3395	.3174
8	3.1659	2.7854	2.7183	1.7593	.3018	.3395	.2801
9	2.8509	2.8673	2.982	1.8976	.2402	.2452	.3395
10	2.7854	2.5911	2.6216	2.0241	.2241	.2263	
11	.2614	.2801	.2241	1.6964	1.7924	2.4366	.3206
12	.2641	.3018	.2452	1.6248	2.332	2.5194	.3206
13	.2829	.2801		1.6091	2.2672	2.6189	.2641
14	.2452	.2987		1.5813	2.0405	2.7183	.2641
15	.2641	.2987		1.8138	2.1195	2.9338	.2427
16	.2987	.2987		1.8724	1.9925	2.5396	.2427
17	.3547	.2987		1.6804	2.1376	2.5194	.2241
18	.3772			1.2003	1.8244	2.4577	.2587
19	.3734	.5041	.2378	.2507	.3292	.3734	.3361
20	.4338	.547	.2987	.2957	.3921	.415	.415
21	.3772	.4715	.2614	.2801	.3547	.3961	.3772
22	.3395	.4338	.2614	.2614	.3361	.3395	.3734
23	.3395	.3772	.1848	.2402	.2829	.3018	.3361
24	.3206	.2987	.3018	.1848	.2218	.2641	.2641
Max	3.1659	3.315	2.982	2.0241	2.332	2.9338	.415
Min	.2452	.2801	.1848	.1848	.1867	.2263	.2241
Avg	1.2147	1.2701	1.4461	1.1676	.9556	1.0677	.2910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 205 / 11 KV Khatav Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.5091	1.2803	.5544	.0762	.415	.4572
2	1.5424	1.5089	1.5546		.0762	.415	.4191
3	1.576	1.5261	1.749		.0762	.415	.4191
4	1.7101	1.5261	1.7497		.0762	.415	.4382
5	1.9448	1.9784	2.1216			.415	.4527
6	2.1795	2.3137	2.4143	.9614		.3772	.5281
7	2.2721	2.146	1.9669	1.3923	.0377	.415	.6161
8	2.4981	2.146	2.146	1.5249	.0377	.2987	.4715
9	1.9616	1.7974	2.1795	1.6575	.1132	.3734	.4854
10	1.7295	1.9113	2.0454	1.5581	.3109	.3395	.4066
11	.3696		.2263	1.3413	.9945	1.8442	.4108
12	.4338		.1848	1.4918	1.4419	1.8564	.2641
13	.4527	.2641		1.4255	1.8107	1.9113	.2218
14	.415	.5281		1.4922	2.2131	1.9784	.2103
15	.4108	.4481		1.6766	1.1065	2.0687	.2263
16	.3547	.4668		1.0277	1.0059	1.8442	.3018
17	.3734	.5601		1.358	1.5424	1.8778	.3395
18	.4854			1.3094	1.7101	1.9113	.3361
19	.5601	.679	.4252		.4668	.3584	.5281
20	.7095	.7733	.4298	.1886	.6036	.6036	.6036
21	.6602	.7356	.3696	.0762	.5788	.6413	.6413
22	.5658	.6979	.3696	.0953	.4527	.6224	.5658
23	.5093	.5281	.3696	.0953	.4338	.5658	.5658
24	.4527	.4715	.4527	.3696	.0762	.415	.4572
Max	2.4981	2.3137	2.4143	1.6766	2.2131	2.0687	.6413
Min	.3547	.2641	.1848	.0762	.0377	.2987	.2103
Avg	1.0635	1.1674	1.2242	1.0314	.6928	.9324	.4319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 201 / 11 KV Arag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4251	.3658		.4338	.3772	.3206	.3772
2	.3921	.3772	.3696	.415	.3772	.3206	.3584
3	.3921	.3584	.3696	.3772	.3772	.3206	.3584
4	.3921	.3584	.3734	.3772	.3772	.3206	.3584
5	.3881	.3395	.4108	.3584		.3206	.3584
6	.4251	.3961	.3982	.3772		.3772	.3584
7	.3801	.4207	.3898	.4066	.4344	.3982	.3696
8	.3982	.4298	.3681	.181	.3467	.4119	.3696
9	.4252	.4607	.4252	.3761	.3944	.4031	
10	.3898		.4508	.3641	.4115	.4458	
11	.4075		.4801	.4161	.3856	.4287	
12	.4382		.4239	.4287	.3601	.4161	
13	.3898		.4409	.3944	.3521	.4161	
14	.4382		.4239	.4115	.3521	.4334	
15	.4252		.4458	.4161	.3944	.4508	
16	.3856		.4706	.4119	.3601	.4334	
17	.3898			.394	.3681	.4334	
18	.4031			.4477	.4207	.3467	
19	.5194		.5068	.4525	.5014	.5014	
20	.6283		.5544	.5249	.5731	.4887	
21	.5359		.4805	.462	.4887	.4805	
22	.462		.4805	.4066	.439	.4066	
23	.4435		.415	.3961	.3696	.3961	
24	.4066	.4066	.4207	.4527	.3772	.3395	.3772
Max	.6283	.4607	.5544	.5249	.5731	.5014	.3772
Min	.3801	.3395	.3681	.181	.3467	.3206	.3584
Avg	.4284	.3913	.4333	.4034	.4017	.4004	.3651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 202 / Arag mix Laxmiwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2263	.2452	.0377	1.2178	1.0364	1.0227
2	.2452	.2263	.2263	.0377	1.1904	1.1336	1.2431
3	.2452	.2263	.2263	.0377	1.2717	1.1984	1.3426
4	.2452	.2263	.2263	.0377	.6935	1.3765	1.3426
5	.2452	.2263	.2452	.0377		1.4255	1.3599
6	.2452	.3018	.2452	.0754		1.7166	1.5912
7	.2829	.2452	.2263	.0754	2.13		1.9006
8		.2452	.2829	.0754	2.332	2.7183	2.2611
9		.2452	.3206	.0754	2.4741	2.4366	
10	.2452		.2452		2.1052	2.3371	
11	2.3537		2.431	.2075	.1698	.1698	
12	2.1714		2.5888	.2263	.1509	.1886	
13	2.0056		2.2834	.2263	.1886	.1886	
14	2.1382		2.5396	.2263	.1698	.1698	
15	2.2874		2.4741	.1698	.1886		
16	2.6355		2.6686	.1509	.1886		
17	2.5692			.1886	.1886		
18	2.4413			.1886	.1698	.2075	
19	.2452			.2075	.1886	.2641	
20	.3018		.0566	.2263	.2829	.2829	
21	.2829		.0754	.2263	.2641	.3018	
22	.3018		.0754	.2075	.2452	.2641	
23	.2641		.0566	.1886	.2263	.2452	
24	.2263	.2452	.2452	.0566	.1698	.2075	.2452
Max	2.6355	.3018	2.6686	.2263	2.4741	2.7183	2.2611
Min	.2263	.2263	.0566	.0377	.1509	.1698	.2452
Avg	1.0110	.2414	.8564	.1386	.7367	.8934	1.3677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 203 / 11 KvAshoknagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7204	1.3927	1.4746	.8619	.1886	.2452	.2263
2	1.7204	1.4255	1.5565	.9054	.1886	.2452	.2263
3	1.7204	1.4419	1.5729	1.4251	.1886	.2452	.2075
4	1.7695	1.4582	1.5729	.9389	.2075	.2452	.2075
5	1.8842	1.5729	1.7204	.9556		.2452	.2263
6	2.1879	2.0553	2.1862	1.0774		.2452	.2263
7	2.2211	2.5692	2.0645	1.3435	.2075	.2263	.2075
8	2.4863	2.7349	2.7206	1.6221	.2075	.2263	.2075
9	2.5194	2.5724	2.6397	1.7328	.1886	.1698	
10	2.2119		2.4777	1.8785	.1886	.1698	
11	.1886		.2452	1.5729	1.8351	2.0885	
12	.2075		.1886	1.8187	2.0809	2.3703	
13	.1886			1.6409	1.8947	2.4646	
14	.2263			1.6712	1.7328	1.9725	
15	.2263			1.6244	1.8515	2.1216	
16	.2452			1.2955	1.8187	2.0481	
17	.2263			1.643	2.0388	2.2283	
18	.2452			1.4403	1.873	2.0885	
19	.2829			.132	.2452	.1886	
20	.3395		.2452	.2075	.3018	.2263	
21	.3584		.2452	.2263	.3018	.3018	
22	.3206		.2452	.2263	.2829	.2641	
23	.2829		.2263	.2075	.2641	.2263	
24	.2263	.2641	.2829	.2075	.2075	.2452	.2263
Max	2.5194	2.7349	2.7206	1.8785	2.0809	2.4646	.2263
Min	.1886	.2641	.1886	.132	.1886	.1698	.2075
Avg	1.0003	1.7487	1.2744	1.1106	.8316	.8791	.2179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 204 / railway station Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	.8421	.9175	.5596	.132	.132	.132
2	.8097	.8421	.9503	.5765	.132	.132	.132
3	.8097	.8421	.9503	.5765	.132	.132	.132
4	.9069	.8421	.9503	.57	.132	.132	.132
5	.9393	.8907	.9831	.5868		.132	.132
6	1.2452	1.0814	1.0814	.6554		.1509	.132
7	1.2289	1.2944	1.0688	.8848	.1509	.1509	.1509
8	1.442	1.4419	1.4089	.9831	.132	.1509	.132
9	1.3435	1.2631	1.2308	1.065	.132	.132	
10	1.2289		1.2146	1.1437	.0943	.132	
11	.1132		.1132	1.2616	1.1506	1.1105	
12	.1132		.1132	1.1469	1.1498	1.358	
13	.132			1.1469	1.1822	1.3272	
14	.132			1.0774	1.1984	1.2407	
15	.1132			1.0395	1.1984	1.2763	
16	.1509			.9831	1.1822	1.1603	
17	.1509			1.0277	1.2289	1.2944	
18	.1886			.9717	1.2289	1.2597	
19	.1886		.132	.1132	.1509	.1509	
20	.1698		.132	.1509	.1509	.1698	
21	.1698		.132	.1698	.1698	.1698	
22	.1509		.132	.1509	.1698	.1509	
23	.1509		.1132	.132	.1509	.1509	
24	.1509	.132	.132	.1132	.132	.1509	.132
Max	1.442	1.4419	1.4089	1.2616	1.2289	1.358	.1509
Min	.1132	.132	.1132	.1132	.0943	.132	.132
Avg	.5349	.9472	.6531	.7119	.5219	.5145	.1341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 205 / Malwadi Ag feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.1509	.2263	.1509	1.2826	1.004	.663
2	.2075	.1509	.2075	.1509	1.2483	1.0526	.8048
3	.2075	.1509	.2075	.132	1.3245	1.085	1.1142
4	.2075	.1509	.2263	.132	1.3904	1.1336	1.1336
5	.2263	.1698	.2452	.132		1.1633	1.166
6	.2452	.2263	.2452	.1698		1.4883	1.3927
7	.2263	.2452	.1886	.1886	1.7532	2.1628	1.8947
8		.2263	.2263	.1886	1.8623	2.4697	2.1879
9		.2263	.2829	.2075	1.9204	2.536	
10	.2452		.2452	.2452	1.7976	2.2611	
11	2.2874		2.5857	.3206	.1509	.1698	
12	2.3868		2.6852	.3018	.1698	.2075	
13	2.6023		2.9001	.2641	.1698	.2263	
14	2.556		2.769	.2641	.1886	.2452	
15	2.6355		2.4863	.2829	.1886	.2641	
16	2.7018		2.7349	.3018	.1886	.2263	
17	2.6852		.763	.2829	.1886	.2641	
18	2.4413			.2641	.1886	.2829	
19	.2641		.1886	.2641	.2075	.3018	
20	.2829		.1698	.2263	.2263	.3018	
21	.2829		.1886	.2263	.2075	.2829	
22	.2452		.1509	.2075	.1886	.2641	
23	.1698		.132	.1886	.132	.2263	
24	.1698	.1509	.2263	.132	.1886	.132	.2075
Max	2.7018	.2452	2.9001	.3206	1.9204	2.536	2.1879
Min	.1698	.1509	.132	.132	.132	.132	.2075
Avg	1.0675	.1848	.8818	.2177	.6892	.8230	1.1738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 201 / 11 KV AKKALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.7969	.4049	.6173	.1143	.1334	.1334
2	.9282	.9156	.502		.0953	.1334	.1334
3	.9878	.9831	.7373	.6171	.0953	.1524	.1334
4	1.1174	1.0883	1.278	.6401	.1143	.1524	.1524
5	1.2308	1.2323	1.749	1.1203	.1143	.1905	.1524
6	1.587	1.668	1.7204	1.2955	.1524	.2096	.1905
7	1.8515	1.8884	1.8023	1.5546	.1715	.2286	.2667
8	1.7736	1.668	1.7166		.1715	.2096	.1715
9	1.7604	1.587	1.5074	1.247	.1524	.2096	.1524
10	1.5249	1.4419	1.3123	1.4251	.1715		.1524
11		.1143	.1143		1.2803	1.1523	.1334
12		.1334	.1334	1.5384	1.5061	1.3279	.1143
13		.1524		1.2146	1.3123	1.5061	.1334
14		.1524		1.3108	1.4089	1.3603	.1334
15		.1524		1.3765	1.4575	1.5043	.1334
16	.1524	.1715			1.5364	1.4883	.1524
17	.1905	.1715		1.2289	1.5402	1.6842	.1715
18	.2096	.2096	.1905	1.2289	1.3923	1.4403	.1715
19	.2286	.2286	.2096	.1524	.1334	.1143	.1715
20	.2096	.2286	.2286	.1524	.1524	.1715	.1905
21	.1905	.1905	.1905	.1334	.1524	.1524	.1715
22	.1524	.1524	.1334	.1143	.1524	.1334	.1715
23	.1334	.1334	.1524	.1143	.1334		.1715
24	.1334	.1334	.1524	.1143	.1143	.1334	.1334
Max	1.8515	1.8884	1.8023	1.5546	1.5402	1.6842	.2667
Min	.1334	.1143	.1143	.1143	.0953	.1143	.1143
Avg	.8000	.6497	.7492	.8598	.5677	.6267	.1580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 202 / 11 KV BORGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.5506	1.012	.9686
2	.1905	.1905	.1905		.7287	1.2163	1.0155
3	.2286	.2286	.1905	.2096	.7701	1.3283	1.1385
4	.2286	.2286	.2096	.1905	.8097	1.4575	1.2492
5	.2477	.0572	.2667	.2477	1.4582	1.7444	1.3757
6	.3429	.362	.3048	.3048	2.5263	2.2283	2.0405
7	.3239	.4191	.381	.3429	2.7526	2.672	1.4232
8	.3429	.3429	.4763	.3239	2.6882	2.6882	2.556
9	.3429	.1905	.3048	.3239	2.6543	2.6355	2.5526
10	.3239	.2286	.3048	.3239	2.4486		1.7004
11		2.7526	2.5692	.1905	.2096	.2286	2.2672
12		2.5263	2.9329	.2858		.2096	2.2939
13		2.4291	2.7199	.2667	.1524	.1905	2.2024
14		2.6216	2.7854		.1524	.2096	2.6216
15		2.5749	3.0001	.1143	.1524	.2286	2.4905
16	2.8182	2.672	1.3272		.1905	.2286	2.672
17	2.9165	2.7035	2.1214	.2286	.1905	.2858	2.753
18	1.5061	2.4615	1.8947	.3048	.2286	.2096	2.4905
19	.2858	.3429	.3048	.3429	.3048	.2096	.3239
20	.3429	.3048	.362	.4001	.362	.2858	.3429
21	.2858	.2858	.3048	.362	.2286	.2286	.3429
22	.2286	.2667	.2096	.3239	.1905	.1905	.3239
23	.2096	.2286	.1905	.2858	.1524		.3048
24	.1905	.1905	.2286	.1905	.1143	.1524	.1905
Max	2.9165	2.7526	3.0001	.4001	2.7526	2.6882	2.753
Min	.1905	.0572	.1905	.1143	.1143	.1524	.1905
Avg	.6077	1.0333	.9904	.2740	.8703	.9018	1.5683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 203 / 11 KV BALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2763	.8421	1.2346	.1715	.1715	.1524
2	1.6057		.9393		.1524	.1715	.1524
3	1.8138		1.0322	1.1888	.1524	.1905	.1905
4	2.0081	1.9757	1.1797	1.3123	.1905	.2286	.2096
5	2.2045	2.1464	2.1376	2.2024	.3048	.3048	.2667
6	2.8675	2.7681	2.7035	2.536	.3429	.4382	.4763
7	3.0664	3.2156	2.7854	2.5724		.4191	.381
8	2.7846	2.7854	3.0445	2.5857	.3239	.381	.3429
9	2.7183	1.9757	2.9165	2.556	.2858	.3048	.1905
10	2.2939	2.13	2.7681	2.3482	.2667		.1715
11		.3048	.2667	2.6216	2.8841	2.5396	.3048
12		.2667	.3048	2.4291	2.8182	2.7183	.2667
13		.2858	.3048	2.5587	2.7515	2.5724	.2286
14		.2096	.2667	2.4249	2.6155	2.556	.2477
15		.1905	.3048	2.5263	2.0809	2.652	.2858
16	.2667	.1715	.2477		2.5857	2.1538	.3239
17	.3429	.2286	.1524	2.3758	2.6189	1.3599	.381
18	.381	.2286	.2096	1.9662	2.556	2.2024	.3429
19	.4191	.381	.4382	.2667	.3048	.3239	.3048
20	.4382	.381	.362	.3048	.3048	.3429	.3048
21	.3239	.2667	.3048	.2858	.3048	.2477	.2477
22	.2477	.2286	.2858	.2667	.1905	.1905	.1905
23	.2286	.2286	.2286	.1905	.1715		.1715
24	.1524	.1905	.2096	.1715	.1715	.1715	.1524
Max	3.0664	3.2156	3.0445	2.6216	2.8841	2.7183	.4763
Min	.1524	.1715	.1524	.1715	.1524	.1715	.1524
Avg	1.3424	.9925	1.0098	1.6784	1.0674	1.0291	.2620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 204 / 11 KV AKKALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572		.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	.0572
4	.0572	.0572	.0572	.0572	.0572	.0572	.0572
5	.0572	.0572	.0572	.0762	.0572	.0762	.0572
6	.0953	.0953	.0762	.0953	.0572	.1143	.0762
7	.0572	.0762	.0762	.0572	.0762	.0762	.0762
8	.0572	.0572	.0572	.0572	.0762	.0572	.0572
9	.0572	.0572	.0572	.0572	.0572	.0572	.0572
10	.0572	.0572	.0572	.0572	.0572		.0572
11		.0572	.0572	.0572	.0572	.0572	.0572
12		.0572	.0572	.0572	.0572	.0572	.0572
13		.0572	.0572	.0572	.0572	.0572	.0572
14		.0572	.0572	.0572	.0572	.0572	.0572
15		.0572	.0572	.0572	.0572	.0572	.0572
16	.0762	.0572	.0572		.0572	.0572	.0762
17	.1143	.0572	.0762		.0572	.0762	.0762
18	.1334	.0953	.0762	.0762	.0953	.0762	.0762
19	.1143	.1143	.1143	.1334	.1143	.1334	.0953
20	.1334	.1143	.1334	.1143	.1524	.1524	.1524
21	.0953	.0762	.0762	.0762	.0762	.0762	.1143
22	.0572	.0572	.0572	.0572	.0572	.0572	.0762
23	.0572	.0572	.0572	.0572	.0572		.0572
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.1334	.1143	.1334	.1334	.1524	.1524	.1524
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0762	.0667	.0667	.0681	.0675	.0719	.0699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 205 / 11 KV BORGI BALGAON
GAVTHAN Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0762	.0953	.0762		.0953
2	.0953	.0953	.0762		.0762	.0953	.0953
3	.0953	.0953	.0953	.0762	.0953	.0953	.0953
4	.1334	.1143	.1143	.0953	.0953	.1143	.1143
5	.1524	.1334	.1524	.1524	.1143	.1524	.1524
6	.2096	.2286	.1715	.1905	.1334	.2286	.2096
7	.1715	.2096	.1905	.1524	.1524	.1715	.1715
8	.1524	.1524	.1524	.1143	.1334	.1524	.1524
9	.1143	.1334	.1715	.0953	.1143	.1334	.1334
10	.0953	.1143	.1524	.0953	.1524		.1143
11		.0762	.1524		.1334	.1334	.1143
12		.0953	.1334	.1143	.1143	.1143	.0953
13		.1143	.1334	.1143	.1143	.1143	.0953
14		.1143	.1334		.1143	.1143	.0953
15		.1143	.1524	.0953	.1334	.1334	.1143
16	.1143	.0953	.1143		.1524	.1143	.1334
17	.1524	.1334	.1905	.0953	.1334	.1905	.1524
18	.2096	.1334	.1715	.1715	.1905	.1524	.1715
19	.2096	.1715	.2667		.2477	.2286	.2286
20	.3048	.1715	.2858	.2286	.2286	.2286	.2286
21	.2286	.1334	.1905	.1715	.1905	.1905	.2096
22	.1524	.1143	.1143	.1143	.1524	.1334	.1334
23	.1143	.0953	.1143	.0953	.1143		.0953
24	.0953	.0953	.0953	.0953	.0762	.0953	.0953
Max	.3048	.2286	.2858	.2286	.2477	.2286	.2286
Min	.0953	.0762	.0762	.0762	.0762	.0953	.0953
Avg	.1524	.1262	.1500	.1244	.1350	.1470	.1374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 201 / 11 KV SUSLAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		1.4403	1.7695
2		1.7604	2.0729
3		1.7604	2.3594
4		2.2672	2.3685
5		2.5911	2.4905
6		2.753	2.5587
7		2.7044	2.7526
8		2.6543	2.7046
9	2.8349	2.5286	
10	2.713	2.1399	
11		.4066	
12		.2801	
13		.16	
14		.2317	
15		.2172	
16		.2572	
17	.4755	.2824	
18	.2976	.2934	
19	.4481	.3121	
20	.4854	.3227	
21	.5228	.2972	
22	.5228	.3418	
23	.3734		
24		.3048	.3567
Max	2.8349	2.753	2.7526
Min	.2976	.16	.3567
Avg	.9637	1.1438	2.1593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 202 / 11 KV UMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3734	.3439		.3292	.3109
2		.2865	.3841	.3582		.3439	.3547
3		.3224	.4066	.3155		.3881	.3772
4		.3898	.3696	.3544		.3734	.3547
5		.3582	.3547	.3761		.3841	.3961
6		.394	.3841	.2587		.3982	.3696
7		.3582	.4344	.4031		.3841	.3841
8		.3801	.3506	.3506		.3721	.3439
9	.3403	.3121	.3641		.3121	.3582	
10	.3224	.3185	.3294		.3506	.3294	
11		.333	.3429		.3366	.2658	
12		.333	.3403		.3086	.3403	
13		.3142	.3544		.3155	.3155	
14		.3475	.3077		.3294	.3403	
15		.3045	.3012		.3045	.298	
16	.3582	.3189	.2947		.2835	.3086	
17	.4031	.3391	.3814		.285	.3506	
18	.3761	.3841	.3467		.2622	.3258	
19	.4656	.3511	.3982		.4024	.3801	
20	.4656	.3326	.4656		.4477	.4031	
21	.4119	.3326	.3696		.3801	.439	
22	.4298	.3982	.3292		.3658	.3921	
23	.3224	.3658	.2587		.3326	.3326	
24		.2896	.3511	.3292		.2926	.2896
Max	.4656	.3982	.4656	.4031	.4477	.439	.3961
Min	.3224	.2865	.2587	.2587	.2622	.2658	.2896
Avg	.3895	.3419	.3580	.3433	.3344	.3519	.3534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 203 / 11 KV SONALGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0829	1.0974	.7947		2.1125	1.6804
2		1.0456	1.1041	.8215		2.1879	1.8947
3		1.0829	1.134	.8501		2.4249	2.4249
4		1.0829	1.1203	.8589		2.6825	2.5857
5		1.0456	1.2071	.8962		2.7854	2.6216
6		1.0498	1.2323	.8775		2.9001	2.8502
7		1.0829	1.3443	1.1203		3.0514	3.0333
8		1.0829	1.2197	1.1203		3.083	3.219
9	.8817	.7842	2.0328		2.7199	2.1628	
10	.852	.6348	.3658		2.8675	1.8138	
11		2.7349	2.7183			.6161	
12		3.1017	3.3065		.6099	.7356	
13		2.4249	2.8178		.9054	.8131	
14		2.304	2.9172		.9709	.8962	
15		2.2131	2.8178		1.0751	.9997	
16		2.1136	2.343		1.1203	1.0456	
17	2.3975	2.8837	2.7515		1.226	1.134	
18	2.7515	1.0974	2.4086		1.251	1.2323	
19	1.1706	1.0498	.7316		1.2826	1.1883	
20	1.1949	1.0242	.8962		1.2323	1.1458	
21	1.1203	1.0164	.5975		1.0562	1.1203	
22	1.0456	1.0082			.9808	1.0562	
23	1.0829	1.0059	.2033		.8501	.8871	
24		1.0719	1.0719	.7468		.5788	.7842
Max	2.7515	3.1017	3.3065	1.1203	2.8675	3.083	3.219
Min	.852	.6348	.2033	.7468	.6099	.5788	.7842
Avg	1.3886	1.4593	1.6278	.8985	1.2963	1.6106	2.3438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 204 / 11 KV UMADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2498	1.0526	.9717		2.2801	1.5729
2		1.2803	1.0526	1.0774		2.4697	1.9559
3		1.3765	.1677	1.166		2.7854	2.1052
4		1.3765	1.2929	1.1469		3.152	2.9165
5		1.4575	1.3748	1.1843		3.2819	3.514
6		1.4575	1.4918	1.3763		3.6549	3.7891
7		1.1523	1.166	1.2146		3.8058	3.7792
8		1.2452	1.1469	.8097		3.8455	3.7388
9	1.1469	1.2631	1.004		3.6549	3.5303	
10	1.1797	1.1523	3.9903		3.5471	3.3608	
11		3.9449	3.8058		1.278	.8322	
12		3.9615	3.7685		1.0722	.9393	
13		3.6374			1.0814	1.0562	
14		3.8542	3.7891		1.0526	1.1174	
15		3.8832	3.9567		1.1797	1.2452	
16		3.9118	3.0769		1.2323	1.2963	
17	2.9127	3.8561	3.5063		1.2452	1.3927	
18	3.315	1.0486	3.3097		1.1984	1.4083	
19	1.3765	.9717	1.0402		1.2929	1.2944	
20	1.1336	.9922	1.1336		1.4251	1.3123	
21	1.1984	.9878	.8962		1.1797	1.2631	
22	1.3283	1.004			1.0111	1.0159	
23	1.2803	1.004	.7287		.9667	.8962	
24		1.2498	.9831	1.1203		.9069	.8583
Max	3.315	3.9615	3.9903	1.3763	3.6549	3.8455	3.7891
Min	1.1336	.9717	.1677	.8097	.9667	.8322	.8583
Avg	1.6524	1.9716	1.9879	1.1186	1.4945	2.0060	2.6922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 205 / 11 KV SUSLAD GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0732	.0747	.0934		.0934	.0366
2		.0732	.0943	.0732		.0739	.037
3		.0914	.112	.0934		.056	.0566
4		.112	.0934	.1109		.0566	.0747
5		.128	.0934	.0914		.0747	.0943
6			.128	.1294		.0943	.0739
7		.1097	.1214	.104		.112	.0754
8		.0895	.0701	.0924		.0943	.056
9	.0995	.0655	.08		.1097	.0983	
10	.0829	.0972	.096		.0701	.128	
11		.0972	.0886		.0914	.08	
12		.0983	.0716		.0625	.0753	
13		.0655	.0886			.0892	
14		.0914	.0905		.0693	.0838	
15		.1086	.0554		.0895	.0686	
16	.1075	.1402	.0686		.0671	.0848	
17	.0914	.0995	.1341		.1017	.1134	
18	.1463	.0914	.1174		.1134	.1265	
19	.144	.0724	.1296		.1402	.128	
20	.144	.0549	.156		.2103	.112	
21	.112	.0747	.1086		.128	.1294	
22	.096	.0934	.0914		.112	.0943	
23	.096	.0732	.0739		.0943	.0739	
24		.0914	.0924	.0754		.0739	.056
Max	.1463	.1402	.156	.1294	.2103	.1294	.0943
Min	.0829	.0549	.0554	.0732	.0625	.056	.0366
Avg	.1120	.0909	.0971	.0959	.1043	.0923	.0623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 201 / 11 KV MADGYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6154			.2012	.1848	.2033
2	.6401	.6478			.2012	.1848	.2033
3	.6401	.6478			.2195	.1848	.2033
4	.8802	.8097			.2195	.2195	.2195
5	1.4575	.9717	.7865		.2772	.2561	.2926
6	1.9204	1.4403	1.8842		.4805	.4706	.4755
7	2.2939	2.2939	2.4806		.4066	.4755	.4755
8	2.0243	1.9433	1.9662		.3326	.3326	.3292
9	1.8623	1.7004	1.9062		.2957	.2772	.2561
10	.8097	1.6194	1.6194	1.3413	.2772	.2926	
11	.1829	.2926	.1646	1.2146	1.7814	1.7814	.2012
12	.1829		.1646	1.2955	1.6194	1.7004	
13	.1829	.2987	.1646		1.5384	1.6194	
14	.1848	.2743	.1848	1.1336	1.587	1.6194	.2743
15	.1663	.2601	.1848	1.3765	1.6194	1.6194	.3361
16	.1848	.2715	.2263		1.7814	1.6194	.3658
17	.1663	.2561	.2172	1.7004	1.5384	1.7814	.4435
18		.3898	.2172	1.4575	1.7004	.8097	.439
19	.2772	.394	.2686	.2926	.2743	.2715	.4656
20	.3326	.4066	.1629	.3696	.3734	.3292	.4525
21	.3326	.3292	.1629	.3142	.3142	.2896	.4298
22	.2218	.2715		.2772	.2772	.2534	.4024
23	.1848	.2534		.2402	.2218	.2195	.3658
24	.2218	.1663	.1848		.2012	.1848	.2033
Max	2.2939	2.2939	2.4806	1.7004	1.7814	1.7814	.4755
Min	.1663	.1663	.1629	.2402	.2012	.1848	.2012
Avg	.6952	.7197	.7192	.9178	.7391	.7074	.3351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 202 / 11 KV SONYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0312	.0312	.0324	.0324	.1829	.1898	.1943
2	.0312	.0312	.0324	.0324	.2286	.2401	.2429
3	.0312	.0312	.0324	.0324	.2286	.2401	.2591
4	.0312	.0316	.0324	.0324	.2743	.2561	.2591
5	.0633	.0316	.0328	.0486	.3048	.3201	.2949
6	.0655	.0655	.0492	.0972	.5376	.4374	.4001
7	.08	.0648	.064	.0474	.6249	.6478	.5121
8	.048	.064	.064	.048	.4858	.4687	.3963
9	.0469	.0474	.048	.048	.4012	.3048	.3269
10	.0486	.0474	.0469	.0486	.4161	.2896	
11	.4877	.578	.5693	.0497	.048	.0463	.3479
12	.4633	.5335	.5693	.048	.048	.0457	.3125
13	.4512	.4755	.5693	.032	.032	.0446	.2743
14	.4633	.4515	.5535	.0309	.0312	.0457	.3395
15	.4877	.4515	.5335	.0312	.0312	.0457	.4268
16	.5155	.4877	.4572		.0312	.0474	.4268
17	.5535	.5312	.4572	.0486	.0312	.0474	.4515
18	.4458	.4633	.381	.0474	.0474	.0446	.4572
19	.0312	.048	.0486	.0474	.0633	.0469	.0625
20	.0474	.0486	.0469	.0474	.0492	.0486	.0937
21	.0474	.0486	.0305	.0312	.048	.0486	.0949
22	.0312	.0324	.0305	.0312	.0316	.0324	.0791
23	.0312	.0305		.0316	.0316	.0316	.0633
24	.0305	.0312	.0316	.0316	.0316	.0316	.0309
Max	.5535	.578	.5693	.0972	.6249	.6478	.5121
Min	.0305	.0305	.0305	.0309	.0312	.0316	.0309
Avg	.1902	.1941	.2049	.0424	.1767	.1667	.2759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 203 / 11 KV UTAGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1783	.2606	.2705	.3048	.0282	.0324	.0297
2	.192	.2667	.2705	.3048	.0297	.0324	.0297
3	.2195	.2743	.2667		.0297	.0324	.0297
4	.2743	.2743	.2667	.3048	.0457	.0486	.0305
5	.4633	.3525	.3384	.381	.0469	.0648	.048
6	.6097	.6241	.6859	.6097	.2458	.1638	.1966
7	.7202	.7316	.6001	.6859	.1457	.1311	.1311
8	.5357	.5944	.5639	.6097	.1134	.096	.1134
9	.4268	.362	.5213	.5335	.096	.0648	.0972
10	.3948	.3841	.4268	.4572	.543	.0457	
11	.0446	.061	.0469	.3048	.543	.4934	.048
12	.0423	.061	.0457	.3048	.439	.4512	.0474
13	.04	.0579	.0457	.3048	.3841	.3841	.064
14	.029	.0594	.0457	.3353	.3567	.3841	.0469
15	.029	.0602	.0457	.3048	.3201	.3567	.0457
16	.0457	.0617	.0457		.4115	.4001	.0617
17	.0633	.048	.0457	.4512	.4801	.4801	.0781
18	.0791	.0926		.3201	.4668		.08
19	.128	.1296	.0972	.081	.0983	.0972	.1296
20	.1107	.1296	.0625	.0819	.1147	.0983	.1265
21	.0781	.096	.0625	.0762	.081	.0648	.125
22	.0463	.048	.0423	.0412	.048	.048	.0762
23	.0457	.0267		.0434	.0297	.0305	.0417
24	.029	.0457	.0271	.0305	.0446	.0297	.029
Max	.7202	.7316	.6859	.6859	.543	.4934	.1966
Min	.029	.0267	.0271	.0305	.0282	.0297	.029
Avg	.2011	.2126	.2193	.3123	.2142	.1752	.0742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 204 / 11 KV SONYAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.112	.1109	.1132	.0924	.0924	.0924
2	.1294	.112	.1109	.1132	.0924	.0924	.0924
3	.1307	.112	.112	.1132	.0924	.0924	.0924
4	.1307	.132	.112	.1132	.1109	.1109	.1109
5	.1867	.1698	.1509	.1509	.1478	.1294	.1294
6	.3018	.2452	.2829	.2829	.2987	.2402	.1663
7	.2427	.2427	.1494	.2195	.2402	.2378	.1848
8	.2054	.2033	.1294	.1463	.1848	.1848	.1478
9	.1663	.1448	.0732	.1097	.1463	.1478	.1478
10	.1478	.1097	.1433	.1097	.128	.1109	
11	.1448	.1254	.1448	.1254	.1097	.1075	.1494
12	.1254	.1052	.1463	.1254	.1097	.1097	.1109
13	.1052	.0886	.128	.1294	.0914	.1097	.1075
14	.1063	.0905	.128	.1109	.0924	.1097	.1086
15	.1075	.1075	.128	.1109	.0924	.1097	.1097
16	.1086	.1075	.128		.1294	.0716	.1075
17	.1267	.1402	.128	.1372	.1294	.1463	.1402
18	.1578	.1991	.1463	.1829	.1463	.1715	.1715
19	.2481	.2353	.2195	.2561	.2033	.2218	.2658
20	.2743	.2957	.2743	.2587	.2587	.2957	.2743
21	.2402	.2218	.2195	.1848	.2033	.1848	.2715
22	.1478	.1663	.128	.1294	.1478	.1294	
23	.112	.1294		.1109	.1109	.1109	.128
24	.1267	.112	.1109	.1109	.1109	.0924	.0924
Max	.3018	.2957	.2829	.2829	.2987	.2957	.2743
Min	.1052	.0886	.0732	.1097	.0914	.0716	.0924
Avg	.1625	.1545	.1480	.1498	.1446	.1421	.1455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 205 / 11 KV UTAGI VHASPETH

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /

OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0732	.1109	.0943	.037	.0924	.0739
2	.0914	.0732	.1097	.0943	.0924	.0924	.0739
3	.0914	.0732	.1086	.0943	.0914	.0924	.0739
4	.0914	.0924	.1109	.0943	.0914	.0914	.0739
5	.1109	.0924	.1109	.1132	.0914	.0914	.0739
6		.1294	.1478	.1886	.2033	.0914	.0554
7	.1097	.1109	.1097		.1478	.0914	.1109
8	.128	.1294	.1109		.1478	.1294	.1109
9	.128	.1663	.0924		.1478	.1294	.0924
10	.1494	.1478	.1478	.1478	.1848	.1294	
11	.1478	.1734	.1097	.1294	.1478	.1109	.1109
12	.1663		.1463		.1294	.1463	
13	.1646	.1402	.1829		.0924	.1646	
14	.1848	.1463	.1463	.1294	.1478	.1294	.1463
15	.1848	.1612	.1463	.1294	.2033	.1109	.2172
16	.1646	.1629	.1052		.2033	.1109	.1829
17	.1294	.1772	.1254	.1848	.2033	.1294	.1448
18	.1294	.1753		.1848	.2218	.1109	.1646
19	.1478	.1612	.1097	.1663	.2033	.1448	.1867
20	.1478	.2033	.1097	.1663	.2241	.1663	.1867
21	.1294	.1848	.112	.1478	.1848	.1463	.2075
22	.1109	.1663	.112	.1109	.1478	.1097	.1509
23	.0924	.1097		.1109	.1294	.0924	.132
24	.0914	.0732	.1109	.0943	.0924	.1109	.0739
Max	.1848	.2033	.1829	.1886	.2241	.1663	.2172
Min	.0914	.0732	.0924	.0943	.037	.0914	.0554
Avg	.1297	.1358	.1216	.1323	.1486	.1173	.1259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 207 / 11 KV JADAR BOBALAD AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3326	.3142	.2458	.945	.9602	.9717
2	.3292	.3326	.3142	.2543	1.0669	1.1203	1.1336
3	.3326	.3326	.3142	.2543	1.1431	1.1203	1.1336
4	.3696	.3361	.3142	.3052	1.2193	1.2003	1.2146
5	.5601	.3734	.3361	.4144	1.3717	1.3765	1.2955
6	.5601	.6535	.6535	.4973	2.2939	2.1862	2.0243
7	.6535	.7468	.6535	.4973	2.5101	1.7604	2.2672
8	.5175	.4805	.5175	.4973	2.1862	1.6194	2.1052
9	.4066	.3658	.4024	.4973	2.0243	1.8623	1.8623
10	.4805	.3292	.3696	.4641	1.7604	1.7814	
11	2.2672	2.1214	2.0243	.2561	.2957	.2686	1.4575
12	2.0309	1.9766	1.9662	.3292	.3326	.2743	1.406
13	1.9052	1.8056	1.9062	.3326	.3696	.2772	1.4661
14	1.8747	1.7966	2.0719	.3142	.3696	.3142	1.5497
15	1.7966	1.7185	2.0719	.3326	.3696	.3734	1.5935
16	1.9204	1.8976	1.6575		.4066	.3696	1.7185
17	2.2939	2.2672	1.9062	.4805	.4805	.4755	1.8747
18	1.9528	2.0809	1.4918	.5175	.6283	.4024	1.7497
19	.4435	.6099	.431	.5175	.6283	.4805	.6722
20	.4066	.5601	.431	.3696	.4805	.4805	.6535
21	.3696	.4854	.431	.3696	.4251	.3696	.5914
22	.3326	.3696	.431	.3326	.3734	.2957	.5601
23	.3326	.3658		.2957	.3326	.2743	.4805
24	.3292	.3326	.3109	.2458	.2772	.3142	.2561
Max	2.2939	2.2672	2.0719	.5175	2.5101	2.1862	2.2672
Min	.3292	.3292	.3109	.2458	.2772	.2686	.2561
Avg	.9498	.9446	.9270	.3748	.9288	.8316	1.3060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 201 / 11 KV SIDHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.1469	1.1469	1.1469	.1638	.1638	.1638
2	1.4746	1.3108	1.3108	1.1469	.1638	.1638	.1638
3	1.4746	1.6385	1.6385	1.3108	.1638	.1638	.1638
4	1.4746	1.6385	1.6385	1.4746	.1638	.1638	.1638
5	1.9662	1.8023	1.9662	1.4746	.1638	.1638	.2458
6	2.13	1.9662	1.9662	1.6385	.2458	.1638	.3277
7	2.2119	2.2939	2.4577	1.8023	.2458	.1638	.3277
8	1.9662	2.13	2.4577	1.8842	.1638	.1638	.3277
9	1.6385	1.9662	2.2939	1.9662	.1638	.1638	.2458
10	1.8023		2.2939	2.0481	.1638	.1638	.2458
11	.1638		.1638	1.4746	1.4746	1.8023	.1638
12	.1638		.1638	1.7204	1.6385	2.13	.2458
13	.1638		.1638	1.7204	2.0481	2.13	.2458
14	.2458		.1638	1.8842	2.13	2.2939	.2458
15	.2458	.1638	.1638	1.8842	2.13	2.2939	.2458
16	.2458	.1638	.1638		2.13	2.2939	.2458
17	.2458	.1638	.1638	.7373	2.13	2.13	.2458
18	.3277	.2458	.1638		1.8023	2.13	.2458
19	.3277	.2458	.1638	.1638	.1638	.1638	.2458
20	.3277	.2458	.1638	.1638	.1638	.2458	.3277
21	.2458	.2458	.1638	.1638	.1638	.2829	.3277
22	.1638	.1638	.1638	.1638	.1638	.2458	.3277
23	.1638	.1638	.1638	.1638	.1638	.1638	.2458
24	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Max	2.2119	2.2939	2.4577	2.0481	2.13	2.2939	.3277
Min	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Avg	.8670	.9400	.8943	1.1953	.7612	.8378	.2458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 202 / 11 KV DARIKONUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0819	.0819	.0819	.2458	.3277	.4915
2	.0819	.0819	.0819	.0819	.2458	.3277	.4915
3		.0819	.0819	.0819	.3277	.3277	.4915
4		.0819	.0819	.0819	.3277	.3277	.4915
5	.0819	.0819	.0819	.0819	.3277	.6554	.4915
6	.1696	.1638	.1638	.0819	.8192	.9831	.6554
7	.1638	.1638	.1638	.0819	1.3108	1.1469	.8192
8	.1638	.0819	.1638	.0819	.8192	1.1469	1.1469
9	.1638	.0819	.1638	.0819	.8192	.9831	1.1469
10	.0819	.0819	.0819	.0819	.8192	.3277	.9831
11	.9831	.8192	.8192	.0819	.0819	.0819	.8478
12	.9831	.9831	.9831	.0819	.0819	.0819	.8192
13	.9831	.9831	.9831	.0819	.0819	.0819	.8192
14	.9831	1.0174	.9831	.0819	.0819	.0819	.8192
15	.9831	1.0174	1.1469	.0819	.0819	.0819	.8478
16	.9831	.9831	.9831		.0819	.0819	.9831
17	.9831	.9831	.9831	.0819	.0819	.0819	1.1469
18	.9831	.8192	.3277	.0819	.0819	.0819	.9831
19	.0819	.1638	.1638	.1638	.1638	.0819	.0819
20	.1638	.1638	.1638	.1638	.1638	.1638	.1638
21	.1638	.1638	.1638	.1638	.1638	.1638	.1638
22	.1638	.1638	.1638	.1638	.1638	.1638	.1638
23	.0819	.0819	.0819	.0819	.1638	.0819	.0848
24	.0819	.0819	.0819	.0819	.0819	.0819	.0819
Max	.9831	1.0174	1.1469	.1638	1.3108	1.1469	1.1469
Min	.0819	.0819	.0819	.0819	.0819	.0819	.0819
Avg	.4528	.3920	.3823	.0961	.3174	.3311	.6340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 203 / 11 KV SHEDYAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0943	.0566	.0566	.0566	.0566
6	.0754	.0566	.0943	.0943	.0754	.0566	.0943
7	.0754	.0566	.0943	.0943	.0754	.0566	.0943
8	.0754	.0566	.0943	.0566	.0754	.0566	.0754
9	.0754	.0566	.0566	.0566	.0754	.0566	.0509
10	.0754	.0566	.0566	.0566	.0566	.0566	.0509
11	.0566	.0566	.0566	.0566	.0566	.0566	.0566
12	.0566	.0566	.0566	.0566	.0566	.0566	.0754
13	.0566	.0754	.0566	.0566	.0566	.0566	.0754
14	.0566	.0566	.0566	.0566	.0566	.0566	.0754
15	.0566	.0566	.0566	.0566	.0566	.0566	.0566
16	.0566	.0566	.0566		.0566	.0566	.0566
17	.0566	.0566	.0943	.0566	.0566	.0566	.0566
18	.0943	.0566	.0943	.0566	.0943	.0566	.0566
19	.0943	.0943	.0943	.0943	.0943	.0754	.0754
20	.0943	.0943	.0943	.0943	.0943	.1132	.1132
21	.0943	.0943	.0943	.0943	.0943	.1132	.1132
22	.0943	.0943	.0943	.0943	.0943	.0943	.0943
23	.0566	.0943	.0566	.0566	.0566	.0754	.0754
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.0943	.0943	.0943	.0943	.0943	.1132	.1132
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0509
Avg	.0684	.0652	.0723	.0664	.0676	.0645	.0703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 204 / 11 KV SHEDYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.1696	.0848		.3391	.3391	.6783
2	.0848	.1696	.0848		.3391	.5087	.6783
3	.0848	.1696	.0848		.3391	.5087	.6783
4	.0848	.1696	.0848		.5087	.5087	.6783
5	.1696	.1696	.1696		.5087	.8478	.8478
6	.1696	.1696	.1696		.6783	1.3565	1.1869
7	.1696	.1696	.1696		.8478	1.5261	1.5261
8	.0848	.1696	.1696		.9326	1.5261	1.5261
9	.0848	.1696	.1696		.9326	1.3565	1.3565
10	.0848	.1696	.1696		.9326	.5087	1.3565
11	1.1869	1.1869	1.2717	.1696	.0848	.0848	.9326
12	1.3565	1.3565	1.3565	.0848	.0848	.0848	1.0174
13	1.3565	1.3565	1.3565	.0848	.0848	.0848	.9326
14	1.3565	1.3565	1.3565	.0848	.0848	.0848	1.1869
15	1.3565	1.3565	1.5261	.0848	.0848	.0848	1.1869
16	1.3565	1.5261	1.3565		.0848	.0819	1.3565
17	1.5261	1.5261	1.1869	.0848	.0848	.0848	1.3565
18	1.1869	1.3565		.0848	.0848	.0848	1.1869
19	.1696	.1696		.1696	.1696	.0848	.0848
20	.1696	.1696		.1696	.1696	.1696	.1696
21	.1696	.1696		.1696	.1696	.1696	.1696
22	.1696	.1696		.1696	.1696	.1696	.1696
23	.1696	.0848		.0848	.1696	.1696	.1696
24	.0848	.1696	.0848		.0848	.1696	.1696
Max	1.5261	1.5261	1.5261	.1696	.9326	1.5261	1.5261
Min	.0848	.0848	.0848	.0848	.0848	.0819	.0848
Avg	.5299	.5688	.6029	.1201	.3321	.4415	.8584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 205 / 11 KV DARIKONUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0566	.0566	.0566	.0566	.0754	.0566	.0566
7	.0566	.0566	.0566	.0566	.0754	.0566	.0566
8	.0566	.0566	.0566	.0566	.0754	.0566	.0566
9	.0566	.0566	.0566	.0566	.0754	.0566	.0566
10	.0566	.0566	.0566	.0566	.0566	.0566	.0566
11	.0566	.0566	.0566	.0566	.0566	.0566	.0566
12	.0566	.0566	.0566	.0566	.0566	.0566	.0566
13	.0566	.0566	.0566	.0566	.0566	.0566	.0566
14	.0566	.0566	.0566	.0566	.0566	.0566	.0566
15	.0566	.0566	.0566	.0566	.1132	.0566	.0566
16	.0566	.0566	.0566		.0566	.0566	.0566
17	.0566	.0566	.0566	.0566	.0566	.0566	.0566
18	.0943	.0566	.0943	.0566	.0943	.0566	.0566
19	.0943	.0943	.0943	.0943	.0943	.0754	.0566
20	.0943	.0943	.0943	.0943	.0943	.0943	.1132
21	.0943	.0943	.0943		.0943	.0943	.1132
22	.0943	.0943	.0566		.0943	.0754	.0754
23	.0566	.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.0943	.0943	.0943	.0943	.1132	.0943	.1132
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.0645	.0629	.0629	.0602	.0699	.0613	.0621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 206 / 11 KV SIDDHANATH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.0754	.0943	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0754	.0754	.0754	.0754	.0754
4	.0754	.0754	.0943	.0754	.0754	.0754	.0754
5	.0754	.0754	.0943	.0754	.0754	.0754	.0754
6	.0943	.0754	.1132	.0754	.0943	.0754	.0943
7	.0943	.0754	.1132	.0754	.0943	.0754	.0943
8	.0943	.0754	.1132	.0754	.0943	.0754	.0943
9		.0754	.0943	.0754	.0943	.0754	.0943
10		.0754	.0943	.0754	.0754	.0754	.0943
11		.0754	.0943	.0754	.0754	.0754	.0754
12		.0754	.0754	.0754	.0754	.0754	.2458
13	.0754	.0754	.0754	.0754	.0754	.0754	.2458
14	.0754	.0754	.0754	.0754	.0754	.0754	.2458
15	.0754	.0754	.0754	.0754	.0754	.0754	.2458
16	.0754	.0754	.1132		.0754	.0754	.2458
17	.0754	.1132	.1132	.0754	.0754	.0943	.2458
18	.0943	.1132	.1132	.0754	.0943	.0943	.2458
19	.132	.1132	.1132	.132	.132	.0943	.2458
20	.1509	.132	.1509	.132	.1509	.1509	.132
21	.1509	.132	.1509	.132	.1509	.1509	.132
22	.132	.132	.132	.132	.0943	.132	.1132
23	.0943	.0754	.0943	.0754	.0943	.1132	.0754
24	.0754	.0943	.0754	.0943	.0754	.0943	.0754
Max	.1509	.132	.1509	.132	.1509	.1509	.2458
Min	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Avg	.0933	.0888	.0998	.0869	.0896	.0888	.1424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 207 / 11 KV DARIBADCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3565	1.3565	1.3565	.2543	.2543	.3391
2	1.5261	1.6956	1.3565	1.3565	.2543	.2543	.3391
3	1.5261	1.6956	1.6956	1.5261	.2543	.2543	.3391
4		1.6956	1.8652	1.5261	.2543	.2543	.3391
5	2.5434	1.8652	1.6956	2.0348	.2543	.3391	.3277
6	2.8826	2.0348	1.6956	2.0348	.4239	.4239	.5087
7	2.9673	2.5434	2.5434	2.6282	.4239	.4239	.5087
8	2.5434	2.3739	2.3739	2.4587	.4239	.4239	.5935
9	2.3739	2.2043	2.3739	2.4587	.3391	.3391	.5935
10	2.3739	2.2043	2.3739	2.2043	.3391	.2543	.5087
11	.3391	.3391	.3391	1.8652	1.6956	1.8652	.4239
12	.3391	.3391	.3391	2.2043	1.6956	2.3739	.4239
13	.3391	.3391	.3391	1.8652	2.0348	2.5434	.4239
14	.3391		.3391	2.2891		2.713	.4239
15	.3391	.3391	.3391	2.2891	2.0348	2.713	.4239
16	.3391	.3391	.3391		1.7804	2.713	.4239
17	.3391	.3391	.3391	.6783	1.7804	2.5434	.4239
18	.3391	.4239	.2543	.763	1.6956	2.3739	.4239
19	.4239	.4239	.3391	.4239	.1696	.3391	.4239
20	.4239	.4239	.4239	.4239	.2543	.4239	.5087
21	.3391	.4239	.4239	.4239	.2543	.4239	.5087
22	.3391	.3391	.3391	.4239	.2543	.4239	.4239
23	.3391	.3391	.3391	.3391	.2543	.4239	.3391
24	.4239	.3391	.3391	.3391	.3391	.2543	.3391
Max	2.9673	2.5434	2.5434	2.6282	2.0348	2.713	.5935
Min	.3391	.3391	.2543	.3391	.1696	.2543	.3277
Avg	1.0790	1.0616	1.0068	1.4745	.7593	1.0562	.4305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 208 / 11 KV MUCHANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1696	.1696	.1696	.6783	.6783	1.0174
2	.1696	.1696	.1696	.1696	.6783	.6783	1.0174
3	.1696	.1696	.1696	.1696	.6783	.6783	1.0174
4	.1696	.1696	.1696	.1696	.8478	.8478	1.1869
5	.2543	.1696	.1696	.1696	.8478	1.0174	1.6956
6	.2543	.0848	.2543	.1696	1.6956	1.8652	1.8652
7	.2543	.0848	.2543	.1696	1.95	2.2043	1.8652
8	.2543	.3391	.1696	.1696	1.6956	2.2043	1.95
9	.2543	.3391	.1696	.2543	1.6956	2.0348	1.95
10	.1696	.2543	.1696	.2543	.1696	.8478	1.8652
11	2.2043	2.0348	2.2891	.2543	.1696	.1696	1.3565
12	2.2043	2.3739	2.3739	.2543	.1696	.1696	1.5261
13	2.2043	2.3739	2.2043	.2543	.1696	.1696	1.5261
14	2.0348	2.3739	2.2043	.2543	.1696	.1696	1.6956
15	2.0348		2.0348	.2543	.1696	.1696	1.8652
16	2.0348	2.3739	2.0348		.1638	.1696	2.0348
17	2.2043	2.2891	1.6956	.1696	.1638	.1638	1.8652
18	1.8652	2.2891	1.5261		.1696	.1696	1.6956
19	.2543	.1696	.1696	.1696	.1696	.1696	.1696
20	.2543	.2543	.2543	.1696	.1696	.2543	.1696
21	.2543	.2543	.2543	.1696	.1696	.2543	.1696
22	.1696	.1696	.1696	.1696	.1696	.2543	.1696
23	.1696	.1696	.1696	.1696	.1696	.1696	.1696
24	.1696	.1696	.1696	.1696	.1696	.1696	.1696
Max	2.2043	2.3739	2.3739	.2543	1.95	2.2043	2.0348
Min	.1696	.0848	.1696	.1696	.1638	.1638	.1696
Avg	.8408	.8368	.8090	.1966	.5542	.6533	1.2505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 202 / 11 KV KONTEBOBLAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3814	.3641	.3814	.2774	.9496	.9835	.9945
2	.3429	.3429	.3429	.2804	1.2574	1.2887	1.2597
3	.3429	.3429	.3429	.3155	1.3413	1.358	1.3413
4	.3988	.3561	.3814	.3814	1.5083	1.5424	1.3923
5	.4409	.407	.4239	.4115	1.6741	1.6741	1.5912
6	.5365	.5365	.5365	.4694	2.556	2.4034	2.2939
7	.5365	.3688	.4748	.4694	3.2442	3.0312	2.7526
8	.503	.3812	.5365	.4748	3.0312	2.7035	1.8564
9	.407	.3978	.503	.4694	2.8837	1.3108	2.3205
10	.4694	.4024	.4748	.3856	2.5484	1.9227	2.3868
11	2.5484	2.5857	2.4905	.3856	.3521	.2883	2.2131
12	2.8837	2.7526	2.7846	.4359	.3688	.3353	2.4034
13		2.7526	2.3205		.1865	.3688	2.1216
14	1.8564	2.7183	2.3205		.2683	.3688	2.3758
15		2.7526	2.6216	.2713	.3018	.3688	1.9662
16		2.9492	1.6095		.2818	.2543	2.6216
17	2.9492	2.9172		.2743	.2652	.4024	2.4531
18	2.7035	2.6216	1.7901	.2743	.2984	.3391	2.1879
19	.3511	.3361	.3734	.3696	.4435	.4108	.3326
20	.4755	.4435	.3734	.4481	.439	.4805	.4066
21	.4805	.5121	.4108	.3361	.2772	.4805	.4435
22	.4805	.5121	.4066	.3326	.2402	.4435	.3921
23	.4066	.4668	.3696	.2957	.2054	.3734	.3734
24	.4066	.3881	.4108	.2987	.2987	.2054	.3734
Max	2.9492	2.9492	2.7846	.4748	3.2442	3.0312	2.7526
Min	.3429	.3361	.3429	.2713	.1865	.2054	.3326
Avg	.9477	1.1920	.9861	.3646	1.0509	.9724	1.6189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 203 / 11 KV PANDOZARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083	1.4403	1.4752	1.2039	.3294	.4161	.4578
2	1.4918	1.5927	1.643	1.326	.3294	.4161	.4334
3	1.5415	1.8442	1.7939	1.326	.3429	.4287	.4115
4	1.8107	2.0454	1.8399	1.643	.3429	.4801	.4239
5	1.989	2.1879	1.9826	1.7736	.3641	.5426	.4801
6	2.5069	2.7183	2.6543	2.0972	.5935	.6874	.6443
7	2.3205	2.3758	2.6073	2.4413	.6539	.7377	.763
8	2.6379	2.0645	2.9001	2.4086	.5533	.6443	.4359
9	1.4419	2.3266	2.7199	2.4577	.4694	.6274	.5868
10	1.8233	1.4918	2.6023	2.4413	.4578	.5256	.6036
11	.4191	.4578	.4191	1.9062	2.2891	2.2542	.6203
12		.5087	.5087	2.1382	2.5484	2.4366	.57
13	.431	.5197	.4973	2.1795	2.431	2.4577	.4694
14	.4694	.5256	.6001	2.0809	2.2874	2.3205	.5426
15		.5365	.6068	1.9498	1.326	2.3205	.57
16		.5596	.2204		2.1628	2.4577	.6371
17		.4862	.3772	1.8399	2.343	2.5232	.6783
18	.4359	.4748	.499	1.2763	2.3371	1.7269	.6443
19	.7577	.6584	.4805	.499	.5544	.4481	.7577
20	.6468	.6838	.4755	.4435	.6584	.5359	.7316
21	.5601	.5121	.4108	.3921	.5359	.5788	.6584
22	.4481	.5175	.3547	.4108	.499	.5729	.5729
23	.4668	.4668	.2987	.3547	.462	.5601	.5359
24	.4481		.3921	.2427	.3547	.4481	.499
Max	2.6379	2.7183	2.9001	2.4577	2.5484	2.5232	.763
Min	.4191	.4578	.2204	.2427	.3294	.4161	.4115
Avg	1.2027	1.1737	1.1816	1.5144	1.0511	1.1311	.5720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 204 / 11 KV TIKONDI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0934	.0747	.0934	.0747	.0754	.0934
2	.0747	.0943	.0739	.0739	.0754	.0754	.0739
3	.0934	.0943	.0747	.0739	.0754	.0747	.0747
4	.1109	.0943	.0934	.0934	.0754	.0934	.0934
5	.1478	.112	.1109	.1294	.0943	.112	.1294
6	.1829	.168	.1646	.1663	.168	.1109	.1829
7	.112	.1848	.1294	.1494	.112	.1663	.112
8	.0924	.1109	.0934	.1109	.0924	.1478	.1294
9	.0747	.0924	.1294	.1109	.0924	.112	.1109
10	.0739	.056	.1294	.0924	.1097	.0934	.1109
11	.0739	.0739	.1294	.0914	.1097	.0924	.1294
12	.0739	.0739	.128	.0914	.0914	.0924	.0924
13		.0747	.128	.0732	.0914	.1109	.0924
14	.0739	.0747	.0924	.0732	.0732	.128	.1097
15		.0739	.1109	.0747	.0732	.1109	.0914
16		.0914	.0934		.0549	.0924	.0914
17	.0739	.0739		.0924	.0732	.128	.0924
18	.0739	.128	.1109	.0924	.0924	.1494	.1109
19	.1109	.1663		.1109	.1478	.1663	.1294
20	.2033	.2195	.1848	.168	.1848	.2033	.1848
21	.1663	.1646	.1478	.1307	.1494	.1478	.168
22	.1307	.1294	.1294	.1109	.1307	.1294	.1307
23	.112	.1109	.0924	.0924	.0934	.1294	.112
24	.0739	.0934	.0934	.0934	.0747	.0747	.0934
Max	.2033	.2195	.1848	.168	.1848	.2033	.1848
Min	.0739	.056	.0739	.0732	.0549	.0747	.0739
Avg	.1050	.1104	.1143	.1039	.1004	.1174	.1141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 205 / 11 KV PANDOZARI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0373	.0187	.0373	.0187	.0373	.0373
2	.0373	.0373	.0189	.037	.0187	.0377	.0373
3	.056	.037	.0187	.0554	.037	.0373	.0554
4	.0554	.0373	.0373	.0747	.037	.056	.056
5	.0739	.0554	.037	.0739	.0554	.056	.0554
6	.0914	.1109	.056	.1097	.0934	.1109	.1097
7	.0739	.1109	.0739	.0747	.056	.0924	.0914
8	.0554	.0732	.0739	.0554	.056	.0739	.0739
9	.0187	.0366	.0373	.0732	.0554	.0747	.056
10	.0187	.037	.037	.0549		.0373	.037
11	.0185		.0549	.0366	.037	.037	.0373
12	.0185		.0549	.0366	.037	.037	.0373
13	.0366		.037	.0366	.0366	.037	.037
14	.0183		.0373	.0183		.0373	.037
15		.0373	.037	.0549	.0183	.0187	.037
16		.0554	.0373		.0183	.037	.0366
17	.0366	.037	.0554	.037	.0366	.0373	.0366
18	.0554	.0732	.0739	.0554	.0549	.0554	.0554
19		.0739	.112	.0747	.0732	.0739	.1109
20	.0924	.1097	.0924		.0924	.1097	.0924
21	.0934	.0739	.0747		.0924	.0924	.0934
22	.0747	.0554		.0373	.056	.0747	.0747
23	.056	.0373		.0373	.056	.0747	.056
24	.0373	.0373	.0187	.0373	.0187	.0373	.0554
Max	.0934	.1109	.112	.1097	.0934	.1109	.1109
Min	.0183	.0366	.0187	.0183	.0183	.0187	.0366
Avg	.0503	.0582	.0497	.0528	.0480	.0572	.0586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 206 / 11 KV KAGNARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0774	1.3077	1.2574	.6783	.3601	.1543	.4681
2	1.1736	1.4251	1.3426	.7209	.3561	.156	.4458
3	1.4251	1.5746	1.3757	.7209	.39	.1886	.463
4	1.6741	1.6409	1.5089	.8383	.407	.2035	.5087
5	1.8187	1.7269	1.6244	.9945	.4409	.2543	.1865
6	1.2763	1.6263	1.3426	1.442	.5365	.4409	.4527
7	1.8351	1.9559	1.9662	1.326	.5868	.503	.57
8	1.8067	1.8399	1.7404	1.5249	.5868	.4359	.3561
9	1.7901	1.7269	1.9334	1.6741	.547	.4578	.6706
10	1.8187	1.6575	1.9006	1.7901	.4527	.407	.6783
11	.4807		.4527	1.576	1.2407	1.7269	.503
12	.6133		.5765	1.9784	2.0119	1.8778	.5868
13	.6203		.5426	1.8896	1.9559	1.2742	.5533
14	.57		.4359	1.757		1.8399	.5868
15		.3185	.4409	1.9784	1.757	1.873	.5967
16		.6706	.2401		2.0222	1.7368	.6299
17	.5197	.4239	.6068	1.4089	1.8842	1.704	.6464
18	.6104	.7377	.5487	1.5257	1.8842	1.6598	.6371
19		.7392	.7842	.4481	.4572	.3734	.5359
20	.6219	.6908	.5729	.4435	.4805	.499	.5359
21	.5304	.5914	.5415	.4251	.462	.499	.3841
22	.5544	.5601	.2054	.3696	.3841	.5041	.4207
23	.5544	.5041	.1867	.3921	.3881	.4854	.4066
24	.5228	.5544	.4294	.1867	.3734	.1478	.5041
Max	1.8351	1.9559	1.9662	1.9784	2.0222	1.8778	.6783
Min	.4807	.3185	.1867	.1867	.3561	.1478	.1865
Avg	1.0426	1.1136	.9399	1.1343	.8681	.8084	.5136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 207 / 11 KV KAREWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2254	.2601	.1886	.1357	.9221	.9221	.8619
2	.2058	.2572	.2103	.1372	1.0774	1.1271	.9831
3	.2058	.2572	.208	.1543	1.2431	1.291	1.0442
4	.2374	.2713	.2229	.2035	1.3592	1.5249	1.4746
5	.2683	.3222	.2374	.3052	1.4746	1.6575	.5197
6	.2374	.3052	.2543	.4024	1.9826	2.0153	.9614
7		.3353		.4527	1.9989	2.2283	
8	.285	.2012	.2683	.3391	2.1714	1.7695	.5087
9	.3185	.3018	.3018	.3688	2.0553	1.9662	2.0222
10	.3353	.2035	.3222	.3353	1.7695	1.8351	2.0153
11	1.7072	1.9227	1.6712	.1844	.2321	.2486	1.6244
12	1.8399	2.0481	1.9662	.3018	.285	.2683	1.8564
13	1.8351	.8383	2.0243		.2984	.1174	1.6598
14	1.8842	1.7736	1.8515		.1326	.2713	1.8067
15		1.9662	1.7695		.1823	.3018	1.8351
16		1.917	1.0395		.2785	.2347	1.8842
17	1.8679	.779	1.5415		.3113	.3018	2.0388
18	1.9227	1.8679	1.5257	.2347		.3185	1.9062
19	.2957	.3361	.2987	.4251	.3361	.3734	.3142
20	.3734	.4066	.3326	.4294	.462	.4435	.3511
21	.3547	.3326	.3326	.3547	.4251	.3921	.3921
22	.3174	.2957	.1494	.2957	.3658	.3881	.3734
23	.2957	.2801	.1478	.2957	.3142	.3734	.3696
24	.2427	.2987	.2054	.1494	.2987	.168	.3326
Max	1.9227	2.0481	2.0243	.4527	2.1714	2.2283	2.0388
Min	.2058	.2012	.1478	.1357	.1326	.1174	.3142
Avg	.7265	.7407	.7422	.2897	.8685	.8557	1.1798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 208 / 11 KV DHULKARWADI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1271	1.291	1.3413	.7042	.2915	.12	.5087
2	1.2407	1.4754	1.3916	.7459	.3052	.1387	.4801
3	1.2431	1.6244	1.4918	.8048	.3052	.208	.4801
4	1.3426	1.6741	1.643	.9556	.3222	.2058	.5144
5	1.6057	1.6876	1.7238	1.0774	.3429	.2401	.1357
6	1.2266	1.757	1.4255	1.4586	.5256	.4917	.4694
7	1.8187	1.8564	2.13	1.8515	.6613	.6371	.57
8	1.9662	1.6575	1.6907	1.6244	.6203	.5365	.5087
9	1.6741	1.8442	1.917	1.6876	.6203	.4973	.6539
10	1.6907	1.3923	1.8067	1.8067	.5087	.4973	.7377
11	.3647		.4862	1.4255	.9054	1.7404	.4578
12	.5365		.6001	1.6741	1.9113	1.8351	.6706
13	.5365		.5721	1.7695	1.7736	.9054	.5197
14	.503		.583	1.8515	1.2431	1.8067	.5426
15		.2012	.4527	1.6244	1.6741	1.8515	.6371
16		.6796	.3353		1.9006	1.8187	.6874
17	.5087	.3688	.6952	.9945	1.6221	1.7072	.7127
18	.7122	.6796	.6783	1.358	1.7695	1.7404	.779
19	.7499	.8131	.8316		.499	.4066	.7762
20	.6838	.7023	.6838	.4108	.5359	.6348	.7316
21	.6468	.6099	.6722	.3921	.5121	.5914	.5853
22	.4854	.5601	.2427	.3326	.3944	.5975	.5359
23	.4435	.5175	.1494	.3326	.4066	.5729	.5359
24	.4108	.4805	.4668		.3326		.5544
Max	1.9662	1.8564	2.13	1.8515	1.9113	1.8515	.779
Min	.3647	.2012	.1494	.3326	.2915	.12	.1357
Avg	.9781	1.0936	1.0005	1.1849	.8326	.8600	.5744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 201 / 11 KV SANMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0876	.0886	.0934	.0886	.0895	.1097
2	.0943	.0886	.0857	.0905	.0914	.0924	.1109
3	.0943	.0914	.0914	.0934	.0934	.0857	.0905
4	.0943	.0867	.0934	.0914	.0857	.1867	.0905
5	.132	.0886	.1791	.1075	.1075	.1905	.0886
6	.1509	.0943	.1753	.1132	.1509	.1132	.124
7	.1509	.132	.132	.112	.1463	.0943	.0914
8	.0943	.0943	.0914	.0934	.1294	.132	.1132
9	.1097	.1494	.0895	.0914	.1463	.1109	.128
10	.0905	.0914	.0886	.0905	.128	.0905	.0895
11	.0914	.0905	.128	.0886	.0924	.0914	.0895
12	.0905	.0886	.1307	.0876	.0914	.0924	.1063
13	.0924	.0876	.0934	.0895	.0934	.0934	.1086
14	.0934	.0886	.0934	.0914	.0905	.0924	.0895
15	.0934	.0914	.0943	.0934	.0914	.0934	.0905
16	.0905	.0914	.0876	.0914	.0373	.0914	.0895
17	.0924	.0924		.0905	.0914	.0905	.0914
18	.1075	.0867		.0867	.0867	.1063	
19	.1448	.1417		.1052	.0876	.128	.0895
20	.1417	.1029	.1991	.181	.1075	.1463	.0876
21	.1463	.1063	.1715	.0857	.1494	.1867	.128
22	.0895	.0857	.0886	.0914	.0914	.1848	.0857
23		.0895	.0876	.0857	.0886	.112	.0886
24	.1132	.0943	.0943	.0943	.0943	.0943	.0934
Max	.1509	.1494	.1991	.181	.1509	.1905	.128
Min	.0895	.0857	.0857	.0857	.0373	.0857	.0857
Avg	.1084	.0976	.1135	.0975	.1025	.1162	.0989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 202 / 11 KV GHOLESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0886	.1433	.0914	.0857	.1219	.1802
2	.0953	.0934	.1029	.0857	.0886	.1677	.218
3	.0953	.1097	.1063	.0895	.0914	.1966	.2652
4	.0953	.112	.1097	.0934	.0905	.253	.2294
5	.0953	.1509	.1734	.0876	.0867	.2347	.2818
6	.1143	.1509	.1448	.0953	.0848	.5765	.3149
7	.0943	.0934	.0934	.0943	.1132	.4359	.3077
8	.0943	.0914	.0934	.0934	.1132	.3647	.3005
9	.0943	.0934	.0943	.0943	.2452	.3185	.2656
10	.0943	.0914	.0886	.0943		.285	.2846
11	.2846	.3361	.3401	.0934		.0943	.2846
12	.3086	.3281	.3725	.0905	.0934	.0953	.285
13	.3086	.2932	.4096	.0934	.0943	.0943	.1677
14	.2846	.2753	.3932	.0924	.0934	.0943	.2883
15	.2753	.2622	.3605	.0943	.0905	.0943	.3222
16	.3321	.3605	.1372	.0943	.0934	.0934	.2846
17	.3887	.3932		.0953	.0924	.0924	.3041
18	.2932	.2561		.0876	.0914	.0934	.2623
19	.0934	.0943		.0886	.0924	.0934	.0943
20	.0857	.1029		.0943	.1075	.112	.0857
21	.0943	.1433	.0857	.0857	.1509	.112	.0943
22	.0876	.0943	.0914	.0886	.0857	.0943	.0895
23	.0895	.0886	.0886	.0914	.0886	.0943	.0914
24	.0953	.1132	.0953	.0934	.0914	.0943	.0943
Max	.3887	.3932	.4096	.0953	.2452	.5765	.3222
Min	.0857	.0886	.0857	.0857	.0848	.0924	.0857
Avg	.1662	.1757	.1762	.0918	.1029	.1794	.2248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 203 / 11 KV KONIKUNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1063	.0857	.0857	.6859	.3121	.5365
2	.0943	.1097	.0934	.0857	.759	.5228	.7287
3	.0943	.1029	.0895	.0895	.8192	.639	.8356
4	.0943	.0895	.0914	.0934	.9842	.7186	.9667
5	.132	.1494		.0867	1.2803	1.0442	1.1012
6	.1698	.1698	.1715	.1063	1.4255	1.1934	1.2944
7	.168	.1307	.1097	.2803	1.4754	1.1469	1.3108
8	.112	.0934	.0934	.0914	1.4419	1.0486	1.3435
9	.1097	.112	.0934	.0914	1.3599	1.1498	1.3108
10	.1433	.1294	.0934	.0905	1.3108	.9069	1.2793
11	1.2944	1.2793	.9339	.0914	.1646	.0934	1.1498
12	1.2955	1.2793	1.3108	.1132	.112	.0943	1.2803
13	1.3279	1.2643	1.0159	.112	.112	.0934	.5468
14	1.3108	1.3108	1.2193	.112	.0914	.0934	1.186
15	1.3272	1.3426	.8684	.0943	.1086	.0914	1.166
16	1.3108	1.326	.6249	.0943	.0905	.0924	1.2955
17	1.278	1.326		.0943	.0905	.1097	1.4091
18	1.2803	1.1469		.0905	.0905	.1109	1.3435
19	.1267	.1075		.0886	.0924	.1307	.128
20	.1417	.1372	.1663	.1478	.1075	.1646	.1753
21	.1509	.1433	.112	.1097	.1509	.1663	.1494
22	.1097	.132	.1063	.0876	.0886	.1307	.0895
23	.1494	.0886	.0857	.0895	.0914	.1307	.0876
24	.1132	.1509	.0943	.0914	.0934	.0857	.0934
Max	1.3279	1.3426	1.3108	.2803	1.4754	1.1934	1.4091
Min	.0943	.0886	.0857	.0857	.0886	.0857	.0876
Avg	.5186	.5095	.3730	.1049	.5428	.4279	.8670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 204 / 11 KV SANAMADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0886	.0819	.0876	.0762	.0857	.0914
2	.0819	.0914	.0762	.0857	.0791	.0876	.0924
3	.08	.0857	.0791	.0886	.0819	.0934	.0924
4	.0791	.0895	.0838	.0905	.0762	.0857	.0934
5	.0772	.0937	.1029	.0943	.1029	.0934	.0934
6	.0914	.1524	.1052	.1113	.112	.0914	.0924
7	.1829	.1698	.1075	.0987	.0934	.0886	.0943
8	.2134	.1852	.1357	.096	.0943	.0838	.0943
9	.1981	.1372	.1509	.1189	.0914	.0848	.0943
10	.1614	.1204	.1467	.132	.061	.0838	.0943
11	.0953	.0857	.0943	.132	.0892	.1219	.0943
12	.0934	.0648	.0934	.132	.0903	.1656	.0838
13	.0934	.0638	.0934	.1219	.104	.1677	.0657
14	.0943	.0838	.0829	.1219	.1189	.1551	.0762
15	.0943	.0848	.0838	.1219	.1204	.1303	.081
16	.0838	.0848	.08	.096	.1355	.1067	.0838
17	.0819	.0857		.0974	.132	.1036	.0857
18	.0848	.0943		.092	.1286	.1097	.0667
19	.0857	.0886		.0949	.1	.0876	.0676
20	.0914	.0914	.0886	.1204	.0857	.0886	.0876
21	.0895	.0857	.0914	.0819	.0924	.0905	.0867
22	.0934	.0914	.0895	.0857	.0895	.0924	.0914
23	.0857	.0819	.0857	.0876	.0934	.0924	.0886
24	.0924	.0905	.0848	.0914	.0743	.0886	.0914
Max	.2134	.1852	.1509	.132	.1355	.1677	.0943
Min	.0772	.0638	.0762	.0819	.061	.0838	.0657
Avg	.1045	.0996	.0970	.1034	.0968	.1033	.0868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 205 / 11 KV GHOLESHWAR GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1063	.1372	.0886	.0857	.0857	.0914
2	.0943	.1097	.0886	.0914	.0914	.0895	.0934
3	.0943	.1029	.0857	.0934	.0867	.0934	.0905
4	.0934	.1772	.0895	.0857	.0934		.0895
5	.1698	.1829		.1829	.1715	.1509	.1097
6	.2452	.2829	.1848	.2614	.2507	.2452	.2452
7	.1772	.2012	.1772	.2378	.197	.1595	.2033
8	.197	.1646	.1578	.1907	.1052	.1629	.1829
9	.1595	.168	.1417	.1595	.1677	.1629	.1629
10	.1578	.1696	.1753	.1595	.1638	.1791	.1612
11	.1463	.1772	.1791	.1417	.1187	.1753	.1595
12	.1463	.1595	.1463	.1478	.12	.1772	.1402
13	.1267	.1612	.1478		.1387	.1254	.1448
14	.1267	.124	.1448		.1463	.1267	.1448
15	.1267	.128	.1646		.1595	.12	.1109
16	.1578	.124		.1739	.128	.156	.1646
17	.1715	.1753		.2347	.1886	.1677	.2241
18	.1715	.2058		.1989	.2374	.2035	.2321
19	.2543	.2804		.2572	.2785	.2427	.2347
20	.2515	.1829	.3109	.2481	.1581	.2658	.2572
21	.2743	.1715	.1867	.0857	.2218	.2629	.2454
22	.0886	.1715	.0914	.0886	.0914	.2254	.2658
23	.0914	.1075	.0886	.0914	.0886	.1949	.0895
24	.132	.1307	.1294	.0943	.0924	.0943	.1307
Max	.2743	.2829	.3109	.2614	.2785	.2658	.2658
Min	.0886	.1029	.0857	.0857	.0857	.0857	.0895
Avg	.1561	.1652	.1488	.1578	.1492	.1681	.1656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 206 / 11 KV NIGADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1791		.1829	.6859	.2303	.2347
2	.1509	.2195	.3258	.2103	.9816	.2195	.3441
3	.1698	.2614	.3544	.2743	1.0608	.2743	.3768
4	.2075	.2743	.3772	.3121	1.1203	.3224	.4321
5	.3584	.3544	.3658	.3544		.3506	.5218
6	.4527	.4904	.4191	.415	1.1065	.6783	.7377
7	.3921	.3961	.2987	.3547	1.0322	.6062	.8029
8	.2801	.2452	.2614	.2587	1.0227	.6371	.8259
9	.2195	.1886	.2402	.2054	.8619	.5407	.7865
10	.181	.197	.9877	.1337	.5601	.506	.7362
11	.664	.8583	.8848	.1219	.1307	.1646	.6325
12	.6325	.7842	.8718	.1265	.1417	.1494	.6009
13	.6167	.5552	.852	.1463	.1463	.1463	.5155
14	.5921	.5376	.6964	.1478	.1494	.1478	.5155
15	.5693	.6081	.639	.1494	.1294	.1494	.506
16	.6642	.7373	.6722	.1663	.1829	.1663	.6958
17	.7287	.8684		.2012	.2012	.1829	.8162
18	.68	.6401		.1848	.2402	.1848	.7935
19	.2427	.2614		.2561	.2987	.2801	.3142
20	.2641	.2743	.2987	.3174	.2103	.2957	.3224
21	.1372	.2481	.2378	.3582	.2641	.2587	.2629
22	.1595	.2402	.2126	.2835	.2987	.2378	.2149
23		.1772	.1715	.1715	.2195	.2054	.1715
24	.1509	.1698	.1509	.2054	.1867	.1886	.168
Max	.7287	.8684	.9877	.415	1.1203	.6783	.8259
Min	.1372	.1698	.1509	.1219	.1294	.1463	.168
Avg	.3767	.4069	.4659	.2307	.4883	.2968	.5137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 207 / 11 KV YELAVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365	.4458	.4973	.3086	.1715	.2229	.1629
2	.6539	.8779	.6733	.4607	.2534	.1734	.1417
3	.7127	1.0829	.8962	.6584	.3189	.2012	.1612
4	.9831	1.166	1.387	.6588	.2926	.2572	.1646
5	1.5249	1.6118	1.5746	.8589	.2743	.2263	.2987
6	1.7238	1.7736	1.6004	.8381	.3511	.3174	.3174
7	1.873	1.7859	1.2146	.953	.3052	.2957	.2641
8	1.9062	1.7859	1.3108	.9722	.3012	.2402	.2218
9	1.4746	1.7532	1.1523	.8223	.2561	.2012	.1663
10	1.3443	.5335		.3418	.2372	.1949	.1646
11	.1663	.1187	.1595	.5218	.852	1.0059	.1646
12	.1663	.12	.1612	.7907	.9282	1.6078	.1612
13	.2012	.1772	.181	.759	.9878	1.2955	.1646
14	.1848	.168	.1791	.6241	1.0202	1.1683	.2033
15	.1848	.1646	.2149	.8223	.9922	1.4403	.2218
16	.1848	.1646	.2743	.9842	1.0526	1.5546	.2033
17	.1848	.1663		.953	1.1736	1.6356	.2033
18	.197	.2507		.3201	1.0595	1.3443	.2303
19	.2561	.2402		.3142	.2715	.2743	.3258
20	.3189	.2804	.2534	.2303	.1753	.2378	.3582
21	.2987	.3292	.2378	.2303	.2987	.2534	.3511
22	.1829	.2587	.1753			.2172	.2743
23	.1543	.1715	.2058	.2103		.1949	.2658
24	.2241	.2033	.2328	.2012	.2328	.1829	.1991
Max	1.9062	1.7859	1.6004	.9842	1.1736	1.6356	.3582
Min	.1543	.1187	.1595	.2012	.1715	.1734	.1417
Avg	.6516	.6512	.6291	.6015	.5366	.6143	.2246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 201 / 11 KV KONTEBOBLAD MIX
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	11-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.6554
2	.1334	.1143	.6554
3	.1524	.0762	.7287
4	.1905	.0762	.8097
5	.2286	.1143	.8097
6	.2096	.1143	1.4089
7	.2286	.2286	1.4089
8	.1905	.2286	1.3927
9	.1715	.2477	1.4582
10	.1334	.2286	1.4089
11	.6554	.1905	1.4918
12	1.5083	.1905	1.3592
13	1.6575	.1905	1.326
14	1.4586	.2286	1.2929
15	1.2431	.2286	1.3094
16	1.2597		1.326
17	1.326	.1524	1.3094
18	1.3094	.1905	1.0814
19	.1905	.2286	.1715
20		.2667	.1905
21		.2667	.1715
22		.2477	.1715
23		.2477	.1524
24	.1715	.1524	.1905
Max	1.6575	.2667	1.4918
Min	.1334	.0762	.1524
Avg	.6285	.1889	.9284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 202 / 11 KV JALYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	11-MAY-18	12-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.8192	
2	.2286	.2477	1.3108	
3	.1905	.1905	1.3108	
4	.2477	.1334	1.4746	
5	.3429	.2286	1.6385	
6	.381	.3429	2.0153	
7	.4954	.4763	2.13	
8	.381	.4572	2.13	
9	.3239	.4572	2.0645	
10	.3239	.4382		
11	.9012	.381	.3429	1.5203
12	2.3205	.381	.381	1.7695
13	2.3537		.4191	1.8233
14	2.3205			1.4918
15	2.2874			1.4752
16	2.3205			2.3371
17	2.2377	.381		2.2045
18	2.2045	.381		1.7901
19		.4191		.2667
20		.4763		.2858
21		.381		.3048
22		.381		.2858
23		.3429		.2667
24	.2667	.3048	.2858	
Max	2.3537	.4763	2.13	2.3371
Min	.1905	.1334	.2858	.2667
Avg	1.0724	.3534	1.2556	1.2170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 203 / 11 KV GIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	11-MAY-18	12-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.4801	.0953	.1143
2	.4588	.4858	.0953	.1143
3	.4915	.6554	.0953	.1143
4	.7459	.7459	.1143	.0953
5	.9614	.8288	.1524	.0953
6	1.0442	.9116		.1905
7	1.1934	.9945	.1905	.1334
8	1.0608	.9116	.1905	.1334
9	.8951	.8288	.1905	.1143
10	.8122	.7956	.1905	.0953
11	.1143	.9831	.663	.1143
12	.0953	.9831	.663	.1143
13	.0953	.8288	.7625	.0953
14	.0953	.7373		.0762
15	.0762	.7373		.0953
16	.0953			.0953
17	.1143	.8288		.1143
18	.1143	.7287		.1143
19	.0762	.1143		.1334
20		.1143		.1334
21		.1143		.1143
22		.1143		.1143
23		.1334		.0953
24	.0953	.0762	.1143	.1143
Max	1.1934	.9945	.7625	.1905
Min	.0762	.0762	.0953	.0762
Avg	.4525	.6144	.2706	.1135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 204 / 11 KV MORBAGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	11-MAY-18	12-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.5668	.1905	.1143
2	.7373	.1905	.1143
3	.9175	.2477	.1143
4	1.1271	.2286	.1143
5	1.3094	.2286	.1143
6	1.4586	.2858	.1905
7	1.5746	.2858	.1905
8	1.5581	.3429	.1905
9	1.5249	.2667	
10	1.3757	.1905	
11	1.4746	1.587	
12	1.5565	1.7269	
13	1.4918	1.8233	
14	1.5565		
15	1.4746		
17	1.3765		.1524
18	1.3927		.2667
19	.1524		.2286
20	.1905		.2667
21	.1524		.2096
22	.1524		.2096
23	.1715		.1905
24	.1905	.1905	.1143
Max	1.5746	1.8233	.2667
Min	.1524	.1905	.1143
Avg	1.0210	.5561	.1738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 201 / 11 KV KANKESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.064	.0724	.0366	.9442	1.3306	1.2929
2	.0716	.064	.0724	.0366	.9602	1.386	1.2631
3	.0716	.064	.0724	.0366	.9602	1.386	1.2631
4	.0716	.064	.0724	.0366	.9282	1.3306	1.2631
5	.0716	.048	.0724	.0366	.9762	1.3306	1.2631
6	.0716	.048	.0905	.0366	.8962	1.5893	1.2955
7	.0716	.048	.0716	.0914		1.7556	1.3927
8	.0537	.048	.0716	.0366		1.9404	1.5223
9	.0537	.048	.0716	.0366		1.7372	1.5203
10		.048	.0537			.0554	.0514
11		2.3266	2.2565			.0554	
12		2.343	2.3365			.037	1.9719
13		2.2611	1.9044		.0724	.0554	1.6975
14		2.2283	2.2245	.0549	.0724	.0554	2.0576
15		2.2283	2.2405	.0549	.0701	.037	2.1948
16	2.0645	2.2775	2.1605		.0526	.037	2.2262
17	2.1464	1.917			.0554		2.0062
18	2.0645	1.9334		.0366	.0554	.037	1.9204
19	.048	.0876		.0549	.0554	.0709	.0514
20	.064	.0876	.032	.0549	.0739	.0876	.0686
21	.064	.1052	.0366	.0549	.0655	.0876	.0686
22	.064	.1063	.0366	.0549	.0739	.0886	.0686
23	.064	.0886	.0366	.0366	.1109	.0716	.0686
24	.0716	.064	.0709	.0366	1.0082	1.3306	1.2266
Max	2.1464	2.343	2.3365	.0914	1.0082	1.9404	2.2262
Min	.048	.048	.032	.0366	.0526	.037	.0514
Avg	.4033	.7749	.6694	.0457	.4129	.6910	1.2067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 202 / 11 KV MHAISHAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6733	.6241	.679	.6283	.5914	.5609	.6224
2	.6379	.6068	.679	.5729	.5544	.5258	.6224
3	.6201	.6068	.6413	.5729	.5544	.5258	.6224
4	.6024	.5548	.6413	.5729	.5729	.5258	.6224
5	.6024	.5548	.6413	.5729	.6468	.5258	.6224
6	.6201	.5548	.6413	.5729	.5914	.5434	.6224
7	.567	.5201	.6099	.5544	.5914	.5083	.5415
8	.4607	.4681	.5359	.499	.5359	.4908	.5601
9	.4784	.5028	.5544	.499	.5175	.4557	.5138
10		.5375	.5729	.499	.5359	.4733	.5014
11		.6241	.6468	.5729	.4961	.631	.6268
12		.6805	.7207	.6283	.5552	.6661	.7343
13		.6984	.6653	.6283	.6089		.6984
14		.6984	.7392	.6468	.5373	.5258	.7522
15		.6984	.9425	.7577	.6447	.7011	.7164
16	.7421	.6805	.9055		.6447	.7011	.7602
17	.7087	.6984			.631	.4908	.6805
18	.7282	.6805		.5914		.5959	.788
19	.7628	.8596	1.0349	.8686	.7888	.8238	.8775
20	.9536	.9877	.961	.9055	.8939	.9694	1.0208
21	.9536	.9149	.9055	.9055	.8688	.8779	1.0387
22	.8149	.9149	.8316	.7762	.7011	.8048	.9492
23	.7802	.8215	.7762	.7392	.631	.7468	.8238
24	.691	.6241	.7167	.7207	.6838	.5609	.679
Max	.9536	.9877	1.0349	.9055	.8939	.9694	1.0387
Min	.4607	.4681	.5359	.499	.4961	.4557	.5014
Avg	.6887	.6714	.7292	.6493	.6251	.6187	.7082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 203 / 11 KV MAHAVEER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4419	1.4754	1.4419			
2	1.4419	1.4754	1.4419			
3	1.4251	1.5089	1.4419			
4	1.4251	1.5089	1.4419			
5	1.4754	1.5089	1.4419			
6	1.5424	1.576	1.4419			
7	1.643	1.5927	1.4922			
8	1.4754	1.643	1.4419			
9	1.643	1.6095	1.4419			
11				1.7604	.7712	1.7269
12				1.6263	.7377	1.8778
13				1.6766	.7545	1.8275
14				1.7101	.7293	1.8107
15				1.7269	1.4255	1.7939
16					1.5912	1.8778
17					1.5424	1.4251
18				1.4586	1.576	1.6263
24	1.4251	1.4754	1.3077			
Max	1.643	1.643	1.4922	1.7604	1.5912	1.8778
Min	1.4251	1.4754	1.3077	1.4586	.7293	1.4251
Avg	1.4938	1.5374	1.4335	1.6598	1.1410	1.7458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 204 / 11 KV NARWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0943	.0366	.381	.5281	.4902
2		.0934	.0943	.0366	.3963	.5281	.4902
3	.0934	.0934	.0943	.0366	.381	.5658	.4902
4	.0934	.0934	.0943	.0366	.3963	.5658	.4902
5	.0934	.0934	.1132	.0366	.442	.6413	.4902
6	.112	.112	.132	.0366	.5792	.9054	.6019
7	.112	.0934	.1307	.0366	.9602	1.0311	.679
8	.0747	.0747	.0934	.0366	.8535	1.1248	.7407
9	.0747	.0934	.112	.0366	.7773	1.1561	.7773
10		.0934	.0934	.0366	.0762	.0625	.0886
11		1.2323	1.278	.0366	.0693	.0781	.7973
12		1.1843	1.3272	.0732	.0886	.0781	.8859
13		1.1363	1.2289	.0671	.1097	.0937	.8328
14		1.0402	1.0159		.0905	.0876	.8682
15		1.1363	1.1469	.1174	.0747	.0781	.9391
16	1.3443	1.3123	1.1633		.0934	.0625	.852
17	1.2492	1.2483			.0754	.0625	.9922
18	1.142	1.0883		.1174	.0943	.0781	.9391
19	.0772	.112		.1006	.0943	.0914	.0886
20	.108	.1494	.0492	.1006	.132	.1478	.124
21	.1494	.168	.0549	.1006	.1509	.1294	.124
22	.1494	.1509	.0366	.1006	.1132	.1294	.1063
23	.112	.1132	.0366	.0838	.0943	.112	.0886
24	.112	.0934	.0943	.0366	.3521	.5281	.381
Max	1.3443	1.3123	1.3272	.1174	.9602	1.1561	.9922
Min	.0747	.0747	.0366	.0366	.0693	.0625	.0886
Avg	.3053	.4625	.4040	.0619	.2865	.3694	.5566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 205 / 11 KV MHAISHAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8564	1.9044	1.7394	1.1561	.0701	.064	.0739
2	1.8404	1.9791	1.7394	1.1405	.0526	.064	.0739
3	1.8244	1.9791	1.7394	1.0936	.0526	.064	.0739
4	1.8404	2.0165	1.7394	1.0155	.0526	.064	.0739
5	1.8404	2.0538	1.7394	1.0155	.0701	.064	.0739
6	1.8884	2.1658	1.8027	1.078	.0701	.064	.0739
7	2.1285	2.6326	1.9845	1.3123	.0876	.08	.0716
8	2.2725	2.8006	2.1285	1.2967	.0701	.096	.0716
9	2.1605	2.6139	2.0165	1.406	.0701	.08	.0701
10		.0747		.0781	.0876	.08	.0701
11		.0747	.0716	1.6404	2.0243	2.1285	
12		.0747	.0716	1.656	2.1052	2.3205	
13		.0747	.0716	1.781	1.9919	2.1765	.0701
14		.056	.0716	1.7341	1.7394	1.9364	.0701
15		.0747	.1075	1.6872	1.8501	2.0645	.0526
16	.0905	.056	.1254		1.8564	2.0645	.0655
17	.0701	.0747			1.7604	1.7444	.0701
18	.0373	.0747		1.4373	1.7284	1.2963	.0701
19	.0373	.0747	.0895	.0876	.048	.0886	.0701
20	.112	.0934	.0716		.064	.0709	.0701
21	.0934	.0934	.0716	.0701	.0819	.0709	.0701
22	.0934	.0747	.0895	.0701	.08	.0709	.0701
23	.0747	.0747	.0716		.064	.0739	.0701
24	1.8724	1.9044	1.6356	1.3763	.0701	.064	.0739
Max	2.2725	2.8006	2.1285	1.781	2.1052	2.3205	.0739
Min	.0373	.056	.0716	.0701	.048	.064	.0526
Avg	1.1185	.9623	.9132	1.1066	.6728	.7038	.0704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 206 / 11 KV MALIWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0362	.0362	.0362	.0362	.0362	.0362
2	.0377	.0362	.0362	.0362	.0362	.0362	.0362
3	.0377	.0362	.0362	.0362	.0362	.0362	.0362
4	.0377	.0362	.0362	.0362	.0362	.0362	.0362
5	.0377	.0362	.0362	.0362	.0362	.0362	.0362
6	.0377	.0362	.0362	.0181	.0362	.0181	.0362
7	.0377	.0362	.0362	.0181	.0362	.0362	.0362
8	.0377	.0362	.0362	.0362	.0181	.0181	.0362
9	.0189	.0181	.0362	.0362	.0181	.0181	.0362
10		.0362	.0181	.0362	.0362	.037	.0362
11		.0362	.0543	.0362	.0362	.0181	.0362
12		.0181	.0543	.0362	.0362	.0362	.0362
13		.0181	.0362	.0362	.0362	.0362	.0181
14			.0362		.0362	.0362	.0362
15		.0362	.0362	.0362	.0362	.0362	.0181
16	.0362	.0181	.0362		.0362	.0362	.0181
17	.0362	.0181			.0362	.0362	.0181
18	.0362	.0181		.0362	.0362	.0362	.0181
19	.0362	.0362	.0543	.0362	.0362	.0362	.0362
20	.0181	.0362	.0362	.0362	.0362	.0362	.0362
21	.0362	.0362	.0362	.0362	.0362	.0362	.0362
22	.0362	.0362	.0362	.0362	.0362	.0362	.0362
23	.0362	.0362	.0362	.0362	.0362	.0362	.0362
24	.0377	.0362	.0362	.0362	.0181	.0362	.0362
Max	.0377	.0362	.0543	.0362	.0362	.037	.0362
Min	.0181	.0181	.0181	.0181	.0181	.0181	.0181
Avg	.0350	.0315	.0378	.0345	.0339	.0332	.0324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 207 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0693	.0514	.0532	.0526	.096	.0983	.1006
2	.052	.0514	.0532	.0526	.096	.0983	.1006
3	.104	.0514	.0532	.0351	.096	.0983	.0995
4	.052	.0514	.0532		.096	.0983	.0995
5	.052	.0514	.0532	.0351	.096	.0983	.0995
6	.052	.0514	.0532	.0526	.096	.0983	.0995
7	.052	.0514	.0532	.0526	.096	.0983	.0995
8	.052	.0514	.0701	.0526	.096	.0983	.0995
9	.0693	.052	.0701	.0526	.096	.0983	.0983
10		.052	.0701	.0526	.096	.0983	.0949
11		.052	.0701		.0829	.0983	.0949
12		.0701	.0701	.0526	.0995	.0983	.0949
13		.0701	.0701	.0526	.0995	.0983	.0949
14		.0701	.0701	.0857	.0926	.0983	.0949
15		.0701	.0701	.0876	.096	.0983	.0949
16	.0701	.0701	.0701		.1017	.0983	.0983
17	.0701	.0701			.0983	.0983	.0949
18	.0686	.0701	.0351	.096	.0983	.0983	.0983
19	.0514	.0532	.0526	.096	.096	.0972	.0983
20	.0533	.0526	.0526	.096	.096	.0972	.0983
21	.0514	.0526	.0526	.096	.096	.081	.0983
22	.0514	.0532	.0526	.096	.096	.0983	.0983
23	.0514	.0532	.0526	.096	.096	.0983	.0983
24	.0693	.0514	.0532	.0526	.096	.096	.1006
Max	.104	.0701	.0701	.096	.1017	.0983	.1006
Min	.0514	.0514	.0351	.0351	.0829	.081	.0949
Avg	.0606	.0573	.0589	.0673	.0960	.0974	.0979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 201 / 11 KV Dhavali Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	1.4754	2.0348	2.0748
2	.0191	.0191	.0191	.0191	1.4754	2.0348	1.9071
3	.0191	.0191	.0191	.0191	1.4754	2.0348	1.9071
4	.0191	.0191	.0191	.0191	1.4754	2.0748	1.9071
5	.0191	.0191	.0191	.0191	1.4255	2.0748	1.9071
6	.0191	.0191	.0191	.0191	1.4255	2.1948	2.0805
7	.0191	.0191	.0191	.0191		2.3663	2.2885
8	.0191	.0191	.0191	.0191		2.4966	2.2885
9	.0191	.0191	.0191	.0191		2.4446	2.4272
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11		3.1207	2.982	.0191	.0191	.0191	2.4863
12			2.4966		.0191	.0191	2.5659
13	.0191		3.0167	.0191	.0191	.0191	2.774
14	.0191	2.8433	2.8433	.0191	.0191	.0191	2.6578
15	.0191		2.878	.0191	.0191	.0191	2.6063
16	2.4356	2.9127	2.7435	.0191	.0191	.0191	2.4863
17	2.7046	2.9127			.0191	.0191	2.6578
18	2.6235	2.6353			.0191	.0191	2.6873
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	1.4754	1.3565	1.4922
Max	2.7046	3.1207	3.0167	.0191	1.4754	2.4966	2.774
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.3694	.7014	.7848	.0191	.4998	.8908	1.7215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 202 / 11 KV Nilaji Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	1.406	1.4083	.4694	.0191	.0191	.0191
2	1.3717	1.406	1.4083	.4694	.0191	.0191	.0191
3	1.3375	1.406	1.4083	.4694	.0191	.0191	.0191
4	1.3969	1.406	1.4083	.4973	.0191	.0191	.0191
5	1.3969	1.4529	1.4083	.4973	.0191	.0191	.0191
6	1.4661	1.6078	1.4969	.4973	.0191	.0191	.0191
7	1.5893	1.6461	1.7002	.9282	.0191	.0191	.0191
8	1.6817	1.6827	1.7741		.0191	.0191	.0191
9	1.7372	1.7924	1.9387	1.2378	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11	.0191	.0191	.0191	1.4403	1.0802	1.4582	.0191
12	.0191		.0191		.9945		.0191
13			.0191	.9282	1.073	1.4582	.0191
14	.0191	.0191	.0191	1.4074	1.0898	1.4243	.0191
15	.0191		.0191	1.4074	1.0898	1.2717	.0191
16	.0191	.0191	.0191	1.3565	1.1022	1.2407	.0191
17	.0191	.0191			1.0682	1.2378	.0191
18	.0191				1.1022		.0191
19	.0191	.0191		.0191	.0191	.0191	.0191
20	.0191	.0191		.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191		.0191	.0191
24	1.358	1.3904	1.3203	.7042	.0191	.0191	.0191
Max	1.7372	1.7924	1.9387	1.4403	1.1022	1.4582	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.6489	.7694	.7731	.6212	.3864	.3817	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3721	.3898	.3801	.3326	.2926	.2614	.1867
2	.3544	.3898	.3801	.3292	.2926	.2614	.1867
3	.3544	.3366	.3801	.3292	.2926	.2614	.1867
4	.3155	.3366	.3761	.3258	.3109	.2614	.1867
5	.3155	.3544		.362	.3856	.2957	.2054
6	.3506	.4031	.5144	.3761	.333	.3258	.2378
7	.3814	.3988	.4862	.3898	.3155	.2865	.2033
8	.3988	.4115	.5533	.3814	.2804	.3155	.2012
9	.407	.4239	.5636	.4287	.298	.333	.2481
10	.4527	.4694	.5636	.4807	.2601	.39	.2572
11	.4578	.4681	.5426	.4917	.2865	.3988	.3988
12	.4641		.3988		.3086	.3988	.4161
13			.5596	.4748	.3155	.3988	.4161
14	.407	.5375	.5658	.4973	.3366		.3856
15	.4334	.5375	.5487	.4973	.3366	.2353	.3506
16	.3856	.5765	.5426	.4748	.333	.4382	.3506
17	.4801	.6443			.3294	.4733	.39
18	.4641	.6241			.3121	.4382	.39
19	.5087	.6415	.3721	.4578	.3258	.2033	.3294
20	.4557	.5895	.4298	.4681	.3292	.2241	.394
21	.4477	.5548	.4344	.443	.3326	.2241	.3544
22	.4298	.3988	.3696	.3801	.3326	.2241	.3439
23	.4024	.4075	.3361	.3326	.3174	.2075	.3475
24	.4075	.3898	.3801	.3326	.3109	.2829	.2075
Max	.5087	.6443	.5658	.4973	.3856	.4733	.4161
Min	.3155	.3366	.3361	.3258	.2601	.2033	.1867
Avg	.4107	.4674	.4608	.4088	.3153	.3104	.2989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 204 / 11 KV Takali Bolwad Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1848	.1886	.181	1.1012	1.7404	1.094
2	.1629	.1848	.1886	.181	1.1012	1.7404	1.094
3	.1629	.1848	.1886	.1646	1.1012	1.7404	1.094
4	.1629	.1848	.1886	.1646	1.085	1.757	1.094
5	.1663	.1848	.1886	.1646	1.085	1.8564	1.094
6	.1848	.2033	.2195	.1663	.9122	2.1548	1.1934
7	.2033	.2054	.2241	.168		1.6907	1.3923
8	.1886	.168	.1509	.1886	.6944	1.5746	1.6575
9	.1867	.1494	.1509	.1509	.6481	1.1469	1.5424
10	.1886	.2075	.1698	.1509	.1509	.1509	
11	2.2131	2.8826	2.7161	.132	.1463	.1494	
12	2.2283		2.0719		.1387	.1509	1.989
13			2.1714	.132	.1509	.1509	2.2211
14	1.8442	2.5149	2.1051	.112	.1509	.1509	2.1548
15	1.9006		2.4646	.132	.1509	.132	2.3205
16	2.2131	2.5652	2.4863		.1109		1.166
17	2.3205	2.6825			.112		2.1879
18	2.2874	2.4417			.1254	.0191	2.146
19	.1867	.2263	.1848	.1478	.1791	.0191	.1867
20	.1867	.2263	.1629	.1829	.197	.0191	.2033
21	.1867	.2263	.1791	.1629	.1772	.1791	.2012
22	.181	.2263	.1612	.1417	.1772	.1433	.2012
23		.2263	.1417	.1433	.1772	.1433	.1829
24	.181	.181	.1886	.181	1.1012	1.0883	1.0608
Max	2.3205	2.8826	2.7161	.1886	1.1012	2.1548	2.3205
Min	.1629	.1494	.1417	.112	.1109	.0191	.1829
Avg	.8053	.7741	.7678	.1574	.4771	.8135	1.2490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 206 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2452	.2641	.2641	.2641	.2641	.2641
2	.2452	.2452	.2641	.2263	.2641	.2641	.2641
3	.2452	.2452	.2641	.1886	.8299	.2641	.2641
4	.2452	.2452	.2641		.2641	.2641	.2641
5	.2452	.2641	.3018	.1886	.2641	.2829	.2641
6	.2829	.3018	.3018	.2452	.2641	.3395	.2641
7	.3206	.3018	.3018	.3206	.2641	.3772	.2263
8	.2452	.2829	.3018	.2829	.2641	.3018	.2641
9	.2452	.2829	.2641	.3018	.2641	.3018	.2641
10	.2075	.2829	.2641	.2641	.2263	.2452	.2641
11	.1886	.3018	.2641	.2452	.2263	.2641	.3018
12	.2263		.2641		.1886	.2829	.3018
13			.2641	.2641	.1886	.3018	.3018
14	.2263	.3018	.2641	.2641	.2263	.2641	.2829
15	.3018		.2829	.2641	.2263	.2641	.2829
16	.3018	.2641	.2829	.2641	.2263	.2829	.2829
17	.2641	.2641			.2641	.2641	.2641
18	.2641	.2263			.1509	.2263	.3018
19	.3018	.3395	.3772	.3772	.2829	.3395	.3018
20	.3772	.3395	.3772	.3772	.3584	.3772	.3772
21	.3772	.3395	.3772	.3584	.3772	.3395	.3584
22	.3772	.3018	.3395	.3395	.3772	.3395	.3395
23	.3395	.3018	.3018	.3018	.3395	.3018	.3206
24	.2641	.2641	.2641	.2641	.2641	.2263	.2641
Max	.3772	.3395	.3772	.3772	.8299	.3772	.3772
Min	.1886	.2263	.2641	.1886	.1509	.2263	.2263
Avg	.2764	.2829	.2932	.2801	.2861	.2908	.2869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 201 / Soni Gavathan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2829	.2829		.2641	.2641	.2641
2	.2829	.2829	.2829		.2641	.2641	.2452
3	.2829	.2829	.2829		.2641	.2641	
4	.2829	.2829	.2829		.2641	.2641	
5	.2829	.2829	.3018		.2641	.2641	
6	.3018	.2987	.3206	.2641	.3018	.2829	
7	.3206	.2987	.2452	.2829	.2801	.2452	
8	.2427	.2427	.2427	.2263	.2241	.2241	
9	.2241	.2427	.2427	.2241	.2241	.2241	.2614
10	.2241	.2427	.2614	.2054	.2241	.1867	.2241
11	.2241	.2427	.2427	.2241	.1867	.1494	.2614
12	.2241	.2054	.2427	.2427	.2241	.2241	.2241
13	.2427	.2427	.2614	.2427	.2241	.2427	.2801
14	.2614	.2427	.2614	.2614	.2241	.2614	.2614
15	.2614	.2614	.2801	.2241	.2427	.2241	.2614
16	.2427	.2427	.2614		.2241	.168	.2427
17	.2241	.2241			.2054	.2054	.168
18	.2801	.2614		.3361		.2614	.2614
19	.3361	.3547		.3734	.3921	.3584	.3734
20	.4108	.4338	.3584	.4108	.3734	.415	.4338
21	.3921	.4527	.3584	.3921	.3961	.3961	.415
22	.3734	.3961	.3206	.3395	.3584	.3772	.3961
23	.3206	.3395	.2829	.2829	.3018	.2829	.3206
24	.3018	.2829	.2829		.2641	.2641	.2641
Max	.4108	.4527	.3584	.4108	.3961	.415	.4338
Min	.2241	.2054	.2427	.2054	.1867	.1494	.168
Avg	.2843	.2885	.2809	.2833	.2692	.2631	.2866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 202 / 11 KV Bhose Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2829	.3395	.2829	.2829	.3018	.3206
2	.3395	.2829	.3395	.2641	.2829	.3018	.3206
3	.3395	.2829	.3395	.2452	.2829	.3018	.3206
4	.3395	.2829	.3395	.2452	.2829	.3018	.3206
5	.3395	.2829	.3206	.2452	.2829	.2829	.3206
6	.3584	.2427	.3206	.2452	.3206	.2641	.3395
7	.3206	.2427	.3395	.2263	.2054	.2075	.3206
8	.2263	.2614	.2987	.2075	.1867	.168	.2075
9	.2427	.3547	.3174	.2075	.2614	.1867	.2241
10	.3921	.2801	.3547	.2054	.2241	.3361	.3547
11	.3921	.3734	.4668	.2054	.1867	.3921	.4294
12	.7095	.3734	.5041	.3174	.3174	.4108	.5415
13	.1307	.4668	.4481	.3734	.4854	.3921	.5415
14	.1494	.2054	.2987	.2241	.3361	.3734	.3361
15	.1494	.5601	.3547	.3734	.6348	.5228	.3174
16	.1494	.3547	.4108		.4854	.2241	.4668
17	.0747	.4294		.3174	.4668	.2427	.4108
18	.3734	.5788		.4481	.3921	.3547	.3734
19	.4668	.2427		.2241	.2241	.2641	.2241
20	.3361	.2641	.1886	.2614	.2241	.2829	.2829
21	.3174	.2641		.2801	.2263	.2829	.2452
22	.3921	.2452	.2263	.3584	.2263	.3206	.2452
23	.3395	.2829	.2452	.3206	.3018	.3584	.3018
24	.3772	.2829	.3206	.2641	.2829	.2829	.3395
Max	.7095	.5788	.5041	.4481	.6348	.5228	.5415
Min	.0747	.2054	.1886	.2054	.1867	.168	.2075
Avg	.3165	.3217	.3387	.2758	.3085	.3065	.3377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 203 / 11 KV PATGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.132	.0943	.0377		.1457	.2105
2	.0943	.132	.0943	.0377		.1457	.1943
3	.0943	.132	.0943	.0377		.1457	.1943
4	.0943	.132	.0943	.0377		.1457	.2105
5	.0943	.132	.0943	.0377		.1943	.2429
6	.1132	.1494	.1132	.0377		.3077	.3401
7	.1132	.1494	.1509	.0377		.4696	.5182
8	.1698	.168	.1867	.0377		.583	.583
9	.1494	.1867	.168	.0377		.5668	.5992
10	.1494	.168	.1307	.056		.0934	.0747
11	1.0688	1.166	1.0364	.056		.112	.6316
12	.9503	1.1498	1.0688	.056		.112	.6802
13	.7537	.8583	1.004		.056	.112	.6802
14	.779	.7287	.9393	.0934	.0934	.112	.6478
15	.8097	.8421	.8907	.0934	.0934	.112	.6316
16	.8745	.9069	1.1336		.112	.112	.6802
17	1.0688	1.1174			.3077	.1307	.8583
18	1.004	.9717		.0747		.1307	.8583
19	.2054	.168		.0934	.1494	.1509	.1307
20	.168	.1886	.0566	.0747	.1307	.132	.132
21	.1494	.1698	.0566	.0747	.132	.132	.132
22	.1494	.132	.0377	.0754	.132	.1132	.132
23	.1509	.0943	.0377	.0747	.1132	.0943	.1132
24	.0943	.1509	.0943	.0377		.1457	.2267
Max	1.0688	1.166	1.1336	.0934	.3077	.583	.8583
Min	.0943	.0943	.0377	.0377	.056	.0934	.0747
Avg	.3914	.4219	.3608	.0571	.1320	.1875	.4043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 204 / Soni AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1698	.1509	.0377	.1943	.2429	.2429
2	.1886	.1698	.132	.0377	.1943	.2429	.2429
3	.1886	.1698	.132	.0377	.1943	.2429	
4	.1886	.1698	.1509	.0377	.2429	.2753	
5	.1886	.1886	.1509	.0566	.3239	.3239	
6	.2075	.2054	.1886	.0754	.4321	.4534	
7	.2641	.3174	.2641	.0377	.5992	.664	
8	.2987	.2801	.2614	.0566	.6478	.8259	
9	.2987	.2427	.2054	.0377	.6964	.8583	.7287
10	.3174	.2801	.1867		.1307	.0934	.1867
11	.7865	.6964	1.1498	.056	.1494	.0934	.8421
12	.9012	.7611	1.1174	.0373	.1307	.1307	.9069
13	.852	.8907	1.004	.0934	.1494	.1494	.5992
14	.852		.9393	.112	.1307	.168	.6478
15	.8097	.7611	.9878	.112	.1494	.168	.6802
16	.8097	1.0202	1.1336		.1867	.2241	.7611
17	.7373	1.1498			.1867	.2054	1.004
18	.6478	1.1336			.168	.2241	.9069
19	.3734	.2614		.1307	.2427		.168
20	.2614	.2263		.1494	.2054	.1698	.2075
21	.2427	.2075	.0754	.1307	.1886	.1886	.1886
22	.2241	.1886	.0566	.132	.1698	.1509	.1886
23	.1867	.1509	.0377	.132	.1509	.132	.1509
24	.2075	.1698	.1509	.0377	.192	.2267	.2591
Max	.9012	1.1498	1.1498	.1494	.6964	.8583	1.004
Min	.1867	.1509	.0377	.0373	.1307	.0934	.1509
Avg	.4259	.4266	.4238	.0769	.2523	.2806	.4951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 206 / 11kv Karoli AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2452	.2452			.3563	.2915
2	.1886	.2452	.2452			.3563	.2753
3	.1886	.2452	.2452			.3563	
4	.2452	.2452	.2829			.4049	
5	.3018	.2829	.3018			.4858	
6	.3584	.3361	.3584			.7449	
7	.3018	.2614	.3584			.9069	
8	.2829	.2614	.2987			.9878	
9	.2241	.2614	.2987			.9069	.8259
10	.1867	.2614	.2987		.2427	.168	.1867
11	.9012	.6478	1.004		.1867	.1867	.9393
12	.9012	.8907	.8745	.2614	.7449	.2054	.8745
13	.7537	.8097	.8097	.2054	.056	.1867	.8259
14	.7459	.8097	.7449	.2054	.168	.168	.8097
15	.8097	.7611	.8583	.2241	.2427	.168	.8421
16	.8745	.9069	1.0364		.2054	.2614	.9878
17	1.0688	1.0688		.168		.2801	1.085
18	.8745	.9717		.2241	.2241	.3174	.9878
19	.3174	.3174		.2241	.2987	.3772	.3921
20	.3734	.3961		.2241	.2987	.3206	.3961
21	.3174	.3584		.2427	.2829	.2829	.3206
22	.3174	.3395		.2075	.2641	.3018	.3206
23	.2829	.2829		.1886	.2452	.3206	.2452
24	.2263	.2452	.2452			.3077	.3239
Max	1.0688	1.0688	1.0364	.2614	.7449	.9878	1.085
Min	.1867	.2452	.2452	.168	.056	.168	.1867
Avg	.4687	.4771	.5004	.2159	.2662	.3899	.6072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 207 / 11KV Bhose AG Spare
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6518	1.5565	1.6032	.5992	.0943	.132	.132
2	1.668	1.5565	1.587	.5344	.0943	.132	.132
3	1.6518	1.5565	1.587	.5344	.0943	.132	.1509
4	1.6842	1.6518	1.587	.5344	.0943	.132	.1509
5	1.7814	1.7814	1.749	.5506	.0943	.1509	.1509
6	2.2024	1.9204	2.1214	.5992	.0943	.1698	.1698
7	2.4939	2.3482	2.4615	.6316	.1307	.1698	.2075
8	2.4453	2.4006	2.5101	.6316	.1494	.168	.1886
9	2.5263	2.5263	2.3644	.664	.1494	.2054	.1867
10	.1307	.0934	.0934		.1307		.168
11	.168	.0934	.1867	.7202	1.1336		.1867
12	.1867	.168	.1307	.7202	1.1822	1.7814	.1494
13	.168	.1494	.1494	.5992	1.1822	1.7004	.1494
14	.168	.1494	.168	.6964	1.1336	1.5708	.112
15	.1867	.1494	.168	.7287	1.1174	1.5546	.112
16	.1867	.168	.1867		.2591	1.8138	.1494
17	.2427	.168		.4801	.7449	1.749	.1867
18	.2241	.1867		.6401	.1017	1.6032	.1867
19	.2241	.1867	.1509	.112	.1867	.1698	.1867
20	.2614	.1886	.1132	.112	.1867	.1509	.1867
21	.2054	.1698	.132	.0934	.1698	.1698	.1698
22	.2054	.1698	.1132	.0943	.1698	.1509	.1509
23	.1867	.132	.1132	.0943	.132	.132	.1132
24	1.5061	1.3765	1.4413	.6478	.0943	.1509	.132
Max	2.5263	2.5263	2.5101	.7287	1.1822	1.8138	.2075
Min	.1307	.0934	.0934	.0934	.0943	.132	.112
Avg	.9315	.8686	.9417	.5008	.3717	.6404	.1587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 201 / 11 KV Savali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.6413	.5975	.168	.2075	.2012	.1867
2	.5601	.6413	.5914	.168	.1867	.2033	.1867
3	.6413	.5975	.6219	.1478	.168	.2054	.2218
4	.7392	.6348	.7392	.1478	.1663	.2054	.8501
5	.8962	.7167	.8962	.168	.1886	.2218	.8779
6	.9808	.9054	.9694	.168	.1848	.2195	.8779
7	1.39	1.5089	1.419	.1886	.1867	.2241	.9335
8	1.307	1.3443	1.4784	.2263	.2263	.2402	1.0185
9	1.226	1.3203	1.2437	.2241	.2263	.2241	1.0829
10	.1867	.1494	.1867	.1886	.2241	.2263	.1509
11	.1509	.1463	.2241	.462	.7392	.8962	.1867
12	.1494	.1478	.2263	.5487	.7682	.9808	.2218
13	.1509	.1463	.1886	.5601	.7842	.8962	.2614
14	.1494	.1867	.1867	.5175	.7682	.7842	.2427
15	.1509	.1848	.2241	.5228	.8316	.7468	.2241
16	.1867	.1829	.2263		.7842	.7167	.2263
17	.2263	.1867	.2241	.4527	.7392	.7842	.2054
18	.2241	.2218		.4668	.7095	.7468	.2075
19	.2263	.2743		.1867	.2378	.1509	.2241
20	.2241	.2801	.1886	.1886	.2427	.168	.2452
21	.2263	.2743		.2075	.2402	.1867	.2641
22	.2241	.2801	.1509	.2054	.2427	.2263	.2641
23	.1886	.2587	.168	.2263	.2033	.2241	.2614
24	.4024	.5975	.5853	.1886	.2241	.2054	.2263
Max	1.39	1.5089	1.4784	.5601	.8316	.9808	1.0829
Min	.1494	.1463	.1509	.1478	.1663	.1509	.1509
Avg	.4688	.4928	.5398	.2839	.3950	.4119	.402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 202 / 11 KV SAIPRASAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.5041	.7682	.6036	.6535	.7842	.7468
2	.7095	.5093	.7762	.5601	.6413	.7762	.679
3	.7167	.4904	.7655	.5601	.6468	.7316	.679
4	.6653	.4854	.7655	.5281	.6722	.695	.5975
5	.6722	.5093	.7392	.5228	.6979	.6722	.5601
6	.6413	.5041	.6767	.5601	.6468	.5914	.5544
7	.4668	.5093	.5788	.5281	.5975	.5601	.5228
8	.4854	.4854	.6099	.4854	.5658	.462	.5658
9	.4904	.547	.6468	.5281	.5415	.6722	.5975
10	.5041	.7762	.7468	.5729	.6584	.7545	.679
11	.547	1.1203	.9054	.8316	.6908	.8962	.7468
12	.5228	1.0974	.9335	.9335	.8131	1.0185	.7922
13	.5281	1.1203	.9808	.8501	.7682	.9335	.823
14	.4854	1.1088	1.0082	.7842	.7468	.8299	
15	.5658	1.1157	1.0456	.8299	.961	.8962	.9431
16	.5975	1.0829	1.0562		.9709	1.0082	.9709
17	.6224	1.0059	1.0829	.5228	.9511	1.1317	.9979
18	.5601	.9522		.7095	.7842	.8962	.9511
19	.5281	.7762		.6584	.7468	.5975	.9335
20	.5228	.695	.6348	.6584	.7023	.6348	.8299
21	.5093	.8215	.6036	.6602	.7842	.7167	.6283
22	.5281	.8131	.5975	.6722	.8131	.7545	.7095
23	.5041	.7316	.6602	.6602	.7682	.7095	.6413
24	.7392	.5281	.7842	.6722	.6584	.7762	.7842
Max	.7392	1.1203	1.0829	.9335	.9709	1.1317	.9979
Min	.4668	.4854	.5788	.4854	.5415	.462	.5228
Avg	.5772	.7621	.7894	.6475	.7284	.7708	.7362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 203 / 11 KV Savali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2241	.2378	.1867	.1867	.2054	.1867
2	.2241	.1886	.2218	.1886	.1886	.1848	.1867
3	.2075	.1867	.2241	.2054	.1848	.1848	.2218
4	.2033	.1886	.2218	.2054	.2054	.1829	.1848
5	.2241	.2054	.2378	.2075	.2075	.2054	.1829
6	.2378	.2263	.2801	.2241	.2033	.2218	.2241
7	.2427	.2427	.2587	.2241	.1867	.2012	.2218
8	.2054	.2263	.2378	.2075	.1698	.2054	.2054
9	.1886	.2427	.2402	.2075	.2054	.2402	.2054
10	.1867	.2241	.2241	.2614	.2012	.2614	.2427
11	.2075	.2772	.2241	.2801	.2987	.2801	.2263
12	.2054	.3658	.2263	.2641	.2033	.3018	.2218
13	.2263	.3361	.2641	.2772	.2195	.2801	.2427
14	.2241	.3326	.2614	.2987	.2241	.2801	.2452
15	.2263	.3109	.2829	.2829	.2218	.2614	.2241
16	.2263	.3361	.2987		.2195	.2641	.4251
17	.2241	.3475	.2641	.2241	.2241	.2614	.2614
18	.2829	.3547		.2641	.2402	.2987	.2957
19	.3174	.3734		.2801	.3475	.3361	.2801
20	.3395	.3658	.2829	.3018	.3547	.2957	.3018
21	.3361		.2801	.2614	.3292	.2801	.3326
22	.3018	.3142	.2614	.2641	.2772	.2641	.3174
23	.2452	.2743	.2263	.2427	.2614	.2801	.2829
24	.2427		.2587	.2054	.2218	.2218	.2263
Max	.3395	.3734	.2987	.3018	.3547	.3361	.4251
Min	.1867	.1867	.2218	.1867	.1698	.1829	.1829
Avg	.2395	.2793	.2507	.2420	.2326	.2500	.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 204 / BOTHRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8131	.7167	.8316	.7468	.9979	.8501	.9431
2	.8048	.6722	.8048	.7468	.9335	.8413	.8962
3	.7842	.679	.8215	.7167	.9054	.8215	.8962
4	.7762	.6348	.8029	.679	.8589	.8131	.8501
5	.7468	.6413	.7762	.6722	.8131	.8215	.8501
6	.7392	.679	.7316	.6535	.7095	.8131	.8215
7	.6401	.6348	.6283	.6602	.6908	.5975	.7842
8	.6722	.6036	.7842	.7468	.6653	.6219	.7545
9	.8131	.7095	.8316	.7842	.8048	.7762	.8962
10	.7468	.8779	.8589	.8676	.924	.5601	.4904
11	.679	.9709	.9054	.9808	.8413	.5228	.5041
12	.6722	1.0164	.9054	1.0164	1.0456	.4527	.547
13	.6413	1.0059	.9335	.9979	1.0082	.5975	.5175
14	.6722	1.0269	.9335	1.0164	.924	.7468	.7545
15	.7545	.961	.9054	.9808	.9877	.8775	.9709
16	.7468	1.0059	.9054		.7392	.9709	1.1694
17	.7167	.9709	.9335	.8215	.8215	.9054	.9335
18	.6722	.961		.9054	.8316	.7468	.7545
19	.6413	.7682		.6653	.8413	.8871	.6348
20	.6722	.7392	.5601	.7842	.8589	.8215	.5658
21	.679		.5281	.9054	.8215	.9054	.5121
22	.7095	.7762	.415	.9335	.7682	.9335	.5281
23	.679	.8402	.5975	1.0185	.8686	1.0082	.5487
24	.8402	.7095	.8501	.7922	1.0269	.8589	.9431
Max	.8402	1.0269	.9335	1.0185	1.0456	1.0082	1.1694
Min	.6401	.6036	.415	.6535	.6653	.4527	.4904
Avg	.7214	.8087	.7838	.8301	.8620	.7813	.7528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 205 / 11 KV REX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0269	.9335	.8029	.9335	1.0082	.7316	1.0349
2	1.0269	.9808	.7762	.9335	.9511	.7468	1.0082
3	1.0164	.9808	.7682	.9054	.9431	.7682	.9709
4	1.0374	.9335	.7842	.9054	.8962	.8589	.9431
5	1.0082	.9808	.7762	.8589	.7762	.8871	.9335
6		1.0185	.7842	.8962	.4715	.8962	.8962
7	.9808	.9335	.7023	.9054	.4755	.961	.9054
8	.8962	.9431	.8413	.8676	.5487	1.0349	.8589
9	.8299	.9709	.8402	.8402	.5658	.9335	.8676
10	.7842	1.0456	.9054	.961	.7095	.9808	.8131
11	.7545	1.1088	.9335	1.0185	.7762	1.0082	.9054
12	.8589	1.1088	1.0082	.9709	.695	1.0562	.961
13	.9808	1.0974	1.1317	.9425	.6908	.9709	1.0082
14	.9335	1.0829	1.1576	.9335	.6653	.9335	1.0562
15	.9808	.961	1.0562	.9431	.695	.9808	1.094
16	.9709	.7682	.9808		.7023	.9709	1.1317
17	1.0185	.9709	1.0082	.4066	.7095	.9709	1.0719
18	.9709	.961		.5228	.6468	.9335	1.0829
19	.9808	.7682	.2641	.9431	.695	.961	.9877
20	.8962	.6653	.2614	.924	.7468	.9335	1.0349
21	.8299	.7468	.2829	.9054	.7095	.9808	1.094
22	.8676	.7392	.3018	.9149	.6401	1.0456	1.1203
23	.8962	.7682		.9431	.7392	.9335	1.1088
24	1.0456	.9431	.7947	.9808	1.0349	.7468	1.1088
Max	1.0456	1.1088	1.1576	1.0185	1.0349	1.0562	1.1317
Min	.7545	.6653	.2614	.4066	.4715	.7316	.8131
Avg	.9388	.9338	.7801	.8851	.7288	.9260	.9999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 208 / 11KV KANADWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.132	.2012	.1698	.1867	.1829	.1307
2	.1867	.1307	.1867	.1307	.1886	.1867	.1509
3	.1663	.132	.1848	.1307	.168	.1848	.1494
4	.1698	.1307	.1829	.1509	.1646	.168	.1294
5	.1663	.1509	.1494	.132	.1478	.1646	.1307
6	.1494	.168	.1478	.1494	.1307	.168	.1109
7	.132	.0754	.1307	.1494	.1478	.1294	.112
8	.1109	.0747	.1294	.1698	.1307	.1307	.1509
9	.0934	.0934	.112	.1848	.0914	.1109	.168
10	.132	.1848	.1132	.1886	.112	.1494	.1509
11	.1494	.1867	.1307	.168	.1109	.1698	.132
12	.1509	.1829	.1294	.1478	.1494	.1867	.1478
13	.112	.1867	.1463	.1463	.1494	.1698	.168
14	.1132	.1848	.1494	.132	.1478	.1494	.1509
15	.112	.1646	.1886	.132	.1463	.1698	.1663
16	.0943	.1478	.2241		.1478	.168	.1494
17	.0934	.1867	.1886	.1509	.1494	.1494	.1698
18	.1132	.1848		.1494	.1478	.1698	.1478
19	.112	.1829		.1132	.1463	.168	.1307
20	.1886	.1109	.1494	.1294	.1463	.1663	.1509
21	.1867	.1307	.168	.132	.2241	.1867	.1663
22	.1698	.1848	.1886		.2218	.2075	.1886
23	.1494	.2012	.1494	.168	.2012	.2054	.2075
24	.2096	.132	.2033	.168	.2012	.2033	.1509
Max	.2096	.2012	.2241	.1886	.2241	.2075	.2075
Min	.0934	.0747	.112	.1132	.0914	.1109	.1109
Avg	.1437	.1517	.1615	.1497	.1566	.1686	.1504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 201 / 11 KV malgaon Gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.6099	.6219	.5415	.5544	.499	.5544
2	.5914	.6099	.6099	.5228	.462	.499	.5415
3	.5975	.6099	.5788	.5228	.462	.499	.5228
4	.6161	.6099	.5788	.5359	.462	.5544	.5228
5	.6161	.6283	.5914	.5544	.462	.5544	.5175
6	.6036	.6468	.6401	.5853	.462	.6099	.5544
7	.567	.5914	.6584	.5316	.5544	.6099	.6036
8	.6219	.6099	.5853	.4938	.5544	.5487	.6219
9	.5121	.6219	.6401	.5249	.5487	.5487	.6036
10		.6401	.6653	.543	.5121	.567	.5121
11		.695	.6838	.543	.5853	.6036	.5544
12		.6219	.6653	.543	.567	.6767	.6099
13		.5914	.7207	.5792	.6219	.6401	.6099
14		.5304		.5792	.5121	.6219	.6036
15		.5304	.7316	.543	.567	.5973	.6201
16	.7762	.5487	.7133		.567	.6584	.6584
17	.6401	.6283			.6401	.7133	.6767
18	.695	.7207		.7783	.7133	.7947	.6401
19	.6767	.7682	.8316	.8316	.7392	.8871	.8131
20	.8686	.8779	.8501	.8316	.8316	.8501	.924
21	.8131	.8686	.7207	.7762	.7762	.7762	.8501
22	.7762	.8402	.6722	.7392	.7392	.7282	.7947
23	.7207	.6908	.6535	.6468	.6468	.6535	.6535
24	.6099	.6283	.6468	.5415	.5914	.5175	.5544
Max	.8686	.8779	.8501	.8316	.8316	.8871	.924
Min	.5121	.5304	.5788	.4938	.462	.499	.5121
Avg	.6618	.6550	.6695	.6040	.5888	.6337	.6299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 202 / 11 KV Cannal AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.724	.7049		.7773	.9602	.852
2	.6668	.724	.6668		.7287	.9389	.9503
3	.6668	.724	.6097		.7287	.9175	1.0364
4	.6859	.724	.6097		.7287	1.0526	1.0322
5	.7049	.7621	.6478		1.3765	1.2631	1.065
6	.7049	.8573	.724		1.5384	1.5684	1.5384
7	.6668	.9145	.8192		1.6194	2.2939	1.8404
8	.743	.8764	.8383		1.9433	2.3922	2.1348
9	.8192	.8764	.743		1.866	2.2885	2.2184
10		.8573	.6478			.4001	.362
11		2.6063	2.8306	.4763		.6097	1.6762
12		2.7808	2.6558		.5335	.6668	2.2024
13		2.7199	1.3599	.5335	.6097	.6859	1.7341
14		2.2245	2.625	.5525		.6859	1.9919
15		1.531	2.7808	.5716		.6859	2.1956
16	2.7854	2.6882	2.3929			.7049	2.3594
17	2.7349	2.6246			.724	.8383	1.8501
18	2.9007	2.484		.5716	.7621	.8764	1.5623
19	.9526	.8192		.5716	.8002	.8764	.8002
20	1.0098	.9145		.5716	.8573	.8383	.8954
21	.9526	.8573		.5716	.6668	.7621	.7811
22	.8383	.7811		.5716	.6859	.6668	.6859
23	.7811	.7621		.5525	.6097	.6097	.6097
24	.6859	.743	.724	.1524	.8421	.8402	.7712
Max	2.9007	2.7808	2.8306	.5716	1.9433	2.3922	2.3594
Min	.6668	.724	.6097	.1524	.5335	.4001	.362
Avg	1.1103	1.3574	1.3165	.5179	.9683	1.0176	1.3811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV MALGAON

Feeder No / Name : 203 / 11KV RAMNAGAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4586	.5281	.2915	.0762	.0762	.1143
2	.4687	.4586	.5571	.2915	.0572	.0762	.1143
3	.4744	.4586	.5571	.3201	.0572	.0762	.1143
4	.5182	.5535	.6241	.3521	.0572	.0762	.1143
5	.8223	.7202	.8962	.3479	.0572	.1143	.1334
6	1.0595	.8802	.9646	.3906	.0572	.1143	.1524
7	1.2323	1.2176	1.0936	.5218	.0762	.1334	.1715
8	1.3125	1.2967	1.2342	.5761	.0572	.0953	.1334
9	1.2967	1.2643	1.0494	.6316	.1143	.1143	.1524
10		.1524	.1143	.1905	.1143	.1143	.1905
11		.1715	.1524	.6802	.5312	.7562	.0953
12		.1524	.1334	.7287	.6249	1.0364	.1143
13		.1524	.1334	.6478	.68	1.0437	.0953
14		.1524	.1143	.6478	.68	1.065	.1143
15		.1524	.1143	.6478	.6874	1.0082	.1143
16	.1905	.1524	.1524		.7407	1.012	.1143
17	.2286	.1715			.6481	1.0082	.1524
18	.2477	.1905		.4696	.6481	.9831	.2096
19	.2477	.2096	.1334	.2286	.1334	.1334	.1524
20	.2667	.2286	.1334	.1905	.1334	.1524	.1905
21	.2667	.2096	.1143	.1905	.1143	.1524	.1715
22	.2286	.1905	.1143	.1524	.1143	.1334	.1524
23	.2286	.1905	.1143	.0762	.0953	.1334	.1524
24	.4572	.4531	.4481	.2915	.0762	.0762	.1143
Max	1.3125	1.2967	1.2342	.7287	.7407	1.065	.2096
Min	.1905	.1524	.1143	.0762	.0572	.0762	.0953
Avg	.5558	.4266	.4308	.4030	.2763	.4035	.1389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 201 / 11 KV Sidhewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1509	.1698	.132	.1341	.3601	.2454
2	.1478	.1509	.1698	.132	.1341	.373	.3294
3	.1463	.1509	.1698	.1097	.1341	.39	.4161
4	.1848	.1509	.1886	.1109	.1341	.3768	.463
5	.2075	.1698	.1886	.0934	.16	.4096	.5243
6	.2075	.2263	.2075	.0943		.5571	.5967
7	.168	.2075	.1886	.0934		.6241	.6241
8	.132	.132	.1886	.0924		.4999	.4687
9	.0934	.132	.1509			.4475	.506
10	.132	.1109	.1646			.056	.0886
11	.6019	.8697	.7449		.1267	.0943	.4012
12	.6481	.7099	.8583		.0747	.0943	.4999
13	.6958	.7099	.8421		.0934	.0566	.4843
14	.6249	.6554	.924		.112	.0566	.506
15	.5864	.6636	.8002	.1086	.0934	.0566	.5535
16	.7116	.6481	.8749		.0543	.0739	.6562
17	.7432	.7274		.0934	.0754	.056	.6009
18	.7682			.0943	.0924	.0754	.5693
19	.1698	.2075		.1132	.1132	.1132	.168
20	.2263	.2075		.132	.1509	.1509	.1886
21	.1886	.1886		.132	.132	.1663	.1886
22	.1698	.1698		.1132	.132	.1307	.1698
23	.1509	.1791	.0943	.1132	.1132	.112	.132
24	.132	.1509	.1509	.0747	.1341	.1715	.1734
Max	.7682	.8697	.924	.132	.16	.6241	.6562
Min	.0934	.1109	.0943	.0747	.0543	.056	.0886
Avg	.3320	.3335	.3931	.1078	.1155	.2293	.3981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 202 / 11KV Kalambi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1698	.0566	.132	.1509	.128
2	.1417	.1509	.1698	.0549		.1509	.1478
3	.1478	.1509	.1698	.037	.132	.132	.1886
4	.1509	.1509	.1494	.0377	.132	.1698	.2241
5	.1494	.1509	.1307	.0373	.132	.1698	.2195
6	.1509	.1698	.1509	.0377	.1509	.132	.2402
7	.1509	.1698	.1509	.0373	.1509	.1214	.2402
8	.1791	.1494	.2601	.0373	.1478	.2641	.1294
9	.2601	.213	.3018		.2454	.2572	.2454
10	.2629	.2743	.3185			.2818	.3185
11	.2126	.2374	.3721		.2915	.2229	.3814
12	.2804	.2785	.3944	.132	.2458	.3277	.3224
13	.3012	.2458	.3812	.1109	.2012	.2865	.2033
14	.2658	.2774	.2601	.1612	.2743	.1402	.2172
15	.208	.3121	.2658	.124	.2774	.1949	.2865
16	.2587	.3121	.4115		.124	.181	.2774
17	.1949	.2658		.218	.156	.2835	.3856
18	.2481	.2543		.1753		.1791	.3988
19	.2054	.2195		.3224	.2195	.2172	.2218
20	.2587	.2241		.3077	.2195	.2075	.2241
21	.2263	.2241		.2241	.1829	.1886	.2263
22	.2075	.2263	.0373	.1698	.1698	.1698	.1886
23	.1698	.1791	.0566	.1509	.132	.1509	.1698
24	.1509	.1509	.1509	.0566	.132	.132	.132
Max	.3012	.3121	.4115	.3224	.2915	.3277	.3988
Min	.1417	.1494	.0373	.037	.124	.1214	.128
Avg	.2055	.2141	.2264	.1244	.1833	.1963	.2382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 203 / 11 KV Kalambi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2972	.4062	.0709	.1663	.128	.1294
2	.4115	.2972	.4062	.0716	.1663	.1294	.128
3	.5312	.2972	.4268	.0732	.1663	.1463	.1448
4	.6241	.2972	.4572	.0739	.1663	.1463	.1509
5	.6718	.3864	.503	.0934	.168	.1663	.1646
6	.703	.6097	.5944	.0895	.168	.1663	.1663
7	.743	.7375	.6539	.0886	.1663	.1829	.1646
8	.6516	.6836	.6748	.0867	.1629	.1629	.1991
9	.5735	.6226	.6895		.1791	.2195	.1595
10	.0886		.104		.1267	.1772	.156
11	.1433	.0876	.1254		.3963	.5182	.0503
12	.1075	.1214	.1052		.3765	.4877	.0497
13	.1267	.1214	.1063		.3525	.5201	.048
14	.1086	.0848	.1052	.1612	.2858	.5135	.0701
15	.1448	.1227	.1433	.3475	.3429	.4607	.0526
16	.1646	.1227	.1543		.2641	.5721	.0701
17	.1646	.1387		.2538	.3269	.5569	.0709
18	.2033	.1753		.2606	.3475	.4841	.1791
19	.2012	.192		.124	.1646	.1595	.2218
20	.2241	.2012		.1663	.1949	.1663	.2218
21	.1867	.2033		.168	.1772	.168	.2033
22	.1663	.1663	.0747	.168	.1463	.1387	.1663
23	.1646	.0924	.0905	.168	.1478	.1478	.1463
24	.2778	.2972	.3125	.0732	.1663	.128	.1294
Max	.743	.7375	.6895	.3475	.3963	.5721	.2218
Min	.0886	.0848	.0747	.0709	.1267	.128	.048
Avg	.3217	.2763	.3228	.1410	.2219	.2769	.1351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 201 / 11 KV NARWAD GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0914	.0924	.0934	.0754	.0934	.0934
2	.0754	.0924	.0934	.0747	.056	.0747	.0934
3	.0747	.0934	.0934	.0754	.0566	.0754	.0934
4	.0747	.0934	.0943	.0754	.0566	.0747	.0934
5	.0754	.0924	.1132	.0934	.0747	.0943	.0924
6	.0924	.1109	.112	.0934	.0943	.1132	.0924
7	.1109	.1307	.112	.0943	.0747	.112	.0924
8	.0739	.1132	.0934	.0747	.0754	.0934	.0924
9	.0914	.1132	.0934	.0754	.0747	.0754	.0924
10	.0914		.0934	.056	.0747	.0754	.0934
11	.0914		.0943	.0377	.0754	.0943	.0943
12	.0914		.112	.056	.0747	.1132	.0934
13	.0914		.112	.0754	.0754	.132	.0943
14	.0914		.132	.0747	.0754	.112	.0934
15	.0914		.1132	.0754	.0747	.112	.1132
16	.1448		.112		.0747	.1132	.1307
17	.1629			.0934	.0754		.132
18	.128	.1307		.132	.0943	.132	.112
19	.1663				.1307	.1509	.1509
20	.1663			.168	.168	.1886	.168
21	.1463	.1629	.132	.168	.1509	.1698	.1698
22	.1307	.1086	.1132	.1132		.1509	.1307
23	.112	.0924	.112	.0934		.0943	.1132
24	.0943	.0924	.0924	.0943	.0754	.0943	.0943
Max	.1663	.1629	.132	.168	.168	.1886	.1698
Min	.0739	.0914	.0924	.0377	.056	.0747	.0924
Avg	.1060	.1084	.1058	.0903	.0845	.1104	.1091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 202 / 11 KV GAYRANWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.1132		.1898	.4321	.3841
2	.0943	.0943	.1132		.1781	.4858	.3841
3	.0934	.0914	.0934		.16	.5992	.427
4	.0934	.0914	.1132		.16	.6401	.4586
5	.0943	.1097	.1307		.1943	.7202	.4586
6	.1132	.1254	.1494		.2267	.7682	.5121
7	.1307	.1075	.168		.2401	1.0526	.4801
8	.1294	.1494	.1494		.2401	1.085	.6722
9	.1267	.1478	.168		.2915	1.0082	1.0402
10	.1267	.1478	.1698		.0377	.0747	.7611
11	.1267	1.7444	1.7652		.0373	.0934	1.0082
12	.1267	1.7284	1.8187			.0934	1.0364
13	.1267	1.5524	1.7695	.0934		.0934	1.1523
14	.1267	1.6324	1.8623	.0189	.056	.0934	1.1984
15	.1267	1.8244	1.6484	.0373	.0566	.0934	1.2163
16	1.7444	1.8299	1.6324		.0754	.112	1.247
17	1.8084	1.6842			.0747		1.3279
18	1.5023	1.6032		.0373	.0754	.056	.0934
19	.1494	.1663			.6401	.0934	.1509
20	.168	.168		.0373	.132	.112	.1494
21	.132	.1307		.0377	.112	.0934	.1509
22	.132	.1307		.0377		.0934	.132
23	.1307	.112		.0187		.0747	.1307
24	.132	.112	.112		.1509	.3681	.3681
Max	1.8084	1.8299	1.8623	.0934	.6401	1.085	1.3279
Min	.0934	.0914	.0934	.0187	.0373	.056	.0934
Avg	.3179	.6491	.7045	.0398	.1664	.3624	.6225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 203 / 11 KV BHAVANI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1132	.132		.6958	.6325	.6964
2	.112	.112	.132		.6562	.6958	.6964
3	.1132	.112	.1307		.6249	.7522	.7202
4	.1132	.1132	.1494		.6325	.8223	.7682
5	.112	.112	.1509		.6958	.8802	.8322
6	.1307	.1132	.1886		.7655	.9922	.9717
7	.1509	.132	.1698		.8855	1.2176	.8097
8	.1307	.1494	.1867		1.0623	1.1702	
9	.1132	.1494	.1886		1.1111	1.1069	
10	.112	.1307	.168		.0747	.0943	
11	.112	1.9433	1.9757		.0754	.0943	1.4723
12	.112	1.9433	1.9919	.0747		.1132	1.5708
13	.112	1.9271	1.8351			.132	1.6004
14	.112	1.9919	1.8084		.0943	.132	1.5971
15	.112	1.9524	1.7652		.0943	.1509	1.6446
16	1.7394	1.8724	1.9685		.1307	.1509	1.6762
17	1.8185	1.8244			.132		1.692
18	1.7444	.2075			.1307	.1132	.0747
19	.1509	.2263			.6722	.132	.1509
20	.1886	.2075			.1509	.1509	.168
21	.1698	.1886			.1494	.132	.1698
22	.1698	.1698				.1132	.1509
23	.1509	.1509				.0943	.1307
24	.132	.132	.1509		.5535	.5601	.6718
Max	1.8185	1.9919	1.9919	.0747	1.1111	1.2176	1.692
Min	.112	.112	.1307	.0747	.0747	.0943	.0747
Avg	.3343	.6656	.7701	.0747	.4694	.4536	.8698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 201 / 11 KV Anjani AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.0457	.061	.4167	.3479	.4687	.0625
2	.064	.0457			.3521	.4572	.0633
3	.064	.0625			.3521	.4816	.0633
4	.0791	.08	.0914	.4475	.4001	.5335	.08
5	.0972	.0949	.112	.4744	.4696	.5647	.1134
6	.1147	.1457	.1739	.5281	.4607	.6171	.1638
7		.1107	.16	.5053	.7773	.7579	.1423
8	.125	.144	.1619	.5868	.884	1.0185	.144
9	.1235	.1235	.1372	1.0269	.9259	.9755	.128
10	.1014	.1174	.1355	.0676			.1067
11	.9374	1.0623	1.0526	.0753	.0949	.112	1.1728
12	.8215	1.0608	1.0031		.0926	.112	1.0536
13	.7095	.9267	.9065	.0594	.0753		1.0105
14	.4572		.9481	.0678	.0572		.8429
15	.5053			.0937	.0762	.0903	.6573
16	.5428	.9783		.0781	.0762	.0926	.8278
17	.6171	.7506		.0937	.1067	.0926	.9145
18	.6908	.7573			.112	.1406	.7727
19	.0781	.1265	.0949	.1406	.1423	.1406	
20	.1134	.1581	.1107		.1423	.1581	.144
21	.0949		.0781		.125	.1423	.1265
22	.0781			.0926	.112	.1265	.0937
23	.064	.0926	.0633		.0972	.1107	.096
24	.0633	.0625	.0791	.4531	.3163	.4115	.0791
Max	.9374	1.0623	1.0526	1.0269	.9259	1.0185	1.1728
Min	.0633	.0457	.061	.0594	.0572	.0903	.0625
Avg	.2872	.3473	.3158	.3063	.2868	.3621	.3852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 202 / 11 KV Bastavade Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4534	.4816	.4858	.1494	.1509	.1886	.5601
2	.4481	.4755			.1509	.1886	.5668
3	.4481	.4633			.1509	.1886	.5668
4	.4858	.5201	.7522	.1698	.1698	.2263	.6478
5	.5506	.6241	.9282	.1886	.2241	.2829	.7287
6		.8993	.9717	.2402	.3361	.3395	.7842
7	1.166	1.1561	1.1469	.2829	.3326	.3174	1.1523
8	1.0486	1.2193	1.0536	.362	.2957	.2218	1.1683
9	.9717	.6706	1.0595	.2033	.1478	.2241	1.1363
10	.1578	.1448	.1227	.2402	.2195		.1791
11	.1494	.2075	.1869	1.2163	1.2037	1.2803	.1463
12		.1848	.1867		1.0385	1.2163	.1629
13		.1494	.1867	1.0562	.8802		.1646
14			.1663	.6722	.7287		.1629
15	.1109			.7362	.7716	.9442	.1463
16	.1307	.168		.9442	.8802	.9922	.181
17	.1478	.1494		.6882	1.0269	1.1683	.1829
18	.1646	.2378			.8762	1.0242	.2587
19	.2172	.2427	.1867		.2303	.2614	.2926
20	.2402	.299	.2427		.2587	.2829	.2957
21	.2241		.2241		.2427		.2743
22	.2241				.2427		.2534
23	.1867	.1848	.168		.2075	.1886	.2561
24	.4588		.4458	.1494	.1886	.1886	.4961
Max	1.166	1.2193	1.1469	1.2163	1.2037	1.2803	1.1683
Min	.1109	.1448	.1227	.1494	.1478	.1886	.1463
Avg	.3992	.4462	.5009	.4866	.4565	.5118	.4485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 203 / 11 KV Dongarsoni AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.2651	.1392	.2641	.2641	.3174	1.2803
2	1.3108	1.2803			.2452	.3174	1.2955
3	1.326	1.3123			.2452	.3547	1.2955
4	1.3272	1.4998	1.6194	.3206	.3395	.4715	1.3765
5	1.2963	1.6644	1.9595	.3961	.4668	.6036	1.587
6	1.9919	2.0645	2.2672	.4338	.7577	.7545	1.9757
7		2.2708	2.4453	.4338	.5729	.4854	2.2405
8	1.7976	2.3922	2.6686	.4108	.499	.4668	2.2885
9	1.5684	1.6604	2.7694	.3109	.4066	.3734	2.0165
10	.1715	.2303	.2401	.2561	.2481		.2058
11		.2561	.3439	1.8404	2.2283	2.4166	.2629
12		.3045	.2715		2.2024	2.2085	.2279
13	.2035	.2804	.2865	1.5524	1.9685		.2561
14	.1928		.2481	1.5203	1.6872		.2353
15	.197			1.3763	1.656	1.6324	.2378
16	.2126	.2715		1.6484	1.7711	2.1605	.3077
17	.3511	.4805		1.7764	1.9364	2.2885	.4835
18	.439	.6535			1.9044	2.1285	.5611
19	.5975	.6468	.5228		.6348	.7282	.7682
20	.5788	.5806	.4481		.6348	.6602	.7023
21	.4904		.5228		.4854		.5121
22	.3921			.3961	.415		.4115
23	.3361	.3142	.2614		.3423	.3395	.4115
24	1.3108	.4902	1.326	.2614	.2829	.3174	1.2163
Max	1.9919	2.3922	2.7694	1.8404	2.2283	2.4166	2.2885
Min	.1715	.2303	.1392	.2561	.2452	.3174	.2058
Avg	.8279	.9959	1.0788	.8249	.9248	1.0013	.9232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 204 / 11 KV Jarandi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.5792	.4744		.1134	.1147	.4801
2	.3887	.5639			.0972	.112	.4801
3	.3841	.5498			.0972	.108	.4744
4	.4428	.6481	.6401	.1638	.1475	.16	.5535
5	.5312	.945	.8259	.1989	.1966	.1943	.4458
6	.8684	1.1265	1.0526	.2006	.2785	.2622	.9231
7		1.186	1.0526	.213	.2429	.3113	1.1498
8	1.012	1.0936	1.1069	.2241	.2267	.2458	1.2323
9	.9686	.587	1.1437	.2489	.1635	.2267	1.2003
10	.0949	.1107	.1067	.2054	.2134		.0937
11	.1457	.144	.1296	1.1363	1.2334	1.3283	.1781
12			.096			1.186	.1619
13	.0926	.1235	.1457	1.0883	.884		.1638
14	.0949		.1296	.8025	.9181		.1265
15	.1134			.8436	.9031	.823	.1265
16	.1296	.1296		1.0311	.7621	.9998	.1943
17	.1781	.2241		1.0155	1.1728	1.2163	.1943
18	.208	.2561			.945	1.1203	.3041
19	.2721	.2753	.1898		.2401	.2591	.3563
20	.2429	.2753	.1802		.2721	.2753	.2984
21	.1943		.1781		.2401		.2241
22	.2105			.1802	.1943		.2105
23	.1619	.1619	.1107		.1475	.1619	
24		.4784	.463	.1094	.1296	.1296	.4481
Max	1.012	1.186	1.1437	1.1363	1.2334	1.3283	1.2323
Min	.0926	.1107	.096	.1094	.0972	.108	.0937
Avg	.3392	.4978	.4721	.5108	.4269	.4860	.4357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 205 / 11 KV Savalaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4294	.3961	.3734	.3961	.3921	.3961
2	.3696	.4108			.3772	.3921	.3772
3	.3734	.415			.3772	.3921	.3772
4	.3881	.4527		.3772	.415	.4294	.415
5	.4251	.5041	.5093	.3969	.4668	.4668	.4668
6	.5487	.5601	.5658	.4435	.5544	.5415	.5544
7		.5228	.5847	.4435	.5175	.5175	.5175
8	.4207	.439	.4207		.4251	.3841	.4251
9	.4119	.3582	.3982	.3734	.3326	.3475	.4066
10	.3582	.3189	.3761	.4854	.3721		.4024
11		.3982	.4207	.4481	.4344	.3881	.394
12	.394	.362	.4207		.4119	.4066	.3982
13	.3801	.4024	.4207	.4294	.4298		.3582
14	.3696		.4251	.4481	.439		.4163
15	.3881			.4435	.4344	.3841	.439
16	.3881	.4024		.4251	.4477	.3841	.3982
17	.3881	.4344		.4435	.4344	.3841	.4298
18	.4344	.443			.4119	.439	.4163
19	.5304	.543	.6036	.4668	.5359	.5544	.5853
20	.6838	.695	.5853		.6468	.7095	.724
21	.6283		.5914		.5788	.6036	.6268
22	.5914			.547	.5415		.5611
23	.4854	.4854	.4303		.4527	.4715	.4755
24	.4163	.4481	.4251	.4108	.415	.4108	.415
Max	.6838	.695	.6036	.547	.6468	.7095	.724
Min	.3582	.3189	.3761	.3734	.3326	.3475	.3582
Avg	.4427	.4512	.4734	.4347	.4520	.4499	.4573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 207 / 11 KV Savlaj Water Supply NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0151	.0145	.0156	.0152	.0149	.0791	.0149
2	.0152	.0141			.0152	.0762	.0152
3	.0152	.0152			.0152	.0655	.0152
4	.0154	.0145	.0145	.0154	.0152	.081	.0312
5	.0151	.0145	.0152	.0305	.0156	.0655	.0312
6	.0147	.0143	.016	.0158	.0312	.0663	.0312
7		.0147	.0158	.0154	.032	.0305	.0312
8	.0151	.0145	.016	.0158	.032	.1017	.0312
9	.0149	.0137	.0158	.016	.016	.1017	.0312
10	.0232	.0088	.0158	.016	.0301		.0617
11	.0297	.017	.0152	.016	.0164	.0343	.0602
12		.0152	.0152		.0164	.0152	.0594
13	.0137	.0154	.0158	.0158	.0162		.0301
14	.0267		.0158	.0158	.081		.0297
15	.0137			.0158	.0648	.0305	.0602
16	.0101	.0153		.0158	.0648	.0152	.0594
17	.0158	.0158		.0158	.08	.0305	.0903
18	.0143	.0156			.032	.0305	.0602
19	.0152	.0158	.0158		.0337	.0312	.0594
20	.0147	.0158	.0158		.032	.0156	.061
21	.0137		.0158		.0617		.0617
22	.0131				.0781		.061
23	.0137	.0006	.0152		.0791	.0149	.0617
24	.0152	.0139	.0158	.0149	.0149	.0972	.0149
Max	.0297	.017	.016	.0305	.081	.1017	.0903
Min	.0101	.0006	.0145	.0149	.0149	.0149	.0149
Avg	.0161	.0140	.0156	.0167	.0370	.0517	.0443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 209 / 11 KV Savlaj Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2801	.2801	1.1336	1.0526	1.0562	.2829
2	.2587	.2614			1.0526	1.0562	.2641
3	.2534	.2614			1.0526	1.0753	.2641
4	.3582	.3395	.3772	1.3426	1.1336	1.4373	.2641
5	.4024	.415	.4338	1.3117	1.3765	1.6518	.3734
6	.5068	.5658	.5658	1.3525	1.5684	1.8023	.5359
7		.5041	.5093	1.5364	1.9204	2.0891	.5175
8	.3582	.4294	.4668	1.5023	2.0485	2.1052	.4805
9	.3658	.3109	.3734	1.4737	1.8884	1.9044	.4251
10	.2743	.3189	.4108	.1663	.2534		.3734
11	1.8679	1.7814	2.1214	.2402	.2587	.2801	2.2725
12		1.7185	1.9919		.3174	.3142	2.0317
13	1.7078	1.5741	1.7924	.2772	.2772		1.8564
14	1.4217		1.5655	.2427	.2743		1.3763
15	1.3916			.2801	.2926	.2772	1.4575
16	1.6164	1.5971		.3361	.3475	.2772	1.6385
17	1.5971	1.5655		.3547	.439		1.8785
18	1.4784	1.6324			.4251	.4805	1.8244
19	.4854	.4294	.3921		.5041	.4435	.4534
20	.4668	.5041	.4668		.5228	.4668	.4915
21	.3921		.3177		.4668		.421
22	.3921				.3921		.3582
23	.2987	.3265	.2801		.3361	.3206	.3292
24	.2534	.2801	.2801	1.21	.9878	1.0202	.3018
Max	1.8679	1.7814	2.1214	1.5364	2.0485	2.1052	2.2725
Min	.2534	.2614	.2801	.1663	.2534	.2772	.2641
Avg	.7456	.7548	.7427	.8507	.7995	1.0032	.8530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 201 / 11 KV Manerajuri Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203		1.2955	1.0031	.4344	.4557	.5316
2	1.0623	1.0688	1.3603	1.1305	.4252	.4525	.5316
3	1.0279	1.0814	1.4232	1.0595	.4207	.4835	.5487
4	1.0486	1.1736	1.5074	1.1561	.4656	.5258	.6335
5	1.3923	1.2498	1.5203	1.2643	.5316	.691	.7316
6	1.6288	1.8785	1.8138	1.4582	.724	.8059	.823
7	1.9595	2.2024	2.1125	1.5546	.7186	.8688	.7316
8	2.1605	2.0271	2.1376	1.5466	.7087	.6733	.6401
9	1.8461	2.1247	2.0325	1.6324	.5731	.7164	.695
10	.3582	.3361	.3982	.3189	.4908	.6697	.6908
11	.4854	.5373	.4075	1.5684	1.9044	2.0309	.5434
12	.4108	.5138	.4161	1.5813	1.6032	2.0424	.5792
13	.3772	.4835	.4525	1.4083	1.7284	1.9528	.5201
14	.4024	.5068	.4656	1.442	1.6604	1.8343	.5493
15	.4294	.4938	.4733	1.4403	1.6484	1.7985	.591
16	.4938	.5544	.5493	1.5623	1.9757	2.1052	.5959
17	.5487	.4477	.5028	1.5223	2.1285	2.1464	.7265
18	.7682	.691		1.3916	1.9925	2.2045	.8238
19	.8048	.7973		.6379	.7783	.5407	.7964
20	.7468	.7964	.4961	.724	.7362	.7796	.7975
21	.6859	.7973	.4508	.6485	.7421	.7087	.7796
22	.6613	.7343	.5249	.5731	.6733	.7133	.6805
23	.5144	.6878	.4557	.543	.591	.5935	.6154
24	1.166	1.0936	1.2003	1.0082	.4961	.5138	.5144
Max	2.1605	2.2024	2.1376	1.6324	2.1285	2.2045	.8238
Min	.3582	.3361	.3982	.3189	.4207	.4525	.5144
Avg	.9208	.9686	.9998	1.1740	1.0063	1.0961	.6529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 202 / 11 KV Yogewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2401	.2303	.0543	.6802	1.2308	.7811
2	.2686	.2561	.2195	.0716	.6722	1.1633	.8697
3	.2481	.2481	.2149	.1052	.68	1.0753	.9326
4	.2507	.3292	.2303	.0867	.7773	1.0402	.9831
5	.3439	.3841	.3439	.1254	.8002	1.004	1.0898
6	.4298	.4344	.4784	.1448	.9069	1.0722	1.0669
7	.4344	.439	.5194	.1595	1.1702	1.3283	1.3748
8	.443	.4024	.5316	.156	1.2803	1.0202	1.5238
9	.4835	.3658	.5792	.1448	1.4899	1.1683	1.4419
10	.3801	.2561	.5373		.2126	.2715	.2743
11	1.4022	1.5339	1.3443		.2507	.2561	1.1843
12	1.4632	1.3123	1.5154		.3077		1.2651
13	1.2654	1.2334	1.4198		.2835	.3018	1.2037
14	1.3435	1.1843	1.4582	.2835	.2658	.2926	1.2955
15	1.4232	1.2643	1.4089	.362	.2896	.2926	1.2452
16	1.1469	1.3279	1.278	.3506	.3224	.3174	1.2643
17	1.326	1.0753	1.3603	.3189	.3898		1.2018
18	1.3763	1.4413		.2454	.4298	.5304	.9877
19	.3292	.4706		.3582	.4706	.5601	.4298
20	.3734	.4477		.3898	.4298	.5121	.5083
21	.3658	.4252		.3544	.3982	.4572	.4706
22	.3475	.4024	.0537	.2804	.3224	.4024	.3467
23	.2926	.3582	.0526	.2658	.2534	.3125	.3012
24	.3403	.2614	.2454	.052	.6081	.6722	.7712
Max	1.4632	1.5339	1.5154	.3898	1.4899	1.3283	1.5238
Min	.2481	.2401	.0526	.052	.2126	.2561	.2743
Avg	.6835	.6706	.7011	.2155	.5705	.6946	.9506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 203 / 11 KV Bhosalenagar Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.3077	.3366	.1734	.7499	1.2163	.8886
2	.3366	.2915	.3292	.2149	.7682	.1619	.8592
3	.3045	.3109	.3224	.1928	.7907	1.0753	.9488
4	.2804	.3366	.3077	.2303	.8745	1.0311	1.0526
5	.3439	.4024	.3721	.2715	.9602	1.2163	1.1469
6	.3582	.4755	.4572	.2454	1.2146	1.2651	1.2498
7	.3982	.5487	.5249	.2774	1.5546	1.4413	1.4685
8	.4656	.5121	.6219	.3224	1.6872	1.247	1.5242
9	.4207	.6219	.5731	.3801	1.9109	1.5238	1.6156
10	.4252	.3921	.543	.4207	.2454	.3077	.2926
11	1.6156	1.7124	1.704	.3544	.3761	.3012	1.6221
12	1.6404	1.2631	1.7284	.3258	.3366	.3292	1.6446
13	1.4632	1.2163	1.8084	.2658	.3582	.3734	1.5154
14	1.4998	1.2146	1.7236	.2629	.362	.4207	1.4403
15	1.5655	1.4243	1.8461	.3189	.3721	.3898	1.4506
16	1.7814	1.491	1.7185	.3856	.5014	.4572	1.5813
17	1.6613	1.2163	1.7284	.3544	.5973	.5487	1.656
18	1.6716	1.7236		.3982	.6268	.7282	1.7924
19	.695	.5316		.3658	.5853	.7842	.4557
20	.6535	.5068		.3898	.5138	.7316	.5249
21	.5373	.4835	.2481	.3582	.4706	.6401	.4508
22	.4525	.4557	.2353	.3155	.4344	.4572	.443
23	.3658	.4298	.1753	.2686	.3898	.3734	.3982
24	.3801	.3361	.3801	.1991	.6401	.9069	.8619
Max	1.7814	1.7236	1.8461	.4207	1.9109	1.5238	1.7924
Min	.2804	.2915	.1753	.1734	.2454	.1619	.2926
Avg	.8198	.7585	.8421	.3038	.7217	.7470	1.1202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 204 / 11 KV Manerajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2054	.1848	.1991	.1829	.1663	.2195
2	.1663	.2054	.168	.1848	.1867	.1698	.2195
3	.168	.2012	.1509	.2012	.1848	.1494	.2195
4	.1509	.2172	.1494	.1698	.1829	.1494	.2241
5	.1478	.2172	.1698	.1867	.1867	.1698	.2195
6	.2054	.2353	.2033	.1991	.2241	.2033	.2195
7	.2075	.2058	.2402	.2195	.1848	.2241	.2427
8	.1848	.2378	.2801	.4527	.2241	.1848	.2427
9		.2743	.2641	.5175	.2614	.4481	.4854
10	.2241	.2195	.2957	.4024	.4805	.2641	.2614
11	.4755	.2218	.4207	.4527	.4207	.3734	.3982
12	.3734		.4904	.4108	.5228	.4854	.4854
13			.4481	.2241	.2587	.3658	.4024
14	.2743	.2926	.4163	.2957	.2829	.2987	.3018
15	.2743	.197	.4805	.3696	.2772	.2987	.4066
16	.4024	.2427	.5487	.4481	.4854	.2987	.4344
17	.3658	.2452	.5281	.462	.3511	.2957	.4755
18	.362	.2587		.3734	.4294	.2987	.5281
19	.4755	.2987		.4527	.5658	.4108	.5914
20	.4108	.3142	.3326	.5228	.4435	.3429	.6722
21	.362	.3361	.2829	.4854	.3361	.2835	.5792
22	.362	.3018	.2987	.3772	.2957	.2401	.3772
23	.2743	.2772	.2561	.2614	.2829	.2378	.2561
24	.2263	.2195	.2241	.2241	.1848	.2054	.2378
Max	.4755	.3361	.5487	.5228	.5658	.4854	.6722
Min	.1478	.197	.1494	.1698	.1829	.1494	.2195
Avg	.2855	.2466	.3106	.3372	.3098	.2735	.3625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 205 / 11 KV AG LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0354		.0354	.0362	.0377
2	.0366	.0351	.0358	.0701	.0716	.0732
3	.0532	.0537	.052	.0686	.0876	.0747
4	.0532	.0905	.0709	.0701	.0895	.0747
5	.0549	.0914	.0905	.0693	.0886	.0732
6	.0549	.0895	.0876	.0709	.0905	.0754
7	.0732	.0886	.0895	.0701	.0886	.0732
8	.0549	.0876	.0914	.0693	.0876	.0732
9	.0566	.0895	.0905	.0701	.0886	.0747
10	.0549	.0886		.0709	.0537	.0732
11	.0358	.0914		.0895	.0914	.0914
12	.0358	.0886		.0886	.0914	.0895
13	.0366	.0895	.0709	.0905	.0934	.0924
14	.0354	.0905	.0876	.0886	.0914	.0905
15	.0358	.0914	.0895	.0876	.0934	.0886
16	.0886	.0886	.0876	.0709	.0934	.0895
Max	.0886	.0914	.0914	.0905	.0934	.0924
Min	.0189	.0351	.0358	.0354	.0362	.0377
Avg	.0487	.0806	.0787	.0738	.0836	.0778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 206 / 11 kv Yogewadi Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.181	.168		.1848	.2033	.2054
2	.168	.181	.1646		.1829	.168	.2054
3	.1478	.1829	.1478		.1867	.1509	.2263
4	.1509	.2054	.1494		.1848	.1509	.2241
5	.1494	.2241	.1848		.2054	.1848	.2378
6	.2587	.2561	.2641		.2402	.2614	.2561
7	.2641	.2195	.2241		.2195	.2218	.2195
8	.1867	.2195	.1886		.1867	.1698	.2427
9	.2263	.2378	.4251		.2218	.2054	.4668
10	.3326	.1867	.547	.0724	.3326	.6283	.0857
11	.4572	.2054	.4338		.3395	.6535	.6348
12	.4527	.2218	.4572		.4066	.6535	.7316
13	.3841	.1867	.5041	.3921	.1494	.5601	.4706
14	.3475	.1478	.4706	.3395	.1663	.3734	.3018
15	.2743	.4338	.5175	.4108	.1886	.3734	.5914
16	.4572	.3881	.8048	.415	.3881	.4108	.695
17	.3658	.168	.6335	.3361	.3547	.5601	.6908
18	.3475	.1663		.3018	.3395	.5975	.7059
19	.2743	.1886		.2614	.4066	.6161	.5175
20	.2534	.2054		.2957	.3395	.5144	.4024
21	.2378	.2218		.2614	.2427	.3658	.3395
22	.2241	.2241	.1646	.2587	.2263	.2378	.2987
23	.1991	.2075	.132	.2241	.2218	.2195	.2172
24	.2241	.181	.2033	.1448	.2241	.2452	.2012
Max	.4572	.4338	.8048	.415	.4066	.6535	.7316
Min	.1478	.1478	.132	.0724	.1494	.1509	.0857
Avg	.2737	.2183	.3392	.2857	.2558	.3636	.3820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 201 / 11 KV WAIFALE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1143	.1143	.1143	.1715	.1143	.1143
2	.1524	.1143	.1143	.1143	.1524	.1143	.1143
3	.1524	.1143	.1524	.1143	.1524	.1143	.1143
4	.1715	.1143	.1143	.1143	.1524	.1143	.1143
5	.1715	.1524	.1143	.1334	.1524	.1524	.1143
6	.1715	.1715	.1524	.2096	.1524	.2096	.1143
7	.1715	.1905	.1905	.1715	.1905	.2096	.1715
8	.1524	.1143	.1905	.1524	.1524	.1524	.1334
9	.1334	.1334	.1524	.1334	.1524	.1334	.1334
10	.1334	.1143	.1334	.1143	.1334	.1143	.1334
11	.1334	.1334	.1334	.0953	.1334	.1143	.1334
12		.1143	.1143	.0953	.1143	.1143	.1143
13		.1143	.1143	.1334	.0953	.1334	.1143
14		.1143	.1143	.1334	.0953	.1334	.1143
15		.1143	.1143	.1143	.1143	.1334	.1143
16	.1334	.1143	.1334	.1524	.1143	.1143	.1143
17	.1334	.1143	.1334	.1334	.1334	.1143	.1334
18	.1715	.2096		.1715	.1715	.1905	.1524
19	.1715	.1905	.1905	.1905	.1905	.1905	.1905
20	.1715	.2477	.2096	.1905	.2096	.2477	.2096
21	.1524	.1715	.2096	.1524	.1905	.2477	.2096
22	.1524	.1715	.1905	.1524	.1715	.1905	.1905
23	.1524	.1143	.1524	.1524	.1334	.1524	.1715
24	.1524	.1143	.1143	.1143	.1334	.1143	.1143
Max	.1715	.2477	.2096	.2096	.2096	.2477	.2096
Min	.1334	.1143	.1143	.0953	.0953	.1143	.1143
Avg	.1543	.1405	.1458	.1397	.1485	.1508	.1389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 202 / 11 KV Waifale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4001	.3772		.1524	.1334	.6173
2	.4338	.4161	.3772	.1334	.1524	.1334	.6173
3	.5281	.4161	.4115	.1334	.1524	.1334	.6241
4	.5544	.4409	.4115	.1524	.1524	.1334	.6485
5	.5914	.426	.4115	.2286	.1905	.2286	.6935
6	.9425	.4508	.9602	.3429	.2286	.362	.9602
7	1.1458	1.0631	1.4746	.3048	.3429	.362	1.5089
8	.9877	.9414	1.4746	.2286	.2858	.2858	1.3717
9	.7947	1.0288	1.1488	.1524	.2096	.1905	1.3546
10	.1715	.1524	.0953	.1334	.1524	.1905	.1143
11	.1143	.1334	.1715	.7964	1.448	1.3375	.1143
12		.1143	.1715	.8145	1.3756	1.3523	.1334
13		.1143	.1524	1.0669	1.3032	1.2269	.1524
14		.1334	.1334	.9145	1.1706	1.166	.1524
15		.1334	.1524	.905	1.267	1.1831	.1524
16	.1334	.1524	.1524	.9593	1.3937	1.166	.1524
17	.1524	.1524	.1524	1.086	1.3575	1.2003	.1715
18	.2096	.1715		1.1393	1.2851	1.2517	.2286
19	.1905	.3048	.2096	.2667	.1905	1.2384	.2477
20	.1905	.3048	.2096	.2667	.2286	.2858	.2477
21	.1905	.2667	.1905	.1905	.2477	.2667	.2286
22	.1905	.2096	.1715	.1905	.2096	.2286	.1905
23	.1905	.1905	.1524	.1905	.1905	.1905	
24	.4001	.4001	.3601	.1334	.1334	.1334	.6001
Max	1.1458	1.0631	1.4746	1.1393	1.448	1.3523	1.5089
Min	.1143	.1143	.0953	.1334	.1334	.1334	.1143
Avg	.4273	.3549	.4140	.4665	.5759	.5992	.4905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 203 / 11 KV Biranwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2667	.3048		1.0679	1.3756	.2858
2	.3429	.2667	.3048		1.1765	1.3756	.2858
3	.3429	.2667	.3048	1.0288	1.1765	1.3756	.2858
4	.381	.2667	.3048	1.0288	1.7013	1.3756	.2667
5	.4191	.2667	.3429	1.2574	1.7194	1.4118	.2477
6	.4191	.4572	.381	1.8564	2.19	1.4506	.3048
7	.4954	.5716	.4763	2.2119	2.7873	2.5206	.5335
8	.4001	.4191	.4572	2.2119	2.6818	2.7831	.362
9	.3429	.4382	.4001	2.1862	2.6578	2.5819	.362
10	.2858	.362	.3429	.2667	.1524	.2058	.2286
11	2.19	2.452	2.5415	.3239	.1715	.2667	2.2405
12		2.452	2.489	.3048	.2858	.2667	2.1605
13		2.4272	2.4188	.2667	.2477	.2667	2.0805
14		2.3579	2.4097	.2858	.2667	.2667	2.0729
15		2.1776	2.2291	.3048	.2858	.2286	2.1862
16	2.2443	2.1605	2.0576	.2858	.3048	.2477	2.0481
17	2.2262	2.1365	2.0576	.3429	.4001	.2477	2.1052
18	2.1357	2.2805		.2096	.4572	.2477	2.1628
19	.3048	.4954	.4191	.4763	.4954	.2858	.4191
20	.3048	.5335	.4191	.4572	.4954	.5144	.4572
21	.3048	.5525	.381	.381	.4191	.4954	.4572
22	.3048	.3429	.3429	.3429	.362	.381	.4572
23	.3239	.3048	.2858	.3429	.3239	.362	.381
24	.3429	.2667	.2858		.9412	1.3756	.2858
Max	2.2443	2.452	2.5415	2.2119	2.7873	2.7831	2.2405
Min	.2858	.2667	.2858	.2096	.1524	.2058	.2286
Avg	.7227	1.0217	.9546	.7797	.9486	.9129	.9449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 204 / 11 KV Agrani agro express NON SHEDDABLE EXPRESS HV FEEDERS
 fdr Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0057	.0229	.0038	.0191	.021	.0229
2	.0191	.0019	.0248	.0038	.0191	.0191	.0248
3	.0191	.0038	.0248	.0057	.0229	.0133	.0229
4	.0191	.0019	.0248	.0057	.0248	.0095	.0229
5	.0191	.0038	.0229	.0133	.0267	.0343	.0191
6	.0191	.0019	.0267	.0191	.0267	.0438	.0191
7	.0191	.0267	.0267	.0076	.0267	.0229	.0191
8	.0324	.0248	.0267	.0057	.0381	.0152	.0191
9	.0019	.0248	.0248	.0191	.0762	.0076	.0191
10		.0038	.0152	.0191	.0019	.0038	.0038
11	.0019	.0248	.0191	.0191	.0019	.0248	.0038
12		.0229	.0191	.0191	.0038		.0191
13		.0191	.0191	.0171	.0038	.0248	.0343
14		.0362		.0171	.0038		.0324
15			.0019	.0191	.0019	.0019	.0191
16	.0038	.0019	.0038	.0038		.0019	.0019
17	.0191	.0019	.0038	.0038	.0038	.0248	.0019
18	.0095	.0019			.0019	.0229	
19	.0038	.0057	.021	.0057	.0191	.0248	.0191
20	.0019	.0114	.0057	.0095	.0229	.0229	.0229
21	.0019	.0019	.0057	.0095	.0171	.0191	.0343
22	.0038	.021	.0038	.0114	.021	.0191	.0324
23	.0057	.0191	.0038	.0305	.0381	.0248	.0095
24	.0038	.0057	.0191		.0305	.04	.0248
Max	.0324	.0362	.0267	.0305	.0762	.0438	.0343
Min	.0019	.0019	.0019	.0038	.0019	.0019	.0019
Avg	.0117	.0119	.0166	.0122	.0196	.0201	.0195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 201 / 11 KV Savarde Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.506	.5418	.5201	.2427	.2452	.2241	.463
2	.4999	.5053	.535	.2218	.2641	.2075	.4268
3	.5312	.5053	.535	.2195	.2452	.1886	.4268
4	.5937	.5647	.5498	.2218	.2263	.2452	.4268
5	.6562	.6321	.535	.2218	.3018	.3018	.4938
6	.7343	.8128	.8128	.3395	.4338	.3961	.68
7	1.0212	1.034	1.0974	.4066	.4668	.4294	.933
8	.945	.9907	1.0957	.3734	.4668	.3361	.8951
9	.6081	.9389	.9957	.3881	.4108	.4294	.7926
10	.1463	.2328	.2378	.3326	.3511	.3696	.1991
11	.0934	.2195	.2987	.9362	.9602	1.0494	.2241
12	.0914		.3018	.8025	.8619	.8802	.2218
13	.1829	.2033	.2195	.695	.7529	.7775	.2218
14	.1848	.2054	.1991	.6687	.6716	.643	.2218
15	.1848	.2218	.2241	.6554	.7042	.6371	.2241
16	.2241	.2772	.2801	.8796	.8025	.7526	.2987
17	.2241	.3511	.3696	.8796	1.0623	.8124	.4481
18	.3921	.5914		.7773	.8688	.8333	.6535
19	.5415	.6722	.2957	.4435	.3109	.4481	.6722
20	.4481	.5041	.2801	.4108	.4338	.3361	.4668
21	.3921	.4108	.2614	.3395	.3206	.3174	.3921
22	.3174	.3921	.2427	.3018	.2641	.2987	.3174
23	.2987	.3174	.1867	.2427	.2452	.2427	.3206
24	.4744	.5268	.5201	.2614	.2452	.2241	.4012
Max	1.0212	1.034	1.0974	.9362	1.0623	1.0494	.933
Min	.0914	.2033	.1867	.2195	.2263	.1886	.1991
Avg	.4288	.5066	.4606	.4692	.4965	.4742	.4509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 202 / 11 KV Khujgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5624	.743	.8025	.1928	.2054	.1494	.7621
2	.5624	.743	.8322	.1772	.1867	.1509	.7316
3	.5937	.823	.8322	.1578	.2054	.1698	.7011
4	.6249	.9145	.8471	.156	.2054	.1886	.7164
5	.7186	1.1584	.8471	.156	.2241	.2452	.8278
6	.7811	1.278	1.1279	.2172	.3206	.3584	1.1138
7	.9362	1.46	1.3426	.2561	.3734	.3547	1.3717
8	.9214	1.5089	1.4043	.3077	.3696	.2614	1.5352
9	.9362	1.286	1.2955	.2126	.3109	.2427	1.3523
10	.1646	.1772	.1829	.2865	.2587	.2926	.1595
11	.181	.1949	.1848	1.3426	1.3094	1.3998	.2378
12	.1578	.1612	.1663	1.1736	1.1443	1.2163	.2801
13	.1463	.1254	.1595	1.0105	1.0002	1.1279	.2218
14	.1433	.1417	.1372	.9511	.8642	1.086	.2012
15	.1448	.1612	.1448	.9957	1.0288	1.028	.2012
16	.1663	.181	.2149	1.1439	1.057	1.1149	.2012
17	.2012	.1991	.2715	1.189	.9482	1.4632	.2987
18	.2743	.3475		1.1004	.8916	1.3523	.3511
19	.3142	.3326	.2774	.2534	.2378	.2957	.3658
20	.3142	.2987	.2896	.2801	.2987	.3142	.3326
21	.2957	.2987	.197	.2641	.2801	.2801	.2987
22	.2587	.2987	.1772	.2263	.2427	.2427	.2801
23	.2427	.2614	.1612	.2075	.2054	.2241	.2218
24	.5312	.743	.7579	.181	.2075	.1663	.7011
Max	.9362	1.5089	1.4043	1.3426	1.3094	1.4632	1.5352
Min	.1433	.1254	.1372	.156	.1867	.1494	.1595
Avg	.4239	.5765	.5502	.5183	.5157	.5719	.5610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 207 / 11 KV Sawarde Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1698	.1886	.1848	.1886	.168	.1867
2	.1698	.1509	.1698	.2033	.1698	.1509	.1867
3	.1509	.1509	.1886	.1867	.1886	.1509	.1867
4	.1698	.1698	.1886	.1867	.1886	.168	.1867
5	.1867	.1867	.2075	.1867	.1886	.1867	.1867
6	.2241	.2054	.2427	.2054	.2452	.2241	.2241
7	.181	.181	.2012	.1829	.168	.181	.168
8	.1612	.1772	.1417	.1463	.1433	.1402	.156
9	.1387	.1402	.156	.1097	.124	.1267	.1402
10	.1543	.1372	.1543	.1638	.156	.1543	.1526
11	.1417	.156	.1595		.156	.1417	.1753
12	.1543	.1595	.1791	.0347	.1715	.1578	.1772
13	.1595	.1791	.1949	.0732	.156	.1753	.197
14	.1646	.1772	.1791	.0732	.1578	.1949	.1791
15	.1646	.1791	.2012	.1753	.1433		.1629
16	.1646	.1772	.1949	.1753	.1578	.1772	.1629
17	.1629	.1715	.1696	.1227	.1578	.1433	.1612
18	.1387	.156		.1433	.1578	.1715	.1063
19	.2254	.2835	.2254	.2715	.2328	.2481	.2126
20	.2896	.3077	.2534	.3142	.3077	.3224	.3258
21	.2743	.2896	.2715	.2801	.2743	.2926	.3077
22	.2561	.2614	.2561	.2452	.2402	.2614	.2743
23	.2033	.2075	.1867	.2075	.1867	.2054	
24	.1867	.1867	.1886	.1646	.1886	.168	.1867
Max	.2896	.3077	.2715	.3142	.3077	.3224	.3258
Min	.1387	.1372	.1417	.0347	.124	.1267	.1063
Avg	.1830	.1900	.1956	.1755	.1854	.1874	.1915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 201 / 11 kv Vadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1143	.1132	.2622	.4973	.2881	.1698
2	.1132	.1143	.1132	.2294	.5304	.2881	.1509
3	.132	.1143	.132	.2294	.57	.3005	.1886
4	.1698	.1524	.1698	.2785	.6036	.4111	.2452
5	.2263	.2263	.2263	.3812	.6554	.6081	.2829
6	.2829	.3206	.3018	.5636	.7537	.8322	.3584
7	.2427	.2641	.3326	.7748	1.166	1.0669	.2957
8	.1848	.2075	.2263	.7977	1.3441	1.1288	.2378
9	.1646	.1886	.2241	.7926	1.2498	1.1279	.1886
10	.1646	.168	.1848	.112	.112	.1509	.1886
11	.8592	1.1248	1.1728	.1698	.1886	.2263	1.2967
12		1.0648	1.0467	.1698	.1698	.2427	1.3435
13		1.0159	.9877	.1698	.1494		1.1288
14		.8962	.9568	.1698	.1494	.2263	.9214
15		.9503	.9374	.168	.1307	.2427	.9722
16	.9722	.9762	1.0669	.168	.1494	.2218	.9877
17	.9722	.9667	.873	.168	.2012	.2587	1.1561
18	.9332	.9556	.3048	.168	.2614	.2987	1.0802
19	.2452	.1886	.1478	.1886	.2427	.3109	.2801
20	.2263	.2241	.1886	.2263	.2452	.3018	.2829
21	.2075	.2075	.1886	.2075	.1886	.2641	.2641
22	.1886	.1886	.1509	.1886	.1698	.2241	.2075
23	.1509	.1698	.1509	.1509	.1509	.2075	.1698
24	.132	.1334	.132	.2458	.4588	.3041	.1886
Max	.9722	1.1248	1.1728	.7977	1.3441	1.1288	1.3435
Min	.1132	.1143	.1132	.112	.112	.1509	.1509
Avg	.3341	.4555	.4304	.2908	.4308	.4144	.5244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 202 / 11KV Anjani Vadgaon

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3239	.3018	.2829	.3048	.2829	.2829
2	.3206	.3239	.2829	.2829	.3048	.2829	.2829
3	.3772	.3239	.3206	.3018	.3048	.3018	.2641
4	.4527	.362	.3961	.3772	.362	.3772	.3018
5	.4904	.4715	.4527	.4527	.4382	.4527	.3961
6	.5847	.5847	.5281	.547	.5281	.5658	.5093
7	.4527	.4904	.4066	.3921	.3961	.4294	.4108
8	.2987	.362	.2987	.3658	.3326	.3439	.3224
9	.2561	.3077	.2534	.2715	.2402	.3258	.2561
10	.2561	.2743	.2715	.2715	.1991	.2835	.2686
11	.2561		.2743	.2561	.181	.2926	.2686
12		.197	.2715	.2587	.2534	.2715	.2715
13		.2378	.2896	.2561	.2561	.2926	.2743
14		.2772	.2926	.2587	.2772	.2957	.2743
15		.2926	.3142	.2587	.2614	.2743	.2772
16	.2743	.3077	.2865	.2587	.2587	.2587	.2772
17	.2743	.2926	.2835	.2534	.2561	.2743	.2743
18	.2686	.2587	.2896	.2561	.2195	.3077	.2743
19	.3658	.4024	.4435	.3361	.3658	.4024	.3841
20	.5281	.4668	.4854	.4805	.499	.499	.5359
21	.4715	.4805	.4668	.4481	.4527	.4481	.4715
22	.4338	.4481	.3961	.3961	.3961	.415	.3961
23	.3772	.3584	.3395	.3584	.3395	.3206	.3584
24	.3395	.3429	.3018	.3018	.3239	.3018	.3018
Max	.5847	.5847	.5281	.547	.5281	.5658	.5359
Min	.2561	.197	.2534	.2534	.181	.2587	.2561
Avg	.3700	.3560	.3436	.3301	.3230	.3458	.3306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 203 / 11 KV Gavan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9282	.8745	1.2452	.0943	.1143	.132	1.1523
2	1.065	.852	1.326	.0943	.1143	.132	1.2452
3	1.1203	.852	1.3763	.0943	.1143	.132	1.3426
4	1.278	.9503	1.4563	.1132	.1715	.1698	1.4754
5	1.3443	1.1336	1.6221	.1698	.2452	.2263	1.4746
6	1.4918	1.4089	1.8233	.2829	.3206	.3206	1.5384
7	1.7204	1.7124	2.1464	.2427	.3018	.2801	2.13
8	2.0056	2.1125	2.1862	.2241	.2829	.2641	2.3685
9	1.8785	2.2283	2.2775	.2241	.2641	.2241	2.3594
10	.2075	.1663	.1478	.1829	.1848	.181	.2829
11		.2054	.2241	1.5402	1.5384	2.304	.2829
12	.2075	.2402	.2054	1.6194	1.8461	2.343	.2829
13		.2587	.2263	1.6194	1.7859	2.2024	.2801
14		.2801	.2263	1.4737	1.7004	2.1628	.2801
15		.2587	.2075	1.6221	1.8351	2.0965	.2772
16	.168	.2378		1.4403	1.9334	2.1136	.2772
17	.2054	.2172	.1494	1.4403	1.7814	2.1538	.2801
18		.2195	.1307	1.3603	1.8351	2.2708	.2829
19	.2054	.2402	.1886	.1848	.1867	.2743	.3361
20	.2263	.2427	.1698	.2427	.2641	.3206	.3395
21	.2263	.2641	.1509	.2452	.2263		.3206
22	.2075	.2263	.1509	.2075	.1867		.2641
23	.1698	.1886	.132	.1698	.1509	.1886	.2263
24	.8029	.9069	1.0898	.1132	.1334	.1509	1.1142
Max	2.0056	2.2283	2.2775	1.6221	1.9334	2.343	2.3685
Min	.168	.1663	.1307	.0943	.1143	.132	.2263
Avg	.8136	.6782	.8199	.6251	.7299	.9383	.8422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 201 / 11 KV DATTANAGAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1132	.1132	.503	.5796	.3688	.1132
2	.1132	.1132	.0943	.4801	.5721	.5304	.1132
3	.1132	.0943	.0943	.4572	.5498	.5243	.1132
4	.1132	.1132	.1132	.4572	.5428	.6325	.132
5	.1509	.1509	.132	.4755	.6015	.7316	.1698
6	.2075	.2263	.2452	.7316	.9568	.9907	.2452
7	.2263	.2241	.2054	.9877	1.2346		.2427
8	.1494	.1494	.1867	.9907	1.2643	1.2498	.1848
9	.1086	.128	.1463	.945	1.1439	1.1111	.1646
10	.124	.1433	.1448	.132	.0709	.0857	.1227
11	1.0974	1.0084	1.1296	.0914	.0747	.0924	1.2041
12	1.0669	1.0416	1.1591	.0914	.0905	.128	.9511
13	.9556	.8573	1.0402	.0701	.0716	.128	1.0254
14	.8543	.8916	1.0402	.0934	.1109	.1097	.9808
15	.8471	.9297	1.0254	.0914	.0716	.1097	.9808
16	.9214	.9145	1.0856	.0895	.0716	.1109	1.0822
17	1.0402	1.1279	1.086	.0914	.1448	.1294	1.1888
18	1.0122	1.0997		.1086	.1478	.1448	1.1142
19	.1494	.1663	.1494	.1307	.1848	.1663	.1867
20	.1698	.1886	.1698	.1886	.2241	.2075	.2054
21	.1698	.2075	.1698	.1698	.2075	.2075	.2075
22	.1698	.1698	.132	.132	.1886	.1886	.1698
23	.1509	.1509	.1132	.132	.1698	.1509	.1698
24	.1307	.1132	.132	.5144	.5556	.5138	.1132
Max	1.0974	1.1279	1.1591	.9907	1.2643	1.2498	1.2041
Min	.1086	.0943	.0943	.0701	.0709	.0857	.1132
Avg	.4239	.4301	.4308	.3398	.4096	.3745	.4659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 202 / 11 KV GOURGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5498	.5693	.5792	.112	.1463	.1307	.5944
2	.5135	.5487	.4344	.0934	.128	.1097	.5647
3	.5135	.5418	.5357	.0829	.128	.1097	.5357
4	.5639	.5944	.5487	.0934	.1267	.1086	.5357
5	.7095	.6923	.6584	.0995	.1448	.1478	.5647
6	.7977	.888	.9031	.1867	.2241	.2054	.743
7	.8655	1.0212	1.0837	.2241	.2218	.2033	.9095
8	.9808	.9482	1.0562	.1463	.1663	.1663	.9701
9	.8543	.8573	.9869	.128	.1848	.1478	.9122
10	.0937	.096	.0857	.1294	.1475	.1341	.1
11	.1109	.1448	.1029	.8833	.8688	.9332	.1254
12	.128	.1387	.1029	.9362		1.0402	.1075
13	.1433	.1387	.1029	.8509	.8145	.9556	.1254
14	.1214	.1254	.1254	.8362	.8318	.86	.1267
15	.1254	.1267	.1463	.8768	.8882	.9122	.1075
16	.1417	.1086	.1448	.8145	.9574	.9846	.1063
17	.1463	.1463	.1311		.9288	.9659	.1254
18	.1463	.2012			.823	.9145	.2172
19	.1629	.2402	.1663	.1848	.1829	.1402	.2195
20	.0739	.2427	.168	.2218	.2033	.2402	.2427
21	.168	.2033	.1698	.1848	.2033	.2033	.2402
22	.1867	.1848	.168	.1646	.1867	.1829	.1848
23	.1867	.1478	.1307	.1463	.1478	.1629	.1848
24	.5498	.6093	.6173	.1109	.1463	.1307	.6097
Max	.9808	1.0212	1.0837	.9362	.9574	1.0402	.9701
Min	.0739	.096	.0857	.0829	.1267	.1086	.1
Avg	.3681	.3965	.3978	.3412	.3827	.4204	.3814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 203 / 11 KV MANJARDE VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.1143	.0876	.0762	.0678	.0953	.1052
2	.0732	.0953	.0857	.0762	.0686	.0953	.0876
3	.0732	.0762	.0857	.0762	.0686	.0953	.0876
4	.0732	.0953	.0876		.0876	.0953	.1063
5	.0924	.1143	.1075	.0762	.1052	.1143	.124
6	.1097	.1334	.1646	.1143	.128	.1334	.1478
7	.0537	.1143	.1294	.1524	.2075	.1715	.1494
8	.2054	.1143	.0943	.1905	.168	.1143	.0857
9	.1478	.1905	.2263	.0762	.0886	.1905	.1086
10	.1478	.1905	.2452	.1905	.2012	.1905	.2195
11	.1715	.2263	.2286	.2667	.3142	.3018	.3018
12	.1143	.2286	.2452	.2427	.2829	.2829	.2477
13	.0572	.1677	.1334	.2829	.2477	.181	.2096
14	.0572	.0526	.1905	.1509	.1905	.1698	.2667
15	.0572	.0709	.2286	.2667	.2452	.2075	.2614
16	.0572	.1307	.2829	.1132	.2829	.2075	.3018
17	.0572	.1294	.2614	.1867	.2096	.2263	.3206
18		.1307		.2452	.2402	.1698	.3174
19		.1109	.2667	.2075	.3361	.2667	.2667
20	.1524	.1494	.1524	.1494	.2641	.1698	.1715
21	.1524	.1494	.1334	.1478	.2477	.1698	.1715
22	.1334	.1494	.1715	.112	.1905	.1478	.1524
23	.1143	.1254	.0953	.1109	.1334	.1254	.1334
24	.0895	.1143	.0876	.0762	.0867	.1334	.1052
Max	.2054	.2286	.2829	.2829	.3361	.3018	.3206
Min	.0537	.0526	.0857	.0762	.0678	.0953	.0857
Avg	.1036	.1323	.1648	.1560	.1860	.1690	.1854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 201 / 11 KV Jarandi Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.1494	.1509	.0934	.1698	.1886	.1132
2	.1698	.1307	.112	.1109	.1509	.1886	.1886
3	.1698	.1132	.1494	.112	.1509	.1886	.2263
4	.1698	.1663	.1867	.1463	.1509	.1886	.2427
5	.1886	.2987	.2561	.168	.2075	.2427	.2614
6	.2452	.3696	.362	.2195	.3206	.3326	.3326
7	.2829	.2801	.4119	.2587	.1886	.3077	.4207
8	.2452	.2402	.3109	.2195	.1698	.2835	.2172
9	.2033	.168	.2195	.181	.1991	.2328	.1848
10	.1848	.132	.1478	.1991	.1991	.1052	.1928
11	.1494	.1494	.112	.1829	.1848	.1463	.181
12	.1132	.1663	.128	.1646	.168	.1867	.1629
13	.1109	.1463	.1494	.1478	.1829	.2218	.1646
14	.0934	.132	.1867	.1494	.1494	.1509	.1463
15	.1109	.112	.132	.132	.168	.1867	.1307
16	.1509	.1848	.168	.1494	.168	.2218	.1791
17	.1663	.2033	.1478	.2172	.2033	.2378	.197
18	.181	.2402		.2328	.2629	.2534	.2279
19	.2561	.2926	.0934	.2402	.2507	.2926	.3012
20	.3582	.3658	.2561	.2614	.3258	.3326	.3224
21	.4024	.3361	.1848	.2452	.2957	.2772	.3224
22	.2218	.2957	.2195	.2075	.2772	.2427	.2378
23	.2241	.2241	.1867	.2075	.2641	.2033	.2033
24	.2054	.1886	.168	.132	.1698	.2772	.1494
Max	.4024	.3696	.4119	.2614	.3258	.3326	.4207
Min	.0934	.112	.0934	.0934	.1494	.1052	.1132
Avg	.2005	.2119	.1930	.1824	.2074	.2287	.2211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789] BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 202 / 11 KV Jarandi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4012	.7373	.7373	.0739	.1132	.1132	.4973
2	.3437	.7773	.7682	.0554	.1132	.0943	.6226
3	.3437	.8697	.8802	.0554	.0943	.0943	.6478
4	.3437	.9172	.9393	.0747	.0943	.0943	.7865
5	.3963	1.0402	.9602	.0943	.132	.1698	.8802
6	.7125	1.1069	1.1069	.112	.2263	.2452	1.0279
7	.9061	1.1561	1.1561	.1698	.1886	.2075	1.1574
8	.8592	1.0753	1.1888	.1478	.1698	.1509	1.1248
9	.7926	.7293	1.0082	.112	.1307	.1307	1.0364
10	.1052	.12	.1109	.1097	.1307		.1063
11	.1307	.1463	.0934	.9145	.9962	.6167	.0739
12	.1132	.0924	.0566	.9297	.9907	.9116	.0914
13	.0943	.0747	.056	.888		1.3435	.0914
14	.0747	.0566	.0754	.873		1.1069	.0905
15	.056	.056	.0739	.8278	.7926	1.0311	.0876
16	.0566	.0754	.0934	.873	1.0364	1.2193	.1075
17	.0934	.0943	.1109	.9095	.9568	1.1717	.1075
18	.1294	.1294		.7674	.9602	1.0722	.1433
19	.168	.168	.1307	.168	.2054	.1109	.2241
20	.2561	.1829	.1663	.1494	.2263	.2054	.2195
21	.2218	.1663	.112	.1509	.1886	.1663	.2054
22	.1867	.1494	.1294	.132	.168	.132	.168
23	.132	.0943	.112	.1132	.1307	.0934	.1494
24	.4001	.5868	.5801	.0934	.1132	.1132	.2572
Max	.9061	1.1561	1.1888	.9297	1.0364	1.3435	1.1574
Min	.056	.056	.056	.0554	.0943	.0934	.0739
Avg	.3049	.4418	.4629	.3665	.3708	.4606	.4127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789] BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 203 / 11 KV Dahiwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.056	.0754	.3725	.4374	.4428	.0566
2	.0754	.0566	.0566	.3681	.4062	.4111	.056
3	.0754	.056	.0566	.4424	.3963	.4161	.0739
4	.0754	.0754	.056	.4973	.3963	.4641	.112
5	.1132	.1307	.1132	.57	.4214	.5121	.1294
6	.2075	.1663	.1478	.5218	.6401	.6882	.1646
7	.2075	.2054	.2054	.4999	.9069	.9014	
8	.1509	.1848	.1663	.5761	.9602	.933	.168
9	.0934	.1494	.1307	.6401	.9282	.9061	.128
10	.0739	.0943	.1109	.0709	.0709	.1052	.0895
11	.5898	.6401	.6478	.0914	.1097	.0934	.8592
12	.6019	.8381	.7116	.0732	.128	.0739	.9568
13	.7907	.8592	.8488	.0732	.0905		.884
14	.9602	.9488	.6859	.0732	.1075		.8951
15	.9172	.8855	.9374	.0914	.0905	.056	.8642
16	.8436	.8436	1.0279	.0732	.0905	.0566	.9568
17	.8381	.6478	.9282	.0716	.1086	.0934	.9568
18	.8162	.5898		.1086	.1629	.1494	1.0031
19	.1433	.1663	.112	.1109	.128	.1848	.1478
20	.2241	.168	.132	.1109	.168	.168	.1494
21	.2054	.1478		.0934	.1307	.1294	.1307
22	.1294	.112	.0754	.0934	.112	.112	.0934
23	.0934	.0943	.056	.0747	.0747	.0754	.0747
24	.0934	.0754	.0747	.3361	.4428	.4218	.0566
Max	.9602	.9488	1.0279	.6401	.9602	.933	1.0031
Min	.0739	.056	.056	.0709	.0709	.056	.056
Avg	.3498	.3413	.3344	.2514	.3128	.3361	.3916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 201 / 11 KV KUMTHE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2926	.2772	.2427	.2614	.2772	.2263
2	.2561	.2629	.2715	.2452	.2402	.2614	.2075
3	.2402	.2658	.2801	.2218	.2353	.2641	.2075
4	.2402	.2427	.2743	.2172	.2103	.2641	.2075
5	.2772	.2587	.2987	.2452	.2561	.2829	.2641
6	.3475	.2865	.7022	.2987	.2801	.3174	.3206
7	.3077	.3109	.6584	.2957	.2303	.2957	.3018
8	.2534	.2454	.5602	.2241	.1829	.2378	.2126
9	.2172	.2126	.4804	.2054	.1612	.2353	.1928
10	.2241	.2263	.2263	.2172		.2378	.1991
11	.2402	.1578	.1886	.2218	.2829	.2172	.2103
12	.2534	.2715	.2534		.2987	.2218	.2328
13	.2195	.3142	.2033	.2103	.2772	.2353	.2353
14	.2402	.2772	.2534	.2303	.2801	.2378	.2481
15	.2279	.2587	.2378	.2402	.2402	.2587	.2561
16	.2126	.2402	.2195	.2534		.2801	.2353
17	.2172	.2172	.2987			.2957	.2402
18	.1772	.2561	.2402	.2507	.3142	.2772	.2772
19	.2279	.3077	.2743	.2926	.298	.3547	.3077
20	.3045	.3658	.3142	.3292	.3439	.3881	.3403
21	.3511	.362	.2715	.3511	.3696	.3696	.3658
22	.3403	.3658	.2772	.3547	.3326	.3772	.3292
23	.3189	.3174	.2614	.3174	.2957	.3018	.3142
24	.2715	.3077	.2896	.2402	.2987	.2772	.2452
Max	.3511	.3658	.7022	.3547	.3696	.3881	.3658
Min	.1772	.1578	.1886	.2054	.1612	.2172	.1928
Avg	.2599	.2760	.3172	.2593	.2709	.2819	.2574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 204 / 11 KV Kumthe Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0322	1.4842	.9602	.0747		.1867	.1905
2	1.0774	1.3735	.8592	.0754		.1886	.1905
3	1.0526	1.3283	.8078	.0747	.2096	.1886	.1715
4	1.0978	1.2955	.8855	.0754	.2096	.1886	.1715
5	1.1523	1.3927	.9686	.0739	.2286	.2075	.1715
6	1.2323	1.3923	1.3272	.0724	.2477	.2427	.2477
7	1.6964	1.4706	1.439	.0934	.2286	.2587	.2667
8	1.7394	1.5339	1.3117	.0924	.2286	.2195	.2218
9	1.4506	1.5779	1.3923	.0934	.2477	.1991	.2012
10	.1905	.1698	.2452	.0381		.1646	.2096
11	.1524	.2957	.2858	.3953	.8962	1.2163	.1905
12	.1524	.2195	.2263		.8179	1.1174	.1905
13	.1143	.1848	.2033	.3704	.8962	.8025	.1905
14	.1905	.2033	.2012	.3953	.8065	1.0279	.2096
15	.2286	.2218	.1848	.4218	.7935	1.0402	.2096
16	.2286	.2378	.1848	.4062		.8749	.2286
17	.2477	.2172				1.1043	.2667
18	.1524	.2561		.3887	.5359	.9374	
19	.2286	.3258	.0566	.1905	.1478	.2641	.2858
20	.2858	.3475	.056	.2096	.2218	.2614	.3239
21	.3239	.3439	.056	.2096	.2402	.2263	.3429
22	.2858	.3174	.0377	.1905	.2587	.2263	.2477
23	.2858	.3142	.0305	.1905	.2218	.2075	.2096
24	.9831	1.4575	.884	.0934	.1905	.1848	.1905
Max	1.7394	1.5779	1.439	.4218	.8962	1.2163	.3429
Min	.1143	.1698	.0305	.0381	.1478	.1646	.1715
Avg	.6492	.7484	.5729	.1921	.4014	.4807	.2230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 206 / 11 KV Upalavi Matkunki Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1509	.128	.0943	.9962	.6478	.852
2	.132	.1509	.1294	.0934	.9374	.6478	.9282
3	.132	.1509	.1294	.0924	.9717		.9831
4		.1867	.1307	.0934	1.0774		.9717
5		.2241	.1478	.1132	1.0311		1.085
6		.2241	.2427	.1463	1.1012		1.2308
7		.2801	.2772	.1307	1.4586		1.4563
8		.2427	.168	.1478	1.5023	1.0031	1.2809
9		.2402	.1848	.1494	1.2963	.9259	1.4232
10	.0366	.1829	.1478	.128	.112	.1097	.1753
11	.6516	1.5432	1.3546	.1307	.1848	.1109	1.3923
12	.7074	1.2742	1.2186	.1417	.181	.0914	1.3441
13	.6455	1.034	1.07	.1478	.168	.2012	1.2811
14	.6944	.9374	1.0402	.1772	.1294	.1867	1.2308
15	.759	.9842	.9783	.1829	.1463	.168	
16	.6562	1.1561	.9259	.2172		.1646	1.2967
17	.7522	1.2963				.2054	1.3426
18	1.1279	1.2803		.2195	.1612	.2926	1.2346
19	.0532	.2896		.2218	.132	.3361	.2303
20	.0543	.2561		.2427	.2452	.3018	.2353
21	.0351	.2172	.0739	.2614	.2452	.2829	.2263
22	.1848	.2054	.112	.2241	.2263	.2452	.1886
23	.1698	.1663	.0934	.1886	.1886	.2263	.1698
24	.1509	.1698	.1448	.0924	1.0159	.6478	.7865
Max	1.1279	1.5432	1.3546	.2614	1.5023	1.0031	1.4563
Min	.0351	.1509	.0739	.0924	.112	.0914	.1698
Avg	.3931	.5352	.4349	.1581	.6140	.3576	.9281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 207 / Nagaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4066	.3982	.3658	.3961	.3658	.3658
2	.3292	.3582	.4066	.3361	.3772	.3475	.3658
3	.3292	.3544	.3658	.3326	.3772	.3475	.3292
4	.3292	.362	.3696	.3395	.3961	.3292	.3292
5	.3475	.3641	.3734	.3734	.4338	.3292	.3292
6	.3658	.3898	.439	.4066	.4527	.3658	.3841
7	.3206	.3841	.3696	.3547	.3658	.3292	.3475
8	.2378	.4075	.3734	.3326	.3189	.3109	.3292
9	.2561	.3681	.3292	.3109	.3366	.2926	.3292
10	.2378	.3658	.3658	.3012	.3439		.3077
11	.2279	.3292	.3658	.3439	.2926	.3292	.3012
12	.2801	.3475	.3658	.3696	.3258	.3142	.2926
13	.2686	.3658	.3658	.3801	.3292	.3475	.2896
14	.2715	.3475	.3658	.3544	.3326	.3292	.3174
15	.2587	.3475	.3658	.4031	.3258	.3696	.3142
16	.2587	.3475	.3658	.3921		.3921	.3292
17	.2614	.3475	.3658			.3439	.3403
18	.3077	.3696		.0886	.3658	.3109	.333
19		.5068	.4938	.4163	.4755	.4572	.4251
20		.567	.5359	.4477	.5304	.5304	.499
21		.543	.4572	.499	.5304	.4938	.547
22	.5093	.5121	.462	.4904	.4572	.4755	.5093
23	.4527	.462	.4715	.4527	.4207	.4207	.4527
24	.3841	.4024	.439	.3921	.415	.3841	.3841
Max	.5093	.567	.5359	.499	.5304	.5304	.547
Min	.2279	.3292	.3292	.0886	.2926	.2926	.2896
Avg	.3143	.3982	.4005	.3688	.3909	.3703	.3647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 208 / Nagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5401	.8381	.6722	.1402	.0754	.0549	.0537
2	.5468	.787	.6316	.1433	.0566	.0554	.0549
3	.5535	.8002	.5668	.12	.0566	.056	.0549
4	.571	.7773	.5864	.1267	.0566	.0566	.0554
5	.5864	.7926	.5851	.1214	.0754	.0754	.0739
6	.5502	.8383	.6249	.1433	.0754	.0747	.0914
7	.8025	.8429	.9172	.1463	.0739	.0924	.0905
8	.888	.8619	.7716	.1478	.0701	.0829	.1075
9	.8322	.8109	.8436	.1867	.0905	.0648	.1086
10	.0869	.0857	.0819	.0924	.112		.112
11	.0892	.0829	.0895	.68	.6019	.8322	.1097
12	.0714	.0695	.0829	.5944	.7202	.8124	.1109
13	.0705	.0857	.0829	.6405	.6874	.7907	.1097
14	.0867	.0857	.0829	.6097	.6718	.8002	.1075
15	.0905	.0701	.0829	.571	.6718	.7842	
16	.0876	.0537	.0848	.5281		.8642	.1063
17	.0886	.0686	.1029			.9442	.0895
18	.104	.0732		.3647	.4451	.8362	.1254
19	.1075	.0924	.0377	.0526	.0693	.1052	.1029
20	.0876	.128	.0373	.0514	.0678	.0876	.0886
21	.0905	.1267	.037	.052	.0686	.0876	.0848
22	.0886	.112	.0373	.0739	.0701	.0724	.0838
23	.0914	.112	.0377	.0754	.0543	.0724	.0829
24	.5093	.7655	.6249	.1753	.0754	.0549	.0532
Max	.888	.8619	.9172	.68	.7202	.9442	.1254
Min	.0705	.0537	.037	.0514	.0543	.0549	.0532
Avg	.3175	.3900	.3349	.2538	.2248	.3373	.0895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 201 / 11 KV PED AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.8173	.2263			.2229		
24	1.0722	.8173	.9175	.6478		.2058	.2427
Max	1.0722	.8173	.9175	.6478	.2229	.2058	.2427
Min	.8173	.2263	.9175	.6478	.2229	.2058	.2427
Avg	.9448	.5218	.9175	.6478	.2229	.2058	.2427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 202 / 11 KV HATNUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.1372	.132			.1715		
24	.1109	.1372	.132	.1109		.743	.8322
Max	.1372	.1372	.132	.1109	.1715	.743	.8322
Min	.1109	.132	.132	.1109	.1715	.743	.8322
Avg	.1241	.1346	.132	.1109	.1715	.743	.8322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 204 / 11KV HATNUR GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.3045	.3361			.3121		
24	.2987	.2865	.3206	.2427		.2774	.4119
Max	.3045	.3361	.3206	.2427	.3121	.2774	.4119
Min	.2987	.2865	.3206	.2427	.3121	.2774	.4119
Avg	.3016	.3113	.3206	.2427	.3121	.2774	.4119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 206 / 11 KV PED GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.0876	.1307			.1227		
24	.0943	.0876	.1132	.1307		.1052	.1829
Max	.0943	.1307	.1132	.1307	.1227	.1052	.1829
Min	.0876	.0876	.1132	.1307	.1227	.1052	.1829
Avg	.0910	.1092	.1132	.1307	.1227	.1052	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 208 / VIJAYNAGAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.2743	.2641		.2572		
24	.7287	.6687	.7956		.2743	.4119
Max	.7287	.6687	.7956	.2572	.2743	.4119
Min	.2743	.2641	.7956	.2572	.2743	.4119
Avg	.5015	.4664	.7956	.2572	.2743	.4119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 209 / 11 KV HONAI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.0514	.3772			.0514		
24	.427	.3418	.3315	.1943		.0514	.0566
Max	.427	.3772	.3315	.1943	.0514	.0514	.0566
Min	.0514	.3418	.3315	.1943	.0514	.0514	.0566
Avg	.2392	.3595	.3315	.1943	.0514	.0514	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV PANMALEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2452	.2241	.2096	1.704	1.2125	1.2955
2		.2452	.2012	.1905	1.6385	1.1797	1.3441
3		.2263	.1848	.1905	1.5546	1.1934	1.3272
4		.2263	.1867	.1698	1.5223	1.2407	1.2643
5		.2641	.1867	.2075	1.5384	1.2929	1.2308
6		.3018	.2452	.2263	1.6712	1.5083	1.3123
7		.3395	.3018	.2452	2.5029	1.8842	1.7004
8		.3696	.2829	.2801	2.5526	2.3868	1.989
9	.3206	.3696	.2987	.3395	2.3922	2.3371	2.1628
10	.2926	.3361	.1448	.3395	.2587	.2012	.1478
11	2.6216	2.4577	1.4918	.3772	.2801	.2641	.9602
12	2.7183	2.5526	1.5746	.2241	.3018	.1886	2.3868
13	2.8509	2.7183	2.42	.1867	.2829	.132	2.42
14	2.4249	2.652	3.1855	.168	.2641	.1509	2.2874
15	2.7515	2.6686	3.0849	.2054	.2987	.1698	1.5089
16	2.6355	2.7496	2.5987	.1867	.3361	.1886	3.0178
17	2.7681	2.9843	2.8502	.3547	.3142	.1494	3.1184
18	2.4577	2.6189		.3921	.3109	.4294	3.0178
19	.3361	.3584	.2241	.3584	.2987	.415	.2987
20	.3734	.3734	.2452	.3772	.2987	.3584	.3174
21	.3395	.3395	.2641	.3206	.2801	.3292	.3018
22	.3018	.3206	.2801	.3018	.2614	.2641	.2641
23	.2829	.2801	.2427	.2452	.2427	.2987	.2452
24		.2641	.2427	.2452	1.5729	1.247	1.278
Max	2.8509	2.9843	3.1855	.3921	2.5526	2.3868	3.1184
Min	.2829	.2263	.1448	.168	.2427	.132	.1478
Avg	1.5650	1.0942	.9114	.2642	.9449	.7926	1.4665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2075	.2054	.1867	.1886	.2241	.2241
2		.1886	.1829	.1848	.1886	.2075	.2263
3		.1886	.1663	.1663	.1886	.1829	.1886
4		.2075	.168	.1867	.2075	.1663	.1848
5		.2075	.1463	.2075	.2263	.1867	.2218
6		.2263	.1829	.2263	.2427	.2801	.2987
7		.168	.2241	.2427	.2402	.2427	.2587
8		.1663	.2033	.2012	.2033	.1848	.1991
9	.1829	.1494	.1867	.1829	.1646	.1629	.1991
10	.1791	.128	.1991	.1949	.1753	.1772	.1928
11	.1478	.1646	.181	.0739	.1612	.1991	.197
12		.1829	.2218	.168	.1949	.181	.1629
13	.2033	.1991	.1848		.181	.2195	.1448
14		.1848	.2033	.1867	.1991	.2378	.1829
15	.2033	.2033	.112	.2054	.2195	.2218	.2012
16	.2033	.2033	.2054	.2054	.2012	.2033	.2033
17	.1829	.1991	.1629	.1867	.1772	.181	.181
18	.1791	.2378		.2195	.2012	.1991	.197
19	.2218	.2534	.2507	.2534	.2353	.2896	.2353
20	.2772	.2987	.2772	.2926	.2801	.3292	.2926
21	.2587	.2614	.2572	.2772	.3142	.3326	.3142
22	.2241	.2614	.2572	.2614	.2801	.3142	.2801
23	.2241	.2452	.2534	.2263	.2427	.2614	.2452
24		.2075	.2075	.2263	.2075	.2241	.2427
Max	.2772	.2987	.2772	.2926	.3142	.3326	.3142
Min	.1478	.128	.112	.0739	.1612	.1629	.1448
Avg	.2067	.2058	.2017	.2071	.2134	.2254	.2198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV SHIRGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3292		.3239	.3326	.3429
2		.3239	.3174		.3048	.3174	.3018
3		.3048	.3142		.3048	.2829	.3018
4		.3048	.2987		.3239	.2614	.2801
5		.3429	.3109		.3429	.2829	.3361
6		.381	.3439	.4294	.362	.3841	.3961
7		.3206	.3961	.4108	.3395	.3511	.415
8		.2987	.3174	.3258	.3174	.2957	.3258
9	.2743	.2957	.2241	.2835	.2263	.2561	.2561
10	.2561	.3366	.3224	.3294	.3189	.2801	.2534
11	.2743	.2743	.3547	.3511	.3506	.2987	.2614
12	.2926	.2561	.2987	.2987	.2801	.3174	.2772
13	.2829	.2641	.2614	.2801	.2614	.2987	.2957
14	.2801	.2829	.2801	.2614	.2987	.3395	.2772
15	.2987	.2829	.3174	.2614	.3174	.2641	
16	.2987	.2614	.3142	.3045	.3361	.2829	
17	.3326	.2987	.2561	.2987	.2957	.3258	.3544
18	.2957	.3361		.2987	.3326	.2587	.3045
19	.4024	.4435	.4207	.3326	.3734	.3734	.4207
20	.4668	.5304	.4805	.4481	.5228	.4755	.4805
21	.4481	.5228	.4435	.4338	.5093	.4904	.4854
22	.415	.4904	.4294	.415	.4294	.4481	.4294
23	.415	.4481	.3961	.362	.3921	.4001	.3772
24		.3429	.3658		.3239	.3292	.381
Max	.4668	.5304	.4805	.4481	.5228	.4904	.4854
Min	.2561	.2561	.2241	.2614	.2263	.2561	.2534
Avg	.3356	.3453	.3388	.3403	.3412	.3311	.3434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4413	1.4575	1.2452	.2241	.1509	
2		1.3927	1.4419	1.2125	.2263	.1494	
3		1.3443	1.4083	1.1336	.2263	.128	
4		1.3283	1.3927	1.166	.2452	.128	
5		1.3441	1.4255	1.1469	.2614	.1448	
6		1.3765	1.6385	1.21	.2987	.1886	
7		1.704	2.0317	1.3443	.2402	.2075	
8		1.6712	1.8138	1.3757	.3174	.2241	
9	1.4737	1.8564	1.7444	1.4723	.2987	.2054	.3361
10	.181	.2218	.2801	.2353	.2801	.1097	.3326
11	.1829	.2587	.0934	1.5565	1.5061	2.1714	.2987
12		.2772	.3734	1.6004	2.2775	2.0885	.2957
13	.2452	.2587	.3361	1.6484	2.2672	1.9062	.3142
14	.1509	.2218	.3206	1.6518	2.1052	2.2874	.2772
15	.1886	.2033	.3018	1.6518	2.2119	2.2377	.2957
16	.2987	.3174	.3547	1.8564	2.1792	2.2542	.3142
17	.3361	.3361	.1494	1.2163		2.0972	.3326
18	.2987	.3584		1.166		2.0809	.3361
19	.3361	.3734	.3206	.2172	.1494	.168	.3921
20	.3734	.3921	.3584	.2427	.1867	.3961	.4108
21	.3547	.3584	.3395	.2427	.1886	.3772	.3734
22	.3174	.3395	.3395	.2241	.1698	.3734	.3361
23	.2614	.3174	.3018	.2241	.1698	.3206	.2801
24		1.4251	1.491	1.4255	.2241	.1509	
Max	1.4737	1.8564	2.0317	1.8564	2.2775	2.2874	.4108
Min	.1509	.2033	.0934	.2172	.1494	.1097	.2772
Avg	.3571	.7966	.8572	1.1027	.7388	.8561	.3284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2075	.2054	.2241	1.7204	1.7078	1.668
2		.2075	.1829	.1886	1.6518	1.6804	1.6004
3		.1886	.168	.1867	1.587	1.6876	1.6057
4		.2075	.1646	.1509	1.5546	1.7404	1.6712
5		.2452	.2012	.1698	1.6194	1.7924	1.7004
6		.2829	.2427	.2263	1.8023	1.9989	1.7924
7		.2614	.2561	.2587	2.4086	2.2939	2.2186
8		.2957	.2614	.2241		2.5749	2.2186
9	.2378	.2218	.2987	.2172	2.4577	2.5425	2.4577
10	.2012	.2218	.2561	.2012	.1646	.0895	.2058
11	2.3758	2.2775	2.1862	.1463	.2012	.1867	2.332
12	2.2611	2.7515		.1663	.2195	.2241	2.4453
13	2.2775	2.6871	2.982	.1848	.1829	.2614	2.5587
14	2.1464	2.6543	2.9172	.2033	.2012		2.2672
15	2.3266	2.4577	2.2708	.2218	.2218	.2218	2.3594
16	2.2939	2.3594	2.3644	.1829	.2218	.2402	2.6189
17	1.9989	2.4249	2.4129	.1578	.2033	.2587	2.4413
18	1.8244	2.364		.2172	.2378	.2772	2.3102
19	.2561	.2829	.2149	.2195	.2641	.2957	.2772
20	.2987	.2987	.2218	.2614	.2829	.2641	.2987
21	.2427	.2801	.2218	.2218	.2587	.2641	.2614
22	.2241	.2561	.2218	.2218	.2402	.2218	.2452
23	.2241	.2378	.2054	.2054	.2241	.2075	.2241
24		.2075	.2033		1.5415	1.704	1.6032
Max	2.3758	2.7515	2.982	.2614	2.4577	2.5749	2.6189
Min	.2012	.1886	.1646	.1463	.1646	.0895	.2058
Avg	1.2793	.9950	.8482	.2025	.8464	.9885	1.6409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV PANMALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.1307	.1307	.1132	.1307	.1334
2		.1132	.128	.132	.1132	.1097	.132
3		.1132	.1109	.1143	.1132	.0924	.112
4		.1132	.0934	.1143	.1132	.0934	.1307
5		.1132	.0934	.132	.1132	.1132	.1698
6		.132	.1097	.168	.1294	.1494	.1886
7		.128	.1267	.1595	.1267	.1509	.1463
8		.1109	.1227	.1698	.1097	.1214	.124
9	.1448	.1086	.1052	.1267	.1075	.1052	.1227
10	.128	.0876	.1006	.12	.1296	.1107	.1094
11	.0924	.1294	.0934	.1132	.1406	.0876	.1006
12	.1075	.1109	.1307	.0867	.1406	.0701	.0857
13	.124	.1132	.0934	.0867	.1311	.052	.0709
14	.1075	.0934	.1132	.104	.116	.0373	.0895
15	.1132	.112	.1307	.0867	.0995	.0381	.1254
16	.0943	.1307	.112	.1029	.1187	.0381	.124
17	.0943	.0934	.0701	.1029	.1187	.0995	.1052
18	.1132	.1307		.112	.1509	.12	.1086
19	.1214	.1417	.1543	.1463	.1357	.1663	.1463
20	.1772	.2241	.2303	.1886	.2229	.2561	.2033
21	.1991	.2353	.2172	.1886	.2172	.2378	.2054
22	.1663	.1867	.2012	.1698	.1829	.2075	.1867
23		.168	.1848	.132	.1478	.1524	.1509
24		.132	.1478	.1509	.1132	.1294	.1524
Max	.1991	.2353	.2303	.1886	.2229	.2561	.2054
Min	.0924	.0876	.0701	.0867	.0995	.0373	.0709
Avg	.1274	.1306	.1305	.1308	.1335	.1196	.1343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 207 / 11 Kv Nimbalk Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7204	1.7368	1.4419	.2263	.2427	
2		1.6385	1.704	1.3927	.2075	.2263	
3		1.5708	1.6907	1.3757	.2075	.2241	
4		1.5384	1.6385	1.3413	.2263	.2012	
5		1.6057	1.6004	1.326	.2452	.2402	
6		1.7404	1.7814	1.442	.2829	.2987	
7		2.3703	2.2874	1.704	.2829	.3018	
8		2.4034	2.4034	2.0153	.2614	.2926	
9	2.2211	2.1548	2.2377	2.0885	.2641	.3326	.3142
10	.197	.1848	.2033		.2263	.2427	.3395
11	.1867	.1294	.2614	2.1382	2.8334	3.1352	.3395
12			.2801	2.2377	2.5316	2.5149	.2829
13	.2033	.2241	.2987	2.3137	2.649	1.7101	.1509
14	.2427	.2054	.2987	2.2348	2.4646	3.1295	.2241
15	.2241	.2263		2.1862	2.5484	3.0803	.168
16	.2241	.2452	.3361	1.8275	2.6322	2.9492	.2987
17	.2427	.2801	.2801	2.0081	2.1628	2.8346	.3142
18	.2987	.2614		1.8515	2.0972	2.5987	.3475
19	.3174	.2565	.2614	.2801	.2743	.2801	.3361
20	.3361	.2801	.2452	.2801	.2957	.2452	.3395
21	.3395	.3018	.2427	.2641	.2926	.2641	.3018
22	.2614	.2829	.2241	.2452	.2772	.2427	.2801
23	.2614	.2614	.3361	.2263	.2561	.2452	.2263
24		1.6741	1.7238		.2263	.2427	
Max	2.2211	2.4034	2.4034	2.3137	2.8334	3.1352	.3475
Min	.1867	.1294	.2033	.2263	.2075	.2012	.1509
Avg	.3969	.9372	1.0033	1.4646	.9988	1.0865	.2842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 208 / 11kv VISAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.1698		1.1603	1.0159	1.2289
2		.1698	.1494		1.0978	.9831	1.2631
3		.1698	.1463		1.0814	.9614	1.1984
4		.1698			1.1305	.9717	1.1469
5		.1886	.1478		1.1633	1.0526	1.1984
6		.2263			1.2944	1.4255	1.3443
7		.2241	.2801		1.7736	1.6385	1.6549
8		.2427	.1867		1.7532	1.917	.6882
9	.1848	.2241	.168		1.6876	1.7859	.7773
10	.1463	.1698	.1494		.1629	.197	.112
11	1.5083	.6154	1.7814	.1829	.2378	.1772	2.0481
12	1.4582	.7611	2.364	.1991		.2033	1.8351
13	1.6244	1.5074	2.4249	.1991	.2054	.2218	1.9498
14	1.6575	1.6385	2.304	.1829	.2241	.2263	1.8023
15	1.6876	1.7238	2.2708	.1646	.2054	.2054	1.7695
16		1.9062	2.0553	.1867	.2241	.1867	1.9662
17	1.7072	1.9393	1.8442	.168	.2614	.2054	1.6244
18	1.6409	1.9334		.1867	.2378	.2195	.6483
19	.2641	.1132	.1867	.2054	.2378	.2427	.2622
20	.2614	.2075	.1867	.2241	.2402	.2452	.2303
21	.2241	.1886	.1886	.2263	.2427	.2452	.2012
22	.2075	.1867	.1698	.2075	.2195	.2241	.1829
23	.1867	.1886	.1509	.168	.2033	.1886	.1886
24		.1886	.1698		1.0059	1.0159	1.1633
Max	1.7072	1.9393	2.4249	.2263	1.7736	1.917	2.0481
Min	.1463	.1132	.1463	.1646	.1629	.1772	.112
Avg	.9114	.6280	.8331	.1924	.6978	.6565	1.1035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 201 / 11 KV ANKALKHOP GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	2.1948	.1886	.2058	.1715	.1715	.1886
2	.1715	2.1948	.1886	.1715	.1715	.1715	.1715
3	.1715	2.1948	.1715	.1715	.1715	.1715	.2058
4	.1715	2.2291	.1715	.1715	.2058	.1715	.2058
5	.2058	2.2977	.0857	.2058	.2401	.2058	.2229
6	.2401	2.4006	.2401	.2401	.2572	.3086	.2572
7	.1715	2.5377	.2058	.2401	.2401	.2058	.2229
8	.1715	.1715	.1715	.2401	.1886	.2058	.1886
9	.1372	.1715	.1886	.2058	.1715	.2058	.1886
10			.1715	.2401		.1715	.1886
11			.1715	.2401	.1715	.1886	.2058
12		.2058	.2058	.2743	.2058	.2058	.2058
13		.2401	.2058	.2401	.2058	.2058	.2058
14		.2229	.2058	.1886	.2401	.2058	.2058
15		.2058	.2058	.2058	.2401	.2229	.2058
16	.2058	.2058	.2058	.2058	.2401	.2915	.2058
17	.2058	.2058	.2401	.1886	.2401	.2058	.2058
18		.2229		.2058	.2058	.2058	.2058
19	.2401	.2743	.3086	.2401	.2401	.2401	.3086
20	.2743	.3086	.3429	.2743	.3086	.3086	.3429
21	.2743	.3086	.3086	.2743	.2743	.2743	.3086
22	.2401	.2743	.2743	.2401	.2401	.2229	.2572
23	.2401	.2229	.2058	.2058	.2058	.2058	.2058
24	.1886	2.0576	.1715	.2058	.1886	.1715	.1886
Max	.2743	2.5377	.3429	.2743	.3086	.3086	.3429
Min	.1372	.1715	.0857	.1715	.1715	.1715	.1715
Avg	.2048	.9704	.2102	.2201	.2185	.2144	.2208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 202 / 11 KV AUDUMBER GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2572	.2058	.2058	.1715	.2058	.2229
2	.2401	.2401	.2058	.2058	.1715	.2058	.2058
3	.2401	.2401	.2058	.2058	.1715	.2058	.2058
4	.2743	.2229	.2229	.1715	.2058	.1715	.2229
5	.2743	.2229	.2915	.2401	.2401	.2058	.2229
6	.3086	.2401	.3258	.3086	.3086	.2743	.2915
7	.2401	.2572	.2401	.2401	.2401	.2058	.2572
8	.1543	.2058	.2058	.1715	.2058	.1715	.1715
9		.2058	.1715	.1372	.1715	.1715	.1715
10			.1715	.1543		.1372	.12
11			.1715	.1543	.1372	.1372	.1715
12		.1715	.1715	.1543	.1372	.1372	.1715
13		.1715	.1715	.1715	.1372	.1715	.1715
14		.2058	.1715	.1886	.1372	.2058	.1715
15		.1715	.1715	.1886	.1715	.1715	.1715
16	.1715	.1715	.1715	.1886	.1715	.1715	.1715
17	.1715	.1715	.2058	.1886		.1715	.1715
18		.1715		.1886		.2058	.1715
19	.2058	.2915	.3086	.2401	.2401	.2229	.2401
20	.2401	.3429	.3086	.2743	.2743	.2915	.3258
21	.2743	.2915	.2743	.3086	.3086	.2915	
22	.2743	.2743	.2743	.2401	.2743	.2572	
23	.2572	.2401	.2401	.2229	.2401	.2401	
24	.2401	.2572	.2229	.2401	.1715	.2058	.2229
Max	.3086	.3429	.3258	.3086	.3086	.2915	.3258
Min	.1543	.1715	.1715	.1372	.1372	.1372	.12
Avg	.2379	.2284	.2222	.2079	.2041	.2015	.2025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 203 / 11 KV BHILAWADI GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.6173	.6173	.6173	.583	.6173	.6516
2	.583	.6173	.6173	.583	.583	.583	.6173
3	.583	.6173	.6173	.5487	.583	.5487	.6173
4	.583	.583	.6173	.5487	.6516	.5487	.6173
5	.6516	.6516	.6859	.6516	.7202	.6516	.6173
6	.703	.6173	.7716	.6859	.703	.7888	.7202
7	.6516	.6516	.7373	.6516		.6516	.6516
8	.5487	.5487	.583	.583	.5487	.5487	.6001
9	.5316	.5144	.583	.5144	.5144	.4801	.5144
10			.5658	.5144		.4801	.5144
11			.583	.5144	.4801	.5144	.6001
12		.6001	.6173	.5144	.4801	.5487	.6344
13		.5144	.6173	.5144	.5144	.583	.6344
14		.5487	.6173	.5658	.583	.583	.6344
15		.6173	.6859		.5487	.6859	.6173
16		.583	.7202		.5144	.6173	.6173
17		.6173	.7545	.6173	.583	.6687	.6516
18		.6516		.5487	.6516	.6859	.6859
19		.823	.823	.703		.7202	.7545
20		.8573	.8573	.823	.8573	.823	.7888
21		.8402	.7888	.8573	.7888	.7888	.8573
22		.7888	.7545	.7888	.7545	.7888	.8573
23		.703	.6859	.6687	.6859	.7202	.7716
24	.6173	.6516	.6516	.6516	.6173	.6173	.6516
Max	.703	.8573	.8573	.8573	.8573	.823	.8573
Min	.5316	.5144	.5658	.5144	.4801	.4801	.5144
Avg	.6036	.6461	.6762	.6212	.6165	.6352	.6616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 204 / 11 KV NAGATHANE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3086	.3429	.3086	.3086	.3086
2	.3086	.2743	.3086	.3086	.3086	.3086	.2915
3	.3086	.2743	.3086	.3086	.3086	.3086	.2915
4	.3429	.1029	.3429	.3429	.3429	.3429	.2915
5	.3429	.3086	.463	.4115	.4115	.3429	.4287
6	.4115	.3772	.4458	.4801	.4458	.4458	.4458
7	.3601	.3601	.3429	.3772	.3772	.4115	.3601
8	.2915	.2401	.3429	.3429	.3429	.3086	.3429
9	.2915	.2401	.3086	.2743	.3258	.3086	.2915
10			.3086	.3086		.3086	.3429
11			.3086	.3086	.3086	.3086	.3086
12		.4115	.3086	.3258	.3429	.3086	.3086
13		.3086	.3086	.3258	.3086	.3429	.3086
14		.3601	.3429	.3258	.3086	.2915	.3086
15		.3429	.3429	.3086	.3086	.3086	.3258
16		.2915	.3086	.2743	.3086	.3086	.3258
17		.2915	.3429	.2229	.2743	.2743	.2915
18		.3258		.3429	.2401	.2743	.2915
19	.4458	.4115	.3772	.3772	.3772	.3429	.3086
20	.4801	.5144	.4801	.3429	.4458	.4287	.3429
21	.4973	.4458	.4458	.3429	.4115	.3944	.3772
22	.4458	.4287	.4115	.3429	.4115	.3944	.4287
23	.4115	.3772	.3772	.3086	.3429	.3429	.3429
24	.3086	.3086	.3429	.3429	.3086	.3086	.3086
Max	.4973	.5144	.4801	.4801	.4458	.4458	.4458
Min	.2915	.1029	.3086	.2229	.2401	.2743	.2915
Avg	.3704	.3320	.3556	.3329	.3422	.3343	.3322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 205 / 11 KV ANKALKHOP AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.0343	.0343	.7202	.7202	.7888
2	.0343		.0343	.0343	.7202		.7888
3	.0343		.0343	.0343	.7202	.7545	.7888
4	.0343		.0343	.0343	.7888	.823	.7888
5	.0343		.0343	.0343	.8573	.8573	.823
6	.0343		.0343	.0343	.9602	.9259	.9602
7	.0343		.0343	.0343	.9945	1.0288	1.1317
8	.0343	.0343	.0343	.0343	.9945	1.0288	1.1317
9	.0343	.0343	.0343	.0343	.9945	1.0288	1.2346
10			.0343	.0343		.0343	.0343
11			1.3375	.0343	.0343	.0343	1.2003
12		1.6804	1.4746	.0343		.0343	1.1488
13		1.6804	1.5432	.0343	.0343	.0343	1.1488
14		1.749	1.5432	.0343	.0343	.0343	1.1145
15		1.6804	1.4746	.0343	.0343	.0343	
16	1.2003	1.6118	1.406	.0343	.0343	.0343	1.0288
17	1.2003	1.406	1.3717	.0343	.0343	.0343	1.0974
18		1.3375		.0343	.0343	.0343	1.1317
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343		.0343		.7202	.7202	.0343
Max	1.2003	1.749	1.5432	.0343	.9945	1.0288	1.2346
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.1715	.8133	.4652	.0343	.4037	.3638	.7194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 206 / 11KV AUDUMBER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	2.915	2.915	3.0521
2	.0343	.0343	.0343	.0343	2.915	2.915	3.0521
3	.0343	.0343	.0343	.0343	3.0178	2.915	3.0864
4	.0343	.0343	.0343	.0343	3.1207	2.8807	3.0864
5	.0343	.0343	.0343	.0343	3.155	2.9835	3.0864
6	.0343	.0343	.0343	.0343	3.1893	3.0864	3.1722
7	.0343	.0343	.0343	.0343	3.4294	3.2236	3.6008
8	.0343	.0343	.0343	.0343	3.4294	3.2236	3.5151
9	.0343	.0343	.0343	.0343	3.3436	3.2236	3.858
10			.0343	.0343		.0343	.0343
11				.0343		.0343	4.1324
12		4.0295				.0343	4.1152
13		4.0809	4.321			.0343	3.9952
14		4.1152	4.321			.0343	3.9781
15		4.0466	4.321			.0343	4.1152
16		4.201	4.321			.0343	4.1152
17	.0343	4.0295	4.2524			.0343	3.9438
18		3.8237		.0343		.0343	4.0466
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	
22	.0343	.0343	.0343	.0343	.0343	.0343	
23	.0343	.0343	.0343	.0343	.0343	.0343	
24	.0343	.0343	.0343	.0343	2.915	2.915	2.8292
Max	.0343	4.201	4.321	.0343	3.4294	3.2236	4.1324
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0343	1.3110	1.0517	.0343	2.1068	1.2817	3.0897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 207 / 11 KV BHILAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	2.1948	2.4006	1.8176	.0343	.0343	.0343
2	1.7147	2.2291	2.4006	1.7147	.0343	.0343	.0343
3	1.7833	2.2634	2.4691	1.7147	.0343	.0343	.0343
4	1.7833	2.2977	2.4691	1.7833	.0343	.0343	.0343
5	1.8176	2.2977	2.4691	1.8861	.0343	.0343	.0343
6	1.8519	2.2977	2.4691	1.989	.0343	.0343	.0343
7	1.989	2.4006	2.6063	2.1262	.0343	.0343	.0343
8	1.989	2.5377	2.8807	2.1605	.0343	.0343	.0343
9	1.9204	2.5377	2.7778	2.1948	.0343	.0343	.0343
10			.0686	2.2634		.0343	.0343
11			.0343	2.572	2.6406	3.2236	.0343
12		.0686	.0343	2.8807	2.7435	3.2922	.0343
13		.0686	.0343	2.7778	2.7435	3.4294	.0343
14		.0686	.0343	2.6749	2.7778	3.1722	.0343
15		.0686	.0343	2.9492	2.6749	3.2236	.0343
16		.0686	.0343		2.6063	3.0178	.0343
17		.0686	.0343	2.5377	2.5377	3.0864	.0343
18		.0686		2.2634	2.4006	2.7435	.0343
19		.0686	.0343	.0343	.0343	.0686	.0343
20		.0686	.0343	.0343	.0343	.0686	.0343
21		.0343	.0857	.0343	.0343	.0343	.0343
22		.0343	.0343	.0343	.0343	.0343	.0343
23		.0343	.0343	.0343	.0343	.0343	.0343
24	1.6461	2.1948	2.332	1.9204	.0343	.0343	.0343
Max	1.989	2.5377	2.8807	2.9492	2.7778	3.4294	.0343
Min	1.6461	.0343	.0343	.0343	.0343	.0343	.0343
Avg	1.821	1.0896	1.122	1.7564	.9408	1.0753	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 208 / 11 KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634		2.1262	1.9204	.1372	.1372	.1372
2	2.2634		2.1262	1.9204	.1372	.1372	.1372
3	2.2634		2.1948	1.9204	.1372	.1372	.1372
4	2.4006			1.989	.2058	.1372	.1372
5	2.4006		2.2634	2.1948	.2058	.1372	.1372
6	2.6749		2.6063	2.332	.2058	.1715	.2058
7	3.3608		3.155	2.8121	.1372	.1372	.1372
8	3.3608		3.3608	3.0864	.2058	.1372	.1372
9	3.3608		3.2922	3.3608	.2058	.1372	.2058
10			.2058	3.3608		.1372	.2058
11			.2058	3.3608	3.5665	3.7037	.1372
12		.1372	.2058	3.3608	3.7037	3.6351	.1372
13		.1372	.1715	3.3436	3.6008	3.8409	.1372
14		.1372	.1372	3.2922	3.4979	3.7037	.1372
15		.1372	.1715	3.0178	3.2579	3.2922	.1372
16		.1372	.1715	2.9492	3.0178	3.4979	.1372
17		.2058	.1715	2.7778	2.9492	3.6351	.1372
18		.2058		2.6749	2.8807	2.9492	.1372
19	.1372		.1715	.2058		.1372	.1372
20	.1372	.1372	.1715	.2058	.2058	.1372	.1372
21	.1372	.2058	.1372	.2058	.2058	.1372	.1372
22	.1372	.2058	.1372	.2058		.1372	.1372
23	.1372	.1372	.1372	.1372	.1715	.1372	.1372
24	2.1948		2.1948	1.9204	.1372	.1372	.1372
Max	3.3608	.2058	3.3608	3.3608	3.7037	3.8409	.2058
Min	.1372	.1372	.1372	.1372	.1372	.1372	.1372
Avg	1.8153	.1621	1.1598	2.1898	1.3701	1.2703	.1458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 201 / 11 KV YELAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.168	.1698			.7842	.7042
2	.168	.1509	.1698			.7682	.6642
3	.168	.168	.1509			.7432	.6562
4	.1886	.1698	.2263			.7682	.6802
5	.2054	.1867	.2452			.8097	.7042
6	.2829	.2641	.2641			1.0082	.8848
7	.2427	.2263	.2829		.9014	1.2803	1.0814
8	.2587	.2452	.2829	.1663	1.4251	1.3283	1.2955
9	.2353	.2427	.2241	.168	1.3603	1.0753	1.2944
10	.2195	.2801	.2241	.1294	.1991	.2149	.2054
11	1.2146	1.2483	1.2631	.1109	.2801	.2829	1.3763
12	1.1683	1.2643	1.4251	.1097	.1294	.2641	1.0688
13	1.1248	1.1142	1.3763	.1109	.1307	.2641	1.2631
14	1.0753	1.1469	1.4251	.1109	.1494	.2641	1.2955
15	1.1012	1.166	1.3603	.112	.2614	.2829	1.3279
16	1.1203	1.2146	1.2176	.2507	.3142	.2801	1.3108
17	1.1043	1.247	1.4089	.181		.3142	1.2003
18	.9998	1.1385		.1663	.2172	.3326	1.1012
19	.2012	.2427	.1848	.2614	.3174	.3142	.2452
20	.2218	.2263	.2263	.2987	.2614	.3174	.2641
21	.2218	.2241	.2075	.2452	.2427	.2772	.2452
22	.2033	.2263	.1886	.2241	.2427	.2402	.2452
23	.1848	.2263	.1886	.1867	.2241	.2241	.2263
24	.1886	.168	.1886	.168	.3953	.6802	.6154
Max	1.2146	1.2643	1.4251	.2987	1.4251	1.3283	1.3763
Min	.168	.1509	.1509	.1097	.1294	.2149	.2054
Avg	.5120	.5398	.5609	.1765	.4148	.5466	.8315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 202 / 11 KV Laxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6972	2.6406	1.7194	2.6595	2.7538	2.6217
2	2.6406	2.6972	2.4897	2.7915	2.7349	2.5463
3	2.6595	2.7349	2.452	2.7349	2.7349	2.584
4	2.6406	2.7726	2.4897	2.7161	2.7538	2.6029
5	2.6029	2.7726	2.584	2.6972	2.7726	2.6406
6	2.7538	2.8292	2.6783	2.8669	2.7349	2.7349
7	3.1121	2.8858	2.6406	3.0367	2.7915	2.6595
8	3.1121	2.8292	.6401	3.0556	2.9801	2.6783
9	3.1121	3.0556	.6874	3.0744	3.0556	2.7915
10	.0094	3.0744	.78	2.9235	3.1121	2.6217
11	2.6595	3.1687	1.448	2.9235	3.0367	2.7726
12	2.7349	3.0178	3.131	2.8669	2.9613	.3801
13	3.1121	2.9801	2.9613	2.8669	3.0367	2.8669
14	3.1121	3.0556	2.8669	2.8292	3.0178	2.9235
15	3.1121	3.0556	1.8107	2.9235	3.0556	3.0367
16	2.5274	2.5463	2.3577	2.3954	2.1691	2.5463
Max	3.1121	3.1687	3.131	3.0744	3.1121	3.0367
Min	.0094	2.5463	.6401	2.3954	2.1691	.3801
Avg	2.6624	2.8823	2.1086	2.8351	2.8563	2.5630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 203 / 11 KV Yelavi Bu'wadi

GAOTHAN FEEDER

Gaonthan Feeder KV- 11 /
OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4854	.5281	.5041	.5041	.5228	.5228
2	.5041	.5093	.5093	.4668	.4854	.5041	.5093
3	.4854	.5093	.4904	.4668	.4904	.5228	.4904
4	.5228	.5281	.4904	.4854	.5041	.5601	.5093
5	.5601	.5788	.5658	.5601	.5788	.6161	.5847
6	.7095	.7095	.6979	.6979	.6979	.7842	.7356
7	.5729	.6099	.5544	.5729	.7023	.5914	.6161
8	.4163	.4525	.3582	.4344	.4572	.4835	.4706
9	.3898	.3898	.3155	.3982	.3801	.4607	.4298
10	.3772	.2481	.3814	.4075	.3814	.4681	.3814
11	.3366	.2303	.4075	.4119	.1772	.443	.4252
12	.3721	.3898	.4252	.3403	.2103	.4557	.443
13	.3761	.4298	.4298	.4298	.1928	.4961	.4298
14		.4298	.4344	.1791	.1949	.5014	.4163
15	.4525	.4344	.4525	.197	.5194	.4706	.4525
16	.4344	.4344	.4835	.1949	.5138	.4656	.4207
17	.4298	.443	.5083	.5083		.4298	.4252
18	.4207	.4733		.4784	.6068	.4801	.4508
19	.5138	.5731	.6268	.5973	.6733	.6268	.6556
20	.695	.7316	.695	.7023	.7865	.7602	.7316
21	.6838	.7095	.6838	.7095	.7392	.7392	.7392
22	.6348	.6722	.6348	.6535	.6838	.6722	.7023
23	.5601	.5975	.5601	.5601	.5975	.5788	.6161
24	.5228	.5041	.5601	.5041	.5228	.5415	.5228
Max	.7095	.7316	.6979	.7095	.7865	.7842	.7392
Min	.3366	.2303	.3155	.1791	.1772	.4298	.3814
Avg	.4981	.5031	.5127	.4775	.5043	.5490	.5284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 204 / 11 KV Burungwadi

Industrial Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.373	.3641	.3048	.282	.2477	.3018	.2521
2	.3429	.3856	.2559	.3121	.2641	.3048	.1943
3	.3721	.3401	.2366	.3353	.257	.2606	.2441
4	.3429	.3018	.23	.2896	.3125	.2195	.2606
5	.3467	.3185	.2538	.2469	.3641	.2688	.3243
6	.2623	.1686	.2606	.2241	.2932	.1846	.21
7	.2968	.3012	.298	.3077	.3077	.1715	.3294
8	.3439	.3681	.3258	.3005	.3018	.1886	.4163
9	.394	.4066	.4207	.4344	.3185	.2787	.5847
10	.3696	.4527	.7356	.5658	.5281	.3294	.5658
11	.4108	.5658	.6036	.679	.6413	.2561	.6413
12	.439	.3801	.5847	.5658	.6979	.2715	.6413
13	.3841	.4481	.4108	.6036	.6722	.2427	.5658
14	.3898		.3658	.4668	.5228	.2429	.5847
15	.3601	.7545	.4334	.5847	.5658	.253	.6224
16	.3601	.547	.4715	.6036	.547	.2709	.5658
17	.373	.8488	.3761	.3521	.5041	.2279	.6036
18	.3601	.4207		.4251	.462	.2105	.4904
19	.4108	.3982	.4294	.3696	.4527	.2105	.4108
20	.4755	.5175	.462	.3549	.3641	.2949	.3841
21	.5041	.5228	.4715	.4161	.5041	.2915	.4805
22	.5041	.5041	.4435	.39	.39	.2787	.4805
23	.2934	.3856	.3898	.3227	.3437	.3086	.362
24	.4031	.2599	.3593	.3647	.2892	.3185	.2881
Max	.5041	.8488	.7356	.679	.6979	.3294	.6413
Min	.2623	.1686	.23	.2241	.2477	.1715	.1943
Avg	.3797	.4331	.3967	.4082	.4230	.2578	.4376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 205 / 11Kv Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5466	1.4146	1.4712	1.5089	1.4712	1.4712	1.5089
2	1.5089	1.4712	1.4901	1.4523	1.2449	1.4335	1.4712
3	1.4523	1.3957	1.4712	1.4335	1.3203	1.3957	1.4901
4	1.4712	1.4335	1.5089	1.4335	1.358	1.4146	1.5844
5	1.5089	1.3769	1.5466	1.4712	1.4712	1.4335	1.5844
6	1.5655	1.5466	1.5844	1.5466	1.6975	1.4712	1.6032
7	1.6975	1.6598	1.6032	1.6975	1.8861	1.6975	1.7918
8	1.6975	1.6975	1.6598	1.8484	1.6975	1.8484	1.7353
9	1.0562	1.6032	1.8107	1.5089	1.8107	1.8484	1.773
10	1.094	1.226	1.358	1.3203	1.4146	1.3957	1.4712
11	1.2826	1.4146	1.4523	1.3203	1.5466	1.5844	1.6598
12	1.5466	.7545	1.7353	1.773	2.0559	1.8861	1.905
13	1.7918	1.4712	2.0748	1.8861	2.037	2.2634	2.1879
14	1.5844	1.8861	2.037	1.9427	1.9427	2.1691	2.2634
15	1.6975	2.0748	2.037	1.9239	1.9427	1.8484	2.0748
16	1.773	1.905	1.9427	1.8861	1.8107	1.8673	2.0936
17	1.7353	1.7353	1.9616	1.0374	1.8107	1.8861	1.8673
18	1.358	1.773	1.7353	1.3203	1.5089	1.3203	1.4523
19	1.226	1.2071	1.2449	1.2449	1.1883	1.3203	1.3392
20	1.0374	.9054	1.226	1.0185	1.0185	1.0562	1.1317
21	.9431	.9431	1.094	.9808	.9619	.9808	1.0562
22	1.6032	1.0185	1.5655	1.6975	1.5089	1.3203	1.0751
23		1.7541	1.6598	1.6409	1.6032	1.5278	1.6409
24	1.5466	1.5089	1.5089	1.5466	1.4146	1.5089	1.7353
Max	1.7918	2.0748	2.0748	1.9427	2.0559	2.2634	2.2634
Min	.9431	.7545	1.094	.9808	.9619	.9808	1.0562
Avg	1.4663	1.4657	1.6158	1.5183	1.5718	1.5812	1.6457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 206 / Yelavi Ag -2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.04	.0314	.0297	.0619	.9717	.9339	.852
2	.04	.024	.0267	.0669	.9878	.9339	.8802
3	.0373	.0343	.0272	.0644	.9831	.9614	.8745
4	.0343	.0366	.0343	.064	1.004	1.0159	.8962
5	.0291	.0518	.0434	.064	1.094	1.0688	1.0242
6	.0572	.0594	.056	.0648	1.6164	1.6032	1.2498
7	.092	.064	.0732	.1	2.1862	2.1052	1.7444
8	.0838	.0652	.0686	.0823	2.2024	2.13	1.8461
9	.0762	.0905	.0953	.0926	1.9826	2.0405	1.8785
10	.1231	.1004	.1069	.1036	.1036	.0615	
11	1.5912	1.8351	2.2283	.0907	.1886	.0648	1.3108
12	1.6263	1.7436	2.3158	.0884		.0648	1.5729
13	1.6448		2.1628	.0829		.064	1.8138
14	1.4754		2.1376			.0713	1.749
15	1.442	1.1437	2.0729		.1753	.072	1.8785
16	1.1736	1.9919	2.13		.1593	.081	2.0081
17	1.3426	2.1376	1.9757	.0854			2.0317
18	1.0682	2.0405		.0941	.1166		1.4523
19	.064	.068	.1267	.105	.08	.1174	.1
20	.0572	.048	.0617	.0686	.0701	.0714	.0613
21	.0495	.0495	.072	.0514	.0713	.0545	.052
22	.0446	.0381	.068	.0486	.06	.0398	.0533
23	.0366	.0389	.0507	.06	.0421	.0389	.0396
24	.04	.04	.0373	.0686	.8029	.7293	.6802
Max	1.6448	2.1376	2.3158	.105	2.2024	2.13	2.0317
Min	.0291	.024	.0267	.0486	.0421	.0389	.0396
Avg	.5112	.5333	.6957	.0766	.7449	.6511	1.1326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 201 / 11 KV VASAGADE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646		.1829			.1646	.1463
2			.1463			.1646	.1463
3	.1646		.1463			.1646	.1463
4	.1646		.1478			.1646	.1463
5	.1646		.1829			.1646	.1663
6	.1829		.2195			.2195	.2195
7	.1646		.2012			.2378	.1646
8	.1646	.128	.1829		.1463	.1829	.1463
9		.1267	.1463		.1097	.1646	.1097
10		.1097	.1097		.128	.1646	.1097
11		.1463	.1448		.1463	.1463	.1448
12		.128	.1612		.1463	.1463	.1433
13		.1463	.1629		.128	.128	.1629
14		.128	.1433		.1646	.1463	.1433
15		.1109	.1612		.1463	.1463	.1448
16		.128	.1433		.1463		.1254
17		.128	.1433		.1463	.1097	.1254
18		.1097			.1829	.1097	.1448
19		.2012	.2328		.181	.2561	.2353
20		.2561	.2534		.2561	.2378	.2353
21		.2561	.2561		.2561	.1829	.2507
22		.2195	.2172		.1829		.2149
23	.2172	.2195	.1791	.2561	.1646	.1829	.181
24	.1829	.2195	.2012		.2534	.1646	.1663
Max	.2172	.2561	.2561	.2561	.2561	.2561	.2507
Min	.1646	.1097	.1097	.2561	.1097	.1097	.1097
Avg	.1745	.1624	.1768	.2561	.1697	.1704	.1633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 202 / 11KV KHATAV GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829		.1463			.1829	.1463
2	.1829		.1478			.1829	.1463
3	.1829		.1478			.1829	.1463
4	.1829		.1463			.1646	.1478
5	.2012		.1646			.1646	.1829
6	.2195		.2012			.2195	.2195
7	.2378		.2195			.2378	.1829
8	.1829	.2561	.1829		.1463	.1829	.1646
9		.2561	.1463		.2195	.1646	.1097
10		.2534	1.7558		.1829	.1646	.1463
11		.2195	.1612		.1463	.1463	.1448
12		.1463	.1629		.1463	.1109	.1612
13			.1791		.1463	.128	.1629
14		.128	.181		.1646	.128	.1646
15		.1097	1.086		.1463		.1629
16		.128	.1612		.1463	.128	.1433
17		.1097	.1646		.1463	.1463	.1629
18		.1097			.1829	.1097	.1646
19		.1829	.2378		.1829	.2561	.181
20			.2561		.2561	.2378	.2507
21		.2561	.2534		.2561	.2378	.2507
22		.2561	.2149		.2195	.2012	.2172
23	.2534	.2195	.181	.2561	.1829	.1646	.1791
24	.1829	.2561	.1829		.2534	.1829	.1663
Max	.2534	.2561	1.7558	.2561	.2561	.2561	.2507
Min	.1829	.1097	.1463	.2561	.1463	.1097	.1097
Avg	.2009	.1925	.2905	.2561	.1838	.1750	.1710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 203 / 11 KV SUKHWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0745		1.2483			.0179	.0179
2	1.1104		1.2971			.0179	.0179
3	1.1393		1.283			.0179	.0179
4	1.1145		1.3535			.0179	.0179
5	1.1145		1.2971			.0179	.0179
6	1.1145		1.3496			.0179	.0179
7	1.1831		1.3696			.0179	.0179
8	1.4232	1.4022	1.4327		.0181	.0179	.0179
9		1.3717	1.4198		.0179	.0179	.0358
10		.0171			.0179	.0179	.0358
11		.0347	.0181				.0358
12			.0179			1.6385	.0181
13		.0173	.0181			1.9498	.0179
14		.0358	.0183			1.7204	.0183
15		.0358	.0181			1.7833	.0181
16			.0179			1.7857	.0179
17		.0179	.0358			1.6632	.0181
18		.0179			1.0288	.0179	.0181
19		.0179	.0358		1.2517	.0179	.0183
20		.0358	.0181		.0179	.0179	.0181
21		.0179	.0179		.0179	.0179	.0179
22		.0179	.0183		.0179	.0179	.0179
23	.0175	.0179	.0181	.0183	.0179	.0179	.0181
24	1.0745	.5258	1.1633		.0181	.0179	.0179
Max	1.4232	1.4022	1.4327	.0183	1.2517	1.9498	.0358
Min	.0175	.0171	.0179	.0183	.0179	.0179	.0179
Avg	1.0366	.2389	.6121	.0183	.2424	.4715	.0202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 204 / 11 KV VASAGADE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149		.394			1.262	1.5432
2	.2328		.394			1.2689	1.5432
3	.2149		.4119			1.286	1.5432
4	.2149		.4119			1.2003	1.6297
5	.2328		.4298			1.286	1.6644
6	.2149		.4298			1.3717	1.7318
7	.197		.4119			1.5432	1.9418
8	.197	.2926	.4119		.7316	2.0576	2.2462
9		.2926	.4119			2.2291	2.4006
10		.2715	.394		.394	.3582	.3772
11		3.2594	3.1493		.3761	.3582	2.6155
12		3.086	3.2236		.3761	.4119	2.6113
13		2.9271			.394	.3761	2.5692
14		1.9071			.4119	.394	2.5149
15		1.9806	2.9664		.3761	.394	
16		2.6006	3.0182		.394	.394	
17		2.774	2.6063		.3761	.3761	1.9227
18		2.4539			.3761	.3761	2.1026
19		.3982	.3944		.3761	.3761	.362
20		.4119	.4075		.394	.394	.394
21		.4298	.3856		.4119	.3982	.394
22		.4119	.2126		.4119	.394	.3801
23	.3077	.394	.3582	.4656	.394	.394	.3658
24	.2149	.2926	.394		.724	1.2536	1.5604
Max	.3077	3.2594	3.2236	.4656	.7316	2.2291	2.6155
Min	.197	.2715	.2126	.4656	.3761	.3582	.362
Avg	.2242	1.4226	1.0103	.4656	.4324	.8397	1.5643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 205 / 11 KV PARSHWNATH LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	10-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4801	.3429
2			.5144	.3429
3			.5144	.3429
4			.5144	.3772
5			.5144	.3429
6			.5144	.3772
7			.5144	.3429
8	.4801		.3772	.2058
9	.5201	.5853	.3429	.3772
10	.4801		.3429	.3429
11	.5087			.3429
12	.5487		.4508	.3467
13	.5144		.3429	.3429
14	.5144		.3467	.3391
15	.5487		.3429	.5144
16			.4115	.5087
Max	.5487	.5853	.5144	.5144
Min	.4801	.5853	.3429	.2058
Avg	.5144	.5853	.4350	.3618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 201 / 11 KV Tasgaon I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0751	1.1458			.9997	
2		1.0562	1.0498			.9808	
3		1.0185	1.0498			.9808	
4		.9997	1.0349				
5		.9808	.9774			.9242	
6		.924	1.0082	.9335		.9055	
7	.8779	.8962	.924	.8962	.8589	.8686	.8215
8	.8507	.8596	.8688		.8871	.7619	.8413
9	.8417		.8859		.7865		.8688
10	.8764				.9036		.9465
11	.8048		1.0745		.9671		1.0498
12	.9145					.9231	1.086
13	.924				.9511		1.0425
14	.9425		1.1523		.9412		1.0974
15	1.0164				1.0059		1.1706
16	1.0164		1.1765		1.0974		1.267
17	.924		1.0745		1.0498		1.1462
18	.8688				.9955		1.0924
19	1.0242				.9955	1.0242	1.134
20	1.2567			1.2382	1.1576	1.2382	1.3491
21	1.2012		1.0903		1.0829		1.2752
22	1.1949		1.251		1.1389	1.1763	1.2382
23	1.2696		1.251		1.1317		1.2883
24	1.1506	1.1506	1.1763		1.0374	1.0374	1.0374
Max	1.2696	1.1506	1.251	1.2382	1.1576	1.2382	1.3491
Min	.8048	.8596	.8688	.8962	.7865	.7619	.8215
Avg	.9975	.9956	1.0701	1.0226	.9993	.9851	1.0973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 202 / 11 KV Tasgaon II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9955	1.0719			.9492	
2		.9774	1.0608			.9313	
3		.9593	.9877			.9036	
4		.9412	.9412			.9036	
5		.9412	1.0349			.9412	
6		.9979	1.0349	.9231		1.0642	
7	1.0082	.9795	1.0456	.924	.9979	.9425	.961
8	.7865	.7701	.8686		.823	.8413	.7964
9	.7421		.8686		.7421		.7865
10	.8316				.8316		.8589
11	.8686		1.0562		.8871		.9896
12	.9522					.9896	1.0374
13					.9425		1.0456
14	.9896				.9425		1.0642
15	.9979				.9145		1.0642
16	1.0164		1.0642		.924		1.0642
17	.9896		1.094		.9522		1.0751
18	.9335				.9808		1.0751
19	1.1694				1.1317	1.1317	1.3014
20	1.3203			1.2637	1.2449	1.358	1.3769
21	1.251				1.251		1.358
22	1.2323		1.1949		1.1949	1.1827	1.251
23	1.1458		1.1273		1.1157		1.1643
24	1.0791	1.0425	1.2696		1.0136	1.0136	1.0136
Max	1.3203	1.0425	1.2696	1.2637	1.251	1.358	1.3769
Min	.7421	.7701	.8686	.9231	.7421	.8413	.7865
Avg	1.0185	.9561	1.0480	1.0369	.9935	1.0117	1.0713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 203 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5544	.5373	.4961		.5552	
2		.5373	.4961			.5373	
3		.5316				.5316	
4		.5316				.5493	
5		.5316				.5847	
6		.5316	.5731	.567		.5316	
7	.5784	.5552	.5847	.5784	.6556	.4961	.6024
8	.5847	.4706	.6661		.6379	.691	.6661
9	.631		.6661		.6379		.6485
10	.5609				.5784		.5959
11	.5316		.6268		.5194		.5138
12	.4835					.567	.5138
13					.443		.5258
14	.4835				.5316		.4607
15	.3475				.5609		.4961
16	.3511		.5847		.6135		.4961
17	.499		.6805		.6135		.6201
18	.6135				.6201		.6379
19	.6201				.5493	.5847	.6379
20	.5959			.4656	.4477	.5316	.6024
21	.443				.4477		.443
22	.4477		.4477		.5316	.4477	.4477
23	.3696		.5853		.4706		.4706
24	.5552	.5373	.5493	.5175	.5194	.5552	.5194
Max	.631	.5552	.6805	.5784	.6556	.691	.6661
Min	.3475	.4706	.4477	.4656	.443	.4477	.443
Avg	.5115	.5312	.5831	.5249	.5517	.551	.5499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 204 / 11KV NEW TASGAON

INDUSTRIAL FE Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0633		.0743		.0572	
2		.0633				.0572	
3		.0625				.0572	
4		.064	.0739			.0572	
5		.064				.0572	
6		.0594		.088		.0572	
7	.064	.0617	.0934	.0556	.0602	.0594	.0549
8	.0633	.0663	.0934		.0625	.0625	.0594
9	.0625		.0739		.0983		.0949
10	.1029				.1829		.2241
11	.112		.2286		.1509		.1886
12	.1509					.2218	.2263
13	.112				.1886		.2263
14	.1109				.1509		.0747
15	.1109				.1886		.1097
16	.1097		.2218		.1509		.1509
17	.1097		.1989		.1886		.1509
18	.1097				.1509		.0754
19	.1509				.1097	.0754	.1086
20	.1509			.1494	.1132	.0716	.0594
21	.1509				.1132		.0594
22			.1132		.112	.0526	.0564
23	.0602		.0789		.0617		.0579
24	.1109	.061	.0724	.0732	.0556	.0579	.0556
Max	.1509	.0663	.2286	.1494	.1886	.2218	.2263
Min	.0602	.0594	.0724	.0556	.0556	.0526	.0549
Avg	.1084	.0628	.1248	.0881	.1258	.0726	.1130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 205 / 11 KV Bendri - Nimani

GAOTHAN FEEDER

GAONTHA Feeder KV- 11 / OUTGOING

DATE	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0381		.0377	
2				.0377	
3				.0377	
4				.0377	
5				.0377	
6	.0366	.0377		.0377	
7	.0377	.0556	.0754	.0377	.0377
8	.0373		.0377	.0377	.0377
9	.0366		.0377		.0377
10			.0377		.0377
11	.0377		.0377		.0377
12				.0373	.0377
13			.0377		.0377
14			.0377		.0377
15			.0377		.0377
16	.0366		.0377		.0377
17	.0362		.0377		.037
18			.0377		.0366
19			.0373	.0747	.0366
20		.0754	.0377	.0754	.0373
21			.0377		.0377
22	.0747		.0377	.0762	.0377
23	.0762		.0377		.0377
24	.0373	.0381	.0377	.0377	.0754
Max	.0762	.0754	.0754	.0762	.0754
Min	.0362	.0377	.0373	.0373	.0366
Avg	.0441	.0490	.0399	.0464	.0396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 201 / 11 KV NIMANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2096	.1905	.1524	1.2498	1.166	1.2811
2	.2286	.2096	.1905	.1524	1.2967	1.1401	1.2651
3	.2096	.2096	.2096	.1334	1.2651	1.1401	1.2334
4	.2096	.2096	.2286	.1334	1.2483	1.1142	1.1248
5	.2477	.2286	.2286	.1524	1.2967	1.2003	1.1544
6	.2858	.2667	.2477	.2096	1.4232	1.4899	1.2651
7	.2667	.2477	.2858	.2286		1.8187	1.5203
8	.2286	.2667	.2667	.2477	1.9608	1.9951	1.3757
9	.2286	.3048	.2667	.2858	2.0715	1.8947	1.6484
10	.2286	.2858	.2667	.2667	.1715	.1715	.1715
11	2.3158		2.3148	.2667	.2477	.1905	2.0083
12	2.1715	2.1506	2.3903	.2858	.2477	.2477	1.9292
13		2.0557	2.0153	.1524	.2286	.2477	1.8278
14	1.8138	2.1247	1.829	.1524	.2286	.2667	1.7764
15	1.6872	1.8278	1.8278	.1905	.2286	.2667	1.7078
16	1.6804	1.8747	1.8278	.2477	.2286	.2667	1.6872
17	1.8275	1.9134	1.8027		.2286	.2477	1.7284
18	1.2944	1.7711			.1905	.2096	1.7124
19	.2096	.2477		.1905	.2477		.2667
20	.2477	.3048	.2096	.2667	.2477	.2667	.2858
21	.2667	.2858	.2286		.2667	.2667	.2667
22	.2477	.2477			.2667	.2286	.2477
23	.2286	.2286	.2096		.2667	.1905	.2096
24	.2286	.2096	.2096	.1715	1.2651	1.2483	1.2651
Max	2.3158	2.1506	2.3903	.2858	2.0715	1.9951	2.0083
Min	.2096	.2096	.1905	.1334	.1715	.1715	.1715
Avg	.7210	.7687	.8213	.2046	.7119	.7511	1.2066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 202 / 11 KV TURACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7385	.6401	.6009	.6241	.0953	.1143	.1143
2	.7335	.6249	.5218	.5868	.0953	.1143	.1143
3	.7133	.6249	.5441	.5868	.0953	.1143	.1143
4	.7042	.6478	.5312	.6093	.1143	.1143	.1143
5	.7529	.6802	.703	.6539	.1334	.1143	.1334
6	.8543	1.0227	.8381	.7773	.1715	.1524	.1334
7	.8802	1.2163	1.1822	.8796	.1905	.1715	.1334
8	.9511	1.1822	1.186	.873	.2096	.1905	.1334
9	.9934	1.1797	1.2492	.8993	.1905	.1143	.1715
10	.0953	.0762	.1143	.1143		.1143	.1524
11	.0953	.1143	.1715	.8078		1.2651	.1334
12	.1524		.1524	.8592	1.1717	1.3916	.1524
13	.1715	.1715	.1715	.8539	1.247	1.3125	.1524
14	.1524	.1715	.1715	.828	1.1305	1.1523	.1715
15	.1524	.1715	.1524	.8697	1.0898	1.1227	.1715
16	.1334	.1715	.1524	.9014	1.0688	1.1227	.1524
17	.1334	.1524	.1524		1.1142	1.1385	.1715
18	.1334	.1524			.9069	.9231	.1715
19	.1143	.1715	.0953	.1334	.1524	.1715	.1905
20	.1524	.1905	.1143	.1524	.1715	.1905	.2096
21	.1143	.1905	.1143		.1524	.1905	.1905
22	.0953	.2096	.0953		.1524	.1334	.1524
23	.0953	.1334	.0953		.1524	.1334	.1143
24	.6483	.6706	.6642	.5944	.1143	.1143	.1143
Max	.9934	1.2163	1.2492	.9014	1.247	1.3916	.2096
Min	.0953	.0762	.0953	.1143	.0953	.1143	.1143
Avg	.4067	.4594	.4249	.6634	.4509	.4865	.1485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 203 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3734	.3961	.3734	.4338	.3961	.3961
2	.3772	.3734	.3772	.3772	.415	.3772	.3772
3	.3772	.3734	.3772	.3584	.3734	.3772	.3734
4		.3734	.3881	.3772	.3772	.3772	.3961
5		.4108	.4294	.3961	.4207	.415	.4251
6	.5175	.5121	.439	.4904	.5601	.5788	.4668
7	.4938	.4572	.4904	.4887	.5121	.5359	.5121
8	.3761	.3982	.3982	.3761	.4163	.4854	.4435
9	.3086	.3077	.3292	.2947	.3403	.3475	.2012
10	.3045	.3582	.3258	.2883		.3982	.2033
11	.2715	.3439	.3475	.2883	.3582	.3982	.4024
12	.2896	.3189	.298	.333	.3439	.394	.3481
13	.3258		.3467	.3366	.3258	.362	.3856
14	.3045	.1991	.3506	.3366	.3506	.362	.3721
15	.3077	.2328	.3467	.362	.3582	.3658	.3721
16	.333	.2835	.3429	.3982	.362	.362	.3856
17	.3086	.362	.3185		.362	.3658	.3294
18	.333	.4024			.3403	.3258	.3224
19	.394	.5121	.4755	.4294	.4163	.4207	.4755
20	.5731	.5601	.5611	.6161	.5973	.5853	.6036
21	.5792	.543	.5487		.567	.5544	.5914
22	.5068	.543	.499		.5304	.5175	.5228
23	.4805	.4481	.4481		.4668	.4668	.4668
24	.4108	.4108	.4108	.4108	.4527	.4338	.4338
Max	.5792	.5601	.5611	.6161	.5973	.5853	.6036
Min	.2715	.1991	.298	.2883	.3258	.3258	.2012
Avg	.3895	.3955	.4019	.3859	.4209	.4251	.4086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 204 / 11 kv RAJAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	1.0242	1.0402	.9297	.1334	.1524	.1334
2	.9633	.9717	1.004	.8471	.1334	.1524	.1334
3	.9362	.9717	1.004	.7482	.1334	.1524	.1334
4	.9332	1.0059	.9602	.743	.1334	.1524	.1524
5	.9633	1.0242	.9831	.7628	.1715	.1524	.1524
6	1.0402	1.2308	1.0526	.8069	.1905	.2286	.1905
7	1.4022	1.5074	1.2809	.9701	.2477	.2286	.2096
8	1.3998	1.6766		1.2186	.2096	.2286	.2286
9	1.3565	1.5546	1.4706	1.1149	.1905	.2286	.0953
10	.0762	.1143	.1143	.1334	.1524	.1905	.0953
11	.1334	.1905	.0953	.9842	1.5546	1.8818	.1715
12	.1524		.1905	.9907	1.406	1.7071	.1334
13	.1334	.1524	.1905	1.0279	1.2803	1.6248	.1524
14	.1334	.1524	.1905	1.0155	1.3413	1.6129	.1334
15	.1143	.1905	.1524	1.0753	1.2955	1.6129	
16	.1715	.1905	.1715	1.186	1.3443	1.6091	.1524
17	.1905	.1524	.1905		1.4251	1.6604	.1905
18	.1905	.1715	.1524		1.2742	1.5813	.1905
19	.0762	.1905	.1715	.1524	.1715	.1524	.2286
20	.1905	.2286	.1905	.1905	.2096	.2096	.2477
21	.1905	.2286	.1905		.1905	.2096	.2096
22	.1905	.2096	.1905		.1905	.1905	.1905
23	.1905	.2096	.1905		.1905	.1905	.1905
24	1.0911	1.0623	1.1385	.9488	.0953	.1524	.1524
Max	1.4022	1.6766	1.4706	1.2186	1.5546	1.8818	.2477
Min	.0762	.1143	.0953	.1334	.0953	.1524	.0953
Avg	.5500	.6266	.5355	.834	.5694	.6776	.1682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 205 / 11 KV Nimani Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2218	.2452	.2218	.2263	.2195
2	.2263	.2263	.1991	.2452	.2033	.2263	.2033
3	.2263	.2263	.1991	.2263	.1829	.2263	.1991
4	.2263	.2263	.2195	.2452	.1867	.2263	.2149
5	.2427	.2641	.2218	.2829	.2195	.2641	.2378
6	.2772	.3734	.2534	.3584	.2715	.3921	.2715
7	.2378	.3142	.2896	.2957	.3142	.3109	.3439
8	.197	.2195	.197	.2172	.2534	.2218	.2686
9	.2229	.2012	.1629	.1791	.181	.181	.2353
10	.1753	.181	.1612	.1928	.197	.2012	.2149
11	.181	.2012	.1867	.1949	.1928	.1991	.2195
12	.1612	.1949	.1772	.197	.1791	.2218	.2254
13	.1928	.1949	.2279	.2149	.181	.2126	.2254
14	.1991	.1949	.2229	.2353	.2353	.2353	.2279
15	.1991	.2172	.2254	.2353	.2172	.2378	.2126
16	.197	.2149	.2103	.2378	.2103	.2328	.1991
17	.1402	.2126	.2303		.2149	.1772	.1949
18	.2149	.2303			.181	.1448	.2126
19	.2715	.2865		.3258	.2279		.2715
20	.362	.3544	.3841	.4024	.3761	.4207	.3841
21	.3439	.3801	.3511		.3439	.3841	.3881
22	.3292	.3439	.3326		.2987	.3696	.3361
23	.2987	.3109	.2801		.2987	.3077	.3018
24	.2241	.2452	.2378	.2641	.2561	.2641	.2561
Max	.362	.3801	.3841	.4024	.3761	.4207	.3881
Min	.1402	.181	.1612	.1791	.1791	.1448	.1949
Avg	.2322	.2517	.2360	.2524	.2352	.2558	.2527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi)

Feeder No / Name : 201 / 11 KV MALWADI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0734	.096	.048	.1029	.0734	.0762
2	.0943	.0734	.1097	.0634	.0943	.0734	.0869
3	.0943	.0734	.0857	.0579	.0857	.0734	.0686
4	.0857	.0734	.0566	.072	.0772	.0734	.0503
5	.0772	.0734	.0686	.0652	.0686	.0734	.0503
6	.0686	.0734	.0737	.064	.0583	.0943	.061
7	.0669	.0734	.0943		.0381	.0838	.0594
8	.0566	.0838	.1307	.0463	.0495	.0838	.0686
9	.0686	.0838	.132	.1307	.1048	.0943	.0857
10	.181	.1389	.1143	.1372	.181	.0854	.12
11	.181	.2303	.1698	.2075	.1991	.1619	.1844
12	.181	.2096	.2075	.1698	.2534	.2328	.2452
13	.1448	.2402	.2241	.2587	.2715	.1867	.197
14	.181	.2452	.2263	.2075	.2715	.1677	.1355
15	.181	.2096	.1886	.2286	.2172	.2801	.1696
16	.181	.1886	.1886	.0333	.2172	.1217	.1383
17		.1905	.1886	.2075	.2172	.1067	.1219
18		.1166			.1448	.0909	.0703
19	.1267	.1294	.0671	.1132	.1267	.0754	.0669
20	.1267	.1509	.1509	.0991	.1267	.0793	.06
21	.1267	.1524	.1509	.0909	.1267	.0793	.0754
22	.1267	.1105	.0926	.0854	.1267	.0789	.1162
23	.1267	.1097	.1315	.1166	.1267	.108	.1029
24	.1097	.1267	.1334	.1296	.1115	.1267	.1149
Max	.181	.2452	.2263	.2587	.2715	.2801	.2452
Min	.0566	.0734	.0566	.0333	.0381	.0734	.0503
Avg	.1222	.1346	.1340	.1197	.1416	.1127	.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi)

Feeder No / Name : 203 / 11 KV MALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9878	1.1336	.9998	.6562	.1267	.1134	.1402
2	1.0402	1.267	.9482	.6325	.1254	.1134	.1086
3	1.1043	1.1336	.9259	.6173	.1227	.1134	.1029
4	1.0802	1.1336	.8802	.6093	.1372	.1134	.1075
5	1.1574	1.1336	.8905	.602	.1526	.1134	.1448
6	1.2651	1.1336	1.0242	.6882	.1543	.1457	.1663
7	1.3283	1.3927	1.2654		.1448	.1619	.2012
8	1.4899	1.4575	1.2803	.9374	.1646	.1781	.2195
9	1.3125	1.2955	1.2803	1.0957	.1629	.1781	.1848
10	.0543	.1402	.1254	.124	.1086	.1619	.2012
11	.1086	.1448	.1267	1.4582	.1086	1.7004	.2033
12	.1086	.1417	.1448	1.1248	.2172	1.9498	.2033
13	.1267	.1433	.1448	1.2793	.0543	1.9662	.2195
14		.1629	.1646	1.166	.0543	1.749	.181
15		.1646	.1463	1.1984	.0543	1.6004	.2012
16	.1086	.2012	.1646		.0543	1.358	.1791
17		.2172	.197	.8796	.0543	1.6164	.1949
18		.1417			1.1222	1.4506	.1791
19	.1448	.1772	.1629	.1578	1.267	.1772	.2195
20	.181	.2012	.2054	.2172	.1448	.1646	.2218
21	.1629	.1663	.1848	.1294	.1448	.1663	.2218
22	.1629	.1663	.1867	.1463	.1448	.1867	.2033
23	.1629	.1463	.168	.128	.1448	.1478	.1848
24	.9555	.8145	.8322	.6642	.128	.1402	.1448
Max	1.4899	1.4575	1.2803	1.4582	1.267	1.9662	.2218
Min	.0543	.1402	.1254	.124	.0543	.1134	.1029
Avg	.6521	.5921	.5413	.6910	.2122	.6569	.1806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 201 / 11 KV ARWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3592	1.6057			.2321	
2		1.326	1.6194				
3		1.2929	1.6575			.2294	
4		1.2597	1.7238			.1966	
5		1.2929	1.8351			.1966	
6		1.6575	1.8896	.57		.2652	
7	1.8233	2.0553	2.42	.8122	.2915	.2321	.2753
8	1.8564	2.2542			.3239	.2321	.2915
9	1.6907		2.4813		.2949		.3277
10	.1311				.2622		.3277
11	.1638		.285		2.1548		.2949
12	.0983					2.2801	.3647
13	.1311		.2818		2.0885		.3647
14	.1989		.2818		2.3868		.3978
15	.1989				2.2542		.3978
16	.1989		.2155		2.2211		.3315
17	.1966		.2652		2.3205		.3605
18	.2622				2.0885		
19	.3277				.1966		.3605
20	.3647			.2915	.2294	.3401	.3605
21	.3315		.2486		.2622		.3605
22	.3277		.2486		.2652	.2915	.3315
23	.2622		.2155		.2652		.2984
24	1.3426	1.3592	1.5402		.2267	.2321	
Max	1.8564	2.2542	2.4813	.8122	2.3868	2.2801	.3978
Min	.0983	1.2597	.2155	.2915	.1966	.1966	.2753
Avg	.5504	1.5397	1.1067	.5579	1.0666	.4298	.3403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 204 / 11 KV DHAVLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0495	.048			1.4091	
2		.0476	.0419			1.3603	
3		.0476	.0438			1.2955	
4		.0419				1.3435	
5		.0503	.04			1.4091	
6		.0613	.0514	.0461		1.7238	
7	.0587	.0549	.0613	.0572	2.0056	1.9006	1.9784
8	.0545	.0617			2.0719	2.1628	2.1548
9	.0686		.0692		1.8564		2.4249
10	.1029				.0457		.2427
11	2.0553		2.4863		.0377		2.2211
12	2.1548					.0669	2.1548
13	.1989				.0514		2.1628
14	1.7695		2.0885		.0488		1.8679
15	1.7901				.0396		1.9006
16	1.8233		2.2045		.0396		1.9006
17	1.989		2.0317		.0892		1.9006
18	1.8679				.08		2.0317
19	.0914				.0846		.08
20	.0747			.0667	.0594	.0718	.0827
21	.072		.0533		.064		.0693
22	.072		.0497		.0613	.0549	.0617
23	.0617		.0497		.0572		.0591
24	.0549	.0438	.0503	.0396	1.2407	1.4083	1.4255
Max	2.1548	.0617	2.4863	.0667	2.0719	2.1628	2.4249
Min	.0545	.0419	.04	.0396	.0377	.0549	.0591
Avg	.7978	.0510	.6246	.0524	.4667	1.1839	1.3733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 212 / 11 KV NIMANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2654	1.3108	.9172		.0732	
2		1.2346	1.2929			.0732	
3		1.1873	1.3923			.0724	
4		1.1561	1.3763			.0724	
5		1.1728	1.4586			.1109	
6		1.2963	1.4419	.4214		.1097	
7	1.4403	1.4685	1.6766	.4161	.0747	.1448	.1109
8	1.5043	1.6446			.0739	.1075	.1494
9	1.3123		1.5432		.1086		.1463
10	.1006				.104		.1402
11	.0716		.1132		1.3443		.112
12	.0739					1.6004	.1494
13	.1097		.1494		1.1873		.1109
14	.1075		.1478		1.1561		
15	.1097				1.1111		.1478
16			.1086		1.1561		.1097
17	.1463		.181		1.2498		.1086
18	.1417				1.0802		.1433
19	.1791				.1402		.1417
20	.1829			.1478	.1086	.1463	.1463
21	.1848				.1097		.1463
22	.1867		.1463		.1097	.1494	.1478
23	.1494		.1478		.1097		.1109
24	1.2334	1.2803	1.2803		.1097	.0739	.1109
Max	1.5043	1.6446	1.6766	.9172	1.3443	1.6004	.1494
Min	.0716	1.1561	.1086	.1478	.0739	.0724	.1086
Avg	.4255	1.3007	.8604	.4756	.5490	.2278	.1313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 401 / 33KV Hatnoor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.678	3.9609			3.7346	
2		3.5082	3.8089			3.6214	
3		3.3951	3.5848			3.5082	
4		3.2819	3.6591			3.5082	
5		3.2819	3.8477			3.5082	
6		3.2819	3.6969	3.2819		3.6214	
7	3.1687	3.1687	3.5848	3.1687	3.2819	3.1687	2.9424
8	2.9424	3.0556			3.0556	3.2487	2.7161
9	2.8292		3.1367		2.8292		3.3608
10	2.7161				2.963		3.6591
11	2.8292		4.3244		3.4728		4.2135
12	3.1687					4.0329	4.2798
13	3.2819				3.6969		4.2798
14	3.3608		3.9209		3.77		3.5082
15	3.2819				3.3608		4.145
16	3.2819		4.3244		3.4728		4.145
17	3.1367		4.1027		3.1047		4.1027
18	3.1367				3.6591		3.8809
19	3.6969				3.8089		4.257
20	4.257			3.9609	4.145	4.481	4.481
21	3.9609		3.8409		4.0741		4.257
22			4.1872		4.0741	4.0741	4.3004
23	3.8477		4.0741		3.9609		
24	3.658	3.8477	4.0329		3.6214	3.9609	2.9424
Max	4.257	3.8477	4.3244	3.9609	4.145	4.481	4.481
Min	2.7161	3.0556	3.1367	3.1687	2.8292	3.1687	2.7161
Avg	3.3267	3.3888	3.8805	3.4705	3.5501	3.7057	3.8512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 201 / 11 KV KASABE DIGRAJ

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.4715	.4854	.6878	.679	.5093	.6154
2	.6224	.4715	.4481	.6878	.679	.4904	.6154
3	.6224	.4527	.4481	.6878	.679	.4904	.6154
4	.6602	.4527	.4527	.6878	.679	.4904	.6154
5	.6602	.4715	.4481	.6878	.679	.5281	.6154
6	.6224	.4904	.4854	.7421	.547	.7733	.4572
7	.6979	.3961	.4294		.4338	.5281	.4344
8	.6348	.3772	.4338	.5973	.5281	.4715	.5552
9	.5415	.6036	.4854	.6154	.3772	.6413	.5731
10	.4294	.7095	.4938	.6335	.5973	.5788	.7167
11	.3361	.8029	.5373	.5068	.3658	.6161	.7356
12		.7282	.7783	.6401	.6805	.6161	.7545
13	.3734	.7095	.5973	.6401	.6805	.6348	.679
14	.4108	.7655	.7602	.695	.4887	.5228	.679
15	.3921	.7842	.6401	.7316	.6626	.7095	.7545
16	.4108	.7095	.5304	.6219	.4024	.7282	.7356
17		.4668	.439	.3475	.5121	.7282	.6036
18		.5975			.4715	.4344	.5975
19	.547	.6979	.6697	.6348	.7167	.6984	.7095
20	.6224	.6535	.7602	1.531	.6224	.8682	.8775
21	.6224	.5601	.7783	2.2916	.7545	.7087	.8029
22	.6224	.5601	.8059	2.1068	.811	.7796	.7282
23	.5658	.5788	.7164	.7167	.7545	.6805	.7167
24	.6602	.4904	.6722	.7059	.679	.7167	.6805
Max	.6979	.8029	.8059	2.2916	.811	.8682	.8775
Min	.3361	.3772	.4294	.3475	.3658	.4344	.4344
Avg	.5560	.5834	.5781	.8271	.6034	.6227	.6612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.0943	.0747	.4917	.4715	.5079
2	.0754	.0943	.0943		.4917	.4715	.5079
3	.0754	.0943	.0943	.0747	.4917	.4904	.5079
4	.0754	.0943	.0943	.0747	.4917	.5093	.5079
5	.0754	.0943	.0943	.0747	.5087	.5093	.5407
6	.0754	.0943	.0943	.0747	.4334	.5658	.5992
7	.0566	.0754	.0943	.0747	.4681	.6036	.664
8	.0566	.0754	.0754	.056	.4854	.6413	.6802
9	.0566	.0754	.0754	.0554	.5028	.6443	.7449
10	.0754	.0566		.0566		.0566	.0566
11	.8745	1.0117	1.0202	.0566	.0747	.0566	.8478
12		.9602		.0566	.0747	.0754	.8478
13	.823	.6173	.9831	.0754	.0747	.0754	.8309
14	.8402	.8745	1.065	.0754	.0747	.0754	.6613
15	.823	.9431	.9831	.0754	.0747	.0754	.6952
16	.9088	.9088	.8848	.0754	.0747	.0754	.6783
17		.9602	.8122	.0754	.0747	.0754	.6952
18		.8916			.0754	.0747	.6859
19	.0943	.0943		.0566	.0754	.0747	.0943
20	.1132	.0943	.0747	.0566	.0943	.0747	.0943
21	.1132	.0943	.0747	.0754	.0943	.0747	.0943
22	.1132	.0943	.0747	.0566	.0943	.0747	.1132
23	.1132	.0934	.0747	.0566	.0943	.0747	.0943
24	.0754	.1132	.0943	.0747	.373	.4715	.5079
Max	.9088	1.0117	1.065	.0754	.5087	.6443	.8478
Min	.0566	.0566	.0747	.0554	.0747	.0566	.0566
Avg	.2662	.3583	.3476	.0674	.2517	.2663	.5107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 203 / 11 KV TUNG GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1509	.2012	.1886	.1886	.1991
2	.1886	.1886	.1509	.2012	.1886	.1698	.1991
3	.1886	.1886	.1509	.2012	.1886	.1698	.1991
4	.1886	.1886	.1886	.2012	.1886	.1698	.1991
5	.2075	.2263	.2263	.2012	.2075	.1886	.2507
6	.2829	.2829	.2452	.2926	.2614	.3018	.2507
7	.2263	.2452	.2263		.2614	.2829	.2328
8	.1886	.2075	.2263	.2195	.2427	.2452	.2353
9	.1886	.2452	.1886	.2378	.2241	.2263	.2534
10	.2829	.2614		.2378		.2614	.2829
11	.2263	.2427	.2353	.2195	.2353	.2241	.2452
12		.2054	.2172	.2452	.2353	.2241	.2641
13	.2452	.2427	.2896	.2614	.2715	.2614	.2452
14	.2452	.2614	.2896	.2614	.2353	.2614	.2641
15	.2263	.2427	.2534	.2427	.181	.2054	.2075
16	.2263	.2054	.2353	.2427	.181	.2054	.2263
17		.2427	.2715	.2614	.2534	.2427	.2263
18					.2452	.2743	.2614
19	.2829	.2829		.3174	.2829	.2561	.2801
20	.3584	.2829	.3109	.3361	.3395	.3258	.3361
21	.3395	.2829	.2926	.3361	.3018	.3077	.3361
22	.3395	.2641	.2926	.2801	.3018	.2896	.3361
23	.2641	.2427	.2561	.2614	.2641	.2534	.2801
24	.1886	.2075	.1886	.2012	.2075	.2075	.1991
Max	.3584	.2829	.3109	.3361	.3395	.3258	.3361
Min	.1886	.1886	.1509	.2012	.181	.1698	.1991
Avg	.2416	.2360	.2327	.2482	.2386	.2393	.2504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 205 / 11 KV TUNG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.0943	.0747	1.291	1.1736	1.0814
2	.0754	.0943	.0943	.0747	1.291	1.2071	1.0814
3	.0754	.0943	.0943	.0747	1.291	1.2071	1.0814
4	.0754	.0943	.0943	.0747	1.2742	1.21	1.0814
5	.0754	.0943	.0943	.0747	1.2742	1.2431	1.1336
6	.0754	.0943	.0943	.0747	1.1233	1.3916	1.2308
7	.0943	.1132			1.4922	1.5089	1.4413
8	.1132	.1132	.1132	.112	1.5592	1.5927	1.6032
9	.0754	.0943	.132	.0739	1.7295	1.5927	1.6842
10	.0943	.0943	.1307	.1132		.1132	.1132
11	1.9161	2.5434	2.1628	.0924	.0934	.0943	2.1195
12		2.4417	2.2708	.0943	.0747	.1132	2.0517
13	1.7804	2.2382	2.0622	.0754	.0747	.0943	2.0178
14	1.7974	2.2721	1.9281	.0754	.0747	.1132	1.8564
15	1.7804	2.0687	1.5581	.0566	.0747	.0943	1.8107
16	1.6956	2.0008	1.8067	.0943	.0934	.0943	1.8067
17		1.8991	1.7604	.0943	.0934	.0943	1.757
18		1.6278			.0943	.1307	1.7974
19	.0943	.1132	.056	.0943	.0943	.1307	.0943
20	.1132	.1132	.0747	.0943	.0943	.1478	.1132
21	.0943	.0943	.0747	.0754	.1132	.1109	.132
22	.0943	.0943	.0747	.0754	.0943	.0924	.0943
23	.0754	.0943	.0747	.0754	.0943	.0924	.0943
24	.0754	.0754	.0943	.0747	1.1233	1.0898	1.0814
Max	1.9161	2.5434	2.2708	.1132	1.7295	1.5927	2.1195
Min	.0754	.0754	.056	.0566	.0747	.0924	.0943
Avg	.4927	.7774	.6791	.0827	.6353	.6139	1.1816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 206 / 11 KV VASANT LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.2641	.1417	.0943	.1509	.0829
2	.1509	.2641	.1417	.0943	.1509	.0995
3	.1509	.2641	.1595	.0943	.1509	.1147
4	.1509	.2641	.1753	.0943		.1311
5	.1698	.2641	.1928	.0943	.1509	.1619
6	.3395	.2641	.298	.0566	.2263	.2267
7	.3395	.3018		.0943	.2452	.2591
8	.3206	.3206	.2481	.1509	.4904	.3841
9	.3772	.3584	.2804	.2452	.4527	.4001
10	.3772		.3018		.4904	.6224
11	.3961	.362	.3584		.5093	.6413
12	.3772		.3772	.2865	.4904	.3772
13	.3584	.3258	.3018	.2865	.4904	.3772
14	.3772	.3429	.2641	.2865	.4904	.3772
15	.3772	.3429	.2641	.2865	.5093	.3206
16	.3772	.3429	.2075	.0724	.5093	.3584
Max	.3961	.362	.3772	.2865	.5093	.6413
Min	.1509	.2641	.1417	.0566	.1509	.0829
Avg	.2994	.3059	.2475	.1598	.3672	.3084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 201 / 11 KV Mouje Digraj Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.032		
2					.032	.0312	
3					.032	.0324	
4					.032	.0324	.0187
5					.0324	.0324	.0373
6					.0324	.0324	.0373
7					.0324	.0324	.0373
8					.0324	.0328	.0373
9					.0324	.0339	.0187
11	.0324	.0373	.0373				.0373
12		.0373	.0373				.0373
13	.0324	.0187	.0373				.0373
14	.0324	.0187	.0373				.0373
15	.0324	.0187	.0373				.0373
16	.0324	.0373	.0373				.0373
17		.0373					.0373
18	.0324	.0187					.0373
24				.032		.0324	.0187
Max	.0324	.0373	.0373	.032	.0324	.0339	.0373
Min	.0324	.0187	.0373	.032	.032	.0312	.0187
Avg	.0324	.028	.0373	.032	.0322	.0325	.0336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 203 / 11 KV PWV BRAMHNAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1254	.168	.0189	.0857	.1227	
2	.1294	.1254		.0189	.0857	.1227	
3	.1294	.1254		.1663	.1214	.1227	
4	.1848	.1254		.1848	.1214	.1227	.168
5	.1848	.1254	.2241	.1848	.1214	.1753	.2427
6	.1867	.2149	.2427	.2033	.1214	.1753	.2427
7	.1867	.2126	.2614		.1387	.2149	.2614
8	.1867	.1254	.2614	.1494	.1214	.2195	.2801
9	.168	.1254	.2614	.1494	.1227	.2126	.2801
10	.1492	.2801	.2241	.1848	.0914	.2957	.2427
11	.168	.3174	.2241	.1848	.0914	.3142	.2427
12		.2987	.2241	.1848	.0537	.2241	.2427
13	.1357	.2614	.2241	.1086	.0701	.2218	.2427
14	.1357	.2801	.1494	.1086	.0526		.2353
15	.1433	.2218	.1494	.1086	.0514	.2218	.2427
16	.1433	.2033	.1494	.1086	.0514	.1867	.2427
17		.2218	.1494	.1086	.0514	.2241	.1829
18	.1433	.056			.0351	.1867	.1829
19	.1433	.2241	.0189	.1029	.1753	.1867	.2241
20	.1433	.2054	.0189	.1029	.1578	.1867	.2241
21	.1433	.1867	.0189	.1029	.1578	.1867	.2241
22	.1433	.168	.0189	.1029	.1578	.168	.2241
23	.1254	.1494	.0189	.1029	.1227	.1494	.2241
24	.1663	.1254	.0189	.1029		.1227	
Max	.1867	.3174	.2614	.2033	.1753	.3142	.2801
Min	.1254	.056	.0189	.0189	.0351	.1227	.168
Avg	.1532	.1877	.1513	.1268	.1026	.1897	.2326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 204 / 11 KV EXPRESS LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2402	.2033	.2033	.1867	
2	.2561		.2033	.2033	.1867	
3	.2561		.2033	.2033	.1867	
4	.2561		.2033	.2054	.1867	.2402
5	.2561	.2427	.2218	.2054	.1867	.2402
6	.2561	.2402	.2218	.2054	.1867	.2614
7	.2614	.2587		.2054	.2987	.2587
8	.2561	.2587	.1867	.0191	.2987	.2587
9	.2614	.2587	.2801	.1494	.2987	.2587
10		.2987	.2801	.1494	.2587	.2561
11	.2801	.2987	.2801	.1494	.2587	.2561
12	.2587	.2987	.2801	.2614	.2587	.2561
13	.2402	.3018	.2801	.2614	.2587	.2561
14	.2587	.2987	.2801	.2587		.2926
15	.2614	.2987	.2801	.2614	.2587	.2926
16	.2614	.2987	.2801	.2614	.2587	.2926
Max	.2801	.3018	.2801	.2614	.2987	.2926
Min	.2402	.2402	.1867	.0191	.1867	.2402
Avg	.2584	.2764	.2456	.2002	.2379	.2631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 205 / 11 KV YESHWANT EXPRESS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2934	1.0985	1.2403	1.2403	1.6301	
2	1.2934		1.2403	1.2403	1.6301	
3	1.2934		1.2403	1.2403	1.6301	
4	1.2934		1.2403	1.2403	1.6301	1.5592
5	1.2934	1.0985	1.2715	1.2403	1.6301	
6	1.4175	1.1218	1.5402	1.3969	1.6301	1.6126
7	1.4529	1.2269		1.4685	1.7364	1.6827
8	1.134	1.2403	1.7551	1.7551	1.7364	1.701
9	1.2403	1.2403	1.773	1.7551	1.7364	1.7878
10	1.2178	1.6461	1.7909	1.7718	1.7364	1.7718
11	1.3112	1.6289	1.7909	1.7718	1.8229	1.7718
12	1.2403	1.6461	1.8267		1.7528	1.7718
13	1.2048	1.5947	1.8088		1.7718	1.7718
14	1.1568	1.6289	1.8088			1.701
15	1.1694	1.6461	1.8088		1.7718	1.701
16	.8505	1.6118	1.5223		1.4529	1.701
Max	1.4529	1.6461	1.8267	1.7718	1.8229	1.7878
Min	.8505	1.0985	1.2403	1.2403	1.4529	1.5592
Avg	1.2414	1.4176	1.5772	1.4655	1.6866	1.7111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 206 / 11 KV NAWARASWADI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.394	.1865	.1677	.3121	
2	.3052		.1865	.1677	.3121	
3	.3052		.1865	.1844	.3121	
4			.1865	.1844	.3121	.2328
5	.3052	.3544	.2012	.1844	.3121	.2328
6	.3052		.2012	.1865	.3121	.2328
7	.2774			.1865	.3121	.4298
8	.0867	.0895	.0663	.0819	.3189	.4656
9	.0867	.0895	.1006	.0819	.3189	.4508
10	.0895	.1086	.1006	.3772	.3224	.3155
11	.3403	.1063	.1174	.3258	.3224	.3155
12	.3224	.1063	.1174	.3294	.3224	.3155
13	.0895	.1063	.2915	.3086	.3224	.3155
14	.2149	.2172	.2915	.3086		.1063
15	.4119	.2195	.2915	.3086	.3224	.1063
16	.2507	.2195	.3086	.3086	.2865	.1052
Max	.4119	.394	.3086	.3772	.3224	.4656
Min	.0867	.0895	.0663	.0819	.2865	.1052
Avg	.2464	.1828	.1889	.2308	.3147	.2788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244037 / 33/11 KV PRAKASH AGRO

Feeder No / Name : 201 / 11 KV HARIPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9724	.8907	.8002		.0189	.0189	.0189
2	.9282	.8907	.7842		.0189	.0189	.0189
3	.9282	.9503	.8002		.0189	.0189	.0189
4	.9175	.9831	.7907		.0189	.0189	.0189
5	.9012	.9717	.8065			.0377	.0189
6	.9503	.9762	.8745		.0189	.0377	.0189
7	1.0242	1.0978	1.0364		.0189	.0189	.0189
8	1.0364	1.166	1.0883		.0189	.0189	.0189
9	1.0688	1.1336	1.1174	.6642	.0189	.0189	.0189
10	.0189	.0566	.0189	.0189	.0377	.0189	.0189
11	.0189	.0189	.0189	.6964	.583	.7042	.0377
12		.0189	.0189	.7202	.6081	.7293	.0377
13	.0189	.0189	.0189	.7773	.506	.6882	.0377
14	.0189	.0189	.0189	.7537	.5601	.779	.0189
15	.0189	.0189	.0189	.7209	.5182	.663	.0189
16	.0189	.0189	.0189	.7274		.7625	.0189
17		.0189		.7274		.7459	.0377
18		.0377				.6722	.0377
19	.0189	.0377		.0189		.0189	.0189
20	.0189	.0189		.0189	.0377	.0189	.0189
21	.0189	.0189		.0189	.0189	.0189	.0377
22	.0189	.0377		.0189	.0189	.0189	.0189
23	.0189	.0377		.0189	.0189	.0189	.0189
24	.9724	.7935	.8097		.0189	.0189	.0189
Max	1.0688	1.166	1.1174	.7773	.6081	.779	.0377
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.4718	.4263	.5318	.4215	.1620	.2535	.0236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 201 / 11 KV DUDHGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.502	.5898	.4801	.2949	.0189	.0187	.0189
2	.5182	.5898	.4744	.426	.0189	.0189	.0187
3	.5304	.5898	.4744	.426	.0189	.0187	.0187
4	.5304	.5898	.5121	.426	.0187	.0189	.0189
5	.5601	.5898	.506	.426	.0189	.0187	.0189
6	.5992	.6062	.5155	.4752	.0189	.0189	.0187
7	.6516	.6226	.5468	.5079	.0189	.0185	.0189
8	.6859	.639	.5535	.5407	.0189	.0187	.0189
9	.6859	.639	.5921	.5898	.0189	.0187	.0189
10	.0187	.0185	.0189	.0177	.0187	.0187	.0183
11		.0183	.0189	.6093	.6133	.6944	.0179
12		.0187	.0189	.6562	.5668	.703	.0185
13		.0189	.0189	.6325	.5921	.679	.0187
14		.0189	.0189	.6241	.6062	.6874	.0189
15		.0189	.0189	.5851	.5668	.6642	.0187
16		.0189	.0189	.5761	.5851	.6405	.0187
17	.0187	.0187	.0189	.5601	.583	.6405	.0185
18	.0187	.0183		.4481	.5601	.6167	.017
19	.0187	.0187	.0189	.0187	.0189	.0185	.0187
20	.0187	.0189	.0189	.0187	.0187	.0189	.0187
21	.0187	.0189	.0189	.0187	.0189	.0189	.0189
22	.0187	.0189	.0189	.0185	.0187	.0189	.0187
23	.0187	.0189	.0189	.0185	.0189	.0189	.0189
24	.4902	.5407	.4801	.2949	.0189	.0189	.0187
Max	.6859	.639	.5921	.6562	.6133	.703	.0189
Min	.0187	.0183	.0189	.0177	.0187	.0185	.017
Avg	.3280	.2608	.2339	.3837	.2073	.2344	.0186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 202 / 11 KV KAVATHE PIRAN

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3734	.3696	.3395	.3734	.3395	.415
2	.3511	.3734	.3696	.3395	.3361	.3547	.3174
3	.3475	.3734	.3658	.3395	.3361	.3361	.3174
4	.3475	.3734	.4251	.3395	.3395	.3206	.3174
5	.3547	.3734	.4572	.3395	.415	.3921	.3142
6	.3734	.4668	.4938	.4481	.4668	.4715	.3547
7	.4024	.4108	.4435	.415	.439	.3395	.4481
8	.3511	.3361	.3921	.3206	.3696	.3142	.3547
9	.3326	.3174	.3734	.2641	.3361	.2926	.3395
10	.2987	.3547	.3224	.3584	.2743	.2715	.3077
11		.3361	.3224	.3395	.2587	.3292	.3439
12		.3547	.3292	.3361	.2587	.3326	.3109
13		.3734	.3361	.3361	.3292	.3292	.3658
14	.3142	.3734	.3547	.3921	.3361	.3326	.3511
15	.3142	.3547	.3547	.3921	.2987	.3361	.3547
16	.3142	.3547	.3734	.3361	.2772	.3142	.3326
17	.2507	.3439	.3547	.3544	.2743	.3174	.2865
18	.3292	.3155		.3881	.2865	.3361	.3439
19	.4854	.443	.4854	.499	.3547	.4904	.439
20	.5415	.5083	.5093	.5175	.3921	.547	.499
21	.5415	.5434	.5093	.5228	.4715	.547	.5415
22	.4854	.5083	.4527	.4668	.4294	.5093	.5093
23	.4294	.4382	.3772	.4481	.3772	.4527	.4668
24	.4108	.3921	.3856	.3584	.3734	.3584	.415
Max	.5415	.5434	.5093	.5228	.4715	.547	.5415
Min	.2507	.3155	.3224	.2641	.2587	.2715	.2865
Avg	.3775	.3914	.3981	.3830	.3502	.3735	.3769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 203 / 11 KV KAVATHE PIRAN AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0117	1.17	1.0974	.7209	.0112	.0126	.0105
2	1.0343	1.17	1.0974	.7209	.0114	.0128	.0107
3	1.0174	1.17	1.1145	.7209	.012	.013	.0109
4	1.0562	1.17	1.1022	.7209	.0122	.0131	.0118
5	1.1145	1.17	1.1191	.7209	.0124	.0131	.0122
6	1.1361	1.17	1.1488	.7377	.0126	.0135	.0126
7	1.166	1.1869	1.1488	.788	.0109	.0131	.013
8	1.2003	1.2039	1.0974	.8215	.0107	.0128	.013
9	1.2174	1.2039	1.0852	.8886	.0107	.0126	.013
10	.0095	.009	.0082	.0084	.0109	.0128	.0128
11		.0078	.0082	1.1736	1.166	1.0898	.0133
12		.0095	.0082	1.17	1.0802	1.1105	.0128
13		.0101	.0082	1.1869	1.0974	1.1736	.013
14		.0109	.0082	1.2209	1.1317	1.1603	.0128
15		.0111	.0082	1.2239	1.166	1.1603	.0126
16		.0109	.0082	1.2209	1.1191	1.1568	.0128
17	.0095	.0109	.0082	1.1317	1.166	1.1568	.0128
18	.0095	.0109		1.0974	1.0974	1.153	.013
19	.0095	.0109	.0082	.0111	.0082	.0084	.0128
20	.0095	.0107	.0082	.0112	.0082	.0084	.0131
21	.0095	.0107	.0082	.0112	.0084	.0084	.0162
22	.0095	.0109	.0082	.0112	.0105	.0084	.016
23	.0095	.0109	.0082	.0111	.013	.0084	.016
24	.9835	1.153	1.0974	.7042	.0109	.0122	.0086
Max	1.2174	1.2039	1.1488	1.2239	1.166	1.1736	.0162
Min	.0095	.0078	.0082	.0084	.0082	.0084	.0086
Avg	.6119	.4964	.4876	.7098	.3833	.3894	.0128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 204 / 11 KV SAMDOLI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2614	.2614	.2614	.2743	.2614	.2614
2	.2561	.2614	.2614	.2614	.2402	.2402	.2427
3	.2587	.2614	.2614	.2614	.2378	.2587	.2241
4	.2587	.2614	.2801	.2614	.2402	.2427	.2263
5	.2195	.2614	.2987	.2614	.2743	.2587	.2263
6	.2218	.2614	.3174	.2801	.3142	.2427	.2241
7	.2378	.2427	.2743	.2614	.2561	.2402	.2427
8	.2033	.2241	.2427	.2241	.2378	.2241	.2427
9	.2054	.2614	.2427	.2054	.2054	.2263	.2054
10	.2241	.2614	.2427	.2427	.2402	.2452	.2402
11	.2241	.2427	.2427	.2427	.2427	.2829	.2772
12		.2427	.2427	.2801	.2772	.2641	.2801
13	.2427	.2614	.2614	.2801	.112	.2641	.2772
14	.2427	.2614	.2801	.2614	.2587	.2641	.2772
15	.2427	.2614	.2801	.2614	.2801	.2641	.2561
16	.0187	.2614	.2987	.2957	.3077	.2614	.2829
17	.0187	.2427	.2614	.2614	.2534	.2614	.2614
18	.2614	.2427		.2801	.2481	.2772	.2614
19	.3921	.3361	.3734		.3142	.3361	.3142
20	.4108	.4294	.3734		.3361	.3734	.3547
21	.4108	.4294	.3734	.439	.3584	.3921	.415
22	.3734	.3734	.3547	.3511	.3361	.3584	.3734
23	.3361	.3734	.3174	.3109	.3206	.3361	.3395
24	.2987	.2801	.3174	.2614	.2743	.2614	.2987
Max	.4108	.4294	.3734	.439	.3584	.3921	.415
Min	.0187	.2241	.2427	.2054	.112	.2241	.2054
Avg	.2528	.2832	.2895	.2748	.2683	.2765	.2752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 205 / 11 KV SAMDOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0189	.0187	.3734	.3856	.4435
2	.0187	.0187	.0189	.0187	.3734	.4862	.462
3	.0187	.0187	.0189	.0187	.3734	.5668	.4938
4	.0185	.0187	.0189	.0187	.3921	.6874	.4938
5	.0018	.0187	.0189	.0187		.547	.5373
6	.0187	.0187	.0189	.0187	.4108	.39	.6099
7	.0183	.0187	.0189	.0187	.2987	.4287	.6584
8	.0189	.0187	.0189	.0187	.4108	.4641	.7762
9	.0189	.0187	.0189	.0187	.4108	.502	.8962
10	.0189	.0187	.0171	.0187		.0187	.0168
11		1.6804	1.7318	.0187		.0187	1.0387
12		1.6975	.0171	.0187	.0164	.0187	1.0277
13		1.7177	1.7318	.0187	.0168	.0187	.9922
14		1.773	1.7147	.0189	.0179	.0187	.9745
15		1.773	1.6804	.0189	.0173	.0187	.985
16		1.773	1.6461	.0189	.0171	.0187	.9568
17	1.1317	1.6975	1.5604		.0181	.0187	.9391
18	1.2174	1.6221		.0189	.0173	.0189	.9114
19	.0187	.0189	.0187		.0179	.0189	.0171
20	.0187	.0189	.0187		.0183	.0189	.0179
21	.0187	.0189	.0187	.0189	.0187	.0189	.0183
22	.0187	.0189	.0187	.0189	.0187	.0189	.0183
23	.0187	.0189	.0187	.0189	.0189	.0189	.0185
24	.0187	.0187	.0189	.0187	.3772	.3721	.4252
Max	1.2174	1.773	1.7318	.0189	.4108	.6874	1.0387
Min	.0018	.0187	.0171	.0187	.0164	.0187	.0168
Avg	.1462	.5848	.4514	.0188	.1730	.2122	.5720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 206 / 11 KV SHAURYA INDUSTRIES NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0373	.056	.0373	.0747	.0187
2	.0187	.0187	.0373	.056	.0373	.0724	.0187
3	.0187	.0187	.0373	.056	.0373	.0335	.0187
4	.0187	.0187	.0373	.056	.0373	.0145	.0187
5	.0187	.0187	.0373	.056	.0373	.017	.0187
6	.0187	.0187	.056	.0187	.0373	.0177	.0187
7	.0187	.0187	.0187	.0187	.0373	.0724	.0187
8	.0187	.0187	.0747	.0187	.0187	.0554	.0187
9	.0187	.0747	.112	.1494	.0187	.0934	.0373
10	.0187	.0934	.1509	.1307	.0537	.0934	.0739
11		.0373	.1509	.1494	.0526	.0934	.1132
12		.0934	.1509	.168	.132	.0934	.132
13		.0934	.1509	.168	.1494	.0934	.1307
14		.112	.1509	.168	.1698	.0934	.1132
15		.1307	.1509	.1494	.112	.0943	.1698
16		.1307	.132	.1494	.132	.0934	.1698
17	.0187	.0934	.1509	.0373	.1698	.0187	.1509
18	.0187	.0747		.0373	.1132	.0373	.132
19	.0187	.056	.0189	.1307	.132	.0373	.0876
20	.0187	.0373	.0189	.0373	.112	.0373	.0732
21	.0187	.0373	.0566	.0373	.132	.0373	.0747
22	.0187	.0373	.0566	.0373	.1109	.0373	.0549
23	.0187	.0373	.0377	.0373	.0905	.056	.0532
24	.0187	.0187	.0373	.0566	.0373	.0537	.0373
Max	.0187	.1307	.1509	.168	.1698	.0943	.1698
Min	.0187	.0187	.0187	.0187	.0187	.0145	.0187
Avg	.0187	.0545	.0810	.0825	.0832	.0592	.0731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 207 / 11 KV WARANA KATH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6882	.5601			
2	.6802	.5243	.5668			
3	.6882	.5243	.5898			
4	.6882	.5243	.5898			
5	.7209	.5243	.583			
6	.7209	.5243	.5761			
7	.7537	.5735	.6081		.0189	
8	.7125	.5898	.6241			
9	.7202	.6478	.6401			
11				.583		.8322
12				.6081	.6478	.8322
13				.6081	.6316	.8453
14				.6316	.6718	.8453
15				.639	.6554	.8453
16				.6226	.6154	.8551
17				.5304	.6299	.8453
18				.5304	.6554	.7701
24	.6478	.6882	.5735	.3277		
Max	.7537	.6882	.6401	.639	.6718	.8551
Min	.6478	.5243	.5601	.3277	.0189	.7701
Avg	.6980	.5809	.5911	.5645	.5658	.8339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 201 / 11 KV BUDHGAON GAONTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373		.7202	.5801	.6882	.8288
2	.7202		.7455	.5801		.8288
3	.6859		.7362	.4973		.663
4	.703		.7362	.4973		.663
5	.7202		.7202	.4973	.6554	.663
6	.703		.7202	.4973		.5801
7	.6859			.4973	.6882	.5801
8	.5487	.6882	.7888		.7045	
11		.7282				
12					.547	
13					.547	
14					.547	
15					.547	
16			.4144		.4973	
17					.5801	
18					.5801	
19					.663	
20			.5801		.7459	
21		.964			.8288	
23			.663			
24	.7545	.6226	.7888	.5801	.6718	.8288
Max	.7545	.964	.7888	.5801	.8288	.8288
Min	.5487	.6226	.4144	.4973	.4973	.5801
Avg	.6954	.7508	.6921	.5284	.6328	.7045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 202 / 11 KV KALERAN (KAVALPUR) SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104		.1387			.2984
2	.104		.12			.4144
3	.104		.12			.4144
4	.104		.1214			.663
5	.104					.663
6	.104		.1715			.8288
7	.104					.8288
8	.0867	.0819		.0497		
11		1.1431				
13					.0663	
16			1.0774			
18			1.0774			
21		.1267			.0663	
23			.0663			
24	.104	.0655	.12			.0663
Max	.104	1.1431	1.0774	.0497	.0663	.8288
Min	.0867	.0655	.0663	.0497	.0663	.0663
Avg	.1021	.3543	.3347	.0497	.0663	.5221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 203 / 11 KV BISUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.208		.2601	.2427	.2241
2	.208		.2572		.2241
3	.208		.2774		.2241
4	.2254		.2804		.2241
5	.208		.2743	.2427	.2241
6	.208		.2804		.1989
7	.1907			.2241	.2241
8	.1734	.1886		.1867	
11		.1848			
12				.1494	
16			.1494		
20			.1867		
21		.2915		.2241	
23			.1867		
24	.2254	.1494	.2804	.2241	.2172
Max	.2254	.2915	.2804	.2427	.2241
Min	.1734	.1494	.1494	.1494	.1989
Avg	.2061	.2036	.2433	.2134	.2201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 204 / 11 KV BUDHGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3121		.2743		.0497	
2	.2947		.3086			
3	.2947		.3048			
4	.3121		.3395			
5	.3121				.0497	
6	.5201		.3772			
7	.5201				.0497	.0663
8	.583	.4915		.1326	.0497	
11		.052				
12					.3315	
13					.3315	
14					.3315	
16			.0663		.3315	
18					.3315	
21					.0663	
24	.3121	.1638	.2439		.0497	.0663
Max	.583	.4915	.3772	.1326	.3315	.0663
Min	.2947	.052	.0663	.1326	.0497	.0663
Avg	.3846	.2358	.2735	.1326	.1793	.0663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 205 / 11 KV EXPRESS COLLEGE

NON SHEDDABLE WATER SUPPLY AND

FEEDER Feeder KV- 11 /

UTILITY

OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.0686	.132	.1307
2	.12		.0693		.1307
3	.1029				.1307
4	.1029				.1494
5	.0514			.0566	.1494
6	.1372		.0514		.1326
7	.1372			.1509	.1494
8	.1372	.1307		.1509	
11		.208			
12				.112	
16			.1307		
20			.112		
21		.1715		.112	
23			.0934		
24	.1372	.1509	.0686	.1509	.1086
Max	.1372	.208	.1307	.1509	.1494
Min	.0514	.1307	.0514	.0566	.1086
Avg	.1181	.1653	.0849	.1236	.1352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 207 / 11 KV JYPTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0747
2				.112
3				.1494
4				.1494
5		.1029		.1326
6		.1029		.1494
7				.1494
8	.1509			
11	.0686			
16	.0343	.1326	.0362	
Max	.1509	.1326	.0362	.1494
Min	.0343	.1029	.0362	.0747
Avg	.0846	.1128	.0362	.1310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 208 / 11 KV BISUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0463			.0446	.1867
2	.0463				.3315
3	.0463		.0686		.3315
4	.0463		.0693		.4973
5	.0463		.0686	.0594	.4973
6	.0617		.0686		.4973
7	.0772			.0743	.4973
8	.0617	.0743		.0594	
13				.0747	
16			.9116		
18			.9116		
21		.0514		.0747	
24	.0463	.0587	.0514	.0446	.0663
Max	.0772	.0743	.9116	.0747	.4973
Min	.0463	.0514	.0514	.0446	.0663
Avg	.0532	.0615	.3071	.0617	.3632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081] BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 401 / 33 KV SHERINALA

Feeder KV- 33 / OUTGOING

DATE	10-MAY-18
HR	Load (MW)
21	.028
Max	.028
Min	.028
Avg	.028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 201 / 11 KV DUDHGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3921	.4108	.3734	.4066	.3921	.4108
2	.3734		.4108	.3734	.4108	.3921	.4108
3	.3734	.3734	.3921	.3734	.3734	.3921	.3921
4	.3921	.3734	.4066	.3734	.3734	.3921	.3734
5	.3921	.3734	.4251	.3921	.4481	.4108	.4108
6	.3921	.3921	.4435	.4294	.4805	.4481	.4481
7	.3734	.3361	.4251	.3547	.4251	.4108	.4668
8	.3547	.3921	.4251	.3174	.3361	.4108	.4668
9	.3361	.3921	.4108	.2987	.3921	.4294	.4481
10	.3547	.3921	.4108	.4294	.3921	.4668	.3921
11	.1509	.4108	.4108	.3174	.4108	.4481	.4481
12		.4108	.4294	.3734	.4108	.4294	.4854
13	.1509	.4108	.4108	.4481	.4481	.4854	.4854
14	.1509	.4108	.4294	.4481	.5041	.5041	.4668
15	.4668	.4294	.4481	.4481	.5041	.5228	.4854
16	.4294	.4108	.4481	.4854	.5041	.5228	.4854
17	.4294	.4108	.4294		.4854	.5041	.4668
18	.4108	.4481		.4805	.4481	.5041	.4481
19	.6348	.5304		.5175	.5228	.4854	.5041
20	.5975	.6036	.3734	.6036	.5041	.6348	.5975
21	.5788	.6036	.5601	.567	.5041	.6161	.5788
22	.5041	.5175	.547	.5175	.4854	.5228	.5601
23	.4668	.4805	.5041	.4805	.4668	.4668	.4668
24	.4294	.4108	.4481	.4108	.4251	.4108	.4108
Max	.6348	.6036	.5601	.6036	.5228	.6348	.5975
Min	.1509	.3361	.3734	.2987	.3361	.3921	.3734
Avg	.3980	.4307	.4363	.4267	.4443	.4668	.4629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 202 / 11 KV SAWALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.8421	.6009	.759
2	.0191	.0191	.0191	.0191	.8421	.6009	.7432
3	.0191	.0191	.0191	.0191	.8745	.6009	.7432
4	.0191	.0191	.0191	.0191	.8745	.6009	.7748
5	.0191	.0191	.0191	.0191	.9069	.6009	.8855
6	.0191	.0191	.0381	.0381	.9231	.68	.9488
7	.1905	.0191	.0381	.0381	.8583	.7274	.9646
8	.0381	.0191	.0381	.0191	.8421	.7748	1.0437
9	.0381	.0191	.0381	.0191	.8259	.8223	1.1227
10	.0381	.0191	.0381	.0381	.0191	.0191	.0381
11		1.4575	1.4413	.0381	.0191	.0191	1.186
12		1.4737	1.4899	.0191	.0191		1.2176
13		1.4737	1.4899	.0191	.0191	.0191	1.186
14		1.4737	1.4899	.0191	.0191	.0191	1.1702
15		1.4251	1.4737	.0191	.0191	.0191	1.1544
16		1.4737	1.4575	.0191	.0191	.0191	1.1069
17		1.4575	1.4251		.0191	.0191	1.0753
18	1.0669	1.3927		.0191	.0191	.0191	1.0753
19	.0191	.0191	.0381	.0191	.0191	.0191	.0381
20	.0191	.0191		.0381	.0191	.0191	.0381
21	.0191	.0381	.0381	.0191	.0191	.0191	.0381
22	.0191	.0191	.0191	.0191	.0191	.0191	.0381
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.8162	.5693	.759
Max	1.0669	1.4737	1.4899	.0381	.9231	.8223	1.2176
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0942	.4980	.4858	.0232	.3697	.2968	.7552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 203 / 11 KV DHARAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0898	1.1065	1.1012	1.0277		
2	1.0898	1.1065	1.1012	1.0277		
3	1.073	1.073	1.1012	1.0277		
4	1.073	1.073	1.1336	1.0277		
5	1.1401	1.2071	1.1336	1.0442		
6	1.2071	1.2574	1.1633	1.1603		
7	1.2742	1.3077	1.2289	1.1934		
8	1.2407	1.291	1.2289	1.326		
9	1.2071	1.3245	1.2125	1.3592		
11				1.3279	1.3441	1.3923
12				1.3763	1.3279	1.4089
13				1.3603	1.3603	1.3923
14				1.3117	1.3441	1.4752
15				1.3279	1.2955	1.4255
16				1.2955	1.2631	1.442
17					1.3117	1.4586
18				1.2308	1.2631	1.3094
24	1.0898	1.1065	1.0526	1.0774		
Max	1.2742	1.3245	1.2289	1.3763	1.3603	1.4752
Min	1.073	1.073	1.0526	1.0277	1.2631	1.3094
Avg	1.1485	1.1853	1.1457	1.2060	1.3137	1.4130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 204 / 11 KV BAGANI ROAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.6154	.664	.6478
2	.0381	.0381	.0381	.0381	.6154	.664	.6478
3	.0381	.0381	.0381	.0381	.6478	.664	.664
4	.0381	.0381	.0381	.0381	.6802	.664	.664
5	.0381	.0381	.0381	.0381	.6802	.664	.6964
6	.0762	.0381	.0572	.0572	.7287	.7125	.7125
7	.0762	.0381	.0572	.0572	.7611	.7935	.7449
8	.0762	.0381	.0381	.0381	.7611	.8259	.8259
9	.0762	.0381	.0381	.0381	.7773	.8097	.7935
10	.0572	.0381	.0381	.0381	.0381	.0191	.0191
11		.9555	.9231	.0381	.0381	.0191	.8421
12		.9555	.8907	.0381	.0381	.0381	.8583
13		.8642	.8421	.0381	.0381	.0381	.7773
14		.8907	.8421	.0381	.0381	.0381	.7773
15		.8907	.8097	.0381	.0381	.0381	.7611
16		.8907	.8259	.0381	.0381	.0381	.7611
17		.8421	.7611		.0381	.0381	.7935
18	.7682	.8097		.0381	.0381	.0381	.7611
19	.0572	.0572	.0381	.0381	.0381	.0381	.0381
20	.0572	.0572	.0381	.0572	.0572	.0572	.0572
21	.0572	.0572	.0572	.0572	.0572	.0572	.0572
22	.0572	.0572	.0572	.0572	.0572	.0572	.0572
23	.0572	.0572	.0572	.0381	.0572	.0572	.0381
24	.0381	.0381	.0381	.0381	.5992	.6154	.6401
Max	.7682	.9555	.9231	.0572	.7773	.8259	.8583
Min	.0381	.0381	.0381	.0381	.0381	.0191	.0191
Avg	.0968	.3252	.2869	.0423	.3115	.3187	.5682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 205 / 11 KV A1 PPS EXPRESS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.7167	.8775	.6979	.7655	.5975
2	.6348	.7167	.8775	.6979	.7655	.5975
3	.6348	.7167	.8775	.6979	.7655	.6348
4	.7095	.7922	.8775	.7167	.7655	.6348
5	.7095	.8299	.8962	.7545	.7655	.7282
6	.7842	.8865	.8962	.7733	.8215	.7282
7	.9335	.8488	.8962	.5093	.8215	.7842
8	.9149	.8488	.9335	.7356	.8402	.7842
9	.9335	.8488	.9335	.7733	.8589	.8029
10	.8865	.8775	.8962	.8775	.8775	.8029
11	.811	.8402	.9149	.8029	.8962	.8029
12	.811	.8029	.9149	.8029	.9149	.7842
13	.7733	.9149	.8402	.8215	.8215	.7842
14	.811	.9149	.8215	.8215	.8402	.7842
15	.9054	.9149	.8029	.8215	.8402	.7842
16	.9431	.9335	.8215		.8402	.8029
Max	.9431	.9335	.9335	.8775	.9149	.8029
Min	.5975	.7167	.8029	.5093	.7655	.5975
Avg	.7996	.8377	.8799	.7536	.8250	.7399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 201 / 11 KV NANDRE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	1.0374	1.0751	.9709	1.0751	.9997	.9808
2	1.0185	1.0185	1.0185	.9335	.9431	.9619	.9619
3	1.0185	1.0185	.9997	.9149	.9242	.9431	.9619
4	.9997	1.0185	1.0562	.9149	.9242	.9431	.9619
5	1.1883	1.1016	1.1317	.9795	.9511	1.0562	.9808
6	1.1016	1.1643	1.1949	1.0349	1.0242	1.1203	1.0829
7	.9242	.9145	.9882	.9511	1.0059	1.0059	1.0534
8	.8215	.8962	.961	.8779	.9593	.9492	.9134
9	.7865	.905	.9328	.8764	.9593	.9036	.9671
10	.7947	.9313	1.0679	.8596	.9134	.8322	.8954
11	.8316	.8682	1.0498	.7442	.8596	.9391	1.9239
12	.7964	.929	1.0791	.8686	.9313	.9134	.9568
13	.8413	.9114	1.0164	.7973	.9214	.9593	.9568
14	.8413	.8764		.7964	.9036	.9511	.6135
15	.8507	.8859	1.0242	.7964	.8939	1.0059	.8589
16	.8316	.8682	.9774	.7087	.8596	.8962	.8682
17	.8316	.8059	.9114		.8596		.8059
18	.7762	.8779			.815	.8859	.7701
19	.9979	1.1088	1.0745		1.086	1.9548	1.0425
20	1.3121	1.3491	1.1523		1.2936	1.2936	1.3676
21	1.2696	1.2986	1.1273		1.307	1.2936	1.3491
22	1.2696	1.2752	1.2197		1.2826	1.2323	1.307
23	1.2071	1.2071	1.1576	1.3256	1.1506	1.0829	1.1694
24	1.0642	1.0562	1.1317	1.0642	1.1883	1.0374	1.0082
Max	1.3121	1.3491	1.2197	1.3256	1.307	1.9548	1.9239
Min	.7762	.8059	.9114	.7087	.815	.8322	.6135
Avg	.9755	1.0135	1.0612	.9119	1.0013	1.0505	1.0316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0532	.0543	.0343	.3462	.4214	.3567
2		.0526	.0537	.0351	.3418	.4115	.3567
3		.0526	.0549	.0358	.3418	.3913	.3521
4	.0532	.0537	.0554	.0366	.3462	.3913	.3521
5	.0537	.0532	.0543	.0549	.3864	.3913	.3567
6	.0514	.0526	.0701	.0739	.431	.4115	.3864
7	.0693	.0526	.0686	.0924	.4458	.4607	.442
8	.0678	.0526	.052	.1097	.4515	.5053	.5182
9	.0701	.0886	.0709	.0895	.4365	.4967	.578
10	.0514	.0886	.0497	.0905	.0509	.0492	.0549
11	.6097	.286	.7468	.0876	.0343	.0543	.587
12	.587	.6241	.787	.0671	.0347	.0549	.602
13	.6097	.6093	.743	.0724	.0347	.0724	.5796
14	.5944	.0301	.7282	.0724	.0351	.0497	.5796
15	.5639	.032	.7074	.0732	.0351	.0514	.5721
16	.5792	.032	.6984	.0709	.0351	.052	.5721
17	.5944	.6401	.6773		.0351	.0351	.5428
18	.5639	.6249			.0532	.048	.5201
19	.0701	.061	.0514		.0347	.052	.048
20	.0701	.0732	.0549		.0709	.0537	.0514
21	.0709	.0497	.0739		.0549	.0732	.0526
22	.0716	.0716	.0358		.0549	.0549	.0532
23	.0537	.0716	.0358	.0351	.0549	.0549	.0532
24	.0549	.0537	.0549	.0362	.3612	.381	.3612
Max	.6097	.6401	.787	.1097	.4515	.5053	.602
Min	.0514	.0301	.0358	.0343	.0343	.0351	.048
Avg	.2624	.1608	.2599	.0649	.1878	.2091	.3720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 203 / 11 KV MALBHAG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3201		.1957	.0754	.0943	.0924
2	.3549	.3201	.2824		.0754	.0754	.1109
3	.3418	.3201	.2709	.1981	.0754	.0747	.1109
4	.3311	.3241	.2824	.1981	.0943	.0924	.1109
5	.3506	.3241	.3201	.2134	.0943	.0924	.1109
6	.3418	.3241	.3395	.2378	.0914	.1086	.1109
7	.4064	.3353	.3963	.2972	.0914	.0924	.1097
8	.4064	.3658	.3462	.3612	.0924	.0914	.0914
9	.3906	.3506	.3121	.3963	.1294	.1109	.0905
10	.0724	.0914	.1663	.0452	.1663	.0914	.128
11	.1086	.128	.1829	.4012	.4268	.5218	.128
12	.0732	.1097	.1463	.4268	.4321	.5093	.1478
13	.0739	.1097	.128	.823	.4374	.4877	.1663
14	.0732	.0914	.1433	.8024		.4515	.1478
15	.0905	.0914	.1448	.3858	.3704	.4572	.1478
16	.0914	.0914	.0185	.3612	.3704	.4115	.1478
17	.128	.1097	.1448		.3506	.4115	.1478
18	.1109	.1448	.0549		.3395	.3668	.1463
19	.1294		.0732		.128	.1254	.1463
20	.1294	.0914	.0549		.112	.1254	.1478
21	.112	.1075	.0549		.112	.128	.1294
22	.0934	.0895	.0554	.0914	.0934	.1097	.1307
23	.0934	.0905	.0554	.0914	.1097	.1097	.1307
24	.3281	.3241	.3321	.216	.0754	.0924	.0914
Max	.4064	.3658	.3963	.823	.4374	.5218	.1663
Min	.0724	.0895	.0185	.0452	.0754	.0747	.0905
Avg	.2082	.2024	.1872	.3190	.1888	.2180	.1259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 201 / 11 KV KAVALAPUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5228	.4805	.4527	.4904	.5041	.4904
2	.4904	.5228	.4805	.4527	.4715	.5041	.4715
3	.4715	.5041	.462	.4527	.4527	.4854	.4527
4	.4338	.5041	.462	.4294	.4527	.4854	.4715
5	.4294	.5228	.5228	.4668	.5093	.5041	.5093
6	.4668	.5788	.5601	.5788	.6036	.5041	.5847
7	.5175	.4668	.5304	.499	.499	.5175	.499
8	.4572	.4706	.4298	.462	.4938	.4572	.4572
9	.4344	.4252	.4557	.4572	.4477	.4298	.4344
10	.3681	.4784	.443	.3856	.362		.3814
11	.3506	.5194	.4656		.4031		.7888
12	.3761	.4908	.5014	.5194	.3898	.5731	.4557
13	.3582	.4557	.4887	.4298	.4252	.4887	
14	.4066	.4508	.5014	.4755	.4344	.5014	
15	.4251	.4298	.4887	.4755	.4207	.4887	.5373
16	.4572	.5068	.4835	.4525	.4477	.4887	.4908
17	.3982	.5304	.5792			.4887	.4854
18	.3898	.5359		.5083		.5068	.463
19	.4887	.6089	.695	.6626	.7619	.6154	.4508
20	.6283	.7011	.6036	.695	.7783	.7023	.7164
21	.6468	.6722		.6653	.7023	.6722	.6661
22	.6722	.6653	.6099	.6535	.6161	.6161	.6241
23	.5975	.6283	.5228	.5788	.5601	.547	.6283
24	.5658	.5729	.5601	.4854	.5281	.5228	.5093
Max	.6722	.7011	.695	.695	.7783	.7023	.7888
Min	.3506	.4252	.4298	.3856	.362	.4298	.3814
Avg	.4725	.5319	.5149	.5108	.5114	.5274	.5258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 202 / 11 KV TUKAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1086	.0914		.2372	.6562	.506
2	.0934	.0914	.0914		.2372	.6562	.4961
3	.0934	.0914	.0914		.2241	.6173	.4801
4	.0943	.0924	.0924		.2214	.6636	.4586
5	.0943	.1109	.1109		.2343	.7186	.4687
6	.1132	.1478	.1097		.2778	.8905	.4938
7	.1307	.1109	.1294		.3086	1.0494	.535
8	.1307	.0905	.0895		.3311	1.0957	.6093
9	.1097	.0876	.0848		.3001	1.2266	.6923
10	.1052	.0876	.1254	.1174	.0693		.1017
11	1.0212	1.0517	1.2037	.0995	.0655		.1017
12	1.1574	1.0669	1.0669	.128	.0693	.156	.7712
13	.9783	1.0031	1.0494	.1075	.0867	.1417	.703
14	.8688	.8796	.9783	.0895	.0886	.1402	.7011
15	.8535	.9259	1.0059		.0886	.1254	
16	1.0031	1.0227	1.0212		.0693	.1433	.7316
17	.9259	.945	.9414			.1417	.7716
18	.7095	.9877		.1086		.1075	.7468
19	.1086	.1294		.1086	.1254	.0934	.1227
20	.1494	.1265	.1075	.128	.1294	.1294	.124
21	.1294			.1294	.1294	.112	.1052
22	.1307	.1107		.1109	.1463	.112	
23	.1097	.1017		.128	.1463	.1109	.1372
24	.112	.1086	.1109		.2056	.6874	.427
Max	1.1574	1.0669	1.2037	.1294	.3311	1.2266	.7716
Min	.0934	.0876	.0848	.0895	.0655	.0934	.1017
Avg	.3889	.4121	.4474	.1141	.1723	.4443	.4675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 203 / 11 KV KONDAKA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6401	.6097	.1543	.1886	.1867	.1886
2	.6173	.5864	.6859	.1134	.1698	.1867	.1886
3	.6173	.5792	.6859	.1134	.1509	.168	.1698
4	.6093	.5639	.7716	.112	.1509	.1867	.1698
5	.6481	.587	.9145	.1296	.1698	.1867	.1886
6	.7621	.7074	1.0059	.192		.2054	.2263
7	1.0686	1.0957	1.0364	.253		.2218	.2614
8	1.0974	1.0669	.7407	.2591		.2587	.2614
9	.9808	.9829	.945	.2294		.2054	.2427
10	.128	.1417	.1214	.0886			.2218
11	.128	.1612	.1928	.6093	.1107		.2012
12	.1463	.1791	.2149	.6249	.587	.8688	.2033
13	.1463	.1753	.2353	.6093	.6308	.8951	.1829
14	.2054	.1772	.2328	.5796	.639	.8796	.2033
15	.2075	.1612	.2481	.5944	.6308	.8436	.1848
16	.2054	.1753	.2507	.571	.4458	.8796	.1848
17	.2033	.1753	.2481			.7773	.1829
18	.2218	.1734		.0732		.7562	.2402
19	.2218	.2629		.1663	.1848	.2427	.2561
20	.2715	.2454	.1086	.1886	.2241	.2427	.2587
21	.2427	.2772		.1886	.2054	.2241	.2614
22	.2614	.2587	.128	.2075	.2054	.2075	.2402
23	.2427	.2218	.128	.2075	.1867	.2263	.2378
24	.6562	.6173	.5407	.1543	.1886	.1867	.2075
Max	1.0974	1.0957	1.0364	.6249	.639	.8951	.2614
Min	.128	.1417	.1086	.0732	.1107	.168	.1698
Avg	.4387	.4255	.4783	.2791	.2982	.4107	.2152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 201 / 11KV GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.8145	.9145	.823	.788	.7602	.7602
2	.7682	.8048	.8688	.7682	.724	.724	.7316
3	.7316	.7602	.8326	.724	.6878	.6878	.695
4	.6516	.724	.8326	.6878	.6584	.6516	.695
5	.6154	.6878	.8048	.6516	.6219	.6516	.6653
6	.6219	.6516	.8048	.6516	.6516	.6335	.6653
7	.6584	.6697	.7316	.6878	.6516	.6335	.6653
8	.724	.7059	.7522	.6626	.6516	.6516	.6584
9	.724	.7164	.7087	.724	.6516	.6335	.7164
10	.815	.8505	.9114	.8688	.7164	.7087	.8688
11	.9412	1.0242	1.0974	.9412	.7602	.8413	.9412
12		.8505	1.1157	1.0498	.8779	.8413	.9877
13		.9877	1.1222	.9412	.8688	.7865	.9877
14		1.0242	1.0242	.8779	.8779	.823	.9412
15	1.182	1.0242	1.0608	1.0242	.8779	.8413	.9511
16	1.0745	1.0608	.9774	.9955	.8779	.823	.9511
17	1.0136	1.0136	1.0745	.9774	.8688	.8131	.905
18	1.0136	1.086		.9412	.8688	.7796	.9955
19	1.2127	1.182	1.3289	1.0517	1.0317	1.0029	1.2048
20	1.3213	1.2536	1.1641	1.1218	1.1403	1.1104	1.2536
21	1.1946	1.1694	1.0387	1.0631	1.0679	1.0745	1.1584
22	1.0498	1.0745	.9671	.9671	.9412	.9671	.9955
23	1.0136	1.0136	.9145	.9313	.8869	.8688	.905
24	.8688	.8507	.9145	.8779	.8954	.7964	.7964
Max	1.3213	1.2536	1.3289	1.1218	1.1403	1.1104	1.2536
Min	.6154	.6516	.7087	.6516	.6219	.6335	.6584
Avg	.9048	.9167	.9549	.8754	.8185	.7961	.8790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 202 / 11KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.724	.9774	.7023	.695	.8326	.7602
2	.7682	.7059	.9877	.6401	.6653	.8145	.7682
3	.724	.6878	.9511	.5853	.6283	.7964	.7682
4	.6516	.6697	.961	.5487	.5487	.7783	.7762
5	.6516	.6516	.9145	.543	.5487	.7602	.7468
6	.6584	.6335	.9145	.543	.5487	.7602	.7468
7	.6516	.5611	.8779	.5792	.5914	.6697	.7095
8	.7164	.5973	.815	.5731	.5853	.6878	.7023
9	.6805	.6447	.823	.7421	.5853	.7522	.7964
10	.6089	.9709	1.1584	.8507	.6447	.7888	.9214
11	.8326	1.1104	1.1584		.8326	.7602	1.1203
12			1.2178	1.2308	1.0136	.9955	1.1576
13			1.2757	.9955	.9774	.905	1.1576
14		1.2048	1.2894	1.086	.9412	.905	1.0745
15	.8688	1.2048	1.3032	1.1222	1.0136	.8688	1.086
16	.9774	1.267	1.2536	1.0498	1.0498	.7964	1.086
17	.905	1.267	1.1104	.9774	.8145	.8413	.905
18	1.0498	1.0745		.7164	.905	.815	.8145
19	1.0317	1.2403		.9114	1.0317	.8954	1.0099
20	1.0679	1.2894		.9214	1.086	1.0498	1.0498
21	.9412	1.1462	.8145	.8596	.7964	.9774	.905
22	.8869	1.1222	.7602	.8326	.9511	.9145	.8507
23	.8326	1.0498	.7392	.8145	.905	.8779	.823
24	.9145	.7602	.9877	.7392	.7316	.8507	.8048
Max	1.0679	1.2894	1.3032	1.2308	1.086	1.0498	1.1576
Min	.6089	.5611	.7392	.543	.5487	.6697	.7023
Avg	.8219	.9356	1.0138	.8071	.7955	.8372	.8975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 203 / 11KV VAKHARBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.7602	.7545	.7392	.7842	.6516	.7095
2	.6413	.724	.7545	.6535	.7468	.6335	.679
3	.6413	.6878	.7095	.6535	.7167	.6335	.6413
4	.6036	.6697	.6722	.5914	.6413	.5973	.6348
5	.5975	.6516	.6413	.5544	.6413	.5792	.6413
6	.6348	.6335	.6478	.5544	.679	.543	.6036
7	.679	.6154	.6097	.6036	.6036	.5611	.5716
8	.679	.6335	.6413	.6468	.5975	.5792	.6097
9	.724	.679	.7468	.6516	.6097	.6602	.6859
10	.7842	.7468	.8215	.724	.7095	.6348	.7545
11	1.0562	1.1694	1.2449	1.1041	.8962	1.0374	1.1317
12		1.2323	1.226	1.1403	1.0562	1.0829	1.2071
13		1.2449	1.2071	1.1222	1.0185	.9709	1.2071
14		1.1694	1.1317	1.1827	1.0456	1.0269	1.1949
15	1.2696	1.1694	1.1694	1.1203	1.0829	1.0082	1.2071
16	1.2449	1.1694	1.094	1.1765	1.094	1.0269	1.1694
17	1.2308	1.2696	1.2936	1.1222	1.1506	1.094	1.1203
18	1.1946	1.307		1.1088	1.086	1.0185	1.226
19	1.3032	1.3443	1.2136	1.1706	1.1946	1.1949	1.2696
20	1.3394	1.3443	1.0456	1.267	1.2803	1.2696	1.307
21	1.1765	1.3306	1.1203	1.182	1.1584	1.1949	1.2696
22	.9412	1.0456	.8215	1.086	.8688	1.0719	1.0269
23	.8688	.9431	.8299	.9877	.8326	.8299	.9431
24	.7545	.7964	.8299	.7842	.8048	.6878	.7468
Max	1.3394	1.3443	1.2936	1.267	1.2803	1.2696	1.307
Min	.5975	.6154	.6097	.5544	.5975	.543	.5716
Avg	.9068	.9724	.9229	.9136	.8875	.8578	.9399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 201 / 11 KV Balaji Mill Road
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.7316	.8589	.6516	.724	.6733	.7602
2	.7682	.724	.8316	.6516	.724	.6556	.7421
3	.7316	.6878	.8316	.6201	.6733	.6344	.724
4	.6516	.6379	.8215	.6201	.6733	.6344	.7087
5	.6516	.6379	.7842	.5847	.6135	.5868	.7087
6	.5847	.5316	.7282	.5731	.5548	.547	.7316
7	.5014	.5144	.6697	.5973	.5609	.4641	.6697
8	.4887	.4801	.5731	.5014	.567	.4696	.5487
9	.4887	.6697	.7468	.5249	.5256	.4973	.6219
10	.6401	.724	.8775	.6697	.5658	.7468	.7655
11		.8215	.9431	.7468	.6626	.6697	.8299
12		.811	.9431	.811	.7421	.6878	.7095
13		.8402	.8131	.6878	.6335	.7059	.6335
14		.9149	.9054	.8215		.7316	.6767
15	.8299	.9335	.9431	.9431	.8048	.7682	.8299
16	.7842	.9522	.9808	.8865	.7964	.724	.9431
17	.7282	.8589	.9242		.7682	.7682	.8029
18	.7023	.7947		.7922	.5792	.6516	.7468
19	.6838	.8029		.6838	.5853	.6335	.7842
20	.7316	.8676	.5083		.6201	.6584	.7207
21	.7468	.8865	.6516	.7577	.6878	.7059	.7865
22	.8402	.9431	.463	.7762	.7499	.8413	.8686
23	.8962	.9808	.724	.7947	.8048	.8326	.8413
24	.8402	.7865	.9054	.6697	.7947	.7164	.7602
Max	.8962	.9808	.9808	.9431	.8048	.8413	.9431
Min	.4887	.4801	.463	.5014	.5256	.4641	.5487
Avg	.7038	.7722	.7922	.6984	.6701	.6669	.7465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 203 / 11 KV Timber Area

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4715	.415	.4715
2		.4527	.3961	.4338
3		.4527	.3961	.415
4		.4527	.3961	.415
5		.415	.3772	.3772
6		.3584	.3584	.3547
7		.3326	.3326	.3361
8		.3174	.2926	.3206
9		.3961	.3961	.3584
10		.4344	.3961	.3961
11		.462	.4715	.499
12		.4668	.4338	.5658
13		.3584	.3395	.415
14		.3772	.3961	.3696
15		.4338	.4338	.4904
16		.4715	.4338	.5658
17		.4527	.3961	.5093
18		.4527	.415	.4338
19		.5281	.4904	.5788
20	.6335	.5359	.5281	.5544
21	.5228	.4854	.4904	.5041
22	.5415	.5093	.4904	.547
23	.547	.4527	.5281	.547
24		.5093	.4527	.4904
Max	.6335	.5359	.5281	.5788
Min	.5228	.3174	.2926	.3206
Avg	.5612	.4408	.419	.4562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 201 / 11 KV MADHAVNAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.6413	.7922	.7167	.7316		
2	.7545	.6224	.7733	.6979	.695		
3	.7545	.6036	.7545	.6979	.6767		
4	.7356	.5847	.7545	.679	.6401		
5	.7356	.5658	.7167	.679	.6401		
6	.6413	.5658	.7167	.6224	.6219		
7	.5847	.5658	.6602	.6413	.5853		
8	.4904	.547	.6224	.5658	.5487		
9	.5281	.5658	.7356	.7545	.5853	.7356	.5658
10	.547	.6413	.8488	.8488	.6219	.8865	.7545
11	.679	.6413	.8488	.905	.695	.811	.8488
12	.6036	.7545	.8676	.8507	.7023	.7922	.8488
13	.5658	.8299	.9431	.7865	.7207	.8676	
14	.6413	.8488	.9997	.8596	.8029	.9242	.8488
15	.7356	.9242	1.0562	1.0242	.9149	.9242	.9242
16	.7167	.9242	1.0374		.8775	.9431	.9431
17	.6979	.9431	.9997		.8402		.9054
18	.7356	1.0185			.8962		.8676
19	.811	.9808		1.0974	.9511		.9795
20	.8299	.9619	.8676	1.0059	.9328		.9055
21	.7922	.9242	.8299	.9145	.9055		.8676
22	.7545	.9242	.811	.823	.8686		.8676
23	.7733	.9242	.8299	.823	.8316		.8865
24	.8299	.679	.8676	.7733	.7499		
Max	.8299	1.0185	1.0562	1.0974	.9511	.9431	.9795
Min	.4904	.547	.6224	.5658	.5487	.7356	.5658
Avg	.6963	.7576	.8333	.7984	.7515	.8606	.8581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 203 / 11 KV INDOTEX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.2071	1.1317	1.226	1.134		
2	1.1888	1.2449	1.1317	1.226	1.134		
3	1.1888	1.226	1.1694	1.226	1.134		
4	1.1888	1.226	1.1694	1.226	1.134		
5		1.2449	1.2071	1.226	1.134		
6	1.1888	1.2449	1.2449	1.1883	1.1523		
7	1.1888	1.226	1.226	1.1883	1.1706		
8	.823	1.2449	1.226	1.2071	1.1706		
9	.8299	1.2826	1.2449	1.1883	1.0974	1.2071	
10	.8676	1.3203	1.2826	1.1506	1.0974	1.226	
11	.8488	1.3203	1.2826	1.3014	1.0974	1.2449	
12	.8488	1.1317	1.3014	1.2637	1.134	1.2637	
13	.811	1.1506	1.3014	1.2449	1.1088	1.226	
14	.7922	1.226	1.2826	1.2449	1.2323	1.1883	
15	.811	1.2826	1.2826	1.2637	1.307	1.2071	
16	.811	1.3014	1.2449		1.2696	1.2449	
17	.7922	1.2449	1.2449		1.1949		1.2449
18	.8488	1.226			1.226		1.226
19	1.0562	1.1694	1.1888		1.2071		1.2254
20	1.1506	1.1694	1.226		1.226		1.1883
21	1.2071	1.1317	1.2071		1.1694		1.1506
22	1.2637	1.1694	1.1883		1.1883		1.1694
23	1.1506	1.226	1.1694		1.226		1.1506
24	1.1888	1.226	1.1317	1.2449	1.134		
Max	1.2637	1.3203	1.3014	1.3014	1.307	1.2637	1.2449
Min	.7922	1.1317	1.1317	1.1506	1.0974	1.1883	1.1506
Avg	1.0102	1.2268	1.2211	1.2260	1.1700	1.226	1.1936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 205 / 11 KV COTTON MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.547	.6224	.6224	.6413	.6413	
2	.6036	.5658	.6413	.6224	.6224	.6224	
3	.6036	.5658	.6036	.6224	.6224	.6224	
4	.6036	.5847	.5847	.6224	.6224	.6036	
5	.6036	.5847	.5847	.6224	.6224	.6036	
6	.6036	.5658	.5847	.6413	.6224	.5847	
7	.5658	.547	.6036	.6413	.6602	.5847	
8	.6224	.9431	.6036	.6224	.679		
9	.5658	.9431	.7545	.9242	.7167	.6979	.9054
10	.547	.9054	.9054	1.0185	.7167	.8299	1.094
11	.547	.8676	.9808	1.1694	.7167	.7922	1.1694
12	.5093	.8488	1.0751	1.0562	.7167	.7733	1.1317
13	.4527	.7733	1.0751	.9619	.7167	.811	1.0562
14	.3772	.9431	1.094	.9242	.8299	.8299	1.1317
15	.3772	1.1317	1.0751	1.1506	.9054	.811	1.1506
16	.3584	1.0374	.9242		.8676	.7922	.8865
17	.3584	1.0374	.8676		.8676		.9997
18	.3584	1.0185			.811		1.1128
19	.3772	.8488	.6224		.7545		.9997
20	.547	.6036	.6036		.679		.8299
21	.5658	.6224	.6224		.6413		.679
22	.5847	.6224	.6036		.6602		.6602
23	.6036	.6036	.6224		.679		.679
24	.547	.5093	.6224	.6036	.6413	.6413	
Max	.6224	1.1317	1.094	1.1694	.9054	.8299	1.1694
Min	.3584	.5093	.5847	.6036	.6224	.5847	.6602
Avg	.5195	.7592	.7512	.8016	.7089	.7026	.9657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 207 / 11KV SPARE 1 FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.132	.132	.0943		
2	.132	.132	.132	.132	.0943		
3	.132	.132	.132	.132	.0943		
4	.132	.132	.132	.132	.0943		
5	.132	.1509	.1509	.132	.0943		
6	.132	.1509	.1509	.132	.0943		
7	.132	.1509	.1509	.132	.1132		
8	.132	.2075	.1132	.132	.132		
9	.132	.2263	.1698	.2075	.132	.2075	
10	.132	.2075	.2075	.2452	.132	.3206	
11	.132	.2263	.2263	.2452	.132	.3395	
12	.1509	.1886	.2452	.2075	.132	.3206	
13	.132	.1509	.2263	.1509	.132	.2263	
14	.1509	.1886	.1886	.2263	.1132	.0943	
15	.1509	.2263	.1509	.2452	.1132	.0943	
16	.1509	.132	.2452		.2641	.1132	
17	.132	.1698	.1886		.3018		.1698
18	.132	.2263			.3018		.132
19	.132	.1886	.1698		.1509		.3584
20	.132	.1698	.1509		.1509		.2263
21	.132	.132	.132		.132		.132
22	.1509	.1509	.132		.132		.1132
23	.1509	.1698	.1132		.132		.1132
24	.132	.1509		.1132	.0943		
Max	.1509	.2263	.2452	.2452	.3018	.3395	.3584
Min	.132	.132	.1132	.1132	.0943	.0943	.1132
Avg	.1367	.1705	.1655	.1686	.1399	.2145	.1778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 208 / 11 KV SIE Ag FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.0983		
2	.1509	.1509		.0983		
3	.1509	.1509	.1509	.0983		
4	.1509	.1509	.1509	.1147		
5	.1509	.1698	.1509	.0819		
6	.1509	.1886	.1509	.0819		
7	.1509	.1886	.1509			
8	.6464	.6019	.5898			
9	.6718	.5864	.639		.1132	
10	.7045	.5937	.7045		.132	
11	.4588	.578	.6226		.1509	
12	.463	.5468	.5407		.1698	
13	.463	.4843	.5407		.1509	
14	.4475	.4999	.5243	.1132	.1698	
15	.463	.4999	.5243	.1132	.1698	
16	.1509	.132	.0943	.1509	.1509	
17	.1698	.132	.1132	.1509		.1509
18	.1698	.132		.1509		.132
19	.1698	.1509		.1509		
20	.1698	.1698		.1886		.1509
21	.1698	.1698		.1886		.1886
22	.1886	.1698		.2315		.1698
23	.1698	.1698		.2315		.1698
24	.1509	.1698	.1698	.1017		
Max	.7045	.6019	.7045	.2315	.1698	.1886
Min	.1509	.132	.0943	.0819	.1132	.132
Avg	.2868	.2891	.3511	.1380	.1509	.1603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 201 / 11 KV OM COLD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1694	2.1313	2.2822	
2				1.1317	2.0936	2.2822	
3				1.094	2.1502	2.2822	
4				1.0562	2.1125	2.2822	
5				1.1317	2.1125	2.3011	
6				1.2071	2.1313	2.3577	
7		1.6598		1.1694	2.3765	2.3011	
8		1.8484		1.1883	2.2257	2.2257	
9				1.2826	2.5086	2.6029	2.5274
10		2.8669	2.8104	1.3203	2.8481	2.8292	2.8858
11		3.131	3.0744	2.3577	3.1499		3.1121
12		3.0556	2.9613	2.9613	2.999		3.2065
13		2.9424	2.9047	2.8669	2.8669		3.0744
14		2.6972		2.9047	2.9801		3.0367
15		2.7349	3.1687	2.6595	3.2253		
16			3.1687		3.0178		
17			3.0178				3.1121
18					2.6029		2.6783
19			1.1694	2.2634	2.584		2.7161
20	1.1506		1.0374		2.4143		2.4709
21			1.0562	2.3388	2.2822		
22			1.0751		2.2822		
23			1.094		2.3011		2.584
24	2.3011		2.3011	1.1128	2.1879	2.3011	2.1691
Max	2.3011	3.131	3.1687	2.9613	3.2253	2.8292	3.2065
Min	1.1506	1.6598	1.0374	1.0562	2.0936	2.2257	2.1691
Avg	1.7259	2.6170	2.2184	1.7342	2.5036	2.3680	2.7978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 202 / 11 KV KVC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3957	1.7164	1.358	
2				1.4335	1.6787	1.3392	
3				1.3203	1.6409	1.3392	
4				1.2449	1.6032	1.358	
5				1.2826	1.5655	1.3957	
6				1.358	1.5278	1.4146	
7		1.3203		1.4146	1.5844	1.3957	
8		1.1883		1.226	1.5466	1.4335	
9	.811			1.4901		1.4712	1.9239
10	.8299	2.0559	2.4143	2.037		1.7353	2.037
11	.8299	1.9805	2.1502	2.2257	1.8296		2.1125
12	.7922	2.2634	2.3388	2.32	2.1691		2.2822
13	.7545	2.2257	1.773	2.3388	1.9805		1.8107
14	.6979	2.1502		2.32	1.8484		2.1879
15	.8676	2.3954	2.2977	1.9616	2.037		
16			2.3577		2.1125		
17			2.3765				2.037
18					2.0559		2.2068
19			1.7541	2.0748	1.9427		2.0559
20	1.0562		1.5089		1.5278		1.773
21			1.5844	1.7164	1.4335		
22			1.5278		1.4901		
23			1.4335		1.5844		1.7353
24	.8488		1.6598	1.4146	1.6787	1.3769	1.6032
Max	1.0562	2.3954	2.4143	2.3388	2.1691	1.7353	2.2822
Min	.6979	1.1883	1.4335	1.226	1.4335	1.3392	1.6032
Avg	.832	1.9475	1.9367	1.6986	1.7407	1.4198	1.9805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 203 / 11 KV DIAMOND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.358	1.3769	1.1128	
2				1.3957	1.3957	1.1317	
3				1.3203	1.4146	1.1128	
4				1.226	1.4335	1.1128	
5				1.3014	1.4523	1.094	
6				1.358	1.4523	.8488	
7		1.358		.9054	1.4712	1.4712	
8		.9242		1.2071	1.4901	1.4146	
9	.415			1.3957	1.5089	1.4712	1.4335
10	.3018	1.6032	1.6787	1.6221	1.6409	1.6221	1.6975
11	.3206	1.6409	1.7541	1.8107	1.7541		1.7164
12	.3206	1.6787	1.1128	1.6221	1.1506		1.6787
13	.3018	1.7353	1.4146	1.6032	1.5655		1.4901
14	.2641	1.6598		1.5844	1.5466		1.6975
15	.3018	1.6409	1.1128	1.6409	1.3957		
16	.3206	1.6221	1.5466		1.7164		
17							1.1317
18					1.5844		1.6221
19			1.5655	1.6032	1.5278		1.358
20	.9431		1.2449		1.5089		1.3392
21			1.358	1.4335	1.4523		
22			.9054		1.2071		
23			1.3203		.8865		1.5089
24	1.4146		1.4335	1.226	1.1317	1.094	1.358
Max	1.4146	1.7353	1.7541	1.8107	1.7541	1.6221	1.7164
Min	.2641	.9242	.9054	.9054	.8865	.8488	1.1317
Avg	.4904	1.5403	1.3706	1.4230	1.4376	1.226	1.5026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 204 / 11KV NATRAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0562	.6224	.7922	
2				1.0185	.6224	.7356	
3				.9808	.6036	.7356	
4				.9431	.6036	.7167	
5				.9808	.5847	.7167	
6				1.0185	.5847	.6979	
7		.9808		1.1128	.5658	.7356	
8		1.0185		1.094	.6224	.7733	
9	.7167			1.2637	.9242	1.0185	1.0562
10	.679	1.2449	1.4712	1.4712	1.1506	1.1883	1.4523
11	.7922	1.8107	2.0936	1.8107	1.1694	1.4712	1.4712
12	.7545	1.9239	2.037	1.9239	1.358	1.6598	.811
13	.811	1.7353	1.5089	1.8107	1.0374		1.3203
14	.7545	1.5844		1.5089	1.094		1.1317
15	.7922	1.9805	1.6975	1.1128	1.1317		
16	.7733		1.358		1.2449		
17			1.6975				1.4523
18					1.0185		1.2449
19			.8676	.415	1.094		.8865
20	.7922		.8865		1.1317		.7545
21			.9054	.7922	.7356		
22			.9054		.8299		
23					.9431		.7733
24	1.0185		1.0374	.9431	.7356	.7545	.6602
Max	1.0185	1.9805	2.0936	1.9239	1.358	1.6598	1.4712
Min	.679	.9808	.8676	.415	.5658	.6979	.6602
Avg	.7884	1.5349	1.3722	1.1809	.8873	.9228	1.0845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 205 / 11 KV OMKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.773	1.6787	1.3957	
2				1.7353	1.6975	1.3769	
3				1.6975	1.7164	1.358	
4				1.5844	1.7353	1.358	
5				1.6787	1.7541	1.3957	
6				1.6221	1.7918	1.5089	
7		.811		1.5278	1.358	1.8484	
8		1.4712		1.3014	1.5844	1.8107	
9	.5658			1.3957	1.5466	1.8484	1.7164
10	.4904	1.6032	1.9616	1.9993	1.3392	1.0562	1.9993
11	1.5844	1.8296	2.32	1.7353	1.773	1.773	1.9616
12	1.7541	1.8673	1.8673	1.9805	1.8673		1.9239
13	1.773	1.773	1.8861	2.037	1.8107		2.1125
14	1.8673	1.6975		1.9993	2.037		1.6787
15	1.8484	1.7918	2.1262	2.0748	2.2445		
16	1.8673		1.6787		1.8484		
17			1.4901				1.8107
18					1.5466		1.1694
19			1.6975	1.5655	1.8484		1.8107
20	.4715		1.4523		1.3392		1.358
21			1.6975	1.6032	1.3203		
22			1.6221		1.4712		
23			1.6975		1.5466		1.5655
24	1.5655		1.7918	1.8107	1.5089	1.4335	1.7918
Max	1.8673	1.8673	2.32	2.0748	2.2445	1.8484	2.1125
Min	.4715	.811	1.4523	1.3014	1.3203	1.0562	1.1694
Avg	1.3788	1.6056	1.7914	1.7290	1.6680	1.5136	1.7415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 206 / 11 kv Adimaya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.094	1.2826	1.1694	
2				1.0562	1.226	1.1317	
3				1.0185	1.1883	1.094	
4				1.0185	1.1506	1.0751	
5				1.0562	1.1128	1.0562	
6				1.094	1.0751	1.1317	
7		.9619		1.1128	1.0562	1.2071	
8		.9997		1.2826	1.2826	1.358	
9	.7922			1.4901	1.5089	1.6975	1.6598
10	.8676	1.6598	2.1879	1.7353	1.8107	1.8484	1.8861
11	.8676	1.8296	2.0748	2.0182	1.7353		1.9616
12	.8299	1.8484	1.9805	1.8107	1.4712		2.1125
13	.7922	1.773	1.7918	1.8296	1.4335		1.7918
14	.8488	1.6598		1.8484	1.8673		1.8296
15	.9054	1.6975	2.0182	1.7541	1.9427		
16		1.8484	1.6787		1.6598		
17			1.9239				1.7918
18					1.4901		1.6221
19			1.1883	1.2449	1.358		1.4335
20	.8865		1.1506		1.2637		1.1883
21			1.1694	1.226	1.1694		
22			1.1317				
23			1.1694				1.2449
24	1.1317		1.1128	1.1317	1.2449	1.2449	1.2826
Max	1.1317	1.8484	2.1879	2.0182	1.9427	1.8484	2.1125
Min	.7922	.9619	1.1128	1.0185	1.0562	1.0562	1.1883
Avg	.8802	1.5865	1.5829	1.3790	1.3967	1.274	1.6504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 207 / 11 kv mandhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4335	1.3957	1.2071	
2				1.3957	1.3392	1.1883	
3				1.358	1.2826	1.1694	
4				1.2826	1.2449	1.1694	
5				1.3014	1.2071	1.1506	
6				1.358	1.1694	.9808	
7		.9619		1.3203	1.2637	1.358	
8		1.0751		1.226	1.1128	1.2071	
9	.7545			1.358	1.4712	1.5089	1.7353
10	.7167	1.6975	1.6032	1.6221	1.5655	1.8673	1.9805
11	.679	1.6598	1.7353	1.7541	1.6221		2.1502
12	.679	1.6221	1.8296	1.8107	1.6975		2.1691
13	.679		1.3014		1.226		1.3769
14	.7356	1.4712			1.6598		1.905
15	.7922	1.5278	1.6787	1.5278	1.8107		
16	.7356		1.7164		1.6032		
17			1.7353				1.5089
18					1.6787		1.5278
19			1.4901	1.8296	1.7353		1.6787
20	.811		1.358		1.358		1.5655
21			1.3203	1.6409	1.3392		
22			1.3957		1.3392		
23			1.358		1.3203		1.4901
24	1.4146		1.3957	1.4146	1.3392	1.2071	1.5844
Max	1.4146	1.6975	1.8296	1.8296	1.8107	1.8673	2.1691
Min	.679	.9619	1.3014	1.226	1.1128	.9808	1.3769
Avg	.7997	1.4308	1.5321	1.4771	1.4253	1.274	1.7227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 208 / 11 KV Devika

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1886	.2075	.1698	
2				.1886	.2075	.1698	
3				.1698	.2075	.1698	
4				.1698	.2075	.1886	
5				.1698	.2075	.1886	
6				.1886	.2075	.2075	
7		.2263		.2075	.2075	.1886	
8		.2641		.2263	.2263	.2075	
9	.2263			.2263	.2263	.2075	.2263
10	.2263	.1886	.3018	.2641	.2263	.2075	.2452
11	.2075	.2452	.3018	.2641	.2263		.3018
12	.2263	.2829	.3018	.3018	.2452		.3018
13	.2075	.2452	.2829	.3018	.2452		.2641
14	.2263	.2452		.3018	.2452		.2829
15	.2263	.2641	.2829	.2641	.2452		
16	.2075		.2829		.2452		
17			.2452				.3206
18					.2263		.2641
19			.1886	.2263	.2075		.2263
20	.2263		.1886		.1886		.2075
21			.2263	.2075	.1886		
22			.1886		.1698		
23			.1886		.1698		.1886
24	.1886		.2075	.1886	.2075	.1698	.2075
Max	.2263	.2829	.3018	.3018	.2452	.2075	.3206
Min	.1886	.1886	.1886	.1698	.1698	.1698	.1886
Avg	.2169	.2452	.2452	.2253	.2149	.1886	.2531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 402 / 33 KV Shah Presicast Unit NON SHEDDABLE EXPRESS HV FEEDERS
 III Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1528	.1415	.1132	
2				.1301	.198	.1132	
3				.198	.1641	.1132	
4				.2263	.2433	.1132	
5				.1471	.198	.1132	
6				.1811	.1415	.1245	
7		.2037		.1132	.1132	.1132	
8		.1415		.1698	.1641	.1132	
9	.2263			.1698	.1641	.1301	.1924
10		.1132	.1528	.6224	.1867	.1358	.2094
11		.1698	.1924	1.3014	.2094		.7922
12		.2263	1.3354	1.2562	1.0751	1.2449	1.2279
13		.7243	1.2335	.7922	1.1883		1.2562
14				.7356	1.2562		1.143
15		.7582	1.143		1.1317		
16	.2546	.2263	.1528				
17			.2263		.2263		.1698
18					.1698		.1415
19			.1698	1.2449			.0679
20	.2263		.1132		.1698		.1188
21				.198	.1698		
22			.1132		.1132		
23			.1698		.1132		
24	.2263			.1528	.3508	.1132	.2263
Max	.2546	.7582	1.3354	1.3014	1.2562	1.2449	1.2562
Min	.2263	.1132	.1132	.1132	.1132	.1132	.0679
Avg	.2334	.3204	.4547	.4583	.3586	.2117	.5041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 407 / 33KV SUYESH DUCTILE

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6111		
2					.5036		
3					.4923		
4					.5602		
5					.3112		
6					.6564		
7		.2263			.7016		
8		.3282			.7469		
9					.464	.7695	
10			.5432		.6111	.679	
11			.2263		.3621	.3395	
12			.7243		.6224	.215	
13			.2263		.9054		
14					.5206		
15			1.2562		.5772		
16			.8601		.8601		
17							1.6975
18							.9054
19							.5885
20	.1754						.5772
21				.2263			
24			1.2222		.8205		.8714
Max	.1754	.3282	1.2562	.2263	.9054	.7695	1.6975
Min	.1754	.2263	.2263	.2263	.3112	.215	.5772
Avg	.1754	.2773	.7227	.2263	.6075	.5008	.928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 201 / 11 KV Ankur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596		.9282		.8718	.7461	.9282
2	.7796		.9069		.8002	.7545	.9069
3	.7545		.8745		.7811	.6935	.8745
4	.7628		.7907		.7499	.6935	.8962
5	.7888		.7811		.7316	.6859	.7811
6	.8139		.7621		.6923	.7545	.7621
7	.1867		.7316		.9175	.9015	.9709
8	.1402		.7682	.4451	.9602	.6379	.631
9	.1227	.6783		.7407	1.4632	1.1706	1.3169
10	.16	1.2567		1.8107	1.5524		
11	.192	1.3169		1.4632	1.6598		
12	.0842	1.2437		1.4632	1.5524		
13	.176	1.1104		1.2894	1.4937		
14	.0793	.9496		1.5927	1.4937		
15	.0777	1.0349		1.7924	1.4784		
16	.176	1.2437	1.5844	1.643	1.4784	1.5844	
17	.1829	1.2178	1.3306		1.3443	1.307	
18	.1905	1.2178			1.1827	1.1949	
19	.4854	1.0517	.9709		.9313	1.0974	1.0974
20	.0732	.9945	.8916		.823	.9114	.5182
21	.0549	.9015	.7407		.9214	.9568	.8048
22	.08	.7133	.7499		.9015	.9709	.8322
23		.4633	.9114		.9114	1.0029	.8139
24	.9808		.4001		.8718	.8413	.2774
Max	.9808	1.3169	1.5844	1.8107	1.6598	1.5844	1.3169
Min	.0549	.4633	.4001	.4451	.6923	.6379	.2774
Avg	.3566	1.0263	.8827	1.3600	1.1068	.9392	.8274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 202 / 11 KV LOKMAT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.4633		.5571	.4664	.4633
2	.4877		.423		.5243	.4268	.423
3	.4115		.3841		.4344	.4001	.3948
4	.3788		.3734		.423	.3944	.3841
5	.3201		.3734		.423	.3887	.3734
6	.2675		.3429		.4172	.4146	.3734
7	.3201		.4329		.3361	.4054	.4999
8	.2881		.4938	.4877	.4054	.4877	.4938
9	.2987	.8688			.7468	.9412	.8048
10	.3521	.8688		1.1317			
11	.439	1.2071		1.0136	1.1317		
12	.3887	1.2071		1.0456	1.1203		
13	.3829	1.1203		.9671	.9412		
14	.3829	1.1203		1.1317	1.0242		
15	.3254	1.0562		1.1317	1.1317		
16	.3658	1.1317	1.3443	1.1317	1.1203	1.1317	
17	.3429		1.1317		1.0562	1.1317	
18	.2987				.961	.961	
19	.2824		.7468		.8779	.9511	.8596
20	.2149		.6241		.7964	.8048	.6104
21	.2195		.5117		.543	.6443	.5121
22	.2241	.5761	.4001		.5761	.6036	.3948
23	.2286	.6226	.5117		.5243	.6935	.4938
24	.6249		.6104		.5365	.4641	.5243
Max	.6249	1.2071	1.3443	1.1317	1.1317	1.1317	.8596
Min	.2149	.5761	.3429	.4877	.3361	.3887	.3734
Avg	.3459	.9779	.5730	1.0051	.7221	.6506	.5070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 206 / 11 KV MIDC Water Supply

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1458		1.2197		1.2197	1.3306	1.2197
2	1.1273		1.1458		1.1458	1.2197	1.1458
3	1.1273		1.1088		1.1088	1.1088	1.1088
4	1.1088		1.1088		1.1088	1.1088	1.1088
5	.9979		1.1088		1.1088	1.1088	1.1088
6	1.0164		1.0534		1.0719	1.0349	1.0534
7	.961		1.0349		1.0164	.924	.961
8	.9055		.924	.5729	.961	.8316	.8686
9	.8131	.8871		.5729	.8316	.7762	.8131
10	.8131	.8501		.6283	.8501		
11	.7207	.8501		.6283	.8501		
12	.7392	.924		.6283	.8131		
13	.7762	.924		.6283	.7762		
14	.8316	.037		.6653	.8501		
15	.961	.037		.7023	.9979		
16	.8871	.8871	1.3306	.037	.9979	.9425	
17	.8131		.0185		.7392	.8501	
18	.8316				.6653	.924	
19	1.1273				.7947	1.2567	1.2382
20	1.4415				.9979	1.4045	1.4784
21	1.423		.0377		1.3491	1.4045	1.46
22	1.4784	1.5154	.2263		1.1088	1.3306	
23	1.46	1.3306			1.2382	1.1827	.462
24	1.2752		1.3306		1.1458	1.1088	1.1643
Max	1.4784	1.5154	1.3306	.7023	1.3491	1.4045	1.4784
Min	.7207	.037	.0185	.037	.6653	.7762	.462
Avg	1.0326	.8242	.8960	.5626	.9895	1.1027	1.0851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 207 / 11 KV Bharat Steel
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0057		.0091		.0183	.1219	.0274
2	.0381		.0091		.0244	.0152	.0259
3	.0038		.0091		.0244	.0152	.0274
4	.0057		.0152		.0305	.0183	.0305
5	.0038		.0213		.0305	.0183	.0213
6	.0019		.0274		.0274	.0267	.0564
7	.003		.064		.6325	.0229	.0274
8	.003		.1638	.2195	.8619	.1829	.9122
9	.003	1.5089		1.5844	.407	.2858	.2401
10	.0038	1.9616		.2881	.3018		
11	.0038	2.2068		1.4937	.6958		
12	.0038	.1646		.3704	1.8107		
13	.0057	1.8107		1.7741	1.7353		
14	.0019	2.2634		1.4784	1.7353		
15	.0019	1.2437		1.5089	1.8107		
16	.0038	.1852	1.5257	1.5089	1.8107	.1524	
17	.0038		.1646		1.8861	1.4937	
18	.003				1.4937	.6325	
19	.003		.0057		2.1437	1.5089	1.6598
20	.003		.0057		2.0698	1.3169	.2401
21	.003		.0057		1.8861	1.2696	.0091
22	.003	.0198	.0057		.0198	.0114	.0091
23	.003	.0183			.0076	.0114	.0091
24	.0061		.1372		.0076	.0076	.0091
Max	.0381	2.2634	1.5257	1.7741	2.1437	1.5089	1.6598
Min	.0019	.0183	.0057	.2195	.0076	.0076	.0091
Avg	.0050	1.1383	.1446	1.1363	.8947	.3951	.2203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 201 / 11 KV MIRAJ CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.701	2.1253	1.8099	1.4685	1.4175	1.5023	1.4352
2	1.6827	2.0452	1.7551	1.3969	1.3466	1.4864	1.4118
3	1.5927	2.0328	1.7741	1.3575	1.2894	1.448	1.3611
4	1.576	1.8099	1.7926	1.3032	1.2894	1.4148	1.3611
5	1.576	1.7737	1.7737	1.3032	1.2894	1.3937	1.3611
6	1.5947	1.7926	1.829	1.3213		1.3937	1.3998
7	1.56	1.8111	1.8461	1.2894		1.3253	1.382
8	1.56	1.7926		1.2894	.2481	1.3032	1.4148
9	1.6118	1.7926	1.7194	1.2894	.2481	1.2715	1.379
10		1.8665	1.8604	1.4969	1.6095	1.382	1.5023
11		1.8473	1.8073	1.4449		1.4148	1.448
12		1.7375	1.701	1.5524	.5973	1.3998	1.4449
13		1.7013	1.701	1.448	.5853	1.379	1.5154
14		1.6297	1.7364	1.4266	.6036	1.3672	1.3306
15		1.6832	1.8404	1.5154	1.6289	1.382	1.6263
16		1.7375	1.8404	1.386	1.5043	1.4299	1.6263
17	2.1719	1.7924	1.5415	.6335	1.3032	1.4352	1.6632
18	2.1357	1.9404		1.0745	.9671	1.3611	1.6448
19	2.2081	2.2497		.5014	1.8267	1.7703	2.0328
20	2.3529	2.3285	.7701	.5552	2.2081	1.9342	2.2916
21	2.4394	2.2497	.7343	1.7177	1.9342	1.8604	2.2177
22	2.347	2.2443	1.7556	1.7193	1.8642	1.7193	
23	2.2177	2.1948	1.6834	1.5746	1.6827	1.6478	
24	1.8088	2.0698	2.0416	1.576	1.4864	1.576	1.5043
Max	2.4394	2.3285	2.0416	1.7193	2.2081	1.9342	2.2916
Min	1.56	1.6297	.7343	.5014	.2481	1.2715	1.3306
Avg	1.8904	1.9270	1.6816	1.3184	1.2824	1.4832	1.5616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 204 / 11 KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1848	.181	.1698	.1612	.181	.1629
2	.1433	.181	.1791	.1509	.1629	.1791	.1612
3	.1448	.181	.1829	.1509	.1612	.1629	.1612
4	.1433	.1646	.1663	.1509	.1629	.1791	.1629
5	.1433	.1629	.181	.1698	.1629	.181	.1612
6	.2012	.1646	.2378	.1886	.2353	.1991	.2507
7	.2149	.1663	.1991	.2263	.1791	.1612	.1791
8	.1791	.1848	.2378	.1886	.1791	.1629	.2149
9	.2149	.2957	.2715	.2075	.1991	.1791	.2865
10		.2957	.3109	.3258	.2378	.1791	
11		.3658	.2926	.2378	.3077	.2172	.3258
12		.3258	.2534	.2957	.2353	.1991	.2402
13		.3224	.2926	.3142	.2378	.1612	.2172
14		.2328	.2353	.2957	.2195	.1612	.2218
15		.2172	.2012	.2218	.1991	.1791	
16		.2172	.1829	.2172	.1791	.1612	.2218
17	.2534	.2012	.1829	.1629	.1991	.1629	.1848
18	.2172	.1848	.1867	.1646	.2149	.1629	.2033
19	.2218	.2012	.1867	.1629	.197	.181	.2218
20	.2195	.2033	.2218	.2012	.1991	.2012	.2402
21	.2218	.2012	.2033	.181	.1791	.2149	.2218
22	.2218	.1991	.2033	.1829	.1829	.2149	
23	.2033	.2012	.1867	.1629	.1829		
24	.1448	.2033	.1791	.1829	.1646	.1791	.1829
Max	.2534	.3658	.3109	.3258	.3077	.2172	.3258
Min	.1433	.1629	.1663	.1509	.1612	.1612	.1612
Avg	.1903	.2191	.2148	.2047	.1975	.1809	.2111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 205 / 11KV Dairy Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.2012	1.1641	1.0082	.9328	.9313	.9328
2	1.0242	1.1763	1.0745	.9709	.8688	.905	.8779
3	.9328	1.1203	1.0498	.9335	.8779	.8688	.8779
4	.9231	1.0829	.9979	.8962	.8779	.8413	.8688
5	.9328	1.0269	.9694	.8962	.8779	.823	.8779
6	.9145	.9335	.9231	.9149	.7499	.7421	.8413
7	.8145	.9149	.8779	.8029	.6697	.6805	.7602
8	.8596	.8775		.8589	.7421	.7164	.7865
9	.8869	.9709	.9877	.8962	.8596	.7164	
10		1.1016	1.0974	1.0829	.8686	.8413	1.0269
11		1.1888	1.1706	1.1883	.9412	.8686	1.0829
12		1.1403	1.2071	1.1203	.8962	.8779	1.1088
13		1.1104	1.3169	1.2696	.9593	.8507	1.0829
14		1.1157	1.2071	1.251	.9955	.8962	1.1949
15		1.1283	1.2254	1.2136	1.0029	.8779	1.251
16		1.1641	1.2254	1.1203	.9955	.905	1.2136
17	.8688	1.1104	1.0791	1.1203	.9313	.8048	1.1389
18	1.1706	1.1041		1.0791	.8417	.823	1.0829
19	1.2567	1.2357		1.1888	1.0566	1.134	1.3256
20	1.3491	1.3032	1.4045	1.1946	1.1041	1.1584	1.3352
21	1.3676	1.2178	1.0791	1.1403	1.0566	1.134	1.2936
22	1.363	1.267	1.2567	1.1888	1.0679	1.1706	
23	1.2936	1.3213	1.1763	1.1523	1.0029	1.0974	
24	1.1523		1.2071	1.0829	.9774	.9774	.9877
Max	1.3676	1.3213	1.4045	1.2696	1.1041	1.1706	1.3352
Min	.8145	.8775	.8779	.8029	.6697	.6805	.7602
Avg	1.0704	1.1223	1.1284	1.0655	.9231	.9018	1.0452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 206 / Vidya nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.924	.9313	.823	.7682	.7164	.695
2	.8145	.8871	.9313	.7865	.7392	.6878	.6516
3	.7682	.8962	.905	.7316	.6878	.6516	.6154
4	.7602	.8402	.9055	.7499	.695	.6401	.6154
5	.7682	.7947	.8596	.7499	.6878	.6036	.6154
6	.7059	.7468	.7964	.7682	.6219	.5611	.6154
7	.695	.7468	.823	.7316	.5973	.5731	.5611
8	.6154	.6908	.7059	.6767	.6036	.5487	.5304
9	.6219	.6722	.6767	.5792	.567	.4656	
10		.6535	.6767	.6979	.5914	.5121	.567
11		.6219	.6401	.6224	.5611	.5068	.5729
12		.6516	.6036	.6099	.567	.567	.6099
13		.6268	.6584	.5914	.5611	.5249	.6161
14		.6219	.6516	.6283	.543	.5487	.6535
15		.6089	.724	.6653	.5194	.5792	.6348
16		.6268	.724		.543	.5853	.6348
17	.7947	.6268	.7133		.5373	.567	.5975
18	.8131	.6516			.5552	.567	.6099
19	.8871	.8775	.9877		.7343	.7316	.8131
20	1.0164	.9955	.9593	1.0679	.8145	.8326	.9795
21	1.0269	.9313	.8869	.9593	.788	.823	.961
22	1.0534	1.0317	.9877	.9511	.8145	.8048	
23	1.0164	1.0498	.9694		.7701	.8048	
24	.905	.9795	.9877	.9145	.8048	.7602	.7316
Max	1.0534	1.0498	.9877	1.0679	.8145	.8326	.9795
Min	.6154	.6089	.6036	.5792	.5194	.4656	.5304
Avg	.8318	.7814	.8133	.7529	.6530	.6318	.6610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 401 / 33 KV Bedag outgoing(
Crossove Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.7075	8.4888	8.4705	3.4156	3.5305	7.6017	7.2102
2	7.7572	8.2922	8.65	3.4156	3.3916	7.6292	7.029
3	7.8464	8.6334	8.8889	3.4568	3.4979	7.6017	7.029
4	8.0476	9.5679	9.1478	3.6008	3.4591	7.5217	7.1765
5	8.3539	11.8199	9.7737	3.8409	1.7604	8.1447	7.324
6	10.663	12.2171	11.358	4.3747	3.7792	10.6967	9.0004
7	12.2823	13.5746	2.9012	5.1852	4.9794	13.4854	10.3967
8	12.3388	12.9773	12.62	5.9534	4.9228	14.0089	11.4866
9	11.5226	12.7515	10.4796	5.3441	8.5991	13.5391	11.2071
10		13.0287	11.3169	6.5158	11.1934	11.1883	9.6108
11		14.8697	11.677	6.4849	4.9954	7.3937	11.837
12		8.742	11.3683	7.276	7.4932	9.1335	9.5565
13		4.2981	10.8025	9.5565	8.3951	8.9392	12.2714
14		11.6587	11.8827	9.6651	6.4746	9.3484	12.1628
15		12.4886	5.4264	6.4615	7.656	9.6834	11.837
16		8.742	11.677		9.1873	8.9301	10.7002
17	1.0317	12.2908		2.4691	9.5565	1.6461	12.9773
18	8.7963	10.4784		4.2267	9.0369	2.5857	11.4283
19	9.5565	3.1276	2.3891	2.7263	2.364	2.7343	3.1379
20	4.2353	3.5482	1.7918	3.3128	3.3665	3.5368	3.7969
21	4.1267	4.1152	2.2805	3.035	3.2773	3.2407	
22	3.8683	3.8409	2.4977	2.9447	3.1493	2.8509	
23	3.2236	3.3665	2.1719	2.6818	2.8532	2.6235	
24	2.6749	2.9012	2.9012	2.1176	2.4177	2.5252	2.4177
Max	12.3388	14.8697	12.62	9.6651	11.1934	14.0089	12.9773
Min	1.0317	2.9012	1.7918	2.1176	1.7604	1.6461	2.4177
Avg	7.2960	8.9925	7.7488	4.6983	5.3890	7.3579	9.0283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 201 / 11KV Jagdish IRON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814						2.0957
2	1.5466						1.9814
3	1.6221						2.1719
4	1.7164						1.6787
5	1.5844						1.905
6	2.191						2.1719
7	1.6221						2.1338
8	1.4098						1.8099
9	.2681	.9145	1.5655		2.21	2.1529	.9511
10	.2473	1.1128	1.2193		.9242	2.191	2.1338
11	.2789	2.2862	2.4196		2.3624	2.2257	2.21
12	.3022	1.1883	2.3243		2.037	2.3954	2.2862
13	.2378	2.2481	1.6032		1.0185	1.094	2.0957
14	.1858	2.1529	1.9427		1.6221	2.3434	1.1317
15	.2143	1.8296	2.2481		1.4901	1.7718	1.5089
16	.2191	2.1125	1.6766		1.773	2.0576	1.7147
17			2.1338			2.3243	1.9052
18						1.6598	2.3243
19			2.2822			1.7147	1.7147
20			.9335			1.1317	1.6804
21			2.21			2.1719	1.6827
22			2.0386			2.1338	1.8861
23			2.0195			2.0957	2.21
24	1.5813			1.6385			2.0195
Max	2.191	2.2862	2.4196	1.6385	2.3624	2.3954	2.3243
Min	.1858	.9145	.9335	1.6385	.9242	1.094	.9511
Avg	1.0123	1.7306	1.9012	1.6385	1.6797	1.9642	1.8918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 202 / 11 KV Mahabal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3769						.3189
2	1.3203						.2873
3	1.2637						.3022
4	1.3203						.2932
5	1.3769						.3447
6	1.4146						.4058
7	1.3769						.4967
8	.1928						.5493
9	.2347	1.2637	1.1431		.9808	.421	1.1128
10	.1886	1.2003	1.9239		1.5051	.5487	1.0669
11	.1425	.811	1.1128		1.8673	.5731	.9431
12	.1665	.9808	1.0185		1.5278	.4801	.8962
13	.1463	1.448	1.7718		1.6004	.2538	1.1317
14	.1463	1.8861	1.4712		1.1431	.5087	1.3336
15	.1578	1.448	1.7541		1.2955	.5731	1.5242
16	.1315	1.5242			1.7918	.3725	1.9052
17			1.3908			.3978	1.8671
18						.3429	1.829
19			.9335			.5487	1.6385
20			1.0562			.2824	1.6004
21			.9522			.3447	1.5623
22			1.0082			.3368	1.1203
23			1.6194			.2824	.9979
24	1.4901			1.5242			.3022
Max	1.4901	1.8861	1.9239	1.5242	1.8673	.5731	1.9052
Min	.1315	.811	.9335	1.5242	.9808	.2538	.2873
Avg	.7322	1.3203	1.3197	1.5242	1.4640	.4178	.9929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 203 / 11KV Shreeji

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774						.3326
2	.2572						.3109
3	.2458						.2926
4	.2774						.3142
5	.2743						.2957
6	.2321						.2534
7	.2652						.2772
8	.1532						.3921
9	.1448	.5281	.5281		.3921	.5194	.9619
10	.1562	.6097	.6287		.4763	.6097	.7545
11	.052	.6287	.6602		.5144	.547	.7095
12	.0703	.5906	.5281		.5525	.5658	.6653
13	.1734	.5906	.5335		.5906	.5906	.7095
14	.1509	.6979	.6097		.8488	.7545	.7621
15	.1389	.7167	.6859		.7167	.7545	.724
16	.0869	.6224	.6097		.6979	.5658	.7167
17			.5847			.5847	.6722
18						.5658	.5914
19			.4477			.5093	.415
20			.2601			.3142	.3734
21			.3189			.2658	.3109
22			.2107			.1907	.3326
23			.3696			.3395	.2957
24	.2629			.3734			.3961
Max	.2774	.7167	.6859	.3734	.8488	.7545	.9619
Min	.052	.5281	.2107	.3734	.3921	.1907	.2534
Avg	.1893	.6231	.4983	.3734	.5987	.5118	.4941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 204 / 11KV JK ICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1502						1.2715
2	1.7924						1.5565
3	1.5497						1.134
4	1.8858						1.3717
5	1.6057						1.4449
6	2.2822						2.1658
7	2.1502						1.9978
8	2.0725						1.5947
9	.9555	1.9805	3.1055			2.3577	3.2007
10	1.5384	3.3008	3.3385		2.0182	2.9613	3.3913
11	2.5274	1.9239	3.6969		2.5911		3.4675
12	1.0454	1.9624	3.3008		2.8769	.0372	3.7723
13	.6722	1.3146	3.2388		3.315	1.6617	3.6199
14	1.3253	1.7741	3.2579		3.2769	2.3765	3.4294
15	2.2731	2.934	3.131		1.9239	3.81	3.5056
16	.8032	3.0293	2.3053		1.4901	2.8769	3.6961
17			1.9239			3.0102	3.4294
18						1.6448	2.4768
19			.3932			1.6263	2.9721
20			1.0749			1.382	2.4272
21			1.3672			1.2309	1.5524
22			1.262			1.1768	1.448
23			2.2218			1.1603	1.2689
24	2.3011			1.0722			1.4327
Max	2.5274	3.3008	3.6969	1.0722	3.315	3.81	3.7723
Min	.6722	1.3146	.3932	1.0722	1.4901	.0372	1.134
Avg	1.7018	2.2775	2.4013	1.0722	2.4989	1.9509	2.4011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 205 / 11KV Shakti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185						1.4146
2	.8131						1.2696
3	.8962						1.3769
4	.7842						1.419
5	.7343						1.1016
6	.5801						1.0164
7	.6556						.8869
8	.3395						1.0608
9	.1509	1.0374	1.4335		.9795	1.0642	1.358
10	.1477	1.4098	1.7353		1.2071	1.4146	1.3717
11	.0347	1.5051	1.8099		1.5432	1.4901	1.8861
12	.0381	1.6032	1.8107		1.358	2.1313	2.037
13	.0381	1.6766	1.905		1.4335	1.3769	1.9052
14	.0143	1.5813	2.0182		1.2955	1.5655	1.6004
15	.0351	1.5655	2.2445		1.5844	2.037	
16	.0613	1.5844	1.9805		1.3717	2.0559	2.2481
17			2.2779			1.7909	1.9052
18						1.6956	1.2193
19			1.9427			1.9624	1.6004
20			1.3817			1.6004	1.5089
21			1.3014			1.7337	1.0456
22			.9242			1.6194	1.1317
23			.8775			1.4146	1.1694
24	1.0562			1.0082			1.4901
Max	1.0562	1.6766	2.2779	1.0082	1.5844	2.1313	2.2481
Min	.0143	1.0374	.8775	1.0082	.9795	1.0642	.8869
Avg	.4352	1.4954	1.6888	1.0082	1.3466	1.6635	1.4358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 206 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722						.7356
2	.5359						.679
3	.4805						.5975
4	.4481						.6535
5	.4207						.5359
6	.2715						.6468
7	.3366						.4854
8	.1707						.7733
9	.2279	.5544	.9997		.6413	.8676	.9619
10	.2658	.6602	1.0669		.8764	.7049	1.1694
11	.2035	.8192	.679		.9526	.7922	1.1812
12	.1658	.9335	.8764		.7922	1.086	1.1431
13	.1646	.8573	.9907		.8954	.9335	1.105
14	.2256	.9526	.9054		.8299	.8676	1.0669
15	.2214	.7922	1.0374		.8676	.9054	1.0288
16	.208	.679	1.1317		1.1622		.9526
17			.9907			.9717	.8676
18						.6859	.8299
19			.5601			.9619	.7621
20			.5249			.8383	.5716
21			.5847			.679	.4191
22			.7922			.7922	.5601
23			.8573				.6348
24	.6602			.8573			.7545
Max	.6722	.9526	1.1317	.8573	1.1622	1.086	1.1812
Min	.1646	.5544	.5249	.8573	.6413	.679	.4191
Avg	.3341	.7811	.8569	.8573	.8772	.8528	.7965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 210 / 11KV Saptrang

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8238						.7842
2	.7282						.8871
3	.5898						.6089
4	.6859						.631
5	.4641						.567
6	.1955						
7	.1635						.5304
8	.3429						.5258
9	.3988	.2724	.8775		.7207	.7392	.8488
10	.0867	1.4712	.7922		.9997	.7762	.7316
11	.0693	1.5844	1.1128		1.1128	.8029	1.1088
12	.08	.9808	1.0456		1.0185	.7023	1.2323
13	.0471	1.3957	1.2449		.8775	.8589	1.2955
14	.0453	.7842	1.0751		1.4335	1.226	1.3336
15	.081	1.3957	1.3203		1.5466	1.2449	1.1317
16	.0297	.6468	1.5089			.5959	.8215
17			1.4335			.7133	.7316
18						.4321	.6089
19						.8589	.6447
20			.2976			.2241	.5144
21			.7964			.1227	.4268
22			1.1389			.2092	.3913
23			1.226			1.0456	.3567
24	.9955			1.0456			1.0456
Max	.9955	1.5844	1.5089	1.0456	1.5466	1.2449	1.3336
Min	.0297	.2724	.2976	1.0456	.7207	.1227	.3567
Avg	.3428	1.0664	1.0669	1.0456	1.1013	.7035	.7721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 401 / 33KV Super Craft Foundry NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2253						3.0624
2	3.3385						2.963
3	2.7161						3.1699
4	3.1121						3.0087
5	3.1687						3.4751
6	3.0556						3.2773
7	2.6029						3.0087
8	.7282						2.7149
9	.2743	3.4517	2.8292		2.9012	.4475	3.4922
10	.152	2.037	3.3608		3.0087	2.6863	1.5775
11	.1749	3.1121	2.7726		1.7353	3.1699	2.6578
12	.2006	2.7726	3.2253		3.2253	1.4563	3.3311
13	.1143	2.0936	.3052		3.2773	1.4118	3.1893
14	.2006	1.7541	2.8858		3.4385	.3081	3.4922
15	.1595	2.0936	2.0936		3.0624	2.9864	2.7149
16	.2058	3.6408	3.1121		3.2579	2.0416	3.3665
17			3.5848			3.0087	3.2236
18						1.8404	3.1161
19			3.3385			2.6326	3.4208
20			3.2036			1.0682	3.2579
21			2.8235			1.5775	3.3665
22			2.6863			3.6534	2.6863
23			3.3122			2.9864	2.2565
24	3.2253			2.5252			2.9864
Max	3.3385	3.6408	3.5848	2.5252	3.4385	3.6534	3.4922
Min	.1143	1.7541	.3052	2.5252	1.7353	.3081	1.5775
Avg	1.5679	2.6194	2.8238	2.5252	2.9883	2.0850	3.0340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 201 / 11KV JACKWELL LIS

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.7356	.7655	.7762	.7468	.7133	.7545
2	.7922	.7545	.7545	.7733	.7392	.7023	.7545
3	.7922	.6097	.7842	.7468	.7842	.6584	.7733
4	.7922	.6097	.7655	.7842	.7577	.7392	.6097
5	.7922	.7545	.7392	.7577	.7468	.695	.6097
6	.7922	.6097	.7468	.7545		.6468	.7922
7	.7733	.7545	.7733	.7842	.7762	.6161	.6097
8	.6413	.7545	.7733	.7762	.6468	.7655	.7922
9	.6413	.6036	.7655	.6722	.7682	.7842	.6602
10	.4668	.7922	.7356	.7922	.7537	.6348	.5093
11		.8299	.7733	.7922	.8299	.7545	.811
12		.415	.7545	.7922	.811	.7356	.811
13		.7922	.7356	.7733	.811	.7356	.7842
14	.6097	.8299	.7356	.7545	.8029	.7356	.7922
15	.6097	.8215	.7356	.7922	.811	.7356	.7922
16	.6097	.811	.7356	.6224	.811	.7356	.811
17	.6097	.8299	.7545	.3366	.7922	.7545	.7922
18	.3475	.811			.7842	.7545	.811
19	.6097	.811	.3658	.1433	.8215	.7545	.811
20	.5906	.8402	.7545	.2534	.811	.7545	.811
21	.7545	.6602	.7545	.2561		.6097	.6036
22	.7356	.679	.811	.6036	.6161	.6478	.6036
23	.7356	.8029	.8215	.6099	.7207	.7922	.7545
24	.7922	.7545	.7922	.8299	.7468	.7762	.7922
Max	.7922	.8402	.8215	.8299	.8299	.7922	.811
Min	.3475	.415	.3658	.1433	.6161	.6097	.5093
Avg	.6800	.7361	.7447	.6599	.7677	.718	.7353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 202 / 11KV GANPATI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1222	1.0631	1.1584	1.1157	1.0349	.9774	1.0277
2	1.086	1.0631	1.1104	1.086	1.0608	.9694	1.0029
3	1.0534	1.0387	1.0498	1.0608	.9979	.9412	.9671
4	1.0164	1.0029	.9671	.9774	.9511	.8859	.905
5	.924	.9922	.9511	.9511	.924	.8869	.8859
6	.8779	.9412	.905	.905		.823	.8596
7	.8326	.905	.8417	.823	.9145	.7865	.815
8	.8688	.8596	.9694	.8048	.8316	.8131	.7701
9	.8859	.8589	.9593	.9145	.8596	.8402	.8238
10	.985	.9709	1.0749	1.0341	.9036	.9425	.9465
11		1.2757	1.4118	1.258	1.1041	1.134	1.0924
12		1.3213	1.448	1.3112	1.2851	1.1283	1.1999
13		1.3176	1.4175	1.3289	1.2803	1.2048	1.134
14	1.6476	1.3253	1.379	1.3253	1.2437	1.1283	1.0631
15	1.448	1.3253	1.3937	1.3169	1.267	1.1946	1.1041
16	1.39	1.3432	1.4118	1.3756	1.1584	1.1999	1.0498
17	1.4045	1.262	1.3937	1.5415	1.3073	1.2127	1.1041
18	1.3847	1.3643		1.5043	1.2536	1.2403	1.1088
19	1.7528	1.773		1.7375	1.6832	1.6126	1.4685
20	1.7703	1.828	1.0517	1.7013	1.701	1.6827	1.576
21	1.4529	1.5181	.6173	1.4815		1.3643	1.386
22	1.3112	1.423	1.335	1.267	1.2308	1.1871	1.267
23	1.2357	1.363	1.2445	1.2254	1.1765	1.134	1.1946
24	1.1222	1.1283	1.2127	1.1403	1.1088	1.0136	1.0566
Max	1.7703	1.828	1.448	1.7375	1.701	1.6827	1.576
Min	.8326	.8589	.6173	.8048	.8316	.7865	.7701
Avg	1.2177	1.2193	1.1502	1.2161	1.1490	1.0960	1.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 203 / 11KV SANGLI WADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9055	.8505	.9149		.7499	.7207	.8316
2	.8402	.8238	.924	.7356	.7392	.695	.7682
3	.8029	.8688	.8962	.7468	.7682	.7207	.7682
4	.8029	.905	.9055	.7545	.7577	.695	.8402
5		.9145	.9335	.7095	.7392	.6838	.8145
6	.8865	.8962	.9425	.679	.7023	.7133	.7316
7	.811	.8954	.8962	.6348	.6908	.6838	.695
8	.8326	.8775	.8686	.6219	.6535	.6348	.6468
9	.8145	.9709	1.0456	.6283	.5601	.6908	.7682
10	.7865	1.0576	1.0229	.6516	.5138	.8131	.8059
11		1.1641	1.0808	.6584	.543	.7343	.8954
12		1.1462	1.0099	.7316	.6379	.7522	.9145
13		1.0679	.9568	.7392	.6379	.8145	.8962
14	.961	1.0679	1.0745	.7023	.7059	.7468	.6584
15	.924	1.0387	1.0679	.6722	.7577	.7577	.8775
16	.9149	.9774	1.0631	.695	.7421	.7783	.7964
17	.8871	.9774	1.0808	.6584	.7421	.8048	.7964
18	.8238	1.0454			.6401	.7783	.7537
19	.9362	1.2567	.6201	.8871	.8596	.9774	.9412
20	1.1283	1.307	.7947	1.0059	1.0059	1.1157	1.0679
21	1.086	1.1389	.8501	.9979		1.0349	1.0498
22	1.0791	1.094	.8686	1.0082	.9694	.9795	.9955
23	.9694	.9709	.8686	.9055	.8048	.9055	.9214
24	.9055	.8962	.8775	.7922	.7947	.7499	.8402
Max	1.1283	1.307	1.0808	1.0082	1.0059	1.1157	1.0679
Min	.7865	.8238	.6201	.6219	.5138	.6348	.6468
Avg	.9049	1.0087	.9375	.7553	.7268	.7909	.8364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 403 / 33 KV- BALAJIMANDIR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7973	.743	.743	1.1431	1.086	1.0631
2	.7762	.7522	.8002	.6859	1.086	1.086	1.0631
3	.6099	.7059	.743	.6859	1.1431	1.0288	1.0317
4	.5544	.7059	.6859	.6287	1.086	.9717	1.0317
5	.543	.6379	.6287	.6859	1.0288	.9145	.9877
6	.6099	.6516	.6859	.6287	.9717	.9145	.9774
7	.543	.5373	.6287	.6287	.9145	.8573	.9328
8	.543	.5373	.6287	.5716	.9145	.8573	.8779
9	.5716	.6379	.7207	.4835	.8962	.9145	.9328
10	.6287	.6836	.8413	.6447	.9882	1.1431	1.1283
11		.8059	.8596	.6984	1.0974	1.0745	1.2894
12		.7802	.9134	.8059	1.1283	1.0745	1.1694
13		.7802	.8505	.6984	.9671	1.0099	1.0745
14		.8596	.8596	.8145	.3801	1.086	1.086
15	.743	.9231	.9134	.9231	1.1523	1.1946	1.4118
16	.8573	.9134	.9568	.8596	1.2489	1.0745	1.4118
17	.7682	.8573	.8505	.1143	1.2003	1.086	1.2357
18	.631	.8573		.8002	.9717	1.0099	1.182
19	.6241	.8002	.4938	.743	1.086	1.0517	1.2094
20	.7282	.8573	.5373	.6287	1.086	1.1043	1.2094
21	.7442	.8573	.6447	1.3146		1.1163	1.2226
22	.7973	.9717	.5316	1.3717	1.2574	1.2357	1.2226
23	.8596	.9717	.743	1.3717	1.3146	1.2357	1.2894
24	.823	.8059	.9145	.743	1.3146	1.2003	1.1946
Max	.8596	.9717	.9568	1.3717	1.3146	1.2357	1.4118
Min	.543	.5373	.4938	.1143	.3801	.8573	.8779
Avg	.6889	.7787	.7467	.7614	1.0599	1.0553	1.1348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 404 / 33 KV -MJP SHERINALA STAGE NON SHEDDABLE EXPRESS HV FEEDERS
 NO- Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1595	.1143		.0572	.1143	.1063
2	.2218	.1612	.1715	.0572	.1143	.1143	.1063
3	.2218	.1629	.1143	.0572	.1715	.1715	.1086
4	.2218	.1629	.1715	.0572	.1715	.2286	.1629
5	.1629	.1595	.1715	.0572	.1715	.1715	.1646
6	.1663	.3258	.1143	.0572	.3429	.2286	.1086
7	.1629	.3224	.1143	.1143	.1715	.3429	.1646
8	.1629	.1612	.0572	.1143	.1715	.1715	.1646
9	.1715	.3189	.0554	.1075	.3361	.3429	.439
10	.1715	.1578	.1578	.1075	.156	.0572	.3761
11		.1612	.3761	.1075	.3292	.1075	
12		.2601	.1612	.1075		.2149	.1595
13		.052	.3721	.1075	.0537	.3721	.3224
14	.3429	.3224	.3761	.1086	.4344	.3801	.3801
15	.1715	.1629	.1612	.1086	.2195	.2172	.2715
16	.1715	.3224	.3721	.1075	.4344	.3761	.4344
17	.3292	.1715	.3189	.1143	.1143	.3801	.3761
18	.3155	.3429		.5144	.1143	.3721	.3761
19	.156	.1715	.3841	.1715	.0572	.2103	.2103
20	.3121	.1715	.3224	.3429	.0572	.3681	.1578
21	.1595	.1715		.1143		.2126	.3721
22	.1595	.3429		.3429	.0572	.3761	.1595
23	.1612	.3429	.0572	.3429	.1143	.2149	.3761
24	.1646	.1612	.1715	.0572	.0572	.1143	.1086
Max	.3429	.3429	.3841	.5144	.4344	.3801	.439
Min	.156	.052	.0554	.0572	.0537	.0572	.1063
Avg	.2060	.2187	.2055	.1468	.1776	.2442	.2437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 201 / 11KV RAMMANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	1.2384	1.2193	1.0669	1.0479	.9997	.9511
2	1.1431	1.1812	1.1812		.9907	.9431	.8779
3	1.0669	1.1431	1.1431		.9526	.9054	.8688
4	.9907	1.086	1.0669	.9526	.9335	.8676	.8326
5	.9145	1.0288	1.0288	.9145	.9335	.8299	.8413
6	.8764	.9335	.9526		.8573	.7922	.7316
7	.8573	.8573	.9526		.7811	.7545	.7316
8	.8383	.8002	.9145	.8002	.743	.7167	.7316
9	.8383	.8192		.8192	.7621	.7167	.7059
10	.8764	.8954	.9526	.8764	.8192	.679	.8192
11	.9145	1.094	.9907	.9526	.8676	.7621	.8764
12	1.105	1.1317	1.2003		.9431	.8002	1.0098
13	1.086	1.094	1.1431	1.2193	.9431	.8002	1.0288
14	1.0288		1.2193	1.1431	.9431	.8002	1.0479
15	.9907	1.2449	1.2193	1.086	.9808	.8002	1.0479
16	1.0288	1.1694	1.2003	1.0479	.9054		1.0098
17	1.0098	1.2071	1.2193	1.0098	.9431	.8002	
18	1.0288	1.2071			.9619	.7783	.9907
19	1.2003	1.5089			1.094	.9145	1.3908
20	1.467	1.5089			1.2449	1.0059	1.448
21	1.3908	1.3957			1.1317	1.1706	1.3527
22	1.3717	1.4335			1.0288	1.1222	1.3146
23	1.3527	1.358			1.1317	1.0608	
24	1.2765	1.2765	1.2955	.9907	1.105	1.0751	1.0136
Max	1.467	1.5089	1.2955	1.2193	1.2449	1.1706	1.448
Min	.8383	.8002	.9145	.8002	.743	.679	.7059
Avg	1.0764	1.1571	1.1117	.9907	.9602	.8737	.9828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 202 / 11KV SHAMRAO NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	1.105			1.0669	1.0374	.961
2	.9907	1.0669	.9907		1.0288	.9808	.924
3	.9145	1.0288	.9907		1.0098	.9054	.924
4	.8764	.9907		.9145	.9907	.9054	.8779
5	.8383	.9526	.9145	.8764		.8676	.8501
6	.8002	.8764	.9145	.8383		.8299	.8131
7	.7811	.8192	.8764		.7621	.7922	.7577
8	.7811	.7811	.8383	.8383	.8002	.7545	.7499
9	.8383	.8573	.9145	.8764	.8192	.7922	.8048
10	.8954	.8954	.9335	.9145	.7811	.7545	.8383
11	.9526	.8676	.9526	.9335	.811	.8383	.8573
12	.8764	.8676	.9335	.9717	.9431	.8573	.8954
13	.8573	.8299	.9335	.9335	.9054	.8573	.9145
14	.9145	.7922	.6097	.9145	.9054	.8764	.9335
15	.9145	.9054	1.105		.9431	.8573	.9907
16	.9335	.9054	1.086	.9717	.9054	.8764	.5906
17	.8573	.9242	1.0288	.9526	.8676	.8954	
18	.8002	.8676			.9054	.8316	1.0669
19	1.0098	1.0562			1.094	.9877	1.3336
20	1.2955	1.2449			1.2071	1.1458	1.3717
21	1.2765	1.2449			1.1317	1.1088	1.3717
22		1.2826			1.1317	1.0903	1.3908
23	1.3146	1.2071			1.1317	1.0974	
24	1.105	1.1241	1.1431	1.086	1.105	1.094	1.0349
Max	1.3146	1.2826	1.1431	1.086	1.2071	1.1458	1.3908
Min	.7811	.7811	.6097	.8383	.7621	.7545	.5906
Avg	.9509	.9789	.9478	.9248	.9657	.9181	.9660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 204 / 11KV CIVIL HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.7621	.8488			.8299	.8029
2	.7621	.7621	.8299		.8192	.7922	.7842
3	.7621	.7811	.811		.8002	.7922	.7842
4	.743	.743	.7733		.7811	.7922	.7842
5	.743	.8002	.7545	.6668	.7621	.7545	.7468
6	.724	.8192	.7167	.6668	.8002	.7167	.7468
7	.724	.8192	.7167		.8002	.679	.7282
8	.7049	.7811	.7167	.6859	.7049	.679	.7842
9	.743	.8192	.7545	.7049	.5906	.7545	.8402
10	.7811	.724	.8383	.743	.8192	.679	.8383
11	.8192	.811	.7811	.7621	.7545	.7049	.7811
12	.4763	.7545	.6668		.679	.5906	.8383
13		.7545	.5906	.9335	.7545	.6478	.8764
14		.7733	.7811	.9526	.7545	.7621	.9145
15		.7545	.7621	.9145	.6859	.743	.8383
16		.7545	.743	.8954	.6413	.7621	.8002
17		.7922	.6668	.7621	.811	.7811	
18	.8764	.7922			.8299	.7655	.8192
19	.8573	.8299			.6413	.7842	.9526
20	.9145	.8488			.9054	.8402	1.0669
21	.9526	.8676			.8676	.8402	.9526
22	.9907	.8676			.8676	.8215	1.0098
23	.8954	.8299			.8299	.8029	
24	.7811	.7811	.8299	.7811	.8383	.8299	.7842
Max	.9907	.8676	.8488	.9526	.9054	.8402	1.0669
Min	.4763	.724	.5906	.6668	.5906	.5906	.7282
Avg	.7911	.7926	.7545	.7891	.7712	.7561	.8397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 205 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8192	.8002		.7621	.7167	.7023
2	.7811	.8192	.8002		.743	.7167	.6653
3	.743	.7811	.7621		.724	.679	.6653
4	.7049	.7621			.7049	.6413	.6468
5	.6668	.724	.724	.6287	.743	.6036	.6468
6	.6287	.6668	.724	.6287	.6478	.5658	.6283
7	.6097	.5906	.6478		.6097	.5281	.5914
8	.6097	.5525	.5716	.5525	.5525	.5281	.5729
9	.5525	.5906	.5716	.5906	.4954	.5658	.5175
10		.5906	.5906	.5906	.5906	.5281	.5144
11		.5281	.5906	.5906	.5281	.4954	.5525
12		.5281	.5525	.5335	.5281	.4954	.6097
13		.547	.5525	.4954	.5281	.5335	.5906
14	.6097	.5281	.5906	.6097	.5281	.5525	.5716
15	.6097	.5658	.6097	.5716	.5281	.5716	.6287
16	.6097	.6036	.5906	.5716	.5658	.5716	.6287
17	.5716	.679	.6097	.6097	.4904	.5716	
18	.5716	.679			.5281	.5359	.6097
19	.724	.9054			.6413	.7316	.7811
20	.9335	.9431			.8299	.9055	.9717
21	.9717	.9808			.8676	.8962	.9335
22	.9907	.9431			.7888	.8686	.9526
23	.9335	.8676			.8299	.8501	
24	.8383	.8383	.8383	.7621	.7621	.7545	.7577
Max	.9907	.9808	.8383	.7621	.8676	.9055	.9717
Min	.5525	.5281	.5525	.4954	.4904	.4954	.5144
Avg	.7230	.7097	.6545	.5950	.6466	.6420	.6700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 206 / 11KV TRIMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	1.0288	1.0288	.8002	.9335	.8488	.7468
2	.9145	.9907	.9526		.9145	.7922	.7468
3	.8764	.9526	.8764		.8954	.7545	.7095
4	.8002	.9145			.8764	.7167	.7095
5	.724	.8383	.7621	.7049	.8764	.679	.6722
6	.6859	.7811	.743	.6668	.7621	.6413	.6161
7	.6478	.724	.724		.6859	.6036	.5975
8	.6668	.7811	.7621	.7049	.6859	.5658	.6722
9	.8002	.8383	.8383	.743	.7049	.6413	.7842
10		1.1241	1.086	1.0669	.7811	.811	1.0288
11		1.1883	1.1622	1.1241	1.0751	.9145	1.1241
12		1.2071	1.3336	1.3336	.7167	.9145	1.2574
13		1.2826	1.3146	1.2765	1.1317	.9335	1.2765
14		1.3203	1.3717	1.2384	1.094	.9717	1.2574
15	1.6194	1.3392	1.3527	1.3336	1.094	.9717	1.2955
16	1.4289	1.2826	1.3146	.5906	1.0562	.9335	1.3146
17	1.3717	1.2071	1.448	1.3527	1.0562	.9145	
18	1.2955	1.2449			.9808	.9054	1.3336
19	1.3336	1.4335			1.1694	1.1576	1.5242
20	1.5432	1.3957			1.226	1.2883	1.5432
21	1.4289	1.3203			1.1694	1.2323	1.3717
22	1.2955	1.2071			.9619	1.0374	1.1812
23	1.1812	1.1317			.9431	1.0082	
24	1.0669	1.0669	1.105	.9526	.9526	.9054	.7842
Max	1.6194	1.4335	1.448	1.3527	1.226	1.2883	1.5432
Min	.6478	.724	.724	.5906	.6859	.5658	.5975
Avg	1.0870	1.1084	1.0692	.9921	.9476	.8809	1.0249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 403 / 33 KV RISALA ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3722	3.1436	3.315		2.9721	2.9424	2.6063
2	3.2579	3.0293	3.2007		2.8006	2.8292	2.4977
3	3.1436	2.915	3.0864		2.7435	2.7161	2.4977
4	2.9721	2.8006			2.6863	2.6029	2.3891
5	2.7435	2.7435	2.8578	2.6863	2.572	2.4897	2.3891
6	2.6292	2.6292	2.7435	2.4006	2.4577	2.4897	2.3348
7	2.5149	2.5149	2.7435	2.3434	2.4006	2.3765	2.3348
8	2.5149	2.4577	2.7435	2.5149		2.3765	2.4691
9	2.7435	2.6863	2.9721	2.8006		2.5463	2.6063
10	2.8578	3.2579	3.6008	3.1436		2.3765	3.2007
11		4.0741	4.401	2.915	3.3951	3.2007	3.9438
12		4.0741	4.5725	4.2867	3.678	3.6008	4.0581
13		3.0556	4.5725	4.1152	3.7346	3.4294	4.0581
14		4.1872	4.3439	4.1152	3.6214	3.4865	4.0581
15	4.2867	4.3004	4.401	4.1152	3.6214	3.3722	4.1724
16	4.2867		4.4582	4.2295	3.7346	2.6292	4.1152
17	4.1152	4.4136	4.401	3.8866	3.6214	3.4294	
18	4.0009	4.2438			3.3436	3.1493	3.9438
19	4.401	5.036			4.4136	3.7311	4.7439
20	4.8583	5.036				4.225	4.8011
21	4.2867	4.5268			3.8477	3.9638	4.2295
22	3.8866	3.8477			3.5082	3.3665	3.7151
23	3.4294	3.6214			3.2819	3.095	
24	3.4865	3.315	3.4294	2.915	3.1436	3.1687	2.8235
Max	4.8583	5.036	4.5725	4.2867	4.4136	4.225	4.8011
Min	2.5149	2.4577	2.7435	2.3434	2.4006	2.3765	2.3348
Avg	3.4894	3.5613	3.6378	3.3191	3.2789	3.0664	3.3631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 404 / 33KV KOLHAPUR ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6868	5.144	5.3155	4.2867	5.2584	4.9794	4.7051
2	4.4582	4.9726	5.144		5.0869	4.8663	4.5931
3	4.2295	4.7439	4.9154		4.9726	4.7531	4.369
4	4.1724	4.5725		4.0009	4.8583	4.6399	4.369
5	4.0581	4.401	4.5725	4.0581	4.7439	4.5268	4.257
6	4.0009	4.2867	4.3439	4.1152	4.5153	4.4136	4.257
7	3.9438	4.1724	4.2867	4.0009	4.3439	4.1872	4.145
8	3.8866	4.0581	4.2295	3.8866		4.0741	4.0329
9	3.8866	4.2867	4.5725	3.7723		4.3004	4.369
10	4.1152	5.2584	4.6868	4.1152		4.4136	5.2012
11		5.4321	6.0585	4.8011	5.0926	4.9726	5.7728
12		5.8848	6.0585	4.9726	5.0926	4.9154	5.7156
13		4.4136	5.6584	4.9154	5.2624	5.2584	5.6013
14	3.6008	5.9414	6.0585	5.0869	5.2624	5.2584	5.487
15	4.1152	5.7716	5.8299	5.0869	5.3189	5.2584	5.9442
16	5.0297	5.7716	6.23	5.0297	5.7716	5.2012	6.0014
17	5.0869	5.7716	5.8299	3.4294	5.5453	4.6296	
18	4.9726	5.7716			5.2624	5.0412	5.8871
19	5.6013	6.5072			5.2058	5.6013	6.5158
20	6.6301	6.394			6.2243	6.7215	6.8587
21	6.0585	5.9414			5.6019	6.1054	6.3443
22	5.9442	5.8282			5.2058	5.7133	6.0585
23	5.7728	5.6584			5.3189	5.4332	
24	4.8583	5.2584	5.487	4.6296	5.4298	5.1492	4.7611
Max	6.6301	6.5072	6.23	5.0869	6.2243	6.7215	6.8587
Min	3.6008	4.0581	4.2295	3.4294	4.3439	4.0741	4.0329
Avg	4.7195	5.2601	5.2516	4.3867	5.2083	5.0172	5.2385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 201 / 11 KV SHASTRI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	1.0562	1.1317	.9088	1.0185	.9808	1.0374
2	.8573	.9808	1.094	.8916	.9997	.9054	.9619
3	.8573	.9619	1.094	.8916	.9808	.9054	.9431
4	.8573	.9619	1.094	.8916	.9808	.9054	.9054
5	.8573	.9619	1.094	.8916	.9808	.9054	.9054
6	.823	.9808	1.1317	.8573	.9431	.9431	.8865
7	.8573	.9431	1.0562	.9431	.9242	.8676	.8865
8	.823	.9431	.9619	.8676	.9242	.8488	.8865
9	.9431	.9054	.8916	.8676	.8865	.8676	.8488
10	1.094	1.1317	1.0288	1.0374	.9808	.9054	1.0751
11		1.2071	1.0974	1.1506	1.0562	.9619	1.2449
12		1.226	1.1488	1.2071	1.1317	.9997	1.3014
13		.1509	1.2003	1.3014	1.2826	.9997	1.2449
14		1.5089	1.2003	1.1694	1.226	1.1128	1.2826
15		1.5089	1.2689	1.5089	1.226	1.094	1.3014
16	1.0185	1.4523	1.286	1.3203	1.2826	1.0374	1.358
17	.9997	1.358	1.2003	1.226	1.2449		1.2826
18	1.5278	1.2637	1.0974	1.2071	1.2826	1.0751	1.2449
19	1.6598	1.5655	1.166	1.3957	1.3392	1.2826	1.4901
20	1.6598	1.5466	1.3032	1.4712	1.4146	1.3957	1.5466
21	1.5655	1.4335	1.2003	1.358	1.3203	1.3203	1.4335
22	1.5466	1.4523	1.2174	1.358	1.3014	1.2826	1.3769
23	1.4146	1.4146	1.1317	1.2637	1.2449	1.2449	1.3014
24	1.0631	1.2637	1.2449	.9774	1.1317	1.094	1.1128
Max	1.6598	1.5655	1.3032	1.5089	1.4146	1.3957	1.5466
Min	.823	.1509	.8916	.8573	.8865	.8488	.8488
Avg	1.1237	1.1741	1.1392	1.1235	1.1293	1.0407	1.1608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 202 / 11 KV FRUIT MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.132	.132	.1029	.132	.1132	.1132
2	.0857	.1132	.1132	.0857	.1132	.1132	.1132
3	.0857	.1132	.1132	.0857	.1132	.1132	.1132
4	.0857	.1132	.1132	.0857	.1132	.1132	.1132
5	.0857	.1132	.1132	.0857	.1132	.1132	.1132
6	.0857	.0943	.1132	.0857	.1132	.1132	.0943
7	.0686	.0754	.0754	.0754	.0943	.0754	.0943
8	.0686	.0754	.0754	.0754	.0943	.0754	.0754
9	.0943	.0943	.1029	.0754	.0943	.0754	.0943
10	.1132	.0943	.12	.1509	.1509	.0943	.1132
11		.132	.1372	.1698	.1509	.132	.1509
12		.1698	.12	.1698	.132	.1509	.132
13		.1698	.1372	.1509	.132	.1132	.1509
14	.0943	.1132	.1372	.1886	.1698	.132	.1698
15	.1509	.1509	.1372	.1509	.1886	.1509	.1886
16	.1509	.1509	.1372	.1698	.1886	.132	.2075
17	.132	.1509	.1372	.132	.1698	.1509	.1886
18	.132	.132	.1372	.1509	.1698	.1132	.1886
19	.132	.1886	.1372	.1509	.1698	.1509	.1698
20	.1886	.1886	.12	.1886	.1886	.1698	.1886
21	.1698	.1886	.1372	.1698	.1698	.1698	.1698
22	.1698	.1886	.1543	.1698	.1509	.1698	.1698
23	.1698	.1698	.1372	.1509	.1509	.1509	.1509
24	.1029	.132	.132	.1372	.132	.1132	.132
Max	.1886	.1886	.1543	.1886	.1886	.1698	.2075
Min	.0686	.0754	.0754	.0754	.0943	.0754	.0754
Avg	.1176	.1352	.1238	.1316	.1415	.1250	.1415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 402 / 33KV SHERINALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2922	3.5648	3.7346	2.8807	3.7912	3.6214	3.7912
2	3.2407	3.4517	3.5648	2.8807	3.678	3.5082	3.7346
3	3.2407	3.3951	3.5648	2.8807	3.6214	3.5082	3.7346
4	3.2407	3.3951	3.5648	2.8807	3.6214	3.5082	3.678
5	3.1893	3.3951	3.5648	2.8807	3.6214	3.5082	3.678
6	3.0864	3.1687	3.5648	2.8292	2.037	3.3951	3.7912
7	2.8807	3.1687	3.3951	3.0556		3.2819	3.5082
8	2.8292	3.2253	3.2253	2.8858	3.2253	3.2253	3.3385
9	2.9424	3.5648	3.035	2.8292	3.5648	3.4517	3.7346
10	3.2253	4.1307	3.7037	3.0556	3.3951	3.5082	4.0741
11		4.3004	4.3724	3.678	4.0741	3.9609	4.6399
12		4.6399	4.1667	3.9043	3.9609	3.9609	4.4702
13		4.1872	4.1667	3.7346	3.8477	4.2438	4.357
14	3.6214	4.5833	4.1667	3.8477	3.678	4.1872	4.1307
15	4.1307	4.4136	4.0638	3.9609	4.4136	4.2438	4.5833
16	4.0175	4.5833	4.321	3.7346	4.5268	4.4702	4.6965
17	4.0175	4.1872	4.2696	2.5463	4.4136	4.4136	4.5268
18	3.5648	4.4136		2.9424	4.4136	4.3004	4.4702
19	4.357	4.8663	.4115	3.6214	4.4702	4.7531	4.9228
20	4.7531	5.036	3.2407	3.9609	4.8663	5.1578	5.036
21	4.357	4.5268	2.6235	4.9228	4.3004	4.4702	4.6965
22	4.3004	4.5833	3.2407	4.5268	4.2438	4.6965	4.5268
23	4.1872	4.4136	3.4979	4.4702	4.3004	4.5268	4.6965
24	3.5494	3.7912	4.1872	3.1379	4.0175	3.8477	3.9609
Max	4.7531	5.036	4.3724	4.9228	4.8663	5.1578	5.036
Min	2.8292	3.1687	.4115	2.5463	2.037	3.2253	3.3385
Avg	3.6202	4.0411	3.5498	3.4187	3.9166	3.9896	4.1990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 201 / 11 KV Government Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.7207	.8048	.7207	.7023	.6653	.6653
2	.7282	.6653	.7762	.6653	.7023	.6099	.6653
3	.7095	.6099	.7762	.6653	.7095	.6099	.6535
4	.6908	.6099	.7577	.6653	.6908	.6099	.6535
5	.6722	.6099	.7392	.6653	.6908	.6099	.6348
6	.6535	.6283	.7392	.6653	.5601	.5914	.6348
7	.6348	.6653	.6722	.6283	.4668	.5544	.6161
8	.5788	.6099	.6161	.5914	.4527	.5544	.5788
9	.5175	.5359	.5975	.5359	.679	.499	.547
10	.5359	.5359		.5175	.547	.5359	.5359
11	.499	.5544		.5175	.5093	.5359	.5415
12	.4805	.5544		.4805	.5093	.5175	.5415
13	.5175	.5359		.4805	.4715	.4805	.5228
14	.5175	.5544		.5544	.5093	.5544	.5359
15	.5359	.5359		.5914	.5093	.5729	.5601
16	.5544	.5914			.5281	.5359	.5544
17	.5175	.5729	.5544		.5281	.5487	.5415
18	.5175	.5914			.5175	.5373	.5415
19	.695	.7164	.9671		.5729	.6984	.6697
20	.8326	.8596	.8596		.7421	.8145	.8417
21	.8326	.8869	.8596	.9979	.8688	.823	.8417
22	.8145	.9231	.8596	.8962	.8688	.8501	.8417
23	.8326	.9145	.7964	.8048	.8048	.8131	.8145
24	.7947	.7682	.7682	.7316	.8686	.7133	.7207
Max	.8326	.9231	.9671	.9979	.8688	.8501	.8417
Min	.4805	.5359	.5544	.4805	.4527	.4805	.5228
Avg	.6418	.6563	.759	.6513	.6254	.6181	.6356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 202 / 11 KV Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499	.5041	.5359	.499	.4805	.4435	.462
2	.499	.4481	.5175	.4481	.4668	.4481	.4435
3	.4854	.4481	.5228	.4481	.4481	.4481	.4481
4	.4854	.4481	.5041	.4481	.4294	.4481	.4294
5	.4854	.4481	.4854	.4481	.4294	.4108	.4294
6	.4668	.4251	.5228	.4294	.3734	.4108	.3921
7	.4294	.4251	.4854	.3921	.3734	.3921	.3921
8	.4294	.3881	.4294	.3921	.415	.3921	.3734
9	.4066	.3881	.4435	.4108	.415	.3921	.415
10	.4251	.462		.4481	.3961	.3921	.3881
11	.3881	.3881		.4108	.3961	.4108	.4024
12	.4066	.4251		.3921	.3961	.4481	.4066
13	.462	.4066		.4108	.3961	.4481	.4024
14	.5175	.4066		.4108	.3772	.4481	.3881
15	.4805	.499		.4108	.3961	.4668	
16	.4251	.462			.3961	.3921	.4066
17	.4435	.4251	.499		.3772	.3881	.3841
18	.3881	.462			.3734	.3841	.4066
19	.5544	.6516	.7316		.462	.591	.5544
20	.6219	.6697	.6767		.567	.6335	.6468
21	.6767	.6697	.6584	.7023	.6401	.6584	.6653
22	.6767	.6584	.6584	.695	.6401	.6468	.6653
23	.6401	.7207	.6036	.6401	.6036	.6468	.6099
24	.5544	.5304	.5914	.5175	.5175	.499	.5175
Max	.6767	.7207	.7316	.7023	.6401	.6584	.6653
Min	.3881	.3881	.4294	.3921	.3734	.3841	.3734
Avg	.4936	.4900	.5541	.4713	.4486	.4683	.4621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 205 / 11 KV CENTRAL BUILDING

SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.6161	.6283
2		.6161	.6283
3		.6161	.6161
4		.6161	.6161
5		.6161	.6161
6		.6653	.6908
7		.7023	.7468
8		.8131	.7762
9		.9055	.924
10		.9979	
11	.8686	1.1273	
12	.9055	1.1458	
13	.9795	1.0719	
14	.961	1.1273	
15	1.0164	1.2567	
16		1.1827	
17	.8686	1.0164	1.1643
18	.7577	.7947	
19	.7577	.7499	
20	.7947	.7682	
21	.7392	.7316	
22	.7023	.7499	
23	.7392	.7577	
24		.6653	.6653
Max	1.0164	1.2567	1.1643
Min	.7023	.6161	.6161
Avg	.8409	.8463	.7338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 201 / 11 KV Doordarshan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9412	.9412	1.0534	1.0679	.8871	.7577	.8326
2	.8779	.8688	1.0164	.9412	.8131	.6838	.7602
3	.8048	.7964	.924	.8688	.8048	.7207	.7059
4	.7682	.7602	.8686	.7316	.7316	.7023	.6838
5	.7316	.7316	.8131	.7316	.7133	.7023	.6838
6	.7316	.7602	.7762	.7316	.695	.7023	.7282
7	.724	.7602	.7602	.6767	.7316	.6878	.7468
8	.6805	.7164	.7522	.6584	.6767	.6697	.7282
9	.6805		.7164	.6984	.6767	.7421	.7282
10	.6661	.7602	.7164	.7265	.7265	.6878	.788
11		.6984	.6447	.7087	.6556	.6154	.6984
12		.724	.788	.6379	.6733	.6516	.7164
13		.6154	.7164	.6984	.7343	.6516	.7343
14	.7619		.7522	.7701	.7059	.7059	.7421
15	.9412	.6154	.8238	.7701	.7421	.724	.724
16	.8507		.8059	.7343	.7059	.724	.6767
17	.7602	.7602	.7964	.7701	.6878	.724	.6767
18	.7602	.7343		.6878	.6878	.6878	.7602
19	.8954	.8682	1.0808	.9231	.8238		.8869
20	.9671	.9412	.9955		.8326		.9593
21	.9671	.9955	.5973	.9774	.9231	1.0498	.9955
22	1.0924	1.1403	1.0498	.9955	.9593	1.0498	1.086
23	1.0745	1.2197	1.4266	.9795	.9795	1.0136	1.0498
24	1.0136	1.0387	1.1088	1.3032	.961	.8316	.9774
Max	1.0924	1.2197	1.4266	1.3032	.9795	1.0498	1.086
Min	.6661	.6154	.5973	.6379	.6556	.6154	.6767
Avg	.8424	.8308	.8688	.8169	.7720	.7493	.7946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 202 / 11 KV WALCHAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584		.6653	.6099	.5914	.6838
2	.5914		.6653	.5544	.5544	.6653
3	.5914		.6468	.5544	.5544	.6283
4	.5914		.6468	.5544	.5544	.5914
5	.6283		.6099	.5788	.5544	.5914
6	.5914		.6535	.044	.5544	.6535
7	.695		.6535		.6584	.7282
8	.695		.6161		.5487	.7095
9	.6878		.9709	.9522	.5487	.7577
10	.7619		1.0608	.905	.5914	.9145
11			1.1706	.8688	.5544	.9511
12	.0168		.9145	.8775	.5853	.9877
13	.0168		1.0974	.8775	.5121	.9877
14			1.0608	.8775	.5853	.961
15			.9145	.8417	.6219	1.1273
16			.9877	.8417	.4755	1.0349
17			.6722	.7522	.5121	.8871
18			.7762	.5853		.7842
19		.6722	.7655	.5853	.6468	.7842
20		.7762	.6348	.7316	.6099	.8402
21		.7023	.5121	.695	.8417	.8215
22		.7207	.7316	.6584	.8059	.7468
23		.7023	.6838	.5914	.7207	.7023
24	.695		.6653	.6283	.5914	.7023
Max	.7619	.7762	1.1706	.9522	.8417	1.1273
Min	.0168	.6722	.5121	.044	.4755	.5914
Avg	.5554	.7147	.7823	.6893	.5989	.8017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 203 / 11 KV VISHRAMBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9909	2.0633	2.2497	1.7193	1.8656	1.6644	1.5893
2	1.9022	1.9204	2.1399	1.7193	1.8107	1.5912	1.4969
3	1.8107	1.8656	2.0302	1.6297	1.7558	1.5912	1.423
4	1.7558	1.8107	1.9204	1.6644	1.7558	1.5364	1.3491
5	1.701	1.7558	1.8107	1.6461	1.6278	1.4969	1.363
6	1.701	1.6461	1.7558	1.4998	1.4266	1.4415	1.419
7	1.5746	1.6289	1.6832	1.6095	1.4415	1.4266	1.4563
8	1.6108	1.5746	1.6118	1.701	1.4415	1.4266	1.363
9	1.5746	1.5203	1.6655	1.5729	1.4003	1.3717	1.46
10	1.2851	1.701	1.8267	1.6476	1.4449	1.4118	1.647
11	1.9004	1.7918	1.9879	1.9022	1.6461	1.448	1.6651
12	1.7737	1.9204	1.9342	1.8839	1.6278	1.3535	1.8461
13	1.7918	1.8656	1.8804	1.9753	1.7375	1.4998	1.7918
14	1.8107		2.0416	1.9022	1.7194	1.4449	1.7375
15	1.8656		2.0416	2.0485	1.7013	1.5729	1.7924
16	1.8656		2.0416	1.9753	1.7556	1.5729	1.848
17		1.885	2.1176	1.8656	1.6461	1.6278	1.885
18	1.9547	1.8656		2.0851	1.7741	1.4266	1.8296
19	2.1719	2.1176	1.5746		2.0485	1.9728	2.2177
20	2.2805	2.4143	1.8804	3.0445	2.2218	2.0633	2.4394
21	2.1719	2.3102	1.7909	2.0452	1.9728	1.8099	2.1253
22	2.3529	2.4143	1.6655	2.0668	2.009	1.9204	2.1437
23	2.3891	2.524	1.7909	2.1216	2.0485	1.957	2.0485
24	2.1719	2.2262	2.3594	1.6655	1.957	1.8839	1.7926
Max	2.3891	2.524	2.3594	3.0445	2.2218	2.0633	2.4394
Min	1.2851	1.5203	1.5746	1.4998	1.4003	1.3535	1.3491
Avg	1.8873	1.9439	1.9044	1.8692	1.7432	1.6047	1.7387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 206 / 11 KV DATTANAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.8238	.8779	.7164	.7682	.7392	.6878
2	.7682	.8215	.8048	.6805	.7316	.7023	.6516
3	.7316	.724	.7316	.6447	.7316	.6653	.5973
4	.695	.6878	.7316	.6268	.6878	.6283	.5853
5	.695	.695	.7316	.6335	.6516	.6283	.5853
6	.695	.7602	.7682	.6335	.5611	.6348	.6099
7	.6878	.7602	.7522	.6335	.6335	.6089	.6468
8	.6089	.6447	.7442	.5973	.5792	.5731	.6099
9	.6089	.6089	.6733	.4887	.5249	.5014	.5544
10	.5959	.5847	.7087	.4908	.4961	.5373	.4961
11	.5784	.5847	.567	.567	.4607	.5373	.5316
12	.5258	.5792	.567	.5316	.4961	.5373	.567
13	.5316	.5792	.6379	.5316	.443	.5014	.4961
14	.5792		.6024	.567	.543	.5373	.5014
15	.5792		.6447	.567	.5068	.5731	.5731
16	.6154		.6805	.6024	.543	.5731	.5792
17	.5973	.5973	.6584	.5609	.5068	.5373	.5792
18	.5792	.6024		1.2934	.4961	.5014	.5258
19	.7522	.7628	.8669	1.4352	.6588	.7362	.7712
20	.8238	.8764	.788	1.6478	.7796	.8059	.8589
21	.8596	.8859	.7701	1.7013	.7602	.7964	.8328
22	.9134	.9568	.8417	.8417	.8326	.7964	.8596
23	.9134	1.0425	.8059	.8413	.8501	.788	.8954
24	.8688	.8596	.9877	.7522	.8048	.7762	.7602
Max	.9134	1.0425	.9877	1.7013	.8501	.8059	.8954
Min	.5258	.5792	.567	.4887	.443	.5014	.4961
Avg	.6947	.7351	.7366	.7744	.6270	.6340	.6398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 201 / 11 KV Madgule AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	1.448	.1629	.2534	.2743	.2507
2	.2743	1.6289	.1612	.2534	.2715	.2507
3	.2715	1.8099	1.5927	.2715	.2743	.2353
4	.2926	2.1948	.1433	.2926	.2534	.2353
5	.2896	2.3777	.1595	.3109	.2561	.3077
6	.2926	2.5606	.1928	.3292	.2896	.2896
7	.2896	3.2922	2.1948	.3258	.2896	.2896
8	2.5339	3.2579	2.4615	.3258	.3109	.2561
9		3.2579	.1417	.3258	.3077	.2896
10		.2534	.3292	.3258	.2926	.2926
11		.2195	2.7435	2.652	3.5665	.2896
12	.2534	.2534		2.5339	3.8409	.2896
13	.2534	.2561		2.7435	3.7104	.2926
14	.2195	.2896		2.7149	3.4389	.2561
15	.2195	.2534			3.6199	.2561
16		.2195			3.5117	.2561
17		.2172		2.7149	3.4751	.2926
18		.2195		2.5339	3.4027	.2926
19		.181		.2896	.2561	.2534
20		.2195		.2896	.2561	.2561
21		.2534		.2896	.3292	.2715
22		.2195		.2896	.3258	.2561
23		.2172		.2715	.2865	.2172
24	.2896	1.3575	.181	.2534	.2896	.2865
Max	2.5339	3.2922	2.7435	2.7435	3.8409	.3077
Min	.2195	.181	.1417	.2534	.2534	.2172
Avg	.4424	1.1024	.8720	.9359	1.3804	.2693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 202 / 11 KV Atpadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.2437	1.267	1.2071	1.267	1.1946
2	1.1888	1.2071	1.2437	1.2071	1.262	1.1584
3	1.2071	1.1706	1.2197	1.2254	1.2308	1.134
4	1.1946	1.1584	1.2567	1.2752	1.1888	1.134
5	1.2127	1.2308	1.2803	1.2936	1.1765	1.2071
6	1.262	1.3032	1.3032	1.3306	1.2071	1.2803
7	1.267	1.3756	1.3535	1.3676	1.3032	1.39
8	1.262	1.4118	1.3032	1.39	1.3169	1.448
9		1.448	1.3394	1.4266	1.3213	1.4998
10		1.5364	1.39	1.4449	1.39	1.5203
11		1.5927	1.3969	1.448	1.4449	1.4998
12	1.2437	1.6827		1.4632	1.4842	1.4998
13	1.4266	1.5927		1.448	1.4842	1.4842
14	1.448	1.5364		1.4299	1.4842	1.5203
15	1.4842	1.4842		1.3717	1.4842	1.5203
16		1.5364		1.3756	1.4632	
17		1.7194		1.39	1.4632	1.4998
18		1.6461		1.3937	1.4998	1.5364
19		1.5927		1.3717	1.5364	1.6651
20		1.5729		1.3756	1.5364	1.7558
21		1.5203		1.39	1.4632	1.6651
22		1.4998		1.3575	1.39	1.5729
23		1.448		1.3394	1.3394	1.448
24	1.2489	1.2803	1.3169	1.3169	1.3575	1.2308
Max	1.4842	1.7194	1.3969	1.4632	1.5364	1.7558
Min	1.1888	1.1584	1.2197	1.2071	1.1765	1.134
Avg	1.2796	1.4496	1.3059	1.3600	1.3789	1.4289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 203 / 11 KV Pujarwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0366	.0537	.2172	.2896	.2172
2	.1086	.0366	.0543	.2172	.3109	.1991
3	.1097		.0366	.1991	.3258	.2012
4	.1267	.0362	.0543	.197	.3658	.2012
5	.128	.0362	.0914	.2149	.3982	.2195
6	.1267	.0543	.1267	.2507	.439	.2561
7	.1463	.0724	.1097	.3258	.4525	.2926
8	.1646	.0724	.0905	.3258	.4572	.3258
9		.0724	.0724	.3258	.4525	.3658
10			.0732	.1646	.0732	.2896
11		.2896	.0732	.181	.0732	.2743
12	.2353	.4024		.2012	.0549	.2561
13	.2353	.3258		.181	.0914	.2534
14	.2534	.3658		.181	.0724	.2534
15	.2561	.3982		.1646	.0724	.2896
16		.439		.1448	.0724	.2743
17		.4525		.1463	.0724	.2561
18		.3982		.1267	.0732	.2378
19		.0914		.1463	.0914	.0905
20		.1086		.1448	.0914	.1097
21		.0914		.1463	.0905	.0905
22		.0724		.1448	.0724	.0914
23		.0732			.0724	.0724
24	.1086	.0549	.0543	.2172	.181	.2172
Max	.2561	.4525	.1267	.3258	.4572	.3658
Min	.1086	.0362	.0366	.1267	.0549	.0724
Avg	.1622	.1809	.0742	.1984	.1978	.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 204 / 11 KV Pujarwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.181	.1086	.1433	.181	.2149
2	.1463	.181	.1463	.1075	.2012	.2149
3	.1448	.181	.1448	.1075	.1991	.2149
4	.1646	.181	.1646	.1075	.2012	.2534
5	.1629	.2012	.181	.1448	.1991	.2896
6	.1829	.2195	.1829	.181	.2012	.2896
7	.181	.2195	.1448	.2195	.1991	.2561
8	.181	.2195	.1463	.2195	.2172	.2534
9		.2195	.1448	.2195	.2195	.2172
10	.2172	.181	.1463	.2353	.2195	.2195
11	.2172	.1463	.1463	.2378	.2195	.2195
12	.2172	.1086		.2353	.2172	.2195
13	.2172	.0914		.2378	.2195	.2172
14	.1829	.1086		.2172	.2195	.2172
15	.181	.128		.2195	.2195	.2195
16		.1267		.2172	.2195	.2195
17		.1463		.2012	.2195	.2195
18		.1086		.1991	.2195	.2172
19		.128		.1829		.2561
20		.1448		.181	.2534	.2896
21		.1829		.1829	.2561	.2561
22		.1448		.181	.2561	.2715
23		.1448			.2534	.2926
24	.1448	.181	.1075	.1791	.181	.2172
Max	.2172	.2195	.1829	.2378	.2561	.2926
Min	.1267	.0914	.1075	.1075	.181	.2149
Avg	.1778	.1615	.1470	.1895	.2170	.2398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 205 / 11 KV Madgule Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2172	.2195	.181	.2353	.181
2	.2378	.181	.2587	.1448	.2561	.1629
3	.2534	.1829	.2926	.181	.2715	.1646
4	.2743	.1829	.2896	.1829	.2926	.1646
5	.2896	.2012	.3292	.2012	.2896	.1829
6	.2926	.2195	.3292	.2561	.3109	.2195
7	.3258	.2561	.362	.2534	.3258	.2534
8	.5636	.2561	.3292	.2534	.3292	.2534
9		.2172	.2534	.2172	.3258	.2896
10		.2896	.2561	.2378	.2896	.2507
11		.2561	.2172	.2353	.2534	.2561
12	.2534	.2896		.2378	.2534	.2561
13	.2172			.2353	.2195	.2172
14	.2195	.2561		.2534	.2378	.2172
15	.2172	.2896			.2195	.181
16		.2896			.2172	
17		.2561		.2534	.2172	.181
18		.2172		.2534	.2172	.2172
19		.2561		.2353	.2926	.2926
20		.2534		.2378	.2926	.2896
21		.2195		.2561	.2896	.2561
22		.2534		.2534	.2534	.2534
23		.2195		.2353	.2534	.2926
24	.2534	.2534	.2172	.2172	.2353	.2172
Max	.5636	.2896	.362	.2561	.3292	.2926
Min	.2172	.181	.2172	.1448	.2172	.1629
Avg	.2795	.2397	.2795	.2278	.2658	.2283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 206 / 11 KV Atpadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.181	.181	1.3717	1.448	1.3169
2	.1629	.1448	.2195	1.4266	1.6461	1.2803
3	.1629	.1463	.2172	1.448	1.8099	1.3394
4	.1646	1.4632	.2534	2.0814	2.5606	1.4842
5	.181	.1829	.2865	2.0814	2.5339	1.5546
6	.1829	.181	.2865	2.3529	2.652	1.829
7	.181	.2172	.2353	2.9264	2.7149	1.9387
8	.181	.2172	.1829	3.1093	2.7618	1.9004
9		.2172	.181	2.8898	2.733	1.9753
10		.2195	.1829	.1629	2.1719	.2172
11		1.9547	.1829	.1646	.2172	2.3529
12	1.086	2.1948		.181	.2195	2.4508
13	1.8099	2.0814		.1829	.2172	2.3891
14	1.9004	1.9204		.1829	.2172	2.3529
15	1.9004	1.9909		.181	.2172	2.4434
16		2.0485		.1829	.2195	2.5606
17		2.3891		.181	.2195	2.652
18		1.3169		.181	.2012	2.5972
19		.2534		.1646	2.2986	.2896
20		.2561		.1629	.2172	.3258
21		.2353		.1646	.2172	.2926
22		.2195		.1629	.2172	.2715
23		.2172			.2195	.2561
24	.181	.181	.1829	1.2437	1.086	1.1888
Max	1.9004	2.3891	.2865	3.1093	2.7618	2.652
Min	.1629	.1448	.181	.1629	.2012	.2172
Avg	.6353	.8512	.216	1.0081	1.2090	1.5525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 401 / 33 KV Soot Girani

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7692	2.6063	2.8829	2.4977	2.9321	2.7435
2	2.7984	2.6063	2.963	2.4977	2.963	2.7435
3	2.7692	2.6063	2.8532	2.3891	2.9321	2.6337
4	2.7435	2.7435	2.7149	2.4143	2.8532	2.6612
5	2.7149	2.7435	2.8532	2.3045	2.8235	2.8829
6	2.6886	2.7435	2.7149	2.1948	2.9081	2.8829
7	2.6063	2.8532	2.6063	2.2805	2.8778	2.7435
8	2.552	2.8532	2.5789	2.3891	2.8532	2.6337
9		2.8532	2.6337	2.6063	2.4977	2.6337
10		1.9547	2.7149	2.963	2.6337	2.2262
11		2.6337	2.7435	3.0407	3.1824	2.4434
12	1.8656	2.9321		3.0178	3.1824	2.7435
13	2.4691	2.8235		2.9864	3.0407	2.8235
14	2.4691	2.6337		2.8778	3.0407	2.9321
15	2.4977	2.7149		2.9081	3.0727	3.0727
16		2.8532		2.8532	2.9321	2.963
17		2.552		2.8235	2.8235	2.8532
18		2.6337		2.8235	2.6063	3.0407
19		2.8235		2.9081	2.6337	2.7435
20		2.7149		2.8778	2.6886	2.2262
21		2.5789		2.963	2.7149	2.3045
22		2.6063		2.9321	2.7435	2.4434
23		2.6337		2.9321	2.7435	2.552
24	2.8778	2.7149	2.7435	2.4977	2.9321	2.7435
Max	2.8778	2.9321	2.963	3.0407	3.1824	3.0727
Min	1.8656	1.9547	2.5789	2.1948	2.4977	2.2262
Avg	2.6016	2.6839	2.7502	2.7075	2.8588	2.6946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 202 / 11 KV Zare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-MAY-18	11-MAY-18
HR	Load (MW)	Load (MW)
1	.6878	.6478
2	.6878	.6478
3	.724	.6802
4	.724	.8097
5	.8869	.8907
6	.5544	1.004
7	.5175	1.2955
8		1.4899
9		1.4575
10	.0895	.081
24	.6878	.6478
Max	.8869	1.4899
Min	.0895	.081
Avg	.6177	.8774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084] BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 203 / 11 KV Zare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	11-MAY-18
HR	Load (MW)	Load (MW)
1	.5175	.4525
2	.5175	.4525
3	.499	.4525
4	.5544	.4525
5	.5544	.5068
6		.543
7		.4887
8		.4887
9		.543
10	.5544	.543
24	.5175	.4525
Max	.5544	.543
Min	.499	.4525
Avg	.5307	.4887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 204 / 11 KV Nelkaranji Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	11-MAY-18
HR	Load (MW)	Load (MW)
1	.1267	.1448
2	.1267	.1448
3	.1267	.1448
4	.1267	.1448
5	.1267	.1448
6		.1448
7		.1448
8		.1448
9		.1448
10	.1267	.1448
24	.1267	.1448
Max	.1267	.1448
Min	.1267	.1448
Avg	.1267	.1448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 205 / 11 KV Mitaki AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-MAY-18	11-MAY-18
HR	Load (MW)	Load (MW)
1	.0895	.1086
2	.0895	.1086
3	.0895	.1086
4	.0895	.0905
5	.0895	.0905
6		.0905
7		.0905
8		.0905
9		.0905
10		.0905
24	.1075	.1267
Max	.1075	.1267
Min	.0895	.0905
Avg	.0925	.0987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 206 / 11 KV Walvan AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-MAY-18	11-MAY-18
HR	Load (MW)	Load (MW)
1	.6249	.5668
2	.6249	.5668
3	.6249	.7287
4	.6249	.7773
5	.6562	.7773
6		.8259
7		1.1336
8		1.3279
9		1.2955
10		.081
24	.5468	.4858
Max	.6562	1.3279
Min	.5468	.081
Avg	.6171	.7788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11 KV Zare (Zare) AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.3913	.3479	.3953	.197	.1402	.181
2	.3953	.3963	.3521	.3906	.197	.1433	.1646
3	.3563	.4321	.3749	.4161	.181	.1417	.1646
4	.426	.4687	.5218	.4372	.181	.124	.2218
5	.5401	.8488	.68	.5401	.2126	.1402	.2614
6	.703	1.0822	1.0562	.703	.2279	.1753	.2801
7	1.6804	1.1574	1.4373	1.1111	.2865		.2534
8	1.5729	1.358	1.4217	.9374	.2715	.1372	.1772
9	1.0105	1.2431	1.186	.9877	.1772	.1578	.1753
10		.1772	.1875	.1562	.1886	.16	.1791
11	.1753	.1772	.2561	1.0623	1.1279	1.0911	.1417
12	.1802	.1753	.2126	1.1265	1.1728	1.2163	.1402
13	.1715	.1227	.2172	1.2342	1.0987	1.2809	.1402
14	.1595	.124	.1829	1.1702	1.0669	1.1873	.1372
15	.1753	.124	.1867	1.0385	.9957	1.0957	.1372
16	.1907	.124	.2263	.9755	1.0105	1.0837	.1696
17	.1848	.2035	.1829	.9105	1.0669	1.3904	.2058
18	.2195	.2286	.208	.945	1.0936	1.1279	.1715
19	.3077	.2715	.2454	.2172	.1753	.2454	.2149
20	.2926	.3292	.2713	.2926	.1753	.3326	.2172
21	.2743	.2926	.2835	.2561	.1734	.2957	.2149
22	.2534	.2614	.2195	.2402	.1715	.2587	.1791
23	.2353	.1829	.2561	.2195	.1753	.2195	.1433
24	.3658	.3658	.3163	.4108	.2172	.1753	.181
Max	1.6804	1.358	1.4373	1.2342	1.1728	1.3904	.2801
Min	.1595	.1227	.1829	.1562	.1715	.124	.1372
Avg	.4470	.4391	.4513	.6739	.4934	.5357	.1855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / Vibhutwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.1097	.0905	.0895	.1254	.1227	.1097
2	.0914	.0905	.0905	.0905	.1063	.1063	.0905
3	.0886	.0716	.0905	.0732	.0876	.1052	.0905
4	.0905	.0716	.1097	.0924	.0709	.1052	.128
5	.0914	.0905	.128	.0914	.1075	.1387	.1463
6	.1772	.1646	.1663	.1886	.1646	.1372	.1867
7	.2012	.1478	.1463	.181	.1448	.1417	.1663
8	.1772	.128	.0905	.1829	.1433	.1227	.1227
9	.1174	.1254	.1097	.1629	.112	.1254	.1417
10		.124	.1267	.1433	.0867	.1417	.1433
11	.1187	.1402	.1267	.1433	.0886	.1417	.1417
12	.1187	.1402	.128	.1448	.1052	.1402	.1417
13	.12	.1227	.1357	.1433	.1017	.1595	.1595
14	.104	.124	.1187	.1417	.1029	.1387	.1402
15	.1029	.1402	.125	.1433	.1052	.1402	.1387
16	.1029	.1402	.124	.1267	.1267	.124	.1715
17	.1227	.0857	.1448	.1063	.1254	.1029	.1715
18	.1433	.1311	.1097	.1075	.1254	.0848	.1753
19	.181	.1402	.168	.1629	.1254	.1052	.1791
20	.181	.181	.1829	.1829	.1448	.1463	.2172
21	.1646	.1646	.1867	.1848	.1448	.1294	.2172
22	.1448	.1294	.2075		.1433	.112	.1791
23	.1267	.1097	.181	.1448	.1267	.1086	.1791
24	.112	.1086	.0914	.1063	.1433	.1254	.1097
Max	.2012	.181	.2075	.1886	.1646	.1595	.2172
Min	.0819	.0716	.0905	.0732	.0709	.0848	.0905
Avg	.1287	.1242	.1325	.1363	.1191	.1252	.1520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1334	.1017	.1097	1.1142	1.0059	1.2407
2	.0886	.1143	.0857	.1097	1.1934	.9221	1.1934
3	.0724	.1143	.0857	.1086	1.2266	.9221	1.1603
4	.0732	.0953	.1017	.1063	1.2944	.8383	1.2407
5	.0886	.1143	.1187	.1448	1.5223	.9945	1.3413
6	.1086	.1715	.1341	.1463	1.8023	1.8233	1.5592
7	.1772	.1715	.2254	.1772	2.4034	1.989	1.7901
8	.1448	.1524	.1829	.1791	2.3102	2.2377	1.861
9	.1433	.1524	.1417	.1715	2.1548	2.6482	1.8233
10		.1524	.1296	.1524		.1524	.1753
11	1.6129	1.8442	1.1469	.1524	.1448	.1524	1.6766
12	1.8679	1.9281	1.8442	.1524	.1417	.1715	1.6766
13	2.0885	1.6575	2.1948	.1524	.1478	.1524	1.7604
14	2.2131	1.0059	2.198	.1524	.1463	.1524	1.8233
15	2.13	2.1548	2.2653	.1334	.1629	.1334	2.0119
16	2.146	2.0957	2.3739	.1334	.1448	.1334	1.8233
17	2.0553	2.0119	1.8442	.1334	.1448	.124	1.6766
18	1.9334	1.9334	1.656	.1334	.1448	.1494	1.6766
19	.1715	.1772	.1543	.1524	.1448	.2075	.1753
20	.1905	.176	.1478	.1905	.1433	.2427	.1791
21	.1905	.1696	.1867	.1905	.1267	.2012	.181
22	.1715	.1357	.1991	.1715	.1254	.1928	.1433
23	.1524	.1187	.1646	.1524	.1254	.1578	.1433
24	.1905	.1334	.1006	.112	.9069	1.0059	1.2039
Max	2.2131	2.1548	2.3739	.1905	2.4034	2.6482	2.0119
Min	.0724	.0953	.0857	.1063	.1254	.124	.1433
Avg	.7870	.7047	.7410	.1466	.7727	.6963	1.2307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 201 / 11 KV Hivtad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829		.1867	.1629		1.0242	1.0745
2	.1829		.1867	.1612		1.0242	1.0631
3	.1848		.1886	.1448		1.0402	1.0631
4	.2054		.2263	.1433		1.1336	1.1919
5	.2241		.2263	.1595		1.4091	1.3176
6	.2614		.2427	.1928		1.5912	2.0576
7	.2241		.2126	.1772		2.652	2.3868
8			.1753	.1578		3.0498	2.652
9				.1417			3.1786
10					2.1948	.1886	.1619
11		2.0481	2.1052		.1715	.1791	2.1628
12		2.13	2.4006		.1267	.2012	2.2939
13		2.1862	2.4905		.1463	.1791	2.5911
14		2.2939	2.5263		.1372	.1646	2.6886
15		2.2283	2.652		.12	.1448	2.8178
16		2.4577	2.4539		.12	.1646	2.7206
17		2.2377	2.0805		.1357	.1478	2.652
18		2.6578	1.2963		.1677	.1341	
19		.2303	.2058		.2229	.2229	.2229
20		.2195	.2103		.2534	.2507	.2149
21			.2126			.2328	.1867
22			.1991			.2172	.2195
23			.2012			.1829	.2012
24	.2033		.1867	.181		1.0242	
Max	.2614	2.6578	2.652	.1928	2.1948	3.0498	3.1786
Min	.1829	.2195	.1753	.1417	.12	.1341	.1619
Avg	.2086	1.8690	.9485	.1622	.3451	.7200	1.5963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 202 / 11 KV Shetphale AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.4801	.5609		.2402	.2172
2	.5601	.4801	.5548		.2378	.2172
3	.5668	.4858	.7164		.2402	.2195
4	.6802	.6802	.8048		.2801	.1991
5	.8848	.9393	.8596		.2987	.2195
6	1.1105	1.065	1.0402		.3395	.3174
7	1.2266	1.3603	1.1203		.3174	.3018
8		1.1203	1.2452		.2427	.2743
9			1.1603			.2534
10				.1829	.1791	.2149
11		.2427		1.4089	1.4403	.2012
12		.208		1.3108	1.4899	.1991
13		.2172		1.2616	1.5043	.2149
14		.2012		1.2146	1.5546	
15		.1848		1.1069	1.6057	
16		.2195		1.3108	1.5223	
17		.2353		1.2146	1.4746	.2058
18		.2772		1.1683	.3086	.2454
19		.2926		.3258	.3086	.2865
20		.3077		.3326	.3155	.3658
21		.2865			.2865	.3121
22		.2561				.2686
23		.2195			.2743	.2401
24	.4111	.4801	.5731		.2402	.2195
Max	1.2266	1.3603	1.2452	1.4089	1.6057	.3658
Min	.4111	.1848	.5548	.1829	.1791	.1991
Avg	.7440	.4654	.8636	.9853	.6682	.2473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 203 / 11 KV Banpuri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6009	.4481	.5144		.128	.1629
2	.5601	.4481	.5201		.128	.1646
3	.5601	.4588	.6805		.128	.1612
4	.6802	.6464	.7682		.168	.1772
5	.9175	.8192	.8326		.1867	.1791
6	1.278	1.1797	.9175		.2427	.2957
7	1.4586	1.5061	1.0212		.2772	.2614
8		1.6385	1.3032		.1829	.208
9			1.2955			.1791
10				.1619	.128	.1646
11		.1907		1.3108	1.5402	.128
12		.1753		1.3927	1.6194	.1311
13		.1612		1.4419	1.704	.1147
14		.1463		1.3765	1.7166	.1357
15		.1448		1.2955	1.7204	.1543
16		.1463		1.326	1.6518	.1387
17		.1612		1.3108	1.6385	.1341
18		.168		1.1336	1.5581	.1257
19		.2378		.2254	.2229	.1486
20		.2534		.2561	.2401	
21		.2149			.208	.1463
22		.1829			.2103	.1463
23		.1663			.1791	.1524
24	.6009	.4481	.5487		.128	.1612
Max	1.4586	1.6385	1.3032	1.4419	1.7204	.2957
Min	.5601	.1448	.5144	.1619	.128	.1147
Avg	.8320	.4519	.8402	1.0210	.6916	.1640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 205 / 11 KV Shetphale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3361	.3403		.3361	.3224
2	.3361	.3395	.3475		.3361	.3292
3	.3395	.3395	.3467		.3361	.3258
4	.3772	.415	.3224		.3772	.3109
5	.4338	.4715	.3012		.4715	.362
6	.5228	.547	.4706		.5281	.4656
7	.4435	.4435	.4481		.4108	.4481
8		.3326	.4024		.3696	.4207
9			.3696			.3982
10				.1829	.2881	.3582
11		.2865		.3142	.333	.3403
12		.2896		.3292	.3258	.3467
13		.3224		.3077	.3475	.394
14		.3439		.3475	.3439	.3841
15		.3475		.3292	.3292	.3403
16		.362		.3439	.3439	.3294
17		.3658		.3403	.3326	.3582
18		.4572		.3544	.3258	.3898
19		.543		.543	.5487	.5731
20		.6219		.6219	.6219	.5792
21		.5068			.5068	.5373
22		.4298			.394	.4656
23		.4024			.3658	.4024
24	.3734	.3361	.3403		.3361	.3258
Max	.5228	.6219	.4706	.6219	.6219	.5792
Min	.3361	.2865	.3012	.1829	.2881	.3109
Avg	.3953	.4018	.3689	.3649	.3873	.3961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 206 / 11 KV Banpuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.1217	.1402		.1132	.1475
2	.1433	.1217	.1387		.1132	.144
3	.1448	.1217	.1475		.1132	.1406
4	.1646	.1429	.128		.1296	.1524
5	.1829	.1882	.1067		.16	.1219
6	.2218	.1932	.1738		.1698	.1718
7	.2218	.1509	.1276		.141	.176
8		.12	.1115		.1829	.1467
9			.1097			.1417
10				.0914	.1067	.1257
11		.084		.1029	.128	.1212
12		.0945		.1029	.0808	.1315
13		.093		.1029	.0914	.1341
14		.0854		.1132	.0945	.1486
15		.0934		.1257	.1097	.1299
16		.112		.12	.1115	.1372
17		.1311		.1063	.1021	.1143
18		.1492		.1299	.1115	.1562
19		.2058		.1486	.1684	.2229
20		.208		.1659	.1734	.2507
21		.2149			.1646	.2303
22		.2012			.16	.2149
23		.1829			.141	.1848
24	.181	.1217	.1433		.1132	.1303
Max	.2218	.2149	.1738	.1659	.1829	.2507
Min	.1433	.084	.1067	.0914	.0808	.1143
Avg	.1777	.1426	.1327	.1191	.1296	.1573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 207 / 11 KV GOMEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701		.0549			.4801	.4801
2	.0701		.0549			.4801	.4908
3	.0709		.0549			.4858	.4961
4	.0895		.0554			.6554	.6089
5	.1097		.0724			.7773	.695
6	.1494		.1063			.9175	.7712
7	.132		.0732			1.0814	.9465
8			.0732			1.166	1.0288
9							1.1096
10					.0549	.0838	.0895
11		1.0111	1.0242		.0732	.0701	1.0174
12		1.1469	1.267		.0732	.0924	1.0898
13		1.1336	1.283		.0732	.0732	1.153
14		1.2146	1.2269		.0732	.0905	***
15		1.1633	1.3432		.0739	.0716	1.2483
16		1.1069	1.4685		.0732	.0732	1.2269
17		1.094	1.6461		.0549	.0554	1.0562
18		1.0159	1.4255		.112	.0554	.9259
19		.128	.1372		.1478	.1463	.12
20		.1646	.1387		.1448	.1478	.1612
21			.1086			.128	.1463
22						.1075	.0895
23			.0914			.1097	.0724
24	.0886		.0549	.0566		.4801	.4801
Max	.1494	1.2146	1.6461	.0566	.1478	1.166	12.1399
Min	.0701	.128	.0549	.0566	.0549	.0554	.0724
Avg	.0975	.9179	.5600	.0566	.0868	.3404	1.1518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 201 / 11 KV Palaskhel

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0808	1.1393	1.0985	.8869	.1143	.1524	.1524
2	1.1517	1.1999	1.1218	.8775	.1143	.1524	.1524
3	1.1584	1.1616	1.1218	.8682	.0953	.1334	.1524
4	1.1096	1.1789	1.1641	.9214	.0953	.1334	.1715
5	1.2357	1.4752	1.2483	1.0867	.1143	.1524	.1715
6	1.829	1.97	1.7375	1.379	.1334	.1905	.1715
7	1.9982	1.56	1.8427	1.5769	.1524	.1905	.1905
8		1.8229	1.5581	1.6476	.1524	.1905	.1905
9		1.7661	1.7375	1.773	.1524	.1524	.1715
10		.1334	.1715	.1334	.1143	.1524	.1715
11		.0953	.1334	1.3432	1.6655	1.6827	.1524
12		.0953	.1143	1.6301	1.7684	2.0748	.1524
13		.1143	.1143	1.6834	1.8519	2.0376	.1715
14		.1334	.1334	1.6301	1.8404	2.0199	.1715
15		.1143	.1143	1.5777	1.7661	1.8378	.1524
16		.1143	.1143	1.5257	1.8073	1.5939	.1524
17		.0953	.1334	1.5249	.1791	1.7528	
18		.1143	.1143	1.4529	1.6651	1.6118	.0953
19	.1334	.1524	.1524	.1334	.1334	.1334	.1334
20	.1715	.1715	.1905	.1524	.1905	.2096	.1905
21	.2096	.1715	.1715	.1715	.1715	.1905	.1905
22	.2096	.1524	.1715	.1715	.1715	.1905	.1715
23	.0762	.1334	.1524	.1334	.1524	.1715	.1524
24	1.0679	1.0343	1.0166	.9134	.1143	.1524	.1524
Max	1.9982	1.97	1.8427	1.773	1.8519	2.0748	.1905
Min	.0762	.0953	.1143	.1334	.0953	.1334	.0953
Avg	.8794	.6708	.6512	1.0498	.6132	.7191	.1624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 202 / 11 KV Rajewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1715	.1524	.1334	1.2403	1.283	1.1641
2	.1143	.1524	.1334	.1334	1.3146	1.386	1.1963
3	.1143	.1524	.1334	.1334	1.4373	1.379	1.2489
4	.1143	.1524	.1143	.1143	1.4506	1.3496	1.2094
5	.1143	.1334	.1334	.1334	1.6124	1.4864	1.3289
6	.1334	.1334	.1524	.1334	1.773	1.5384	1.4043
7	.1334	.1715	.1715	.1524	1.8625	1.7741	1.6476
8		.1334	.1715	.1715	1.773	1.7926	1.6804
9		.1524	.1715	.1715	1.6827	1.8604	1.4706
10		.1524	.1524	.1334	.1334	.1334	.1334
11		1.8204	1.7909	.1143	.1524	.1715	1.5181
12		2.0953	2.0157	.1143	.1334		1.5746
13		1.9982	2.0376	.1334	.1715	.1715	1.5592
14		1.949	1.9281	.1334	.1715	.1715	1.5364
15		1.9313	1.8959	.1334	.1715	.1524	1.491
16		1.9071	1.647	.1334	.1524	.1524	1.5043
17		1.8054	1.7372	.1143	.1524	.1524	1.829
18		1.8959	1.7013	.1334	.1524	.1334	1.5415
19	.1334	.1334	.1334	.1524	.1715	.1524	.1334
20	.2096	.1905	.1715	.1715	.1905	.1524	.1715
21	.1905	.1905	.1715	.1905	.1905	.1524	.1715
22	.1905	.1715	.1715	.1715	.1715	.1334	.1524
23	.1715	.1524	.1524	.1524	.1715	.1334	.1524
24	.1334	.1715	.1524	.1524	1.267	1.2048	.9816
Max	.2096	2.0953	2.0376	.1905	1.8625	1.8604	1.829
Min	.1143	.1334	.1143	.1143	.1334	.1334	.1334
Avg	.1451	.7466	.7164	.1421	.7375	.7399	1.1167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 203 / 11 KV Dhole Mala,
Dighanchi Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7282	.7343	.8417	.6653	.0953	.1334	.1334
2	.7164	.7628	.9055	.6036	.0762	.1334	.1143
3	.7343	.7796	.8962	.5973	.0762	.1143	.1143
4	.6836	.7545	.9511	.6838	.0762	.1143	.1143
5	.7973	1.0029	1.1273	.8676	.0762	.1143	.1143
6	1.2437	1.4217	1.5684	1.1104	.0953	.1524	.1334
7	1.4175	1.0136	1.6263	1.3213	.1143	.1715	.1715
8		1.2656	1.262	1.4266	.1143	.1524	.1524
9		1.3213	1.4784	1.5339	.1143	.1524	.1524
10		.1143	.1334	.1143	.0953	.1524	.1524
11		.0762	.1143	1.0791	1.2309	1.1789	.1524
12		.0762	.0953	1.4045	1.3394	1.4864	.1524
13		.0953	.0953	1.4449	1.3146	1.4022	.1524
14		.1143	.1143	1.423	1.3032	1.3146	.1524
15		.0953	.0953	1.4003	1.3289	1.3611	.1334
16		.0953	.0953	1.3306	1.2483	1.2048	.1334
17		.0762	.0953	1.3443	1.3643	1.2489	.0953
18		.1143	.0762	1.2567	1.166	1.1043	.1143
19		.1143	.1143	.1143	.0953	.1334	.1143
20	.1715	.1334	.1143	.1143	.1715	.1715	.1524
21	.1524	.1334	.1143	.1143	.1524	.1524	.1334
22	.1524	.1143	.0953	.1143	.1524	.1524	.1524
23	.1334	.0953	.1143	.0953	.1524	.1524	.1524
24	.6733	.6661	.8048	.6535	.0953	.1334	.1334
Max	1.4175	1.4217	1.6263	1.5339	1.3643	1.4864	.1715
Min	.1334	.0762	.0762	.0953	.0762	.1143	.0953
Avg	.6337	.4654	.5387	.8672	.5020	.5245	.1365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1387	.1109	.128	.1109	.128	.1294
2	.1052	.124	.1109	.128	.0914	.1052	.1227
3	.1006	.128	.1086		.0924	.112	.1267
4	.0867	.1052	.1097	.1294	.1109	.104	.104
5	.1017	.1006	.128	.1494	.1307	.0924	.1029
6	.1448	.1433	.181	.1848	.168	.1341	.197
7	.168	.1478	.1629	.181	.1478	.1949	.2218
8		.1402	.1612	.1417	.1227	.1478	.1698
9		.1433	.1214	.1227	.1174	.1509	.1402
10		.1417	.12	.1227	.2034	.1254	.1307
11		.1006	.124	.124	.128	.1307	.1086
12		.1017	.1063	.072	.104	.1052	.0857
13		.1227	.1063	.1075	.1075	.0983	.0983
14		.1075	.1075	.1086	.0857	.1075	.124
15		.1086	.0905	.124	.0819	.0886	.1294
16		.0905	.0895	.124	.0724	.1109	.1052
17		.0867	.0876	.1052	.0701	.1052	.1086
18		.1214	.124	.1402	.0543	.0905	.1294
19	.1294	.1578	.1612	.1595	.1109	.104	.1494
20	.2328	.2012	.2033	.1829	.168	.2241	.2353
21	.2829	.197	.1829	.1829	.1886	.2195	.2561
22	.2012	.1663	.1494	.1478	.1829	.1595	.2054
23	.1734	.1294	.1478	.1307	.1478	.1463	.1629
24	.1254	.1629	.128	.1494	.112	.1254	.1254
Max	.2829	.2012	.2033	.1848	.2034	.2241	.2561
Min	.0867	.0867	.0876	.072	.0543	.0886	.0857
Avg	.1524	.1320	.1301	.1368	.1212	.1296	.1445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 201 / 11 KV Kauthuly

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.6827	1.8023	2.0348	.1646	.2103	.2743
2	1.2887	1.7833	1.933	1.9334	.1478	.2058	.2835
3	1.3413	1.7635	1.9006	1.989	.1478	.2058	.2835
4	1.406	1.8991	1.933	2.0153	.168	.2035	.2507
5	1.7857	2.0576	1.9662	2.0576	.2033	.2035	.2572
6	2.1704	2.4691	2.3137	2.4272	.2926	.2713	.2401
7	2.6658		2.8841	3.0803	.3012	.2683	.2561
8	2.5149	3.0849	3.0476	3.1131	.333	.2743	.2507
9		3.2236	1.4918	.2195	.2743		.2172
10			.3258	.2401	.2374	.2865	.1402
11			.2561	2.3472	3.155	2.8807	.1715
12	.2035		.2401	2.3868	3.0864	3.0148	.1696
13	.1357			2.4577	3.1901	3.1161	.1341
14	.1341		.2126	2.5232	3.1901	3.1131	.1341
15	.1326		.2195	2.5692	3.155	2.915	.1526
16	.1326		.2328	2.6825	3.5056	2.6871	.1696
17	.1326		.2561	3.0346	3.5757	3.2217	.1886
18			.2686	3.12	2.9767	3.0178	.1907
19	.2035		.2926	.2743	.2149	.2507	.2279
20	.2743		.2507	.3641	.2804	.2926	.3189
21	.2058		.2896	.333	.362	.2686	.2686
22	.2103		.2561	.3012	.2896	.2534	.2534
23	.1402		.2507	.2149	.2172	.2378	.2353
24		1.4327	1.5912	1.8442	.1829	.2103	.2507
Max	2.6658	3.2236	3.0476	3.12	3.5757	3.2217	.3189
Min	.1326	1.4327	.2126	.2149	.1478	.2035	.1341
Avg	.8571	2.1552	1.0528	1.8151	1.2355	1.2004	.2216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 202 / 11 KV Nimbawade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1753	.1829	.1629	1.4198	1.262	1.326
2	.1357	.1715	.1829	.4207	1.2934	1.3032	.9259
3		.2035	.1578	.1612	1.2048	1.4403	1.406
4		.2035	.1646	.1715	1.3253	1.6278	1.3413
5		.2058	.1791	.1612	1.5769	1.7635	1.3923
6		.2454	.1595	.1753	1.9631	2.3137	1.4419
7			.1543	.1829	1.5604	2.4863	2.0557
8		.2103	.1646	.1646	2.5377	2.7092	2.2634
9		.1433	.1829	.1433	2.4417		2.1956
10			.1791	.1928	.1187	.2035	.1715
11			2.0576	.1543	.1402	.7316	1.9616
12	.9156		2.34	.1696	.1372	.1612	2.1382
13	1.7635		2.4531	.1509	.1402	.1448	2.2211
14	2.3807		2.3594	.1509	.1753	.1646	2.13
15	2.3868		2.4813	.1526	.1715	.1791	2.1628
16	2.5194		2.4905	.1526	.1753	.1772	2.1548
17	2.6189		2.4531	.1526	.1753	.2012	2.0287
18			.213	.1543	.1772	.2172	1.8652
19	.2374		.1715	.1734	.2149	.7602	.1734
20	.2743		.1646	.2103	.2534	.2601	.2454
21	.2401		.1433	.2303	.2534	.1791	.2303
22	.2103		.1595	.2149	.2172	.1907	.197
23	.1753		.1646	.181	.2172	.6859	.181
24	.1734	.1791	.1829	.1646	1.2269	1.1191	1.2548
Max	2.6189	.2454	2.4905	.4207	2.5377	2.7092	2.2634
Min	.1357	.1433	.1433	.1433	.1187	.1448	.1715
Avg	1.0130	.1931	.8143	.1812	.7965	.8818	1.3943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 203 / 11 KV Kauthuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.2804	.2614	.2058	.1294	.1753	.1734
2	.1387	.2743	.2481	.2374	.112	.1753	.1886
3	.1715	.2035	.2229	.218	.112	.1715	.156
4	.1928	.2035	.2427	.2321	.1478	.2058	.1696
5	.1772	.2401	.2686	.2401	.2012	.2743	.2229
6	.2774	.3681	.2743	.2774	.3077	.3601	.2427
7	.2743		.2427	.1886	.1417	.3688	.1865
8	.2915	.362	.2427	.156	.2427	.3772	.1734
9		.3439	.2195	.1791	.2915		.2103
10			.2149	.1578	.2543	.3403	.1715
11			.2481	.1543	.2507	.2915	.1357
12	.1543		.2149	.2572	.2454	.2561	.1844
13	.12		.2303	.2543	.2303	.197	.1658
14	.1187		.2561	.2012	.2303	.2401	.1658
15	.1187		.2149	.2012	.2279	.2254	.1677
16	.1029		.2378	.1696	.1063	.1949	.1844
17	.1029		.2058	.1865	.1063	.2481	.2035
18			.1715	.2058	.1254	.2229	.2401
19	.2454		.1663	.2254	.2172	.2987	.2601
20	.3045		.197	.2629	.3077	.3258	.298
21	.3045		.2058	.2454	.2926	.2947	.3544
22	.3224		.2254	.1949	.2561	.1886	.3403
23	.3224		.1715	.1991	.2195		.3077
24	.1417	.3224	.0274	.1928	.128	.1949	.1715
Max	.3224	.3681	.2743	.2774	.3077	.3772	.3544
Min	.1029	.2035	.0274	.1543	.1063	.1715	.1357
Avg	.2018	.2887	.2171	.2101	.2035	.2558	.2114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 204 / Nimbawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2804		.1715		.2103	.2427
2	.1417	.2743		.208		.2103	.2743
3	.1372	.2374		.2279		.2058	.2427
4	.1753	.2374		.2427		.2401	.7202
5	.1772	.3086		.2401		.2743	.2454
6	.2774	.3506		.2572		.3429	.1928
7	.2915			.3121	.156	.3353	.208
8	.2401	.362		.7362	.1543	.3429	.1734
9		.3258		.2328	.1187		.2572
10				.2103	.1187	.2865	.1886
11				.2058	.1433	.2561	.2035
12	.2058			.2204	.1402	.2254	.2012
13	.1715			.2347	.1417	.2103	.1823
14	.2035			.2347	.1772	.2507	.1658
15	.2035			.1989	.2103	.208	.1677
16	.1715			.1844	.1772	.2401	.1844
17	.1715		.2058	.1696	.2126	.2774	.1696
18			.2601	.1715	.2149	.1715	.1715
19	.2454		.2572	.208	.2896	.2601	.1734
20	.3224		.2507	.2629	.3258	.2804	.298
21	.3224		.2229	.3012	.3292	.1734	.3721
22	.3224		.7628	.2507	.2926	.3258	.4119
23	.3224		.2401	.2353	.2561		.3077
24	.2126	.3224		.2279		.2126	.2743
Max	.3224	.362	.7628	.7362	.3292	.3429	.7202
Min	.1372	.2374	.2058	.1696	.1187	.1715	.1658
Avg	.2243	.2999	.3142	.2477	.2034	.2518	.2512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 201 / 11 KV Gorewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.1417	.1227	.1029	.8383	.8048	.6706
2	.1402	.1254	.12	.1029	.8453	.7459	.6874
3	.1595	.1254	.12	.1029	.8453	.9054	.6874
4	.1612	.1254	.1227	.1029	.9282	1.0852	.7042
5	.1753	.1254	.1402	.1214	1.0608	1.2742	.7537
6	.2085	.1772	.1526	.1907	1.6057	1.5415	1.1633
7	.1949	.2481	.1696	.208	1.9662	1.7939	1.4419
8	.2103	.1949	.1865	.1886	1.7859	1.8067	1.491
9	.1417	.1578	.1341	.1372	1.8187	1.7436	1.2452
10	.1052	.1543	.12	.1543	.2058	.1696	.1341
11	1.5249	1.5947	1.7404	.1715	.1715	.1696	1.0004
12	1.5074	1.5261	1.6766	.1357	.1543	.1543	1.1233
13		1.358	1.6244	.1187	.1543	.1526	.9945
14	1.2742	1.2717	1.5604	.12	.1372	.1526	
15	1.291	1.1904		.1029	.1372	.1526	
16	1.491	1.4575		.1029	.1543	.1357	1.3592
17	1.5729	1.5091	.1417	.1372	.1715	.1341	1.7101
18	1.5238	1.56	.1543	.156	.2427	.1526	1.5091
19	.208	.2035	.2058	.1907	.2507	.2229	.1715
20	.208	.2572	.2401	.2454	.2658	.2629	.2572
21	.2279	.2401	.2058	.2103	.2401	.2629	
22	.1928	.2058	.1715	.1928	.2195	.2126	
23	.1578		.1372	.1595	.181	.1772	
24	.1417	.1417	.12	.12	.8383	.7969	.6706
Max	1.5729	1.5947	1.7404	.2454	1.9662	1.8067	1.7101
Min	.1052	.1254	.12	.1029	.1372	.1341	.1341
Avg	.5626	.6127	.4258	.1490	.6341	.6254	.9355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 202 / 11 KV Bhivghat AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4862	.5868	.3561	.124	.1063	.1052
2	.5138	.4862	.6001	.373	.1063	.1075	.1063
3	.547	.4862	.6613	.373	.1063	.1052	.1063
4	.5365	.4973	.6203	.373	.1063	.1214	.1063
5	.5935	.4973	.6274	.407	.124	.1227	.124
6		.6796	.6687	.5935	.1578	.124	.1417
7	1.0442	1.0159	1.1022	.7461	.1402	.1433	.1227
8	.9389	.9995	1.1191	.7122	.1227	.124	.1052
9	.9614	1.0322	1.073	.6882	.1372	.1052	.1052
10	.1174	.1187	.1017	.1357	.1543	.1017	.1372
11	.1006	.0848	.12	.5801	.9156	.9835	.104
12	.1017	.0848	.156	.6464	.8383		.12
13		.0848	.121	.6718	.7712	1.0174	.052
14	.1187	.1187	.1029	.6226	.7712	.9665	.1187
15	.1187	.1187		.431	.7712	.9665	.1341
16	.1372			.6554	.8288	.9665	.1029
17	.12	.1174	.12	.7045	.9282	1.0174	.104
18	.1372	.1187	.1372	.5898	.743	.9389	.1543
19	.1387	.1357	.1543	.1187	.1372	.1357	.1526
20	.1578	.1696	.1543	.1543	.1372	.1372	.1696
21	.1578	.1696	.1543	.1543	.1387	.1543	
22	.1578	.1526	.1543	.1387	.1387	.1214	
23	.1417		.12	.1402	.1052	.104	
24	.5087	.503	.6104	.4409	.1227	.1052	.1052
Max	1.0442	1.0322	1.1191	.7461	.9282	1.0174	.1696
Min	.1006	.0848	.1017	.1187	.1052	.1017	.052
Avg	.3548	.3708	.4212	.4503	.3594	.3816	.1180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 203 / 11 KV Khanapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5533	.3561	.1227	.124	.1052
2			.5596	.3391	.124	.1075	.1063
3			.5935	.3391	.124	.124	.1063
4			.6783	.407	.124	.1402	.1063
5			.8383	.4748	.1417	.1612	.1063
6			.9326	.6443	.1928	.168	.1402
7			1.4251	.9835	.1578	.2012	.1578
8			1.4074	1.0159	.156	.1402	.1387
9			1.3413	1.0159	.1387	.1372	.104
10			.1187	.1715		.1357	.1543
11			.104	.8288	1.0852	1.2346	.1402
12			.1052	.8684	1.1065	1.3321	.1417
13			.12	.6554	1.0395	1.1869	.1402
14			.12	.7209	.6706	1.1142	.1174
15	.1372			.7701	.9389	1.1869	.1578
16	.1715			.6226	.6962	1.2887	.1214
17	.1387		.1402	.8848	1.094	1.3565	
18	.1907		.1402	.8684	.9297	1.2071	.1187
19	.1753		.1578	.12	.1629	.1543	.1341
20	.1753		.1753	.1715	.1402	.1734	.1865
21	.1402	.4578	.1753	.1578	.124	.156	
22	.1417	.4239	.1753	.1402	.1402	.1227	
23	.1063		.1578	.1227	.12	.1052	
24			.5658	.373	.1227	.1227	.1227
Max	.1907	.4578	1.4251	1.0159	1.1065	1.3565	.1865
Min	.1063	.4239	.104	.12	.12	.1052	.104
Avg	.1530	.4409	.4811	.5438	.4197	.5075	.1303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 204 / 11 KV Khanapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3403	.3403	.3086	.2629	.3582	.3721	.3403
2	.3544	.3224	.3155	.2629	.3403	.3721	.3403
3	.3681	.3224	.3086	.2629	.3403		.3403
4	.3814	.3224	.3258	.2629	.3403	.443	.3403
5	.4031	.3224	.3258	.2629	.3544	.4733	.3366
6	.3898	.4075	.3353	.298	.3898	.4557	.443
7	.4045	.4252	.3391	.3506	.4075	.4801	.443
8	.3721	.3681	.3391	.3155	.3681	.3814	.3721
9	.354	.333	.3391	.2454	.333	.3772	.3544
10	.298		.3353	.298		.3391	.3506
11		.3052	.3561	.3506	.3506	.373	.3429
12		.3222	.3294	.4161	.3506	.373	.3814
13		.3222	.4287	.4334	.333	.373	.2915
14	.2804	.3391	.4115	.3944	.2804	.3052	.3561
15	.4733	.3561		.3601	.3086	.3052	.4031
16	.3988	.373		.2374	.3429	.3391	.3772
17	.3814	.3856	.4031	.3561	.3429	.3391	
18	.3086	.4239		.2915	.4161	.3772	
19	.4287	.4578		.4557	.4887	.4334	.5087
20	.4733	.4917	.4733		.5258	.5258	.5765
21	.4557		.4733	.5258	.5138	.4733	.4578
22	.443		.4031	.4557	.4382	.4733	
23	.3898		.3856	.4252	.3944	.4075	
24	.3258	.3544	.2883		.3544	.3506	.3544
Max	.4733	.4917	.4733	.5258	.5258	.5258	.5765
Min	.2804	.3052	.2883	.2374	.2804	.3052	.2915
Avg	.3821	.3647	.3612	.342	.3771	.3975	.3855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 205 / 11 KV Bhivghat Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1612	.1402	.1753	.1612	.1772	.1612
2	.1753	.1433	.1402	.1578	.1612	.1612	.1612
3	.1949	.1433	.1402	.1578	.1612	.1227	.1612
4	.1734	.1433	.1543	.1578	.1612	.1372	.1612
5	.1886	.1612	.1543	.1578	.1595	.1791	.1612
6		.2126	.1715	.2103	.1928	.2103	.1949
7	.1734	.2303	.2058	.1928	.1928	.2126	.1949
8	.1543	.2279	.1865	.2103	.1753	.1578	.1772
9	.156	.1928	.1341	.1578	.208	.1715	.1772
10	.156	.1715	.1886	.1578	.2058	.2035	.1928
11	.1886	.2058	.2427	.1734		.2012	.2401
12	.1734	.2012	.2507	.1734	.1886	.1886	.1907
13		.1865	.1772	.1734	.1715	.1696	.1578
14	.1543	.1677	.1734	.1372	.1543	.1543	.1417
15	.1526	.1526		.1357	.1543	.1509	.1372
16	.1402	.1509		.1357	.1715	.1509	.1734
17	.1578	.1865	.1907	.1357	.1715	.1526	.1928
18	.1417	.1865	.1543	.1696	.1734	.1886	.1543
19	.2303	.2035	.1715	.1734	.2534	.1907	.2058
20	.2303	.2374	.2058	.2279	.2279	.156	.2401
21	.2658	.2229	.1886	.2454	.208	.2454	
22	.2328	.2058	.2058	.2103	.1928	.2103	
23	.197		.1753	.1772	.1772	.1753	
24	.1595	.1612	.1578	.1753	.1595	.1578	.1595
Max	.2658	.2374	.2507	.2454	.2534	.2454	.2401
Min	.1402	.1433	.1341	.1357	.1543	.1227	.1372
Avg	.1797	.1850	.1777	.1741	.1819	.1761	.1779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 207 / 11 KV GOREWADI gaovthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0716	.0509	.0514	.0532	.0532	.0532
2	.0532	.0537	.0335	.0514	.0532	.0362	.0532
3	.0724	.0537	.0339	.0514	.0537	.0543	.0537
4	.0716	.0537	.0335	.0514	.0537	.0686	.0537
5	.0886	.0537	.0509	.0686	.0537	.0886	.0709
6		.0709	.0678	.1029	.0716	.1075	.0886
7	.0983	.0886	.1017	.1029	.124	.0886	.1402
8	.0876	.124	.0848	.1029	.124	.0701	.1052
9	.0686	.0701	.0848	.0857	.1052	.0886	.1052
10	.0686	.0671		.0686	.1052	.0848	.0857
11		.0509	.0867	.0686		.0686	.0693
12		.0509	.0686	.0678	.0701	.0678	.0686
13		.0509	.052	.0848	.0701	.0678	
14	.0848	.0503	.0701	.0857	.0701	.0678	.0686
15	.0678	.0509		.052	.0701	.0678	.0686
16	.0867	.0509		.0693	.0686	.0671	.0693
17	.0867	.0509	.0693	.0867	.0686	.0678	.0701
18	.1052	.0678	.0693	.0876	.0693	.1214	.0678
19	.1052	.0848	.1214	.1227	.1086	.1387	.1017
20	.1402	.1187	.1387	.1402	.124	.1578	.1187
21	.124	.1029	.1214	.1402	.0895	.1227	
22	.1063	.0848	.12	.1052	.0709	.1063	
23	.0895		.1029	.0709	.0526	.0886	
24	.0526	.0716	.0509	.0686	.0532	.0537	.0709
Max	.1402	.124	.1387	.1402	.124	.1578	.1402
Min	.0526	.0503	.0335	.0514	.0526	.0362	.0532
Avg	.0856	.0693	.0768	.0828	.0775	.0835	.0792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 201 / PALASHI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2587	.2507	.2279	1.2003	.663	.663
2	.2378	.2561	.2507	.2279	.6516	.663	.663
3	.2378	.2561	.2507	.2328	.6036	.663	.663
4	.2561	.2561	.2715	.2454	.6371	.6802	.6802
5	.2534	.2743	.2896	.2743	.7545	.7701	.7373
6	.3658	.4435	.3475	.3222	1.166	1.2574	1.1603
7	.3142	.3475	.3696	.3856	1.3375	1.7072	1.4089
8	.2328	.3696	.3174	.3045	1.4083	1.6518	1.5223
9	.2715	.3258	.3547	.3258	1.2452	1.5257	1.3763
10	.2686	.2658	.2507	.2804	.1949	.2303	.2515
11		1.1012	1.3375	.2401	.197	.2401	.9231
12		1.1145	.5258	.2401	.2328	.2279	1.065
13		1.3375	1.0343	.2229	.2427	.2543	1.0774
14		1.2003	1.1736	.2629	.2658	.2481	1.0174
15		1.17	1.3441	.2103	.2743	.2481	1.0343
16		1.3245	1.5424	.1753	.2629	.2572	1.2266
17	1.1683	1.166	1.1641	.2454	.298	.2572	1.3279
18	1.3283	.6706	.7343	.2865	.3561	.4001	.7316
19	.3511	.3366	.3077	.3439	.3814	.394	.3772
20	.4294	.4207	.4031	.4108	.4119	.4382	.4163
21	.3921	.4024	.3475	.4108	.4001	.4191	.3982
22	.3547	.362	.2865	.3109	.3429	.381	.3224
23	.2987	.2686	.2279	.2534	.2667	.3048	.2481
24	.2561	.2561	.2507	.2328	.583	.6443	.6539
Max	1.3283	1.3375	1.5424	.4108	1.4083	1.7072	1.5223
Min	.2328	.2561	.2279	.1753	.1949	.2279	.2481
Avg	.4042	.5910	.5680	.2780	.5714	.6053	.8311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 202 / 11 KV HIVARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4641	.4588	.547	.407	.2686	.2858	.2477
2	.4915	.4588	.5182	.4024	.2686	.2858	.2477
3	.502	.4696	.5182	.3978	.2658	.2858	.2477
4	.5182	.4915	.5243	.4191	.2658	.2858	.2477
5	.5921	.5636	.547	.4694	.2865	.3048	.2667
6	1.1984	1.065	1.0288	.7291	.439	.4763	.4163
7	1.2803	1.4089	1.2071	1.2517	.4481	.4382	.4572
8	1.3283	1.3443	1.4403	1.3321	.3841	.3982	.4119
9	1.2643	1.2334	1.5604	1.3032	.3224	.3601	.333
10	.2896	.3582	.3012	.3391	.3582	.2984	.333
11	.2865	.3012	.3224	.7712	1.4232	1.5384	.3429
12		.362	.3801	.9069	1.286	1.3923	.3258
13		.362	.3582	.8848	1.1437	1.1904	.3506
14		.3403	.3052	.8583	.9665	1.0229	.394
15		.3544	.2883	.7935	.9503	1.0111	.333
16	.362	.3544	.3521	.5506	1.0608	1.2944	.333
17	.3403	.2865	.3258	1.1248	1.4074	1.3927	.3898
18	.362	.3681	.3681	1.0623	1.1305	1.3592	.3856
19	.4755	.4525	.4119	.3898	.3898	.4031	.4119
20	.4854	.4755	.4656	.4207	.5144	.4763	.4938
21	.4294	.4344	.4344	.4251	.4763	.4763	.4572
22	.3921	.3982	.3506	.3658	.4001	.381	.3761
23	.3174	.3224	.2915	.3258	.3239	.3429	.3403
24	.4578	.4475	.4527	.3688	.2865	.3048	.2858
Max	1.3283	1.4089	1.5604	1.3321	1.4232	1.5384	.4938
Min	.2865	.2865	.2883	.3258	.2658	.2858	.2477
Avg	.5919	.5463	.5541	.6791	.6278	.6669	.3512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 203 / 11 KV HIVARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0532	.0716	.0537	.0543	.052	.0503
2	.0532	.0532	.0716	.0543	.0358	.0514	.0503
3	.0537	.0526	.0716	.0543	.0358	.0514	.0503
4	.0532	.0526	.0716	.0537	.0358	.0514	.0503
5	.0532	.0351	.0537	.0526	.0543	.0532	.0514
6		.0693	.0724	.0514	.0732	.0857	.0663
7	.0693	.0857	.0732	.0716	.0934	.0678	.0876
8	.0701	.104	.0554	.0549	.0549	.052	.0686
9	.0354	.0686	.0924	.0358	.0701	.0663	.0895
10	.1029	.1357	.0876	.0905	.0857	.1017	.0867
11	.0373	.0848	.0709	.1052	.0857	.0693	.1017
12		.1052	.0895	.0701	.0857	.0857	.0848
13		.124	.0876	.0526	.0693	.0701	.1029
14		.0701	.0701	.0351	.0497	.0503	.0532
15		.0526	.0358	.0351	.0678	.0678	.0532
16	.0709	.1029	.0724	.0351	.0526	.0663	.0701
17	.0876	.0526	.0716	.0686	.0686	.0514	.0701
18	.0867	.0514	.0724	.0686	.0867	.0671	.0857
19	.0351	.1086	.0537	.0709	.0671	.0693	.0876
20	.0867	.0914	.0747	.0934	.1052	.1017	.0905
21	.0876	.1097	.0943	.0934	.1052	.1029	.0905
22	.0709	.0724	.0747	.0739	.0857	.0838	.0716
23	.0716	.0905	.0543	.0732	.052	.0838	.0716
24	.0526	.0526	.0716	.0537	.0543	.052	.052
Max	.1029	.1357	.0943	.1052	.1052	.1029	.1029
Min	.0351	.0351	.0358	.0351	.0358	.0503	.0503
Avg	.0648	.0783	.0714	.0626	.0679	.0689	.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 201 / 11 KV RENA VI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4374	.4687	.5218	.3795	.0709	.0537	.0732
2	.4687	.5624	.5155	.3795	.0709	.0543	.0732
3	.5624	.5624	.5376	.3795	.0709	.0549	.0724
4	.5624	.5937	.5376	.3795	.0709	.0549	.0724
5	.5624	.6249	.5624	.3795	.0709	.0732	.0732
6	.5937	.6249	.6944	.5851	.0886	.0716	.0924
7	.7968		.9061	.6405	.0886	.0724	.0924
8	.9061	.3749	.9568	.7099	.0895	.0886	.1267
9	.8436	.6562	.8642	.7164	.1063	.0709	.0701
10	.0937	.0617	.081	.0617	.1063	.1052	.0876
11	.0312		.0709	.4843	.7907	.7968	.0701
12	.0937		.0876	.5864	.68	.6173	.0701
13	.0781		.0895	.6019	.68	.7407	.0625
14	.0781		.0709	.5556	.6722	.7716	.0625
15	.0781	.0543		.6019	.5851	.7811	.0781
16	.0781	.0924		.6636	.7748	.8488	.0937
17	.0781	.0895		.7343	.828	.9414	.0937
18	.0781	.1214		.6944	.7499	.9414	.0937
19	.0781	.104		.0829	.0876	.0716	.0937
20	.0937	.0905	.0905	.1029	.0886	.1063	.0937
21	.0937	.1075	.1086	.0876	.0895	.1063	.0937
22	.0937	.1075	.0876	.0876	.0886	.1075	.0937
23	.0937	.1086	.0693	.0701	.0701	.0724	.0781
24	.4218	.4218	.4902	.3953	.0709	.0709	.0724
Max	.9061	.6562	.9568	.7343	.828	.9414	.1267
Min	.0312	.0543	.0693	.0617	.0701	.0537	.0625
Avg	.3040	.3067	.3864	.4317	.2954	.3197	.0826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 202 / 11 KV RENA VI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.112	.128	.1294	.1307	.1307
2	.0732	.0914	.1109	.1307	.128	.1307	.1307
3	.0732	.1097	.1109	.1307	.128	.1307	.1294
4	.1097	.1463	.1109	.1307	.128	.1307	.1294
5	.1463	.1646	.1109	.1307	.128	.1307	.1463
6	.1646	.1829	.1848	.1478	.1478	.1478	.1829
7	.1829	.1829	.1829		.1663	.1478	.2012
8	.1646	.1463	.1433	.1612	.1629	.1463	.1612
9	.128	.1646	.0914	.1387	.1629	.1433	.1448
10	.128	.1063	.1402	.1417	.1402	.1063	.1417
11	.0914	.1075	.1433	.1433	.1267	.1402	.1463
12	.0914	.1075	.1433	.1267	.1086	.1448	.1463
13	.128	.0914	.1267	.1075	.1267	.1086	.1463
14	.128		.1448	.1075	.1086	.1086	.128
15	.128	.1086		.1097	.0732	.1433	.1463
16	.128	.1612		.1267	.1448	.1433	.1463
17	.128	.1595		.128	.1433	.1612	.1463
18	.1829	.1753		.1612	.1612	.1928	.1829
19	.1829	.1791		.1829	.181	.197	.2012
20	.2378	.2195	.181	.2195	.2195	.2353	.2378
21	.2195	.2218	.181	.1867	.1829	.2054	.2195
22	.1829	.1848	.1663	.168	.1663	.1867	.2012
23	.1463	.1494	.1494	.168	.1494	.1494	.1829
24	.1097	.1097	.1307	.1494	.1494	.1494	.1307
Max	.2378	.2218	.1848	.2195	.2195	.2353	.2378
Min	.0732	.0914	.0914	.1075	.0732	.1063	.128
Avg	.1394	.1462	.1402	.1446	.1443	.1505	.1608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 201 / 11 KV BURLI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0787	.0754	.0892	.1006	1.2334	1.2483	1.3283
2	.072	.0772	.0857	.1029	1.2483	1.2334	1.3443
3	.0747	.0823	.084	.1029	1.2334	1.2631	1.4403
4	.076	.0789	.0823	.1052	1.2334	1.3283	1.4746
5	.0943	.1006	.0857	.1029	1.3443	1.4232	1.4998
6	.0977	.1067	.1029	.1143	1.4575	1.4575	1.7695
7	.1075	.1105	.1097	.1143	1.6712	1.6324	2.2131
8	.1006	.128	.0983	.1006	1.8461	1.8244	2.4143
9	.0972	.1012	.0953	.0909	1.8896	1.8461	2.3868
10	.0983	.0953	.1048	.0602	.0579	.1006	.1286
11	1.8679	2.2874	2.2382	.0791	.061	.1162	2.0645
12	1.8679	2.2085	2.4756	.0762	.0926	.1143	2.0645
13		2.3868	2.4143	.0617	.1105	.1027	2.1879
14	1.8896	2.4143	2.1879	.08	.1048	.1027	2.2874
15	2.0119	2.3137	2.4417	.0734	.1048	.12	2.2874
16		1.989	2.4143	.0909	.0991	.101	2.2874
17		2.1879	2.2874	.0985	.0819	.0857	2.2611
18	1.8679	1.9662	2.1879	.072	.0983	.1143	1.8679
19	.0892	.1067	.0972	.0857	.0874	.1143	.1097
20	.1124	.1029	.1029	.0926	.1029	.1235	.1183
21	.0991	.112	.1143	.0977	.0953	.1132	.1143
22	.096	.1048	.1048	.08	.101	.1048	.1115
23	.0869	.1048	.0943	.0674	.0953	.1067	.084
24	.0926	.0874	.1029	.0892	1.278	1.0562	1.278
Max	2.0119	2.4143	2.4756	.1143	1.8896	1.8461	2.4143
Min	.072	.0754	.0823	.0602	.0579	.0857	.084
Avg	.5228	.8054	.8417	.0891	.6553	.6597	1.4635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 202 / 11 KV RAMANANDNAGAR 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.415	.4527	.5175	.4527	.4527	.4527
2	.4527	.415	.3772	.4481	.4527	.3772	.415
3	.3772	.3772	.3772	.4527	.415	.3772	.3772
4	.4481	.3772	.3772	.415	.415	.3772	.2263
5	.4527	.415	.415	.415	.4527	.4527	.4527
6	.4481	.4527	.4481	.4527	.5228	.4527	.5281
7	.4344	.4481	.5068	.4854	.5175	.5121	.5487
8	.4298	.4435	.5068	.5121	.5121	.5068	.5853
9	.4908	.5373	.6379	.5792	.5487	.5548	.5487
10	.4024	.5792	.6241	.567	.5548	.6104	.6036
11	.394	.5609	.6379	.567	.567	.6379	.6024
12	.3582	.439	.5228	.4854	.4435	.5175	.5175
13	.3658	.4481	.5228	.4481	.4435	.543	.4481
14	.4066	.5121	.5914	.5121	.5175	.5121	.5731
15	.4108	.5914	.5853	.5487	.5228	.5792	.5731
16	.439	.5068	.5731	.5316	.5068	.5731	.5731
17	.3018	.5068	.567	.543	.5121	.5853	.543
18	.3658	.567	.543	.5068	.5068	.5121	.5068
19	.5121	.6447	.5914	.5175	.5121	.5853	.6219
20	.5914	.6653	.5975	.6283	.5914	.6653	.6283
21	.5544	.5914	.5281	.5601	.5228	.6036	.5658
22	.5228	.5975	.5281	.5281	.5228	.5281	.5281
23	.4904	.5228	.4904	.5281	.5281	.5281	.5281
24	.4527	.4527	.5281	.4904	.4527	.4527	.4527
Max	.5914	.6653	.6379	.6283	.5914	.6653	.6283
Min	.3018	.3772	.3772	.415	.415	.3772	.2263
Avg	.4398	.5028	.5221	.5100	.4997	.5207	.5167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 203 / 11 KV SAWANTPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0903	.0724	.0753	.1113	1.5912	1.5364	1.704
2	.0734	.0714	.0743	.0812	1.5729	1.5912	1.6644
3	.0772	.0743	.0762	.0823	1.5912	1.5912	1.6644
4	.0914	.0753	.0926	.0705	1.5912	1.8461	1.6842
5	.0903	.0914	.0903	.0734	1.9113	1.9662	1.8564
6	.0926	.0949	.1235	.0995	2.146	1.9662	1.989
7	.1054	.1204	.128	.116	2.3868	2.2283	2.4143
8	.088	.104	.1235	.1311	2.332	2.332	2.3205
9	.104	.1189	.096	.108	2.2542	2.3594	2.5194
10	.1143	.1189	.1406	.0734	.1	.08	.0975
11		2.652	2.6825	.0743	.1094	.0949	2.652
12		2.652	2.7846	.0743	.1158	.088	2.7846
13	2.2542	2.7846	2.6852	.0743	.1027	.1067	2.7846
14		2.652	2.7515	.0781	.1014	.116	2.652
15		2.652	2.6543	.096	.104	.1067	2.652
16	2.0972	2.652	2.652	.1265	.1054	.1054	2.652
17	2.3594	2.652		.1204	.1014	.0914	2.652
18	2.4905	2.0972	.4451	.1189	.104	.104	2.4905
19	.1158	.1014	.0587	.0657	.1174	.1219	.108
20	.0857	.1189	.096	.0724	.1054	.0914	.1067
21	.0857	.1158	.0983	.0724	.1219	.128	.1189
22	.088	.1067	.0972	.0762	.1067	.1423	.108
23	.1	.0926	.0926	.0772	.1067	.0937	.0772
24	.0834	.0734	.0914	.1562	1.4586	1.5729	1.7238
Max	2.4905	2.7846	2.7846	.1562	2.3868	2.3594	2.7846
Min	.0734	.0714	.0587	.0657	.1	.08	.0772
Avg	.5343	.9310	.7917	.0929	.8474	.8525	1.7282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 204 / 11 KV RAMANANDNAGAR 2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.679	.679	.6722	.679	.679	.6036
2	.5975	.6413	.679	.6036	.6413	.6036	.6036
3	.6036	.6036	.6036	.5658	.6036	.6036	.5658
4	.679	.6036	.679	.5658	.6036	.5975	.6036
5	.679	.679	.7167	.6036	.679	.679	.679
6	.7167	.7842	.7468	.679	.7545	.7545	.7545
7	.7095	.6653	.7392	.7095	.7468	.7316	.7545
8	.6516	.6283	.7164	.6653	.6653	.695	.6653
9	.6653	.6516	.724	.695	.6878	.7087	.8299
10	.6584	.7087	.7164	.567	.7087	.7628	.6783
11	.6089	.7011	.8596	.5731	.7164	.7796	.8413
12	.6516	.6379	.7468	.5175	.6878	.7316	.6722
13	.6653	.6653	.7762	.6584	.7087	.724	.7392
14	.6653	.724	.8596	.8048	.7095	.8688	.8688
15	.6653	.7316	.8962	.8048	.7316	.8299	.8048
16	.5853	.6653	.8048	.7316	.724	.7545	.7316
17	.4527	.5853	.7164	.6447	.724	.724	.6447
18	.5316	.6733	.7316	.6584	.6516	.6935	.6661
19	.7316	.7964	.6584	.695	.695	.7602	.7392
20	.8215	.8871	.8962	.8215	.8871	.8962	.8871
21	.8589	.8962	.8299	.8299	.8215	.8299	.8215
22	.8215	.8215	.8299	.8299	.8215	.7545	.8215
23	.7545	.8299	.7545	.7545	.7545	.7545	.7922
24	.7167	.679	.7545	.679	.679	.679	.679
Max	.8589	.8962	.8962	.8299	.8871	.8962	.8871
Min	.4527	.5853	.6036	.5175	.6036	.5975	.5658
Avg	.6706	.7058	.7548	.6804	.7117	.7331	.7270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 201 / 11 KV DUDHONDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0709		.4915	.4481	.5921	.0924
2	.0732	.0716		.4915	.4801	.6154	.0747
3	.0739	.0724		.5182	.502	.6154	.0747
4	.0747	.0905		.5121	.5182	.6882	.0934
5	.0934	.0914		.5506	.583	.7537	.0934
6	.112	.1463		.6226	.7449	.8848	.1307
7	.1132	.1086		.7537	1.0159	1.0978	.112
8	.1132	.1086		.8619	1.0753	1.166	.132
9	.1132	.1086		.8192	1.0688		.1132
10	.1132	.1086		.0934	.0943		.1132
11	.9393	1.17		.112	.0934	.1132	1.2929
12	1.1961	1.2163		.112	.0934	.1132	1.6278
13	1.1797	1.2308	.9831	.0747	.0934	.0934	1.643
14	1.2125	1.2146	1.0814	.0747	.0924	.1109	1.6095
15	1.166	1.166	1.1603	.0747	.0924	.0924	1.5581
16	1.1469	1.1822		.0747	.0934	.0934	1.4918
17	1.065	1.1203	1.094	.1132	.0943	.1132	1.4255
18	1.065	.7042	1.0486	.1132	.1307	.132	1.2955
19	.1478	.0934	.112	.1097	.1509	.132	.1132
20	.1254	.1132	.1086	.1097	.128	.1132	.1294
21	.0895	.112	.1075	.1097	.1267	.1086	.1109
22	.0895	.0924	.1075	.1097	.1267	.0914	.1086
23	.0724	.0924	.0914	.1086	.1097	.0914	.1063
24	.0934	.0716		.4534	.4111	.5601	.1109
Max	1.2125	1.2308	1.1603	.8619	1.0753	1.166	1.643
Min	.0724	.0709	.0914	.0747	.0924	.0914	.0747
Avg	.4400	.4399	.5894	.3110	.3486	.3805	.5689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 202 / 11 KV NAGRALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4111	.5376	.6401	.0772	.064	.0867	.7682
2	.4428	.5441	.6562	.0772	.081	.0867	.7522
3	.5121	.6176	.6483	.0633	.0648	.0701	.7362
4	.5441	.6401	.6642		.0983	.0693	.7773
5	.6401	.7125	.6958	.1029	.0819	.0876	.7935
6	.7209	.7537	.8192	.1063	.1086	.1063	1.0111
7	.7773	.8421	.9012	.0983	.0867	.1017	1.1736
8	.8745	.9175	1.0486	.0892	.0734	.1054	1.2742
9	.9282	.9069	1.0814	.0648	.0781	.0762	1.2431
10	.081	.0446	.0572	.0495	.0753	.0753	.0709
11	.0633	.0572	.0724	1.3923	1.3757	1.6617	
12	.0791	.0587	.0714	1.4251	1.3426	1.7269	.0772
13	.064	.0474	.0791	1.3592	1.3923	1.7101	.0625
14	.0671	.048	.0648	1.3592	1.3923	1.6741	.0772
15	.0648	.0633	.0655	1.3426	1.3923	1.6766	.0648
16	.0648	.0701		1.3599	1.4089	1.5729	.0819
17	.0617	.0617	.0762	1.3272	.68	1.5238	.064
18	.0625	.0625	.0772	1.2308	.8421	1.4419	.0781
19	.0834	.0602	.0995	.061	.1006	.0648	.1029
20	.08	.0486	.1029	.061	.0867	.0678	.1052
21	.0983	.0648	.1029	.0648	.1052	.0867	.0995
22	.0949	.0655	.0995	.0819	.1029	.0686	.1017
23	.0781	.0655	.08	.0972	.0857	.0671	.081
24	.3795	.4744	.5121	.08	.0772	.1029	.506
Max	.9282	.9175	1.0814	1.4251	1.4089	1.7269	1.2742
Min	.0617	.0446	.0572	.0495	.064	.0648	.0625
Avg	.3031	.3235	.3789	.5205	.4665	.5963	.4392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 203 / 11 KV TAKARI EXPS

NON SHEDDABLE WATER SUPPLY AND
UTILITY

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5487	.5548	.5609	.5784	.5316	.567
2	.5083	.543	.5375	.5609	.567	.5258	.5434
3	.4854	.5792	.5609	.5201	.5493	.5609	.5258
4	.5083	.5731	.5959	.5201	.5609	.5609	.567
5	.5316	.5373	.6241	.5609	.5609	.5316	.567
6	.567	.5373	.5493	.5959	.6024	.5316	.591
7	.6024	.5316	.567	.5959	.567	.5258	.6154
8	.6447	.5373	.6878	.6447	.6089	.5731	.6401
9	.5792	.5792	.7602	.6878	.724	.5731	.7682
10	.6516	.6089	.6805	.6379	.6154	.5373	.6447
11	.5792	.724	.6516	.7164	.7316	.6878	.7316
12	.5487	.6516	.6447	.7602	.6089	.6878	.6584
13	.5068	.6805	.7087	.6878	.5731	.6447	.6516
14	.2241	.6878	.6516	.4024	.6154	.6379	.6219
15	.2641	.6379	.6089	.3772	.6268	.5014	.6584
16	.2641	.6447		.4715	.6154	.5609	.6878
17	.1886	.5609	.5609	.3961	.5258	.6089	.6089
18	.2641	.5373	.5548	.4706	.5316	.6516	.5731
19	.2641	.631	.4481	.6241	.5258	.5731	.6219
20	.2641	.5609	.6516	.5316	.5731	.6447	.6154
21	.2587	.5895	.5959	.5609	.5258	.6268	.5792
22	.3658	.5959	.567	.5609	.5258	.5731	.5731
23	.3292	.567	.6733	.567	.5258	.5552	.5373
24	.5609	.5544	.6024	.6024	.5959	.5316	.6089
Max	.6516	.724	.7602	.7602	.7316	.6878	.7682
Min	.1886	.5316	.4481	.3772	.5258	.5014	.5258
Avg	.4370	.5916	.6103	.5673	.5848	.5807	.6149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 204 / 11 KV NAGRALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.8402	.8962	.7922	.8962	.8676	.7842
2	.7842	.8316	.8589	.7842	.8865	.8589	.7468
3	.8215	.8413	.8865	.8131	.9054	.8962	.7356
4	.8676	.8686	.9054	.8589	.8865	.8871	.7733
5	.9431	.9431	.9619	.9431	.9431	.9335	.9431
6	1.1317	1.1203	1.1317	1.1317	1.1506	1.1128	1.1317
7	.961	.724	1.0349	.8413	.9335	.924	.924
8	.7602	.724	.7964	.7164	.7964	.7762	.7316
9	.6447	.7087	.7265	.6447	.724	.7087	.724
10	.7164	.7282	.3429	.6516	.6661	.6935	.6588
11	.7087	.7087	.8238	.5609	.7522	.7796	.7442
12	.7087	.7164	.788	.8859	.788	.7796	.7964
13	.724	.724	.8326	.724	.7602	.7783	.8048
14	.7316	.7316	.7682	.7421	.0768	.7682	.7762
15	.8326	.7316	.7964	.7682	.7316	.7964	.7682
16	.5792	.7682		.8688	.7602	.7442	.8131
17	.5316	.7087	.6516	.8063	.7011	.7265	.6878
18	.5258	.7011	.5548	.7108	.7087	.7011	.7442
19	.9492	.8954	.7602	.905	.8688	.9412	1.0608
20	1.1643	1.1088	1.1088	1.1088	1.0534	1.0903	1.086
21	1.1203	1.0829	1.1088	1.1016	1.0719	1.1016	1.1203
22	1.0829	1.1016	1.1203	1.0829	1.0642	1.0456	1.0829
23	.9709	.9709	1.0082	.9522	.9335	.9335	.9431
24	.8676	.8775	.9242	.8676	.9149	.8676	.811
Max	1.1643	1.1203	1.1317	1.1317	1.1506	1.1128	1.1317
Min	.5258	.7011	.3429	.5609	.0768	.6935	.6588
Avg	.8316	.8399	.8603	.8443	.8322	.8630	.8497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 205 / SATTESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5788	.5975	.5601	.5601	.6161
2	.5544	.5788	.5788	.5788	.5975	.5975
3	.5544	.5788	.5544	.5788	.5914	.6161
4	.567	.5601	.5729	.5975	.5975	.6161
5	.5729	.5601	.5975	.6161	.6161	.6161
6	.5975	.5975	.5975	.6348	.6348	.6348
7	.6099	.5975	.6161	.6348	.6161	.6413
8	.6099	.5975	.6099	.6348	.6722	.6602
9	.6099	.5975	.5975	.6413	.6161	.6413
10	.5914		.5975	.5975	.6161	.5788
11	.6161		.5975	.6161	.6224	.6224
12	.5601		.6036	.6161	.6036	.6224
13	.5788	.5041	.6224	.6348	.5975	.5975
14	.5847	.5175	.6036	.5975	.5975	.5975
15	.5601	.5601	.6036	.6348	.5975	.6099
16	.5658		.5975	.5975	.5975	.5975
Max	.6161	.5975	.6224	.6413	.6722	.6602
Min	.5121	.5041	.5544	.5601	.5601	.5788
Avg	.5778	.5690	.5967	.6107	.6084	.6166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 201 / 11 KV PALUS CITY FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4523	1.5466	1.4712		1.4712	1.4335	1.358
2	1.4146	1.5466	1.4146	1.3817	1.3957	1.4335	1.226
3	1.4335	1.4712	1.3203	1.4335	1.4146	1.4146	1.358
4	1.4712	1.4712	1.4335	1.4712	1.4712	1.4146	1.4712
5	1.5089	1.6804	1.5466	1.475	1.5466	1.5123	1.5089
6	1.6244	1.6804	1.6244	1.531	1.6804	1.6057	1.5684
7	1.6448	1.6448	1.5893	1.5708	1.6448	1.6804	1.5339
8	1.4299	1.5524	1.5023	1.3937	1.4842	1.4415	1.4148
9	1.3432		1.5043	1.3575	1.4327	1.5023	1.3073
10	1.3672	1.6124		1.576		1.4661	1.4815
11		1.6655	1.8604	1.6118	1.4506	1.5043	1.4883
12		1.7177		1.6118	1.5729	1.4685	1.5023
13		1.7372	1.7193	1.647	1.4327	1.5023	1.4661
14		1.6476	1.7556	1.647	1.4842	1.5364	1.5181
15		1.6461	1.7918		1.5746	1.4815	1.6827
16		1.6095	1.7372	1.9366	1.5402	1.448	1.6832
17	1.6263	1.6834	1.7337	1.8099	1.5939	1.576	1.7187
18		1.701		1.7375	1.5023	1.6655	1.7896
19	2.4209			1.9387	1.8107	1.8642	2.0485
20	2.347	2.1948	2.0328	2.0883	2.0698	2.0513	2.1992
21	2.2405	2.0328	1.7926	1.9605	1.9605	1.885	2.0513
22	2.1098	1.9959	1.7551	1.8484	1.7177	1.7737	1.9589
23	1.8484	1.7551	1.5684	1.643	1.643	1.7741	1.7924
24	1.475	1.5684	1.5123	1.4003	1.4901	1.4712	1.4003
Max	2.4209	2.1948	2.0328	2.0883	2.0698	2.0513	2.1992
Min	1.3432	1.4712	1.3203	1.3575	1.3957	1.4146	1.226
Avg	1.6916	1.6891	1.6333	1.6396	1.5819	1.5794	1.6053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 202 / 11 KV MIDC PALUS FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5281	.4904	.5658	.5658	.5658	.5281
2	.5281	.5281	.5093	.5281	.547	.5658	.547
3	.5093	.5281	.4904	.5281	.547	.5658	.5658
4	.5093	.5093	.5093	.6036	.5658	.5093	.5281
5	.5281	.5093	.4904	.6036	.6036	.5281	.547
6	.5281	.5093	.5093	.6413	.6036	.5281	.547
7	.5281	.5281	.4904	.6036	.7356	.547	.547
8	.4904	.6602	.547	.6602	.8299	.6413	.6602
9	.4904		1.1883	.961	.9795	1.094	1.0185
10	.4904	1.0751	1.3203	1.1128	1.4815	1.0751	.9997
11		.9522	1.3203	.9808	1.5089	1.0562	1.0185
12		.9145	.9619	.8676	1.0185	.9808	.8145
13		.9774	1.3491	1.5278	.9054	1.094	1.3352
14		1.3169	1.358	1.8861	1.2637	1.4712	1.9616
15		1.4937	1.3957		1.358	1.3957	1.1389
16		1.3769	1.358		1.0374	1.0751	1.358
17	.4904	1.2637	.6979	2.037	.811	.8505	.9955
18		1.1506		.7356	.7545	.679	.8865
19	.5093	.6413	.5658	.9054	.547	.5847	.7356
20	.5093	.5658	.6224	.6036	.5847	.6036	.6036
21	.5093	.5121	.6979	.811	.547	.5658	.547
22	.4904	.4904	.6413	.6224	.547	.547	.5281
23	.5093	.5093	.6413	.7356	.547	.5658	.5281
24	.5093	.5281	.4904	.679	.5658	.5658	.547
Max	.5281	1.4937	1.3957	2.037	1.5089	1.4712	1.9616
Min	.4904	.4904	.4904	.5281	.547	.5093	.5281
Avg	.5082	.7856	.8107	.8727	.8106	.7773	.8119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 203 / 11 KV GONDILWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2987	.0754		1.4403	1.3279	1.3279
2	.2641	.2987	.0754	.0377	1.4251	1.2803	1.3927
3	.2452	.2987	.0566	.0377	1.3927	1.2803	1.4918
4	.2641	.3361	.0754	.0377	1.4575	1.3763	1.576
5	.2829	.3326	.0943	.0566	1.6804	1.4737	1.5546
6	.3174	.3511	.0943	.0566	1.9134	1.9919	1.587
7	.3109	.4481	.1294	.0754	2.6235	2.672	2.0645
8	.3511	.3881	.1132	.0377	2.9797		2.1605
9	.3801		.1132	.0566	2.7854	2.5101	2.2885
10	.3439	.3734		.0549	.3961	.3395	.3018
11		2.9312	2.834	.3658	.3961	.3772	2.4326
12		2.0965	3.0931	.3841	.3961	.3584	2.5286
13		1.2492	.1669	.4435	.3772	.3206	2.1032
14		2.8166	3.0639	.4435	.3961	.3224	2.2725
15		2.9312	3.195		.3961	.2801	2.4129
16		.7682	3.3198	.3511	.4207	.3018	2.4326
17			1.945	.3881	.4527	.3841	2.5126
18		2.1862		.2896	.4108	.3772	2.3685
19	.1829	.3961	.3547	.4481	.4108	.415	.3772
20		.4338	.4904	.4668	.3734	.415	.4527
21	.3734	.4338	.4527	.4527	.3734	.415	.415
22	.4108	.4715	.4338	.4338	.3772	.3961	.415
23	1.6385	.1698	.3961	.3772	.3395	.3584	.3584
24	.2829	1.5565	.0754	.3584	1.4563	1.3279	1.2955
Max	1.6385	2.9312	3.3198	.4668	2.9797	2.672	2.5286
Min	.1829	.1698	.0566	.0377	.3395	.2801	.3018
Avg	.3942	.9803	.9385	.2570	1.0279	.8827	1.5884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 204 / 11 KV MINI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1698	.2263	.1886	.2263	.2263
2	.1698	.1886	.1698	.2075	.1886	.2263	.2075
3	.1698	.1886	.1509	.1886	.2075	.2075	.1886
4	.1886	.1886	.1698	.1886	.1886	.2075	.1698
5	.1698	.2263	.1886	.2075	.1886	.1886	.1886
6	.2075	.2263	.1886	.2263	.2075	.1886	.1886
7	.2075	.2075	.2075	.2263	.2075		.2263
8	.2075	.415	.4338	.3584	.4527	.4338	.3961
9	.1886		.415	.5093	.4527	.5093	.4527
10	.2075	.4715	.4527	.4527	.3921	.4338	.4904
11		.4668	.4527	.3772	.415	.4527	.5281
12			.3772	.2829	.3475	.415	.3961
13			.415	.3772	.3772	.3961	.3961
14		.4527	.4904	.3772	.4338	.4527	.5093
15		.4527	.415		.3961	.415	.4715
16		.4527	.4338	.4527	.4338	.4904	.4904
17		.3584	.3961	.415	.3961	.4527	.4715
18		.3961		.3395	.3772	.3772	.4338
19	.1886	.2829	.3018	.3206	.3018	.3584	.3772
20	.1886	.2452	.3206	.2452	.2641	.3772	.3206
21	.2263	.1886	.2075	.1886	.2263	.3206	.2829
22	.1886	.1698	.2075	.1886	.2075	.3018	.2263
23	.1886	.1698	.2075	.2075	.2075	.2641	.2263
24	.2263	.1886	.1886	.2641	.2075	.2452	.2452
Max	.2263	.4715	.4904	.5093	.4527	.5093	.5281
Min	.1698	.1698	.1509	.1886	.1886	.1886	.1698
Avg	.1945	.2917	.3026	.2969	.3027	.3453	.3379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 205 / 11 KV MAHADA COLONY

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1629	.1448	.1433	.1448	.1463	.1463
2	.1448	.1448	.1254	.1267	.1448	.128	.1254
3	.1463	.1463	.128	.1267	.128	.128	.128
4	.1448	.1463	.1433	.128	.1448	.1254	.1448
5	.1448	.1629	.1629	.1433	.1433	.1433	.1646
6	.1595	.1791	.1612	.1448	.1578	.1612	.1629
7	.1907	.208	.1907	.1753	.1928	.1753	.1772
8	.1715	.1658	.1696	.1492	.1658	.1543	.1526
9	.1658		.1526	.1658	.1341	.1492	.1581
10	.1696	.1509	.16	.1619	.1235	.1423	.1389
11		.16	.1619	.1341	.1966	.1781	.1677
12			.1311	.1341	.1509	.1638	.1457
13			.1509	.1372	.1509	.1543	.1543
14		.1311	.1402	.1372	.1402	.1543	.1543
15		.1326	.1526		.1417	.1387	.1526
16		.1543	.1677	.156	.1341	.1509	.1509
17	.1402	.1526	.1562	.156	.16	.1509	.1475
18	.2103	.1658		.1781	.1844	.1581	.1781
19	.2058	.1907	.1989	.2058	.1886	.1696	.1907
20	.2149	.2126	.1928	.2126	.2149	.1928	.2126
21	.2149	.2172	.181	.181	.197	.1991	.1991
22	.2149	.1991	.181	.181	.2012	.181	.2149
23	.181	.1829	.1791	.1829	.1646	.1829	.181
24	.1448	.1629	.1463	.1612	.1433	.1463	.1463
Max	.2149	.2172	.1989	.2126	.2149	.1991	.2149
Min	.1402	.1311	.1254	.1267	.1235	.1254	.1254
Avg	.1727	.1680	.1599	.1575	.1603	.1573	.1623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 206 / 11 KV M.I.D.C. JAWAHAR SHEDDABLE FEEDER HAVING WEEKLY
VIDYLAY Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5658	.4904	.5093	.4904	.5093	.5658
2	.5281	.5658	.5093	.4904	.4904	.5658	.5281
3	.5281	.5658	.5093	.4904	.5093	.5658	.5093
4	.5093	.5847	.5281	.5281	.4904	.5658	.5281
5	.5281	.5847	.5281	.547	.5093	.5093	.4904
6	.5093	.5658	.5281	.5847	.5093	.4904	.4715
7	.4904	.5658	.3395	.5658	.4904	.5093	.4904
8	.4904	.547	.3206	.5847	.5093	.5281	.4338
9	.5093		.9997	.4715	.5281	.9054	.7356
10	.6602	.6224	.5093	.4904	.4715	1.3817	.6413
11		.6224	.679	.9054	.5281	1.5089	.7468
12			.9808	.9431	.5093	1.358	1.3032
13			.5847	1.0269	.6413	1.0374	1.0374
14		.5658	.5658	.9808	.6224	.6602	1.1946
15		.547	.5847		.5093	1.4146	1.475
16		.5281	.547	1.3203	.547	1.3769	.6626
17		.5847	.4527	.5658	.5093	.7167	.679
18		.6413		.547	.6036	.6036	.6413
19	.4904	.679	.4904	.547	.6036	.5847	.6224
20	.4904	.7167	.5281	.4904	.547	.5847	.6413
21	.547	.6224	.5281	.4715	.5281	.5847	.6602
22	.5658	.6224	.547	.4904	.5281	.6036	.6602
23	.5847	.4904	.5658	.4904	.5093	.6036	.6602
24	.547	.5658	.4904	.547	.4904	.5093	.5847
Max	.6602	.7167	.9997	1.3203	.6413	1.5089	1.475
Min	.4904	.4904	.3206	.4715	.4715	.4904	.4338
Avg	.5328	.5883	.5568	.6343	.5281	.7782	.7068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 201 / 11KV ASAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.0343	.0343		.4908	.7373	.0343
2	.0492	.0343	.0343	.8192	.4557	.7373	.0343
3	.0492	.0343	.0343	.8192	.4287	.7537	.0343
4	.0492	.0343	.0343	.8192	.4458	.7701	.0343
5	.0328	.0343	.0343		.4458	.8029	.0343
6	.0492	.0343	.0343		.4694	.8356	.0343
7	.0492	.0343	.0343		.503	1.0159	.0343
8	.0492	.0514	.0343		.57	1.0722	.0343
9	.0328	.0514	.0343		.7865	1.0978	.0343
10		.0503	.0335		.048	.0343	.0335
11		1.3916	1.5592	.0343	.032	.0343	1.1736
12		1.4922	1.643	.0343	.048	.0343	1.4074
13		1.4091	1.6712	.0343	.032	.0343	1.4582
14		1.491	1.6057	.0335	.032	.0343	1.5089
15	1.2289	1.4746	1.5729	.0335	.032	.0343	1.5432
16	1.2944	1.5592	1.5074	.0335	.032	.0343	1.4918
17	1.4419	1.6095		.0335	.032	.0343	1.4091
18	1.4091	1.4255	1.5089		.048	.0343	1.2944
19	.0514	.0343		.0343	.0469	.0343	.0514
20	.0514	.0343		.0514	.0469	.0343	.0514
21	.0514	.0343	.0343	.0343	.0469	.0343	.0514
22	.0514	.0343	.0343	.0343	.032	.0343	.0514
23	.0514	.0343	.0343	.0343	.032	.0343	.0514
24	.0492	.0343	.0343	.8573	.4908	.7209	.0343
Max	1.4419	1.6095	1.6712	.8573	.7865	1.0978	1.5432
Min	.0328	.0343	.0335	.0335	.032	.0343	.0335
Avg	.3206	.5188	.5499	.2338	.2345	.3760	.4967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 202 / 11KV M WADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8351	2.0153	1.8679	.1029	.0876	.0838	1.6385
2	1.8842	1.9989	1.8679	.1029	.0701	.0838	1.6385
3	1.917	2.0481	1.8679	.1029	.0701	.0838	1.6385
4	1.9006	2.1136	1.8679	.1029	.0701	.0838	1.6385
5	1.8679	2.2119	1.9662	.1029	.0686	.0838	1.6385
6	1.9826	2.3102	2.0972	.1029	.0857	.1006	1.6385
7	2.1956	2.3922	2.2611	.1029	.0686	.1006	1.9662
8	2.13	2.2939	2.3102	.1029	.0838	.0983	2.0972
9	2.0317	2.3102	2.2447	.0857	.0838	.0983	2.0645
10		.0838	.0838	.0671	.0819	.1029	.0671
11		.1006		2.2131	2.0485	2.4249	.0838
12		.0983	.0838	2.2801	2.0805	2.4249	.1017
13		.1006	.1341	2.0957	2.1285	2.2283	.1187
14		.0671	.1311	2.0153	2.0965	2.2283	.12
15	.0686	.0671	.1311	2.3594	2.0645	2.2611	.1029
16	.12	.0983	.1311	2.3758		2.2939	.1372
17	.1372	.0983		2.2801	2.2085	2.13	.1174
18	.1372	.1372	.1029		2.1125	1.9989	.1029
19	.1372	.1372	.1372	.0857	.0819	.1029	.12
20	.1543	.1372	.1372	.0857	.0983	.1029	.12
21	.1372	.1372	.1372	.0857	.0983	.0857	.1029
22	.1372	.1372	.1372	.0857	.0983	.0857	.1029
23	.12	.1029	.1372	.0857	.0983	.0857	.0857
24	1.8351	1.9826	1.8679	.1029	.0876	.0838	1.6385
Max	2.1956	2.3922	2.3102	2.3758	2.2085	2.4249	2.0972
Min	.0686	.0671	.0838	.0671	.0686	.0838	.0671
Avg	1.0910	.9658	.9865	.7446	.6988	.8107	.7950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 203 / 11 KV 4TH SONSAI FEEDER NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0686	.0514	.0686	.0701	.104	.0514
2	.1029	.0514	.0514	.0686	.0701	.0867	.0514
3	.1029	.0686	.0514	.0686	.0701	.0867	.0514
4	.1029	.0686	.0514	.0686	.0351	.0693	.0514
5	.0857	.0514	.0514		.0343	.0693	.0514
6	.0857	.0686	.0343	.0686	.0343	.0693	.0343
7	.1029	.0686	.0514	.0686	.0686	.0693	.0514
8	.1029	.0686	.0514	.0857	.0686	.0514	.0514
9	.0343	.0343	.0343	.0343	.0335	.0514	.0514
10		.0351	.0701	.0876	.0335	.0514	.0503
11		.0526	.1052	.0701	.0686	.0514	.1006
12		.1029	.0701	.0857	.0514	.0514	.1017
13		.1029	.0686	.0857	.0857	.0514	.0509
14		.1029	.0857	.0857	.0514	.0514	.0857
15	.0857		.1029	.12	.0686	.0514	.0686
16	.0686		.1006	.1174	.12	.0686	.0686
17	.0343				.0343	.0514	.0514
18	.0343		.0686	.0343	.0343	.0514	.0514
19	.0343	.0686	.0686	.0514	.0343	.0514	.0343
20	.0343	.0686	.0686	.0514	.0514	.0514	.0343
21	.0686	.0686	.0686	.0514	.0514	.0514	.0514
22	.0857	.0686	.0686	.1029	.0514	.0514	.0686
23	.1029	.0686	.0686	.0857	.0686	.0514	.0857
24	.0857	.0857	.4115	.0686	.0876	.0867	.0514
Max	.1029	.1029	.4115	.12	.12	.104	.1017
Min	.0343	.0343	.0343	.0343	.0335	.0514	.0343
Avg	.0767	.0687	.0806	.0741	.0574	.0617	.0584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 204 / 11KV M WADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.5487	.5487	.5487	.5121	.5487	.5487
2	.5487	.5121	.5487	.5487	.4938	.5487	.5487
3	.5487	.5121	.5121	.5487	.4938	.5487	.5487
4	.5487	.5487	.5121	.5487	.4854	.5487	.5487
5	.567	.5853	.5487		.5415	.567	.5487
6	.7133	.6219	.6219	.7682			.695
7	.7133	.6584	.695	.7316	.7468	.7133	.7316
8	.6584	.5487	.5487	.6401	.5121	.5792	.5853
9	.5487	.5487	.4755	.6036	.5853	.5304	.4588
10		.5228	.5228	.4481	.4525	.5304	.4668
11		.4668	.4668	.5041	.4887	.5304	.4481
12		.4854	.4805	.5853	.4706	.5487	.5228
13		.5304	.5729	.5853	.5068	.5487	.4706
14		.6036	.4805	.5487	.4887	.5304	.5249
15		.5487	.5121	.4572	.4887	.5121	.4706
16	.5121	.5415	.5121	.5041	.4887	.5121	.4755
17	.5487	.4668		.4854	.5973	.5121	.4572
18	.5853		.5121		.5792	.5487	.4024
19	.695	.5853	.695	.6722	.6154	.6584	.6219
20	.8413	.695	.7316	.7964	.8688	.7682	.8048
21	.7316	.8413	.695	.7421	.7964	.7316	.7316
22	.695	.7316	.6219	.6878	.7421		.6584
23	.6219	.695	.5853	.5792	.6154	.6219	.5487
24	.5853	.5853	.5853	.5487	.5487	.567	.5487
Max	.8413	.8413	.7316	.7964	.8688	.7682	.8048
Min	.5121	.4668	.4668	.4481	.4525	.5121	.4024
Avg	.6239	.5819	.5646	.5947	.5704	.5775	.5570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 205 / 11 KV RAMAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.491	1.587	1.8023		.0838	.1006	1.4746
2	1.4582	1.587	1.8023		.0655	.1006	1.4746
3	1.4419	1.6032	1.8023	.0857	.0655	.0838	1.4746
4	1.3927	1.7328	1.8023	.0857	.0655	.0838	1.4746
5	1.3763	1.8785	1.8023	.0857	.0655	.0838	1.4746
6	1.5238	2.0567	1.9662	.0857	.081	.1006	1.6385
7	1.8023	2.17	2.0317	.0857	.081	.1006	1.8023
8	1.8351	2.1376	2.1136	.1029	.0648	.096	1.9334
9	1.917	2.1214	1.9052	.0857	.081		1.8515
10		.0655	.0671	.0671	.0781		.0503
11		.4096	.0819	2.4478	2.3266		.0671
12		.1006	.0819	2.5774	2.4453		.0655
13		.1006	.0819	2.2891	2.2405	2.4577	.0983
14		.1006	.0819	2.2382	2.1214	2.2939	.0838
15	.0857	.0819	.0838	1.7436		2.13	.1006
16	.0857	.1147	.0838	2.0454	2.0243	2.0317	.0838
17	.0857	.0819		2.0957	2.1214	1.9334	.0819
18	.0857		.1029		1.9498	1.8679	.0857
19	.1029	.1029	.0857	.0857	.0983	.1029	.1029
20	.12	.12	.0857	.0819	.0983	.1029	.12
21	.12	.12	.0686	.0819	.0983	.1029	.12
22	.12	.12	.0857	.0819	.0983	.1029	.12
23	.1029	.12	.0857	.0819	.0819	.0857	.1029
24	1.491	1.5546	1.8023	.0857	.0838	.0838	1.4746
Max	1.917	2.17	2.1136	2.5774	2.4453	2.4577	1.9334
Min	.0857	.0655	.0671	.0671	.0648	.0838	.0503
Avg	.8757	.8725	.8655	.7914	.7183	.7023	.7232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 206 / 11 KV CHINCHNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0983	.0857	.0857	.9831	1.0159	.8192	.0857
2	.0983	.0857	.0857	.9831	.9831	.8192	.0857
3	.0983	.0857	.0857	.9831	1.0059	.852	.0857
4	.0983	.0857	.0857	.9831	.9724	.852	.0857
5	.0983	.1029	.0857		.9892	.8848	.1029
6	.0983	.1029	.12	.9175	1.0395	.9012	.1029
7	.1311	.12	.12	1.0322	1.1065	1.1305	.1372
8	.1147	.12	.12	1.065	1.2125	1.1717	
9	.0983	.1029	.0686	1.0486	1.1633	1.1961	.1029
10		.0983	.1174	.0503	.0781	.1372	.1006
11		1.8187	1.8778	.0671	.0781	.1372	1.4754
12		1.9109	2.0287	.0686	.0937	.1372	1.6549
13		2.0405	2.0119	.0686	.0781	.1372	1.7532
14		1.9757	1.9334	.0686	.0781	.1029	1.643
15	1.7368	1.9006	1.9334	.0671	.0937	.1029	1.6263
16	1.8351	2.1792	1.917	.0838	.0781	.1029	1.6766
17	1.8842	2.0972		.1006	.1094	.1029	1.5729
18	1.8515	1.704	1.5729		.096		1.491
19	.12	.12	.1372	.1006	.096	.12	.1029
20	.12	.12	.1372	.1134	.096	.1029	.1029
21	.12	.12	.1029	.0972	.096	.1029	.1029
22	.1029	.12	.1029	.0972	.096	.1029	.0857
23	.1029	.1029	.1029	.081	.064	.1029	.0857
24	.0983	.0857	.1029	1.065	1.065	.7701	.0857
Max	1.8842	2.1792	2.0287	1.065	1.2125	1.1961	1.7532
Min	.0983	.0857	.0686	.0503	.064	.1029	.0857
Avg	.4687	.7202	.6494	.4602	.4910	.4734	.6238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 207 / 11 KV AMBAK AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.1715	.2058	.9831	1.3375	1.1568	.1715
2	.1341	.1543	.2058	.9831	1.2689	1.1568	.1715
3	.1341	.1543	.2058	.9831	1.2174	1.1736	.1715
4	.1341	.1715	.2058	.9831	1.1736	1.1736	.1715
5	.1509	.2058	.2058		1.1736	1.1904	.1715
6	.1844	.2229	.2058	.8848	1.2407	1.2742	.1715
7	.1844	.2401	.1886	1.065	1.4922	1.5089	.1715
8	.1844	.2401	.1886		1.6095	1.6057	.1715
9	.1174	.1715	.1715		1.5089	1.4419	.1715
10		.1677	.1402	.0686	.0671	.1372	.1341
11		1.7772	1.8519	.0686	.0655	.1372	1.8778
12		1.9784	2.2634	.0686	.213	.1372	1.9784
13		1.9448	2.0062		.0819	.1372	2.2291
14		1.9204		.0671	.1147	.1372	2.0919
15	1.8399	1.8861	2.1776	.0838	.1311	.1715	1.989
16	1.9062	2.2291	1.7604		.1638	.2058	2.2405
17	1.9227	2.2119		.1372	.1638	.2058	1.8275
18	1.8896	2.0576	1.5729		.1966	.2058	1.7772
19	.1715	.1372	.1715	.1715	.16	.2058	.2058
20	.2058	.1372	.1715	.1677	.16	.2058	.2058
21	.2058	.1715	.1715	.1677	.16	.2058	.1715
22	.1886	.1715	.1715	.1509	.1475	.2058	.1715
23	.1886	.2058	.1715	.1509	.1311	.2058	.1715
24	.1509	.1715		1.1469	1.3032	1.1233	.1715
Max	1.9227	2.2291	2.2634	1.1469	1.6095	1.6057	2.2405
Min	.1174	.1372	.1402	.0671	.0655	.1372	.1341
Avg	.5278	.7875	.6864	.4629	.6367	.6379	.7828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 201 / 11 KV WINE PARK 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2452				.2006	.2263
2	.1886	.2263				.1898	.2263
3	.1886	.2263				.218	.2263
4	.1886	.2263				.2229	.1943
5	.1886	.2263				.2229	.2263
6	.1886	.2263				.2254	.3772
7	.1886	.2263				.2229	.679
8	.1698	.3018				.5487	.7545
9		.5658		.9808		1.7353	1.2071
10			.9431	.6602	.6036		
11			1.3203	.7545	1.1317		
12			1.5089	.2652	.9808		
13			.3018	1.4335	.8299		
14			1.5089	1.7541	.679		
15			1.5089	1.5278	.7733		
16			.8488	.8488	.9054		
17			.9431	.3584	.9054		
18	.2263		.9054	.7545	.724	.679	
19	.2263			.3429	.2134	.6036	
20	.2263			.2263	.1829	.3961	
21	.2263			.3772	.1593	.2263	
22	.1886			.2263	.1852	.2263	
23	.2452			.2263	.1829	.2452	
24	.2263	.2452	.0943		.2263	.2056	.2263
Max	.2452	.5658	1.5089	1.7541	1.1317	1.7353	1.2071
Min	.1698	.2263	.0943	.2263	.1593	.1898	.1943
Avg	.2049	.2716	.9884	.7158	.5789	.3980	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 202 / 11 KV ANDHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.5684				.4527	1.7532
2	1.2803	1.5524				.4338	1.7532
3	1.2803	1.5524				.4338	1.7695
4	1.2803	1.5684				.4904	1.7652
5	1.2803					.5281	1.8187
6	1.4083					.6036	1.9498
7	1.7924					.6036	2.2939
8	1.9662					.6602	2.5606
9		2.7046		.5041		.4715	2.4646
10			.5281	.6036	.6036		
11			.5658	2.8509	3.3951		
12			.5281	2.8012	2.9165		
13			.5975	2.7018	2.8502		
14			.5601	2.6023	2.8166		
15			.5658	2.4413	2.7366		
16			.5658	2.3703	2.5911		
17			.5601	2.4034	2.5888		
18	.4527		.5228	2.2672	2.3967	1.9595	
19	.5281			.5281	.4527	.5281	
20	.5658			.5658	.4904	.5281	
21	.6036			.6036	.4527	.5281	
22	.5281			.5281	.4904	.4904	
23	.4715			.415	.4715	.4715	
24	1.2803	1.6385	1.8351		.4527	.4338	1.6804
Max	1.9662	2.7046	1.8351	2.8509	3.3951	1.9595	2.5606
Min	.4527	1.5524	.5228	.415	.4527	.4338	1.6804
Avg	1.0666	1.7641	.6829	1.6124	1.7137	.6011	1.9809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 203 / 11KV ANDHALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3734				.4108	.4527
2	.3292	.3547				.3921	.3961
3	.3292	.3547				.3734	.3772
4	.3361	.3547				.4108	.3772
5	.3772	.3921				.4481	.3772
6	.4904	.4854				.5415	.415
7	.4715	.4527				.5228	.6036
8	.3772	.4527				.4338	.4706
9		.4715		.2835		.4904	.4715
10			.4527	.2947	.3018		
11			.3544	.3155	.3018		
12			.3544	.3121	.3292		
13			.3544	.3121	.3658		
14			.362	.3155	.4706		
15			.362	.3121	.4904		
16			.3258	.3155	.5281		
17			.4115	.3155	.4527		
18	.3721		.3429	.3856	.4001	.5281	
19	.4527			.439	.567	.6224	
20	.5281			.543	.5316	.6413	
21	.5281			.462	.4961	.6036	
22	.4527			.4024	.4681	.4904	
23	.4527			.3734	.4075	.4527	
24	.3258	.3772	.3772		.3734	.4108	.4715
Max	.5281	.4854	.4527	.543	.567	.6413	.6036
Min	.3258	.3547	.3258	.2835	.3018	.3734	.3772
Avg	.4101	.4069	.3697	.3588	.4323	.4858	.4413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 204 / 11KV BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144	.144			.4321	.4481	.16
2	.144	.144			.4321	.4321	.16
3	.144	.144			.4321	.4481	.16
4	.144	.144			.4321	.4801	.16
5	.144	.16			.4801	.5761	.16
6	.192	.192			.6882	.7202	.176
7	.208	.192			1.0883	.8802	.192
8	.112	.16			1.1683	1.1043	.16
9		.128		1.0562	1.1363	1.1043	.128
10			.16	.192	.096		
11			1.2803	.128	.112		
12			1.3603	.144	.128		
13			1.2483	.128	.128		
14			.9282	.128	.144		
15			1.0242	.144			
16			1.1043	.144			
17			1.0402	.192	.144		
18	1.0722		.8002	.144	.176		
19	.144			.208	.16		
20	.16			.2401	.192	.208	
21	.192			.2241	.192	.2241	
22	.192			.192	.192		
23	.176		1.3603	.4321	.16	.192	
24	.144	.144	.16			.4481	.16
Max	1.0722	.192	1.3603	1.0562	1.1683	1.1043	.192
Min	.112	.128	.16	.128	.096	.192	.128
Avg	.2208	.1552	.9515	.2464	.3864	.5589	.1616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 205 / 11 KV MORALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1107				1.3283	.112
2	.112	.0949				1.3283	.112
3	.112	.0949				1.3443	.112
4	.112	.096				1.3763	.112
5	.112	.1107				1.4403	.112
6	.144	.1423				1.4706	.112
7	.16	.176				1.5023	1.3923
8	.144	.1739				1.0753	.128
9		.1581		1.3923		1.0911	.144
10			.144	.128	.096		
11			1.4563	.112	.0983		
12			1.3923	.112	.1147		
13			1.3283	.112	.1311		
14			1.1363	.096	.1475		
15			1.1363	.112			
16			1.1683	.096			
17				.16	.1311		
18	1.2963		.9922	.128	.144	.08	
19	.128			.16	.16	.16	
20	.144			.16	.112	.16	
21	.144			.16	.112	.144	
22	.112			.16	.128	.128	
23	.112		1.0883	.144	.112	.112	
24	.112	.112	.144		1.0242	1.3123	.112
Max	1.2963	.176	1.4563	1.3923	1.0242	1.5023	1.3923
Min	.112	.0949	.144	.096	.096	.08	.112
Avg	.2038	.1270	.9986	.2155	.1931	.8783	.2448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 206 / 11KV LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197				.5847	.5788
2	.197				.5847	.5788
3	.197				.5847	.5788
4	.197				.5658	.5788
5	.197				.5847	.5788
6	.197				.5847	
7	.3658				.5847	.8962
8	.5281				.8299	
9	.547		.5601		.679	
10			.7733			
11			.8488			
12		.7842	.8299			
13		.8215	.8299			
14		.8488	.8299	.0013		
15		.8299	.8299	.7842		
16		.811	.8299	.7842		
Max	.547	.8488	.8488	.7842	.8299	.8962
Min	.197	.7842	.5601	.0013	.5658	.5788
Avg	.2914	.8191	.7915	.5232	.6203	.6317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 207 / 11 KV Kranti LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715				.1734	.1734
2	.1715				.1734	.1734
3	.1715				.1734	.1734
4	.1715				.1734	.1734
5	.1886				.1734	.1734
6	.1886				.1734	.1734
7	.1886				.1734	.208
8	.1886				.1734	.1886
9	.1715		.0057		.1907	.1886
10		.1886		.1886		
11		.0002		.1886		
12		.0886	.1734	.1886		
13		.0876	.1907	.1886		
14		.2054	.1928	.1886		
15		.2054	.1928	.1907		
16		.2054	.1907	.1907		
Max	.1886	.2054	.1928	.1907	.1907	.208
Min	.1715	.0002	.0057	.1886	.1734	.1734
Avg	.1791	.1402	.1577	.1892	.1753	.1806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 401 / 33 KV SOOTGIRANI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5123	1.6804				1.5844	1.5844
2	1.5684	1.6804				1.5844	1.5844
3	1.5684	1.5684				1.5844	1.4712
4	1.6244	1.5684				1.5844	1.4712
5	1.5684	1.5684				1.5844	1.4712
6	1.6244	1.5684				1.5844	1.5684
7	1.4003	1.5684				1.4712	
8	1.5123	1.6804				1.4712	1.5684
9		1.4563		1.5844		1.358	1.5684
10			1.4563	1.4712	1.4712		
11			1.5123	1.6975	1.7924		
12			1.4563	1.358	1.4563		
13			1.5684	1.5844	1.4563		
14			1.6804	1.5684	1.3443		
15			1.5684	1.6975	1.4563		
16			1.5684	1.5844	1.7924		
17			1.5684	1.2449	1.5684		
18	1.3443		1.5684	1.2449	1.4712	1.4712	
19	1.4563			1.1317	1.6975	1.4563	
20	1.4563			1.2449	1.5844	1.4563	
21	1.4563			1.3014	1.4712	1.358	
22	1.5684			1.358	1.4712	1.4563	
23	1.6804			1.5844	1.358	1.5844	
24	1.5123	1.6804	1.6804		1.5278	1.5844	1.6975
Max	1.6804	1.6804	1.6804	1.6975	1.7924	1.5844	1.6975
Min	1.3443	1.4563	1.4563	1.1317	1.3443	1.358	1.4712
Avg	1.5235	1.6020	1.5628	1.4437	1.5279	1.5109	1.5539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 201 / 11 KV PADLI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0282	.0274	.0305	.9259	.8124	1.0562	.0305
2	.0282	.0267	.0305	.8951	.8124	1.0562	.0305
3	.029	.0267	.0305	.8951	.8124	1.0242	.0305
4	.029	.029	.0305	.8025	.8436	1.0242	.0305
5	.0293	.0297	.0305	.8025	.8642	1.0402	.0305
6	.0297	.0297	.0305	.8333	.9259	1.1363	.0305
7	.0297	.0297	.0305	.8951	1.3426	1.3923	.0305
8	.029	.0446	.0305	1.1574	1.3889	1.5043	.0324
9		.0446	.0305	1.1728	1.3889	1.4327	.0324
10	.0305	.0446	.029	.0309	.0423	.0305	.0305
11	1.7071	2.0062	2.0243	.0309	.0423	.0305	1.9204
12	1.9509	1.9753	2.1052	.0309	.0282	.0305	2.1338
13	1.89	1.9753	2.0309	.0305	.029	.0305	2.1338
14		1.9753	2.0891	.0305	.029	.0305	2.0424
15		1.8827	1.9757	.0297	.029	.0305	1.8595
16		1.8519	2.0729	.0305	.029	.0324	1.6766
17	1.781	1.6766	1.3923	.0305	.04	.0305	1.5432
18	1.6716	1.6975	1.2651	.0297	.0372	.0305	1.5432
19	.0271	.0309	.044	.0297	.0267	.0305	.0293
20	.0282	.0305	.0282	.0297	.0248	.0305	.0293
21	.0297	.0305	.0282	.0297	.0259	.0305	.0293
22	.0446	.0305	.029	.0297	.0267	.0305	.0297
23	.029	.0305	.029	.0297	.0274	.0305	.0297
24	.029	.0282	.0305	1.358	.8886	1.004	.0305
Max	1.9509	2.0062	2.1052	1.358	1.3889	1.5043	2.1338
Min	.0271	.0267	.0282	.0297	.0248	.0305	.0293
Avg	.4725	.6481	.6437	.4233	.4382	.5041	.6391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 202 / 11 SONSAL GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5281	.5068		.439	.5487	.5068
2	.5068	.5281	.5068		.439	.5281	.5068
3	.5068	.5281	.5068		.439	.5281	.5068
4	.5068	.5281	.5068		.439	.5281	.5068
5	.543	.5658	.543		.4755	.547	.5068
6	.5792	.6161	.6154		.5121	.6535	.543
7	.6154	.6099	.5792	.2195	.6154	.6283	.6154
8	.5068	.5611	.543	.2534	.4887	.5487	.5121
9	.439	.4706	.4706	.2353	.4525	.5487	.543
10	.439	.4344	.5068	.5973	.4344	.543	.5121
11	.439	.4344	.4706	.543	.4163	.4706	.439
12	.439	.4344	.4755	.5792	.4344	.4755	.4344
13	.439	.4344	.499	.5068	.4344	.4344	.5068
14		.4344	.499	.4706	.4525	.4706	.4706
15		.4344	.499	.4755	.4525	.4706	.4344
16		.4525	.4755	.4755	.4525	.4706	.5068
17	.4252	.4344	.567	.5487	.4656	.4344	.4525
18	.4207	.4344	.4525	.5487	.3761	.4344	.4525
19	.6468	.5068	.5068	.5973	.6219	.543	.6878
20	.7282	.6878	.6878		.7577	.6878	.7421
21	.6602	.6878	.6878	.6697	.7282	.6878	.724
22	.6602	.6516	.6878	.6283	.6979	.6516	.6516
23	.6036	.543	.5792	.5544	.6602	.6154	.6154
24	.543	.5281	.5068	.5068	.4805	.6224	.543
Max	.7282	.6878	.6878	.6697	.7577	.6878	.7421
Min	.4207	.4344	.4525	.2195	.3761	.4344	.4344
Avg	.5312	.5195	.5366	.4947	.5069	.5446	.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 203 / 11 KV SONKIRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2651	1.4091	1.1336	.0594	.0423	.0518	.9717
2	1.2651	1.3927	1.1336	.0594	.0423	.0533	.9717
3	1.2651	1.3927	1.1336	.061	.0423	.0549	.9717
4	1.2651	1.3927	1.1336	.061	.0423	.0549	.9717
5	1.3283	1.4091	1.1336	.061	.0423	.0572	1.0364
6	1.3916	1.5074	1.2308	.0594	.0423	.0587	1.1012
7	1.3916	1.6221	1.4419	.0587	.0423	.0572	1.2308
8	1.4864	1.6549	1.5546	.0579		.0442	1.4089
9	1.4548	1.4232	1.587	.0579	.0579	.0648	1.3603
10	.061	.0446	.0594	.0579	.0579	.0648	.0648
11	.0648	.0434	.0594	1.3108	1.2651	1.5546	.0648
12	.0648	.0434	.0594	1.3763	1.7394	1.6032	.0648
13	.0648	.0587	.0572		1.7394	1.6032	.0648
14		.0587	.0556	1.3763	1.5813	1.668	.0648
15		.0587	.0564	1.3599	1.5813	1.6356	.0648
16		.0579	.0572	1.3123	1.5813	1.587	.0648
17	.0503	.0648	.0533	1.3123	1.5364	1.5708	.0734
18	.0591	.0648	.0564	1.2163	1.4899	1.4575	.088
19	.0564	.0648	.0594	1.2163	.0412	.0648	.0743
20	.0533	.0648	.0594	.064	.0503	.0648	.0743
21	.0541	.0648	.0587	.0434	.0457	.0648	.0594
22	.0572	.0648	.0579	.0423	.0412	.0648	.0594
23	.0587	.0648	.0579	.0423	.0427	.0648	.0587
24	1.2334	1.4089	1.1336	.0579	.0423	.0472	.9717
Max	1.4864	1.6549	1.587	1.3763	1.7394	1.668	1.4089
Min	.0503	.0434	.0533	.0423	.0412	.0442	.0587
Avg	.6662	.6430	.5593	.4923	.5735	.5672	.4974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 201 / 11 KV KADEPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1494	.1478		1.4419	1.6644	.1097
2	.1075	.1463	.1463		1.4419	1.6644	.1097
3	.0716	.1463	.1478		1.5074	1.6004	.1097
4	.0724	.1463	1.6834		1.5074	1.6644	.1478
5	.0732	.1463	.1791		1.6385	1.7284	.1478
6	.1494	.2241	.1772		1.704	1.7924	.1989
7	.1494	.2218	.1791		2.0972	2.3594	.2058
8	.1494	.2218	.197		2.2283	2.3594	.1402
9	.1478	.2195	.1907		2.3594	2.3045	.2035
10	.1989	.2401	.1612		.2225	.1265	.1677
11	2.9492	2.652	3.219		.2058	.1326	2.8675
12	2.9447	3.1131	3.219		.1448	.1402	2.8182
13	2.9797	3.315	3.0178	.1357	.1086	.2103	2.8509
14		3.1131	2.9835	.1341	.1448	.1357	2.8841
15		3.1161	3.0178	.2126	.1448	.2126	2.9508
16		3.1131	2.1125	.2126	.2172	.1463	2.7681
17	3.0498	3.2278	2.1765	.1402	.1372	.1387	2.652
18	2.7854	2.9172	2.0485	.1387	.1494	.2103	2.5232
19	.2035	.2012	.1433	.1235	.2195	.2195	.1463
20	.208	.181	.2012	.1357	.2172	.2195	.1478
21	.1402	.1848	.1341	.1402	.1433	.2103	.1478
22	.1448	.1848	.1326	.1417	.1433	.2172	.1402
23	.1463	.1478	.1341	.1387	.1463	.2218	.1463
24	.1387	.1494	.1463		1.3763	1.5181	.1433
Max	3.0498	3.315	3.219	.2126	2.3594	2.3594	2.9508
Min	.0716	.1463	.1326	.1235	.1086	.1265	.1097
Avg	.8055	1.1449	1.0790	.1503	.8186	.8832	1.0303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 203 / 11 KV WANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2651	1.3108	1.7924	.0732	.1311	.1402	1.3283
2	1.1873	1.2955	1.7924	.0724	.1372	.1402	1.2651
3	1.1248	1.2955	1.8138	.0716	.1372	.1387	1.3283
4	1.1873	1.3108	1.8244	.0724	.1372	.1402	1.3916
5	1.2346	1.4419	1.8122	.0724	.1372	.1402	1.4548
6	1.3443	1.5074	1.8435	.1463	.1402	.1433	1.6667
7	1.8564	1.5181	2.2565	.1433	.2149	.1417	1.8747
8	1.9204	1.8785	2.2885	.1402	.2103	.1448	2.0241
9	.0633	1.8138	2.3365	.2103	.2012	.2149	1.9845
10	.1296	.1265	.1715	.1966	.1402	.2126	.1677
11	.1387	.1357	.2172	2.2024	2.1125	2.2405	.1612
12		.3856	.2172	2.2939	2.332	2.556	.1638
13	.1341	.1372	.2126	2.1376	2.4326	2.4615	.1619
14	.1143	.1402	.1372	2.2283	2.3685	2.1765	.1006
15	.1219	.1402	.1433	2.3594	2.3685	2.1125	.0995
16	.1158	.1753	.1311	2.3594	2.5263	2.2672	.0995
17	.1829	.2103	.1402	2.1125	2.4326	2.2405	.1402
18	.1341	.1791	.1387	1.8564	2.2405	1.9997	.1387
19	.1372	.1494	.1417	.1341	.1372	.1402	.1372
20	.1372	.1417	.1372	.192	.1326	.1417	.1227
21	.1372	.1433	.1387	.1966	.1311	.1402	.1052
22	.0663	.1433	.0678	.1341	.1387	.1417	.1063
23	.0655	.1433	.0686	.1311	.104	.1433	.1075
24	1.3443	1.3108	1.7604	.0701	.1311	.1417	1.3916
Max	1.9204	1.8785	2.3365	2.3594	2.5263	2.556	2.0241
Min	.0633	.1265	.0678	.0701	.104	.1387	.0995
Avg	.6149	.7098	.8993	.8169	.8823	.8525	.7301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 204 / 11 KV AMARAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1829	.181	.1663	.1867	.1991	.1848
2	.1629	.1829	.1829	.132	.168	.1791	.1646
3	.1629	.1829	.1829	.1307	.168	.197	.1646
4	.1629	.1867	.1619	.1494	.168	.2172	.1848
5	.1829	.2012	.2195	.168	.1867	.2353	.2033
6	.2218	.2195	.2587	.1867	.2241	.2561	.2587
7	.2195	.2328	.1848	.2353	.1494	.2686	.2328
8	.1753	.1867	.168	.1772	.2172	.1753	.197
9	.1417	.168	.156	.1772	.1734	.1753	.2254
10	.1492	.1492	.333	.1543	.1907	.1865	.1966
11	.1402	.1214	.1402	.156	.156	.1715	.1696
12	.1372	.1402	.1433	.1543	.1387	.156	.1696
13	.1227	.1433	.1433	.156	.1227	.1753	.1886
14	.1387	.1402	.1417	.1543	.1753	.1907	.208
15	.1214	.1433	.1595	.1753	.1595	.1928	.2103
16	.1341	.1417	.1174	.1696	.1578	.1928	.197
17	.1147	.1753	.1372	.156	.1387	.1734	.2149
18	.1357	.1791	.1387	.1753	.1907	.2204	.2103
19	.1907	.2103	.1753	.1928	.2601	.2629	.2835
20	.208	.2195	.2195	.2561	.2686	.2865	.2865
21	.2378	.1791	.2012	.2561	.2507	.2378	.2715
22	.2218	.2149	.1848	.2427	.2328	.2218	.2534
23	.2012	.1791	.1663	.2241	.1991	.2054	.2195
24	.1848	.1867	.181	.1663	.2075	.1991	.1848
Max	.2378	.2328	.333	.2561	.2686	.2865	.2865
Min	.1147	.1214	.1174	.1307	.1227	.156	.1646
Avg	.1688	.1778	.1783	.1797	.1871	.2073	.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 205 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1867	.1848	.2195	.2263	.2172	.2075
2	.1886	.1867	.1829	.2195	.1886	.181	.1886
3	.1886	.1867	.1848	.2012	.1886	.181	.1886
4	.2075	.1867	.1848	.2402	.2263	.2534	.2263
5	.2263	.2054	.2218	.2772	.2641	.2896	.2452
6	.2829	.2241	.2614	.3142	.3174	.3258	.3018
7	.3361	.2801	.2218	.2743	.3018	.3403	.3206
8	.2801	.2561	.1848	.208	.2561	.2658	.2402
9	.2896	.2195	.2126	.213	.2561	.2401	.1867
10	.2835	.2218	.0983	.2601	.3292	.2543	.2279
11	.2743	.3174	.3189	.1928	.2149	.2427	.2629
12	.2241	.1848	.2587	.1715	.2534	.2534	.2401
13	.1928	.1646	.2218	.1886	.2402	.2686	.213
14	.1928	.2172	.1867	.1867	.2328	.2614	.2321
15	.208	.2195	.2507	.2454	.2303	.2896	.2486
16	.197	.2126	.1865	.2401	.2303	.3012	.4475
17	.2103	.2149	.192	.2481	.2686	.298	.1989
18	.1734	.2149	.1715	.2126	.2614	.2353	.2058
19	.2896	.2534	.2103	.2454	.3222	.2987	.2218
20	.2926	.2195	.2715	.3292	.3155	.2987	.2614
21	.2641	.2218	.2427	.2957	.3012	.2829	.2957
22	.2641	.2195	.2263	.2829	.2561	.2641	.2829
23	.2241	.2218	.2218	.2263	.2507	.2641	.2587
24	.2452	.1886	.1867	.2195	.2263	.2303	.2263
Max	.3361	.3174	.3189	.3292	.3292	.3403	.4475
Min	.1734	.1646	.0983	.1715	.1886	.181	.1867
Avg	.2401	.2177	.2118	.238	.2566	.2641	.2470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 206 / 11 KV CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1463	.1646	1.3763	1.4083	1.6842	.1109
2	.1097	.1463	.1629	1.2163	1.4083	1.6194	.1109
3	.1097	.1463	.1663	1.2018	1.4083	1.6004	.1109
4	.1109	.1463	.1646	1.2955	1.5424	1.8138	.1478
5	.1478	.1463	.1829	1.2955	1.5364	1.9662	.1478
6	.1494	.2195	.2033	1.3763	1.6004	2.0317	.1848
7	.1478	.2218	.2218	1.6004	1.9662	2.4143	.1848
8	.1433	.2012	.2218	1.8785	2.1628	2.7496	.1448
9	.1663	.2195	.2033	1.6644	1.9845	2.5484	.1829
10	.208	.2033	.2195	.1357	.0686	.1219	.1734
11	2.5263	2.4996	2.3472	.1311	.1448	.104	2.5484
12	2.0729	2.6216	2.6825	.1372	.1734	.1448	2.5526
13	2.3685	2.652	2.4813	.2195	.1372	.1848	2.6216
14	2.2283	2.6216	2.2801	.2058	.1829	.1848	2.9835
15	2.1628	2.5911	2.3472	.2195	.1463	.2241	3.0849
16	2.1628	2.9569	1.6644	.1402	.1463	.1867	2.8841
17	.208	2.5194	1.7284	.2126	.1829	.1848	2.2939
18	.2103	2.1765	1.6194	.208	.1848	.181	1.9062
19	.2195	.1646	.1063	.1311	.1848	.1696	.1463
20	.2195	.1646	.1063	.1463	.1448	.1433	.1829
21	.1463	.1612	.1063	.1494	.1433	.1478	.1848
22	.1463	.1629	.1063	.1494	.1448	.1478	.1848
23	.1463	.1646	.104	.1463	.1017	.1463	.1848
24	.1463	.1463	.1629	1.3283	1.2803	1.6842	.1109
Max	2.5263	2.9569	2.6825	1.8785	2.1628	2.7496	3.0849
Min	.1097	.1463	.104	.1311	.0686	.104	.1109
Avg	.6819	.9750	.8231	.6902	.7660	.9327	.9737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 207 / 11 KV KADEPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2641	.3326	.3772	.2641	.3018	.3772
2	.3206	.2641	.3292	.2641	.2641	.3395	.3584
3	.3018	.2641	.3696	.2263	.2641	.3395	.3772
4	.3395	.2641	.3326	.3018	.3018	.3772	.415
5	.3584	.3018	.4066	.3395	.3772	.415	.4527
6	.4338	.4338	.4527	.3772	.4527	.4527	.5658
7	.415	.4338	.4435	.415	.4338	.415	.5281
8	.3395	.3395	.4294	.2829	.3772	.3734	.4715
9	.2829	.3018	.4294	.3018	.3395	.2987	.3475
10	.2835	.3189	.3696	.2896	.3018	.3395	.415
11	.2481	.3856	.4904	.3326	.2829	.3018	.3961
12	.2587	.3982	.4527	.2987	.2452	.3142	.3772
13	.3018	.3658	.415	.2801	.2772	.3206	.3772
14	.2896	.3142	.3584	.2987	.3395	.3018	.3395
15	.2427	.2987	.4527	.3174	.3018	.3018	.3361
16	.2452	.3142	.415	.3361	.2829	.3174	.2829
17	.2772	.3361	.415	.2743	.2957	.3206	.3361
18	.2865	.3696	.2452	.3292	.3361	.3658	.3696
19	.2987	.4108	.3475	.3584	.3734	.3961	.4251
20	.3018	.4481	.415	.3921	.3772	.415	.4527
21	.3395	.4435	.415		.415	.415	.4715
22	.3206	.4435	.4527	.3584	.4715	.3961	.4715
23	.2829	.2263	.415	.3395	.4338	.3961	.4108
24	.3395	.2641	.3772	.3961	.3018	.415	.3772
Max	.4338	.4481	.4904	.415	.4715	.4527	.5658
Min	.2427	.2263	.2452	.2263	.2452	.2987	.2829
Avg	.3103	.3419	.3984	.3255	.3379	.3596	.4055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 401 / 33 KV SAGARESHWAR SAHAKARI NON SHEDDABLE EHV INDUSTRIAL FEEDERS

SOO Feeder KV- 33 / OUTGOING

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1883	2.6029	2.4897	2.4897	2.2634	2.1502	2.4897
2	1.1317	2.6029	2.4897	2.3765	2.2634	2.1502	2.3765
3	1.1317	2.6029	2.4897	2.4897	2.2634	2.2068	2.3765
4	1.1317	2.6029	2.4897	2.4897	2.2634	2.2068	2.2634
5	1.1883	2.6029	2.4897	2.4897	2.2634	2.2634	2.1502
6	1.1883	2.6029	2.4897	2.5463	2.1502	2.2634	2.2068
7	1.1883	2.6029	2.4331	2.4897	2.2634	2.5463	2.2068
8	1.1883	2.6595	2.4331	2.5463	2.1502	2.4331	2.5463
9	2.2634	2.5463	2.7161	2.3765	2.4897	2.6595	2.4331
10	2.1502	2.1502	2.2634	2.2068	2.4331	2.32	2.3765
11	2.4897	2.4331	2.6595	2.3765	2.2634	2.32	2.5463
12	2.4897	2.6029	2.999	2.3765	2.4897	2.4897	2.6029
13	2.4897	2.6029	3.0556	2.4331	2.6029	2.6595	2.7161
14	2.3765	2.8292	3.1687	2.4897	2.5463	2.7161	2.8292
15	2.6029	2.8292	2.999	2.3765	2.7726	2.6029	2.999
16		2.8292	1.2449	2.32	2.4897	2.6595	2.4897
17	2.5463	2.7726	2.4331	2.1502	2.6595	2.7161	2.6595
18	2.4331	2.4897	2.4331	2.2068	2.32	2.5463	2.7161
19	2.1502	2.4331	2.32	1.9239	2.2634	2.6029	
20	2.2634		2.4331	1.9239	2.2634	2.5463	2.2634
21	2.3765	2.3765	2.32	2.037	2.1502	2.4331	2.2068
22	2.4897	2.4897	2.3765	1.9805	2.2068	2.4897	2.32
23	2.5463	2.4897	2.4897	2.2634	2.3765	2.3765	2.4897
24	1.1883	2.6029	2.5463	2.6029	2.32	2.5463	2.4897
Max	2.6029	2.8292	3.1687	2.6029	2.7726	2.7161	2.999
Min	1.1317	2.1502	1.2449	1.9239	2.1502	2.1502	2.1502
Avg	1.9214	2.5807	2.5109	2.3317	2.3553	2.4544	2.4676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 201 / 11 KV KADEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.9522	1.0608	.9431	1.0185	.9511	.9808
2	.9335	.9055	.9774		.9808	.924	.9242
3	.8962	.9149	.9511	.7922	.9431	.9145	.8962
4	.9054	.8962	.9979	.7545	.9431	.9979	.9242
5	.9431	.9709	1.0745	.8676	1.0562	1.0974	.9522
6	1.2071	1.2071	1.1706	.9808	1.2449	1.1643	1.2071
7	1.2696	1.2936	1.2567	1.0269	1.3306	1.2803	.6036
8	1.0719	1.2071	1.2803	.9335	1.1827	1.1458	1.1827
9	.9877	1.1458	1.1088	.7468	.9877	1.0242	1.0608
10	.8145	1.0608	1.0974		.9774	.961	1.0608
11	.9134	1.0242	1.0974	1.39	.9511	1.0242	1.086
12	.9877	1.0136	1.0974	1.2803	.924	1.0029	1.086
13	.9671	1.0719	1.0974	1.2071	.8779	1.0608	1.086
14	.985	1.0974	1.0974	1.2437	.9412	.9877	1.0974
15	.9877	1.086	1.1458	1.2071	.9877	.9877	1.0974
16	.9671	1.134	1.0059	1.1706	.9795	.9671	1.1765
17	1.0059	1.1088	1.0164	1.1706	.9511	1.0425	1.1222
18	.9671	1.0242	.985	1.1403	.9877	1.0608	1.0745
19	1.2883	1.1888	1.1222	1.2437	1.0974	1.2752	1.267
20	1.419	1.3032	1.4003	1.419	1.2936	1.4563	1.4784
21	1.4045	1.2803	1.2936	1.3443	1.2323	1.5278	1.4784
22	1.358	1.2197	1.1765	1.307	1.0974	1.3957	1.307
23	1.1576	1.134	1.0829	1.2323		1.1458	1.1576
24	1.0642	1.0374	1.086	1.0374	1.0562	.9979	1.0185
Max	1.419	1.3032	1.4003	1.419	1.3306	1.5278	1.4784
Min	.8145	.8962	.9511	.7468	.8779	.9145	.6036
Avg	1.0614	1.0949	1.1117	1.1109	1.0453	1.0997	1.0969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 202 / 11 KV MIDC NO.1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3213	1.3169	1.2894	1.3112	1.3253	1.3253	1.2894
2	1.3073	1.3253	1.2403		1.3073	1.3032	1.2894
3	1.2894	1.3253	1.1919	1.262	1.3073	1.3253	1.3213
4	1.2894	1.262	1.182	1.262	1.2757	1.3466	1.3073
5	1.2445	1.3253	1.182	1.262	1.2757	1.3253	1.2795
6	1.2757	1.2971	1.2308	1.262	1.2934	1.2894	1.2894
7	1.262	1.2894	1.2803	1.3611	1.3253	1.3394	1.2894
8	.8951	1.2357	1.3306	1.3611		1.3169	1.2894
9	.7876	1.262	1.4045	1.4632	1.3756	1.3306	1.3611
10	.7775	1.3169	1.4266	1.39	1.4415	1.4415	1.39
11	.7529	1.2803	1.4784	1.4415	1.4118	1.3253	1.4937
12		1.267	1.4784	1.4045	1.39	1.39	1.4045
13	.8109	1.2567	1.2403	1.39	1.4784	1.0974	1.3032
14	.8253	1.2936	1.267	1.3717	1.4632	1.4045	1.3306
15	.6615	1.2254	1.4045	1.39	1.4415	1.4003	1.4563
16	.6341	1.2567	1.4045	1.4784	1.4632	1.39	1.4937
17	.6893	1.2197	1.3676	1.4415	1.4415	1.3169	1.419
18	.7819	1.2437	1.4784	1.423	1.39	1.423	1.267
19	.6733	1.2437	1.4045	1.5123	1.39	1.3676	1.3169
20	.5441	1.267	1.39	1.4632	1.3672	1.3169	1.3169
21	1.182	1.2894	1.3756	1.3717	1.3969	1.3676	1.3756
22	1.1999	1.3169	1.3112	1.3253	1.39	1.3352	1.2757
23	1.1919	1.3676	1.2536	1.2715	1.3676	1.2894	1.2894
24	1.3213	1.2536	1.3394	1.3253	1.3253	1.3535	1.2894
Max	1.3213	1.3676	1.4784	1.5123	1.4784	1.4415	1.4937
Min	.5441	1.2197	1.182	1.262	1.2757	1.0974	1.267
Avg	.9877	1.2807	1.3313	1.3715	1.3758	1.3384	1.3391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 203 / 11 KV SHALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6518	1.7859	1.6644	.1294	.1307	.128	1.6324
2	1.6194	1.7124	1.9662		.1307	.1294	1.6164
3		1.6644	1.989	.1086	.1494	.1097	1.6004
4	1.8023	1.6484	1.9845	.1097	.1494	.1086	1.6164
5	1.9662	1.7166	2.1052	.1294	.168	.128	1.6324
6	2.0481	2.0972	2.2634	.168	.1867	.1494	1.749
7	2.3703	2.4413	2.3685	.2402	.2218	.1698	2.1382
8	2.6189	2.6023	2.4905	.1848	.1663	.1848	2.3594
9	2.3594	2.5724	2.4249	.1433	.1478	.1867	2.4741
10	.1267	.1109	.1254	.1448	.1509	.181	.128
11	.128	.1294	.1612	1.9595	2.0805	2.42	.1086
12	.1294	.128	.1791	2.1862	2.3758	2.6852	.1433
13	.128	.1267	.181	2.1628	2.9569	2.7831	.1463
14	.1478	.128	.1646	2.1792	2.7035	2.7515	.1448
15	.1463	.124	.1663	2.2611	2.4006	2.5526	.1463
16	.1478	.1214	.1663	2.2283	2.3805	2.4863	.1463
17	.1478	.1254	.1387	2.1628	2.2939	2.5194	.1448
18	.1848	.1448	.156	2.0645	2.17	2.4249	.1734
19	.1829	.1829	.1629	.1417	.1097	.1829	.2012
20	.1848	.2218	.2054	.1433	.1478	.2033	.1829
21	.1848	.2195	.1478	.1612	.1829	.1867	.1463
22	.1646	.181	.1494	.1463	.1848	.1848	.1478
23	.1478	.1829	.1494	.1494	.1463	.168	.1294
24	1.6842	1.7695	1.6644	.1307	.1307	.1267	1.6907
Max	2.6189	2.6023	2.4905	2.2611	2.9569	2.7831	2.4741
Min	.1267	.1109	.1254	.1086	.1097	.1086	.1086
Avg	.8814	.9224	.9656	.8450	.9111	.9646	.8583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 204 / 11 KV KADEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1663	.1829	.9488		1.0562	.2012
2	.1629	.1463	.1629		.9172	.9998	.2033
3	.1629	.1463	.1612		.8223	1.0814	.2012
4	.1646	.1478	.1829	.7827	.8322		.2033
5	.1829	.168	.2033	.823		1.3603	.2378
6	.2195	.2054	.2195	.8642	1.2003	1.6644	.2402
7	.2587	.2427	.2195	1.2803	1.8351		.3292
8	.2801	.2378	.1989	1.3599	1.8461		.3109
9	.2149	.2218	.2195	1.3283	1.8138	1.8564	.2957
10	.2012	.1829	.1478	.1402	.197	.1478	.2012
11		1.6385	1.704	.1267	.1791	.2012	1.3763
12	1.6804	1.9433	1.6385	.1267	.1829	.2195	1.5089
13	1.2654	1.9006	1.7814	.1448	.1478	.2149	2.2211
14	1.3283	1.7924	1.7814	.1448	.1463	.1829	2.8509
15	1.6964	1.704	1.6194	.1448	.1829	.1829	2.652
16	1.5813	1.6575	1.6194	.1448	.2218	.1848	2.3922
17	1.6644	1.5684	1.2346	.1578	.2195	.2561	2.3594
18	1.4864	1.5364	1.2346	.1696	.2172	.2801	2.1376
19	.2033	.1097	.2195	.2035	.2195	.2957	.2126
20	.2378	.1448	.1867	.2058	.2218	.3361	.2587
21	.2402	.1829	.1848	.1928	.2033	.2926	.2614
22	.2195	.2218	.1867	.1753	.1867	.2743	.2614
23	.2033	.2195	.1829	.1791	.1848	.2402	.2587
24	.181	.1829	.181	.9602	.9488	.9686	.2218
Max	1.6964	1.9433	1.7814	1.3599	1.8461	1.8564	2.8509
Min	.1629	.1097	.1478	.1267	.1463	.1478	.2012
Avg	.6094	.6945	.6522	.4820	.5876	.5855	.8915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 205 / 11 KV MIDC NO.2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4335	1.5089	1.4632	1.5844
2		1.3957	1.4146	1.3676	1.5278
3		1.3957	1.3203	1.39	1.6221
4		1.3203	1.1203	1.2936	1.6221
5		1.1694	1.0829	1.3169	1.5278
6		1.094	1.1016	1.7551	1.773
7		1.2449	1.1949	1.1088	1.5278
8		.9774	.7865	1.0082	1.5844
9		.7377	.9568	1.0349	1.2826
10		.8505	1.2323	1.1706	
11		1.0136	1.2071	1.6598	
12		1.0974	1.2936	1.5466	
13		1.3443	1.3443	1.6221	
14		1.7353	1.3676	1.3014	
15		1.7353	1.307	1.2637	
16		1.7353	1.2071	1.5844	
17		1.773	1.1576	1.3957	
18		1.8673	1.1827	1.2637	
19		1.4377	1.2197	1.2826	
20		1.4937	1.2803	1.0608	
21	1.5089	1.5844	1.3306	1.2071	
22	1.1203	1.6598	1.3535	1.3957	
23	1.6975	1.7164	1.448	1.2637	
24		1.5089	1.5466	1.5154	1.2071
Max	1.6975	1.8673	1.5466	1.7551	1.773
Min	1.1203	.7377	.7865	1.0082	1.2071
Avg	1.4422	1.3884	1.2485	1.3447	1.5259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 206 / 11 KV SHALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.3881	.415	.4066	.4251	.415	.3881
2	.4066	.3658	.3734		.4066	.3696	.3658
3	.3881	.3658	.3696	.3658	.4066	.3734	.3658
4	.3921	.4066	.4024	.3696	.3734	.4024	.4066
5	.4854	.439	.4344	.4108	.5228	.4344	.4435
6	.5975	.5729	.5121	.5228	.5975	.5121	.5487
7	.6283	.6099	.5487	.5544	.6099	.5487	.6283
8	.4344	.5121	.5175	.4298	.4887	.5175	.4024
9	.4075	.6283	.4755	.4207	.4854	.439	.4572
10	.5175	.5373	.4435	.3086	.4161	.3696	.4572
11	.4359	.4755	.4161	.3121	.394	.4024	.4961
12		.4435	.4557	.3155	.3658		.4252
13	.3681	.3658	.394	.3045	.3696	.394	.3582
14	.394	.3658	.394	.2896	.4066	.439	.362
15	.4477	.3155	.3814	.3224	.3658	.4572	.3856
16	.333	.2865		.3772	.3734	.4298	.3544
17	.4477	.3658	.3467	.3772	.4066	.4755	.4207
18	.4477	.5068	.3467	.3561	.4527	.5373	.431
19	.5729	.5853	.5144	.4607	.4805	.6219	.5014
20	.6584	.6283	.5601	.6089	.5121	.6653	.6584
21	.5729	.5975	.5228	.5731	.5792	.6401	.5914
22	.5544	.5658	.4854	.543	.5544	.567	.5228
23	.5175	.5175	.4108	.5304	.4755	.4938	.4481
24	.4435	.439	.4481	.4108	.4435	.4481	.4294
Max	.6584	.6283	.5601	.6089	.6099	.6653	.6584
Min	.333	.2865	.3467	.2896	.3658	.3696	.3544
Avg	.4721	.4702	.4421	.4161	.4547	.4762	.4520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 207 / 11 KV KHAMBALE-A AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8564	1.7124	1.8023	.112		.1478	1.7072
2	1.8233	1.7166	1.989		.132	.1494	1.6549
3	1.8233	1.6964	1.8884	.1109	.1509	.132	1.6385
4	1.9062	1.6804	1.9662	.1109	.1509	.1478	1.6712
5	1.989	1.7444	2.2708	.112	.1698	.1646	1.7204
6	2.1051	2.0481	2.3137	.112	.1698	.1698	1.8842
7	2.5194	2.6189	2.2497	.1509	.1698	.1848	2.0972
8	2.3205	2.4531	2.4006	.1509	.1886	.1829	2.2611
9	2.2708	2.5232	2.4531	.1132	.1698	.1663	2.3266
10	.1307	.1294	.132	.1086	.1307	.132	.0924
11	.1463	.1463	.132	2.304	2.2497		.132
12	.1848	.1848	.1509	2.42	2.4387	2.1963	.1509
13	.1848	.2012	.1698	2.3537	2.7526	2.4478	.1509
14	.1829	.1829	.132	2.3205	2.7854	2.7999	.1509
15	.1848	.2033	.132	2.2283	2.6406	2.8669	.1509
16	.1829	.2263	.1494	2.1792	2.5309	2.8841	.1494
17	.1848	.2263	.112	2.0317	2.4006	2.7515	.1698
18	.1829	.2427	.1509	1.917	2.3102	2.5194	.1886
19	.2054	.2402	.1132	.0914	.128	.1478	.1886
20	.2218	.2195	.1132	.0924	.1494	.112	.1886
21	.2218	.2172	.1132	.112	.1867	.1307	.1886
22	.2054	.1829	.132	.112	.2075	.128	.1509
23	.1848	.1848	.132	.1132	.2075	.1294	.1509
24	1.8896	1.5684	1.4746	.1132	.132	.1886	1.6876
Max	2.5194	2.6189	2.4531	2.42	2.7854	2.8841	2.3266
Min	.1307	.1294	.112	.0914	.128	.112	.0924
Avg	.9628	.9396	.9447	.8465	.9805	.9078	.8688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 208 / 11 KV MIDC NO 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9172	.7537	1.773	
2	.9602	.7209	1.6632	
3	.9602	.7362	1.5684	
4	.9995	.8048	1.4784	
5	1.0227	.7537	1.3535	
6	1.0513	.7186	1.2826	
7	1.0749	.9313	1.2936	
8	.8916	.9877	1.3443	
9	.8421	1.4335	.7282	
10	.5573	1.9616	1.307	1.134
11	.5357	1.9993	1.587	1.8861
12	.4089	1.922	1.4784	1.5089
13	.5639	1.8671	1.6032	1.4146
14	.3641	1.848	1.4146	1.7353
15	.3201	1.8298	1.6032	1.8861
16	.2608	1.5089	1.6975	1.9427
17	.2961	1.4045	.924	1.8861
18	.2538	1.3817	1.6032	1.1576
19	.3243	1.4045	1.3203	1.6975
20	.3921	1.4937	1.4146	1.358
21	.8192	1.4998		1.2136
22	.9877	1.5154		1.6975
23	.9877	1.6804		1.5466
24	.9014	.9313	1.6975	
Max	1.0749	1.9993	1.773	1.9427
Min	.2538	.7186	.7282	1.134
Avg	.6955	1.3370	1.4350	1.5760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 201 / 11 KV TONDOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4024	.394	.4251		.9831	2.7999	
7	.439	.4298	.4024	2.1548		3.0849	.4435
8	.4024		.4163	2.4646		3.083	.439
9	.4207	.3582	.4572	2.8166		3.0849	.3734
10	.3772	.3658	.3206	.2926		.3395	.3696
11	2.8509	3.3484	3.3913		.362	.3045	3.7342
12		3.4019	3.3482		.3326	.3142	3.8666
13	2.9172	3.6037			.3696	.3292	3.0807
14		2.8349			.3658	.3224	3.2065
15	2.8502	2.7435		.2743	.362	.3395	2.9874
16	2.6852	3.0178		.3475	.439	.5359	2.8292
17	2.6825	2.5339		.3292	.439	.4715	2.8006
18	2.2672	2.652		.439	.4344	.4656	
19	.3734	.3696		.4024	2.146		.4904
24	.3475		.2926		1.7532		.2743
Max	2.9172	3.6037	3.3913	2.8166	2.146	3.0849	3.8666
Min	.3475	.3582	.2926	.2743	.3326	.3045	.2743
Avg	1.4628	2.0041	1.1317	1.0579	.7261	1.1904	1.9150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 202 / 11 KV RAIGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	3.1786	2.4417	2.6825		.2743	.2481	
7	2.7854	2.713	3.1017	.2957	.2926	.2926	2.9569
8	3.0639	2.4417	2.8826	.2987	.3292	.2926	2.713
9	3.2769	2.5774	2.652	.2507	.3292	.2507	2.5888
10	.2622	.2347	.1865	.2534	.2957	.2561	.2321
11	.3018	.2035	.2195	2.0317	2.4143		.2683
12	.2926	.1677	.2263	2.3102	2.5194		
13	.2987	.2601		2.3922	2.652		
14	.3772	.2629		2.2939	2.5194		
15	.439	.2804		2.2939	2.4143	2.5774	.2713
16	.4481			2.0317	2.3868	2.713	.3018
17	.4435			1.9662	2.2542	2.6113	.443
18	.4435			1.7204	2.2131	2.5194	.4477
19	.3361	.3189		.2561	.2614		.4572
24	2.8018		2.0481		.2561		1.7436
Max	3.2769	2.713	3.1017	2.3922	2.652	2.713	2.9569
Min	.2622	.1677	.1865	.2507	.2561	.2481	.2321
Avg	1.2500	1.082	1.7499	1.4150	1.4275	1.3068	1.1294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 203 / 11 KV SOHOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.8131	.7468	.924		.924	.8962	
7	.8686	.9335	1.0269	.9054	.7947	.8962	.7682
8	.7392	.695	.9431	.8238	.7392	.7316	.679
9	.7023	.7762	.7468	.7947	.6838	.7023	.6348
10	.7087	.7468	.8488	.7207	.8063	.6805	.8402
11	.695	.6602	.7762	.7577	.7316	.6767	.7545
12	.7316	.7842	.695	.7762	.7316	.6447	.7468
13	.7316	.5658		.7392	.6089		.8488
14	.695	.6535		.7762	.6154		.8402
15	.7095	.7468		.2458	.6584	.823	.8316
16	.7762	.8316		.7577	.7164	.8871	
17	.8048	.9335		.7762	.788	.8488	.8402
18	.7964	.8316		.7947	.7392	.8316	.8488
19	.9145	.9431		.7762	.8779		.9145
24	.7577		.9335		.7207		.7164
Max	.9145	.9431	1.0269	.9054	.924	.8962	.9145
Min	.695	.5658	.695	.2458	.6089	.6447	.6348
Avg	.7629	.7749	.8618	.7419	.7424	.7835	.7895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 204 / 11 KV UPALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3441	.3688	.4668		1.9334	2.3472	
7	.3441	.4694	.4338		2.3266	2.2466	.4338
8	.3277	.4024	.3734	1.2929	2.3594	2.4478	.3403
9	.3441	.4191	.3772	1.4255	2.2119	2.4646	.3395
10	.3277	.3086	.2865	.2458	.218	.2561	.3018
11	1.9784	3.034	2.5019	.213	.2347	.3772	3.3608
12	2.2969	2.7343	2.6029	.213	.3018	.3292	3.3008
13	2.7999	2.7149		.1966	.3018	.3224	2.9874
14	2.5819	2.809		.1966	.3018	.3395	3.3008
15	2.6993	2.7435		.2458	.3185	.3018	2.7073
16	2.6658	2.8349		.2458	.3856	.3658	2.5873
17	2.5149	2.4832		.2458	.3353	.4066	2.7073
18	1.9951	2.452		.2622	.3185	.4207	2.452
19	.3353	.3921		1.6221	.3353		.3361
24	.3277		.3772		1.5729		.3475
Max	2.7999	3.034	2.6029	1.6221	2.3594	2.4646	3.3608
Min	.3277	.3086	.2865	.1966	.218	.2561	.3018
Avg	1.4589	1.7262	.9275	.5338	.8970	.9712	1.8216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 205 / 11 KV BOMBALEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	2.5069	2.3472	2.8292		.1802	.1509	
7	2.3922	2.6825	2.894	.2507	.213	.2012	2.0719
8	2.4249	2.5819	2.9235	.2801	.2294	.1677	2.1195
9	2.3594	2.431	2.8006	.2614	.1966	.1677	1.9951
10	.1326	.2204	.1478	.1802	.1341	.1791	1.8484
11	.1677	.1543	.1448	2.343	1.6095	2.4417	.1294
12	.1677	.1753	.1886	2.2939	2.2801	2.3868	.1509
13	.1677	.1791		2.2447	2.431	2.4078	.1494
14	.1677	.1829		2.1792	2.3472	2.3205	.1478
15	.1677	.181		2.2119	2.2131	2.079	.1494
16	.1509	.2195		2.1464	2.1963	1.9669	.1698
17	.1677	.2353		1.9334	2.0622	1.9669	.1867
18	.2012	.2743		1.917	2.1125	1.757	.2427
19	.2347	.2772		.1802	.1677		.2452
24	1.9334				.1311		1.4413
Max	2.5069	2.6825	2.9235	2.343	2.431	2.4417	2.1195
Min	.1326	.1543	.1448	.1802	.1311	.1509	.1294
Avg	.8895	.8673	1.7041	1.4171	1.2336	1.3995	.7891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / 33/11 KV BELAWADE S/STN

Feeder No / Name : 206 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.5359	.6224	.724		.6468	.7356	
7	.3142	.6224	.695	.0185	.6653	.7545	.7499
8	.3326	.6413	.7468	.0377	.6838	.7922	.6805
9	.7207	.7733	.7023	.0362	.6653	.7733	.6767
10	.679	.7167	.7356	.0185	.679	.6268	.924
11	1.0185	.8402	.7164		.2641	.6908	.6348
12	.9808	.7922	.7682		.2452	.6722	.7545
13	.7733	1.0269			.7356	.679	.7468
14	.7545	.924		.2218	.7167	.6401	.5281
15	.7922	.7392		.7577	.6979	.6413	.7468
16	.2829	.1829		.5175	.5281	.3511	.3734
Max	1.0185	1.0269	.7682	.7577	.7356	.7922	.924
Min	.2829	.1829	.695	.0185	.2452	.3511	.3734
Avg	.6531	.7165	.7269	.2297	.5934	.6688	.6816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 201 / 11 KV WANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.156	.1463	.1448	1.4089	1.491	1.5023	.181
2	.1387	.1307	.1267	1.4419	1.3443	1.4706	.1629
3	.1372	.1307	.1267	1.4089	1.2803	1.4529	.1448
4	.1372	.1132	.1267	1.4419	1.3599	1.406	.1448
5	.1696	.168	.1448		1.4419	1.4842	.1629
6	.2374	.2378	.181	1.4413	1.5238	1.6512	.2172
7	.3521	.2614	.2353	1.6221	1.7652	1.7901	.2715
8	.2321	.2801	.2896	1.6032	1.7859	1.8747	.2534
9	.1989	.2241	.2172	1.5565	1.8138	1.5089	.2534
10	.2347	.2195	.2172	.128	.197	.218	.2715
11	2.3975	2.3685	2.3644	.1448	.2353	.2172	2.4577
12	2.4413	2.4486	2.6379	.1463	.2353	.2172	2.5749
13	2.3158	2.4326	2.4905	.1646	.2561	.2172	2.5888
14	2.1628	2.4006	2.3644	.1646	.2561	.1991	2.4129
15	2.2131	2.1765	2.3922	.1463	.2402	.2353	2.5749
16	2.13	2.1125	2.1464	.168	.2587	.2353	2.6052
17	2.0645	2.1285	1.9498	.2054	.2587		2.4615
18	1.9524	1.9364			.2743	.2353	2.4615
19	.2328	.2254	.1991	.2614	.2743	.2534	.2303
20	.2195	.2254	.2195	.2614	.2715	.2534	.2328
21	.2378	.208	.1991	.2241	.2328	.2534	.2172
22	.2195	.1734	.1829	.2012	.2149	.2172	.2507
23	.1463	.156	.1646	.1829	.2149	.1991	.2149
24	.156	.1463	.1448	1.4413	1.4582	1.5181	.181
Max	2.4413	2.4486	2.6379	1.6221	1.8138	1.8747	2.6052
Min	.1372	.1132	.1267	.128	.197	.1991	.1448
Avg	.8701	.8771	.8376	.7166	.7785	.8091	.9803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 202 / 11 KV TADSAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4723	1.6278	.2896			1.1544
2	1.358	1.3763	1.576	.282			1.1227
3	1.3256	1.3603	1.5257				1.1069
4	1.2986	1.2651	1.6975				1.2651
5	1.3256	1.5223	1.6766				1.439
6	1.6137	1.7078	2.0687				1.6288
7	2.0005	2.2184	2.5819			.132	1.8976
8	1.9471		2.4478	.1158	.1457	.1467	1.9925
9	1.7471	2.3205	2.3137	.1143	.1781	.1614	1.7236
10	.2934	.4049	.3641	.1303	.3681	.3227	.3163
11	.421	.4382	.3944	.7287		1.7553	.3563
12	.421	.4908	.4508	.7935	1.7421	2.2613	.3887
13	.421	.4382	.4287	1.8884		2.1664	.4214
14	.4641	.4382	.4508	1.9044	.8345	2.119	.4268
15	.3932	.4908	.4681	1.9109	1.7246	2.0715	.4268
16	.4858	.5083	.4161	1.9006	.4451	2.0873	.4458
17	.4915	.5784	.4801	1.9044	.4729	2.0083	.4515
18	.5243	.6485	.5028	1.692	1.4882	1.8501	.442
19	.4641	.5784	.4458		.3715	.4161	.4531
20	.3841	.5434	.4334	.3932	.3567	.4161	.4111
21	.3841	.5083	.3155	.3441	.3227	.3988	.3906
22	.3768	.4557	.3067	.3041	.3081	.3467	.3658
23	.3277	.4207	.3909	.2881	.2934	.3294	.3125
24	1.3306	1.4746	1.6766	.2896		.2494	1.1702
Max	2.0005	2.3205	2.5819	1.9109	1.7421	2.2613	1.9925
Min	.2934	.4049	.3067	.1143	.1457	.132	.3125
Avg	.8821	.9418	1.0434	.8486	.6466	1.0688	.8379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 203 / 11 KV YERALA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8223	.8192	.7202	.0895	.0747	.0686	.6401
2	.8065	.6882	.7042	.0905	.0747	.0686	.6081
3	.7907	.6401	.6722	.1086	.0934	.0686	.5921
4	.7499	.583	.6562	.0914	.0934	.0678	.6081
5	.7343	.6327	.7042		.0924	.0848	.6562
6	.828	.7186	.7842	.1448	.1097	.1174	.7362
7	.9105	.8905	.8482	.1791	.2054	.1509	.7842
8	.8993	.9122	.8482	.1433	.1509	.1492	.8802
9	.8535	.828	.8002	.1267	.1494	.116	.8322
10	.1174	.1463	.1254	.128	.1698	.1357	.1267
11	.1433	.1829	.1433	.8381	.7811	1.0242	.1267
12	.128	.1646	.1433	.8855	.933	.9122	.128
13	.1463	.1463	.1448	.8802	1.0082	.9122	.1267
14	.1097	.128	.1463	.8802	1.0082	.8482	.1267
15	.1294	.128	.1463	.8436	.8962	.8802	.1086
16	.1307	.1463	.1463		.9602	.9442	.1463
17	.128	.1463	.1629		1.0202	.9282	.1448
18	.1646	.1463	.1463		.9069	.8962	.1463
19	.1646	.1646	.1448	.1254	.0876	.1433	.1086
20	.1463	.1646	.128	.1463	.0876	.1433	.1086
21	.1307	.1646	.1463	.112	.1052	.1254	.1097
22	.1463	.1463	.1448	.0914	.0876	.1254	.0905
23	.128	.128	.0732	.0934	.0693	.0895	.0914
24	.7907	.7537	.7611	.0914	.0732	.0693	.6401
Max	.9105	.9122	.8482	.8855	1.0202	1.0242	.8802
Min	.1097	.128	.0732	.0895	.0693	.0678	.0905
Avg	.4208	.3987	.3934	.3045	.3849	.3779	.3611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 204 / 11 KV AMBAK AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1581	.1543	.9831	.9922	.9646	.1372
2	.1372	.176	.1372	.933	.9282	.9646	.1372
3	.1357	.1475	.1372	.9488	.9717	.9374	.12
4	.1187	.1475	.1543	.9922	.9878	.9374	.12
5	.1696	.1802	.1715	1.0082	1.0202	.9568	.1372
6	.1844	.176	.1543	1.0402	1.0437	1.0526	.1543
7	.1844	.16	.1715	1.0402	1.1523	1.0822	.1715
8	.1658	.16	.1372	1.1174	1.1702	1.0974	.1372
9	.1492	.1638	.1372	1.1142	1.2323	1.0517	.1372
10	.1509	.1509	.12	.0838	.1147	.12	.1372
11	1.2498	1.2811	1.2955	.1147	.12	.1543	1.2186
12	1.2955	1.1405	1.3927	.0983	.1387	.1543	1.2334
13	1.2963	1.1561	1.5384	.0983	.1402	.1372	1.3123
14	1.3763	1.2186	1.4746	.096	.1595	.1372	1.3441
15	1.2803	1.1561	1.4419	.112	.1433	.1543	1.4074
16	1.3123	1.2342	1.4255	.1134	.1612	.1715	1.3283
17	1.3603	1.2967	1.3927	.1265	.1791	.1543	1.3435
18	1.3763	.2812	1.3117	.128	.1772	.1715	1.3916
19	.1581	.2058	.1341	.1311	.1949	.1543	.1475
20	.176	.1886	.1147	.1475	.1578	.1715	.1457
21	.1781	.1886	.1134	.1475	.156	.1715	.1638
22	.1581	.1715	.0972	.112	.104	.1543	.1619
23	.1581	.1715	.1147	.112	.1029	.1372	.1457
24	.1543	.1581	.1543	1.004	.9602	.9804	.12
Max	1.3763	1.2967	1.5384	1.1174	1.2323	1.0974	1.4074
Min	.1187	.1475	.0972	.0838	.1029	.12	.12
Avg	.5443	.4779	.5615	.4918	.5212	.5070	.5355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 205 / 11 KV HINGANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3757	1.4243	1.2967	.1475	.1781	.1543	1.2346
2	1.3599	1.3283	1.2654	.1492	.1619	.1543	1.2346
3	1.3279	1.3283	1.2498	.1526	.16	.1357	1.2037
4	1.2967	1.3117	1.2342	.1696	.176	.1357	1.1574
5	1.3889	1.3763	1.2654		.208	.1696	1.1883
6	1.6204	1.6164	1.5466	.213	.2294	.2347	1.4043
7	1.6918	1.7284	1.7966	.2267	.2458	.2347	1.5586
8	1.7223	1.8724	1.6091	.1802	.208	.2155	1.5586
9	1.6461	1.8501	1.781	.1638	.208	.2321	1.5278
10	.1696	.176	.1718	.1898	.213	.1844	.2006
11	.1966	.2713	.2454	1.6221	1.6404	1.4969	.213
12	.213	.2713	.2481	1.6876	1.5655	1.4815	.2294
13	.1943	.2374	.2328	1.6964	1.6004	1.5123	.2267
14	.2294	.2204	.2743	1.5971	1.7004	1.2191	.2267
15	.2458	.2543	.3045	1.5844	1.6518	1.358	.2622
16	.2591	.2713	.2865	1.5339	1.6194	1.6667	.2753
17	.2561	.2543	.2686	1.5684	1.3927	1.6204	.2622
18	.2561	.2204	.2865	1.5223	1.4575	1.6358	.3077
19	.2401	.2713	.2896	.2056	.2254	.1865	.2949
20	.2241	.2713	.2835	.2241	.2427	.2035	.2818
21	.2401	.2713	.2686	.2056	.208	.2204	.2652
22	.208	.2374	.2686	.192	.1886	.2035	.2429
23	.1581	.2204	.2149	.1943	.1715	.1865	.2105
24	1.3441	1.3283	1.3123	.1638	.1781	.1715	1.3735
Max	1.7223	1.8724	1.7966	1.6964	1.7004	1.6667	1.5586
Min	.1581	.176	.1718	.1475	.16	.1357	.2006
Avg	.7443	.7755	.7500	.6778	.6596	.6256	.7059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 206 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3403	.3582	.3582	.3582	.3761	.3224	.394
2	.3366	.3224	.3224	.3224	.3582	.3224	.3582
3	.3189	.3439	.3045	.2835	.3582	.3012	.3224
4	.3155	.4252	.3224	.3045	.3366	.3012	.3582
5	.3856	.5138	.3814		.3721	.4075	.4477
6	.4854	.5792	.5375		.5014	.5258	.5434
7	.4334	.5194	.4854		.5249	.4557	.5028
8	.4287	.4119	.3681		.4119	.3814	.4161
9	.4115	.4119	.4908	.4298	.3982	.4334	.4161
10	.3856	.394	.4733	.4656	.4835		.4334
11	.3582	.4119	.4908	.4119	.4344		.4298
12	.394	.394	.4298	.3761	.4344	.4835	.4298
13	.3582	.3761	.394	.394	.4572		.4477
14	.3582	.3403	.4298	.3898	.4024		.4298
15	.3582	.4477	.4656	.3544	.3658	.4298	.4298
16	.3761	.4477	.4477	.3582	.3841	.4656	.4252
17	.3761	.4298	.394	.4607	.4755	.4961	.4656
18	.4163	.3898	.4835	.4656	.4572	.4835	.4298
19	.4477	.4961	.4298	.5014	.5068	.5316	.5373
20	.5373	.5493	.5611	.5611	.543	.5609	.5731
21	.5014	.5316	.5373	.5138	.543	.5609	.6024
22	.4835	.4961	.4119	.5014	.4525	.4961	.5316
23	.4119	.4607	.4119	.4298	.4119	.443	.4252
24	.3582	.4119	.394	.3761	.3761	.3582	.394
Max	.5373	.5792	.5611	.5611	.543	.5609	.6024
Min	.3155	.3224	.3045	.2835	.3366	.3012	.3224
Avg	.3990	.4360	.4302	.4129	.4319	.4380	.4476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 201 / 11KV BHIKWADI-KH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854		.5175	.462	.4668	.5544	.4572
2	.4938		.4755	.4251	.462	.5304	.4572
3	.4805		.5544	.4251	.4481	.499	.439
4	.5121		.5853	.4251	.4527	.5853	.439
5	.5415		.6468	.462	.4854	.6283	.439
6	.5544		.6653		.5658	.6219	.5544
7	.6219		.695	.6099	.6602	.6697	.6099
8	.5359		.7207	.5175	.6161	.5552	.5544
9	.5121		.5975	.5359	.6602	.5304	.5544
10	.462		.5914	.5359	.6161	.5359	.5729
11	.6219		.6468	.5544	.5788	.5544	.6099
12	.4938	.5121	.5544	.6908	.6722	.5175	.6722
13	.4706	.4805	.4805	.4527	.4435	.462	.6224
14	.5544	.4805	.5729	.4294	.4938	.4805	.5228
15	.567	.6219	.5175	.6036	.5304	.4805	.679
16	.5487	.6401		.5975	.5544	.4251	.5093
17	.5914	.6219	.5544	.6036	.5914	.4805	.5975
18	.543	.6283	.5544	.5426	.6767	.4572	.7282
19	.7499	.6767	.5729	.6344	.7392	.6219	.811
20	.7343	.6838	.7762	.7356	.6468	.6584	.8775
21	.7133	.6722	.6468	.679	.6219	.695	.6908
22	.5729	.6468	.5544	.5975	.6348	.6219	.6413
23	.5121	.5601		.5281	.5175	.5487	.5601
24	.5041	.4572	.4938	.4435	.4668	.4572	.4755
Max	.7499	.6838	.7762	.7356	.7392	.695	.8775
Min	.462	.4572	.4755	.4251	.4435	.4251	.439
Avg	.5574	.5909	.5897	.5431	.5667	.5488	.5865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 202 / 11 KV NEWARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646		.2743	1.6118	1.3765	1.4575	.2195
2	.1478		.2957	1.6118	1.4091	1.4582	.2195
3	.1829		.2743	1.6118	1.3603	1.4251	.2012
4	.1663		.2957	1.6476	1.4752	1.4746	.2012
5	.1829		.2561	1.6476	1.4746	1.6385	.2012
6	.1848		.2926		1.9109	1.7695	.2561
7	.1867		.2957	1.8267	2.0481	2.2708	.2743
8	.2402		.3658	1.9281	2.1538	2.2447	.2561
9	.2012		.3511	1.9631	2.0222	2.3205	.2378
10	.1663		.2743	.1715	.1509	.1928	.2012
11	2.5526	2.4615	2.7435	.2378	.2195	.2561	2.4577
12	2.6726	2.8292	2.8166	.2427	.2587	.2743	2.769
13	2.7044	2.6707	3.1312	.2263	.2957	.2926	2.652
14	2.4034	2.5766	3.0361	.2427	.2614	.3109	2.6543
15	2.1879	2.6852	2.8959	.2263	.2427	.2926	2.4366
16	2.0805	2.6189		.1886	.2614	.2743	2.343
17	2.0243	2.4905	2.4977	.2241	.2772	.3109	2.4646
18	2.0056	2.4086	2.1719	.218	.2957	.3077	2.304
19	.208	.2534	.2378	.2829	.2743	.3658	.2054
20	.1989	.2686	.2743	.2614	.2218	.3292	.2801
21	.192	.2896		.2829	.1829	.2743	.2801
22	.1943	.3109	.2378	.2614	.1848	.2561	.2801
23	.2172	.3077	.2195	.2075	.1463	.2561	.2641
24	.1646	.2012	.2715	1.6476	1.3763	1.56	.2195
Max	2.7044	2.8292	3.1312	1.9631	2.1538	2.3205	2.769
Min	.1478	.2012	.2195	.1715	.1463	.1928	.2012
Avg	.9013	1.5980	1.0686	.8161	.8283	.9005	.9949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 203 / 11 KV DHANEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662		1.9006	.1463	.1867	.2743	2.0576
2	2.0056		1.9227	.1463	.1886	.2534	2.0576
3	1.9826		1.8842	.1463	.1867	.2561	2.0919
4			1.9062	.1463	.2263	.2378	2.1262
5	2.1216		2.0645	.1463	.2801	.2715	2.1605
6	2.7018		2.8509		.3395	.2896	2.4539
7	2.7526		3.2156	.1463	.4338	.4024	2.8464
8	2.9172		3.2114	.1829	.3921	.4066	2.934
9	2.6379		3.1327	.1646	.3961	.3109	2.8635
10	.2035		.2279	.2353	.2987	.2772	.1543
11	.2622	.2818	.2279	2.3312	2.8346	3.2236	.2172
12	.2915	.3224	.2804	2.2611	2.9007	3.2579	.2987
13	.2915	.3077	.3258	2.5926	3.0148	3.3093	.3361
14	.2753	.3258	.3109	2.8673	2.9473	3.2386	.2987
15	.2818	.3292	.2926	2.6189	2.967	3.0007	.3395
16	.2622	.3511		2.556	2.9835	2.4348	.3361
17	.2818	.3395	.1646	2.556		2.7263	.3547
18	.2785	.3326	.1829	2.5286	2.9835	2.6406	.3395
19	.2721	.3077		.2785	.2896	.2353	.3547
20	.3077	.2926	.1646	.3361	.2926	.2534	.3772
21	.3113	.3077	.1646	.3018	.2865	.2715	.3547
22	.2984	.2926	.1829	.2801	.3077	.2195	.3206
23	.2785	.2772	.1829	.2075	.2865	.2195	.2241
24	2.2298	1.8404	2.4508	.1463	.1867	.2743	2.1033
Max	2.9172	1.8404	3.2156	2.8673	3.0148	3.3093	2.934
Min	.2035	.2772	.1646	.1463	.1867	.2195	.1543
Avg	1.0962	.4220	1.2385	1.0140	1.0961	1.1785	1.1667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 204 / 11 KV YETGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461		1.5238	.1457	.1494	.1595	1.326
2	1.6078		1.442	.1457	.1494	.1448	1.4251
3	1.704		1.5565	.1457	.1509	.1463	1.4251
4	1.6409		2.0698	.1296	.1698	.1448	1.4251
5	2.343		1.9334	.1296	.1867	.1612	1.5424
6	2.3758		2.3285		.1886	.181	1.8442
7	2.7183		2.4905	.1943	.2075	.2195	2.3703
8	2.7362		2.652	.1619	.1867	.1848	2.3371
9	1.8233		2.4756	.1457	.1494	.1829	2.3371
10	.1696		.1612	.1296	.1698	.1848	.1326
11	.1677	.1475	.1372	2.1376	2.3594	2.7778	.1341
12	.1619	.181	.1715	2.4086	2.4531	2.6235	.1886
13	.176	.1578	.3086	2.4166	2.4577	2.572	.1698
14	.16	.1753	.1372	2.3644	2.4863	1.6804	.1867
15	.1619	.1629		2.0972	2.4697	2.0233	.1886
16	.1677	.1646		2.2542	2.5069	1.6289	.1886
17	.1696	.1848	.1543	2.2119	2.5396	2.6235	.2263
18	.16	.1829	.1696	2.2447	2.4863	2.2291	.2054
19	.1966	.2033	.1619	.1886	.2303	.1844	.2263
20	.2105	.2218	.1943	.2241	.2172	.1886	.2263
21	.1802	.2012	.1943	.2075	.2328	.2229	.2263
22	.1619	.2195	.1781	.2054	.2172	.2012	.2241
23	.1658	.1848	.1619	.1886	.1612	.1989	.1867
24	1.6617	1.5238	1.7924	.1457	.1494	.1417	1.2431
Max	2.7362	1.5238	2.652	2.4166	2.5396	2.7778	2.3703
Min	.16	.1475	.1372	.1296	.1494	.1417	.1326
Avg	.9444	.2794	1.0179	.8966	.9448	.8752	.8327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 205 / 11 KV TUPEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4807		.4801	.0486	.0747	.056	.4024
2	.4641		.5087	.0486	.0754	.0747	.4024
3	.4475		.4973	.0486	.0754	.056	.4191
4	.4917		.4578	.0486	.0754	.056	.4024
5	.5087		.4748	.0486	.0566	.0747	.4024
6	.5316		.6401		.0754	.0747	.4527
7	.5801		.7207	.0663	.0754	.0747	.5801
8	.6226		.4938	.0663	.0754	.0554	.6464
9	.6796		.499	.0663	.0943	.056	.6706
10	.0509		.0509	.081	.0934	.056	.0671
11	.0876	.0492	.0469	.421	.6882	.6836	.0914
12	.0532	.0724	.0648	.5921	.7459	.5365	.0747
13	.0532	.0537	.0648	.5243	.78	.6203	.0754
14	.0358	.0905	.081	.6964	.7716	.6371	.0747
15	.037	.0549	.0648	.7209	.7545	.6371	.0754
16	.037	.0732		.6802	.7373	.6036	.0934
17	.0366	.0732	.0648	.6483	.7362	.6962	.0943
18	.037	.0732	.0648	.6554	.6733	.663	.0934
19	.0543	.0739	.0503	.0934	.0876	.0995	.0943
20	.0549	.0739	.081	.0943	.0732	.0972	.1307
21	.056	.0747	.081	.0934	.0924	.0995	.1132
22	.0566	.0747	.0648	.0943	.0732	.0829	.112
23	.0549	.0747	.0486	.0747	.0732	.0829	.0934
24	.4805	.439	.4805	.0486	.0754	.0554	.3353
Max	.6796	.439	.7207	.7209	.78	.6962	.6706
Min	.0358	.0492	.0469	.0486	.0566	.0554	.0671
Avg	.2497	.0965	.2644	.2591	.2972	.2595	.2499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 206 / 11 KV YERALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905		.0739	.0497	1.6964	1.5971	.0663
2	.1097		.0732	.0497	1.7004	1.6221	.0663
3	.0829		.0914	.0497	1.7204	1.6575	.0663
4	.0983		.0739	.0497	1.7404	1.6876	.0663
5	.0924		.0747	.0497	1.9784	1.6712	.0663
6	.1097		.0924		2.0243	1.8023	.0663
7	.1294		.112	1.7404	2.1125	2.1548	.0829
8	.0934		.112	1.9559	2.2611	2.2447	.0995
9	.0747		.0924	1.9559	2.0485	2.2045	.0995
10	.0924		.0914	.0497	.0754	.0934	.0663
11	2.4209	1.9559	1.6804	.0663	.0754	.1086	2.1714
12	2.4356	2.0388	2.1262	.0934	.0747	.0671	2.3266
13	2.3777	2.0972	2.2805	.1509	.1109	.0838	2.3805
14	2.3167	2.1136	2.2291	.1307	.112	.1006	2.3594
15	2.347	2.2874	2.3491		.0934	.1006	2.251
16	2.1491	2.1548		.168	.1109	.0671	2.2447
17	2.0814	1.9498	2.1948	.1509	.1294	.1006	2.0645
18	2.0302	1.9498	1.9719	.1307	.112	.1006	2.0481
19	.0895	.0724	.0486	.0943	.1109	.0995	.0934
20	.1075	.0732	.0503	.0934	.0914	.0995	.0943
21	.1097	.1109	.0497	.0943	.0739	.0829	.0934
22	.0924	.1097	.0663	.0747	.0732	.0829	.0747
23	.0895	.0924	.0663	.0754	.0739	.0663	.0747
24	.0895	.0924		.0497	1.7368	1.7833	.0663
Max	2.4356	2.2874	2.3491	1.9559	2.2611	2.2447	2.3805
Min	.0747	.0724	.0486	.0497	.0732	.0663	.0663
Avg	.8213	1.2213	.7273	.3329	.8474	.8199	.7954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 201 / 11 KV SHIVANI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0081	2.0241	2.4863	.1134	.112	.1107	1.9662
2	1.9433	2.0485	2.5194	.1134	.1029	.1107	1.9271
3	1.9433	2.0325	2.5194	.1134	.1017	.1017	1.8884
4	1.9595	2.0485	2.5232	.1134	.1357	.096	1.8884
5	1.9919	2.0805	2.5232	.116	.1326	.1029	1.8884
6	2.2119	2.1664	2.556	.116	.1478	.1052	2.1862
7	2.3525	2.4352	2.8178	.116	.1326	.1658	2.5069
8	2.5263	2.4939	2.9504	.1174	.104	.1492	2.6543
9	2.5101	2.4166	2.9172	.096	.1067	.1094	2.6379
10	.1027	.092	.1027	.0937	.1067	.104	.0732
11		.0686	.1029	2.9508	3.2861	3.4476	.0762
12		.0695	.0983	3.0001	3.219	2.7681	.0995
13		.0777	.1017		3.219	2.7035	.0903
14	.0903	.0709	.0949	3.3029	3.315	2.6216	.0869
15		.0714	.1052		3.3648	2.9338	.1
16		.0903	.1017	.3185		2.8012	.1107
17	.0667	.0834	.1341	2.9984		2.8841	.096
18	.096	.0869	.1307	2.9675		2.4697	.0987
19	.112	.1134	.1402	.1265	.1027	.0762	.1067
20	.128	.1357	.1494	.128	.128	.0781	.0934
21	.128	.116	.1433	.112	.1357	.081	.0974
22	.1219	.0983	.112	.1254	.1107	.081	.0974
23	.0869	.0995	.112	.1029	.112	.081	.08
24	2.0243	2.0485	2.4697	.112	.1132	.1107	1.9989
Max	2.5263	2.4939	2.9504	3.3029	3.3648	3.4476	2.6543
Min	.0667	.0686	.0949	.0937	.1017	.0762	.0732
Avg	1.1791	.9612	1.1630	.7888	.8709	1.0122	.9520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 202 / 11 KV HANMANTWADIYE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.128	.1063	1.576	1.7204	1.5364	.1595
2	.1267	.1294	.1075	1.576	1.7204	1.6385	.1578
3	.1267	.1294	.0905	1.576	1.6484	1.6385	.1578
4	.1267	.1294	.0914	1.5927	1.7604	1.6712	.1595
5	.1417	.1294	.1097	1.5565	1.7604	1.8351	.1595
6	.1646	.1463	.1612	1.5203	1.8084	1.8461	.1791
7	.1791	.1448	.1612		2.1125	1.989	.1991
8	.156	.1267	.1433		2.1879	2.0165	.1595
9	.156	.128	.1433		2.0645	2.0005	.1387
10	.156	.1387	.1612		.1006	.1187	.1187
11		3.4808	2.6355		.124	.12	.0829
12		3.514	2.8178		.1387	.1187	.1802
13	2.9338	3.4311	2.8178		.1595	.1433	2.3878
14		2.5692	2.5987		.1629	.1791	2.5888
15		2.7349	2.5126		.1619	.124	2.7854
16		2.7183	2.1293		.1677	.1387	2.3245
17	2.1033	2.6379	2.1125		.1791	.1387	3.131
18		2.7183	.218		.1254	.1612	3.0996
19	.1638	.1595	.1029	.1677	.1372	.1772	.2126
20	.1791	.1612	.1254	.1677	.1595	.1772	.1949
21	.1629	.1433	.12	.1492	.1578	.2149	.1949
22	.1629	.1433	.1174	.1492	.1387	.1772	.1753
23	.1463	.1433	.1174	.1341	1.5939	.1791	.1734
24	.1417	.1463	.1063	1.643	1.7695	1.5939	.1578
Max	2.9338	3.514	2.8178	1.643	2.1879	2.0165	3.131
Min	.1267	.1267	.0905	.1341	.1006	.1187	.0829
Avg	.4150	1.0846	.8253	.9840	.9192	.8306	.8033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 203 / 11 KV SHIVANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.5121	.5228	.6838	.4527	.462	.4854
2	.4805	.499	.5228	.462	.4338	.462	.4715
3	.4854	.499	.5175	.462	.4527	.462	.4715
4	.4854	.499	.5175	.462	.5658	.4715	.4715
5	.499	.499	.5975	.5544	.6413	.5658	.4668
6	.6722	.7316	.7392	.6838	.6838	.6653	.6653
7	.6268	.7164	.6805	.7023	.7059	.6516	.6447
8	.6089	.6836	.6733	.6722	.6554	.6805	.6068
9	.6135	1.5083	.6135	.5601	.6447	.5721	.463
10	.5609	.6241	.6762	.5087	.6661	.5721	.5868
11		.5201	.7537	.5258	.6089	.5487	.5895
12		.5895	.6556	.591		.583	.5138
13	.5373	.5895	.6626	.5194	.4733	.5493	.5138
14	.4525	.5258	.6201	.4835	.4854	.5373	.4961
15		.5373	.6805	.5493	.5316	.5373	.5201
16		.6024	.6089	.5493	.5601	.5611	
17	.5144	.5083	.5729	.6089	.5729	.4458	.5201
18	.6516	.6068	.6722	.5434	.5552	.5487	.6001
19	.6935	.6836	.7655	.6556	.631	.6556	.6415
20	.7964	.7964	.8589	.7964	.7682	.7421	.7011
21	.8507	.8048	.8589	.7682	.7499	.724	.4119
22	.6036	.7133	.7421	.7282	.6447	.6584	
23	.6036	.6219	.7316	.5847	.6447	.5914	.5853
24	.5175		.5544	.7316	.5658	.5731	.499
Max	.8507	1.5083	.8589	.7964	.7682	.7421	.7011
Min	.4525	.499	.5175	.462	.4338	.4458	.4119
Avg	.5867	.6466	.6583	.5994	.5954	.5759	.5421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 201 / 11 KV VITA(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9418	1.7353	1.9616	1.8484	1.8671	1.9052	1.9814
2	1.8671	1.6975	1.9239		1.848	1.7909	1.9052
3	1.8861	1.6598	1.8861	1.773	1.7551	1.7147	1.7909
4	1.9239	1.6598	1.8484	1.7353	1.773	1.6004	1.7147
5	1.8484	1.6975	1.8861	1.8107	1.8107	1.6766	1.7909
6	1.8484	1.7353	1.9239	1.8861	1.8671	1.9052	1.9052
7	1.773	1.7353	1.8107	1.8484	1.9044	1.9052	1.829
8	1.773	1.7924	1.9418	1.922	1.9044	1.848	1.9959
9	1.7353	1.885	2.0851	1.9387	1.9753	1.9387	2.0119
10	1.885	2.1357	2.3891	2.1948	2.1491	1.7909	1.989
11	1.9239	2.3045	2.4764	2.2916	2.2546	2.1068	2.3285
12	1.8861	2.1807	2.3525	2.2405	2.1068	2.0538	2.2546
13	1.8861	2.1437	2.3525	2.2405	2.0165	2.0328	2.1658
14	1.8861	2.2546	2.4025	2.2916	2.1437	1.9022	2.2916
15	1.9239	2.3655	2.2405	2.3655	2.2916	2.1437	2.4143
16	1.9993	2.3525	2.2177	2.4394	2.1437	2.1068	2.4025
17	1.9616	2.2032	2.3045	2.4874		2.2916	2.3777
18	1.8861	2.3411		2.3777	2.2177	2.268	2.2916
19	2.0748	2.5133	2.3777	2.5972	2.4394	2.3777	2.5133
20	2.3765	2.6513	2.5606	2.5873	2.5019	2.5133	2.6513
21	2.2634	2.3388	2.0805	2.2779	2.2032	2.2779	2.3899
22	2.0748	2.1879	2.0485	2.2405	2.1719	2.21	2.2634
23		2.2032	2.1216	2.2032	2.1719	2.21	2.2405
24	2.0911	1.8861	2.0748	2.037	2.0538	2.0195	2.0576
Max	2.3765	2.6513	2.5606	2.5972	2.5019	2.5133	2.6513
Min	1.7353	1.6598	1.8107	1.7353	1.7551	1.6004	1.7147
Avg	1.9442	2.0692	2.1420	2.1580	2.0683	2.0246	2.1482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 202 / 11 KV LENGARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3565	.8764	1.1584	1.2971	1.3565	1.1603	1.387
2	1.2887	.8002	1.1222	1.262	1.2346	1.1271	1.283
3	1.2346	.7621	1.0974	1.2269	1.1443	1.0608	1.2136
4	1.2536	.724	1.0719	1.1919	1.1443	.8951	1.1789
5	1.2071	.724	1.0349	1.2269	1.1568	.9945	1.283
6	.8962	.7621	1.0349	1.262	1.1789	1.0852	1.326
7	.8962	.7545	1.2048	1.2689	1.2003	1.2742	1.3413
8	.8299	1.1088	1.3413	1.4091	1.3413	1.4251	1.4255
9	.6413	1.4255	1.5074	1.5546	1.5684	1.5181	1.6004
10	.8215	1.6248	1.7497	1.7814	1.6975	1.6975	1.7459
11	.7621	1.7166	1.9109	1.9433	1.7924	1.9524	1.9524
12	.6478	1.3523	1.406	1.2403	1.2597	1.1443	1.4582
13	.6859	1.0985	1.262	1.4083		1.1603	
14	.724	1.5223		1.7166	1.6964	1.5364	1.6446
15	.724	1.6518	1.8679	1.7814	1.9342	1.6324	1.7711
16	.7621	1.5424	1.6194	1.6575	1.5249	1.4899	1.6057
17	.6859	1.5089	1.7185	1.8233		1.5684	1.5813
18	.6859	1.3923		1.5402	1.4091	1.4723	1.4899
19	.7621	1.406	1.6057	1.6842	1.5223	1.5729	1.5729
20	.8764	1.4022	1.4746	1.6385	1.5249	1.5581	1.6244
21	.8764	1.0456	.9831	1.1946	1.0166	1.182	1.1104
22	.9145	1.3112	1.4746	1.3717	1.4083	1.5581	1.4746
23	.9145	1.4217	1.5402	1.4754	1.6057	1.5912	1.6842
24	1.3717	.8764		1.4217	1.4243	1.3923	1.4563
Max	1.3717	1.7166	1.9109	1.9433	1.9342	1.9524	1.9524
Min	.6413	.724	.9831	1.1919	1.0166	.8951	1.1104
Avg	.9091	1.2004	1.3898	1.4741	1.4155	1.3770	1.4874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 203 / 11 KV BHALWANI(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1443	1.0136	1.1568	1.1694	1.1919	1.1789	1.2136
2	1.1096	.9877	1.1919	1.134	1.1694	1.1443	1.1096
3	1.0985	.9511	1.134	1.0985	1.0631	1.0402	1.0402
4	1.0631	.9412	1.0985	1.1568	1.0631	.9362	.9362
5	1.0631	.9671	1.134	1.0867	1.0517	1.0056	1.0056
6	1.0277	.9671	1.1694	1.1218	1.0867	1.1443	1.0402
7	1.0277	1.0277	1.2971	1.2548	1.2689	1.1789	1.2136
8	1.134	1.0867	1.3904	1.3592	1.3226	1.2548	1.3226
9	1.0402	1.2742	1.3592	1.3592	1.3923	1.326	1.3923
10	1.0814	1.3443	1.4403	1.3923	1.4723	1.3763	
11	1.1443	1.4419	1.5089	1.4255	1.5402	1.4255	1.4091
12	1.1568	1.3763	1.4922	1.3923	1.4918	1.4255	1.3603
13	1.0056	1.1797	1.2689	1.3592	1.2742	1.2742	1.2125
14	1.0166	1.2742	1.3032	1.3413	1.326	1.3748	1.2929
15	1.0166	1.2407	1.3904	1.442	1.3748	1.4083	1.3592
16	1.0517	1.5249	1.4586	1.4918	1.4918	1.4419	1.4419
17	1.0517	1.4918	1.4723	1.4754		1.4255	1.3592
18	1.0402	1.2631		1.2955	1.2407	1.3927	1.2929
19	1.1443	1.4922			1.326	1.4918	1.3077
20	1.2269	1.5089	1.3123	1.4243	1.4419	1.4582	1.4243
21	1.1919	1.4217	1.1523	1.3176	1.2209	1.3226	1.3032
22	1.1568	1.382	1.2163	1.2689	1.2483	1.387	1.3032
23		1.3321	1.2483		1.2346	1.3523	1.3375
24	1.2136	1.0136	1.2048	1.2269	1.2136	1.1789	1.2483
Max	1.2269	1.5249	1.5089	1.4918	1.5402	1.4918	1.4419
Min	1.0056	.9412	1.0985	1.0867	1.0517	.9362	.9362
Avg	1.0959	1.2293	1.2909	1.2997	1.2829	1.2894	1.2577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 204 / 11 KV PARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	.7842	1.2567	1.2803	1.3032	1.2536	1.4327
2	1.2308	.7842	1.1827	1.2437	1.2803	1.2178	1.3253
3	1.2071	.7468	1.1203	1.1706	1.2071	1.1462	1.2536
4	1.1088	.7392	1.1203	1.134	1.1706	.9671	1.1462
5	1.0185	.7762	1.1576	1.2071	1.1584	1.0745	1.2178
6	.9145	.7762	1.2323	1.2071	1.1946	1.1706	1.3253
7	.9526	.9922	1.39	1.3611	1.4175	1.2536	1.3523
8	.9431	1.3253	1.5257	1.5089	1.491	1.4373	1.5257
9	.8413	1.4022	1.6118	1.4403	1.4746	1.4563	1.4922
10	.7461	1.4918	1.576	1.5432	1.5402	1.4918	1.4563
11	.7164	1.4922	1.6278	1.576	1.576	1.6575	1.6278
12	.4706	1.387	1.3112	1.134	1.3176	1.2178	1.283
13	.4904	1.1104	1.1736	1.262	1.1462	1.182	1.262
14	.5658	1.3375	1.4746	1.3717	1.4563	1.2269	1.4403
15	.5601	1.4746	1.3523	1.4918	1.5257	1.4922	1.4373
16	.5914	1.4217	1.3904	1.5424	1.3466	1.4217	1.4217
17	.5914	1.5432	1.4419	1.5432		1.5261	1.4754
18	.7442	1.4243		1.4754	1.5424	1.4582	1.4746
19	.8596	1.5074	1.3763	1.56	1.595	1.5604	1.5775
20	.905	1.6118	1.3763	1.5074	1.5592	1.6301	1.6126
21	.905	1.307	1.1469	1.1576	1.2567	1.3306	1.3676
22	.9877	1.4415	1.3108	1.3306	1.3969	1.576	1.5402
23		1.4118	1.4091	1.5402	1.4685	1.576	1.5775
24	1.3394	.8131	1.3169	1.3756	1.3756	1.3611	1.4327
Max	1.3394	1.6118	1.6278	1.576	1.595	1.6575	1.6278
Min	.4706	.7392	1.1203	1.134	1.1462	.9671	1.1462
Avg	.8677	1.2126	1.3427	1.3735	1.3826	1.3619	1.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA OLD S/STN

Feeder No / Name : 403 / 33KV NAGEVADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.8891	5.9374	5.8162	3.155	3.5117	3.6408	4.6811
2	4.7851	6.0985	5.7065	3.0498	3.3665	3.6408	4.6811
3		6.5421		2.8395	3.2579	3.6408	4.6811
4	5.0972	6.5547	6.0357	2.7343	3.2236	3.6408	4.6811
5	5.7213	7.1674	6.6941	3.0498	3.546	3.6408	4.6811
6	6.5535	7.6292	8.3402	3.5757	4.0398	4.6811	5.7213
7	8.0098	8.3453	8.3402	4.6273	5.2115	5.2012	7.2017
8	8.2179	8.7037	8.3402	4.9429	5.3212	4.784	7.2817
9	7.4897	8.1664	8.011	5.7316	5.6413	5.2012	7.2817
10	1.3375	2.0416	1.9753	5.9945	2.0805	2.0805	1.8724
11	4.3724	6.1248	4.9429	6.9696	7.2817	7.8018	5.0972
12	1.5604	6.19	2.1033	6.8884	8.059	8.2305	5.6173
13	4.6205	5.647	1.7878	7.2565	8.5963	5.2012	5.6173
14	4.465	5.5418	1.6827	7.6543	8.5963	8.3219	4.7851
15	4.3118	6.4746	5.3635	4.2067	6.4472	8.3219	6.0334
16	4.7308	2.0851	3.9963	6.6575	8.059	8.2305	5.0972
17	4.513	6.0357	4.5222	6.31		8.3219	2.2885
18	4.3439	5.7065		7.1228	5.2012	7.8018	4.6811
19	1.8461	1.4266	1.1568	2.4177	2.0805	2.1491	2.0805
20	1.9753	2.524	1.0517	1.8461	2.1491	1.6118	1.7684
21	1.6461	1.9753	1.1568	1.7375	1.6118	1.6118	1.7684
22	1.6078	1.7558	5.1532	1.5364	1.6118	1.6118	1.4563
23		1.5364	1.3672	1.3306	1.6118	1.6118	1.2483
24	4.7851	5.9374	5.487	3.2602	3.5117	3.7609	4.6811
Max	8.2179	8.7037	8.3402	7.6543	8.5963	8.3219	7.2817
Min	1.3375	1.4266	1.0517	1.3306	1.6118	1.6118	1.2483
Avg	4.4036	5.2561	4.5014	4.3706	4.5225	4.7809	4.3744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 201 / 11 KV ALSAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2218	.1715	.1658	1.749	1.8138	1.7328
2	.2353	.2218	.1829	.1658	1.7166	1.8138	1.7328
3	.2353	.2218	.1875	.1638	1.6842	1.7814	1.6518
4	.2353	.2195	.1875	.1638	1.6964	1.749	1.6194
5	.2534	.2195	.2012	.1619	1.7444	1.749	1.7004
6	.2743	.2378	.218	.197	1.7814	1.7814	1.8138
7	.2957	.2926	.2629	.2374	2.3868	2.1051	1.9271
8	.2896	.3292	.2458	.2347	2.2775	2.2447	2.0081
9	.3045	.2865	.2743	.2774	2.2447	2.343	2.0729
10	.3018	.3121	.3018	.2829	.2214	.1638	.2926
11	2.4034	2.5526	2.7183	.3018	.2401	.2743	2.2708
12	2.4531	2.5692	2.8012	.3142	.2321	.333	2.3703
13	2.42	2.5692	2.7681	.2987	.2321	.3258	2.2447
14	2.4086	2.0645	2.7515	.2987	.2401	.3258	2.2939
15	2.42	2.0645	2.7328	.3018	.333	.2896	.7611
16	2.3703	2.2939	2.8509	.2829	.3506	.0537	2.3537
17	2.1348	2.4034	2.4939	.3018	.3506	.0537	2.3102
18	.213	2.1052	2.2024	.3018	.2865	.3761	2.3102
19	.2075	.2865	.1844	.2829		.4024	.2658
20	.2641	.2254	.2303	.2829	.3258	.3982	.3224
21	.2641	.2279	.2103	.2829	.3403	.362	.3224
22	.2614	.2279	.1844	.2241	.3155	.2347	.3224
23	.2614	.2254	.1886	.2054	.3224	.1658	.2534
24	.2353	.2218	.2225	.1844	1.7652	1.8299	1.7652
Max	2.4531	2.5692	2.8509	.3142	2.3868	2.343	2.3703
Min	.2075	.2195	.1715	.1619	.2214	.0537	.2534
Avg	.8741	.9417	1.0322	.2465	.9929	.9571	1.5299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 202 / 11 KV BHALWANI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	1.8233	1.9109		.1075	.1097	.1075
2	1.8515	1.7901	1.9109	1.5223	.1075	.0732	.0895
3	1.8023	1.7238	1.9662	1.3927	.1075	.0739	.0905
4	1.749	1.8233	1.917	1.3927	.1097	.0739	.0905
5		1.8896	1.917	1.3923	.1097	.0754	.0905
6	1.989	1.9725	1.9662	1.4899	.1097	.1132	.0886
7	2.1628	2.3205	2.2024	1.8027	.1097	.112	.1063
8	2.3922	2.536	2.2939	2.0399	.1448	.1478	.1448
9	2.2611	2.1628	2.1376	2.0965	.1463	.1463	.1463
10	.1132	.1017	.1387	.1132	.181	.1829	.1402
11	.1097	.1463	.1478	2.3205	2.556	2.6155	.1086
12	.1097	.1097	.1494	2.3703	1.6004	2.652	
13	.1494	.1097	.1478	2.1548	2.4006	2.7846	
14	.1867	.1097	.1478	2.1382	2.4615	2.7846	
15	.112	.1494	.1478	2.0972	2.4905	2.6852	.1254
16	.112	.1494	.0905	2.0809	2.4577	2.6189	.1075
17	.1494	.1463	.0848	2.2405	2.4249	2.3102	.1791
18	.1867	.1448	.0781	2.3845	1.9662	2.1376	.1254
19	.1132	.1463	.1187	.1132		.104	.1294
20	.1478	.1494	.0924	.1357	.1063	.1341	.1663
21	.1848	.1478	.1097	.1509	.1448	.1341	.1663
22	.1494	.1478	.0924	.1463	.1448	.1075	.1417
23	.1132	.1109	.0924	.1097	.1097	.112	.1307
24	2.0885	1.8399	1.8785	1.6385	.1075	.1097	.1063
Max	2.3922	2.536	2.2939	2.3845	2.556	2.7846	.1791
Min	.1097	.1017	.0781	.1097	.1063	.0732	.0886
Avg	.8792	.9063	.9058	1.4488	.8784	.9333	.1229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 203 / 11 KV KAMLAPUR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7368	1.9559	1.9662	1.3117	.2587		.2374
2	1.7204	1.9227	2.0317	1.2803	.2587		.2374
3	1.6876	1.989	2.0553	1.2643	.2587		.2347
4	1.6712	2.0553	1.9559	1.2483	.2587		.2347
5	1.6518	2.0885	1.989	1.2334	.2561		.2347
6	1.989	2.1216	2.1216	1.3765	.2561		.3018
7	2.4034	2.4034	2.5194	1.4723	.2926		.3688
8	2.4034	2.6155	2.5857	.5135	.2926		.3978
9	2.42	2.5857	2.5857		.2865		.3978
10	.2683	.2713	.2486	.0339	.2774		.5068
11	.3292	.2601	.4066	.5087	2.8837		.4435
12	.3658	.3696	.4207	1.7859	3.0849		.4207
13	.3429	.3696	.4435	1.9662	3.0178	2.6189	.4251
14	.3772	.3658	.4251	2.2377	2.9007	2.649	.4572
15	.4066	.3658	.4435	2.5149	2.5194	2.6155	.4755
16	.4066	.3658	.4066	2.7161	2.5194	2.6155	.4755
17	.4024	.4755	.3292	2.5149	2.5194	2.5029	.4344
18	.4024	.4805	.3258	2.3868		2.3537	.4344
19	.394	.4805	.0362	.2713		.2652	.4024
20	.4024	.4066	.3511	.3086	2.5194	.2984	.4805
21	.4024	.4344	.3511	.3189		.2984	.4251
22	.2926	.4344	.3326	.2896		.2652	.3658
23	.2614	.3326	.2534	.2896		.2321	.1848
24	1.7695	1.9559	1.9662	1.6518	.2587		.2347
Max	2.42	2.6155	2.5857	2.7161	3.0849	2.649	.5068
Min	.2614	.2601	.0362	.0339	.2561	.2321	.1848
Avg	1.0211	1.1294	1.1063	1.2824	1.3116	1.5195	.3671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 204 / BHALWANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1886	.1494	.1698	.1478	.1494	.1509
2	.1494	.1886	.1494	.1698	.1478	.1494	.1509
3	.1494	.1886	.1509	.1698	.1478	.1509	.132
4	.1494	.1886	.1132	.1698	.1494	.1132	.1132
5	.168	.1886	.1509	.1698	.1494	.1132	.1132
6	.1886	.1886	.1509	.2075	.1867	.1886	.1509
7	.1132	.1886	.1509	.1905	.1867	.1509	.1509
8	.1698	.1509	.1524	.1698	.1886	.1524	.1509
9	.1509	.1494	.1509	.1509	.1509	.1132	.1334
10	.1478	.1143	.132	.1132	.1132	.1132	.1132
11	.1132	.112	.1109	.1478	.1143	.1132	.132
12	.1132	.1132	.1307	.1478	.1524	.1143	.1334
13	.1509	.1132	.1509	.1109	.1143	.1509	.1334
14	.1509	.1109	.132	.1097	.1143	.1509	.1524
15	.1509	.1109	.112	.1509	.1132	.132	.132
16	.1509	.1109	.1334	.1509	.1143	.132	
17		.1132	.132	.1132	.1143	.1132	.0309
18	.1478	.1463	.0943	.1132	.0754	.1132	.1143
19	.112	.1509	.1698	.1132		.2075	.1334
20	.2263	.2286	.2286	.1886	.2263	.2263	.2075
21	.2263	.2263	.2075	.1886	.2263	.2241	.1886
22	.1886	.2263	.2075	.1867	.1905	.1867	.1886
23	.1886	.1886	.1886	.1867	.1509	.1867	.1698
24	.168	.1886	.1494	.1698	.1478	.1494	.1509
Max	.2263	.2286	.2286	.2075	.2263	.2263	.2075
Min	.112	.1109	.0943	.1097	.0754	.1132	.0309
Avg	.1575	.1614	.1499	.1566	.1488	.1498	.1403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 205 / ALSAND / KAMALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3801	.3696	.3696	.3734	.4066	.1867	.394
2	.3801	.3696	.3696	.3734	.3696	.1867	.3658
3	.3801	.4435	.3696	.3734	.3696	.1886	.3658
4	.4024	.4854	.3696	.3734	.4435	.1886	.3658
5	.4435	.5228	.3696	.4294	.4805	.1886	.4755
6	.7095	.5975	.5729	.6722	.5544	.3018	.6626
7	.5487	.5914	.5853	.6219	.695	.2641	.5552
8	.4784	.5014	.4784	.4706	.5316	.2561	.5373
9	.3086	.4557	.4161	.4075	.4161	.2172	.4656
10	3.7388	.3277	.4251	.3647	.3812	.2149	.4207
11	.3353	.3155	.4031	.4115	.3772	.1791	.2204
12	.3467	.3467	.4252	.4161	.407	.1791	.4458
13	.3429	.3467	.3681	.4527	.3814	.1791	.463
14	.3391	.3467	.3681	.4252	.3814	.181	.4458
15	.3467	.3155	.394	.3898	.3814	.181	.4508
16	.3467	.3506	.3772	.3856	.3814	.1791	.4161
17	.3429	.3506	.4475	.4207	.3978	.1791	.4409
18	.3688	.4694	.4557	.407		.1791	.4801
19	.4207	.5609	.4656	.5144		.6805	.6201
20	.4557	.6335	.5487	.5731	.362	.6805	.6697
21	.543	.5175	.5175	.5731	.3326	.6447	.6219
22	.4706	.4805	.4854	.5068	.2801	.5373	.5792
23	.4481	.4294	.4294	.4755	.2241	.4656	.5121
24	.4066	.3696	.4066	.3921	.4435	.1867	.4298
Max	3.7388	.6335	.5853	.6722	.695	.6805	.6697
Min	.3086	.3155	.3681	.3647	.2241	.1791	.2204
Avg	.5535	.4374	.4341	.4501	.409	.2844	.4752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 206 / 11 KV Umar Kanchan AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.2172	.1663	.1478	1.1469	1.6324	1.6518
2	.1848	.2172	.1663	.1294	1.1142	1.6004	1.6221
3	.1848	.2172	.168	.1294	1.0486	1.6194	1.5729
4	.1848	.2172	.2241	.1294	1.1469	1.5729	1.6057
5	.2241	.2149	.2241	.1646	1.4243	1.5546	1.6518
6	.2614	.2149	.2241	.1867	1.7924	1.749	1.9271
7	.2195	.2172	.1463	.2378	2.1956	1.8679	2.17
8	.1848	.2172	.2218	.2126	2.251	2.0405	2.3266
9	.1991	.2195	.2743	.1949	2.2939	2.1376	2.3758
10	.1886	.2058	.1848	.2195	.1772	.1311	.16
11	2.6216	2.556	2.7846	.2587	.1829	.1357	2.6216
12	2.7035	2.8841	3.083	.2587	.2012	.1478	2.8509
13	2.6216	2.8841	2.9835	.2507	.2195	.1109	2.6216
14	2.6052	2.8841	2.9504	.2507	.2195	.1097	2.6543
15		2.8841	2.8178	.2149	.2149	.1097	2.6052
16	1.5893	2.8841	2.4741	.2149	.2149	.1867	2.7349
17	2.2939	2.8841	2.1376	.2218	.2686	.1829	2.7526
18	2.6216	2.6543	2.1052	.2218	.1791	.1448	2.4453
19	.2195	.2507	.0159	.2614		.2534	.2033
20	.2587	.2012	.2012	.2195	.2012	.2587	.2402
21	.2772	.2195	.2012	.2195	.2012	.2587	.2402
22	.2172	.2195		.181	.2012	.2218	.2218
23	.2172	.1848		.181	.181	.1663	.2402
24	.1848	.2172	.1663	.1478	1.2289	1.6324	1.6842
Max	2.7035	2.8841	3.083	.2614	2.2939	2.1376	2.8509
Min	.1848	.1848	.0159	.1294	.1772	.1097	.16
Avg	.8890	1.0819	1.0873	.2023	.7959	.8261	1.7158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/STN

Feeder No / Name : 207 / VITA WATER SUPPLY,ALSAND NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2155	.1296	.1966	.2321	.2321	.1966	.2347
2	.2155	.2321	.1966	.0373	.2321	.1966	.2347
3	.2155	.2321	.2321	.2294	.2321	.1966	.218
4	.2155	.2321	.2321	.2294	.2321	.1966	.218
5	.2155	.2321	.2321	.213	.2321	.1966	.2155
6	.0358	.2321	.2321	.2155	.2321	.1966	.2294
7	.2321	.2321	.2294	.2155	.2321	.2294	.2294
8	.2321	.2321	.2294	.213	.2321	.2294	.2321
9	.2294	.2321	.2294	.4967	.2321	.2321	.2321
10	.2321	.2241	.2267	.2321	.2241	.2267	.2321
11	.2321	.2321	.2347	.2321	.2321	.2347	.2321
12	.2267	.2294	.2515	.2321	.2267	.2347	.2321
13	.2241	.2294	.2515	.0347	.2267	.218	.2294
14	.032	.2294	.2347	.037	.2267	.2155	.2294
15	.0362	.2321	.2347	.0343	.2267	.2347	.2321
16	.0362	.2321	.2294	.0343	.2267	.2321	
17	.032	.2321	.2267	.0343	.2294	.2321	.2294
18	.032	.2294	.2241	.125	.2294	.2294	.2321
19	.2321	.2321	.0354	.1402		.2321	.2321
20	.0312	.2321	.2294	.2321	.1943	.2294	.218
21	.0312	.2321	.2155	.2321	.1943	.2321	.218
22	.0312	.2321	.213	.2321	.1943	.2321	.2105
23	.0312	.2347	.2155	.2321	.1966	.2321	.2105
24	.2155	.1296	.1966	.2155	.2321	.1966	.2347
Max	.2321	.2347	.2515	.4967	.2321	.2347	.2347
Min	.0312	.1296	.0354	.0343	.1943	.1966	.2105
Avg	.1443	.2229	.2179	.1817	.2239	.2201	.2268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 201 / 11 KV GARDI FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083		1.5249		.112	.061	1.6907
2	1.3763	1.5424	1.5581		.0937	.061	1.6907
3	1.3599	1.4754	1.5746		.0949	.0625	1.7238
4	1.4746	1.5424	1.643		.0772	.064	1.6876
5	1.5402	1.6095	1.8442		.0937	.081	1.7204
6	1.7238	1.7436	2.0287		.125	.1006	1.8023
7	1.8778	2.146	2.146		.112	.1107	2.1795
8	1.8861	2.1704	2.2801	.0633	.1147	.088	2.1125
9	1.989	2.0119	2.146	.0671	.1134	.0503	2.0622
10	.0579	.0465	.0791	.0396	.072	.096	.1063
11	.0625	.064	.0671	2.1125	2.3472	2.1704	.1109
12	.0511	.0791	.0678	2.1963	2.4078	2.1382	.1017
13	.0587	.0995	.0671	2.1795	2.1792	2.3807	.0983
14	.0572	.096	.0671	2.2382	2.2298	2.3807	.0937
15	.0572	.0791	.0633	2.0885		2.3472	.0972
16	.0602	.0655	.0533	2.146		2.2466	.108
17	.0693	.0633	.0404	2.0119	.0829	2.1795	.0734
18	.0572	.0892	.0442	1.9448	.0995	2.0119	.0762
19	.0541		.0526	.1143	.061	.0655	.064
20	.0572	.0791	.0564	.06	.0974	.0655	.1017
21	.0602	.08	.061	.0667	.1	.0995	.0949
22	.0594	.0663	.0648	.108	.0914	.1052	.1029
23	.061	.0663	.0655	.108	.0762	.0876	.0857
24	1.4083	1.5424	1.4918	.0617	.1296	.0781	1.6741
Max	1.989	2.1704	2.2801	2.2382	2.4078	2.3807	2.1795
Min	.0511	.0465	.0404	.0396	.061	.0503	.064
Avg	.7028	.7617	.7953	1.0357	.4959	.7972	.8191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 202 / 11KV PRABHAT STEEL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0091	.0091	.0069	.0305	.0061	.0107	.0061
2	.0107	.0091	.0051	.029	.0046	.0152	.0046
3	.0091	.0091	.0051	.0305	.003	.0152	.0046
4	.0091	.0152	.012	.0259	.0046	.0183	.003
5	.0061	.0152	.0183	.0274	.0046	.029	.0046
6	.0061	.0305	.0381	.029	.0061	.0533	.0061
7	.0061	.0259	.0335	.0305	.0061	.0305	.0061
8	.0015	.1097	.0412	.1524	.2957	.029	.0107
9	.0015	.2241	.2452	.2347	.2218	.4001	.6653
10	.0061	.2263	.2667	.3048	.2587	.2452	.9149
11	.0046		.415	.2263	.1848	.3772	.1646
12	.0046	.4904	.5281	.3772	.1829	.679	.3395
13	.0061	.2829	.3772	.3734	.2263	.2587	.7733
14	.0061	.2263	.1886	.2614	.2218	.2587	.5093
15	.0061	.2054	.2561	.5175	.1848	.2614	.415
16	.0061	.2241	.2926	.7655	.1867	.3734	.2829
17	.0046	.3772	.2926	.2241	.2075	.2614	.7167
18		.3239	.3018	.2218	.3018	.2218	.0457
19	.0076	.5335	.2058	.2263	.2667	.4435	.547
20	.0274	.9242	.2058	.0053	.0514	.3881	.7621
21	.0274	.0171	.1734	.0069	.0206	.0133	.0206
22	.0076	.0343	.1677	.0069	.0137	.0061	.0137
23	.0091	.0309	.1677	.0061	.0137	.0061	
24	.0076	.0091	.0069	.0335	.0061	.0122	.0061
Max	.0274	.9242	.5281	.7655	.3018	.679	.9149
Min	.0015	.0091	.0051	.0053	.003	.0061	.003
Avg	.0083	.1893	.1771	.1728	.1200	.1836	.2705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 203 / 11 KV YETGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3018	.2263	1.6766	2.1776	2.2291	.2263
2	.3395	.2263	.1886	1.6766	2.1365	2.2043	.1886
3	.3018	.2263	.1886	1.7436	2.1704	2.2891	.2263
4	.3018	.2641	.1886	1.8107	2.2291	2.3739	.2263
5	.3018	.3048	.2641	1.9448	2.2891	2.6282	.2263
6	.3429	.381	.3018	2.34	2.713	3.1708	.2829
7	.381	.5335	.3048	2.7808	3.4082	3.4591	.3018
8	.3395	.5281	.3239	3.0521	3.3065	3.3913	.3048
9		.4572	.3239	3.0521	3.3913	3.3234	.2641
10		.4572	.2667	.2286	.2477	.168	.2286
11	3.3913	3.3913	3.2895	.2263	.2667	.2614	3.1878
12	.2317	3.3913		.2641	.2263	.2641	
13	3.3913	3.4591		.2263	.2263	.2641	3.3913
14	3.2556	3.2895		.2263	.2452	.2641	3.546
15	3.1878	3.3404	3.4252	.2286	.2641	.2614	3.3913
16	3.3913	2.7808	2.3739	.2286	.2641	.3018	.4973
17	3.3913	3.3913	2.4417	.2286	.2452	.3018	
18	3.0521	3.0352	2.4417	.2858	.2402	.2987	3.4894
19	.381		.2241	.2263	.2641	.2987	.2641
20	.4572	.3018	.2263	.2667	.2452	.2987	.2641
21	.4572	.3048	.2241	.2641	.2641	.3018	.2641
22	.381	.2667	.2263	.2641	.2641	.2829	.2829
23	.381	.2667	.2263	.2263	.2263	.2614	.2641
24	.3395	.3018	.2452	1.6766	2.0233	2.1776	.2241
Max	3.3913	3.4591	3.4252	3.0521	3.4082	3.4591	3.546
Min	.2317	.2263	.1886	.2263	.2263	.168	.1886
Avg	1.2881	1.3566	.8534	1.0477	1.2223	1.2948	.9792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 204 / 11 KV SALSHINGE FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.7635	1.7804	.2926	.2587	.3048	1.6933
2	1.4918	1.8313	1.7804	.2587	.2587	.2858	1.6598
3	1.6244	1.8313	1.8652	.2195	.2587	.2858	1.643
4	2.2801	1.8313	2.0348	.2195	.2957	.3239	1.7436
5	2.8166	1.9669	2.3739	.3018	.3326		1.8275
6	3.152	2.5774	2.8826	.3772	.4435	.5093	2.2801
7	3.219	3.3913	3.2217	.4527	.4435	.4904	2.9675
8	3.1893	3.3913	3.0691	.4527	.4251	.4904	2.8837
9	2.8807	3.0521	2.9504	.4527	.3696	.4527	2.3777
10	.2195	.3772	.3018	.4527	.2957	.3772	.4066
11	.2263		.3395	2.7328	3.1161	2.8837	.4001
12	.3018	.4338	.3772	2.5987	3.12	2.9508	.1494
13	.2263	.4108	.3395	2.6322	2.6621	2.8502	.3584
14	.2263	.3734	.3395	2.6825	2.9843	2.8502	.3584
15	.2263	.3881			2.8147	2.8837	.3772
16	.2263	.3696		1.7269	3.0013	2.9843	.4338
17	.3772	.3439	.3292	1.7101	2.8656	2.6825	.5093
18	.3772	.4904	.3921	1.7436	2.9504	2.4366	.4527
19	.4481	.4715	.2926	.4066	.4715	.4066	
20	.4527	.4904	.2987	.4435	.5281	.4435	.3961
21	.3772	.4904	.3361	.4435	.4904	.4805	.4527
22	.3772	.415		.3696	.4527	.4805	.3881
23	.3018	.3772	.3361	.2957	.4024	.3881	.3361
24	1.4586	1.7635	1.6617	.2926	.2957	.3239	1.5424
Max	3.219	3.3913	3.2217	2.7328	3.12	2.9843	2.9675
Min	.2195	.3439	.2926	.2195	.2587	.2858	.1494
Avg	1.1654	1.2535	1.3001	.9373	1.2307	1.2420	1.1147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/STN

Feeder No / Name : 206 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3696	.3921	.3658	.3395	.3881	.2957
2	.3292	.3326	.3734	.3292	.3018	.3734	.2926
3	.3292	.3326	.3734	.3292	.2987	.3734	.2926
4	.3189	.3696	.4108	.3439	.3547	.4108	.3326
5	.3658	.4066	.4668	.362	.4108	.462	.4066
6	.4755	.6099	.5601	.4344	.5601	.5729	.5914
7	.6219	.5729	.5853	.5068	.5544	.5068	.462
8		.5249	.5373	.4784	.5194	.4784	.4163
9		.39	.5014	.4382	.5138	.4801	.462
10	.4801	.4641	.503	.4049	.4475	.4801	.4588
11	.4607		.4641	.4031	.4733	.5201	.4161
12	.3561	.3772	.3601	.3155	.4252	.4668	.4191
13	.3681	.3772	.3368	.3155	.3988	.4435	.3772
14	.3681	.4115	.2322	.4031	.4252	.4435	.3944
15	.3814	.4458	.2585	.4382	.4607	.4298	.3856
16	.3681	.4287	.2629	.4382	.4477	.4835	.4733
17	.3681	.4973	.3658	.4458	.5083	.4656	.431
18	.4191	.4588	.4321	.4372	.3898	.4656	.4049
19	.4784		.4784	.567	.567	.5914	.567
20	.5731	.6516	.4755	.6036	.6154	.5914	.6878
21	.5552	.6516	.4854	.5544	.5853	.5914	.6219
22	.4805	.5729		.5175	.5544	.547	.5487
23	.462	.4668	.4108	.4481	.4805	.4251	.4805
24	.4207	.4066	.4294	.3921	.415	.4251	.3696
Max	.6219	.6516	.5853	.6036	.6154	.5914	.6878
Min	.3189	.3326	.2322	.3155	.2987	.3734	.2926
Avg	.4232	.4599	.4215	.4280	.4603	.4757	.4412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 201 / 11 KV LENGARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1498	1.0802	1.2193	.0701	.0857	.0857	.9842
2	1.1305	1.0364	1.3435	.0526	.0857	.0943	1.0467
3	1.1305	1.0623	1.2803	.0537	.0686	.0876	1.0669
4	1.1174	1.0031	1.1873	.0537	.0686	.0709	1.0715
5	1.186	1.0031	1.2929	.0693	.0876	.0709	1.1443
6	1.4043	1.3717	1.3696	.0819	.1052	.0701	1.2041
7	1.8027	2.1032		.0926	.1052	.0857	1.5432
8	1.7711	1.9498			.1014	.0943	1.5935
9	1.7711	1.873		.1214	.1158	.0867	1.5779
10	.1107	.0995		1.5181	.1128	.0867	.1
11	.112	.096		1.866	1.9204	1.4815	.0633
12	.1174	.1029	.0293	2.0165	2.0881	1.7394	.0286
13	.1174	.12	.0301	2.0805	2.0309	2.0557	.0676
14	.1006	.1433	.0305	2.1125	1.7985	2.1445	.0705
15	.1017	.0762	.0255	2.119	1.8435	1.866	.1014
16	.1017	.081		1.9997	2.1214	1.5779	.1235
17	.1029	.0995		1.9685	1.7652	1.5935	.0937
18	.1029	.088	.1054	1.8673	1.6842	1.4148	.0974
19	.1029	.096	.124	.0655	.1134	.0914	.0949
20		.0781	.0983	.0819	.0972	.0762	.1017
21		.0762	.0983	.0983	.0819	.0829	.0983
22		.0772	.1017	.081	.0819	.0663	.1006
23		.0926	.0867	.081		.0714	.0829
24	1.1683	1.1069	1.1288	.0686	.0829	.0857	.9414
Max	1.8027	2.1032	1.3696	2.119	2.1214	2.1445	1.5935
Min	.1006	.0762	.0255	.0526	.0686	.0663	.0286
Avg	.7351	.6215	.5619	.8096	.7237	.6325	.5583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 202 / 11 KV VEJEGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.16	.2054	1.4563	1.6617	1.5242	.1187
2	.1334	.16	.168	1.4563	1.8313	1.5935	.1214
3	.1334	.1619	.1663	1.4074	1.7974	1.6129	.1357
4	.1334	.1619	.1886	1.4575	2.5095	1.6484	.156
5	.1524	.1677	.2263	1.543	2.7978	1.6842	.156
6	.1715	.1829	.2263	1.7703	2.8826	1.7204	.1715
7	.2452	.2006	.2058	2.5892	2.9165	3.1493	.1715
8	.2075	.2006	.2229	2.5819		3.0352	.1715
9	.2452	.1898	.1886	2.7949		3.1878	.2229
10	.2378	.1886	.2401	.2103		.1865	.2572
11	3.3265	3.1722	3.6456	.2103	.2263	.1543	2.915
12	4.0143	2.9673	3.4808	.1928	.2303	.1886	3.3436
13	3.514	3.2556	3.4122	.1791	.2353	.2058	3.3436
14	3.5305	3.6694	3.3951	.1791	.2126	.2401	3.3951
15	3.4736	3.0607	3.0007	.181	.2454	.2229	3.4155
16	3.4408	3.2322	2.8121	.2033	.2614	.2401	3.4155
17	3.3198	3.6117		.2218	.2507	.2401	3.4122
18	3.2769	3.1878	1.7974	.2218	.2241	.2743	2.7435
19	.3018	.2743	.2149	.2641	.2614	.2572	.2263
20		.2401	.2195	.2641	.2454	.1715	.2641
21		.2858	.1848	.2075		.1886	.2263
22		.2454	.1829	.1698		.1372	.2218
23		.2229	.208	.1509		.1543	.181
24	.1905	.2347	.2058	1.4582	1.6787	1.5242	.1372
Max	4.0143	3.6694	3.6456	2.7949	2.9165	3.1878	3.4155
Min	.1334	.16	.1663	.1509	.2126	.1372	.1187
Avg	1.5100	1.2264	1.0782	.8905	1.1371	.9809	1.2051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 203 / 11 KV SALSHINGE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0513	.8383	1.004	.1791	.197	.1791	1.2536
2	.9835	.787	1.0059	.1646	.2012	.181	1.3352
3	1.0056	.9061	1.0802	.1663	.2195	.2241	1.4045
4	1.0056	.9282	1.1523	.1663	.2195	.2241	1.4449
5	1.0442	.9231	1.2431	.1829	.2561	.2263	1.3904
6	1.1984	.9717	1.326	.1865	.2561	.2263	1.3763
7	1.6244	1.4419	1.4737	.2294	.2561	.2452	1.6461
8		1.4746	1.5524	.2214	.2454	.2401	1.6385
9	1.491	1.5074	1.3927	.216	.2279	.2629	1.6385
10	.213	.213	.192	1.3763	.2031	.2658	.1635
11	.1989	.1581	.1928	1.4091	1.491	1.6842	.1907
12	.218	.176	.1928	1.5074		1.7072	.1823
13		.1943	.1989	1.4746		1.7859	.1781
14	.2155	.1715	.213	1.3763		1.8138	.1823
15	.2012	.1928	.2056	1.4582		1.5249	.1658
16	.218	.2058	.1932	1.3927			.1658
17	.2374	.2058		1.3603		1.6741	.2241
18	.2035	.2107	.2401	1.3279		1.6741	.2774
19	.2713	.2374	.2204	.2683	.2572	.2279	.2804
20		.2279	.2401	.2515	.3547	.2279	
21		.2454	.2401	.2347	.2987	.2507	.2804
22		.2058	.2058	.2155	.2987	.2149	.2427
23		.208		.2155		.1907	.2229
24	1.0277	.9882	.9442	.1949	.197	.2263	1.1012
Max	1.6244	1.5074	1.5524	1.5074	1.491	1.8138	1.6461
Min	.1989	.1581	.192	.1646	.197	.1791	.1635
Avg	.6894	.5675	.6686	.6573	.3237	.6729	.7385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 204 / 11 KV LENGARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.2743	.2614	.3429	.3511	.3326	.3258
2	.3395	.2829	.2328	.3429	.3511	.3584	.3326
3	.3395	.3018	.2534	.3048	.3258	.3584	.3174
4	.3395	.3206	.2896	.3048	.3439	.3584	.3734
5	.3734	.3395	.3109	.3239	.362	.3961	.4024
6	.439	.3395	.3292	.3547	.3801	.3772	.4163
7	.4163	.3584	.362	.4163	.3982	.3772	.4075
8	.3189	.3734	.3467	.4119	.3601	.3772	.3506
9		.362	.3601	.3681	.3429	.362	.2229
10	.3772	.3506	.3429	.3681	.3277	.362	.3149
11	.3681	.2883	.443	.3506	.3467	.2572	.3429
12	.3506	.3086	.3189	.3582	.3429	.3429	.333
13	.3544	.2915	.3366	.3582	.3429	.2601	.3544
14	.3506	.3224	.3761	.3403	.3506	.3012	.3582
15	.3429	.3189	.3582	.3224	.3582	.3045	.3772
16	.2778	.3506	.2835	.333	.3506	.2629	.3366
17	.2812	.333		.3155	.3361	.2804	.2968
18	.2915	.3222	.4207	.3121	.3294	.3277	.3429
19	.3366	.4252	.5068	.3696	.4161	.4031	.4024
20		.4477	.5175	.4251	.4908	.4115	.5121
21		.4805	.4805	.462	.4382	.462	.4805
22		.439	.4755	.4251	.4382	.3439	.4024
23		.4066	.4854	.3881		.3696	.3921
24	.3734	.3658	.2772	.3772	.3511	.3696	.3403
Max	.439	.4805	.5175	.462	.4908	.462	.5121
Min	.2778	.2743	.2328	.3048	.3258	.2572	.2229
Avg	.3489	.3501	.3639	.3615	.3667	.3482	.3640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 205 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2263	.2195	.2195	.2743	.2452	.2353
2	.1905	.2263	.2172	.1848	.2561	.2452	.2218
3	.1905	.2075	.2033	.1848	.2454	.2263	.2033
4	.1905	.1886	.1848	.1867	.2629	.2263	.2614
5	.2075	.2263	.2743	.2033	.2804	.2263	.2743
6	.2614	.2641	.2926	.2172	.2743	.2263	.2896
7	.2614	.2829	.2835	.2865	.2743	.2263	.3142
8		.2896	.2772	.2865	.2804	.2263	.2378
9	.2865	.2896	.2686	.2481	.2629	.1949	.2195
10	.3045	.3109	.2126	.2561	.2629	.2686	.1907
11	.2686	.2715	.3224	.2378	.1886	.2172	.1829
12	.2149	.1848	.2896	.2587	.2804	.2328	.2458
13	.2353	.2587	.2926	.2402	.3012	.2149	.2321
14	.2561	.2686	.3109	.2218	.2658	.2303	.2347
15	.2587	.3077	.3109	.2218		.2534	.2401
16	.2801	.2507	.1734	.2507	.2303	.2353	.2572
17	.2926	.2804		.2686	.2658	.2507	.2601
18	.3142	.2486	.2454	.2865	.3189	.2401	.2629
19	.1867	.3366	.2926	.3077	.2328	.2957	.2835
20		.3258	.394	.3439	.3189	.3109	.3326
21		.3511	.3721	.362	.3189	.3547	.3475
22		.2743	.3439	.3475	.3258	.3142	.2957
23		.2987	.2926	.3109		.2987	.2743
24	.2667	.2772	.2452	.2507	.2743	.2452	.2801
Max	.3142	.3511	.394	.362	.3258	.3547	.3475
Min	.1867	.1848	.1734	.1848	.1886	.1949	.1829
Avg	.2471	.2686	.2747	.2576	.2725	.2502	.2574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 206 / 11 KV VEJEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3018	.2743	.2772	.3155	.3018	.2772
2	.2477	.2829	.2715	.2614	.3155	.3018	.2427
3	.2477	.2641	.2865	.2452	.3109		.2452
4	.2477	.2641	.2507	.2452	.3475		.2641
5	.2858	.2829	.3174	.2801	.3658	.3395	.2987
6	.3395		.3326	.2926	.3658	.362	.3077
7	.3366	.3018	.3403	.362	.3658	.3658	.3366
8			.3366	.394	.3582	.3506	.3155
9	.3403		.4239	.439	.3582	.362	.2572
10		.3077	.3163	.439	.3582	.362	.3612
11	.2743	.181	.3041	.4755	.394	.3521	.3605
12	.362	.4119	.3005	.439	.4525	.4424	.2486
13	.362	.394	.2688	.4066	.3982	.3429	.2374
14	.3326	.2774	.253	.3881	.3403	.2774	.2006
15	.2896	.3189	.3841	.3881	.4887	.4359	.2279
16	.3142	.3401	.2155	.3439	.5175	.4096	.2454
17	.3109	.3647		.3077	.4435	.4475	.2658
18	.3292	.3281	.3814	.2715	.4481	.4744	.2658
19	.439	.3681	.4163	.3326	.3734	.333	.4344
20		.3982	.394	.3696	.4481	.3801	.4656
21		.4207	.3898	.4251	.4294	.4207	.4298
22		.3841	.3761	.3681	.3961	.3142	.3982
23		.3511	.3475	.3506		.3326	.3582
24	.3048	.2926	.2957	.3077	.3155	.3018	.3109
Max	.439	.4207	.4239	.4755	.5175	.4744	.4656
Min	.2477	.181	.2155	.2452	.3109	.2774	.2006
Avg	.3128	.3255	.3251	.3504	.3872	.3641	.3065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV LENGRE S/STN

Feeder No / Name : 207 / 11KV KANDESARWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0566	.0543	.3944	.4999		.0549
2	.056	.0566	.0543	.39	.5937		.0362
3	.056	.0566	.0537	.3812	.5247		.0358
4	.056	.0566	.0358	.3978	.6173		.0358
5	.0554	.0566	.0351	.4409	.7407		.0526
6	.0549	.0566	.0351	.547	.8642		.0526
7	.0537	.0566	.0351	.7045	.9061		.0526
8		.0543	.0526	.6859	.8749	.6562	.0537
9	.0537	.0543	.0537	.6805	.9061	.7655	.0537
10	.0549	.0543	.0537	.0537	.0526	.0469	.0537
11	.6706	.7362	.7293	.0537	.0532	.048	.788
12	.7621	.6299	.7537	.0351		.048	.779
13	.7316	.8122	.7459	.0351		.0474	.7625
14	.703	.7459	.6718	.0351		.048	.7625
15	.7362	.6613	.6133	.0358		.064	.7956
16	.7042	.6554	.5601	.0537		.064	.7956
17	.6802	.547		.0716		.064	.779
18	.6554	.4915	.3521	.0716		.064	.4973
19	.0678	.0526		.0716	.0532	.048	.0716
20		.0543	.037	.0526	.0532	.048	.0543
21		.0724	.0549	.0526		.048	.0549
22		.0732	.0543	.0358	.056	.048	.0549
23		.0554	.0549	.0358		.048	.0549
24	.056	.0526	.0554	.4287	.4801	.4572	.0554
Max	.7621	.8122	.7537	.7045	.9061	.7655	.7956
Min	.0537	.0526	.0351	.0351	.0526	.0469	.0358
Avg	.3296	.2583	.2339	.2394	.4851	.1537	.2828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 201 / 11 KV TEXTILE PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3086	.3429	.3429	.4115	.3772	.5144
2	.5144	.2743	.3429	.3086	.4115	.3772	.5487
3	.583	.2915	.3086		.3429	.3944	.5487
4	.583	.2915	.2915	.3086	.3429	.4115	.5144
5	.5487	.2743	.2743	.3601	.3429	.4287	.5144
6	.5144	.3086	.3429	.3772	.3086	.4287	.4801
7	.4801	.2915	.3772	.3772	.3086	.4287	.4458
8	.3772	.4287	.3772	.5144	.3086	.4801	.4458
9	.3429	.6001	.5487	.5316	.5487	.5316	.6001
10	.2035	.6173	.6001	.4458	.5487	.583	.6001
11	.2058	.3944	.6001	.4458	.5658	.5658	.6344
12	.2743	.5658	.7202	.5144	.5487	.583	.5658
13	.3258	.583	.6859	.4458	.5487	.583	.5487
14	.3086	.4973	.6859	.4458	.5316	.6173	.583
15	.3086	.5144	.6516	.5487	.5316	.6173	.6001
16	.3086	.6344	.6516	.5144	.5487	.7202	.6173
17	.2915	.6173	.6516	.583	.5487	.7202	.583
18	.3258	.583	.4115	.5144	.5144	.7202	.5658
19	.1886	.5487	.3772	.3772	.5316	.6859	.5487
20	.2229	.5144	.3429	.3086	.5144	.6516	.5487
21	.3258	.3944	.3086	.3086	.3772	.6173	.5487
22	.3601	.3944	.3086	.3429	.3772	.6001	.5316
23	.3429	.3772	.3429	.3086	.3772	.6001	.5316
24	.583	.3086	.3772	.3429	.3772	.3772	.5144
Max	.583	.6344	.7202	.583	.5658	.7202	.6344
Min	.1886	.2743	.2743	.3086	.3086	.3772	.4458
Avg	.3764	.4422	.4551	.4160	.4487	.5458	.5473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 202 / 11 KV PARE FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1663	.1829	1.0936	.9614	1.0623	.1433
2	.1402	.1478	.1829	1.0494	.8848	1.078	.1097
3	.1791	.1663	.1463	1.0031	.9374	1.1069	.1086
4	.1734	.168	.1478	.9488	1.0242	1.1385	.1052
5	.1387	.2012	.1848	.9145	1.0494	1.1523	.1387
6	.1829	.2195	.2218	.9907	1.1843	1.2483	.1387
7	.1829	.2195	.2218	1.0155	1.3603	1.2803	.1417
8	.181	.2195	.2218	1.186	1.4746	1.4737	.1052
9	.1791	.2195	.1829	1.2483	1.6004	1.6194	.1372
10	.2172	.2172	.1829	.1372	.1696	.1753	.1387
11	1.7124	2.2348	1.3603	.1402	.1753	.1753	2.1136
12	2.1052	1.9433	2.0972	.1463	.1791	.2103	2.2283
13	1.9204	2.0729		.1433	.1791	.1075	2.3371
14	1.9433	1.9757	1.7814	.1417	.2149	.1052	2.2542
15	1.9433	1.9919	1.6604	.1402	.2149	.1372	2.2611
16	1.9595	1.9433	1.5623	.1372	.1791	.1402	2.1125
17	2.0081	1.7328	1.4575	.104	.1791	.1433	1.9524
18	1.9433	1.5384	1.1203	.1063	.1433	.1448	1.6004
19	.2149	.1829	.1372	.0724	.1433	.1433	.2012
20	.2218	.1829	.1417	.1086	.1433	.1052	.2218
21	.2402	.1829	.1433	.0716	.1829	.1387	.2507
22	.2218	.1829	.1753	.0701	.1829	.1075	.2614
23	.2218	.1829	.1715	.1052	.1829	.1448	.2229
24	.1463	.2033	.1829	1.0402	.9602	1.0623	.1029
Max	2.1052	2.2348	2.0972	1.2483	1.6004	1.6194	2.3371
Min	.1387	.1478	.1372	.0701	.1433	.1052	.1029
Avg	.7717	.7707	.6029	.5048	.5794	.5917	.8078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 203 / 11 KV WAZAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0883	1.1603	1.166	.0686	.0724	.1029	1.2407
2	1.1012	1.094	1.1843	.0716	.0701	.0686	1.2483
3	.8436	1.0608	1.2163	.0686	.0716	.0701	1.1523
4	.9282	1.1401	1.2643	.0732	.0693	.0701	1.0936
5	1.1984	1.2742	1.3441	.0701	.0716	.1075	1.1469
6	1.3927	1.4754	1.3927	.0732	.0716	.1791	1.2803
7	1.4403	1.4922	1.4251	.0716		.1075	1.4842
8	1.4746	1.6095	1.5402	.0716	.0701	.1075	1.7404
9	1.406	1.7101	1.7368	.0716	.0716	.1075	2.13
10			.0937	.0716	.0686	.1075	.0686
11	.1006	.08	.064	1.5746	2.2611	1.8842	.1267
12	.104	.0648	.0732	2.13	2.304	2.4531	.1433
13	.1017	.0648	.0701	2.0005	2.4531	2.2119	.1646
14	.1006	.0648	.0716	2.0309	2.3205	1.6804	.1433
15	.081	.0655	.0732	1.8747	2.2874	1.8623	.1417
16	.0838	.0671		1.8023	2.0885	2.13	.1612
17	.1052	.0671	.0701	1.8652	1.7859	2.1052	.1772
18	.1052	.0671	.0686	1.3927	1.6385	1.6404	.1448
19	.104	.1029	.0724	.0716	.1029	.0686	.1463
20	.1052	.1029	.0724	.0716	.1433	.0716	.1448
21	.0895	.1402	.0724	.0732	.1753	.0732	.1433
22	.1075	.1402	.0716	.0724	.1402	.0701	.1063
23	.1075	.1402	.1029	.0716	.1372	.0686	.1097
24	1.0526	1.1934	1.166	.0716	.0724	.1029	1.3927
Max	1.4746	1.7101	1.7368	2.13	2.4531	2.4531	2.13
Min	.081	.0648	.064	.0686	.0686	.0686	.0686
Avg	.5749	.6251	.6266	.6589	.8064	.7271	.6596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV MIDC KARVE S/STN

Feeder No / Name : 204 / TEXTILE NO. 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.0762		.0762	.0762	.1143	
2	.2096	.0762		.0762	.0762	.1524	
3	.1905	.0762		.0762	.0762	.1524	
4		.0762		.0762	.0762	.1905	
5	.1905	.0762		.0762	.0762	.1905	
6	.1905	.0762		.0762	.0762	.1905	
7	.1905	.0762				.2286	
8		.0762			.0762	.2286	
9		.1143		.0762	.0762	.2286	
10	.1143		.1143	.1524	.0762	.2286	.1715
11	.1143		.1524	.1524	.0762	.3429	.2096
12	.0953	.1715	.1334		.0762	.3429	.1715
13	.0762	.1715	.1143		.0762	.3048	.1905
14	.0953	.1334	.1334		.1905	.4191	.1715
15	.0953	.1334	.1334	.1334	.1905	.381	.1715
16	.1143	.1905	.1334	.1334	.1905	.381	.1715
17	.1143	.1334	.1334	.1905	.1524	.3429	.1334
18	.1143		.0762	.1905	.1905	.3429	.0953
19	.0762		.0762	.1524	.1524	.3048	.1143
20	.0762	.1334	.0762	.0762	.1143		.1334
21	.0762		.0762	.0953	.1905		.1715
22	.0762		.0762	.1143	.1905		.2477
23	.0762		.0762	.0762	.1143		.2667
24	.2096	.0762		.0762	.0762	.1143	
Max	.2096	.1905	.1524	.1905	.1905	.4191	.2667
Min	.0762	.0762	.0762	.0762	.0762	.1143	.0953
Avg	.1279	.1098	.1075	.1093	.1160	.2591	.1729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 201 / Yashodhan Garment

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3239	.3018	.3206	.3018	.3018	.3239
2	.3048	.3048	.3018	.3206	.3018	.3018	.3048
3	.3048	.3048	.3018	.3018	.3018	.3018	.3048
4	.3048	.3018	.3018	.3018	.3018	.3018	.3239
5	.3048	.3018	.3206	.2987	.3018	.2801	.3239
6	.3239	.3018	.3206	.2987	.3018	.2801	.3048
7	.3239	.3018	.3206	.2987	.3018	.2957	.3048
8	.2477	.3429	.3018	.2987	.3018	.2987	.3048
9	.1905	.3429	.3395	.3206	.3395	.3018	.3429
10	.2103	.362	.3395	.3429	.3584	.3429	.3395
11	.2286	.3772	.3584	.3395	.3772	.4191	.4001
12	.2096	.3395	.3584	.3584	.3584	.381	.3961
13	.2096	.3395	.381	.3584	.3584	.381	.3584
14	.1905	.3395	.381	.3206	.4191	.4001	.3584
15	.1905	.3395	.4001	.3395	.4001	.381	.381
16	.1905	.3395	.381	.3206	.4001	.362	.4001
17	.1905	.3584	.362	.3395	.4001	.362	.415
18	.2477	.3584	.3584	.3584	.381	.381	.381
19	.2667	.3395	.3395	.3018	.3584	.3547	.3395
20	.2667	.3206	.3206	.3206	.3174	.3395	.3174
21	.3239	.3206	.3206	.3395	.3206	.3429	.2534
22	.3206	.3206	.3206	.3206	.3206	.3239	.2641
23	.3018	.3395	.3206	.3018	.3206	.2926	.2641
24	.3048	.3239	.3018	.3206	.3018	.3206	.3239
Max	.3239	.3772	.4001	.3584	.4191	.4191	.415
Min	.1905	.3018	.3018	.2987	.3018	.2801	.2534
Avg	.2609	.3310	.3356	.3226	.3394	.3353	.3346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 202 / GHANWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5441	.5426	.4858	.1097	.1402	.0943	.5258
2	.5556	.5426	.4858	.1097	.1402	.0905	.5182
3	.6009	.5426	.4858	.0914	.1402	.0895	.5571
4	.6097	.6203	.5182	.0914	.1402	.0895	.6859
5	.7042	.7042	.6478	.1086	.1612	.1132	.7042
6	.8749	.7293	.7773	.1267	.1612	.132	.9175
7	.9804	.9724	.9602	.1448	.1612	.1494	1.1174
8	1.0486	1.1065	.9831	.128	.1612	.1307	1.1069
9	1.012	1.0059	.8848	.1097	.1433	.1097	1.1904
10	.0553	.0754	.0895	.1109	.1402	.1063	.0876
11	.1109	.112	.1097		1.0526	1.0202	.1294
12	.1109	.1109	.1307		1.0883	1.1336	.112
13	.1109	.1109	.1524		1.1174	1.1203	.112
14	.1109	.1097	.1524		1.1797	1.1401	.1063
15	.1109	.1097	.1509		1.1797	1.1069	.1086
16	.1109	.1097	.1494	.5668	1.1336	1.1012	.1227
17	.1307	.1254	.1478	.663	1.004	1.1142	.1494
18	.1494	.1254	.128	1.1088	1.0526	1.1568	.1417
19	.1478	.1402	.1267	.1543	.128	.1158	.1463
20	.1646	.1402	.1267	.1387	.1307	.1235	.168
21	.1646	.1612	.1267	.1463	.128	.1269	.168
22	.1478	.1433	.1463	.1646	.1307	.1334	.1494
23	.1478	.1433	.1463	.1612	.1132	.1128	.1494
24	.4321	.5087	.4915	.128	.1578	.1132	.4801
Max	1.0486	1.1065	.9831	1.1088	1.1797	1.1568	1.1904
Min	.0553	.0754	.0895	.0914	.1132	.0895	.0876
Avg	.3807	.3747	.3585	.2296	.4619	.4468	.4023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI S/STN

Feeder No / Name : 203 / GHANWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5228	.4458	.5175	.4557	.462	.4298
2	.4525	.4854	.4458	.4805	.4557	.4755	.439
3	.4656	.4854	.4458	.4854	.4557	.4525	.4458
4	.4784	.4854	.5144	.4854	.4557	.4572	.4656
5	.5258	.6036	.631	.5544	.4557	.5359	.5609
6	.5973	.7167	.6859	.6219	.5258	.6767	.6584
7	.6838	.7316	.6516	.6878	.6661	.7265	.703
8	.6661	.6024	.6135	.703	.703	.6859	.7011
9	.6539	.5784	.5765	.7209	.703	.6299	.6516
10	.583	.6836	.6173	.5967	.6443	.6562	.5079
11	.6001	.5801	.6068	.5596	.7116	.6154	.6516
12	.6001	.5487	.6068	.6443	.6554	.6371	.6415
13	.583	.5784	.5959	.5658	.6274	.5601	.5335
14	.583	.5658	.6024	.5596	.6344	.547	.5258
15	.583	.6001	.6241	.6068	.6001	.5601	.5375
16	.5658	.6859	.703	.6516	.6203	.6344	.583
17	.5487	.6516	.6935	.5868	.547	.631	.5256
18	.5487	.583	.7011	.6379	.5487	.5571	.6203
19		.8238	.7442	.6556	.6001	.6706	.7087
20	.8326	.7164	.7783	.815	.7522	.788	.8145
21	.8048	.7164	.7316	.7762	.788	.7499	.7783
22	.695	.6661	.6584	.7059	.724	.6838	.6878
23	.5914	.583	.567	.5658	.567	.6401	.5973
24	.5138	.5228	.4801	.5175	.4801	.5121	.4572
Max	.8326	.8238	.7783	.815	.788	.788	.8145
Min	.4525	.4854	.4458	.4805	.4557	.4525	.4298
Avg	.5919	.6132	.6134	.6126	.5990	.6060	.5927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 201 / 11 KV PARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4251	.4382	.4954	.3696	.4572	.439	.4572
2	.4251	.4191	.4572	.3696	.4191	.4481	.4572
3	.4191	.4191	.4572	.3361	.4191	.4108	.4382
4	.4191	.4191	.4572	.3174	.4294	.3841	.4382
5	.4572	.4207	.4854	.3174	.4715	.3761	.4382
6	.4805	.4481	.5121	.3326	.5281	.4207	.4763
7	.4706	.462	.5068	.3326	.4477	.4656	.5228
8	.5068	.5093	.5068	.3801	.4784	.362	.4805
9	.4706	.462	.5121	.362	.4656	.3856	.4938
10	.4572	.4572	.543	.4572	.3841	.4191	.4755
11	.4066	.4344	.5014	.4527	.3658	.4572	.4755
12	.3761	.4344	.4706	.499	.381	.4706	.4251
13	.394	.4344	.4525	.5415	.4001	.4477	.439
14	.4207	.4024	.4525	.5359	.4001	.439	.3982
15	.4344	.4163		.5359	.4001	.2481	.3982
16	.4298	.4344		.4572	.4001	.3224	.4207
17	.4706	.4344	.4066	.4715	.4001	.3439	.4066
18	.4334	.4755		.4954	.4191	.5304	.3696
19	.5093	.5249	.4835	.5335	.4954	.6036	.439
20	.6722	.6722	.6219	.6859	.6478	.6838	.6733
21	.6154	.679	.567	.6478	.6287	.7468	.6379
22	.5853	.5975	.499	.5716	.5335	.6036	.6154
23	.5544	.5601	.4668	.5144	.4572	.5716	.5304
24	.4572	.4954	.5281		.4715	.4572	.4763
Max	.6722	.679	.6219	.6859	.6478	.7468	.6733
Min	.3761	.4024	.4066	.3174	.3658	.2481	.3696
Avg	.4704	.4771	.4944	.4573	.4542	.4599	.4743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 202 / 11 KV PARE AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.0572	.3637	.4062	.4475	.0572
2	.0381	.0381	.0572	.3321	.4012	.4321	.0572
3	.0381	.0381	.0572	.3321	.3858	.4321	.0572
4	.0381	.0572	.0572	.3163	.4012	.4321	.0572
5	.0381	.0572	.0572	.3479	.4687	.4268	.0572
6	.0572	.0762	.0572	.3795	.6019	.6019	.0572
7	.0572	.0953	.0762	.5864	.9842	.945	.0572
8	.0572	.0762	.0762	.5864	1.034	.7253	.0572
9	.0953	.0572	.0572	.5312	1.1092	.8688	.0572
10	.0762	.0572	.0953	.0953	.0762	.0762	.0762
11	.9374	.945	.9722	.0762	.0762	.0762	1.1584
12	.9568	.9686	.9877	.0762	.0762	.0762	1.2041
13	.4954	.9877	.9259	.0762	.0762	.0762	1.142
14	.7407	.8333	.828	.0762	.0762	.0762	1.142
15	.8025	.9259		.0762	.0762	.0762	1.142
16	.8488	.945	.7968	.0572	.0762	.0572	1.1717
17	.8749	.9145	.8436	.0572	.0762	.0762	1.2029
18	.8749	.8535	.4161	.0762	.0762	.0762	1.0279
19	.0953	.0572	.0572	.0953	.0953	.0762	.0762
20	.0953	.0572	.0572	.0953	.0953	.0762	.0762
21	.0762	.0572	.0572	.0953	.0953	.0572	.0762
22	.0762	.0572	.0572	.0762	.0762	.0572	.0762
23	.0572	.0572	.0572	.0762	.0762	.0572	.0762
24	.0572	.0572	.0572		.4531	.4475	.0572
Max	.9568	.9877	.9877	.5864	1.1092	.945	1.2041
Min	.0381	.0381	.0572	.0572	.0762	.0572	.0572
Avg	.3142	.3461	.2940	.2122	.3071	.2812	.4258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV PARE S/STN

Feeder No / Name : 203 / 11 KV GHOTI (BK) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1715	.3953	.3086	.3906	.1524
2	.1524	.1524	.1524	.3637	.2932	.3281	.1334
3	.1334	.1334	.1524	.3637	.3125	.3321	.1334
4	.1334	.1334	.1524	.3479	.3593	.3321	.1334
5	.1334	.1334	.1715	.3637	.4167	.3281	.1524
6	.1524	.1524	.1905	.3953	.5155	.463	.1715
7	.1905	.1905	.1905	.5247	.7343	.6481	.2096
8	.1905	.1524	.1905	.6019	.7407	.5247	.1715
9	.2096	.1334	.1715	.5155	.6944	.5944	
10	.1905	.1334	.1524	.1905	.1524	.1524	
11	.7716	.8025	.7748		.1524	.1524	
12	.8488	.8025	.7116	.1715	.1524	.1715	1.0957
13	.7499	.8025	.6958	.1715	.1334	.1524	.9998
14	.7186	.7407	.68	.1905	.1334	.1524	.8905
15	.7186	.6481		.1524	.1334	.1524	.8124
16	.7099	.6019	.6167	.1524	.1334	.1715	.9061
17	.7253	.6859	.6958	.1524	.1524	.1715	.9061
18	.7253	.7253	.4321	.1715	.1524	.1905	.8802
19	.2096	.1905	.2096	.2286	.2096	.2286	.2286
20	.3048	.2477	.2477	.2858	.2477	.2667	.2667
21	.2858	.2477	.2286	.2667	.2477	.2667	.2667
22	.2477	.2286	.2096	.2096	.2096	.2477	.2477
23	.2096	.1905	.1715	.1715	.1715	.1715	.1905
24	.1715	.1715	.1905		.3395	.4218	.1524
Max	.8488	.8025	.7748	.6019	.7407	.6481	1.0957
Min	.1334	.1334	.1524	.1524	.1334	.1524	.1334
Avg	.3773	.3564	.3287	.2903	.2957	.2921	.4334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 KV VITA NEW S/STN

Feeder No / Name : 201 / 11 KV Harewadi URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.583	.5801	.6001	.6783	.6001
2	.6371	.6415	.5596	.5636	.6001	.6687	.6001
3	.6274	.6135	.5365	.5596	.5765	.6344	.6001
4	.6415	.5784	.5658	.503	.5765	.6104	
5	.6344	.5609	.5935	.4973	.6783	.6274	.6001
6	.6443	.5609	.6706	.5533	.788	.6874	.6203
7	.8215	.8048	.7537	.7202	.8122	.779	.788
8	.8288	.8886	.8192	.7968	.7865	.8383	.8785
9	.8029	.9503	.9779	.8162	.7935	.852	.9448
10	.8192	.9667	1.0277	.8097	.8162	.8684	.8962
11	.8718	.9892	1.0486	.8551	.9221	.8648	.9667
12	.8122	.9448	.9945	.9389	.9779	.9448	.9448
13	.7935	.8097	.9012	.8951	.9448	1.0004	.9175
14		.8029	.8619	.8718	.9448	.9326	.9282
15	.7459	.6882	.8097	.8097	.9945		.8097
16	.7956	.7625	.8002	.7682	.9667	.9835	.8583
17	.8097	.852	.8097	.8684	1.065	1.0059	.852
18	.8583	1.065		.9175	.9175	.9389	.8259
19	.8192	.8951	.6133	.8453	.8583	.8785	.7956
20	.763	.8573	.5935	.788	.8192	.7956	.7956
21	.7461	.8048	.57	.7377	.8122	.7377	.7701
22	.763	.763	.5596	.6962	.7956	.7373	.7712
23	.7291	.703	.5658	.6706	.7545	.6859	.7545
24	.7202	.7202	.6344	.583	.6173	.7042	.6344
Max	.8718	1.065	1.0486	.9389	1.065	1.0059	.9667
Min	.6274	.5609	.5365	.4973	.5765	.6104	.6001
Avg	.7552	.7879	.7326	.7352	.8091	.8024	.7892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 KV VITA NEW S/STN

Feeder No / Name : 203 / 11 K V NEWARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.0943		.1067		.0754
2	.0953	.0943	.0943		.108		.0762
3	.0953	.0943	.0754		.125		.0762
4	.0953	.0943	.0943		.1265		.0762
5	.1143	.0943	.0943		.16		.0762
6	.1143	.1132	.1132		.1718		.0762
7	.132	.132	.1509		.3241		.0953
8	.1132	.132	.132		.2846		.0953
9	.1132	.1132	.1132		.2656		.0953
10	.0934	.1132	.0943		.1334	.0943	.0754
11	.3906	.3077	.3277		.0943	.1132	.4001
12	.3963	.3593	.3481	.0754	.0754	.0754	.2915
13	.3658	.3549	.3521	.0754	.0943	.1132	.2721
14	.7773	.3593	.3239	.0943	.0943	.0754	.253
15	.3395	.3125	.2721	.0943	.0754	.0754	.2968
16	.3163	.3725	.2753	.0754	.0943	.0754	.2812
17		.3201	.2984	.0754	.1132	.0754	.2688
18	.2559	.2623	.16	.0754	.1132	.0754	.2743
19	.1132	.132	.1132	.0953	.1132	.1132	.0943
20	.1509	.1509	.0943	.0953	.1509	.1132	.0943
21	.132	.132	.1132	.1143	.1509	.1132	.1132
22	.132	.132	.0943	.1143	.132	.1132	.132
23	.1132	.1132	.0943	.1143	.0943	.0943	.1132
24	.1132	.1132	.1132	.125	.1094		.0943
Max	.7773	.3725	.3521	.125	.3241	.1132	.4001
Min	.0934	.0943	.0754	.0754	.0754	.0754	.0754
Avg	.2033	.1882	.1682	.0942	.1380	.0943	.1582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 201 / 11 KV Shelakbav Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2926	.2926	.2957	.2957	.2427	.2957
2	.2957	.2743	.2715	.2926	.2772	.2587	.3292
3	.2743	.2743	.3258	.2743	.2743	.2743	.3292
4	.2743	.3142	.3658	.2715	.3109	.3224	.3142
5	.2896	.3696	.4024	.2896	.3475	.3439	.3292
6	.2715	.4024	.4207	.3045	.4251		.3475
7	.2715	.4163	.3982	.3012	.3988		.3439
8		.3077	.3721	.2835	.3045	.2865	.3224
9	.2947	.3544	.4075	.298	.3189	.3366	.3155
10	.2947	.3294	.3814	.2743	.3294	.2804	.3429
11	.2774	.3189	.3544	.2686	.3506	.2835	.4161
12	.2947	.333	.333		.3155	.2835	.3814
13	.298	.3121	.2835		.2804	.2629	.3258
14	.2804	.2835	.2835	.3582	.2835	.2507	.3155
15	.2658	.3045	.3012	.3224	.2865	.2507	.3189
16	.298	.298	.3012	.3189	.2835	.2481	.3467
17	.3121	.3189	.2804	.3121	.2804	.2774	.3544
18	.3641	.3467	.3012	.3681	.3012	.2835	.3506
19	.3582	.4252	.3544	.4075	.3439	.3403	
20	.4525	.4163	.3801	.4572	.362	.3801	.4344
21	.4163	.4207	.3658	.3841	.3881	.3658	.4572
22	.3696	.4024	.3511	.3696	.3361	.3292	.4066
23	.3511	.3658	.3142	.3326	.2987	.3142	.3511
24		.3109	.3109	.2957	.3142	.2801	.2957
Max	.4525	.4252	.4207	.4572	.4251	.3801	.4572
Min	.2658	.2743	.2715	.2686	.2743	.2427	.2957
Avg	.3136	.3413	.3397	.3218	.3211	.2953	.3489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 202 / 11 KV Dhawaleshawar AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2427	.1848	.1829	.9061	.7407	.787
2	.2195	.2427	.1848	.1829	.9488	.7811	.7926
3	.2012	.2195	.2012	.1991	.9962	.8381	.8333
4	.2012	.2402	.2172	.1991	1.0911	.9488	.8688
5	.1991	.2534	.2378	.2126	1.186	1.1092	.9568
6	.2172	.2534	.2587	.2126	1.2963	1.1574	1.0623
7	.2328	.2587	.2481	.2279	1.5655	1.2651	1.0957
8	.2303	.2743	.2534	.2254	1.692	1.4232	1.4232
9	.2328	.2774	.1848	.1907	1.6164	1.2334	1.5181
10	.2126	.2772	.2507	.2254	.1753	.2149	.2155
11	1.6804	1.6194	1.6964	.2126	.2378	.2172	1.439
12	1.7814	1.7166	1.9685	.2507	.2172	.2172	1.439
13	1.5497	1.7976	1.8084	.2328	.2149	.2561	1.4548
14	1.6164	1.668	1.3757	.2454	.2353	.0554	1.439
15	1.656	1.5524	.9804	.2658	.2353	.0554	1.4232
16	1.5154	1.5546	1.1873	.2454	.2126	.0554	1.4074
17	1.7029	1.4706	1.5971	.2035	.2126	.2328	1.186
18	1.7394	1.3748	1.4089	.208	.2126	.2743	.9568
19	.2103	.2534	.1949	.2427	.2328	.2926	
20	.2195	.2957	.197	.2481	.2353	.3077	.2172
21	.2402	.2772	.2012	.2481	.2378	.2743	.2195
22	.2427	.2614	.2012	.2172	.2378	.2534	.2402
23	.2427	.2402	.1629	.181	.197	.2328	.1991
24		.2427	.2033	.1829	.8749	.679	.787
Max	1.7814	1.7976	1.9685	.2658	1.692	1.4232	1.5181
Min	.1991	.2195	.1629	.181	.1753	.0554	.1991
Avg	.7202	.7027	.6419	.2185	.6362	.5465	.9548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-MAY-18 and 14-MAY-18

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 203 / 11 KV Shelakbav AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-18	09-MAY-18	10-MAY-18	11-MAY-18	12-MAY-18	13-MAY-18	14-MAY-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8785	1.7236	1.5971	1.3748	.1791	.1753	.1928
2	1.9433	1.7553	1.6091	1.4217	.1791	.1928	.1772
3	2.0081	.216	1.6667	1.4706	.181	.1949	.1772
4	2.0485	1.7966	1.7341	1.5181	.1829	.2328	.197
5	2.1765	1.8056	1.7869	1.531	.2218	.2172	.2353
6		1.7985	1.7966	1.5971	.2402	.2507	.2715
7	2.2405	2.1348	2.0005	1.6091	.2481	.2658	.2686
8	2.332	2.2245	2.2245	1.6358	.2507	.2481	.2896
9	2.2405	2.1445	2.1032	1.7966	.2507	.2328	.2865
10	.1475	.1823	.2058	.1475	.2629	.2204	.2686
11	.1928	.2454	.2126	1.8027	2.1052	2.1862	.3155
12	.2303	.2715	.2254	1.9364	2.2186	2.1925	.298
13	.2481	.2774	.3012	1.9524	2.3045	2.1822	.2774
14	.2481	.298		1.7553	2.2996	2.3845	.2658
15	.2686	.3012	.2774	1.8501	2.2834	2.2725	.2507
16	.2658	.2835	.2229	1.8818	2.3482	2.3205	
17	.2507	.3189	.1865	1.9766	2.1285	2.2245	.2835
18	.2804	.333	.1696	1.9766	1.9826	1.9919	.3121
19	.3189	.3403	.1949	.2218	.2254	.2629	
20	.3077	.3292	.1949	.2353	.2279	.3045	.2715
21	.3077	.3258	.2126	.2172	.2481	.2715	.2481
22	.2507	.2896	.2303	.2012	.2279	.2328	.2149
23	.2507	.2658	.2328	.181	.2103	.197	.1791
24		1.692	1.5813	1.3435	.1791	.1928	.1928
Max	2.332	2.2245	2.2245	1.9766	2.3482	2.3845	.3155
Min	.1475	.1823	.1696	.1475	.1791	.1753	.1772
Avg	.9289	.8897	.9116	1.3181	.8827	.8936	.2488